

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

**AP-42 Section Number:** 9.9.4

**Reference Number:** 9

**Title:** Source Emissions Report for Shofstall  
Alfalfa, Alfalfa Dehydrating Facility,  
Odessa, NE

AirSource Technologies

AirSource Technologies

October 1993

PLANT #2

**SOURCE EMISSIONS REPORT**  
for  
**SHOFSTALL ALFALFA**  
**Alfalfa Dehydration Facility**  
**Odessa, Nebraska**

prepared by  
**AirSource Technologies**

**11635 W. 83rd Terrace**  
**Lenexa, Kansas 66214**

**AirSource Project No. 411922**

## PREFACE

This report was prepared by AirSource Technologies in response to a test that was conducted at the Shofstall Alfalfa Facility in Odessa, Nebraska on September 2, 1993. Any questions concerning this report should be directed to Mr. Blane Wood, Project Manager, or to Mr. George Cobb, General Manager.

AirSource Technologies



Blane Wood  
Project Manager

Approved



George R. Cobb  
General Manager

Date: October 15, 1993

## **SECTION 1**

### **INTRODUCTION**

A stack test was conducted by AirSource Technologies on the Shofstall Alfalfa, alfalfa dehydration plant in Odessa, Nebraska on September 2, 1993.

The AirSource Technologies personnel who conducted the test were: Mr. Blane Wood, Project Manager and Mr. Tim Titus, Environmental Scientist.

The results of the test were used to evaluate the process' performance with regards to the particulate emission rate.

The appendices contain the following:

|             |                               |
|-------------|-------------------------------|
| Appendix A: | Example Calculations          |
| Appendix B: | Computer Forms                |
| Appendix C: | Particulate Field Data Forms  |
| Appendix D: | Laboratory and Analysis Forms |
| Appendix E: | Pretest Calibrations          |
| Appendix F: | Posttest Calibrations         |
| Appendix G: | Process Data                  |

## **SECTION 2**

### **SUMMARY OF RESULTS**

The results of the particulate emissions are: 46.21 lb.hr, 36.26 lb/hr, and 29.93 lb/hr for Runs 1, 2 and 3 respectively.

The sampling and particulate results are shown in Table 1.

**Table 1**  
**SUMMARY OF SAMPLING AND PARTICULATE RESULTS**  
**Shofstall Alfalfa**  
**Odessa, Nebraska**

| Parameters                     | Unit of Measure         | Run 1  | Run 2  | Run 3  |
|--------------------------------|-------------------------|--------|--------|--------|
| Particulate Emissions          |                         |        |        |        |
| Front Half                     | gr/dscf                 | 0.1091 | 0.0877 | 0.0739 |
| Uncorrected                    | gr/dscf                 | 0.4362 | 0.3071 | 0.2586 |
| Corrected to 7% O <sub>2</sub> | gr/dscf                 | 0.8725 | 0.7018 | 0.5910 |
| Emission Rate                  | lb/hr                   | 46.21  | 36.26  | 29.93  |
| Weight                         | grams                   | 0.2680 | 0.2135 | 0.1788 |
| Isokinetics                    | %                       | 91.7   | 93.1   | 94.5   |
| Stack Flow Rate                |                         |        |        |        |
| Actual                         | acfm                    | 77,333 | 78,339 | 79,515 |
| Standard Conditions            | dscfm                   | 49,442 | 48,234 | 47,277 |
| Velocity                       | ft/min.                 | 6,154  | 6,234  | 6,328  |
| Sampling Results               |                         |        |        |        |
| Sampling Volume                | dscf                    | 37.841 | 37.478 | 37.278 |
| Avg. Stack Temperature         | °F                      | 178    | 190    | 202    |
| Avg. ΔP                        | inches H <sub>2</sub> O | 2.413  | 2.413  | 2.429  |
| Avg. ΔH                        | inches H <sub>2</sub> O | 1.4    | 1.39   | 1.39   |
| Avg. Meter Temperature         | °F                      | 69     | 72     | 79     |
| Oxygen, Orsat                  | %                       | 17.5   | 17.0   | 17.0   |
| Carbon Dioxide, Orsat          | %                       | 1.5    | 1.5    | 1.5    |
| Static Pressure                | inches H <sub>2</sub> O | 0.85   | 0.85   | 0.85   |
| Moisture Collected             | ml                      | 164.5  | 180.9  | 197.5  |
| Moisture                       | % H <sub>2</sub> O      | 17.0   | 18.5   | 20.0   |
| Sampling Time                  | min.                    | 60     | 60     | 60     |

### **SECTION 3**

#### **PROCESS OPERATION**

The alfalfa dehydration plant operates a Heil 105 triple pass dryer. The control equipment used are a 2-Kire CK-126 cyclone and a single compartment baghouse. The condition for each of the test runs were the same.

Table 2 summarizes the results of the process operations and Table 3 provides process data collected during the tests.

**Table 2**  
**SUMMARY OF RESULTS**  
**Process Data**

|                                                    |                        |
|----------------------------------------------------|------------------------|
| Historical Average Process Weight (@ 30% moisture) | 26,000 lb/hr           |
| Historical Maximum Process Weight (@ 30% moisture) | 32,000 lb/hr           |
| Type of Fuel Normally Burned                       | Natural Gas            |
| Approximate Quantity of Fuel Burned Annually       | 27,000 MCF             |
| Baghouse - Positive pressure                       |                        |
| Number of Bags                                     | 144                    |
| Clean Cycle                                        | 3 minutes              |
| Fan Rated H.P.                                     | 100 H.P.               |
| Cyclone - 2-Kire CK-126                            |                        |
| Diameter                                           | 10.5 ft.               |
| $\Delta P$                                         | 3 in. H <sub>2</sub> O |
| Fan Rated H.P.                                     | 125                    |



**Table 3**  
**PROCESS DATA**

|       | <b>Gresen Hay<br/>Moisture<br/>%</b> | <b>Scale Reading<br/><br/>Tons</b> | <b>Pellet Moisture<br/><br/>%</b> |
|-------|--------------------------------------|------------------------------------|-----------------------------------|
| 08:30 | -                                    | -                                  | 33                                |
| 08:45 | 8.0                                  | 2                                  | 34                                |
| 09:15 | 7.8                                  | 1.5                                | -                                 |
| 09:30 | 7.8                                  | 1.7                                | -                                 |
| 9:45  | 7.5                                  | 1.7                                | -                                 |
| 10:00 | 7.4                                  | 1.8                                | 33                                |
| 10:15 | 7.5                                  | 1.9                                | -                                 |
| 10:30 | 7.3                                  | 2.1                                | -                                 |
| 10:45 | 7.2                                  | 2.1                                | -                                 |
| 11:00 | 7.0                                  | 2.2                                | 35                                |
| 11:15 | 7.1                                  | 1.9                                | -                                 |
| 11:30 | 7.0                                  | 2.2                                | -                                 |
| 11:45 | 7.3                                  | 2.0                                | -                                 |
| 12:00 | 7.5                                  | 2.2                                | 33                                |
| 12:15 | 7.0                                  | 2.0                                | -                                 |
| 12:30 | 7.0                                  | 2.4                                | -                                 |
| 12:45 | 7.1                                  | 2.3                                | -                                 |
| 13:00 | 7.3                                  | 2.3                                | 33                                |

## SECTION 4


### SAMPLING AND ANALYTICAL PROCEDURES

#### Particulates

EPA Methods 1-4 were used for the determination of traverse point locations, velocities and flows of stack gas, oxygen, carbon dioxide, and moisture. The particulate sampling and recovery of the samples were done according to EPA Method 5 recovery procedures.

Figure 1 shows a schematic of the sampling train.

Figure 2 shows a schematic of the stack and traverse locations.



Schematic of Method 5 sampling train.

Figure 1

**Stack dimensions - Shofstall Alfalfa**


Inside diameter 48"

Port length 4"

**Sampling Port Location**

3 Diameters upstream from disturbance

2 Diameters downstream from disturbance



**Traverse Point Locations  
(Excluding Port Length)**

|    |       |     |       |
|----|-------|-----|-------|
| 1. | 1.0"  | 7.  | 30.9" |
| 2. | 3.2"  | 8.  | 36"   |
| 3. | 5.7"  | 9.  | 39.5" |
| 4. | 8.5"  | 10. | 42.3" |
| 5. | 12.0" | 11. | 44.8" |
| 6. | 17.1" | 12. | 47"   |

Figure 2

**APPENDIX A**

**EXAMPLE CALCULATIONS**

## NOMENCLATURE

| <u>Equation<br/>No.</u> | <u>Symbol</u>      | <u>Description</u>                                                        | <u>Units</u>         |
|-------------------------|--------------------|---------------------------------------------------------------------------|----------------------|
| 1                       | Vi                 | Initial meter reading                                                     | dcf                  |
|                         | Vf                 | Final meter reading                                                       | dcf                  |
|                         | Vm                 | Volume meter, actual                                                      | dcf                  |
| 2                       | Pb                 | Barometric pressure                                                       | in. Hg               |
|                         | $\Delta H_{avg}$   | Average orifice pressure drop                                             | in. H <sub>2</sub> O |
|                         | Tm <sub>avg</sub>  | Average meter temperature                                                 | °F                   |
|                         | Vm <sub>std</sub>  | Volume meter, standard conditions                                         | dscf                 |
| 3                       | Vlc                | Total moisture collected                                                  | grams                |
|                         | Vw <sub>std</sub>  | Volume of water vapor collected,<br>standard conditions                   | ft <sup>3</sup>      |
|                         | % H <sub>2</sub> O | Percent moisture by volume                                                | -                    |
|                         |                    |                                                                           |                      |
| 4                       | Mf                 | Mole fraction of dry gas                                                  | -                    |
| 5                       | % CO <sub>2</sub>  | Percent carbon dioxide by volume, dry                                     | -                    |
|                         | % O <sub>2</sub>   | Percent oxygen by volume, dry                                             | -                    |
|                         | % CO               | Percent carbon monoxide by volume, dry                                    | -                    |
|                         | % N <sub>2</sub>   | Percent nitrogen by volume, dry                                           | -                    |
| 6                       | Md                 | Molecular weight, dry stack gas                                           | lb/lb-mole           |
| 7                       | Ms                 | Molecular weight, stack gas                                               | lb/lb-mole           |
| 8                       | Θi                 | Sampling time interval                                                    | minutes              |
|                         | Dn                 | Diameter of nozzle                                                        | inches               |
|                         | ΔPs                | Velocity head of S pitot                                                  | in. H <sub>2</sub> O |
|                         | Ts                 | Temperature of stack gas                                                  | °F                   |
|                         | Vm <sub>i</sub>    | Volume of meter per sampling interval                                     | ft <sup>3</sup>      |
| 9                       | Ps                 | Stack pressure, absolute                                                  | in. Hg               |
|                         | Pg                 | Stack gas pressure                                                        | in. H <sub>2</sub> O |
| 10                      | ΔPs <sub>avg</sub> | Average velocity head of S pitot                                          | in. H <sub>2</sub> O |
|                         | Ts <sub>avg</sub>  | Average temperature of stack gas                                          | °F                   |
|                         | Vs                 | Average stack gas velocity                                                | fpm                  |
| 11                      | Θ                  | Total time of test                                                        | minutes              |
|                         | % I                | Percent isokinetic                                                        | -                    |
| 12                      | ID                 | Inside diameter of stack                                                  | inches               |
|                         | As                 | Area of stack                                                             | in <sup>2</sup>      |
| 13                      | Qs                 | Stack flow rate, dry standard conditions                                  | dscfm                |
| 14                      | m <sub>a</sub>     | Total particulate matter collected                                        | mg                   |
|                         | Cs <sub>std</sub>  | Concentration of particulate collected,<br>dry basis, standard conditions | gr/dscf              |

|    |                                              |                                                                          |                                           |
|----|----------------------------------------------|--------------------------------------------------------------------------|-------------------------------------------|
| 15 | $C_{s_{ad}}(\text{corr } 7\% \text{ O}_2)$   | Concentration of particulate collected,<br>dry basis standard conditions | gr/dscf<br>(corr to 7% O <sub>2</sub> )   |
| 16 | $C_{s_{ad}}(\text{corr } 12\% \text{ CO}_2)$ | Concentration of particulate collected,<br>dry basis standard condition  | gr/dscf<br>(corr to 12% CO <sub>2</sub> ) |
| 17 | $C_{s_{ad}}$                                 | Concentration of particulate collected,<br>actual conditions             | gr/acf                                    |
| 18 | $E_p$                                        | Particulate emission rate                                                | lb/hr                                     |

# PARTICULATE CALCULATION EQUATIONS

$$1. \quad V_m = V_f - V_i$$

$$2. \quad V_{m(std)} = \frac{17.64 (V_m) Y \left( P_b + \frac{\Delta H_{avg}}{13.6} \right)}{T_{m(avg)} + 460}$$

$$3. \quad V_{wc(std)} = 0.0471(V_{lc})$$

$$\% H_2O = \frac{100(V_{wc(std)})}{V_{m(std)} + V_{wc(std)}}$$

$$4. \quad M_f = \frac{100 - \% H_2O}{100}$$

$$5. \quad \% N_2 = 100 - (\% CO_2 + \% O_2 + \% CO)$$

$$6. \quad M_d = (\% CO_2 \times 0.44) + (\% O_2 \times 0.32) + (\% N_2 + \% CO \times 0.28)$$

$$7. \quad M_s = (M_d \times M_p) + 18(1 - M_p)$$

$$8. \quad V_{mi} = \frac{5.168(T_m + 460)(C_p)(\theta)(M_p)(D_n^2)}{\sqrt{P_b}} \times \sqrt{\frac{\Delta P_s}{T_s + 460}}$$

$$9. \quad P_s = P_b + \frac{P_g}{13.6}$$

$$10. \quad V_s = 5128.8 \times C_p \times \sqrt{\Delta P_{s(avg)}} \times \sqrt{\frac{T_{s(avg)} + 460}{P_s \times M_s}}$$

$$11. \quad \% I = \frac{1039(T_{s(avg)} + 460)(V_{m(std)})}{V_s(\theta)(P_s)(M_p)(D_n^2)}$$



$$12. A_s = \pi \left( \frac{ID}{2} \right)^2$$

$$13. Q_s = \frac{0.122(V_s)(A_s)(M_p)(P_s)}{T_{s(avg)} + 460}$$

$$14. C_{s(std)} = 0.0154 \left( \frac{M_n}{V_{m(std)}} \right)$$

$$15. C_{s(act)} = \frac{17.64(C_{s(std)})(P_s)(M_p)}{T_{s(avg)} + 460}$$

$$16. E_p = 0.00857(C_{s(std)})(Q_s)$$

**APPENDIX B**

**COMPUTER FORMS**

FILE NAME - ODESSA.R1  
RUN # - ODESSA.R1  
LOCATION - DRYER STACK  
DATE - SEPTEMBER 2, 1993  
PROJECT # - 411922

PROG.=VER 06/27/89  
09-29-1993 09:33:05

|                                       |         |
|---------------------------------------|---------|
| Initial Meter Volume (Cubic Feet)=    | 741.000 |
| Final Meter Volume (Cubic Feet)=      | 780.938 |
| Meter Factor=                         | 1.019   |
| Final Leak Rate (cu ft/min)=          | 0.002   |
| Net Meter Volume (Cubic Feet)=        | 40.697  |
| Gas Volume (Dry Standard Cubic Feet)= | 37.841  |

|                               |       |
|-------------------------------|-------|
| Barometric Pressure (in Hg)=  | 27.79 |
| Static Pressure (Inches H2O)= | 0.85  |

|                          |       |
|--------------------------|-------|
| Percent Oxygen=          | 17.5  |
| Percent Carbon Dioxide=  | 1.5   |
| Moisture Collected (ml)= | 164.5 |
| Percent Water=           | 17.0  |

|                                |       |
|--------------------------------|-------|
| Average Meter Temperature (F)= | 69    |
| Average Delta H (in H2O)=      | 1.40  |
| Average Delta P (in H2O)=      | 2.413 |
| Average Stack Temperature (F)= | 178   |

|                       |       |
|-----------------------|-------|
| Dry Molecular Weight= | 28.94 |
| Wet Molecular Weight= | 27.08 |

|                                          |        |
|------------------------------------------|--------|
| Average Square Root of Delta P (in H2O)= | 1.5530 |
| % Isokinetic=                            | 91.7   |

|                           |       |
|---------------------------|-------|
| Pitot Coefficient=        | 0.84  |
| Sampling Time (Minutes)=  | 60.0  |
| Nozzle Diameter (Inches)= | 0.179 |
| Stack Axis #1 (Inches)=   | 48.0  |
| Stack Axis #2 (Inches)=   | 48.0  |
| Circular Stack            |       |
| Stack Area (Square Feet)= | 12.57 |

|                                          |        |
|------------------------------------------|--------|
| Stack Velocity (Actual, Feet/min)=       | 6,154  |
| Flow Rate (Actual, Cubic ft/min)=        | 77,333 |
| Flow rate (Standard, Wet, Cubic ft/min)= | 59,566 |
| Flow Rate (Standard, Dry, Cubic ft/min)= | 49,442 |

#### Particulate Loading - Front Half

|                                         |        |
|-----------------------------------------|--------|
| Particulate Weight (g)=                 | 0.2680 |
| Particulate Loading, Dry Std. (gr/scf)= | 0.1091 |
| Particulate Loading, Actual (gr/cu ft)= | 0.0697 |
| Emission Rate (lb/hr)=                  | 46.21  |

|                          |
|--------------------------|
| Corr. to 7% O2 & 12% CO2 |
| 0.4362      0.8725       |

#### Particulate Loading - Total Catch Including Impingers

|                                         |        |
|-----------------------------------------|--------|
| Particulate Weight (g)=                 | 0.2764 |
| Particulate Loading, Dry Std. (gr/scf)= | 0.1125 |
| Particulate Loading, Actual (gr/cu ft)= | 0.0719 |
| Emission Rate (lb/hr)=                  | 47.66  |
| Percent Impinger Catch=                 | 3.0    |

|                    |
|--------------------|
| 0.4499      0.8998 |
|--------------------|

\* \* METRIC UNITS \* \*

FILE NAME - ODESSA.R1  
 RUN # - ODESSA.R1  
 LOCATION - DRYER STACK  
 DATE - SEPTEMBER 2, 1993  
 PROJECT # - 411922

PROG.=VER 06/27/89  
 09-29-1993 09:33:06

Initial Meter Volume (Cubic Meters)= 20.982  
 Final Meter Volume (Cubic Meters)= 22.113  
 Meter Factor= 1.019  
 Final Leak Rate (cu m/min)= 0.0001  
 Net Meter Volume (Cubic Meters)= 1.152  
 Gas Volume (Dry Standard Cubic Meters)= 1.072

Barometric Pressure (mm Hg)= 706  
 Static Pressure (mm H2O)= 22

Percent Oxygen= 17.5  
 Percent Carbon Dioxide= 1.5  
 Moisture Collected (ml)= 164.5  
 Percent Water= 17.0

Average Meter Temperature (C)= 21  
 Average Delta H (mm H2O)= 35.7  
 Average Delta P (mm H2O)= 61.3  
 Average Stack Temperature (C)= 81

Dry Molecular Weight= 28.94  
 Wet Molecular Weight= 27.08

Average Square Root of Delta P (mm H2O)= 7.8268  
 % Isokinetic= 91.7

Pitot Coefficient= 0.84  
 Sampling Time (Minutes)= 60.0  
 Nozzle Diameter (mm)= 4.55  
 Stack Axis #1 (Meters)= 1.219  
 Stack Axis #2 (Meters)= 1.219  
 Circular Stack  
 Stack Area (Square Meters)= 1.167

Stack Velocity (Actual, m/min)= 1,876  
 Flow rate (Actual, Cubic m/min)= 2,190  
 Flow rate (Standard, Wet, Cubic m/min)= 1,687  
 Flow rate (Standard, Dry, Cubic m/min)= 1,400

Particulate Loading - Front Half

|                                          |        |                          |
|------------------------------------------|--------|--------------------------|
| Particulate Weight (g)=                  | 0.2680 | Corr. to 7% O2 & 12% CO2 |
| Particulate Loading, Dry Std. (mg/cu m)= | 250.1  | 1000.4 2000.7            |
| Particulate Loading, Actual (mg/cu m)=   | 159.8  |                          |
| Emission Rate (kg/hr)=                   | 20.98  |                          |

Particulate Loading - Total Catch Including Impingers

|                                          |       |               |
|------------------------------------------|-------|---------------|
| Particulate Weight (g)=                  | 0.3   |               |
| Particulate Loading, Dry Std. (mg/cu m)= | 257.9 | 1031.7 2063.5 |
| Particulate Loading, Actual (mg/cu m)=   | 164.8 |               |
| Emission Rate (kg/hr)=                   | 21.64 |               |
| Percent Impinger Catch=                  | 3.0   |               |

FILE NAME - ODESSA.R1  
 RUN # - ODESSA.R1  
 LOCATION - DRYER STACK  
 DATE - SEPTEMBER 2, 1993  
 PROJECT # - 411922

PROG.=VER 06/27/89  
 09-29-1993 09:33:06

| Point # | Delta P<br>(in. H2O) | Delta H<br>(in. H2O) | Stack T<br>(F) | Meter T<br>In(F) | Meter T<br>Out(F) |
|---------|----------------------|----------------------|----------------|------------------|-------------------|
| 1       | 2.300                | 1.30                 | 177            | 66               | 66                |
| 2       | 2.400                | 1.40                 | 173            | 67               | 66                |
| 3       | 2.400                | 1.40                 | 177            | 67               | 66                |
| 4       | 2.400                | 1.40                 | 176            | 68               | 67                |
| 5       | 2.500                | 1.45                 | 178            | 68               | 67                |
| 6       | 2.500                | 1.45                 | 177            | 69               | 67                |
| 7       | 2.400                | 1.40                 | 177            | 69               | 67                |
| 8       | 2.500                | 1.45                 | 175            | 70               | 68                |
| 9       | 2.400                | 1.40                 | 175            | 70               | 68                |
| 10      | 2.400                | 1.40                 | 176            | 70               | 68                |
| 11      | 2.300                | 1.35                 | 177            | 70               | 69                |
| 12      | 2.300                | 1.35                 | 177            | 70               | 68                |
| 13      | 2.300                | 1.35                 | 177            | 70               | 68                |
| 14      | 2.300                | 1.35                 | 178            | 71               | 68                |
| 15      | 2.400                | 1.40                 | 180            | 71               | 68                |
| 16      | 2.500                | 1.45                 | 181            | 72               | 68                |
| 17      | 2.500                | 1.45                 | 182            | 72               | 69                |
| 18      | 2.500                | 1.45                 | 182            | 72               | 69                |
| 19      | 2.400                | 1.40                 | 179            | 73               | 69                |
| 20      | 2.600                | 1.50                 | 180            | 73               | 69                |
| 21      | 2.500                | 1.45                 | 180            | 73               | 69                |
| 22      | 2.400                | 1.40                 | 180            | 73               | 68                |
| 23      | 2.300                | 1.35                 | 180            | 73               | 69                |
| 24      | 2.400                | 1.40                 | 181            | 73               | 69                |

| Fraction  | Final Wt.<br>(g) | Tare Wt.<br>(g) | Blank Wt.<br>(g) | Net Wt.<br>(g) |
|-----------|------------------|-----------------|------------------|----------------|
| DRY CATCH | 0.0000           | 0.0000          | 0.0000           | 0.0000         |
| FILTER    | 33.5650          | 33.5089         | -0.0003          | 0.0564         |

| Fraction                                                           | Final Wt.<br>(g) | Tare Wt.<br>(g) | Vol.<br>(ml) | Net Wt.<br>(g) |
|--------------------------------------------------------------------|------------------|-----------------|--------------|----------------|
| PROBE RINSE                                                        | 63.5033          | 63.2907         | 130.0        | 0.2116         |
| IMPINGERS                                                          | 240.9925         | 240.9822        | 200.0        | 0.0084         |
| Probe Rinse Blank (mg/ml)= 0.0080 High Acetone Blank - Limit .0079 |                  |                 |              |                |
| Impinger Blank (mg/ml)= 0.0095                                     |                  |                 |              |                |

FILE NAME - ODESSA.R2  
RUN # - ODESSA.R2  
LOCATION - DRYER STACK  
DATE - SEPTEMBER 2, 1993  
PROJECT # - 411922

PROG.=VER 06/27/89  
09-28-1993 16:00:46

|                                       |         |
|---------------------------------------|---------|
| Initial Meter Volume (Cubic Feet)=    | 782.453 |
| Final Meter Volume (Cubic Feet)=      | 822.238 |
| Meter Factor=                         | 1.019   |
| Final Leak Rate (cu ft/min)=          | 0.002   |
| Net Meter Volume (Cubic Feet)=        | 40.541  |
| Gas Volume (Dry Standard Cubic Feet)= | 37.478  |

|                               |       |
|-------------------------------|-------|
| Barometric Pressure (in Hg)=  | 27.79 |
| Static Pressure (Inches H2O)= | 0.85  |

|                          |       |
|--------------------------|-------|
| Percent Oxygen=          | 17.0  |
| Percent Carbon Dioxide=  | 1.5   |
| Moisture Collected (ml)= | 180.9 |
| Percent Water=           | 18.5  |

|                                |       |
|--------------------------------|-------|
| Average Meter Temperature (F)= | 72    |
| Average Delta H (in H2O)=      | 1.39  |
| Average Delta P (in H2O)=      | 2.413 |
| Average Stack Temperature (F)= | 190   |

|                       |       |
|-----------------------|-------|
| Dry Molecular Weight= | 28.92 |
| Wet Molecular Weight= | 26.90 |

|                                          |        |
|------------------------------------------|--------|
| Average Square Root of Delta P (in H2O)= | 1.5530 |
| % Isokinetic=                            | 93.1   |

|                           |       |
|---------------------------|-------|
| Pitot Coefficient=        | 0.84  |
| Sampling Time (Minutes)=  | 60.0  |
| Nozzle Diameter (Inches)= | 0.179 |
| Stack Axis #1 (Inches)=   | 48.0  |
| Stack Axis #2 (Inches)=   | 48.0  |
| Circular Stack            |       |
| Stack Area (Square Feet)= | 12.57 |

|                                          |        |
|------------------------------------------|--------|
| Stack Velocity (Actual, Feet/min)=       | 6,234  |
| Flow Rate (Actual, Cubic ft/min)=        | 78,339 |
| Flow rate (Standard, Wet, Cubic ft/min)= | 59,200 |
| Flow Rate (Standard, Dry, Cubic ft/min)= | 48,234 |

#### Particulate Loading - Front Half

|                                         |        |                          |        |
|-----------------------------------------|--------|--------------------------|--------|
| Particulate Weight (g)=                 | 0.2135 | Corr. to 7% O2 & 12% CO2 |        |
| Particulate Loading, Dry Std. (gr/scf)= | 0.0877 | 0.3071                   | 0.7018 |
| Particulate Loading, Actual (gr/cu ft)= | 0.0540 |                          |        |
| Emission Rate (lb/hr)=                  | 36.26  |                          |        |

#### Particulate Loading - Total Catch Including Impingers

|                                         |        |        |        |
|-----------------------------------------|--------|--------|--------|
| Particulate Weight (g)=                 | 0.2213 |        |        |
| Particulate Loading, Dry Std. (gr/scf)= | 0.0909 | 0.3183 | 0.7275 |
| Particulate Loading, Actual (gr/cu ft)= | 0.0560 |        |        |
| Emission Rate (lb/hr)=                  | 37.59  |        |        |
| Percent Impinger Catch=                 | 3.5    |        |        |

\* \* METRIC UNITS \* \*

FILE NAME - ODESSA.R2  
 RUN # - ODESSA.R2  
 LOCATION - DRYER STACK  
 DATE - SEPTEMBER 2, 1993  
 PROJECT # - 411922

PROG.=VER 06/27/89  
 09-28-1993 16:00:46

Initial Meter Volume (Cubic Meters)= 22.156  
 Final Meter Volume (Cubic Meters)= 23.282  
 Meter Factor= 1.019  
 Final Leak Rate (cu m/min)= 0.0001  
 Net Meter Volume (Cubic Meters)= 1.148  
 Gas Volume (Dry Standard Cubic Meters)= 1.061

Barometric Pressure (mm Hg)= 706  
 Static Pressure (mm H2O)= 22

Percent Oxygen= 17.0  
 Percent Carbon Dioxide= 1.5  
 Moisture Collected (ml)= 180.9  
 Percent Water= 18.5

Average Meter Temperature (C)= 22  
 Average Delta H (mm H2O)= 35.3  
 Average Delta P (mm H2O)= 61.3  
 Average Stack Temperature (C)= 88

Dry Molecular Weight= 28.92  
 Wet Molecular Weight= 26.90

Average Square Root of Delta P (mm H2O)= 7.8267  
 % Isokinetic= 93.1

Pitot Coefficient= 0.84  
 Sampling Time (Minutes)= 60.0  
 Nozzle Diameter (mm)= 4.55  
 Stack Axis #1 (Meters)= 1.219  
 Stack Axis #2 (Meters)= 1.219  
 Circular Stack  
 Stack Area (Square Meters)= 1.167

Stack Velocity (Actual, m/min)= 1,900  
 Flow rate (Actual, Cubic m/min)= 2,218  
 Flow rate (Standard, Wet, Cubic m/min)= 1,676  
 Flow rate (Standard, Dry, Cubic m/min)= 1,366

Particulate Loading - Front Half

Particulate Weight (g)= 0.2135  
 Particulate Loading, Dry Std. (mg/cu m)= 201.2  
 Particulate Loading, Actual (mg/cu m)= 123.8  
 Emission Rate (kg/hr)= 16.46

Corr. to 7% O2 & 12% CO2  
 704.1 1609.5

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)= 0.2  
 Particulate Loading, Dry Std. (mg/cu m)= 208.5  
 Particulate Loading, Actual (mg/cu m)= 128.3  
 Emission Rate (kg/hr)= 17.07  
 Percent Impinger Catch= 3.5

729.9 1668.3

FILE NAME - ODESSA.R2  
 RUN # - ODESSA.R2  
 LOCATION - DRYER STACK  
 DATE - SEPTEMBER 2, 1993  
 PROJECT # - 411922

PROG.=VER 06/27/89  
 09-28-1993 16:00:47

| Point # | Delta P<br>(in. H2O) | Delta H<br>(in. H2O) | Stack T<br>(F) | Meter T<br>In(F) Out(F) |
|---------|----------------------|----------------------|----------------|-------------------------|
| 1       | 2.300                | 1.30                 | 187            | 70 70                   |
| 2       | 2.300                | 1.35                 | 188            | 70 70                   |
| 3       | 2.400                | 1.40                 | 190            | 71 70                   |
| 4       | 2.300                | 1.30                 | 190            | 72 70                   |
| 5       | 2.500                | 1.45                 | 190            | 73 71                   |
| 6       | 2.500                | 1.45                 | 189            | 73 71                   |
| 7       | 2.500                | 1.45                 | 190            | 73 71                   |
| 8       | 2.400                | 1.40                 | 190            | 73 71                   |
| 9       | 2.500                | 1.45                 | 191            | 74 71                   |
| 10      | 2.300                | 1.30                 | 192            | 73 71                   |
| 11      | 2.300                | 1.30                 | 192            | 73 71                   |
| 12      | 2.300                | 1.30                 | 192            | 74 72                   |
| 13      | 2.400                | 1.40                 | 190            | 72 71                   |
| 14      | 2.300                | 1.30                 | 190            | 73 71                   |
| 15      | 2.400                | 1.40                 | 191            | 73 71                   |
| 16      | 2.400                | 1.40                 | 192            | 74 71                   |
| 17      | 2.500                | 1.40                 | 192            | 74 72                   |
| 18      | 2.500                | 1.45                 | 190            | 74 72                   |
| 19      | 2.500                | 1.45                 | 192            | 74 72                   |
| 20      | 2.500                | 1.45                 | 190            | 75 72                   |
| 21      | 2.500                | 1.45                 | 190            | 75 72                   |
| 22      | 2.500                | 1.45                 | 190            | 75 72                   |
| 23      | 2.500                | 1.45                 | 191            | 75 72                   |
| 24      | 2.300                | 1.30                 | 191            | 75 72                   |

| Fraction  | Final Wt.<br>(g) | Tare Wt.<br>(g) | Blank Wt.<br>(g) | Net Wt.<br>(g) |
|-----------|------------------|-----------------|------------------|----------------|
| DRY CATCH | 0.0000           | 0.0000          | 0.0000           | 0.0000         |
| FILTER    | 33.5988          | 33.5561         | -0.0003          | 0.0430         |

| Fraction                                                           | Final Wt.<br>(g) | Tare Wt.<br>(g) | Vol.<br>(ml) | Net Wt.<br>(g) |
|--------------------------------------------------------------------|------------------|-----------------|--------------|----------------|
| PROBE RINSE                                                        | 65.4422          | 65.2706         | 140.0        | 0.1705         |
| IMPINGERS                                                          | 241.7733         | 241.7636        | 200.0        | 0.0078         |
| Probe Rinse Blank (mg/ml)= 0.0080 High Acetone Blank - Limit .0079 |                  |                 |              |                |
| Impinger Blank (mg/ml)= 0.0095                                     |                  |                 |              |                |



FILE NAME - ODESSA.R3  
RUN # - ODESSA.R3  
LOCATION - DRYER STACK  
DATE - SEPTEMBER 2, 1993  
PROJECT # - 411922

PROG.=VER 06/27/89  
09-28-1993 16:03:14

|                                       |         |
|---------------------------------------|---------|
| Initial Meter Volume (Cubic Feet)=    | 822.500 |
| Final Meter Volume (Cubic Feet)=      | 862.605 |
| Meter Factor=                         | 1.019   |
| Final Leak Rate (cu ft/min)=          | 0.004   |
| Net Meter Volume (Cubic Feet)=        | 40.867  |
| Gas Volume (Dry Standard Cubic Feet)= | 37.278  |

|                               |       |
|-------------------------------|-------|
| Barometric Pressure (in Hg)=  | 27.79 |
| Static Pressure (Inches H2O)= | 0.85  |

|                          |       |
|--------------------------|-------|
| Percent Oxygen=          | 17.0  |
| Percent Carbon Dioxide=  | 1.5   |
| Moisture Collected (ml)= | 197.5 |
| Percent Water=           | 20.0  |

|                                |       |
|--------------------------------|-------|
| Average Meter Temperature (F)= | 79    |
| Average Delta H (in H2O)=      | 1.39  |
| Average Delta P (in H2O)=      | 2.429 |
| Average Stack Temperature (F)= | 202   |

|                       |       |
|-----------------------|-------|
| Dry Molecular Weight= | 28.92 |
| Wet Molecular Weight= | 26.74 |

|                                          |        |
|------------------------------------------|--------|
| Average Square Root of Delta P (in H2O)= | 1.5583 |
| % Isokinetic=                            | 94.5   |

|                           |       |
|---------------------------|-------|
| Pitot Coefficient=        | 0.84  |
| Sampling Time (Minutes)=  | 60.0  |
| Nozzle Diameter (Inches)= | 0.179 |
| Stack Axis #1 (Inches)=   | 48.0  |
| Stack Axis #2 (Inches)=   | 48.0  |
| Circular Stack            |       |
| Stack Area (Square Feet)= | 12.57 |

|                                          |        |
|------------------------------------------|--------|
| Stack Velocity (Actual, Feet/min)=       | 6,328  |
| Flow Rate (Actual, Cubic ft/min)=        | 79,515 |
| Flow rate (Standard, Wet, Cubic ft/min)= | 59,074 |
| Flow Rate (Standard, Dry, Cubic ft/min)= | 47,277 |

#### Particulate Loading - Front Half

|                                         |        |                          |        |
|-----------------------------------------|--------|--------------------------|--------|
| Particulate Weight (g)=                 | 0.1788 | Corr. to 7% O2 & 12% CO2 |        |
| Particulate Loading, Dry Std. (gr/scf)= | 0.0739 | 0.2586                   | 0.5910 |
| Particulate Loading, Actual (gr/cu ft)= | 0.0439 |                          |        |
| Emission Rate (lb/hr)=                  | 29.93  |                          |        |

#### Particulate Loading - Total Catch Including Impingers

|                                         |        |        |        |
|-----------------------------------------|--------|--------|--------|
| Particulate Weight (g)=                 | 0.1859 |        |        |
| Particulate Loading, Dry Std. (gr/scf)= | 0.0768 | 0.2688 | 0.6145 |
| Particulate Loading, Actual (gr/cu ft)= | 0.0456 |        |        |
| Emission Rate (lb/hr)=                  | 31.12  |        |        |
| Percent Impinger Catch=                 | 3.8    |        |        |

\* \* METRIC UNITS \* \*

FILE NAME - ODESSA.R3  
 RUN # - ODESSA.R3  
 LOCATION - DRYER STACK  
 DATE - SEPTEMBER 2, 1993  
 PROJECT # - 411922

PROG.=VER 06/27/89  
 09-28-1993 16:03:15

|                                         |        |
|-----------------------------------------|--------|
| Initial Meter Volume (Cubic Meters)=    | 23.290 |
| Final Meter Volume (Cubic Meters)=      | 24.426 |
| Meter Factor=                           | 1.019  |
| Final Leak Rate (cu m/min)=             | 0.0001 |
| Net Meter Volume (Cubic Meters)=        | 1.157  |
| Gas Volume (Dry Standard Cubic Meters)= | 1.056  |

|                              |     |
|------------------------------|-----|
| Barometric Pressure (mm Hg)= | 706 |
| Static Pressure (mm H2O)=    | 22  |

|                          |       |
|--------------------------|-------|
| Percent Oxygen=          | 17.0  |
| Percent Carbon Dioxide=  | 1.5   |
| Moisture Collected (ml)= | 197.5 |
| Percent Water=           | 20.0  |

|                                |      |
|--------------------------------|------|
| Average Meter Temperature (C)= | 26   |
| Average Delta H (mm H2O)=      | 35.3 |
| Average Delta P (mm H2O)=      | 61.7 |
| Average Stack Temperature (C)= | 94   |

|                       |       |
|-----------------------|-------|
| Dry Molecular Weight= | 28.92 |
| Wet Molecular Weight= | 26.74 |

|                                          |        |
|------------------------------------------|--------|
| Average Square Root of Delta P (mm H2O)= | 7.8537 |
| % Isokinetic=                            | 94.5   |

|                             |       |
|-----------------------------|-------|
| Pitot Coefficient=          | 0.84  |
| Sampling Time (Minutes)=    | 60.0  |
| Nozzle Diameter (mm)=       | 4.55  |
| Stack Axis #1 (Meters)=     | 1.219 |
| Stack Axis #2 (Meters)=     | 1.219 |
| Circular Stack              |       |
| Stack Area (Square Meters)= | 1.167 |

|                                         |       |
|-----------------------------------------|-------|
| Stack Velocity (Actual, m/min)=         | 1,929 |
| Flow rate (Actual, Cubic m/min)=        | 2,252 |
| Flow rate (Standard, Wet, Cubic m/min)= | 1,673 |
| Flow rate (Standard, Dry, Cubic m/min)= | 1,339 |

Particulate Loading - Front Half

|                                          |        |
|------------------------------------------|--------|
| Particulate Weight (g)=                  | 0.1788 |
| Particulate Loading, Dry Std. (mg/cu m)= | 169.4  |
| Particulate Loading, Actual (mg/cu m)=   | 100.7  |
| Emission Rate (kg/hr)=                   | 13.59  |

|                          |
|--------------------------|
| Corr. to 7% O2 & 12% CO2 |
| 592.9      1355.3        |

Particulate Loading - Total Catch Including Impingers

|                                          |       |
|------------------------------------------|-------|
| Particulate Weight (g)=                  | 0.2   |
| Particulate Loading, Dry Std. (mg/cu m)= | 176.1 |
| Particulate Loading, Actual (mg/cu m)=   | 104.7 |
| Emission Rate (kg/hr)=                   | 14.13 |
| Percent Impinger Catch=                  | 3.8   |

|                   |
|-------------------|
| 616.5      1409.1 |
|-------------------|

FILE NAME - ODESSA.R3  
 RUN # - ODESSA.R3  
 LOCATION - DRYER STACK  
 DATE - SEPTEMBER 2, 1993  
 PROJECT # - 411922

PROG.=VER 06/27/89  
 09-28-1993 16:03:15

| Point # | Delta P<br>(in. H2O) | Delta H<br>(in. H2O) | Stack T<br>(F) | Meter T<br>In(F) Out(F) |
|---------|----------------------|----------------------|----------------|-------------------------|
| 1       | 2.300                | 1.30                 | 198            | 76 76                   |
| 2       | 2.300                | 1.30                 | 199            | 77 76                   |
| 3       | 2.300                | 1.30                 | 200            | 78 77                   |
| 4       | 2.400                | 1.40                 | 200            | 78 77                   |
| 5       | 2.400                | 1.40                 | 199            | 79 77                   |
| 6       | 2.500                | 1.40                 | 199            | 79 77                   |
| 7       | 2.500                | 1.45                 | 201            | 80 78                   |
| 8       | 2.500                | 1.40                 | 201            | 80 78                   |
| 9       | 2.500                | 1.45                 | 203            | 80 78                   |
| 10      | 2.500                | 1.45                 | 202            | 81 78                   |
| 11      | 2.500                | 1.40                 | 202            | 81 78                   |
| 12      | 2.400                | 1.40                 | 202            | 81 78                   |
| 13      | 2.400                | 1.40                 | 201            | 80 77                   |
| 14      | 2.400                | 1.40                 | 201            | 80 77                   |
| 15      | 2.300                | 1.30                 | 201            | 82 78                   |
| 16      | 2.500                | 1.45                 | 200            | 82 79                   |
| 17      | 2.500                | 1.40                 | 202            | 82 79                   |
| 18      | 2.600                | 1.50                 | 202            | 82 77                   |
| 19      | 2.500                | 1.45                 | 204            | 82 79                   |
| 20      | 2.500                | 1.40                 | 204            | 82 79                   |
| 21      | 2.500                | 1.45                 | 205            | 83 79                   |
| 22      | 2.400                | 1.40                 | 204            | 84 80                   |
| 23      | 2.300                | 1.30                 | 204            | 84 81                   |
| 24      | 2.300                | 1.30                 | 204            | 84 81                   |

| Fraction  | Final Wt.<br>(g) | Tare Wt.<br>(g) | Blank Wt.<br>(g) | Net Wt.<br>(g) |
|-----------|------------------|-----------------|------------------|----------------|
| DRY CATCH | 0.0000           | 0.0000          | 0.0000           | 0.0000         |
| FILTER    | 34.0298          | 33.9864         | -0.0003          | 0.0437         |

| Fraction    | Final Wt.<br>(g) | Tare Wt.<br>(g) | Vol.<br>(ml) | Net Wt.<br>(g) |
|-------------|------------------|-----------------|--------------|----------------|
| PROBE RINSE | 65.8865          | 65.7502         | 150.0        | 0.1351         |
| IMPINGERS   | 239.5222         | 239.5132        | 200.0        | 0.0071         |


Probe Rinse Blank (mg/ml)= 0.0080 High Acetone Blank - Limit .0079  
 Impinger Blank (mg/ml)= 0.0095

**APPENDIX C**

**PARTICULATE FIELD DATA FORMS**

# TRAVERSE POINT LOCATIONS

PROJECT NO. 411922  
 ANT. Odessa Refinery  
 DATE 9-2-93  
 SAMPLING LOCATION Dryer Stack  
 INSIDE OF FAR WALL TO OUTSIDE OF NIPPLE (Distance A) 52  
 INSIDE OF NEAR WALL TO OUTSIDE OF NIPPLE (Distance B) 4  
 STACK I.D. (Distance A - Distance B) 48  
 NEAREST UPSTREAM DISTURBANCE (in.) 744"  
 NEAREST DOWNSTREAM DISTURBANCE (in.) 96"  
 DIAMETERS UPSTREAM 1  
 DIAMETERS DOWNSTREAM 2  
 OPERATOR B. Wood



DRAWING OF STACK

| TRAVERSE POINT NUMBER | FRACTION OF STACK I.D. | STACK I.D. | PRODUCT OF COLUMNS 2 AND 3 | DISTANCE B | TRAVERSE POINT LOCATION FROM OUTSIDE OF NIPPLE (SUM OF COLUMNS 4 & 5) |                             |
|-----------------------|------------------------|------------|----------------------------|------------|-----------------------------------------------------------------------|-----------------------------|
|                       |                        |            |                            |            | Decimal                                                               | Fraction to nearest 1/8 in. |
| 1                     | 2.1                    | 48         | 1                          |            |                                                                       |                             |
| 2                     | 6.7                    |            | 3.2                        |            |                                                                       |                             |
| 3                     | 11.8                   |            | 5.7                        |            |                                                                       |                             |
| 4                     | 17.7                   |            | 8.5                        |            |                                                                       |                             |
| 5                     | 25.0                   |            | 12                         |            |                                                                       |                             |
| 6                     | 35.6                   |            | 17.1                       |            |                                                                       |                             |
| 7                     | 64.4                   |            | 30.9                       |            |                                                                       |                             |
| 8                     | 75.0                   |            | 36                         |            |                                                                       |                             |
| 9                     | 82.3                   |            | 39.5                       |            |                                                                       |                             |
| 10                    | 88.2                   |            | 42.3                       |            |                                                                       |                             |
| 11                    | 93.3                   |            | 44.8                       |            |                                                                       |                             |
| 12                    | 97.9                   |            | 47                         |            |                                                                       |                             |
|                       |                        |            |                            |            |                                                                       |                             |
|                       |                        |            |                            |            |                                                                       |                             |

Comments:

Reviewed by: \_\_\_\_\_ Date: \_\_\_\_\_


# AIRSOURCE TECHNOLOGIES

11635 W 83RD TERRACE  
Lenexa, Kansas 66215  
(913) 492-1613  
FAX: (913) 492-1012

PROJECT NO. 411927  
RUN NO. 1  
DATE 9/02  
SAMPLE TYPE particulate  
PLANT Odessa

PROJECT LEADER Blane Wood  
CONSOLE OPERATOR TRitus  
LAB PERSON TI  
SUPPORT PERSONNEL OB

SAMPLING LOCATION —  
TOTAL SAMPLING TIME 60 min.  
METER NO. 4 ASSUMED MOISTURE 25 %  
UMBILICAL CORD I.D. NO. - METER CORRECTION FACTOR 1.019  
UMBILICAL/SAMPLER HOOKUP X METER ΔH @ 1.843  
OVEN BOX NO. 1 BAROMETRIC PRESSURE 27.79 in Hg  
PROBE NO. 3A STATIC PRESSURE .85 in H<sub>2</sub>O  
PROBE LENGTH & TYPE 5' 6h1 RECORD DATA EVERY 2.5 MIN  
PITOT NO. 3A PITOT COEFFICIENT .84  
THERMOCOUPLE I.D. NO. 3A NOZZLE DIAMETER .179 in  
NOZZLE NO. .179 STACK AXIS #1 48  
NOZZLE TYPE SS/GIO STACK AXIS #2 48



SCHEMATIC OF TRAVERSE  
POINT LAYOUT

| SAMPLE TRAIN LEAK CHECKS                 | INITIAL | FINAL |
|------------------------------------------|---------|-------|
| TIME (24 HRS.)                           | 8:40    | 9:57  |
| VACUUM, in. Hg                           | .215    | .6"   |
| CFM                                      | .002    | .002  |
| PITOT LEAK CHECK<br>23" H <sub>2</sub> O | pass    | pass  |

|                      |         |
|----------------------|---------|
| INITIAL METER VOLUME | 741.000 |
| FINAL METER VOLUME   | 760.938 |

## ORSAT/FYRITE

## RECOVERY DATA

| TRIAL | PERCENT CO <sub>2</sub> | PERCENT CO + O <sub>2</sub> | PERCENT O <sub>2</sub> |
|-------|-------------------------|-----------------------------|------------------------|
| 1     | 1.5                     |                             | 17.5                   |
| 2     | 1.5                     |                             | 17.5                   |
| 3     |                         |                             |                        |
| AVG   | 1.5                     |                             | 17.5                   |

|        | FINAL | INITIAL | DIFFERENCE |
|--------|-------|---------|------------|
| IMP. 1 | 186   | 100     | 88         |
| IMP. 2 | 185   | 100     | 55         |
| IMP. 3 | 9     | 0       | 9          |
| IMP. 4 | 765.3 | 752.8   | 12.5       |
| TOTAL: |       |         | 164.5      |

COMMENTS:

FILTER NO. 8-20-93-3

% BLUE 70

REVIEWED BY: \_\_\_\_\_

| Traverse Point Number | Sample Time (min) | Clock Time (24-hr) | Dry Gas Meter ft <sup>3</sup> |         | Velocity Head Δp in. H <sub>2</sub> O | Orifice ΔH in. H <sub>2</sub> O |        | Stack Temp. °F | Dry Gas Meter Temperature °F |        | Pump VAC. in. Hg | Probe Temp. °F | Filter Temp. °F | Impinger Temp. °F |
|-----------------------|-------------------|--------------------|-------------------------------|---------|---------------------------------------|---------------------------------|--------|----------------|------------------------------|--------|------------------|----------------|-----------------|-------------------|
|                       |                   |                    | Initial                       | Desired | Actual                                | Desired                         | Actual |                | Inlet                        | Outlet |                  |                |                 |                   |
| A1                    |                   | 8:50               | 742.62                        |         | 742.63                                | 1.33                            | 1.3    | 177            | 66                           | 66     | 3                | 225            | 235             | 66                |
| 2                     | 5                 | 8:55               | 744.27                        |         | 744.29                                | 1.40                            | 1.4    | 173            | 67                           | 66     | 3                | 231            | 234             | 59                |
| 3                     |                   |                    | 745.93                        |         | 745.95                                | 1.39                            | 1.4    | 177            | 67                           | 66     | 3                | 246            | 228             | 57                |
| 4                     | 10                | 9:00               | 747.58                        |         | 747.60                                | 1.40                            | 1.4    | 176            | 68                           | 67     | 3                | 250            | 230             | 55                |
| 5                     |                   |                    | 749.27                        |         | 749.28                                | 1.45                            | 1.45   | 178            | 68                           | 67     | 3                | 255            | 233             | 55                |
| 6                     | 15                | 9:05               | 750.96                        |         | 750.94                                | 1.45                            | 1.45   | 177            | 69                           | 67     | 3                | 249            | 230             | 51                |
| 7                     |                   |                    | 752.62                        |         | 752.61                                | 1.40                            | 1.4    | 177            | 69                           | 67     | 3                | 247            | 231             | 52                |
| 8                     | 20                | 9:10               | 754.32                        |         | 754.32                                | 1.46                            | 1.45   | 175            | 70                           | 68     | 3                | 251            | 233             | 52                |
| 9                     |                   |                    | 755.98                        |         | 755.98                                | 1.40                            | 1.4    | 175            | 70                           | 68     | 3                | 252            | 235             | 51                |
| 10                    | 25                | 9:15               | 757.64                        |         | 757.65                                | 1.40                            | 1.4    | 176            | 70                           | 68     | 3                | 252            | 237             | 51                |
| 11                    |                   |                    | 759.27                        |         | 759.28                                | 1.34                            | 1.35   | 177            | 70                           | 69     | 3                | 253            | 240             | 53                |
| 12                    | 30                | 9:20               | 760.84                        |         | 760.84                                | 1.34                            | 1.35   | 177            | 70                           | 68     | 3                | 250            | 239             | 54                |
|                       |                   | 9:15               |                               |         |                                       |                                 |        |                |                              |        |                  |                |                 |                   |
| B1                    |                   |                    | 762.52                        |         | 762.53                                | 1.34                            | 1.35   | 177            | 70                           | 68     | 3                | 250            | 238             | 54                |
| 2                     | 5                 | 9:30               | 764.15                        |         | 764.13                                | 1.34                            | 1.35   | 178            | 71                           | 68     | 3                | 247            | 240             | 57                |
| 3                     |                   |                    | 765.80                        |         | 765.78                                | 1.39                            | 1.4    | 180            | 71                           | 68     | 3                | 247            | 241             | 58                |
| 4                     | 10                | 9:35               | 767.50                        |         | 767.44                                | 1.45                            | 1.45   | 181            | 72                           | 68     | 3                | 249            | 244             | 60                |
| 5                     |                   |                    | 769.19                        |         | 769.17                                | 1.45                            | 1.45   | 182            | 72                           | 69     | 3                | 251            | 243             | 60                |
| 6                     | 15                | 9:40               | 770.88                        |         | 770.84                                | 1.45                            | 1.45   | 182            | 72                           | 69     | 3                | 252            | 240             | 60                |
| 7                     |                   |                    | 772.55                        |         | 772.53                                | 1.40                            | 1.4    | 179            | 73                           | 69     | 3                | 254            | 242             | 57                |
| 8                     | 20                | 9:45               | 774.28                        |         | 774.27                                | 1.51                            | 1.5    | 180            | 73                           | 69     | 3                | 251            | 242             | 54                |
| 9                     |                   |                    | 775.97                        |         | 775.95                                | 1.46                            | 1.45   | 180            | 73                           | 69     | 3                | 253            | 242             | 52                |
| 10                    | 25                | 9:50               | 777.65                        |         | 777.64                                | 1.41                            | 1.4    | 180            | 73                           | 69     | 3                | 250            | 244             | 52                |
| 11                    |                   |                    | 779.28                        |         | 779.28                                | 1.34                            | 1.35   | 180            | 73                           | 69     | 3                | 247            | 240             | 57                |
| 12                    | 30                | 9:55               | 780.93                        |         | 780.93                                | 1.44                            | 1.4    | 181            | 73                           | 69     | 3                | 249            | 241             | 52                |

# AIRSOURCE TECHNOLOGIES

11635 W 83RD TERRACE  
Lenexa, Kansas 66215  
(913) 492-1613  
FAX: (913) 492-1012

PROJECT NO. 411922  
RUN NO. 2  
DATE 9/02/93  
SAMPLE TYPE pass  
PLANT Messrs  
SAMPLING LOCATION ✓  
TOTAL SAMPLING TIME 60 min  
METER NO. 4 ASSUMED MOISTURE 25 %  
UMBILICAL CORD I.D. NO. ✓ METER CORRECTION FACTOR 1.018  
UMBILICAL/SAMPLER HOOKUP 3 METER ΔH @ 1.843  
OVEN BOX NO. 1 BAROMETRIC PRESSURE 27.79 in Hg  
PROBE NO. 3 WH STATIC PRESSURE .85 in H<sub>2</sub>O  
PROBE LENGTH & TYPE 3' G RECORD DATA EVERY 7.5 MIN  
PITOT NO. 3 WH PITOT COEFFICIENT .84  
THERMOCOUPLE I.D. NO. 3 WH NOZZLE DIAMETER .179 in  
NOZZLE NO. 179 STACK AXIS #1 48  
NOZZLE TYPE 82 G10 STACK AXIS #2 48

PROJECT LEADER OBW  
CONSOLE OPERATOR TT  
LAB PERSON TT  
SUPPORT PERSONNEL: \_\_\_\_\_

see sm 1

## SCHEMATIC OF TRAVERSE POINT LAYOUT

| SAMPLE TRAIN LEAK CHECKS                 | INITIAL | FINAL |
|------------------------------------------|---------|-------|
| TIME (24 HRS.)                           | 1015    | 1125  |
| VACUUM, in. Hg                           | ±15     | 10"   |
| CFM                                      | .004    | .002  |
| PITOT LEAK CHECK<br>±3" H <sub>2</sub> O | pass    | pass  |

|                      |         |
|----------------------|---------|
| INITIAL METER VOLUME | 782.453 |
| FINAL METER VOLUME   | 822.238 |

## ORSAT/FYRITE

## RECOVERY DATA

| TRIAL | PERCENT CO <sub>2</sub> | PERCENT CO <sub>2</sub> + O <sub>2</sub> | PERCENT O <sub>2</sub> |
|-------|-------------------------|------------------------------------------|------------------------|
| 1     | 1.5                     |                                          | 17.0                   |
| 2     | 1.5                     |                                          | 17.0                   |
| 3     |                         |                                          |                        |
| AVG   | 1.5                     |                                          | 17.0                   |

|        | FINAL | INITIAL | DIFFERENCE |
|--------|-------|---------|------------|
| IMP. 1 | 199   | 180     | 99         |
| IMP. 2 | 163   | 100     | 63         |
| IMP. 3 | 5     | 0       | 5          |
| IMP. 4 | 795.4 | 781.5   | 13.9       |
| TOTAL: |       |         | 180.9      |

COMMENTS:

FILTER NO.: 8-20-93-13

% BLUE 88

REVIEWED BY: \_\_\_\_\_



| Traverse Point Number | Sample Time (min) | Clock Time (24-hr) | Dry Gas Meter ft <sup>3</sup> |         | Velocity Head Ap in. H <sub>2</sub> O | Orifice ΔH in. H <sub>2</sub> O |        | Stack Temp. °F | Dry Gas Meter Temperature °F |        | Pump VAC in. Hg | Probe Temp. °F | Filter Temp. °F | Impinger Temp. °F |
|-----------------------|-------------------|--------------------|-------------------------------|---------|---------------------------------------|---------------------------------|--------|----------------|------------------------------|--------|-----------------|----------------|-----------------|-------------------|
|                       |                   |                    | Initial                       | Desired |                                       | Desired                         | Actual |                | Inlet                        | Outlet |                 |                |                 |                   |
| A 1                   |                   | 1020               | 784.07                        | 784.05  | 2.3                                   | 1.32                            | 1.3    | 147            | 70                           | 70     | 3               | 246            | 232             | 63                |
| 2                     | 5                 | 1025               | 785.69                        | 785.67  | 2.3                                   | 1.34                            | 1.35   | 188            | 70                           | 70     | 3               | 245            | 231             | 60                |
| 3                     |                   |                    | 787.34                        | 787.33  | 2.4                                   | 1.37                            | 1.4    | 190            | 71                           | 70     | 3               | 246            | 233             | 55                |
| 4                     | 10                | 1030               | 788.96                        | 788.96  | 2.3                                   | 1.32                            | 1.3    | 190            | 72                           | 70     | 3               | 245            | 232             | 49                |
| 5                     |                   |                    | 790.64                        | 790.64  | 2.5                                   | 1.44                            | 1.45   | 190            | 73                           | 71     | 3               | 245            | 231             | 45                |
| 6                     | 15                | 1035               | 792.33                        | 792.34  | 2.5                                   | 1.44                            | 1.45   | 189            | 73                           | 71     | 3               | 247            | 233             | 47                |
| 7                     |                   |                    | 794.02                        | 794.03  | 2.5                                   | 1.44                            | 1.45   | 190            | 73                           | 71     | 3               | 246            | 235             | 45                |
| 8                     | 20                | 1040               | 795.67                        | 795.69  | 2.4                                   | 1.38                            | 1.4    | 190            | 73                           | 71     | 3               | 245            | 232             | 46                |
| 9                     |                   |                    | 797.36                        | 797.38  | 2.5                                   | 1.44                            | 1.45   | 191            | 74                           | 71     | 3               | 246            | 234             | 46                |
| 10                    | 25                | 1045               | 798.98                        | 798.98  | 2.3                                   | 1.32                            | 1.3    | 192            | 73                           | 71     | 3               | 246            | 237             | 46                |
| 11                    |                   |                    | 800.59                        | 800.58  | 2.3                                   | 1.32                            | 1.3    | 192            | 73                           | 71     | 3               | 245            | 235             | 47                |
| 12                    | 30                | 1050               | 802.210                       | 802.208 | 2.3                                   | 1.32                            | 1.3    | 192            | 74                           | 72     | 3               | 244            | 240             | 47                |
| B 1                   |                   | 1053               | 803.86                        | 803.86  | 2.4                                   | 1.38                            | 1.4    | 190            | 72                           | 71     | 3               | 244            | 241             | 48                |
| 2                     | 5                 | 1054               | 805.48                        | 805.48  | 2.3                                   | 1.32                            | 1.3    | 190            | 73                           | 71     | 3               | 243            | 239             | 48                |
| 3                     |                   |                    | 807.13                        | 807.14  | 2.4                                   | 1.38                            | 1.4    | 191            | 73                           | 71     | 3               | 242            | 239             | 50                |
| 4                     | 10                | 1103               | 808.78                        | 808.80  | 2.4                                   | 1.38                            | 1.4    | 192            | 74                           | 71     | 4               | 243            | 238             | 50                |
| 5                     |                   |                    | 810.47                        | 810.46  | 2.5                                   | 1.43                            | 1.4    | 192            | 74                           | 72     | 3               | 244            | 233             | 50                |
| 6                     | 15                | 1108               | 812.16                        | 812.15  | 2.5                                   | 1.44                            | 1.45   | 190            | 74                           | 72     | 3               | 240            | 232             | 51                |
| 7                     |                   |                    | 813.85                        | 813.85  | 2.5                                   | 1.43                            | 1.45   | 192            | 74                           | 72     | 3               | 241            | 231             | 50                |
| 8                     | 20                | 1113               | 815.54                        | 815.54  | 2.5                                   | 1.44                            | 1.45   | 190            | 75                           | 72     | 3               | 243            | 233             | 50                |
| 9                     |                   |                    | 817.23                        | 817.24  | 2.5                                   | 1.44                            | 1.45   | 190            | 75                           | 72     | 3               | 240            | 235             | 49                |
| 10                    | 25                | 1118               | 818.92                        | 818.93  | 2.5                                   | 1.44                            | 1.45   | 190            | 75                           | 72     | 3               | 239            | 233             | 49                |
| 11                    |                   |                    | 820.61                        | 820.62  | 2.5                                   | 1.44                            | 1.45   | 191            | 75                           | 72     | 3               | 241            | 237             | 51                |
| 12                    | 30                | 1123               | 822.335                       | 822.236 | 2.3                                   | 1.32                            | 1.3    | 191            | 75                           | 72     | 3               | 243            | 236             | 51                |

# AIRSOURCE TECHNOLOGIES

11635 W 83RD TERRACE  
Lenexa, Kansas 66215  
(913) 492-1613  
FAX: (913) 492-1012

PROJECT NO. 411922  
RUN NO. 3  
DATE 9/02/93  
SAMPLE TYPE positive  
PLANT Deason  
SAMPLING LOCATION -  
TOTAL SAMPLING TIME -  
METER NO. 4 ASSUMED MOISTURE 25 %  
UMBILICAL CORD I.D. NO. - METER CORRECTION FACTOR 1.019  
UMBILICAL/SAMPLER HOOKUP 3 METER AH @ 1.843  
OVEN BOX NO. 1 BAROMETRIC PRESSURE 27.79 in Hg  
PROBE NO. 3-1 STATIC PRESSURE .85 in H<sub>2</sub>O  
PROBE LENGTH & TYPE 3' 6 RECORD DATA EVERY 2.5 MIN  
PITOT NO. 3-1 PITOT COEFFICIENT .84  
THERMOCOUPLE I.D. NO. 3-1 NOZZLE DIAMETER .179 in  
NOZZLE NO. .179 STACK AXIS #1 48  
NOZZLE TYPE SS/G/O STACK AXIS #2 48

PROJECT LEADER BW  
CONSOLE OPERATOR TT  
LAB PERSON TT  
SUPPORT PERSONNEL: \_\_\_\_\_

see run 1

## SCHEMATIC OF TRAVERSE POINT LAYOUT

| SAMPLE TRAIN LEAK CHECKS                | INITIAL | FINAL |
|-----------------------------------------|---------|-------|
| TIME (24 HRS.)                          | 1135    | 1147  |
| VACUUM, in. Hg                          | .15     | 10"   |
| CFM                                     | .006    | .004  |
| PITOT LEAK CHECK<br>2" H <sub>2</sub> O | pass    | pass  |

|                      |         |
|----------------------|---------|
| INITIAL METER VOLUME | 822.500 |
| FINAL METER VOLUME   | 862.605 |

## ORSAT/FYRITE

## RECOVERY DATA

| TRIAL | PERCENT CO. | PERCENT CO. + O. | PERCENT O. |
|-------|-------------|------------------|------------|
| 1     | 1.5         |                  | 17.0       |
| 2     | 1.5         |                  | 17.0       |
| 3     |             |                  |            |
| AVG   | 1.5         |                  | 17.0       |

|        | FINAL | INITIAL | DIFFERENCE |
|--------|-------|---------|------------|
| IMP. 1 | 221   | 100     | 121        |
| IMP. 2 | 168   | 100     | 58         |
| IMP. 3 | 5     | 0       | 5          |
| IMP. 4 | 682.6 | 669.1   | 13.5       |
| TOTAL: |       |         | 197.5      |

COMMENTS:

FILTER NO: 8-20-93-2

% BLUE \_\_\_\_\_

REVIEWED BY: \_\_\_\_\_

Run No. 3

Project No. 411922

Location

Odessa

Date

9/24/95

Operator

Page 1 of 1

| Traverse Point Number | Sample Time (min) | Clock Time (24-hr) | Dry Gas Meter ft <sup>3</sup> |         | Velocity Head $\Delta p$ in. H <sub>2</sub> O | Orifice $\Delta H$ in. H <sub>2</sub> O |        | Stack Temp. °F | Dry Gas Meter Temperature °F |        | Pump VAC in. Hg | Probe Temp. °F | Filter Temp. °F | Impinger Temp. °F |
|-----------------------|-------------------|--------------------|-------------------------------|---------|-----------------------------------------------|-----------------------------------------|--------|----------------|------------------------------|--------|-----------------|----------------|-----------------|-------------------|
|                       |                   |                    | Desired                       | Actual  |                                               | Desired                                 | Actual |                | Inlet                        | Outlet |                 |                |                 |                   |
| A1                    |                   | 1140               | 824.12                        | 824.12  | 2.3                                           | 1.31                                    | 1.3    | 198            | 76                           | 76     | 7               | 250            | 245             | 66                |
| 2                     | 5                 | 1145               | 825.74                        | 825.73  | 2.3                                           | 1.31                                    | 1.3    | 199            | 77                           | 76     | 7               | 248            | 247             | 64                |
| 3                     |                   |                    | 827.36                        | 827.37  | 2.3                                           | 1.31                                    | 1.3    | 200            | 78                           | 77     | 7               | 252            | 250             | 60                |
| 4                     | 10                | 1150               | 829.02                        | 829.03  | 2.4                                           | 1.37                                    | 1.4    | 200            | 78                           | 77     | 7               | 253            | 251             | 59                |
| 5                     |                   |                    | 830.68                        | 830.68  | 2.4                                           | 1.37                                    | 1.4    | 199            | 79                           | 77     | 7               | 251            | 250             | 58                |
| 6                     | 15                | 1155               | 832.38                        | 832.40  | 2.5                                           | 1.43                                    | 1.4    | 199            | 79                           | 77     | 7               | 252            | 249             | 58                |
| 7                     |                   |                    | 834.07                        | 834.08  | 2.5                                           | 1.43                                    | 1.45   | 201            | 80                           | 78     | 7               | 247            | 248             | 58                |
| 8                     | 20                | 1200               | 835.77                        | 835.78  | 2.5                                           | 1.43                                    | 1.4    | 201            | 80                           | 78     | 7               | 246            | 251             | 60                |
| 9                     |                   |                    | 837.46                        | 837.46  | 2.5                                           | 1.43                                    | 1.45   | 203            | 80                           | 78     | 7               | 240            | 250             | 60                |
| 10                    | 25                | 1205               | 839.15                        | 839.14  | 2.5                                           | 1.43                                    | 1.45   | 202            | 81                           | 78     | 7               | 237            | 250             | 61                |
| 11                    |                   |                    | 840.65                        | -       | 2.5                                           | 1.43                                    | 1.4    | 202            | 81                           | 78     | 7               | 239            | 251             | 59                |
| 12                    | 30                | 1210               | 842.51                        | 842.51  | 2.4                                           | 1.37                                    | 1.4    | 202            | 81                           | 78     | 7               | 241            | 252             | 58                |
|                       |                   | 14                 |                               |         |                                               |                                         |        |                |                              |        |                 |                |                 |                   |
| B1                    |                   |                    | 844.17                        | 844.17  | 2.4                                           | 1.37                                    | 1.4    | 201            | 80                           | 77     | 7               | 240            | 250             | 60                |
| 2                     | 5                 | 1219               | 845.83                        | 845.84  | 2.4                                           | 1.37                                    | 1.4    | 201            | 80                           | 77     | 7               | 244            | 251             | 60                |
| 3                     |                   |                    | 847.46                        | 847.47  | 2.3                                           | 1.32                                    | 1.3    | 201            | 82                           | 78     | 7               | 243            | 253             | 61                |
| 4                     | 10                | 1224               | 849.16                        | 849.16  | 2.5                                           | 1.44                                    | 1.45   | 200            | 82                           | 79     | 7               | 245            | 250             | 61                |
| 5                     |                   |                    | 850.86                        | 850.86  | 2.5                                           | 1.43                                    | 1.4    | 202            | 82                           | 79     | 7               | 245            | 252             | 60                |
| 6                     | 15                | 1229               | 852.59                        | 852.60  | 2.6                                           | 1.49                                    | 1.5    | 202            | 82                           | 77     | 7               | 245            | 251             | 57                |
| 7                     |                   |                    | 854.28                        | 854.30  | 2.5                                           | 1.43                                    | 1.45   | 204            | 82                           | 79     | 7               | 247            | 249             | 57                |
| 8                     | 20                | 1234               | 855.98                        | 856.00  | 2.5                                           | 1.43                                    | 1.4    | 204            | 82                           | 79     | 7               | 250            | 247             | 56                |
| 9                     |                   |                    | 857.67                        | 857.68  | 2.5                                           | 1.43                                    | 1.45   | 205            | 83                           | 79     | 7               | 250            | 250             | 54                |
| 10                    | 25                | 1239               | 859.34                        | 859.34  | 2.4                                           | 1.37                                    | 1.4    | 204            | 84                           | 80     | 7               | 248            | 250             | 52                |
| 11                    |                   |                    | 860.97                        | 860.98  | 2.3                                           | 1.32                                    | 1.3    | 204            | 84                           | 81     | 7               | 247            | 251             | 51                |
| 12                    | 30                | 1244               | 862.605                       | 862.605 | 2.3                                           | 1.32                                    | 1.3    | 204            | 84                           | 81     | 7               | 247            | 251             | 51                |

**APPENDIX D**

**LABORATORY AND ANALYSIS FORMS**



## FINAL FILTER WEIGHING

|                                                                                  |                    |
|----------------------------------------------------------------------------------|--------------------|
| Project No.: 411992                                                              | Analyst: C.H.      |
| Filter Type and Size: 85 mm filter paper                                         | Weight Unit: grams |
| Filter Treatment:                                                                |                    |
| <input checked="" type="checkbox"/> Desiccate 24 hours/6 hours between weighings |                    |
| <input type="checkbox"/> Oven Treated                                            |                    |
| <input type="checkbox"/> Other                                                   |                    |

### Balance Check:

|                  |         |         |         |  |
|------------------|---------|---------|---------|--|
| Weight Value(g)  | 2 + 35  | 35      | 35      |  |
| Initial Check(g) | 35.0000 | 35.0003 | 35.0001 |  |
| Final Check(g)   | 35.0001 | 35.0002 | 35.0000 |  |

|               |         |         |         |  |
|---------------|---------|---------|---------|--|
| Date:         | 9-10-93 | 9-11-93 | 9-12-93 |  |
| Time (24 hr): | 1225    | 1845    | 1050    |  |

[illegible]

# INITIAL FILTER WEIGHING

|                                                                                                                                                             |                           |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|
| Analyst: <u>Cobb</u>                                                                                                                                        | <u>bottom only</u>        |
| Filter Type and Size: <u>85 mm funnel can</u>                                                                                                               | Weight Unit: <u>grams</u> |
| Filter Treatment:                                                                                                                                           |                           |
| <input checked="" type="checkbox"/> Desiccate 24 hours/6 hours between weighings<br><input type="checkbox"/> Oven Treated<br><input type="checkbox"/> Other |                           |

| Balance Check:    |                    |                    |                 |                |
|-------------------|--------------------|--------------------|-----------------|----------------|
| Weight Value(g)   | <u>30</u>          | <u>30</u>          |                 |                |
| Initial Check(g)  | <u>30.0001</u>     | <u>30.0002</u>     |                 |                |
| Final Check(g)    | <u>30.0002</u>     | <u>30.0001</u>     |                 |                |
|                   |                    |                    |                 |                |
| Date:             | <u>8-21-93</u>     | <u>8-22-93</u>     |                 |                |
| Time (24 hr):     | <u>1300</u>        | <u>1230</u>        |                 |                |
| Filter No.        | Weigh No. <u>1</u> | Weigh No. <u>2</u> | Weigh No. _____ | Average        |
| <u>8-20-93- 1</u> | <u>31.6537</u>     | <u>31.6540</u>     |                 | <u>31.6539</u> |
| <u>- 2</u>        | <u>33.9863</u>     | <u>33.9864</u>     |                 | <u>33.9864</u> |
| <u>- 3</u>        | <u>33.5089</u>     | <u>33.5088</u>     |                 | <u>33.5089</u> |
| <u>- 4</u>        | <u>44.7618</u>     | <u>44.7619</u>     |                 | <u>44.7619</u> |
| <u>- 5</u>        | <u>32.8210</u>     | <u>32.8212</u>     |                 | <u>32.8211</u> |
| <u>- 6</u>        | <u>37.6922</u>     | <u>37.6926</u>     |                 | <u>37.6924</u> |
| <u>- 7</u>        | <u>33.4384</u>     | <u>33.4384</u>     |                 | <u>33.4384</u> |
| <u>- 8</u>        | <u>50.2424</u>     | <u>50.2426</u>     |                 | <u>50.2425</u> |
| <u>- 9</u>        | <u>31.5228</u>     | <u>31.5229</u>     |                 | <u>31.5229</u> |
| <u>-10</u>        | <u>36.9209</u>     | <u>36.9209</u>     |                 | <u>36.9209</u> |
| <u>-11</u>        | <u>31.8142</u>     | <u>31.8144</u>     |                 | <u>31.8143</u> |
| <u>-12</u>        | <u>33.8494</u>     | <u>33.8495</u>     |                 | <u>33.8495</u> |
| <u>-13</u>        | <u>33.5561</u>     | <u>33.5561</u>     |                 | <u>33.5561</u> |
| <u>-14</u>        | <u>42.2211</u>     | <u>42.2214</u>     |                 | <u>42.2213</u> |
| <u>-15</u>        | <u>33.9741</u>     | <u>33.9742</u>     |                 | <u>33.9742</u> |
| <u>-16</u>        | <u>31.0860</u>     | <u>31.0861</u>     |                 | <u>31.0861</u> |
| <u>-17</u>        | <u>32.2630</u>     | <u>32.2628</u>     |                 | <u>32.2629</u> |

## FINAL BEAKER WEIGHING

|                                                                                                                    |                    |
|--------------------------------------------------------------------------------------------------------------------|--------------------|
| Project No.: 411992                                                                                                | Analyst: C.H.      |
| Beaker Size: 150 ml                                                                                                | Weight Unit: grams |
| Beaker Treatment:                                                                                                  |                    |
| <input checked="" type="checkbox"/> Desiccate 24 hours/6 hours between weighings<br><input type="checkbox"/> Other |                    |

[illegible]



# INITIAL BEAKER WEIGHING

Analyst: Cobb

Beaker Size: 150 ml

Weight Unit: grams

Beaker Treatment:

☒ Desiccate 24 hours/6 hours between weighings

☐ Other

Balance Check:

|                  |         |         |         |  |
|------------------|---------|---------|---------|--|
| Weight Value(g)  | 70      | 70      | 70      |  |
| Initial Check(g) | 69.9999 | 69.9998 | 69.9998 |  |
| Final Check(g)   | 69.9997 | 70.0000 | 69.9998 |  |

|               |                    |                    |                    |         |
|---------------|--------------------|--------------------|--------------------|---------|
| Date:         | 8-23-93            | 8-24-93            | 8-24-93            |         |
| Time (24 hr): | 1700               | 0820               | 1825               |         |
| Beaker No.    | Weigh No. <u>1</u> | Weigh No. <u>2</u> | Weigh No. <u>3</u> | Average |
| 8-23-18       | 68.3417            | 68.3450            | 68.3422            | →       |
| -19           | 75.2457            | 75.2502            | 75.2472            | →       |
| -20           | 68.9971            | 69.0013            | 68.9991            | →       |
| -21           | 67.5494            | 67.54536           | 67.5508            | →       |
| -22           | 67.7590            | 67.7629            | 67.7614            | →       |
| -23           | 76.3139            | 76.3189            | 76.3159            | →       |
| -24           | 67.6512            | 67.6554            | 67.6531            | →       |
| -25           | 68.2014            | 68.2045            | 68.2028            | →       |
| 8-23-26       | 76.2650            | 76.2688            | 76.2670            | →       |
| -27           | 69.7655            | 69.7691            | 69.7675            | →       |
| -28           | 63.2897            | 63.2934            | 63.2916            | →       |
| -29           | 65.2695            | 65.2725            | 65.2714            | →       |
| -30           | 70.9722            | 70.9754            | 70.9737            | →       |
| -31           | 68.2015            | 68.2052            | 68.2037            | →       |
| -32           | 65.7497            | 65.7540            | 65.7515            | →       |
| -33           | 74.9287            | 74.9315            | 74.9299            | →       |
| 8-23-34       | 69.0180            | 69.0204            | 69.0195            | →       |

# INITIAL BEAKER WEIGHING

Analyst: Cobb

Beaker Size: 150

Weight Unit: grams

Beaker Treatment:

☒ Desiccate 24 hours/6 hours between weighings  
☐ Other

Balance Check:

| Weight Value(g)  | <u>70</u>          | <u>70</u>          | <u>70</u>          |                |
|------------------|--------------------|--------------------|--------------------|----------------|
| Initial Check(g) | <u>69.9997</u>     | <u>69.9999</u>     | <u>69.9997</u>     |                |
| Final Check(g)   | <u>69.9996</u>     | <u>69.9998</u>     | <u>69.9997</u>     |                |
| Date:            | <u>8-25-93</u>     | <u>8-25-93</u>     | <u>8-26-93</u>     |                |
| Time (24 hr):    | <u>0920</u>        | <u>1530</u>        | <u>0930</u>        |                |
| Beaker No.       | Weigh No. <u>4</u> | Weigh No. <u>5</u> | Weigh No. <u>6</u> | Average        |
| <u>8-23-18</u>   | <u>68.3420</u>     | <u>68.3418</u>     |                    | <u>68.3419</u> |
| <u>-19</u>       | <u>75.2464</u>     | <u>75.2461</u>     |                    | <u>75.2463</u> |
| <u>-20</u>       | <u>68.9968</u>     | <u>68.9978</u>     | <u>68.9974</u>     | <u>68.9976</u> |
| <u>-21</u>       | <u>67.5497</u>     | <u>67.5497</u>     |                    | <u>67.5497</u> |
| <u>-22</u>       | <u>67.7601</u>     | <u>67.7601</u>     |                    | <u>67.7601</u> |
| <u>-23</u>       | <u>76.3148</u>     | <u>76.3161</u>     | <u>76.3156</u>     | <u>76.3159</u> |
| <u>-24</u>       | <u>67.6525</u>     | <u>67.6523</u>     |                    | <u>67.6524</u> |
| <u>-25</u>       | <u>68.2013</u>     | <u>68.2020</u>     | <u>68.2016</u>     | <u>68.2018</u> |
| <u>8-23-26</u>   | <u>76.2655</u>     | <u>76.2663</u>     | <u>76.2659</u>     | <u>76.2661</u> |
| <u>-27</u>       | <u>69.7662</u>     | <u>69.7666</u>     |                    | <u>69.7664</u> |
| <u>-28</u>       | <u>63.2900</u>     | <u>63.2907</u>     | <u>63.2907</u>     | <u>63.2907</u> |
| <u>-29</u>       | <u>65.2700</u>     | <u>65.2707</u>     | <u>65.2705</u>     | <u>65.2706</u> |
| <u>-30</u>       | <u>70.9722</u>     | <u>70.9725</u>     |                    | <u>70.9724</u> |
| <u>-31</u>       | <u>68.2022</u>     | <u>68.2021</u>     |                    | <u>68.2022</u> |
| <u>-32</u>       | <u>65.7503</u>     | <u>65.7501</u>     |                    | <u>65.7502</u> |
| <u>-33</u>       | <u>74.9288</u>     | <u>74.9289</u>     |                    | <u>74.9289</u> |
| <u>8-23-34</u>   | <u>69.0180</u>     | <u>69.0181</u>     |                    | <u>69.0181</u> |

**APPENDIX E**  
**PRETEST CALIBRATIONS**

# BAROMETER CALIBRATION SHEET

|                             |         |
|-----------------------------|---------|
| Date                        | 8-15-93 |
| Barometer Number            | #1      |
| Ambient Temperature         | 17.40   |
| Calibrator                  | Ripley  |
| Barometer Reading           | 28.85   |
| Reference Barometer Reading | 28.80   |
| Difference                  | .05     |

Acceptance Criteria: Difference  $\leq$  0.1 inch

# CONSOLE WORKSHEET

NAME Rigdon K FACTOR 5312 PROJECT #             
 DATE 8/16/97 TRAIN ID #4 PREVIOUS Y FACTOR 1.026  
 ORIFICE # 2 PYROMETER #           

## RUN NUMBER

| DGM             | 1             | = | 2             |
|-----------------|---------------|---|---------------|
| FINAL READING   | <u>178,24</u> |   | <u>181,84</u> |
| INITIAL READING | <u>174,80</u> |   | <u>179,40</u> |

## INLET & OUTLET TEMPERATURES

|         |                |                |
|---------|----------------|----------------|
| INITIAL | <u>80 / 79</u> | <u>82 / 80</u> |
| FINAL   | <u>82 / 80</u> | <u>83 / 80</u> |

|                 |                |                |
|-----------------|----------------|----------------|
| TIME Sec        | <u>300</u>     | <u>300</u>     |
| ORIFICE RDG. "E | <u>1.50</u>    | <u>1.50</u>    |
| BAR. PRESSURE   | <u>28.85</u>   | <u>28.85</u>   |
| ROOM TEMP.      | <u>75 / 75</u> | <u>75 / 75</u> |
| PUMP VACUUM Hg" | <u>15"</u>     | <u>15"</u>     |

109

165

CONSOLE CALIBRATION

|                |           |                   |       |
|----------------|-----------|-------------------|-------|
| Project        | 411775    | Orifice number    | 2     |
| Date           | AUG 16 93 | Orifice K factor  | .5312 |
| Operator       | RIGDON    | Previous Y factor | 1.026 |
| Console Number | 4         |                   |       |

|                     | Run 1   | Run 2   |
|---------------------|---------|---------|
| Final DGM Volume    | 178.240 | 181.840 |
| Initial DGM Volume  | 174.800 | 178.400 |
| Net DGM Volume (Vm) | 3.440   | 3.440   |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                      |       |       |
|----------------------|-------|-------|
| In/Out DGM Temp.     |       |       |
| Inlet Deg. F         |       |       |
| initial              | 80.0  | 82.0  |
| final                | 82.0  | 83.0  |
| Outlet Deg. F        |       |       |
| initial              | 79.0  | 80.0  |
| final                | 80.0  | 80.0  |
| Avg. DGM Temp Deg. F | 80.3  | 81.3  |
| Time, sec.           | 300.0 | 300.0 |
| Orifice DH, in. H2O  | 1.50  | 1.50  |
| Baro. Press., in. Hg | 28.85 | 28.85 |
| Room temp., Deg. F   |       |       |
| initial              | 75.0  | 75.0  |
| final                | 75.0  | 75.0  |
| Avg. Room Temp.      | 75.0  | 75.0  |
| Pump Vacuum, in. Hg  | 15    | 15    |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|           |       |       |
|-----------|-------|-------|
| Vcr (std) | 3.313 | 3.313 |
| Vm (std)  | 3.253 | 3.247 |
| Y Factor  | 1.018 | 1.020 |
| Delta H@  | 1.845 | 1.841 |

|                  |       |
|------------------|-------|
| Average Y        | 1.019 |
| Average Delta H@ | 1.843 |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                    |      |
|--------------------|------|
| +/- 2% criteria    |      |
| Percent of Avg Y   | .09  |
|                    | PASS |
| +/- 5% criteria    |      |
| Percent of final Y | .65  |
|                    | PASS |

BRACKETING WORKSHEET

NAME Rigdon K. FACTOR 1. 3199 2. 6405  
PROJECT # \_\_\_\_\_ DATE 8/16/93 TRAIN I.D. #4  
ORIFICE # 1. 4 2. 5

| DCM             | 1             | 2             |
|-----------------|---------------|---------------|
| Final Reading   | <u>184.15</u> | <u>189.17</u> |
| Initial reading | <u>182.10</u> | <u>185.00</u> |
| Difference      | _____         | _____         |

INLET & OUTLET TEMP.

|            |              |              |
|------------|--------------|--------------|
| Initial    | <u>83.80</u> | <u>85.81</u> |
| Final      | <u>85.81</u> | <u>89.84</u> |
| Avg. Temp. | _____        | _____        |

|                 |              |              |
|-----------------|--------------|--------------|
| Time            | <u>300</u>   | <u>300</u>   |
| Orifice rdg. ^H | <u>.55</u>   | <u>2.25</u>  |
| Bar. Pressure   | <u>29.85</u> | <u>29.85</u> |
| Room Temp.      | <u>75.75</u> | <u>75.75</u> |
| Pump Vacuum     | <u>16"</u>   | <u>15</u>    |

ORFICE BRACKETING

|                  |           |                       |    |
|------------------|-----------|-----------------------|----|
| Project          | 962002    | Bracket Orifices:     |    |
| Date             | AUG 16 93 | Orifice No. 1         | 4. |
| Operator         | RIGDON    | Orifice NO.1 K factor | .  |
| Orifice Number   | 4         | Orifice No. 2         | 7. |
| Orifice Y factor | 1.019     | Orifice NO.2 K factor | .  |

|                     |                |              |
|---------------------|----------------|--------------|
|                     | : Orifice #1 : | Orifice #2 : |
| Final DGM Volume    | : 184.150 :    | 189.170 :    |
| Initial DGM Volume  | : 182.100 :    | 185.000 :    |
| Net DGM Volume (Vm) | : 2.050 :      | 4.170 :      |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                      |           |         |   |
|----------------------|-----------|---------|---|
| In/Out DGM Temp.     | :         | :       | : |
| Inlet                | :         | :       | : |
| initial              | : 83.0 :  | 85.0 :  |   |
| final                | : 85.0 :  | 89.0 :  |   |
| Outlet               | :         | :       | : |
| initial              | : 80.0 :  | 81.0 :  |   |
| final                | : 81.0 :  | 82.0 :  |   |
| Avg. DGM Temp        | : 82.3 :  | 84.3 :  |   |
| Time, sec.           | : 300.0 : | 300.0 : |   |
| Orifice DH, in. H2O  | : .55 :   | 2.25 :  |   |
| Baro. Press., in. Hg | : 28.85 : | 28.85 : |   |
| Room temp., Deg. F   | :         | :       | : |
| initial              | : 75.0 :  | 75.0 :  |   |
| final                | : 75.0 :  | 75.0 :  |   |
| Avg. Room Temp.      | : 75.0 :  | 75.0 :  |   |
| Pump Vacuum, in. Hg  | : 16 :    | 15 :    |   |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                     |           |         |   |
|---------------------|-----------|---------|---|
|                     | :         | :       | 0 |
| Vcr (std)           | : 1.995 : | 3.994 : |   |
| Vm (std)            | : 1.927 : | 3.922 : |   |
| Y Factor (brackets) | : 1.035 : | 1.019 : |   |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                 |          |        |   |
|-----------------|----------|--------|---|
| +/- 2% criteria | :        | :      | : |
| Percent of Y    | : 1.62 : | .04 :  |   |
|                 | : PASS : | PASS : |   |



# DRY GAS METER THERMOCOUPLE CALIBRATION SHEET

|            |           |                            |       |
|------------|-----------|----------------------------|-------|
| Date       | 5/16/93   | Thermocouple Number        | # 4   |
| Calibrator | B. Golden | Reference Mercury-In-glass | Astma |
|            |           | Other                      |       |

| Thermocouple | Source         | Reference Thermometer Temperature (°F) | Thermocouple Potentiometer Temperature (°F) | Temperature Difference (°F) |
|--------------|----------------|----------------------------------------|---------------------------------------------|-----------------------------|
| Inlet        | Ambient Air    | 76°                                    | 76                                          | 0°                          |
|              | Hot Water Bath | 132°                                   | 132                                         | 0°                          |
| Outlet       | Ambient Air    | 76°                                    | 77                                          | +1°                         |
|              | Hot Water Bath | 132°                                   | 131°                                        | -1°                         |

• Reference Temperature -- Thermocouple Temperature  $\leq \pm 5.4^\circ\text{F}$

# TYPE S PITOT TUBE CALIBRATION

PITOT # 91AB

|                           |                       |
|---------------------------|-----------------------|
| Calibrator: <u>Rigdon</u> | Project no.: <u></u>  |
| Date: <u>8-15-93</u>      | Probe no.: <u>5-3</u> |

|                                                                    |                                |
|--------------------------------------------------------------------|--------------------------------|
| Pitot Tube Assembly Level? <u>(Y)</u> N                            |                                |
| Pitot Tube Openings Damaged? Y / <u>(N)</u> (If yes explain below) |                                |
| $\alpha^1$ <u>0</u> ° (<10°)                                       | $\beta^1$ <u>0</u> ° (<5°)     |
| $\alpha^2$ <u>0</u> ° (<10°)                                       | $\beta^2$ <u>1</u> ° (<5°)     |
| Y = <u>0</u> O = <u>0</u> A = <u>.923</u> in.                      |                                |
| Z = A sin Y <u>0</u> in. (<1/8 in.)                                |                                |
| W = A sin O <u>0</u> in. (<1/32 in.)                               |                                |
| P <sub>1</sub> <u>.461</u> in.                                     | P <sub>2</sub> <u>.461</u> in. |
| DT = <u>.371</u> in.                                               |                                |
| Calibration Required? Y / <u>(N)</u> (If yes explain below)        |                                |
| Comments:                                                          |                                |

# STACK THERMOCOUPLE CALIBRATION SHEET

Date 8-15-93 Thermocouple Number 5-1 in. Hg  
 Ambient Temp. 28.80  
 F Barometric Pressure 28.80  
 Calibrator Rigdon Reference: mercury-in-glass Astm  
 Other \_\_\_\_\_

| Reference Point Number <sup>a</sup> | Source <sup>b</sup> (Specify) | Reference Thermometer Temperature F | Thermocouple Potentiometer Temperature F | Temperature Difference % |
|-------------------------------------|-------------------------------|-------------------------------------|------------------------------------------|--------------------------|
| 1                                   | Ambient                       | 74.0                                | 75.0                                     | +1.0                     |
| 2                                   | Tube Over                     | 248.0                               | 250                                      | +2.0                     |

<sup>a</sup> Every 50°F for each reference point

<sup>b</sup> Type of calibration system used

<sup>c</sup> (ref temp, °F + 460) - (test thermom temp, °F + 460)

ref temp, °F + 460

100 ≤ 1.5%

# UMBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

|            |         |                             |   |
|------------|---------|-----------------------------|---|
| Date       | 8-22-93 | Thermocouple Number         | 2 |
| Calibrator | B. Wood | Reference: mercury-In-glass |   |
|            |         | Other                       |   |

| Source      | Reference Thermometer Temperature °F | Thermocouple Potentiometer Temperature °F | Temperature Difference °F |
|-------------|--------------------------------------|-------------------------------------------|---------------------------|
| Ambient Air | 90                                   | 91                                        | 1                         |
| Ice Bath    | 39                                   | 39                                        | 0                         |

<sup>a</sup>Reference Temperature - Thermocouple Temperature  $\leq \pm 2^{\circ}\text{F}$

# UMBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

|            |         |                             |   |
|------------|---------|-----------------------------|---|
| Date       | 8-22-93 | Thermocouple Number         | 3 |
| Calibrator | B. Wood | Reference: mercury-in-glass |   |
|            |         | Other                       |   |

| Source                                                                      | Reference Thermometer Temperature °F | Thermocouple Potentiometer Temperature °F | Temperature Difference °F |
|-----------------------------------------------------------------------------|--------------------------------------|-------------------------------------------|---------------------------|
| Ambient Air                                                                 | 91                                   | 91                                        | 0                         |
| Ice Bath                                                                    | 40                                   | 40                                        | 0                         |
| Reference Temperature - Thermocouple Temperature $\leq \pm 2^\circ\text{F}$ |                                      |                                           |                           |

# UNIVERSITY MICROFILMS INTERNATIONAL THERMOCOUPLE CALIBRATION SHEET

|            |         |                             |   |
|------------|---------|-----------------------------|---|
| Date       | 8-22-93 | Thermocouple Number         | 8 |
| Calibrator | B. Wood | Reference: mercury-in-glass |   |
|            |         | Other                       |   |

| Source                                                                                     | Reference Thermometer Temperature<br>F | Thermocouple Potentiometer Temperature<br>F | Temperature Difference <sup>a</sup><br>F |
|--------------------------------------------------------------------------------------------|----------------------------------------|---------------------------------------------|------------------------------------------|
| Ambient Air                                                                                | 92                                     | 91                                          | 1                                        |
| Ice Bath                                                                                   | 40                                     | 39                                          | 1                                        |
| <sup>a</sup> Reference Temperature - Thermocouple Temperature $\leq \pm 2^{\circ}\text{F}$ |                                        |                                             |                                          |

**APPENDIX F**

**POSTTEST CALIBRATIONS**

# CONSOLE WORKSHEET

NAME Rigdon K FACTOR 5312 PROJECT #             
 DATE 9/7/93 TRAIN ID #4 PREVIOUS Y FACTOR 1019  
 ORIFICE #            PYROMETER #           

## RUN NUMBER

DCM

FINAL READING

INITIAL READING

|  |               |   |               |
|--|---------------|---|---------------|
|  | 1             | = | 2             |
|  | <u>866.93</u> |   | <u>870.62</u> |
|  | <u>863.50</u> |   | <u>867.20</u> |

## INLET & OUTLET TEMPERATURES

INITIAL

FINAL

|           |           |           |           |
|-----------|-----------|-----------|-----------|
| <u>64</u> | <u>64</u> | <u>68</u> | <u>64</u> |
| <u>68</u> | <u>64</u> | <u>70</u> | <u>65</u> |

TIME Sec

ORIFICE RDG. "H

BAR. PRESSURE

ROOM TEMP.

PUMP VACUUM "Hg"

|              |              |
|--------------|--------------|
| <u>300</u>   | <u>300</u>   |
| <u>1.55</u>  | <u>1.55</u>  |
| <u>29.20</u> | <u>29.20</u> |
| <u>63</u>    | <u>63</u>    |
| <u>15</u>    | <u>15</u>    |



# BAROMETER CALIBRATION SHEET

|                             |         |
|-----------------------------|---------|
| Date                        | 9-15-93 |
| Barometer Number            | #1      |
| Ambient Temperature         | 72°     |
| Calibrator                  | Rigdon  |
| Barometer Reading           | 29.00   |
| Reference Barometer Reading | 29.05   |
| Difference                  | .05     |

Acceptance Criteria: Difference  $\leq$  0.1 inch

# CONSOLE CALIBRATION

|                |          |                   |       |
|----------------|----------|-------------------|-------|
| Project        | 411775   | Orifice number    | 2     |
| Date           | SEP 7 93 | Orifice K factor  | .5312 |
| Operator       | RIGDON   | Previous Y factor | 1.019 |
| Console Number | 4        |                   |       |

|                     |         |         |
|---------------------|---------|---------|
|                     | Run 1   | Run 2   |
| Final DGM Volume    | 866.930 | 870.620 |
| Initial DGM Volume  | 863.500 | 867.200 |
| Net DGM Volume (Vm) | 3.430   | 3.420   |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                      |       |       |
|----------------------|-------|-------|
| In/Out DGM Temp.     |       |       |
| Inlet Deg. F         |       |       |
| initial              | 64.0  | 68.0  |
| final                | 68.0  | 70.0  |
| Outlet Deg. F        |       |       |
| initial              | 64.0  | 64.0  |
| final                | 64.0  | 65.0  |
| Avg. DGM Temp Deg. F | 65.0  | 66.8  |
| Time, sec.           | 300.0 | 300.0 |
| Orifice DH, in. H2O  | 1.55  | 1.55  |
| Baro. Press., in. Hg | 29.20 | 29.20 |
| Room temp., Deg. F   |       |       |
| initial              | 63.0  | 63.0  |
| final                | 63.0  | 63.0  |
| Avg. Room Temp.      | 63.0  | 63.0  |
| Pump Vacuum, in. Hg  | 15    | 15    |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|           |       |       |
|-----------|-------|-------|
| Vcr (std) | 3.391 | 3.391 |
| Vm (std)  | 3.378 | 3.357 |
| Y Factor  | 1.004 | 1.010 |
| Delta H@  | 1.863 | 1.868 |

|                  |       |
|------------------|-------|
| Average Y        | 1.007 |
| Average Delta H@ | 1.865 |

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE

|                    |      |
|--------------------|------|
| +/- 2% criteria    |      |
| Percent of Avg Y   | .31  |
|                    | PASS |
| +/- 5% criteria    |      |
| Percent of final Y | 1.20 |
|                    | PASS |

GRC 6/8/90

## CONSOLE CALIBRATION

|                |          |                   |       |
|----------------|----------|-------------------|-------|
| Project        | 411775   | Orifice number    | 2     |
| Date           | SEP 7 93 | Orifice K factor  | .5312 |
| Operator       | RIGDON   | Previous Y factor | 1.019 |
| Console Number | 4        |                   |       |

|       |       |
|-------|-------|
| Run 1 | Run 2 |
|-------|-------|

BRACKETING WORKSHEET

NAME Bridon K. FACTOR 1. 3199 2. 6405  
PROJECT # \_\_\_\_\_ DATE 9/7/93 TRAIN I.D. 4#  
ORIFICE # 1. 4 2. 5

DGM

|                 | 1             | 2             |
|-----------------|---------------|---------------|
| Final Reading   | <u>873.61</u> | <u>878.32</u> |
| Initial reading | <u>871.50</u> | <u>874.20</u> |
| Difference      | _____         | _____         |

INLET & OUTLET TEMP.

|                 |              |              |
|-----------------|--------------|--------------|
| Initial         | <u>70.65</u> | <u>71.66</u> |
| Final           | <u>71.66</u> | <u>71.66</u> |
| Avg. Temp.      | _____        | _____        |
| Time            | <u>300</u>   | <u>300</u>   |
| Orifice rdg. ^E | <u>.56</u>   | <u>.25</u>   |
| Bar. Pressure   | <u>29.20</u> | <u>29.20</u> |
| Room Temp.      | <u>64.64</u> | <u>64.64</u> |
| Pump Vacuum     | <u>17"</u>   | <u>16"</u>   |



# DRY GAS METER THERMOCOUPLE CALIBRATION SHEET

|            |           |                            |    |
|------------|-----------|----------------------------|----|
| Date       | 9/17/93   | Thermocouple Number        | #4 |
| Calibrator | B. Gordon | Reference Mercury-In-glass |    |
|            |           | Other                      |    |

| Thermocouple                                                                       | Source         | Reference Thermometer Temperature (°F) | Thermocouple Potentiometer Temperature (°F) | Temperature Difference (°F) |
|------------------------------------------------------------------------------------|----------------|----------------------------------------|---------------------------------------------|-----------------------------|
| Inlet                                                                              | Ambient Air    | 64°                                    | 64°                                         | 0°                          |
|                                                                                    | Hot Water Bath | 134°                                   | 133°                                        | -1°                         |
| Outlet                                                                             | Ambient Air    | 64°                                    | 65°                                         | +1°                         |
|                                                                                    | Hot Water Bath | 134°                                   | 135°                                        | +1°                         |
| • Reference Temperature -- Thermocouple Temperature $\leq \pm 5.4^{\circ}\text{F}$ |                |                                        |                                             |                             |

# TYPE S PITOT TUBE CALIBRATION

PITOT # 9/4/13 (5-3)

|                           |                       |
|---------------------------|-----------------------|
| Calibrator: <u>Rigdon</u> | Project no.:          |
| Date: <u>9-15-93</u>      | Probe no.: <u>5-3</u> |

|                                                                  |                            |
|------------------------------------------------------------------|----------------------------|
| Pitot Tube Assembly Level? <u>(Y)</u> N                          |                            |
| Pitot Tube Openings Damaged? Y <u>(N)</u> (If yes explain below) |                            |
| $\alpha^1$ <u>0</u> ° (<10°)                                     | $\beta^1$ <u>0</u> ° (<5°) |
| $\alpha^2$ <u>0</u> ° (<10°)                                     | $\beta^2$ <u>1</u> ° (<5°) |
| Y = <u>0</u> O = <u>0</u> A = <u>922</u> in.                     |                            |
| Z = A sin Y <u>0</u> in. (<1/8 in.)                              |                            |
| W = A sin O <u>0</u> in. (<1/32 in.)                             |                            |
| P = <u>461</u> in.                                               | P = <u>461</u> in.         |
| DT = <u>372</u> in.                                              |                            |
| Calibration Required? Y / N (If yes explain below)               |                            |
| Comments:                                                        |                            |

# STACK THERMOCOUPLE CALIBRATION SHEET

Date 9-16-93 Thermocouple Number 5-1 29.05 in. Hg  
 Ambient Temp.          F Barometric Pressure           
 Calibrator Rigdon Reference: mercury-in-glass Aster  
         Other         

| Reference Point Number <sup>a</sup> | Source <sup>b</sup> (Specify) | Reference Thermometer Temperature F | Thermocouple Potentiometer Temperature F | Temperature Difference % |
|-------------------------------------|-------------------------------|-------------------------------------|------------------------------------------|--------------------------|
| 1                                   | Ambient                       | 72.0                                | 73.0                                     | 1.4                      |
| 2                                   | Tube Over                     | 240.0                               | 242.0                                    | +2.0                     |

<sup>a</sup> Every 50°F for each reference point

<sup>b</sup> Type of calibration system used

<sup>c</sup> (ref temp, °F + 460) - (test thermom temp, °F + 460)

ref temp, °F + 460

100 < 1.5%

# UNBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

|                |         |                             |      |
|----------------|---------|-----------------------------|------|
| Date           | 9/15/93 | Thermocouple Number         | 2    |
| Calibrated for | Bigelow | Reference: mercury-in-glass | Asst |
|                |         | Other                       |      |

| Source                                                                                   | Reference Thermometer Temperature<br>°F | Thermocouple Potentiometer Temperature<br>°F | Temperature Difference <sup>a</sup><br>°F |
|------------------------------------------------------------------------------------------|-----------------------------------------|----------------------------------------------|-------------------------------------------|
| Ambient Air                                                                              | 72°                                     | 72°                                          | 0°                                        |
| Ice Bath                                                                                 | 33°                                     | 33°                                          | 0°                                        |
| <sup>a</sup> Reference Temperature - Thermocouple Temperature $\leq \pm 2^\circ\text{F}$ |                                         |                                              |                                           |



# UMBILICAL TROOP THERMOCOUPLE CALIBRATION SHEET

|            |         |                             |      |
|------------|---------|-----------------------------|------|
| Date       | 9/15/93 | Thermocouple Number         | 3    |
| Calibrator | Bigelow | Reference: mercury-in-glass | Asma |
|            |         | Other                       |      |

| Source                                                                                     | Reference Thermometer Temperature<br>F | Thermocouple Potentiometer Temperature<br>F | Temperature Difference <sup>a</sup><br>F |
|--------------------------------------------------------------------------------------------|----------------------------------------|---------------------------------------------|------------------------------------------|
| Ambient Air                                                                                | 72°                                    | 72°                                         | 0°                                       |
| Ice Bath                                                                                   | 33°                                    | 32°                                         | -1°                                      |
| <sup>a</sup> Reference Temperature - Thermocouple Temperature $\leq \pm 2^{\circ}\text{F}$ |                                        |                                             |                                          |

# UMBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

|            |         |                             |       |
|------------|---------|-----------------------------|-------|
| Date       | 9-15-93 | Thermocouple Number         | 8     |
| Calibrator | Bigelow | Reference: mercury-in-glass | Astma |
|            |         | Other                       |       |

| Source      | Reference Thermometer Temperature<br>F | Thermocouple Potentiometer Temperature<br>F | Temperature Difference <sup>a</sup><br>F |
|-------------|----------------------------------------|---------------------------------------------|------------------------------------------|
| Ambient Air | 72°                                    | 73°                                         | +1°                                      |
| Ice Bath    | 33°                                    | 33                                          | 0°                                       |

<sup>a</sup>Reference Temperature - Thermocouple Temperature  $\leq \pm 2^{\circ}\text{F}$

**APPENDIX G**  
**PROCESS DATA**

**PARTICULATE EMISSION TEST  
OPERATING DATA**  
(Type of Source)

|             |                   |         |        |
|-------------|-------------------|---------|--------|
| Owner       | SHOFSTALL ALUMINA | Run No. |        |
| Source I.D. |                   | Date    | 9-2-93 |

|                                                              |                       |
|--------------------------------------------------------------|-----------------------|
|                                                              | lbs/hr                |
| Maximum Continuous Process Weight<br>(Manufacturer's Rating) |                       |
| Historical Average Process Weight                            | 26,000 @ 30% Moisture |
| Historical Maximum Process Weight                            | 32,000 @ 30% Moisture |

|                                                                  |                                  |
|------------------------------------------------------------------|----------------------------------|
| Type and Sources of Fuels Normally Burned                        | NATURAL GAS<br>KANSAS - NEBRASKA |
| Approximate Quantities of Each of Above Fuels<br>Burned Annually | 27000 MCF<br>1992                |

|                      |     |    |
|----------------------|-----|----|
|                      | Yes | No |
| Recycling Capability | X   |    |

| Process Data During Run (Averaged) |        |  |
|------------------------------------|--------|--|
| Process Weight (dry)               | lbs/hr |  |
| Percent Moisture                   | %      |  |
| Process Weight (wet)               | lbs/hr |  |
| How Process Weight Determined      |        |  |

|                                |  |
|--------------------------------|--|
| Type of Fuel Burned During Run |  |
|--------------------------------|--|

|                       |     |    |
|-----------------------|-----|----|
|                       | Yes | No |
| Recycling in Progress | X   |    |

Person Responsible for Data: LARRY DUFFEE

Signature: Larry Duffee

Title/Position: Manager

\* Averages of operating data taken during actual test run, unless requested otherwise.

# PROCESS DATA

|                                                        |                         |                                          |                                                         |                                                                   |                       |
|--------------------------------------------------------|-------------------------|------------------------------------------|---------------------------------------------------------|-------------------------------------------------------------------|-----------------------|
| Plant                                                  | SHOFSTALL ALFALFA       |                                          | Location                                                | ODESSA, NE                                                        |                       |
| Source Type                                            |                         |                                          | Rated Production                                        |                                                                   |                       |
| Date                                                   | Time                    |                                          | Actual Production                                       |                                                                   |                       |
| Air Flow Data                                          |                         |                                          |                                                         | Rm No.                                                            |                       |
| Mechanical Collector <u>N/A</u>                        |                         |                                          |                                                         |                                                                   |                       |
| Tube Diameter (in.)                                    |                         | No. of Tubes                             |                                                         | Design $\Delta P$ _____ in. H <sub>2</sub> O @ Gas Temp. _____ °F |                       |
| Observed $\Delta P$ _____ in. H <sub>2</sub> O         |                         |                                          | Design cfm/tube @ Observed $\Delta P$ _____ @ _____ °F  |                                                                   |                       |
| Fan Rated H.P.                                         |                         | Operating Volts                          |                                                         | Operating Amps                                                    |                       |
| Electrostatic Precipitator <u>N/A</u>                  |                         |                                          |                                                         |                                                                   |                       |
| Field No.                                              | Primary Voltage (volts) | Primary Current (amps)                   | Secondary Voltage (kV)                                  | Secondary Current (ma)                                            | Spark Rate (per min.) |
|                                                        |                         |                                          |                                                         |                                                                   |                       |
|                                                        |                         |                                          |                                                         |                                                                   |                       |
|                                                        |                         |                                          |                                                         |                                                                   |                       |
|                                                        |                         |                                          |                                                         |                                                                   |                       |
|                                                        |                         |                                          |                                                         |                                                                   |                       |
| Scrubber <u>N/A</u>                                    |                         |                                          |                                                         |                                                                   |                       |
| Type                                                   |                         |                                          | $\Delta P$ (across scrubber) _____ in. H <sub>2</sub> O |                                                                   |                       |
| Fan Rated H.P.                                         |                         | Operating Volts                          |                                                         | Operating Amps                                                    |                       |
| Liquid Circulation Rate (gal/min)                      |                         | % Make-up                                |                                                         | Blowdown (gpm)                                                    |                       |
| Scrubbing Water Change Interval                        |                         |                                          |                                                         |                                                                   |                       |
| Settling Tank Cleaning Interval                        |                         |                                          |                                                         |                                                                   |                       |
| Baghouse                                               |                         |                                          |                                                         |                                                                   |                       |
| Pressure-Positive                                      | <u>+</u>                | Negative                                 |                                                         | No. Compartments                                                  | <u>144 bags</u>       |
| Type Cleaning                                          |                         |                                          | Clean Cycle (min.)                                      | <u>3</u>                                                          |                       |
| Average Baghouse $\Delta P$ _____ in. H <sub>2</sub> O |                         |                                          | $\Delta P$ Range _____ in. H <sub>2</sub> O             |                                                                   |                       |
| Fan Rated H.P.                                         | <u>100</u>              | Operating Volts                          |                                                         | Operating Amps                                                    |                       |
| Cyclone                                                |                         |                                          |                                                         |                                                                   |                       |
| Type                                                   | <u>2- KICE CK-126</u>   | $\Delta P$ <u>3</u> in. H <sub>2</sub> O |                                                         | Diameter                                                          | <u>10' 6"</u>         |
| Fan Rated H.P.                                         | <u>125</u>              | Operating Volts                          |                                                         | Operating Amps                                                    |                       |

Person Responsible for Data:

LARRY DUFFEE

Signature:

Larry Duffee

Title/Position:

Manager

\*Average of operating data taken during actual test run, unless requested otherwise.

INTER-OFFICE MEMO

TO \_\_\_\_\_ DATE 9-2-93

| Pelle/5   | Green Hay   | SCALE |
|-----------|-------------|-------|
| 9:00 8.0  | 8:30 = 33%  |       |
| 9:15 7.8  | 9:00 = 34%  |       |
| 9:30 7.8  | 10:00 = 33% |       |
| 9:45 7.5  | 11:00 = 35% |       |
| 10:00 7.4 | 12:00 = 33% |       |
| 10:15 7.5 | 1:00 = 33%  |       |
| 10:30 7.3 | 2:00 =      |       |
| 10:45 7.2 | 3:00 =      |       |
| 11:00 7.0 |             |       |
| 11:15 7.1 |             |       |
| 11:30 7.0 |             |       |
| 11:45 7.3 |             |       |
| 12:00 7.5 |             |       |



GREIF BROS. CONTAINERS

INTER-OFFICE MEMO

TO \_\_\_\_\_ DATE \_\_\_\_\_

| Pellets   | SCALE     |
|-----------|-----------|
| 12:15 7.0 | 2:0 = ton |
| 12:30 7.0 | 2.4 = "   |
| 12:45 7.1 | 2.3 = "   |
| 1:00 7.3  | 2.3 = "   |
| 1:15      | = "       |
| 1:30      | = "       |
| 1:45      | = "       |
| 2:00      | = "       |
| 2:15      | = "       |
| 2:30      | = "       |
| 2:45      | = "       |
| 3:00      | = "       |



GREIF BROS. CONTAINERS

# CONSOLIDATED BLENDERS, INC.

## OPERATOR'S REPORT

LANT: **ODESSA**

SHIFT NO. **1**

DATE: **9-2-93**

| HAY CUSTOMER          | CUT NO.               | TIME START  | TIME FINISH | SCALE READ. FINISH | SCALE READ. START | NET WEIGHT |
|-----------------------|-----------------------|-------------|-------------|--------------------|-------------------|------------|
| <b>REICHENEKER #3</b> | <b>3<sup>rd</sup></b> | <b>8:30</b> |             |                    | <b>109125</b>     |            |
|                       |                       |             |             |                    |                   |            |
|                       |                       |             |             |                    |                   |            |
|                       |                       |             |             |                    |                   |            |
|                       |                       |             |             |                    |                   |            |
|                       |                       |             |             |                    |                   |            |
|                       |                       |             |             |                    |                   |            |

### PRODUCT DISPOSITION

| O: (CAR, NO. TRUCK TANK, WAREHOUSE, STORAGE TANK ETC.) | SCALE READ. FINISH | SCALE READ. START | NET WEIGHT |
|--------------------------------------------------------|--------------------|-------------------|------------|
| <b>TANK W</b>                                          |                    | <b>109125</b>     |            |
|                                                        |                    |                   |            |
|                                                        |                    |                   |            |
|                                                        |                    |                   |            |

### DOWN TIME

| DRUM NO.      | TIME OFF | TIME ON     | DOWN TIME | REASON |
|---------------|----------|-------------|-----------|--------|
| <b>TANK W</b> |          | <b>8:30</b> |           |        |
|               |          |             |           |        |
|               |          |             |           |        |
|               |          |             |           |        |


### POLLUTION CONTROL DATA

| TIME: | TOTAL 200 POUND BAGS PRODUCED |           | AVERAGE FURNACE TEMPERATURES |            | AVERAGE DISCHARGE TEMPERATURES |   | MOISTURE CONTENT OF GREEN CHOPPED ALFALFA-% |            | MOISTURE CONTENT OF DEHYDRATED ALFALFA-% |   | PELLET MOISTURE |   | VISUAL OPACITY |   |
|-------|-------------------------------|-----------|------------------------------|------------|--------------------------------|---|---------------------------------------------|------------|------------------------------------------|---|-----------------|---|----------------|---|
|       | 1                             | 2         | 1                            | 2          | 1                              | 2 | 1                                           | 2          | 1                                        | 2 | 1               | 2 | 1              | 2 |
| 7-7   | <b>125</b>                    |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |
| 7-8   |                               |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |
| 7-9   | <b>145</b>                    | <b>20</b> | <b>220</b>                   | <b>170</b> |                                |   |                                             | <b>33%</b> | <b>9.4</b>                               |   | <b>8.0</b>      |   |                |   |
| 7-10  | <b>210</b>                    | <b>65</b> | <b>233</b>                   | <b>183</b> |                                |   |                                             | <b>34%</b> | <b>9.2</b>                               |   | <b>7.8</b>      |   |                |   |
| 7-11  | <b>295</b>                    | <b>85</b> | <b>226</b>                   | <b>180</b> |                                |   |                                             | <b>73%</b> | <b>9.0</b>                               |   | <b>7.4</b>      |   |                |   |
| 7-12  | <b>375</b>                    | <b>80</b> | <b>236</b>                   | <b>208</b> |                                |   |                                             | <b>35%</b> | <b>9.0</b>                               |   | <b>7.3</b>      |   |                |   |
| 2-1   | <b>465</b>                    | <b>90</b> | <b>227</b>                   | <b>200</b> |                                |   |                                             | <b>33%</b> | <b>9.2</b>                               |   | <b>7.0</b>      |   |                |   |
| 2-2   |                               |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |
| 2-3   |                               |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |
| 2-4   |                               |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |
| 2-5   |                               |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |
| 2-6   |                               |           |                              |            |                                |   |                                             |            |                                          |   |                 |   |                |   |

*Edward Myers*


OPERATOR'S SIGNATURE

ELEV. - 4-2723



WILSON A. C. CO.





alfalfa  
Sec. #4  
Ref. #6