

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section Number: 9.10.1.2

Reference Number: 14

Title: Emission Measurement Test Report of
C. E. Boilers, Union Boilers, and Pulp
Dryers - Permit Compliance for SO₂,
Particulate, and PM-10 with Back-
Half Emissions - Holly Sugar
Corporation, Montana Division

The Emission Measurement Group, Inc.

The Emission Measurement Group, Inc.

November 1993

EMISSION MEASUREMENT TEST REPORT

of

C.E. Boilers, Union Boilers & Pulp Dryers
Permit Compliance

for

SO₂, Particulate and PM₁₀ with back-half Emission(s)

C.E. Boilers, Union Boilers, Pulp Dryers
Sidney, Montana Plant, Sidney, MT
Test Date: October 19-23, 1993

Prepared for:

Holly Sugar Corporation
Montana Division

East Holly Street
Sidney, MT 59270

Mr. Tom B. Jacobsen, Environmental Engineer
Phone: 307 532-7141, Ext.: N/A

Submitted to:

Montana State Department of Health and Environmental Sciences
Air Quality Bureau

Room A116
Cogswell Bldg.
Helena, MT 59620

Mr. Brian Hohn, Environmental Specialist
Phone: 406 444-3454

Prepared by:

THE EMISSION MEASUREMENT GROUP, INC.

P.O. Box 4953, ENGLEWOOD, CO 80155-4953
Nationwide Watts: 800-222-4187
Office Phone: 303 693-6725

Report Date: November 16, 1993

CONTENTS OF EMISSION MEASUREMENT TEST REPORT

C.E. Boilers, Union Boilers & Pulp Dryers
for SO₂, Particulate and PM₁₀ with back-half Emission(s)
Sidney, Montana Plant, Sidney, MT

<u>Section</u>	<u>Page</u>
Review, Certification, and Acceptance of Report	
<u>1.0 Introduction and Project Overview</u>	<u>1</u>
1.1 Tables for Section 1.0	2
Table 1-1 AGENCY, COMPANY, and PLANT INFORMATION	3
Table 1-2 REGULATIONS, EMISSION LIMITS, and PRIOR TESTS	5
Table 1-3 EXECUTIVE SUMMARY of RESULTS	7
<u>2.0 Results Summary and Conclusions</u>	<u>9</u>
2.1 Determination of Compliance	9
2.2 Tables for Section 2.0	10
Table 2-1 SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS	11
3.1 Quality Assurance (QA) Documentation	15
3.1.1 Records Reference Document	15
3.1.2 Manual Methods QA	15
3.1.3 Instrumental Methods QA	16
3.1.4 Data Collection and Reduction QA	17
3.1.5 Chain-of-Custody for Data and Sample(s)	18
3.2 Project Activity Log and Personnel	18
3.3 Plant Operation and Production	19
3.4 Location of Test Port(s) and Sampling Point(s)	19
3.5 Sampling and Analytical Procedures and Modifications	19
3.5.1 Description of Sampling Equipment	19
3.5.2 Measurement of Pollutant Emissions	20
3.5.3 Measuring Non-Pollutant Flue Gas Parameters	21
3.5.4 Laboratory Analyses	21
3.6 Detailed Test Results and Discussion	22
3.7 Tables for Section 3.0	24
Table 3-1(a) QA DOCUMENTATION - CALIBRATIONS	25
Table 3-1(b) QA DOCUMENTATION - AUDIT CHECKS	26
Table 3-1(c) QA DOCUMENTATION - QA CHECKS	27
Table 3-1(d) "PROTOCOL ONE" AND QA DOCUMENTATION	28
Table 3-2 PROJECT PERSONNEL	29
Table 3-3 PLANT OPERATION and PRODUCTION, by Run	30
Table 3-4(a) TEST PORT(S) and SAMPLING POINT(S)	31
Table 3-4(b) TEST PORT(S) and SAMPLING POINT(S)	32
Table 3-4(c) TEST PORT(S) and SAMPLING POINT(S)	33
Table 3-4(d) TEST PORT(S) and SAMPLING POINT(S)	34
Table 3-5(a) TEST METHOD SPECIFICATIONS	35
Table 3-5(b) INSTRUMENTAL EQUIPMENT SPECIFICATIONS	36

Table 3-5(CE-E)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	37
Table 3-5(CE-W)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	38
Table 3-5(UB-E)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	39
Table 3-5(UB-W)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	40
Table 3-5(Pulp-NE)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	41
Table 3-5(Pulp-NW)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	42
Table 3-5(Pulp-SE)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	43
Table 3-5(Pulp-SW)	LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS . . .	44
Table 3-6(CE-E)	TEST RESULTS, by RUN	45
Table 3-6(CE-W)	TEST RESULTS, by RUN	47
Table 3-6(Union-E)	TEST RESULTS, by RUN	49
Table 3-6(Union-W)	TEST RESULTS, by RUN	51
Table 3-6(Pulp-NE)	TEST RESULTS, by RUN	53
Table 3-6(Pulp-NW)	TEST RESULTS, by RUN	55
Table 3-6(Pulp-SE)	TEST RESULTS, by RUN	57
Table 3-6(Pulp-SW)	TEST RESULTS, by RUN	59
Table 3-7(CE-E)	SAMPLING and ANALYTICAL DATA, by RUN	61
Table 3-7(CE-W)	SAMPLING and ANALYTICAL DATA, by RUN	63
Table 3-7(Union-E)	SAMPLING and ANALYTICAL DATA, by RUN	65
Table 3-7(Union-W)	SAMPLING and ANALYTICAL DATA, by RUN	67
Table 3-7(Pulp-NE)	SAMPLING and ANALYTICAL DATA, by RUN	69
Table 3-7(Pulp-NW)	SAMPLING and ANALYTICAL DATA, by RUN	71
Table 3-7(Pulp-SE)	SAMPLING and ANALYTICAL DATA, by RUN	73
Table 3-7(Pulp-SW)	SAMPLING and ANALYTICAL DATA, by RUN	75
Figure 3-1(a)	STACK CONFIGURATION and PORT LOCATION(S)	77
Figure 3-1(b)	STACK CONFIGURATION and PORT LOCATION(S)	78
Figure 3-1(c)	STACK CONFIGURATION and PORT LOCATION(S)	79
Figure 3-1(d)	STACK CONFIGURATION and PORT LOCATION(S)	80

4.0 Appendices

4.1 Project Documentation

- 4.1.1 Correspondence
- 4.1.2 Compliance Test Protocol (Title Sheet and Contents)
- 4.1.3 Records Reference Document (Title Sheet and Contents)
- 4.1.4 Project Activities Log

4.2 Quality Assurance Documentation

- 4.2.1 Q.A. Audit Results (if applicable)
- 4.2.2 Post-test Calibrations (if applicable)
- 4.2.3 Chain-of-Custody for Data and Sample(s)

4.3 Plant Operation and Production Data (as available)

4.4 Field Sampling Data Records

- 4.4.1 Data Sheets for Reference Methods
- 4.4.2 Emission Data Printouts from CEM Tests
- 4.4.3 Drift Records for CEM Tests
- 4.4.4 Opacity (if applicable)

4.5 Laboratory Analytical Results

4.6 Calculations and Computer Printouts

CERTIFICATION, REVIEW, and ACCEPTANCE of REPORT

*** This Emission Measurement Compliance Test Report was compiled and prepared by the Project Leader for The Emission Measurement People, Inc., using data collected by The Emission Measurement People, Inc. under contract to the Operating Company, as well as data supplied by the plant operator(s). ***

CERTIFICATION

*** As on site Project Leader for The Emission Measurement People, Inc., I hereby certify that this report and these data are authentic and correct for the emission testing reported here. ***

Project Leader: *Joe R. Hays*

Date: 11-19-93

REVIEW

*** As Technical Operations Director for The Emission Measurement People, Inc., I have reviewed the report for accuracy and completeness and find it acceptable and technically correct. ***

Technical Director: *Paul Hays*

Date: 11/19/93

ACCEPTANCE

*** As a final document, and from my level of involvement, I have reviewed this report and find it accurate, complete, and a fair presentation of the pertinent facts, process records, and emission levels for the subject facility. On behalf of the Operating Company I approve the report for release for purposes of evaluating the compliance status of the facility with applicable air pollution regulations. ***

Signed: _____

Date: _____

Name: _____

Title: _____

1.0 Introduction and Project Overview

The objective of this Emission Measurement Project was to conduct the specified number of valid test runs for certain parameter(s) of the flue gases coming from the plant's specific stack(s) (described in Table 1-1), such that the MT-AQB, listed in Table 1-1, can make a determination as to the compliance status of the facility with applicable air pollution regulations, emission limitations, permit conditions, and/or permit requirements, listed in Table 1-2, below. The Emission Measurement Group, Inc. of Englewood, Colorado have been retained by Holly Sugar Corporation (HSC) to conduct the required air pollution emission tests at the subject plant. This plant may have been tested previously, as given in Table 1-2, in Section 1.1.

Operating Co.: Holly Sugar Corporation
Facility Name: Sidney, Montana Plant
Reg. Agency: MT-AQB
Test Location: Sidney, MT
Test Date: October 19-23, 1993

This Emission Measurement Test Report contains the description of the tests conducted, including quality control checks, original copies of all test data and records, and the final test results and production records during the tests. The major points of this report are organized as follows.

<u>Report Topic</u>	<u>Section No.</u>
Results Summary and Conclusion	2.0
Quality Assurance Documentation	3.1
Plant Operation and Production	3.3
Sampling and Analytical Procedures	3.5
Detailed Test Results and Discussion	3.6
Appendices/Data	4.0

A compliance test protocol (plan) was prepared and sent to the MT-AQB with (or just following) the usual "30-day advance notification to test". The protocol contained critical plant specifications, flue drawing(s), detailed test method descriptions, and the project schedule. It was reviewed, amended (as needed), and approved by the Agency prior to the commencement of testing. There was a short pre-test conference with all key personnel on site just prior to the start of the tests, in order to review the approved test protocol and project plans, and assure concurrence of all parties for testing responsibilities and field schedules, etc. Certain information in the protocol and/or the Records Reference Document (RRD) (described in Section 3.1.1, below) is not repeated in this report, except as it may have changed from the time these documents were issued. Appendix 4.1 contains certain project correspondence and documentation of contents of all related submittals to the MT-AQB, including:

- Transmittal Letters and Project Activities Log,
- Protocol Submittal and Approval,
- Protocol Title Sheet and Contents, and
- Records Reference Document Title Sheet and Contents

Table 1-1
AGENCY, COMPANY, and PLANT INFORMATION

Agency Name: Montana State Department of Health and
Environmental Sciences
Department: Air Quality Bureau
Address/City: Room A116
Cogswell Bldg., Helena, MT 59620
Department Manager: Mr. Jeff Chaffe, Chief, Air Quality Bureau
Observer Contact: Mr. Brian B. Hohn, Environmental Specialist
Phone, AC, No., Ext.: 406 444-3454
Fax: 406 444-1374

Company: Holly Sugar Corporation
Street/City: East Holly Street, Sidney, MT 59270
Mailing/City: P.O. Box 1168, Sidney, MT 59270
Contact/Title: Mr. Tom B. Jacobsen, Environmental Engineer
Phone, AC, No., Ext.: 307 532-7141, Ext.: N/A
Fax: 307 532-4117(WY)/406-482-5892(MT)

Facility Name:	Sidney, Montana Plant
Test Location:	Sidney, MT
Mailing/City:	P.O. Box 1168, Sidney, MT 59270
Contact/Title:	Mr. Gene Thompson, District/Factory Manager
Phone, AC, No., Ext.:	406 482-3303
Directions to Plant:	See Protocol, Appendix 4.1.3
Base Elevation (ft., MSL):	1924
Processes Tested:	C.E. Boilers, Union Boilers & Pulp Dryers
Stack/Duct ID:	C.E. Boiler #1, C.E. Boiler #2
Unit No(s).:	Unit 1 (West) and Unit 2 (East)
Equipment Type:	Combustion Engineering Boilers
Model/S.N.:	
Max. Rated Capacity (MRC):	92500 (Oper.) 95000(Plate)Units: lb/hr steam
Cap. During Tests, % MRC:	>90%
BTU Rate/hr.:	115 MMBTU/hr each boiler
Hours of Operation/Year:	4320 hrs (= 180 days/yr @ 24 hrs/day)

Feed Type:	steam	steam
Coal Stoker Feed Rate:	17400 lbs/hr.	17400 lbs/hr.
Fuel Type:	Lignite Coal	Lignite Coal
F_d , (dscf/ 10^6 BTU):	9900 (O_2)	9900 (O_2)
F_{O_2} , (orsat range):	1.016 - 1.130	1.016 - 1.130

Location:	---- Primary ----	---- Primary ----
Pollutant Removed:	Particulate	SO ₂
Type(s)/Design:	Organ Pipe Dust Collector	Venturi Anderson 2000
	6 OPOWHS No. 8-240	WAV-162
		Separator Anderson 2000
		VES-162

The Emission Measurement Group, Inc.

Table 1-1 - continued
AGENCY, COMPANY, and PLANT INFORMATION

Stack/Duct ID:	Union Boiler #1, Union Boiler #2	
Unit No(s):	Unit 1 (East) and Unit 2 (West)	
Equipment Type:	Union Iron Works	
Model/S.N.:	S.N.: 23418	S.N.: 23001
Max. Rated Capacity (MRC):	100,000 lb/hr steam	60,000 lb/hr steam
Cap. During Tests, % MRC:	>90%	
BTU Rate/hr.:	130 MMBTU/hr	83 MMBTU/hr
Hours of Operation/Year:	4320 hrs (= 180 days/yr @ 24 hrs/day)	

Process Variables:	----- (1) -----	----- (2) -----
Feed Type:	steam	steam
Test Fuel Type	#6 Fuel Oil	#6 Fuel Oil
F_d , (dscf/10 ⁶ BTU):	9220 (O ₂)	9220 (O ₂)
F_o , (orsat range):	1.260-1.413	1.260-1.413

Air Pollution Control Equipment *****

Location: ---- Primary ----
Pollutant Removed: Particulate
Type(s)/Design:

Stack/Duct ID:	Pulp Dryer #1, Pulp Dryer #2	
Unit No(s):	Unit 1 (South) and Unit 2 (North)	
Equipment Type:	Coen Co., Model 200 Series	
Model:	Style DAZ 30	Style DAZ 34
Serial Number:	S.N.: D3940	S.N.: D6909
Max. Rated Capacity (MRC):	48.78 Tons wet pulp input/hr	
Cap. During Tests, % MRC:	>90%	
BTU Rate/hr.:	95 MMBTU/hr	95 MMBTU/hr
Hours of Operation/Year:	4320 hrs (= 180 days/yr @ 24 hrs/day)	

Process Variables:	----- (1) -----	----- (2) -----
Feed Type:	wet beet pulp	wet beet pulp
Test Fuel Type	#6 Fuel Oil	#6 Fuel Oil
F_d , (dscf/10 ⁶ BTU):	9220 (O ₂)	9220 (O ₂)
F_o , (orsat range):	1.260-1.413	1.260-1.413
Alt. Fuel Type:	Nat. Gas	Nat. Gas

Air Pollution Control Equipment *****

Location: ---- Primary ----
Pollutant Removed: Particulate
Type(s)/Design: Dry Scrubber w/ Skimmer fans and cyclones
Model: Mac Equipment

The Emission Measurement Group, Inc.

Table 1-2
REGULATIONS, EMISSION LIMITS, and PRIOR TESTS
C.E. Boilers, Union Boilers & Pulp Dryers

Permit No(s): 1826-01

C.E. Boilers

Parameter: Partic. SO₂

Emission Limit No. 1: 0.10 0.43

Units/Basis: lbs/10⁶BTU lbs/10⁶BTU

Emission Limit No. 2: 0.046 106.8

Units/Basis: gr/dscf TPY

Emission Limit No. 3: 23.0 70%

Units/Basis: lbs/hr Removal Efficiency (based on Total Sulfur in coal)

Results of Prior Tests:

Unit No.:	1		2	
Parameter(s):	Partic.	SO ₂	Partic.	SO ₂
	(w/Backhalf)		(w/Backhalf)	
No. Runs Valid:	3	2	3	3
Results:				
gr/dscf:	0.0320	-	0.0385	-
lbs/10 ⁶ BTU:	0.090	0.124	0.097	0.0482
lbs/hr.:	6.82	-	9.95	-
TPY:	-	56.14	-	40.42
SO ₂ %RE:	-	86.97	-	95.21
Pass:	All Yes		All Yes	

The Emission Measurement Group, Inc.

Table 1-2 - continued
REGULATIONS, EMISSION LIMITS, and PRIOR TESTS
Holly Sugar Corporation
C.E. Boilers, Union Boilers, and Pulp Dryers

Permit No.: 1326-01

	Union Boiler #1	Union Boiler #2
Parameter: ¹	Partic.	Partic.
Emission Limit No. 1:	0.39	.42
Units/Basis:	lbs/10 ⁶ BTU	lbs/10 ⁶ BTU

	Pulp Dryers
Parameter: ¹	Partic.
Emission Limit No. 1:	88.6
Units/Basis:	lbs/hr per both dryer

¹ No SO₂ or PM10 limit but required to test.

The Emission Measurement Group, Inc.

Table 1-3
EXECUTIVE SUMMARY of RESULTS
Holly Sugar Corporation
Sidney, Montana Plant

Unit:	C.E. Boiler East	C.E. Boiler West
Parameter:		
<u>PM-10</u>		
gr./dscf:	0.0311	0.0369
lb./hr.:	6.87	8.52
lbs/10 ⁶ BTU:	0.058	0.078
TPY:	14.83	18.40

Unit:	Union Boiler East	Union Boiler West
Parameter:		
<u>PM-10</u>		
gr./dscf:	0.0525	0.0426
lb./hr.:	7.52	5.00
lbs/10 ⁶ BTU:	0.112	0.092
TPY:	16.24	10.79

<u>Particulate</u>		
gr./dscf:	0.0636	0.0540
lb./hr.:	9.13	6.34
lbs/10 ⁶ BTU:	0.136	0.117
TPY:	19.72	13.69

<u>Sulphur Dioxide</u>		
ppmd:	409.75	403.30
lb./hr.:	69.14	54.98
lbs/10 ⁶ BTU:	1.017	1.017
TPY:	149.33	118.75

The Emission Measurement Group, Inc.

Table 1-3 (Continued)
EXECUTIVE SUMMARY of RESULTS
Holly Sugar Corporation
Sidney, Montana Plant

Unit:	Pulp Dryer North ¹	Pulp Dryer South ¹
Parameter:		
<u>PM-10</u>		
gr./dscf: ²	0.0597	0.1157
lb./hr.:	13.34	38.02
lbs/10 ⁶ BTU: ²	0.379	0.468
TPY:	39.61	82.11
<u>Particulate</u>		
gr./dscf: ²	0.094	0.146
lb./hr.:	26.44	45.03
lbs/10 ⁶ BTU: ²	0.548	0.585
TPY:	57.10	97.27
<u>Sulphur Dioxide</u>		
ppmd: ²	47.82	79.09
lb./hr.:	15.66	28.08
lbs/10 ⁶ BTU: ²	0.310	0.367
TPY:	33.83	60.64

¹ Totals from both stacks on each dryer.

² Weighted average of both stacks on each dryer with respect to DSCFM.

2.0 Results Summary and Conclusions

Table 2-1, in Section 2.2, summarizes the plant production and air pollution emission results for this Emission Measurement Project. The results for this test program are of acceptable quality for purposes of the defined objective of this project (1.0 above, and in Section 1.0 of the protocol). All the procedures for advance Agency notification, test protocol, and quality assurance were applied in this project. All results are presented for each test run in detail in Table 3-6. At least two (2) valid test runs are required (minimum on each stack tested) by the regulations and these were conducted. More may have been conducted as needed to obtain representative results. Any test problems or test (or analytical) method variations for this project are discussed in Section 3.5, below.

All process data and production records for these tests were made by plant personnel and/or the plant process instrumentation system (computer). These data for each test run are presented in Table 3-3 in Section 3.7, and discussed in detail in Section 3.3, below. All emission data were collected by The Emission Measurement Group, Inc. personnel. Copies of all raw project data and records are contained in Appendices 4.3 and 4.4.

There were no major process or test-related upsets or malfunctions during these tests which would cause the results to be unrepresentative of the air pollution emissions of the plant as operated on the date tested. The data should be accepted by the MT-AQB for purposes of the stated test objective, and are valid for confirming the compliance status of the facility with all applicable air pollution emission requirements for which tests have been conducted at this time. This Emission Measurement Test Report has been reviewed and certified above (following the contents page) for accuracy and correctness by project personnel, both from The Emission Measurement Group, Inc., and Holly Sugar Corporation.

2.1 Determination of Compliance

Results in terms of compliance status are given in Section 1.0, of this Emission Measurement Test Report. Any outstanding issues or problems with this compliance determination are specified here.

-- None --

The Emission Measurement Group, Inc.

Table 2-1
SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS
Sidney, Montana Plant

Stack/Duct ID:	C.E. Boiler - East ¹	C.E. Boiler - West
----------------	---------------------------------	--------------------

Plant Process and Production Results *****
Steam Rate, lb./hr.: 84111 83300

PM-10 Emission Results *****
gr./dscf: 0.0311 0.0369
gr./acf: 0.0204 0.0237
lbs./hr.: 6.87 8.52
lbs./10⁶BTU: 0.058 0.078
Tons/Year: 14.83 18.40

Parametric (Non-Pollutant) Flue Gas Results *****
Pressure, Velocity,
Delta P, (in. w.g.): 0.4270 0.4854
Moisture, (% w/w): 21.06 22.20
CO₂, Inst, (% dry, v/v): 13.96 12.41
O₂, Inst., (% dry, v/v): 6.11 7.84
Temp. of Stack, (°F): 138.0 131.6
Velocity, (fps): 40.92 44.01
Vol. Flow, (DSCFM): 25559 27002
Vol. Flow, (ACFM): 39050 41993

¹ Average of all valid test runs, see Tables 3-6 and 3-7.

The Emission Measurement Group, Inc.

Table 2-1 (Continued)
SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS
Sidney, Montana Plant

Stack/Duct ID:	Union Boiler - East ¹	Union Boiler - West
Plant Process and Production Results *****		
Steam Rate, lb./hr.:	77383	52848
Particulate Emission Results *****		
gr./dscf:	0.0485	0.0464
gr./acf:	0.0279	0.0321
lbs./hr.:	6.97	5.44
lbs./10 ⁶ BTU:	0.104	0.101
Tons/Year:	15.05	11.76
PM-10 Emission Results *****		
gr./dscf:	0.0525	0.0426
gr./acf:	0.0301	0.0294
lbs./hr.:	7.52	5.00
lbs./10 ⁶ BTU:	0.112	0.092
Tons/Year:	16.24	10.79
Total Particulate Emission Results *****		
gr./dscf:	0.0636	0.0540
gr./acf:	0.0366	0.0374
lbs./hr.:	9.13	6.34
lbs./10 ⁶ BTU:	0.136	0.117
Tons/Year:	19.72	13.69
Sulfur Dioxide (SO ₂) Emission Results *****		
ppm, (dry, v/v):	409.75	403.3
ppm, (wet, v/v):	380.63	368.72
lbs./hr.:	69.135	54.979
lbs./10 ⁶ BTU:	1.0168	1.0174
Tons/Year:	149.33	118.75
Parametric (Non-Pollutant) Flue Gas Results *****		
Pressure, Velocity,		
Delta P, (in. w.g.):	0.2990	0.1661
Moisture, (% w/w):	7.13	8.58
CO ₂ , Inst, (% dry, v/v):	10.22	10.30
O ₂ , Inst., (% dry, v/v):	8.01	8.22
Temp. of Stack, (°F):	326.6	194.4
Velocity, (fps):	38.62	26.26
Vol. Flow, (DSCFM):	16940	13692
Vol. Flow, (ACFM):	29121	19798

¹ Average of all valid test runs, see Tables 3-6 and 3-7.

The Emission Measurement Group, Inc.

Table 2-1 (Continued)
SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS
Sidney, Montana Plant

Stack/Duct ID:	Pulp Dryer-Northeast ¹	Pulp Dryer-Northwest
Plant Process and Production Results *****		
Feed Rate, TPH:	25	25
Particulate Emission Results *****		
gr./dscf:	0.0691	0.0668
gr./acf:	0.0303	0.0315
lbs./hr.:	9.12	10.06
lbs./10 ⁶ BTU:	0.430	0.361
lbs./Ton:	0.365	0.402
Tons/Year:	19.71	21.73
PM-10 Emission Results *****		
gr./dscf:	0.0651	0.0548
gr./acf:	0.0292	0.0258
lbs./hr.:	9.65	8.69
lbs./10 ⁶ BTU:	0.470	0.298
lbs./Ton:	0.386	0.348
Tons/Year:	20.84	18.77
Total Particulate Emission Results *****		
gr./dscf:	0.0920	0.0964
gr./acf:	0.0403	0.0456
lbs./hr.:	12.19	14.25
lbs./10 ⁶ BTU:	0.580	0.519
lbs./Ton:	0.49	0.57
Tons/Year:	26.32	30.78
Sulfur Dioxide (SO ₂) Emission Results *****		
ppm, (dry, v/v):	48.32	47.37
ppm, (wet, v/v):	29.10	31.11
lbs./hr.:	7.378	8.283
lbs./10 ⁶ BTU:	0.3305	0.2919
lbs./Ton:	0.30	0.33
Tons/Year:	15.94	17.89
Parametric (Non-Pollutant) Flue Gas Results *****		
Pressure, Velocity,		
Delta P, (in. w.g.):	0.1482	0.1616
Moisture, (% w/w):	39.97	34.08
CO ₂ , Inst, (% dry, v/v):	4.41	4.23
O ₂ , Inst., (% dry, v/v):	16.34	15.78
Temp. of Stack, (°F):	209.5	225.4
Velocity, (fps):	27.15	28.26
Vol. Flow, (DSCFM):	15540	17326
Vol. Flow, (ACFM):	35263	36705

¹ Average of all valid test runs, see Tables 3-6 and 3-7.

The Emission Measurement Group, Inc.

Table 2-1 (Continued)
SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS
Sidney, Montana Plant

Stack/Duct ID:	Pulp Dryer-Southeast ¹	Pulp Dryer-Southwest
Plant Process and Production Results *****		
Feed Rate, TPH:	24.8	24.8
Particulate Emission Results *****		
gr./dscf:	0.1085	0.0921
gr./acf:	0.0488	0.0407
lbs./hr.:	16.82	14.33
lbs./10 ⁶ BTU:	0.431	0.372
lbs./Ton:	0.679	0.575
Tons/Year:	36.33	30.95
PM-10 Emission Results *****		
gr./dscf:	0.1218	0.1092
gr./acf:	0.0540	0.0491
lbs./hr.:	19.97	18.05
lbs./10 ⁶ BTU:	0.495	0.440
lbs./Ton:	0.808	0.722
Tons/Year:	43.13	38.98
Total Particulate Emission Results *****		
gr./dscf:	0.1544	0.1372
gr./acf:	0.0699	0.0603
lbs./hr.:	24.54	20.49
lbs./10 ⁶ BTU:	0.614	0.554
lbs./Ton:	0.99	0.83
Tons/Year:	53.01	44.26
Sulfur Dioxide (SO ₂) Emission Results *****		
ppm, (dry, v/v):	78.49	79.74
ppm, (wet, v/v):	49.67	49.54
lbs./hr.:	14.371	13.705
lbs./10 ⁶ BTU:	0.3602	0.3741
lbs./Ton:	0.58	0.55
Tons/Year:	31.04	29.60
Parametric (Non-Pollutant) Flue Gas Results *****		
Pressure, Velocity,		
Delta P, (in. w.g.):	0.1943	0.1804
Moisture, (% w/w):	37.04	37.80
CO, Inst, (% dry, v/v):	5.57	5.55
O ₂ , Inst., (% dry, v/v):	13.94	14.07
Temp. of Stack, (°F):	216.8	239.6
Velocity, (fps):	30.74	30.14
Vol. Flow, (DSCFM):	18327	17175
Vol. Flow, (ACFM):	39930	39146

¹ Average of all valid test runs, see Tables 3-6 and 3-7.

3.0 Technical Discussion

3.1 Quality Assurance (QA) Documentation

General - These Emission Measurement Tests have incorporated the procedures of "The Red Book"--*The U.S. EPA Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III - Stationary Source Specific Methods (# EPA 600/4-77-027b), August, 1977 (as updated)*. Appendix 4.2 of this report contains the post-test equipment calibrations, chain-of-custody for data and sample(s) records and any other data involving quality assurance audit checks which may have been made or requested by the Agency observer(s) during (or after) the tests. Tables 3-1(a-d), in Section 3.7, summarize the pre- and post-test equipment calibration(s) and other quality assurance aspects of the tests. The results of all calibrations and audit checks were well within Agency requirements or guidelines. Complete pre-test calibrations of all test equipment and materials are contained in the Records Reference Document (RRD), discussed below.

3.1.1 Records Reference Document - There are several critical parts of an Emission Measurement Project for verification of data quality. Some of the regulatory specifications, equipment design/schematics and/or calibrations, etc. tend to remain constant for at least a six-month period. These include:

- Pre-test calibrations of test equipment,
- Pre-test tare weights of filter media(e),
- Certification records for calibration gases,
- Forms for recording emission and production data,
- Specifications, schematic(s), and description(s) of test equipment and data reduction software, and
- Agency compliance documentation requirements for the test protocol, emission test report, and quality assurance.

The Emission Measurement Group, Inc. update and compile the repetitive records into a self-contained Records Reference Document. See contents of Records Reference Document in Appendix 4.1.3. As equipment calibrations, etc. are updated in the current Records Reference Document, they are valid for both pre-test records for upcoming projects, and post-test records checks for past projects.

3.1.2 Manual Methods QA

Moisture and Volumetric Flowrate (M2, M4) - Specific QA Considerations are listed below:

1. Pitot tube coefficient (C_p) of 0.84 with geometric specifications for pitotube per M2; otherwise, the pitotube/nozzle recalibrated in a wind tunnel (or test redone, if required); Delta P values <0.05 in. w.g. measured with Dwyer "microtector" (hook gauge), accurate to 0.001 in. w.g.
2. Leak check of orsat analyzer; performance check with ambient air; calculation of F_0 factor (each repetition). See F_0 results in Table 3-7, in Section 3.7, below. Field check of console dry gas meter calibration factor (Y_0) with observer's QA critical flow orifice, if requested. Pitot system leak-check after each test run. Special pre-

test back side leak-check of pump, dry gas meter, T/Cs, orifice, valves, manometer, and orsat bag-fill system, per "Red Book" Section 3.4.2, paragraph 2.1.2 and Method 5, paragraph 5.6.

3. Current equipment calibration data in Records Reference Document. All data available anytime for review and/or copying by Agency or plant.

Annual calibration (or 200 hours) of "Standard Dry Gas Meter" directly against a spirometer. Six month calibration of console dry gas meter rate factor (Y_0) and orifice factor (ΔH_0) against the "Standard Dry Gas Meter", both with triplicate runs at five (5) flow (ΔH) rates (M5, 7.1.1 & 7.1.2). Post-test triplicate calibration check of console dry gas meter rate factor (Y_0) at a single flow near the sampling rate during the tests. Full 5-point re-calibration of the console done if post-test check not within the required 5.0% deviation and 3% range (M5, 5.3.2). All data reduced (by flowrate - tabular and graphically) by computer.

4. Use of Field Micro-Computer (FMC) for data reduction as described in Section 3.1.4, below. Equipment schematic(s) and example data sheets contained in Records Reference Document; 3-part sample labels used, as applicable.

Particulate (M5) - Specific QA Considerations are listed below.

1. Records of evaporation beakers and 3" (90 mm) glass fiber filter(s) tare weights in Records Reference Document.
2. Filter and acetone blank (field & lab) to check handling and analytical procedures. One set (selected at random) offered to the Agency Observer with tare weight(s).
3. Probe(s) and nozzle(s) pre-wash (water and acetone) & dynamic blank (acetone only) on site, to assure clean equipment prior to start of tests. Nozzle(s) diameter specifications rechecked prior to, and after tests.
4. Use of agency analytical forms (including density of acetone). Sample analyses may have been observed at The Emission Measurement Group, Inc. laboratory by advance arrangement with Mr. John Floyd at 303 680-0406.

3.1.3 Instrumental Methods QA - QA procedures are as follows.

1. Analyses of Agency audit gases and/or operation of Agency co-located (and/or redundant) monitor(s), if requested.
2. Use of "Protocol One" certified gases for all calibrations. Certification records available on site, see Table 3-1(d), in Section 3.7.

3. Leak-check of entire system before and after each set of 3 runs of a test.
4. Use of digital DAS (3.1.4 below) to eliminate analog digitizing errors and allow immediate results on site.
5. Performance of 3-point calibration error, interference, bias, and response time tests prior to the project (submitted to Agency in Records Reference Document). These data were verified on site, if requested.
6. 2-point calibration drift checks between runs (example data sheet in Records Reference Document).
7. Calibration checks of instruments at same flow and pressure as sampling (precisely 1.0 Lpm and 10.0" w.g.) to assure consistent, accurate and repeatable system response.

3.1.4 Data Collection and Reduction QA - Among the issues which affect emission data quality for this project, close attention and efficiency in the data reduction and results calculation stages are areas in which virtually all errors should be consistently preventable. Using automated procedures to handle all project data (after they were once recorded and entered into the system manually) has proven to help accomplish a much higher degree of data quality and reporting accuracy. A documentation package for each software subroutine used in this project, as well as a listing of the manual calculations, is contained in the Records Reference Document. Also, due to the digital-based data system used, a chain-of-custody sheet is established for the data, as well as the samples, see Section 3.1.5, below. Specific QA procedure(s) for the two types of data handling for this project are listed below.

Manual Reference Methods QA - To check the software proficiency and repeatability, a "known" set of data accompanied the project run data sets through the entire process from manual data entry in the field through the generation of the report results table(s). The below procedure for automated handling for manual method emission data was followed to assure high precision and accuracy in the data reduction, calculation, and reporting activities.

1. Manually verify and enter all data constants for the project from Table 3-6 of protocol into Field Micro-Computer (FMC) and obtain printout of registers.
2. Manually enter "known" standard run data from data sheet into FMC and save same on magnetic media.
3. Manually record specific test data & variables on a test run data sheet and enter same into FMC as each test run is progressing.
4. At conclusion of each test run, complete leak check and field analytical work, and enter same into FMC. Obtain average(s)/total(s) for each data column on the test run sheet, and obtain optional printout, using Field Thermal Printer (FTP).

5. Save all data for completed test run on hard disk (up to 3 runs) in FMC prior to start of next test run.
6. Complete data recording and entry of test run data for each project test run as in 3 through 5, above.
7. Save field data for all runs (and "known" run) on magnetic media before departure from site (or after each 4 runs, to clear hard disk).
8. Manually record all post-test laboratory analytical activity and/or calibration(s) data on data sheet(s) and enter same into FMC, and save same on magnetic media.
9. Recall all complete data file(s) from magnetic media into FMC and execute "results" subroutines as required by project for each test run and save results on magnetic media. Interface with instrumental methods digital data on magnetic media (as applicable), to obtain gas emission results in proper final units.
10. Recall all results file(s) for each test run (and "known" run) from magnetic media into FMC (with large printer) and compile and print results file table(s) for project report.
11. Compare printed results of "known" run to expected "known" results as a system operational check of the software.

Instrumental Reference Methods QA - Quality assurance for the instrumental methods data reduction is essentially built into the procedures discussed in Section 3.5, below. The data acquisition system (DAS) assures proper digital recording of the analog signal without digitizing errors when manually converting analog strip chart tracings to proper units. The design and operation of this system is discussed in the Records Reference Document. In order to obtain results in proper units (wet ppm, lbs./hr. or lbs./10⁹BTU, etc.), digital concentration gas data are interfaced with other reference method data on magnetic media, as given in paragraph 9, above.

3.1.5 Chain-of-Custody for Data and Sample(s) - A chain-of-custody record for the data and the sample(s) was made and followed throughout the sampling and analysis process. This record shows the when, where, and who, regarding the handling of the critical project samples and data. A copy of this record is contained in Appendix 4.2.2.

3.2 Project Activity Log and Personnel

Table 3-2 provides a listing of all key personnel involved in this project. The tests were observed by the plant and/or third party personnel, as listed. All parties agreed during the testing that, from a plant operation standpoint, as well as the field aspects of sample collection, these emission measurement data should be valid and acceptable for the stated purpose(s) and for evaluating compliance with applicable air pollution emission regulation(s) and/or permit requirement(s).

These tests were conducted by The Emission Measurement Group, Inc. personnel of Englewood, Colorado, whose qualifications and corporate experience are included in Section 5.0 of the Records Reference Document (see Section 3.1.1 and Appendix 4.1.3). A record of the project activities is contained in the Project Activity Log in Appendix 4.1.4.

3.3 Plant Operation and Production

During the emission tests, the plant process operation and production load were at normal operation and the plant was operated at different loads for the different processes tested, as specified in Table 3-6's.

These production data were reported to The Emission Measurement Group, Inc. Project Leader (listed in Table 3-2, in Section 3.7) at the conclusion of all test runs. Copies of the plant operator's recorded production data, taken at the required 20-30 minute intervals (or continuously by plant computerized instrumentation during the tests) are contained in Appendix 4.3, and/or at the plant (if not available for this report).

Specific extraordinary process operational issues (if any) during these tests are discussed here.

-- None --

3.4 Location of Test Port(s) and Sampling Point(s)

Table 3-4 and Figure 3-1, in Section 3.7, describe in detail the flue duct (stack) configuration, the sampling port(s) location(s), and the test point(s) used for this Emission Measurement Project. The test location(s) meet(s) the specifications of EPA Method 1 for straight duct length distance (diameters) before (upstream) and after (downstream) of test ports. No adverse conditions involving the sampling location(s) were present which could artificially affect the magnitude (or representativeness) of the final emission results or the overall quality of the data, except as are noted here.

-- None --

3.5 Sampling and Analytical Procedures and Modifications

Tables 3-5(a-c) (as applicable) summarize(s) the basic test methods and specifications applied during these tests. Any modifications or adjustments in the published EPA Reference Methods applied to these tests are described below.

3.5.1 Description of Sampling Equipment

Flowrate & Moisture (M2, M4) - The sampling equipment used for this project was a system of standard design for M5-type sampling and meets the construction guidelines set out by EPA. The unique features of the equipment are described in Section 3.1 of the Records Reference Document. The amount of moisture trapped on the silica gel was calculated based on Dalton's Law, as described fully in the RRD.

Molecular Weight (M3) - The gas sample for molecular weight, % CO₂ and % O₂ was taken using instruments, see Table 3-5(a).

Particulate (M5) - The equipment was the same as M2 and M4, above, with the addition of the heater elements for the probe and filter, a sample nozzle, probe wash recovery, and filter media.

Instrumental Methods (M3A, and M6C) - The pollutant parameters listed in Table 3-5(b) are all gaseous compounds and were tested using instrumental, real-time (monitor) methods. The portable continuous emission monitor system (PCEMS) used for these tests is described (including schematics) in detail in the Records Reference Document, Section 3.1. The sample was extracted through a stainless-steel probe (heated by the stack gas and considered part of the system's condenser unit when out of the stack) and passed through a glass-lined (or TFE) condenser to remove moisture. No contact was made between the condensed water liquid and the flowing gas, per M20 and M6C. The condenser was fitted with a 3-way valve at the inlet, as required by M6C and M20 for calibration and system bias and leak checks.

The dry sample was then conveyed through TFE line to the remote PCEMS control console. If multiple stacks were tested, one stack was being analyzed while another was being purged for a fresh sample. The gas to be analyzed was regulated for flow and pressure, before being directed to each analyzer in parallel at 1 liter per minute (each) and a precise pressure of 10.0 in. w.g. The analyzers full scale spans (outputs), analytical technique, and instrument serial numbers, as well as the values for low, middle, and high gas calibration points are given in Table 3-5(b).

The computer clock was set to local (plant) time. The analog output of each instrument was 0-1.0 V DC or 4-20 MA, full scale. This signal was converted to a digital signal in a Programmable Logic Controller (PLC) Analog-to-Digital board, before being recorded and processed in a 80386SX computer. Concentration results and clock time of the sample for each parameter were printed out on 8.5 x 11.0 paper at least once each minute during the tests. After each test run, while the post-test gas calibrations were being done, average concentration values for each gaseous pollutant parameter (on magnetic media) were combined with the parametric values for the run (% moisture, volumetric flow, etc.), and the run results (in ppm (wet), ISO standard conditions, lbs./10⁶BTU, and/or lbs./hr., etc.) were calculated and printed before being stored on magnetic media and starting the next run. Software documentation for this procedure is contained in the Records Reference Document, Section 3.3.

3.5.2 Measurement of Pollutant Emissions

Particulate (M5, M201A, M202) - Point-by-point isokinetic values were calculated, recorded and adjusted in the field (as each point was being sampled), sufficiently detailed so as to be suitable for point-by-point Agency audit review. Final isokinetic sampling rates (reported in Table 3-7 in Section 3.7, below) were calculated after each test run following final moisture and orsat analyses. Test method specifications are given in Table 3-5(a) in Section 3.7, below.

Instrumental Methods (M3A, and M6C) - Appendix A of 40 CFR Part 60 contains the instrumental reference methods for SO₂, O₃ and/or CO₂ (Methods 6C, 3A and/or 3A, respectively). Table 3-5(b), below, describes the equipment, instrument spans, and sampling times. Equipment description(s) and schematics are contained in the Method and in the Records Reference Document (Section 3.1).

The sample was extracted through a stainless-steel probe from at least 3 points (1 point, if no pollutant gradient) in the stack for at least 7 minutes per point (minimum 21 sampling minutes over 30 clock minutes per run), as given in Tables 3-5(a and b). Moisture was removed in a "non-contact" chiller/condenser before the sample was pumped through the analyzer(s) in parallel. Calibration of the system was done before and after each set of 3 runs at the zero, mid-scale (40-60%), and up-scale (80-100%) points, and between runs at the zero and mid-scale or up-scale points. Drift test results for each run are presented in Appendix 4.4.3, below. EPA Protocol One certified calibration gases were used, per the Method. Concentration values for the calibration gases are listed in Table 3-1(d), as well as expected stack concentrations. Certification of the calibration gases were contained in the Records Reference Document.

Data was recorded by an automated digital data acquisition system (DAS) at least every 30 seconds. When calculating pounds per hour, the ppm data for each parameter were combined with the flowrate results of Method 2. To obtain ppm (ISO), ppm (at 15% O₂), and/or lbs./10⁶ BTU, the digital O₂ signal was used and the calculations were made after each run. This was done by entering the necessary ancillary data sometime soon after each test, upon reducing the data for flowrate, moisture, etc., in a separate computer.

3.5.3 Measuring Non-Pollutant Flue Gas Parameters

Moisture (M4) - Moisture sampling specifications using EPA Method 4 are described in Table 3-5(a), below. All requirements of this Method were followed, including a constant sample rate of at least 0.53 cfm (ca. 1.0 Delta H) for at least 40 minutes to obtain at least 21.0 scf for the moisture tests, which were at the same points, with the same probe and for the same time as the pollutant tests. Should weather or process problems have prevented the full 40 minutes of sampling, the 21.0 scf may be obtained by using a higher flowrate, above the constant Delta H of at least 1.0. This was done together with Method 5, if applicable (but then at a variable sample rate).

A comparison of the results of moisture collected on the silica gel using Dalton's Law to gravimetric analyses was included in the Records Reference Document. As specified in EPA Method 4, paragraph 2.1.2, Dalton's Law was used to determine the moisture volume collected on the silica gel. This was discussed in the approved protocol.

Oxygen/Carbon Dioxide/Molecular Weight (M3A) - The gas sample for molecular weight was taken using the instrumentation as described above and in Table 3-5(b), the sample was the same as the gaseous pollutant parameters, described in Section 3.5.2, above.

Volumetric Flowrate, Velocity, and Temperature (M2) - These tests were conducted for the same time as the moisture and molecular weight tests, above (except at more points, as required by EPA Methods 1 and 2). Point locations are given in Table 3-4.

3.5.4 Laboratory Analyses

Particulate (M15, M201A, M202) - The analytical procedures for the acetone evaporations and filter weighings for the front-half particulate catches are as provided for in EPA QA Volume III and EPA Method 5, 201A and the back-half in Method 202. The lab data sheet is included in the

Records Reference Document. Specific details of the procedure used are described below. The analyses of the particulate catches are done by The Emission Measurement Group, Inc. at their laboratory in Englewood, Colorado, following the procedures of Method 5, paragraph 4.1.1, 4.2, and 4.3, Method 17, Method 201A and Method 202 which is listed in Appendix section 4.1.2.

A blank filter and a 200-400 ml. field blank acetone sample and a water sample are collected in the field along with the regular run samples. To obtain tare weights, all numbered filters (and cleaned, numbered beakers) are dried at 68°F in a desiccator for at least 24 hours and weighed at 6 hour intervals to 0.10 mg. to a constant weight, i.e., when two consecutive weighings agree within 0.5 mg. as required by the method. These tare weight data are included in the Records Reference Document, Section 4.5, for all filters and beakers to be used in the current 6-month period. Beakers are washed and re-tared before and after each use.

The density of the acetone and the wash volume (from the sample jar label) of each probe/filter bell (and blank) washes are recorded on the lab sheet. The weight of each acetone sample is then calculated (using volume and density) and recorded. The washes are then individually evaporated to dryness at less than the boiling point of acetone (56.2°C) in 250 ml. tared beakers using an infra-red heat lamp. The beakers are then cooled, desiccated, and weighed to a constant weight, as above.

The result of the field blank analysis is given in terms of milligram of blank residue per gram of acetone. By applying the milligram weight of blank residue per gram of acetone to the known grams of acetone in each sample (using the acetone volume and density above), a subtractive blank correction, in milligrams, for each acetone wash sample is determined.

Condensate - The density of the water and the wash volume (from the sample jar label) of each impinger set (and blank) washes are recorded on the lab sheet. The weight of each water sample is then calculated (using volume and density) and recorded. The washes are then individually evaporated to dryness at less than the boiling point of acetone (56.2°C) in 250 ml. tared beakers using an infra-red heat lamp. The beakers are then cooled, desiccated, and weighed to a constant weight, as above.

The result of the field blank analysis is given in terms of milligram of blank residue per gram of water. By applying the milligram weight of blank residue per gram of water to the known grams of water in each sample (using the water volume and density above), a subtractive blank correction, in milligrams, for each water wash sample is determined.

3.6 Detailed Test Results and Discussion

Detailed Test Results - All project data are presented tabularly in Tables. Table 3-3 contains all the plant performance, process operation, air pollution abatement system data, and production records for this project. Table 3-6 contains all the pertinent emission test results for each test run in this project. Performance data (by run) on the sampling and analytical equipment are contained in Table 3-7.

The minimum number of required valid runs were completed on each stack tested, as given in Table 3-5(a). More runs were likely conducted only to assure an acceptable set of representative data. All runs were reported in Tables 3-6 and 3-7, and non-valid runs are noted along with the reasons.

The results of these emission tests are summarized in Table 2-1, in Section 2.2, above. Results in terms of compliance status are given in Section 1.0, above. This project has met the objective as defined in Section 1.0, above.

The Emission Measurement Group, Inc.

Table 3-2
PROJECT PERSONNEL
Holly Sugar Corporation
Reference Methods (w/special)

POSITION	NAME/TITLE	COMPANY/Phone
<u>Company</u> *****		
Coordinator	Tom Jacobsen Environmental Engineer	IHC 307 532-7141
Observer(s)	Gene Thompson District/Factory Manager	HSC 406 482-3303
<u>Regulatory Agency</u> *****		
Administrator	Jeff Chaffe Chief, Air Quality Bureau	MT-AQB 406 444-3454
Observer(s)	Brian Hohn Environmental Specialist	MT-AQB 406 444-3454
<u>Third Party</u> *****		
	None	
<u>Testing Contractor</u> *****		
Project Leader	John R. Floyd President/CEO	The Emission Measurement Group, Inc. 303 680-0406
Technologist(s)	Michael J. Lynn Senior Emission Technician	

The Emission Measurement Group, Inc.

Table 3-3
PLANT OPERATION and PRODUCTION, by Run
Holly Sugar Corporation
Reference Methods (w/special)

Plant Name:	Sidney, Montana Plant
Plant Location:	Sidney, MT

Stack/Duct ID:	C.E. Boiler West		
Run Number:	1101	1102	1103
Plant Production Data (Power/Boiler)	*****		
Steam Flow, (lbs./hr.):	83,882	82,920	83,680
Fuel Flow, (lbs./hr.):	15,099	14,926	15,062

Stack/Duct ID:	C.E. Boiler East		
Run Number:	2101	2102	2103
Plant Production Data (Power/Boiler)	*****		
Steam Flow, (lbs./hr.):	85,047	83,927	83,360
Fuel Flow, (lbs./hr.):	15,308	15,107	15,005

Stack/Duct ID:	Union Boiler West		
Run Number:	3101	3102	3103
Plant Production Data (Power/Boiler)	*****		
Steam Flow, (lbs./hr.):	52,176	53,591	52,778
Fuel Flow, (gal./hr.):	395 (over 3 runs)		

Stack/Duct ID:	Union Boiler East			
Run Number:	4101	4102	4103	4104
Plant Production Data (Power/Boiler)	*****			
Steam Flow, (lbs./hr.):	77,474	78,632	77,424	76,000
Fuel Flow, (gal./hr.):	583 (over 4 runs)			

Stack/Duct ID:	Pulp Dryer South	
Run Number:	5101 & 6101	5102-5104 & 6102-6104
Plant Production Data (Feed Process)	*****	
Feed Rate (TPH):	24	25
Fuel Flow, (gals./hr.): ¹	275	275

Stack/Duct ID:	Pulp Dryer North	
Run Number:	7101-7103 & 8101-8103	
Plant Production Data (Feed Process)	*****	
Feed Rate (TPH):	25	
Fuel Flow, (gals./hr.): ¹	275	

¹ Read explanation of fuel measurement in Appendix 4.3.

The Emission Measurement Group, Inc.

Table 3-4(c)
TEST PORT(S) and SAMPLING POINT(S)
Stack/Duct ID: Union Boiler #2
Holly Sugar Corporation

Stack Configuration:		Round		
Applicable Figure No. in Report:	3-1(c)			
Stack Height, above Grade, (ft.):	50.0			
Height of Test Platform, (ft.):	48.25			
Flow Direction (@ Test Port(s)):	Vertical			
Flue Size(s), Inside Dia., (in.):	48.0			
Outside Dia., (in.): ¹	48.5			
Straight Flue Distance to Test Port:	in.	ft.	Dia(s).	
B, Before:	216.0	18.0	4.50	
A, After:	26.0	2.17	0.54	
Sample Ports: Type:	8-hole			
Description:	Flange			
Size, Dia., (in.):	6			
Nip., Length., (in.):	4			
Quantity Used:	2			
Orientation:	90			
Sample Train / ID:	Partic.	MW/H ₂ O	Flow	
Instruments				
No. of Sample Points				
Total: ²	24	24	24	3
Per Port:	12	12	12	3
Required Probe Length, (in. E.L.):	60	60	60	60
Pitobe ID No.:	60-1	60-1	60-1	Cems
Point(s) / Location(s): ³				
Point No.: %:	Distance to Point from (in.):		Instruments (in.):	
	Near Wall	Roller		
1 / 2.10	1.01	5.01	12.02	
2 / 6.70	3.22	7.22	28.00	
3 / 11.80	5.66	9.66	43.98	
4 / 17.70	8.50	12.50		
5 / 25.00	12.00	16.00		
6 / 35.60	17.09	21.09		
7 / 64.40	30.91	34.91		
8 / 75.00	36.00	40.00		
9 / 82.30	39.50	43.50		
10 / 88.20	42.34	46.34		
11 / 93.30	44.78	48.78		
12 / 97.90	46.99	50.99		

- 1 Including wall thickness and stack wall insulation.
- 2 Half of total points to be on each diameter.
- 3 Distance to point from inside near wall (for each diametric traverse).

The Emission Measurement Group, Inc.

Table 3-4(d)
TEST PORT(S) and SAMPLING POINT(S)
Stack/Duct ID: Pulp Dryer #1 and Pulp Dryer #2
Holly Sugar Corporation

Stack Configuration:	Round		
Applicable Figure No. in Report:	3-1(d)		
Stack Height, above Grade, (ft.):	60.0		
Height of Test Platform, (ft.):	45		
Flow Direction (@ Test Port(s)):	Vertical		
Flue Size(s), Inside Dia., (in.):	63.0		
Outside Dia., (in.): ¹	63.5		
Straight Flue Distance to Test Port:	in.	ft.	Dia(s).
B, Before:	163.0	13.58	2.59
A, After:	81.50	6.79	1.29
Sample Ports: Type:	8-hole		
Description:	Flange		
Size, Dia., (in.):	6		
Nip., Length., (in.):	4		
Quantity Used:	2		
Orientation:	90		

Sample Train / ID:	Partic.	MW/H ₂ O	Flow	
Instruments				
No. of Sample Points				
Total: ²	24	24	24	3
Per Port:	12	12	12	3
Required Probe Length, (in. E.L.):	72	72	72	72
Pitobe ID No.:	96-1	96-1	96-1	Cems
Point(s) / Location(s): ³				

Point No.: %:	Distance to Point from (in.):		Instruments (in.):
	Near Wall	Roller	
1 / 2.10	1.32	5.32	14.52
2 / 6.70	4.22	8.22	35.50
3 / 11.80	7.43	11.43	56.48
4 / 17.70	11.15	15.15	
5 / 25.00	15.75	19.75	
6 / 35.60	22.43	26.43	
7 / 64.40	40.57	44.57	
8 / 75.00	47.25	51.25	
9 / 82.30	51.85	55.85	
10 / 88.20	55.57	59.57	
11 / 93.30	58.78	62.78	
12 / 97.90	61.68	65.68	

- ¹ Including wall thickness and stack wall insulation.
- ² Half of total points to be on each diameter.
- ³ Distance to point from inside near wall (for each diametric traverse).

The Emission Measurement Group, Inc.

Table 3-5(a)
TEST METHOD SPECIFICATIONS
Sidney, Montana Plant
Reference Methods (w/special)

Method Type	<u>Manual</u>	<u>Manual</u>	<u>Manual</u>	<u>Manual</u>
Parameter:	Particulate PM10	MW/H ₂ O	Flow	SO ₂
Method No.(s): ¹	M5, 201A, 202	M3/M4	M2	M6C
Number of Runs: ²	3	3	3	3
Number of Sample Points: ³	24	24	24	3
Sampling Time/Point, (min.):	2.5	2.5	2.5	7
Sampling Time/Run, (min.):	60	60	60	21
Sampling Flowrate, (dscfm):	>.53	>.53	-	-
Sample Volume, (dscf):	>30	>30	-	-
Clock Time/Run, (min.):	70-90	70-90	70-90	30-40
Clock Time/All Runs, (hrs.):	3-5	3-5	3-5	3-5

¹ C.E. Boilers need only PM10. Pulp dryers will be tested consecutively with a few simultaneous Method 5 on stack to same dryer.
² Per stack tested.
³ See point location(s) in Table 3-4.

The Emission Measurement Group, Inc.

Table 3-5(b)
INSTRUMENTAL EQUIPMENT SPECIFICATIONS
Methods M1-M4, M6, M17, M201A, and M202

Parameter	CO ₂	O ₂	SO ₂
Channel No.: ¹	6	1	2
Method No.:	3A	3A	6C
Monitor Type:	Horiba	Horiba	Western Research
Anal. Technique:	NDIR		NDUV
Model No.:			721AT
Serial No.:			1084
In Service:			7/90
Basis/Units:	%(d,v/v)	%(d,v/v)	ppm(d,v/v)
Stack Conc.:	9	9	10-50
Span value, 100 % of Full Scale:	14	21	100
Computer FS Location:	-	23	27
Calibration Points			
Level 1 of Span	Cyl. ID		
M6C M20			
Zero <0.25 <0.25	1-N/C ³	1	1
	1-S/O ⁵		1 1
	Air ⁴		1 1
Low N/A ⁵ 20-30	1-N/C		1 1
	1-S/O 1	1	
Mid 50-60 45-55	2-N/C		1 1
	2-S/O 1	1	
High 80-90 80-90	3-N/C		1 1
	3-S/O 1	1	
	Air ⁶	1	

- ¹ Channel of analog-to-digital data acquisition system.
- ² See certification data in Table 3-1(d), above.
- ³ Use any N/C or S/O cylinder to zero opposite parameters.
- ⁴ Purified air to check high O₂ and/or zero all other parameters.
- ⁵ Only 3 levels required by Section 5.3 of M6C.

The Emission Measurement Group, Inc.

**Table 3-6 (Pulp - NE)
TEST RESULTS, by Run**

Pulp Dryer - Northeast Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Northeast
Equiv.Flue Dia,(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93	
Test Operator, (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.	
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.	
Run ID Number, (VDRR):	8101	8102	8103	AVERAGE
Time- Start, (24hr.):	10:24	16:32	20:02	
- End, (24hr.):	12:38	18:27	22:29	
Time of Test, (t, min.):	100.0	100.0	100.0	100.0
Max. Rtd. Cap.,(TPH,Feed):	48.8	48.8	48.8	48.8
Feed Load, (TPH):	25.0	25.0	25.0	25.0
Test Cond., Feed, (%MRC):	51.25	51.25	51.25	51.25

PARTICULATE RESULTS, (RM5)

gr./dscf:	0.0609	0.0596	0.0868	0.0691
gr./acf:	0.0273	0.0268	0.0367	0.0303
lbs./hr.:	9.03	7.62	10.72	9.12
lbs./10 ⁶ BTU:	0.439	0.296	0.554	0.430
lbs./Ton of Feed:	0.361	0.305	0.429	0.365
Tons/Year:	19.50	16.46	23.16	19.71

The Emission Measurement Group, Inc.

**Table 3-6 (Pulp - NE Continued)
TEST RESULTS, by Run**

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93	
Run ID Number, (VDRR):	8101	8102	8103	AVERAGE

PM-10 RESULTS, (including backhalf)

gr./dscf:	0.0651	N/A	N/A	0.0651
gr./acf:	0.0292	N/A	N/A	0.0292
lbs./hr.:	9.65	N/A	N/A	9.65
lbs./10 ⁶ BTU:	0.470	N/A	N/A	0.470
lbs./Ton of Feed:	0.386	N/A	N/A	0.386
Tons/Year:	20.84	N/A	N/A	20.84

PARTICULATE TOTAL RESULTS (including backhalf)

gr./dscf:	0.0876	0.0680	0.1204	0.0920
gr./acf:	0.0393	0.0305	0.0510	0.0403
lbs./hr.:	12.99	8.69	14.88	12.19
lbs./10 ⁶ BTU:	0.632	0.338	0.769	0.580
lbs./Ton of Feed:	0.52	0.35	0.60	0.49
Tons/Year:	28.07	18.77	32.13	26.32

SO2 RESULTS, (RM6C)

ppm, (dry, v/v):	34.09	70.96	39.93	48.32
ppm, (wet, v/v):	20.96	43.38	22.95	29.10
lbs./hr.:	5.871	10.535	5.729	7.378
lbs./10 ⁶ BTU:	0.2857	0.4094	0.2963	0.3305
lbs./Ton of Feed:	0.23	0.42	0.23	0.30
Tons/Year:	12.68	22.76	12.37	15.94

PARAMETRIC FLUE GAS RESULTS

Pres.Vel.Del.P(in.w.g.):	0.1764	0.1318	0.1364	0.1482
Moisture, (%v/v):	38.50	38.86	42.53	39.97
CO2, Inst., (% dry,v/v):	4.08	4.88	4.26	4.41
O2, Inst., (% dry,v/v):	17.09	15.36	16.59	16.34
Temperature,Stack, (°F):	212.8	208.4	207.2	209.5
Velocity,Flue Gas,(Furl/Ftnt):	29.67	25.57	26.21	27.15
Volume Flow, (DSCFM):	17297	14912	14411	15540
Volume Flow, (ACFM):	38539	33209	34041	35263

The Emission Measurement Group, Inc.

Table 3-6 (Pulp - NW)
TEST RESULTS, by Run

Pulp Dryer - Northwest Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Northwest
Equiv.Flue Dia.(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93	
Test Operator, (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.	
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.	
Run ID Number, (VDRR):	7101	7102	7103	AVERAGE
Time- Start, (24hr.):	10:26	15:18	19:18	
- End, (24hr.):	12:40	17:20	21:57	
Time of Test, (t, min.):	100.0	100.0	100.0	100.0
Max. Rtd. Cap.,(TPH,Feed):	48.8	48.8	48.8	48.8
Feed Load, (TPH):	25.0	25.0	25.0	25.0
Test Cond., Feed, (%MRC):	51.25	51.25	51.25	51.25

PARTICULATE RESULTS, (RM5)

gr./dscf:	0.0524	0.0724	0.0755	0.0668
gr./acf:	0.0250	0.0337	0.0358	0.0315
lbs./hr.:	6.73	11.55	11.89	10.06
lbs./10 ⁶ BTU:	0.276	0.368	0.439	0.361
lbs./Ton of Feed:	0.269	0.462	0.476	0.402
Tons/Year:	14.54	24.95	25.69	21.73

The Emission Measurement Group, Inc.

Table 3-6 (Pulp - NW Continued)
TEST RESULTS, by Run

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93	
Run ID Number, (VDRR):	7101	7102	7103	AVERAGE

PM-10 RESULTS, (including backhalf)

gr./dscf:	N/A	0.0567	0.0529	0.0548
gr./acf:	N/A	0.0264	0.0251	0.0258
lbs./hr.:	N/A	9.05	8.33	8.69
lbs./10 ⁶ BTU:	N/A	0.289	0.307	0.298
lbs./Ton of Feed:	N/A	0.362	0.333	0.348
Tons/Year:	N/A	19.55	17.99	18.77

PARTICULATE TOTAL RESULTS (including backhalf)

gr./dscf:	0.1039	0.0946	0.0908	0.0964
gr./acf:	0.0496	0.0441	0.0431	0.0456
lbs./hr.:	13.35	15.10	14.30	14.25
lbs./10 ⁶ BTU:	0.548	0.481	0.527	0.519
lbs./Ton of Feed:	0.53	0.60	0.57	0.57
Tons/Year:	28.83	32.62	30.88	30.78

SO2 RESULTS, (RM6C)

ppm, (dry, v/v):	39.10	70.56	32.44	47.37
ppm, (wet, v/v):	25.67	45.92	21.74	31.11
lbs./hr.:	5.833	13.083	5.933	8.283
lbs./10 ⁶ BTU:	0.2396	0.4171	0.2189	0.2919
lbs./Ton of Feed:	0.23	0.52	0.24	0.33
Tons/Year:	12.60	28.26	12.82	17.89

PARAMETRIC FLUE GAS RESULTS

Pres.Vel.Del.P(in.w.g.):	0.1188	0.1893	0.1767	0.1616
Moisture, (%v/v):	34.35	34.92	32.98	34.08
CO2, Inst., (% dry,v/v):	4.15	4.60	3.93	4.23
O2, Inst., (% dry,v/v):	15.68	15.49	16.16	15.78
Temperature,Stack, (°F):	216.1	225.9	234.1	225.4
Velocity,Flue Gas,(fps):	24.20	30.78	29.80	28.26
Volume Flow, (DSCFM):	14984	18623	18370	17326
Volume Flow, (ACFM):	31428	39979	38709	36705

The Emission Measurement Group, Inc.

**Table 3-6 (Pulp - SE)
TEST RESULTS, by Run**

Pulp Dryer - Southeast Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Southeast
Equiv.Flue Dia,(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/21/93	10/22/93	10/22/93	10/22/93	
Test Operator, (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.	Lynn, M.	
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.	Floyd, J.	
Run ID Number, (VDRR):	6101	6102	6103	6104	AVERAGE
Time- Start, (24hr.):	20:56	9:34	15:27	19:24	
- End, (24hr.):	21:16	13:36	17:46	21:50	
Time of Test, (t, min.):	20.0	113.5	120.0	120.0	93.4
Max. Rtd. Cap.,(TPH,Feed):	48.8	48.8	48.8	48.8	48.8
Feed Load, (TPH):	24.0	25.0	25.0	25.0	24.8
Test Cond., Feed, (%MRC):	49.20	51.25	51.25	51.25	50.74

PARTICULATE RESULTS, (RM5)

gr./dscf:	0.1306	0.1281	0.0705	0.1047	0.1085
gr./acf:	0.0555	0.0582	0.0374	0.0440	0.0488
lbs./hr.:	15.99	24.34	12.61	14.33	16.82
lbs./10 ⁶ BTU:	0.535	0.518	0.278	0.393	0.431
lbs./Ton of Feed:	0.666	0.974	0.504	0.573	0.679
Tons/Year:	34.54	52.58	27.24	30.96	36.33

The Emission Measurement Group, Inc.

**Table 3-6 (Pulp - SE Continued)
TEST RESULTS, by Run**

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/21/93	10/22/93	10/22/93	10/22/93	
Run ID Number, (VDRR):	6101	6102	6103	6104	AVERAGE

PM-10 RESULTS, (including backhalf)

gr./dscf:	0.0943	0.1494	N/A	N/A	0.1218
gr./acf:	0.0401	0.0679	N/A	N/A	0.0540
lbs./hr.:	11.54	28.40	N/A	N/A	19.97
lbs./10 ⁶ BTU:	0.386	0.605	N/A	N/A	0.495
lbs./Ton of Feed:	0.481	1.136	N/A	N/A	0.808
Tons/Year:	24.92	61.33	N/A	N/A	43.13

PARTICULATE TOTAL RESULTS (including backhalf)

gr./dscf:	0.1582	0.2133	0.1089	0.1372	0.1544
gr./acf:	0.0673	0.0970	0.0577	0.0577	0.0699
lbs./hr.:	19.36	40.55	19.48	18.79	24.54
lbs./10 ⁶ BTU:	0.647	0.863	0.429	0.515	0.614
lbs./Ton of Feed:	0.81	1.62	0.78	0.75	0.99
Tons/Year:	41.82	87.58	42.07	40.59	53.01

SO2 RESULTS, (RM6C)

ppm, (dry, v/v):	71.31	72.19	88.02	82.43	78.49
ppm, (wet, v/v):	42.00	45.29	63.96	47.45	49.67
lbs./hr.:	10.138	15.940	18.292	13.115	14.371
lbs./10 ⁶ BTU:	0.3389	0.3395	0.4030	0.3595	0.3602
lbs./Ton of Feed:	0.42	0.64	0.73	0.52	0.58
Tons/Year:	21.90	34.43	39.51	28.33	31.04

PARAMETRIC FLUE GAS RESULTS

Pres.Vel.Del.P(in.w.g.):	0.1312	0.2825	0.1940	0.1694	0.1943
Moisture, (%v/v):	41.10	37.27	27.34	42.44	37.04
CO2, Inst., (% dry,v/v):	5.32	5.20	5.57	6.18	5.57
O2, Inst., (% dry,v/v):	14.17	14.10	13.92	13.57	13.94
Temperature, Stack, (°F):	222.5	219.4	213.4	211.8	216.8
Velocity, Flue Gas, (fps):	25.86	37.54	30.32	29.26	30.74
Volume Flow, (DSCFM):	14279	22177	20872	15980	18327
Volume Flow, (ACFM):	33584	48757	39378	38003	39930

The Emission Measurement Group, Inc.

**Table 3-6 (Pulp-SW)
TEST RESULTS, by Run**

Pulp Dryer - Southwest Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Southwest
Equiv.Flue Dia,(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/21/93	10/22/93	10/22/93	10/22/93	
Test Operator, (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.	Lynn, M.	
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.	Floyd, J.	
Run ID Number, (VDRR):	5101	5102	5103	5104	AVERAGE
Time- Start, (24hr.):	21:08	9:43	15:24	19:27	
- End, (24hr.):	21:33	13:35	17:43	21:59	
Time of Test, (t, min.):	25.0	110.5	120.0	120.0	93.9
Max. Rtd. Cap.,(TPH,Feed):	48.8	48.8	48.8	48.8	48.8
Feed Load, (TPH):	24.0	25.0	25.0	25.0	24.8
Test Cond., Feed, (%MRC):	49.20	51.25	51.25	51.25	50.74

PARTICULATE RESULTS, (RM5)

gr./dscf:	0.0431	0.0666	0.1409	0.1179	0.0921
gr./acf:	0.0183	0.0283	0.0609	0.0552	0.0407
lbs./hr.:	4.66	9.96	22.30	20.40	14.33
lbs./10 ⁶ BTU:	0.175	0.269	0.594	0.451	0.372
lbs./Ton of Feed:	0.194	0.398	0.892	0.816	0.575
Tons/Year:	10.06	21.51	48.17	44.07	30.95

The Emission Measurement Group, Inc.

Table 3-6 (Pulp-SW Continued)
TEST RESULTS, by Run

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/21/93	10/22/93	10/22/93	10/22/93	
Run ID Number, (VDRR):	5101	5102	5103	5104	AVERAGE

PM-10 RESULTS, (including backhalf)

gr./dscf:	N/A	N/A	0.1154	0.1030	0.1092
gr./acf:	N/A	N/A	0.0499	0.0482	0.0491
lbs./hr.:	N/A	N/A	18.27	17.83	18.05
lbs./10 ⁶ BTU:	N/A	N/A	0.486	0.394	0.440
lbs./Ton of Feed:	N/A	N/A	0.731	0.713	0.722
Tons/Year:	N/A	N/A	39.45	38.51	38.98

PARTICULATE TOTAL RESULTS (including backhalf)

gr./dscf:	0.1276	0.0916	0.1709	0.1585	0.1372
gr./acf:	0.0540	0.0390	0.0739	0.0742	0.0603
lbs./hr.:	13.77	13.71	27.05	27.43	20.49
lbs./10 ⁶ BTU:	0.518	0.370	0.720	0.606	0.554
lbs./Ton of Feed:	0.57	0.55	1.08	1.10	0.83
Tons/Year:	29.74	29.60	58.43	59.25	44.26

SO2 RESULTS, (RM6C)

ppm, (dry, v/v):	72.50	86.83	84.48	75.17	79.74
ppm, (wet, v/v):	44.16	52.20	51.94	49.84	49.54
lbs./hr.:	9.089	15.089	15.532	15.110	13.705
lbs./10 ⁶ BTU:	0.3419	0.4069	0.4137	0.3338	0.3741
lbs./Ton of Feed:	0.38	0.60	0.62	0.60	0.55
Tons/Year:	19.63	32.59	33.55	32.64	29.60

PARAMETRIC FLUE GAS RESULTS

Pres.Vel.Del.P(in.w.g.):	0.1000	0.1928	0.2091	0.2197	0.1804
Moisture, (%v/v):	39.08	39.88	38.51	33.70	37.80
CO2, Inst., (% dry,v/v):	5.45	5.24	5.25	6.27	5.55
O2, Inst., (% dry,v/v):	14.12	14.08	14.37	13.70	14.07
Temperature,Stack, (°F):	248.7	235.9	238.4	235.4	239.6
Velocity,Flue Gas,(fps):	22.89	31.57	32.88	33.22	30.14
Volume Flow, (DSCFM):	12591	17453	18466	20189	17175
Volume Flow, (ACFM):	29735	40999	42701	43148	39146

The Emission Measurement Group, Inc.

**Table 3-7 (Pulp - NE)
SAMPLING and ANALYTICAL DATA, by Run**

Pulp Dryer - Northeast Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Northeast
Equiv.Flue Dia,(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Operator (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.
Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93
Run ID Number, (VDRR):	8101	8102	8103
Time- Start, (24hr.):	10:24	16:32	20:02
- End, (24hr.):	12:38	18:27	22:29
Time of Test, (t, min.):	100.0	100.0	100.0

PROCESS LOAD DATA

Max. Rtd. Cap., (TPH, Feed):	48.8	48.8	48.8
Feed Load, (TPH):	25.0	25.0	25.0
Test Cond., Feed, (%MRC):	51.25	51.25	51.25

SAMPLE VOLUME DATA

Reference Diluent (CO2) %:	12.0	12.0	12.0
Reference Diluent (O2) %:	15.0	15.0	15.0
Console ID #:	CC-2	CC-2	CC-2
Gas Meter ID Number:	6848398	6848398	6848398
Gas Mtr. Cal Factor, (Yo):	0.99650	0.99650	0.99650
Volume, Gas Samp. @ Std. Cond, (dscf):	46.551	38.077	37.750
Corrected for Excess Leak, (acf):	50.476	41.847	40.498
At Meter Conditions, (acf):	50.476	41.847	40.498
Temperature, @ Gas Meter, (°F):	72.10	78.80	66.60
Delta H Pres. @ Meter, (in.w.g.):	1.09	0.80	0.86
Pressure Barometric, Abs., (in.Hg.):	27.825	27.820	27.850
Leak Ck. Result, Post, Excessive, (acf):	0.000	0.000	0.000
Leak Rate Result, (cfm):	0.000	0.000	0.000
At Vacuum, (in. Hg.):	24.00	25.00	25.00
High During Run, (in. Hg.):	15.00	5.80	3.00

The Emission Measurement Group, Inc.

Table 3-7 (Pulp - NE Continued)
SAMPLING and ANALYTICAL DATA, by Run

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93
Run ID Number, (VDRR):	8101	8102	8103

STACK MOISTURE DATA

Press.H2O Vap.@ Saturation,(in.Hg.):	0.2411	0.2586	0.2374
Of Gas @ Silica Gel, (in. Hg.):	19.025	23.620	25.850
Temperature @ Silica Gel Imp., (°F):	39.30	41.10	38.90
Vacuum @ Silica Gel/Pump,(in.Hg.):	8.800	4.200	2.000
Volume H2O @ Silica Gel,(gm):	13.75	9.83	7.97
Condensed H2O @ Impingers,(ml.):	605.0	504.0	585.0
Total Vol. H2O Collected,(ml.):	618.75	513.83	592.97

FLUE GAS MOL. WT. & FLOWRATE DATA

Area of Flue, (sq. ft.):	21.65	21.65	21.65
Pres., Duct, Static, (in. w.g.):	0.00	0.00	0.00
Pitobe ID #:	PM-60	PM-60	PM-60
Pitot ID #:	PM-60	PM-60	PM-60
Pitot Side ID #:	A	A	A
Pitot Coef., (Cp):	0.840	0.840	0.840
Density of Flue Gas, (lb/cf):	0.0647	0.0647	0.0635
Molecular Weight, wet:	24.984	24.980	24.533

PARTICULATE SAMPLING DATA

Isokinetic Sampling Rate, Final,(%):	104.32	98.97	101.53
" Point-by-Point, (Avg., %):	104.40	96.90	94.30
" Point-by-Point, (High, %):	140.30	112.80	106.40
" Point-by-Point, (Low, %):	91.20	50.80	69.60
Filter A ID #:	7492	7490	7497
B ID #:	N/A	N/A	N/A
Nozzle ID #:	PM10-11	PM10-11	PM10-11
Nozzle Diameter, (in.):	0.32000	0.32000	0.32000
Orifice Factor, Del. Ha, (in. w.g.):	1.904	1.904	1.904
Sampling Rate Factor, (K3):	4.29	4.18	4.06

The Emission Measurement Group, Inc.

**Table 3-7 (Pulp - NW)
SAMPLING and ANALYTICAL DATA, by Run**

Pulp Dryer - Northwest Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Northwest
Equiv.Flue Dia,(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Operator (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.
Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93
Run ID Number, (VDRR):	7101	7102	7103
Time- Start, (24hr.):	10:26	15:18	19:18
- End, (24hr.):	12:40	17:20	21:57
Time of Test, (t, min.):	100.0	100.0	100.0

PROCESS LOAD DATA

Max. Rtd. Cap., (TPH, Feed):	48.8	48.8	48.8
Feed Load, (TPH):	25.0	25.0	25.0
Test Cond., Feed, (%MRC):	51.25	51.25	51.25

SAMPLE VOLUME DATA

Reference Diluent (CO2) %:	12.0	12.0	12.0
Reference Diluent (O2) %:	15.0	15.0	15.0
Console ID #:	JC-1	JC-1	JC-1
Gas Meter ID Number:	382459	382459	382459
Gas Mtr. Cal Factor, (Yo):	0.99650	0.99650	0.99650
Volume, Gas Samp. @ Std. Cond. (dscf):	34.178	47.555	46.146
Corrected for Excess Leak, (acf):	37.149	53.029	49.506
At Meter Conditions, (acf):	37.149	53.029	49.506
Temperature, @ Gas Meter, (°F):	72.20	86.20	66.00
Delta H Pres. @ Meter, (in.w.g.):	0.25	0.46	0.43
Pressure Barometric, Abs., (in.Hg.):	27.825	27.820	27.850
Leak Ck.Result, Post, Excessive, (acf):	0.000	0.000	0.000
Leak Rate Result, (cfm):	0.000	0.000	0.000
At Vacuum, (in. Hg.):	23.50	23.50	23.50
High During Run, (in. Hg.):	17.00	5.20	4.00

The Emission Measurement Group, Inc.

**Table 3-7 (Pulp - NW Continued)
SAMPLING and ANALYTICAL DATA, by Run**

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/23/93	10/23/93	10/23/93
Run ID Number, (VDRR):	7101	7102	7103

STACK MOISTURE DATA

Press.H2O Vap.@ Saturation,(in.Hg.):	0.3586	0.3252	0.2392
Of Gas @ Silica Gel, (in. Hg.):	18.425	25.320	25.350
Temperature @ Silica Gel Imp., (°F):	49.70	47.10	39.10
Vacuum @ Silica Gel/Pump,(in.Hg.):	9.400	2.500	2.500
Volume H2O @ Silica Gel,(gm):	15.65	14.65	10.01
Condensed H2O @ Impingers,(ml.):	364.0	527.0	472.0
Total Vol. H2O Collected,(ml.):	379.65	541.65	482.01

FLUE GAS MOL. WT. & FLOWRATE DATA

Area of Flue, (sq. ft.):	21.65	21.65	21.65
Pres., Duct, Static, (in. w.g.):	0.20	0.20	0.20
Pitobe ID #:	60-1	60-2	60-2
Pitot ID #:	60-1	60-2-PM10	60-2-PM10
Pitot Side ID #:	A	A	A
Pitot Coef., (Cp):	0.840	0.840	0.840
Density of Flue Gas, (lb/cf):	0.0659	0.0658	0.0662
Molecular Weight, wet:	25.425	25.403	25.569

PARTICULATE SAMPLING DATA

Isokinetic Sampling Rate, Final,(%):	88.41	98.97	97.37
" Point-by-Point, (Avg., %):	88.70	98.90	99.20
" Point-by-Point, (High, %):	118.00	111.60	114.60
" Point-by-Point, (Low, %):	81.50	94.10	88.50
Filter A ID #:	7493	7489	7496
B ID #:	N/A	N/A	N/A
Nozzle ID #:	10-2	PM10-11	PM10-11
Nozzle Diameter, (in.):	0.32000	0.32000	0.32000
Orifice Factor, Del. Ha, (in. w.g.):	0.940	0.940	0.940
Sampling Rate Factor, (K3):	2.16	2.29	2.21

The Emission Measurement Group, Inc.

**Table 3-7 (Pulp - SE)
SAMPLING and ANALYTICAL DATA, by Run**

Pulp Dryer - Southeast Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Southeast
Equiv.Flue Dia.(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Operator (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.	Lynn, M.
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.	Floyd, J.
Test Date, (mm/dd/yy):	10/21/93	10/22/93	10/22/93	10/22/93
Run ID Number, (VDRR):	6101	6102	6103	6104
Time- Start, (24hr.):	20:56	9:34	15:27	19:24
- End, (24hr.):	21:16	13:36	17:46	21:50
Time of Test, (t, min.):	20.0	113.5	120.0	120.0

PROCESS LOAD DATA

Max. Rtd. Cap., (TPH, Feed):	48.8	48.8	48.8	48.8
Feed Load, (TPH):	24.0	25.0	25.0	25.0
Test Cond., Feed, (%MRC):	49.20	51.25	51.25	51.25

SAMPLE VOLUME DATA

Reference Diluent (CO2) %:	12.0	12.0	12.0	12.0
Reference Diluent (O2) %:	15.0	15.0	15.0	15.0
Console ID #:	CC-2	CC-2	CC-2	CC-2
Gas Meter ID Number:	6848398	6848398	6848398	6848398
Gas Mtr. Cal Factor, (Yo):	0.99650	0.99650	0.99650	0.99650
Volume, Gas Samp. @ Std. Cond, (dscf):	8.719	51.819	27.042	46.895
Corrected for Excess Leak, (acf):	9.165	54.983	29.744	50.673
At Meter Conditions, (acf):	9.165	54.983	29.744	50.673
Temperature, @ Gas Meter, (F):	57.60	62.70	79.70	69.80
Delta H Pres. @ Meter, (in.w.g.):	1.10	1.33	0.92	0.97
Pressure Barometric, Abs., (in.Hg.):	27.920	27.915	27.835	27.810
Leak Ck.Result, Post, Excessive, (acf):	0.000	0.000	0.000	0.000
Leak Rate Result, (cfm):	0.000	0.000	0.000	0.000
At Vacuum, (in. Hg.):	14.00	14.00	14.00	23.50
High During Run, (in. Hg.):	5.00	17.80	2.80	5.80

The Emission Measurement Group, Inc.

Table 3-7 (Pulp - SE)
SAMPLING and ANALYTICAL DATA, by Run

STACK MOISTURE DATA

Press.H2O Vap.@ Saturation,(in.Hg.):	0.2656	0.2430	0.2729	0.2656
Of Gas @ Silica Gel, (in. Hg.):	24.020	21.215	26.135	24.110
Temperature @ Silica Gel Imp., (°F):	41.80	39.50	42.50	41.80
Vacuum @ Silica Gel/Pump,(in.Hg.):	3.900	6.700	1.700	3.700
Volume H2O @ Silica Gel,(gm):	2.18	13.52	6.66	11.98
Condensed H2O @ Impingers,(ml.):	127.0	640.0	209.3	722.0
Total Vol. H2O Collected,(ml.):	129.18	653.52	215.96	733.98

FLUE GAS MOL. WT. & FLOWRATE DATA

Area of Flue, (sq. ft.):	21.65	21.65	21.65	21.65
Pres., Duct, Static, (in. w.g.):	0.00	0.00	0.00	0.00
Pitot ID #:	PM10-60	PM10-60	60-1	60-1
Pitot ID #:	PM10-60	PM10-60	60-1	60-1
Pitot Side ID #:	A	A	A	A
Pitot Coef., (Cp):	0.840	0.840	0.840	0.840
Density of Flue Gas, (lb/cf):	0.0641	0.0652	0.0682	0.0638
Molecular Weight, wet:	24.739	25.162	26.332	24.651

PARTICULATE SAMPLING DATA

Isokinetic Sampling Rate, Final,(%):	133.75	90.19	47.30	107.13
" Point-by-Point, (Avg., %):	80.40	100.00	103.30	94.20
" Point-by-Point, (High, %):	111.20	111.40	114.60	119.00
" Point-by-Point, (Low, %):	99.90	20.20	88.10	87.80
Filter A ID #:	7480	7481	7485	7488
B ID #:	N/A	7484	N/A	N/A
Nozzle ID #:	PM10-10	PM10-10	10.2	10.2
Nozzle Diameter, (in.):	0.30100	0.30100	0.30100	0.30100
Orifice Factor, Del. Ha, (in. w.g.):	1.904	1.904	1.904	1.904
Sampling Rate Factor, (K3):	5.02	3.28	3.30	3.09

The Emission Measurement Group, Inc.

**Table 3-7 (Pulp - SW)
SAMPLING and ANALYTICAL DATA, by Run**

Pulp Dryer - Southwest Sidney, MT

CORPORATE DATA

Company Name:	Holly Sugar Corporation
Division Name:	Montana Division
Plant/Fac. Name:	Sidney, MT
Dept. Name:	Environmental
Contact Name:	Mr. Tom Jacobsen
Contact's Title:	Environmental Engineer
Process Ident./Type:	Sugar Beet Processing
Fuel Type:	#6 Fuel Oil
Fd(dscf gas/10 ⁶ BTU):	9220
Stack/Duct Identifier:	Pulp Dryer - Southwest
Equiv.Flue Dia,(ft.):	5.250
Hrs of Oper./Year:	4320

TEST CONDITIONS

Test Operator (LN,FI):	Lynn, M.	Lynn, M.	Lynn, M.	Lynn, M.
Tech. Helper #1:	Floyd, J.	Floyd, J.	Floyd, J.	Floyd, J.
Test Date, (mm/dd/yy):	10/21/93	10/21/93	10/21/93	10/21/93
Run ID Number, (VDRR):	5101	5102	5103	5104
Time- Start, (24hr.):	21:08	9:43	15:24	19:27
- End, (24hr.):	21:33	13:35	17:43	21:59
Time of Test, (t, min.):	25.0	110.5	120.0	120.0

PROCESS LOAD DATA

Max. Rtd. Cap., (TPH, Feed):	48.8	48.8	48.8	48.8
Feed Load, (TPH):	24.0	25.0	25.0	25.0
Test Cond., Feed, (%MRC):	49.20	51.25	51.25	51.25

SAMPLE VOLUME DATA

Reference Diluent (CO ₂) %:	12.0	12.0	12.0	12.0
Reference Diluent (O ₂) %:	15.0	15.0	15.0	15.0
Console ID #:	JC-1	JC-1	JC-1	JC-1
Gas Meter ID Number:	352648	352648	352648	352648
Gas Mtr. Cal Factor, (Yo):	0.99650	0.99650	0.99650	0.99650
Volume, Gas Samp. @ Std. Cond, (dscf):	8.704	45.704	47.334	54.085
Corrected for Excess Leak, (acf):	9.021	48.808	53.503	58.278
At Meter Conditions, (acf):	9.021	48.808	53.503	58.278
Temperature, @ Gas Meter, (°F):	49.00	64.90	93.80	67.50
Delta H Pres. @ Meter, (in.w.g.):	0.18	0.35	0.36	0.39
Pressure Barometric, Abs., (in. Hg.):	27.915	27.925	27.835	27.810
Leak Ck. Result, Post, Excessive, (acf):	0.000	0.000	0.000	0.000
Leak Rate Result, (cfm):	0.000	0.000	0.000	0.000
At Vacuum, (in. Hg.):	5.00	14.00	23.00	23.50
High During Run, (in. Hg.):	1.50	4.80	4.80	8.00

The Emission Measurement Group, Inc.

**Table 3-7 (Pulp - SW Continued)
SAMPLING and ANALYTICAL DATA, by Run**

TEST CONDITIONS

Test Date, (mm/dd/yy):	10/21/93	10/21/93	10/21/93	10/21/93
Run ID Number, (VDRR):	5101	5102	5103	5104

STACK MOISTURE DATA

Press.H2O Vap.@ Saturation,(in.Hg.):	0.2143	0.2365	0.3015	0.2576
Of Gas @ Silica Gel, (in. Hg.):	26.585	25.525	25.835	23.810
Temperature @ Silica Gel Imp., (°F):	36.30	38.80	45.10	41.00
Vacuum @ Silica Gel/Pump,(in.Hg.):	1.330	2.400	2.000	4.000
Volume H2O @ Silica Gel,(gm):	1.56	9.69	13.41	13.53
Condensed H2O @ Impingers,(ml.):	117.0	634.0	616.0	570.0
Total Vol. H2O Collected,(ml.):	118.56	643.69	629.41	583.53

FLUE GAS MOL. WT. & FLOWRATE DATA




Area of Flue, (sq. ft.):	21.65	21.65	21.65	21.65
Pres., Duct, Static, (in. w.g.):	0.00	0.00	0.00	0.00
Pitobe ID #:	60-1	60-1	60-1	60-1
Pitot ID #:	60-1	60-1	60-1	60-1
Pitot Side ID #:	A	A	A	A
Pitot Coef., (Cp):	0.840	0.840	0.840	0.840
Density of Flue Gas, (lb/cf):	0.0647	0.0644	0.0648	0.0665
Molecular Weight, wet:	24.980	24.868	25.032	25.672

PARTICULATE SAMPLING DATA

Isokinetic Sampling Rate, Final,(%):	139.59	103.82	93.58	97.80
" Point-by-Point, (Avg., %):	172.95	91.60	94.50	104.30
" Point-by-Point, (High, %):	240.00	181.80	127.20	118.60
" Point-by-Point, (Low, %):	105.90	42.50	34.10	94.70
Filter A ID #:	7479	7482	7486	7487
B ID #:	N/A	N/A	N/A	N/A
Nozzle ID #:	9.2	10.2	10.2	10.2
Nozzle Diameter, (in.):	0.28040	0.30100	0.30100	0.30100
Orifice Factor, Del. Ha, (in. w.g.):	0.940	0.940	0.940	0.940
Sampling Rate Factor, (K3):	1.75	1.52	1.50	1.62

The Emission Measurement Group, Inc.


Figure 3-1(a)
STACK CONFIGURATION and PORT LOCATION(S)
C.E. Boilers, Union Boilers & Pulp Dryers
Sidney, Montana Plant



The Emission Measurement Group, Inc.

Figure 3-1(b)
STACK CONFIGURATION and PORT LOCATION(S)
C.E. Boilers, Union Boilers & Pulp Dryers
Sidney, Montana Plant


#1 Boiler 100 K Union East Stack



Union Iron Works
100,000 lbs/hr
250 PSI Max
operate at 200 PSI
S/N 23418
79.52 sq ft Heating Surface

Figure 3-1(c)
STACK CONFIGURATION and PORT LOCATION(S)
C.E. Boilers, Union Boilers & Pulp Dryers
Sidney, Montana Plant


#2 Boiler 60 K Union West Stack



Union Iron Works
60,000 lbs/hr
250 PSI Max
operate at 200 PSI
S/N 23001
5265 sqft Heating Surface

The Emission Measurement Group, Inc.

Figure 3-1(d)
STACK CONFIGURATION and PORT LOCATION(S)
C.E. Boilers, Union Boilers & Pulp Dryers
Sidney, Montana Plant



4.0 Appendices

4.1 Project Documentation

- 4.1.1 Project Correspondence
- 4.1.2 Compliance Test Protocol (Title Sheet and Contents)
- 4.1.3 Records Reference Document (Title Sheet and Contents)
- 4.1.4 Project Activities Log

4.2 Quality Assurance Documentation

- 4.2.1 Q.A. Audit Results (if applicable)
- 4.2.2 Chain-of-Custody for Data and Sample(s)
- 4.2.3 Post-test Calibrations (if applicable)

4.3 Plant Operation and Production Data (as available)

4.4 Field Sampling Data Records

- 4.4.1 Data Sheets for Reference Methods
- 4.4.2 Emission Data Printouts from CEM Tests
- 4.4.3 Drift Records for CEM Tests
- 4.4.4 Opacity Observations (as available)

4.5 Calculations and Computer Printouts

4.6 Laboratory Analytical Results

Appendix 4.3

Plant Operation and Production Data (as Available)

HOLLY SUGAR CORPORATION
SIDNEY, MT FACTORY
OPERATING CONDITIONS

11/10/93

SUMMARY

PULP DRYERS

<u>PULP DRYER No. 1 (South)</u>	<u>TONS WET PULP PER HOUR INPUT</u>	<u>*galbns per hour Fuel Oil Consumed</u>
10-21-93 RUNS 5101 thru 6101	24	275*
10-22-93 RUNS 5102 thru 6104	25	275*
<u>PULP DRYER No. 2 (North)</u>		
10-23-93 RUNS 7101 thru 8103	25	275*

* Data were collected of fuel oil consumed during testing by monitoring elevation changes in the fuel oil storage tank, temperature of the tank, and fuel oil deliveries. All testing was performed with only one unit (2 union boilers + 2 pulp dryers) on fuel oil in an attempt to get accurate information. But calculated fuel oil consumption was highly variable though the process ran steady. Our best estimate of fuel oil consumed is based on recent data on Dryer No. 2 (North) over a number of days of operation with no other units on fuel oil. They had been averaging approx. 275 gph at ≈ 225 TPH slice rate. The same method of tank measurement was employed, but over periods of days rather than hours. Testing was performed at 220 to 224 TPH slice.

PULP DRYER No. 1 (South)

DATE	TIME	BELT COUNTER	WET PULP TO DRYER	FUEL OIL LEVEL READING	FUEL CONSUMED	COMMENTS
10-21-93	1938	—	—	9'5 1/16" @ 46%		
	1947	0211		—		
	2036	0391		—		
	2044	—	—	9'5 1/16" @ 47		
	2151	0668		—		
	2200	—	—	9'6" @ 44		
$(668 - 391) \times .9945 \times .0599 = 16.5 \text{ Tons Dry Pulp}$ $\% \text{ Moisture in dry pulp} = 11.27\%$ $\% \text{ Moisture in wet pulp} = 76.03\%$ $\frac{16.5 \times (1.00 - .1127)}{(1.00 - .7603)} \div \left(\frac{2151 \text{ hrs} - 2036 \text{ hrs}}{75 \text{ min}} \right) \times 60 \text{ min} \div 2 \text{ pulp dryers} = 24 \text{ TPH}$						
(Slice Rate = 220 TPH)						

1. Approx. 50% split on wet pulp to two dryers.
2. WET PULP () = 24 TPH 4.3.3

PULP DRYER No. 1 (South)

DATE	TIME	BELT COUNTER	WET PULP TO DRYER	FUEL OIL LEVEL READING	FUEL CONSUMED	COMMENTS
10-22-93	0941	—	—	9' 4 5/8" @ 4400		
	0954	3268		—		
	1009	3327		—		
	1040	3444		—		15.3 barrels (42 gal.) No. 6 Fuel Oil added to storage.
	1049	—	—	9' 1 7/8" @ 45		
	1151	3707		—		
	1333	4091		—		
	1456	—	—	9' 3 1/2" @ 49		
	1505	4432		—		
	1609	4671		—		
	1630	—	—	9' 4" @ 50		
	1714	4918		—		
	1834	5219		—		
	1938	—	—	9' 5 5/16" @ 47		
	1947	5491		—		
	2112	5812		—		
	2118	—	—	9' 5 15/16" @ 46		
	2214	—	—	9' 6 7/8" @ 46		
	2222	6068		—		
$(6068 - 3268) \times .9945 \times .0599 = 166.8$ Tons Dry Pulp correction factor scale % pulp on beet estimate % Moisture in dry pulp = 10.74% % Moisture in wet pulp = 76.03% $\frac{166.8 \times (1.00 - .1074)}{(1.00 - .7603)} \div (740 \text{ min}) \times 60 \text{ min.} \div 2 \text{ pulp dryers} = 25 \text{ TPH}$ 2222 hrs - 0954 hrs (5/hr Rate = 223 TPH)						

1. Approx. 50% split on wet pulp to two dryers.

2. WET PULP C) = 25 TPH 4.3.4

PULP DRYER No. 2 (North)

DATE	TIME	BELT COUNTER	WET PULP TO DRYER	FUEL OIL LEVEL READING	FUEL CONSUMED	COMMENTS
10-23-93	0830	—	—	9'10 ¹⁵ / ₁₆ " @ 4690		
	0836	8218		—		
	1029	8637		—		fuel oil added to tank (Tech. Services will have quantity).
	1033	—	—	9'2 ¹ / ₈ " @ 49		
	1134	8881		—		
	1235	9112		—		
	1240	—	—	9'2 ⁷ / ₈ " @ 52		
	1350	9396		—		
	1454	9640		—		
	1504	—	—	9'3 ³ / ₄ " @ 47		
	1616	9954		—		
	1713	0173		—		COUNTER TURNED OVER, 46 + 173 = 219.
	1721	—	—	9'4 ¹³ / ₁₆ " @ 48		
	1835	0475		—		
	1900	0566		—		
	1953	0764		—		
	2001	—	—	9'5 ⁹ / ₁₆ " @ 48		
	2056	0999		—		
	2142	1168		—		
	2150	—	—	9'6 ⁷ / ₈ " @ 47		(Slice Rate = 224 TPH)
	$\frac{(1168 - 8637) \times .9945 \times .0599 = 150.77 \text{ Tons Dry Pulp}}{2142 \text{ lbs} - 1029 \text{ lbs}}$ $\frac{150.77 \times (1.00 - .1126)}{(1.00 - .7580)} \div (673 \text{ min}) \times 60 \text{ min} \div 2 \text{ pulp dryers} = 25 \text{ TPH}$					
	$\frac{150.77 \times (1.00 - .1126)}{(1.00 - .7580)} \div (673 \text{ min}) \times 60 \text{ min} \div 2 \text{ pulp dryers} = 25 \text{ TPH}$					

1. Approx. 50% split on wet pulp to two dryers.

2. WET PULP @ = 25 TPH 4.3.5

11/10/43

Union Boilers

Recent attempts at estimating fuel oil consumed during stack testing of the pulp dryers indicate that data collected on fuel oil consumption during testing of the Union Boilers may also be highly variable. The only means the factory has for estimating fuel ~~oil~~ consumption is by measuring of tank level changes by use of a float in the storage tank and chain. This provides good information over long periods of time, but ~~does not~~ appear to be accurate over a short period of time.

The factory switched to fuel oil on each unit (one at a time) for each stack test to better able to measure fuel oil consumption. Consequently we do not have a series of 24 hour days of operation for each fuel oil operated piece of equipment to estimate fuel oil consumption accurately.

10/23/93

HOLLY SUGAR

~~MEMORANDUM~~

The C.E. Boilers were tested at 90% of operating capacity (92,500 LBS/HR Steam).
Name plate capacity = 95,000.

The No. 3 Union Boiler (East) was run at approximately 77% of rated capacity. This unit ~~was~~ tested at conditions above which it is normally operated.

The No. 4 Union Boiler (West) was run at approximately 88% of rated capacity. This unit was tested at conditions above which it is normally operated.

Pulp dryers were tested at approximately 90+% of what is currently expected to be fed to these units based on the beet slicing rate ~~at the factory~~ currently ~~being~~ seen at the factory. It is assumed that approx. 50% of the wet pulp goes to each drier (based on factory personnel knowledge).

OPERATING CONDITION SUMMARY

<u>C.E. BOILERS</u>	<u>LBS/HR STEAM</u>	<u>STEAM % OPERATING CAPACITY</u>	<u>LBS. COAL PER HOUR</u>
No. 1 (WEST)			
RUN 1101	83,882	90.7	15,099
1102	82,920	89.6	14,926
1103	83,680	90.5	15,062

No. 2 (EAST)			
RUN 2101	85,047	91.9	15,308
2102	83,927	90.7	15,107
2103	83,360	90.1	15,005


<u>UNION BOILERS</u>	<u>LBS/HR STEAM</u>	<u>STEAM % OPERATING CAPACITY</u>	<u>FUEL OIL (No. 6) CONSUMED</u>
No. 4 UNION (WEST)			
RUN 3101	52,176	87.0	395 gallons/hour
3102	53,591	89.3	OVER 3 runs.
3103	52,778	88.0	

No. 3 UNION (EAST)			
RUN 4101	77,474	77.5	583 gal./hr.
4102	78,632	78.6	OVER 4 runs
4103	77,424	77.4	
4104	76,000	76.0	

4.3.8

4.4.1

Data Sheets for Reference Methods



5.0 m5

RUN # 5101 DATE 10-21-93		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID JOY Meter ID	
PLANT Pulp Dryers - South		50 www 50 FIELD DATA SHEET		PITOT ID 60-1 PITOT ID 60-1	
DUCT/FLUE Stack UNIT WEST				NOZZLE ID 9-2	
TEST LDR MTL MJL		METHODS - M2, M3, M4, M5		FILTER ID (A) 7479 (B)	
HELPER(S) JRE #2		Client Holly Sugar		ORSAT BAG ID 1st BARCH ID B	

PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS			
Ambient Temp 40	Rel Hum	Weather		STACK TYPE Road	Diameter 63.0	%O2=	
Delta P Level -	Zero: ✓			NO of POINTS 20	Min/Prnt 25.0	%CO2=	
Delta H Level -	Zero: ✓			Pbar 27.92/27.91	P _s 10.20	ppm SO2=	
Pilot Lk. Chk. (-) 0 5	in wg 0 6	in wg		Co 0.84	dn/des 2000.317	ppm NOx=	
Nozzle Leak Rate 0	CFM 23.5	in Hg.		Yo 0.9965	dn(alt) 0.2824	ppm CO=	
Backside Leak Rate 0	CFM 10	in H2O		Delta Ha 0.44	K3 2712.140	MW (sl)=	

ASSUMED VALUES											
DATA SOURCE	Head, Delta P	Delta H, Orifice	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP.	G.MTR	Vac.	ISO
Prev. Test or Estimate	in. H2O	in. H2O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%

POINT -- BY -- POINT DATA														
Location		Time		VELOCITY	DRY GAS METER		SYSTEM TEMPERATURES (Deg. F)						VAC.	RATE
Pctg/Prnt	Sec	Clock	Elap.	Delta P	Inex Rog.	Delta H Orifice	Stack	Probe	Filter	Imp	G.Mtr	Main	ISO	
Lt/No	#	24 Hr.	Min	in. H2O	Cu. Ft.	in. H2O	1	2	3	4	5	in. Hg	%	
START	0	2108	0		422.220	DES	ACT							
A	1	2108	5	0.1		0.175	0.2	246	37			43	1	
	2	2118	10		421.091					250	250		246	
	3	2123	15	0.1	428.79	0.175	0.175	250	36	250	250	51	1.5 105.7	
	4	2128	20	0.1		0.175	0.175	250	36			53	1.5	
	5	2133	25	0.1	432.241	0.175	0.175			250	250			
	6		30							250	250			
	7		35											
	8		40							250	250			
	9		45							250	250			
	10		50											
B	11		55							250	250			
	12		60							250	250			
	13		65											
	14		70							250	250			
	15		75							250	250			
	16		80											
	17		85							250	250			
	18		90							250	250			
	19		95											
	20		100							250	250			
	21													
	22													
	23													
	24													
	25													
TOTALS / AVERAGES		7.25	0.1	9.021				248.7	36.3	X	X	49	1.33	

FINAL LEAK CHECKS				ORSAT			COND. MOISTURE			DALTON'S LAW	
Pilot (+)	@	in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O
Pilot (-)	@	in H2O	1				1	208	100	108	Vapor Pressure
Nozzle Rate	0		2				2	107	100	7	Total ml H2O
in. Hg. Vac.	23.5		3				3	7	0	7	Vw (std)
Leak Cu. Ft.			Avg.				Volume Condensed H2O = 117			FINAL % H2O	
FINAL AVERAGES				V(m)=	Vm (std)=		FINAL Yo @ avg D. H.=			FINAL ISO %=	

TEST LEADER SIGNATURE: Michael R. [Signature] WITNESS: Jay R. [Signature]

6.0

M5

RUN # <u>510</u> DATE <u>10-22-93</u>		THE EMISSION MEASUREMENT GROUP INC. <u>Sydney, MT</u> FIELD DATA SHEET METHODS -- M2, M3, M4, M5 Client <u>MOLLY SUGAR</u>		CONSOLE ID <u>5C-1</u> Meter ID									
PLANT <u>Pulp Dryer - South</u>				PITOT ID <u>60-1</u> PITOT ID <u>60-1</u>									
DUCT/FLUE <u>West</u> UNIT <u>5000</u>				NOZZLE ID <u>10-2</u>									
TEST LDR <u>M5L</u>				FILTER ID (A) <u>7482</u> (B)									
HELPER(S) <u>JRF</u> #2		ORSAT BAG ID <u>inst.</u> BAROM ID <u>B</u>											
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS									
Ambient Temp <u>40-70</u> Rel Hum <u>10-15</u> Weather <u>Clear</u>				STACK TYPE <u>Round</u> Diameter <u>63.0</u> %O2= <u>15.5</u>									
Delta P Level <u>Zero</u>				NO. of POINTS <u>20</u> Min/Pnt <u>6.0</u> %CO2= <u>4.1</u>									
Delta H Level <u>Zero</u>				Phar <u>27.96/27.87</u> Ps <u>27.96/27.87</u> ppm SO2= <u>55</u>									
Pilot Lk Chk. (+) <u>0.55</u> in wg (-) <u>0.60</u> in wg				Co <u>0.84</u> dnices <u>0.387</u> ppm NOx= <u>-</u>									
Nozzle Leak Rate <u>0</u> CFM @ <u>23.5</u> in Hg				Yo <u>0.9965</u> dnices <u>30</u> ppm CO= <u>-</u>									
Backside Leak Rate <u>0.0</u> CFM @ <u>10</u> in H2O				Delta Hs <u>0.94</u> K3 <u>1.517</u> MW (s)= <u>-</u>									
504 WEST ASSUMED VALUES													
DATA SOURCE		Head, Delta P	Delta H, Orifice	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP	G.MTR	Vac.	ISO	
Prev. Test or Estimate		in. H2O	in. H2O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%	
<u>SW</u> POINT -- BY -- POINT DATA <u>SW</u>													
Location		Time	VELOCITY	DRY GAS METER			SYSTEM TEMPERATURES (Deg F)					VAC	RATE
Port/Pnt	Seq	Clock	Elap	Delta P	Index Rdg.	Delta H Orifice	Stack	Probe	Filter	Imp	G Mtr	Main	ISO
Lv/No.	#	24 Hr	Min	in. H2O	Cu. Ft.	in. H2O	1	2	3	4	8	in. Hg	%
START	0	0943	0		2467.298	DES	ACT						
A	1	0949	6	0.1	2468.06	0.152	0.15	247		33	45	1	42.2
	2	0955	12	0.1	2471.36	0.152	0.25	252	250	35	49	1	181.8
	3	1001	18	0.1	2472.53	0.152	0.2	253		35	51	1.0	119.2
	4	1007	24	0.1	2475.62	0.152	0.18	250	250	34	51	1	114.5
	5	1013	30	0.12	2477.69	0.182	0.18	255		34	53	1.2	103.5
	6	1019	36	0.25	2480.47	0.379	0.38	240	250	35	54	2	95.2
	7	1025	42	0.37	2484.01	0.581	0.55	215		34	56	4	97.2
	8	1031	48	0.50	2488.02	0.758	0.75	217	250	34	58	4	74.8
	9	1037	54	0.55	2492.526	0.834	0.8	212		34	58.5	4.5	76.6
	10	1045	60	0.50	2496.504	0.758	0.75	212	250	36	58.5	4.2	98.3
B	11	1245	66	0.25	2497.56	0.379	0.4	241		48	66	3	102.3
	12	1257	72	0.17	2501.98	0.258	0.25	243	250	44	71	2	97.4
	13	1303	78	0.17	2504.33	0.258	0.25	244		46	74	2	94.1
	14	1309	84	0.06	2505.69	0.091	0.1	250	250	47	77	1	91.5
	15	1315	90	0.04	2506.51	0.061	0.06	250		44	79.5	1	87.3
	16	1321	96	0.15	2508.65	0.228	0.25	222	250	41	80.5	2	88.7
	17	1327	102	0.15	2511.02	0.228	0.25	237		41	82.5	2	99.0
	18	1333	108	0.35	2514.54	0.531	0.5	225	250	42	84	4	95.2
end	19	1335.5	114	0.45	2516.100	0.683	0.7	221		41	83.5	4.8	70
	20		120					250	250				
	21												
	22												
	23												
	24												
	25												
TOTALS / AVERAGES		110.5	1028	48.808		0.748	275.9	X	X	38.8	649	2.4	91.6
FINAL LEAK CHECKS		ORSAT			COND. MOISTURE			DALTON'S LAW					
Pilot (+) <u>0</u> @ <u>6.0</u> in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O <u>9.7</u>				
Pilot (-) <u>0</u> @ <u>6.0</u> in H2O	1				1	250.156	120	30.6	Vapor Pressure <u>229.2/238.3</u>				
Nozzle Rate <u>0.0</u>	2				2	250	100	150	Total ml H2O <u>643.7</u>				
in. Hg. Vac. <u>14</u>	3				3	178	0	178	Vw (std)				
Leak Cu. Ft.	Avg.				Volume Condensed H2O = <u>6.70</u>				FINAL % H2O <u>29.91</u>				
FINAL AVERAGES		V(m)=	Vm (std)= <u>45.685</u>		FINAL Yo @ avg O. H. =				FINAL ISO % = <u>103.19</u>				
TEST LEADER SIGNATURE: <u>Michael J. Ly</u> WITNESS: <u>JRF</u> <u>1335.5 Lost Power</u> WEST 4.16													

6.0

PM-10

RUN # 5103 DATE 10-22-93		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID 56-1 Meter ID	
PLANT Pulp Dryer - South		Sydney, MT		PITOT ID 60-2 PITOT ID 60-2 PM10	
DUCT/FLUE West UNIT 5000		FIELD DATA SHEET		NOZZLE ID 402 PM10-10	
TEST LDR MJL		METHODS -- M2,M3,M4,M5		FILTER ID (A) 7456 (B)	
HELPER(S) JRF #2		Client HOLLY SUGAR		ORSAT BAG ID, inst BAROM ID B	

PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS			
Ambient Temp 40-70	Rel Hum 10-15	Weather Clear		STACK TYPE Hand	Diameter 63.0	%O2= 15.8	
Delta P Level Zero	Zero			NO. of POINTS 20	Min/Pnt 6.0	%CO2= 4.1	
Delta H Level Zero	Zero			Pbar 27.81/27.81 Ps +0.20		ppm SO2= 55	
Pilot Lk Chk (+) A 0.55 in wg	(-) 0 @ 6.0 in wg			Cd 0.84	dnidesi 0.370	ppm NOx=	
Nozzle Leak Rate C CFM @ 23.5 in Hg				Yo 0.0965	dnacti 300/301	ppm CO=	
Backside Leak Rate 0.0 CFM @ 10 in H2O				Delta Ha 0.94	K3 1408	MAN (s)=	

ASSUMED VALUES											
DATA SOURCE	Head, Delta P	Delta H, Orifice	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP	G MTR	Vac.	ISO
Prev. Test or Estimate	in. H2O	in. H2O	%	OSCF	Deq. F	Deq. F	Deq. F	Deq. F	Deq. F	in. Hg	%

POINT -- BY -- POINT DATA																																																																																																																																							
Location		Time		VELOCITY		DRY GAS METER		SYSTEM TEMPERATURES (Deg. F)						VAC		RATE																																																																																																																							
Port/Pnt	Seq	Clock	Elap	Delta P	Index Reg.	Delta H Orifice		Stack	Probe	Filter	Imp	G Mtr	Main	ISO																																																																																																																									
Ltr/No.	#	24 Hr.	Min	in. H2O	Cu. Ft.	in. H2O		1	2	3	4	5	6	7	8	9																																																																																																																							
START	0	1524	0		2517.168	DES	ACT																																																																																																																																
A	1	1530	6	0.20	2519.85	0.300	0.3	250			51	77	1	77.1																																																																																																																									
	2	1536	12	0.22	2522.71	0.330	0.35	251	250	250	45	80	1	101.6																																																																																																																									
	3	1542	18	0.15	2525.02	0.225	0.2	230			44	83	1	98.8																																																																																																																									
	4	1548	24	0.10	2526.86	0.150	0.15	234	250	250	46	84	0.8	96.4																																																																																																																									
	5	1554	30	0.06	2528.38	0.090	0.1	237			47	83	0.5	103.2																																																																																																																									
	6	1600	36	0.12	2530.45	0.180	0.2	238	250	250	49	82	1	99.7																																																																																																																									
	7	1606	42	0.28	2533.52	0.420	0.4	243			42	83	1.8	97.0																																																																																																																									
	8	1612	48	0.43	2537.39	0.644	0.45	242	250	250	44	87	2	97.8																																																																																																																									
	9	1618	54	0.50	2541.65	0.749	0.75	240			40	88	3	99.7																																																																																																																									
	10	1624	60	0.50	2545.84	0.749	0.75	215	250	250	41	89	3	96.2																																																																																																																									
B	11	1630	66	0.1	2547.80	0.150	0.15	235			53	82	1.5	103.0																																																																																																																									
	12	1635	72	0.15	2549.94	0.225	0.2	237	250	250	48	84	2	91.8																																																																																																																									
	13	1701	78	0.1	2551.69	0.150	0.15	242			47	86.5	1.5	91.8																																																																																																																									
	14	1707	84	0.03	2552.48	0.045	0.05	245	250	250	50	86.5	1	95.8																																																																																																																									
	15	1713	90	0.1	2554.90	0.150	0.15	248			52	88	1.5	127.2																																																																																																																									
	16	1719	96	0.1	2555.55	0.150	0.15	248	250	250	45	89	1.5	134.1																																																																																																																									
	17	1725	102	0.30	2558.93	0.449	0.45	250			43	88.5	3	102.7																																																																																																																									
	18	1731	108	0.30	2562.20	0.449	0.45	247	250	250	40	88.5	3	99.1																																																																																																																									
	19	1737	114	0.50	2566.41	0.749	0.75	230			40	87	4.8	98.0																																																																																																																									
	20	1743	120	0.50	2570.671	0.749	0.75	226	250	250	40	86.5	4.8	99.0																																																																																																																									
<table border="1"> <tr> <td>TOTALS / AVERAGES</td> <td>120</td> <td>2091</td> <td>57.503</td> <td>0.395</td> <td>278.1</td> <td>X</td> <td>X</td> <td>45.1</td> <td>93.8</td> <td>2.0</td> <td>94.5</td> </tr> </table>																	TOTALS / AVERAGES	120	2091	57.503	0.395	278.1	X	X	45.1	93.8	2.0	94.5																																																																																																											
TOTALS / AVERAGES	120	2091	57.503	0.395	278.1	X	X	45.1	93.8	2.0	94.5																																																																																																																												
<table border="1"> <tr> <td colspan="4">FINAL LEAK CHECKS</td> <td colspan="4">ORSAT</td> <td colspan="4">COND. MOISTURE</td> <td colspan="5">DALTON'S LAW</td> </tr> <tr> <td>Pilot (+) 0 @ 6.0 in H2O</td> <td>Run #</td> <td>% CO2</td> <td>% Total</td> <td>% O2</td> <td>Imp.</td> <td>Total</td> <td>Tare</td> <td>Net</td> <td colspan="8">Silica Gel Adsorbed H2O 13.4</td> </tr> <tr> <td>Pilot (-) 0 @ 5.0</td> <td>1</td> <td></td> <td></td> <td></td> <td>1</td> <td>190</td> <td>100</td> <td>90</td> <td colspan="8">Vapor Pressure 3009/3120</td> </tr> <tr> <td>Nozzle Leak Rate 0</td> <td>2</td> <td></td> <td></td> <td></td> <td>2</td> <td>25240</td> <td>100</td> <td>203</td> <td colspan="8">Total ml H2O 629.4</td> </tr> <tr> <td>in. Hg. Vac. 23</td> <td>3</td> <td></td> <td></td> <td></td> <td>3</td> <td>25240</td> <td>0</td> <td>323</td> <td colspan="8">Vw (std) 47.336</td> </tr> <tr> <td>Leak Cu. Ft.</td> <td>Avg.</td> <td></td> <td></td> <td></td> <td colspan="4">Volume Condensed H2O = 616</td> <td colspan="8">FINAL % H2O 39.53</td> </tr> <tr> <td>FINAL AVERAGES</td> <td>m)=</td> <td></td> <td></td> <td></td> <td colspan="4">FINAL Yo @ avg D. H.=</td> <td colspan="8">FINAL ISO %= 93.58</td> </tr> </table>																	FINAL LEAK CHECKS				ORSAT				COND. MOISTURE				DALTON'S LAW					Pilot (+) 0 @ 6.0 in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O 13.4								Pilot (-) 0 @ 5.0	1				1	190	100	90	Vapor Pressure 3009/3120								Nozzle Leak Rate 0	2				2	25240	100	203	Total ml H2O 629.4								in. Hg. Vac. 23	3				3	25240	0	323	Vw (std) 47.336								Leak Cu. Ft.	Avg.				Volume Condensed H2O = 616				FINAL % H2O 39.53								FINAL AVERAGES	m)=				FINAL Yo @ avg D. H.=				FINAL ISO %= 93.58							
FINAL LEAK CHECKS				ORSAT				COND. MOISTURE				DALTON'S LAW																																																																																																																											
Pilot (+) 0 @ 6.0 in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O 13.4																																																																																																																														
Pilot (-) 0 @ 5.0	1				1	190	100	90	Vapor Pressure 3009/3120																																																																																																																														
Nozzle Leak Rate 0	2				2	25240	100	203	Total ml H2O 629.4																																																																																																																														
in. Hg. Vac. 23	3				3	25240	0	323	Vw (std) 47.336																																																																																																																														
Leak Cu. Ft.	Avg.				Volume Condensed H2O = 616				FINAL % H2O 39.53																																																																																																																														
FINAL AVERAGES	m)=				FINAL Yo @ avg D. H.=				FINAL ISO %= 93.58																																																																																																																														

TEST LEADER SIGNATURE: Michael J. Rhy 4.4.17 IESS: Jay R. Rhy

WEST - PM10

6.0

PM1-10 7/2

RUN # 51624 DATE 10-22-13		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID JC-1 Meter ID *	
PLANT Pulp Dryer - South		Sydney, MT		PITOT ID 60-2 PITOT ID 60-2-PM10	
DUCT/FLUE West UNIT 500		FIELD DATA SHEET		NOZZLE ID 102 PM10-10	
TEST LDR MJL				FILTER ID (A) 7487 (B)	
HELPER(S) JAF #2		METHODS -- M2,M3,M4,M5		ORSAT BAG ID ^{inst} BAROM ID B	
CLIENT HOLLY SUGAR					

PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS			
Ambient Temp 40-70	Rel Hum 10-15	Weather Clear		STACK TYPE Hand	Diameter 63.0	%O2= 15.8	
Delta P Level ✓	Zero ✓			NO. of POINTS 20	Min/Pnt 6.0	%CO2= 4.1	
Delta H Level ✓	Zero ✓			Pbar 27.80/27.82	+0.20	pm SO2= 55	
Prior Lk. Chk. (-) 1 @ 5.5 in wg	(i) 0 @ 6.0 in wg			Co 0.84	dn/dst 0.359	pm H2O=	
Nozzle Leak Rate 0 CFM	@ 23.5 in Hg			Yo 0.9965	dn(alt) .301	pm CO=	
Backpipe Leak Rate 0 CFM	@ 10 in H2O			Delta Hs 0.94	K3 1.622	MW (s)=	

ASSUMED VALUES											
DATA SOURCE	Head, Delta P	Delta H, Orifice	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP	G MTR	Vac.	ISO
Prev. Test or Estimate	in. H2O	in. H2O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%

5W
JOY
POINT -- BY -- POINT DATA
WEST 5W

Location	Time	VELOCITY	DRY GAS METER		SYSTEM TEMPERATURES (deg. F)								VAC	RATE
Port/Pnt	Seq	Clock	Elap	Delta P	Index Rdg	Delta H Orifice	Stack	Probe	Filter	Imp	G Mtr	Main	ISO	
Ltr/No.	#	24 Hr	Min	in. H2O	in. H2O	in. H2O	1	2	3	4	5	6	%	
START	0	1727	0		2509.501									
					1927	DES	ACT							
A	1	1933	6	0.25	2575.57	0.406	0.4	247			53	69.5	103.3	
	2	1939	12	0.25	2578.63	0.406	0.4	241	250	250	36	71	102.3	
	3	1945	18	0.18	2581.39	0.292	0.3	241			36	71.5	108.6	
	4	1951	24	0.12	2583.62	0.195	0.2	238	250	250	38	71	107.3	
	5	1957	30	0.1	2585.57	0.162	0.155	236			40	71.5	102.5	
	6	2003	36	0.15	2587.89	0.243	0.25	237	250	250	40	71.5	99.7	
	7	2009	42	0.25	2590.91	0.406	0.4	238			38	70.5	100.8	
	8	2015	48	0.36	2594.75	0.584	0.6	235	250	250	38	70.5	106.7	
	9	2021	54	0.40	2598.46	0.649	0.65	236			40	70.5	97.9	
	10	2027	60	0.47	2602.610	0.763	0.75	210	250	250	41	71.5	98.9	
B	11	2032	66	0.24	2605.49	0.389	0.4	238			45	59	107.3	
	12	2105	72	0.20	2608.68	0.324	0.325	239	250	250	40	60.5	113.8	
	13	2111	78	0.18	2611.04	0.292	0.3	243			43	62	94.7	
	14	2117	84	0.18	2614.0	0.292	0.3	248	250	250	44	63	118.6	
	15	2123	90	0.12	2616.26	0.195	0.2	243			44	65	110.4	
	16	2135	96	0.05	2617.56	0.081	0.1	242	250	250	38	65	98.3	
	17	2141	102	0.20	2620.11	0.324	0.325	242			39	66	96.3	
	18	2147	108	0.48	2624.41	0.779	0.8	228	250	250	39	66	103.9	
	19	2153	114	0.45	2628.68	0.73	0.725	221			44	67	105.7	
	20	2159	120	0.1	2630.77	0.162	0.15	208	250	250	44	67	109.0	
	21													
	22													
	23													
	24													
	25													
TOTALS / AVERAGES		120		2197	38.278		0.386	235.4	X	X	41.0	62.5	104.3	

FINAL LEAK CHECKS				ORSAT				COND. MOISTURE				DALTON'S LAW	
Pitot (+) 0 @ 6.0 in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O 13.5				
Pitot (-) 0 @ 5.0 in H2O	1				1	232	100	132	Vapor Pressure -2576/2577				
Nozzle Rate 0	2				2	254/32	100	282	Total ml H2O 587.5				
in. Hg. Vac. 23.5	3				3	156	0	156	Vw (std)				
Leak Cu. Ft.	Avg.				Volume Condensed H2O = 570				FINAL % H2O 33.72				
FINAL AVERAGES		V(m)=	Vm (std)= 54.1188	FINAL Yo @ avg O. H.=				FINAL ISO %= 97.71					

TEST LEADER SIGNATURE: Michael R. Rys 4.4.18 FITNESS: Jay R. Rys

Stop at 17 Kinked Line
Restart at 23

S. WEST - PM.10

5-0

DM-10

RUN # 6101 DATE 10-21-93		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID CC-2 Meter ID			
PLANT Pulp Dryers - Scott		SE		PITOT ID 50-3 in			
DUCT/FLUE Stack UNIT East		FIELD DATA SHEET		NOZZLE ID PM10-10			
TEST LDR MJL MJL		METHODS - M2,M3,M4,M5		FILTER ID (A) 7480 (B)			
HELPER(S) JRE		Client Holly Sugar		ORSAT BAG ID 1st BARCM ID B			
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS			
Ambient Temp		Rel Hum		Weather		STACK TYPE Road	
Delta P Level		Zero				Diameter 63.0	
Delta H Level		Zero				Min/Pnt 3.50	
Pitot Lk. Chk. (+)		in wg		(-)		Ps +0.20	
Nozzle Leak Rate		CFM		in Hg		Co 0.84	
Backside Leak Rate		CFM		in H2O		Yo 0.9890	
						Delta H 1.904	
						K3 1.19	
						MW (g)	
ASSUMED VALUES				EAST			
DATA SOURCE		Head, Delta P		Delta H, Orifice		Moisture	
Prev. Test or Estimate		in. H2O		in. H2O		%	
						DSCF	
						Deg. F	
						Deg. F	
						Deg. F	
						Deg. F	
						in. Hg	
						%	
POINT -- BY -- POINT DATA							
Location		Time		VELOCITY		DRY GAS METER	
Port/Pnt		Seq		Clock		Elap.	
Ltr/No.		#		24 Hr		Min.	
				Delta P		Index Rtg.	
				in. H2O		Cu. Ft.	
						in. H2O	
START		0		2056		0	
A		1		2101		5	
		2		2106		10	
		3		2111		15	
		4		2116		20	
		5				25	
		6				30	
		7				35	
		8				40	
		9				45	
		10				50	
B		11				55	
		12				60	
		13				65	
		14				70	
		15				75	
		16				80	
		17				85	
		18				90	
		19				95	
		20				100	
		21					
		22					
		23					
		24					
		25					
TOTALS / AVERAGES		20		0.1312		9.165	
FINAL LEAK CHECKS		ORSAT		COND. MOISTURE		DALTON'S LAW	
Pnt (+) @ in H2O		Run #		% CO2		% Total	
Pnt (-) @ in H2O		1				% O2	
Nozzle Rate 0.0		2				Imp.	
in. Hg. Vac. (V)		3				Total	
Leak Cu. Ft.		Avg.				Tare	
FINAL AVERAGES		V(m)=		Vm (std)=		Net	
						Silica Gel Adsorbed H2O	
						Vapor Pressure	
						Total ml H2O	
						Vw (std)	
						FINAL % H2O	
						FINAL ISO %	
TEST LEADER SIGNATURE: Michael J. Ry							
WITNESS: Jay R. Hays							
4.4.19							

6.0

P1110

RUN # <u>6102</u> DATE <u>10-22-93</u>		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID <u>CC-2</u> Meter ID	
PLANT <u>Pulp Dryer - Santa</u>		<u>Sydney, MT</u> FIELD DATA SHEET METHODS -- M2, M3, M4, M5 Client <u>HOLLY SUGAR</u>		PITOT ID <u>60-2</u> PITOT ID <u>60-2-PM10</u>	
DUCT/FLUE <u>East</u> UNIT <u>6000</u>				NOZZLE ID <u>17481 wt</u> <u>PM10-10</u>	
TEST LDR <u>MJL</u>				FILTER ID (A) <u>784</u> (B)	
HELPER(S) <u>JRF</u> #2				ORSAT BAG ID <u>inst</u> BAROM ID <u>B</u>	

PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS			
Ambient Temp <u>40-70</u> Rel Hum <u>10-15</u> Weather <u>Clear</u>		STACK TYPE <u>Round</u> Diameter <u>63.0</u> %CO ₂ <u>15.8</u>					
Delta P Level <u>✓</u> Zero: <u>✓</u>		NO OF POINTS <u>20</u> MiniPnt <u>6.0</u> %CO ₂ <u>4.1</u>					
Delta H Level <u>✓</u> Zero: <u>✓</u>		Pbar <u>27.96/2787</u> P _s <u>+0.20</u> ppm SO ₂ <u>55</u>					
Pilot Lk. Chk. (+) <u>0.55</u> in wg (-) <u>0.60</u> in wg		Co <u>0.84</u> dn(des) <u>0.363</u> ppm NO _x <u>—</u>					
Nozzle Leak Rate <u>0</u> CFM @ <u>23.5</u> in Hg		Yo <u>0.9890</u> dn(act) <u>.301</u> ppm CO ₂ <u>—</u>					
Backside Leak Rate <u>0.0</u> CFM @ <u>10</u> in H ₂ O		Delta Ha <u>1.904</u> K3 <u>3.281</u> MW (s) <u>—</u>					

SE ASSUMED VALUES SE											
DATA SOURCE	Head, Delta P	Delta H, Orifice	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP	G MTR	Vac.	ISO
Prev. Test or Estimate	in. H ₂ O	in. H ₂ O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%

POINT -- BY -- POINT DATA													
Location	Time	VELOCITY	DRY GAS METER			SYSTEM TEMPERATURES (Deg. F)						VAC	RATE
Port/Pnt	Seq	Clock	Elap	Delta P	Index Rdg	Delta H Orifice	Stack	Probe	Filter	Imp.	G Mtr	Vac	Rate
Ltr/No.	#	24 Hr	Min	in. H ₂ O	Cu. Ft.	in. H ₂ O	1	2	3	4	5	6	7
START	0	0934	0		589.842	OES	ACT						
A.	1	0940	6	0.1	590.23	0.328	0.33	224		42	46	1.5	20.2
	2	0946	12	0.23	592.13	0.755	1.3	219	250	250	36	47.5	4 65.7
	3	0952	18	0.1	594.14	0.328	0.8	220		35	50	3	109.8
	4	0958	24	0.1	596.18	0.328	0.8	221	250	250	36	51	3.2 106.3
	5	1004	30	0.1	598.18	0.328	0.77	221		37	52	3.2	109.0
	6	1010	36	0.49	601.14	1.608	2.1	221	250	250	37	53	5.2 89.6
	7	1016	42	0.62	605.37	2.034	2.5	221		39	54.5	14	88.3
	8	1022	48	0.78	609.38	2.555	2.7	217	250	250	42	56	15.8 74.1
	9	1028	54	0.84	612.80	2.756	1.6	215		44	55	17	60.8
	10	1034	60	0.80	615.807	2.625	1.35	212	250	250	45	55.5	17.8 54.6
B.	11	1040	66	0.33	619.89	1.083	1.5	221		46	78	4.8	111.4
	12	1254	72	0.27	623.48	0.886	1.4	221	250	250	40	80	5 107.9
	13	1300	78	0.16	626.56	0.525	1.0	222		42	81.5	4.2	119.8
	14	1306	84	0.07	628.99	0.230	0.7	221	250	250	46	81.5	3.5 —
	15	1312	90	0.1	631.55	0.328	0.8	221		49	83	3.8	—
	16	1318	96	0.03	633.47	0.098	0.5	220	250	250	44	82	3 —
	17	1324	102	0.26	636.81	1.345	1.7	219		45	82.5	5.5	—
	18	1330	108	0.41	640.77	1.345	1.7	217	250	250	42	83.5	6 95.7
	19	1336	114	0.60	644.828	1.769	2.4	217		44	84	8.5	81
	20		120						250	250			
	21												
	22												
	23												
	24												
	25												
TOTALS / AVERAGES		113.5			54.983		6259	219.4	X	X	41.6	62.7	6.7 —

FINAL LEAK CHECKS				COND. MOISTURE				DALTON'S LAW	
Pilot (+)	Pilot (-)	Nozzle Rate	in. Hg. Vac.	Imp.	Total	Tare	Net	Silica Gel Adsorbed H ₂ O	Vapor Pressure
0 @ 1.0 in H ₂ O	0 @ 5.0 in H ₂ O	0.0	14	1	250 + 152	100	302	7516/2677	754.6
				2	250 + 148	100	298	Total ml H ₂ O	754.6
				3	220 + 108	100	220	Vw (std)	
Leak Cu. Ft.				Volume Condensed H ₂ O = 640				(1) FINAL % H ₂ O 40.90	
FINAL AVERAGES V(m)=				V(m) std= 21.417				FINAL ISO %=	

TEST LEADER SIGNATURE: <u>Michael Ryan</u> 4.4.20	NESS: <u>Jay R. Floyd</u>
---	---------------------------

1335.5 Lost Power

88.68

EAST

6.0

M-5

115

RUN # 6103 DATE 10-22-73		THE EMISSION MEASUREMENT GROUP INC.	CONSOLE ID 60-2 Meter ID	
PLANT Pulp Dryer - South		Sydney, MT	PITOBID 60-1 PITOT ID 60-1	
DUCT/FLUE East UNIT 6000		FIELD DATA SHEET	NOZZLE ID 7-2 10-1	
TEST LDR MJL		METHODS -- M2,M3,M4,M5	FILTER ID (A) 7485 (B)	
HELPER(S) JRF #2		Client HOLLY SUGAR	ORSAT BAG ID 101 BAROM ID B	

PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS							
Ambient Temp	40-70	Rel Hum	10-15	Weather	clear	STACK TYPE	Round	Diameter	63.0	%O2=	15.8
Delta P Level	Zero	Delta H Level	Zero			NO of POINTS	20	Min/Pnt	6.0	%CO2=	4.1
Pitot Lk. Chk. (+)	6 @ 5.5 in wg	(-)	0 @ 6.0 in wg			Pbar	57.96/278	Ps	40.20	ppm SO2=	55
Nozzle Leak Rate	CFM	23.5	in Hg			Co	0.84	dn/des		ppm NOx=	-
Backside Leak Rate	CFM	10	in H2O			Vo	0.9890	dn/act	3021	ppm CO=	-
						Delta Ma	1.904	X3	3.090	MW (S)=	-

ASSUMED VALUES											
DATA SOURCE	Head, Delta P	Delta H, On/Off	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP.	G MTR	Vac.	ISO
Prev. Test or Estimate	in. H2O	in. H2O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%

POINT -- BY -- POINT DATA														
Location		Time		VELOCITY	DRY GAS METER			SYSTEM TEMPERATURES (Deg. F)					VAC	RATE
Port/Pnt	Seq	Clock	Elap	Delta P	Index Rdg.	Delta H On/Off	Stack	Probe	Filter	Imp	G Mtr	Vac	RATE	
Ltr/No.	#	24 Hr.	Min	in. H2O	Cu Ft.	in. H2O	1	2	3	4	6	in. Hg	ISO	
START	0	1527	0		645.524	DES	ACT							
A	1	1533	6	0.39	649.77	1.205	1.6	225		54	75.5	2.8	114.2	
	2	1539	12	0.25	652.91	0.772	1.2	204	250	250	42	77.5	2	103.3
	3	1545	18	0.14	655.41	0.433	0.75	212		43	77	1.8	110.6	
	4	1551	24	0.1	657.62	0.309	0.65	213	250	250	43	77	1.5	115.8
	5	1550	30	0.1	659.54	0.309	0.55	215		43	77	1.8	100.7	
	6	1603	36	0.1	661.52	0.304	0.55	212	250	250	43	76	1.5	103.8
	7	1609	42	0.1	663.58	0.309	0.55	212		43	76	1.5	108.0	
	8	1615	48	0.33	666.75	1.020	1.2	210	250	250	42	76.5	2	91.4
	9	1621	54	0.59	670.84	1.823	1.9	209		41.5	76	2.4	88.1	
B	10	1627	60	0.56	674.988	1.730	1.9	207	250	250	43	79	2.5	91.3
	11	1645	66	0.20	677.45	0.618	0.8	215		47	79	1.5	91.0	
	12	1658	72	0.29	680.69	0.896	1.1	217	250	250	39	81	2	99.3
	13	1709	78	0.18	683.43	0.556	0.8	220		40	82.5	1.8	106.5	
	14	1710	84	0.07	685.27	0.216	0.45	220	250	250	41	82.5	1	114.6
	15	1716	90	0.03	686.26	0.092	0.25	222		41	82.5	0.5	94.2	
	16	1723	96	0.08	688.10	0.247	0.5	217	250	250	41	82	0.5	107.0
	17	1728	102	0.15	690.31	0.463	0.7	210		40	83.5	1	93.2	
	18	1734	108	0.28	693.50	0.865	1.1	208	250	250	40	83.5	2	98.4
	19	1740	114	0.54	697.79	1.669	1.9	210		41	84	2.8	95.6	
	20	1746	120	0.03	699.268	0.093	0.3	210	250	250	42	83	0.5	111
	21													
	22													
	23													
	24													
	25													

TOTALS / AVERAGES		120	294	57.794	924	212.4	X	X	42.5	79.7	1.7	103.3	
FINAL LEAK CHECKS		ORSAT				COND. MOISTURE				DALTON'S LAW			
Pnt (+)	0 @ 6.0 in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O 6.6			
Nozzle Rate	NO	1				1	250+48	100	148	Vapor Pressure 26.77/2782			
in. Hg. Vac.	5.5	2				2	110	100	10	Total ml H2O 215.6			
Leak Cu. Ft.	2.77	3				3	12	0	1.3	Vw (std)			
FINAL AVERAGES		V(m)=	Vm (std)= 26.542			Volume Condensed H2O = 208.3				FINAL % H2O 22.47			
						FINAL Yo @ avg D. H. =				FINAL ISO % =			

TESTER SIGNATURE: Michael West WITNESS: Jay R. F.
Filter Elbow Broken
S. West.
4.4.21

6.0

(11)

RUN # <u>61084</u> DATE <u>10-22-13</u>		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID <u>22-2</u> Meter ID											
PLANT <u>Pulp Dryer - Santa</u>		Sydney, MT FIELD DATA SHEET METHODS -- M2, M3, M4, M5 Client <u>HOLLY SUGAR</u>		PITOT ID <u>60-1</u> PITOT ID <u>60-1</u>											
DUCT/FLUE <u>Fast</u> UNIT <u>6000</u>				NOZZLE ID <u>4-2</u> <u>10-1</u>											
TEST LDR <u>MJL</u>				FILTER ID (A) <u>7488</u> (B)											
HELPER(S) <u>JAF</u>				ORSAT BAG ID <u>inst.</u> BAROM ID <u>B</u>											
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS											
Ambient Temp <u>40-70</u> Rel Hum <u>10-15</u> Weather <u>Clear</u>		STACK TYPE <u>Hand</u>		Diameter <u>63.0</u>		%O ₂ <u>15.8</u>									
Delta P Level <u>Zero</u>		NO. of POINTS <u>20</u>		Min/Pnt <u>6.0</u>		%CO ₂ <u>4.1</u>									
Delta H Level <u>Zero</u>		Pbar <u>27.80/27.92</u>		+0.20		ppm SO ₂ <u>55</u>									
Pilot Lk. Chk. (+) <u>0.55</u> in wg		Co <u>0.84</u>		dn/dst		ppm H ₂ O <u>—</u>									
Nozzle Leak Rate <u>0</u> CFM		Yo <u>0.9890</u>		dn/fact		ppm CO <u>—</u>									
Backside Leak Rate <u>0.0</u> CFM		Delta Ha <u>1.904</u>		K3 <u>2.851</u>		MW (s) <u>—</u>									
SE ASSUMED VALUES SE															
DATA SOURCE		Head, Delta P	Delta H, Office	Moisture	Calc. Volume	STACK PROBE	FILTER	IMP	G.MTR	Vac.	ISO				
Prev. Test or Estimate		in. H ₂ O	in. H ₂ O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%				
POINT -- BY -- POINT DATA															
Location		Time		VELOCITY		DRY GAS METER		SYSTEM TEMPERATURES (Deg. F)						VAC	RATE
Port/Pnt	Seq	Clock	Elap	Delta P	Index Rdg.	Delta H Office		Stack	Probe	Filter	Imp	G Mtr	Man	ISO	
Lt/No.	#	24 Hr	Min	in. H ₂ O	Cu Ft.	in. H ₂ O		1	2	3	4	5	in. Hg	%	
START	0	1924	0		699.678	DES	ACT								
A	1	1930	6	0.33	703.17	1.271	1.5	217			49	70.5	2	92.4	
	2	1936	12	0.38	706.74	1.464	1.7	217	250	250	39	72	3	87.8	
	3	1942	18	0.22	709.68	0.847	1.0	193			40	73	2.8	93.0	
	4	1948	24	0.07	711.31	0.270	0.5	194	250	250	40	72	2	91.6	
	5	1954	30	0.03	712.67	0.116	0.4	221			39	72.5	2	119.0	
	6	2000	36	0.19	715.25	0.732	0.98	221	250	250	39	71	3	90.0	
	7	2006	42	0.17	717.81	0.655	0.90	209			39	71	3	93.6	
	8	2012	48	0.29	721.17	1.117	1.35	215	250	250	41	71.5	4	94.5	
	9	2018	54	0.55	725.69	2.118	2.35	212			44	72	5.8	92.3	
	10	2024	60	0.1	727.722	0.385	0.6	207	250	250	45	71.5	4	96.6	
B	11	2030	66	0.35	731.22	1.548	1.6	219			46	67.5	4.8	90.6	
	12	2102	72	0.26	734.40	1.001	1.25	216	250	250	41	69	4.5	88.0	
	13	2108	78	0.14	736.85	0.539	0.78	217			44	69	4	99.6	
	14	2114	84	0.1	738.77	0.385	0.64	218	250	250	47	68.5	4	92.3	
	15	2120	90	0.1	740.71	0.385	0.64	216			48	68	4	93.4	
	16	2126	96	0.1	742.68	0.385	0.64	221	250	250	51	68	4	95.2	
	17	2132	102	0.1	744.65	0.385	0.64	210			37	67.5	4	94.5	
	18	2138	108	0.1	746.56	0.385	0.64	200	250	250	35	67	4	91.1	
	19	2144	114	0.1	748.52	0.385	0.64	205			35	67	4	93.8	
	20	2150	120	0.1	750.351	0.385	0.64	207	250	250	36	67	4.2	87.8	
2122232425															
TOTALS / AVERAGES		20		1.694	50.672		0.97	211.8	X	X	41.8	14.8	3.7	94.2	
FINAL LEAK CHECKS		ORSAT				COND. MOISTURE				DALTON'S LAW					
Pilot (+)	0 @ 1.0 in H ₂ O	Run #	% CO ₂	% Total	% O ₂	Imp.	Total	Tare	Net	Silica Gel Adsorbed H ₂ O					
Pilot (-)	0 @ 5.0 in H ₂ O	1				1	250+90	120	330	Vapor Pressure 2576/2677					
Nozzle Rate	0	2				2	265	100	165	Total ml H ₂ O 7339					
in. Hg. Vac.	23.5	3				3	257	0	257	Vw (std)					
Leak Cu. Ft.	Avg.					Volume Condensed H ₂ O = 722				FINAL % H ₂ O 43.64					
FINAL AVERAGES		V(m)=		Vm (std)=	46.452	FINAL Yo @ avg O. H. =				FINAL ISO % = 106.68					
TEST LEADER SIGNATURE: <u>Michael Thompson</u> WITNESS: <u>Jay R. Taylor</u>															

5-0

105

RUN # 710 L DATE 10-23-93		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID 32-1 Meter ID									
PLANT Pulp Dryers, North		FIELD DATA SHEET		PITOT ID 60-1 PITOT ID 60-1									
DUCT/FLUE West St. UNIT 7000				NOZZLE ID 10-2									
TEST LDR MTL MJL				FILTER ID (A) 7475 (B)									
HELPER(S) JRF #2		Client Holly Sugar		ORSAT BAG ID 145T BAROM ID B									
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS									
Ambient Temp 52-70 Rel Hum 10-15 Weather clear		STACK TYPE Road		Diameter 63.0									
Delta P Level Zero: ✓		NO. of POINTS 20		Min/Pnt 8.5.0									
Delta H Level Zero: ✓		Pba 6723/127-7		Ps +0.20									
Plot Lk. Chk. (+) 0 @ 5 in wg (-) 0 @ 6 in wg		Co 0.24		dn(des) 0.353									
Nozzle Leak Rate 0 CFM @ 23.5 in Hg		Yo 0.9965		dn(act) 0.32									
Backsweep Leak Rate 0 CFM @ 10 in H2O		Delta Hs 0.94		K3 2.157									
				MW (s)=									
ASSUMED VALUES													
DATA SOURCE		Head, Delta P	Delta H, On/Off	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP.	G.MTR	Vac.	ISO	
Prev. Test or Estimate		in. H2O	in. H2O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%	
POINT -- BY -- POINT DATA													
Location		Time	VELOCITY	DRY GAS METER		SYSTEM TEMPERATURES (Deg. F)							
Port/Pnt	Seq	Clock	Elap.	Index Rdg.	Delta H On/Off	Stack	Probe	Filter	Imp.	G.Mtr.	Vac.	RATE	
Lv/No.	#	24 Hr.	Min.	in. H2O	Cu. Ft.	in. H2O	1	2	3	4	5	in. Hg	%
START	0	1026.5	0		2564.42	DES	ACT						
A	1	1031.5	5	0.08	2566.05	0.173	0.175	237	50		58	2	98.6
	2	1035.5	10	0.05	2567.14	0.108	0.1	238	45	250	250	62.5	1.2 81.5
	3	1041.5	15	0.03	2568.02	0.065	0.075	238	47	250	250	65	1 85.3
	4	1048.5	20	0.1	2569.72	0.216	0.2	240	45			67	2.5 92.2
	5	1051.5	25	0.1	2571.60	0.216	0.2	234	43	250	250	69.5	3.0 96.6
	6	1056.5	30	0.08	2573.21	0.173	0.175	223	41	250	250	67.5	2.5 93.7
	7	1001.5	35	0.15	2575.35	0.324	0.325	210	40			70	4.8 90.1
	8	1106.5	40	0.18	2577.90	0.388	0.4	216	39	250	250	71	6.8 98.2
	9	1111.5	45	0.20	2580.52	0.431	0.45	212	40	250	250	71.5	7.8 95.4
	10	1116.5	50	0.20	2583.192	0.431	0.45	209	41			72	8.5 98.0
B	11	1122.5	55	0.20	2585.62	0.431	0.45	229	50	250	250	63	11.5 91.0
	12	1200.5	60	0.17	2587.78	0.367	0.375	229	44	250	250	67	15.8 87.1
	13	1205.5	65	0.12	2589.75	0.259	0.25	229	47			70	17 99.0
	14	1210.5	70	0.05	2591.35	0.108	0.1	229	50	250	250	71	6.8 118.0
	15	1215.5	75	0.1	2593.01	0.216	0.2	232	53	250	250	77	11.5 85.8
	16	1220.5	80	0.07	2594.57	0.151	0.15	223	52			78	9 95.6
	17	1225.5	85	0.12	2596.35	0.259	0.25	220	55	250	250	83	17 82.3
	18	1230.5	90	0.18	2598.12	0.388	0.25	212	51	250	250	84	19.5 66.3
	19	1235.5	95	0.15	2599.86	0.324	0.2	210	52			86	19.5 68.1
	20	1240.5	100	0.18	2701.570	0.388	0.2	209	55	250	250	78	19.5 63.5
	21												
	22												
	23												
	24												
	25												
TOTALS / AVERAGES		100	1188	37.149			740	216.1	49.7	X	X	72.2	9.4 88.7
FINAL LEAK CHECKS		ORSAT				COND. MOISTURE				DALTON'S LAW			
Port (+)	@	in H2O	Run #	% CO2	% Total	% O2	Imp.	Total	Tare	Net	Silica Gel Adsorbed H2O	15.6	
Pilot (+)	@	in H2O	1				1	250	100	187.17	Vapor Pressure	3492/7626	
Nozzle Rate	=		2				2	250	100	190	Total ml H2O	389.6	
in. Hg. Vac.	=	23.5	3				3	2	0	2	Vw (std)		
Leak Cu. Ft.			Avg.				Volume Condensed H2O = 220				FINAL % H2O 34.96		
FINAL AVERAGES		V(m)=		Vm (std)=	34.164		FINAL Yo @ avg D. H. = JRF 764				FINAL ISO % =		
TEST LEADER SIGNATURE: Michael L. Ray						WITNESS: Jay R. Ford							

N- West, JOY 4.4.23

5

5.0

A9-10 K

RUN # 7102 DATE 10-23-93		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID JC-1 Meter ID	
PLANT Pulp Dryers North		FIELD DATA SHEET		PITOBID 60-2 PITOT ID 60-2-PM10	
DUCT/FLUE West St. UNIT 7000				NOZZLE ID PM10-11	
TEST LDR MTL MJL		METHODS - M2,M3,M4,M5		FILTER ID (A) 7102 (B)	
HELPER(S) JRF		Client Holly Sugar		ORSAT BAG ID 1st BAROM ID B	
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS	
Ambient Temp 50-70 Rel Hum 10-15 Weather clear		STACK TYPE Road		Diameter 63.0	
Delta P Level Zero		NO. of POINTS 20		Min/Pnt 25.0	
Delta H Level Zero		Pbar 27.8727.82 ps		ppm SO2=	
Pitot Lk. Chk. (+) 0 @ 5 in wg (-) 0 @ 6 in wg		Co 0.84		ppm NOx=	
Nozzle Leak Rate 0 CFM @ 23.5 in Hg		Yo		ppm CO=	
Backside Leak Rate 0 CFM @ 10 in H2O		Delta Ha		MW (s)=	
		K3 2.288			
ASSUMED VALUES					
DATA SOURCE		Head, Delta P	Delta H, Office	Moisture	Calc. Volume
Prev. Test or Estimate		in. H2O	in. H2O	%	DSCF
					Stack Deg. F
					Probe Deg. F
					Filter Deg. F
					Imp. Deg. F
					G.MTR Deg. F
					Vac. in. Hg
					ISO %
NEW JOY POINT -- BY -- POINT DATA WEST NEW					
Location		Time	VELOCITY	DRY GAS METER	
Port/Pnt	Seq	Clock	Elap.	Index Rdg.	Delta H Office
Ltr/No.	#	24 Hr.	Min.	in. H2O	in. H2O
				Cu. Ft.	
START	0	1518	0		
A	1	1523	0.27	2710.209	DES ACT
	2	1528	0.22	2711.41	0.618 0.6
	3	1533	0.22	2714.24	0.503 0.5
	4	1538	0.1	2717.12	0.503 0.5
	5	1543	0.1	2719.29	0.229 0.25
	6	1548	0.1	2721.18	0.229 0.25
	7	1553	0.1	2723.05	0.229 0.25
	8	1558	0.17	2724.93	0.229 0.25
	9	1603	0.20	2727.42	0.412 0.4
	10	1608	0.22	2730.17	0.458 0.45
B	11	1608	0.45	2732.951	0.503 0.5
	12	1613	0.45	2736.98	1.029 1.0
	13	1618	0.42	2740.98	0.961 0.95
	14	1623	0.35	2744.67	0.801 0.8
	15	1628	0.31	2748.12	0.709 0.7
	16	1633	0.20	2750.86	0.458 0.45
	17	1638	0.1	2752.80	0.229 0.225
	18	1643	0.1	2754.64	0.229 0.225
	19	1648	0.15	2756.48	0.229 0.225
	20	1653	0.15	2758.82	0.343 0.35
	21	1658	0.15	2761.238	0.343 0.35
	22				
	23				
	24				
	25				
TOTALS / AVERAGES		100	-1893	53.029	2458
FINAL LEAK CHECKS		ORSAT		COND. MOISTURE	
Pitot (+)	@ in H2O	Run #	% CO2	% Total	% O2
Pitot (-)	@ in H2O	1			
Nozzle Rate	@	2			
in. Hg. Vac.	23.5	3			
Leak Cu. Ft.	Avg.				
FINAL AVERAGES		V(m)=	Vm (std)= 47.555		Volume Condensed H2O = 527
					FINAL Yo at avg O.H.=
					FINAL ISO % = 98.89
TEST LEADER SIGNATURE: Michael P. Wittness: Jay R. Hays					

N - West, JOY

4.4.24

5.0

5-0

RUN # 7103 DATE 10-23-93		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID JC-1 Meter ID																																																			
PLANT Pulp Dryers, North		FIELD DATA SHEET		PITOT ID 60-2 PITOT ID 60-2-PMK																																																			
DUCT/FLUE West St. UNIT 7000				NOZZLE ID PM 10-11																																																			
TEST LDR MTL MJL				FILTER ID (A) T-406 (B)																																																			
HELPER(S) JRF #2				ORSAT BAG ID 11ST BAROM ID B																																																			
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS																																																			
Ambient Temp 50.70 Rel Hum 10-15 Weather clear				STACK TYPE Road Diameter 63.0																																																			
Delta P Level 2 Zero: ✓				NO of POINTS 20 Min/Pnt 25.0																																																			
Delta H Level 2 Zero: ✓				Pbar 27.65/27.85 P1 +0.20																																																			
Pitot Lk. Chk. (+) 0 @ 5 in wg (-) 0 @ 6 in wg				Co 0.24 dn(des) 0.358																																																			
Nozzle Leak Rate 0 CFM @ 23-5 in Hg				Yo 0.9955 dn(fact) 0.32																																																			
Backside Leak Rate 0 CFM @ 10 in H2O				Delta Ha 0.94 K3 2.210																																																			
MW (s) =																																																							
ASSUMED VALUES																																																							
DATA SOURCE		Prev. Test or Estimate		in. H2O		in. H2O		Moisture %		Calc. Volume		STACK		PROBE		FILTER		IMP.		G.MTR		Vac.		ISO																															
										DSCF		Deg. F		Deg. F		Deg. F		Deg. F		Deg. F		in. Hg		%																															
POINT -- BY -- POINT DATA																																																							
NEW								WEST NEW																																															
Location								Time								VELOCITY								DRY GAS METER								SYSTEM TEMPERATURES (Deg. F)								VAC.								RATE							
Port/Pnt		Seq		Clock		Elap.		Delta P		Index Rqd.		Delta H Office		Stack		Probe		Filter		Imp.		G.Mtr		Main		ISO																													
Ltr/No.		#		24 Hr.		Min.		in. H2O		Cu. Ft.		in. H2O		1		2		3		4		5		6		in. Hg		%																											
START		0		1917		0				2761.639		DES		ACT																																									
A		1		1923		5		0.18		2764.16		1.398		0.4		242		50						61		1.8		102.3																											
		2		1928		10		0.25		2767.11		1.553		0.55		244		37		250		250		65		2.8		100.9																											
		3		1933		15		0.18		2769.69		0.398		0.4		243		39		250		250		68		2		103.3																											
		4		1938		20		0.15		2772.06		0.332		0.332		240		40						70		2		103.3																											
		5		1943		25		0.05		2773.81		0.111		0.1		238		40		250		250		69		1																													
		6		2000		30		0.1		2775.24		0.221		0.22		227		42		250		250		60		1.2																													
		7		2010		35		0.1		2777.06		0.221		0.22		230		37						64		1.5		97.6																											
		8		2015		40		0.20		2779.64		0.442		0.45		223		36		250		250		64.5		2.5		97.3																											
		9		2020		45		0.23		2782.46		0.508		0.5		210		34		250		250		66		3		97.9																											
		10		2025		50		0.23		2785.282		0.508		0.5		207		35						67		3		97.6																											
B		11		2030		55		0.47		2789.60		1.039		1.0		241		39		250		250		60		5		108.7																											
		12		2103		60		0.45		2793.00		0.995		1.0		240		35		250		250		63		5		86.0																											
		13		2108		65		0.30		2796.60		0.663		0.7		238		37						66		4		114.6																											
		14		2113		70		0.30		2800.07		0.663		0.7		236		38		250		250		66		4		104.8																											
		15		2118		75		0.10		2802.139		0.221		0.22		235		39		250		250		67		2		110.7																											
		16		2123		80		0.22		2804.48		0.486		0.5		231		43		250		250		63		2		84.9																											
		17		2142		85		0.1		2806.45		0.221		0.22		234		37		250		250		66		2		105.5																											
		18		2147		90		0.05		2807.63		0.111		0.1		235		45		250		250		75		1.5		78.5																											
		19		2152		95		0.1		2809.35		0.221		0.22		239		42		250		250		70		2		91.8																											
		20		2157		100		0.1		2811.145		0.221		0.22		237		37		250		250		69		2		95.8																											
		21																																																					
		22																																																					
		23																																																					
		24																																																					
		25																																																					
TOTALS / AVERAGES								100		1767		49.506		.428		234.1		22-1		X		X		166.0		2.5		99.2																											
FINAL LEAK CHECKS								ORSAT								COND. MOISTURE								DALTON'S LAW																															
Prot (+)		@ in H2O		Run #		% CO2		% Total		% O2		Imp.		Total		Tare		Net		Silica Gel Adsorbed H2O		10.0																																	
Prot (-)		@ in H2O		1								1		209		100		109		Vapor Pressure		2393/2475																																	
Nozzle Rate		0.1		2								2		351		100		251		Total ml H2O		482																																	
in. Hg. Vac.		23		3								3		112		0		112		Vw (std)																																			
Leak Cu. Ft.		Avg.																		Volume Condensed H2O = 47.2		FINAL % H2O		33.0																															
FINAL AVERAGES								V(m) =		Vm (std) = 46.144		FINAL Yo @ avg O. H. =										FINAL ISO % = 97.37																																	
TEST LEADER SIGNATURE: Michael R. Joy																												WITNESS: Jay R. Hays																											

n-west- Joy 4.4.25

5

5-0

PM-1a

RUN # <u>8101</u> DATE <u>10-23-93</u>		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID <u>CC-2</u> Meter ID																							
PLANT <u>Pulp Dryers, North</u>		FIELD DATA SHEET METHODS - M2,M3,M4,M5 Client <u>Holly Sugar</u>		PITOT ID <u>60-2</u> PITOT ID <u>60-2-PM16</u>																							
DUCT/FLUE <u>East St. UNIT 8000</u>				NOZZLE ID <u>PM10-11</u>																							
TEST LDR <u>MTL MJL</u>				FILTER ID (A) <u>7178</u> (B)																							
HELPER(S) <u>TRF</u>				ORSAT BAG ID <u>INST</u> BAROM ID <u>B</u>																							
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS																							
Ambient Temp		Rel Hum		Weather		STACK TYPE <u>Round</u>		Diameter <u>63.0</u>		%O2=																	
Delta P Level		Zero		Zero		NO. of POINTS <u>20</u>		Min/Pnt <u>8.50</u>		%CO2=																	
Delta H Level		Zero		Zero		Pbar <u>28.3/27.82</u>		Pa <u>+0.20</u>		ppm SO2=																	
Pitot Lk. Chk. (+)		0 0 5 in wg		0 0 6 in wg		Co <u>0.24</u>		dn(des)		ppm NOx=																	
Nozzle Leak Rate		0 CFM		0.35 in Hg		Yo <u>0.9890</u>		dn(act)		ppm CO=																	
Backswe Leak Rate		0 CFM		10 in H2O		Delta Ha <u>4.25</u>		K3 <u>4.25</u>		MW (s)=																	
NE ASSUMED VALUES				1.904 NE																							
DATA SOURCE		Head, Delta P		Delta H, Onifice		Moisture		Calc. Volume		STACK		PROBE		FILTER		IMP.		G.MTR		Vac.		ISO					
Prev. Test or Estimate		in. H2O		in. H2O		%		DSCF		Deg. F		Deg. F		Deg. F		Deg. F		Deg. F		in. Hg		%					
POINT -- BY -- POINT DATA																											
Location		Time		VELOCITY		DRY GAS METER				SYSTEM TEMPERATURES (Deg. F)								VAC.		RATE							
Port/Pnt		Seq		Clock		Elaop.		Delta P		Index Rdg.		Delta H Onifice		Stack		Probe		Filter		Imp.		G.Mtr.		Main		ISO	
Ltr/No.		#		24 Hr.		Min.		in. H2O		Cu. Ft.		in. H2O		1		2		3		4		6		in. Hg		%	
START		0		1124		0				791.92		DES		ACT													
A		1		1029		5		0.48		795.65		2.057		2.3		217		49				65.5		14		91.2	
		2		1034		10		0.41		799.38		1.757		2.0		218		39		250		250		70		12.8 98.1	
		3		1039		15		1.24		802.32		1.028		1.3		218		41		250		250		71		8 100.7	
		4		1044		20		1.18		804.93		0.771		1.0		218		40						69.5		7 103.5	
		5		1049		25		0.02		806.33		0.086		0.33		216		40		250		250		68.5		3 9	
		6		1054		30		0.1		808.28		0.429		0.68		214		34		250		250		68.5		5 103.5	
		7		1059		35		0.09		810.17		0.386		0.61		213		37						68.5		4.2 105.7	
		8		1104		40		0.16		812.53		0.686		0.93		210		37		250		250		69		7 98.7	
		9		1109		45		0.17		814.95		0.728		0.95		212		37		250		250		69.5		7 82.0	
		10		1114		50		0.16		817.393		0.686		0.93		210		37						70.5		7 118.5	
B		11		1118		55		0.18		820.02		0.771		1.1		198		44		250		250		67.5		7.5 103.0	
		12		1158		60		0.19		822.57		0.814		1.1		209		38		250		250		70		7.5 97.7	
		13		1203		65		0.19		825.09		0.814		1.1		210		37						71		7.8 96.4	
		14		1208		70		0.13		827.57		0.557		0.8		206		38		250		250		73		6.2 113.9	
		15		1213		75		1.12		829.33		0.514		0.76		209		38		250		250		75		5.5 83.9	
		16		1218		80		0.03		830.80		0.129		0.37		213		39						76		4 140.3	
		17		1223		85		0.12		833.0		0.514		0.76		215		38		250		250		76.5		7 105.1	
		18		1228		90		0.19		835.46		0.814		1.1		216		38		250		250		78.5		7 93.1	
		19		1233		95		0.35		838.81		1.5		1.75		217		38						81		13.5 93.3	
		20		1238		100		1.40		842.409		1.714		1.95		217		39		250		250		82		15 93.7	
		21																									
		22																									
		23																									
		24																									
		25																									
TOTALS / AVERAGES		100		1744		50.476		1.091		1229		39.3		X		X		72.1		18.8		104.4					
FINAL LEAK CHECKS		ORSAT		COND. MOISTURE		DALTON'S LAW																					
Pnt (+)		C in H2O		Run #		% CO2		% Total		% O2		Imo.		Total		Tare		Net		Silica Gel Adsorbed H2O		13.2					
Pnt (-)		C in H2O		1								1		250		100		150		Vapor Pressure 2383/2475							
Nozzle Rate		2										2		250-132		100		282		Total ml H2O		618.2					
in. Hg. Vac.		24		3								3		178		0		173		Vw (std)							
Leak Cu. Fl.		Avg.												Volume Condensed H2O = 6.05						FINAL % H2O		38.68					
FINAL AVERAGES		V(m)=				Vm (std)= 46.201						FINAL Yo @ avg O. H.=								FINAL ISO % = 103.67							
TEST LEADER SIGNATURE:		Michael		WITNESS:		Jay R. King																					

N-EAST-CC2

4.4.26



5.0

M5 72

RUN # <u>8103</u> DATE <u>10-23-93</u>		THE EMISSION MEASUREMENT GROUP INC.		CONSOLE ID <u>CC-2</u> Meter ID											
PLANT <u>Pulp Dryers, North</u>		FIELD DATA SHEET METHODS -- M2,M3,M4,M5 Client <u>Holly Sugar</u>		PITOT ID <u>60-1</u> PITOT ID <u>60-1</u>											
DUCT/FLUE <u>East St. UNIT 8000</u>				NOZZLE ID <u>10-2</u>											
TEST LDR <u>MJL MJL</u>				FILTER ID (A) <u>7477</u> (B)											
HELPER(S) <u>JRF</u>				ORSAT BAG ID <u>11ST</u> BAROM ID <u>B</u>											
PRE-TEST CHECKS and CONDITIONS				CONSTANTS and CALCULATIONS											
Ambient Temp <u>45</u> Rel Hum <u>10</u> Weather <u>clear</u>		STACK TYPE <u>Roof</u> Diameter <u>63.0</u>		%O ₂ =											
Delta P Level <u>0</u> Zero: <u>✓</u>		NO. of POINTS <u>20</u> Min/Prnt <u>3.50</u>		%CO ₂ =											
Delta H Level <u>0</u> Zero: <u>✓</u>		Pbar <u>27.85/27.85</u> Ps		ppm SO ₂ =											
Pilot Lk. Chk. (+) <u>0</u> 5 in wg <u>0</u> 6 in wg <u>0</u>		Co <u>0.24</u> dn(des) <u>29.315</u>		ppm NO _x =											
Nozzle Leak Rate <u>0</u> CFM <u>0.24</u> in Hg.		Yo		ppm CO =											
Backswe Leak Rate <u>0</u> CFM <u>0</u> 10 in H ₂ O		Delta Ha		MW (s) =											
K3 <u>4.064</u>															
NE ASSUMED VALUES NE															
DATA SOURCE		Head, Delta P	Delta H, Orifice	Moisture	Calc. Volume	STACK	PROBE	FILTER	IMP.	G.MTR	Vac.	ISO			
Prev. Test or Estimate		in. H ₂ O	in. H ₂ O	%	DSCF	Deg. F	Deg. F	Deg. F	Deg. F	Deg. F	in. Hg	%			
CC-2 POINT -- BY -- POINT DATA EAST															
Location		Time		VELOCITY		DRY GAS METER		SYSTEM TEMPERATURES (Deg. F)						VAC.	RATE
Port/Prnt	Secd	Clock	Elap.	Delta P	Index Rdg.	Delta H Orifice	Stack	Probe	Filter	Imp.	G.Mtr.	Main	ISO		
Lt/No.	#	24 Hr.	Min.	in. H ₂ O	Cu. Ft.	in. H ₂ O	1	2	3	4	5	6	in. Hg	%	
START	0	2002.5	0		875.906	DES	ACT								
A	1	2007.5	5	0.20	888.46	0.813	1.0	209	42			64.5	2	100.2	
	2	2012.5	10	0.14	890.47	0.569	0.8	214	37	250	250	64.5	1.5	94.6	
	3	2017.5	15	0.07	891.52	0.285	0.4	214	37	250	250	65.5	1	69.6	
	4	2022.5	20	0.1	893.125	0.406	0.65	216	37			65.5	1	84.3	
	5	2027.5	25	0.1	894.84	0.406	0.65	223	40	250	250	65	1	96.0	
	6	2041	30	0.04	895.74	0.163	0.3	222	37	250	250	66.5	1	79.3	
	7	2046	35	0.11	897.42	0.447	0.69	212	36			57	1.5	88.6	
	8	2051	40	0.14	899.43	0.569	0.8	210	37	250	250	67	1.9	93.8	
	9	2056	45	0.17	901.99	0.772	1.1	206	36	250	250	67.5	2	102.3	
	10	2001	50	0.21	904.8	0.854	1.2	207	36			67.5	2	92.2	
B	11	2101	55	0.12	906.5	0.488	0.73	210	40	250	250	64.5	2	88.6	
	12	2106	60	0.14	908.53	0.569	0.4	212	35	250	250	64	2	93.1	
	13	2154	65	0.1	910.30	0.406	0.65	216	35			66	2	98.3	
	14	2159	70	0.1	912.03	0.406	0.65	218	34	250	250	65.5	2	96.4	
	15	2204	75	0.1	913.74	0.406	0.65	220	35	250	250	65	2	95.5	
	16	2209	80	0.15	915.89	0.610	0.86	227	36			66	2.2	98.4	
	17	2214	85	0.19	918.52	0.772	1.3	222	36	250	250	67.5	3	106.4	
	18	2219	90	0.22	921.19	0.894	1.4	220	39	250	250	67.5	3	100.2	
	19	2224	95	0.21	923.89	0.854	1.3	219	40			67.5	3	103.6	
	20	2229	100	0.20	926.404	0.813	1.2	217	42	250	250	66.5	3	98.9	
	21														
	22														
	23														
	24														
	25														
TOTALS / AVERAGES		100		0.1364	4A 400		0.862	2072	399	X	X	66.6	3.0	100.3	
FINAL LEAK CHECKS		ORSAT		COND. MOISTURE				DALTON'S LAW							
Prnt (+)	0	in H ₂ O	Run #	% CO ₂	% Total	% O ₂	Imp.	Total	Tare	Net	Silica Gel Adsorbed H ₂ O	7.9			
Prnt (-)	0	in H ₂ O	1				1	340	100	240	Vapor Pressure	2242/2383			
Nozzle Rate	0.02						2	341	100	241	Total ml H ₂ O	592.9			
in. Hg. Vac.	25	3					3	104	0	104	Vw (std)				
Leak Cu. Ft.		Avg.					Volume Condensed H ₂ O = 585				FINAL % H ₂ O	42.71			
FINAL AVERAGES		V(m) =		Vm (std) = 37.507			FINAL Yo @ avg O. H. =				FINAL ISO % = 101.08				
TEST LEADER SIGNATURE: <u>Michael R. [Signature]</u> WITNESS: <u>Jay R. [Signature]</u>															

N-EAST - CC2

4.4.28

⑤

4.4.2

Emission Data Printouts from CEM Tests

Holly Sugar, Sydney, MT

Stack ID - Name: South Pulp Drier - West Date(s): 10/22/93

Run No. ID:	¹⁰⁻²¹⁻⁹³ 5101	¹⁰⁻²² 5102	5103	5104 Aug.
Time, Start:	2056	0943	1524	1927
End:	2116	1335	1743	2159
Results, O ₂ (% dry)	14.120	14.076	14.370	13.70
CO ₂ (% dry)	5.4461	5.239	5.248	6.269
SO ₂ (ppm dry)	72.502	86.829	84.428	75.666
CO (ppm dry)	—	—	—	—
% H ₂ O (%)	38.24	39.91	38.53	33.72
V _m (std) (dscf)	9.019	45.688	47.336	54.088
Trak (kinetic) (%)	96.0	103.19	93.58	97.71
Zero Drift, Post Test	—	—	—	—
O ₂ cal zero	—	—	—	—
drift, %	—	—	—	—
CO ₂ cal zero	—	—	—	—
drift, %	—	—	—	—
SO ₂ cal zero	—	—	—	—
drift, %	—	—	—	—
Upscal Drift, Post Test	—	—	—	—
O ₂ cal span	—	—	—	—
drift, %	—	—	—	—
CO ₂ cal span	—	—	—	—
drift, %	—	—	—	—
SO ₂ cal span	—	—	—	—
drift, %	—	—	—	—
Spans	—	—	—	—
O ₂	—	—	—	—
CO ₂	—	—	—	—
SO ₂	—	—	—	—
	M5	M5	PM-10	PM-10

6000 east

500

STACK NO. 1
POINT NO. 3

5601

Series 5000 Tests

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
20:48	14.061	60.625	5.5671	0.0000	0.0000	0.0000	5.5132	0.0000	0.0000
20:49	14.130	62.551	5.5662	0.0000	0.0000	0.0000	5.5014	0.0000	0.0000
20:50	14.156	62.564	5.4648	0.0000	0.0000	0.0000	5.5367	0.0000	0.0000
20:50	13.916	62.210	5.5616	0.0000	0.0000	0.0000	5.0565	0.0000	0.0000
20:51	13.984	63.020	5.5317	0.0000	0.0000	0.0000	5.5757	0.0000	0.0000
20:51	14.036	70.454	5.4153	0.0000	0.0000	0.0000	5.5516	0.0000	0.0000
20:52	14.016	69.585	5.5033	0.0000	0.0000	0.0000	5.5531	0.0000	0.0000
20:52	14.067	63.174	5.5616	0.0000	0.0000	0.0000	5.5075	0.0000	0.0000
20:53	13.986	63.461	5.4535	0.0000	0.0000	0.0000	5.5651	0.0000	0.0000
20:53	13.564	66.527	5.5278	0.0000	0.0000	0.0000	5.3757	0.0000	0.0000

5 MIN

AVERAGE 14.041 64.553 5.5253 0.0000 0.0000 0.0000 5.5535 0.0000 0.0000

STACK NO. 1
POINT NO. 4

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
20:55	14.036	70.615	5.3806	0.0000	0.0000	0.0000	5.5345	0.0000	0.0000
20:55	14.116	71.631	5.4297	0.0000	0.0000	0.0000	5.6653	0.0000	0.0000
20:56	14.172	71.529	5.3953	0.0000	0.0000	0.0000	5.6174	0.0000	0.0000
20:56	14.172	71.222	5.3855	0.0000	0.0000	0.0000	5.6174	0.0000	0.0000
20:57	14.169	70.812	5.5131	0.0000	0.0000	0.0000	5.6200	0.0000	0.0000
20:57	14.110	70.536	5.5426	0.0000	0.0000	0.0000	5.6706	0.0000	0.0000
20:58	14.079	70.249	5.4542	0.0000	0.0000	0.0000	5.6672	0.0000	0.0000
20:58	13.980	69.939	5.6113	0.0000	0.0000	0.0000	5.6744	0.0000	0.0000
20:58	14.070	69.784	5.4542	0.0000	0.0000	0.0000	5.6052	0.0000	0.0000
20:58	14.135	66.713	5.4542	0.0000	0.0000	0.0000	5.6455	0.0000	0.0000

5 MIN

AVERAGE 14.105 70.423 5.4621 0.0000 0.0000 0.0000 5.6751 0.0000 0.0000

STACK NO. 1
POINT NO. 7

5101

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
21:13	14.147	53.760	5.4542	0.0000	0.0000	0.0000	5.6367	0.0000	0.0000
21:13	14.096	57.126	5.4669	0.0000	0.0000	0.0000	5.6312	0.0000	0.0000
21:14	14.162	55.225	5.4935	0.0000	0.0000	0.0000	5.6254	0.0000	0.0000
21:14	14.161	53.122	5.3315	0.0000	0.0000	0.0000	5.6094	0.0000	0.0000
21:15	14.101	58.989	5.5131	0.0000	0.0000	0.0000	5.6786	0.0000	0.0000
21:15	14.119	59.276	5.5573	0.0000	0.0000	0.0000	5.6636	0.0000	0.0000
21:16	14.045	70.915	5.5622	0.0000	0.0000	0.0000	5.6265	0.0000	0.0000
21:16	14.021	71.530	5.5917	0.0000	0.0000	0.0000	5.6475	0.0000	0.0000
21:17	14.119	73.116	5.4787	0.0000	0.0000	0.0000	5.6626	0.0000	0.0000
21:17	14.110	73.270	5.3413	0.0000	0.0000	0.0000	5.6706	0.0000	0.0000

5 MIN
AVERAGE 14.110 65.136 5.4792 0.0000 0.0000 0.0000 5.6703 0.0000 0.0000

STACK NO. 1
POINT NO. 8

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
21:19	14.236	75.316	5.3511	0.0000	0.0000	0.0000	5.7615	0.0000	0.0000
21:19	14.166	76.240	5.5062	0.0000	0.0000	0.0000	5.6227	0.0000	0.0000
21:20	14.135	76.496	5.3364	0.0000	0.0000	0.0000	5.6453	0.0000	0.0000
21:20	14.135	76.654	5.3315	0.0000	0.0000	0.0000	5.6433	0.0000	0.0000
21:21	14.136	76.603	5.3020	0.0000	0.0000	0.0000	5.6466	0.0000	0.0000
21:21	14.135	77.571	5.3560	0.0000	0.0000	0.0000	5.6433	0.0000	0.0000
21:22	14.116	76.266	5.4051	0.0000	0.0000	0.0000	5.6653	0.0000	0.0000
21:22	14.195	79.236	5.5229	0.0000	0.0000	0.0000	5.7934	0.0000	0.0000
21:23	14.064	76.746	5.4591	0.0000	0.0000	0.0000	5.9105	0.0000	0.0000
21:23	14.061	79.977	5.4444	0.0000	0.0000	0.0000	5.9132	0.0000	0.0000

5 MIN
AVERAGE 14.136 77.453 5.4017 0.0000 0.0000 0.0000 5.6461 0.0000 0.0000

14.098 70.787 5.467

STACK NO. 1
POINT NO. 3

5101

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	"F	LB/HR
21:51	14.248	57.346	5.5062	0.0000	0.0000	0.0000	5.7506	0.0000	0.0000
21:51	14.161	66.787	5.4156	0.0000	0.0000	0.0000	5.6054	0.0000	0.0000
21:52	14.159	72.246	5.2673	0.0000	0.0000	0.0000	5.6260	0.0000	0.0000
21:52	14.193	73.116	5.5160	0.0000	0.0000	0.0000	5.7367	0.0000	0.0000
21:53	14.230	74.151	5.4767	0.0000	0.0000	0.0000	5.7666	0.0000	0.0000
21:53	14.199	74.506	5.5160	0.0000	0.0000	0.0000	5.7654	0.0000	0.0000
21:54	14.122	76.166	5.2676	0.0000	0.0000	0.0000	5.6600	0.0000	0.0000
21:54	14.236	77.055	5.4365	0.0000	0.0000	0.0000	5.7615	0.0000	0.0000
21:55	14.221	77.660	5.4365	0.0000	0.0000	0.0000	5.7746	0.0000	0.0000
21:55	14.216	76.553	5.4767	0.0000	0.0000	0.0000	5.7774	0.0000	0.0000

5 MIN
AVERAGE 14.201 72.678 5.4355 0.0000 0.0000 0.0000 5.7621 0.0000 0.0000

STACK NO. 1
POINT NO. 4

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	"F	LB/HR
21:57	14.159	79.926	5.3413	0.0000	0.0000	0.0000	5.6260	0.0000	0.0000
21:57	14.107	80.541	5.4591	0.0000	0.0000	0.0000	5.6733	0.0000	0.0000
21:58	14.136	80.646	5.5131	0.0000	0.0000	0.0000	5.7661	0.0000	0.0000
21:58	14.141	80.694	5.3689	0.0000	0.0000	0.0000	5.6440	0.0000	0.0000
21:59	14.172	80.436	5.3757	0.0000	0.0000	0.0000	5.6174	0.0000	0.0000
21:59	14.164	80.499	5.5671	0.0000	0.0000	0.0000	5.6067	0.0000	0.0000
22:00	14.147	81.155	5.2726	0.0000	0.0000	0.0000	5.6367	0.0000	0.0000
22:00	14.221	81.206	5.3413	0.0000	0.0000	0.0000	5.7746	0.0000	0.0000
22:01	14.221	81.411	5.4146	0.0000	0.0000	0.0000	5.7746	0.0000	0.0000
22:01	14.172	81.155	5.4591	0.0000	0.0000	0.0000	5.6174	0.0000	0.0000

5 MIN
AVERAGE 14.172 80.766 5.4051 0.0000 0.0000 0.0000 5.6171 0.0000 0.0000

09:36 14.647 50.331 5.2077 0.0000 0.0000 399.86 5.4000 0.0000 0.0000

STACK NO. 1

POINT NO. 1 5102

W

TIME	02	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
09:38	14.604	66.153	5.2224	0.0000	0.0000	404.11	5.4432	0.0000	0.0000
09:39	14.678	70.500	5.0456	0.0000	0.0000	411.86	5.3734	0.0000	0.0000
09:40	14.537	75.372	5.0603	0.0000	0.0000	416.10	5.3635	0.0000	0.0000
09:40	14.558	75.216	5.2470	0.0000	0.0000	413.11	5.4630	0.0000	0.0000
09:41	14.820	76.752	5.0014	0.0000	0.0000	423.23	5.4255	0.0000	0.0000
09:41	14.703	77.827	4.8666	0.0000	0.0000	424.35	5.3562	0.0000	0.0000
09:42	14.611	79.851	5.0536	0.0000	0.0000	427.10	5.4373	0.0000	0.0000
09:42	14.683	79.517	5.0259	0.0000	0.0000	429.35	5.3674	0.0000	0.0000
09:43	14.681	80.131	4.9564	0.0000	0.0000	436.10	5.3756	0.0000	0.0000
09:43	14.617	81.785	4.9564	0.0000	0.0000	430.33	5.4325	0.0000	0.0000

5 MIN

AVERAGE 14.644 75.689 5.0562 0.0000 0.0000 426.56 5.4032 0.0000 0.0000

STACK NO. 1

POINT NO. 2

TIME	02	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
09:45	14.260	65.046	5.4266	0.0000	0.0000	534.31	5.7407	0.0000	0.0000
09:45	14.368	65.712	5.2568	0.0000	0.0000	539.19	5.6477	0.0000	0.0000
09:46	14.174	66.582	5.4435	0.0000	0.0000	545.31	5.6151	0.0000	0.0000
09:46	14.186	67.137	5.2912	0.0000	0.0000	540.94	5.7365	0.0000	0.0000
09:47	14.313	67.146	5.5363	0.0000	0.0000	535.13	5.6555	0.0000	0.0000
09:47	14.171	67.453	5.3747	0.0000	0.0000	533.44	5.6177	0.0000	0.0000
09:48	14.144	67.611	5.4337	0.0000	0.0000	540.06	5.6416	0.0000	0.0000
09:48	14.063	67.665	5.3600	0.0000	0.0000	540.61	5.6634	0.0000	0.0000
09:49	14.113	68.426	5.5416	0.0000	0.0000	548.93	5.6662	0.0000	0.0000
09:49	14.057	67.703	5.5565	0.0000	0.0000	556.16	5.6213	0.0000	0.0000

5 MIN

AVERAGE 14.183 67.105 5.4234 0.0000 0.0000 542.44 5.6034 0.0000 0.0000

STACK NO. 1
POINT NO. 5 5102

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
10:03	13.670	65.305	5.6022	0.0000	0.0000	561.05	6.0781	0.0000	0.0000
10:03	13.720	60.592	5.6955	0.0000	0.0000	606.29	6.2062	0.0000	0.0000
10:04	13.666	78.595	5.6741	0.0000	0.0000	622.26	6.2374	0.0000	0.0000
10:04	13.713	71.734	5.6857	0.0000	0.0000	600.17	6.2135	0.0000	0.0000
10:05	13.761	60.797	5.7256	0.0000	0.0000	591.17	6.1551	0.0000	0.0000
10:05	13.715	66.690	5.7432	0.0000	0.0000	566.67	6.2735	0.0000	0.0000
10:05	13.765	50.371	5.7776	0.0000	0.0000	592.17	6.1710	0.0000	0.0000
10:06	13.600	55.444	5.6201	0.0000	0.0000	530.05	6.1031	0.0000	0.0000
10:07	13.646	54.724	5.6316	0.0000	0.0000	528.17	6.0653	0.0000	0.0000
10:07	13.725	56.106	5.7554	0.0000	0.0000	525.55	6.2002	0.0000	0.0000

5 MIN
AVERAGE 13.762 / 65.656 / 5.6267 / 0.0000 0.0000 594.36 6.1716 0.0000 0.0000

STACK NO. 1
POINT NO. 6

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
10:08	13.643	67.736	5.6216	0.0000	0.0000	571.63	6.1020	0.0000	0.0000
10:09	13.793	57.161	5.7265	0.0000	0.0000	571.43	6.1445	0.0000	0.0000
10:10	13.601	67.642	5.6397	0.0000	0.0000	575.30	6.0515	0.0000	0.0000
10:10	13.656	57.551	5.7530	0.0000	0.0000	572.60	6.1073	0.0000	0.0000
10:11	13.670	66.506	5.6765	0.0000	0.0000	575.60	6.0761	0.0000	0.0000
10:11	13.661	66.620	5.6259	0.0000	0.0000	567.30	6.0660	0.0000	0.0000
10:12	13.757	66.076	5.7187	0.0000	0.0000	575.42	6.1763	0.0000	0.0000
10:12	13.666	66.076	5.7629	0.0000	0.0000	560.55	6.0646	0.0000	0.0000
10:13	13.752	65.076	5.6611	0.0000	0.0000	560.05	6.1976	0.0000	0.0000
10:13	13.775	66.176	5.7236	0.0000	0.0000	565.67	6.1604	0.0000	0.0000

5 MIN
AVERAGE 13.625 / 66.374 / 5.7636 / 0.0000 0.0000 576.22 6.1166 0.0000 0.0000

STACK NO. 1
POINT NO. 5

5102

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB "F	STEAM LB/HR
10:27	14.328	61.309	5.3109	0.0000	0.0000	465.06	5.6622	0.0000	0.0000
10:27	13.965	73.566	5.6843	0.0000	0.0000	541.06	5.6630	0.0000	0.0000
10:28	14.266	70.300	5.3895	0.0000	0.0000	478.33	5.7354	0.0000	0.0000
10:28	14.318	77.181	5.2323	0.0000	0.0000	460.53	5.6302	0.0000	0.0000
10:29	14.325	64.176	5.1436	0.0000	0.0000	450.46	5.6622	0.0000	0.0000
10:29	14.392	68.326	5.1537	0.0000	0.0000	454.97	5.6265	0.0000	0.0000
10:30	14.184	67.565	5.1753	0.0000	0.0000	453.72	5.6071	0.0000	0.0000
10:30	14.265	65.547	5.0696	0.0000	0.0000	454.54	5.7360	0.0000	0.0000
10:31	14.237	60.015	5.1195	0.0000	0.0000	457.53	5.7058	0.0000	0.0000
10:31	14.217	50.318	5.0456	0.0000	0.0000	452.09	5.7775	0.0000	0.0000

5 MIN
AVERAGE 14.256 65.656 5.2342 0.0000 0.0000 470.02 5.7441 0.0000 0.0000

STACK NO. 1
POINT NO. 10

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB "F	STEAM LB/HR
10:33	14.310	51.037	5.0658	0.0000	0.0000	451.84	5.6355	0.0000	0.0000
10:33	14.217	50.627	5.1436	0.0000	0.0000	454.22	5.7775	0.0000	0.0000
10:34	14.362	50.320	5.1530	0.0000	0.0000	448.22	5.6530	0.0000	0.0000
10:34	14.362	50.576	5.1664	0.0000	0.0000	451.09	5.6530	0.0000	0.0000
10:35	14.214	50.366	5.1144	0.0000	0.0000	445.72	5.7605	0.0000	0.0000
10:35	14.334	51.447	5.0253	0.0000	0.0000	452.57	5.6769	0.0000	0.0000
10:36	14.346	51.703	5.0357	0.0000	0.0000	455.46	5.6653	0.0000	0.0000
10:36	14.337	51.703	4.9766	0.0000	0.0000	467.53	5.6743	0.0000	0.0000
10:37	14.273	51.242	4.9766	0.0000	0.0000	466.96	5.7501	0.0000	0.0000
10:37	14.366	50.730	5.2617	0.0000	0.0000	470.05	5.6316	0.0000	0.0000

5 MIN
AVERAGE 14.314 51.037 5.0658 0.0000 0.0000 457.12 5.6359 0.0000 0.0000

STACK NO. 1
POINT NO. 1

15102

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
11:40	14.604	60.654	4.9227	0.0000	0.0000	470.34	5.4432	0.0000	0.0000
11:40	14.531	79.926	5.1340	0.0000	0.0000	463.56	5.5069	0.0000	0.0000
11:41	14.534	60.060	5.0556	0.0000	0.0000	460.48	5.5043	0.0000	0.0000
11:41	14.650	75.624	5.0210	0.0000	0.0000	454.22	5.4033	0.0000	0.0000
11:42	14.585	79.924	5.1537	0.0000	0.0000	456.53	5.4616	0.0000	0.0000
11:42	14.254	64.002	5.2077	0.0000	0.0000	470.46	5.7460	0.0000	0.0000
11:43	14.478	53.677	5.1054	0.0000	0.0000	456.97	5.5521	0.0000	0.0000
11:43	14.331	70.454	5.1045	0.0000	0.0000	466.34	5.6796	0.0000	0.0000
11:44	14.462	77.724	5.0645	0.0000	0.0000	456.53	5.5494	0.0000	0.0000
11:44	14.462	60.552	5.0603	0.0000	0.0000	456.03	5.5494	0.0000	0.0000

5 MIN
AVERAGE 14.453 / 75.180 / 5.0856 / 0.0000 / 0.0000 / 461.56 / 5.5356 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
11:46	14.429	62.996	5.0505	0.0000	0.0000	460.64	5.5946	0.0000	0.0000
11:46	14.471	64.175	5.1631	0.0000	0.0000	457.34	5.6105	0.0000	0.0000
11:47	14.365	64.535	5.1363	0.0000	0.0000	460.53	5.6504	0.0000	0.0000
11:47	14.454	65.966	4.9666	0.0000	0.0000	462.55	5.5733	0.0000	0.0000
11:48	14.556	66.650	4.9719	0.0000	0.0000	462.56	5.6236	0.0000	0.0000
11:48	14.452	67.606	5.0751	0.0000	0.0000	456.66	5.5513	0.0000	0.0000
11:49	14.406	66.221	5.0210	0.0000	0.0000	463.46	5.5895	0.0000	0.0000
11:49	14.265	66.764	5.0645	0.0000	0.0000	471.46	5.7360	0.0000	0.0000
11:50	14.276	66.477	5.1753	0.0000	0.0000	466.64	5.7274	0.0000	0.0000
11:50	14.406	67.703	5.1054	0.0000	0.0000	457.34	5.6132	0.0000	0.0000

5 MIN
AVERAGE 14.367 / 66.562 / 5.0795 / 0.0000 / 0.0000 / 462.23 / 5.6312 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 5

5102

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
12:04	14.160	56.116	5.1242	0.0000	0.0000	457.47	5.6088	0.0000	0.0000
12:04	14.137	57.658	5.2470	0.0000	0.0000	457.60	5.6469	0.0000	0.0000
12:05	14.270	57.655	4.9915	0.0000	0.0000	453.60	5.7527	0.0000	0.0000
12:05	14.164	57.402	5.2126	0.0000	0.0000	454.22	5.6071	0.0000	0.0000
12:06	14.303	57.350	4.9964	0.0000	0.0000	448.72	5.7035	0.0000	0.0000
12:06	14.300	57.197	5.0014	0.0000	0.0000	453.65	5.7062	0.0000	0.0000
12:07	14.147	57.246	5.2077	0.0000	0.0000	456.60	5.6330	0.0000	0.0000
12:07	14.236	56.982	5.0357	0.0000	0.0000	447.22	5.7616	0.0000	0.0000
12:08	14.206	57.760	5.1566	0.0000	0.0000	442.22	5.7656	0.0000	0.0000
12:08	14.159	57.985	5.2077	0.0000	0.0000	444.09	5.6263	0.0000	0.0000

5 MIN

AVERAGE 14.212 57.525 5.1165 0.0000 0.0000 440.15 5.7521 0.0000 0.0000

STACK NO. 1
POINT NO. 6

5102

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
12:10	14.164	59.194	5.0885	0.0000	0.0000	476.56	5.6071	0.0000	0.0000
12:10	14.174	59.706	5.0161	0.0000	0.0000	466.33	5.6151	0.0000	0.0000
12:11	14.070	59.659	5.2274	0.0000	0.0000	461.03	5.6054	0.0000	0.0000
12:11	14.065	59.911	5.2765	0.0000	0.0000	465.06	5.6321	0.0000	0.0000
12:12	14.015	59.655	5.1575	0.0000	0.0000	454.56	5.6532	0.0000	0.0000
12:12	14.126	59.423	5.2026	0.0000	0.0000	455.06	5.6549	0.0000	0.0000
12:13	14.039	59.679	5.2372	0.0000	0.0000	512.32	5.6319	0.0000	0.0000
12:13	14.125	59.167	5.0701	0.0000	0.0000	505.62	5.6576	0.0000	0.0000
12:14	14.162	59.474	5.0696	0.0000	0.0000	497.63	5.6257	0.0000	0.0000
12:14	14.171	59.652	5.1045	0.0000	0.0000	494.70	5.6177	0.0000	0.0000

5 MIN

AVERAGE 14.115 59.110 5.1522 0.0000 0.0000 493.14 5.6661 0.0000 0.0000

STACK NO. 1
POINT NO. 7

5107

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB "F	STEAM LB/HR
12:16	14.015	51.139	5.1034	0.0000	0.0000	529.57	5.3532	0.0000	0.0000
12:16	14.125	50.660	4.9817	0.0000	0.0000	533.06	5.3576	0.0000	0.0000
12:17	13.990	51.139	5.0751	0.0000	0.0000	530.57	5.3745	0.0000	0.0000
12:17	14.065	51.447	5.0063	0.0000	0.0000	522.19	5.3921	0.0000	0.0000
12:18	14.174	51.395	5.3649	0.0000	0.0000	505.20	5.3151	0.0000	0.0000
12:18	14.051	50.730	5.2553	0.0000	0.0000	507.45	5.3213	0.0000	0.0000
12:18	14.125	51.139	5.2175	0.0000	0.0000	511.20	5.3576	0.0000	0.0000
12:19	14.045	52.010	5.4209	0.0000	0.0000	504.32	5.3256	0.0000	0.0000
12:20	13.978	52.727	5.3846	0.0000	0.0000	505.95	5.3651	0.0000	0.0000
12:20	14.045	52.419	5.2561	0.0000	0.0000	506.32	5.3256	0.0000	0.0000

5 MIN
AVERAGE 14.065 / 51.500 / 5.2116 / 0.0000 0.0000 515.66 5.3110 0.0000 0.0000

STACK NO. 1
POINT NO. 6

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB "F	STEAM LB/HR
12:22	14.024	53.065	5.2617	0.0000	0.0000	509.45	5.3452	0.0000	0.0000
12:22	13.978	52.660	5.3600	0.0000	0.0000	502.20	5.3651	0.0000	0.0000
12:23	13.972	52.163	5.4042	0.0000	0.0000	497.33	5.3304	0.0000	0.0000
12:23	14.116	52.317	5.3305	0.0000	0.0000	496.70	5.3523	0.0000	0.0000
12:24	14.015	52.163	5.4051	0.0000	0.0000	500.20	5.3532	0.0000	0.0000
12:24	14.051	51.754	5.2224	0.0000	0.0000	502.06	5.3668	0.0000	0.0000
12:25	13.993	51.242	5.3305	0.0000	0.0000	492.95	5.3716	0.0000	0.0000
12:25	14.027	51.066	5.1467	0.0000	0.0000	495.65	5.3425	0.0000	0.0000
12:26	14.036	52.727	5.3600	0.0000	0.0000	484.45	5.3615	0.0000	0.0000
12:26	14.011	53.290	5.2274	0.0000	0.0000	497.45	5.3553	0.0000	0.0000

5 MIN
AVERAGE 14.033 / 52.271 / 5.3055 / 0.0000 0.0000 496.66 5.3375 0.0000 0.0000

STACK NO. 1
POINT NO. 1

6102

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	°F	LB/HR
13:23	13.662	77.923	4.9123	0.0000	0.0000	524.63	6.0674	0.0000	0.0000
13:23	13.660	62.057	5.1045	0.0000	0.0000	506.45	6.1331	0.0000	0.0000
13:24	13.632	61.269	4.9364	0.0000	0.0000	521.44	6.0555	0.0000	0.0000
13:24	13.764	73.116	5.2077	0.0000	0.0000	532.81	6.1524	0.0000	0.0000
13:25	13.800	60.643	5.1575	0.0000	0.0000	556.18	6.1331	0.0000	0.0000
13:25	13.725	63.510	5.2175	0.0000	0.0000	567.30	6.2002	0.0000	0.0000
13:26	13.633	64.276	5.0161	0.0000	0.0000	570.76	6.1095	0.0000	0.0000
13:26	13.741	65.354	5.1630	0.0000	0.0000	566.60	6.1636	0.0000	0.0000
13:27	13.750	65.700	5.1565	0.0000	0.0000	572.43	6.1617	0.0000	0.0000
13:27	13.803	67.705	5.1733	0.0000	0.0000	571.30	6.1312	0.0000	0.0000

5 MIN

AVERAGE	13.662	76.262	5.1178	0.0000	0.0000	549.58	6.1370	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

STACK NO. 1

POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	°F	LB/HR
13:25	13.744	60.064	5.2470	0.0000	0.0000	577.43	6.1670	0.0000	0.0000
13:25	13.635	60.115	5.0210	0.0000	0.0000	575.93	6.1046	0.0000	0.0000
13:30	13.615	60.750	5.3404	0.0000	0.0000	575.05	6.2365	0.0000	0.0000
13:30	13.656	60.935	5.1733	0.0000	0.0000	566.05	6.2513	0.0000	0.0000
13:31	13.621	61.355	5.2657	0.0000	0.0000	566.52	6.2332	0.0000	0.0000
13:31	13.636	61.344	5.1762	0.0000	0.0000	551.05	6.2266	0.0000	0.0000
13:32	13.656	61.365	5.2716	0.0000	0.0000	562.67	6.2613	0.0000	0.0000
13:32	13.757	61.242	5.0255	0.0000	0.0000	564.05	6.1763	0.0000	0.0000
13:33	13.736	60.761	5.0500	0.0000	0.0000	560.17	6.1323	0.0000	0.0000
13:33	13.750	60.263	5.0347	0.0000	0.0000	574.66	6.1471	0.0000	0.0000

5 MIN

AVERAGE	13.712	60.627	5.1635	0.0000	0.0000	561.20	6.2146	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

M

STACK NO. 1
POINT NO. 1

5103 W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX ISO PPM,D	CO PPM,D	CO2 %,D	TEMP °F	STEAM LB/HR
15:31	15.369	64.642	6.3862	0.0000	0.0000	762.61	6.5721	0.0000	0.0000
15:31	15.317	94.160	6.0799	0.0000	0.0000	747.62	6.5562	0.0000	0.0000
15:32	15.335	62.696	6.6764	0.0000	0.0000	453.72	4.2425	0.0000	0.0000
15:32	15.246	62.976	4.4566	0.0000	0.0000	166.56	1.4253	0.0000	0.0000
15:33	20.446	47.464	0.4574	0.0000	0.0000	71.725	0.3607	0.0000	0.0000
15:33	20.607	57.826	0.1626	0.0000	0.0000	56.565	0.0652	0.0000	0.0000
15:34	20.665	31.335	0.1577	0.0000	0.0000	13.663	0.0234	0.0000	0.0000
15:34	20.916	27.597	0.1862	0.0000	0.0000	13.665	-0.0715	0.0000	0.0000
15:35	20.466	25.652	0.5962	0.0000	0.0000	47.755	0.3562	0.0000	0.0000
15:35	16.316	20.314	2.2676	0.0000	0.0000	115.06	2.2065	0.0000	0.0000

5 MIN
AVERAGE 16.353 52.256 2.1511 0.0000 0.0000 246.55 2.1663 0.0000 0.0000

STACK NO.
POINT NO.

5103

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX ISO PPM,D	CO PPM,D	CO2 %,D	TEMP °F	STEAM LB/HR
15:36	14.884	60.260	6.6216	0.0000	0.0000	100.85	0.1433	0.0000	0.0000
15:36	14.802	97.122	6.0000	0.0000	0.0000	146.12	0.1618	0.0000	0.0000
15:37	14.654	49.363	5.4671	0.0000	0.0000	341.36	1.5643	0.0000	0.0000
15:37	14.656	56.322	5.6470	0.0000	0.0000	462.71	5.5346	0.0000	0.0000
15:38	13.916	61.493	5.6520	0.0000	0.0000	423.72	6.0362	0.0000	0.0000
15:38	13.630	66.409	6.6661	0.0000	0.0000	476.46	6.1126	0.0000	0.0000
15:39	13.603	71.427	6.0761	0.0000	0.0000	565.65	6.3692	0.0000	0.0000
15:39	13.416	75.062	6.0061	0.0000	0.0000	529.62	6.4712	0.0000	0.0000
15:40	13.366	76.544	6.1634	0.0000	0.0000	546.06	6.4651	0.0000	0.0000
15:40	13.243	61.667	6.2422	0.0000	0.0000	562.42	6.6266	0.0000	0.0000
15:41	13.216	64.642	6.3866	0.0000	0.0000	606.66	6.5412	0.0000	0.0000
15:41	13.247	66.665	6.0564	0.0000	0.0000	612.04	6.6173	0.0000	0.0000

5 MIN
AVERAGE 13.643 71.201 5.9456 0.0000 0.0000 562.76 6.2744 0.0000 0.0000

STACK NO. 1
POINT NO. 5

503

W

TIME 24 HR.	O2 %	SO2 #1 PPM	SO2 #2 PPM	NOX PPM	NOXISO PPM	CO PPM	CO2 %	TEMP °F	STEAM LB/HR
15:55	12.656	81.703	6.6375	0.0000	0.0000	646.33	6.5547	0.0000	0.0000
15:56	12.645	77.053	6.5515	0.0000	0.0000	652.26	6.6776	0.0000	0.0000
15:56	12.657	76.555	6.7145	0.0000	0.0000	634.71	7.0526	0.0000	0.0000
15:56	12.657	82.624	6.7764	0.0000	0.0000	652.57	7.0526	0.0000	0.0000
15:57	12.730	101.66	6.7566	0.0000	0.0000	654.44	7.0536	0.0000	0.0000
15:57	12.730	105.96	6.5505	0.0000	0.0000	606.69	7.0217	0.0000	0.0000
15:56	12.672	106.53	6.7663	0.0000	0.0000	615.05	7.1140	0.0000	0.0000
15:56	12.776	110.23	6.6715	0.0000	0.0000	616.55	7.0237	0.0000	0.0000
15:55	12.773	111.10	6.6600	0.0000	0.0000	604.53	7.0254	0.0000	0.0000
15:55	12.673	112.54	6.5556	0.0000	0.0000	605.61	6.5519	0.0000	0.0000

5 MIN

AVERAGE	12.774	85.014	6.7666	0.0000	0.0000	671.31	7.0255	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

STACK NO. 1
POINT NO. 6

TIME 24 HR.	O2 %	SO2 #1 PPM	SO2 #2 PPM	NOX PPM	NOXISO PPM	CO PPM	CO2 %	TEMP °F	STEAM LB/HR
16:01	12.623	81.132	6.7666	0.0000	0.0000	639.07	6.9766	0.0000	0.0000
16:01	12.735	115.20	6.9063	0.0000	0.0000	612.19	7.0076	0.0000	0.0000
16:02	12.693	115.66	6.8766	0.0000	0.0000	607.44	6.9226	0.0000	0.0000
16:02	12.973	115.76	6.7666	0.0000	0.0000	605.56	6.9537	0.0000	0.0000
16:03	12.506	116.74	6.7561	0.0000	0.0000	635.60	6.9122	0.0000	0.0000
16:03	12.666	117.56	6.8030	0.0000	0.0000	626.35	6.9467	0.0000	0.0000
16:04	12.641	117.50	6.8079	0.0000	0.0000	624.31	6.9673	0.0000	0.0000
16:04	12.633	117.25	6.7566	0.0000	0.0000	636.33	6.8663	0.0000	0.0000
16:05	12.650	117.56	6.7591	0.0000	0.0000	654.60	6.8600	0.0000	0.0000
16:05	12.761	116.63	6.7663	0.0000	0.0000	665.04	7.0370	0.0000	0.0000

5 MIN

AVERAGE	12.665	116.56	6.8025	0.0000	0.0000	627.01	6.9475	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

M

STACK NO. 1
POINT NO. 11 5103

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
16:31	15.265	66.354	3.4335	0.0000	0.0000	214.30	3.9675	0.0000	0.0000
16:31	15.153	67.535	3.3026	0.0000	0.0000	217.17	4.1043	0.0000	0.0000
16:32	15.306	66.616	3.2564	0.0000	0.0000	211.05	3.9715	0.0000	0.0000
16:32	15.214	66.405	3.3652	0.0000	0.0000	213.05	4.0512	0.0000	0.0000
16:33	15.156	64.621	3.2268	0.0000	0.0000	216.30	4.0672	0.0000	0.0000
16:33	15.005	64.565	3.6450	0.0000	0.0000	245.79	4.2316	0.0000	0.0000
16:34	15.646	65.180	3.9401	0.0000	0.0000	253.66	4.3700	0.0000	0.0000
16:34	15.747	66.102	3.8647	0.0000	0.0000	272.90	4.4550	0.0000	0.0000
16:35	15.665	67.025	4.0562	0.0000	0.0000	261.27	4.5106	0.0000	0.0000
16:35	15.643	66.354	4.1520	0.0000	0.0000	260.55	4.5450	0.0000	0.0000

5 MIN
AVERAGE 15.005 / 66.516 / 3.6346 / 0.0000 0.0000 241.60 4.2295 0.0000 0.0000

STACK NO. 1
POINT NO. 12

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
16:37	15.265	73.215	4.3676	0.0000	0.0000	353.63	4.6720	0.0000	0.0000
16:37	15.246	75.164	4.2569	0.0000	0.0000	353.25	4.6660	0.0000	0.0000
16:38	15.336	75.676	4.2549	0.0000	0.0000	353.13	4.6105	0.0000	0.0000
16:38	15.639	64.770	3.7627	0.0000	0.0000	329.63	4.3753	0.0000	0.0000
16:39	15.646	61.304	4.0326	0.0000	0.0000	345.63	4.5426	0.0000	0.0000
16:39	15.095	66.066	4.4568	0.0000	0.0000	405.46	5.0161	0.0000	0.0000
16:40	14.666	64.053	4.5634	0.0000	0.0000	431.60	5.2174	0.0000	0.0000
16:40	14.512	66.563	4.5656	0.0000	0.0000	442.97	5.1775	0.0000	0.0000
16:41	14.715	66.563	4.7223	0.0000	0.0000	460.64	5.3475	0.0000	0.0000
16:41	14.667	66.634	4.7665	0.0000	0.0000	468.59	5.3714	0.0000	0.0000

5 MIN
AVERAGE 15.161 / 66.644 / 4.3632 / 0.0000 0.0000 355.17 4.5621 0.0000 0.0000

CALIBRATION MODE

TIME 24 HR.	CO %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	SO2 %,D	7-AME "F	STEAM LB/HR
16:56	20.672	12.339	0.0363	0.0000	0.0000	7.1225	0.0241	0.0000	0.0000
16:56	20.696	10.136	0.1574	0.0000	0.0000	-0.743	0.0025	0.0000	0.0000
16:57	2.4645	1.0432	10.737	0.0000	0.0000	55.555	15.514	0.0000	0.0000
16:57	0.2457	1.4646	11.564	0.0000	0.0000	101.03	17.655	0.0000	0.0000
16:58	0.1966	1.2600	11.707	0.0000	0.0000	55.716	17.307	0.0000	0.0000
16:58	0.0796	1.1776	11.615	0.0000	0.0000	103.21	18.002	0.0000	0.0000
16:58	0.1761	1.3524	12.075	0.0000	0.0000	102.09	17.917	0.0000	0.0000
16:59	0.0952	1.0752	11.731	0.0000	0.0000	101.96	17.566	0.0000	0.0000
17:00	0.1669	1.0752	11.805	0.0000	0.0000	99.591	17.525	0.0000	0.0000
17:00	0.1105	1.0240	11.766	0.0000	0.0000	96.716	17.576	0.0000	0.0000
17:01	0.1443	1.1776	11.699	0.0000	0.0000	104.71	17.546	0.0000	0.0000
17:01	0.0430	1.1264	11.722	0.0000	0.0000	99.666	18.034	0.0000	0.0000
17:02	0.1413	1.0752	11.630	0.0000	0.0000	103.09	17.649	0.0000	0.0000
17:02	0.2466	37.562	9.3166	0.0000	0.0000	73.650	17.656	0.0000	0.0000
17:03	6.9891	97.486	0.0560	0.0000	0.0000	-0.999	12.026	0.0000	0.0000
17:03	7.1667	97.949	0.1229	0.0000	0.0000	2.3741	11.855	0.0000	0.0000
17:04	7.1345	96.001	0.0635	0.0000	0.0000	0.3956	11.650	0.0000	0.0000
17:04	7.1920	97.949	0.1229	0.0000	0.0000	1.9743	11.847	0.0000	0.0000
17:05	7.2225	97.896	0.0963	0.0000	0.0000	2.1242	11.826	0.0000	0.0000
17:05	7.1765	96.052	0.0666	0.0000	0.0000	0.3746	11.666	0.0000	0.0000
17:06	7.2010	98.154	-0.063	0.0000	0.0000	-0.749	11.645	0.0000	0.0000
17:06	7.2267	98.103	0.0963	0.0000	0.0000	-1.249	11.821	0.0000	0.0000
17:07	7.0362	98.001	0.0590	0.0000	0.0000	1.6244	11.965	0.0000	0.0000
17:07	7.0321	97.847	-0.019	0.0000	0.0000	0.2493	11.951	0.0000	0.0000
17:08	7.1273	97.744	-0.014	0.0000	0.0000	-2.749	11.908	0.0000	0.0000
17:08	7.2746	97.689	0.0705	0.0000	0.0000	155.69	11.781	0.0000	0.0000
17:09	13.720	65.670	5.6667	0.0000	0.0000	686.07	6.2062	0.0000	0.0000
17:09	13.677	69.430	5.6667	0.0000	0.0000	667.76	6.2454	0.0000	0.0000
17:10	13.612	73.835	5.6421	0.0000	0.0000	667.01	6.1265	0.0000	0.0000
17:10	13.765	64.276	5.4945	0.0000	0.0000	700.65	6.1445	0.0000	0.0000
17:11	13.772	91.851	5.6667	0.0000	0.0000	700.51	6.1631	0.0000	0.0000
17:11	13.800	98.260	5.5260	0.0000	0.0000	684.01	6.1391	0.0000	0.0000
17:12	13.765	95.434	5.6715	0.0000	0.0000	639.26	6.1657	0.0000	0.0000
17:12	13.744	100.61	5.5191	0.0000	0.0000	706.66	6.1670	0.0000	0.0000
17:13	13.636	101.27	5.5929	0.0000	0.0000	707.26	6.2269	0.0000	0.0000
17:13	13.750	101.62	5.5055	0.0000	0.0000	669.64	6.1471	0.0000	0.0000
17:14	13.720	101.76	5.5505	0.0000	0.0000	707.26	6.2062	0.0000	0.0000
17:14	13.760	102.14	5.7454	0.0000	0.0000	714.66	6.1737	0.0000	0.0000
17:15	13.632	102.50	5.6520	0.0000	0.0000	702.56	6.2021	0.0000	0.0000
17:15	13.655	101.94	5.4856	0.0000	0.0000	667.76	6.0913	0.0000	0.0000
17:16	13.630	102.76	5.6224	0.0000	0.0000	703.65	6.1726	0.0000	0.0000
17:16	13.763	103.17	5.6274	0.0000	0.0000	721.36	6.1657	0.0000	0.0000
17:17	13.744	103.66	5.6615	0.0000	0.0000	714.66	6.1670	0.0000	0.0000

13.14 85.0 5.65

STACK NO. 1
POINT NO. 3

5103

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
17:30	14.356	66.564	5.1256	0.0000	0.0000	535.67	5.6563	0.0000	0.0000
17:30	14.475	67.744	5.1746	0.0000	0.0000	533.42	5.6521	0.0000	0.0000
17:31	14.494	66.813	4.5435	0.0000	0.0000	536.43	5.5566	0.0000	0.0000
17:31	14.644	64.526	4.8354	0.0000	0.0000	532.61	5.4065	0.0000	0.0000
17:32	14.675	65.557	5.0026	0.0000	0.0000	533.66	5.5521	0.0000	0.0000
17:32	14.617	67.805	4.5436	0.0000	0.0000	543.54	5.4575	0.0000	0.0000
17:33	14.764	60.520	4.8256	0.0000	0.0000	521.63	5.3050	0.0000	0.0000
17:33	14.835	63.040	4.8305	0.0000	0.0000	493.63	5.2435	0.0000	0.0000
17:34	14.765	65.374	4.7321	0.0000	0.0000	460.70	5.2765	0.0000	0.0000
17:34	14.781	67.605	4.7025	0.0000	0.0000	486.63	5.3077	0.0000	0.0000

5 MIN
AVERAGE 14.647 62.660 / 4.9116 0.0000 0.0000 540.50 5.4115 0.0000 0.0000

STACK NO. 1
POINT NO. 4

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
17:36	14.562	65.455	4.7415	0.0000	0.0000	449.47	5.1164	0.0000	0.0000
17:36	14.666	64.381	4.6140	0.0000	0.0000	446.47	5.2174	0.0000	0.0000
17:37	14.805	64.432	4.6059	0.0000	0.0000	446.22	5.1826	0.0000	0.0000
17:37	14.846	63.669	4.5766	0.0000	0.0000	431.60	5.1457	0.0000	0.0000
17:38	14.864	63.305	4.5648	0.0000	0.0000	430.72	5.1324	0.0000	0.0000
17:38	14.927	62.947	4.6059	0.0000	0.0000	442.22	5.1642	0.0000	0.0000
17:39	14.905	62.935	4.6236	0.0000	0.0000	433.35	5.1628	0.0000	0.0000
17:39	14.678	62.466	4.5648	0.0000	0.0000	427.40	5.2063	0.0000	0.0000
17:40	14.909	61.616	4.5003	0.0000	0.0000	416.65	5.1602	0.0000	0.0000
17:40	14.842	61.417	4.7469	0.0000	0.0000	420.75	5.1510	0.0000	0.0000

5 MIN
AVERAGE 14.825 63.230 / 4.6750 0.0000 0.0000 435.31 5.1630 0.0000 0.0000

14.370 64.479 5.248

STACK NO. 1
POINT NO. 5 5104

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB "F	STEAM LB/HR
18:23	13.240	66.576	5.2613	0.0000	0.0000	764.88	6.6226	0.0000	0.0000
18:23	13.233	66.272	5.0701	0.0000	0.0000	756.93	6.5721	0.0000	0.0000
18:24	13.403	67.656	5.9471	0.0000	0.0000	741.74	6.4616	0.0000	0.0000
18:24	13.523	66.941	5.6536	0.0000	0.0000	716.13	6.3726	0.0000	0.0000
18:25	13.566	66.013	5.3615	0.0000	0.0000	701.65	6.3410	0.0000	0.0000
18:25	13.664	65.712	5.6536	0.0000	0.0000	719.65	6.2550	0.0000	0.0000
18:26	13.683	65.614	5.8467	0.0000	0.0000	705.13	6.2401	0.0000	0.0000
18:26	13.670	65.507	5.7454	0.0000	0.0000	656.36	6.2507	0.0000	0.0000
18:27	13.612	65.200	5.6054	0.0000	0.0000	656.01	6.1205	0.0000	0.0000
18:27	13.677	65.066	5.5660	0.0000	0.0000	664.35	6.2454	0.0000	0.0000

5 MIN
AVERAGE 13.554 66.460 5.6558 0.0000 0.0000 716.30 6.3511 0.0000 0.0000

STACK NO. 1 6104
POINT NO. 4

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB "F	STEAM LB/HR
18:25	13.636	65.664	5.5733	0.0000	0.0000	661.77	6.1073	0.0000	0.0000
18:25	13.813	63.664	5.5536	0.0000	0.0000	673.77	6.0408	0.0000	0.0000
18:30	14.008	63.971	5.8566	0.0000	0.0000	649.28	5.8565	0.0000	0.0000
18:30	14.513	66.373	5.4454	0.0000	0.0000	515.70	5.6302	0.0000	0.0000
18:31	14.485	47.413	5.1551	0.0000	0.0000	560.56	5.5468	0.0000	0.0000
18:31	14.123	72.655	5.6667	0.0000	0.0000	635.66	5.8543	0.0000	0.0000
18:32	14.050	76.035	5.6616	0.0000	0.0000	610.66	5.3353	0.0000	0.0000
18:32	13.996	80.131	5.6323	0.0000	0.0000	615.29	5.9691	0.0000	0.0000
18:33	14.101	63.510	5.7405	0.0000	0.0000	619.04	5.6763	0.0000	0.0000
18:33	14.223	61.001	5.6372	0.0000	0.0000	550.67	5.7725	0.0000	0.0000

5 MIN
AVERAGE 14.104 74.642 5.5324 0.0000 0.0000 610.24 5.6753 0.0000 0.0000

STACK NO. 1
POINT NO. 5 5104

E

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
19:35	14.223	63.561	5.4257	0.0000	0.0000	575.30	5.7726	0.0000	0.0000
19:36	14.331	63.152	5.4096	0.0000	0.0000	563.60	5.6756	0.0000	0.0000
19:36	14.227	62.966	5.2732	0.0000	0.0000	543.44	5.7655	0.0000	0.0000
19:36	14.298	63.613	5.3765	0.0000	0.0000	561.61	5.7166	0.0000	0.0000
19:37	14.353	63.406	5.4109	0.0000	0.0000	560.66	5.6610	0.0000	0.0000
19:37	14.423	63.306	5.3371	0.0000	0.0000	543.93	5.5969	0.0000	0.0000
19:38	14.266	63.049	5.2584	0.0000	0.0000	554.06	5.7354	0.0000	0.0000
19:38	14.220	63.203	5.2732	0.0000	0.0000	565.05	5.7752	0.0000	0.0000
19:39	14.260	63.561	5.2181	0.0000	0.0000	563.60	5.7407	0.0000	0.0000
19:39	14.371	63.254	5.3663	0.0000	0.0000	543.43	5.6451	0.0000	0.0000
19:40	14.217	63.306	5.5273	0.0000	0.0000	553.16	5.7779	0.0000	0.0000
19:40	14.195	63.510	5.2630	0.0000	0.0000	564.43	5.7506	0.0000	0.0000
19:41	14.343	63.715	5.3614	0.0000	0.0000	559.93	5.6630	0.0000	0.0000
19:41	14.313	63.453	5.2976	0.0000	0.0000	550.43	5.6355	0.0000	0.0000

7 MIN
AVERAGE 14.266 / 63.357 / 5.3365 / 0.0000 / 0.0000 / 556.51 / 5.7166 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 6 5104

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
19:43	14.377	63.357	5.3614	0.0000	0.0000	551.66	5.6397	0.0000	0.0000
19:43	14.457	62.742	5.3519	0.0000	0.0000	539.19	5.5707	0.0000	0.0000
19:44	14.257	62.753	5.2535	0.0000	0.0000	545.06	5.7433	0.0000	0.0000
19:44	14.276	62.667	5.2663	0.0000	0.0000	550.61	5.7274	0.0000	0.0000
19:45	14.374	62.077	5.3076	0.0000	0.0000	541.19	5.6424	0.0000	0.0000
19:45	14.446	62.025	5.5273	0.0000	0.0000	527.34	5.5766	0.0000	0.0000
19:46	14.261	61.672	5.2269	0.0000	0.0000	513.57	5.7141	0.0000	0.0000
19:46	14.405	61.462	5.3421	0.0000	0.0000	522.32	5.6156	0.0000	0.0000
19:47	14.356	61.360	5.2161	0.0000	0.0000	527.44	5.6553	0.0000	0.0000
19:47	14.423	61.155	5.1639	0.0000	0.0000	525.62	5.5956	0.0000	0.0000
19:48	14.472	60.265	5.1639	0.0000	0.0000	522.69	5.5574	0.0000	0.0000
19:48	14.254	71.222	5.2564	0.0000	0.0000	511.75	5.7460	0.0000	0.0000
19:49	14.125	57.756	5.2336	0.0000	0.0000	634.03	5.6576	0.0000	0.0000
19:49	14.362	49.512	5.0715	0.0000	0.0000	551.43	5.6265	0.0000	0.0000

7 MIN
AVERAGE 14.351 / 77.165 / 5.2560 / 0.0000 / 0.0000 / 546.93 / 5.6627 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 7

5104

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
18:51	14.588	62.927	4.9535	0.0000	0.0000	477.55	5.4544	0.0000	0.0000
18:51	14.585	64.758	4.9848	0.0000	0.0000	460.21	5.4585	0.0000	0.0000
18:52	14.555	64.715	5.0556	0.0000	0.0000	451.65	5.4657	0.0000	0.0000
18:52	14.435	64.185	4.8662	0.0000	0.0000	455.21	5.5635	0.0000	0.0000
18:53	14.485	64.207	4.9555	0.0000	0.0000	450.20	5.5601	0.0000	0.0000
18:53	14.294	64.617	5.1255	0.0000	0.0000	518.69	5.7115	0.0000	0.0000
18:54	14.205	65.160	5.2437	0.0000	0.0000	530.65	5.7585	0.0000	0.0000
18:54	14.174	66.153	5.2535	0.0000	0.0000	535.94	5.8151	0.0000	0.0000
18:55	14.061	67.177	5.1737	0.0000	0.0000	555.58	5.9134	0.0000	0.0000
18:55	15.925	67.586	5.4386	0.0000	0.0000	572.86	6.0502	0.0000	0.0000
18:56	15.645	68.615	5.5339	0.0000	0.0000	572.05	6.0956	0.0000	0.0000
18:56	17.262	15.566	2.7202	0.0000	0.0000	134.16	5.1454	0.0000	0.0000
18:57	20.779	5.5610	0.2902	0.0000	0.0000	8.7470	0.1056	0.0000	0.0000
18:57	20.716	4.4055	0.0544	0.0000	0.0000	1.5555	0.1563	0.0000	0.0000

7 MIN
AVERAGE 15.421 55.506 4.2568 0.0000 0.0000 422.55 4.7565 0.0000 0.0000

STACK NO. 1
POINT NO. 8

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR

STACK NO. 1

POINT NO. 1 5104

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
20:06	13.474	56.472	6.7635	0.0000	0.0000	666.63	6.4267	0.0000	0.0000
20:07	13.566	57.864	6.6650	0.0000	0.0000	666.14	6.3410	0.0000	0.0000
20:10	13.664	73.167	6.7440	0.0000	0.0000	665.36	6.2560	0.0000	0.0000
20:10	13.531	75.472	6.5564	0.0000	0.0000	666.07	6.3156	0.0000	0.0000
20:11	13.536	76.240	6.5617	0.0000	0.0000	664.01	6.3224	0.0000	0.0000
20:11	13.517	77.161	6.6217	0.0000	0.0000	664.26	6.3635	0.0000	0.0000
20:12	13.608	76.556	6.7566	0.0000	0.0000	675.36	6.3036	0.0000	0.0000
20:12	13.637	77.066	6.6751	0.0000	0.0000	675.52	6.2755	0.0000	0.0000
20:13	13.664	76.544	6.7637	0.0000	0.0000	664.78	6.2560	0.0000	0.0000
20:13	13.612	73.773	6.9663	0.0000	0.0000	705.01	6.3012	0.0000	0.0000
20:14	13.652	60.367	6.6424	0.0000	0.0000	711.50	6.2667	0.0000	0.0000
20:14	13.575	60.646	6.7735	0.0000	0.0000	667.76	6.3331	0.0000	0.0000
20:15	13.600	61.411	6.6666	0.0000	0.0000	665.14	6.3116	0.0000	0.0000
20:15	13.646	62.435	6.7735	0.0000	0.0000	720.36	6.2720	0.0000	0.0000

7 MIN
AVERAGE 13.530 76.152 6.7651 0.0000 0.0000 661.93 6.3120 0.0000 0.0000

STACK NO. 1

POINT NO. 2

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
20:17	13.557	62.636	6.9014	0.0000	0.0000	665.27	6.3460	0.0000	0.0000
20:17	13.652	62.250	6.7469	0.0000	0.0000	651.77	6.2667	0.0000	0.0000
20:18	13.677	61.623	6.7536	0.0000	0.0000	654.52	6.2454	0.0000	0.0000
20:18	13.631	61.667	6.6554	0.0000	0.0000	656.15	6.2653	0.0000	0.0000
20:19	13.757	61.676	6.6112	0.0000	0.0000	664.15	6.1763	0.0000	0.0000
20:19	13.965	61.513	6.4960	0.0000	0.0000	666.63	5.9957	0.0000	0.0000
20:20	13.853	61.001	6.5617	0.0000	0.0000	677.64	6.0010	0.0000	0.0000
20:20	13.643	60.336	7.1031	0.0000	0.0000	659.40	6.1020	0.0000	0.0000
20:21	14.328	58.319	6.5455	0.0000	0.0000	534.31	5.6622	0.0000	0.0000
20:21	14.076	51.099	6.6226	0.0000	0.0000	622.03	5.5001	0.0000	0.0000
20:22	13.753	62.569	6.6719	0.0000	0.0000	656.02	6.1750	0.0000	0.0000
20:22	13.736	75.062	6.6473	0.0000	0.0000	656.27	6.1416	0.0000	0.0000
20:23	13.761	60.336	6.7764	0.0000	0.0000	655.90	6.1557	0.0000	0.0000
20:23	13.635	62.691	6.7633	0.0000	0.0000	649.78	6.1035	0.0000	0.0000

7 MIN
AVERAGE 13.629 75.947 6.7146 0.0000 0.0000 646.15 6.1135 0.0000 0.0000

STACK NO. 1
POINT NO. 5

5104

W

TIME	SO2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
20:41	14.174	66.665	5.7553	0.0000	0.0000	568.50	5.8151	0.0000	0.0000
20:41	14.374	52.635	5.5131	0.0000	0.0000	551.31	5.6424	0.0000	0.0000
20:42	14.534	42.702	5.3125	0.0000	0.0000	466.09	5.5043	0.0000	0.0000
20:42	14.737	38.630	5.0125	0.0000	0.0000	420.10	5.3255	0.0000	0.0000
20:43	14.785	40.133	5.1207	0.0000	0.0000	406.46	5.2636	0.0000	0.0000
20:43	14.712	41.063	4.9562	0.0000	0.0000	406.61	5.3502	0.0000	0.0000
20:44	14.721	43.415	4.5141	0.0000	0.0000	336.11	5.3422	0.0000	0.0000
20:44	14.604	44.658	4.7764	0.0000	0.0000	365.74	5.2765	0.0000	0.0000
20:45	14.662	46.604	5.3662	0.0000	0.0000	416.10	5.2200	0.0000	0.0000
20:45	14.676	46.337	5.6077	0.0000	0.0000	431.65	5.3734	0.0000	0.0000
20:46	14.700	44.545	5.6034	0.0000	0.0000	456.65	5.5606	0.0000	0.0000
20:46	14.555	44.065	6.2570	0.0000	0.0000	453.46	5.4657	0.0000	0.0000
20:47	14.531	45.723	6.5226	0.0000	0.0000	461.63	5.5736	0.0000	0.0000
20:47	14.265	47.256	6.6258	0.0000	0.0000	452.45	5.7360	0.0000	0.0000
7 MIN	14.180	46.137	5.5131	0.0000	0.0000	451.13	5.4572	0.0000	0.0000
AVERAGE	14.556	46.645	5.5327	0.0000	0.0000	453.13	5.4572	0.0000	0.0000
13:13	14.033	66.665	5.7553	0.0000	0.0000	568.50	5.8151	0.0000	0.0000
13:13	14.374	52.635	5.5131	0.0000	0.0000	551.31	5.6424	0.0000	0.0000
13:13	14.534	42.702	5.3125	0.0000	0.0000	466.09	5.5043	0.0000	0.0000
13:13	14.737	38.630	5.0125	0.0000	0.0000	420.10	5.3255	0.0000	0.0000
13:13	14.785	40.133	5.1207	0.0000	0.0000	406.46	5.2636	0.0000	0.0000
13:13	14.712	41.063	4.9562	0.0000	0.0000	406.61	5.3502	0.0000	0.0000
13:13	14.721	43.415	4.5141	0.0000	0.0000	336.11	5.3422	0.0000	0.0000
13:13	14.604	44.658	4.7764	0.0000	0.0000	365.74	5.2765	0.0000	0.0000
13:13	14.662	46.604	5.3662	0.0000	0.0000	416.10	5.2200	0.0000	0.0000
13:13	14.676	46.337	5.6077	0.0000	0.0000	431.65	5.3734	0.0000	0.0000
13:13	14.700	44.545	5.6034	0.0000	0.0000	456.65	5.5606	0.0000	0.0000
13:13	14.555	44.065	6.2570	0.0000	0.0000	453.46	5.4657	0.0000	0.0000
13:13	14.531	45.723	6.5226	0.0000	0.0000	461.63	5.5736	0.0000	0.0000
13:13	14.265	47.256	6.6258	0.0000	0.0000	452.45	5.7360	0.0000	0.0000
STACK NO.	1	66.665	5.7553	0.0000	0.0000	568.50	5.8151	0.0000	0.0000
POINT NO.	5	52.635	5.5131	0.0000	0.0000	551.31	5.6424	0.0000	0.0000
13:13	14.180	46.137	5.5131	0.0000	0.0000	451.13	5.4572	0.0000	0.0000
13:13	14.556	46.645	5.5327	0.0000	0.0000	453.13	5.4572	0.0000	0.0000
TIME	SO2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
20:49	13.636	50.075	6.2664	0.0000	0.0000	493.56	6.1073	0.0000	0.0000
20:49	13.646	46.946	6.3210	0.0000	0.0000	498.20	6.0963	0.0000	0.0000
20:50	13.624	50.752	6.4341	0.0000	0.0000	505.32	6.1779	0.0000	0.0000
20:50	13.627	52.640	6.4292	0.0000	0.0000	532.07	6.2678	0.0000	0.0000
20:51	13.597	54.325	6.5226	0.0000	0.0000	536.56	6.3145	0.0000	0.0000
20:51	13.546	55.755	6.5364	0.0000	0.0000	552.61	6.3570	0.0000	0.0000
20:52	13.565	57.551	6.5515	0.0000	0.0000	552.66	6.3364	0.0000	0.0000
20:52	13.551	55.067	6.7469	0.0000	0.0000	561.16	6.5270	0.0000	0.0000
20:53	13.422	60.674	6.7036	0.0000	0.0000	556.63	6.4655	0.0000	0.0000
20:53	13.415	62.364	6.7735	0.0000	0.0000	560.56	6.4712	0.0000	0.0000
20:54	13.565	55.645	6.6521	0.0000	0.0000	573.16	6.5110	0.0000	0.0000
20:54	13.240	65.160	6.6670	0.0000	0.0000	577.42	6.6226	0.0000	0.0000
20:55	13.353	66.150	6.9063	0.0000	0.0000	572.55	6.5425	0.0000	0.0000
20:55	13.207	66.616	6.9250	0.0000	0.0000	581.50	6.5516	0.0000	0.0000
7 MIN	13.513	56.173	6.6460	0.0000	0.0000	546.60	6.3666	0.0000	0.0000
AVERAGE	13.513	56.173	6.6460	0.0000	0.0000	546.60	6.3666	0.0000	0.0000

STACK NO. 1
POINT NO. 1

5104

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	°F	LB/HR
21:27	12.875	83.768	7.6540	0.0000	0.0000	766.75	6.5367	0.0000	0.0000
21:27	12.783	85.655	7.6511	0.0000	0.0000	766.73	6.5131	0.0000	0.0000
21:28	12.828	86.552	7.6766	0.0000	0.0000	773.48	6.5512	0.0000	0.0000
21:28	13.016	87.662	7.5533	0.0000	0.0000	760.24	6.6185	0.0000	0.0000
21:29	12.875	86.631	7.6565	0.0000	0.0000	766.11	6.5367	0.0000	0.0000
21:29	12.872	89.655	7.7376	0.0000	0.0000	763.74	6.5414	0.0000	0.0000
21:30	12.850	90.525	7.6451	0.0000	0.0000	759.55	6.5254	0.0000	0.0000
21:30	12.835	90.781	7.6737	0.0000	0.0000	760.66	6.623	0.0000	0.0000
21:31	12.884	91.543	7.6635	0.0000	0.0000	764.53	6.6308	0.0000	0.0000
21:31	12.924	92.568	7.6046	0.0000	0.0000	761.36	6.6562	0.0000	0.0000
21:32	12.961	92.215	7.5602	0.0000	0.0000	753.24	6.6643	0.0000	0.0000
21:32	12.942	92.112	7.7160	0.0000	0.0000	753.53	6.6603	0.0000	0.0000
21:33	12.816	92.860	7.6540	0.0000	0.0000	773.23	6.5652	0.0000	0.0000
21:33	12.635	93.065	7.7061	0.0000	0.0000	766.43	6.5733	0.0000	0.0000

7 MIN

AVERAGE 12.863 / 85.652 / 7.6765 / 0.0000 0.0000 767.23 6.6266 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	°F	LB/HR
21:35	12.838	94.314	7.6442	0.0000	0.0000	769.36	6.6706	0.0000	0.0000
21:35	12.899	95.082	7.6668	0.0000	0.0000	761.11	6.6175	0.0000	0.0000
21:36	13.050	95.538	7.4517	0.0000	0.0000	756.49	6.7526	0.0000	0.0000
21:36	12.973	96.280	7.6147	0.0000	0.0000	766.74	6.6537	0.0000	0.0000
21:37	12.792	96.674	7.6065	0.0000	0.0000	771.73	7.0104	0.0000	0.0000
21:37	12.512	96.523	7.7278	0.0000	0.0000	771.46	6.5066	0.0000	0.0000
21:38	12.927	96.720	7.6442	0.0000	0.0000	763.66	6.6336	0.0000	0.0000
21:38	13.050	97.150	7.5310	0.0000	0.0000	771.73	6.7573	0.0000	0.0000
21:38	12.356	101.27	7.6634	0.0000	0.0000	769.73	6.6670	0.0000	0.0000
21:39	12.573	103.55	7.6057	0.0000	0.0000	750.61	6.6537	0.0000	0.0000
21:40	12.527	103.55	7.6365	0.0000	0.0000	751.96	6.6536	0.0000	0.0000
21:40	12.542	103.54	7.5506	0.0000	0.0000	751.23	6.6603	0.0000	0.0000
21:41	12.667	103.94	7.7061	0.0000	0.0000	765.46	6.6261	0.0000	0.0000
21:41	12.968	104.29	7.5507	0.0000	0.0000	750.98	6.6404	0.0000	0.0000

7 MIN

AVERAGE 12.840 / 99.252 / 7.6593 / 0.0000 0.0000 775.46 6.6626 0.0000 0.0000

13.70 75.166 6.269

Holly Sugar, Sydney, MT

Stack ID - Name: South Pulp Dryer - East Date(s): 10/22/93

Run No. ID: 6201 6202 6203 6204 Aug.

Time, Start: 2056 0974 1527 1924

End: 2116 1336 1746 2150

Results, O₂ (% dry) 14.172 14.100 13.916 13.568

CO₂ (% dry) 5.324 5.20 5.570 6.175

SO₂ (ppm, dry) 71.310 72.19 88.02 82.43

CO (ppm, dry) —

% H₂O (V/V) 41.42 34.5 32.47 42.64

V_m, std (dscf) 8.653 51.417 26.842 corr. 46.542

Flow kinetic (%) — 103.7 93.30 106.68

Zero Drift, Post-Test 10/21 10/22

O₂ cal zero .0986 .0485 .1077 .1240 .0483 .1566

drift, %

CO₂ cal zero .0096 .044 .0099 .0541 .0885 .1777

drift, %

SO₂ cal zero .670 .122 .204 .1024 .10752 .921

drift, %

Upscal Drift, Post-Test

O₂ cal span 10.539 0.46 7.11 7.1058 7.1704 7.1212

drift, %

CO₂ cal span 14.413 4.389 11.933 11.824 11.746 11.885

drift, %

SO₂ cal span 49.461 48.437 101.12 98.615 97.386 96.720

drift, %

Spans O₂ 25 25 25 25

CO₂ 40 40 40 40

SO₂ 110 110 110 110

PM-10

PM-10

M5

M5

4.4.117

STACK NO. 1
POINT NO. 1

601 Series 6000 Tests

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
20:37	14.129	61.647	5.3413	0.0000	0.0000	0.0000	5.6546	0.0000	0.0000
20:37	14.206	63.797	5.2576	0.0000	0.0000	0.0000	5.7654	0.0000	0.0000
20:38	14.052	65.999	5.3855	0.0000	0.0000	0.0000	5.6212	0.0000	0.0000
20:38	14.159	67.023	5.3266	0.0000	0.0000	0.0000	5.6260	0.0000	0.0000
20:39	14.129	67.791	5.2576	0.0000	0.0000	0.0000	5.6546	0.0000	0.0000
20:39	14.150	66.916	5.3767	0.0000	0.0000	0.0000	5.6560	0.0000	0.0000
20:40	14.036	65.756	5.4002	0.0000	0.0000	0.0000	5.5345	0.0000	0.0000
20:40	14.110	71.324	5.2971	0.0000	0.0000	0.0000	5.6706	0.0000	0.0000
20:41	14.144	72.062	5.4002	0.0000	0.0000	0.0000	5.6415	0.0000	0.0000
20:41	14.125	72.346	5.4637	0.0000	0.0000	0.0000	5.6573	0.0000	0.0000
5 MIN									
AVERAGE	14.124	66.073	5.3467	0.0000	0.0000	0.0000	5.6564	0.0000	0.0000

E
S

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
20:43	14.036	70.812	5.2775	0.0000	0.0000	0.0000	5.6612	0.0000	0.0000
20:43	14.172	70.403	5.4355	0.0000	0.0000	0.0000	5.6174	0.0000	0.0000
20:44	14.147	69.655	5.2971	0.0000	0.0000	0.0000	5.6367	0.0000	0.0000
20:44	14.175	69.532	5.3167	0.0000	0.0000	0.0000	5.6147	0.0000	0.0000
20:45	14.113	69.430	5.3855	0.0000	0.0000	0.0000	5.6679	0.0000	0.0000
20:45	14.116	69.327	5.3413	0.0000	0.0000	0.0000	5.6653	0.0000	0.0000
20:46	14.076	69.669	5.5276	0.0000	0.0000	0.0000	5.6333	0.0000	0.0000
20:46	14.104	69.713	5.4935	0.0000	0.0000	0.0000	5.6753	0.0000	0.0000
20:47	14.092	69.669	5.3167	0.0000	0.0000	0.0000	5.6666	0.0000	0.0000
20:47	14.119	69.610	5.5622	0.0000	0.0000	0.0000	5.6626	0.0000	0.0000
5 MIN									
AVERAGE	14.121	69.460	5.3656	0.0000	0.0000	0.0000	5.6610	0.0000	0.0000

E

STACK NO. 1
POINT NO. 5

6101

E

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
21:01	14.027	66.916	5.3757	0.0000	0.0000	0.0000	5.6425	0.0000	0.0000
21:01	14.230	66.583	5.0806	0.0000	0.0000	0.0000	5.7668	0.0000	0.0000
21:02	14.239	65.590	5.1105	0.0000	0.0000	0.0000	5.7566	0.0000	0.0000
21:02	14.019	62.722	5.4145	0.0000	0.0000	0.0000	5.6504	0.0000	0.0000
21:03	13.981	66.356	5.3216	0.0000	0.0000	0.0000	5.6624	0.0000	0.0000
21:03	13.975	66.201	5.2775	0.0000	0.0000	0.0000	5.6677	0.0000	0.0000
21:04	14.147	65.071	5.2135	0.0000	0.0000	0.0000	5.6387	0.0000	0.0000
21:04	14.056	65.122	5.3707	0.0000	0.0000	0.0000	5.6155	0.0000	0.0000
21:05	14.166	65.516	5.1155	0.0000	0.0000	0.0000	5.6227	0.0000	0.0000
21:05	14.153	66.662	5.2971	0.0000	0.0000	0.0000	5.6353	0.0000	0.0000

5 MIN
AVERAGE 14.055 67.504 5.2586 0.0000 0.0000 0.0000 5.6753 0.0000 0.0000

STACK NO. 1
POINT NO. 5

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
21:07	14.085	67.535	5.3413	0.0000	0.0000	0.0000	5.6892	0.0000	0.0000
21:07	14.230	67.126	5.1842	0.0000	0.0000	0.0000	5.7655	0.0000	0.0000
21:08	14.261	67.464	5.1351	0.0000	0.0000	0.0000	5.7482	0.0000	0.0000
21:08	14.249	67.545	5.0858	0.0000	0.0000	0.0000	5.7506	0.0000	0.0000
21:09	14.065	66.406	5.3605	0.0000	0.0000	0.0000	5.6635	0.0000	0.0000
21:09	14.153	66.225	5.1540	0.0000	0.0000	0.0000	5.7587	0.0000	0.0000
21:10	14.162	66.552	5.3462	0.0000	0.0000	0.0000	5.6254	0.0000	0.0000
21:10	14.132	66.363	5.2166	0.0000	0.0000	0.0000	5.6520	0.0000	0.0000
21:11	14.064	66.400	5.3653	0.0000	0.0000	0.0000	5.6105	0.0000	0.0000
21:11	14.016	65.692	5.4637	0.0000	0.0000	0.0000	5.6504	0.0000	0.0000

5 MIN
AVERAGE 14.149 66.134 5.2755 0.0000 0.0000 0.0000 5.6368 0.0000 0.0000

(14.12) 66.46 5.31a

STACK NO. 1
POINT NO. 1

6101

E

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
21:33	14.216	67.791	5.2460	0.0000	0.0000	0.0000	5.7774	0.0000	0.0000
21:33	14.193	71.222	5.2333	0.0000	0.0000	0.0000	5.7367	0.0000	0.0000
21:40	14.256	72.663	5.3904	0.0000	0.0000	0.0000	5.7429	0.0000	0.0000
21:40	14.264	73.664	5.4002	0.0000	0.0000	0.0000	5.7373	0.0000	0.0000
21:41	14.156	73.833	5.2575	0.0000	0.0000	0.0000	5.6466	0.0000	0.0000
21:41	14.233	74.038	5.4145	0.0000	0.0000	0.0000	5.7641	0.0000	0.0000
21:42	14.261	74.140	5.4453	0.0000	0.0000	0.0000	5.7402	0.0000	0.0000
21:42	14.315	74.140	5.4247	0.0000	0.0000	0.0000	5.6656	0.0000	0.0000
21:43	14.227	74.191	5.2624	0.0000	0.0000	0.0000	5.7635	0.0000	0.0000
21:43	14.186	74.140	5.2362	0.0000	0.0000	0.0000	5.7557	0.0000	0.0000

5 MIN
AVERAGE 14.231 73.034 5.3535 0.0000 0.0000 0.0000 5.7663 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
21:45	14.230	75.547	5.2235	0.0000	0.0000	0.0000	5.7666	0.0000	0.0000
21:45	14.304	76.496	5.4100	0.0000	0.0000	0.0000	5.7029	0.0000	0.0000
21:46	14.310	76.393	5.4136	0.0000	0.0000	0.0000	5.6376	0.0000	0.0000
21:46	14.265	76.035	5.3504	0.0000	0.0000	0.0000	5.7165	0.0000	0.0000
21:47	14.236	75.523	5.2235	0.0000	0.0000	0.0000	5.7515	0.0000	0.0000
21:47	14.267	75.216	5.1536	0.0000	0.0000	0.0000	5.7343	0.0000	0.0000
21:48	14.273	75.523	5.3315	0.0000	0.0000	0.0000	5.7295	0.0000	0.0000
21:48	14.266	75.523	5.1846	0.0000	0.0000	0.0000	5.7163	0.0000	0.0000
21:48	14.424	75.420	5.4542	0.0000	0.0000	0.0000	5.5931	0.0000	0.0000
21:49	14.336	73.577	5.5616	0.0000	0.0000	0.0000	5.6736	0.0000	0.0000

5 MIN
AVERAGE 14.295 75.625 5.3353 0.0000 0.0000 0.0000 5.7104 0.0000 0.0000

STACK NO. 1
POINT NO. 3

6102

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	°F	LB/HR
09:51	13.603	51.703	5.6450	0.0000	0.0000	535.52	6.1365	0.0000	0.0000
09:51	13.723	53.165	5.7235	0.0000	0.0000	613.16	6.2002	0.0000	0.0000
09:52	13.661	53.504	5.5233	0.0000	0.0000	616.91	6.2567	0.0000	0.0000
09:52	13.704	54.560	5.5643	0.0000	0.0000	623.51	6.2215	0.0000	0.0000
09:53	13.606	55.236	5.7530	0.0000	0.0000	616.16	6.3066	0.0000	0.0000
09:53	14.042	54.361	5.1573	0.0000	0.0000	541.19	5.9253	0.0000	0.0000
09:54	13.001	73.748	4.5150	0.0000	0.0000	491.53	5.1005	0.0000	0.0000
09:54	13.544	72.504	5.5516	0.0000	0.0000	635.26	6.0743	0.0000	0.0000
09:55	13.704	63.276	5.7573	0.0000	0.0000	622.01	6.2215	0.0000	0.0000
09:55	13.581	63.373	5.6351	0.0000	0.0000	675.77	6.3276	0.0000	0.0000

5 MIN

AVERAGE	13.678	62.556	5.5563	0.0000	0.0000	613.21	6.0717	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

STACK NO. 1
POINT NO. 4

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	°F	LB/HR
09:57	13.750	74.545	5.5123	0.0000	0.0000	642.03	6.1737	0.0000	0.0000
09:57	13.723	75.420	5.5713	0.0000	0.0000	626.26	6.2056	0.0000	0.0000
09:58	13.664	76.356	5.6464	0.0000	0.0000	617.54	6.2560	0.0000	0.0000
09:58	13.763	76.595	5.6513	0.0000	0.0000	602.29	6.1657	0.0000	0.0000
09:59	13.695	79.586	5.6204	0.0000	0.0000	591.54	6.0566	0.0000	0.0000
09:59	13.654	80.797	5.6744	0.0000	0.0000	554.67	6.0634	0.0000	0.0000
10:00	13.786	81.323	5.6513	0.0000	0.0000	590.60	6.1664	0.0000	0.0000
10:00	13.570	81.513	5.6204	0.0000	0.0000	593.17	6.0435	0.0000	0.0000
10:01	13.600	81.523	5.6733	0.0000	0.0000	593.17	6.1351	0.0000	0.0000
10:01	13.635	82.077	5.6537	0.0000	0.0000	567.62	6.1055	0.0000	0.0000

5 MIN

AVERAGE	13.756	75.512	5.6667	0.0000	0.0000	604.34	6.1402	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

STACK NO. 1
POINT NO. 7

602

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
10:15	13.862	66.001	5.4775	0.0000	0.0000	566.55	5.5564	0.0000	0.0000
10:16	13.892	66.275	5.6057	0.0000	0.0000	561.92	5.0555	0.0000	0.0000
10:16	13.895	66.678	5.2617	0.0000	0.0000	560.43	6.0566	0.0000	0.0000
10:16	14.006	61.672	5.2572	0.0000	0.0000	549.61	5.3565	0.0000	0.0000
10:17	13.956	65.148	5.2372	0.0000	0.0000	544.56	5.0037	0.0000	0.0000
10:17	14.040	67.197	5.0600	0.0000	0.0000	540.61	5.6240	0.0000	0.0000
10:18	14.131	67.146	5.3944	0.0000	0.0000	537.06	5.6523	0.0000	0.0000
10:18	14.119	67.402	5.4140	0.0000	0.0000	532.61	5.6623	0.0000	0.0000
10:19	14.076	66.941	5.1733	0.0000	0.0000	521.54	5.9001	0.0000	0.0000
10:19	14.166	65.365	5.3453	0.0000	0.0000	517.45	5.7555	0.0000	0.0000

E

5 MIN
AVERAGE 14.028 67.663 5.3507 0.0000 0.0000 545.24 5.3412 0.0000 0.0000

STACK NO. 1
POINT NO. 8

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
10:21	14.211	62.998	4.9870	0.0000	0.0000	492.20	5.7632	0.0000	0.0000
10:21	14.326	62.998	5.3695	0.0000	0.0000	491.45	5.6822	0.0000	0.0000
10:22	14.325	64.227	5.1684	0.0000	0.0000	489.35	5.6849	0.0000	0.0000
10:22	14.326	63.715	5.1635	0.0000	0.0000	471.05	5.6822	0.0000	0.0000
10:23	14.360	64.074	5.1467	0.0000	0.0000	466.05	5.6371	0.0000	0.0000
10:23	14.462	64.735	5.0652	0.0000	0.0000	462.03	5.5494	0.0000	0.0000
10:24	14.465	63.920	5.0701	0.0000	0.0000	453.95	5.5466	0.0000	0.0000
10:24	14.500	64.565	5.0701	0.0000	0.0000	455.22	5.5335	0.0000	0.0000
10:25	14.426	64.565	5.2026	0.0000	0.0000	455.34	5.5372	0.0000	0.0000
10:25	14.417	64.176	5.3404	0.0000	0.0000	446.05	5.6052	0.0000	0.0000

5 MIN
AVERAGE 14.366 64.002 5.1566 0.0000 0.0000 463.05 5.6302 0.0000 0.0000

STACK NO. 1
POINT NO. 11

6102

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
10:35	14.515	51.705	51.2513	0.0000	0.0000	441.22	5.6502	0.0000	0.0000
10:36	14.245	51.544	4.9564	0.0000	0.0000	455.57	5.7513	0.0000	0.0000
10:40	14.368	50.371	5.0014	0.0000	0.0000	445.10	5.6477	0.0000	0.0000
10:40	14.265	55.405	4.7505	0.0000	0.0000	445.34	5.7354	0.0000	0.0000
10:41	14.505	55.552	4.5526	0.0000	0.0000	445.34	5.5262	0.0000	0.0000
10:41	14.350	52.540	4.7455	0.0000	0.0000	455.71	5.6571	0.0000	0.0000
10:42	14.251	51.515	4.7551	0.0000	0.0000	475.77	5.7141	0.0000	0.0000
10:42	14.275	54.534	4.7501	0.0000	0.0000	461.55	5.7247	0.0000	0.0000
10:43	14.355	55.552	4.5424	0.0000	0.0000	457.45	5.6516	0.0000	0.0000
10:43	14.515	55.755	4.5575	0.0000	0.0000	455.55	5.6555	0.0000	0.0000

5 MIN
AVERAGE 14.355 55.525 4.5555 0.0000 0.0000 461.54 5.6755 0.0000 0.0000

STACK NO. 1
POINT NO. 12

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
10:45	14.242	55.075	4.7704	0.0000	0.0000	459.05	5.7555	0.0000	0.0000
10:45	14.392	55.514	5.2077	0.0000	0.0000	457.33	5.6255	0.0000	0.0000
10:46	14.435	55.555	5.2755	0.0000	0.0000	455.20	5.5555	0.0000	0.0000
10:46	14.255	55.405	5.0555	0.0000	0.0000	450.33	5.7354	0.0000	0.0000
10:47	14.545	55.175	5.1144	0.0000	0.0000	455.75	5.6553	0.0000	0.0000
10:47	14.411	55.551	5.1550	0.0000	0.0000	457.21	5.6155	0.0000	0.0000
10:48	14.540	55.541	5.0557	0.0000	0.0000	455.35	5.6715	0.0000	0.0000
10:48	14.411	57.755	5.1555	0.0000	0.0000	455.55	5.6155	0.0000	0.0000
10:49	14.355	57.402	5.1550	0.0000	0.0000	454.71	5.6235	0.0000	0.0000
10:49	14.245	57.555	5.1575	0.0000	0.0000	455.55	5.7545	0.0000	0.0000

5 MIN
AVERAGE 14.545 55.521 5.1242 0.0000 0.0000 455.45 5.6542 0.0000 0.0000

STACK NO. 1
POINT NO. 5 6102

II

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
11:52	14.248	67.504	5.1930	0.0000	0.0000	475.46	5.7513	0.0000	0.0000
11:52	14.265	66.067	5.1635	0.0000	0.0000	470.21	5.7194	0.0000	0.0000
11:53	14.356	67.662	4.9964	0.0000	0.0000	479.33	5.6236	0.0000	0.0000
11:53	14.351	66.523	5.0306	0.0000	0.0000	477.08	5.6796	0.0000	0.0000
11:54	14.411	66.221	5.0845	0.0000	0.0000	470.55	5.6105	0.0000	0.0000
11:54	14.382	67.656	5.0600	0.0000	0.0000	451.47	5.6265	0.0000	0.0000
11:55	14.328	67.197	5.0505	0.0000	0.0000	435.65	5.6622	0.0000	0.0000
11:55	14.362	66.836	5.0707	0.0000	0.0000	424.10	5.6530	0.0000	0.0000
11:56	14.377	66.850	5.0112	0.0000	0.0000	418.96	5.6387	0.0000	0.0000
11:56	14.263	67.054	5.1733	0.0000	0.0000	419.96	5.7360	0.0000	0.0000

5 MIN

AVERAGE	14.358	67.566	5.0654	0.0000	0.0000	452.10	5.6724	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

STACK NO. 1
POINT NO. 4

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
11:58	14.325	66.836	5.1664	0.0000	0.0000	421.23	5.6646	0.0000	0.0000
11:58	14.343	66.562	5.0751	0.0000	0.0000	421.23	5.6630	0.0000	0.0000
11:59	14.405	66.562	4.9666	0.0000	0.0000	424.46	5.6156	0.0000	0.0000
11:59	14.322	66.836	4.9621	0.0000	0.0000	432.35	5.6675	0.0000	0.0000
12:00	14.214	67.350	5.1635	0.0000	0.0000	430.97	5.7605	0.0000	0.0000
12:00	14.353	67.705	5.0014	0.0000	0.0000	434.10	5.6610	0.0000	0.0000
12:01	14.308	66.477	4.9915	0.0000	0.0000	435.60	5.6962	0.0000	0.0000
12:01	14.276	66.323	5.2026	0.0000	0.0000	430.72	5.7274	0.0000	0.0000
12:02	14.305	66.631	5.0306	0.0000	0.0000	436.57	5.6562	0.0000	0.0000
12:02	14.349	66.579	4.9915	0.0000	0.0000	432.65	5.6637	0.0000	0.0000

5 MIN

AVERAGE	14.321	67.551	5.0574	0.0000	0.0000	429.65	5.6666	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

STACK NO. 1
POINT NO. 3

5102

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
13:35	13.738	50.535	5.1373	0.0000	0.0000	563.05	6.1823	0.0000	0.0000
13:35	13.731	50.474	4.9719	0.0000	0.0000	563.53	6.1657	0.0000	0.0000
13:36	13.769	50.423	5.0554	0.0000	0.0000	566.55	6.1657	0.0000	0.0000
13:36	13.753	50.676	4.9517	0.0000	0.0000	564.68	6.1760	0.0000	0.0000
13:37	13.663	50.935	5.2519	0.0000	0.0000	567.30	6.2346	0.0000	0.0000
13:37	13.674	50.663	5.2765	0.0000	0.0000	570.18	6.2461	0.0000	0.0000
13:38	13.656	50.320	5.2427	0.0000	0.0000	570.30	6.2613	0.0000	0.0000
13:38	13.655	50.676	5.0866	0.0000	0.0000	560.67	6.2640	0.0000	0.0000
13:39	13.683	51.037	5.0554	0.0000	0.0000	567.05	6.2407	0.0000	0.0000
13:39	13.677	51.754	5.2175	0.0000	0.0000	577.17	6.2454	0.0000	0.0000

5 MIN
AVERAGE 13.706 50.612 5.1350 0.0000 0.0000 570.63 6.2168 0.0000 0.0000

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
13:41	13.563	51.560	5.0438	0.0000	0.0000	570.05	6.3437	0.0000	0.0000
13:41	13.652	51.447	5.1330	0.0000	0.0000	565.05	6.2321	0.0000	0.0000
13:42	13.655	51.754	5.0603	0.0000	0.0000	566.43	6.2540	0.0000	0.0000
13:42	13.609	52.419	5.1094	0.0000	0.0000	563.60	6.3036	0.0000	0.0000
13:43	13.723	52.266	4.9670	0.0000	0.0000	565.18	6.2056	0.0000	0.0000
13:43	13.646	52.829	5.0259	0.0000	0.0000	567.36	6.2720	0.0000	0.0000
13:44	13.747	52.829	5.1045	0.0000	0.0000	562.43	6.1643	0.0000	0.0000
13:44	13.687	52.573	5.1831	0.0000	0.0000	565.05	6.2567	0.0000	0.0000
13:45	13.612	52.112	5.0366	0.0000	0.0000	564.53	6.3072	0.0000	0.0000
13:45	13.660	52.163	5.2126	0.0000	0.0000	566.31	6.2427	0.0000	0.0000

5 MIN
AVERAGE 13.659 52.199 5.1001 0.0000 0.0000 566.45 6.2606 0.0000 0.0000

14070 86.824
5.239

STACK NO. 1
POINT NO. 5

602

E

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AME "F	STEAM LB/HR
13:47	13.603	31.656	5.1133	0.0000	0.0000	560.06	6.3052	0.0000	0.0000
13:47	13.643	31.703	5.0112	0.0000	0.0000	562.30	6.2746	0.0000	0.0000
13:48	13.631	31.656	5.0161	0.0000	0.0000	571.30	6.2653	0.0000	0.0000
13:48	13.600	32.675	4.9564	0.0000	0.0000	571.60	6.3118	0.0000	0.0000
13:49	13.594	32.727	5.1242	0.0000	0.0000	571.05	6.3171	0.0000	0.0000
13:49	13.547	33.233	5.0063	0.0000	0.0000	569.60	6.3623	0.0000	0.0000
13:50	13.643	33.751	5.1467	0.0000	0.0000	564.93	6.2746	0.0000	0.0000
13:50	13.735	34.705	5.0366	0.0000	0.0000	556.81	6.1543	0.0000	0.0000
13:51	13.569	34.466	4.9125	0.0000	0.0000	555.67	6.3364	0.0000	0.0000
13:51	13.652	34.672	5.0600	0.0000	0.0000	562.16	6.2667	0.0000	0.0000

5 MIN AVERAGE	13.621	33.106	5.0515	0.0000	0.0000	564.60	6.2935	0.0000	0.0000
------------------	--------	--------	--------	--------	--------	--------	--------	--------	--------

13:51	13.603	34.703	5.1133	0.0000	0.0000	560.06	6.3052	0.0000	0.0000
13:51	13.643	34.703	5.0112	0.0000	0.0000	562.30	6.2746	0.0000	0.0000
13:51	13.631	34.703	5.0161	0.0000	0.0000	571.30	6.2653	0.0000	0.0000
13:51	13.600	34.703	4.9564	0.0000	0.0000	571.60	6.3118	0.0000	0.0000
13:51	13.594	34.703	5.1242	0.0000	0.0000	571.05	6.3171	0.0000	0.0000
13:51	13.547	34.703	5.0063	0.0000	0.0000	569.60	6.3623	0.0000	0.0000
13:51	13.643	34.703	5.1467	0.0000	0.0000	564.93	6.2746	0.0000	0.0000
13:51	13.735	34.703	5.0366	0.0000	0.0000	556.81	6.1543	0.0000	0.0000
13:51	13.569	34.703	4.9125	0.0000	0.0000	555.67	6.3364	0.0000	0.0000
13:51	13.652	34.703	5.0600	0.0000	0.0000	562.16	6.2667	0.0000	0.0000

STACK NO. 1
POINT NO. 5

51027
End run
602

E: 14.100 72.19 5.20

M: 14.076 86.829 5.239

M

STACK NO. 1
POINT NO. 3

Act 6103 E

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
15:43	15.315	45.061	5.6572	0.0000	0.0000	627.16	6.1255	0.0000	0.0000
15:43	15.237	47.322	5.6033	0.0000	0.0000	660.64	6.6253	0.0000	0.0000
15:44	15.157	54.120	6.1635	0.0000	0.0000	706.38	6.6536	0.0000	0.0000
15:44	12.967	53.765	6.1144	0.0000	0.0000	747.12	6.6550	0.0000	0.0000
15:45	12.985	62.623	6.2665	0.0000	0.0000	754.12	6.6551	0.0000	0.0000
15:45	12.864	66.460	6.1133	0.0000	0.0000	751.74	6.6506	0.0000	0.0000
15:46	12.875	70.505	6.2127	0.0000	0.0000	770.36	6.6567	0.0000	0.0000
15:46	12.864	74.345	6.6554	0.0000	0.0000	765.46	6.6506	0.0000	0.0000
15:47	12.809	77.212	6.5364	0.0000	0.0000	763.23	6.6035	0.0000	0.0000
15:47	12.647	75.566	6.5276	0.0000	0.0000	765.36	6.5526	0.0000	0.0000

5 MIN
AVERAGE 15.051 63.511 6.2216 0.0000 0.0000 740.62 6.7777 0.0000 0.0000

STACK NO. 1
POINT NO. 4

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOX150 PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
15:48	12.808	67.722	6.5374	0.0000	0.0000	635.46	7.1006	0.0000	0.0000
15:49	12.867	66.736	6.5374	0.0000	0.0000	617.05	6.6122	0.0000	0.0000
15:50	12.890	67.806	6.6060	0.0000	0.0000	634.71	6.6254	0.0000	0.0000
15:50	12.826	66.323	6.7046	0.0000	0.0000	646.27	6.9766	0.0000	0.0000
15:51	12.850	65.706	6.6346	0.0000	0.0000	646.53	6.5600	0.0000	0.0000
15:51	12.804	65.552	6.4144	0.0000	0.0000	643.55	6.6556	0.0000	0.0000
15:52	12.743	60.064	6.4665	0.0000	0.0000	662.70	7.0530	0.0000	0.0000
15:52	12.752	65.911	6.7440	0.0000	0.0000	661.45	7.0450	0.0000	0.0000
15:53	12.724	61.344	6.6546	0.0000	0.0000	663.57	7.0669	0.0000	0.0000
15:53	12.663	61.005	6.6600	0.0000	0.0000	661.45	6.9494	0.0000	0.0000

5 MIN
AVERAGE 12.605 66.301 6.6062 0.0000 0.0000 653.66 6.5663 0.0000 0.0000

STACK NO. 1
POINT NO. 7

6603

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	°F	LB/HR
16:07	12.876	120.53	6.5817	0.0000	0.0000	557.30	6.5361	0.0000	0.0000
16:07	12.807	122.21	6.5079	0.0000	0.0000	562.67	6.3572	0.0000	0.0000
16:08	12.810	124.01	6.7483	0.0000	0.0000	557.05	6.3845	0.0000	0.0000
16:08	12.853	125.33	6.6303	0.0000	0.0000	577.15	6.9464	0.0000	0.0000
16:09	12.758	127.29	6.8407	0.0000	0.0000	562.65	7.0337	0.0000	0.0000
16:09	12.924	99.076	6.5817	0.0000	0.0000	612.06	6.8962	0.0000	0.0000
16:10	12.965	75.675	6.3649	0.0000	0.0000	626.58	6.6451	0.0000	0.0000
16:10	12.992	76.700	6.4243	0.0000	0.0000	592.28	6.6378	0.0000	0.0000
16:11	13.056	67.506	6.3253	0.0000	0.0000	1004.13	6.7714	0.0000	0.0000
16:11	13.333	96.772	5.9717	0.0000	0.0000	575.25	6.5423	0.0000	0.0000
5 MIN									
AVERAGE	12.542	105.53	6.5035	0.0000	0.0000	565.75	6.6605	0.0000	0.0000

STACK NO. 1
POINT NO. 6

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	°F	LB/HR
16:13	13.621	104.70	5.5028	0.0000	0.0000	527.13	6.2932	0.0000	0.0000
16:13	13.564	105.58	5.6045	0.0000	0.0000	522.31	6.3251	0.0000	0.0000
16:14	13.627	108.49	5.5230	0.0000	0.0000	638.57	6.1152	0.0000	0.0000
16:14	13.879	106.24	5.5028	0.0000	0.0000	655.08	6.0701	0.0000	0.0000
16:15	14.031	106.14	5.5614	0.0000	0.0000	651.33	5.8663	0.0000	0.0000
16:15	14.211	106.24	5.2630	0.0000	0.0000	631.56	5.7632	0.0000	0.0000
16:16	14.282	105.47	5.2534	0.0000	0.0000	606.60	5.7221	0.0000	0.0000
16:16	14.254	104.25	5.2523	0.0000	0.0000	612.50	5.7450	0.0000	0.0000
16:17	14.276	104.13	5.3224	0.0000	0.0000	602.05	5.7274	0.0000	0.0000
16:17	14.435	102.36	5.0455	0.0000	0.0000	745.67	5.5653	0.0000	0.0000
5 MIN									
AVERAGE	14.046	105.67	5.4425	0.0000	0.0000	644.55	5.3256	0.0000	0.0000

STACK NO. 1
POINT NO. 5

5103

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
16:19	14.460	99.639	5.0613	0.0000	0.0000	555.26	5.5660	0.0000	0.0000
16:19	14.743	96.306	4.5535	0.0000	0.0000	553.66	5.3236	0.0000	0.0000
16:20	14.650	96.004	4.6632	0.0000	0.0000	555.67	5.2507	0.0000	0.0000
16:20	14.916	92.776	4.6632	0.0000	0.0000	556.05	5.1722	0.0000	0.0000
16:21	14.535	91.191	4.7570	0.0000	0.0000	556.43	5.1336	0.0000	0.0000
16:21	15.127	86.154	4.6366	0.0000	0.0000	522.07	4.5916	0.0000	0.0000
16:22	15.165	87.043	4.6632	0.0000	0.0000	504.52	4.5411	0.0000	0.0000
16:22	15.145	96.326	4.6661	0.0000	0.0000	501.53	4.6756	0.0000	0.0000
16:23	15.164	85.712	4.5206	0.0000	0.0000	501.45	4.5567	0.0000	0.0000
16:23	15.185	84.637	4.6632	0.0000	0.0000	494.70	4.5411	0.0000	0.0000
5 MIN									
AVERAGE	14.572	91.063	4.7252	0.0000	0.0000	555.22	5.1257	0.0000	0.0000

STACK NO. 1
POINT NO. 10

5103

W

TIME 24 HR.	O2 %,D	SO2 #1 PPM,D	SO2 #2 PPM,D	NOX PPM,D	NOXISO PPM,D	CO PPM,D	CO2 %,D	T-AMB °F	STEAM LB/HR
16:25	15.495	80.233	4.4271	0.0000	0.0000	410.96	4.6726	0.0000	0.0000
16:25	15.627	77.053	4.2546	0.0000	0.0000	362.25	4.5566	0.0000	0.0000
16:26	13.753	83.450	6.1439	0.0000	0.0000	635.46	6.1730	0.0000	0.0000
16:26	13.944	76.670	5.4749	0.0000	0.0000	633.53	6.0143	0.0000	0.0000
16:27	15.763	74.566	4.0936	0.0000	0.0000	555.01	4.4417	0.0000	0.0000
16:27	16.045	75.369	4.0926	0.0000	0.0000	260.40	4.1673	0.0000	0.0000
16:28	16.131	76.086	3.9500	0.0000	0.0000	263.66	4.1229	0.0000	0.0000
16:28	16.164	74.458	4.0060	0.0000	0.0000	243.73	4.1466	0.0000	0.0000
16:29	16.262	72.346	3.5006	0.0000	0.0000	236.23	3.9326	0.0000	0.0000
16:29	16.263	71.017	3.7630	0.0000	0.0000	230.67	4.0067	0.0000	0.0000
5 MIN									
AVERAGE	15.541	77.013	4.4360	0.0000	0.0000	363.60	4.6336	0.0000	0.0000

STACK NO. 1
POINT NO. 1

6103

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	"F	LB/HR
17:16	13.915	103.63	5.6323	0.0000	0.0000	719.13	6.1259	0.0000	0.0000
17:18	13.698	104.04	5.5978	0.0000	0.0000	723.75	6.2266	0.0000	0.0000
17:19	13.713	104.24	5.6175	0.0000	0.0000	712.00	6.2135	0.0000	0.0000
17:19	13.720	104.61	5.5280	0.0000	0.0000	721.66	6.2082	0.0000	0.0000
17:20	13.778	105.27	5.6362	0.0000	0.0000	733.50	6.1577	0.0000	0.0000
17:20	13.760	105.57	5.6175	0.0000	0.0000	726.37	6.1737	0.0000	0.0000
17:21	13.707	106.09	5.5536	0.0000	0.0000	722.25	6.2166	0.0000	0.0000
17:21	13.744	105.60	5.7155	0.0000	0.0000	735.50	6.1670	0.0000	0.0000
17:22	13.677	106.60	5.6716	0.0000	0.0000	726.37	6.2454	0.0000	0.0000
17:22	13.616	106.65	5.7206	0.0000	0.0000	716.63	6.1232	0.0000	0.0000

5 MIN
AVERAGE 13.743 / 105.37 / 5.6352 / 0.0000 / 0.0000 / 724.14 / 6.1650 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	"F	LB/HR
17:24	14.614	73.065	5.7155	0.0000	0.0000	669.43	5.4352	0.0000	0.0000
17:24	13.984	55.389	5.7155	0.0000	0.0000	734.62	6.0468	0.0000	0.0000
17:25	13.606	101.27	5.5142	0.0000	0.0000	726.12	6.1336	0.0000	0.0000
17:25	13.624	103.17	5.5565	0.0000	0.0000	723.50	6.1175	0.0000	0.0000
17:26	14.016	103.37	5.5366	0.0000	0.0000	666.36	5.5503	0.0000	0.0000
17:26	14.158	102.09	5.2240	0.0000	0.0000	660.15	5.6263	0.0000	0.0000
17:27	14.045	100.57	5.2663	0.0000	0.0000	641.30	5.6550	0.0000	0.0000
17:27	14.273	100.76	5.3421	0.0000	0.0000	652.27	5.7301	0.0000	0.0000
17:28	14.214	99.639	5.2643	0.0000	0.0000	640.26	5.7605	0.0000	0.0000
17:28	14.160	95.727	5.2535	0.0000	0.0000	634.16	5.6616	0.0000	0.0000

5 MIN
AVERAGE 14.134 / 97.558 / 5.3735 / 0.0000 / 0.0000 / 666.26 / 5.6466 / 0.0000 / 0.0000

4.4.130

STACK NO. 1
POINT NO. 5

6003

E

TIME	SO2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AME	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
17:42	14.836	76.517	4.4651	0.0000	0.0000	354.86	5.1563	0.0000	0.0000
17:42	15.065	76.953	4.7026	0.0000	0.0000	402.98	5.0447	0.0000	0.0000
17:43	14.893	76.877	4.7714	0.0000	0.0000	454.09	5.1935	0.0000	0.0000
17:43	15.867	76.547	5.4106	0.0000	0.0000	705.76	5.5771	0.0000	0.0000
17:44	14.325	82.625	4.5526	0.0000	0.0000	344.06	5.5345	0.0000	0.0000
17:44	14.813	67.643	4.8150	0.0000	0.0000	425.73	5.2525	0.0000	0.0000
17:45	14.847	72.611	4.8150	0.0000	0.0000	405.23	5.2333	0.0000	0.0000
17:45	14.579	75.574	4.7124	0.0000	0.0000	402.73	5.1244	0.0000	0.0000
17:46	14.942	75.583	4.5403	0.0000	0.0000	357.11	5.1510	0.0000	0.0000
17:46	15.016	75.623	4.5206	0.0000	0.0000	353.74	5.0872	0.0000	0.0000

5 MIN
AVERAGE 14.783 74.627 4.7375 0.0000 0.0000 452.73 5.2515 0.0000 0.0000

STACK NO. 1
POINT NO. 5

TIME	SO2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AME	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
17:48	15.071	75.700	4.6436	0.0000	0.0000	354.24	5.0554	0.0000	0.0000
17:48	14.516	77.161	4.6731	0.0000	0.0000	400.73	5.1722	0.0000	0.0000
17:49	14.945	77.560	4.7662	0.0000	0.0000	412.65	5.1463	0.0000	0.0000
17:49	14.767	76.533	4.7075	0.0000	0.0000	428.57	5.3024	0.0000	0.0000
17:50	14.804	79.168	4.8285	0.0000	0.0000	434.72	5.2705	0.0000	0.0000
17:50	14.746	79.414	4.8551	0.0000	0.0000	434.47	5.3210	0.0000	0.0000
17:51	14.620	80.745	5.0026	0.0000	0.0000	455.57	5.4253	0.0000	0.0000
17:51	14.555	81.621	5.0666	0.0000	0.0000	466.64	5.4857	0.0000	0.0000
17:52	14.566	82.281	5.0466	0.0000	0.0000	463.71	5.4750	0.0000	0.0000
17:52	14.611	82.557	5.0713	0.0000	0.0000	471.21	5.4575	0.0000	0.0000

5 MIN
AVERAGE 14.760 79.539 4.8782 0.0000 0.0000 438.67 5.3062 0.0000 0.0000

6003
Avg East 13.916 88.02 5.570

STACK NO. 1
POINT NO. 1

5104

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	"F	LB/HR
19:11	14.168	58.711	5.2630	0.0000	0.0000	588.15	5.8204	0.0000	0.0000
19:11	12.653	53.987	6.3357	0.0000	0.0000	504.19	6.9573	0.0000	0.0000
19:12	12.608	70.454	6.6356	0.0000	0.0000	546.05	7.1638	0.0000	0.0000
19:12	12.632	73.107	6.5864	0.0000	0.0000	535.55	7.1486	0.0000	0.0000
19:13	12.629	62.077	6.3847	0.0000	0.0000	520.68	7.1512	0.0000	0.0000
19:13	12.664	63.561	6.5666	0.0000	0.0000	522.43	7.1054	0.0000	0.0000
19:14	12.660	61.974	6.4390	0.0000	0.0000	515.56	7.1247	0.0000	0.0000
19:14	12.630	73.525	6.5521	0.0000	0.0000	555.64	7.0561	0.0000	0.0000
19:15	12.750	73.721	6.4734	0.0000	0.0000	568.07	7.0211	0.0000	0.0000
19:15	12.577	60.587	6.5767	0.0000	0.0000	552.07	7.1954	0.0000	0.0000

5 MIN
AVERAGE 12.628 72.765 6.3874 0.0000 0.0000 566.47 6.9751 0.0000 0.0000

STACK NO. 1
POINT NO. 2

5104

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%,D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%,D	"F	LB/HR
19:17	12.694	61.574	6.5716	0.0000	0.0000	565.35	7.0555	0.0000	0.0000
19:17	12.712	62.793	6.5276	0.0000	0.0000	553.71	7.0785	0.0000	0.0000
19:18	12.703	63.920	6.4341	0.0000	0.0000	546.71	7.0675	0.0000	0.0000
19:18	12.656	64.790	6.4341	0.0000	0.0000	556.08	7.1433	0.0000	0.0000
19:19	12.614	65.354	6.4764	0.0000	0.0000	551.71	7.1645	0.0000	0.0000
19:19	12.694	65.917	6.4662	0.0000	0.0000	536.84	7.0955	0.0000	0.0000
19:20	12.761	65.562	6.5571	0.0000	0.0000	537.46	7.0370	0.0000	0.0000
19:20	12.730	67.350	6.5915	0.0000	0.0000	534.96	7.0636	0.0000	0.0000
19:21	12.684	66.374	6.5472	0.0000	0.0000	620.84	6.9966	0.0000	0.0000
19:21	13.010	66.426	6.5603	0.0000	0.0000	755.60	6.8218	0.0000	0.0000

5 MIN
AVERAGE 12.736 65.548 6.4990 0.0000 0.0000 540.32 7.0566 0.0000 0.0000

STACK NO. 1
POINT NO. 3

6104

E

TIME	SO2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
20:25	13.824	66.865	6.4331	0.0000	0.0000	628.26	6.1176	0.0000	0.0000
20:25	13.847	67.402	6.7056	0.0000	0.0000	636.65	6.0116	0.0000	0.0000
20:26	13.870	66.170	6.6967	0.0000	0.0000	643.03	6.0761	0.0000	0.0000
20:26	13.892	66.323	6.7134	0.0000	0.0000	630.41	6.0595	0.0000	0.0000
20:27	13.923	66.323	6.5177	0.0000	0.0000	616.73	6.0276	0.0000	0.0000
20:27	13.950	66.374	6.6423	0.0000	0.0000	616.91	6.0090	0.0000	0.0000
20:28	13.895	66.272	6.4784	0.0000	0.0000	612.58	6.0513	0.0000	0.0000
20:28	13.876	67.614	6.3357	0.0000	0.0000	594.23	5.9857	0.0000	0.0000
20:29	14.086	67.555	6.3406	0.0000	0.0000	575.55	5.8634	0.0000	0.0000
20:29	14.107	66.787	6.3505	0.0000	0.0000	566.30	5.8735	0.0000	0.0000
20:30	14.165	66.013	6.3652	0.0000	0.0000	559.06	5.8230	0.0000	0.0000
20:30	14.230	65.502	6.4035	0.0000	0.0000	556.31	5.7873	0.0000	0.0000
20:31	14.246	64.227	6.3554	0.0000	0.0000	553.56	5.7513	0.0000	0.0000
20:31	14.164	64.074	6.2177	0.0000	0.0000	523.57	5.6071	0.0000	0.0000
7 MIN	13.988	66.100	6.3330	0.0000	0.0000	575.74	5.8454	0.0000	0.0000
AVERAGE	14.019	66.955	6.4713	0.0000	0.0000	587.74	5.8454	0.0000	0.0000
20:32	14.281	67.120	6.3077	0.0000	0.0000	497.09	5.9983	0.0000	0.0000
20:33	14.012	67.182	6.4091	0.0000	0.0000	464.76	5.8220	0.0000	0.0000
20:33	14.118	67.211	6.3268	0.0000	0.0000	438.39	5.9876	0.0000	0.0000
20:33	14.215	67.183	6.4070	0.0000	0.0000	431.80	5.9804	0.0000	0.0000
20:33	14.249	67.096	6.3200	0.0000	0.0000	401.20	5.8881	0.0000	0.0000
7 MIN	14.057	67.292	6.3592	0.0000	0.0000	456.48	5.9422	0.0000	0.0000
AVERAGE	14.360	79.862	6.1548	0.0000	0.0000	476.24	5.8543	0.0000	0.0000
20:33	14.386	62.364	6.1931	0.0000	0.0000	455.83	5.8238	0.0000	0.0000
20:33	14.343	62.179	6.2864	0.0000	0.0000	486.70	5.8690	0.0000	0.0000
20:34	14.303	61.616	6.1665	0.0000	0.0000	466.83	5.6362	0.0000	0.0000
20:34	14.435	61.411	6.1763	0.0000	0.0000	477.46	5.6893	0.0000	0.0000
20:35	14.331	60.643	6.2275	0.0000	0.0000	461.71	5.6736	0.0000	0.0000
20:35	14.262	60.541	6.2127	0.0000	0.0000	466.21	5.7221	0.0000	0.0000
20:36	14.260	60.131	6.1144	0.0000	0.0000	476.86	5.7407	0.0000	0.0000
20:36	14.420	78.619	6.0160	0.0000	0.0000	459.21	5.6026	0.0000	0.0000
20:37	14.405	76.697	5.9914	0.0000	0.0000	456.71	5.6156	0.0000	0.0000
20:37	14.405	76.441	6.2029	0.0000	0.0000	466.21	5.6156	0.0000	0.0000
20:38	14.291	76.339	6.1144	0.0000	0.0000	467.74	5.7141	0.0000	0.0000
20:38	14.442	76.339	6.1661	0.0000	0.0000	465.09	5.5840	0.0000	0.0000
20:38	14.362	76.134	6.2177	0.0000	0.0000	473.05	5.6530	0.0000	0.0000
20:38	14.353	77.676	6.0455	0.0000	0.0000	471.46	5.6610	0.0000	0.0000

STACK NO. 1
POINT NO. 7

6104

F 5

TIME	02	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
20:57	13.320	69.532	6.6079	0.0000	0.0000	610.04	6.5535	0.0000	0.0000
20:57	13.185	70.607	6.5601	0.0000	0.0000	627.66	6.6704	0.0000	0.0000
20:58	13.130	71.785	7.0086	0.0000	0.0000	642.28	6.7182	0.0000	0.0000
20:58	13.237	72.553	6.9654	0.0000	0.0000	648.48	6.6253	0.0000	0.0000
20:59	13.161	70.423	7.0293	0.0000	0.0000	655.88	6.6917	0.0000	0.0000
20:59	12.862	74.560	7.1424	0.0000	0.0000	658.76	6.6456	0.0000	0.0000
21:00	13.016	76.700	7.1375	0.0000	0.0000	703.38	6.6165	0.0000	0.0000
21:00	12.635	76.134	7.1720	0.0000	0.0000	711.25	6.6351	0.0000	0.0000
21:01	12.933	77.627	6.1439	0.0000	0.0000	622.53	6.6663	0.0000	0.0000
21:01	12.861	75.574	4.0463	0.0000	0.0000	333.26	6.6643	0.0000	0.0000
21:02	13.555	70.812	5.9619	0.0000	0.0000	590.06	5.5357	0.0000	0.0000
21:02	15.004	60.478	3.4335	0.0000	0.0000	206.30	5.0978	0.0000	0.0000
21:03	5.5556	54.171	1.8336	0.0000	0.0000	51.465	5.7970	0.0000	0.0000
21:03	7.4514	46.334	1.4604	0.0000	0.0000	55.231	11.645	0.0000	0.0000
7 MIN									
AVERAGE	12.605	69.631	6.5583	0.0000	0.0000	615.35	7.1263	0.0000	0.0000
STACK NO. 1	13.253	69.832	4.3511	0.0000	0.0000	422.12	6.9912	0.0000	0.0000
POINT NO. 7	16.102	99.293	4.9982	0.0000	0.0000	434.49	6.9122	0.0000	0.0000
TIME 20	02.052	60.242	2.0321	0.0000	0.0000	431.33	12.8220	0.0000	0.0000
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
21:05	13.274	65.734	6.7637	0.0000	0.0000	740.74	6.5534	0.0000	0.0000
21:05	13.111	72.758	6.8063	0.0000	0.0000	727.25	6.7342	0.0000	0.0000
21:05	13.170	75.164	6.6670	0.0000	0.0000	723.25	6.6637	0.0000	0.0000
21:05	13.085	77.264	6.6965	0.0000	0.0000	736.82	6.7740	0.0000	0.0000
21:07	13.105	80.643	6.7833	0.0000	0.0000	736.37	6.7335	0.0000	0.0000
21:07	13.178	81.565	6.7154	0.0000	0.0000	741.12	6.6764	0.0000	0.0000
21:08	13.022	81.306	6.5356	0.0000	0.0000	752.67	6.6112	0.0000	0.0000
21:08	13.070	80.737	6.6112	0.0000	0.0000	764.36	6.6216	0.0000	0.0000
21:09	13.047	76.134	6.5506	0.0000	0.0000	753.62	6.7500	0.0000	0.0000
21:09	13.053	76.444	6.7735	0.0000	0.0000	747.37	6.7501	0.0000	0.0000
21:10	13.053	76.342	6.6713	0.0000	0.0000	727.50	6.7501	0.0000	0.0000
21:10	13.047	77.673	6.8522	0.0000	0.0000	717.66	6.7500	0.0000	0.0000
21:11	12.995	79.004	6.6260	0.0000	0.0000	706.51	6.6351	0.0000	0.0000
21:11	13.105	78.312	6.7539	0.0000	0.0000	702.26	6.7335	0.0000	0.0000
7 MIN									
AVERAGE	13.064	77.253	6.6508	0.0000	0.0000	734.84	6.7494	0.0000	0.0000

4.4.134

STACK NO. 1
POINT NO. 3

604

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
21:43	12.365	105.42	7.5556	0.0000	0.0000	768.25	6.8451	0.0000	0.0000
21:43	12.375	105.66	7.5560	0.0000	0.0000	806.60	6.8537	0.0000	0.0000
21:44	13.013	106.65	7.5409	0.0000	0.0000	797.46	6.8152	0.0000	0.0000
21:44	13.016	106.60	7.5753	0.0000	0.0000	789.69	6.8165	0.0000	0.0000
21:45	13.416	105.12	7.5634	0.0000	0.0000	775.73	6.4712	0.0000	0.0000
21:45	13.173	107.55	7.5015	0.0000	0.0000	813.57	6.5757	0.0000	0.0000
21:46	13.035	105.92	7.6865	0.0000	0.0000	826.71	6.6005	0.0000	0.0000
21:46	13.050	105.16	7.5409	0.0000	0.0000	858.45	6.7673	0.0000	0.0000
21:47	12.666	107.11	7.7225	0.0000	0.0000	866.69	6.5467	0.0000	0.0000
21:47	12.912	109.72	7.5753	0.0000	0.0000	804.66	6.5066	0.0000	0.0000
21:48	12.895	111.10	7.6545	0.0000	0.0000	811.31	6.5175	0.0000	0.0000
21:48	12.864	111.32	7.6786	0.0000	0.0000	815.13	6.6617	0.0000	0.0000
21:49	12.861	113.25	7.6340	0.0000	0.0000	834.53	6.8643	0.0000	0.0000
21:49	12.855	114.23	7.5635	0.0000	0.0000	826.31	6.8883	0.0000	0.0000

7 MIN

AVERAGE 13.014 107.45 7.5465 0.0000 0.0000 853.25 6.5160 0.0000 0.0000

STACK NO. 1
POINT NO. 4

TIME	O2	SO2 #1	SO2 #2	NOX	NOXISO	CO	CO2	T-AMB	STEAM
24 HR.	%D	PPM,D	PPM,D	PPM,D	PPM,D	PPM,D	%D	"F	LB/HR
21:51	13.323	53.403	7.1769	0.0000	0.0000	852.06	6.5503	0.0000	0.0000
21:51	13.415	66.050	7.1375	0.0000	0.0000	867.45	6.4655	0.0000	0.0000
21:52	13.563	62.466	7.0047	0.0000	0.0000	855.33	6.3437	0.0000	0.0000
21:52	13.637	55.166	6.8699	0.0000	0.0000	838.59	6.2736	0.0000	0.0000
21:53	13.655	57.026	6.8703	0.0000	0.0000	821.84	6.2640	0.0000	0.0000
21:53	13.652	56.567	6.8176	0.0000	0.0000	752.23	6.0540	0.0000	0.0000
21:54	13.916	55.164	6.7391	0.0000	0.0000	776.36	6.0362	0.0000	0.0000
21:54	13.830	64.314	6.8621	0.0000	0.0000	783.71	6.7126	0.0000	0.0000
21:55	13.766	54.724	6.8604	0.0000	0.0000	819.55	6.1664	0.0000	0.0000
21:55	13.803	55.545	6.9250	0.0000	0.0000	833.71	6.1365	0.0000	0.0000
21:55	13.904	64.980	6.7637	0.0000	0.0000	815.22	6.0466	0.0000	0.0000
21:56	13.868	56.186	6.7245	0.0000	0.0000	806.47	6.3530	0.0000	0.0000
21:57	13.922	56.154	6.7536	0.0000	0.0000	766.10	6.0323	0.0000	0.0000
21:57	13.955	57.566	6.7056	0.0000	0.0000	766.56	6.8657	0.0000	0.0000

7 MIN

AVERAGE 13.752 59.651 6.8954 0.0000 0.0000 816.32 6.1605 0.0000 0.0000

Rm 104

Arg East

13.568

82.43

6.175

Holly Sugar, Sydney, MT

Stack ID-Name = North Pulp Dyer - West Date(s) = 10-23-93

Run No. ID:	7101	7102	7103	504 Aug.
Time, Start:	1026	1518	1618	
End:	1241	1720	2157	
Results, O ₂ (%, dry)	15.681	15.491	16.161	15.783
CO ₂ (%, dry)	4.147	4.549	3.929	
SO ₂ (ppm, dry)	39.048	70.558	32.439	
CO (ppm, dry)				
% H ₂ O (1/10)	33.96	34.94	see run sheet	
V _m , std (dscf)	34.164	42.555		
Exokinetic (%)	92.1	98.89		
Zero Drift, Post Test	-09:26	1838	2154	
O ₂ cal zero	0.081	0.136	0.102	
drift, %				
CO ₂ cal zero	-0.058	-0.018	-0.018	
drift, %				
SO ₂ cal zero	-1.481	1.02	0.683	
drift, %				
Upscal Drift, Post Test	1438	1831	2143	
O ₂ cal, span	7.116	7.064	7.019	
drift, %				
CO ₂ cal, span	11.89	11.888	12.01	
drift, %				
SO ₂ cal, span	98.826	97.439	98.382	
drift, %				
Spans O ₂	25	25	25	
CO ₂	40	40	40	
SO ₂	120	120	120	

4.4.137

STACK NO. 1
POINT NO. 1

7001

7000 Series - Tests

10-23 W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-ANG	STEAM
24 HR.	%	PPM.U	PPM.U	PPM.U	PPM.U	PPM.U	%	°F	LB/HR
08:44	15.007	43.081	4.7557	0.0000	0.0000	255.41	5.0552	0.0000	0.0000
08:44	14.870	38.888	4.7513	0.0000	0.0000	257.28	5.1271	0.0000	0.0000
08:45	14.841	38.323	4.7570	0.0000	0.0000	255.26	5.2366	0.0000	0.0000
08:45	14.855	41.576	4.8058	0.0000	0.0000	258.91	5.1403	0.0000	0.0000
08:46	14.821	44.288	4.8368	0.0000	0.0000	257.41	5.1855	0.0000	0.0000
08:46	14.818	44.138	4.7882	0.0000	0.0000	258.55	5.2571	0.0000	0.0000
08:47	14.878	45.518	4.7124	0.0000	0.0000	255.41	5.1131	0.0000	0.0000
08:47	15.848	40.758	4.8417	0.0000	0.0000	264.55	4.8700	0.0000	0.0000
08:48	15.838	33.881	4.6448	0.0000	0.0000	182.43	4.7848	0.0000	0.0000
08:48	15.111	32.520	4.5255	0.0000	0.0000	255.28	5.0048	0.0000	0.0000
08:48	14.857	35.431	4.7518	0.0000	0.0000	255.16	5.1237	0.0000	0.0000
08:48	14.752	38.258	4.6534	0.0000	0.0000	256.78	5.2511	0.0000	0.0000
08:50	14.755	40.803	4.6455	0.0000	0.0000	252.64	5.2765	0.0000	0.0000
08:50	14.881	42.088	4.6502	0.0000	0.0000	255.31	5.2041	0.0000	0.0000

7 MIN
AVERAGE 15.055 40.105 4.6604 0.0000 0.0000 255.64 5.0193 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-ANG	STEAM
24 HR.	%	PPM.U	PPM.U	PPM.U	PPM.U	PPM.U	%	°F	LB/HR
08:52	14.850	43.675	4.6529	0.0000	0.0000	257.65	5.1351	0.0000	0.0000
08:52	14.815	43.726	4.6583	0.0000	0.0000	259.15	5.1749	0.0000	0.0000
08:53	14.748	44.833	4.8106	0.0000	0.0000	258.65	5.3210	0.0000	0.0000
08:53	14.758	44.750	4.8403	0.0000	0.0000	258.15	5.3104	0.0000	0.0000
08:54	14.778	45.518	4.7875	0.0000	0.0000	276.53	5.2444	0.0000	0.0000
08:54	14.818	45.353	4.6581	0.0000	0.0000	255.15	5.1722	0.0000	0.0000
08:55	14.778	47.105	4.7518	0.0000	0.0000	259.03	5.2557	0.0000	0.0000
08:55	14.743	46.130	4.8255	0.0000	0.0000	255.28	5.3235	0.0000	0.0000
08:55	14.788	45.550	4.7518	0.0000	0.0000	253.55	5.2758	0.0000	0.0000
08:55	14.788	45.553	4.8500	0.0000	0.0000	270.75	5.2638	0.0000	0.0000
08:57	14.818	50.485	4.6500	0.0000	0.0000	271.40	5.2555	0.0000	0.0000
08:57	14.755	51.202	4.8553	0.0000	0.0000	274.53	5.3130	0.0000	0.0000
08:58	14.718	51.570	4.7511	0.0000	0.0000	275.75	5.3443	0.0000	0.0000
08:58	14.801	52.431	4.6583	0.0000	0.0000	275.03	5.2732	0.0000	0.0000

7 MIN
AVERAGE 14.755 47.553 4.7557 0.0000 0.0000 273.41 5.2745 0.0000 0.0000

STACK NO. 1
POINT NO. 1

7161

W

TIME	WV	NOV 41	NOV 42	NOX	NOX ISO	NO	NOV	TEMP	WIND
74 HR.	2 D	PER D	PER D	PER D	PER D	PER D	2 D	°F	18/HR
10:34	14.740	44.183	4.8788	0.0000	0.0000	714.80	4.8833	0.0000	0.0000
10:34	14.050	44.774	4.8180	0.0000	0.0000	720.80	4.0580	0.0000	0.0000
10:35	14.887	44.051	4.7173	0.0000	0.0000	713.78	4.1855	0.0000	0.0000
10:35	14.886	41.818	4.5057	0.0000	0.0000	708.82	4.1888	0.0000	0.0000
10:35	14.884	44.884	4.8747	0.0000	0.0000	708.84	4.1874	0.0000	0.0000
10:35	14.888	44.058	4.8180	0.0000	0.0000	707.84	4.1111	0.0000	0.0000
10:37	14.838	47.048	4.8800	0.0000	0.0000	713.84	4.1838	0.0000	0.0000
10:38	14.041	47.704	4.8457	0.0000	0.0000	720.85	4.0748	0.0000	0.0000
10:38	14.044	48.083	4.8761	0.0000	0.0000	719.80	4.0833	0.0000	0.0000
10:38	14.888	47.704	4.8877	0.0000	0.0000	718.87	4.1887	0.0000	0.0000
10:38	11.101	11.101	4.7187	0.0000	0.0000	713.87	1.1010	0.0000	0.0000
10:40	14.888	48.418	4.8877	0.0000	0.0000	717.17	4.1877	0.0000	0.0000
10:40	14.878	11.401	4.1140	0.0000	0.0000	717.17	1.1117	0.0000	0.0000

7 MIN

AVERAGE 15.000 14.887 4.7813 0.0000 0.0000 717.17 4.1888 0.0000 0.0000

64.877 4.7367

STACK NO. 1
POINT NO. 2

TIME	WV	NOV 41	NOV 42	NOX	NOX ISO	NO	NOV	TEMP	WIND
74 HR.	2 D	PER D	PER D	PER D	PER D	PER D	2 D	°F	18/HR
10:47	11.004	107.1070	4.17700	0.0000	0.0000	711.00	1.0070	0.0000	0.0000
10:47	11.007	107.1077	4.18131	0.0000	0.0000	707.10	1.0070	0.0000	0.0000
10:47	11.101	107.1077	4.18131	0.0000	0.0000	701.10	4.1811	0.0000	0.0000
10:47	11.741	107.1014	4.18131	0.0000	0.0000	704.10	4.1813	0.0000	0.0000
10:47	11.114	11.107	4.18144	0.0000	0.0000	704.10	4.1811	0.0000	0.0000
10:47	11.100	11.100	4.18131	0.0000	0.0000	704.10	4.1811	0.0000	0.0000
10:47	11.170	11.1047	4.18131	0.0000	0.0000	707.10	4.1813	0.0000	0.0000
10:47	11.771	107.1101	4.18131	0.0000	0.0000	707.10	4.1813	0.0000	0.0000
10:47	11.000	107.1070	4.18131	0.0000	0.0000	711.10	4.1813	0.0000	0.0000
10:48	11.114	107.1070	4.18131	0.0000	0.0000	707.10	4.1813	0.0000	0.0000
10:47	11.718	107.1118	4.18131	0.0000	0.0000	717.10	4.1813	0.0000	0.0000
10:47	11.778	107.1070	4.18131	0.0000	0.0000	718.10	4.1813	0.0000	0.0000
10:48	11.481	107.1088	4.18131	0.0000	0.0000	720.10	4.1813	0.0000	0.0000
10:48	11.478	107.1088	4.18131	0.0000	0.0000	727.10	4.1813	0.0000	0.0000

7 MIN

AVERAGE 15.747 107.1071 4.1813 0.0000 0.0000 711.74 4.1813 0.0000 0.0000

82.371 4.6244

STACK NO. 1
POINT NO. 8

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX180	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
12:07	14.813	28.501	4.4074	0.0000	0.0000	208.42	0.0000	0.0000	0.0000
12:07	14.828	28.548	4.5588	0.0000	0.0000	214.17	0.0000	0.0000	0.0000
12:08	14.700	28.288	4.7888	0.0000	0.0000	228.82	0.0000	0.0000	0.0000
12:08	17.004	18.717	2.8188	0.0000	0.0000	187.71	0.0000	0.0000	0.0000
12:08	20.788	8.1881	0.3182	0.0000	0.0000	11.248	0.0000	0.0000	0.0000
12:08	20.481	8.5882	0.8571	0.0000	0.0000	1.8888	0.0000	0.0000	0.0000
12:10	20.487	8.8888	0.1874	0.0000	0.0000	-0.488	0.0000	0.0000	0.0000
12:10	20.548	8.8884	-0.028	0.0000	0.0000	0.8888	0.0000	0.0000	0.0000

7101

14.85 28.6 4.70

STACK NO. 1
POINT NO. 1

~~810~~ 7001

W

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AMB	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
12:14	18.547	8.2488	8.8818	8.0000	8.0000	48.881	1.1888	8.0000	8.0000
12:14	18.581	8.3488	8.7478	8.0000	8.0000	44.881	1.2888	8.0000	8.0000
12:15	18.588	8.5888	8.8588	8.0000	8.0000	48.888	1.1778	8.0000	8.0000
12:15	18.488	8.8818	8.8444	8.0000	8.0000	48.888	1.2221	8.0000	8.0000
12:15	18.581	8.8834	1.8477	8.0000	8.0000	44.781	1.3848	8.0000	8.0000
12:15	18.588	7.1888	1.8188	8.0000	8.0000	48.481	1.3888	8.0000	8.0000
12:17	18.448	7.2787	8.8888	8.0000	8.0000	48.888	1.2887	8.0000	8.0000
12:17	18.542	7.4248	8.8888	8.0000	8.0000	48.188	1.4478	8.0000	8.0000
12:18	18.488	7.8218	8.8884	8.0000	8.0000	58.782	1.2888	8.0000	8.0000
12:18	18.888	7.8218	1.8828	8.0000	8.0000	48.888	1.7877	8.0000	8.0000
12:18	18.487	7.7818	8.8214	8.0000	8.0000	58.887	1.3848	8.0000	8.0000
12:18	18.488	7.8888	8.8881	8.0000	8.0000	52.482	1.2888	8.0000	8.0000
12:20	18.888	8.1811	1.8188	8.0000	8.0000	58.188	1.3284	8.0000	8.0000
12:20	18.481	8.1888	8.8284	8.0000	8.0000	52.882	1.2484	8.0000	8.0000

7 MIN

AVERAGE 18.484 7.2481 8.8212 8.0000 8.0000 47.878 1.2871 8.0000 8.0000

STACK NO. 1
POINT NO. 2

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AMB	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
12:22	28.228	8.1288	8.2888	8.0000	8.0000	12.128	8.8888	8.0000	8.0000
12:22	28.388	8.4888	8.8888	8.0000	8.0000	8.2488	8.4488	8.0000	8.0000
12:23	1.8188	8.4817	8.1181	8.0000	8.0000	-1.481	18.871	8.0000	8.0000
12:23	8.4888	8.8818	8.8888	8.0000	8.0000	8.874	17.878	8.0000	8.0000
12:24	8.8828	4.8448	-8.888	8.0000	8.0000	2.8888	17.482	8.0000	8.0000
12:24	8.8418	4.1478	8.8888	8.0000	8.0000	-2.824	17.778	8.0000	8.0000
12:25	8.2872	4.8887	-8.848	8.0000	8.0000	8.2488	17.848	8.0000	8.0000
12:25	8.2211	4.8188	-8.888	8.0000	8.0000	1.1248	17.888	8.0000	8.0000
12:25	8.1187	4.8884	8.8188	8.0000	8.0000	2.8888	17.878	8.0000	8.0000
12:25	8.4881	2.7848	8.8888	8.0000	8.0000	-8.888	17.887	8.0000	8.0000
12:27	18.887	2.8878	8.1888	8.0000	8.0000	8.8888	1.8884	8.0000	8.0000
12:27	18.888	4.8888	8.5788	8.0000	8.0000	27.118	8.8488	8.0000	8.0000
12:28	28.382	1.7488	8.2282	8.0000	8.0000	2.8748	8.4888	8.0000	8.0000
12:28	28.484	1.8888	8.8288	8.0000	8.0000	8.8888	8.8881	8.0000	8.0000

7 MIN

AVERAGE 8.8888 8.8878 8.1188 8.0000 8.0000 4.7781 18.347 8.0000 8.0000

STACK NO. 1
POINT NO. 3

7101

W

TIME 24 HR.	SO2 %D	SO2 T1 PPM.D	SO2 T2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %D	I-AMB °F	STEAM LB/HR
12:15	15.027	43.725	3.8842	0.0000	0.0000	125.25	4.2133	0.0000	0.0000
12:16	15.032	44.135	3.8842	0.0000	0.0000	125.45	4.1854	0.0000	0.0000
12:17	15.038	45.155	3.7825	0.0000	0.0000	125.55	4.1857	0.0000	0.0000
12:18	15.113	45.252	3.7237	0.0000	0.0000	125.75	4.1588	0.0000	0.0000
12:19	15.051	44.235	3.8842	0.0000	0.0000	125.75	4.1825	0.0000	0.0000
12:20	15.024	43.885	3.8401	0.0000	0.0000	115.55	4.2158	0.0000	0.0000
12:21	15.073	43.317	3.7775	0.0000	0.0000	121.55	4.1734	0.0000	0.0000
12:22	15.035	43.415	3.7532	0.0000	0.0000	127.33	4.2053	0.0000	0.0000
13:00	15.012	44.157	3.8811	0.0000	0.0000	124.55	4.2212	0.0000	0.0000
13:01	15.035	44.235	3.8842	0.0000	0.0000	124.55	4.1825	0.0000	0.0000
13:02	15.025	43.824	3.8555	0.0000	0.0000	125.75	4.3055	0.0000	0.0000
13:03	15.035	42.385	3.8555	0.0000	0.0000	123.45	4.3275	0.0000	0.0000
13:04	15.031	45.877	3.8547	0.0000	0.0000	131.55	4.3222	0.0000	0.0000
13:05	15.070	45.845	4.0237	0.0000	0.0000	137.75	4.3457	0.0000	0.0000

7 MIN

AVERAGE 15.011 44.421 3.8817 0.0000 0.0000 125.75 4.2257 0.0000 0.0000

16.011

14.421

STACK NO. 1
POINT NO. 4

TIME 24 HR.	SO2 %D	SO2 T1 PPM.D	SO2 T2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %D	I-AMB °F	STEAM LB/HR
----------------	-----------	-----------------	-----------------	--------------	-----------------	-------------	-----------	-------------	----------------

7101

32.048

4.147

STACK NO. 1
POINT NO. 3

7102

W

TIME 24 HR.	O2 %	SO2 T1 PPM.D	SO2 T2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %	TEMP °F	STEAM LB/HR
15:14	7.1242	41.217	0.6612	0.0000	0.0000	15.984	11.911	0.0000	0.0000
15:14	8.8148	37.631	0.2468	0.0000	0.0000	7.3723	12.178	0.0000	0.0000
15:15	8.7824	34.817	0.3888	0.0000	0.0000	3.5237	12.188	0.0000	0.0000
15:15	18.320	22.838	0.2282	0.0000	0.0000	13.745	1.3858	0.0000	0.0000
15:15	15.552	42.283	3.3302	0.0000	0.0000	183.81	3.7558	0.0000	0.0000
15:15	15.071	45.774	4.5558	0.0000	0.0000	215.42	5.0384	0.0000	0.0000
15:17	15.052	55.488	4.4418	0.0000	0.0000	211.82	5.0474	0.0000	0.0000
15:17	14.888	51.055	4.5558	0.0000	0.0000	213.87	5.1058	0.0000	0.0000
15:18	15.016	56.888	4.4512	0.0000	0.0000	213.82	5.0888	0.0000	0.0000
15:18	15.052	56.888	4.5255	0.0000	0.0000	205.83	5.0474	0.0000	0.0000
15:18	15.022	56.888	4.4271	0.0000	0.0000	208.68	5.0818	0.0000	0.0000
15:18	15.044	52.773	4.4458	0.0000	0.0000	208.68	5.0533	0.0000	0.0000
15:20	15.055	52.773	4.4517	0.0000	0.0000	208.83	5.0527	0.0000	0.0000
15:20	15.081	56.488	4.4517	0.0000	0.0000	210.42	5.1005	0.0000	0.0000

7 MIN

AVERAGE 13.708 51.520 4.4458 0.0000 0.0000 181.88 5.2173 0.0000 0.0000

16.0 - 93.5 - 4.45 -

STACK NO. 1
POINT NO. 4

TIME 24 HR.	O2 %	SO2 T1 PPM.D	SO2 T2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %	TEMP °F	STEAM LB/HR
15:22	15.044	55.858	4.5008	0.0000	0.0000	210.35	5.0533	0.0000	0.0000
15:22	15.015	55.852	4.5558	0.0000	0.0000	207.83	5.0572	0.0000	0.0000
15:23	15.025	55.858	4.5187	0.0000	0.0000	207.38	5.0782	0.0000	0.0000
15:23	15.087	55.811	4.5532	0.0000	0.0000	207.38	5.0251	0.0000	0.0000
15:24	14.752	55.855	4.5187	0.0000	0.0000	204.73	5.0787	0.0000	0.0000
15:24	15.445	55.852	4.5337	0.0000	0.0000	208.87	4.7758	0.0000	0.0000
15:25	15.446	55.818	4.4458	0.0000	0.0000	208.75	4.7208	0.0000	0.0000
15:25	15.434	55.818	4.4753	0.0000	0.0000	208.52	4.7258	0.0000	0.0000
15:25	15.415	55.787	4.5452	0.0000	0.0000	208.55	4.7773	0.0000	0.0000
15:25	15.455	55.458	4.5545	0.0000	0.0000	207.38	4.7073	0.0000	0.0000
15:27	15.488	55.848	4.5188	0.0000	0.0000	205.83	4.7488	0.0000	0.0000
15:27	15.514	55.648	4.5558	0.0000	0.0000	205.83	4.5558	0.0000	0.0000
15:28	15.434	55.848	4.4558	0.0000	0.0000	205.83	4.7258	0.0000	0.0000
15:28	15.488	55.858	4.4551	0.0000	0.0000	205.38	4.7525	0.0000	0.0000

7 MIN

AVERAGE 15.277 55.488 4.5388 0.0000 0.0000 205.85 4.8526 0.0000 0.0000

88.4 - 46381 -

STACK NO. 1
POINT NO. 7

7102

W

TIME 24 HR.	O2 %	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX180 PPM.D	CO PPM.D	CO2 %	TEMP °F	STEAM LB/HR
15:45	15.288	57.228	4.5288	0.0000	0.0000	212.55	4.8428	0.0000	0.0000
15:46	15.284	57.484	4.7176	0.0000	0.0000	215.32	4.8898	0.0000	0.0000
15:47	15.328	57.484	4.7518	0.0000	0.0000	216.42	4.8218	0.0000	0.0000
15:47	15.288	57.588	4.8551	0.0000	0.0000	214.17	4.8554	0.0000	0.0000
15:48	15.328	57.382	4.7555	0.0000	0.0000	209.98	4.8188	0.0000	0.0000
15:48	15.364	57.382	4.8551	0.0000	0.0000	209.88	4.8555	0.0000	0.0000
15:48	15.218	57.384	4.7754	0.0000	0.0000	210.38	4.8172	0.0000	0.0000
15:48	15.288	57.542	4.8452	0.0000	0.0000	207.52	4.8451	0.0000	0.0000
15:50	15.282	58.688	4.8554	0.0000	0.0000	207.82	4.8747	0.0000	0.0000
15:50	15.288	57.542	4.8188	0.0000	0.0000	207.52	4.8558	0.0000	0.0000
15:51	15.288	57.538	4.7754	0.0000	0.0000	210.42	4.8278	0.0000	0.0000
15:51	15.787	57.484	4.7714	0.0000	0.0000	215.42	4.8358	0.0000	0.0000
15:52	15.288	57.888	4.8558	0.0000	0.0000	218.55	4.8278	0.0000	0.0000
15:52	15.285	58.588	4.8558	0.0000	0.0000	225.54	4.8728	0.0000	0.0000

7 MIN
AVERAGE 15.287 57.703 4.7553 0.0000 0.0000 212.55 4.8708 0.0000 0.0000

87.71 / 4.7823 /

STACK NO. 1
POINT NO. 8

TIME 24 HR.	O2 %	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX180 PPM.D	CO PPM.D	CO2 %	TEMP °F	STEAM LB/HR
15:54	15.154	58.888	4.8452	0.0000	0.0000	225.17	4.8577	0.0000	0.0000
15:54	15.888	58.281	4.8188	0.0000	0.0000	228.28	5.0181	0.0000	0.0000
15:55	15.881	58.252	4.8558	0.0000	0.0000	231.57	5.0758	0.0000	0.0000
15:55	15.844	58.688	4.8552	0.0000	0.0000	237.78	5.0538	0.0000	0.0000
15:55	15.847	58.488	4.8453	0.0000	0.0000	238.54	5.0585	0.0000	0.0000
15:55	15.111	58.818	4.8555	0.0000	0.0000	242.81	5.0848	0.0000	0.0000
15:57	15.818	58.534	4.8553	0.0000	0.0000	248.54	5.0899	0.0000	0.0000
15:57	15.844	58.737	5.0428	0.0000	0.0000	253.15	5.0533	0.0000	0.0000
15:58	15.838	58.737	4.8554	0.0000	0.0000	254.83	5.0585	0.0000	0.0000
15:58	15.858	70.147	5.0715	0.0000	0.0000	258.83	5.0588	0.0000	0.0000
15:58	14.881	70.454	5.0578	0.0000	0.0000	258.41	5.1358	0.0000	0.0000
15:58	14.888	70.555	4.8558	0.0000	0.0000	257.81	5.1882	0.0000	0.0000
15:58	15.847	71.118	5.0223	0.0000	0.0000	258.81	5.0585	0.0000	0.0000
15:58	14.888	71.278	5.0322	0.0000	0.0000	258.58	5.1558	0.0000	0.0000

7 MIN
AVERAGE 15.834 58.488 4.8393 0.0000 0.0000 247.87 5.0715 0.0000 0.0000

88.49 / 4.8393 /

STACK NO. 1
POINT NO. 14

7107

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:34	14.852	84.876	5.8754	0.0000	0.0000	341.25	5.1430	0.0000	0.0000
18:34	14.893	72.759	5.8888	0.0000	0.0000	339.51	5.1835	0.0000	0.0000
18:35	14.875	78.517	4.8535	0.0000	0.0000	339.93	5.2084	0.0000	0.0000
18:35	15.013	78.749	5.0518	0.0000	0.0000	329.53	5.0889	0.0000	0.0000
18:35	15.029	88.820	4.8808	0.0000	0.0000	315.75	5.0755	0.0000	0.0000
18:36	15.170	88.843	4.8897	0.0000	0.0000	305.14	4.9514	0.0000	0.0000
18:37	15.133	88.582	4.8108	0.0000	0.0000	288.39	4.9953	0.0000	0.0000
18:37	15.311	88.582	4.8345	0.0000	0.0000	289.77	4.9822	0.0000	0.0000
18:38	15.271	88.131	4.7818	0.0000	0.0000	288.88	4.9887	0.0000	0.0000
18:38	15.408	78.312	4.7714	0.0000	0.0000	284.81	4.7488	0.0000	0.0000
18:38	15.415	77.890	4.5187	0.0000	0.0000	249.19	4.7418	0.0000	0.0000
18:38	15.527	78.488	4.8845	0.0000	0.0000	225.84	4.5831	0.0000	0.0000
18:40	15.739	74.887	4.2843	0.0000	0.0000	214.77	4.4530	0.0000	0.0000
18:40	15.775	73.372	4.2353	0.0000	0.0000	199.59	4.4311	0.0000	0.0000

7 MIN

AVERAGE 15.255 75.827 4.7707 0.0000 0.0000 204.14 4.6808 0.0000 0.0000

78.93 4.7707

STACK NO. 1
POINT NO. 14

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:42	15.128	88.888	4.8882	0.0000	0.0000	171.18	4.1288	0.0000	0.0000
18:42	15.205	88.888	4.8155	0.0000	0.0000	159.18	4.0582	0.0000	0.0000
18:43	15.285	88.180	4.8844	0.0000	0.0000	151.18	4.8801	0.0000	0.0000
18:43	15.608	84.285	4.8457	0.0000	0.0000	145.87	4.8715	0.0000	0.0000
18:44	15.685	81.854	4.8401	0.0000	0.0000	139.78	4.8211	0.0000	0.0000
18:44	15.414	81.884	4.8515	0.0000	0.0000	134.85	4.8785	0.0000	0.0000
18:45	15.488	88.111	4.8847	0.0000	0.0000	128.33	4.8334	0.0000	0.0000
18:45	15.554	88.138	4.7138	0.0000	0.0000	124.78	4.7484	0.0000	0.0000
18:45	15.461	88.833	4.8881	0.0000	0.0000	127.85	4.8121	0.0000	0.0000
18:45	15.624	88.877	4.8881	0.0000	0.0000	121.45	4.7825	0.0000	0.0000
18:47	15.677	87.888	4.7825	0.0000	0.0000	128.88	4.7376	0.0000	0.0000
18:47	15.885	88.888	4.8488	0.0000	0.0000	114.33	4.7218	0.0000	0.0000
18:48	15.823	88.478	4.7484	0.0000	0.0000	112.71	4.6878	0.0000	0.0000
18:48	15.585	88.888	4.7483	0.0000	0.0000	108.83	4.7218	0.0000	0.0000

7 MIN

AVERAGE 15.438 88.751 4.8031 0.0000 0.0000 132.75 4.8578 0.0000 0.0000

15.

80.75

7.8031

4.4.145

STACK NO. 1
POINT NO. 8

7102

W

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	%	LB/HR
18:38	14.721	48.181	4.8862	0.0000	0.0000	288.82	5.3422	0.0000	0.0000
18:39	14.839	48.081	4.7887	0.0000	0.0000	288.75	5.4219	0.0000	0.0000
18:40	14.740	48.717	4.8848	0.0000	0.0000	287.75	5.3253	0.0000	0.0000
18:41	14.780	50.024	4.8887	0.0000	0.0000	287.87	5.3343	0.0000	0.0000
18:42	14.778	50.184	4.8747	0.0000	0.0000	288.77	5.3478	0.0000	0.0000
18:43	14.772	51.365	4.8238	0.0000	0.0000	287.77	5.3502	0.0000	0.0000
18:44	14.858	51.508	4.7754	0.0000	0.0000	287.27	5.3554	0.0000	0.0000
18:45	14.778	51.818	4.8888	0.0000	0.0000	287.82	5.3748	0.0000	0.0000
18:46	14.848	52.181	4.8482	0.0000	0.0000	288.77	5.4000	0.0000	0.0000
18:47	14.855	52.788	5.0488	0.0000	0.0000	288.27	5.4518	0.0000	0.0000
18:48	14.855	53.045	4.8188	0.0000	0.0000	277.25	5.4188	0.0000	0.0000
18:49	14.848	53.382	4.8828	0.0000	0.0000	277.25	5.4553	0.0000	0.0000
18:50	14.848	53.587	4.8648	0.0000	0.0000	277.25	5.4553	0.0000	0.0000
18:51	14.855	54.171	4.8181	0.0000	0.0000	278.75	5.4287	0.0000	0.0000

7 MIN
AVERAGE 14.845 51.554 4.8870 0.0000 0.0000 288.75 5.4000 0.0000 0.0000

61.681 4.887

STACK NO. 1
POINT NO. 10

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	%	LB/HR
18:45	14.337	55.885	5.0813	0.0000	0.0000	458.34	5.8743	0.0000	0.0000
18:46	14.285	57.582	5.0883	0.0000	0.0000	458.58	5.7184	0.0000	0.0000
18:47	14.284	58.472	5.1108	0.0000	0.0000	478.45	5.7115	0.0000	0.0000
18:48	14.242	58.188	5.1787	0.0000	0.0000	487.88	5.7888	0.0000	0.0000
18:49	14.188	58.701	5.1748	0.0000	0.0000	501.88	5.7838	0.0000	0.0000
18:50	14.184	58.213	5.1881	0.0000	0.0000	501.88	5.8071	0.0000	0.0000
18:51	14.187	58.828	5.2884	0.0000	0.0000	505.28	5.8044	0.0000	0.0000
18:52	14.144	51.135	5.2888	0.0000	0.0000	518.82	5.8418	0.0000	0.0000
18:53	14.055	51.483	5.3421	0.0000	0.0000	528.18	5.8187	0.0000	0.0000
18:54	14.158	52.857	5.3518	0.0000	0.0000	517.84	5.8388	0.0000	0.0000
18:55	14.128	52.188	5.2834	0.0000	0.0000	518.32	5.8548	0.0000	0.0000
18:56	14.078	52.057	5.2878	0.0000	0.0000	522.57	5.8881	0.0000	0.0000
18:57	14.262	52.415	5.2882	0.0000	0.0000	528.32	5.7812	0.0000	0.0000
18:58	14.118	53.183	5.2248	0.0000	0.0000	532.55	5.8885	0.0000	0.0000

7 MIN
AVERAGE 14.188 52.524 5.2124 0.0000 0.0000 504.52 5.8054 0.0000 0.0000

50.621 6.2124

70558 4.499

4.4.146.

STACK NO. 1
 POINT NO. 15

7103

W

TIME	CO	SO2 #1	SO2 #2	NOX	NOX150	CO	SO2	FLAME	STEAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
18:26	16.488	55.144	4.1554	0.0000	0.0000	187.55	4.5702	0.0000	0.0000
18:26	16.515	55.451	4.1552	0.0000	0.0000	188.88	4.5552	0.0000	0.0000
18:27	16.558	55.125	4.1712	0.0000	0.0000	188.46	4.5581	0.0000	0.0000
18:27	16.732	54.738	4.0485	0.0000	0.0000	181.18	4.4582	0.0000	0.0000
18:28	16.534	54.519	4.1818	0.0000	0.0000	171.51	4.5533	0.0000	0.0000
18:28	16.558	53.513	3.8844	0.0000	0.0000	159.55	4.5555	0.0000	0.0000
18:28	16.422	53.147	4.2545	0.0000	0.0000	228.29	4.7335	0.0000	0.0000
18:28	14.825	41.527	4.0782	0.0000	0.0000	300.37	5.4245	0.0000	0.0000
18:30	15.253	34.512	4.7412	0.0000	0.0000	235.41	4.5551	0.0000	0.0000
18:30	15.557	33.558	3.5204	0.0000	0.0000	174.51	4.5241	0.0000	0.0000
18:31	15.531	34.553	4.0531	0.0000	0.0000	155.32	4.5555	0.0000	0.0000
18:31	15.755	35.573	3.8552	0.0000	0.0000	153.44	4.4523	0.0000	0.0000
18:32	15.755	35.124	3.8457	0.0000	0.0000	153.19	4.4125	0.0000	0.0000
18:32	15.772	35.124	3.8417	0.0000	0.0000	149.32	4.4337	0.0000	0.0000

7 MIN

15

AVERAGE	15.545	45.088	4.1088	0.0000	0.0000	187.13	4.5255	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

46.888-4.109

STACK NO. 1
 POINT NO. 15

TIME	CO	SO2 #1	SO2 #2	NOX	NOX150	CO	SO2	FLAME	STEAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
18:34	15.882	33.742	3.8122	0.0000	0.0000	140.25	4.3381	0.0000	0.0000
18:34	15.924	33.535	3.8417	0.0000	0.0000	139.75	4.3355	0.0000	0.0000
18:35	15.952	33.435	3.7434	0.0000	0.0000	138.75	4.3351	0.0000	0.0000
18:35	15.888	32.871	3.7775	0.0000	0.0000	135.82	4.3325	0.0000	0.0000
18:35	15.855	32.355	3.8752	0.0000	0.0000	137.57	4.3554	0.0000	0.0000
18:35	15.825	32.153	3.7434	0.0000	0.0000	134.45	4.2553	0.0000	0.0000
18:37	15.855	31.855	3.7827	0.0000	0.0000	134.57	4.3554	0.0000	0.0000
18:37	15.882	31.542	3.8543	0.0000	0.0000	127.33	4.2545	0.0000	0.0000
18:38	15.855	31.455	3.8824	0.0000	0.0000	127.33	4.2537	0.0000	0.0000
18:38	15.821	31.435	3.5888	0.0000	0.0000	127.45	4.2155	0.0000	0.0000
18:38	15.855	31.355	3.7532	0.0000	0.0000	125.75	4.2451	0.0000	0.0000
18:38	15.855	31.135	3.7527	0.0000	0.0000	123.85	4.2744	0.0000	0.0000
18:40	15.855	30.825	3.7525	0.0000	0.0000	124.33	4.2372	0.0000	0.0000
18:40	15.122	30.574	3.5872	0.0000	0.0000	122.25	4.1355	0.0000	0.0000

7 MIN

15

AVERAGE	15.843	32.575	3.7434	0.0000	0.0000	131.52	4.2555	0.0000	0.0000
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------

32.07-3.7434

STACK NO. 1
POINT NO. 1

7103

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150"	CO	CO2	I-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
20:45	15.884	15.802	3.8500	0.0000	0.0000	217.05	5.2550	0.0000	0.0000
20:46	15.253	15.591	4.3779	0.0000	0.0000	204.55	4.8927	0.0000	0.0000
20:47	15.884	17.255	4.4412	0.0000	0.0000	202.82	5.0259	0.0000	0.0000
20:47	15.154	18.200	4.4271	0.0000	0.0000	202.42	4.9531	0.0000	0.0000
20:48	15.208	21.912	4.3730	0.0000	0.0000	200.28	4.9252	0.0000	0.0000
20:48	15.124	22.733	4.4355	0.0000	0.0000	201.04	4.9842	0.0000	0.0000
20:49	15.255	23.850	4.2843	0.0000	0.0000	202.42	4.8774	0.0000	0.0000
20:49	15.255	24.833	4.3325	0.0000	0.0000	210.55	4.7875	0.0000	0.0000
20:50	15.257	25.255	4.4517	0.0000	0.0000	217.42	4.9550	0.0000	0.0000
20:50	15.255	27.751	4.3335	0.0000	0.0000	212.82	4.7817	0.0000	0.0000
20:51	15.305	28.878	4.3227	0.0000	0.0000	211.82	4.8375	0.0000	0.0000
20:51	15.425	30.250	4.1858	0.0000	0.0000	209.82	4.7688	0.0000	0.0000
20:52	15.452	30.575	4.3437	0.0000	0.0000	204.85	4.7025	0.0000	0.0000
20:52	15.501	31.875	4.1951	0.0000	0.0000	202.55	4.5575	0.0000	0.0000

7 MIN
AVERAGE 15.153 24.021 4.3249 0.0000 0.0000 217.75 4.8553 0.0000 0.0000

24.021-4.3248

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150"	CO	CO2	I-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
20:54	15.581	31.581	4.2107	0.0000	0.0000	183.05	4.5305	0.0000	0.0000
20:54	15.485	31.745	4.2451	0.0000	0.0000	182.43	4.5725	0.0000	0.0000
20:55	15.521	32.154	4.1355	0.0000	0.0000	188.81	4.5535	0.0000	0.0000
20:55	15.553	32.154	4.2402	0.0000	0.0000	181.81	4.5788	0.0000	0.0000
20:55	15.587	32.418	3.9844	0.0000	0.0000	185.43	4.5831	0.0000	0.0000
20:55	15.540	32.452	3.8745	0.0000	0.0000	181.43	4.5430	0.0000	0.0000
20:57	15.741	32.554	4.0335	0.0000	0.0000	177.85	4.4503	0.0000	0.0000
20:57	15.750	32.718	4.0582	0.0000	0.0000	172.85	4.4444	0.0000	0.0000
20:58	15.853	32.718	3.5551	0.0000	0.0000	155.57	4.2770	0.0000	0.0000
20:58	15.815	32.305	3.3522	0.0000	0.0000	144.45	3.9509	0.0000	0.0000
20:58	15.540	32.052	3.2055	0.0000	0.0000	137.75	3.7555	0.0000	0.0000
20:58	15.515	32.001	3.3055	0.0000	0.0000	134.87	3.7808	0.0000	0.0000
21:00	15.825	31.855	3.1531	0.0000	0.0000	125.55	3.5553	0.0000	0.0000
21:00	15.755	31.855	3.3448	0.0000	0.0000	130.85	3.5310	0.0000	0.0000

7 MIN
AVERAGE 15.582 32.151 3.7901 0.0000 0.0000 155.74 4.2520 0.0000 0.0000

32.151-3.7901

Holly Sugar, Sydney, MT

Stack ID - Name: North Pulp Dryer - East Date(s): 10-23-92

Run No. ID:	8101	8102	8103	04 Aug.
Time, Start:	1024	1632	2002	
End:	1238	1827	2230	
Results, O ₂ (% dry)	17.085	15.358	16.501	
CO ₂ (% dry)	4.078	4.893	4.255	
SO ₂ (ppm dry)	34.089	70.956	39.928	
CO (ppm dry)				
% H ₂ O (%)	38.68	39.06		
V _m , std (dscf)	46.201	37.792		
Evaporative (%)	103.67	98.35		
Zero Drift, Post Test				
O ₂ cal zero				
drift, %				
CO ₂ cal zero				
drift, %				
SO ₂ cal zero				
drift, %				
Upscal Drift, Post Test				
O ₂ cal, span				
drift, %				
CO ₂ cal, span				
drift, %				
SO ₂ cal, span				
drift, %				
Spans O ₂				
CO ₂				
SO ₂				

see run sheet

see 7000 series calcs

STACK NO. 1
POINT NO. 1

8101

E

TIME	O ₂	SO ₂ #1	SO ₂ #2	NO _x	NO _x ISO	CO	CO ₂	TEMP	STEAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
10:25	18.214	18.888	3.2513	0.0000	0.0000	188.81	4.0812	0.0000	0.0000
10:25	18.184	18.074	3.2178	0.0000	0.0000	173.81	4.1488	0.0000	0.0000
10:25	18.223	18.781	3.0085	0.0000	0.0000	145.02	4.0432	0.0000	0.0000
10:25	18.411	18.125	2.8874	0.0000	0.0000	137.78	3.8812	0.0000	0.0000
10:27	18.371	17.884	2.8888	0.0000	0.0000	135.02	3.8152	0.0000	0.0000
10:27	18.481	18.888	2.8578	0.0000	0.0000	132.85	3.8121	0.0000	0.0000
10:28	18.481	18.435	2.8245	0.0000	0.0000	131.83	3.8487	0.0000	0.0000
10:28	18.512	18.434	2.7841	0.0000	0.0000	127.58	3.7835	0.0000	0.0000
10:28	17.222	15.555	2.2873	0.0000	0.0000	88.081	3.1738	0.0000	0.0000
10:28	18.435	14.000	1.0428	0.0000	0.0000	57.738	2.1308	0.0000	0.0000
10:30	18.087	13.005	0.8852	0.0000	0.0000	34.238	1.5875	0.0000	0.0000
10:30	18.128	15.258	1.4363	0.0000	0.0000	74.348	1.5363	0.0000	0.0000
10:31	15.088	27.137	5.2838	0.0000	0.0000	234.17	5.0155	0.0000	0.0000
10:31	15.151	26.878	4.8141	0.0000	0.0000	231.28	4.8703	0.0000	0.0000

7 MIN

AVERAGE 18.778 / 18.088 / 2.8340 / 0.0000 0.0000 134.55 3.5838 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME	O ₂	SO ₂ #1	SO ₂ #2	NO _x	NO _x ISO	CO	CO ₂	TEMP	STEAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR

STACK NO. 1
POINT NO. 1

8101

E

TIME	OX	SO2 T1	SO2 T2	NOX	NOX150	CO	CO2	I-AMH	SI-FAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
11:04	15.317	54.848	4.8788	0.0000	0.0000	177.81	4.8878	0.0000	0.0000
11:04	15.344	55.788	4.8188	0.0000	0.0000	188.81	4.8888	0.0000	0.0000
11:04	15.788	55.847	4.1874	0.0000	0.0000	174.88	4.8774	0.0000	0.0000
11:04	15.387	54.881	4.1878	0.0000	0.0000	177.81	4.7874	0.0000	0.0000
11:05	15.388	54.881	4.1871	0.0000	0.0000	174.41	4.7887	0.0000	0.0000
11:05	15.787	55.481	4.8817	0.0000	0.0000	184.41	4.8747	0.0000	0.0000
11:06	15.378	55.888	4.8788	0.0000	0.0000	178.41	4.8747	0.0000	0.0000
11:06	15.718	55.787	4.8788	0.0000	0.0000	184.41	4.8118	0.0000	0.0000
11:07	15.788	57.887	4.8848	0.0000	0.0000	188.84	4.8787	0.0000	0.0000
11:07	15.771	58.718	4.8748	0.0000	0.0000	188.88	4.8887	0.0000	0.0000
11:08	15.441	58.787	4.1874	0.0000	0.0000	171.88	4.7788	0.0000	0.0000
11:08	15.838	57.887	4.7788	0.0000	0.0000	184.57	4.8848	0.0000	0.0000
11:08	15.884	48.888	4.7748	0.0000	0.0000	188.88	4.8144	0.0000	0.0000
11:08	15.388	57.738	4.4878	0.0000	0.0000	184.41	4.8378	0.0000	0.0000

7 MIN

AVERAGE 15.384 54.881 4.1787 0.0000 0.0000 174.58 4.7887 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME	OX	SO2 T1	SO2 T2	NOX	NOX150	CO	CO2	I-AMH	SI-FAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
11:11	15.138	57.888	4.7778	0.0000	0.0000	184.44	4.8818	0.0000	0.0000
11:11	15.788	57.448	4.8888	0.0000	0.0000	181.88	4.8778	0.0000	0.0000
11:12	15.178	58.718	4.8847	0.0000	0.0000	188.44	4.8481	0.0000	0.0000
11:12	15.184	58.874	4.8788	0.0000	0.0000	184.88	4.8887	0.0000	0.0000
11:13	15.888	58.887	4.7174	0.0000	0.0000	188.41	5.0158	0.0000	0.0000
11:13	15.187	58.888	4.8388	0.0000	0.0000	184.88	4.8888	0.0000	0.0000
11:14	15.187	58.888	4.8844	0.0000	0.0000	188.88	4.8878	0.0000	0.0000
11:14	15.888	58.848	4.8878	0.0000	0.0000	187.88	5.0158	0.0000	0.0000
11:15	15.888	58.787	4.8878	0.0000	0.0000	188.88	5.0888	0.0000	0.0000
11:15	15.884	58.488	4.8488	0.0000	0.0000	188.88	5.0788	0.0000	0.0000
11:16	15.877	58.787	4.8844	0.0000	0.0000	208.88	5.0818	0.0000	0.0000
11:16	15.841	58.787	4.8881	0.0000	0.0000	204.88	5.0888	0.0000	0.0000
11:17	15.887	58.787	4.8848	0.0000	0.0000	208.18	5.0781	0.0000	0.0000
11:17	15.121	58.887	4.8888	0.0000	0.0000	208.18	4.8888	0.0000	0.0000

7 MIN

AVERAGE 15.118 58.888 4.8387 0.0000 0.0000 188.87 4.8888 0.0000 0.0000

STACK NO. 1
POINT NO. 7

8101

E

TIME	02	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
11:51	15.532	15.104	3.7055	0.0000	0.0000	154.57	4.5408	0.0000	0.0000
11:51	15.515	15.082	3.6918	0.0000	0.0000	154.57	4.5382	0.0000	0.0000
11:52	15.537	15.105	3.7075	0.0000	0.0000	153.75	4.5308	0.0000	0.0000
11:52	15.553	15.411	3.8105	0.0000	0.0000	153.75	4.5708	0.0000	0.0000
11:53	15.515	15.557	3.6853	0.0000	0.0000	151.72	4.5552	0.0000	0.0000
11:53	15.575	15.555	3.7550	0.0000	0.0000	147.20	4.5537	0.0000	0.0000
11:54	15.534	15.486	3.6918	0.0000	0.0000	145.74	4.5533	0.0000	0.0000
11:54	15.704	15.707	3.8855	0.0000	0.0000	145.82	4.4822	0.0000	0.0000
11:55	15.518	15.712	3.7525	0.0000	0.0000	143.20	4.5555	0.0000	0.0000
11:55	15.720	15.411	3.7237	0.0000	0.0000	140.57	4.4758	0.0000	0.0000
11:55	15.555	15.453	3.8055	0.0000	0.0000	137.52	4.5501	0.0000	0.0000
11:55	15.707	15.255	3.7334	0.0000	0.0000	135.25	4.4585	0.0000	0.0000
11:57	15.555	15.555	3.7532	0.0000	0.0000	135.57	4.5501	0.0000	0.0000
11:57	15.741	15.453	3.5755	0.0000	0.0000	135.57	4.4503	0.0000	0.0000

7 MIN
AVERAGE 15.545 / 15.482 / 3.6753 / 0.0000 / 0.0000 / 145.55 / 4.5402 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 8

TIME	02	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
11:58	0.5522	15.872	-0.555	0.0000	0.0000	0.4555	17.555	0.0000	0.0000
11:58	0.4761	15.453	0.1151	0.0000	0.0000	-1.555	17.552	0.0000	0.0000
12:00	0.2181	15.557	0.8855	0.0000	0.0000	-0.124	17.553	0.0000	0.0000
12:00	0.1528	14.851	0.1155	0.0000	0.0000	-0.524	17.555	0.0000	0.0000
12:01	0.1751	14.345	0.8855	0.0000	0.0000	-0.245	17.525	0.0000	0.0000
12:01	0.0821	14.745	0.1524	0.0000	0.0000	-0.555	17.552	0.0000	0.0000
12:02	0.1557	14.357	0.1425	0.0000	0.0000	0.7457	17.533	0.0000	0.0000
12:02	0.1555	14.153	-0.555	0.0000	0.0000	-2.455	17.525	0.0000	0.0000
12:03	0.1044	15.855	0.4427	0.0000	0.0000	52.755	17.551	0.0000	0.0000
12:03	15.541	17.555	3.7237	0.0000	0.0000	135.20	4.5535	0.0000	0.0000
12:04	15.552	15.545	3.7551	0.0000	0.0000	142.75	4.5573	0.0000	0.0000
12:05	15.710	15.754	3.8555	0.0000	0.0000	137.55	4.4555	0.0000	0.0000
12:05	15.554	15.252	3.7433	0.0000	0.0000	135.45	4.5575	0.0000	0.0000
12:05	15.455	15.743	4.0575	0.0000	0.0000	152.32	4.7047	0.0000	0.0000

7 MIN
AVERAGE 5.7155 / 15.335 / 1.4415 / 0.0000 / 0.0000 / 52.555 / 16.125 / 0.0000 / 0.0000

2101
W

16.7

4.75

16.445

STACK NO. 1
POINT NO. 1

8601

E

TIME 24 HR.	O2 %	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %	TEMP °F	STEAM LE/HR
12:40	15.408	28.576	4.3468	0.0000	0.0000	282.55	4.7472	0.0000	0.0000
12:40	15.517	32.257	4.2187	0.0000	0.0000	185.43	4.5542	0.0000	0.0000
12:41	15.541	35.022	4.1818	0.0000	0.0000	185.18	4.5338	0.0000	0.0000
12:41	15.488	35.558	4.2500	0.0000	0.0000	183.55	4.5781	0.0000	0.0000
12:42	15.527	43.888	4.2500	0.0000	0.0000	181.88	4.5525	0.0000	0.0000
12:42	15.551	45.881	4.0828	0.0000	0.0000	181.18	4.5250	0.0000	0.0000
12:43	15.575	48.232	4.1752	0.0000	0.0000	180.81	4.5637	0.0000	0.0000
12:43	15.543	48.588	4.0877	0.0000	0.0000	185.43	4.5453	0.0000	0.0000
12:44	15.580	48.688	4.2656	0.0000	0.0000	181.88	4.5164	0.0000	0.0000
12:44	15.732	48.688	4.2688	0.0000	0.0000	178.81	4.4886	0.0000	0.0000
12:45	15.781	48.418	4.0587	0.0000	0.0000	171.84	4.4256	0.0000	0.0000
12:45	15.882	48.873	3.8745	0.0000	0.0000	170.37	4.3828	0.0000	0.0000
12:45	15.788	50.228	3.8877	0.0000	0.0000	168.87	4.4088	0.0000	0.0000
12:45	15.842	48.848	3.2818	0.0000	0.0000	164.87	4.3725	0.0000	0.0000

7 MIN
AVERAGE 15.534 44.052 4.0877 0.0000 0.0000 181.88 4.5227 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME 24 HR.	O2 %	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %	TEMP °F	STEAM LE/HR
12:48	4.5787	45.888	0.5813	0.0000	0.0000	18.888	13.773	0.0000	0.0000
12:48	5.1488	45.888	0.5885	0.0000	0.0000	12.878	13.518	0.0000	0.0000
12:48	5.4845	45.888	0.5885	0.0000	0.0000	15.244	13.487	0.0000	0.0000
12:48	7.1212	48.878	0.5885	0.0000	0.0000	38.881	11.814	0.0000	0.0000
12:50	14.277	25.825	2.1845	0.0000	0.0000	122.83	3.1821	0.0000	0.0000
12:50	18.228	18.888	0.8287	0.0000	0.0000	48.111	1.4453	0.0000	0.0000
12:51	18.337	18.888	1.8888	0.0000	0.0000	118.71	2.2758	0.0000	0.0000
12:51	15.187	37.878	3.8481	0.0000	0.0000	148.84	4.8751	0.0000	0.0000
12:52	15.844	37.428	3.8555	0.0000	0.0000	138.57	4.2858	0.0000	0.0000
12:52	15.875	41.728	3.8514	0.0000	0.0000	135.55	4.1881	0.0000	0.0000
12:53	15.838	43.875	3.7881	0.0000	0.0000	133.82	4.2853	0.0000	0.0000
12:53	15.827	44.238	4.7838	0.0000	0.0000	134.57	4.2133	0.0000	0.0000
12:54	15.821	44.888	3.8548	0.0000	0.0000	125.78	4.2188	0.0000	0.0000
12:54	15.845	43.478	3.7848	0.0000	0.0000	1287.33	4.1873	0.0000	0.0000

7 MIN
AVERAGE 13.858 35.578 2.2814 0.0000 0.0000 257.815 5.3472 0.0000 0.0000

(7085 34.089 4.078

STACK NO. 1
POINT NO. 1

8102

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AMB	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	%	LB/HR
14:58	14.828	61.488	4.8800	0.0000	0.0000	255.08	5.4218	0.0000	0.0000
14:59	14.858	61.555	4.8995	0.0000	0.0000	255.08	5.3874	0.0000	0.0000
14:59	14.828	61.691	4.8485	0.0000	0.0000	254.58	5.4218	0.0000	0.0000
14:59	14.700	61.688	4.7885	0.0000	0.0000	254.88	5.3888	0.0000	0.0000
15:00	14.888	62.005	4.8385	0.0000	0.0000	255.08	5.3888	0.0000	0.0000
15:00	14.758	62.313	4.8338	0.0000	0.0000	272.78	5.3104	0.0000	0.0000
15:01	14.715	63.095	4.8205	0.0000	0.0000	273.78	5.3475	0.0000	0.0000
15:01	14.712	64.053	4.8838	0.0000	0.0000	273.18	5.3888	0.0000	0.0000
15:02	14.784	64.770	4.8288	0.0000	0.0000	272.88	5.3888	0.0000	0.0000
15:02	14.748	65.887	4.8535	0.0000	0.0000	271.75	5.3183	0.0000	0.0000
15:03	14.858	65.821	4.8882	0.0000	0.0000	255.08	5.3874	0.0000	0.0000
15:03	14.788	67.484	4.8188	0.0000	0.0000	257.15	5.3528	0.0000	0.0000
15:04	14.758	67.884	4.8882	0.0000	0.0000	257.08	5.3184	0.0000	0.0000
15:04	14.715	68.158	4.8985	0.0000	0.0000	257.75	5.3475	0.0000	0.0000

7 MIN
AVERAGE 14.785 / 64.544 / 4.8916 / 0.0000 0.0000 257.95 5.3555 0.0000 0.0000

STACK NO. 1
POINT NO. 2

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AMB	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	%	LB/HR
15:05	14.715	68.225	4.8157	0.0000	0.0000	255.78	5.3475	0.0000	0.0000
15:05	14.887	68.532	4.7321	0.0000	0.0000	254.78	5.2578	0.0000	0.0000
15:07	14.724	68.553	4.7124	0.0000	0.0000	253.78	5.3388	0.0000	0.0000
15:07	14.787	70.044	4.8843	0.0000	0.0000	253.58	5.3288	0.0000	0.0000
15:08	14.715	70.157	4.7811	0.0000	0.0000	253.78	5.3475	0.0000	0.0000
15:08	14.828	68.883	4.8482	0.0000	0.0000	245.88	5.2483	0.0000	0.0000
15:08	14.818	68.834	4.7887	0.0000	0.0000	245.84	5.2572	0.0000	0.0000
15:08	14.743	67.838	4.8534	0.0000	0.0000	245.88	5.3288	0.0000	0.0000
15:10	14.832	68.818	4.7173	0.0000	0.0000	245.54	5.2488	0.0000	0.0000
15:10	14.821	68.818	4.7875	0.0000	0.0000	244.54	5.1585	0.0000	0.0000
15:11	14.824	68.784	4.2254	0.0000	0.0000	268.85	5.1588	0.0000	0.0000
15:11	12.245	68.285	2.5188	0.0000	0.0000	52.343	7.4833	0.0000	0.0000
15:12	5.5542	68.357	1.5288	0.0000	0.0000	45.858	12.317	0.0000	0.0000
15:12	5.7048	67.141	1.2287	0.0000	0.0000	38.112	13.138	0.0000	0.0000

7 MIN
AVERAGE 14.883 / 68.858 / 4.6884 / 0.0000 0.0000 266.76 5.1888 0.0000 0.0000

STACK NO. 1
POINT NO. 11

8102

E

TIME 24 HR.	O2 %D	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %D	I-AMB °F	STEAM LB/HR
18:18	14.788	71.828	5.8817	0.0000	0.0000	339.78	0.2768	0.0000	0.0000
18:19	14.878	72.287	4.8838	0.0000	0.0000	342.08	0.3821	0.0000	0.0000
18:19	14.888	72.811	4.8877	0.0000	0.0000	349.58	0.3888	0.0000	0.0000
18:19	14.788	73.884	4.8288	0.0000	0.0000	349.88	0.3843	0.0000	0.0000
18:20	14.787	74.888	4.8888	0.0000	0.0000	354.38	0.3288	0.0000	0.0000
18:20	14.718	75.888	4.8747	0.0000	0.0000	358.82	0.3288	0.0000	0.0000
18:21	14.718	76.882	5.8817	0.0000	0.0000	358.82	0.3478	0.0000	0.0000
18:21	14.814	76.848	5.8822	0.0000	0.0000	358.82	0.4888	0.0000	0.0000
18:22	14.748	77.822	4.8141	0.0000	0.0000	358.12	0.3218	0.0000	0.0000
18:22	14.881	77.888	4.8888	0.0000	0.0000	358.28	0.4888	0.0000	0.0000
18:23	14.878	77.724	4.8288	0.0000	0.0000	358.88	0.3784	0.0000	0.0000
18:23	14.888	78.288	4.8188	0.0000	0.0000	358.78	0.3884	0.0000	0.0000
18:24	14.888	78.812	4.8488	0.0000	0.0000	357.82	0.3874	0.0000	0.0000
18:24	14.888	78.878	0.0000	0.0000	0.0000	354.12	0.4188	0.0000	0.0000

7 MIN
AVERAGE 14.888 76.882 4.8888 0.0000 0.0000 352.88 0.3888 0.0000 0.0000

STACK NO. 1
POINT NO. 12

TIME 24 HR.	O2 %D	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %D	I-AMB °F	STEAM LB/HR
18:25	14.888	88.887	5.8488	0.0000	0.0000	358.88	0.4148	0.0000	0.0000
18:26	14.888	88.884	4.8288	0.0000	0.0000	358.87	0.3888	0.0000	0.0000
18:27	14.888	88.888	4.8844	0.0000	0.0000	358.88	0.4888	0.0000	0.0000
18:27	14.878	81.821	4.8877	0.0000	0.0000	358.78	0.3784	0.0000	0.0000
18:28	14.881	82.288	4.8888	0.0000	0.0000	358.87	0.3788	0.0000	0.0000
18:28	14.814	83.888	4.8488	0.0000	0.0000	352.87	0.4888	0.0000	0.0000
18:28	14.748	84.128	5.1888	0.0000	0.0000	374.87	0.3218	0.0000	0.0000
18:28	14.887	84.788	5.1888	0.0000	0.0000	378.88	0.3714	0.0000	0.0000
18:30	14.721	85.488	5.1888	0.0000	0.0000	378.87	0.3888	0.0000	0.0000
18:30	14.888	85.888	5.1288	0.0000	0.0000	378.74	0.3888	0.0000	0.0000
18:31	14.841	85.881	5.8822	0.0000	0.0000	378.87	0.4118	0.0000	0.0000
18:31	14.878	87.788	5.1888	0.0000	0.0000	374.74	0.3784	0.0000	0.0000
18:32	14.888	88.477	5.1787	0.0000	0.0000	378.48	0.3884	0.0000	0.0000
18:32	15.818	88.818	4.8884	0.0000	0.0000	388.27	0.3828	0.0000	0.0000

7 MIN
AVERAGE 14.888 81.872 5.8484 0.0000 0.0000 362.87 0.3814 0.0000 0.0000

STACK NO. 1
POINT NO. 2

802 7102

W

TIME	OX	SO2 T1	SO2 T2	NOX	NOX150	CO	CO2	I-AMB	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
15:02	14.884	72.841	4.8833	0.0000	0.0000	251.15	5.1324	0.0000	0.0000
15:02	15.784	54.171	4.8828	0.0000	0.0000	257.55	5.4231	0.0000	0.0000
15:03	17.178	34.151	3.2857	0.0000	0.0000	195.08	3.2171	0.0000	0.0000
15:03	15.782	42.180	4.4124	0.0000	0.0000	241.15	4.4583	0.0000	0.0000
15:04	15.158	48.512	4.7754	0.0000	0.0000	257.47	4.8885	0.0000	0.0000
15:04	15.888	58.788	4.8845	0.0000	0.0000	257.25	5.0527	0.0000	0.0000
15:05	15.182	58.782	4.8483	0.0000	0.0000	257.41	5.0123	0.0000	0.0000
15:05	15.878	58.888	4.8885	0.0000	0.0000	251.15	5.0341	0.0000	0.0000
15:05	15.114	58.887	4.8551	0.0000	0.0000	258.53	5.0622	0.0000	0.0000
15:05	14.855	52.354	4.8535	0.0000	0.0000	258.53	5.1466	0.0000	0.0000
15:07	14.855	51.854	5.0323	0.0000	0.0000	257.53	5.1783	0.0000	0.0000
15:07	15.887	58.418	5.0025	0.0000	0.0000	257.48	5.0452	0.0000	0.0000
15:08	15.881	58.248	4.8882	0.0000	0.0000	278.78	5.0314	0.0000	0.0000
15:08	15.188	57.387	4.8483	0.0000	0.0000	272.28	5.0875	0.0000	0.0000

7 MIN
AVERAGE 15.387 55.455 4.8448 0.0000 0.0000 252.88 4.8354 0.0000 0.0000

55.4 4.8448

STACK NO. 1
POINT NO. 10

8(02)

E

TIME	OX	SO2 T1	SO2 T2	NOX	NOX150	CO	CO2	I-AMB	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
15:10	14.888	55.788	5.0428	0.0000	0.0000	274.48	5.1838	0.0000	0.0000
15:10	14.812	55.881	4.8582	0.0000	0.0000	278.28	5.1775	0.0000	0.0000
15:11	14.821	58.478	4.8551	0.0000	0.0000	275.55	5.1888	0.0000	0.0000
15:11	14.888	54.888	4.8582	0.0000	0.0000	255.55	5.1835	0.0000	0.0000
15:12	14.888	48.788	4.7754	0.0000	0.0000	255.82	5.2438	0.0000	0.0000
15:12	14.778	58.254	5.0125	0.0000	0.0000	255.82	5.2871	0.0000	0.0000
15:13	14.888	58.252	5.1818	0.0000	0.0000	318.14	5.3874	0.0000	0.0000
15:13	14.712	70.718	4.8844	0.0000	0.0000	315.14	5.3582	0.0000	0.0000
15:14	14.888	71.171	4.8878	0.0000	0.0000	315.88	5.3888	0.0000	0.0000
15:14	14.715	71.222	5.0813	0.0000	0.0000	312.51	5.3475	0.0000	0.0000
15:15	14.788	70.555	4.8582	0.0000	0.0000	317.75	5.2881	0.0000	0.0000
15:15	14.748	70.484	4.8885	0.0000	0.0000	322.14	5.3183	0.0000	0.0000
15:15	14.888	70.488	4.8141	0.0000	0.0000	324.78	5.3888	0.0000	0.0000
15:15	14.878	70.147	4.8885	0.0000	0.0000	325.13	5.3784	0.0000	0.0000

7 MIN
AVERAGE 14.778 58.888 4.8282 0.0000 0.0000 301.54 5.2818 0.0000 0.0000

83.889 x

STACK NO. 1
POINT NO. 5

7102

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
15:30	15.488	55.284	4.5747	0.0000	0.0000	207.55	4.5534	0.0000	0.0000
15:30	15.505	55.388	4.5550	0.0000	0.0000	207.55	4.5548	0.0000	0.0000
15:31	15.528	55.153	4.5688	0.0000	0.0000	207.45	4.5438	0.0000	0.0000
15:31	15.482	55.488	4.4851	0.0000	0.0000	207.85	4.7820	0.0000	0.0000
15:32	15.482	55.787	4.5008	0.0000	0.0000	205.85	4.7711	0.0000	0.0000
15:32	15.428	55.918	4.5534	0.0000	0.0000	205.77	4.7413	0.0000	0.0000
15:33	15.388	55.921	4.4714	0.0000	0.0000	205.73	4.7558	0.0000	0.0000
15:34	15.488	57.382	4.5438	0.0000	0.0000	207.35	4.8857	0.0000	0.0000
15:34	15.418	57.484	4.5534	0.0000	0.0000	208.42	4.7418	0.0000	0.0000
15:34	15.418	57.484	4.5761	0.0000	0.0000	211.57	4.7882	0.0000	0.0000
15:35	15.388	57.278	4.4851	0.0000	0.0000	212.17	4.7887	0.0000	0.0000
15:35	15.388	57.388	4.4811	0.0000	0.0000	213.55	4.7888	0.0000	0.0000
15:35	15.387	57.228	4.5384	0.0000	0.0000	213.55	4.7878	0.0000	0.0000
15:35	15.428	57.484	4.5842	0.0000	0.0000	213.55	4.7413	0.0000	0.0000

7 MIN
AVERAGE 15.432 55.824 4.5837 0.0000 0.0000 208.75 4.7275 0.0000 0.0000

E

STACK NO. 1
POINT NO. 5

8102

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
15:38	15.381	57.177	4.5881	0.0000	0.0000	215.85	4.7531	0.0000	0.0000
15:38	15.418	55.818	4.5877	0.0000	0.0000	215.42	4.7418	0.0000	0.0000
15:38	15.488	55.818	4.5887	0.0000	0.0000	214.87	4.7488	0.0000	0.0000
15:38	15.317	55.821	4.5788	0.0000	0.0000	215.42	4.8288	0.0000	0.0000
15:38	15.412	57.822	4.7518	0.0000	0.0000	215.88	4.7418	0.0000	0.0000
15:38	15.388	55.814	4.5888	0.0000	0.0000	214.82	4.7887	0.0000	0.0000
15:41	15.288	55.818	4.5828	0.0000	0.0000	215.88	4.8588	0.0000	0.0000
15:41	15.382	57.822	4.7511	0.0000	0.0000	220.17	4.7711	0.0000	0.0000
15:42	15.381	57.125	4.7555	0.0000	0.0000	217.57	4.7531	0.0000	0.0000
15:42	15.388	55.811	4.7515	0.0000	0.0000	217.85	4.8188	0.0000	0.0000
15:43	15.348	55.284	4.7458	0.0000	0.0000	214.55	4.8003	0.0000	0.0000
15:43	15.488	55.838	4.5827	0.0000	0.0000	208.55	4.7488	0.0000	0.0000
15:44	15.382	55.748	4.7888	0.0000	0.0000	212.17	4.7711	0.0000	0.0000
15:44	15.388	55.878	4.8288	0.0000	0.0000	211.88	4.7887	0.0000	0.0000

7 MIN
AVERAGE 15.378 55.782 4.7177 0.0000 0.0000 215.88 4.7888 0.0000 0.0000

STACK NO. 1
POINT NO. 15

7102

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
16:00	16.651	54.678	6.6885	0.0000	0.0000	168.68	6.5713	0.0000	0.0000
16:00	16.628	54.120	6.6781	0.0000	0.0000	161.68	6.5828	0.0000	0.0000
16:01	16.628	54.588	6.6488	0.0000	0.0000	168.68	6.7808	0.0000	0.0000
16:01	16.636	52.482	6.4861	0.0000	0.0000	88.488	6.7824	0.0000	0.0000
16:02	16.654	52.672	6.6802	0.0000	0.0000	86.217	6.5713	0.0000	0.0000
16:02	16.708	51.818	6.4888	0.0000	0.0000	52.888	6.5288	0.0000	0.0000
16:03	16.674	51.888	6.6442	0.0000	0.0000	54.842	6.7888	0.0000	0.0000
16:03	16.638	51.888	6.4187	0.0000	0.0000	86.717	6.5888	0.0000	0.0000
16:04	16.647	51.888	6.6848	0.0000	0.0000	54.717	6.5787	0.0000	0.0000
16:04	16.718	51.888	6.4488	0.0000	0.0000	68.888	6.5188	0.0000	0.0000
16:05	16.687	50.888	6.6878	0.0000	0.0000	88.848	6.5842	0.0000	0.0000
16:05	16.647	50.228	6.5171	0.0000	0.0000	88.888	6.5787	0.0000	0.0000
16:05	16.647	48.822	6.4878	0.0000	0.0000	88.888	6.5787	0.0000	0.0000
16:05	16.781	48.717	6.6184	0.0000	0.0000	88.728	6.5784	0.0000	0.0000

7 MIN 15.568
AVERAGE 16.658 51.888 6.4218 0.0000 0.0000 54.771 6.5877 0.0000 0.0000

61.586

7.4219

E

STACK NO. 1
POINT NO. 15

8102

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
16:08	16.628	51.888	4.5888	0.0000	0.0000	278.78	4.5888	0.0000	0.0000
16:08	16.187	48.888	4.4888	0.0000	0.0000	244.28	4.5888	0.0000	0.0000
16:08	16.608	48.888	6.5888	0.0000	0.0000	188.88	6.5788	0.0000	0.0000
16:08	16.608	50.288	6.5848	0.0000	0.0000	82.848	6.7882	0.0000	0.0000
17:00	16.618	52.828	6.5847	0.0000	0.0000	88.888	6.7888	0.0000	0.0000
17:00	16.488	52.881	6.4777	0.0000	0.0000	87.878	6.6888	0.0000	0.0000
17:01	16.612	52.878	6.5188	0.0000	0.0000	88.728	6.7888	0.0000	0.0000
17:01	16.608	56.788	6.5481	0.0000	0.0000	88.478	6.7888	0.0000	0.0000
17:02	16.414	58.288	6.5814	0.0000	0.0000	87.848	6.5788	0.0000	0.0000
17:02	16.688	58.882	6.5888	0.0000	0.0000	88.844	6.5878	0.0000	0.0000
17:03	16.618	58.888	6.5888	0.0000	0.0000	83.218	6.5882	0.0000	0.0000
17:03	16.682	58.788	6.7188	0.0000	0.0000	88.882	6.5871	0.0000	0.0000
17:04	16.288	51.488	6.7888	0.0000	0.0000	182.88	4.8114	0.0000	0.0000
17:04	16.281	52.888	6.5887	0.0000	0.0000	182.71	6.5848	0.0000	0.0000

7 MIN
AVERAGE 16.288 50.848 6.7888 0.0000 0.0000 117.84 4.8182 0.0000 0.0000

7.7888 x

STACK NO. 1
POINT NO. 17

8102

E

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX160	CO	CO2	TEMP	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
17:05	15.952	54.478	5.8505	0.0000	0.0000	175.21	4.2556	0.0000	0.0000
17:05	15.959	55.518	4.8535	0.0000	0.0000	175.55	4.2556	0.0000	0.0000
17:07	15.957	55.220	4.1221	0.0000	0.0000	175.65	4.2514	0.0000	0.0000
17:07	15.921	57.387	4.8237	0.0000	0.0000	175.65	4.2512	0.0000	0.0000
17:09	15.934	58.531	4.1515	0.0000	0.0000	177.55	4.2533	0.0000	0.0000
17:09	15.954	58.357	4.7875	0.0000	0.0000	175.15	4.2223	0.0000	0.0000
17:09	15.914	51.547	4.3532	0.0000	0.0000	155.32	4.2555	0.0000	0.0000
17:09	15.905	52.571	4.5453	0.0000	0.0000	155.55	4.2375	0.0000	0.0000
17:10	15.929	53.553	4.4415	0.0000	0.0000	177.15	4.2153	0.0000	0.0000
17:10	15.157	54.551	4.5555	0.0000	0.0000	155.53	4.2555	0.0000	0.0000
17:11	15.134	55.252	4.5515	0.0000	0.0000	155.55	4.2331	0.0000	0.0000
17:11	15.058	55.555	4.5255	0.0000	0.0000	205.55	5.0555	0.0000	0.0000
17:12	15.016	57.574	4.7575	0.0000	0.0000	214.17	5.0525	0.0000	0.0000
17:12	15.541	57.554	4.5575	0.0000	0.0000	215.52	5.0555	0.0000	0.0000

7 MIN
AVERAGE 15.455 / 51.534 / 4.3575 / 0.0000 / 0.0000 / 154.55 / 4.7575 / 0.0000 / 0.0000

STACK NO. 1
POINT NO. 18

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX160	CO	CO2	TEMP	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
17:14	15.252	55.557	4.3551	0.0000	0.0000	155.15	4.2554	0.0000	0.0000

STACK NO. 1
POINT NO. 1

8102

E

TIME	02	SO2 #1	SO2 #2	NOX	NOX180	CO	CO2	I-AME	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
17:34	14.875	31.840	4.8858	0.0000	0.0000	535.44	5.3821	0.0000	0.0000
17:34	14.818	37.833	5.3371	0.0000	0.0000	518.84	5.3355	0.0000	0.0000
17:35	13.828	41.115	5.2732	0.0000	0.0000	541.88	5.3078	0.0000	0.0000
17:35	14.027	44.587	5.3878	0.0000	0.0000	545.28	5.3728	0.0000	0.0000
17:35	14.085	48.437	5.3470	0.0000	0.0000	538.48	5.3827	0.0000	0.0000
17:35	14.075	51.553	5.2240	0.0000	0.0000	537.15	5.3801	0.0000	0.0000
17:37	14.223	53.845	5.1848	0.0000	0.0000	538.87	5.3728	0.0000	0.0000
17:37	14.254	55.455	5.0825	0.0000	0.0000	573.58	5.3752	0.0000	0.0000
17:38	14.385	53.711	5.1453	0.0000	0.0000	558.84	5.5232	0.0000	0.0000
17:38	14.288	53.857	4.8731	0.0000	0.0000	558.82	5.7718	0.0000	0.0000
17:38	14.408	54.581	5.1404	0.0000	0.0000	557.55	5.6731	0.0000	0.0000
17:38	14.383	55.144	5.0875	0.0000	0.0000	558.47	5.7838	0.0000	0.0000
17:40	14.318	55.117	5.0223	0.0000	0.0000	558.37	5.6823	0.0000	0.0000
17:40	14.450	55.424	5.0813	0.0000	0.0000	558.55	5.5808	0.0000	0.0000

7 MIN
AVERAGE 14.240 48.388 5.1823 0.0000 0.0000 537.75 5.7838 0.0000 0.0000

STACK NO. 1
POINT NO. 2

7102

W

TIME	02	SO2 #1	SO2 #2	NOX	NOX180	CO	CO2	I-AME	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
17:42	14.552	55.478	4.8568	0.0000	0.0000	517.58	5.4823	0.0000	0.0000
17:42	14.581	55.825	4.7714	0.0000	0.0000	533.51	5.4804	0.0000	0.0000
17:43	14.718	55.834	4.7428	0.0000	0.0000	512.51	5.3448	0.0000	0.0000
17:43	14.830	55.880	4.5844	0.0000	0.0000	287.15	5.1515	0.0000	0.0000
17:44	14.875	55.572	4.5435	0.0000	0.0000	255.48	5.1217	0.0000	0.0000
17:44	15.078	55.322	4.5353	0.0000	0.0000	255.54	5.0341	0.0000	0.0000
17:45	15.243	55.158	4.4811	0.0000	0.0000	228.84	4.8885	0.0000	0.0000
17:45	15.372	55.451	4.2542	0.0000	0.0000	285.12	4.7781	0.0000	0.0000
17:45	15.372	54.881	4.0888	0.0000	0.0000	184.85	4.7781	0.0000	0.0000
17:45	15.531	54.735	4.1278	0.0000	0.0000	178.12	4.5555	0.0000	0.0000
17:47	15.557	53.954	3.8858	0.0000	0.0000	157.81	4.5241	0.0000	0.0000
17:47	15.554	53.455	3.8555	0.0000	0.0000	152.84	4.3548	0.0000	0.0000
17:48	15.838	52.788	3.7237	0.0000	0.0000	147.45	4.3753	0.0000	0.0000
17:48	15.884	52.534	3.7728	0.0000	0.0000	135.45	4.1514	0.0000	0.0000

7 MIN
AVERAGE 15.275 55.272 4.3888 0.0000 0.0000 228.27 4.8822 0.0000 0.0000

66.272 4.3098

STACK NO. 1
POINT NO. 3

7102

TIME 24 HR.	02 %D	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %D	I-AMB °F	STEAM LB/HR
17:50	18.065	51.555	3.8855	0.0000	0.0000	128.55	4.2318	0.0000	0.0000
17:50	18.147	51.355	3.8855	0.0000	0.0000	121.55	4.1887	0.0000	0.0000
17:51	18.167	51.645	3.8847	0.0000	0.0000	122.55	4.1442	0.0000	0.0000
17:51	18.185	50.741	3.8810	0.0000	0.0000	114.21	4.0772	0.0000	0.0000
17:52	18.245	50.434	3.8887	0.0000	0.0000	112.55	4.0247	0.0000	0.0000
17:52	18.254	48.870	3.4875	0.0000	0.0000	105.55	4.0157	0.0000	0.0000
17:53	18.388	48.818	3.5122	0.0000	0.0000	105.55	3.9184	0.0000	0.0000
17:53	18.382	48.857	3.4435	0.0000	0.0000	98.455	3.8871	0.0000	0.0000
17:54	18.411	48.154	3.4555	0.0000	0.0000	83.855	3.8812	0.0000	0.0000
17:54	18.442	48.744	3.4755	0.0000	0.0000	83.845	3.9545	0.0000	0.0000
17:55	18.454	48.232	3.4777	0.0000	0.0000	84.842	3.8446	0.0000	0.0000
17:55	18.485	48.232	3.2552	0.0000	0.0000	80.554	3.8835	0.0000	0.0000
17:55	18.500	48.130	3.3252	0.0000	0.0000	82.725	3.8842	0.0000	0.0000
17:55	18.395	47.725	3.3545	0.0000	0.0000	82.844	3.8825	0.0000	0.0000

7 MIN AVERAGE 15.307 / 18.387 48.555 3.4854 0.0000 0.0000 104.55 3.8700 0.0000 0.0000

48.688 3.4867 /

STACK NO. 1
POINT NO. 4

8102

TIME 24 HR.	02 %D	SO2 #1 PPM.D	SO2 #2 PPM.D	NOX PPM.D	NOX150 PPM.D	CO PPM.D	CO2 %D	I-AMB °F	STEAM LB/HR
17:55	18.414	47.255	3.3154	0.0000	0.0000	87.725	3.8705	0.0000	0.0000
17:55	18.455	47.155	3.2554	0.0000	0.0000	81.557	3.8354	0.0000	0.0000
17:55	18.500	47.054	3.3154	0.0000	0.0000	75.475	3.8642	0.0000	0.0000
17:55	18.425	45.855	3.2857	0.0000	0.0000	83.845	3.8732	0.0000	0.0000
18:00	18.571	45.852	3.3445	0.0000	0.0000	75.474	3.7451	0.0000	0.0000
18:00	18.472	45.257	3.1777	0.0000	0.0000	75.555	3.8251	0.0000	0.0000
18:01	18.585	45.445	3.3845	0.0000	0.0000	75.555	3.7852	0.0000	0.0000
18:01	18.577	45.135	3.2557	0.0000	0.0000	77.725	3.7575	0.0000	0.0000
18:02	18.524	45.572	3.3551	0.0000	0.0000	75.224	3.7525	0.0000	0.0000
18:02	18.445	45.415	3.2554	0.0000	0.0000	75.555	3.8455	0.0000	0.0000
18:03	18.553	44.855	3.1824	0.0000	0.0000	77.225	3.8515	0.0000	0.0000
18:04	18.471	37.455	4.0541	0.0000	0.0000	105.31	4.5541	0.0000	0.0000
18:04	18.057	25.575	4.3155	0.0000	0.0000	211.55	5.0552	0.0000	0.0000
18:04	18.851	35.877	3.5255	0.0000	0.0000	115.45	4.3222	0.0000	0.0000

7 MIN AVERAGE 18.270 / 45.375 / 3.4375 / 0.0000 0.0000 85.355 4.0525 0.0000 0.0000

STACK NO. 1
POINT NO. E

8102

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX160	CO	CO2	I-AME	STEAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
18:05	18.187	38.750	3.3882	0.0000	0.0000	88.585	4.1178	0.0000	0.0000
18:06	18.282	38.188	3.3888	0.0000	0.0000	88.845	4.0818	0.0000	0.0000
18:07	18.187	38.888	3.4878	0.0000	0.0000	87.845	4.1442	0.0000	0.0000
18:07	18.147	40.188	3.5171	0.0000	0.0000	87.888	4.1087	0.0000	0.0000
18:08	18.878	40.448	3.6848	0.0000	0.0000	87.718	4.1581	0.0000	0.0000
18:08	18.110	40.448	3.6488	0.0000	0.0000	87.718	4.1418	0.0000	0.0000
18:08	18.110	40.818	3.6888	0.0000	0.0000	88.487	4.1418	0.0000	0.0000
18:08	18.688	41.824	3.8888	0.0000	0.0000	88.717	4.2828	0.0000	0.0000
18:10	18.887	41.728	3.8318	0.0000	0.0000	88.488	4.2478	0.0000	0.0000
18:10	18.888	41.834	3.8748	0.0000	0.0000	88.48	4.3248	0.0000	0.0000
18:11	18.788	42.788	3.7888	0.0000	0.0000	88.88	4.4181	0.0000	0.0000
18:11	18.888	43.817	3.8842	0.0000	0.0000	88.88	4.5788	0.0000	0.0000
18:12	18.778	43.418	3.8782	0.0000	0.0000	121.88	4.4811	0.0000	0.0000
18:12	18.888	44.882	3.7881	0.0000	0.0000	125.48	4.5828	0.0000	0.0000

7 MIN
AVERAGE 18.881 41.848 3.8488 0.0000 0.0000 88.848 4.2488 0.0000 0.0000

STACK NO. 1
POINT NO. E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX160	CO	CO2	I-AME	STEAM
24 HR.	%	PPM	PPM	PPM	PPM	PPM	%	°F	LB/HR
18:14	18.884	48.774	3.8888	0.0000	0.0000	132.88	4.5878	0.0000	0.0000
18:14	18.841	48.188	4.0888	0.0000	0.0000	137.88	4.5888	0.0000	0.0000
18:15	18.884	48.842	4.2888	0.0000	0.0000	148.48	4.7888	0.0000	0.0000
18:15	18.281	47.888	4.2888	0.0000	0.0000	155.18	4.8818	0.0000	0.0000
18:15	18.288	48.188	4.2288	0.0000	0.0000	151.87	4.8278	0.0000	0.0000
18:15	18.188	58.488	4.2884	0.0000	0.0000	171.18	4.8888	0.0000	0.0000
18:17	18.888	54.878	4.8881	0.0000	0.0000	177.44	5.0447	0.0000	0.0000
18:17	18.888	54.888	4.8828	0.0000	0.0000	188.18	5.0888	0.0000	0.0000
18:18	18.882	54.888	4.8878	0.0000	0.0000	188.88	5.0818	0.0000	0.0000
18:18	14.888	58.788	4.8881	0.0000	0.0000	208.88	5.1888	0.0000	0.0000
18:18	14.888	58.871	4.8888	0.0000	0.0000	208.17	5.1882	0.0000	0.0000
18:18	14.888	58.878	4.7872	0.0000	0.0000	214.17	5.2848	0.0000	0.0000
18:20	14.881	57.888	4.7818	0.0000	0.0000	224.87	5.2782	0.0000	0.0000
18:20	14.788	57.788	4.8818	0.0000	0.0000	238.84	5.3184	0.0000	0.0000

7 MIN
AVERAGE 18.188 52.872 4.8888 0.0000 0.0000 181.81 5.0184 0.0000 0.0000

STACK NO. 1
POINT NO. 7

8102

E

TIME	O2	SO2 #1	SO2 #2	NOX	NOX180	CO	CO2	I-AMB	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:22	14.782	58.472	4.8551	0.0000	0.0000	232.81	0.2811	0.0000	0.0000
18:22	14.773	58.188	4.7825	0.0000	0.0000	243.72	0.2871	0.0000	0.0000
18:23	14.832	58.577	4.7784	0.0000	0.0000	246.81	0.2458	0.0000	0.0000
18:23	14.881	58.577	4.7875	0.0000	0.0000	251.78	0.3755	0.0000	0.0000
18:24	14.782	58.687	4.7515	0.0000	0.0000	253.41	0.3532	0.0000	0.0000
18:24	14.887	58.284	4.7321	0.0000	0.0000	253.51	0.3535	0.0000	0.0000
18:25	14.718	58.521	4.7813	0.0000	0.0000	255.91	0.3448	0.0000	0.0000
18:25	14.757	58.725	4.8403	0.0000	0.0000	258.03	0.3824	0.0000	0.0000
18:25	14.712	51.483	4.8682	0.0000	0.0000	258.15	0.3502	0.0000	0.0000
18:26	14.721	51.442	4.8255	0.0000	0.0000	274.72	0.3422	0.0000	0.0000
18:27	14.727	52.108	4.8485	0.0000	0.0000	288.56	0.3858	0.0000	0.0000
18:27	14.801	52.188	4.7811	0.0000	0.0000	287.82	0.4458	0.0000	0.0000
18:28	14.832	53.132	4.8288	0.0000	0.0000	288.62	0.4184	0.0000	0.0000
18:28	14.835	53.285	5.0322	0.0000	0.0000	282.52	0.4155	0.0000	0.0000

7 MIN
AVERAGE 14.714 58.523 4.8273 0.0000 0.0000 253.75 0.3487 0.0000 0.0000

STACK NO. 1
POINT NO. 8

7102

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX180	CO	CO2	I-AMB	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:30	14.825	54.259	5.8223	0.0000	0.0000	301.38	0.4245	0.0000	0.0000
18:30	14.858	54.297	5.8131	0.0000	0.0000	301.14	0.4544	0.0000	0.0000
18:31	14.811	54.853	5.8025	0.0000	0.0000	295.54	0.4378	0.0000	0.0000
18:31	14.846	54.544	4.8885	0.0000	0.0000	308.84	0.4886	0.0000	0.0000
18:32	14.823	54.548	5.8558	0.0000	0.0000	304.38	0.4272	0.0000	0.0000
18:32	14.854	54.888	4.8354	0.0000	0.0000	287.77	0.4777	0.0000	0.0000
18:33	14.854	54.558	5.8488	0.0000	0.0000	285.85	0.4887	0.0000	0.0000
18:33	14.885	52.488	4.8843	0.0000	0.0000	277.15	0.4511	0.0000	0.0000
18:34	15.273	43.317	3.5554	0.0000	0.0000	105.45	4.8887	0.0000	0.0000
18:34	15.818	48.881	4.8831	0.0000	0.0000	183.43	4.3834	0.0000	0.0000
18:35	14.842	42.887	4.8731	0.0000	0.0000	275.03	0.4518	0.0000	0.0000
18:35	14.745	44.885	4.8425	0.0000	0.0000	253.98	0.3183	0.0000	0.0000
18:35	14.775	45.188	4.8452	0.0000	0.0000	257.55	0.3557	0.0000	0.0000
18:35	14.715	45.588	4.8532	0.0000	0.0000	252.15	0.3475	0.0000	0.0000

7 MIN
AVERAGE 14.851 55.152 4.7238 0.0000 0.0000 272.24 0.4218 0.0000 0.0000

66.162
4.7230

STACK NO. 1
POINT NO. 11

8102

[Handwritten signature]

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	1-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:54	14.451	45.850	4.7415	0.0000	0.0000	355.25	5.5750	0.0000	0.0000
18:54	14.353	35.841	4.8150	0.0000	0.0000	382.88	5.5510	0.0000	0.0000
18:55	14.005	41.832	5.2553	0.0000	0.0000	518.57	5.5512	0.0000	0.0000
18:55	13.817	51.407	5.2052	0.0000	0.0000	541.15	5.5115	0.0000	0.0000
18:55	13.855	55.445	5.2525	0.0000	0.0000	525.44	5.5515	0.0000	0.0000
18:55	13.925	54.105	5.3555	0.0000	0.0000	522.44	5.5275	0.0000	0.0000
18:57	13.835	55.204	5.3125	0.0000	0.0000	515.82	5.5225	0.0000	0.0000
18:57	13.855	55.521	5.1454	0.0000	0.0000	511.70	5.5555	0.0000	0.0000
18:58	13.554	55.552	5.1551	0.0000	0.0000	511.52	5.5755	0.0000	0.0000
18:58	13.572	55.555	5.2550	0.0000	0.0000	455.55	5.5504	0.0000	0.0000
18:58	13.555	75.245	5.2142	0.0000	0.0000	452.55	5.5550	0.0000	0.0000
18:58	14.005	77.775	5.3125	0.0000	0.0000	452.55	5.5555	0.0000	0.0000
18:59	13.815	72.554	5.3571	0.0000	0.0000	472.55	5.5455	0.0000	0.0000
18:59	14.054	75.555	5.3125	0.0000	0.0000	455.55	5.5157	0.0000	0.0000

7 MIN
AVERAGE 14.535 51.332 5.2545 0.0000 0.0000 455.44 5.5357 0.0000 0.0000

STACK NO. 1
POINT NO. 12

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	1-AME	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:02	14.115	72.707	5.0553	0.0000	0.0000	452.72	5.5525	0.0000	0.0000
18:02	14.255	75.552	5.1555	0.0000	0.0000	445.54	5.7553	0.0000	0.0000
18:03	14.155	75.514	5.0225	0.0000	0.0000	445.47	5.5253	0.0000	0.0000
18:03	14.252	75.157	4.8552	0.0000	0.0000	441.72	5.7221	0.0000	0.0000
18:04	14.245	72.257	4.8553	0.0000	0.0000	455.57	5.7513	0.0000	0.0000
18:04	14.345	71.555	4.8553	0.0000	0.0000	427.15	5.5557	0.0000	0.0000
18:05	14.254	72.552	4.8543	0.0000	0.0000	427.35	5.7115	0.0000	0.0000
18:05	14.245	72.552	4.8525	0.0000	0.0000	425.45	5.7513	0.0000	0.0000
18:05	14.355	72.553	4.8755	0.0000	0.0000	451.22	5.5477	0.0000	0.0000
18:05	14.355	72.552	4.8555	0.0000	0.0000	454.47	5.5211	0.0000	0.0000
18:07	14.354	72.552	4.8755	0.0000	0.0000	452.55	5.7555	0.0000	0.0000
18:07	14.452	72.755	4.8755	0.0000	0.0000	445.22	5.5155	0.0000	0.0000
18:08	14.254	71.754	5.2555	0.0000	0.0000	445.54	5.7455	0.0000	0.0000
18:08	14.217	51.552	5.3553	0.0000	0.0000	515.54	5.7775	0.0000	0.0000

7 MIN
AVERAGE 14.277 71.554 5.0252 0.0000 0.0000 445.45 5.7251 0.0000 0.0000

15.358 70.956 4.883

STACK NO. 1
POINT NO. 12

8103

E

TIME	O2	S02 #1	S02 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:10	14.832	55.555	5.1818	0.0000	0.0000	248.88	5.4188	0.0000	0.0000
18:10	14.773	55.455	4.8787	0.0000	0.0000	235.54	5.2871	0.0000	0.0000
18:11	14.785	55.555	4.8659	0.0000	0.0000	235.02	5.2854	0.0000	0.0000
18:11	14.818	54.427	4.8885	0.0000	0.0000	275.78	5.2572	0.0000	0.0000
18:12	14.818	55.348	4.8157	0.0000	0.0000	275.48	5.2552	0.0000	0.0000
18:12	14.788	55.527	4.8787	0.0000	0.0000	273.88	5.2758	0.0000	0.0000
18:13	14.853	55.528	4.8551	0.0000	0.0000	287.55	5.2288	0.0000	0.0000
18:13	14.842	55.578	4.8188	0.0000	0.0000	255.55	5.1518	0.0000	0.0000
18:14	14.821	55.578	4.8508	0.0000	0.0000	252.55	5.1888	0.0000	0.0000
18:14	15.007	55.527	4.7124	0.0000	0.0000	255.55	5.0552	0.0000	0.0000
18:15	14.888	55.588	4.7813	0.0000	0.0000	258.81	5.1111	0.0000	0.0000
18:15	15.031	55.424	4.5208	0.0000	0.0000	255.81	5.0738	0.0000	0.0000
18:15	15.031	55.527	4.8485	0.0000	0.0000	255.41	5.0738	0.0000	0.0000
18:15	15.007	55.424	4.8588	0.0000	0.0000	252.77	5.0552	0.0000	0.0000

7 MIN
AVERAGE 14.888 55.578 4.7888 0.0000 0.0000 275.28 5.1888 0.0000 0.0000

STACK NO. 1
POINT NO. 14

TIME	O2	S02 #1	S02 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:16	15.088	55.588	4.5544	0.0000	0.0000	248.54	5.0151	0.0000	0.0000
18:16	15.124	55.478	4.4858	0.0000	0.0000	245.55	4.9542	0.0000	0.0000
18:16	15.253	55.117	4.4173	0.0000	0.0000	248.78	4.8527	0.0000	0.0000
18:16	15.333	55.351	4.4753	0.0000	0.0000	232.42	4.8135	0.0000	0.0000
18:20	15.225	55.588	4.4555	0.0000	0.0000	228.84	4.8885	0.0000	0.0000
18:20	15.053	55.758	4.5888	0.0000	0.0000	221.57	4.7878	0.0000	0.0000
18:21	15.392	55.348	4.2482	0.0000	0.0000	221.17	4.7711	0.0000	0.0000
18:21	15.483	55.488	4.4359	0.0000	0.0000	212.17	4.7525	0.0000	0.0000
18:22	15.483	55.542	4.2588	0.0000	0.0000	211.57	4.7525	0.0000	0.0000
18:22	15.471	54.881	4.2554	0.0000	0.0000	208.55	4.5541	0.0000	0.0000
18:23	15.333	55.144	4.3778	0.0000	0.0000	213.88	4.8135	0.0000	0.0000
18:23	15.452	55.588	4.4222	0.0000	0.0000	218.88	4.7188	0.0000	0.0000
18:24	15.385	55.555	4.2254	0.0000	0.0000	212.55	4.7534	0.0000	0.0000
18:24	15.588	55.555	4.3388	0.0000	0.0000	205.55	4.5522	0.0000	0.0000

7 MIN
AVERAGE 15.333 55.548 4.4552 0.0000 0.0000 222.48 4.8888 0.0000 0.0000

STACK NO. 1
POINT NO. 17

7103

W

TIME	CO	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:42	18.118	28.788	3.5712	0.0000	0.0000	118.88	4.1888	0.0000	0.0000
18:42	18.818	28.887	3.7888	0.0000	0.0000	114.88	4.2288	0.0000	0.0000
18:43	18.144	28.848	3.4828	0.0000	0.0000	113.88	4.1128	0.0000	0.0000
18:43	18.164	28.482	3.4874	0.0000	0.0000	112.88	4.1488	0.0000	0.0000
18:44	18.182	28.884	3.5258	0.0000	0.0000	108.78	4.0888	0.0000	0.0000
18:44	18.881	28.888	3.5778	0.0000	0.0000	110.88	4.1878	0.0000	0.0000
18:45	18.188	28.188	3.5858	0.0000	0.0000	108.88	4.1878	0.0000	0.0000
18:45	18.274	28.888	3.4828	0.0000	0.0000	111.78	4.0812	0.0000	0.0000
18:45	18.187	28.878	3.7848	0.0000	0.0000	108.71	4.1442	0.0000	0.0000
18:45	18.128	28.878	3.8481	0.0000	0.0000	107.88	4.1288	0.0000	0.0000
18:47	18.147	28.888	3.5784	0.0000	0.0000	108.88	4.1887	0.0000	0.0000
18:47	18.171	28.814	3.5888	0.0000	0.0000	108.88	4.0881	0.0000	0.0000
18:48	18.288	28.888	3.5872	0.0000	0.0000	107.88	4.0888	0.0000	0.0000
18:48	18.187	28.887	3.8488	0.0000	0.0000	108.78	4.0781	0.0000	0.0000

7 MIN
AVERAGE 18.148 28.882 3.5887 0.0000 0.0000 108.87 4.1182 0.0000 0.0000

28.882 3.6637

E

STACK NO. 1
POINT NO. 18

8103

TIME	CO	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	TEMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
18:50	18.288	27.887	3.4888	0.0000	0.0000	108.71	4.0887	0.0000	0.0000
18:50	18.288	27.841	3.5884	0.0000	0.0000	108.88	4.0884	0.0000	0.0000
18:51	18.242	27.188	3.4888	0.0000	0.0000	108.48	4.0278	0.0000	0.0000
18:51	18.288	27.187	3.5888	0.0000	0.0000	108.48	4.0888	0.0000	0.0000
18:52	18.188	28.778	3.4878	0.0000	0.0000	108.88	4.0887	0.0000	0.0000
18:52	18.148	28.727	3.5881	0.0000	0.0000	108.48	4.1188	0.0000	0.0000
18:53	18.888	28.881	3.8824	0.0000	0.0000	117.88	4.2188	0.0000	0.0000
18:53	18.888	28.811	3.8487	0.0000	0.0000	108.82	4.0884	0.0000	0.0000
18:54	18.882	28.248	3.7888	0.0000	0.0000	108.78	4.2888	0.0000	0.0000
18:54	18.182	28.888	3.8817	0.0000	0.0000	118.88	4.0884	0.0000	0.0000
18:55	18.187	27.877	3.8171	0.0000	0.0000	112.48	4.1442	0.0000	0.0000
18:55	18.118	28.482	3.8188	0.0000	0.0000	112.88	4.1418	0.0000	0.0000
18:55	18.848	28.884	3.8888	0.0000	0.0000	118.88	4.2888	0.0000	0.0000
18:55	18.824	28.828	3.7484	0.0000	0.0000	118.28	4.2188	0.0000	0.0000

7 MIN
AVERAGE 18.118 28.878 3.5884 0.0000 0.0000 118.18 4.1418 0.0000 0.0000

STACK NO. 1
POINT NO. 1E

803

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX100	CO	CO2	I-AME	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
18:58	16.876	48.888	3.8824	0.0000	0.0000	132.33	4.3437	0.0000	0.0000
18:59	16.827	46.188	3.8882	0.0000	0.0000	135.87	4.3888	0.0000	0.0000
18:59	16.888	46.448	4.0000	0.0000	0.0000	144.28	4.4878	0.0000	0.0000
18:59	16.788	46.881	3.8848	0.0000	0.0000	142.70	4.4888	0.0000	0.0000
20:00	16.747	41.288	3.8842	0.0000	0.0000	148.87	4.4888	0.0000	0.0000
20:00	16.888	41.888	4.1028	0.0000	0.0000	158.88	4.8144	0.0000	0.0000
20:01	16.840	42.241	4.1782	0.0000	0.0000	151.84	4.8188	0.0000	0.0000
20:07	16.448	42.788	4.0778	0.0000	0.0000	158.88	4.7188	0.0000	0.0000
20:07	16.748	43.888	4.2481	0.0000	0.0000	172.81	4.7888	0.0000	0.0000
20:07	16.488	43.888	4.1172	0.0000	0.0000	178.84	4.7872	0.0000	0.0000
20:08	16.881	43.888	4.2788	0.0000	0.0000	177.88	4.7881	0.0000	0.0000
20:08	16.474	43.878	4.1128	0.0000	0.0000	178.84	4.8814	0.0000	0.0000
20:04	16.487	43.888	4.2748	0.0000	0.0000	180.81	4.7288	0.0000	0.0000
20:04	16.484	44.288	4.1074	0.0000	0.0000	184.88	4.7288	0.0000	0.0000

7 MIN
AVERAGE 16.888 42.218 4.0848 0.0000 0.0000 161.27 4.8882 0.0000 0.0000

STACK NO. 1
POINT NO. 2E

7103

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX100	CO	CO2	I-AME	STEAM
24 HR.	%D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%D	°F	LB/HR
20:08	16.482	38.782	4.0881	0.0000	0.0000	188.81	4.8788	0.0000	0.0000
20:08	16.882	38.181	4.1418	0.0000	0.0000	188.88	4.8801	0.0000	0.0000
20:07	16.888	28.878	4.8842	0.0000	0.0000	201.88	4.8188	0.0000	0.0000
20:07	14.882	27.848	4.8888	0.0000	0.0000	228.84	5.1184	0.0000	0.0000
20:08	16.884	28.828	4.8888	0.0000	0.0000	231.78	5.0878	0.0000	0.0000
20:08	16.818	28.788	4.7821	0.0000	0.0000	238.84	5.0888	0.0000	0.0000
20:08	14.882	38.884	4.8787	0.0000	0.0000	238.84	5.1888	0.0000	0.0000
20:08	14.821	38.818	4.7488	0.0000	0.0000	241.28	5.1888	0.0000	0.0000
20:10	14.870	38.721	4.7818	0.0000	0.0000	244.84	5.1271	0.0000	0.0000
20:10	14.833	31.881	4.8881	0.0000	0.0000	248.78	5.1888	0.0000	0.0000
20:11	14.878	32.188	4.7272	0.0000	0.0000	251.41	5.1181	0.0000	0.0000
20:11	14.888	32.184	4.7714	0.0000	0.0000	251.81	5.1888	0.0000	0.0000
20:12	14.884	32.184	4.7818	0.0000	0.0000	254.41	5.1824	0.0000	0.0000
20:12	14.844	32.887	4.8878	0.0000	0.0000	258.18	5.2888	0.0000	0.0000

7 MIN
AVERAGE 16.884 38.811 4.7888 0.0000 0.0000 227.87 5.0284 0.0000 0.0000

30.84 - 4.7088

STACK NO. 1
POINT NO. 3

7103

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
21:02	16.752	31.551	3.0783	0.0000	0.0000	122.08	3.6383	0.0000	0.0000
21:02	16.770	31.439	3.2258	0.0000	0.0000	121.26	3.6704	0.0000	0.0000
21:03	16.808	31.335	2.8750	0.0000	0.0000	118.21	3.4608	0.0000	0.0000
21:03	16.838	31.192	3.0547	0.0000	0.0000	118.33	3.4243	0.0000	0.0000
21:04	16.855	31.335	3.0153	0.0000	0.0000	114.71	3.4110	0.0000	0.0000
21:04	17.039	31.079	2.8125	0.0000	0.0000	110.83	3.3353	0.0000	0.0000
21:05	17.192	30.877	2.8137	0.0000	0.0000	103.59	3.2144	0.0000	0.0000
21:05	17.229	30.721	2.8455	0.0000	0.0000	105.85	3.1745	0.0000	0.0000
21:05	17.288	30.557	2.7054	0.0000	0.0000	103.82	3.1575	4.1515	0.0000
21:07	17.187	30.557	2.8385	0.0000	0.0000	95.151	3.2277	0.0000	0.0000
21:07	17.388	30.870	2.6512	0.0000	0.0000	100.35	3.0551	0.0000	0.0000
21:08	17.485	30.455	2.6823	0.0000	0.0000	95.457	2.8701	0.0000	0.0000
21:08	17.451	30.158	2.6867	0.0000	0.0000	95.857	2.8727	0.0000	0.0000
21:08	17.483	30.414	2.6671	0.0000	0.0000	98.215	2.8541	0.0000	0.0000

7 MIN 16.

AVERAGE 16.941 30.855 3.1411 0.0000 0.0000 108.10 3.4205 0.0000 0.0000

33.888 3.1411

STACK NO. 1
POINT NO. 4

8103

W

TIME	O2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AMP	STEAM
24 HR.	%	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	%	°F	LB/HR
21:10	17.388	28.853	2.8100	0.0000	0.0000	101.05	3.0524	0.0000	0.0000
21:11	16.770	27.602	1.9741	0.0000	0.0000	107.07	3.0184	0.0000	0.0000
21:11	16.535	24.701	3.0418	0.0000	0.0000	101.18	3.0303	0.0000	0.0000
21:12	16.815	26.640	3.0043	0.0000	0.0000	100.70	3.0000	0.0000	0.0000
21:12	16.858	22.882	4.0877	0.0000	0.0000	105.82	4.2537	0.0000	0.0000
21:13	16.842	22.628	4.1858	0.0000	0.0000	105.85	4.3725	0.0000	0.0000
21:13	16.828	22.635	4.1457	0.0000	0.0000	107.57	4.2883	0.0000	0.0000
21:14	16.882	23.804	4.1515	0.0000	0.0000	105.07	4.3351	0.0000	0.0000
21:14	16.882	23.811	4.0434	0.0000	0.0000	105.82	4.3351	0.0000	0.0000
21:15	16.882	23.808	3.8855	0.0000	0.0000	100.70	4.2345	0.0000	0.0000
21:15	16.854	23.808	4.1555	0.0000	0.0000	104.32	4.3540	0.0000	0.0000
21:15	16.848	23.852	4.1512	0.0000	0.0000	102.20	4.3700	0.0000	0.0000
21:15	16.878	24.055	4.1515	0.0000	0.0000	105.55	4.3434	0.0000	0.0000
21:17	16.852	23.852	4.0878	0.0000	0.0000	102.85	4.3547	0.0000	0.0000

7 MIN

AVERAGE 16.838 24.338 3.8000 0.0000 0.0000 105.78 4.3352 0.0000 0.0000

7103

15.783

32.434 3.924

STACK NO. 1
POINT NO. 6

8103

E

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	X.D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	X.D	°F	LB/HR
21:18	15.878	23.882	4.0237	0.0000	0.0000	132.83	4.2558	0.0000	0.0000
21:18	15.936	24.115	4.0434	0.0000	0.0000	131.52	4.2828	0.0000	0.0000
21:18	15.957	24.218	4.1221	0.0000	0.0000	134.57	4.3514	0.0000	0.0000
21:18	15.728	24.625	4.2500	0.0000	0.0000	141.70	4.4708	0.0000	0.0000
21:20	15.874	24.833	4.2746	0.0000	0.0000	144.85	4.5187	0.0000	0.0000
21:20	15.728	24.835	4.2845	0.0000	0.0000	145.85	4.4708	0.0000	0.0000
21:21	15.781	25.148	4.3581	0.0000	0.0000	147.82	4.4848	0.0000	0.0000
21:21	15.854	25.148	4.3148	0.0000	0.0000	153.18	4.5287	0.0000	0.0000
21:22	15.717	25.265	4.3385	0.0000	0.0000	154.55	4.4815	0.0000	0.0000
21:22	15.843	25.545	4.2555	0.0000	0.0000	154.87	4.5453	0.0000	0.0000
21:23	15.887	25.703	4.4577	0.0000	0.0000	155.57	4.5831	0.0000	0.0000
21:23	15.554	25.851	4.4874	0.0000	0.0000	151.57	4.5223	0.0000	0.0000
21:24	15.443	25.471	4.3305	0.0000	0.0000	152.55	4.7188	0.0000	0.0000
21:24	15.455	25.925	4.4517	0.0000	0.0000	171.31	4.7073	0.0000	0.0000

7 MIN
AVERAGE 15.881 25.188 4.2732 0.0000 0.0000 148.85 4.5035 0.0000 0.0000

STACK NO. 1
POINT NO. 6

8103

TIME	SO2	SO2 #1	SO2 #2	NOX	NOX150	CO	CO2	I-AME	STEAM
24 HR.	X.D	PPM.D	PPM.D	PPM.D	PPM.D	PPM.D	X.D	°F	LB/HR
21:25	15.354	27.288	4.5285	0.0000	0.0000	152.85	4.7558	0.0000	0.0000
21:25	15.485	27.341	4.5845	0.0000	0.0000	154.31	4.7488	0.0000	0.0000
21:27	15.342	27.751	4.5188	0.0000	0.0000	155.55	4.8055	0.0000	0.0000
21:27	15.375	27.855	4.5553	0.0000	0.0000	155.53	4.7754	0.0000	0.0000
21:28	15.358	28.253	4.5528	0.0000	0.0000	157.53	4.7517	0.0000	0.0000
21:28	15.385	28.522	4.4811	0.0000	0.0000	155.73	4.8375	0.0000	0.0000
21:28	15.333	28.575	4.5157	0.0000	0.0000	151.53	4.8135	0.0000	0.0000
21:29	15.351	28.134	4.5747	0.0000	0.0000	152.53	4.7577	0.0000	0.0000
21:30	15.358	28.338	4.4458	0.0000	0.0000	152.43	4.7517	0.0000	0.0000
21:30	15.532	28.447	4.5537	0.0000	0.0000	55.255	4.8555	0.0000	0.0000
21:31	17.308	28.355	3.1531	0.0000	0.0000	175.57	3.1855	0.0000	0.0000
21:31	15.328	28.115	4.4515	0.0000	0.0000	157.15	4.8242	0.0000	0.0000
21:32	15.225	28.325	4.5542	0.0000	0.0000	200.35	4.8535	0.0000	0.0000
21:32	15.157	28.522	3.5551	0.0000	0.0000	122.55	4.8575	0.0000	0.0000

7 MIN
AVERAGE 15.784 27.685 4.1341 0.0000 0.0000 172.23 4.4822 0.0000 0.0000

8103 16.581 39.828 4.255

4.4.3

Drift Records for CEM Tests

The Emission Measurement Group, Inc.

Percent Cal Drift of Runs

Holly Sugar Corporation

Pulp Dryers

10/19-10/23/93

Runs	Pollutant SPAN =	O2 25	Pre-Cal	Post-Cal	Difference	%Drift
5101	ZERO UPSCALE		0.099 10.539	0.099 10.616	0.000 0.077	0.00 0.31
5102	ZERO UPSCALE		0.108 7.110	0.129 7.106	0.021 -0.004	0.09 -0.02
5103	ZERO UPSCALE		0.129 7.106	0.098 7.130	-0.031 0.025	-0.12 0.10
5104	ZERO UPSCALE		0.098 7.130	0.157 7.121	0.058 -0.009	0.23 -0.04
6101	ZERO UPSCALE		0.099 10.539	0.099 10.616	0.000 0.077	0.00 0.31
6102	ZERO UPSCALE		0.108 7.110	0.129 7.106	0.021 -0.004	0.09 -0.02
6103	ZERO UPSCALE		0.129 7.106	0.098 7.130	-0.031 0.025	-0.12 0.10
6104	ZERO UPSCALE		0.098 7.130	0.157 7.121	0.058 -0.009	0.23 -0.04
7101	ZERO UPSCALE		0.092 7.112	0.081 7.064	-0.011 -0.048	-0.04 -0.19
7102	ZERO UPSCALE		0.081 7.064	0.136 7.079	0.055 0.015	0.22 0.06
7103	ZERO UPSCALE		0.136 7.079	0.102 7.019	-0.034 -0.060	-0.14 -0.24
8101	ZERO UPSCALE		0.092 7.112	0.081 7.064	-0.011 -0.048	-0.04 -0.19
8102	ZERO UPSCALE		0.081 7.064	0.136 7.079	0.055 0.015	0.22 0.06
8103	ZERO UPSCALE		0.136 7.079	0.102 7.019	-0.034 -0.060	-0.14 -0.24

The Emission Measurement Group, Inc.

Percent Cal Drift of Runs

Holly Sugar Corporation

Pulp Dryers

10/19-10/23/93

Runs	Pollutant SPAN =	CO2 15	Pre-Cal	Post-Cal	Difference	%Drift
5101	ZERO UPSCALE		0.010 14.413	-0.044 14.389	-0.054 -0.024	-0.36 -0.16
5102	ZERO UPSCALE		0.010 11.933	0.054 11.874	0.044 -0.059	0.29 -0.39
5103	ZERO UPSCALE		0.054 11.874	0.089 11.746	0.034 -0.128	0.23 -0.85
5104	ZERO UPSCALE		0.089 11.746	0.138 11.885	0.049 0.139	0.33 0.93
6101	ZERO UPSCALE		0.010 14.413	-0.044 14.389	-0.054 -0.024	-0.36 -0.16
6102	ZERO UPSCALE		0.010 11.933	0.054 11.874	0.044 -0.059	0.29 -0.39
6103	ZERO UPSCALE		0.054 11.874	0.089 11.746	0.034 -0.128	0.23 -0.85
6104	ZERO UPSCALE		0.089 11.746	0.138 11.885	0.049 0.139	0.33 0.93
7101	ZERO UPSCALE		-0.058 11.840	-0.018 11.840	0.040 0.000	0.27 0.00
7102	ZERO UPSCALE		-0.018 11.840	-0.018 11.888	0.000 0.048	0.00 0.32
7103	ZERO UPSCALE		-0.018 11.888	0.002 12.010	0.020 0.122	0.13 0.81
8101	ZERO UPSCALE		-0.058 11.840	-0.018 11.840	0.040 0.000	0.27 0.00
8102	ZERO UPSCALE		-0.018 11.840	-0.018 11.888	0.000 0.048	0.00 0.32
8103	ZERO UPSCALE		-0.018 11.888	0.002 12.010	0.020 0.122	0.13 0.81

The Emission Measurement Group, Inc.

Percent Cal Drift of Runs

Holly Sugar Corporation

Pulp Dryers

10/19-10/23/93

Runs	Pollutant SPAN =	SO2 100	Pre-Cal	Post-Cal	Difference	%Drift
5101	ZERO UPSCALE		-0.670 49.461	-1.220 48.437	-0.550 -1.024	-0.55 -1.02
5102	ZERO UPSCALE		-0.204 101.120	0.102 98.615	0.306 -2.505	0.31 -2.51
5103	ZERO UPSCALE		0.102 98.615	1.075 97.386	0.973 -1.229	0.97 -1.23
5104	ZERO UPSCALE		1.075 97.386	-0.921 96.720	-1.996 -0.666	-2.00 -0.67
6101	ZERO UPSCALE		-0.670 49.461	-1.220 48.437	-0.550 -1.024	-0.55 -1.02
6102	ZERO UPSCALE		-0.204 101.120	0.102 98.615	0.306 -2.505	0.31 -2.51
6103	ZERO UPSCALE		0.102 98.615	1.075 97.386	0.973 -1.229	0.97 -1.23
6104	ZERO UPSCALE		1.075 97.386	-0.921 96.720	-1.996 -0.666	-2.00 -0.67
7101	ZERO UPSCALE		-1.481 98.826	-0.402 97.439	1.079 -1.387	1.08 -1.39
7102	ZERO UPSCALE		-0.402 97.439	1.020 98.382	1.422 0.943	1.42 0.94
7103	ZERO UPSCALE		1.020 98.382	0.683 98.001	-0.337 -0.381	-0.34 -0.38
8101	ZERO UPSCALE		-1.481 98.826	-0.402 97.439	1.079 -1.387	1.08 -1.39
8102	ZERO UPSCALE		-0.402 97.439	1.020 98.382	1.422 0.943	1.42 0.94
8103	ZERO UPSCALE		1.020 98.382	0.683 98.001	-0.337 -0.381	-0.34 -0.38

Appendix 4.5

CALCULATIONS AND COMPUTER PRINTOUTS

Constant of 17.64 = $T_1/P_1 = (68^\circ\text{F} + 459.7^\circ\text{R})/29.92 \text{ in. Hg.}$	
Standard Conditions = 68°F and 29.92 " Hg.	
Conv. Factors: 15.4322 gr./gm., 453.597 gm./lb., 7000 gr./lb.	
P_1	= Barometric Pressure, in. Hg Absolute
ϕH	= Average Gas Meter Pressure, in. w.g.
Y_1	= Gas Meter Calibration Factor, dimensionless
V_1	= Volume of Dry Gas Sampled, @ Meter Conditions, ft ³
T_1	= Average Gas Meter Temperature, (°F + 459.7°R)
V_{1st}	= $(V_1) (Y_1) (17.74) (P_1 + \phi H / 13.5962) / T_1$ = Volume of Meter @ Standard Condition
V_{1c}	= Total H ₂ O Collected, Impingers plus Silica Gel, ml. or grams
T_1	= (°F + 459.7°R) = Average Stack Temperature
$V_{1(120)}$	= Condensate Volume, Net, @ Impingers, ml.
$V_{1(160)}$	= Weight of Water @ Silica Gel, gm.
V_{1st}	= $0.04707 (V_{1(120)}) + 0.04715 (V_{1(160)})$
B_{1c}	= $(V_{1st}) / (V_{1st} + V_{1(160)})$
$\phi P_1^{1/2}$	= Average of Square Roots of Velocity Heads

The Emission Measurement People, Inc.

SOURCE TESTING CALCULATIONS - continued

Page 2

d_n	= Diameter of Nozzle, in.
A_n	= $d_n^2 / 183.3465$ = Area of Nozzle, ft^2
% CO_2	= Carbon Dioxide, dry, (v/v)
% O_2	= Oxygen, dry, (v/v)
% SO_2	= Sulfur Dioxide, dry, (v/v) = (ppm $\times 10^{-4}$)
% N_2	= Nitrogen, by Difference from 100%
MW_i	= $(0.4401 \times \% CO_2) + (0.320 \times \% O_2) + (0.6407 \times \% SO_2) + (0.29014 \times \% N_2)$
MW_s	= $(MW_i) (1 - B_{ps}) + 18.016 (B_{ps})$ = Molecular Weight of Stack Gas, Actual
P_{ps}	= Stack Static Pressure, in. w.g.
P_s	= $(P_s) + (P_{ps} / 13.5962)$ = Stack Pressure, in. Hg, Absolute
C_p	= Pitot Tube Coefficient, Dimensionless
V_s	= $85.49 (CF) [(T_s / (P_s) MW_s) (\phi P_s)]^{1/2}$ = Velocity of Stack Gases, fps
θ	= Time of Test, min. (also T_s)

4.5.3

$\% I$	- $\% \text{ Isokinetic Sampling Rate}$ $100 T_1 [(0.002669 (V_{1s})) + ((Y_1) (V_{1s}) (P_1 / T_1))] / [(0) (V_1 (P_1) (A_1) 60)]$
I_1	- $T_1 [(0.09450 (T_1) V_{1s})] / [P_1 V_1 A_1 0 (1 - B_{1s})]$ - Intermediate Values for Isokinetic
D	- Stack Diameter , ft.
A_1	- $0.7854 D$ - Stack Area, ft^2
Q_1	- $(V_1) (A_1) (60)$ - Stack Volumetric Flowrate, Actual, ACFM
Q_s	- $(17.64) (Q_1) [(P_1) / (T_1)] (1 - B_{1s})$ - Stack Volumetric Flowrate, DSCFM
F_1	- P-Factor, dry @ O_2 % of 0.0, dscf / 10^6 BTU
$\% EA$	- $[(\% O_2) - (0.5) (\% CO)] / [(0.264) (\% N_2) - ((\% O_2) + (0.5) (\% CO))] (100)$ - $\% \text{ Excess Air in Duct (Combustion Source only)}$
F_2	- $(20.9 - \% O_2) / \% CO_2$ - Orsat QC Performance Check Factor, Dimensionless

The Emission Measurement People, Inc.

SOURCE TESTING CALCULATIONS - continued
Particulate Results

Page 4

m_1	- Partic. @ Nozzle, Probe, Cyclone (or Bypass Filter L) & Filter, mg.
m_2	- Particulate @ Total, mg (incl. Back Half)
C_{11}	- $[(m_1) (0.015432)] / V_{11}$ - Particulate @ Nozzle, Probe, Cyclone & Filter, gr./dscf
C_{12}	- $(m_2) (0.015432) / V_{12}$ - Particulate @ Total, gr./dscf
P_{11}	- $[(C_{11}) (Q_1) (60)] / 7000$ - Particulate @ Nozzle, Probe, Cyclone & Filter, lbs./hr.
P_{12}	- $[(C_{12}) (Q_1) (60)] / 7000$ - Particulate @ Total, lbs./hr.
E	- $\{(C_{11}) (F_1) [(20.9 / (20.9 - Q_1))]\} / 7000$ - Particulate @ Nozzle, Probe, Cyclone & Filter, lbs./10 ⁶ BTU

4.5.5

SOURCE TESTING CALCULATIONS - continued
Sulfur Dioxide Results

C_{11}	$= [(7.061 \times 10^{-4} (V_i - V_{11}) (N) (V_{111} / V_{1111}))] / V_{111}$ $= \text{SO}_2 \text{ Conc., lbs./dscf}$
C_{11}	$= [(1.081 \times 10^{-4} (V_i - V_{11}) (N) (V_{111} / V_{1111}))] / V_{111}$ $= \text{SO}_2 \text{ Conc., lbs./dscf}$
PPMD	$= \text{SO}_2 \text{ lbs./dscf } (2.59 \times 10^{-4}) (64.07)$
PPMW	$= \text{PPMD} \times (1.0 - B_{11})$

Appendix 4.6

Laboratory Analytical Results

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

BACKSIDE

Company Name: Hollis Water Density (gm/ml): 1.000
 Plant Name: Sidwell Mt Lab Conditions: _____
 Unit Name: Union Boiler - East Temp: _____
 Test Date: 10-21-03 Humidity: _____
 Analysts Sign.: Michael H. Bur Reviewer Sign.: _____

Sample Id./Run No.:	Blank	4101	4102	4103	4104
Beaker No.:	19	32 C ✓	49 ✓	55 ✓	43 ✓
Wash Volume (ml.):	250	197	270	265	523
Wt. of Water Wash (g):					
Tare Lab Book Page:	101.3676	B41	B41	B41	B43
1st Weight (g):	101.3675	99.2301	98.2438	99.1798	100.1424
2nd Weight (g):	101.36755	99.2302	98.2435	99.1794	100.1427
Average (g):		99.23015	98.24365	99.1796	100.14255
Final Lab Book Page:		B42	B42	B42	B44
1st Weight (g):	101.3712	99.2565	98.2739	99.2185	100.2161
2nd Weight (g):	101.3716	99.2561	98.2734	99.2184	100.2160
Average (g):	101.3714	99.2563	98.27565	99.21855	100.21605
Raw Net Wt. (mg):					
Blank Wt. (mg/g):					
Blank Correction (mg):					
Net Corrected Wt. (mg):	0	23.1162	27.8420	34.8690	65.4458

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.
Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: <u>Holly</u>	Acetone Density (gm/ml) <u>0.787</u>
Plant Name: <u>Sidney, MT</u>	Lab Conditions: _____
Unit Name: <u>Pulp Driver South-West</u>	Temp: _____
Test Date: <u>10-21-22-93</u>	Humidity: _____
Analysts Sign.: <u>Ellie Hall P. J. Big</u>	Reviewer Sign.: _____

Sample Id./Run No.:	Blank	MS <u>5101</u>	MS <u>5102</u>	PM-10 <u>5103</u>	PM-10 <u>5104</u>	PM-10 <u>5105</u>
---------------------	-------	----------------	----------------	-------------------	-------------------	------------------------------

Beaker No.:	_____	_____	_____	_____	_____
Wash Volume (ml.):	_____	_____	_____	_____	_____
Wt. of Acetone Wash (g):	_____	_____	_____	_____	_____

Tare Lab Book Page:	_____	_____	_____	_____	_____
1st Weight (g):	_____	_____	_____	_____	_____
2nd Weight (g):	_____	_____	_____	_____	_____
Average (g):	_____	_____	_____	_____	_____

Final Lab Book Page:	_____	_____	_____	_____	_____
1st Weight (g):	_____	_____	_____	_____	_____
2nd Weight (g):	_____	_____	_____	_____	_____
Average (g):	_____	_____	_____	_____	_____

Raw Net Wt. (mg):	_____	_____	_____	_____	_____
Blank Wt. (mg/g):	_____	_____	_____	_____	_____
Blank Correction (mg):	_____	_____	_____	_____	_____
Net Corrected Wt. (mg):	_____	_____	_____	_____	_____

Filter Id. No.:	7479	7482	7486	7487	_____
Tare Lab Book Page:	F11	F11	F11	F11	_____
1st Weight (g):	0.3377	0.3345	0.3371	0.3348	_____
2nd Weight (g):	0.3375	0.3346	0.3370	0.3346	_____
Average (g):	0.3376	0.33455	0.33705	0.3347	_____

Final Lab Book Page:	_____	_____	_____	_____	_____
1st Weight (g):	_____	_____	_____	_____	_____
2nd Weight (g):	_____	_____	_____	_____	_____
Average (g):	0.3546	0.4932	0.4583	0.3927	_____

Raw Net Wt. (mg):	_____	_____	_____	_____	_____
Blank Wt. (mg/g):	_____	_____	_____	_____	_____
Blank Correction (mg):	_____	_____	_____	_____	_____
Net Corrected Wt. (mg):	17.0	158.65	121.25	95.0	_____

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

FRONTSIDE - Cyclone

Company Name: Holly Acetone Density (gm/ml) 0.787
 Plant Name: Pulper Lab Conditions: _____
 Unit Name: Pulp Drier South-West Temp: _____
 Test Date: 10-21-22-93 Humidity: _____
 Analysts Sign.: Michael J. [Signature] Reviewer Sign.: _____

Sample Id./Run No.: Blank M5 PM-10 Cyclone
5101-5102 5103-5104 5103-5104

Beaker No.: 7 58 57
 Wash Volume (ml.): 430 425 173
 Wt. of Acetone Wash (g): _____

Tare Lab Book Page: B 37 B 45 B 45
 1st Weight (g): 102.5480 101.7765 101.7121
 2nd Weight (g): 102.5481 101.7763 101.7129
 Average (g): 102.54805 101.7764 101.7120

Final Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): 102.59435 102.0783 102.0767

Raw Net Wt. (mg): _____
 Blank Wt. (mg/g): _____
 Blank Correction (mg): _____
 Net Corrected Wt. (mg): 7.3296 38.4871 140.6791 160.7437
170.3051 194.5949 194.5949 194.5949

0.159976
 .84002
 .46671728
 .5332827

Filter Id. No.: _____
 Tare Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): _____

Final Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): _____

Raw Net Wt. (mg): _____
 Blank Wt. (mg/g): _____
 Blank Correction (mg): _____
 Net Corrected Wt. (mg): _____

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g. for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

BACKSIDE

Company Name:	<u>Holly</u>	Water Density (gm/ml):	<u>1.000</u>
Plant Name:	<u>5-Hwy. mt</u>	Lab Conditions:	
Unit Name:	<u>Pulp Drier - South-West</u>	Temp:	
Test Date:	<u>10-(21-22)-93</u>	Humidity:	
Analysts Sign.:	<u>Michael J. King</u>	Reviewer Sign.:	

Sample Id./Run No.:	Blank	<u>5101</u>	<u>5102</u>	<u>5103</u>	<u>5104</u>
Beaker No.:		<u>33 ✓</u>	<u>61 ✓</u>	<u>44 ✓</u>	<u>27 ✓</u>
Wash Volume (ml.):		<u>310 ✓</u>	<u>860 ✓</u>	<u>845 ✓</u>	<u>790 ✓</u>
Wt. of Water Wash (g):					
Tare Lab Book Page:		<u>B41</u>	<u>B41</u>	<u>B43</u>	<u>B43</u>
1st Weight (g):		<u>101.0701</u>	<u>106.2127</u>	<u>102.6575</u>	<u>98.6253</u>
2nd Weight (g):		<u>101.0789</u>	<u>106.2127</u>	<u>102.6577</u>	<u>98.6258</u>
Average (g):		<u>101.0395</u>	<u>106.2127</u>	<u>102.6576</u>	<u>98.6255</u>
Final Lab Book Page:		<u>B42</u>	<u>B42</u>	<u>B44</u>	<u>B44</u>
1st Weight (g):		<u>101.0891</u>	<u>106.2911</u>	<u>102.7534</u>	<u>98.7743</u>
2nd Weight (g):		<u>101.0889</u>	<u>106.2906</u>	<u>102.7536</u>	<u>98.7748</u>
Average (g):		<u>101.0890</u>	<u>106.29085</u>	<u>102.7535</u>	<u>98.77455</u>
Raw Net Wt. (mg):					
Blank Wt. (mg/g):					
Blank Correction (mg):					
Net Corrected Wt. (mg):	<u>0</u>	<u>47.624</u>	<u>74.194</u>	<u>920.3</u>	<u>142.336</u>

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: Holly Acetone Density (gm/ml) 0.787
 Plant Name: Sidney, MT Lab Conditions:
 Unit Name: Pulp Driller - South - East Temp: _____
 Test Date: 10-(21-22)-93 Humidity: _____
 Analysts Sign.: Michael J. Ray Reviewer Sign.: _____

Sample Id./Run No.:	Blank	<u>6101</u>	<u>6102</u>	<u>6103</u>	<u>6104</u>	<u>6102</u>
Beaker No.:						
Wash Volume (ml.):						
Wt. of Acetone Wash (g):						
Tare Lab Book Page:						
1st Weight (g):						
2nd Weight (g):						
Average (g):						
Final Lab Book Page:						
1st Weight (g):						
2nd Weight (g):						
Average (g):						
Raw Net Wt. (mg):						
Blank Wt. (mg/g):						
Blank Correction (mg):						
Net Corrected Wt. (mg):						
Filter Id. No.:		<u>7480</u>	<u>7481</u>	<u>7485</u>	<u>7488</u>	<u>7484 (Filter B)</u>
Tare Lab Book Page:		<u>F11</u>	<u>F11</u>	<u>F11</u>	<u>F11</u>	<u>F11</u>
1st Weight (g):		<u>0.3363</u>	<u>0.3355</u>	<u>0.3361</u>	<u>0.3354</u>	<u>0.3384</u>
2nd Weight (g):		<u>0.3362</u>	<u>0.3355</u>	<u>0.3360</u>	<u>0.3355</u>	<u>0.3384</u>
Average (g):		<u>0.33625</u>	<u>0.3355</u>	<u>0.33605</u>	<u>0.33545</u>	<u>0.3384</u>
Final Lab Book Page:						
1st Weight (g):						
2nd Weight (g):						
Average (g):		<u>0.35415</u>	<u>0.30325</u>	<u>0.38275</u>	<u>0.52025</u>	<u>0.37825</u>
Raw Net Wt. (mg):						
Blank Wt. (mg/g):						
Blank Correction (mg):						
Net Corrected Wt. (mg):		<u>17.9</u>	<u>57.85</u>	<u>46.7</u>	<u>187.8</u>	<u>311.85</u>

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: Hollv Acetone Density (gm/ml) 0.787
 Plant Name: St. Louis MO Lab Conditions: _____
 Unit Name: Pulp Dyer South-East Temp: _____
 Test Date: 10-21-22-93 Humidity: _____
 Analysts Sign.: Michael J. Ryan Reviewer Sign.: _____

Sample Id./Run No.:	Blank	PM-10 6101 → 6102	Cyclone 6101 → 6102	mg 6103 → 6104
Beaker No.:		59	45	39
Wash Volume (ml.):		540	542	362
Wt. of Acetone Wash (g):				
Tare Lab Book Page:		B45	B45	B45
1st Weight (g):		98.0159	102.4930	98.5653
2nd Weight (g):		98.0156	102.4927	98.5650
Average (g):		98.01575	102.49285	98.56515
Final Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):		98.1538	102.7342	98.7756
Raw Net Wt. (mg):		19.7986	117.6439	76.822
Blank Wt. (mg/g):		36.119	217.6243	
Blank Correction (mg):				
Net Corrected Wt. (mg):				
Filter Id. No.:				
Tare Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):				
Final Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):				
Raw Net Wt. (mg):				
Blank Wt. (mg/g):				
Blank Correction (mg):				
Net Corrected Wt. (mg):				

6101 144049
 6102 185596
 6103 3657438
 6104 6342562

PM-10
cyclone

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g. for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

BACKSIDE

Company Name:	<u>Holly</u>	Water Density (gm/ml):	<u>1.000</u>
Plant Name:	<u>Sidwell Mt</u>	Lab Conditions:	
Unit Name:	<u>Pulp Dryer South-East</u>	Temp:	
Test Date:	<u>10-21-23-83</u>	Humidity:	
Analysts Sign.:	<u>Michael P. H.</u>	Reviewer Sign.:	

Sample Id./Run No.:	Blank	<u>6101</u>	<u>6102</u>	<u>6103</u>	<u>6104</u>
Beaker No.:		<u>26</u>	<u>32</u>	<u>31</u>	<u>42</u>
Wash Volume (ml.):		<u>500</u>	<u>323</u>	<u>1055</u>	<u>411</u>
Wt. of Water Wash (g):					
Tare Lab Book Page:		<u>B43</u>	<u>B43</u>	<u>B43</u>	<u>B43</u>
1st Weight (g):		<u>99.1374</u>	<u>98.3063</u>	<u>100.3914</u>	<u>101.7825</u>
2nd Weight (g):		<u>99.1334</u>	<u>98.3067</u>	<u>100.3915</u>	<u>101.7828</u>
Average (g):		<u>99.1374</u>	<u>98.3065</u>	<u>100.39145</u>	<u>101.78265</u>
Final Lab Book Page:		<u>B44</u>	<u>B44</u>	<u>B44</u>	<u>B44</u>
1st Weight (g):		<u>99.1397</u>	<u>98.3236</u>	<u>100.6850</u>	<u>101.8519</u>
2nd Weight (g):		<u>99.1397</u>	<u>98.3235</u>	<u>100.6855</u>	<u>101.8517</u>
Average (g):		<u>99.1397</u>	<u>98.32355</u>	<u>100.68255</u>	<u>101.8518</u>
Raw Net Wt. (mg):					
Blank Wt. (mg/g):					
Blank Correction (mg):					
Net Corrected Wt. (mg):		<u>0</u>	<u>15.6642</u>	<u>286.247</u>	<u>67.2594</u>

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.
Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: <u>Hollv</u>	Acetone Density (gm/ml) <u>0.787</u>
Plant Name: <u>Richard W. T.</u>	Lab Conditions:
Unit Name: <u>Pulp Dryer North-West</u>	Temp: _____
Test Date: _____	Humidity: _____
Analysts Sign.: _____	Reviewer Sign.: _____

Sample Id./Run No.:	Reagent Acetone	M5	Residual Blank PM10	Cyclone
	Blank	7101	Acetone 7102 → 7103	7102 → 7103

Beaker No.:	2c	60	2a	18
Wash Volume (ml.):	445	590	500	203
Wt. of Acetone Wash (g):				

Tare Lab Book Page:	B-45 337 Jf	B45	B45	
1st Weight (g):	103.6196	96.4944	101.4980	
2nd Weight (g):	101.6684	96.4942	101.4979	
Average (g):	102.6035	96.4943	101.49795	105.70265
	101.49745			

Final Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):	101.49795	96.55135	101.61820	105.9220

Raw Net Wt. (mg):				
Blank Wt. (mg/g):				
Blank Correction (mg):				
Net Corrected Wt. (mg):			116.3911	113.3208

Filter Id. No.:				
Tare Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):				

Final Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):				

Raw Net Wt. (mg):				
Blank Wt. (mg/g):				
Blank Correction (mg):				
Net Corrected Wt. (mg):				

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: Holly Acetone Density (gm/ml) 0.787
 Plant Name: Sidney, MT Lab Conditions: _____
 Unit Name: Pulp Dryer - North-West Temp: _____
 Test Date: 10-23-93 Humidity: _____
 Analysts Sign.: Michael J. [Signature] Reviewer Sign.: _____

Sample Id./Run No.: Blank 7101 7102 7103

Beaker No.: _____
 Wash Volume (ml.): _____
 Wt. of Acetone Wash (g): _____

Tare Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): _____

Final Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): _____

Raw Net Wt. (mg): _____
 Blank Wt. (mg/g): _____
 Blank Correction (mg): _____
 Net Corrected Wt. (mg): 62.3871 60.244 55.9442

Filter Id. No.: 7493 7489 7496
 Tare Lab Book Page: F13 F11 F13
 1st Weight (g): 0.3341 0.3337 0.3356
 2nd Weight (g): 0.3341 0.3338 0.3354
 Average (g): 0.3341 0.33375 0.3355

Final Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): 38775 37920 38910

Raw Net Wt. (mg): _____
 Blank Wt. (mg/g): _____
 Blank Correction (mg): _____
 Net Corrected Wt. (mg): 57.65 45.45 53.6

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

BACKSIDE

Company Name:	<u>Holly</u>	Water Density (gm/ml):	<u>1.000</u>
Plant Name:	<u>Sidney, MT</u>	Lab Conditions:	
Unit Name:	<u>Pulp Dyer - North-West</u>	Temp:	
Test Date:	<u>10-23-93</u>	Humidity:	
Analysts Sign.:	<u>Michael J. Ry</u>	Reviewer Sign.:	

Sample Id./Run No.:	Blank	<u>7101</u>	<u>7102</u>	<u>7103</u>
Beaker No.:		<u>46</u>	<u>20</u>	<u>660 35</u>
Wash Volume (ml.):		<u>590</u>	<u>750</u>	<u>35 680</u>
Wt. of Water Wash (g):				
Tare Lab Book Page:		<u>B43</u>	<u>B39</u>	<u>B43</u>
1st Weight (g):		<u>98.7023</u>	<u>105.2440</u>	<u>99.1136</u>
2nd Weight (g):		<u>98.6998</u>	<u>105.2441</u>	<u>99.1139</u>
Average (g):		<u>98.70005</u>	<u>105.24405</u>	<u>99.11375</u>
Final Lab Book Page:		<u>B44</u>	<u>B40</u>	<u>B44</u>
1st Weight (g):		<u>98.8168</u>	<u>105.3158</u>	<u>99.1625</u>
2nd Weight (g):		<u>98.8170</u>	<u>105.3162</u>	<u>99.1625</u>
Average (g):		<u>98.8169</u>	<u>105.3160</u>	<u>99.1625</u>
Raw Net Wt. (mg):				
Blank Wt. (mg/g):				
Blank Correction (mg):				
Net Corrected Wt. (mg):	<u>0</u>	<u>14.136</u>	<u>68.5</u>	<u>45.622</u>

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g.) for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: Holly Acetone Density (gm/ml) 0.787
 Plant Name: Sidney, MT Lab Conditions: _____
 Unit Name: Pulp Drier - North-East Temp: _____
 Test Date: 11-23-93 Humidity: _____
 Analysts Sign.: Michael Thompson Reviewer Sign.: _____

Sample Id./Run No.: Blank 8101 8102 8103
10-23

Beaker No.: _____
 Wash Volume (ml.): _____
 Wt. of Acetone Wash (g): _____

Tare Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): _____

Final Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): _____

Raw Net Wt. (mg): _____
 Blank Wt. (mg/g): _____
 Blank Correction (mg): _____
 Net Corrected Wt. (mg): _____

Filter Id. No.: 7492 7490 7497
 Tare Lab Book Page: F13 F13 F13
 1st Weight (g): 0.3341 0.3342 0.3342
 2nd Weight (g): 0.3341 0.3342 0.3343
 Average (g): 0.3341 0.3342 0.33425

Final Lab Book Page: _____
 1st Weight (g): _____
 2nd Weight (g): _____
 Average (g): 0.3939 0.4451 0.51065
0.51065

Raw Net Wt. (mg): _____
 Blank Wt. (mg/g): _____
 Blank Correction (mg): _____
 Net Corrected Wt. (mg): _____

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g. for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

FRONTSIDE

Company Name: Hollv Acetone Density (gm/ml) 0.787
 Plant Name: Sidney Mt Lab Conditions: _____
 Unit Name: Pulp Drier North-East Temp: _____
 Test Date: 10-23-93 Humidity: _____
 Analysis Sign.: Michael J Ry Reviewer Sign.: _____

	Blank	PM10	Cyclone	MS
Sample Id./Run No.:		<u>8101</u>	<u>8101</u>	<u>8102 → 8103</u>
Beaker No.:		<u>17</u>	<u>36</u>	<u>34</u>
Wash Volume (ml.):		<u>552</u>	<u>288</u>	<u>535</u>
Wt. of Acetone Wash (g):				
Tare Lab Book Page:		<u>B45</u>	<u>B45</u>	
1st Weight (g):		<u>98.7745</u>	<u>104.7690</u>	
2nd Weight (g):		<u>98.7742</u>	<u>104.7678</u>	
Average (g):		<u>98.77435</u>	<u>104.7679</u>	<u>106.43345</u>
Final Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):		<u>98.8308</u>	<u>104.8367</u>	<u>106.5062</u>
Raw Net Wt. (mg):				
Blank Wt. (mg/g):				
Blank Correction (mg):				
Net Corrected Wt. (mg):				
Filter Id. No.:				
Tare Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):				
Final Lab Book Page:				
1st Weight (g):				
2nd Weight (g):				
Average (g):				
Raw Net Wt. (mg):				
Blank Wt. (mg/g):				
Blank Correction (mg):				
Net Corrected Wt. (mg):				

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g. for each weighing.

The Emission Measurement Group, Inc.

Particulate Lab Analytical Data Entry Sheet

BACKSIDE

Company Name: Holler Water Density (gm/ml): 1.000
 Plant Name: S. du... MT Lab Conditions: _____
 Unit Name: Pulp Drier North-East Temp: _____
 Test Date: 10-23-93 Humidity: _____
 Analysts Sign.: Michael J. Ray Reviewer Sign.: _____

Sample Id./Run No.:	Blank	8101	8102	8103	Post Test Dynamic Blank H ₂ O
Beaker No.:		29	14	3	1a + 15a
Wash Volume (ml.):		935	725	830	450
Wt. of Water Wash (g):					
Tare Lab Book Page:		B43	B37	B37	B45
1st Weight (g):		98.2279	105.1454	103.6086	100.2125
2nd Weight (g):		98.2281	105.1457	103.6084	100.2127
Average (g):		98.2280	105.1455	103.6085	100.2126
Final Lab Book Page:		B44	B38	B38	B46
1st Weight (g):		98.3127	105.1697	103.6948	100.2120
2nd Weight (g):		98.3123	105.1693	103.6944	100.2123
Average (g):		98.3125	105.1695	103.6946	100.21215
Raw Net Wt. (mg):					
Blank Wt. (mg/g):					
Blank Correction (mg):					
Net Corrected Wt. (mg):					

Balance pre and post calibrations at 100.0008 g. (internal weight) +/- 0.0001g. for each weighing.