

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 10.6.1

Background Report Section: 4

Reference Number: 12

**Title: Report of Evaluation Emission
Testing on the Chip Dryer Inlet
and Outlet at Georgia-Pacific
Corp. In Woodland Maine on
October 25, 1988**

Analytical Testing Consultants, Inc

November 1988

Anal. Testing Consultants, Inc.
(1988)

See pp. 4, 11, 21

Ref (12)

Ref 12
Sec 4

REPORT

of

EVALUATION EMISSION TESTING

on the

CHIP DRYER INLET AND OUTLET

at

GEORGIA PACIFIC CORPORATION

in

WOODLAND, MAINE

on

OCTOBER 25, 1988

TEST REPORT #4829

ANALYTICAL TESTING CONSULTANTS, INC.

506 Broad Street
Kannapolis, N. C. 28081
(704) 932-3193

P. O. Box 767190
Roswell, Georgia 30076
(404) 587-5696

Prepared by:
cc

Distribution:
Mr. Larson Harsey
(5 copies)

Issue Date:
November 18, 1988

✓
on the report

TABLE OF CONTENTS

Introduction

Source Description

Diagram

Results Summary

Efficiency Summary

Results, Conclusions, and Comments

Sampling and Analytical Procedures

Calculations

Data Sheets

INTRODUCTION

This report presents the results of evaluation emission testing performed on the chip dryer inlet and outlet at Georgia Pacific Corporation in Woodland, Maine on October 25, 1988.

The purpose of this test was to determine efficiency of the United McGill ESP which operates on the outlet side of the chip dryer. Testing was performed by EPA Method 5 for particulate and EPA 25 for total volatile organic compounds (non-methane). Additional testing for back half condensibles and formaldehyde were sampled for at the same time as the Method 5.


The test was conducted by ANALYTICAL TESTING CONSULTANTS, INC. Kannapolis, N. C. Members of the test team were Charles Wilkes, Richard Westbrook, Keith Poole and Dan McCombs.

SOURCE DESCRIPTION

This test was performed at the oriented Strand Board Plant operated by Georgia-Pacific located in Woodland, Maine. Oriented Strand Board (OSB) is manufactured by a process that yields plywood strength properties while using wood flakes. This process orients the wood flakes basically in two directions.

There are two wood fired dryers at the Georgia-Pacific OSB Plant, which are used to dry green wood flakes (50% moisture content, wet basis) for use in OSB production. The dryers are direct-fired, triple pass, rotary drum dryers, each equipped with its own sanderdust suspension burner. The dryers are identified as being either the "Surface" or "Core" dryer. "Surface" flakes refers to the flakes used on the outside or surface of the manufactured board and which are dried to approximately 8% moisture content. "Core" flakes are dried to a moisture content of approximately 5% and are oriented 90 degrees from the surface flake layer. Flue gases and dry wood flakes are pneumatically conveyed from each dryer to its own individual high efficiency cyclone and I.D. Fan, then to a common duct which leads to a pre-quench chamber which knocks out large flakes and/or wood fibers and also saturates and cools the incoming gas stream in order to condense any organic compounds present. The saturated gas stream passes through a United McGill three field wet electrostatic precipitator and stack to the atmosphere.

During this testing, the both dryers operated at approximately 20 tons which is capacity for the system.



Woodland, ME OSB - Flow Diagram

RESULTS SUMMARY

SYSTEM GEORGIA PACIFIC
 CHIP DRYER EXHAUST
 WOODLAND, MAINE

TEST DATE OCTOBER 25, 1988

PARAMETER	RUN #1-O	RUN #2-O	RUN #3-O	AVERAGE
Qs, FLOW, ACFM	87660.7	83307.7	83186.0	84718.14
Qs dry, FLOW SCFM	56278.9	52692.9	54024.9	54332.2
Vm std, CUBIC FT.	44.12	41.84	42.62	
%I	108.1	109.5	105.7	
PMR AVG, LB/HR DRY CATCH	3.65	3.70	4.31	3.88
DRY AND WET	6.45	6.68	7.65	6.93
Cs, GR/SCF DRY CATCH	.0073	.0078	.0090	.0080
DRY AND WET	0.0128	0.0141	0.0160	0.0143
ALLOWABLE, LB/HR (DRY CATCH ONLY)				8.6*
TGNMO LB/HR	37.99	18.77	19.25	
FORMALDEHYDE LB/HR	.0596	.0495	.0490	.0527

*based on limiting total waferboard plant particulate emissions to 50 Tons/Year or less, and deducting other waferboard plant emissions

RESULTS SUMMARY

SYSTEM GEORGIA PACIFIC
 CHIP DRYER INLET
 WOODLAND, MAINE

TEST DATE OCTOBER 25, 1988

PARAMETER	RUN 1-I	RUN 2-1	RUN 3-I	AVERAGE
Qs, FLOW, ACFM	88135	88387	86270	87597
Qs dry. FLOW SCFM	62735	60425	59797	60986
Vm std, CUBIC FT.	24.01	14.99	15.01	
%I	122.2	110.2	110.3	
PMR AVG, LB/HR DRY CATCH	80.27	54.36	55.95	63.53
DRY AND WET	189.80	126.38	142.73	152.97
Cs, GR.SCF DRY CATCH	0.134	0.0998	0.1038	0.1126
DRY AND WET	0.317	0.232	0.265	0.271
TGNMO LB/HR	83.52	143.21	60.99	
FORMALDEHYDE LB/HR	.1084	.0978	.1294	.1118

RESULTS SUMMARY

SYSTEM	GEORGIA PACIFIC CHIP DRYER EXHAUST WOODLAND, MAINE	
TEST DATE	OCTOBER 25, 1988	
PARAMETER	RUN 4-I	RUN 4-O
Qs, FLOW, ACFM	92199	80824
Qs dry, FLOW SCFM	69788	58344
Vm std, CUBIC FT.	7.81	15.69
%I	107.8	108.9
PMR AVG, LB/HR		
DRY CATCH	78.28	5.86
DRY AND WET	118.17	7.968
Cs, GR/SCF		
DRY CATCH	0.126	0.011
DRY AND WET	0.190	0.015
FORMALDEHYDE LB/HR	.0817	.0931

EFFICIENCY SUMMARY

RUN #	TGMNO lb/hr	FORMALDEHYDE lb/hr	DRY CATCH lb/hr	DRY/WET COMB. lb/hr
1-I	83.52	.1192	80.27	189.81
2-I	143.21	.1026	54.36	126.38
3-I	60.99	.1357	55.95	142.73
4-I	--	.0817	78.28	118.17
1-0	37.99	.0596	3.65	6.45
2-0	18.77	.0495	3.70	6.68
3-0	19.25	.0490	4.31	7.65
4-0	--	.0931	5.86	7.97

EFFICIENCY

RUN #	%	%	%	%	
1	54.51	45.00	95.46	96.60	HIGH 97%
2	86.89	49.34	93.20	94.72	
3	68.45	62.14	92.30	94.64	
4	--		92.52	93.26	

RESULTS, CONCLUSIONS AND COMMENTS

Results of the particulate, formaldehyde and VOC emission testing are presented in the preceding Test Summaries. Additional information may be reviewed in the Calculations and Data Sheets sections of this report.

The average particulate emission concentration for the official part of this testing was 3.88 lb/hr. This is below the maximum allowable level of 8.6 lb/hr. The combined wet and dry catch numbers had to be adjusted for the chemical solution (Sodium Bisulfite) in the impingers for the formaldehyde collection.

The outlet runs 1-3 were 80 minutes in order to get a 10 minute wash cycle in each run. Since the port traverses took 20 minutes the wash was started five minutes into each run so it would not be taken place during a port change. Run 4 was setup to test an entire run without a wash, but only half a run could be made due to the plant running out of chips.

SAMPLING AND ANALYTICAL PROCEDURES

Particulate testing and analysis were performed according to procedures developed by the U. S. Environmental Protection Agency (EPA) and referred to as Method 5. Sampling port locations and number of test points to be used were determined according to Method 1. The above federal test methods appear in the Code of Federal Regulations (Reference 1).

Volatile organic compound testing and analysis were performed according to EPA method 25. The formaldehyde testing and analysis were performed, modified for large impingers, by method P&CAM 125.

Test point locations and sampling port placement for velocity traverses are shown in the data sheets. Test point locations were calculated based upon a 64" diameter stack for the outlet and 68" for the inlet.

Gas sampling and analysis for oxygen content was performed in accordance with EPA method 3A on the outlet and EPA method 3 on the inlet. Carbon dioxide concentrations were determined utilizing EPA method 3, Fyrite analyzer procedure.

REFERENCES

1. CODE OF FEDERAL REGULATIONS, Title 40, Part 60, Appendix A, July 1, 1986.

CALCULATIONS

Particulate Emission Rate Calculations
Formaldehyde Emission Rate Calculation
TGNMO Emission Rate Calculation
Square Root of DP
Nomenclature
Calculation Formulae

PARTICULATE EMISSION RATE CALCULATION
DRY CATCH ONLY

DATA/CALCULATION	RUN 1-0	RUN 2-0	RUN 3-0	AVERAGE
DATE	10/25/88	10/25/88	10/25/88	
AVG DH (IN H2O)	0.87	0.77	0.78	
P ATM (IN HG)	28.76	28.76	28.76	
PM (IN HG)	28.82397	28.81661	28.81735	
PS (GUAGE)	-1.1	-1.1	-1.1	
PS (IN HG)	28.67911	28.67911	28.67911	
tM (DEG F)	63	63	67	
TM (DEG R)	523	523	527	
VM (FT3)	44.12	41.84	42.62	
VM STD (FT3)	42.91014	40.68228	41.12721	
VLQ (ML)	278	280.2	255	
VV STD (FT3)	13.09870	13.20236	12.015	
V STD (FT3)	56.00884	53.88464	53.14221	
%M	23.38685	24.50116	22.60914	23.49905
MD	0.766131	0.754988	0.773908	
MWD	29.084	29.112	29.096	
M	26.49180	26.38943	26.58728	
tS (DEG F)	147	147	146	146.6666
TS (DEG R)	607	607	606	606.6666
SUM SQRT DP	20.39	19.34	19.4	
N DP	20	20	20	
AVG SQRT DP	1.0195	0.967	0.97	
CP	0.84	0.84	0.84	
VS (FT/SEC)	65.43147	62.18229	62.09146	63.23507
DS (IN)	64	64	64	
AS (FT2)	22.32888	22.32888	22.32888	
QS, ACFM	87660.73	83307.68	83186.00	84718.14
Q STD (FT3/MIN)	73458.58	69792.97	69807.82	71019.79
Q STD DRY, SCFM	56278.93	52692.88	54024.86	54332.22
WT (GM)	0.0202	0.0206	0.0241	
PMRC (LB/HR)	3.505073	3.529992	4.188334	3.741133
DN (IN)	0.19	0.19	0.192	
AN (IN2)	0.028338	0.028338	0.028938	
TIME (MIN)	80	80	80	
PMRA (LB/HR)	3.790303	3.865358	4.428375	4.028012
%I	108.1376	109.5004	105.7311	
PMR AVG (LB/HR)	3.647688	3.697675	4.308354	3.884572
%CO2	2.3	2.6	2.5	2.466666
%O2	17.9	17.4	17.4	17.56666
%CO	0	0	0	0
%N2	79.8	80	80.1	79.96666
%EA	565.1679	467.7419	464.4458	499.1185
CS (GR/SCFD)	0.007263	0.007813	0.009041	0.008039

PARTICULATE EMISSION RATE CALCULATION
DRY CATCH ONLY

DATA/CALCULATION	RUN 1-I	RUN 2-I	RUN 3-I	AVERAGE
DATE	10/25/88	10/25/88	10/25/88	
AVG DH (IN H2O)	0.84	0.19	0.32	
P ATM (IN HG)	28.76	28.76	28.76	
PM (IN HG)	28.82176	28.77397	28.78352	
PS (GUAGE)	2.6	2.6	2.6	
PS (IN HG)	28.95117	28.95117	28.95117	
tM (DEG F)	58	61	67	
TM (DEG R)	518	521	527	
VM (FT3)	24.01	14.99	15.01	
VM STD (FT3)	23.57519	14.60952	14.46726	
VLQ (ML)	43	41	37	
VV STD (FT3)	2.026058	1.931823	1.743352	
V STD (FT3)	25.60125	16.54134	16.21061	
%M	7.913904	11.67875	10.75438	10.11568
MD	0.920860	0.883212	0.892456	
MWD	29.28	29.284	29.436	
M	28.38731	27.96616	28.20612	
tS (DEG F)	198	196	194	196
TS (DEG R)	658	656	654	656
SUM SQRT DP	17.2332	21.7008	21.3043	
N DP	19	24	24	
AVG SQRT DP	0.907010	0.9042	0.887679	
CP	0.84	0.84	0.84	
VS (FT/SEC)	58.27386	58.44005	57.04056	57.91816
DS (IN)	68	68	68	
AS (FT2)	25.20722	25.20722	25.20722	
QS, ACFM	88135.33	88386.68	86270.05	87597.36
Q STD (FT3/MIN)	68126.65	68415.60	67003.69	67848.65
Q STD DRY, SCFM	62735.17	60425.51	59797.85	60986.18
WT (GM)	0.2052	0.0945	0.0973	
PMRC (LB/HR)	72.24254	51.71016	53.20737	59.05336
DN (IN)	0.173	0.13	0.13	
AN (IN2)	0.023494	0.013266	0.013266	
TIME (MIN)	47.5	60	60	
PMRA (LB/HR)	88.30172	57.01268	58.70195	68.00545
%I	122.2295	110.2543	110.3267	
PMR AVG (LB/HR)	80.27213	54.36142	55.95466	63.52940
%CO2	3.9	4	5.2	4.366666
%O2	16.4	16.1	15.1	15.866666
%CO	0	0	0	0
%N2	79.7	79.9	79.7	79.766666
%EA	353.3873	322.4126	254.1745	309.9915
CS (GR/SCFD)	0.134303	0.099807	0.103774	0.112628

PARTICULATE EMISSION RATE CALCULATION
DRY CATCH ONLY

DATA/CALCULATION	RUN 4-I	RUN 4-O
DATE	10/25/88	10/25/88
AVG DH (IN H2O)	28.76	28.76
P ATM (IN HG)	28.76	28.76
PM (IN HG)	30.87470	30.87470
PS (GUAGE)	2.6	-1.1
PS (IN HG)	28.95117	28.67911
tM (DEG F)	56	49
TM (DEG R)	516	509
VM (FT3)	7.81	15.69
VM STD (FT3)	8.246629	16.79501
VLQ (ML)	18.5	91.2
VV STD (FT3)	0.871676	4.297129
V STD (FT3)	9.118306	21.09214
%M	9.559631	20.37312
MD	0.904403	0.796268
MWD	29.392	29.112
M	28.30296	26.84813
tS (DEG F)	191	141
TS (DEG R)	651	601
SUM SQRT DP	11.43	9.51
N DP	12	10
AVG SQRT DP	0.9525	0.951
CP	0.84	0.84
VS (FT/SEC)	60.96073	60.32836
DS (IN)	68	64
AS (FT2)	25.20722	22.32888
QS, ACFM	92199.04	80823.92
Q STD (FT3/MIN)	77165.04	73272.43
Q STD DRY, SCFM	69788.34	58344.54
WT (GM)	0.0673	0.0122
PMRC (LB/HR)	75.34966	5.607117
DN (IN)	0.13	0.19
AN (IN2)	0.013266	0.028338
TIME (MIN)	30	30
PMRA (LB/HR)	81.20537	6.104515
%I	107.7713	108.8708
PMR AVG (LB/HR)	78.27752	5.855816
%CO2	4.8	2.6
%O2	15.6	17.4
%CO	0	0
%N2	79.6	80
%EA	288.1205	467.7419
CS (GR/SCFD)	0.125922	0.011208

PARTICULATE EMISSION RATE CALCULATION
FRONT AND BACK HALF COMBINED

DATA/CALCULATION	RUN 1-I	RUN 2-I	RUN 3-I	AVERAGE
DATE	10/25/88	10/25/88	10/25/88	
AVG DH (IN H2O)	0.84	0.19	0.32	
P ATM (IN HG)	28.76	28.76	28.76	
PM (IN HG)	28.82176	28.77397	28.78352	
PS (GUAGE)	2.6	2.6	2.6	
PS (IN HG)	28.95117	28.95117	28.95117	
tM (DEG F)	58	61	67	
TM (DEG R)	518	521	527	
VM (FT3)	24.01	14.99	15.01	
VM STD (FT3)	23.57519	14.60952	14.46726	
VLQ (ML)	43	41	37	
VV STD (FT3)	2.026058	1.931823	1.743352	
V STD (FT3)	25.60125	16.54134	16.21061	
%M	7.913904	11.67875	10.75438	10.11568
MD	0.920860	0.883212	0.892456	
MWD	29.28	29.284	29.436	
M	28.38731	27.96616	28.20612	
tS (DEG F)	198	196	194	196
TS (DEG R)	658	656	654	656
SUM SQRT DP	17.2332	21.7008	21.3043	
N DP	19	24	24	
AVG SQRT DP	0.907010	0.9042	0.887679	
CP	0.84	0.84	0.84	
VS (FT/SEC)	58.27386	58.44005	57.04056	57.91816
DS (IN)	68	68	68	
AS (FT2)	25.20722	25.20722	25.20722	
QS, ACFM	88135.33	88386.68	86270.05	87597.36
Q STD (FT3/MIN)	68126.65	68415.60	67003.69	67848.65
Q STD DRY, SCFM	62735.17	60425.51	59797.85	60986.18
WT (GM)	0.4852	0.2197	0.2482	
PMRC (LB/HR)	170.8191	120.2192	135.7252	142.2545
DN (IN)	0.173	0.13	0.13	
AN (IN2)	0.023494	0.013266	0.013266	
TIME (MIN)	47.5	60	60	
PMRA (LB/HR)	208.7914	132.5469	149.7412	163.6932
%I	122.2295	110.2543	110.3267	
PMR AVG (LB/HR)	189.8052	126.3831	142.7332	152.9738
%CO2	3.9	4	5.2	4.366666
%O2	16.4	16.1	15.1	15.866666
%CO	0	0	0	0
%N2	79.7	79.9	79.7	79.766666
%EA	353.3873	322.4126	254.1745	309.9915
CS (GR/SCFD)	0.317564	0.232038	0.264716	0.271439

PARTICULATE EMISSION RATE CALCULATION
FRONT AND BACK HALF COMBINED

DATA/CALCULATION	RUN 1-0	RUN 2-0	RUN 3-0	AVERAGE
DATE	10/25/88	10/25/88	10/25/88	
AVG DH (IN H2O)	0.87	0.77	0.78	
P ATM (IN HG)	28.76	28.76	28.76	
PM (IN HG)	28.82397	28.81661	28.81735	
PS (GUAGE)	-1.1	-1.1	-1.1	
PS (IN HG)	28.67911	28.67911	28.67911	
tM (DEG F)	63	63	67	
TM (DEG R)	523	523	527	
VM (FT3)	44.12	41.84	42.62	
VM STD (FT3)	42.91014	40.68228	41.12721	
VLQ (ML)	278	280.2	255	
VV STD (FT3)	13.09870	13.20236	12.015	
V STD (FT3)	56.00884	53.88464	53.14221	
%M	23.38685	24.50116	22.60914	23.49905
MD	0.766131	0.754988	0.773908	
MWD	29.084	29.112	29.096	
M	26.49180	26.38943	26.58728	
tS (DEG F)	147	147	146	146.6666
TS (DEG R)	607	607	606	606.6666
SUM SQRT DP	20.39	19.34	19.4	
N DP	20	20	20	
AVG SQRT DP	1.0195	0.967	0.97	
CP	0.84	0.84	0.84	
VS (FT/SEC)	65.43147	62.18229	62.09146	63.23507
DS (IN)	64	64	64	
AS (FT2)	22.32888	22.32888	22.32888	
QS, ACFM	87660.73	83307.68	83186.00	84718.14
Q STD (FT3/MIN)	73458.58	69792.97	69807.82	71019.79
Q STD DRY, SCFM	56278.93	52692.88	54024.86	54332.22
WT (GM)	0.0357	0.0372	0.0428	
PMRC (LB/HR)	6.194609	6.374548	7.438203	6.669120
DN (IN)	0.19	0.19	0.192	
AN (IN2)	0.028338	0.028338	0.028938	
TIME (MIN)	80	80	80	
PMRA (LB/HR)	6.698704	6.980162	7.8645	7.181122
%I	108.1376	109.5004	105.7311	
PMR AVG (LB/HR)	6.446657	6.677355	7.651351	6.925121
%CO2	2.3	2.6	2.5	2.466666
%O2	17.9	17.4	17.4	17.56666
%CO	0	0	0	0
%N2	79.8	80	80.1	79.96666
%EA	565.1679	467.7419	464.4458	499.1185
CS (GR/SCFD)	0.012837	0.014109	0.016057	0.014334

PARTICULATE EMISSION RATE CALCULATION
COMBINED FRONT AND BACK HALF

DATA/CALCULATION	RUN 4-I	RUN 4-O
DATE	10/25/88	10/25/88
AVG DH (IN H2O)	28.76	28.76
P ATM (IN HG)	28.76	28.76
PM (IN HG)	30.87470	30.87470
PS (GUAGE)	2.6	-1.1
PS (IN HG)	28.95117	28.67911
tM (DEG F)	56	49
TM (DEG R)	516	509
VM (FT3)	7.81	15.69
VM STD (FT3)	8.246629	16.79501
VLQ (ML)	18.5	91.2
VV STD (FT3)	0.871676	4.297129
V STD (FT3)	9.118306	21.09214
%M	9.559631	20.37312
MD	0.904403	0.796268
MWD	29.392	29.112
M	28.30296	26.84813
tS (DEG F)	191	141
TS (DEG R)	651	601
SUM SQRT DP	11.43	9.51
N DP	12	10
AVG SQRT DP	0.9525	0.951
CP	0.84	0.84
VS (FT/SEC)	60.96073	60.32836
DS (IN)	68	64
AS (FT2)	25.20722	22.32888
QS, ACFM	92199.04	80823.92
Q STD (FT3/MIN)	77165.04	73272.43
Q STD DRY, SCFM	69788.34	58344.54
WT (GM)	0.1016	0.0166
PMRC (LB/HR)	113.7522	7.629356
DN (IN)	0.13	0.19
AN (IN2)	0.013266	0.028338
TIME (MIN)	30	30
PMRA (LB/HR)	122.5923	8.306143
%I	107.7713	108.8708
PMR AVG (LB/HR)	118.1723	7.967749
%CO2	4.8	2.6
%O2	15.6	17.4
%CO	0	0
%N2	79.6	80
%EA	288.1205	467.7419
CS (GR/SCFD)	0.190100	0.015250

FORMALDEHYDE EMISSION RATE CALCULATION

DATA/CALCULATION	RUN 1-I	RUN 2-I	RUN 3-I	AVERAGE
DATE	10/25/88	10/25/88	10/25/88	
AVG DH (IN H2O)	0.84	0.19	0.32	
P ATM (IN HG)	28.76	28.76	28.76	
PM (IN HG)	28.82176	28.77397	28.78352	
PS (GUAGE)	2.6	2.6	2.6	
PS (IN HG)	28.95117	28.95117	28.95117	
tM (DEG F)	58	61	67	
TM (DEG R)	518	521	527	
VM (FT3)	24.01	14.99	15.01	
VM STD (FT3)	23.57519	14.60952	14.46726	
VLQ (ML)	43	41	37	
VV STD (FT3)	2.026058	1.931823	1.743352	
V STD (FT3)	25.60125	16.54134	16.21061	
%M	7.913904	11.67875	10.75438	10.11568
MD	0.920860	0.883212	0.892456	
MWD	29.28	29.284	29.436	
M	28.38731	27.96616	28.20612	
tS (DEG F)	198	196	194	196
TS (DEG R)	658	656	654	656
SUM SQRT DP	17.2332	21.7008	21.3043	
N DP	19	24	24	
AVG SQRT DP	0.907010	0.9042	0.887679	
CP	0.84	0.84	0.84	
VS (FT/SEC)	58.27386	58.44005	57.04056	57.91816
DS (IN)	68	68	68	
AS (FT2)	25.20722	25.20722	25.20722	
QS, ACFM	88135.33	88386.68	86270.05	87597.36
Q STD (FT3/MIN)	68126.65	68415.60	67003.69	67848.65
Q STD DRY, SCFM	62735.17	60425.51	59797.85	60986.18
WT (GM)	0.000277	0.00017	0.000225	
PMRC (LB/HR)	0.097520	0.093023	0.123038	0.104527
DN (IN)	0.173	0.13	0.13	
AN (IN2)	0.023494	0.013266	0.013266	
TIME (MIN)	47.5	60	60	
PMRA (LB/HR)	0.119198	0.102562	0.135744	0.119168
%I	122.2295	110.2543	110.3267	
PMR AVG (LB/HR)	0.108359	0.097793	0.129391	0.111848
%CO2	3.9	4	5.2	4.366666
%O2	16.4	16.1	15.1	15.866666
%CO	0	0	0	0
%N2	79.7	79.9	79.7	79.766666
%EA	353.3873	322.4126	254.1745	309.9915
CS (GR/SCFD)	0.000181	0.000179	0.000239	0.000200

FORMALDEHYDE EMISSION CALCULATION

DATA/CALCULATION	RUN 1-0	RUN 2-0	RUN 3-0	AVERAGE
DATE	10/25/88	10/25/88	10/25/88	
AVG DH (IN H2O)	0.87	0.77	0.78	
P ATM. (IN HG)	28.76	28.76	28.76	
PM (IN HG)	28.82397	28.81661	28.81735	
PS (GUAGE)	-1.1	-1.1	-1.1	
PS (IN HG)	28.67911	28.67911	28.67911	
tM (DEG F)	63	63	67	
TM (DEG R)	523	523	527	
VM (FT3)	44.12	41.84	42.62	
VM STD (FT3)	42.91014	40.68228	41.12721	
VLQ (ML)	278	280.2	255	
VV STD (FT3)	13.09870	13.20236	12.015	
V STD (FT3)	56.00884	53.88464	53.14221	
%M	23.38685	24.50116	22.60914	23.49905
MD	0.766131	0.754988	0.773908	
MWD	29.084	29.112	29.096	
M	26.49180	26.38943	26.58728	
tS (DEG F)	147	147	146	146.6666
TS (DEG R)	607	607	606	606.6666
SUM SQRT DP	20.39	19.34	19.4	
N DP	20	20	20	
AVG SQRT DP	1.0195	0.967	0.97	
CP	0.84	0.84	0.84	
VS (FT/SEC)	65.43147	62.18229	62.09146	63.23507
DS (IN)	64	64	64	
AS (FT2)	22.32888	22.32888	22.32888	
QS. ACFM	87660.73	83307.68	83186.00	84718.14
Q STD (FT3/MIN)	73458.58	69792.97	69807.82	71019.79
Q STD DRY, SCFM	56278.93	52692.88	54024.86	54332.22
WT (GM)	0.00033	0.000276	0.000274	
PMRC (LB/HR)	0.057261	0.047295	0.047618	0.050724
DN (IN)	0.19	0.19	0.192	
AN (IN2)	0.028338	0.028338	0.028938	
TIME (MIN)	80	80	80	
PMRA (LB/HR)	0.061920	0.051788	0.050347	0.054685
%I	108.1376	109.5004	105.7311	
PMR AVG (LB/HR)	0.059590	0.049541	0.048982	0.052705
%CO2	2.3	2.6	2.5	2.466666
%O2	17.9	17.4	17.4	17.56666
%CO	0	0	0	0
%N2	79.8	80	80.1	79.96666
%EA	565.1679	467.7419	464.4458	499.1185
CS (GR/SCFD)	0.000118	0.000104	0.000102	0.000108

FORMALDEHYDE EMISSION RATE CALCULATION

DATA/CALCULATION	RUN 4-I	RUN 4-O
DATE	10/25/88	10/25/88
AVG DH (IN H2O)	28.76	28.76
P ATM (IN HG)	28.76	28.76
PM (IN HG)	30.87470	30.87470
PS (GUAGE)	2.6	-1.1
PS (IN HG)	28.95117	28.67911
tM (DEG F)	56	49
TM (DEG R)	516	509
VM (FT3)	7.81	15.69
VM STD (FT3)	8.246629	16.79501
VLQ (ML)	18.5	91.2
VV STD (FT3)	0.871676	4.297129
V STD (FT3)	9.118306	21.09214
%M	9.559631	20.37312
MD	0.904403	0.796268
MWD	29.392	29.112
M	28.30296	26.84813
tS (DEG F)	191	141
TS (DEG R)	651	601
SUM SQRT DP	11.43	9.51
N DP	12	10
AVG SQRT DP	0.9525	0.951
CP	0.84	0.84
VS (FT/SEC)	60.96073	60.32836
DS (IN)	68	64
AS (FT2)	25.20722	22.32888
QS, ACFM	92199.04	80823.92
Q STD (FT3/MIN)	77165.04	73272.43
Q STD DRY, SCFM	69788.34	58344.54
WT (GM)	0.000070	0.000194
PMRC (LB/HR)	0.078596	0.089162
DN (IN)	0.13	0.19
AN (IN2)	0.013266	0.028338
TIME (MIN)	30	30
PMRA (LB/HR)	0.084704	0.097071
%I	107.7713	108.8708
PMR AVG (LB/HR)	0.081650	0.093117
%CO2	4.8	2.6
%O2	15.6	17.4
%CO	0	0
%N2	79.6	80
%EA	288.1205	467.7419
CS (GR/SCFD)	0.000131	0.000178

TGNMO EMISSION RATE CALCULATION

TGNMO EM. RT., LB/HR = mg/M x scfm x .00000375

.00000375 = 60/(35.315 x 1000 x 453.6)

RUN #	mg/M3	scfm	LB/HR	EFFICIENCY
1-I	355.00	62735.17	83.52	
2-I	632.00	60425.51	143.21	
3-I	272.00	59797.85	60.99	
1-O	180.00	56278.93	37.99	54.51
2-O	95.00	52692.88	18.77	86.89
3-O	95.00	54024.86	19.25	68.45

SUM SQRT DP CALCULATION

DATE 10/25/88

[illegible]

SUM SQRT DP CALCULATION

DATE OCTOBER 25, 1988

[illegible]

SUM SQRT DP CALCULATION

DATE OCTOBER 25, 1988

[illegible]

NOMENCLATURE

AN	(square inches), Cross sectional area of nozzle
AS	(square feet), Cross sectional area of stack
CP	Pitot tube calibration coefficient
%EA	Percent Excess Air
F	(scfd/10 ⁶ BTU), F factor
DH	(inches of water) Average orifice meter reading
HI	(million BTU/hr), Heat Input Rate
%I	Percent Isokineticity
M	(lb/lb mole), Molecular Weight of wet gas
%M	Percent Moisture
MD	Mole fraction of dry gas
MWD	(lb/lb mole) molecular weight of dry gas
N DP	Number of sample points
P ATM	(in Hg), Local atmospheric pressure
PM	(in Hg), Absolute pressure in dry gas meter
PS	(in Hg), Absolute stack pressure
PS gauge	(inches of water), Measured static stack pressure (gauge)
P STD	(29.92 in Hg), Standard pressure
PMRA	(lb/hr), Pollutant mass rate based on ratio of areas
PMR AVG.	(lb/hr), Average pollutant mass rate
PMRC	(lb/hr), Pollutant mass rate based on concentration
PMRU	(lb/million BTU), Specific emission rate
DP	(inches of water), Velocity pressure
Q S	(cubic feet/min.) Actual stack volume flow rate
Q STD	(cubic feet/min.), Stack volume flow rate at standard conditions

TM (degrees R), Average dry gas meter temperature

TS (degrees R) Average stack temperature

T STD (528 degrees R), Standard temperature

VLD (ml), Liquid volume

VM (cubic feet), Sample volume measured by dry gas meter

VM STD (cubic feet), Sample volume at standard conditions

VS (ft/sec), stack velocity

VV STD (cubic feet), Volume of water vapor collected, corrected to standard conditions

WT (gm), Total weight of particulate collected

e (min), Duration of test

CALCULATION FORMULAE

1. Absolute pressure in dry gas meter

$$P_M = P_{ATM} + DH/13.6$$

2. Absolute Stack Pressure

$$P_S = P_{ATM} + P_S \text{ gauge}/13.6$$

3. Sample volume at standard conditions

$$V_M \text{ STD} = (V_M) (T \text{ STD}/T_M) (P_M/P \text{ STD})$$

4. Volume of water collected, corrected to standard conditions

$$V_V \text{ STD} = (.00267) (V_L) (T \text{ STD}/P \text{ STD})$$

5. Total sample volume at standard conditions

$$V \text{ STD} = V_M \text{ STD} + V_V \text{ STD}$$

6. Percent moisture in stack gas

$$\%M = (100) (V_V \text{ STD})/V \text{ STD}$$

7. Mole Fraction of dry gas

$$M_D = (100 - \%M)/100$$

8. Molecular weight of the wet gas

$$M = (100) (M_D) + 18(1 - M_D)$$

9. Stack velocity

$$V_S = (85.48) (CF) ((TS/(PS) (PM))^{1/2} ((\sum DF^{1/4})/N \text{ DF})^{1/2})$$

10. Stack volume flow rate

$$Q_S = (60) (V_S) (AS)$$

11. Stack volume flow rate, standard conditions including moisture

$$Q_{STD} = (T_{STD}/P_{STD}) (P_5/T_5) (Q_5)$$

12. Stack volume flow rate standard conditions dry

$$Q_{STD DRY} = (Q_{STD}) (1 - X_M)$$

13. Pollutant mass rate, concentration basis

$$PMRC = (.1323) (WT) (Q_{STD}) / V_{STD}$$

14. pollutant mass rate ratio of areas basis

$$PMRA = (.1323) (WT) (AS) / (Q) (AN) (144)$$

15. Percent Isokineticity

$$\%I = (100) (PMRA) / PMRC$$

16. Average pollutant mass rate

$$PMR_{AVG} = (PMRA + PMRC) / 2$$

17. % excess air

$$\%EA = \frac{(100) (\%oxygen + (.5) (\%carbon\ monoxide) + (.264) (\%nitrogen) - \%oxygen + (.5) (\%carbon\ monoxide))}{(100) (\%oxygen + (.5) (\%carbon\ monoxide) + (.264) (\%nitrogen) - \%oxygen + (.5) (\%carbon\ monoxide))}$$

18. Heat input rate

$$H = ((.6) (Q_{STD DRY}) / F) ((20.9 - \%oxygen) / 20.9)$$

19. Specific emission rate

$$PMER = PMR_{AVG} / H$$

DATA SHEETS

Method 5 Sampling Data Sheets
Method 25 Sampling Data Sheets
Impinger Data Sheets
Temperature Data Sheets
Orsat Data Sheets
Chain of Custody Sheets
Test Survey Data
Equal Area Determinations
Laboratory Reports
Calibration Information (supplied upon request)

MODULE SAMPLING DATA SHEET

CLIENT G.P.

DATE 10/25/99

LOCATION Woodland, Mo.

SOURCE ESP - Outlet

TEST TEAM DM, KP

RUN # 1-0

TIME	POINT	LINE VAC	t _m ° F	t _a ° F	V _p H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS
9:45	A1	1	56	148	.79	.62	972.96	
9:49	2	1	57	148	.97	.79	974.92	
9:53	3	2	57	148	1.0	.83	977.02	
9:57	4	2	58	148	1.1	.93	—	
10:01	5	2	59	149	1.1	.93	981.42	
10:04	SHUT DOWN						983.66	
10:07	B1	2	61	148	1.0	.83	983.66	
	2	2	61	148	1.0	.83	985.89	
	3	2	62	148	1.0	.83	988.03	
	4	2	62	148	1.1	.93	990.23	
	5	2	63	147	1.1	.93	—	
	SHUT DOWN						994.79	
10:29	C1	2	64	147	1.0	.83	994.79	
	2	2	64	145	1.1	.93	997.04	
	3	2	64	143	1.1	.93	999.33	
	4	2	66	143	1.2	.99	—	
	5	2	66	144	1.2	.99	004.12	
	SHUT DOWN						006.48	

P_{bar} 28.76

P_a 1.1

MODULE RNW-1

FILTER B515

NOZZLE 32

PITOT 33

METHOD 5

LEAK RATES:
Start @ 16
End @ 16

Pitot: OK
Start
A 7.2 E 5.8

End
A 7.2 E 5.8

SETUP:
F 1.54

t_m 75

% H₂O 20

NOZZLE 32

C 0.66

t_a 140

Theo. Pitot

2.25

AVERAGE/NET
NOTES:

63	147		.87	44.12
----	-----	--	-----	-------

MODULE SAMPLING DATA SHEET

RUN # 1-0

SETUP:
 ξ _____
 t_m _____
 % H_2O _____
 NOZZLE _____
 C _____
 t_c _____
 Theo. Pitot _____

MODULE SAMPLING DATA SHEET

CLIENT GP
LOCATION Woodland Mr
TEST TEAM CBT, KP

DATE 10/25/88
SOURCE ESP-Outlet
RUN # 2-0

TIME	POINT	LINE VAC	t _m ° F	t _a ° F	V _D H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS
12:15	A1	1	61	142	.65	.53	17.67	17.67
:19	2	1	62	144	.88	.72	19.55	19.55
:23	3	2	62	144	.97	.77	21.52	
:27	4	2	62	146	.97	.77	23.64	
:31	5	2	62	147	.97	.77	25.78	
:35	SHUT DOWN						27.72	
:37	B1	3	62	146	.97	.77	27.72	
:41	2	3	63	147	.88	.72	—	
:45	3	3	63	147	.88	.72	32.01	
:49	4	4	63	148	1.0	.83	33.88	
:53	5	4	63	148	1.0	.83	36.08	
:57	SHUT DOWN						38.41	
1:00	C1	3	63	144	1.0	.83	38.11	
:04	2	3	64	148	1.0	.83	40.30	
:08	3	3	64	148	1.1	.83	42.58	
:12	4	3	65	148	1.1	.93	45.37	
:16	5	3	65	148	1.1	.93	—	
:20							47.45	

P_{bar} _____

P_a -1.1

MODULE RAW-1

FILTER B518

NOZZLE 35

PITOT 35

METHOD _____

LEAK RATES:

Start @ _____

<.015 10

End @ _____

Pitot: _____

Start OK

A 6.8 B 7.2

End _____

A _____ B _____

SETUP:

E _____

t_m _____

% H₂O _____

NOZZLE _____

C _____

t_a _____

Theo. Pitot _____

AVERAGE/NET
NOTES:

1.3 1.47 — .77 41.84

MODULE SAMPLING DATA SHEET

DATE 10/25/88
SOURCE ESP - Outlet
RUN # 2-0

Per _____

P.

MODULE /

FILTER✓

NOZZLE

~~P~~ TOT

METHOD

LEAK RATES:

Start @

End @

2.015

Pitot:

Start

SECRET

End OK

7.5' R 6.2

11 12

SETUP:

g

—

cm _____

% H₂O /

76 1250 7

NOZZLE

NOZ 291

2/

7/1

+ /

9.
 Theo Pitot

THEO. F1101

AVERAGE/NET
NOTES:

MODULE SAMPLING DATA SHEET

CLIENT GP

DATE 10/25/88

LOCATION Woodland, Me.

SOURCE ESP - Outlet

TEST TEAM DM, KP

RUN # 3-D

TIME	POINT	LINE VAC	t _m ° F	t _a ° F	V _p H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS
3:45	A1	2	66	134	.65	.53	59.74	Begin
:49	2	2	67	143	.80	.65	61.65	
:53	3	3	67	145	.93	.76	63.53	
:57	4	4	67	147	.93	.76	65.78	
:01	5	4	67	148	.98	.80	67.78	
:05	SHUT DOWN						69.94	
:07	B1	4	67	148	.93	.76	69.94	
:11	2	4	67	150	.93	.76	72.12	
:15	3	4	67	149	.94	.76	74.22	
:19	4	4	67	147	.93	.76	76.33	
:23	5	4	68	147	.98	.80	78.58	
:27	SHUT DOWN						80.79	
:30	C1	5	67	144	1.0	.83	80.79	
:34	2	5	67	146	1.1	.93	83.11	
:38	3	5	67	147	1.1	.93	—	
:42	4	5	67	146	1.1	.93	—	
:46	5	5	68	146	1.1	.93	89.98	
:50	SHUT DOWN						92.28	

P_{bar} _____

P_m _____

MODULE RNW 4

FILTER B516

NOZZLE 33

PITOT 34

METHOD 5

LEAK RATES:

Start @
_____ /
End @

Pitot: OK
Start
A 72 B 81

End
A _____ B _____

SETUP:

E _____

t_m _____

% H₂O _____

NOZZLE _____

C _____

t_m _____
Theo. Pitot

AVERAGE/NET
NOTES:

67	146		.98	42.11
----	-----	--	-----	-------

MODULE SAMPLING DATA SHEET

DATE 10/25/88

SOURCE ESP-O.Het

RUN # 3-0

Pbar _____

P. _____

MODULE

FILTER

NOZZLE

PITOT

METHOD

LEAK RATES:

Start @

End @

2.01 6

Pitot:

~~Start~~

A. _____ B. _____

End OK.

A 70 B. 8.3

SETUP:

g _____

 t_m _____

% H₂O _____

NOZZLE _____

C

ts.

Theo. Pitot

Atlanta, Ga.

MODULE SAMPLING DATA SHEET

DATE Oct 25, 1988

SOURCE ESP Exhaust

RUN # 4-0

TIME	POINT	LINE VAC	t _m ° F	t _a ° F	V _p H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS	P. _____
8:10	A1	3	47	139	.64	.51	102.55		MODULE <u>RNU-1</u>
1:13	2	3	47	140	.85	.68	104.84		FILTER <u>B-522</u>
1:16	3	3	47	141	.90	.73	106.11		NOZZLE <u>35</u>
1:19	4	3	47	142	.95	.76	107.59		PITOT <u>35</u>
1:21	5	3	48	142	.95	.76	109.68		METHOD <u>5-in</u>
1:24	SKUT DOWN						110.49		LEAK RATES: Start @ <u>2.02</u> End @ <u>0</u>
1:25	B1	5	49	140	.96	.73	110.49		Pitot: Start A _____ B _____
1:28	2	6	50	142	.95	.76	112.05		End A _____ B _____
1:31	3	6	51	142	.97	.79	113.49		
1:34	4	7	51	142	.97	.79	115.18		
1:37	5	7	52	144	1.0	.83	116.25		
1:40	SKUT DOWN						118.24		SETUP: E _____ t _m _____ % H ₂ O _____ NOZZLE _____ C _____ t _a _____ Theo. Pitot _____
AVERAGE/NET			119	141		.73	15.69		
NOTES:									

ANALYTICAL TESTING CONSULTANTS, INC.
Kannapolis, N. C. Atlanta, Ga.

MODULE SAMPLING DATA SHEET

CLIENT C.P.
LOCATION Woodland, ME.
TEST TEAM RW, CW

DATE 10/25/88
SOURCE ESP Inlet
RUN # 1-I

TIME	POINT	LINE VAC	t _m ° F	t _a ° F	V _m H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS
9:53								
00	A 1	2.0	53	196	0.78	0.80	208.94	
02.5	2	2.0	53	197	0.78	0.80	210.20	
05	3	2.5	53	197	0.80	0.83	—	
07.5	4	2.5	54	197	0.85	0.87	—	
10	5	2.5	54	197	0.81	0.84	213.95	
12.5	6	2.5	55	198	0.81	0.84	—	
15	7	3.0	55	198	0.81	0.84	—	
17.5	8	3.0	56	199	0.84	0.86	—	
20	9	3.0	57	198	0.84	0.86	—	
22.5	10	3.0	58	198	0.85	0.87	—	
25	11	3.5	59	197	0.85	0.87	—	
27.5	12	3.5	59	197	0.85	0.87	—	
30	CHANGE PORTS						224.16	
30	B 1	2.5	61	200	0.74	0.75	224.11	10.32
32.5	2	3.5	61	200	0.78	0.80	—	
35	3	4.5	61	201	0.85	0.87	—	
37.5	4	7.0	61	200	0.85	0.87	—	
40	5	12.0	62	200	0.90	0.90	0.92	
42.5	6	17.0	62	200	0.88	0.89	—	

P_{bar} 28.76

P_a +2.6

MODULE PMW-2

FILTER 8519

NOZZLE 3/

PITOT 73

METHOD 5

LEAK RATES:

Start @ 0.02 @ 15"

End @ 0.02 @ 22"

Pitot:

Start OK
A 2.4 B 1.8

End
A 3.3 B 3.0

SETUP:
g 1.87

t_m 75

% H₂O 10

NOZZLE 190

C 0.94

t_a 200

Theo. Pitot

1.80

AVERAGE/NET
NOTES:

58 198 — .84 24.01

MODULE SAMPLING DATA SHEET

RUN # 1-I

SETUP:
g _____
t_m _____
% H₂O _____
NOZZLE _____
C _____
t_m _____
Theo. Pitot _____

AVERAGE/NET
NOTES:

MODULE SAMPLING DATA SHEET

CLIENT G.P.

DATE 10/25/86

LOCATION Woodland Mo.

SOURCE ESP Inlet

TEST TEAM RW, CW

RUN # 2-I

1:00

TIME	POINT	LINE VAC	t _m ° F	t _a ° F	V _m H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS
12.5								
00	A1	1	57	192	0.86	0.20	233.77	233.77
02.5	2	1	57	192	0.86	0.20		
05	3	1	57	194	0.83	0.19		
07.5	4	1	57	194	0.83	0.19		
10	5	1	57	195	0.86	0.20		
12.5	6	1	58	196	0.86	0.20		
15	7	1	59	197	0.86	0.20		
17.5	8	1	59	197	0.86	0.20		
20	9	1	59	196	0.86	0.20		
22.5	10	1	60	196	0.83	0.19		
25	11	1.5	60	197	0.83	0.19		
27.5	12	1.5	61	197	0.83	0.19		
30	CHANGE PORTS						241.44	
30	B1	1.5	63	197	0.78	0.18	241.44	1132
32.5	2	2	63	197	0.86	0.20		
35	3	2	64	196	0.85	0.20		
37.5	4	2	64	195	0.83	0.19		
40	5	2	64	195	0.83	0.19		
42.5	6	2	64	194	0.83	0.19		

P_{bar} 28.76

P_a +2.6

MODULE RM-2

FILTER B520

NOZZLE 0.130

PITOT #12

METHOD 5

LEAK RATES:

Start @

0.02 @ 15"

End @

0.015 @ 10"

Pitot:

Start

A 3.1 B 2.8

End

A 2.7 B 3.3

SETUP:

E _____

t_m _____

% H₂O _____

NOZZLE _____

C _____

t_a _____

Theo. Pitot

8.0

AVERAGE/NET
NOTES:

61	196		.19	14.99
----	-----	--	-----	-------

MODULE SAMPLING DATA SHEET

RUN # 2-I

Theo. Pitot

--	--	--	--	--

MODULE SAMPLING DATA SHEET

CLIENT G.P.
LOCATION Woodland, Me
TEST TEAM BW, CW

DATE 10/25/88
SOURCE ESP Inlet
RUN # 3-I

TIME 4.84	POINT	LINE VAC	t _m ° F	t _a ° F	V _g H ₂ O	P _m H ₂ O	V _m ft ³	REMARKS
00	A1	1.5	66	193	0.86	0.20	250.08	START Run.
02.5	2	1.5	65	191	0.83	0.19		
05	3	1.5	65	180	0.81	0.19		
07.5	4	2.0	65	179	0.83	0.19		
10	5	2.0	65	178	0.83	0.19		
12.5	6	2.0	66	201	0.83	0.19		
15	7	2.0	66	205	0.86	0.20		
17.5	8	2.0	67	206	0.87	0.20		
20	9	2.0	67	206	0.83	0.19		
22.5	10	2.0	68	186	0.85	0.20		
25	11	2.5	68	182	0.87	0.20		
27.5	12	2.5	68	180	0.83	0.19		
30	CHANGE PORTS						257.87	
30	B1	1.5	68	195	0.73	0.17	257.87	4:41.
32.5	2	1.5	68	200	0.76	0.18		
35	3	1.5	68	200	0.76	0.18		
37.5	4	1.5	67	199	0.73	0.17		
40	5	2.0	68	199	0.83	0.19		
42.5	6		67	194	0.79	0.18		

P_{bar} 28.76

P_a 2.6

MODULE BW-2

FILTER B521

NOZZLE 0.130

PITOT 71

METHOD 5

LEAK RATES:

Start @

0.015 @ 12"

End @

0.015 @ 7"

Pitot:

Start

A 3.2 B 3.0

End

A 2.8 B 3.1

SETUP:

E _____

t_m _____

% H₂O _____

NOZZLE _____

C _____

t_a _____

Theo. Pitot _____

AVERAGE/NET
NOTES:

67	194		1.32	15.01
----	-----	--	------	-------

ANALYTICAL TESTING CONSULTANTS, INC.
Kannapolis, N. C. Atlanta, Ga.

MODULE SAMPLING DATA SHEET

CLIENT G.P.
LOCATION Woodland Mo.
TEST TEAM RW, CW

DATE 10/25/88
SOURCE ESI Tank
RUN # 4-I

TIME <i>8:10 PM</i>	POINT	LINE VAC	t_m ° F	t_a ° F	V_a H ₂ O	P_m H ₂ O	V_m ft ³	REMARKS
00	A1	2.0	54	200	1.00	0.23	274.26	START <i>Rm</i>
02.5	2	2.0	54	199	0.48	0.22		
05	3	2.0	55	198	0.96	0.22		
07.5	4	2.0	55	199	0.95	0.22		
10	5	2.0	55	199	0.95	0.22		
12.5	6	2.5	55	199	0.95	0.22		
15	7	2.5	56	200	0.95	0.22		
17.5	8	2.5	56	199	0.91	0.21		
20	9	2.5	57	179	0.88	0.20		
22.5	10	2.5	57	176	0.88	0.20		
25	11	2.0	58	175	0.75	0.18		
27.5	12	2.0	59	174	0.75	0.18		
30	CHANGE PORTS						282.07	
30	B1						282.07	
32.5	2							
35	3							
37.5	4							
40	5							
42.5	6							

P_{bar} _____

P_a _____

MODULE RM-2

FILTER B523

NOZZLE 0.130

PITOT 73

METHOD 5

LEAK RATES:

Start @ _____

0.02 @ 9'

End @ _____

Pitot:

Start

A 3.1 B 2.6

End

A 3.3 B 3.1

SETUP:

E _____

t_m _____

% H₂O _____

NOZZLE _____

C _____

t_a _____

Theo. Pitot _____

AVERAGE/NET
NOTES:

56	191		.21	7.81
----	-----	--	-----	------

VOLATILE ORGANIC CARBON

FACILITY G.P. SAMPLE LOCATION ESP-Inlet
 LOCATION Woodland, Me. OPERATOR WILKES
 DATE 10/25/88 RUN NUMBER 1-I
 TANK NUMBER 4T42 TRAP # DV SAMPLE # 1-I

TANK VACUUM inches Hg	BAROMETRIC PRESSURE IN. Hg	AMBIENT TEMPERATURE °F
PRETEST (Manometer) <u>29.3</u> (Gauge) <u>29</u>	<u>28.76</u>	<u>52°</u>
POST TEST (Manometer) <u>2.9</u> (GAUGE) <u>2.0</u>	<u>29.07</u>	<u>48°</u>

LEAK RATE, IN. Hg/5 min.:	TANK	TRAP HALF
PRETEST	<u>0</u>	<u>0</u>
<u>9.46</u> POST TEST	<u>0</u>	<u>0</u>

TIME CLOCK/SAMPLE	GAUGE VACUUM In. Hg	FLOWMETER SETTING	COMMENTS
<u>00</u>	<u>29</u>	<u>50</u>	<u>Start run</u>
<u>05</u>	<u>25</u>	<u>50</u>	
<u>10</u>	<u>23</u>	<u>50</u>	
<u>15</u>	<u>20</u>	<u>50</u>	
<u>20</u>	<u>18</u>	<u>50</u>	
<u>25</u>	<u>16</u>	<u>40</u>	<u>Change flow to 40</u>
<u>30</u>	<u>14</u>	<u>40</u>	
<u>35</u>	<u>12</u>	<u>40</u>	
<u>40</u>	<u>10</u>	<u>40</u>	<u>Change flow to 30</u>
<u>45</u>	<u>8</u>	<u>30</u>	
<u>50</u>	<u>7</u>	<u>30</u>	
<u>55</u>	<u>4</u>	<u>30</u>	
<u>60</u>	<u>2.0</u>	<u>30</u>	<u>END RUN</u>

VOLATILE ORGANIC CARBON

FACILITY G.P. SAMPLE LOCATION ESP. Inlet
 LOCATION Woodland, Me. OPERATOR Wilkes
 DATE 10/25/88 RUN NUMBER 2-I
 TANK NUMBER 744 (4T20) TRAP # EZ SAMPLE # 2-I

TANK VACUUM inches Hg	BAROMETRIC PRESSURE IN. Hg	AMBIENT TEMPERATURE °F
PRETEST (Manometer) <u>29.3</u> (Gauge) <u>29</u>	<u>28.76</u>	<u>52°</u>
POST TEST (Manometer) <u>10.0</u> (GAUGE) <u>9.0</u>	<u>29.07</u>	<u>48°</u>

LEAK RATE, IN. Hg/5 min.:	TANK	TRAP HALF
PRETEST	<u>0</u>	<u>0</u>
POST TEST	<u>0</u>	<u>0</u>

12:15

TIME CLOCK/SAMPLE	GAUGE VACUUM In. Hg	FLOWMETER SETTING	COMMENTS
<u>00</u>	<u>29</u>	<u>50</u>	<u>START RUN</u>
<u>05</u>	<u>27.5</u>	<u>50</u>	
<u>10</u>	<u>26</u>	<u>50</u>	<u>Frozen Trap start to fix</u>
<u>15</u>	<u>23</u>	<u>50</u>	<u>1:49 Restart</u>
<u>20</u>	<u>21</u>	<u>50</u>	<u>:54</u>
<u>25</u>	<u>19</u>	<u>50</u>	<u>:59</u>
<u>30</u>	<u>16.9</u>	<u>50</u>	<u>:04</u>
<u>35</u>	<u>15.4</u>	<u>50</u>	<u>:09</u>
<u>40</u>	<u>13.9</u>	<u>50</u>	<u>:14</u>
<u>45</u>	<u>12.3</u>	<u>50</u>	<u>:19</u>
<u>50</u>	<u>11.0</u>	<u>50</u>	<u>:24</u>
<u>55</u>	<u>10.0</u>	<u>50</u>	<u>:29</u>
<u>60</u>	<u>9.0</u>		<u>END RUN</u>

VOLATILE ORGANIC CARBON

FACILITY G.P. SAMPLE LOCATION ESP-Inlet
 LOCATION Woodland, Me. OPERATOR Wilkes
 DATE 10/25/88 RUN NUMBER 3-I
 TANK NUMBER 745 (4T35) TRAP # NONE (FD) SAMPLE # 3-I

TANK VACUUM inches Hg	BAROMETRIC PRESSURE IN. Hg	AMBIENT TEMPERATURE °F
PRETEST (Manometer) <u>29.3</u> (Gauge) <u>28</u>	<u>28.76</u>	<u>52°</u>
POST TEST (Manometer) <u>7.7</u> (GAUGE) <u>7</u>	<u>29.07</u>	<u>48°</u>

LEAK RATE, IN. Hg/5 min.:	TANK	TRAP HALF
PRETEST	<u>0</u>	<u>0</u>
POST TEST	<u>0</u>	<u>0</u>

TIME CLOCK/SAMPLE	GAUGE VACUUM In. Hg	FLOWMETER SETTING	COMMENTS
<u>00 3:45</u>	<u>28</u>	<u>50</u>	<u>Start Run</u>
<u>05</u>	<u>27.5</u>	<u>50</u>	
<u>10</u>	<u>24.0</u>	<u>50</u>	
<u>15</u>	<u>22.5</u>	<u>50</u>	
<u>20</u>	<u>21</u>	<u>50</u>	
<u>25</u>	<u>19</u>	<u>50</u>	
<u>30</u>	<u>17</u>	<u>50</u>	
<u>35</u>	<u>15.5</u>	<u>50</u>	
<u>40</u>	<u>14.5</u>	<u>50</u>	
<u>45</u>	<u>13.5</u>	<u>50</u>	
<u>50</u>	<u>11.0</u>	<u>50</u>	
<u>55</u>	<u>9.5</u>	<u>50</u>	
<u>60</u>	<u>7.0</u>	<u>END RUN</u>	

VOLATILE ORGANIC CARBON

FACILITY Georgia-Pacific

SAMPLE LOCATION ESP Outlet

LOCATION Woodland, Me.

OPERATOR Job

DATE 10/25/88

RUN NUMBER 1-0

TANK NUMBER 4T31

TRAP # E-E SAMPLE # 2-0

TANK VACUUM
inches Hg

BAROMETRIC
PRESSURE
IN. Hg

AMBIENT
TEMPERATURE
°F

PRETEST (Manometer) 29.3 (Gauge) 29.0

28.76

52°

POST TEST (Manometer) 1.2 (GAUGE) 2

29.07

48°

LEAK RATE, IN. Hg/5 min.:

TANK

TRAP HALF

PRETEST

0

0

POST TEST

0

0

TIME
CLOCK/SAMPLE

GAUGE VACUUM
In. Hg

FLOWMETER SETTING

COMMENTS

9:50

29

60

Start Run

:55

26

60

10:00

24

60

:05

22

60

:10

20

60

:15

18

60

:20

16

50

Change flow to 50

:25

11

50

:30

9

50

:35

7

50

:40

5

50

:45

3

50

10:50

2

50

VOLATILE ORGANIC CARBON

FACILITY Georgia-Pacific SAMPLE LOCATION Outlet
 LOCATION Woodland, Maine OPERATOR Pool
 DATE 10/25/88 RUN NUMBER 2-0
 TANK NUMBER 4T 40 TRAP # CK SAMPLE # 2-0

TANK VACUUM inches Hg	BAROMETRIC PRESSURE IN. Hg.	AMBIENT TEMPERATURE °F
PRETEST (Manometer) <u>29.4</u> (Gauge) <u>28</u>	<u>28.76</u>	<u>52°</u>
POST TEST (Manometer) <u>1.5</u> (GAUGE) <u>1.5</u>	<u>29.07</u>	<u>78°</u>

LEAK RATE, IN. Hg/5 min.:	TANK	TRAP HALF
PRETEST	<u>0</u>	<u>0</u>
POST TEST	<u>0</u>	<u>0</u>

TIME CLOCK/SAMPLE	GAUGE VACUUM In. Hg	FLOWMETER SETTING	COMMENTS
<u>12:15</u>	<u>28</u>	<u>40</u>	<u>Start Run</u>
<u>20</u>	<u>24</u>	<u>40</u>	
<u>25</u>	<u>21</u>	<u>40</u>	
<u>30</u>	<u>19</u>	<u>35</u>	
<u>35</u>	<u>16</u>	<u>35</u>	
<u>40</u>	<u>14</u>	<u>35</u>	
<u>45</u>	<u>12</u>	<u>35</u>	<u>Stop (to fix inlet problem)</u>
<u>56 1:55</u>	<u>12</u>	<u>35</u>	<u>Resume</u>
<u>2:00</u>	<u>10</u>	<u>35</u>	
<u>:05</u>	<u>9</u>	<u>30</u>	
<u>:10</u>	<u>7</u>	<u>30</u>	
<u>:15</u>	<u>5</u>	<u>30</u>	
<u>:20</u>	<u>3</u>	<u>30</u>	
<u>:25</u>	<u>1.5</u>	<u>30</u>	<u>End Run</u>

VOLATILE ORGANIC CARBON

FACILITY Georgia-Pacific SAMPLE LOCATION Crude
 LOCATION Woodland Maine OPERATOR Pool
 DATE 10/25/88 RUN NUMBER 3-0
 TANK NUMBER 4T37 TRAP # AA SAMPLE # 3-0

TANK VACUUM inches Hg	BAROMETRIC PRESSURE IN. Hg	AMBIENT TEMPERATURE °F
PRETEST (Manometer) <u>29.4</u> (Gauge) <u>29</u>	<u>28.74</u>	<u>52°</u>
POST TEST (Manometer) <u>1.6</u> (GAUGE) <u>2.0</u>	<u>29.07</u>	<u>48°</u>

LEAK RATE, IN. Hg/5 min.:	TANK	TRAP HALF
PRETEST	<u>0</u>	<u>.</u>
POST TEST	<u>0</u>	<u>0</u>

TIME CLOCK/SAMPLE	GAUGE VACUUM In. Hg	FLOWMETER SETTING	COMMENTS
<u>3:45</u>	<u>29</u>	<u>40</u>	<u>Start Run</u>
<u>3:50</u>	<u>26</u>	<u>40</u>	
<u>3:55</u>	<u>23</u>	<u>40</u>	
<u>4:00</u>	<u>21</u>	<u>40</u>	
<u>:05</u>	<u>18.5</u>	<u>40</u>	
<u>:10</u>	<u>16.0</u>	<u>40</u>	
<u>:15</u>	<u>14.0</u>	<u>40</u>	
<u>:20</u>	<u>11.0</u>	<u>30</u>	<u>Adjust flow to 30</u>
<u>:25</u>	<u>8.5</u>	<u>30</u>	
<u>:30</u>	<u>7.0</u>	<u>30</u>	
<u>:35</u>	<u>5.0</u>	<u>30</u>	
<u>:40</u>	<u>3.5</u>	<u>30</u>	
<u>:45</u>	<u>2.0</u>	<u>30</u>	<u>End Run</u>

ANALYTICAL TESTING CONSULTANTS, INC.

IMPINGER DATA SHEET

JOE Go. Pa.LOCATION: Woodland MeUNIT ESP Outle

80% IPA - ΔWT = 83.4 G
3% H₂O - " = 99.8 G

RUN #	DATE	CYCL-ONE	CONTENTS OF IMPINGER				TOTAL CONDENSATE V ₁ EPA	(DE V _W) WF-50	LOCATION & REMARKS
			1	2	3	4 (cc)			
1-0	START	10/25/88	100mL	100mL	Dry	300 5102			
	END	11-1-88	360	100	1	317.			
	Δ		260	0	1	17.	278.	ml	
2-0	START	10/25/88	100mL	100mL	Dry	300 5102			
	END	11-1-88	370	100	1	309.1			
	Δ		270	0	1	9.2	280.2	ml	
3-0	START	10/25/88	100mL	100mL	Dry	300 5102			
	END	11/1/88	340	100	0	315.			
	Δ		240	0	0	15.	255.	ml	
	START								
	END								
	Δ							ml	
	START								
	END								
	Δ							ml	

Data by R. J. Heston

Approved by _____

ANALYTICAL TESTING CONSULTANTS, INC.

IMPINGER DATA SHEET

JOE Georgia-Pacific LOCATION Woodland, Me. UNIT CSP Inlet

80% IPA - Δ WT = 83.4 G
3% H_2O_2 - " = 99.8 G

RUN #	DATE	CYC-ONE	CONTENTS OF IMPINGERS				TOTAL CONDENSATE		LOCATION & REMARKS
			1	2	3	4 (cc)	V ₁₂ EPA	(DE V _w) WF-50	
1-I	START	10/25/88	100 ml NaHSO ₃	100 ml NaHSO ₃	DRY	300g SiO ₂			
	END		120	114	0	309			
	Δ		20	14	0	9	43	ml	
2-I	START	10/25/88	100 ml NaHSO ₃	100 ml NaHSO ₃	DRY	300g SiO ₂			
	END		116	110	0	315			
	Δ		16	10	0	15	41	ml	
3-I	START	10/25/88	100 ml NaHSO ₃	100 ml NaHSO ₃	DRY	300g SiO ₂			
	END		123	107	0	317			
	Δ		23	7	0	17	47	ml	
	START								
	END								
	Δ							ml	
	START								
	END								
	Δ							ml	

Data by UK Pool

Approved by _____

ANALYTICAL TESTING CONSULTANTS, INC.

IMPINGER DATA SHEET

JOB C.P.LOCATION Woodland, Mo.UNIT ESP-Inlet
Outlet

RUN #	DATE	CYCL-ONE	CONTENTS OF IMPINGERS				TOTAL CONDENSATE V ₁₀ EPA (OR V _W) WF-50	LOCATION & REMARKS
			1	2	3	4 (cc)		
4-I	START	11/24/88	100ml	100ml	Dry	300g 5.02		
	END	11/1/88	110	100	2	306.5		
	Δ		10	0	2	6.5	18.5	ml
4-D								
4-D	START	11/25/88	100ml	100ml	Dry	300g 5.02		
	END	11/1/88	174	101	1	315.2		
	Δ		74	1	1	15.2	91.2	ml
	START							
	END							
	Δ							ml
	START							
	END							
	Δ							ml
	START							
	END							
	Δ							ml

Data by [Signature]

Approved by _____

20

80% IHA - Δ WT = 83.4 g
 38% H₂O - Δ WT = 99.8 g

ANALYTICAL TESTING CONSULTANTS, INC.

TEMPERATURE DATA

JOE Ga. PacificLOCATION Woodland Wre.UNIT E, S, P OutletDATE 10/25/88MADE BY P. [Signature]

CHECKED BY _____

Run # 1-0				Run # 2-0				Run # 3-0			
Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.	Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.	Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.
A1	Hot	270°	52°	A1	Good	250°	52°	A1	Good	270°	60°
2		270°	52°	2		285°	54°	2		270°	60°
3		270°	52°	3		285°	54°	3		270°	60°
4		270°	54°	4		275°	46°	4		275°	60°
5		275°	54°	5		275°	46°	5		275°	62°
B1		275°	54°	B1		275°	44°	B1		275°	62°
2		275°	56°	2		270°	44°	2		275°	62°
3		275°	56°	3		270°	44°	3		270°	64°
4		275°	59°	4		265°	44°	4		270°	64°
5		275°	60°	5		265°	50°	5		265°	64°
C1		275°	62°	C1		265°	50°	C1		240°	64°
2		275°	64°	2		265°	50°	2		248°	64°
3		270°	64°	3		250°	50°	3		230°	64°
4		265°	64°	4		250°	48°	4		230°	64°
5		265°	64°	5		250°	48°	5		250°	64°
D1		250°	64°	D1		250°	54°	D1		265°	64°
2		250°	66°	2		240°	54°	2		265°	62°
3		250°	66°	3		240°	54°	3		265°	62°
4		250°	66°	4		240°	54°	4		260°	62°
5		250°	66°	5		240°	54°	5		260°	62°

ANALYTICAL TESTING CONSULTANTS, INC.

TEMPERATURE DATA

JOB Ga. Pacific LOCATION Woodland, Me. UNIT ESP Outlet
 DATE 10/25/88 MADE BY Jed CHECKED BY _____

Run # 4-0				Run #				Run #			
Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.	Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.	Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.
A1	Hot	270°	42°								
2	{	270°	42°								
3	{	265°	42°								
4	{	260°	40°								
5	{	260°	40°								
B1	{	265°	40°								
2	{	265°	42°								
3	{	265°	42°								
4	{	265°	42°								
5	{	265°	44°								

ANALYTICAL TESTING CONSULTANTS, INC.

TEMPERATURE DATA

JOB G.P.LOCATION Woodland, Me.UNIT ESP InletDATE 10/25/88

MADE BY _____

CHECKED BY _____

Run # 1-I				Run # 2-I				Run # 3-I			
Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.	Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.	Time or Pt.	Probe Temp. F.	"Hot Box" Temp. F.	Exit Gas Temp. F.
A1	OK	245	61	A1	245	59		41	245	57	
2		250	61	2	250	59		2	250	57	
3		250	61	3	255	59		3	250	58	
4		250	61	4	255	60		4	250	58	
5		250	61	5	260	60		5	255	58	
6		255	61	6	260	60		6	255	58	
7		250	61	7	260	60		7	255	58	
8		255	62	8	260	60		8	255	58	
9		260	62	9	255	61		9	260	58	
10		265	62	10	260	61		10	260	58	
11		265	62	11	260	61		11	260	59	
12		260	62	12	260	61		12	260	59	
B1	OK	265	62	B1	260	61		B1	260	60	
2		265	62	2	255	61		2	260	60	
3		260	62	3	255	62		3	260	60	
4		260	62	4	260	62		4	255	60	
5		260	62	5	260	62		5	255	59	
6		265	63	6	265	62		6	255	59	
7		260	63	7	265	62		7	255	59	
8		260	63	8	265	62		8	255	59	
9		260	63	9	270	63		9	250	59	
10		260	63	10	270	63		10	250	59	
11		255	64	11	270	63		11	250	59	
12		255	64	12	270	63		12	250	59	

[illegible]

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/68

ANALYST: Wilke

CLIENT: Gl Waddell

SOURCE: ESP Inlet

INSTRUMENT: Fyrite

CAL. GASES:

Type:	%	Inst. Reading
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<u>Run 1-I</u>						
A 2	17.0	3.0				
4	17.5	2.5				
6	16.5	3.5				
8	16.5	3.0				
10	16.5	3.5				
B 2	15.5	4.5				
4	15.5	4.0				
6	16.0	4.0				
8						
10					79.7	

Avg.

16.4

3.9

20.3

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: Wilkes

CLIENT: GP Woodland

SOURCE: ESP Inlet

INSTRUMENT: Fyrite

CAL. GASES:

Type:	%	Inst. Reading
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<u>2I</u>						
<u>A2</u>	<u>17.0</u>	<u>3</u>				
<u>4</u>	<u>16.5</u>	<u>3.5</u>				
<u>6</u>	<u>16.5</u>	<u>3.5</u>				
<u>8</u>	<u>16.5</u>	<u>3.5</u>				
<u>10</u>	<u>16.0</u>	<u>4.5</u>				
<u>B2</u>	<u>16.5</u>	<u>3.5</u>				
<u>4</u>	<u>16.5</u>	<u>3.5</u>				
<u>6</u>	<u>16.0</u>	<u>4.5</u>				
<u>8</u>	<u>16.0</u>	<u>4.5</u>				
<u>10</u>	<u>15.5</u>	<u>5.5</u>			<u>79.9</u>	

Avg. 16.1 4.0

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: W. J. Lee

CLIENT: G P Woodland

SOURCE: ESP Inlet

INSTRUMENT: Fugite

CAL. GASES:

Type:	%	Inst. Reading
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<u>Run 4I</u>						
<u>A 2</u>	<u>15.5</u>	<u>4.5</u>				
<u>4</u>	<u>15.5</u>	<u>5.0</u>				
<u>6</u>	<u>15.5</u>	<u>5.0</u>				
<u>8</u>	<u>16.0</u>	<u>4.5</u>				
<u>10</u>	<u>15.5</u>	<u>5.0</u>				

Aug. 15.6 4.8

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: K. Poole

CLIENT: GP

SOURCE: ESP - Outlet

INSTRUMENT: 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Quinert</u>	<u>20.95</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

_____ X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<i>Run 1-0</i>						
1A	19.0	2.5				
2A	18.4	2.5				
3A	17.9	2.7				
4A	17.3	2.7				
5A	17.4	2.7				
1B	17.5	2.4				
2B	17.5	2.4				
3B	17.3	2.5				
4B	17.6	2.5				
5B	17.4	2.3				

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: K Poole

CLIENT: GP

SOURCE: ESP - Outlet

INSTRUMENT: 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Ambient</u>	<u>20.95</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<u>Run 1-0</u>						
1C	17.8	2.3				
2C	17.6	2.5				
3C	18.4	1.8				
4C	17.3	2.5				
5C	17.7	2.2				
1D	18.2	2.0				
2D	18.4	2.0				
3D	18.2	2.1				
4D	18.5	2.1				
5D	17.9	2.2				

Aug.

17.9

2.3

79.8

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: K. Poole

CLIENT: G.P.

SOURCE: ESP - Outlet

INSTRUMENT: 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Ambient</u>	<u>20.95</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
Run 2-0						
1A	17.6	2.4				
2A	17.8	2.3				
3A	19.3	2.6				
4A	17.3	2.6				
5A	17.5	2.4				
1B	17.3	2.5				
2B	17.4	2.5				
3B	17.2	2.7				
4B	17.1	2.8				
5B	17.4	2.6				

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/69

ANALYST: K Poole

CLIENT: GP

SOURCE: ESP. Outlet

INSTRUMENT: 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Ambient</u>	<u>20.95</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<i>Run 2-0</i>						
1C	17.4	2.7				
2C	17.2	2.6				
3C	17.0	2.8				
4C	17.4	2.7				
5C	17.7	2.4				
1D	17.5	2.3				
2D	17.4	2.4				
3D	17.6	2.5				
4D	17.4	2.6				
5D	17.4	2.6				

Aug.

17.4

2.6

80

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: K. Poole

CLIENT: G.P.

SOURCE: ESP - Outlet

INSTRUMENT: 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Ambient</u>	<u>20.95</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

x Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<i>Run 3-0</i>						
1A	17.4	2.6				
2A	17.2	2.6				
3A	17.3	2.4				
4A	17.3	2.7				
5A	17.3	2.8				
1B	17.6	2.3				
2B	17.6	2.3				
3B	17.4	2.5				
4B	17.2	2.6				
5B	17.3	2.6				

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: Keith Poole

CLIENT: G.P. Wollard

SOURCE: ESP. Outlet

INSTRUMENT: PCA 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Ambient</u>	<u>20.95</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

_____ X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
3-0						
1C	17.3	2.3				
2C	17.3	2.5				
3C	17.2	2.4				
4C	17.8	2.4				
5C	17.6	2.5				
1D	17.5	2.4				
2D	17.5	2.5				
3D	17.4	2.5				
4D	17.6	2.6				
5D	17.5	2.5				

Avg.

17.4

2.5

80.1

ANALYTICAL TESTING CONSULTANTS, INC. GAS ANALYSIS DATA

DATE: 10/25/88

ANALYST: K. Pool

CLIENT: Ga Pacific

SOURCE: ESP - Outlet

INSTRUMENT: PCA 611

CAL. GASES:

Type:	%	Inst. Reading
<u>Ambient</u>	<u>20.85</u>	<u>20.9</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

_____ Integrated bag

X Individual point readings

RUN/POINT	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	N ₂ % by dif	REMARK
<u>Run 4-0</u>						
1A	17.0	2.8				
2A	17.4	2.6				
3A	17.4	2.5				
4A	17.4	2.7				
5A	17.6	2.5				
1B	17.6	2.5				
2B	17.5	2.5				
3B	17.6	2.7				
4B	17.4	2.4				
5B	17.4	2.4				

Aug. 17.4 2.6

ANALYTICAL TESTING CONSULTANTS, INC.

CHAIN OF CUSTODY FORMPlant Georgia-Pacific - Woodland MaRun No. 1, 2, 3.Sampling Location ESP OutletFilter No. BS16, BS15, BS18Test Method☒ EPA 5 ☐ EPA 8☐ EPA 6 ☐ _____☐ EPA 7 ☐ _____

Container No.	Contents	Sample Recovered by	Remarks
Run #1 BS15 Run #2 BS18 Run #3 BS16	Filter	KP	
<u>423</u> -Dry Catch Wash	Probe, nozzle and cyclone washings	C.W. R.W.	
<u>423</u> -Wet Catch Solution	Impinger solutions	D.Mc.	
<u>423</u> -Wet Catch Wash	Impinger washings	D.Mc.	
Run, 1, 2, 3.	Silica gel	KP	
	Solvent blank	KP	

Note: Liquid levels to be marked with grease pencil on all sample containers and to be checked when delivered to lab.

Delivered to lab by: D.Mc.Date 10-28-88Received in lab by: K.P.Date 10-28-88Analysis completed by K.P.Date 11-2-88

ANALYTICAL TESTING CONSULTANTS, INC.

CHAIN OF CUSTODY FORM

Plant Georgian-Pacific, Waco, Tenn., Me.

Test Method

Run No. 1I, 2I, 3I, 4I, 40☒ EPA 5 ☐ EPA 6Sampling Location ESP Inlet & Outlet☐ EPA 6 ☐ EPA 7Filter No. B522, B519, B520, B521, B523☐ EPA 7 ☐ EPA 8

Container No.	Contents	Sample Recovered by	Remarks
Run 4-0 B522 Run 1-I B519 Run 2-I B520 Run 3-I B521	Run 4-I - B523 Filter	KP	
1-I, 2I 3I, 4I 4-0 - Dry Catch Wash	Probe, nozzle and cyclone washings	C.W. R.W.	
1I, 2I, 3I 4I, 40 - Wet Catch Solution	Impinger solutions	D.M.C.	
1I, 2I, 3I 4I, 40 - Wet Catch Wash	Impinger washings	D.M.C.	
Runs 1I, 2I, 3I 4I, 40	Silica gel	KP	
	Solvent blank	KP	

Note: Liquid levels to be marked with grease pencil on all sample containers and to be checked when delivered to lab.

Delivered to lab by: D.M.C.Date 10-28-88Received in lab by: K.P.Date 10-28-88Analysis completed by: K.P.Date 11-2-88

SOURCE TEST SURVEY

SOURCE NAME: C-F Woodland Chip Dryer Exhaust
 LOCATION: Woodland Mine
 DATE: Oct 24 1988

OBSERVER'S NAME: Keith Poole

PURPOSE OF TEST: Compliance
 TESTING DONE BY: ATC Inc.
 LAB ANALYSIS DONE BY: _____

COMPANY CONTACT: LARSON HARRY TELEPHONE _____
 CONTROL EQUIPMENT OPERATING: ESP
 OPACITY READING MADE: _____ YES X NO

UNIT/PROCESS NAME: _____
 RATED CAPACITY: _____
 TYPE FUEL USED: WOOD

APPROX. PROCESS RATE: _____
 METHOD OF DETERMINING PROCESS RATE: _____
 STACK HEIGHT: 100
 INDIVIDUAL STACK ✓ COMMON STACK
 DIAMETER: (IF ROUND) 64" (IF RECTANGULAR) WIDTH _____ LENGTH _____

I. SAMPLING POINT LOCATION

- A. DISTANCE DOWNSTREAM FROM ANY FLOW DISTURBANCE:
 NATURE OF DISTURBANCE 30' Branching
 (BEND, CONTRACTION, EXPANSION, FAN, BAFFLES, ETC.)
 B. DISTANCE UPSTREAM FROM ANY FLOW DISTURBANCE:
 NATURE OF DISTURBANCE 25'
 (BEND, STACK EXIT, CONTRACTION, FAN, BAFFLES, EXPANSION, ETC.)
 C. NUMBER OF PORTS IN STACK: 4
 D. NUMBER OF POINTS SAMPLED PER PORT: 5

II. STACK GAS

- A. STACK TEMPERATURE: 140° F
 B. ORSAT ANALYSIS:
 GRAVE _____ CONTINUOUS _____ NUMBER OF INTEGRATED SAMPLES _____
 C. PRELIMINARY ΔP : MIN. .62 MAX. 1.1

III. PARTICULATE TEST

- A. SAMPLING TRAIN:
 1. TEST METHOD: EPA METHOD 5 ✓ ASME FIC 21/27 _____
 OTHER (DISCRIPTION) _____
 2. TYPE FILTERS _____
 3. PROBE IDENTIFICATION _____
 4. METER CALIBRATION FACTOR 1.0
 5. ORIFICE $\Delta H @$ FACTOR 1.6
 6. DATE OF LAST CALIBRATION CHECK _____
 a. ORIFICE METER _____ d. DRY GAS METER _____
 b. TEMPERATURE DEVICES _____ e. PITOT TUBE _____
 c. NOZZLE DIAMETER _____ f. OTHER _____


ANALYTICAL TESTING CONSULTANTS, INC.

JOE Georgia-Pacific LOCATION Wooland, Me. DATE 10/24/88
 UNIT ESP Outlet MADE BY Pool CHECKED BY _____

EQUAL AREA CALCULATIONS

Description

ROUND DUCT - TEN POINT TRAVERSE PER DIAMETER




Stack I.D. = 64 In.		
Point No.	% of Diameter	Distance (Inches)
1	2.5	1.6
2	8.2	5.25
3	14.6	9.34
4	22.6	14.46
5	34.2	21.89
6	65.8	42.11
7	77.4	49.54
8	85.4	54.66
9	91.8	58.75
10	97.5	62.4

ANALYTICAL TESTING CONSULTANTS, INC.

JOE Ga. Pacific LOCATION Woodland, Me DATE 10/24/88
 UNIT ESP ~~Test~~ MADE BY BN7 CHECKED BY _____
Inlet

Description: EQUAL AREA CALCULATIONS
ROUND DUCT - TWELVE POINT TRAVERSE PER DIAMETER

2" Port Depth



STACK I.D. = 68 IN.		
POINT NO.	% OF DIAMETER	DISTANCE (INCHES)
1	2.1	1.43
2	6.7	4.56
3	11.8	8.02
4	17.7	12.04
5	25.0	17.00
6	35.5	24.14
7	64.5	43.86
8	75.0	51.00
9	82.3	55.96
10	88.2	59.98
11	93.3	63.44
12	97.9	66.57

Customer GP Test No. _____ Test Team DM
Location Woodland ME. Date Oct 24 1988 KP
Unit CHP Dryer Exhaust Barometer 29.06 in. Hg.
Dry Bulb _____ F.

Dry Bulb F.

Wet Bulb F.

Time 4.30 AM

SP 7/1 in WG
in Hg

Pitot Type 5

Fs for Pitot, 84

64" ID STACK

Sketch (if applicable)

$$1.t_s \text{ (Avg.)} = 140,5 + 460 =$$
$$\underline{600.5} \text{ } T_s \text{ (Rankin)}$$

2. Duct Area = A = 22.34 = 22.34 Sq. Ft.

3. P_s = Barometer $\rightarrow$ SP =

28.98 in. Hg.

$$4.G.D. = \rho_s \left(\frac{530}{T_s} \right) \left(\frac{P_s}{29.92} \right) = 0.0641 \text{ lbs/cu.}$$
$$5. K = \text{Constant} = \frac{1096}{\sqrt{G.D.}} = 4330.4$$
$$6. V = \text{Velocity} = K F_s \sqrt{V_D \text{ Avg.}}$$

3,393.8 ft/mi

7. VOLUME average = $A \times V =$

75,818 ACF

$$8. \text{SCFM} = \text{Volume} \left(\frac{530}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$

64 871.9 SCFM

$$\rho_s = \text{Spec. Wt. of Air} = .075 \text{ lbs/ft}^3$$

α = angle in degree of to yield $0\Delta P$

TRAVERSE DATA & FLOW COMPUTATION

Customer GPTest No. 01Test Team RAWLocation Woodland ME.Date 10/24/88CWUnit ESP InletBarometer 29.06 in. Hg.

Dry Bulb _____ F.

Wet Bulb _____ F.

Time 4:35 AMSP +2.6 in WG
in HgPitot Type SPECFs for Pitot 0.8468" ϕ

SMPL POINT	Vp inches	$\sqrt{V_p}$	Temp. ts F.	ΔP 0°REF.	α°
A1	0.55		188		
2	0.75		193		
3	0.78		195		
4	0.83		198		
5	0.85		201		
6	0.92		203		
7	0.88		204		
8	0.80		206		
9	0.75		207		
10	0.74		207		
11	0.73		207		
12	0.72		206		
B1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
AVERAGE					

Sketch (if applicable)

1. t_s (Avg.) = _____ + 460 =_____ T_s (Rankin)

2. Duct Area = A = _____ =

_____ Sq. Ft.

3. P_s = Barometer + SP =

_____ in. Hg.

4. G.D. = $P_s \left(\frac{530}{T_s} \right) \left(\frac{P_s}{29.92} \right) =$

_____ lbs/cu.

5. K = Constant = $\frac{1096.5}{\sqrt{G.D.}} =$ 6. V = Velocity = $K P_s \sqrt{V_p}$ Avg.

_____ ft/min

7. VOLUME average = $A \times V =$

_____ ACF

 P_s = Spec. Wt. of Air = .075 lbs/ft³# α = angle in degree of to yield $0 \Delta P$ 8. SCFM = Volume $\left(\frac{530}{T_s} \right) \left(\frac{P_s}{29.92} \right) =$

_____ SCFM

Georgia-Pacific/Woodland, Me.

BALANCE Check - AUTOCAL

WASH

RUN#	BEAKER#	FINAL WT.	INITIAL WT.	NET
1-0	2	79.8869	79.8810	.0059
2-0	4	82.3504	82.3433	.0071
3-0	6	77.1396	77.1313	.0083
4-0 BLANK	9	76.3552	76.3550	.0002

FILTERS

RUN#	FILTER #	FINAL	INITIAL	NET
1-0	B 515	.3602	.3459	.0143
2-0	B 518	.3613	.3478	.0135
3-0	B 516	.3640	.3482	.0158

TOTALTOTAL WT.

RUN	NET GAIN (FILTER)	WASH	GAIN
1-0	.0143	.0059	.0202
2-0	.0135	.0071	.0206
3-0	.0158	.0083	.0241

W. Keith Poole
11/2/88

14 Georgia-Pacific, Woodland, Me.
Back Half Evaporations

BALANCE CK-AUTOCAL

RUN #	BEAKER	Alq. (ML)	Final	INITIAL	Net
1-I-1 st	1	50	75.7312	75.5912	.1400
1-I-2 nd	2	50	83.1221	82.9515	.1706
1-O-1 st	3	50	79.5454	79.3560	.1894
1-O-2 nd	4	50	71.8104	71.8004	.0100
2-I-1 st	5	50	79.1855	78.9023	.2832
2-I-2 nd	6	25	76.4546	76.3415	.1131
2-O-1 st	7	50	82.7841	82.6798	.1043
2-O-2 nd	8	50	76.7060	76.5042	.2018
3-I-1 st	9	50	81.6204	81.3783	.2421
3-I-2 nd	10	50	82.1636	81.8864	.2772
3-O-1 st	11	50	66.1229	66.0027	.1202
3-O-2 nd	12	25	77.0985	76.9583	.1402
4-I-1 st	13	50	77.1998	76.8973	.3025
4-I-2 nd	14	50	82.7932	82.5848	.2084
4-O-1 st	15	50	78.5438	78.3183	.2255
4-O-2 nd	16	50	77.8716	77.6807	.1909
BLANK	17	50	74.6279	74.2400	* .0002

* Corrected for NaHSO₂

W. Keith Paul
10/31/88

Georgia-Pacific
Woodland, Me.

15

FRONT HALF EVAPORATIONS

BALANCE CK-AUTOCL

RUN#	BEAKER	FINAL	INITIAL	NET
1-I	1	76.6328	76.5978	.0350
1-O	2	79.8869	79.8810	.0059
2-I	3	82.7868	82.7729	.0139
2-O	4	82.3504	82.3433	.0071
3-I	5	63.4758	63.4405	.0353
3-O	6	77.1396	77.1313	.0083
4-I	7	79.4976	79.4531	.0245
4-O	8	63.3209	63.3180	.0029
BLANK	9	76.3552	76.3550	.0002

FILTERS

RUN	FILTER#	Final	INITIAL	Net
1-I	B 519	.5155	.3453	.1702
2-I	B 520	.4268	.3462	.0806
3-I	B 521	.4086	.3466	.0620
4-I	B 523	.3875	.3447	.0428
1-O	B 515	.3602	.3459	.0143
2-O	B 518	.3613	.3478	.0135
3-O	B 516	.3640	.3482	.0158
4-O	B 522	.3536	.3443	.0093

W. K. Paul
10/3/80

18

Georgia-Pacific
WOODLAND, ME.

BALANCE CK - AUTOCAL

FRONT HALF / BACK HALF COMBINED WEIGHT GAINS.

<u>RUN</u>	<u>Beaker Wt.</u>	<u>FILTER GAIN</u>	<u>TOTAL</u>
1-I	.0350	.1702	.2052
2-I	.0139	.0806	.0945
3-I	.0353	.0620	.0973
4-I	.0245	.0428	.0673
1-0	.0059	.0143	.0202
2-0	.0071	.0135	.0206
3-0	.0083	.0158	.0241
4-0	.0029	.0093	.0122

WK Paul
10/31/88

Research Triangle Laboratories, Inc.

November 3, 1988

Mr. Dan McCombs
Analytical Testing Consultants, Inc.
506 Broad Street
Kannapolis, NC 28081

Dear Mr. McCombs:


We enclose the report for the Method 25 samples analyzed November 2nd. The report consists of a summary table of results, an experimental procedure, a sample calculation, a calibration data sheet, and a set of data reports.

Note that the tank vacuum readings were set equal to the barometric pressures to avoid negative absolute pressures. Note also that the cap on the probe lead of tank EE (Sample #2) was loose.

Let us know if you have any problems. Thank you for choosing us for your Method 25 analyses.

Sincerely,

RESEARCH TRIANGLE LABORATORIES, INC.



John Y. Morimoto
Chemist

JYM

Enclosures

Research Triangle Laboratories, Inc.

prepared for

ANALYTICAL TESTING CONSULTANTS

prepared by .

RESEARCH TRIANGLE LABORATORIES, INC.

Gene Mull

Gene Mull
Chemist

John Y. Morimoto

John Y. Morimoto, Ph.D.
Chemist

RTL ID #88-297
November 3, 1988

RESEARCH TRIANGLE LABORATORIES

METHOD 25 TABLE OF RESULTS

Name: Analytical Testing Consultants

ID #88-80-297

Date: 11/2/88

Sample Number	Sample Description	Concentrations (ppmC)				Mass Conc. (mgC/cu.m)
		CO+CH4	CO2	Noncon- densibles	Condens- sibles	
1	1-I	243	27578	45	668	355
2	1-O	102	20918	38	324	180
3	2-I	393	40208	58	1210	632
4	2-O	69	8412	39	151	95
5	3-I	251	38274	89	456	272
6	3-O	51	10173	14	177	95

Research Triangle Laboratories, Inc.

METHOD 25 EXPERIMENTAL PROCEDURE

Calibration

A propane calibration gas mixture of 74.7 ppm CO, 70.5 ppm CH₄, 2.10% CO₂ and 67.2 ppm propane is injected via a 1 mL sampling loop into the analyzer. The injections are repeated until three integrated areas indicate reasonable (<5%) agreement. A 1.00% CO₂ standard is run daily with the same requirement. The average daily response factors must agree within 5% of the RF(CO₂) and the RF(NMO) from the initial performance check.

Duplicate injections of the propane calibration mix are made prior to each sample analysis. Two injections of the propane mix standard are made after the final sample each day.

Response factors (average integrated area/concentration in ppmC) are calculated daily from the initial triplicate injections.

Analysis

Each trap is stored with dry ice until just prior to analysis and is flushed of CO₂ by passing zero air through it at -78 °C and via the CO₂ NDIR to the sample tank. Flushing is continued until no NDIR response is noted. The trap is baked at 200 °C with zero air flushing through the trap and via the oxidation catalyst and the NDIR into the collection vessel. Collection is continued until no NDIR response is noted. The trap is transferred to an oven set at 350 °C and baking is continued for 30 minutes. This ensures the cleanliness of the trap for a subsequent sampling. The trap is taken out of the oven and allowed to cool; it is then capped and stored for shipment.

The sample tank is analyzed by injecting an aliquot via a 1 mL sample loop into the GC column, which is held at 85 °C to elute the CO+CH₄ and then the CO₂ which is passed to the oxidation catalyst, reduction catalyst, and FID. The column is then backflushed at 195 °C to elute the organic fraction. The collection vessel is analyzed identically. In both cases, triplicate injections are made.

The sample tank is pumped for 5 minutes (to less than 5 mmHg) and air is then allowed in via a paper fiber filter; this procedure is repeated. The tank is pumped 10 minutes and allowed to stand overnight. The tank is then connected to a pressure gauge to test for leaks (maximum permissible leak rate = 10 mmHg/day). If the tank passes the leak test, it is filled with zero air to slightly greater than atmospheric pressure and stored for shipment.

Calculations

Calculations are done in accord with EPA Method 25 procedures. A sample calculation is provided using client/RTL data.

RESEARCH TRIANGLE LABORATORIES
METHOD 25 SAMPLE CALCULATION

Note: All pressure values have been converted when necessary to mm Hg and all temperature values to Kelvin.

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 1 1-I

DATA

Tank 4T42:	Trap DV	Collection Vessel:
Volume (cu.m) = 0.004190		Volume (cu.m) = 0.004551
Pressure	Temp. (K)	Pressure Temp. (K)
(mm Hg)		(mm Hg)
Presampling 0.0 284.3		
Postsampling 664.7 282.0		
Final 1008.0 295.2	Final	1120.0 299.2

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

CO + CH4	33,111	32,828	32,425
CO2	3,717,400	3,728,400	3,727,800
Noncondensibles	6,814	7,155	7,155
Condensibles	75,493	77,036	76,098

CALCULATIONS

Measured Concentrations, corrected for blank:

$$\begin{aligned}
 C_m(CO+CH_4) &= \text{Area}(CO+CH_4) / RF(CO_2) \\
 &= 33111 / 196 = 169.2 \\
 &= 32828 / 196 = 167.7 \\
 &= 32425 / 196 = 165.7
 \end{aligned}$$

$$\begin{aligned}
 C_m(CO_2) &= \text{Area}(CO_2) / RF(CO_2) \\
 &= 3717400 / 196 = 18995.4 \\
 &= 3728400 / 196 = 19051.6 \\
 &= 3727800 / 196 = 19048.5
 \end{aligned}$$

$$\begin{aligned}
 C_m(\text{Noncondensibles}) &= [\text{Area}(\text{Noncondensibles}) - \text{Blank Area (NMO)}] / RF(NMO) \\
 &= (6814 - 681) / 206 = 29.8 \\
 &= (7155 - 681) / 206 = 31.5 \\
 &= (7155 - 681) / 206 = 31.5
 \end{aligned}$$

$$\begin{aligned}
 C_m(\text{Condensibles}) &= \text{Area}(\text{Condensibles}) / RF(CO_2) - \text{Blank}(CO_2) \\
 &= 75493 / 196 - 2.0 = 383.8 \\
 &= 77036 / 196 - 2.0 = 391.6 \\
 &= 76098 / 196 - 2.0 = 386.9
 \end{aligned}$$

Pressure-Temperature Ratio, $Q(i) = P(i)/T(i)$:

postsampling tank: $Q(1) = 664.718 / 282.0389 = 2.356831$

presampling tank: $Q(2) = 0 / 284.2611 = 0$

final tank: $Q(3) = 1008 / 295.15 = 3.415213$

final CV: $Q(4) = 1120 / 299.15 = 3.743941$

Volume Sampled (dscm) = $0.386 \times \text{Tank Volume} \times [Q(1) - Q(2)]$
 $= 0.386 \times .00419 \times [2.3568 - 0.0000]$
 $= 0.003812$

Averages and % Relative Standard Deviations (%RSD) of C_m 's are calculated.
 (%RSD of C = %RSD of C_m)

Calculated Concentrations:

$C(\text{CO} + \text{CH}_4) = Q(3) / [Q(1) - Q(2)] \times C_m(\text{CO} + \text{CH}_4)$
 $= 3.4152 / (2.3568 - 0.0000) \times 167.5 = 242.8$

$C(\text{CO}_2) = Q(3) / [Q(1) - Q(2)] \times C_m(\text{CO}_2)$
 $= 3.4152 / (2.3568 - 0.0000) \times 19031.9 = 27578.5$

$C(\text{Noncondensibles}) = Q(3) / [Q(1) - Q(2)] \times C_m(\text{Noncondensibles})$
 $= 3.4152 / (2.3568 - 0.0000) \times 30.9 = 44.8$

$C(\text{Condensibles})$
 $= \text{Volume}(\text{CV}) / \text{Volume}(\text{Tank}) \times Q(4) / [Q(1) - Q(2)] \times C_m(\text{Condensibles})$
 $= 0.004551 / 0.004190 \times 3.7439 / (2.3568 - 0.0000) \times 387.4 = 668.5$

Total Gaseous Non-Methane Organics (TGNMO) = $C(\text{Noncondensibles}) + C(\text{Condensibles})$
 $= 44.8 + 668.5$
 $= 713.3$

Mass Concentration = $0.498 \times \text{TGNMO}$
 $= 0.498 \times 713.3 = 355.2$

Research Triangle Laboratories, Inc.

SAMPLE QA/QC DATA

METHOD 25 CALIBRATION CHECK

5.1.1 Carrier gas and auxiliary oxygen blank (9/29/87)

$\text{CO} + \text{CH}_4 + \text{CO}_2 + \text{NMO} = 0 \text{ ppm}$ Requirement: $<5 \text{ ppm}$

5.1.2 Catalyst Efficiency Check (10/1/87)

$\text{CO}_2 \text{ ppmC} = 10036$ Requirement: $(\text{CO}_2 \text{ ppmC} = 10000 \pm 200)$

5.1.3 System Performance Check (10/1-2/87)

	Average percent Recovery ($100 \pm 5\%$)	% RSD ($<2\%$)
50 uL Hexane	100.6%	0.2
10 uL Hexane	100.9%	0.2

5.2.1 Oxidation Catalyst Efficiency Check (10/2/87)

FID Response with Reduction Catalyst out = 0.85%

Requirement: $<1\%$ FID Response

5.2.2 Reduction Catalyst Efficiency Check (10/2-9/87)

Response factor of CO_2 with Oxidation Catalyst and Reduction Catalyst operative was 121.2% of response with Catalysts out.

Requirement: Response Factor $>95\%$

5.2.3 Analyzer Linearity Check and NMO Calibration (Initial, 10/4-6/87).

$\overline{\text{RF}}$ Values agree within 2% Requirement: Agree within 2.5%

% RSD values for triplicates $<2\%$ Requirement: % RSD values $<2\%$

$$\frac{\text{RF(NMO)}}{\text{RF(CO}_2\text{)}} = 1.018 \quad \text{Requirement: } \frac{\text{RF(NMO)}}{\text{RF(CO}_2\text{)}} = 1.0 \pm 0.1$$

5.2.4 System Performance check (10/4/87)

	Measured Value	Expected Value	Requirement
Propane Mix	56.6 ppm	56.7 ppm	Expected $\pm 5\%$
Hexane	54.2 ppm	51.8 ppm	Expected $\pm 5\%$
Toluene	60.7 ppm	60.5 ppm	Expected $\pm 5\%$
Methanol	94.2 ppm	92.7 ppm	Expected $\pm 5\%$

5.3 NMO Analyzer Daily Calibration

Mixed propane gas plus high level CO_2 triplicate injections are made at the beginning of the day.

$$\text{DRF(CO}_2\text{)} = \text{RF(CO}_2\text{)} \pm 5\%$$

Requirement: $\text{DRF(NMO)} = \text{RF(NMO)} \pm 5\%$

RESEARCH TRIANGLE LABORATORIES

METHOD 25 DATA REPORT

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 1 1-I

TANK 4T42:

Volume (cu.m) = 0.004190

TRAP DV

COLLECTION VESSEL:

Volume (cu.m) = 0.004551

	Pressure (mm Hg)	Temp.(K)		Pressure (mm Hg)	Temp.(K)
Presampling	0.0	284.3			
Postsampling	664.7	282.0			
Final	1008.0	295.2	Final	1120.0	299.2

Volume Sampled (dscm) = 0.003812

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

	33,111	32,828	32,425
CO + CH4			
CO2	3,717,400	3,728,400	3,727,800
Noncondensibles	6,814	7,155	7,155
Condensibles	75,493	77,036	76,098

Concentrations (ppmC):

	%RSD
CO + CH4	242.7803
CO2	27578.4800
Noncondensibles	44.8059
Condensibles	668.4996
TGNMO	713.3055

(= 355.2261 mgC/cu.m)

RESEARCH TRIANGLE LABORATORIES

METHOD 25 DATA REPORT

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 2 1-0

TANK 4T31:

TRAP EE

COLLECTION VESSEL:

Volume (cu.m) = 0.004215

Volume (cu.m) = 0.004551

	Pressure (mm Hg)	Temp.(K)		Pressure (mm Hg)	Temp.(K)
Presampling	0.0	284.3			
Postsampling	707.9	282.0			
Final	975.0	294.2	Final	1011.0	298.2

Volume Sampled (dscm) = 0.004084

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

CO + CH4	15.260	14.890	15.050
CO2	3,063.400	3,118.200	3,118.000
Noncondensibles	6.814	6.814	6.133
Condensibles	43.871	44.216	43.609

Concentrations (ppmC):

	%RSD
CO + CH4	101.6718
CO2	20918.2900
Noncondensibles	37.9169
Condensibles	324.3123
TGNMO	362.2293

(= 180.3902 mgC/cu.m)

RESEARCH TRIANGLE LABORATORIES

METHOD 25 DATA REPORT

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 3 2-I

TANK 4T20:

Volume (cu.m) = 0.004215

TRAP EZ

COLLECTION VESSEL:

Volume (cu.m) = 0.004551

	Pressure (mm Hg)	Temp.(K)		Pressure (mm Hg)	Temp.(K)
Presampling	0.0	284.3			
Postsampling	484.4	282.0			
Final	1020.0	294.2	Final	1324.0	299.2

Volume Sampled (dscm) = 0.002794

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

CO + CH4	38.306	37.848	38.111
CO2	3,896,600	3,895,800	3,899,000
Noncondensibles	6.133	6.473	7.155
Condensibles	82.878	87.841	85.781

Concentrations (ppmC):

	%RSD
CO + CH4	392.9679
CO2	40207.8000
Noncondensibles	57.9716
Condensibles	1210.1640
TGNMO	1268.1350

(= 631.5313 mgC/cu.m)

RESEARCH TRIANGLE LABORATORIES

METHOD 25 DATA REPORT

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 4 2-0

TANK 4T40:

TRAP CK

COLLECTION VESSEL:

Volume (cu.m) = 0.004190

Volume (cu.m) = 0.004551

	Pressure (mm Hg)	Temp.(K)		Pressure (mm Hg)	Temp.(K)
Presampling	0.0	284.3			
Postsampling	700.3	282.0			
Final	998.0	294.2	Final	996.0	298.2

Volume Sampled (dscm) = 0.004016

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

CO + CH4	10.043	9.718	9.756
CO2	1,207,600	1,202,300	1,204,400
Noncondensibles	6.473	6.473	6.814
Condensibles	20.813	20.646	20.312

Concentrations (ppmC):

	%RSD
CO + CH4	68.7006
CO2	8412.2520
Noncondensibles	39.2315
Condensibles	150.8419
TGNHO	190.0734

(= 94.6566 mgC/cu.m)

RESEARCH TRIANGLE LABORATORIES

METHOD 25 DATA REPORT

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 5 3-I

TANK 4T35:

Volume (cu.m) = 0.004210

TRAP FD

COLLECTION VESSEL:

Volume (cu.m) = 0.004551

	Pressure (mm Hg)	Temp.(K)		Pressure (mm Hg)	Temp.(K)
Presampling	0.0	284.3			
Postsampling	542.8	282.0			
Final	1056.0	293.2	Final	978.0	298.2

Volume Sampled (dscm) = 0.003128

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

CO + CH4	26.018	26.255	26.307
CO2	3,987.400	4,006.400	4,011.500
Noncondensibles	10.798	10.480	10.162
Condensibles	48.424	49.282	48.881

Concentrations (ppmC):

	%RSD
CO + CH4	250.5213
CO2	38274.1700
Noncondensibles	89.1646
Condensibles	456.3717
TGNMO	545.5363

(= 271.6771 mgC/cu.m)

RESEARCH TRIANGLE LABORATORIES

METHOD 25 DATA REPORT

Name: Analytical Testing Consultants

ID #88-80-297 Date: 11/2/88

Sample # 6 3-0

TANK 4T37:

Volume (cu.m) = 0.004190

TRAP AA

COLLECTION VESSEL:

Volume (cu.m) = 0.004551

	Pressure (mm Hg)	Temp.(K)		Pressure (mm Hg)	Temp.(K)
Presampling	0.0	284.3			
Postsampling	697.7	282.0			
Final	1000.0	295.2	Final	1130.0	299.2

Volume Sampled (dscm) = 0.004001

Calibration Data:

	CO2	Backflush
Response Factor (area units/ppmC)	195.7	205.7
Blank (ppmC)	2.0	
Blank Area (area units)		681

Areas:

	7.252	7.342	7.441
CO + CH4			
CO2	1,450.800	1,461.300	1,449.100
Noncondensibles	3.066	3.407	1.704
Condensibles	22.216	21.614	19.909

Concentrations (ppmC):

		%RSD
CO + CH4	51.4014	1.2871
CO2	10173.4400	0.4545
Noncondensibles	13.6133	44.0692
Condensibles	176.7443	5.7379
TGNMO	190.3576	

(= 94.7981 mgC/cu.m)