

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

## **Background Report Reference**

**AP-42 Section Number: 10.6.1**

**Background Report Section: 4**

**Reference Number: 31**

**Title: Results of the November 8 & 9, 1994  
Relative Accuracy Certifications  
At The Louisiana Pacific Plant  
Located in Hayward, Wisconsin**

**Interpoll Laboratories, Inc.**

**November 1994**

RESULTS OF THE NOVEMBER 8 & 9, 1994  
RELATIVE ACCURACY CERTIFICATIONS  
AT THE LOUISIANA PACIFIC PLANT  
LOCATED IN HAYWARD, WISCONSIN

 **interpoll**

---

---



Route 8, Box 8263  
Hayward, Wisconsin 54843  
715/634-3332  
FAX: 715/634-5117

November 23, 1994

Mr. Michael F. Wood, Director  
Mr. Laxmi Kesari  
Multi Media Enforcement & Strategic  
Planning Division U.S. EPA  
Aerials Rios Boulevard  
1200 Pennsylvania N.W., 7th Floor  
Room 7120A  
Washington D.C. 20004

RE: Clean Air Enforcement Action - United States v. Louisiana Pacific Corporation  
No. CV 93-0869 (W.D. La.)

Subject: Continuous Monitoring Equipment Certification: L-P Hayward OSB  
CO, Flow and Opacity Drift Test Results.

Gentlemen:

Enclosed please find the re-certification test results ( Interpoll Labs. Inc. Report # 4-4294 dated November 21, 1994) for the Line #1 Dryer RTO carbon monoxide (CO) and Line #2 Press RTO Flow monitoring systems installed at Louisiana Pacific's OSB plant in Hayward, WI. These are submitted in conjunction with the September 30, 1994 (request for an extension) letter from Elizabeth Smith, Director of Environmental Affairs - Louisiana Pacific Corporation, Portland, Oregon. Attach these test results to you copy of the Interpoll Laboratories, Inc. Report No. 4-3688R dated September 27, 1994. Also enclosed are the Opacity Zero & Calibration Drift calculations of relative accuracy for the four (4) USI Opacity Monitors (one for each of the RTO stacks).

Mr. Michael Wood/Laxmi Kesari  
November 23, 1994  
Page 2

If you have any questions or need additional information please contact me.

Sincerely,



Robert W. Schultz  
Environmental Engineer  
Hayward, WI - Engineering Office

cc w/encls: Tom Parker - Graseby STI  
Jim Lake - Hayward OSB Plant Manager  
Liz Smith - Director of Environmental Affairs  
Jim Ross - WI DNR  
File: HA 613.0 CEMS

cc w/out encls: Julie Domike U.S. EPA  
U.S. EPA, Region 5 Chicago, IL  
Jim Evensen - Hayden Lake  
Keith Seelig - Hayward Environmental  
Bert Krages - Portland  
Norm Radford Jr. - Vinson & Elkins, Dallas, TX  
Brad Pyle - WI DNR Park Falls, WI  
A.E. Cavadeas - Hayward Engineering  
Mark Becker - Hayward Environmental

Interpoll Laboratories, Inc.  
4500 Ball Road N.E.  
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020  
FAX: (612) 786-7854

**RESULTS OF THE NOVEMBER 8 & 9, 1994  
RELATIVE ACCURACY CERTIFICATIONS  
AT THE LOUISIANA PACIFIC PLANT  
LOCATED IN HAYWARD, WISCONSIN**

Submitted to:

**GRASEBY STI**  
45 Fir Street  
Waldron, AR 72958

Attention:

Tom Parker

Reviewed by:



Daniel J. Despen  
Manager  
Stationary Source Testing Department

Report Number 4-4294  
November 21, 1994  
SP/slp

## TABLE OF CONTENTS

ABBREVIATIONS .....	iii
1 INTRODUCTION .....	1
2 SUMMARY AND DISCUSSION .....	3
2.1 Results of Volumetric Flow Rate Determinations .....	6

### APPENDICES:

- A - Sampling Train Calibration Data
- B - Reference Method Results
- C - Field Data Sheets
- D - Measurement Systems Performance Specifications
- E - Calibration Gas Certification Sheets
- F - Gas Analyzer Specifications
- G - CEM Instrument Information Sheet
- H - CEM Data
- I - Operating Data
- J - Procedures
- K - Calculation Equations

## ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 <sup>6</sup> BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm <sup>3</sup>	milligrams per dry standard cubic meter
ug/Nm <sup>3</sup>	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.

## 1 INTRODUCTION

On November 8 & 9, 1994, Interpoll Laboratories personnel conducted Relative Accuracy Certification Tests of the CO CEM installed on the Line 1 Dryer RTO Stack, and the Flow Monitor installed on the Line 2 Press RTO Stack at the Louisiana Pacific Corporation Plant in Hayward, Wisconsin. The certifications were performed on the following:

Monitor				
Type	Manufacturer	Model	Serial No.	Location
CO	TECO	48	48-47743-279	Line 1 Dryer
Flow	United Sciences	100	9401658	Line 2 Press

On-site testing was performed by Ed Trowbridge and Ken Nuessmeier. Coordination between testing activities and plant operation was provided by Bob Schultz of Louisiana Pacific. The test was witnessed by Jim Ross of the Wisconsin Department of Natural Resources.

The Relative Accuracy Certifications were performed in accordance with Specification 4, CFR Title 40, Part 60 Appendix B (revised July 1, 1993). Evaluations were performed in accordance with EPA Method 10 (Ibid: Appendix A). A slip stream of exhaust gas was drawn from the exhaust gas stream using test ports provided by the plant using a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser to remove moisture. The particulate-free dry gas was then split, half the sample was collected directly in 44-Liter Tedlar bags. The other half of the sample gas stream was passed through an alkaline potassium permanganate scrubber to remove interferences and then collected in 44-Liter Tedlar bags. Each set of bags was then analyzed: the scrubbed sample for CO, the unscrubbed sample for O<sub>2</sub> and CO<sub>2</sub>. The CO<sub>2</sub> level was also measured in the scrubbed sample to correct for residual CO<sub>2</sub>. The O<sub>2</sub>, CO<sub>2</sub> and CO analyzers were calibrated on-site using EPA Protocol standard gases. A three-way valve on the probe was used to introduce standard gas for the "system bias check". The analog response of the CO analyzer was recorded using a strip chart recorder. Moisture determinations were performed in accordance with EPA Method 4. Volumetric Flow Rate Determinations were performed in accordance with EPA Method 2.



Twelve 21-minute test runs for CO were performed on the Line 1 Dryer RTO Stack using a 30-minute cycle. During each run, the sample probe was moved through a three-point traverse (1/6, 3/6, 5/6 of the stack dia).

The important results of the tests are summarized in Tables 1 & 2. Field data and all other supporting information are presented in the appendices.

## 2 SUMMARY AND DISCUSSION

The important results of the Relative Accuracy Certifications are summarized in Tables 1 & 2 . No difficulties were encountered in the field or in the data reduction. On the basis of this fact and a complete review of all of the data, it is our opinion that the concentrations reported herein are accurate and closely reflect the actual values which existed at the time the test was performed.

Table 1. Summary of the Results of the November 8, 1994 Relative Accuracy Certification of the CO CEM installed on the Line 1 Driver RTO Stack at the Louisiana Pacific Plant in Hayward, Wisconsin.

Run	Time (HRS)	CO(ppm,d)		
		RM	CEM	DIFF
1	0945-1015	326	306	-20
2	1030-1100	366	360	-6
3	1115-1145	327	320	-7
4	1200-1230	356	353	-3
5*	1245-1315	374	401	27
6	1330-1400	394	389	-5
7*	1415-1445	329	308	-21
8	1500-1530	376	372	-4
9	1545-1615	394	389	-5
10*	1630-1700	411	358	-53
11	1715-1745	363	353	-10
12	1800-1830	291	283	-8
Average				10
Confidence Coefficient				11.5
Standard Deviation				5.13
Relative Accuracy				5.9

\* Note: Runs 5, 7, and 10 not used in the calculation of relative accuracy.

Table 2.

Summary of the Results of the November 9, 1994 Relative Accuracy Certification of the **Flow Monitor** installed on the Line 2 Press Stack at the Louisiana Pacific Plant in Hayward, Wisconsin.

Run	Time (HRS)	Flow (KCFM)		
		RM	CEM	DIFF
1	1000-1030	110	100	-10
2	1045-1115	110	100	-10
3	1200-1230	110	101	-9
4	1245-1315	112	101	-11
5*	1330-1400	111	100	-11
6*	1415-1445	112	101	-11
7*	1500-1530	113	100	-13
8	1545-1615	110	101	-9
9	1630-1700	110	102	-8
10	1715-1745	109	101	-8
11	1800-1830	111	101	-10
12	1845-1915	110	101	-9
Average				10
Confidence Coefficient				0.92
Standard Deviation				1
Relative Accuracy				9.8

\* Note: Runs 5, 6, and 7 not used in the calculation of relative accuracy.

## 2.1 Results of Volumetric Flow Rate Determinations

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1000
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.3
Avg. gas temp.....(DEG-F)	235
Moisture content.....(% V/V)	7.19
Avg. linear velocity.....(FT/SEC)	58.3
Gas density.....(LB/ACF)	.05369
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	355243
Volumetric flow rate.....	
actual.....(ACFM)	110269
dry standard.....(DSCFM)	75404

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1045
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.48
Avg. gas temp.....(DEG-F)	240
Moisture content.....(% V/V)	8.24
Avg. linear velocity.....(FT/SEC)	58.2
Gas density.....(LB/ACF)	.05303
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	350177
Volumetric flow rate.....	
actual.....(ACFM)	110052
dry standard.....(DSCFM)	73790

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1200
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.5
Avg. gas temp.....(DEG-F)	243
Moisture content.....(% V/V)	8.55
Avg. linear velocity.....(FT/SEC)	58.1
Gas density.....(LB/ACF)	.05274
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	347351
Volumetric flow rate.....	
actual.....(ACFM)	109771
dry standard.....(DSCFM)	73032



Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1245
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.55
Avg. gas temp.....(DEG-F)	240
Moisture content.....(% V/V)	6.81
Avg. linear velocity.....(FT/SEC)	59.2
Gas density.....(LB/ACF)	.05332
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	357994
Volumetric flow rate.....	
actual.....(ACFM)	111908
dry standard.....(DSCFM)	76190

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1330
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.46
Avg. gas temp.....(DEG-F)	241
Moisture content.....(% V/V)	6.42
Avg. linear velocity.....(FT/SEC)	58.5
Gas density.....(LB/ACF)	.05333
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	353737
Volumetric flow rate.....	
actual.....(ACFM)	110545
dry standard.....(DSCFM)	75484

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1415
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.47
Avg. gas temp.....(DEG-F)	241
Moisture content.....(% V/V)	8.24
Avg. linear velocity.....(FT/SEC)	59.0
Gas density.....(LB/ACF)	.05296
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	354633
Volumetric flow rate.....	
actual.....(ACFM)	111608
dry standard.....(DSCFM)	74729

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1500
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.42
Avg. gas temp.....(DEG-F)	241
Moisture content.....(% V/V)	7.49
Avg. linear velocity.....(FT/SEC)	59.5
Gas density.....(LB/ACF)	.05312
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	358643
Volumetric flow rate.....	
actual.....(ACFM)	112528
dry standard.....(DSCFM)	75971

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1545
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.43
Avg. gas temp.....(DEG-F)	238
Moisture content.....(% V/V)	7.23
Avg. linear velocity.....(FT/SEC)	58.2
Gas density.....(LB/ACF)	.05340
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	352279
Volumetric flow rate.....	
actual.....(ACFM)	109953
dry standard.....(DSCFM)	74754

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1630
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.41
Avg. gas temp.....(DEG-F)	237
Moisture content.....(% V/V)	6.57
Avg. linear velocity.....(FT/SEC)	58.4
Gas density.....(LB/ACF)	.05362
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	355051
Volumetric flow rate.....	
actual.....(ACFM)	110369
dry standard.....(DSCFM)	75689

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1715
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.4
Avg. gas temp.....(DEG-F)	238
Moisture content.....(% V/V)	6.88
Avg. linear velocity.....(FT/SEC)	57.7
Gas density.....(LB/ACF)	.05348
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	349939
Volumetric flow rate.....	
actual.....(ACFM)	109065
dry standard.....(DSCFM)	74441

Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1800
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.47
Avg. gas temp.....(DEG-F)	236
Moisture content.....(% V/V)	6.95
Avg. linear velocity.....(FT/SEC)	58.8
Gas density.....(LB/ACF)	.05360
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	357559
Volumetric flow rate.....	
actual.....(ACFM)	111172
dry standard.....(DSCFM)	76022



Test No. 2  
Line 2 Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	11-09-94
Time of Determination.....(HRS)	1845
Barometric pressure.....(IN.HG)	29.02
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.48
Avg. gas temp.....(DEG-F)	235
Moisture content.....(% V/V)	6.99
Avg. linear velocity.....(FT/SEC)	58.4
Gas density.....(LB/ACF)	.05367
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	355364
Volumetric flow rate.....	
actual.....(ACFM)	110349
dry standard.....(DSCFM)	75536

## APPENDIX A

### SAMPLING TRAIN CALIBRATION DATA

## Interpoll Laboratories, Inc.

Temperature Measurement Device  
Calibration Sheet

Unit under test:

Vendor OMEGA  
 Model OMEGA Serial Number #38  
 Range 0 - 2000 °F Thermocouple Type K  
 Date of Calibration 10/28/1994 Technician K. Nussmeier

## Method of Calibration:

- ☐ Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- ☐ Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is  $\pm 0.1\%$  of span (2100 °F)  $\pm 1$  degree (for negative temperatures add  $\pm 2$  degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			$\Delta t$ (°F)	(%)
0	TEMP 0	4	-4	.17
100	100	97	3	.53
200	200	200	0	0
300	300	299	1	.33
400	400	399	1	.25
500	500	499	2	.20
600	600	600	0	0
700	700	699	1	.14
800	800	801	-1	-.07
900	900	899	1	.11
1000	1000	1001	-1	-.06
1100	1100	1099	1	.09
1200	1200	1202	-2	-.17
1300	1300	1299	1	.08
1400	1400	1401	-1	-.07
1500	1500	1500	0	0
1600	1600	1602	-2	-.13
1700	1700	1701	-1	-.06
1800	1800	1803	-3	-.17
1900	1900	1901	-1	-.05
2000	2000	2001	-1	-.05
2100	2100	2099	1	.05
Averages:			1.27	.096

OF = off scale response by unit under test (°F)  
 $\% \text{ dev} = 100 \Delta t / (460 + t)$

- ☐ Unit in tolerance  
☐ Unit was not in tolerance: recalibrated - See new calibration sheet.

$$\frac{(100)(4)}{460 + 0}$$

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 27-8

Pitot tube dimensions:

1. External tubing diameter ( $D_t$ ) 3.16 IN.
2. Base to Side A opening plane ( $P_A$ ) 4.60 IN.
3. Base to Side B opening plane ( $P_B$ ) 4.60 IN.

Alignment:

4.  $\alpha_1$   $< 10^\circ$  0
5.  $\alpha_2$   $< 10^\circ$  0
6.  $B_1$   $< 5^\circ$  0
7.  $B_2$   $< 5^\circ$  0
8. Z  $< .125"$  0
9. W  $< .0625"$  .01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle 1.750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 1.760 IN.

- ☒ Meets all EPA design criteria thus  $C_p = 0.84$   
☐ Does not meet EPA design criteria - thus calibrate in wind tunnel.  
 $C_p =$  \_\_\_\_\_

Date of Inspection:

4-7-94

Inspected by:

E. J. [Signature]

## INTERPOLL LABORATORIES

(612)786-6020

Stack Sampling Department - QA  
Aneroid Barometer Calibration Sheet

Date 10-28-94  
Technician E. Trowbridge  
Mercury Column Barometer No. ULTIMETER MODEL 12  
Aneroid Barometer No. SN - 01002008

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P <sub>ba</sub> -P <sub>bm</sub> )
28.75	80	.134	28.616	28.58	.036

Has this barometer shown any consistent problems with calibration? Yes/No. If  
yes, explain. No

Has problem been alleviated? Yes/No. How? \_\_\_\_\_

**\*Note**

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

S-312

## APPENDIX B

### REFERENCE METHOD RESULTS

Report No. 4-4294							
GRASEBY ST1 - LP HAYWARD							
Hayward, Wisconsin							
Source: Line 1 Dryer RTO Stack							
RUN 1	O2	CO	CO2	RUN 2	O2	CO	CO2
0945-1015				1030-1100			
1	16.8	380	3.9	1	16.4	439	4.1
2	16.7	411	3.9	2	16.4	469	4.2
3	16.6	452	4.0	3	16.4	398	4.1
4	16.6	339	3.8	4	16.3	368	4.2
5	16.8	302	3.7	5	16.6	348	3.9
6	16.6	335	4.0	6	16.7	362	3.9
7	17.1	304	3.5	7	16.4	495	4.3
8	16.7	433	4.0	8	16.1	486	4.4
9	16.4	435	4.1	9	16.1	402	4.3
10	16.5	415	4.1	10	16.3	401	4.2
11	16.5	432	4.1	11	16.4	427	4.2
12	16.9	459	3.5	12	16.3	520	4.3
13	17.3	459	3.2	13	16.1	409	4.4
14	16.9	270	3.7	14	16.4	403	4.1
15	16.9	298	3.7	15	16.4	361	4.1
16	16.5	384	4.0	16	16.8	338	3.9
17	16.8	328	3.5	17	16.7	354	3.9
18	17.1	350	3.6	18	16.5	313	4.0
19	17.7	314	2.7	19	16.6	283	3.9
20	17.6	220	3.0	20	16.6	276	3.9
21	17.6	218	3.0	21	16.8	279	3.8
22	16.9	325	3.3	22	16.6	354	4.0
23	17.9	279	2.6	23	16.5	282	4.0
24	17.6	237	3.3	24	16.7	274	3.9
25	17.9	217	2.8	25	16.6	286	3.9
26	17.6	208	3.1	26	16.7	323	3.9
27	18.3	242	2.3	27	16.6	380	4.0
28	17.3	310	3.4	28	16.4	334	4.1
29	18.0	223	2.5	29	16.5	316	4.0
30	17.2	214	3.3	30	16.5	307	4.0
Average	17.1	326	3.45	Average	16.5	366	4.06

from, d

							Report No. 4-4294	
GRASEBY STI - LP HAYWARD								
Hayward, Wisconsin								
Source: Line 1 Dryer RTO Stack								
RUN 3	O2	CO	CO2		RUN 4	O2	CO	CO2
1115-1145					1200-1230			
1	16.5	338	3.9		1	16.4	392	3.9
2	16.3	351	4.1		2	16.4	356	4.0
3	16.3	322	4.1		3	16.5	381	4.0
4	16.3	343	4.1		4	16.5	357	3.9
5	16.5	314	4.0		5	16.6	416	4.0
6	16.4	347	4.0		6	16.5	424	4.1
7	16.4	333	4.1		7	16.4	370	4.1
8	16.3	299	4.1		8	16.5	357	4.0
9	16.4	325	4.1		9	16.7	309	3.8
10	16.5	310	4.0		10	16.7	358	3.8
11	16.5	353	4.1		11	16.5	352	3.9
12	16.2	339	4.2		12	16.6	298	3.9
13	16.3	334	4.2		13	16.7	296	3.8
14	16.4	318	4.1		14	16.7	316	3.8
15	16.5	312	4.1		15	16.7	368	3.9
16	16.4	372	4.1		16	16.5	359	4.0
17	16.2	370	4.2		17	16.6	314	3.9
18	16.4	321	4.0		18	16.5	322	3.9
19	16.4	308	3.9		19	16.7	320	3.8
20	16.6	320	3.9		20	16.7	370	3.8
21	16.4	426	4.2		21	16.5	361	3.9
22	16.2	362	4.2		22	16.5	346	4.0
23	16.4	315	4.0		23	16.5	330	3.9
24	16.4	300	4.0		24	16.8	340	3.8
25	16.6	288	3.9		25	16.5	447	4.0
26	16.7	342	3.9		26	16.3	386	4.1
27	16.4	315	4.1		27	16.5	353	4.0
28	16.5	286	3.9		28	16.5	327	3.9
29	16.5	269	3.9		29	16.7	341	3.8
30	16.7	274	3.8		30	16.6	412	3.9
Average	16.4	327	4.04		Average	16.6	356	3.92



Report No. 4-4294

GRASEBY STI - LP HAYWARD  
Hayward, Wisconsin

Source: Line 1 Dryer RTO Stack

RUN 5	O2	CO	CO2	RUN 6	O2	CO	CO2
1245-1315				1330-1400			
1	16.4	376	3.8	1	16.4	355	3.9
2	16.5	358	3.8	2	16.5	455	3.8
3	16.6	316	3.7	3	16.5	404	3.8
4	16.6	393	3.9	4	16.4	409	4.0
5	16.4	418	3.9	5	16.2	362	4.0
6	16.4	337	3.9	6	16.4	395	4.0
7	16.5	345	3.8	7	16.4	385	3.9
8	16.6	302	3.7	8	16.5	451	3.9
9	16.6	418	4.0	9	16.4	447	4.0
10	16.4	389	3.9	10	16.4	416	4.0
11	16.5	318	3.8	11	16.5	421	4.0
12	16.5	340	3.9	12	16.7	396	3.8
13	16.7	340	3.7	13	16.5	433	3.9
14	16.6	380	3.7	14	16.5	398	3.9
15	16.5	377	3.9	15	16.4	378	3.9
16	16.7	287	3.9	16	16.4	382	3.9
17	16.6	308	3.8	17	16.6	371	3.8
18	16.6	332	3.8	18	16.8	428	3.8
19	16.5	393	3.9	19	16.4	403	4.0
20	16.3	378	4.0	20	16.3	420	4.0
21	16.3	376	4.0	21	16.3	406	4.0
22	16.4	377	4.0	22	16.5	441	3.9
23	16.6	377	3.8	23	16.4	533	4.1
24	16.5	445	3.9	24	16.2	427	4.0
25	16.4	417	4.0	25	16.3	399	3.9
26	16.3	427	4.1	26	16.7	249	3.5
27	16.2	397	4.1	27	17.3	215	3.2
28	16.4	424	4.0	28	16.9	299	3.6
29	16.4	487	4.0	29	16.6	255	3.9
30	16.3	401	4.0	30	16.3	482	4.1
Average	16.5	374	3.89	Average	16.5	394	3.88

							Report No. 4-4294	
GRASEBY STI - LP HAYWARD								
Hayward, Wisconsin								
Source: Line 1 Dryer RTO Stack								
RUN 7	O2	CO	CO2		RUN 8	O2	CO	CO2
1415-1445					1500-1530			
1	17.2	279	3.5		1	16.7	356	3.6
2	16.8	231	3.0		2	16.6	361	3.8
3	17.3	256	3.4		3	16.5	325	3.8
4	16.8	255	3.7		4	16.5	375	3.9
5	16.7	316	3.7		5	16.5	334	3.8
6	16.6	321	3.7		6	16.6	395	3.8
7	16.5	401	3.9		7	16.4	384	3.9
8	16.4	380	3.9		8	16.4	342	3.9
9	16.5	355	3.9		9	16.5	349	3.8
10	16.7	222	3.4		10	16.6	358	3.8
11	17.5	161	3.0		11	16.5	401	3.8
12	17.2	191	3.2		12	16.4	390	4.0
13	17.1	193	3.3		13	16.2	365	4.0
14	16.8	225	3.5		14	16.3	377	4.0
15	16.6	357	3.9		15	16.6	367	3.8
16	16.6	424	3.8		16	16.6	453	3.8
17	16.5	546	3.9		17	16.5	384	3.9
18	16.3	493	3.9		18	16.5	411	3.9
19	16.5	419	3.8		19	16.4	404	3.9
20	16.5	329	3.7		20	16.5	449	3.9
21	17.5	156	2.9		21	16.4	526	3.9
22	17.5	171	3.0		22	16.2	483	4.1
23	16.9	166	3.3		23	16.3	433	4.0
24	17.1	194	3.2		24	16.7	318	3.5
25	16.7	293	3.2		25	16.9	283	3.5
26	16.6	391	3.8		26	16.7	365	3.6
27	16.5	554	3.9		27	16.5	329	3.8
28	16.2	502	4.1		28	16.6	329	3.7
29	16.3	538	4.1		29	16.5	314	3.7
30	16.1	561	4.2		30	16.7	333	3.7
Average	16.8	329	3.59		Average	16.5	376	3.82

Report No. 4-4294							
GRASEBY STI - LP HAYWARD							
Hayward, Wisconsin							
Source: Line 1 Dryer RTO Stack							
RUN 9	O2	CO	CO2	RUN 10	O2	CO	CO2
1545-1615				1630-1700			
1	16.3	417	4.0	1	16.2	487	4.1
2	16.4	374	3.9	2	16.3	478	4.1
3	16.5	361	3.8	3	16.5	395	3.8
4	16.7	364	3.7	4	16.6	413	3.7
5	16.6	459	3.8	5	16.5	344	3.8
6	16.3	418	3.9	6	16.4	365	3.8
7	16.4	384	3.9	7	16.5	359	3.8
8	16.4	386	3.9	8	16.6	388	3.8
9	16.6	376	3.8	9	16.6	443	3.8
10	16.4	457	3.9	10	16.4	417	3.9
11	16.3	399	3.9	11	16.3	418	4.0
12	16.4	392	3.9	12	16.4	381	3.9
13	16.4	364	3.8	13	16.7	400	3.8
14	16.7	386	3.7	14	16.6	475	3.8
15	16.6	454	3.8	15	16.3	435	3.9
16	16.4	385	3.9	16	16.5	400	3.8
17	16.5	372	3.8	17	16.5	395	3.8
18	16.5	346	3.8	18	16.6	413	3.8
19	16.7	371	3.7	19	16.5	473	3.8
20	16.6	436	3.8	20	16.4	451	3.9
21	16.3	395	4.0	21	16.4	486	3.9
22	16.4	392	3.9	22	16.3	424	3.9
23	16.5	348	3.7	23	16.7	406	3.7
24	16.6	431	3.8	24	16.6	451	3.8
25	16.5	428	3.8	25	16.4	409	3.9
26	16.4	385	3.8	26	16.6	414	3.8
27	16.5	403	3.9	27	16.8	361	3.6
28	16.5	364	3.8	28	16.8	360	3.6
29	16.6	383	3.7	29	16.7	373	3.6
30	16.6	395	3.8	30	16.7	316	3.6
Average	16.5	394	3.83	Average	16.5	411	3.82

Report No. 4-4294							
GRASEBY STI - LP HAYWARD							
Hayward, Wisconsin							
Source: Line 1 Dryer RTO Stack							
RUN 11	O2	CO	CO2	RUN 12	O2	CO	CO2
1715-1745				1800-1830			
1	16.5	413	3.8	1	17.0	259	3.3
2	16.6	410	3.8	2	17.0	334	3.4
3	16.6	480	3.8	3	16.7	317	3.6
4	16.4	428	3.9	4	16.7	288	3.6
5	16.5	395	3.9	5	16.7	280	3.5
6	16.5	382	3.8	6	17.0	275	3.4
7	16.7	388	3.7	7	17.0	324	3.4
8	16.6	482	3.8	8	16.7	308	3.6
9	16.4	421	3.8	9	16.7	284	3.6
10	16.5	403	3.9	10	16.7	273	3.5
11	16.5	379	3.8	11	16.8	322	3.6
12	16.7	394	3.7	12	16.8	370	3.6
13	16.6	490	3.8	13	16.6	322	3.8
14	16.4	385	3.9	14	16.7	310	3.7
15	16.6	360	3.8	15	16.7	317	3.7
16	16.7	326	3.6	16	16.9	333	3.6
17	16.8	362	3.6	17	16.7	409	3.8
18	16.7	435	3.7	18	16.7	290	3.7
19	16.7	302	3.6	19	16.9	244	3.6
20	16.8	264	3.5	20	17.0	181	3.4
21	16.8	250	3.4	21	17.5	189	3.1
22	17.0	270	3.3	22	17.1	306	3.4
23	17.0	289	3.4	23	16.8	320	3.7
24	16.7	257	3.5	24	16.7	328	3.8
25	16.9	244	3.5	25	16.9	233	3.6
26	16.8	246	3.4	26	17.1	253	3.4
27	16.9	319	3.5	27	17.0	311	3.6
28	16.6	398	3.7	28	16.8	271	3.6
29	16.5	344	3.8	29	17.0	257	3.4
30	16.6	361	3.7	30	17.0	229	3.3
Average	16.7	363	3.68	Average	16.9	291	3.54


## APPENDIX C

### FIELD DATA SHEETS

## EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRASSBY/STI A/HAVENED  
Source LINE 2 RTI TRUSS STACK  
Test 2 Run 1 Date 11-9-94  
Stack Dimen. 76 IN.  
Dry Bulb 239 °F Wet bulb 119 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -1.30 IN.WC  
Operators E. TROWBRIDGE K. NESSURICK  
Pitot No. 27V-8 C 84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6 IN.	Time Start: 1000	HRS
A 1	.032	2.43	8.43	.72	
2	.105	7.98	13.98	.75	
3	.194	14.74	20.74	.72	
4	.323	24.55	30.55	.78	231
5	.677	51.45	57.45	.98	
6	.406	61.25	67.25	.95	
7	.895	68.02	74.02	.75	
8	.968	73.57	79.57	.73	
B 1				.70	
2				.82	
3				.88	239
4				.88	
5				.80	
6				.70	
7				.68	
8				.60	
		TS-235			
		FPS - 57.88			
		ALFM-109419			
		DSCM - 78148			
Temp. Meas. Device & S/N: PDT-38				Time End: 1030 HRS	


R or nothing - reg. manometer; S - expanded; E - electronic

Time End: 1130 HRS

# EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GLASBY ST/CP HAYWARD  
Source AREA 2 FLOSS RTD STACK  
Test 2 Run 2 Date 11-9-44  
Stack Dimen. 76 IN.  
Dry Bulb 241 °F Wet bulb 122 °F  
Manometer ☐ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -1.45 IN.WC  
Operators ETGKH  
Pitot No. 274-8 C<sub>p</sub> 1.84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start: 1045 HRS	
A 1				.80	
2				.78	
3				.85	
4				.80	239
5				.82	
6				.90	
7				.75	
8				.73	
B 1				.70	
2				.80	
3				.88	
4				.88	241
5				.85	
6				.65	
7				.62	
8				.52	
				.	
		5757			
	AVIA	108836			
		7725 Z			
Temp. Meas. Device & S/N: PDT 38				Time End: 1115 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

(612) 786-6020

# EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRISOBY STEEL PLANT  
Source LINE 2. LOSS RTD STACK  
Test 2 Run 3 Date 11-9-94  
Stack Dimen. 76 IN.  
Dry Bulb            °F Wet bulb 123 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.  
Static Pressure -1.50 IN.  
Operators ET-KN  
Pitot No. 27V-8 C 184

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length:		IN.	Time Start: 1200 HRS		
A 1				1.56	
2				.88	
3				.86	
4				.90	
5				.84	243
6				.78	
7				.65	
8				.63	
B 1				.40	
2				.62	
3				.78	
4				.85	244
5				.82	
6				.78	
7				.88	
8				.68	
TS 243.5					
FPS 57.45					
ACFM - 108601					
DSCFM - 76588					
Temp. Meas. Device & S/N: PDT 38				Time End: 1230 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Time End: 1230 HRS



## EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRABBY STI  
Source CINE 2 PRESS RPD STACK  
Test 2 Run 4 Date 11-9-94  
Stack Dimen. 76 IN.  
Dry Bulb            °F Wet bulb 118 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -1.55 IN.WC  
Operators ET 2KN  
Pitot No. 274-8 C<sub>n</sub> .54

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start: 1245	HRS
A 1				.85	
2				.78	
3				.84	
4				.90	
5				.80	241
6				.75	
7				.70	
8				.78	
B 1				.60	
2				.72	
3				.76	
4				.92	239
5				.85	
6				.94	
7				.74	
8				.76	
	TS	240			
	LCFM	111043			
	DSCFM	78091			
Temp. Meas. Device & S/N: PDT 38			Time End: 1315 HRS		

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:\STACK\WP\FORMS\S-392.1

(612) 786-6020

### Drawing of Test Site

Cross-section View	Elevation View

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start: 1330	HRS
A 1				.57	
2				.88	
3				.85	
4				.88	242
5				.84	
6				.80	
7				.74	
8				.72	
B 1				.52	
2				.65	
3				.76	
4				.78	240
5				1.00	
6				.90	
7				.84	
8				.70	
	T <sub>c</sub>	241			
	ACFM	109772			
	DSCFM	77698			
Temp. Meas. Device & S/N: PNT 38				Time End: 1400 HRS	

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOL LABORATORIES, INC.  
(612) 786-6020  
EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRASB, STI  
Source Line 2 Power R/O Stack  
Test 2 Run 6 Date 11-2-94  
Stack Dimen. 74 IN.  
Dry Bulb            °F Wet bulb 122 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -1.47 IN.WC  
Operators ET - KN  
Pitot No. 27Y-8 C<sub>u</sub> .84

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start:	1415 HRS
A 1				.65	
2				.78	
3				.86	245
4				.95	
5				.84	
6				.70	
7				.87	
8				.68	
B 1				.58	239
2				.78	
3				.70	
4				.80	
5				.88	
6				.96	
7				.85	
8				.68	
	TS				
	ACFM	110518			
	DSCFM	78112			
Temp. Meas. Device & S/N: RDT-38				Time End: 1445 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1

## EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRISBY STI/CP HAWARD  
Source LIND PASS RTO STACK  
Test 2 Run 7 Date 11-9-94  
Stack Dimen. 76 IN.  
Dry Bulb            °F Wet bulb 120 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -4.2 IN.WC  
Operators ET-KN  
Pitot No. 27V-8 C. 84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start: 1500	HRS
A 1				.58	
2				.77	
3				.85	244
4				.95	
5				.88	
6				.75	
7				.95	
8				.80	
B 1				.60	238
2				.67	
3				.78	
4				.90	
5				1.00	
6				.98	
7				.85	
8				.62	
	TS	241			
	ACFM	111512			
	DSCFM	78457			
Temp. Meas. Device & S/N: PDT 38				Time End: 1530 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:\STACK\WP\FORMS\S-392.1

# EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRASSBY ST I  
Source Line 2 Press HTV Stock  
Test 2 Run S Date 11-9-94  
Stack Dimen. 76 IN.  
Dry Bulb        °F Wet bulb 119 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -.43 IN.WC  
Operators ET-KN  
Pitot No. 27V-8 C<sub>p</sub> 184

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

R or nothing = reg. manometer; S = expanded; E = electronic

## EPA Method 2 Field Data Sheet

Elevation  
View

Pitot No. 271-8 C, 840

Temp. Meas. Device & S/N: ADT 38 Time End: 1730 HRS

Time End: / 700 HRS

## EPA Method 2 Field Data Sheet

Elevation  
View

Pitot No. 27V-8 C<sub>1</sub>, 84

Temp. Meas. Device & S/N:	PTT-38	Time End: 1745 HRS
---------------------------	--------	--------------------

C-10

### Drawing of Test Site

Cross-section View	Elevation View
--------------------	----------------

R or nothing - reg. manometer; S - expanded; E - electronic



INTERPOLL LABORATORIES, INC.

(612) 786-6020

# EPA Method 2 Field Data Sheet

### Drawing of Test Site

Job GRABBY SIT  
Source Low 2 Press RTD STACK  
Test 2 Run 2 Date 11-9-92  
Stack Dimen. 76 IN.  
Dry Bulb            °F Wet bulb 115 °F  
Manometer ☒ Reg. ☐ Exp ☐ Elec.  
Barometric Pressure 29.02 IN.HG  
Static Pressure -1.48 IN.WC  
Operators ET-LN  
Pitot No. 27K-8 C, 840

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start: 1845	HRS
A 1				1.58	
2				1.72	
3				1.92	234
4				1.85	
5				1.94	
6				1.80	
7				1.70	
8				1.78	
B 1				1.52	236
2				1.65	
3				1.73	
4				1.92	
5				1.84	
6				1.00	
7				1.88	
8				1.65	
TS		235			
ACFM		109450			
DSCFM		78155			
Temp. Meas. Device & S/N: PDT 38			Time End: 1915 HRS		

R or nothing - reg. manometer; S - expanded; E - electronic

## APPENDIX D

### MEASUREMENT SYSTEM PERFORMANCE SPECIFICATIONS

## INTERPOLL LABORATORIES

## Calibration Error Check

Job GRASBY/STITest 1 Run 0 Date 11-7-94Operator [Signature]

CO Calibration:

Time (HRS) \_\_\_\_\_

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	1000	0
Mid level	249	250	1	1000	
High level	594	592	2	1000	

NO<sub>x</sub> Calibration:

Time (HRS) \_\_\_\_\_

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

O<sub>2</sub> Calibration:

Time (HRS) \_\_\_\_\_

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	25	0
Mid level	13.5	0	0	25	0
High level	21.2	21.0	2	25	

CO<sub>2</sub> Calibration:

Time (HRS) \_\_\_\_\_

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	20	0
Mid level	10.9	0	0	20	0
High level	16.4	16.4	0	20	0

Must be within 2% of the span for each calibration gas

S-420-10

## INTERPOLL LABORATORIES, INC

(612) 786-6020

CO System Bias CheckJob GRASEP/STI - LPHAYWARDSource LINDI DYER RTOTest 1 Run 1 Date 1-8-94Site STACK

Operator \_\_\_\_\_

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0850	Zero Gas	0	0	0	0	1000	0
		Upscale	594	592	592	0	1000	0
2	1020	Zero Gas	0	0	2	2	1000	.2
		Upscale	594	592	587	5	1000	.5
3	1105	Zero Gas	0	0	1	1	1000	
		Upscale	594	592	588	4	1000	.4
4	1148	Zero Gas	0	0	2	2	1000	.2
		Upscale	594	592	586	6	1000	.6
5	1232	Zero Gas	0	0	2	2	1000	.2
		Upscale	594	592	584	8	1000	.8
6	1317	Zero Gas	0	0	1	1	1000	.1
		Upscale	594	592	585	7	1000	.7
7	1404	Zero Gas	0	0	2	2	1000	.2
		Upscale	594	592	582	10	1000	1.0
8	1447	Zero Gas	0	0	3	3	1000	.3
		Upscale	594	592	586	6	1000	.6
9	1532	Zero Gas	0	0	2	2	1000	.2
		Upscale	594	592	582	10	1000	1.0
10	1617	Zero Gas	0	0	3	3	1000	.3
		Upscale	594	592	583	9	1000	.9
11	1702	Zero Gas	0	0	4	4	1000	.4
		Upscale	594	592	583	9	1000	.9
12	1747	Zero Gas	0	0	3	3	1000	.3
		Upscale	594	592	587	5	1000	.5

Must be within 5% of the span for the zero or upscale cal. gas.

## INTERPOL LABORATORIES, INC

(612) 786-6020

02 System Bias Check

Job

CR-50 BUST

Source

LIN-1 DRIVE RTO

Test

Run 0Date 11-5-86

Site

STACK

Operator

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0850	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
2	1020	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
3	1105	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
4	1148	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
5	1232	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
6	1317	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
7	1404	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
8	1447	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
9	1532	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
10	1617	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
11	1702	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.6	.1	25	.4
12	1747	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.6	.1	25	.4

Must be within 5% of the span for the zero or upscale cal. gas.

033194-C:STACK\WP\FORM55-420-11

## INTERPOL LABORATORIES, INC

(612) 786-6020

CO2 System Bias CheckJob GRASB1STTSource LINCOLN DRILLINGTest 1 Run 11570 Date 11/5/70Site STACKOperator F T KOWALSKI

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0850	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.4	0	20	0
2	1020	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.9	0	20	0
3	1105	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.9	0	20	0
4	1148	Zero Gas	0	0	0.1	0.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
5	1232	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
6	1317	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
7	1404	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
8	1447	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
9	1532	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.8	.1	20	.5
10	1617	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.8	.1	20	.5
11	1702	Zero Gas	0	0			20	
		Upscale	10.9	10.9	10.8	.1	20	.5
12	1747	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.9	0	20	0

Must be within 5% of the span for the zero or upscale cal. gas.

## INTERPOLL LABORATORIES, INC

(612) 786-6020

02 System Bias Check

Job

GLASCOBY STILLER HAYWARD

Source

Line 2 Pure RTO

Test

2 Run 1-12 Date 11-9-94

Site

STACK

Operator

E. T. M. C. C. C.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0930	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
2	1032	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
3	1120	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
4	1234	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
5	1317	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
6	1402	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
7	1447	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.6	.1	25	.4
8	1532	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.6	.1	25	.4
9	1617	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
10	1702	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
11	1747	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
12	1832	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.4

Must be within 5% of the span for the zero or upscale cal. gas.

033194-G:STACKWPFORMSS-420-11

## INTERPOL LABORATORIES, INC

(612) 786-6020

CO2 System Bias Check

Job

GLASSBY STI/UP HAWK

Source

Line 2 Pave PTC

Test

2

Run

Date

11-4-94

Site

STACK

Operator

W. J. [Signature]

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.9	0	20	0
2	1032	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
3	1120	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	11.0	.1	20	.5
4	1234	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
5	1317	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
6	1402	Zero Gas	0	0	0	0.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
7	1447	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	11.0	.1	20	.5
8	1532	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
9	1617	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0
10	1702	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	11.0	.1	20	.5
11	1747	Zero Gas	0	0	0	0	20	0
		Upscale	10.9	10.9	10.9	0	20	0
12	1832	Zero Gas	0	0	.1	.1	20	.5
		Upscale	10.9	10.9	10.9	0	20	0

Must be within 5% of the span for the zero or upscale cal. gas.



## INTERPOLL LABORATORIES, INC

(612) 786-6020

02 System Bias Check

Job

GRABER/STI-LP/HAYWARD

Source

LINE 2 PRESS BTD

Test

2

Run

1-12

Date

11-9-94

Site

Stack

Operator

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
13	1417	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
2		Zero Gas	0					
		Upscale						
3		Zero Gas	0					
		Upscale						
4		Zero Gas	0					
		Upscale						
5		Zero Gas	0					
		Upscale						
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

033194-G:\STACK\WP\FORMS\5-420-11

## APPENDIX E

### CALIBRATION GAS CERTIFICATION SHEETS



# Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063-0000  
PHONE: 313-589-2950 FAX: 313-589-2134

8/02/91

GENEX  
4018 DUNCAN AVENUE

PROJECT #: 05-26600  
PO #: 4970SA

ST LOUIS

MO 63110-0000

CYLINDER #: AAL19103

ANALYTICAL ACCURACY: +-2%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 ( MOLES) U/M
CARBON MONOXIDE	250.0 PPM	249. PPM
NITROGEN	BALANCE	N/A

NOTES: CERTIFIED MASTER GAS

ANALYTICAL METHOD: CMG

DATE OF ANALYSIS: 7/29/91

ANALYST

ANALYST

APPROVED BY:

SUPERVISOR



# Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063-0000  
PHONE: 313-589-2950 FAX: 313-589-2134

8/02/91

GENEX  
4018 DUNCAN AVENUE

PROJECT #: 05-26600  
PO #: 4970SA

ST LOUIS

MO 63110-0000

CYLINDER #: ALM020902

ANALYTICAL ACCURACY: +-2%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 ( MOLES) U/M
CARBON MONOXIDE	600.0 PPM	594. PPM
NITROGEN	BALANCE	N/A

NOTES: CERTIFIED MASTER GAS

ANALYTICAL METHOD: CMG

DATE OF ANALYSIS: 7/29/91

ANALYST:

ANALYST

APPROVED BY:

SUPERVISOR

NATIONAL SPECIALTY GASES  
630 UNITED DRIVE  
DURHAM, N.C. 27713  
(919) 544-3772

TO: TWIN CITY OXYGEN

CERTIFICATE OF ANALYSIS

DATE REPORTED: 9/29/94

REFERENCE #: 88-34130

MATERIAL SUBMITTED: OXYGEN, CARBON DIOXIDE IN NITROGEN,  
CERTIFIED CYL. #CC111962

INFORMATION REQUESTED: RATIO ANALYSIS

METHOD OF ANALYSIS: OXYGEN ANALYZER, INFRARED

RESULT OF INVESTIGATION:

---

<u>COMPONENT</u>	<u>SPECIFICATION</u>	<u>CONCENTRATION</u>
OXYGEN	13.5%	13.5%
CARBON DIOXIDE	11%	10.9%
NITROGEN		BALANCE

---

  
AUTHORIZED SIGNATURE

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

NATIONAL SPECIALTY GASES  
630 UNITED DRIVE  
DURHAM, N.C. 27713  
(919) 544-3772

TO: TWIN CITY OXYGEN

CERTIFICATE OF ANALYSIS

DATE REPORTED: 12/13/93

REFERENCE #:88-28413

MATERIAL SUBMITTED: CARBON DIOXIDE AND OXYGEN IN NITROGEN,  
CERTIFIED CYL. #CC112272

INFORMATION REQUESTED: RATIO ANALYSIS

METHOD OF ANALYSIS: INFRARED AND OXYGEN ANALYZERS

RESULT OF INVESTIGATION:

---

<u>COMPONENT</u>	<u>SPECIFICATION</u>	<u>CONCENTRATION</u>
CO2	17%	16.4%
O2	21%	21.2%
N2		BALANCE

---

  
AUTHORIZED SIGNATURE

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

## APPENDIX F

### GAS ANALYZER SPECIFICATIONS

SPECIFICATIONS FOR ACS MODEL 3300 CO NDIR

Measuring principle	NDIR single beam method
Operating ranges	0 - 500 ppm 0 - 1000 ppm
Reproducibility	$\pm 0.5\%$ of full scale
Stability	Zero drift; $\pm 1\%$ of full scale/24H Span drift; $\pm 1\%$ of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500 $\Omega$ max.)
Linearity	Better than $\pm 2\%$ of full scale (when linearizer is used)
Power supply	AC 115 V $\pm 10\%$ , 60 Hz



Power consumption	Approx. 30 VA
Materials of gas- contacting parts	Measuring cell; SUS304 Window; CaF <sub>2</sub> Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.

INTERPOLL LABORATORIES  
4500 BALL ROAD N.E.  
CIRCLE PINES, MN 55014-1819  
(612) 786-6020

# Servomex

## 1420 Oxygen Analyser Instruction Manual

Ref: 01420/001A/0

Order as part No. 01420001A

was (7982-2842)

INTERPOLL LABORATORIES  
4500 BALL ROAD N.E.  
CIRCLE PINES, MN 55014-1819  
(612) 786-6020

### 1.3 Sampling System

The sampling system of the analyser includes a combination filter/automatic flow control device, designed to keep a constant flow of sample gas through the measuring cell for varying input pressures and to prevent the entrance of particulate matter into the measuring cell. Excess flow is vented to the by-pass.

### 1.4 Specification

#### Performance Specification (typical)

Repeatability: Better than  $\pm 0.2\%$  O<sub>2</sub> under constant conditions.

Drift: Less than 0.2% O<sub>2</sub> per week under constant conditions. (Excluding variation due to barometric pressure changes; reading is proportional to barometric pressure.)

#### Outputs

Display: 3 1/2 digit LCD reading 0.0 to 100.0% oxygen with overrange capability.

Output: 0 to 1V (non-isolated) for 0 to 100% oxygen available on 'D' type connector located on the back panel of the instrument. Output impedance is less than 10 ohms.

Option: 4 - 20mA isolated, Max impedance 500 ohms.

Flow alarm output: Change over relay contact rated at 3A/115V ac, 1A/240V ac or 1A/28V dc. 4 sets of single pole changeover contacts. Alarm becomes active when sample gas flow through the analyser fails.

#### Sample requirements

Condition: Clean, dry gas with dew point 5 deg C below ambient temperature.

Inlet pressure: 0.5 to 3psig (3.5 to 21kPa). Inlet pressure changes within this range will change the reading by less than 0.1% O<sub>2</sub>. May be operated up to 10psig (70kPa) with degraded stability.

Flowrate: 1.5 to 6 litres/minute approximately depending on sample pressure.

Filtering: 0.6 micron replaceable filter integral to the automatic flow control device.

Response time: Less than 15 secs. to 90% at an inlet pressure of 3psig (21kPa).

Inlet/vent connections: 1/4 inch OD tube (stainless steel) suitable for 6mm ID flexible tubing or 1/4 inch OD compression fittings.

Materials exposed to the sample: Stainless steel, Pyrex glass, brass, platinum, epoxy resin, Viton, polypropylene and glass fibre filter.

### Physical Characteristics

Case: Steel and aluminium finished in epoxy powder paint.

Case classification: IP 20 (IEC 529) when fitted into the Servomex 1400 series 19 inch case.

Dimensions: See Figure 2.1.

Weight: 10Kg (22lb) approximately.

### Electrical

AC Supply: 110 to 120V AC or 220 to 240V AC, +/-10%, 48 to 62Hz. Voltage selected by a voltage selector integral to the IEC supply plug.

Power required: 15VA maximum.

### Environmental Limits

Operating ambient temperature: 0 to +40 deg C (32 to 104 deg F)

Storage temp. range: -20 to +70 deg C (-4 to 158 deg F)

Relative humidity: 0-85%, non-condensing.

# SPECIFICATIONS FOR ACS MODEL 3300 CO<sub>2</sub> NDIR

Measuring principle	NDIR single beam method
Measurable gas components and measuring range	0 - 20%
Reproducibility	±0.5% of full scale
Stability	Zero drift; $\pm$ % of full scale/24H Span drift; $\pm$ % of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500Ω max.)
Linearity	Better than ±2% of full scale (when linearizer is used)
Power supply	AC 115 V ± 10%, 60 Hz

Power consumption	Approx. 30 VA
Materials of gas- contacting parts	Measuring cell; SUS304 Window; CaF <sub>2</sub> Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.

## APPENDIX G

### CEM INSTRUMENT INFORMATION SHEET

CEM Relative Field Accuracy Certification Instrument Information Sheet

Plant Name LOUISIANA-PACIFIC CORP.

Plant Location HAYWARD, WI

Pollutant Gas Monitor Data:

Vendor TECO - Thermo Environmental Instruments, Inc.

Flow & Temperature Effluent Monitor Data:

Vendor USI - United Sciences, Inc.

Model 48 SIN 48-47743-279

Model 100 SIN 9401658

Location Line 1 DRYER RTO STACK

Location Line 2 Press RTO STACK

Gas(es): ☐ SO<sub>2</sub> ☐ NO<sub>x</sub> ☒ CO

Gas: ☐ O<sub>2</sub> ☐ CO<sub>2</sub> ☒ Airflow - ultrasonic

Type of System: ☐ In-situ ☒ Extractive

Type of System: ☐ In-situ ☐ Extractive

Installation Date JULY 24, 1994

Installation Date JULY 25, 1994

Startup Date AUGUST 10, 1994

Startup Date AUGUST 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer

Relative Accuracy Certification Units:

☒ ppm, dry ☐ LB/10<sup>6</sup>BTU by O<sub>2</sub> F-Factor

☐ ppm, wet ☐ LB/10<sup>6</sup>BTU by CO<sub>2</sub> F-Factor

Span Value (ppm):

SO<sub>2</sub> \_\_\_\_\_

NO<sub>x</sub> \_\_\_\_\_

CO 0-1000 ppm

Output Units:

☐ % O<sub>2</sub>, dry ☐ % CO<sub>2</sub>, dry

☐ % O<sub>2</sub>, wet ☐ % CO<sub>2</sub>, wet

Span Gas Values (% v/v):

\*\*\*\*\*Oxygen\*\*\*\*\*

Low 0 Flow

High 120 kacf/m

\*\*\*Carbon Dioxide\*\*\*

☒ kacf/m  
☒ Temperature - of

Robert W. Schmitt

Signature of Person  
Responsible for Data

11-09-94

Date S-253 RR-9/25



## APPENDIX H

### CEM DATA

# DAILY CO SUMMARY REPORT

Line #1 Dryers CO ppm FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-08-1994  
TIME: 15:32:36

REPORTING PERIOD  
DAY: November 8

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 71	265.6 0	386.8 0	440.3 0	434.4 0	381.8 0
Hour 81	580.3 0	467.5 0	463.3 0	471.9 0	495.7 0
Hour 91	462.0 0	442.1 0	490.5 0	357.1 0	437.9 0
Hour 101	253.9 0	340.9 0	413.6 0	306.4 0	328.7 0
Hour 111	277.5 0	323.9 0	316.4 0	316.2 0	308.5 0
Hour 121	348.5 0	357.0 0	331.2 0	407.8 0	361.1 0
Hour 131	394.2 0	387.0 0	403.6 0	374.5 0	389.8 0
Hour 141	429.0 0	272.9 0	343.4 0	354.6 0	350.0 0
Hour 151	362.3 0	381.5 0	394.9 0	391.2 0	382.5 0
Hour 161	386.3 0	444.1 0	394.5 0	321.9 0	386.7 0
Hour 171	386.8 0	411.2 0	295.5 0	315.8 0	352.4 0
Hour 181	303.7 0	261.9 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 191	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 201	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 211	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 221	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 231	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 01	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 11	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 31	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 41	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 51	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 61	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

#1	305.5	9:45-10:15	#7	308.15	2:15-2:45
#2	360	10:30-11:00	#8	371.9	3:00-3:30
#3	320.15	11:15-11:45	#9	388.75	3:45-4:15
#4	352.75	12:00-12:30	#10	358.2	4:30-5:00
#5	401	12:45-1:15	#11	353.35	5:15-5:45
#6	389.05	1:30-2:00	#12	282.8	6:00-6:30

# DAILY FLOW SUMMARY REPORT

Line #2 Press FLOW kcfm FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 19:15:30

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 71	100.2 0	100.3 0	100.3 0	102.6 0	100.9 0
Hour 81	101.8 0	103.1 0	100.8 0	102.6 0	102.0 0
Hour 91	102.2 0	101.8 0	101.1 0	100.1 0	101.3 0
Hour 101	101.4 0	98.8 0	99.5 0	98.3 0	98.9 0
Hour 111	100.2 0	102.2 0	101.1 0	101.1 0	101.2 0
Hour 121	101.2 0	101.2 0	99.2 0	102.4 0	101.0 0
Hour 131	100.6 0	101.2 0	101.2 0	99.4 0	100.6 0
Hour 141	101.1 0	100.8 0	100.6 0	101.3 0	100.9 0
Hour 151	101.4 0	99.5 0	99.8 0	101.5 0	100.5 0
Hour 161	100.7 0	100.0 0	100.4 0	102.6 0	101.0 0
Hour 171	100.4 0	99.7 0	103.1 0	100.9 0	101.0 0
Hour 181	99.0 0	102.0 0	99.6 0	101.6 0	100.6 0
Hour 191	100.0 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 201	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 211	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 221	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 231	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 01	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 11	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 31	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 41	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 51	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 61	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

Run	Flow	Run	Flow
1	100	7	100
2	100	8	101
3	101	9	102
4	101	10	101
5	100	11	101
6	101	12	101

# DAILY TEMP SUMMARY REPORT

Line #2 Press TEMP Deg-F FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 19:16:15

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	212.4 0	213.4 0	212.8 0	213.4 0	213.0 0
Hour 8	213.7 0	214.3 0	215.6 0	216.2 0	214.9 0
Hour 9	218.0 0	218.2 0	219.7 0	220.8 0	219.2 0
Hour 10	220.8 0	222.4 0	222.1 0	222.6 0	222.0 0
Hour 11	223.0 0	223.8 0	226.3 0	224.2 0	224.3 0
Hour 12	225.9 0	225.0 0	225.1 0	224.4 0	225.1 0
Hour 13	225.6 0	225.9 0	225.2 0	225.0 0	225.4 0
Hour 14	224.6 0	223.3 0	224.6 0	223.8 0	224.1 0
Hour 15	223.8 0	223.5 0	223.7 0	223.8 0	223.7 0
Hour 16	224.8 0	222.5 0	222.3 0	221.1 0	222.7 0
Hour 17	220.6 0	220.8 0	217.8 0	219.8 0	219.8 0
Hour 18	219.8 0	217.6 0	218.9 0	218.7 0	218.8 0
Hour 19	218.1 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 1	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 2	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 3	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 4	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 5	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 6	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0

# DAILY FLOW SUMMARY REPORT

Line #2 Press FLOW kcfm FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 14:08:32

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	100.2 0	100.3 0	100.3 0	102.6 0	100.9 0
Hour 8	101.8 0	103.1 0	100.8 0	102.6 0	102.0 0
Hour 9	102.2 0	101.8 0	101.1 0	100.1 0	101.3 0
Hour 10	101.4 0	98.8 0	99.5 0	98.3 0	99.5 0
Hour 11	100.2 0	102.2 0	101.3 0	101.1 0	101.2 0
Hour 12	101.2 0	101.2 0	99.2 0	102.4 0	101.0 0
Hour 13	100.6 0	101.2 0	101.2 0	99.4 0	100.6 0
Hour 14	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 15	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 16	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 17	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

100.0 25

# DAILY FLOW SUMMARY REPORT

Line #2 Press FLOW kcfm FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 12:46:08

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	100.2 0	100.3 0	100.3 0	102.6 0	100.9 0
Hour 8	101.8 0	103.1 0	100.8 0	102.6 0	102.0 0
Hour 9	102.2 0	101.8 0	101.1 0	100.1 0	101.3 0
Hour 10	101.4 0	98.8 0	99.5 0	98.3 0	99.5 0
Hour 11	100.2 0	102.2 0	101.3 0	101.1 0	101.2 0
Hour 12	101.2 0	101.2 0	99.2 0	-1.0 -1	-1.0 -1
Hour 13	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 14	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 15	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 16	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 17	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

# DAILY TEMP SUMMARY REPORT

Line #2 Press TEMP Deg-F FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 12:46:16

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	212.4 0	213.4 0	212.8 0	213.4 0	213.0 0
Hour 8	213.7 0	214.3 0	215.6 0	216.2 0	214.9 0
Hour 9	218.0 0	218.2 0	219.7 0	220.8 0	219.2 0
Hour 10	220.8 0	222.4 0	222.1 0	222.6 0	222.0 0
Hour 11	223.0 0	223.9 0	226.3 0	224.2 0	224.3 0
Hour 12	225.9 0	225.0 0	225.1 0	-1.0 -1	-1.0 -1
Hour 13	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 14	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 15	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 16	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 17	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 1	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 2	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 3	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 4	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 5	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 6	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0

# DAILY FLOW SUMMARY REPORT

Line #2 Press FLOW kcfm FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 10:36:18

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	100.2 0	100.3 0	100.3 0	102.6 0	100.9 0
Hour 8	101.8 0	103.1 0	100.8 0	102.6 0	102.0 0
Hour 9	102.2 0	101.8 0	101.1 0	100.1 0	101.3 0
Hour 10	101.4 0	98.8 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 11	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 12	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 13	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 14	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 15	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 16	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 17	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1



# DAILY TEMP SUMMARY REPORT

Line #2 Press TEMP Deg-F FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 10:36:27

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	212.4 0	213.4 0	212.8 0	213.4 0	213.0 0
Hour 8	213.7 0	214.3 0	215.6 0	216.2 0	214.9 0
Hour 9	218.0 0	218.2 0	219.7 0	220.8 0	219.2 0
Hour 10	220.8 0	222.4 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 11	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 12	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 13	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 14	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 15	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 16	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 17	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 1	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 2	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 3	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 4	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 5	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 6	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0

# DAILY FLOW SUMMARY REPORT

Line #2 Press FLOW kcfm FIFTEEN MINUTE AVERAGES  
LOUISIANA PACIFIC  
Hayward, WI

TODAY'S DATE: 11-09-1994  
TIME: 15:11:54

REPORTING PERIOD  
DAY: November 9

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	100.2 0	100.3 0	100.3 0	102.6 0	100.9 0
Hour 8	101.8 0	103.1 0	100.8 0	102.6 0	102.0 0
Hour 9	102.2 0	101.8 0	101.1 0	100.1 0	101.3 0
Hour 10	101.4 0	98.8 0	99.5 0	98.3 0	99.5 0
Hour 11	100.2 0	102.2 0	101.3 0	101.1 0	101.2 0
Hour 12	101.2 0	101.2 0	99.2 0	102.4 0	101.0 0
Hour 13	100.6 0	101.2 0	101.2 0	99.4 0	100.6 0
Hour 14	101.1 0	100.8 0	100.6 0	101.3 0	100.9 0
Hour 15	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 16	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 17	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

**APPENDIX I**  
**OPERATING DATA**

[illegible]

DAILY PRODUCTION REPORT

HAYWARD DATE: 11/9/94 ENV. DLS

CALENDAR  
7AM-7PM

LOADS	#PANELS	LINE I SUR FTG	3/8 FTG	7AM-7PM	LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4	0	0	0	1/4	19	912	29184	19457
3/8	0	0	0	3/8	0	0	0	0
7/16	288	9216	10752	7/16	189	9072	290304	338698
15/32	0	0	0	15/32	0	0	0	0
1/2	0	0	0	1/2	0	0	0	0
19/32SE	0	0	0	19/32SE	0	0	0	0
19/32H	0	0	0	19/32H	0	0	0	0
23/32SE	37	56832	108930	23/32SE	0	0	0	0
23/32H	88	135168	259077	23/32H	0	0	0	0
TOTAL	1776	135168	378759	TOTAL	0	0	0	358155

LOADS	#PANELS	LINE I SUR FTG	3/8 FTG	7PM-7AM	LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4	0	0	0	1/4	0	0	0	0
3/8	0	0	0	3/8	0	0	0	0
7/16	0	0	0	7/16	0	0	0	0
15/32	0	0	0	15/32	205	9840	314880	367370
1/2	0	0	0	1/2	0	0	0	0
19/32SE	0	0	0	19/32SE	0	0	0	0
19/32H	0	0	0	19/32H	0	0	0	0
23/32SE	0	0	0	23/32SE	0	0	0	0
23/32H	130	199680	382727	23/32H	0	0	0	0
TOTAL	6240	199680	382727	TOTAL	0	0	0	367370

LOADS	#PANELS	LINE I TOTALS	3/8 FTG	7AM-7PM TOTAL	LOADS	#PANELS	LINE II TOTALS	3/8 FTG
1/4	0	0	0	1/4	19	912	29184	19457
3/8	0	0	0	3/8	0	0	0	0
7/16	6	9216	10752	7/16	394	18912	605184	706068
15/32	0	0	0	15/32	0	0	0	0
1/2	0	0	0	1/2	0	0	0	0
19/32SE	0	0	0	19/32SE	0	0	0	0
19/32H	0	0	0	19/32H	0	0	0	0
23/32SE	37	56832	108930	23/32SE	0	0	0	0
23/32H	218	10464	641803	23/32H	0	0	0	0
TOTALS	218	12528	761485	TOTALS	0	0	0	0
LINE I TOTAL	1487011	12528	761485	LINE II TOTAL	19824	634368	725525	725525

DAILY PLANT TOTAL= 1487011

7AM-7PM TOTAL= 736913  
7PM-7AM TOTAL= 750097

LINE I MTD TOTALS	MTDX	WD #1	WD #2	WD #3	WD #4	WD #5	PLANT MTD	WD #1	WD #2	WD #3	WD #4	WD #5
1/4	0.4	5107486	1523854	0	0	0	10092182	1/4	4984696	7/16	54.4	2.8
3/8	2.9	193536	24.2	0	0	0	2973112	3/8	1449258	15/32	10.8	10.7
7/16	24.2	1603886	11.2	0	0	0	0	7/16	0	1/2	1.2	1.6
15/32	21.1	743040	21.1	0	0	0	0	15/32	0	19/32SE	1.6	1.4
1/2	2.4	1398749	2.4	0	0	0	0	1/2	0	23/32SE	1.4	16.2
19/32SE	2.4	158077	3.2	0	0	0	0	19/32SE	0	23/32H	1.4	16.2
19/32H	3.2	209148	31.8	0	0	0	0	19/32H	0	23/32SE	1.4	16.2
23/32SE	2.8	188419	0	0	0	0	0	23/32SE	0	23/32H	1.4	16.2
23/32H	31.8	2110885	0	0	0	0	0	23/32H	0	23/32SE	1.4	16.2
PLANT MTD	13065294	0	0	0	0	0	0	PLANT MTD	6433954	23/32H	1.4	16.2

[illegible]



# APPENDIX J

## PROCEDURES



9. Entropy Environmentalists, Inc. Traverse Point Study. EPA Contract No. 68-02-3172. June 1977. 19 p.

10. Brown, J. and K. Yu. Test Report: Particulate Sampling Strategy in Circular Ducts. Emission Measurement Branch, Emission Standards and Engineering Division. U.S. Environmental Protection Agency, Research Triangle Park, NC. 27711. July 31, 1980. 12 p.

11. Hawksley, P.G.W., S. Badzioch, and J.H. Blackett. Measurement of Solids in Flue Gases. Leatherhead, England. The British Coal Utilisation Research Association, 1961. p. 129-133.

12. Knapp, K.T. The Number of Sampling Points Needed for Representative Source Sampling. In: Proceedings of the Fourth National Conference on Energy and the Environment, Theodore, L. et al. (ed.). Dayton, Dayton Section of the American Institute of Chemical Engineers. October 3-7, 1976. p. 563-568.

13. Smith, W.S. and D.J. Grove. A Proposed Extension of EPA Method 1 Criteria. "Pollution Engineering." XV (8):36-37. August 1983.

14. Gerhart, P.M. and M.J. Dorsey. Investigation of Field Test Procedures for Large Fans. University of Akron. Akron, OH. (EPRI Contract CS-1651). Final Report (RP-1649-5) December 1980.

15. Smith, W.S. and D.J. Grove. A New Look at Isokinetic Sampling—Theory and Applications. "Source Evaluation Society Newsletter." VIII (3):19-24. August 1983.

## METHOD 2—DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE (TYPE S PITOT TUBE)

### 1. Principle and Applicability

1.1 Principle. The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Staustscheibe or reverse type) pitot tube.

1.2 Applicability. This method is applicable for measurement of the average velocity of a gas stream and for quantifying gas flow.

This procedure is not applicable at measurement sites which fail to meet the criteria of Method 1, Section 2.1. Also, the method cannot be used for direct measurement in cyclonic or swirling gas streams; Section 2.4 of Method 1 shows how to determine cyclonic or swirling flow conditions. When unacceptable conditions exist, alternative procedures, subject to the approval of the Administrator, U.S. Environmental Protection Agency, must be employed to make accurate flow rate determinations; examples of such alternative procedures are: (1) to install straightening vanes; (2) to calculate the total volumetric flow rate stoichiometrically, or (3) to move to another measurement site at which the flow is acceptable.

### 2. Apparatus

Specifications for the apparatus are given below. Any other apparatus that has been demonstrated (subject to approval of the Administrator) to be capable of meeting the specifications will be considered acceptable.




Figure 2-1. Type S pitot tube manometer assembly.

2.1 Type S Pitot Tube. The Type S pitot tube (Figure 2-1) shall be made of metal tubing (e.g., stainless steel). It is recommended that the external tubing diameter (dimension  $D$ , Figure 2-2b) be between 0.48 and 0.95 centimeter ( $\frac{1}{4}$  and  $\frac{3}{8}$  inch). There shall be an equal distance from the base of each leg of the pitot tube to its face-opening plane (dimensions  $P_1$  and  $P_2$ , Figure 2-2b); it is recommended that this distance be between 1.05 and 1.50 times the external

tubing diameter. The face openings of the pitot tube shall, preferably, be aligned as shown in Figure 2-2; however, slight misalignments of the openings are permissible (see Figure 2-3).

The Type S pitot tube shall have a known coefficient, determined as outlined in Section 4. An identification number shall be assigned to the pitot tube; this number shall be permanently marked or engraved on the body of the tube.




Figure 2-2. Properly constructed Type S pitot tube, shown in: (a) end view; face opening planes perpendicular to transverse axis; (b) top view; face opening planes parallel to longitudinal axis; (c) side view; both legs of equal length and centerlines coincident, when viewed from both sides. Baseline coefficient values of 0.84 may be assigned to pitot tubes constructed this way.




Figure 2-3. Types of face-opening misalignment that can result from field use or improper construction of Type S pitot tubes. These will not affect the baseline value of  $C_p(s)$  so long as  $\alpha_1$  and  $\alpha_2 < 10^\circ$ ,  $\beta_1$  and  $\beta_2 < 5^\circ$ ,  $z < 0.32$  cm (1/8 in.) and  $w < 0.08$  cm (1/32 in.) (citation 11 in Section 6).

A standard pitot tube may be used instead of a Type S, provided that it meets the specifications of Sections 2.7 and 4.2; note, however, that the static and impact pressure holes of standard pitot tubes are susceptible to plugging in particulate-laden gas streams. Therefore, whenever a standard pitot tube is used to perform a traverse, adequate proof must be furnished that the openings of the pitot tube have not plugged up during the traverse period; this can be done by taking a velocity head ( $\Delta p$ ) reading at the final traverse point, cleaning out the impact and static holes of the standard

pitot tube by "back-purging" with pressurized air, and then taking another  $\Delta p$  reading. If the  $\Delta p$  readings made before and after the air purge are the same ( $\pm 5$  percent), the traverse is acceptable. Otherwise, reject the run. Note that if  $\Delta p$  at the final traverse point is unsuitably low, another point may be selected. If "back-purging" at regular intervals is part of the procedure, then comparative  $\Delta p$  readings shall be taken, as above, for the last two back purges at which suitably high  $\Delta p$  readings are observed.

**2.2 Differential Pressure Gauge.** An inclined manometer or equivalent device is used. Most sampling trains are equipped with a 10-in. (water column) inclined-vertical manometer, having 0.01-in. H<sub>2</sub>O divisions on the 0-to 1-in. inclined scale, and 0.1-in. H<sub>2</sub>O divisions on the 1- to 10-in. vertical scale. This type of manometer (or other gauge of equivalent sensitivity) is satisfactory for the measurement of  $\Delta p$  values as low as 1.3 mm (0.05 in.) H<sub>2</sub>O. However, a differential pressure gauge of greater sensitivity shall be used (subject to the approval of the Administrator), if any of the following is found to be true: (1) the arithmetic average of all  $\Delta p$  readings at the traverse points in the stack is less than 1.3 mm (0.05 in.) H<sub>2</sub>O; (2) for traverses of 12 or more points, more than 10 percent of the individual  $\Delta p$  readings are below 1.3 mm (0.05 in.) H<sub>2</sub>O; (3) for traverses of fewer than 12 points, more than one  $\Delta p$  reading is below 1.3 mm (0.05 in.) H<sub>2</sub>O. Citation 18 in Section 6 describes commercially available instrumentation for the measurement of low-range gas velocities.

As an alternative to criteria (1) through (3) above, the following calculation may be performed to determine the necessity of using a more sensitive differential pressure gauge:

$$T = \frac{\sum_{i=1}^n \sqrt{\Delta p_i} + K}{\sum_{i=1}^n \sqrt{\Delta p_i}}$$

Where:

$\Delta p_i$  = Individual velocity head reading at a traverse point, mm H<sub>2</sub>O (in. H<sub>2</sub>O).

$n$  = Total number of traverse points.

$K$  = 0.13 mm H<sub>2</sub>O when metric units are used and 0.005 in. H<sub>2</sub>O when English units are used.

If  $T$  is greater than 1.05, the velocity head data are unacceptable and a more sensitive differential pressure gauge must be used.

**NOTE:** If differential pressure gauges other than inclined manometers are used (e.g., magnehelic gauges), their calibration must be checked after each test series. To check the calibration of a differential pressure gauge, compare  $\Delta p$  readings of the gauge with those of a gauge-oil manometer at a minimum of three points, approximately representing the range of  $\Delta p$  values in the stack. If, at each point, the values of  $\Delta p$  as read by the differential pressure gauge and gauge-oil manometer agree to within 5 percent, the differential pressure gauge shall be considered to be in proper calibration. Otherwise, the test series shall either be voided, or procedures to adjust the meas-

ured  $\Delta p$  values and final results shall be used subject to the approval of the Administrator.

**2.3 Temperature Gauge.** A thermocouple, liquid-filled bulb thermometer, bimetallic thermometer, mercury-in-glass thermometer, or other gauge, capable of measuring temperature to within 1.5 percent of the minimum absolute stack temperature shall be used. The temperature gauge shall be attached to the pitot tube such that the sensor tip does not touch any metal; the gauge shall be in an interference-free arrangement with respect to the pitot tube face openings (see Figure 2-1 and also Figure 2-7 in Section 4). Alternate positions may be used if the pitot tube-temperature gauge system is calibrated according to the procedure of Section 4. Provided that a difference of not more than 1 percent in the average velocity measurement is introduced, the temperature gauge need not be attached to the pitot tube; this alternative is subject to the approval of the Administrator.

**2.4 Pressure Probe and Gauge.** A piezometer tube and mercury- or water-filled U-tube manometer capable of measuring stack pressure to within 2.5 mm (0.1 in.) Hg is used. The static tap of a standard type pitot tube or one leg of a Type S pitot tube with the face opening planes positioned parallel to the gas flow may also be used as the pressure probe.

**2.5 Barometer.** A mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg) may be used. In many cases, the barometric reading may be obtained from a nearby National Weather Service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the weather station and the sampling point shall be applied at a rate of minus 2.5 mm (0.1 in.) Hg per 30-meter (100 foot) elevation increase or vice-versa for elevation decrease.

**2.6 Gas Density Determination Equipment.** Method 3 equipment, if needed (see Section 3.6), to determine the stack gas dry molecular weight, and Reference Method 4 or Method 5 equipment for moisture content determination; other methods may be used subject to approval of the Administrator.

**2.7 Calibration Pitot Tube.** When calibration of the Type S pitot tube is necessary (see Section 4), a standard pitot tube is used as a reference. The standard pitot tube shall, preferably, have a known coefficient, obtained either (1) directly from the National Bureau of Standards, Route 270, Quince Orchard Road, Gaithersburg, Maryland, or (2) by calibration against another standard pitot tube with an NBS-traceable coefficient. Alternatively, a standard pitot tube

designed according to the criteria given in 2.7.1 through 2.7.5 below and illustrated in Figure 2-4 (see also Citations 7, 8, and 17 in Section 6) may be used. Pitot tubes designed according to these specifications will have baseline coefficients of about  $0.99 \pm 0.01$ .

2.7.1 Hemispherical (shown in Figure 2-4), ellipsoidal, or conical tip.

2.7.2 A minimum of six diameters straight run (based upon  $D$ , the external diameter of the tube) between the tip and the static pressure holes.

2.7.3 A minimum of eight diameters straight run between the static pressure holes and the centerline of the external tube, following the 90 degree bend.

2.7.4 Static pressure holes of equal size (approximately  $0.1 D$ ), equally spaced in a piezometer ring configuration.

2.7.5 Ninety degree bend, with curved or mitered junction.

2.8 Differential Pressure Gauge for Type S Pitot Tube Calibration. An inclined manometer or equivalent is used. If the single-velocity calibration technique is employed (see Section 4.1.2.3), the calibration differential pressure gauge shall be readable to the nearest  $0.13 \text{ mm H}_2\text{O}$  ( $0.005 \text{ in. H}_2\text{O}$ ). For multivelocity calibrations, the gauge shall be readable to the nearest  $0.13 \text{ mm H}_2\text{O}$  ( $0.005 \text{ in. H}_2\text{O}$ ) for  $\Delta p$  values between  $1.3$  and  $25 \text{ mm H}_2\text{O}$  ( $0.05$  and  $1.0 \text{ in. H}_2\text{O}$ ), and to the nearest  $1.3 \text{ mm H}_2\text{O}$  ( $0.05 \text{ in. H}_2\text{O}$ ) for  $\Delta p$  values above  $25 \text{ mm H}_2\text{O}$  ( $1.0 \text{ in. H}_2\text{O}$ ). A special, more sensitive gauge will be required to read  $\Delta p$  values below  $1.3 \text{ mm H}_2\text{O}$  [ $0.05 \text{ in. H}_2\text{O}$ ] (see Citation 18 in Section 6).




Figure 2-4. Standard pitot tube design specifications.

### 3. Procedure

3.1 Set up the apparatus as shown in Figure 2-1. Capillary tubing or surge tanks installed between the manometer and pitot tube may be used to dampen  $\Delta p$  fluctuations. It is recommended, but not required, that a pretest leak-check be conducted, as follows: (1) blow through the pitot impact opening until at least 7.6 cm (3 in.) H<sub>2</sub>O velocity pressure registers on the manometer; then, close off the impact opening. The pressure shall remain stable for at least 15 seconds; (2) do the same for the static pressure side, except using suction to obtain the minimum of 7.6 cm (3 in.) H<sub>2</sub>O. Other leak-check procedures, subject to the approval of the Administrator, may be used.

3.2 Level and zero the manometer. Because the manometer level and zero may


drift due to vibrations and temperature changes, make periodic checks during the traverse. Record all necessary data as shown in the example data sheet (Figure 2-5).

3.3 Measure the velocity head and temperature at the traverse points specified by Method 1. Ensure that the proper differential pressure gauge is being used for the range of  $\Delta p$  values encountered (see Section 2.2). If it is necessary to change to a more sensitive gauge, do so, and remeasure the  $\Delta p$  and temperature readings at each traverse point. Conduct a post-test leak-check (mandatory), as described in Section 3.1 above, to validate the traverse run.

3.4 Measure the static pressure in the stack. One reading is usually adequate.

3.5 Determine the atmospheric pressure.



[illegible]

J-9 519

3.6 Determine the stack gas dry molecular weight. For combustion processes or processes that emit essentially  $\text{CO}_2$ ,  $\text{O}_2$ ,  $\text{CO}$ , and  $\text{N}_2$ , use Method 3. For processes emitting essentially air, an analysis need not be conducted; use a dry molecular weight of 29.0. For other processes, other methods, subject to the approval of the Administrator, must be used.

3.7 Obtain the moisture content from Reference Method 4 (or equivalent) or from Method 5.

3.8 Determine the cross-sectional area of the stack or duct at the sampling location. Whenever possible, physically measure the stack dimensions rather than using blueprints.

#### 4. Calibration

4.1 Type S Pitot Tube. Before its initial use, carefully examine the Type S pitot tube in top, side, and end views to verify that the face openings of the tube are aligned within the specifications illustrated in Figure 2-2 or 2-3. The pitot tube shall not be used if it fails to meet these alignment specifications.


After verifying the face opening alignment, measure and record the following dimensions of the pitot tube: (a) the external tubing diameter (dimension  $D_t$ , Figure 2-2b); and (b) the base-to-opening plane distances (dimensions  $P_1$  and  $P_2$ , Figure 2-2b). If  $D_t$  is between 0.48 and 0.95 cm ( $\frac{1}{8}$  and  $\frac{3}{8}$  in.) and if  $P_1$  and  $P_2$  are equal and between 1.05 and 1.50  $D_t$ , there are two possible options: (1) the pitot tube may be calibrated according to the procedure outlined in Sections 4.1.2 through 4.1.5 below, or (2) a baseline (isolated tube) coefficient value of 0.84 may be assigned to the pitot tube. Note, however, that if the pitot tube is part of an assembly, calibration may still be required, despite knowledge of the baseline coefficient value (see Section 4.1.1).

If  $D_t$ ,  $P_1$ , and  $P_2$  are outside the specified limits, the pitot tube must be calibrated as outlined in 4.1.2 through 4.1.5 below.


4.1.1 Type S Pitot Tube Assemblies. During sample and velocity traverses, the isolated Type S pitot tube is not always used; in many instances, the pitot tube is used in combination with other source-sampling components (thermocouple, sampling probe, nozzle) as part of an "assembly." The presence of other sampling components can sometimes affect the baseline value of the Type S pitot tube coefficient (Citation 9 in Section 6); therefore an assigned (or otherwise known) baseline coefficient value may or may not be valid for a given assembly. The baseline and assembly coefficient values will be identical only when the relative placement of the components in the assembly is such that aerodynamic interference effects are eliminated. Figures 2-6 through 2-8 illustrate interference-free component arrangements for Type S pitot tubes having external tubing diameters between 0.48 and 0.95 cm ( $\frac{1}{8}$  and  $\frac{3}{8}$  in.). Type S pitot tube assemblies that fail to meet any or all of the specifications of Figures 2-6 through 2-8 shall be calibrated according to the procedure outlined in Sections 4.1.2 through 4.1.5 below, and prior to calibration, the values of the intercomponent spacings (pitot-nozzle, pitot-thermocouple, pitot-probe sheath) shall be measured and recorded.

**NOTE:** Do not use any Type S pitot tube assembly which is constructed such that the impact pressure opening plane of the pitot tube is below the entry plane of the nozzle (see Figure 2-6b).

4.1.2 Calibration Setup. If the Type S pitot tube is to be calibrated, one leg of the tube shall be permanently marked A, and the other, B. Calibration shall be done in a flow system having the following essential design features:



**A. BOTTOM VIEW: SHOWING MINIMUM PITOT-NOZZLE SEPARATION.**



**B. SIDE VIEW: TO PREVENT PITOT TUBE FROM INTERFERING WITH GAS FLOW STREAMLINES APPROACHING THE NOZZLE, THE IMPACT PRESSURE OPENING PLANE OF THE PITOT TUBE SHALL BE EVEN WITH OR ABOVE THE NOZZLE ENTRY PLANE.**




Figure 2-7. Proper thermocouple placement to prevent interference;  
 $D_t$  between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 2-8. Minimum pitot-sample probe separation needed to prevent interference;  
 $D_t$  between 0.48 and 0.95 cm (3/16 and 3/8 in.).

4.1.2.1 The flowing gas stream must be confined to a duct of definite cross-sectional area, either circular or rectangular. For circular cross-sections, the minimum duct diameter shall be 30.5 cm (12 in.); for rectangular cross-sections, the width (shorter side) shall be at least 25.4 cm (10 in.).

4.1.2.2 The cross-sectional area of the calibration duct must be constant over a distance of 10 or more duct diameters. For a rectangular cross-section, use an equivalent diameter, calculated from the following equation, to determine the number of duct diameters:

$$D_e = \frac{2LW}{(L+W)} \quad \text{Eq. 2-1}$$

Where:

$D_e$  = Equivalent diameter

$L$  = Length

$W$  = Width

To ensure the presence of stable, fully developed flow patterns at the calibration site, or "test section," the site must be located at least eight diameters downstream and two diameters upstream from the nearest disturbances.

NOTE: The eight- and two-diameter criteria are not absolute; other test section locations may be used (subject to approval of the Administrator), provided that the flow at the test site is stable and demonstrably parallel to the duct axis.

4.1.2.3 The flow system shall have the capacity to generate a test-section velocity around 915 m/min (3,000 ft/min). This velocity must be constant with time to guarantee steady flow during calibration. Note that Type S pitot tube coefficients obtained by single-velocity calibration at 915 m/min (3,000 ft/min) will generally be valid to within  $\pm 3$  percent for the measurement of velocities above 305 m/min (1,000 ft/min) and to within  $\pm 5$  to 6 percent for the measurement of velocities between 180 and 305 m/min (600 and 1,000 ft/min). If a more precise correlation between  $C_p$  and velocity is desired, the flow system shall have the capacity to generate at least four distinct, time-invariant test-section velocities covering the velocity range from 180 to 1,525 m/min (600 to 5,000 ft/min), and calibration data shall be taken at regular velocity intervals over this range (see Citations 9 and 14 in Section 6 for details).

4.1.2.4 Two entry ports, one each for the standard and Type S pitot tubes, shall be cut in the test section; the standard pitot entry port shall be located slightly down-

stream of the Type S port, so that the standard and Type S impact openings will lie in the same cross-sectional plane during calibration. To facilitate alignment of the pitot tubes during calibration, it is advisable that the test section be constructed of plexiglas or some other transparent material.

4.1.3 Calibration Procedure. Note that this procedure is a general one and must not be used without first referring to the special considerations presented in Section 4.1.5. Note also that this procedure applies only to single-velocity calibration. To obtain calibration data for the A and B sides of the Type S pitot tube, proceed as follows:

4.1.3.1 Make sure that the manometer is properly filled and that the oil is free from contamination and is of the proper density. Inspect and leak-check all pitot lines; repair or replace if necessary.

4.1.3.2 Level and zero the manometer. Turn on the fan and allow the flow to stabilize. Seal the Type S entry port.

4.1.3.3 Ensure that the manometer is level and zeroed. Position the standard pitot tube at the calibration point (determined as outlined in Section 4.1.5.1), and align the tube so that its tip is pointed directly into the flow. Particular care should be taken in aligning the tube to avoid yaw and pitch angles. Make sure that the entry port surrounding the tube is properly sealed.

4.1.3.4 Read  $\Delta p_{std}$  and record its value in a data table similar to the one shown in Figure 2-9. Remove the standard pitot tube from the duct and disconnect it from the manometer. Seal the standard entry port.

4.1.3.5 Connect the Type S pitot tube to the manometer. Open the Type S entry port. Check the manometer level and zero. Insert and align the Type S pitot tube so that its A side impact opening is at the same point as was the standard pitot tube and is pointed directly into the flow. Make sure that the entry port surrounding the tube is properly sealed.

4.1.3.6 Read  $\Delta p_s$  and enter its value in the data table. Remove the Type S pitot tube from the duct and disconnect it from the manometer.

4.1.3.7 Repeat steps 4.1.3.3 through 4.1.3.6 above until three pairs of  $\Delta p$  readings have been obtained.

4.1.3.8 Repeat steps 4.1.3.3 through 4.1.3.7 above for the B side of the Type S pitot tube.

4.1.3.9 Perform calculations, as described in Section 4.1.4 below.

4.1.4 Calculations.

4.1.4.1 For each of the six pairs of  $\Delta p$  readings (i.e., three from side A and three from side B) obtained in Section 4.1.3 above, calculate the value of the Type S pitot tube coefficient as follows:

PITOT TUBE IDENTIFICATION NUMBER: \_\_\_\_\_ DATE: \_\_\_\_\_

CALIBRATED BY: \_\_\_\_\_

"A" SIDE CALIBRATION				
RUN NO.	$\Delta p_{std}$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$\Delta p(s)$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1				
2				
3				
			$\bar{C}_p$ (SIDE A)	

"B" SIDE CALIBRATION				
RUN NO.	$\Delta p_{std}$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$\Delta p(s)$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1				
2				
3				
			$\bar{C}_p$ (SIDE B)	

$$\text{AVERAGE DEVIATION} = a(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

$$C_{p(s)} = C_{p(s,cal)} \sqrt{\frac{\Delta p_{std}}{\Delta p_s}}$$

Equation 2-2

Where:

 $C_{p(s)}$  = Type S pitot tube coefficient $C_{p(s,cal)}$  = Standard pitot tube coefficient; use 0.99 if the coefficient is unknown and the tube is designed according to the criteria of Sections 2.7.1 to 2.7.5 of this method. $\Delta p_{std}$  = Velocity head measured by the standard pitot tube, cm H<sub>2</sub>O (in. H<sub>2</sub>O) $\Delta p_s$  = Velocity head measured by the Type S pitot tube, cm H<sub>2</sub>O (in. H<sub>2</sub>O)

4.1.4.2 Calculate  $C_p$  (side A), the mean A-side coefficient, and  $C_p$  (side B), the mean B-side coefficient; calculate the difference between these two average values.

4.1.4.3 Calculate the deviation of each of the three A-side values of  $C_{p(s)}$  from  $C_p$  (side A), and the deviation of each B-side value of  $C_{p(s)}$  from  $C_p$  (side B). Use the following equation:

$$\text{Deviation} = C_{p(s)} - \bar{C}_p (\text{A or B})$$

Equation 2-3

4.1.4.4 Calculate  $\delta$ , the average deviation from the mean, for both the A and B sides of the pitot tube. Use the following equation:

$$\sigma (\text{side A or B}) = \frac{\sum_{i=1}^3 |C_{p(s,i)} - \bar{C}_p (\text{A or B})|}{3}$$

Equation 2-4

4.1.4.5 Use the Type S pitot tube only if the values of  $\delta$  (side A) and  $\delta$  (side B) are less than or equal to 0.01 and if the absolute value of the difference between  $C_p$  (A) and  $C_p$  (B) is 0.01 or less.

4.1.5 Special considerations.

4.1.5.1 Selection of calibration point.

4.1.5.1.1 When an isolated Type S pitot tube is calibrated, select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The Type S pitot coefficients so obtained, i.e.,  $C_p$  (side A) and  $C_p$  (side B), will be valid, so long as either: (1) the isolated pitot tube is used; or (2) the

pitot tube is used with other components (nozzle, thermocouple, sample probe) in an arrangement that is free from aerodynamic interference effects (see Figures 2-6 through 2-8).

4.1.5.1.2 For Type S pitot tube-thermocouple combinations (without sample probe), select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The coefficients so obtained will be valid so long as the pitot tube-thermocouple combination is used by itself or with other components in an interference-free arrangement (Figures 2-6 and 2-8).

4.1.5.1.3 For assemblies with sample probes, the calibration point should be located at or near the center of the duct; however, insertion of a probe sheath into a small duct may cause significant cross-sectional area blockage and yield incorrect coefficient values (Citation 9 in Section 6). Therefore, to minimize the blockage effect, the calibration point may be a few inches off-center if necessary. The actual blockage effect will be negligible when the theoretical blockage, as determined by a projected-area model of the probe sheath, is 2 percent or less of the duct cross-sectional area for assemblies without external sheaths (Figure 2-10a), and 3 percent or less for assemblies with external sheaths (Figure 2-10b).

4.1.5.2 For those probe assemblies in which pitot tube-nozzle interference is a factor (i.e., those in which the pitot-nozzle separation distance fails to meet the specification illustrated in Figure 2-6a), the value of  $C_{p(s)}$  depends upon the amount of free-space between the tube and nozzle, and therefore is a function of nozzle size. In these instances, separate calibrations shall be performed with each of the commonly used nozzle sizes in place. Note that the single-velocity calibration technique is acceptable for this purpose, even though the larger nozzle sizes (>0.635 cm or 1/4 in.) are not ordinarily used for isokinetic sampling at velocities around 915 m/min (3,000 ft/min), which is the calibration velocity; note also that it is not necessary to draw an isokinetic sample during calibration (see Citation 19 in Section 6).

4.1.5.3 For a probe assembly constructed such that its pitot tube is always used in the same orientation, only one side of the pitot tube need be calibrated (the side which will face the flow). The pitot tube must still meet the alignment specifications of Figure 2-2 or 2-3, however, and must have an average deviation ( $\delta$ ) value of 0.01 or less (see Section 4.1.4.4).




Figure 2-10. Projected-area models for typical pitot tube assemblies.



#### 4.1.6 Field Use and Recalibration.

##### 4.1.6.1 Field Use.

4.1.6.1.1 When a Type S pitot tube (isolated tube or assembly) is used in the field, the appropriate coefficient value (whether assigned or obtained by calibration) shall be used to perform velocity calculations. For calibrated Type S pitot tubes, the A side coefficient shall be used when the A side of the tube faces the flow, and the B side coefficient shall be used when the B side faces the flow; alternatively, the arithmetic average of the A and B side coefficient values may be used, irrespective of which side faces the flow.

4.1.6.1.2 When a probe assembly is used to sample a small duct (12 to 36 in. in diameter), the probe sheath sometimes blocks a significant part of the duct cross-section, causing a reduction in the effective value of  $C_{pu}$ . Consult Citation 9 in Section 6 for details. Conventional pitot-sampling probe assemblies are not recommended for use in ducts having inside diameters smaller than 12 inches (Citation 16 in Section 6).

##### 4.1.6.2 Recalibration.

4.1.6.2.1 Isolated Pitot Tubes. After each field use, the pitot tube shall be carefully reexamined in top, side, and end views. If the pitot face openings are still aligned within the specifications illustrated in Figure 2-2 or 2-3, it can be assumed that the baseline coefficient of the pitot tube has not changed. If, however, the tube has been damaged to the extent that it no longer meets the specifications of Figure 2-2 or 2-3, the damage shall either be repaired to restore proper alignment of the face openings or the tube shall be discarded.

4.1.6.2.2 Pitot Tube Assemblies. After each field use, check the face opening alignment of the pitot tube, as in Section 4.1.6.2.1; also, remeasure the intercomponent spacings of the assembly. If the intercomponent spacings have not changed and the face opening alignment is acceptable, it can be assumed that the coefficient of the assembly has not changed. If the face opening alignment is no longer within the specifications of Figures 2-2 or 2-3, either repair the damage or replace the pitot tube (calibrating the new assembly, if necessary). If the intercomponent spacings have changed, restore the original spacings or recalibrate the assembly.

4.2 Standard pitot tube (if applicable). If a standard pitot tube is used for the velocity traverse, the tube shall be constructed according to the criteria of Section 2.7 and shall be assigned a baseline coefficient value of 0.99. If the standard pitot tube is used as part of an assembly, the tube shall be in an interference-free arrangement (subject to the approval of the Administrator).

4.3 Temperature Gauges. After each field use, calibrate dial thermometers, liquid-filled bulb thermometers, thermocou-

ple-potentiometer systems, and other gauges at a temperature within 10 percent of the average absolute stack temperature. For temperatures up to 405° C (761° F), use an ASTM mercury-in-glass reference thermometer, or equivalent, as a reference; alternatively, either a reference thermocouple and potentiometer (calibrated by NBS) or thermometric fixed points, e.g., ice bath and boiling water (corrected for barometric pressure) may be used. For temperatures above 405° C (761° F), use an NBS-calibrated reference thermocouple-potentiometer system or an alternate reference, subject to the approval of the Administrator.

If, during calibration, the absolute temperatures measured with the gauge being calibrated and the reference gauge agree within 1.5 percent, the temperature data taken in the field shall be considered valid. Otherwise, the pollutant emission test shall either be considered invalid or adjustments (if appropriate) of the test results shall be made, subject to the approval of the Administrator.

4.4 Barometer. Calibrate the barometer used against a mercury barometer.

#### 5. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

##### 5.1 Nomenclature.

$A$  = Cross-sectional area of stack,  $m^2$  ( $ft^2$ ).

$B_{ws}$  = Water vapor in the gas stream (from Method 5 or Reference Method 4), proportion by volume.

$C_p$  = Pitot tube coefficient, dimensionless.

$K_p$  = Pitot tube constant,

$$34.97 \frac{m}{sec} \left[ \frac{(g/g\text{-mole})(mm\ Hg)}{(^{\circ}K)(mm\ H_2O)} \right]^{1/2}$$

for the metric system and

$$85.49 \frac{ft}{sec} \left[ \frac{(lb/lb\text{-mole})(in.\ Hg)}{(^{\circ}R)(in.\ H_2O)} \right]^{1/2}$$

for the English system.

$M_d$  = Molecular weight of stack gas, dry basis (see Section 3.8)  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).

$M_w$  = Molecular weight of stack gas, wet basis,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).

$$= M_d (1 - B_{ws}) + 18.0 B_{ws}$$

Eq. 2-5

$P_{bar}$  = Barometric pressure at measurement site,  $mm\ Hg$  ( $in.\ Hg$ ).

$P_s$  = Stack static pressure,  $mm\ Hg$  ( $in.\ Hg$ ).

$P_t$  = Absolute stack gas pressure,  $mm\ Hg$  ( $in.\ Hg$ ).

$$= P_{bar} + P_s$$

Eq. 2-6

$P_{std}$  = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).

$Q_{std}$  = Dry volumetric stack gas flow rate corrected to standard conditions, dscm/hr (dscf/hr).

$t_s$  = Stack temperature, °C (°F).

$T_s$  = Absolute stack temperature, °K, (°R).

= 273 +  $t_s$  for metric.

Eq. 2-7

= 460 +  $t_s$  for English.

Eq. 2-8

$T_{std}$  = Standard absolute temperature, 293 °K (528° R).

$v_s$  = Average stack gas velocity, m/sec (ft/sec).

$\Delta p$  = Velocity head of stack gas, mm H<sub>2</sub>O (in. H<sub>2</sub>O).

3,600 = Conversion factor, sec/hr.

18.0 = Molecular weight of water, g/g-mole (lb/lb-mole).

5.2 Average Stack Gas Velocity.

$$v_s = K_p C_p (\sqrt{\Delta p})_{ave} \sqrt{\frac{T_{std}}{P_s M_s}}$$

Equation 2-9

5.3 Average Stack Gas Dry Volumetric Flow Rate.

$$Q_{std} = 3,600(1 - B_{std})v_s A \left( \frac{T_{std}}{T_s (avg)} \right) \left( \frac{P_s}{P_{std}} \right)$$

Eq. 2-10

## 6. Bibliography

1. Mark, L. S. *Mechanical Engineers' Handbook*. New York, McGraw-Hill Book Co., Inc. 1951.

2. Perry, J. H. *Chemical Engineers' Handbook*. New York, McGraw-Hill Book Co., Inc. 1960.

3. Shigehara, R. T., W. F. Todd, and W. S. Smith. Significance of Errors in Stack Sampling Measurements. U.S. Environmental Protection Agency, Research Triangle Park, NC (Presented at the Annual Meeting of the Air Pollution Control Association, St. Louis, MO, June 14-19, 1970.)

4. Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Book of ASTM Standards, Part 23. Philadelphia, PA 1971. ASTM Designation D-2928-71.

5. Vennard, J. K. *Elementary Fluid Mechanics*. New York, John Wiley and Sons, Inc. 1947.

6. Fluid Meters—Their Theory and Application. American Society of Mechanical Engineers, New York, NY 1959.

7. ASHRAE Handbook of Fundamentals. 1972. p. 208.

8. Annual Book of ASTM Standards, Part 26. 1974. p. 648.

9. Vollaro, R. F. Guidelines for Type S Pitot Tube Calibration. U.S. Environmental Protection Agency, Research Triangle Park, NC (Presented at 1st Annual Meeting, Source Evaluation Society, Dayton, OH, September 18, 1975.)

10. Vollaro, R. F. A Type S Pitot Tube Calibration Study. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC July 1974.

11. Vollaro, R. F. The Effects of Impact Opening Misalignment on the Value of the Type S Pitot Tube Coefficient. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC. October 1976.

12. Vollaro, R. F. Establishment of a Baseline Coefficient Value for Properly Constructed Type S Pitot Tubes. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC. November 1976.

13. Vollaro, R. F. An Evaluation of Single-Velocity Calibration Technique as a Means of Determining Type S Pitot Tubes Coefficient. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC. August 1975.

14. Vollaro, R. F. The Use of Type S Pitot Tubes for the Measurement of Low Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC. November 1976.

15. Smith, Marvin L. Velocity Calibration of EPA Type Source Sampling Probe. United Technologies Corporation, Pratt and Whitney Aircraft Division, East Hartford, CN. 1975.

16. Vollaro, R. F. Recommended Procedure for Sample Traverses in Ducts Smaller than 12 Inches in Diameter. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC. November 1976.

17. Ower, E. and R. C. Pankhurst. *The Measurement of Air Flow*, 4th Ed., London, Pergamon Press. 1966.

18. Vollaro, R. F. A Survey of Commercially Available Instrumentation for the Measurement of Low-Range Gas Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, NC. November 1976. (Unpublished Paper)

19. Gnyp, A. W., C. C. St. Pierre, D. S. Smith, D. Mozzon, and J. Steiner. An Experimental Investigation of the Effect of Pitot Tube-Sampling Probe Configurations on the Magnitude of the S Type Pitot Tube Coefficient for Commercially Available Source Sampling Probes. Prepared by the Universi-

Method 3A—Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 Applicability. This method is applicable to the determination of oxygen ( $O_2$ ) and carbon dioxide ( $CO_2$ ) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 Principle. A sample is continuously extracted from the effluent stream: a portion of the sample stream is conveyed to an instrumental analyzer(s) for determination of  $O_2$  and  $CO_2$  concentration(s). Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

Same as Method 6C, Sections 2.1 and 2.2, except that the span of the monitoring system shall be selected such that the average  $O_2$  or  $CO_2$  concentration is not less than 20 percent of the span.

3. Definitions

3.1 Measurement System. The total equipment required for the determination of the  $O_2$  or  $CO_2$  concentration. The measurement system consists of the same major subsystems as defined in Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.2 Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, Response Time, and Calibration Curve. Same as Method 6C, Sections 3.2 through 3.8, and 3.10.

3.3 Interference Response. The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 Measurement System. Any measurement system for  $O_2$  or  $CO_2$  that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 Sample Probe. A leak-free probe, of sufficient length to traverse the sample points.

5.1.2 Sample Line. Tubing, to transport the sample gas from the probe to the moisture removal system. A heated sample line is not required for systems that measure the  $O_2$  or  $CO_2$  concentration on a dry basis, or transport dry gases.

5.1.3 Sample Transport Line, Calibration Value Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder. Same as Method 6C, Sections 5.1.3 through 5.1.9, and 5.1.11, except that the requirements to use stainless steel, Teflon, and nonreactive glass filters do not apply.

5.1.4 Gas Analyzer. An analyzer to determine continuously the  $O_2$  or  $CO_2$  concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer. The requirements for measuring and controlling the analyzer flow rate are not applicable if data are presented that demonstrate the analyzer is insensitive to flow variations over the range encountered during the test.

5.2 Calibration Gases. The calibration gases for  $CO_2$  analyzers shall be  $CO_2$  in  $N_2$  or  $CO_2$  in air. Alternatively,  $CO_2/SO_2$ ,  $O_2/SO_2$ , or  $O_2/CO_2/SO_2$  gas mixtures in  $N_2$  may be used. Three calibration gases, as specified Section 5.3.1 through 5.3.3 of Method 6C, shall be used. For  $O_2$  monitors that cannot analyze zero gas, a calibration gas concentration equivalent to less than 10 percent of the span may be used in place of zero gas.

## 6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Concentration Verification. Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 3 and change the acceptance criteria for agreement among Method 3 results to 5 percent (or 0.2 percent by volume, whichever is greater).

6.2 Interference Response. Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the type of gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 Measurement System Preparation, Analyzer Calibration Error, and Sampling System Bias Check. Follow Sections 6.2 through 6.4 of Method 6C.

## 7. Emission Test Procedure

7.1 Selection of Sampling Site and Sampling Points. Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 3.

7.2 Sample Collection. Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the sampling system bias check. Maintain constant rate sampling (i.e.,  $\pm 10$  percent) during the entire run. The sampling time per run shall be the same as for tests conducted using Method 3 plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed to determine the average effluent concentration.

7.3 Zero and Calibration Drift Test. Follow Section 7.4 of Method 6C.

## 8. Quality Control Procedures

The following quality control procedures are recommended when the results of this method are used for an emission rate correction factor, or excess air determination. The tester should select one of the following options for validating measurement results:

8.1 If both  $O_2$  and  $CO_2$  are measured using Method 3A, the procedures described in Section 4.4 of Method 3 should be followed to validate the  $O_2$  and  $CO_2$  measurement results.

8.2 If only  $O_2$  is measured using Method 3A, measurements of the sample stream  $CO_2$  concentration should be obtained at the sample by-pass vent discharge using an Orsat or Fyrite analyzer, or equivalent. Duplicate samples should be obtained concurrent with at least one run. Average the duplicate Orsat or Fyrite analysis results for each run. Use the average  $CO_2$  values for comparison with the  $O_2$  measurements in accordance with the procedures described in Section 4.4 of Method 3.

8.3 If only  $CO_2$  is measured using Method 3A, concurrent measurements of the sample stream  $O_2$  concentration should be obtained using an Orsat or Fyrite analyzer as described in Section 8.2. For each run, differences greater than 0.5 percent between the Method 3A results and the average of the duplicate Fyrite analysis should be investigated.

## 9. Emission Calculation

For all  $CO_2$  analyzers, and for  $O_2$  analyzers that can be calibrated with zero gas, follow Section 8 of Method 6C, except express all concentrations as percent, rather than ppm.

For  $O_2$  analyzers that use a low-level calibration gas in place

of a zero gas, calculate the effluent gas concentration using Equation 3A-1.

$$C_{100} = \frac{C_{100} - C_{100}}{C_{100} - C_{100}} (\bar{C} - C_{100}) + C_{100} \quad \text{Eq. 3A-1}$$

Where:

- $C_{100}$  = Effluent gas concentration, dry basis, percent.
- $C_{100}$  = Actual concentration of the upscale calibration gas, percent.
- $C_{100}$  = Actual concentration of the low-level calibration gas, percent.
- $C_{100}$  = Average of initial and final system calibration bias check responses for the upscale calibration gas, percent.
- $C_{100}$  = Average of initial and final system calibration bias check responses for the low-level gas, percent.
- $\bar{C}$  = Average gas concentration indicated by the gas analyzer, dry basis, percent.

#### 10. Bibliography

Same as bibliography of Method 6C.

4.2 Performance Evaluation Tests. The owner of a lidar system shall subject such a lidar system to the performance verification tests described in Section 3, prior to first use of this method. The annual calibration shall be performed for three separate, complete runs and the results of each should be recorded. The requirements of Section 3.3.1 must be fulfilled for each of the three runs.

Once the conditions of the annual calibration are fulfilled the lidar shall be subjected to the routine verification for three separate complete runs. The requirements of Section 3.3.2 must be fulfilled for each of the three runs and the results should be recorded. The Administrator may request that the results of the performance evaluation be submitted for review.

### 5. References

5.1 The Use of Lidar for Emissions Source Opacity Determination. U.S. Environmental Protection Agency, National Enforcement Investigations Center, Denver, CO. EPA-330/1-79-003-R, Arthur W. Dybdahl, current edition [NTIS No. PB81-246662].

5.2 Field Evaluation of Mobile Lidar for the Measurement of Smoke Plume Opacity. U.S. Environmental Protection Agency, National Enforcement Investigations Center, Denver, CO. EPA/NEIC-TS-128, February 1976.

5.3 Remote Measurement of Smoke Plume Transmittance Using Lidar. C. S. Cook, G. W. Bethke, W. D. Conner (EPA/RTP). Applied Optics 11, pg 1742, August 1972.

5.4 Lidar Studies of Stack Plumes in Rural and Urban Environments, EPA-650/4-73-002, October 1973.

5.5 American National Standard for the Safe Use of Lasers ANSI Z 136.1-176, March 8, 1976.

5.6 U.S. Army Technical Manual TB MED 279, Control of Hazards to Health from Laser Radiation, February 1969.

5.7 Laser Institute of America Laser Safety Manual, 4th Edition.

5.8 U.S. Department of Health, Education and Welfare, Regulations for the Administration and Enforcement of the Radiation Control for Health and Safety Act of 1968, January 1976.

5.9 Laser Safety Handbook, Alex Mallow, Leon Chabot, Van Nostrand Reinhold Co., 1978.

## METHOD 10--DETERMINATION OF CARBON MONOXIDE EMISSIONS FROM STATIONARY SOURCES

### 1. Principle and Applicability

1.1 Principle. An integrated or continuous gas sample is extracted from a sampling point and analyzed for carbon monoxide

(CO) content using a Luft-type nondispersive infrared analyzer (NDIR) or equivalent.

1.2 Applicability. This method is applicable for the determination of carbon monoxide emissions from stationary sources only when specified by the test procedures for determining compliance with new source performance standards. The test procedure will indicate whether a continuous or an integrated sample is to be used.

### 2. Range and Sensitivity

2.1 Range. 0 to 1,000 ppm.

2.2 Sensitivity. Minimum detectable concentration is 20 ppm for a 0 to 1,000 ppm span.

### 3. Interferences

Any substance having a strong absorption of infrared energy will interfere, to some extent. For example, discrimination ratios for water (H<sub>2</sub>O) and carbon dioxide (CO<sub>2</sub>) are 3.5 percent H<sub>2</sub>O per 7 ppm CO and 10 percent CO<sub>2</sub> per 10 ppm CO, respectively, for devices measuring in the 1,500 to 3,000 ppm range. For devices measuring in the 0 to 100 ppm range, interference ratios can be as high as 3.5 percent H<sub>2</sub>O per 25 ppm CO and 10 percent CO<sub>2</sub> per 50 ppm CO. The use of silica gel and ascarite traps will alleviate the major interference problems. The measured gas volume must be corrected if these traps are used.

### 4. Precision and Accuracy

4.1 Precision. The precision of most NDIR analyzers is approximately  $\pm 2$  percent of span.

4.2 Accuracy. The accuracy of most NDIR analyzers is approximately  $\pm 5$  percent of span after calibration.

### 5. Apparatus

5.1 Continuous Sample (Figure 10-1).

5.1.1 Probe. Stainless steel or sheathed Pyrex<sup>1</sup> glass, equipped with a filter to remove particulate matter.

5.1.2 Air-Cooled Condenser or Equivalent. To remove any excess moisture.

5.2 Integrated Sample (Figure 10-2).

5.2.1 Probe. Stainless steel or sheathed Pyrex glass, equipped with a filter to remove particulate matter.

5.2.2 Air-Cooled Condenser or Equivalent. To remove any excess moisture.

5.2.3 Valve. Needle valve, or equivalent, to adjust flow rate.

5.2.4 Pump. Leak-free diaphragm type, or equivalent, to transport gas.

5.2.5 Rate Meter. Rotameter, or equivalent, to measure a flow range from 0 to 1.0 liter per min (0.035 cfm).

<sup>1</sup> Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

**5.2.6 Flexible Bag.** Tedlar, or equivalent, with a capacity of 60 to 90 liters (2 to 3 ft<sup>3</sup>). Leak-test the bag in the laboratory before using by evacuating bag with a pump followed by a dry gas meter. When evacuation is complete, there should be no flow through the meter.

5.2.7 Pitot Tube. Type S, or equivalent, attached to the probe so that the sampling rate can be regulated proportional to the stack gas velocity when velocity is varying with the time or a sample traverse is conducted.


### 5.3 Analysis (Figure 10-3).

**5.3.1 Carbon Monoxide Analyzer.** Nondispersive infrared spectrometer, or equivalent. This instrument should be demonstrated, preferably by the manufacturer, to meet or exceed manufacturer's specifications and those described in this method.


5.3.2 Drying Tube. To contain approximately 200 g of silica gel.

**5.3.3 Calibration Gas.** Refer to section 6.1.

5.3.4 Filter. As recommended by NDIR manufacturer.



**Figure 10-1. Continuous sampling train.**



**Figure 10-2. Integrated gas sampling unit.**

5.3.5 CO<sub>2</sub> Removal Tube. To contain approximately 500 g of ascarite.

5.3.6 Ice Water Bath. For ascarite and silica gel tubes.


5.3.7 Valve. Needle valve, or equivalent, to adjust flow rate

5.3.8 Rate Meter. Rotameter or equivalent to measure gas flow rate of 0 to 1.0 liter per min (0.035 cfm) through NDIR.

5.3.9 Recorder (optional). To provide permanent record of NDIR readings.

## 6. Reagents

6.1 Calibration Gases. Known concentration of CO in nitrogen (N<sub>2</sub>) for instrument span, prepurified grade of N<sub>2</sub> for zero, and two additional concentrations corresponding approximately to 60 percent and 30 percent span. The span concentration shall not exceed 1.5 times the applicable source performance standard. The calibration gases shall be certified by the manufacturer to be within  $\pm 2$  percent of the specified concentration.



**Figure 10-3. Analytical equipment.**

6.2 Silica Gel. Indicating type, 6 to 16 mesh, dried at 175° C (347° F) for 2 hours.

**6.3 Ascarite. Commercially available.**

## 7. Procedure

### 7.1 Sampling.

7.1.1 Continuous Sampling. Set up the equipment as shown in Figure 10-1 making sure all connections are leak free. Place the probe in the stack at a sampling point and purge the sampling line. Connect the analyzer and begin drawing sample into the analyzer. Allow 5 minutes for the system to stabilize, then record the analyzer reading as required by the test procedure. (See section 7.2 and 8). CO<sub>2</sub> content of the gas may be determined by using the Method 3 integrated sample procedure, or by weighing the ascarite CO<sub>2</sub> removal tube and computing CO<sub>2</sub> concentration from the gas volume sampled and the weight gain of the tube.

**7.1.2 Integrated Sampling.** Evacuate the flexible bag. Set up the equipment as shown in Figure 10-2 with the bag disconnected. Place the probe in the stack and purge the sampling line. Connect the bag, making sure that all connections are leak free. Sample at a rate proportional to the stack velocity. CO<sub>2</sub> content of the gas may be determined by using the Method 3 integrated sample procedures, or by weighing the ascarite CO<sub>2</sub> removal tube and computing CO<sub>2</sub> concentra-



tion from the gas volume sampled and the weight gain of the tube.

7.2 CO Analysis. Assemble the apparatus as shown in Figure 10-3, calibrate the instrument, and perform other required operations as described in section 8. Purge analyzer with N<sub>2</sub> prior to introduction of each sample. Direct the sample stream through the instrument for the test period, recording the readings. Check the zero and span again after the test to assure that any drift or malfunction is detected. Record the sample data on Table 10-1.

### 3. Calibration

Assemble the apparatus according to Figure 10-3. Generally an instrument requires a warm-up period before stability is obtained. Follow the manufacturer's instructions for specific procedure. Allow a minimum time of 1 hour for warm-up. During this time check the sample conditioning apparatus, i.e., filter, condenser, drying tube, and CO<sub>2</sub> removal tube, to ensure that each component is in good operating condition. Zero and calibrate the instrument according to the manufacturer's procedures using, respectively, nitrogen and the calibration gases.

TABLE 10-1—FIELD DATA

Comments	
Location.....	
Test.....	
Date.....	
Operator.....	
Clock time	Rotameter setting, liters per minute (cubic feet per minute)

### 3. Calculation

Calculate the concentration of carbon monoxide in the stack using Equation 10-1.

$$C_{CO \text{ stack}} = C_{CO \text{ NDIR}}(1 - F_{CO_2})$$

Eq. 10-1

Where:

$C_{CO \text{ stack}}$  = Concentration of CO in stack, ppm by volume (dry basis).

$C_{CO \text{ NDIR}}$  = Concentration of CO measured by NDIR analyzer, ppm by volume (dry basis).

$F_{CO_2}$  = Volume fraction of CO<sub>2</sub> in sample, i.e., percent CO<sub>2</sub> from Orsat analysis divided by 100.

## 10. Alternative Procedures

10.1 Interference Trap. The sample conditioning system described in Method 10A sections 2.1.2 and 4.2, may be used as an alternative to the silica gel and ascarite traps.

## 11. Bibliography

1. McElroy, Frank, The Intertech NDIR-CO Analyzer, Presented at 11th Methods Conference on Air Pollution, University of California, Berkeley, CA, April 1, 1970.
2. Jacobs, M. B., et al., Continuous Determination of Carbon Monoxide and Hydrocarbons in Air by a Modified Infrared Analyzer, J. Air Pollution Control Association, 9(2): 110-114, August 1959.
3. MSA LIRA Infrared Gas and Liquid Analyzer Instruction Book, Mine Safety Appliances Co., Technical Products Division, Pittsburgh, PA.
4. Models 215A, 315A, and 415A Infrared Analyzers, Beckman Instruments, Inc., Beckman Instructions 1635-B, Fullerton, CA, October 1967.
5. Continuous CO Monitoring System, Model A5611, Intertech Corp., Princeton, NJ.
6. UNOR Infrared Gas Analyzers, Bendix Corp., Ronceverte, WV

## ADDENDA

### A. PERFORMANCE SPECIFICATIONS FOR NDIR CARBON MONOXIDE ANALYZERS

Range (minimum).....	0-1000 ppm.
Output (minimum).....	0-10mV.
Minimum detectable sensitivity.	20 ppm.
Rise time, 90 percent (maximum).	30 seconds.
Fall time, 90 percent (maximum).	30 seconds.
Zero drift (maximum).....	10% in 8 hours.
Span drift (maximum).....	10% in 8 hours.
Precision (minimum).....	±2% of full scale.
Noise (maximum).....	±1% of full scale.
Linearity (maximum deviation).	2% of full scale.
Interference rejection ratio.....	CO <sub>2</sub> —1000 to 1, H <sub>2</sub> O—500 to 1.

### B. Definitions of Performance Specifications.

**Range**—The minimum and maximum measurement limits.

**Output**—Electrical signal which is proportional to the measurement; intended for connection to readout or data processing devices. Usually expressed as millivolts or milliamperes full scale at a given impedance.

**Full scale**—The maximum measuring limit for a given range.

**Minimum detectable sensitivity**—The smallest amount of input concentration that can be detected as the concentration approaches zero.

**Accuracy**—The degree of agreement between a measured value and the true value; usually expressed as  $\pm$  percent of full scale.

**Time to 90 percent response**—The time interval from a step change in the input concentration at the instrument inlet to a reading of 90 percent of the ultimate recorded concentration.

**Rise Time (90 percent)**—The interval between initial response time and time to 90 percent response after a step increase in the inlet concentration.

**Fall Time (90 percent)**—The interval between initial response time and time to 90 percent response after a step decrease in the inlet concentration.

**Zero Drift**—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is zero; usually expressed as percent full scale.

**Span Drift**—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is a stated upscale value; usually expressed as percent full scale.

**Precision**—The degree of agreement between repeated measurements of the same concentration, expressed as the average deviation of the single results from the mean.

**Noise**—Spontaneous deviations from a mean output not caused by input concentration changes.

**Linearity**—The maximum deviation between an actual instrument reading and the reading predicted by a straight line drawn between upper and lower calibration points.

#### METHOD 10A—DETERMINATION OF CARBON MONOXIDE EMISSIONS IN CERTIFYING CONTINUOUS EMISSION MONITORING SYSTEMS AT PETROLEUM REFINERIES

##### 1. Applicability and Principle

**1.1 Applicability.** This method applies to the measurement of carbon monoxide (CO) at petroleum refineries. This method serves as the reference method in the relative accuracy test for nondispersive infrared (NDIR) CO continuous emission monitoring systems (CEMS's) that are required to be in-

stalled in petroleum refineries on fluid catalytic cracking unit catalyst regenerators [40 CFR Part 60.105(a)(2)].

**1.2 Principle.** An integrated gas sample is extracted from the stack, passed through an alkaline permanganate solution to remove sulfur and nitrogen oxides, and collected in a Tedlar bag. The CO concentration in the sample is measured spectrophotometrically using the reaction of CO with p-sulfamino-benzoic acid.

##### 1.3 Range and Sensitivity.

**1.3.1 Range.** Approximately 3 to 1800 ppm CO. Samples having concentrations below 400 ppm are analyzed at 425 nm, and samples having concentrations above 400 ppm are analyzed at 600 nm.

**1.3.2 Sensitivity.** The detection limit is 3 ppm based on three times the standard deviation of the mean reagent blank values.

**1.4 Interferences.** Sulfur oxides, nitric oxide, and other acid gases interfere with the colorimetric reaction. They are removed by passing the sampled gas through an alkaline potassium permanganate scrubbing solution. Carbon dioxide (CO<sub>2</sub>) does not interfere, but, because it is removed by the scrubbing solution, its concentration must be measured independently and an appropriate volume correction made to the sampled gas.

##### 1.5 Precision, Accuracy, and Stability.

**1.5.1 Precision.** The estimated intralaboratory standard deviation of the method is 3 percent of the mean for gas samples analyzed in duplicate in the concentration range of 39 to 412 ppm. The interlaboratory precision has not been established.

**1.5.2 Accuracy.** The method contains no significant biases when compared to an NDIR analyzer calibrated with National Bureau of Standards (NBS) standards.

**1.5.3 Stability.** The individual components of the colorimetric reagent are stable for at least 1 month. The colorimetric reagent must be used within 2 days after preparation to avoid excessive blank correction. The samples in the Tedlar<sup>1</sup> bag should be stable for at least 1 week if the bags are leak-free.

##### 2. Apparatus

**2.1 Sampling.** The sampling train is shown in Figure 10A-1, and component parts are discussed below:

<sup>1</sup> Mention of trade names or commercial products in this publication does not consti-

tute the endorsement or recommendation for use by the Environmental Protection Agency.

**APPENDIX K**

**CALCULATION EQUATIONS**

METHOD 2  
CALCULATION EQUATIONS

$$\bar{V}_s = 85.49 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60 (1 - B_{ws}) \bar{V}_s A \left( \frac{528}{T_{s(avg)}} \right) \left( \frac{P_s}{29.92} \right)$$

$$Q_a = 60 \bar{V}_s A$$

$$\dot{m}_s = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} - 0.0003641 P_s (T_{db} - T_{twb})) / vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

\*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

032294-G:STACKWPMETHODS-EQ.15

## SYMBOLS

$A$	=	Cross Sectional area of stack, SQ. FT.
$A_n$	=	Cross sectional area of nozzle, SQ. FT.
$B_{ws}$	=	Water vapor in gas stream, proportion by volume
$C_p$	=	Pitot tube coefficient, dimensionless
$C_s$	=	Concentration of particulate matter in stack gas, wet basis, GR/ACF
$C_d$	=	Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
$EA$	=	Excess air, percent by volume
$\gamma$	=	Dry test meter correction factor, dimensionless
$G_d$	=	Specific gravity (relative to air), dimensionless
$I$	=	Isokinetic variation, percent by volume
$M_d$	=	Molecular weight of stack gas, dry basis, g/g - mole.
$\dot{m}_s$	=	Mass flow of wet flue gas, LB/HR
$\dot{m}_p$	=	Particulate mass flow, LB/HR
$M_s$	=	Molecular weight of stack gas, wet basis, g/g mole.
$M_p$	=	Total amount of particulate matter collected, g
$P_{bar}$	=	Atmospheric pressure, IN. HG. (uncompensated)
$P_g$	=	Stack static gas pressure, IN. WC.
$P_s$	=	Absolute pressure of stack gas, IN. HG.
$P_{std}$	=	Standard absolute pressure, 29.92 IN. HG.
$A_s$	=	Actual volumetric stack gas flow rate, ACFM
$Q_{s, d}$	=	Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
$RH$	=	Relative humidity, %

032294-G:\STACK\WPMETHODSS-EQ.15

$T_{db}$	=	Dry bulb temperature of stack gas, °F
$T_{wb}$	=	Wet bulb temperature of stack gas, °F
$T_{m(avg)}$	=	Absolute average dry gas meter temperature, °R
$T_{s(avg)}$	=	Absolute average stack temperature, °R
$T_{std}$	=	Standard absolute temperature, 528 °R (68 °F)
$\theta$	=	Total sampling time, min.
$V_{lc}$	=	Total volume of liquid collected in impingers and silica gel, ml
$V_m$	=	Volume of gas sample as measured by dry gas meter, CF
$V_{m(std)}$	=	Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
$V_{w(std)}$	=	Volume of water vapor in the gas sample corrected to standard conditions, SCF
$\bar{V}_s$	=	Average actual stack gas velocity, FT/SEC
$vP_{tdb}$	=	Vapor pressure at $T_{db}$ , IN. HG.
$vP_{twb}$	=	Vapor pressure at $T_{wb}$ , IN. HG.
$\overline{\Delta H}$	=	Average pressure differential across the orifice meter, IN. WC.
$\Delta P$	=	Velocity pressure of stack gas, IN. WC.
$\gamma$	=	Dry test meter correction coefficient, dimensionless
$\rho$	=	Actual gas density, LB/ACF

METHOD 3  
CALCULATION EQUATIONS

$$\%EA = \frac{100(\%O_2 - 0.5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (I - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

## CALCULATION EQUATIONS

### METHOD 10

$$CO\cdot PPM\cdot DRY = CO_{CO_2} - free, dry, avg (1 - CO_2, d/100)$$

$$CO\cdot PPM\cdot WET = CO\cdot PPM\cdot DRY (1 - MC/100)$$

$$GR/DSCF = 5.0885 \times 10^{-4} (CO\cdot PPM\cdot DRY)$$

$$mg/dscm = 1.165 (CO\cdot PPM\cdot DRY)$$

$$\dot{m} = 8.5714 \times 10^{-3} (GR/DSCF) (Q_{s,d})$$

$$E = \frac{2.9857 \times 10^{-3} F_d (GR/DSCF)}{20.9 - O_{2,d}}$$

where:

$CO_{CO_2} - free, dry, avg$

= average of two determinations of carbon monoxide on a dry,  $CO_2$  - free integrated flue gas sample reported in ppm by volume

$CO_{2,d}$  = carbon dioxide concentration of flue gas on a dry percent by volume basis

$O_{2,d}$  = oxygen concentration of flue gas on a dry percent by volume basis

G:\STACK\WPMETHODS\EQ.M10



MC	=	moisture content of flue gas on a percent by volume basis
CO·PPM·DRY	=	carbon monoxide concentration in ppm by volume on a dry basis
CO·PPM·WET	=	carbon monoxide concentration in ppm by volume on a wet or actual basis
GR/DSCF	=	concentration of carbon monoxide in flue gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
mg/dscm	=	concentration of carbon monoxide in flue gas on a milligrams per dry standard cubic meter basis (60 °F, 29.92 IN. HG.)
m	=	emissions or mass rate of carbon monoxide on a LB/HR basis
$Q_{s,d}$	=	volumetric flow rate of flue gas in dry standard cubic feet per minute
E	=	emission factor of carbon monoxide in pounds of carbon monoxide emitted per million BTU heat input (LB/MMBTU)
$F_d$	=	F-Factor of respective fuel in dry standard cubic feet of exhaust gas at 0% oxygen per million BTU of heat input (DSCF/MMBTU)

G:\STACK\WP\METHODS\SEQ.M10