

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 10.6.1

Background Report Section: 4

Reference Number: 33

**Title: Results of the August 23-26, 1994
Relative Accuracy Certifications of
Four CO/Flow CERM Systems at the
Louisiana Pacific Plant Located in
Hayward, Wisconsin**

Interpoll Laboratories, Inc.

September 1994

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020
FAX: (612) 786-7854

FILE COPY

**RESULTS OF THE AUGUST 23 - 26, 1994
RELATIVE ACCURACY CERTIFICATIONS OF
FOUR CO/FLOW CERM SYSTEMS AT THE
LOUISIANA PACIFIC PLANT
LOCATED IN HAYWARD, WISCONSIN**


Submitted to:

LOUISIANA PACIFIC CORPORATION
Route 8, Box 8263
Hayward, Wisconsin 54843

Attention:

Bob Schultz

Reviewed by:



Daniel J. Despen
Manager
Stationary Source Testing Department

Report Number 4-3688R
September 27, 1994
SP/slp

TABLE OF CONTENTS

ABBREVIATIONS	iii
1 INTRODUCTION	1
2 SUMMARY AND DISCUSSION	2
2.1 Results of Orsat & Moisture Analyses	4
2.2 Results of Volumetric Flow Rate Determinations	

APPENDICES:

- A - Sampling Train Calibration Data
- B - Reference Method Results
- C - Field Data Sheets
- D - Measurement Systems Performance Specifications
- E - Calibration Gas Certification Sheets
- F - Gas Analyzer Specifications
- G - CEM Instrument Information Sheet
- H - CEM Data
- I - Operating Data
- J - Procedures
- K - Calculation Equations
- L - Calibration Drift Data
- M - Transmissometer Factory Performance Specification Tests

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.

1 INTRODUCTION

During August 23 - 26, 1994, Interpoll Laboratories personnel conducted Relative Accuracy Certification Tests of four CO/Flow CERMs installed on the Line 1 Dryer, Line 2 Dryer, Line 1 Press, and Line 2 Press RTO Stacks at the Louisiana Pacific Corporation Plant in Hayward, Wisconsin. The certifications were performed on the following:

Monitor				
Type	Manufacturer	Model	Serial No.	Location
Flow	United Sciences	100	9401655	Line 1 Dryer
CO	TECO	48	48-47743-279	Line 1 Dryer
Flow	United Sciences	100	9401656	Line 2 Dryer
CO	TECO	48	48-47744-279	Line 2 Dryer
Flow	United Sciences	100	9401657	Line 1 Press
CO	TECO	48	48-48535-281	Line 1 Press
Flow	United Sciences	100	9401658	Line 2 Press
CO	TECO	48	48-48536-281	Line 2 Press

On-site testing was performed by Bob Aschenbach and Dennis Marso. Coordination between testing activities and plant operation was provided by Bob Schultz of Louisiana Pacific. The test was not witnessed by a member of the Wisconsin Department of Natural Resources.

The Relative Accuracy Certifications were performed in accordance with Specification 4, CFR Title 40, Part 60 Appendix B (revised July 1, 1993). Evaluations were performed in accordance with EPA Method 10 (Ibid: Appendix A). A slip stream of exhaust gas was drawn from the exhaust gas stream using test ports provided by the plant using a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser to remove moisture. The particulate-free dry gas was then split, half the sample was collected directly in 44-Liter Tedlar bags. The other half of the sample gas stream was passed through an alkaline potassium permanganate scrubber to remove interferences and then collected in 44-Liter Tedlar bags. Each set of bags was then analyzed: the scrubbed sample for CO, the unscrubbed sample for O₂ and CO₂. The CO₂ level was also measured in the scrubbed sample to correct for residual CO₂. The O₂, CO₂ and CO analyzers were

calibrated on-site using EPA Protocol standard gases. A three-way valve on the probe was used to introduce standard gas for the "system bias check". The analog response of the CO analyzer was recorded using a strip chart recorder. Moisture determinations were performed in accordance with EPA Method 4.

Twelve 21-minute test runs for CO were performed at each test site using a 30-minute cycle. During each run, the sample probe was moved through a three-point traverse (1/6, 3/6, 5/6 of the stack dia).

The important results of the tests are summarized in Tables 1 - 4. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The important results of the Relative Accuracy Certifications are summarized in Tables 1 - 4. No difficulties were encountered in the field or in the data reduction. On the basis of this fact and a complete review of all of the data, it is our opinion that the concentrations reported herein are accurate and closely reflect the actual values which existed at the time the test was performed.

Table 1. Summary of the Results of the August 23, 1994 Relative Accuracy Test Audit on the **CO/Flow** CERM System installed on the Line 2 Dryer RTO Stack at the Louisiana Pacific Plant in Hayward, Wisconsin.

Run	TIME (HRS)	CO (ppm,d)			Flow (kcfm)		
		RM	CERM	DIFF	RM	CERM	DIFF
1	0832-0902	277	275	-2	122	124	2
*2	0917-0947	449	401	-48	132	125	-7
3	1002-1032	174	180	6	129	125	-4
4	1047-1117	241	224	-17	125	124	-1
5	1132-1202	325	307	-18	126	125	-1
6	1217-1247	369	393	24	127	126	-1
*7	1332-1402	553	426	-127	125	126	1
8	1417-1447	370	360	-10	131	126	-5
9	1502-1532	409	357	-52	129	124	-5
10	1547-1617	393	366	-27	124	124	0
*11	1632-1702	506	399	-107	126	125	-1
12	1717-1747	449	439	-10	124	127	3
Average Diff				11.8	1.3		
Confidence Coefficient				16.3	2.21		
Standard Deviation				21.3	2.87		
Relative Accuracy				8.4	2.8		

* Note: Runs 2, 7, and 11 were not used in the calculation of relative accuracy.

RM = Reference Method

CERM = Continuous Emission Rate Monitor

Table 2. Summary of the Results of the August 24, 1994 Relative Accuracy Test Audit on the CO/Flow CERM System installed on the Line 1 Dryer RTO Stack at the Louisiana Pacific Plant in Hayward, Wisconsin.

Run	TIME (HRS)	CO (ppm,d)			Flow (kcfm)		
		RM	CERM	DIFF	RM	CERM	DIFF
1	0817-0847	385	361	-24	109	114	5
2	0902-0932	401	357	-44	108	115	7
3	0947-1017	480	395	-85	123	115	-8
*4	1032-1102	621	447	-174	122	115	-7
*5	1117-1147	553	412	-141	120	115	-5
*6	1202-1232	456	369	-87	116	117	1
7	1247-1317	216	206	-10	118	117	-1
8	1332-1402	394	382	-12	116	117	1
9	1417-1447	262	249	-13	116	118	2
10	1547-1617	153	150	-3	112	118	6
11	1632-1702	232	265	33	124	119	-5
12	1715-1745	290	233	-57	119	116	-3
Average Difference				23.9	0.44		
Confidence Coefficient				26.3	3.96		
Standard Deviation				34.2	5.15		
Relative Accuracy				16.1	3.8		

Note: Runs 4, 5, and 6 were not used in the calculation of relative accuracy.

RM = Reference Method

CERM = Continuous Emission Rate Monitor

Table 3. Summary of the Results of the August 25, 1994 Relative Accuracy Test Audit on the CO/Flow CERM System installed on the Line 1 Press RTO Stack at the Louisiana Pacific Plant in Hayward, Wisconsin.

M actm

Run	TIME (HRS)	CO (ppm,d)			Flow (kcfm)		
		RM	CERM	DIFF	RM	CERM	DIFF
*1	0802-0832	18.5	16.2	-2.3	96	87	-9
2	0847-0917	15.5	14.8	-0.7	98	88	-10
3	0932-1002	15.7	14.2	-1.5	97	88	-9
4	1017-1047	14.9	14.7	-0.2	97	88	-9
*5	1147-1217	16.5	14.8	-1.7	96	89	-7
6	1232-1302	15.4	15.0	-0.4	96	90	-6
7	1317-1347	13.4	14.0	0.6	96	88	-8
8	1402-1432	12.9	14.4	1.5	98	89	-9
*9	1447-1517	17.1	12.2	-4.9	93	88	-5
10	1532-1602	16.2	14.6	-1.6	97	88	-9
11	1617-1647	15.7	14.8	-0.9	96	87	-9
12	1702-1732	15.9	15.4	-0.5	96	88	-8
Average Difference				0.41	8.56		
Confidence Coefficient				0.752	0.87		
Standard Deviation				0.98	1.13		
Relative Accuracy				7.7	9.7		

* Note: Runs 1, 5, and 9 were not used in the calculation of relative accuracy.

RM = Reference Method

CERM = Continuous Emission Rate Monitor

Table 4. Summary of the Results of the August 26, 1994 Relative Accuracy Test Audit on the CO/Flow CERM System installed on the Line 2 Press RTO Stack at the Louisiana Pacific Plant in Hayward, Wisconsin.

Run	TIME (HRS)	CO (ppm,d)			Flow (kcfm)		
		RM	CERM	DIFF	RM	CERM	DIFF
1	0747-0817	11.6	10.0	-1.6	111	98	-13
*2	0832-0902	12.5	8.15	-4.35	110	97	-13
3	0917-0947	12.8	11.9	-0.9	108	98	-10
4	1102-1132	12.7	11.4	-1.3	110	97	-13
5	1147-1217	13.7	12.0	-1.7	111	102	-9
6	1232-1302	11.3	11.7	0.4	110	96	-14
7	1317-1347	10.3	11.2	0.9	111	101	-10
8	1402-1432	10.6	11.5	0.9	111	101	-10
*9	1447-1517	17.1	11.3	-5.8	110	100	-10
10	1530-1602	9.8	11.7	1.9	111	100	-11
*11	1617-1647	8.1	11.1	3.0	109	101	-8
12	1702-1732	8.3	11.1	2.8	109	98	-11
Average Difference				0.16	11		
Confidence Coefficient				1.24	1.32		
Standard Deviation				1.62	1.72		
Relative Accuracy				12.5	11.4		

* Note: Runs 2, 9, and 11 were not used in the calculation of relative accuracy.

RM = Reference Method

CERM = Continuous Emission Rate Monitor

2.1 Results of Orsat & Moisture Analyses

Test No. 1
Line 2 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	08-23-94	08-23-94	08-23-94

Dry basis (orsat)

carbon dioxide.....	2.85	3.25	2.25
oxygen.....	17.69	17.24	18.40
nitrogen.....	79.46	79.51	79.35

Wet basis (orsat)

carbon dioxide.....	2.39	2.59	1.91
oxygen.....	14.81	13.73	15.60
nitrogen.....	66.51	63.31	67.28
water vapor.....	16.30	20.38	15.21

Dry molecular weight.....	29.16	29.21	29.10
Wet molecular weight.....	27.34	26.93	27.41
Specific gravity.....	0.945	0.930	0.947

FO	1.126	1.126	1.111
----	-------	-------	-------

Test No. 1
Line 2 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 4 08-23-94	Run 5 08-23-94	Run 6 08-23-94
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	2.32	3.17	3.13
oxygen.....	18.35	17.31	17.32
nitrogen.....	79.33	79.52	79.55

Wet basis (orsat)

carbon dioxide.....	1.98	2.55	2.52
oxygen.....	15.68	13.91	13.97
nitrogen.....	67.80	63.89	64.17
water vapor.....	14.54	19.66	19.33
Dry molecular weight.....	29.11	29.20	29.19
Wet molecular weight.....	27.49	27.00	27.03
Specific gravity.....	0.950	0.933	0.934

FO	1.099	1.132	1.144
----	-------	-------	-------

Test No. 1
Line 2 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 7 08-23-94	Run 8 08-23-94	Run 9 08-23-94
Dry basis (orsat)			
carbon dioxide.....	3.24	3.01	3.17
oxygen.....	17.03	17.55	17.30
nitrogen.....	79.73	79.44	79.53
Wet basis (orsat)			
carbon dioxide.....	2.56	2.38	2.52
oxygen.....	13.45	13.87	13.76
nitrogen.....	62.95	62.77	63.27
water vapor.....	21.05	20.99	20.45
Dry molecular weight.....	29.20	29.18	29.20
Wet molecular weight.....	26.84	26.84	26.91
Specific gravity.....	0.927	0.927	0.929
FO	1.194	1.113	1.136

Test No. 1
Line 2 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 10	Run 11	Run 12
Date of run	08-23-94	08-23-94	08-23-94

Dry basis (orsat)

carbon dioxide.....	3.06	3.12	3.23
oxygen.....	17.33	17.27	17.12
nitrogen.....	79.61	79.61	79.65

Wet basis (orsat)

carbon dioxide.....	2.48	2.48	2.54
oxygen.....	14.03	13.75	13.44
nitrogen.....	64.46	63.37	62.53
water vapor.....	19.03	20.40	21.50
Dry molecular weight.....	29.18	29.19	29.20
Wet molecular weight.....	27.05	26.91	26.79
Specific gravity.....	0.935	0.929	0.926

FO	1.167	1.163	1.170
----	-------	-------	-------

Test No. 2
Line 1 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(t/v/v)

Date of run	Run 1 08-24-94	Run 2 08-24-94	Run 3 08-24-94
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.74	3.57	3.71
oxygen.....	16.77	16.79	16.71
nitrogen.....	79.49	79.64	79.58

Wet basis (orsat)

carbon dioxide.....	2.93	2.75	2.83
oxygen.....	13.14	12.92	12.73
nitrogen.....	62.30	61.31	60.61
water vapor.....	21.62	23.02	23.84
Dry molecular weight.....	29.27	29.24	29.26
Wet molecular weight.....	26.83	26.65	26.58
Specific gravity.....	0.927	0.921	0.918

FO	1.104	1.151	1.129
----	-------	-------	-------

Test No. 2
Line 1 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 4	Run 5	Run 6
Date of run	08-24-94	08-24-94	08-24-94

Dry basis (orsat)

carbon dioxide.....	3.95	3.72	3.56
oxygen.....	16.49	16.72	16.91
nitrogen.....	79.56	79.56	79.53

Wet basis (orsat)

carbon dioxide.....	2.99	2.80	2.75
oxygen.....	12.49	12.58	13.04
nitrogen.....	60.27	59.87	61.35
water vapor.....	24.25	24.75	22.86
Dry molecular weight.....	29.29	29.26	29.25
Wet molecular weight.....	26.55	26.48	26.68
Specific gravity.....	0.917	0.915	0.921

FO	1.116	1.124	1.121
----	-------	-------	-------

Test No. 2
Line 1 Dryer RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(tv/v)

	Run 7	Run 8	Run 9
Date of run	08-24-94	08-24-94	08-24-94

Dry basis (orsat)

carbon dioxide.....	3.11	3.35	2.96
oxygen.....	17.53	17.12	17.46
nitrogen.....	79.36	79.53	79.58

Wet basis (orsat)

carbon dioxide.....	2.45	2.64	2.36
oxygen.....	13.80	13.48	13.92
nitrogen.....	62.46	62.61	63.46
water vapor.....	21.29	21.27	20.26
Dry molecular weight.....	29.20	29.22	29.17
Wet molecular weight.....	26.81	26.83	26.91
Specific gravity.....	0.926	0.927	0.929

FO	1.084	1.128	1.162
----	-------	-------	-------

Test No. 2
Line 1 Dryer RT0 Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(tv/v)

	Run 10	Run 11	Run 12
Date of run	08-24-94	08-24-94	08-24-94

Dry basis (orsat)

carbon dioxide.....	2.55	3.22	2.22
oxygen.....	17.47	17.31	18.11
nitrogen.....	79.98	79.47	79.67

Wet basis (orsat)

carbon dioxide.....	2.07	2.55	1.83
oxygen.....	14.21	13.71	14.91
nitrogen.....	65.04	62.96	65.59
water vapor.....	18.68	20.78	17.67
Dry molecular weight.....	29.11	29.21	29.08
Wet molecular weight.....	27.03	26.88	27.12
Specific gravity.....	0.934	0.928	0.937

FO	1.345	1.115	1.257
----	-------	-------	-------

Test No. 3
Line 1 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-25-94	Run 2 08-25-94	Run 3 08-25-94
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	0.37	0.38	0.36
oxygen.....	20.40	19.97	20.64
nitrogen.....	79.23	79.65	79.00

Wet basis (orsat)

carbon dioxide.....	0.36	0.37	0.35
oxygen.....	19.73	19.29	19.95
nitrogen.....	76.62	76.92	76.36
water vapor.....	3.30	3.43	3.34
Dry molecular weight.....	28.88	28.86	28.88
Wet molecular weight.....	28.52	28.49	28.52
Specific gravity.....	0.985	0.984	0.985

FO	1.351	2.447	0.722
----	-------	-------	-------

Test No. 3
Line 1 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 4 08-25-94	Run 5 08-25-94	Run 6 08-25-94
Dry basis (orsat)			
carbon dioxide.....	0.36	0.33	0.33
oxygen.....	20.54	20.53	20.14
nitrogen.....	79.10	79.14	79.53
Wet basis (orsat)			
carbon dioxide.....	0.35	0.32	0.32
oxygen.....	19.86	19.91	19.47
nitrogen.....	76.48	76.77	76.88
water vapor.....	3.31	3.00	3.33
Dry molecular weight.....	28.88	28.87	28.86
Wet molecular weight.....	28.52	28.55	28.50
Specific gravity.....	0.985	0.986	0.984
FO	1.000	1.121	2.303

Test No. 3
Line 1 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 7 08-25-94	Run 8 08-25-94	Run 9 08-25-94
Dry basis (orsat)			
carbon dioxide.....	0.48	0.48	0.48
oxygen.....	20.07	19.98	20.46
nitrogen.....	79.45	79.54	79.06
Wet basis (orsat)			
carbon dioxide.....	0.46	0.46	0.46
oxygen.....	19.41	19.32	19.78
nitrogen.....	76.82	76.90	76.44
water vapor.....	3.31	3.32	3.32
Dry molecular weight.....	28.88	28.88	28.90
Wet molecular weight.....	28.52	28.51	28.53
Specific gravity.....	0.985	0.985	0.986
FO	1.729	1.917	0.917

Test No. 3
Line 1 Press RT0 Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 10	Run 11	Run 12
Date of run	08-25-94	08-25-94	08-25-94

Dry basis (orsat)

carbon dioxide.....	0.47	0.46	0.44
oxygen.....	20.45	20.43	20.46
nitrogen.....	79.08	79.11	79.10

Wet basis (orsat)

carbon dioxide.....	0.45	0.44	0.42
oxygen.....	19.76	19.70	19.69
nitrogen.....	76.42	76.27	76.14
water vapor.....	3.37	3.59	3.74
Dry molecular weight.....	28.89	28.89	28.89
Wet molecular weight.....	28.53	28.50	28.48
Specific gravity.....	0.985	0.984	0.984

FO	0.957	1.022	1.000
----	-------	-------	-------

Test No. 4
Line 2 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	08-26-94	08-26-94	08-26-94

Dry basis (orsat)

carbon dioxide.....	0.27	0.29	0.28
oxygen.....	20.49	20.50	20.53
nitrogen.....	79.24	79.21	79.19

Wet basis (orsat)

carbon dioxide.....	0.26	0.28	0.27
oxygen.....	19.87	19.90	19.92
nitrogen.....	76.84	76.87	76.82
water vapor.....	3.03	2.95	2.99
Dry molecular weight.....	28.86	28.87	28.87
Wet molecular weight.....	28.53	28.55	28.54
Specific gravity.....	0.986	0.986	0.986

FO	1.519	1.379	1.321
----	-------	-------	-------

Test No. 4
Line 2 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 4	Run 5	Run 6
Date of run	08-26-94	08-26-94	08-26-94

Dry basis (orsat)

carbon dioxide.....	0.28	0.27	0.28
oxygen.....	20.56	20.29	20.29
nitrogen.....	79.16	79.44	79.43

Wet basis (orsat)

carbon dioxide.....	0.27	0.26	0.27
oxygen.....	19.90	19.63	19.70
nitrogen.....	76.61	76.86	77.10
water vapor.....	3.22	3.25	2.93

Dry molecular weight.....	28.87	28.85	28.86
Wet molecular weight.....	28.52	28.50	28.54
Specific gravity.....	0.985	0.985	0.986

FO	1.214	2.259	2.179
----	-------	-------	-------

Test No. 4
Line 2 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 7	Run 8	Run 9
Date of run	08-26-94	08-26-94	08-26-94

Dry basis (orsat)

carbon dioxide.....	0.27	0.36	0.48
oxygen.....	20.29	20.29	20.46
nitrogen.....	79.44	79.35	79.06

Wet basis (orsat)

carbon dioxide.....	0.26	0.35	0.47
oxygen.....	19.68	19.69	19.84
nitrogen.....	77.05	76.99	76.68
water vapor.....	3.01	2.98	3.01

Dry molecular weight.....	28.85	28.87	28.90
Wet molecular weight.....	28.53	28.55	28.57
Specific gravity.....	0.985	0.986	0.987

FO	2.259	1.694	0.917
----	-------	-------	-------

Test No. 4
Line 2 Press RTO Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 10 08-26-94	Run 11 08-26-94	Run 12 08-26-94
-------------	--------------------	--------------------	--------------------

Dry basis (orsat)

carbon dioxide.....	0.36	0.32	0.32
oxygen.....	20.51	20.20	20.22
nitrogen.....	79.13	79.48	79.46

Wet basis (orsat)

carbon dioxide.....	0.35	0.31	0.31
oxygen.....	19.90	19.58	19.59
nitrogen.....	76.77	77.02	77.00
water vapor.....	2.98	3.09	3.10
Dry molecular weight.....	28.88	28.86	28.86
Wet molecular weight.....	28.55	28.52	28.52
Specific gravity.....	0.986	0.985	0.985

FO	1.083	2.187	2.125
----	-------	-------	-------

Test No. 1
Line 2 Dryer RTO Stack
(Run 2)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	920
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.54
Avg. gas temp.....(DEG-F)	325
Moisture content.....(% V/V)	20.38
Avg. linear velocity.....(FT/SEC)	61.6
Gas density.....(LB/ACF)	.04507
Molecular weight.....(LB/LBMOLE)	29.21
Mass flow of gas.....(LB/HR)	357454
Volumetric flow rate.....	
actual.....(ACFM)	132198
dry standard.....(DSCFM)	67839

Test No. 1
Line 2 Dryer RTO Stack
(Run 4)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1050
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.75
Avg. gas temp.....(DEG-F)	320
Moisture content.....(% V/V)	14.54
Avg. linear velocity.....(FT/SEC)	58.4
Gas density.....(LB/ACF)	.04628
Molecular weight.....(LB/LBMOLE)	29.11
Mass flow of gas.....(LB/HR)	348185
Volumetric flow rate.....	
actual.....(ACFM)	125386
dry standard.....(DSCFM)	69468

Test No. 1
Line 2 Dryer RTO Stack

(Run 5)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1130
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.62
Avg. gas temp.....(DEG-F)	316
Moisture content.....(% V/V)	19.66
Avg. linear velocity.....(FT/SEC)	58.5
Gas density.....(LB/ACF)	.04570
Molecular weight.....(LB/LBMOLE)	29.20
Mass flow of gas.....(LB/HR)	344340
Volumetric flow rate.....	
actual.....(ACFM)	125575
dry standard.....(DSCFM)	65764

Test No. 1
Line 2 Dryer RTO Stack
(Run 6)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1220
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.54
Avg. gas temp.....(DEG-F)	319
Moisture content.....(% V/V)	19.33
Avg. linear velocity.....(FT/SEC)	59.2
Gas density.....(LB/ACF)	.04559
Molecular weight.....(LB/LBMOLE)	29.19
Mass flow of gas.....(LB/HR)	347953
Volumetric flow rate.....	
actual.....(ACFM)	127206
dry standard.....(DSCFM)	66648

Test No. 1
Line 2 Dryer RTO Stack
(Run 7)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1335
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.62
Avg. gas temp.....(DEG-F)	326
Moisture content.....(% V/V)	21.05
Avg. linear velocity.....(FT/SEC)	58.3
Gas density.....(LB/ACF)	.04486
Molecular weight.....(LB/LBMOLE)	29.20
Mass flow of gas.....(LB/HR)	336783
Volumetric flow rate.....	
actual.....(ACFM)	125123
dry standard.....(DSCFM)	63574

Test No. 1
Line 2 Dryer RTO Stack

(Run 8)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1415
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.66
Avg. gas temp.....(DEG-F)	325
Moisture content.....(% V/V)	20.99
Avg. linear velocity.....(FT/SEC)	61.1
Gas density.....(LB/ACF)	.04490
Molecular weight.....(LB/LBMOLE)	29.18
Mass flow of gas.....(LB/HR)	353642
Volumetric flow rate.....	
actual.....(ACFM)	131262
dry standard.....(DSCFM)	66822

Test No. 1
Line 2 Dryer RTO Stack
(Run 9)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1500
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.64
Avg. gas temp.....(DEG-F)	338
Moisture content.....(% V/V)	20.45
Avg. linear velocity.....(FT/SEC)	59.9
Gas density.....(LB/ACF)	.04429
Molecular weight.....(LB/LBMOLE)	29.20
Mass flow of gas.....(LB/HR)	341691
Volumetric flow rate.....	
actual.....(ACFM)	128571
dry standard.....(DSCFM)	64830

Test No. 1
Line 2 Dryer RTO Stack
(Run 10)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1545
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.73
Avg. gas temp.....(DEG-F)	348
Moisture content.....(% V/V)	19.03
Avg. linear velocity.....(FT/SEC)	57.9
Gas density.....(LB/ACF)	.04397
Molecular weight.....(LB/LBMOLE)	29.18
Mass flow of gas.....(LB/HR)	327741
Volumetric flow rate.....	
actual.....(ACFM)	124223
dry standard.....(DSCFM)	62952

Test No. 1
Line 2 Dryer RT0 Stack

(Run 11)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1630
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.66
Avg. gas temp.....(DEG-F)	321
Moisture content.....(% V/V)	20.40
Avg. linear velocity.....(FT/SEC)	58.7
Gas density.....(LB/ACF)	.04525
Molecular weight.....(LB/LBMOLE)	29.19
Mass flow of gas.....(LB/HR)	342210
Volumetric flow rate.....	
actual.....(ACFM)	126038
dry standard.....(DSCFM)	64973

Test No. 1
Line 2 Dryer RTO Stack
(Run 12)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-23-94
Time of Determination.....(HRS)	1715
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.54
Avg. gas temp.....(DEG-F)	323
Moisture content.....(% V/V)	21.50
Avg. linear velocity.....(FT/SEC)	57.8
Gas density.....(LB/ACF)	.04496
Molecular weight.....(LB/LBMOLE)	29.20
Mass flow of gas.....(LB/HR)	334646
Volumetric flow rate.....	
actual.....(ACFM)	124055
dry standard.....(DSCFM)	62925

Test No. 2
Line 1 Dryer RTO Stack
(Run 1)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	820
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.66
Avg. gas temp.....(DEG-F)	325
Moisture content.....(% V/V)	21.62
Avg. linear velocity.....(FT/SEC)	50.7
Gas density.....(LB/ACF)	.04491
Molecular weight.....(LB/LBMOLE)	29.27
Mass flow of gas.....(LB/HR)	293109
Volumetric flow rate.....	
actual.....(ACFM)	108770
dry standard.....(DSCFM)	54950

Test No. 2
Line 1 Dryer RTO Stack
(Run 2)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	910
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.51
Avg. gas temp.....(DEG-F)	335
Moisture content.....(% V/V)	23.02
Avg. linear velocity.....(FT/SEC)	50.5
Gas density.....(LB/ACF)	.04407
Molecular weight.....(LB/LBMOLE)	29.24
Mass flow of gas.....(LB/HR)	286555
Volumetric flow rate.....	
actual.....(ACFM)	108370
dry standard.....(DSCFM)	53114

Test No. 2
Line 1 Dryer RTO Stack
(run 3)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	945
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.63
Avg. gas temp.....(DEG-F)	335
Moisture content.....(% V/V)	23.84
Avg. linear velocity.....(FT/SEC)	57.3
Gas density.....(LB/ACF)	.04393
Molecular weight.....(LB/LBMOLE)	29.26
Mass flow of gas.....(LB/HR)	324320
Volumetric flow rate.....	
actual.....(ACFM)	123048
dry standard.....(DSCFM)	59647

Test No. 2
Line 1 Dryer RTO Stack

(Run 4)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1030
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.52
Avg. gas temp.....(DEG-F)	337
Moisture content.....(% V/V)	24.25
Avg. linear velocity.....(FT/SEC)	56.6
Gas density.....(LB/ACF)	.04379
Molecular weight.....(LB/LBMOLE)	29.29
Mass flow of gas.....(LB/HR)	319312
Volumetric flow rate.....	
actual.....(ACFM)	121527
dry standard.....(DSCFM)	58462

Test No. 2
Line 1 Dryer RTO Stack
(Run 5)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1115
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.67
Avg. gas temp.....(DEG-F)	335
Moisture content.....(% V/V)	24.75
Avg. linear velocity.....(FT/SEC)	55.8
Gas density.....(LB/ACF)	.04376
Molecular weight.....(LB/LBMOLE)	29.26
Mass flow of gas.....(LB/HR)	314542
Volumetric flow rate.....	
actual.....(ACFM)	119805
dry standard.....(DSCFM)	57376

Test No. 2
Line 1 Dryer RTO Stack
(Run 6)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1210
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.56
Avg. gas temp.....(DEG-F)	334
Moisture content.....(% V/V)	22.86
Avg. linear velocity.....(FT/SEC)	54.1
Gas density.....(LB/ACF)	.04415
Molecular weight.....(LB/LBMOLE)	29.25
Mass flow of gas.....(LB/HR)	307856
Volumetric flow rate.....	
actual.....(ACFM)	116205
dry standard.....(DSCFM)	57137

Test No. 2
Line 1 Dryer RTO Stack
(Run 7)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1245
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.69
Avg. gas temp.....(DEG-F)	334
Moisture content.....(% V/V)	21.29
Avg. linear velocity.....(FT/SEC)	54.8
Gas density.....(LB/ACF)	.04437
Molecular weight.....(LB/LBMOLE)	29.20
Mass flow of gas.....(LB/HR)	313313
Volumetric flow rate.....	
actual.....(ACFM)	117689
dry standard.....(DSCFM)	59025

Test No. 2
Line 1 Dryer RTO Stack
(Run 8)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1330
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.48
Avg. gas temp.....(DEG-F)	336
Moisture content.....(% V/V)	21.27
Avg. linear velocity.....(FT/SEC)	53.9
Gas density.....(LB/ACF)	.04431
Molecular weight.....(LB/LBMOLE)	29.22
Mass flow of gas.....(LB/HR)	307651
Volumetric flow rate.....	
actual.....(ACFM)	115706
dry standard.....(DSCFM)	57931

Test No. 2
Line 1 Dryer RTO Stack
(Run 9)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1415
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.68
Avg. gas temp.....(DEG-F)	335
Moisture content.....(% V/V)	20.26
Avg. linear velocity.....(FT/SEC)	54.2
Gas density.....(LB/ACF)	.04447
Molecular weight.....(LB/LBMOLE)	29.17
Mass flow of gas.....(LB/HR)	310288
Volumetric flow rate.....	
actual.....(ACFM)	116289
dry standard.....(DSCFM)	59013

Test No. 2
Line 1 Dryer RTO Stack
(Run 10)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1545
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.6
Avg. gas temp.....(DEG-F)	335
Moisture content.....(% V/V)	18.68
Avg. linear velocity.....(FT/SEC)	52.0
Gas density.....(LB/ACF)	.04468
Molecular weight.....(LB/LBMOLE)	29.11
Mass flow of gas.....(LB/HR)	299387
Volumetric flow rate.....	
actual.....(ACFM)	111668
dry standard.....(DSCFM)	57803

Test No. 2
Line 1 Dryer RTO Stack
(Run 11)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1630
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.44
Avg. gas temp.....(DEG-F)	338
Moisture content.....(% V/V)	20.78
Avg. linear velocity.....(FT/SEC)	57.6
Gas density.....(LB/ACF)	.04428
Molecular weight.....(LB/LBMOLE)	29.21
Mass flow of gas.....(LB/HR)	328830
Volumetric flow rate.....	
actual.....(ACFM)	123764
dry standard.....(DSCFM)	62201

Test No. 2
Line 1 Dryer RTO Stack
(Run 12)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-24-94
Time of Determination.....(HRS)	1715
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81
Duct area.....(SQ.FT)	35.78
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.58
Avg. gas temp.....(DEG-F)	345
Moisture content.....(% V/V)	17.67
Avg. linear velocity.....(FT/SEC)	55.3
Gas density.....(LB/ACF)	.04428
Molecular weight.....(LB/LBMOLE)	29.08
Mass flow of gas.....(LB/HR)	315260
Volumetric flow rate.....	
actual.....(ACFM)	118667
dry standard.....(DSCFM)	61419

Test No. 3
Line 1 Press RTO Stack
(Run 1)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	810
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.46
Avg. gas temp.....(DEG-F)	261
Moisture content.....(% V/V)	3.30
Avg. linear velocity.....(FT/SEC)	50.8
Gas density.....(LB/ACF)	.05218
Molecular weight.....(LB/LBMOLE)	28.88
Mass flow of gas.....(LB/HR)	300605
Volumetric flow rate.....	
actual.....(ACFM)	96024
dry standard.....(DSCFM)	65422

Test No. 3
Line 1 Press RTO Stack
(Run 2)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	845
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.68
Avg. gas temp.....(DEG-F)	259
Moisture content.....(% V/V)	3.43
Avg. linear velocity.....(FT/SEC)	51.8
Gas density.....(LB/ACF)	.05224
Molecular weight.....(LB/LBMOLE)	28.86
Mass flow of gas.....(LB/HR)	306843
Volumetric flow rate.....	
actual.....(ACFM)	97900
dry standard.....(DSCFM)	66759

Test No. 3
Line 1 Press RTO Stack
(Run 3)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	930
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.47
Avg. gas temp.....(DEG-F)	248
Moisture content.....(% V/V)	3.34
Avg. linear velocity.....(FT/SEC)	51.3
Gas density.....(LB/ACF)	.05314
Molecular weight.....(LB/LBMOLE)	28.88
Mass flow of gas.....(LB/HR)	308927
Volumetric flow rate.....	
actual.....(ACFM)	96894
dry standard.....(DSCFM)	67198

Test No. 3
Line 1 Press RTO Stack
(Run 4)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1015
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.65
Avg. gas temp.....(DEG-F)	256
Moisture content.....(% V/V)	3.31
Avg. linear velocity.....(FT/SEC)	51.4
Gas density.....(LB/ACF)	.05252
Molecular weight.....(LB/LBMOLE)	28.88
Mass flow of gas.....(LB/HR)	306426
Volumetric flow rate.....	
actual.....(ACFM)	97242
dry standard.....(DSCFM)	66676

Test No. 3
Line 1 Press RTO Stack

(Run 5)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1145
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.68
Avg. gas temp.....(DEG-F)	263
Moisture content.....(% V/V)	3.00
Avg. linear velocity.....(FT/SEC)	50.7
Gas density.....(LB/ACF)	.05206
Molecular weight.....(LB/LBMOLE)	28.87
Mass flow of gas.....(LB/HR)	299518
Volumetric flow rate.....	
actual.....(ACFM)	95890
dry standard.....(DSCFM)	65316

Test No. 3
Line 1 Press RTO Stack

(Run 6)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1230
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.42
Avg. gas temp.....(DEG-F)	260
Moisture content.....(% V/V)	3.33
Avg. linear velocity.....(FT/SEC)	50.7
Gas density.....(LB/ACF)	.05222
Molecular weight.....(LB/LBMOLE)	28.86
Mass flow of gas.....(LB/HR)	300272
Volumetric flow rate.....	
actual.....(ACFM)	95840
dry standard.....(DSCFM)	65374

Test No. 3
Line 1 Press RTO Stack

(Run 7)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1315
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.66
Avg. gas temp.....(DEG-F)	267
Moisture content.....(% V/V)	3.31
Avg. linear velocity.....(FT/SEC)	50.7
Gas density.....(LB/ACF)	.05172
Molecular weight.....(LB/LBMOLE)	28.88
Mass flow of gas.....(LB/HR)	297286
Volumetric flow rate.....	
actual.....(ACFM)	95792
dry standard.....(DSCFM)	64686

Test No. 3
Line 1 Press RTO Stack
(Run 8)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1400
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.58
Avg. gas temp.....(DEG-F)	264
Moisture content.....(% V/V)	3.32
Avg. linear velocity.....(FT/SEC)	51.7
Gas density.....(LB/ACF)	.05194
Molecular weight.....(LB/LBMOLE)	28.88
Mass flow of gas.....(LB/HR)	304573
Volumetric flow rate.....	
actual.....(ACFM)	97731
dry standard.....(DSCFM)	66275

Test No. 3
Line 1 Press RTO Stack
(Run 9)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1445
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.69
Avg. gas temp.....(DEG-F)	265
Moisture content.....(% V/V)	3.32
Avg. linear velocity.....(FT/SEC)	49.0
Gas density.....(LB/ACF)	.05189
Molecular weight.....(LB/LBMOLE)	28.90
Mass flow of gas.....(LB/HR)	288453
Volumetric flow rate.....	
actual.....(ACFM)	92652
dry standard.....(DSCFM)	62727

Test No. 3
Line 1 Press RTO Stack
(Run 10)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1530
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.58
Avg. gas temp.....(DEG-F)	264
Moisture content.....(% V/V)	3.37
Avg. linear velocity.....(FT/SEC)	51.4
Gas density.....(LB/ACF)	.05196
Molecular weight.....(LB/LBMOLE)	28.89
Mass flow of gas.....(LB/HR)	302939
Volumetric flow rate.....	
actual.....(ACFM)	97168
dry standard.....(DSCFM)	65860

Test No. 3
Line 1 Press RTO Stack
(Run 11)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1615
Barometric pressure.....(IN.HG)	28.82
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.58
Avg. gas temp.....(DEG-F)	263
Moisture content.....(% V/V)	3.59
Avg. linear velocity.....(FT/SEC)	50.8
Gas density.....(LB/ACF)	.05199
Molecular weight.....(LB/LBMOLE)	28.89
Mass flow of gas.....(LB/HR)	299336
Volumetric flow rate.....	
actual.....(ACFM)	95968
dry standard.....(DSCFM)	64988

Test No. 3
Line 1 Press RTO Stack
(run 12)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-25-94
Time of Determination.....(HRS)	1700
Barometric pressure.....(IN.HG)	28.8
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.56
Avg. gas temp.....(DEG-F)	266
Moisture content.....(% V/V)	3.74
Avg. linear velocity.....(FT/SEC)	51.0
Gas density.....(LB/ACF)	.05170
Molecular weight.....(LB/LBMOLE)	28.89
Mass flow of gas.....(LB/HR)	299309
Volumetric flow rate.....	
actual.....(ACFM)	96482
dry standard.....(DSCFM)	64923

Test No. 4
Line 2 Press RTO Stack
(Run 1)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	755
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.5
Avg. gas temp.....(DEG-F)	249
Moisture content.....(% V/V)	3.03
Avg. linear velocity.....(FT/SEC)	58.8
Gas density.....(LB/ACF)	.05307
Molecular weight.....(LB/LBMOLE)	28.86
Mass flow of gas.....(LB/HR)	353882
Volumetric flow rate.....	
actual.....(ACFM)	111143
dry standard.....(DSCFM)	77185

Test No. 4
Line 2 Press RTO Stack
(Run 2)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	830
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.8
Avg. gas temp.....(DEG-F)	240
Moisture content.....(% V/V)	2.95
Avg. linear velocity.....(FT/SEC)	58.3
Gas density.....(LB/ACF)	.05373
Molecular weight.....(LB/LBMOLE)	28.87
Mass flow of gas.....(LB/HR)	355563
Volumetric flow rate.....	
actual.....(ACFM)	110291
dry standard.....(DSCFM)	77583

Test No. 4
Line 2 Press RTO Stack
(Run 3)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	920
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.68
Avg. gas temp.....(DEG-F)	245
Moisture content.....(% V/V)	2.99
Avg. linear velocity.....(FT/SEC)	57.3
Gas density.....(LB/ACF)	.05336
Molecular weight.....(LB/LBMOLE)	28.87
Mass flow of gas.....(LB/HR)	346752
Volumetric flow rate.....	
actual.....(ACFM)	108311
dry standard.....(DSCFM)	75642

Test No. 4
Line 2 Press RTO Stack
(Run 4)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1100
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.78
Avg. gas temp.....(DEG-F)	247
Moisture content.....(% V/V)	3.22
Avg. linear velocity.....(FT/SEC)	58.3
Gas density.....(LB/ACF)	.05315
Molecular weight.....(LB/LBMOLE)	28.87
Mass flow of gas.....(LB/HR)	351425
Volumetric flow rate.....	
actual.....(ACFM)	110202
dry standard.....(DSCFM)	76543

Test No. 4
Line 2 Press RTO Stack
(Run 5)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1145
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.68
Avg. gas temp.....(DEG-F)	250
Moisture content.....(% V/V)	3.25
Avg. linear velocity.....(FT/SEC)	58.6
Gas density.....(LB/ACF)	.05291
Molecular weight.....(LB/LBMOLE)	28.85
Mass flow of gas.....(LB/HR)	351867
Volumetric flow rate.....	
actual.....(ACFM)	110840
dry standard.....(DSCFM)	76657

Test No. 4
Line 2 Press RTO Stack
(Run 6)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1230
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.84
Avg. gas temp.....(DEG-F)	245
Moisture content.....(% V/V)	2.93
Avg. linear velocity.....(FT/SEC)	58.2
Gas density.....(LB/ACF)	.05333
Molecular weight.....(LB/LBMOLE)	28.86
Mass flow of gas.....(LB/HR)	352251
Volumetric flow rate.....	
actual.....(ACFM)	110084
dry standard.....(DSCFM)	76896

Test No. 4
Line 2 Press RTO Stack

(Run 7)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1315
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.51
Avg. gas temp.....(DEG-F)	251
Moisture content.....(% V/V)	3.01
Avg. linear velocity.....(FT/SEC)	58.9
Gas density.....(LB/ACF)	.05291
Molecular weight.....(LB/LBMOLE)	28.85
Mass flow of gas.....(LB/HR)	353334
Volumetric flow rate.....	
actual.....(ACFM)	111309
dry standard.....(DSCFM)	77097

Test No. 4
Line 2 Press RTO Stack
(Run 8)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1400
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.65
Avg. gas temp.....(DEG-F)	250
Moisture content.....(% V/V)	2.98
Avg. linear velocity.....(FT/SEC)	58.7
Gas density.....(LB/ACF)	.05299
Molecular weight.....(LB/LBMOLE)	28.87
Mass flow of gas.....(LB/HR)	352746
Volumetric flow rate.....	
actual.....(ACFM)	110940
dry standard.....(DSCFM)	76946

Test No. 4
Line 2 Press RTO Stack
(Run 9)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1445
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.72
Avg. gas temp.....(DEG-F)	250
Moisture content.....(% V/V)	3.01
Avg. linear velocity.....(FT/SEC)	58.1
Gas density.....(LB/ACF)	.05302
Molecular weight.....(LB/LBMOLE)	28.90
Mass flow of gas.....(LB/HR)	349209
Volumetric flow rate.....	
actual.....(ACFM)	109763
dry standard.....(DSCFM)	76092

Test No. 4
Line 2 Press RTO Stack
(Run 10)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1530
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.68
Avg. gas temp.....(DEG-F)	257
Moisture content.....(% V/V)	2.98
Avg. linear velocity.....(FT/SEC)	58.8
Gas density.....(LB/ACF)	.05249
Molecular weight.....(LB/LBMOLE)	28.88
Mass flow of gas.....(LB/HR)	349890
Volumetric flow rate.....	
actual.....(ACFM)	111102
dry standard.....(DSCFM)	76300

Test No. 4
Line 2 Press RTO Stack
(Run 11)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1615
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.65
Avg. gas temp.....(DEG-F)	247
Moisture content.....(% V/V)	3.09
Avg. linear velocity.....(FT/SEC)	57.9
Gas density.....(LB/ACF)	.05318
Molecular weight.....(LB/LBMOLE)	28.86
Mass flow of gas.....(LB/HR)	348917
Volumetric flow rate.....	
actual.....(ACFM)	109355
dry standard.....(DSCFM)	76082

Test No. 4
Line 2 Press RTO Stack
(Run 12)

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	08-26-94
Time of Determination.....(HRS)	1700
Barometric pressure.....(IN.HG)	28.81
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.84
Avg. gas temp.....(DEG-F)	250
Moisture content.....(% V/V)	3.10
Avg. linear velocity.....(FT/SEC)	57.6
Gas density.....(LB/ACF)	.05293
Molecular weight.....(LB/LBMOLE)	28.86
Mass flow of gas.....(LB/HR)	345633
Volumetric flow rate.....	
actual.....(ACFM)	108839
dry standard.....(DSCFM)	75359

APPENDIX A

SAMPLING TRAIN CALIBRATION DATA

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 29, 1994

Meter Box No. : CEM Trailer (Rockwell Dry Test Meter Serial No. 964554)

Date of Last Calibration: July 22, 1994

Calibration Technician: S. Bainville

Wet Test Meter No.: American Meter AL-17

Date of Use	Report No.	Initial Meter		Final Meter		Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
		Reading		Reading			
July 27, 1994	4-3470	592.610		600.600	7.990		7.990
August 23, 1994	4-3688	600.627		655.078	54.451		62.441

* Total volume through meter since last calibration.

Meter Box No. TR1
Serial No. DTH 964554
Met Test Meter No. AL-17 (.05 CF/REV)
Technician. SLB

INTERPOLL LABORATORIES

MINIMODULE CALIBRATION SHEET
Flow Rate Range 0-0.13 CFM
(0-4 LPM)

Bar. Press. 28.89 in. Hg

Rota- meter Reading (cc/min)	ΔP_d (IN/IN/HC)	Gas Volume Test Meter (ft ³)	Cal. Index ♦ (%)	Diff. Met. Test Meter ΔP_w (in. WC)	Gas Volume Dry test meter (ft ³)		Gas temperatures			Time θ (min/sec)	Meter Coeff.	Rota- meter Coeff.
					V_{dl}	V_{df}	Met Test t_w (°F)	Dry Test				
								t_{dl} (°F)				
1000	.001	.6	99.55	0.04	591.000	591.598	73.5	68		9920	Y	Z
1000	.001	.4	99.55	0.04	591.700	592.097	74	68		9932		
1000	.001	.4	99.55	0.04	592.200	592.598	74	68		9927		
										10/11 Average:	9937	

Water was in tolerance ☒

Gas Meter Bimetallic Therm. Calibration/Verification

Water was not in tolerance ☒; readjusted linkage

☐ 2.5% (Out of control) ☐ Recalibrated //

Water was not in tolerance ☒; changed dry test waters

☒ $\leq 2.50F$ (1a control) ☐ No action required

Approved by  Date 8/1/94

Temperature compensated
• Verified against mercury in glass thermometer or calibrated platinum resistance thermometer.

*** Based on AL-17 wet test meter calibration in August 1989 against Bell Prover (NBS Traceable) - Carl Poe Co.

PULSATION RANGE

30

20

10

0

A-3

PROOF

01

00

99

CORRECT VOLUME

INDEX READING x PROOF = 100

2

4

6

8


10

FLOW RATE - CUBIC FEET OF AIR PER HOUR

DAVID BANKS
AUGUST, 1989

Data obtained on an American 5 Ft.
Bell Prover, Serial No. 2260. Traceable
to the Bureau of Standards. Reference
No. 106870, PI-TAPE.

AL-17 American Wet Test Meter
Serial No. P-718
Stainless Steel w/Removable Back
Calibrated with Saturated Air
Water Temp. 74° F.
Air Temp. 74° F.
Inlet Pressure 2" H₂O Constant
Calibration Rate: 4 CFH Air
Capacity Rate: 8 CFH Air
Restricted Outlet for Rate Deviation.



Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test:

Vendor Omega
 Model HH81 Serial Number 74JX0223
 Range -300 - 2100 °F Thermocouple Type K
 Date of Calibration 8-1-94 Technician Bob

Method of Calibration:

- ☐ Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- ☒ Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-2	-2	.21
100	100	99	1	.17
200	200	200	0	0
300	300	299	1	.13
400	400	399	1	.11
500	500	499	1	.10
600	600	601	1	.09
700	700	700	0	0
800	800	802	2	.15
900	900	901	1	.07
1000	1000	1001	1	.06
1100	1100	1100	0	0
1200	1200	1201	1	.06
1300	1300	1300	0	0
1400	1400	1402	2	.10
1500	1500	1501	1	.05
1600	1600	1603	3	.14
1700	1700	1701	1	.04
1800	1800	1804	4	.17
1900	1900	1901	1	.04
2000	2000	2001	1	.04
2100	2100	2099	1	.04
Averages:			1	.08

OF = off scale response by unit under test (°F)
 % dev = $100 \Delta t / (460 + t)$

- ☒ Unit in tolerance
☐ Unit was not in tolerance: recalibrated - See new calibration sheet.

Interpoll Laboratories, Inc.
(612) 786-6020

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 27-8

Pitot tube dimensions:

1. External tubing diameter (D_t) 316 IN.
2. Base to Side A opening plane (P_A) 460 IN.
3. Base to Side B opening plane (P_B) 460 IN.

Alignment:

4. α_1 $< 10^\circ$ 0
5. α_2 $< 10^\circ$ 0
6. β_1 $< 5^\circ$ 0
7. β_2 $< 5^\circ$ 0
8. Z $< .125"$ 0
9. W $< .0625"$.01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle 750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 760 IN.

- ☒ Meets all EPA design criteria thus $C_p = 0.84$
☐ Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

E. J. [Signature]

INTERPOLL LABORATORIES
(612)786-6020
Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 2-7-94
Technician BB
Mercury Column Barometer No. CAA
Aneroid Barometer No. 107 23629

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} -P _{bm})
28.78	28	.129	28.85	28.84	.01

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. NO

Has problem been alleviated? Yes/No. How? _____

***Note**

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

S-312

APPENDIX B

REFERENCE METHOD RESULTS

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH11
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	08:31:00	241	2.58	18.00
235	08:32:00	283	2.83	17.66
235	08:33:00	278	2.63	17.89
235	08:34:00	235	2.59	17.89
235	08:35:00	214	2.48	18.06
235	08:36:00	294	2.73	17.99
235	08:37:00	281	2.81	17.61
235	08:38:00	263	2.85	17.69
235	08:39:00	294	2.39	18.04
235	08:40:00	213	2.51	18.21
235	08:41:00	274	2.59	17.88
235	08:42:00	232	2.63	17.97
235	08:43:00	256	3.09	17.47
235	08:44:00	225	2.55	17.76
235	08:45:00	233	2.85	17.85
235	08:46:00	224	2.71	17.89
235	08:47:00	308	3.14	17.55
235	08:48:00	301	3.12	17.27
235	08:49:00	327	3.26	17.29
235	08:50:00	339	2.90	17.51
235	08:51:00	332	2.85	17.82
235	08:52:00	321	2.89	17.63
235	08:53:00	278	3.00	17.63
235	08:54:00	273	3.10	17.30
235	08:55:00	231	2.95	17.57
235	08:56:00	288	2.89	17.66
235	08:57:00	227	2.82	17.82
235	08:58:00	359	3.19	17.53
235	08:59:00	335	3.32	17.10
235	09:00:00	345	3.38	17.14
Run Average		277	2.85	17.69

Interpoll Laboratories, Inc.

(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH12
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	09:16:00	415	3.33	17.01
235	09:17:00	387	3.15	17.21
235	09:18:00	346	3.04	17.63
235	09:19:00	339	3.41	17.24
235	09:20:00	576	3.41	17.07
235	09:21:00	522	3.76	16.78
235	09:22:00	585	3.66	16.67
235	09:23:00	547	3.44	16.93
235	09:24:00	385	2.89	17.54
235	09:25:00	309	3.01	17.62
235	09:26:00	421	3.39	17.32
235	09:27:00	494	3.63	16.75
235	09:28:00	487	3.48	16.85
235	09:29:00	466	3.26	17.40
235	09:30:00	514	3.68	16.91
235	09:31:00	726	3.46	16.95
235	09:32:00	619	3.62	16.89
235	09:33:00	599	3.48	16.88
235	09:34:00	559	3.02	17.29
235	09:35:00	406	3.08	17.59
235	09:36:00	494	3.31	17.22
235	09:37:00	550	3.03	17.49
235	09:38:00	417	3.44	17.09
235	09:39:00	452	3.37	16.97
235	09:40:00	345	2.96	17.39
235	09:41:00	293	2.57	17.99
235	09:42:00	272	2.82	17.78
235	09:43:00	339	2.95	17.74
235	09:44:00	319	3.02	17.34
235	09:45:00	299	2.93	17.51
Run Average		449	3.25	17.24

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH13
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	10:01:00	150	2.06	18.46
235	10:02:00	156	1.99	18.66
235	10:03:00	135	1.89	18.75
235	10:04:00	155	1.91	18.89
235	10:05:00	197	2.14	18.62
235	10:06:00	141	1.96	18.55
235	10:07:00	152	2.23	18.46
235	10:08:00	173	1.83	18.76
235	10:09:00	147	2.03	18.84
235	10:10:00	159	1.97	18.61
235	10:11:00	154	2.17	18.63
235	10:12:00	187	2.57	18.02
235	10:13:00	190	1.91	18.59
235	10:14:00	181	2.28	18.56
235	10:15:00	158	1.92	18.60
235	10:16:00	206	2.30	18.67
235	10:17:00	162	2.30	18.12
235	10:18:00	177	2.26	18.43
235	10:19:00	223	2.33	18.29
235	10:20:00	139	2.07	18.63
235	10:21:00	208	2.39	18.28
235	10:22:00	146	2.31	18.27
235	10:23:00	211	2.67	18.01
235	10:24:00	189	2.27	18.16
235	10:25:00	162	2.48	18.39
235	10:26:00	180	2.45	18.10
235	10:27:00	187	2.67	18.20
235	10:28:00	218	2.93	17.56
235	10:29:00	172	2.60	17.92
235	10:30:00	219	2.70	18.02
Run Average		174	2.25	18.40

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH14
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RT0 Stack -- Run 4

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	10:46:00	137	2.05	18.47
235	10:47:00	157	2.31	18.47
235	10:48:00	217	2.68	18.14
235	10:49:00	344	2.74	17.99
235	10:50:00	454	3.09	17.41
235	10:51:00	647	3.41	17.26
235	10:52:00	729	2.77	17.80
235	10:53:00	495	2.62	17.80
235	10:54:00	350	2.20	18.37
235	10:55:00	163	1.77	18.86
235	10:56:00	154	1.89	18.64
235	10:57:00	141	2.11	18.74
235	10:58:00	162	1.94	18.73
235	10:59:00	200	2.42	18.37
235	11:00:00	334	2.70	18.11
235	11:01:00	363	2.68	17.82
235	11:02:00	325	2.65	17.81
235	11:03:00	260	2.18	18.31
235	11:04:00	133	1.64	19.15
235	11:05:00	131	1.66	19.04
235	11:06:00	149	1.94	19.18
235	11:07:00	105	1.97	18.61
235	11:08:00	112	2.32	18.43
235	11:09:00	140	2.25	18.52
235	11:10:00	117	2.22	18.59
235	11:11:00	152	2.41	18.32
235	11:12:00	119	2.43	18.27
235	11:13:00	148	2.25	18.35
235	11:14:00	155	2.36	18.42
235	11:15:00	133	2.06	18.64
Run Average		241	2.32	18.35

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH15
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 5

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	11:31:00	307	3.16	17.42
235	11:32:00	285	3.32	17.25
235	11:33:00	438	3.36	17.09
235	11:34:00	434	3.50	16.99
235	11:35:00	416	3.53	16.86
235	11:36:00	439	3.42	17.21
235	11:37:00	390	3.25	17.21
235	11:38:00	311	3.10	17.36
235	11:39:00	309	3.12	17.46
235	11:40:00	281	3.34	17.09
235	11:41:00	307	3.19	17.11
235	11:42:00	273	2.88	17.70
235	11:43:00	249	3.20	17.44
235	11:44:00	424	3.31	17.17
235	11:45:00	384	3.39	17.11
235	11:46:00	383	3.64	16.82
235	11:47:00	488	3.31	16.95
235	11:48:00	364	3.10	17.44
235	11:49:00	341	3.28	17.24
235	11:50:00	450	3.29	17.26
235	11:51:00	373	3.27	17.04
235	11:52:00	266	3.08	17.25
235	11:53:00	231	2.49	17.96
235	11:54:00	191	2.86	17.81
235	11:55:00	248	2.70	17.75
235	11:56:00	207	3.04	17.51
235	11:57:00	226	3.03	17.40
235	11:58:00	258	2.98	17.44
235	11:59:00	242	2.87	17.67
235	12:00:00	250	3.21	17.41
Run Average		325	3.17	17.31

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH16
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 6

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	12:16:00	263	3.03	17.57
235	12:17:00	343	2.99	17.43
235	12:18:00	324	3.25	17.25
235	12:19:00	339	3.25	17.13
235	12:20:00	332	3.01	17.29
235	12:21:00	293	2.79	17.68
235	12:22:00	255	2.94	17.64
235	12:23:00	407	3.01	17.54
235	12:24:00	337	3.08	17.32
235	12:25:00	345	3.27	17.15
235	12:26:00	389	2.88	17.52
235	12:27:00	289	2.93	17.63
235	12:28:00	369	3.08	17.41
235	12:29:00	365	3.28	17.20
235	12:30:00	442	3.45	16.91
235	12:31:00	382	2.99	17.33
235	12:32:00	339	2.90	17.61
235	12:33:00	265	2.83	17.62
235	12:34:00	339	3.08	17.56
235	12:35:00	302	3.27	17.10
235	12:36:00	349	3.47	16.97
235	12:37:00	435	3.01	17.21
235	12:38:00	357	3.10	17.45
235	12:39:00	442	3.25	17.21
235	12:40:00	413	3.30	17.07
235	12:41:00	418	3.37	16.97
235	12:42:00	454	3.28	17.01
235	12:43:00	461	3.10	17.41
235	12:44:00	427	3.33	17.19
235	12:45:00	609	3.41	17.14
Run Average		369	3.13	17.32

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH17
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 7

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	13:31:00	590	3.28	16.79
235	13:32:00	500	2.57	17.45
235	13:33:00	263	2.59	17.89
235	13:34:00	314	2.62	17.65
235	13:35:00	297	2.63	17.79
235	13:36:00	286	3.15	17.21
235	13:37:00	438	3.15	17.05
235	13:38:00	425	3.06	17.27
235	13:39:00	490	3.37	17.03
235	13:40:00	738	3.32	16.99
235	13:41:00	599	3.46	16.75
235	13:42:00	582	3.48	16.73
235	13:43:00	634	3.22	17.06
235	13:44:00	390	2.92	17.32
235	13:45:00	445	3.04	17.27
235	13:46:00	523	3.41	17.11
235	13:47:00	721	3.70	16.47
235	13:48:00	705	3.52	16.60
235	13:49:00	771	3.71	16.69
235	13:50:00	846	3.90	16.40
235	13:51:00	1060	4.01	16.29
235	13:52:00	1015	4.17	15.82
235	13:53:00	1012	3.88	16.11
235	13:54:00	789	2.73	17.17
235	13:55:00	299	2.62	17.75
235	13:56:00	246	2.72	17.70
235	13:57:00	290	2.60	17.63
235	13:58:00	223	3.16	17.32
235	13:59:00	432	3.38	16.89
235	14:00:00	680	3.77	16.70
Run Average		553	3.24	17.03

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH18
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 8

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	14:16:00	758	3.01	17.20
235	14:17:00	298	2.43	18.10
235	14:18:00	247	2.31	18.22
235	14:19:00	233	2.58	18.15
235	14:20:00	278	3.18	17.45
235	14:21:00	314	2.97	17.56
235	14:22:00	378	3.42	17.26
235	14:23:00	457	3.50	17.14
235	14:24:00	728	3.42	17.07
235	14:25:00	495	3.33	17.17
235	14:26:00	554	3.35	17.05
235	14:27:00	453	2.73	17.75
235	14:28:00	321	2.83	17.89
235	14:29:00	452	3.14	17.50
235	14:30:00	456	3.24	17.35
235	14:31:00	472	3.58	17.00
235	14:32:00	532	3.23	17.09
235	14:33:00	395	2.96	17.56
235	14:34:00	245	2.82	17.80
235	14:35:00	260	2.60	17.99
235	14:36:00	188	2.71	17.80
235	14:37:00	202	2.89	17.73
235	14:38:00	260	2.65	17.96
235	14:39:00	192	2.95	17.81
235	14:40:00	305	2.83	17.63
235	14:41:00	229	2.99	17.75
235	14:42:00	314	3.29	17.22
235	14:43:00	313	2.87	17.59
235	14:44:00	316	3.30	17.43
235	14:45:00	463	3.31	17.26
Run Average		370	3.01	17.55

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH19
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 9

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	15:01:00	433	3.45	17.21
235	15:02:00	531	3.39	17.02
235	15:03:00	423	3.36	17.07
235	15:04:00	355	3.14	17.18
235	15:05:00	287	2.70	17.60
235	15:06:00	201	2.35	18.16
235	15:07:00	213	3.06	17.71
235	15:08:00	398	3.09	17.42
235	15:09:00	282	3.33	17.20
235	15:10:00	578	3.72	16.68
235	15:11:00	657	3.29	17.13
235	15:12:00	465	3.38	17.18
235	15:13:00	562	3.14	17.21
235	15:14:00	369	3.11	17.35
235	15:15:00	317	3.14	17.30
235	15:16:00	331	2.94	17.48
235	15:17:00	288	2.99	17.57
235	15:18:00	394	3.29	17.32
235	15:19:00	642	3.61	16.96
235	15:20:00	654	3.73	16.59
235	15:21:00	628	3.47	16.78
235	15:22:00	472	2.84	17.58
235	15:23:00	300	3.09	17.54
235	15:24:00	390	2.84	17.54
235	15:25:00	278	2.96	17.55
235	15:26:00	316	3.24	17.24
235	15:27:00	366	3.06	17.33
235	15:28:00	311	2.96	17.56
235	15:29:00	360	3.21	17.36
235	15:30:00	470	3.33	17.20
Run Average		409	3.17	17.30

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH110
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 10

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	15:46:00	327	2.86	17.48
235	15:47:00	328	2.86	17.70
235	15:48:00	343	3.40	16.99
235	15:49:00	406	3.40	16.89
235	15:50:00	394	3.14	17.16
235	15:51:00	391	3.01	17.35
235	15:52:00	355	3.07	17.36
235	15:53:00	334	3.00	17.37
235	15:54:00	291	3.10	17.17
235	15:55:00	267	2.93	17.33
235	15:56:00	257	2.70	17.70
235	15:57:00	250	2.90	17.65
235	15:58:00	404	3.23	17.23
235	15:59:00	495	3.39	17.04
235	16:00:00	500	3.60	16.68
235	16:01:00	447	3.21	16.86
235	16:02:00	328	2.74	17.65
235	16:03:00	255	2.79	17.68
235	16:04:00	332	2.73	17.65
235	16:05:00	261	3.07	17.41
235	16:06:00	405	3.49	16.93
235	16:07:00	589	3.42	16.99
235	16:08:00	691	3.59	16.91
235	16:09:00	927	3.51	16.72
235	16:10:00	686	3.28	17.07
235	16:11:00	371	2.63	17.47
235	16:12:00	264	2.50	17.84
235	16:13:00	284	2.55	18.06
235	16:14:00	235	2.68	17.79
235	16:15:00	366	3.09	17.62
Run Average		393	3.06	17.33

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH111
Job Number: 4-3677
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 11

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	16:31:00	273	2.19	18.27
235	16:32:00	319	2.87	17.87
235	16:33:00	327	3.22	17.13
235	16:34:00	384	3.37	16.98
235	16:35:00	605	3.57	16.98
235	16:36:00	824	3.85	16.53
235	16:37:00	820	3.45	16.71
235	16:38:00	520	2.84	17.31
235	16:39:00	297	2.62	17.68
235	16:40:00	288	2.43	17.99
235	16:41:00	266	2.78	17.75
235	16:42:00	322	3.14	17.48
235	16:43:00	669	3.67	16.90
235	16:44:00	847	4.03	16.24
235	16:45:00	908	3.79	16.32
235	16:46:00	739	3.05	17.12
235	16:47:00	329	2.94	17.59
235	16:48:00	412	2.53	17.68
235	16:49:00	233	2.59	17.86
235	16:50:00	257	2.96	17.49
235	16:51:00	275	2.74	17.61
235	16:52:00	292	3.11	17.57
235	16:53:00	634	3.64	16.84
235	16:54:00	977	3.90	16.54
235	16:55:00	1047	4.19	16.01
235	16:56:00	877	3.54	16.30
235	16:57:00	446	2.40	17.81
235	16:58:00	282	2.44	18.10
235	16:59:00	360	2.45	18.01
235	17:00:00	341	3.26	17.33
Run Average		506	3.12	17.27

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH112
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Stack -- Run 12

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
235	17:16:00	564	3.11	17.12
235	17:17:00	317	2.93	17.31
235	17:18:00	305	3.14	17.24
235	17:19:00	334	2.58	17.62
235	17:20:00	281	2.78	17.86
235	17:21:00	349	3.00	17.39
235	17:22:00	372	3.40	17.11
235	17:23:00	494	3.49	16.71
235	17:24:00	481	3.33	16.90
235	17:25:00	479	3.00	17.35
235	17:26:00	377	3.33	17.29
235	17:27:00	653	3.33	17.02
235	17:28:00	511	3.59	16.79
235	17:29:00	617	3.62	16.56
235	17:30:00	448	2.74	17.36
235	17:31:00	271	2.84	17.78
235	17:32:00	423	3.17	17.19
235	17:33:00	425	3.20	17.31
235	17:34:00	409	3.39	16.87
235	17:35:00	443	3.56	16.74
235	17:36:00	417	2.84	17.29
235	17:37:00	309	3.01	17.60
235	17:38:00	460	3.18	17.13
235	17:39:00	397	3.23	17.20
235	17:40:00	487	3.67	16.74
235	17:41:00	580	3.42	16.62
235	17:42:00	477	3.27	17.28
235	17:43:00	560	3.40	17.00
235	17:44:00	580	3.50	16.95
235	17:45:00	644	3.87	16.35
Run Average		449	3.23	17.12

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH21
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	08:16:00	216	3.31	17.28
236	08:17:00	218	3.12	17.47
236	08:18:00	218	3.31	17.31
236	08:19:00	212	3.35	17.08
236	08:20:00	221	3.38	17.23
236	08:21:00	303	3.53	16.93
236	08:22:00	280	3.32	17.29
236	08:23:00	305	3.66	16.95
236	08:24:00	274	3.47	16.90
236	08:25:00	244	3.38	17.18
236	08:26:00	274	3.44	17.09
236	08:27:00	349	3.63	17.01
236	08:28:00	322	3.58	16.91
236	08:29:00	290	3.65	16.86
236	08:30:00	398	3.83	16.74
236	08:31:00	376	3.81	16.65
236	08:32:00	423	3.83	16.75
236	08:33:00	484	4.08	16.40
236	08:34:00	399	3.88	16.52
236	08:35:00	399	3.81	16.72
236	08:36:00	431	3.93	16.72
236	08:37:00	488	4.01	16.47
236	08:38:00	461	4.19	16.27
236	08:39:00	525	4.15	16.22
236	08:40:00	558	4.18	16.28
236	08:41:00	672	4.36	16.20
236	08:42:00	775	4.46	15.98
236	08:43:00	637	4.13	16.09
236	08:44:00	436	3.77	16.67
236	08:45:00	353	3.55	16.86
Run Average		385	3.74	16.77

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH22
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	09:01:00	330	3.39	17.17
236	09:02:00	310	3.33	16.90
236	09:03:00	235	3.25	17.11
236	09:04:00	292	3.37	17.02
236	09:05:00	306	3.38	17.12
236	09:06:00	367	3.40	16.98
236	09:07:00	271	3.20	17.06
236	09:08:00	201	3.07	17.37
236	09:09:00	237	3.23	17.18
236	09:10:00	248	3.37	17.22
236	09:11:00	345	3.65	16.73
236	09:12:00	300	3.58	16.70
236	09:13:00	335	3.58	16.81
236	09:14:00	377	3.51	16.84
236	09:15:00	438	3.71	16.80
236	09:16:00	521	4.01	16.46
236	09:17:00	669	4.26	15.94
236	09:18:00	654	3.65	16.31
236	09:19:00	457	2.31	17.94
236	09:20:00	339	3.26	17.48
236	09:21:00	313	3.42	16.95
236	09:22:00	278	3.53	16.82
236	09:23:00	344	3.65	16.80
236	09:24:00	425	3.84	16.58
236	09:25:00	536	3.96	16.43
236	09:26:00	526	4.02	16.23
236	09:27:00	510	4.03	16.19
236	09:28:00	618	4.09	16.20
236	09:29:00	565	4.18	16.13
236	09:30:00	686	3.89	16.34
Run Average		401	3.57	16.79

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH23
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	09:46:00	629	4.33	15.92
236	09:47:00	771	4.35	15.97
236	09:48:00	806	4.31	16.02
236	09:49:00	869	4.15	16.15
236	09:50:00	727	4.14	16.18
236	09:51:00	638	3.96	16.29
236	09:52:00	622	3.54	16.71
236	09:53:00	331	2.98	17.44
236	09:54:00	258	3.07	17.53
236	09:55:00	277	3.37	17.14
236	09:56:00	247	2.95	17.34
236	09:57:00	213	3.11	17.52
236	09:58:00	246	3.19	17.36
236	09:59:00	228	2.89	17.56
236	10:00:00	212	3.37	17.23
236	10:01:00	287	3.57	16.96
236	10:02:00	373	3.65	16.81
236	10:03:00	402	3.67	16.90
236	10:04:00	411	3.72	16.76
236	10:05:00	398	3.87	16.50
236	10:06:00	399	3.71	16.73
236	10:07:00	404	3.76	16.69
236	10:08:00	516	3.91	16.64
236	10:09:00	606	4.17	16.31
236	10:10:00	605	4.29	15.98
236	10:11:00	687	4.14	16.20
236	10:12:00	647	3.98	16.38
236	10:13:00	645	3.84	16.64
236	10:14:00	530	3.73	16.65
236	10:15:00	404	3.63	16.77
Run Average		480	3.71	16.71

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH24
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 4

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	10:31:00	401	3.64	16.85
236	10:32:00	411	3.88	16.68
236	10:33:00	545	3.99	16.46
236	10:34:00	497	3.98	16.37
236	10:35:00	599	4.04	16.49
236	10:36:00	712	4.08	16.31
236	10:37:00	708	3.88	16.56
236	10:38:00	504	3.34	16.89
236	10:39:00	207	2.77	17.71
236	10:40:00	226	3.36	17.38
236	10:41:00	344	3.76	16.87
236	10:42:00	565	4.13	16.49
236	10:43:00	770	4.65	15.80
236	10:44:00	913	4.68	15.60
236	10:45:00	1004	4.76	15.62
236	10:46:00	1004	4.52	15.79
236	10:47:00	975	4.36	15.96
236	10:48:00	621	3.62	16.47
236	10:49:00	351	3.25	17.29
236	10:50:00	366	3.65	16.96
236	10:51:00	405	3.96	16.60
236	10:52:00	621	3.99	16.50
236	10:53:00	626	4.00	16.37
236	10:54:00	714	3.88	16.64
236	10:55:00	796	4.05	16.42
236	10:56:00	807	3.97	16.47
236	10:57:00	773	4.13	16.36
236	10:58:00	709	4.17	16.16
236	10:59:00	780	4.15	16.25
236	11:00:00	689	3.86	16.48
Run Average		621	3.95	16.49

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH25
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 5

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	11:16:00	513	3.69	16.73
236	11:17:00	358	3.41	16.94
236	11:18:00	310	3.44	17.14
236	11:19:00	417	3.74	16.77
236	11:20:00	573	4.00	16.61
236	11:21:00	748	4.32	16.09
236	11:22:00	720	4.14	16.06
236	11:23:00	723	4.00	16.39
236	11:24:00	632	3.55	16.69
236	11:25:00	340	2.75	17.69
236	11:26:00	242	3.22	17.51
236	11:27:00	249	3.26	17.15
236	11:28:00	278	3.50	17.19
236	11:29:00	385	3.92	16.60
236	11:30:00	657	4.07	16.47
236	11:31:00	812	4.40	15.99
236	11:32:00	839	4.21	16.09
236	11:33:00	986	4.21	16.18
236	11:34:00	841	3.88	16.43
236	11:35:00	449	2.82	17.44
236	11:36:00	288	3.30	17.34
236	11:37:00	252	2.99	17.40
236	11:38:00	277	3.44	17.30
236	11:39:00	439	3.78	16.88
236	11:40:00	603	4.13	16.42
236	11:41:00	718	4.32	16.00
236	11:42:00	847	4.23	16.13
236	11:43:00	861	4.07	16.23
236	11:44:00	805	3.95	16.44
236	11:45:00	440	2.95	17.17
Run Average		553	3.72	16.72

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH26
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 6

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	12:01:00	629	3.77	16.59
236	12:02:00	478	3.53	16.85
236	12:03:00	406	3.51	17.06
236	12:04:00	353	3.66	16.89
236	12:05:00	388	3.92	16.55
236	12:06:00	519	3.95	16.50
236	12:07:00	601	4.03	16.39
236	12:08:00	709	4.09	16.43
236	12:09:00	807	4.23	16.11
236	12:10:00	823	4.20	16.11
236	12:11:00	898	4.06	16.27
236	12:12:00	658	3.57	16.76
236	12:13:00	340	2.54	17.69
236	12:14:00	204	3.06	17.71
236	12:15:00	208	3.08	17.45
236	12:16:00	322	3.72	16.98
236	12:17:00	606	4.05	16.53
236	12:18:00	764	4.14	16.26
236	12:19:00	626	3.89	16.27
236	12:20:00	354	2.84	17.41
236	12:21:00	247	2.84	17.84
236	12:22:00	271	3.42	17.24
236	12:23:00	282	3.57	16.93
236	12:24:00	394	3.86	16.58
236	12:25:00	475	3.61	16.80
236	12:26:00	397	3.04	17.30
236	12:27:00	248	2.75	17.91
236	12:28:00	202	3.07	17.59
236	12:29:00	200	3.20	17.31
236	12:30:00	274	3.50	17.12
Run Average		456	3.56	16.91

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH27
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 7

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	12:46:00	289	3.43	17.34
236	12:47:00	338	3.54	17.04
236	12:48:00	250	3.23	17.25
236	12:49:00	209	3.21	17.46
236	12:50:00	227	3.10	17.45
236	12:51:00	216	3.19	17.61
236	12:52:00	257	3.26	17.34
236	12:53:00	207	3.06	17.46
236	12:54:00	200	3.01	17.70
236	12:55:00	219	3.20	17.51
236	12:56:00	273	3.29	17.39
236	12:57:00	245	3.23	17.31
236	12:58:00	184	2.99	17.55
236	12:59:00	189	3.04	17.67
236	13:00:00	203	3.02	17.68
236	13:01:00	201	3.28	17.44
236	13:02:00	249	3.27	17.17
236	13:03:00	167	3.06	17.59
236	13:04:00	245	3.12	17.46
236	13:05:00	198	3.07	17.77
236	13:06:00	278	3.45	17.22
236	13:07:00	225	3.10	17.41
236	13:08:00	225	3.31	17.34
236	13:09:00	192	2.81	17.67
236	13:10:00	173	3.01	17.68
236	13:11:00	152	2.65	17.94
236	13:12:00	125	2.84	17.63
236	13:13:00	136	2.71	18.15
236	13:14:00	226	2.97	17.48
236	13:15:00	186	2.83	18.09
Run Average		216	3.11	17.53

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH28
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTD Stack -- Run 8

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	13:31:00	149	2.45	18.07
236	13:32:00	174	2.62	17.73
236	13:33:00	152	2.76	17.99
236	13:34:00	194	2.41	17.85
236	13:35:00	194	3.23	17.58
236	13:36:00	218	2.57	17.64
236	13:37:00	279	3.49	17.39
236	13:38:00	406	3.40	17.20
236	13:39:00	250	3.36	17.31
236	13:40:00	324	3.34	16.93
236	13:41:00	230	3.24	17.29
236	13:42:00	366	3.50	16.96
236	13:43:00	359	3.43	17.13
236	13:44:00	437	3.67	16.86
236	13:45:00	430	3.51	16.75
236	13:46:00	348	3.29	17.18
236	13:47:00	375	3.43	17.04
236	13:48:00	473	3.58	16.98
236	13:49:00	553	3.77	16.65
236	13:50:00	523	3.70	16.61
236	13:51:00	582	3.54	16.85
236	13:52:00	516	3.49	16.99
236	13:53:00	596	3.69	16.79
236	13:54:00	536	3.56	16.75
236	13:55:00	376	3.36	17.02
236	13:56:00	435	3.50	16.98
236	13:57:00	517	3.70	16.86
236	13:58:00	666	3.79	16.59
236	13:59:00	592	3.68	16.62
236	14:00:00	572	3.47	16.88
Run Average		394	3.35	17.12

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH29
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 9

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	14:16:00	540	4.18	16.07
236	14:17:00	554	4.06	16.17
236	14:18:00	500	4.05	16.21
236	14:19:00	491	3.90	16.43
236	14:20:00	568	3.88	16.46
236	14:21:00	510	3.84	16.66
236	14:22:00	538	3.98	16.41
236	14:23:00	484	3.90	16.41
236	14:24:00	510	3.79	16.54
236	14:25:00	428	3.46	16.83
236	14:26:00	339	3.31	17.17
236	14:27:00	295	3.23	17.13
236	14:28:00	179	2.97	17.38
236	14:29:00	145	2.64	17.75
236	14:30:00	111	2.58	17.93
236	14:31:00	117	2.68	17.86
236	14:32:00	119	2.80	17.73
236	14:33:00	131	2.91	17.56
236	14:34:00	166	2.92	17.59
236	14:35:00	184	2.68	17.75
236	14:36:00	140	2.37	18.05
236	14:37:00	120	2.51	17.95
236	14:38:00	102	2.21	18.18
236	14:39:00	105	2.22	18.22
236	14:40:00	81.8	2.02	18.55
236	14:41:00	93.7	2.18	18.28
236	14:42:00	83.2	1.78	18.66
236	14:43:00	75.6	2.01	18.50
236	14:44:00	72.2	1.96	18.69
236	14:45:00	79.2	1.86	18.54
Run Average		262	2.96	17.46

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH210
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 10

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	15:46:00	229	2.89	16.98
236	15:47:00	166	3.04	17.30
236	15:48:00	199	2.90	16.91
236	15:49:00	156	2.79	17.48
236	15:50:00	190	2.68	17.14
236	15:51:00	126	2.68	17.77
236	15:52:00	190	2.72	17.11
236	15:53:00	139	2.79	17.53
236	15:54:00	143	2.25	17.50
236	15:55:00	126	2.77	17.57
236	15:56:00	119	1.98	18.03
236	15:57:00	114	2.64	17.62
236	15:58:00	117	2.45	17.78
236	15:59:00	156	2.48	17.40
236	16:00:00	133	2.60	17.72
236	16:01:00	137	2.24	17.77
236	16:02:00	157	2.84	17.31
236	16:03:00	126	2.47	17.71
236	16:04:00	156	2.49	17.43
236	16:05:00	150	2.73	17.63
236	16:06:00	164	2.34	17.66
236	16:07:00	159	2.85	17.22
236	16:08:00	123	2.46	17.77
236	16:09:00	155	2.48	17.35
236	16:10:00	124	0.11	17.77
236	16:11:00	162	2.37	17.40
236	16:12:00	125	3.02	17.43
236	16:13:00	185	2.53	17.26
236	16:14:00	141	3.06	17.36
236	16:15:00	232	2.70	17.17
Run Average		153	2.55	17.47

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH211
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RT0 Stack -- Run 11

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	16:31:00	112	2.73	17.92
236	16:32:00	199	3.03	17.35
236	16:33:00	137	2.47	18.10
236	16:34:00	163	2.90	17.66
236	16:35:00	132	2.69	18.05
236	16:36:00	182	3.03	17.23
236	16:37:00	143	2.81	18.01
236	16:38:00	222	2.92	17.29
236	16:39:00	155	3.00	17.93
236	16:40:00	231	2.78	17.36
236	16:41:00	159	3.26	17.61
236	16:42:00	233	2.71	17.49
236	16:43:00	236	3.59	17.36
236	16:44:00	293	2.82	17.44
236	16:45:00	257	3.67	17.06
236	16:46:00	243	2.75	17.44
236	16:47:00	234	3.54	17.28
236	16:48:00	247	2.83	17.41
236	16:49:00	184	3.31	17.62
236	16:50:00	301	3.56	16.73
236	16:51:00	206	3.32	17.25
236	16:52:00	305	3.70	16.82
236	16:53:00	280	3.57	17.02
236	16:54:00	341	3.76	16.71
236	16:55:00	265	3.51	16.87
236	16:56:00	256	3.36	17.12
236	16:57:00	249	3.46	17.09
236	16:58:00	299	3.60	17.02
236	16:59:00	351	3.93	16.60
236	17:00:00	342	3.87	16.51
Run Average		232	3.22	17.31

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH212
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Stack -- Run 12

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
236	17:16:00	676	4.81	15.29
236	17:17:00	730	4.79	15.27
236	17:18:00	751	4.42	15.60
236	17:19:00	581	4.42	15.59
236	17:20:00	648	3.27	16.26
236	17:21:00	410	2.13	18.16
236	17:22:00	298	3.65	16.84
236	17:23:00	500	3.94	15.74
236	17:24:00	520	3.97	15.71
236	17:25:00	569	3.22	16.53
236	17:26:00	396	3.87	16.61
236	17:27:00	443	3.83	16.31
236	17:28:00	329	3.60	16.49
236	17:29:00	319	3.53	16.66
236	17:30:00	349	3.55	16.68
236	17:31:00	349	2.66	17.15
236	17:32:00	157	1.31	18.82
236	17:33:00	94.5	0.60	19.90
236	17:34:00	70.8	0.48	20.26
236	17:35:00	44.9	0.41	20.29
236	17:36:00	33.3	0.38	20.45
236	17:37:00	53.3	0.52	20.26
236	17:38:00	47.3	0.50	20.18
236	17:39:00	42.3	0.45	20.30
236	17:40:00	39.4	0.36	20.37
236	17:41:00	43.3	0.41	20.39
236	17:42:00	61.1	0.48	20.25
236	17:43:00	47.7	0.42	20.27
236	17:44:00	46.6	0.42	20.33
236	17:45:00	40.2	0.33	20.44
Run Average		290	2.22	18.11

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH31
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	08:01:00	16.4	0.36	20.39
237	08:02:00	12.3	0.37	20.41
237	08:03:00	20.5	0.33	20.50
237	08:04:00	27.7	0.44	20.40
237	08:05:00	26.5	0.42	20.32
237	08:06:00	13.2	0.31	20.48
237	08:07:00	9.8	0.32	20.49
237	08:08:00	24.8	0.37	20.47
237	08:09:00	26.0	0.46	20.33
237	08:10:00	21.1	0.38	20.33
237	08:11:00	9.4	0.37	20.42
237	08:12:00	14.2	0.30	20.50
237	08:13:00	26.6	0.40	20.46
237	08:14:00	26.5	0.42	20.34
237	08:15:00	14.8	0.36	20.42
237	08:16:00	8.1	0.34	20.42
237	08:17:00	17.6	0.34	20.51
237	08:18:00	23.2	0.42	20.36
237	08:19:00	24.3	0.40	20.32
237	08:20:00	15.1	0.36	20.41
237	08:21:00	13.9	0.32	20.48
237	08:22:00	20.6	0.36	20.49
237	08:23:00	20.8	0.43	20.34
237	08:24:00	15.5	0.36	20.39
237	08:25:00	9.3	0.37	20.34
237	08:26:00	20.0	0.32	20.40
237	08:27:00	26.0	0.40	20.30
237	08:28:00	14.3	0.40	20.27
237	08:29:00	14.8	0.36	20.35
237	08:30:00	21.8	0.35	20.37
Run Average		18.5	0.37	20.40

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH32
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	08:46:00	19.9	0.44	20.41
237	08:47:00	13.9	0.38	20.49
237	08:48:00	16.0	0.39	20.49
237	08:49:00	25.6	0.36	20.59
237	08:50:00	19.2	0.40	20.48
237	08:51:00	8.5	0.41	20.45
237	08:52:00	14.2	0.40	20.50
237	08:53:00	21.7	0.35	20.54
237	08:54:00	17.4	0.34	4.59
237	08:55:00	8.9	0.43	20.45
237	08:56:00	17.1	0.39	20.48
237	08:57:00	23.2	0.39	20.49
237	08:58:00	16.4	0.30	20.62
237	08:59:00	10.3	0.39	20.53
237	09:00:00	7.2	0.41	20.45
237	09:01:00	6.8	0.37	20.51
237	09:02:00	6.9	0.32	20.54
237	09:03:00	16.2	0.35	20.58
237	09:04:00	19.7	0.43	20.46
237	09:05:00	12.3	0.37	20.47
237	09:06:00	8.8	0.37	20.51
237	09:07:00	18.2	0.32	20.59
237	09:08:00	23.3	0.40	20.53
237	09:09:00	10.8	0.40	20.44
237	09:10:00	11.4	0.37	20.51
237	09:11:00	18.0	0.35	20.50
237	09:12:00	26.0	0.32	20.59
237	09:13:00	11.8	0.39	20.48
237	09:14:00	14.6	0.38	20.45
237	09:15:00	22.4	0.39	20.50
Run Average		15.5	0.38	19.97

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH33
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	09:31:00	12.7	0.40	20.62
237	09:32:00	17.8	0.43	20.55
237	09:33:00	23.0	0.37	20.63
237	09:34:00	12.6	0.31	20.69
237	09:35:00	17.9	0.33	20.73
237	09:36:00	21.5	0.42	20.59
237	09:37:00	13.9	0.36	20.61
237	09:38:00	9.5	0.36	20.65
237	09:39:00	9.3	0.29	20.74
237	09:40:00	10.0	0.38	20.68
237	09:41:00	15.4	0.42	20.56
237	09:42:00	22.8	0.36	20.64
237	09:43:00	12.7	0.32	20.67
237	09:44:00	14.7	0.32	20.73
237	09:45:00	22.0	0.42	20.59
237	09:46:00	20.2	0.37	20.58
237	09:47:00	13.0	0.36	20.65
237	09:48:00	21.2	0.31	20.71
237	09:49:00	24.8	0.37	20.69
237	09:50:00	10.9	0.39	20.58
237	09:51:00	15.5	0.37	20.64
237	09:52:00	17.8	0.34	20.63
237	09:53:00	11.9	0.31	20.74
237	09:54:00	12.2	0.39	20.60
237	09:55:00	19.5	0.39	20.56
237	09:56:00	11.6	0.35	20.65
237	09:57:00	11.0	0.29	20.70
237	09:58:00	21.1	0.36	20.70
237	09:59:00	13.3	0.39	20.58
237	10:00:00	10.2	0.34	20.63
Run Average		15.7	0.36	20.64

Interpoll Laboratories, Inc.

(612) 786-6020

Printout of ESC Model 80 DAS

for CEM Trailer No. 1

- 1994 -

File Name: LPH34

Job Number: 4-3688

Client: Louisiana Pacific Corporation

Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 4

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	10:16:00	14.4	0.32	20.61
237	10:17:00	15.8	0.43	20.48
237	10:18:00	18.4	0.37	20.46
237	10:19:00	8.9	0.37	20.52
237	10:20:00	14.7	0.32	20.59
237	10:21:00	20.4	0.39	20.56
237	10:22:00	9.8	0.41	20.45
237	10:23:00	13.3	0.37	20.52
237	10:24:00	20.6	0.34	20.52
237	10:25:00	17.4	0.31	20.63
237	10:26:00	14.4	0.38	20.51
237	10:27:00	22.0	0.39	20.46
237	10:28:00	19.6	0.35	20.53
237	10:29:00	11.1	0.29	20.60
237	10:30:00	16.7	0.37	20.59
237	10:31:00	14.7	0.40	20.45
237	10:32:00	9.8	0.34	20.52
237	10:33:00	16.0	0.35	20.53
237	10:34:00	26.1	0.31	20.63
237	10:35:00	12.7	0.37	20.51
237	10:36:00	10.5	0.39	20.46
237	10:37:00	4.5	0.37	20.52
237	10:38:00	11.3	0.29	20.59
237	10:39:00	10.2	0.32	20.62
237	10:40:00	14.7	0.41	20.49
237	10:41:00	15.8	0.33	20.52
237	10:42:00	8.1	0.34	20.54
237	10:43:00	18.3	0.31	20.64
237	10:44:00	23.7	0.37	20.54
237	10:45:00	13.4	0.38	20.46
Run Average		14.9	0.36	20.54

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH37
Job Number: 4-3677
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 7

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	13:16:00	11.0	0.49	20.08
237	13:17:00	21.4	0.45	20.17
237	13:18:00	10.7	0.49	20.07
237	13:19:00	10.8	0.51	20.02
237	13:20:00	21.0	0.50	20.09
237	13:21:00	11.9	0.41	20.16
237	13:22:00	10.3	0.47	20.16
237	13:23:00	8.9	0.52	20.03
237	13:24:00	15.7	0.51	20.07
237	13:25:00	15.0	0.46	20.06
237	13:26:00	8.8	0.43	20.20
237	13:27:00	9.8	0.52	20.04
237	13:28:00	17.9	0.50	20.00
237	13:29:00	11.0	0.49	20.06
237	13:30:00	9.6	0.42	20.13
237	13:31:00	18.2	0.52	20.09
237	13:32:00	13.2	0.52	19.99
237	13:33:00	9.8	0.47	20.07
237	13:34:00	15.8	0.46	20.07
237	13:35:00	21.9	0.44	20.12
237	13:36:00	10.7	0.53	20.01
237	13:37:00	14.3	0.50	19.99
237	13:38:00	18.5	0.49	20.02
237	13:39:00	9.3	0.40	20.14
237	13:40:00	8.9	0.50	20.07
237	13:41:00	14.9	0.53	19.97
237	13:42:00	12.8	0.47	20.04
237	13:43:00	7.1	0.42	20.08
237	13:44:00	15.9	0.46	20.11
237	13:45:00	15.8	0.52	19.98
Run Average		13.4	0.48	20.07

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH38
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 8

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	14:01:00	15.8	0.44	20.02
237	14:02:00	8.8	0.51	20.01
237	14:03:00	9.9	0.55	19.90
237	14:04:00	19.9	0.51	19.96
237	14:05:00	10.4	0.45	19.99
237	14:06:00	12.4	0.44	20.08
237	14:07:00	18.0	0.53	19.96
237	14:08:00	13.0	0.48	19.95
237	14:09:00	9.3	0.49	19.99
237	14:10:00	18.5	0.45	20.06
237	14:11:00	17.5	0.50	20.01
237	14:12:00	6.2	0.51	19.93
237	14:13:00	11.8	0.49	19.99
237	14:14:00	14.0	0.44	20.00
237	14:15:00	8.5	0.42	20.07
237	14:16:00	9.4	0.53	19.95
237	14:17:00	17.9	0.48	19.95
237	14:18:00	10.7	0.47	19.97
237	14:19:00	11.8	0.43	20.07
237	14:20:00	19.8	0.52	19.97
237	14:21:00	12.3	0.50	19.90
237	14:22:00	9.0	0.48	19.97
237	14:23:00	14.1	0.45	20.01
237	14:24:00	16.1	0.45	20.04
237	14:25:00	6.3	0.51	19.92
237	14:26:00	11.1	0.48	19.95
237	14:27:00	14.5	0.47	19.96
237	14:28:00	9.7	0.42	20.08
237	14:29:00	12.2	0.49	19.95
237	14:30:00	19.0	0.50	19.88
Run Average		12.9	0.48	19.98

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH311
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 11

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	16:16:00	11.7	0.51	20.38
237	16:17:00	12.7	0.47	20.41
237	16:18:00	20.2	0.48	20.41
237	16:19:00	17.0	0.41	20.54
237	16:20:00	13.1	0.49	20.42
237	16:21:00	18.1	0.51	20.35
237	16:22:00	16.5	0.46	20.42
237	16:23:00	9.6	0.40	20.49
237	16:24:00	18.6	0.47	20.50
237	16:25:00	18.5	0.50	20.37
237	16:26:00	13.1	0.46	20.42
237	16:27:00	15.2	0.46	20.42
237	16:28:00	23.7	0.42	20.53
237	16:29:00	11.7	0.47	20.41
237	16:30:00	12.4	0.48	20.36
237	16:31:00	20.7	0.47	20.41
237	16:32:00	12.8	0.38	20.51
237	16:33:00	15.2	0.45	20.51
237	16:34:00	21.2	0.51	20.35
237	16:35:00	16.3	0.45	20.42
237	16:36:00	9.3	0.43	20.42
237	16:37:00	19.3	0.43	20.50
237	16:38:00	18.3	0.47	20.39
237	16:39:00	12.4	0.44	20.39
237	16:40:00	17.2	0.47	20.42
237	16:41:00	20.5	0.38	20.50
237	16:42:00	11.4	0.46	20.47
237	16:43:00	12.9	0.51	20.34
237	16:44:00	20.4	0.46	20.39
237	16:45:00	10.6	0.40	20.42
Run Average		15.7	0.46	20.43

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH312
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Press RTO Stack -- Run 12

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	17:01:00	11.1	0.47	20.33
237	17:02:00	11.3	0.46	20.41
237	17:03:00	21.8	0.42	20.45
237	17:04:00	19.0	0.43	20.51
237	17:05:00	10.8	0.49	20.40
237	17:06:00	18.1	0.47	20.43
237	17:07:00	17.1	0.43	20.45
237	17:08:00	12.1	0.41	20.56
237	17:09:00	19.1	0.50	20.42
237	17:10:00	21.8	0.47	20.36
237	17:11:00	12.2	0.45	20.45
237	17:12:00	16.0	0.41	20.51
237	17:13:00	22.9	0.45	20.50
237	17:14:00	10.9	0.48	20.40
237	17:15:00	12.6	0.46	20.45
237	17:16:00	17.6	0.43	20.44
237	17:17:00	14.4	0.38	20.57
237	17:18:00	10.9	0.47	20.45
237	17:19:00	18.5	0.48	20.39
237	17:20:00	21.6	0.45	20.44
237	17:21:00	12.5	0.37	20.55
237	17:22:00	19.7	0.47	20.53
237	17:23:00	19.9	0.49	20.38
237	17:24:00	12.3	0.45	20.46
237	17:25:00	14.1	0.42	20.47
237	17:26:00	24.9	0.41	20.55
237	17:27:00	11.8	0.46	20.45
237	17:28:00	11.2	0.45	20.43
237	17:29:00	18.0	0.46	20.46
237	17:30:00	13.4	0.36	20.57
Run Average		15.9	0.44	20.46

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH41
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	07:46:00	9.8	0.27	20.46
238	07:47:00	12.4	0.26	20.52
238	07:48:00	16.1	0.29	20.48
238	07:49:00	19.1	0.27	20.46
238	07:50:00	11.0	0.25	20.51
238	07:51:00	9.3	0.28	20.49
238	07:52:00	14.1	0.29	20.46
238	07:53:00	16.2	0.26	20.52
238	07:54:00	6.3	0.26	20.49
238	07:55:00	5.4	0.27	20.48
238	07:56:00	11.2	0.27	20.51
238	07:57:00	14.4	0.27	20.48
238	07:58:00	9.5	0.28	20.48
238	07:59:00	5.4	0.24	20.52
238	08:00:00	9.0	0.27	20.49
238	08:01:00	16.1	0.29	20.47
238	08:02:00	12.2	0.24	20.52
238	08:03:00	5.5	0.25	20.49
238	08:04:00	5.0	0.27	20.47
238	08:05:00	4.8	0.26	20.52
238	08:06:00	10.5	0.28	20.47
238	08:07:00	16.5	0.27	20.45
238	08:08:00	12.1	0.25	20.52
238	08:09:00	9.4	0.25	20.50
238	08:10:00	15.1	0.27	20.46
238	08:11:00	17.8	0.28	20.49
238	08:12:00	13.8	0.27	20.48
238	08:13:00	10.0	0.24	20.47
238	08:14:00	11.4	0.27	20.50
238	08:15:00	17.6	0.28	20.51
Run Average		11.6	0.27	20.49

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH42
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RT0 Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	08:31:00	9.8	0.29	20.50
238	08:32:00	12.6	0.32	20.46
238	08:33:00	12.8	0.29	20.46
238	08:34:00	6.7	0.27	20.52
238	08:35:00	6.3	0.31	20.48
238	08:36:00	13.2	0.32	20.45
238	08:37:00	19.7	0.28	20.51
238	08:38:00	11.4	0.28	20.50
238	08:39:00	7.5	0.29	20.50
238	08:40:00	9.1	0.28	20.53
238	08:41:00	14.2	0.30	20.49
238	08:42:00	18.8	0.31	20.48
238	08:43:00	13.1	0.27	20.54
238	08:44:00	6.9	0.27	20.50
238	08:45:00	9.5	0.31	20.50
238	08:46:00	15.7	0.28	20.52
238	08:47:00	17.2	0.29	20.49
238	08:48:00	12.4	0.28	20.50
238	08:49:00	7.5	0.25	20.56
238	08:50:00	8.5	0.27	20.53
238	08:51:00	15.9	0.31	20.48
238	08:52:00	19.0	0.29	20.52
238	08:53:00	14.3	0.28	20.50
238	08:54:00	10.5	0.27	20.50
238	08:55:00	10.5	0.27	20.55
238	08:56:00	15.7	0.30	20.52
238	08:57:00	21.3	0.27	20.48
238	08:58:00	13.8	0.28	20.53
238	08:59:00	9.7	0.29	20.52
238	09:00:00	11.7	0.25	20.49
Run Average		12.5	0.29	20.50

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH43
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	09:16:00	10.2	0.31	20.53
238	09:17:00	18.4	0.32	20.50
238	09:18:00	21.5	0.28	20.53
238	09:19:00	7.2	0.31	20.51
238	09:20:00	4.4	0.30	20.50
238	09:21:00	8.2	0.28	20.56
238	09:22:00	12.4	0.31	20.53
238	09:23:00	17.1	0.30	20.51
238	09:24:00	12.5	0.27	20.57
238	09:25:00	9.2	0.29	20.52
238	09:26:00	13.0	0.31	20.52
238	09:27:00	16.0	0.28	20.56
238	09:28:00	15.6	0.28	20.53
238	09:29:00	8.6	0.28	20.53
238	09:30:00	7.7	0.26	20.58
238	09:31:00	12.3	0.29	20.53
238	09:32:00	19.5	0.32	20.50
238	09:33:00	18.3	0.28	20.54
238	09:34:00	8.0	0.27	20.53
238	09:35:00	5.9	0.27	20.52
238	09:36:00	10.9	0.27	20.57
238	09:37:00	17.4	0.29	20.54
238	09:38:00	18.5	0.28	20.51
238	09:39:00	15.5	0.27	20.56
238	09:40:00	6.6	0.27	20.55
238	09:41:00	8.8	0.26	20.52
238	09:42:00	13.3	0.30	20.55
238	09:43:00	17.4	0.30	20.52
238	09:44:00	18.3	0.24	20.51
238	09:45:00	10.4	0.26	20.55
Run Average		12.8	0.28	20.53

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH44
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 4

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	11:01:00	17.3	0.30	20.56
238	11:02:00	8.1	0.30	20.56
238	11:03:00	11.3	0.27	20.55
238	11:04:00	14.1	0.31	20.56
238	11:05:00	10.9	0.31	20.55
238	11:06:00	6.8	0.25	20.57
238	11:07:00	9.5	0.30	20.56
238	11:08:00	16.9	0.30	20.55
238	11:09:00	9.3	0.26	20.59
238	11:10:00	6.3	0.28	20.56
238	11:11:00	15.6	0.32	20.53
238	11:12:00	21.1	0.27	20.57
238	11:13:00	10.9	0.28	20.56
238	11:14:00	14.7	0.30	20.54
238	11:15:00	20.3	0.27	20.57
238	11:16:00	10.8	0.28	20.56
238	11:17:00	7.6	0.28	20.56
238	11:18:00	13.0	0.27	20.59
238	11:19:00	13.9	0.28	20.54
238	11:20:00	8.0	0.27	20.54
238	11:21:00	11.1	0.26	20.59
238	11:22:00	17.2	0.29	20.54
238	11:23:00	19.2	0.28	20.53
238	11:24:00	11.3	0.24	20.60
238	11:25:00	11.3	0.27	20.56
238	11:26:00	17.9	0.31	20.54
238	11:27:00	22.5	0.25	20.58
238	11:28:00	9.9	0.25	20.56
238	11:29:00	7.3	0.27	20.54
238	11:30:00	7.6	0.26	20.59
Run Average		12.7	0.28	20.56

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH45
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 5

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	11:46:00	18.3	0.29	20.23
238	11:47:00	8.7	0.26	20.31
238	11:48:00	6.8	0.29	20.27
238	11:49:00	11.7	0.31	20.26
238	11:50:00	19.5	0.29	20.29
238	11:51:00	13.8	0.28	20.28
238	11:52:00	10.8	0.28	20.28
238	11:53:00	14.3	0.27	20.32
238	11:54:00	17.1	0.30	20.28
238	11:55:00	21.8	0.29	20.26
238	11:56:00	13.0	0.24	20.34
238	11:57:00	10.9	0.26	20.30
238	11:58:00	13.9	0.31	20.28
238	11:59:00	18.0	0.29	20.29
238	12:00:00	12.8	0.26	20.28
238	12:01:00	7.1	0.27	20.28
238	12:02:00	8.3	0.26	20.32
238	12:03:00	12.7	0.28	20.30
238	12:04:00	18.8	0.26	20.27
238	12:05:00	9.0	0.24	20.34
238	12:06:00	7.0	0.26	20.32
238	12:07:00	12.0	0.27	20.26
238	12:08:00	17.1	0.30	20.28
238	12:09:00	18.0	0.27	20.29
238	12:10:00	10.6	0.21	20.30
238	12:11:00	11.1	0.25	20.34
238	12:12:00	17.7	0.29	20.31
238	12:13:00	24.6	0.25	20.29
238	12:14:00	13.5	0.27	20.28
238	12:15:00	11.0	0.27	20.28
Run Average		13.7	0.27	20.29

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH46
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 6

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	12:31:00	18.6	0.31	20.26
238	12:32:00	13.0	0.29	20.26
238	12:33:00	8.8	0.30	20.25
238	12:34:00	10.8	0.29	20.30
238	12:35:00	14.6	0.31	20.27
238	12:36:00	16.9	0.28	20.25
238	12:37:00	6.8	0.28	20.31
238	12:38:00	5.6	0.29	20.29
238	12:39:00	11.0	0.28	20.26
238	12:40:00	12.8	0.32	20.28
238	12:41:00	11.5	0.29	20.28
238	12:42:00	4.4	0.24	20.29
238	12:43:00	4.5	0.28	20.30
238	12:44:00	11.0	0.31	20.28
238	12:45:00	18.0	0.27	20.29
238	12:46:00	7.6	0.27	20.28
238	12:47:00	8.7	0.28	20.27
238	12:48:00	13.5	0.27	20.32
238	12:49:00	15.4	0.30	20.28
238	12:50:00	16.5	0.27	20.27
238	12:51:00	9.6	0.24	20.33
238	12:52:00	10.1	0.28	20.30
238	12:53:00	15.7	0.30	20.27
238	12:54:00	20.4	0.26	20.30
238	12:55:00	8.8	0.25	20.29
238	12:56:00	5.3	0.27	20.29
238	12:57:00	8.4	0.26	20.33
238	12:58:00	11.5	0.28	20.28
238	12:59:00	13.7	0.28	20.27
238	13:00:00	4.8	0.24	20.31
Run Average		11.3	0.28	20.29

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH47
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 7

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	13:16:00	14.7	0.32	20.22
238	13:17:00	17.5	0.26	20.29
238	13:18:00	6.7	0.27	20.28
238	13:19:00	6.2	0.28	20.26
238	13:20:00	10.0	0.28	20.30
238	13:21:00	13.4	0.30	20.26
238	13:22:00	8.5	0.28	20.27
238	13:23:00	4.3	0.25	20.32
238	13:24:00	6.7	0.26	20.30
238	13:25:00	12.1	0.31	20.28
238	13:26:00	14.6	0.25	20.32
238	13:27:00	4.5	0.25	20.30
238	13:28:00	5.4	0.28	20.28
238	13:29:00	12.5	0.28	20.31
238	13:30:00	16.9	0.27	20.29
238	13:31:00	13.1	0.26	20.27
238	13:32:00	8.3	0.25	20.32
238	13:33:00	11.0	0.27	20.31
238	13:34:00	16.5	0.27	20.28
238	13:35:00	16.9	0.27	20.31
238	13:36:00	8.7	0.27	20.31
238	13:37:00	6.2	0.23	20.29
238	13:38:00	7.3	0.28	20.30
238	13:39:00	14.5	0.29	20.28
238	13:40:00	10.1	0.22	20.32
238	13:41:00	3.7	0.24	20.32
238	13:42:00	6.8	0.27	20.29
238	13:43:00	12.2	0.25	20.33
238	13:44:00	10.8	0.26	20.29
238	13:45:00	7.7	0.25	20.28
Run Average		10.3	0.27	20.29

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH48
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 8

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	14:01:00	11.4	0.31	20.28
238	14:02:00	17.6	0.31	20.26
238	14:03:00	9.7	0.26	20.25
238	14:04:00	6.9	0.29	20.30
238	14:05:00	7.4	0.32	20.28
238	14:06:00	13.3	0.31	20.27
238	14:07:00	14.9	0.33	20.28
238	14:08:00	9.8	0.35	20.28
238	14:09:00	9.3	0.33	20.32
238	14:10:00	8.6	0.38	20.29
238	14:11:00	15.7	0.39	20.26
238	14:12:00	7.5	0.35	20.31
238	14:13:00	5.6	0.38	20.29
238	14:14:00	12.4	0.39	20.27
238	14:15:00	18.6	0.39	20.30
238	14:16:00	13.7	0.39	20.28
238	14:17:00	9.5	0.39	20.28
238	14:18:00	9.9	0.38	20.33
238	14:19:00	11.2	0.40	20.29
238	14:20:00	13.7	0.41	20.28
238	14:21:00	6.9	0.37	20.33
238	14:22:00	6.2	0.38	20.30
238	14:23:00	10.8	0.42	20.28
238	14:24:00	16.7	0.39	20.31
238	14:25:00	7.9	0.38	20.31
238	14:26:00	8.3	0.39	20.29
238	14:27:00	7.8	0.41	20.32
238	14:28:00	13.5	0.41	20.29
238	14:29:00	9.2	0.36	20.28
238	14:30:00	3.9	0.39	20.32
Run Average		10.6	0.36	20.29

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH49
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RT0 Stack -- Run 9

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
237	14:46:00	22.4	0.48	20.50
237	14:47:00	21.7	0.53	20.40
237	14:48:00	13.0	0.49	20.40
237	14:49:00	16.1	0.52	20.44
237	14:50:00	23.9	0.43	20.54
237	14:51:00	13.4	0.51	20.48
237	14:52:00	13.1	0.53	20.40
237	14:53:00	21.9	0.50	20.45
237	14:54:00	12.2	0.43	20.50
237	14:55:00	12.9	0.45	20.55
237	14:56:00	19.0	0.55	20.40
237	14:57:00	16.0	0.48	20.43
237	14:58:00	9.9	0.48	20.46
237	14:59:00	18.9	0.45	20.56
237	15:00:00	20.4	0.50	20.45
237	15:01:00	10.2	0.50	20.40
237	15:02:00	15.2	0.49	20.46
237	15:03:00	20.4	0.43	20.50
237	15:04:00	15.4	0.45	20.54
237	15:05:00	15.2	0.52	20.41
237	15:06:00	24.0	0.49	20.43
237	15:07:00	15.3	0.46	20.44
237	15:08:00	14.1	0.43	20.57
237	15:09:00	20.8	0.51	20.43
237	15:10:00	19.5	0.49	20.39
237	15:11:00	13.1	0.47	20.46
237	15:12:00	19.3	0.43	20.52
237	15:13:00	25.0	0.47	20.51
237	15:14:00	13.8	0.50	20.40
237	15:15:00	16.5	0.48	20.46
Run Average		17.1	0.48	20.46

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH410
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 10

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	15:31:00	3.8	0.36	20.48
238	15:32:00	6.3	0.38	20.48
238	15:33:00	12.3	0.37	20.52
238	15:34:00	12.1	0.37	20.50
238	15:35:00	6.8	0.36	20.48
238	15:36:00	7.5	0.36	20.52
238	15:37:00	10.8	0.40	20.49
238	15:38:00	16.0	0.37	20.47
238	15:39:00	7.1	0.33	20.54
238	15:40:00	6.8	0.34	20.53
238	15:41:00	11.6	0.39	20.50
238	15:42:00	16.3	0.35	20.53
238	15:43:00	6.4	0.35	20.50
238	15:44:00	7.1	0.36	20.50
238	15:45:00	10.4	0.36	20.54
238	15:46:00	15.4	0.35	20.52
238	15:47:00	7.6	0.34	20.49
238	15:48:00	5.9	0.36	20.53
238	15:49:00	10.6	0.39	20.51
238	15:50:00	18.2	0.34	20.48
238	15:51:00	8.6	0.34	20.52
238	15:52:00	7.8	0.36	20.52
238	15:53:00	12.2	0.35	20.50
238	15:54:00	11.6	0.37	20.48
238	15:55:00	6.9	0.35	20.50
238	15:56:00	5.4	0.32	20.55
238	15:57:00	8.0	0.36	20.51
238	15:58:00	16.4	0.36	20.49
238	15:59:00	10.7	0.32	20.54
238	16:00:00	6.9	0.35	20.50
Run Average		9.8	0.36	20.51

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH411
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 11

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	16:16:00	9.6	0.32	20.15
238	16:17:00	11.5	0.34	20.18
238	16:18:00	6.3	0.33	20.19
238	16:19:00	6.3	0.31	20.20
238	16:20:00	8.7	0.35	20.19
238	16:21:00	13.9	0.33	20.16
238	16:22:00	5.8	0.30	20.22
238	16:23:00	5.5	0.33	20.19
238	16:24:00	12.6	0.35	20.16
238	16:25:00	10.6	0.31	20.21
238	16:26:00	3.7	0.33	20.18
238	16:27:00	7.3	0.34	20.17
238	16:28:00	13.7	0.31	20.21
238	16:29:00	4.7	0.30	20.21
238	16:30:00	4.0	0.32	20.21
238	16:31:00	8.6	0.32	20.23
238	16:32:00	10.9	0.31	20.18
238	16:33:00	4.1	0.33	20.19
238	16:34:00	4.3	0.31	20.22
238	16:35:00	8.5	0.33	20.19
238	16:36:00	11.0	0.31	20.18
238	16:37:00	3.0	0.29	20.23
238	16:38:00	5.4	0.32	20.22
238	16:39:00	13.8	0.31	20.18
238	16:40:00	8.0	0.31	20.23
238	16:41:00	4.1	0.31	20.22
238	16:42:00	8.5	0.30	20.19
238	16:43:00	12.1	0.33	20.20
238	16:44:00	9.3	0.31	20.20
238	16:45:00	7.3	0.28	20.21
Run Average		8.1	0.32	20.20

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LPH412
Job Number: 4-3688
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Press RTO Stack -- Run 12

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)		
		CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
238	17:01:00	3.6	0.33	20.20
238	17:02:00	4.6	0.33	20.19
238	17:03:00	7.9	0.34	20.23
238	17:04:00	9.4	0.33	20.23
238	17:05:00	4.5	0.31	20.19
238	17:06:00	4.9	0.35	20.21
238	17:07:00	12.3	0.36	20.19
238	17:08:00	9.5	0.28	20.23
238	17:09:00	5.2	0.30	20.26
238	17:10:00	10.0	0.34	20.24
238	17:11:00	18.0	0.31	20.23
238	17:12:00	7.3	0.31	20.23
238	17:13:00	7.2	0.33	20.21
238	17:14:00	12.5	0.32	20.26
238	17:15:00	11.9	0.31	20.23
238	17:16:00	5.5	0.31	20.22
238	17:17:00	5.5	0.30	20.25
238	17:18:00	8.8	0.34	20.22
238	17:19:00	9.7	0.31	20.22
238	17:20:00	3.1	0.28	20.27
238	17:21:00	4.8	0.30	20.24
238	17:22:00	12.5	0.35	20.22
238	17:23:00	10.6	0.29	20.25
238	17:24:00	6.0	0.29	20.23
238	17:25:00	9.8	0.33	20.22
238	17:26:00	14.3	0.31	20.22
238	17:27:00	6.8	0.29	20.18
238	17:28:00	4.9	0.29	20.16
238	17:29:00	7.1	0.32	20.19
238	17:30:00	11.1	0.31	20.16
Run Average		8.3	0.32	20.22


APPENDIX C

FIELD DATA SHEETS

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP / HAYWARD
Source FILE 2 Dwyer RTO STACK
Test 1 Run 1 Date 5-23-54
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -1.63 IN.WC
Operators D MARSO B ASCHENBACH
Pitot No. 270-8 C. 84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6.0	IN.	Time Start: 0835	HRS
A - 1	.032	2.592	8.592	.36	342
2	.105	8.505	14.505	.58	
3	.194	15.714	21.714	.55	
4	.323	26.163	32.163	.64	
5	.677	54.837	60.837	.71	
6	.806	65.286	71.286	.72	
7	.895	72.495	78.495	.74	
8	.968	78.408	84.408	.70	
B - 1				.48	
2				.67	
3				.64	
4				.60	
5				.48	
6				.64	
7				.69	
8				.63	
			FT/SEC	56.66	
			ACFM	121670	
			OSCFM	64228	
Temp. Meas. Device & S/N:				Time End: 0845 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

Drawing of Test Site

Cross-section View	Elevation View
-----------------------	-------------------

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP 1 MAYLIARD
Source LINE 2 DIRECT IRTD STATIC
Test 1 Run 3 Date 5-23-54
Stack Dimen. 51 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -.61 IN.WC
Operators BA PM
Pitot No. 270-8 Cn .54

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6.0	IN.	Time Start: 1005	HRS
A-1				.58	
2				.65	
3				.69	325
4				.73	
5				.81	
6				.84	
7				.86	
8				.79	
B-1				.46	
2				.58	
3				.68	
4				.64	
5				.76	
6				.71	
7				.79	
8				.63	
			PT/SEC	59.83	
			ACFM	128468	
			DSCFM	70193	
Temp. Meas. Device & S/N:				Time End: 100 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP / MAY 4-72
Source LINE 2 Dryer RTD SMIC
Test 1 Run 4 Date 8-23-84
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp. ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -7.75 IN.WC
Operators BA DM
Pitot No. 270-8 C_p .84

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

Temp. Meas. Device & S/N:

Time End: 1055 HRS

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / HAYWARD
Source LINE 2 D 1/2 IN. PTO STACK
Test 1 Run 5 Date 8-23-74
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -.62 IN.WC
Operators BA DM
Pitot No. 270-8 C. -84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6.0 IN.		Time Start: 1130 HRS	
A-1				.51	316
2				.64	
3				.62	
4				.60	
5				.62	
6				.71	
7				.74	
8				.67	
B-1				.48	
2				.69	
3				.70	
4				.69	
5				.84	
6				.70	
7				.76	
8				.67	
			FT/SEC	58.46	
			ACFM	125534	
			DSCFM	65742	
Temp. Meas. Device & S/N:				Time End: 1135 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP1 HAYWARD
Source LINE 2 Dry or RTO Stack
Test 1 Run 6 Date 8-23-94
Stack Dimen. 51 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -.54 IN.WC
Operators BA DM
Pitot No. Z70-8 C₂ -84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: 6.0		IN.	Time Start: 1220	HRS	
A-1				.46	319
2				.58	
3				.68	
4				.71	
5				.81	
6				.77	
7				.75	
8				.71	
B-1				.44	
2				.67	
3				.79	
4				.78	
5				.69	
6				.59	
7				.75	
8				.68	
			FT/SEC	59.27	
			ACFM	127269	
			DSCFM	66680	
Temp. Meas. Device & S/N:				Time End: 1225 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP 1 MAY 4 1970
Source LOWE 2 DRYER RTO STATIC
Test 1 Run 2 Date 5-23-74
Stack Dimen. 51 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp. ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -1.62 IN.WC
Operators RA DM
Pitot No. 270-8 C. -84

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP 1 HAYWARD
Source LINE 2 Dry, RTD STALK
Test 1 Run 8 Date 5-23-74
Stack Dimen. 51 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -.66 IN.WC
Operators BA DN
Pitot No. 270-8 C. -84

Cross-section View	Elevation View

[illegible]

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / MAY 4, 1954
Source LOWE 2 Dye - RTO Stack
Test 1 Run 2 Date 5-23-54
Stack Dimen. 81 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN. HG
Static Pressure -.64 IN. WC
Operators BA DM
Pitot No. 270-8 C .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6.0 IN.	Time Start: 1500 HRS		
A-1				.58	338
2				.67	
3				.72	
4				.68	
5				.70	
6				.69	
7				.77	
8				.73	
B-1				.53	
2				.58	
3				.65	
4				.68	
5				.77	
6				.74	
7				.66	
8				.63	
			FT/SEC	59.81	
			ACFM	128.427	
			DSCFM	64756	
Temp. Meas. Device & S/N:				Time End: 1505 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:\STACK\WP\FORMS\S-392.1

EPA Method 2 Field Data Sheet

Drawing of Test Site

LP/Hayward

Job _____

Source Line 2 Dryer RTO Stack

Test 1 Run 12 Date 8-23-94

Stack Dimen. 81 IN.

Dry Bulb _____ °F Wet bulb _____ °F

Manometer ☐ Reg. ☐ Exp ☒ Elec.

Barometric Pressure 28.71 IN.HG

Static Pressure -.73 IN.WC

Operators DA DM

Pitot No. 270-5 C. 54

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6.0	IN.	Time Start: 1545	HRS
A-1				.49	
2				.47	
3				.56	348
4				.60	
5				.58	
6				.66	
7				.68	
8				.65	
B-1				.63	
2				.64	
3				.74	
4				.68	
5				.70	
6				.66	
7				.68	
8				.58	
			FT/SEC	57.77	
			ACFM	124054	
			DSCFM	62866	
Temp. Meas. Device & S/N:				Time End: 1550 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 2 Dryer RTU Stack
Test 1 Run 11 Date 8-23-94
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -0.66 IN.WC
Operators BA DM
Pitor No. 27 U-8 C. 134

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6.0 IN.	Time Start: 1630 HRS	
A-1				.58	
2				.67	
3				.68	321
4				.70	
5				.64	
6				.60	
7				.69	
8				.54	
B-1				.49	
2				.53	
3				.68	
4				.74	
5				.80	
6				.89	
7				.78	
8				.65	
			FT / SEC	59.06	
			KCFM	126822	
			DSCFM	62420	
Temp. Meas. Device & S/N:				Time End: 1635 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOLL LABORATORIES, INC.

EPA Method 2 Field Data Sheet

Job LP / Hayward
Source Line 2 Dryer RTO Stack
Test 1 Run 12 Date 8-23-94
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure -.54 IN.WC
Operators BA DM
Pitot No. 27U-8 C. 84

Cross-section View	Elevation View

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / HAYWARD
Source Zone 2 Dry RTO STACK
Date 8-23-94 Test 1 Run 1

Operator(s) BA DM
Meter Box No. 441 Gas meter coef. .9937
 Δ Hg in.WC Bar. press 28.71 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 6.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(0830)	(600.627)								
	5	600.823	1000	2	250	—	—	68	—	—
	10	601.009	1000	2	248	—	—	68	—	—
	15	601.195	1000	2	250	—	—	68	—	—
	20	601.381	1000	2	249	—	—	68	—	—
	25	601.568	1000	2	249	—	—	68	—	—
	30	601.747	1000	2	247	—	—	68	—	—
	(0900)									
	$t=30$	$V_m=1.120$	(ΔH) <u>2000</u>					(t_m) avg. = <u>68</u>		

Condensate Data: #1

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	74.530	70.119	4.411
		Total	4.411

Preliminary results of SO₂ concentration determination

V_{std} = 1.067 DSCF

Moisture = 16.30 %v/v

SO₂, dry = ppm

SO₂, wet = ppm

LB/MMBtu =

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / Hayward
Source CENE 2 Dryer RTO Stack
Date 8-23-94 Test 1 Run 2

Operator(s) BA DM
Meter Box No. 1001 Gas meter coef. .9937
 ΔH_0 in.WC Bar. press 28.71 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(0915)	(601.779)								
	5	601.962	1000	2	249	-	-	68	-	-
	10	602.145	1000	2	251	-	-	68	-	-
	15	602.328	1000	2	248	-	-	68	-	-
	20	602.512	1000	2	248	-	-	68	-	-
	25	602.700	1000	2	250	-	-	68	-	-
	30	602.883	1000	2	249	-	-	68	-	-
	(0945)									
	$\theta=30$	$V_m=1.104$	$(\Delta H)_{avg}=1000$					$(t_m)_{avg}=68$		

Condensate Data: #2

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	78.310	72.592	5.718
Total			5.718

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.052 DSCF
Moisture	= 20.38 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LINE 2 DRYER RTO STACK
Date 8-23-74 Test 1 Run 3

Operator(s) BA DM
Meter Box No. COM1 Gasmeter coef. .8937
 ΔH in.WC Bar. press 28.71 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 00 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1000)	(603.920)								
	5	603.097	1000	2	248	-	-	68	-	-
	10	603.375	1000	2	249	-	-	68	-	-
	15	603.453	1000	2	250	-	-	68	-	-
	20	603.631	1000	2	250	-	-	68	-	-
	25	603.809	1000	2	249	-	-	68	-	-
	30	603.987	1100	2	249	-	-	68	-	-
	(1030)									
	$\theta=30$	$V_m=1.067$	$(\Delta H)=7000$					$(t_m)_{avg}=68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	74.436	70.564	3.872
	Total		3.872

Preliminary results of SO₂ concentration determination

$V_{std} = 1.017$ DSCF

Moisture = 15.21 %v/v

SO₂, dry = ppm

SO₂, wet = ppm

LB/MMBtu =

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP/HAYWARD
Source LINE 2 DRYER PTO STACK
Date 8-23-94 Test 1 Run 4

Operator(s) BA DM
Meter Box No. CEU 1 Gasmeter coef. 7937
 Δ Hg in.WC Bar. press 28.21 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1045)	(604.031)								
	5	604.216	1000	2	247	—	—	68	—	—
	10	604.401	1000	2	247	—	—	68	—	—
	15	604.586	1000	2	249	—	—	68	—	—
	20	604.771	1000	2	251	—	—	68	—	—
	25	604.956	1000	2	247	—	—	68	—	—
	30	605.141	1000	2	249	—	—	68	—	—
	(1115)									
	$\theta=30$	$V_m=1.110$	(Δ H) 7000					(t_m) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	74.161	70.339	3.822
		Total	3.822

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1058 DSCF
Moisture	= 1454 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LINE 2 Dryer RTO Stack
Date 8-23-94 Test 1 Run 5

Operator(s) BA DM
Meter Box No. 601 Gasmeter coef. 7937
 ΔH in.WC Bar. press 29.71 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1130)	(605.185)								
	5	605.372	1000	2	251	—	—	68	—	—
	10	605.560	1000	2	247	—	—	68	—	—
	15	605.747	1000	2	247	—	—	68	—	—
	20	605.935	1000	2	249	—	—	68	—	—
	25	606.122	1000	2	250	—	—	68	—	—
	30	606.310	1000	2	248	—	—	68	—	—
	(1200)									
	$\theta=30$	$V_m=1.125$	(ΔH) <u>1000</u>					$(t_m)_{avg.} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	69.008	63.439	5.569
	Total		5.569

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.072 DSCF
Moisture	= 19.66 %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job (P1 HAYWARD)
Source LINE 2 Dryer RTD STAIN
Date 8-23-84 Test 1 Run 6

Operator(s) BA DM
Meter Box No. CELL Gasmeter coef. 9937
^H₂ in.WC Bar. press 29.71 in.Hg.

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ✓
Posttest: 0.0 cfm at 15 in. Hg. ✓

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1215)	(606.354)								
	5	606.540	1000	2	247	—	—	68	—	—
	10	606.726	1000	2	248	—	—	68	—	—
	15	606.912	1000	2	247	—	—	68	—	—
	20	607.098	1000	2	251	—	—	68	—	—
	25	607.284	1000	2	249	—	—	68	—	—
	30	607.475	1000	2	250	—	—	68	—	—
	(1245)									
	θ = 30	V _m = 1.121	(^H) _{avg} = 1000					(t _m) _{avg} = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	71.643	66.207	5.436
	Total		5.436

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.068 DSCF
Moisture	= 19.33 %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / HAYWARD
Source LINE 2 Dryer 1270 STACK
Date 8-23-94 Test 1 Run 2

Operator(s) BA DM
Meter Box No. CEM1 Gasmeter coef. 8937
 ΔH — in.WC Bar. press 28.7 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	5	607.694	1000	2	250	—	—	68	—	—
	10	607.878	1000	2	247	—	—	68	—	—
	15	608.062	1000	2	248	—	—	68	—	—
	20	608.246	1000	2	257	—	—	68	—	—
	25	608.430	1000	2	249	—	—	68	—	—
	30	608.615	1000	2	248	—	—	68	—	—
	(1400)									
	$\theta = 30$	$V_m = 1.105$	(ΔH) 1000					(t_m) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	76.673	20.710	5.963
		Total	5.963

Preliminary results of SO₂ concentration determination

$V_{std} = 1.053$ DSCF

Moisture = 21.05 %v/v

SO₂, dry = ppm

SO₂, wet = ppm

LB/MMBtu =

INTERPOL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LINE 2 DRYER ETO STIRK
Date 8-27-84 Test 1 Run 8

Operator(s) BA DN
Meter Box No. CM Gasmeter coef. 9937
 ΔH in.WC Bar. press 28.71 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1415)	(608.662)								
	5	608.846	1000	2	251	—	—	68	—	—
	10	609.031	1000	2	249	—	—	68	—	—
	15	609.216	1000	2	250	—	—	68	—	—
	20	609.401	1000	2	250	—	—	68	—	—
	25	609.586	1000	2	248	—	—	68	—	—
	30	609.771	1000	2	249	—	—	68	—	—
	(1445)									
	$\theta = 30$	$V_m = 1.109$	$(\Delta H) = 280$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	77.074	71.110	5.964
		Total	5.964

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.057 DSCF
Moisture	= 20.99 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LINE 2 Diesel RTO Stack
Date 8-23-84 Test 1 Run 9

Operator(s) DA DM
Meter Box No. 4211 Gasmeter coef. 9937
 ΔHg in.WC Bar. press 28.71 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1500)	(60.860)								
	5	610.043	1000	2	251	—	—	68	—	—
	10	610.227	1000	2	250	—	—	68	—	—
	15	610.411	1000	2	250	—	—	68	—	—
	20	610.555	1000	2	249	—	—	68	—	—
	25	610.779	1000	2	247	—	—	68	—	—
	30	610.963	1000	2	250	—	—	68	—	—
	(1530)									
	$\theta = 30$	$V_m = 1.103$	(ΔH) <u>7080</u>					(t_m) avg. = <u>68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	76.912	71.176	5.736
		Total	5.736

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.051 DSCF
Moisture	= 20.45 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source CP# 2 Dryer RTO STAIRS
Date 8-23-74 Test 1 Run 11

Operator(s) BA DM
Meter Box No. CEM 1 Gasmeter coef. 9937
 ΔH_2 — in.WC Bar. press 28.21 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(1630)	(612.059)								
	5	612.240	1000	2	249	—	—	68	—	—
	10	612.422	1000	2	251	—	—	68	—	—
	15	612.604	1000	2	247	—	—	68	—	—
	20	612.786	1000	2	249	—	—	68	—	—
	25	612.968	1000	2	249	—	—	68	—	—
	30	613.150	1000	2	250	—	—	68	—	—
	(1700)									
	$\theta = 30$	$V_m = 1091$	$(\Delta H)_{avg} = 0$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	79.765	74.111	5.654
		Total	5.654

Preliminary results of SO₂ concentration determination

$V_{std} = 1.039$ DSCF

Moisture = 20.4 %v/v

SO₂, dry = ppm

SO₂, wet = ppm

LB/MMBtu =

INTERPOL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LINE 2 DRYER PTO STALK
Date 8-23-84 Test 1 Run 12

Operator(s) BA DM
Meter Box No. 1001 Gasmeter coef. .7537
 ΔH — in.WC Bar. press 28.7 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1715)	(613.190)								
	5	613.382	1000	2	249	—	—	68	—	—
	10	613.574	1000	2	257	—	—	68	—	—
	15	613.766	1000	2	248	—	—	68	—	—
	20	613.958	1000	2	247	—	—	68	—	—
	25	614.150	1000	2	250	—	—	68	—	—
	30	614.350	1000	2	257	—	—	68	—	—
	(1745)									
	$\theta = 30$	$V_m = 1.160$	(ΔH) ≈ 7000					(t_m) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	78.860	72.433	6.427
		Total	6.427

Preliminary results of SO₂ concentration determination

V_{std} = 1.105 DSCF
Moisture = 21.50 %v/v
SO₂, dry = ppm
SO₂, wet = ppm
LB/MMBtu =

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP / HAYWARD
Source LINE 1 Dryer. RTO STAGE
Test 2 Run 1 Date 5-24-24
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.72 IN.HG
Static Pressure -1.66 IN.WC
Operators B. Aschbacher D. Marso
Pitot No. 270-8 C. 24

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6.0	IN.	Time Start: 0820	HRS
A 1				.44	
2				.58	
3				.57	
4				.56	325
5				.60	
6				.59	
7				.58	
8				.50	
B 1				.42	
2				.44	
3				.38	
4				.39	
5				.41	
6				.44	
7				.48	
8				.47	
			FT/SEC	50.60	
			ACFM	108659	
			DSCFM	54893	
Temp. Meas. Device & S/N:				Time End: 0825 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOLL LABORATORIES, INC.

EPA Method 2 Field Data Sheet

Job 24 / Hayward
Source Line 1 Dryer RTO Stack
Test 2 Run 4 Date 8-21-94
Stack Dimen. 31 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.72 IN.HG
Static Pressure -.52 IN.WC
Operators BA DM
Pitot No. 27U-8 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 60	IN.	Time Start: 1030	HRS
A	1			.44	
	2			.49	
	3			.54	
	4			.49	337
	5			.45	
	6			.43	
	7			.68	
	8			.66	
B	1			.58	
	2			.63	
	3			.75	
	4			.78	
	5			.78	
	6			.70	
	7			.64	
	8			.55	
			FT/SEC	56.53	
			ACFM	121389	
			DSCFM	58395	
Temp. Meas. Device & S/N:				Time End: 1035 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
 Source Line 1 ~~2~~ Dryer RTO Stack
 Test 2 Run 5 Date 8-24-94
 Stack Dimen. 81 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp ☒ Elec.
 Barometric Pressure 28.72 IN.HG
 Static Pressure -1.67 IN.WC
 Operators BA DM
 Pitot No. 270-8 C_p .34

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: <u>6.0</u> IN.			Time Start: <u>1115</u> HRS		
A 1				.56	
2				.71	
3				.58	335
4				.57	
5				.57	
6				.69	
7				.97	
8				.87	
B 1				.42	
2				.48	
3				.44	
4				.39	
5				.61	
6				.57	
7				.56	
8				.39	
				FT/SEC	55.73
				ACFM	119674
				DSCFM	57312
Temp. Meas. Device & S/N:				Time End: <u>1120</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
 Source Line 1 Dyer RTO Stack
 Test 2 Run 6 Date 8-24-94
 Stack Dimen. 81 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp ☒ Elec.
 Barometric Pressure 28.72 IN.HG
 Static Pressure -56 IN.WC
 Operators BA DM
 Pitot No. 27U-8 C, 184

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6.0</u> IN.	Time Start: <u>1210</u> HRS		
A 1				.48	
2				.52	
3				.63	
4				.58	334
5				.51	
6				.68	
7				.52	
8				.48	
B 1				.38	
2				.56	
3				.51	
4				.54	
5				.64	
6				.66	
7				.61	
8				.57	
				FT/SEC	54.07
				ACFM	116102
				DSCFM	57086
Temp. Meas. Device & S/N:				Time End: <u>1215</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 1 Dryer RTD Stack
Test 2 Run 1 Date 8-24-94
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.72 IN.HG
Static Pressure -69 IN.WC
Operators BA DM
Pitot No. 27U-8 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6.0 IN.	Time Start:	1245 HRS
A	1			.53	
	2			.56	
	3			.58	
	4			.57	
	5			.58	
	6			.64	
	7			.56	
	8			.44	
B	1			.49	
	2			.63	
	3			.52	
	4			.51	
	5			.61	
	6			.68	
	7			.60	
	8			.55	
			FT/SEC	54.77	
			ACFM	117606	
			DSCFM	58983	
Temp. Meas. Device & S/N:				Time End: 1250 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:\STACK\WP\FORMS\S-392.1

EPA Method 2 Field Data Sheet

Cross-section View	Elevation View

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 1 Dryer RTO Stack
Test 2 Run 9 Date 8-24-94
Stack Dimen. 31 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.72 IN.HG
Static Pressure -1.68 IN.WC
Operators BA DM
Pitot No. 27U-8 C_p .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
██████		Port Length:	6.0 IN.	Time Start: 1415	HRS
A	1			.46	
	2			.64	
	3			.59	
	4			.58	375
	5			.60	
	6			.65	
	7			.56	
	8			.44	
B	1			.44	
	2			.50	
	3			.49	
	4			.57	
	5			.50	
	6			.64	
	7			.65	
	8			.56	
			FT/SEC	54.10	
			ACFM	116161	
			DSCPM	58947	
Temp. Meas. Device & S/N:				Time End: 1420 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 2 Field Data Sheet

Elevation
View

Pitot No. 27V-B C₁, 84

Temp. Meas. Device & S/N:	Time end: 330 HRS
---------------------------	-------------------

Time End: 1550 HRS

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 1 Dryer RTO Stack
Test 2 Run 11 Date 8-24-94
Stack Dimen. 81 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure IN.HG
Static Pressure IN.WC
Operators BA DM
Pitot No. 270-8 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: 6.0 IN.		Time Start: 1630 HRS			
A 1				.52	
2				.62	
3				.59	
4				.65	338
5				.73	
6				.75	
7				.54	
8				.60	
B 1				.50	
2				.63	
3				.60	
4				.62	
5				.65	
6				.68	
7				.68	
8				.63	
			FT/SEC	57.58	
			ACFM	123635	
			DSCFM	62135	
Temp. Meas. Device & S/N:				Time End: 1635 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
 Source Line 1 Dryer RTO Stack
 Test 2 Run 12 Date 8-24-94
 Stack Dimen. 81 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp. ☒ Elec.
 Barometric Pressure 28.72 IN.HG
 Static Pressure -1.58 IN.WC
 Operators BA DM
 Pitot No. 270-8 C .34

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: <u>6.0</u> IN.			Time Start: <u>1715</u> HRS		
A 1				.52	
2				.62	
3				.53	
4				.55	345
5				.68	
6				.66	
7				.68	
8				.48	
B 1				.46	
2				.32	
3				.57	
4				.49	
5				.61	
6				.63	
7				.58	
8				.61	
			PT/SEC	55.2	
			ACFM	118529	
			DSCFM	61347	
Temp. Meas. Device & S/N:				Time End: <u>1720</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job (P) HAYWARD
Source ONG / Dryer RTO STAIR
Date 8-24-94 Test 2 Run 1

Operator(s) GA DM
Meter Box No. 101 (Gasmeter coef. .9937)
^H@ — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	<u>(0815)</u>	<u>(64.395)</u>								
	<u>5</u>	<u>614.572</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>10</u>	<u>614.750</u>	<u>1000</u>	<u>2</u>	<u>247</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>15</u>	<u>614.928</u>	<u>1000</u>	<u>2</u>	<u>247</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>20</u>	<u>615.106</u>	<u>1000</u>	<u>2</u>	<u>249</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>25</u>	<u>615.283</u>	<u>1000</u>	<u>2</u>	<u>251</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>30</u>	<u>615.474</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>(0845)</u>									
	<u>θ = 30</u>	<u>V_m = 1.079</u>	<u>(^H) 780°C</u>					<u>(t_m) avg. = 68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>80.816</u>	<u>74.788</u>	<u>6.028</u>
		<u>Total</u>	<u>6.028</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>= 1.079</u> DSCF
Moisture	<u>= 21.62</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP/HAYWARD
Source LINE 1 Dryer PTO STAIRS
Date 8-24-94 Test 2 Run 2

Operator(s) BA DM
Meter Box No. LEM1 Gasmeter coef. .9937
 ΔH — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(0700)	(615.500)								
	5	615.682	1000	2	250	—	—	68	—	—
	10	615.865	1000	2	251	—	—	68	—	—
	15	616.047	1000	2	248	—	—	68	—	—
	20	616.230	1000	2	250	—	—	68	—	—
	25	616.412	1000	2	249	—	—	68	—	—
	30	616.595	1000	2	247	—	—	68	—	—
	(0930)									
	$\theta = 30$	$V_m = 1.095$	(ΔH) <u>7080</u>					(t_m) avg. = <u>68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	79.531	72.900	6.631
		Total	6.631

Preliminary results of SO ₂ concentration determination	
V_{std}	= <u>1.044</u> DSCF
Moisture	= <u>23.02</u> %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job (P) HAYWARD
Source Line 1 Dryer RTO STALC
Date 6-24-84 Test 2 Run 3

Operator(s) SA DM
Meter Box No. 6001 Gasmeter coef. 9937
 Δ Hg — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

Moisture

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(0945)	(616.605)								
	5	616.786	1000	2	250	—	—	68	—	—
	10	616.967	1000	2	250	—	—	68	—	—
	15	617.149	1000	2	247	—	—	68	—	—
	20	617.331	1000	2	248	—	—	68	—	—
	25	617.512	1000	2	251	—	—	68	—	—
	30	617.695	1000	2	249	—	—	68	—	—
	(1015)									
	$\theta = 30$	$V_m = 1.090$	(Δ H) 288°C					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	80.131	73.223	6.908
		Total	6.908

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.039 DSCF
Moisture	= 23.84 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / MAYWOOD
Source LINE 1 Dryer Stack
Date 8-24-94 Test 2 Run 4

Operator(s) BA DM
Meter Box No. 601 Gasmeter coef. 9937
 ΔH — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1030)	(617.720)								
	5	617.906	1000	2	257	—	—	68	—	—
	10	618.093	1000	2	247	—	—	68	—	—
	15	618.279	1000	2	249	—	—	68	—	—
	20	618.466	1000	2	250	—	—	68	—	—
	25	618.653	1000	2	250	—	—	68	—	—
	30	618.840	1000	2	248	—	—	68	—	—
	(1100)									
	$\theta = 30$	$V_m = 1.120$	$(\Delta H) = 1000$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	77.280	71.757	7.523
		Total	7.523

Preliminary results of SO₂ concentration determination

$V_{std} = 1.067$ DSCF

Moisture = 24.25 %v/v

SO₂, dry = ppm

SO₂, wet = ppm

LB/MMBtu =

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP/Hwy 6, 420
Source LP# 1 Dryer RTO 37AC15
Date 6-24-84 Test 2 Run 5

Operator(s) BA DM
Meter Box No. 4041 Gas meter coef. .9937
^He in.WC Bar. press 28.22 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	1115	618.855								
	5	619.050	1000	2	247	—	—	68	—	—
	10	619.236	1000	2	247	—	—	68	—	—
	15	619.427	1000	2	257	—	—	68	—	—
	20	619.618	1000	2	249	—	—	68	—	—
	25	619.809	1000	2	250	—	—	68	—	—
	30	620.000	1000	2	247	—	—	68	—	—
	(1145)									
	0=30	V _m =1.145	(^H) 1000					(t _m) _{avg.} =68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	74.604	67.343	7.261
		Total	7.261

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.091 DSCF
Moisture	= 24.75 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERFOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / HAYWARD
Source LEAG 1 Dryer RTO STALL
Date 8-24-94 Test 2 Run 6

Operator(s) BA DM
Meter Box No. CM Gasmeter coef. 7937
^H@ — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	1200	620.012								
	5	620.193	1000	2	250	—	—	68	—	—
	10	620.375	1000	2	250	—	—	68	—	—
	15	620.557	1000	2	250	—	—	68	—	—
	20	620.738	1000	2	247	—	—	68	—	—
	25	620.920	1000	2	249	—	—	68	—	—
	30	621.102	1000	2	251	—	—	68	—	—
	1230									
	$\theta = 30$	$V_m = 1090$	$(^H)_{avg} = 1000$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>76.085</u>	<u>69.545</u>	<u>6.540</u>
		<u>Total</u>	<u>6.540</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>= 1.039</u> DSCF
Moisture	<u>= 22.86</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP1 HAYWARD Operator(s) BA DM
 Source LFAC 1 Dryer RTO SMC Meter Box No. 6746 Gasmeter coef. 9937
 Date 8-24-74 Test 2 Run 7 Δ Hg in.WC Bar. press 28.22 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
 Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(1245)	(621.155)								
	5	621.337	1000	2	250	—	—	68	—	—
	10	621.519	1000	2	250	—	—	68	—	—
	15	621.701	1000	2	247	—	—	68	—	—
	20	621.883	1000	2	250	—	—	68	—	—
	25	622.065	1000	2	257	—	—	68	—	—
	30	622.247	1000	2	249	—	—	68	—	—
	(1315)									
	$\theta=30$	$V_m=1.092$	(ΔH)	1000				$(t_m)_{avg.}=68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>79.533</u>	<u>73.552</u>	<u>5.981</u>
		<u>Total</u>	<u>5.981</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>=1041</u> DSCF
Moisture	<u>=21.29</u> %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / H04W12D
Source LIVE 1 DRYER PTO SMC
Date 8-24-94 Test 2 Run 8

Operator(s) BA DM
Meter Box No. 2841 Gasmeter coef. .9937
^H₀ — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	1330	622.341								
	5	622.520	1000	2	249	—	—	68	—	—
	10	622.699	1000	2	248	—	—	68	—	—
	15	622.878	1000	2	250	—	—	68	—	—
	20	623.057	1000	2	248	—	—	68	—	—
	25	623.236	1000	2	251	—	—	68	—	—
	30	623.416	1000	2	249	—	—	68	—	—
	(1400)									
	$\theta = 30$	$V_m = 1.075$	$(^H) = 28.72$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>79.388</u>	<u>73.509</u>	<u>5.879</u>
		Total	<u>5.879</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>= 1.025</u> DSCF
Moisture	<u>21.27</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / MAYWARD
Source LDX 1 Dryer RTD STAIRS
Date 8-28-84 Test 2 Run 9

Operator(s) BA DM
Meter Box No. 621 Gasmeter coef. 9937
^H₀ — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. 8

Posttest: 0.0 cfm at 5 in. Hg. 18

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(1415)	(623.440)								
	5		1000	2	248	—	—	68	—	—
	10		1000	2	249	—	—	68	—	—
	15		1000	2	250	—	—	68	—	—
	20		1000	2	247	—	—	68	—	—
	25		1000	2	257	—	—	68	—	—
	30	24.538	1000	2	248	—	—	68	—	—
	(1445)									
	θ = 30	V _m = 1.098	(~H) 1000					(t _m) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	76.326	70.677	5.649
		Total	5.649

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.047 DSCF
Moisture	= 20.26 %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LDL 1 Dyer PTO STALK
Date 8-24-84 Test 2 Run 10

Operator(s) SA DM
Meter Box No. LEM Gasmeter coef. 7937
 ΔH — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1545)	(624.546)								
	5	624.723	1000	2	251	—	—	68	—	—
	10	624.901	1000	2	252	—	—	68	—	—
	15	625.078	1000	2	252	—	—	68	—	—
	20	625.255	1000	2	247	—	—	68	—	—
	25	625.432	1000	2	248	—	—	68	—	—
	30	625.610	1000	2	250	—	—	68	—	—
	(1615)									
	$\theta = 30$	$V_m = 1.064$	$(\Delta H) 700^\circ C$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	78.671	73.723	4.948
		Total	4.948

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.014 DSCF
Moisture	= 18.68 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP / HAYWARD
Source LDUE / Dye / RTO / SINK
Date 8-24-94 Test 2 Run 11

Operator(s) BA DM
Meter Box No. CEM1 Gasmeter coef. .9937
 ΔH_0 — in.WC Bar. press 29.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1630)	(625.645)								
	5	625.827	1000	2	249	—	—	68	—	—
	10	626.005	1000	2	250	—	—	68	—	—
	15	626.142	1000	2	247	—	—	68	—	—
	20	626.360	1000	2	257	—	—	68	—	—
	25	626.537	1000	2	249	—	—	68	—	—
	30	626.710	1000	2	249	—	—	68	—	—
	(1700)									
	$\theta = 30$	$V_m = 1065$	$(\Delta H)_{avg} = 1000$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	80.654	74.997	5.655
		Total	5.655

Preliminary results of SO ₂ concentration determination	
V _{std}	7.015 DSCF
Moisture	20.78 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / MAYLWTRD
Source LINE 1 DRYER RTO STACK
Date 8-24-94 Test 2 Run 12

Operator(s) BA JAM
Meter Box No. 1241 Gasmeter coef. 1.957
 Δ Hg — in.WC Bar. press 28.72 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	<u>(1715)</u>	<u>(62.725)</u>								
	<u>5</u>		<u>1000</u>	<u>2</u>	<u>248</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>10</u>		<u>1000</u>	<u>2</u>	<u>247</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>15</u>		<u>1000</u>	<u>2</u>	<u>251</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>20</u>		<u>1000</u>	<u>2</u>	<u>249</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>25</u>		<u>1000</u>	<u>2</u>	<u>251</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>30</u>	<u>62.770</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>(1745)</u>									
	<u>$\theta = 30$</u>	<u>$V_m = 1.065$</u>	<u>$(\Delta H)_{avg} =$</u>					<u>$(t_m)_{avg} = 68$</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>77.268</u>	<u>72.642</u>	<u>4.626</u>
		<u>Total</u>	<u>4.626</u>

Preliminary results of SO ₂ concentration determination	
V_{std}	<u>= 1.045</u> DSCF
Moisture	<u>= 17.67</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

(612) 786-6020

Drawing of Test Site

Cross-section View	Elevation View
--------------------	----------------

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
 Source Line 1 Press RTO Stack
 Test 3 Run 2 Date 8-25-94
 Stack Dimen. 26 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp. ☒ Elec.
 Barometric Pressure 29.82 IN.HG
 Static Pressure -1.68 IN.WC
 Operators BA DM
 Pitot No. 270-8 C_p .84

Cross-section View	Elevation View

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6</u> IN.	Time Start: <u>0845</u> HRS		
<u>A</u> <u>1</u>				<u>.57</u>	
<u>2</u>				<u>.52</u>	
<u>3</u>				<u>.67</u>	<u>259</u>
<u>4</u>				<u>.63</u>	
<u>5</u>				<u>.68</u>	
<u>6</u>				<u>.67</u>	
<u>7</u>				<u>.57</u>	
<u>8</u>				<u>.44</u>	
<u>B</u> <u>1</u>				<u>.45</u>	
<u>2</u>				<u>.54</u>	
<u>3</u>				<u>.65</u>	
<u>4</u>				<u>.68</u>	
<u>5</u>				<u>.64</u>	
<u>6</u>				<u>.65</u>	
<u>7</u>				<u>.64</u>	
<u>8</u>				<u>.53</u>	
			FT/SEC	<u>51.71</u>	
			ACFM	<u>97744</u>	
			DSCFM	<u>66652</u>	
Temp. Meas. Device & S/N:			Time End: <u>0850</u> HRS		

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Hayward
Source Line 1 Press RTG Stack
Test 3 Run 3 Date 8-25-94
Stack Dimen. 36 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.82 IN.HG
Static Pressure -.47 IN.WC
Operators BA DM
Pitot No. 27U-8 C. 34

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Elevation
View

Job LP / Hayward
Source Line 1 Press RIO stack
Test 3 Run 4 Date 8-25-94
Stack Dimen. 86 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.87 IN.HG
Static Pressure -.65 IN.WC
Operators BA DM
Pitot No. 270-8 C. .86

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6 IN.	Time Start: 10 15 HRS	
A	1			.56	
	2			.68	
	3			.72	
	4			. 62	256
	5			.66	
	6			.59	
	7			.56	
	8			.47	
B	1			.46	
	2			.63	
	3			.71	
	4			.65	
	5			.55	
	6			.63	
	7			.53	
	8			.44	
			PTISEZ	51.43	
			ACFM	97230	
			DSCFM	66667	
Temp. Meas. Device & S/N:				Time End: 1020 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Job LT/ Hayward
Source Line 1 Press RTO Stack
Test 3 Run 6 Date 9-25-84
Stack Dimen. 86 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 29.82 IN.
Static Pressure - .42 IN.
Operators BA DM
Pitot No. 270-8 C. .84

Drawing of Test Site

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (^o F)
		Port Length:	6 IN.	Time Start: 1230 HRS	
A	1			.48	
	2			.56	
	3			.63	
	4			.72	260
	5			.58	
	6			.57	
	7			.56	
	8			.45	
B	1			.34	
	2			.58	
	3			.61	
	4			.65	
	5			.57	
	6			.63	
	7			.62	
	8			.57	
			FT/SEC	50.63	
			ACFM	95716	
			DSCFM	65290	
Temp. Meas. Device & S/N:				Time End: 1235 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Hayward
Source Line 1 Press RTO Stock
Test 3 Run 2 Date 8-25-94
Stack Dimen. 86 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.82 IN.HG
Static Pressure -1.66 IN.WC
Operators BA DM
Pitot No. 370-3 C .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6 IN.	Time Start: 1315	HRS
A	1			.47	
	2			.57	
	3			.63	
	4			.61	267
	5			.58	
	6			.63	
	7			.54	
	8			.45	
B	1			.47	
	2			.52	
	3			.66	
	4			.66	
	5			.63	
	6			.60	
	7			.55	
	8			.46	
			FT/SEC	50.62	
			ACFM	95687	
			DSCFM	64616	
Temp. Meas. Device & S/N:				Time End: 1320 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

(612) 786-6020

Drawing of Test Site

Cross-section View	Elevation View
-----------------------	-------------------

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Hayward
 Source Line 1 Press BTO Stack
 Test 3 Run 9 Date 8-25-94
 Stack Dimen. 86 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp ☒ Elec.
 Barometric Pressure 28.82 IN.HG
 Static Pressure -.69 IN.WC
 Operators BA DM
 Pitot No. 270-8 C .84

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6</u> IN.	Time Start: <u>1445</u> HRS		
A 1				.51	
2				.48	
3				.53	
4				.58	265
5				.59	
6				.57	
7				.54	
8				.44	
B 1				.42	
2				.52	
3				.58	
4				.58	
5				.54	
6				.55	
7				.55	
8				.48	
FT/SEC				49.04	
ACFM				92.713	
DSCFM				62.768	
Temp. Meas. Device & S/N:				Time End: <u>1450</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WPA\FORM55-392.1

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Hayward
Source Line 1 Press RTO Stack
Test 3 Run/Date 3-25-94
Stack Dimen. 76 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.82 IN.HG
Static Pressure -.58 IN.WC
Operators BA DM
Pitot No. 270-8 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: 6 IN.		Time Start: 1530 HRS			
A 1				48	
2				63	
3				65	
4				66	
5				61	264
6				56	
7				57	
8				52	
B 1				53	
2				53	
3				60	
4				72	
5				57	
6				55	
7				59	
8				55	
			PT/SEC	51.40	
			ACFM	97163	
			DSCFM	45856	
Temp. Meas. Device & S/N:				Time End: 1535 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job 24/Hayward
Source Line 1 Press RTO Stack
Test 3 Run// Date 8-25-94
Stack Dimen. 26 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.52 IN.HG
Static Pressure -56 IN.WC
Operators BA DM
Pitot No. 270-3 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Elevation
View

Pitot No.

27U-8 C. 84

Temp. Meas. Device & S/N:	Time End: 1705 HRS
---------------------------	--------------------

C-60

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP/HAYWARD
Source LOWE Press PTO STACK
Date 8-25-94 Test 3 Run 1

Operator(s) BA DM
Meter Box No. COM1 Gasmeter coef. 9937
^H₀ in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(0800)	(627.825)								
	5	628.008	1000	2	250	—	—	68	—	—
	10	628.191	1000	2	250	—	—	68	—	—
	15	628.374	1000	2	248	—	—	68	—	—
	20	628.557	1000	2	250	—	—	68	—	—
	25	628.740	1000	2	250	—	—	68	—	—
	30	628.925	1000	2	249	—	—	68	—	—
	(0830)									
	θ = 30	V _m = 1.100	([^] H) = 28.0					(t _m) _{avg} = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	73.537	72.738	.799
		Total	.799

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.052 DSCF
Moisture	= 3.30 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job (2/11/14)
Source LINE 1 PRESS 210 STKR
Date 8-25-84 Test 3 Run 2

Operator(s) RA DM
Meter Box No. CM1 Gas meter coef. 5937
 ΔH — in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

(11/13/14)

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(0845)	(628.942)								
	5	629.135	1000	2	250	—	—	68	—	—
	10	629.328	1000	2	257	—	—	68	—	—
	15	629.521	1100	2	245	—	—	68	—	—
	20	629.714	1000	2	250	—	—	68	—	—
	25	629.907	1000	2	248	—	—	68	—	—
	30	630.100	1000	2	247	—	—	68	—	—
	(0915)									
	$\theta = 30$	$V_m = 1.158$	(ΔH) <u>28.82</u>					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	75.023	74.188	.835
		Total	.835

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.107 DSCF
Moisture	= 343 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP1 HAYWARD
Source LINE 1 Press RTO STMC
Date 6-25-84 Test 3 Run 3

Operator(s) BA DM
Meter Box No. 6441 Gasmeter coef. .9937
 ΔH_e in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(0930)	636.110								
	5	630.294	1000	2	249	—	—	68	—	—
	10	630.478	1000	2	249	—	—	68	—	—
	15	630.662	1000	2	248	—	—	68	—	—
	20	630.847	1000	2	250	—	—	68	—	—
	25	631.031	1000	2	249	—	—	68	—	—
	30	631.216	1000	2	247	—	—	68	—	—
	(1000)									
	$\theta = 30$	$V_m = 1.106$	$(\Delta H)_{avg} =$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	72.898	72.121	.777
		Total	.777

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.058 DSCF
Moisture	= 3.34 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job (P/ HAYWARD)
 Source LDL 1 (P-155) PTO STATIC
 Date 8-25-84 Test 3 Run 4

Operator(s) BA DM
 Meter Box No. (144) Gasmeter coef. .9937
 ^H@ in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
 Posttest: 00 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
<u>(1015)</u>	<u>(631.130)</u>									
	<u>5</u>	<u>631.411</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>-</u>	<u>-</u>	<u>68</u>	<u>-</u>	<u>-</u>
	<u>10</u>	<u>631.593</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>-</u>	<u>-</u>	<u>68</u>	<u>-</u>	<u>-</u>
	<u>15</u>	<u>631.774</u>	<u>1000</u>	<u>2</u>	<u>248</u>	<u>-</u>	<u>-</u>	<u>68</u>	<u>-</u>	<u>-</u>
	<u>20</u>	<u>631.955</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>-</u>	<u>-</u>	<u>68</u>	<u>-</u>	<u>-</u>
	<u>25</u>	<u>632.137</u>	<u>1000</u>	<u>2</u>	<u>249</u>	<u>-</u>	<u>-</u>	<u>68</u>	<u>-</u>	<u>-</u>
	<u>30</u>	<u>632.320</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>-</u>	<u>-</u>	<u>68</u>	<u>-</u>	<u>-</u>
<u>(1045)</u>										
	<u>θ=30</u>	<u>V_m=1.090</u>	<u>(^H)_{avg}=2000</u>					<u>(t_m)_{avg}=68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>73.649</u>	<u>72.891</u>	<u>.758</u>
		Total	<u>.758</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>=1.042</u> DSCF
Moisture	<u>=3.31</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP/MAY 21
 Source LAKE PROSS RTO STAGE
 Date 6-25-96 Test 2 Run 5

Operator(s) BA DM
 Meter Box No. CON Gasmeter coef. .5937
 ^He — in.WC Bar. press 28.62 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(1145)	(633.036)								
	5	633.218	1000	2	248	—	—	68	—	—
	10	633.401	1000	2	249	—	—	68	—	—
	15	633.589	1000	2	257	—	—	68	—	—
	20	633.765	1000	2	250	—	—	68	—	—
	25	633.947	1000	2	249	—	—	68	—	—
	30	634.130	1000	2	249	—	—	68	—	—
	(1215)									
	$\theta=30$	$V_m=1.094$	$(^H)$ 2000					$(t_m)_{avg}=68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	69.630	68.942	.688
		Total	.688

Preliminary results of SO ₂ concentration determination	
V_{std}	= <u>6046</u> DSCF
Moisture	= <u>3.00</u> %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP1 HAYWARD Operator(s) JA DM
 Source LDK 1 Cross RTO Stack Meter Box No. (EM) Gasmeter coef. .9937
 Date 8-25-84 Test 3 Run 6 ΔH — in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 13 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1230)	(634.140)								
	5	634.321	1000	2	251	—	—	68	—	—
	10		1000	2	249	—	—	68	—	—
	15		1000	2	249	—	—	68	—	—
	20		1000	2	250	—	—	68	—	—
	25		1000	2	248	—	—	68	—	—
	30	635.230	1000	2	248	—	—	68	—	—
	(1300)									
	$t = 30$	$V_m = 1.090$	$(\Delta H)_{avg} = 1000$					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	76.143	75.379	.764
		Total	.764

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.043 DSCF
Moisture	= 333 %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP/HAYWARD
 Source LEAG 1 POSS PTO STATION
 Date 8-25-84 Test 3 Run 7

Operator(s) BA DM
 Meter Box No. 1941 Gas meter coef. 9937
 ^Hg in. WC Bar. press 28.82 in. Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
 Posttest: 0.0 cfm at 15 in. Hg. ☒

164372E

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1315)	(635.235)								
	5	635.419	1000	2	251	—	—	68	—	—
	10	635.603	1000	2	249	—	—	68	—	—
	15	635.787	1000	2	250	—	—	68	—	—
	20	635.971	1000	2	248	—	—	68	—	—
	25	636.155	1000	2	247	—	—	68	—	—
	30	636.340	1000	2	252	—	—	68	—	—
	(1345)									
	0=30	V _m =1105	(^H) 2080					(t _m) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	74.546	73.778	768
		Total	768

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1057 DSCF
Moisture	= 331 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP1 HAYWARD
Source LINE 1 (PASS PRO STAIR)
Date 8-25-84 Test 3 Run 8

Operator(s) B/A DM
Meter Box No. 1001 Gasmeter coef. 9937
^HG — in.WC Bar. press 28.82 in. Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	<u>1400</u>	<u>(636.358)</u>								
	<u>5</u>	<u>636.531</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>10</u>	<u>636.712</u>	<u>1000</u>	<u>2</u>	<u>249</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>15</u>	<u>636.893</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>20</u>	<u>637.074</u>	<u>1000</u>	<u>2</u>	<u>247</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>25</u>	<u>637.255</u>	<u>1000</u>	<u>2</u>	<u>248</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>30</u>	<u>637.446</u>	<u>1000</u>	<u>2</u>	<u>249</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>(1430)</u>									
	<u>0 = 30</u>	<u>V_m = 7.089</u>	<u>(^H)_{avg} = 1000</u>					<u>(t_m)_{avg} = 68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>73.329</u>	<u>72.569</u>	<u>.760</u>
Total			<u>.760</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>7.041</u> DSCF
Moisture	<u>3.32</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP/HAYWARD
Source FILE 1 P1053 P1050K10
Date 8-25-84 Test 3 Run 9

Operator(s) RP DM
Meter Box No. CEMC Gas meter coef. 9837
^HG — in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1445)	(637.455)								
	5	637.632	1000	2	247	—	—	68	—	—
	10	637.810	1000	2	250	—	—	68	—	—
	15	637.988	1000	2	248	—	—	68	—	—
	20	638.166	1000	2	249	—	—	68	—	—
	25	638.349	1000	2	249	—	—	68	—	—
	30	638.524	1000	2	250	—	—	68	—	—
	(1515)									
	0=30	V=7.069	(^H) 700=					(tm) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	73.871	73.124	.747
		Total	.747

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.022 DSCF
Moisture	= 3.32 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP/ HAYWARD
Source LEAK 1 (PSS 210 STAIRS)
Date 8-25-84 Test 3 Run 10

Operator(s) BT DM
Meter Box No. 1041 Gasmeter coef. 987
 ΔHg in.WC Bar. press 28.62 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg.

Posttest: 0.0 cfm at 15 in. Hg.

Moisture

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxyg. (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1530)	(638.538)								
	5	638.715	1000	2	251	—	—	68	—	—
	10	638.893	1000	2	247	—	—	68	—	—
	15	639.0714	1000	2	249	—	—	68	—	—
	20	639.249	1000	2	248	—	—	68	—	—
	25	639.427	1000	2	250	—	—	68	—	—
	30	639.605	1000	2	250	—	—	68	—	—
	(1600)									
	$\theta = 38$	$V_m = 1.067$	(ΔH) <u>2880</u>					(t_m) <u>avg. = 68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	75.540	74.784	.756
	Total		.756

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.020 DSCF
Moisture	= 337 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP/ HAYWTR
Source LDX 1 Press RTO STAIR
Date 8-25-84 Test 3 Run 1

Operator(s) BA DM
Meter Box No. CFM1 Gasmeter coef. 9437
He in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MASTLPC

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
(1615)		(639.611)								
5		639.784	1000	2	250	—	—	68	—	—
10		639.958	1000	2	249	—	—	68	—	—
15		640.134	1000	2	250	—	—	68	—	—
20		640.310	1000	2	248	—	—	68	—	—
25		640.484	1000	2	257	—	—	68	—	—
30		640.653	1000	2	249	—	—	68	—	—
(1645)										
0=30		V _m =1042	(^H) 1000					(t _m) _{avg} =68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	76.880	76.692	-788
		Total	788

Preliminary results of SO ₂ concentration determination	
V _{std}	=996 DSCF
Moisture	=359 %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP/ HAYWARD Operator(s) BA DW
Source LINE 1 PRESS 2ND ST Meter Box No. 104 Gasmeter coef. 9937
Date 8-21-84 Test 3 Run 12 Δ Hg in.WC Bar. press 28.82 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒

Posttest: cfm at in. Hg. ☐

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1700)	(640.667)								
	5	640.838	1000	2	251	—	—	68	—	—
	10	641.015	1000	2	248	—	—	68	—	—
	15	641.192	1000	2	250	—	—	68	—	—
	20	641.369	1000	2	249	—	—	68	—	—
	25	641.546	1000	2	249	—	—	68	—	—
	30	641.730	1000	2	247	—	—	68	—	—
	(1730)									
	0=30	V _m = 7.063	(Δ H) = 7200					(t _m) avg. = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	74.739	73.898	.841
		Total	.841

Preliminary results of SO ₂ concentration determination	
V _{std}	= 1.017 DSCF
Moisture	= 374 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

(612) 786-6020

Drawing of Test Site

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP1 Hayward
Source Line 2 Press RTO Stack
Test 4 Run 2 Date 8-26-94
Stack Dimen. 76 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 29.81 IN.HG
Static Pressure -.80 IN.WC
Operators BA DM
Pitot No. 270-8 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: 6 IN.		Time Start: 0830 HRS			
A 1				.69	240
2				.68	
3				.74	
4				.69	
5				.68	
6				.93	
7				.80	
8				.67	
B 1				.55	
2				.64	
3				.63	
4				.78	
5				1.00	
6				1.88	
7				.89	
8				.76	
			PTISFL	58.32	
			ACFM	110.247	
			DSCFM	77.551	
Temp. Meas. Device & S/N:				Time End: 0835 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:STACK\WP\FORMS\S-392.1

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 2 Press BTD Stack
Test 4 Run 3 Date 8-26-94
Stack Dimen. 76 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 29.51 IN.HG
Static Pressure -.68 IN.WC
Operators BA BM
Pitot No. 270-8 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6 IN.	Time Start:	0920 HRS
A	1			.53	
	2			.65	
	3			.83	245
	4			.68	
	5			.80	
	6			.75	
	7			.71	
	8			.68	
B	1			.52	
	2			.61	
	3			.72	
	4			.85	
	5			.93	
	6			.92	
	7			.85	
	8			.70	
			FT/SEC	5228	
			ACFM	108273	
			DSCFM	75615	
Temp. Meas. Device & S/N:				Time End: 0927 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 2 Press RTO Stack
Test 4 Run 4 Date 8-26-94
Stack Dimen. 76 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 29.31 IN.HG
Static Pressure - .78 IN.WC
Operators BA DM
Pitot No. 27U-8 C. 184

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 6 IN.	Time Start: 1100 HRS		
A	1			.58	
	2			.76	
	3			.92	
	4			.91	
	5			.82	247
	6			.75	
	7			.60	
	8			.67	
B	1			.52	
	2			.64	
	3			.67	
	4			.82	
	5			1.01	
	6			.99	
	7			.86	
	8			.82	
			FT/SEC	58.28	
			fpm	110171	
			OR fpm	76521	
Temp. Meas. Device & S/N:				Time End: 1105 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 2 Field Data Sheet

Elevation
View

Pitot No.

270-8 C, 84


76.578

Time End: 1650 HRS

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 2 Press RTO Stack
Test 4 Run 2 Date 8-26-94
Stack Dimen. 76 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 29.81 IN.HG
Static Pressure -.51 IN.WC
Operators BA DM
Pitot No. 270-8 C. .84

[illegible]

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
 Source Line 2 Press RTO Stack
 Test 4 Run 8 Date 8-26-94
 Stack Dimen. 76 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp. ☒ Elec.
 Barometric Pressure 28.81 IN.HG
 Static Pressure -.125 IN.WC
 Operators BA DM
 Pitot No. 27U-8 Cp .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6</u> IN.	Time Start: <u>1400</u> HRS		
A 1				.63	
2				.83	
3				.85	
4				.96	
5				1.08	250
6				.73	
7				.70	
8				.83	
B 1				.48	
2				.65	
3				.72	
4				.75	
5				.97	
6				.95	
7				.85	
8				.70	
			FT/SEC	58.64	
			ACFM	110853	
			DSCFM	76885	
Temp. Meas. Device & S/N:					
				Time End: <u>1405</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 2 - Press RTO Stock
Test 4 Run 9 Date 8-26-94
Stack Dimen. 76 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.81 IN.HG
Static Pressure -.72 IN.WC
Operators BA DM
Pitot No. 27U-3 C. .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6 IN.	Time Start:	1445 HRS
A	1			.59	
	2			.62	
	3			.79	
	4			.83	250
	5			.67	
	6			.83	
	7			.63	
	8			.59	
B	1			.59	
	2			.63	
	3			.71	
	4			.84	
	5			.84	
	6			.95	
	7			.92	
	8			.81	
			FT/SCE	58-18	
			ACFM	109983	
			DSCPM	76245	
Temp. Meas. Device & S/N:				Time End: 1450 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
Source Line 2 Press RTO Stack
Test 4 Run 10 Date 8-26-94
Stack Dimen. 76 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.81 IN.HG
Static Pressure -.68 IN.WC
Operators BA DM
Pitot No. 270-8 C. 94

Cross-section View	Elevation View

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	6 IN.	Time Start: 1530 HRS	
A	1			.68	
	2			.84	
	3			.90	
	4			.83	257
	5			.90	
	6			.85	
	7			.73	
	8			.61	
B	1			.53	
	2			.65	
	3			.65	
	4			.89	
	5			.90	
	6			.91	
	7			.85	
	8			.73	
			FT/SEC	58.76	
			ACFM	111079	
			DSCFM	76284	
Temp. Meas. Device & S/N:				Time End: 1535 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

EPA Method 2 Field Data Sheet

Elevation
View

Job LP / Hayward
Source Line 2 Press RTO Stack
Test 4 Run 11 Date 3-26-94
Stack Dimen. 76 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 25.81 IN.HG
Static Pressure -.65 IN.WC
Operators BA DM
Pitot No. 270 - 8 C. 14

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length:		6	IN.	Time Start: 1615	HRS
4	1			.60	
	2			.52	
	3			.91	
	4			.83	247
	5			.85	
	6			.75	
	7			.73	
	8			.70	
8	1			.45	
	2			.64	
	3			.65	
	4			.75	
	5			.95	
	6			.81	
	7			.88	
	8			.82	
			PT/SEC	57.78	
			ACFM	109228	
			OSCFM	75884	
Temp. Meas. Device & S/N:				Time End: 1620 HRS	

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP/HAYWARD
Source LINE 2 PROCESS RTO STACK
Date 8-26-84 Test 4 Run 8

Operator(s) RA DM
Meter Box No. CEM Gas meter coef. .9937
 ΔH_0 — in. WC Bar. press. 28.87 in. Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. X
Posttest: 0.0 cfm at 15 in. Hg. X

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1400)	(649.650)								
	5	649.878	1000	2	249	—	—	68	—	—
	10	650.010	1000	2	250	—	—	68	—	—
	15	650.187	1000	2	248	—	—	68	—	—
	20	650.366	1000	2	248	—	—	68	—	—
	25	650.545	1000	2	250	—	—	68	—	—
	30	650.725	1000	2	249	—	—	68	—	—
	(1430)									
	$\theta = 30$	$V_m = 1.075$	(ΔH) <u>200</u>					(t_m) avg. <u>68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	75.696	75.025	.671
		Total	.671

Preliminary results of SO ₂ concentration determination	
V_{std}	= 1.028 DSCF
Moisture	= 2.98 %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job CP / HAYWARD
Source LEWIS & PRUSS RTO STACK
Date 8-26-94 Test 4 Run 9

Operator(s) BA DM
Meter Box No. 621 Gasmeter coef. 9937
 Δ Hg — in.WC Bar. press 28.61 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 6.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
<u>(1445)</u>		<u>(650.756)</u>								
	<u>5</u>	<u>650.932</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>10</u>	<u>651.108</u>	<u>1000</u>	<u>2</u>	<u>249</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>15</u>	<u>651.284</u>	<u>1000</u>	<u>2</u>	<u>248</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>20</u>	<u>651.460</u>	<u>1000</u>	<u>2</u>	<u>247</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>25</u>	<u>651.635</u>	<u>1000</u>	<u>2</u>	<u>251</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>30</u>	<u>651.825</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
<u>(1515)</u>										
<u>030</u>		<u>V_m = 1.069</u>	<u>(ΔH) = 1000</u>					<u>(t_m) avg. = 68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>74.896</u>	<u>74.224</u>	<u>.672</u>
		<u>Total</u>	<u>.672</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>= 1.022</u> DSCF
Moisture	<u>= 3.01</u> %v/v
SO ₂ , dry =	ppm
SO ₂ , wet =	ppm
LB/MMBtu =	

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job LP1 HAYWARD
Source LDUE 21155 270 STAIR
Date 8-26-94 Test 4 Run 10

Operator(s) BA PM
Meter Box No. 0041 Gas meter coef. 9937
 Δ He — in.WC Bar. press 28.87 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Orif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen
					Probe	Oven	Impg.	Gas/In	Gas/Out	(%v/v)
	(1530)	(651.852)								
	5	652.031	1000	2	249	—	—	68	—	—
	10	652.210	1000	2	248	—	—	68	—	—
	15	652.390	1000	2	250	—	—	68	—	—
	20	652.573	1000	2	250	—	—	68	—	—
	25	652.756	1000	2	249	—	—	68	—	—
	30	652.950	1000	2	248	—	—	68	—	—
	(600)									
	$\theta = 38$	$V_m = 1.098$	(ΔH)					$(t_m)_{avg} = 68$		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>74.851</u>	<u>74.165</u>	<u>.686</u>
		<u>Total</u>	<u>.686</u>

Preliminary results of SO ₂ concentration determination
V _{std} = <u>1.050</u> DSCF
Moisture = <u>2.98</u> %v/v
SO ₂ , dry = ppm
SO ₂ , wet = ppm
LB/MMBtu =

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job UP1 MAYLIARD
Source LAKE 2. PRESS. 270 STAIR
Date 8-26-84 Test 4 Run 11

Operator(s) BA DM
Meter Box No. 1041 Gasmeter coef. 5937
 Δ He in.WC Bar. press 28.67 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ☒
Posttest: 0.0 cfm at 15 in. Hg. ☒

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drif. Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
<u>(1615)</u>	<u>(65298)</u>									
	<u>5</u>	<u>653.148</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>10</u>	<u>653.321</u>	<u>1000</u>	<u>2</u>	<u>249</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>15</u>	<u>653.484</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>20</u>	<u>653.667</u>	<u>1000</u>	<u>2</u>	<u>248</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>25</u>	<u>653.840</u>	<u>1000</u>	<u>2</u>	<u>247</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
	<u>30</u>	<u>654.015</u>	<u>1000</u>	<u>2</u>	<u>250</u>	<u>—</u>	<u>—</u>	<u>68</u>	<u>—</u>	<u>—</u>
<u>(1645)</u>										
	<u>0=30</u>	<u>V_m=1.046</u>	<u>(ΔH) 1000</u>					<u>(t_m) avg. 68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>77.807</u>	<u>77.135</u>	<u>.672</u>
		Total	<u>.672</u>

Preliminary results of SO ₂ concentration determination	
V _{std}	<u>= 994</u> DSCF
Moisture	<u>= 30%</u> %v/v
SO ₂ , dry	= ppm
SO ₂ , wet	= ppm
LB/MMBtu	=

INTERPOLL LABORATORIES
EPA Method 4 and 6 Field Data Sheet

Job UP / HAYWARD
Source LINE 2 PRESS 270 STAINC
Date 8-26-94 Test 4 Run 12

Operator(s) RA DM
Meter Box No. 004 Gasmeter coef. 9937
 ΔH_0 — in.WC Bar. press 28.67 in.Hg

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. ~~X~~

Posttest: 0.0 cfm at 15 in. Hg. ~~X~~

MOISTURE

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Drift Meter (inWC)	VAC. inHg	Temperatures (°F)					Oxygen (%v/v)
					Probe	Oven	Impg.	Gas/In	Gas/Out	
	(700)	(654.637)								
	5	654.206	1000	2	247	—	—	68	—	—
	10	654.375	1000	2	248	—	—	68	—	—
	15	654.545	1000	2	249	—	—	68	—	—
	20	654.718	1000	2	250	—	—	68	—	—
	25	654.885	1000	2	251	—	—	68	—	—
	30	655.078	1000	2	248	—	—	68	—	—
	(730)									
	$\theta = 30$	$V_m = 1.041$	(ΔH) <u>28.67</u>					(t_m) avg. = <u>68</u>		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser			
Desiccant	<u>79.366</u>	<u>78.680</u>	<u>.676</u>
	Total		

Preliminary results
of SO₂ concentration
determination

V_{std} = 995 DSCF

Moisture = 3.10 %v/v

SO₂, dry = ppm

SO₂, wet = ppm

LB/MMBtu =


APPENDIX D

MEASUREMENT SYSTEM PERFORMANCE SPECIFICATIONS

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP1 HAYWARD
Source LEAVE 2 Dryer RTO STACK
Test 1 Run 8 Date 8-23-74
Stack Dimen. 81" IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☐ Elec.
Barometric Pressure 28.71 IN.HG
Static Pressure IN.WC
Operators B. ASHTENISACH D. MARSO
Pitot No. FIRST 8' C_p
A = 51' R_A B = 38' R_A

[illegible]

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOL LABORATORIES, INC

(612) 786-6020

CO System Bias Check

Job

LP1 HAYWARD

Source

LIME 2 Dryer PTO

Test

1 Run 1-12 Date 8-23-94

Site

STACK

Operator

BBB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0730	Zero Gas	0	2	4	2	1000	.2
		Upscale	249	249	248	1	1000	.1
2	0904	Zero Gas	0	2	8	6	1000	.60
		Upscale	249	249	248	1	1000	.1
3	0950	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	249	247	2	1000	.20
4	1035	Zero Gas	0	2	4	2	1000	.20
		Upscale	249	249	247	2	1000	.20
5	1120	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	247	245	4	1000	.40
6	1205	Zero Gas	0	2	8	6	1000	.60
		Upscale	249	249	245	4	1000	.40
7	1250	Zero Gas	0	2	1	1	1000	.10
		Upscale	249	249	248	1	1000	.10
8	14005	Zero Gas	0	2	8	6	1000	.60
		Upscale	249	249	248	1	1000	.10
9	1450	Zero Gas	0	2	9	7	1000	.70
		Upscale	249	249	247	0	1000	.0
10	1535	Zero Gas	0	2	6	4	1000	.40
		Upscale	249	249	250	1	1000	.10
11	1620	Zero Gas	0	2	10	8	1000	.80
		Upscale	249	249	248	1	1000	.10
12	1705	Zero Gas	0	2	9	7	1000	.70
		Upscale	249	249	245	4	1000	.40

Must be within 5% of the span for the zero or upscale cal. gas.

8

245

033194-C:STACK\WP\FORMS\5-420-11

INTERPOL LABORATORIES, INC

(612) 786-6020

O₂ System Bias Check

Job CP / HAYWARD Source LINE 2 DRY RTD
 Test 1 Run 1-12 Date 8-23-94 Site STACK
 Operator BOB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0730	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
2	0906	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
3	0950	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
4	1035	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
5	1120	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
6	1205	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40
7	1250	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
8	1405	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
9	1450	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
10	1535	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40
11	1620	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
12	1705	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40

Must be within 5% of the span for the zero or upscale cal. gas.

0

13.5

033194-G:STACK\WP\FORM55-420-11

INTERPOL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check

Job

LP / HAYWARD

Source

LINE 2 Diesel PTO

Test

1 Run 1-12 Date 8-23-84

Site

Static

Operator

Bob

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0730	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
2	0906	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
3	0950	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
4	1035	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	10.9	.1	20	.50
5	1120	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.1	.1	20	.50
6	1205	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
7	1250	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
8	1405	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	.1	20	.50
9	1450	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
10	1535	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
11	1620	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
12	1705	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	10.9	.1	20	.50

Must be within 5% of the span for the zero or upscale cal. gas.

.1

11.0 D-4

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP/ HAY ARW
 Source LINE 1 Dry or PRO STACK
 Test 2 Run 6 Date 5-24-86
 Stack Dimen. 21 IN.
 Dry Bulb °F Wet bulb °F
 Manometer ☐ Reg. ☐ Exp ☐ Elec.
 Barometric Pressure 28.22 IN.HG
 Static Pressure IN.WC
 Operators G. A. Schenck D. Marse
 Pitot No. 81 DUST C_p

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start:	HRS
Temp. Meas. Device & S/N:				Time End:	HRS

INTERPOLL LABORATORIES, INC
(612) 786-6020

CO System Bias Check

Job LP/ HAYWARD
Test 2 Run 1-12 Date 5-24-84
Operator Gas

Source LINE 1 Dryer PTO
Site STAC

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0716	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	249	249	0	1000	0
2	0850	Zero Gas	0	2	6	4	1000	.40
		Upscale	249	249	251	2	1000	.20
3	0935	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	249	250	1	1000	.10
4	1020	Zero Gas	0	2	6	4	1000	.40
		Upscale	249	249	252	3	1000	.30
5	1105	Zero Gas	0	2	7	5	1000	.50
		Upscale	249	249	252	3	1000	.30
6	1150	Zero Gas	0	2	7	5	1000	.50
		Upscale	249	249	251	2	1000	.20
7	1235	Zero Gas	0	2	7	5	1000	.50
		Upscale	249	249	251	2	1000	.20
8	1320	Zero Gas	0	2	6	4	1000	.40
		Upscale	249	249	247	2	1000	.20
9	1405	Zero Gas	0	2	6	4	1000	.40
		Upscale	249	249	245	4	1000	.40
10	1450	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	249	244	5	1000	.50
11	1620	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	249	242	7	1000	.70
12	1705	Zero Gas	0	2	5	3	1000	.30
		Upscale	249	249	243	6	1000	.60

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

O₂ System Bias Check

Job LP / HAYWARD Source LINE 1 Dye 210
Test 2 Run 1-12 Date 5-24-94 Site STACK
Operator BB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0714	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.40
2	0850	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
3	0935	Zero Gas	0	0	-1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
4	1020	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
5	1105	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
6	1150	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
7	1235	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
8	1320	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
9	1405	Zero Gas	0	0	-1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
10	1450	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40
11	1620	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.3	13.4	.1	25	.40
12	1705	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check
 Job LPI HAYWARD
 Test 2 Run 1-12 Date 5-24-84
 Operator Bob

 Source LINE 1 D-401 PTO
 Site SMC

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0716	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
2	0850	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
3	0935	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
4	1020	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
5	1105	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
6	1150	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
7	1235	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
8	1320	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.1	.1	20	.50
9	1405	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
10	1450	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
11	1620	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
12	1705	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0

Must be within 5% or the span for the zero or upscale cal. gas.

.1

10.9

033194-G:STACK\WP\FORMS\S-420-11

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO System Bias Check

Job

LP/ HAYWARD

Source

LINE 1 Press RTO

Test

3 Run 1-12 Date 8-25-96

Site

STACK

Operator

Sc3

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0715	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	148	0	250	0
2	0835	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	148	0	250	0
3	0920	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	147	1	250	.40
4	1005	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
5	1050	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	146	2	250	.80
6	1138	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
7	1220	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	147	1	250	.40
8	1305	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	146	2	250	.80
9	1350	Zero Gas	0	1	0	1.0	250	.40
		Upscale	150	148	144	4	250	1.60
10	1435	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	144	4	250	1.60
11	1520	Zero Gas	0	1	3	2	250	.80
		Upscale	150	148	147	1	250	.40
12	1605	Zero Gas	0	1	3	2	250	.80
		Upscale	150	148	146	2	250	.80

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC
(612) 786-6020

02 System Bias Check

Job CP/HAYWARD Source LINE 1 Press ETO
Test 3 Run 1-12 Date 8-25-80 Site STACK
Operator BCB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0715	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
2	0835	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
3	0920	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
4	1005	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
5	1050	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
6	1136	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
7	1220	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40
8	1305	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.3	.2	25	.80
9	1350	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40
10	1435	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
11	1520	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
12	1605	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check

Job LP1 HAYWARD Source LINE 1 Press 270
 Test 3 Run 1-12 Date F-25-84 Site STACK
 Operator G.B.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0715	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
2	0835	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	-.1	20	-.50
3	0920	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	10.9	-.1	20	-.50
4	1005	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	-.1	20	-.50
5	1050	Zero Gas	0	0	.1	-.1	20	-.50
		Upscale	11.1	11.0	10.9	-.1	20	-.50
6	1138	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	-.1	20	-.50
7	1220	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	10.9	-.1	20	.50
8	1305	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	-.1	20	.50
9	1350	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.1	-.1	20	.50
10	1435	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
11	1520	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
12	1605	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

ACC System Bias Check

Job

LPI HAYWARD

Source

LEVEL PRESS RTD

Test

3Run 1-12Date 5-25-84

Site

STACK

Operator

EB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1650	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	145	3	250	1.20
2	1735	Zero Gas	0	1	3	2	250	.80
		Upscale	150	148	146	2	250	.80
3		Zero Gas	0					
		Upscale						
4		Zero Gas	0					
		Upscale						
5	1650	Zero Gas	0	0	.1	-.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
6	1735	Zero Gas	0	0	.0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9	1650	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	10.9	-.1	20	.50
10	1735	Zero Gas	0	0	-.1	-.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

033194-G:STACK\WPA\FORM55-420-11

INTERPOLL LABORATORIES, INC
(612) 786-6020

CO System Bias Check

Job CP/ HAYWARD Source LINE 2 Press RTO
Test 41 Run 1-12 Date 8-26-9K Site STACK
Operator LSB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0707	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
2	0820	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
3	0905	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
4	0950	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
5	1050	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
6	1135	Zero Gas	0	1	2	1	250	.40
		Upscale	150	148	147	1	250	.40
7	1220	Zero Gas	0	1	3	2	250	.80
		Upscale	150	148	147	1	250	.40
8	1305	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	145	3	250	1.20
9	1350	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	146	2	250	.80
10	1435	Zero Gas	0	1	0	0	250	.40
		Upscale	150	148	146	2	250	.80
11	1520	Zero Gas	0	1	1	0	250	0
		Upscale	150	148	147	1	250	.40
12	1605	Zero Gas	0	1	0	1	250	.40
		Upscale	150	148	145	3	250	1.20

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

O₂ System Bias Check

Job LP1 HAYGARD Source LINE 2 PRESS RTO
 Test 41 Run 1-12 Date 8-26-84 Site SINCE
 Operator BUS

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0707	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.40
2	0820	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
3	0805	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
4	0958	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.6	.1	25	.40
5	1050	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	.1	25	.40
6	1135	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
7	1220	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40
8	1305	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
9	1350	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.4	.1	25	.40
10	1435	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
11	1520	Zero Gas	0	0	.1	.1	25	.40
		Upscale	13.5	13.5	13.5	0	25	0
12	1605	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.40

Must be within 5% of the span for the zero or upscale cal. gas.

033194-G:STACK\WP\FORMS\SS-420-11

INTERPOL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check

Job (P) MAY 4, 1984 Source LINE 2 PRESS RTD
 Test 4 Run 1-12 Date 5-26-84 Site STMIK
 Operator BEB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	0207	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	11.0	0	20	0
2	0520	Zero Gas	0	0	1	.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
3	0905	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	11.0	0	20	0
4	0950	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
5	1050	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	11.0	0	20	0
6	1135	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	10.9	-.1	20	.50
7	1220	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	-.1	20	.50
8	1305	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	10.9	-.1	20	.50
9	1350	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	-.1	20	.50
10	1435	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.1	-.1	20	.50
11	1520	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	11.0	0	20	0
12	1605	Zero Gas	0	0	.1	-.1	20	.50
		Upscale	11.1	11.0	10.9	-.1	20	.50

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

ALL System Bias Check

Job

LP/HAYWARD

Source

LINE 2 Press RTO

Test

4 Run 1-12 Date 8-26-84

Site

STACK

Operator

LAB

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
13	1650	Zero Gas	0	1	0	1	250	.40
		Upscale	150	148	148	0	250	0
24	1735	Zero Gas	0	1	0	1	250	.4
		Upscale	150	148	147	1	250	.4
3		Zero Gas	0					
		Upscale						
4		Zero Gas	0					
		Upscale						
83	1650	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.3	.2	25	.80
64	1735	Zero Gas	0	0	.1	.1	25	.41
		Upscale	13.5	13.5	13.4	.1	25	.40
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
13	1650	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.0	10.9	.1	20	.50
14	1735	Zero Gas	0	0	.1	.1	20	.50
		Upscale	11.1	11.0	10.9	.1	20	.50
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES

Calibration Error Check

Job CP/ HAYWARDTest 1 Run 1-12 Date 8-23-94Operator Bob

Calibration:

Time (HRS) 0705

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	2	2	1000	2
Mid level	249	249	0	1000	0
High level	594	597	5	1000	.5

NO_x Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

O₂ Calibration:Time (HRS) 0705

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	25	0
Mid level	13.5	13.5	0	25	0
High level	21	21.0	0	25	0

CO₂ Calibration:Time (HRS) 0705

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	20	0
Mid level	11.1	11.0	.1	20	.50
High level	17	17.0	0	20	0

Must be within 2% of the span for each calibration gas

S-420-10

INTERPOLL LABORATORIES

Calibration Error Check

Job LP / MAY 4, 2011Test 3 Run 0 Date 8-25-94Operator Bob

CO Calibration:

Time (HRS) 0700

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	1	1	250	40
Mid level	150	148	2	250	.80
High level	249	251	2	250	.80

NO_x Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

CO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

Must be within 2% of the span for each calibration gas

S-420-10

APPENDIX E

CALIBRATION GAS CERTIFICATION SHEETS

Interpoll Laboratories, Inc.
(612) 786-6020

CERTIFICATE OF ANALYSIS FOR
MIDRANGE STANDARD GAS FOR METHOD 3A

Vendor: National Specialty Gases
Cylinder No: CC 103339
Date of Preparation: 3-11-93
Label: 17% CO₂ / 21.1% O₂ BAL NIT
Blend Specification: _____

Results Of Analyses Of Standard Gas (by Orsat)

Date of Analysis	Run	CO ₂ (% v/v)	O ₂ (% v/v)
<u>8-11-93</u>	<u>1</u>	<u>16.99</u>	<u>21.21</u>
<u>"</u>	<u>2</u>	<u>17.12</u>	<u>21.24</u>
<u>"</u>	<u>3</u>	<u>17.15</u>	<u>21.23</u>
_____	<u>4</u>	_____	_____
_____	<u>5</u>	_____	_____
_____	<u>6</u>	_____	_____
_____	Avg	<u>17.09</u>	<u>21.23</u>

Analyst: Bob Aschenbach

- ☒ Results are within 5% of the vendor tag value; use tag value.
☐ Results are not within 5% of the vendor tag value; conduct another set of triplicate analyses.
☐ All results within $\pm 5\%$ of the average; relabel as above.
☐ All results not within $\pm 5\%$ of the average; perform another set of triplicate analyses.

Approved by,

August 16, 1993
Date

Daniel H. Desper for
Dr. Perry Lonnes

S-424

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1993 -

File Name: CG5
Job Number: 3-3333
Client: Interpoll Laboratories
Location: Circle Pines, Minnesota

CC103339 - 21 02/ 17 CO2 -- Run 1 - 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO2 (%v/v)	O2 (%v/v)
223	14:52:00	16.92	21.20
223	14:52:30	16.97	21.21
223	14:53:00	17.02	21.21
223	14:53:30	17.06	21.22
223	14:54:00	11.57	17.83
223	14:54:30	0.66	0.30
223	14:55:00	0.51	0.07
223	14:55:30	0.23	0.06
223	14:56:00	-0.05	0.03
223	14:56:30	-0.08	0.02
223	14:57:00	7.89	7.95
223	14:57:30	10.83	13.52
223	14:58:00	10.87	13.53
223	14:58:30	8.03	14.65
223	14:59:00	10.90	13.04
223	14:59:30	6.44	9.14
223	15:00:00	0.11	0.10
223	15:00:30	7.95	7.39
223	15:01:00	10.84	12.69
223	15:01:30	10.74	12.72
223	15:02:00	10.81	12.45
223	15:02:30	10.82	12.42
223	15:03:00	9.40	12.47
223	15:03:30	8.80	13.64
223	15:04:00	10.97	11.88
223	15:04:30	10.97	11.87
223	15:05:00	11.02	11.86
223	15:05:30	7.05	13.43
223	15:06:00	5.08	22.18
223	15:06:30	1.71	20.09
223	15:07:00	9.59	16.19
223	15:07:30	10.81	13.92
223	15:08:00	10.99	13.56
223	15:08:30	11.01	13.56

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1993 -

File Name: CG5
Job Number: 3-3333
Client: Interpoll Laboratories
Location: Circle Pines, Minnesota

CC103339 - 21 02/ 17 CO2 -- Run 1 - 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO2 (%v/v)	O2 (%v/v)
223	15:09:00	15.87	18.94
223	15:09:30	17.00	21.21
223	15:10:00	17.05	21.23
223	15:10:30	17.10	21.24
223	15:11:00	17.14	21.24
223	15:11:30	17.19	21.25
223	15:12:00	11.45	17.75
223	15:12:30	0.37	0.23
223	15:13:00	0.08	0.06
223	15:13:30	4.74	4.41
223	15:14:00	10.78	13.54
223	15:14:30	10.99	13.56
223	15:15:00	10.96	13.56
223	15:15:30	15.12	17.64
223	15:16:00	17.01	21.21
223	15:16:30	17.06	21.22
223	15:17:00	17.10	21.21
223	15:17:30	17.13	21.23
223	15:18:00	17.17	21.24
223	15:18:30	17.21	21.25



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063-0000
PHONE: 313-589-2950 FAX: 313-589-2134

8/02/91

GENEX
4018 DUNCAN AVENUE

PROJECT #: 05-26600
PO #: 4970SA

ST LOUIS

MO 63110-0000

CYLINDER #: ALM008828

ANALYTICAL ACCURACY: +-2%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 (MOLES) U/M
CARBON MONOXIDE	150.0 PPM	150. PPM
NITROGEN	BALANCE	N/A

NOTES: CERTIFIED MASTER GAS

ANALYTICAL METHOD: CMG

DATE OF ANALYSIS: 7/29/91

ANALYST:

ANALYST

APPROVED BY:

SUPERVISOR



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063-0000
PHONE: 313-589-2950 FAX: 313-599-2134

8/02/91

GENEX
4018 DUNCAN AVENUE

PROJECT #: 05-26600
PO #: 49705A

ST LOUIS

MO 63110-0000

CYLINDER #: AAL19103

ANALYTICAL ACCURACY: +-2%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 (MOLES) U/M
CARBON MONOXIDE	250.0 PPM	249. PPM
NITROGEN	BALANCE	N/A

NOTES: CERTIFIED MASTER GAS

ANALYTICAL METHOD: CMG

DATE OF ANALYSIS: 7/29/91

ANALYST

ANALYST

APPROVED BY:

SUPERVISOR



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063-0000
PHONE: 313-589-2950 FAX: 313-589-2134

8/02/91

GENEX
4018 DUNCAN AVENUE

PROJECT #: 05-26600
PO #: 4970SA

ST LOUIS

MO 63110-0000

CYLINDER #: ALM020902

ANALYTICAL ACCURACY: +-2%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 (MOLES) U/M
CARBON MONOXIDE	600.0 PPM	594. PPM
NITROGEN	BALANCE	N/A

NOTES: CERTIFIED MASTER GAS

ANALYTICAL METHOD: CMG

DATE OF ANALYSIS: 7/29/91

ANALYST:

Frank P. Lora
ANALYST

APPROVED BY:

J. Shapiro
SUPERVISOR

APPENDIX F

GAS ANALYZER SPECIFICATIONS

Servomex

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1420 Oxygen Analyser Instruction Manual

Ref : 01420/001A/0

Order as part No. 01420001A

was (7982-2842)

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

SPECIFICATIONS FOR ACS MODEL 3300 CO NDIR

Measuring principle	NDIR single beam method
Operating ranges	0 - 500 ppm 0 - 1000 ppm
Reproducibility	±0.5% of full scale
Stability	Zero drift; ±% of full scale/24H Span drift; ±% of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500Ω max.)
Linearity	Better than ±2% of full scale (when linearizer is used)
Power supply	AC 115 V ± 10%, 60 Hz

Power consumption	Approx. 30 VA
Materials of gas- contacting parts	Measuring cell; SUS304 Window; CaF ₂ Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.

APPENDIX G

CEM INSTRUMENT INFORMATION SHEETS

CEM Relative Field Accuracy Certification Instrument Information Sheet

Plant Name LP/ HAYWARD

GRAYBY-STI HI-FLOW CO PROBE & EXTRACTIVE SYSTEM
Pollutant Gas Monitor Data:

Vendor TECO - THERMAL ENVIRONMENTAL INSTRUMENTS, INC.

Model 48 CO ANALYZER SIN 48-47744-279

Location LINE 2 DRYER RTO STACK & SHELTER HOUSE

Gas(es): ☐ SO2 ☐ NOx ☒ CO

Type of System: ☐ In-situ ☒ Extractive

Installation Date JULY 22, 1994

Startup Date AUGUST 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer IN SHELTER HOUSE
and
DAS

Relative Accuracy Certification Units:

☒ ppm, dry ☐ LB/10⁶BTU by O₂ F-Factor

☐ ppm, wet ☐ LB/10⁶BTU by CO₂ F-Factor

Span Value (ppm):

SO₂ _____

NO_x _____

CO 500

* Print outs of kcfm & temperature are actual
stack data. Computer program calcs kdsicfm
and CO' #/HR are calculated from COppmd
and kdsicfm (kcfm corrected for temp, pressure and % moisture content).

Plant Location HAYWARD CA

Flow & Temperature
Effluent Monitor Data:

Vendor USI - United Sciences, Inc.

Model 100 SIN 9401656

Location LINE 2 DRYER RTO STACK

Gas: ☐ O₂ ☐ CO₂ ☒ Air Flow

Type of System: ☐ In-situ ☐ Extractive ULTRASONIC

Installation Date JULY 22, 1994

Startup Date AUGUST 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer IN SHELTER HOUSE
and
DAS

Output Units:

☐ % O₂, dry ☐ % CO₂, dry ☒ kacfms *

☐ % O₂, wet ☐ % CO₂, wet ☒ OF Temperature *

Span Gas Values (%v/v):

*****Oxygen*****

LOW 0 FLOW

HIGH 120 kacfms

Carbon Dioxide

8-23-94

Date S-253 RR-9/25

Bob Schultz
Signature of Person
Responsible for Data

CEM Relative Field Accuracy Certification Instrument Information Sheet

Plant Name CP / HAYWARD

Plant Location HAYWARD CA

Pollutant Gas Monitor Data:

Vendor Thermo Environmental Instruments Inc.

Model 48 CO ANALYZER SIN 48-47743-279

Location Line I DAYVIA RTO STACK & STEELER HOUSE

Gas(es): ☐ SO2 ☐ NOx ☒ CO

Type of System: ☐ In-situ ☒ Extractive

Installation Date July 24, 1994

Startup Date August 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer

Relative Accuracy Certification Units:

☒ ppm, dry ☐ LB/10⁶BTU by O₂ F-Factor

☐ ppm, wet ☐ LB/10⁶BTU by CO₂ F-Factor

Span Value (ppm):

SO₂ _____

NO_x _____

CO 500

Output Units:

☐ % O₂, dry ☐ % CO₂, dry

☐ % O₂, wet ☐ % CO₂, wet

Span ~~Gas~~ Values (~~ppm~~): kgpm

*****Oxygen*****

LOW 0 FLOW

HIGH 120 kgpm

Carbon Dioxide

* Printouts of kgpm & temperature are actual stack data. Computer program calculates kgdsfm and CO #/hr from CO ppm and kgdsfm (kgpm corrected for temp., pressure and % O₂)

Flow & Temperature

Diluent Monitor Data:

Vendor DSI - United Sciences, Inc.

Model 100 SIN 9401655

Location Line I Dryer RTO Stack

Gas: ☐ O₂ ☐ CO₂ ☒ Airflow

Type of System: ☐ In-situ ☐ Extractive

Installation Date July 24, 1994

Startup Date August 10, 1994

8-24-94

Date S-253 RR-9/25

Signature of Person Responsible for Data

Bob Schultz

CEM Relative Field Accuracy Certification Instrument Information Sheet

Plant Name LP / HAYWARD

Plant Location HAYWARD, WI

Pollutant Gas Monitor Data:

Vendor TECO - Thermo Environmental Instruments, Inc.

Model 48 CO Analyzer SIN 48-48535-281

Location Line / PRESS RTO STACK & SHELTER HOUSE

Gas(es): ☐ SO₂ ☐ NO_x ☒ CO

Type of System: ☐ In-situ ☒ Extractive

Installation Date July 20, 1994

Startup Date August 10, 1994

Flow & Temperature

-Effluent Monitor Data:

Vendor USI - United Sciences, Inc.

Model 100 SIN 9401057

Location Line / Press RTO STACK

Gas: ☐ O₂ ☐ CO₂ ☒ Airflow

Type of System: ☐ In-situ ☐ Extractive ☒ Ultrasonic

Installation Date July 20, 1994

Startup Date August 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System

☒ Computer

Relative Accuracy Certification Units:

☒ ppm, dry ☐ LB/10⁶BTU by O₂ F-Factor

☐ ppm, wet ☐ LB/10⁶BTU by CO₂ F-Factor

Span Value (ppm):

SO₂ _____

NO_x _____

CO 100

Output Units:

☐ % O₂, dry ☐ % CO₂, dry

☐ % O₂, wet ☐ % CO₂, wet

Span Gas Values (% v/v):

*****Oxygen*****

Low Flow

High 120 kacf/m

Carbon Dioxide

Output Units:

☐ % O₂, dry ☐ % CO₂, dry

☐ % O₂, wet ☐ % CO₂, wet

Span Gas Values (% v/v):

*****Oxygen*****

Low Flow

High 120 kacf/m

Carbon Dioxide

* Pintouts of kacf/m & temperature are actual stack data. Computer program calculates kdsf/m and CO #/hr from CO ppm dry and kdsf/m = (Kacf/m corrected for temp., pressure, and % moisture content).

Signature of Person Responsible for Data Robert W. Kline

8-25-94

Date 8-25-94 S-253 RR-9/25

LN 2 PRESS

Interpoll Laboratories
(612)786-6020

CEM Relative Field Accuracy Certification Instrument Information Sheet

Plant Name LP/HAYWARDPlant Location HAYWARD, WI

Pollutant Gas Monitor Data:

Vendor TECO - Thermo Environmental Instruments, IncModel 48 CO Analyzer SIN 48-48536-281Location Line 2 Press RTO Stack & SHELTER HOUSEGas(es): ☐ SO₂ ☐ NO_x ☒ COType of System: ☐ In-situ ☒ ExtractiveInstallation Date July 25, 1994Startup Date August 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System☒ Computer

Relative Accuracy Certification Units:

☒ ppm, dry ☐ LB/10⁶BTU by O₂ F-Factor☐ ppm, wet ☐ LB/10⁶BTU by CO₂ F-Factor

Span Value (ppm):

SO₂ _____NO_x _____CO 100

* Pintouts of kgcfm & temperature are actual stack data. Computer program calculates kgcfm and CO #/hr from CO ppm dry and kgcfm = (kgcfm corrected for temp, pressure, and % O₂)

Flow & Temperature Effluent Monitor Data:

Vendor VSI - United Sciences, Inc.Model 100 SIN 9401058Location Line 2 Press RTO StackGas: ☐ O₂ ☐ CO₂ ☒ AirflowType of System: ☐ In-situ ☐ Extractive UltrasonicInstallation Date July 25, 1994Startup Date August 10, 1994

Data Recording System:

☐ Strip Chart Recorder ☐ Data Logger System☒ Computer

Output Units:

☐ % O₂, dry ☐ % CO₂, dry ☒ kgcfm *☐ % O₂, wet ☐ % CO₂, wet ☒ temperature - 9-*

Span Gas Values (% v/v):

*****Oxygen*****

Low FlowHigh 120 kgcfm

Carbon Dioxide

Signature of Person

Responsible for Data

Date

S-253 RR-9/25

APPENDIX H

CEM DATA

DAILY TEMP SUMMARY REPORT

Dryer #1 TEMP Deg-F FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

DAY'S DATE: 08-24-1994
TIME: 17:57:54

REPORTING PERIOD
DAY: August 24

Period	15		30		45		60		Hr. AVG.	
	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.
Hour 7	331.7	0	337.1	0	337.8	0	339.2	0	336.4	0
Hour 8	339.2	0	337.6	0	339.3	0	343.2	0	339.8	0
Hour 9	340.0	0	338.8	0	338.9	0	344.9	0	340.6	0
Hour 10	342.3	0	342.3	0	347.5	0	351.1	0	345.8	0
Hour 11	351.9	0	351.9	0	349.7	0	350.4	0	351.0	0
Hour 12	353.6	0	354.7	0	351.6	0	347.6	0	351.9	0
Hour 13	347.5	0	344.9	0	342.5	0	347.1	0	345.5	0
Hour 14	354.3	0	357.0	0	353.2	0	353.1	0	354.4	0
Hour 15	353.1	0	351.6	0	352.1	0	346.3	0	350.8	0
Hour 16	346.2	0	346.0	0	346.8	0	350.6	0	347.4	0
Hour 17	352.5	0	367.6	0	352.3	0	-1.0	-1	-1.0	-1
Hour 18	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 19	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 20	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 21	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 22	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 23	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 1	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 2	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 3	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 4	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 5	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 6	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0

DAILY TEMP SUMMARY REPORT

Dryer #1 TEMP Deg-F FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994
TIME: 11:43:35

REPORTING PERIOD
DAY: August 24

Period	15		30		45		60		Hr. AVG.	
	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.
Hour 7	331.7	0	337.1	0	337.8	0	339.2	0	336.4	0
Hour 8	339.2	0	337.6	0	339.3	0	343.2	0	339.8	0
Hour 9	340.0	0	338.8	0	338.9	0	344.9	0	340.6	0
Hour 10	342.3	0	342.3	0	347.5	0	351.1	0	345.8	0
Hour 11	351.9	0	351.9	0	349.7	0	350.4	0	351.0	0
Hour 12	353.6	0	354.7	0	351.6	0	347.6	0	351.9	0
Hour 13	347.5	0	344.9	0	342.5	0	347.1	0	345.5	0
Hour 14	354.3	0	357.0	0	353.2	0	353.1	0	354.4	0
Hour 15	353.1	0	351.6	0	352.1	0	346.3	0	350.8	0
Hour 16	346.2	0	346.0	0	346.8	0	350.6	0	347.4	0
Hour 17	352.5	0	367.6	0	352.3	0	325.7	0	349.5	0
Hour 18	353.8	0	355.0	0	355.3	0	353.0	0	354.3	0
Hour 19	352.2	0	349.6	0	349.0	0	350.0	0	350.2	0
Hour 20	354.1	0	352.5	0	350.8	0	352.8	0	352.6	0
Hour 21	343.6	0	327.8	0	323.2	0	318.2	0	328.2	0
Hour 22	309.2	0	322.1	0	324.7	0	325.0	0	320.3	0
Hour 23	336.0	0	340.7	0	348.7	0	352.0	0	344.4	0
Hour 0	352.0	0	352.4	0	351.8	0	342.6	0	349.7	0
Hour 1	346.9	0	354.4	0	350.9	0	344.8	0	349.3	0
Hour 2	334.5	0	335.5	0	346.7	0	338.4	0	338.8	0
Hour 3	338.4	0	355.1	0	360.6	0	362.3	0	354.1	0
Hour 4	360.5	0	358.8	0	358.8	0	358.8	0	359.2	0
Hour 5	343.8	0	346.1	0	343.6	0	339.0	0	343.1	0
Hour 6	337.0	0	341.9	0	340.9	0	340.6	0	340.1	0

DAILY CO SUMMARY REPORT

Dryer #1 CO ppm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-24-1994
TIME: 17:56:19

REPORTING PERIOD
DAY: August 24

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	237.2	0	265.0	0	242.2
Hour 8	281.9	0	271.1	0	451.2
Hour 9	292.9	0	420.7	0	354.3
Hour 10	452.2	0	491.7	0	430.7
Hour 11	460.8	0	395.9	0	427.4
Hour 12	419.4	0	319.3	0	289.1
Hour 13	195.8	0	188.9	0	287.9
Hour 14	498.1	0	384.6	0	114.1
Hour 15	109.6	0	201.4	0	224.1
Hour 16	158.9	0	136.1	0	195.8
Hour 17	390.7	0	418.3	0	48.4
Hour 18	-1.0	-1	-1.0	-1	-1.0
Hour 19	-1.0	-1	-1.0	-1	-1.0
Hour 20	-1.0	-1	-1.0	-1	-1.0
Hour 21	-1.0	-1	-1.0	-1	-1.0
Hour 22	-1.0	-1	-1.0	-1	-1.0
Hour 23	-1.0	-1	-1.0	-1	-1.0
Hour 0	0.0	0	0.0	0	0.0
Hour 1	0.0	0	0.0	0	0.0
Hour 2	0.0	0	0.0	0	0.0
Hour 3	0.0	0	0.0	0	0.0
Hour 4	0.0	0	0.0	0	0.0
Hour 5	0.0	0	0.0	0	0.0
Hour 6	0.0	0	0.0	0	0.0

DAILY CO SUMMARY REPORT

Dryer #1 CO ppm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994

TIME: 11:43:06

REPORTING PERIOD

DAY: August 24

Period	15	30	45	60	Hr. AVG.					
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.					
Hour 7	237.2	0	265.0	0	242.2	0	367.2	0	277.9	0
Hour 8	281.9	0	271.1	0	451.2	0	307.8	0	328.0	0
Hour 9	292.9	0	420.7	0	354.3	0	337.0	0	351.2	0
Hour 10	452.2	0	491.7	0	430.7	0	462.7	0	459.3	0
Hour 11	460.8	0	395.9	0	427.4	0	480.6	0	441.2	0
Hour 12	419.4	0	319.3	0	289.1	0	215.7	0	310.9	0
Hour 13	195.8	0	188.9	0	287.9	0	476.4	0	287.2	0
Hour 14	498.1	0	384.6	0	114.1	0	83.3	0	270.0	0
Hour 15	109.6	0	201.4	0	224.1	0	140.7	0	168.9	0
Hour 16	158.9	0	136.1	0	195.8	0	334.8	0	206.4	0
Hour 17	390.7	0	418.3	0	48.4	0	354.3	0	302.9	0
Hour 18	365.1	0	301.1	0	221.2	0	193.4	0	270.2	0
Hour 19	176.8	0	169.6	0	223.3	0	217.4	0	196.8	0
Hour 20	196.1	0	141.2	0	216.4	0	306.0	0	214.9	0
Hour 21	57.6	0	29.8	0	11.7	0	8.8	0	27.0	0
Hour 22	264.9	0	473.0	0	403.1	0	312.5	0	363.4	0
Hour 23	305.2	0	294.8	0	411.2	0	498.9	0	377.5	0
Hour 0	390.9	0	311.8	0	163.5	0	125.1	0	247.8	0
Hour 1	376.7	0	430.7	0	291.5	0	152.4	0	312.8	0
Hour 2	88.4	0	314.3	0	139.1	0	247.1	0	197.2	0
Hour 3	485.3	0	498.0	0	498.8	0	498.8	0	495.2	0
Hour 4	276.1	0	245.8	0	228.6	0	137.2	0	221.9	0
Hour 5	202.9	0	204.2	0	132.4	0	112.4	0	163.0	0
Hour 6	122.7	0	111.1	0	117.1	0	207.3	0	139.5	0

DAILY FLOW SUMMARY REPORT

Dryer #1 FLOW kcfm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

DAY'S DATE: 08-24-1994
TIME: 17:57:03

REPORTING PERIOD
DAY: August 24

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	115.3 0	114.4 0	115.6 0	114.6 0	115.0 0
Hour 8	116.0 0	113.3 0	113.8 0	115.4 0	114.6 0
Hour 9	115.7 0	114.5 0	114.9 0	113.8 0	114.7 0
Hour 10	115.1 0	116.2 0	115.3 0	115.6 0	115.5 0
Hour 11	115.5 0	114.7 0	116.2 0	117.7 0	116.0 0
Hour 12	116.4 0	118.5 0	116.3 0	116.2 0	116.9 0
Hour 13	117.2 0	117.4 0	118.5 0	118.3 0	117.9 0
Hour 14	118.2 0	117.4 0	118.7 0	119.2 0	118.4 0
Hour 15	118.7 0	117.3 0	117.9 0	118.6 0	118.1 0
Hour 16	119.0 0	119.0 0	119.3 0	118.1 0	118.8 0
Hour 17	117.1 0	116.2 0	115.5 0	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 1	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 2	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 3	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 4	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 5	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 6	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0

DAILY FLOW SUMMARY REPORT

Dryer #1 FLOW kcf# FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994

TIME: 11:43:20

REPORTING PERIOD

DAY: August 24

Period	15	30	45	60	Hr. AVG.					
Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.					
Hour 7	115.3	0	114.4	0	115.6	0	114.6	0	115.0	0
Hour 8	116.0	0	113.3	0	113.8	0	115.4	0	114.6	0
Hour 9	115.7	0	114.5	0	114.9	0	113.8	0	114.7	0
Hour 10	115.1	0	116.2	0	115.3	0	115.6	0	115.5	0
Hour 11	115.5	0	114.7	0	116.2	0	117.7	0	116.0	0
Hour 12	116.4	0	118.5	0	116.3	0	116.2	0	116.9	0
Hour 13	117.2	0	117.4	0	118.5	0	118.3	0	117.9	0
Hour 14	118.2	0	117.4	0	118.7	0	119.2	0	118.4	0
Hour 15	118.7	0	117.3	0	117.9	0	118.6	0	118.1	0
Hour 16	119.0	0	119.0	0	119.3	0	118.1	0	118.8	0
Hour 17	117.1	0	116.2	0	115.5	0	118.5	0	116.8	0
Hour 18	117.5	0	118.7	0	120.9	0	120.5	0	119.4	0
Hour 19	121.5	0	122.0	0	120.6	0	120.6	0	121.2	0
Hour 20	119.2	0	120.3	0	119.8	0	118.4	0	119.4	0
Hour 21	117.2	0	121.5	0	122.0	0	123.3	0	121.0	0
Hour 22	122.8	0	120.2	0	119.8	0	116.9	0	119.9	0
Hour 23	118.9	0	119.2	0	119.2	0	120.5	0	119.5	0
Hour 0	119.9	0	119.9	0	121.6	0	119.7	0	120.3	0
Hour 1	119.9	0	116.6	0	117.1	0	117.8			

Sector not found error reading file
REPORT1.TMP

DAILY SUMMARY REPORT
Dryer #1 HOURLY AVERAGES
LOUISIANA PACIFIC
Hayward, WI

REPORTING PERIOD August 24

Period	CO ppm	FLOW kcfm	TEMP Deg-F	CO #/HR
7:00 to 8:00	277.9	115.0	336.4	66.5
8:00 to 9:00	328.0	114.6	339.8	77.9
9:00 to 10:00	351.2	114.7	340.6	83.4
10:00 to 11:00	459.3	115.5	345.8	109.2
11:00 to 12:00	441.2	116.0	351.0	104.6
12:00 to 13:00	310.9	116.9	351.9	74.2
13:00 to 14:00	287.2	117.9	345.5	69.7
14:00 to 15:00	270.0	118.4	354.4	65.1
15:00 to 16:00	168.9	118.1	350.8	40.8
16:00 to 17:00	206.4	118.8	347.4	50.4
17:00 to 18:00	302.9	116.8	349.5	72.5
18:00 to 19:00	270.2	119.4	354.3	65.7
19:00 to 20:00	196.8	121.2	350.2	48.8
20:00 to 21:00	214.9	119.4	352.6	52.4
21:00 to 22:00	27.0	121.0	328.2	6.9
22:00 to 23:00	363.4	119.9	320.3	92.6
23:00 to 24:00	377.5	119.5	344.4	93.0
0:00 to 1:00	247.8	120.3	349.7	61.0
1:00 to 2:00	312.8	117.9	349.3	75.5
2:00 to 3:00	197.2	118.2	338.8	48.4
3:00 to 4:00	495.2	118.7	354.1	119.7
4:00 to 5:00	221.9	119.1	359.2	53.5
5:00 to 6:00	163.0	118.5	343.1	39.9
6:00 to 7:00	139.5	118.6	340.1	34.3

Averages

7:00 to 19:00	306.2	116.9	347.3	73.5
19:00 to 7:00	246.4	119.4	344.2	60.6
7:00 to 7:00	276.3	118.1	345.7	67.1

* Bad data not used for averages.

DAILY OPAC SUMMARY REPORT

Dryer #1 OPAC pct SIX MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994
TIME: 11:43:51

REPORTING PERIOD
DAY: August 24

Period	6	12	18	24	30	36	42	48	54	60
Hr 7	1.1 0	1.0 0	1.0 0	1.1 0	1.1 0	1.1 0	1.2 0	1.3 0	1.4 0	1.4 0
Hr 8	1.4 0	1.3 0	1.2 0	1.4 0	1.4 0	1.5 0	1.6 0	1.4 0	1.3 0	1.3 0
Hr 9	1.3 0	1.3 0	1.6 0	1.4 0	1.6 0	1.3 0	1.6 0	1.7 0	1.6 0	1.3 0
Hr 10	1.5 0	1.7 0	1.6 0	1.7 0	1.7 0	1.7 0	1.5 0	1.9 0	1.7 0	1.9 0
Hr 11	1.7 0	1.6 0	1.7 0	1.7 0	1.5 0	1.6 0	1.6 0	1.5 0	1.7 0	1.8 0
Hr 12	1.6 0	1.8 0	1.5 0	1.5 0	1.4 0	1.4 0	1.4 0	1.4 0	1.3 0	1.3 0
Hr 13	1.3 0	1.2 0	1.2 0	1.1 0	1.2 0	1.2 0	1.4 0	1.6 0	1.7 0	1.7 0
Hr 14	1.7 0	1.7 0	1.7 0	1.6 0	1.2 0	1.1 0	0.9 0	0.9 0	0.8 0	0.8 0
Hr 15	0.9 0	0.9 0	0.9 0	1.0 0	1.1 0	1.1 0	1.0 0	1.0 0	1.0 0	1.1 0
Hr 16	0.9 0	0.9 0	0.9 0	0.9 0	0.8 0	0.9 0	0.9 0	0.9 0	1.0 0	1.1 0
Hr 17	1.1 0	1.1 0	1.4 0	1.2 0	1.2 0	1.1 0	1.1 0	1.1 0	1.1 0	1.4 0
Hr 18	1.3 0	1.3 0	1.2 0	1.2 0	1.1 0	1.1 0	1.1 0	1.1 0	1.1 0	1.0 0
Hr 19	1.0 0	1.0 0	0.8 0	0.8 0	0.8 0	0.8 0	0.9 0	0.9 0	0.9 0	0.9 0
Hr 20	1.0 0	0.8 0	0.7 0	0.8 0	0.8 0	0.9 0	0.9 0	1.0 0	1.1 0	1.1 0
Hr 21	0.9 0	0.9 0	1.0 0	1.0 0	1.3 0	1.3 0	1.3 0	1.3 0	1.3 0	1.4 0
Hr 22	1.4 0	1.9 0	2.5 0	2.5 0	2.5 0	2.1 0	1.8 0	1.6 0	1.5 0	1.3 0
Hr 23	1.3 0	1.3 0	1.3 0	1.4 0	1.3 0	1.4 0	1.4 0	1.5 0	1.5 0	1.3 0
Hr 0	1.3 0	1.3 0	1.2 0	1.1 0	1.0 0	1.0 0	0.9 0	0.8 0	0.8 0	1.0 0
Hr 1	1.3 0	1.5 0	1.4 0	1.4 0	1.3 0	1.3 0	1.1 0	1.1 0	1.0 0	1.0 0
Hr 2	0.9 0	0.9 0	0.9 0	1.2 0	1.2 0	1.0 0	0.9 0	0.9 0	1.0 0	1.4 0
Hr 3	1.6 0	1.8 0	1.7 0	1.7 0	1.8 0	1.9 0	1.9 0	1.9 0	2.1 0	1.9 0
Hr 4	1.6 0	1.4 0	1.4 0	1.3 0	1.1 0	1.1 0	1.1 0	1.1 0	1.0 0	0.9 0
Hr 5	1.0 0	1.1 0	1.3 0	1.2 0	1.2 0	1.1 0	1.0 0	0.9 0	0.9 0	1.0 0
Hr 6	1.0 0	1.0 0	0.9 0	0.8 0	0.8 0	0.8 0	0.9 0	0.9 0	1.0 0	1.1 0

TOTAL NUMBER OF MINUTES ABOVE 20 0
NUMBER OF SIX MINUTE EXCURSIONS: 0

TOTAL NUMBER OF MINUTES ABOVE 30 0
NUMBER OF SIX MINUTE EXCURSIONS: 0

DAILY TEMP SUMMARY REPORT

Dryer #2 TEMP Deg-F FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

DAY'S DATE: 08-23-1994
TIME: 18:04:50

REPORTING PERIOD
DAY: August 23

Period	15		30		45		60		Hr. AVG.	
	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.
Hour 7	311.4	64	311.6	64	313.6	0	310.5	0	312.1	0
Hour 8	312.0	0	311.3	0	308.6	0	310.3	0	310.5	0
Hour 9	312.0	0	316.4	0	315.4	0	311.8	0	313.9	0
Hour 10	310.7	0	301.3	0	307.6	0	306.4	0	306.5	0
Hour 11	302.3	0	306.4	0	313.0	0	312.9	0	308.6	0
Hour 12	312.6	0	315.4	0	314.4	0	317.0	0	314.9	0
Hour 13	322.7	0	320.0	0	317.6	0	320.6	0	320.2	0
Hour 14	319.5	0	317.7	0	317.6	0	320.6	0	318.8	0
Hour 15	317.7	0	317.9	0	316.1	0	316.8	0	317.1	0
Hour 16	319.7	0	319.6	0	321.6	0	323.3	0	321.0	0
Hour 17	323.0	0	324.8	0	323.8	0	322.0	0	323.2	0
Hour 18	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 19	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 20	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 21	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 22	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 23	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 1	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 2	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 3	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 4	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 5	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0
Hour 6	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0

DAILY CO SUMMARY REPORT

Dryer #2 CO ppm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-23-1994
TIME: 18:00:59

REPORTING PERIOD
DAY: August 23

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	280.7 68	-1.0 196	-1.0 0	450.2 0	224.6 0
Hour 8	421.7 0	270.7 0	251.7 0	298.7 0	310.7 0
Hour 9	371.9 0	452.6 0	349.8 0	164.0 0	334.6 0
Hour 10	168.6 0	190.9 0	267.8 0	304.6 0	233.0 0
Hour 11	143.3 0	266.4 0	348.7 0	265.8 0	256.0 0
Hour 12	335.7 0	349.5 0	436.2 0	500.0 0	405.3 0
Hour 13	421.4 0	436.1 0	441.0 0	411.7 0	427.6 0
Hour 14	424.2 0	416.6 0	303.9 0	325.5 0	367.6 0
Hour 15	352.6 0	361.7 0	340.9 0	335.6 0	347.7 0
Hour 16	396.2 0	368.6 0	408.1 0	390.8 0	390.9 0
Hour 17	419.1 0	428.4 0	449.6 0	420.5 0	429.4 0
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

DAILY SUMMARY REPORT
 Dryer #2 HOURLY AVERAGES
 LOUISIANA PACIFIC
 Hayward, WI

REPORTING PERIOD August 23

Period	CO ppm	FLOW kefm	TEMP Deg-F	CO #/HR
7:00 to 8:00	224.6	124.3	312.1	59.9
8:00 to 9:00	310.7	123.9	310.5	82.8
9:00 to 10:00	334.6	124.5	313.9	89.2
10:00 to 11:00	233.0	124.3	306.5	62.7
11:00 to 12:00	256.0	124.5	308.6	68.7
12:00 to 13:00	405.3	125.5	314.9	%108.9
13:00 to 14:00	427.6	125.2	320.2	%113.8
14:00 to 15:00	367.6	125.9	318.8	98.5
15:00 to 16:00	347.7	124.1	317.1	92.1
16:00 to 17:00	390.9	124.5	321.0	%103.3
17:00 to 18:00	429.4	126.0	323.2	%114.5
18:00 to 19:00	388.2	125.5	318.5	%103.8
19:00 to 20:00	416.8	126.3	320.0	%111.9
20:00 to 21:00	383.5	126.9	319.4	%103.5
21:00 to 22:00	422.0	126.2	320.8	%113.1
22:00 to 23:00	324.6	125.2	315.8	86.9
23:00 to 24:00	314.8	124.7	311.7	84.3
24:00 to 1:00	310.4	125.1	312.0	83.4
1:00 to 2:00	385.7	126.9	312.4	%105.0
2:00 to 3:00	422.3	125.3	312.4	%113.6
3:00 to 4:00	360.6	125.5	311.9	97.2
4:00 to 5:00	273.8	125.0	309.1	73.8
5:00 to 6:00	231.8	125.4	306.1	62.9
6:00 to 7:00	308.6	126.9	313.9	83.9

Averages

7:00 to 19:00	343.0	124.9	315.5	91.5
9:00 to 7:00	346.2	125.8	313.8	93.3
2:00 to 7:00	344.6	125.3	314.6	92.4

Bad data not used for averages.

DAILY FLOW SUMMARY REPORT

Dryer #2 FLOW kcfm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-23-1994
TIME: 18:03:18

REPORTING PERIOD
DAY: August 23

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	126.0 64	126.6 64	125.4 0	123.2 0	124.3 0
Hour 8	123.5 0	124.4 0	123.7 0	124.1 0	123.9 0
Hour 9	125.5 0	125.4 0	124.7 0	122.4 0	124.5 0
Hour 10	124.5 0	125.2 0	123.9 0	123.7 0	124.3 0
Hour 11	123.3 0	123.9 0	124.8 0	125.8 0	124.5 0
Hour 12	123.7 0	126.7 0	124.9 0	126.8 0	125.5 0
Hour 13	124.5 0	125.1 0	126.4 0	124.9 0	125.2 0
Hour 14	126.8 0	127.1 0	125.6 0	124.0 0	125.9 0
Hour 15	123.4 0	124.3 0	124.2 0	124.5 0	124.1 0
Hour 16	123.6 0	124.3 0	126.6 0	123.3 0	124.5 0
Hour 17	124.6 0	125.6 0	127.7 0	126.2 0	126.0 0
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

DAILY SUMMARY REPORT
Press #1 HOURLY AVERAGES
LOUISIANA PACIFIC
Hayward, WI

REPORTING PERIOD August 25

Period	CO ppm	FLOW kcfs	TEMP Deg-F	CO #/HR
8:00 to 8:00	13.9	87.7	230.0	3.8
8:00 to 9:00	15.5	87.5	235.1	4.2
9:00 to 10:00	14.4	88.3	237.8	3.9
10:00 to 11:00	14.9	88.5	239.4	4.0
11:00 to 12:00	10.4	87.9	245.3	2.8
12:00 to 13:00	14.6	89.6	246.3	4.0
13:00 to 14:00	14.4	88.9	248.3	3.9
14:00 to 15:00	13.2	88.7	246.9	3.5
15:00 to 16:00	14.4	87.9	247.4	3.8
16:00 to 17:00	15.0	87.4	248.3	4.0
17:00 to 18:00	0.0*	0.0*	0.0*	0.0*
18:00 to 19:00	0.0*	0.0*	0.0*	0.0*
19:00 to 20:00	0.0*	0.0*	0.0*	0.0*
20:00 to 21:00	0.0*	0.0*	0.0*	0.0*
21:00 to 22:00	0.0*	0.0*	0.0*	0.0*
22:00 to 23:00	0.0*	0.0*	0.0*	0.0*
23:00 to 24:00	0.0*	0.0*	0.0*	0.0*
24:00 to 1:00	0.0*	0.0*	0.0	0.0*
1:00 to 2:00	0.0*	0.0*	0.0	0.0*
2:00 to 3:00	0.0*	0.0*	0.0	0.0*
3:00 to 4:00	0.0*	0.0*	0.0	0.0*
4:00 to 5:00	0.0*	0.0*	0.0	0.0*
5:00 to 6:00	0.0*	0.0*	0.0	0.0*
6:00 to 7:00	0.0*	0.0*	0.0	0.0*

Averages

8:00 to 19:00	14.0	88.2	242.5	3.8
19:00 to 7:00	0.0	0.0	0.0	0.0
7:00 to 7:00	14.0	88.2	142.6	4.4

* data not used for averages.

DAILY TEMP SUMMARY REPORT

Press #1 TEMP Deg-F FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-25-1994
TIME: 17:38:54

REPORTING PERIOD
DAY: August 25

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	230.1 0	229.4 0	229.9 0	230.5 0	230.0 0
Hour 8	233.7 0	234.5 0	235.5 0	236.6 0	235.1 0
Hour 9	236.7 0	238.1 0	238.2 0	238.2 0	237.8 0
Hour 10	238.2 0	238.2 0	238.2 0	242.9 0	239.4 0
Hour 11	242.7 0	245.0 0	246.8 0	246.8 0	245.3 0
Hour 12	245.1 0	245.1 0	247.2 0	247.6 0	246.3 0
Hour 13	248.3 0	248.4 0	248.3 0	248.4 0	248.3 0
Hour 14	247.7 0	246.5 0	246.2 0	247.2 0	246.9 0
Hour 15	247.3 0	247.4 0	248.1 0	247.0 0	247.4 0
Hour 16	248.0 0	248.5 0	248.6 0	248.2 0	248.3 0
Hour 17	248.7 0	249.2 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 1	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 2	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 3	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 4	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 5	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 6	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0

DAILY CO SUMMARY REPORT

Press #1 CO ppm FIFTEEN MINUTE AVERAGES

LOUISIANA PACIFIC

Hayward, WI

DATE: 08-25-1994

REPORTING PERIOD

TIME: 17:38:24

DAY: August 25

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	12.2 0	14.5 0	13.8 0	15.2 0	13.9 0
Hour 8	16.3 0	16.1 0	14.7 0	15.0 0	15.5 0
Hour 9	14.6 0	14.5 0	13.1 0	15.3 0	14.4 0
Hour 10	14.9 0	15.0 0	14.4 0	15.2 0	14.9 0
Hour 11	6.9 0	4.3 0	15.2 0	15.0 0	10.4 0
Hour 12	14.5 0	13.8 0	14.4 0	15.5 0	14.6 0
Hour 13	14.5 0	14.0 0	13.9 0	15.1 0	14.4 0
Hour 14	13.8 0	14.4 0	14.6 0	9.9 0	13.2 0
Hour 15	14.5 0	13.9 0	14.7 0	14.5 0	14.4 0
Hour 16	15.2 0	15.1 0	14.4 0	15.1 0	15.0 0
Hour 17	15.6 0	15.1 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 00	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 01	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 02	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 03	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 04	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 05	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 06	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

DAILY FLOW SUMMARY REPORT

Press #1 FLOW kcf# FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 88-25-1994

REPORTING PERIOD

TIME: 17:39:34

DAY: August 25

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 71	87.5 0	86.2 0	88.5 0	88.7 0	87.7 0
Hour 81	87.3 0	87.5 0	87.5 0	87.8 0	87.5 0
Hour 91	88.8 0	88.2 0	87.9 0	88.2 0	88.3 0
Hour 101	89.0 0	87.0 0	89.0 0	88.9 0	88.5 0
Hour 111	87.9 0	87.6 0	87.4 0	88.9 0	87.9 0
Hour 121	88.5 0	89.6 0	90.0 0	90.3 0	89.6 0
Hour 131	90.6 0	87.4 0	88.1 0	89.3 0	88.9 0
Hour 141	88.3 0	89.2 0	89.8 0	87.5 0	88.7 0
Hour 151	87.7 0	87.9 0	88.0 0	87.9 0	87.9 0
Hour 161	87.6 0	87.6 0	87.1 0	87.3 0	87.4 0
Hour 171	87.9 0	87.1 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 181	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 191	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 201	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 211	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 221	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 231	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 01	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 11	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

Sector not found error reading file

REPORT2.TMP

DAILY CO SUMMARY REPORT

Press #2 CO ppm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-26-1994
TIME: 17:37:24

REPORTING PERIOD
DAY: August 26

Period	15		30		45		60		Hr. AVG.	
	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.
Hour 7	5.1	0	10.6	0	10.9	0	10.6	0	9.3	0
Hour 8	9.4	0	10.7	0	10.2	0	6.1	0	9.1	0
Hour 9	10.4	0	11.3	0	12.5	0	13.1	0	11.8	0
Hour 10	11.6	128	-1.0	128	11.6	0	11.4	0	11.5	0
Hour 11	11.8	0	11.0	0	11.1	0	11.8	0	11.4	0
Hour 12	12.1	0	11.2	0	11.0	0	12.3	0	11.7	0
Hour 13	11.5	0	11.0	0	11.4	0	11.2	0	11.3	0
Hour 14	11.1	0	11.8	0	11.0	0	11.5	0	11.4	0
Hour 15	11.1	0	11.6	0	11.9	0	11.5	0	11.5	0
Hour 16	11.2	0	11.0	0	11.1	0	10.3	0	10.9	0
Hour 17	11.1	0	11.1	0	-1.0	-1	-1.0	-1	-1.0	-1
Hour 18	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 19	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 20	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 21	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 22	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 23	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 0	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 2	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 3	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 4	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 5	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1
Hour 6	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1	-1.0	-1

DAILY CO SUMMARY REPORT

Press #2 CO ppm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994
TIME: 11:17:15

REPORTING PERIOD
DAY: August 26

Period	15		30		45		60		Hr. AVG.	
	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.
Hour 7	5.1	0	10.6	0	10.9	0	10.6	0	9.3	0
Hour 8	9.4	0	10.7	0	10.2	0	6.1	0	9.1	0
Hour 9	10.4	0	11.3	0	12.5	0	13.1	0	11.8	0
Hour 10	11.6	128	-1.0	128	11.6	0	11.4	0	11.5	0
Hour 11	11.8	0	11.0	0	11.1	0	11.8	0	11.4	0
Hour 12	12.1	0	11.2	0	11.0	0	12.3	0	11.7	0
Hour 13	11.5	0	11.0	0	11.4	0	11.2	0	11.3	0
Hour 14	11.1	0	11.8	0	11.0	0	11.5	0	11.4	0
Hour 15	11.1	0	11.6	0	11.9	0	11.5	0	11.5	0
Hour 16	11.2	0	11.0	0	11.1	0	10.3	0	10.9	0
Hour 17	11.1	0	11.1	0	11.4	0	11.0	0	11.2	0
Hour 18	11.0	0	10.2	0	9.9	0	9.6	0	10.2	0
Hour 19	6.3	0	4.3	0	9.1	0	8.0	0	6.9	0
Hour 20	9.6	0	10.2	0	10.7	0	11.7	0	10.6	0
Hour 21	10.9	0	8.2	0	10.4	0	10.6	0	10.0	0
Hour 22	10.3	0	11.1	0	10.8	0	11.3	0	10.9	0
Hour 23	11.5	0	12.2	0	12.1	0	11.4	0	11.8	0
Hour 0	12.5	0	12.2	0	12.3	0	11.8	0	12.2	0
Hour 1	11.6	0	12.6	0	12.2	0	12.6	0	12.2	0
Hour 2	12.1	0	12.4	0	12.7	0	12.7	0	12.5	0
Hour 3	12.5	0	12.2	0	12.9	0	12.8	0	12.6	0
Hour 4	12.2	0	11.9	0	12.3	0	12.1	0	12.1	0
Hour 5	13.0	0	12.8	0	11.9	0	13.2	0	12.7	0
Hour 6	11.9	0	11.5	0	11.6	0	11.8	0	11.7	0

DAILY FLOW SUMMARY REPORT

Press #2 FLOW kcfm FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-26-1994
TIME: 17:38:25

REPORTING PERIOD
DAY: August 26

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	96.4 0	96.7 0	90.7 0	95.7 0	94.9 0
Hour 8	99.3 0	97.3 0	97.6 0	96.5 0	97.7 0
Hour 9	97.4 0	99.4 0	97.2 0	97.9 0	98.0 0
Hour 10	97.8 0	99.0 0	100.6 0	102.5 0	100.0 0
Hour 11	96.4 0	97.4 0	96.9 0	101.4 0	98.0 0
Hour 12	102.2 0	94.5 0	96.0 0	95.8 0	97.1 0
Hour 13	97.3 0	100.5 0	99.6 0	101.6 0	99.8 0
Hour 14	101.3 0	101.3 0	101.1 0	100.4 0	101.0 0
Hour 15	100.5 0	100.2 0	98.9 0	101.8 0	100.4 0
Hour 16	102.3 0	102.1 0	100.5 0	97.5 0	100.6 0
Hour 17	98.3 0	97.7 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 2	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 3	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 4	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 5	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 6	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1

DAILY FLOW SUMMARY REPORT

Press #2 FLOW kcf FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994

TIME: 11:17:49

REPORTING PERIOD

DAY: August 26

Period	15		30		45		60		Hr. AVG.	
	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.	Read.	Stat.
Hour 7	96.4	0	96.7	0	98.7	0	95.7	0	94.9	0
Hour 8	99.3	0	97.3	0	97.6	0	96.5	0	97.7	0
Hour 9	97.4	0	99.4	0	97.2	0	97.9	0	98.0	0
Hour 10	97.8	0	99.0	0	100.6	0	102.5	0	100.0	0
Hour 11	96.4	0	97.4	0	96.9	0	101.4	0	98.0	0
Hour 12	102.2	0	94.5	0	96.0	0	95.8	0	97.1	0
Hour 13	97.3	0	100.5	0	99.6	0	101.6	0	99.8	0
Hour 14	101.3	0	101.3	0	101.1	0	100.4	0	101.0	0
Hour 15	100.5	0	100.2	0	98.9	0	101.8	0	100.4	0
Hour 16	102.3	0	102.1	0	100.5	0	97.5	0	100.6	0
Hour 17	98.3	0	97.7	0	100.9	0	100.3	0	99.3	0
Hour 18	95.5	0	93.3	0	94.7	0	96.9	0	95.1	0
Hour 19	96.2	0	96.1	0	100.7	0	100.2	0	98.3	0
Hour 20	100.4	0	100.4	0	98.9	0	93.8	0	98.4	0
Hour 21	97.6	0	97.7	0	97.7	0	101.5	0	98.6	0
Hour 22	101.4	0	98.3	0	99.6	0	98.9	0	99.5	0
Hour 23	97.3	0	97.2	0	95.0	0	93.8	0	95.8	0
Hour 0	95.2	0	94.6	0	93.1	0	96.5	0	94.9	0
Hour 1	97.7	0	96.0	0	100.6	0	97.7	0	98.0	0
Hour 2	94.2	0	100.8	0	101.1	0	101.2	0	99.3	0
Hour 3	98.8	0	97.9	0	99.0	0	101.6	0	99.3	0
Hour 4	101.1	0	97.8	0	93.7	0	93.4	0	96.5	0
Hour 5	99.5	0	96.2	0	94.2	0	94.8	0	96.2	0
Hour 6	98.2	0	101.3	0	102.5	0	102.7	0	101.2	0

DAILY TEMP SUMMARY REPORT

Press #2 TEMP Deg-F FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 08-26-1994
TIME: 17:39:22

REPORTING PERIOD
DAY: August 26

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	174.2 0	173.5 0	178.3 0	175.7 0	175.4 0
Hour 8	174.4 0	176.2 0	177.3 0	178.2 0	176.5 0
Hour 9	176.4 0	176.9 0	178.0 0	178.9 0	177.6 0
Hour 10	175.3 0	179.1 0	187.6 0	199.1 0	185.3 0
Hour 11	208.0 0	208.7 0	208.4 0	207.8 0	208.3 0
Hour 12	207.0 0	209.9 0	210.6 0	210.9 0	209.6 0
Hour 13	210.7 0	208.0 0	209.7 0	210.4 0	209.7 0
Hour 14	211.1 0	209.0 0	208.9 0	209.1 0	209.5 0
Hour 15	211.1 0	210.8 0	212.1 0	210.6 0	211.1 0
Hour 16	211.3 0	211.9 0	212.9 0	212.9 0	212.2 0
Hour 17	213.0 0	213.9 0	-1.0 -1	-1.0 -1	-1.0 -1
Hour 18	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 19	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 20	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 21	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 22	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 23	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1	-1.0 -1
Hour 0	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 1	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 2	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 3	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 4	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 5	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0
Hour 6	0.0 0	0.0 0	0.0 0	0.0 0	0.0 0

DAILY TEMP SUMMARY REPORT

Press #2 TEMP Deg-F FIFTEEN MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994
TIME: 11:18:16

REPORTING PERIOD
DAY: August 26

Period	15	30	45	60	Hr. AVG.
	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.	Read. Stat.
Hour 7	174.2 0	173.5 0	178.3 0	175.7 0	175.4 0
Hour 8	174.4 0	176.2 0	177.3 0	178.2 0	176.5 0
Hour 9	176.4 0	176.9 0	178.0 0	178.9 0	177.6 0
Hour 10	175.3 0	179.1 0	187.6 0	199.1 0	185.3 0
Hour 11	208.0 0	208.7 0	208.4 0	207.8 0	208.3 0
Hour 12	207.0 0	209.9 0	210.6 0	210.9 0	209.6 0
Hour 13	210.7 0	208.0 0	209.7 0	210.4 0	209.7 0
Hour 14	211.1 0	209.0 0	208.9 0	209.1 0	209.5 0
Hour 15	211.1 0	210.8 0	212.1 0	210.6 0	211.1 0
Hour 16	211.3 0	211.9 0	212.9 0	212.9 0	212.2 0
Hour 17	213.0 0	213.9 0	212.6 0	212.1 0	212.9 0
Hour 18	213.7 0	214.5 0	214.1 0	212.7 0	213.8 0
Hour 19	213.8 0	213.9 0	212.9 0	209.7 0	212.6 0
Hour 20	209.7 0	209.4 0	209.8 0	208.4 0	209.3 0
Hour 21	208.0 0	208.0 0	207.7 0	204.7 0	207.1 0
Hour 22	205.0 0	205.3 0	204.5 0	204.7 0	204.9 0
Hour 23	205.4 0	205.6 0	204.7 0	205.4 0	205.3 0
Hour 0	203.9 0	203.4 0	202.0 0	201.8 0	202.8 0
Hour 1	201.8 0	201.9 0	200.7 0	201.4 0	201.5 0
Hour 2	202.3 0	200.1 0	199.8 0	199.5 0	200.4 0
Hour 3	199.5 0	199.5 0	200.2 0	198.1 0	199.3 0
Hour 4	198.7 0	198.9 0	199.0 0	199.2 0	198.9 0
Hour 5	199.0 0	199.4 0	199.8 0	201.3 0	199.9 0
Hour 6	200.0 0	198.6 0	199.6 0	199.6 0	199.5 0

DAILY OPAC SUMMARY REPORT

Press #2 OPAC pct SIX MINUTE AVERAGES
LOUISIANA PACIFIC
Hayward, WI

TODAY'S DATE: 09-19-1994
TIME: 11:18:32

REPORTING PERIOD
DAY: August 26

Period	6	12	18	24	30	36	42	48	54	60
Hr 7	2.2 0	2.2 0	2.1 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.1 0	2.1 0
Hr 8	2.1 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.3 0
Hr 9	2.3 0	2.3 0	2.2 0	2.2 0	2.2 0	2.3 0	2.3 0	2.3 0	2.3 0	2.2 0
Hr 10	2.3 0	2.2 0	2.3 0	2.2 0	2.2 0	2.4 0	2.2 0	2.3 0	2.3 0	2.3 0
Hr 11	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0
Hr 12	2.3 0	2.3 0	2.4 0	2.3 0	2.3 0	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0
Hr 13	2.4 0	2.4 0	2.3 0	2.4 0	2.4 0	2.4 0	2.4 0	2.5 0	2.4 0	2.3 0
Hr 14	2.4 0	2.4 0	2.4 0	2.5 0	2.5 0	2.4 0	2.4 0	2.5 0	2.5 0	2.5 0
Hr 15	2.5 0	2.5 0	2.5 0	2.5 0	2.5 0	2.5 0	2.6 0	2.5 0	2.6 0	2.5 0
Hr 16	2.6 0	2.5 0	2.6 0	2.6 0	2.5 0	2.5 0	2.5 0	2.5 0	2.5 0	2.5 0
Hr 17	2.6 0	2.6 0	2.6 0	2.5 0	2.5 0	2.5 0	2.5 0	2.4 0	2.5 0	2.4 0
Hr 18	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0	2.4 0
Hr 19	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.2 0	2.2 0	2.1 0
Hr 20	2.2 0	2.2 0	2.2 0	2.2 0	2.3 0	2.2 0	2.2 0	2.2 0	2.2 0	2.0 0
Hr 21	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.3 0	2.3 0
Hr 22	2.3 0	2.2 0	2.2 0	2.2 0	2.2 0	2.3 0	2.3 0	2.2 0	2.2 0	2.2 0
Hr 23	2.2 0	2.2 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0
Hr 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.4 0	2.3 0	2.3 0
Hr 1	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.2 0
Hr 2	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.1 0	2.2 0	2.2 0
Hr 3	2.2 0	2.1 0	2.1 0	2.2 0	2.2 0	2.2 0	2.2 0	2.1 0	2.2 0	2.2 0
Hr 4	2.2 0	2.2 0	2.2 0	2.2 0	2.1 0	2.2 0	2.2 0	2.2 0	2.3 0	2.3 0
Hr 5	2.2 0	2.2 0	2.2 0	2.2 0	2.2 0	2.1 0	2.2 0	2.2 0	2.2 0	2.3 0
Hr 6	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0	2.3 0

TOTAL NUMBER OF MINUTES ABOVE 20 0

NUMBER OF SIX MINUTE EXCURSIONS: 0

TOTAL NUMBER OF MINUTES ABOVE 30 0

NUMBER OF SIX MINUTE EXCURSIONS: 0

DAILY SUMMARY REPORT
Press #2 HOURLY AVERAGES
LOUISIANA PACIFIC
Hayward, WI

REPORTING PERIOD August 26

Period	CO ppm	FLOW kcfm	TEMP Deg-F	CO #/HR
7:00 to 8:00	9.3	94.9	175.4	3.0
8:00 to 9:00	9.1	97.7	176.5	3.0
9:00 to 10:00	11.8	98.0	177.6	3.9
10:00 to 11:00	11.5	100.0	185.3	3.8
11:00 to 12:00	11.4	98.0	208.3	3.6
12:00 to 13:00	11.7	97.1	209.6	3.6
13:00 to 14:00	11.3	99.8	209.7	3.6
14:00 to 15:00	11.4	101.0	209.5	3.7
15:00 to 16:00	11.5	100.4	211.1	3.7
16:00 to 17:00	10.9	100.6	212.2	3.5
17:00 to 18:00	11.2	99.3	212.9	3.5
18:00 to 19:00	10.2	95.1	213.8	3.1
19:00 to 20:00	6.9	98.3	212.6	2.2
20:00 to 21:00	10.6	98.4	209.3	3.3
21:00 to 22:00	10.0	98.6	207.1	3.2
22:00 to 23:00	10.9	99.5	204.9	3.5
23:00 to 24:00	11.8	95.8	205.3	3.6
0:00 to 1:00	12.2	94.9	202.8	3.7
1:00 to 2:00	12.2	98.0	201.5	3.9
2:00 to 3:00	12.5	99.3	200.4	4.0
3:00 to 4:00	12.6	99.3	199.3	4.1
4:00 to 5:00	12.1	96.5	198.9	3.8
5:00 to 6:00	12.7	96.2	199.9	4.0
6:00 to 7:00	11.7	101.2	199.5	3.8

Averages

7:00 to 19:00	10.9	98.5	200.2	3.5
19:00 to 7:00	11.4	98.0	203.5	3.6
7:00 to 7:00	11.1	98.2	201.0	3.5

* Bad data not used for averages.

7-20-94
R. Schultz

LINE #2 PRESS

RUN #11 16:17 thru 16:47 8-26-94

15 min avg.

16:30	11.0 ppm CO	16:45	11.1 ppm CO
	102.1 kcfm		100.5 kcfm
	211.9 °F		212.9 °F

$$\#CO/HR = \frac{CO_{ppm} \times FLOW \times 2.14424}{(460 + temp)}$$

(dry)

$$16:30 \frac{(11.0)(102.1)(2.14424)}{(460 + 211.9)} = 3.5842 \#CO/HR$$

$$16:45 = \frac{(11.1)(100.5)(2.14424)}{(460 + 212.9)} = 3.5548 \#CO/HR$$

$$AVG RUN \#11 = (3.5842 + 3.5548) / 2 = 7.139 / 2 = 3.5695 \#CO/HR$$

RUN #12 17:02 thru 17:32 8-26-94

15 min avg.

17:15	11.1 ppm CO	17:30	11.1 ppm CO
	98.3 kcfm		97.7 kcfm
	213.0 °F		213.9 °F

$$\#CO/HR = \frac{CO_{ppm} \times FLOW \times 2.14424}{(460 + temp)}$$

(dry)

$$17:15 \rightarrow \frac{(11.1)(98.3)(2.14424)}{(460 + 213)} = 3.4764 \#CO/HR$$

$$17:30 \rightarrow \frac{(11.1)(97.7)(2.14424)}{(460 + 213.9)} = 3.4506 \#CO/HR$$

$$AVG RUN \#12 = (3.4764 + 3.4506) / 2 = 6.927 / 2 = 3.4635 \#CO/HR$$

08/29/94, Rev.
R. Schmitz

Louisiana-Pacific Corporation
Hayward, WI

CEMS Computer program to calculate CO LB/HR (dry)

$$\text{CO LB/HR} = \text{RD!} * \text{lbcf!} * \text{MW!} * \text{FF!} * 1000 * \text{Temp!} * \text{Pcmp!} * \text{Mcmp!} * 60$$

(dry)

Where:

Pb! = 14.08, Local Barometric pressure based on altitude

lbcf! = $2.6E-9$, Conversion factor for ppm to lbcf without CO molecular weight

Temp! = $(460 + 68) / (460 + \text{FT!})$

Pcmp! = $\text{Pb!} / 14.696$

Mcmp! = $(100 - \text{Moisture!}) / 100$

MW! = 28.01, Molecular weight for CO

Moisture! = 25 for Dryers and 3 for Presses

RD! = CO reading

FF! = Flow reading

FT! = Temperature reading

Therefore, to calculate CO LB/HR (dry) from the 15 minute averages of CO ppm; flow & temperature, substitute those values into this equation:

$$\text{DRYER CO LB/HR (dry)} = \frac{\text{CO ppm} \times \text{Flow} \times 1.65792}{(460 + \text{Temperature})}$$

$$\text{PRESS CO LB/HR (dry)} = \frac{\text{CO ppm} \times \text{Flow} \times 2.14424}{(460 + \text{Temperature})}$$

* Constant based on 25% moisture content for dryer RTO's and 3% for press RTO's.

APPENDIX I

OPERATING DATA

LINE I	8/94	CONT.	19/32"H FTG	19/32"SE LBS	23/32"SE LBS	23/32"H FTG	23/32"H LBS	TOTAL DAILY LBS
38.5	19/32"SE FTG	39.3	0	0	0	418.055	499,053	736,747
			0	0	0		0	789,959
			0	0	0	47.105	56,232	907,598
			0	0	0		0	866,941
			0	0	0		0	908,046
			0	0	0		0	884,890
			0	0	0		0	819,433
			0	0	0		0	824,270
			0	0	0		0	848,604
			0	0	0		0	949,573
			0	0	0		0	565,529
			0	0	0		0	846,466
			0	0	0		0	874,028
			0	0	0		0	809,090
			0	0	0		0	839,568
			0	0	0		0	851,734
			0	0	0		0	932,405
			0	0	0		0	890,343
			0	0	0		0	856,136
			0	0	0		0	902,354
			0	0	0		0	897,793
			0	0	0		0	777,876
			0	0	0		0	798,914
			0	0	0		0	869,626
			0	0	0		0	829,725
226.171	272,112		0	0	0		0	856,136
			0	0	0		0	944,591
			0	0	0		0	927,969
			0	0	0		0	0
			0	0	0		0	0
			0	0	0		0	0
			0	0	0		0	0
			0	0	0		0	0
			0	0	0		0	0
			0	0	0		0	0
			0	0	0		0	0
226.171	272,112	0.000	0	0.000	0	465.160	555,285	23,806,343

LOUISIANA PACIFIC HAYWARD

FISCAL

FACTOR

DATE

DAILY TONNAGE

LINE II

8/94

DATE	FACTOR	1 1/4" LBS	3 3/8" FTG	3 3/8" LBS	7 1/16" FTG	7 1/16" LBS	15 3/32" FTG	15 3/32" LBS	39 1/2" FTG	1 1/2" LBS
7/31	43.7	0	0	0	202.502	247,432	309.120	388,332	155.644	194,069
8/1	1 1/4"	0	0	0	0	0	312.960	393,156	0	0
8/2	25.601	34,961	0	0	0	0	0	0	0	0
8/3	0	0	35.328	42,614	154.116	188,310	0	0	0	0
8/4	0	0	0	0	0	0	368.640	463,104	0	0
8/5	0	0	0	0	0	0	0	0	0	0
8/6	0	0	0	0	0	0	0	0	0	0
8/7	5.120	6,992	0	0	0	0	0	0	321.528	400,905
8/8	0	0	0	0	0	0	0	0	325.624	406,012
8/9	0	0	0	0	0	0	0	0	30.719	38,303
8/10	0	0	0	0	0	0	0	0	0	0
8/11	22.529	30,766	0	0	0	0	0	0	215.035	268,122
8/12	0	0	0	0	0	0	0	0	0	0
8/13	0	0	75.264	90,787	0	0	0	0	317.432	395,798
8/14	0	0	0	0	0	0	0	0	335.864	418,780
8/15	0	0	0	0	0	0	0	0	344.055	428,994
8/16	0	0	0	0	0	0	0	0	356.343	444,315
8/17	27.649	37,758	70.656	85,229	256.263	313,121	0	0	18.432	22,982
8/18	0	0	35.328	42,614	322.569	394,139	0	0	0	0
8/19	0	0	0	0	0	0	0	0	0	0
8/20	0	0	0	0	374.539	467,640	0	0	0	0
8/21	0	0	27.648	33,350	0	0	0	0	0	0
8/22	0	0	0	0	0	0	0	0	317.432	395,798
8/23	33.794	46,150	0	0	0	0	332.160	417,276	24.575	30,642
8/24	0	0	0	0	0	0	0	0	516.083	643,491
8/25	0	0	0	0	0	0	0	0	352.247	439,208
8/26	0	0	86.016	103,757	197.126	240,863	328.320	412,452	286.713	357,495
8/27	0	0	0	0	0	0	0	0	0	0
TOTALS=	114.693	156628	330.240	398352	1507.115	1841506	1651.200	2074320	3917.726	4884915

1

२५

२५

6127867854; # 5

DAILY PRODUCTION REPORT
FISCAL

DATE: 8/23/94 ENV. DLS

7AM-7PM

	LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4		0	0	0
3/8	46	2208	70656	70656
7/16	137	6576	210432	245511
15/32		0	0	0
1/2		0	0	0
19/32SE		0	0	0
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL			316167	

7PM-7AM

	LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4		0	0	0
3/8		0	0	0
7/16	218	10464	334848	390667
15/32		0	0	0
1/2		0	0	0
19/32SE		0	0	0
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL			390667	

LINE I TOTALS

	LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0	0
3/8	46	2208	70656	70656
7/16	355	17040	545280	636178
15/32	0	0	0	0
1/2	0	0	0	0
19/32SE	0	0	0	0
19/32H	0	0	0	0
23/32SE	0	0	0	0
23/32H	0	0	0	0
TOTALS	19248	615936	706834	706834
LINE I TOTAL =			706834	

DAILY PLANT TOTAL= 1384387

7AM-7PM TOTAL=

651782

7PM-7AM TOTAL=

732804

7AM-7PM

	LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4		0	0	0
3/8		0	0	0
7/16		0	0	0
15/32	162	7776	248832	311040
1/2	12	576	18432	24575
19/32SE		0	0	0
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL			335615	

7PM-7AM

	LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4		0	0	0
3/8		0	0	0
7/16		0	0	0
15/32	11	528	16896	21120
1/2		0	0	0
19/32SE	87	4176	133632	211580
19/32H	45	2160	69120	109438
23/32SE		0	0	0
23/32H		0	0	0
TOTAL			342137	

LINE II TOTALS

	LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0	0
3/8	0	0	0	0
7/16	0	0	0	0
15/32	173	8304	265728	332160
1/2	12	576	18432	24575
19/32SE	87	4176	133632	211580
19/32H	45	2160	69120	109438
23/32SE	0	0	0	0
23/32H	0	0	0	0
TOTALS	15216	486912	677753	677753
LINE II TOTAL=			677753	

LINE I MTD TOTALS

	MTD	MTD %	WTD #1	WTD #2	WTD #3	WTD #4	WTD #5	MTD TOTAL
1/4	129030	0.8	4784423					
3/8	273408	1.7	4627425					
7/16	10311463	62.9	4988236					
15/32	3144960	19.2	1984175					
1/2	2060236	12.6	0					
19/32SE	0	0.0	16384258					
19/32H	0	0.0						
23/32SE	0	0.0						
23/32H	465160	2.8						
PLANT WTD			9396543	9549427	9703652	4004644	0	

PLANT MTD 32654266

LINE II MTD TOTALS

	MTD	MTD %	WTD #1	WTD #2	WTD #3	WTD #4	WTD #5	MTD TOTAL
1/4	80900	0.5	4612121					
3/8	244224	1.5	4922002					
7/16	1309989	8.1	4715416					
15/32	1322880	8.1	2020470					
1/2	2762685	17.0	0					
19/32SE	2113364	13.0						
19/32H	469366	2.9						
23/32SE	306181	1.9						
23/32H	7660421	47.1						
MTD %								

1/4	0.6
3/8	1.6
7/16	35.6
15/32	13.7
1/2	14.8
19/32SE	6.5
19/32H	1.4
23/32SE	0.9
23/32H	24.9

DAILY PRODUCTION REPORT

DATE:

8/24/94 ENV.

DLS

FISCAL

7AM-7PM

	LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4		0	0	0
3/8		0	0	0
7/16	191	9168	293376	342282
15/32		0	0	0
1/2		0	0	0
19/32SE		0	0	0
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL				342282

7PM-7AM

	LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4		0	0	0
3/8		0	0	0
7/16	186	8928	285696	333322
15/32		0	0	0
1/2		0	0	0
19/32SE		0	0	0
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL				333322

LINE I TOTALS

	LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0	0
3/8	0	0	0	0
7/16	377	18096	579072	675603
15/32	0	0	0	0
1/2	0	0	0	0
19/32SE	0	0	0	0
19/32H	0	0	0	0
23/32SE	0	0	0	0
23/32H	0	0	0	0
TOTALS=		18096	579072	675603
LINE I TOTAL =				675603

DAILY PLANT TOTAL= 1240072

7AM-7PM TOTAL=

609796

7PM-7AM TOTAL=

630274

7AM-7PM

	LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4		33	1584	50688
3/8		0	0	0
7/16		0	0	0
15/32		0	0	0
1/2	107	5136	164352	219131
19/32SE	6	288	9216	14592
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL				267516

7PM-7AM

	LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4		0	0	0
3/8		0	0	0
7/16		0	0	0
15/32		0	0	0
1/2	145	6960	222720	296953
19/32SE		0	0	0
19/32H		0	0	0
23/32SE		0	0	0
23/32H		0	0	0
TOTAL				296953

LINE II TOTALS

	LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	33	1584	50688	33794
3/8	0	0	0	0
7/16	0	0	0	0
15/32	0	0	0	0
1/2	252	12096	387072	516083
19/32SE	6	288	9216	14592
19/32H	0	0	0	0
23/32SE	0	0	0	0
23/32H	0	0	0	0
TOTALS=		13968	446976	564468
LINE II TOTAL=				564468

LINE I MTD TOTALS

	MTD	MTD
1/4	129030	0.8
3/8	273408	1.6
7/16	10987066	64.4
15/32	3144960	18.4
1/2	2060236	12.1
19/32SE	0	0.0
19/32H	0	0.0
23/32SE	0	0.0
23/32H	445160	2.7

PLANT MTD 33894338

WTD #1	WTD #2	WTD #3	WTD #4	WTD #5	MTD TOTAL
4784423	4627425	4988236	2659778	0	17059861

PLANT MTD

WTD #1	WTD #2	WTD #3	WTD #4	WTD #5
9394543	9549427	9703652	5244716	0

LINE II MTD TOTALS

	MTD	MTD
1/4	114694	0.7
3/8	244224	1.5
7/16	1309989	7.8
15/32	1322880	7.9
1/2	3278766	19.5
19/32SE	2127955	12.6
19/32H	469366	2.8
23/32SE	306181	1.8
23/32H	7660421	45.5

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

MTD

DAILY PRODUCTION REPORT

DATE:

8/25/94 ENV.

DLS

FISCAL

7AM-7PM

LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	189	290304	338698
15/32	0	0	0
1/2	0	0	0
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTAL			338698

7PM-7AM

LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	200	307200	358410
15/32	0	0	0
1/2	0	0	0
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTAL			358410

LINE I TOTALS

LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	389	597504	697108
15/32	0	0	0
1/2	0	0	0
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTALS=	18672	597504	697108
LINE I TOTAL =			697108

DAILY PLANT TOTAL= 1382033

7AM-7PM

LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	0	0	0
15/32	0	0	0
1/2	20	30720	40959
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	15	23040	44161
23/32H	93	142848	273797
TOTAL			358917

7PM-7AM

LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	0	0	0
15/32	0	0	0
1/2	152	233472	311288
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	5	7680	14720
TOTAL			326008

LINE II TOTALS

LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	0	0	0
15/32	0	0	0
1/2	172	8256	332267
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	15	23040	44161
23/32H	98	13680	288517
TOTALS=	4704	150528	684925
LINE II TOTAL=			684925

7AM-7PM TOTAL=

697614

7PM-7AM TOTAL=

684419

LINE I MTD TOTALS

MTD	MTD
1/4	129030
3/8	273408
7/16	11684174
15/32	3144960
1/2	2060236
19/32SE	0
19/32H	0
23/32SE	0
23/32H	465160

PLANT MTD 35276371

WTD #1	WTD #2	WTD #3	WTD #4	WTD #5
4784423	4627425	4988236	3356886	0
MTD TOTAL	17756969			

PLANT WTD	WTD #1	WTD #2	WTD #3	WTD #4	WTD #5
9396543	9549427	9703652	6626749	0	

LINE II MTD TOTALS

MTD	MTD
1/4	114694
3/8	244224
7/16	1309989
15/32	1322880
1/2	3431013
19/32SE	2127955
19/32H	469366
23/32SE	350342
23/32H	7948938

MTD=

WTD #1	WTD #2	WTD #3	WTD #4	WTD #5
4612121	4922002	4715416	3269863	0
MTD TOTAL	17519402			

MTD	MTD
1/4	0.7
3/8	1.5
7/16	16.8
15/32	12.7
1/2	16.1
19/32SE	6.0
19/32H	1.3
23/32SE	1.0
23/32H	23.9

DAILY PRODUCTION REPORT
FISCAL

DATE:

8/26/94 ENV.

DLS

7AM-7PM

LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	15	23040	26881
15/32	183	8784	281088
1/2	0	0	0
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTAL			378241

7PM-7AM

LOADS	#PANELS	LINE I SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	207	9936	317952
15/32	7	336	10752
1/2	0	0	0
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTAL			384395

LINE I TOTALS

LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	222	10656	340992
15/32	190	9120	291840
1/2	0	0	0
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTALS=			
	19776	632832	762635
LINE I TOTAL =			762635

DAILY PLANT TOTAL= 1423881

7AM-7PM TOTAL=

7PM-7AM TOTAL=

695675

728206

7AM-7PM

LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4	0	0	0
3/8	56	2688	86016
7/16	0	0	0
15/32	0	0	0
1/2	113	5624	173568
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	0	0	0
TOTAL			317434

7PM-7AM

LOADS	#PANELS	LINE II SUR FTG	3/8 FTG
1/4	0	0	0
3/8	0	0	0
7/16	0	0	0
15/32	0	0	0
1/2	27	1296	41472
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	98	4704	150528
TOTAL			288517

LINE II TOTALS

LOADS	#PANELS	SUR FTG	3/8 FTG
1/4	0	0	0
3/8	56	2688	86016
7/16	0	0	0
15/32	0	0	0
1/2	140	6720	215040
19/32SE	0	0	0
19/32H	0	0	0
23/32SE	0	0	0
23/32H	98	4704	150528
TOTALS=			
	16112	451584	288517
LINE II TOTAL=			661246

LINE I MTD TOTALS	MTD%
1/4	129030
3/8	273408
7/16	12082009
15/32	3509760
1/2	2060236
19/32SE	0
19/32H	0
23/32SE	0
23/32H	465160

PLANT MTD 36700252

WTD #1	WTD #2	WTD #3	WTD #4	WTD #5	WTD TOTAL
4784425	4627425	4988236	4119521	0	18519604
9396543	9549427	9703652	8050630	0	

LINE II MTD TOTALS	MTD%
1/4	114696
3/8	330240
7/16	1309989
15/32	1322880
1/2	3917726
19/32SE	2127955
19/32H	469366
23/32SE	350342
23/32H	8237455

MTD%=

WTD #1	WTD #2	WTD #3	WTD #4	WTD #5	WTD TOTAL
4612121	4922002	4715416	3931109	0	18180648
0.7	1.6	36.5	13.2	16.3	
19/32SE	5.8	1.3	1.0	23.7	

APPENDIX J

PROCEDURES

Accuracy—The degree of agreement between a measured value and the true value; usually expressed as $\pm$ percent of full scale.

Time to 90 percent response—The time interval from a step change in the input concentration at the instrument inlet to a reading of 90 percent of the ultimate recorded concentration.

Rise Time (90 percent)—The interval between initial response time and time to 90 percent response after a step increase in the inlet concentration.

Fall Time (90 percent)—The interval between initial response time and time to 90 percent response after a step decrease in the inlet concentration.

Zero Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is zero; usually expressed as percent full scale.

Span Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is a stated upscale value; usually expressed as percent full scale.

Precision—The degree of agreement between repeated measurements of the same concentration, expressed as the average deviation of the single results from the mean.

Noise—Spontaneous deviations from a mean output not caused by input concentration changes.

Linearity—The maximum deviation between an actual instrument reading and the reading predicted by a straight line drawn between upper and lower calibration points.

METHOD 10A—DETERMINATION OF CARBON MONOXIDE EMISSIONS IN CERTIFYING CONTINUOUS EMISSION MONITORING SYSTEMS AT PETROLEUM REFINERIES

1. Applicability and Principle

1.1 Applicability. This method applies to the measurement of carbon monoxide (CO) at petroleum refineries. This method serves as the reference method in the relative accuracy test for nondispersive infrared (NDIR) CO continuous emission monitoring systems (CEMS's) that are required to be in-

stalled in petroleum refineries on fluid catalytic cracking unit catalyst regenerators [40 CFR Part 60.105(a)(2)].

1.2 Principle. An integrated gas sample is extracted from the stack, passed through an alkaline permanganate solution to remove sulfur and nitrogen oxides, and collected in a Tedlar bag. The CO concentration in the sample is measured spectrophotometrically using the reaction of CO with p-sulfamino-benzoic acid.

1.3 Range and Sensitivity.

1.3.1 Range. Approximately 3 to 1800 ppm CO. Samples having concentrations below 400 ppm are analyzed at 425 nm, and samples having concentrations above 400 ppm are analyzed at 600 nm.

1.3.2 Sensitivity. The detection limit is 3 ppm based on three times the standard deviation of the mean reagent blank values.

1.4 Interferences. Sulfur oxides, nitric oxide, and other acid gases interfere with the colorimetric reaction. They are removed by passing the sampled gas through an alkaline potassium permanganate scrubbing solution. Carbon dioxide (CO₂) does not interfere, but, because it is removed by the scrubbing solution, its concentration must be measured independently and an appropriate volume correction made to the sampled gas.

1.5 Precision, Accuracy, and Stability.

1.5.1 Precision. The estimated intralaboratory standard deviation of the method is 3 percent of the mean for gas samples analyzed in duplicate in the concentration range of 39 to 412 ppm. The interlaboratory precision has not been established.

1.5.2 Accuracy. The method contains no significant biases when compared to an NDIR analyzer calibrated with National Bureau of Standards (NBS) standards.

1.5.3 Stability. The individual components of the colorimetric reagent are stable for at least 1 month. The colorimetric reagent must be used within 2 days after preparation to avoid excessive blank correction. The samples in the Tedlar¹ bag should be stable for at least 1 week if the bags are leak-free.

2. Apparatus

2.1 Sampling. The sampling train is shown in Figure 10A-1, and component parts are discussed below:

¹ Mention of trade names or commercial products in this publication does not consti-

tute the endorsement or recommendation for use by the Environmental Protection Agency.




Figure 10A-1. Sampling train.

2.1.1 Probe. Stainless steel, sheathed Pyrex glass, or equivalent, equipped with a glass wool plug to remove particulate matter.

2.1.2 Sample Conditioning System. Three Greenburg-Smith impingers connected in series with leak-free connections.

2.1.3 Pump. Leak-free pump with stainless steel and Teflon parts to transport sample at a flow rate of 300 ml/min to the flexible bag.

2.1.4 Surge Tank. Installed between the pump and the rate meter to eliminate the pulsation effect of the pump on the rate meter.

2.1.5 *Rate Meter.* Rotameter, or equivalent, to measure flow rate at 300 ml/min. Calibrate according to Section 5.2.

2.1.6 *Flexible Bag.* Tedlar, or equivalent, with a capacity of 10 liters and equipped with a sealing quick-connect plug. The bag must be leak-free according to Section 4.1. For protection, it is recommended that the bag be enclosed with a rigid container.

2.1.7 *Valves.* Stainless-steel needle valve to adjust flow rate, and stainless-steel three-way valve, or equivalent.

2.1.8 *CO₂ Analyzer.* Method 3 or its approved alternative to measure CO₂ concentration to within 0.5 percent.

2.1.9 *Volume Meter.* Dry gas meter, calibrated and capable of measuring the sample volume under rotameter calibration conditions of 300 ml/min for 10 minutes.

2.1.10 *Pressure Gauge.* A water filled U-tube manometer, or equivalent, of about 28 cm (12 in.) to leak-check the flexible bag.

2.2 Analysis.

2.2.1 *Spectrophotometer.* Single- or double-beam to measure absorbance at 425 and 600 nm. Slit width should not exceed 20 nm.

2.2.2 *Spectrophotometer Cells.* 1-cm path-length.

2.2.3 *Vacuum Gauge.* U-tube mercury manometer, 1 meter (39 in.), with 1-mm divisions, or other gauge capable of measuring pressure to within 1 mm Hg.

2.2.4 *Pump.* Capable of evacuating the gas reaction bulb to a pressure equal to or less than 40 mm Hg absolute, equipped with coarse and fine flow control valves.

2.2.5 *Barometer.* Mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 1 mm Hg.

2.2.6 *Reaction Bulbs.* Pyrex glass, 100 ml with Teflon stopcock (Figure 10A-2), leak-free at 40 mm Hg, designed so that 10 ml of the colorimetric reagent can be added and removed easily and accurately. Commercially available gas sample bulbs such as Supelco Catalog No. 2-2161 may also be used.




Figure 10A-2. Sample reaction bulbs.

2.2.7 *Manifold.* Stainless steel, with connections for three reaction bulbs and the appropriate connections for the manometer and sampling bag as shown in Figure 10A-3.

2.2.8 *Pipets.* Class A, 10-ml size.

2.2.9 *Shaker Table.* Reciprocating-stroke type such as Eberbach Corporation, Model 6015. A rocking arm or rotary-motion type shaker may also be used. The shaker must

be large enough to accommodate at least six gas sample bulbs simultaneously. It may be necessary to construct a table top extension for most commercial shakers to provide sufficient space for the needed bulbs (Figure 10A-4).

2.2.10 *Valve.* Stainless steel shut-off valve.




Figure 10A-3. Sample bulb filling system.

2.2.11 *Analytical Balance.* Capable of accurately weighing to 0.1 mg.

3. Reagents

Unless otherwise indicated, all reagents shall conform to the specifications estab-

ished by the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available, otherwise, the best available grade shall be used.

3.1 Sampling.

3.1.1 *Water.* Deionized distilled, as described in Method 6, Section 3.1.1.

3.1.2 *Alkaline Permanganate Solution.* 0.25 M KMnO_4 /1.5 M NaOH. Dissolve 40 g KMnO_4 and 60 g NaOH in water, and dilute to 1 liter.

3.2 Analysis.

3.2.1 *Water.* Same as in Section 3.1.1.

3.2.2 *1 M Sodium Hydroxide (NaOH) Solution.* Dissolve 40 g NaOH in approximately 900 ml of water, cool, and dilute to 1 liter.

3.2.3 *0.1 M Silver Nitrate (AgNO_3) Solution.* Dissolve 8.5 g AgNO_3 in water, and dilute to 500 ml.

3.2.4 *0.1 M Para-Sulfaminobenzoic Acid (p-SABA) Solution.* Dissolve 10.0 g p-SABA in 0.1 M NaOH (prepared by diluting 50 ml of 1 M NaOH to 500 ml), and dilute to 500 ml with 0.1 M NaOH.




Figure 10A-4. Shaker table adapter.

3.2.5 Colorimetric Solution. To a flask, add 100 ml of p-SABA solution and 100 ml of AgNO₃ solution. Mix, and add 50 ml of 1 M NaOH with shaking. The resultant solution should be clear and colorless. This solution is acceptable for use for a period of 2 days.

3.2.6 Standard Gas Mixtures. Traceable to NBS standards and containing between 50 and 1000 ppm CO in nitrogen. At least two concentrations are needed to span each calibration range used (Section 5.3).

The calibration gases shall be certified by the manufacturer to be within 2 percent of the specified concentrations.

4. Procedure

4.1 Sample Bag Leak-checks. While a bag leak-check is required after bag use, it should also be done before the bag is used for sample collection. The bag should be leak-checked in the inflated and deflated condition according to the following procedures.

Connect the bag to a water manometer, and pressurize the bag to 5 to 10 cm H₂O (2 to 4 in. H₂O). Allow the bag to stand for 60 minutes. Any displacement in the water manometer indicates a leak. Now, evacuate the bag with a leakless pump that is connected on the downstream side of a flow-indicating device such as a 0-to 100-ml/min rotameter or an impinger containing water. When the bag is completely evacuated, no flow should be evident if the bag is leak-free.

4.2 Sampling. Evacuate the Tedlar bag completely using a vacuum pump. Assemble the apparatus as shown in Figure 10A-1. Loosely pack glass wool in the tip of the probe. Place 400 ml of alkaline permanganate solution in the first two impingers and 250 ml in the third. Connect the pump to the third impinger, and follow this with the surge tank, rate meter, and three-way valve. Do not connect the Tedlar bag to the system at this time.

Leak-check the sampling system by placing a vacuum gauge at or near the probe inlet, plugging the probe inlet, opening the

three-way valve, and pulling a vacuum approximately 250 mm Hg on the system while observing the rate meter for flow. If flow is indicated on the rate meter, do not proceed further until the leak is found and corrected.

Purge the system with sample gas by inserting the probe into the stack and drawing sample through the system at 300 ml/min for 5 minutes. Connect the evacuated Tedlar bag to the system, record the starting time, and sample at a rate of 3 ml/min for 30 minutes, or until the Tedlar bag is nearly full. Record the sampling time, the barometric pressure, and the ambient temperature. Purge the system as described above immediately before each sample.

The scrubbing solution is adequate for removing sulfur and nitrogen oxides from 10 liters of stack gas when the concentration of each is less than 1,000 ppm and the CO₂ concentration is less than 15 percent. Replace the scrubber solution after every fifth sample.

4.3 Carbon Dioxide Measurement. Measure the CO₂ content in the stack to the nearest 0.5 percent each time a CO sample is collected. A simultaneous grab sample analyzed by the Fyrite analyzer is acceptable.

4.4 Analysis. Assemble the system shown in Figure 10A-3, and record the information required in Table 10A-1 as it is obtained. Pipet 10.0 ml of the colorimetric reagent into each gas reaction bulb, and attach the bulbs to the system. Open the stopcocks on the reaction bulbs, but leave the valve to the Tedlar bag closed. Turn on the pump, fully open the coarse-adjust flow valve, and slowly open the fine-adjust valve until the pressure is reduced to at least 40 mm Hg. Now close the coarse adjust valve, and observe the manometer to be certain that the system is leak-free. Wait a minimum of 10 minutes. If the pressure has increased less than 1 mm, proceed as described below. If a leak is present, find and correct it before proceeding further.

TABLE 10A-1. DATA RECORDING SHEET FOR SAMPLES ANALYZED IN TRIPLICATE

Sample no./type	Room temp. °C	Stack % CO ₂	Bulb no.	Bulb vol., liters	Reagent vol. in bulb, liter	Partial pressure of gas in bulb mm Hg	P _{bar.} mm Hg	Shaking time, min	Abs versus water	A - A _r	A _s	Avg. A _s
Blank												
Std. 1												
Std. 2												
Sample 1												
Sample 2												
Sample 3												

Record the vacuum pressure (P_v) to the nearest 1 mm Hg, and close the reaction bulb stopcocks. Open the Tedlar bag valve, and allow the system to come to atmospheric pressure. Close the bag valve, open the pump coarse adjust valve, and evacuate the system again. Repeat this fill/evacuation procedure at least twice to flush the manifold completely. Close the pump coarse adjust valve, open the Tedlar bag valve, and let the system fill to atmospheric pressure. Open the stopcocks to the reaction bulbs, and let the entire system come to atmospheric pressure. Close the bulb stopcocks, remove the bulbs, record the room temperature and barometric pressure (P_{bar} to nearest mm Hg), and place the bulbs on the shaker table with their main axis either parallel to or perpendicular to the plane of the table top. Purge the bulb-filling system with ambient air for several minutes between samples. Shake the samples for exactly 2 hours.

Immediately after shaking, measure the absorbance (A) of each bulb sample at 425 nm if the concentration is less than or equal to 400 ppm CO or at 600 nm if the concentration is above 400 ppm. This may be accomplished with multiple bulb sets by sequentially collecting sets and adding to the shaker at staggered intervals, followed by sequentially removing sets from the shaker for absorbance measurement after the two-hour designated intervals have elapsed.

Use a small portion of the sample to rinse a spectrophotometer cell several times before taking an aliquot for analysis. If one cell is used to analyze multiple samples, rinse the cell several times between samples with water.

Prepare and analyze standards and a reagent blank as described in Section 5.3. Use water as the reference. Reject the analysis if the blank absorbance is greater than 0.1. All conditions should be the same for analysis of samples and standards. Measure the absorbances as soon as possible after shaking is completed. Determine the CO concentration of each bag sample using the calibration curve for the appropriate concentration range as discussed in Section 5.3.

5. Calibration

5.1 Bulb Calibration. Weigh the empty bulb to the nearest 0.1 g. Fill the bulb to the stopcock with water, and again weigh to the nearest 0.1 g. Subtract the tare weight, and calculate the volume in liters to three significant figures using the density of water (at the measurement temperature). Record the volume on the bulb; alternatively, mark an identification number on the bulb, and record the volume in a notebook.

5.2 Rate Meter Calibration. Assemble the system as shown in Figure 10A-1 (the impingers may be removed), and attach a volume meter to the probe inlet. Set the ro-

tameter at 300 ml/min, record the volume meter reading, start the pump, and pull gas through the system for 10 minutes. Record the final volume meter reading. Repeat the procedure and average the results to determine the volume of gas that passed through the system.

5.3 Spectrophotometer Calibration Curve. The calibration curve is established by taking at least two sets of three bulbs of known CO collected from Tedlar bags through the analysis procedure. Reject the standard set where any of the individual bulb absorbances differ from the set mean by more than 10 percent. Collect the standards as described in Section 4.2. Prepare standards to span the 0- to 400- or 400- to 1000-ppm range. If any samples span both concentration ranges, prepare a calibration curve for each range. A set of three bulbs containing colorimetric reagent but no CO should serve as a reagent blank and be taken through the analysis procedure.

Calculate the average absorbance for each set (3 bulbs) of standards using Equation 10A-1 and Table 10A-1. Construct a graph of average absorbance for each standard against its corresponding concentration in ppm. Draw a smooth curve through the points. The curve should be linear over the two concentration ranges discussed in Section 1.3.1.

6. Calculations

Carry out calculations retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

6.1 Nomenclature.

A = Sample absorbance, uncorrected for the reagent blank.
 A_r = Absorbance of the reagent blank.
 A_s = Average sample absorbance per liter, units/liter.
 B_w = Moisture content in the bag sample.
 C = CO concentration in the stack gas, dry basis, ppm.
 C_b = CO concentration of the bag sample, dry basis, ppm.
 C_c = CO concentration from the calibration curve, ppm.
 F = Volume fraction of CO₂ in the stack.
 n = Number of reaction bulbs used per bag sample.
 P_{bar} = Barometric pressure, mm Hg.

P_r = Residual pressure in the sample bulb after evacuation, mm Hg.

P_w = Vapor pressure of H₂O in the bag (from Table 10A-2), mm Hg.

V_b = Volume of the sample bulb, liters.

V_r = Volume of reagent added to the sample bulb, 0.0100 liter.

6.2 Average Sample Absorbance per Liter.

Average the three absorbance values for each bulb set. Then calculate A_s for each set of gas bulbs using Equation 10A-1. Use A_s to determine the CO concentration from the calibration curve (C_c).

$$A_s = \frac{(A - A_r)(P_{bar})}{(V_b - V_r)(P_{bar} - P_r)}$$

Eq. 10A-1

NOTE: A and A_r must be at the same wavelength.

6.3 CO Concentration in the Bag.

Calculate C_b using Equations 10A-2 and 10A-3. If condensate is visible in the Tedlar bag, calculate B_w using Table 10A-2 and the temperature and barometric pressure in the analysis room. If condensate is not visible, calculate B_w using the temperature and barometric pressure recorded at the sampling site.

$$B_w = \frac{P_w}{P_{bar}}$$

Eq. 10A-2

$$C_b = \frac{C_c}{(1 - B_w)}$$

Eq. 10A-3

6.4 CO Concentration in the Stack.

$$C = C_b(1 - F)$$

Eq. 10A-4

TABLE 10A-2. MOISTURE CORRECTION

Temperature, °C	Vapor pressure of H ₂ O, mm Hg	Temperature, °C	Vapor pressure of H ₂ O, mm Hg
4	6.1	18	15.5
6	7.0	20	17.5
8	8.0	22	19.8
10	9.2	24	22.4
12	10.5	26	25.2
14	12.0	28	28.3
16	13.6	30	31.8

7. BIBLIOGRAPHY

1. Butler, F.E., J.E. Knoll, and M.R. Midgett. Development and Evaluation of Methods for Determining Carbon Monoxide Emissions. Quality Assurance Division, Environmental Monitoring Systems Laboratory, U.S. Environmental Protection Agency, Research Triangle Park, NC 27711. June 1985. 33 p.

2. Ferguson, B.B., R.E. Lester, and W.J. Mitchell. Field Evaluation of Carbon Monoxide and Hydrogen Sulfide Continuous Emission Monitors at an Oil Refinery. U.S. Environmental Protection Agency, Research Triangle Park, NC. Publication No. EPA-600/4-82-054. August 1982. 100 p.

3. Lambert, J.L., and R.E. Weins. Induced Colorimetric Method for Carbon Monoxide. *Analytical Chemistry*. 46(7):929-930. June 1974.

4. Levaggi, D.A., and M. Feldstein. The Colorimetric Determination of Low Concentrations of Carbon Monoxide. *Industrial Hygiene Journal*. 25:64-66. January-February 1964.

5. Repp, M. Evaluation of Continuous Monitors for Carbon Monoxide in Stationary Sources. U.S. Environmental Protection Agency, Research Triangle Park, NC. Publication No. EPA-600/2-77-063. March 1977. 155 p.

6. Smith, F., D.E. Wagoner, and R.P. Donovan. Guidelines for Development of a Quality Assurance Program: Volume VIII—Determination of CO Emissions from Stationary Sources by NDIR Spectrometry. U.S. Environmental Protection Agency, Research Triangle Park, NC. Publication No. EPA-650/4-74-005-h. February 1975. 96 p.

METHOD 10B—DETERMINATION OF CARBON MONOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Applicability and Principle

1.1 Applicability. This method applies to the measurement of carbon monoxide (CO) emissions at petroleum refineries and from other sources when specified in an applicable subpart of the regulations.

1.2 Principle. An integrated gas sample is extracted from the sampling point and analyzed for CO. The sample is passed through a conditioning system to remove interferences and collected in a Tedlar bag. The CO is separated from the sample by gas chromatography (GC) and catalytically reduced to methane (CH₄) prior to analysis by flame ionization detection FID. The analytical portion of this method is identical to applicable sections in Method 25 detailing CO measurement. The oxidation catalyst re-

APPENDIX K
CALCULATION EQUATIONS

CALCULATION EQUATIONS

METHOD 10

$$CO \cdot PPM \cdot DRY = CO_{CO_2} - free, dry, avg (1 - CO_2, d/100)$$

$$CO \cdot PPM \cdot WET = CO \cdot PPM \cdot DRY (1 - MC/100)$$

$$GR/DSCF = 5.0885 \times 10^{-4} (CO \cdot PPM \cdot DRY)$$

$$mg/dscm = 1.165 (CO \cdot PPM \cdot DRY)$$

$$\dot{m} = 8.5714 \times 10^{-3} (GR/DSCF) (Q_{s,d})$$

$$E = \frac{2.9857 \times 10^{-3} F_d (GR/DSCF)}{20.9 - O_{2,d}}$$

where:

$CO_{CO_2} - free, dry, avg$

= average of two determinations of carbon monoxide on a dry, CO_2 - free integrated flue gas sample reported in ppm by volume

$CO_{2,d}$ = carbon dioxide concentration of flue gas on a dry percent by volume basis

$O_{2,d}$ = oxygen concentration of flue gas on a dry percent by volume basis

MC	=	moisture content of flue gas on a percent by volume basis
CO·PPM·DRY	=	carbon monoxide concentration in ppm by volume on a dry basis
CO·PPM·WET	=	carbon monoxide concentration in ppm by volume on a wet or actual basis
GR/DSCF	=	concentration of carbon monoxide in flue gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
mg/dscm	=	concentration of carbon monoxide in flue gas on a milligrams per dry standard cubic meter basis (60 °F, 29.92 IN. HG.)
m	=	emissions or mass rate of carbon monoxide on a LB/HR basis
Q_d	=	volumetric flow rate of flue gas in dry standard cubic feet per minute
E	=	emission factor of carbon monoxide in pounds of carbon monoxide emitted per million BTU heat input (LB/MMBTU)
F_d	=	F-Factor of respective fuel in dry standard cubic feet of exhaust gas at 0% oxygen per million BTU of heat input (DSCF/MMBTU)

Interpoll Laboratories, Inc.
(612) 786-6020

CARBON MONOXIDE CONCENTRATION CALCULATION

EPA METHOD 10
(WITH ALTERNATIVE INTERFERENCE TRAP)

$$C_{CO_{stack}} = C_{CO_{NDIR}} (1 - (f_{CO_2} - f_{RCO_2}))$$

where:

- $C_{CO_{stack}}$ = Concentration of CO in stack, ppm by volume (dry basis)
- $C_{CO_{NDIR}}$ = Concentration of CO measured by NDIR analyzer, ppm by volume (dry basis)
- f_{CO_2} = Volume fraction of CO_2 in sample
- f_{RCO_2} = Volume fraction of residual CO_2 in sample after scrubbing.

DS-009

4-3688.LB

LP- HAYWARD				Report No. 4-3688					
		Hayward, Wisconsin							
				Carbon Monoxide					
				LB/HR Calculations					
Line 2 Dryer RTO Stack									
RUN	CO ppm	Flow	LB/DSCF	LB/HR		RUN	CO ppm	Flow	LB/DSCF
1	277	64296	2.01E-05	77.64444			1	385	54950
2	449	67839	3.26E-05	132.7922			2	401	53114
3	174	70246	1.26E-05	53.28654			3	480	59647
4	241	69468	1.75E-05	72.9875			4	621	58462
5	325	65764	2.36E-05	93.17904			5	553	57376
6	369	66648	2.68E-05	107.2161			6	456	57137
7	553	63574	4.02E-05	153.2679			7	216	59025
8	370	66822	2.69E-05	107.7874			8	394	57931
9	409	64830	2.97E-05	115.5968			9	262	59013
10	393	62952	2.86E-05	107.8571			10	153	57803
11	506	64973	3.68E-05	143.3277			11	232	62201
12	449	62925	3.26E-05	123.1732			12	290	61419
Line 1 Press RTO Stack									
RUN	CO ppm	Flow	LB/DSCF	LB/HR		RUN	CO ppm	Flow	LB/DSCF
1	18.5	65422	1.34E-06	5.276454			1	11.6	77185
2	15.5	66759	1.13E-06	4.511159			2	12.5	77583
3	15.7	67198	1.14E-06	4.599415			3	12.8	75642
4	14.9	66676	1.08E-06	4.331142			4	12.7	76543
5	16.5	65316	1.2E-06	4.698402			5	13.7	76657
6	15.4	65374	1.12E-06	4.389069			6	11.3	76896
7	13.4	64686	9.74E-07	3.778868			7	10.3	77097
8	12.9	66275	9.37E-07	3.727229			8	10.6	76946
9	17.1	62727	1.24E-06	4.676245			9	17.1	76092
10	16.2	65860	1.18E-06	4.651397			10	9.8	76300
11	15.7	64988	1.14E-06	4.44815			11	8.1	76082
12	15.9	64923	1.16E-06	4.500309			12	8.3	75359
Line 2 Press RTO Stack									
RUN	CO ppm	Flow	LB/DSCF	LB/HR		RUN	CO ppm	Flow	LB/DSCF
1	18.5	65422	1.34E-06	5.276454			1	11.6	77185
2	15.5	66759	1.13E-06	4.511159			2	12.5	77583
3	15.7	67198	1.14E-06	4.599415			3	12.8	75642
4	14.9	66676	1.08E-06	4.331142			4	12.7	76543
5	16.5	65316	1.2E-06	4.698402			5	13.7	76657
6	15.4	65374	1.12E-06	4.389069			6	11.3	76896
7	13.4	64686	9.74E-07	3.778868			7	10.3	77097
8	12.9	66275	9.37E-07	3.727229			8	10.6	76946
9	17.1	62727	1.24E-06	4.676245			9</		

APPENDIX L

CALIBRATION DRIFT DATA

Dryer #1 Normal Opacity Calibration Report

LOUISIANA PACIFIC

05:00:00 08-23-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.20	0.00	0.93	102.42
Epan	43.33	44.62	45.28	1.29	30.66

Dirt Drift % 0.92

Back Taper Ratio (Exit/Monitoring) 1.00

Dryer #1 Normal Opacity Calibration Report

LOUISIANA PACIFIC

05:00:00 08-22-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.23	0.00	0.90	102.47
Span	43.33	44.49	45.16	1.16	30.81

Dirt Drift % 0.89

Stack Taper Ratio (Exit/Monitoring) 1.00

Dryer #1 Normal Opacity Calibration Report

LOUISIANA PACIFIC

05:00:00 08-21-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.29	-0.00	0.84	102.59
Span	43.33	44.40	45.11	1.07	30.91

Dirt Drift % 0.83

Stack Taper Ratio (Exit/Monitoring) 1.00

Dryer #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-20-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.41	-0.00	0.72	102.83
Span	43.33	44.32	45.09	0.98	31.01

Dirt Drift % 0.71

Stack Taper Ratio (Exit/Monitoring) 1.00

Dryer #1 Normal Opacity Calibration Report

LOUISIANA PACIFIC

05:00:00 08-19-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.62	-0.00	0.50	103.27
Span	43.33	44.40	45.29	1.07	30.91

Int Drift % 0.50

Stack Taper Ratio (Exit/Monitoring) 1.00

Dryer #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-18-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.44	-0.00	0.68	102.91
Span	43.34	44.30	45.09	0.96	31.03

Net Drift % 0.67

Stack Taper Ratio (Exit/Monitoring) 1.00

Dryer #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-17-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-2.13	-1.54	-0.00	0.59	103.10
Span	43.34	44.32	45.16	0.98	31.01

Dirt Drift % 0.58

Stack Taper Ratio (Exit/Monitoring) 1.00

Dryer #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 07:00:03 08-23-1994

SA S PLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.68	0.00	0.75	92.77
Blank	47.36	47.62	45.61	0.26	27.44

Net Drift % 0.78

Blank Taper Ratio (Exit/Monitoring) 1.00

Dryer #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 07:00:02 08-22-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.67	-0.00	0.74	92.80
Blank	47.36	47.64	45.64	0.28	27.42

Net Drift % 0.77

Lock Taper Ratio (Exit/Monitoring) 1.00

Dryer #2 Normal Opacity Calibration Report

LOUISIANA PACIFIC

07:00:02 08-21-1994

FILE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.68	0.00	0.75	92.77
an	47.36	47.64	45.64	0.28	27.42

Int Drift % 0.78

Block Taper Ratio (Exit/Monitoring) 1.00

Dryer #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 07:00:02 08-20-1994

FILE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.49	-0.00	0.56	93.14
Jan	47.36	47.50	45.60	0.14	27.56

Net Drift % 0.58

Lock Taper Ratio (Exit/Monitoring) 1.00

Dryer #2 Normal Opacity Calibration Report

LOUISIANA PACIFIC

07:00:02 08-19-1994

FILE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.62	-0.00	0.69	92.90
Std	47.36	47.52	45.55	0.16	27.54

Net Drift % 0.72

Back Taper Ratio (Exit/Monitoring) 1.00

Dryer #2 Normal Opacity Calibration Report

LOUISIANA PACIFIC

07:00:02 08-18-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.31	0.00	0.39	93.48
Span	47.36	47.52	45.72	0.16	27.54
Dirt Drift % 0.40					
Stack Taper Ratio (Exit/Monitoring) 1.00					
=====					

Dryer #2 Normal Opacity Calibration Report
LOUISIANA PACIFIC
07:00:02 08-17-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	2.93	3.34	0.00	0.41	93.43
Span	47.36	47.52	45.71	0.16	27.54

Dirt Drift % 0.43

Back Taper Ratio (Exit/Monitoring) 1.00

=====

Press #1 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-23-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.28	0.26	-0.00	-0.02	99.49
Span	45.30	44.87	44.73	-0.43	30.40

Int Drift % -0.02

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-22-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.28	0.23	-0.00	-0.04	99.54
Span	45.30	45.02	44.90	-0.28	30.22

Int Drift % -0.04

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #1 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-21-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
ero	0.28	0.16	-0.00	-0.12	99.68
span	45.30	44.91	44.82	-0.39	30.35

Port Drift % -0.12

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #1 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-20-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
ero	0.28	-0.02	0.00	-0.30	100.05
pan	45.30	44.96	44.97	-0.34	30.30

Net Drift % -0.30

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-19-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.28	0.38	-0.00	0.10	99.24
Span	45.30	45.00	44.79	-0.30	30.25

Percent Drift % 0.10

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-18-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.27	0.20	-0.00	-0.08	99.61
Span	45.30	45.07	44.96	-0.23	30.18

pt Drift % -0.08

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #1 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-17-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.27	0.12	0.00	-0.15	99.76
Span	45.30	45.09	45.02	-0.21	30.15

Int Drift % -0.15

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-23-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.00	0.18	-0.00	0.18	99.63
Span	44.92	45.13	45.03	0.22	30.10

Net Drift % 0.18

Back Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-22-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.00	0.38	0.00	0.38	99.24
Span	44.92	45.22	45.01	0.31	30.00

Int Drift % 0.38

back Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-21-1994

FILE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.00	0.34	-0.00	0.34	99.32
Span	44.92	45.13	44.95	0.22	30.10

Int Drift % 0.34

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-20-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.00	0.31	0.00	0.31	99.39
pan	44.92	45.07	44.90	0.15	30.18

Percent Drift % 0.31

Back Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
 LOUISIANA PACIFIC
 05:00:00 08-19-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	0.00	0.24	-0.00	0.24	99.51
Span	44.92	44.85	44.71	-0.07	30.42

Percent Drift % 0.25

Stack Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-18-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-0.00	0.34	0.00	0.34	99.32
Span	44.92	45.00	44.81	0.08	30.25

Dirt Drift % 0.35

Back Taper Ratio (Exit/Monitoring) 1.00

Press #2 Normal Opacity Calibration Report
LOUISIANA PACIFIC
05:00:00 08-17-1994

SAMPLE	CALIBRATION STANDARD	READING	ADJUSTED READING	PERCENT DRIFT	PERCENT TRANSMISSION
Zero	-0.00	0.12	0.00	0.12	99.76
Span	44.92	45.07	45.00	0.15	30.18

Dist Drift % 0.12

Black Taper Ratio (Exit/Monitoring) 1.00

APPENDIX M

TRANSMISSOMETER FACTORY PERFORMANCE SPECIFICATION TESTS

(Provided by Louisiana-Pacific)

TRANSMISSOMETER FACTORY PERFORMANCE
SPECIFICATION TESTS
PER
CODE OF FEDERAL REGULATIONS
TITLE 40, PART 60, APPENDIX B, SPECIFICATION 1

UNITED SCIENCES INC.
MODEL 500C COMPLIANCE OPACITY MONITOR

SERIAL NO: 0993724

TRANSMISSOMETER PERFORMANCE SPECIFICATION TESTS

PER

CODE OF FEDERAL REGULATIONS

TITLE 40, PART 60, APPENDIX B

SPECIFICATION 1

GRASEBY / STI

ID# LOUISIANA PACIFIC CHILCO

Transmissometer Serial No. 0993724

This signed and completed document certifies that the Model 500C Transmissometer has been tested and meets the factory certification tests herein.



Signed

Dean Murray

Please Print Above Signature

Date: 3-16-94

IDENT NO. C93GRG09

TRANSMISSOMETER FACTORY PERFORMANCE
SPECIFICATION TESTS
PER
CODE OF FEDERAL REGULATIONS
TITLE 40, PART 60, APPENDIX B, SPECIFICATION 1

UNITED SCIENCES INC.
MODEL 500C COMPLIANCE OPACITY MONITOR

SERIAL NO: 0993724

TABLE OF CONTENTS

	Page
1.0 Introduction	1
2.0 Test Results Summary	1
2.1 Design Specifications	1
2.2 Performance Specifications	1
3.0 Instrument Description	1
4.0 Design Specifications	3
4.1 Spectral Response	3
4.2 Angle of View	5
4.3 Angle of Projection	5
4.4 Optical Alignment	14
4.5 Simulated Zero and Upscale Calibration	14
4.6 Access to External Optics	14
4.7 Auto Zero Compensation Indicator	14
4.8 External Calibration Filter Access	14
5.0 Performance Specifications	14
5.1 Calibration Error Test	14
5.2 Neutral Density Attenuators	18
5.3 Response Time Test	18

APPENDIX A - Equations Used

APPENDIX B - Neutral Density Filters Certificate of Analysis

1.0 INTRODUCTION

This report describes the procedures used and the test results obtained during testing of the United Sciences Inc. (USI) Model 500C Transmissometer.

These tests were conducted in accordance with the Code of Federal Regulations, Title 40, Part 60, Appendix B, Specification 1.

2.0 TEST RESULTS SUMMARY

A summary of test results is listed here in tabular form for quick reference. Discussions of test procedures, actual test data, and calculations will be described later in the appropriate sections of this report.

2.1 DESIGN SPECIFICATIONS

Refer to Manufacturer's Certificate of Conformance with Design Specifications, page 2.

2.2 PERFORMANCE SPECIFICATIONS

2.2.1 CALIBRATION ERROR

Low Filter	0.3/	% Opacity
Mid Filter	0.73	% Opacity
High Filter	0.86	% Opacity

2.2.2 RESPONSE TIME	2.11	seconds
---------------------	------	---------

3.0 INSTRUMENT DESCRIPTION

The USI Model 500C transmissometer is a double-pass, two detector analyzer designed to continuously monitor the opacity of effluent in a duct or stack exhausting combustion gases.

The analyzer uses a special solid state light source (Light Emitting Diode) to project a modulated light beam from the optical head assembly through a medium of interest to the passive retroreflector. The retroreflector returns the beam through the medium to the optical head where the beam is refocused onto the "signal" detector. A second "reference" detector is used in the optical head assembly to monitor and control the output of the LED in order to provide long term operational stability regardless of extremes in ambient temperature or aging of optical and electronic components.

United Sciences inc.

5310 NORTH PIONEER ROAD • GIBSONIA, PA 15044 • 412 - 443-8610 • FAX 412 - 443-4025

MANUFACTURER'S CERTIFICATE OF CONFORMANCE WITH DESIGN SPECIFICATIONS

United Sciences Inc. certifies that the Model 500C transmissometer randomly sampled from the September 1993 production was tested according to Sections 6.1 through 6.4 of the Code of Federal Regulations, Title 40, Part 60, Appendix B, Specification 1 and met all requirements of Section 5 of this specification.

Test results are listed below. These data are valid for Serial Numbers 0993534 through 0993743.

Serial Number Tested - 0993541

5.1.1 Spectral Response		
	<u>Relative Response</u>	<u>Wavelength</u>
	Peak	570nm
	Mean	576nm
	< 1%	< 400nm
	< 1%	> 700nm
5.1.2	Angle of View	≤ 3.24 Degrees
5.1.3	Angle of Projection	
	Projection Aperture .141" Diam	≤ 2.67 Degrees
5.1.4	Optical Alignment	Provided
5.1.5	Simulated Zero and Upscale Calibration	Provided
5.1.6	Access to External Optics	Provided
5.1.7	Auto Zero Compensation Indicator	Provided
5.1.8	Slotted Tube	Not Applicable
5.1.9	External Calibration Filter Access	Provided

Signed: _____

By: Joseph Ziolkowski

Date: September 19, 1993

A calibration wheel, located in the optical head, rotates continuously in front of the projected beam in order to provide simulated zero and upscale calibration values. Signals proportional to the simulated zero, upscale calibration, and the opacity of the effluent are time multiplexed and transmitted via a 0-20 mA current loop to the microprocessor controlled remote display panel. Assessment of these signals by the microprocessor permits the remote display panel to correct the opacity data for dirt accumulation on the optical surfaces and to output the amount of the automatic zero correction to the digital display.

Since the simulated zero, upscale calibration, and actual opacity values are monitored continuously by the microprocessor, the panel can immediately provide alarms to indicate operational malfunctions without waiting for auto calibration cycle evaluation.

These data are analyzed by the remote display panel, and analog outputs are generated in terms of instantaneous and integrated opacity. These outputs may be corrected or uncorrected for stack geometry, depending on the specific user's needs.

A Calibration Kit is provided which may be installed on the Optical Head to check the operation of the analyzer while the stack or duct is in operation. Calibrated Neutral Density Filters may be installed in this fixture to provide audit and calibration information.

4.0 DESIGN SPECIFICATIONS

4.1 SPECTRAL RESPONSE

4.1.1 PROCEDURE


USI obtained curves of the spectral data of the yellow-green LED and the silicon photo diode from their respective manufacturers. The relative response of each curve was determined at 10 nanometer intervals and the product of the response of the two curves calculated. The product data were then normalized and a composite analyzer spectral response curve constructed. Reference Drawing No. 600-0005-01, Figure 1.

Since the entire output of the LED source falls within the 400 to 700nm range, the use of color correction filters is unnecessary.

4.1.2 RESULTS

The spectral data on the Manufacturer's Certificate of Conformance was obtained from the Analyzer Response Curve, Drawing No. 600-0005-01, and indicate that the analyzer met or exceeded the performance specification.

ANALYZER SPECTRAL RESPONSE UNITED SCIENCES INC. MODEL 500C



LED	WAVELENGTH (nm)	PROD.	RELATIVE RESPONSE	WAVELENGTH (nm)
<1	65	65	0.089	538
4.3	66	283	0.039	540
10.5	68	1250	0.177	550
60.2	70	4775	0.672	560
98.7	72	7106	1.0	570
76.7	74	5676	0.799	580
44.2	76	3359	0.473	590
24.0	77	1840	0.260	600
12.3	79	971	0.137	610
6.2	80	496	0.070	620
2.0	82	164	0.023	630
<1	83	83	0.011	640

UNITED SCIENCES INC. MODEL 500C

ANALYZER SPECTRAL RESPONSE CURVE

FINISH

600-0005

1-1

1

4.2 ANGLE OF VIEW

4.2.1 PROCEDURE

USI chose an analyzer, Serial No. 0993541, at random and performed the angle of view test in both the vertical and horizontal directions. A small, 1.3 centimeter, quartz halogen light source was placed on an arc whose radius was 3 meters from the analyzer. The analyzer's response was monitored while the light source was moved until the analyzer's maximum response indicated the viewing centerline. The analyzer's response was then recorded at the centerline and at 5 centimeter intervals along the arc for a total of 30 centimeters on each side (see Figures 2 and 4). These readings were then normalized and the angle of view curves of Figures 3 and 5 constructed.

4.2.2 RESULTS

The angle of view reported on the Manufacturer's Certificate of Conformance was obtained from the angle of view curves, Figures 3 and 5, according to the formula:

$$\text{Angle of View in Degrees} = \text{arc tan } \frac{D}{300}$$

Where D = Total distance, in centimeters, along the arc during which the analyzer's response was greater than 2.5% of the peak response.

4.3 ANGLE OF PROJECTION

4.3.1 PROCEDURE

USI chose an analyzer, Serial No. 0993541, at random and performed an angle of projection test on the analyzer in both the vertical and the horizontal direction. A small, .25 centimeter, silicon photo diode was placed on an arc whose radius was 3 meters from the analyzer. The analyzer's projection system was focused to the 3 meter range and by measuring the output of the silicon photo diode the centerline of the projected beam was determined.

Measurements of the photo diode's output were recorded at the centerline and at 5 centimeter intervals for 30 centimeters on each side of the centerline (see Figures 6 and 8). These readings were then normalized and the angle of projection curves of Figures 7 and 9 were constructed.

4.3.2 RESULTS

The angle of projection reported on the Manufacturer's Certificate of Conformance was obtained from the angle of projection curves, Figures 7 and 9, according to the formula:

$$\text{Angle of Projection in Degrees} = \text{arc tan } \frac{D}{300}$$

Where D = Total distance in centimeters along the arc during which the detector response was greater than 2.5% of the peak response.

FIGURE 2

ANGLE OF VIEW TEST

1. VERTICAL/HORIZONTAL VERTICAL
2. SERIAL NO. TESTED 0993541
3. FOR ANALYZERS PRODUCED SEPTEMBER MONTH 1993 YEAR
4. VALID FOR SERIAL NOS. 0993534 through 0993743
5. LIGHT SOURCE SIZE 1.3 cm
6. DATE OF TEST SEPTEMBER 16, 1993
7. TEST PERSONNEL WILLIAM SMITH and JOSEPH ZIOLKOWSKI
8. RANGE: ANALYZER TO SOURCE 3 METERS
9. PC BOARD SERIAL NO. L-08715M-0493
10. TEST POINT USED FOR OUTPUT TP3

<u>POSITION</u>	<u>READING</u>	<u>RELATIVE RESPONSE</u>
+30 cm	<u>-2.18</u>	<u>0.00%</u>
+25 cm	<u>-2.18</u>	<u>0.00%</u>
+20 cm	<u>-2.18</u>	<u>0.00%</u>
+15 cm	<u>-2.18</u>	<u>0.00%</u>
+10 cm	<u>-2.19</u>	<u>0.19%</u>
+5 cm	<u>-3.32</u>	<u>21.67%</u>
0 cl	<u>-7.44</u>	<u>100.00%</u>
-5 cm	<u>-2.27</u>	<u>1.71%</u>
-10 cm	<u>-2.18</u>	<u>0.00%</u>
-15 cm	<u>-2.18</u>	<u>0.00%</u>
-20 cm	<u>-2.18</u>	<u>0.00%</u>
-25 cm	<u>-2.18</u>	<u>0.00%</u>
-30 cm	<u>-2.18</u>	<u>0.00%</u>

FIGURE 3

ANGLE OF VIEW (vertical)
 SERIAL #0993541
 Aperture= .141" Angle= 2.58 deg.
 Month: Sept. 93
 Test Date: 9/16/93




FIGURE 4

ANGLE OF VIEW TEST

1. VERTICAL/HORIZONTAL HORIZONTAL

2. SERIAL NO. TESTED 0993541

3. FOR ANALYZERS PRODUCED SEPTEMBER MONTH 1993 YEAR

4. VALID FOR SERIAL NOS. 0993534 through 0993743

5. LIGHT SOURCE SIZE 1.3 cm

6. DATE OF TEST SEPTEMBER 16, 1993

7. TEST PERSONNEL WILLIAM SMITH and JOSEPH ZIOLKOWSKI

8. RANGE: ANALYZER TO SOURCE 3 METERS

9. PC BOARD SERIAL NO. L-08715M-0493

10. TEST POINT USED FOR OUTPUT TP3

<u>POSITION</u>	<u>READING</u>	<u>RELATIVE RESPONSE</u>
+30 cm	<u>-2.18</u>	<u>0.00%</u>
+25 cm	<u>-2.18</u>	<u>0.00%</u>
+20 cm	<u>-2.18</u>	<u>0.00%</u>
+15 cm	<u>-2.18</u>	<u>0.00%</u>
+10 cm	<u>-2.19</u>	<u>0.21%</u>
+5 cm	<u>-2.50</u>	<u>6.61%</u>
0 cl	<u>-7.02</u>	<u>100.00%</u>
-5 cm	<u>-3.12</u>	<u>19.42%</u>
-10 cm	<u>-2.19</u>	<u>0.21%</u>
-15 cm	<u>-2.19</u>	<u>0.21%</u>
-20 cm	<u>-2.18</u>	<u>0.00%</u>
-25 cm	<u>-2.18</u>	<u>0.00%</u>
-30 cm	<u>-2.18</u>	<u>0.00%</u>

FIGURE 5

ANGLE OF VIEW (horiz.)

Serial #0993541

Aperture= .141" Angle= 3.24 deg.

Month: Sept. 93

Test Date: 9/16/93




FIGURE 6

ANGLE OF PROJECTION TEST

1. VERTICAL/HORIZONTAL VERTICAL

2. SERIAL NO. TESTED 0993541

3. FOR ANALYZERS PRODUCED SEPTEMBER MONTH 1993 YEAR

4. VALID FOR SERIAL NOS. 0993534 through 0993743

5. DETECTOR SIZE .25 cm

6. DATE OF TEST SEPTEMBER 16, 1993

7. TEST PERSONNEL WILLIAM SMITH and JOSEPH ZIOLKOWSKI

8. RANGE: ANALYZER TO DETECTOR 3 METERS

9. PROJECTION APERTURE .141 (-09)

10. PC BOARD SERIAL NO. L-08715M-0493

11. TEST POINT USED FOR OUTPUT TP12

<u>POSITION</u>	<u>READING</u>	<u>RELATIVE RESPONSE</u>
+30 cm	<u>-0.11</u>	<u>0.00%</u>
+25 cm	<u>-0.11</u>	<u>0.00%</u>
+20 cm	<u>-0.11</u>	<u>0.00%</u>
+15 cm	<u>-0.11</u>	<u>0.00%</u>
+10 cm	<u>-0.11</u>	<u>0.00%</u>
+5 cm	<u>-0.21</u>	<u>1.40%</u>
0 cl	<u>-7.27</u>	<u>100.0%</u>
-5 cm	<u>-0.14</u>	<u>0.42%</u>
-10 cm	<u>-0.11</u>	<u>0.00%</u>
-15 cm	<u>-0.11</u>	<u>0.00%</u>
-20 cm	<u>-0.11</u>	<u>0.00%</u>
-25 cm	<u>-0.11</u>	<u>0.00%</u>
-30 cm	<u>-0.11</u>	<u>0.00%</u>

FIGURE 7

ANGLE OF PROJECTION (vert.)
 Serial # 0993541
 Aperture= .141" Angle=1.53 deg.
 Month: Sept. 93
 Test Date: 9/16/93




FIGURE 8

ANGLE OF PROJECTION TEST

1. VERTICAL/HORIZONTAL HORIZONTAL

2. SERIAL NO. TESTED 0993541

3. FOR ANALYZERS PRODUCED SEPTEMBER MONTH 1993 YEAR

4. VALID FOR SERIAL NOS. 0993534 through 0993743

5. DETECTOR SIZE .25 cm

6. DATE OF TEST SEPTEMBER 16, 1993

7. TEST PERSONNEL WILLIAM SMITH and JOSEPH ZIOLKOWSKI

8. RANGE: ANALYZER TO DETECTOR 3 METERS

9. PROJECTION APERTURE .141 (-09)


10. PC BOARD SERIAL NO. L-08715M-0493

11. TEST POINT USED FOR OUTPUT TP12

<u>POSITION</u>	<u>READING</u>	<u>RELATIVE RESPONSE</u>
+30 cm	<u>-0.10</u>	<u>0.00%</u>
+25 cm	<u>-0.10</u>	<u>0.00%</u>
+20 cm	<u>-0.10</u>	<u>0.00%</u>
+15 cm	<u>-0.10</u>	<u>0.00%</u>
+10 cm	<u>-0.10</u>	<u>0.00%</u>
+5 cm	<u>-2.75</u>	<u>36.96%</u>
0 cl	<u>-7.27</u>	<u>100.00%</u>
-5 cm	<u>-0.12</u>	<u>0.28%</u>
-10 cm	<u>-0.10</u>	<u>0.00%</u>
-15 cm	<u>-0.10</u>	<u>0.00%</u>
-20 cm	<u>-0.10</u>	<u>0.00%</u>
-25 cm	<u>-0.10</u>	<u>0.00%</u>
-30 cm	<u>-0.10</u>	<u>0.00%</u>

FIGURE 9

ANGLE OF PROJECTION (horiz)
Serial # 0993541
Aperture= .141" Angle= 2.67 deg
Month: Sept. 93
Test Date: 9/16/93



4.4 OPTICAL ALIGNMENT

4.4.1 PROCEDURE

USI chose an analyzer, Serial No. 0993541, at random from the September 1993 month's production and conducted an optical alignment sight test per Section 6.4 of 40 CFR Part 60, Appendix B, Specification 1. USI considers the optical system misaligned when the circle of the gunsight reticle intersects the edge of the retro image, as viewed from the optical head eyepiece.

4.4.2 RESULTS

The results of this test are shown in Figures 10, 11, and 12 and confirm that the Model 500C tested met or exceeded the Performance Specification. The instrument provided a clear indication when it was misaligned.

4.5 SIMULATED ZERO AND UPSCALE CALIBRATION

USI certifies that the Model 500C meets or exceeds the requirements of this specification and that compliance is inherent in the basic analyzer design details.

4.6 ACCESS TO EXTERNAL OPTICS

USI certifies that the Model 500C meets or exceeds the requirements of this specification and that compliance is inherent in the basic analyzer design details.

4.7 AUTO ZERO COMPENSATION INDICATOR

USI certifies that the Model 500C meets or exceeds the requirements of this specification and that compliance is inherent in the basic analyzer design details.

4.8 EXTERNAL CALIBRATION FILTER ACCESS

USI certifies that the Model 500C meets or exceeds the requirements of this specification and that compliance is inherent in the basic analyzer design details.

5.0 PERFORMANCE SPECIFICATIONS

5.1 CALIBRATION ERROR TEST

5.1.1 PROCEDURE

USI performed a Calibration Error test at the USI laboratory in Gibsonia, Pennsylvania, on the analyzer after the calibration and optical alignments were complete.

OPTICAL ALIGNMENT TEST

SERIAL NO. TESTED 0993541

FOR ANALYZERS PRODUCED SEPTEMBER MONTH 1993 YEAR

VALID FOR SERIAL NO. 0993534 through 0993743

DATE OF TEST SEPTEMBER 19, 1993

TEST PERSONNEL JOSEPH ZIOLKOWSKI

TEST DISTANCE 8 METERS

FILTER USED CLEAR

INSTRUMENT PROJECTION APERTURE .125 (-08)

Optical Head

1. OPACITY, PROPER ALIGNMENT 9.4%

2A. OPACITY, VERTICAL MISALIGNMENT 11.4% ±2.0%

2B. DISTANCE BEAM OFFSET AT 8 METERS 1 1/8"

3A. OPACITY, LATERAL MISALIGNMENT 7.3% ±2.0%

3B. DISTANCE BEAM OFFSET AT 8 METERS 1 1/8"

Retro Reflector

1. OPACITY, PROPER ALIGNMENT 9.4%

2. OPACITY, LATERAL MISALIGNMENT 7.5%

3. DISTANCE OFFSET (APPARENT) INSIGHT IMAGE 1 1/8"

COMMENTS: IN ALL TESTS, THE CIRCLE IN THE GUNSIGHT INTERSECTED THE EDGE OF
THE RETRO IMAGE BEFORE THE ±2% OPACITY MOVEMENT WAS INDICATED.

FIGURE 11

PROJECTOR UNIT MISALIGNMENT TEST

SERIAL NO. TESTED 0993541
TEST DATE SEPTEMBER 19, 1993
FILTER VALUE CLEAR O.D.
TEST DISTANCE 8 METERS
TEST PERSONNEL JOSEPH ZIOLKOWSKI

9.4 % OPACITY

VERTICAL MISALIGNMENT:

11.4 % OPACITY

HORIZONTAL MISALIGNMENT:

7.3 % OPACITY

Image as viewed from
optical head alignment sight






FIGURE 12

REFLECTOR UNIT
MISALIGNMENT TEST

SERIAL NO. TESTED 0993541

TEST DATE SEPTEMBER 19, 1993


FILTER VALUE CLEAR

TEST DISTANCE 8 METERS


TEST PERSONNEL JOSEPH ZIOLKOWSKI

PROPERLY ALIGNED: 9.4 % OPACITY

Image as viewed from
optical head alignment sight



LATERAL MISALIGNMENT: 7.5 % OPACITY



Low, mid, and high value neutral density attenuators were placed in the optical path between the Optical Head and the Retro. The analyzer's response to each attenuator was recorded. Each attenuator was measured five times non-consecutively, and its value was recorded in Figure 13. The test output device was a stripchart recorder, which was connected to the integrated analog output of the Remote Display panel.

5.1.2 RESULTS

The analyzer's response was subtracted from the pathlength adjusted neutral density attenuator value for each data point. The mean, standard deviation, confidence coefficient, and the total drift values were calculated and reported in Figure 13. These data indicate that the analyzer calibration error was less than three percent opacity for each filter and met or exceeded the performance specification.

5.2 RESPONSE TIME TEST

5.2.1 PROCEDURE

A high value attenuator was placed in the optical path and the time required for the analyzer to respond to 95% of the attenuator's value measured. The attenuator was then removed from the path and the time required for the analyzer to return to within 5% of its zero value measured. This procedure was then repeated until five upscale and five downscale times were recorded.

5.2.2 RESULTS

These data were recorded and a mean response time calculated in Figure 14.

5.3 NEUTRAL DENSITY ATTENUATORS

5.3.1 ATTENUATOR SELECTION

The values of the attenuators selected to perform the Calibration Error Test of Section 5.1 above are determined according to Section 7.1.2 of the CFR Title 40, Part 60, Appendix B, PS-1.

Low, mid, and high attenuators are chosen based on the analyzer full scale, and the automatic pathlength compensation (if any), and the availability of standard attenuator values. See Appendix A for the appropriate calculation used.

5.3.2 ATTENUATOR CALIBRATION

All attenuators were calibrated and maintained in accordance with all requirements of Section 7.1.3 of the Code of Federal Regulations Title 40, Part 60, Appendix B, Specification 1.

Certified calibration information is provided in Appendix B.

CALIBRATION ERROR TEST

Page 1 of 2

Date: 03/16/94

Customer

GRABBY / STI - LOUISIANA PACIFIC / CHILCO

Location of Test

GIBSONIA PA

Analyzer Manufacturer

UNITED SCIENCES INC.

Model Number

500C

Serial Number

0990724

Person Conducting Test

DEAN MURRAY

Person's Affiliation

UNITED SCIENCES

THE MONITORING SYSTEM IS NOT PATHLENGTH CORRECTED

Monitor calib. distance

9.479167 Feet

CALIBRATED NEUTRAL DENSITY ATTENUATOR VALUES

Serial Number	Stability Check Date	Certified Value Opacity	Corrected Value Opacity
NBS-026	1-6-94	22.50	22.50
NBS-003	1-6-94	59.80	59.80
NBS-039	1-6-94	85.70	85.70


CUSTOMER GRABBY / STISO# 015694DATE 9/14/94☐ NO EXCEPTIONS NOTED☐ EXCEPTIONS NOTED☐ RETURNED FOR CORRECTIONS☐ RECORD COPY☐ REVISE AND RESUBMIT☒ INFORMATION ONLY

BY

Joseph P. Zwick

UNITED SCIENCES, INC.

RUN NO.	ATTENUATOR VALUE (PATH ADJUSTED)	INSTRUMENT READING	DIFFERENCE READINGS		
			LOW	MID	HI
LOW1	22.50	22.20	-0.30	XXX	XXX
MID1	59.80	60.40	XXX	0.60	XXX
HI1	85.70	85.50	XXX	XXX	-0.20
LOW2	22.50	22.20	-0.30	XXX	XXX
MID2	59.80	60.50	XXX	0.70	XXX
HI2	85.70	86.00	XXX	XXX	0.30
LOW3	22.50	22.30	-0.20	XXX	XXX
MID3	59.80	60.40	XXX	0.60	XXX
HI3	85.70	86.40	XXX	XXX	0.70
LOW4	22.50	22.30	-0.20	XXX	XXX
MID4	59.80	60.50	XXX	0.70	XXX
HI4	85.70	86.40	XXX	XXX	0.70
LOW5	22.50	22.30	-0.20	XXX	XXX
MID5	59.80	60.50	XXX	0.70	XXX
HI5	85.70	86.20	XXX	XXX	0.50
ARITHMETIC MEAN=			-0.24	0.66	0.40
CONFIDENCE COEFFICIENT=			0.07	0.07	0.46
TOTAL ERROR=			0.31	0.73	0.86



CUSTOMER GRASEBY / S.I.
 SO # 015644
 DATE 9/14/94
☐ NO EXCEPTIONS NOTED
☐ EXCEPTIONS NOTED
☐ RETURNED FOR CORRECTIONS
☐ RECORD COPY
☐ REVISE AND RESUBMIT
☒ INFORMATION ONLY
 BY Joseph P. Zwick
 UNITED SCIENCES, INC.

FIGURE 14

RESPONSE TIME TEST

Serial Number

0993724

Calibration Distance

9' 5 3/4"

Date of Test

3-14-94

Place of Test

Gibson, Pa.

Test Personnel

Dean Murray

Data Display Device

Fluke Meter

Filter Value Used

89.5%

Upscale

1 2.66 seconds2 2.77 seconds3 1.57 seconds4 2.02 seconds5 1.99 seconds

Downscale

1 1.98 seconds2 1.63 seconds3 1.88 seconds4 2.68 seconds5 1.95 seconds

AVERAGE RESPONSE

2.113 seconds

CUSTOMER	GANSKY / STE
SO #	015634
DATE	9/14/94
☐ NO EXCEPTIONS NOTED ☐ EXCEPTIONS NOTED ☐ RETURNED FOR CORRECTIONS ☐ RECORD COPY ☐ REVISE AND RESUBMIT ☒ INFORMATION ONLY	
BY	Paul P. Zwickler
UNITED SCIENCES, INC.	

APPENDIX A

EQUATIONS USED

PROCEDURE FOR DETERMINING VALUES AND CONFIDENCE INTERVALS

The mean value of the data set is calculated according to Equation 1.

$$\bar{X} = \frac{1}{n} \sum_{i=1}^n X_i \quad \text{EQUATION 1}$$

Where:

X_i = Algebraic value of the individual measurements

n = Number of data points

$\bar{X}$ = Mean value of data points

The standard deviation is calculated according to Equation 2.

$$S_d = \sqrt{\frac{\sum_{i=1}^n X_i^2 - \frac{\left(\sum_{i=1}^n X_i\right)^2}{n}}{n-1}} \quad \text{EQUATION 2}$$

Where:

S_d = The standard deviation of the data set

The confidence coefficient is calculated according to Equation 3.

$$CC = t_{0.975} \frac{S_d}{\sqrt{n}} \quad \text{EQUATION 3}$$

Where:

CC = The confidence coefficient

$t_{0.975}$ = t value, see table on following page

The error is calculated according to Equation 4.

$$\text{Error} = |\bar{X}| + |CC| \quad \text{EQUATION 4}$$

VALUES FOR $t_{0.975}$

<u>n</u>	<u>$t_{0.975}$</u>
2	12.706
3	4.303
4	3.182
5	2.776
6	2.571
7	2.447
8	2.365
9	2.306
10	2.262
11	2.228
12	2.201
13	2.179
14	2.160
15	2.145
16	2.131

CONVERSION OF OPACITY VALUES FROM MONITOR PATH LENGTH TO EMISSION OUTLET PATH LENGTH

$$OP_e = 1 - [(1 - OP_m) STR] \quad \text{EQUATION 5}$$

$$OP_m = 1 - [(1 - OP_e)^{1/STR}] \quad \text{EQUATION 6}$$

Where: OP_e = Opacity at the Emission Outlet (expressed as a decimal).

OP_m = Opacity at the Monitor (expressed as a decimal).

STR = Stack Taper Ratio = $\frac{\text{Effluent Pathlength Emission Outlet}}{\text{Effluent Pathlength at the Monitor Location}}$

$$O.D._e = O.D._m (STR) \quad \text{EQUATION 7}$$

$$\frac{O.D._e}{STR} = O.D._m$$

Where: $O.D._e$ = Optical Density at Emission Outlet

$O.D._m$ = Optical Density at the Monitor

STR = See Above

APPENDIX B

CERTIFICATE OF ANALYSIS, NEUTRAL DENSITY
FILTERS

UNITED SCIENCES INC.

CERTIFIED NEUTRAL DENSITY ATTENUATOR
ANALYSIS REPORT

I. PURPOSE

This analysis was conducted in order to determine the CIE Daylight Luminous Transmittance and effective opacity of neutral density attenuators.

II. SPECTRAL TRANSMITTANCE MEASUREMENTS

Spectral transmittance measurements were performed using a laboratory scanning spectrophotometer whose specification meets or exceeds those described in the Code of Federal Regulations Title 40, Part 60, Appendix B, Specification 1, Section 3.4. Transmittance values were determined at 2 nanometer intervals over the range of 350 to 750 nanometers. Two scans are conducted on each attenuator. The second scan is conducted after rotating the attenuator 90 degrees from its original orientation.

The arithmetic mean of the transmittance at each wavelength measured is calculated and these data used to compute the overall transmittance and effective opacity. All attenuator calibration procedures were in accordance with CFR Title 40, Part 60, Appendix B, Specification 1, Section 7.1.3.

III. ACCURACY

The accuracy of the spectrophotometer is insured using the National Institute of Standards Technology Standard Reference Material 930D to assess its operation method, the NIST traceable calibration is certified to be within $\pm 0.5\%$ transmittance.

IV. STABILITY

In accordance with CFR Title 40, Part 60, Appendix B, Specification 1, Section 7.1.3, these attenuators must be returned to USI for checks of stability every three months in order to maintain valid attenuator certification. These stability checks are performed using a laboratory transmissometer, and any time the attenuator value as measured on the transmissometer varies by $\pm 2\%$ opacity the attenuator is recalibrated.

United Sciences inc.

5310 NORTH PIONEER ROAD • GIBSONIA, PA 15044 • 412 - 443-8610 • FAX 412 - 443-4025

CERTIFICATE OF ANALYSIS NEUTRAL DENSITY FILTERS

The enclosed calibration attenuators have been calibrated in accordance with Title 40 Code of Federal Regulations Part 60, Appendix B, Specification 1, Section 7.1.3.

These attenuators are certified to have the following opacity values:

<u>Serial Number</u>	<u>Opacity In Percent</u>	<u>Calibration Date</u>	<u>Stability Check Date</u>
<u>NBS001</u>	<u>21.0%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS002</u>	<u>30.5%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS003</u>	<u>59.8%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS004</u>	<u>86.4%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS006</u>	<u>77.7%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS007</u>	<u>74.9%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS008</u>	<u>64.6%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS009</u>	<u>35.5%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS010</u>	<u>8.7%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS011</u>	<u>46.1%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS012</u>	<u>77.6%</u>	<u>06/28/93</u>	<u>01/06/94</u>
<u>NBS024</u>	<u>91.7%</u>	<u>06/28/93</u>	<u>01/06/94</u>

SIGNATURE

Joseph P. Zickler

DATE

January 6, 1994

CUSTOMER

United Sciences Inc.

In-house Reference Filters - Set #1

5310 North Pioneer Road

Gibsonia, Pennsylvania 15044-9629

United Sciences inc.

5310 NORTH PIONEER ROAD • GIBSONIA, PA 15044 • 412 - 443-8610 • FAX 412 - 443-4025

CERTIFICATE OF ANALYSIS NEUTRAL DENSITY FILTERS

The enclosed calibration attenuators have been calibrated in accordance with Title 40 Code of Federal Regulations Part 60, Appendix B, Specification 1, Section 7.1.3.

These attenuators are certified to have the following opacity values:

<u>Serial Number</u>	<u>Opacity In Percent</u>	<u>Calibration Date</u>	<u>Stability Check Date</u>
NBS013	9.5%	01/06/94	01/06/94
NBS014	22.3%	01/06/94	01/06/94
NBS015	37.2%	01/06/94	01/06/94
NBS016	44.4%	01/06/94	01/06/94
NBS018	68.4%	01/06/94	01/06/94
NBS019	75.1%	01/06/94	01/06/94
NBS020	79.9%	01/06/94	01/06/94
NBS021	80.7%	01/06/94	01/06/94
NBS022	84.4%	01/06/94	01/06/94
NBS023	91.4%	01/06/94	01/06/94

SIGNATURE

DATE

CUSTOMER

Joseph P. Zwick

January 6, 1994

United Sciences Inc.

In-house Reference Filters - Set #2

5310 North Pioneer Road

Gibsonia, Pennsylvania 15044-9629

5310 NORTH PIONEER ROAD • GIBSONIA, PA 15044 • 412 - 443-8610 • FAX 412 - 443-4025

The enclosed calibration attenuators have been calibrated in accordance with Title 40 Code of Federal Regulations Part 60, Appendix B, Specification 1, Section 7.1.3.

These attenuators are certified to have the following opacity values:

[illegible]

SIGNATURE

Joseph P. Zwick

DATE _____

January 6, 1994

CUSTOMER

United Sciences Inc.

In-house Reference Filters - Set #3

5310 North Pioneer Road

Gibsonia, Pennsylvania 15044-9629

United Sciences inc.

5310 NORTH PIONEER ROAD • GIBSONIA, PA 15044 • 412 - 443-8610 • FAX 412 - 443-4025

CERTIFICATE OF ANALYSIS NEUTRAL DENSITY FILTERS

The enclosed calibration attenuators have been calibrated in accordance with Title 40 Code of Federal Regulations Part 60, Appendix B, Specification 1, Section 7.1.3.

These attenuators are certified to have the following opacity values:

<u>Serial Number</u>	<u>Opacity In Percent</u>	<u>Calibration Date</u>	<u>Stability Check Date</u>
047	8.9%	01/06/94	01/06/94
048	20.7%	01/06/94	01/06/94
049	60.2%	01/06/94	01/06/94
050	86.7%	01/06/94	01/06/94
051	89.5%	01/06/94	01/06/94

SIGNATURE

Joseph P. Zilchowski

DATE

January 6, 1994

CUSTOMER

United Sciences Inc.

In-house Reference Filters #6

5310 North Pioneer Road

Gibsonia, PA 15044-9629