

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 10.6.1

Background Report Section: 4

Reference Number: 60


**Title: Results Of The July 11-13, 1995 Air
Air Emission Compliance Tests At the
Louisian Pacific Waferboard Plant In
Tomahawk, Wisconsin**

Interpoll Laboratories, Inc.

July 1995

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020
FAX: (612) 786-7854



**RESULTS OF THE JULY 11 - 13, 1995
AIR EMISSION COMPLIANCE TESTS
AT THE LOUISIANA PACIFIC WAFERBOARD
PLANT IN TOMAHAWK, WISCONSIN**

Submitted to:

LOUISIANA PACIFIC CORPORATION
P.O. Box 190
Tomahawk, Wisconsin 54487

Attention:

Brion Petts

Approved by:

A handwritten signature in dark ink, appearing to read "Daniel J. Despen", written over a horizontal line.

Daniel J. Despen
Manager
Stationary Source Testing Department

Report Number 5-6006
July 18, 1995
KE/kce

TABLE OF CONTENTS

	ABBREVIATIONS	iii
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	4
3	AIR EMISSION RESULTS	9
	3.1 Results of Orsat and Moisture Determinations	10
	3.2 Results of Particulate Determinations	15
	3.3 Results of Oxides of Nitrogen Determinations	17
	3.4 Results of Carbon Monoxide Determinations	20
4	RESULTS OF FUEL ANALYSES	25

APPENDICES:

- A - Results of Volumetric Flow Rate Determinations
- B - Location of Test Ports
- C - Field Data Sheets
- D - Interpoll Laboratories Analytical Data
- E - Continuous Emission Monitor Printouts
- F - Analyzer Specifications
- G - Measurement Systems Performance Specifications
- H - Calibration Gas Certification Sheets
- I - Process Rate Information
- J - Procedures
- K - Calculation Equations
- L - Sampling Train Calibration Data

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.

1 INTRODUCTION

During the Period July 11 - 13, 1995 Interpoll Laboratories personnel conducted air emission compliance tests on the Dryers and Thermal Oil Heater at the Louisiana Pacific Corporation (LP) Waferboard Plant located in Tomahawk, Wisconsin. Testing was also conducted on the Press to gather data for permit revisions and establish informational data. On-site testing was performed by B. Aschenbach and T. Hansen. Coordination between testing activities and plant operation was provided by Brion Petts of LP. The test was witnessed by Biren Patel and Aaron Rosinski of the Wisconsin DNR.

The Dryers tested are Model 1260 TNW/L dryers manufactured by MEC Company. Particulate emissions from each dryer are controlled by a set of multicyclones installed in series with a E-TUBE wet electrostatic precipitator. Cleaned flue gas is emitted to the atmosphere by a 100-foot high radial steel stack which has a diameter of 59 inches.

The press vents tested are the exhaust from general ventilators positioned over the board press and unloader. The press and unloader vent exhausts are emitted to the atmosphere via a common stack which has a diameter of 62.5 inches.

The Thermal Oil Heater tested was manufactured by GEKA in 1992. It is equipped with a ram-type stoker and is fired with a mixture of wet bark and wood. The unit has a design heat input capacity of 30×10^6 BTU/HR. Particulate emissions from the GEKA are controlled by a large diameter cyclone in series with a fabric filter dust collector manufactured by C.E. Preheater. The baghouse has a pulsed air cleaning system. Cleaned flue gas is emitted to the atmosphere by a 75-foot high radial steel stack which has a diameter of 42 inches.

Particulate evaluations on the Press Vent were performed in accordance with EPA Methods 2-5, CFR Title 40, Part 60, Appendix A (revised July 1, 1994). A preliminary determination of the gas linear velocity profile was made before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a

heated glass-lined probe. Condensible particulate material samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with EPA Method 202.

Gas composition, carbon monoxide and oxides of nitrogen determinations were performed in accordance with Methods 3A, 7E and 10. A slip stream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice which was used to ensure that the flow from the stack exceeds the requirements of the analyzers. A three-way valve on the probe was used to introduce standard gas for the "system bias check".

The analog response of the analyzers was recorded with a data logger and strip chart recorder as backup. The analyzers were calibrated with Scott Specialty and National Specialty Gases EPA Protocol 1 or Certified Master standard gases. The instrument was calibrated before and after each run as per EPA Methods 3A, 7E and 10. The sample probe was moved through a three-point traverse (1/6, 3/6, 5/6 of the stack diameter) to measure oxides of nitrogen and carbon monoxide concentrations.

Particulate testing on the Press Vent was conducted from two test ports oriented at 90 degrees on the stack. These test ports are located 3.85 stack diameters downstream of the nearest flow disturbance and 3.85 diameters upstream of the stack exit. A 24-point traverse was used to collect the particulate samples. Each traverse point was sampled 2.5 minutes for a total sampling time of 60 minutes per run.

Volumetric flow rate testing at the Dryer Stack was conducted from two test ports oriented at 90 degrees on the stack. These test ports are located 5.0 stack diameters downstream of the nearest flow disturbance and 5.0 stack diameters upstream of the stack exit. A 20-point traverse was used to measure the flow rate.

Volumetric flow rate testing at the Thermal Oil Heater Stack was also conducted from two test ports oriented at 90 degrees on the stack. These test ports are located 6.1 stack

diameters from the nearest flow disturbance and 2.3 diameters from the stack exit. A 16-point traverse was used measure the flow rate.

A 3-point traverse was used at each test site to collect samples for oxides of nitrogen and carbon monoxide analyses. Each traverse point was sampled 20 minutes for a total sampling time of 60 minutes per run.

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The important results of the air emission compliance tests are summarized in Tables 1 - 4. A summary of the concentrations and emission rates is presented below:

<u>Parameter</u>	<u>LIMIT</u>	<u>MEASURED</u>
<u>PRESS VENT</u>		
Particulate (LB/HR)		
Press (dry + wet)	6.82	21.5
Press (dry)	-	5.04
Carbon monoxide (LB/TON FP)	0.2	0.45
Carbon monoxide (LB/HR)	2.52	4.84
<u>DRYER STACK</u>		
Oxides of Nitrogen (LB/HR)	10.6	10.1
Carbon monoxide		
Wood-fired (LB/TDF)	21.8	2.13
NG-fired (LB/10 ⁶ BTU)	0.69	0.13
<u>GEKA</u>		
Oxides of Nitrogen (LB/HR)	7.85	0.46
Carbon Monoxide (LB/TDF)	7.5	0.52

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples which were conducted by Interpoll Labs. On the basis of this fact and a complete review of the entire data and results, it is our opinion that the results reported herein are accurate and closely reflect the actual values which existed at the time the test was performed.

Table 1a. Summary of the Results of the July 13, 1995 Particulate Emission Compliance Test on the Press Vent at the Louisiana-Pacific OSB plant in Tomahawk, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-13-95	07-13-95	07-13-95
Time runs were done (HRS)	915/1016	1105/1206	1335/1436
Process rate (TON FP/HR)	10.9	10.9	10.9
Volumetric flow actual (ACFM) standard (DSCFM)	108004 92137	107819 91680	110413 93272
Gas temperature (DEG-F)	105	109	110
Moisture content (%V/V)	3.43	3.15	3.62
Gas composition (%V/V, dry) carbon dioxide oxygen nitrogen	0.03 20.90 79.07	0.03 20.90 79.07	0.03 20.90 79.07
Isokinetic variation (%)	98.6	99.3	100.0
Particulate concentration actual (GR/ACF) standard (GR/DSCF)	.008213 .009631	.004086 .004807	.003933 .004658
part. emission rate (LB/HR)	7.61	3.78	3.72

Note: Dry Catch Only

Table 1b Summary of the Results of the July 13, 1995 Particulate Emission Compliance Test on the Press Vent at the Louisiana-Pacific OSB plant in Tomahawk, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-13-95	07-13-95	07-13-95
Time runs were done (HRS)	915/1016	1105/1206	1335/1436
Process rate (TON FP/HR)	10.9	10.9	10.9
Volumetric flow actual (ACFM) standard (DSCFM)	108004 92137	107819 91680	110413 93272
Gas temperature (DEG-F)	105	109	110
Moisture content (%V/V)	3.43	3.15	3.62
Gas composition (%V/V, dry) carbon dioxide oxygen nitrogen	0.03 20.90 79.07	0.03 20.90 79.07	0.03 20.90 79.07
Isokinetic variation (%)	98.6	99.3	100.0
Particulate concentration actual (GR/ACF) standard (GR/DSCF)	.0298 .0349	.0336 .0396	.006111 .007236
part. emission rate (LB/HR)	27.56	31.08	5.79

Note: Dry + Method 202 Condensable Particulate Material

Table 3. Summary of the Oxides of Nitrogen Emission Determinations at the Louisiana Pacific Waferboard Plant in Tomahawk, Wisconsin.

Time	Concentration	Emission Rate	
	(ppm,d)	(LB/HR)	(LB/TDF)
(Dryer 7/12/95 - Wood fired)			
0745-0845	26	10.9	4.49
0900-1000	24	9.86	4.06
1145-1245	24	9.64	3.96
Avg.	25	10.1	4.17
(GEKA 7/12/95)			
1955-2055	50	4.44	4.31
2110-2210	45	3.71	3.60
2225-2325	41	3.46	3.36
Avg.	45	3.37	3.76

Note: TDF = Tons Dry Fuel (Dryer test - 2.43 TDF/HR, GEKA Test 1.03 TDF/HR)

Table 4.

Summary of the Carbon Monoxide Emission Determinations at the Louisiana Pacific Waferboard Plant in Tomahawk, Wisconsin.

	Concentration	Emission Rate		Emission Factor	
Time	(ppm,d)	(LB/HR)	(LB/TDF)	(LB/TFP)	(LB/10 ⁶ BTU)
(Dryer 7/11/95 - Natural gas fired)					
0800-0900	10.4	2.70			0.11
0920-1020	11.7	2.94			0.13
1040-1140	13.6	3.49			0.14
Avg.	11.9	3.04			0.13
(Dryer 7/12/95 - Wood fired)					
0745-0845	20.2	5.17	2.13		
0900-1000	17.2	4.25	1.75		
1145-1245	22.0	5.40	2.22		
Avg.	19.8	4.94	2.03		
(GEKA 7/12/95)					
1955-2055	10.2	0.54	0.52	-	0.022
2110-2210	7.80	0.40	0.39	-	0.018
2225-2325	8.80	0.45	0.44	-	0.020
Avg.	8.93	0.46	0.45	-	0.020
(Press 7/13/95)					
0915-1015	12.9	5.18	-	0.48	
1105-1205	13.6	5.44	-	0.50	
1335-1436	9.60	3.91	-	0.36	
Avg.	12.0	4.84	-	0.45	

Note: TDF = Tons Dry Fuel (Dryer test - 2.43 TDF/HR, GEKA Test 1.03 TDF/HR) TFP = Tons Finished Product (Press Test, 10.9 TFP/HR)

3 AIR EMISSION RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition and moisture are presented first followed by the computer printout of the particulate, oxides of nitrogen and carbon monoxide results. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in Extended BASIC specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs.

The emission rates have been calculated using the product of the concentration times flow method.

3.1 Results of Orsat and Moisture Determinations

Test No. 1
Dryer Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	07-11-95	07-11-95	07-11-95

Dry basis (orsat)

carbon dioxide.....	1.05	1.00	1.04
oxygen.....	19.70	19.74	19.63
nitrogen.....	79.25	79.26	79.33

Wet basis (orsat)

carbon dioxide.....	0.87	0.82	0.86
oxygen.....	16.35	16.20	16.29
nitrogen.....	65.78	65.05	65.84
water vapor.....	17.00	17.93	17.01
Dry molecular weight.....	28.96	28.95	28.95
Wet molecular weight.....	27.09	26.99	27.09
Specific gravity.....	0.936	0.932	0.936

FO	1.143	1.160	1.221
----	-------	-------	-------

Test No. 3
Thermal Oil Heater Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	07-12-95	07-12-95	07-12-95

Dry basis (orsat)

carbon dioxide.....	6.16	6.11	6.24
oxygen.....	14.18	14.41	14.29
nitrogen.....	79.66	79.48	79.47

Wet basis (orsat)

carbon dioxide.....	6.02	5.97	6.10
oxygen.....	13.86	14.09	13.97
nitrogen.....	77.85	77.72	77.71
water vapor.....	2.27	2.21	2.22
Dry molecular weight.....	29.55	29.55	29.57
Wet molecular weight.....	29.29	29.30	29.31
Specific gravity.....	1.012	1.012	1.013

FO	1.091	1.062	1.059
----	-------	-------	-------

Test No. 4
Press Vent Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	07-13-95	07-13-95	07-13-95

Dry basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07

Wet basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.18	20.24	20.14
nitrogen.....	76.36	76.58	76.21
water vapor.....	3.43	3.15	3.62
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.47	28.50	28.45
Specific gravity.....	0.983	0.984	0.983
Water mass flow.....(LB/HR)	9189	8367	9813

3.2 Results of Particulate Determinations

Test No. 4
Press Vent Stack

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-13-95	07-13-95	07-13-95
Time run start/end.....(HRS)	915/1016	1105/1206	1335/1436
Static pressure.....(IN.WC)	-1.70	-1.70	-1.70
Cross sectional area (SQ.FT)	21.31	21.31	21.31
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	16.0	17.0	18.0
desiccant.....(GRAMS)	20.0	16.0	21.0
total.....(GRAMS)	36.0	33.0	39.0
Total particulate material..			
.....collected(grams)	0.1080	0.1226	0.0230
Gas meter coefficient.....	0.9996	0.9996	0.9996
Barometric pressure..(IN.HG)	28.43	28.43	28.43
Avg. orif.pres.drop..(IN.WC)	2.26	2.36	2.42
Avg. gas meter temp..(DEF-F)	89.1	90.5	99.2
Volume through gas meter....			
at meter conditions...(CF)	51.99	52.20	54.35
standard conditions.(DSCF)	47.74	47.83	49.03
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.185	.185	.185
Avg.stack gas temp ..(DEG-F)	105	109	110
Volumetric flow rate.....			
actual.....(ACFM)	108004	107819	110413
dry standard.....(DSCFM)	92137	91680	93272
Isokinetic variation.....(%)	98.6	99.3	100.0
Particulate concentration...			
actual.....(GR/ACF)	0.02975	0.03362	0.00611
dry standard.....(GR/DSCF)	0.03489	0.03955	0.00724
Particle mass rate...(LB/HR)	27.555	31.081	5.785

3.3 Results of Oxides of Nitrogen Determinations

Interpoll Labs Report No. 5-6006
Louisiana-Pacific Corporation
Tomahawk, Wisconsin

Test No. 2
Dryer Stack (Wood-fired)

Results of Oxides of Nitrogen Determinations ~~Method 7E~~

	Run 1	Run 2	Run 3
Date of run	07-12-95	07-12-95	07-12-95
Time run start/end (HRS)	0745-0845	0900-1000	1145-1245
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	15.64	18.46	18.95 <i>17.68</i>
Oxygen Content (%V/V)	19.04	19.10	18.71
Volumetric flow rate (DSCFM)	58697	56619	56281 <i>57199</i>
Oxides of Nitrogen concentration (ppm,dry)	25.9	24.3	23.9
Oxides of Nitrogen emission rate (LB/HR)	10.9	9.86	9.64

Interpoll Labs Report No. 5-6006

Louisiana-Pacific Corporation

Tomahawk, Wisconsin

Test No. 3

GEKA Stack

Results of Oxides of Nitrogen Determinations-----**Method 7E**

	Run 1	Run 2	Run 3
Date of run	07-12-95	07-12-95	07-12-95
Time run start/end (HRS)	1955-2055	2110-2210	2225-2325
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	2.27	2.21	2.22
Oxygen Content (%V/V)	14.18	14.41	14.29
Volumetric flow rate (DSCFM)	12328	11625	11721
Oxides of Nitrogen concentration (ppm,dry)	50.3	44.5	41.2
Oxides of Nitrogen emission rate (LB/HR)	4.44	3.71	3.46

3.4 Results of Carbon Monoxide Determinations

Test No. 1
Dryer Stack (NG)

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-11-95	07-11-95	07-11-95
Time run start/end.....(HRS)	0800-0900	0920-1020	1040-1140
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	17.00	17.93	17.01
O2 Concentration.....(%V/V)	19.70	19.74	19.63
Volumetric flow rate (DSCFM)	59543	57517	58781
CO concentration.....			58619
(GR/DSCF).....	0.0053	0.0060	0.0069
(MG/DSCM).....	12.12	13.63	15.84
(PPM-WET).....	8.63	9.60	11.29
(PPM-DRY).....	10.40	11.70	13.60
CO emission rate.....(LB/HR)	2.701	2.935	3.487

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 2
Dryer Stack (Wood-fired)

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-12-95	07-12-95	07-12-95
Time run start/end.....(HRS)	0745-0845	0900-1000	1145-1245
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	15.64	18.46	18.95
O2 Concentration.....(%V/V)	19.04	19.10	18.71
Volumetric flow rate (DSCFM)	58697	56619	56281
CO concentration.....			
(GR/DSCF).....	0.0103	0.0088	0.0112
(MG/DSCM).....	23.53	20.04	25.63
(PPM-WET).....	17.04	14.02	17.83
(PPM-DRY).....	20.20	17.20	22.00
CO emission rate.....(LB/HR)	5.171	4.247	5.400

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value
is less than or equal to the reported value

Test No. 3
Thermal Oil Heater Stack

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-12-95	07-12-95	07-12-95
Time run start/end.....(HRS)	1955-2055	2110-2210	2225-2325
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	2.27	2.21	2.22
O2 Concentration.....(%V/V)	14.18	14.41	14.29
Volumetric flow rate (DSCFM)	12328	11625	11721
CO concentration.....			
(GR/DSCF).....	0.0052	0.0040	0.0045
(MG/DSCM).....	11.88	9.09	10.25
(PPM-WET).....	9.97	7.63	8.60
(PPM-DRY).....	10.20	7.80	8.80
CO emission rate.....(LB/HR)	0.548	0.395	0.450
CO emission factor.....(LB/MMBTU)	0.022	0.018	0.020

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value
is less than or equal to the reported value

Test No. 4
Press Vent Stack

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-13-95	07-13-95	07-13-95
Time run start/end.....(HRS)	0915-1016	1105-1206	1335-1436
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	3.43	3.15	3.62
O2 Concentration.....(%V/V)	20.90	20.90	20.90
Volumetric flow rate (DSCFM)	92137	91680	93272
CO concentration.....			
(GR/DSCF).....	0.0066	0.0069	0.0049
(MG/DSCM).....	15.03	15.84	11.18
(PPM-WET).....	12.46	13.17	9.25
(PPM-DRY).....	12.90	13.60	9.60
CO emission rate.....(LB/HR)	5.184	5.438	3.905

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

4 RESULTS OF FUEL ANALYSES

INTERPOLL LABORATORIES, INC.
Fuel Laboratory
(612) 786-6020


7/31/95

Client: L.P. TOMAHAWK
Laboratory Log Number: 6006-01-9208
Source: Dryer
Sample Identification: WOOD

Ultimate Analysis WT %

Parameter	Moisture & Ash Free	Moisture Free	As Received
Moisture, Total			3.65
Ash		0.72	0.70
Carbon	50.12	49.76	47.94
Hydrogen	6.01	5.97	5.75
Nitrogen	0.30	0.30	0.29
Oxygen (calculated)	43.54	43.22	41.64
Sulfur	0.03	0.03	0.03
Heating Value, BTU/LB	8082	8023	7730

Respectfully submitted,



Jeannie F. O'Neil, Manager
Inorganic Chemistry Group

9726

INTERPOLL LABORATORIES, INC.

Fuel Laboratory
(612) 786-6020


7/31/95

Client: L.P. TOMAHAWK
Laboratory Log Number: 6006-02-9209
Source: Dryer
Sample Identification: BARK

Ultimate Analysis WT %

Parameter	Moisture & Ash Free	Moisture Free	As Received
Moisture, Total			38.71
Ash		3.73	2.29
Carbon	52.14	50.19	30.76
Hydrogen	6.11	5.88	3.60
Nitrogen	0.81	0.78	0.48
Oxygen (calculated)	40.88	39.35	24.12
Sulfur	0.06	0.06	0.06
Heating Value, BTU/LB	8455	8139	4988

Respectfully submitted,


Jeannie F. O'Neil, Manager
Inorganic Chemistry Group

9860

APPENDIX A

RESULTS OF VOLUMETRIC FLOW RATE DETERMINATIONS

Test No. 1
Dryer Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-11-95
Time of Determination.....(HRS)	800
Barometric pressure.....(IN.HG)	28.62
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	20
Shape of duct.....	Round
Stack diameter.....(IN)	59
Duct area.....(SQ.FT)	18.99
Direction of flow.....	UP
Static pressure.....(IN.WC)	-1.04
Avg. gas temp.....(DEG-F)	133
Moisture content.....(% V/V)	17.00
Avg. linear velocity.....(FT/SEC)	74.1
Gas density.....(LB/ACF)	.05976
Molecular weight.....(LB/LBMOLE)	28.96
Mass flow of gas.....(LB/HR)	302848
Volumetric flow rate.....	
actual.....(ACFM)	84456
dry standard.....(DSCFM)	59543

Test No. 1
Dryer Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-11-95
Time of Determination.....(HRS)	920
Barometric pressure.....(IN.HG)	28.62
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	20
Shape of duct.....	Round
Stack diameter.....(IN)	59
Duct area.....(SQ.FT)	18.99
Direction of flow.....	UP
Static pressure.....(IN.WC)	-1.13
Avg. gas temp.....(DEG-F)	135
Moisture content.....(% V/V)	17.93
Avg. linear velocity.....(FT/SEC)	72.7
Gas density.....(LB/ACF)	.05931
Molecular weight.....(LB/LBMOLE)	28.95
Mass flow of gas.....(LB/HR)	294684
Volumetric flow rate.....	
actual.....(ACFM)	82803
dry standard.....(DSCFM)	57517

Test No. 1
Dryer Stack

Results of Volumetric Flow Rate Determination-----Method 2

Method 2

Date of Determination.....	07-11-95	07-12-95
Time of Determination.....(HRS)	1040	745
Barometric pressure.....(IN.HG)	28.62	28.52
Pitot tube coefficient.....	.84	.84
Number of sampling ports.....	2	2
Total number of points.....	20	20
Shape of duct.....	Round	Round
Stack diameter.....(IN)	59	59
Duct area.....(SQ.FT)	18.99	18.99
Direction of flow.....	UP	UP
Static pressure.....(IN.WC)	-1.14	-1.04
Avg. gas temp.....(DEG-F)	133	135
Moisture content.....(% V/V)	17.01	15.64
Avg. linear velocity.....(FT/SEC)	73.2	72.4
Gas density.....(LB/ACF)	.05974	.05986
Molecular weight.....(LB/LBMOLE)	28.95	29.05
Mass flow of gas.....(LB/HR)	298954	296230
Volumetric flow rate.....		
actual.....(ACFM)	83406	82478
dry standard.....(DSCFM)	58781	58697

83555

Test No. 2
Dryer Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-95
Time of Determination.....(HRS)	900
Barometric pressure.....(IN.HG)	28.52
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	20
Shape of duct.....	Round
Stack diameter.....(IN)	59
Duct area.....(SQ.FT)	18.99
Direction of flow.....	UP
Static pressure.....(IN.WC)	-1.05
Avg. gas temp.....(DEG-F)	136
Moisture content.....(% V/V)	18.46
Avg. linear velocity.....(FT/SEC)	72.4
Gas density.....(LB/ACF)	.05909
Molecular weight.....(LB/LBMOLE)	29.06
Mass flow of gas.....(LB/HR)	292331
Volumetric flow rate.....	
actual.....(ACFM)	82451
dry standard.....(DSCFM)	56619

Test No. 2
Dryer Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-95
Time of Determination.....(HRS)	1145
Barometric pressure.....(IN.HG)	28.52
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	20
Shape of duct.....	Round
Stack diameter.....(IN)	59
Duct area.....(SQ.FT)	18.99
Direction of flow.....	UP
Static pressure.....(IN.WC)	-1.06
Avg. gas temp.....(DEG-F)	137
Moisture content.....(% V/V)	18.95
Avg. linear velocity.....(FT/SEC)	72.5
Gas density.....(LB/ACF)	.05889
Molecular weight.....(LB/LBMOLE)	29.07
Mass flow of gas.....(LB/HR)	291859
Volumetric flow rate.....	
actual.....(ACFM)	82595
dry standard.....(DSCFM)	56281

Test No. 3
GEKA Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-95
Time of Determination.....(HRS)	1955
Barometric pressure.....(IN.HG)	28.43
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.24
Avg. gas temp.....(DEG-F)	348
Moisture content.....(% V/V)	3.98
Avg. linear velocity.....(FT/SEC)	35.8
Gas density.....(LB/ACF)	.04688
Molecular weight.....(LB/LBMOLE)	29.55
Mass flow of gas.....(LB/HR)	58200
Volumetric flow rate.....	
actual.....(ACFM)	20690
dry standard.....(DSCFM)	12328

Test No. 3
GEKA Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-95
Time of Determination.....(HRS)	2110
Barometric pressure.....(IN.HG)	28.43
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.26
Avg. gas temp.....(DEG-F)	351
Moisture content.....(% V/V)	16.06
Avg. linear velocity.....(FT/SEC)	38.8
Gas density.....(LB/ACF)	.04447
Molecular weight.....(LB/LBMOLE)	29.55
Mass flow of gas.....(LB/HR)	59770
Volumetric flow rate.....	
actual.....(ACFM)	22402
dry standard.....(DSCFM)	11625

Test No. 3
GEKA Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-95
Time of Determination.....(HRS)	2225
Barometric pressure.....(IN.HG)	28.43
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.24
Avg. gas temp.....(DEG-F)	348
Moisture content.....(% V/V)	16.01
Avg. linear velocity.....(FT/SEC)	39.0
Gas density.....(LB/ACF)	.04467
Molecular weight.....(LB/LBMOLE)	29.57
Mass flow of gas.....(LB/HR)	60271
Volumetric flow rate.....	
actual.....(ACFM)	22490
dry standard.....(DSCFM)	11721


Test No. 4
Press Vent Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-13-95
Time of Determination.....(HRS)	900
Barometric pressure.....(IN.HG)	28.43
Pitot tube coefficient.....	.84
Number of sampling ports.....	1
Total number of points.....	12
Shape of duct.....	Round
Stack diameter.....(IN)	62.5
Duct area.....(SQ.FT)	21.31
Direction of flow.....	UP
Static pressure.....(IN.WC)	-1.7
Avg. gas temp.....(DEG-F)	104
Moisture content.....(% V/V)	3.60
Avg. linear velocity.....(FT/SEC)	81.9
Gas density.....(LB/ACF)	.06542
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	410891
Volumetric flow rate.....	
actual.....(ACFM)	104674
dry standard.....(DSCFM)	89370

APPENDIX B


LOCATION OF TEST PORTS



L-P TOMAHAWK
THERMAL OIL HEATER STACK

20,000 - 32,600 ACFM
250 - 350° F

N.T.S.




APPENDIX C
FIELD DATA SHEETS

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP/Tomahawk
Source Dryer Stack
Test 1 Run 1 Date 7-11-95
Stack Dimen. 59 IN.
Dry Bulb 133 °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.62 IN.HG
Static Pressure -1.04 IN.WC
Operators B. Exenbach T. Hansen
Pitot No. 270-8 C. 1.84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4.25</u> IN.		Time Start: <u>0800</u> HRS	
B-1	.026	1.534	5.784	1.28	
2	.082	4.838	9.088	1.36	
3	.146	8.614	12.864	1.48	
4	.226	13.334	17.584	1.58	
5	.342	20.178	24.428	1.53	
6	.658	38.822	43.072	1.63	
7	.774	45.666	49.916	1.52	
8	.854	50.386	54.636	1.30	
9	.918	54.162	58.412	1.26	
10	.974	57.466	61.716	1.09	
C-1				1.14	
2				1.42	
3				1.56	
4				1.46	
5				1.58	
6				1.47	
7				1.39	
8				1.43	
9				1.34	
10				1.14	
		Avg $\sqrt{P}$	1.1769		
		ST	133		
		FRS	74.01213		
		ACFM	84311.19		
		DSCFM	59441.35		
Temp. Meas. Device & S/N: <u>PDT 33</u>				Time End: <u>0900</u> HRS	


R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACKWP\FORMS\S-392.1

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Job CP/ TONALUX
 Source Dryer STAC
 Test 1 Run 2 Date 2-11-85
 Stack Dimen. 53 IN.
 Dry Bulb 135 °F Wet bulb _____ °F
 Manometer ☐ Reg. ☐ Exp. ☒ Elec.
 Barometric Pressure 28.62 IN.HG
 Static Pressure -1.13 IN.WC
 Operators B. A. Hansen
 Pitot No. 22-8 C_p .84

Drawing of Test Site



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4.25</u> IN.		Time Start: <u>0920</u> HRS	
C-1				1.18	
2				1.29	
3				1.37	
4				1.35	
5				1.33	
6				1.42	
7				1.38	
8				1.36	
9				1.32	
10				1.02	
B-1				1.07	
2				1.32	
3				1.37	
4				1.40	
5				1.49	
6				1.46	
7				1.26	
8				1.48	
9				1.49	
10				1.15	
		Avg $\sqrt{P}$	<u>1.1515</u>		
		ST	<u>135</u>		
		FPS	<u>72.68837</u>		
		ACFM	<u>82803.72</u>		
		DSCFM	<u>57516.7</u>		
Temp. Meas. Device & S/N: <u>PDT 33</u>				Time End: <u>1020</u> Hrs	


R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:STACKWPAFORMSS-392.1

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP / Tomahawk
 Source Dryer Stack
 Test 1 Run 3 Date 7-11-85
 Stack Dimen. 59 IN.
 Dry Bulb 133 °F Wet bulb _____ °F
 Manometer ☐ Reg. ☐ Exp ☒ Elec.
 Barometric Pressure 28.62 IN.HG
 Static Pressure -1.14 IN.WC
 Operators B. Aschbach T. Hansen
 Pitot No. 270-8 C_p .84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4.25</u> IN.		Time Start: <u>1040</u> HRS	
C - 1				1.17	
2				1.32	
3				1.49	
4				1.43	
5				1.32	
6				1.47	
7				1.42	
8				1.39	
9				1.25	
10				1.11	
B - 1				1.19	
2				1.40	
3				1.42	
4				1.48	
5				1.61	
6				1.41	
7				1.43	
8				1.38	
9				1.34	
10				1.22	
		Avg $\sqrt{D}$	1.144092		
		ST	133		
		PPS	73.21785		
		ACFM	83406.38		
		DSCFM	58781.2		
Temp. Meas. Device & S/N: <u>PDT 33</u>				Time End: <u>1140</u> HRS	

R or notbing = reg. manometer; S = expanded; E = electronic

EPA Method 4 and 6 Field Data Sheet

Job LP / Tama Hawk
 Source Dryer Sinter
 Date 7-1-85 Test 1 Run 1
 Wet Bulb _____
 Dry Bulb _____

Operator(s) BA TH
 Meter Box No. 1041 Gasmeter Coef. 9950
 $\Delta H@$ _____ in.WC Bar.Press 28.62
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.10 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cc)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(0800)	(82.860)									
1	5	783.063	1000 cc	2	133	236	—	—	68	—	—
1	10	783.214	1000 cc	2	133	238	—	—	68	—	—
1	15	783.423	1000 cc	2	133	240	—	—	68	—	—
1	20	783.635	1000 cc	2	133	237	—	—	68	—	—
2	25	783.841	1000 cc	2	133	242	—	—	68	—	—
2	30	784.028	1000 cc	2	133	242	—	—	68	—	—
2	35	784.226	1000 cc	2	133	240	—	—	68	—	—
2	40	784.430	1000 cc	2	133	238	—	—	68	—	—
3	45	784.620	1000 cc	2	133	241	—	—	68	—	—
3	50	784.825	1000 cc	2	133	243	—	—	68	—	—
3	55	785.017	1000 cc	2	133	245	—	—	68	—	—
3	60	785.225	1000 cc	2	133	243	—	—	68	—	—
	(0800)										
	0-60	$V_m = 2.365$	$\Delta H = 1000 cc$		133				68		

Condensate Data: Free Moisture

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	210	200	10
Desiccant	1558	1553	5
	Total		15

Preliminary Results of SO ₂ Concentration Determination	
V _m =	2.25 DSCF
Moisture Gravimetric =	17.00 %v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job CP / Tomahawk
 Source Dryer / STARS
 Date 2-11-95 Test 1 Run 2
 Wet Bulb _____
 Dry Bulb _____

Operator(s) GA JH
 Meter Box No. CEM 1 Gasmeter Coef. .9950
 $\Delta H@$ _____ in.WC Bar.Press 28.62 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cc)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(0920)	(785.300)									
1	5	785.500	1000 cc	2	135	237	—	—	68	—	—
1	10	785.698	1000 cc	2	135	240	—	—	68	—	—
1	15	785.893	1000 cc	2	135	243	—	—	68	—	—
1	20	786.088	1000 cc	2	135	241	—	—	68	—	—
2	25	786.283	1000 cc	2	135	239	—	—	68	—	—
2	30	786.471	1000 cc	2	135	241	—	—	68	—	—
2	35	786.661	1000 cc	2	135	241	—	—	68	—	—
2	40	786.853	1000 cc	2	135	240	—	—	68	—	—
3	45	787.050	1000 cc	2	135	243	—	—	68	—	—
3	50	787.243	1000 cc	2	135	241	—	—	68	—	—
3	55	787.437	1000 cc	2	135	237	—	—	68	—	—
3	60	787.622	1000 cc	2	135	240	—	—	68	—	—
	(1020)										
	0-60	V _m = 2.322	$\Delta H = 1000 cc$		135				68		

Condensate Data: Free Moisture

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	210	200	10
Desiccant	1390	1387	3
	Total		13

Preliminary Results of SO ₂ Concentration Determination		
V _m =	2.20	DSCF
Moisture Gravimetric =	17.93	%v/v
Moisture Psychrometric =		%v/v
SO ₂ , DRY =		PPM
SO ₂ , WET =		PPM
LB/MMBtu =		

EPA Method 4 and 6 Field Data Sheet

Job CP / Tomahawk
 Source Dryer Stack
 Date 7-11-95 Test 1 Run 3
 Wet Bulb _____
 Dry Bulb _____

Operator(s) SA TH
 Meter Box No. CEM 1 Gasmeter Coef. .9950
 ΔH@ _____ in.WC Bar.Press 28.62
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(1040)	(787.760)									
1	5	787.881	1000 cc	2	133	239	—	—	68	—	—
1	10	788.091	1000 cc	2	133	241	—	—	68	—	—
1	15	788.274	1000 cc	2	133	247	—	—	68	—	—
1	20	788.476	1000 cc	2	133	247	—	—	68	—	—
2	25	788.673	1000 cc	2	133	246	—	—	68	—	—
2	30	788.860	1000 cc	2	133	250	—	—	68	—	—
2	35	789.066	1000 cc	2	133	248	—	—	68	—	—
2	40	789.255	1000 cc	2	133	245	—	—	68	—	—
3	45	789.456	1000 cc	2	133	247	—	—	68	—	—
3	50	789.645	1000 cc	2	133	251	—	—	68	—	—
3	55	789.848	1000 cc	2	133	249	—	—	68	—	—
3	60	790.044	1000 cc	2	133	250	—	—	68	—	—
	(1140)										
	0-60	V _m = 2.344	ΔP = 1000 cc		133				68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	208	200	8
Desiccant	1560	1558	2
	Total		10

Preliminary Results of SO ₂ Concentration Determination	
V _m = 2.23	DSCF
Moisture Gravimetric = 17.01	%v/v
Moisture Psychrometric =	%v/v
SO ₂ , DRY =	PPM
SO ₂ , WET =	PPM
LB/MMBtu =	

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP / Tomahawk
Source Dryer Smelt
Test 2 Run/4 Date 7-12-95
Stack Dimen. 59 IN.
Dry Bulb 135 °F Wet bulb 134 °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.52 IN.HG
Static Pressure -1.04 IN.WC
Operators S. Schenck Troy Hansen
Pitot No. 27U-8 C .84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4.25</u> IN.	Time Start: <u>0745</u> HRS		
C-1				1.12	
2				1.32	
3				1.42	
4				1.42	
5				1.42	
6				1.39	
7				1.41	
8				1.32	
9				1.29	
10				1.14	
B-1				1.14	
2				1.39	
3				1.41	
4				1.43	
5				1.46	
6				1.45	
7				1.40	
8				1.34	
9				1.28	
10				1.16	
		Avg VP	1.15342		
		ST	135		
		FPS	72.46978		
		ACFM	82554.21		
		DSCFM	58750.91		
Temp. Meas. Device & S/N: <u>POT 33</u>				Time End: <u>0845</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP/ Tomahawk
 Source Dryer Stack
 Test 2 Run 2A Date 7-12-85
 Stack Dimen. 59 IN.
 Dry Bulb 136 °F Wet bulb _____ °F
 Manometer ☐ Reg. ☐ Exp ☒ Elec.
 Barometric Pressure 28.52 IN.HG
 Static Pressure -1.05 IN.WC
 Operators B. Schuler & T. Hansen
 Pitot No. 270-8 C. .84

Cross-section View	Elevation View

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4.25</u> IN.	Time Start: <u>0900</u> HRS		
1				1.15	
2				1.28	
3				1.32	
4				1.41	
5				1.40	
6				1.38	
7				1.38	
8				1.35	
9				1.29	
10				1.16	
1				1.16	
2				1.27	
3				1.37	
4				1.37	
5				1.41	
6				1.33	
7				1.38	
8				1.40	
9				1.29	
10				1.14	
		Avg $\sqrt{D}$	1.14451		
		ST	136		
		FPS	22.37531		
		ACFM	82446.6		
		DSCFM	56616.34		
Temp. Meas. Device & S/N: <u>PDT 33</u>				Time End: <u>1000</u> HR.	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-GASTACKWPFORM55-392.1

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CD / Tomahawk
Source Dryer Stack
Test 2 Run 3A Date: _____
Stack Dimen. 59 IN.
Dry Bulb 137 °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp. ☒ Elec.
Barometric Pressure 28.52 IN.HG
Static Pressure -1.06 IN.WC
Operators B. Kucharski - T. Harker
Pitot No. 270-8 C_p .88

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4.25</u> IN.		Time Start: <u>1145</u> HRS	
C-1				1.13	
2				1.29	
3				1.33	
4				1.35	
5				1.39	
6				1.40	
7				1.35	
8				1.32	
9				1.31	
10				1.13	
B-1				1.18	
2				1.29	
3				1.38	
4				1.40	
5				1.42	
6				1.42	
7				1.38	
8				1.39	
9				1.29	
10				1.16	
		Avg √P	1.114123		
		ST	1.37		
		FPS	72.47606		
		ACFM	82561.36		
		DSCFM	56758.6		
Temp. Meas. Device & S/N: <u>POT 33</u>				Time End: <u>1245</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

EPA Method 4 and 6 Field Data Sheet

Job CP / Tomahawks
 Source Dryer Sinec
 Date 7-12-95 Test 2 Run 1A
 Wet Bulb _____
 Dry Bulb _____

Operator(s) SA TH
 Meter Box No. 1001 Gasmeter Coef. 9950
 $\Delta H@$ _____ in.WC Bar.Press 28.52
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(0745)	(794.975)									
	5	795.212	1000cc	2		240	-	47	68	-	-
	10	795.400	1000cc	2		243	-	45	68	-	-
	15	795.588	1000cc	2		239	-	43	68	-	-
	20	795.802	1000cc	2		241	-	43	68	-	-
	25	795.992	1000cc	2		243	-	41	68	-	-
	30	796.222	1000cc	2		240	-	39	68	-	-
	35	796.390	1000cc	2		247	-	39	68	-	-
	40	796.558	1000cc	2		250	-	37	68	-	-
	45	796.726	1000cc	2		245	-	39	68	-	-
	50	796.985	1000cc	2		247	-	38	68	-	-
	55	797.193	1000cc	2		250	-	38	68	-	-
	60	797.385	1000cc	2		248	-	39	68	-	-
	(0845)										
	0-60	V _m = 2.410	ΔP = 100cc		F =				E = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	206	200	6
Desiccant	1561	1558	3
	Total		9

Preliminary Results of SO ₂ Concentration Determination	
V _{ad} =	2.28 DSCF
Moisture Gravimetric =	15.64 %v/v
Moisture Psychrometric =	%v/v
SO ₂ , DRY =	PPM
SO ₂ , WET =	PPM
LB/MMBtu =	

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job LP / Tomahawk
 Source Dryer Stack
 Date 7-12-95 Test 2 Run 2A
 Wet Bulb _____
 Dry Bulb _____

Operator(s) BA TH
 Meter Box No. CEM1 Gasmeter Coef. .9950
 $\Delta H@$ _____ in.WC Bar.Press 28.52 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	(%v/v)
	(0900)	(797.463)									
1	5	797.650	1000 cc	2		245	-	39	68	-	-
1	10	797.852	1000 cc	2		247	-	39	68	-	-
1	15	798.052	1000 cc	2		250	-	42	68	-	-
1	20	798.241	1000 cc	2		246	-	41	68	-	-
2	25	798.430	1000 cc	2		237	-	40	68	-	-
2	30	798.640	1000 cc	2		240	-	38	68	-	-
2	35	798.848	1000 cc	2		238	-	37	68	-	-
2	40	799.039	1000 cc	2		240	-	37	68	-	-
3	45	799.231	1000 cc	2		237	-	39	68	-	-
3	50	799.440	1000 cc	2		240	-	38	68	-	-
3	55	799.634	1000 cc	2		238	-	41	68	-	-
3	60	799.838	1000 cc	2		240	-	40	68	-	-
	(1000)										
	0 - 60	3.375	$\Delta H = 1000 cc$		5 -				5 - 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	208	200	8
Desiccant	1395	1390	5
	Total		13

Preliminary Results of SO ₂ Concentration Determination	
V _{std} =	2.25 DSCF
Moisture Gravimetric =	18.46 %v/v
Moisture Psychrometric =	%v/v
SO ₂ , DRY =	PPM
SO ₂ , WET =	PPM
LB/MMBtu =	

EPA Method 4 and 6 Field Data Sheet

Job LP / Towne Hawk
 Source Dryer Smelt
 Date 7-12-95 Test 2 Run 3a
 Wet Bulb _____
 Dry Bulb _____

Operator(s) SA TH
 Meter Box No. COM 1 Gasmeter Coef. .9950
 $\Delta H@$ _____ in.WC Bar.Press 28.52
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 6.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cc)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(1145)	(799.884)									
1	5	800.091	1000 cc	2		247	-	45	68	-	-
1	10	800.278	1000 cc	2		251	-	43	68	-	-
1	15	800.476	1000 cc	2		250	-	43	68	-	-
1	20	800.673	1000 cc	2		244	-	40	68	-	-
2	25	800.868	1000 cc	2		247	-	39	68	-	-
2	30	801.063	1000 cc	2		247	-	38	68	-	-
2	35	801.254	1000 cc	2		250	-	39	68	-	-
2	40	801.452	1000 cc	2		244	-	41	68	-	-
3	45	801.650	1000 cc	2		248	-	43	68	-	-
3	50	801.845	1000 cc	2		250	-	40	68	-	-
3	55	802.031	1000 cc	2		249	-	38	68	-	-
3	60	802.228	1000 cc	2		250	-	40	68	-	-
	(1245)										
	0 - 60	V _m = 2.344	$\Delta H = 1000$ cc		F =				E = 68		

Condensate Data:


Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	209	200	9
Desiccant	1420	1417	3
	Total		12

Preliminary Results of SO ₂ Concentration Determination	
V _m =	2.22 DSCF
Moisture Gravimetric =	18.95 %v/v
Moisture Psychrometric =	%v/v
SO ₂ , DRY =	PPM
SO ₂ , WET =	PPM
LB/MMBtu =	

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job UP / Tomahawk
Source GEIA Stack
Test 3 Run 8 Date 7-12-75
Stack Dimen. 42 IN.
Dry Bulb 33.2 °F Wet bulb 14.6 °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.43 IN.HG
Static Pressure - .28 IN.WC
Operators B. A. K. back T. Hansen
Pitot No. 27-4 C. .84

[illegible]

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\392.1

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Job CP / Tomahawk
 Source CEKA Stack
 Test 3 Run 1 Date 7-12-95
 Stack Dimen. 42 IN.
 Dry Bulb 34.8 °F Wet bulb 14.7 °F
 Manometer ☐ Reg. ☐ Exp. ☒ Elec.
 Barometric Pressure 28.93 IN.HG
 Static Pressure -.24 IN.WC
 Operators B. Schenker & T. Hansen
 Pitot No. 270-4 C. .84

Drawing of Test Site

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>1.75</u> IN.	Time Start: <u>1955</u> HRS		
A-1	.032	1.344	3.094	.19	
2	.105	4.41	6.16	.23	
3	.194	8.148	9.898	.26	
4	.323	13.566	15.316	.26	
5	.677	28.434	30.184	.28	
6	.806	33.852	35.602	.27	
7	.895	37.590	39.340	.25	
8	.968	40.656	42.406	.19	
B-1				.24	
2				.30	
3				.34	
4				.34	
5				.29	
6				.26	
7				.22	
8				.19	
		Avg VP	548183		
		ST	348		
		FPS	35.84185		
		ACFM	20690.32		
		DSCFM	12328.13		
Temp. Meas. Device & S/N: <u>PDT 33</u>					
				Time End: <u>2055</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:STACK\WP\FORMS\S-392.1

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP/ Tomahawk
Source GETCO STATION
Test 3 Run 2 Date 7-12-93
Stack Dimen. 42 IN.
Dry Bulb 351 °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☒ Elec.
Barometric Pressure 28.43 IN.HG
Static Pressure -1.26 IN.WC
Operators S. Schenck T. Hansen
Pitot No. 270-4 C₂ .84

Cross-section View	Elevation View

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: 1.75 IN.		Time Start: 2110 HRS	
B-1				.22	
2				.27	
3				.29	
4				.31	
5				.34	
6				.36	
7				.32	
8				.23	
B-1				.28	
2				.33	
3				.35	
4				.33	
5				.28	
6				.24	
7				.22	
8				.20	
		Avg VP	.5323305		
		ST	351		
		FPS	38-80781		
		ACFM	22402.47		
		DSCFM	11025.27		
Temp. Meas. Device & S/N: PPT 33				Time End: 2200 HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Job CP/Tomahawk
 Source GERA STALK
 Test 3 Run 3 Date 7-72-95
 Stack Dimen. 42 IN.
 Dry Bulb 34.8 °F Wet bulb _____ °F
 Manometer ☐ Reg. ☐ Exp. ☐ Elec.
 Barometric Pressure 28.43 IN.HG
 Static Pressure -.24 IN.WC
 Operators B. Schleich T. Hansen
 Pitot No. 220-4 C-84

Drawing of Test Site

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>1.75</u> IN.	Time Start: <u>2225</u> HRS		
C 1				.22	
2				.26	
3				.28	
4				.28	
5				.34	
6				.35	
7				.31	
8				.27	
B-1 1				.24	
2				.34	
3				.35	
4				.36	
5				.30	
6				.26	
7				.24	
8				.22	
Avg $\sqrt{D}$				535394	
ST				348	
FPS				38.95443	
ACFM				22487.12	
DSCPM				11220.05	
Temp. Meas. Device & S/N: <u>PDT 33</u>				Time End: <u>2325</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job LD/ Tomahawk
 Source GOCA STATION
 Date 7-12-95 Test 3 Run /
 Wet Bulb _____
 Dry Bulb 332

Operator(s) SA TT
 Meter Box No. 1211 Gasometer Coef. .9950
 $\Delta H@$ _____ in.WC Bar.Press 28.43 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cc)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(1955)	(802.321)									
1	5	802.500	1000 cc	2		243	-	48	68	-	-
1	10	802.710	1000 cc	2		248	-	45	68	-	-
1	15	802.902	1000 cc	2		250	-	43	68	-	-
1	20	803.105	1000 cc	2		251	-	40	68	-	-
2	25	803.314	1000 cc	2		248	-	38	68	-	-
2	30	803.509	1000 cc	2		250	-	37	68	-	-
2	35	803.710	1000 cc	2		251	-	39	68	-	-
2	40	803.911	1000 cc	2		247	-	41	68	-	-
3	45	804.110	1000 cc	2		250	-	38	68	-	-
3	50	804.315	1000 cc	2		247	-	39	68	-	-
3	55	804.511	1000 cc	2		248	-	37	68	-	-
3	60	804.724	1000 cc	2		250	-	39	68	-	-
	(2055)										
	0-60	V _m = 2.463	ΔH = 1000 cc	5-					E = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	202	200	2
Desiccant	1395	1395	0
		Total	2

Preliminary Results of SO ₂ Concentration Determination		
V _{ad} =	2.27	DSCF
Moisture Gravimetric =	3.98	%v/v
Moisture Psychrometric =		%v/v
SO ₂ DRY =		PPM
SO ₂ WET =		PPM
LB/MMBtu =		

EPA Method 4 and 6 Field Data Sheet

Job LP/Tomahawk
 Source GEKA STAIL
 Date 7-12-95 Test 3 Run 2
 Wet Bulb _____
 Dry Bulb _____

Operator(s) SA TM
 Meter Box No. COM 1 Gasmeter Coef. .8950
 $\Delta H@$ _____ in.WC Bar.Press 28.43 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: 0.0 cfm at 15 in.WC ☒

Trav. Point No.	Sample Time (min)	Sample Volume (cc)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(2110)	(804.826)									
1	5	805.018	1000 cc	2		248	-	39	68	-	-
1	10	805.210	1000 cc	2		250	-	37	68	-	-
1	15	805.400	1000 cc	2		251	-	40	68	-	-
1	20	805.600	1000 cc	2		250	-	38	68	-	-
2	25	805.797	1000 cc	2		247	-	37	68	-	-
2	30	805.999	1000 cc	2		251	-	39	68	-	-
2	35	806.190	1000 cc	2		247	-	41	68	-	-
2	40	806.380	1000 cc	2		250	-	40	68	-	-
3	45	806.575	1000 cc	2		247	-	40	68	-	-
3	50	806.772	1000 cc	2		251	-	37	68	-	-
3	55	806.971	1000 cc	2		248	-	37	68	-	-
3	60	807.168	1000 cc	2		250	-	39	68	-	-
	(2210)										
	0-60	V _m = 2.342	$\Delta H = 1000$ cc		F =				F _m = 68		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	204	200	4
Desiccant	1399	1394	5
	Total		9

Preliminary Results of SO ₂ Concentration Determination	
V _m =	2.21 DSCF
Moisture Gravimetric =	16.06 %v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job LP / Tomahawk
 Source GECA Smelter
 Date 7-12-95 Test 3 Run 3
 Wet Bulb _____
 Dry Bulb _____

Operator(s) JA TN
 Meter Box No. CEM 1 Gasmeter Coef. 9750
 $\Delta H@$ _____ in.WC Bar.Press 28.43 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC ☒
 Post Test: _____ cfm at _____ in.WC ☐

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	(2225)	(807.280)									
1	5	807.474	1000 cc	2		245	-	37	68	-	-
1	10	807.669	1000 cc	2		247	-	38	68	-	-
1	15	807.864	1000 cc	2		250	-	39	68	-	-
1	20	808.065	1000 cc	2		248	-	41	68	-	-
2	25	808.263	1000 cc	2		252	-	37	65	-	-
2	30	808.461	1000 cc	2		250	-	36	68	-	-
2	35	808.659	1000 cc	2		246	-	39	68	-	-
2	40	808.849	1000 cc	2		250	-	41	68	-	-
3	45	809.051	1000 cc	2		247	-	38	68	-	-
3	50	809.234	1000 cc	2		248	-	39	68	-	-
3	55	809.444	1000 cc	2		250	-	37	68	-	-
3	60	809.631	1000 cc	2		250	-	39	68	-	-
	(2325)										
	60	V _m = 2.351	$\Delta H = 1000 \text{ cc}$		F =				E = 65		


Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers			
Condenser	204	200	4
Desiccant	1359	1395	5
	Total		9

Preliminary Results of SO ₂ Concentration Determination	
V _{std} =	2.22 DSCF
Moisture Gravimetric =	16.01 %v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Job CD / Tomahawk
 Source Press Vent Sme
 Test 4 Run 5 Date _____
 Stack Dimen. 62.5 IN.
 Dry Bulb 104 °F Wet bulb 85 °F
 Manometer ☒ Reg. ☐ Exp ☐ Elec.
 Barometric Pressure 29.43 IN.HG
 Static Pressure -1.70 IN.WC
 Operators B. Aschenbach T. Hansen
 Pitot No. 270-60 C_p .84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>3</u> IN.		Time Start:	HRS
<u>B-1</u>	<u>.021</u>	<u>1.31</u>	<u>4.31</u>	<u>1.90</u>	
<u>2</u>	<u>.067</u>	<u>4.19</u>	<u>7.19</u>	<u>1.70</u>	
<u>3</u>	<u>.118</u>	<u>7.37</u>	<u>10.37</u>	<u>2.00</u>	
<u>4</u>	<u>.177</u>	<u>11.06</u>	<u>14.06</u>	<u>2.00</u>	
<u>5</u>	<u>.250</u>	<u>15.62</u>	<u>18.62</u>	<u>2.00</u>	
<u>6</u>	<u>.354</u>	<u>22.25</u>	<u>25.25</u>	<u>1.95</u>	
<u>7</u>	<u>.644</u>	<u>46.25</u>	<u>49.25</u>	<u>2.10</u>	
<u>8</u>	<u>.750</u>	<u>46.87</u>	<u>49.87</u>	<u>2.20</u>	
<u>9</u>	<u>.823</u>	<u>51.44</u>	<u>54.44</u>	<u>2.10</u>	
<u>10</u>	<u>.882</u>	<u>55.12</u>	<u>58.12</u>	<u>1.25</u>	
<u>11</u>	<u>.933</u>	<u>58.31</u>	<u>61.31</u>	<u>1.40</u>	
<u>12</u>	<u>.977</u>	<u>61.18</u>	<u>64.18</u>	<u>1.30</u>	
<u>1</u>					
<u>2</u>					
<u>3</u>			<u>Aug 2P</u>	<u>1.86</u>	
<u>4</u>					
<u>5</u>					
<u>6</u>					
<u>7</u>					
<u>8</u>					
<u>9</u>					
<u>10</u>					
<u>11</u>					
<u>12</u>					
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP / TomahawkDate 7-13-95 Test CL Run 1Source Press Unit StackNo. of traverse points 24Method 51202 Filter holder: GlassFilter type: 4" 6PT

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac) ☒Post test: 0.0 cfm at 16 IN. HG (vac) ☒

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

C1) 7844☒ Acetone☒ Other(s) MCC

No. of probe wash bottles:

(1)

Sample recovered by:

SA TH

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	506	490	16
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1439	1419	20
Total			36

Integrated Gas Sampling Data:

Bag Pump No. 229
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.0
 Time start: _____
 Sampling rate: 400

Box No. 10 Bag No. 1
 Size: 44 L
 cc/min at 22 IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: SA

S/N of O₂ Analyzer used to monitor train outlet:5

052394-G:\STACK\WP\FORMS\SS-0046RR

EPA Method 5 Field Data Sheet

Job LP / Tomahawk Operators DA TH Nozzle No. 5-8 Pilot No. 270-6
 Source Press Vent Stack Meter Box No. 8-1110 in WC 1.84 Nozzle Dia. .185 C_p .84
 Date 7-13-91 Test 51 Run 1 Gasmer Coeff. .9996 Bar. Press. 29.43 in Hg 5 H_2O 5 %

Date 7-13-95 Test 61 Run 1 Gasmeter Coeff. 1.7728													
Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in WC)	Orifice Meter (in WC)	Des. Vol. (cf)	VAC. (in Hg)	Temperatures (°F)					Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.	Gas/In		Gas/Out
B-12	(0915)	466.10											
11	5.5	468.06	1.60	1.79	8.01	8	110	235	227	49	85	82	20.9
10	7.5	470.63	1.80	1.91	8.00	8.5	110				89	82	20.9
9	10	472.11	2.00	2.26	2.16	10	110	240	230	45	91	82	20.9
8	12.5	474.47	2.10	2.37	4.37	12	110				91	83	21.4
7	15	476.74	2.16	2.39	6.60	12	106	239	233	45	92	82	21.5
6	17.5	484.85	1.90	2.15	8.71	10	109				92	82	21.4
5	20	481.02	2.00	2.29	6.89	11	104	240	235	43	92	83	21.4
4	22.5	483.17	2.10	2.41	3.13	12	101				93	83	21.5
3	25	485.50	2.10	2.41	5.36	12	103	241	237	41	93	84	21.5
2	27.5	487.65	2.15	2.48	7.63	12	100				94	83	21.4
1	30	489.86	1.90	2.19	9.77	11	100	241	235	40	94	84	21.4
A-12	32.5	491.96	1.80	2.08	1.85	10	105				94	84	21.3
11	35	493.94	1.60	1.83	3.80	8	114	239	235	42	94	84	21.2
10	37.5	495.93	1.80	2.03	5.86	8.5	109				95	85	21.2
9	40	498.16	2.10	2.39	8.09	12	109	241	240	39	96	85	21.3
8	42.5	500.40	2.10	2.35	0.32	12	111				97	86	21.4
7	45	502.51	1.80	2.06	2.40	10	108	245	237	41	97	86	21.5
6	47.5	504.59	1.80	2.06	4.48	10	107				97	86	21.5
5	50	506.82	2.05	2.39	6.71	12	98	241	240	40	97	86	21.5
4	52.5	508.07	2.15	2.45	8.98	12	107				97	86	21.5
3	55	511.34	2.20	2.53	1.28	10	104	237	241	39	97	86	21.5
2	57.5	513.63	2.45	2.62	3.70	13	104				97	86	21.5
1	60	515.85	1.90	2.20	5.85	11	100	241	245	38	97	86	21.5
	62	518.09	2.00	2.33	8.04	11.5	98				97	86	21.5
	(1016)												
	0-10	V _m - 51.99		2.26							AVG. 89.1		

INTERPOL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP / TomahawkDate 7-13-85 Test 4 Run 2Source Press West SincicNo. of traverse points 24Method 5-202 Filter holder: GlassFilter type: 4" GFR

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac) ☒Post test: 0.0 cfm at 16 IN. HG (vac) ☒

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

11) 7845☒ Acetone☒ Other(s) MILK

No. of probe wash bottles:

11)
BA TH

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	507	490	17
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1415	1399	16
Total			33

Integrated Gas Sampling Data:

Bag Pump No. 223Box No. 10 Bag No. 2Bag Material: 5-layer Aluminized TedlarSize: 44 LPretest leak check: 0.0cc/min at 22 IN.HG

Time start: _____

(HRS) Time end: _____ (HRS)

Sampling rate: 400cc/min Operator: BAS/N of O₂ Analyzer used to monitor train outlet: 5

052394-G:STACKWP\FORMS\S-0046RR

EPA Method 5 Field Data Sheet

Job CP / Tomahawk Operators DA TH Nozzle No. 5-3 Pilot No. 2726
 Source Doe's Kent Street Meter Box No. 8 ΔH 1.84 in. WC Nozzle Dia. .185 in. C_p .84
 Date 7-13-88 Test 1 Run 2 Gasmeter Coeff. 1.896 Bar. Press. 28.43 in. Hg H_2O 4 %

Date	Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in WC)	Orifice Meter (in WC)	Des. Vol. (cf)	VAC. (in Hg)	Temperatures (°F)					Oxygen (% v/v)		
								Stack	Probe	Oven	Imp.	Gas/In		Gas/Out	
7-13-33		1105	518.50												
	A-12	2.5	519.83	1.75	.87	9.84	3	110	234	246	42	84	84	20.8	
	11	5	521.50	1.96	2.16	1.95	9	114				86	84	20.8	
	10	7.5	524.15	2.20	2.52	4.23	13	110	235	250	41	87	84	21.2	
	9	10	526.45	2.05	2.36	6.44	11	108				88	85	21.1	
	8	12.5	528.64	1.90	2.17	8.54	11	113	238	256	40	89	85	21.1	
	7	15	530.77	1.85	2.13	6.67	10	109				90	85	21.1	
	6	17.5	532.97	2.00	2.32	2.36	11	106	240	253	41	91	85	21.1	
	5	20	535.23	2.20	2.53	5.15	12	111				92	86	21.1	
	4	22.5	537.48	2.35	2.73	7.54	13	106	237	250	39	93	86	21.1	
	3	25	539.86	2.50	2.90	9.99	13	107				92	86	21.1	
	2	27.5	542.29	2.80	2.56	2.36	12	106	240	249	40	93	87	21.1	
	1	30	544.39	2.10	2.46	4.56	12	102				93	87	21.1	
	B-12	32.5	546.33	1.40	1.63	6.41	7	105	237	253	40	93	87	20.9	
	11	35	548.02	.90	1.04	7.85	5	110				94	87	20.9	
	10	37.5	550.24	2.10	2.43	6.14	13	111	239	251	41	98	87	20.9	
	9	40	552.48	2.10	2.43	2.39	13	112				99	88	20.9	
	8	42.5	554.70	2.30	2.68	4.76	13	110	241	249	39	99	88	20.9	
	7	45.0	556.91	2.00	2.31	6.96	11	114				99	88	20.9	
	6	47.5	559.20	2.10	2.46	9.23	13	107	239	251	41	100	89	20.9	
	5	50	561.52	2.05	2.39	1.47	13	110				100	89	20.9	
	4	52.5	563.80	2.15	2.50	3.77	13	112	241	255	39	100	90	20.9	
	3	55	566.08	2.20	2.58	6.09	13	108				100	89	20.9	
	2	57.5	568.40	2.20	2.59	8.42	13	105	240	253	40	100	90	20.9	
	1	60	570.70	2.10	2.48	6.71	13	108				100	90	20.9	
		1206													
		0.60	V _m = 52.20		ΔH = 2.25							20.5			

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP / TomahawkDate 1-13-95 Test CI Run 3Source Press UENT StackNo. of traverse points 24Method 5-202 Filter holder: GlassFilter type: 4" GFF

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac) ☒Post test: 0.0 cfm at 15 IN. HG (vac) ☒

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

CI 7908☒ Acetone☒ Other(s) MCC

No. of probe wash bottles:

CI
BA TH

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	504	486	18
Impinger No. 2			
Impinger No. 3			
Condenser	1460	1439	21
Desiccant			
Total			39

Integrated Gas Sampling Data:

Bag Pump No. 273
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 00
 Time start: _____
 Sampling rate: 400

Box No. 10 Bag No. 3
 Size: 44 L
 cc/min at 12 IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: BA

S/N of O₂ Analyzer used to monitor train outlet: 5

EPA Method 5 Field Data Sheet

Job CP / Tomahawk Operators SA JH Nozzle No. 5-3 Pitot No. 27-6
 Source Process Water Storage Meter Box No. 5-A110 in WC 1.84 Nozzle Dia. 1.85 in. 34
 Date 7-13-95 Test 1 Run 3 Gasometer Coeff. 5.996 Bar. Press. 28.43 in. Hg 35 % 35

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)					Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.	Gas/In		Gas/Out
1335		571.10											
12	25	573.16	1.70	1.98	3.13	8	112	235	264	50	94	93	20.9
11	5	575.31	2.00	2.30	5.33	11	120				95	94	20.9
10	7.5	577.61	2.00	2.36	7.55	11.5	108	240	258	46	96	94	20.9
9	10	579.79	2.20	2.55	9.89	12	110				97	94	20.9
8	12.5	582.05	2.26	2.61	2.23	12	106	242	260	44	98	95	20.9
7	15	584.35	2.05	2.42	4.49	11.5	110	239	258	43	99	95	20.9
6	17.5	586.62	2.00	2.35	6.71	11.0	113				99	95	20.9
5	20	588.89	1.95	2.30	8.92	11	112	240	261	41	100	95	20.9
4	22.5	591.18	2.10	2.49	1.21	12	111				101	95	20.9
3	25	593.49	2.10	2.48	3.50	12	108	242	259	39	101	96	20.9
2	27.5	595.78	2.05	2.43	5.76	12	105				102	96	20.9
1	30	598.09	1.95	2.33	7.98	11.5	110	238	261	41	101	96	20.9
A-12	32.5	600.37	1.90	2.25	0.17	11	110				102	97	20.9
11	35	602.64	2.10	2.47	2.46	12	113	245	255	40	103	97	20.9
10	37.5	604.89	2.15	2.52	4.77	12	116				103	97	20.9
9	40	607.11	2.00	2.37	7.02	11	110	243	257	38	104	97	20.9
8	42.5	609.33	1.90	2.27	9.21	11	108				105	98	20.9
7	45	611.57	2.00	2.37	1.45	11.5	113	245	257	40	106	98	20.9
6	47.5	613.80	2.00	2.38	3.70	11.5	110	245	257	40	106	98	20.9
5	50	616.03	2.10	2.49	6.01	12	113				108	99	20.9
4	52.5	618.29	2.15	2.56	8.35	12	107	247	253	39	109	99	20.9
3	55	620.62	2.30	2.77	0.78	14	106				110	99	20.9
2	57.5	622.95	2.10	2.51	3.10	12.5	111	245	256	40	110	99	20.9
1	60	625.45	2.10	2.53	5.40	12.5	107				109	99	20.9
1434													
0-60		V _m - 54.35		ΔF _m - 0.14							Avg. - 99.2		

APPENDIX D

INTERPOLL LABORATORIES ANALYTICAL DATA

INTERPOLL LABORATORIES, INC.
(612) 786-6020
Solvent Rinse Data Reporting Sheet

☒ EPA Method 5 Probe Wash ☐ EPA Method 29 Probe Wash ☐ EPA Method 202 Cup & Tube Wash

Job LP/Tomahawk Source/Site Press vent / Stack
 Date Submitted 7- Test No. 4
 Date of Analysis 7-17-95 Technician B.D.
 Transport Leakage ☐ None ☒ ml Solvent Acetone

Test: <u>4</u>	Run: <u>0</u>	Dish No: <u>807</u>
Log No: <u>6006-03P</u>		Dish + Sample Wt: <u>46.0306</u> g
Volume of Solvent <u>100</u> ml		Dish Tare Wt: <u>46.0304</u> g
*Solvent Residue <u>2.0</u> ug/ml		Sample Wt: <u>0.0002</u> g
Test: <u>4</u>	Run: <u>1</u>	Dish No: <u>810</u>
Vol. of Solvent <u>110</u> ml		Dish + Sample Wt: <u>45.2790</u> g
Log Number <u>-04P</u>		Dish Tare Wt: <u>45.2509</u> g
Comments		Sample Wt: <u>0.0281</u> g
Test: <u>4</u>	Run: <u>2</u>	Dish No: <u>817</u>
Vol. of Solvent <u>90</u> ml		Dish + Sample Wt: <u>46.6486</u> g
Log Number <u>-05P</u>		Dish Tare Wt: <u>46.6364</u> g
Comments		Sample Wt: <u>0.0122</u> g
Test: <u>4</u>	Run: <u>3</u>	Dish No: <u>818</u>
Vol. of Solvent <u>90</u> ml		Dish + Sample Wt: <u>45.9144</u> g
Log Number <u>-06P</u>		Dish Tare Wt: <u>45.9029</u> g
Comments		Sample Wt: <u>0.0115</u> g

*Solvent Residue 2.0 ug/ml = [(Sample Wt. 0.0002g) (10⁶)]/Vol. of Sol. 100 ml

EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

	RUN	RUN 1	RUN 2	RUN 3
Results of Solvent Rinse g	D-2	0.0279	0.0120	0.0113

INTERPOL LABORATORIES, INC.
(612) 786-6020
Filter Gravimetrics Reporting Sheet

Filter Type: ☒ EPA Method 5 ☐ EPA Method 29 ☐ EPA Method 202 ☐ Other _____

Job LP/Tomahawk Source/Site Press Vent/Stack
Date Submitted 7- Test No. 4
Date of Analysis 7-17-95 Technician B.D.

Test: <u>4</u>	Run: <u>0</u>	Filter No: <u>7939</u>
Field Blank:		Filter Type: <u>4"GF</u>
Log No: <u>6006-03F</u>		Filter + Sample Wt: <u>.9620</u> g
Color:		Filter Tare Wt: <u>.9620</u> g
		Sample Wt: <u>0.0000</u> g
Test: <u>4</u>	Run: <u>1</u>	Filter No: <u>7844</u>
Log No: <u>-04F</u>		Filter Type: <u>4"GF</u>
Color:		Filter + Sample Wt: <u>.9962</u> g
		Filter Tare Wt: <u>.9943</u> g
		Sample Wt: <u>0.0019</u> g
Test: <u>4</u>	Run: <u>2</u>	Filter No: <u>7845</u>
Log No: <u>-05F</u>		Filter Type: <u>4"GF</u>
Color:		Filter + Sample Wt: <u>1.0032</u> g
		Filter Tare Wt: <u>1.0003</u> g
		Sample Wt: <u>0.0029</u> g
Test: <u>4</u>	Run: <u>3</u>	Filter No: <u>7908</u>
Log No: <u>-06F</u>		Filter Type: <u>4"GF</u>
Color:		Filter + Sample Wt: <u>.9490</u> g
		Filter Tare Wt: <u>.9455</u> g
		Sample Wt: <u>0.0035</u> g

	RUN	RUN 1	RUN 2	RUN 3
Results of Filter Analysis g		<u>0.0019</u>	<u>0.0029</u>	<u>0.0035</u>

	RUN	RUN 1	RUN 2	RUN 3
Total Mass g				

	A	B	C	D	E	F	G	H	I	J	K
1	EPA Method 202 Calculations										
2	Job: Louisiana Pacific Tomahawk										
3	Date: 13-Jul-95										
4	Report No. 5-6006										
5	PRESS VENT										
6	RUN	Vic (ml)	Sulfate (mg/ml)	Mc (mg)	Mr (mg)	Mi (mg)	Mo (mg)	Mb (mg)	ENTER IN CPM COMPUTER (g)		
7	1	211	1.10E-03	0.04	5.3	5.26	68.7	0.6	73.36	0.073357	
8	2	210	2.00E-04	0.01	3.7	3.69	100.9	0.6	103.99	0.103992	
9	3	208	1.70E-04	0.01	3.2	3.19	2.5	0.6	5.09	0.005093	
10											
11	EPA Method 201A/202 Totals										
12		Probe (mg)	Filter (mg)	CPM (mg)	Total (mg)						
13	RUN										
14	1	27.9	1.9	73.36	103.1573						
15	2	12	2.9	103.99	118.8923						
16	3	11.3	3.5	5.09	19.89349						
17											
18											

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Impinger Catch Data Reporting Sheet

Protocol: ☐ Minnesota ☐ Wisconsin ☐ Iowa☒ EPA Method 202 ☐ OtherJob: Town LakeSource/Site: Press vent / schoolDate Submitted: 7-14-95Test No.: 4Date of Analysis: 7-24-95Technician: J. Lorenz

		Solvent Phase		Aqueous Phase	
Test: 4	Run: 0	Dish No: 853		Dish No: 828	
Log No: 6006-03I		Dish + Sample Wt: 47.4008 g		Dish + Sample Wt: 45.6233 g	
Color & Appearance:		Dish Tare Wt: 47.4007 g		Dish Tare Wt: 45.6229 g	
		Fraction Wt: .0001 g		Fraction Wt: .0004 g	
Comments: Field Blk		Smpl Vol: 202 ml, Alqt: 177 ml, Factor: 1.141		Smpl Vol: 202 ml, Alqt: 177 ml, Factor: 1.141	
		Sample Wt: .0001 g		Sample Wt: .0005 g	
Test: 4	Run: 1	Dish No: 869		Dish No: 829	
Log No: -04I		Dish + Sample Wt: 47.8564 ^{J.L. 7-16-95} g		Dish + Sample Wt: 45.6971 g	
Color & Appearance:		Dish Tare Wt: 47.3958 g		Dish Tare Wt: 45.6924 g	
		Fraction Wt: .0606 g		Fraction Wt: .0047 g	
Comments: liquid residue in dish		Smpl Vol: 211 ml, Alqt: 186 ml, Factor: 1.134		Smpl Vol: 211 ml, Alqt: 186 ml, Factor: 1.134	
		Sample Wt: .0687 g		Sample Wt: .0053 g	
* Test: 4	Run: 2	Dish No: 874		Dish No: 830	
Log No: -05I		Dish + Sample Wt: 45.5022 ^{J.L. 7-27-95} g		Dish + Sample Wt: 43.3563 g	
Color & Appearance:		Dish Tare Wt: 31.7541 ^{J.L. 7-27-95} g		Dish Tare Wt: 43.3526 g	
		Fraction Wt: .0889 g		Fraction Wt: .0037 g	
Comments: white, waxy residue in dish		Smpl Vol: 210 ml, Alqt: 185 ml, Factor: 1.135		Smpl Vol: 210 ml, Alqt: 185 ml, Factor: 1.135	
		Sample Wt: .01009 g		Sample Wt: .0042 g	
Test: 4	Run: 3	Dish No: 875		Dish No: 844	
Log No: -06I		Dish + Sample Wt: 38.9905 g		Dish + Sample Wt: 45.0241 g	
Color & Appearance:		Dish Tare Wt: 38.9883 g		Dish Tare Wt: 45.0209 g	
		Fraction Wt: .0022 g		Fraction Wt: .0032 g	
Comments:		Smpl Vol: 208 ml, Alqt: 183 ml, Factor: 1.137		Smpl Vol: 208 ml, Alqt: 183 ml, Factor: 1.137	
		Sample Wt: .0025 g		Sample Wt: .0036 g	

* Solvent phase transferred to 2nd dish (#845) to assure no particulate contamination.

Note: Factor = Sample Volume / Aliquot Volume

Blank Solvent Wt. .0001 g

		RUN 0 Field Blk	RUN 1	RUN 2	RUN 3
Results of Solvent Phase	g	.0001	.0686	.1008	.0024
Results of Aqueous Phase	g	.0005	.0052 ^{J.L. 7-27-95}	.0037	.0031

Interpoll Laboratories, Inc.
(612) 786-6020

Ion Chromatography Laboratory

Due 7/25/95

DIONEX MODEL 40001 WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: MTG

Date of Analysis: 7/25/95

Job: LP Tomahawk

Source: Press Vent

Site: STCK

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient(List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
% A										
% B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc.(ug/ml)	Total ug Sulfate	meq of Sulfate
4/0	6006-03	202	1.0	0.18	36	0.00075
4/1	-04	211	1.0	1.1 <i>7/24/95</i> 1232 730		0.0048
4/2	-05	210	1.0	0.20	42	0.00088
4/3	-06	208	1.0	0.17	35	0.00073

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

LSC-08RR

INTERPOL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer CP / Remahawk Source Less DEPT Date of Test 7-13-95 Site Smex Log No. 6036
Boo Test No. 4 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
4	Probe Wash: ☒ Decont ☐ MeCl ₂	☒ EPA M-5 ☐ EPA M-29		
4	Filter: ☒ 3" Glass ☐ 55 Thimble	☒ EPA M-5 ☐ EPA M-29 ☐ EPA M-201A		
4 DF	Impingers: ☒ Water ☐ 3% O ₂ ☐ 1N NaOH ☐ 12.4 DNPH	☐ EPA Protocol ☒ Formaldehyde ☐ EPA M-29 ☐ EPA M-26 ☐ Acid Gases		
3	Integrated Gas: ☒ Afterburn Bag	☒ EPA M-3 ☐ EPA M-10		Co Analysis
—	Oxides of Nitrogen:	☐ EPA M-7A ☐ EPA M-16		
—	Fuel Lab: ☐ Fuel Sample	☐ EPA M-16		
—	Particle Sizing:	☐ X-Ray Scatroph ☐ Cascade Imp		
—	Miscellaneous:	☐ EPA M-16		

Fuel Type: Coal: ☐ Biomimints ☐ Wood: ☐ Waste Oil ☐ Natural Gas
☐ Anthracite ☐ Misc: ☐ CIRD ☐

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Robey, J. Threl</u>	<u>7/14/95 1100</u>

INTERPOL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Log No. 600L
No. of Runs 3

Site STAC
Test No. 2

Source STAC

Date of Test 7/12/95

Job
Field Engineer Bob


No. Items	Sample Type	Analysis	Sequence No.	Comments
—	Probe Wash: ☐ Acetone ☐ MeCl ₄	☐ EPA M-5 ☐ EPA M-29	☐ EPA M-201A	
—	Filter: ☐ 4" Glass ☐ SS Thimble	☐ EPA M-5 ☐ EPA M-29 ☐ EPA M-201A	☐ EPA M-17	
—	Impingers: ☐ DI Water ☐ H ₂ SO ₄ ☐ HNO ₃ /H ₂ O ₂ ☐ KMnO ₄ /H ₂ SO ₄ ☐ H ₂ O ☐ 4-DNPH	☐ EPA M-5 ☐ EPA M-29 ☐ EPA M-201A ☐ EPA M-202 ☐ EPA M-6, B ☐ Acid Gases	☐ EPA M-17 ☐ EPA M-29 ☐ EPA M-26 ☐ EPA M-10	
—	Integrated Gas: ☐ Tedlar Bag	☐ EPA M-3	☐ EPA M-10	
—	Oxides of Nitrogen	☐ EPA M-7A		
—	Fuel Lab: ☒ Fuel Sample	☒ Per 5-016.3		
—	Particle Sizing	☐ X-Ray Scatograph ☐ Cascade Imp		
—	Miscellaneous:	☐		

Fuel Type: ☐ Coal
☐ Bituminous
☐ Anthracite
☐ Lignite

Wood: ☒ Wood Waste
☐ Dust
☐ Bark

Oil: ☐ Waste Oil
☐ No. 2
☐ No. 6

Misc: ☐ Natural Gas
☐ RDF
☐

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Bob, T. T. T. T.</u>	<u>7/14/95 1100</u>

INTERPOL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer

LP/Tancher K

Source

CEAT

Site

STAC

Log No.

6006

No. of Runs

3

Date of Test

7-12-95

Test No.

3

No. Items	Sample Type	Analysis	Sequence No.	Comments
1	Probe Wash: ☐ Acetone ☐ MeCl ₃	☐ EPA M-5 ☐ EPA M-29	☐ EPA M-201A	
1	Filters: ☐ 4" Glass ☐ 55 Humble	☐ EPA M-5 ☐ EPA M-29 ☐ EPA M-201A	☐ EPA M-17	
1	Impingers: ☐ DI Water ☐ 1% H ₂ O ₂ ☐ 1N NaOH ☐ 12.4-DNPH	☐ IMN Protocol ☐ IWI Protocol ☐ EPA M-202 ☐ EPA M-6,8 ☐ Acid Gases	☐ IIA Protocol ☐ Formaldehyde ☐ EPA M-29 ☐ EPA M-26	
1	Integrated Gas: ☐ Tedlar Bag	☐ EPA M-3	☐ EPA M-10	
1	Oxides of Nitrogen	☐ EPA M-7A		
1	Fuel Lab: ☒ Fuel Sample	☒ X-Ray Scdgraph ☐ Cascade Imp		
1	Particle Sizing			
1	Miscellaneous:			

Fuel Type: Coal: ☐ Bituminous ☐ Anthracite ☐ Lignite
 Wood: ☐ Wood Waste ☐ Dust ☒ Bag
 Oil: ☐ Waste Oil ☐ No. 2 ☐ No. 6
 Misc: ☐ Natural Gas ☐ RDF ☐

Relinquished by/Affiliation: LP/Tancher K Accepted by/Affiliation: LP/Tancher K Date: 7/14/95

APPENDIX E

CONTINUOUS EMISSION MONITOR PRINTOUTS

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT11
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
192	08:01:00	5.4	16.1	1.07	19.63
192	08:02:00	5.4	13.4	1.10	19.57
192	08:03:00	5.3	13.0	1.07	19.65
192	08:04:00	5.4	12.1	1.04	19.69
192	08:05:00	5.5	11.7	1.01	19.78
192	08:06:00	5.3	11.4	0.97	19.87
192	08:07:00	5.5	13.2	0.97	19.87
192	08:08:00	5.8	11.1	0.98	19.87
192	08:09:00	6.2	10.7	1.01	19.77
192	08:10:00	6.2	9.9	1.06	19.70
192	08:11:00	5.7	12.0	1.07	19.64
192	08:12:00	5.7	11.6	1.06	19.67
192	08:13:00	5.8	10.5	1.06	19.67
192	08:14:00	5.9	10.6	1.04	19.72
192	08:15:00	6.1	10.6	1.05	19.70
192	08:16:00	6.8	12.8	0.93	19.96
192	08:17:00	8.5	10.2	0.99	19.83
192	08:18:00	8.8	7.6	1.00	19.82
192	08:19:00	8.1	9.8	1.00	19.83
192	08:20:00	6.7	11.6	1.10	19.62
192	08:21:00	6.1	14.3	1.08	19.64
192	08:22:00	6.2	9.5	1.08	19.63
192	08:23:00	6.4	9.8	1.07	19.65
192	08:24:00	6.5	12.2	1.04	19.70
192	08:25:00	6.8	12.3	1.04	19.74
192	08:26:00	6.9	12.9	1.02	19.77
192	08:27:00	7.0	13.1	1.01	19.78
192	08:28:00	7.2	11.2	1.03	19.75
192	08:29:00	7.3	9.2	1.03	19.75
192	08:30:00	7.6	8.1	1.03	19.74
192	08:31:00	7.5	11.2	1.03	19.74
192	08:32:00	7.6	12.3	1.06	19.70
192	08:33:00	7.5	10.8	1.04	19.72
192	08:34:00	8.5	11.2	1.05	19.73

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT11
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
192	08:35:00	8.6	9.7	1.06	19.70
192	08:36:00	8.7	9.2	1.06	19.70
192	08:37:00	8.7	10.3	1.10	19.60
192	08:38:00	8.7	9.8	1.07	19.66
192	08:39:00	8.7	9.4	1.06	19.67
192	08:40:00	8.8	9.3	1.10	19.60
192	08:41:00	8.9	10.3	1.07	19.67
192	08:42:00	9.1	9.4	1.09	19.61
192	08:43:00	9.0	9.0	1.07	19.68
192	08:44:00	9.0	9.1	1.06	19.68
192	08:45:00	9.0	8.8	1.07	19.69
192	08:46:00	9.0	9.4	1.04	19.75
192	08:47:00	9.0	9.9	1.07	19.67
192	08:48:00	9.3	9.1	1.07	19.69
192	08:49:00	9.3	8.9	1.05	19.72
192	08:50:00	9.3	7.8	1.08	19.66
192	08:51:00	9.3	6.8	1.06	19.70
192	08:52:00	9.3	6.2	1.09	19.63
192	08:53:00	9.4	9.3	1.09	19.65
192	08:54:00	9.4	10.7	1.11	19.59
192	08:55:00	9.3	7.6	1.11	19.60
192	08:56:00	9.3	10.5	1.09	19.66
192	08:57:00	9.2	10.1	1.08	19.66
192	08:58:00	9.3	7.5	1.07	19.69
192	08:59:00	9.5	9.2	1.07	19.69
192	09:00:00	9.5	8.5	1.08	19.67
Run Average		7.7	10.4	1.05	19.70

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT12
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
192	09:21:00	7.4	11.6	1.06	19.62
192	09:22:00	7.5	11.9	1.05	19.64
192	09:23:00	7.5	11.6	1.07	19.61
192	09:24:00	7.6	12.3	1.07	19.62
192	09:25:00	7.6	12.5	1.08	19.57
192	09:26:00	7.6	13.9	1.08	19.60
192	09:27:00	7.7	15.3	1.08	19.59
192	09:28:00	7.9	10.6	1.10	19.56
192	09:29:00	7.9	11.2	1.10	19.54
192	09:30:00	8.1	14.5	1.15	19.45
192	09:31:00	7.9	14.6	1.14	19.46
192	09:32:00	7.8	11.3	1.12	19.49
192	09:33:00	7.6	10.0	1.07	19.62
192	09:34:00	7.6	10.7	1.05	19.64
192	09:35:00	7.6	13.4	1.01	19.73
192	09:36:00	7.6	10.6	1.00	19.76
192	09:37:00	7.5	9.6	0.97	19.82
192	09:38:00	7.9	13.7	1.01	19.75
192	09:39:00	7.9	13.5	1.01	19.76
192	09:40:00	7.9	10.6	1.04	19.67
192	09:41:00	7.6	10.6	0.93	19.89
192	09:42:00	7.8	12.1	0.90	19.95
192	09:43:00	7.5	44.6	0.89	19.98
192	09:44:00	7.5	21.9	0.88	19.99
192	09:45:00	7.7	19.9	0.89	19.98
192	09:46:00	8.0	12.2	0.91	19.94
192	09:47:00	8.3	12.9	0.93	19.88
192	09:48:00	8.3	10.1	0.95	19.85
192	09:49:00	8.4	9.2	0.94	19.87
192	09:50:00	8.2	12.0	0.94	19.87
192	09:51:00	8.2	16.1	0.94	19.88
192	09:52:00	8.2	12.1	0.93	19.89
192	09:53:00	8.2	10.7	0.94	19.87
192	09:54:00	8.1	15.4	0.93	19.88

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT12
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
192	09:55:00	8.3	15.2	0.93	19.88
192	09:56:00	8.3	10.5	0.94	19.86
192	09:57:00	8.5	12.3	0.95	19.85
192	09:58:00	8.4	12.7	0.95	19.84
192	09:59:00	8.6	8.9	1.00	19.74
192	10:00:00	8.4	7.8	0.97	19.80
192	10:01:00	8.5	9.1	0.97	19.79
192	10:02:00	8.3	10.5	0.93	19.88
192	10:03:00	8.5	7.0	0.94	19.84
192	10:04:00	8.7	9.7	0.95	19.85
192	10:05:00	8.9	8.1	0.97	19.79
192	10:06:00	9.1	5.6	1.01	19.72
192	10:07:00	9.2	9.8	1.05	19.62
192	10:08:00	9.2	8.4	1.03	19.66
192	10:09:00	9.1	6.6	1.02	19.70
192	10:10:00	9.1	9.6	1.03	19.69
192	10:11:00	8.9	8.8	1.00	19.73
192	10:12:00	9.0	6.2	1.02	19.69
192	10:13:00	9.0	7.7	1.02	19.69
192	10:14:00	9.0	10.7	1.05	19.63
192	10:15:00	9.0	9.4	1.02	19.68
192	10:16:00	9.0	6.9	1.04	19.65
192	10:17:00	9.1	10.2	1.01	19.72
192	10:18:00	8.9	9.2	1.04	19.66
192	10:19:00	8.9	8.7	1.07	19.57
192	10:20:00	8.9	10.9	1.03	19.64
Run Average		8.3	11.7	1.00	19.74

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT13
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
192	10:41:00	9.1	13.8	1.04	19.74
192	10:42:00	9.1	12.6	1.04	19.72
192	10:43:00	9.1	12.2	1.04	19.72
192	10:44:00	9.1	14.2	1.02	19.73
192	10:45:00	9.3	12.3	1.02	19.73
192	10:46:00	9.5	10.5	1.02	19.72
192	10:47:00	9.5	13.8	1.05	19.67
192	10:48:00	9.5	15.3	1.03	19.68
192	10:49:00	9.4	12.6	1.03	19.69
192	10:50:00	9.3	14.5	1.03	19.68
192	10:51:00	9.2	18.6	1.01	19.72
192	10:52:00	9.0	17.1	1.01	19.73
192	10:53:00	9.0	14.8	0.99	19.77
192	10:54:00	9.5	13.1	0.99	19.74
192	10:55:00	9.6	16.0	1.01	19.72
192	10:56:00	9.6	17.7	0.99	19.74
192	10:57:00	9.5	16.0	1.00	19.72
192	10:58:00	9.5	12.9	1.01	19.71
192	10:59:00	9.6	11.0	1.01	19.69
192	11:00:00	9.7	11.0	1.06	19.61
192	11:01:00	9.6	15.4	1.07	19.56
192	11:02:00	9.4	18.4	1.07	19.55
192	11:03:00	9.5	24.2	1.02	19.68
192	11:04:00	9.6	14.6	1.05	19.61
192	11:05:00	9.5	11.9	1.01	19.71
192	11:06:00	9.4	13.5	1.00	19.71
192	11:07:00	9.6	13.7	1.08	19.58
192	11:08:00	9.5	20.2	1.02	19.65
192	11:09:00	9.6	14.9	1.04	19.60
192	11:10:00	9.6	15.2	1.07	19.58
192	11:11:00	9.9	13.6	1.05	19.62
192	11:12:00	10.1	13.6	1.04	19.62
192	11:13:00	10.1	13.2	1.03	19.65
192	11:14:00	10.1	13.1	1.02	19.65

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT13
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
192	11:15:00	10.3	10.5	1.05	19.60
192	11:16:00	10.4	10.7	1.04	19.65
192	11:17:00	10.6	13.5	1.03	19.63
192	11:18:00	10.8	14.6	1.06	19.60
192	11:19:00	10.8	13.5	1.04	19.62
192	11:20:00	10.9	9.4	1.05	19.59
192	11:21:00	10.9	9.7	1.05	19.58
192	11:22:00	11.0	11.2	1.06	19.57
192	11:23:00	10.8	13.3	1.03	19.64
192	11:24:00	10.7	10.7	1.01	19.68
192	11:25:00	10.8	17.6	1.05	19.60
192	11:26:00	10.8	14.8	1.05	19.62
192	11:27:00	10.8	16.2	1.00	19.66
192	11:28:00	10.9	11.6	1.01	19.70
192	11:29:00	11.2	8.0	1.00	19.69
192	11:30:00	11.4	8.2	1.05	19.60
192	11:31:00	11.2	12.6	1.08	19.55
192	11:32:00	11.0	11.1	1.09	19.48
192	11:33:00	10.9	11.2	1.13	19.45
192	11:34:00	10.7	16.8	1.13	19.40
192	11:35:00	10.6	14.1	1.15	19.37
192	11:36:00	10.4	12.9	1.11	19.45
192	11:37:00	10.4	15.1	1.10	19.46
192	11:38:00	10.3	12.3	1.07	19.54
192	11:39:00	10.2	12.2	1.03	19.62
192	11:40:00	10.3	10.6	1.05	19.58
Run Average		10.0	13.6	1.04	19.63

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT21A
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	07:47:00	23.1	28.8	1.82	19.04
193	07:48:00	23.0	25.2	1.82	19.06
193	07:49:00	23.6	24.8	1.81	19.09
193	07:50:00	22.9	26.7	1.86	19.02
193	07:51:00	23.8	29.1	1.78	19.10
193	07:52:00	23.2	21.7	1.85	19.04
193	07:53:00	23.9	26.6	1.83	19.03
193	07:54:00	23.5	21.8	1.83	19.06
193	07:55:00	24.1	27.7	1.83	19.03
193	07:56:00	24.8	22.6	1.79	19.12
193	07:57:00	24.1	25.5	1.84	19.00
193	07:58:00	24.7	23.4	1.77	19.13
193	07:59:00	24.0	24.2	1.84	19.01
193	08:00:00	25.2	20.6	1.74	19.16
193	08:01:00	24.7	17.3	1.86	19.01
193	08:02:00	25.0	23.0	1.78	19.09
193	08:03:00	25.3	16.8	1.80	19.10
193	08:04:00	24.8	20.0	1.85	19.00
193	08:05:00	24.6	21.3	1.82	19.05
193	08:06:00	24.5	21.3	1.88	18.98
193	08:07:00	24.1	24.8	1.87	18.97
193	08:08:00	24.3	25.7	1.85	18.99
193	08:09:00	25.4	22.2	1.80	19.06
193	08:10:00	25.6	20.0	1.82	19.05
193	08:11:00	26.1	21.6	1.83	19.03
193	08:12:00	26.3	19.9	1.77	19.09
193	08:13:00	26.5	14.3	1.83	19.04
193	08:14:00	26.6	18.4	1.80	19.05
193	08:15:00	26.2	17.2	1.83	19.04
193	08:16:00	26.0	22.1	1.86	18.98
193	08:17:00	26.5	24.9	1.80	19.05
193	08:18:00	26.8	21.2	1.84	19.02
193	08:19:00	26.4	23.3	1.84	19.00
193	08:20:00	27.0	19.9	1.83	19.02

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT21A
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	08:21:00	26.2	20.3	1.88	18.94
193	08:22:00	26.5	23.4	1.86	18.98
193	08:23:00	26.4	21.2	1.86	18.99
193	08:24:00	26.7	22.6	1.83	19.01
193	08:25:00	26.4	21.2	1.89	18.93
193	08:26:00	26.3	22.6	1.85	18.98
193	08:27:00	26.6	20.7	1.87	18.96
193	08:28:00	26.7	21.0	1.85	18.98
193	08:29:00	27.7	17.4	1.74	19.14
193	08:30:00	27.5	12.8	1.76	19.11
193	08:31:00	27.3	12.8	1.72	19.18
193	08:32:00	27.9	11.9	1.73	19.16
193	08:33:00	27.3	13.1	1.80	19.05
193	08:34:00	27.7	14.3	1.75	19.13
193	08:35:00	27.6	14.8	1.80	19.07
193	08:36:00	27.4	18.3	1.84	19.00
193	08:37:00	27.4	17.2	1.86	18.97
193	08:38:00	27.6	18.9	1.85	18.96
193	08:39:00	26.8	18.0	1.83	18.99
193	08:40:00	27.4	16.0	1.83	19.03
193	08:41:00	27.2	15.0	1.83	19.02
193	08:42:00	27.4	16.6	1.81	19.06
193	08:43:00	27.7	15.1	1.85	19.00
193	08:44:00	27.7	17.2	1.82	19.02
193	08:45:00	28.1	13.0	1.82	19.05
193	08:46:00	27.4	15.3	1.87	18.95
Run Average		25.9	20.2	1.82	19.04

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT22A
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	09:01:00	22.5	19.3	1.91	19.13
193	09:02:00	22.3	18.2	1.89	19.15
193	09:03:00	22.8	18.8	1.88	19.17
193	09:04:00	22.9	14.6	1.84	19.23
193	09:05:00	22.1	16.8	1.92	19.12
193	09:06:00	22.9	21.4	1.87	19.18
193	09:07:00	22.7	18.2	1.86	19.22
193	09:08:00	22.9	20.6	1.82	19.25
193	09:09:00	23.1	17.2	1.84	19.25
193	09:10:00	23.0	20.1	1.87	19.19
193	09:11:00	23.1	19.5	1.86	19.22
193	09:12:00	22.9	20.1	1.89	19.16
193	09:13:00	23.8	20.4	1.86	19.20
193	09:14:00	23.9	18.7	1.89	19.18
193	09:15:00	23.5	19.3	1.89	19.16
193	09:16:00	23.9	18.2	1.83	19.24
193	09:17:00	24.0	15.8	1.81	19.28
193	09:18:00	23.2	17.8	1.82	19.25
193	09:19:00	23.4	16.0	1.83	19.25
193	09:20:00	23.4	18.6	1.86	19.21
193	09:21:00	23.3	21.0	1.86	19.20
193	09:22:00	23.2	19.4	1.87	19.18
193	09:23:00	22.7	19.4	1.89	19.16
193	09:24:00	23.3	19.3	1.86	19.18
193	09:25:00	23.7	16.8	1.83	19.25
193	09:26:00	23.6	17.3	1.90	19.16
193	09:27:00	23.4	17.1	1.88	19.17
193	09:28:00	23.8	17.7	1.87	19.19
193	09:29:00	23.5	17.8	1.87	19.17
193	09:30:00	23.9	16.2	1.86	19.21
193	09:31:00	23.7	17.6	1.87	19.17
193	09:32:00	23.8	16.9	1.82	19.24
193	09:33:00	24.2	15.8	1.84	19.23
193	09:34:00	24.0	17.0	1.85	19.21

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT22A
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	09:35:00	24.0	15.2	1.81	19.27
193	09:36:00	24.0	15.3	1.82	19.26
193	09:37:00	24.0	16.2	1.86	19.20
193	09:38:00	23.9	15.6	1.86	19.20
193	09:39:00	24.6	15.5	1.85	19.20
193	09:40:00	23.8	14.9	1.89	19.16
193	09:41:00	24.2	17.9	1.85	19.21
193	09:42:00	24.4	15.5	1.94	19.09
193	09:43:00	24.4	19.0	1.90	19.12
193	09:44:00	24.5	15.6	1.92	19.12
193	09:45:00	24.5	18.3	1.92	19.07
193	09:46:00	24.8	14.6	1.85	19.22
193	09:47:00	24.8	14.3	1.89	19.16
193	09:48:00	24.9	15.4	1.86	19.18
193	09:49:00	24.8	13.2	1.84	19.22
193	09:50:00	25.1	13.6	1.83	19.25
193	09:51:00	24.7	14.2	1.87	19.19
193	09:52:00	25.2	14.8	1.83	19.26
193	09:53:00	25.2	12.8	1.88	19.19
193	09:54:00	25.0	13.9	1.90	19.15
193	09:55:00	25.1	15.7	1.91	19.15
193	09:56:00	25.1	16.4	1.93	19.12
193	09:57:00	24.6	18.0	1.94	19.10
193	09:58:00	24.8	19.6	1.93	19.12
193	09:59:00	24.7	19.3	1.92	19.12
193	10:00:00	48.7	16.9	1.21	13.99
Run Average		24.3	17.2	1.86	19.10

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT23A
Job Number: S-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	11:46:00	25.0	22.3	2.02	18.72
193	11:47:00	24.8	21.1	2.08	18.67
193	11:48:00	24.7	21.6	2.07	18.69
193	11:49:00	24.7	22.5	2.13	18.63
193	11:50:00	23.8	26.5	2.11	18.63
193	11:51:00	24.7	26.0	2.04	18.70
193	11:52:00	23.8	26.4	2.23	18.55
193	11:53:00	23.8	34.2	2.20	18.54
193	11:54:00	23.6	32.0	2.22	18.53
193	11:55:00	24.1	33.6	2.10	18.62
193	11:56:00	24.9	25.5	2.06	18.69
193	11:57:00	25.0	24.3	2.07	18.67
193	11:58:00	25.1	22.2	2.05	18.70
193	11:59:00	24.7	23.0	2.11	18.63
193	12:00:00	24.6	24.8	2.04	18.70
193	12:01:00	24.3	24.0	2.08	18.67
193	12:02:00	23.9	29.4	2.12	18.62
193	12:03:00	23.6	30.7	2.16	18.59
193	12:04:00	23.7	33.8	2.14	18.60
193	12:05:00	23.7	31.0	2.05	18.69
193	12:06:00	24.2	27.0	2.06	18.68
193	12:07:00	24.4	24.3	2.05	18.69
193	12:08:00	24.8	22.0	1.99	18.76
193	12:09:00	24.6	19.4	2.01	18.75
193	12:10:00	24.0	22.2	2.05	18.69
193	12:11:00	24.5	21.5	1.98	18.77
193	12:12:00	24.4	17.0	1.99	18.76
193	12:13:00	24.1	19.5	2.01	18.73
193	12:14:00	24.3	22.0	2.00	18.74
193	12:15:00	23.9	20.6	1.99	18.76
193	12:16:00	23.5	20.2	2.04	18.70
193	12:17:00	23.7	23.5	2.05	18.68
193	12:18:00	23.7	23.8	2.01	18.72
193	12:19:00	23.9	22.5	1.98	18.77

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT23A
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Dryer Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	12:20:00	23.2	20.2	1.97	18.80
193	12:21:00	23.3	19.9	1.97	18.79
193	12:22:00	23.9	19.5	1.98	18.79
193	12:23:00	23.8	20.4	1.99	18.75
193	12:24:00	23.9	19.0	1.99	18.77
193	12:25:00	23.1	20.8	2.03	18.71
193	12:26:00	23.7	20.5	2.00	18.75
193	12:27:00	23.7	19.6	1.97	18.78
193	12:28:00	23.7	18.2	2.00	18.74
193	12:29:00	23.5	19.7	1.96	18.79
193	12:30:00	22.8	18.6	2.01	18.74
193	12:31:00	23.4	20.9	1.98	18.76
193	12:32:00	23.2	16.4	2.00	18.77
193	12:33:00	23.2	19.0	2.01	18.72
193	12:34:00	24.1	18.6	1.97	18.78
193	12:35:00	23.9	15.8	1.94	18.82
193	12:36:00	24.0	13.6	1.95	18.82
193	12:37:00	23.5	14.8	1.99	18.75
193	12:38:00	23.6	16.7	1.96	18.78
193	12:39:00	23.1	15.3	1.96	18.78
193	12:40:00	23.0	17.2	1.96	18.79
193	12:41:00	22.9	16.3	2.00	18.74
193	12:42:00	23.0	20.8	1.98	18.74
193	12:43:00	23.5	16.2	1.99	18.78
193	12:44:00	22.9	20.7	2.07	18.65
193	12:45:00	23.2	21.6	1.98	18.74
Run Average		23.9	22.0	2.03	18.71

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT31
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

GEKA Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	19:56:00	51.8	11.1	6.45	13.86
193	19:57:00	54.0	10.2	6.54	13.78
193	19:58:00	53.3	8.8	6.09	14.23
193	19:59:00	52.2	8.5	5.86	14.54
193	20:00:00	54.3	8.7	6.26	14.15
193	20:01:00	55.3	10.1	6.20	14.15
193	20:02:00	56.9	12.3	6.37	14.01
193	20:03:00	56.7	12.9	6.14	14.14
193	20:04:00	55.8	12.7	6.26	14.15
193	20:05:00	54.2	14.6	6.13	14.19
193	20:06:00	54.8	13.0	6.36	14.04
193	20:07:00	53.1	10.1	6.36	13.93
193	20:08:00	53.1	8.7	6.42	13.93
193	20:09:00	51.7	9.1	6.38	13.93
193	20:10:00	50.3	9.4	5.99	14.34
193	20:11:00	52.0	9.3	6.14	14.26
193	20:12:00	50.2	11.1	6.11	14.22
193	20:13:00	55.3	10.1	6.50	13.87
193	20:14:00	52.9	11.2	6.19	14.07
193	20:15:00	49.2	6.7	5.95	14.46
193	20:16:00	48.4	7.6	6.28	14.07
193	20:17:00	46.7	7.4	6.15	14.21
193	20:18:00	49.4	11.2	6.59	13.71
193	20:19:00	45.6	10.7	6.34	13.93
193	20:20:00	45.9	8.9	6.19	14.20
193	20:21:00	46.5	8.5	6.09	14.24
193	20:22:00	48.0	11.2	5.82	14.58
193	20:23:00	50.4	11.6	6.50	13.84
193	20:24:00	47.7	12.4	6.09	14.25
193	20:25:00	48.4	13.8	6.36	13.99
193	20:26:00	46.9	14.1	6.15	14.18
193	20:27:00	49.2	14.6	6.36	13.95
193	20:28:00	49.0	17.3	5.86	14.45
193	20:29:00	51.0	11.9	5.99	14.46

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT31
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

GEKA Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	20:30:00	51.3	11.0	5.85	14.45
193	20:31:00	53.5	10.4	6.17	14.28
193	20:32:00	47.3	9.7	6.19	14.12
193	20:33:00	46.9	9.7	6.39	13.90
193	20:34:00	49.1	7.3	5.71	14.57
193	20:35:00	52.1	7.8	5.66	14.86
193	20:36:00	47.9	12.2	6.23	14.05
193	20:37:00	49.2	11.0	5.99	14.41
193	20:38:00	47.8	10.8	6.13	14.19
193	20:39:00	49.7	8.7	6.33	14.02
193	20:40:00	50.1	7.5	5.99	14.27
193	20:41:00	50.8	7.0	5.64	14.78
193	20:42:00	50.1	9.9	5.73	14.64
193	20:43:00	51.4	10.8	6.16	14.24
193	20:44:00	50.3	9.5	6.44	13.93
193	20:45:00	47.8	10.0	6.41	13.80
193	20:46:00	48.8	7.7	6.07	14.29
193	20:47:00	49.7	8.7	6.09	14.26
193	20:48:00	46.6	8.2	5.99	14.34
193	20:49:00	49.5	7.8	6.29	14.06
193	20:50:00	50.4	10.2	5.84	14.43
193	20:51:00	49.8	7.9	5.59	14.90
193	20:52:00	49.8	11.4	6.39	13.91
193	20:53:00	48.0	12.4	6.66	13.65
193	20:54:00	45.9	9.5	6.44	13.75
193	20:55:00	44.9	7.4	5.69	14.61
Run Average		50.3	10.2	6.16	14.18

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT32
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

GEKA Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	21:11:00	46.0	8.2	6.15	14.31
193	21:12:00	46.9	9.8	6.58	13.78
193	21:13:00	43.3	7.2	6.29	14.15
193	21:14:00	45.8	5.8	6.17	14.24
193	21:15:00	43.5	6.4	6.27	14.21
193	21:16:00	50.2	5.5	6.21	14.25
193	21:17:00	46.9	5.9	5.84	14.63
193	21:18:00	47.8	5.7	5.60	14.91
193	21:19:00	47.8	7.0	5.86	14.73
193	21:20:00	45.4	12.5	6.08	14.40
193	21:21:00	44.9	11.7	6.52	13.97
193	21:22:00	44.9	9.1	6.14	14.31
193	21:23:00	44.2	8.0	6.33	14.16
193	21:24:00	41.7	7.6	6.17	14.29
193	21:25:00	43.6	7.4	6.24	14.31
193	21:26:00	42.7	7.2	6.13	14.33
193	21:27:00	43.0	4.7	5.88	14.64
193	21:28:00	45.4	5.3	6.02	14.51
193	21:29:00	44.3	8.7	5.86	14.66
193	21:30:00	45.1	10.7	6.25	14.34
193	21:31:00	46.5	11.6	6.47	14.03
193	21:32:00	45.1	13.1	6.33	14.11
193	21:33:00	48.3	11.3	6.28	14.19
193	21:34:00	42.9	6.9	5.94	14.56
193	21:35:00	41.7	4.4	6.20	14.38
193	21:36:00	40.8	6.5	6.03	14.47
193	21:37:00	40.8	5.7	6.18	14.40
193	21:38:00	41.3	6.3	6.19	14.32
193	21:39:00	42.2	6.6	6.43	14.06
193	21:40:00	43.3	7.0	6.16	14.44
193	21:41:00	47.8	8.1	6.26	14.14
193	21:42:00	44.8	7.9	5.70	14.83
193	21:43:00	43.1	5.4	5.73	14.91
193	21:44:00	44.7	7.3	5.90	14.63

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT32
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

GEKA Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	21:45:00	48.0	9.6	6.14	14.47
193	21:46:00	47.9	9.4	6.20	14.35
193	21:47:00	49.6	8.2	6.22	14.28
193	21:48:00	50.9	7.4	5.74	14.77
193	21:49:00	49.0	9.2	5.60	15.02
193	21:50:00	45.2	7.3	6.16	14.41
193	21:51:00	41.8	7.7	5.87	14.66
193	21:52:00	43.3	5.7	6.10	14.49
193	21:53:00	45.2	7.6	5.95	14.52
193	21:54:00	47.1	10.8	5.89	14.79
193	21:55:00	45.1	11.2	6.19	14.32
193	21:56:00	43.4	7.3	6.24	14.31
193	21:57:00	44.0	5.2	6.12	14.36
193	21:58:00	44.2	9.4	5.91	14.67
193	21:59:00	42.3	10.1	6.29	14.24
193	22:00:00	43.1	9.8	5.99	14.53
193	22:01:00	44.0	8.7	6.16	14.41
193	22:02:00	42.3	8.5	6.12	14.40
193	22:03:00	44.6	8.1	6.27	14.28
193	22:04:00	42.7	5.8	6.20	14.29
193	22:05:00	43.3	4.8	6.23	14.33
193	22:06:00	40.8	5.2	6.23	14.29
193	22:07:00	41.6	6.1	6.24	14.34
193	22:08:00	39.8	7.3	6.21	14.29
193	22:09:00	42.8	6.7	5.86	14.69
193	22:10:00	42.2	8.3	6.11	14.42
Run Average		44.5	7.8	6.11	14.41

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT33
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

GEKA Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	22:26:00	39.3	7.5	6.24	14.28
193	22:27:00	39.5	7.9	6.21	14.32
193	22:28:00	42.0	6.3	6.26	14.20
193	22:29:00	41.2	4.1	6.34	14.24
193	22:30:00	40.2	5.6	6.35	14.12
193	22:31:00	42.2	7.5	6.18	14.38
193	22:32:00	39.7	8.6	6.26	14.21
193	22:33:00	40.0	7.7	6.18	14.40
193	22:34:00	39.5	8.9	6.17	14.34
193	22:35:00	41.6	5.8	6.05	14.54
193	22:36:00	38.3	7.4	6.30	14.19
193	22:37:00	39.7	7.5	6.09	14.47
193	22:38:00	38.4	9.1	6.47	14.03
193	22:39:00	39.4	8.3	6.24	14.30
193	22:40:00	39.2	8.5	6.39	14.13
193	22:41:00	40.7	9.5	6.06	14.44
193	22:42:00	40.1	6.9	6.08	14.50
193	22:43:00	39.5	8.3	6.14	14.42
193	22:44:00	41.2	12.1	6.28	14.26
193	22:45:00	41.3	12.4	6.32	14.26
193	22:46:00	39.6	10.0	6.57	13.87
193	22:47:00	39.1	8.5	6.24	14.31
193	22:48:00	40.9	7.1	6.29	14.20
193	22:49:00	43.5	7.2	5.84	14.72
193	22:50:00	45.3	8.9	6.35	14.26
193	22:51:00	42.5	8.6	6.29	14.20
193	22:52:00	41.6	9.8	6.35	14.15
193	22:53:00	42.3	7.7	6.07	14.45
193	22:54:00	42.9	7.3	6.52	14.00
193	22:55:00	40.5	7.2	6.29	14.16
193	22:56:00	41.6	5.4	6.35	14.18
193	22:57:00	40.8	6.0	6.15	14.36
193	22:58:00	41.3	5.6	6.01	14.60
193	22:59:00	42.0	8.8	6.24	14.26

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT33
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

GEKA Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	23:00:00	41.4	9.6	6.43	14.09
193	23:01:00	42.4	9.4	6.49	13.95
193	23:02:00	42.8	8.5	6.50	14.01
193	23:03:00	41.3	8.4	6.23	14.23
193	23:04:00	43.0	10.0	5.81	14.76
193	23:05:00	44.4	11.9	6.17	14.40
193	23:06:00	44.2	12.7	6.05	14.52
193	23:07:00	40.9	11.9	6.34	14.20
193	23:08:00	41.5	9.3	6.28	14.25
193	23:09:00	39.6	9.6	6.38	14.09
193	23:10:00	41.2	9.4	6.34	14.20
193	23:11:00	43.0	11.2	6.28	14.20
193	23:12:00	44.1	8.8	6.47	14.02
193	23:13:00	41.0	9.0	6.19	14.29
193	23:14:00	42.4	8.5	6.16	14.47
193	23:15:00	41.7	9.3	6.37	14.11
193	23:16:00	39.4	11.4	6.13	14.35
193	23:17:00	41.0	9.8	6.22	14.35
193	23:18:00	40.6	9.2	6.14	14.39
193	23:19:00	40.8	12.2	6.14	14.43
193	23:20:00	40.9	8.9	6.48	14.01
193	23:21:00	39.2	9.4	6.30	14.18
193	23:22:00	42.7	10.7	6.36	14.14
193	23:23:00	41.5	8.6	5.90	14.65
193	23:24:00	42.6	9.2	5.94	14.71
193	23:25:00	41.3	11.4	6.03	14.45
Run Average		41.2	8.8	6.24	14.29

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT41
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Press Vent Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO (ppmv)	O2 (%v/v)
194	09:16:00	13.4	20.82
194	09:17:00	10.8	20.83
194	09:18:00	10.9	20.83
194	09:19:00	11.9	20.83
194	09:20:00	16.0	20.83
194	09:21:00	14.5	20.82
194	09:22:00	14.1	20.83
194	09:23:00	12.5	20.83
194	09:24:00	10.2	20.83
194	09:25:00	11.0	20.82
194	09:26:00	12.2	20.83
194	09:27:00	14.6	20.83
194	09:28:00	15.6	20.83
194	09:29:00	15.5	20.83
194	09:30:00	17.7	20.83
194	09:31:00	13.7	20.83
194	09:32:00	13.5	20.83
194	09:33:00	12.8	20.83
194	09:34:00	11.1	20.84
194	09:35:00	9.6	20.83
194	09:36:00	11.6	20.83
194	09:37:00	12.2	20.83
194	09:38:00	12.1	20.83
194	09:39:00	14.4	20.83
194	09:40:00	14.2	20.83
194	09:41:00	9.8	20.83
194	09:42:00	8.4	20.83
194	09:43:00	9.3	20.83
194	09:44:00	9.8	20.83
194	09:45:00	11.9	20.83
194	09:46:00	12.4	20.83
194	09:47:00	11.2	20.84
194	09:48:00	12.7	20.85
194	09:49:00	10.9	20.85

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT41
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Press Vent Stack -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO (ppmv)	O2 (%v/v)
194	09:50:00	12.3	20.85
194	09:51:00	12.4	20.85
194	09:52:00	10.3	20.85
194	09:53:00	8.3	20.85
194	09:54:00	8.8	20.85
194	09:55:00	10.7	20.86
194	09:56:00	13.7	20.85
194	09:57:00	12.9	20.84
194	09:58:00	10.1	20.84
194	09:59:00	8.3	20.84
194	10:00:00	9.1	20.84
194	10:01:00	12.4	20.84
194	10:02:00	15.4	20.84
194	10:03:00	17.4	20.84
194	10:04:00	16.4	20.83
194	10:05:00	14.4	20.83
194	10:06:00	12.8	20.84
194	10:07:00	16.1	20.83
194	10:08:00	17.0	20.83
194	10:09:00	15.6	20.84
194	10:10:00	13.5	20.83
194	10:11:00	15.8	20.83
194	10:12:00	17.3	20.83
194	10:13:00	15.3	20.84
194	10:14:00	15.7	20.83
194	10:15:00	15.1	20.83
194	10:16:00	16.3	20.83
Run Average		12.9	20.83

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT42
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Press Vent Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO (ppmv)	O2 (%v/v)
194	11:06:00	12.8	20.79
194	11:07:00	12.8	20.78
194	11:08:00	13.5	20.79
194	11:09:00	13.0	20.79
194	11:10:00	12.2	20.78
194	11:11:00	13.8	20.78
194	11:12:00	14.3	20.78
194	11:13:00	13.3	20.79
194	11:14:00	12.8	20.78
194	11:15:00	11.8	20.79
194	11:16:00	10.5	20.78
194	11:17:00	10.6	20.78
194	11:18:00	11.2	20.78
194	11:19:00	14.1	20.78
194	11:20:00	14.7	20.78
194	11:21:00	15.6	20.78
194	11:22:00	14.2	20.77
194	11:23:00	15.7	20.77
194	11:24:00	14.9	20.77
194	11:25:00	13.5	20.77
194	11:26:00	15.2	20.77
194	11:27:00	16.3	20.77
194	11:28:00	17.6	20.77
194	11:29:00	16.0	20.77
194	11:30:00	11.6	20.77
194	11:31:00	10.2	20.77
194	11:32:00	9.9	20.77
194	11:33:00	13.2	20.77
194	11:34:00	11.0	20.77
194	11:35:00	12.2	20.77
194	11:36:00	15.2	20.77
194	11:37:00	17.2	20.77
194	11:38:00	12.1	20.77
194	11:39:00	9.5	20.77

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT42
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Press Vent Stack -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO (ppmv)	O2 (%v/v)
194	11:40:00	9.3	20.77
194	11:41:00	11.9	20.76
194	11:42:00	10.7	20.76
194	11:43:00	10.8	20.76
194	11:44:00	11.9	20.76
194	11:45:00	12.7	20.76
194	11:46:00	12.0	20.75
194	11:47:00	11.8	20.75
194	11:48:00	13.0	20.75
194	11:49:00	13.0	20.75
194	11:50:00	13.4	20.75
194	11:51:00	13.9	20.75
194	11:52:00	15.6	20.74
194	11:53:00	15.5	20.74
194	11:54:00	15.0	20.75
194	11:55:00	16.2	20.74
194	11:56:00	15.6	20.74
194	11:57:00	16.9	20.74
194	11:58:00	19.8	20.74
194	11:59:00	17.9	20.73
194	12:00:00	16.2	20.74
194	12:01:00	15.9	20.74
194	12:02:00	16.2	20.73
194	12:03:00	14.4	20.73
194	12:04:00	12.8	20.74
194	12:05:00	12.9	20.73
194	12:06:00	14.1	20.73
Run Average		13.6	20.76

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT43
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Press Vent Stack -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO (ppmv)	O2 (%v/v)
194	13:36:00	12.7	20.80
194	13:37:00	13.2	20.79
194	13:38:00	12.9	20.79
194	13:39:00	11.8	20.79
194	13:40:00	12.8	20.79
194	13:41:00	16.1	20.79
194	13:42:00	12.7	20.79
194	13:43:00	11.1	20.80
194	13:44:00	9.9	20.80
194	13:45:00	10.1	20.79
194	13:46:00	9.8	20.79
194	13:47:00	9.1	20.79
194	13:48:00	9.2	20.79
194	13:49:00	11.7	20.79
194	13:50:00	12.9	20.79
194	13:51:00	12.4	20.79
194	13:52:00	12.3	20.79
194	13:53:00	11.5	20.79
194	13:54:00	11.4	20.79
194	13:55:00	13.3	20.79
194	13:56:00	13.1	20.78
194	13:57:00	14.7	20.78
194	13:58:00	13.0	20.78
194	13:59:00	11.6	20.78
194	14:00:00	9.6	20.78
194	14:01:00	8.1	20.78
194	14:02:00	9.4	20.78
194	14:03:00	8.0	20.78
194	14:04:00	7.0	20.78
194	14:05:00	5.2	20.78
194	14:06:00	4.6	20.78
194	14:07:00	8.2	20.78
194	14:08:00	9.9	20.78
194	14:09:00	9.6	20.78

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1995 -

File Name: LPT43
Job Number: 5-6006
Client: Louisiana - Pacific
Location: Tomahawk, Wisconsin

Press Vent Stack -- Run 3


Julian Date	Time (Hrs)	Conc. (dry basis unless noted)	
		CO (ppmv)	O2 (%v/v)
194	14:10:00	9.7	20.77
194	14:11:00	10.1	20.78
194	14:12:00	9.2	20.78
194	14:13:00	7.7	20.77
194	14:14:00	6.4	20.77
194	14:15:00	6.3	20.77
194	14:16:00	6.1	20.77
194	14:17:00	7.0	20.78
194	14:18:00	8.3	20.78
194	14:19:00	9.7	20.77
194	14:20:00	7.7	20.77
194	14:21:00	9.0	20.77
194	14:22:00	9.6	20.77
194	14:23:00	9.8	20.77
194	14:24:00	7.6	20.77
194	14:25:00	6.1	20.77
194	14:26:00	6.2	20.77
194	14:27:00	4.9	20.77
194	14:28:00	4.4	20.76
194	14:29:00	4.9	20.77
194	14:30:00	7.4	20.76
194	14:31:00	9.4	20.77
194	14:32:00	9.4	20.77
194	14:33:00	10.8	20.77
194	14:34:00	11.3	20.77
194	14:35:00	10.3	20.77
194	14:36:00	8.0	20.77
Run Average		9.6	20.78

APPENDIX F

ANALYZER SPECIFICATIONS

Interpoll Laboratories
(612) 786-6020

CEM TRAILER



E = EXHAUST
FC = FLOW CONTROL
I = IMPINGER (METHOD 10a)

CEMTRAILER

Servomex

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1420 Oxygen Analyser Instruction Manual

Ref : 01420/001A/0

Order as part No. 01420001A

was (7982-2842)

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1.3 Sampling System

The sampling system of the analyser includes a combination filter/automatic flow control device, designed to keep a constant flow of sample gas through the measuring cell for varying input pressures and to prevent the entrance of particulate matter into the measuring cell. Excess flow is vented to the by-pass.

1.4 Specification

Performance Specification (typical)

Repeatability: Better than $\pm 0.2\%$ O₂ under constant conditions.

Drift: Less than 0.2% O₂ per week under constant conditions. (Excluding variation due to barometric pressure changes; reading is proportional to barometric pressure.)

Outputs

Display: 3 1/2 digit LCD reading 0.0 to 100.0% oxygen with overrange capability.

Output: 0 to 1V (non-isolated) for 0 to 100% oxygen available on 'D' type connector located on the back panel of the instrument. Output impedance is less than 10 ohms.

Option: 4 - 20mA isolated, Max impedance 500 ohms.

Flow alarm output: Change over relay contact rated at 3A/115V ac, 1A/240V ac or 1A/28V dc. 4 sets of single pole changeover contacts. Alarm becomes active when sample gas flow through the analyser fails.

Sample requirements

Condition: Clean, dry gas with dew point 5 deg C below ambient temperature.

Inlet pressure: 0.5 to 3psig (3.5 to 21kPa). Inlet pressure changes within this range will change the reading by less than 0.1% O₂. May be operated up to 10psig (70kPa) with degraded stability.

Flowrate: 1.5 to 6 litres/minute approximately depending on sample pressure.

Filtering: 0.6 micron replaceable filter integral to the automatic flow control device.

Response time: Less than 15 secs. to 90% at an inlet pressure of 3psig (21kPa).

Inlet/vent connections: 1/4 inch OD tube (stainless steel) suitable for 6mm ID flexible tubing or 1/4 inch OD compression fittings.

Materials exposed to the sample: Stainless steel, Pyrex glass, brass, platinum, epoxy resin, Viton, polypropylene and glass fibre filter.

Physical Characteristics

Case: Steel and aluminium finished in epoxy powder paint.

Case classification: IP 20 (IEC 529) when fitted into the Servomex 1400 series 19 inch case.

Dimensions: See Figure 2.1.

Weight: 10Kg (22lb) approximately.

Electrical

AC Supply: 110 to 120V AC or 220 to 240V AC, +/-10%, 48 to 62Hz. Voltage selected by a voltage selector integral to the IEC supply plug.

Power required: 15VA maximum.

Environmental Limits

Operating ambient temperature: 0 to +40 deg C (32 to 104 deg F)

Storage temp. range: -20 to +70 deg C (-4 to 158 deg F)

Relative humidity: 0-85%, non-condensing.

SPECIFICATIONS FOR ACS MODEL 3300 CO₂ NDIR

Measuring principle	NDIR single beam method
Measurable gas components and measuring range	0 - 20%
Reproducibility	±0.5% of full scale
Stability	Zero drift; ±% of full scale/24H Span drift; ±% of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500Ω max.)
Linearity	Better than ±2% of full scale (when linearizer is used)
Power supply	AC 115 V ± 10%, 60 Hz

Power consumption	Approx. 30 VA
Materials of gas-contacting parts	Measuring cell; SUS304 Window; CaF ₂ Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.

SPECIFICATIONS FOR MODEL 10A
ROCK MOUNTED CHEMILUMINESCENT
NO-NO₂ GAS ANALYZER

Sensitivity	Each instrument is equipped with the following ranges: 0 - 2.5 ppm 0 - 10 ppm 0 - 25 ppm 0 - 100 ppm 0 - 250 ppm 0 - 1000 ppm 0 - 2500 ppm 0 - 10000 ppm
Accuracy	Derived from the NO or NO ₂ calibration gas, $\pm 1\%$ of fullscale
Response time (0-90%) Typical	1.5 seconds - NO Mode 1.7 seconds - NO _x Mode
Output	0 - 10mV and 0 - 10V
Zero Drift	Negligible after 1/2-hour warm-up
Linearity	$\pm 1\%$ of full scale
Input Power Requirements	115v/50Hz; 115v/60Hz

See manual for details
for model 10A and 10B
(see page 10)

For more information, contact:
Rockwell International Corp.
P.O. Box 1000
El Segundo, CA 90245

SH 30, 201 ± 10 Hz

Figure 1-1

SPECIFICATIONS FOR ACS MODEL 3300 CO NDIR

Measuring principle	NDIR single beam method
Operating ranges	0 - 500 ppm 0 - 1000 ppm
Reproducibility	$\pm 0.5\%$ of full scale
Stability	Zero drift; $\pm\%$ of full scale/24H Span drift; $\pm\%$ of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500 Ω max.)
Linearity	Better than $\pm 2\%$ of full scale (when linearizer is used)
Power supply	AC 115 V $\pm 10\%$, 60 Hz

Power consumption	Approx. 30 VA
Materials of gas- contacting parts	Measuring cell; SUS304 Window; CaF ₂ Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.

APPENDIX G

MEASUREMENT SYSTEMS PERFORMANCE SPECIFICATIONS

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Tomahawk
Source Dryer Stack
Test 1 Run Date 7-11-85 - 7-12-85
Stack Dimen. 59.0 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☐ Elec.
Barometric Pressure _____ IN.HG
Static Pressure _____ IN.WC
Operators B. Aschenbach Tray Hansen
Pitot No. 1.1 INST C₁

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]

R or nothing - reg. manometer; S - expanded; E - electronic

INTERPOLL LABORATORIES, INC

(612) 786-6020

NOx Cal Drift Check

Job

LP / Tomahawk

Source

Piper

Test

1 RunDate 2-11-95

Site

STACK

Operator

Bob

N.G.

0715

0702

1022

1142

1000
1233

1352

1547

0720

1001

1130

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	7.56	Zero Gas	0	3	1	2		
		Upscale	86.7	86	86		0	
2	11.81	Zero Gas	0	1	6	5		
		Upscale	86.7	86	87		1	
3	13.66	Zero Gas	0	6	5	1		
		Upscale	86.7	87	89		2	
4		Zero Gas	0	5	4	1		
		Upscale	86.7	89	87		2	
1		Zero Gas	0	4	3	1		
		Upscale	86.7	87	90		1	
2	30.13 17.80 10	Zero Gas	0	3	4	1		
		Upscale	86.7	88	89		1	
3	29.70	Zero Gas	0	4	3	1		
		Upscale	86.7	89	87		2	
4	25.86	Zero Gas	0	3	1	2		
		Upscale	86.7	87	86		1	
5		Zero Gas	0	1	1	0		
		Upscale	86.7	86	91		5	
6		Zero Gas	0	1	1	0		
		Upscale	86.7	81	86		5	
7		Zero Gas	0	1	1	0		
		Upscale	86.7	86	85		1	
8		Zero Gas	0	1	1	0		
		Upscale	86.7	85	84		1	

080

085

092

1010

1046

1135

125

144

154

074

0845

090

095

114

1244

Must be within 5% or the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC
(612) 786-6020

CO Cal Drift Check

Job LP/Tomahawk Source Bryer
Test 1 Run Date 7-11-95 Site STACK
Operator BBB

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	10.52	Zero Gas	0	3	1	2		
		Upscale	150	146	145		1	
2	8.21	Zero Gas	0	1	2	1		
		Upscale	150	145	145		0	0
3	10.0	Zero Gas	0	2	2	0		0
		Upscale	150	145	146		1	
4		Zero Gas	0	2	2	0		0
		Upscale	150	146	145		1	
1	17.8	Zero Gas	0	2	0	2		
		Upscale	150	145	145		0	
2	13.18	Zero Gas	0	0	1	1		
		Upscale	150	145	145		0	
3		Zero Gas	0	1	0	1		
		Upscale	150	145	144		1	
4	20.31	Zero Gas	0	0	1	1		
		Upscale	150	144	145		1	
5		Zero Gas	0	1	3	2		
		Upscale	150	145	148		3	
6		Zero Gas	0	3	2	1		
		Upscale	150	148	147		1	
7		Zero Gas	0	2	1	1		
		Upscale	150	147	146		1	
8		Zero Gas	0	1	2	1		
		Upscale	150	146	144		2	

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

Q1 Cal Drift Check

Job

LP / Tomahawk

Source

Dryer

Test

1 Run 7-11-85

Site

STACK

Operator

SOB





Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	19.7	Zero Gas	0	.1	0	.1		
		Upscale	13.5	13.8	13.7		.1	
2	19.74	Zero Gas	0	0	0	0		0
		Upscale	13.5	13.7	13.8		.1	
3	19.63	Zero Gas	0	0	0	0		0
		Upscale	13.5	13.8	13.7		.1	
4		Zero Gas	0	0	0	0		0
		Upscale	13.5	13.7	13.7		0	0
1	19.16	Zero Gas	0	0	0	0		
		Upscale	13.5	13.7	13.8		.1	
2	19.36	Zero Gas	0	0	0	0		0
		Upscale	13.5	13.8	13.8		0	
3		Zero Gas	0	0	0	0		
		Upscale	13.5	13.6	13.8		0	
4		Zero Gas	0	0	.1	.1		
		Upscale	13.5	13.8	13.8		0	
5		Zero Gas	0	.1	0	.1		
		Upscale	13.5	13.8	13.6		.2	
6		Zero Gas	0	0	0	0		
		Upscale	13.5	13.6	13.6		0	
7		Zero Gas	0	0	0	0		
		Upscale	13.5	13.6	13.6		0	
8		Zero Gas	0	0	0	0		
		Upscale	13.5	13.6	13.5		.1	

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

CO₂ Cal Drift Check

Job LP / Dmahawk Source Dryer
Test 1 Run 7- -95 Site STACK
Operator Bob

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	1.05	Zero Gas	0	.1	0	.1		
		Upscale	10.7	10.5	10.6		.1	
2	1.00	Zero Gas	0	0	.1	.1		
		Upscale	10.7	10.6	10.7		.1	
3	1.04	Zero Gas	0	.1	0	.1		
		Upscale	10.7	10.7	10.5		.2	
4		Zero Gas	0	0	.1	.1		
		Upscale	10.7	10.5	10.6		.1	
1	2.00	Zero Gas	0	.1	0	.1		
		Upscale	10.7	10.6	10.7		.1	
2	2.00	Zero Gas	0	.1	.3	.2		
		Upscale	10.7	10.7	10.8			
3		Zero Gas	0	.3	.1	.2		
		Upscale	10.7	10.8	10.7		.1	
4		Zero Gas	0	.1	.1	0		
		Upscale	10.7	10.7	10.8		.1	
5		Zero Gas	0	.1	0	.1		
		Upscale	10.7	10.8	10.5		.3	
6		Zero Gas	0	0	0	0		
		Upscale	10.7	10.5	10.5		0	
7		Zero Gas	0	0	.1	.1		
		Upscale	10.7	10.5	10.5		0	
8		Zero Gas	0	.1	0	.1		
		Upscale	10.7	10.5	10.4		.1	

Must be within 5% or the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Job CP / Tomahawk
Source GERA STAGE
Test 3 Run Date _____
Stack Dimen. 42 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer ☐ Reg. ☐ Exp ☐ Elec.
Barometric Pressure _____ IN.HG
Static Pressure _____ IN.WC
Operators B. Beckwith, T. Traylor
Pitot No. _____ C_p _____

Drawing of Test Site

Cross-section View	Elevation View

[illegible]

R or nothing - reg. manometer; S - expanded; E - electronic

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOLL LABORATORIES, INC

(612) 786-6020

NOV Cal Drift Check

Job

LP Tonnage

Source

GERA

Test

3 Run 7-12-95

Site

Stack

Operator

BA

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C_s	C_m	C_{gas}
				Initial	Final			
1		Zero Gas	0	1	1	0		
		Upscale	86.7	84	86		2	
2		Zero Gas	0	1	1	0		
		Upscale	86.7	86	84			
3		Zero Gas	0	1	2	1		
		Upscale	86.7	84	86		2	
4		Zero Gas	0	2	2	0		
		Upscale	86	86	85		1	
5		Zero Gas	0	2	1	1		
		Upscale	86	85	84		1	
6		Zero Gas	0	1	1	0		
		Upscale	86	84	83		1	
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% or the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

10 Cal Drift Check

Job

LP Tomahawk

Source

GETA

Test

3 Run 7-12-95

Site

STAC

Operator

BBB

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C_o	C_m	C_{gas}
				Initial	Final			
1		Zero Gas	0	1	2	1		
		Upscale	150	145	146		1	
2		Zero Gas	0	2	2	0		
		Upscale	150	146	146		0	
3		Zero Gas	0	2	2	0		
		Upscale	150	144	144		0	
4		Zero Gas	0	2	2	0		
		Upscale	150	144	144		0	
5		Zero Gas	0	2	1	1		
		Upscale	150	144	144		0	
6		Zero Gas	0	1	2	1		
		Upscale	150	144	143		1	
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC
(612) 786-6020

O₂ Cal Drift Check

Job LP / Tomahawk Source GEKA
Test 3 Run 7-12-95 Site SMCC
Operator BO

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0	0	0		
		Upscale	13.5	13.5	13.5		0	
2		Zero Gas	0	0	0	0		
		Upscale	13.5	13.5	13.5		0	
3		Zero Gas	0	0	0	0		
		Upscale	13.5	13.5	13.4		-1	
4		Zero Gas	0	0	0	0		
		Upscale	13.5	13.4	13.4		0	
5		Zero Gas	0	0	0	0		
		Upscale	13.5	13.4	13.5			
6		Zero Gas	0	0	0	0		
		Upscale	13.5	13.5	13.6		-1	
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

CO₂ Cal Drift Check

Job

LP / Tanawhau

Source

GENA

Test

3 RunDate 7-12-95

Site

STRELL

Operator

BGB

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0	0	0		
		Upscale	10.7	10.4	10.5		.1	
2		Zero Gas	0	0	.2	.2		
		Upscale	10.7	10.5	10.6		.1	
3		Zero Gas	0	.2	.2	0		
		Upscale	10.7	10.6	10.5		-.1	
4		Zero Gas	0	-.2	.2	0		
		Upscale	10.7	10.5	10.5		0	
5		Zero Gas	0	.2	.2	0		
		Upscale	10.7	10.5	10.5		0	
6		Zero Gas	0	.2	.2	0		
		Upscale	10.7	10.5	10.6		-.1	
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Tomahawk
Source Press Vent Stairs
Test 4 Run 7-13-88
Stack Dimen. 62.5 IN.
Dry Bulb °F Wet bulb °F
Manometer ☐ Reg. ☐ Exp ☐ Elec.
Barometric Pressure IN.HG
Static Pressure IN.WC
Operators B. Schleich T. Hansen
Pitot No. 6th FUSE C₂

Cross-section View	Elevation View
-----------------------	-------------------

[illegible]


R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOL LABORATORIES, INC

(612) 786-6020

CO Cal Drift Check

Job CP / Tomahawk Source Press VENT
 Test 4 Run _____ Date 2-13-95 Site Stack
 Operator 603

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	2	2	0		
		Upscale	150	143	144		1	
2		Zero Gas	0	2	2	0		
		Upscale	150	144	146		2	
3		Zero Gas	0	2	2	0		
		Upscale	150	140	146		0	
4		Zero Gas	0	2	2	0		
		Upscale	150	146	144		2	
5		Zero Gas	0					
		Upscale						
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

02 Cal Drift Check

Job LP/ Tomahawk Source Press Vent
Test 4 Run 7-13-95 Site STALL
Operator AS

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0	0	0		
		Upscale	13.5	13.6	13.6		0	
2		Zero Gas	0	0	0	0		
		Upscale	13.5	13.6	13.4		.2	
3		Zero Gas	0	0	0	0		
		Upscale	13.5	13.4	13.30		.1	
4		Zero Gas	0	0	0	0		
		Upscale	13.5	13.3	13.4		.1	
5		Zero Gas	0					
		Upscale						
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

CO₂ Cal Drift Check

Job

CP/Tomahawk

Source

Press UNIT

Test

LC

Run

Date 2-13-85

Site

Static

Operator

CRB

Run	$\bar{C}$	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	.2	.2	0		
		Upscale	10.7	10.6	10.6		0	
2		Zero Gas	0	.2	0	.2		
		Upscale	10.7	10.0	10.5		.1	
3		Zero Gas	0	0	.1			
		Upscale	10.7	10.5	10.6		.1	
4		Zero Gas	0	.1	.2	.1		
		Upscale	10.7	10.6	10.4		.2	
5		Zero Gas	0					
		Upscale						
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

Instrumental Analysis Preliminary Field Calculations

603
7-13-95

[illegible]

APPENDIX H

CALIBRATION GAS CERTIFICATION SHEETS

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, N.C. 27713
(919) 544-3772

TO: TWIN CITY OXYGEN

CERTIFICATE OF ANALYSIS

DATE REPORTED: 11/10/94

REFERENCE #:88-34977


MATERIAL SUBMITTED:OXYGEN, CARBON DIOXIDE IN NITROGEN,
CERTIFIED CYL. #CC36114

INFORMATION REQUESTED:RATIO ANALYSIS

METHOD OF ANALYSIS:OXYGEN ANALYZER

RESULT OF INVESTIGATION:

<u>COMPONENT</u>	<u>SPECIFICATION</u>	<u>CONCENTRATION</u>
OXYGEN	13.5%	13.5%
CARBON DIOXIDE	11%	10.7%
NITROGEN		BALANCE


AUTHORIZED SIGNATURE

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, N.C. 27713
(919) 544-3772

TO: TWIN CITY OXYGEN

CERTIFICATE OF ANALYSIS

DATE REPORTED: 12/13/93

REFERENCE #:88-28413


MATERIAL SUBMITTED: CARBON DIOXIDE AND OXYGEN IN NITROGEN,
CERTIFIED CYL. #CC112272

INFORMATION REQUESTED: RATIO ANALYSIS

METHOD OF ANALYSIS: INFRARED AND OXYGEN ANALYZERS

RESULT OF INVESTIGATION:

<u>COMPONENT</u>	<u>SPECIFICATION</u>	<u>CONCENTRATION</u>
CO2	17%	16.4%
O2	21%	21.2%
N2		BALANCE


AUTHORIZED SIGNATURE

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

Interpoll Laboratories, Inc.
(612) 786-6020

CERTIFICATE OF ANALYSIS FOR
NO STANDARD GASES FOR METHOD 7E

Vendor: National Specialty Gases
Cylinder No: CC114264
Date of Preparation: 6-11-93
Label: 86.7 ppm NOx
Blend Specification: _____

Results Of Analyses Of Standard Gas (by Method 7A)

Date of Analysis	Run	NO in N ₂ (ppm)
<u>8-10-93</u>	1	<u>88.57</u>
_____	2	<u>88.65</u>
_____	3	<u>88.37</u>
_____	4	_____
_____	5	_____
_____	6	_____
_____	Avg	<u>88.53</u>

Analyst: Bob Aschenbach

- ☒ Results are within 10% of the vendor tag value; use tag value.
☐ Results are not within 10% of the vendor tag value; conduct another set of triplicate analyses.
☐ Results of six consecutive analyses within $\pm 10\%$ of the average; relabel as above.
☐ All results not within $\pm 10\%$ of the average; perform another set of triplicate analyses.

Approved by,

August 16, 1993
Date

Perry Lonnes
Dr. Perry Lonnes

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1993 -

File Name: CG5
Job Number: 3-3333
Client: Interpoll Laboratories Inc.
Location: Circle Pines, Minnesota

CC114264 - 86.7 ppm NOx -- Run 1 - 3

Julian

Time

Conc. (dry basis unless noted)

Date	(Hrs)	NOx (ppmv)
222	11:19:00	88.6
222	11:19:30	88.5
222	11:20:00	88.7
222	11:20:30	88.5
222	11:21:00	59.5
222	11:21:30	1.7
222	11:22:00	1.5
222	11:22:30	181
222	11:23:00	233
222	11:23:30	203
222	11:24:00	113
222	11:24:30	89.3
222	11:25:00	88.8
222	11:25:30	88.7
222	11:26:00	88.5
222	11:26:30	88.5
222	11:27:00	176
222	11:27:30	233
222	11:28:00	157
222	11:28:30	2.2
222	11:29:00	1.7
222	11:29:30	1.5
222	11:30:00	29.9
222	11:30:30	88.1
222	11:31:00	88.1
222	11:31:30	88.4
222	11:32:00	88.3
222	11:32:30	88.4
222	11:33:00	88.4
222	11:33:30	88.5

Run 1 <

Run 2 <

Run 3 <

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC 27713
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-24727 CYLINDER #: CC114264 CYL. PRESSURE: 2000PSIG

EXPIRATION DATE: 6-11-95

LAST ANALYSIS DATE: 6-11-93

CUSTOMER: TWIN CITY

P.O.# 59810

METHOD: EPA PROTOCOL # 13.0.4.G-1

STANDARD:

SRM #: 1684B

CYL #: CLM2226

CONC.: 95.2PPM

INSTRUMENT:

BECKMAN

COMPONENT: CHEMILUMINESCENT

MODEL #: 951A

SERIAL #: 0101572

LAST CAL: 4-2-93

COMPONENT: NO

MEAN CONC: 86.7PPM

REPLICATE CONC.

DATE: 6-4-93

DATE: 6-11-93

86.2PPM

87.0PPM

86.6PPM

87.1PPM

86.1PPM

86.9PPM

COMPONENT:

MEAN CONC:

REPLICATE CONC.

DATE:

DATE:

COMPONENT:

MEAN CONC:

REPLICATE CONC.

DATE:

DATE:

BALANCE GAS: N2

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC 27713
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-26556 CYLINDER #:CC63681 CYL PRESSURE:2000PSIG

EXPIRATION DATE: 9/9/95 LAST ANALYSIS DATE:9/9/93

CUSTOMER:TWIN CITY OXYGEN P.O.# 6232
METHOD: EPA PROTOCOL # 13.0.4. G-1

STANDARD:

SRM #:1685B

CYL #:CLM4908

CONC.:244.4PPM

INSTRUMENT:

COMPONENT: BECKMAN CHEMILUMINESCENT

MODEL #: 951A

SERIAL #: 0101572

LAST CAL: 9/1/93

COMPONENT:	NO	<u>REPLICATE CONC.</u>	
MEAN CONC:	142PPM	DATE: 9/2/93	DATE: 9/9/93
		141PPM	142PPM
		142PPM	141PPM
		143PPM	142PPM

COMPONENT:	NO2	<u>REPLICATE CONC.</u>	
MEAN CONC:	1.07PPM	DATE:	DATE:

COMPONENT:		<u>REPLICATE CONC.</u>	
MEAN CONC:		DATE:	DATE:

BALANCE GAS:N2



Scott Specialty Gases

a division of
Scott Environmental Technology, Inc.

Shipped From : Scott, Michigan

Our Project # : 338035

Your P.O. # : 40142

Expiration Date : 12-22-93

Cylinder Number : ALN014793

Cylinder Pressure : 1900 psig

1 of 1 Component(s)

1290 COMBERMERE STREET, TROY, MICHIGAN 48084 (313) 589-2950

Customer :

GENEX

C/O AES BARBER POINT COAL

91-086 KADMI LOOP

EMA BEACH HI 96707

1111 CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES 1111

PERFORMED ACCORDING TO SECTION 3.0.4

Certified Per Traceability Procedure # 81

Protocol # 1

File # PO 3626

Certified Accuracy 1 ± NBS Traceable

INSTRUMENTATION

REFERENCE STD

ANALYZED CYLINDER

CERTIFIED CONC.

SRM # CYLINDER NUMBER

INSIR/MODEL/SERIAL # LAST CALIBRATION DATE

ANALYTICAL PRINCIPLE

CARBON MONOXIDE

150.5 PPM

1680

475.00 PPM

BECKMAN

6-3-92

NON-DISPERSIVE INFRARED

ALANCE GAS : NITROGEN

951A
270-0828998

FIRST ANALYSIS

DATE : 6-16-92

SECOND ANALYSIS

DATE : 6-22-92

ZERO : TEST

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

ZERO : TEST

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

ZERO : TEST

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

ZERO : TEST

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

REFERENCE : REFERENCE

GAS : GAS

(mV) : (mV)

RESULTS : RESULTS

PPM : PPM

CONC. : CONC.

CALIBRATION CURVE

2 nd DEGREE

SRM # CONC. SPLIT DVM FITTED PERCENT

(CRM #) PPM PT (%) (mV) VALUE ERROR

1680 475.00 100 175.00 475.00 0.00

2636 243.40 51 91.60 244.14 0.30

6HIS 240.40 51 89.90 239.52 -0.37

1679 96.67 20 36.80 96.86 0.19

0.00 0 0.00 0.00 0.00

0 0 0.0000 0.00

0 0 0.00 0.00

2636 243.4 LOW 91.60 244.14 0.00

1680 475.00 HIGH 175.00 475.00 0.00

J. Shapiro

Ann Fisher

Ann Fisher

Ann Fisher

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, N.C. 27713
(919) 544-3772

TO: TWIN CITY OXYGEN

CERTIFICATE OF ANALYSIS

DATE REPORTED: 4-20-93

REFERENCE #: 88-23715

MATERIAL SUBMITTED: CARBON MONOXIDE IN NITROGEN, CERTIFIED
CYLINDER#CC109767

INFORMATION REQUESTED: RATIO ANALYSIS

METHOD OF ANALYSIS: INFRARED

RESULT OF INVESTIGATION:

<u>COMPONENT</u>	<u>SPECIFICATION</u>	<u>CONCENTRATION</u>
CARBON MONOXIDE	300 PPM	312 PPM
NITROGEN		BALANCE

Richard Sykes
AUTHORIZED SIGNATURE

THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE. ANY USE OF THIS REPORT OR THE INFORMATION CONTAINED HEREIN SHALL BE AT THE SOLE RISK OF THE USER.

APPENDIX I

PROCESS RATE INFORMATION

**STACK TESTING PERFORMED FOR
LOUISIANA-PACIFIC CORPORATION
AT THEIR ORIENTED STRANDBOARD FACILITY
LOCATED NEAR TOMAHAWK WISCONSIN
ON JULY 11, 12, & 13, 1995**

PROCESS DATA

PAGE #

TEST SCHEDULE / PROCESS DATA SUMMARY
DATA SPECIFIED IN TEST PLAN

2 - 3
4 - 9

DRYER TESTING ON NATURAL GAS

BOARD WEIGHTS / PRODUCTION / BTU INPUT
DRYER DATA SHEETS
DRYER CHARTS
PRESS CHARTS
PRESS REPORT
E-TUBE DATA SHEETS
UNIT INFORMATION SHEET

10 - 12
13 - 17
18 - 19
20 - 21
22
23 - 24
25

DRYER TESTING ON WOOD

BOARD WEIGHTS / PRODUCTION / BTU INPUT
DRYER DATA SHEETS
DRYER CHARTS
PRESS CHARTS
PRESS REPORT
E-TUBE DATA SHEETS
UNIT INFORMATION SHEET

26 - 28
29 - 31
32 - 33
34 - 35
36
37 - 38
39

GEKA THERMAL OIL HEATER TESTING ON BARK

BOARD WEIGHTS / PRODUCTION / BTU INPUT
PRESS CHARTS
PRESS REPORT
GEKA REPORT / DATA SHEET

40 - 41
42 - 43
44 - 45
46 - 47

PRESS TESTING

BOARD WEIGHTS / PRODUCTION / BTU INPUT
PRESS CHARTS
PRESS REPORT
RESIN & WAX USAGE
UNIT INFORMATION SHEET

48 - 49
50 - 51
52 - 53
54
55

TEST SCHEDULE / PROCESS DATA SUMMARY

TOMAHAWK WI

TESTING TIMES (military)

DATE	TFP @ HR.	TDF @ HR.	POLLUTANT	RUN #1	RUN #2	RUN #3
------	-----------	-----------	-----------	--------	--------	--------

DRYERS OUTLET TESTING (WOOD)

			CO	7:45-8:45	9:00-10:00	11:45-12:45
July 12, '95	11.9	2.43	NOX			

DRYERS OUTLET TESTING (GAS)

July 11, '95	11.5	36.18mmBTU	CO	8:00-9:00	9:20-10:20	10:40-11:40
--------------	------	------------	----	-----------	------------	-------------

THERMAL OIL HEATER (BARK)

			CO	19:55-20:55	21:10-22:10	22:25-23:25
July 12, '95	11.0	1.03	NOX			

PRESS

			CO	9:15-10:15	11:05-12:05	13:35-14:35
July 13, '95	10.9	2.42	TSP			

PRETEST INFORMATION FOR TOMAHAWK, WISCONSIN

1. Description of the air pollution control equipment associated with the process:

THERMAL OIL HEATER

- a) Particulate emissions from the GEKA thermal oil heater are controlled by a cyclone installed in series with a baghouse.
- b) The baghouse is designed to operate at a pressure drop of 2 to 6 inches of water column.
- c) The maximum design airflow through the stack is 32,600 acfm. The rated heat input capacity of the heater is 30mm BTUs. Control efficiencies of the cyclone and baghouse are estimated to be 50% and 99% respectively.
- d) Collected material is presently stored temporarily on site. In the future this material will be either landfilled or spread as a soil amendment.

DRYER

- a) Particulate emissions from each MEC dryer are controlled by a set of multicyclones installed in series with a E-TUBE wet electrostatic precipitator.
- b) Specific multicyclone operating parameters are not monitored. The wet electrostatic precipitator operates within the following ranges:
 - voltage - 45 to 65 kv
 - amperage - 50 to 600 ma
 - spark rate - up to 300 sparks per minute
- c) The maximum design airflow through the stack is 100,000 acfm. The rated heat

input capacity of each burner is 32mm BTUs. Control efficiencies of the multicyclones and wet electrostatic precipitators are estimated to be 60% and 90% respectively.

- d) Collected material is mixed with bark and sold or burned in the thermal oil heater.
- 2. Diagrams of the sampling trains are enclosed in the attachments.
- 3. Descriptions of the sampling and analysis procedures are enclosed in the attachments.
- 4. Sketches indicating the flow of the exhaust gases through the equipment are enclosed in the attachments.
- 5.
 - a) Elevation views of each stack are shown in the attachments.
 - b) Cross-sectional views of each stack are provided in the attachments.
- 6. Estimated flue gas conditions are indicated on the attached stack drawings.

7. PROCESS AND CONTROL EQUIPMENT OPERATING DATA

a) THERMAL OIL HEATER OPERATING DATA:

- 1) Design heat input is 30mm BTU's per hour. Operating heat input will be determined by f factor. Heat output will be estimated based on an efficiency of 66%.
- 2) Type of fuel to be burned is green wood bark and fines.
- 3) Acfm of exhaust gas through the thermal oil heater will be determined.
- 4) Tons of fuel burned in the thermal oil heater on a dry basis during testing will be determined [REDACTED]

[REDACTED] by a calibrated conveyor scale and will be adjusted for moisture content as stated in the operating permit under "Conditions Applicable to B03, S03" Sec. 3. Brian Pett 6-14-95
Pg. 5 I-6

5) Plant production rate during testing will be determined from board weights and press charts.

6) Thermal oil heater operating parameters to be recorded during testing include the following:

- refractory temperature
- incoming oil temperature
- outgoing oil temperature

~~_____~~ 6-14-95

- thermal oil temperature setpoint

7) Thermal oil heater control equipment operating parameters to be recorded during testing include the following:

- baghouse pressure drop

b. DRYER OPERATING DATA

- 1) The moisture content of wet and dry wafers will be recorded during testing.
- 2) It is anticipated that the plant will process a minimum of 99% green wood and a maximum of 1% dry dead wood.
- 3) It is anticipated that the plant will process approximately 90% hardwood and 10% softwood as required by the air emission permit during testing.
- 4) The dryer inlet and outlet temperatures during testing will be recorded.
- 5) Design airflow rate is 80,000 acfm. Actual airflow rate will be determined during testing.

- 6) The fuels to be burned during testing are dry fines and natural gas as described in Table 1. Waste oil is not used as a fuel for this process. Liquid resin waste is not used as a fuel for this process.
- 7) The heat content of the dry fines fuel will be determined by analysis.
- 8) The dryer drums are 12' in diameter and 60' long.
- 9) Dryer production rate (lbs of dry material produced per hour) will be determined as follows:

$$\frac{\text{pounds of dryer production}}{\text{HR}} = \frac{\text{tons of finished product} \times 2000 \text{ lbs}}{1 - (\text{board trim \%} + \text{fines \%})}$$

The maximum permitted production rate is 7,674 tons of finished product per month. This is equivalent to 10.3 tons per hour for a 31 day month. The maximum permitted hourly production rate is 12.6 tons of finished product per hour. At an estimated 7% board trim and 8% fines, each dryer is required to produce 14,800 lbs. per hour of material to reach the maximum hourly permitted plant production rate.

The design rate of each dryer is estimated to be 29,105 lbs per hour of dry material.

The test rate is anticipated to be greater than or equal to 90% of the maximum hourly permit rate.

- 10) The level of the dry bins will be recorded before and after testing.
- 11) Additional dryer operating parameters to be recorded during testing include:

•Wet bin feed rate

- 12) Additional electrostatic precipitator operating parameters to be recorded during testing include:

•Voltage

•Amperage

•Quench chamber inlet temperature

•Quench chamber outlet temperature

c) PRESS OPERATING DATA

- 1) Nominal board thickness will be recorded
- 2) The number of sheet produced per hour will be determined by multiplying the number of press loads (as recorded on the press chart).
- 3) Pounds of resin used per hour will be recorded.
- 4) Pounds of wax used per hour will be recorded.
- 5) Type of resin used will be recorded.
- 6) Press temperature will be recorded.
- 7) There are two exhaust fans with a design airflow of 100,000 acfm. Actual acfm will be determined during sampling.

8.

9. The names and titles of testing personal are not available at this time. Testing will be preformed by Interpoll Laboratories, Inc.

10. Procedures for maintaining sample integrity and chain of custody are provided in the attachments. Interpoll Laboratories' QA-QC manual will be followed. Due to size of this document it is not included here but can be provided on request.
11. Calibration sheets will be provided prior to testing.
12. Filter lists will be provided prior to testing.

BOARD WEIGHTS IN TONS

TOMAHAWK WI

DRYERS ON GAS JULY 11, 1995

1	<u>Hours during testing (military)</u>	<u>5</u>
2	<u>Pressloads during testing</u>	<u>77</u>
3	<u>Mats per Pressload</u>	<u>8</u>
4	<u>Finished Product Boards per Pressload</u>	<u>32</u>
5	<u>Weight of Mats (untrimmed)*</u>	<u>117,040</u>
6	<u>Weight of Finished Product (trimmed)**</u>	<u>107,092</u>
7	<u>Trim Percentage</u>	<u>8.50%</u>
8	<u>Thickness Average **</u>	<u>0.430</u>
9	<u>Pounds per cubic foot (average)**</u>	<u>37.90</u>
10	<u>TFP per hour (Avg. from 7:00am to 6:00pm)</u>	<u>11.5</u>

* Taken from conveyor scale tapes using every ninth board for an average weight of the mats.

** "Unit Information Sheet" (attached)

Percentage of fines (taken from last stack test) is 8.0%

DRYER TESTING (GAS)

TOMAHAWK WI

Testing Date 07/11/95

Data Time: Start	8.00	Stop	9.00	Total Hrs.	1.00
Data Time: Start	9.20	Stop	10.20	Total Hrs.	1.00
Data Time: Start	10.40	Stop	11.40	Total Hrs.	1.00
Pollutants Testing For:				Total Data Hours:	3.00

A.) TOTAL DRYER(S) PRODUCTION RATE

1	<u>lbs. of Dryer Production per Hour *</u>	<u>25,400</u>
---	--	---------------

* (Pounds Finished Prod. - (% Trim, Fines) / Hours of Testing)

2	<u>Fines Percentage</u>	<u>8.00%</u>
3	<u>Trim Percentage</u>	<u>8.50%</u>
4	<u>Moisture Content of Incoming Wood Flakes (Avg. from 2 samples)</u>	<u>50.90%</u>
5	<u>Moisture Content of Wood Flakes After Drying</u>	<u>6.15%</u>

B.) FACE DRYER PRODUCTION RATE (55%)

1	<u>lbs of Dryer Production per Hour</u>	<u>13,970</u>
---	---	---------------

C.) CORE DRYER PRODUCTION RATE (45%)

1	<u>lbs of Dryer Production per Hour</u>	<u>11,430</u>
---	---	---------------

D.) FACE DRYER FUEL BURNING RATE

1	<u>Natural Gas Correction Factor</u>	<u>2.695</u>
2	<u>Meter Reading * 100</u>	<u>29600</u>
3	<u>Hours The Meter was Recorded during Testing 7am - 11am</u>	<u>4</u>
4	<u>Total BTU'S</u>	<u>79,772</u>
5	<u>Total mmBTU's</u>	<u>79.77</u>
6	<u>mmBTU's per hour Average</u>	<u>19.94</u>
7	<u>Moisture Content of Wood Flakes After Drying</u>	<u>6.80%</u>
8		
9	<u>Average Inlet Temperature (Fahrenheit)</u>	<u>870</u>
10	<u>Average Outlet Temperature (Fahrenheit)</u>	<u>240</u>

DRYER OPERATOR'S REPORT
LOUISIANA-PACIFIC CORP.
TOMAHAWK VM

Oper: LES
 Crew: C
 Date: 7-11-95
 Shift: 1st

TIME	FACE DRYER							CORE DRYER						
	OUTLET TEMP.	INLET TEMP.	FEED SPEED	FUEL COUNTS	MOIST. HOUR	W. COST. 1/2 HR.		OUTLET TEMP.	INLET TEMP.	FEED SPEED	FUEL COUNTS	MOIST. HOUR	W. COST. 1/2 HR.	CO RDNG.
07:00	226	801	49	8520	8.4	10.4		242	630	33	6447	4	4.0	314
08:00	238	874	47	0	8.8	5.8		236	655	35	0	4.8	9.5	81
09:00	244	913	47	0	5.8	5.6		232	620	35	0	5.9	4.3	
10:00	239	821	46	0	11.2	7.6		232	598	33	0	4.8	6.0	73
11:00	241	886	47	0	6.4	6.2		231	620	34	0	4.9	5.5	74
12:00	234	774	57	118	4.7	5.3		224	851	39	82	4.2	4.5	106
01:00	229	949	62	636	5.4	7.2		224	947	42	464	5.2	5.0	76
02:00	245	868	51	1193	6.0	5.8		246	906	30	857	5.3	3.9	70
03:00	236	743	55	1699	6.8	6.4		228	894	37	1220	6.2	6.9	71
04:00	234	754	55	2146	8.0	6.4		227	855	37	1558	5.2	5.3	76
05:00	235	761	62	2697	6.8	7.4		230	883	37	1912	5.6	5.9	77
06:00	239	869	64	3311	6.4	6.8		226	888	39	2300	5.8	5.2	75
AVG.	237	835	53	3311	6.7	6.7		232	779	36	2300	5.2	5.5	99

Face * ID * Fan Load	<u>2565</u>	Wet Bin Lvl.	<u>FULL</u>	Core * ID * Fan Load	<u>65</u>	Wet Bin Lvl.	<u>FULL</u>	LOG COUNT
Face E-Tube Fan Load	<u>75</u>	Dry Bin Lvl.	<u>50</u>	Core E-Tube Fan Load	<u>75</u>	Dry Bin Lvl.	<u>50</u>	<u>4739</u>

NATURAL GAS USAGE				Furnace Cleaned	
Include Time in Minutes:	FACE:	Include Time in Minutes:	CORE:	Face	Core
	<u>0700 - 1145</u>		<u>0700 - 1145</u>		

DOWNTIME			
Include Time in Minutes:	FACE:	Include Time in Minutes:	CORE:
	<u>-145</u>		<u>-1145</u>

dryopsht

READINGS EVERY TEN MINUTES

BIN LEVELS EVERY THIRTY MINUTES

FLAKE MOISTURE EVERY HOUR

Date: 7-11-95
 Employee Recording Data: J Teal

FUEL CALIBRATION 5.2

FUEL CALIBRATION 5.8

TIME	FACE					CORE					OUTLET FLAKE MOISTURE					
	OUTLET SET POINT	FRED RATE	DRYER INLET TEMP.	DRYER OUTLET TEMP.	FUEL COUNT	DRY BIN LEVEL	WET BIN LEVEL	OUTLET FLAKE MOISTURE	OUTLET SET POINT	FRED RATE		DRYER INLET TEMP.	DRYER OUTLET TEMP.			
7:15	226	51	926	226	X	60%	100%	8.4	226	40	755	237	X	60%	100%	4.0
7:30	236	45	879	229					236	35	842	239				
7:40	235	45	842	237					236	35	657	233				
7:50	238	45	843	239		70%	100%		235	35	629	237	X	70%	100%	
8:00	238	47	837	237					234	35	632	233				
8:10	238	47	858	238					232	35	651	231				
8:20	245	47	871	245	X	65%	100%	8.8	234	35	697	233	X	70%	100%	4.8
8:30	245	47	882	244				5.8	234	35	630	234				9.5
8:40	245	47	917	245					232	35	620	232				
8:50	244	47	885	243	X	60%	100%		232	35	622	231	X	55%	100%	
9:00	244	47	913	244				5.8	232	35	620	232				
9:10	244	47	885	246				5.8	232	37	645	233				5.9
9:20	241	47	898	241	X	70%	100%		232	37	648	234	X	60%	100%	
9:30	241	47	906	241				5.6	232	37	647	231				4.3
9:40	241	40	830	242					231	33	643	231				
9:50	240	40	789	246	X	75%	100%		230	33	593	229		80%	100%	
10:00	240	40	833	239					230	33	599	232				
10:10	240	45	843	241					230	33	608	231				
10:20	243	45	879	244	X	55%	100%	7.2	230	33	607	230	X	60%	100%	4.8
10:30	243	45	850	242				7.6	230	33	607	232				6.0
10:40	244	45	879	243					230	33	611	232				
10:50	244	45	892	244	X	55%	100		230	33	616	232	X	50%	100	
11:00	243	47	877	241				6.4	230	34	619	231				4.9
11:10	243	47	919	243					230	34	626	229				

slktsld

16.88

from 7 to 11 = AVG. 870 240

632 233


5.5


Date: 7-11-95
 Employee Recording Data: J. Teal


FUEL CALIBRATION 5.2

TIME	FACE						CORE					
	OUTLET SET POINT	FEED RATE	DRYER INLET TEMP.	DRYER OUTLET TEMP.	FUEL COUNT	DRY BIN LEVEL	WET BIN LEVEL	OUTLET FLAKE MOISTURE	OUTLET SET POINT	FEED RATE	DRYER INLET TEMP.	DRYER OUTLET TEMP.
11:20	243	47	885	243	x	55%	100	10.2	230	34	630	230
11:30	243	47	882	244					230	36	627	227
11:40	243	47	889	244	Done				230	36	625	231
11:50	231	49	709	254		55%	100%	4.2	228	39	721	236
12:00	234	57	779	235					228	39	853	223
12:10	233	59	927	232					225	40	873	227
12:20	233	59	884	235		55%	100%	5.3	223	40	861	225
12:30	233	62	947	231					223	43	903	218
12:50	233	62	915	234	545				222	44	989	223
1:00	231	62	954	229	645	55%	100%	5.4	221	42	934	224
1:10	228	62	955	228	741				221	42	907	222
1:20	228	62	969	227	823				221	43	890	220
1:30	228	62	966	226	923	60%	100%	7.2	221	43	944	219
1:40	227	61	965	228	1012				222	41	942	223
1:50	227	61	964	227	1102				222	41	927	221
2:00	238	51	877	245	1190	60%	100%	6.0	235	30	916	246
2:10	244	51	763	245	1268				234	37	880	233
2:20	236	55	769	234	1343			5.8	226	37	828	226
2:30	236	55	819	235	1435	60%	100%	6.8	226	37	860	226
2:40	236	55	901	235	1519				224	37	885	226
2:45	236	55	848	236	1556				224	37	895	223

sktaci







TOMAHAWK WI

PRESS REPORT

Shir:

SIZE	TIME FROM	TIME TO	Total Time	Down Time	Production Efficiency In Percent	PL ↓ PRODUCTION FOOTAGE
7/16	0700	0840	100	13	88	29 33452
7/16	0848	1758	610 550	16	97	151 180400
15/22	1858	1900	62	0	100	14 17920
			720	29		193 231771

[illegible]

	PRESSLOADS ALLOWED	LINE SPEED	LINE PRESSLOADS	HAMMERMILL DUMPED	ANCILLARY
SIZE	PER HOUR	SET	PER HOUR		Press Temp.
7/16	17.48	820	17.5	0720-1212	Blow Down
7/16	17.48	800	17.1	158-205	Former
1 5/32	15.73	656	14.0	305-314	FCOS
				325-347	Spin flush
				500-520	
					E-Tubes Shutdown
				FACE	
				FACE	
				CORE	
				CORE	

E - TUBE REPORT

LOUISIANA - PACIFIC CORP.
TOMAHAWK WI

Date: 7-11-95

Shift: DAY

Crew: C

By: Doug

SURFACE E - TUBE	7	8	9	10	11	12	1	2	3	4	5	6
Quench Ch. Inlet Temp.	205.1	212.6	221.5	217.3	228.6	215.9	207.8	214.2	213.5	213.5	214.0	213.2
Quench Ch. Outlet Tem.	124.6	129.2	133.0	130.4	131.1	135.2	139.6	135.3	136.9	137.9	136.5	140.4
Primary Current	80	80	90	80	70	50	50	60	60	50	50	60
Precipitator Voltage	52	52	52	54	54	50	50	50	52	50	50	50
Precipitator Current	340	350	340	360	290	180	210	240	210	160	190	200
Spark Rate	30.2	29.8	29.9	29.9	29.9	29.7	29.8	29.8	29.8	29.7	29.8	29.7
Strip Chart Recorder	X	X	X	X	X	X	X	X	X	X	X	X
CORE E - TUBE	7	8	9	10	11	12	1	2	3	4	5	6
Quench Ch. Inlet Temp.	217.8	214.9	212.1	212.3	212.3	212.5	205.7	220.3	209.1	213.4	210.9	212.7
Quench Ch. Outlet Tem.	128.5	133.9	133.8	133.5	131.8	135.7	137.2	130.2	134.1	132.8	132.9	134.4
Primary Current	80	70	70	80	80	50	40	60	40	50	60	50
Precipitator Voltage	50	52	50	54	54	54	52	54	54	52	54	52
Precipitator Current	300	250	270	330	320	170	150	240	150	150	250	170
Spark Rate	30.1	29.9	29.9	30.0	29.8	29.8	30.0	30.0	30.0	29.9	29.9	29.9
Strip Chart Recorder	X	X	X	X	X	X	X	X	X	X	X	X

etube

EMISSIONS TEST 95
E-TUBE READINGS
TOMAHAWK WI

Date: 7/11/95

Employee Recording Data: C. King
TAKEN EVERY THIRTY MINUTES

TIME	FACE				CORE			
	QUENCH CHAMBER INLET	QUENCH CHAMBER OUTLET	KV	MA	QUENCH CHAMBER INLET	QUENCH CHAMBER OUTLET	KV	MA
0730	217.1	139.4	50	300	206.1	132.2	48	220
0800	213	129.7	51	345	213.7	134.3	52	240
0830	218.3	120.7	50	360	213.3	133.2	52	250
910	222	133.2	50	350	212	135.4	52	255
935	220.6	131	52	440	214.2	134.9	52	290
1005	217.4	130.4	51	340	211.8	133.3	53	310
1035	220.6	132.0	50	340	213.1	131.7	54	335
1100	223.1	133.6	50	310	213.3	132.2	55	280
1135	222.6	133.3	49	320	213.2	135.1	48	230
1205	219.4	135.3	50	210	214.2	136.3	53	180
1236	211.7	136.7	48	200	207.1	136.7	52	190
1300	216.5	138.4	48	800	208.7	136.4	52	180
1330	209.0	138.5	49	210	205.4	136.7	54	180
1400	215.8	135.0	49	240	219.6	130.6	53	260
1430	213.6	136.9	50	180	211.6	133.3	52	310
1459	214.1	136.3	50	240	212.2	134.0	54	170
1532	213.3	136.1	50	230	212.7	134.0	50	195
1600	213.9	135.9	49	200	212.5	133.7	49	170
1630	214.3	136.9	49	240	210.1	133.5	49	210
1700	213.9	137.1	48	210	214.1	134.2	51	191

stktstdt

UNIT INFORMATION SHEET

PAPER FILTERS

OK 7 4-25

CHANGED NO

INITIALS GmG

DATE: 7-11-95

SHIFT: 1st

CREW: C

FOREMAN: Jeff Roberts

#	Time	# PCS	AVG HGT	LBS	LBS/ FT CU	AVG THICK	#	Time	# PCS	AVG HGT	LBS	LBS/ FT CU	AVG THICK
1	0715	90	38 7/8	4052	39.1	.432	46	1515	90	38 3/4	3916	37.9	.431
2	0727	1	39 1/4	4007	38.3	.436	47	1524	↑	39 1/8	4002	38.4	.435
3	0752	1	39	3968	38.2	.433	48	1536	1	38.625	3986	38.7	.429
4	0800	1	39.375	4009	38.2	.438	49	1547	1	38.75	3934	38.1	.431
5	0815	✓	39 1/8	3967	38.0	.435	50	1556	1	38.75	3872	37.5	.431
6	0823	1	39 1/8	3995	37.6	.443	51	1604	1	38.75	3876	37.5	.431
7	0834	1	39.5	3991	37.9	.439	52	1621	1	38 5/8	3853	37.4	.429
8	0844	1	38 7/8	3967	38.3	.432	53	1625	1	38 7/8	3856	37.2	.432
9	0854	1	39.0	3924	37.7	.433	54	1634	1	38.75	3855	37.3	.431
10	0905	1	38.625	3911	38.0	.429	55	1645	1	38 3/4	3866	37.4	.431
11	0917	1	38.25	3824	37.5	.425	56	1654	1	38.75	3869	37.4	.431
12	0935	1	38 3/8	3925	38.4	.426	57	1709	1	38.75	3845	37.2	.431
13	0951	1	38.75	3941	38.1	.431	58	1716	1	38.75	3839	37.2	.431
14	0959	1	38.625	3889	37.8	.429	59	1726	1	38.625	3830	37.2	.429
15	1008	1	38.5	3918	38.2	.428	60	1734	1	38.75	3852	37.3	.431
16	1020	1	38.58	3947	38.3	.429	61	1745	1	38.825	3906	37.7	.432
17	1029	1	38 3/4	3958	38.3	.431	62	1756	✓	38.75	3911	37.8	.431
18	1038	1	38 1/2	3924	38.2	.428	63	1807	90	38.825	3948	38.1	.432
19	1050	1	38.25	3919	38.4	.425	64	1821	82	39.125	3823	36.6	.427
20	1100	1	38.5	3932	38.3	.428	65	1832	1	39.125	3973	38.1	.427
21	1109	1	38 1/2	3918	38.5	.424	66	1843	1	39 1/4	4109	39.3	.479
22	1121	1	38.0	3927	38.8	.422	67	1857	1	39 5/8	4268	40.4	.483
23	1128	1	38.0	3920	38.7	.422	68						
24	1136	1	38 5/8	3903	37.9	.429	69						
25	1147	1	38.5	3879	37.8	.428	70						
26	1159	1	38.5	3830	37.3	.428	71						
27	1209	1	38.5	3831	37.3	.428	72						
28	1221	1	38.75	3881	37.6	.431	73						
29	1228	1	38 3/8	3890	38.0	.426	74						
30	1240	1	38 3/4	3901	37.8	.431	75						
31	1246	1	38.25	3896	38.2	.425	76	2:00	91	7 1/2	4-Grade		
32	1257	1	38.625	3908	37.9	.429	77						
33	1310	1	38.375	3864	37.8	.426	78	1644	110	3 1/2	6-Grade		
34	1323	1	38.375	3916	38.3	.426	79						
35	1330	1	38.50	3934	38.3	.428	80						
36	1337	1	38.375	3954	38.6	.426	81	0820	1	.433	45	39.1	
37	1347	1	38.625	3926	38.1	.429	82	0900	1	.440	47	40.2	
38	1359	1	38.625	3899	37.9	.429	83	0936	1	.432	46	40.4	
39	1408	1	38.50	3900	37.9	.427	84	1200	1	40.0	44	38.6	
40	1416	1	38.75	3859	37.3	.431	85	0935	1		193		
41	1430	1	39.0	3862	37.1	.433	86	0943	32	14 3/4	1355		
42	1440	1	38.75	3844	37.2	.431	87	1311	90	38.875	4091	34.5	.432
43	1449	1	38.75	3911	37.8	.431	88	1512	1	.431	44	38.6	
44	1459	1	38 3/4	3931	38.0	.431	89	1813	18	8	818		
45	1505	90	38 7/8	3880	37.4	.432	90	1816	61	26 7/8	2686		

Tack
sting

Avg. Den.

✓

OVER

Reg.
Bur.

Stac

Q.C.

Test

Boat

16

Sat.

Q.C.

16

Q.C.

16

BOARD WEIGHTS IN TONS

TOMAHAWK WI

1 <u>Hours during testing (military)</u>	<u>6</u>
2 <u>Pressloads during testing</u>	<u>102</u>
3 <u>Mats per Pressload</u>	<u>8</u>
4 <u>Finished Product Boards per Pressload</u>	<u>32</u>
5 <u>Weight of Mats (untrimmed)*</u>	<u>157.896</u>
6 <u>Weight of Finished Product (trimmed)**</u>	<u>144.040</u>
7 <u>Trim Percentage</u>	<u>8.78%</u>
8 <u>Thickness Average **</u>	<u>0.432</u>
9 <u>Pounds per cubic foot (average)**</u>	<u>38.31</u>
10 <u>Tons of Finished Product per Hour (6 / 1)</u>	<u>11.9</u>

* Taken from conveyor scale tapes using every ninth board for an average weight of the mats.

** "Unit Information Sheet" (attached)

Percentage of fines (taken from last stack test) is 8.0%

DRYER TESTING (WOOD)

TOMAHAWK WI

Testing Date 7/12/95

Test Time: Start	7.45	Stop	8.45	Total Hrs.	1.00
Test Time: Start	9.00	Stop	10.00	Total Hrs.	1.00
Test Time: Start	11.45	Stop	12.45	Total Hrs.	1.00
Pollutants Testing For: CO, NOX				Total Test Hours:	3.00

A.) TOTAL DRYER(S) PRODUCTION RATE

1	lbs. of Dryer Production per Hour *	28,600
---	-------------------------------------	--------

* (Pounds Finished Prod. - (% Trim, Fines) / Hours of Testing)

2	Fines Percentage	8.00%
3	Trim Percentage	8.78%
4	Moisture Content of Incoming Wood Flakes (Avg. from 2 samples)	50.90%
5	Moisture Content of Wood Flakes After Drying	6.50%

B.) FACE DRYER PRODUCTION RATE (55%)

1	lbs of Dryer Production per Hour	15,730
---	----------------------------------	--------

C.) CORE DRYER PRODUCTION RATE (45%)

1	lbs of Dryer Production per Hour	12,870
---	----------------------------------	--------

D.) FACE DRYER FUEL BURNING RATE

1	Fuel Calibration (lbs per Count)	5.2
2	Total Counts During Testing (From 7am - 2pm)	3727
3	Hours During Testing	7
4	Ttl. lbs of Fuel Burned During Testing (D1*D2)	19,380
5	lbs of Fuel Burned per Hour (D4/D3)	2,769
6	Tons of Fuel Burned per Hour (D5/2000)	1.38
7	Estimated BTU Content per Pound of Dry Fuel	8600
8	Estimated mmBTU Input per Hour (D5*D7)/1,000,000	23.81
9	Average Inlet Temperature (Fahrenheit)	817
10	Average Outlet Temperature (Fahrenheit)	237

E.) CORE DRYER FUEL BURNING RATE

1	<u>Fuel Calibration (lbs per Count)</u>	<u>5.8</u>
2	<u>Total Counts During Testing (From 7am - 2pm)</u>	<u>2533</u>
3	<u>Hours During Testing</u>	<u>7</u>
4	<u>Ttl. lbs of Fuel Burned During Testing (E1*E2)</u>	<u>14,691</u>
5	<u>lbs of Fuel Burned per Hour (E4/E3)</u>	<u>2,099</u>
6	<u>Tons of Fuel Burned per Hour (E5/2000)</u>	<u>1.05</u>
7	<u>Estimated BTU Content per Pound of Dry Fuel</u>	<u>8,600</u>
8	<u>Estimated mmBTU Input per Hour (E5*E7)/1,000,000</u>	<u>18.05</u>
9	<u>Average Inlet Temperature (Fahrenheit)</u>	<u>884</u>
10	<u>Average Outlet Temperature (Fahrenheit)</u>	<u>228</u>

F.) TOTAL DRYER(S) FUEL BURNING RATE

Estimated mmBTU Input per Hour (D8+E8) 41.86

DRYER OPERATOR'S REPORT
LOUISIANA-PACIFIC CORP.
TOMAHAWK W

Oper: LES
 Crew: C
 Date: 7-12-95
 Shift: 1st

TIME	FACE DRYER							CORE DRYER						
	OUTLET TEMP.	INLET TEMP.	FEED SPEED	FUEL COUNTS	MOIST. HOUR	MOIST. 1/2 HR.		OUTLET TEMP.	INLET TEMP.	FEED SPEED	FUEL COUNTS	MOIST. HOUR	MOIST. 1/2 HR.	CO RING.
07:00	238	754	57	0	6.8	6.6		226	896	35	0	6.6	6.2	71
08:00	239	779	57	538	6.9	6.9		227	847	35	363	5.6	5.0	74
09:00	236	815	56	1077	7.4	8.6		228	843	35	720	5.0	6.4	0 m.c.1
10:00	236	789	56	1571	7.1	6.2		228	879	35	1067	5.0	7.0	68
11:00	235	933	56	2132	6.4	6.5		228	889	35	1421	6.4	5.6	73
12:00	238	868	56	2722	7.8	6.8		228	928	35	1821	5.3	7.2	82
01:00	240	816	56	3204	5.9	6.6		230	914	35	2166	6.5	6.8	65
02:00	240	833	56	3728	7.5	6.2		234	884	36	2535	6.1	5.4	68
03:00	238	914	63	4292	6.2	7.0		229	968	41	2915	5.8	4.8	90
04:00	239	837	63	4864	6.6	6.6		230	947	41	336	5.2	5.4	81
05:00	240	789	58	5357	7.8	6.8		230	802	37	3642	5.4	5.4	73
06:00	240	762	58	5879	6.0	6.4		229	869	37	4000	5.5	6.2	70
AVG.	238	824	57.6	5879	6.9	6.8		229	889	36.4	4000	5.7	6.0	75

Face "ID" Fan Load	65	Wet Bin Lvl.	50	Core "ID" Fan Load	65	Wet Bin Lvl.	50	LOG COUNT
Face E-Tube Fan Load	75	Dry Bin Lvl.	60	Core E-Tube Fan Load	70	Dry Bin Lvl.	50	3492

NATURAL GAS USAGE		Furnace Cleaned	
Include Time In Minutes:	Include Time In Minutes:	Face	Core
FACE:	CORE:		

DOWNTIME	
Include Time In Minutes:	Include Time In Minutes:
FACE:	CORE:

dryopsht

Date: 7-12-93
 Employee Recording Data: David L. Lumsden

FUEL CALIBRATION 5.2

FACE													
TIME	OUTLET SET POINT	FEED RATE	DRYER INLET TEMP.	DRYER OUTLET TEMP.	FUEL COUNT	DRY BIN LEVEL	WET BIN LEVEL	OUTLET FLAKE MOISTURE					
8:30	240	63	936	242	4496	60%	90%	6.2					
8:30	240	63	884	242	4579			7.0					
8:40	240	63	861	243	4676								
8:30	240	59	826	241	5111	60%	50%	6.6					
8:40	240	55	839	241	5196								
8:50	240	55	819	242	5284								
9:00	240	58	791	240	5358	60%	50%	6.6					
9:10	240	52	801	241	5454			7.8					
9:20	240	52	781	240	5531								
9:30	240	52	797	241	5624	60%	50%	6.8					
9:40	240	58	814	240	5722								
9:50	240	52	785	241	5779								
9:00	240	52	760	240	5872	60%	90%	6.0					
9:10	240	52	726	240	5960								
9:20	240	52	806	240	6064								
9:30	240	52	802	240	6141	50%	95%	6.4					
9:40	240	52	832	242	6232								
9:50	240	58	818	240	6322								
10:00	240	52	761	239	6402	60%	90%	6.6					
10:10	240	52	865	241	6501								
10:20	240	52	850	240	6601								
10:30	240	52	864	240	6672	60%	75%	7.0					
10:40	240	52	849	241	6782								
10:50	240	58	825	240	6865								

sktsid

DRYER DATA SHEET

BIN LEVELS EVERY THIRTY MINUTES


ТОМАНАВК W


FLAKE MOISTURE EVERY HOUR


Date: 7/12/95
Employee Recording Data: Dan

[illegible]

Abstract








DATA STOP
TIME
12:45pm

DATA
STOP
TIME
7:45



TOMAHAWK WI

PRESS REPORT

Operator: LES

CREW: _____

Shift: 1st

PRODUCTION EFFICIENCY

[illegible]

DOWNTIME

[illegible]

PERMIT PRESSLOAD LIMITATIONS

SIZE	PRESSLOADS	LINE	LINE	HAMMERMILL	ANCILLARY
	ALLOWED	SPEED	PRESSLOADS	DUMPED	Press Temp.
	PER HOUR	SET	PER HOUR		
7/16	17.48	800	17.1	730-751	Blow Down 1030
				757-800	Former 1040
				820-836	FCOS 1045
				925-945	Spin flush
				1035-1046	112-132 342-400
				1109-1123	246-301 435 500
					542-610
				E-Tubes Shutdown	
				FACE	
				FACE	
				CORE	
				CORE	

E - TUBE REPORT

LOUISIANA - PACIFIC CORP.
TOMAHAWK WI

Date: 7-12-95

Shift: DAY

Crew: C

By: DOUGL

SURFACE E - TUBE	7	8	9	10	11	12	1	2	3	4	5	6
Quench Ch. Inlet Temp.	212.6	211.8	211.3	211.1	212.1	210.8	213.3	215.3	215.5	218.0	217.0	215.5
Quench Ch. Outlet Tem.	136.8	138.1	136.9	137.3	139.4	138.3	137.0	138.0	141.5	139.9	137.5	138.3
Primary Current	60	60	60	60	50	50	50	40	50	70	60	50
Precipitator Voltage	50	48	50	50	50	50	50	50	50	48	48	50
Precipitator Current	240	240	250	210	220	200	210	170	220	250	200	180
Spark Rate	30.0	29.9	29.9	29.9	30.0	29.8	29.9	32.8	29.8	29.7	30.0	29.8
Strip Chart Recorder	X	X	X	X	X	X	X	X	X	X	X	X
CORE E - TUBE	7	8	9	10	11	12	1	2	3	4	5	6
Quench Ch. Inlet Temp.	212.7	211.7	209.9	210.0	210.1	210.3	212.6	213.7	212.3	213.4	215.5	214.4
Quench Ch. Outlet Tem.	133.9	133.2	133.8	134.2	135.1	136.4	135.4	133.2	137.1	138.5	133.3	134.8
Primary Current	40	40	30	50	50	30	50	60	40	40	60	40
Precipitator Voltage	52	48	52	50	52	52	54	50	52	52	52	52
Precipitator Current	170	170	140	190	220	120	180	200	160	170	240	210
Spark Rate	30.0	30.1	29.9	29.9	30.0	29.9	30.0	29.9	29.9	30.0	30.0	30.0
Strip Chart Recorder	X	X	X	X	X	X	X	X	X	X	X	X

etube

EMISSIONS TEST 95
E-TUBE READINGS
TOMAHAWK WI

Date:

7-12-95

Employee Recording Data:

TAKEN EVERY THIRTY MINUTES

TIME	FACE				CORE			
	QUENCH CHAMBER INLET	QUENCH CHAMBER OUTLET	KV	MA	QUENCH CHAMBER INLET	QUENCH CHAMBER OUTLET	KV	MA
700	212.5	136.2	50	²³⁰ 230	210.4	134.1	48	180
730	212.1	136.8	44.6	179.7	211.0	134.9	44.8	120.7
800	212.2	138.5	41.68	188.6	211.0	133.5	46.5	166.1
900	212.0	138.1	46.10	175.2	210.0	133.5	43.97	123.5
1000	211.0	136.6	46.47	170.0	210.7	134.8	46.70	148.6
1100	211.9	139.3	41.55	166.7	210.1	135.4	47.99	146.1
1200	210.9	137.9	46.19	173.8	210.2	136.2	48.70	123.8
1300	213.3	136.9	46.59	172.0	212.3	136.0	45.6	141.5
1400	213.8	137.5	44.96	182.1 161.6	214.3	134.9	47.11	144.7
1500	213.8	140.5	46.63	174.6	210.2	137.4	48.66	103.1
1600	216.9	139.7	45.88	195.3	214.4	138.5	51.5	119.6
1700	216.7	138.4	45.15	192.7	215.5	132.7	49.73	181.3
1800	214.4	138.5	47.71	130.1	214.7	134.4	47.89	166.8
1830	215.4	138.7	45.61	130.1	214.5	134.8	46.96	130.1
1900	214.9	138.9	46.72	176.2	214.1	135.4	46.84	142.0
1930	215.8	140.4	45.97	159.2	213.1	136.1	50.20	123.4
2000	216.3	140.6	47.39	166.7	215.3	132.1	47.32	137.7
2030	216.8	139.7	46.74	183.2	214.4	137.8	47.88	180.6
2100	217.1	139.1	47.44	213.3	213.9	137.6	46.72	138.4
2130	216.4	137.9	48.68	200.5	213.4	132.6	49.91	131.1
2200	213.5	138.8	47.05	196.3	212.9	136.8	50.12	180.4
2230	213.8	140.0	47.03	229.3	211.5	137.0	47.22	183.3
2300	210.1	139.1	46.95	166.0	210.0	132.7	41.55	132.8
2330	207.8	140.0	46.04	166.8	210.8	132.5	49.0	144.6

stktstdt

UNIT INFORMATION SHEET

PAPER FILTERS
 OK? ☒ YES
 CHANGED ☒ NO
 INITIALS *DL*

DATE: 7-12-95
 SHIFT: 1st
 CREW: C.
 FOREMAN: Jeff Roberts

#	Time	# PCS	AVG HGT	LBS	LBS/ FT CU	AVG THICK	#	Time	# PCS	AVG HGT	LBS	LBS/ FT CU	AVG THICK
1	0715	90	39 1/8	4101	39.3	.435	46	1503	90	38 7/8	3935	38.0	.432
2	0724		39.0	4110	39.5	.433	47	1512	↑	38 5/8	3995	38.8	.429
3	0735	✓	39	4090	39.3	.433	48	1528		39	3996	38.4	.433
4	0745	✓	39.25	4074	38.9	.436	49	1531		38.875	4003	38.6	.432
5	0759		39 1/8	3984	38.2	.435	50	1545		38.75	4011	38.8	.431
6	0808		38 3/4	3966	38.4	.431	51	1557		38.875	4046	39.0	.432
7	0814		38.625	3949	38.3	.429	52	1605		38.75	4000	38.7	.431
8	0826		38.875	3935	38.0	.432	53	1611		39	3958	38.1	.433
9	0835		38 7/8	3946	38.1	.432	54	1627		38 3/4	3939	38.1	.431
10	0847		38.75	3927	38.0	.431	55	1639		38 3/4	3942	38.1	.431
11	0857		38 7/8	3962	38.2	.432	56	1645		38 3/4	3911	37.8	.431
12	0910		39.125	4031	38.6	.435	57	1654		38 5/8	3833	37.2	.429
13	0920		39	4068	39.1	.433	58	1709		38 3/4	3783	36.6	.431
14	0930		39 1/8	4079	39.1	.435	59	1711		38 3/4	3857	37.3	.431
15	0941		39 1/8	4062	38.9	.435	60	1724		38 3/4	3871	37.5	.431
16	0956		39 1/4	4053	38.7	.425	61	1730		38 3/4	3845	37.2	.431
17	0958		38 3/4	4031	39.1	.431	62	1739		38 3/4	3874	37.5	.431
18	1008		39.0	3979	38.3	.433	63	1750		38 3/4	3869	37.4	.431
19	1019		38.875	3946	38.1	.432	64	1801		38 5/8	3855	37.4	.429
20	1027		38.75	3903	37.8	.431	65	1811		38 5/8	3861	37.5	.429
21	1037		38.75	3821	37.0	.431	66	1819		39	3926	37.6	.433
22	1049		38.75	3878	37.5	.431	67	1830		38 3/4	3949	38.2	.431
23	1058		39.0	3962	38.1	.433	68	1840		39	4017	38.6	.433
24	1107		38.875	3956	38.2	.432	69	1849	↓	38 7/8	4041	39.0	.432
25	1118		39.0	4050	38.9	.433	70	1858	90	39	4026	38.7	.433
26	1127		38.875	4050	39.1	.432	71					AVG.	.432
27	1139		38 3/4	4035	39.0	.431	72						
28	1148		39 1/8	4052	38.5	.439	73					AVG.	38.39
29	1157		38 3/4	3952	38.2	.431	74						
30	1207		38 7/8	3956	38.2	.432	75					AVG. BOARD WGT	44.13
31	1219		38 3/4	3983	38.5	.431	76						
32	1229		38 3/4	3948	38.2	.431	77						
33	1238		38.75	3949	38.2	.431	78						
34	1250		38.5	3947	38.4	.428	79						
35	1313		38.5	3943	38.4	.428	80						
36	1307		38.625	3947	38.3	.429	81						
37	1318		39 1/8	3978	38.1	.435	82						
38	1328		38 5/8	3940	38.3	.429	83						
39	1338		38 7/8	4008	38.7	.432	84	755	1	434	45	39.1	
40	1348		38 3/4	3984	38.6	.431	85	830	1	427	43	38.1	
41	1358	↓	38 7/8	4003	38.6	.432	86	1100	1	427	44	38.9	
42	1411	90	39 1/8	4027	38.6	.435	87	1431	1	433	45	39.1	
43	1417	91	39 1/4	4082	39.0	.431	88	1503	1	431	44	38.6	
44	1428	90	38 5/8	4035	39.2	.429	89	1730	1	438	45	38.8	
45	1443	90	38 3/4	4019	38.9	.431	90						

QC
Test
Board

BOARD WEIGHTS IN TONS

TOMAHAWK WI

GEKA ON BARK JULY 12, 1995

1 <u>Hours during testing (military)</u>	<u>4.67</u>
2 <u>Pressloads during testing</u>	<u>83</u>
3 <u>Mats per Pressload</u>	<u>8</u>
4 <u>Finished Product Boards per Pressload</u>	<u>32</u>
5 <u>Weight of Mats (untrimmed)*</u>	<u>111987</u>
6 <u>Weight of Finished Product (trimmed)*</u>	<u>102740</u>
7 <u>Trim Percentage</u>	<u>8.26%</u>
8 <u>Thickness Average</u>	<u>0.432</u>
9 <u>Pounds per cubic foot (average)</u>	<u>38.62</u>
10 <u>TFP per hour</u>	<u>11.0</u>

*Using figures from July's density formulation sheet.

Percentage of fines (taken from last stack test) is 8.0%

THERMAL OIL HEATER (GEKA)


TOMAHAWK WI

Testing Date 7/12/95

Test Time: Start	19.55 Stop	20.55 Total Hrs.	1.00
Test Time: Start	21.10 Stop	22.10 Total Hrs.	1.00
Test Time: Start	22.25 Stop	23.25 Total Hrs.	1.00
Pollutants Testing For: CO, NOX		Total Test Hours:	3.00

GEKA FUEL BURNING RATE

<u>Tons of Fuel* (wet)</u>	<u>20.7</u>
<u>Pounds of Fuel (wet)</u>	<u>41,400</u>
<u>Hours During Data Collection (All of Second Shift)</u>	<u>12</u>
<u>Pounds of Fuel (wet) Burned per Hour</u>	<u>3,450</u>
<u>Moisture Content of Fuel* (Average)</u>	<u>40.35%</u>
<u>Pounds of Fuel (dry) Burned per Hour</u>	<u>2,058</u>
<u>Estimated BTU Content of Dry Fuel per Pound</u>	<u>9000</u>
<u>Estimated mmBTU Input per Hour</u>	<u>18.52</u>
<u>Tons of Dry Fuel Burned per Hour</u>	<u>1.03</u>



GEKA REPORT

LOUISIANA - PACIFIC
TOMAHAWK WI

Date: 7-12-95
Shift: Night
Crew: A
By: Kew T.

Readings

Bark Feed Hours Bin:	3 1/4 Hrs	Primary Air Flow	.4
Clark Bin Level:	80 %	ID Fan	.15

Primary Oil Flow

# 1 Suction	—	# 1 Dschrg	—
# 2 Suction	47	# 2 Dschrg	122

FLOW RATE: .25

GEKA SCALE CONVEYOR

Beginning of Shift	320.1
End of Shift	340.7
Total Used on Shift	20.7

Grate Speed

# 1	690	# 2	730
Feed Oil	491	Return Oil	470
Furnace Temp.	1232		
Steamchest OK ?	OK		
Spaceheat Pump # 1	829.1		
Spaceheat Pump # 2	—		
Suction	14	Dschrg	48

Baghouse

Cyclone

Time	Press.	Temp.	Pressure
7:00	3.9	390	5-25
11:30	4.9	396	5-5
5:45	4.6	390	4.75

Temp. Set Points & Readings

Geka	490
Space Heating	0
Steamchest	0

Emergency Diesel

Fuel Level	OK
Oil Level	OK
Start & Run, Day Shift	OK
Thermal Oil Level	.1
Geka Deashed ?	Yes
Ashpit Cleaned ?	No
Inlet Temp.	NA
Outlet Temp.	NA

Gas Usage, Actual Time From - To

0

Gas Meter Readings

	Geka	Core	Face
Start	74214	921334	751900
Stop	74214	921334	751905
Used	0	0	5

gekar

Date:

7-12-95

Employee Recording Data:

READINGS TAKEN HOURLY EXCEPT SCALE

[illegible]

THROWN ON
DUE TO E
TEST

DL-91

2nd shift

$$20.7 \text{ Transket bank} \times 59.65\% = 12.35 \text{ TDBF}$$
$$12.35 \div 12 \text{ hrs.} = 1.03 \text{ TDBF per hour.}$$

BOARD WEIGHTS IN TONS

TOMAHAWK WI

PRESS JULY 13, 1995

1 <u>Hours during testing (military)</u>	<u>7</u>
2 <u>Pressloads during testing</u>	<u>123</u>
3 <u>Mats per Pressload</u>	<u>8</u>
4 <u>Finished Product Boards per Pressload</u>	<u>32</u>
5 <u>Weight of Mats (untrimmed)*</u>	<u>190798</u>
6 <u>Weight of Finished Product (trimmed)**</u>	<u>174758</u>
7 <u>Trim Percentage</u>	<u>8.41%</u>
8 <u>Thickness Average **</u>	<u>0.431</u>
9 <u>Pounds per cubic foot (average)**</u>	<u>38.63</u>
10 <u>TFP per hour (Avg. from 7:00am to 3:00pm less 1 hr.)</u>	<u>10.9</u>

* Taken from conveyor scale tapes using every ninth board for an average weight of the mats.

** "Unit Information Sheet" (attached)

Percentage of fines (taken from last stack test) is 8.0%

PRESS TESTING

TOMAHAWK WI				Testing Date 07/13/95
Test Time: Start	9.15	Stop	10.15	Total Hrs. 1.00
Test Time: Start	11.05	Stop	12.05	Total Hrs. 1.00
Test Time: Start	13.35	Stop	14.35	Total Hrs. 1.00
Pollutants Testing For: CO, PM			Total Test Hours:	3.00

1	<u>lbs. of Dryer Production per Hour</u>	<u>29600</u>
2	<u>Weight of Finished Product (trimmed)</u>	<u>174758</u>

PLANT PRODUCTION RATE

1	<u>Data Hours (From 7am to 3pm less 1 hour downtime)</u>	<u>7</u>
2	<u>Pressloads</u>	<u>123</u>
3	<u>No. of Boards Produced (Pressloads x 8 boards per load).</u>	<u>984</u>
4	<u>Pounds of Finished Product</u>	<u>152,205</u>
5	<u>Pounds of Finished Product per Hour (No. 4 / No. 1)</u>	<u>21,744</u>
6	<u>Tons of Finished Product per Hour (No. 5 / 2000)</u>	<u>10.9</u>

RESIN & WAX USAGE

1	<u>Data Hours (From 7am to 2:30pm)</u>	<u>7.5</u>
2	<u>Pressloads from 7am to 2:30pm</u>	<u>115</u>
3	<u>Pounds of MDI resin used during testing</u>	<u>1605</u>
4	<u>Pounds of Liquid Phenolic Resin used during testing (100% Solids)</u>	<u>4070</u>
5	<u>Pounds of wax used during testing (100% Solids)</u>	<u>1456</u>


RESIN & WAX USAGE AS PERCENTAGE OF FINISHED PRODUCT

1	<u>Percentage of MDI resin used during testing</u>	<u>0.92%</u>
2	<u>Percentage of Liquid Phenolic Resin used during testing (100% Solids)</u>	<u>2.33%</u>
3	<u>Percentage of wax used during testing (100% Solids)</u>	<u>0.83%</u>


DATA
STOP TIME
11:35 PM

2 PL INK LOGGED

8/0



3515
30
11:35 PM



TOMAHAWK WI

PRESS REPORT

Operator: LES

Crew:

Shirley 25

PRODUCTION EFFICIENCY

[illegible]

DOWNTIME

			DOWN TIME
FROM	TO	TOTAL	REASON
7	1244	27	Blow Down Press
46	1255	11	TRIPPED Core Dry Blw Rake Chicks
+57(1250)	1311	21	" "
367	1403	56	Wipe Down Press
405	415	10	AIR PRESS
430	458	28	ROBIN PUMP Drive went OUT

1 Hour
TAKEN
ACCOUNT
DO

NOT
COUNTED

PERMIT PRESSLOAD LIMITATIONS

SIZE	PRESSLOADS	LINE	LINE	HAMMERMILL	ANCILLARY
	ALLOWED PER HOUR	SPEED SET	PRESSLOADS PER HOUR	DUMPED	Press Temp. Blow Down Former FCOS Spin flush
7/16	17.48	000	17.1	702-726 89-859 911-936	
				1120-1254	
				30-500	
					E-Tubes Shutdown
				FACE 320-416	
				FACE	
				CORE 1200-115	
				CORE 320-416	

THIS PAGE INTENTIONALLY LEFT BLANK

UNIT INFORMATION SHEET

PAPER FILTERS

OK? YES
 CHANGED NO
 INITIALS

DATE: 7-13-95

SHIFT: 1st

CREW: C

FOREMAN: Jeff Roberts

#	Time	#	PCS	AVG HGT	LBS	LBS/ FT CU	AVG THICK	#	Time	#	PCS	AVG HGT	LBS	LBS/ FT CU	AVG THICK
1	0708	90		38 1/8	4118	40.5	.424	46	1624	90		38 7/8	3976	38.5	.431
2	0715	↑		38 3/4	4125	39.9	.431	47	1728			38 3/4	4083	39.5	.431
3	0726			38 5/8	4100	39.8	.429	48	1757			38 8/8	3997	38.6	.432
4	0739			38 1/2	4070	39.6	.428	49	1800			39 1/2	4007	38.4	.435
5	0751			38 3/4	4058	39.3	.431	50	1758			38 3/4	3977	38.5	.431
6	0757			38 5/8	4072	39.5	.429	51	1809			38 3/4	3986	38.6	.431
7	0807			38 1/2	4038	39.3	.428	52	1819			38 7/8	3969	38.3	.432
8	0815			38 1/2	4001	39.0	.428	53	1829			38 3/4	3928	38.0	.431
9	0826			38 1/2	3966	38.6	.428	54	1837			38 5/8	3874	37.6	.429
10	0838			38 3/4	3953	38.3	.431	55	1854			38 3/4	3844	37.2	.431
11	0846			38 5/8	3941	38.3	.429	56	1856			38 3/4	3925	38.0	.431
12	0856			38 5/8	3964	38.5	.429	57							
13	0907			38 3/4	3934	38.1	.431	58							
14	0921			39	3961	38.1	.433	59							
15	0926			38 3/4	3948	38.2	.431	60							
16	0940			38 1/2	3955	38.5	.428	61							
17	0945			38 7/8	3966	38.7	.431	62							
18	0959			38 7/8	3980	38.5	.431	63	TTL 5011	TTL		223823 = AVG. WGT.		44.40	
19	1006			38 7/8	3970	38.4	.431	64							
20	1019			38 5/8	3946	38.3	.429	65					AVG.	38.67	
21	1030			38 5/8	3964	38.5	.429	66							
22	1036			38 3/4	4016	38.9	.431	67						AVG.	.431
23	1047			39	4056	39.0	.433	68							
24	1057			39	4130	39.7	.433	69							
25	1106			39 1/8	4090	39.2	.435	70							
26	1113	91		39	4094	39.4	.433	71							
27	1125			39	4025	38.7	.433	72							
28	1132			39	4010	38.6	.433	73							
29	1142			38 3/4	4020	38.9	.431	74							
30	1158			38 3/4	3996	38.7	.431	75							
31	1203			38 5/8	3966	38.5	.429	76							
32	1213			38 7/8	3942	38.0	.432	77							
33	1252			38 3/4	3910	37.8	.431	78							
34	1322			39	3904	37.5	.433	79							
35	1331			38 3/4	4002	38.7	.431	80							
36	1341			39	3988	38.3	.433	81							
37	1358			39	4042	38.9	.433	82							
38	1403			38 1/2	4031	39.3	.428	83	815	1		429	45	39.5	QC
39	1417			38 5/8	3996	38.8	.429	84	1100	1		435	45	39.1	Test Board
40	1421			38 5/8	3955	38.5	.428	85	1400	1		424	44	39.3	
41	1436			38 3/4	4005	38.8	.431	86	1716	128		440	6838		-E-Grade
42	1443			38 7/8	4091	39.0	.432	87	1800	1		422	49	39.3	QC
43	1457			39	4026	38.7	.433	88	1230	32			1535		4-Grade
44	1504			38 1/8	3988	38.5	.432	89							
45	1528	90		39	3994	38.4	.433	90							4-Grade - All ready Doen Weigh.

TOMAHAWK WI

Employee Recording Data: Daniel W. Wisniewski
TAKEN EVERY 30 MINUTES

[illegible]

stktstt

APPENDIX J

PROCEDURES

Method 3A—Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 Applicability. This method is applicable to the determination of oxygen (O_2) and carbon dioxide (CO_2) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 Principle. A sample is continuously extracted from the effluent stream: a portion of the sample stream is conveyed to an instrumental analyzer(s) for determination of O_2 and CO_2 concentration(s). Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

Same as Method 6C, Sections 2.1 and 2.2, except that the span of the monitoring system shall be selected such that the average O_2 or CO_2 concentration is not less than 20 percent of the span.

3. Definitions

3.1 Measurement System. The total equipment required for the determination of the O_2 or CO_2 concentration. The measurement system consists of the same major subsystems as defined in Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.2 Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, Response Time, and Calibration Curve. Same as Method 6C, Sections 3.2 through 3.8, and 3.10.

3.3 Interference Response. The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 Measurement System. Any measurement system for O_2 or CO_2 that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 Sample Probe. A leak-free probe, of sufficient length to traverse the sample points.

5.1.2 Sample Line. Tubing, to transport the sample gas from the probe to the moisture removal system. A heated sample line is not required for systems that measure the O_2 or CO_2 concentration on a dry basis, or transport dry gases.

5.1.3 Sample Transport Line, Calibration Value Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder. Same as Method 6C, Sections 5.1.3 through 5.1.9, and 5.1.11, except that the requirements to use stainless steel, Teflon, and nonreactive glass filters do not apply.

5.1.4 Gas Analyzer. An analyzer to determine continuously the O_2 or CO_2 concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer. The requirements for measuring and controlling the analyzer flow rate are not applicable if data are presented that demonstrate the analyzer is insensitive to flow variations over the range encountered during the test.

5.2 Calibration Gases. The calibration gases for CO_2 analyzers shall be CO_2 in N_2 or CO_2 in air. Alternatively, CO_2/SO_2 , O_2/SO_2 , or $O_2/CO_2/SO_2$ gas mixtures in N_2 may be used. Three calibration gases, as specified Section 5.3.1 through 5.3.3 of Method 6C, shall be used. For O_2 monitors that cannot analyze zero gas, a calibration gas concentration equivalent to less than 10 percent of the span may be used in place of zero gas.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Concentration Verification. Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 3 and change the acceptance criteria for agreement among Method 3 results to 5 percent (or 0.2 percent by volume, whichever is greater).

6.2 Interference Response. Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the type of gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 Measurement System Preparation, Analyzer Calibration Error, and Sampling System Bias Check. Follow Sections 6.2 through 6.4 of Method 6C.

7. Emission Test Procedure

7.1 Selection of Sampling Site and Sampling Points. Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 3.

7.2 Sample Collection. Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the sampling system bias check. Maintain constant rate sampling (i.e., ± 10 percent) during the entire run. The sampling time per run shall be the same as for tests conducted using Method 3 plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed to determine the average effluent concentration.

7.3 Zero and Calibration Drift Test. Follow Section 7.4 of Method 6C.

8. Quality Control Procedures

The following quality control procedures are recommended when the results of this method are used for an emission rate correction factor, or excess air determination. The tester should select one of the following options for validating measurement results:

8.1 If both O₂ and CO₂ are measured using Method 3A, the procedures described in Section 4.4 of Method 3 should be followed to validate the O₂ and CO₂ measurement results.

8.2 If only O₂ is measured using Method 3A, measurements of the sample stream CO₂ concentration should be obtained at the sample by-pass vent discharge using an Orsat or Fyrite analyzer, or equivalent. Duplicate samples should be obtained concurrent with at least one run. Average the duplicate Orsat or Fyrite analysis results for each run. Use the average CO₂ values for comparison with the O₂ measurements in accordance with the procedures described in Section 4.4 of Method 3.

8.3 If only CO₂ is measured using Method 3A, concurrent measurements of the sample stream O₂ concentration should be obtained using an Orsat or Fyrite analyzer as described in Section 8.2. For each run, differences greater than 0.5 percent between the Method 3A results and the average of the duplicate Fyrite analysis should be investigated.

9. Emission Calculation

For all CO₂ analyzers, and for O₂ analyzers that can be calibrated with zero gas, follow Section 8 of Method 6C, except express all concentrations as percent, rather than ppm.

For O₂ analyzers that use a low-level calibration gas in place of a zero gas, calculate the effluent gas concentration using Equation 3A-1.

$$C_{gas} = \frac{C_{ma} - C_{oa}}{C_m - C_o} - (\bar{C} - C_m) \div C_{ma} \text{ Eq. 3A - 1}$$

Where:

- C_{gas} = Effluent gas concentration, dry basis, percent.
- C_{ma} = Actual concentration of the upscale calibration gas, percent.
- C_{oa} = Actual concentration of the low-level calibration gas, percent.
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, percent.
- C_o = Average of initial and final system calibration bias check responses for the low-level gas, percent.
- $\bar{C}$ = Average gas concentration indicated by the gas analyzer, dry basis, percent.

10. Bibliography

Same as bibliography of Method 6C.

Particulate Loading and Emission Rates

The particulate emission rates were determined per EPA Methods 1 - 5, CFR Title 40, Part 60, Appendix A (revised July 1, 1992). In this procedure a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass-lined sampling probe equipped with a Type S pitot and a thermocouple. The probe is attached to a sampling module which houses the all-glass in line filter holder in a temperature controlled oven. The sampling module also houses the impinger case and a Drierite filled column. The sampling module is connected by means of an umbilical cord to the control module. The control module houses the dry test gas meter, the calibrated orifice, a leakless pump, two inclined manometers, and all controls required for operating the sampling train.

Particulate samples are collected as follows: The sample gas is drawn through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter where particulates are removed. The sample gas is then passed through an ice-cooled impinger train and a desiccant-packed column which absorbs remaining moisture. The sample gas then passes through a vacuum pump followed by a dry test gas meter. The gas meter integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gasmeter provides real time flow rate data.


A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each test point maintaining isokinetic sampling conditions. Nomographs are used for rapid determination of the sampling rate.

Particulate Loading and Emission Rates

When sampling is complete the filter is removed with tweezers and placed in a clean container. The nozzle, pitot tube and inlet side of the filter holder are quantitatively washed with acetone and the washings are stored in a second container. A brush is often used in the cleaning step to help dislodge deposits. The samples are returned to the laboratory where they are logged in and analyzed. The volume of the acetone rinse ("probe wash") is noted and the rinse is transferred to a tared 120 cc porcelain evaporating dish. The acetone is then evaporated off at 97 - 105 °F. At this elevated temperature condensation of atmospheric moisture is prevented. The acetone-free sample is then dried at 105 °C for 30 minutes, cooled in a desiccator over Drierite, and weighed to the nearest 0.01 mg. The filter sample is transferred to a 6 inch watch glass and dried at 105 °C for two hours. The filter and watch glass are then cooled in a desiccator and the filter weighed to the nearest 0.01 mg. All weighings are performed in a balance room where the relative humidity is maintained at less than 50%. Microscopic examination of the samples is performed if any unusual characteristics are observed. The weight of the acetone rinse blank is subtracted from the samples. The Drierite column is weighed on-site and the water absorbed by the Drierite is added to the condensate to give the total amount of absorbed water.

PARTICULATE SAMPLING TRAIN

MPINGER TRAIN OPTIONAL. MAY BE REPLACED
BY AN EQUIVALENT CONDENSER



**ENVIRONMENTAL PROTECTION
AGENCY**

40 CFR Part 51

(AD-FRL-3977-4)

**Preparation, Adoption, and Submittal
of State Implementation Plans, Method
for Measurement of Condensible
Particulate Emissions From Stationary
Sources**

AGENCY: Environmental Protection
Agency (EPA).

ACTION: Final rule.

SUMMARY: Method 202 for the measurement of condensible particulate matter (CPM) was proposed in the Federal Register on October 12, 1990, at (55 FR 41546). This action promulgates this method. On April 17, 1990 at (55 FR 14246) EPA promulgated two methods for measuring particulate matter (PM) with an aerodynamic diameter of 10 μ m or less (PM₁₀). Since CPM emissions form very fine particles in the PM₁₀ size range and are considered PM₁₀ emissions, the Agency is adding a method for measuring CPM emissions from stationary sources to appendix M in 40 CFR part 51. The purpose of this

rule is to provide the States with a method for measuring CPM.

EFFECTIVE DATE: December 17, 1991.

ADDRESSES: Background Information Document. The Background Information Document for the promulgated test methods may be obtained from Candace Sorrell or Peter Westlin, MD-19, U.S. EPA, Research Triangle Park, North Carolina 27711, telephone number (919) 541-1064. Please refer to "Summary of Comments and Responses for Method 202."

Docket. Docket No. A-90-03, containing materials relevant to this rulemaking, is available for public inspection and copying between 8:30 a.m. to 12 Noon and 1:30 to 3:30 p.m., Monday through Friday, at EPA's Air Docket Section, Waterside Mall, room M1500, 1st Floor, Gallery 1, 401 M Street SW., Washington, DC 20460. A reasonable fee may be charged for copying.

FOR FURTHER INFORMATION CONTACT: Candace Sorrell or Peter Westlin, Emission Measurement Branch (MD-19), Technical Support Division, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina 27711, telephone number (919) 541-1064.

SUPPLEMENTARY INFORMATION:

I. The Rulemaking

The EPA is proposing to add a method for measuring CPM emissions to appendix M in 40 CFR part 51 to provide a method that States can use in their State implementation plans.

II. Public Participation

The opportunity to hold a public hearing on November 2, 1990 at 10 a.m. was presented in the proposal notice, but no one desired to make an oral presentation. The public comment period was from October 12, 1990 to December 17, 1990.

III. Significant Comments and Changes to the Proposed Rulemaking

Six comment letters were received from the proposal rulemaking. A detailed discussion of these comments is contained in the background document entitled "Summary of Comments and Responses for Method 202" which is referred to in the ADDRESSES section of this preamble. The major comments raised in these letters and the Agency's responses follow.

One commenter suggests that EPA determine the chemical composition of the material collected in the sampling train to verify that it will form ambient condensibles.

The EPA believes that material will collect in the impingers only by

condensation or dissolution. Dissolved gases will evaporate during analysis and will not be measured unless the gases react to form a solid or liquid while they are in solution. The EPA has designed Method 202 to prevent the formation of reaction materials from dissolved gases. The EPA believes that any remaining material collected and measured by Method 202 represents the material that would condense in the ambient air. Additional analysis of chemical composition is not necessary.

Another comment raises the concern that the method may collect some portion of the sulfur dioxide (SO_2) as condensible.

The dissolution of SO_2 in water does not lead immediately to the formation of sulfuric acid (H_2SO_4), but tends to lower the solution pH, which further inhibits sulfate or H_2SO_4 formation. The method includes a purging procedure which effectively removes SO_2 before significant oxidation occurs. No additional revisions are necessary.

The commenter feels that if EPA is allowing Method 202 to be used in conjunction with Method 201 or 201A or another dry catch procedure to determine the total PM_{10} measurement, the combined methods should be tested for precision.

The imprecision associated with combining Method 202 with Method 201 or 201A or any other dry catch procedure is not additive because each train provides a separate measurement. Since the total precision associated with the combined methods cannot be larger than the least precise sampling method, a precision evaluation of a combined sampling system is unnecessary.

A commenter suggests that EPA add specific language to the applicability section of the method stating that Method 202 cannot be used on wet sources. He notes that Method 17 is excluded from use on wet sources, and Methods 201 and 201A are not recommended for wet sources.

The EPA agrees that Method 202 with an in-stack filter is not recommended for wet sources, and such a statement has been added to the applicability. However, a heated Method 5 filter could be used in Method 202 instead of the in-stack filter which would allow application to wet sources.

One commenter requests that EPA clearly state that Method 202 should not be used for assessing compliance with emission limits set on the basis of data derived from a different measurement approach.

The EPA agrees that a violation must be shown in the first instance, by means of measurements made with the

applicable test method. Once such a showing is made, however, section 113(e) of the Clean Air Act allows the Agency to rely on any credible evidence including evidence other than the applicable test method, to establish the duration of the period of noncompliance for the purposes of assessing a penalty.

A commenter believes that the sampling collection efficiency and method precision may be affected by the sampling conditions such as impinger temperature and sampling flow rate and the method should address this possibility.

The EPA agrees that the nature of material in the sample gas may affect collection efficiency. For example, a field demonstration of Method 202 on an oil-fired boiler resulted in about 75 percent impinger collection efficiency. This collection efficiency can be improved with the addition of a second filter place between the second and third impinger. This option has been included in the method with a discussion of applicability.

The commenter feels the 1-hour nitrogen (N_2) purge is too long. He believes the majority of the SO_2 is removed in the first few minutes. He suggests the method be revised to reduce the purge time in conjunction with maintaining the sample under conditions and analyzing it within hours.

The EPA does not agree with reducing the purge time. Laboratory tests have shown that a 1-hour purge time is necessary to ensure the adequate removal of SO_2 from the impinger solution.

Another commenter suggests the method should be revised to give for ammonium sulfate ($(\text{NH}_4)_2\text{SO}_4$) dihydrate and other condensible particulate matter formed in the stream due to ammonia (NH_3) in used to enhance the efficiency of the control device.

The EPA does not agree. The condensible particulate matter in the gas stream due to NH_3 injected into the atmosphere. The EPA believes that condensible particulate matter emitted from the source be counted as such even if it is a part of a pollution-control technique.

The commenter suggests that consider an alternative to MeC, consistent with the Montreal Protocol.

The EPA investigated the effectiveness of a chloroform-ether extraction during the method development phase. The chloroform-ether was not as effective as the chloroform-ether procedure in removing organic materials.

found to be acceptable for organic extraction. The method has been revised to allow a chloroform-ether extraction.

The commenter supports the exclusion of ammonium chloride as a condensable; however, he expresses concern about $(\text{NH}_4)_2\text{SO}_4$ forming in the impingers.

The N_2 purge removes SO_2 before significant oxidation occurs. If NH_3 is present in the flue gas, the $(\text{NH}_4)_2\text{SO}_4$ formed in the impingers would not be counted as a condensable, although the H_2SO_4 , which reacted with NH_3 , would be counted as a condensable. Method 202 corrects for the NH_3 by measuring the sulfate using an IC analysis and subtracting out the ammonium ion (NH_4^+) mass.

The commenter agrees that the NH_3 added during the titration should be subtracted from the final weight. However, he does not agree with adding back in the water removed by the acid-base reaction.

Because H_2SO_4 is hygroscopic, the H_2SO_4 mass found in the atmosphere would have the water attached to it. The method has been revised to allow the source to correct for only the NH_4^+ or for both NH_4^+ and water as an option—depending on the basis for the regulation.

A. Docket

The docket is an organized and complete file of all the information submitted to or otherwise considered by EPA in the development of this proposed rulemaking. The principle purposes of the docket are to: (1) Allow interested parties to identify and locate documents so that they can effectively participate in the rulemaking process, and (2) serve as the record in case of judicial review except for interagency review materials (Section 307(d)(7)(A)).

B. Office of Management and Budget Review

Under Executive Order 12291, EPA must judge whether a regulation is "major" and, therefore, subject to the requirement of a regulatory impact analysis. This rulemaking would not result in any of the adverse economic effects set forth in Section 1 of the Order as grounds for finding a "major rule." It will neither have an annual effect on the economy of \$100 million or more, nor will it result in a major increase in costs or prices. There will be no significant adverse effects on competition, employment, investment, productivity, innovation, or on the ability of U.S.-based enterprises to compete with foreign-based enterprises in domestic or export markets. This rulemaking was submitted to the Office of Management

and Budget (OMB) for review as required by Executive Order 12291.

C. Regulatory Flexibility Act Compliance

Pursuant to the provisions of 5 U.S.C. 605(b), I hereby certify that this attached rule, if promulgated, will not have any economic impact on small entities because no additional costs will be incurred.

This rule does not contain any information collection requirements subject to OMB review under the Paperwork Reduction Act of 1980, 44 U.S.C. 3501 *et seq.*

Dated: December 6, 1991.

F. Henry Habicht II,

Acting Administrator.

List of Subjects in 40 CFR Part 51

Administrative practice and procedure.

Air pollution control.

Carbon Monoxide.

Inter-governmental relations.

Lead.

Nitrogen dioxide.

Ozone.

Particulate matter.

Reporting and recordkeeping requirements.

Sulfur Oxides.

Volatile Organic Compounds.

The EPA amends title 40, chapter I, part 51 of the Code of Federal Regulations as follows:

PART 51—(AMENDED)

1. The authority citation for part 51 continues to read as follows:

Authority: Section 110 of the Clean Air Act as amended (42 U.S.C. 7410).

2. Appendix M, to part 51 Table of Contents is amended by adding an entry to read as follows:

Method 202—Determination of Condensible Particulate Emissions From Stationary Sources

3. By adding Method 202 to Appendix M to part 51 to read as follows:

Method 202—Determination of Condensible Particulate Emissions From Stationary Sources

1. Applicability and Principle

1.1 Applicability. 1.1.1 This method applies to the determination of condensible particulate matter (CPM) emissions from stationary sources. It is intended to represent condensible matter as material that condenses after passing through a filter and as measured by this method (Note: The filter catch can be analyzed according to the appropriate method).

1.1.2 This method may be used in conjunction with Method 201 or 201A if the

probes are glass-lined. Using Method 202 in conjunction with Method 201 or 201A, only the impinger train configuration and analysis is addressed by this method. The sample train operation and front end recovery and analysis shall be conducted according to Method 201 or 201A.

1.1.3 This method may also be modified to measure material that condenses at other temperatures by specifying the filter and probe temperature. A heated Method 5 out-of-stack filter may be used instead of the in-stack filter to determine condensable emissions at wet sources.

1.2 Principle. 1.2.1 The CPM is collected in the impinger portion of a Method 17 (appendix A, 40 CFR part 80) type sampling train. The impinger contents are immediately purged after the run with nitrogen (N_2) to remove dissolved sulfur dioxide (SO_2) gases from the impinger contents. The impinger solution is then extracted with methylene chloride (MeCl_2). The organic and aqueous fractions are then taken to dryness and the residues weighed. The total of both fractions represents the CPM.

1.2.2 The potential for low collection efficiency exist at oil-fired boilers. To improve the collection efficiency at these type of sources, an additional filter placed between the second and third impinger is recommended.

2. Precision and Interference

2.1 Precision. The precision based on method development tests at an oil-fired boiler and a catalytic cracker were 11.7 and 4.8 percent, respectively.

2.2 Interference. Ammonia. In sources that use ammonia injection as a control technique for hydrogen chloride (HCl), the ammonia interferes by reacting with HCl in the gas stream to form ammonium chloride (NH_4Cl) which would be measured as CPM. The sample may be analyzed for chloride and the equivalent amount of NH_4Cl can be subtracted from the CPM weight. However, if NH_4Cl is to be counted as CPM, the inorganic fraction should be taken to near dryness (less than 1 ml liquid) in the oven and then allowed to air dry at ambient temperature to prevent any NH_4Cl from vaporizing.

3. Apparatus

3.1 Sampling Train. Same as in Method 17, section 2.1, with the following exceptions noted below (see Figure 202-1). Note: Mention of trade names or specific products does not constitute endorsement by EPA.

3.1.1 The probe extension shall be glass-lined or Teflon.

3.1.2 Both the first and second impingers shall be of the Greenburg-Smith design with the standard tip.

3.1.3 All sampling train glassware shall be cleaned prior to the test with soap and tap water, water, and rinsed using tap water, water, acetone, and finally, MeCl_2 . It is important to completely remove all silicone grease from areas that will be exposed to the MeCl_2 during sample recovery.

3.2 Sample Recovery. Same as in Method 17, section 2.2, with the following additions:

3.2.1 N_2 Purge Line. Inert tubing and fittings capable of delivering 0 to 28 liters/min of N_2 gas to the impinger train from a

standard gas cylinder (see Figure 202-2). Standard 0.95 cm (3/8-inch) plastic tubing and compression fittings in conjunction with an adjustable pressure regulator and needle valve may be used.

3.2.2 Rotameter. Capable of measuring gas flow at 20 liters/min.

3.3 Analysis. The following equipment is necessary in addition to that listed in Method 17, section 2.3:

3.3.1 Separatory Funnel. Glass, 1-liter.

3.3.2 Weighing Tins. 350-ml.

3.3.3 Dry Equipment. Hot plate and oven with temperature control.

3.3.4 Pipets. 5-ml.

3.3.5 Ion Chromatograph. Same as in Method 5F, Section 2.1.8.

4. Reagents

Unless otherwise indicated, all reagents must conform to the specifications established by the Committee on Analytical Reagents of the American Chemical Society. Where such specifications are not available, use the best available grade.

4.1 Sampling. Same as in Method 17, section 3.1, with the addition of deionized distilled water to conform to the American Society for Testing and Materials Specification D 1193-74, Type II and the omission of section 3.1.4.

4.2 Sample Recovery. Same as in Method 17, section 3.2, with the following additions:

4.2.1 N_2 Gas. Zero N_2 gas at delivery pressures high enough to provide a flow of 20 liters/min for 1 hour through the sampling train.

4.2.2 Methylene Chloride. ACS grade. Blanks shall be run prior to use and only methylene chloride with low blank values (0.001 percent) shall be used.

4.2.3 Water. Same as in section 4.1.

4.3 Analysis. Same as in Method 17, section 3.3, with the following additions:

4.3.1 Methylene Chloride. Same as section 4.2.2.

4.3.2 Ammonium Hydroxide. Concentrated (14.8 M) NH_4OH .

4.3.3 Water. Same as in section 4.1.

4.3.4 Phenolphthalein. The pH indicator solution, 0.05 percent in 50 percent alcohol.

5. Procedure

5.1 Sampling. Same as in Method 17, section 4.1, with the following exceptions:

5.1.1 Place 100 ml of water in the first three impingers.

5.1.2 The use of silicone grease in train assembly is not recommended because it is very soluble in $MeCl_2$ which may result in sample contamination. Teflon tape or similar means may be used to provide leak-free connections between glassware.

5.2 Sample Recovery. Same as in Method 17, section 4.2 with the addition of a post-test N_2 purge and specific changes in handling of individual samples as described below.

5.2.1 Post-test N_2 Purge for Sources Emitting SO_2 . (Note: This step is recommended, but is optional. With little or no SO_2 is present in the gas stream, i.e., the pH of the impinger solution is greater than 4.5, purging has been found to be unnecessary.) As soon as possible after the post-test leak check, detach the probe and filter from the impinger train. Leave the ice in

the impinger box to prevent removal of moisture during the purge. If necessary, add more ice during the purge to maintain the gas temperature below 20 °C. With no flow of gas through the clean purge line and fittings, attach it to the input of the impinger train (see Figure 202-2). To avoid over- or under-pressurizing the impinger array, slowly commence the N_2 gas flow through the line while simultaneously opening the meter box pump valve(s). When using the gas cylinder pressure to push the purge gas through the sample train, adjust the flow rate to 20 liters/min through the rotameter. When pulling the purge gas through the sample train using the meter box vacuum pump, set the orifice pressure differential to $\Delta P_{1/2}$ and maintain an overflow rate through the rotameter of less than 2 liters/min. This will guarantee that the N_2 delivery system is operating at greater than ambient pressure and prevents the possibility of passing ambient air (rather than N_2) through the impingers. Continue the purge under these conditions for 1 hour, checking the rotameter and ΔH value(s) periodically. After 1 hour, simultaneously turn off the delivery and pumping systems.

5.2.2 Sample Handling.

5.2.2.1 Container Nos. 1, 2, and 3. If filter catch is to be determined, as detailed in Method 17, section 4.2.

5.2.2.2 Container No. 4 (Impinger Contents). Measure the liquid in the first three impingers to within 1 ml using a clean graduated cylinder or by weighing it to within 0.5 g using a balance. Record the volume or weight of liquid present to be used to calculate the moisture content of the effluent gas. Quantitatively transfer this liquid into a clean sample bottle (glass or plastic); rinse each impinger and the connecting glassware, including probe extension, twice with water, recover the rinse water, and add it to the same sample bottle. Mark the liquid level on the bottle.

5.2.2.3 Container No. 5 ($MeCl_2$ Rinse). Follow the water rinses of each impinger and the connecting glassware, including the probe extension with two rinses of $MeCl_2$; save the rinse products in a clean, glass sample jar. Mark the liquid level on the jar.

5.2.2.4 Container No. 6 (Water Blank). Once during each field test, place 500 ml of water in a separate sample container.

5.2.2.5 Container No. 7 ($MeCl_2$ Blank). Once during each field test, place in a separate glass sample jar a volume of $MeCl_2$ approximately equivalent to the volume used to conduct the $MeCl_2$ rinse of the impingers.

5.3 Analysis. Record the data required on a sheet such as the one shown in Figure 202-3. Handle each sample container as follows:

5.3.1 Container Nos. 1, 2, and 3. If filter catch is analyzed, as detailed in Method 17, section 4.3.

5.3.2 Container Nos. 4 and 5. Note the level of liquid in the containers and confirm on the analytical data sheet whether leakage occurred during transport. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Measure the liquid in Container No. 4 either volumetrically to ± 1 ml or gravimetrically to ± 0.5 g. Remove a 5-ml aliquot and set aside for later ion

chromatographic (IC) analysis of sulfates. (Note: Do not use this aliquot to determine chlorides since the HCl will be evaporated during the first drying step; Section 8.2 details a procedure for this analysis.)

5.3.2.1 Extraction. Separate the organic fraction of the sample by adding the contents of Container No. 4 ($MeCl_2$) to the contents of Container No. 4 in a 1000-ml separatory funnel. After mixing, allow the aqueous and organic phases to fully separate, and drain off most of the organic/ $MeCl_2$ phase. Then add 75 ml of $MeCl_2$ to the funnel, mix well, and drain off the lower organic phase. Repeat with another 75 ml of $MeCl_2$. This extraction should yield about 250 ml of organic extract. Each time, leave a small amount of the organic/ $MeCl_2$ phase in the separatory funnel, ensuring that no water is collected in the organic phase. Place the organic extract in a tared 350-ml weighing tin.

5.3.2.2 Organic Fraction Weight Determination (Organic Phase from Container Nos. 4 and 5). Evaporate the organic extract at room temperature and pressure in a laboratory hood. Following evaporation, desiccate the organic fraction for 24 hours in a desiccator containing anhydrous calcium sulfate. Weigh to a constant weight and report the results to the nearest 0.1 mg.

5.3.2.3 Inorganic Fraction Weight Determination. (Note: If NH_4Cl is to be counted as CPM, the inorganic fraction should be taken to near dryness (less than 1 ml liquid) in the oven and then allow to air dry at ambient temperature. If multiple acid emissions are suspected, the ammonium titration procedure in section 8.1 may be preferred.) Using a hot plate, or equivalent, evaporate the aqueous phase to approximately 50 ml; then, evaporate to dryness in a 105 °C oven. Redissolve the residue in 100 ml of water. Add five drops of phenolphthalein to this solution; then, add concentrated (14.8 M) NH_4OH until the sample turns pink. Any excess NH_4OH will be evaporated during the drying step. Evaporate the sample to dryness in a 105 °C oven, desiccate the sample for 24 hours, weigh to a constant weight, and record the results to the nearest 0.1 mg. (Note: The addition of NH_4OH is recommended, but is optional when little or no SO_2 is present in the gas stream, i.e., when the pH of the impinger solution is greater than 4.5, the addition of NH_4OH is not necessary.)

5.3.2.4 Analysis of Sulfate by IC to Determine Ammonium Ion (NH_4^+) Retain the Sample. (Note: If NH_4OH is not added omit this step.) Determine the amount of sulfate in the aliquot taken from Container No. 4 earlier as described in Method 5F (appendix A, 40 CFR part 60). Based on SO_4^{2-} analysis of the aliquot, calculate a correction factor to subtract the NH_4^+ retained in the sample and to add the combined water removed by the acid-base reaction (see section 7.2).

5.3.3 Analysis of Water and $MeCl_2$ (Container Nos. 6 and 7). Analyze sample blanks as described above in sections 5.3.2.3 and 5.3.2.2, respectively.

5.3.4 Analysis of Acetone Blank (Container No. 8). Same as in Method 17, section 4.3.

6. Calibration

Same as in Method 17, section 5, except for the following:

6.1 IC Calibration. Same as Method 5F, section 5.

6.2 Audit Procedure. Concurrently, analyze the audit sample and a set of compliance samples in the same manner to evaluate the technique of the analyst and the standards preparation. The same analyst, analytical reagents, and analytical system shall be used both for compliance samples and the EPA audit sample. If this condition is met, auditing of subsequent compliance analyses for the same enforcement agency within 30 days is not required. An audit sample set may not be used to validate different sets of compliance samples under the jurisdiction of different enforcement agencies, unless prior arrangements are made with both enforcement agencies.

6.3 Audit Samples. Audit Sample Availability. Audit samples will be supplied only to enforcement agencies for compliance tests. The availability of audit samples may be obtained by writing:

Source Test Audit Coordinator (MD-778), Quality Assurance Division, Atmospheric Research and Exposure Assessment Laboratory, U.S. Environmental Protection Agency, Research Triangle Park, NC 27711

or by calling the Source Test Audit Coordinator (STAC) at (919) 541-7834. The request for the audit sample must be made at least 30 days prior to the scheduled compliance sample analysis.

6.4 Audit Results. Calculate the audit sample concentration according to the calculation procedure described in the audit instructions included with the audit sample. Fill in the audit sample concentration and the analyst's name on the audit response form included with the audit instructions. Send one copy to the EPA Regional Office or the appropriate enforcement agency and a second copy to the STAC. The EPA Regional Office or the appropriate enforcement agency will report the results of the audit to the laboratory being audited. Include this response with the results of the compliance samples in relevant reports to the EPA Regional Office or the appropriate enforcement agency.

7. Calculations

Same as in Method 17, section 8, with the following additions:

7.1 Nomenclature. Same as in Method 17, section 8.1 with the following additions.

C_{gas} = Concentration of the CPM in the stack gas, dry basis, corrected to standard conditions, g/dscm (g/dscf).

C_{gas} = Concentration of SO_4^{2-} in the sample, mg/ml.

m_b = Sum of the mass of the water and MeCl_2 blanks, mg.

m_c = Mass of the NH_4^+ added to sample to form ammonium sulfate, mg.

m_i = Mass of inorganic CPM matter, mg.

m_o = Mass of organic CPM, mg.

m_s = Mass of dried sample from inorganic fraction, mg.

V_a = Volume of aliquot taken for IC analysis, ml.

V_{ic} = Volume of impinger contents sample, ml.

7.2 Correction for NH_4^+ and H_2O .

Calculate the correction factor to subtract the NH_4^+ retained in the sample based on the IC SO_4^{2-} and if desired, add the combined water removed by the acid-base reaction.

$$m_c = K C_{\text{gas}} V_a \quad \text{Eq. 202-1}$$

where:

$K = 0.0205$, when correcting for NH_4^+ and H_2O .

$= 0.1840$, when only correcting for NH_4^+ .

7.3 Mass of Inorganic CPM.

$$m_i = m_s \frac{V_a}{V_{\text{ic}} - V_a} - m_c \quad \text{Eq. 202-2}$$

7.4

Concentration of CPM.

$$C_{\text{PM}} = \frac{m_i + m_o - m_c}{V m_{\text{gas}}} \quad \text{Eq. 202-3}$$

8. Alternative Procedures

8.1 Determination of NH_4^+ Retained in Sample by Titration.

8.1.1 An alternative procedure to determine the amount of NH_4^+ added to the inorganic fraction by titration may be used. After dissolving the inorganic residue in 100 ml of water, titrate the solution with 0.1 N NH_4OH to a pH of 7.0, as indicated by a pH meter. The 0.1 N NH_4OH is made as follows: Add 7 ml of concentrated (14.8 M) NH_4OH to 1 liter of water. Standardize against standardized 0.1 N H_2SO_4 and calculate the exact normality using a procedure parallel to that described in section 5.5 of Method 8 (appendix A, 40 CFR part 60). Alternatively, purchase 0.1 N NH_4OH that has been standardized against a National Institute of Standards and Technology reference material.

8.1.2 Calculate the concentration of SO_4^{2-} in the sample using the following equation.

$$C_{\text{SO}_4} = \frac{48.03 V_t N}{100} \quad \text{Eq. 202-4}$$

where

N = Normality of the NH_4OH , mg/ml.

V_t = Volume of NH_4OH titrant, ml.

48.03 = mg/meq.

100 = Volume of solution, ml.

8.3.1 Calculate the CPM as described in section 7.

8.2 Analysis of Chlorides by IC. At the conclusion of the final weighing as described in section 5.3.2.1, redissolve the inorganic fraction in 100 ml of water. Analyze an aliquot of the redissolved sample for chlorides by IC using techniques similar to those described in Method 5F for sulfates. Previous drying of the sample should have

removed all HCl. Therefore, the remaining chlorides measured by IC can be assumed to be NH_4Cl , and this weight can be subtracted from the weight determined for CPM.

8.3 Air Purge to Remove SO_2 from Impinger Contents. As an alternative to the post-test N_2 purge described in section 5.3.1, the tester may opt to conduct the post-test purge with air at 20 liter/min. Note: The use of an air purge is not as effective as a N_2 purge.

8.4 Chloroform-ether Extraction. As an alternative to the methylene chloride extraction described in section 5.3.2.1, the tester may opt to conduct a chloroform-ether extraction. Note: The Chloroform-ether was not as effective as the MeCl_2 in removing the organics, but it was found to be an acceptable organic extractant. Chloroform and diethylether of ACS grade, with low blank values (0.001 percent), shall be used. Analysis of the chloroform and diethylether blanks shall be conducted according to Section 5.3.3 for MeCl_2 .

8.4.1 Add the contents of Container No. 4 to a 1000-ml separatory funnel. Then add 75 ml of chloroform to the funnel, mix well, and drain off the lower organic phase. Repeat two more times with 75 ml of chloroform. Then perform three extractions with 75 ml of diethylether. This extraction should yield approximately 450 ml of organic extraction. Each time, leave a small amount of the organic/ MeCl_2 phase in the separatory funnel ensuring that no water is collected in the organic phase.

8.4.2 Add the contents of Container No. 5 to the organic extraction. Place approximately 300 ml of the organic extract in a tared 350-ml weighing tin while storing the remaining organic extract in a sample container. As the organic extract evaporates, add the remaining extract to the weighing tin.

8.4.3 Determine the weight of the organic phase as described in Section 5.3.2.2.

8.5 Improving Collection Efficiency. If low impinger collection efficiency is suspected, the following procedure may be used.

8.5.1 Place an out-of-stock filter as described in Method 8 between the second and third impingers.

8.5.2 Recover and analyze the filter according to Method 17, Section 4.2. Include the filter holder as part of the connecting glassware and handle as described in sections 5.2.2.2 and 5.2.2.3.

8.5.3 Calculate the Concentration of CPM as follows:

$$C_{\text{PM}} = \frac{m_o + m_i - m_f - m_c}{V m_{\text{gas}}} \quad \text{Eq. 202-5}$$

where:

m_f = amount of CPM collected on out-of-stock filter, mg.

8.6 Wet Source Testing. When testing at a wet source, use a heated out-of-stock filter as described in Method 5.

9. Bibliography

1. DeWees, W.D., S.C. Steinsberger, G.M. Plummer, L.T. Lay, C.D. McAllister, and R.T.

Shigenara. "Laboratory and Field Evaluation of the EPA Method 5 Impinger Catch for Measuring Condensible Matter from Stationary Sources." Paper presented at the 1989 EPA/AWMA International Symposium on Measurement of Toxic and Related Air Pollutants. Raleigh, North Carolina. May 1-5, 1989.

2. DeWees, W.D. and K.C. Steinsberger. "Method Development and Evaluation of Draft Protocol for Measurement of Condensible Particulate Emissions." Draft Report. November 17, 1989.

3. Texas Air Control Board, Laboratory Division. "Determination of Particulate in Stack Gases Containing Sulfuric Acid and/or Sulfur Dioxide." *Laboratory Methods for Determination of Air Pollutants*. Modified December 3, 1978.

4. Nothstein, Greg. Masters Thesis. University of Washington. Department of Environmental Health. Seattle, Washington.

5. "Particulate Source Test Procedures Adopted by Puget Sound Air Pollution Control Agency Board of Directors." Puget Sound Air Pollution Control Agency.

Engineering Division. Seattle, Washington. August 11, 1983.

6. Commonwealth of Pennsylvania. Department of Environmental Resources. Chapter 139, Sampling and Testing, Rules and Regulations, Part I. Department of Environmental Resources, Subpart C, Protection of Natural Resources, Article Air Resources). January 8, 1960.

7. Wisconsin Department of Natural Resources. *Air Management Operations Handbook, Revision 2*. January 11, 1988.

BILLING CODE 6550-60-4




Figure 202-1. Schematic of condensible particulate sampling train.




Figure 202-2. Schematic of post-test nitrogen purge system.

Federal Register / Vol. 58.

Moisture Determination

Volume or weight of liquid in impinger: _____

_____ ml or g

Weight of moisture in silica gel: _____ g

Sample Preparation (Container No. 4)

Amount of liquid lost during transport: _____

_____ ml

Final volume: _____ ml

pH of sample prior to analysis: _____

Addition of NH_4OH required: _____

Sample extracted 2X with 75 ml MeCl_2 : _____

For Titration of Sulfate

Normality of NH_4OH : _____ N

Volume of sample titrated: _____ ml

Volume of titrant: _____ ml

Sample Analysis

Container number	Weight of condensable particulate, mg		
	Final weight	Tare weight	Weight gain
4 (Inorganic)			
4 & 5 (Organic)			

Total: _____

Less Blank: _____

Weight of Condensable Particulate: _____

Figure 202-3. Analytical data sheet.

[FR Doc. 91-29957 Filed 12-18-91; 8:45 am]

BILLING CODE 6860-60-M

Method 7E—Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 **Applicability.** This method is applicable to the determination of nitrogen oxides (NO_x) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 **Principle.** A gas sample is continuously extracted from a stack, and a portion of the sample is conveyed to an instrumental chemiluminescent analyzer for determination of NO_x concentration. Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

Same as Method 6C, Sections 2.1 and 2.2.

3. Definitions

3.1 **Measurement System.** The total equipment required for the determination of NO_x concentration. The measurement system consists of the following major subsystems:

3.1.1 **Sample Interface, Gas Analyzer, and Data Recorder.** Same as Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.1.2 **NO_2 to NO Converter.** A device that converts the nitrogen dioxide (NO_2) in the sample gas to nitrogen oxide (NO).

3.2 **Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, and Response Time.** Same as Method 6C, Sections 3.2 through 3.8.

3.3 **Interference Response.** The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 **Measurement System.** Any measurement system for NO_x that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 Sample Probe, Sample Line, Calibration Valve Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder. Same as Method 6C, Sections 5.1.1 through 5.1.9, and 5.1.11.

5.1.2 NO₂ to NO Converter. That portion of the system that converts the nitrogen dioxide (NO₂) in the sample gas to nitrogen oxide (NO). An NO₂ to NO converter is not necessary if data are presented to demonstrate that the NO₂ portion of the exhaust gas is less than 5 percent of the total NO_x concentration.

5.1.3 NO_x Analyzer. An analyzer based on the principles of chemiluminescence, to determine continuously the NO_x concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer.

5.2 NO_x Calibration Gases. The calibration gases for the NO_x analyzer shall be NO in N₂. Three calibration gases, as specified in Sections 5.3.1 through 5.3.3. of Method 6C, shall be used. Ambient air may be used for the zero gas.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Gas Concentration Verification. Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 7, and change all 5 percent performance values to 10 percent (or 10 PPM, whichever is greater).

6.2 Interference Response. Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 Measurement System Preparation, Analyzer Calibration Error, and Sample System Bias Check. Follow Sections 6.2 through 6.4 of Method 6C.

6.4 NO₂ to NO Conversion Efficiency. Unless data are presented to demonstrate that the NO₂ concentration within the sample stream is not greater than 5 percent of the NO_x concentration, conduct an NO₂ to NO conversion efficiency test in accordance with Section 5.6 of Method 20.

7. Emission Test Procedure

7.1 Selection of Sampling Site and Sampling Points. Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 7.

7.2 Sample Collection. Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the system calibration drift test. Maintain constant rate sampling (i.e., ± 10 percent) during the entire run. The sampling time per run shall be the same as the total time required to perform a run using Method 7, plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed, to determine the average effluent concentration.

7.3 Zero and Calibration Drift Test. Follow Section 7.4 of Method 6C.

8. Emission Calculation

Follow Section 8 of Method 6C.

9. Bibliography

Same as bibliography of Method 6C.

Method 10—Determination of Carbon Monoxide Emissions From Stationary Sources

1. Principle and Applicability

1.1 Principle. An integrated or continuous gas sample is extracted from a sampling point and analyzed for carbon monoxide (CO) content using a Luft-type nondispersive infrared analyzer (NDIR) or equivalent.

1.2 Applicability. This method is applicable for the determination of carbon monoxide emissions from stationary sources only when specified by the test procedures for determining compliance with new source performance standards. The test procedure will indicate whether a continuous or an integrated sample is to be used.

2. Range and Sensitivity

2.1 Range. 0 to 1,000 PPM.

2.2 Sensitivity. Minimum detectable concentration is 20 PPM for a 0 to 1,000 PPM span.

3. Interferences

Any substance having a strong absorption of infrared energy will interfere to some extent. For example, discrimination ratios for water (H₂O) and carbon dioxide (CO₂) are 3.5 percent H₂O per 7 PPM CO and 10 percent CO₂ per 10 PPM CO, respectively, for devices measuring in the 1,500 to 3,000 PPM range. For devices measuring in the 0 to 100 PPM range, interference ratios can be as high as 3.5 percent H₂O per 25 PPM CO and 10 percent CO₂ per 50 PPM CO. The use of silica gel and ascarite traps will alleviate the major interference problems. The measured gas volume must be corrected if these traps are used.

4. Precision and Accuracy

4.1 Precision. The precision of most NDIR analyzers is approximately ± 2 percent of span.

4.2 Accuracy. The accuracy of most NDIR analyzers is approximately ± 5 percent of span after calibration.

5. Apparatus

5.1 Continuous Sample (Figure 10-1).

5.1.1 Probe. Stainless steel or sheathed Pyrex\1\ glass, equipped with a filter to remove particulate matter.

5.1.2 Air-Cooled Condenser or Equivalent. To remove any excess moisture.

5.2 Integrated Sample (Figure 10-2).

5.2.1 **Probe.** Stainless steel or sheathed Pyrex glass, equipped with a filter to remove particulate matter.

5.2.2 **Air-Cooled Condenser or Equivalent.** To remove any excess moisture.

5.2.3 **Valve.** Needle valve, or equivalent, to adjust flow rate.

5.2.4 **Pump.** Leak-free diaphragm type, or equivalent, to transport gas.

5.2.5 **Rate Meter.** Rotameter, or equivalent, to measure a flow range from 0 to 1.0 liter per min (0.035 cfm).

5.2.6 **Flexible Bag.** Tedlar, or equivalent, with a capacity of 60 to 90 liters (2 to 3 ft³). Leak-test the bag in the laboratory before using by evacuating bag with a pump followed by a dry gas meter. When evacuation is complete, there should be no flow through the meter.

5.2.7 **Pitot Tube.** Type S, or equivalent, attached to the probe so that the sampling rate can be regulated proportional to the stack gas velocity when velocity is varying with the time or a sample traverse is conducted.

5.3 Analysis (Figure 10-3).

5.3.1 **Carbon Monoxide Analyzer.** Nondispersive infrared spectrometer, or equivalent. This instrument should be demonstrated, preferably by the manufacturer, to meet or exceed manufacturer's specifications and those described in this method.

5.3.2 **Drying Tube.** To contain approximately 200 g of silica gel.

5.3.3 **Calibration Gas.** Refer to section 6.1.

5.3.4 **Filter.** As recommended by NDIR manufacturer.

{_See_CFR_paper_publication_for_illustration_18A

5.3.5 **CO₂ Removal Tube.** To contain approximately 500 g of ascarite.

5.3.6 **Ice Water Bath.** For ascarite and silica gel tubes.

5.3.7 **Valve.** Needle valve, or equivalent, to adjust flow rate

5.3.8 **Rate Meter.** Rotameter or equivalent to measure gas flow rate of 0 to 1.0 liter per min (0.035 cfm) through NDIR.

5.3.9 **Recorder (optional).** To provide permanent record of NDIR readings.

6. Reagents

6.1 **Calibration Gases.** Known concentration of CO in nitrogen (N₂) for instrument span, prepurified grade of N₂ for zero, and two additional concentrations corresponding approximately to 60 percent and 30 percent span. The span concentration shall not exceed 1.5 times the applicable source performance standard. The calibration gases shall be certified by the manufacturer to be within ± 2 percent of the specified concentration.

|_See_CFR_paper_publication_for_illustration_19A

6.2 **Silica Gel.** Indicating type, 6 to 16 mesh, dried at 175°C (347°F) for 2 hours.

6.3 **Ascarite.** Commercially available.

7. Procedure

7.1 Sampling.

7.1.1 **Continuous Sampling.** Set up the equipment as shown in Figure 10-1 making sure all connections are leak free. Place the probe in the stack at a sampling point and purge the sampling line. Connect the analyzer and begin drawing sample into the analyzer. Allow 5 minutes for the system to stabilize, then record the analyzer reading as required by the test procedure. (See section 7.2 and 8). CO₂ content of the gas may be determined by using the Method 3 integrated sample procedure, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.1.2 **Integrated Sampling.** Evacuate the flexible bag. Set up the equipment as shown in Figure 10-2 with the bag disconnected. Place the probe in the stack and purge the sampling line. Connect the bag, making sure that all connections are leak free. Sample at a rate proportional to the stack velocity. CO₂ content of the gas may be determined by using the Method 3 integrated sample procedures, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.2 **CO Analysis.** Assemble the apparatus as shown in Figure 10-3, calibrate the instrument, and perform other required operations as described in section 8. Purge analyzer with N₂ prior to introduction of each sample. Direct the sample stream through the instrument for the test period, recording the readings. Check the zero and span again after the test to assure that any drift or malfunction is detected. Record the sample data on Table 10-1.

8. Calibration

Assemble the apparatus according to Figure 10-3. Generally an instrument requires a warm-up period before stability is obtained. Follow the manufacturer's instructions for specific procedure. Allow a minimum time of 1 hour for warm-up. During this time check the sample conditioning apparatus, i.e., filter, condenser, drying tube, and CO₂ removal tube, to ensure that each component is in good operating condition. Zero and calibrate the instrument according to the manufacturer's procedures using, respectively, nitrogen and the calibration gases.

Table 10-1—Field data

Comments	
Location _____	
Test _____	
Date _____	
Operator _____	
Clock time	Rotameter setting, liters per minute (cubic feet per minute)

9. Calculation

Calculate the concentration of carbon monoxide in the stack using Equation 10-1.

$$CCO_{stack} = CCO_{NDIR}(1 - FCO_2) \quad \text{Eq. 10-1}$$

Where:

CCO stack = Concentration of CO in stack, PPM by volume (dry basis).

CCO NDIR = Concentration of CO measured by NDIR analyzer, PPM by volume (dry basis).

FCO₂ = Volume fraction of CO₂ in sample, i.e., percent CO₂ from Orsat analysis divided by 100.

10. Alternative Procedures

10.1 **Interference Trap.** The sample conditioning system described in Method 10A, sections 2.1.2 and 4.2, may be used as an alternative to the silica gel and ascarite traps.

11. Bibliography

1. McElroy, Frank, The Intertech NDIR-CO Analyzer, Presented at 11th Methods Conference on Air Pollution, University of California, Berkeley, CA. April 1, 1970.
2. Jacobs, M. B., et al., Continuous Determination of Carbon Monoxide and Hydrocarbons in Air by a Modified Infrared Analyzer, J. Air Pollution Control Association, 9(2): 110-114. August 1959.
3. MSA LIRA Infrared Gas and Liquid Analyzer Instruction Book, Mine Safety Appliances Co., Technical Products Division, Pittsburgh, PA.
4. Models 215A, 315A, and 415A Infrared Analyzers, Beckman Instruments, Inc., Beckman Instructions 1635-8, Fullerton, CA. October 1967.
5. Continuous CO Monitoring System, Model A5611, Intertech Corp., Princeton, NJ.
6. UNOR Infrared Gas Analyzers, Bendix Corp., Ronceverte, WV

Agenda

A. Performance Specifications for NDIR Carbon Monoxide Analyzers

Range (minimum)	0—1000 PPM.
Output (minimum)	0—10mV.
Minimum detectable sensitivity	20 PPM.
Rise time, 90 percent (maximum)	30 seconds.
Fall time, 90 percent (maximum)	30 seconds.
Zero drift (maximum)	10% in 8 hours.
Span drift (maximum)	10% in 8 hours.
Precision (minimum)	± 2% of full scale.
Noise (maximum)	± 1% of full scale.
Linearity (maximum deviation)	2% of full scale.
Interference rejection ratio	CO ₂ —1000 to 1, H ₂ O—500 to 1.

B. Definitions of Performance Specifications.

Range—The minimum and maximum measurement limits.

Output—Electrical signal which is proportional to the measurement; intended for connection to readout or data processing devices. Usually expressed as millivolts or milliamps full scale at a given impedance.

Full scale—The maximum measuring limit for a given range.

Minimum detectable sensitivity—The smallest amount of input concentration that can be detected as the concentration approaches zero.

Accuracy—The degree of agreement between a measured value and the true value; usually expressed as $\pm$ percent of full scale.

Time to 90 percent response—The time interval from a step change in the input concentration at the instrument inlet to a reading of 90 percent of the ultimate recorded concentration.

Rise Time (90 percent)—The interval between initial response time and time to 90 percent response after a step increase in the inlet concentration.

Fall Time (90 percent)—The interval between initial response time and time to 90 percent response after a step decrease in the inlet concentration.

Zero Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is zero; usually expressed as percent full scale.

Span Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is a stated upscale value; usually expressed as percent full scale.

Precision—The degree of agreement between repeated measurements of the same concentration, expressed as the average deviation of the single results from the mean.

Noise—Spontaneous deviations from a mean output not caused by input concentration changes.

Linearity—The maximum deviation between an actual instrument reading and the reading predicted by a straight line drawn between upper and lower calibration points.

Method 10A—Determination of Carbon Monoxide Emissions in Certifying Continuous Emission Monitoring Systems at Petroleum Refineries

1. Applicability and Principle

1.1 Applicability. This method applies to the measurement of carbon monoxide (CO) at petroleum refineries. This method serves as the reference method in the relative accuracy test for nondispersive infrared (NDIR) CO continuous emission monitoring systems (CEMS's) that are required to be installed in petroleum refineries on fluid catalytic cracking unit catalyst regenerators [40 CFR Part 60.105(a)(2)].

1.2 Principle. An integrated gas sample is extracted from the stack, passed through an alkaline permanganate solution to remove sulfur and nitrogen oxides, and collected in a Tedlar bag. The CO concentration in the sample is measured spectrophotometrically using the reaction of CO with p-sulfaminobenzoic acid.

1.3. Range and Sensitivity.

1.3.1 Range. Approximately 3 to 1800 PPM CO. Samples having concentrations below 400 PPM are analyzed at 425 nm, and samples having concentrations above 400 PPM are analyzed at 600 nm.

1.3.2 Sensitivity. The detection limit is 3 PPM based on three times the standard deviation of the mean reagent blank values.

042694-G:\STACK\WP\METHODS\METH.10

APPENDIX K

CALCULATION EQUATIONS

METHOD 2
CALCULATION EQUATIONS

$$\bar{V}_s = 85.49 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60 (1 - B_{ws}) \bar{V}_s A \left(\frac{528}{T_{s(avg)}} \right) \left(\frac{P_s}{29.92} \right)$$

$$Q_a = 60 \bar{V}_s A$$

$$\dot{m}_s = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} - 0.0003641 P_s (T_{db} - T_{wb})) / vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

SYMBOLS

A	=	Cross Sectional area of stack, SQ. FT.
A_n	=	Cross sectional area of nozzle, SQ. FT.
B_{ws}	=	Water vapor in gas stream, proportion by volume
C_p	=	Pitot tube coefficient, dimensionless
C_s	=	Concentration of particulate matter in stack gas, wet basis, GR/ACF
C_s	=	Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	=	Excess air, percent by volume
γ	=	Dry test meter correction factor, dimensionless
G_d	=	Specific gravity (relative to air), dimensionless
I	=	Isokinetic variation, percent by volume
M_d	=	Molecular weight of stack gas, dry basis, g/g - mole.
m_g	=	Mass flow of wet flue gas, LB/HR
m_p	=	Particulate mass flow, LB/HR
M_s	=	Molecular weight of stack gas, wet basis, g/g mole.
M_p	=	Total amount of particulate matter collected, g
P_{bar}	=	Atmospheric pressure, IN. HG. (uncompensated)
P_s	=	Stack static gas pressure, IN. WC.
P_s	=	Absolute pressure of stack gas, IN. HG.
P_{std}	=	Standard absolute pressure, 29.92 IN. HG.
A_s	=	Actual volumetric stack gas flow rate, ACFM
$Q_{s,d}$	=	Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
RH	=	Relative humidity, %

032294-G:STACKWPMETHODS-EQ.15

T_{db}	=	Dry bulb temperature of stack gas, °F
T_{wb}	=	Wet bulb temperature of stack gas, °F
$T_{m(avg)}$	=	Absolute average dry gas meter temperature, °R
$T_{s(avg)}$	=	Absolute average stack temperature, °R
T_{std}	=	Standard absolute temperature, 528 °R (68 °F)
θ	=	Total sampling time, min.
V_{lc}	=	Total volume of liquid collected in impingers and silica gel, ml
V_m	=	Volume of gas sample as measured by dry gas meter, CF
$V_{m(std)}$	=	Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
$V_{w(std)}$	=	Volume of water vapor in the gas sample corrected to standard conditions, SCF
$\bar{V}_s$	=	Average actual stack gas velocity, FT/SEC
vp_{tdb}	=	Vapor pressure at T_{db} , IN. HG.
vp_{twb}	=	Vapor pressure at T_{wb} , IN. HG.
$\overline{\Delta H}$	=	Average pressure differential across the orifice meter, IN. WC.
ΔP	=	Velocity pressure of stack gas, IN. WC.
γ	=	Dry test meter correction coefficient, dimensionless
ρ	=	Actual gas density, LB/ACF

METHOD 3
CALCULATION EQUATIONS

$$\%EA = \frac{100(\%O_2 - 0.5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (J - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

METHOD 5
CALCULATION EQUATIONS

$$V_{m(std)} = 17.65 V_m \gamma \left(\frac{P_{bar} + \overline{\Delta H}/13.6}{T_{m(avg)}} \right)$$

$$V_{w(std)} = 0.0472 V_{ls}$$

$$B_{wg} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$I = 0.0944 \left(\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (I - B_{wg})} \right)$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_d = \frac{272.3 M_p P_s}{T_{s(avg)} (V_{w(std)} + V_{m(std)})}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_{s,d}$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{\theta A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

032294-G:STACKWPMETHODS-EQ.15

CALCULATION EQUATIONS

METHOD 10

$$CO\cdot PPM\cdot DRY = CO_{CO_2 - free, dry, avg} (1 - CO_2, d/100)$$

$$CO\cdot PPM\cdot WET = CO\cdot PPM\cdot DRY (1 - MC/100)$$

$$GR/DSCF = 5.0885 \times 10^{-4} (CO\cdot PPM\cdot DRY)$$

$$mg/dscm = 1.165 (CO\cdot PPM\cdot DRY)$$

$$\dot{m} = 8.5714 \times 10^{-3} (GR/DSCF) (Q_{s,d})$$

$$E = \frac{2.9857 \times 10^{-3} F_d (GR/DSCF)}{20.9 - O_{2,d}}$$

where:

$CO_{CO_2 - free, dry, avg}$

= average of two determinations of carbon monoxide on a dry, CO_2 - free integrated flue gas sample reported in ppm by volume

$CO_{2,d}$ = carbon dioxide concentration of flue gas on a dry percent by volume basis

$O_{2,d}$ = oxygen concentration of flue gas on a dry percent by volume basis

MC	=	moisture content of flue gas on a percent by volume basis
CO-PPM-DRY	=	carbon monoxide concentration in ppm by volume on a dry basis
CO-PPM-WET	=	carbon monoxide concentration in ppm by volume on a wet or actual basis
GR/DSCF	=	concentration of carbon monoxide in flue gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
mg/dscm	=	concentration of carbon monoxide in flue gas on a milligrams per dry standard cubic meter basis (60 °F, 29.92 IN. HG.)
m	=	emissions or mass rate of carbon monoxide on a LB/HR basis
$Q_{s,d}$	=	volumetric flow rate of flue gas in dry standard cubic feet per minute
E	=	emission factor of carbon monoxide in pounds of carbon monoxide emitted per million BTU heat input (LB/MMBTU)
F_d	=	F-Factor of respective fuel in dry standard cubic feet of exhaust gas at 0% oxygen per million BTU of heat input (DSCF/MMBTU)

APPENDIX L

SAMPLING TRAIN CALIBRATION DATA

INTERPOLL LABORATORIES, INC.
(612) 786-6020

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job CP / Tomahawk Date 7-13-95
Operator Bob Module No. 8

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.44 in.Hg $\theta =$.9996 $\Delta H@$ 1.84 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(458.06)		
2.5	459.97	94	79
5.0	461.94	95	79
7.5	463.90	96	81
10	465.89	98	81
	$V_m = 7.89$	$Avg(t_m) =$	87.875 °F

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_m = \frac{1.786}{(7.89)(.9996)} \left[\frac{(87.875) + 460}{(28.44)} \right]^{0.5}$$

$$Y_m = \underline{.9941}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

Interpoll Laboratories, Inc.
(612) 786-620

Meter Box Calibration and Usage Status

Date of Report: July 14, 1995

Meter Box No. : 8 (Rockwell Dry Test Meter Serial No. 964547)

Date of Last Calibration: May 12, 1995

Calibration Technician: E. Trowbridge

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter		Final Meter		Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
		Reading		Reading			
June 13, 1995	5-5703	770.80		915.70		144.90	144.90
June 16, 1995	5-5702	925.90		1059.80		133.90	278.80
June 22, 1995	5-5763	1071.10		1182.14		111.04	389.84
June 27, 1995	5-5898	1242.60		1325.60		83.00	472.84
July 07, 1995	5-5966	1343.20		1455.61		112.41	585.25
July 13, 1995	5-6006	1466.10		1625.45		159.35	744.60

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: July 14, 1995

Meter Box No. : CEM Trailer (Rockwell Dry Test Meter Serial No. 964554)

Date of Last Calibration: October 11, 1994
Calibration Technician: D. Van Hoever
Wet Test Meter No.: American Meter AL-17

Date of Use	Report No.	Initial Meter		Final Meter		Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
		Reading		Reading			
November 15, 1994	4-4337	736.610		752.485		15.875	15.875
December 06, 1994	4-4477	752.518		760.437		7.919	23.794
January 05, 1994	4-4630	760.315		763.608		3.293	27.087
January 18, 1994	5-4697	763.637		774.970		11.333	38.420
February 07, 1995	5-4810	774.990		782.804		7.814	46.234
July 11, 1995	5-6006	782.860		809.631		26.771	73.005

* Total volume through meter since last calibration.

INTERPOL. LABORATORIES, INC.
(612) 786-6020

Meter Calibration Sheet EPA/Method 5

Date _____

55-81-3

Date _____
Bar. Press. _____

5-12-95

5-12-95

Date _____
Bar. Press. _____
Wet Test Meter No. _____

AL-20

Control Module No.

Control Module
Serial No. DTM

Control Mo
Serial No. E
Technician

06547

2007-07-15
24546

[illegible]

Positive leak check performed by
Meter was in tolerance
Approved by
*Based on AI-20 wet test meter

Meter was not in tolerance ☐: readjusted linkage
 Meter was not in tolerance ☐: changed dry test meter
 Date: 5/24/95

Meter was not in tolerance ☐ readjusted linkage
 Meter was not in tolerance ☐ changed dry test meter
 Date: 5/24/95

Approved by _____
 *Based on Al-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

031794-G:\STACK\WP\FORMS\5-0102RR

(612) 786-6020

10/11/94

Wet Test Meter No.

5 CF/FEV)

Technician

1-55796

D. van Hoever

1011 Avg.

Approved by

☒: changed dry test meters

Date 10/12/94


 ~~$\Delta \leq \pm 5^\circ\text{F (In control)} - \mathcal{N}$~~ ~~$\Delta \leq \pm 5^\circ\text{F (In control)} - \mathcal{N}$~~ ☒

*Verified against mercury in/glass thermometer or calibrated platinum resistance thermometer.

*Based on AL-17 wet test meter calibration in Aug. 1989 against Bell Prover (NBS Traceable) - Carl Poe Co.

PROOF CALIBRATION CURVE

DIFFERENTIAL PRESSURE
TEST METER



Data obtained on an American 5 Ft.
Bell-Prover, Serial No. 2260. Traceable
to the Bureau of Standards. Reference
No. 106870, PI-TAPE.

AL-17 American Wet Test Meter
Serial No. P-718
Stainless Steel w/Removable Back
Calibrated with Saturated Air
Water Temp. 74° F.
Air Temp. 74° F.
Inlet Pressure 2" H₂O Constant
Calibration Rate: 14 CFH Air
Capacity Rate: 8 CFH Air
Restricted Outlet for Rate Deviation.

DAVID BANKS
AUGUST, 1989

INDEX READING x PROOF = 100
CORRECT VOLUME =
FLOW RATE - CUB. FEET OF AIR PER HOUR

DIFFERENTIAL - INCHES H2O

PULSATION RANGE

30
20
10
0

DIFFERENTIAL - PRE

100

100

100

100

100

100

100

100

100

WET TEST METER

Calibrated with a 10 ft. American Bell
Prover, Serial No. 3157. Traceable to
the Bureau of Standards. Reference No.
5249060, PI-TAPE.

AL-20 American Wet Test Meter

Serial No. 217

Stainless Steel w/Removable Back

Calibrated w/Saturated Air

Water Temp. 74° F.

Air Temp. 74° F.

Inlet Pressure 2" H2O Constant

Calibration Rate: 60 CFH Per/Hr.

Capacity Rate: 120 CFH Per/Hr.

Restricted Outlet for Rate Deviation

PROOF

100

100

90

80

70

60

50

40

30

20

10

CORRECT VOLUME + INDEX READING X PROOF = 100

120

100

80

60

40

20

DAVID BARKS

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-13-95
Technician: Bob Aschenbach

Nozzle Number 5-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.185
2	.185
3	.185
Average:	.185

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor

Model

Range

Date of Calibration

Method of Calibration:

Omega

HH61

0 - 2500

3-31-95

Serial Number

Thermocouple Type

Technician

PDT No.

74JX0223

K

B22 A

33

☐ Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.

☒ Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-2.3	-2.3	-.5
100	100	97.1	2.9	.51
200	200	199.1	.9	.13
300	300	297.3	2.7	.35
400	400	397	3	.34
500	500	497	3	.31
600	600	599	1	.09
700	700	698	2	.17
800	800	800	0	0
900	900	899	1	.07
1000	1000	999	1	.06
1100	1100	1098	2	.12
1200	1200	1199	1	.06
1300	1300	1298	2	.11
1400	1400	1400	0	0
1500	1500	1499	1	.05
1600	1600	1601	1	.04
1700	1700	1699	1	.04
1800	1800	1802	2	.08
1900	1900	1899	1	.04
2000	2000	2000	0	0
2100	2100	2097	3	.11
		Averages:	1.28	.099

OF = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

☒ Unit in tolerance

☐ Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:\STACK\WP\FORMS\433

S-Type Pitot Tube Inspection Sheet

Pitot Tube No 27-4

Pitot tube dimensions:

1. External tubing diameter (D) 1.316 IN.
2. Base to Side A opening plane (P_A) 1.460 IN.
3. Base to Side B opening plane (P_B) 1.460 IN.

Alignment:

4. α_1 < 10° 0
5. α_2 < 10° 0
6. β_1 < 5° 0
7. β_2 < 5° 0
8. Z < .125" .02
9. W < .0625" .01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle 1.750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 1.760 IN.

- ☒ Meets all EPA design criteria thus $C_p = 0.84$
☐ Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

[Signature]

Interpoll Laboratories, Inc.
(612) 786-6020

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 27-6

Pitot tube dimensions:

1. External tubing diameter (D_t) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. α_1 $< 10^\circ$ 0
5. α_2 $< 10^\circ$ 0
6. B_1 $< 5^\circ$ 0
7. B_2 $< 5^\circ$ 0
8. Z $< .125"$.01
9. W $< .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- ☒ Meets all EPA design criteria thus $C_p = 0.84$
☐ Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 27-8

Pitot tube dimensions:

1. External tubing diameter (D_t) 316 IN.
2. Base to Side A opening plane (P_A) 460 IN.
3. Base to Side B opening plane (P_B) 460 IN.

Alignment:

4. α_1 $< 10^\circ$ 0
5. α_2 $< 10^\circ$ 0

6. B_1 $< 5^\circ$ 0
7. B_2 $< 5^\circ$ 0

8. Z $< .125"$ 0
9. W $< .0625"$.01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle 750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 760 IN.

- ☒ Meets all EPA design criteria thus $C_p = 0.84$
☐ Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

E. J. Lawler

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date

3-31-95

Technician

Bob A

Mercury Column Barometer No.

No 1 L+B

Aneroid Barometer No.

10723029

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference ($P_{ba} - P_{bm}$)
29.33	77	.127	29.213	29.22	.01

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain _____

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.