

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

RESULTS OF THE JULY 23 - 25, 1996
AIR EMISSION COMPLIANCE TESTS
AT THE LOUISIANA PACIFIC OSB PLANT
SAGOLA, MICHIGAN

Louisiana-Pacific Corporation

Route 8, Box 82
Hayward, Wisconsin
715/634-3332
FAX: 715/634-5117
November 5, 1996

Director, Air Enforcement Division
U.S. EPA
Ariel Rios Building, Room 1119
Mail Code 2242A
12th Street and Pennsylvania Ave., N.W.
Washington, D.C. 20004

Mr. Laxmi Kesari
Multi-Media Enforcement & Strategic Planning Division
U.S. EPA
401 M. Street SW
Mail Code 2248A
Washington, D.C. 20460

re: United States v. Louisiana-Pacific Corporation
No. CV93-0869(W.D. La)

subject: Sagola, MI Acceptance Testing

Dear Sir/Madam:

Upon review of the compliance test results for Louisiana-Pacific's Oriented Strand facility located near Sagola, MI, it was determined that the test report was in error. Emissions reported from the dryer regenerative thermal oxidizer (RTO) outlet were from propane to a single carbon; therefore, the emission rate of 4.2 lb/hr from the RTO has been revised to 14.6 lb/hr.

This revision did not effect the compliance status, as the destruction removal efficiency (1-(14.6/476)) is 97%. This demonstrates compliance with the 95% limit as required by Amendment to the Consent Decree.

Find the enclosed copy of the revision to the test report. If you have any comments, please feel free to contact me.

DRYER R1
Particulate
DRY #1



Route 8, Box 8253
Hayward, Wisconsin 54843
715/634-3332
FAX: 715/634-5117
November 5, 1996

Director, Air Enforcement Division
U.S. EPA
Ariel Rios Building, Room 1119
Mail Code 2242A
12th Street and Pennsylvania Ave., N.W.
Washington, D.C. 20004

Mr. Laxmi Kesari
Multi-Media Enforcement & Strategic Planning Division
U.S. EPA
401 M. Street SW
Mail Code 2248A
Washington, D.C. 20460

re: United States v. Louisiana-Pacific Corporation
No. CV93-0869(W.D. La)

subject: Sagola, MI Acceptance Testing

Dear Sir/Madam:

Upon review of the compliance test results for Louisiana-Pacific's Oriented Strand Board (OSB) facility located near Sagola, MI, it was determined that the test report was in error. The VOC emissions reported from the dryer regenerative thermal oxidizer (RTO) outlet were not converted from propane to a single carbon; therefore, the emission rate of 4.2 lb/hr from the dryer RTO has been revised to 14.6 lb/hr.

This revision did not effect the compliance status, as the destruction removal efficiency (DRE) (1-(14.6/476)) is 97%. This demonstrates compliance with the 95% limit as stated in the First Amendment to the Consent Decree.

Please find the enclosed copy of the revision to the test report.

If you have any questions or comments, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Keith Seelig'. The signature is written in a cursive style with a large, sweeping 'K' and 'S'.

Keith Seelig
Environmental Manager
North Central Division

cc w/enc: Julie Domike - U.S. EPA, Air Toxics, New Source Review and Permit
Kim Armbruster - MI DEQ, Air Quality Division

PARAMETER **MEASURED**
DRYER PRIMARY CYCLONE EXHAUST 3

Particulate		
DRY + WET CATCH	(GR/DSCF)	0.303
.....	(LB/HR)	70
DRY CATCH ONLY	(GR/DSCF)	0.198
.....	(LB/HR)	46
Oxides of Nitrogen		
.....	(ppm,d)	47
.....	(LB/HR)	9.0
Carbon Monoxide		
.....	(ppm,d)	1744
.....	(LB/HR)	204
Total Hydrocarbons		
.....	(ppmC,w)	3189
.....	(LBC/HR)	209
Formaldehyde		
.....	(ppm,d)	12
.....	(LB/HR)	1.5

E-TUBE OUTLET

Particulate		
DRY + WET CATCH	(GR/DSCF)	0.0417
.....	(LB/HR)	37
DRY CATCH ONLY	(GR/DSCF)	0.00829
.....	(LB/HR)	7.3
Oxides of Nitrogen		
.....	(ppm,d)	2.4
.....	(LB/HR)	1.8
Carbon Monoxide		
.....	(ppm,d)	1836
.....	(LB/HR)	826
Opacity	(%)	*

DRYER RTO OUTLET

Particulate		
DRY + WET CATCH	(GR/DSCF)	0.00635
.....	(LB/HR)	5.5
DRY CATCH ONLY	(GR/DSCF)	0.00228
.....	(LB/HR)	2.0
Oxides of Nitrogen		
.....	(ppm,d)	2.8
.....	(LB/HR)	2.0
Carbon Monoxide		
.....	(ppm,d)	229
.....	(LB/HR)	100
Total Hydrocarbons		
.....	(ppmC,w)	59.9
.....	(LBC/HR)	14.6
Formaldehyde		
.....	(ppm,d)	2.5
.....	(LB/HR)	1.2

* Visible emission determinations were unable to be performed due to inclement weather conditions.

Table 9. Summary of the Results of the July 23 - 25, 1996 Total Hydrocarbons Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppmC,w)	Emission Rate (LBC/HR)
Primary Cyclone Exhaust 1			
7-23-96	1435-1535	1937	129
7-23-96	1645-1745	1796	120
7-23-96	1925-2025	1677	112
Avg		1803	121
Primary Cyclone Exhaust 2			
7-23-96	1435-1535	2165	153
7-23-96	1645-1745	2125	153
7-23-96	1925-2025	1840	133
Avg		2043	146
Primary Cyclone Exhaust 3			
7-23-96	1435-1535	3498	237
7-23-96	1645-1745	2595	167
7-23-96	1925-2025	3474	223
Avg		3189	209
Dryer RTO Stack*			
7-23-96	1435-1535	82.1	19.9
7-23-96	1645-1745	32.5	8.0
7-23-96	1925-2025	65.1	16.0
Avg		59.9	14.6
Press Inlet			
7-25-96	1620-1720	705	88
7-25-96	1800-1900	764	101
7-25-96	1934-2034	744	104
Avg		738	98
Press Stack*			
7-25-96	1620-1720	11.9	1.8
7-25-96	1800-1900	19.4	2.9
7-25-96	1934-2034	6.8	1.0
Avg		12.7	1.9

* TGNMOs = corrected for methane

Test No. 2
Dryer RTO Stack

Results of Total Hydrocarbons Determinations-----**Method 25A**

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.9	23.5	23.5
Oxygen content (%V/V)	17.3	17.3	17.3
Volumetric flow rate (DSCFM)	99560	100405	100405
THC concentration			
ppmC,wet (as carbon)	82.1	32.5	65.1
THC emission rate (LB/HR)	19.9	8.0	16.0

Test No. 8
Press RTO Stack

Results of Total Hydrocarbons Determinations—————**Method 25A**

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	2.9	3.3	3.4
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	77990	76250	77090
THC concentration			
ppmC,wet (as carbon)	11.9	19.4	6.8
THC emission rate (LB/HR)	1.8	2.9	1.0

		Total HydroCarbons Calculations				Report No. 6-8024	
		CONC	GASFLOW	MASSRATE	AVERAGE		
		(ppmC,w)	(DSCFM)	(LB/HR)	(ppmC,w)	(LB/HR)	(GR/DSCF)
Dryer RTO Stack							
TEST #	RUN	MC%	CONC	GASFLOW	MASSRATE	AVERAGE	(GR/DSCF)
			(ppmC,w)	(DSCFM)	(LB/HR)	(ppmC,w)	(LB/HR)
2	1	22.9	82.1	99560	19.81		0.0232137
	2	23.5	32.5	100405	7.97		0.0092614
	3	23.5	65.1	100405	15.97		0.0185514
						59.9	14.58197
Press RTO Inlet							
TEST #	RUN	MC%	CONC	GASFLOW	MASSRATE	AVERAGE	(GR/DSCF)
			(ppmC,w)	(DSCFM)	(LB/HR)	(ppmC,w)	(LB/HR)
8	1	3.9	705	64300	88.14		0.1599272
	2	2.9	764.0	68979	101.41		0.1715263
	3	3	744	72300	103.62		0.1672082
						737.66667	97.72591
Press RTO Stack							
TEST #	RUN	MC%	CONC	GASFLOW	MASSRATE	AVERAGE	(GR/DSCF)
			(ppmC,w)	(DSCFM)	(LB/HR)	(ppmC,w)	(LB/HR)
8	1	2.9	11.9	77990	1.79		0.0026717
	2	3.3	19.4	76250	2.86		0.0043735
	3	3.4	6.8	77090	1.01		0.0015346
						12.7	1.886125

LOUISIANA PACIFIC - SAGOLA					Report No. 6-8024				
Sagola, Michigan									
Gas Concentration Correction Calculations									
PCE#1									
THC Calculations									
<i>C_{bar}</i>					<i>C_{ma}</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm.w)	(Final)	(Initial)	<i>C_o</i>	(Upscale)	(Final)	(Initial)	<i>C_m</i>	<i>C_{gas}</i>
2	665.39	8.6	1	4.80	287	310	287	299	645.52
3	580.81	2.4	0	1.20	287	270	288	279	598.81
4	547.44	7.65	2.4	5.03	287	280	287	284	559.02
PCE #2									
<i>C_{bar}</i>					<i>C_{ma}</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm.w)	(Final)	(Initial)	<i>C_o</i>	(Upscale)	(Final)	(Initial)	<i>C_m</i>	<i>C_{gas}</i>
2	705.39	5.5	1	3.25	287	282	283	283	721.63
3	694.91	4	1	2.50	287	282	284	283	708.46
4	586.96	4	1	2.50	287	270	282	276	613.31
PCE #3									
<i>C_{bar}</i>					<i>C_{ma}</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm.w)	(Final)	(Initial)	<i>C_o</i>	(Upscale)	(Final)	(Initial)	<i>C_m</i>	<i>C_{gas}</i>
2	1124.87	1	2	1.50	287	269	287	278	1166.03
3	844.41	10	0	5.00	287	280	287	284	865.03
4	1143.93	0	0	0.00	287	284	283	284	1158.05
Dryer RTO Stack									
<i>C_{bar}</i>					<i>C_{ma}</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm.w)	(Final)	(Initial)	<i>C_o</i>	(Upscale)	(Final)	(Initial)	<i>C_m</i>	<i>C_{gas}</i>
2	27.37	0	0	0.00	30	27	30	29	28.81
3	12.36	1	0	0.50	30	29	30	30	12.27
4	22.21	2	0	1.00	30	27	30	29	23.14
Press RTO Inlet									
<i>C_{bar}</i>					<i>C_{ma}</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm.w)	(Final)	(Initial)	<i>C_o</i>	(Upscale)	(Final)	(Initial)	<i>C_m</i>	<i>C_{gas}</i>
1	233.39	0	0	0.00	285	281	285	283	235.04
2	255.7	1	0	0.50	285	287	285	286	254.75
3	252.27	0	0	0.00	285	292	287	290	248.35
Press RTO Stack									
<i>C_{bar}</i>					<i>C_{ma}</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm.w)	(Final)	(Initial)	<i>C_o</i>	(Upscale)	(Final)	(Initial)	<i>C_m</i>	<i>C_{gas}</i>
1	6.30	0	0.4	0.20	30.4	28.6	30.7	30	6.30
2	8.45	0	0	0.00	30.4	28.8	29.5	29	8.81
3	5.11	1.5	0	0.75	30.4	29.2	30.0	30	4.59

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020
FAX: (612) 786-7854

**RESULTS OF THE JULY 23 - 25, 1996
AIR EMISSION COMPLIANCE TESTS
AT THE LOUISIANA PACIFIC OSB PLANT
SAGOLA, MICHIGAN**

Submitted to:

LOUISIANA PACIFIC CORPORATION
Route 8, Box 8263
Hayward, Wisconsin 54843

Attention:

Keith Seelig

Approved by:



Daniel J. Despen

Manager

Stationary Source Testing Department

Report Number 6-8024
August 29, 1996
SL/sll

TABLE OF CONTENTS

	ABBREVIATIONS	iii
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	6
3	RESULTS	28
	3.1 Results of Orsat & Moisture Determinations	29
	3.2 Results of Particulate Determinations	43
	3.3 Results of Oxides of Nitrogen Determinations	50
	3.4 Results of Opacity Observations	64
	3.5 Results of Carbon Monoxide Determinations	66
	3.6 Results of Total Hydrocarbons Determinations	74
	3.7 Results of Formaldehyde Determinations	81
	3.8 Results of Phenol Determinations	88
	3.9 Results of MDI Determinations	91
4	RESULTS OF FUEL ANALYSES	93

APPENDICES:

- A - Results of Volumetric Flow Rate Determinations
- B - Location of Test Ports
- C - Field Data Sheets
- D - Interpoll Laboratories Analytical Results
- E - Total Hydrocarbons Stripchart
- F - Computer Datalogger Printouts
- G - Measurement Systems Performance Specifications
- H - Calibration Gas Certification Sheets
- I - Process Rate Information
- J - Procedures
- K - Calculation Equations
- L - Sampling Train Calibration Data

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.

1 INTRODUCTION

During the period of July 23 - 25, 1996 Interpoll Laboratories personnel conducted Air Emission Compliance tests at the Louisiana Pacific Corporation (LP) OSB Plant Located in Sagola, Michigan on the following sources:

<u>Source</u>	<u>Parameters</u>
Dryer Primary Cyclone Exhaust 1	PM,NO _x ,CO,THC's,CH ₂ O
Dryer Primary Cyclone Exhaust 2	PM,NO _x ,CO,THC's,CH ₂ O
Dryer Primary Cyclone Exhaust 3	PM,NO _x ,CO,THC's,CH ₂ O
E-Tube Outlet	PM,NO _x (7E),VE,CO,THC's
Dryer RTO Outlet	PM,NO _x (7E),CO,THC's,CH ₂ O
Press RTO Inlet	PM,NO _x (7E),CO,THC's,CH ₂ O,Phenol
Press RTO Stack	PM,NO _x (7E),VE,CO,THC's,CH ₂ O,Phenol,MDI

On-site testing was performed by Mark Kaehler, Duane Van Hoever, Ed Juers, Scott Fjelsta, Jamie Bainville, Mark Petersen, Scott Bainville, Jim Lorenz, Lee Hansen, and Dan Hulleman. Coordination between testing activities and plant operation was provided by Keith Seelig of LP. The tests were not witnessed by a member of the Michigan Department of Natural Resources.

The Sagola plant operates three 12 x 60 Heil wafer dryers fired by Coen burners, a press and one GEKA thermal oil heater. Press emissions are ducted to an RTO prior to exhaust to the atmosphere.

Particulate evaluations were performed in accordance with EPA Methods 2-5, CFR Title 40, Part 60, Appendix A (revised July 1, 1995). A preliminary determination of the gas linear velocity profile was made at each test location before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with EPA Method 202.

An integrated flue gas sample was extracted using a specially designed gas sampling system. Integrated flue gas samples were collected in 44-liter Tedlar bags housed in a protective aluminum container. After sampling was complete, the bags were sealed and returned to the laboratory for Orsat analysis. Prior to sampling, the Tedlar bags are leak-checked at 15 IN.HG. vacuum with an in-line rotameter. Bags with any detectable in-leakage are discarded. Integrated flue gas samples collected during each particulate sampling were also analyzed for carbon monoxide as per EPA Method 10 (NDIR).

The oxides of nitrogen samples at each Dryer Primary Exhaust site were collected using an all-glass Method 7 sampling train. A heated stainless steel probe was used to extract the samples from the exhaust stream. A plug of glass-wool was used in the end of the probe to remove particulate material.

The NO_x samples were collected in volume-calibrated two-liter all-glass flasks. An aliquot of 25 cc of absorbing solution was added to each flask on-site; the flask was closed; inserted into the sampling train; and evacuated. The probe was then purged and the sample collected over a 15 second interval. The flask was then closed; the flask removed from the sampling train; shook for two minutes and then secured for transport to the laboratory.

Upon arrival at the laboratory, the NO_x samples are logged in, placed in a designated area and maintained at 72 °F for 24 hours to allow completion of the conversion of NO to NO_2 and absorption in the acidified peroxide reagent. The flasks are then shook to complete absorption; attached to a mercury manometer and the static pressure and temperature recorded. The samples are then recovered and analyzed by ion chromatography.

Oxides of nitrogen, carbon monoxide, oxygen, and carbon dioxide concentrations were determined in accordance with Methods 7E, 10, and 3A (Ibid). A slip stream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice which was used to ensure that the flow from

the stack exceeds the requirements of the analyzers. A three-way valve on the probe was used to introduce standard gas for the "system bias check".

The analog response of each analyzer was recorded with a computer datalogger and backed up with a strip chart recorder. The NO_x, CO, O₂ and CO₂ analyzers were calibrated with National Specialty Gases and Air Products and Chemicals standard gases. The instrument was calibrated before and after each run as per EPA Method 7E, 10, and 3A. The sample probe was moved through a three-point traverse (1/6, 3/6, 5/6 of the stack diameter) to measure oxides of nitrogen and carbon monoxide concentrations.

Formaldehyde samples were collected using EPA Method 0011 (SW 846 3rd Ed.). The samples were collected isokinetically using a Method 5 sampling train with an aqueous acidic 2,4-dinitrophenylhydrazine absorbing solution and analyzed by high performance liquid chromatography.

Total gaseous hydrocarbon concentrations were determined instrumentally using a Ratfisch Model RS55 heated flame ionization detector (HFID) calibrated against propane in air standards. The THC concentration was continuously monitored by extracting a slipstream of exhaust gas by means of a heated probe and filter holder. A heat-traced teflon line was used to transport the sample gas from the filter holder outlet to the analyzer inlet.

Phenol concentrations were determined from each source using a Method 5 sampling train with neutral buffered absorbing reagent. The first impinger in each sampling was spiked with isotopically-labeled phenol (phenol-d₅) and 2-fluorophenol for sampling and recovery efficiency surrogates. The recovered samples were extracted and analyzed by GC/MS for phenol, phenol-d₅, and 2-fluorophenol.

MDI concentrations were determined in accordance with the 1,2-PP Method as developed by Radian Corporation under contract to USEPA. This method employs collection of MDI with 1,2-PP in toluene reagent, with analysis by HPLC.

Testing on the Primary Cyclone Outlet Exhaust 1 was conducted from two test ports oriented at 90 degrees. These test ports are located 6.7 diameters downstream and 2.4 diameters upstream of the nearest flow disturbances. A 16-point traverse was used to collect

representative particulate and formaldehyde samples. Each traverse point was sampled 4 minutes to give a total sampling time of 64 minutes per run.

Testing on the Primary Cyclone Outlet Exhaust 2 was conducted from two test ports oriented at 90 degrees. These test ports are located > 2 diameters downstream and > 0.5 diameters upstream of the nearest flow disturbances. A 12-point traverse was used to collect representative particulate and formaldehyde samples. Each traverse point was sampled 5 minutes to give a total sampling time of 60 minutes per run.

Testing on the Primary Cyclone Outlet Exhaust 3 was conducted from two test ports oriented at 90 degrees. These test ports are located > 2 diameters downstream and > 0.5 diameters upstream of the nearest flow disturbances. A 12-point traverse was used to collect representative particulate and formaldehyde samples. Each traverse point was sampled 5 minutes to give a total sampling time of 60 minutes per run.

Testing on the E-Tube Outlet was conducted from two test ports oriented at 90 degrees. These test ports are located approximately 10 diameters downstream and 1 diameter upstream of the nearest flow disturbances. A 24-point traverse was used to collect representative particulate samples. Each traverse point was sampled for 2.5 minutes to give a total sampling time of 60 minutes per run.

Testing on the Dryer RTO Outlet was conducted from two test ports oriented at 90 degrees. These test ports are located approximately 5 diameters downstream and 2 diameters upstream of the nearest flow disturbances. A 16-point traverse was used to collect representative particulate and formaldehyde samples. Each traverse point was sampled for 4 minutes to give a total sampling time of 60 minutes per run.

Testing on the Press RTO Inlet was conducted from two test ports oriented at 90 degrees. These test ports are located 2.1 stack diameters downstream and 4.5 stack diameters upstream of the nearest flow disturbances. A 24-point traverse was used to collect the particulate and formaldehyde samples. Each traverse point was sampled 2.5 minutes to give a total sampling time of 60 minutes per run. A 3-point traverse was used to collect representative phenol samples. Each traverse point was sampled for 20 minutes to give a total sampling time of 60 minutes per run.

Testing on the Press RTO Stack was conducted from two test ports oriented at 90 degrees on the stack. These test ports are located 5.5 stack diameters downstream and 4.3 stack diameters upstream of the nearest flow disturbances. A 20-point traverse was used to collect the particulate, formaldehyde, MDI samples. Each traverse point was sampled 3 minutes to give a total sampling time of 60 minutes per run. A 3-point traverse was used to collect representative phenol samples. Each traverse point was sampled for 20 minutes to give a total sampling time of 60 minutes per run.

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The important results of the particulate emission compliance tests are summarized in Tables 1 - 12. The particulate results have been calculated using the dry plus method 202 condensible wet catch ("a" Tables) and again with the dry catch only ("b" Tables). An overview of all results is presented in the tables on the following pages:

<u>PARAMETER</u>	<u>MEASURED</u>
<u>DRYER PRIMARY CYCLONE EXHAUST 1</u>	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.324
. (LB/HR)	75
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.211
. (LB/HR)	49
Oxides of Nitrogen	
. (ppm,d)	37
. (LB/HR)	7.1
Carbon Monoxide	
. (ppm,d)	1798
. (LB/HR)	211
Total Hydrocarbons	
. (ppmC,w)	1803
. (LBC/HR)	121
Formaldehyde	
. (ppm,d)	13
. (LB/HR)	1.6
<u>DRYER PRIMARY CYCLONE EXHAUST 2</u>	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.242
. (LB/HR)	60
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.179
. (LB/HR)	44
Oxides of Nitrogen	
. (ppm,d)	35
. (LB/HR)	7.1
Carbon Monoxide	
. (ppm,d)	1902
. (LB/HR)	239
Total Hydrocarbons	
. (ppmC,w)	2043
. (LBC/HR)	146
Formaldehyde	
. (ppm,d)	13
. (LB/HR)	1.7

<u>PARAMETER</u>	<u>MEASURED</u>
<u>DRYER PRIMARY CYCLONE EXHAUST 3</u>	
Particulate	
DRY + WET CATCH (GR/DSCF)	0.303
. (LB/HR)	70
DRY CATCH ONLY (GR/DSCF)	0.198
. (LB/HR)	46
Oxides of Nitrogen	
. (ppm,d)	47
. (LB/HR)	9.0
Carbon Monoxide	
. (ppm,d)	1744
. (LB/HR)	204
Total Hydrocarbons	
. (ppmC,w)	3189
. (LBC/HR)	209
Formaldehyde	
. (ppm,d)	12
. (LB/HR)	1.5
<u>E-TUBE OUTLET</u>	
Particulate	
DRY + WET CATCH (GR/DSCF)	0.0417
. (LB/HR)	37
DRY CATCH ONLY (GR/DSCF)	0.00829
. (LB/HR)	7.3
Oxides of Nitrogen	
. (ppm,d)	2.4
. (LB/HR)	1.8
Carbon Monoxide	
. (ppm,d)	1836
. (LB/HR)	826
Opacity (%)	*
<u>DRYER RTO OUTLET</u>	
Particulate	
DRY + WET CATCH (GR/DSCF)	0.00635
. (LB/HR)	5.5
DRY CATCH ONLY (GR/DSCF)	0.00228
. (LB/HR)	2.0
Oxides of Nitrogen	
. (ppm,d)	2.8
. (LB/HR)	2.0
Carbon Monoxide	
. (ppm,d)	229
. (LB/HR)	100
Total Hydrocarbons	
. (ppmC,w)	17.1
. (LBC/HR)	4.2
Formaldehyde	
. (ppm,d)	2.5
. (LB/HR)	1.2

* Visible emission determinations were unable to be performed due to inclement weather conditions.

<u>PARAMETER</u>	<u>MEASURED</u>
<u>PRESS RTO INLET</u>	
Oxides of Nitrogen	
..... (ppm,d)	7.3
..... (LB/HR)	3.6
Carbon Monoxide	
..... (ppm,d)	4.9
..... (LB/HR)	1.5
Total Hydrocarbons	
..... (ppmC,w)	738
..... (LBC/HR)	98
Formaldehyde	
..... (ppm,d)	6.3
..... (LB/HR)	2.0
Phenol	
..... (ppm,d)	< 0.17
..... (LB/HR)	< 0.17
<u>PRESS RTO STACK</u>	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.0148
..... (LB/HR)	9.3
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.00233
..... (LB/HR)	1.5
Oxides of Nitrogen	
..... (ppm,d)	35.2
..... (LB/HR)	19.4
Opacity (%)	0
Carbon Monoxide	
..... (ppm,d)	21.4
..... (LB/HR)	7.2
Total Hydrocarbons	
..... (ppmC,w)	12.7
..... (LBC/HR)	1.9
Formaldehyde	
..... (ppm,d)	0.16
..... (LB/HR)	0.056
Phenol	
..... (ppm,d)	< 0.17
..... (LB/HR)	< 0.20
MDI	
..... (ppm,d)	< 0.0008
..... (LB/HR)	< 0.0024

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples which were conducted by Interpoll Labs. On the basis of these facts and a complete review of the data and results, it is our opinion that the results reported

herein are accurate and closely reflect the actual values which existed at the time the test was performed.

Table 1a Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust 1 at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1130/1330	1436/1543	1645/1751
Process rate			
Volumetric flow (ACFM) actual	48712	50015	50083
standard (DSCFM)	26981	26838	27141
Gas temperature (DEG-F)	223	224	223
Moisture content (%V/V)	22.53	24.86	24.25
Gas composition (%V/V, dry)			
carbon dioxide	3.00	3.40	3.70
oxygen	17.60	17.10	16.80
nitrogen	79.40	79.50	79.50
Isokinetic variation (%)	96.8	100.4	98.8
Particulate concentration			
actual (GR/ACF)	0.155	0.178	0.196
standard (GR/DSCF)	0.280	0.331	0.362
Part. emission rate (LB/HR)	64.79	76.13	84.22

Note: Dry + Method 202 Condensable Particulate Material

Table 1b Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust 1 at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1130/1330	1436/1543	1645/1751
Process rate			
Volumetric flow actual (ACFM)	48712	50015	50083
standard (DSCFM)	26981	26838	27141
Gas temperature (DEG-F)	223	224	223
Moisture content (%V/V)	22.53	24.86	24.25
Gas composition (%V/V, dry)			
carbon dioxide	3.00	3.40	3.70
oxygen	17.60	17.10	16.80
nitrogen	79.40	79.50	79.50
Isokinetic variation (%)	96.8	100.4	98.8
Particulate concentration			
actual (GR/ACF)	.0967	0.111	0.137
standard (GR/DSCF)	0.175	0.206	0.253
Part. emission rate (LB/HR)	40.41	47.39	58.92

Note: Dry Catch Only

Table 2a Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust 2 at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1134/1330	1435/1542	1645/1750
Process rate			
Volumetric flow actual (ACFM)	50773	51371	52976
standard (DSCFM)	27990	28278	29969
Gas temperature (DEG-F)	205	205	211
Moisture content (%V/V)	25.03	25.14	22.40
Gas composition (%V/V, dry)			
carbon dioxide	3.20	3.80	3.20
oxygen	17.20	16.90	17.20
nitrogen	79.60	79.30	79.60
Isokinetic variation (%)	99.9	100.2	98.7
Particulate concentration			
actual (GR/ACF)	0.137	0.125	0.141
standard (GR/DSCF)	0.248	0.228	0.250
Part. emission rate (LB/HR)	59.45	55.19	64.13

Note: Dry + Method 202 Condensable Particulate Material

Table 2b Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust 2 at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1134/1330	1435/1542	1645/1750
Process rate			
Volumetric flow (ACFM) actual	50773	51371	52976
standard (DSCFM)	27990	28278	29969
Gas temperature (DEG-F)	205	205	211
Moisture content (%V/V)	25.03	25.14	22.40
Gas composition (%V/V, dry)			
carbon dioxide	3.20	3.80	3.20
oxygen	17.20	16.90	17.20
nitrogen	79.60	79.30	79.60
Isokinetic variation (%)	99.9	100.2	98.7
Particulate concentration			
actual (GR/ACF)	.0986	.0930	0.107
standard (GR/DSCF)	0.179	0.169	0.190
Part. emission rate (LB/HR)	42.94	40.97	48.73

Note: Dry Catch Only

Table 3a Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust 3 at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1133/1328	1435/1529	1645/1736
Process rate			
Volumetric flow actual (ACFM)	47773	49892	47420
standard (DSCFM)	25358	27973	27234
Gas temperature (DEG-F)	214	214	213
Moisture content (%V/V)	26.69	22.66	20.79
Gas composition (%V/V, dry)			
carbon dioxide	3.10	3.70	3.10
oxygen	17.50	16.80	17.40
nitrogen	79.40	79.50	79.50
Isokinetic variation (%)	101.1	95.5	96.6
Particulate concentration			
actual (GR/ACF)	0.140	0.186	0.179
standard (GR/DSCF)	0.265	0.331	0.312
Part. emission rate (LB/HR)	57.51	79.46	72.83

Note: Dry + Method 202 Condensible Particulate Material

Table 3b Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust 3 at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1133/1328	1435/1529	1645/1736
Process rate			
Volumetric flow actual (ACFM)	47773	49892	47420
standard (DSCFM)	25358	27973	27234
Gas temperature (DEG-F)	214	214	213
Moisture content (%V/V)	26.69	22.66	20.79
Gas composition (%V/V, dry)			
carbon dioxide	3.10	3.70	3.10
oxygen	17.50	16.80	17.40
nitrogen	79.40	79.50	79.50
Isokinetic variation (%)	101.1	95.5	96.6
Particulate concentration			
actual (GR/ACF)	.0953	0.117	0.118
standard (GR/DSCF)	0.180	0.209	0.206
Part. emission rate (LB/HR)	39.05	50.20	48.18

Note: Dry Catch Only

Table 4a Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the E-Tube Outlet at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1133/1326	1435/1539	1645/1748
Process rate			
Volumetric flow (ACFM) actual	165860	166648	167899
standard (DSCFM)	103433	103228	103158
Gas temperature (DEG-F)	157	162	161
Moisture content (%V/V)	22.68	22.60	23.41
Gas composition (%V/V, dry)			
carbon dioxide	2.80	2.90	2.90
oxygen	17.80	17.70	17.60
nitrogen	79.40	79.40	79.50
Isokinetic variation (%)	97.9	101.5	102.6
Particulate concentration			
actual (GR/ACF)	.0260	.0236	.0279
standard (GR/DSCF)	.0416	.0382	.0454
part. emission rate (LB/HR)	36.91	33.79	40.15

Note: Dry + Method 202 Condensable Particulate Material

Table 4b Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the E-Tube Outlet at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1133/1326	1435/1539	1645/1748
Process rate			
Volumetric flow actual (ACFM)	165860	166648	167899
standard (DSCFM)	103433	103228	103158
Gas temperature (DEG-F)	157	162	161
Moisture content (%V/V)	22.68	22.60	23.41
Gas composition (%V/V, dry)			
carbon dioxide	2.80	2.90	2.90
oxygen	17.80	17.70	17.60
nitrogen	79.40	79.40	79.50
Isokinetic variation (%)	97.9	101.5	102.6
Particulate concentration			
actual (GR/ACF)	.006906	.003974	.004517
standard (GR/DSCF)	.0111	.006418	.007355
Part. emission rate (LB/HR)	9.82	5.68	6.50

Note: Dry Catch Only

Table 5a Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer RTO Outlet at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1132/1331	1435/1540	1645/1751
Process rate			
Volumetric flow (ACFM) actual	192090	186922	189616
standard (DSCFM)	103148	99560	100405
Gas temperature (DEG-F)	261	263	262
Moisture content (%V/V)	22.55	22.94	23.53
Gas composition (%V/V, dry)			
carbon dioxide	3.00	3.00	3.00
oxygen	17.30	17.30	17.30
nitrogen	79.70	79.70	79.70
Isokinetic variation (%)	97.9	94.2	100.3
Particulate concentration (GR/ACF)			
actual	.003123	.004124	.002911
standard (GR/DSCF)	.005819	.007745	.005499
Part. emission rate (LB/HR)	5.14	6.61	4.73

Note: Dry + Method 202 Condensibile Particulate Material

Table 5b Summary of the Results of the July 23, 1996 Particulate Emission Compliance Test of the Dryer RTO Outlet at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-23-96	07-23-96	07-23-96
Time runs were done (HRS)	1132/1331	1435/1540	1645/1751
Process rate			
Volumetric flow actual (ACFM)	192090	186922	189616
standard (DSCFM)	103148	99560	100405
Gas temperature (DEG-F)	261	263	262
Moisture content (%V/V)	22.55	22.94	23.53
Gas composition (%V/V, dry)			
carbon dioxide	3.00	3.00	3.00
oxygen	17.30	17.30	17.30
nitrogen	79.70	79.70	79.70
Isokinetic variation (%)	97.9	94.2	100.3
Particulate concentration			
actual (GR/ACF)	.001214	.001679	.000747
standard (GR/DSCF)	.002261	.003154	.001412
Part. emission rate (LB/HR)	2.00	2.69	1.22

Note: Dry Catch Only

Table 6a Summary of the Results of the July 24, 1996 Particulate Emission Compliance Test of the Press RTO Stack at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-24-96	07-24-96	07-24-96
Time runs were done (HRS)	1835/1936	2005/2108	2137/2237
Process rate			
Volumetric flow (ACFM) actual	109804	110107	111185
standard (DSCFM)	73214	73818	74439
Gas temperature (DEG-F)	259	257	255
Moisture content (%V/V)	3.92	3.67	4.07
Gas composition (%V/V, dry)			
carbon dioxide	0.03	0.03	0.03
oxygen	20.90	20.90	20.90
nitrogen	79.07	79.07	79.07
Isokinetic variation (%)	96.6	100.0	100.5
Particulate concentration (GR/ACF) actual	.008852	.0182	.002554
standard (GR/DSCF)	.0133	.0272	.003816
Part. emission rate (LB/HR)	8.33	17.23	2.43

Note: Dry + Method 202 Condensible Particulate Material

Table 6b Summary of the Results of the July 24, 1996 Particulate Emission Compliance Test of the Press RTO Stack at the Louisiana Pacific Plant in Sagola, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	07-24-96	07-24-96	07-24-96
Time runs were done (HRS)	1835/1936	2005/2108	2137/2237
Process rate			
Volumetric flow (ACFM) actual	109804	110107	111185
standard (DSCFM)	73214	73818	74439
Gas temperature (DEG-F)	259	257	255
Moisture content (%V/V)	3.92	3.67	4.07
Gas composition (%V/V, dry)			
carbon dioxide	0.03	0.03	0.03
oxygen	20.90	20.90	20.90
nitrogen	79.07	79.07	79.07
Isokinetic variation (%)	96.6	100.0	100.5
particulate concentration			
actual (GR/ACF)	.002736	.000857	.001076
standard (GR/DSCF)	.004105	.001278	.001608
Part. emission rate (LB/HR)	2.58	0.809	1.03

Note: Dry Catch Only

Table 7.

Summary of the Results of the July 23 - 25, 1996 Oxides of Nitrogen Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppm.d)	Emission Rate (LB/HR)
Primary Cyclone Exhaust 1			
7-23-96	1130-1330	40	7.8
7-23-96	1436-1543	36	6.9
7-23-96	1645-1751	34	6.7
Avg		37	7.1
Primary Cyclone Exhaust 2			
7-23-96	1134-1330	36	7.1
7-23-96	1435-1542	34	6.9
7-23-96	1645-1750	35	7.4
Avg		35	7.1
Primary Cyclone Exhaust 3			
7-23-96	1133-1328	65	11.7
7-23-96	1435-1529	45	9.0
7-23-96	1645-1736	32	6.2
Avg		47	9.0
E-Tube Outlet			
7-23-96	1435-1535	3.2	2.4
7-23-96	1645-1745	2.4	1.8
7-23-96	1925-2025	1.7	1.3
Avg		2.4	1.8
Dryer RTO Stack			
7-23-96	1435-1535	2.5	1.8
7-23-96	1645-1745	2.8	2.0
7-23-96	1925-2025	3.2	2.3
Avg		2.8	2.0
Press Inlet			
7-25-96	1620-1720	8.2	3.8
7-25-96	1800-1900	7.6	3.8
7-25-96	1934-2034	6.2	3.2
Avg		7.3	3.6
Press Stack			
7-25-96	1620-1720	36.3	20.3
7-25-96	1800-1900	34.3	18.7
7-25-96	1934-2034	34.9	19.3
Avg		35.2	19.4

Table 8.

Summary of the Results of the July 23 - 25, 1996 Carbon Monoxide Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppm.d)	Emission Rate (LB/HR)
Primary Cyclone Exhaust 1			
7-23-96	1130-1330	1822	214
7-23-96	1436-1543	1794	210
7-23-96	1645-1751	1778	210
Avg		1798	211
Primary Cyclone Exhaust 2			
7-23-96	1134-1330	1590	194
7-23-96	1435-1542	1902	235
7-23-96	1645-1750	2214	289
Avg		1902	239
Primary Cyclone Exhaust 3			
7-23-96	1133-1328	1756	194
7-23-96	1435-1529	1770	216
7-23-96	1645-1736	1706	203
Avg		1744	204
E-Tube Outlet			
7-23-96	1435-1535	1817	818
7-23-96	1645-1745	1841	828
7-23-96	1925-2025	1851	833
Avg		1836	826
Dryer RTO Stack			
7-23-96	1435-1535	212	92
7-23-96	1645-1745	234	102
7-23-96	1925-2025	241	106
Avg		229	100
Press Inlet			
7-25-96	1620-1720	5.0	1.4
7-25-96	1800-1900	5.3	1.6
7-25-96	1934-2034	4.4	1.6
Avg		4.9	1.5
Press Stack			
7-25-96	1620-1720	19.2	6.5
7-25-96	1800-1900	24.2	8.0
7-25-96	1934-2034	20.8	7.0
Avg		21.4	7.2

Table 9. Summary of the Results of the July 23 - 25, 1996 Total Hydrocarbons Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppmC,w)	Emission Rate (LBC/HR)
Primary Cyclone Exhaust 1			
7-23-96	1435-1535	1937	129
7-23-96	1645-1745	1796	120
7-23-96	1925-2025	1677	112
Avg		1803	121
Primary Cyclone Exhaust 2			
7-23-96	1435-1535	2165	153
7-23-96	1645-1745	2125	153
7-23-96	1925-2025	1840	133
Avg		2043	146
Primary Cyclone Exhaust 3			
7-23-96	1435-1535	3498	237
7-23-96	1645-1745	2595	167
7-23-96	1925-2025	3474	223
Avg		3189	209
Dryer RTO Stack			
7-23-96	1435-1535	24.5	5.9
7-23-96	1645-1745	8.0	2.0
7-23-96	1925-2025	18.8	4.6
Avg		17.1 59.9	4.2 14.6
Press Inlet			
7-25-96	1620-1720	705	88
7-25-96	1800-1900	764	101
7-25-96	1934-2034	744	104
Avg		738	98
Press Stack			
7-25-96	1620-1720	11.9	1.8
7-25-96	1800-1900	19.4	2.9
7-25-96	1934-2034	6.8	1.0
Avg		12.7	1.9

Table 10. Summary of the Results of the July 24 & 25, 1996 Formaldehyde Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
Primary Cyclone Exhaust 1			
7-24-96	1710-1828	12	1.5
7-24-96	1915-2020	13	1.7
7-24-96	2040-2144	15	1.7
Avg		13	1.6
Primary Cyclone Exhaust 2			
7-24-96	1710-1830	12	1.6
7-24-96	1915-2017	14	1.8
7-24-96	2040-2142	13	1.8
Avg		13	1.7
Primary Cyclone Exhaust 3			
7-24-96	1710-1828	14	1.8
7-24-96	1915-2015	14	1.7
7-24-96	2040-2140	8	1.0
Avg		12	1.5
Dryer RTO Outlet			
7-24-96	1710-1830	1.8	0.9
7-24-96	1915-2025	2.7	1.3
7-24-96	2040-2142	2.9	1.3
Avg		2.5	1.2
Press Inlet			
7-25-96	0937-1039	6.0	2.0
7-25-96	1235-1335	6.1	1.9
7-25-96	1410-1512	6.8	2.2
Avg		6.3	2.0
Press Stack			
7-25-96	0937-1039	0.16	0.057
7-25-96	1235-1335	0.16	0.055
7-25-96	1410-1512	0.15	0.055
Avg		0.16	0.056

Table 11. Summary of the Results of the July 25, 1996 **Phenol** Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppm.d)	Emission Rate (LB/HR)
Press RTO Inlet			
7-25-96	1620-1720	< 0.18	< 0.17
7-25-96	1800-1900	< 0.17	< 0.17
7-25-96	1935-2035	< 0.17	< 0.18
Avg		< 0.17	< 0.17
Press RTO Stack			
7-25-95	1620-1720	< 0.17	< 0.20
7-25-95	1800-1900	< 0.17	< 0.19
7-25-95	1935-2035	< 0.17	< 0.20
Avg		< 0.17	< 0.20

Table 12. Summary of the Results of the July 25, 1996 MDI Emission Compliance Tests at the Louisiana Pacific Plant in Sagola, Michigan.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
Press RTO Stack			
7-25-96	1620-1720	< 0.0008	< 0.0024
7-25-96	1800-1900	< 0.0008	< 0.0024
7-25-96	1935-2035	< 0.0008	< 0.0024
Avg		< 0.0008	< 0.0024

3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Orsat (gas composition) and moisture is presented first followed by the computer printout of the particulate, oxides of nitrogen, opacity, carbon monoxide, total hydrocarbons, formaldehyde, phenol, and MDI results. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in Extended BASIC specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The emission rates have been calculated using the product of the concentration times flow method.

3.1 Results of Orsat and Moisture Determinations

Test No. 1
 Dryer Primary Cyclone Exhaust 1 PM

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-23-96	Run 2 07-23-96	Run 3 07-23-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.00	3.40	3.70
oxygen.....	17.60	17.10	16.80
nitrogen.....	79.40	79.50	79.50

Wet basis (orsat)

carbon dioxide.....	2.32	2.55	2.80
oxygen.....	13.63	12.85	12.73
nitrogen.....	61.51	59.74	60.22
water vapor.....	22.53	24.86	24.25
Dry molecular weight.....	29.18	29.23	29.26
Wet molecular weight.....	26.66	26.44	26.53
Specific gravity.....	0.921	0.913	0.916
Water mass flow.....(LB/HR)	22015	24900	24372

FO	1.100	1.118	1.108
----	-------	-------	-------

Test No. 1
 Dryer Primary Cyclone Exhaust 2 *PM*

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-23-96	Run 2 07-23-96	Run 3 07-23-96
Dry basis (orsat)			
carbon dioxide.....	3.20	3.80	3.20
oxygen.....	17.20	16.90	17.20
nitrogen.....	79.60	79.30	79.60
Wet basis (orsat)			
carbon dioxide.....	2.40	2.84	2.48
oxygen.....	12.89	12.65	13.35
nitrogen.....	59.67	59.37	61.77
water vapor.....	25.03	25.14	22.40
Dry molecular weight.....	29.20	29.28	29.20
Wet molecular weight.....	26.40	26.45	26.69
Specific gravity.....	0.912	0.914	0.922
Water mass flow.....(LB/HR)	26218	26632	24264
FO	1.156	1.053	1.156

Test No. 1
Dryer Primary Cylcone Exhaust 3 *PK*

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96

Dry basis (orsat)

carbon dioxide.....	3.10	3.70	3.10
oxygen.....	17.50	16.80	17.40
carbon monoxide.....	0.00	0.00	0.00
nitrogen.....	79.40	79.50	79.50

Wet basis (orsat)

carbon dioxide.....	2.27	2.86	2.46
oxygen.....	12.83	12.99	13.78
carbon monoxide.....	0.00	0.00	0.00
nitrogen.....	58.21	61.48	62.97
water vapor.....	26.69	22.66	20.79
Dry molecular weight.....	29.20	29.26	29.19
Wet molecular weight.....	26.21	26.71	26.87
Specific gravity.....	0.905	0.923	0.928
Water mass flow.....(LB/HR)	25899	22991	20046

FO

1.097

1.108

1.129

Test No. 1
E Tube Outlet *PM*

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-23-96	Run 2 07-23-96	Run 3 07-23-96
Dry basis (orsat)			
carbon dioxide.....	2.80	2.90	2.90
oxygen.....	17.80	17.70	17.60
nitrogen.....	79.40	79.40	79.50
Wet basis (orsat)			
carbon dioxide.....	2.17	2.24	2.22
oxygen.....	13.76	13.70	13.48
nitrogen.....	61.39	61.45	60.89
water vapor.....	22.68	22.60	23.41
Dry molecular weight.....	29.16	29.17	29.17
Wet molecular weight.....	26.63	26.65	26.55
Specific gravity.....	0.920	0.920	0.917
Water mass flow.....(LB/HR)	85089	84570	88459
FO	1.107	1.103	1.138

Test No. 1
 Dryer RTO Stack *PM*

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-23-96	Run 2 07-23-96	Run 3 07-23-96
Dry basis (orsat)			
carbon dioxide.....	3.00	3.00	3.00
oxygen.....	17.30	17.30	17.30
nitrogen.....	79.70	79.70	79.70
Wet basis (orsat)			
carbon dioxide.....	2.32	2.31	2.29
oxygen.....	13.40	13.33	13.23
nitrogen.....	61.73	61.42	60.95
water vapor.....	22.55	22.94	23.53
Dry molecular weight.....	29.17	29.17	29.17
Wet molecular weight.....	26.65	26.61	26.54
Specific gravity.....	0.921	0.919	0.917
Water mass flow.....(LB/HR)	84217	83132	86652
FO	1.200	1.200	1.200

Test No. 7
Press RTO Stack *PM*

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-24-96	Run 2 07-24-96	Run 3 07-24-96
Dry basis (orsat)			
carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07
Wet basis (orsat)			
carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.08	20.13	20.05
nitrogen.....	75.97	76.17	75.85
water vapor.....	3.92	3.67	4.07
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.42	28.44	28.40
Specific gravity.....	0.982	0.982	0.981
Water mass flow.....(LB/HR)	8377	7885	8853

Test No. 4
 Dryer Primary Cyclone Exhaust 1 Form

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-24-96	Run 2 07-24-96	Run 3 07-24-96
Dry basis (orsat)			
carbon dioxide.....	3.20	3.20	3.30
oxygen.....	17.20	17.20	17.00
nitrogen.....	79.60	79.60	79.70
Wet basis (orsat)			
carbon dioxide.....	2.52	2.48	2.55
oxygen.....	13.55	13.36	13.13
nitrogen.....	62.69	61.81	61.54
water vapor.....	21.24	22.34	22.78
Dry molecular weight.....	29.20	29.20	29.21
Wet molecular weight.....	26.82	26.70	26.65
Specific gravity.....	0.926	0.922	0.921
Water mass flow.....(LB/HR)	0.00	0.00	0.00
FO	1.156	1.156	1.182

Test No. 4
Dryer Primary Cyclone Exhaust 2 *FORM*

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	07-24-96	07-24-96	07-24-96

Dry basis (orsat)

carbon dioxide.....	3.40	3.80	3.10
oxygen.....	17.10	16.80	16.80
nitrogen.....	79.50	79.40	80.10

Wet basis (orsat)

carbon dioxide.....	2.73	2.87	2.44
oxygen.....	13.73	12.68	13.24
nitrogen.....	63.85	59.92	63.15
water vapor.....	19.69	24.53	21.17

Dry molecular weight.....	29.23	29.28	29.17
Wet molecular weight.....	27.02	26.51	26.80
Specific gravity.....	0.933	0.916	0.926
Water mass flow.....(LB/HR)	0.00	0.00	0.00

FO	1.118	1.079	1.323
----	-------	-------	-------

Test No. 4
Dryer Primary Cyclone Exhaust 3

Edran

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-24-96	Run 2 07-24-96	Run 3 07-24-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.50	3.20	3.80
oxygen.....	17.00	17.00	16.50
nitrogen.....	79.50	79.80	79.70

Wet basis (orsat)

carbon dioxide.....	2.72	2.42	2.88
oxygen.....	13.20	12.87	12.49
nitrogen.....	61.72	60.39	60.32
water vapor.....	22.36	24.32	24.32
Dry molecular weight.....	29.24	29.19	29.27
Wet molecular weight.....	26.73	26.47	26.53
Specific gravity.....	0.923	0.914	0.916
Water mass flow.....(LB/HR)	0.00	0.00	0.00

FO	1.114	1.219	1.158
----	-------	-------	-------

Test No. 4
 Dryer RTO Stack

FORM

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-24-96	Run 2 07-24-96	Run 3 07-24-96
Dry basis (orsat)			
carbon dioxide.....	2.50	3.20	2.90
oxygen.....	18.20	17.30	17.60
nitrogen.....	79.30	79.50	79.50
Wet basis (orsat)			
carbon dioxide.....	2.01	2.47	2.20
oxygen.....	14.65	13.33	13.38
nitrogen.....	63.83	61.27	60.43
water vapor.....	19.51	22.94	23.99
Dry molecular weight.....	29.13	29.20	29.17
Wet molecular weight.....	26.96	26.63	26.49
Specific gravity.....	0.931	0.920	0.915
Water mass flow.....(LB/HR)	0.00	0.00	0.00
FO	1.080	1.125	1.138

Test No. 9 *FORM*
 Press Inlet

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-25-96	Run 2 07-25-96	Run 3 07-25-96
Dry basis (orsat)			
carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07
Wet basis (orsat)			
carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.28	20.42	20.31
nitrogen.....	76.74	77.27	76.86
water vapor.....	2.95	2.27	2.80
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.52	28.59	28.54
Specific gravity.....	0.985	0.988	0.986
Water mass flow.....(LB/HR)	0.00	0.00	0.00

Test No. 9 *Edm.*
 Press Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-25-96	Run 2 07-25-96	Run 3 07-25-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07

Wet basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.31	20.41	20.29
nitrogen.....	76.82	77.22	76.76
water vapor.....	2.84	2.34	2.92
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.53	28.59	28.52
Specific gravity.....	0.986	0.987	0.985
Water mass flow.....(LB/HR)	0.00	0.00	0.00

3.2 Results of Particulate Determinations

Test No. 1
Dryer Primary Cyclone Exhaust 1

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1130/1330	1436/1543	1645/1751
Static pressure.....(IN.WC)	-9.00	-9.00	-9.00
Cross sectional area (SQ.FT)	8.73	8.73	8.73
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	207.0	233.0	242.0
desiccant.....(GRAMS)	23.0	37.0	18.0
total.....(GRAMS)	230.0	270.0	260.0
Total particulate material..			
.....collected(grams)	0.6769	0.8255	0.8985
Gas meter coefficient.....	1.0024	1.0024	1.0024
Barometric pressure..(IN.HG)	28.33	28.33	28.33
Avg. orif.pres.drop..(IN.WC)	1.21	1.30	1.28
Avg. gas meter temp..(DEF-F)	85.5	89.8	88.5
Volume through gas meter....			
at meter conditions...(CF)	40.47	42.10	41.79
standard conditions.(DSCF)	37.28	38.49	38.29
Total sampling time...(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.189	.189	.189
Avg.stack gas temp ..(DEG-F)	223	224	223
Volumetric flow rate.....			
actual.....(ACFM)	48712	50015	50083
dry standard.....(DSCFM)	26981	26838	27141
Isokinetic variation.....(%)	96.8	100.4	98.8
Particulate concentration...			
actual.....(GR/ACF)	0.15512	0.17752	0.19612
dry standard.....(GR/DSCF)	0.28016	0.33095	0.36204
Particle mass rate...(LB/HR)	64.791	76.131	84.224

Test No. 1
Dryer Primary Cyclone Exhaust 2

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1134/1330	1435/1542	1645/1750
Static pressure.....(IN.WC)	-8.60	-8.60	-8.60
Cross sectional area (SQ.FT)	9.39	9.39	9.39
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	211.0	211.0	189.0
desiccant.....(GRAMS)	10.0	14.0	13.0
total.....(GRAMS)	221.0	225.0	202.0
Total particulate material..			
.....collected(grams)	0.5011	0.4663	0.5339
Gas meter coefficient.....	1.0056	1.0056	1.0056
Barometric pressure..(IN.HG)	28.33	28.33	28.33
Avg. orif.pres.drop..(IN.WC)	0.94	0.99	1.04
Avg. gas meter temp..(DEF-F)	94.7	97.7	86.7
Volume through gas meter....			
at meter conditions...(CF)	34.36	34.97	35.80
standard conditions.(DSCF)	31.20	31.60	33.00
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.179	.179	.179
Avg.stack gas temp ..(DEG-F)	205	205	211
Volumetric flow rate.....			
actual.....(ACFM)	50773	51371	52976
dry standard.....(DSCFM)	27990	28278	29969
Isokinetic variation.....(%)	99.9	100.2	98.7
Particulate concentration...			
actual.....(GR/ACF)	0.13654	0.12530	0.14118
dry standard.....(GR/DSCF)	0.24778	0.22771	0.24966
Particle mass rate...(LB/HR)	59.447	55.194	64.131

Test No. 1
Dryer Primary Cylcone Exhaust 3

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1133/1328	1435/1529	1645/1736
Static pressure.....(IN.WC)	-9.00	-9.00	-9.00
Cross sectional area (SQ.FT)	8.73	8.73	8.73
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	238.0	152.0	135.0
desiccant.....(GRAMS)	27.0	24.0	12.0
total.....(GRAMS)	265.0	176.0	147.0
Total particulate material..			
.....collected(grams)	0.5884	0.6083	0.5341
Gas meter coefficient.....	1.0032	1.0032	1.0032
Barometric pressure..(IN.HG)	28.33	28.33	28.33
Avg. orif.pres.drop..(IN.WC)	1.12	1.22	1.16
Avg. gas meter temp..(DEF-F)	92.1	93.7	90.0
Volume through gas meter....			
at meter conditions...(CF)	37.68	31.18	28.89
standard conditions.(DSCF)	34.32	28.32	26.41
Total sampling time....(MIN)	60.00	47.50	45.00
Nozzle diameter.....(IN)	.189	.189	.189
Avg.stack gas temp ..(DEG-F)	214	214	213
Volumetric flow rate.....			
actual.....(ACFM)	47773	49892	47420
dry standard.....(DSCFM)	25358	27973	27234
Isokinetic variation.....(%)	101.1	95.5	96.6
Particulate concentration...			
actual.....(GR/ACF)	0.14038	0.18574	0.17912
dry standard.....(GR/DSCF)	0.26458	0.33142	0.31201
Particle mass rate...(LB/HR)	57.51	79.46	72.83

Test No. 1
E Tube Outlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1133/1326	1435/1539	1645/1748
Static pressure.....(IN.WC)	-1.83	-1.83	-1.83
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	190.0	194.0	210.0
desiccant.....(GRAMS)	11.0	13.0	9.0
total.....(GRAMS)	201.0	207.0	219.0
Total particulate material..			
.....collected(grams)	0.0872	0.0827	0.0994
Gas meter coefficient.....	0.9973	0.9973	0.9973
Barometric pressure..(IN.HG)	28.35	28.35	28.35
Avg. orif.pres.drop..(IN.WC)	1.09	1.17	1.19
Avg. gas meter temp..(DEF-F)	82.8	90.0	89.2
Volume through gas meter....			
at meter conditions...(CF)	35.07	36.74	37.08
standard conditions.(DSCF)	32.31	33.42	33.78
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.188	.188	.188
Avg.stack gas temp ..(DEG-F)	157	162	161
Volumetric flow rate.....			
actual.....(ACFM)	165860	166648	167899
dry standard.....(DSCFM)	103433	103228	103158
Isokinetic variation.....(%)	97.9	101.5	102.6
Particulate concentration...			
actual.....(GR/ACF)	0.02596	0.02364	0.02789
dry standard.....(GR/DSCF)	0.04164	0.03819	0.04541
Particle mass rate...(LB/HR)	36.914	33.787	40.150

Test No. 1
Dryer RTO Stack

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1132/1331	1435/1540	1645/1751
Static pressure.....(IN.WC)	-0.54	-0.54	-0.54
Cross sectional area (SQ.FT)	50.79	50.79	50.79
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	242.0	239.0	262.0
desiccant.....(GRAMS)	15.0	5.0	9.0
total.....(GRAMS)	257.0	244.0	271.0
Total particulate material..			
.....collected(grams)	0.0157	0.0194	0.0148
Gas meter coefficient.....	0.9964	0.9964	0.9964
Barometric pressure..(IN.HG)	28.35	28.35	28.35
Avg. orif.pres.drop..(IN.WC)	1.48	1.27	1.47
Avg. gas meter temp..(DEF-F)	84.3	88.6	90.9
Volume through gas meter....			
at meter conditions...(CF)	45.30	42.41	45.74
standard conditions.(DSCF)	41.63	38.65	41.53
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.245	.245	.245
Avg.stack gas temp ..(DEG-F)	261	263	262
Volumetric flow rate.....			
actual.....(ACFM)	192090	186922	189616
dry standard.....(DSCFM)	103148	99560	100405
Isokinetic variation.....(%)	97.9	94.2	100.3
Particulate concentration...			
actual.....(GR/ACFM)	0.00312	0.00412	0.00291
dry standard.....(GR/DSCFM)	0.00582	0.00775	0.00550
Particle mass rate...(LB/HR)	5.145	6.610	4.732

Test No. 7
Press RTO Stack

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-24-96	07-24-96	07-24-96
Time run start/end.....(HRS)	1835/1936	2005/2108	2137/2237
Static pressure.....(IN.WC)	-0.27	-0.27	-0.27
Cross sectional area (SQ.FT)	31.50	31.50	31.50
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	25.0	27.0	31.0
desiccant.....(GRAMS)	15.0	12.0	13.0
total.....(GRAMS)	40.0	39.0	44.0
Total particulate material..			
.....collected(grams)	0.0398	0.0852	0.0121
Gas meter coefficient.....	0.9973	0.9973	0.9973
Barometric pressure..(IN.HG)	28.31	28.31	28.31
Avg. orif.pres.drop..(IN.WC)	2.23	2.46	2.53
Avg. gas meter temp..(DEF-F)	88.3	95.1	96.0
Volume through gas meter....			
at meter conditions...(CF)	50.61	53.48	54.27
standard conditions.(DSCF)	46.24	48.29	48.93
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.251	.251	.251
Avg.stack gas temp ..(DEG-F)	259	257	255
Volumetric flow rate.....			
actual.....(ACFM)	109804	110107	111185
dry standard.....(DSCFM)	73214	73818	74439
Isokinetic variation.....(%)	96.6	100.0	100.5
Particulate concentration...			
actual.....(GR/ACF)	0.00885	0.01824	0.00255
dry standard.....(GR/DSCF)	0.01328	0.02722	0.00382
Particle mass rate...(LB/HR)	8.335	17.225	2.435

3.3 Results of Oxides of Nitrogen Determinations

Test No. 1
Dryer Primary Cyclone Exhaust 1

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 1A	Run 1B	Run 1C	Run 1D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1130	1145	1215	1325
Flask number.....	1	2	3	4
Volume of flask.....(ML)	2086	2063	2055	2116
Data: time of sampling				
flask temperature..(DEG-F)	102.00	106.00	108.00	110.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.38	26.38	26.38	26.35
flask abs. press...(IN.HG)	1.95	1.95	1.95	1.98
Data: Time of Flask Opening				
flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-0.70	-0.50	-0.50	-0.90
flask abs. press...(IN.HG)	28.40	28.60	28.60	28.20
Volume gas sampled....(DSML)	1815	1809	1802	1827
Moisture content.....(%V/V)	22.53	22.53	22.53	22.53
Nitrate in gas sample...(JG)	190.0	190.0	190.0	180.0
NO2 in gas sample.....(JG)	141.0	141.0	141.0	133.6
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0339	0.0341	0.0342	0.0319
(MG/DSCM).....	78	78	78	73
(PPM-DRY).....	41	41	41	38
(PPM-WET).....	31	32	32	30
NOX Emission rate....(LB/HR)	7.85	7.88	7.91	7.39

Test No. 1
Dryer Primary Cyclone Exhaust 1

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 2A	Run 2B	Run 2C	Run 2D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1436	1445	1515	1540
Flask number.....	5	6	19	20
Volume of flask.....(ML)	2057	2100	2069	2060

Data: time of sampling

flask temperature..(DEG-F)	110.00	108.00	110.00	110.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.15	26.10	26.80	26.40
flask abs. press...(IN.HG)	2.18	2.23	1.53	1.93

Data: Time of Flask Opening

flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press...(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-0.10	-0.60	-0.90	-0.40
flask abs. press...(IN.HG)	29.00	28.50	28.20	28.70
Volume gas sampled....(DSML)	1817	1817	1814	1815
Moisture content.....(%V/V)	24.86	24.86	24.86	24.86
Nitrate in gas sample...(JG)	190.0	180.0	150.0	150.0
NO2 in gas sample.....(JG)	141.0	133.6	111.3	111.3

NOx Concentration

(GR/DSCF).....	0.0339	0.0321	0.0268	0.0268
(MG/DSCM).....	78	73	61	61
(PPM-DRY).....	41	38	32	32
(PPM-WET).....	30	29	24	24
NOX Emission rate....(LB/HR)	7.80	7.39	6.17	6.16

Test No. 1
Dryer Primary Cyclone Exhaust 1

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 3A	Run 3B	Run 3C	Run 3D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1650	1710	1730	1745
Flask number.....	21	22	23	24
Volume of flask.....(ML)	2068	2031	2056	2031

Data: time of sampling

flask temperature..(DEG-F)	110.00	109.00	109.00	108.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.40	26.30	26.40	26.40
flask abs. press...(IN.HG)	1.93	2.03	1.93	1.93

Data: Time of Flask Opening

flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-1.60	0.10	-0.85	-0.05
flask abs. press...(IN.HG)	27.50	29.20	28.25	29.05
Volume gas sampled....(DSML)	1741	1816	1781	1812
Moisture content.....(%V/V)	24.25	24.25	24.25	24.25
Nitrate in gas sample...(JG)	160.0	150.0	160.0	160.0
NO2 in gas sample.....(JG)	118.7	111.3	118.7	118.7

NOx Concentration

(GR/DSCF).....	0.0298	0.0268	0.0291	0.0286
(MG/DSCM).....	68	61	67	66
(PPM-DRY).....	36	32	35	34
(PPM-WET).....	27	24	26	26
NOX Emission rate....(LB/HR)	6.93	6.23	6.78	6.66

Test No. 1
Dryer Primary Cyclone Exhaust 2

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 1A	Run 1B	Run 1C	Run 1D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1234	1245	1305	1319
Flask number.....	55	56	57	58
Volume of flask.....(ML)	2086	2069	2062	2085
Data: time of sampling				
flask temperature..(DEG-F)	91.00	92.00	94.00	95.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.02	25.95	26.03	25.92
flask abs. press...(IN.HG)	2.31	2.38	2.30	2.41
Data: Time of Flask Opening				
flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-4.20	-0.20	0.10	-0.80
flask abs. press...(IN.HG)	24.90	28.90	29.20	28.30
Volume gas sampled....(DSML)	1549	1803	1823	1775
Moisture content.....(%V/V)	25.03	25.03	25.03	25.03
Nitrate in gas sample...(JG)	170.0	180.0	160.0	120.0
NO2 in gas sample.....(JG)	126.1	133.6	118.7	89.0
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0356	0.0324	0.0285	0.0219
(MG/DSCM).....	81	74	65	50
(PPM-DRY).....	43	39	34	26
(PPM-WET).....	32	29	26	20
NOX Emission rate....(LB/HR)	8.54	7.77	6.83	5.26

Test No. 1
Dryer Primary Cyclone Exhaust 2

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 2A	Run 2B	Run 2C	Run 2D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1438	1454	1509	1530
Flask number.....	59	60	43	44
Volume of flask.....(ML)	2077	2066	2088	2090

Data: time of sampling

flask temperature..(DEG-F)	97.00	97.00	97.00	98.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	25.92	26.12	25.95	25.99
flask abs. press...(IN.HG)	2.41	2.21	2.38	2.34

Data: Time of Flask Opening

flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-0.05	-1.00	-4.20	-4.10
flask abs. press...(IN.HG)	29.05	28.10	24.90	25.00
Volume gas sampled....(DSML)	1820	1759	1548	1559
Moisture content.....(%V/V)	25.14	25.14	25.14	25.14
Nitrate in gas sample...(JG)	120.0	140.0	140.0	180.0
NO2 in gas sample.....(JG)	89.0	103.9	103.9	133.6

NOx Concentration

(GR/DSCF).....	0.0214	0.0258	0.0293	0.0374
(MG/DSCM).....	49	59	67	86
(PPM-DRY).....	26	31	35	45
(PPM-WET).....	19	23	26	34
NOX Emission rate....(LB/HR)	5.18	6.26	7.11	9.07

Test No. 1
Dryer Primary Cyclone Exhaust 2

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 3A	Run 3B	Run 3C	Run 3D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1650	1704	1729	1750
Flask number.....	45	46	47	48
Volume of flask.....(ML)	2086	2090	2074	2102
Data: time of sampling				
flask temperature..(DEG-F)	96.00	96.00	97.00	97.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.12	26.11	25.88	26.11
flask abs. press...(IN.HG)	2.21	2.22	2.45	2.22
Data: Time of Flask Opening				
flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-4.30	-4.00	-0.50	-3.20
flask abs. press...(IN.HG)	24.80	25.10	28.60	25.90
Volume gas sampled....(DSML)	1550	1573	1784	1638
Moisture content.....(%V/V)	22.40	22.40	22.40	22.40
Nitrate in gas sample...(JG)	130.0	140.0	160.0	150.0
NO2 in gas sample.....(JG)	96.5	103.9	118.7	111.3
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0272	0.0289	0.0291	0.0297
(MG/DSCM).....	62	66	67	68
(PPM-DRY).....	33	35	35	36
(PPM-WET).....	25	27	27	28
NOX Emission rate....(LB/HR)	6.98	7.41	7.47	7.63

Test No. 1
Dryer Primary Cyclone Exhaust 3

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 1A	Run 1B	Run 1C	Run 1D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1133	1250	1305	1325
Flask number.....	25	26	27	28
Volume of flask.....(ML)	2100	2035	2054	2031
Data: time of sampling				
flask temperature..(DEG-F)	102.00	102.00	103.00	103.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.06	26.03	25.59	25.82
flask abs. press...(IN.HG)	2.27	2.30	2.74	2.51
Data: Time of Flask Opening				
flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-2.40	-2.00	-2.30	-2.20
flask abs. press...(IN.HG)	26.70	27.10	26.80	26.90
Volume gas sampled....(DSML)	1689	1661	1629	1631
Moisture content.....(%V/V)	26.69	26.69	26.69	26.69
Nitrate in gas sample...(JG)	300.0	270.0	260.0	270.0
NO2 in gas sample.....(JG)	222.6	200.3	192.9	200.3
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0576	0.0527	0.0518	0.0537
(MG/DSCM).....	132	121	118	123
(PPM-DRY).....	69	63	62	64
(PPM-WET).....	51	46	45	47
NOX Emission rate....(LB/HR)	12.52	11.46	11.25	11.66

Test No. 1
Dryer Primary Cyclone Exhaust 3

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 2A	Run 2B	Run 2C	Run 2D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1435	1450	1505	1528
Flask number.....	29	30	37	38
Volume of flask.....(ML)	2068	2071	2054	2056
Data: time of sampling				
flask temperature..(DEG-F)	103.00	103.00	90.00	90.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	25.91	25.60	25.39	26.20
flask abs. press...(IN.HG)	2.42	2.73	2.94	2.13
Data: Time of Flask Opening				
flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-2.00	-2.40	-1.20	-2.85
flask abs. press...(IN.HG)	27.10	26.70	27.90	26.25
Volume gas sampled....(DSML)	1681	1636	1686	1629
Moisture content.....(%V/V)	22.66	22.66	22.66	22.66
Nitrate in gas sample...(JG)	250.0	230.0	150.0	140.0
NO2 in gas sample.....(JG)	185.5	170.7	111.3	103.9
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0482	0.0456	0.0289	0.0279
(MG/DSCM).....	110	104	66	64
(PPM-DRY).....	58	55	35	33
(PPM-WET).....	45	42	27	26
NOX Emission rate....(LB/HR)	11.56	10.93	6.92	6.68

Test No. 1
Dryer Primary Cyclone Exhaust 3

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 3A	Run 3B	Run 3C	Run 3D
Date of run.....	07-23-96	07-23-96	07-23-96	07-23-96
Time of run.....(HRS)	1645	1700	1715	1730
Flask number.....	39	40	41	42
Volume of flask.....(ML)	2062	2093	2076	2094
Data: time of sampling				
flask temperature..(DEG-F)	95.00	95.00	95.00	95.00
bar. press.....(IN.HG)	28.33	28.33	28.33	28.33
flask vacuum.....(IN.HG)	26.00	25.82	25.87	25.54
flask abs. press...(IN.HG)	2.33	2.51	2.46	2.79
Data: Time of Flask Opening				
flask temperature..(DEG-F)	72.00	72.00	72.00	72.00
lab. bar. press....(IN.HG)	29.10	29.10	29.10	29.10
flask static press.(IN.HG)	-0.70	-0.10	-0.50	-0.30
flask abs. press...(IN.HG)	28.40	29.00	28.60	28.80
Volume gas sampled....(DSML)	1767	1824	1785	1792
Moisture content.....(%V/V)	18.75	18.75	18.75	18.75
Nitrate in gas sample...(JG)	130.0	160.0	140.0	160.0
NO2 in gas sample.....(JG)	96.5	118.7	103.9	118.7
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0239	0.0284	0.0254	0.0289
(MG/DSCM).....	55	65	58	66
(PPM-DRY).....	29	34	30	35
(PPM-WET).....	23	28	25	28
NOX Emission rate....(LB/HR)	5.57	6.64	5.94	6.76

Test No. 2
 E-Tube Outlet

Results of Oxides of Nitrogen Determinations Method 7E

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.6	23.4	23.4
Oxygen content (%V/V)	17.7	17.6	17.6
Volumetric flow rate (DSCFM)	103228	103158	103160
NO_x concentration ppm,dry	3.2	2.4	1.7
NO_x emission rate (LB/HR)	2.4	1.8	1.3

Test No. 2
Dryer RTO Stack

Results of Oxides of Nitrogen Determinations Method 7E

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.9	23.5	23.5
Oxygen content (%V/V)	17.3	17.3	17.3
Volumetric flow rate (DSCFM)	99560	100405	100405
NO_x concentration			
ppm,dry	2.5	2.8	3.2
NO_x emission rate (LB/HR)	1.8	2.0	2.3

Test No. 8
Press RTO Inlet

Results of Oxides of Nitrogen Determinations Method 7E

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	3.9	2.9	3.0
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	64300	68979	72300
NO_x concentration ppm,dry	8.2	7.6	6.2
NO_x emission rate (LB/HR)	3.8	3.8	3.2

Test No. 8
Press RTO Stack

Results of Oxides of Nitrogen Determinations Method 7E

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	2.9	3.3	3.4
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	77990	76250	77090
NO _x concentration ppm,dry	36.3	34.3	34.9
NO _x emission rate (LB/HR)	20.3	18.7	19.3

3.4 Results of Opacity Observations

Test No. 1
E-Tube Outlet

Results of the Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	
5	0.0223	
10	0.0458	
15	0.0706	
20	0.0969	
25	0.1249	
30	0.1549	
35	0.1871	
40	0.2219	
45	0.2596	
50	0.3010	
55	0.3468	
60	0.3979	
65	0.4559	
70	0.5229	
75	0.6021	
80	0.6690	
85	0.8239	
90	1.0000	
95	1.3010	
99	2.0000	
Average Opacity	Avg OD	Time Average

* Note: Opacity observations were unable to be performed due to inclement weather conditions.

Observer: Mark Petersen
Cert. Date: 04-03-96
Date of Observation: 7-23-96
Time of Observation: -

Test No. 9
Press RTO Stack

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	100.00
5	0.0223	0.00
10	0.0458	0.00
15	0.0706	0.00
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac 0.00	Avg OD 0.0000	Time average

Observer: Mark Petersen
Cert. Date: 04-03-96
Date of Observation: 07-25-96
Time of Observation: 0937-1037

3.5 Results of Carbon Monoxide Determinations

Test No. 1
Dryer Primary Cyclone Exhaust 1

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1130-1330	1436-1543	1645-1751
Total sampling time....(MIN)	64.0	64.0	64.0
Moisture content.....(%V/V)	22.53	24.86	24.25
O2 Concentration.....(%V/V)	17.60	17.10	16.80
Volumetric flow rate (DSCFM)	26981	26838	27141
CO concentration.....			
(GR/DSCF).....	0.9271	0.9129	0.9047
(MG/DSCM).....	2122.	2090.	2071.
(PPM-WET).....	1411.	1348.	1346.
(PPM-DRY).....	1822.	1794.	1778.
(PPM-DRY @ 7% O2).....	7502.	6440.	5926.
CO emission rate.....(LB/HR)	214.401	209.988	210.465

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 1
Dryer Primary Cyclone Exhaust 2

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1134-1330	1435-1542	1645-1750
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	25.03	25.14	22.40
O2 Concentration.....(%V/V)	17.20	16.90	17.20
Volumetric flow rate (DSCFM)	27990	28278	29969
CO concentration.....			
(GR/DSCF).....	0.8091	0.9678	1.1266
(MG/DSCM).....	1852.	2215.	2579.
(PPM-WET).....	1192.	1423.	1718.
(PPM-DRY).....	1590.	1902.	2214.
(PPM-DRY @ 7% O2).....	5857.	6494.	8156.
CO emission rate.....(LB/HR)	194.098	234.574	289.382

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 1
Dryer Primary Cyclone Exhaust 3

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-23-96	07-23-96	07-23-96
Time run start/end.....(HRS)	1133-1328	1435-1529	1645-1736
Total sampling time....(MIN)	60.0	47.5	45.0
Moisture content.....(%V/V)	26.69	22.66	20.79
O2 Concentration.....(%V/V)	17.50	16.80	17.40
Volumetric flow rate (DSCFM)	25358	27973	27234
CO concentration.....			
(GR/DSCF).....	0.8935	0.9007	0.8681
(MG/DSCM).....	2045.	2062.	1987.
(PPM-WET).....	1287.	1368.	1351.
(PPM-DRY).....	1756.	1770.	1706.
(PPM-DRY @ 7% O2).....	7024.	5900.	6634.
CO emission rate.....(LB/HR)	194.205	215.940	202.634

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 2
E-Tube Outlet

Results of Carbon Monoxide Determinations ----- **Method 10**

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.6	23.4	23.4
Oxygen content (%V/V)	17.7	17.6	17.6
Volumetric flow rate (DSCFM)	103228	103158	103160
CO concentration			
ppm,dry	1817	1841	1851
CO emission rate (LB/HR)	818	828	833

Test No. 2
Dryer RTO Stack

Results of Carbon Monoxide Determinations Method 10

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.9	23.5	23.5
Oxygen content (%V/V)	17.3	17.3	17.3
Volumetric flow rate (DSCFM)	99560	100405	100405
CO concentration			
ppm,dry	212	234	241
CO emission rate (LB/HR)	92	102	106

Test No. 8
Press RTO Inlet

Results of Carbon Monoxide Determinations **Method 10**

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	3.9	2.9	3.0
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	64300	68979	72300
CO concentration ppm,dry	5.0	5.3	4.4
CO emission rate (LB/HR)	1.4	1.6	1.4

Test No. 8
Press RTO Stack

Results of Carbon Monoxide Determinations Method 10

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	2.9	3.3	3.4
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	77990	76250	77090
CO concentration ppm,dry	19.2	24.2	20.8
CO emission rate (LB/HR)	6.5	8.0	7.0

3.6 Results of Total Hydrocarbons Determinations

Test No. 2
Primary Cyclone Exhaust 1

Results of Total Hydrocarbons Determinations ~~Method 25A~~

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	24.9	24.3	24.3
Oxygen content (%V/V)	17.1	16.8	16.8
Volumetric flow rate (DSCFM)	26838	27141	27140
THC concentration ppmC,wet (as carbon)	1937	1796	1677
THC emission rate (LB/HR)	129	120	112

Test No. 2
Primary Cyclone Exhaust 2

Results of Total Hydrocarbons Determinations Method 25A

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	25.1	22.4	22.4
Oxygen content (%V/V)	16.9	17.2	17.2
Volumetric flow rate (DSCFM)	28278	29969	29970
THC concentration			
ppmC,wet (as carbon)	2165	2125	1840
THC emission rate (LB/HR)	153	153	133

Test No. 2
Primary Cyclone Exhaust 3

Results of Total Hydrocarbons Determinations Method 25A

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.7	20.8	20.8
Oxygen content (%V/V)	16.8	17.4	17.4
Volumetric flow rate (DSCFM)	27973	27234	27230
THC concentration			
ppmC,wet (as carbon)	3498	2595	3474
THC emission rate (LB/HR)	237	167	223

Test No. 2
Dryer RTO Stack

Results of Total Hydrocarbons Determinations Method 25A

	Run 1	Run 2	Run 3
Date of run	7-23-96	7-23-96	7-23-96
Time run start/end (HRS)	1435-1535	1645-1745	1925-2025
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.9	23.5	23.5
Oxygen content (%V/V)	17.3	17.3	17.3
Volumetric flow rate (DSCFM)	99560	100405	100405
THC concentration			
ppmC,wet (as carbon)	24.5	8.0	18.8
THC emission rate (LB/HR)	5.9	2.0	4.6

Test No. 8
Press RTO Inlet

Results of Total Hydrocarbons Determinations Method 25A

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	3.9	2.9	3.0
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	64300	68979	72300
THC concentration			
ppmC,wet (as carbon)	705	764	744
THC emission rate (LB/HR)	88	101	104

Test No. 8
Press RTO Stack

Results of Total Hydrocarbons Determinations Method 25A

	Run 1	Run 2	Run 3
Date of run	7-25-96	7-25-96	7-25-96
Time run start/end (HRS)	1620-1720	1800-1900	1934-2034
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	2.9	3.3	3.4
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	77990	76250	77090
THC concentration			
ppmC,wet (as carbon)	18.9	26.4	13.8
THC emission rate (LB/HR)	2.8	3.9	2.1

3.7 Results of Formaldehyde Determinations

Test No. 4
 Dryer Primary Cyclone Exhaust 1

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-24-96	07-24-96	07-24-96
Time run start/end.....(HRS)	1710/1828	1915/2020	2040/2144
Static pressure.....(IN.WC)	-9.00	-9.00	-9.00
Cross sectional area (SQ.FT)	8.73	8.73	8.73
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	199.0	208.0	208.0
desiccant.....(GRAMS)	20.0	28.0	23.0
total.....(GRAMS)	219.0	236.0	231.0
Formaldehyde in sample..(UG)	16000	18000	19000
Gas meter coefficient.....	1.0024	1.0024	1.0024
Barometric pressure..(IN.HG)	28.53	28.33	28.33
Avg. orif.pres.drop..(IN.WC)	1.27	1.32	1.19
Avg. gas meter temp..(DEF-F)	90.6	91.1	90.5
Volume through gas meter....			
at meter conditions...(CF)	41.65	42.40	40.44
standard conditions.(DSCF)	38.29	38.67	36.91
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.189	.189	.189
Avg.stack gas temp ..(DEG-F)	229	232	227
Volumetric flow rate.....			
actual.....(ACFM)	48023	49388	46236
dry standard.....(DSCFM)	27006	27081	25390
Isokinetic variation.....(%)	99.3	100.0	101.8
CH ₂ O concentration.....			
(GR/DSCF).....	0.0065	0.0072	0.0080
(MG/DSCM).....	14.92	16.50	18.24
(PPM-DRY).....	11.95	13.21	14.61
(PPM-WET).....	9.41	10.27	11.28
CH ₂ O emission rate...(LB/HR)	1.50752	1.67210	1.73310

CH₂O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 4
Dryer Primary Cyclone Exhaust 2

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-24-96	07-24-96	07-24-96
Time run start/end.....(HRS)	1710/1830	1915/2017	2040/2142
Static pressure.....(IN.WC)	-8.60	-8.60	-8.60
Cross sectional area (SQ.FT)	9.39	9.39	9.39
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	146.0	220.0	174.0
desiccant.....(GRAMS)	18.0	6.0	9.0
total.....(GRAMS)	164.0	226.0	183.0
Formaldehyde in sample..(uG)	13000	16000	15000
Gas meter coefficient.....	1.0056	1.0056	1.0056
Barometric pressure..(IN.HG)	28.33	28.33	28.33
Avg. orif.pres.drop..(IN.WC)	0.98	1.06	1.02
Avg. gas meter temp..(DEF-F)	94.8	94.2	92.7
Volume through gas meter....			
at meter conditions...(CF)	34.73	36.05	35.25
standard conditions.(DSCF)	31.54	32.78	32.14
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.179	.179	.179
Avg.stack gas temp ..(DEG-F)	211	207	209
Volumetric flow rate.....			
actual.....(ACFM)	51190	51616	51144
dry standard.....(DSCFM)	29935	28552	29442
Isokinetic variation.....(%)	94.4	102.9	97.8
CH2O concentration.....			
(GR/DSCF).....	0.0064	0.0075	0.0072
(MG/DSCM).....	14.60	17.29	16.53
(PPM-DRY).....	11.69	13.85	13.24
(PPM-WET).....	9.39	10.46	10.43
CH2O emission rate...(LB/HR)	1.63543	1.84754	1.82165

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 4
Dryer Primary Cyclone Exhaust 3

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-24-96	07-24-96	07-24-96
Time run start/end.....(HRS)	1710/1828	1915/2015	2040/2140
Static pressure.....(IN.WC)	-9.00	-9.00	-9.00
Cross sectional area (SQ.FT)	8.73	8.73	8.73
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	210.0	240.0	234.0
desiccant.....(GRAMS)	14.0	12.0	11.0
total.....(GRAMS)	224.0	252.0	245.0
Formaldehyde in sample..(uG)	18000	18000	10000
Gas meter coefficient.....	1.0032	1.0032	1.0032
Barometric pressure..(IN.HG)	28.33	28.33	28.33
Avg. orif.pres.drop..(IN.WC)	1.24	1.27	1.21
Avg. gas meter temp..(DEF-F)	88.7	89.5	88.0
Volume through gas meter....			
at meter conditions...(CF)	40.00	40.39	39.18
standard conditions.(DSCF)	36.67	36.97	35.96
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.189	.189	.189
Avg.stack gas temp ..(DEG-F)	223	223	224
Volumetric flow rate.....			
actual.....(ACFM)	49906	49649	48961
dry standard.....(DSCFM)	27711	26880	26462
Isokinetic variation.....(%)	98.8	102.7	101.5
CH2O concentration.....			
(GR/DSCF).....	0.0076	0.0075	0.0043
(MG/DSCM).....	17.40	17.26	9.86
(PPM-DRY).....	13.94	13.82	7.89
(PPM-WET).....	10.81	10.46	5.98
CH2O emission rate...(LB/HR)	1.80432	1.73584	0.97601

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 4
Dryer RTO Stack

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-24-96	07-24-96	07-24-96
Time run start/end.....(HRS)	1710/1830	1915/2025	2040/2142
Static pressure.....(IN.WC)	-0.54	-0.54	-0.54
Cross sectional area (SQ.FT)	50.79	50.79	50.79
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	223.0	311.0	320.0
desiccant.....(GRAMS)	42.0	19.0	21.0
total.....(GRAMS)	265.0	330.0	341.0
Formaldehyde in sample..(uG)	3300	5000	5100
Gas meter coefficient.....	0.9957	0.9957	0.9957
Barometric pressure..(IN.HG)	28.31	28.31	28.31
Avg. orif.pres.drop..(IN.WC)	2.18	2.26	2.16
Avg. gas meter temp..(DEF-F)	72.7	77.1	80.0
Volume through gas meter....			
at meter conditions...(CF)	54.91	56.14	55.02
standard conditions.(DSCF)	51.55	52.28	50.95
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.270	.270	.270
Avg.stack gas temp ..(DEG-F)	261	265	261
Volumetric flow rate.....			
actual.....(ACFM)	192533	195385	191748
dry standard.....(DSCFM)	107172	103593	100886
Isokinetic variation.....(%)	96.1	100.8	100.9
CH2O concentration.....			
(GR/DSCF).....	0.0010	0.0015	0.0016
(MG/DSCM).....	2.27	3.40	3.56
(PPM-DRY).....	1.82	2.72	2.85
(PPM-WET).....	1.47	2.10	2.16
CH2O emission rate...(LB/HR)	0.91223	1.31754	1.34262

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 9
 Press Inlet

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-25-96	07-25-96	07-25-96
Time run start/end.....(HRS)	937/1039	1235/1335	1410/1512
Static pressure.....(IN.WC)	-4.75	-4.75	-4.75
Cross sectional area (SQ.FT)	17.72	17.72	17.72
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	12.0	10.0	18.0
desiccant.....(GRAMS)	18.0	12.0	10.0
total.....(GRAMS)	30.0	22.0	28.0
Formaldehyde in sample..(uG)	9800	9500	11000
Gas meter coefficient.....	0.9957	0.9957	0.9957
Barometric pressure..(IN.HG)	28.45	28.45	28.45
Avg. orif.pres.drop..(IN.WC)	2.06	1.90	2.00
Avg. gas meter temp..(DEF-F)	79.8	79.9	81.7
Volume through gas meter....			
at meter conditions...(CF)	49.99	47.93	49.44
standard conditions.(DSCF)	46.52	44.58	45.84
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.189	.189	.189
Avg.stack gas temp ..(DEG-F)	128	126	127
Volumetric flow rate.....			
actual.....(ACFM)	85586	82319	84579
dry standard.....(DSCFM)	70110	68048	69412
Isokinetic variation.....(%)	100.7	99.4	100.2
CH2O concentration.....			
(GR/DSCF).....	0.0033	0.0033	0.0037
(MG/DSCM).....	7.48	7.57	8.52
(PPM-DRY).....	5.99	6.06	6.82
(PPM-WET).....	5.81	5.92	6.63
CH2O emission rate...(LB/HR)	1.96288	1.92656	2.21332

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 9
 Press Stack

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-25-96	07-25-96	07-25-96
Time run start/end.....(HRS)	937/1039	1235/1336	1410/1512
Static pressure.....(IN.WC)	-0.27	-0.27	-0.27
Cross sectional area (SQ.FT)	31.50	31.50	31.50
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	18.0	16.0	18.0
desiccant.....(GRAMS)	12.0	9.0	14.0
total.....(GRAMS)	30.0	25.0	32.0
Formaldehyde in sample..(uG)	280	270	270
Gas meter coefficient.....	0.9973	0.9973	0.9973
Barometric pressure..(IN.HG)	28.45	28.45	28.45
Avg. orif.pres.drop..(IN.WC)	2.46	2.52	2.64
Avg. gas meter temp..(DEF-F)	92.1	92.6	96.3
Volume through gas meter....			
at meter conditions...(CF)	52.97	53.97	55.40
standard conditions.(DSCF)	48.32	49.20	50.18
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.251	.251	.251
Avg.stack gas temp ..(DEG-F)	253	255	258
Volumetric flow rate.....			
actual.....(ACFM)	108245	110070	112242
dry standard.....(DSCFM)	73954	75412	76183
Isokinetic variation.....(%)	99.9	99.7	100.7
CH2O concentration.....			
(GR/DSCF).....	0.0001	0.0001	0.0001
(MG/DSCM).....	0.21	0.20	0.19
(PPM-DRY).....	0.16	0.16	0.15
(PPM-WET).....	0.16	0.15	0.15
CH2O emission rate...(LB/HR)	0.05701	0.05507	0.05456

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

3.8 Results of Phenol Determinations

Test No. 6
Press Inlet

Results of Phenol Determinations -----

	Run 1	Run 2	Run 3
Date of run	07-25-96	07-25-96	07-25-96
Time run start/end.....(HRS)	1620-1720	1800-1900	1935-2035
Barometric pressure..(IN.HG)	28.45	28.45	28.45
Meter temperature....(DEG-F)	80.75	80.75	78.75
Meter correction coefficient	0.9968	0.9968	0.9968
Volume through gas meter.... at meter conditions...(CF)	44.630	49.020	47.440
standard conditions (DSCF)	41.494	45.575	44.270
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	3.93	2.91	3.00
Volumetric flow rate (DSCFM)	64300	68979	72300
Phenol in sample.....(uG)	840.00<	840.00<	840.00<
Phenol concentration..... (GR/10 ³ DSCF).....	0.3124<	0.2844<	0.2928<
(uG/DSCM).....	715.42<	651.35<	670.55<
(PPB-DRY).....	182.82<	166.45<	171.35<
(PPB-WET).....	175.63<	161.60<	166.21<
Phenol emis. rate(10 ⁻³ LB/HR)	172.148<	168.137<	181.427<

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Analysis performed according to NIOSH Method 3502

Test No. 6
Press Stack

Results of Phenol Determinations -----

	Run 1	Run 2	Run 3
Date of run	07-25-96	07-25-96	07-25-96
Time run start/end.....(HRS)	1620-1720	1800-1900	1935-2035
Barometric pressure..(IN.HG)	28.45	28.45	28.45
Meter temperature....(DEG-F)	84.38	86.63	88.29
Meter correction coefficient	0.9929	0.9929	0.9929
Volume through gas meter.... at meter conditions...(CF)	47.810	48.370	47.930
standard conditions (DSCF)	43.986	44.318	43.782
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	2.91	3.29	3.43
Volumetric flow rate (DSCFM)	77990	76250	77090
Phenol in sample.....(uG)	840.00<	840.00<	840.00<
Phenol concentration..... (GR/10 ³ DSCF).....	0.2947<	0.2925<	0.2960<
(uG/DSCM).....	674.89<	669.83<	678.03<
(PPB-DRY).....	172.46<	171.17<	173.27<
(PPB-WET).....	167.44<	165.54<	167.32<
Phenol emis. rate(10 ⁻³ LB/HR)	196.971<	191.134<	195.605<

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Analysis performed according to NIOSH Method 3502

3.9 Results of MDI Determinations

Test No. 5
Press RTO Stack

Results of MDI Determinations-----

	Run 1	Run 2	Run 3
Date of run	07-25-96	07-25-96	07-25-96
Time run start/end.....(HRS)	1620/1720	1800/1900	1935/2035
Static pressure.....(IN.WC)	-0.27	-0.27	-0.27
Cross sectional area (SQ.FT)	31.50	31.50	31.50
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	0.0	0.0	0.0
desiccant.....(GRAMS)	19.0	16.0	17.0
total.....(GRAMS)	19.0	16.0	17.0
MDI in sample(ug)	< 6.2	< 6.2	< 6.2
Gas meter coefficient.....	0.9973	0.9973	0.9973
Barometric pressure..(IN.HG)	28.45	28.45	28.45
Avg. orif.pres.drop..(IN.WC)	0.74	0.70	0.72
Avg. gas meter temp..(DEF-F)	93.2	94.6	94.8
Volume through gas meter....			
at meter conditions...(CF)	29.01	28.67	29.10
standard conditions.(DSCF)	26.30	25.92	26.30
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.181	.181	.181
Avg.stack gas temp ..(DEG-F)	255	255	255
Volumetric flow rate.....			
actual.....(ACFM)	114901	111880	113173
dry standard.....(DSCFM)	77991	76253	77090
Isokinetic variation.....(%)	99.1	99.9	100.3
MDI Concentration.....(ppm)	< 0.0008	< 0.0008	< 0.0008
MDI Emission Rate.....(LB/HR)	< 0.0024	< 0.0024	< 0.0024

4 RESULTS OF FUEL ANALYSES

INTERPOLL LABORATORIES, INC.

Fuel Laboratory

(612) 786-6020

Date: 8/12/96
Client: LOUISIANA PACIFIC/SAGOLA
Laboratory Log Number: 8024-69-0359
Sample Collected: 7/24/96
Sample Received: 7/26/96
Source: DRYER
Sample Identification: ASPEN DRY WOOD

Ultimate Analysis WT %

Parameter	Moisture & Ash Free	Moisture Free	As Received
Moisture, Total			2.10
Ash		1.07	1.04
Carbon	49.34	48.81	47.79
Hydrogen	6.07	6.00	5.88
Nitrogen	0.34	0.34	0.33
Oxygen (calculated)	44.26	43.78	42.87
Sulfur	< 0.05	< 0.05	< 0.05
Heating Value, BTU/LB	8443	8353	8178

Respectfully submitted,



David J. Schneider, Manager
Chemistry Department

9150

INTERPOLL LABORATORIES, INC.

Fuel Laboratory

(612) 786-6020

Date: 8/12/96
Client: LOUISIANA PACIFIC/SAGOLA
Laboratory Log Number: 8024-70-0360
Sample Collected: 7/24/96
Sample Received: 7/26/96
Source: DRYER
Sample Identification: SOFTWOOD

Ultimate Analysis WT %

Parameter	Moisture & Ash Free	Moisture Free	As Received
Moisture, Total			2.40
Ash		0.94	0.92
Carbon	50.01	49.54	48.35
Hydrogen	5.95	5.89	5.75
Nitrogen	0.32	0.32	0.31
Oxygen (calculated)	43.73	43.31	42.28
Sulfur	< 0.05	< 0.05	< 0.05
Heating Value, BTU/LB	8790	8707	8498

Respectfully submitted,



David J. Schneider, Manager
Chemistry Department

8885

APPENDIX A

RESULTS OF VOLUMETRIC FLOW RATE DETERMINATIONS

Test No. 1
Dryer Primary Cyclone Exhaust 1

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-23-96
Time of Determination.....(HRS)	720
Barometric pressure.....(IN.HG)	28.33
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	40
Duct area.....(SQ.FT)	8.73
Direction of flow.....	UP
Static pressure.....(IN.WC)	-9
Avg. gas temp.....(DEG-F)	265
Moisture content.....(% V/V)	22.53
Avg. linear velocity.....(FT/SEC)	95.4
Gas density.....(LB/ACF)	.04663
Molecular weight.....(LB/LBMOLE)	29.18
Mass flow of gas.....(LB/HR)	139766
Volumetric flow rate.....	
actual.....(ACFM)	49953
dry standard.....(DSCFM)	26061

Test No. 1
Dryer Primary Cylcone Exhaust 3

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-23-96
Time of Determination.....(HRS)	740
Barometric pressure.....(IN.HG)	28.33
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	12
Shape of duct.....	Round
Stack diameter.....(IN)	40
Duct area.....(SQ.FT)	8.73
Direction of flow.....	UP
Static pressure.....(IN.WC)	-9
Avg. gas temp.....(DEG-F)	216
Moisture content.....(% V/V)	26.69
Avg. linear velocity.....(FT/SEC)	88.5
Gas density.....(LB/ACF)	.04916
Molecular weight.....(LB/LBMOLE)	29.20
Mass flow of gas.....(LB/HR)	136655
Volumetric flow rate.....	
actual.....(ACFM)	46333
dry standard.....(DSCFM)	24533

Test No. 1
E Tube Outlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-23-96
Time of Determination.....(HRS)	907
Barometric pressure.....(IN.HG)	28.35
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	81.5
Duct area.....(SQ.FT)	36.23
Direction of flow.....	UP
Static pressure.....(IN.WC)	-1.83
Avg. gas temp.....(DEG-F)	155
Moisture content.....(% V/V)	22.68
Avg. linear velocity.....(FT/SEC)	71.0
Gas density.....(LB/ACF)	.05599
Molecular weight.....(LB/LBMOLE)	29.16
Mass flow of gas.....(LB/HR)	518549
Volumetric flow rate.....	
actual.....(ACFM)	154363
dry standard.....(DSCFM)	96635

Test No. 1
Dryer RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-23-96
Time of Determination.....(HRS)	1000
Barometric pressure.....(IN.HG)	28.35
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	96.5
Duct area.....(SQ.FT)	50.79
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.54
Avg. gas temp.....(DEG-F)	260
Moisture content.....(% V/V)	22.55
Avg. linear velocity.....(FT/SEC)	61.1
Gas density.....(LB/ACF)	.04803
Molecular weight.....(LB/LBMOLE)	29.17
Mass flow of gas.....(LB/HR)	536895
Volumetric flow rate.....	
actual.....(ACFM)	186316
dry standard.....(DSCFM)	100134

Test No. 4
Dryer RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-24-96
Time of Determination.....(HRS)	1600
Barometric pressure.....(IN.HG)	28.35
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	96.5
Duct area.....(SQ.FT)	50.79
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.54
Avg. gas temp.....(DEG-F)	260
Moisture content.....(% V/V)	19.51
Avg. linear velocity.....(FT/SEC)	60.7
Gas density.....(LB/ACF)	.04857
Molecular weight.....(LB/LBMOLE)	29.13
Mass flow of gas.....(LB/HR)	539208
Volumetric flow rate.....	
actual.....(ACFM)	185012
dry standard.....(DSCFM)	103329

Test No. 7
Press RTO Stack

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-24-96
Time of Determination.....(HRS)	1810
Barometric pressure.....(IN.HG)	28.31
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	20
Shape of duct.....	Round
Stack diameter.....(IN)	76
Duct area.....(SQ.FT)	31.50
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.27
Avg. gas temp.....(DEG-F)	255
Moisture content.....(% V/V)	3.92
Avg. linear velocity.....(FT/SEC)	57.1
Gas density.....(LB/ACF)	.05152
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	333754
Volumetric flow rate.....	
actual.....(ACFM)	107959
dry standard.....(DSCFM)	72427

Test No. 8
Press Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-25-96
Time of Determination.....(HRS)	1620
Barometric pressure.....(IN.HG)	28.45
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	57.25
Duct area.....(SQ.FT)	17.88
Direction of flow.....	UP
Static pressure.....(IN.WC)	-4.75
Avg. gas temp.....(DEG-F)	123
Moisture content.....(% V/V)	3.00
Avg. linear velocity.....(FT/SEC)	72.7
Gas density.....(LB/ACF)	.06299
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	294528
Volumetric flow rate.....	
actual.....(ACFM)	77933
dry standard.....(DSCFM)	64300

Test No. 8
Press Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-25-96
Time of Determination.....(HRS)	1800
Barometric pressure.....(IN.HG)	28.45
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	57.25
Duct area.....(SQ.FT)	17.88
Direction of flow.....	UP
Static pressure.....(IN.WC)	-4.75
Avg. gas temp.....(DEG-F)	123
Moisture content.....(% V/V)	2.90
Avg. linear velocity.....(FT/SEC)	77.9
Gas density.....(LB/ACF)	.06301
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	315752
Volumetric flow rate.....	
actual.....(ACFM)	83517
dry standard.....(DSCFM)	68979

Test No. 8
Press Inlet

Results of Volumetric Flow Rate Determination-----Method 2


Date of Determination.....	07-25-96
Time of Determination.....(HRS)	1935
Barometric pressure.....(IN.HG)	28.45
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	57.25
Duct area.....(SQ.FT)	17.88
Direction of flow.....	UP
Static pressure.....(IN.WC)	-4.75
Avg. gas temp.....(DEG-F)	123
Moisture content.....(% V/V)	3.00
Avg. linear velocity.....(FT/SEC)	81.7
Gas density.....(LB/ACF)	.06299
Molecular weight.....(LB/LBMOLE)	28.84
Mass flow of gas.....(LB/HR)	331173
Volumetric flow rate.....	
actual.....(ACFM)	87629
dry standard.....(DSCFM)	72300


35

APPENDIX B


LOCATION OF TEST PORTS







**PRIMARY CYCLONE
OUTLET (3 SITES)**



NOTE:
SEE DRAWING P9-949 FOR PLAN VIEW.

LOUISIANA-PACIFIC CORPORATION
NORTHERN DIVISION


NO. 17, SEPT. 25, 1948
SCALE: 1/4" = 1'-0"

DATE: 1/27/48
BY: J. L. HARRIS
CHECKED BY: J. L. HARRIS
APPROVED BY: J. L. HARRIS
DESIGNED BY: J. L. HARRIS
DRAWN BY: J. L. HARRIS


REV. 1
REV. 2
REV. 3
REV. 4
REV. 5
REV. 6
REV. 7
REV. 8
REV. 9
REV. 10
REV. 11
REV. 12
REV. 13
REV. 14
REV. 15
REV. 16
REV. 17
REV. 18
REV. 19
REV. 20
REV. 21
REV. 22
REV. 23
REV. 24
REV. 25
REV. 26
REV. 27
REV. 28
REV. 29
REV. 30
REV. 31
REV. 32
REV. 33
REV. 34
REV. 35
REV. 36
REV. 37
REV. 38
REV. 39
REV. 40
REV. 41
REV. 42
REV. 43
REV. 44
REV. 45
REV. 46
REV. 47
REV. 48
REV. 49
REV. 50
REV. 51
REV. 52
REV. 53
REV. 54
REV. 55
REV. 56
REV. 57
REV. 58
REV. 59
REV. 60
REV. 61
REV. 62
REV. 63
REV. 64
REV. 65
REV. 66
REV. 67
REV. 68
REV. 69
REV. 70
REV. 71
REV. 72
REV. 73
REV. 74
REV. 75
REV. 76
REV. 77
REV. 78
REV. 79
REV. 80
REV. 81
REV. 82
REV. 83
REV. 84
REV. 85
REV. 86
REV. 87
REV. 88
REV. 89
REV. 90
REV. 91
REV. 92
REV. 93
REV. 94
REV. 95
REV. 96
REV. 97
REV. 98
REV. 99
REV. 100

NOTES:

1. DUCT SPECS: #104 10 GAUGE STAINLESS STEEL
3" x 3" 1/4" ANGLE FLANGES AT JOINTS.
2. DUCT INSULATION: 3" 1.000 DEG. F. 88 DENSITY
FIBERGLASS INSULATION AND 1/2" LAGGED ALUM.
LAGGING. ALL EXTERIOR DUCT TO BE INSULATED.
3. DUCT SPRINKLER: DUCTWORK PROTECTION SHOULD
BE PROVIDED BY AUTOMATIC SPRINKLERS RATED AT
LEAST 50 DEG.F. ABOVE THE MAXIMUM EXPECTED
AMBIENT DUCT TEMPERATURE. HEADS SHOULD BE
SPACED NO MORE THAN 12 FT. VERTICALLY AND
HORIZONTALLY. SPRINKLER HEADS SHOULD BE
PROTECTED BY GROUNDING TO 2 GPM/50. FT OVER THE
PROJECTED AREA OF THE DUCTWORK INCLUDING UP
TO 100 LINEAL FT. OF DUCT. A 250 GPM HOSE
STREAM ALLOWANCE SHOULD BE INCLUDED.
SEPARATE CONTROL VALVES AND FLOW ALARMS SHOULD
BE PROVIDED FOR THE DUCTWORK PROTECTION.
FACTORY MUTUAL APPROVAL REQUIRED.
SYSTEM TO BE DIRT VALUE.
4. TEST PORTS: 4" DIA. X 6" LONG STAINLESS STEEL WITH
THREADED CAP.
5. ACCESS DOORS: 2' X 2' 10. RAISED FLANGE, BOLTED AND
INSULATED.
6. ALL ELBOW RADI TO BE 2' X DUCT DIA. EXCEPT
WHERE OTHERWISE SPECIFIED.





LOUISIANA-PACIFIC CORPORATION
 NORTHERN DIVISION
 PRESS INTO DUCTING LAY
 DATE: 1 OCT 61
 SCALE: 1"=10'
 DRAWN BY: J.P.S.
 CHECKED BY: R.M.B.
 DESIGNED BY: R.E.S.
 PROJECT NO. 54000-14
 SHEET NO. P9-18C



NOTE:
 THIS IS A HAND DRAWN DIAG. PG-127 FOR MORE
 DETAIL ON SURROUNDING SITE.


LOUISIANA-PACIFIC CORPORATION		STACK LOCATION LAYOUT	
NORTHERN DIVISION		MOBILE, AL	
DATE: 10 MAR 56	BY: H.W.	APPROVED BY: M.	DRAWING NO. PG-135
SCALE: 1" = 40'	BY: J.L.	DATE: 10 MAR 56	
NO. IN PROJECT	NO. OF SHEETS	NO. OF SHEETS	
10	1	1	



Mississippi Green Air Systems, Inc.
 1015 S. GULF BLVD.
 MEMPHIS, TENN. 38119
 (901) 525-1000

Submittal Systems, Inc.
 GENERAL ARRANGEMENT
 DRYER UNIT


NO.	DATE	BY	CHKD.
1	11/11/83	J. W. HARRIS	J. W. HARRIS
2	11/11/83	J. W. HARRIS	J. W. HARRIS
3	11/11/83	J. W. HARRIS	J. W. HARRIS
4	11/11/83	J. W. HARRIS	J. W. HARRIS
5	11/11/83	J. W. HARRIS	J. W. HARRIS
6	11/11/83	J. W. HARRIS	J. W. HARRIS
7	11/11/83	J. W. HARRIS	J. W. HARRIS
8	11/11/83	J. W. HARRIS	J. W. HARRIS
9	11/11/83	J. W. HARRIS	J. W. HARRIS
10	11/11/83	J. W. HARRIS	J. W. HARRIS



SEE VEHICULAR CLEAN AIR SYSTEMS, INC. DRAWINGS
 2-318-100 AND 2-318-101 FOR DISPERSION TUBE
 INSTALLATION AND DETAILS.

NOTE:
 SEE DRAWING P9-942 FOR LONGITUDINAL ELEVATION.

1. ALL DUCTING BETWEEN PRIMARY CYCLONE AND E-TUBE TO BE 10 GA. MILD STEEL, PRIMED AND PAINTED.
2. ALL DUCTING DOWNSTREAM OF E-TUBE TO BE 10 GA. 304 STAINLESS STEEL.
3. DUCT INSULATION 3" LOOSI DEC. F. 6# DENSITY FIBERGLASS INSULATION AND 30# ENHANCED ALUMINUM LAGGING. ALL EXTERIOR DUCT TO BE INSULATED.
4. TEST PROBES, 4" DIA. X 6' LONG STAINLESS STEEL WITH THREADED CAPS.
5. ACCESS DOORS: 2' X 31" LB. RAISED FLANGE, SOLID AND INSULATED.
6. ALL ELBOW RADI TO BE 2 X DUCT DIA. EXCEPT WHERE OTHERWISE SPECIFIED.
7. CONTRACTOR TO PROVIDE INSTALLATION AND ASSEMBLY DRAWINGS.
8. DUCTING 48" DIA. AND SMALLER TO HAVE 6" X 2" X 1/4" PLATE X 1/4" FLANGES. FLANGES TO BE MADE FROM ROLLED ANGLES.
9. ALL DUCT TO BE DESIGNED FOR AN UNSUPPORTED SPAN OF 40'.
10. DUCTING & PLATFORMS TO BE SANDA BLUE (COUPONT 98V2365) HANDRAILS & LADDERS TO BE HIGH VISIBILITY YELLOW (COUPONT SAFETY COLORS).
11. TYPICAL CATWALK FRAMING TO BE C4 X 7.25 WITH TYPE 19V4 1-1/2 X 1/8 OPEN FLOOR GRATING. HANDRAILS-1-1/4 SCH. 40 PIPE.



LOUISIANA-PACIFIC CORPORATION NORTHERN DIVISION	
PROJ. NO. P9-950 SHEET NO. 11 DATE 11/15/50	DRAWN BY CHECKED BY APPROVED BY TITLE

APPENDIX C

FIELD DATA SHEETS

Faint, illegible text or markings on the left side of the page.



INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Sagehen
 Source Primary Cyclone Exhaust #1
 Test 1 Run 0 Date 7-23-96
 Stack Dimen. 40 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 28.33 IN.HG
 Static Pressure -9.0 IN.WC
 Operators SE/SB
 Pitot No. V22-4 C₂ 0.84

Cross-section View	Elevation View
-----------------------	-------------------

* Particulate *

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>6</u> IN.	Time Start: <u>720</u> HRS		
A - 1	0.032 .032	1.28	7.28	1.7	
2	0.105 .105	4.20	10.20	2.0	
3	0.194 .194	7.76	13.76	2.1	265
4	0.323 .323	12.92	18.92	2.0	
5	0.677 .677	27.08	33.08	1.7	
6	0.806 .806	32.24	38.24	1.6	
7	.895	35.80	41.80	1.6	
8	.968	38.72	44.72	1.6	
B. 1				1.5	
2				1.9	265
3				1.9	
4				1.8	
5				1.7	
6				1.9	
7				1.9	
8				1.9	
Temp. Meas. Device & S/N: <u>PDT-# 40</u>				Time End: <u>732</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Sagola Date 7-23-96 Test 1 Run 1

Source Primary Cyclone outlet #1 No. of traverse points 16

Method 5 Filter holder: S.S Filter type: S.S. Th. - 6/6

Sample Train Leak Check: Bluss 4" 6F

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.02 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

32
8539

~~Acetone~~
~~Other(s)~~ Mecl₂

No. of probe wash bottles:

1

Sample recovered by:

SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>705</u>	<u>498</u>	<u>207</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1459</u>	<u>1436</u>	<u>23</u>
Total			<u>230</u>

Integrated Gas Sampling Data:

Bag Pump No. 22A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.02
 Time start: 1130
 Sampling rate: 400

Box No. 2 Bag No. 1
 Size: 44 L
 cc/min at 16 IN.HG
 (HRS) Time end: 1230 (HRS)
 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 8

TEL. █ L █ WA. █ S, █
(612) 786-6020

EPA Method 5 Field Data Sheet

Job RF/Sagevia Operators SF/SB Nozzle No. 413 Pilot No. V22-5
 Source Perimeter Cyclehouse District #1 Meter Box No. 13 AH @ 1.84 in. WC in. 1.59 C_p 0.84
 Date 7-23-96 Test (Run 1) Gasmeter Coeff. 1.0084 Bar. Press. 28.23 in. Hg in. Hg 25 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)					Gas/Out	Oxygen (% v/v)	
							Stack	Probe	Oven	Insp.	Gas/In			
██████████			██████████	██████████	██████████	██████████	██████████	██████████	██████████	██████████	██████████	██████████	██████████	██████████
A-8	<u>(4:30.1)</u> 4	710.48	1.6	1.07	2.86	7	██████████	243	N/A	47	██████████	76	17.5	
7	8	715.19	1.6	1.01	5.16	7		247		49		78	17.8	
6	12	717.29	1.3	.86	7.26	8		252		50		82	18.2	
5	16	719.85	1.8	1.17	9.77	12		255		50		84	18.2	
4	20	722.43	1.9	1.26	2.35	8		255		50		84	18.4	
3	24	725.03	2.1	1.37	5.07	8		253		52		84	18.0	
2	28	727.60	1.9	1.28	7.67	9		250		51		84	17.7	
1	32	730.30	2.1	1.39	0.38	10		248		54		84	18.1	
B-8	36	733.84	1.8	1.19	2.89	8		247		51		85	18.0	
7	40	735.35	1.9	1.26	5.47	9		249		51		84	18.0	
6	44	738.03	1.9	1.28	8.09	10		246		53		85	18.1	
5	48	740.60	1.8	1.21	0.64	10		248		55		85	18.3	
4	52	743.21	1.8	1.21	3.18	10		248		56		85	18.1	
3	56	745.83	1.9	1.28	5.80	10		250		54		85	17.7	
2	60	748.46	2.0	1.35	8.49	10		253		52		86	17.8	
1	64	750.95	1.7	1.14	0.96	9		254		53		86	17.9	
██████████														
██████████	0 - 64	V_m - 40.47		ΔT 4.21								AVE. - 85.5	██████████	

ORITECH CANS TAC KWPAI CORP-AS 5 111

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Sample Date 7-23-96 Test 1 Run 2
 Source Primary Cyclone Exhaust No. of traverse points 76
 Method 5 Filter holder: Glass Filter type: 4" GF

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 14 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

8351

Acetone
 Other(s) MeCl₂ (Impinger Rinse)

No. of probe wash bottles:

1
SF

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	<u>745</u>	<u>512</u>	<u>233</u>
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	<u>1326</u>	<u>1289</u>	<u>37</u>
Total			<u>270</u>

Integrated Gas Sampling Data:

Bag Pump No. 22A Box No. 2 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 14"
 Pretest leak check: 0.02 cc/min at 16 IN.HG
 Time start: 1436 (HRS) Time end: 1543 (HRS)
 Sampling rate: 4.00 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 8

EPA Method 5 Field Data Sheet

Job LP Sample Operators SF/SB Pilot No. V22-5
 Source Primary Cyclohexane Extract H-1 Meter Box No. 23-Δ1@184 in. WC 1.89 in. 0.84
 Date 5-23-96 Test 1 Run 2 Gasmeter Coeff. 1.0024 Bar. Press. 28.33 in. Hg 24 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)
							Stack	Probe	Oven	Imp.			
B-8	4	751.23	1.80	1.22	4.27	4.5	253	249	47	86	86	18.0	
7	8	756.83	1.85	1.26	6.86	8	253	252	48	88	85	18.0	
6	12	759.37	1.90	1.30	9.48	8	250	255	48	90	86	18.0	
5	16	762.02	1.90	1.30	2.11	9	251	257	52	91	86	18.1	
4	20	764.60	1.80	1.23	4.67	8	253	257	52	91	86	18.3	
3	24	767.23	1.90	1.30	7.31	9	257	256	53	91	86	18.0	
2	28	768.99	1.90	1.31	9.96	9	258	259	55	91	87	17.9	
1	32	772.54	1.80	1.23	2.52	9	262	260	56	93	87	18.1	
A-8	36	775.02	1.80	1.24	5.10	9	259	257	52	93	87	17.6	
7	40	777.70	2.00	1.37	7.80	11	254	257	52	94	87	17.9	
6	44	780.43	2.00	1.37	0.51	11	257	255	51	96	87	18.1	
5	48	783.25	2.10	1.44	3.29	12	257	256	53	96	87	18.0	
4	52	785.97	1.90	1.30	5.93	11	252	254	53	95	87	17.8	
3	56	788.63	1.90	1.30	8.58	11	253	251	54	95	88	17.9	
2	60	791.25	1.95	1.34	1.26	11	253	252	54	96	88	17.8	
1	64	793.83	1.80	1.24	3.84	12	254	250	55	96	84	17.8	
(1543)													
0-64		V _m - 412.10	ΔT - 430								AVG. - 89.8		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job 27/Sage 1a Date 7-23-96 Test 1 Run 3

Source Primary Cyclone Exhaust #1 No. of traverse points 16

Method 5 Filter holder: 6/6ss Filter type: 4" GP

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.00 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

8575

Acetone
 Other(s) MeCl₂

No. of probe wash bottles:

1

Sample recovered by:

SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	749	507	242
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1477	1459	18
Total			260

Integrated Gas Sampling Data:

Bag Pump No. 22A

Box No. 2 Bag No. 3

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: 0.00

cc/min at 16 IN.HG

Time start: 1645

(HRS) Time end: 1751 (HRS)

Sampling rate: 400

cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 8

EPA Method 5 Field Data Sheet

Job: LR/Sage Operators: SF/SB Nozzle No.: 4-3 Pilot No.: U22-5
 Source: Process Exhaust 1 Meter Box No.: 23 AH@: 1.58 in. WC: _____ Nozzle Dia.: .189 in. C_v: 0.84
 Date: 2-23-86 Test: 1 Run: 3 Gas meter Coeff.: 1.0029 Bar. Press.: 28.33 in. Hg H₂O: 25 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)				
							Stack	Probe	Oven	Insp.		Gas/In	Gas/Out		
A - 8	(1645)	799.70													
	4	797.24	2.0	1.34	7.38	8	247	255	48	85	86	18.0			
	7	799.92	1.90	1.37	9.97	8	249	254	48	88	84	16.4			
	6	802.50	1.90	1.27	2.56	8	252	255	49	90	85	18.2			
	5	805.09	1.90	1.27	5.16	8	253	257	50	91	84	18.0			
	4	807.87	2.10	1.41	7.90	11	254	259	50	92	84	18.2			
	3	810.66	2.10	1.40	0.63	11	255	258	50	90	84	18.0			
	2	813.30	1.90	1.27	3.24	10	257	262	51	89	83	18.0			
	1	815.90	1.90	1.27	5.83	10	260	261	52	91	84	18.2			
	8	818.37	1.75	1.17	8.33	9	258	260	51	93	84	17.8			
B - 8	40	820.98	1.90	1.27	0.93	9	257	259	52	95	84	17.9			
	44	823.49	1.90	1.28	3.54	9	257	256	53	96	84	17.6			
	45	826.05	1.90	1.28	6.16	10	253	257	54	97	85	17.9			
	4	828.70	1.80	1.21	8.71	10	250	255	55	97	85	17.6			
	3	831.28	1.90	1.28	1.32	10	248	254	56	97	85	17.7			
	2	833.87	1.90	1.28	3.94	10	250	245	56	96	85	17.8			
	1	836.49	1.80	1.21	6.48	11	254	250	57	96	86	17.7			
	(1750)														
		0-67	V _m - 41.79	ΔT - 1.26			AVG. - 88.5								

EPA Method 7 Sampling Collection Field Data Sheet

Job L.P. / SAGOLA Date 7-23-96 Bar Pressure 28.33 IN.HG
 Test Location PRIMARY CYCLONE Fuel Type PROPANE Sample Train No 3
 Technician SLB Pump No 1

No.	Test Run Point	Flask No.	Time (HRS)	Vacuum (IN.HG)	Flask Temp. (°F)	Leak Rate <0.4 IN.HG/MIN.	
1	2-1-1	1	1130	26.38	102	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
2	2-1-2	2	1145	26.39	106	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
3	2-1-3	3	1215	26.38	108	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
4	2-1-4	4	1325	26.35	110	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
5	2-2-1	5	1434	26.15	110	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
6	2-2-2	6	1445	26.10	108	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
7	2-2-3	19	1515	26.80	110	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
8	2-2-4	20	1540	26.40	110	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
9	2-3-1	21	1650	26.40	110	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
10	2-3-2	22	1710	26.30	109	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
11	2-3-3	23	1730	26.40	109	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
12	2-3-4	24	1745	26.40	108	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
13						<input type="checkbox"/> YES	<input type="checkbox"/> NO
14						<input type="checkbox"/> YES	<input type="checkbox"/> NO
15						<input type="checkbox"/> YES	<input type="checkbox"/> NO
16						<input type="checkbox"/> YES	<input type="checkbox"/> NO
17						<input type="checkbox"/> YES	<input type="checkbox"/> NO
18						<input type="checkbox"/> YES	<input type="checkbox"/> NO
19						<input type="checkbox"/> YES	<input type="checkbox"/> NO
20						<input type="checkbox"/> YES	<input type="checkbox"/> NO
21						<input type="checkbox"/> YES	<input type="checkbox"/> NO
22						<input type="checkbox"/> YES	<input type="checkbox"/> NO
23						<input type="checkbox"/> YES	<input type="checkbox"/> NO
24						<input type="checkbox"/> YES	<input type="checkbox"/> NO
25						<input type="checkbox"/> YES	<input type="checkbox"/> NO
26						<input type="checkbox"/> YES	<input type="checkbox"/> NO
27						<input type="checkbox"/> YES	<input type="checkbox"/> NO


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job h. P. Sagola
 Source No 2 Cyclone Outlet
 Test 1 Run Date 7/23/96
 Stack Dimen. 4.5 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.33 IN.HG
 Static Pressure -8.6 IN.WC
 Operators J. Van Hoever & J. Lorenz
 Pitot No. V23-5 C. 84



Partic. into

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	9 IN.	Time Start:	HRS
A 1	.044	1.82	10.82		
2	.146	6.06	15.06		
3	.296	12.28	21.28		
4	.704	29.22	38.22		
5	.854	35.44	44.44		
6	.956	39.67	48.67		
B 1					
2					
3					
4					
5					
6					

Temp. Meas. Device & S/N: PDT #35 Time End: _____ HRS

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagola Date 7/23/96 Test 1 Run 1

Source No 2 Cyclone Outlet No. of traverse points 12

Method 5 Filter holder: glass Filter type: glass fiber

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8585

Recovery solvent(s)

acetone _____

other(s) MeCl₂ & D₂O

No. of probe wash bottles:

1
DVH

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			211
Impinger No. 2	411	200	
Impinger No. 3			
Condenser			
Desiccant	1360	1350	10
Total			221

Integrated Gas Sampling Data:

Bag Pump No. 29 A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1140
 Sampling rate: 400

Box No. 19 Bag No. 1
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 1330 (HRS)
 cc/min Operator: DVH

S/N of O₂ Analyzer used to monitor train outlet:

4

EPA Method 5 Field Data Sheet

Job L. P. Saegola
 Source N.S. Cyclone Outlet
 Date 7/23/96 Test 1 Run/

Operator D.H. & J.L.
 Meter Box No. 5 ΔH @ 1.80 in. WC
 Gas Meter Coeff. 1.0056

Nozzle No. 6-3
 Nozzle Dia. 179 in.
 Bar. Press. 28.33 in. Hg

Pilot No. V23-5
 C_p 1.87
 H₂O 2.6 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cl)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cl)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/In
A 6	134	956.26	2.10	1.08	9.24	7	207	253	261	90	101	17.7
A 5	5	959.29	2.2	1.19	2.85	8	207	257	260	106	89	17.4
A 4	10	967.47	1.80	.97	5.34	8	199	267	263	91	88	17.1
A 3	15	965.39	1.60	.86	8.04	7	199	268	261	95	87	16.9
A 2	20	968.17	1.50	.81	0.66	6	202	268	271	101	92	16.8
A 1	25	970.30	1.0	.54	2.81	8	212	268	271	103	90	17.0
B 6	30	977.89	1.95	1.05	5.81	8	205	271	270	104	92	16.9
B 5	35	975.89	1.90	1.03	8.78	8	205	271	270	103	90	16.7
B 4	40	978.96	1.80	.96	1.65	7	205	271	270	103	90	16.6
B 3	45	981.81	1.80	.96	4.54	7	205	271	270	104	92	17.0
B 2	50	984.51	1.80	.98	7.44	7	205	271	270	104	92	16.9
B 1	55	987.37	1.50	.81	6.09	7	205	271	270	104	92	17.5
1	60 (1330)	990.52	1.50	.81	6.09	7	205	271	270	104	92	17.5
	0-60	V _n - 33.76	ΔH - .94									
												AVG - 94.7

Stop Test
 8 min into
 1330 at 11:30

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagala Date 7/23/96 Test 1 Run 2
 Source No. 2 Cyclone Outlet No. of traverse points 12
 Method 5 Filter holder: # glass Filter type: glass fiber

Sample Train Leak Check:
 Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:
 No. of filters used: 8560 Recovery solvent(s): acetone
 other(s) ?

No. of probe wash bottles: 1
 Sample recovered by: Dust
 Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>411</u>	<u>200</u>	<u>211</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1489</u>	<u>1475</u>	<u>14</u>
Total			<u>225</u>

Integrated Gas Sampling Data:
 Bag Pump No. 294 Box No. 19 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Prerest leak check: 0 cc/min at 14 IN.HG
 Time start: 1435 (HRS) Time end: 1542 (HRS)
 Sampling rate: 400 cc/min Operator: J.H.

S/N of O₂ Analyzer used to monitor train outlet: 4

Job: L. P. Sappala Date: 1/23/80 Test: 1 Run: 2
 Source: No. 2 Cyl. Oxide Outlet
 Operators: Den & J.C.
 Meter Box No.: 5 Alt: 1.80 in. WC
 Gas meter Coeff.: 1.0056
 Nozzle No.: 6-3
 Nozzle Dia.: 1.79 in.
 Bar. Press.: 28.33 in. Hg
 Pilot No.: V23-5
 C_p: 1.81
 H₂O: 2.5 %

EPA Method 5 Field Data Sheet

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity (ft./min. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Insp.		Gas/In	Gas/Out
B 6	1435	991.725	1.90	1.04	4.71	7	208	153	260	57	90	90	16.5
B 5	5	994.77	2.10	1.05	7.84	7.5	203	261	263	57	99	92	16.5
B 4	10	997.86	2.0	1.11	0.92	7.5	203	261	263	57	101	93	16.9
B 3	15	1000.91	1.85	1.02	3.89	7	206	264	266	53	103	93	16.2
B 2	20	1003.99	1.30	1.72	6.39	6	206	264	266	53	104	94	17.1
B 1	25	1006.62	1.1	1.61	8.69	5	204	260	258	56	104	94	17.1
A 6	30	1008.78	2.15	1.20	1.90	7	204	260	258	56	100	93	16.8
A 5	35	1011.79	2.0	1.11	4.99	7	204	261	260	56	105	94	16.9
A 4	40	1015.02	2.0	1.11	8.10	7	204	261	260	56	105	96	16.5
A 3	45	1018.16	1.9	1.0	1.04	7	205	262	257	54	105	95	16.7
A 2	50	1021.11	1.4	1.06	4.06	7	205	262	257	54	105	94	16.3
A 1	55	1024.11	1.4	1.18	6.66	7	205	262	257	54	106	94	16.3
	60	1026.70											
	(1542)												
	0 - 60	V _m - 34.985		ΔH - 99									
													AVG. - 97.7

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagola Date 7/23/96 Test 1 Run 3
 Source No 2 Cyclone Outlet No. of traverse points 12
 Method 5 Filter holder: glass Filter type: glass fiber

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles: _____

Sample recovered by: _____

1
Duff

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	389	200	189
Impinger No. 3			
Condenser			
Desiccant	1414	1401	13
			-
Total			202

Integrated Gas Sampling Data:

Bag Pump No. 29A Box No. 19 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 5h (HRS) Time end: 1750 (HRS)
 Sampling rate: 400 cc/min Operator: DAH

S/N of O₂ Analyzer used to monitor train outlet: _____

4

U.S. EPA
(612) 786-6020

EPA Method 5 Field Data Sheet

Job L.P. Sample Pilot No. U23-5
 Source No. 2 Cyclonez Outlet Nozzle No. 6-3
 Date 01/23/96 Test Run 3 Meter Box No. 5 Bar. Press. 14.0 in. Hg
 Gasmeter Coeff. 1.0056 in. WC

Operators J.P. & J.C. Orifice Meter (in. WC) 1.80
 Velocity Head (in. WC) 1.80
 Sample Vol. (cf) 1.0056
 Des. Vol. (cf) 1.0056
 VAC. (in. Hg) 0

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)					Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.	Gas/In		Gas/Out
	(1645)	27.30	2.4	1.32	2.67	0	211	262	261	52	90	90	17.0
A 6	5	35.40	2.4	1.30	5.99	0	211	262	261	52	90	90	16.7
5	10	35.96	1.90	1.03	8.95	0	211	263	261	53	98	92	17.8
4	15	38.97	1.90	1.04	1.93	7	211	270	264	54	99	92	17.4
3	20	41.99	1.95	1.07	4.83	8	210	272	261	53	100	92	17.0
2	25	44.93	1.95	1.07	7.97	8	210	274	263	54	102	93	16.6
1	30	47.40	1.85	1.02	8.42	8	210	274	263	54	102	93	17.1
B 6	35	50.44	1.80	0.99	3.48	8	210	274	263	54	102	93	17.3
5	40	53.41	1.85	1.02	6.51	7	210	274	263	54	102	93	17.3
4	45	56.47	1.85	1.02	9.48	8	210	274	263	54	102	93	17.3
3	50	59.55	1.80	0.99	2.40	7	210	274	263	54	102	93	17.3
2	55	62.43	1.85	1.02	5.02	7	210	274	263	54	102	93	17.3
1	60	65.10	1.85	1.02	5.02	7	210	274	263	54	102	93	17.3
	(1750)												
	0.60	V _m = 35.80		ΔT = 1.00									
													AVG. = 96.7

EPA Method 7 Sampling Collection Field Data Sheet

Job LP Sagala Date 1-23-96 Bar Pressure 28.33 IN.HG
 Test Location No 2 Cyclone Outlet Fuel Type wood waste Sample Train No _____
 Technician J. Lorenz Pump No 36

No.	Test Run Point	Flask No.	Time (HRS)	Vacuum (IN.HG)	Flask Temp. (°F)	Leak Rate <0.4 IN.HG/MIN.	
						<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
1	2/1/1	55	12:34 ^{PM}	26.02	91	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
2	2/1/2	56	12:45	25.95	92	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
3	2/1/3	57	1:05 PM	26.03	90	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
4	2/1/1	58	1:19 PM	25.92	95	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
5	2/2/2	59	14:38	25.92	97	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
6	2/2/3	60	14:54	26.12	97	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
7	2/2/1	51 943	15:09	25.95	97	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
8	2/2/2	44	15:30	25.99	98	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
9	2/3/3	45	16:50	26.12	96	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
10	2/3/1	46	17:04	26.11	96	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
11	2/3/2	47	17:29	25.88	97	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
12	2/3/3	48	17:50	26.11	97	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
13						<input type="checkbox"/> YES	<input type="checkbox"/> NO
14						<input type="checkbox"/> YES	<input type="checkbox"/> NO
15						<input type="checkbox"/> YES	<input type="checkbox"/> NO
16						<input type="checkbox"/> YES	<input type="checkbox"/> NO
17						<input type="checkbox"/> YES	<input type="checkbox"/> NO
18						<input type="checkbox"/> YES	<input type="checkbox"/> NO
19						<input type="checkbox"/> YES	<input type="checkbox"/> NO
20						<input type="checkbox"/> YES	<input type="checkbox"/> NO
21						<input type="checkbox"/> YES	<input type="checkbox"/> NO
22						<input type="checkbox"/> YES	<input type="checkbox"/> NO
23						<input type="checkbox"/> YES	<input type="checkbox"/> NO
24						<input type="checkbox"/> YES	<input type="checkbox"/> NO
25						<input type="checkbox"/> YES	<input type="checkbox"/> NO
26						<input type="checkbox"/> YES	<input type="checkbox"/> NO
27						<input type="checkbox"/> YES	<input type="checkbox"/> NO


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. Songola
 Source Dryer Primary Cyclone Exhaust 3
 Test 1 Run Date 7-23-96
 Stack Dimen. 40 IN.
 Dry Bulb 153 °F Wet bulb 216 °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 28.33 IN.HG
 Static Pressure -9.0 IN.WC
 Operators EJURB Lee Hansen
 Pitot No. Taylor 4 C .840



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>9.5</u> IN.	Time Start: <u>0740</u> HRS		
A-1	<u>.044</u>	<u>1.76</u>	<u>11.26</u>	<u>.70</u>	
2	<u>.146</u>	<u>5.84</u>	<u>15.34</u>	<u>.83</u>	
3	<u>.296</u>	<u>28-11.84</u>	<u>21.34</u>	<u>1.2</u>	
4	<u>.704</u>	<u>28-16</u>	<u>37.66</u>	<u>2.0</u>	
5	<u>.854</u>	<u>34.16</u>	<u>43.66</u>	<u>2.12</u>	
6	<u>.956</u>	<u>38-24</u>	<u>47.74</u>	<u>2.0</u>	
B-1				<u>1.6</u>	<u>216</u>
2				<u>1.7</u>	
3				<u>1.8</u>	
4				<u>1.9</u>	
5				<u>2.1</u>	
6				<u>2.1</u>	
Temp. Meas. Device & S/N: <u>PDT 47 + 42</u>				Time End: <u>0755</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sangola Date 7-23-96 Test 1 Run 1
 Source Dier Primary Cyclone Exhaust 3 No. of traverse points 12
 Method 5 Filter holder: Glass Filter type: 4"CF

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 9 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8586

Recovery solvent(s)

Acetone
 Other(s) MECl₂ Imp Rinse

No. of probe wash bottles:

1
EJ

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	240	502	238
Impinger No. 3			
Condenser			
Desiccant	1481	1454	27
Total			265

Integrated Gas Sampling Data:

Bag Pump No. 29D Box No. 4 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1133 (HRS) Time end: 1328 (HRS)
 Sampling rate: 900 cc/min Operator: EJ

S/N of O₂ Analyzer used to monitor train outlet: 29B

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L. P. Samples Date 7-23-96 Test 1 Run 2
 Source Dryer Primary Cyclone Exhaust 3 No. of traverse points 12
 Method 5 Filter holder SS Filter type: SS + hi mbk

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 2.02 cfm at 18 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8639

Recovery solvent(s)

Acetone
 Other(s) MeCl₂ Imp Rinst

No. of probe wash bottles:

1

Sample recovered by:

EJ

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	649	497	152
Impinger No. 3			
Condenser			
Desiccant	1497	1473	24
Total			176

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 4 Bag No. 2
 Bag Material: 3-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1435 (HRS) Time end: 1529 (HRS)
 Sampling rate: 400 cc/min Operator: EJ

S/N of O₂ Analyzer used to monitor train outlet: 29B

EPA Method 5 Field Data Sheet

8-3

Pilot No. 7F-4

Job L.P. Spooler

Source Asst. Airway Galbar

Operators EJLH

Nozzle No. 189

C_p 11.0

Date 7-27-96 Test 1 Run 2

Meter Box No. 17 AI @ 1.73 in. WC

Bar. Press. 28.33 in. Hg

% 26

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity (ft/min, WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)								
							Stack	Probe	Oven	Insp.		Gas/in	Gas/Out						
A 6	5 (1435)	413.60	2.0	1.29	6.93	5.5	215	298	230	46	91	90	16.8						
3	10	416.86	1.80	1.19	0.19	5.5	213	282	241	49	94	90	16.5						
4	15	423.39	1.75	1.70	3.33	6	214	250	246	49	95	91	16.5						
3	20	426.47	2.0	1.26	6.68	6.5	213	246	253	51	97	91	16.5						
2	25	429.71	1.9	1.20	9.96	6.5	214	240	250	53	99	92	16.4						
1	30	432.90	1.60	1.01	2.98	7	215	242	250	50	99	92	16.8						
3	35	436.44	2.10	1.33	6.43	8	214	241	250	58	96	92	17.4						
5	40	439.88	2.0	1.27	9.80	8.5	212	238	247	50	97	92	17.0						
4	45	443.20	2.0	1.27	3.17	10	212	234	246	52	97	92	17.3						
3	50	446.44	2.1	1.33	6.62	5	213	236	242	55	96	92	17.0						
2	55																		
1	60 (1529)																		
	0-475	v _m - 31.18		2.21 ΔT															

475
475
475

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Scapla Date 7-23-96 Test 1 Run 3
 Source Ayer Primary Cyclone Exhaust No. of traverse points 12
 Method S Filter holder: SS Filter type: SS Thimble

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 20 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

2640

Recovery solvent(s)

Acetone
 Other(s) mecl₂ Imp. Rust

No. of probe wash bottles:

1
EJ

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	637	502	135
Impinger No. 3			
Condenser			
Desiccant	1510	1498	12
Total			147

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 4 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1645 (HRS) Time end: 1736 (HRS)
 Sampling rate: 400 cc/min Operator: EJ

S/N of O₂ Analyzer used to monitor train outlet: 29B

OPERATOR: [REDACTED] (612) 786-6020

EPA Method 5 Field Data Sheet

Job: C.P. Sangola Operators: [REDACTED] Pilot No.: TRFlam-6
 Source: Dryer Primary Cyclone Exhaust 3 Meter Box No.: 17 A11@ 1.73 in.WC Nozzle No.: 8-3
 Date: 7-23-86 Test Run: 3 Gasmeter Coeff.: 1.0032 Nozzle Dia.: .189 in. C_p: .840
 Bar. Press.: 26.33 in.Hg Gas/In: 11.0 Gas/Out: 24 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Inp.		Gas/In
A 6	(1645)	447.00	2.0	1.30	0.37	6	215	236	239	48	87	17.0
5	5	450.20	2.1	1.37	3.85	6	213	241	240	52	92	17.1
4	15	453.55	2.0	1.31	7.26	6.5	214	242	250	53	93	16.7
3	20	457.04	1.75	1.15	0.46	6	215	244	253	51	94	12.0
2	25	460.32	1.3	.83	3.22	5	214	246	252	53	94	17.2
1	30	465.79	1.1	.72	5.75	5	214	247	250	51	94	17.2
B 6	35	469.20	1.9	1.25	9.08	7	214	251	250	53	91	16.7
5	40	472.50	1.9	1.25	2.42	7	210	250	239	50	93	16.9
4	45	475.87	1.9	1.25	5.76	7.5	212	256	244	54	94	16.8
3	50											
2	55											
1	60											
(1736)												
0-45		V _m = 28.67		1.16								
				ΔFT =							Avg. =	90.0

EPA Method 7 Sampling Collection Field Data Sheet

Job L.P. Sagola Date 7-23-96 Bar Pressure 28.33 IN.HG
 Test Location Dryer Primary Cyclone Exhaust³ Fuel Type Natural Gas Sample Train No B1JR
 Technician EJ-LH Pump No 29


Box
5
7

No.	Test Run Point	Flask No.	Time (HRS)	Vacuum (IN.HG)	Flask Temp. (°F)	Leak Rate <0.4 IN.HG/MIN.	
1	2-1-A	25	1133	26.06	102	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
2	B	26	1240	26.03	102	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
3	C	27	1305	25.59	103	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
4	A	28	1324	25.82	103	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
5	2-2-B	29	1434	25.91	103	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
6	C	30	1440	25.60	103	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
7	A	37	1609	25.39	90	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
8	B	38	1528	26.20	90	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
9	2-3-C	39	1645	26.00	95	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
10	A	40	1700	25.82	95	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
11	B	41	1715	25.87	95	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
12	C	42	1730	25.54	95	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
13						<input type="checkbox"/> YES	<input type="checkbox"/> NO
14						<input type="checkbox"/> YES	<input type="checkbox"/> NO
15						<input type="checkbox"/> YES	<input type="checkbox"/> NO
16						<input type="checkbox"/> YES	<input type="checkbox"/> NO
17						<input type="checkbox"/> YES	<input type="checkbox"/> NO
18						<input type="checkbox"/> YES	<input type="checkbox"/> NO
19						<input type="checkbox"/> YES	<input type="checkbox"/> NO
20						<input type="checkbox"/> YES	<input type="checkbox"/> NO
21						<input type="checkbox"/> YES	<input type="checkbox"/> NO
22						<input type="checkbox"/> YES	<input type="checkbox"/> NO
23						<input type="checkbox"/> YES	<input type="checkbox"/> NO
24						<input type="checkbox"/> YES	<input type="checkbox"/> NO
25						<input type="checkbox"/> YES	<input type="checkbox"/> NO
26						<input type="checkbox"/> YES	<input type="checkbox"/> NO
27						<input type="checkbox"/> YES	<input type="checkbox"/> NO

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Sagola, MI
 Source 'E' Tube / Outlet
 Test 1 Run 0 Date 7-23-86
 Stack Dimen. 01.5 IN.
 Dry Bulb 155 °F Wet bulb 143 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.35 IN.HG
 Static Pressure -1.93 IN.WC
 Operators M. Kuehler + D. Holloman
 Pitot No. 4MS-B C₀ 04



Particulate

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>6.0</u> IN.	Time Start: <u>0907</u> HRS		
A - 1	.021	1.71	7.71 ML	1.17	
2	.067	5.46	11.46	1.20	
3	.119	9.62	15.62	1.18	
4	.177	14.43	20.43	1.15	
5	.250	20.39	26.39	1.09	
6	.356	29.01	35.01	1.17	
7	.644	52.49	58.49	1.29	
8	.750	61.13	67.13	1.47	
9	.823	67.07	73.07	1.43	
10	.892	71.88	77.88	1.25	↑
11	.933	76.04	82.04	1.15	
12	.979	79.79	85.79	1.14	155
B - 1				.98	
2				1.00	↓
3				1.05	
4				1.10	
5				1.12	
6				1.13	
7				1.17	
8				1.35	
9				1.40	
10				1.31	
11				1.25	
12				1.20	
Temp. Meas. Device & S/N: <u>PDT-45 / TC</u>				Time End: <u>0915</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagola, MI
~~Detroit, Michigan, IA~~ Date 2-23-96 Test 1 Run 1
 Source 'E' Tube / Outlet No. of traverse points 24
 Method 5 Filter holder: Glass Filter type: 4" G.F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 2.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

9431

Acetone
 Other(s) Me Li₂

No. of probe wash bottles:

1

Sample recovered by:

M. Kuehler + D. Hillman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	670	500	170
Impinger No. 2	20	0	20
Impinger No. 3			
Condenser			
Desiccant	1371	1360	11
Total			201 <u>TOT MK</u>

Integrated Gas Sampling Data:

Bag Pump No. 31B Box No. 1 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: ~~0930~~ 1133 (HRS) Time end: 1326 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kuehler

S/N of O₂ Analyzer used to monitor train outlet: 31A

IL... S, (612) 786-6020

EPA Method 5 Field Data Sheet

Job A.P. / Saginaw, MI Operator M. S. ... Meter Box No. 10 AH @ 1.93 in. WC Gasmeter Coeff. .9973
 Source E. T. ... / Outlet Nozzle No. 2-3 Pitot No. 4-015-8
 Date 7-23-96 Test 1 Run 1 Nozzle Dia. 1.00 in. C_p .84
 Bar. Press. 20.35 in. Hg H₂O 24 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
B-12	0930	537.20	1.07	1.03	0.96	5	156	240	243	44	20	20	12.3
11	2.5	538.91	1.27	1.98	0.34	4	158	251	239	43	23	20	12.3
10	5	540.41	1.38	1.07	1.78	4	156	251	239	43	22	21	12.5
9	10	541.84	1.29	1.00	3.18	4	156				23	21	12.5
8	12.5	543					157						
7	15												
6	17.5												
5	20												
4	22.5												
3	25												
2	27.5												
1	30												
A-12													
11													
10													
9													
8													
7													
6													
5													
4													
3													
2													
1													
	0 -	V _m -	ΔH -										

A B D R T

Down 18:37
12:15
10:00
12:01

EPA Method 5 Field Data Sheet

Job K.P. / Sagala, Mt Outlet Operator M. K. Schuler Nozzle No. 2-3 Pilot No. H-15-B
 Source E. 106 / Outlet Meter Box No. 10 Alt @ 1.93 in. WC Nozzle Dia. 1.08 in. C₁ 64
 Date 2-23-96 Test 1 Run 1 Gasmeter Coeff. 5923 Bar. Press. 28.35 in. Hg H₂O 24 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/In
11B-3	2.5	545.00	1.23	1.01	6.36	3	243	257	45	74	73	17.3
11	5	546.43	1.30	1.01	7.77	3				76	72	17.5
10	2.5	549.23	1.21	1.08	9.12	3	235	251	43	77	73	12.8
9	10	550.74	1.38	1.10	0.58	3.5	243	258	47	80	73	18.0
8	12.5	552.20	1.40	1.07	2.04	3.5				76	75	17.8
7	15	553.51	1.37	1.07	3.49	3.5				79	75	12.8
6	12.5	554.99	1.43	1.12	4.98	4	245	253	44	81	75	12.2
5	20	556.52	1.50	1.17	6.50	5				84	75	12.8
4	12.5	557.99	1.42	1.11	7.98	5	240	255	44	86	76	17.5
3	25	559.57	1.36	1.07	9.44	4.5				88	76	12.5
2	12.5	560.70	1.03	1.01	0.71	4	246	249	45	89	77	12.4
1	30	561.99	1.92	1.02	1.92	4				90	77	17.5
A-12	32.5	563.55	1.50	1.18	3.44	5	243	254	45	88	78	17.5
11	35	564.99	1.41	1.12	4.93	4				92	78	12.6
10	37.5	566.01	1.45	1.15	6.44	5	239	250	50	93	78	12.7
9	40	568.20	1.48	1.17	7.97	4.5				94	79	12.4
8	42.5	569.75	1.41	1.12	9.47	4	244	255	48	95	79	17.3
7	45	571.13	1.47	1.17	1.00	4.5				95	79	12.3
6	47.5	572.50	1.42	1.14	2.51	4	241	253	48	96	80	17.4
5	50	574.04	1.43	1.14	4.02	4				97	81	17.5
4	52.5	575.65	1.52	1.24	5.58	4.5	240	256	47	98	81	17.5
3	55	577.20	1.49	1.19	7.12	4				98	81	17.5
2	57.5	578.21	1.45	1.15	8.64	4	237	254	47	98	82	17.6
1	60	580.07	1.50	1.19	0.19	4				99	82	17.6
	(1326)											
	0-60	V _m = 35.07		1.09 ΔFT							AVG. = 82.9	

2000
1144
1144
1230

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job h.p. / Sayola, MI Date 7-23-96 Test 1 Run 2
 Source 'E' Tube / Outlet No. of traverse points 24
 Method 5 Filter holder: 6/acc Filter type: 4" G/F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8432

Recovery solvent(s)

Acetone _____
 Other(s) MeOH

No. of probe wash bottles:

1

Sample recovered by:

M. Kaehler + D. Hullemann

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	669	495	174
Impinger No. 2	20	0	20
Impinger No. 3			
Condenser			
Desiccant	1513	1500	13
Total			207 + 87 MK

Integrated Gas Sampling Data:

Bag Pump No. 31B Box No. 1 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1435 (HRS) Time end: 1539 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kaehler

S/N of O₂ Analyzer used to monitor train outlet: 51A

052394-GASTACKWPMFORMS-0046RR

INTERPOOL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job L.P. / Sample, M1
 Source E. Tobe / Outlet
 Date 2-23-96 Test 1 Run 2

Operators M. Kashalet & D. Holloman
 Meter Box No. 10
 Gas Meter Coeff. 1.93

Nozzle Dia. 1.93 in. WC
 Bar. Press. 29.35 in. Hg

Nozzle No. 2-3
 Pilot No. 4-105-5

C_p 1.04
 H₂O 20.9 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (L)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Stack	Temperatures (°F)			Gas/Out	Oxygen (% v/v)	
								Probe	Oven	Inp.			
A-12	1435	582.30											
11	2.5	583.108	1.42	1.20	3.84	4	159	237	244	43	82	83	17.4
10	5	585.47	1.45	1.21	5.39	4	164						
9	7.5	586.96	1.38	1.16	6.90	4	163	241	253	42	87	82	17.1
8	10	588.51	1.50	1.26	8.48	4	164	239	257	42	90	82	17.2
7	12.5	590.10	1.42	1.19	10.03	4	164	239	257	42	91	82	17.4
6	15	591.77	1.63	1.37	11.68	4.5	163	245	257	43	93	82	17.3
5	17.5	593.26	1.60	1.35	13.33	4.5	164	245	257	43	94	82	17.3
4	20	594.96	1.62	1.37	14.98	4.5	162	249	245	45	95	82	17.4
3	22.5	596.55	1.35	1.14	16.50	4	162	249	245	45	96	83	17.4
2	25	598.15	1.38	1.17	18.03	4	162	249	245	45	96	83	17.5
1	27.5	599.73	.97	1.02	19.32	3	161	243	249	45	97	83	17.5
	30	600.62	0.72	1.09	20.50	3	162	240	255	46	97	83	17.3
B-12	31.5	602.15	1.48	1.25	21.09	4.5	163	240	255	46	94	85	17.4
11	35	603.63	1.25	1.06	23.55	4	163	243	258	47	99	84	17.2
10	37.5	604.99	1.20	1.02	24.99	5	163	243	258	47	98	85	17.2
9	40	606.63	1.27	1.08	26.46	4.5	163	249	255	47	99	85	17.2
8	41.5	608.21	1.42	1.21	28.03	5	161	249	255	47	100	85	17.1
7	45	609.77	1.41	1.20	29.59	5	161	245	257	47	100	86	17.4
6	47.5	611.30	1.39	1.19	31.14	5	161	245	257	47	100	86	17.4
5	50	612.80	1.37	1.17	32.68	4.5	161	247	253	48	101	86	17.3
4	52.5	614.38	1.49	1.28	34.29	5	161	247	253	48	101	86	17.2
3	55	615.95	1.42	1.22	35.86	5	159	243	256	48	102	87	17.2
2	57.5	617.46	1.50	1.28	37.47	5	162	243	256	48	102	88	17.3
1	60	619.04	1.48	1.27	39.08	5	162	243	256	48	102	88	17.2
(1539)													
0-60		V _m = 36.74		1.17 ΔH _T							AVG. = 90.0		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagala, NY Date 7-13-96 Test 1 Run 3
 Source E. Inlet / Outlet No. of traverse points 24
 Method 5 Filter holder: Glass Filter type: 4" G.F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

0432

Recovery solvent(s)

Acetone
 Other(s) MeCl₂

No. of probe wash bottles:

1
M. Kachler + D. Hullemann

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	664	494	170
Impinger No. 2	40	0	40
Impinger No. 3			
Condenser			
Desiccant	1380	1371	9
Total			219 + 179 MK

Integrated Gas Sampling Data:

Bag Pump No. 31 B Box No. 1 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1045 (HRS) Time end: 1748 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kachler

S/N of O₂ Analyzer used to monitor train outlet: 31A

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job h.p. / Susquehanna
 Source E, Tube / Outlet
 Date 2-23-96 Test / Run 3

Operators Mr. Kenneth O. McElleman
 Meter Box No. 10 ΔH @ 1.93 in. WC
 Gas Meter Coeff. 0.9773

Nozzle No. 2-3
 Nozzle Dia. .108 in.
 Bar. Press. 29.35 in. Hg

Pilot No. 4MS-B
 C_p 1.04
 H₂O 20.9 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity (ft/min)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/In
13-12	1645	619.90	1.15	.98	1.30	3	159	243	256	43	94	17.5
11	2.5	621.25	1.27	1.07	2.76	3.5	159	243	256	43	94	17.5
10	2.5	624.05	1.30	1.10	4.24	4	159	247	251	44	96	17.4
9	10	625.55	1.27	1.07	5.70	4	160	239	246	44	98	17.4
8	12.5	627.12	1.35	1.14	7.21	4	159	239	246	44	99	17.4
7	15	628.71	1.44	1.22	8.77	4	159	243	255	45	91	17.4
6	17.5	630.33	1.41	1.20	0.31	4	158	243	255	45	92	17.6
5	20	631.97	1.49	1.27	1.91	4	158	244	257	45	93	17.5
4	22.5	633.61	1.51	1.28	3.51	4.5	158	244	257	45	94	17.4
3	25	635.22	1.45	1.23	5.08	4	159	249	251	47	95	17.5
2	27.5	636.79	1.53	1.31	6.70	4.5	157	249	251	47	96	17.4
1	30	638.37	1.48	1.26	8.29	4.5	157	245	256	48	96	17.4
A-12	32.5	639.98	1.57	1.33	9.93	4.5	160	245	256	48	92	17.0
11	35	641.63	1.39	1.18	1.46	4	161	241	257	48	96	17.3
10	37.5	643.20	1.42	1.21	3.02	4	161	241	257	48	97	17.2
9	40	644.84	1.47	1.25	4.61	4	163	245	253	49	98	17.3
8	42.5	646.27	1.56	1.32	6.24	4.5	163	245	253	49	99	17.3
7	45	647.99	1.68	1.43	7.94	5	163	241	250	51	99	17.3
6	47.5	649.69	1.50	1.28	9.54	4	163	241	250	51	100	17.4
5	50	651.27	1.54	1.31	1.17	4.5	163	237	254	51	100	17.4
4	52.5	652.93	1.51	1.28	2.78	4	164	237	254	51	100	17.5
3	55	654.49	1.46	1.24	4.37	4	164	240	255	50	101	17.5
2	57.5	655.05	1.15	.98	5.78	3.5	163	240	255	50	101	17.4
1	60	656.98	.28	.66	6.94	3	164	240	255	50	101	17.4
	(1748)											
	0-60	V _m - 37.08		1.19 ΔH -							AVG. - 99.2	

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP SAGULA
 Source DRYER LTD STACK
 Test 1 Run 0 Date 7-23-96
 Stack Dimen. 96.5 IN.
 Dry Bulb 252 °F Wet bulb 130 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.35 IN.HG
 Static Pressure -.54 IN.WC
 Operators S.B. / M.P.
 Pitot No. 427-5 C_p .84

Cross-section View	Elevation View
-----------------------	-------------------

** Particulate **

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
Port Length: _____ IN.			Time Start: _____ HRS		
A 1				.63	
2				.73	
3				.77	
4				.76	
5				.80	
6				.75	
7				.79	
8				.82	
B 1				.65	
2				.73	
3				.74	
4				.78	
5				.79	
6				.78	
7				.81	
8				.82	
				FPS = 60.76	
				AFPM = 185.162	
				DLEM = 98.741	
				NO _x 7	
				CO 192	

Temp. Meas. Device & S/N: PDT #2 Time End: _____ HRS

R or nothing = reg. manometer; S = expanded; E = electronic

LEAK CHECK PITOT

032594-G:STACK\WP\FORMS\IS-392.1

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/SAGULA Date 7-23-96 Test 1 Run 1
 Source ONYEN LTD STACK No. of traverse points 16
 Method 5/20² Filter holder: GLASS Filter type: GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN. HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

Acetone _____

Other(s) METH _____

No. of probe wash bottles: _____

1
38

Sample recovered by: _____

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	<u>744</u>	<u>502</u>	<u>242</u>
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	<u>1500</u>	<u>1485</u>	<u>15</u>
Total			<u>257</u>

Integrated Gas Sampling Data:

Bag Pump No. B6 Box No. 21 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: 0 cc/min at 15 IN. HG
 Time start: 11 32 (HRS) Time end: 12 31 (HRS)
 Sampling rate: 400 cc/min Operator: SB

S/N of O₂ Analyzer used to monitor train outlet: _____

Job No. 027-5

Source DRYER LTD STACK

Date 7-23-96 Test 1 Run 1

Operator LP S960LA

Meter Box No. 5 MP

Gas Meter Coeff. 1.79

in. WC 0.9764

Bar. Press. 28.35

in. Hg 24

in. Hg 24.5

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

in. Hg 24

EPA Method 5 Field Data Sheet

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Inp.		Gas/In	Gas/Out
A 1	(1132)	393.33	1.00	1.78	6.38	7	271	247	231	48	80	80	17.5
2	8	396.37	1.10	2.00	9.68	10	254	245	231	49	81	79	17.5
3	12	399.63	1.20	2.18	3.13	10	256	251	230	42	80	80	17.3
4	16	403.10	.65	1.17	5.66	6	263	250	231	42	80	80	17.4
5	20	405.60	.77	1.39	8.41	7	262	252	229	45	84	80	17.1
6	24	408.38	.75	1.36	1.14	7	260	247	230	47	86	80	17.2
7	28	411.13	.76	1.39	3.91	7	256	245	232	50	80	80	17.1
8	32	413.92	.60	1.10	6.36	5	256	246	230	51	89	84	17.2
1	36	416.40	.80	1.46	9.19	7	256	246	233	55	87	81	17.3
2	40	419.20	.78	1.43	2.00	7	255	245	238	56	90	82	17.3
3	44	422.96	.79	1.45	4.83	7	258	247	237	57	90	82	17.0
4	48	427.56	.75	1.37	7.58	7	259	250	235	58	91	82	17.0
5	52	430.30	.77	1.40	0.36	7	267	248	236	41	92	83	17.1
6	56	433.12	.78	1.42	3.16	7	263	249	237	43	93	83	17.2
7	60	435.91	.76	1.42	5.97	7	265	250	235	44	93	84	17.3
8	64	438.63	.73	1.33	8.68	7	265	250	236	45	94	84	17.3
	(1531)												
	64	V _m = 46.7		1.046									
				AVG.									84.3

1142
0.0001
10.250

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / BAGOLA Date 7-23-96 Test C Run 2
 Source DRYER RTD STACK No. of traverse points 16
 Method 5/20² Filter holder: GLASS Filter type: GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN. HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

Acetone _____

Other(s) MCTA

No. of probe wash bottles: _____

Sample recovered by: _____

SB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	714	475	239
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1440	1435	5
Total			244

Integrated Gas Sampling Data:

Bag Pump No. 66
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1135
 Sampling rate: 400

Box No. 21 Bag No. 2
 Size: 14 L
 cc/min at 15 IN. HG
 (HRS) Time end: 1540 (HRS)
 cc/min Operator: SB

S/N of O₂ Analyzer used to monitor train outlet: _____

EPA Method 5 Field Data Sheet

Job: L.P. / Saginaw Nozzle No.: 5-2 Pilot No.: U27-5
 Source: DMYER RD STARK Nozzle Dia.: 0.245 in. C_p: 0.89
 Date: 7-23-76 Test: Run 2 Bar. Press.: 28.35 in.Hg H₂O: 2.8 %

Operators: S.D. / M.F.
 Meter Box No.: 15 Air @ 1.74 in.WC
 Gas Meter Coeff.: 0.9964

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/In
B	(14 35 7)	(430.90)	.76	1.26	1.55	6	262	273	232	56	83	16.8
	4	441.50	.80	1.31	4.24	6	268	271	235	57	83	16.7
	8	444.19	.77	1.28	6.88	6	263	270	234	58	83	17.0
	12	446.85	.79	1.30	9.56	6	267	265	237	42	83	17.0
	16	449.55	.77	1.27	2.21	6	269	249	241	47	83	16.9
	20	452.25	.78	1.30	4.89	6	265	257	242	46	84	17.2
	24	454.89	.75	1.25	7.52	6	265	253	240	48	84	17.0
	28	457.51	.62	1.04	7.93	5	259	252	241	49	85	16.9
A	32	459.90	.84	1.41	2.72	6	260	250	243	51	85	16.9
	36	462.68	.86	1.45	5.56	7	257	254	247	53	86	17.0
	40	465.50	.84	1.42	8.36	7	257	253	246	54	86	16.9
	44	468.35	.70	1.18	0.93	6	258	255	249	44	86	16.9
	48	470.93	.75	1.26	3.58	6	262	253	250	45	86	17.0
	52	473.60	.80	1.35	6.32	7	261	252	250	47	87	16.8
	56	476.32	.74	1.24	8.94	6	265	254	251	46	87	16.8
	60	478.95	.62	1.04	1.35	5	265	253	250	49	87	16.8
64	481.33											
	(1540)											
	0 - 64	V _m - 42.41		1.27								
				ΔH -								
											AVG. -	88.6

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/SAGOLA Date 7-23⁹⁶ Test 1 Run 3
 Source PAPER REO STACK No. of traverse points 16
 Method 5/100² Filter holder: GLASS Filter type: GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____ Recovery solvent(s) _____
 _____ Acetone _____
 _____ Other(s) MCT _____

No. of probe wash bottles: _____
 Sample recovered by: JD
 Condensate Data: _____

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	771	509	262
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1472	1463	9
Total			271

Integrated Gas Sampling Data:

Bag Pump No. B6 Box No. 21 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1645 (HRS) Time end: 1751 (HRS)
 Sampling rate: 400 cc/min Operator: JB

S/N of O₂ Analyzer used to monitor train outlet: _____

IL 1 RA S,
(612) 786-6020

EPA Method 5 Field Data Sheet

Job LP / SAGOLA
Source OMER RTO STACK
Date 7-23-98 Test 1 Run 3

Operators S.B. / m.p.
Meter Box No. 15 Alt @ 1.77 in. WC
Gas meter Coeff. 7764

Nozzle No. 5-2
Nozzle Dia. 22-45 in.
Bar. Press. 28.35 in. Hg

Pilot No. U27-5
C_p .84
H₂O 23 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Insp.		Gas/In	Gas/Out
A 1	(0645) 4	(481.60) 484.50	.84	1.58	4.55	7	260	245	247	48	86	86	17.1
2	8	487.51	.86	1.61	7.53	7	257	246	250	49	89	85	17.2
3	12	490.37	.80	1.50	0.41	7	261	247	247	51	91	85	17.2
4	20	493.27	.80	1.49	3.28	7	264	246	249	52	93	85	17.1
5	20	496.10	.77	1.44	6.11	7	257	245	251	53	94	85	17.2
6	24	498.93	.79	1.49	8.98	7	257	245	250	54	95	86	17.1
7	28	501.80	.76	1.44	1.81	7	257	247	251	56	96	86	17.2
8	32	504.43	.86	1.25	4.45	6	258	246	251	57	96	86	17.0
B 1	36	507.34	.80	1.51	7.35	7	260	252	257	41	94	87	17.1
2	40	510.22	.79	1.49	0.22	7	259	255	260	42	97	88	16.8
3	44	513.10	.80	1.51	3.13	7	260	257	262	42	97	88	16.6
4	48	515.90	.78	1.46	5.98	7	268	254	260	44	98	88	16.9
5	52	518.78	.79	1.48	8.86	7	267	255	261	45	98	88	16.8
6	56	521.65	.78	1.46	1.71	7	268	257	260	47	98	89	16.8
7	60	524.45	.75	1.42	4.53	7	261	256	262	48	99	89	16.8
8	64	527.34	.75	1.42	7.35	7	263	258	261	49	99	89	16.8
	(1750)												
	0.64	V _m - 45.74		1.42 ΔIT -									
													AVG. - 90.9


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Sagala
 Source Primary Cyclone Exhaust #1
 Test 4 Run 0 Date 7-24-96
 Stack Dimen. 40 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 28.33 IN.HG
 Static Pressure -9.0 IN.WC
 Operators SB/SF
 Pitot No. V22.5 C_p 0.84



CH₂O

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
Port Length: <u>6</u> IN.			Time Start: _____ HRS		
<u>A</u>	<u>1</u>	<u>.032</u>	<u>1.28</u>	<u>7.28</u>	
	<u>2</u>	<u>.105</u>	<u>4.20</u>	<u>10.20</u>	
	<u>3</u>	<u>.194</u>	<u>7.74</u>	<u>13.74</u>	
	<u>4</u>	<u>.323</u>	<u>12.72</u>	<u>18.72</u>	
	<u>5</u>	<u>.677</u>	<u>27.08</u>	<u>33.08</u>	
	<u>6</u>	<u>.906</u>	<u>32.24</u>	<u>38.24</u>	
	<u>7</u>	<u>.995</u>	<u>35.80</u>	<u>41.80</u>	
	<u>8</u>	<u>.960</u>	<u>38.72</u>	<u>44.72</u>	
Temp. Meas. Device & S/N: <u>DIGITAL TC - PDT 40</u>				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP/Sagola Date 7-24-96 Test 4 Run 1

Source Perry Cyclone Exhaust #4 No. of traverse points 16

Method 0011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.00 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone

Other(s) MeCl₂

No. of probe wash bottles: _____

Sample recovered by: _____

SUB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	663	464	199
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1513	1493	20
Total			219

Integrated Gas Sampling Data:

Bag Pump No. 22A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.00
 Time start: 1710
 Sampling rate: 400

Box No. 2 Bag No. 1
 Size: 44 L
 cc/min at 16 IN.HG
 (HRS) Time end: 1828 (HRS)
 cc/min Operator: S

S/N of O₂ Analyzer used to monitor train outlet: 8

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

W/Sagala

Job Primary Cyclone Exhaust A1 Nozzle No. 4-3 Pilot No. V22-5
 Date 7-24-96 Test 4 Run 1 Meter Box No. 27 ΔH@ 1.87 Nozzle Dia. .189 in. C₀
 Gasmeter Coeff. 1.0027 Bar. Press. 28.53 in. Hg 11.0 0.87 %
 Operators SE/38 in. WC 24 in. Hg 24 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (L)	Velocity Head (ft. WC)	Orifice Meter (ft. WC)	Des. Vol. (L)	VAC. (ft. Hg)	Temperatures (°F)						Oxygen (% v/v)
							Stack	Probe	Oven	Imp.	C ₀ /A ₀	Gas/Out	
A-8	(1710)	(966.25)	1.70	1.22	8.80	7	228	254	NA	49	83	18.5	
7	4	968.74	1.65	1.17	1.28	8	228	254		47	83	18.7	
5	12	973.80	1.75	1.24	3.85	9	230	244		48	83	18.8	
5	16	970.42	1.80	1.28	6.46	9	229	244		48	83	18.9	
4	20	979.00	1.80	1.28	2.08	9	220	244		48	81	18.9	
3	24	981.70	1.90	1.36	1.78	10	227	244		48	83	18.9	
2	28	984.30	1.90	1.36	4.48	10	228	246		47	84	18.7	
1	32	987.29	2.05	1.48	2.29	11	227	248		46	85	18.7	
B-2	26	989.99	1.85	1.34	9.97	10	225	244		46	84	17.9	
7	40	992.70	1.70	1.22	2.53	11	226	244		47	86	18.1	
6	44	995.04	1.60	1.15	5.01	10	228	244		47	86	18.4	
5	48	997.91	1.70	1.22	7.57	10	230	246		47	86	18.2	
4	52	1000.43	1.70	1.22	0.13	10	230	246		47	84	18.1	
3	56	1002.81	1.70	1.21	2.68	9	236	244		48	87	18.1	
2	60	1005.38	1.80	1.30	5.33	9	225	248		49	87	18.3	
1	64 (1728)	1007.90	1.75	1.26	7.93	9	231	247		49	86	17.7	
	0-64	V _m - 41.65		ΔH - 1.27									
											Avg. - 90.4		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Sagala Date 7-24-96 Test 4 Run 2
 Source Primary Cyclone Exhaust #1 No. of traverse points 16
 Method 0011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.00 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 Other(s) MeCl₂ _____

No. of probe wash bottles: 1

Sample recovered by: SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	679	471	208
Impinger No. 3			
Condenser			
Desiccant	1383	1355	28
Total			236

Integrated Gas Sampling Data:

Bag Pump No. 22A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.00
 Time start: 1915
 Sampling rate: 400

Box No. 2 Bag No. 2
 Size: 44 L
 cc/min at 16 IN.HG
 (HRS) Time end: 2020 (HRS)
 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 8

EPA Method 5 Field Data Sheet

Job: LP/Soyola Source: Zimmerman System Exhaust #1 Test: 4 Run: 2 Operator: SF/SB
 Date: 7-24-96 Meter Box No. 13 ΔH @ 1.84 in. WC Des. Vol. (cc) 1.084
 Nozzle No. 4-3 Nozzle Dia. .189 in. Bar. Press. 28.33 in. Hg. Pilot No. V22-5
 C₁₀ 0.84 % C₁₀ 22 %

Inverse Point No.	Sampling Time (min)	Sample Vol. (cc)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cc)	VAC. (in. Hg)	Temperatures (°F)				Gas/Out	Oxygen (% v/v)	
							Slack	Probe	Oven	Imp.			
B-8	(1915)	(1008.60)	1.85	1.33	1.24	9	227	245	N/A	47	87	86	18.1
7	4	1011.26	1.75	1.24	3.83	9	232	246		49	90	85	18.2
6	8	1013.89	1.65	1.17	6.33	9	232	246		48	92	86	18.2
5	12	1014.45	2.00	1.42	9.08	9	231	246		48	93	85	18.6
4	16	1019.07	2.05	1.46	1.87	9	233	246		47	95	85	18.6
3	20	1021.77	2.15	1.52	4.72	10	236	246		47	97	85	18.8
2	24	1024.64	2.10	1.51	7.56	11	234	247		47	98	85	18.9
1	28	1027.37	2.10	1.49	0.39	11	235	245		50	98	86	18.4
A-8	32	1030.39	1.70	1.21	2.94	11	235	246		50	97	86	18.4
7	36	1032.99	1.75	1.25	5.53	10	234	246		51	98	86	18.4
6	40	1035.82	1.70	1.22	8.09	9	231	244		50	98	86	18.4
5	44	1038.25	1.60	1.15	0.57	9	230	244		50	97	84	18.0
4	48	1040.64	1.75	1.25	3.17	10	231	240		50	100	86	18.2
3	52	1043.09	1.80	1.29	5.80	11	229	241		50	100	86	18.6
2	56	1045.72	1.75	1.26	8.41	11	227	244		50	101	86	18.2
1	60	1048.34	1.85	1.34	1.09	11	227	244		50	101	87	18.2
	64	1051.00											
	(2020)												
		V _m - 42.40		ΔH - 1.32							AVG - 91.1		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP-SAGOLA Date 7-24-96 Test 4 Run 3
 Source #1 PRIMARY CYCLONE EXHAUST No. of traverse points 16
 Method 0011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.00 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

acetone
 Other(s) MeCl₂

No. of probe wash bottles:

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	629	421	208
Impinger No. 3			
Condenser			
Desiccant	1578	1555	23
Total			231

Integrated Gas Sampling Data:

Bag Pump No. 22A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 00
 Time start: 2040
 Sampling rate: 400 CC

Box No. 2 Bag No. 3
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 2144 (HRS)
 cc/min Operator: SCB

S/N of O₂ Analyzer used to monitor train outlet:

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job: LP-SAGOLA
 Source: #1 PRIMARY EXHAUST
 Date: 7-24-96 Test 4 Run 3
 Operators: SUBPBF
 Meter Box No. 13
 Gasmeter Coeff. 1.84
 Nozzle No. 4-3
 Nozzle Dia. .787 in.
 Bar. Press. 28.37 in.Hg
 Pilot No. V22-5
 C_p .840
 H₂O 2/

Inverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		C./ft	Gas/Out
A-8	(2010)	(1051.74)	1.50	1.09	4.16	10	233	249	N/A	48	89	86	18.4
7	8	1054.20	1.60	1.16	6.64	10	234	249		48	91	86	18.4
6	12	1059.10	1.60	1.16	9.12	10	235	248		49	94	86	18.4
5	16	1061.70	1.55	1.14	1.60	10	232	249		50	94	85	18.3
4	20	1064.17	1.70	1.25	4.15	10	222	251		51	96	85	18.3
3	24	1066.70	1.65	1.21	6.74	10	225	251		50	96	85	18.2
2	28	1069.20	1.55	1.14	9.21	10	225	250		50	97	85	18.2
1	32	1071.60	1.55	1.14	1.68	10	224	250		51	98	85	18.6
B-8	36	1074.24	1.60	1.18	4.20	10	227	251		52	76	85	18.4
7	40	1076.80	1.75	1.28	6.82	10	227	254		51	96	85	18.4
6	44	1079.49	1.70	1.25	9.10	10	228	254		51	97	85	18.7
5	48	1081.99	1.65	1.21	4.95	11	220	254		51	98	85	18.4
4	52	1084.49	1.55	1.14	4.42	10	224	254		50	98	85	18.7
3	56	1086.99	1.65	1.22	6.98	10	222	254		49	98	86	18.6
2	60	1089.50	1.70	1.26	9.58	10	224	254		48	98	85	18.7
1	64	1092.18	1.70	1.26	2.18	10	223	256		48	98	85	18.6
	(2144)												
	0-64	v _m - 40.44		ΔH - 1.19							AVG	90.5	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. Saggio
Source No 2 Cyclone Outlet
Test 4 Run Date 7/24/96
Stack Dimen. 4.5 IN.
Dry Bulb _____ °F Wet bulb _____ °F
Manometer Reg. Exp Elec.
Barometric Pressure 29.33 IN.HG
Static Pressure 8.6 IN.WC
Operators J. Van Hoever & J. Lorenz
Pitot No. V23-5 C .84

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	IN.	Time Start:	HRS
A 1					
2					
3					
4					
5					
6					
B 1					
2					
3					
4					
5					
6					
Temp. Meas. Device & S/N: <u>POT #35</u>				Time End:	HRS

R or nothing A (reg) manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagola Date 7/24/96 Test 4 Run 1
 Source No 2 Cyclone Outlet No. of traverse points 12
 Method Coil Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN. HG (vac)
 Post test: 0 cfm at 9 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 other(s) MeCl₂ & DI H₂O

No. of probe wash bottles: _____

Sample recovered by: _____

Condensate Data: _____

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	346	200	146
Impinger No. 3			
Condenser			
Desiccant	1525 ^{not} 1335	1515 ^{not} 1317	10 18
Total			^{not} 156 164

Integrated Gas Sampling Data:

Bag Pump No. 29a Box No. 29 Bag No. 1
 Bag Material: 3-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN. HG
 Time start: 1715 (HRS) Time end: 1830 (HRS)
 Sampling rate: 400 cc/min Operator: DAI

S/N of O₂ Analyzer used to monitor train outlet: 4

NILE L L RA LS,
 (612) 786-6020
EPA Method 5 Field Data Sheet
 Job L.P. Seyala
 Source No. 2 Cyclone Outlet
 Date 7/24/96 Test 4 Run 1
 Operators DeW & J.C.
 Meter Box No. 5 ΔH @ 1.80 in.WC
 Gasmeter Coeff. 1.0056
 Nozzle No. 6-3
 Nozzle Dia. 1.129 in.
 Bar. Press. 28.33 in.Hg
 Pilot No. U23-5
 C_p 284
 H₂O 24 %

Inverse Point No.	Sampling Time (min)	Sample Vol. (l)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (l)	VAC. (in.Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)
							Probe	Oven	Imp.	Stack			
B 6	1710	170.83	2.0	1.10	3.88	6	205	257	NA	53	97	88	16.7
5	5	173.87	2.0	1.09	6.93	6	207	258		54	98	90	16.7
4	10	176.80	2.0	1.09	9.88	6	212	258		54	98	90	16.9
3	15	179.96	1.8	.99	2.90	6	204	261		57	100	90	17.6
2	20	182.88	1.70	.93	5.72	6	214	261		57	101	90	17.0
1	25	185.84	1.3	.71	8.19	5	214	261		53	101	91	17.2
A 6	30	188.20	2.05	1.12	1.29	6	214	264		53	96	90	17.8
5	35	191.91	2.1	1.15	4.42	6	209	261		57	100	91	17.7
4	40	194.46	2.0	1.09	7.48	6	212	261		57	101	91	17.7
3	45	197.47	2.05	1.12	0.59	6	212	261		57	101	91	16.8
2	50	200.51	1.55	.84	3.27	6	227			102	102	91	17.3
1	55	203.93	1.05	.57	5.50	6	211			101	101	91	16.9
	60	205.56											
	(1830)												
	0-60	V _m - 341		ΔH - 98									
													Avg. - 94.8

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Seale Date 7/24/86 Test 4 Run 2
 Source No 2 Cyclone Outlet No. of traverse points 12
 Method MD11 Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 11 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____ Recovery solvent(s) _____

Acetone _____
 Other(s) MeCL₂ & DI H₂O

No. of probe wash bottles: _____

Sample recovered by: _____

1
DWH

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>400</u>	<u>200</u>	<u>220</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1510</u>	<u>1504</u>	<u>6</u>
Total			<u>226</u>

Integrated Gas Sampling Data:

Bag Pump No. 29a Box No. 29 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: 0 cc/min at 14 IN.HG
 Time start: 1920 (HRS) Time end: 2016 (HRS)
 Sampling rate: 400 cc/min Operator: DWH

S/N of O₂ Analyzer used to monitor train outlet: 4

(612) 786-6020

EPA Method 5 Field Data Sheet

Job Source Date: L.P. Sagola
No. 2 Cyclone Outlet
1/24/96 Test U Run 2

Operators: DWH + J.C.
Meter Box No. 5 Alt @ 1.80 in. WC
Gas meter Coeff. 1.0056

Nozzle No. 6-3
Nozzle Dia. .179 in.
Bar. Press. 28.33 in. Hg

Pilot No. 123-5
C_p .84
W₂ .22

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Slack	Probe	Oven	Imp.		Gas/Out	
A 1	1915	206.60	2.10	1.23	4.87	5	211	257	NA	47	89	89	18.0
A 5	5	209.91	2.0	1.17	2.98	5	205	257	NA	47	94	90	17.8
A 4	10	212.99	2.0	1.22	6.21	5	209	259		49	96	90	17.2
A 3	15	216.27	2.0	1.22	9.13	5	207	261		49	98	90	16.4
A 2	20	219.26	1.70	1.0	2.05	5	206	261		53	99	91	16.9
A 1	25	222.13	1.45	1.84	4.76	5	206	262		53	99	91	16.8
B 6	30	224.86	2.0	1.29	8.09	6	206	262		53	100	91	16.8
B 5	35	228.10	2.0	1.18	1.26	6	206	262		53	100	92	16.7
B 4	40	231.40	1.70	1.99	4.19	6	211	262		54	100	92	17.5
B 3	45	234.07	1.60	1.94	7.04	6	205	264		54	100	92	16.2
B 2	50	237.07	1.45	1.94	9.89	6	205	264		54	100	92	16.2
B 1	55	239.76	1.45	1.86	2.60	6	205	264		54	99	92	16.2
	60	242.65											
		V _m - 36.05		ΔT - 1.06								Avg. - 94.2	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagola Date 7/24/96 Test 4 Run 3
 Source No 2 Cyclone Outlet No. of traverse points 12
 Method DD11 Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac) X
 Post test: 0 cfm at 10 IN. HG (vac) X

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
~~Other(s)~~ MeCl₂ + DIH₂O

No. of probe wash bottles: _____

Sample recovered by: _____

DWH

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		<u>S</u>	
Impinger No. 2	<u>314</u>	<u>200</u>	<u>114</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1344</u>	<u>1335</u>	<u>9</u>
Total	<u>XXXXXX</u>		<u>183</u>

Integrated Gas Sampling Data:

Bag Pump No. 29A Box No. 29 Bag No. 3
 Bag Material: 3-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 14 IN.HG
 Time start: 2044 (HRS) Time end: 2142 (HRS)
 Sampling rate: 400 cc/min Operator: DWH

S/N of O₂ Analyzer used to monitor train outlet: 4

052394-GASTACKWPF-FORMSS-00-6RR


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. Saigala
 Source Dryer Primary Cyclone Exhaust 3
 Test 4 Run Date 7-24-96
 Stack Dimen. 40 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.33 IN.HG
 Static Pressure -9.0 IN.WC
 Operators E. J. Jurs + Leo Hansen
 Pitot No. TAF-6 C_p .840
CH₂O



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: _____ IN.		Time Start: _____ HRS	
A 1	.044	1.76	11.26		
2	.146	5.84	15.34		
3	.246	11.84	21.34		
4	.704	29.16	37.66		
5	.854	34.16	43.66		
6	.956	38.24	47.74		
B 1					
2					
3					
4					
5					
6					
Temp. Meas. Device & S/N:				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job C.P. Sagola Date 7-24-96 Test 4 Run 1
 Source Dryer Primary Cyclone Exhaust 3 No. of traverse points 12
 Method 0011 Filter holder: — Filter type: —

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 11 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

Acetone _____
 Other(s) DI, nCl₂

No. of probe wash bottles: _____

Sample recovered by: _____

ES

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	656	475	181
Impinger No. 2	502	473	29
Impinger No. 3			
Condenser			
Desiccant	1529	1515	14
Total			224

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 5 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1710 (HRS) Time end: 1828 (HRS)
 Sampling rate: 400 cc/min Operator: ES

S/N of O₂ Analyzer used to monitor train outlet: 29B

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

8-3

Nozzle No. 189
Nozzle Dia. in. 28.33
Bar. Press. 29

Pilot No. 78-6
C_p H₂O 29

Job L.P. Sagoles
Source Dry Primary Systems Exhaust 3
Date 7-24-96 Test 4 Run 1

Operators ES, CF
Meter Box No. 17AH@ 1.73
Gasmeter Coeff. 1.0037

Inverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity (ft/min)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)
							Stack	Probe	Oven	Imp.	
6	(1710) 5	599.20	2.15	1.41	2.72	7	240	-	45	85	16.7
5	10	602.49	1.9	1.21	5.99	7	239	-	46	85	16.6
4	15	605.75	1.9	1.22	9.27	8	241	-	49	85	17.2
3	20	609.20	2.0	1.29	2.64	8	243	-	51	85	17.4
2	25	612.34	1.9	1.22	5.93	8	235	-	53	85	17.1
1	30	614.73	1.7	1.10	9.05	8	240	-	51	86	17.1
6	35	619.10	2.2	1.43	2.60	9	240	-	52	87	17.3
5	40	622.67	2.1	1.36	6.08	9	241	-	53	85	17.3
4	45	626.28	2.0	1.31	2.42	8	246	-	54	88	17.7
3	50	629.73	1.8	1.17	2.72	7.5	243	-	55	88	12.6
2	55	633.05	1.7	1.11	5.85	7	240	-	50	89	17.9
1	60	636.14	1.6	1.05	8.90	7	240	-	51	89	17.9
	(1820)	639.20									
	0-60	V _m = 40		ΔH = 1.2						Ave = 88.7	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagola Date 7-24-96 Test 4 Run 2
 Source Dryer Primary Cyclone Exhaust 3 No. of traverse points 12
 Method 0011 Filter holder: _____ Filter type: _____

Sample Train Leak Check:
 Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 14 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____ Recovery solvent(s)
 acetone _____
 other(s) DI, meCl₂

No. of probe wash bottles: _____
 Sample recovered by: ES LH

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	499	472	27
Impinger No. 2	685	472	213
Impinger No. 3			
Condenser			
Desiccant	1510	1498	12
Total			252

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 5 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1915 (HRS) Time end: 2015 (HRS)
 Sampling rate: 400 cc/min Operator: ES

S/N of O₂ Analyzer used to monitor train outlet: 29B

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

8-3

Pilot No. 2EFL-6

Nozzle No. 8-3

Operator L.P. Sagola

Meter Box No. 17

Job L.P. Sagola

Nozzle Dia. .189 in.

Altitude 173 in.WC

Source Dryer Primary Cyclone Exhaust 3

Date 7-27-96 Test 4 Run 2

Bar. Press. 28.33 in.Hg

Gastmeter Coeff. 1.0032

Gas/In 92

Gas/Out 87

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Dis. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)
							Stack	Probe	Oven	Imp.			
A 6	5 (1915)	639.90	2.2	1.49	3.53	7	223	234	-	48	87	16.8	
3	10	653.39	2.1	1.42	7.07	8.5	221	238	-	48	87	16.8	
4	15	667.1	1.9	1.29	0.45	8	222	240	-	49	87	17.0	
3	20	653.76	1.8	1.22	3.74	8	222	243	-	51	87	16.8	
2	25	657.07	1.8	1.22	7.04	8	221	239	-	53	87	17.2	
1	30	660.17	1.6	1.09	0.14	7.5	221	240	-	55	88	16.8	
B 6	35	663.67	2.0	1.36	3.62	9	222	240	-	50	88	17.0	
5	40	667.07	2.0	1.36	7.04	9	224	243	-	50	87	17.4	
4	45	670.38	1.4	1.22	0.38	8.5	223	241	-	51	87	17.4	
3	50	673.74	1.9	1.29	3.76	9	223	246	-	49	88	17.8	
2	55	677.07	1.8	1.22	7.07	8.5	224	255	-	50	88	17.7	
1	60 (2015)	680.29	1.6	1.08	0.15	8	224	250	-	52	88	17.8	
							Avg. -				89.5		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Sagola Date 7-24-86 Test 4 Run 3
 Source Dryer Primary Cyclone Exhaust 3 No. of traverse points 12
 Method 001 Filter holder: _____ Filter type: _____

Sample Train Leak Check:
 Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 10 IN. HG (vac)

Particulate Catch Data:
 No. of filters used: _____ Recovery solvent(s)

 acetone _____
 other(s) DI, MeCl₂

No. of probe wash bottles: _____
 Sample recovered by: ES LH
 Condensate Data: _____

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	662	471	191
Impinger No. 2	510	467	43
Impinger No. 3			
Condenser			
Desiccant	1497	1486	11
Total			245

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 5 Bag No. 3
 Bag Material: 3-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 2040 (HRS) Time end: 2140 (HRS)
 Sampling rate: 400 cc/min Operator: ES

S/N of O₂ Analyzer used to monitor train outlet: 29B

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job C.P. Singola Operators EJ CJH Nozzle No. 8-3 Pilot No. TRF-6
 Source Boyer Primary Spillars Street 3 Meter Box No. 17 AH @ 1.73 in. WC Nozzle Dia. .189 in. 876
 Date 7-24-96 Test # 4 Run # 3 Gasmer Coeff. 1.0037 Bar. Press. 28.33 in. Hg. 11.0 % 23

Inverse Point No.	Sampling Time (min)	Sample Vol. (cl)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cl)	VAC. (in. Hg)	Temperatures (°F)				Gas/Out	Oxygen (% v/v)		
							Probe	Oven	Imp.	Cas/In				
	(2040)	680.80												
B 6	5	684.13	2.0	1.33	4.23	7		240	N/A	46	86	86	17.2	
5	10	687.48	1.9	1.25	7.54	7		243		49	86	86	16.9	
4	15	690.80	1.7	1.13	0.70	7		239		49	87	87	17.2	
3	20	693.94	1.6	1.06	3.76	7		240		51	87	87	17.3	
2	25	697.04	1.6	1.19	7.00	7		243		52	86	86	17.2	
1	30	700.08	1.7	1.12	0.16	7		243		53	87	87	17.4	
A 6	35	703.65	2.1	1.39	3.67	9		236		50	87	87	17.3	
5	40	707.10	2.1	1.39	7.18	9		235		51	86	86	17.1	
4	45	710.55	2.0	1.32	0.59	9		234		47	86	86	17.3	
3	50	713.90	1.8	1.19	3.84	8.5		236		49	85	85	12.5	
2	55	716.98	1.7	1.12	6.99	8		240		51	86	86	17.8	
1	60	719.96	1.5	99	9.96	6		222	↓		90	86	17.8	
	(2140)													
	0-60	V _m - 39.18		1.21							AVR -	88.0		

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / SAGOLA
 Source DRYER KTO STACK
 Test 4 Run 0 Date 7-24-96
 Stack Dimen. 96.5 IN.
 Dry Bulb 26.0 °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.35 IN.HG
 Static Pressure -.54 IN.WC
 Operators J.B. - M.P.
 Pitot No. V27-5 C. 84

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
Port Length: <u>5.5</u> IN.			Time Start: <u>1600</u> HRS		
A 1				.61	
2				.72	
3				.75	
4				.90	
5				.73	↑
6				.80	
7				.81	
8				.79	
B 1				.67	260
2				.71	↓
3				.74	
4				.80	
5				.76	
6				.81	
7				.84	
8				.80	
Temp. Meas. Device & S/N: <u>POT # 2</u>				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/SAGOLA Date 7-24-96 Test 4 Run 1
 Source DRYER RTU STACK No. of traverse points 16
 Method 001 Filter holder: _____ Filter type: _____

Sample Train Leak Check:
 Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:
 No. of filters used: _____

Recovery solvent(s)
 acetone _____
 other(s) _____

No. of probe wash bottles: _____
 Sample recovered by: SB
 Condensate Data: _____

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	802	579	223
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1512	1470	42
Total			265

Integrated Gas Sampling Data:

Bag Pump No. B6 Box No. 17 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1710 (HRS) Time end: 1830 (HRS)
 Sampling rate: 400 cc/min Operator: SB

S/N of O₂ Analyzer used to monitor train outlet: _____

612) 786-6020

EPA Method 5 Field Data Sheet

Job L.P./SAGOLA Source OXFORD STACK Date 7-24-96 Test 4 Run 1
 Operators SS-/M.P. Meter Box No. 4 ΔH @ 1.78 in.WC Gasmeter Coeff. .9957
 Nozzle No. 270 Glass 077-5 Pilot No. 077-5
 Nozzle Dia. .270 in. C_p .84
 Bar. Press. 28.31 in.Hg H_0 23 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)					Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.	Gas/In		Gas/Out
A 1	(1810) 4	(742.79) 946.02	.74	1.99	6.07	10	260	240	273	41	70	69	
2	8	949.40	.78	2.08	9.42	10	259	250	272	40	71	70	
3	12	952.81	.82	2.18	2.85	10	254	251	270	41	72	70	
4	16	956.25	.86	2.29	6.36	11	260	249	273	42	72	70	
6	20	959.80	.81	2.17	9.78	10	257	250	271	44	73	71	
6	24	963.16	.78	2.09	3.14	10	258	251	272	45	73	71	
7	28	966.50	.80	2.14	6.54	10	258	250	270	46	73	71	
8	32	969.95	.83	2.21	0.00	10	260	252	270	47	74	72	
A 1	36	973.61	.86	2.30	3.53	11	259	254	268	49	73	72	
2	40	977.09	.84	2.23	7.00	10	263	252	271	51	94	73	
3	44	980.45	.79	2.10	0.36	10	265	250	267	52	75	73	
4	48	983.98	.85	2.27	3.88	11	263	253	269	54	75	73	
5	52	987.50	.87	2.30	7.42	11	264	257	265	56	76	73	
6	56	990.01	.86	2.30	0.95	11	261	257	267	47	76	73	
7	60	994.50	.83	2.22	4.42	11	263	260	268	42	76	73	
8	64	997.81	.77	2.04	7.75	11	269	258	268	43	76	74	
	(1830)	-0.11 Losses AT POINT 4											
		(997.70)											
	0.64	V _n - 54.91		2.16 ΔH									
													Avg. - 72.7

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/SABVOLA Date 7-24-96 Test 4 Run 2
 Source DMYON RTD STACK No. of traverse points 16
 Method 0011 Filter holder: _____ Filter type: _____

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____

other(s) _____

No. of probe wash bottles: _____

Sample recovered by: _____

SB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	740	579	219
Impinger No. 2	192	100	92
Impinger No. 3			
Condenser			
Desiccant	1505	1486	19
Total			330

Integrated Gas Sampling Data:

Bag Pump No. B6 Box No. 17 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1915 (HRS) Time end: 2025 (HRS)
 Sampling rate: 400 cc/min Operator: S.B.

S/N of O₂ Analyzer used to monitor train outlet: _____

ELI. L. RAIS, (612) 786-6020

EPA Method 5 Field Data Sheet

Operators LP / SAGOLA
 Meter Box No. 4 $\Delta H @ 1.78$ in. WC
 Gas meter Coeff. 1.78

Nozzle No. 6455
 Nozzle Dia. 0.70 in.
 Bar. Press. 28.31 in. Hg

Pilot No. V27-5
 C_p 0.84
 H_2O 22 %

Job LP / SAGOLA
 Source PM2.5 TO STACK
 Date 7-24-96 Test 4 Run 2

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Inp.		Gas/In	Gas/Out
1	(1915) 4	(998.45) 1002.01	.88	2.40	2.05	8	260	242	255	41	73	73	
2	8	1005.50	.82	2.21	5.51	8	270	250	262	42	75	73	
3	12	1008.94	.79	2.13	8.91	8	270	254	267	44	76	77	
4	16	1012.47	.86	2.33	2.46	8	268	261	270	46	78	74	
5	20	1016.10	.88	2.39	6.07	8	268	265	273	47	79	74	
6	24	1019.60	.85	2.31	9.62	8	267	264	271	48	80	74	
7	28	1023.15	.84	2.30	3.16	8	262	263	270	48	82	75	
8	32	1026.40	.82	2.09	6.42	8	260	267	268	49	83	76	
1	36	1029.80	.76	2.60	7.81	8	260	268	271	50	84	76	
2	40	1033.37	.85	2.31	3.37	8	272	270	268	53	85	77	
3	44	1037.00	.86	2.42	7.22	8	267	267	269	55	87	88	
4	48	1040.50	.79	2.14	0.48	8	266	271	265	42	88	99	
5	52	1044.06	.84	2.32	9.06	8	266	268	267	43	89	80	
6	56	1047.54	.80	2.22	7.56	8	263	266	269	44	90	81	
7	60	1051.00	.78	2.17	1.04	8	262	264	270	46	89	81	
8	64	1054.59	.81	2.26	4.57	8	261	267	268	47	88	81	
	(2025)												
	0.64	$V_m - 56.14$		2.26 $\Delta H -$									
													AVG. 77.1

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / SAGMO Date 7-24-96 Test 4 Run 3
 Source DRYER TO STACK No. of traverse points 16
 Method 00N Filter holder: _____ Filter type: _____

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____

other(s) _____

No. of probe wash bottles: _____

Sample recovered by: _____

SB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	807	587	220
Impinger No. 2	151	51	100
Impinger No. 3			
Condenser			
Desiccant	1498	1477	21
Total			341

Integrated Gas Sampling Data:

Bag Pump No. SB Box No. 17 Bag No. 3
 Bag Material: 3-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 2040 (HRS) Time end: 2142 (HRS)
 Sampling rate: 400 cc/min Operator: SB

S/N of O₂ Analyzer used to monitor train outlet: _____

U.S. ENVIRONMENTAL PROTECTION AGENCY
(612) 786-6020

EPA Method 5 Field Data Sheet

Job LP / Stryker Pilots No. 027-S
 Source OWNER'S STACK C_p -84
 Date 2-24-96 Test U Run 3 H₂O 83


Operators DL Nozzle No. 01433
 Meter Box No. 4 Nozzle Dia. 2.70 in.
 Gasmeter Coeff. 1.78 Bar. Press. 28.31 in.Hg

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Gas/ft ³	Gas/Out	Oxygen (% v/v)	
							Probe	Oven	Imp.	Gas/In				
A 1	6040 4	(1055.22) 1056.58	.76	2.05	8.66	8	232	259	43	79	79	79	8	
2	6	1062.10	.84	2.27	2.08	8	237	264	44	79	79	79	8	
3	12	1065.68	.84	2.27	5.60	8	241	267	44	81	81	79	8	
4	16	1067.05	.80	2.15	4.04	8	245	271	45	81	81	79	8	
5	20	1072.44	.77	2.07	2.42	8	243	270	46	81	81	79	8	
6	24	1075.81	.79	2.14	5.84	8	244	269	47	81	81	79	8	
7	28	1079.28	.80	2.17	9.25	8	245	270	48	82	82	78	8	
8	32	1082.65	.76	2.06	2.65	8	247	271	49	82	82	78	8	
B 1	36	1086.02	.84	2.27	6.18	8	246	270	50	80	80	78	8	
2	40	1089.63	.80	2.16	9.61	8	248	269	51	82	82	79	8	
3	44	1093.11	.82	2.23	3.11	8	249	271	52	82	82	79	8	
4	48	1096.60	.84	2.28	6.64	8	250	271	53	82	82	79	8	
5	52	1100.05	.80	2.17	0.09	8	249	270	54	82	82	79	8	
6	56	1103.64	.85	2.31	3.65	8	247	269	55	82	82	79	8	
7	60	1107.00	.74	2.01	6.97	8	250	270	56	82	82	79	8	
8	64	1110.24	.72	1.96	0.25	8	250	269	58	87	87	79	8	
	(2142)													
	0.64	V _{in} - 55.02		2.16 ΔH -										
										Avg. -		80.0		

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Sagola, MI
 Source Press RTD / Stack
 Test 5 Run 0 Date 7-25-86
 Stack Dimen. 76 IN.
 Dry Bulb 255 °F Wet bulb 108 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.45 IN.HG
 Static Pressure - .27 IN.WC
 Operators M. Kuehler + D. Hillman
 Pitot No. 415-B C₁ 184



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	<u>4</u> IN.	Time Start:	<u>NA</u> HRS
<u>Refer to test 7</u>					
<u>for pts and flows</u>					
Temp. Meas. Device & S/N: <u>PDT-45/12</u>				Time End: <u>NA</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagala, MI Date 2-25-96 Test 5 Run 1
 Source Press RTU / stack No. of traverse points 20
 Method MDI Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 5 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

~~Toluene~~
~~Diacetone~~ Toluene
~~Other(s)~~ Acetonitrile

No. of probe wash bottles:

0

Sample recovered by:

M. Kuehler + D. Helleman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	521	540	(19)
Impinger No. 2	397	407	(10)
Impinger No. 3			
Condenser			
Desiccant	1353	1340	13
Charcoal	1445	1410	35
Total			19

Integrated Gas Sampling Data:

Bag Pump No. 31B Box No. 22 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1620 (HRS) Time end: 1700-2035 (HRS)
 Sampling rate: 150 cc/min Operator: M. Kuehler

S/N of O₂ Analyzer used to monitor train outlet: NA

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job: L.P. / Sample - 1 Operator: M. Cassinelli / P. Holloman Nozzle No.: A-3 Pilot No.: 4MS-B
 Source: Pass AFO / Stack Meter Box No.: 10 In. WG: 1.93 Nozzle Dia.: 1.81 in. C_p: 1.04
 Date: 2-25-96 Test: S Run: 1 Bar. Press.: 28.45 in. Hg H₂O: 2.9 %

Oxygen	Temperatures (°F)						Gas/Out	Oxygen
	Stack	Probe	Oven	Imp.	Gas/In	Gas/Out		
████████	████████	████████	████████	████████	████████	████████	████████	████████
A-10	255	230	253	46	88	89	20.4	
9	255	237	260	45	89	88		
8	256	241	257	45	91	87		
7	257	236	245	44	93	87		
6	255	229	247	45	94	87		
5	255	230	244	47	95	88		
4	255	237	257	47	96	87		
3	260	240	250	46	97	86		
2	254	235	250	48	98	88		
1	253	238	247	48	99	88		
A-10	254	241	240	49	100	88		
9	254	245	245	50	100	89		
8	251	240	247	57	100	89		
7	252	235	252	57	101	89		
6	252	231	251	47	101	89		
5	250	237	255	46	101	90		
4	251	230	247	46	102	91		
3	257	227	246	44	102	91		
2	256	236	241	47	103	91		
1	258	235	249	48	103	91		
						AVG. - 93.2	████████	

V_m = 29.0 ΔH = 1.24
29.01

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Saginaw, MI Date 2-25-96 Test 5 Run 2
 Source Press RTD / Stack No. of traverse points 20
 Method MDI Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 6 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

NA

~~Acetone~~ Toluene
~~Other(s)~~ Acetonitrile

No. of probe wash bottles:

0
Mikaehler & P. Hullemann

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	561	577	(16)
Impinger No. 2	410	473	(3)
Impinger No. 3			
Condenser			
Desiccant	1487	1485	2
Charcoal	1452	1419	33
Total			16

Integrated Gas Sampling Data:

Bag Pump No. 31B Box No. 22 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1800 (HRS) Time end: 1900-2055 (HRS)
 Sampling rate: 150 cc/min Operator: Mikaehler

S/N of O₂ Analyzer used to monitor train outlet:

NA

052394-C:\STACK\WP\FORMS\S-0046RR

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job A.P. / Sepola, MI Operator M. Luchalar + D. Appelman Nozzle No. 1-3 Pilot No. 4M5-8
 Source Press #10 / Stack Meter Box No. TOA110A93 in.WC 101 in. 101 C_p .84
 Date 2-25-86 Test 5 Run 2 Gasmeter Coeff. 2845 in.Hg 2.845 H₂O 3.3 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
A-10	1:00	260.40	.57	.51	3.12	2	256	210	256	45	91	91	20.9
9	3	262.25	.74	.66	3.51	2.5	259	237	257	43	92	90	/
8	6	263.57	.77	.69	4.93	2.5	256	246	250	44	95	89	/
7	9	264.94	.75	.68	6.34	2.5	253	244	251	44	95	89	/
6	12	266.35	.89	.81	7.87	2.5	251	241	247	47	96	89	/
5	15	269.46	.83	.75	9.35	2.5	252	235	253	46	97	89	/
4	18	270.93	.80	.72	0.80	2.5	255	233	255	47	98	89	/
3	21	272.22	.88	.80	2.33	2.5	253	241	254	48	99	89	/
2	24	273.66	.79	.71	3.77	2.5	256	239	254	47	100	89	/
1	27	275.31	.72	.65	5.15	2.5	257	246	253	45	101	90	/
10	30	276.27	.58	.52	6.39	2	260	240	250	46	101	90	/
9	33	277.45	.69	.62	7.74	2.5	259	237	255	46	101	90	/
8	36	279.15	.78	.70	9.18	3	259	230	247	48	101	90	/
7	39	280.74	.91	.83	0.74	3	253	226	244	50	102	91	/
6	42	282.31	.82	.75	2.21	3	255	240	250	51	102	91	/
5	45	283.53	.84	.76	3.71	3	255	243	253	52	102	91	/
4	48	285.31	.89	.81	5.25	3	251	242	255	50	102	91	/
3	51	286.53	.64	.58	6.56	2	255	235	247	51	103	92	/
2	54	288.00	.80	.73	8.05	3	254	240	244	53	103	92	/
1	57	289.57	.78	.71	9.47	3	254	242	238	54	103	91	/
	(1900)												
0 - 60	V _m -	28.67	ΔH ₁ -	.70									
												AVG. -	94.6



Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sayala, MI Date 7-25-96 Test 5 Run 3
 Source Process RTD / Stack No. of traverse points 20
 Method M01 Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 5 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

~~None~~ Toluene
 Other(s) Acetonitrile

No. of probe wash bottles:

Sample recovered by:

Condensate Data:

Item	[REDACTED]		Difference
	Pre	Post	
Impinger No. 1	523	540	(17)
Impinger No. 2	392	410	(18)
Impinger No. 3			
Condensate			
Desiccant	1355	1340	15
Charcoal	1402	1445	37
Total	[REDACTED]		17

Integrated ~~Gas~~ Sampling Data:

Bag Pump No. 31 B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1620/935
 Sampling rate: 150

Box No. 22 Bag No. 2
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 1720/55 (HRS)
 cc/min Operator: M. Kessler

S/N of O₂ Analyzer used to monitor train outlet:

NA

EPA Method 5 Field Data Sheet

Job E.P. / Sample 1-1
Source Press 1270 / Stack
Date 2-25-96 Test 5 Run 3

Operators M. Kachalick & D. Hellebrand
Meter Box No. 10A1@ 1.93 in. WC
Gasmeter Coeff. 1.9973

Nozzle No. 1-3
Nozzle Dia. 1.81 in.
Bar. Press. 29.55 in. Hg

Pitot No. 405-8
C_p 1.24
H₂O 1.0 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity I-head (ft./min)	Orifice Meter (ft. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
A-10	1935	291.20	.67	.61	2.53	2	255	247	253	53	92	91	20.7
9	3	292.57	.81	.74	4.00	3	253	250	250	52	93	91	
8	6	294.13	.89	.81	5.53	3	253	239	251	50	95	90	
7	9	295.37	.85	.78	2.03	3	254	247	255	46	96	90	
6	12	297.00	.88	.80	1.76	3	255	245	260	47	98	90	
5	15	298.50	.87	.80	0.08	3	255	240	261	47	99	89	
4	18	300.01	.92	.84	1.65	3	254	243	259	44	99	89	
3	21	301.60	.82	.75	3.83	3	254	242	253	48	100	89	
2	24	303.21	.79	.72	4.18	3	255	250	247	50	101	89	
1	27	304.50	.75	.68	0.00	3	255	245	252	51	101	90	
10	30	306.13	.72	.66	4.32	3	255	245	256	49	101	90	
9	33	307.49	.81	.74	1.80	3	253	246	251	46	101	90	
8	36	308.95	.75	.68	4.32	3	253	247	243	46	101	90	
7	39	310.51	.83	.76	1.80	3	256	247	243	46	101	90	
6	42	311.84	.80	.73	3.27	3	260	239	247	46	102	90	
5	45	313.29	.85	.78	4.78	3	261	246	249	47	102	90	
4	48	314.64	.80	.73	6.25	3	267	246	250	48	102	91	
3	51	316.11	.75	.68	7.72	3	257	247	246	48	102	91	
2	54	317.29	.75	.68	9.19	3	254	247	244	49	102	91	
1	57	318.99	.65	.60	10.66	3	253	238	239	49	102	91	
1	60	320.30	.57	.52	12.13	3	253	235	248	50	102	91	
	(2035)												
	0 - 60	V _m = 29.10		ΔH = .72								Avg. = 94.8	

EPA Method 4 and 6 Field Data Sheet

Job LP SAGULA
 Source PINES NTU 2-LET
 Date 7-25-96 Test 6 Run 1
 Wet Bulb _____
 Dry Bulb 126

Operator(s) SB / mp
 Meter Box No. 4 Gasmeter Coef. 9968
 $\Delta H@$ 1.78 in.WC Bar.Press 28.45 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC
 Post Test: 0 cfm at 10 in.WC

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1620)	303.88									
	5	312.60	1.78	5					80	78	
	10	316.32							80	78	
	15	320.04							81	79	
	20	323.76							81	79	
	25	327.48							82	79	
	30	331.19							81	80	
	35	334.91							82	79	
	40	338.63							82	79	
	45	342.35							82	80	
	50	346.07							83	80	
	55	349.79							83	80	
	60	353.51							83	80	
	(1720)										
	0-60	V _m = 44.63	$\Delta P = 1.78$		126				F _m = 80.75		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers	361	346	15
Condenser	297	290	7
Desiccant	1438	1424	14
		Total	36

Preliminary Results of SO ₂ Concentration Determination	
V _m =	41.43 DSCF
Moisture Gravimetric =	4.53 3.93 %v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

EPA Method 4 and 6 Field Data Sheet

Job LP SAGOLA
 Source PRESS RTG IMPLER
 Date 7-25-96 Test 6 Run 2
 Wet Bulb _____
 Dry Bulb 126

Operator(s) SB/MP
 Meter Box No. 4 Gasmeter Coef. 9964
 $\Delta H@$ 1.78 in.WC Bar.Press 28.45 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC
 Post Test: 0 cfm at 10 in.WC

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/In	Gas/Out	
	(1800)	356.48									
	5	360.57	1.78	5					80	80	
	10	364.65							80	80	
	15	368.74							80	80	
	20	372.82							80	80	
	25	376.91							80	80	
	30	380.99							81	80	
	35	385.08							82	80	
	40	389.16							83	80	
	45	393.25							83	80	
	50	397.33							83	80	
	55	401.42							83	80	
	60	405.50							83	80	
	(1900)								83	80	
	0.60	V _m = 49.02	$\Delta H = 1.78$		126				80.75		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers	360	346	14
Condenser	292	290	2
Desiccant	1530	1517	13
		Total	29

Preliminary Results of SO ₂ Concentration Determination	
V _{std} =	45.51 DSCF
Moisture Gravimetric =	2.91 %v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

EPA Method 4 and 6 Field Data Sheet

Job LP SAGOLA
 Source PNCSJ RTO F-40T
 Date 7-25-96 Test 6 Run 3
 Wet Bulb _____
 Dry Bulb 126

Operator(s) 36 IMP
 Meter Box No. 4 Gasmeter Coef. 1.9968
 $\Delta H@$ 1.79 in.WC Bar.Press 28.45 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC
 Post Test: 0 cfm at 10 in.WC

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/In	Gas/Out	
	1935	406.33									
	5	410.28	1.78	5					78	77	
	10	414.24							78	77	
	15	416.19							78	77	
	20	422.14							79	77	
	25	426.10							79	77	
	30	430.05							79	77	
	35	434.00							81	77	
	40	437.96							81	78	
	45	441.91							81	79	
	50	445.86							81	79	
	55	449.82							81	79	
	60	453.77							81	79	
	2035										
	0.60	V _m = 47.44	$\Delta F = 1.78$		126				F _m = 78.75		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers	367	344	23
Condenser	290	289	1
Desiccant	1418	1413	5
		Total	29

Preliminary Results of SO ₂ Concentration Determination	
V _m = 44.20	DSCF
Moisture Gravimetric = 3.00	%v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Sagala, MI
 Source Press WTD / Starch
 Test 6 Run 0 Date 7-25-98
 Stack Dimen. 20 IN.
 Dry Bulb 255 °F Wet bulb 100 °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 28.45 IN.HG
 Static Pressure -.27 IN.WC
 Operators M. Kachler + D. Killeman
 Pitot No. 314-6 C. 04



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	4 IN.	Time Start: <u>NA</u> HRS	
1	1/6	12.67	16.67		
2	3/6	38.00	42.00		
3	5/6	63.33	67.33		
Temp. Meas. Device & S/N: <u>PDT-31/Te</u>				Time End: <u>NA</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagala, NY Date 2-25-96 Test 6 Run 1
 Source Pres RTD / Sted No. of traverse points 3
 Method Phenol Filter holder: NA Filter type: 1A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acstone _____

other(s) _____

No. of probe wash bottles:

NA

Sample recovered by:

M. Kachlen + D. Hoffman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant			
Total			

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____

Box No. _____

Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____

IN.HG

Time start: _____

(HRS) Time end: _____

(HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job L.P. / Sagala, M.
 Source Pres. ATO / Stack
 Date 7-25-86 Test 6 Run 1
 Wet Bulb _____
 Dry Bulb _____

Operator(s) M. Kaelin + D.H. Haman
 Meter Box No. 14 Gasmeter Coef. .9929
 $\Delta H@$ 1.82 in.WC Bar.Press 29.45 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC
 Post Test: 0.2 cfm at 7 in.WC

Trav. Point No.	Sample Time (min)	Sample Volume (ci)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	1620	979.90									
A-3	5	983.91	1.82	4	255	243	250	49	79	78	20.9
3	10	987.98	1.82	4	257	247	253	46	80	78	
3	15	992.01	1.82	4	255	255	249	46	80	78	
3	20	996.05	1.82	4	250	241	244	47	85	78	
2	25	999.67	1.82	4	253	237	251	46	84	79	
2	30	1003.28	1.82	4	260	240	253	46	91	79	
A-2	35	1007.14	1.82	4	254	243	255	47	92	79	
2	40	1011.00	1.82	4	255	237	250	49	93	80	
1	45	1014.94	1.92	4	260	234	256	50	94	80	
1	50	1018.87	1.92	4	253	233	251	50	95	81	
1	55	1023.29	1.92	4	251	240	250	49	96	82	
1	60	1027.71	1.92	4	252	241	245	51	96	82	↓
	(1720)										
	0-60	V _m = 47.81	ΔP = 1.82		255				E = 84.39		

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers SA	311	295	16
Condenser SB	292	292	-
Desiccant	1352	1340	12
		Total	28

Preliminary Results of SO ₂ Concentration Determination	
V _{nd} = 43.44	DSCF
Moisture Gravimetric = 2.91	%v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagala, MI Date 7-25-76 Test 6 Run 2
 Source Press RTO / Stack No. of traverse points 3
 Method Phenol Filter holder: NA Filter type: NA

Sample Train Leak Check:
 Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 2 IN. HG (vac)

Particulate Catch Data:

No. of filters used: NA Recovery solvent(s)
 acetone _____
 other(s) _____

No. of probe wash bottles: NA
 Sample recovered by: M. Koehler + D. Hallemann

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant		1493	
Total			

Integrated Gas Sampling Data: NA / Ambient

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 14 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job L.P. / Sagala MI
 Source Press RTD / Stack
 Date 7-25-96 Test 6 Run 7
 Wet Bulb _____
 Dry Bulb _____

Operator(s) M. Kuchler & D. H. Herman
 Meter Box No. 17 Gasmeter Coef. .9929
 $\Delta H@$ 1.02 in.WC Bar.Press 28.45 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC
 Post Test: 0.02 cfm at 7 in.WC

Trav. Point No.	Sample Time (min)	Sample Volume (cf)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/ In	Gas/ Out	
	1900	27.90									
B-3	5	31.83	1.02	4	252	243	250	253	82	82	20.9
3	10	35.76	1.02	4	254	237	253	50	85	82	
3	15	39.65	1.02	4	251	240	249	46	87	82	
3	20	43.62	1.92	4	255	245	247	48	89	82	
2	25	47.55	1.02	4	255	250	253	48	92	82	
2	30	51.49	1.02	4	255	246	250	47	92	82	
2	35	55.42	1.02	4	253	240	248	47	93	82	
2	40	59.44	1.02	4	257	233	247	49	94	82	
1	45	63.05	1.02	4	254	238	251	49	94	82	
1	50	67.86	1.02	4	256	235	255	48	94	82	
1	55	72.06	1.02	4	253	241	256	46	95	83	
1	60	76.27	1.02	4	255	242	257	46	95	84	↓
	(1900)										
	0-66	V _m = 48.37	$\Delta H = 1.02$		254						86.63

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impingers 6A	318	304	14
Condenser 6B	300	298	2
Desiccant	1509	1493	16
		Total	32

Preliminary Results of SO ₂ Concentration Determination	
V _m = 44.32	DSCF
Moisture Gravimetric = 3.29	%v/v
Moisture Psychrometric =	%v/v
SO ₂ DRY =	PPM
SO ₂ WET =	PPM
LB/MMBtu =	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagola MI

Date 7-25-96 Test 6 Run 3

Source Process NTO / Sturb

No. of traverse points 3

Method Phenol Filter holder: NA

Filter type: NA

Sample ⁰²⁷⁰ Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

NA

acetone _____

other(s) _____

No. of probe wash bottles:

0

Sample recovered by:

W. Kachler + P. H. Hemmen

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant			
Total			

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____

Box No. _____ Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____ IN.HG

Time start: _____

(HRS) Time end: _____ (HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-GASTACKWPAFORMSS-0046RR

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 4 and 6 Field Data Sheet

Job L.P. / Sapola, MI
 Source Process RTA / S. Fresh
 Date 7-25-96 Test 6 Run 3
 Wet Bulb _____
 Dry Bulb _____

Operator(s) Michael + D. Hilleman
 Meter Box No. 14 Gasmeter Coef. 1.9929
 $\Delta H@$ 1.02 in.WC Bar.Press 28.45 in.Hg
 Sample Train Leak Check:
 Pretest: < 0.02 cfm at 15 in.WC
 Post Test: 0.02 cfm at 7 in.WC

Trav. Point No.	Sample Time (min)	Sample Volume (cc)	Orif. Meter (in.WC)	Vac. in.Hg	Temperatures (°F)						O ₂ (%v/v)
					Stack	Probe	Oven	Impg.	Gas/In	Gas/Out	
	1935	77.93									
B-3	5	81.96	1.02	4	255	253	250	48	94	93	20.9
3	10	85.99	1.02	4	255	227	255	45	97	93	1
3	15	89.92	1.02	4	253	231	257	45	90	92	
3	20	93.95	1.02	4	256	235	251	46	93	92	
2	25	97.93	1.02	4	254	240	247	47	95	92	
L	30	101.90	1.02	4	251	241	244	46	95	92	
2	35	105.98	1.02	4	253	240	247	46	96	93	
L	40	109.96	1.02	4	257	245	248	48	96	93	
1	45	113.93	1.02	4	260	244	251	50	96	94	
1	50	117.91	1.02	4	259	239	253	51	97	94	
1	55	121.78	1.02	4	257	237	256	52	97	94	
1	60	125.76	1.02	4	255	235	254	54	97	94	
	(2035)										
	0-60	V _m = 47.93	ΔP = 1.02		255				F = 88.29		

Condensate Data:


Item	Weight (g)		
	Final	Tare	Difference
Impingers 2A	314	296	18
Condenser 2B	299	296	3
Desiccant	1364	1352	12
		Total	33

Preliminary Results of SO ₂ Concentration Determination	
V _m = 43.78	DSCF
Moisture Gravimetric = 3.43	%v/v
Moisture Psychrometric =	%v/v
SO ₂ , DRY =	PPM
SO ₂ , WET =	PPM
LB/MMBtu =	

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job h.p. / Sagola MI
 Source Press 1170 / Street
 Test 7 Run Date 7-24-96
 Stack Dimen. 76 IN.
 Dry Bulb 75.5 °F Wet bulb 100 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.31 IN.HG
 Static Pressure -.27 IN.WC
 Operators M. Kuchler + D. Hilleman
 Pitot No. 4MSB C₀ 00



* Particulate *

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: <u>4</u> IN.			Time Start: <u>1810</u> HRS		
A-1	.066	1.87	5.87	.162	
2	.082	5.90	9.90	.173	
3	.146	10.51	14.51	.190	
4	.226	16.27	20.27	.197	
5	.342	24.62	28.26	.194	
6	.658	47.38	51.38	.183	
7	.774	55.73	59.73	.178	
8	.854	61.49	65.49	.168	↑
9	.918	66.10	70.10	.158	
10	.974	70.13	74.13	.157	255
B-1				.161	↓
2				.170	
3				.181	
4				.183	
5				.174	
6				.180	
7				.175	
8				.164	
9				.157	
10				.155	
Temp. Meas. Device & S/N: <u>PDT-45/TC</u>				Time End: <u>1915</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagola, MI Date 2-24-96 Test 7 Run 1
 Source Press RTO / STACK No. of traverse points 20
 Method 5 Filter holder: Glass Filter type: 4" G.F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

0472

Acetone
 Other(s) MeCl₂

No. of probe wash bottles:

1

Sample recovered by:

M. Kaehler + D. Hultman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	519	494	25
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1500	1485	15
Total			40

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

L. P. / Sagala, MI
 (612) 786-6020

EPA Method 5 Field Data Sheet

Job: L.P. / Sagala, MI Operator: M. Koehler + D. Hollenman Pilot No.: 401-3
 Source: Press / ATO stands Meter Box No.: 10 ΔH@ 1.93 in.WC Nozzle No.: 2-4
 Date: 7-24-96 Test: 7 Run: 1 Gasmeter Coeff.: .9973 Bar. Press.: 28.31 in.Hg Nozzle Dia.: 2.51 in.
 % 8 % 2.5

Traverse Point No.	Sampling Time (min)	Sample Vol. (cl)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cl)	VAC. (in.Hg)	Temperatures (°F)				Gas/Out	Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.			
A-10	1935	040.70	.63	1.88	1.00	4	255	233	253	50	79	78	20.9
1	3	051.13	.60	1.79	3.24	3.5	262	227	243	47	81	77	
2	6	053.30	.67	2.00	5.62	4	261	238	242	46	85	77	
3	9	055.71	.78	2.35	8.21	4	256	241	242	45	87	77	
4	12	058.27	.81	2.43	0.81	4.5	259	243	250	46	90	77	
5	15	060.90	.74	2.23	3.36	4	259	239	256	48	93	78	
6	18	063.41	.73	2.21	5.88	4	257	237	249	45	93	78	
7	21	065.97	.84	2.54	8.58	4.5	260	246	257	46	95	79	
8	24	068.75	.83	2.51	1.26	4.5	262	245	240	47	97	80	
9	27	071.44	.63	1.92	3.61	3.5	257	240	237	47	97	80	
B-10	30	073.28	.60	1.83	5.91	3.5	257	237	244	46	97	82	
1	33	075.97	.65	1.97	8.30	4	262	241	240	46	99	82	
2	36	078.43	.90	2.73	1.11	5	263	248	235	48	100	82	
3	39	081.19	.88	2.67	3.89	5	263	251	241	48	102	83	
4	42	083.94	.87	2.65	6.66	5	262	245	242	50	102	83	
5	45	086.90	.92	2.81	9.51	5.5	260	241	253	50	102	84	
6	48	089.65	.81	2.48	2.19	5	260	237	257	51	103	85	
7	51	092.37	.73	2.25	4.25	4	257	244	249	50	104	86	
8	54	094.93	.58	1.79	7.04	3	258	241	244	50	103	86	
9	57	097.33	.52	1.60	9.10	3	258	235	247	51	103	87	
10	60	099.31											
(1936)													
0 - 60		V _m - 50.61		2.23 ΔH _m		AVG. - 88.3							

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job h.p. / Sagola, MI Date 2-24-96 Test 7 Run 2
 Source Presc NTO / Stuck No. of traverse points 20
 Method 5 Filter holder: glass Filter type: 4" 61F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

9453

Recovery solvent(s)

Acetone _____
 Other(s) MeCl₂

No. of probe wash bottles:

1

Sample recovered by:

M. Kambler + D. Hullerman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	535	508	27
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1413	1401	12
Total			39

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

HEALTH SERVICES
(612) 786-6020

EPA Method 5 Field Data Sheet

Job Lib / Sagala, MI Operator M. Kach (last) P. Kellerman Pilot No. YMS-8
 Source Press ATO / Stack Meter Box No. 10 A110 Nozzle Dia. 1.251 in. 1.04
 Date 2-24-96 Test 7 Run 2 Gasmer Coeff. 1.9923 Bar. Press. 28.31 in.Hg 3.9 %

In-verse Point No.	Sampling Time (min)	Sample Vol. (cl)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cl)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		C./m	Gas/Out
	2005	899.150	.67	2.19	2.01	4	258	237	246	45	89	87	10.9
B-10		902.107	.83	2.69	4.29	4.5	263	243	241	45	93	87	
9	6	904.85	.78	2.56	2.51	4.5	256	245	247	47	96	86	
8	9	907.68	.87	2.85	0.38	4.5	255	260	243	46	97	87	
7	12	910.135	.77	2.53	3.09	4.5	258	261	250	48	95	87	
6	15	913.30	.82	2.70	5.89	4.5	254	253	256	46	101	87	
5	18	915.97	.73	2.42	8.54	4	257	247	249	46	102	88	
4	21	918.77	.67	2.22	1.08	3.5	257	240	253	47	103	88	
3	24	921.24	.53	1.76	3.35	3	256	235	250	47	105	88	
2	27	923.47	.55	1.83	5.67	3	255	235	246	47	103	88	
1	30	925.83	.56	1.86	7.99	3	258	240	253	48	100	89	
A-10	33	927.99	.61	2.02	0.42	3.5	258	243	258	46	103	89	
9	36	930.50	.72	2.35	3.06	4	258	241	261	45	104	89	
8	39	933.11	.62	2.05	5.51	4	261	235	257	46	105	90	
7	42	935.47	.87	2.89	8.41	5	259	244	259	45	105	89	
6	45	938.32	.88	2.93	1.34	5	255	232	256	46	105	90	
5	48	941.31	.83	2.77	4.19	4.5	254	240	253	47	106	90	
4	51	944.20	.90	3.00	7.15	5	256	245	250	47	106	90	
3	54	947.23	.98	2.93	0.87	5	257	241	255	48	107	91	
2	57	950.30	.77	2.57	2.82	4	256	232	256	47	107	91	
1	60	952.98					256	232	256	47	107	91	
	(2108)												
	0-60	V _m - 53.48		2.46 AFT -									

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagola, MI Date 7-24-96 Test 7 Run 3
 Source Press 1170 / Steel No. of traverse points 20
 Method 5 Filter holder: G114 Filter type: 4" G.F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

0454

Racstone

Other(s) MeCl

No. of probe wash bottles:

1

Sample recovered by:

M. Kadleit, D. Hullman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	537	506	31
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1513	1500	13
Total			44

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

1. L. RA: 5,
(612) 786-6020

EPA Method 5 Field Data Sheet

Job L.P. / Sagola M1 Operators M. Kuebler, P. H. Johnson Pilot No. 4MS-8
 Source Kress RTD / Stack Meter Box No. 10 ΔH@ 1.93 in.WC Nozzle Dia. 2.51 in.
 Date 7-24-96 Test 7 Run 3 Gasmeter Coeff. 1.9973 Bar. Press. 28.31 in.Hg. C_p 1.94
 % 3.7

Traverse Point No.	Sampling Time (min)	Sample Vol. (c)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (c)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
A-10	2137	953.30	.67	2.23	5.84	4	258	240	253	47	91	90	20.9
9	3	955.97	.70	2.30	8.42	4	259	237	260	45	95	89	
8	6	958.45	.81	2.68	1.21	4.5	257	245	257	44	97	89	
7	9	961.29	.73	2.44	3.87	4	252	241	253	44	98	89	
6	12	963.93	.74	2.47	6.54	4	253	233	260	46	100	89	
5	15	966.64	.90	2.99	9.49	5	257	240	263	47	101	89	
4	18	965.20	.81	2.67	2.28	4.5	262	246	257	47	102	89	
3	21	972.41	.90	2.98	5.22	5	259	250	251	48	102	89	
2	24	975.35	.74	2.46	7.90	4	261	243	256	48	103	89	
1	27	977.97	.72	2.41	0.55	4	253	240	253	49	104	89	
B-10	30	980.67	.58	1.95	2.94	3	251	246	250	50	101	90	
9	33	982.99	.75	2.50	5.64	4.5	255	243	256	51	104	90	
8	36	985.72	.86	2.88	8.54	5	253	235	259	51	105	90	
7	39	988.54	.83	2.78	1.39	5	255	235	253	48	105	90	
6	42	991.43	.73	2.45	4.07	4.5	253	240	251	47	105	90	
5	45	994.10	.88	2.95	2.01	5	253	241	245	47	106	90	
4	48	997.11	.75	2.52	9.72	4.5	254	235	243	47	106	91	
3	51	999.87	.87	2.92	3.65	5	254	240	247	48	106	91	
2	54	1002.67	.63	2.12	5.44	4	255	233	253	48	107	92	
1	57	1005.23	.74	2.45	2.45	3.5	253	237	250	48	106	92	
	60	1007.157											
	(2237)												
	0 - 60	V _m - 54.27		ΔH - 2.53								Avg. - 96.0	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP SAGOLA
 Source PRESS RTD INLET
 Test 8 Run / Date 7-25-96
 Stack Dimen. 57.25 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.45 IN.HG
 Static Pressure -4.75 IN.WC
 Operators S.B. / M.P.
 Pitot No. V27-5 C_p - 84

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>3.75</u> IN.		Time Start: <u>1620</u> HRS	
A 1	.021	1.20	4.95	1.35	
2	.067	3.85	7.60	1.25	
3	.118	6.79	10.54	1.45	
4	.177	10.18	13.93	1.40	
5	.250	14.38	18.13	1.50	
6	.356	20.47	24.22	1.95	
7	.644	37.03	40.78	1.80	
8	.750	43.13	46.88	1.85	
9	.823	47.32	51.07	1.10	
10	.882	50.72	54.47	1.10	
11	.933	53.65	57.40	1.05	
12	.974	56.27	60.04	1.00	
B 1				1.30	
2				1.50	
3				1.45	
4				1.50	
5				1.80	
6				1.80	
7				1.75	
8				1.45	
9				1.35	
10				1.25	
11				1.15	
12				1.00	
Temp. Meas. Device & S/N: <u>PDT # 2</u>				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/SAGOLA
 Source PROSS ATO INLET
 Test B Run 2 Date 7-25-96
 Stack Dimen. 57.25 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.45 IN.HG
 Static Pressure -4.75 IN.WC
 Operators S.B. / M.P.
 Pitot No. U27-5 C_p - 84

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
Port Length:			IN.	Time Start: <u>1800</u>	HRS
A 1				<u>2.00</u>	
2				<u>2.10</u>	
3				<u>1.75</u>	
4				<u>1.95</u>	
5				<u>2.00</u>	
6				<u>2.05</u>	
7				<u>2.25</u>	
8				<u>2.35</u>	
9				<u>2.40</u>	
10				<u>2.00</u>	
11				<u>1.30</u>	
12				<u>1.30</u>	
B 1				<u>1.10</u>	
2				<u>1.30</u>	
3				<u>1.45</u>	
4				<u>1.20</u>	
5				<u>1.70</u>	
6				<u>1.40</u>	
7				<u>1.65</u>	
8				<u>1.70</u>	
9				<u>1.30</u>	
10				<u>1.35</u>	
11				<u>1.10</u>	
12				<u>.80</u>	
Temp. Meas. Device & S/N: <u>PDT #2</u>				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\S-392.1


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP SAGOLA
 Source PROSSATO STREET
 Test 40 Run # 3 Date 7-25-96
 Stack Dimen. 57.25 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.45 IN.HG
 Static Pressure -14.75 IN.WC
 Operators SA / MP
 Pitot No. V27-5 C_p -84




Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
			Port Length: _____ IN.	Time Start: <u>1935</u> HRS	
A 1				<u>1.90</u>	
2				<u>2.05</u>	
3				<u>2.20</u>	
4				<u>2.05</u>	
5				<u>2.10</u>	
6				<u>1.70</u>	
7				<u>1.80</u>	
8				<u>2.30</u>	
9				<u>2.15</u>	
10				<u>1.60</u>	
4				<u>1.25</u>	
12				<u>1.70</u>	
D 1				<u>1.65</u>	
2				<u>2.60</u>	
3				<u>2.05</u>	
4				<u>1.75</u>	
5				<u>1.90</u>	
6				<u>2.10</u>	
7				<u>2.15</u>	
8				<u>1.90</u>	
9				<u>1.95</u>	
10				<u>.98</u>	
11				<u>1.05</u>	
12				<u>.97</u>	
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP-SAGOLA
 Source PR + S + RTO INGT
 Test 9 Run 0 Date 7-25-76
 Stack Dimen. 57 IN.
 Dry Bulb 122 °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.45 IN.HG
 Static Pressure -4.75 IN.WC
 Operators SB + JB + MK
 Pitot No. V29-6 C₀-840



* *Tranalyzer* *

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>10</u> IN.	Time Start: <u>0735</u> HRS		
<u>A-1</u>	<u>.021</u>	<u>1.20</u>	<u>11.20</u>	<u>.60</u>	<u>122</u>
<u>2</u>	<u>.067</u>	<u>3.82</u>	<u>13.82</u>	<u>.98</u>	
<u>3</u>	<u>.119</u>	<u>6.73</u>	<u>16.73</u>	<u>1.08</u>	
<u>4</u>	<u>.177</u>	<u>10.09</u>	<u>20.09</u>	<u>1.05</u>	
<u>5</u>	<u>.250</u>	<u>14.25</u>	<u>24.25</u>	<u>1.55</u>	<u>123</u>
<u>6</u>	<u>.356</u>	<u>20.29</u>	<u>30.29</u>	<u>2.00</u>	
<u>7</u>	<u>.644</u>	<u>36.71</u>	<u>46.71</u>	<u>1.80</u>	
<u>8</u>	<u>.750</u>	<u>42.75</u>	<u>52.75</u>	<u>1.45</u>	
<u>9</u>	<u>.823</u>	<u>46.91</u>	<u>56.91</u>	<u>1.55</u>	<u>124</u>
<u>10</u>	<u>.883</u>	<u>50.27</u>	<u>60.27</u>	<u>1.50</u>	
<u>11</u>	<u>.933</u>	<u>53.18</u>	<u>63.18</u>	<u>1.20</u>	
<u>12</u>	<u>.979</u>	<u>55.90</u>	<u>65.80</u>	<u>1.15</u>	<u>122</u>
Temp. Meas. Device & S/N: <u>DIGITAL TR -PDT 45</u>				<u>0740</u>	Time End: _____ HRS

R or nothing = reg. manometer; S = expanded; E = electronic

A = 12" 2.5 dia
 B = 24" 4.42 dia

INTERPOLL LABORATORIES, INC

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP - SA CRACK

Date 7-25-86 Test 9 Run 1

Source PRESS RTO INLET

No. of traverse points 24

Method 0011 Filter holder: M/A

Filter type: M/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.00 cfm at 60 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

acetone

Other(s) MeCL₂

No. of probe wash bottles:

1
SCB

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	580	573	7
Impinger No. 3			
Condenser			
Desiccant	1500	1489	11
Total			18

Integrated Gas Sampling Data: (N/A Ambient Air)

Bag Pump No. _____

Box No. _____ Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____ IN.HG

Time start: _____

(HRS) Time end: _____ (HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-GASTACKIWPFFORMS-0046RR

EPA Method 5 Field Data Sheet

Job: LP- SACOLA
 Source: P200 PTO INLET
 Date: 2-25-96 Test 9 Run 1
 Operators: JB + MP
 Meter Box No.: 4 A110 1.78 in. WC
 Gasmeter Coeff.: 9957
 Nozzle No.: 5-1
 Nozzle Dia.: .189 in.
 Bar. Press.: 28.46 in. Hg
 Pilot No.: V29-6
 C_p: .820
 H₂O: 4 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)			
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out	
	(0805)	(110.90)												
A-12	2.5	112.63	1.35	1.54	2.69	3		122	251	N/A	47	70	70	20.9
4	5	114.39	1.25	1.41	4.43	3		118	254		48	70	69	20.9
10	7.5	116.29	1.45	1.65	6.28	4		124	254		48	71	70	20.9
9	10	118.13	1.40	1.60	8.12	3		120	254		48	72	70	20.9
8	12.5	120.04	1.50	1.72	0.02	4		120	254		48	73	70	20.9
7	15	122.10	1.95	2.22	20.9	4		123	255		49	74	71	20.9
6	17.5	124.20	1.80	2.05	4.27	4		124	255		49	74	71	20.9
5	20	126.54	1.85	2.11	2.37	4		125	255		50	75	71	20.9
4	22.5	128.19	1.10	1.25	8.09	4		125	251		50	76	71	20.9
3	25	129.75	1.18	1.26	9.63	3		124	251		51	76	72	20.9
2	27.5	131.15	1.05	1.18	1.22	3		133	250		50	74	72	20.9
1	30	132.58	1.00	1.14	2.27	3		115	251		50	76	73	20.9
B-12	32.5	134.64	1.65	1.90	4.78	4		120	251		50	77	73	20.9
11	35	136.85	2.00	2.20	6.98	5		121	254		50	77	73	20.9
10	37.5	139.20	2.05	2.35	7.21	5		124	254		51	78	74	20.9
9	40	141.20	2.175	2.26	1.27	4		124	250		48	79	75	20.9
8	42.5	143.08	1.90	2.20	5.43	4		120	248		47	80	75	20.9
7	45	145.49	2.10	2.42	5.70	5		123	240		46	79	75	20.9
6	47.5	147.90	2.18	2.46	7.98	5		127	240		45	80	75	20.9
5	50	150.22	1.80	2.16	5.12	5		131	241		44	80	75	20.9
4	52.5	152.35	1.90	2.17	2.27	4		128	245		48	80	76	20.9
3	55	154.40	1.95	2.23	4.75	4		128	246		47	80	75	20.9
2	57.5	155.98	.98	1.12	5.99	3		129	246		47	81	74	20.9
1	60	157.55	.97	1.11	7.53	3		128	246		47	81	76	20.9
	(0908)													
	0-60	V _m = 46.65		1.82	ΔH =								AVG. = 74.6	

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP. SAGOWA Date 7-25-96 Test 9 Run 2
 Source Process BTO INLET No. of traverse points 24
 Method 0011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.00 cfm at 8 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 other(s) MeCl₂

No. of probe wash bottles: _____

Sample recovered by: _____

1
SIB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	581	569	12
Impinger No. 3			
Condenser			
Desiccant	1424	1406	18
Total			30

Integrated Gas Sampling Data:

(N/A Ambient Air)

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-C:STACK\WP\FORMS\5-0046RR

EPA Method 5 Field Data Sheet

Job: LP - SAGROVA Operator: SB & MP Nozzle No.: 5-1 Pilot No.: V24-6
 Source: PROXY RT FUEL Meter Box No.: 4 ΔH@: 1.78 in.WC Nozzle Dia.: 1.89 in. C_p: 850
 Date: 7-24-96 Test: 9 Run: 2 Gasmeter Coeff.: 9957 Bar. Press.: 28.45 in.Hg H₂O: 2 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)			Gas/In	Gas/Out	Oxygen (% v/v)
							Stack	Probe	Oven			
	(0937)	(158.52)										
A-12	2.5	160.70	2.00	2.35	0.72	5	128	240	75	75	20.9	
11	5	163.12	2.10	2.47	3.01	5	128	240	76	75	20.9	
10	7.5	165.09	1.75	2.06	5.09	4	129	241	76	76	20.9	
9	10	167.38	1.95	2.30	7.70	5	127	240	76	75	20.9	
8	12.5	169.63	2.00	2.37	7.84	5	127	240	78	76	20.9	
7	15	171.88	2.05	2.44	6.81	5	127	241	79	77	20.9	
6	17.5	174.24	2.25	2.68	4.20	6	127	244	81	77	20.9	
5	20	176.75	2.25	2.68	6.58	6	125	244	81	77	20.9	
4	22.5	179.02	2.35	2.80	7.02	6	125	244	81	78	20.9	
3	25	181.50	2.40	2.84	1.48	6	130	244	82	78	20.9	
2	27.5	183.81	2.00	2.39	3.73	5	125	240	82	78	20.9	
1	30	185.55	1.30	1.55	5.55	3	126	244	82	78	20.9	
B-12	32.5	187.43	1.30	1.57	7.38	4	120	247	82	78	20.9	
11	35	189.39	1.50	1.81	7.35	4	120	247	80	78	20.9	
10	37.5	191.31	1.45	1.72	1.24	4	129	242	83	79	20.9	
9	40	193.24	1.50	1.79	3.22	4	128	241	83	79	20.9	
8	42.5	195.30	1.80	2.17	5.37	4	122	241	84	80	20.9	
7	45	197.50	1.80	2.11	7.60	4	133	241	84	80	20.9	
6	47.5	199.20	1.75	2.09	9.62	4	127	241	85	80	20.9	
5	50	201.62	1.45	1.72	1.54	4	133	241	85	80	20.9	
4	52.5	203.45	1.35	1.60	3.79	4	131	241	85	81	20.9	
3	55	205.20	1.25	1.47	5.18	4	136	240	85	81	20.9	
2	57.5	206.92	1.15	1.34	6.14	3	136	240	85	81	20.9	
1	60	208.49	1.00	1.19	8.49	3	130	240	85	81	20.9	
	(1039)											
	0.60	V _m = 49.99		2.06 ΔH ₂					Avg. = 79.8			

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP-SACTOW Date 7-29-86 Test 9 Run 3
 Source PROD RTD FILTER No. of traverse points 24
 Method 001 Filter holder: NA Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.0 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

Acetone _____

Other(s) MCCB

No. of probe wash bottles: _____

Sample recovered by: _____

JB

1

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	573	563	10
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1496	1484	12
Total			22

Integrated Gas Sampling Data:

(M) AMBIENT AIR

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

EPA Method 5 Field Data Sheet

Job: LP - Sacramento Operators: JB & MK Nozzle No.: 5-1 Pilot No.: R29-6
 Source: Process RTD TOWER Meter Box No.: 4 AFH @ 1.28 in. WC Nozzle Dia.: 1.89 in. C_p: -840
 Date: 7-25-96 Test # 9 Run 3 Bar. Press.: 28.45 in. Hg H₂O: 3 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)								
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out						
	(1235)	209.64																	
A-12	2.5	211.83	1.90	2.21	1.81	4		232	42	76	76	76	20.9						
11	5	214.04	2.05	2.37	4.05	4		234	43	77	76	76	20.9						
10	7.5	216.40	2.20	2.55	6.37	5		235	43	77	76	76	20.9						
9	10	218.60	2.05	2.39	8.62	5		235	43	78	76	76	20.9						
8	12.5	220.94	2.10	2.44	0.89	4		240	45	79	77	77	20.9						
7	15	222.81	1.70	1.94	2.95	3		242	45	79	77	77	20.9						
6	17.5	225.04	1.80	2.10	5.06	4		242	45	80	77	77	20.9						
5	20	227.41	2.30	2.70	7.46	5		245	46	81	78	78	20.9						
4	22.5	229.76	2.15	2.52	9.77	5		244	46	82	78	78	20.9						
3	25	231.95	1.60	1.87	1.77	4		247	43	82	78	78	20.9						
2	27.5	233.30	1.25	1.47	3.54	3		250	43	82	78	78	20.9						
1	30	235.37	1.70	2.01	5.61	4		252	44	82	79	79	20.9						
B-12	32.5	237.24	1.10	1.29	1.27	3		251	44	82	79	79	20.9						
11	35	239.08	1.30	1.54	9.09	3		254	43	82	79	79	20.9						
10	37.5	241.03	1.45	1.71	1.00	4		254	43	83	79	79	20.9						
9	40	242.78	1.20	1.42	2.75	3		255	43	83	79	79	20.9						
8	42.5	244.84	1.70	1.98	4.80	3		252	44	83	80	80	20.9						
7	45	246.71	1.40	1.66	6.69	4		254	44	84	80	80	20.9						
6	47.5	248.72	1.65	1.93	8.72	3		254	44	84	80	80	20.9						
5	50	250.78	1.70	2.00	0.80	4		253	45	84	80	80	20.9						
4	52.5	252.63	1.30	1.53	2.61	4		256	45	84	80	80	20.9						
3	55	254.44	1.35	1.57	4.45	3		254	46	84	80	80	20.9						
2	57.5	256.11	1.10	1.29	6.11	4		257	46	84	80	80	20.9						
1	60	257.57	.79	0.93	7.53	3		256	47	84	80	80	20.9						
	(1335)																		
	0 - 60	V _m = 47.93		ΔFT = 1.90															

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP SABOLA Date 7-25-96 Test 9 Run 4
 Source PKDSS KFO Inlet No. of traverse points 24
 Method 0011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 other(s) MCLL _____

No. of probe wash bottles: _____

Sample recovered by: _____

JA

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	592	574	18
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1494	1484	10
Total			28

Integrated Gas Sampling Data:

N/A AMBIENT ASK

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

MIL
 (612) 786-6020

EPA Method 5 Field Data Sheet


Job LP 5A606 Operators 5D/mf Nozzle No. 5-1 Pitot No. V27-6
 Source PN575 RTD J-Loc Meter Box No. 4 AH@ 1.78 in.WC Des. Vol. (cf) 9.91 Gas/In 79 Gas/Out 78
 Date 7-25-96 Test 9 Run 4 Gasmeter Coeff. 9457 Bar. Press. 28.45 in.Hg. 28.4 in. 3 %
 O₂ 20.7 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Inp.			
1	(1410) 2.5	259.73	1.2	1.39	9.91	4	125	230	NA	41	79	78	20.7
2	5	261.78	1.4	1.65	1.79	4	122	230		41	79	78	20.7
3	7.5	263.90	1.1	1.30	3.46	3	122	232		41	77	78	20.7
4	10	265.38	1.4	1.65	5.34	4	122	231		42	80	78	20.7
5	12.5	267.40	1.65	1.94	7.37	4	126	231		42	82	79	20.4
6	15	269.62	1.95	2.27	9.58	5	133	232		43	83	79	20.4
7	17.5	271.95	2.15	2.52	1.90	5	129	232		43	84	79	20.7
8	20	273.74	1.30	1.52	3.71	3	131	233		44	84	80	20.9
9	22.5	275.76	1.65	1.73	5.75	4	132	234		43	84	80	20.7
10	25	277.58	1.30	1.52	7.56	3	131	235		44	84	80	20.7
11	27.5	279.10	1.92	1.98	9.08	3	130	234		44	84	80	20.7
12	30	280.76	1.05	1.23	0.72	3	130	235		45	85	80	20.7
A1	32.5	282.88	1.80	2.11	2.85	4	129	232		45	84	81	20.9
2	35	285.12	2.00	2.36	5.10	5	125	234		46	84	81	20.9
3	37.5	287.15	1.60	1.89	7.12	4	125	235		46	84	81	20.9
4	40	289.37	1.95	2.29	9.34	5	129	236		47	84	81	20.9
5	42.5	291.73	2.20	2.60	1.71	5	126	235		46	85	81	20.7
6	45	294.04	2.15	2.52	4.03	5	131	237		47	85	81	20.7
7	47.5	296.55	2.50	2.93	6.54	6	130	236		47	85	81	20.9
8	50	298.91	2.15	2.53	8.88	5	125	236		48	85	81	20.9
9	52.5	301.40	2.50	2.94	1.39	6	127	237		48	85	81	20.9
10	55	303.60	1.90	2.23	3.59	5	129	238		48	85	81	20.7
11	57.5	305.71	1.75	2.07	5.70	4	125	239		49	85	81	20.7
12	60	307.64	1.35	1.61	7.56	4	122	240		48	85	81	20.9
	(1512)												
	0.60	V _m = 419.44		2.00 ΔH -								AVG. = 81.7	

INTERPOLL LABORATORIES, INC.
 (612) 786-6020
EPA Method 2 Field Data Sheet

Job L.P. / Sayola, MI
 Source Pack RTD / Stack
 Test 7 Run 0 Date 7-24-96
 Stack Dimen. 20 IN.
 Dry Bulb 255 °F Wet bulb 108 °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 29.45 IN.HG
 Static Pressure - .27 IN.WC
 Operators M. Kachler + D. Mullen
 Pitot No. 1M5-B C₀ 104

Drawing of Test Site



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
[Pattern]		Port Length:	<u>4</u> IN.	Time Start:	<u>NA</u> HRS
		<u>Refer to test 7</u>			
		<u>for pts. and flows</u>			
Temp. Meas. Device & S/N: <u>PDT-45 ITC</u>				Time End: <u>NA</u> HRS	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagala, MI Date 7-15-96 Test 9 Run 1
 Source Press RW / Stack No. of traverse points 20
 Method 0011 Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 5 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone
 other(s) MeCl₂

No. of probe wash bottles:

Sample recovered by:

Mike Miller / D. Hollerman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	491	476	15
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1424	1413	11
Total			26

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagola, MI

Date 7-25-96 Test 9 Run 2

Source Presc. RTO / Study

No. of traverse points 20

Method poll Filter holder: _____

Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

NA

~~Recovery~~ _____

Other(s) MeCl₂

No. of probe wash bottles: _____

0

Sample recovered by:

M. Kudalov + D. Hultman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	492	474	18
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1525	1513	1513 12
Total			30

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____

Box No. _____

Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____ IN.HG

Time start: _____

(HRS) Time end: _____ (HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-C:STACKWP\FORMS5-0046RR

EPA Method 5 Field Data Sheet

Job L.P. / Szepka, MI Operators M. Kachler, E. Holloman Nozzle No. 2-Y Pilot No. 4MS-6
 Source Press RTD / Stack Meter Box No. 10 Alt @ 1.93 in. WC Nozzle Dia. 2.51 in. C_p 1.04
 Date 7-25-96 Test 9 Run 2 Gasmeter Coeff. ML-448 .5973 Bar. Press. 29.95 in. Hg H₂O 11.0 % 2.5

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)					
							Stack	Probe	Oven	Insp.								
	0937	67.20																
A-10	3	69.60	.63	2.12	9.65	3	251	240	250	48	0.1	83	20.9					
9	6	72.00	.62	2.07	8.08	3	254	233	246	45	98	83						
8	9	74.73	.71	2.39	4.68	4	252	241	253	45	92	83						
7	12	77.43	.79	2.65	7.44	4	255	237	255	45	94	83						
6	15	80.12	.75	2.52	8.12	4	255	246	250	47	95	83						
5	18	82.97	.83	2.80	8.95	4.5	254	243	257	48	90	84						
4	21	85.86	.91	3.08	5.93	5	253	235	251	46	99	84						
3	24	88.77	.80	2.71	8.72	4	254	240	247	47	99	84						
2	27	91.35	.68	2.30	1.29	3	254	235	250	47	100	85						
1	30	93.67	.60	1.85	3.73	3	251	233	244	47	101	85						
13-10	33	96.25	.55	1.88	6.06	2.5	251	240	247	48	99	85						
9	36	98.97	.81	2.74	8.87	4	254	245	244	44	100	86						
8	39	101.65	.80	2.71	1.66	4	255	241	248	44	101	87						
7	42	104.43	.77	2.61	4.41	4	255	243	253	45	102	86						
6	45	107.47	.88	2.99	2.35	4.5	254	239	259	44	103	86						
5	48	110.11	.71	2.41	8.00	4	255	246	248	45	104	88						
4	51	112.83	.80	2.71	2.80	4	258	241	253	45	104	88						
3	54	115.47	.65	2.23	5.35	3	252	247	250	46	104	89						
2	57	117.78	.65	2.23	2.89	3	251	247	256	48	103	89						
1	60	120.17	.59	2.02	8.32	3	251	250	253	49	104	89						
	(1039)																	
	0-60	V _m - 52.97		2.5/6 ΔH -														

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagola, MI Date 7-15-96 Test 9 Run 3 & MK
 Source Press BTO / Stack No. of traverse points 20
 Method 0011 Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____

other(s) MeCl₂

No. of probe wash bottles:

0
M. Kaepler + D. Hullerman

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	493	477	16
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1433	1424	9
Total			25

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____

Box No. _____

Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____

IN.HG

Time start: _____

(HRS) Time end: _____

(HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-GASTACKWPFORMS-0046RR

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job: C.P. / Sagella, WI Operator: W. K. K. / K. K. / K. K. Nozzle No.: 2-7 Pilot No.: 7-115-2
 Source: Press ATO / Stack Meter Box No.: 10 ΔH@: 1.93 in. WC Nozzle Dia.: 1.51 in. C_p: 1.0
 Date: 7-25-96 Test: 9 Run: 3 Gasmeter Coeff.: 9973 Bar. Press.: 28.41 in. Hg in. Hg: 2.8 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Insp.		Gas/In	Gas/Out
B-10	1235	121.40	.93	2.80	4.24	4	253	233	258	49	85	85	20.9
9	3	124.31	.75	2.79	6.90	4	256	246	251	46	88	84	
8	6	126.97	.73	2.44	9.53	4	254	244	258	48	90	84	
7	9	132.21	.70	2.33	2.11	3.5	258	247	255	48	92	84	
6	12	134.82	.72	2.41	4.74	4	255	241	259	47	95	85	
5	15	137.65	.83	2.78	2.56	4	255	247	253	47	96	85	
4	18	140.29	.75	2.52	0.25	4	256	244	250	48	97	85	
3	21	142.99	.77	2.58	2.98	4	257	241	255	48	99	85	
2	24	145.72	.75	2.53	5.67	4	254	245	249	48	99	86	
1	27	148.37	.71	2.39	8.30	4	257	253	245	46	100	86	
A-10	30	150.78	.60	2.03	0.72	3.5	255	249	246	45	59	87	
9	33	153.41	.70	2.36	3.33	3.5	255	258	240	47	101	87	
8	36	156.07	.74	2.50	6.02	4	256	247	237	47	102	88	
7	39	158.85	.77	2.61	8.77	4	255	241	247	48	103	88	
6	42	161.50	.77	2.60	1.51	4	257	247	250	45	103	88	
5	45	164.23	.76	2.59	4.15	4	251	249	256	46	103	88	
4	48	167.35	.88	2.98	2.19	4.5	255	245	258	48	104	90	
3	51	170.10	.81	2.76	0.02	4	253	240	251	49	105	89	
2	54	172.84	.73	2.48	2.71	4	256	236	247	51	105	80	
1	57	175.37	.67	2.28	5.28	3.5	255	243	245	51	105	91	
	60	(1336)											
	0-60	V _m - 5397		2.52 ΔH									

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Sagala MI Date 7-25-76 Test 9 Run 4
 Source Press NTO / Stack No. of traverse points 20
 Method 0011 Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____
 other(s) MeCl₂

No. of probe wash bottles:

6
M. Kachler + D. Hilleman

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	495	477	18
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1539 1539	1525	14
Total			32

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

VISIBLE EMISSION OBSERVATION FORM 1

Form Number		Page	Of
Continued on VEO Form Number			

Method Used (Circle One)
 Method 9 203A 203B Other _____

Company Name
 Louisiana Pacific
 City Name
 Sagola
 State MI Zip _____

Process
 Dryer
 Unit # _____ Operating Mode _____
 Control Equipment
 RTC E-tube Operating Mode _____


Describe Emission Point

Height of Emiss. Pt. _____
 End _____
 Height of Emiss. Pt. Rel. to Observer
 Start _____ End _____
 Distance to Emiss. Pt. _____
 Direction to Emiss. Pt. (Degrees)
 Start _____ End _____

Vertical Angle to Obs. Pt. _____
 End _____
 Direction to Obs. Pt. (Degrees)
 Start _____ End _____
 Distance and Direction to Observation Point from Emission Point
 Start _____ End _____

Describe Emissions
 Emission Color _____
 End _____
 Water Droplet Plume
 Attached Detached None

Describe Plume Background
 Background Color _____
 End _____
 Sky Conditions _____
 End _____
 Wind Speed _____
 End _____
 Wind Direction _____
 Start _____ End _____
 Ambient Temp. _____
 End _____
 Wet Bulb Temp. _____
 RH Percent _____



Longitude _____ Latitude _____ Declination _____

Additional Information

Observation Date	Time Zone	Start Time	End Time		
7-23-96	COST				
Sec Min	0	15	30	45	Comments
1					Unable to read due
2					to overcast clouds
3					and intermittent rain
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

Observer's Name (Print)
 Mark Petersen
 Observer's Signature
 Mark Petersen
 Date
 7/23/96
 Organization
 Interpill Laboratories, Inc.
 Certified By
 Eastern Technical Associates
 Date
 7-3-96

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)
 Method 9 202A 202B Other: _____

Company Name
 Louisiana Pacific Corp.

Facility Name
 Stgolet Plant

Street Address
 Hwy 95

City State Zip
 Stgolet ME 2ip

Process
 Press vent Unit # NA Operating Mode

Control Equipment
 RTO Operating Mode

Describe Emission Point
 silver stack next to RTO on

east side of the building

Height of Emiss. Pt. Rel. to Observer
 Start ~80' End same Start ~80' End same

Distance to Emiss. Pt.
 Start ~160' End same Start 330° End same

Remot. Angle to Obs. Pt.
 Start ~26° End same Start 330° End same

Distance and Direction to Observation Point from Emission Point
 Start 3' Above End same

Describe Emissions
 Start None visible End same


Emission Color
 Start None End same Attached Detached None

Describe Plume Background
 Start sky w/ clouds End same

Background Color
 Start blue/white End same Start Partly cloudy End same

Wind Speed
 Start ~4 to 8 mph End same Start north End same

Wet Bulb Temp. RH Percent
 Start 83° End same Start 69° RH Percent 46%



Longitude Latitude Declination

Additional Information

Form Number _____ Page 1 of 2
 Continued on VEO Form Number _____

Observation Date 7-25-96 Time Zone COST Start Time 0937 End Time 1007

Sec Min	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print)
 Mark Peteresen

Observer's Signature
 Mark Peteresen Date 7/25/96

Organization
 Interpoll Laboratories, Inc.

Checked By
 Eastern Technical Associates Date 4-3-96

VISIBLE EMISSION OBSERVATION FORM 1

Form Number Page 2 of 2
Continued on VEO Form Number

Unit (Circle One)
 Mod 203A 203B Other _____

Company Name
 Consultant Pacific

Name
 SANDLA Plant

Street Address
 Hwy 95

City
 Bayola

State
 ME

Zip

Unit #
 NA

Operating Mode

Equipment
 RTO

Emission Point
 Lower stack next to RTO on west side of building

Height of Emiss. Pt. Rel. to Observer
 Start ~80' End same

Direction to Emiss. Pt. (Degrees)
 Start ~160' End same

Angle to Obs. Pt.
 ~20' End same

Distance and Direction to Observation Point from Emission Point
 3' Above End same

Visible Emissions
 None visible End same

Emission Color
 None End same

Water Droplet Plume
 Attached Detached None

Plume Background
 sky w/ clouds End same

Background Color
 White End same


Sky Conditions
 Start Partly cloudy End same

Wind Direction
 Start north End same

Wind Speed
 4 to 8 mph End same

Wet Bulb Temp.
 69°

RH Percent
 46%



Latitude

Longitude

Additional Information

Observation Date	Time Zone	Start Time	End Time	Comments					
7-25-96	EDST	1007	1037	Sec	0	15	30	45	
1	0	0	0	0					
2	0	0	0	0					
3	0	0	0	0					
4	0	0	0	0					
5	0	0	0	0					
6	0	0	0	0					
7	0	0	0	0					
8	0	0	0	0					
9	0	0	0	0					
10	0	0	0	0					
11	0	0	0	0					
12	0	0	0	0					
13	0	0	0	0					
14	0	0	0	0					
15	0	0	0	0					
16	0	0	0	0					
17	0	0	0	0					
18	0	0	0	0					
19	0	0	0	0					
20	0	0	0	0					
21	0	0	0	0					
22	0	0	0	0					
23	0	0	0	0					
24	0	0	0	0					
25	0	0	0	0					
26	0	0	0	0					
27	0	0	0	0					
28	0	0	0	0					
29	0	0	0	0					
30	0	0	0	0					

Observer's Name (Print)
 Mark Petersen

Observer's Signature
 Mark Petersen

Date
 7/25/96

Organization
 Interpoll Laboratories, Inc.

Certified By
 Eastern Technical Associates

Date
 4-3-96

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Mark Petersen

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single day or exceeding test opportunity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

Thomas Lane
President

252753
Certificate Number

Minneapolis, Minnesota

David B. Savage, Jr.
Program Manager


April 3, 1996
Date of Issue

APPENDIX D

INTERPOLL LABORATORIES ANALYTICAL DATA

TABLE OF CONTENTS

Orsat	1
Particulate	11
Oxides of Nitrogen	41
Carbon Monoxide	47
Methane	50
Formaldehyde	52
Phenol	54
MDI	55
Spiking Information	56
Sample Deposition Sheets	59



EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job h.p. / Sagala, MI
 Team Leader S. Ejelsta
 Date Submitted 7-24-96
 Test No. 1
 Date of Analysis 7-24-96

Source No. 1 Primary Cyclone
 Test Site Exhaust
 Date of Test 7-23-96
 No. of Runs Completed 3
 Technician Mark Bachler

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/1	B□F	1	0.00	3.00	20.60	3.00	17.60	1.109
		2	0.00	3.00	20.60	3.00	17.60	1.100
		Avg				3.00	17.60	
1/2	B□F	1	0.00	3.40	20.50	3.40	17.10	1.116
		2	0.00	3.40	20.50	3.40	17.10	1.119
		Avg				3.40	17.10	
1/3	B□F	1	0.00	3.70	20.50	3.70	16.90	1.109
		2	0.00	3.70	20.50	3.70	16.80	1.108
		Avg				3.70	16.90	
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						

EPA Method 3 Guidelines

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F = Flask (250 cc all glass)

B = Tedlar Bag (5 layer)

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP-SAGOLS
 Team Leader DUY
 Date Submitted 7-26-96
 Test No. 1
 Date of Analysis 7-31-96

Source NO. 2 CYCLOME
 Test Site 05087
 Date of Test 7-27-96
 No. of Runs Completed 3
 Technician SWB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/1	8024-	1	0.00	3.2	20.4	3.2	17.2	1.16
		2	0.00	3.2	20.4	3.2	17.2	1.16
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg				3.2	17.2
1/2		1	0.00	3.8	20.7	3.8	16.9	1.05
		2	0.00	3.8	20.7	3.8	16.9	1.05
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg				3.8	16.9
1/3		1	0.00	3.2	20.4	3.2	17.2	1.16
		2	0.00	3.2	20.4	3.2	17.2	1.16
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg				3.2	17.2
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines
 for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job L.P. / Sagala, MI
 Team Leader E. Ivett
 Date Submitted 7-24-96
 Test No. 1
 Date of Analysis 7-24-96

Source Dryer Primary Cyclone
 Test Site No. 3 Exhaust
 Date of Test 7-23-96
 No. of Runs Completed 3
 Technician Mark Bookler

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/1	B□F	1	0.00	3.10	20.60	3.10	17.50	1.097
		2	0.00	3.10	20.60	3.10	17.50	1.097
		Avg				3.10	17.50	
1/2	B□F	1	0.00	3.70	20.50	3.70	16.80	1.108
		2	0.00	3.70	20.50	3.70	16.80	1.108
		Avg				3.70	16.80	
1/3	B□F	1	0.00	3.10	20.50	3.10	17.40	1.129
		2	0.00	3.10	20.50	3.10	17.40	1.129
		Avg				3.10	17.40	
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						
	□B□F	1						
		2						
		Avg						

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F = Flask (250 cc all glass)
 B = Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP-S440LA
 Team Leader M K
 Date Submitted 7-26-96
 Test No. 1
 Date of Analysis 7-31-96

Source ETUBA
 Test Site OUTLET
 Date of Test 7-23-96
 No. of Runs Completed 3
 Technician SLB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/1	8024	1	0.00	2.8	20.0	2.8	17.8	1.11
		2	0.00	2.8	20.4	2.1	17.8	1.11
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				2.9	17.8
1/2		1	0.00	2.9	20.6	2.9	17.7	1.10
		2	0.00	2.8	20.5	2.9	17.7	1.10
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				2.9	17.7
1/3		1	0.00	2.9	20.5	2.9	17.6	1.14
		2	0.00	2.9	20.5	2.9	17.6	1.14
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				2.9	17.6
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)
 B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP-4600A
 Team Leader MLK
 Date Submitted 7-26-96
 Test No. 1
 Date of Analysis 7-31-96

Source E-TUR
 Test Site OUTLET
 Date of Test 7-23-96
 No. of Runs Completed 2
 Technician SUB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/4	8024	1	0.00	2.9	20.5	2.9	17.6	1.14
		2	0.00	2.9	20.5	2.9	17.6	1.14
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				2.9	17.6
1/5	1	1	0.00	2.6	20.5	2.6	17.9	1.15
		2	0.00	2.6	20.5	2.6	17.9	1.15
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				2.6	17.9
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where F₀ = $\frac{20.9 \cdot O_2}{CO_2}$

F - Flask (250 cc all glass)
 B - Tedlar Bag (5 layer)

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP SAGOLA
 Team Leader S. BAINVILLE
 Date Submitted 7-23-96
 Test No. 1
 Date of Analysis 7-23-96

Source DRYEN KTO
 Test Site DRYEN KTO STACK
 Date of Test 7-23-96
 No. of Runs Completed 3
 Technician JB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/1	B	1	0	3.1	20.4	3.1	17.3	1.16
		2	0	3.1	20.4	3.1	17.3	1.16
		Avg				3.1	17.3	
1/2	B	1	0	3.1	20.4	3.1	17.3	1.16
		2	0	3.1	20.4	3.1	17.3	1.16
		Avg				3.1	17.3	
1/3	B	1	0	3.0	20.4	3.0	17.4	1.17
		2	0	3.0	20.4	3.0	17.4	1.17
		Avg				3.0	17.4	
	B	1						
		2						
		Avg						
	B	1						
		2						
		Avg						
	B	1						
		2						
		Avg						
	B	1						
		2						
		Avg						
	B	1						
		2						
		Avg						

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)
 B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LD-SAGOLA
Team Leader SLB
Date Submitted 7-26-96
Test No. 4
Date of Analysis 8-6-96

Source Primary Cyclone No. 1
Test Site 12M445F
Date of Test 7-24-96
No. of Runs Completed 3
Technician SLB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
4/1	80-4-	1	0.00	3.2	20.4	3.2	17.2	1.15
		2	0.00	3.2	20.4	3.2	17.2	1.15
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.2	17.2
4/2	80-4-	1	0.00	3.2	20.4	3.2	17.2	1.14
		2	0.00	3.2	20.4	3.2	17.2	1.14
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.2	17.2
4/3	80-4-	1	0.00	3.3	20.7	3.3	17.0	1.18
		2	0.00	3.3	20.7	3.3	17.0	1.18
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.3	17.0
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP-SAGOLA
 Team Leader DUH
 Date Submitted 7-26-96
 Test No. 7
 Date of Analysis 8-6-96

Source NA 2 CYCLOWE
 Test Site DIRECT
 Date of Test 7-24-96
 No. of Runs Completed 3
 Technician SUD

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
4/1	8024-	1	0.00	3.4	20.8	3.4	17.1	1.12
		2	0.00	3.4	20.5	3.4	17.1	1.12
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F Avg				3.4	17.1	
4/2		1	0.00	3.8	20.4	3.8	16.8	1.08
		2	0.00	3.8	20.4	3.8	16.8	1.08
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F Avg				3.8	16.8	
4/3		1	0.00	3.1	19.9	3.1	16.8	1.32
		2	0.00	3.1	19.9	3.1	16.8	1.32
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F Avg				3.1	16.8	
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP- SACOLA
 Team Leader EJ
 Date Submitted 7-20-96
 Test No. 4
 Date of Analysis 8-6-96

Source NO. 3 CYCLOANE
 Test Site OUTLET
 Date of Test 7-24-94
 No. of Runs Completed 3
 Technician SUD

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
4/1	8024-	1	0.00	3.5	20.5	3.5	17.0	1.11
		2	0.00	2.5	20.5	3.5	17.0	1.11
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.5	17.0
4/2		1	0.00	3.2	20.2	3.2	17.0	1.22
		2	0.00	3.2	20.2	3.2	17.0	1.22
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.2	17.0
4/3		1	0.00	3.8	20.3	3.8	16.5	1.16
		2	0.00	3.8	20.3	3.8	16.5	1.16
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.8	16.5
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job 47-SAGOLA
 Team Leader DB
 Date Submitted 7-20-96
 Test No. 4
 Date of Analysis 7-15-96

Source DRY to Rto STACK
 Test Site STACK
 Date of Test 7-24-96
 No. of Runs Completed 3
 Technician SUP

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
4/1	8024	1	0.00	2.5	20.7	2.5	18.2	1.09
		2	0.00	2.5	20.7	2.5	18.2	1.09
		<input type="checkbox"/> B <input type="checkbox"/> F Avg				2.5	18.2	
4/2		1	0.00	3.2	20.5	3.2	17.3	1.13
		2	0.00	3.2	20.5	3.2	17.3	1.13
		<input type="checkbox"/> B <input type="checkbox"/> F Avg				3.2	17.3	
4/3		1	0.00	2.9	20.5	2.9	17.6	1.14
		2	0.00	2.9	20.5	2.9	17.6	1.14
		<input type="checkbox"/> B <input type="checkbox"/> F Avg				2.9	17.6	
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F Avg						

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

INTERPOL LABORATORIES, INC.

(612) 786-6020

Impinger Catch Data Reporting Sheet

REVIEWED

Protocol:

Minnesota Wisconsin Iowa EPA Method 202 Other

Job

L.P. Sagola

Date Submitted

7/26/96

Date of Analysis

8/5/96

Source/Site

Primary Cyclone Exhaust #1

Test No.

AUG Technician 1996

WT

		Solvent Phase		Aqueous Phase	
Test: 1	Run: 0	Dish No: 847	Dish No: 856		
Log No: 8024 - 01I		Dish + Sample Wt: 45.4145 g	Dish + Sample Wt: 49.2660 g		
Color & Appearance:		Dish Tare Wt: 45.4143 g	Dish Tare Wt: 49.2659 g		
		Fraction Wt: 0.0002 g	Fraction Wt: 0.0001 g		
Comments:		Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333	Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333		
		Sample Wt: 0.0003 g	Sample Wt: 0.0001 g		
Test: 1	Run: 1	Dish No: 852	Dish No: 857		
Log No: -02I		Dish + Sample Wt: 47.5270 g	Dish + Sample Wt: 42.7720 g		
Color & Appearance:		Dish Tare Wt: 47.4072 g	Dish Tare Wt: 42.6674 g		
		Fraction Wt: 0.1198 g	Fraction Wt: 0.1046 g		
Comments:		Smpl Vol: 415 ml, Alqt: 365 ml, Factor 1.137	Smpl Vol: 415 ml, Alqt: 365 ml, Factor 1.137		
		Sample Wt: 0.1362 g	Sample Wt: 0.1189 g		
Test: 1	Run: 2	Dish No: 853	Dish No: 868		
Log No: -03I		Dish + Sample Wt: 47.5441 g	Dish + Sample Wt: 49.4688 g		
Color & Appearance:		Dish Tare Wt: 47.4007 g	Dish Tare Wt: 49.3343 g		
		Fraction Wt: 0.1434 g	Fraction Wt: 0.1345 g		
Comments:		Smpl Vol: 455 ml, Alqt: 405 ml, Factor 1.123	Smpl Vol: 455 ml, Alqt: 405 ml, Factor 1.123		
		Sample Wt: 0.1610 g	Sample Wt: 0.1510 g		
Test: 1	Run: 3	Dish No: 854	Dish No: 870		
Log No: -04I		Dish + Sample Wt: 45.1827 g	Dish + Sample Wt: 44.2054 g		
Color & Appearance:		Dish Tare Wt: 45.0584 g	Dish Tare Wt: 44.0959 g		
		Fraction Wt: 0.1243 g	Fraction Wt: 0.1095 g		
Comments:		Smpl Vol: 370 ml, Alqt: 320 ml, Factor 1.156	Smpl Vol: 370 ml, Alqt: 320 ml, Factor 1.156		
		Sample Wt: 0.1437 g	Sample Wt: 0.1266 g		

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. g

		RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Phase	g	0.0003	0.1359	0.1607	0.1434
Results of Aqueous Phase	g	0.0001	0.1188	0.1509	0.1265

165 8/8/96



INTERPOLL LABORATORIES, INC.

(612) 786-6020

Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job: LP-SAGOLA Source/Site: No. 1 Cyclohex Texaco
 Date Submitted: 7-26-96 Test No.: 1
 Date of Analysis: 8-9-96 Technician: SB
 Transport Leakage None _____ ml Solvent: Acetone

Test: 1	Run: 0	Dish No: 2
Log No: 8024-01		Dish + Sample Wt: 40.0020 g
Volume of Solvent: 95 ml		Dish Tare Wt: 40.0018 g
*Solvent Residue: _____ ug/ml		Sample Wt: .0002 g
Test: 1	Run: 1	Dish No: 767
Vol. of Solvent: 100 ml		Dish + Sample Wt: 42.3691 g
Log Number: -03		Dish Tare Wt: 42.4108 g
Comments		Sample Wt: .1583 g
Test: 1	Run: 2	Dish No: 854
Vol. of Solvent: 90 ml		Dish + Sample Wt: 47.3274 g
Log Number: -03		Dish Tare Wt: 47.2530 g
Comments		Sample Wt: .0744 g
Test: 1	Run: 3	Dish No: 766
Vol. of Solvent: 105 ml		Dish + Sample Wt: 42.3691 42.3266 g
Log Number: -04		Dish Tare Wt: 42.2461 g
Comments		Sample Wt: .0805 g

*Solvent Residue 2.11 ug/ml = [(Sample Wt. .0002g) (10⁶)]/Vol. of Sol. 95 ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

✓SLC

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Rinse	D-82 .0002	0.1581	0.0742	0.0803



INTERPOL LABORATORIES, INC.
 (612) 786-6020

Filter Gravimetrics Reporting Sheet

Filter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: LP - SACRAM Source/Site: No. 1 CYCLOANE TERTHANE
 Date Submitted: 7-26-96 Test No.: 1
 Date of Analysis: 8-9-96 Technician: SD

Test: <u>1</u>	Run: <u>0</u>	Filter No: <u>8633</u>	
Field Blank: <u>8024-01</u>		Filter Type: <u>4" GF</u>	
Log No:		Filter + Sample Wt: <u>1.0499</u>	g
Color: <u>WHITE</u>		Filter Tare Wt: <u>1.0496</u>	g
		Sample Wt: <u>.0003</u>	g
Test: <u>1</u>	Run: <u>1</u>	Filter No: <u>8535</u>	
Log No: <u>-02</u>		Filter Type: <u>4" GF</u>	
Color: <u>DK BRN</u>		Filter + Sample Wt: <u>1.2249</u>	g
		Filter Tare Wt: <u>.9608</u>	g
		Sample Wt: <u>.2641</u>	g
Test: <u>1</u>	Run: <u>2</u>	Filter No: <u>8351</u>	
Log No: <u>-03</u>		Filter Type: <u>4" GF</u>	
Color: <u>DK BRN</u>		Filter + Sample Wt: <u>1.3804</u>	g
		Filter Tare Wt: <u>.9407</u>	g
		Sample Wt: <u>.4397</u>	g
Test: <u>1</u>	Run: <u>3</u>	Filter No: <u>8575</u>	
Log No: <u>-04</u>		Filter Type: <u>4" GF</u>	
Color: <u>DK BRN</u>		Filter + Sample Wt: <u>1.5954</u>	g
		Filter Tare Wt: <u>1.0473</u>	g
		Sample Wt: <u>.5483</u>	g

SD

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Filter Analysis g		<u>0.2641</u>	<u>0.4397</u>	<u>0.5483</u>

	RUN	RUN	RUN	RUN
Total Mass g				



REVIEWED
AUG 15 1996
Date of Analysis: 8/12/96

Ion Chromatography Laboratory

DIONEX MODEL 40001 WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: MTG

Job: 1D020/LP Sagola Source: Cyclone #1 Site: Exhaust

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient(List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
* A										
* B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch +	8024-01	200	1.0	<0.025	<5.0	<0.0010
Mech. Finse	02	415	1.0	0.670	257	0.0054
	03	455	1.0	0.449	204	0.0042
	04	370	1.0	0.217	80.3	0.0017
METHOD 8/27/96 BLANK 200 pm	Blank	400	1.0	<0.025	<10	<0.0021

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000



6-8024.202

A	B	C	D	E	F	G	H	I	J	
1	EPA Method 202 Calculations									
2	Job: LP/sagola									
3	Date: 23-Jul-96									
4	Dryer Primary Cyclone Exhaust 1									
5	Vic	Sulfate	MC	Mr	Mi	MO	Mb	CPM	ENTER IN	
6	(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER	
7	415	6.20E-04	0.05	136.2	136.15	118.9	0.4	254.65	(g)	
8	455	4.49E-04	0.04	161	160.96	151	0.4	311.56	0.2547	
9	370	2.17E-04	0.01	143.7	143.69	126.6	0.4	269.89	0.3116	
10										
11										
12	EPA Method 201A/202 Totals									
13	Probe	Filter	CPM	Total						
14	(mg)	(mg)	(mg)	(mg)						
15	RUN	158.1	264.1	254.65	676.8527					
16	1	74.2	439.7	311.56	825.4624					
17	2	80.3	548.3	269.89	898.4852					
18	3									

Report No. 6-8024



REVIEWED

Impinger Catch Data Reporting Sheet

Protocol:

Minnesota Wisconsin Iowa EPA Method 202 Other

Job

L.P. Sagola

Source/Site

NO. 2 Cyclone, Inlet

Date Submitted

7/26/96

Test No.

Date of Analysis

8/5/96

Technician

YLT

		Solvent Phase		Aqueous Phase	
Test: 1	Run: 0	Dish No: 845		Dish No: 856	
Log No: 8024-01I		Dish + Sample Wt: 45.4145 g		Dish + Sample Wt: 49.2660 g	
Color & Appearance:		Dish Tare Wt: 45.4143 g		Dish Tare Wt: 49.2659 g	
		Fraction Wt: 0.0002 g		Fraction Wt: 0.0001 g	
Comments:		Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333		Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333	
		Sample Wt: 0.0003 g		Sample Wt: 0.0001 g	
Test: 1	Run: 1	Dish No: 32		Dish No: 796	
Log No: -35I		Dish + Sample Wt: 57.8615 g		Dish + Sample Wt: 44.8695 g	
Color & Appearance:		Dish Tare Wt: 57.8111 g		Dish Tare Wt: 44.7972 g	
		Fraction Wt: 0.0504 g		Fraction Wt: 0.0723 g	
Comments:		Smpl Vol: 415 ml, Alqt: 365 ml, Factor: 1.137		Smpl Vol: 415 ml, Alqt: 365 ml, Factor: 1.137	
		Sample Wt: 0.0573 g		Sample Wt: 0.0822 g	
Test: 1	Run: 2	Dish No: 41		Dish No: 795	
Log No: -36I		Dish + Sample Wt: 45.3650 g		Dish + Sample Wt: 44.0937 g	
Color & Appearance:		Dish Tare Wt: 45.3211 g		Dish Tare Wt: 44.0318 g	
		Fraction Wt: 0.0439 g		Fraction Wt: 0.0619 g	
Comments:		Smpl Vol: 405 ml, Alqt: 355 ml, Factor: 1.141		Smpl Vol: 405 ml, Alqt: 355 ml, Factor: 1.141	
		Sample Wt: 0.0501 g		Sample Wt: 0.0706 g	
Test: 1	Run: 3	Dish No: 43		Dish No: 771	
Log No: -37I		Dish + Sample Wt: 47.4360 g		Dish + Sample Wt: 43.8974 g	
Color & Appearance:		Dish Tare Wt: 47.3975 g		Dish Tare Wt: 43.8234 g	
		Fraction Wt: 0.0385 g		Fraction Wt: 0.0740 g	
Comments:		Smpl Vol: 400 ml, Alqt: 350 ml, Factor: 1.143		Smpl Vol: 400 ml, Alqt: 350 ml, Factor: 1.143	
		Sample Wt: 0.0440 g		Sample Wt: 0.0846 g	

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. _____ g

		VGL			
		RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Phase	g	0.0003	0.0570	0.0498	0.0437
Results of Aqueous Phase	D-16g	0.0001	0.0821	0.0705	0.0845



INTERPOL LABORATORIES, INC.

(612) 786-6020

Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job LP-SAGULA Source/Site No. 2 CYCLONE OUTLET
 Date Submitted 7-26-96 Test No. 1
 Date of Analysis 8-9-96 Technician SCB
 Transport Leakage None .ml Solvent DLX7019

Test: <u>1</u>	Run: <u>1</u>	Dish No: <u>23</u>
Log No: <u>8024-35</u>		Dish + Sample Wt: <u>46.2111</u> g
Volume of Solvent <u>70</u> ml		Dish Tare Wt: <u>46.0863</u> g
*Solvent Residue <u> </u> ug/ml		Sample Wt: <u>.1249</u> g
Test: <u>1</u>	Run: <u>2</u>	Dish No: <u># 59</u>
Vol. of Solvent <u>80</u> ml		Dish + Sample Wt: <u>38.6321</u> g
Log Number <u>-36</u>		Dish Tare Wt: <u>38.5853</u> g
Comments		Sample Wt: <u>.0468</u> g
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>749</u>
Vol. of Solvent <u>75</u> ml		Dish + Sample Wt: <u>43.3510</u> g
Log Number <u>-37</u>		Dish Tare Wt: <u>43.2907</u> g
Comments		Sample Wt: <u>.0603</u> g
Test: <u> </u>	Run: <u> </u>	Dish No: <u> </u>
Vol. of Solvent <u> </u> ml		Dish + Sample Wt: <u> </u> g
Log Number <u> </u>		Dish Tare Wt: <u> </u> g
Comments <u> </u>		Sample Wt: <u> </u> g

*Solvent Residue ug/ml = [(Sample Wt. g) (10⁶)]/Vol. of Sol. ml

EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

	RUN 1	RUN 2	RUN 3	RUN
Results of Solvent Rinse <u> </u> g	<u>0.1247</u>	<u>0.0466</u>	<u>0.0601</u>	



INTERPOLL LABORATORIES, INC.

(612) 786-6020

Filter Gravimetrics Reporting Sheet

Fiter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: LP - SACOLA Source/Site: No. 2 CYCLONE OUTLET
 Date Submitted: 7-26-96 Test No.: 1
 Date of Analysis: 8-9-96 Technician: SCR

Test: 1	Run: 1	Filter No: 8585	
Field Blank:		Filter Type: 4" G.F.	
Log No: 8024-35		Filter + Sample Wt: 1.2932	g
Color: DK BRN		Filter Tare Wt: 1.0559	g
		Sample Wt: .2373	g
Test: 1	Run: 2	Filter No: 8560	
Log No: -36		Filter Type: 4" G.F.	
Color: DK BRN		Filter + Sample Wt: 1.3396	g
		Filter Tare Wt: 1.0401	g
		Sample Wt: .2995	g
Test: 1	Run: 3	Filter No: 8642	
Log No: -37		Filter Type: 4" G.F.	
Color: DK BRN		Filter + Sample Wt: 1.3744	g
		Filter Tare Wt: 1.0288	g
		Sample Wt: .3456	g
Test:	Run:	Filter No:	
Log No:		Filter Type:	
Color:		Filter + Sample Wt:	g
		Filter Tare Wt:	g
		Sample Wt:	g

VGN

	RUN 1	RUN 2	RUN 3	RUN
Results of Filter Analysis	g 0.2373	0.2995	0.3456	

	RUN	RUN	RUN	RUN
Total Mass	g			



REVIEWED

Dec 8/8/96

Ion Chromatography Laboratory

AUG 15 1996

DIONEX MODEL 40001 WITH ANION MICRO MEMBRANE SUPPRESSION

Robert J. Wark
Date of Analysis: 8/12/96

Analyst: MJB

Job: ID020 / LP Sassa Source: No. 2 Cyclone Site: outlet

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient (List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
* A										
* B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch	8024-35	415	1.0	0.625	259	0.0054
↓	36	405	1.0	0.822	333	0.0069
↓	37	400	1.0	0.307	123	0.0026
METHOD 8/12/96 BLANK 7:00pm	Blank	400	1.0	<0.025	<10	<0.00021

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

LSC-08RR



	A	B	C	D	E	F	G	H	I	J
19										
20										
21	EPA Method 202 Calculations									Report No. 6-8024
22	Job: LP/Sagola									
23	Date: 23-Jul-96									
24	<i>Dryer Primary Cyclone Exhaust 2</i>									
25		Vlc	Sulfate	MC	Mr	MI	MO	Mb	CPM	ENTER IN
26	RUN	(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER
27	1	415	6.25E-04	0.05	57.3	57.25	82.2	0.4	139.05	(g)
28	2	405	8.22E-04	0.06	50.1	50.04	70.6	0.4	120.24	
29	3	400	3.07E-04	0.02	44	43.98	84.6	0.4	128.18	
30										
31										
32	EPA Method 201A/202 Totals									
33										
34		Probe	Filter	CPM	Total					
35	RUN	(mg)	(mg)	(mg)	(mg)					
36	1	124.7	237.3	139.05	501.0523					
37	2	46.6	299.5	120.24	466.3387					
38	3	60.1	345.6	128.18	533.8774					
39										



REVIEWED
 INTERPOL LABORATORIES, INC.
 (612) 786-6020

Impinger Catch Data Reporting Sheet

Protocol: Minnesota Wisconsin Iowa EPA Method 202 Other
 Job: L.P. Sasola Source/Site: DRYER 3 PRIMARY CYCLONE PHASE
 Date Submitted: 7/26/96 Test No.: 1
 Date of Analysis: 8/5/96 Technician: WJ

		Solvent Phase		Aqueous Phase	
Test: 1	Run: 0	Dish No: 328	Dish No: 872		
Log No: 804-OAT		Dish + Sample Wt: 41.9694 g	Dish + Sample Wt: 47.2517 g		
Color & Appearance:		Dish Tare Wt: 41.9689 g	Dish Tare Wt: 47.2517 g		
		Fraction Wt: 0.0005 g	Fraction Wt: 0.0000 g		
Comments:		Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333	Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333		
		Sample Wt: 0.0007 g	Sample Wt: 0.0000 g		
Test: 1	Run: 1	Dish No: 400	Dish No: 892		
Log No: -072I		Dish + Sample Wt: 47.1972 g	Dish + Sample Wt: 38.1744 g		
Color & Appearance:		Dish Tare Wt: 47.1036 g	Dish Tare Wt: 38.1005 g		
		Fraction Wt: 0.0936 g	Fraction Wt: 0.0739 g		
Comments:		Smpl Vol: 430 ml, Alqt: 380 ml, Factor: 1.132	Smpl Vol: 430 ml, Alqt: 380 ml, Factor: 1.132		
		Sample Wt: 0.1060 g	Sample Wt: -0.09750.0836 g		
Test: 1	Run: 2	Dish No: 404	Dish No: 896		
Log No: -073I		Dish + Sample Wt: 47.7513 g	Dish + Sample Wt: 39.7392 g		
Color & Appearance:		Dish Tare Wt: 47.6449 g	Dish Tare Wt: 39.6525 g		
		Fraction Wt: 0.1064 g	Fraction Wt: 0.0867 g		
Comments:		Smpl Vol: 355 ml, Alqt: 305 ml, Factor: 1.164	Smpl Vol: 355 ml, Alqt: 305 ml, Factor: 1.164		
		Sample Wt: 0.1238 g	Sample Wt: 0.1009 g		
Test: 1	Run: 3	Dish No: 411	Dish No: 897		
Log No: -074I		Dish + Sample Wt: 46.7664 g	Dish + Sample Wt: 39.0629 g		
Color & Appearance:		Dish Tare Wt: 46.6882 g	Dish Tare Wt: 38.9856 g		
		Fraction Wt: 0.0782 g	Fraction Wt: 0.0773 g		
Comments:		Smpl Vol: 350 ml, Alqt: 300 ml, Factor: 1.167	Smpl Vol: 350 ml, Alqt: 300 ml, Factor: 1.167		
		Sample Wt: 0.0913 g	Sample Wt: 0.0902 g		

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. _____ g

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Phase g	0.0007	0.1053	0.1057.1234	0.0906
Results of Aqueous Phase g	0.0000	0.0975	0.1009	0.0902



Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job: LP-SAGOLA Source/Site: NO 3 CYCLONE EXHAUST
 Date Submitted: 7-26-96 Test No.: 1
 Date of Analysis: 8-9-96 Technician: SIB
 Transport Leakage: None ml Solvent: ACETONE

Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>700</u>
Log No: <u>8024-71</u>		Dish + Sample Wt: <u>49.7642</u> g
Volume of Solvent: <u>155</u> ml		Dish Tare Wt: <u>49.7639</u> g
*Solvent Residue: <u> </u> ug/ml		Sample Wt: <u>.0003</u> g
Test: <u>1</u>	Run: <u>1</u>	Dish No: <u>748</u>
Vol. of Solvent: <u>-72</u>	<u>120</u> ml	Dish + Sample Wt: <u>45.5058</u> g
Log Number		Dish Tare Wt: <u>45.3891</u> g
Comments		Sample Wt: <u>.1167</u> g
Test: <u>1</u>	Run: <u>2</u>	Dish No: <u>769</u>
Vol. of Solvent: <u>-73</u>	<u>100</u> ml	Dish + Sample Wt: <u>45.2736</u> g
Log Number		Dish Tare Wt: <u>45.1966</u> g
Comments		Sample Wt: <u>.0770</u> g
Test: <u>1-</u>	Run: <u>3</u>	Dish No: <u>616</u>
Vol. of Solvent: <u>-74</u>	<u>110</u> ml	Dish + Sample Wt: <u>50.9973</u> g
Log Number		Dish Tare Wt: <u>50.9300</u> g
Comments		Sample Wt: <u>.0673</u> g

*Solvent Residue 194 ug/ml = [(Sample Wt. .0003 g) (10⁶)] / Vol. of Sol. 155 ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

vsu

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Rinse	<u>1.0003</u>	<u>0.1165</u>	<u>0.0768</u>	<u>0.0671</u>





REVIEWED

Ion Chromatography Laboratory

AUG 15 1996

DIONEX MODEL 4000i WITH ANION MICRO MEMBRANE SUPPRESSION

John J. Winkler
Date of Analysis: 8/12/96

Analyst: MJG

Job: 10020 / LP Sagola Source: No. 3 Cyclone Site: outlet

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
<i>✓</i> AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	<i>✓</i>	Isocratic
	ml/min			Gradient (List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
* A										
* B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch	8024-71	200	1.0	<0.025	<5.0	<0.0010
	72	430	1.0	0.664	286	0.0060
	73	355	1.0	0.268	95.1	0.0020
	74	350	1.0	0.177	62.0	0.0013
METHOD 8/12/96 BLANK 7:00 PM	Blank	400	1.0	<0.025	<10	<0.00021

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

LSC-08RR



	A	B	C	D	E	F	G	H	I	J
40										
41										
42		EPA Method 202 Calculations								
43		Job: LP/Sagola								
44		Date: 23-Jul-96								
45		Dryer Primary Cyclone Exhaust 3								
46		Vic	Sulfate	MC	Mf	MI	MO	Mb	CPM	ENTER IN
47		(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER
48		1	430	6.64E-04	0.05	106	105.95	83.6	0.7	188.85
49		2	355	2.68E-04	0.02	123.8	123.78	100.9	0.7	223.98
50		3	350	1.77E-04	0.01	91.3	91.29	90.2	0.7	180.79
51										0.1888
52										0.2240
53		EPA Method 201A/202 Totals								
54										0.1808
55		Probe	Filter	CPM	Total					
56		(mg)	(mg)	(mg)	(mg)					
57		1	116.5	283.1	188.85	588.4475				
58		2	76.8	307.5	223.98	608.2825				
59		3	67.1	286.2	180.79	534.0886				
60										

Report No. 6-8024



REVIEWED

Impinger Catch Data Reporting Sheet

AUG 9 1996
 EPA Method 202 Other
 Source/Site: E TUBES / OUTLET
 Technician: [Signature]

Protocol: Minnesota Wisconsin Iowa
 Job: L-P Sagola
 Date Submitted: 7/26/96
 Date of Analysis: 8/6/96

		Solvent Phase		Aqueous Phase	
Test: 1	Run: 0	Dish No: 754	Dish No: 161		
Log No: 8024-105 I	Dish + Sample Wt: 45.2843 g	Dish + Sample Wt: 49.1386 g			
Color & Appearance:	Dish Tare Wt: 45.2840 g	Dish Tare Wt: 49.1386 g			
	Fraction Wt: 0.0003 g	Fraction Wt: 0.0000 g			
Comments:	Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333	Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333			
	Sample Wt: 0.0004 g	Sample Wt: 0.0000 g			
Test: 1	Run: 1	Dish No: 751	Dish No: 45		
Log No: -106 I	Dish + Sample Wt: 44.2791 g	Dish + Sample Wt: 48.1855 g			
Color & Appearance:	Dish Tare Wt: 44.2550 g	Dish Tare Wt: 48.1536 g			
	Fraction Wt: 0.0241 g	Fraction Wt: 0.0319 g			
Comments:	Smpl Vol: 380 ml, Alqt: 330 ml, Factor 1.152	Smpl Vol: 380 ml, Alqt: 330 ml, Factor 1.152			
	Sample Wt: 0.0278 g	Sample Wt: 0.0367 g			
Test: 1	Run: 2	Dish No: 755	Dish No: 50		
Log No: -107 I	Dish + Sample Wt: 46.0264 g	Dish + Sample Wt: 45.4997 g			
Color & Appearance:	Dish Tare Wt: 45.9977 g	Dish Tare Wt: 45.4684 g			
	Fraction Wt: 0.0287 g	Fraction Wt: 0.0313 g			
Comments:	Smpl Vol: 380 ml, Alqt: 330 ml, Factor 1.152	Smpl Vol: 380 ml, Alqt: 330 ml, Factor 1.152			
	Sample Wt: 0.0331 g	Sample Wt: 0.0361 g			
Test: 1	Run: 3	Dish No: 702	Dish No: 209		
Log No: -108 I	Dish + Sample Wt: 46.2102 g	Dish + Sample Wt: 43.2451 g			
Color & Appearance:	Dish Tare Wt: 46.2249 g	Dish Tare Wt: 43.2082 g			
	Fraction Wt: 0.0353 g	Fraction Wt: 0.0369 g			
Comments:	Smpl Vol: 365 ml, Alqt: 315 ml, Factor 1.159	Smpl Vol: 365 ml, Alqt: 315 ml, Factor 1.159			
	Sample Wt: 0.0409 g	Sample Wt: 0.0428 g			

Note: Factor = Sample Volume/Aliquot Volume Blank Solvent Wt: _____ g

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Phase g	0.0004	0.0274	0.0327	0.0405
Results of Aqueous Phase D ₂₆ ^B	0.0000	0.0367	0.0361	0.0428



Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash

EPA Method 29 Probe Wash

EPA Method 202 Cup & Tube Wash

Job
Date Submitted
Date of Analysis

LP - SACOLA
7-26-96
8-9-96

Source/Site
Test No.
Technician

"E" TUBE OUTLET
1
SOB
ACETONE

Transport Leakage

None _____ ml Solvent

Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>10</u>	
Log No: <u>8024-105</u>		Dish + Sample Wt: <u>32.4740</u>	g
Volume of Solvent	<u>115</u> ml	Dish Tare Wt: <u>32.4735</u>	g
*Solvent Residue	ug/ml	Sample Wt: <u>.0005</u>	g
Test: <u>1</u>	Run: <u>1</u>	Dish No: <u>77</u>	
Vol. of Solvent	<u>85</u> ml	Dish + Sample Wt: <u>36.6050</u>	g
Log Number <u>-106</u>		Dish Tare Wt: <u>35.9894</u>	g
Comments		Sample Wt: <u>.0156</u>	g
Test: <u>1</u>	Run: <u>2</u>	Dish No: <u>809</u>	
Vol. of Solvent	<u>95</u> ml	Dish + Sample Wt: <u>48.2330</u>	g
Log Number <u>-107</u>		Dish Tare Wt: <u>48.2227</u>	g
Comments		Sample Wt: <u>.0103</u>	g
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>816</u>	
Vol. of Solvent	<u>85</u> ml	Dish + Sample Wt: <u>43.9360</u>	g
Log Number <u>-108</u>		Dish Tare Wt: <u>43.9257</u>	g
Comments		Sample Wt: <u>.0103</u>	g

*Solvent Residue 4.35 ug/ml = [(Sample Wt. .0005g) (10⁶)] / Vol. of Sol. 115 ml
EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

VOL

	RUN <u>0</u>	RUN <u>1</u>	RUN <u>2</u>	RUN <u>3</u>
Results of Solvent Rinse	<u>10005</u>	<u>0.0152</u>	<u>0.0099</u>	<u>0.0104</u>

D-27



INTERPOLL LABORATORIES, INC.

(612) 786-6020

Filter Gravimetrics Reporting Sheet

Filter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: LP-SAGOLA Source/Site: E-TUBE OUTPUT
 Date Submitted: 7-26-96 Test No.: 1
 Date of Analysis: 8-9-96 Technician: SLB

Test: 1	Run: 0	Filter No: 8429
Field Blank:		Filter Type: 4" G.F.
Log No: 4024-105		Filter + Sample Wt: .9502 g
Color: WHITE		Filter Tare Wt: .9501 g
		Sample Wt: .0001 g
Test: 1	Run: 1	Filter No: 8431
Log No: -106		Filter Type: 4" G.F.
Color: TAN		Filter + Sample Wt: .9598 g
		Filter Tare Wt: .9518 g
		Sample Wt: .0080 g
Test: 1	Run: 2	Filter No: 8433
Log No: -107		Filter Type: 4" G.F.
Color: TAN		Filter + Sample Wt: .9560 g
		Filter Tare Wt: .9520 g
		Sample Wt: .0040 g
Test: 1	Run: 3	Filter No: 8432
Log No: -108		Filter Type: 4" G.F.
Color: TAN		Filter + Sample Wt: .9525 g
		Filter Tare Wt: .9468 g
		Sample Wt: .0057 g

SLB

Results of Filter Analysis	g	RUN 0	RUN 1	RUN 2	RUN 3
			0.0080	0.0040	0.0057

Total Mass	g	RUN	RUN	RUN	RUN



REVIEWED

AUG 15 1996

DIONEX MODEL 40001 WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: MJG

Date of Analysis: 8/10/96

Job: 10020/ LP Sample

Source: E-Tube

Site: Outlet

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
<u>k</u> AS4A	<u>2</u> ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	<input checked="" type="checkbox"/>	Isocratic
	ml/min			Gradient (List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
* A										
* B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch	8024-105	200	1.0	<0.025	<5.0	<0.0010
	106	380	1.0	0.850	323	0.0067
	107	380	1.0	0.269	102	0.0021
	108	365	1.0	0.277	101	0.0021
METHOD 8/12/96 BLANK 2100 PM	Blank	400	1.0	<0.025	<10	<0.0021

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000



	A	B	C	D	E	F	G	H	I	J
61	Report No. 6-8024									
62	EPA Method 202 Calculations									
63	Job: LP/Sagola									
64	Date: 23-Jul-96									
65	<i>E-Tube Outlet</i>									
66		Vic	Sulfate	MC	Mr	MI	MO	Mb	CPM	ENTER IN
67		(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER
68	RUN									(g)
69	1	380	8.50E-04	0.06	27.8	27.74	36.7	0.4	64.04	0.0640
70	2	380	2.69E-04	0.02	33.1	33.08	36.1	0.4	68.78	0.0688
71	3	365	2.77E-04	0.02	40.9	40.88	42.8	0.4	83.28	0.0833
72										
73										
74	EPA Method 201A/202 Totals									
75										
76		Probe	Filter	CPM	Total					
77	RUN	(mg)	(mg)	(mg)	(mg)					
78	1	15.2	8	64.04	87.24057					
79	2	9.9	4	68.78	82.68119					
80	3	10.4	5.7	83.28	99.3814					



Impinger Catch Data Reporting Sheet

AUG 20 1996

Protocol: Minnesota Wisconsin Iowa

EPA Method 202 Other

Job: L.P. Sagala

Source/Site: DRYER/RTO STACK

Date Submitted: 7/29/96

Test No.: 1

Date of Analysis: 8/16/96

Technician: VLS

		Solvent Phase		Aqueous Phase	
Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>831</u>	Dish No: <u>208</u>		
Log No: <u>8024 H3T</u>	Dish + Sample Wt: <u>43.6422</u> g	Dish + Sample Wt: <u>52.8005</u> g			
Color & Appearance:	Dish Tare Wt: <u>42.6419</u> g	Dish Tare Wt: <u>52.8004</u> g			
	Fraction Wt: <u>0.0003</u> g	Fraction Wt: <u>0.0001</u> g			
Comments:	Smpl Vol: <u>200</u> ml, Alqt: <u>150</u> ml, Factor: <u>1.333</u>		Smpl Vol: <u>200</u> ml, Alqt: <u>150</u> ml, Factor: <u>1.333</u>		
	Sample Wt: <u>0.0004</u> g	Sample Wt: <u>0.0001</u> g			
Test: <u>1</u>	Run: <u>1</u>	Dish No: <u>835</u>	Dish No: <u>797</u>		
Log No: <u>-144T</u>	Dish + Sample Wt: <u>44.9815</u> g	Dish + Sample Wt: <u>43.0542</u> g			
Color & Appearance:	Dish Tare Wt: <u>44.9773</u> g	Dish Tare Wt: <u>43.0494</u> g			
	Fraction Wt: <u>0.0042</u> g	Fraction Wt: <u>0.0048</u> g			
Comments:	Smpl Vol: <u>455</u> ml, Alqt: <u>405</u> ml, Factor: <u>1.123</u>		Smpl Vol: <u>455</u> ml, Alqt: <u>405</u> ml, Factor: <u>1.123</u>		
	Sample Wt: <u>0.0047</u> g	Sample Wt: <u>0.0054</u> g			
Test: <u>1</u>	Run: <u>2</u>	Dish No: <u>843</u>	Dish No: <u>58</u>		
Log No: <u>-145I</u>	Dish + Sample Wt: <u>49.9355</u> g	Dish + Sample Wt: <u>40.7193</u> g			
Color & Appearance:	Dish Tare Wt: <u>49.9296</u> g	Dish Tare Wt: <u>40.7146</u> g			
	Fraction Wt: <u>0.0059</u> g	Fraction Wt: <u>0.0047</u> g			
Comments:	Smpl Vol: <u>430</u> ml, Alqt: <u>380</u> ml, Factor: <u>1.132</u>		Smpl Vol: <u>430</u> ml, Alqt: <u>380</u> ml, Factor: <u>1.132</u>		
	Sample Wt: <u>0.0067</u> g	Sample Wt: <u>0.0053</u> g			
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>844</u>	Dish No: <u>105</u>		
Log No: <u>-146I</u>	Dish + Sample Wt: <u>45.0281</u> g	Dish + Sample Wt: <u>38.1345</u> g			
Color & Appearance:	Dish Tare Wt: <u>45.0225</u> g	Dish Tare Wt: <u>38.1297</u> g			
	Fraction Wt: <u>0.0056</u> g	Fraction Wt: <u>0.0048</u> g			
Comments:	Smpl Vol: <u>490</u> ml, Alqt: <u>440</u> ml, Factor: <u>1.114</u>		Smpl Vol: <u>490</u> ml, Alqt: <u>440</u> ml, Factor: <u>1.114</u>		
	Sample Wt: <u>0.0062</u> g	Sample Wt: <u>0.0052</u> g			

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. _____ g

		RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Phase	g	0.0004	0.0043	0.0063	0.0058
Results of Aqueous Phase	D-31 g	0.0001	0.0053	0.0052	0.0052



INTERPOL LABORATORIES, INC.
 (612) 786-6020
Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job: LP-SAGOLA Source/Site: DRY-IN RTO STACK
 Date Submitted: 7-26-96 Test No.: 1
 Date of Analysis: 8-9-96 Technician: SLB
 Transport Leakage None _____ ml Solvent: ACETONE

Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>28</u>	
Log No: <u>8024-143</u>		Dish + Sample Wt: <u>42.1765</u>	g
Volume of Solvent	<u>105</u> ml	Dish Tare Wt: <u>42.1760</u>	g
*Solvent Residue	ug/ml	Sample Wt: <u>.0005</u>	g
Test: <u>1</u>	Run: <u>1</u>	Dish No: <u>879</u>	
Vol. of Solvent	<u>130</u> ml	Dish + Sample Wt: <u>38.6670</u>	g
Log Number <u>-144</u>		Dish Tare Wt: <u>38.6607</u>	g
Comments		Sample Wt: <u>.0063</u>	g
Test: <u>1</u>	Run: <u>2</u>	Dish No: <u>797</u>	
Vol. of Solvent	<u>85</u> ml	Dish + Sample Wt: <u>45.9620</u>	g
Log Number <u>-145</u>		Dish Tare Wt: <u>45.9563</u>	g
Comments		Sample Wt: <u>.0057</u>	g
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>22</u>	
Vol. of Solvent	<u>75</u> ml	Dish + Sample Wt: <u>51.3657</u>	g
Log Number <u>-146</u>		Dish Tare Wt: <u>51.3629</u>	g
Comments		Sample Wt: <u>.0028</u>	g

*Solvent Residue 4.76 ug/ml = [(Sample Wt. .0005g) (10⁶)] / Vol. of Sol. 105 ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

Vgn

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Rinse	<u>.0005</u>	<u>0.0057</u>	<u>0.0053</u>	<u>0.0024</u>



Filter Gravimetrics Reporting Sheet

Filter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: LP-SAGOLA
Date Submitted: 7-26-96
Date of Analysis: 8-9-96

Source/Site: Dryer PTO STACK
Test No.: 1
Technician: SUB

Test: <u>1</u>	Run: <u>0</u>	Filter No: <u>8596</u>	
Field Blank:		Filter Type: <u>4" G.F.</u>	
Log No: <u>8024-143</u>		Filter + Sample Wt: <u>.9926</u>	g
Color: <u>WHITE</u>		Filter Tare Wt: <u>.9936</u>	g
		Sample Wt: <u>.0000</u>	g
Test: <u>1</u>	Run: <u>1</u>	Filter No: <u>8191</u>	
Log No: <u>-144</u>		Filter Type: <u>4" G.F.</u>	
Color: <u>LT. TAN</u>		Filter + Sample Wt: <u>.9175</u>	g
		Filter Tare Wt: <u>.9171</u>	g
		Sample Wt: <u>.0004</u>	g
Test: <u>1</u>	Run: <u>2</u>	Filter No: <u>7976</u>	
Log No: <u>-145</u>		Filter Type: <u>4" G.F.</u>	
Color: <u>LT. TAN</u>		Filter + Sample Wt: <u>.9468</u>	g
		Filter Tare Wt: <u>.9442</u>	g
		Sample Wt: <u>.0026</u>	g
Test: <u>1</u>	Run: <u>3</u>	Filter No: <u>8594</u>	
Log No: <u>-146</u>		Filter Type: <u>4" G.F.</u>	
Color: <u>LT. TAN</u>		Filter + Sample Wt: <u>.8630</u>	g
		Filter Tare Wt: <u>.8616</u>	g
		Sample Wt: <u>.0014</u>	g

VGN

	RUN <u>0</u>	RUN <u>1</u>	RUN <u>2</u>	RUN <u>3</u>
Results of Filter Analysis	g	<u>0.0004</u>	<u>0.0026</u>	<u>0.0014</u>

	RUN	RUN	RUN	RUN
Total Mass	g			



REVIEWED

AUG 15 1996

DIONEX MODEL 40001 WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: MTJ

Date of Analysis: 8/13/96

Job: 10020/LP Sample Source: Dryer RTO Site: STACK

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X Isocratic	
	ml/min		Gradient (List program below)	

Gradient Program	Time (Min.)									
Eluent	0.0									
% A										
% B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch	8024-143	200	1.0	0.025	<5.0	<0.00010
	144	455	1.0	0.109	49.6	0.0010
	145	430	1.0	0.0986	42.4	0.00089
	146	490	1.0	0.208	102	0.0021
METHOD 8/14/96 BLANK 7:00 PM	BLANK	490	1.0	<0.025	<11	<0.00021

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

LSC-08RR



	A	B	C	D	E	F	G	H	I	J							
81	Report No. 6-8024																
82	EPA Method 202 Calculations																
83	Job: LP/sagola																
84	Date: 23-Jul-96																
85	Dryer RTO Stack																
86	Vic	(ml)	Sulfate	(mg/ml)	MC	(mg)	MR	(mg)	MI	(mg)	MO	(mg)	Mb	(mg)	CPM	(mg)	ENTER IN
87	RUN	1	455	1.09E-04	0.01	4.7	4.69	5.4	0.5	9.59	0.0096						
88		2	430	9.86E-05	0.01	6.7	6.69	5.3	0.5	11.49	0.0115						
89		3	490	2.08E-04	0.02	6.2	6.18	5.3	0.5	10.98	0.0110						
90																	
91																	
92	EPA Method 201A/202 Totals																
93																	
94																	
95	Probe	(mg)	Filter	(mg)	CPM	Total	(mg)										
96	RUN	1	5.7	0.4	9.59	15.69087											
97		2	5.3	2.6	11.49	19.3922											
98		3	2.4	1.4	10.98	14.78125											
99																	



Impinger Catch Data Reporting Sheet

Protocol:

Minnesota Wisconsin Iowa

AP 1996
 EPA Method 202 Other

Job

L.P. Sagola

Source/Site: Dress RTO / Stack

Date Submitted

7/26/96

Test No. 7
 Technician [Signature]

Date of Analysis

8/6/96

		Solvent Phase		Aqueous Phase	
Test: 1	Run: 0	Dish No: 831	Dish No: 208		
Log No: 8024-143I		Dish + Sample Wt: 43.6422 g	Dish + Sample Wt: 52.8005 g		
Color & Appearance:		Dish Tare Wt: 43.6419 g	Dish Tare Wt: 52.8004 g		
		Fraction Wt: 0.0003 g	Fraction Wt: 0.0001 g		
Comments:		Smpl Vol: 250 ml, Alqt: 50 ml, Factor: 1.333	Smpl Vol: 200 ml, Alqt: 50 ml, Factor: 1.333		
		Sample Wt: 0.0004 g	Sample Wt: 0.0001 g		
Test: 7	Run: 1	Dish No: 770	Dish No: 55		
Log No: -133I		Dish + Sample Wt: 45.3828 g	Dish + Sample Wt: 47.7983 g		
Color & Appearance:		Dish Tare Wt: 45.3807 g	Dish Tare Wt: 47.7781 g		
		Fraction Wt: 0.0021 g	Fraction Wt: 0.0202 g		
Comments:		Smpl Vol: 240 ml, Alqt: 90 ml, Factor: 2.63	Smpl Vol: 240 ml, Alqt: 90 ml, Factor: 2.63		
		Sample Wt: 0.0027 g	Sample Wt: 0.0255 g		
Test: 7	Run: 2	Dish No: 324	Dish No: 56		
Log No: -134I		Dish + Sample Wt: 46.7794 g	Dish + Sample Wt: 47.7590 g		
Color & Appearance:		Dish Tare Wt: 46.2182 g	Dish Tare Wt: 47.7563 g		
		Fraction Wt: 0.0612 g	Fraction Wt: 0.0027 g		
Comments:		Smpl Vol: 230 ml, Alqt: 80 ml, Factor: 2.78	Smpl Vol: 230 ml, Alqt: 80 ml, Factor: 2.78		
		Sample Wt: 0.0782 g	Sample Wt: 0.0035 g		
Test: 7	Run: 3	Dish No: 326	Dish No: 106		
Log No: 135I		Dish + Sample Wt: 43.4989 g	Dish + Sample Wt: 43.0209 g		
Color & Appearance:		Dish Tare Wt: 43.4968 g	Dish Tare Wt: 43.0170 g		
		Fraction Wt: 0.0021 g	Fraction Wt: 0.0039 g		
Comments:		Smpl Vol: 245 ml, Alqt: 95 ml, Factor: 1.256	Smpl Vol: 245 ml, Alqt: 95 ml, Factor: 1.256		
		Sample Wt: 0.0026 g	Sample Wt: 0.0049 g		

Note: Factor = Sample Volume / Aliquot Volume

		Blank Solvent Wt. g			
		RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Phase	g	0.0004	0.0023	0.0778	0.0022
Results of Aqueous Phase	D-36 g	0.0001	0.0254	0.0034	0.0048



INTERPOLL LABORATORIES, INC.
(612) 786-6020
Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job: LP - SAGUNA Source/Site: PRESS RTO STACK
 Date Submitted: 7-26-96 Test No.: 7
 Date of Analysis: 8-9-96 Technician: SB
 Transport Leakage None _____ ml Solvent: ACETONE

Test: <u>7</u>	Run: <u>1</u>	Dish No: <u>845</u>
Log No: <u>9024-133</u>		Dish + Sample Wt: <u>42.3572</u> g
Volume of Solvent: <u>130</u> ml		Dish Tare Wt: <u>42.3444</u> g
*Solvent Residue: _____ ug/ml		Sample Wt: <u>.0128</u> g
Test: <u>7</u>	Run: <u>2</u>	Dish No: <u>859</u>
Vol. of Solvent: <u>-</u>	<u>90</u> ml	Dish + Sample Wt: <u>45.0631</u> g
Log Number: <u>-194</u>		Dish Tare Wt: <u>45.0590</u> g
Comments: _____		Sample Wt: <u>.0041</u> g
Test: <u>7</u>	Run: <u>3</u>	Dish No: <u>792</u>
Vol. of Solvent: _____	<u>90</u> ml	Dish + Sample Wt: <u>47.2637</u> g
Log Number: <u>-135</u>		Dish Tare Wt: <u>47.2585</u> g
Comments: _____		Sample Wt: <u>.0052</u> g
Test: _____	Run: _____	Dish No: _____
Vol. of Solvent: _____		Dish + Sample Wt: _____ g
Log Number: _____		Dish Tare Wt: _____ g
Comments: _____		Sample Wt: _____ g

*Solvent Residue _____ ug/ml = [(Sample Wt. _____ g) (10⁶)] / Vol. of Sol. _____ ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

	RUN 0	RUN 1	RUN 2	RUN 3
Results of Solvent Rinse g		0.0122	0.0037	0.0048

D-37



INTERPOLL LABORATORIES, INC.
 (612) 786-6020
Filter Gravimetrics Reporting Sheet

Filter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: LP-SAGOLA
 Date Submitted: 7-26-94
 Date of Analysis: 8-9-94

Source/Site: PROCESS RTO STACK
 Test No.: 7
 Technician: SUP

Test: 7	Run: 1	Filter No: 8452	
Field Blank:		Filter Type: 4" G.F.	
Log No: 9024-133		Filter + Sample Wt: .9506	mg
Color: White		Filter Tare Wt: .9505	mg
		Sample Wt: .0001	mg
Test: 7	Run: 2	Filter No: 8597	
Log No: -04		Filter Type: 4" G.F.	
Color: White		Filter + Sample Wt: .9918	mg
		Filter Tare Wt: .9915	mg
		Sample Wt: .0003	mg
Test: 7	Run: 3	Filter No: 8598	
Log No: -135		Filter Type: 4" G.F.	
Color: White		Filter + Sample Wt: .9938	mg
		Filter Tare Wt: .9935	mg
		Sample Wt: .0003	mg
Test:	Run:	Filter No:	
Log No:		Filter Type:	
Color:		Filter + Sample Wt:	mg
		Filter Tare Wt:	mg
		Sample Wt:	mg

VSL

	RUN 1	RUN 2	RUN 3	RUN
Results of Filter Analysis	g 0.0001	0.0003	0.0003	

	RUN	RUN	RUN	RUN
Total Mass	g			



REVIEWED

Ion Chromatography Laboratory

AUG 15 1996

DIONEX MODEL 4000i WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: mot

Date of Analysis: 8/13/96

Job: 1D030 / LP Sagola Source: Press RTO Site: Stack

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient (List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
* A										
* B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch	8024-133	240	1.0	3.58	859	0.018
	-134	230	1.0	0.0657	15.1	0.00031
	-135	245	1.0	0.210	51.4	0.0011
	X					
METHOD 8/14/96 BLANK 7:08pm	BLANK	400	1.0	0.025	10	0.00021

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

	A	B	C	D	E	F	G	H	I	J
100										
101										
102		EPA Method 202 Calculations								
103		Job: LP/Sagola								
104		Date: 23-Jul-96								
105		<i>Press RTO Stack</i>								
106		Vic	Sulfate	Mc	Mr	Mi	MO	Mb	CPM	ENTER IN
107		(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER
108		1	3.58E-03	0.16	2.7	2.54	25.5	0.5	27.54	(g)
109		2	6.57E-05	0.00	78.2	78.20	3.5	0.5	81.20	
110		3	2.10E-04	0.01	2.6	2.59	4.9	0.5	6.99	
111										
112										
113		EPA Method 201A/202 Totals								
114										
115		Probe	Filter	CPM	Total					
116		(mg)	(mg)	(mg)	(mg)					
117		1	12.2	0.1	27.54	39.84191				
118		2	3.7	0.3	81.20	85.19722				
119		3	4.8	0.3	6.99	12.09053				

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (1)

*****SOURCE*****
Job LP / SAGOLA
*****RECOVERY*****
Date of Recovery 7-31-96
*****ANALYTICAL*****
Date of Analysis 8/14/96
Source No. 1 Cyclone Outlet
Recovered by SLB Analyst MOG
Recovery volume 500 ml Eluent AS/A
Date of Sampling 7-23-96
Barometric at time 29.0 IN.HG. Chromatograph: Dionex System 4000i
Test No(s) 2

Samples collected in accordance with EPA Method 7, CFR Title 40, Part 60, Appendix A. Samples analyzed in accordance with EPA Method 7A by ion chromatography. Mercury manometers used to measure flask pressures/vacuums in sampling and in recovery. Thommen Model TX 19 jewel barometer calibrated against laboratory mercury in glass barometer used to measure field barometric pressure. Three field blanks are prepared and the average used to correct measured nitrate concentrations. All samples are analyzed as a batch using a Dionex Model 4270 Chromatograph Data Integrator. The integrator is programmed to give the actual concentration of the 500 ml recovered sample even if a subsequent dilution was made. The dilution is indicated here as well as on the chromatogram.

$$C_{RS} = DF(C_{DS}) \quad M_{NO_3} = (C_{RS} - \bar{C}_B)V_R \quad \bar{C}_B = (C_{B1} + C_{B2} + C_{B3})/3$$

where: C_{RS} = concentration of nitrate in 500 ml recovered sample in ug/ml

DF = dilution factor

C_{DS} = concentration of nitrate of a 500 ml recovered sample which has been diluted by a factor of DF to bring it into the proper range for the ion chromatograph. This value is an intermediate number and is not outputted by the electronic integrator which is programmed to output the concentration of the original undiluted 500 ml recovered sample.

M_{NO_3} = total mass of nitrate in micrograms in the 500 ml recovered sample and/or in the 2L flask.

C_B = average conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

C_{B1}, C_{B2}, C_{B3} = conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

V_R = recovery volume for samples and field blanks in ml

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (2)

Sample Log ID No.	Flask No.	Test/Run	Final Flask Conditions			Chrom Run No.	DF	Nitrate Concentration (ug/ml)		Total nitrate in Sample (ug) (MNO ₃)
			t _f (°F)	+	-			Δ Pg (IN.HG.)	Uncorr. for blank CRS	
8	1	2-1	72		.7	26	1	0.307	0.377	190
9	2	2-1	72		.5	27	1	0.376	0.376	190
10	3	2-1	72		.5	30	1	0.385	0.385	190
11	4	2-1	72		.9	31	1	0.370	0.370	180
12	5	2-2	72		.6	32	1	0.381	0.381	190
13	6	2-2	72		.6	33	1	0.353	0.353	180
14	19	2-2	72		.9	36	1	0.300	0.300	150
15	20	2-2	72		.4	37	1	0.292	0.292	150
16	21	2-3	72		.6	38	1	0.324	0.324	160
17	22	2-3	72		.1	39	1	0.298	0.298	150
18	23	2-3	72		.85	40	1	0.321	0.321	160
19	24	2-3	72		.05	43	1	0.319	0.317	160
Blank 1							1	CB1		
Blank 2							1	CB2		
Blank 3							1	CB3		

C_B = 0.020

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (1)

*****SOURCE*****
Job LP/SAGTOLA
Source No. 2 CYCLONE OUTLET
Date of Sampling 7-23-76
Test No(s) Z
*****RECOVERY*****
Date of Recovery 7-31-76
Recovered by SLB
Recovery volume 500 ml
Barometric at time 29.10 IN.HG.
*****ANALYTICAL*****
Date of Analysis 8/14/76
Analyst MJK
Eluent ASHA
Chromatograph: Dionex System 4000i

Samples collected in accordance with EPA Method 7, CFR Title 40, Part 60, Appendix A. Samples analyzed in accordance with EPA Method 7A by ion chromatography. Mercury manometers used to measure flask pressures/vacuums in sampling and in recovery. Thommen Model TX 19 jewel barometer calibrated against laboratory mercury in glass barometer used to measure field barometric pressure. Three field blanks are prepared and the average used to correct measured nitrate concentrations. All samples are analyzed as a batch using a Dionex Model 4270 Chromatograph Data Integrator. The integrator is programmed to give the actual concentration of the 500 ml recovered sample even if a subsequent dilution was made. The dilution is indicated here as well as on the chromatogram.

$$C_{RS} = DF(C_{DS}) \quad M_{NO_3} = (C_{RS} - \bar{C}_B)V_R \quad \bar{C}_B = (C_{B1} + C_{B2} + C_{B3})/3$$

where: C_{RS} = concentration of nitrate in 500 ml recovered sample in ug/ml

DF = dilution factor

C_{DS} = concentration of nitrate of a 500 ml recovered sample which has been diluted by a factor of DF to bring it into the proper range for the ion chromatograph. This value is an intermediate number and is not outputted by the electronic integrator which is programmed to output the concentration of the original undiluted 500 ml recovered sample.

M_{NO_3} = total mass of nitrate in micrograms in the 500 ml recovered sample and/or in the 2L flask.

C_B = average conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

C_{B1}, C_{B2}, C_{B3} = conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

V_R = recovery volume for samples and field blanks in ml

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (2)

Sample Log ID No.	Flask No.	Test/Run	Final Flask Conditions			Chrom Run No.	DF	Nitrate Concentration (ug/ml) Uncorr. for blank CRS	Nitrate Concentration (ug/ml) Corr. for blank (CRS - CB)	Total nitrate in Sample (ug) (MNO ₃)
			bf (bf)	+	-					
1										
2	55	2-1	72		42	46	0.337	0.339	170	
3	56	2-1	72		72	47	0.356	0.356	180	
4	57	2-1	72	1	72	48	0.321	0.321	160	
5	58	2-1	72	1	72	49	0.242	0.242	120	
6	59	2-2	72	05	72	50	0.243	0.243	120	
7	60	2-2	72	10	72	51	0.290	0.290	140	
8	43	2-2	72	42	72	52	0.299	0.299	140	
9	44	2-2	72	41	72	53	0.320	0.320	180	
10	45	2-3	72	43	72	56	0.262	0.262	130	
11	46	2-3	72	40	72	59	0.288	0.288	140	
12	47	2-3	72	15	72	60	0.312	0.312	160	
13	48	2-3	72	32	72	61	0.306	0.306	150	
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
Blank 1										
Blank 2										
Blank 3										

$\bar{C}_B = 0.020$

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (1)

*****SOURCE*****
 Job LP / SAGOLA
 Source No. 3 Cycles Outlet
 Date of Sampling 7-23-96
 Test No(s) Z
 *****RECOVERY*****
 Date of Recovery 7-31-96
 Recovered by SLB
 Recovery volume 500 ml
 Barometric at time 22.10 IN.HG.
 *****ANALYTICAL*****
 Date of Analysis 8/14/96
 Analyst MSJ
 Eluent AS4A
 Chromatograph: Dionex System 4000i

Samples collected in accordance with EPA Method 7, CFR Title 40, Part 60, Appendix A. Samples analyzed in accordance with EPA Method 7A by ion chromatography. Mercury manometers used to measure flask pressures/vacuums in sampling and in recovery. Thommen Model TX 19 jewel barometer calibrated against laboratory mercury in glass barometer used to measure field barometric pressure. Three field blanks are prepared and the average used to correct measured nitrate concentrations. All samples are analyzed as a batch using a Dionex Model 4270 Chromatograph Data Integrator. The integrator is programmed to give the actual concentration of the 500 ml recovered sample even if a subsequent dilution was made. The dilution is indicated here as well as on the chromatogram.

$$C_{RS} = DF(C_{DS}) \quad M_{NO_3} = (C_{RS} - \bar{C}_B)V_R \quad \bar{C}_B = (C_{B1} + C_{B2} + C_{B3})/3$$

where:

C_{RS} = concentration of nitrate in 500 ml recovered sample in ug/ml

DF = dilution factor

C_{DS} = concentration of nitrate of a 500 ml recovered sample which has been diluted by a factor of DF to bring it into the proper range for the ion chromatograph. This value is an intermediate number and is not outputted by the electronic integrator which is programmed to output the concentration of the original undiluted 500 ml recovered sample.

M_{NO_3} = total mass of nitrate in micrograms in the 500 ml recovered sample and/or in the 2L flask.

C_B = average conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

C_{B1}, C_{B2}, C_{B3} = conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

V_R = recovery volume for samples and field blanks in ml

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (2)

Sample Log ID No.	Flask No.	Test/Run	Final Flask Conditions		Chrom Run No.	DF	Nitrate Concentration (ug/ml)		Total nitrate in Sample (ug) (MNO ₃)
			t _f (DF)	Δ Pg (IN.HG.)			Uncorr. for blank CRS	Corr. for blank (CRS - C _B)	
75	25	2-1	72	2.4	62	1	0.578	0.578	200
76	26	2-1	72	2.0	63	1	0.549	0.549	270
77	27	2-1	72	2.5	66	1	0.578 0.576	0.576	260
78	28	2-1	72	2.1	67	1	0.548	0.548	270
79	29	2-2	72	2.0	68	1	0.589	0.589	250
80	30	2-2	72	2.4	69	1	0.460	0.460	270
81	31	2-2	72	1.2	70	1	0.300	0.300	170
82	38	2-2	72	2.8	71	1	0.287	0.287	190
83	39	2-3	72	2.7	74	1	0.268	0.268	170
84	40	2-3	72	2.6	77	1	0.210	0.210	160
85	41	2-3	72	2.5	78	1	0.281	0.281	140
86	42	2-3	72	2.3	79	1	0.326	0.326	160
175		BLANK			80	1	<0.020	<0.020	<10
Blank 1						1	CB1		
Blank 2						1	CB2		
Blank 3						1	CB3		

C_B = <0.020

S-340(2) R-9/85

EPA Method 10 NDIR Analysis

Job Name L.P. / Sagala, MI
 Source No. 1 Primary Cycles / Exhaust
 Date of Analysis 7-24-96
 Technician Mark Gachler

NDIR Analyzer: Fugi ACS Model 3300
 Mon. Lab Model 8310
 Dasibi Model 3003
 Range: 0 - 1000 PPM
 Flow rate: 1000 cc/min

Pretest Calibration				
	Concentration		Reading	
Zero Gas	0.0 PPM		0.0 PPM	
Upscale Gas	299 PPM		299 PPM	
Upscale Gas	620 PPM		620 PPM	
Upscale Gas	PPM		PPM	

Sample Description Test/Run	Sample Log No.	CO Conc. (PPM, Dry)		
		Dilution Factor	Reading	Actual PPM
1/1		2	911	1822
1/2		2	897	1794
1/3		2	889	1778

Post-Test Calibration				
	Conc.		Reading	
Zero Gas	0.0 PPM		0.0	PPM
Upscale Gas	620 PPM		620	PPM
Upscale Gas	PPM			PPM
Upscale Gas	PPM			PPM

Note 1: If sample dilution is required, the sample is diluted with CO-free gas prior to analysis.
 Note 2: The Fugi ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000: 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000: 1 and thus CO₂ removal prior to analysis is not required.
 Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

EPA Method 10 NDIR Analysis

Job Name LP-SAGOLA
 Source No. 2 CYCLONE DUCT
 Date of Analysis 7-31-96
 Technician S-B

NDIR Analyzer:

 Range: 0 - 1000 PPM
 Flow rate: 1000 cc/min

Fuji ACS Model 3300
 Mon. Lab Model 8310
 Dasibi Model 3003

Pretest Calibration					
	Concentration		Reading	Vendor	Cyl. No.
Zero Gas	0 PPM		0 PPM	TCO	mm 7135
Upscale Gas	609 PPM		610 PPM	TCO	SL9164993
Upscale Gas	301 PPM		300 PPM	TCO	ALM014233
Upscale Gas					

Sample Description Test/Run	Sample Log No.	CO Conc. (PPM, Dry)		
		Dilution Factor	Reading	Actual PPM
1/1	8024 -	6	265	1590
1/2	-	6	317	1902
1/3	-	6	369	2214

Post-Test Calibration			
	Conc.		Reading
Zero Gas	0 PPM		0 PPM
Upscale Gas	609 PPM		602 PPM
Upscale Gas	301 PPM		300 PPM
Upscale Gas			

Note 1: If sample dilution is required, the sample is diluted with CO-free gas prior to analysis.
 Note 2: The Fuji ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000: 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000: 1 and thus CO₂ removal prior to analysis is not required.
 Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

EPA Method 10 NDIR Analysis

Job Name: L.P. / Sagala, MI NDIR Analyzer: Fugl ACS Model 3300
 Source: Dyer Prima Cyclone / No. 3 Exhaust Mon. Lab Model 8310
 Date of Analysis: 7-24-96 Dasibi Model 3003
 Technician: Mark Gachala Range: 0 - 1000 PPM
 Flow rate: 1000 cc/min

Pretest Calibration				
	Concentration		Reading	
Zero Gas	0.0 PPM		0.0 PPM	
Upscale Gas	299 PPM		299 PPM	
Upscale Gas	620 PPM		620 PPM	
Upscale Gas	PPM		PPM	

Sample Description Test/Run	Sample Log No.	CO Conc. (PPM, Dry)		
		Dilution Factor	Reading	Actual PPM
1/2 (1)		2	878	1756
1/3 (2)		2	885	1770
1/4 (3)		2	853	1706

Post-Test Calibration				
	Conc.		Reading	
Zero Gas	0.0 PPM		0.0 PPM	
Upscale Gas	620 PPM		620 PPM	
Upscale Gas	PPM		PPM	
Upscale Gas	PPM		PPM	

Note 1: If sample dilution is required, the sample is diluted with CO-free gas prior to analysis.
 Note 2: The Fugl ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000: 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000: 1 and thus CO₂ removal prior to analysis is not required.
 Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

Data Reporting Sheet
(With Regulatory Limits)

CLIENT: 10070 / LP Saspla

 PHONE: _____
 CONTACT: _____

JOB: _____
 CLIENT NO: _____
 P.O. NO: _____
 PROJECT MGR: _____
 DATE: _____

LABORATORY REPORT #: _____
 SAMPLES COLLECTED: _____
 SAMPLES RECEIVED: _____

Prison Stock

SAMPLE I.D:

8/2	8/4		
1.6.5.	1.6.5.		
8024-127	-128		

Report
Invoicing Signature Routing

PL
 Lab Mgr
 InO Mgr
 Org Mgr

SAMPLE TYPE:

LOG NO:

PARAMETER	UNITS	DET. LIMIT	REG. LIMIT	ANALYSIS DATE & INITIALS	METHOD				
<i>Methane</i>	<i>ppmV</i>	<i>1</i>		<i>8/5/96</i> <i>JMM/ST</i>	<i>MZS</i>	<i>BDL</i>	<i>14</i>		

Footnotes:

In-House Comments:

Data Reporting Sheet
(With Regulatory Limits)

CLIENT: 10020 LP Sagola

JOB: _____
CLIENT NO: _____
P.O. NO: _____
PROJECT MGR: _____

PHONE: _____

DATE: _____

CONTACT: _____

Dryer RTO Stack

LABORATORY REPORT #: _____
SAMPLES COLLECTED: _____
SAMPLES RECEIVED: _____

SAMPLE I.D:

1/2	1/4	1/5	
165.	→		
8024-147	-148	-149	

Invoicing Signature Report Routing

PL
Lab Mgr
InO Mgr
Org Mgr

SAMPLE TYPE:

LOG NO:

PARAMETER	UNITS	DET. LIMIT	REG. LIMIT	ANALYSIS DATE & INITIALS	METHOD				
Methane	ppmV	1		8/5/96 ^{Max}	M25	39	4.8	4.2	

Footnotes:

In-House Comments:

INTERPOLL LABORATORIES INC.

Formaldehyde Results Using EPA Method 0011
For Dept. 20/LP Sagola
Collected 7/24 and 25/96

	Field Spike			Test: 4 Source: Dryer Primary Cyclone Exhaust #1			
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3
Log #		(8024-28)		(8024-27)	(8024-29)	(8024-30)	(8024-31)
Mass (ug)*	750	560	74.7	54	16000	18000	19000

	Field Spike			Test: 4 Source: Dryer Primary Cyclone Exhaust #2			
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3
Log #		(8024-62)		(8024-61)	(8024-63)	(8024-64)	(8024-65)
Mass (ug)*	750	610	81.3	25	13000	16000	15000

	Field Spike			Test: 4 Source: Dryer Primary Cyclone Exhaust #3			
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3
Log #		(8024-98)		(8024-97)	(8024-99)	(8024-100)	(8024-101)
Mass (ug)*	750	510	68.0	120	18000	18000	10000

	Field Spike			Test: 4 Source: Dryer RTO Stack			
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3
Log #		(8024-158)		(8024-157)	(8024-159)	(8024-160)	(8024-161)
Mass (ug)*	750	510	68.0	40	3300	5000	5100

* = Total Mass of formaldehyde in the sample in ug.

Reviewed by:



David J. Schneider, Manager
Chemistry Department

INTERPOLL LABORATORIES INC.

Formaldehyde Results Using EPA Method 0011
 For Dept. 20/LP Sagola
 Collected 7/24 and 25/96

	Field Spike			Test: 9						Source: Press RTO Stack
	Actual	Found	% Recovery	Run 0	Run 00	Run 1	Run 2	Run 3	Run 4	
Log #		(8024-137)		(8024-136)	(8024-138)	(8024-139)	(8024-140)	(8024-141)	(8024-142)	
Mass (ug)*	750	440	58.7	13	13	350	280	270	270	

	Field Spike			Test: 9					Source: Press RTO Inlet
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3	Run 4	
Log #		(8024-167)		(8024-166)	(8024-168)	(8024-169)	(8024-170)	(8024-171)	
Mass (ug)*	750	470	62.7	13	9800	9500	11000	7300	

* = Total Mass of formaldehyde in the sample in ug.

Reviewed by:



David J. Schneider, Manager
 Chemistry Department

INTERPOLL LABORATORIES INC.

Phenol Result By EPA Method 8270
 For Dept. 20/ LP Sagola
 Collected 7/24 and 25/96

	Test: 6				Source: Press RTO Stack
	Run 0	Run 1	Run 2	Run 3	
Log #	8024-129	8024-130	8024-131	8024-132	
Phenol*	< 840	< 840	< 840	< 840	
2-Fluorophenol**	79.1	60.0	65.3	55.7	
D6-Phenol**	55.9	47.9	59.9	60.2	
2,4,6-Tribromophenol***	90.7	96.1	103	92.8	

	Test: 6				Source: Press RTO Inlet
	Run 0	Run 1	Run 2	Run 3	
Log #	8024-162	8024-163	8024-164	8024-165	
Phenol*	< 840	< 840	< 840	< 840	
2-Fluorophenol**	99.4	66.4	69.7	54.2	
D6-Phenol**	65.5	55.0	70.7	44.5	
2,4,6-Tribromophenol***	49.5	39.0	63.7	89.8	

* = Total mass of the specified compound in the sample in ug.

** = Percent recovery of the field surrogate. (60120 ug 2-Fluorophenol and 5006 ug Phenol-D6 was added to the impinger solution before sampling.)

*** = Percent recovery of the lab surrogates.

Reviewed by:



David J. Schneider, Manager
 Chemistry Department

INTERPOLL LABORATORIES INC.

4,4-Methylenebis(phenyl isocyanate) Results
 For Dept. 20/LP Sagola
 Collected 7/25/96

Item	Field Spike			Test: 5		Source: Press RTO Stack		
	Actual	Found	% Rec.	Run 0	Run 00	Run 1	Run 2	Run 3
EPA Draft Method 1,2-PP								
Log #		8024-122		8024-121	8024-123	8024-124	8024-124	8024-125
MDI (ug)*	297	260	87.5	< 6.2	< 6.2	< 6.2	< 6.2	< 6.2

* = Total mass of MDI in the sample in ug.

Reviewed by:



David J. Schneider, Manager
 Chemistry Department

Interpoll Laboratories
(612) 786-6020

IMPINGER CATCHES

Project Name: LP / Sagola Order Date: 7-17-96
Date Required: 7-19-96 Delivery Date: 7-18-96

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
MDI 95204-83-A in Dry Toluene	297 µg/mL	1.0 mL	297 µg

SPECIAL REQUIREMENTS

Spiked 7-18-96 B.D.
Verified 7-18-96 YW

**Please return this form with the samples.

Interpoll Laboratories
(612) 786-6020

IMPINGER CATCHES

Project Name: LPI Sagola Order Date: 7-17-96
Date Required: 7-19-96 Delivery Date: 7-18-96

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
* Formaldehyde in ACIV #95082-59-A	3.75 mg/mL	200 μ l	750 μ g

SPECIAL REQUIREMENTS

* Prepared six (6) Field Spikes B.D. 7-18-96
Verified by [Signature] 7/18/96

**Please return this form with the samples.

Interpoll Laboratories
(612) 786-6020

IMPINGER CATCHES

Project Name: LPI Saqola Order Date: 7-17-96
Date Required: 7-19-96 Delivery Date: 7-19-96

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
<u>#95078-26-A</u> D-6 Phenol	<u>5.006 mg/mL</u>	<u>1.0 mL</u>	<u>5.006 mg</u>
<u>#95078-26-B</u> 2-fluorophenol	<u>50.10 mg/mL</u>	<u>1.2 mL</u>	<u>60.120 mg</u>

SPECIAL REQUIREMENTS

Spiked 7-19-96 B.D.
Verified 7-19-96 [Signature]

**Please return this form with the samples.

INTERPOIL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job SP/Seydel Source Primary Cyclone Sweater Site Log No. 2027
 Field Engineer S. Finkel Date of Test 7-24-96 Test No. 1 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
4	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____		
5	Filter: <input checked="" type="checkbox"/> 4" Glass <input checked="" type="checkbox"/> SS Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass		
4	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____		
3	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag	<input type="checkbox"/> _____		
12	Oxides of Nitrogen:	<input type="checkbox"/> _____		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Aggregate		
-	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
3	Miscellaneous: <input checked="" type="checkbox"/> Imp Rise (Mech)	<input checked="" type="checkbox"/> M-202		<u>Run 3's Imp rise included in Imp catch</u>

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation <u>Seth Finkel Interpoll Labs</u>	Accepted by/Affiliation <u>Chris Finkel</u>	Date <u>7-26-96</u>
--	--	------------------------

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sagole Source No 2 Cyclone Date of Test 7/23/96 Site Outlet Log No. 8024
Pen Test No. 1 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____		
3	Filters: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17		
3	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WJ Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> _____		
3	Integrated Gas: <input checked="" type="checkbox"/> Medlar Bag <input type="checkbox"/> _____ Oxides of Nitrogen:	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per S-0163		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate			
	Particle Sizing: <input type="checkbox"/> _____	<input type="checkbox"/> X-Ray Scgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp		
	Miscellaneous: <input type="checkbox"/> _____			

Fuel Type: Coal: Bituminous Wood: Wood Waste Waste Oil Natural Gas
 Anthracite Dust No. 2 RDF
 Lignite Bark No. 6 No. 6

Relinquished by/Affiliation <u>Duane Van Hoven</u>	Accepted by/Affiliation <u>Carl ICI</u>	Date <u>7/28/96</u>

INTERPOIL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Snyder Source Byrd Primary Cyclone Exhaust Site Over Log No. 8024
EJ Date of Test 7-23-96 Test No. 1 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
4	Probe Wash: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
4	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> 5S Thimble	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
4	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases		
7	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10		<u>Analyzed by MK</u>
	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A		
	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Per S-0163		
	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
4	Miscellaneous: <input type="checkbox"/> Bituminous <input type="checkbox"/> Anthracite <input type="checkbox"/> Lignite	<input checked="" type="checkbox"/> M-202		<u>check for heavy particulates may have had breakthrough</u>

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF

Requisitioned by/Affiliation <u>[Signature]</u>	Accepted by/Affiliation <u>Carl F. L. I.</u>	Date <u>7/26/96</u>
--	---	------------------------

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sagalayan Source Outlet Site Outlet Log No. 8024
Mikaela Date of Test 7-23-96 Test No. 1 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3+1	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
3+1	Filter: <input checked="" type="checkbox"/> 2.5" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
3+1	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> MeCl ₂	<input type="checkbox"/> IMN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26		
3	Integrated Gas: <input checked="" type="checkbox"/> Pedlar Bag <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per 5-0163		
-	Oxides of Nitrogen: <input type="checkbox"/> _____			
-	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate			
-	Particle Sizing: <input type="checkbox"/> _____	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
-	Miscellaneous: <input type="checkbox"/> _____			

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood Waste Wood Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation <u>Mikaela Sagalayan / Interpoll Labs</u>	Accepted by/Affiliation <u>ASG / ILL</u>	Date <u>7/26/96 1500</u>
--	---	-----------------------------

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer J.P. Sagola Source Dryer KTO Site Stack Log No. 8024

Date of Test 7/23/96 Test No. 1 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
4	Pyrolytic Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____	(143-116)P	
4	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17	(143-116)F	
4	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 12.4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____	(143-116)J	
3	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____ Oxides of Nitrogen: <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input checked="" type="checkbox"/> Methness <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per S-0163 Run 2, 4, 5	(143-118, 141)	AG Mess. on Run # 2, 4, 5
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate			
	Particle Sizing: <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp			
4	Miscellaneous: <input checked="" type="checkbox"/> Methness	<input checked="" type="checkbox"/> MC-202	(143-116)P	

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<i>[Signature]</i> / ELS	7/29/96

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody
No. 2 Cyclone Site Outlet

Job Field Engineer L.P. Sagola Source Diff Date of Test _____ Log No. 8024
Diff Test No. 2 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____		
	Integrated Gas: <input type="checkbox"/> Textlar Bag <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input checked="" type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
<u>12</u>	Oxides of Nitrogen: <input type="checkbox"/> _____	<input type="checkbox"/> Per S-0163		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp		
	Particle Sizing: <input type="checkbox"/> _____			
	Miscellaneous: <input type="checkbox"/> _____			

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Retrieved by/Affiliation: James Van Hoven Accepted by/Affiliation: Clay / J.L.I.
 Date: 7/26/96

INTERPOL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sagola

Source No. 3 Dryer Exhaust

Date of Test 7-23-96



Test No. 2

Log No. 8024

No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-17 <input type="checkbox"/> _____		
	Filters: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17 <input type="checkbox"/> _____		
	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IIA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____		
	Integrated Gas: <input type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-10		
<u>12</u>	Oxides of Nitrogen: <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per 5-0163		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp		
	Particle Sizing: <input type="checkbox"/> _____			
	Miscellaneous: <input type="checkbox"/> _____			

Fuel Type: Coal: Bituminous Wood Waste Natural Gas
 Anthracite Dust RDF
 Ignite Bark Misc: No. 2 No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
		7-26-96
	1500	

INTERPOIL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer SP/Sayola Source Primary Cyclone Exhaust #1 Log No. 8027
SF Date of Test 7-24-96 Test No. 4 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
2	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₄ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____		
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IIA Protocol <input checked="" type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____		1 BLANK 1 SPIKE 6 Pumps Imp. Col.
3	Integrated Gas: <input checked="" type="checkbox"/> Fedlar Bag <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____		
	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
	Particle Sizing:	<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp		
	Miscellaneous:	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation <u>Andrew FCI</u>	Accepted by/Affiliation <u>Carl FCI</u>	Date <u>7/26/96</u>
		<u>1500</u>

INTERPOIL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Saylor Source Port Date of Test 7/24/96 Test No. 4 Log No. 8024 No. of Runs 3

Site Outlet

No. Items	Sample Type	Analysis	Sequence No.	Comments	
3	Probe Wash: <input type="checkbox"/> Acetone <input checked="" type="checkbox"/> MeCl ₂ Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input checked="" type="checkbox"/> DI Water <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17	<input type="checkbox"/> EPA M-201A <input checked="" type="checkbox"/> <u>well</u>	
5	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 12,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> MeCl ₂	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-7A <input type="checkbox"/> Per S-0163	<input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> <u>well</u>	<u>1 Blank</u> <u>6 Spikes</u> <u>3 Runs</u>
3	Integrated Gas: <input checked="" type="checkbox"/> Cellar Bag Oxides of Nitrogen:				
2	Fuel Lab: <input checked="" type="checkbox"/> Fuel Sample Particle Sizing: Miscellaneous:	<input type="checkbox"/> Aggregate			<u>Aspen & Line</u> <u>Ultimate 2-See</u> <u>Kathy E.</u>

Fuel Type: Coal: Bituminous Wood: Wood Waste Natural Gas
 Anthracite Dust No. 2 RDF
 Lignite Bark No. 6 No. 6

Retrieved by/Affiliation <u>James VanHorn</u>	Accepted by/Affiliation <u>CRD / ILLI</u>	Date <u>7/26/96</u>
--	--	------------------------

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sogeler Source No. 3 cyclone Site OUTLET Log No. 8027
ES Date of Test 7-24-96 Test No. 4 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
9	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____		
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> IWI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6, B <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input checked="" type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____		1 blank 1 spike 3 runs
3	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____ Oxides of Nitrogen: <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per S-0163		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp <input type="checkbox"/> _____		
	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> Wood Waste <input type="checkbox"/> Wood <input type="checkbox"/> Dust <input type="checkbox"/> Bark <input type="checkbox"/> Oil: <input type="checkbox"/> Waste Oil <input type="checkbox"/> No. 2 <input type="checkbox"/> No. 6 <input type="checkbox"/> Natural Gas <input type="checkbox"/> RDF <input type="checkbox"/> _____		

Relinquished by/Affiliation: [Signature]

Accepted by/Affiliation: Carl / ILL

Date: 1508 7-26-96

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer A.P. / Sagala, Al Source Press RTO Site Stack LOG No. 6024
Mukachira Date of Test 7-25-96 Test No. 5 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
1	Probe Wash: <input type="checkbox"/> DI Water <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
1	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
6 + 4	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> 1-2 pp	<input type="checkbox"/> IMN Protocol <input type="checkbox"/> TWI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> I/A Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> ADI		
2	Integrated Gas: <input checked="" type="checkbox"/> Medlar Bag	<input type="checkbox"/> EPA M-3 <input checked="" type="checkbox"/> AS-Heave		Ambient Air
1	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/>		
1	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
1	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/>		
1	Miscellaneous: <input type="checkbox"/>	<input type="checkbox"/>		

Fuel Type: Coal Bituminous Wood Waste Natural Gas
 NA Anthracite IDust IRDF
 Lignite Bark No. 2 No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Manabu Sakabe / Interpoll Lab</u>	<u>AS / ICI</u>	<u>7/26/96 1500</u>

INTERPOIL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sagala Source Dyer RTO Site Stack Log No. 8024
 Date of Test 7/24/96 Test No. 27 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: <input type="checkbox"/> Acetone <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input checked="" type="checkbox"/> EPA M-201A	(159-161)	
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17		
5	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄	(157-161)	Blank 3 Runs
3	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10	(172,173,174)	
	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A		
	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Per S-0163		
	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
	Miscellaneous:	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<i>[Signature]</i>	1200 7/27/96

INTERPOIL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sagola Source Press RTD Date of Test 7/25/96 Site INLET Test No. 6 Log No. 8024 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
<u>Y</u> <u>Pris</u>	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input checked="" type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> Neutral Buffer	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> Phos / 8270 <input type="checkbox"/> EPA M-10	<u>(162-165)</u> <u>46</u>	
	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> EPA M-3		
	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Wood: Wood Waste Natural Gas
 Anthracite Dust RDF
 Lignite Bark Misc: IRDF _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>OS / FLI</u>	<u>7/29/96</u>

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. / Saypol, et al Source Stack Site Stack Log No. 502Y
W. Kaehler Date of Test 2-27-86 Test No. 6 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
1	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____		
1	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass		
3 A	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____		
1	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> _____		<u>Archer Ave</u>
1	Oxides of Nitrogen:			
1	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
1	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp		
1	Miscellaneous: <input type="checkbox"/> _____			

Fuel Type: Coal: NA Bituminous Wood Waste Waste Oil Natural Gas
 Anthracite No. 2 IRDF
 Lignite Bark No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Kaehler / Interpoll Labs</u>	<u>AKL / ILL</u>	<u>7/26/86 1500</u>

INTERPOIL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P./Snyder, M.I. Muehler Source Press RTD Site Stack Log No. 6024
 Date of Test 2-24-96 Test No. 7 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
3	Filter: <input checked="" type="checkbox"/> 1" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
3	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> <u>MeCl₂</u>	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26		
1	Integrated Gas: <input type="checkbox"/> Textlar Bag	<input checked="" type="checkbox"/> EPA M-3		<u>Ambient Air</u>
1	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A		
1	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Per S-0163		
1	Particle Sizing:	<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> Cascade Imp		
1	Miscellaneous:			

Fuel Types: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas IRDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Scoblen / Interpoll Labs</u>	<u>Paul / IUI</u>	<u>7/26/96 1500</u>

INTERPOL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Sogola Source Press #10 Site Inlet Log No. 802-1
J.B. Date of Test 7/25/96 Test No. 9 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
<u>3</u>	Probe Wash: <input type="checkbox"/> Acetone <input checked="" type="checkbox"/> MeCl,	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input checked="" type="checkbox"/> EPA M-201A		<u>Added to 1. Catch</u>
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
<u>7</u>	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH + H ₂ O ₂	<input type="checkbox"/> IMN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases	<u>(166-171)</u>	<u>Blank</u> <u>1 Spike</u> <u>3 Runs</u>
	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10		
	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> Per S-0163		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
	Particle Sizing: Miscellaneous: <input type="checkbox"/>			

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Chad / E-L-I</u>	<u>7/29/96</u>

INTERPOIL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.R. / Sapota, M.L. Source Cross MFO Site Stack Log No. 9004
M. Suetler Date of Test 7-29-96 Test No. 9 No. of Runs 4

No. Items	Sample Type	Analysis	Sequence No.	Comments
—	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		<u>Added to Insp</u>
—	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> 5S Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
4 + 7	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> Acid Gases <input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10 <input type="checkbox"/> EPA M-7A		
—	Integrated Gas: <input type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10		<u>Amb. next A.v.</u>
—	Oxides of Nitrogen: <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
—	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
—	Particle Sizing: <input type="checkbox"/> _____	<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> Cascade Imp <input type="checkbox"/> _____		
—	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		


Fuel Type: Coal: NA Bituminous Anthracite Lignite
 Wood: Wood Waste MC Dust Bark MC
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas IRDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mash Goodwin / Inspectors Lab</u>	<u>Paul / ICI</u>	<u>7/20/96 1500</u>



APPENDIX E

COMPUTER DATALOGGER PRINTOUTS



WHEELABRATOR
 SAGOLA MI
 7/23/96
 TEST 2 / RUN 2 (1)
 14:36:00 - 15:35:00

NO. 3 CYCLONE OUTLET	NO. 2 CYCLONE OUTLET	NO. 1 CYCLONE OUTLET
THC PPM	THC PPM	THC PPM
1046	654	623
1059	673.5	616.5
1065	724	613.9
1044	766.5	621.9
1036	778.5	635.4
1363	783.5	684.1
1391	767.1	687.1
1405	721.4	701.4
1454	677	666.8
1484	633.8	705.9
1473	623.9	709.3
1492	619.9	710.4
1480	639.9	736.3
1447	672.7	701.8
1425	682.3	696.3
1419	724.4	690.5
1396	713.1	685
1374	710.5	681.8
1366	683.6	678.2
1364	663.2	684.9
1351	660.8	678.9
1349	664.5	652
1360	685.8	648.2
1353	686.7	636.2
1356	665.8	639.6
1344	640.6	626.7
1344	639	626.3
1379	652.1	621.9
1385	659.6	615.8
1393	666.2	623.7
959.4	689.2	621
889	685.1	613.6
819	685	630.2
948.7	665.4	636.6
929.8	660.1	640.9
909.2	685.8	667.5
870.5	690.9	665.6
888.1	708.2	659.4
918.4	719.5	643.6
940.8	732.4	628.5
938.6	742	619.6
952.7	722.8	630.6
985.7	716.9	652.1
1021	704.7	650.4
1010	693.6	684.7
1020	694.9	696.5
990.1	746.3	713.6
997.4	778.5	699.5
967.2	828.6	698.4
910.9	835.4	674.5
873.9	827.3	648.9
860	806.7	642.1
860.9	771.4	687.4
848.5	740.7	696.1
828.8	718.8	694.8
806.3	700.7	717.5
797.4	692.5	735.8
810.2	702.2	705.2
818.6	717.2	676.8
824.3	723.8	676.2

AVERAGE	AVERAGE	AVERAGE
<u>1124.87</u>	<u>705.39</u>	<u>665.39</u>

WHEELABRATOR
 SAGOLA, MI
 7/23/86
 TEST 2 / RUN 3 (2)
 16:46:00 - 17:45:00

NO. 3 CYCLONE OUTLET	NO. 2 CYCLONE OUTLET	NO. 1 CYCLONE OUTLET
THC PPM	THC PPM	THC PPM
977.1	700.3	584.2
979.7	694.4	586.3
984.1	715.2	600.3
997.3	767	617.3
991.6	787	621.6
1019	738.9	616.9
990.2	758.3	607.7
990.7	728.8	608.7
982.7	702.9	630.3
971.3	694	630
966	711.3	627.6
949.2	651.9	647.8
927.2	634.6	659.6
900.4	638.5	613.1
909.2	644.3	600.7
903	695.9	582.3
929.5	679.4	577.2
940.9	711.4	565.7
949.3	732.4	580.5
925.1	761.1	582.9
895.6	799.1	578.8
901.3	795.8	571.6
899.6	792.9	561.7
878.4	784.1	554.3
878.9	742.5	529.8
878.2	693.2	537.1
882.8	652.4	554
852.1	645.7	561.2
832.7	637.6	570.4
813.3	678.5	585.8
810.6	716.7	568.5
797.4	736	568.7
755.6	728.9	557.7
706.8	717.3	568.9
671.1	669.4	572.6
658.4	657.8	571.8
666.5	640.8	561.8
651.1	620.7	546.1
661.7	628.1	535.2
669.6	633.1	525.2
733.5	630.8	542.6
713.7	643.8	547.2
685.2	713.7	549.2
668	724.5	543.3
671.1	693.7	543.2
659.6	672.3	554.4
642	646.2	566.8
705.8	850.4	588.7
1050	668.8	577.7
797.9	685.9	585.1
779.8	682.1	585.1
771	685.8	594
767.5	679.2	583.7
778.9	670	589.2
790.4	661.8	587.1
863	669.7	615.2
953.7	681.8	602.3
940.2	714.4	591.9
887.6	721.7	596.7
832.8	732	593.5
<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>
<u>844.41</u>	<u>694.91</u>	<u>580.81</u>

WHEELABRATOR
 SAGOLA, MI
 7/23/96
 TEST 2 / RUN 4 (3)
 19:25:00 - 20:24:00

NO. 3 CYCLONE OUTLET	NO. 2 CYCLONE OUTLET	NO. 1 CYCLONE OUTLET
THC PPM	THC PPM	THC PPM
1326	546.9	699.5
1293	557.8	677
1284	603.9	664.9
1224	629.3	681.7
1205	629.7	666.4
1164	596.3	653.6
1161	573.7	638.6
1126	570.4	644.7
1111	584.8	629.6
1094	587.6	623.6
1111	593.5	614.7
1115	584.4	630.8
1096	611.6	647.7
1065	651.2	677.7
1027	670.5	677.8
958.8	673.8	668.8
928.5	679.4	627.7
928.1	671.7	596.8
938.8	675	555.4
990.5	680.8	532.7
1036	686	500.7
1052	673.9	483.6
1086	643.6	470.8
1089	621.4	459.8
1063	592.3	438.5
1060	593.7	419.8
1109	598.9	411.4
1117	594.4	428.6
1107	582.9	426.6
1108	572.5	424.6
1113	574.1	460
1121	592.6	448.9
1119	585.5	432.5
1129	562.7	433.3
1143	542.5	457.3
1145	539.4	484.9
1144	535.2	509.9
1158	550.4	513.6
1170	565.4	536.9
1175	568.2	555
1180	574.7	555
1183	575.7	594.6
1183	582.6	597.5
1189	584.2	581.3
1194	561	581.4
1206	544.5	553.2
1219	507.4	552.1
1231	490.8	522.4
1230	505.7	505.1
1235	537.9	508
1245	574.4	511.6
1249	552.6	508.1
1237	578	528.1
1295	590.4	510.1
1239	570	520
1237	549.1	510.5
1221	538.9	514.6
1188	535.5	516.2
1169	532.6	527.5
1177	543.6	532.3
<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>
<u>1143.93</u>	<u>586.96</u>	<u>547.44</u>

WHEELABRATOR
 SAGOLA, MI
 E TUBE / OUTLET
 7/23/96
 TEST 2 / RUN 2 (1)
 14:36:00-15:35:00

NOX PPM	O2 %	CO PPM	CO2 %
4.16202	17.2416	1813.84	3.25053
4.36257	17.2091	1811.16	3.32895
4.9747	17.1935	1811.32	3.32808
5.135	17.2118	1811.58	3.318
5.44733	17.2299	1812.62	3.28803
4.86377	17.4018	1815.63	3.11883
4.71993	17.4818	1816.4	3.08487
4.50222	17.5374	1815.71	2.9605
4.5023	17.6156	1816.81	2.9155
4.08543	17.6185	1814.78	2.93383
4.36667	17.5309	1808.84	3.05133
4.37897	17.4879	1799.76	3.068
4.82272	17.4896	1791.01	3.02833
4.72002	17.4239	1782.71	3.108
4.87618	17.3171	1777.14	3.2105
4.50228	17.3275	1775.1	3.21487
4.40373	17.4278	1779.99	3.153
4.27215	17.4252	1782.59	3.15133
4.24343	17.5622	1783.77	3.0255
4.21462	17.6963	1799.97	2.88717
4.268	17.6183	1799.64	2.96717
4.16533	17.527	1792.56	3.05383
4.12835	17.4957	1784.14	3.06533
4.05033	17.4474	1784.67	3.078
3.8819	17.433	1783.61	3.10133
4.04208	17.3692	1789.26	3.17717
4.21457	17.3497	1792.8	3.20133
4.08542	17.377	1797.73	3.188
3.98868	17.39	1805.95	3.1455
3.82838	17.4305	1809.45	3.10133
3.7298	17.483	1810.38	3.07883
3.77912	17.4182	1812.01	3.13217
3.77498	17.351	1809.49	3.19718
3.8229	17.2845	1801.72	3.24633
3.93123	17.2702	1807.62	3.24135
3.95585	17.3614	1810.87	3.19633
4.08675	17.3015	1812.09	3.28472
4.16842	17.2573	1811.93	3.30055
4.07492	17.437	1816.61	3.09717
3.71738	17.4827	1816.89	3.06133
3.94755	17.4082	1816.81	3.16383
3.94763	17.3665	1815.63	3.14133
3.86135	17.4842	1814.41	3.14487
3.79967	17.3328	1815.18	3.23052
3.964	17.4304	1815.14	3.14133
3.95993	17.3704	1812.54	3.193
4.02972	17.4096	1812.46	3.1505
4.03798	17.4291	1811.85	3.13715
4.07492	17.3913	1807.94	3.16833
4.1899	17.3732	1802.65	3.19133
4.09962	17.2807	1790.53	3.27135
4.35428	17.2052	1785.6	3.3785
4.35433	17.109	1795.94	3.43312
4.37898	17.1388	1808.1	3.35587
4.36255	17.3236	1814.82	3.22487
4.43247	17.3483	1817.22	3.23467
4.64597	17.3432	1817.06	3.21383
4.48893	17.3758	1817.14	3.1755
4.69532	17.2951	1817.54	3.32388
4.78585	17.2221	1815.43	3.3591

<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>
<u>4.2626</u>	<u>17.384</u>	<u>1804.6</u>	<u>3.1858</u>

WHEELABRATOR

SAGOLA, MI

E TUBE / CUTLET

7/23/96

TEST 2 / RUN 3 (2)

16:46:00-17:45:00

NOX PPM	O2 %	CO PPM	CO2 %
3.18305	17.4213	1830	2.91383
3.25283	17.39	1829.95	2.9855
3.35157	17.3054	1827.76	3.09717
3.35953	17.3119	1827.72	3.0655
3.50342	17.5191	1826.82	2.90717
3.46653	17.2689	1826.37	3.103
3.6968	17.282	1825.58	3.16802
3.81198	17.2963	1826.58	3.11717
3.48293	17.5009	1828.16	2.88717
3.44185	17.5453	1830.04	2.85383
3.72127	17.6117	1829.95	2.82467
3.33092	17.4865	1829.22	2.9105
3.18542	17.5244	1826.9	2.898
3.19945	17.5322	1821.82	2.89383
3.08262	17.613	1819.01	2.843
3.00627	17.484	1819.13	2.928
2.9364	17.3875	1818.68	2.99967
2.91587	17.3887	1818.52	3.00883
2.98982	17.4422	1819.46	2.98633
2.91067	17.3706	1820.76	3.02467
3.01447	17.448	1822.65	2.96467
2.98803	17.4396	1824.67	2.82217
2.9651	17.4737	1825.6	2.878
3.01862	17.5505	1825.32	2.88467
3.24058	17.4588	1823.57	2.92717
3.25705	17.429	1823.16	2.94133
3.27757	17.398	1822.35	2.908
3.29808	17.4774	1820.07	2.94717
3.30207	17.3731	1819.7	3.03715
3.55697	17.2638	1819.78	3.17833
3.69878	17.0934	1816.88	3.29898
3.86133	17.0934	1812.46	3.36572
4.00515	16.9945	1814.66	3.42308
4.07482	17.044	1818.58	3.36257
3.94757	17.135	1823	3.31975
3.74207	17.3067	1824.5	3.09133
3.80367	17.3835	1824.42	3.03133
3.81607	17.2937	1825.4	3.11633
4.0132	17.2481	1826.09	3.11383
4.30912	17.2588	1825.85	3.1655
4.2351	17.0322	1825.03	3.34393
4.0462	17.07	1825.56	3.35568
3.84487	16.9488	1825.07	3.48482
3.91473	16.9789	1826.41	3.4265
4.29273	17.0206	1825.52	3.40465
4.19407	17.0738	1825.15	3.34407
4.02565	17.0869	1825.8	3.31808
3.9312	17.1077	1824.38	3.31388
4.05433	17.1129	1824.05	3.2587
4.03385	17.2755	1823.4	3.13217
3.87365	17.2404	1823.49	3.20467
4.01742	17.1844	1824.1	3.22717
3.96402	17.0986	1824.14	3.28557
3.90657	17.1363	1825.23	3.324
4.2084	17.0934	1825.28	3.33898
4.32147	17.1518	1823.81	3.19633
4.31325	17.2872	1823.93	3.13383
4.35853	17.2963	1824.67	3.17867
4.60498	17.1623	1824.91	3.24718
4.69532	17.2169	1824.14	3.19217

AVERAGE	AVERAGE	AVERAGE	AVERAGE
<u>3.6849</u>	<u>17.29</u>	<u>1823.9</u>	<u>3.1167</u>

WHEELABRATOR
SAGOLA, MI
E TUBE / OUTLET
7/23/96
TEST 2 / RUN 4 (3)
19:25:00-20:24:00

NOX PPM	O2 %	CO PPM	CO2 %
2.74745	17.2755	1829.55	3.09967
2.96513	17.1389	1826.62	3.25865
3.01452	17.0674	1826.58	3.34738
3.0639	17.1388	1828.34	3.25307
3.1461	17.1298	1830.52	3.2205
2.83363	17.3601	1830.52	3.0505
2.83777	17.4057	1830.12	2.92298
2.78022	17.5726	1828.53	2.808
2.92405	17.6494	1829.22	2.75383
2.82542	17.5127	1828.38	2.84967
2.72583	17.4278	1831.18	2.96133
2.4762	17.2	1828.12	3.10133
2.4885	17.2091	1827.68	3.18217
2.55018	17.0999	1827.8	3.28468
2.71463	17.2117	1830.93	3.15633
2.62017	17.2588	1828.67	3.08633
2.53377	17.3835	1830.73	3.00633
2.47213	17.4266	1830.57	2.98883
2.51318	17.4858	1831.95	2.85467
2.36272	17.4867	1830.62	2.86633
2.22538	17.4892	1829.63	2.87133
2.27453	17.4865	1830.18	2.89967
2.1102	17.6247	1830.4	2.798
2.04458	17.4448	1829.38	2.93383
2.11435	17.2546	1824.5	3.1605
2.24992	17.1258	1820.84	3.22867
2.29102	17.3055	1828.33	3.12217
2.27047	17.2183	1830	3.15883
2.41853	17.2664	1831.3	3.128
2.4638	17.4188	1829.06	2.92133
2.39807	17.437	1828.5	2.93633
2.58718	17.2274	1831.18	3.133
2.55435	17.2052	1830.77	3.16633
2.47202	17.178	1830.83	3.23053
2.3774	17.282	1830.97	3.0655
2.25397	17.3849	1830.97	3.06133
2.16772	17.2185	1831.3	3.18717
2.25822	17.1051	1830.24	3.31315
2.60355	17.0713	1830.44	3.34003
2.8584	17.0322	1831.01	3.35583
2.79683	17.0452	1831.58	3.31808
2.89118	17.2377	1832.23	3.13633
2.86242	17.3588	1828.77	2.98217
2.91182	17.4291	1826.09	2.94383
2.70635	17.4122	1827.39	2.9655
2.73108	17.4655	1829.51	2.9455
2.82143	17.3745	1831.66	3.0255
2.62422	17.3366	1826.66	3.07383
2.5172	17.3458	1823.77	3.03383
2.56665	17.3666	1827.99	3.04883
2.51315	17.3991	1827.47	2.95383
2.51727	17.4787	1831.66	2.9105
2.34443	17.4801	1831.05	2.88383
2.21697	17.5387	1831.42	2.8855
2.29515	17.544	1831.05	2.82467
2.28282	17.5478	1831.26	2.83883
2.13893	17.4422	1829.63	2.9805
2.15942	17.3067	1825.44	3.07383
2.24168	17.3847	1825.48	3.01383
2.2869	17.39	1823.89	2.99133

<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>
<u>2.5335</u>	<u>17.335</u>	<u>1829.2</u>	<u>3.0492</u>

LP / SAGOLA, MI. TEST 2 RUN 2 (1)
 DRYER RTO STACK
 7/23/96

NOX	O2	CO	CO2	THC
3.662	16.784	221.09	3.62037	33.1722
3.95075	16.7759	225.179	3.5821	29.2249
3.73927	16.786	213.196	3.60403	27.2571
3.79622	16.7768	232.137	3.59843	32.8565
3.7718	16.8673	225.484	3.4921	31.7668
3.62947	17.0077	229.919	3.36593	30.7471
3.45458	17.0351	212.585	3.35273	27.9623
3.4668	17.1551	212.423	3.25512	32.2234
3.48307	17.151	240.153	3.25835	32.9163
3.4668	17.1378	214.966	3.31842	28.2708
3.38953	17.0544	198.059	3.36493	28.1048
3.50748	17.0646	202.983	3.29255	31.4811
3.59287	17.0788	217.529	3.34215	9.89708
3.46273	16.9995	187.236	3.44657	8.44803
3.31227	16.9903	186.096	3.46185	14.259
3.43833	16.9923	191.081	3.42778	19.1251
3.40987	17.0869	196.086	3.39027	21.8197
3.22687	17.0524	184.245	3.3324	20.3234
3.2472	17.2049	188.029	3.19903	24.8625
3.31227	17.1652	217.611	3.23315	28.54
3.19027	17.1093	199.097	3.30807	27.6536
3.11707	17.0422	191.528	3.34135	27.0297
3.296	17.0981	202.148	3.33488	33.1681
3.3326	17.0961	222.941	3.33245	29.2521
3.28787	17.0157	199.992	3.40897	25.6594
3.1984	16.9485	203.349	3.45778	32.2148
3.2472	16.9222	209.086	3.449	29.7013
3.2472	16.9985	214.559	3.41963	32.1611
3.11707	17.0066	205.528	3.4033	18.8844
3.1374	17.0056	208.333	3.38615	23.4895
3.27567	17.0036	234.782	3.39758	25.962
3.21467	16.9507	214.64	3.46863	24.161
3.19027	16.9182	205.485	3.50365	23.6475
3.4058	16.8592	215.129	3.52225	28.9154
3.41393	16.8687	225.037	3.48812	27.5041
3.39767	16.8816	212.118	3.52062	24.4462
3.37327	16.8003	212.93	3.5814	30.1689
3.44847	16.8663	228.115	3.44235	28.6023
3.39767	17.0636	235.474	3.35108	33.3822
3.38953	16.9548	215.23	3.47108	28.807
3.40987	16.8958	209.737	3.46455	33.8859
3.41393	16.9436	234.497	3.44738	34.4731
3.52373	16.9101	212.83	3.51003	30.7735
3.4302	16.8877	202.108	3.45707	30.1912
3.51153	16.9273	214.091	3.45625	31.3375
3.54407	16.9517	219.014	3.49505	21.1556
3.4812	16.9853	204.163	3.4229	21.0335
3.5156	16.9273	197.774	3.44167	28.3597
3.601	16.9782	205.994	3.43595	26.0054
3.56033	16.8687	202.881	3.4938	27.7128
3.53593	16.8114	179.596	3.5846	24.0568
3.61727	16.722	179.972	3.64077	27.8613
3.70267	16.7342	213.196	3.61798	28.7876
3.67013	16.8419	206.686	3.51573	27.0224
3.57253	16.904	204.854	3.50282	28.8204
3.6986	16.8572	222.371	3.4938	34.3661
3.6864	16.9141	230.957	3.43182	30.2877
3.67827	16.8511	219.971	3.55295	26.2683
3.75553	16.7911	213.135	3.57797	31.7712
3.62873	16.7901	220.479	3.56593	29.3217

AVERAGES
 3.4624 16.952 210.73 3.4434 27.371

LF / SAGOLA, MI. TEST 2 RUN 3 (2)
 DRYER RTO STACK
 7/23/96

NOX	O2	CO	CO2	THC
3.58067	17.088	264.079	3.34945	26.8331
3.62947	17.0078	236.247	3.42858	28.1628
3.662	16.9751	220.439	3.45222	30.3943
3.68233	17.1764	236.674	3.29485	31.2304
3.7962	17.0717	233.948	3.38873	27.2493
3.6986	16.968	208.984	3.50932	25.8626
3.67013	16.9619	208.374	3.4856	29.8311
3.65387	17.15	243.978	3.27872	30.8789
3.59693	17.2405	232.483	3.25267	25.8382
3.57253	17.209	229.045	3.22272	26.2569
3.662	17.2466	239.38	3.25503	30.4329
3.5766	17.2079	242.879	3.24528	28.4408
3.43833	17.3066	215.78	3.20722	24.3323
3.3814	17.2569	198.669	3.18918	30.2803
3.40987	17.2547	211.507	3.22833	27.5195
3.41393	17.1774	219.421	3.30795	29.4576
3.37327	17.1256	198.812	3.32575	25.8207
3.47087	17.1429	195.282	3.31842	30.2478
3.479	17.0585	226.156	3.3731	30.883
3.418	17.15	215.413	3.31273	19.2615
3.418	17.1591	202.535	3.28112	5.87845
3.48273	17.1673	217.611	3.24863	5.3902
3.60913	17.1886	242.574	3.2259	5.07648
3.6864	17.2242	222.778	3.25437	4.76353
3.56847	17.1673	211.812	3.27542	4.46455
3.6498	17.1835	224.65	3.27468	2.99478
3.601	17.2262	228.983	3.24053	0.37557
3.52373	17.1713	205.017	3.34295	0.06142
3.59287	17.0087	202.474	3.42452	2.07553
3.73113	16.8232	225.159	3.54075	5.25593
3.78807	16.8774	217.916	3.588	4.30418
3.81247	16.7553	196.147	3.66202	1.44777
3.8857	16.8084	204.793	3.6318	0.28813
3.9345	16.8429	239.543	3.5741	0.19613
3.723	16.9294	226.278	3.4643	0.13175
3.89453	17.0849	229.108	3.35757	0.11548
3.97528	16.8843	247.782	3.4229	0.11143
3.90603	16.8286	259.926	3.4433	0.11022
4.02408	16.9365	251.689	3.48283	0.05488
4.00775	16.8276	238.871	3.61797	0.02843
4.0933	16.7402	254.272	3.6473	0.0468
4.12587	16.6537	251.383	3.71508	0.34585
4.04027	16.6343	230.469	3.72243	1.89743
4.13802	16.7055	233.805	3.70528	3.35735
4.1299	16.7126	270.284	3.65308	5.89478
4.00775	16.7392	250.264	3.63178	7.79452
3.86533	16.8053	233.398	3.61875	5.45977
3.9955	16.7391	255.269	3.60863	4.78728
4.0403	16.8835	274.638	3.4929	4.54875
3.9182	16.9478	260.905	3.51723	3.61042
3.90193	16.8569	247.457	3.56527	4.29448
4.10955	16.7562	264.872	3.61487	4.4995
4.07693	16.7512	270.732	3.60345	4.23787
4.19918	16.6933	241.13	3.6563	4.86123
4.18283	16.7991	230.652	3.55785	4.28908
4.15845	16.9304	252.624	3.45463	5.34505
4.1584	16.9477	249.349	3.49282	5.99412
4.19508	16.845	226.746	3.54978	19.5822
4.23175	16.8581	231.059	3.53843	29.8104
4.23178	16.9019	259.094	3.48232	20.7214

AVERAGES
 3.7927 16.983 232.69 3.4431 12.381

LP/SAGOLA, MI. TEST 2 RUN 4 (3)
 DRYER RTO STACK
 7/23/96

NOX	O2	CO	CO2	THC
3.24313	16.2991	240.925	3.50117	25.6644
3.2228	16.1781	215.902	3.60158	22.5687
3.27567	16.1801	216.227	3.56597	26.2911
3.35293	16.233	238.525	3.52627	24.8889
3.32853	16.3571	252.218	3.40573	26.5483
3.174	16.4733	242.676	3.30292	23.2121
3.33667	16.5845	239.746	3.20497	26.5853
3.38547	16.6426	305.603	3.13235	27.0756
3.235	16.6588	291.585	3.19347	23.1677
3.0398	16.5844	240.489	3.27287	22.1208
3.04387	16.4888	231.954	3.37145	26.2481
3.15772	16.4253	247.355	3.44575	25.6274
3.1862	16.3428	224.752	3.53025	21.2528
3.1618	16.3409	228.583	3.49047	24.0889
3.23093	16.3948	243.917	3.45065	27.3914
3.21873	16.5355	254.415	3.34126	24.2997
3.10883	16.5345	238.41	3.3386	25.1786
3.1008	16.6538	229.472	3.2098	26.7317
3.05605	16.6934	254.282	3.2228	26.1987
3.05198	16.7138	270.671	3.20893	22.3034
2.98287	16.6241	245.199	3.2421	21.0766
2.97468	16.8013	229.584	3.12173	24.7518
2.9015	16.7464	262.431	3.20885	25.4244
2.94215	16.5866	227.193	3.36982	20.6864
2.95845	16.4101	207.052	3.4953	21.2117
3.1618	16.4817	218.381	3.418	25.3202
3.1984	16.4571	245.036	3.43433	22.4276
3.174	16.457	232.239	3.4474	20.6336
3.2228	16.5732	242.554	3.32663	25.3634
3.25533	16.6436	285.136	3.28757	23.2589
3.32447	16.5232	291.565	3.43597	23.5889
3.27567	16.4898	251.872	3.44738	20.7388
3.21873	16.406	230.062	3.53353	23.9925
3.26753	16.4927	257.629	3.40168	24.5772
3.23093	16.5814	243.835	3.3548	19.7885
3.113	16.4958	224.203	3.47578	18.0254
3.31833	16.3695	229.248	3.58147	21.0583
3.52373	16.3194	245.341	3.60905	19.9532
3.45867	16.2736	231.242	3.65792	15.9477
3.50747	16.2462	227.641	3.63587	15.4353
3.56033	16.3581	250.59	3.54322	17.5098
3.53593	16.508	275.289	3.40085	18.1685
3.601	16.5875	265.218	3.34205	18.1632
3.50747	16.5854	261.678	3.34613	20.5371
3.53593	16.6354	292.826	3.31352	21.4632
3.45053	16.6283	279.399	3.33308	18.7024
3.3082	16.5763	227.58	3.38288	18.3874
3.25127	16.6384	202.311	3.3176	22.4556
3.357	16.5845	227.783	3.3543	23.0957
3.30413	16.6242	213.806	3.32817	18.9038
3.20653	16.7087	213.257	3.24133	21.0014
3.21873	16.727	243.734	3.24535	24.1781
3.20653	16.723	257.346	3.2421	21.2028
3.17807	16.7769	240.743	3.18862	21.7074
3.113	16.8104	231.14	3.19442	22.5443
3.1252	16.7484	254.598	3.27383	18.1209
3.20247	16.6405	241.781	3.347	18.1168
3.12113	16.6578	202.596	3.33472	18.6684
3.14553	16.6628	198.483	3.307	22.7686
3.18213	16.7097	225.973	3.28263	23.9888

AVERAGES

3.23384	16.5369	242.438	3.36871	22.2061
---------	---------	---------	---------	---------

LP SAGOLA, MI. TEST 8 RUN 1
 PRESS RTO INLET
 7/25/98

DATE	TIME	NOX	O2	CO	CO2	THC
725.96	421.02	1.099	20.916	5.493	0.024	50.049
725.96	422.02	1.058	20.894	4.476	0.033	76.497
725.96	423.02	2.645	20.928	4.679	0.065	274.658
725.96	424.02	4.395	20.958	5.697	0.09	388.997
725.96	425.02	5.005	20.916	6.104	0.024	111.898
725.96	426.02	4.557	20.958	5.697	0.033	83.008
725.96	427.02	5.859	20.958	5.697	0.057	288.086
725.96	428.02	8.016	20.947	6.51	0.09	405.273
725.96	429.02	8.138	20.905	5.29	0.049	110.27
725.96	430.02	6.999	20.937	3.662	0.041	135.498
725.96	431.02	8.179	20.916	4.272	0.081	400.798
725.96	432.02	9.725	20.937	4.883	0.041	290.527
725.96	433.02	8.789	20.958	3.662	0.033	91.553
725.96	434.02	7.528	20.979	2.848	0.049	242.92
725.96	435.02	9.644	20.905	3.459	0.09	424.388
725.96	436.02	10.539	20.958	6.104	0.049	128.581
725.96	437.02	8.219	20.916	5.697	0.008	111.898
725.96	438.02	8.87	20.968	6.714	0.065	362.142
725.96	439.02	10.62	20.905	7.324	0.073	335.693
725.96	440.02	10.213	20.894	6.51	0.033	89.518
725.96	441.02	8.301	20.937	5.9	0.033	183.278
725.96	442.02	10.254	20.928	6.104	0.098	445.964
725.96	443.02	11.353	20.968	7.121	0.065	181.478
725.96	444.02	9.44	20.968	6.714	0.033	102.539
725.96	445.02	9.196	20.916	5.697	0.073	324.707
725.96	446.02	10.742	20.873	6.51	0.081	360.514
725.96	447.02	10.62	20.937	5.29	0.033	96.438
725.96	448.02	8.423	20.937	4.883	0.033	150.553
725.96	449.02	10.091	20.905	5.493	0.081	406.494
725.96	450.02	10.986	20.928	5.697	0.057	234.375
725.96	451.02	9.766	20.947	4.272	0.033	90.739
725.96	452.02	8.911	20.894	4.272	0.057	249.837
725.96	453.02	11.434	20.894	5.086	0.088	426.025
725.96	454.02	11.312	20.926	4.883	0.033	121.663
725.96	455.02	8.789	20.937	3.052	0.041	120.85
725.96	456.02	10.254	20.916	4.272	0.081	363.383
725.96	457.02	11.434	20.937	6.307	0.057	298.258
725.96	458.02	10.132	20.894	5.493	0.033	91.146
725.96	459.02	8.852	20.958	5.29	0.041	220.133
725.96	500.02	11.271	20.894	6.917	0.09	432.536
725.96	501.02	11.393	20.926	6.917	0.041	193.057
725.96	502.02	9.481	20.926	5.493	0.049	107.015
725.96	503.02	9.644	20.916	6.104	0.081	328.369
725.96	504.02	12.004	20.894	7.121	0.081	369.873
725.96	505.02	11.23	20.947	5.697	0.024	94.808
725.96	506.02	8.748	20.947	4.476	0.033	175.781
725.96	507.02	11.149	20.926	5.086	0.098	444.743
725.96	508.02	12.248	20.937	5.086	0.041	215.251
725.96	509.02	10.254	20.926	3.459	0.024	99.691
725.96	510.02	9.44	20.979	3.459	0.057	305.583
725.96	511.02	10.824	20.894	3.662	0.081	384.115
725.96	512.02	11.108	20.937	2.948	0.024	102.946
725.96	513.02	8.952	20.947	3.052	0.024	139.567
725.96	514.02	10.132	20.926	3.866	0.073	403.239
725.96	515.02	11.637	20.926	4.679	0.065	320.231
725.96	516.02	10.213	20.916	3.459	0.016	91.96
725.96	517.02	8.952	20.926	2.645	0.049	255.534
725.96	518.02	10.986	20.937	3.459	0.09	455.729
725.96	519.02	11.393	20.926	3.459	0.024	131.022
725.96	520.02	8.993	20.937	2.645	0.033	131.836

AVERAGES
 9.1757 20.929 5.0117 0.0531 233.39

LP SAGOLA MI. TEST 8 RUN 2
 PRESS RTO INLET
 7/25/98

DATE	TIME	NOX	O2	CO	CO2	THC
725.96	601.02	6.999	20.947	6.307	0.09	479.736
725.96	602.02	7.446	20.968	5.9	0.033	141.602
725.96	603.02	6.388	20.937	4.476	0.016	136.719
725.96	604.02	7.08	20.958	5.697	0.073	415.446
725.96	605.02	8.83	20.947	6.307	0.073	380.859
725.96	606.02	7.935	21.011	3.868	0.033	104.98
725.96	607.02	6.144	20.958	3.662	0.049	240.479
725.96	608.02	7.65	20.979	5.493	0.09	520.833
725.96	609.02	8.28	20.979	5.697	0.057	173.747
725.96	610.02	7.365	20.916	4.679	0.016	125.326
725.96	611.02	7.08	20.958	5.493	0.073	381.256
725.96	612.02	7.812	20.98	6.917	0.073	364.176
725.96	613.02	8.057	20.947	5.697	0.024	101.725
725.96	614.02	6.307	20.916	4.272	0.016	188.395
725.96	615.02	6.999	20.979	5.9	0.081	474.04
725.96	616.02	8.26	20.99	5.697	0.041	215.658
725.96	617.02	7.487	21	4.883	0.024	103.76
725.96	618.02	6.838	20.916	5.086	0.049	323.079
725.96	619.02	8.016	20.905	5.9	0.081	439.86
725.96	620.02	8.87	20.968	5.9	0.024	115.153
725.96	621.02	6.999	20.958	5.086	0.024	157.064
725.96	622.02	6.999	20.958	5.697	0.09	444.336
725.96	623.02	8.423	20.926	6.51	0.057	295.003
725.96	624.02	7.853	20.937	5.493	0.024	98.681
725.96	625.02	6.592	20.947	5.086	0.041	279.541
725.96	626.02	7.324	20.947	5.9	0.081	441.081
725.96	627.02	9.074	20.979	5.29	0.024	122.07
725.96	628.02	7.284	20.979	4.679	0.008	125.732
725.96	629.02	7.324	20.905	5.086	0.057	386.149
725.96	630.02	8.993	20.894	5.493	0.057	349.528
725.96	631.02	8.952	20.968	5.29	0.016	91.553
725.96	632.02	7.243	20.958	4.272	0.041	220.133
725.96	633.02	7.731	20.968	5.493	0.09	478.074
725.96	634.02	9.44	20.926	5.493	0.041	149.333
725.96	635.02	7.975	20.916	4.272	0.024	116.374
725.96	636.02	7.65	20.947	6.307	0.049	385.397
725.96	637.02	8.382	20.947	7.324	0.057	347.087
725.96	638.02	8.708	20.926	7.528	0.024	93.587
725.96	639.02	7.08	21	7.324	0.041	177.409
725.96	640.02	8.138	21	7.528	0.09	445.964
725.96	641.02	9.888	20.905	8.341	0.041	209.554
725.96	642.02	8.26	20.947	6.104	0.033	95.215
725.96	643.02	7.406	20.905	5.493	0.065	305.99
725.96	644.02	9.074	21.011	6.307	0.073	405.273
725.96	645.02	9.582	20.947	5.086	0.024	104.167
725.96	646.02	7.568	20.979	4.272	0.024	148.519
725.96	647.02	8.341	20.947	4.476	0.081	406.494
725.96	648.02	9.074	20.937	5.086	0.057	273.437
725.96	649.02	8.993	20.968	3.052	0.033	91.96
725.96	650.02	7.69	20.926	3.052	0.049	277.1
725.96	651.02	9.359	20.947	3.868	0.098	433.35
725.96	652.02	9.989	20.979	3.856	0.041	119.829
725.96	653.02	8.138	20.947	3.052	0.024	118.001
725.96	654.02	8.83	20.968	3.868	0.081	393.066
725.96	655.02	9.806	20.968	5.086	0.049	332.438
725.96	656.02	9.359	20.979	3.866	0.024	85.449
725.96	657.02	7.853	20.968	3.052	0.041	231.527
725.96	658.02	9.928	20.958	4.476	0.073	446.37
725.96	659.02	10.213	20.968	4.679	0.041	142.415
725.96	700.02	8.708	20.937	3.459	0.024	112.305

AVERAGES
 8.1001 20.954 5.2253 0.0488 255.7

LP SAGOLA, MI. TEST 8 RUN 3
 PRESS FTO INLET
 7/25/96

DATE	TIME	NOX	O2	CO	CO2	THC
725.96	735.22	7.161	20.905	5.086	0.073	431.722
725.96	736.22	7.731	20.979	3.866	0.024	117.594
725.96	737.22	6.429	21.042	2.441	0.024	132.243
725.96	738.22	6.714	21	4.679	0.081	399.17
725.96	739.22	7.202	21.011	5.697	0.057	304.769
725.96	740.22	7.08	20.979	5.086	0.008	87.077
725.96	741.22	5.778	21.074	3.052	0.049	215.658
725.96	742.22	7.243	20.99	3.459	0.09	487.061
725.96	743.22	7.935	21.064	3.866	0.033	141.602
725.96	744.22	6.673	20.979	3.866	0.024	111.898
725.96	745.22	6.755	20.979	5.29	0.057	362.956
725.96	746.22	6.958	20.99	5.697	0.073	358.073
725.96	747.22	7.365	20.99	4.679	0.016	93.18
725.96	748.22	6.144	20.958	4.272	0.008	196.533
725.96	749.22	6.958	21	5.29	0.09	459.391
725.96	750.22	7.65	20.958	7.121	0.041	194.906
725.96	751.22	7.121	21	7.121	0.033	95.622
725.96	752.22	6.877	20.99	8.138	0.073	314.535
725.96	753.22	7.284	20.979	8.341	0.09	418.294
725.96	754.22	7.975	20.979	6.104	0.033	109.863
725.96	755.22	6.307	20.99	4.476	0.024	139.567
725.96	756.22	7.121	21.011	4.883	0.081	421.548
725.96	757.22	8.097	20.979	5.086	0.065	315.755
725.96	758.22	8.097	20.958	3.662	0.024	97.656
725.96	759.22	7.08	21	2.848	0.065	270.589
725.96	800.22	7.487	21	4.069	0.081	453.695
725.96	801.22	8.464	21.053	4.272	0.033	127.767
725.96	802.22	6.673	21	3.866	0.024	125.732
725.96	803.22	6.836	21.021	4.272	0.09	392.66
725.96	804.22	8.097	20.968	4.476	0.065	347.9
725.96	805.22	8.016	21	4.272	0.024	89.925
725.96	806.22	6.877	21.032	4.272	0.041	212.402
725.96	807.22	7.609	20.99	4.476	0.081	493.164
725.96	808.22	8.016	20.99	4.272	0.033	163.574
725.96	809.22	7.039	21.011	2.238	0.024	112.712
725.96	810.22	6.917	21.011	2.645	0.065	354.004
725.96	811.22	7.284	20.979	4.272	0.057	382.894
725.96	812.22	7.935	20.968	3.459	0.016	100.098
725.96	813.22	6.47	20.99	3.459	0.033	171.305
725.96	814.22	7.121	21.042	4.476	0.081	448.812
725.96	815.22	7.609	21.011	4.272	0.057	226.237
725.96	816.22	6.877	20.99	2.848	0.041	98.877
725.96	817.22	6.632	20.979	2.848	0.057	318.604
725.96	818.22	6.714	20.968	3.866	0.081	423.684
725.96	819.22	7.935	21.053	3.052	0.024	109.458
725.96	820.22	6.47	21.011	2.848	0.024	135.498
725.96	821.22	6.877	20.947	3.459	0.073	413.818
725.96	822.22	7.568	20.937	3.866	0.049	301.921
725.96	823.22	8.097	20.979	3.459	0.033	78.904
725.96	824.22	6.144	21	4.476	0.024	93.587
725.96	825.22	6.144	21.011	5.29	0.073	347.493
725.96	826.22	6.348	21.011	5.086	0.081	379.232
725.96	827.22	7.853	20.937	3.662	0.024	98.063
725.96	828.22	5.859	21.042	2.645	0.041	105.794
725.96	829.22	6.144	21	3.052	0.081	370.28
725.96	830.22	7.243	20.968	4.069	0.065	379.639
725.96	831.22	8.341	21	3.662	0.016	97.656
725.96	832.22	6.714	21.042	2.645	0.033	218.878
725.96	833.22	7.406	20.947	4.272	0.106	502.116
725.96	834.22	8.097	20.99	7.121	0.041	186.361

AVERAGES

7.1608 20.994 4.3233 0.0501 252.27 E-12

LP
 SAGOLA MI
 PRESS RTG / STACK
 7/25/98
 TEST 8 / RUN 1

TIME	NOX PPM	CO PPM
421.11	15.689	9.742
422.11	25.739	32.325
423.11	49.258	19.914
424.11	51.333	6.283
425.11	20.858	19.304
426.11	26.228	27.442
427.11	50.072	9.945
428.11	48.078	11.573
429.11	21.792	28.866
430.11	35.983	19.1
431.11	57.233	5.573
432.11	27.245	22.559
433.11	24.193	28.628
434.11	47.02	11.166
435.11	50.316	11.166
436.11	22.565	28.256
437.11	32.412	20.321
438.11	57.64	6.283
439.11	32.68	22.355
440.11	21.914	28.424
441.11	42.951	12.59
442.11	53.164	10.148
443.11	22.443	28.459
444.11	28.181	20.321
445.11	50.926	5.573
446.11	39.899	21.338
447.11	20.694	28.831
448.11	37.743	15.438
449.11	53.937	9.335
450.11	24.691	30.9
451.11	25.088	21.948
452.11	47.386	7.3
453.11	48.729	20.728
454.11	22.118	29.68
455.11	35.057	15.845
456.11	55.24	7.707
457.11	27.611	32.121
458.11	23.949	24.797
459.11	43.439	7.057
500.11	50.235	18.693
501.11	22.118	29.68
502.11	31.69	16.252
503.11	54.304	5.489
504.11	37.214	31.104
505.11	22.81	26.221
506.11	40.268	8.114
507.11	54.548	15.235
508.11	23.298	32.528
509.11	28.879	17.473
510.11	46.939	5.573
511.11	40.998	30.697
512.11	21.467	29.68
513.11	35.553	9.945
514.11	57.478	13.404
515.11	27.367	35.783
516.11	25.251	17.676
517.11	43.806	6.079
518.11	47.997	28.459
519.11	20.287	31.511
520.11	32.819	9.742

AVERAGE

AVERAGE

38.433

18.883

LP.
SAGOLA, MI
PRESS RTA / STACK
7/25/96
TEST 8 / RUN 1

TIME	THC PPM
16:21:00	4.15
16:22:00	4.493
16:23:00	6.133
16:24:00	5.645
16:25:00	3.913
16:26:00	3.139
16:27:00	4.788
16:28:00	6.006
16:29:00	2.968
16:30:00	7.307
16:31:00	12.78
16:32:00	4.379
16:33:00	2.739
16:34:00	3.856
16:35:00	5.386
16:36:00	2.686
16:37:00	3.086
16:38:00	5.417
16:39:00	4.933
16:40:00	3.148
16:41:00	3.776
16:42:00	6.648
16:43:00	4.234
16:44:00	4.163
16:45:00	6.828
16:46:00	15.87
16:47:00	12.79
16:48:00	13.32
16:49:00	14.88
16:50:00	4.005
16:51:00	3.038
16:52:00	9.013
16:53:00	15.8
16:54:00	12.98
16:55:00	10.81
16:56:00	10.53
16:57:00	13.4
16:58:00	5.337
16:59:00	3.983
17:00:00	5.68
17:01:00	2.612
17:02:00	2.194
17:03:00	3.75
17:04:00	5.113
17:05:00	1.301
17:06:00	2.211
17:07:00	12.4
17:08:00	12.48
17:09:00	11.53
17:10:00	13.49
17:11:00	5.021
17:12:00	2.379
17:13:00	2.88
17:14:00	5.79
17:15:00	4.462
17:16:00	2.255
17:17:00	3.645
17:18:00	5.948
17:19:00	2.264
17:20:00	2.405

AVERAGE

6.302783333

LP
 SAGOLA, MI
 PRESS RTO / STACK
 7/25/98
 TEST 8 / RUN 2

TIME	NOX PPM	CO PPM
601.11	43.48	43.311
602.11	20.531	18.897
603.11	30.419	6.893
604.11	51.293	31.918
605.11	27.448	38.021
606.11	22.972	10.759
607.11	38.848	14.421
608.11	48.882	42.701
609.11	22.443	19.1
610.11	28.018	6.283
611.11	46.979	28.459
612.11	31.07	38.835
613.11	22.158	12.58
614.11	34.691	12.386
615.11	48.688	43.718
616.11	23.338	22.762
617.11	27.082	6.883
618.11	45.333	24.797
619.11	39.615	39.852
620.11	21.955	14.828
621.11	32.372	10.148
622.11	51.252	41.48
623.11	26.024	27.238
624.11	24.803	7.91
625.11	41.975	21.338
626.11	45.148	41.887
627.11	21.955	17.473
628.11	29.239	7.91
629.11	52.92	38.021
630.11	30.012	30.697
631.11	21.874	8.521
632.11	38.19	18.49
633.11	48.2	42.294
634.11	22.769	19.1
635.11	26.512	9.335
636.11	48.322	35.376
637.11	34.488	35.987
638.11	21.792	8.928
639.11	36.685	16.659
640.11	53.164	42.904
641.11	25.576	20.118
642.11	25.943	5.469
643.11	44.375	32.731
644.11	43.277	36.8
645.11	20.409	10.759
646.11	32.901	14.828
647.11	52.432	43.107
648.11	26.594	20.728
649.11	24.6	7.097
650.11	42.137	29.273
651.11	48.688	38.428
652.11	22.81	11.573
653.11	30.829	11.778
654.11	55.118	43.921
655.11	31.151	20.728
656.11	21.141	6.893
657.11	39.004	26.221
658.11	51.781	38.225
659.11	22.728	14.421
700.11	27.814	9.742

AVERAGE

AVERAGE

34.505

23.366

LP.
 SAGOLA, MI
 PRESS RTO / STACK
 7/25/98
 TEST 8 / RUN 2

TIME	THC PPM
18:01:00	4.988
18:02:00	2.071
18:03:00	2.101
18:04:00	6.415
18:05:00	2.941
18:06:00	1.831
18:07:00	4.041
18:08:00	5.742
18:09:00	5.057
18:10:00	11.78
18:11:00	10.2
18:12:00	2.836
18:13:00	0.7782
18:14:00	2.541
18:15:00	4.933
18:16:00	1.759
18:17:00	1.196
18:18:00	3.698
18:19:00	4.308
18:20:00	1.587
18:21:00	3.091
18:22:00	11.51
18:23:00	12.7
18:24:00	11.71
18:25:00	15.11
18:26:00	16.74
18:27:00	11.83
18:28:00	12.78
18:29:00	16.68
18:30:00	12.86
18:31:00	11.75
18:32:00	14.09
18:33:00	15.8
18:34:00	11.91
18:35:00	11.96
18:36:00	14.7
18:37:00	1.521
18:38:00	0.3958
18:39:00	7.575
18:40:00	16.45
18:41:00	11.69
18:42:00	11.24
18:43:00	15.48
18:44:00	13.98
18:45:00	11.04
18:46:00	12.35
18:47:00	5.258
18:48:00	1.662
18:49:00	0.8309
18:50:00	13.52
18:51:00	14.23
18:52:00	7.733
18:53:00	12.31
18:54:00	16.42
18:55:00	13.18
18:56:00	10.78
18:57:00	14.74
18:58:00	6.12
18:59:00	1.051
19:00:00	1.618

AVERAGE

8.448948333

LP.
 SAGOLA, MI
 PRESS RTO / STACK
 7/25/98
 TEST 8 / RUN 3

TIME	NOX PPM	CO PPM
735.51	24.03	14.421
736.51	44.009	41.887
737.51	44.619	18.49
738.51	20.124	7.3
739.51	31.354	32.325
740.51	55.85	30.697
741.51	27.285	9.742
742.51	21.507	12.59
743.51	38.981	38.859
744.51	51.577	18.083
745.51	19.951	7.097
746.51	27.285	28.652
747.51	54.283	34.968
748.51	32.168	9.742
749.51	19.921	12.183
750.51	38.231	39.445
751.51	51.374	18.897
752.51	20.938	6.283
753.51	23.868	24.187
754.51	49.014	35.173
755.51	39.248	11.166
756.51	19.382	9.538
757.51	33.47	38.428
758.51	54.182	18.897
759.51	24.519	8.114
800.51	22.565	20.524
801.51	42.87	37.004
802.51	44.68	12.59
803.51	18.252	8.114
804.51	31.029	35.783
805.51	56.684	20.728
806.51	27.53	7.3
807.51	20.531	16.659
808.51	39.37	33.138
809.51	52.473	12.997
810.51	20.734	8.724
811.51	27.204	33.138
812.51	52.432	23.169
813.51	33.257	7.097
814.51	19.514	14.828
815.51	36.359	33.342
816.51	54.507	14.824
817.51	21.711	8.079
818.51	24.152	29.273
819.51	48.586	23.78
820.51	41.893	8.283
821.51	18.903	12.987
822.51	33.908	31.511
823.51	55.524	15.642
824.51	24.6	6.283
825.51	22.077	26.424
826.51	43.317	27.238
827.51	46.817	6.283
828.51	18.008	11.776
829.51	29.076	31.714
830.51	55.362	15.845
831.51	27.814	5.876
832.51	19.758	22.968
833.51	40.938	28.256
834.51	53.042	7.707

<u>AVERAGE</u>	<u>AVERAGE</u>
<u>34.884</u>	<u>19.731</u>

LP.
 SAGOLA MI
 PRESS RTC / STACK
 7/25/98
 TEST 8 / RUN 3


TIME	THC PPM
19:35:00	3.394
19:36:00	5.065
19:37:00	6.595
19:38:00	5.21
19:39:00	3.733
19:40:00	5.878
19:41:00	7.645
19:42:00	3.469
19:43:00	4.906
19:44:00	6.768
19:45:00	6.586
19:46:00	3.662
19:47:00	5.724
19:48:00	7.927
19:49:00	3.689
19:50:00	3.926
19:51:00	6.379
19:52:00	5.992
19:53:00	3.653
19:54:00	4.703
19:55:00	7.567
19:56:00	3.952
19:57:00	3.579
19:58:00	6.005
19:59:00	7.278
20:00:00	3.566
20:01:00	4.676
20:02:00	7.709
20:03:00	4.322
20:04:00	3.337
20:05:00	6.108
20:06:00	6.551
20:07:00	3.579
20:08:00	3.944
20:09:00	5.734
20:10:00	5.695
20:11:00	3.481
20:12:00	4.951
20:13:00	6.969
20:14:00	3.522
20:15:00	4.186
20:16:00	5.645
20:17:00	6.288
20:18:00	3.478
20:19:00	5.092
20:20:00	6.666
20:21:00	3.949
20:22:00	3.654
20:23:00	5.034
20:24:00	6.081
20:25:00	3.632
20:26:00	3.862
20:27:00	6.799
20:28:00	4.287
20:29:00	3.834
20:30:00	4.696
20:31:00	6.723
20:32:00	4.028
20:33:00	4.05
20:34:00	6.732

AVERAGE

5.10735

APPENDIX F

THC ANALYZER SPECIFICATIONS





TOTAL HYDROCARBON ANALYZER (FLAME IONIZATION)
Model RS 55

TECHNICAL DATA

MAINS : 115V/60H

RECORDER OUTPUT : 0 - 5 V / 4-20mA

MODEL: Manual switching
 Solenoid valves

HOUSING: Case, 19"- Rack

MEASURING RANGES:	1 = 0 - 10	C ₁
	2 = 0 - 100	C ₁
	3 = 0 - 1,000	C ₁
	4 = 0 - 10,000	C ₁

SPECIAL OPTIONS :

Flame out alarm

1 Alarm

Sample line

.....

ANALYZER CONDITIONS :

Temperature : ..160.°C

Zero Point : ..3,90....

Gain :7,70.....

Pressure Setting: Sample/Spangas/Zerogas: 200 mbar


Fuel: Hydrogen : .. 0,35 bar

Combustion Air :0,80 bar


Span Gases : ..300. ppm C₁

24.000. ppm C₁

CALIBRATION DIAGRAM




26A



- 1 Inductometer pressure regulator
- 2 Manometer Gauge
- 3 Filter
- 4 Abdeckventil/Abdeck valve
- 5 3 Wege Ventil/3 way valve
- 6 Kupplung/capillary
- 7 Magnetventil/solenoid valve
- 8 Pumpe/pump
- 9 Hochdruckregler/hoch pressure regulator

Zündventil/
Ignition valve
P-A angezapft/
energized
E-A Stromlos
at rest



FLAMMEN IONISATION DETECTOR
Flame Ionization Detector

Fließplan
Flowchart


KS 33
13 DE 31 45

Handumschaltung
Manual switching



APPENDIX G

MEASUREMENT SYSTEMS PERFORMANCE SPECIFICATIONS



INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job Li.P. Sagola
 Source No. 1, 2, 3 Cyclone Outlets
 Test 2 Run Date 7/23, 24/96
 Stack Dimen. 41.5 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 28.33 IN.HG
 Static Pressure 8.6 - 9.0 IN.WC
 Operators D. Van Hoever
 Pitot No. C_p

Cross-section View	Elevation View
-----------------------	-------------------


Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>9</u> IN.		Time Start:	HRS
A 1	<u>1/6</u>	<u>6.92</u>	<u>15.92</u>		
2	<u>3/6</u>	<u>20.75</u>	<u>29.75</u>		
3	<u>5/6</u>	<u>34.58</u>	<u>43.58</u>		
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Job L.P. / Sagala, MI
 Source E Tube / Outlet
 Test 2 Run 0 Date 7-23-96
 Stack Dimen. 01.5 IN.
 Dry Bulb 155 °F Wet bulb 143 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.35 IN.HG
 Static Pressure -1.93 IN.WC
 Operators M. Kuchwitt D. Hilleman
 Pitot No. ENST C₀ N/A

Drawing of Test Site



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: <u>6.0</u> IN.			Time Start: <u>NA</u> HRS		
<u>1</u>	<u>.4 m</u>	<u>15.60</u>	<u>21.60</u>		
<u>2</u>	<u>1.2 m</u>	<u>46.90</u>	<u>52.80</u>		<u>155</u>
<u>3</u>	<u>2 m</u>	<u>79.00</u>	<u>84.00</u>		
Temp. Meas. Device & S/N: <u>PDT-45 / TC</u>				Time End: <u>NA</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/SAMPLE
 Source DWYER RTO STACK
 Test 2 Run 0 Date 7-23-76
 Stack Dimen. 96.5 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure _____ IN.HG
 Static Pressure _____ IN.WC
 Operators S.D. M.P.
 Pitot No. C_p 69

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>5.5</u> IN.		Time Start: _____ HRS	
1	.16	15.44	19.94		
2	.50	48.25	53.75		
3	.83	80.01	85.51		


Temp. Meas. Device & S/N: _____ Time End: _____ HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Sagolay, MI
 Source Process RTD / Stack
 Test B Run 0 Date 7-25-96
 Stack Dimen. 26 IN.
 Dry Bulb 255 °F Wet bulb 100 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.45 IN.HG
 Static Pressure -.27 IN.WC
 Operators M. K. ... + D. ...
 Pitot No. TWST C, N/A



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	IN.	Time Start:	<u>NA</u> HRS
<u>1</u>	<u>1/6</u>	<u>12.67</u>	<u>16.67</u>		
<u>2</u>	<u>3/6</u>	<u>39.00</u>	<u>42.00</u>		
<u>3</u>	<u>5/6</u>	<u>62.33</u>	<u>67.33</u>		

Temp. Meas. Device & S/N: PDT-31/TZ Time End: NA HRS

R or nothing = reg. manometer; S = expanded; E = electronic

Calibration Error Check

Job L.P. / Sangola, MI

Test 2 Run 0 Date 7-22-76

Operator M. Kuehler

NO_x

SO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Mid Level					
Low Level High Level NO _x	91.9	93.2	1.3	250	.52

NO₂ Calibration:

Time (HRS) 1740

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	450	0
Mid Level	139.7	143.1	3.4	450	1.36
High Level	239	240	1	250	.40

O₂ Calibration:

Time (HRS) 0730

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0.0	0	25%	0
Mid Level	13.5	13.6	0.1	25%	.4
High Level	20.8	20.8	0	25%	0

CO₂ Calibration

Time (HRS) 0730

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0.0	0	20%	0
Mid Level	10.8	10.9	0.1	20%	.5
High Level	16.6	16.6	0	20%	0

CO Calibration

Time (HRS) 0730

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	1	1	1000	.1
Mid Level	289 300 ML	299	10	1000	1
High Level	620	620	0	1000	0

INTERPOLL LABORATORIES, INC

(612) 786-6020

System Bias Check

Job L.P. / Sasola, MN Source E Tube
 Test 2 Run 0 Date 7-22-98 Site Outlet
 Operator M. Kuehler

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
NOx	Zero Gas	0	0	0	0	100	0
	Upscale	91.9	93.2	92.1	1.1	100	1.1
O2	Zero Gas	0	0.2	0.2	0	25%	0
	Upscale	13.5	13.5	13.5	0	25%	0
CO2	Zero Gas	0	0.2	0.2	0	20%	0
	Upscale	10.8	10.9	10.8	0	20%	0
CO	Zero Gas	0	0	0	0	1000	0
	Upscale	620	609	612	3	1000	13
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

EPA Method 25 A

Calibration Error Check & Drift Determination

*Date logged
Checked*

(A.)

Job L.P. Sagola No. 1 Cyclone Outlet
 Test 0 Run 0 Date 7/22/96
 Operator Jwt

THC Calibration (Low Range):

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	100	0
Low Level	30.6	31.24	.64	100	.64
Mid Level	287	287	0	1000	0
High Level	2973	2952	20	10,000	.2

THC Calibration (High Range):

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Span					

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

CO₂ Calibration:

Time: (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

Must be within 2% of the span for each calibration gas.

052394-G:STACK\WP\FORMS\SS-420-14

INTERPOLL LABORATORIES, INC
(612) 786-6020

System Bias Check

Job L.P. Sagola Source No. 1 Cyclone Outlet
 Test 2 Run 0 Date 7/22/96 Site -11-
 Operator D. Van Hoever

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
Rattisch #2	Zero Gas	0	0	1	1	100	1
	Upscale	287	287	284	3	1000	.3
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

EPA Method 25 A

Calibration Error Check & Drift Determination

Job

L.P. Saigola No 1 Cyclone Outlet

Test

2

Run 0

Date 7/22/96

Operator

E. Van Hoever

(A2) MK

THC Calibration (Low Range):

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	100	0
Low Level	30.6	29.5	1.1	100	1.1
Mid Level	287	287	0	1000	0
High Level	2972	2973	1	1000	.01

THC Calibration (High Range):

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Span					

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

CO₂ Calibration:

Time: (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

Must be within 2% of the span for each calibration gas.

052394-G:\STACK\WPF\FORMS\S-420-14

INTERPOLL LABORATORIES, INC

(612) 786-6020

System Bias Check

Job L.P. Sagola Source No. 2 Cyclone
 Test 2 Run 1- Date 7/23, 24/96 Site Outlet
 Operator E. Van Hoever

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
Rattisch No. 2	Zero Gas	0	0	1	1	100	1
	Upscale	287	287	284	3	1000	.3
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

System Bias Check

Job L.P. Sagola
 Test 2 Run 1- Date _____
 Operator D. Van Hoever

Source No 3 Cyclone
 Site Outlet

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
	Zero Gas	0	9	.5	.5	100	.5
	Upscale	287	281	290	4	1000	.4
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

EPA Method 25 A
Calibration Error Check & Drift Determination

Job L.P. Saqola No 3 Cyclone Outlet A3
 Test 2 Run 0 Date 07/22/96
 Operator D. Van Heuver

THC Calibration (Low Range):

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	100	0
Low Level	30.6	30.7	.1	100	.1
Mid Level	287	286	1	1000	.1
High Level	2972	3083	111	1000	1.11

THC Calibration (High Range):

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Span					

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

CO₂ Calibration:

Time: (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

Must be within 2% of the span for each calibration gas.

Calibration Error Check

Job LP. / SAGULA
 Test 2 Run 0 Date 7-23-96
 Operator S. OARVILLE

TML
SO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	1,000	0
Low Level	30	30	0	100	0
Mid Level	285	282	3	1,000	0.3%
High Level	2960	2960	0	10,000	0

NO_x Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	250	0
Mid Level	90.6	90.6	0	250	0
High Level	143	148	5	250	2%

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM) %	Percent of Span
Zero Gas	0	0	0	25	0
Mid Level	13.5	13.5	0	25	0
High Level	21	21	0	25	0

CO₂ Calibration

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM) %	Percent of Span
Zero Gas	0	0	0	20	0
Mid Level	10.8	10.8	0	20	0
High Level	16.8	17.2	.4	20	2%

CO Calibration

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	1000	0
Mid Level	147	147	0	1000	0
High Level	:	292	10	1000	1.0%

System Bias Check

Job LP / SAGOLTA Source DMYEN RIO
 Test 2 Run 0 Date 7-23-96 Site STACK
 Operator S. HARTWELL

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
THL	Zero Gas	0	0	0	0	100	0
	Upscale	30	30	30	0	100	0
CO	Zero Gas	0	0	1	1	500	0
	Upscale	147	147	148	1	500	.28
NOX	Zero Gas	0	0	1	1	100	218
	Upscale	90.6	90.6	90.6	0	100	0
O ₂	Zero Gas	0	0	.1	.1	25%	.48
	Upscale	13.5	13.5	13.5	0	25%	0
CO ₂	Zero Gas	0	0	0	0	20%	0
	Upscale	10.8	10.8	10.6	.2	20%	18
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within ~~3%~~ of the span for the zero or upscale cal. gas.

3%

EPA Method 6C/7E Response Time

Job LP/SAGULAS Technician S. BATHURLE
 Source DYER LTO STACK System Flow Rate 1 l/min
 Date of Test 7-23-96

Moisture removal: Via Model MK-1 Condenser

Analyzer Type	Response Time (secs)		
	SO ₂ /NO _x	O ₂	CO ₂
Analyzer S/N			
Analyzer Range			
High Level Span Gas Conc. (PPM or %)			
Upscale 1			
Upscale 2			
Upscale 3			
Average			
Downscale 1			
Downscale 2			
Downscale 3			
Average			


System response time 60 seconds

1. Introduce gases at the 3-way valve on the probe. Use zero and stack gas for the upscale tests and high-level span gas and stack gas for the downscale tests. Alternatively, use zero and high-level gases for a more stringent test. Record the time in seconds from the moment of introduction until a stable response is achieved.
2. The response time test need only be conducted prior to the initial field use of the measurement system.
3. Attach a copy of the flow system schematic to this test.

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP 5A602A
 Source PRESS RJO INLET
 Test 6 Run 0 Date 9-25-96
 Stack Dimen. 57.25 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure _____ IN.HG
 Static Pressure _____ IN.WC
 Operators 3B IMP
 Pitot No. C_p
A = 260 B = 11A



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>3.75</u> IN.	Time Start: _____ HRS		
1	.16	9.16	12.91		
2	.50	28.62	32.37		
3	.83	47.52	51.27		
Temp. Meas. Device & S/N:				Time End:	HRS

THC Cal Drift Check

Job L.P. Sagola Source No. 1 Cyclone
 Test 2 Run 1-6 Date 7/23, 24/96 Site Outlet
 Operator E. Van Hoever Channel 3 ML

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C ₂₅
				Initial	Final			
1		Zero Gas	0	1	-10		██████	
		Upscale	287	284	110	██████		
2 2/L	665.39	Zero Gas	0	1	8.6	4.8	██████	645.52
		Upscale	287	287	310	██████	298.5	
3 2/3	580.81	Zero Gas	0	0	2.4	1.2	██████	598.81
		Upscale	287	288	270	██████	279	
4 2/4	547.44	Zero Gas	0	2.4	7.65	5.025	██████	559.02
		Upscale	287	287	280	██████	283.5	
5		Zero Gas	0	0	10		██████	
		Upscale	287	287	297	██████		
6		Zero Gas	0	1.8	10.8		██████	
		Upscale	287	287	283	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

THC's Cal Drift Check

Job L.P. Sagola Source No. 2 Cyclone
 Test 2 Run 1-6 Date 7/23, 24/86 Site Outlet
 Operator D. Van Hoever Channel 2 Channel 2

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	1	10.3		██████	
		Upscale	287	284	260	██████		
2 2/2	705.39 665.79 ML	Zero Gas	0	1	5.5	3.25	██████	
		Upscale	287	283	282	██████	202.5	721.63
3 2/3	694.91	Zero Gas	0	1	4	2.5	██████	
		Upscale	287	284	282	██████	203	709.46
4 2/4	506.96	Zero Gas	0	1	4	2.5	██████	
		Upscale	287	282	270	██████	276	613.31
5		Zero Gas	0	2	1.8		██████	
		Upscale	287	287	290	██████		
6		Zero Gas	0	0	1		██████	
		Upscale	287	290	286	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

THC's Cal Drift Check

Job L.P. Sayola Source NO 3 Cyclone Outlet
 Test 2 Run 1-6 Date 7/23, 24/96 Site _____
 Operator D. Van Hoover Channel 1 MC

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	1	10		██████	
		Upscale	287	287	300	██████		
2 2/2	1124.07 H25 MK	Zero Gas	0	2	1	1.5	██████	
		Upscale	287	287	269	██████	276	1166.03
3 2/3	944.41	Zero Gas	0	0	10	5	██████	
		Upscale	287	287	290	██████	203.5	865.03
4 2/4	1143.93	Zero Gas	0	0	0	0	██████	
		Upscale	287	293	284	██████	203.5	1158.05
5		Zero Gas	0	0	0		██████	
		Upscale	287	284	299	██████		
6		Zero Gas	0	0	6.3		██████	
		Upscale	287	286	283	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

*Jim Jordan
Phoenix Inst*

INTERPOL LABORATORIES, INC
 (612) 786-6020
THL Cal Drift Check

Job LP SAGOLA Source DNYENRTO
 Test 2 Run Date 7-23-96 Site STACK
 Operator S.O. / M.P.

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1		Zero Gas	0	0	0	0	██████	
		Upscale	30	30	28	██████	29	
2 <i>Hood</i>	27.37	Zero Gas	0	0	0	0	██████	28.81
		Upscale	30	30	27	██████	28.5	
3 <i>Hood</i>	12.36	Zero Gas	0	0	1	-5	██████	12.27
		Upscale	30	30	29	██████		
4 <i>Hood</i>	22.21	Zero Gas	0	0	2	1	██████	23.14
		Upscale	30	30	27	██████	28.5	
5		Zero Gas	0	0	0	0	██████	
		Upscale	30	30	28	██████	28.5	
6		Zero Gas	0	0	0	0	██████	
		Upscale	30	30	31	██████	30.5	
7		Zero Gas	0				██████	
		Upscale					██████	
8		Zero Gas	0				██████	
		Upscale					██████	
9		Zero Gas	0				██████	
		Upscale					██████	
10		Zero Gas	0				██████	
		Upscale					██████	
11		Zero Gas	0				██████	
		Upscale					██████	
12		Zero Gas	0				██████	
		Upscale					██████	

Must be within 5% of the span for the zero or upscale cal. gas.

BAD 30 min Run 1 DVH
BAD 30 min Run 2 JB
BAD 10 min Run 3
Run without flow
2 PFLC NAMES XLS XLA

*Run 6 2 PFLC NAMES LPSATARK. XLS 1st 1/2 Hour
 XLA 2nd 3/4 Hour*

INTERPOLL LABORATORIES, INC

(612) 786-6020

THL Cal Drift Check

Job

LP 50606A

Source

PRESS RTO

Test

0

Run

Date

7-25-96

Site

INLET

Operator

S. BARRON / M. POTTS

620
720
800
900
935
935
035
2100
145

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C _{sp}
				Initial	Final			
1	233.39	Zero Gas	0	0	0	0	██████	235.04
		Upscale	285	285	281	██████	283	
2	255.70	Zero Gas	0	0	1	.5	██████	254.75
		Upscale	285	285	287	██████	286	
3	252.27	Zero Gas	0	0	0	0	██████	248.35
		Upscale	285	287	292	██████	289.5	
4		Zero Gas	0	0			██████	
		Upscale	285	285		██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

THC Cal Drift Check

Job L.P. / Sagola, MI
 Test 8 Run 1, 2, 3 Date 2-25-96
 Operator M. Kuehler

Source Press RTD
 Site Stack

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₉₅
				Initial	Final			
1 8/11	6.30	Zero Gas	0	0.4	0.0	0.2	██████	6.30
		Upscale	30.4	20.7	29.6	██████	29.65	
2 8/12	8.45 6.30 MK	Zero Gas	0	0.0	20.0	0.0	██████	8.81
		Upscale	30.4	MK 29.5 28.8	28.8	██████	29.15	
3 8/13	5.11	Zero Gas	0	0.0	1.5	0.75	██████	4.59
		Upscale	30.4	30.0	29.2	██████	29.6	
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

NOx Cal Drift Check

Job L.P. / Sasola, MI Source 'E' Tube
 Test 2 Run 1, 2, 3 Date 7-23-96 Site Outlet
 Operator M. Kaehler

1230
1330
1435
1535
1645
1745
1925
2025
2115
2215
(7-24-96)
130 →
230

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _s	C _m	C _{gas}
				Initial	Final			
1 2/1	2.18	Zero Gas	0	0.2	0.9	0.55	██████	
		Upscale	91.9	92.5	91.7	██████	92.1	
2 2/2	4.26	Zero Gas	0	0.9	1.3	1.1	██████	3.18
		Upscale	91.9	91.7	92.9	██████	92.3	
3 2/3	3.66	Zero Gas	0	1.3	1.3	1.3	██████	2.37
		Upscale	91.9	92.9	92.5	██████	92.7	
4 2/4	2.53	Zero Gas	0	1.3	.4	0.05	██████	1.69
		Upscale	91.9	92.5	92.0	██████	92.25	
5 2/5	2.53	Zero Gas	0	.4	.5	0.45	██████	2.08
		Upscale	91.9	92.0	92.4	██████	92.2	
6 2/6	8.13	Zero Gas	0	0.0	1.2	0.6	██████	7.60
		Upscale	91.9	91.8	91.7	██████	91.75	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

NOX Cal Drift Check

Job LP / SAGOLA Source DNYER R TO
 Test 2 Run Date 7-23-96 Site STACK
 Operator SB / MP

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0	1	-5	██████	
		Upscale	90.6	90.6	90.6	██████	90.6	
2	3.46	Zero Gas	0	1	0	1	██████	2.49
		Upscale	90.6	90.6	90.6	██████	90.6	
3	3.79	Zero Gas	0	1	1	1	██████	2.82
		Upscale	90.6	90.6	90.6	██████	90.6	
4	3.23	Zero Gas	0	1	-1	0	██████	3.23
		Upscale	90.6	90.6	90.6	██████	90.6	
5		Zero Gas	0	-1	-2	-1	██████	
		Upscale	90.6	90.6	90.6	██████	90.6	
6		Zero Gas	0	0	0	0	██████	
		Upscale	90.6	90.6	89.6	██████	90.1	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

NOF Cal Drift Check

Job CP / STAGOLA

Source PROCESS INTO

Test 8 Run Date 7-25-96

Site INLET

Operator SB / MP

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{pa}
				Initial	Final			
1	9.10	Zero Gas	0	0	2	1	██████	8.16
		Upscale	90.6	90.6	93	██████	91.8	
2	8.10	Zero Gas	0	0	1	.5	██████	7.64
		Upscale	90.6	90.6	90.6	██████	90.6	
3	7.16	Zero Gas	0	1	1	1	██████	6.16
		Upscale	90.6	90.6	92.6	██████	91.6	
4		Zero Gas	0	1			██████	
		Upscale	90.6	90.6		██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

NO_x Cal Drift Check

Job hwp / Sagola, MI Source Press RFD
 Test 8 Run 1, 2, 3 Date 7-25-96 Site Stack
 Operator Mickael

1640
1700
1800
1900
1435
2035

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1 8/1	36.43	Zero Gas	0	0.2	0.2	0.2	██████	36.31
		Upscale	91.9	91.4	92.4	██████	91.9	
2 8/2	34.51	Zero Gas	0	0.2	-0.1	0.05	██████	34.27
		Upscale	91.9	92.4	92.5	██████	92.45	
3 8/3	34.88	Zero Gas	0	-0.1	-0.6	-0.35	██████	34.91
		Upscale	91.9	92.5	92.3	██████	92.4	
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

C.O Cal Drift Check

Job L.P. / Sasola, MI Source E Tube
 Test 2 Run 2, 3 Date 7-13-76 Site Outlet
 Operator M. Kaelbler

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1 2/11	1697	Zero Gas	0	2	-3	-0.5	██████	
		Upscale	620	615	603	██████	609	
2 2/12	1805	Zero Gas	0	-1	3	1	██████	1817
		Upscale	620	616	617	██████	616.5	
3 2/13	1824	Zero Gas	0	3	1	2	██████	1841
		Upscale	620	617	614	██████	615.5	
4 2/14	1829	Zero Gas	0	1	0	0.5	██████	1851
		Upscale	620	614	612	██████	613	
5 2/15	1739 1739	Zero Gas	0	0	0	0	██████	
		Upscale	620	612	610	██████	611	
6 2/16	1750	Zero Gas	0	1	2	1.5	██████	
		Upscale	620	610	616	██████	613	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

CO Cal Drift Check

Job LP SAGULA Source DATEN RTU
 Test 2 Run Date 7-23-96 Site STACK
 Operator S.D. / MP

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C _{sp}
				Initial	Final			
1		Zero Gas	0	0	2	1	██████	
		Upscale	147	147	147	██████	147	
2	210.73	Zero Gas	0	2	0	1	██████	212
		Upscale	147	147	146	██████	146.5	
3	232.69	Zero Gas	0	0	0	0	██████	234
		Upscale	147	146	146	██████	146	
4	242.44	Zero Gas	0	0	0	0	██████	241
		Upscale	147	146	150	██████	148	
5		Zero Gas	0	0	3	1.5	██████	
		Upscale	147	150	150	██████	150	
6		Zero Gas	0	0	2	1	██████	
		Upscale	147	147	146	██████	146.5	
7		Zero Gas	0				██████	
		Upscale					██████	
8		Zero Gas	0				██████	
		Upscale					██████	
9		Zero Gas	0				██████	
		Upscale					██████	
10		Zero Gas	0				██████	
		Upscale					██████	
11		Zero Gas	0				██████	
		Upscale					██████	
12		Zero Gas	0				██████	
		Upscale					██████	

DATA LOG ON 2nd 14. MAY WAS WITH RAYS & STRIP CHART 7

CR T 1000

Must be within 3% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

CO Cal Drift Check

Job
Test
Operator

LP/SABGOLA
8 Run 3D. 1 MP. Date 7-25-96

Source PHOS MTO
Site INLET

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{ps}
				Initial	Final			
1	5.01	Zero Gas	0	0	0	0	██████	5.04
		Upscale	147	147	145	██████	146	
2	5.23	Zero Gas	0	0	0	0	██████	5.32
		Upscale	147	145	144	██████	144.5	
3	4.38	Zero Gas	0	0	0	0	██████	4.39
		Upscale	147	144	145	██████	144.5	
4		Zero Gas	0	0			██████	
		Upscale	147	145		██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

CO Cal Drift Check

Job

L.P. / Sagola, MI

Source

PPG, LTD

Test

6 Run 1, 2, 3

Date 2-25-96

Site

Stack

Operator

M. Kuebler

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C _{gas}
				Initial	Final			
1 0/1	18.89	Zero Gas	0	0.0	0.0	0.0	██████	19.21
		Upscale	143.3	141.5	140.2	██████	140.05	
2 0/2	23.37	Zero Gas	0	0.0	-0.6	-0.3	██████	24.18
		Upscale	143.3	140.2	139.8	██████	140.0	
3 0/3	19.73	Zero Gas	0	-0.6	-0.6 -0.6	-0.6	██████	20.76
		Upscale	143.3	139.8	139.6	██████	139.7	
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

O₂ Cal Drift Check

Job i.P. / Sagala, MI
 Test 2 Run 1,2,3 Date 7.23.86
 Operator M. Kaehler

Source 'E' Tube
 Site Outlet

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1 2/1	17.49	Zero Gas	0	0.0	0.0	0.0	██████	
		Upscale	13.5	13.5	13.6	██████	13.55	
2 2/2	17.38	Zero Gas	0	0.0	0.0	0.0	██████	17.44
		Upscale	13.5	13.5	13.4	██████	13.45	
3 2/3	17.29	Zero Gas	0	0.0	0.0	0.0	██████	17.42
		Upscale	13.5	13.4	13.4	██████	13.4	
4 2/4	17.34	Zero Gas	0	0.0	0.0	0.0	██████	17.47
		Upscale	13.5	13.4	13.4	██████	13.4	
5 2/5	17.62	Zero Gas	0	0.0	0.0	0.0	██████	
		Upscale	13.5	13.4	13.4	██████	13.4	
6 2/6	17.48	Zero Gas	0	0.0	0.0	0.0	██████	
		Upscale	13.5	13.5	13.4	██████	13.45	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

02 Cal Drift Check

Job LP SAGOLA Source LP SAGOLA DEPT BTD
 Test 2 Run Date 7-23-96 Site STACK
 Operator S.D. IMP

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1		Zero Gas	0	0	-1	-0.05	██████	
		Upscale	13.5	13.5	13.5	██████	13.5	
2	16.95	Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.5	██████	13.5	16.95
3	16.98	Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.6	██████	13.55	16.92
4	16.54	Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.5	██████	13.5	16.54
5		Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.4	██████	13.45	
6		Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.6	██████	13.55	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

O₂ Cal Drift Check

Job
Test
Operator

LP/SABOLO
B Run Date 7-25-96
S.D. / M.P.

Source
Site

PNSS RTU
INLET

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	20.9	Zero Gas	0	0	0	0	██████	20.9
		Upscale	13.5	13.5	13.5	██████	13.5	
2	20.9	Zero Gas	0	0	0	0	██████	20.9
		Upscale	13.5	13.5	13.5	██████	13.5	
3	20.9	Zero Gas	0	0	.1	.05	██████	20.9
		Upscale	13.5	13.5	13.5	██████	13.5	
4		Zero Gas	0	.1			██████	
		Upscale	13.5	13.5		██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

CO2 Cal Drift Check

Job L.P. / Sapola, MI Source E Tube
 Test 2 Run 0 Date 7-23-96 Site Outlet
 Operator M. Kuebler

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1 2/1	2.95	Zero Gas	0	0.1	0.0	0.05	██████	
		Upscale	10.8	10.8	10.8	██████	10.8	
2 2/2	3.17	Zero Gas	0	0.0	0.2	0.1	██████	3.08
		Upscale	10.8	10.8	10.9	██████	10.85	
3 2/3	3.12	Zero Gas	0	0.2	0.2	0.2	██████	2.95
		Upscale	10.8	10.9	10.9	██████	10.9	
4 2/4	3.05	Zero Gas	0	0.2	0.2	0.2	██████	2.89
		Upscale	10.8	10.9	10.8	██████	10.85	
5 4/5	2.89	Zero Gas	0	0.2	0.1	0.15	██████	
		Upscale	10.8	10.8	10.8	██████	10.8	
6 2/6	3.14	Zero Gas	0	0.0	0.2	0.1	██████	
		Upscale	10.8	10.9	10.8	██████	10.85	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

CO Cal Drift Check

Job LP ISAGOLA Source DMYER RD
 Test 2 Run Date 7-23-76 Site STACK
 Operator S.O. / M.P.

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gs}
				Initial	Final			
1		Zero Gas	0	0	0	0	██████	
		Upscale	10.8	10.8	10.8	██████	10.8	
2	3.44	Zero Gas	0	0	0	0	██████	3.44
		Upscale	10.8	10.8	10.8	██████	10.8	
3	3.44	Zero Gas	0	0	0	0	██████	3.44
		Upscale	10.8	10.8	10.7	██████	10.75	
4	3.37	Zero Gas	0	0	0	0	██████	3.39
		Upscale	10.8	10.8	10.7	██████	10.75	
5		Zero Gas	0	0	0	0	██████	
		Upscale	10.8	10.8	10.7	██████	10.75	
6		Zero Gas	0	0	0	0	██████	
		Upscale	10.8	10.8	10.8	██████	10.8	
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

CO₂ ~~LEAK~~ Cal Drift Check

Job LP SAGOLA Source Process RTU
 Test 8 Run Date 7-25-76 Site F-65
 Operator SD. / MP.

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C ₂₅
				Initial	Final			
1	0	Zero Gas	0	0	0	0	10.4	0
		Upscale	10.4	10.4	10.4	10.4	10.4	
2	0	Zero Gas	0	0	0	0	10.4	0
		Upscale	10.4	10.4	10.4	10.4	10.4	
3	0	Zero Gas	0	0	0	0	10.4	0
		Upscale	10.4	10.4	10.4	10.4	10.4	
4		Zero Gas	0	0			10.4	
		Upscale	10.4	10.4		10.4		
5		Zero Gas	0				10.4	
		Upscale				10.4		
6		Zero Gas	0				10.4	
		Upscale				10.4		
7		Zero Gas	0				10.4	
		Upscale				10.4		
8		Zero Gas	0				10.4	
		Upscale				10.4		
9		Zero Gas	0				10.4	
		Upscale				10.4		
10		Zero Gas	0				10.4	
		Upscale				10.4		
11		Zero Gas	0				10.4	
		Upscale				10.4		
12		Zero Gas	0				10.4	
		Upscale				10.4		

Must be within 5% of the span for the zero or upscale cal. gas.

APPENDIX H

CALIBRATION GAS CERTIFICATION SHEETS



NATIONAL SPECIALTY GASES
 630 UNITED DRIVE
 DURHAM, NC 27713
 (919)544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-40607 CYLINDER #:CC46348 CYL. PRESSURE:2000PSIG
 EXPIRATION DATE: 6/2/98 LAST ANALYSIS DATE:6/2/95
 CUSTOMER: TWIN CITY OXYGEN P.O.# 17405

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION
 OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993:G-1.
 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0
 MEGAPASCALS (150 PSIG).

STANDARD: INSTRUMENT:BECKMAN NDIR BECKMAN PARAMAGNETIC
 SRM #: 1675B 2659A MODEL #:880 755
 CYL #: CLM6413 CLM6737 SERIAL #:2000418 1001419
 CONC.: 14.01% 20.72% LAST CAL.:5/22/95 6/1/95

COMPONENT:CO2	COMPONENT: O2	COMPONENT:
MEAN CONC:16.8%	MEAN CONC: 21.0%	MEAN CONC:
REPLICATE CONC.	REPLICATE CONC.	REPLICATE CONC.
DATE:6/2/95 DATE:	DATE:6/2/95 DATE:	DATE: DATE:
16.8%	21.0%	
16.8%	21.0%	
16.9%	21.1%	

BALANCE GAS:N2

REPLICATE DATA

DATE: 6/2/95
 Z 0 R 168.0 C 201.5
 R 168.5 Z 0 C 202.1
 Z 0 C 203.9 R 169.0

COMPONENT:CO2

DATE:
 Z R C
 R Z C
 Z C R

REPLICATE DATA

DATE: 6/2/95
 Z 0 R 210.0 C 212.8
 R 210.5 Z 0 C 213.0
 Z 0 C 214.9 R 211.0

COMPONENT:O2

DATE:
 Z R C
 R Z C
 Z C R

REPLICATE DATA

DATE:
 Z R C
 R Z C
 Z C R

COMPONENT:

DATE:
 Z R C
 R Z C
 Z C R

Z=ZERO C=CANDIDATE R=REFERENCE

ANALYST: *Mary A. Savage*

APPROVED BY: *Jana Rowe*

THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE.

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #:	88-16474	CYLINDER #:	CC 35931	CYL. PRESSURE:	2000 PSIG	P.O. #:	27209
EXP. DATE:	3/14/96	LAST ANALYSIS DATE:	3/14/96	CUSTOMER:	TWIN CITY OXYGEN		
METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993.0-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG).							
COMPONENT: CARBON DIOXIDE		COMPONENT: OXYGEN		COMPONENT:			
STANDARD		STANDARD		STANDARD			
SRM #:	1675B	SRM #:	2659A	SRM #:		SRM #:	
CYL #:	CLM 6481	CYL #:	CLM 6737	CYL #:		CYL #:	
CONC:	14.01 %	CONC:	20.72 %	CONC:		CONC:	
INSTRUMENT: ROSEMOUNT NDIR		INSTRUMENT: BECKMAN PARAMAGNETIC		INSTRUMENT:			
MODEL #:	880	MODEL #:	755	MODEL #:		MODEL #:	
SERIAL #:	2000418	SERIAL #:	1001419	SERIAL #:		SERIAL #:	
LAST CAL:	2/20/96	LAST CAL:	3/1/96	LAST CAL:		LAST CAL:	
MEAN CONC:	10.8% +/-	MEAN CONC:	13.3% +/-	MEAN CONC:	0.11 %	MEAN CONC:	
REPLICATE CONC.		REPLICATE CONC.		REPLICATE CONC.		REPLICATE CONC.	
DATE: 3/14/96		DATE: 3/14/96		DATE:		DATE:	
10.8 %		13.5 %					
10.9 %		13.4 %					
10.8 %		13.5 %					

BALANCE GAS: NITROGEN

REPLICATE DATA		REPLICATE DATA		REPLICATE DATA	
DATE: 3/14/96		DATE: 3/14/96		DATE:	
Z 0	R 14.1	Z 0	R 400.2	Z	R
R 14.1	Z 0	R 400.3	Z 0	R	Z
Z 0	C 10.9	Z 0	C 260.9	Z	C
	C 11.0		R 400.4		R
	R 14.0				R
DATE		DATE:		DATE:	
Z	R	Z	R	Z	R
R	Z	R	Z	R	Z
Z	C	Z	C	Z	C

ANALYST: *John McK...* Z= ZERO C=CANDIDATE R=REFERENCE APPROVED BY: *Laura...*

THIS LABORATORY ACCEPTS ONLY THE RESULTS OF THE OPERATIONS TO BE PERFORMED BY THIS LABORATORY. THE RESULTS OF THIS ANALYSIS ARE VALID ONLY IF THE SAMPLE IS ANALYZED IN ACCORDANCE WITH THE EPA'S TEST METHOD. NATIONAL SPECIALTY GASES SHALL HAVE SOLE LIABILITY IN EXCESS OF ITS ESTABLISHED CAPACITY FOR THE ANALYSIS. ANALYZED AT: NATIONAL SPECIALTY GASES 630 UNITED DRIVE, DURHAM, NC 27713. (919)544-3772

uc em. s, c.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer: AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes: Order No: CSS-188055-01
Batch No: 861-26103

Cylinder No: SG9150306BAL
Cylinder Pressure*: 2000 psig
Certification Date: 06/13/95
Expiration Date: 06/13/98

PO: Rel: ***** Reference Standards ***** Analytical Instrumentation *****
Certified Instrument Serial Last Measurement
Concentration Cylinder # Concentration Make/Model Number Calibration Principal
CARBON MONOXIDE 147 ±0.4 PPM SG9113611BAL GMIS 151.5000 PPM Horiba VIA-510 405079 05/20/95 INFRARED HORIBA

Balance Gas: Nitrogen

* Standard should not be used below 150 psig

Analyst: Shaher Aboor
Shaher Aboor

Approved By: Robert McNear
Robert McNear

Shipped From : Scott Michigan
 Our Project # : 542740
 Your P.O. # : 40643
 Expiration Date : 4-19-94
 Cylinder Number : ALM011467

Customer : GENEX
 2455 CLEVELAND AVENUE
 ROSEVILLE MN 55113

*** CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES ***
 PERFORMED ACCORDING TO SECTION 3.0.4

Certified Accuracy 1 % NIST Traceable
 LAB # 5302
 Certification Date : 10-19-92
 1 of 1 Component(s)

Cylinder Pressure : 1900 psig
 Procedure # 61
 Protocol # 1
 Instrumentation
 Instrument/Model/Serial # : BECKMAN 867
 Last Calibration Date : 10-14-92
 Analytical Principle : NON-DISPERSIVE INFRARED

ANALYZED	CYLINDER	CERTIFIED CONCENTRATION	SRM # (CRM #)	CYLINDER NUMBER	CONCENTRATION	INSTRUMENT/MODEL/SERIAL #	LAST CALIBRATION DATE
CARBON MONOXIDE	282.3 PPM	282.3 PPM	1680	AAL16199	475.0 PPM	BECKMAN 867	10-14-92
			2636	ALM013383	243.4 PPM		
			1679	AAL1355	96.67 PPM		

FIRST ANALYSIS				SECOND ANALYSIS				DATE : 10-19-92							
ZERO GAS	TEST GAS (PPM)	CURVE RESULTS (PPM)	REFERENCE GAS CONCENTR.	ZERO GAS (PPM)	TEST GAS (PPM)	CURVE RESULTS (PPM)	REFERENCE GAS CONCENTR.	ZERO GAS (PPM)	TEST GAS (PPM)	CURVE RESULTS (PPM)	REFERENCE GAS CONCENTR.	ZERO GAS (PPM)	TEST GAS (PPM)	CURVE RESULTS (PPM)	REFERENCE GAS CONCENTR.
0.00	65.20	282.3	100.0	0.00	65.20	282.3	100.0	0.00	65.20	282.3	100.0	0.00	65.20	282.3	100.0
0.00	65.20	282.3	475.0 PPM	0.00	65.20	282.3	475.0	0.00	65.20	282.3	475.0	0.00	65.20	282.3	475.0
CALCULATED RESULTS				CALCULATED RESULTS				CALCULATED RESULTS				CALCULATED RESULTS			
282.3				282.3				282.3				282.3			
AVERAGE : 282.3 PPM				AVERAGE : 282.3 PPM				AVERAGE : 282.3 PPM				AVERAGE : 282.3 PPM			

ANALYST : *[Signature]* Approved By : *[Signature]*
 * GMS - GAS MANUFACTURER'S INTERNAL STANDARD
 Revised : 3/31/92 RNL

Certificate of Analysis for Standard Gas

Vendor Air Products
Cylinder No. 50 916 2775
Date of Preparation 11-9-95
Label Nitric Oxide
Blend Specification 145 ppm Nitrogen N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run	NO	
4-5-96	1	143.3031	
4-5-96	2	142.8554	
4-5-96	3	142.9570	
	4		
	5		
	6		
	Avg	143.0385	-1.3550

Analyst Boz A

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: April 5, 1996
Approved by: [Signature]

INTERPOLL LABS

TANK CERT
TANK NUMBER SG9162775
4/5/96

4/5/96	12:29:00 PM			
0	144.809	0	0	0
4/5/96	12:29:06 PM			
0	144.809	0	0	0
4/5/96	12:29:12 PM			
0	144.809	0	0	0
4/5/96	12:29:18 PM			
0	143.995	0	0	0
4/5/96	12:29:24 PM			
0	143.588	0	0	0
4/5/96	12:29:30 PM			
0	143.181	0	0	0
4/5/96	12:29:36 PM			
0	143.995	0	0	0
4/5/96	12:29:42 PM			
0	143.181	0	0	0
4/5/96	12:29:48 PM			
0	143.588	0	0	0
4/5/96	12:29:54 PM			
0	142.774	0	0	0
4/5/96	12:30:00 PM			
0	143.588	0	0	0
4/5/96	12:30:06 PM			
0	142.774	0	0	0
4/5/96	12:30:12 PM			
0	142.367	0	0	0
4/5/96	12:30:18 PM			
0	142.774	0	0	0
4/5/96	12:30:24 PM			
0	142.774	0	0	0
4/5/96	12:30:30 PM			
0	142.774	0	0	0
4/5/96	12:30:36 PM			
0	142.367	0	0	0
4/5/96	12:30:42 PM			
0	143.181	0	0	0
4/5/96	12:30:48 PM			
0	142.367	0	0	0
4/5/96	12:30:54 PM			
0	142.367	0	0	0

143.3031

INTERPOLL LABS

TANK CERT
 TANK NUMBER SG9162775
 4/5/96

4/5/96	12:36:00 PM			
0	144.402	0	0	0
4/5/96	12:36:06 PM			
0	144.809	0	0	0
4/5/96	12:36:12 PM			
0	143.181	0	0	0
4/5/96	12:36:18 PM			
0	143.588	0	0	0
4/5/96	12:36:24 PM			
0	143.181	0	0	0
4/5/96	12:36:30 PM			
0	142.367	0	0	0
4/5/96	12:36:36 PM			
0	142.367	0	0	0
4/5/96	12:36:42 PM			
0	142.774	0	0	0
4/5/96	12:36:48 PM			
0	143.181	0	0	0
4/5/96	12:36:54 PM			
0	142.367	0	0	0
4/5/96	12:37:00 PM			
0	143.181	0	0	0
4/5/96	12:37:06 PM			
0	142.367	0	0	0
4/5/96	12:37:12 PM			
0	142.367	0	0	0
4/5/96	12:37:18 PM			
0	142.367	0	0	0
4/5/96	12:37:24 PM			
0	142.367	0	0	0
4/5/96	12:37:30 PM			
0	142.367	0	0	0
4/5/96	12:37:36 PM			
0	142.367	0	0	0
4/5/96	12:37:42 PM			
0	141.96	0	0	0
4/5/96	12:37:48 PM			
0	142.774	0	0	0
4/5/96	12:37:54 PM			
0	142.774	0	0	0

142.8554

INTERPOL LABS

TANK CERT
 TANK NUMBER SG9162775
 4/5/96

4/5/96	12:42:00 PM			
0	144.809	0	0	0
4/5/96	12:42:06 PM			
0	144.402	0	0	0
4/5/96	12:42:12 PM			
0	143.995	0	0	0
4/5/96	12:42:18 PM			
0	143.181	0	0	0
4/5/96	12:42:24 PM			
0	143.588	0	0	0
4/5/96	12:42:30 PM			
0	143.995	0	0	0
4/5/96	12:42:36 PM			
0	142.774	0	0	0
4/5/96	12:42:42 PM			
0	143.181	0	0	0
4/5/96	12:42:48 PM			
0	142.367	0	0	0
4/5/96	12:42:54 PM			
0	142.774	0	0	0
4/5/96	12:43:00 PM			
0	142.367	0	0	0
4/5/96	12:43:06 PM			
0	141.96	0	0	0
4/5/96	12:43:12 PM			
0	143.181	0	0	0
4/5/96	12:43:18 PM			
0	142.774	0	0	0
4/5/96	12:43:24 PM			
0	142.367	0	0	0
4/5/96	12:43:30 PM			
0	142.367	0	0	0
4/5/96	12:43:36 PM			
0	142.367	0	0	0
4/5/96	12:43:42 PM			
0	142.367	0	0	0
4/5/96	12:43:48 PM			
0	141.96	0	0	0
4/5/96	12:43:54 PM			
0	142.367	0	0	0

142.95715

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer: TWIN CITY OXYGEN (MAIN ACCT.) Notes:

305 2ND STREET NW MN 55112- NEW BRIGHTON

Order No: CSS-296700-01

Batch No: 861-28757

Cylinder No: SG9162775BAL
Cylinder Pressure*: 2000 psig
Certification Date: 11/09/95
Expiration Date: 11/09/97

PO: 20013 Rel: *** Certified Concentration *** Reference Standards ***** Analytical Instrumentation *****
Certified Instrument Serial Last Measurement
Concentration Make/Model Number Calibration Principal
145 ±1.0 PPM SG9151688BAL GMIS 145.5000 PPM Rosemount: 951a 0101877 10/19/95 CHEMILUMINESCENCE

Balance Gas: NITROGEN

Contaminant

Nitrogen Dioxide 1.80 PPM

* Standard should not be used below 150 psig

Analyst: Shaher Aboor
Shaher Aboor

Approved By: Richard Fry
Richard Fry

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard


Customer: AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379


Notes:

Order No: CSS-411663-0
Batch No: 861-31683
Cylinder No: SG913604IBAL
Cylinder Pressure*: 2000 psig
Certification Date: 04/29/96
Expiration Date: 04/29/98
PO: Rel: ***** Analytical Instrumentation *****
*** Certified Concentration *** Reference Standards *****
Certified Standard Instrument Serial Last Measurement
Concentration Cylinder # Number Make/Model Number Calibration Principal
NITRIC OXIDE 90.6 ±.27 PPM SG9148169BAL GMIS 96.0200 PPM Rosemount 951a 0101877 04/19/96 CHEMILUMINESCENCE

Balance Gas: NITROGEN
Contaminant Nitrogen Dioxide .400 PPM

* Standard should not be used below 150 psig

Analyst: 
James Laas

Approved By: 
Richard Fry

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-41643
 EXPIRATION DATE: 7/25/98
 METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993:G-1.
 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (160PSIG).

CYLINDER #: CC46326
 LAST ANALYSIS DATE: 7/25/95
 CUSTOMER:TWIN CITY
 P.O.#:SHELIA

STANDARD:
 SRM #: 1667B
 CYL. #: CLM5293
 CONC.: 47.3PPM
 INSTRUMENT:ROSEMOUNT THC
 MODEL#:400A
 SERIAL #:2000335
 LAST CAL.:7/14/95

COMPONENT:PROPANE
 MEAN CONC:30.5 + 0.31PPM
 REPLICATE CONC.
 DATE:7/25/95 DATE:
 30.5PPM
 30.5PPM
 30.6PPM

BALANCE GAS:AIR

COMPONENT:PROPANE	COMPONENT:	COMPONENT:
REPLICATE DATA	REPLICATE DATA	REPLICATE DATA
DATE: 7/25/95	DATE:	DATE:
Z 0 R 47.3 C 30.5	Z R C	Z R C
R 47.3 Z 0 C 30.5	R Z C	R Z C
Z 0 C 30.6 R 47.3	Z Z C	Z R C
DATE:	DATE:	DATE:
Z R C	Z Z C	Z Z C
R Z C	R R C	R Z C
Z C R	Z Z C	Z Z C

Z=ZERO C=CANDIDATE R=REFERENCE

ANALYST: *Richard Sykes*

APPROVED BY: *Anne Probst*

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-320133-01
Batch No: 861-29310

PO: Rel:


*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****

Component	Certified	Standard	Instrument	Serial	Last	Measurement
PROPANE	Concentration	Number	Make/Model	Number	Calibration	Principal
	286 ±3.2 PPM	SG9128611BAL	GMIS	351.5000 PPM	Gow-Mac 750	59405U
					11/14/95	GC-FID

Balance Gas: AIR
Oxygen Concentration 20.1 %

* Standard should not be used below 150 psig

Analyst:


Richard VanDuke

Approved By:


Richard Fry

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #: 88-44768 CYLINDER #: CC112943 CYL. PRESSURE: 2000 PSIG P. O. # 20694
 EXP. DATE: 12/19/98 LAST ANALYSIS DATE: 12/19/95 CUSTOMER: TWIN CITY OXYGEN

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG).

COMPONENT: PROPANE
 STANDARD
 SRM #: 2648A
 CYL. #: FT 26617
 CONC: 4892 PPM
 INSTRUMENT: ROSEMOUNT THC
 MODEL #: 400A
 SERIAL #: 2000335
 LAST CAL.: 11/28/95

MEAN CONC.: 2960 PPM +/- 23.7 PPM
 REPLICATE CONC.
 DATE: 12/19/95
 2961 PPM
 2963 PPM
 2965 PPM

BALANCE GAS: AIR

REPLICATE DATA		REPLICATE DATA		REPLICATE DATA	
DATE:	12/19/95				
Z	0	R	183.6	C	111.1
R	183.7	Z	0	C	111.3
Z	0	C	111.4	R	183.8
DATE					
Z		R		C	
R		Z		C	
Z		C		R	

ANALYST: *Nancy A. Savage* APPROVED BY: *Laura Christman*
 Z= ZERO C=CANDIDATE R=REFERENCE
 THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED. HOWEVER IN CONNECTION WITH THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE.
 NATIONAL SPECIALTY GASES, 630 UNITED DRIVE, DURHAM, NC 27713. (919)544-3772

Certificate of Analysis for Standard Gas

Vendor SCOTT SPECIALTY GASES
Cylinder No. ALM 030977
Date of Preparation 11-2-92
Label NITRIC OXIDE
Blend Specification 144.1 PPM BALANCE N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run		
4-24-96	1	140.12	
4-24-96	2	138.04	
4-24-96	3	139.48	
4-24-96	4	140.30	
4-24-96	5	140.58	
4-24-96	6	139.47	
	Avg	139.738	

Analyst JAMES BAINVILLE

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: APRIL 24, 1996
Approved by: [Signature]

Shipped From : Scott Michigan
 Our Project # : 542740
 Your P.O. # : 40643
 Expiration Date : 4-19-94
 Cylinder Number : ALM030977
 Cylinder Pressure : 1900 psig

Customer : GENEX
 2455 CLEVELAND AVENUE
 ROSEVILLE MI 48069

*** CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES ***
 PERFORMED ACCORDING TO SECTION 3.0.4

Certified Per Traceability Procedure # G1
 Protocol # 1

Certified Accuracy 1% NIST Traceable
 Lab # 5299

Certification Date : 10-19-92
 1 of 1 Component(s)

INSTRUMENTATION

ANALYTICAL PRINCIPLE
 CHEMILUMINESCENCE

INSTRUMENT/SERIAL #
 BECKMAN 951A
 270-082899B

LAST CALIBRATION DATE
 10-1-92

REFERENCE STANDARDS

CYLINDER NUMBER	CONCENTRATION
ALM-008716	250.3 PPM
ALM-010464	95.26 PPA

ANALYZED CYLINDER

COMPONENT	CERTIFIED CONCENTRATION	SRM # (CRM #)
NITRIC OXIDE	144.1 PPM	1685
		1684

BALANCE GAS : NITROGEN

NITROGEN DIOXIDE 1.00 PPM (FROM SECOND ANALYSIS)

FIRST ANALYSIS			DATE : 10-15-92		
ZERO GAS (mV)	TEST GAS (mV)	CURVE RESULTS PPM	ZERO GAS (mV)	TEST GAS (mV)	CURVE RESULTS PPM
0.00	57.50	144.2	0.00	57.60	144.2
0.00	57.50	143.9	0.00	57.60	144.2
0.00	57.50	143.9	0.00	58.00 NOX	145.2
CALCULATED RESULTS			CALCULATED RESULTS		
144.2			144.2		
143.9			144.2		
143.9			144.2		
AVERAGE : 144.0 PPM			AVERAGE : 144.2 PPM		

SECOND ANALYSIS			DATE : 10-19-92		
ZERO GAS (mV)	TEST GAS (mV)	CURVE RESULTS PPM	ZERO GAS (mV)	TEST GAS (mV)	CURVE RESULTS PPM
0.00	57.60	144.2	0.00	57.60	144.2
0.00	57.60	144.2	0.00	57.60	144.2
0.00	58.00 NOX	145.2	0.00	58.00 NOX	145.2
CALCULATED RESULTS			CALCULATED RESULTS		
144.2			144.2		
144.2			144.2		
144.2			144.2		
AVERAGE : 144.2 PPM			AVERAGE : 144.2 PPM		

CALIBRATION CURVE 1 at DEGREE			
SRM # (CRM #)	CONC. PPM	SPLIT PT (%)	DVM FITTED PERCENT VALUE ERROR
1685	250.3	100	100.0 250.3 0.00
1684	95.26	38	38.05 95.24 -0.02
	0.0000	0	0.0000 0.00 0.00
		0	0.00 0.00 0.00
		0	0.00 0.00 0.00
		0	0.00 0.00 0.00
1684	95.26	LOW	38.05 95.24 -0.02
1685	250.3	HIGH	100.0 250.3 0.00

* GHS - GAS MANUFACTURER'S INTERNAL STANDARD

Analyst : *[Signature]*
 Approved By : *[Signature]*

DOE EICHLER, JR

Revised : 3/31/92 RML

Certificate of Analysis for Standard Gas

Vendor National Specialty Gases
Cylinder No. CC 114192
Date of Preparation ~~4-4-96~~ 3-23-93
Label Nitric Oxide
Blend Specification 239 ppm Balance N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run	NO _x	
4-5-96	1	236.5035	
4-5-96	2	235.5680	
4-5-96	3	234.6729	
	4		
	5		
	6		
	Avg	235.5815	1.43%

Analyst Gas A

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: April 5, 1996
Approved by: [Signature]

INTERPOL LABS

TANK CERT
 TANK NUMBER CCI14192
 4/5/96

4/5/96	7:54:00 AM			
0	237.175	0	0	0
4/5/96	7:54:06 AM			
0	236.361	0	0	0
4/5/96	7:54:12 AM			
0	236.768	0	0	0
4/5/96	7:54:18 AM			
0	236.361	0	0	0
4/5/96	7:54:24 AM			
0	237.175	0	0	0
4/5/96	7:54:30 AM			
0	236.361	0	0	0
4/5/96	7:54:36 AM			
0	236.768	0	0	0
4/5/96	7:54:42 AM			
0	236.361	0	0	0
4/5/96	7:54:48 AM			
0	235.954	0	0	0
4/5/96	7:54:54 AM			
0	236.768	0	0	0
4/5/96	7:55:00 AM			
0	236.361	0	0	0
4/5/96	7:55:06 AM			
0	236.768	0	0	0
4/5/96	7:55:12 AM			
0	236.361	0	0	0
4/5/96	7:55:18 AM			
0	235.548	0	0	0
4/5/96	7:55:24 AM			
0	235.954	0	0	0
4/5/96	7:55:30 AM			
0	237.582	0	0	0
4/5/96	7:55:36 AM			
0	235.548	0	0	0
4/5/96	7:55:42 AM			
0	235.954	0	0	0
4/5/96	7:55:48 AM			
0	236.361	0	0	0
4/5/96	7:55:54 AM			
0	237.582	0	0	0

236.50355

INTERPOLL LABS

TANK CERT
 TANK NUMBER CC114192
 4/5/96

4/5/96	8:09:00 AM			
0	234.327	0	0	0
4/5/96	8:09:06 AM			
0	234.734	0	0	0
4/5/96	8:09:12 AM			
0	235.141	0	0	0
4/5/96	8:09:18 AM			
0	235.141	0	0	0
4/5/96	8:09:24 AM			
0	235.548	0	0	0
4/5/96	8:09:30 AM			
0	235.141	0	0	0
4/5/96	8:09:36 AM			
0	235.141	0	0	0
4/5/96	8:09:42 AM			
0	234.734	0	0	0
4/5/96	8:09:48 AM			
0	234.734	0	0	0
4/5/96	8:09:54 AM			
0	235.141	0	0	0
4/5/96	8:10:00 AM			
0	234.734	0	0	0
4/5/96	8:10:06 AM			
0	234.734	0	0	0
4/5/96	8:10:12 AM			
0	235.141	0	0	0
4/5/96	8:10:18 AM			
0	235.141	0	0	0
4/5/96	8:10:24 AM			
0	235.141	0	0	0
4/5/96	8:10:30 AM			
0	234.734	0	0	0
4/5/96	8:10:36 AM			
0	233.106	0	0	0
4/5/96	8:10:42 AM			
0	233.513	0	0	0
4/5/96	8:10:48 AM			
0	233.92	0	0	0
4/5/96	8:10:54 AM			
0	233.513	0	0	0

234.67295

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC 27713
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-23182 CYLINDER #: CC114192 CYL. PRESSURE: 2000PSIG

EXPIRATION DATE: 3-23-95 LAST ANALYSIS DATE: 3-23-93

CUSTOMER: TWIN CITY OXYGEN P.O.#
METHOD: EPA PROTOCOL # 1 3.0.4. G-1

STANDARD:

SRM #: 1685B

CYL #: CLM-4728

CONC.: 248 PPM

INSTRUMENT:

COMPONENT: BECKMAN
CHEMILUMINESCENT

MODEL #: 951A

SERIAL #: 100532

LAST CAL.: 1-2-93

COMP: NO
MEAN CONC: 239 PPM

<u>REPLICATE CONC.</u>	
DATE: 3-16-93	DATE: 3-23-93
240 PPM	236 PPM
240 PPM	237 PPM
241 PPM	238 PPM

COMP: NO2
MEAN CONC: 2.99 PPM

<u>REPLICATE CONC.</u>	
DATE:	DATE:

COMP:
MEAN CONC:

<u>REPLICATE CONC.</u>	
DATE:	DATE:

BALANCE GAS: NITROGEN

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-411663-01
Batch No: 861-31683

Cylinder No: SG9169061BAL
Cylinder Pressure*: 2000 psig
Certification Date: 04/29/96
Expiration Date: 04/29/98

PO: Rel: ***** Analytical Instrumentation *****
*** Certified Concentration *** Reference Standards *****
Certified Standard Instrument Serial Last Measurement
Component Concentration Cylinder # Number Concentration Make/Model Number Calibration Principal
NITRIC OXIDE 91.9 ±.39 PPM SG9148169BAL GMIS 96.0200 PPM Rosemount 951a 0101877 04/19/96 CHEMILUMINESCENCE

Balance Gas: NITROGEN
Contaminant Nitrogen Dioxide 1.40 PPM

* Standard should not be used below 150 psig

Analyst:

James Laas

Approved By:

Richard Fry

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #:	38-16472	CYLINDER #:	CC 61434	CYL. PRESSURE:	2000 PSIG	P.O. #:	22209
EXP. DATE:	3/14/96	LAST ANALYSIS DATE:	3/14/96	CUSTOMER:	TWIN CITY OXYGEN		

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS. SEPTEMBER 1993. G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 10 MEGAPASCALS (150 PSIG).

COMPONENT: CARBON DIOXIDE		COMPONENT: OXYGEN	
STANDARD	SRM #:	STANDARD	SRM #:
1675B	1675A		2659A
CYL #:	CLM 6481	CYL #:	CLM 6737
CONC:	14.01 %	CONC:	20.72 %
INSTRUMENT:	ROSEMONT NDIR	INSTRUMENT:	BECKMAN PARAMAGNETIC
MODEL #:	880	MODEL #:	755
SERIAL #:	2000418	SERIAL #:	1001419
LAST CAL:	2/20/96	LAST CAL:	3/1/96
MEAN CONC.:	16.6%	MEAN CONC.:	20.8%
REPLICATE CONC.:	-/-	REPLICATE CONC.:	0.17 %
DATE:	3/14/96	DATE:	
	%		%
	%		%
	%		%

BALANCE GAS: NITROGEN

REPLICATE DATA		REPLICATE DATA		REPLICATE DATA	
DATE:	3/14/96	DATE:	3/14/96	DATE:	3/14/96
Z	0	R	14.1	C	16.7
R	14.1	Z	0	C	16.8
Z	0	C	16.6	R	14.0
DATE:		DATE:		DATE:	
Z		R		C	
K		Z		C	
Z		C		R	

ANALYST: *Robert McK...*
 APPROVED BY: *Laura...*
 Z ZERO C-CANDIDATE R-REFERENCE

THIS REPORT PREPARED AND ANALYZED BY THE NATIONAL SPECIALTY GASES LABORATORY. EVERY EFFORT HAS BEEN MADE TO OBTAIN THE MOST ACCURATE RESULTS. THE NATIONAL SPECIALTY GASES LABORATORY IS NOT RESPONSIBLE FOR THE RESULTS OF REPLICATIONS PERFORMED BY OTHER LABORATORIES. (10/19/94-177)

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #:	88-46474	CYLINDER #:	CC-47432	CYL. PRESSURE:	2000 PSIG	P.O. #:	22209
EXP. DATE:	3/14/96	LAST ANALYSIS DATE:	3/14/96	CUSTOMER:	TWIN CITY OXYGEN		

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG).

COMPONENT: CARBON DIOXIDE		COMPONENT: OXYGEN		COMPONENT: STANDARD	
STANDARD		STANDARD		STANDARD	
SRM #:	1675B	SRM #:	2639A	SRM #:	
CYL. #:	CLM 6481	CYL. #:	CLM 6737	CYL. #:	
CONC.:	14.01 %	CONC.:	20.75 %	CONC.:	
INSTRUMENT: ROSEMOUNT NDIR		INSTRUMENT: BECKMAN PARAMAGNETIC		INSTRUMENT:	
MODEL #:	380	MODEL #:	755	MODEL #:	
SERIAL #:	2000418	SERIAL #:	1001419	SERIAL #:	
LAST CAL.:	2/20/96	LAST CAL.:	3/1/96	LAST CAL.:	
MEAN CONC.:	10.8%	MEAN CONC.:	13.5%	MEAN CONC.:	0.11 %
REPLICATE CONC.:		REPLICATE CONC.:		REPLICATE CONC.:	
DATE:	3/14/96	DATE:	3/14/96	DATE:	
	10.8 %		13.5 %		
	10.9 %		13.4 %		
	10.8 %		13.5 %		

BALANCE GAS: NITROGEN

REPLICATE DATA		REPLICATE DATA		REPLICATE DATA	
DATE:	3/14/96	DATE:	3/14/96	DATE:	
Z	0	K	14.1	C	10.9
R	14.1	Z	0	C	11.0
Z	0	C	10.8	R	14.0
DATE:		R		C	
Z		R		C	
R		Z		R	
Z		C		R	

ANALYST: *[Signature]*
 THIS REPORT STANDS AS VALIDATION OF THE ANALYSIS. THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY EVERY DAY AT 10:00 AM MUST BE KEPT IN THE LABORATORY UNTIL THE ANALYSIS IS COMPLETE. THE ANALYST IS RESPONSIBLE FOR THE QUALITY OF THE ANALYSIS. THE ANALYST IS RESPONSIBLE FOR THE QUALITY OF THE ANALYSIS. THE ANALYST IS RESPONSIBLE FOR THE QUALITY OF THE ANALYSIS.
 APPROVED BY: *[Signature]*
 Z= ZERO C=CANDIDATE R=REFERENCE

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS 1 EPA PROTOCOL MIXTURES

REFERENCE #:	88-45052	CYLINDER #:	CC50725	CYL. PRESSURE:	2000PSIG	P.O. #:	
EXP. DATE:	1/5/99	LAST ANALYSIS DATE:	1/5/96	CUSTOMER:	TWIN CITY OXYGEN		

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG)

COMPONENT: CARBON MONOXIDE		COMPONENT: NITROGEN	
STANDARD	ROSEMOUNT NDIR	STANDARD	
SRM #:	1680B	SRM #:	
CYL. #:	FF 34077	CYL. #:	
CONC:	477 PPM	CONC:	
INSTRUMENT:	ROSEMOUNT NDIR	INSTRUMENT:	
MODEL #:	880A	MODEL #:	
SERIAL #:	2000172	SERIAL #:	
LAST CAL.:	12/13/95	LAST CAL.:	
MEAN CONC.:	289 PPM +/-	MEAN CONC.:	2.31 PPM
REPLICATE CONC.:		REPLICATE CONC.:	
DATE:	12/28/95	DATE:	1/5/96
	289 PPM		289 PPM
	289 PPM		289 PPM
	290 PPM		289 PPM

BALANCE GAS: NITROGEN		BALANCE GAS: NITROGEN	
DATE:	12/28/95	DATE:	1/5/96
Z 0	R 478	Z 0	R 478
R 477	Z 0	R 477	Z 0
Z 0	C 290.0	Z 0	C 290.0
DATE:	1/5/96	DATE:	1/5/96
Z 0	R 478	Z 0	R 478
R 477	Z 0	R 477	Z 0
Z 0	C 289.6	Z 0	C 289.6

ANALYST: *Ann Hare* APPROVED BY: *Diana J. Hartono*
 Z= ZERO C=CANDIDATE R=REFERENCE
 THIS REPORT STATES ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED. HOWEVER, IN CONNECTION WITH THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE.
 ASSAYED AT: NATIONAL SPECIALTY GASES, 630 UNITED DRIVE, DURHAM, NC 27713 (919)544-3772

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC 27713
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-25249 CYLINDER #:CC44391 CYL. PRESSURE: 200PSG

EXPIRATION DATE: 7-7-96 LAST ANALYSIS DATE:7-7-93

CUSTOMER:TWIN CITY OXYGEN P.O.# 5337
METHOD: EPA PROTOCOL # 13.0.4.G-1

STANDARD:

SRM #:1681B

CYL #:CLM4470

CONC.:975PPM

INSTRUMENT:

BECKMAN
COMPONENT: NDIR

MODEL #: 865

SERIAL #: 0103409

LAST CAL.: 4-2-93

COMPONENT:	CO	<u>REPLICATE CONC.</u>	
MEAN CONC:	620PPM	DATE: 6-30-93	DATE: 7-7-93
		623PPM	618PPM
		620PPM	616PPM
		621PPM	619PPM

COMPONENT:		<u>REPLICATE CONC.</u>	
MEAN CONC:		DATE:	DATE:

COMPONENT:		<u>REPLICATE CONC.</u>	
MEAN CONC:		DATE:	DATE:

BALANCE GAS:N2

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-41643 CYLINDER #: CC35905 CYL. PRESSURE: 2000PSIG CUSTOMER: TWIN CITY
 EXPIRATION DATE: 7/25/98 LAST ANALYSIS DATE: 7/25/95
 METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION
 STANDARDS-SEPTEMBER 1993:G-1. P.O.#: SHELLA
 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150PSIG).

STANDARD: STANDARD:
 SRM #: 1667B SRM #:
 CYL #: CLM5293 CYL. #:
 CONC.: 47.3PPM CONC.:
 INSTRUMENT: ROSEMOUNT THC INSTRUMENT:
 MODEL #: 400A MODEL #:
 SERIAL #: 2000335 SERIAL #:
 LAST CAL.: 7/14/95 LAST CAL.:

COMPONENT: PROPANE COMPONENT:
 MEAN CONC: 30.6 ± 0.31PPM MEAN CONC:
 REPLICATE CONC. REPLICATE CONC.
 DATE: 7/25/95 DATE:
 30.6PPM
 30.5PPM
 30.6PPM

BALANCE GAS: AIR

COMPONENT: PROPANE	COMPONENT:			
REPLICATE DATA	REPLICATE DATA			
DATE: 7/25/95	DATE:			
Z 0 R 47.3 C 30.6	Z	R	C	R
R 47.3 Z 0 C 30.5	R	Z	C	C
Z 0 C 30.6 R 47.3	Z	C	R	R
DATE:	DATE:			
Z R C	Z	R	C	C
R Z C	R	Z	C	C
Z C R	Z	C	R	R

Z=ZERO C=CANDIDATE R=REFERENCE

ANALYST: *Richard Sykes* APPROVED BY: *John Hines*

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer: Order No: CSS-320133-01

Batch No: 861-29310

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Cylinder No: SC9165627BAL
Cylinder Pressure*: 2000 psig
Certification Date: 12/04/95
Expiration Date: 12/04/98


PO: Rel: *** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****
Certified Standard

Component	Concentration	Cylinder #	Standard	Instrument	Serial	Last	Measurement
PROPANE	287 ±3.2 PPM	SG9128611BAL	GMIS	Gow-Mac 750	59405U	11/14/95	GC-FID

Balance Gas: AIR

Oxygen Concentration 20.2 %


* Standard should not be used below 150 psig



Analyst:

Richard Van Dyke

Approved By:



Richard Van Dyke

APPENDIX I

PROCESS RATE INFORMATION



SAGOLA DRYER/PRESS TESTS

<u>CONTENTS</u>	<u>PAGE</u>
TEST SCHEDULES	1
GENERAL INFORMATION SUMMARY	2
DRYER TEST, JULY 23, 1996	
PM,NOX,CO:VOC:VOC (E-TUBE\RTO)	
PRODUCTION/SUMMARY	3-5
PRESS CHART	6-7
PRESS REPORT	8-9
SHIFT OPERATING REPORT	10-11
PRODUCTION REPORT	12
SURFACE DRYER CHART	13-14
CORE DRYER CHART	15-16
SURFACE/CORE CHART	17-18
DRYER DATA	19-24
DRYER OPERATING REPORT	25-26
SURFACE E- TUBE CHART	27
CORE E- TUBE CHART	28
SURFACE/CORE E-TUBE CHART	29
E- TUBE DATA SHEET	30-35
E- TUBE LOG SHEET	36-37
DRYER RTO CHART	38
RTO DATA SHEET	39-40
RTO LOG SHEET	41-42
BUNDLE HEIGHT PARAMETERS W/WEIGHTS	43-44
DRYER TEST, JULY 24, 1996	
HCHO:HCHO (E-TUBE\RTO)	
PRODUCTION/SUMMARY	45-46
PRESS CHART	47-48
PRESS REPORT	49-50
SHIFT OPERATING REPORT	51-52
PRODUCTION REPORT	53
SURFACE DRYER CHART	54-55
CORE DRYER CHART	56-57
SURFACE/CORE CHART	58-59
DRYER DATA	60-65
DRYER OPERATING REPORT	66-67
SURFACE E- TUBE CHART	68
CORE E- TUBE CHART	69
SURFACE/CORE E-TUBE CHART	70
E- TUBE DATA SHEET	71-79
E- TUBE LOG SHEET	80-81
DRYER RTO CHART	82
RTO DATA SHEET	83-85
RTO LOG SHEET	86-87
BUNDLE HEIGHT PARAMETERS W/WEIGHTS	88-89
PRESS TEST, JULY 24, 1996	
PM	
PRODUCTION/SUMMARY	90
PRESS RTO CHART	91
PRESS RTO DATA SHEET	92
RTO LOG SHEET	93-94
RAW MATERIAL USAGE	95
PRESS TEST, JULY 25, 1996	
HCHO:MDI,PHENOL,VOC,NOX,CO	
PRODUCTION/SUMMARY	96
PRESS CHART	97-98
PRESS REPORT	99-100
SHIFT OPERATING REPORT	101-102
PRODUCTION REPORT	103
PRESS RTO CHART	104
PRESS RTO DATA SHEET	105-106
RTO LOG SHEET	107-108
BUNDLE HEIGHT PARAMETERS W/WEIGHTS	109-110
RAW MATERIAL USAGE	111

SAGOLA TEST SCHEDULE JULY 23-25, 1996

Dryer

	<u>POLLUTANT</u>	<u>RUN #1</u>	<u>RUN #2</u>	<u>RUN #3</u>
7-23 (100% PINE)	PM,CO,NOX	1130-1330 <i>shutdown 1138-1230</i>	1436-1543	1645-1751
7-23 (100% PINE)	VOC	1435-1535 <i>1- 224 2- 205 3- 214</i>	1645-1745 <i>223 211 213</i>	1925-2025 <i>243 193 224</i>
7-24	HCHO	1710-1828	1915-2020	2040-2144

E-Tube/RTO

7-23 (100% PINE)	NOX,CO,VOC <i>(217)</i>	1435-1535	1645-1745	1925-2025
7-24	HCHO <i>229 209 223</i>	1710-1828 <i>(220)</i>	1915-2020	2040-2144

Press

7-24	PM	1835-1936	2005-2108	2137-2237
7-25 (100% PINE)	HCHO	0937-1039	1235-1336	1410-1512
7-25 (100% PINE)	MDI,PHENOL,VOC, NOX,CO	1620-1720	1800-1900	1935-2035

SAGOLA TESTING JULY 23-25, 1996
Process data summary

DRYER JULY 23, 1996 - PM,CO,NOX

29.02 =PressProduction rate in Tons per hour
70,689 =Production rate of both dryers in pounds per hour
6.33 =Total fuel burned in tons per hour
43.84% =average incoming moisture percent
6.04% =average dry moisture percent
984 =average inlet temperature
1,548 =average RTO burner temperature #1
1,558 =average RTO burner temperature #2
1,542 =average RTO burner temperature #3

DRYER JULY 23, 1996 - VOC

31.80 =PressProduction rate in Tons per hour
77,163 =Production rate of both dryers in pounds per hour
6.78 =Total fuel burned in tons per hour
39.91% =average incoming moisture percent
5.77% =average dry moisture percent
992 =average inlet temperature
1,557 =average RTO burner temperature #1
1,569 =average RTO burner temperature #2
1,551 =average RTO burner temperature #3

DRYER JULY 24, 1996 - HCHO

31.31 =PressProduction rate in Tons per hour
75,385 =Production rate of both dryers in pounds per hour
6.39 =Total fuel burned in tons per hour
32.31% =average incoming moisture percent
6.37% =average dry moisture percent
886 =average inlet temperature
1,539 =average RTO burner temperature #1
1,540 =average RTO burner temperature #2
1,540 =average RTO burner temperature #3

E-TUBE/RTO JULY 23, 1996 - NOX,CO,VOC

31.80 =PressProduction rate in Tons per hour
77,163 =Production rate of both dryers in pounds per hour
6.78 =Total fuel burned in tons per hour
39.91% =average incoming moisture percent
5.77% =average dry moisture percent
992 =average inlet temperature
1,557 =average RTO burner temperature #1
1,569 =average RTO burner temperature #2
1,551 =average RTO burner temperature #3

E-TUBE/RTO JULY 24, 1996 - HCHO

31.31 =PressProduction rate in Tons per hour
75,385 =Production rate of both dryers in pounds per hour
6.39 =Total fuel burned in tons per hour
32.31% =average incoming moisture percent
6.37% =average dry moisture percent
886 =average inlet temperature
1,539 =average RTO burner temperature #1
1,540 =average RTO burner temperature #2
1,540 =average RTO burner temperature #3

PRESS JULY 24, 1996 - PM

30.34 =Plant Production rate in Tons per hour
792.33 =MDI resin usage in pounds per hour
1.31% =MDI resin usage as % of finished product
1,502.67 =Liquid phenolic resin usage in pounds per hour (100% solids)
2.48% =Liquid phenolic resin usage as % of finished product (100% solids)
693.67 =Wax usage in pounds per hour
1.14% =Wax usage as % of finished product

PRESS JULY 25, 1996 - HCHO

28.50 =Plant Production rate in Tons per hour
836.67 =MDI resin usage in pounds per hour
1.47% =MDI resin usage as % of finished product
1,781.67 =Liquid phenolic resin usage in pounds per hour (100% solids)
3.09% =Liquid phenolic resin usage as % of finished product (100% solids)
696.33 =Wax usage in pounds per hour
1.22% =Wax usage as % of finished product

PRESS JULY 25, 1996 - MDI,PHENOL

30.48 =Plant Production rate in Tons per hour
793.00 =MDI resin usage in pounds per hour
1.30% =MDI resin usage as % of finished product
1,706.33 =Liquid phenolic resin usage in pounds per hour (100% solids)
2.80% =Liquid phenolic resin usage as % of finished product (100% solids)
677.00 =Wax usage in pounds per hour
1.11% =Wax usage as % of finished product

DRYER JULY 23rd, 1996
PM,NOX,CO

DATA TIME:	START=	11:30	END=	11:38	HOURS=	0.13
	START=	12:30	END=	13:30	HOURS=	1.00
	START=	14:36	END=	15:43	HOURS=	1.12
	START=	16:45	END=	17:51	HOURS=	1.10
				TOTAL=		3.35

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
per/peice 50.01
per/ 8' x 24' 300.03

4500.5 lb= average
bundle weight
90 piece units

PLANT PRODUCTION RATE

3.35 =hours during testing
54 =pressloads
648 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
124,416 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
145,156 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
194,422 =lbs of finished product (boards produced x weight of finished board)
58,037 =lbs of finished product per hour (lbs of finished product / hours)
29.02 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

8 =SURFACE fuel calibration in pounds per count
1,882 =SURFACE counts during testing hours
15,056 =SURFACE lbs of fuel burned during testing
3.35 =hours during testing
4,494 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.25 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8,500 =estimated BTU content per pound of dry fuel,
38.2 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
888 =average inlet temperature
32.33 =average incoming moisture percent
6.17 =average dry moisture percent

CORE

7.96 =CORE fuel calibration in pounds per count
1,709 =CORE counts during testing hours
13,604 =CORE lbs of fuel burned during testing
3.35 =hours during testing
4,061 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.03 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8,500 =estimated BTU content per pound of dry fuel,
34.5 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
1,033 =average inlet temperature
49.60 =average incoming moisture percent
6.40 =average dry moisture percent

SURFACE/CORE

7.42 =SURFACE/CORE fuel calibration in pounds per count
1,850 =SURFACE/CORE counts during testing hours
13,727 =SURFACE/CORE lbs of fuel burned during testing
3.35 =hours during testing
4,098 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.05 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8,500 =estimated BTU content per pound of dry fuel,
34.8 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
1,032 =average inlet temperature
49.60 =average incoming moisture percent
5.54 =average dry moisture percent

DRYER THROUGHPUT RATE

12,653 =Total pounds of fuel burned per hour in Core, Surface and Surface/Core Dryers
58,037 =lbs of finished product per hour (lbs of finished product / hours)
70,689 =Pounds of material produced by the dryer per hour (dry basis, assumming fuel balances)
3,055 = weight of trim per hour at 5.0% of finished product
9,598 =weight of screened fines per hour (total fuel - trim)
13.58% =resulting loss to fines as percentage of dryer throughput

11.78 03/77

DRYER JULY 23rd, 1996

VOC

DATA TIME	START=	14:35	END=	15:35	HOURS=	1.00
	START=	16:45	END=	17:45	HOURS=	1.00
	START=	19:25	END=	20:25	HOURS=	1.00
					TOTAL=	3.00

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
 per/peice 50.01
 per/ 8' x 24' 300.03

4500.5 lb= average
 bundle weight
 90 piece units

PLANT PRODUCTION RATE

- 3.00 =hours during testing
- 53 =pressloads
- 636 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
- 122,112 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
- 142,468 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
- 190,822 =lbs of finished product (boards produced x weight of finished board)
- 63,607 =lbs of finished product per hour (lbs of finished product / hours)
- 31.80 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 8 =SURFACE fuel calibration in pounds per count
- 1,804 =SURFACE counts during testing hours
- 14,432 =SURFACE lbs of fuel burned during testing
- 3.00 =hours during testing
- 4,811 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.41 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 40.9 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 877 =average inlet temperature
- 29.93 =average incoming moisture percent
- 5.99 =average dry moisture percent

CORE

- 7.96 =CORE fuel calibration in pounds per count
- 1,591 =CORE counts during testing hours
- 12,664 =CORE lbs of fuel burned during testing
- 3.00 =hours during testing
- 4,221 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.11 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 35.9 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1,004 =average inlet temperature
- 44.90 =average incoming moisture percent
- 5.87 =average dry moisture percent

SURFACE/CORE

- 7.42 =SURFACE/CORE fuel calibration in pounds per count
- 1,829 =SURFACE/CORE counts during testing hours
- 13,571 =SURFACE/CORE lbs of fuel burned during testing
- 3.00 =hours during testing
- 4,524 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.26 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 38.5 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1,096 =average inlet temperature
- 44.90 =average incoming moisture percent
- 5.44 =average dry moisture percent

DRYER THROUGHPUT RATE

- 13,556 =Total pounds of fuel burned per hour in Core, Surface and Surface/Core Dryers
- 63,607 =lbs of finished product per hour (lbs of finished product / hours)
- 77,163 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 3,348 = weight of trim per hour at 5.0% of finished product
- 10,208 =weight of screened fines per hour (total fuel - trim)
- 13.23% =resulting loss to fines as percentage of dryer throughput

12.85 0574

E-TUBE/RT0 JULY 23rd, 1996

VOC

DATA TIME	START=	14:35	END=	15:35	HOURS=	1.00
	START=	16:45	END=	17:45	HOURS=	1.00
	START=	19:25	END=	20:25	HOURS=	1.00
					TOTAL=	3.00

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
 per/peice 50.01
 per/ 8' x 24' 300.03

4500.5 lb= average
 bundle weight
 90 piece units

PLANT PRODUCTION RATE

- 3.00 =hours during testing
- 53 =pressloads
- 636 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
- 122,112 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
- 142,468 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
- 190,822 =lbs of finished product (boards produced x weight of finished board)
- 63,607 =lbs of finished product per hour (lbs of finished product / hours)
- 31.80 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 8 =SURFACE fuel calibration in pounds per count
- 1,804 =SURFACE counts during testing hours
- 14,432 =SURFACE lbs of fuel burned during testing
- 3.00 =hours during testing
- 4,811 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.41 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 40.9 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 877 =average inlet temperature
- 29.93 =average incoming moisture percent
- 5.99 =average dry moisture percent

CORE


- 7.96 =CORE fuel calibration in pounds per count
- 1,591 =CORE counts during testing hours
- 12,664 =CORE lbs of fuel burned during testing
- 3.00 =hours during testing
- 4,221 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.11 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 35.9 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1,004 =average inlet temperature
- 44.90 =average incoming moisture percent
- 5.87 =average dry moisture percent

SURFACE/CORE

- 7.42 =SURFACE/CORE fuel calibration in pounds per count
- 1,829 =SURFACE/CORE counts during testing hours
- 13,571 =SURFACE/CORE lbs of fuel burned during testing
- 3.00 =hours during testing
- 4,524 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.26 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 38.5 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1,096 =average inlet temperature
- 44.90 =average incoming moisture percent
- 5.44 =average dry moisture percent


DRYER THROUGHPUT RATE

- 13,556 =Total pounds of fuel burned per hour in Core, Surface and Surface/Core Dryers
- 63,607 =lbs of finished product per hour (lbs of finished product / hours)
- 77,163 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 3,348 = weight of trim per hour at 5.0% of finished product
- 10,208 =weight of screened fines per hour (total fuel - trim)
- 13.23% =resulting loss to fines as percentage of dryer throughput



Press
 Screw
 KNACK
 CHART NO. KPC105/0096
 DATE 7-23-96
 3 DAY
 158

SAGOLA PRESS
 7/23/96
 0700 - 1900



SAGOLA PRESS
 7/23/96
 1900 - 0700

OPERATOR Krackenberger DATE 2-23-96
SHIFT DAY CREW B

1	47	51	73	121	164	181	73
2	49	52	77	122	164	182	72
3	49	53	73	123	163	183	71
4	47	54	75	124	164	184	70
5	47	55	78	125	163	185	71
6	48	56	74	126	161	186	67
7	46	57	72	127	163	187	66
8	50	58	70	128	162	188	66
9	49	59	70	129	162	189	
10	47	70	70	130	164	190	
11	47	71	71	131	165	191	
12	50	72	71	132	165	192	
13	52	73	72	133	168	193	
14	51	74	71	134	167	194	
15	51	75	70	135	167	195	
16	52	76	71	136	168	196	
17	55	77	71	137	71	197	
18	50	78	71	138	71	198	
19	53	79	71	139	72	199	
20	52	80	72	140	73	200	
21	52	81	70	141	70	201	
22	57	82	71	142	70	202	
23	52	83	72	143	69	203	
24	52	84	72	144	69	204	
25	53	85	70	145	67	205	
26	68	86	70	146	68	206	
27	69	87	72	147	66	207	
28	70	88	69	148	67	208	
29	72	89	69	149	67	209	
30	71	90	69	150	68	210	
31	75	91	70	151	65	211	
32	75	92	69	152	63	212	
33	81	93	69	153	65	213	
34	83	94	69	154	66	214	
35	84	95	68	155	67	215	
36	80	96	66	156	67	216	
37	78	97	67	157	65	217	
38	74	98	66	158	64	218	
39	73	99	64	159	67	219	
40	71	100	66	160	67	220	
41	71	101	62	161	66	221	
42	70	102	64	162	68	222	
43	70	103	65	163	68	223	
44	69	104	66	164	69	224	
45	70	105	63	165	68	225	
46	68	106	63	166	69	226	
47	69	107	64	167	69	227	
48	70	108	63	168	68	228	
49	71	109	65	169	67	229	
50	70	110	66	170	68	230	
51	70	111	68	171	69	231	
52	74	112	68	172	68	232	
53	72	113	67	173	69	233	
54	72	114	68	174	67	234	
55	74	115	67	175	67	235	
56	76	116	65	176	68	236	
57	75	117	66	177	68	237	
58	79	118	67	178	70	238	
59	75	119	67	179	71	239	
60	73	120	65	180	72	240	

GREASE COLUMNS _____
FLUSH BLENDER _____
BAGHOUSE PRES. _____
HYD OIL TEMP _____
INSP. FIT/RET CONVS _____
CLEAN DECKLE CHAIN _____
CLEAN BLENDERS _____
CLEAN TAIL PULLEYS _____

BLOW OUT _____
FIL RADIATORS _____
HYD. COOLING FANS _____
FPS COOLING FANS _____
F.C.O.S. _____
FORMER DECK _____
LOADER _____
UNLOADER _____
PRESS _____

LN	SPD FROM	TO	THICK	PRESS	LDS	FOOTAGE
93	2:00	8:00	7/16	---	---	---
86	8:00	8:15	7/16	---	---	---
83	8:15	8:45	7/16	---	---	---
78	8:45	100	7/16	---	---	---
85	100	7:00	7/16	188	505, 358	---

FROM	TO	M	E	O	MINS.	REASON FOR DOWN TIME
7:20	7:45	V	V	V	25	sched Maint
8:00	8:02	/			2	FCOS Plug
8:55	8:58	/			3	" "
8:20	8:28	/			1	Backed up
6:37	6:39				2	SAWline SAM

33

8

OPERATOR Levi DATE 7-23-96
SHIFT Nite CREW 0

- BLOW OUT _____
F.L. RADIATORS _____
HYD. COOLING FANS _____
PRS COOLING FANS _____
F.C.O.S. _____
FORMER DECK _____
LOADER _____
UNLOADER _____
PRESS _____

- GREASE COLUMNS _____
FLUSH BLENDER _____
BAGHOUSE PRES. _____
HYD OIL TEMP _____
INSP. FIT/RET CONVS _____
CLEAN DECKLE CHAIN _____
CLEAN BLENDERS _____
CLEAN TAIL PULLEYS _____

93 - softwood 7/16
7 - Aspen 7/16

LN	SPD	FROM	TO	THICK	PRESS	LDS	FOOTAGE
487	84	7:00	7:08	7/16	100		268,808
16.5	90	1:08	2:05	1/4	16		24,577
15.0	90	2:05	2:38	3/8	10		23,040
104.8	81	2:38	6:49	1/2	55		168,956
	81	6:49		7/16	3		2,064
					(184)		(493,445)

FROM	TO	M	E	O	MINS.	REASON FOR DOWNTIME
10:48	10:53				5	Dropped #8 unbadder
10:55	10:57				2	unloader out of sequence
1:17	1:20				3	SAWline
6:02	6:03				1	TLF - Plugging
					(11)	

1	66	51	74	121	48	181	49
2	64	52	74	122	46	182	46
3	64	53	73	123	45	183	47
4	65	54	73	124	45	184	49
5	64	55	72	125	42	185	
6	65	56	70	126	44	186	
7	66	57	70	127	46	187	
8	67	58	70	128	43	188	
9	69	59	69	129	44	189	
10	72	70	68	130	49	190	
11	69	71	69	131	47	191	
12	70	72	70	132	47	192	
13	73	73	64	133	47	193	
14	70	74	71	134	51	194	
15	68	75	72	135	50	195	
16	69	76	73	136	49	196	
17	69	77	73	137	49	197	
18	68	78	75	138	47	198	
19	68	79	75	139	48	199	
20	69	80	73	140	48	200	
21	70	81	74	141	47	201	
22	71	82	73	142	46	202	
23	72	83	74	143	47	203	
24	70	84	74	144	45	204	
25	73	85	75	145	45	205	
26	78	86	75	146	47	206	
27	84	87	74	147	47	207	
28	82	88	74	148	49	208	
29	83	89	69	149	49	209	
30	80	90	69	150	50	210	
31	80	91	66	151	50	211	
32	80	92	64	152	47	212	
33	78	93	62	153	47	213	
34	73	94	58	154	46	214	
35	70	95	50	155	46	215	
36	72	96	52	156	45	216	
37	72	97	51	157	47	217	
38	73	98	51	158	47	218	
39	75	99	51	159	51	219	
40	72	100	52	160	51	220	
41	75	101	46	161	56	221	
42	74	102	46	162	53	222	
43	74	103	44	163	52	223	
44	73	104	44	164	50	224	
45	73	105	44	165	46	225	
46	75	106	45	166	46	226	
47	75	107	43	167	47	227	
48	73	108	43	168	52	228	
49	73	109	45	169	50	229	
50	74	110	42	170	50	230	
51	76	111	43	171	50	231	
52	75	112	44	172	53	232	
53	74	113	43	173	53	233	
54	72	114	44	174	55	234	
55	74	115	43	175	55	235	
56	75	116	43	176	56	236	
57	77	117	40	177	51	237	
58	74	118	49	178	52	238	
59	75	119	48	179	55	239	
60	74	120	44	180	53	240	

SUPERVISOR Steve S. SHIFT 6-6 CREW 1 DATE 7-23-96

SHIFT OPERATING REPORT

PRESS OPERATION

Minutes Downtime

LINE SPEED	FROM	TO	THICKNESS	PRESS LOADS	3/8" FOOTAGE	M	E	O
83	7:00	7:00	7/16	188	505,358	33		
TOTAL				188	505,358	33	-	-

Dryer Lamp Test (OK)	
Surface Dryer Fan Load	90
Core Dryer Fan Load	91
Surf/Core Dryer Fan Load	83
#1 Baghouse Pressure	
#2 Baghouse Pressure	
Surface Wet Bin Volume*	40
Core Wet Bin Volume*	30
Surf/Core Wet Bin Volume*	70
Surface Dry Bin Volume*	65
Core Dry Bin Volume*	58
Wet Bin	652

NATURAL GAS METER READINGS	
(taken end of the shift)	
MAIN	21268315
PRESS RTO	59721690
DRYER RTO	14790720
GEKA	0823986
S DRYER	
C DRYER	
S/C DRYER	

GEKA EFB	BED KV	ION KV	ION MA	EFB - P	BH - P
	10	71	71	2.8	1.8

FLAKER RUN HOURS	
#1 T.LF	#2 T.LF

BARK % MOISTURE	3.7%	FUEL % MOISTURE	2.0%
GRECON'S 5.3		5.2	

LOG COUNT ^{not possible} _{150 available}
 #1 6592 #2 1588 = 8180
 TOTAL

BARK FUEL COUNT: A 297 B 297

DRYER OPERATION

	Dry Fuel Usage Lbs.	Gas Usage Hrs.	Sust Gas Usage Hrs.	Average Inlet Temp.	Running Time Mins	Ave. Wet Moisture	Ave. Dry Moisture
Surface	5926	1	1	919	720	4.50	6.7
Core	5718	15 mins	0	980	720	4.24	6.1
S/Core	5463	20 min	1	941	720	4.35	6.6

REMARKS: 25 min sawtooth on raw fuel

SUPERVISOR AVE OGATA SHIFT NIGHTS CREW D DATE 7-27-6

SHIFT OPERATING REPORT

LINE SPEED	FROM	TO	THICKNESS	PRESS LOADS	3/8" FOOTAGE	Minutes Downtime		
						M	E	O
24	7:00	1:08	7/16	100	—	7		
90	1:08	2:05	1/4	110	24,577	3		
90	2:05	2:38	3/8	10	23,040			
21	2:38	6:49	1/2	55	168,956	1		
21	6:49	7:00	7/16	3	276,872			
TOTAL				184	493,445	11		

Dryer Lamp Test (OK)	OK
Surface Dryer Fan Load	93.6
Core Dryer Fan Load	93.1
Surf/Core Dryer Fan Load	87.8
#1 Baghouse Pressure	OK
#2 Baghouse Pressure	OK
Surface Wet Bin Volume*	75
Core Wet Bin Volume*	68
Surf/Core Wet Bin Volume*	75
Surface Dry Bin Volume*	65
Core Dry Bin Volume*	75
Laidig Bin	45 %

NATURAL GAS METER READINGS	
(taken end of the shift)	
MAIN	0127083000
PRESS RTO	59780430
DRYER RTO	14836110
GEKA	03239810
S DRYER	
C DRYER	
S/C DRYER	

GEKA EFB	BED KV	ION KV	ION MA	EFB - P	BH - P
	8.2	21	.8	3.4	1.9

FLAKER RUN HOURS	
#1 T.L.F	#2 T.L.F
396	411

BARK % MOISTURE	37.6%	FUEL % MOISTURE	2.8%
GRECOINS		15	

LOG COUNT

#1 6270 #2 1567 = 7837
TOTAL

BARK FUEL COUNT: A 321 B 321

DRYER OPERATION

	Dry Fuel Usage Lbs.	Gas Usage Hrs.	Sust. Gas Usage Hrs.	Average Inlet Temp.	Running Time Mins	Ave. Wet Moisture	Ave. Dry Moisture
Surface	5839	10 min.	92	837°	719	40.2	5.9
Core	5421	8	252	962°	720	40.8	5.9
S/Cor	4625	34 HRS 35 MIN	56	1041°	720	41.4	6.0

REMARKS: 11 min MISC

DAILY PRODUCTION REPORT

DATE: JULY 23, 1996

LOUISIANA-PACIFIC CORPORATION

DAY: TUESDAY

SAGOLA, MICHIGAN

SHIFT	BOARD SIZE	PRESS LOADS	NO. OF PANELS	SURFACE FOOTAGE	3/8" FOOTAGE
7AM.	7/16"	188	13,536	433,152	505,358
TO	0	0	0	0	0
7PM.	0	0	0	0	0
	0	0	0	0	0
	0	0	0	0	0
B	0	0	0	0	0
CREW	0	0	0	0	0
SHIFT TOTAL					505,358

SHIFT	1/4"	3/8"	1/2"	7/16"	0	0	TOTAL
7PM.	16	10	55	103	0	0	24,577
TO	0	0	0	0	0	0	23,040
7AM.	0	0	0	0	0	0	168,956
	0	0	0	0	0	0	276,872
D	0	0	0	0	0	0	0
CREW	0	0	0	0	0	0	0
SHIFT TOTAL							493,445

DAILY TOTAL	372	26,784	857,088	5,053,127
TOTAL	372	26,784	857,088	998,803
TOTAL				24,901,742
TOTAL				191,073,535

MTD 3/8" FOOTAGE					
1/4"	202,761	1/2"	4,094,875	23/32"SE	0
3/8"	85,248	19/32"SE	988,587	23/32"H	5,966,122
7/16"	11,007,677	19/32"H	164,156	7/8"H	295,676
15/32"	2,096,640	5/8"	0	1 1/8"	0

DAY	SCHED. RUN HOURS	NET RUN HOURS	% RUN TIME	% PLANT CAP.
DAY	11.50	11.50	100.0%	134.7%
NIGHT	12.00	11.75	97.9%	126.0%
DAILY	23.50	23.25	98.9%	130.3%
WTD	115.50	113.50	98.3%	
MTD	601.75	550.00	91.4%	
YTD	4,684.00	4,414.50	94.2%	


FOREMAN	% PLANT	CAP
"A" M. MESSINA	132.0%	
"B" D. SPIGARELLI	139.1%	
"C" F. SHOQUIST	135.0%	
"D" D. DONATI	142.1%	

LOG CNT.	DAILY	WTD	MTD
A CREW	0	36,215	130,597
B CREW	8,180	17,018	143,318
C CREW	0	34,332	131,563
D CREW	7,837	16,504	143,814

GAS USAGE (MCF)	DAY	MTD
SURFACE DRYER	0	16,865
CORE DRYER	0	0
S/C DRYER	0	0
GEKA	0	0
PRESS RTO	0	0
DRYER RTO	0	0
TOTAL	461	16,865


DOWNTIME DAY SHIFT B-CREW 25 MIN. SCHEDULED MAINT: 8 MIN. MISC.

NIGHT SHIFT D-CREW 11 MIN. MISC.




SAGOLA SURF. DRY
7/23/96
0700-1900

13




SAGOLA SURF. DRYER
 7/23/96
 1900-0700
 14




SAGOLA CORE DRYER
 7/23/94
 0700-1900

15




SAGOLA CORE DRYER
 7/23/46
 1900-0700

16



SAGOLA SURF/CORE
 DRYER 7/23/96
 0700 - 1900

17



SAGOLA SURF./CORE
 DRYER 7/23/96
 1900-0700

SAGOLA DRYER DATA
(FUEL CALIB. LB/COUNT)

7-23-91

SURFACE

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	ETUBE OUT
7:10 A	MAN	61.8	612	227	134	25	55/94		8.8	13
7:20	"	61.7	725	239	217	25			8.0	139
7:30	"	69	767	240	292	50			7.3	141
7:40	"	73.3	720	242	377	50			6.9	141
7:50	"	78.6	710	240	483	75	64/60		7.3	141
8:00	239	80.8	697	247	568	75			7.2	146
8:10	238	87.1	816	238	666	75			7.7	146
8:20	234.8	85.2	877	236	776	75	60/60		8.4	150
8:30	"	87.5	1046	236	861	F			6.3 A	150
8:40	"	88.5	1076	233	953	F			6.8	153
8:50	"	89.6	893	236	1065	F			6.7	151
9:00	"	90.8	1089	234	1132	75	70/65	46.2	6.6	151
9:10	"	90.8	1128	234	1256	F			6.8	151
9:20	"	90.8	1072	236	1336	75			6.3	153
9:30	"	90.8	1027	236	1423	75			6.2	152
9:40	"	90.7	835	235	1511	50	80/70		6.0	151
9:50	234.5	90.8	913	237	1609	75			6.1	149
10:00	"	"	805	235	1682	75			6.6	150
10:10	"	"	990	235	1778	75			7.0	151
10:20	"	"	1020	235	1868	75			6.6	151
10:30	"	"	910	236	1958	75	78/75		6.8	151
10:40	"	"	954	232	2034	75			7.2	139
10:50	234.0	"	1075	233	2130	50			6.8	151
11:00	"	82.6	935	233	2222	50			7.2	151
11:10	"	"	762	234	2301	50			7.5	151
11:20	"	86.4	683	236	2381	25	F/70		7.1	148
11:30	"	"	673	236	2460	50			6.9	141
11:40	"	"	680	233	2527	50		42.0	7.6	141
11:50	"	"	683	232	2593	50			7.5	141
12:00	234.5	"	848	234	2670	75			8.1	152
12:10	235	"	803	235	2751	50			8.0	151
12:20	"	"	807	237	2839	75			7.8	151
12:30	"	"	800	232	2898	50			6.2	149
12:40	"	"	840	236	2972	75			6.2	150
12:50	"	"	729	235	3049	75	68/73		6.5	141
1:00	"	87.5	683	237	3123	50		47.4	6.0	141
1:10	"	"	669	234	3200	50			6.3	140
1:20	"	"	888	232	3274	75			7.9	157
1:30	237.5	88.6	957	235	3367	50	72/64		7.2	151
1:40	"	"	977	234	3460	25			6.9	151
1:50	"	"	717	239	3558	25			5.1	153
2:00	"	"	704	239	3616	25	65/70		5.6	150
2:10	236.5	90.9	718	234	3699	50			5.7	140
2:20	"	"	907	233	3770	50		41.8	5.9	151
2:30	"	"	1012	734	3871	75			5.5	152
2:40	234.6	"	1065	235	3947	75			6.0	151
2:50	"	"	783	235	4036	75			5.7	151

SAGOLA DRYER DATA
(FUEL CALIB. LB/COUNT)

SURFACE

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
3:00	234.6	92	980	236	4124	75	68/65		5.9
3:10	"	"	1078	237	4212	75			6.2
3:20	"	"	963	237	4295	50			5.9
3:30	235	"	960	235	4385	75			6.3
3:40	"	"	115	236	4471	50			5.9
3:50	"	"	993	235	4558	50	64/72		6.6
4:00	"	"	998	235	4636	50			5.5
4:10	"	"	698	235	4725	25			5.2
4:20	"	"	738	237	4786	25			4.7
4:30	"	"	647	234	4859	50			5.0
4:40	"	"	731	235	4922	75			5.2
4:50	"	"	817	234	5027	75	63/70		6.0
5:00	"	"	847	237	5123	75			6.0
5:10	"	"	760	236	5211	75			6.0
5:20	"	"	906	235	5285	75			5.8
5:30	"	93.1	1153	233	5379	75		49.6	7.0
5:40	233.5	"	1153	236	5466	75			6.4
5:50	"	"	856	235	5553	75			6.0
6:00	"	83.1	852	234	5648	50			5.5
6:10	"	77.3	731	239	5710	50			5.5
6:20	230.1	49.5	651	252	5786	25			5.8
6:30	"	"	670	234	5824	25	65/58		6.4
6:40	MAN	"	776	252	5876	25			6.5
6:50	"	44.4	528	263	5920	-25			6.0
7:00	"	65.0	673	265	5977	25			5.4
7:10	221.1	70.1	784	221	107	50	45/57		7.2
7:20	252.1	91.9	850	354	208	50			4.6
7:30	247.7	94.3	846	241	320	50			4.9
7:40	"	"	914	246	376	75			4.6
7:50	"	"	914	242	484	50	48/46		6.4
8:00	239.5	"	760	239	541	75			6.9
8:10	"	"	727	241	621	50			6.3
8:20	"	"	726	236	764	75		40.2	7.0
8:30	"	"	826	239	787	F			6.9
8:40	"	"	753	242	840	75			6.9
8:50	237	"	718	237	945	75	45/43		6.7
9:00	235.2	"	693	236	1030	F			6.8
9:10	"	"	751	237	1107	F			5.3
9:20	230.4	"	937	238	1194	F			6.5
9:30	"	"	1160	239	1273	75	LLC/18		6.5
9:40	"	"	798	233	1362	F			6.1
9:50	"	"	754	237	1434	75			5.7
10:00	"	"	824	232	1524	50			6.0
10:10	"	"	427	232	1663	75	45/52		6.5
10:20									

151
757
150
150
152
152
148
147
147
144
157
150
150
150
152
154
150
153
142
137
135
131
131
127
132
143
150
150
150
148
147
149
147
146
148
149
152
153
149
149
146
151

7-23-96

Branch
7-23-96

SURFACE/CORE

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	Quota
231	7:10A	MAN	61.5	605	263	0	20	59/54	7.6	131
238	7:20	11	61.6	1027	253	0	25		6.9	132
244	7:30	11	62.8	964	255	0	25		6.7	135
246	7:40	11	72.9	1133	253	0	50		5.2	136
225	7:50	11	75.2	740	245	0	50	64/60	6.4	137
217	8:00	11	77.3	821	220	65	50		8.9	138
216	8:10	230.5	82.6	705	232	162	F		6.2	135
209	8:20	222.5	85.9	781	275	217	75	60/60	5.9	137
207	8:30	11	87.1	1007	219	257	F		5.4A	138
207	8:40	11	88.2	1120	220	253	75		7.5	141
211	8:50	11	89.3	1198	224	282	75		7.0	141
211	9:00	11	89.3	1159	223	657	F	70/65	6.4	141
208	9:10	221.5	89.2	1131	220	787	50		6.7	141
208	9:20	11	89.2	1117	222	872	50		6.7	141
209	9:30	11	89.3	974	223	976	75		6.4	139
210	9:40	11	89.2	834	224	1072	75	80/70	5.6	130
208	9:50	11	89.3	1148	221	1165	50		6.7	131
205	10:00	11	11	1209	221	1263	F		7.1	142
212	10:10	11	11	875	227	1345	75		3.7	135
207	10:20	221.0	11	830	220	1418	75		5.6	131
203	10:30	11	11	1137	219	1508	75	78/75		141
208	10:40	11	11	1039	225	1592	75		5.7	150
207	10:50	221.5	11	936	218	1682	75		4.8	139
210	11:00	11	87.1	805	224	1762	50		5.1	131
208	11:10	221.0	84.8	830	221	1832	50		6.1	131
206	11:20	210.0	11	901	217	1912	50	F/70	5.2	137
207	11:30	11	11	831	219	1982	75		5.1	136
207	11:40	11	11	753	221	2044	50	42.0	4.7	135
207	11:50	11	11	719	220	2108	50	77/80	4.1	134
207	12:00p	11	11	796	218	2181	75		5.4	134
207	12:10	11	11	717	220	2274	75		4.7	131
207	12:20	11	11	941	217	2338	50		6.4	131
210	12:30	11	11	868	221	2398	50		5.4	130
207	12:40	11	11	882	218	2468	75		6.3	137
208	12:50	11	11	879	219	2544	75	68/73	6.0	137
207	1:00	218.5	86.0	776	219	2618	50		4.6	137
206	1:10	218	11	1148	216	2703	50		5.9	140
210	1:20	11	11	977	221	2772	50		5.9	137
210	1:30	221.1	87.2	964	221	2861	50	72/64	5.6	137
208	1:40	221.5	83.9	1201	222	2955	75		7.2	140
212	1:50	11	84.0	1074	227	3049	75		6.0	140
207	2:00	11	11	1037	219	3104	75	65/70	6.0	140
210	2:10	220.0	82.1	1028	223	3207	75		5.4	131
211	2:20	11	11	1109	222	3272	75	41.8	6.2	140
211	2:30	11	11	1097	222	3380	75		5.5	139
212	2:40	11	11	1038	223	3436	75		5.3	139
212	2:50	11	11	904	224	3521	75		5.2	131

SAGOLA DRYER DATA
(FUEL CALIB. LB/COUNT)

SURFACE/CORE										
TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	
3:00	221.5	89.3	1077	219	3663	75	62/65		6.5	139
3:10	"	"	1112	219	3682	75			5.9	141
3:20	"	"	1037	221	3768	75			5.2	139
3:30	"	"	1100	221	3857	50			5.9	140
3:40	"	"	1155	221	3947	50			5.9	140
3:50	"	"	1015	222	4028	50			5.4	139
4:00	"	"	997	219	4127	50	64/72		5.5	140
4:10	"	"	947	221	4212	75			5.7	139
4:20	"	"	867	222	4275	50			4.4	139
4:30	220.5	"	970	221	4357	50			5.7	140
4:40	"	"	1026	219	4427	75			5.7	140
4:50	"	"	999	220	4529	50	63/70		4.0	141
5:00	"	"	1034	221	4620	75			5.3	140
5:10	"	"	1010	221	4712	75			5.0	140
5:20	"	"	1119	221	4785	75			5.5	143
5:30	"	"	1132	221	4872	75		419.6	5.7	144
5:40	"	"	1165	221	4962	F			6.0	143
5:50	"	"	1167	221	5066	50			6.1	142
6:00	"	87.8	1036	224	5151	50			4.7	138
6:10	220	69.9	793	222	5220	50			4.7	133
6:20	231.0	54.3	703	234	5302	50			4.9	126
6:30	"	"	750	232	5392	75	65/58		5.9	125
6:40	234.5	66.7	783	234	5409	75			5.9	129
6:50	"	74.0	753	235	55	75			4.6	133
7:00	"	"	781	233	89	75			4.3	135
7:10	221.0	83.7	807	222	162	50	45/57		6.2	137
7:20	225.7	90.4	1092	226*	273	50			5.4	141
7:30	226.2	93.9	979	226	400	50			4.1	140
7:40	"	"	1069	226	438	50			4.3	140
7:50	"	"	1231	218	557	F			6.8	144
8:00	224.2	"	1209	224.1	630	75	48/46		5.0	145
8:10	"	"	1228	226	725	75			5.1	145
8:20	"	"	1183	225*	819	F		410.2	5.2	143
8:30	"	"	1144	219	897	75			6.0	149
8:40	"	"	1264	221	970	75			7.3	144
8:50	225.0	"	1219	220	1096	F	45/45		5.3	144
9:00	"	"	1138	224	1183	75			4.9	142
9:10	"	"	1053	227	1263	75			4.1	140
9:20	219.7	"	900	224	1344	75			4.1	136
9:30	216.5	"	772	217	1441	F	46/48		4.4	134
9:40	"	"	818	217	1475	75			4.8	134
9:50	"	"	903	214	1540	75			5.7	137
10:00	"	"	1021	219	1630	50			5.7	138
10:10	"	"	807	220	1698	25	46/52		4.5	137
10:20										

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE	B.C. Furnace F°	ABB KENT Inlet F°	ABB KENT Outlet F°	GAS & VALVE	MOISTURE METER %	MOISTURE
SURFACE									
7:50	78	71	72	1210	709	246		7.5	6.3
9:20	89		75	1200	1112	235		7.5	6.8
10:50	89	9	72	1240	1030	235		7.9	7.7
12:10	85		58	1210	575	234		7.5	6.7
1:35	87	"	68	1210	1000	237		8.4	5.6
3:05	90		76	1210	940	233		8.0	6.1
4:40	91	1	67	1230	757	232		7.7	5.6
		3			Avs - 919	235			6.4
		1							
		5							

CORE									
7:50	74	711	40	1060	680	224	23	4.6	4.8
9:20	84	1	68	1010	1092	194		6.7	5.0
10:50	84	9	63	1010	1049	192		6.9	7.0
12:10	83		48	1050	633	192		6.7	6.0
1:35	85	1	57	1060	1037	196		7.9	7.2
3:05	88		60	1060	1027	193		7.3	5.6
4:40	88	1	63	1174	1171	191		6.9	6.0
		3			Avs 950	197			6.0
		5							

SURFACE CORE									
7:50	75	71		1050	857	229	45	6.1	5.4
9:20	82	1	79	910	1182	221		7.4	5.0
10:50	83	9	60	910	779	220		6.5	5.0
12:10	85		57	910	735	221		6.1	4.0
1:35	86	1	60	770	743	221		7.4	5.0
3:05	88	1	66	905	1097	221		7.4	6.0
4:40	89	1	65	910	1000	219		7.5	5.0
		3			Avs 971	222			5.0
		5							

(25)

DRYER OPERATIONS REPORT

LOUISIANA-PACIFIC CORPORATION SAGOLA ME

NAME U. RA/GOULD/FRANKY

CREW A

SHIFT DAY NIGHT

DATE 7-27-66

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE	B.C. Furnace °	ABB KENT Inlet °	Outlet °	GAS VALVE	MOISTURE METER %	MOISTURE
SURFACE									
7:30	92	(5)	68.6	1250°	879°	231°		6.0	6.3
8:55	92		61.7	1225°	722°	222°		6.1	4.3
1:00	93	(6)	56.1	1290°	709°	224°		6.9	5.8
2:00	92		82.4	1310°	1199°	224°		7.4	6.1
4:35	75	(11)	68.4	1225°	725°	236°		7.9	7.0
				Avg.	837°	227°			5.9
		(7)							
		(8)							
		(9)							
		(10)							
		(11)							


Graycons (3)

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE	B.C. Furnace °	ABB KENT Inlet °	Outlet °	GAS VALVE	MOISTURE METER %	MOISTURE
CORE									
7:30	92	(2)	58.6	1100°	991°	214°		6.9	5.8
8:55	92		76.9	1150°	1149°	206°		7.6	6.1
11:00	90	(6)	55.8	1100°	942°	210°	S.C.	6.2	5.6
2:00	85		64.0	1005°	1128°	217°		6.1	5.8
4:35	70	(11)	61.5	1050°	698°	227°		6.9	6.3
				Avg.	962°	215°			5.9
		(1)							
		(2)							
		(3)							
		(4)							
		(5)							
		(6)							
		(7)							
		(8)							
		(9)							
		(10)							
		(11)							

Graycons (2)


TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE	B.C. Furnace °	ABB KENT Inlet °	Outlet °	GAS VALVE	MOISTURE METER %	MOISTURE
SURFACE CORE									
7:30	92	(2)	66.4	925°	1141°	236°		7.5	6.3
8:55	92		67.4	850°	1142°	233°		6.4	4.3
11:00	92	(6)	79.1	990°	1021°	230°		7.9	6.1
2:00	92		78.1	950°	1031°	237°		6.0	5.8
4:35	75	(11)	25.4	975°	869°	238°		7.7	7.5
				Avg.	1011°	236°			6.0
		(1)							
		(2)							
		(3)							
		(4)							
		(5)							
		(6)							
		(7)							
		(8)							
		(9)							
		(10)							
		(11)							

(26)




SAGOLA SURFACE
E-TUBE 7/23/96

27



SAGOLA CORE
 E-TUBE 7/23/46

28



SAGOLA SURF./CORE
 E-TUBE 7/23/96

29

1/23/96

SAGOLA E-TUBE DATA SHEET

SURFACE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1130	55	310	29.0	55	310	29.1		
1140	55	370	28.9	54	310	29.0		
1150	55	370	29.0	54	340	29.0		
1200	57	360	29.0	53	240	29.1		
1210	56	370	29.0	55	290	28.9		
1220	54	390	29.1	55	300	28.9		
1230	53	310	29.0	55	310	29.1		
1240	53	310	29.0	56	310	29.0		
1250	55	320	29.1	55	320	29.0		
1300	56	350	29.1	54	300	29.1		
1310	55	350	28.9	54	320	29.0		
1320	55	340	29.0	55	320	29.1		
1330	55	350	29.0	57	320	29.0		
1340	57	370	28.9	56	320	29.0		
1350	55	350	29.0	55	390	29.0		
1400	55	420	29.1	56	420	28.9		
1410	56	400	28.9	55	330	28.9		
1420	57	320	28.9	54	320	29.0		
1430	60	330	29.0	54	310	28.9		
1440	55	290	29.0	54	350	28.8		
1450	57	420	29.0	54	340	29.0		
1500	54	400	29.1	50	200	29.1		
1510	55	400	28.9	50	300	28.7		
1520	55	400	28.9	51	310	28.9		
1530	55	400	29.0	51	330	29.2		
1540	51	370	29.0	55	310	29.2		
1550	55	370	29.0	56	400	29.1		
1600	56	420	29.0	51	300	29.1		
1610	55	440	29.1	56	360	29.2		
1620	57	440	29.1	54	350	29.1		
1630	40	100	29.7	50	550	29.3		

FT-JL

7/23/96

SAGOLA E-TUBE DATA SHEET

SURFACE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1640	53	350	28.9	55	400	29.1		
1650	50	370	29.0	55	370	28.9		
1700	54	300	29.0	54	350	29.0		
1710	55	400	29.0	54	380	28.9		
1720	55	400	29.0	53	370	28.9		
1730	55	430	29.0	52	370	29.1		
1740	56	400	29.0	55	390	29.0		
1750	57	410	28.9	54	380	29.0		
1800	53	400	29.0	25	50	29.8		
1810	54	400	28.9	52	300	28.3		
1820	52	370	29.0	50	320	29.0		
1830	54	420	29.0	52	340	29.0		
1840	50	400	29.1	50	300	29.0		
1850	55	400	29.0	50	300	29.0		
1900	52	410	28.9	50	320	29.1		
1910	49	350	29.0	50	270	29.1		
1920	49	290	29.0	50	200	29.1		
1930	40	100	29.6	50	250	29.0		
1940	50	270	29.1	50	300	29.0		
1950	50	350	29.1	54	320	29.0		
2000	56	370	29.1	52	300	28.9		
2010	56	390	29.1	52	330	28.9		
2020	54	370	29.1	54	330	29.0		
2030	54	300	29.1	54	350	29.0		
2040	54	330	29.1	55	400	29.0		
2050	53	400	29.1	54	360	29.0		
2100	50	290	29.1	20	100	29.1		
2110	50	300	29.0	50	230	29.2		
2120	55	360	29.0	52	300	28.9		
2130	54	310	29.1	52	270	29.0		
2140	55	400	29.0	53	320	29.0		
2150	55	380	29.0	53	320	28.9		
2200	53	330	29.0	55 I-32	310	29.0		

FL-5L

FL-5L

7/23/96

SAGOLA E-TUBE DATA SHEET

CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1130	S3	300	29.1	S2	290	18.4		
1140	S5	300	29.0	S1	295	19.6		
1150	S5	300	29.1	S1	295	19.0		
1200	S3	300	29.0	S3	250	24.3		
1210	S3	300	29.1	S3	260	21.8		
1220	S5	300	29.2	S3	300	20.5		
1230	S5	300	29.0	S3	250	20.2		
1240	S3	330	29.1	S3	260	20.7		
1250	S5	380	29.1	S3	260	21.6		
1300	S5	400	29.0	S3	280	17.8		
1310	S4	400	29.0	S3	280	19.4		
1320	S3	350	29.2	S3	280	20.9		
1330	S4	400	29.0	S3	290	18.8		
1340	S5	400	29.2	S0	290	17.0		
1350	S4	390	28.9	S2	300	14.6		
1400	S8	450	29.0	S2	300	11.6		
1410	S6	430	28.9	S2	310	15.7		
1420	S5	350	29.1	S1	300	20.5		
1430	S5	470	29.0	S1	310	18.6		
1440	S5	340	29.0	S2	320	18.0		
1450	S4	470	29.0	S0	300	27.3		
1500	S5	400	28.9	S1	300	27.0		
1510	S5	400	28.9	S2	290	21.4		
1520	S0	300	29.1	S0	260	20.4		
1530	S1	440	29.1	S0	290	20.1		
1540	S2	500	29.0	S1	300	16.5		
1550	S1	450	29.0	S2	300	17.1		
1600	S3	460	28.9	S1	300	16.2		
1610	S2	450	29.0	S2	310	18.8		
1620	40	10	29.5	45	250	20.0		
1630	S0	400	29.0	S0	350	25.5		

f14

32

7/23/96

SAGOLA E-TUBE DATA SHEET

CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1640	51	350	29.1	52	350	21.8		
1650	50	370	29.0	50	340	20.0		
1700	54	400	29.0	50	330	20.6		
1710	55	360	28.9	50	330	19.8		
1720	54	400	29.2	50	310	25.9		
1730	51	360	29.0	50	320	22.8		
1740	50	450	29.0	50	320	21.0		
1750	54	430	29.0	50	330	22.5		
1800	55	420	29.1	50	320	22.9		
Fluor 1810	25	10	29.8	25	10	20.0		
1820	54	390	28.4	50	320	27.4		
1830	53	400	29.0	50	310	21.8		
1840	55	400	29.0	50	300	23.9		
1850	50	350	29.0	50	290	22.5		
1900	50	300	29.1	52	300	24.1		
1910	54	430	28.9	52	300	23.4		
1920	49	190	29.6	49	200	26.0		
1930	52	400	28.7	51	300	23.9		
1940	50	290	28.9	51	300	21.5		
1950	51	310	28.9	51	300	21.3		
2000	52	310	29.0	51	300	21.2		
2010	54	350	29.0	51	300	24.0		
2020	55	370	29.0	51	300	20.9		
2030	55	400	29.0	51	300	22.6		
2040	54	400	28.5	51	310	22.1		
Fluor 2050	45	150	29.3	20	100	22.2		
2100	54	450	28.7	51	300	27.1		
2110	54	460	29.2	51	300	24.7		
2120	53	450	29.1	51	300	25.5		
2130	55	450	29.0	51	300	16.0		
2140	56	480	29.0	50	300	14.2		
2150	54	450	29.0	52	300	16.6		
2200	56	500	29.0	52	300	17.7		

7/23/96

SAGOLA E-TUBE DATA SHEET

SURFACE/CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1130	45	150	29.1	15	50	29.9		
1140	50	290	29.0	49	270	29.1		
1150	54	340	29.0	50	280	28.9		
1200	53	350	29.1	50	290	29.1		
1210	53	360	29.0	54	320	29.0		
1220	50	360	29.2	54	280	29.1		
1230	53	360	28.9	55	280	29.0		
1240	53	350	29.0	52	300	29.1		
1250	53	320	29.0	55	320	29.0		
1300	55	300	29.1	54	350	29.1		
1310	52	350	29.0	52	300	29.1		
1320	53	350	29.0	54	300	29.1		
1330	10	10	30.0	20	10	29.8		
1340	50	210	29.2	50	280	29.1		
1350	51	320	28.9	55	300	28.9		
1400	53	370	29.0	54	350	28.9		
1410	52	340	29.0	52	290	28.9		
1420	55	350	29.1	52	300	29.1		
1430	54	350	29.2	54	360	29.0		
1440	50	300	29.1	48	150	29.4		
1450	55	380	29.0	54	280	29.8		
1500	53	320	29.1	53	280	29.0		
1510	53	350	29.0	55	300	29.1		
1520	54	350	29.1	55	320	29.0		
1530	53	310	29.0	55	300	29.0		
1540	50	350	28.9	53	300	29.0		
1550	55	370	29.0	55	320	28.9		
1600	55	400	29.1	55	280	29.0		
1610	52	230	29.3	52	400	29.1		
1620	52	310	28.4	55	370	28.8		
1630	54	310	29.0	54	320	29.1		

34

7/23/96

SAGOLA E-TUBE DATA SHEET

SURFACE/CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1640	S5	350	29.1	S5	300	29.0		
1650	S8	300	28.9	S4	300	29.0		
1700	S3	310	29.1	S3	300	29.1		
1710	S6	390	29.0	S4	300	28.9		
1720	S5	410	29.0	S2	300	29.0		
1730	S7	300	29.1	S3	320	28.9		
1740	S4	380	29.0	S0	100	29.5		
1750	S3	380	29.0	S0	320	28.6		
1800	S2	350	29.0	S2	300	28.9		
1810	S4	450	29.1	S0	340	28.9		
1820	S0	300	29.0	S0	310	29.0		
1830	S0	300	29.0	S0	300	29.0		
1840	S2	400	28.9	S2	300	29.0		
1850	S2	320	29.0	S2	350	29.0		
1900	S0	320	28.9	S2	310	29.1		
1910	S0	10	29.8	49	210	29.3		
1920	S5	360	28.1	S0	270	28.9		
1930	S3	300	29.0	S0	280	29.0		
1940	S1	200	29.0	S2	300	29.0		
1950	S5	350	29.1	S3	300	28.9		
2000	S4	340	29.0	S1	280	29.0		
2010	S4	300	29.0	S4	300	29.0		
2020	S2	310	29.1	S5	310	29.0		
2030	S2	300	29.1	S0	230	29.0		
2040	S2	310	29.0	S0	250	29.0		
2050	S0	400	29.0	S0	250	28.2		
2100	S5	380	28.9	S3	320	29.0		
2110	S5	360	29.0	S4	310	29.1		
2120	S3	370	28.9	S5	350	29.1		
2130	S3	400	29.1	S4	310	29.1		
2140	S4	400	29.1	S0	300	29.1		
2150	S2	410	29.0	S2	300	29.1		
2200	S3	430	29.0	S3	310	28.9		

FI-SL

UNIT 1 S/C E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel					
	TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)	No. 2 (S.)	INLET OUTLET		PSI	PSI	in H2O	in H2O								
10	kv	mA	KV	mA	deg. F	deg. F										
4	30	300	48	300	211	135	15	22	8	468.761	255.147	320	320	5	831	786

Recycle Water Solids % 12.82 13.09 Blow Off sec. 10: _____ 4: _____
 Recycle Water pH 8.4 8.1

UNIT 2 CORE E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel					
	TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)	No. 2 (S.)	INLET OUTLET		PSI	PSI	in H2O	in H2O								
10	kv	mA	KV	mA	deg. F	deg. F										
4	45	100	65	100	208	151	19	25	1	458.592	109.914	320	320	5		

Recycle Water Solids % 9.36 9.76 Blow Off sec. 10: _____ 4: _____
 Recycle Water pH 8.0 7.1

UNIT 3 SURFACE E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel					
	TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)	No. 2 (S.)	INLET OUTLET		PSI	PSI	in H2O	in H2O								
10	kv	mA	KV	mA	deg. F	deg. F										
4	55	230	50	300	212	152	17	20	1	402.575	392.835	320	320	6		

Recycle Water Solids % 9.69 9.69 Blow Off sec. 10: _____ 4: _____
 Recycle Water pH 8.4 8.0

		Surface	Core
DISPERSION TUBE DRAIN MAGNEHELIC:	10	<u>6.5</u>	<u>10</u>
	4	<u>6.5</u>	<u>4</u>

BLOW OFF LINE FLOW METERS (ON TOP OF BLOW DOWN TANK)

TOTAL GALLONS BLOWN DOWN		"AFTER" MINUS "BEFORE"		DRYER RUN TIME	
BEFORE	AFTER	S/C	CORE	S/C	CORE
S/C <u>6546</u>	S/C <u>6576</u>	S/C <u>6</u>	S/C <u>720</u>		
CORE <u>137346</u>	CORE <u>137741</u>	CORE <u>407</u>	CORE <u>720</u>		
SURFACE <u>112170</u>	SURFACE <u>112331</u>	SURFACE <u>161</u>	SURFACE <u>720</u>		

GALLONS PER MINUTE BLOWN OFF =	GALLONS BLOWN OFF	S/C	GPM
	DRYER RUN TIME	CORE	GPM
		SURFACE	GPM

CORE WET BIN FLOW METER	BEFORE	AFTER	TOTAL GALLONS LOST "AFTER" MINUS "BEFORE"
		<u>47"</u>	

COMMENTS:

OPERATOR W. C. PA / E. N. W. SHIFT NIGHTS CREW A DATE 7-23-96

UNIT 1 S/C E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM							Beginning & End of Shift on the Vessel				
	TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)		No. 2 (S.)		INLET	OUTLET	PSI	PSI								
	kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O		total gal.	total gal.	N.	S.			
10	52	400	53	270	202	137	16	25	7	469192	207902	29.0	29.0	3	8765	792
4	52	260	51	320	216	132	20	27	7	409905	207680	28.9	29.0	3	8486	796

Recycle Water Solids % 14.3 % 13.8 % Blow Off sec. 10: 41 4: 42
 Recycle Water pH 8.3 8.3

UNIT 2 CORE E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM							Beginning & End of Shift on the Vessel				
	TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)		No. 2 (S.)		INLET	OUTLET	PSI	PSI								
	kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O		total gal.	total gal.	N.	S.			
10	51	310	52	470	205	148	19	27	8	459128	109914	17.5	29.0	.2		
4	50	220	50	210	200	150	19	27	8	454235	109914	29.0	29.1	2		

Recycle Water Solids % 11.1 % 10.3 % Blow Off sec. 10: 42 4: 42
 Recycle Water pH 6.7 7.0

UNIT 3 SURFACE E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM							Beginning & End of Shift on the Vessel				
	TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)		No. 2 (S.)		INLET	OUTLET	PSI	PSI								
	kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O		total gal.	total gal.	N.	S.			
10	52	260	52	370	207	149	19	21	3	422921	262835	29.1	29.0	.3		
4	52	270	51	330	200	109	19	26	7	422989	25129	28.9	28.9	3		

Recycle Water Solids % 10.9 % 10.4 % Blow Off sec. 10: 24 4: 24
 Recycle Water pH 7.7 % 7.6

	Surface	Core
DISPERSION TUBE DRAIN MAGNEHELIC:	10 <u>5</u>	10
	4 <u>5</u>	4


BLOW OFF LINE FLOW METERS (ON TOP OF BLOW DOWN TANK)

	BEFORE	AFTER	"AFTER" MINUS "BEFORE"	DRYER RUN TIME
S/C	<u>6546</u>	<u>7889</u>	<u>1343</u>	<u>720</u>
CORE	<u>15721</u>	<u>138221</u>	<u>480</u>	<u>720</u>
SURFACE	<u>112331</u>	<u>162713</u>	<u>382</u>	<u>719</u>

GALLONS PER MINUTE BLOWN OFF = $\frac{\text{GALLONS BLOWN OFF}}{\text{DRYER RUN TIME}}$
 S/C 1.9 GPM
 CORE .7 GPM
 SURFACE .53 GPM

TOTAL GALLONS LOST "AFTER" MINUS "BEFORE"
 CORE WET BIN FLOW METER 570 260 190
 BLOW DOWN TANK LEVEL 49' 78'

COMMENTS:



SAGOLA DRYER RTO
7/23/96

1/23/96

SAGOLA DRYER RTO DATA SHEET

TIME 10 MINUTES	CHAMBER TEMPS.										INLET PRESS.	BURNERS			COMB. TEMP.	EXHAUST TEMP.	PRESS DROP	GAS USAGE
	#1	#2	#3	#4	#5	#6	#7	#8	#1	#2		#3						
1150	383	384	358	395	410	354	388	360	152	1539	1530	1516	215	15.6	869			
1140	375	386	358	389	421	351	389	363	150	1536	1522	1513	257	16.0	985			
1150	378	387	360	389	419	381	388	364	151	1531	1512	1499	254	15.6	1064			
1200	382	393	352	400	412	350	394	355	152	1515	1518	1498	254	15.7	5782			
1210	378	390	360	390	421	351	390	366	152	1507	1534	1515	256	15.7	1348			
1220	385	393	353	401	411	352	395	356	153	1527	1520	1499	251	15.6	2670			
1230	382	389	361	392	417	353	389	367	153	1523	1526	1507	260	15.9	2389			
1240	384	395	352	401	411	351	395	357	154	1525	1526	1501	251	15.7	3441			
1250	387	392	354	399	409	353	393	361	154	1528	1523	1504	258	15.7	2512			
1300	387	390	359	397	409	353	391	363	153	1527	1525	1506	247	15.7	3389			
1310	387	391	356	399	407	352	393	360	155	1533	1536	1507	256	15.9	3576			
1320	380	390	360	389	417	350	390	368	155	1523	1528	1509	264	15.9	1067			
1330	380	391	359	389	416	350	390	369	155	1519	1520	1504	256	15.7	1653			
1340	384	395	351	399	408	348	395	358	156	1533	1544	1509	247	15.7	1069			
1350	384	394	351	398	406	349	393	358	154	1539	1540	1522	256	15.8	906			
1400	377	397	351	392	412	345	394	361	154	1534	1530	1515	263	16.0	829			
1410	385	390	353	396	403	349	391	359	155	1537	1527	1510	255	15.7	925			
1420	376	395	354	389	413	346	392	363	156	1533	1546	1515	261	15.6	955			
1430	382	388	359	390	406	350	388	366	157	1547	1537	1526	265	15.9	946			
1440	377	396	354	390	411	345	393	362	156	1550	1562	1531	263	16.0	942			
1450	385	389	355	394	401	350	390	360	156	1549	1561	1510	255	15.7	945			
1500	385	391	353	397	400	349	391	358	155	1546	1558	1521	256	15.7	948			
1510	377	395	354	390	411	345	392	363	156	1542	1556	1522	253	15.7	903			
1520	383	389	358	392	404	350	389	365	156	1556	1568	1538	261	16.1	731			
1530	384	395	351	400	402	347	393	367	157	1557	1570	1532	252	15.6	924			
1540	385	392	355	398	401	350	391	361	157	1555	1566	1532	250	15.9	975			
1550	380	392	360	390	410	348	390	368	157	1557	1568	1531	257	15.8	1033			
1600	386	393	356	399	401	350	391	362	156	1555	1567	1534	247	15.9	984			
1610	385	392	356	397	401	350	391	361	154	1551	1562	1529	246	15.7	852			
1620	384	391	357	395	401	350	390	362	153	1550	1560	1527	256	16.0	915			
1630	382	391	360	390	407	349	389	367	154	1545	1557	1526	248	15.7	867			
1640	380	391	360	390	407	349	389	367	155	1551	1562	1528	255	16.1	932			
1650	381	401	350	400	405	347	396	357	155	1554	1568	1537	259	16.0	892			
1700	377	401	355	392	412	346	394	363	155	1560	1572	1540	260	15.9	912			

SAGOLA DRYER RTO DATA SHEET

TIME 10 MINUTES	CHAMBER TEMPS.										INLET PRESS.	BURNERS			COMB TEMP.	EXHAUST TEMP.	PRESS. DROIP	GAS USAGE
	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10		#1	#2	#3				
1710	384	398	352	402	402	349	395	359	1564	1576	1555	1540	248	15.7	957			
1720	384	401	351	402	404	348	396	359	1552	1566	1550	1532	255	15.7	984			
1730	387	397	357	401	403	353	392	365	1567	1577	1555	1542	260	16.1	961			
1740	387	396	361	398	405	353	391	369	1569	1582	1562	1555	251	15.5	864			
1750	384	406	353	403	409	349	399	362	1565	1578	1564	1546	261	15.9	872			
1800	388	398	362	399	406	354	393	370	1573	1584	1564	1555	261	16.2	914			
1810	388	397	362	400	405	354	392	369	1559	1570	1547	1540	259	16.1	1023			
1820	381	400	360	393	410	350	392	370	1530	1540	1518	1504	254	16.0	1279			
1830	378	401	356	392	411	347	393	366	1511	1514	1507	1487	248	16.2	9530			
1840	377	399	354	391	409	347	390	368	1534	1534	1537	1519	251	16.0	4674			
1850	384	397	353	399	398	348	390	359	1525	1528	1527	1506	257	16.0	3733			
1900	378	397	356	390	406	347	388	368	1520	1536	1537	1518	260	15.4	2712			
1910	376	405	349	395	405	344	394	362	1520	1528	1523	1501	266	15.8	1533			
1920	379	399	351	404	407	346	390	368	1544	1556	1550	1524	255	15.8	974			
1930	380	407	349	399	403	346	395	362	1557	1568	1556	1535	248	15.6	964			
1940	381	399	358	397	404	350	388	371	1559	1569	1555	1573	253	15.5	1074			
1950	385	403	350	400	397	349	394	361	1560	1572	1555	1538	249	15.3	979			
2000	384	407	349	400	399	347	394	361	1555	1568	1556	1537	255	15.3	972			
2010	379	404	356	390	406	348	390	370	1567	1580	1568	1533	257	15.5	985			
2020	378	406	354	391	406	347	391	368	1572	1582	1564	1553	258	15.3	1003			
2030	386	404	350	400	396	350	392	362	1571	1581	1565	1550	251	15.3	1024			
2040	385	399	358	395	399	352	389	369	1582	1591	1577	1563	256	15.8	1022			
2050	379	408	353	394	405	347	394	366	1578	1586	1568	1557	259	15.8	1023			
2100	378	408	355	393	406	348	393	368	1581	1590	1569	1559	256	15.8	1053			
2110	386	400	358	398	397	353	390	368	1585	1586	1567	1555	258	16.1	1051			
2120	382	402	359	393	404	351	390	372	1568	1577	1563	1545	255	15.9	997			
2130	387	402	357	401	397	354	392	366	1562	1571	1551	1539	257	15.9	1013			
2140	382	412	351	402	403	349	398	364	1551	1560	1544	1529	249	15.9	1046			
2150	389	405	355	404	397	353	395	364	1541	1549	1530	1513	255	15.5	1041			
2200	381	414	352	402	404	349	398	365	1544	1553	1536	1521	246	15.5	1002			

RTO LOG SHEET

Wheelabrator Clean Air Systems

Huntington Energy Systems RTO

DATA SHEET

LP Sagola (Dryer)

rev.3, DHS 4/1/96

Regenerative Thermal Oxidizer

Date	7-23-96	7-23-96	Fill out data column once a shift, attach final sheet with chart recorder sheet; submit to Environmental
Time	10:00 AM	4:00 PM	
Burner S.P.	1540	1540	Comments
Bnr #1 temp	1583	1555	(Note anything out of the ordinary)
Bnr #1 out	1.5	1.1	
Bnr #2 temp	1596	1567	
Bnr #2 out	5.8	6.6	
Bnr #3 temp	1577	1545	
Bnr #3 out	6.2	6.1	
Inlet temp	155	156	
Chamber temp	1573	1537	
Exhaust temp	251	253	
RTO diff press	15.9	15.8	
#1 VFD Amps	574	573	
#1 VFD RPM	1374	1361	
#2 VFD Amps	614	621	
#2 VFD RPM	1410	1392	
PM setpoint	1.0	1.0	
PM out	.98	.82	
Cbr #1 B.O. temp	370	380	
Cbr #2 B.O. temp	376	393	
Cbr #3 B.O. temp	353	360	
Cbr #4 B.O. temp	380	390	
Cbr #5 B.O. temp	414	409	
Cbr #6 B.O. temp	348	349	
Cbr #7 B.O. temp	377	389	
Cbr #8 B.O. temp	357	368	
#1 Fan brg #1 temp	121	126	
#1 Fan brg #2 temp	114	120	
#2 Fan brg #1 temp	125	129	
#2 Fan brg #2 temp	110	112	
#1 Motor brg #1 temp	106	121	
#1 Motor brg #2 temp	105	91	
#2 Motor brg #1 temp	127	96	
#2 Motor brg #2 temp	100	89	
Dryer #1 RTO/ATMOS	RTO	RTO	
Dryer #2 RTO/ATMOS	RTO	RTO	
Dryer #3 RTO/ATMOS	RTO	RTO	
Chamber Prg Fan	ON	ON	
Total gas flow	966	929	
BTUE flow	0	0	

41

RTO Log SHEET

Wheelabrator Clean Air Systems

Wilmington Energy Systems RTO

DATA SHEET

W.S. DHS 4/1/96

LP Sagola (Dryer)

Regenerative Thermal Oxidizer

Date	7-23-96		Fill out data column once a shift, attach final sheet with chart recorder sheet; submit to Environmental
Time	10:00	4:00	
Burner S.P.	1540	1540	<p>Comments (Note anything out of the ordinary)</p>
Burner #1 temp	1542	1548	
Burner #1 out	2.0	0.2	
Burner #2 temp	1551	1551	
Burner #2 out	5.8	4.4	
Burner #3 temp	1535	1537	
Burner #3 out	2.0	2.6	
Inlet temp	155	150	
Chamber temp	1524	1513	
Exhaust temp	249	252	
RTO diff press	15.5	15.8	
#1 VFD Amps	585	533	
#1 VFD RPM	1363	1288	
#2 VFD Amps	566	507	
#2 VFD RPM	1342	1306	
FM setpoint	1.0	1.0	
FM out	68.1	64.7	
Cbr #1 B.O. temp	382	366	
Cbr #2 B.O. temp	408	384	
Cbr #3 B.O. temp	360	333	
Cbr #4 B.O. temp	395	380	
Cbr #5 B.O. temp	409	375	
Cbr #6 B.O. temp	351	335	
Cbr #7 B.O. temp	394	380	
Cbr #8 B.O. temp	373	350	
#1 Fan brg #1 temp	121	117	
#1 Fan brg #2 temp	85	84	
#2 Fan brg #1 temp	125	112	
#2 Fan brg #2 temp	85	84	
#1 Motor brg #1 temp	113	108	
#1 Motor brg #2 temp	107	102	
#2 Motor brg #1 temp	117	111	
#2 Motor brg #2 temp	100	95	
Dryer #1 RTO/ATMOS	Rto	Rto	
Dryer #2 RTO/ATMOS	Rto	Rto	
Dryer #3 RTO/ATMOS	Rto	Rto	
Chamber Prg Fan	on	on	
Total gas flow	1013	7714	
STUE flow	0	6055	
	7701	7701	

Bundle Height Parameters

heights

Board Size	Pieces / Bundle	Target Thickness	Target Hgt.	Target Wgt.
1/4"	120	0.260	31 1/4"	3286
1/4"	150	0.260	39"	4108
3/8"	100	0.380	38"	4003
7/16"	66	0.380	28 3/4"	2932
7/16"	90	0.435	39 1/8"	3999
15/32"	82	0.485	39 3/4"	4232
1/2"	66	0.510	30 5/8"	3100
1/2"	80	0.510	40 3/4"	4134
19/32" SE	65	0.595	38 5/8"	3981
19/32" HY	55	0.610	33 1/2"	3418
5/8" SE	40	0.620	24 3/4"	2612
23/32" SE	55	0.700	38 1/2"	3850
23/32" HY	45	0.730	32 7/8"	3285
7/8" HY	38	0.890	33 7/8"	3389
1-1/8" SE	36	1.085	39"	3854
1-1/8" HY	30	1.110	33 3/8"	3286

Notes:

If the bundles heights are running plus or minus 3/8" from these figures, please notify the Quality Control Department and the Shift Forman.

6
7/23/9

If the bundles weights are plus or minus 100 pounds from these figures, please notify the Quality Control Department and the Shift Forman.

U Grade: Use normal piece count, edge seal, and 2 green stripes with the stencil on each side of the unit. Stencil the thickness on the lower right hand corner of the unit face, place tag close to bottom, and cover with plastic.

E Grade: 80 piece units thru 1/2", 50 piece units for 19/32 and 23/32, and 40 piece units for 7/8" and above. No edge seal, and 2 black stripes with the thickness logo on the lower right hand corner of the unit face. Place tag close to the bottom, and cover with plastic.

Bundle Height Data

Size		Size		Size		Size		Size		Size		Size	
No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height
3	35 1/4												
6	39 1/4												
9	39 1/4												
12	39 1/4												
15	39 1/4												
18	39 1/4												
21	40 3/8												
24	40 3/8												
27	40 3/8												
30	40 3/8												
33	40 3/8												
36	40 3/8												
39	40 3/8												
42	40 3/8												
45	40 3/8												
48	40 3/8												
51	40 3/8												
54	40 3/8												
57	40 3/8												
60	40 3/8												
63	40 3/8												
66	40 3/8												
69	40 3/8												
72	40 3/8												
75	40 3/8												
78	40 3/8												
81	40 3/8												
84	40 3/8												
87	40 3/8												
90	40 3/8												
93	40 3/8												
96	40 3/8												
99	40 3/8												
102	40 3/8												
105	40 3/8												
108	40 3/8												
111	40 3/8												
114	40 3/8												
117	40 3/8												
120	40 3/8												

EPA Data

Size	Time	Pieces	Height	Weight
7/16	0716	70	39 1/4	4201
7/16	0800	50	41	4136
7/16	0819	90	39 1/4	4177
7/16	0831	90	39 1/4	4172
7/16	0845	70	39 1/4	4191
7/16	0907	90	39 1/4	4188
7/16	1031	90	40 3/8	4515
7/16	1052	70	40 3/8	4526
7/16	1102	90	40 3/8	4530
7/16	1115	90	40 3/8	4591
7/16	1130	70	40 3/8	4532
7/16	1150	70	40 3/8	4570
7/16	1215	90	40 3/8	4560
7/16	1230	90	40	4554
7/16	1245	50	40 3/8	4516
7/16	1300	90	39 1/4	4558
7/16	1315	90	40	4467
7/16	1330	90	40	4471
7/16	1345	90	39 1/4	4491
7/16	1415	90	39 1/4	4455
7/16	1445	90	40 3/8	4460
7/16	1500	90	40 3/8	4533
7/16	1515	90	39 1/4	4450
7/16	1533	90	40	4452
7/16	1550	90	40 3/8	4521
7/16	1615	90	40 3/8	4515
7/16	1633	90	40 3/8	4491
7/16	1653	90	40	4486
	1711	90	40	4497
	1730	90	40	4492
		90		
		90		
		90		

43

Bundle Height Parameters w/ weights

Standard Size	Pieces / Bundle	Target Thickness	Target Bcl. Height	Target Bcl. Weight
1/4"	120	0.260	31 1/4"	3286
1/4"	150	0.260	39"	4108
3/8"	100	0.380	38"	4003
7/16"	66	0.380	28 3/4"	2932
7/16"	90	0.435	39 1/8"	3999
15/32"	82	0.485	39 3/4"	4232
1/2"	66	0.510	30 5/8"	3100
1/2"	80	0.510	40 3/4"	4134
19/32" SE	65	0.595	38 5/8"	3981
19/32" HY	55	0.610	33 1/2"	3418
5/8" SE	40	0.620	24 3/4"	2612
23/32" SE	55	0.700	38 1/2"	3850
23/32" HY	45	0.730	32 7/8"	3285
7/8" HY	38	0.890	33 7/8"	3389
1-1/8" SE	36	1.085	39"	3854
1-1/8" HY	30	1.110	33 3/8"	3286

Notes: 7/23/91

If the bundles heights are running plus or minus 3/8" from these figures, please notify the Quality Control Department and the Shift Forman.

If the bundles weights are plus or minus 100 pounds from these figures, please notify the Quality Control Department and the Shift Forman.

U Grade: Use normal piece count, edge seal, and 2 green stripes with the stencil on each side of the unit. Stencil the thickness on the lower right hand corner of the unit face, place tag close to bottom, and cover with plastic.

E Grade: 80 piece units thru 1/2", 50 piece units for 19/32 and 23/32, and 40 piece units for 7/8" and above. No edge seal, and 2 black stripes with the thickness logo on the lower right hand corner of the unit face. Place tag close to the bottom, and cover with plastic.

Bundle Height Data

Size	No.	Height	Size	No.	Height	Size	No.	Height	Size	No.	Height	Size	No.	Height
1/4"	3	40	1/4"	3	40									
1/4"	6	40	1/4"	6	40									
1/4"	9	40	1/4"	9	40									
1/4"	12	40	1/4"	12	40									
1/4"	15	40	1/4"	15	40									
1/4"	18	40	1/4"	18	40									
1/4"	21	40	1/4"	21	40									
1/4"	24	40	1/4"	24	40									
1/4"	27	40	1/4"	27	40									
1/4"	30	40	1/4"	30	40									
1/4"	33	40	1/4"	33	40									
1/4"	36	40	1/4"	36	40									
1/4"	39	40	1/4"	39	40									
1/4"	42	40	1/4"	42	40									
1/4"	45	40	1/4"	45	40									
1/4"	48	40	1/4"	48	40									
1/4"	51	40	1/4"	51	40									
1/4"	54	40	1/4"	54	40									
1/4"	57	40	1/4"	57	40									
1/4"	60	40	1/4"	60	40									
1/4"	63	40	1/4"	63	40									
1/4"	66	40	1/4"	66	40									
1/4"	69	40	1/4"	69	40									
1/4"	72	40	1/4"	72	40									
1/4"	75	40	1/4"	75	40									
1/4"	78	40	1/4"	78	40									
1/4"	81	40	1/4"	81	40									
1/4"	84	40	1/4"	84	40									
1/4"	87	40	1/4"	87	40									
1/4"	90	40	1/4"	90	40									

7/16 EPA Data

Size	Time	Pieces	Height	Weight
7/16	1917	90	40 1/2	436
7/16	1934	90	40 3/4	441
7/16	1947	90	40 1/2	450
7/16	2006	90	40 1/2	496
7/16	2026	90	40	4438
7/16	2044	90	40 1/2	4523
7/16	2109	90	40	4561
7/16	2117	90	40 1/2	4541
7/16	2138	90	40 1/2	4559
7/16	2168	90	40 3/4	4496
7/16	2224	90	40 1/2	4514
7/16	2314	90	40 1/2	4541
7/16	2400	90	40	4469
7/16	2431	100	38	4145
7/16	2346	80	40 1/2	4154
7/16	2411	80	40 3/4	4124
7/16	2514	80	40 1/2	4186

44

DRYER JULY 24th, 1996

HCHO

DATA TIME	START=	17:10	END=	18:28	HOURS=	1.30
	START=	19:15	END=	20:20	HOURS=	1.08
	START=	20:40	END=	21:44	HOURS=	<u>1.07</u>
				TOTAL=		3.45

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
per/peice 46.15
per/ 8' x 24' 276.93

4153.9 lb= average
bundle weight
90 piece units

PLANT PRODUCTION RATE

3.45 =hours during testing
65 =pressloads
780 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
149,760 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
174,725 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
216,005 =lbs of finished product (boards produced x weight of finished board)
62,610 =lbs of finished product per hour (lbs of finished product / hours)
31.31 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

8 =SURFACE fuel calibration in pounds per count
1,987 =SURFACE counts during testing hours
15,896 =SURFACE lbs of fuel burned during testing
3.45 =hours during testing
4,608 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.30 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8,500 =estimated BTU content per pound of dry fuel,
39.2 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
793 =average inlet temperature
36.35 =average incoming moisture percent
6.40 =average dry moisture percent

CORE

7.96 =CORE fuel calibration in pounds per count
1,769 =CORE counts during testing hours
14,081 =CORE lbs of fuel burned during testing
3.45 =hours during testing
4,082 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.04 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8,500 =estimated BTU content per pound of dry fuel,
34.7 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
973 =average inlet temperature
24.23 =average incoming moisture percent
6.77 =average dry moisture percent

SURFACE/CORE

7.42 =SURFACE/CORE fuel calibration in pounds per count
1,900 =SURFACE/CORE counts during testing hours
14,098 =SURFACE/CORE lbs of fuel burned during testing
3.45 =hours during testing
4,086 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.04 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8,500 =estimated BTU content per pound of dry fuel,
34.7 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
891 =average inlet temperature
36.35 =average incoming moisture percent
5.93 =average dry moisture percent

DRYER THROUGHPUT RATE

12,775 =Total pounds of fuel burned per hour in Core, Surface and Surface/Core Dryers
62,610 =lbs of finished product per hour (lbs of finished product / hours)
75,385 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
3,295 = weight of trim per hour at 5.0% of finished product
9,480 =weight of screened fines per hour (total fuel - trim)
12.58% =resulting loss to fines as percentage of dryer throughput

E-TUBE/RT0 JULY 24th, 1996

HCHO

DATA TIME	START=	17:10	END=	18:28	HOURS=	1.30
	START=	19:15	END=	20:20	HOURS=	1.08
	START=	20:40	END=	21:44	HOURS=	1.07
					TOTAL=	3.45

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
 per/peice 46.15
 per/ 8' x 24' 276.93

4153.9 lb= average
 bundle weight
 90 piece units

PLANT PRODUCTION RATE

- 3.45 =hours during testing
- 65 =pressloads
- 780 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
- 149,760 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
- 174,725 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
- 216,005 =lbs of finished product (boards produced x weight of finished board)
- 62,610 =lbs of finished product per hour (lbs of finished product / hours)
- 31.31 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 8 =SURFACE fuel calibration in pounds per count
- 1,987 =SURFACE counts during testing hours
- 15,896 =SURFACE lbs of fuel burned during testing
- 3.45 =hours during testing
- 4,608 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.30 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 39.2 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 793 =average inlet temperature
- 36.35 =average incoming moisture percent
- 6.40 =average dry moisture percent

CORE


- 7.96 =CORE fuel calibration in pounds per count
- 1,769 =CORE counts during testing hours
- 14,081 =CORE lbs of fuel burned during testing
- 3.45 =hours during testing
- 4,082 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.04 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 34.7 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 973 =average inlet temperature
- 24.23 =average incoming moisture percent
- 6.77 =average dry moisture percent

SURFACE/CORE

- 7.42 =SURFACE/CORE fuel calibration in pounds per count
- 1,900 =SURFACE/CORE counts during testing hours
- 14,098 =SURFACE/CORE lbs of fuel burned during testing
- 3.45 =hours during testing
- 4,086 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.04 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 34.7 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 891 =average inlet temperature
- 36.35 =average incoming moisture percent
- 5.93 =average dry moisture percent


DRYER THROUGHPUT RATE

- 12,775 =Total pounds of fuel burned per hour in Core, Surface and Surface/Core Dryers
- 62,610 =lbs of finished product per hour (lbs of finished product / hours)
- 75,385 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 3,295 = weight of trim per hour at 5.0% of finished product
- 9,480 =weight of screened fines per hour (total fuel - trim)
- 12.58% =resulting loss to fines as percentage of dryer throughput



SAGOLA PRESS
7/24/96
0700 - 1900

47



SAGOLA PRESS
 7/24/96
 1900 - 0700

48

SUPERVISOR Steve J SHIFT D CREW 3 DATE 7-21-96

SHIFT OPERATING REPORT

PRESS OPERATION

Minutes Downtime

LINE SPEED	FROM	TO	THICKNESS	PRESS LOADS	3/8" FOOTAGE	Minutes Downtime		
						M	E	O
93	7:00	7:00	7/16	215	577,937	22		
TOTAL				215	577,937	22		

NATURAL GAS METER READINGS
(taken end of the shift)

MAIN	<u>0127447300</u>
PRESS RTO	<u>59856420</u>
DRYER RTO	<u>14927880</u>
GEKA	<u>6323 9810</u>
S DRYER	
C DRYER	
S/C DRYER	

Dryer Lamp Test (OK)	
Surface Dryer Fan Load	<u>91</u>
Core Dryer Fan Load	<u>93</u>
Surf/Core Dryer Fan Load	<u>87</u>
#1 Baghouse Pressure	
#2 Baghouse Pressure	
Surface Wet Bin Volume*	<u>45</u>
Core Wet Bin Volume*	<u>40</u>
Surf/Core Wet Bin Volume*	<u>40</u>
Surface Dry Bin Volume*	<u>72</u>
Core Dry Bin Volume*	<u>FWD</u>
Laidig Bin	<u>502</u>

GEKA EFB	BED KV	ION KV	ION MA	EFB - P	BH - P
	<u>10</u>	<u>21</u>	<u>1.7</u>	<u>3.6</u>	<u>1.8</u>

FLAKER RUN HOURS

#1 T.LF	#2 T.LF

BARK % MOISTURE	FUEL % MOISTURE
	<u>2.89</u>
	<u>GRECONS 5.3 c.2 1/2</u>

LOG COUNT

#1 6224 #2 4167 = 10,391
TOTAL

BARK FUEL COUNT: A 252 B 252

DRYER OPERATION

	Dry Fuel Usage Lbs.	Gas Usage Hrs.	Sust Gas Usage Hrs.	Average Inlet Temp	Running Time Mins	Ave. Wet Moisture	Ave. Dry Moisture
Surface	<u>6607</u>	<u>0</u>	<u>0</u>	<u>836</u>	<u>720</u>	<u>46.0</u>	<u>7.2</u>
Core	<u>5821</u>	<u>0</u>	<u>201</u>	<u>995</u>	<u>720</u>	<u>44.2</u>	<u>7.1</u>
S/Co	<u>6609</u>	<u>0</u>	<u>0</u>	<u>950</u>	<u>720</u>	<u>43.8</u>	<u>7.2</u>

REMARKS: LEFT PIP Saw Phased 15min - FCS PHASED 5x 6min

SUPERVISOR DAVE SCARTE SHIFT 2nd CREW 0 DATE 7-24-96

SHIFT OPERATING REPORT

PRESS OPERATION						Minutes Downtime		
SPEED	FROM	TO	THICKNESS	PRESS LOADS	3/8" FOOTAGE	M	E	O
14	2:00	10:55	7/16	20	182,165	3	1	
18	10:55	12:50	19/32	25	91,198	5		
21	12:50	5:39	1/2	75	230,394	9		
21	5:39	2:00	15/32	22	63,360			
TOTAL				192	573,117	17	1	-

Dryer Lamp Test (OK)	OK
Surface Dryer Fan Load	90.9
Core Dryer Fan Load	92.5
Surf/Core Dryer Fan Load	88.1
Baghouse Pressure	OK
Baghouse Pressure	OK
Surface Wet Bin Volume*	60
Core Wet Bin Volume*	60
Surf/Core Wet Bin Volume*	75
Surface Dry Bin Volume*	50
Core Dry Bin Volume*	58
Log Bin	55-60

NATURAL GAS METER READINGS	
(taken end of the shift)	
MAIN	0127717200
PRESS RTO	59920720
DRYER RTO	14997580
GEKA	03239810
S DRYER	
C DRYER	
S/C DRYER	

GEKA EFB	BED KV	ION KV	ION MA	EFB - P	BH - P
	9.4	21	1.6	4.1	1.9

FLAKER RUN HOURS	
T.L.F	#2 T.L.F
384	417

BARK % MOISTURE	36.6%	FUEL % MOISTURE	1.9%
GRECONS		13	

LOG COUNT		
5177	#2 7364	= 12541
TOTAL		

BARK FUEL COUNT: A 232 B 232

DRYER OPERATION							
	Dry Fuel Usage Lbs.	Gas Usage Hrs.	Sust. Gas Usage Hrs.	Average Inlet Temp.	Running Time Mins	Ave. Wet Moisture	Ave. Dry Moisture
Surface	6549	8	140	1100°	720	41.8/45.2	6.7
Core	5530	8	273	1001°	720	44.4%	5.9
Surf/Core	6027	8	224	971°	720	42.9%	6.3

REMARKS: TESTED ALL GRECONS. SURF. FLOPPERS PLUS 7 MIN FLOS PLUS 4X 9 MIN.

2nd shift

DAILY PRODUCTION REPORT

DATE: JULY 24, 1998

DAY: WEDNESDAY

SCHED. NET
RUN RUN
HOURS HOURS
% RUN % PLANT
TIME CAP.

SHIFT	BOARD SIZE	PRESS LOADS	NO. OF PANELS	SURFACE FOOTAGE	3/8" FOOTAGE
7AM.	7/16"	215	15,480	495,360	577,937
TO	0	0	0	0	0
7PM.	0	0	0	0	0
	0	0	0	0	0
	0	0	0	0	0
B	0	0	0	0	0
CREW	0	0	0	0	0
SHIFT TOTAL					577,937

DAY	12.00	11.75	97.9%	147.6%
NIGHT	12.00	11.75	97.9%	146.4%
DAILY	24.00	23.50	97.9%	147.0%
WTD	139.50	137.00	98.2%	
MTD	625.75	573.50	91.7%	
YTD	4,708.00	4,438.00	94.3%	

FOREMAN	% PLANT	CAP
"A" M. MESSINA	132.0%	
"B" D. SPIGARELLI	140.0%	
"C" F. SHOQUIST	135.0%	
"D" D. DONATI	142.7%	

SHIFT	7/16"	70	5,040	161,280	188,165
7PM.	19/32"SE	25	1,800	57,600	91,198
TO	1/2"	75	5,400	172,800	230,394
7AM.	15/32"	22	1,584	50,688	63,360
D	0	0	0	0	0
CREW	0	0	0	0	0
SHIFT TOTAL					573,117

LOG CNT.	DAILY	WTD	MTD
A CREW	0	36,215	130,597
B CREW	10,391	27,409	153,709
C CREW	0	34,332	131,563
D CREW	12,541	29,045	156,355

DAILY	TOTAL	407	937,728	1,151,054
SHIFT TOTAL				
TOTAL	29,304	937,728	1,151,054	6,204,181
TOTAL				
TOTAL	26,052,796			
TOTAL				
TOTAL	192,224,589			


GAS USAGE (MCF)	DAY	MTD
SURFACE DRYER	0	17,499
CORE DRYER	0	0
S/C DRYER	0	0
GEKA	0	0
PRESS RTO	0	0
DRYER RTO	0	0
TOTAL		17,499

MTD 3/8" FOOTAGE					
1/4"	202,761	1/2"	4,325,269	23/32"SE	0
3/8"	85,248	19/32"SE	1,079,785	23/32"H	5,966,122
7/16"	11,773,779	19/32"H	164,156	7/8"H	295,676
15/32"	2,160,000	5/8"	0	1 1/8"	0

DOWNTIME DAY SHIFT B-CREW 15 MIN. RIP SAW PLUGGED.


NIGHT SHIFT D-CREW 18 MIN. MISC.

53




SAGOLA SURF. DRYER
 7/24/96
 0700-1900


54



SAGOLA SURF. DRYER
 7/24/46
 1900-0700
 55




SAGOLA CORE DRYER
 7/24/96
 0700 - 1900




SAGOLA CORE DRYER
 7/24/96
 1900-0700

57



SAGOLA SURF./CORE DRYER
 7/24/96
 0700 - 1900
 58



SAGOLA SURF/CORE DRY

7/24/96

1900 - 0700

59

7-24-96

SURFACE

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	ET. OUT
7:20	242.0	92	842	868	383	75	70-78		5.9	149
7:30	242.0	91	829	241.1	483	75	70-78		6.4	151
7:40	242.0	85	910	241.2	549	75	70-78		6.2	151
7:50	242.0	91	995	240.4	610	75	70-78		6.6	152
8:00	240	91	987	242.2	654	60	70-70		5.5	150
8:10	234.5	92	104	235.4	777	40	70-70		5.6	150
8:20	234.0	92	795	234.0	896	50	70-70		5.7	150
8:30	233.5	92	806	232.4	972	40	68-100		5.3	151
8:40	233.5	92	768	233.9	1057	40	68-70		5.7	150
8:50	233.5	92	718	224.3	1158	40	73-78	46.0	6.0	148
9:00	233.5	92	750	232.8	1252	45	74-70		5.6	149
9:10	233.5	92	816	231.1	1334	45	74-70		7.0	149
9:20	233.5	92	685	236.3	1438	40	74-70		5.3	146
9:30	233.5	92	676	236.5	1520	25	74-70		5.4	141
9:40	233.5	92	729	233.4	1587	40	74-70		6.4	144
9:50	233.5	92	663	233.9	1685	40	74-70		6.7	145
10:00	233.5	92	652	235.3	1763	40	74-70		6.5	146
10:10	233.5	92	708	231.8	1850	60	78-60	40.4	6.3	148
10:20	233.5	93	711	231.9	1955	80	78-60		6.8	149
10:30	233.5	93	704	233.5	2063	65	78-60		7.0	149
10:40	233.5	93	709	233.2	2191	75	70-65		6.4	149
10:50	233.5	93	731	233.3	2248	75	70-65		6.5	149
11:00	233.5	93	697	233.0	2370	65	70-65		7.0	148
11:10	233.5	93	678	234.0	2413	40	70-65		5.4	147
11:20	233.5	93	708	232.5	2513	40	70-65		6.5	149
11:30	233.5	93	753	232.6	2607	60	65-70	39.4	7.0	150
11:40	233.5	93	716	234.2	2702	60	65-70		6.5	149
11:50	233.5	93	733	233.6	2811	40	68-70		6.5	149
12:00	233.5	93	725	233.3	2896	40	68-70		6.8	149
12:10	233.5	93	820	232.4	2985	40	68-70		7.1	150
12:20	233.5	93	914	232.2	3108	60	68-70	34.4	7.3	151
12:30	233.5	93	816	233.4	3207	60	68-70		6.8	151
12:40	233.5	93	713	235.3	3292	65	68-70		6.3	149
12:50	233.5	93	732	233.2	3393	60	68-70		6.4	149
1:00	233.5	93	887	231.7	3496	60	68-70		6.3	152
1:10	233.5	93	941	234.5	3596	60	68-70		6.5	151
1:20	234.0	93	834	234.2	3707	60	68-70		6.3	149
1:30	234.0	93	855	234.6	3746	75	68-70		6.9	149
1:40	234.0	93	843	235.0	3793	75	68-70		6.5	150
1:50	234.0	90	966	232.6	3998	80	70-FULL		6.6	151
2:00	234	90	1115	233.9	4109	65	70-FULL	46.0	6.5	152
2:10	234	90	1155	232.9	4225	75	70-FULL		7.0	153
2:20	234	91	880	235.2	4373	85	70-FULL		6.8	150
2:30	234	90	1023	231.8	4517	70	70-FULL		7.0	152
2:40	234	87	1014	235.2	4599	75	70-FULL		7.0	151
2:50	234	87	955	237.6	4647	90	FULL-70		6.2	150
3:00	234	87	795	238.0	4737	85	FULL-70		6.0	149

60

SAGOLA DRYER DATA
(FUEL CALIB. LB/COUNT)

7-24-96

SURFACE											
Inlet Feet	TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	Outlet Temp
213	3:10	234.0	87	803	234.9	4833	80	73-FULL		6.1	142
214	3:20	234.0	87	797	235.0	4930	80	73-FULL	36.2	6.0	138
214	3:30	233.5	88	738	234.8	5012	80	73-FULL		6.3	150
213	3:40	233.5	92	758	230.8	5096	90	73-FULL		6.6	150
213	3:50	233.5	86	701	233.0	5180	80	73-FULL		6.4	148
214	4:00	233.5	70	693	235.2	5256	80	73-FULL		7.1	148
218	4:10	240.0	61	725	240.7	5313	60	73-FULL		6.1	142
220	4:20	240.0	61	687	240.3	5386	60	73-FULL		6.3	142
221	4:30	240.0	68	659	242.1	5470	80	73-FULL		5.7	142
220	4:40	240.0	72	737	235.8	5496	80	73-FULL		5.6	142
221	4:50	240.0	80	714	236.9	5575	80	73-FULL		6.1	144
221	5:00	240.0	83	704	238.0	5660	90	73-FULL		6.7	144
222	5:10	242.0	84	844	241.7	5745	90	73-FULL		6.8	144
223	5:20	242.0	86	921	244.3	5844	80	73-FULL		6.6	130
224	5:30	242.0	88	723	243.0	5932	80	73-FULL		6.3	151
223	5:40	241.0	88	833	242.4	6009	60	Full-Full		6.4	151
222	5:50	242.0	88	733	240.9	6095	60	Full-Full		6.2	151
220	6:00	239.5	88	678	240.1	6194	60	Full-Full		6.6	148
220	6:10	239.5	88	683	239.6	6264	80	Full-Full		6.4	148
220	6:20	239.5	88	712	238.4	6355	80	Full-Full		5.8	148
219	6:30	239.5	88	794	239.4	6422	80	Full-Full		6.0	148
219	6:40	237.0	89	830	236.7	6571	40	Full-70		5.6	151
218	6:50	242.0	92	1875	241.1	133	60	Full-70		6.3	151
217	7:00	242.0	92	1089	240.7	182	65	Full-70		6.5	151
218	7:10	239.0	92	1040	242.8	190	65	78-FULL		6.3	151
219	7:20	242.0	94	980	241.1	276	65	78-FULL	36.1	5.5	152
220	7:30	242.0	95	30	241.7	387	40	78-FULL		5.9	152
219	7:40	242.0	92	40	241.7	523	40	78-FULL		6.0	152
220	7:50	242.0	91	1825	242.3	564	40	78-FULL		5.9	152
221	8:00	242.5	94	684	243.5	675	40	Full-72		5.5	152
221	8:10	238.4	94	680	239.5	751	65	Full-72		6.2	152
219	8:20	238.4	94	861	237.4	813	65	Full-72		6.9	152
218	8:30	240.6	94	1080	240.0	936	65	Full-72		6.9	152
218	8:40	241.4	94	910	240.4	1023	65	Full-72		7.0	152
219	8:50	242.4	94	1004	243.2	1149	80	80-FULL		6.1	152
220	9:00	242.4	94	1230	242.9	1235	80	80-FULL	36.6	5.7	152
219	9:10	243.0	95	1172	242.2	1348	80	FW-FW		6.3	152
220	9:20	243.5	88	1039	240.7	1460	65	FW-FW		7.6	152
223	9:30	243.5	80	670	240.5	1540	50	FW-FW		7.2	152
224	9:40	243.5	65	645	252.3	1630	45	FW-FW		7.4	152
221	9:50	243.5	58	785	240.1	1710	50	FW-FW		7.3	152
218	10:00	243.5	50	584	244.4	1742	40	FW-FW	45.2	6.4	136
218	10:10	243.5	57	618	247.5	1799	40	FW-FW		6.3	136
220	10:20	245.7	60	689	244.7	1867	48	FW-FW		6.3	136
	10:30	245.7	60	708	245.5	1935	40	FW-FW			136
	10:40										

61

7-24-96

CORE

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
7:20	199.4	82	1144	202.6	303	50	70-78		7.0
7:30	197.0	82	991	196.4	344	75	70-78		6.5
7:40	197.0	83	1002	197.3	445	75	70-78		6.4
7:50	197.0	83	1087	196.4	500	55	70-78		6.3
8:00	197	83	1139	195.3	552	60	70-70		7.0
8:10	197	83	1050	196.2	657	50	70-70		7.3
8:20	197	82	1270	196.7	709	45	70-70		6.7
8:30	197	82	1115	198.0	844	45	68-100		7.4
8:40	197	82	872	200.9	917	45	68-90		6.5
8:50	197	82	860	194.6	994	45	73-78	46.0	6.8
9:00	197	82	997	195.1	1080	45	74-70		6.7
9:10	197	82	871	198.2	1145	60	74-70		7.2
9:20	197	82	987	196.6	1240	45	74-70		6.4
9:30	197	82	774	195.9	1218	45	74-70		6.5
9:40	197	82	821	197.4	1390	45	74-70		5.8
9:50	196	82	854	196.4	1475	45	74-70		7.1
10:00	196	82	699	197.8	1541	65	74-70		7.2
10:10	196	82	782	195.5	1616	65	78-60	40.4	6.7
10:20	196.2	83	826	195.1	1708	45	78-60		6.9
10:30	196.5	84	952	194.7	1809	55	78-60		7.2
10:40	196.5	84	824	196.1	1931	70	70-65		7.0
10:50	197.5	84	748	199.1	1982	70	70-65		6.9
11:00	195.8	84	774	199.1	2068	60	70-65		6.8
11:10	197.5	84	807	196.4	2128	60	70-65		6.7
11:20	197.5	84	873	196.4	2226	40	70-65		6.6
11:30	197.5	84	880	199.2	2312	40	65-70	39.4	7.0
11:40	196.5	86	768	194.9	2396	45	65-70		7.6
11:50	196.5	86	891	191.7	2495	60	68-70		8.2
12:00	196.5	86	1106	197.8	2580	40	68-70		6.3
12:10	196.5	86	1030	195.9	2665	40	68-70		8.8
12:20	197	86	1248	197.1	2782	40	68-70	34.4	8.0
12:30	197	86	856	200.7	2871	65	68-70		7.9
12:40	197	86	730	197.6	2942	60	68-70		7.0
12:50	197	86	956	196.8	3032	80	68-70		7.8
1:00	197	86	1156	191.6	3122	70	68-70		8.3
1:10	198	86	1211	197.6	3215	80	68-70		8.6
1:20	199.5	86	1138	199.2	3315	70	68-70		7.1
1:30	199.5	86	1131	195.0	3396	80	68-70		7.5
1:40	199.6	83	133	198.9	3490	80	68-70		7.0
1:50	197.0	83	702	198.1	3564	80	70-70		6.8
2:00	197	83	719	193.3	3647	75	70-70	46.0	6.6
2:10	195	83	986	189	3731	80	70-70		6.6
2:20	195	83	187	195	3857	75	70-70		6.7
2:30	195	83	1107	195.8	3982	F	70-70		6.8
2:40	196	81	1263	197.3	4056	F	70-70		7.0
2:50	197.5	81	1155	207.0	4096	F	Full-70		6.3
3:00	197.5	81	865	201.6	4169	75	Full-70		6.5

FT
6.5
154
153
152
154
153
154
154
153
154
154
153
150
151
151
151
151
151
149
149
148
148
149
151
151
151
150
150
153
150
150
154
149
148
150
156
154
152
155
150
147
148
153
151
153
153
151

62

SAGOLA DRYER DATA
(FUEL CALIB. LB/COUNT)

7-24-90

CORE											E-Tide Inlet Temp	E-Tide Outlet Temp
TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT			
210	3:10	197.5	81	1046	198.3	4246	80	73-FULL		6.5	136	
212	3:20	195.5	81	708	196.4	4324	FULL	73-FULL	36.2	6.9	148	
212	3:30	195.5	82	654	198.1	4389	80	73-FULL		6.6	145	
210	3:40	195.0	86	813	193.5	4456	60	73-FULL		7.7	145	
210	3:50	195.0	80	716	194.5	4523	80	73-FULL		7.5	147	
210	4:00	195.0	66	680	192.7	4588	60	73-FULL		6.7	148	
214	4:10	194.6	59	671	203.3	4635	80	73-FULL		5.8	147	
215	4:20	194.6	60	662	204.0	4709	80	73-FULL		6.0	147	
215	4:30	194.6	60	709	200.1	4787	80	73-FULL		6.2	146	
215	4:40	194.6	70	751	196.8	4815	90	73-FULL		6.3	147	
216	4:50	194.6	81	754	193.7	4888	75	73-FULL		7.0	147	
216	5:00	197.5	83	761	195.2	4961	80	73-FULL		7.3	147	
215	5:10	194.0	84	1187	197.5	5038	65	73-FULL		7.6	153	
215	5:20	194.0	78	1190	197.7	5124	80	73-FULL		6.9	153	
216	5:30	194.0	78	891	198.6	5196	60	73-FULL		7.1	147	
216	5:40	199.0	80	803	200.6	5269	60	FULL-FULL		7.9	147	
214	5:50	197.0	80	783	197.4	5348	80	FULL-FULL		6.4	148	
212	6:00	197.0	80	1073	194.2	5444	65	FULL-FULL		6.2	148	
211	6:10	197.0	80	730	193.9	5506	80	FULL-FULL		7.4	147	
213	6:20	197.0	80	833	198.7	5594	80	FULL-FULL		6.6	147	
212	6:30	197.0	80	947	197.2	5661	60	FULL-FULL		6.4	147	
212	6:40	197.0	80	715	197.0	5730	40	FULL-FULL		6.5	147	
214	6:50	197.0	81	744	196.8	5790	40	FULL-70		6.8	147	
213	7:00	197.0	87	804	196.2	103	40	FULL-70		6.4	147	
213	7:10	197.0	87	929	194.8	150	40	FULL-70		6.2	151	
214	7:20	197.0	91	679	194.8	227	40	78-FULL	36.1	6.5	148	
211	7:30	191.5	83	1049	192.7	322	40	78-FULL		5.8	147	
209	7:40	192.0	83	1083	191.1	441	40	78-FULL		6.1	147	
210	7:50	194.9	87	1182	196.4	498	40	78-FULL		6.7	153	
208	8:00	194.9	89	995	197.9	577	65	78-FULL		6.2	151	
207	8:10	192.2	94	1219	185.4	656	65	FULL-72		8.2	137	
206	8:20	192.0	94	1157	195.4	718	65	FULL-72		6.9	150	
208	8:30	194.0	94	1083	194.2	829	65	FULL-72		7.6	154	
208	8:40	194.5	94	1165	196.7	1961	70	FULL-72		6.6	151	
209	8:50	194.5	94	953	193.7	1007	80	80-FULL		6.4	147	
208	9:00	194.5	94	1238	193.3	1088	60	80-FULL	36.6	7.8	151	
208	9:10	194.5	94	1170	195.1	1192	50	FW-FW			153	
208	9:20	194.5	88	836	192.7	1282	65	FW-FW		6.4	151	
209	9:30	194.2	88	859	192.5	1360	60	FW-FW		6.3	137	
210	9:40	194.2	65	707	196.5	1441	45	FW-FW		6.4	147	
208	9:50	194.2	50	670	195.8	1539	50	FW-FW		7.2	143	
206	10:00	194.2	60	748	198.3	1569	60	FW-FW	45.2	5.7	147	
206	10:10	194.2	58	741	189.8	1631	40	FW-FW		6.3	147	
201	10:20	194.2	60	979	188.3	1688	40	FW-FW		7.2	148	
	10:30	194.2	60	728	194.4	1794	40	FW-FW				
	10:40											

7-24-96

SURFACE/CORE

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	E.T. OUTLET
7:20	205.6	75	945	212.7	149	50	70-78		6.2	135
7:30	226.6	83	791	232	1	60	70-78		6.3	134
7:40	226.5	84	832	228	360	60	70-78		5.3	136
7:50	226.5	87	1042	252.9	416	55	70-78		5.6	139
8:00	223.6	88	1159	227.5	484	60	70-70		5.5	140
8:10	222.5	89	1105	222.6	612	50	70-70		5.8	140
8:20	221.5	89	1252	219.8	757	45	70-70		6.2	140
8:30	221.5	88	1211	220.7	847	40	68-110		6.9	141
8:40	221.5	88	980	226.1	940	45	68-90		6.0	136
8:50	221.5	88	793	230.6	1030	45	73-78	46.0	6.2	129
9:00	214.1	88	871	214.5	1114	45	74-70		7.6	126
9:10	219.6	88	884	219.3	1191	60	74-70		6.9	135
9:20	222.5	88	807	225.0	1297	60	74-70		6.2	133
9:30	222.5	88	838	223.9	1388	40	74-70		6.5	135
9:40	222.5	88	846	226.6	1473	65	74-70		5.6	135
9:50	221.5	88	790	222.1	1568	45	74-70		7.0	135
10:00	221.5	88	820	221.3	1648	45	74-70		6.7	136
10:10	221.5	88	935	220.7	1738	65	78-60	40.4	7.7	137
10:20	223.0	89	846	223.8	1842	65	78-60		7.4	136
10:30	223	90	1010	223.6	1955	60	78-60		8.0	139
10:40	223.7	88	1149	222.6	2095	60	70-65		8.2	142
10:50	224.5	88	1132	226	2202	45	70-65		7.0	140
11:00	220.7	89	1226	226	2271	40	70-65		6.2	142
11:10	226.0	89	1115	224.4	2344	60	70-65		5.6	139
11:20	225.9	89	819	227.7	2449	45	70-65		6.1	135
11:30	225.9	89	861	226.7	2535	45	65-70	39.4	6.0	135
11:40	224.5	90	760	227.9	2617	60	65-70		6.2	135
11:50	224.5	90	1200	219.3	2727	40	68-70		7.6	141
12:00	225.7	90	1159	225.5	2821	40	68-70		6.2	142
12:10	225.0	90	1090	226.9	2915	40	68-70		5.1	140
12:20	224.0	90	949	223.1	3029	40	68-70	34.4	7.1	139
12:30	224.0	90	913	224.3	3127	40	68-70		7.6	139
12:40	226.0	90	1110	224.3	3219	60	68-70		7.7	141
12:50	226.5	90	1153	225.8	3332	65	68-70		6.8	141
1:00	226.5	90	1152	227.2	3442	65	68-70		7.0	141
1:10	226.5	90	1085	226.4	3544	80	68-70		7.0	140
1:20	226.5	90	1140	225.8	3649	90	68-70		7.0	143
1:30	226.5	90	1188	226.6	3762	80	68-70		6.6	143
1:40	227.0	88	1140	226.7	3887	80	68-70		6.4	142
1:50	226.0	86	1198	225.9	3989	80	70-FULL		6.9	142
2:00	226	86	1125	224.2	4075	80	70-FULL	46.0	7.0	142
2:10	226	86	1134	225.3	4199	70	70-FULL		6.2	141
2:20	224.5	86	1036	224.3	4328	80	70-FULL		6.7	139
2:30	224.5	86	1133	223.7	4428	70	70-FULL		6.7	142
2:40	225.0	84	1174	222.2	4578	F	FULL-70		6.8	142
2:50	225.0	82	1248	222.3	4634	F	FULL-70		6.1	141
3:00	228.2	82	1059	222.6	4726	80	FULL-70		7.6	141

64

SAGOLA DRYER DATA
(FUEL CALIB. LB/COUNT)

7-24-96

5-706
-alet
Temp

SURFACE/CORE

5-
outlet
Temp

	TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT	
221	3:10	227.0	82	1093	227.5	4816	80	73-FULL		6.0	131
220	3:20	226.0	82	821	224.3	4910	80	73-FULL	36.2	5.2	135
217	3:30	225.0	83	752	225.1	4929	80	73-FULL		5.6	135
216	3:40	224.0	87	849	222.3	5070	80	73-FULL		6.2	135
217	3:50	221.0	77	846	221.6	5149	65	73-FULL		6.2	135
221	4:00	220.6	66	825	221.1	5221	80	73-FULL		7.6	132
214	4:10	239.3	57	709	236.2	5273	90	73-FULL		6.7	138
246	4:20	257.2	59	800	258.3	5356	80	73-FULL		5.5	138
222	4:30	236.3	60	791	236.0	5446	65	73-FULL		5.2	138
213	4:40	230.0	70	752	230.9	5475	65	73-FULL		7.1	130
238	4:50	243.5	80	789	243.2	5562	90	73-FULL		5.6	130
222	5:00	229.0	81	792	229.0	5643	80	73-FULL		4.6	132
217	5:10	223.5	83	746	225.5	5716	65	73-FULL		4.9	132
214	5:20	222.0	87	764	221.5	5801	65	73-FULL		5.5	131
213	5:30	221.5	90	784	220.2	5876	65	73-FULL		6.5	133
213	5:40	221.5	90	765	220.4	5953	65	73-FULL		6.8	134
212	5:50	221.5	90	901	221.2	6041	80	FULL-FULL		6.4	130
214	6:00	221.5	90	1130	218.7	6158	65	FULL-FULL		7.0	139
214	6:10	221.5	90	949	220.7	6240	65	FULL-FULL		6.4	138
214	6:20	221.5	90	941	221.4	6337	40	FULL-FULL		6.7	140
215	6:30	221.5	90	1054	223.2	6416	40	FULL-FULL		6.2	137
216	6:40	221.5	90	966	222.8	6500	60	FULL-FULL		6.9	138
215	6:50	221.5	91	908	222.9	6569	40	FULL-70		6.2	138
214	7:00	221.5	91	980	219.2	6650	40	FULL-70		6.5	138
215	7:10	221.5	91	1067	220.7	6736	40	FULL-70		6.7	139
212	7:20	221.5	93	832	225.2	6820	30	78-FULL		5.7	135
218	7:30	223.8	95	754	227.1	6905	40	78-FULL		5.8	136
220	7:40	223.8	95	839	214.5	6990	60	78-FULL	36.1	5.3	136
210	7:50	223.8	91	963	224.4	7075	60	78-FULL		5.4	137
216	8:00	224.5	93	1023	223.2	7160	65	78-FULL		5.3	137
213	8:10	221.4	94	875	220.0	7245	65	FULL-72		5.9	137
211	8:20	220.4	94	959	219.7	7330	65	FULL-72		6.0	137
208	8:30	221.0	94	1079	221.3	7415	65	FULL-72		5.1	138
212	8:40	221.0	94	822	222.9	7500	70	FULL-72		4.6	136
208	8:50	220.3	94	896	217.9	7585	70	80-FULL		5.7	136
210	9:00	220.3	94	980	218.8	7670	80	80-FULL	36.6	5.8	136
205	9:10	220.3	95	847	218.7	7755	65	FW-FW			137
207	9:20	219.0	88	809	216.7	7840	80	FW-FW		7.3	136
208	9:30	219.0	88	870	219.0	7925	75	FW-FW		8.3	136
312	9:40	220.0	65	771	226.5	8010	60	FW-FW		6.7	136
305	9:50	222.8	50	784	234.0	8095	50	FW-FW		7.4	134
197	10:00	222.8	50	611	228.2	8180	40	FW-FW	45.2	7.9	137
205	10:10	222.8	57	728	210.6	8265	40	FW-FW		8.6	137
219	10:20	232.3	60	855	234.5	8350	30	FW-FW		7.9	137
	10:30	238.1	60	754	243.9	8435	40	FW-FW			137
	10:40										

65

URTEX OPERATIONS REPORT

LOUISIANA-PACIFIC CORPORATION SAGOLA MI

NAME Lundy

CREW D

SHIFT

DAY NIGHT

DATE 2-1-96

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE %	B.C. Furnace F°	ABB KENT Inlet F°	ABB KENT Outlet F°	GAS % VALVE	MOISTURE METER %	MOISTURE	
7:46	91	1	75	1310	826	241		6.7	5.0	
9:05	92		73	1316	759	234		7.4	6.2	
10:18	92	9	71	1315	679	231		7.9	7.9	
11:30	93	1	77	1350	757	233		8.4	8.2	
1:00	93	1	78	1320	868	232		7.5	7.9	
2:15	89		75	1260	1135	234		7.5	8.2	
					Avg- 836	234			6.7	7.2

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE %	B.C. Furnace F°	ABB KENT Inlet F°	ABB KENT Outlet F°	GAS % VALVE	MOISTURE METER %	MOISTURE	
7:41	82	7	66	990	996	196		6.9	6.5	
9:05	82		65	1080	981	197		6.6	6.8	
10:16	82	9	62	1090	820	193		7.2	6.8	
11:30	84		69	1060	850	199		7.0	6.2	
1:00	86	11	78	1050	1100	191		8.5	8.9	
2:15	82		76	1070	1214	192		8.0	7.4	
					Avg- 995	195			6.9	7.1

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE %	B.C. Furnace F°	ABB KENT Inlet F°	ABB KENT Outlet F°	GAS % VALVE	MOISTURE METER %	MOISTURE	
7:40	84	7	76	940	842	226		6.1	5.0	
9:05	88		69	940	881	221		8.6	6.6	
10:17	88	9	71	970	919	221		8.3	6.6	
11:30	89	11	68	970	808	227		7.0	6.2	
1:00	90	11	80	910	1168	227		8.1	7.4	
2:15	86		82	890	1073	225		7.9	6.6	
					Avg- 950	225			6.1	7.6

TEL

DRYER OPERATIONS REPORT

LOUISIANA-PACIFIC CORPORATION SAGOLA ME

NAME NORA Finny/Gov 12

CREW D

SHIFT DAY NIGHT


DATE 7-24-9

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE %	B.C. Furnace °	ABB KENT Inlet °	ABB KENT Outlet °	GAS % VALVE	MOISTURE METER %	MOISTU
SURFACE									
7:30	92	(6) —	73.4	1350	1000	225	/	7.3	6.1
8:50	92	—	77.3	1300	1005	227	/	7.2	6.6
11:45	92	(6) —	76.0	1350	1163	228	/	7.6	6.3
2:00	88	—	79.6	1300	1193	221	/	9.2	7.5
4:30	93	(11) —	82.2	1200	1139	224	/	7.6	6.8
		—		Avg.	1100	226	—	—	6.7
		(1) —							
		(3) —							
		(5) —							
		TEST III		GRAYS.	3				

TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE %	B.C. Furnace °	ABB KENT Inlet °	ABB KENT Outlet °	GAS % VALVE	MOISTURE METER %	MOISTU
CORE									
7:30	82	(7) —	72.7	1000	996	206	/	5.8	6.7
8:50	92	—	65.4	1000	951	208	/	6.4	5.2
11:45	92	(9) —	102.8	1010	1164	209	subst	7.0	5.4
2:00	86	—	69.7	1010	833	210	/	7.5	6.7
4:30	92	(11) —	68.1	7075	1063	211	54.97	6.4	5.7
		—		Avg.	1001	209	—	—	5.7
		(1) II							
		(3) —							
		(5) —							
		TEST III		GRAYS.	7				


TIME	WET FEED RATE %	GRAYCONS	WOOD VALVE %	B.C. Furnace °	ABB KENT Inlet °	ABB KENT Outlet °	GAS % VALVE	MOISTURE METER %	MOISTU
SURFACE CORE									
7:30	90	(6) —	59.5	1000	782	231	/	7.3	6.7
8:50	92	—	69.5	1000	954	223	/	6.7	5.8
11:45	92	(6) —	70.6	960	1105	229	subst	6.8	5.7
2:00	88	—	76.7	950	1010	226	/	6.9	6.6
4:30	93	(11) —	74.2	975	974	219	/	6.9	6.7
		—		Avg.	971	226	—	—	6.7
		(1) —							
		(3) —							

(6.7)




SAGOLA SURF. E-TUBE
7/24/96





SAGOLA CORE E-TUBE
7/24/96





SAGOLA SURF./CORE E-TUB
7/24/96

70

7/24/96

SAGOLA E-TUBE DATA SHEET

SURFACE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
730	52	320	29.0	51	250	29.0		
740	45	110	29.6	48	200	29.2		
750	50	250	28.5	51	270	28.9		
800	50	280	28.9	52	320	29.2		
810	54	320	29.0	54	300	28.9		
820	51	300	29.0	50	250	29.1		
830	52	320	28.9	51	300	29.1		
840	50	320	29.0	52	300	29.1		
850	55	300	29.0	55	300	29.0		
900	54	320	28.9	52	300	29.1		
910	53	320	28.8	52	310	29.0		
920	50	270	29.1	20	-	29.8		
930	55	400	29.0	51	270	28.1		
940	55	370	29.0	54	290	29.0		
950	54	350	29.0	52	250	29.0		
1000	52	280	29.0	50	280	29.1		
1010	54	370	29.0	50	290	29.0		
1020	53	340	28.8	50	270	28.9		
1030	53	330	29.2	52	250	29.1		
1040	15	50	29.9	45	100	29.5		
1050	52	340	29.1	52	280	29.0		
1100	51	360	29.0	53	290	28.9		
1110	52	330	28.8	53	300	29.2		
1120	54	350	29.1	53	320	29.0		
1130	53	320	29.0	52	310	29.1		
1140	55	300	29.0	54	300	28.9		
1150	54	310	28.9	53	300	29.0		
1200	51	290	29.0	53	310	29.2		
1210	54	300	29.0	54	300	28.9		
1220	55	350	29.1	50	250	29.1		
1230	57	350	28.9	51	300	29.0		

Flux

Flux


Flux

7/24/96

SAGOLA E-TUBE DATA SHEET

SURFACE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1240	55	350	29.0	55	310	29.2		
1250	55	340	29.1	54	300	29.0		
1300	55	370	29.0	53	300	29.0		
1310	54	340	29.0	52	290	29.1		
1320	55	350	29.0	55	300	29.1		
1330	55	350	29.0	54	330	28.9		
1340	20	50	29.8	45	180	29.2		
1350	51	310	29.0	50	270	29.0		
1400	51	320	29.3	53	300	29.0		
1410	51	320	29.1	50	290	29.1		
1420	52	360	29.0	54	300	29.1		
1430	53	300	29.1	52	320	29.1		
1440	55	290	28.9	51	250	28.9		
1450	54	310	28.9	54	300	29.1		
1500	54	310	29.0	53	290	29.1		
1510	52	360	29.0	50	300	29.0		
1520	54	370	29.0	51	250	29.0		
1530	53	330	29.0	53	270	29.0		
1540	54	310	29.0	52	260	29.1		
1550								
1600								
1610								
1620								
1630								
1640								
1650								
1700								
1710	54	350	29.1	55	380	29.0		
1720	54	380	29.1	54	350	29.0		
1730	55	400	28.9	54	300	29.1		
1740	55	370	28.9	55	350	28.9		

Flyh



7/24/96

SAGOLA E-TUBE DATA SHEET

SURFACE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1750	55	390	29.1	55	310	29.1		
1760	54	350	29.0	54	330	29.0		
1810	57	400	29.0	55	340	29.1		
1820	53	330	29.1	50	280	29.3		
1830	54	350	29.0	51	300	28.9		
1840	54	350	29.0	53	260	29.3		
1850	53	320	29.1	52	280	29.1		
1900	53	300	29.1	54	300	29.1		
1910	53	350	29.0	54	270	29.0		
20	55	320	29.0	53	260	29.1		
30	53	300	29.0	53	260	29.0		
40	50	300	29.0	52	300	28.9		
FL 50	40	100	29.5	51	250	29.0		
2000	53	350	28.8	53	250	29.1		
2060	53	330	28.1	52	250	29.1		
2070	55	340	29.0	53	300	29.1		
2030	53	350	29.0	50	300	29.0		
2040	55	320	29.1	50	250	29.1		
2050	55	300	29.0	51	260	29.1		
2100	55	300	28.9	50	280	28.9		
2110	54	300	28.9	51	250	29.0		
FL 2120	54	200	28.9	40	50	29.4		
2130	51	290	28.9	51	220	28.3		
2140	51	320	29.0	51	300	29.0		
2150								
2200								

ST # 2
 ✓ 1910
 20
 30
 40
 FL 50

FL

7/24/96

SAGOLA E-TUBE DATA SHEET

CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
730	50	300	29.0	50	280	28.6		
740	50	310	29.0	50	250	27.4		
750	50	300	28.9	50	220	27.7		
800	50	320	28.2	50	250	28.2		
810	52	350	29.1	50	260	27.9		
820	55	400	29.0	50	290	28.2		
830	52	360	28.0	50	250	28.0		
840	50	360	29.2	50	220	28.2		
850	52	360	29.0	50	270	28.8		
900	45	200	29.1	40	150	29.5		
910	52	260	28.8	50	250	27.6		
920	55	370	28.9	50	270	27.1		
930	54	360	29.2	50	270	26.9		
940	35	340	29.0	50	260	26.9		
950	53	330	29.1	50	300	27.1		
1000	52	380	29.2	50	280	26.6		
1010	51	350	28.9	50	250	28.0		
1020	52	310	29.3	52	310	27.9		
1030	40	-	29.8	49	200	27.1		
1040	51	350	28.5	51	290	27.5		
1050	51	300	28.9	52	300	27.9		
1100	50	310	29.0	50	280	28.0		
1110	50	310	29.0	51	280	28.7		
1120	51	320	29.0	50	250	28.7		
1130	52	320	28.9	50	270	28.9		
1140	54	350	29.0	50	270	28.9		
1150	50	300	29.0	50	280	29.0		
1200	45	150	29.4	30	-	29.2		
1210	52	340	29.1	50	250	28.5		
1220	54	350	29.0	50	260	27.1		
1230	50	350	29.2	52	280	22.7		

F1-54

F1-5L

F1-7

74

7/24/96

SAGOLA E-TUBE DATA SHEET

CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1240	50	270	29.1	52	270	21.8		
1250	54	380	29.0	51	280	26.1		
1300	50	300	29.2	50	260	27.8		
1310	53	350	29.1	51	280	27.1		
1320	50	360	29.1	50	270	24.9		
1330	25	100	29.9	40	200	26.3		
1340	53	370	28.6	51	290	24.9		
1350	54	400	21.9	50	300	24.9		
1400	56	390	29.1	50	300	25.6		
1410	55	380	29.0	50	300	28.1		
1420	50	300	29.0	50	250	28.0		
1430	50	290	29.0	50	260	27.3		
1440	52	270	29.0	51	270	28.3		
1450	54	340	29.0	51	300	27.5		
1500	53	330	29.1	50	270	27.7		
1510	52	350	28.9	50	280	27.5		
1520	54	350	28.9	51	250	25.7		
1530	54	370	28.8	51	300	23.3		
1540	53	390	29.2	51	290	24.5		
1550								
1600								
1610								
1620								
1630								
1640								
1650								
1700								
1710	50	300	28.9	50	210	28.5		
1720	52	380	29.0	50	250	27.9		
1730	54	450	28.8	53	300	27.2		
1740	55	460	29.1	52	300	26.3		

7/24/96

SAGOLA E-TUBE DATA SHEET

CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1750	54	450	29.1	50	270	27.3		
1800	52	430	29.1	50	270	27.3		
1810	52	350	29.1	51	270	28.9		
1820	56	350	29.1	50	270	28.2		
1830	50	250	29.0	51	280	26.3		
1840	53	430	29.1	51	290	25.9		
1850	52	400	29.1	51	290	25.1		
1900	50	300	28.9	50	250	26.1		
1910	52	350	29.2	50	270	27.2		
1920	51	350	29.0	51	290	25.7		
1930	53	360	28.9	51	300	26.8		
FL 1940	45	130	29.6	49	180	27.0		
1950	51	290	28.9	50	300	27.2		
2000	54	380	29.0	50	310	26.9		
2010	52	360	29.0	50	310	26.9		
2020	52	370	29.0	52	300	27.5		
2030	55	360	29.0	50	250	27.2		
2040	51	330	29.0	51	300	26.8		
2050	53	370	29.0	51	320	27.1		
2100	50	300	29.0	50	290	27.3		
2110	51	300	29.0	50	200	28.3		
2120	52	370	29.1	51	300	26.0		
2130	54	410	29.0	51	300	24.4		
2140	52	400	29.0	51	270	25.5		
2150								
2200								

76

7/24/96

SAGOLA E-TUBE DATA SHEET

SURFACE/CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
730	50	350	28.9	50	310	29.1		
740	52	350	29.0	50	300	29.0		
750	52	310	28.9	50	300	28.9		
800	52	310	29.1	52	300	29.1		
810	50	260	28.9	50	280	29.1		
820	50	300	29.0	50	300	28.9		
830	52	350	29.0	50	300	29.1		
840	50	310	29.0	52	300	28.2		
850	49	290	29.0	45	200	29.1		
900	50	360	28.9	50	250	28.5		
910	50	340	28.9	50	250	29.1		
920	50	290	29.0	52	300	29.1		
930	50	290	29.1	52	290	29.0		
940	50	320	29.2	53	280	29.0		
950	52	350	29.1	50	350	29.0		
1000	51	300	29.2	52	290	29.0		
1010	53	370	29.1	52	300	29.0		
1020	25	70	29.7	40	50	29.1		
1030	50	320	28.4	54	280	29.0		
1040	53	330	29.2	52	300	29.0		
1050	53	330	29.1	53	350	29.0		
1100	54	370	29.1	51	300	29.1		
1110	54	340	29.0	50	280	28.2		
1120	51	350	29.0	52	330	29.0		
1130	51	310	29.0	50	310	29.0		
1140	50	400	28.9	52	320	29.0		
1150	40	140	29.2	20	—	29.0		
1200	50	340	28.8	50	310	28.3		
1210	52	350	28.9	50	330	29.0		
1220	51	360	29.1	54	320	29.0		
1230	50	400	29.1	54	200	29.2		

Flt

Flt

77


7/24/96

SAGOLA E-TUBE DATA SHEET

SURFACE/CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1240	51	400	29.0	50	300	29.0		
1250	51	350	29.0	53	300	29.0		
1300	55	370	29.0	53	300	29.0		
1310	51	340	29.0	52	310	29.1		
1320	30	—	29.1	52	300	29.0		
1330	50	300	28.2	52	300	29.1		
1340	51	350	28.9	52	340	29.0		
1350	55	340	28.9	54	400	29.0		
1400	55	340	29.1	55	390	29.1		
1410	53	330	29.0	51	300	29.1		
1420	54	360	29.1	54	410	29.0		
1430	54	340	29.0	54	350	29.1		
1440	53	350	29.1	50	410	29.0		
1450	45	180	29.4	20	10	29.9		
1500	53	300	29.0	50	280	29.0		
1510	55	460	28.9	51	310	29.0		
1520	55	470	29.0	51	330	29.0		
1530	54	550	29.0	54	350	29.0		
1540	53	550	29.2	53	310	29.1		
1550								
1600								
1610								
1620								
1630								
1640								
1650								
1700								
1710	55	450	29.0	55	370	29.1		
1720	50	400	29.1	50	250	29.1		
1730	53	450	28.9	50	300	28.9		
1740	55	450	28.9	51	300	28.9		

7/24

Flu



7/24/91

SAGOLA E-TUBE DATA SHEET

SURFACE/CORE								
TIME	SOUTH TR SET			NORTH TR SET			QUENCH	
	KV	MA	SPARK	KV	MA	SPARK	INLET	OUTLET
			RATE			RATE		
1750	S1	350	29.1	S3	300	29.0		
1800	S0	310	28.9	S5	300	29.0		
1810	S2	410	29.1	S1	350	29.1		
1820	S3	300	29.0	S5	360	29.1		
1830	S4	370	29.1	S5	400	29.0		
1840	S3	320	29.0	S4	370	29.1		
1850	S3	310	29.1	S3	360	29.0		
1900	S2	330	29.0	S1	320	28.9		
1910	S3	360	28.9	S1	300	28.9		
1920	S5	380	29.1	S2	400	28.9		
1930	S3	370	29.2	S2	350	29.0		
1940	S4	350	29.0	S2	430	29.0		
1950	S1	300	28.9	S1	350	28.9		
2000	S1	340	29.0	S3	300	29.0		
2010	S1	320	29.1	S2	310	28.9		
2020	S2	350	29.0	40	20	29.4		
2030	S3	350	29.0	S0	300	29.0		
2040	S5	380	29.0	S0	250	28.9		
2050	S4	370	29.0	S1	300	29.0		
2100	S4	450	29.0	S3	310	29.0		
2110	S4	470	29.1	S2	300	29.1		
2120	S5	400	29.1	S2	330	29.2		
2130	S5	400	29.0	S4	370	29.0		
2140	S3	410	28.9	S2	350	29.1		
2150								
2200								

FL.

OPERATOR Linda Harper SHIFT 2nd CREW B DATE 7-24-96

UNIT 1 S/C E-TUBE:

T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel					
TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water total gal.	Make-up Water total gal.	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
No. 1 (N.)		No. 2 (S.)		INLET	OUTLET	PSI	PSI				N.	S.			
kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O								
52	220	50	300	213	155	18	24	6	40965	258620	20	21	15	8436	796
52	350	50	300	225	131	16	25	8	40945	258620	20	21	15	8521	803

Recycle Water Solids % 9.36 8.99 Blow Off sec. 10: _____ 4: _____
 Recycle Water pH 7.9 8.4

UNIT 2 CORE E-TUBE:

T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel					
TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water total gal.	Make-up Water total gal.	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
No. 1 (N.)		No. 2 (S.)		INLET	OUTLET	PSI	PSI				N.	S.			
kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O								
52	280	50	300	209	150	14	27	7	454235	109914	20	21	15		
52	480	48	300	216	148	19	26	7	454235	109914	20	21	15		

Recycle Water Solids % 8.72 9.92 Blow Off sec. 10: _____ 4: _____
 Recycle Water pH 7.3 6.6

UNIT 3 SURFACE E-TUBE:

T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel					
TRANSFORMER/RECTIFIERS				QUENCH		INLET	OUTLET	P	Flush Water total gal.	Make-up Water total gal.	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
No. 1 (N.)		No. 2 (S.)		INLET	OUTLET	PSI	PSI				N.	S.			
kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O								
52	280	52	300	212	147	19	21	1	422959	245129	20	21	15		
52	280	50	300	221	144	19	25	7	422959	245129	20	21	15		

Recycle Water Solids % 6.99 9.12 Blow Off sec. 10: _____ 4: _____
 Recycle Water pH 8.6 7.8

Surface Core

DISPERSION TUBE DRAIN MAGNEHELIC:

10	<u>5.5</u>	10	_____
4	<u>5.5</u>	4	_____

BLOW OFF LINE FLOW METERS (ON TOP OF BLOW DOWN TANK)

TOTAL GALLONS BLOWN DOWN			DRYER RUN TIME
BEFORE	AFTER	"AFTER" MINUS "BEFORE"	
S/C <u>7889</u>	S/C <u>9377</u>	S/C <u>1488</u>	S/C <u>720</u>
CORE <u>138221</u>	CORE <u>128938</u>	CORE <u>717</u>	CORE <u>720</u>
SURFACE <u>162713</u>	SURFACE <u>162713</u>	SURFACE <u>0</u>	SURFACE <u>720</u>

GALLONS PER MINUTE BLOWN OFF = $\frac{\text{GALLONS BLOWN OFF}}{\text{DRYER RUN TIME}}$

S/C	<u>2.0</u>	GPM
CORE	<u>.99</u>	GPM
SURFACE	<u>0</u>	GPM

CORE WET BIN FLOW METER

BEFORE	<u>572.160</u>	AFTER	<u>574360</u>	TOTAL GALLONS LOST "AFTER" MINUS "BEFORE"	<u>2200</u>
--------	----------------	-------	---------------	---	-------------

BLOW DOWN TANK LEVEL

BEFORE	<u>28"</u>	AFTER	<u>123"</u>
--------	------------	-------	-------------

COMMENTS:

80

OPERATOR ALBA/FUNNY SHIFT U CREW 0 DATE 7-24-86

UNIT 1 S/C E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel						
	TRANSFORMER/RECTIFIERS				QUENCH		INLET		OUTLET		Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)		No. 2 (S.)		INLET OUTLET		PSI	PSI	in H2O	in H2O							
kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O	P	total gal.	total gal.	N.	S.	Mesh Pad	Caustic Meter	Defoamer Meter		
10	51	270	51	300	177	157	18	25	7	909.418	25933%	29.1	28.8	.3	8521	80.3	
4	51	300	54	270	201	119	20	26	6	909.410	25934%	29.0	29.1	.3	8548	80.7	

Recycle Water Solids % 11.7% 11.1% Blow Off sec. 10: 43 4: 43
 Recycle Water pH 8.1 8.2

UNIT 2 CORE E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel						
	TRANSFORMER/RECTIFIERS				QUENCH		INLET		OUTLET		Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)		No. 2 (S.)		INLET OUTLET		PSI	PSI	in H2O	in H2O							
kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O	P	total gal.	total gal.	N.	S.	Mesh Pad	Caustic Meter	Defoamer Meter		
10	50	320	50	330	206	138	9	27	18	456.378	110.241	26.2	24.1	.2			
4	51	250	50	320	212	138	2	26	24	459.270	110.750	26.4	29.0	.2			

Recycle Water Solids % 6.9% 9.6% Blow Off sec. 10: 32 4: 32
 Recycle Water pH 6.6 6.8

UNIT 3 SURFACE E-TUBE:

Time	T/R CONTROL PANEL DIGITAL				ZYCOM						Beginning & End of Shift on the Vessel						
	TRANSFORMER/RECTIFIERS				QUENCH		INLET		OUTLET		Flush Water	Make-up Water	Spark Rate	Spark Rate	Mesh Pad	Caustic Meter	Defoamer Meter
	No. 1 (N.)		No. 2 (S.)		INLET OUTLET		PSI	PSI	in H2O	in H2O							
kv	mA	KV	mA	deg. F	deg. F	in H2O	in H2O	P	total gal.	total gal.	N.	S.	Mesh Pad	Caustic Meter	Defoamer Meter		
10	51	260	51	330	218	133	19	23	4	423.018	295.127	29.1	29.1	.3			
4	51	260	52	280	228	137	19	22	3	423.010	295.120	29.0	28.9	.3			

Recycle Water Solids % 10.8% 11.3% Blow Off sec. 10: 27 4: 24
 Recycle Water pH 7.4 7.0

	Surface	Core
DISPERSION TUBE DRAIN MAGNETIC:	10 <u>5</u>	10 <u>5</u>
	4 <u>5</u>	4 <u>4</u>

BLOW OFF LINE FLOW METERS (ON TOP OF BLOW DOWN TANK)

TOTAL GALLONS BLOWN DOWN

	BEFORE	AFTER	"AFTER" MINUS "BEFORE"	DRYER RUN TIME
S/C	<u>9377</u>	<u>9367</u>	<u>5 (-10)</u>	<u>720</u>
CORE	<u>138938</u>	<u>139144</u>	<u>206</u>	<u>720</u>
SURFACE	<u>162713</u>	<u>162713</u>	<u>0</u>	<u>720</u>

GALLONS PER MINUTE BLOWN OFF -	GALLONS BLOWN OFF	S/C	GPM
	<u>DRYER RUN TIME</u>	<u>—</u>	<u>—</u>
		CORE <u>.24</u>	GPM
		SURFACE <u>—</u>	GPM


TOTAL GALLONS LOST "AFTER" MINUS "BEFORE"

CORE WET BIN FLOW METER BEFORE: 574360 AFTER: 576000 1640

BLOW DOWN TANK LEVEL BEFORE: 103" AFTER: 127"

COMMENTS: Removed the guts from surface Blowoff meter.

(81)



SAGOLA DRYER RTO
7/24/96
0700-0700

82

SAGOLA DRYER RTO DATA SHEET

TIME 10 MINUTES	CHAMBER TEMPS.										INLET PRESS.	BURNERS			COMB TEMP.	EXHAUST TEMP.	PRESS. DROP	GAS USAGE
	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10		#1	#2	#3				
	7:30	373	370	339	381	369	341	379	349	349		353	1529	1541				
7:40	369	368	342	376	373	340	377	354	354	353	1547	1550	1544	1525	243	15.6	9539/7666	
7:50	365	371	341	373	377	338	378	355	355	354	1532	1546	1539	1521	252	15.7	4521/3366	
8:00	364	377	335	377	378	335	382	350	350	354	1518	1525	1517	1496	246	15.9	9042/5101	
8:10	364	374	338	375	379	337	380	353	353	354	1536	1542	1532	1515	250	15.9	9080/7247	
8:20	363	375	338	373	379	336	380	352	352	352	1544	1552	1539	1518	249	16.2	6946/5997	
8:30	363	375	338	374	379	336	380	352	352	352	1544	1552	1539	1496	250	16.3	12,682/7997	
8:40	371	369	340	382	370	341	378	349	349	351	1525	1530	1519	1506	243	15.7	7061/5835	
8:50	369	374	333	383	369	337	383	343	343	350	1529	1540	1534	1508	246	15.9	12336/8870	
9:00	371	368	335	381	368	336	382	342	342	351	1540	1540	1532	1508	246	15.8	6320/5015	
9:10	368	372	331	382	369	336	383	342	342	351	1533	1544	1536	1510	244	15.8	11658/8516	
9:20	370	370	332	382	368	337	382	342	342	351	1536	1540	1536	1514	247	15.1	7312/5488	
9:30	362	371	336	372	377	334	380	348	348	351	1527	1538	1528	1505	247	16.0	11,612/9062	
9:40	366	365	339	371	373	337	377	351	351	352	1537	1541	1533	1518	256	16.0	8494/6150	
9:50	363	372	332	376	375	334	382	344	344	351	1524	1535	1527	1505	242	15.6	11,628/8370	
10:00	367	370	331	380	371	335	382	341	341	351	1535	1536	1527	1505	239	15.6	8451/6211	
10:10	363	367	339	370	378	336	378	350	350	352	1521	1533	1528	1510	253	15.6	11,044/6338	
10:20	362	373	333	375	377	334	383	344	344	352	1536	1541	1536	1515	244	15.7	6070/4179	
10:30	364	373	332	378	375	334	384	342	342	352	1525	1533	1520	1500	268	15.8	10,804/9041	
10:40	362	369	339	370	381	336	379	350	350	352	1551	1552	1543	1525	248	15.8	11,858/7894	
10:50	369	366	337	378	372	339	380	346	346	353	1534	1537	1526	1507	242	15.5	7710/7920	
11:00	368	370	332	380	372	337	383	342	342	353	1540	1548	1541	1524	243	15.7	9930/6277	
11:10	369	367	336	379	372	338	381	344	344	352	1524	1530	1517	1496	249	16.0	11,719/9062	
11:20	369	370	333	381	372	336	382	342	342	352	1538	1544	1540	1518	248	15.7	5549/4301	
11:30	361	370	338	371	382	334	382	349	349	353	1527	1540	1532	1512	248	15.6	13,062/9878	
11:40	362	367	340	371	381	336	379	351	351	352	1539	1542	1534	1518	248	15.7	6897/5088	
11:50	369	366	337	378	374	338	380	346	346	355	1538	1547	1534	1515	249	15.6	12,685/8107	
12:00	364	373	333	378	379	334	385	344	344	355	1524	1533	1526	1506	257	16.0	11,571/7244	
12:10	367	365	342	375	385	335	379	352	352	354	1540	1547	1538	1518	260	16.2	12,856/9614	
12:20	362	370	341	372	385	336	380	352	352	355	1560	1565	1539	1537	254	15.9	7735/6161	
12:30	369	369	337	381	374	338	382	344	344	353	1557	1566	1553	1535	249	15.8	13,340/8000	
12:40	363	375	335	379	380	334	385	345	345	354	1515	1512	1503	1492	243	15.8	13,340/8000	
12:50	362	372	341	373	386	336	382	352	352	354	1537	1539	1529	1571	251	16.0	20000	
13:00	371	371	339	383	377	340	383	347	347	356	1560	1556	1548	1591	251	15.9	11,745	

7/24/96

SAGOLA DRYER RTO DATA SHEET

TIME 10 MINUTES	CHAMBER TEMPS.										INLET PRESS.	BURNERS			COMB. TEMP.	EXHAUST TEMP.	PRESS. DROP	GAS USAGE	
	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10		#1	#2	#3					
1310	364	378	339	381	385	336	388	349	349	349	155	1536	1537	1543	1538	245	15.9	5513	
1320	364	376	343	377	388	338	386	353	353	353	155	1537	1534	1539	1548	254	16.2	10474	
1330	368	371	347	376	386	341	383	355	355	355	156	1548	1546	1546	1565	251	16.2	8101	
1340	368	371	346	377	385	340	383	355	355	355	154	1535	1539	1540	1550	262	16.2	6389	
1350	372	371	342	383	379	341	384	348	348	348	154	1546	1542	1541	1552	252	16.0	7726	
1400	371	370	344	381	380	341	383	350	350	350	154	1541	1544	1544	1548	252	16.1	5002	
1410	372	370	343	381	379	341	384	350	350	350	155	1542	1539	1536	1535	254	16.0	6685	
1420	364	377	342	376	389	337	386	352	352	352	155	1536	1539	1539	1536	252	15.9	5378	
1430	372	370	346	379	381	342	382	352	352	352	156	1545	1545	1547	1549	256	16.3	6111	
1440	371	370	346	379	383	343	382	354	354	354	156	1542	1546	1545	1546	263	16.3	4145	
1450	372	371	346	381	381	343	383	353	353	353	155	1531	1533	1528	1523	238	16.2	5877	
1500	372	370	345	381	381	342	383	352	352	352	154	1537	1533	1536	1561	235	16.2	16117	
1510	371	377	338	386	382	338	388	347	347	347	153	1543	1549	1547	1592	258	16.4	14356	
1520	370	377	338	385	382	339	388	346	346	346	153	1541	1540	1543	1577	254	15.7	3457	
1530	365	374	345	375	389	339	384	353	353	353	152	1557	1538	1542	1581	236	16.2	4148	
1540	373	373	340	384	379	340	384	348	348	348	153	1583	1540	1535	1587	252	16.0	14350	
1550																			
1600																			
1610																			
1620																			
1630																			
1640																			
1650																			
1700																			
1710	369	373	336	381	377	338	382	344	344	344	153	1545	1543	1538	1590	250	16.1	12,805	
1720	368	367	345	373	382	340	377	355	355	355	153	1536	1541	1547	1590	264	16.5	12,500	
1730	365	372	343	371	386	338	379	353	353	353	153	1536	1539	1542	1585	255	16.0	13,430	
1740	364	372	343	372	386	338	379	354	354	354	153	1539	1542	1544	1589	255	16.0	12,900	
1750	369	368	345	373	382	341	377	354	354	354	154	1535	1540	1543	1586	263	16.5	12,277	
1800	364	376	339	375	386	337	382	349	349	349	155	1542	1538	1536	1580	252	16.0	12,899	
1810	372	369	344	376	379	342	378	352	352	352	154	1531	1536	1539	1578	258	16.3	12,132	
1820	369	369	345	373	383	341	377	355	355	355	154	1538	1541	1545	1588	262	16.3	12,124	
1830	370	377	336	381	381	345	381	356	356	356	153	1545	1542	1539	1584	248	16.0	10,646	
1840	367	377	337	379	383	337	384	347	347	347	154	1543	1538	1537	1575	249	16.0	11,149	

HRom

1440

Wheelabrator Clean Air Systems

Huntington Energy Systems RTO

LP Sagola (Dryer)

Regenerative Thermal Oxidizer

DATA SHEET

Rev 3, DHS 4/1/96

Fill out data column once a shift, attach final sheet with chart recorder sheet; submit to Environmental

	7-24-96	7-24-96	
Time	10:00 A.M.	4:00 P.M.	
Turner S.P.	1540	1540	Comments (Note anything out of the ordinary)
Fan #1 temp	1529	1537	
Fan #1 out	12.7	49.4	
Fan #2 temp	1535	1540	
Fan #2 out	7.1	40.1	
Fan #3 temp	1526	1544	
Fan #3 out	8.1	60.8	
Inlet temp	151	150	
Chamber temp	1509	1583	
Exhaust temp	245	251	
RTO diff press	15.7	16.0	
#1 VFD Amps	555	562	
#1 VFD RPM	1319	1322	
#2 VFD Amps	592	635	
#2 VFD RPM	1360	1366	
RV setpoint	1.0	1.0	
RV out	.83	.82	
Chamber #1 B.O. temp	370	367	
Chamber #2 B.O. temp	360	372	
Chamber #3 B.O. temp	338	335	
Chamber #4 B.O. temp	376	380	
Chamber #5 B.O. temp	371	377	
Chamber #6 B.O. temp	339	336	
Chamber #7 B.O. temp	377	381	
Chamber #8 B.O. temp	348	343	
Fan #1 Motor temp	119	123	
Fan #2 Motor temp	112	117	
Fan #3 Motor temp	120	125	
Fan #4 Motor temp	105	108	
Fan #5 Motor temp	131	133	
Fan #6 Motor temp	90	99	
Fan #7 Motor temp	98	101	
Fan #8 Motor temp	94	91	
Dryer #1 RTO/ATMOS	RTO	RTO	
Dryer #2 RTO/ATMOS	RTO	RTO	
Dryer #3 RTO/ATMOS	RTO	RTO	
Chamber Prg Fan	ON	ON	
Total gas flow	11005	12496	
RTO flow	7217	7	

86

Wheelabrator Clean Air Systems

Huntington Energy Systems RTO

DATA SHEET

LP Sagola (Dryer)

rev.3, DHS 4/1/96

Regenerative Thermal Oxidizer

Date	7-24-96		Fill out data column once a shift, attach final sheet with chart recorder sheet; submit to Environmental
Time	10:00	400	Comments (Note anything out of the ordinary)
Burner S.P.	1540	1540	
Bnr #1 temp	1544	1545	
Bnr #1 out	35.7	25.8	
Bnr #2 temp	1542	1540	
Bnr #2 out	35.5	13.4	
Bnr #3 temp	1539	1538	
Bnr #3 out	53.8	31.6	
Inlet temp	148	154	
Chamber temp	1575	1545	
Exhaust temp	253	261	
RTO diff press	15.7	16.3	
#1 VFD Amps	615	591	
#1 VFD RPM	1361	1322	
#2 VFD Amps	616	590	
#2 VFD RPM	1352	1381	
PV setpoint	1.0	1.0	
PV out	65.5	65.3	
Cbr #1 B.O. temp	368	373	
Cbr #2 B.O. temp	379	377	
Cbr #3 B.O. temp	337	301	
Cbr #4 B.O. temp	378	372	
Cbr #5 B.O. temp	380	398	
Cbr #6 B.O. temp	335	344	
Cbr #7 B.O. temp	379	379	
Cbr #8 B.O. temp	348	366	
#1 Fan brg #1 temp	122	109	
#1 Fan brg #2 temp	83	78	
#2 Fan brg #1 temp	97	91	
#2 Fan brg #2 temp	85	84	
#1 Motor brg #1 temp	116	114	
#1 Motor brg #2 temp	110	108	
#2 Motor brg #1 temp	119	113	
#2 Motor brg #2 temp	102	97	
Dryer #1 RTO/ATMOS	Rto	Rto	
Dryer #2 RTO/ATMOS	Rto	Rto	
Dryer #3 RTO/ATMOS	Rto	Rto	
Chamber Prg Fan	ON	ON	
Total gas flow	11463	4692	
BTUE flow			

87

BUNDLE HEIGHT PARAMETERS \checkmark / WEIGHTS

Notes: 7/24/96

Board Size	Pieces / Bundle	Target Thickness	Target Hcl. Height	Target Bcl. Weight
1/4"	120	0.260	31 1/4"	3296
1/4"	150	0.260	39"	4108
3/8"	100	0.380	38"	4003
7/16"	66	0.380	28 3/4"	2932
7/16"	90	0.435	39 1/8"	3999
15/32"	92	0.485	39 3/4"	4232
1/2"	66	0.510	30 5/8"	3100
1/2"	90	0.510	40 3/4"	4134
19/32" SE	65	0.595	38 5/8"	3981
19/32" HY	55	0.610	33 1/2"	3418
3/8" SE	40	0.620	24 3/4"	2612
23/32" SE	55	0.700	38 1/2"	3850
23/32" HY	45	0.730	32 7/8"	3285
7/8" HY	38	0.890	33 7/8"	3389
1-1/8" SE	36	1.085	39"	3854
1-1/8" HY	30	1.110	33 3/8"	3286

If the bundles heights are running plus or minus 3/8" from these figures, please notify the Quality Control Department and the Shift Foreman.

If the bundles weights are plus or minus 100 pounds from these figures, please notify the Quality Control Department and the Shift Foreman.

U Grade: Use normal piece count, edge seal, and 2 green stripes with the stencil on each side of the unit. Stencil the thickness on the lower right hand corner of the unit face, place tag close to bottom, and cover with plastic.

E Grade: 80 piece units thru 1/2", 50 piece units for 19/32 and 23/32, and 40 piece units for 7/8" and above. No edge seal, and 2 black stripes with the thickness logo on the lower right hand corner of the unit face. Place tag close to the bottom, and cover with plastic.

BUNDLE HEIGHT DATA

Size 7/16		Size 1/2		Size		Size		Size		Size		Size	
No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height
5	39 1/4	2	39 1/4										
9	39 1/4	1	39 1/4										
2	39 1/4	1	39 1/4										
12	39 1/4	52	39 1/4										
18	39 1/4	155	39 1/4										
21	39 1/4	110	39 1/4										
22	39 1/4	163	39 1/4										
25	39 1/4	57	39 1/4										
27	39 1/4												
30	39 1/4												
31	39 1/4												
32	39 1/4												
33	39 1/4												
34	39 1/4												
35	39 1/4												
36	39 1/4												
37	39 1/4												
38	39 1/4												
39	39 1/4												
40	39 1/4												
41	39 1/4												
42	39 1/4												
43	39 1/4												
44	39 1/4												
45	39 1/4												
46	39 1/4												
47	39 1/4												
48	39 1/4												
49	39 1/4												
50	39 1/4												
51	39 1/4												
52	39 1/4												
53	39 1/4												
54	39 1/4												
55	39 1/4												
56	39 1/4												
57	39 1/4												
58	39 1/4												
59	39 1/4												
60	39 1/4												
61	39 1/4												
62	39 1/4												
63	39 1/4												
64	39 1/4												
65	39 1/4												
66	39 1/4												
67	39 1/4												
68	39 1/4												
69	39 1/4												
70	39 1/4												
71	39 1/4												
72	39 1/4												
73	39 1/4												
74	39 1/4												
75	39 1/4												
76	39 1/4												
77	39 1/4												
78	39 1/4												
79	39 1/4												
80	39 1/4												

EPA DATA

Size	Time	Pieces	Height	Weight
7/16	07:00	94	39 1/4	4340
7/16	07:15	94	39 1/4	4293
7/16	07:30	90	39 1/4	4350
7/16	07:45	70	39 1/4	4140
7/16	08:00	72	39 1/4	4137
7/16	08:15	92	39 1/4	4150
7/16	08:30	96	39 1/4	4230
7/16	08:45	90	39 1/4	4350
7/16	09:00	92	39 1/4	4342
7/16	09:15	90	39 1/4	4442
7/16	09:30	92	39 1/4	4320
7/16	09:45	90	39 1/4	4145
7/16	10:00	70	39 1/4	4201
7/16	10:15	90	39 1/4	4188
7/16	10:30	90	39 1/4	4294
5/16	10:45	92	39 1/4	4237
7/16	11:00	90	39 1/4	4180
7/16	11:15	92	39 1/4	4180
7/16	11:30	92	39 1/4	4163
7/16	11:45	90	39 1/4	4107
7/16	12:00	90	39 1/4	4086
7/16	12:15	90	39 1/4	4124
7/16	12:30	51	39 1/4	4028
7/16	12:45	90	39 1/4	4140
7/16	13:00	90	39 1/4	4156
7/16	13:15	90	39 1/4	4138
7/16	13:30	92	39 1/4	4180
7/16	13:45	90	39 1/4	4170
7/16	14:00	90	39 1/4	4183
7/16	14:15	90	39 1/4	4143
7/16	14:30	90	39 1/4	4143
7/16	14:45	90	39 1/4	4097
7/16	15:00	90	39 1/4	4048
7/16	15:15	90	39 1/4	4026
7/16	15:30	90	39 1/4	4092
7/16	15:45	40	39 1/4	4100
7/16	16:00	90	39 1/4	4105

88

PRESS JULY 24th 1996

PM

DATA TIME	START=	18:35	END=	19:36	HOURS=	1.02
	START=	20:05	END=	21:08	HOURS=	1.05
	START=	21:37	END=	22:37	HOURS=	<u>1.00</u>
					TOTAL=	3.07

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
per/peice 46.15
per/ 8' x 24' 276.93

4153.9 lb= average
bundle weight
90 piece units

PLANT PRODUCTION RATE

- 3.07 =hours during testing
- 56 =pressloads
- 672 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
- 129,024 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
- 150,532 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
- 186,096 =lbs of finished product (boards produced x weight of finished board)
- 60,684 =lbs of finished product per hour (lbs of finshed product / hours)
- 30.34 =tons of finished product per hour (lbs of finshed product per hour / 2000 lb)

3.3 min / piece load

47.03 MSE₈ / hr

39.56 16/22

RESIN USAGE TAKEN FROM TOTALIZERS

TIME	MDI	PHENOL	WAX
18:35-19:36	788	1,495	691
20:05-21:08	814	1,543	712
21:37-22:37	775	1,470	678
AVERAGE	792.33	1,502.67	693.67


- 60,684 =average lbs. per hour finished product produced during testing
- 792.33 =average lbs. per hour of MDI resin used during testing
- 1.31% = MDI resin used as % of finished product

- 1,502.67 =average lbs. per hour of phenolic resin (100% solids) used during testing
- 2.48% =Phenolic resin used as % of finished product

- 693.67 =average lbs. per hour of wax (100% solids) used during testing
- 1.14% =wax used as % of finished product

info copied to summary page

- 30.34 =Plant Production rate in Tons per hour
- 792.33 =MDI resin usage in pounds per hour
- 1.31% =MDI resin usage as % of finished product
- 1,502.67 =Liquid phenolic resin usage in pounds per hour (100% solids)
- 2.48% =Liquid phenolic resin usage as % of finished product (100% solids)
- 693.67 =Wax usage in pounds per hour
- 1.14% =Wax usage as % of finished product



SAGOLA PRESS RTO
7/24/96

91

18:00 start
 19:56 END
 21:51 start
 22:04 END

7/24/96

SAGOLA PRESS RTO DATA SHEET

No. DECEMBER

TIME 10 MINUTES	#1	#2	#3	#4	#5	INLET PRESS.	BURNERS #1	BURNERS #2	COMB. TEMP.	EXHAUST TEMP.	PRESS DROP	GAS USAGE
18:30	435	381	396	403	373	124	1543	1540	1542	240	21.4	598568.10
18:40	428	377	398	410	372	124	1544	1536	1546	246	21.1	598578.70
18:50	433	381	397	404	371	125	1541	1532	1543	244	21.1	598586.00
19:00	428	373	398	414	374	125	1543	1539	1545	241	21.0	598575.90
19:10	427	375	399	413	372	125	1533	1543	1545	240	21.3	598606.30
19:20	432	372	396	413	374	125	1539	1542	1543	241	21.1	598615.80
19:30	430	374	397	413	373	125	1537	1546	1544	242	20.9	598625.60
19:40	436	378	396	407	373	125	1537	1550	1540	244	21.0	598635.00
19:50	437	375	396	408	374	125	1541	1548	1549	240	21.2	598645.20
20:00	432	361	399	407	374	126	1541	1532	1538	242	21.3	598654.00
20:10	431	381	399	406	372	125	1541	1534	1538	242	21.2	598664.50
20:20	439	379	396	404	373	124	1537	1543	1538	242	20.9	598673.30
20:30	436	374	396	409	372	124	1538	1532	1537	241	21.2	598682.00
20:40	436	376	396	409	372	123	1538	1530	1546	239	21.1	598694.20
20:50	429	376	397	408	371	123	1538	1546	1546	239	21.2	598704.40
21:00	431	373	395	411	372	122	1536	1551	1547	239	21.0	598712.80
21:10	429	379	397	404	370	122	1538	1538	1544	239	21.1	598721.60
21:20	434	377	395	402	371	121	1538	1531	1539	240	21.1	598734.40
21:30	427	379	395	410	372	121	1537	1552	1547	238	21.1	598744.10
21:40	428	373	395	408	371	121	1534	1550	1544	238	21.1	598744.70
21:50	422	370	393	408	372	121	1537	1547	1538	240	21.4	598763.90
22:00	433	372	393	405	372	122	1540	1533	1537	240	20.9	598771.00
22:10	433	374	393	404	371	121	1542	1532	1540	239	21.1	598780.00
22:20	432	375	394	402	371	121	1538	1531	1540	239	21.2	598790.50
22:30	427	376	396	403	371	121	1545	1535	1544	239	21.2	598800.00
22:40												
22:50												
23:00												
23:10												
23:20												
23:30												
23:40												
23:50												
24:00												

RTO LOG SHEET

Wheelabrator Clean Air Systems

Wilmington Energy Systems RTO
 IP Sagola Data Sheet
 Rev. 01 DHS 3/5/96

Press

Crew / Name	B	MATT
Date	7-24-96	7-24-96
Time	10:00	16:00
Gas Meter reading	598060	598423
Burner S.P.	1570	1570
Bnr #1 temp	1572	1570
Bnr #1 out	32.8	30.8
Bnr #2 temp	1532	1549
Bnr #2 out	41.3	37.8
Inlet temp	121	124
Chamber temp	1543	1570
Exhaust temp	240	239
RTO D.P.	21.2	20.9
Chm Pur Fan Amp	25	6.8
Main Fan Amps	25	22
BTUE on/off	ON	ON
PV setpoint	3.507	3.603
PV out	65.2	68.8
Cbr #1 B.O. temp	426	428
Cbr #2 B.O. temp	376	372
Cbr #3 B.O. temp	323	395
Cbr #4 B.O. temp	401	413
Cbr #5 B.O. temp	368	371
Brg next to mtr	95	97
Brg opp mtr	96	93
Mtr brg #1	113	116
Mtr brg #2	93	95

LINE OPERATORS

READINGS MUST BE TAKEN TWICE A SHIFT DAYS - 10:00 AND 16:00
 NIGHTS - 22:00 AND 04:00

24 HR. CHARTS MUST BE CHANGED OUT EVERY DAY @ 07:00

NOTE: INCONSISTENT AND UNUSUAL READINGS MUST BE ADDRESSED IN THE COMMENTS SECTION!

COMMENTS:

Wheelabrator Clean Air Systems

Washington Energy Systems, RTO
 P. Sagola Data Sheet
 REV. 0. D.H.S. 3/5/96

Press

Crew / Name	S. Carlsberg / AD		
Date	7-24-96		
Time	11:00	4:00	
Gas Meter reading	598707	599099	
Burner S.P.	1540	1540	
Bnr #1 temp	63.39	63.42	
Bnr #1 out	32.7	33.6	
Bnr #2 temp	65.45	65.33	
Bnr #2 out	38.6	39.3	
Inlet temp	126	118	
Chamber temp	1542	1532	
Exhaust temp	232	235	
RTO D.P.	21.3	21.1	
Chm Pur Fan Amp	78	70	
Main Fan Amps	80	55	
BTUE on/off	ON	ON	
PV setpoint	362	362	
PV out	67.7	62.2	
Cbr #1 B.O. temp	427	430	
Cbr #2 B.O. temp	372	368	
Cbr #3 B.O. temp	463	389	
Cbr #4 B.O. temp	411	406	
Cbr #5 B.O. temp	386	371	
Brg next to mtr	700	588	
Brg opp mtr	97	77	
Mtr brg #1	118	105	
Mtr brg #2	103	84	

LINE OPERATORS

READINGS MUST BE TAKEN TWICE A SHIFT
 DAYS - 10:00 AND 16:00
 NIGHTS - 22:00 AND 04:00

24 HR. CHARTS MUST BE CHANGED OUT EVERY DAY @ 07:00

NOTE: INCONSISTENT AND UNUSUAL READINGS MUST BE ADDRESSED IN THE COMMENTS SECTION!

COMMENTS:

RAW MATERIAL USAGE Data

** Please make recording every half hour **

DATE	TIME	THICK	LINE	SURFACE		SURFACE		CORE		CORE	
				DRY-BIN %	DRY-BIN %	POT-SET	GPM	POT-SET	GPM	POT-SET	GPM
7-24	8:00	7/16	93	70	70	825	4.13	852	683	1238	817
DAY	8:25	7/16	93	68	F	825	4.12	852	683	1240	817
	8:40	7/16	93	73	78	825	4.12	852	683	1245	817
	9:00	7/16	93	74	70	825	4.12	852	683	1249	817
	10:00	7/16	93	78	60	825	4.11	852	683	1238	817
	10:40	7/16	93	70	65	825	4.13	852	683	1238	817
	11:25	7/16	93	65	70	825	4.12	852	683	1238	817
	11:40	7/16	93	68	70	825	4.11	852	683	1238	817
	1:00	7/16	93	70	65	825	4.12	852	683	1238	817
	1:25	7/16	93	68	70	825	4.13	852	683	1249	817
	1:45	7/16	93	70	F	825	4.13	852	683	1249	817
	2:30	7/16	93	80	75	825	4.13	852	683	1238	817
	3:05	7/16	93	73	F	828	4.13	852	683	1238	817
	4:30	7/16	94	F	F	839	4.17	861	686	1248	826
	5:40	7/16	94	F	F	839	4.16	861	686	1249	826
	6:35	7/16	94	F	F	839	4.16	861	686	1249	826
Notes	7:13	7/16	94	78	FW	839	4.16	861	686	1249	826
	8:00	7/16	94	FW	72	839	4.16	861	686	1249	826
	8:30	7/16	94	80	FW	839	4.16	861	686	1249	826
	9:10	7/16	94	FW	FW	839	4.16	861	686	1249	826
	9:30	7/16	94	F	F	839	4.16	861	686	1249	826
	10:30	7/16	94	FW	80	839	4.16	861	686	1249	826
	11:10	19/32	68	68	71	917	4.57	853	677	1238	817
	11:50	19/32	68	70	70	917	4.57	853	677	1238	817
	12:00	19/32	68	65	F	917	4.57	853	677	1238	817
	12:50	1/2	81	70	FW						
	1:30	1/2	81	F	F	885	4.41	857	649	1188	822
	2:50	1/2	81	60	68						
	3:35	1/2	81	80	67						
	4:15	1/2	81	80	73						
	4:35	1/2	81	78	FW						
	5:15	1/2	81	FW	FW						

- PHENOL 5.89 LBS = gallon

- MDT 10.34 LBS = gallon

LOUISIANA-PACIFIC
Sagola, Michigan

PRESS JULY 25th 1996

HCHO

DATA TIME	START=	09:37	END=	10:39	HOURS=	1.03
	START=	12:35	END=	13:36	HOURS=	1.02
	START=	14:10	END=	15:12	HOURS=	<u>1.03</u>
					TOTAL=	3.08

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
 per/peice 49.81
 per/ 8' x 24' 298.85

4482.8 lb= average
 bundle weight
 90 piece units

PLANT PRODUCTION RATE.

3.08 =hours during testing
 49 =pressloads
 588 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
 112,896 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
 131,716 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
 175,726 =lbs of finished product (boards produced x weight of finished board)
 56,992 =lbs of finished product per hour (lbs of finshed product / hours)
 28.50 =tons of finished product per hour (lbs of finshed product per hour / 2000 lb)

3.8 min/pressload

*1.1667 - conversion
from 7/16 to 3/8*

*42.69 lb/ft³
42.74 MSC³/ft³*

RESIN USAGE TAKEN FROM TOTALIZERS

TIME	MDI	PHENOL	WAX
09:37-10:39	819	1,775	700
12:35-13:36	872	1,743	689
14:10-15:12	819	1,767	700
AVERAGE	836.67	1,761.67	696.33

56,992 =average lbs. per hour finished product produced during testing
 836.67 =average lbs. per hour of MDI resin used during testing
 1.47% = MDI resin used as % of finished product

1,761.67 =average lbs. per hour of phenolic resin (100% solids) used during testing
 3.09% =Phenolic resin used as % of finished product

696.33 =average lbs. per hour of wax (100% solids) used during testing
 1.22% =wax used as % of finished product

info copied to summary page

28.50 =Plant Production rate in Tons per hour
 836.67 =MDI resin usage in pounds per hour
 1.47% =MDI resin usage as % of finished product
 1,761.67 =Liquid phenolic resin usage in pounds per hour (100% solids)
 3.09% =Liquid phenolic resin usage as % of finished product (100% solids)
 696.33 =Wax usage in pounds per hour
 1.22% =Wax usage as % of finished product

96

PRESS JULY 25th 1996
MDI, PHENOL, VOC, NOX, CO

DATA TIME	START=	16:20	END=	17:20	HOURS=	1.00
	START=	18:00	END=	19:00	HOURS=	1.00
	START=	19:35	END=	20:35	HOURS=	1.00
					TOTAL=	3.00

BOARD WEIGHTS - LBS

average weights determined by taking finished bundle weights.

7/16"
 per/peice 49.81
 per/ 8' x 24' 298.85

4482.8 lb= average
 bundle weight
 90 piece units

PLANT PRODUCTION RATE

- 3.00 =hours during testing
- 51 =pressloads
- 612 =no. of 8'x24' boards produced (pressloads x 12 boards per load)
- 117,504 =volume produced in surface footage (pressloads x 8'x24'x12 openings)
- 137,092 =volume produced 3/8" basis (pressloads x 8'x24'x 12 openings x 1.1667)
- 182,898 =lbs of finished product (boards produced x weight of finished board)
- 60,966 =lbs of finished product per hour (lbs of finished product / hours)
- 30.48 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

3.5 min / PRESSLOAD

*45.70 MSE/hr
318*

RESIN USAGE TAKEN FROM TOTALIZERS

TIME	MDI	PHENOL	WAX
16:20-17:20	793	1,707	677
18:00-19:00	793	1,703	677
19:35-20:35	793	1,709	677
AVERAGE	793.00	1,706.33	677.00

60,966 =average lbs. per hour finished product produced during testing
 793.00 =average lbs. per hour of MDI resin used during testing
 1.30% = MDI resin used as % of finished product

1,706.33 =average lbs. per hour of phenolic resin (100% solids) used during testing
 2.80% =Phenolic resin used as % of finished product

677.00 =average lbs. per hour of wax (100% solids) used during testing
 1.11% =wax used as % of finished product

info copied to summary page


- 30.48 =Plant Production rate in Tons per hour
- 793.00 =MDI resin usage in pounds per hour
- 1.30% =MDI resin usage as % of finished product
- 1,706.33 =Liquid phenolic resin usage in pounds per hour (100% solids)
- 2.80% =Liquid phenolic resin usage as % of finished product (100% solids)
- 677.00 =Wax usage in pounds per hour
- 1.11% =Wax usage as % of finished product

LOUISIANA-PACIFIC Sagola, Michigan

PRESS


7/25/96

0700-1900



LOUISIANA-PACIFIC Sagola, Michigan

PRESS
7/25/96
1900-0700



LOUISIANA-PACIFIC CORPORATION
SAGOLA, MICHIGAN PRESS REPORT

OPERATOR Krackenberger DATE 7-25-96
SHIFT Day CREW B

TIME TO POSITION (SECONDS)

SLOW OUT

F.L. RADIATORS	_____
HYD. COOLING FANS	_____
FRS COOLING FANS	_____
F.C.O.S.	_____
FORMER DECK	_____
LOADER	_____
UNLOADER	_____
PRESS	_____

GREASE COLUMNS	_____
FLUSH BLENDER	_____
BAGHOUSE PRES.	_____
HYD OIL TEMP	_____
INSP. PIT/RET CONVS	_____
CLEAN DECKLE CHAIN	_____
CLEAN BLENDERS	_____
CLEAN TAIL FULLEYS	_____

LN	SPD	FROM	TO	THICK	PRESS	LDs	FOOTAGE
81	7:00	7:10	5/32	3			8640
85	7:10	7:00	1/4	163			438157
						(1166)	(446,797)

DOWNTIME

FROM TO M E O MINS. REASON FOR DOWNTIME

FROM	TO	M	E	O	MINS.	REASON FOR DOWNTIME
10:45	11:10	V	V	V	25	sched MAint
11:20	12:25	✓			65	Lost Sur. Spinner Heads (changed #5)
1:10	1:12	✓			2	storage conv stopped
3:00	3:00	✓			1	Backed up (Prod)
3:14	3:20	✓			6	Storage CONV stopped
3:41	3:42	✓			1	changed Prod on storage
4:20	4:21	✓			1	Didn't make Limit #1 in Press
						(101)

1	55	61	68	121	78	181
2	54	62	68	122	78	182
3	53	63	65	123	76	183
4	45	64	67	124	74	184
5	47	65	67	125	73	185
6	49	66	72	126	73	186
7	52	67	73	127	73	187
8	55	68	72	128	73	188
9	52	69	76	129	74	189
10	56	70	77	130	72	190
11	55	71	79	131	76	191
12	57	72	81	132	73	192
13	57	73	82	133	73	193
14	72	74	79	134	74	194
15	71	75	74	135	73	195
16	68	76	75	136	74	196
17	70	77	73	137	74	197
18	71	78	70	138	74	198
19	70	79	72	139	72	199
20	70	80	71	140	73	200
21	69	81	71	141	75	201
22	69	82	72	142	75	202
23	68	83	72	143	74	203
24	70	84	74	144	75	204
25	69	85	82	145	76	205
26	69	86	84	146	76	206
27	70	87	82	147	75	207
28	70	88	82	148	75	208
29	68	89	84	149	72	209
30	65	90	79	150	72	210
31	69	91	78	151	72	211
32	62	92	78	152	71	212
33	63	93	78	153	69	213
34	61	94	73	154	71	214
35	64	95	74	155	72	215
36	64	96	77	156	69	216
37	63	97	76	157	68	217
38	63	98	77	158	69	218
39	63	99	80	159	71	219
40	64	100	81	160	69	220
41	62	101	82	161	69	221
42	63	102	85	162	69	222
43	63	103	84	163	69	223
44	63	104	84	164	67	224
45	62	105	82	165	66	225
46	62	106	81	166	64	226
47	58	107	75	167		227
48	52	108	82	168		228
49	59	109	74	169		229
50	57	110	75	170		230
51	58	111	79	171		231
52	60	112	78	172		232
53	61	113	80	173		233
54	60	114	79	174		234
55	60	115	78	175		235
56	62	116	76	176		236
57	64	117	76	177		237
58	64	118	78	178		238
59	64	119	78	179		239
60	64	120	79	180		240

OPERATOR Levi DATE 7-25-96
SHIFT Nites CREW 0

BLOW OUT _____
F.L. RADIATORS _____
HYD. COOLING FANS _____
PPS COOLING FANS _____
F.C.O.S. _____
FORMER DECK _____
LOADER _____
UNLOADER _____
PRESS _____

GREASE COLUMNS _____
FLUSH BLENDER _____
BAGHOUSE PRES. _____
HYD OIL TEMP _____
INSP. FIT/RET CONVS _____
CLEAN DECKLE CHAIN NEW TEST _____
CLEAN BLENDERS _____
CLEAN TAIL FULLEYS _____

1	64	61	66	121	52	181	55
2	64	62	65	122	54	182	55
3	64	63	64	123	52	183	55
4	63	64	66	124	52	184	55
5	61	65	62	125	53	185	55
6	65	66	60	126	53	186	56
7	64	67	58	127	52	187	54
8	66	68	54	128	50	188	54
9	69	69	44	129	50	189	55
10	69	70	44	130	48	190	54
11	69	71	43	131	49	191	52
12	69	72	44	132	48	192	54
13	69	73	44	133	46	193	54
14	71	74	46	134	48	194	54
15	67	75	45	135	46	195	54
16	68	76	43	136	47	196	54
17	69	77	42	137	46	197	54
18	68	78	43	138	47	198	54
19	68	79	42	139	48	199	54
20	71	80	42	140	49	200	54
21	70	81	42	141	49	201	54
22	69	82	41	142	52	202	54
23	70	83	42	143	51	203	54
24	70	84	43	144	51	204	54
25	69	85	44	145	51	205	54
26	69	86	42	146	51	206	54
27	68	87	40	147	51	207	54
28	70	88	57	148	49	208	54
29	71	89	54	149	50	209	54
30	69	90	54	150	47	210	54
31	69	91	54	151	47	211	54
32	69	92	57	152	47	212	54
33	69	93	55	153	48	213	54
34	69	94	58	154	48	214	54
35	70	95	57	155	44	215	54
36	68	96	52	156	47	216	54
37	71	97	49	157	48	217	54
38	69	98	53	158	55	218	54
39	69	99	55	159	54	219	54
40	68	100	55	160	55	220	54
41	69	101	50	161	56	221	54
42	70	102	55	162	55	222	54
43	69	103	55	163	56	223	54
44	68	104	55	164	54	224	54
45	69	105	39	165	54	225	54
46	68	106	57	166	56	226	54
47	67	107	57	167	54	227	54
48	66	108	54	168	56	228	54
49	67	109	54	169	54	229	54
50	63	110	52	170	54	230	54
51	66	111	50	171	57	231	54
52	68	112	49	172	58	232	54
53	67	113	46	173	59	233	54
54	65	114	48	174	55	234	54
55	65	115	47	175	55	235	54
56	67	116	47	176	56	236	54
57	66	117	49	177	57	237	54
58	65	118	50	178	60	238	54
59	67	119	49	179	57	239	54
60	67	120	51	180	56	240	54

LN	SPD FROM	TO	THICK	FRESS	LDS	FOOTAGE
84	7:00	11:00	7/16		67	
94	11:00	12:08	7/16		20	233,863
68	12:08	1:40	19/32		20	72,958
82	1:40	4:47	1/2		50	153,596
82	4:47	7:00	19/32		35	100,800
					193	561,217

softwood
Aspen

FROM	TO	M	E	O	MINS.	REASON FOR DOWNTIME
12:08	12:11				3	R1 #3 loader limit stuck
1:50	1:54				4	stall line - stacker Jam
5:21	5:32				1	dropped H.8 in loader #1 NO #
5:41	5:42				1	" "
					(9)	

SUPERVISOR Steve S. SHIFT D CREW B DATE 7-25-96

SHIFT OPERATING REPORT

PRESS OPERATION

Minutes Downtime

LINE SPEED	FROM	TO	THICKNESS	PRESS LOADS	3/8" FOOTAGE	Minutes Downtime		
						M	E	O
81	7:00	7:10	15/32	3	8640			
85	7:00	7:00	7/16	163	438,157	25	75	1
TOTAL				166	446,797	25	75	1

Dryer Lamp Test (OK)	
Surface Dryer Fan Load	92
Core Dryer Fan Load	92
Surf/Core Dryer Fan Load	89
#1 Baghouse Pressure	
#2 Baghouse Pressure	
Surface Wet Bin Volume*	90
Core Wet Bin Volume*	90
Surf/Core Wet Bin Volume*	F
Surface Dry Bin Volume*	75
Core Dry Bin Volume*	FL
Waldig Bin	408

NATURAL GAS METER READINGS	
(taken end of the shift)	
MAIN	02807160
PRESS RTO	59983190
DRYER RTO	15041150
GEKA	03241860
S DRYER	
C DRYER	
S/C DRYER	

GEKA EFB	BED KV	ION KV	ION MA	EFB - P	BH - P
	13	20	21	3.2	2.0

FLAKER RUN HOURS

#1 T.L.F	#2 T.L.F

BARK % MOISTURE	39.8%	FUEL % MOISTURE	2.2%
GRECONS. F-1			1.2/1.2

LOG COUNT

#1 6,487 #2 7,429 = 13,916
TOTAL

BARK FUEL COUNT: A 261 B 261

DRYER OPERATION

	Dry Fuel Usage Lbs.	Gas Usage Hrs.	Sust. Gas Usage Hrs.	Average Inlet Temp.	Running Time Mins	Ave. Wet Moisture	Ave. Dry Moisture
Surface	4637	6	123	746	691	48.8	6.6
Core	3022	4:20	5	755	720	46.2	6.9
S/Co	4873	0	29	710	720	44.8	6.1

REMARKS: #5 SPINNER HEAD SURF BLADES RIPPED OUT 6.5 min; 25 min SCHED 27 min

SUPERVISOR Dave Donati SHIFT Night CREW D DATE 7-25-96

SHIFT OPERATING REPORT

LINE SPEED	FROM	TO	THICKNESS	PRESS LOADS	3/8" FOOTAGE	Minutes Downtime		
						M	E	O
84	7:00	11:00	7/16	67				
94	11:00	12:08	7/16	20	233,863			
68	12:08	1:48	19/32	20	22,958	3		
82	1:49	4:47	1/2	50	153,596	4		
82	4:47	7:00	15/32	35	100,800	2		
TOTAL				192	561,217	9	-	-

Dryer Lamp Test (OK)	OK
Surface Dryer Fan Load	92.1
Core Dryer Fan Load	95.2
Surf/Core Dryer Fan Load	90.4
#1 Baghouse Pressure	OK
#2 Baghouse Pressure	OK
Surface Wet Bin Volume*	78
Core Wet Bin Volume*	74
Surf/Core Wet Bin Volume*	50
Surface Dry Bin Volume*	40
Core Dry Bin Volume*	30
Laidig Bin	Full

NATURAL GAS METER READINGS	
(taken end of the shift)	
MAIN	0128304400
PRESS RTO	60044380
DRYER RTO	15100360
GEKA	03241860
S DRYER	
C DRYER	
S/C DRYER	

GEKA EFB	BED KV	ION KV	ION MA	EFB - P	BH - P
	9.0	20	2.2	3.5	2.0

FLAKER RUN HOURS	
#1 T.LF	#2 T.LF

BARK % MOISTURE	36.8	FUEL % MOISTURE	2.2
GRECONS		20	

LOG COUNT

#1 4561 #2 7166 = 11727
TOTAL

BARK FUEL COUNT: A 256 B 256

DRYER OPERATION

	Dry Fuel Usage Lbs.	Gas Usage Hrs.	Sust. Gas Usage Hrs.	Average Inlet Temp.	Running Time Mins	Ave. Wet Moisture	Ave. Dry Moisture
Surface	6180	✓	0	774	720	40.2	6.0
Core	5524	✓	132	886	720	44.4	5.5
S/ICore	6293	✓	35	1027	720	46.8	6.0

REMARKS: NWDT 9min MISC

DAILY PRODUCTION REPORT

DATE: JULY 25, 1996

DAY: THURSDAY

LOUISIANA PACIFIC CORPORATION

SADOLA, MISSISSIPPI

SHIFT	BOARD SIZE	PRESS LOADS	NO. OF PANELS	SURFACE FOOTAGE	3/8" FOOTAGE
7AM.	15/32"	3	216	6,912	8,640
TO	7/16"	163	11,736	375,552	438,157
7PM.	0	0	0	0	0
	0	0	0	0	0
	0	0	0	0	0
B	0	0	0	0	0
CREW	0	0	0	0	0
SHIFT TOTAL				446,797	

SHIFT	7/16"	87	6,264	200,448	233,863
7PM.	19/32"SE	20	1,440	46,080	72,958
TO	1/2"	50	3,600	115,200	153,596
7AM.	15/32"	35	2,520	80,640	100,800
D	0	0	0	0	0
CREW	0	0	0	0	0
SHIFT TOTAL				561,217	

DAILY TOTAL	358	25,776	824,632	1,008,014
TOTAL			WTD.,	7,212,195

TOTAL	MTD	27,060,810
-------	-----	------------

TOTAL	YTD	193,232,603
-------	-----	-------------

MTD 3/8" FOOTAGE					
1/4"	202,761	1/2"	4,478,865	23/32"SE	0
3/8"	85,248	19/32"SE	1,152,743	23/32"H	5,966,122
7/16"	12,445,799	19/32"H	164,156	7/8"H	295,676
15/32"	2,269,440	5/8"	0	1 1/8"	0

SCHED. NET
 RUN RUN
 HOURS HOURS
 TIME CAP.

DAY	11.50	10.25	89.1%	119.1%
NIGHT	12.00	11.75	97.9%	143.4%
DAILY	23.50	22.00	93.6%	131.5%
WTD	163.00	159.00	97.5%	
MTD	649.25	595.50	91.7%	
YTD	4,731.50	4,460.00	94.3%	

FOREMAN	% PLANT	CAP
"A" M. MESSINA		132.0%
"B" D. SPIGARELLI		139.6%
"C" F. SHOQUIST		135.0%
"D" D. DONATI		142.9%

LOG CNT.	DAILY	WTD	MTD
A CREW	0	36,215	130,597
B CREW	13,916	41,325	167,625
C CREW	0	34,332	131,563
D CREW	11,727	40,772	168,082

GAS USAGE (MCF)	DAY	MTD
SURFACE DRYER	0	18,086
CORE DRYER	0	0
S/C DRYER	0	0
GEKA	0	0
PRESS RTO	0	0
DRYER RTO	0	0
TOTAL	587	18,086


DOWNTIME DAY SHIFT B-CREW 25 MIN. SCHEDULED MAINT., 65 MIN. SPINNER SURFACE BLENDER BURNED OUT., 11 MIN. MISC. DOWNTIME.

NIGHT SHIFT D-CREW 9 MIN. MISC.

LOUISIANA-PACIFIC Sagola, Michigan

PRESS RTD
7/25/96

PRESS RTD



7/25/96

SAGOLA PRESS RTO DATA SHEET

TIME 10 MINUTES	#1	#2	#3	#4	#5	INLET TEMP	BURNERS #1 #2	COMB. TEMP	EXHAUST TEMP	PRESS DROP	GAS USAGE
1:50	427	376	401	403	365	124	1522 1515	1522	240	20.7	9624.1
2:00	429	375	400	401	365	124	1521 1514	1521	243	20.6	
2:10	430	368	398	407	367	124	1519 1517	1526	240	20.8	9647.3
2:20	436	372	396	401	368	124	1520 1529	1529	239	20.2	
2:30	435	371	396	403	369	125	1514 1527	1517	239	20.3	
2:40	431	376	399	400	367	124	1519 1507	1516	236	20.7	9670.4
2:50	428	376	400	402	367	123	1521 1510	1521	237	20.8	
3:00	426	376	402	404	366	125	1525 1513	1527	240	20.6	
3:10	425	374	401	407	367	124	1522 1515	1525	243	20.6	9693.2
3:20	433	372	400	408	369	131	1513 1531	1534	241	20.5	
3:30	436	378	399	402	369	125	1516 1517	1524	243	20.7	
3:40	433	379	401	402	368	123	1519 1510	1519	238	20.7	9717.2
3:50	427	378	402	405	367	123	1523 1514	1523	240	20.6	
4:00	429	377	400	401	366	123	1523 1528	1517	238	20.6	
4:10	430	369	399	408	369	123	1524 1533	1531	238	20.6	9740.4
4:20	434	369	396	407	370	123	1515 1533	1525	235	20.7	
4:30	435	370	397	405	369	123	1513 1532	1521	236	20.6	
4:40	435	373	398	404	368	123	1516 1529	1519	239	20.4	
4:50	427	376	402	403	365	123	1524 1514	1524	239	20.7	9762.7
5:00	426	373	401	406	365	122	1520 1514	1525	241	20.6	
5:10	427	374	402	406	365	123	1520 1517	1524	241	20.7	
5:20	434	373	400	405	366	123	1512 1530	1523	237	20.6	9785.3
5:30	436	380	400	407	364	123	1518 1515	1514	238	21.0	
5:40	421	380	401	406	363	122	1519 1510	1518	235	20.9	9807.7
5:50	430	371	399	406	365	121	1520 1524	1528	238	20.7	
6:00	430	373	399	404	365	122	1521 1515	1522	242	20.8	
6:10	430	372	398	406	366	123	1522 1519	1524	241	20.8	9829.6
6:20	438	373	396	402	367	124	1515 1528	1519	236	20.9	
6:30	433	374	400	400	366	124	1521 1511	1521	238	20.3	
6:40	440	376	396	401	369	124	1521 1527	1518	240	20.8	
6:50	435	379	398	400	368	124	1522 1510	1519	239	20.8	9852.2
7:00	438	370	396	407	371	124	1513 1531	1521	237	20.7	
7:10	434	369	397	410	372	124	1514 1528	1527	238	20.7	9874.6
7:20	437	371	396	406	372	124	1517 1531	1522	238	20.7	
7:30	435	376	397	402	371	124	1521 1511	1518	240	20.9	
7:40	430	376	399	405	371	124	1521 1510	1520	239	20.9	9874.6

7/25/96

SAGOLA PRESS RTO DATA SHEET

TIME 10 MINUTES	#1	#2	#3	#4	#5	INLET TEMP	BURNERS #1 #2	COMB TEMP	EXHAUST TEMP.	PRESS DROP	GAS USAGE
7:50	428	374	400	407	373	124	1519 1513	1522	242	20.7	9877.3
8:00	429	368	400	413	374	124	1517 1528	1528	238	20.5	
8:10	429	368	400	413	374	123	1519 1527	1529	237	20.6	
8:20	431	369	399	412	374	123	1514 1529	1528	238	20.7	9919.6
8:30	433	376	399	404	371	122	1517 1510	1515	240	20.8	
8:40	434	373	399	406	370	124	1518 1529	1520	238	20.8	
8:50	429	380	402	403	367	123	1521 1514	1523	238	21.0	9942.8
9:00	431	373	399	409	369	124	1520 1525	1529	239	20.5	
9:10	436	375	399	405	368	124	1524 1532	1528	239	20.7	
9:20	438	380	397	400	367	124	1527 1529	1527	241	20.3	9966.0
9:30	432	382	398	400	365	123	1524 1518	1526	237	20.9	

Wheelabrator Clean Air Systems

Washington Energy Systems, Inc.
 P. Sagola Data Sheet
 Rev. 0. D.H.S. 3/5/95

Press

Crew / Name	R	MAT
Date	7-25-76	7-25-96
Time	10:00	16:00
Gas Meter reading	599431	599235
Burner S.P.	152/0	1519
Bnr #1 temp	1523	1514
Bnr #1 out	39.1	37.7
Bnr #2 temp	1524	1526
Bnr #2 out	37.2	36.5
Inlet temp	121	123
Chamber temp	1528	1527
Exhaust temp	238	238
RTO D.P.	21.0	20.4
Chm Pur Fan Amp	78	78
Main Fan Amps	25	22
BTUE on/off	OFF	OFF
PV setpoint	3.62	3.62
PV out	6.17	6.37
Cbr #1 B.O. temp	427	427
Cbr #2 B.O. temp	377	375
Cbr #3 B.O. temp	359	401
Cbr #4 B.O. temp	407	405
Cbr #5 B.O. temp	372	367
Brig next to mtr	92	97
Brig opp mtr	83	86
Mtr brig #1	108	116
Mtr brig #2	88	95

LINE OPERATORS

READINGS MUST BE TAKEN TWICE A SHIFT DAYS - 10:00 AND 16:00
 NIGHTS - 22:00 AND 04:00

24 HR. CHARTS MUST BE CHANGED OUT EVERY DAY @ 07:00

NOTE: INCONSISTENT AND UNUSUAL READINGS MUST BE ADDRESSED IN THE COMMENTS SECTION!

COMMENTS:

Blank lines for handwritten comments.

Wheelabrator Clean Air Systems

High Efficiency Energy System RTO
 P. Sagda Data Sheet
 Rev. D. D.H.S. 3/5/86

Press

Crew / Name	<i>E. C. ...</i>
Date	7-25-86
Time	9:55
Gas Meter reading	57499.6
Burner S.P.	1540
Bnr #1 temp	1538
Bnr #1 out	25.0
Bnr #2 temp	1536
Bnr #2 out	34.8
Inlet temp	123
Chamber temp	1542
Exhaust temp	243
RTO D.P.	20.9
Chm Pur Fan Amp	75
Main Fan Amps	75
BTUE on/off	ON
PV setpoint	3.62
PV out	6.33
Cbr #1 B.O. temp	436
Cbr #2 B.O. temp	382
Cbr #3 B.O. temp	395
Cbr #4 B.O. temp	397
Cbr #5 B.O. temp	366
Brig next to mtr	91
Brig opp mtr	83
Mtr brg #1	107
Mtr brg #2	80

LINE OPERATORS

READINGS MUST BE TAKEN TWICE A SHIFT DAYS - 10:00 AND 16:00
 NIGHTS - 22:00 AND 04:00

24 HR. CHARTS MUST BE CHANGED OUT EVERY DAY @ 07:00

NOTE: INCONSISTENT AND UNUSUAL READINGS MUST BE ADDRESSED IN THE COMMENTS SECTION!

COMMENTS:

Bundle Height Parameters H/weights

Notes:

Board Size	Pieces / Bundle	Target Thickness	Target Bd. Height	Target Bd. Weight
1/4"	120	0.290	31 1/4"	3288
1/4"	150	0.290	39"	4108
3/8"	100	0.380	38"	4002
7/16"	88	0.380	28 3/4"	2932
7/16"	90	0.435	39 1/8"	3998
1 5/32"	92	0.485	38 3/4"	4232
1/2"	86	0.510	30 5/8"	3100
1/2"	80	0.510	40 3/4"	4134
1 9/32" SE	85	0.595	38 5/8"	3681
1 9/32" HY	55	0.610	33 1/2"	3418
5/8" SE	40	0.620	24 3/4"	2612
7/8" SE	55	0.700	38 1/2"	3850
2 3/32" HY	45	0.730	32 7/8"	3285
7/8" HY	38	0.860	33 7/8"	3389
1-1/8" SE	38	1.085	38"	3854
1-1/8" HY	30	1.110	33 3/8"	3288

If the bundles heights are running plus or minus 3/8" from these figures, please notify the Quality Control Department and the Shift Foreman.

If the bundles weights are plus or minus 100 pounds from these figures, please notify the Quality Control Department and the Shift Foreman.

U Grade: Use normal piece count, edge seal, and 2 green stripes with the stencil on each side of the unit. Stencil the thickness on the lower right hand corner of the unit face, place tag close to bottom, and cover with plastic.

E Grade: 80 piece units thru 1/2", 50 piece units for 1 9/32 and 2 3/32, and 40 piece units for 7/8" and above. No edge seal, and 2 black stripes with the thickness logo on the lower right hand corner of the unit face. Place tag close to the bottom, and cover with plastic.

Bundle Height Data

Size 1 3/32		Size 7/16		Size		Size		Size		Size		Size	
No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height
2	33 3/4"	5	125 1/2"										
9	40 3/8"	5	87"										
		8	59 1/2"										
		9	40 1/2"										
		12	40 1/4"										
		15	98"										
		21	40"										
		22	40 1/8"										
		24	40 1/2"										
		31	40 1/2"										
		39	35 1/2"										
		45	57 1/2"										
		56	40 1/2"										
		62	40 1/2"										
		77	40 1/2"										
		83	40 1/2"										
		87	40 1/2"										
		92	40 1/2"										

Size	Time	Pieces	Height	Weight
7 1/2"	1613	90	41"	4587
	1650		40 1/2"	4547
	1645		40 5/8"	4532
	1700		40 1/4"	4507
	1710		40 1/2"	4562
	1790		40 1/2"	4550
	1745		"	4562
	1800		40 1/2"	4567
	1815		40 1/4"	4550
	1830		40 5/8"	4551
	1848		40 1/2"	4529
	1900		40 1/4"	4552

EPA Data

Size	Time	Pieces	Height	Weight
15 1/2"	07:00	82	40	4301
15 1/2"	07:15	82	40	4291
7 1/2"	07:30	90	38 3/4"	4128
7 1/2"	07:45	90	38 3/4"	4229
7 1/2"	08:00	90	38 3/4"	4288
7 1/2"	08:15	90	40 1/2"	4513
7 1/2"	08:30	90	40 1/2"	4522
7 1/2"	08:45	90	40 1/2"	4477
7 1/2"	09:00	90	40 1/4"	4505
7 1/2"	09:15	90	40 1/2"	4371
	09:30		40	4417
	09:45		40 1/2"	4467
	10:00		41 1/2"	4401
	10:15		39 3/4"	4389
	10:30		"	4457
	10:45		40 1/2"	4465
	11:00		40 1/2"	4400
	11:15		40 1/2"	4431
	11:30		41 1/4"	4432
Down Time				
	12:45		38 1/2"	4159
	13:00		39 3/4"	4139
	13:15		39 1/2"	4130
	13:30		40 1/2"	4345
	13:45		39 1/2"	4099
	14:00		40 3/4"	4377
	14:15		40 1/2"	4389
	14:30		40 1/2"	4409
	14:45		40 1/2"	4477
	15:00		40 1/2"	4400
	15:15		40 3/4"	4372
	15:30		"	4458
	15:45		40 1/2"	4471
	16:00		40 1/2"	4583

Bundle Height Parameters / weights

7/25/91

Notes:

If the bundles heights are running plus or minus 3/8" from these figures, please notify the Quality Control Department and the Shift Foreman.

If the bundles weights are plus or minus 100 pounds from these figures, please notify the Quality Control Department and the Shift Foreman.

U Grade: Use normal piece count, edge seal, and 2 green stripes with the stencil on each side of the unit. Stencil the thickness on the lower right hand corner of the unit face, place tag close to bottom, and cover with plastic.

E Grade: 80 piece units thru 1/2", 50 piece units for 19/32 and 23/32, and 40 piece units for 7/8" and above. No edge seal, and 2 black stripes with the thickness logo on the lower right hand corner of the unit face. Place tag close to the bottom, and cover with plastic.

Board Size	Pieces / Bundle	Target Thickness	Target Bd. Height	Target Bd. Weight
1/4"	120	0.260	31 1/4"	3286
1/4"	150	0.260	39"	4108
3/8"	100	0.380	38"	4003
7/16"	66	0.380	28 3/4"	2932
7/16"	90	0.435	39 1/8"	3999
15/32"	82	0.485	39 3/4"	4232
1/2"	66	0.510	30 5/8"	3100
1/2"	80	0.510	40 3/4"	4134
19/32" SE	65	0.595	38 5/8"	3981
19/32" HY	55	0.610	33 1/2"	3418
5/8" SE	40	0.620	24 3/4"	2612
23/32" SE	55	0.700	38 1/2"	3850
23/32" HY	45	0.730	32 7/8"	3285
7/8" HY	38	0.890	33 7/8"	3389
1-1/8" SE	36	1.085	39"	3854
1-1/8" HY	30	1.110	33 3/8"	3288

Bundle Height Data

Size		Size		Size		Size		Size		Size	
No.	Height	No.	Height	No.	Height	No.	Height	No.	Height	No.	Height
3	40										
6	40 1/4										
9	40										
12	-										
15	39 3/4										
18	-										
21	40										
24	39 3/4										
27	40										
30	-										
33	41 1/4										
36	39 3/4										
39	-										
42	-										
45	-										
48	-										
51	-										
54	-										
57	-										
60	-										
63	-										
66	-										
69	-										
72	-										

EPA Data


Size	Time	Pieces	Height	Weight
7/16	1914	90	40	443
7/16	1922	90	39 3/4	4424
7/16	1934	90	40	4513
7/16	1954	90	39 1/2	4461
7/16	2000	90	39 3/4	4475
7/16	2018	90	40	4487
7/16	2036	90	40	4500
7/16	2052	70	39 3/4	4464
7/16	2109	90	40	4491
7/16	2124	90	40 1/4	4484
7/16	2138	90	39 3/4	4438
7/16				

Variable Data

** Please make recording every half hour **

DATE	TIME	THICK	LINE SPEED	SURFACE		SUFACE			CORE		
				DRY-3IN %	DRY-3IN %	RESIN	RESIN	SURFACE	RESIN	RESIN	CCRE
				POT-SET	GPM	WAX	POT-SET	GPM	WAX		
25	8:05	7/16	85	48	65	999	4.87	948	702	1.268	743
	8:40	7/16	85	43	55	999	4.87	948	702	1.268	743
	9:15	7/16	85	43	45	999	4.86	948	702	1.278	743
	9:45	7/16	85	40	35	999	4.87	948	702	1.278	743
	10:20	7/16	84	42	25	999	4.85	948	702	1.278	743
	11:10	7/16		55	50	999	4.85	948	702	1.289	743
	11:40	7/16		64	63	999	4.85	948	702	1.382	743
	1:10	7/16		F	77	999	4.85	948	752	6382	783
	2:05	7/16	82	F	F	999	4.84	948	702	1.278	743
	3:00	7/16	84	F	F	999	4.84	948	702	1.278	743
	4:45	7/16	84	70	F	999	4.84	948	702	1.278	743
	5:00	7/16	84	78	F	999	4.82	948	702	1.278	743
	5:35	7/16	84	F	70	999	4.72	948	702	1.268	743
	6:50	7/16	84	70	F	999	4.83	948	702	1.278	743
	26	7:20	7/16	84	FW	FW	999	4.84	948	702	1.278
8:30		7/16	84	FW	FW	999	4.85	948	702	1.278	743
9:30		7/16	84	65	70	999	4.85	948	702	1.278	743
11:10		7/16	94	70	70						
11:55		7/16	94	73	72						
1:00		19/32	68	FW	80						
1:25		19/32	68	FW	FW						
2:00		1/2	82	FW	FW						
3:00		1/2	82	70	67						
4:00		1/2	82	70	65						
4:30		1/2	82	68	68						
6:30		15/32	81	FW	74						
6:45		15/32	81	78	74						
7:26		7:15	15/32	81	68	70					
7:30		15/32	81	63	65						
7:15	15/32	81	60	61							
8:50	15/32	81	46	50	914	4.56	856	707	1.293	820	
9:25	15/32	81	40	40							

LOUISIANA PACIFIC
Sagola, Michigan





APPENDIX J

PROCEDURES



Particulate Loading and Emission Rates

The particulate emission rates were determined per EPA Methods 1 - 5, CFR Title 40, Part 60, Appendix A (revised July 1, 1995). In this procedure a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass-lined sampling probe equipped with a Type S pitot and a thermocouple. The probe is attached to a sampling module which houses the all-glass in line filter holder in a temperature controlled oven. The sampling module also houses the impinger case and a Drierite filled column. The sampling module is connected by means of an umbilical cord to the control module. The control module houses the dry test gas meter, the calibrated orifice, a leakless pump, two inclined manometers, and all controls required for operating the sampling train.

Particulate samples are collected as follows: The sample gas is drawn through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter where particulates are removed. The sample gas is then passed through an ice-cooled impinger train and a desiccant-packed column which absorbs remaining moisture. The sample gas then passes through a vacuum pump followed by a dry test gas meter. The gas meter integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gasmeter provides real time flow rate data.

A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each test point maintaining isokinetic sampling conditions. Nomographs are used for rapid determination of the sampling rate.


Particulate Loading and Emission Rates

After sampling is complete, the filter is removed and placed in a clean container. The nozzle and inlet side of the filter holder are quantitatively washed with acetone and the washings are stored in a second container. A brush is often used in the cleaning step to help dislodge deposits. The samples are returned to the laboratory where they are logged in and analyzed. The volume of the acetone rinse ("probe wash") is noted and then the rinse is quantitatively transferred to a tared 120 cc porcelain evaporating dish and the acetone evaporated off at 97-105 °F. This temperature is used to prevent condensation of atmospheric moisture due to the cooling effect induced by the evaporation of acetone. The acetone-free sample is then transferred to an oven and dried at 105 °C for 30 minutes, cooled in a desiccator over Drierite, and then weighed to the nearest .01 mg. The filter sample is quantitatively transferred to a 6-inch watch glass and dried in an oven at 105 °C for two hours. The filter and watch glass are then cooled in a desiccator and the filter weighed to the nearest .01 mg. All weighings are performed in a balance room where the relative humidity is hydrostated to less than 50% relative humidity. Microscopic examination of the samples is performed if any unusual characteristics are observed. The weight of the acetone rinse is corrected for the acetone blank. The Drierite column is weighed on-site and the water collected by Drierite is added to the condensate so that the total amount of absorbed water may be ascertained.

Integrated flue gas samples for Orsat analysis were collected simultaneously with each pollutant sample. The samples were collected in 15-liter gas sampling bags at a constant flow rate throughout each particulate run. The bags were at a constant flow rate throughout each particulate run. The bags were then returned to the laboratory and analyzed by Orsat analysis. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen).

Interpoll Laboratories
(612) 786-6020

PARTICULATE SAMPLING TRAIN



Method 3A—Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 **Applicability.** This method is applicable to the determination of oxygen (O₂) and carbon dioxide (CO₂) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 **Principle.** A sample is continuously extracted from the effluent stream: a portion of the sample stream is conveyed to an instrumental analyzer(s) for determination of O₂ and CO₂ concentration(s). Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

Same as Method 6C, Sections 2.1 and 2.2, except that the span of the monitoring system shall be selected such that the average O₂ or CO₂ concentration is not less than 20 percent of the span.

3. Definitions

3.1 **Measurement System.** The total equipment required for the determination of the O₂ or CO₂ concentration. The measurement system consists of the same major subsystems as defined in Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.2 **Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, Response Time, and Calibration Curve.** Same as Method 6C, Sections 3.2 through 3.8, and 3.10.

3.3 **Interference Response.** The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 **Measurement System.** Any measurement system for O₂ or CO₂ that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 **Sample Probe.** A leak-free probe, of sufficient length to traverse the sample points.

5.1.2 **Sample Line.** Tubing, to transport the sample gas from the probe to the moisture removal system. A heated sample line is not required for systems that measure the O₂ or CO₂ concentration on a dry basis, or transport dry gases.

5.1.3 **Sample Transport Line, Calibration Value Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder.** Same as Method 6C, Sections 5.1.3 through 5.1.9, and 5.1.11, except that the requirements to use stainless steel, Teflon, and nonreactive glass filters do not apply.

5.1.4 **Gas Analyzer.** An analyzer to determine continuously the O₂ or CO₂ concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer. The requirements for measuring and controlling the analyzer flow rate are not applicable if data are presented that demonstrate the analyzer is insensitive to flow variations over the range encountered during the test.

5.2 **Calibration Gases.** The calibration gases for CO₂ analyzers shall be CO₂ in N₂ or CO₂ in air. Alternatively, CO₂/SO₂, O₂/SO₂, or O₂/CO₂/SO₂ gas mixtures in N₂ may be used. Three calibration gases, as specified Section 5.3.1 through 5.3.3 of Method 6C, shall be used. For O₂ monitors that cannot analyze zero gas, a calibration gas concentration equivalent to less than 10 percent of the span may be used in place of zero gas.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 **Calibration Concentration Verification.** Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 3 and change the acceptance criteria for agreement among Method 3 results to 5 percent (or 0.2 percent by volume, whichever is greater).

6.2 **Interference Response.** Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the type of gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 **Measurement System Preparation, Analyzer Calibration Error, and Sampling System Bias Check.** Follow Sections 6.2 through 6.4 of Method 6C.

7. Emission Test Procedure

7.1 **Selection of Sampling Site and Sampling Points.** Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 3.

7.2 **Sample Collection.** Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the sampling system bias check. Maintain constant rate sampling (i.e., ± 10 percent) during the entire run. The sampling time per run shall be the same as for tests conducted using Method 3 plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed to determine the average effluent concentration.

7.3 **Zero and Calibration Drift Test.** Follow Section 7.4 of Method 6C.

8. Quality Control Procedures

The following quality control procedures are recommended when the results of this method are used for an emission rate correction factor, or excess air determination. The tester should select one of the following options for validating measurement results:

8.1 If both O₂ and CO₂ are measured using Method 3A, the procedures described in Section 4.4 of Method 3 should be followed to validate the O₂ and CO₂ measurement results.

8.2 If only O₂ is measured using Method 3A, measurements of the sample stream CO₂ concentration should be obtained at the sample by-pass vent discharge using an Orsat or Fyrite analyzer, or equivalent. Duplicate samples should be obtained concurrent with at least one run. Average the duplicate Orsat or Fyrite analysis results for each run. Use the average CO₂ values for comparison with the O₂ measurements in accordance with the procedures described in Section 4.4 of Method 3.

8.3 If only CO₂ is measured using Method 3A, concurrent measurements of the sample stream CO₂ concentration should be obtained using an Orsat or Fyrite analyzer as described in Section 8.2. For each run, differences greater than 0.5 percent between the Method 3A results and the average of the duplicate Fyrite analysis should be investigated.

9. Emission Calculation

For all CO₂ analyzers, and for O₂ analyzers that can be calibrated with zero gas, follow Section 8 of Method 6C, except express all concentrations as percent, rather than ppm.

For O₂ analyzers that use a low-level calibration gas in place of a zero gas, calculate the effluent gas concentration using Equation 3A-1.

$$C_{gas} = \frac{C_{ma} - C_{oa}}{C_m - C_o} - (\bar{C} - C_m) + C_{ma} \text{ Eq. 3A-1}$$

Where:

- C_{gas} = Effluent gas concentration, dry basis, percent.
- C_{ma} = Actual concentration of the upscale calibration gas, percent.
- C_{oa} = Actual concentration of the low-level calibration gas, percent.
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, percent.
- C_o = Average of initial and final system calibration bias check responses for the low-level gas, percent.
- \bar{C} = Average gas concentration indicated by the gas analyzer, dry basis, percent.

10. Bibliography

Same as bibliography of Method 6C.

Flow

Flow determinations were carried out in accordance with EPA Method 2, CFR Title 40, Part 60, Appendix A (Revised July 1, 1987). A type S pitot was used to sense velocity pressure and an inclined manometer was used to measure velocity pressures. Gas temperatures were measured using a calibrated Type K thermocouple and digital temperature meter. Gas density (i.e. molecular weight) was calculated from the composition of the gas which was determined by Orsat.

Gas Flow Density

Gas compositions were determined as per Method 3 by Orsat analysis of an integrated gas sample collected from the stack during the oxides of nitrogen determinations. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen).


Oxides of Nitrogen

Oxides of nitrogen concentrations were collected in accordance with EPA Method 7 (see above-cited reference) with a specially designed all glass manifold and valving assembly and a heated stainless steel-lined probe. Samples were collected in two-liter evacuated insulated flasks which contained 25 cc of acidified peroxide solution (Method 7 reagent). Nine sets or more of three samples each were collected over a period of 4.5 to 5 hours.

The sampling train was leak checked through the probe at the beginning and end of the test and, in addition, the system leak checked at the time of evacuation of each flask. Before the samples were collected, the probe was purged to eliminate dead volume effects and to raise the temperature of the probe outlet and manifold assembly to minimize condensation of moisture. A plug of microfiber glass wool inserted in the probe inlet was used to prevent particulate material from entering into the flask. The temperature of the flask, vacuum in the

flask and barometric pressure at the time of sampling was recorded for each flask. After sampling was complete, as evidenced by the in-line vacuum gauge, the flask valve was closed, the flask assembly disconnected from the manifold/valve assembly and the flask shook for several minutes to promote oxidation and absorption. The recovered oxides of nitrogen samples were returned to the laboratory and analyzed immediately by ion chromatography as per EPA 7A.

The internal volume of each numbered flask assembly has been measured prior to initial use by filling with water, weighing before and after and then converting the weight of water to volume by means of the density of water at room temperature. Flask volumes are stored in the computer and recalled automatically in the computer calculation.



Sampling train, flask valve, and flask.

Method 7E—Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 **Applicability.** This method is applicable to the determination of nitrogen oxides (NO_x) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 **Principle.** A gas sample is continuously extracted from a stack, and a portion of the sample is conveyed to an instrumental chemiluminescent analyzer for determination of NO_x concentration. Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

Same as Method 6C, Sections 2.1 and 2.2.

3. Definitions

3.1 **Measurement System.** The total equipment required for the determination of NO_x concentration. The measurement system consists of the following major subsystems:

3.1.1 **Sample Interface, Gas Analyzer, and Data Recorder.** Same as Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.1.2 **NO_2 to NO Converter.** A device that converts the nitrogen dioxide (NO_2) in the sample gas to nitrogen oxide (NO).

3.2 **Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, and Response Time.** Same as Method 6C, Sections 3.2 through 3.8.

3.3 **Interference Response.** The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 **Measurement System.** Any measurement system for NO_x that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 Sample Probe, Sample Line, Calibration Valve Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder. Same as Method 6C, Sections 5.1.1 through 5.1.9, and 5.1.11.

5.1.2 NO₂ to NO Converter. That portion of the system that converts the nitrogen dioxide (NO₂) in the sample gas to nitrogen oxide (NO). An NO₂ to NO converter is not necessary if data are presented to demonstrate that the NO₂ portion of the exhaust gas is less than 5 percent of the total NO_x concentration.

5.1.3 NO_x Analyzer. An analyzer based on the principles of chemiluminescence, to determine continuously the NO_x concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer.

5.2 NO_x Calibration Gases. The calibration gases for the NO_x analyzer shall be NO in N₂. Three calibration gases, as specified in Sections 5.3.1 through 5.3.3. of Method 6C, shall be used. Ambient air may be used for the zero gas.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Gas Concentration Verification. Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 7, and change all 5 percent performance values to 10 percent (or 10 PPM, whichever is greater).

6.2 Interference Response. Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 Measurement System Preparation, Analyzer Calibration Error, and Sample System Bias Check. Follow Sections 6.2 through 6.4 of Method 6C.

6.4 NO₂ to NO Conversion Efficiency. Unless data are presented to demonstrate that the NO₂ concentration within the sample stream is not greater than 5 percent of the NO_x concentration, conduct an NO₂ to NO conversion efficiency test in accordance with Section 5.6 of Method 20.

7. Emission Test Procedure

7.1 **Selection of Sampling Site and Sampling Points.** Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 7.

7.2 **Sample Collection.** Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the system calibration drift test. Maintain constant rate sampling (i.e., ± 10 percent) during the entire run. The sampling time per run shall be the same as the total time required to perform a run using Method 7, plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed, to determine the average effluent concentration.

7.3 **Zero and Calibration Drift Test.** Follow Section 7.4 of Method 6C.

8. Emission Calculation

Follow Section 8 of Method 6C.

9. Bibliography

Same as bibliography of Method 6C.

Method 10—Determination of Carbon Monoxide Emissions From Stationary Sources

1. Principle and Applicability

1.1 **Principle.** An integrated or continuous gas sample is extracted from a sampling point and analyzed for carbon monoxide (CO) content using a Luft-type nondispersive infrared analyzer (NDIR) or equivalent.

1.2 **Applicability.** This method is applicable for the determination of carbon monoxide emissions from stationary sources only when specified by the test procedures for determining compliance with new source performance standards. The test procedure will indicate whether a continuous or an integrated sample is to be used.

2. Range and Sensitivity

2.1 **Range.** 0 to 1,000 PPM.

2.2 **Sensitivity.** Minimum detectable concentration is 20 PPM for a 0 to 1,000 PPM span.

3. Interferences

Any substance having a strong absorption of infrared energy will interfere to some extent. For example, discrimination ratios for water (H₂O) and carbon dioxide (CO₂) are 3.5 percent H₂O per 7 PPM CO and 10 percent CO₂ per 10 PPM CO, respectively, for devices measuring in the 1,500 to 3,000 PPM range. For devices measuring in the 0 to 100 PPM range, interference ratios can be as high as 3.5 percent H₂O per 25 PPM CO and 10 percent CO₂ per 50 PPM CO. The use of silica gel and ascarite traps will alleviate the major interference problems. The measured gas volume must be corrected if these traps are used.

4. Precision and Accuracy

4.1 **Precision.** The precision of most NDIR analyzers is approximately ± 2 percent of span.

4.2 **Accuracy.** The accuracy of most NDIR analyzers is approximately ± 5 percent of span after calibration.

5. Apparatus

5.1 Continuous Sample (Figure 10-1).

5.1.1 **Probe.** Stainless steel or sheathed Pyrex\1\ glass, equipped with a filter to remove particulate matter.

5.1.2 **Air-Cooled Condenser or Equivalent.** To remove any excess moisture.

5.2 Integrated Sample (Figure 10-2).

042694-G:\STACK\WPMETHODS\METH.10

5.2.1 **Probe.** Stainless steel or sheathed Pyrex glass, equipped with a filter to remove particulate matter.

5.2.2 **Air-Cooled Condenser or Equivalent.** To remove any excess moisture.

5.2.3 **Valve.** Needle valve, or equivalent, to adjust flow rate.

5.2.4 **Pump.** Leak-free diaphragm type, or equivalent, to transport gas.

5.2.5 **Rate Meter.** Rotameter, or equivalent, to measure a flow range from 0 to 1.0 liter per min (0.035 cfm).

5.2.6 **Flexible Bag.** Tedlar, or equivalent, with a capacity of 60 to 90 liters (2 to 3 ft³). Leak-test the bag in the laboratory before using by evacuating bag with a pump followed by a dry gas meter. When evacuation is complete, there should be no flow through the meter.

5.2.7 **Pitot Tube.** Type S, or equivalent, attached to the probe so that the sampling rate can be regulated proportional to the stack gas velocity when velocity is varying with the time or a sample traverse is conducted.

5.3 Analysis (Figure 10-3).

5.3.1 **Carbon Monoxide Analyzer.** Nondispersive infrared spectrometer, or equivalent. This instrument should be demonstrated, preferably by the manufacturer, to meet or exceed manufacturer's specifications and those described in this method.

5.3.2 **Drying Tube.** To contain approximately 200 g of silica gel.

5.3.3 **Calibration Gas.** Refer to section 6.1.

5.3.4 **Filter.** As recommended by NDIR manufacturer.

[_See_CFR_paper_publication_for_illustration_18A

5.3.5 **CO₂ Removal Tube.** To contain approximately 500 g of ascarite.

5.3.6 **Ice Water Bath.** For ascarite and silica gel tubes.

5.3.7 **Valve.** Needle valve, or equivalent, to adjust flow rate

5.3.8 **Rate Meter.** Rotameter or equivalent to measure gas flow rate of 0 to 1.0 liter per min (0.035 cfm) through NDIR.

5.3.9 **Recorder (optional).** To provide permanent record of NDIR readings.

6. Reagents

6.1 **Calibration Gases.** Known concentration of CO in nitrogen (N₂) for instrument span, prepurified grade of N₂ for zero, and two additional concentrations corresponding approximately to 60 percent and 30 percent span. The span concentration shall not exceed 1.5 times the applicable source performance standard. The calibration gases shall be certified by the manufacturer to be within ± 2 percent of the specified concentration.

|_See_CFR_paper_publication_for_illustration_19A

6.2 **Silica Gel.** Indicating type, 6 to 16 mesh, dried at 175°C (347°F) for 2 hours.

6.3 **Ascarite.** Commercially available.

7. Procedure

7.1 **Sampling.**

7.1.1 **Continuous Sampling.** Set up the equipment as shown in Figure 10-1 making sure all connections are leak free. Place the probe in the stack at a sampling point and purge the sampling line. Connect the analyzer and begin drawing sample into the analyzer. Allow 5 minutes for the system to stabilize, then record the analyzer reading as required by the test procedure. (See section 7.2 and 8). CO₂ content of the gas may be determined by using the Method 3 integrated sample procedure, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.1.2 **Integrated Sampling.** Evacuate the flexible bag. Set up the equipment as shown in Figure 10-2 with the bag disconnected. Place the probe in the stack and purge the sampling line. Connect the bag, making sure that all connections are leak free. Sample at a rate proportional to the stack velocity. CO₂ content of the gas may be determined by using the Method 3 integrated sample procedures, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.2 **CO Analysis.** Assemble the apparatus as shown in Figure 10-3, calibrate the instrument, and perform other required operations as described in section 8. Purge analyzer with N₂ prior to introduction of each sample. Direct the sample stream through the instrument for the test period, recording the readings. Check the zero and span again after the test to assure that any drift or malfunction is detected. Record the sample data on Table 10-1.

8. Calibration

Assemble the apparatus according to Figure 10-3. Generally an instrument requires a warm-up period before stability is obtained. Follow the manufacturer's instructions for specific procedure. Allow a minimum time of 1 hour for warm-up. During this time check the sample conditioning apparatus, i.e., filter, condenser, drying tube, and CO₂ removal tube, to ensure that each component is in good operating condition. Zero and calibrate the instrument according to the manufacturer's procedures using, respectively, nitrogen and the calibration gases.

Table 10-1—Field data

Comments

Location _____

Test _____

Date _____

Operator _____

Clock time	Rotameter setting, liters per minute (cubic feet per minute)
------------	---

9. Calculation

Calculate the concentration of carbon monoxide in the stack using Equation 10-1.

$$\text{CCO stack} = \text{CCO NDIR}(1-\text{FCO}_2) \quad \text{Eq. 10-1}$$

Where:

CCO stack = Concentration of CO in stack, PPM by volume (dry basis).

CCO NDIR = Concentration of CO measured by NDIR analyzer, PPM by volume (dry basis).

FCO₂ = Volume fraction of CO₂ in sample, i.e., percent CO₂ from Orsat analysis divided by 100.

10. Alternative Procedures

10.1 **Interference Trap.** The sample conditioning system described in Method 10A, sections 2.1.2 and 4.2, may be used as an alternative to the silica gel and ascarite traps.

11. Bibliography

1. McElroy, Frank, The Intertech NDIR-CO Analyzer, Presented at 11th Methods Conference on Air Pollution, University of California, Berkeley, CA. April 1, 1970.
2. Jacobs, M. B., et al., Continuous Determination of Carbon Monoxide and Hydrocarbons in Air by a Modified Infrared Analyzer, J. Air Pollution Control Association, 9(2): 110-114. August 1959.
3. MSA LIRA Infrared Gas and Liquid Analyzer Instruction Book, Mine Safety Appliances Co., Technical Products Division, Pittsburgh, PA.
4. Models 215A, 315A, and 415A Infrared Analyzers, Beckman Instruments, Inc., Beckman Instructions 1635-B, Fullerton, CA. October 1967.
5. Continuous CO Monitoring System, Model A5611, Intertech Corp., Princeton, NJ.
6. UNOR Infrared Gas Analyzers, Bendix Corp., Ronceverte, WV

Agenda

A. Performance Specifications for NDIR Carbon Monoxide Analyzers

Range (minimum)	0—1000 PPM.
Output (minimum)	0—10mV.
Minimum detectable sensitivity	20 PPM.
Rise time, 90 percent (maximum)	30 seconds.
Fall time, 90 percent (maximum)	30 seconds.
Zero drift (maximum)	10% in 8 hours.
Span drift (maximum)	10% in 8 hours.
Precision (minimum)	± 2% of full scale.
Noise (maximum)	± 1% of full scale.
Linearity (maximum deviation)	2% of full scale.
Interference rejection ratio	CO ₂ —1000 to 1, H ₂ O—500 to 1.

B. Definitions of Performance Specifications.

Range—The minimum and maximum measurement limits.

Output—Electrical signal which is proportional to the measurement; intended for connection to readout or data processing devices. Usually expressed as millivolts or milliamps full scale at a given impedance.

Full scale—The maximum measuring limit for a given range.

Minimum detectable sensitivity—The smallest amount of input concentration that can be detected as the concentration approaches zero.

Accuracy—The degree of agreement between a measured value and the true value; usually expressed as \pm percent of full scale.

Time to 90 percent response—The time interval from a step change in the input concentration at the instrument inlet to a reading of 90 percent of the ultimate recorded concentration.

Rise Time (90 percent)—The interval between initial response time and time to 90 percent response after a step increase in the inlet concentration.

Fall Time (90 percent)—The interval between initial response time and time to 90 percent response after a step decrease in the inlet concentration.

Zero Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is zero; usually expressed as percent full scale.

Span Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is a stated upscale value; usually expressed as percent full scale.

Precision—The degree of agreement between repeated measurements of the same concentration, expressed as the average deviation of the single results from the mean.

Noise—Spontaneous deviations from a mean output not caused by input concentration changes.

Linearity—The maximum deviation between an actual instrument reading and the reading predicted by a straight line drawn between upper and lower calibration points.

Method 10A—Determination of Carbon Monoxide Emissions in Certifying Continuous Emission Monitoring Systems at Petroleum Refineries

1. Applicability and Principle

1.1 Applicability. This method applies to the measurement of carbon monoxide (CO) at petroleum refineries. This method serves as the reference method in the relative accuracy test for nondispersive infrared (NDIR) CO continuous emission monitoring systems (CEMS's) that are required to be installed in petroleum refineries on fluid catalytic cracking unit catalyst regenerators [40 CFR Part 60.105(a)(2)].

1.2 Principle. An integrated gas sample is extracted from the stack, passed through an alkaline permanganate solution to remove sulfur and nitrogen oxides, and collected in a Tedlar bag. The CO concentration in the sample is measured spectrophotometrically using the reaction of CO with p-sulfaminobenzoic acid.

1.3. Range and Sensitivity.

1.3.1 Range. Approximately 3 to 1800 PPM CO. Samples having concentrations below 400 PPM are analyzed at 425 nm, and samples having concentrations above 400 PPM are analyzed at 600 nm.

1.3.2 Sensitivity. The detection limit is 3 PPM based on three times the standard deviation of the mean reagent blank values.

Method 25A-Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer

1. Applicability and Principle

1.1 **Applicability.** This method applies to the measurement of total gaseous organic concentration of vapors consisting primarily of alkanes, alkenes, and/or arenes (aromatic hydrocarbons). The concentration is expressed in terms of propane (or other appropriate organic calibration gas) or in terms of carbon.

1.2 **Principle.** A gas sample is extracted from the source through a heated sample line, if necessary, and glass fiber filter to a flame ionization analyzer (FIA). Results are reported as volume concentration equivalents of the calibration gas or as carbon equivalents.

2. Definitions

2.1 **Measurement Systems.** The total equipment required for the determination of the gas concentration. The system consists of the following major subsystems:

2.1.1 **Sample Interface.** That portion of the system that is used for one or more of the following: sample acquisition, sample transportation, sample conditioning, or protection of the analyzer from the effects of the stack effluent.

2.1.2 **Organic Analyzer.** That portion of the system that senses organic concentration and generates an output proportional to the gas concentration.

2.2 **Span Value.** The upper limit of a gas concentration measurement range that is specified for affected source categories in the applicable part of the regulations. The span value is established in the applicable regulation and is usually 1.5 to 2.5 times the applicable emission limit. If no span value is provided, use a span value equivalent to 1.5 to 2.5 times the expected concentration. For convenience, the span value should correspond to 100 percent of the recorder scale.

2.3 **Calibration Gas.** A known concentration of a gas in an appropriate diluent gas.

2.4 **Zero Drift.** The difference in the measurement system response to a zero level calibration gas before and after a stated period of operation during which no unscheduled maintenance, repair, or adjustment took place.

2.5 **Calibration drift.** The difference in the measurement system response to a midlevel calibration gas before and after a stated period of operation during which no unscheduled maintenance, repair or adjustment took place.

2.6 **Response Time.** The time interval from a step change in pollutant concentration at the inlet to the emission measurement system to the time at which 95 percent of the corresponding final value is reached as displayed on the recorder.

2.7 **Calibration Error.** The difference between the gas concentration indicated by the measurement system and the known concentration of the calibration gas.

3. Apparatus

A schematic of an acceptable measurement system is shown in Figure 25A-1. The essential components of the measurement system are described below:

3.1 **Organic Concentration Analyzer.** A flame ionization analyzer (FIA) capable of meeting or exceeding the specifications in this method.

3.2 **Sample Probe.** Stainless steel, or equivalent, three-hole rake type. Sample holes shall be 4 mm in diameter or smaller and located at 16.7, 50, and 83.3 percent of the equivalent stack diameter. Alternatively, a single opening probe may be used so that a gas sample is collected from the centrally located 10 percent area of the stack cross-section.

3.3 **Sample Line.** Stainless steel or Teflon * tubing to transport the sample gas to the analyzer. The sample line should be heated, if necessary, to prevent condensation in the line.

3.4 **Calibration Valve Assembly.** A three way valve assembly to direct the zero and calibration gases to the analyzers is recommended. Other methods, such as quick-connect lines, to route calibration gas to the analyzers are applicable.

3.5 **Particulate Filter.** An in-stack or an out-of-stack glass fiber filter is recommended if exhaust gas particulate loading is significant. An out-of-stack filter should be heated to prevent any condensation.

* Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

3.6 **Recorder.** A strip-chart recorder, analog computer, or digital recorder for recording measurement data. The minimum data recording requirement is one measurement value per minute. Note: This method is often applied in highly explosive areas. Caution and care should be exercised in choice of equipment and installation.

4. Calibration and Other Gases.

Gases used for calibrations, fuel, and combustion air (if required) are contained in compressed gas cylinders. Preparation of calibration gases shall be done according to the procedure in Protocol No. 1, listed in Citation 2 of Bibliography. Additionally, the manufacturer of the cylinder should provide a recommended shelf life for each calibration gas cylinder over which the concentration does not change more than ± 2 percent from the certified value. For calibration gas values not generally available (i.e., organics between 1 and 10 percent by volume), alternative methods for preparing calibration gas mixtures, such as dilution systems, may be used with prior approval of the Administrator.

Calibration gases usually consist of propane in air or nitrogen and are determined in terms of the span value. Organic compounds other than propane can be used following the above guidelines and making the appropriate corrections for response factor.

4.1 **Fuel.** A 40 percent H₂/60 percent N₂ gas mixture is recommended to avoid an oxygen synergism effect that reportedly occurs when oxygen concentration varies significantly from a mean value.

4.2 **Zero Gas.** High purity air with less than 0.1 parts per million by volume (PPMv) of organic material (propane or carbon equivalent) or less than 0.1 percent of the span value, whichever is greater.

4.3 **Low-level Calibration Gas.** An organic calibration gas with a concentration equivalent to 25 to 35 percent of the applicable span value.

4.4 **Mid-level Calibration Gas.** An organic calibration gas with a concentration equivalent to 45 to 55 percent of the applicable span value.

4.5 **High-level Calibration Gas.** An organic calibration gas with a concentration equivalent to 80 to 90 percent of the applicable span value.

5. Measurement System Performance Specifications

5.1 **Zero Drift.** Less than ± 3 percent of the span value.

5.2 **Calibration Drift.** Less than ± 3 percent of span value.

5.3 **Calibration Error.** Less than ± 5 percent of the calibration gas value.

6. Pretest Preparations

6.1 **Selection of Sampling Site.** The location of the sampling site is generally specified by the applicable regulation or purpose of the test; i.e., exhaust stack, inlet line, etc. The sample port shall be located at least 1.5 meters or 2 equivalent diameters upstream of the gas discharge to the atmosphere.

6.2 **Location of Sample Probe.** Install the sample probe so that the probe is centrally located in the stack, pipe, or duct and is sealed tightly at the stack port connection.

6.3 **Measurement System Preparation.** Prior to the emission test, assemble the measurement system following the manufacturer's written instructions in preparing the sample interface and the organic analyzer. Make the system operable.

FIA equipment can be calibrated for almost any range of total organics concentrations. For high concentrations of organics (> 1.0 percent by volume as propane) modifications to most commonly available analyzers are necessary. One accepted method of equipment modification is to decrease the size of the sample to the analyzer through the use of a smaller diameter sample capillary. Direct and continuous measurement of organic concentration is a necessary consideration when determining any modification design.

6.4 Calibration Error Test. Immediately prior to the test series, (within 2 hours of the start of the test) introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level responses. Then introduce low-level and mid-level calibration gases successively to the measurement system. Record the analyzer responses for low-level and mid-level calibration gases and determine the differences between the measurement system responses and the predicted responses. These differences must be less than 5 percent of the respective calibration gas value. If not, the measurement system is not acceptable and must be replaced or repaired prior to testing. No adjustments to the measurement system shall be conducted after the calibration and before the drift check (Section 7.3). If adjustments are necessary before the completion of the test series, perform the drift checks prior to the required adjustments and repeat the calibration following the adjustments. If multiple electronic ranges are to be used, each additional range must be checked with a mid-level calibration gas to verify the multiplication factor.

6.5 Response Time Test. Introduce Zero gas into the measurement system at the calibration valve assembly. When the system output has stabilized, switch quickly to the high-level calibration gas. Record the time from the concentration change to the measurement system response equivalent to 95 percent of the step change. Repeat the test three times and average the results.

7. Emission Measurement Test Procedure

7.1 Organic Measurement. Begin sampling at the start of the test period, recording time and any required process information as appropriate. In particular, note on the recording chart periods of process interruption or cyclic operation.

7.2 Drift Determination. Immediately following the completion of the test period and hourly during the test period, reintroduce the zero and mid-level calibration gases, one at a time, to the measurement system at the calibration valve assembly. (Make no adjustments to the measurement system until after both the zero and calibration drift checks are made.) Record the analyzer response. If the drift values exceed the specified limits, invalidate the test results preceding the check and repeat the test following corrections to the measurement system. Alternatively, recalibrate the test measurement system as in Section 6.4 and report the results using both sets of calibration data (i.e., data determined prior to the test period and data determined following the test period).

8. Organic Concentration calculations

Determine the average organic concentration in terms of PPMv as propane or other calibration gas. The average shall be determined by the integration of the output recording over the period specified in the applicable regulation. If results are required in terms of PPMv as carbon, adjust measured concentrations using Equation 25A-1.

$$C_c = K C_{meas} \quad \text{Eq. 25A-1}$$

Where:

- C_c = Organic concentration as carbon, PPMv.
- C_{meas} = Organic concentration as measured, PPMv.
- K = Carbon equivalent correction factor.
 - $K = 2$ for ethane.
 - $K = 3$ for propane.
 - $K = 4$ for butane.
 - K = Appropriate response factor for other organic calibration gases.

9. Bibliography

1. Measurement of Volatile Organic Compounds-Guideline Series. U.S. Environmental Protection Agency. Research Triangle Park, NC. Publication No. EPA-450/2-78-041. June 1978. p. 46-54.
2. Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors (Protocol No. 1). U.S. Environmental Protection Agency, Environmental Monitoring and Support Laboratory. Research Triangle Park, NC. June 1978.
3. Gasoline Vapor Emission Laboratory Evaluation-Part 2. U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards. Research Triangle Park, NC. EMB Report No. 75-GAS-6. August 1975.

SAMPLING FOR FORMALDEHYDE EMISSIONS FROM STATIONARY SOURCES JUL 16 1990

INTERPOLL LABORATORIES

1.0 SCOPE AND APPLICATION

1.1 This method is applicable to the determination of Destruction and Removal Efficiency (DRE) of formaldehyde, CAS Registry number 50-00-0, and possibly other aldehydes and ketones from stationary sources as specified in the regulations. The methodology has been applied specifically to formaldehyde; however, many laboratories have extended the application to other aldehydes and ketones. Compounds derivatized with 2,4-dinitrophenylhydrazine can be detected as low as 6.4×10^{-8} lbs/cu ft (1.8 ppbv) in stack gas over a 1 h sampling period, sampling approximately 45 cu ft.

2.0 SUMMARY OF METHOD

2.1 Gaseous and particulate pollutants are withdrawn isokinetically from an emission source and are collected in aqueous acidic 2,4-dinitrophenylhydrazine. Formaldehyde present in the emissions reacts with the 2,4-dinitrophenylhydrazine to form the formaldehyde dinitrophenylhydrazone derivative. The dinitrophenylhydrazone derivative is extracted, solvent-exchanged, concentrated, and then analyzed by high performance liquid chromatography.

3.0 INTERFERENCES

3.1 A decomposition product of 2,4-dinitrophenylhydrazine, 2,4-dinitroaniline, can be an analytical interferent if concentrations are high. 2,4-dinitroaniline can coelute with the 2,4-dinitrophenylhydrazone of formaldehyde under high performance liquid chromatography conditions which may be used for the analysis. High concentrations of highly oxygenated compounds, especially acetone, that have the same retention time or nearly the same retention time as the dinitrophenylhydrazone of formaldehyde and that also absorb at 360 nm will interfere with the analysis.

Formaldehyde, acetone, and 2,4-dinitroaniline contamination of the aqueous acidic 2,4-dinitrophenylhydrazine (DNPH) reagent is frequently encountered. The reagent must be prepared within five days of use in the field and must be stored in an uncontaminated environment both before and after sampling in order to minimize blank problems. Some level of acetone contamination is unavoidable, because acetone is ubiquitous in laboratory and field operations. However, the acetone contamination must be minimized.

4.0 APPARATUS AND MATERIALS

4.1 A schematic of the sampling train is shown in Figure 1. This sampling train configuration is adapted from EPA Method 5 procedures. The sampling train consists of the following components: Probe Nozzle, Pitot Tube, Differential Pressure Gauge, Metering System, Barometer, and Gas Density Determination Equipment.

4.1.1 Probe Nozzle: Quartz or glass with sharp, tapered (30° angle) leading edge. The taper shall be on the outside to preserve a constant inner diameter. The nozzle shall be buttonhook or elbow design. A range of nozzle sizes suitable

for isokinetic sampling should be available in increments of 0.16 cm (1/16 in), e.g., 0.32 to 1.27 cm (1/8 to 1/2 in), or larger if higher volume sampling trains are used. Each nozzle shall be calibrated according to the procedures outlined in Section 8.1.

4.1.2 Probe Liner: Borosilicate glass or quartz shall be used for the probe liner. The tester should not allow the temperature in the probe to exceed $120 \pm 14^{\circ}\text{C}$ ($248 \pm 25^{\circ}\text{F}$).

4.1.3 Pitot Tube: The Pitot tube shall be Type S, as described in Section 2.1 of EPA Method 2, or any other appropriate device. The pitot tube shall be attached to the probe to allow constant monitoring of the stack gas velocity. The impact (high pressure) opening plane of the pitot tube shall be even with or above the nozzle entry plane (see EPA Method 2, Figure 2-6b) during sampling. The Type S pitot tube assembly shall have a known coefficient, determined as outlined in Section 4 of EPA Method 2.

4.1.4 Differential Pressure Gauge: The differential pressure gauge shall be an inclined manometer or equivalent device as described in Section 2.2 of EPA Method 2. One manometer shall be used for velocity-head readings and the other for orifice differential pressure readings.

4.1.5 Impingers: The sampling train requires a minimum of four impingers, connected as shown in Figure 1, with ground glass (or equivalent) vacuum-tight fittings. For the first, third, and fourth impingers, use the Greenburg-Smith design, modified by replacing the tip with a 1.3-cm inside diameter (1/2 in) glass tube extending to 1.3 cm (1/2 in) from the bottom of the flask. For the second impinger, use a Greenburg-Smith impinger with the standard tip. Place a thermometer capable of measuring temperature to within 1°C (2°F) at the outlet of the fourth impinger for monitoring purposes.

4.1.6 Metering System: The necessary components are a vacuum gauge, leak-free pump, thermometers capable of measuring temperature within 3°C (5.4°F), dry-gas meter capable of measuring volume to within 1%, and related equipment as shown in Figure 1. At a minimum, the pump should be capable of 4 cfm free flow, and the dry gas meter should have a recording capacity of 0-999.9 cu ft with a resolution of 0.005 cu ft. Other metering systems may be used which are capable of maintaining sampling rates within 10% of isokinetic collection and of determining sample volumes to within 2%. The metering system may be used in conjunction with a pitot tube to enable checks of isokinetic sampling rates.

4.1.7 Barometer: The barometer may be mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in Hg). In many cases, the barometric reading may be obtained from a nearby National Weather Service Station, in which case the station value (which is the absolute barometric pressure) is requested and an adjustment for elevation differences between the weather station and sampling point is applied at a rate of minus 2.5 mm Hg (0.1 in Hg) per 30 m (100 ft) elevation increase (vice versa for elevation decrease).

4.1.8 Gas Density Determination Equipment: Temperature sensor and pressure gauge (as described in Sections 2.3 and 2.4 of EPA Method 2), and gas analyzer, if necessary (as described in EPA Method 3). The temperature sensor ideally should be permanently attached to the pitot tube or sampling probe in a fixed

configuration such that the tip of the sensor extends beyond the leading edge of the probe sheath and does not touch any metal. Alternatively, the sensor may be attached just prior to use in the field. Note, however, that if the temperature sensor is attached in the field, the sensor must be placed in an interference-free arrangement with respect to the Type S pitot tube openings (see EPA Method 2, Figure 2-7). As a second alternative, if a difference of no more than 1% in the average velocity measurement is to be introduced, the temperature gauge need not be attached to the probe or pitot tube.

4.2 Sample Recovery

4.2.1 Probe Liner: Probe nozzle and brushes; Teflon® bristle brushes with stainless steel wire handles are required. The probe brush shall have extensions of stainless steel, Teflon®, or inert material at least as long as the probe. The brushes shall be properly sized and shaped to brush out the probe liner, the probe nozzle, and the impingers.

4.2.2 Wash Bottles: Three wash bottles are required. Teflon® or glass wash bottles are recommended; polyethylene wash bottles should not be used because organic contaminants may be extracted by exposure to organic solvents used for sample recovery.

4.2.3 Graduated Cylinder and/or Balance: A graduated cylinder or balance is required to measure condensed water to the nearest 1 mL or 1 g. Graduated cylinders shall have divisions not >2 mL. Laboratory balances capable of weighing to ± 0.5 g are required.

4.2.4 Amber Glass Storage Containers: One-liter wide-mouth amber flint glass bottles with Teflon®-lined caps are required to store impinger water samples. The bottles must be sealed with Teflon® tape.

4.2.5 Rubber Policeman and Funnel: A rubber policeman and funnel are required to aid in the transfer of materials into and out of containers in the field.

5.0 REAGENTS

Reagent grade chemicals or better grades shall be used in all tests. Unless otherwise indicated, all reagents shall conform to the specifications of the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available.

5.1 Water: HPLC-grade water is used in preparation of DNPH reagent and in all other applications in the sampling train.

5.2 Silica Gel: Silica gel shall be indicating type, 6-16 mesh. If the silica gel has been used previously, dry at 175°C (350°F) for 2 h before using. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used.

5.3 Crushed Ice: Quantities ranging from 10-50 lb may be necessary during a sampling run, depending upon ambient temperature. Samples which have been taken must be stored and shipped cold; sufficient ice for this purpose must be allowed.

5.4 2,4-Dinitrophenylhydrazine Reagent: The 2,4-dinitrophenylhydrazine reagent must be prepared in the laboratory within five days of sampling use in the field. Preparation of DNPH can also be done in the field, with consideration of appropriate procedures required for safe handling of solvent in the field. When a container of prepared DNPH reagent is opened in the field, the contents of the opened container should be used within 48 hours. All laboratory glassware must be washed with detergent and water and rinsed with water, methanol, and methylene chloride prior to use.

NOTE: The glassware must not be rinsed with acetone or unacceptable levels of acetone contamination will be introduced. If field preparation of DNPH is performed, caution must be exercised in avoiding acetone contamination.

Reagent bottles for storage of cleaned DNPH derivatizing solution must be rinsed with acetonitrile and dried before use. Baked glassware is not essential for preparation of DNPH reagent.

NOTE: DNPH crystals or DNPH solution should be handled with plastic gloves at all times, with prompt and extensive use of running water in case of skin exposure.

5.4.1 Preparation of Aqueous Acidic DNPH: The following materials and reagents are required for preparation of the reagent.

5.4.1.1 Bottles/Caps: amber 1- or 4 L bottles with Teflon[®]-lined caps are required for storing cleaned DNPH solution. Additional 4-L bottles are required to collect waste organic solvents.

5.4.1.2 Large Glass Container: at least one large glass container (8 to 16 L) is required for mixing the aqueous acidic DNPH solution.

5.4.1.3 Stir Plate/Large Stir Bars/Stir Bar Retriever: a magnetic stir plate and large stir bar are required for the mixing of the aqueous acidic DNPH solution. A stir bar retriever is needed for removing the stir bar from the large container holding the DNPH solution.

5.4.1.4 Buchner Filter/Filter Flask/Filter Paper: a large filter flask (2-4 L) with a buchner filter, appropriate rubber stopper, filter paper, and connecting tubing are required for filtering the aqueous acidic DNPH solution prior to cleaning.

5.4.1.5 Separatory Funnels: at least one large separatory funnel (2 L) is required for cleaning the DNPH prior to use.

5.4.1.6 Beakers: beakers (150 mL, 250 mL, and 400 mL) are useful for holding/measuring organic liquids when cleaning the aqueous acidic DNPH solution and for weighing DNPH crystals.

5.4.1.7 Funnels: at least one large funnel is needed for pouring the aqueous acidic DNPH into the separatory funnel.

5.4.1.8 Graduated Cylinders: at least one large graduated cylinder (1 to 2 L) is required for measuring HPLC-grade water and acid when preparing the DNPH solution.

5.4.1.9 Top-Loading Balance: a one-place top loading balance is needed for weighing out the DNPH crystals used to prepare the aqueous acidic DNPH solution.

5.4.1.10 Spatulas: spatulas are needed for weighing out DNPH when preparing the aqueous DNPH solution.

5.4.1.11 HPLC-Grade Water: water (HPLC-grade) is required to mix the aqueous DNPH solution.

5.4.1.12 Hydrochloric Acid: reagent grade hydrochloric acid (approximately 12N) is required for acidifying the aqueous DNPH solution.

5.4.1.13 2,4-Dinitrophenylhydrazine: a supply of moist solid 2,4-dinitrophenylhydrazine (DNPH) is required for preparation of aqueous acidic DNPH solution. The quantity of water may vary from 10 to 30%. Reagent grade or equivalent is required.

5.4.1.14 Methylene Chloride: methylene chloride (suitable for residue and pesticide analysis, GC/MS, HPLC, GC, Spectrophotometry or equivalent) is required for cleaning the aqueous acidic DNPH solution, rinsing glassware, and recovery of sample trains.

5.4.1.15 Cyclohexane: cyclohexane (HPLC grade) is required for cleaning the aqueous acidic DNPH solution.

NOTE: Do not use spectroanalyzed grades of cyclohexane if this sampling methodology is extended to aldehydes and ketones with four or more carbon atoms.

5.4.1.16 Methanol: methanol (HPLC grade or equivalent) is required for rinsing glassware.

5.4.1.17 Acetonitrile: acetonitrile (HPLC grade or equivalent) is required for rinsing glassware.

5.4.1.18 Formaldehyde: Analytical grade or equivalent formaldehyde is required for preparation of standards. If other aldehydes or ketones are used, analytical grade or equivalent is required.

5.4.2 Preparation of Aqueous Acidic DNPH Derivatizing Reagent: Each batch of DNPH reagent should be prepared and purified within five days of sampling, according to the procedure described below.

5.4.2.1 Place an 8-L container under a fume hood on a magnetic stirrer. Add a large stir bar and fill the container half full of HPLC-grade water. Save the empty bottle from HPLC-grade water. Start the stirring bar and adjust the stir rate to be as fast as possible. Using a graduated cylinder, measure 1.4 mL of concentrated hydrochloric acid. Slowly pour the acid into the stirring water. Fumes may be generated and the water may become warm. Weigh the DNPH crystals on a one-place balance (see Table 1 for approximate amounts) and add to the stirring acid solution. Fill the 8 L container to the 8 L mark with HPLC water and stir overnight. If all of the DNPH crystals have dissolved overnight, add additional DNPH and stir for two more hours. Continue the process of adding DNPH with additional stirring until a saturated solution has been formed. Filter the DNPH solution using vacuum filtration. Gravity filtration may be used, but a

much longer time is required. Store the filtered solution in an amber bottle at room temperature.

TABLE 1. APPROXIMATE AMOUNT OF CRYSTALLINE DNPB USED TO PREPARE A SATURATED SOLUTION

Amount of Moisture in DNPB	Weight Required per 8 L of Solution
10 weight percent	31 g
15 weight percent	33 g
30 weight percent	40 g

Within five days of proposed use, place about 1.6 L of the DNPB reagent in a 2 L separatory funnel. Add approximately 200 mL of methylene chloride and stopper the funnel. Wrap the stopper of the funnel with paper towels to absorb any leakage. Invert and vent the funnel. Then shake vigorously for 3 minutes. Initially, the funnel should be vented frequently (every 10 - 15 sec). After the layers have separated, discard the lower (organic) layer.

Extract the DNPB a second time with methylene chloride and finally with cyclohexane. When the cyclohexane layer has separated from the DNPB reagent, the cyclohexane layer will be the top layer in the separatory funnel. Drain the lower layer (the cleaned extracted DNPB reagent solution) into an amber bottle that has been rinsed with acetonitrile and allowed to dry.

5.4.3 Quality Control: Take two aliquots of the extracted DNPB reagent. The size of the aliquots is dependent upon the exact sampling procedure used, but 100 mL is reasonably representative. To ensure that the background in the reagent is acceptable for field use, analyze one aliquot of the reagent according to the procedure of EPA Draft Method 8315. Save the other aliquot of aqueous acidic DNPB for use as a method blank when the analysis is performed.

5.4.4 Shipment to the Field: Tightly cap the bottle containing extracted DNPB reagent using a Teflon®-lined cap. Seal the bottle with Teflon® tape. After the bottle is labeled, the bottle may be placed in a friction-top can (paint can or equivalent) containing a 1 -2 inch layer of granulated charcoal and stored at ambient temperature until use.

If the DNPB reagent has passed the Quality Control criteria, the reagent may be packaged to meet necessary shipping requirements and sent to the sampling area. If the Quality Control criteria are not met, the reagent solution may be re-extracted or the solution may be re-prepared and the extraction sequence repeated.

If the DNPB reagent is not used in the field within five days of extraction, an aliquot may be taken and analyzed as described Draft Method 8315. If the reagent meets the Quality Control requirements, the reagent may be used. If the reagent does not meet Quality Control requirements, the reagent must be discarded and new reagent must be prepared and tested.

5.4.5 Calculation of Acceptable Levels of Impurities in DNPH Reagent: The acceptable impurity level (AIL, $\mu\text{g}/\text{mL}$) is calculated from the expected analyte level in the sampled gas (EAL, ppbv), the volume of air that will be sampled at standard conditions (SVOL, L), the formula weight of the analyte (FW, g/mol), and the volume of DNPH reagent that will be used in the impingers (RVOL, mL):

$$\text{AIL} = 0.1 \times [\text{EAL} \times \text{SVOL} \times \text{FW}/22.4 \times (\text{FW} + 180)/\text{FW}]/(\text{RVOL} \times 1000).$$

where 0.1 is the acceptable contaminant level, 22.4 is a factor relating ppbv to g/L, 180 is a factor relating the underivatized analyte to the derivatized analyte, and 1000 is a unit conversion factor.

5.4.6 Disposal of Excess DNPH Reagent: Excess DNPH reagent may be returned to the laboratory and recycled or treated as aqueous waste for disposal purposes. 2,4-Dinitrophenylhydrazine is a flammable solid when dry so water should not be evaporated from the solution of the reagent.

5.5 Field Spike Standard Preparation: To prepare a formaldehyde field spiking standard at 4.01 mg/mL, use a 500 μL syringe to transfer 0.5 mL of 37% by weight of formaldehyde (401 mg/mL) to a 50 mL volumetric flask containing approximately 40 mL of methanol. Dilute to 50 mL with methanol.

6.0 SAMPLE COLLECTION, PRESERVATION, AND HANDLING

6.1 Because of the complexity of this method, field personnel should be trained in and experienced with the test procedures in order to obtain reliable results.

6.2 Laboratory Preparation:

6.2.1 All the components shall be maintained and calibrated according to the procedure described in APTD-0576, unless otherwise specified.

6.2.2 Weigh several 200- to 300-g portions of silica gel in airtight containers to the nearest 0.5 g. Record on each container the total weight of the silica gel plus containers. As an alternative to preweighing the silica gel, it may instead be weighed directly in the impinger or sampling holder just prior to train assembly.

6.3 Preliminary Field Determinations:

6.3.1 Select the sampling site and the minimum number of sampling points according to EPA Method 1 or other relevant criteria. Determine the stack pressure, temperature, and range of velocity heads using EPA Method 2. A leak-check of the pitot lines according to EPA Method 2, Section 3.1, must be performed. Determine the stack gas moisture content using EPA Approximation Method 4 or its alternatives to establish estimates of isokinetic sampling-rate settings. Determine the stack gas dry molecular weight, as described in EPA Method 2, Section 3.6. If integrated EPA Method 3 sampling is used for molecular weight determination, the integrated bag sample shall be taken simultaneously with, and for the same total length of time as, the sample run.

6.3.2 Select a nozzle size based on the range of velocity heads so that it is not necessary to change the nozzle size in order to maintain isokinetic sampling rates below 28 L/min (1.0 cfm). During the run, do not change the nozzle.

Ensure that the proper differential pressure gauge is chosen for the range of velocity heads encountered (see Section 2.2 of EPA Method 2).

6.3.3 Select a suitable probe liner and probe length so that all traverse points can be sampled. For large stacks, to reduce the length of the probe, consider sampling from opposite sides of the stack.

6.3.4 A minimum of 45 ft³ of sample volume is required for the determination of the Destruction and Removal Efficiency (DRE) of formaldehyde from incineration systems (45ft³ is equivalent to one hour of sampling at 0.75 dscf). Additional sample volume shall be collected as necessitated by the capacity of the DNPH reagent and analytical detection limit constraints. To determine the minimum sample volume required, refer to sample calculations in Section 10.

6.3.5 Determine the total length of sampling time needed to obtain the identified minimum volume by comparing the anticipated average sampling rate with the volume requirement. Allocate the same time to all traverse points defined by EPA Method 1. To avoid timekeeping errors, the length of time sampled at each traverse point should be an integer or an integer plus 0.5 min.

6.3.6 In some circumstances (e.g., batch cycles) it may be necessary to sample for shorter times at the traverse points and to obtain smaller gas-volume samples. In these cases, careful documentation must be maintained in order to allow accurate calculation of concentrations.

6.4 Preparation of Collection Train:

6.4.1 During preparation and assembly of the sampling train, keep all openings where contamination can occur covered with Teflon® film or aluminum foil until just prior to assembly or until sampling is about to begin.

6.4.2 Place 100 mL of cleaned DNPH solution in each of the first two impingers, and leave the third impinger empty. If additional capacity is required for high expected concentrations of formaldehyde in the stack gas, 200 mL of DNPH per impinger may be used or additional impingers may be used for sampling. Transfer approximately 200 to 300 g of pre-weighed silica gel from its container to the fourth impinger. Care should be taken to ensure that the silica gel is not entrained and carried out from the impinger during sampling. Place the silica gel container in a clean place for later use in the sample recovery. Alternatively, the weight of the silica gel plus impinger may be determined to the nearest 0.5 g and recorded.

6.4.3 With a glass or quartz liner, install the selected nozzle using a Viton-A O-ring when stack temperatures are <260°C (500°F) and a woven glass-fiber gasket when temperatures are higher. See APTD-0576 (Rom, 1972) for details. Other connecting systems utilizing either 316 stainless steel or Teflon® ferrules may be used. Mark the probe with heat-resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point.

6.4.4 Assemble the train as shown in Figure 1. During assembly, do not use any silicone grease on ground-glass joints upstream of the impingers. Use Teflon® tape, if required. A very light coating of silicone grease may be used on ground-glass joints downstream of the impingers, but the silicone grease should be limited to the outer portion (see APTD-0576) of the ground-glass joints to

necessary, a leak check shall be conducted immediately after the interruption of sampling and before the change is made. The leak check shall be done according to the procedure described in Section 6.5.1, except that it shall be done at a vacuum greater than or equal to the maximum value recorded up to that point in the test. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable. If a higher leakage rate is obtained, the tester must void the sampling run.

NOTE: Any correction of the sample volume by calculation reduces the integrity of the pollutant concentration data generated and must be avoided.

6.5.2.2 Immediately after a component change and before sampling is re-initiated, a leak check similar to a pre-test leak check must also be conducted.

6.5.3 Post-test Leak Check:

6.5.3.1 A leak check is mandatory at the conclusion of each sampling run. The leak check shall be done with the same procedures as the pre-test leak check, except that the post-test leak check shall be conducted at a vacuum greater than or equal to the maximum value reached during the sampling run. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable. If, however, a higher leakage rate is obtained, the tester shall record the leakage rate and void the sampling run.

6.6 Sampling Train Operation:

6.6.1 During the sampling run, maintain an isokinetic sampling rate to within 10% of true isokinetic, below 28 L/min (1.0 cfm). Maintain a temperature around the probe of 120° ± 14°C (248° ± 25°F).

6.6.2 For each run, record the data on a data sheet such as the one shown in Figure 2. Be sure to record the initial dry-gas meter reading. Record the dry-gas meter readings at the beginning and end of each sampling time increment, when changes in flow rates are made, before and after each leak check, and when sampling is halted. Take other readings required by Figure 2 at least once at each sample point during each time increment and additional readings when significant adjustments (20% variation in velocity head readings) necessitate additional adjustments in flow rate. Level and zero the manometer. Because the manometer level and zero may drift due to vibrations and temperature changes, make periodic checks during the traverse.

6.6.3 Clean the stack access ports prior to the test run to eliminate the chance of sampling deposited material. To begin sampling, remove the nozzle cap, verify that the filter and probe heating systems are at the specified temperature, and verify that the pitot tube and probe are properly positioned. Position the nozzle at the first traverse point, with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Nomographs, which aid in the rapid adjustment of the isokinetic sampling rate without excessive computations, are available. These nomographs are designed for use when the Type S pitot tube coefficient is 0.84 ± 0.02 and the stack gas equivalent density (dry molecular weight) is equal to 29 ± 4. APTD-0576 details the procedure for using the nomographs. If the stack gas molecular weight and

minimize silicone grease contamination. If necessary, Teflon® tape may be used to seal leaks. Connect all temperature sensors to an appropriate potentiometer/display unit. Check all temperature sensors at ambient temperature.

6.4.5 Place crushed ice all around the impingers.

6.4.6 Turn on and set the probe heating system at the desired operating temperature. Allow time for the temperature to stabilize.

6.5 Leak-Check Procedures:

6.5.1 Pre-test Leak Check:

6.5.1.1 After the sampling train has been assembled, turn on and set the probe heating system at the desired operating temperature. Allow time for the temperature to stabilize. If a Viton-A O-ring or other leak-free connection is used in assembling the probe nozzle to the probe liner, leak-check the train at the sampling site by plugging the nozzle and pulling a 381-mm Hg (15 in Hg) vacuum.

NOTE: A lower vacuum may be used, provided that the lower vacuum is not exceeded during the test.

6.5.1.2 If an asbestos string is used, do not connect the probe to the train during the leak check. Instead, leak-check the train by first attaching a carbon-filled leak check impinger to the inlet and then plugging the inlet and pulling a 381-mm Hg (15 in Hg) vacuum. (A lower vacuum may be used if this lower vacuum is not exceeded during the test.) Then connect the probe to the train and leak-check at about 25 mm Hg (1 in Hg) vacuum. Alternatively, leak-check the probe with the rest of the sampling train in one step at 381 mm Hg (15 in Hg) vacuum. Leakage rates in excess of 4% of the average sampling rate or $>0.00057 \text{ m}^3/\text{min}$ (0.02 cfm), whichever is less, are acceptable.

6.5.1.3 The following leak check instructions for the sampling train described in APTD-0576 and APTD-0581 may be helpful. Start the pump with the fine-adjust valve fully open and coarse-adjust valve completely closed. Partially open the coarse-adjust valve and slowly close the fine-adjust valve until the desired vacuum is reached. Do not reverse direction of the fine-adjust valve, as liquid will back up into the train. If the desired vacuum is exceeded, either perform the leak check at this higher vacuum or end the leak check, as shown below, and start over.

6.5.1.4 When the leak check is completed, first slowly remove the plug from the inlet to the probe. When the vacuum drops to 127 mm (5 in) Hg or less, immediately close the coarse-adjust valve. Switch off the pumping system and reopen the fine-adjust valve. Do not reopen the fine-adjust valve until the coarse-adjust valve has been closed to prevent the liquid in the impingers from being forced backward into the sampling line and silica gel from being entrained backward into the third impinger.

6.5.2 Leak Checks During Sampling Runs:

6.5.2.1 If, during the sampling run, a component change (i.e., impinger) becomes

the pitot tube coefficient are outside the above ranges, do not use the nomographs unless appropriate steps are taken to compensate for the deviations.

6.6.4 When the stack is under significant negative pressure (equivalent to the height of the impinger stem), take care to close the coarse-adjust valve before inserting the probe into the stack in order to prevent liquid from backing up through the train. If necessary, the pump may be turned on with the coarse-adjust valve closed.

6.6.5 When the probe is in position, block off the openings around the probe and stack access port to prevent unrepresentative dilution of the gas stream.

6.6.6 Traverse the stack cross section, as required by EPA Method 1, being careful not to bump the probe nozzle into the stack walls when sampling near the walls or when removing or inserting the probe through the access port, in order to minimize the chance of extracting deposited material.

6.6.7 During the test run, make periodic adjustments to keep the temperature around the probe at the proper levels. Add more ice and, if necessary, salt, to maintain a temperature of $<20^{\circ}\text{C}$ (68°F) at the silica gel outlet. Also, periodically check the level and zero of the manometer.

6.6.8 A single train shall be used for the entire sampling run, except in cases where simultaneous sampling is required in two or more separate ducts or at two or more different locations within the same duct, or in cases where equipment failure necessitates a change of trains. An additional train or additional trains may also be used for sampling when the capacity of a single train is exceeded.

6.6.9 When two or more trains are used, separate analyses of components from each train shall be performed. If multiple trains have been used because the capacity of a single train would be exceeded, first impingers from each train may be combined, and second impingers from each train may be combined.

6.6.10 At the end of the sampling run, turn off the coarse-adjust valve, remove the probe and nozzle from the stack, turn off the pump, record the final dry gas meter reading, and conduct a post-test leak check. Also, leak check the pitot lines as described in EPA Method 2. The lines must pass this leak check in order to validate the velocity-head data.

6.6.11 Calculate percent isokineticity (see Method 2) to determine whether the run was valid or another test should be made.

7.0 SAMPLE RECOVERY

7.1 Preparation:

7.1.1 Proper cleanup procedure begins as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool. When the probe can be handled safely, wipe off all external particulate matter near the tip of the probe nozzle and place a cap over the tip to prevent losing or gaining particulate matter. Do not cap the probe tip tightly while the sampling train is cooling because a vacuum will be created, drawing liquid from the impingers back through the sampling train.

7.1.2 Before moving the sampling train to the cleanup site, remove the probe from the sampling train and cap the open outlet, being careful not to lose any condensate that might be present. Remove the umbilical cord from the last impinger and cap the impinger. If a flexible line is used, let any condensed water or liquid drain into the impingers. Cap off any open impinger inlets and outlets. Ground glass stoppers, Teflon® caps, or caps of other inert materials may be used to seal all openings.

7.1.3 Transfer the probe and impinger assembly to an area that is clean and protected from wind so that the chances of contaminating or losing the sample are minimized.

7.1.4 Inspect the train before and during disassembly, and note any abnormal conditions.

7.1.5 Save a portion of all washing solutions (methylene chloride, water) used for cleanup as a blank. Transfer 200 mL of each solution directly from the wash bottle being used and place each in a separate, pre-labeled sample container.

7.2 Sample Containers:

7.2.1 Container 1: Probe and Impinger Catches. Using a graduated cylinder, measure to the nearest mL, and record the volume of the solution in the first three impingers. Alternatively, the solution may be weighed to the nearest 0.5 g. Include any condensate in the probe in this determination. Transfer the impinger solution from the graduated cylinder into the amber flint glass bottle. Taking care that dust on the outside of the probe or other exterior surfaces does not get into the sample, clean all surfaces to which the sample is exposed (including the probe nozzle, probe fitting, probe liner, first impinger, and impinger connector) with methylene chloride. Use less than 500 mL for the entire wash (250 mL would be better, if possible). Add the washings to the sample container.

7.2.1.1 Carefully remove the probe nozzle and rinse the inside surface with methylene chloride from a wash bottle. Brush with a Teflon® bristle brush, and rinse until the rinse shows no visible particles or yellow color, after which make a final rinse of the inside surface. Brush and rinse the inside parts of the Swagelok® fitting with methylene chloride in a similar way.

7.2.1.2 Rinse the probe liner with methylene chloride. While squirting the methylene chloride into the upper end of the probe, tilt and rotate the probe so that all inside surfaces will be wetted with methylene chloride. Let the methylene chloride drain from the lower end into the sample container. The tester may use a funnel (glass or polyethylene) to aid in transferring the liquid washes to the container. Follow the rinse with a Teflon® brush. Hold the probe in an inclined position, and squirt methylene chloride into the upper end as the probe brush is being pushed with a twisting action through the probe. Hold the sample container underneath the lower end of the probe, and catch any methylene chloride, water, and particulate matter that is brushed from the probe. Run the brush through the probe three times or more. With stainless steel or other metal probes, run the brush through in the above prescribed manner at least six times since there may be small crevices in which particulate matter can be entrapped. Rinse the brush with methylene chloride or water, and quantitatively collect these washings in the sample container. After the brushings, make a final rinse

of the probe as described above.

NOTE: Two people should clean the probe in order to minimize sample losses. Between sampling runs, brushes must be kept clean and free from contamination.

7.2.1.3 Rinse the inside surface of each of the first three impingers (and connecting tubing) three separate times. Use a small portion of methylene chloride for each rinse, and brush each surface to which sample is exposed with a Teflon® bristle brush to ensure recovery of fine particulate matter. Water will be required for the recovery of the impingers in addition to the specified quantity of methylene chloride. There will be at least two phases in the impingers. This two-phase mixture does not pour well, and a significant amount of the impinger catch will be left on the walls. The use of water as a rinse makes the recovery quantitative. Make a final rinse of each surface and of the brush, using both methylene chloride and water.

7.2.1.4 After all methylene chloride and water washings and particulate matter have been collected in the sample container, tighten the lid so that solvent, water, and DNPH reagent will not leak out when the container is shipped to the laboratory. Mark the height of the fluid level to determine whether leakage occurs during transport. Seal the container with Teflon® tape. Label the container clearly to identify its contents.

7.2.1.5 If the first two impingers are to be analyzed separately to check for breakthrough, separate the contents and rinses of the two impingers into individual containers. Care must be taken to avoid physical carryover from the first impinger to the second. The formaldehyde hydrazone is a solid which floats and froths on top of the impinger solution. Any physical carryover of collected moisture into the second impinger will invalidate a breakthrough assessment.

7.2.2 Container 2: Sample Blank. Prepare a blank by using an amber flint glass container and adding a volume of DNPH reagent and methylene chloride equal to the total volume in Container 1. Process the blank in the same manner as Container 1.

7.2.3 Container 3: Silica Gel. Note the color of the indicating silica gel to determine whether it has been completely spent and make a notation of its condition. The impinger containing the silica gel may be used as a sample transport container with both ends sealed with tightly fitting caps or plugs. Ground-glass stoppers or Teflon® caps may be used. The silica gel impinger should then be labeled, covered with aluminum foil, and packaged on ice for transport to the laboratory. If the silica gel is removed from the impinger, the tester may use a funnel to pour the silica gel and a rubber policeman to remove the silica gel from the impinger. It is not necessary to remove the small amount of dust particles that may adhere to the impinger wall and are difficult to remove. Since the gain in weight is to be used for moisture calculations, do not use water or other liquids to transfer the silica gel. If a balance is available in the field, the spent silica gel (or silica gel plus impinger) may be weighed to the nearest 0.5 g.

7.2.4 Sample containers should be placed in a cooler, cooled by although not in contact with ice. Sample containers must be placed vertically and, since they are glass, protected from breakage during shipment. Samples should be cooled during shipment so they will be received cold at the laboratory.

8.0 CALIBRATION

8.1 Probe Nozzle: Probe nozzles shall be calibrated before their initial use in the field. Using a micrometer, measure the inside diameter of the nozzle to the nearest 0.025 mm (0.001 in). Make measurements at three separate places across the diameter and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.004 in). When the nozzles become nicked or corroded, they shall be replaced and calibrated before use. Each nozzle must be permanently and uniquely identified.

8.2 Pitot tube: The Type S pitot tube assembly shall be calibrated according to the procedure outlined in Section 4 of EPA Method 2, or assigned a nominal coefficient of 0.84 if it is not visibly nicked or corroded and if it meets design and intercomponent spacing specifications.

8.3 Metering system:

8.3.1 Before its initial use in the field, the metering system shall be calibrated according to the procedure outlined in APTD-0576. Instead of physically adjusting the dry-gas meter dial readings to correspond to the wet-test meter readings, calibration factors may be used to correct the gas meter dial readings mathematically to the proper values. Before calibrating the metering system, it is suggested that a leak check be conducted. For metering systems having diaphragm pumps, the normal leak check procedure will not detect leakages within the pump. For these cases, the following leak check procedure will apply: make a ten-minute calibration run at 0.00057 m³/min (0.02 cfm). At the end of the run, take the difference of the measured wet-test and dry-gas meter volumes and divide the difference by 10 to get the leak rate. The leak rate should not exceed 0.00057 m³/min (0.02 cfm).

8.3.2 After each field use, check the calibration of the metering system by performing three calibration runs at a single intermediate orifice setting (based on the previous field test). Set the vacuum at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet-test meter and the inlet of the metering system. Calculate the average value of the calibration factor. If the calibration has changed by more than 5%, recalibrate the meter over the full range of orifice settings, as outlined in APTD-0576.

8.3.3 Leak check of metering system: The portion of the sampling train from the pump to the orifice meter (see Figure 1) should be leak-checked prior to initial use and after each shipment. Leakage after the pump will result in less volume being recorded than is actually sampled. Use the following procedure: Close the main valve on the meter box. Insert a one-hole rubber stopper with rubber tubing attached into the orifice exhaust pipe. Disconnect and vent the low side of the orifice manometer. Close off the low side orifice tap. Pressurize the system to 13 - 18 cm (5 - 7 in) water column by blowing into the rubber tubing. Pinch off the tubing and observe the manometer for 1 min. A loss of pressure on the manometer indicates a leak in the meter box. Leaks must be corrected.

NOTE: If the dry-gas-meter coefficient values obtained before and after a test series differ by >5%, either the test series must be voided or calculations for test series must be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

8.4 Probe heater: The probe heating system must be calibrated before its initial use in the field according to the procedure outlined in APTD-0576. Probes constructed according to APTD-0581 need not be calibrated if the calibration curves in APTD-0576 are used.

8.5 Temperature gauges: Each thermocouple must be permanently and uniquely marked on the casting. All mercury-in-glass reference thermometers must conform to ASTM E-1 63C or 63F specifications. Thermocouples should be calibrated in the laboratory with and without the use of extension leads. If extension leads are used in the field, the thermocouple readings at ambient air temperatures, with and without the extension lead, must be noted and recorded. Correction is necessary if the use of an extension lead produces a change $>1.5\%$.

8.5.1 Impinger and dry-gas meter thermocouples: For the thermocouples used to measure the temperature of the gas leaving the impinger train, three-point calibration at ice water, room air, and boiling water temperatures is necessary. Accept the thermocouples only if the readings at all three temperatures agree to $\pm 2^{\circ}\text{C}$ (3.6°F) with those of the absolute value of the reference thermometer.

8.5.2 Probe and stack thermocouple: For the thermocouples used to indicate the probe and stack temperatures, a three-point calibration at ice water, boiling water, and hot oil bath temperatures must be performed. Use of a point at room air temperature is recommended. The thermometer and thermocouple must agree to within 1.5% at each of the calibration points. A calibration curve (equation) may be constructed (calculated) and the data extrapolated to cover the entire temperature range suggested by the manufacturer.

8.6 Barometer: Adjust the barometer initially and before each test series to agree to within ± 2.5 mm Hg (0.1 in Hg) of the mercury barometer or the corrected barometric pressure value reported by a nearby National Weather Service Station (same altitude above sea level).

8.7 Triple-beam balance: Calibrate the triple-beam balance before each test series, using Class S standard weights. The weights must be within $\pm 0.5\%$ of the standards, or the balance must be adjusted to meet these limits.

9.0 CALCULATIONS

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

9.1 Calculation of Total Formaldehyde:

To determine the total formaldehyde in mg, use the following equation:

$$\text{Total mg formaldehyde} = C_d \times V \times DF \times$$

$$\left(\frac{[\text{g/mole aldehyde}]}{[\text{g/mole DNPH derivative}]} \right) \times$$

$$10^{-3} \text{ mg}/\mu\text{g}$$

where:

- C_d - measured concentration of DNPH-formaldehyde derivative, $\mu\text{g}/\text{mL}$.
- V - organic extract volume, mL
- DF - dilution factor

9.2 Formaldehyde concentration in stack gas:

Determine the formaldehyde concentration in the stack gas using the following equation:

$$C_2 = K \left[\frac{\text{total formaldehyde, mg}}{V_{n(\text{std})}} \right]$$

where:

- K - 35.31 ft^3/m^3 if $V_{n(\text{std})}$ is expressed in English units
- 1.00 m^3/m^3 if $V_{n(\text{std})}$ is expressed in metric units

$V_{n(\text{std})}$ - volume of gas sample as measured by dry gas meter, corrected to standard conditions, dscm (dscf)

9.3 Average Dry Gas Meter Temperature and Average Orifice Pressure Drop are obtained from the data sheet.

9.4 Dry Gas Volume: Calculate $V_{n(\text{std})}$ and adjust for leakage, if necessary, using the equation in Section 6.3 of EPA Method 5.

9.5 Volume of Water Vapor and Moisture Content: Calculate the volume of water vapor and moisture content from equations 5-2 and 5-3 of EPA Method 5.

10.0 DETERMINATION OF VOLUME TO BE SAMPLED

To determine the minimum sample volume to be collected, use the following sequence of equations.

10.1 From prior analysis of the waste feed, the concentration of formaldehyde (FORM) introduced into the combustion system can be calculated. The degree of destruction and removal efficiency that is required is used to determine the maximum amount of FORM allowed to be present in the effluent. This amount may be expressed as:

Max FORM₁ Mass -

$$[(WF) (FORM_1 \text{ conc}) (100 - ZDRE)] / 100$$

where:

WF - mass flow rate of waste feed per h, g/h (lb/h)

FORM₁ - concentration of FORM (wt %) introduced into the combustion process

DRE - percent Destruction and Removal Efficiency required

Max FORM - mass flow rate (g/h [lb/h]) of FORM emitted from the combustion source

10.2 The average discharge concentration of the FORM in the effluent gas is determined by comparing the Max FORM with the volumetric flow rate being exhausted from the source. Volumetric flow rate data are available as a result of preliminary EPA Method 1 - 4 determinations:

$$\text{Max FORM}_1 \text{ conc} = [\text{Max FORM}_1 \text{ Mass}] / DV_{\text{exh}}(\text{std})$$

where:

DV_{exh}(std) - volumetric flow rate of exhaust gas, dscm (dscf)

FORM₁ conc - anticipated concentration of the FORM in the exhaust gas stream, g/dscm (lb/dscf)

10.3 In making this calculation, it is recommended that a safety margin of at least ten be included.

$$[\text{LDL}_{\text{FORM}} \times 10] / [\text{FORM}_1 \text{ conc}] = V_{\text{Lbc}}$$

where:

LDL_{FORM} - detectable amount of FORM in entire sampling train

V_{Lbc} - minimum dry standard volume to be collected at dry-gas meter

10.4 The following analytical detection limits and DNPB Reagent Capacity (based on a total volume of 200 mL in two impingers) must also be considered in determining a volume to be sampled.

Table 2. Instrument Detection Limits and Reagent Capacity for Formaldehyde Analysis¹

Analyte	Detection Limit, ppbv ²	Reagent Capacity, ppbv
formaldehyde	1.8	66
acetaldehyde	1.7	70
acrolein	1.5	75
acetone/propionaldehyde	1.5	75
butyraldehyde	1.5	79
methyl ethyl ketone	1.5	79
valeraldehyde	1.5	84
isovaleraldehyde	1.4	84
hexaldehyde	1.3	88
benzaldehyde	1.4	84
o-/m-/p-tolualdehyde	1.3	89
dimethylbenzaldehyde	1.2	93

¹ Oxygenated compounds in addition to formaldehyde are included for comparison with formaldehyde; extension of the methodology to other compounds is possible.

² Detection limits are determined in solvent. These values therefore represent the optimum capability of the methodology.

11.0 QUALITY CONTROL

11.1 Sampling: See EPA Manual 600/4-77-027b for Method 5 quality control.

11.2 Analysis: The quality assurance program required for this method includes the analysis of field and method blanks, procedure validations, and analysis of field spikes. The assessment of combustion data and positive identification and quantitation of formaldehyde are dependent on the integrity of the samples received and the precision and accuracy of the analytical methodology. Quality Assurance procedures for this method are designed to monitor the performance of the analytical methodology and to provide the required information to take corrective action if problems are observed in laboratory operations or in field sampling activities.

11.2.1 Field Blanks: Field blanks must be submitted with the samples collected at each sampling site. The field blanks include the sample bottles containing aliquots of sample recovery solvents, methylene chloride and water, and unused DNPH reagent. At a minimum, one complete sampling train will be assembled in the field staging area, taken to the sampling area, and leak-checked at the beginning and end of the testing (or for the same total number of times as the actual sampling train). The probe of the blank train must be heated during the sample test. The train will be recovered as if it were an actual test sample. No gaseous sample will be passed through the Blank sampling train.

11.2.2 Method Blanks: A method blank must be prepared for each set of analytical operations, to evaluate contamination and artifacts that can be derived from glassware, reagents, and sample handling in the laboratory.

11.2.3 Field Spike: A field spike is performed by introducing 200 μ L of the Field Spike Standard into an impinger containing 200 mL of DNPH solution. Standard impinger recovery procedures are followed and the field spike sample is returned to the laboratory for analysis. The field spike is used as a check on field handling and recovery procedures. An aliquot of the field spike standard is retained in the laboratory for derivatization and comparative analysis.

12.0 METHOD PERFORMANCE

12.1 Method performance evaluation: The following expected method performance parameters for precision, accuracy, and detection limits are provided in Table 3.


Table 3. Expected Method Performance for Formaldehyde

Parameter	Precision	¹ Accuracy ²	Detection Limit ³
Matrix: Dual trains	$\pm 15\%$ RPD	$\pm 20\%$	1.5×10^{-7} lb/ft ³ (1.8 ppbv)

¹ Relative percent difference limit for dual trains.


² Limit for field spike recoveries.

³ The lower reporting limit having less than 1% probability of false positive detection.



Formaldehyde Sampling Train

Plant _____
 Location _____
 Operator _____
 Date _____
 Run No. _____
 Sample Box No. _____
 Meter Box No. _____
 Meter H@ _____
 C Factor _____
 Pilot Tube Coefficient C_p _____



Schematic of Stack Cross Section

Ambient Temperature _____
 Barometric Pressure _____
 Assumed Moisture % _____
 Probe Length, m(ft) _____
 Nozzle Identification No. _____
 Average Calibrated Nozzle Diameter, cm (in) _____
 Probe Heating Setting _____
 Leak Rate, m³/min. (cfm) _____
 Probe Liner Material _____
 Static Pressure, mm Hg (in. Hg) _____
 Filter No. _____

Transverse Point Number	Sampling Time (t) Min.	Vacuum mm Hg (in. Hg)	Stack Temperature (T _s) °C(°F)	Velocity Head (P _v) mm (in) H ₂ O	Pressure Differential Across Orifice Meter mm (in H ₂ O)	Gas Sample Volume m ³ (ft ³)	Gas Sample Temp. at Dry Gas Meter		Filter Holder Temperature °C(°F)	Temperature of Gas Leaving Last Impinger °C(°F)
							Inlet °C(°F)	Outlet °C(°F)		
Total										
Average										

2594C 2096

Figure 2. Field Data Sheet

PHENOL

Phenol samples were collected using a Method 5 sampling train at 0.75 CFM using neutral-buffered absorbing reagent. The first impinger in each sampling was spiked with isotopically-labeled phenol (phenol-d₅) and 2-fluorophenol for sampling and recovery efficiency surrogates. The recovered samples were extracted and the extracts analyzed by GC/MS for phenol, phenol-d₅ and 2-fluorophenol as per EPA Method 8270. The recoveries of phenol-d₅ and 2-fluorophenol were used to adjust the measured phenol concentrations.

DRAFT

DCN No.: 93-275-065-55-07
Radian No.: 275-065-55
EPA NO.: 68-D1-0010

This document is a preliminary draft. It has not been formally released by EPA and should not at this stage be construed to represent Agency policy. It is being circulated for comment on its technical accuracy and for any implications.

FIELD TEST OF A GENERIC METHOD FOR SAMPLING AND ANALYSIS OF ISOCYANATES

Interim Report
(Work Assignment 55)

Prepared for:

Frank Wilshire
Atmospheric Research and Exposure Assessment Laboratory
Methods Research and Development Division
Source Methods Research Branch
U.S. Environmental Protection Agency
Research Triangle Park, NC 27711

Prepared by:

J. F. McGaughey
S. C. Foster
R. G. Merrill

RADIAN
CORPORATION

P.O. Box 13000
Research Triangle Park, NC 27709

July 1993

DRAFT

This document is a preliminary draft
It has not been formally released by EPA
and should not at this stage be construed
to represent Agency policy. It is being
circulated for comment on its technical
accuracy and policy implications.

DISCLAIMER

The information in this document has been funded wholly by the United States Environmental Protection Agency under EPA Contract Number 68-D1-0010 to Radian. It has been subjected to the Agency's peer and administrative review, and it has been approved for publication as an EPA document. Mention of trade names or commercial products does not constitute endorsement or recommendation for use.

ACKNOWLEDGEMENT

We wish to acknowledge the contributions of the following individuals to the success of this program: Mark Owens, Danny Harrison, Darrell Doerlé and Jim Southerland

EXECUTIVE SUMMARY

Isocyanates are used extensively in the production of polyurethane materials such as flexible foam, enamel wire coatings, paint formulations and in binders for the pressed board industry. Because of their widespread use and known adverse physiological effects, several isocyanates have been listed in Title III of the Clean Air Act Amendments of 1990. The isocyanates of interest are: 2,4-toluene diisocyanate (TDI), methylene diphenyl diisocyanate (MDI), 1,6-hexamethylene diisocyanate (HDI) and methyl isocyanate (MI). Previously, no validated sampling and analytical methodology for these compounds relative to stationary sources existed.

The field validation study presented in this report is a culmination of laboratory investigations, performed under previous work assignments, which were designed to develop and evaluate a viable approach for the determination of isocyanate emissions from stationary sources. After the successful completion of the laboratory studies, the sampling and analysis approach was formulated and a field validation test was initiated. At the direction of the EPA, TDI was selected as the primary analyte.

The test site selected was a flexible foam manufacturing facility in High Point, North Carolina, which used TDI in the manufacturing process. The approximate level of TDI in the emission stream was determined by the analysis of samples collected during a presurvey. A sampling scheme was then designed to ensure the collection of sufficient samples to yield statistically valid data. Following the EPA Method 301 protocol, quadruplicate trains (QUAD) were operated simultaneously with four co-located probes. Two of the trains were spiked with TDI and two were unspiked. Samples from eight QUAD runs (minimum of six valid runs required by Method 301) were returned to the laboratory and analyzed according to the analytical procedure developed in laboratory studies. These data were statistically evaluated following Method 301 protocol to determine the performance of the method relative to bias and precision. These results are summarized in the following table. The precision for both the spiked and unspiked trains was less than 5% RSD, which is well within the precision criteria (% RSD <50)

Method Validation Statistical Summary

Precision ^a	
% RSD for Spiked Samples	3.55 ^b
% RSD for Unspiked Samples	4.72 ^b
Accuracy ^a	
Bias:	-295 μ g
Significant?	No
Correction Factor	1.0 ^c
Recovery ^a	
Amount Spiked (as TDI)	7828 μ g
Average Percent Recovered	95

^aResults are based on the average of seven QUAD runs (14 spiked trains and 14 unspiked trains). TDI was present in the stack emissions and was therefore collected as background in the unspiked trains as well as in the spiked trains.

^bEPA Method 301 requires the precision to be <50% RSD for the method to be acceptable.

^cEPA Method 301 requires the calculated Correction Factor to be between 0.7 and 1.3 for the method to be acceptable.

for an acceptable method as tested. Using the data from all eight runs, the bias was found to be significant at the 95% level of confidence thus requiring the use of a correction factor of 1.053. Using the data from only seven runs (eliminating run number eight due to a questionable leak check for one of the trains) the bias was not significant and therefore did not require the calculation of a correction factor. In either case, the method was well within the bias acceptance criteria (correction factor between 0.7 and 1.3) for an acceptable method as tested.

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1-1
2.0 CONCLUSIONS AND RECOMMENDATIONS	2-1
3.0 FIELD TEST	3-1
3.1 Site Description	3-1
3.2 Sampling Location	3-1
3.3 Test Schedule	3-3
3.4 Sample Collection	3-3
3.4.1 Quad Probe	3-3
3.4.2 Quad-Train Assembly	3-6
3.5 Sampling Preparation	3-6
3.5.1 Glassware Preparation	3-6
3.5.2 Preparation of Impinger Absorbing Solution	3-8
3.5.3 Preparation of TDI Spiking Solution	3-8
3.5.4 Sampling Equipment Preparation	3-9
3.5.5 Sampling Operations	3-10
3.5.6 Sample Recovery	3-13
3.6 Quality Control	3-16
4.0 ANALYTICAL PROCEDURES	4-1
4.1 Sample Preparation	4-1
4.2 Chromatographic Analyses	4-1
4.2.1 Standard Preparation	4-1
4.2.2 Analysis	4-2
4.3 Qualitative Identification	4-3
4.4 Calculations	4-3
4.4.1 Calculation of the Amount of Isocyanate Collected	4-3
4.4.2 Normalization of the Amount of Isocyanate Collected	4-6
4.5 Quality Control	4-12

TABLE OF CONTENTS, continued

	Page
5.0 RESULTS AND DISCUSSION	5-1
5.1 Bias and Precision	5-1
5.2 Breakthrough and Recovery	5-3
5.2.1 Breakthrough	5-3
5.2.2 Recovery	5-6
5.3 Quality Assurance/Quality Control	5-6
5.3.1 Overview of Data Quality	5-8
5.3.2 Sampling Quality Control	5-10
5.3.3 Sample Storage and Holding Time	5-10
5.3.4 Analytical Quality Control	5-10

LIST OF TABLES

	Page
1-1 Isocyanates Listed in the Clean Air Act Amendments of 1990	1-2
3-1 Test Schedule	3-4
3-2 Sampling Train Test Matrix	3-7
3-3 Quad Train Sample Volumes	3-14
4-1 2,4-TDI Detected in Unspiked Trains, μg	4-7
4-2 2,4-TDI Detected in Spiked Trains, μg	4-9
4-3 Normalized Amount of 2,4-TDI Detected in Unspiked Trains, μg	4-13
4-4 Normalized Amount of 2,4-TDI Detected in Spiked Trains, μg	4-14
5-1 Summary of Method 301 Statistical Calculations	5-2
5-2 Distribution of 2,4-TDI Within the Spiked Trains	5-4
5-3 Distribution of 2,4-TDI Within the Unspiked Trains	5-5
5-4 Percent Recovery of the Spiked 2,4-TDI	5-7
5-5 Data Quality Acceptance Criteria and Results	5-9
5-6 Sampling Train Leak Check Summary	5-11
5-7 Summary of Analytical Quality Control Results	5-12

LIST OF FIGURES

	Page
3-1 Sample Location	3-2
3-2 Schematic of Quad Train Setup	3-5
3-3 Sampling Train for Isocyanate	3-12
4-1 Chromatogram of Unspiked Train	4-4
4-2 Chromatogram of Spiked Train	4-5

INTRODUCTION

Sampling and analytical methods for a particular analyte or group of analytes can be evaluated and validated by demonstrating their performance in field tests, thereby establishing the precision and bias of the methods experimentally. Few methods have been fully validated for sampling and analyzing the organic compounds listed in Title III of the Clean Air Act Amendments of 1990. For some analytes, methods have been validated for sample analysis, but not for sample collection. Full validation for both sampling and analytical methods, for both field and laboratory operations, is available for fewer than 10 percent of the analytes listed in Title III of the Clean Air Act Amendments at any source category. Field validation may be performed by side-by-side comparison of a candidate method to a validated method to establish comparable performance for the same analytes in the same matrix (same source category). Another procedure for validation of a method is to spike known quantities of analytes into the collection apparatus in the field so that the precision and bias of the method can be demonstrated from sample collection through analysis.

EPA, under the authority of Title III of the Clean Air Act Amendments (CAAA) of 1990, requires the identification and validation of sampling and analytical methods for the isocyanate compounds which are listed among the 189 hazardous air pollutants identified in Title III. These isocyanate compounds are listed in Table 1-1. Development of sampling and analytical methods for these four compounds was accomplished under Work Assignments 11, 21, and 40 on EPA Contract No. 68-D1-0010. At the direction of EPA, initial efforts were directed to the measurement of 2,4-toluene diisocyanate (TDI) emissions.

The objective of this work assignment was to validate the isocyanate sampling and analytical test method through field testing at an operating stationary source. The method was validated by collecting flue gas samples for the analysis of 2,4-TDI, and evaluating the data for bias and precision. EPA Method 301, "Field Validation of Pollutant Measurement Methods from Various Waste Media," was used as

Table 1-1

Isocyanates Listed in the Clean Air Act Amendments of 1990

Hexamethylene-1,6-diisocyanate (HDI)
2,4-Toluene diisocyanate (TDI)*
Methylene diphenyl diisocyanate (MDI)
Methyl isocyanate (MI)

*The 2,6 TDI isomer may also be present but is not listed in the CAAA.

a model for the validation protocol. Analyte spiking was used with quadruplicate sampling trains to generate the required data. The field validation was performed at an industrial facility which manufactures flexible foam products. Only two of the quadruplicate trains were spiked for each run. The two unspiked trains were used to establish the background level of target compound in the stack gas.

The sampling method utilizes a Method 5-type sampling train, which operates with a solution of 1-(2-pyridyl) piperazine and toluene in the impingers. Stack gas is extracted from the source through a heated probe and drawn through the impingers. TDI present in the stack gas reacts with the piperazine to form an isocyanate derivative. The quantity of isocyanate is determined by solvent exchange of the toluene solution with acetonitrile followed by high pressure liquid chromatographic (HPLC) analysis.

This report discusses the details of the field validation study. Section 2.0, Conclusions and Recommendations, summarizes the results and provides recommendations for future work. Sections 3.0 and 4.0 provide details of the sampling and analysis procedures respectively. Section 5.0 is a detailed discussion of the procedures, calculations and quality control.

CONCLUSIONS AND RECOMMENDATIONS

Based on the results presented in Section 6.0 of this report, the following conclusions can be made concerning the validity of the method as tested under the conditions described in this report:

- The calculated values for precision (%RSD) for both the spiked and unspiked trains, 3.55 and 4.72 respectively, are both well within the acceptance criteria of less than 50% RSD found in Section 6.3 of the EPA Method 301. Therefore, the method as tested at the source category described meets the precision requirements;
- The method bias, at the concentration levels tested, was found to be significantly different from zero at the 95% level of confidence when the data from all eight runs (minimum of six runs required) were used in the calculations. A correction factor of 1.053 would be required if all eight runs are included in the bias calculation. Good technical reasons exist for excluding one of eight QUAD runs. If this run is eliminated, no bias correction is required. In either case the correction factor is well within the acceptance criteria of 0.7 to 1.3 found in Section 1.2 of the EPA Method 301. Therefore, the method as tested at the source category described meets the bias and correction factor requirements; and
- The method as tested is sufficiently robust to allow testing at sources similar to the source tested in this study where the stack gas moisture is less than 1% by volume, the stack temperature is less than 30 degrees C and the presence of other compounds that may interfere with the analysis are minimal.

Recommendations for future testing and validation of the method for the sampling and analysis of isocyanates include the following:

- Identify a source for testing that has more than one isocyanate present in the stack gas;
- Spike as many of the four CAAA target isocyanates as possible into the train before sampling in order to gain as much information as possible from the field test; and

- Design the condenser between the first and second impinger of the train to more efficiently reduce the loss of toluene from the first impinger and minimize compound breakthrough due entrained aerosols.

3.0 FIELD TEST

The objective of this program was to perform a field test to establish the bias and precision of a sampling and analytical method for isocyanate compounds listed in Title III of the Clean Air Act Amendments of 1990. The method evaluation in this test series resulted from extensive literature reviews, industry consultation and laboratory development. To achieve the test objective, an industrial source with known emissions of TDI was selected as a field test site. Factors in the site selection were easy access, ample space for the quadruple sampling trains and proximity to Radian's office and laboratory in Research Triangle Park, North Carolina.

3.1 Site Description

The field validation test was performed at a flexible foam production plant located in High Point, North Carolina. In the manufacturing process starting materials (TDI, water, a polyether resin, methylene chloride, an amine catalyst, and coloring additives) are blended and continuously fed onto a conveyer belt. The TDI reacts with water and releases CO₂, which causes foaming in the resin material. Dichloromethane (DCM) can be added as a supplemental "blowing" or foaming agent. The heat from the reaction of TDI and water causes the DCM to vaporize, resulting in increased foaming. The density of the foam is controlled by the amount of TDI, water and DCM added. The foaming action continues as the material proceeds down the conveyer belt. Finished product is then allowed to cure and degas for 24 to 48 hours.

3.2 Sampling Location

Figure 3-1 presents a schematic view of the sampling location. Three induced draft (ID) fans are used to exhaust TDI and DCM vapors from the production process through three separate uninsulated sheet metal ducts that extend through the roof. Two of the ducts are connected by a 30-foot horizontal duct, 34 inches in diameter, which then extends vertically to a height of 25 feet above the roof top. A 6 inch




Figure 3-1. Sample Location

diameter sampling port is located in the horizontal duct midway between vertical ducts number 2 and 3, approximately 5 feet above the roof level. The roof level is approximately 15 feet above the ground.

A recovery trailer was located on the ground immediately in front of the sampling area, allowing easy communication between the sampling crew and recovery area. Two-way radio communication between the facility production personnel and the sampling crew allowed coordination between production startup and the start of each sampling run.

3.3 Test Schedule

The recovery trailer and test equipment were mobilized on Saturday, February 20, 1993. Equipment setup took place Saturday afternoon and Sunday, and testing began Monday morning.

The sampling schedule is shown in Table 3-1. Eight runs were completed, which included two extra runs above the required minimum of six.

3.4 Sample Collection

3.4.1 Quad Probe

Sampling was performed by withdrawing stack gas from a single port in the stack through a quad probe, then directing the sampled gas simultaneously to four independently operated sampling trains. The quad probe contains four similar heated sampling probes that were inserted into the stack as one unit, as shown in Figure 3-2. The front end of the quad probe was positioned in the center of the stack and remained

Table 3-1
Test Schedule

Run	Date	Start Time	Stop Time
1	2-22-93	1215	1300
2	2-22-93	1330	1410
3	2-23-93	0945	1085
4	2-23-93	1335	1415
5	2-24-93	1010	1110
6	2-24-93	1335	1420
7	2-25-93	1215	1255
8	2-25-93	1315	1355




Figure 3-2. Schematic of Quad Train Setup

in that location during each test. The stack was not traversed nor were stack gas velocity measurements made, because determination of the true concentration and emission rate of the target compound in the stack gas was not required to meet the objectives of this program.

Method 301 of 40 CFR Part 63 describes field validation procedures and details the criteria for the quadruple sampling probe tip arrangement. This method requires the inside edge of sampling probe tips to be situated in a 6.0 cm x 6.0 cm square area. The area encompassed by the probe tip arrangement should occupy less than 5% of the stack cross-sectional area. The cross-sectional area of the probe tip arrangement used in this test was 5.8 square inches as measured from the probe/nozzle centerlines. This area is less than 1% of the stack cross-sectional area of 908 square inches, which satisfies the Method 301 criterion.

3.4.2 Quad-Train Assembly

Four independent sampling trains made up the quad-train assembly. Although four meter boxes were required, the velocity head (ΔP) was determined using only one set of pitot tubes. The sampling trains were identified as Train A, B, C, and D. Two of the four trains were spiked before each run. The spiking compound was added to the first impinger of these trains in the field for bias determination. The sampling train test matrix is given in Table 3-2.

3.5 Sampling Preparation

3.5.1 Glassware Preparation

All glassware used for sampling was thoroughly cleaned prior to use. This included the probe, impingers, all sample bottles and all utensils used during sample recovery. All glassware was washed with hot soapy water, rinsed with hot tap water, rinsed with distilled water and baked in a oven at 300 °C for four hours. The glassware

Table 3-2

Sampling Train Test Matrix

Run #	Train Designation	
	Spiked	Unspiked
1	A, B	C, D
2	C, D	A, B
3	A, B	C, D
4	C, D	A, B
5	A, B	C, D
6	C, D	A, B
7	A, B	C, D
8	C, D	A, B

was then triple-rinsed with HPLC grade acetonitrile, followed by triple-rinsing with HPLC grade toluene. Open ends of glassware were covered with aluminum foil to minimize potential contamination during transportation and set-up.

3.5.2 Preparation of Impinger Absorbing Solution

Historical data available from the host test site facility and data resulting from the collection of preliminary samples by Radian indicated that the concentration of TDI in the process exhaust was 1 ppm or less, depending on the density of foam being produced on any given day. At this concentration, a 30 cubic foot sample size would result in the collection of approximately 7 mg of TDI. Using the reaction stoichiometry of two moles of 1,2-PP per mole of TDI, the piperazine in toluene solution was then prepared at a concentration level three times the calculated minimum needed, or 133 $\mu\text{g}/\text{mL}$. This would provide a total of approximately 40 mg of 1,2-PP in 300 mL of impinger solution in the first impinger available for reaction with TDI. At this concentration, approximately 22 mg of TDI could be collected in the first impinger before the reagent was exhausted. This solution was prepared in the laboratory just prior to use in the field, and was used within 10 days of preparation.

3.5.3 Preparation of TDI Spiking Solution

The TDI spiking solution was prepared at a concentration of 1.5 mg of the derivatized TDI per 1 mL of acetonitrile. Fifteen mL of this spiking solution was spiked into the first impinger of two of the four trains prior to each QUAD run. This spiking scheme resulted in a total spike amount of derivatized TDI of 22.5 mg, which is equivalent to 7.83 mg of underivatized TDI. This is an amount equivalent to the amount of TDI expected to be collected in the train from the stack gas based on presurvey samples. Therefore, the amount present in the two spiked trains was designed to be at least twice the amount present in the two unspiked trains.

3.5.4 Sampling Equipment Preparation

Final sampling train preparations included calibration and leak checking of all the train equipment, including meter boxes, thermocouples, nozzles, pitot tubes, and umbilicals. Reference calibration procedures were followed when available, and the results were properly documented and archived. If a referenced calibration technique for a particular piece of apparatus was not available, then a state-of-the-art technique was used. A discussion of the techniques used to calibrate this equipment is presented below.

S-Type Pitot Tube Calibration

The EPA has specified guidelines concerning the construction and geometry of an acceptable S-Type pitot tube. If the specified design and construction guidelines are met, a pitot tube coefficient of 0.84 can be used. Information pertaining to the design and construction of the Type-S pitot tube is presented in detail in Section 4.1.1 of EPA Document 600/4-77027b. Only S-Type pitot tubes meeting the required EPA specifications were used. Pitot tubes were inspected and documented as meeting EPA specifications prior to field sampling.

Sampling Nozzle Calibration

Glass nozzles were used for sampling. All nozzles were thoroughly cleaned, visually inspected for damage, and calibrated according to the procedure outlined in Section 4.4.2 of EPA Document 600/4-77-027b.

Dry Gas Meter Calibration

Dry gas meters (DGMs) were used in the sample trains to measure the sample volume and sampling rate. All DGMs were calibrated to document the volume correction factor prior to the departure of the equipment to the field. Post-test

calibration checks were performed after the equipment was returned to Radian's laboratory. Pre- and post-test calibrations agreed to within 5 percent.

Prior to calibration, a positive pressure leak check of the system was performed using the procedure outlined in Section 4.3.2 of EPA Document 600/4-77-23b. The system was placed under approximately 10 inches of water pressure and an oil manometer was used to determine if the pressure decreased over a one-minute period.

After the sampling console was assembled and leak checked, the pump was allowed to run for 15 minutes to allow the pump and DGM to warm up. The valve was then adjusted to obtain the desired flow rate. For the pre-test calibrations, data were collected at the orifice manometer settings (ΔH) of 0.5, 1.0, 1.5, 2.0, 3.0, and 4.0 inches of water. Gas volumes of 5 ft³ were used for the two lower orifice settings, and volumes of 10 ft³ were used for the higher settings. The individual gas meter correction factors (γ_i) were calculated for each orifice setting and averaged. The method requires that each of the individual correction factors fall within $\pm 2\%$ of the average correction factor or the meter must be cleaned, adjusted, and recalibrated. In addition, Radian requires that the average correction factor be 1.00 ± 1 percent. For the post-test calibration, the meter was calibrated three times at the average orifice setting and vacuum which were used during the actual test.

Dry gas meter calibrations were performed at Radian's laboratory using an American® wet test meter as an intermediate standard. The intermediate standard is calibrated every six months against the EPA spirometer at EPA's Emission Measurement Laboratory in Research Triangle Park (RTP), North Carolina.

3.5.5 Sampling Operations

Vent gas samples were collected isokinetically from a single sampling point located in the center of the duct. Preliminary information about the stack gas velocity useful in selecting nozzle size and calculating the K-factor was obtained during the

pre-site survey. Prior to testing, a leak check of pitot lines was performed according to EPA Method 2. Oxygen (O₂) and carbon dioxide (CO₂) concentrations were ambient levels as determined by EPA Method 3. The stack gas moisture data was measured by the host facility as the relative humidity.

Preparation of Sampling Train

The four sampling trains for each QUAD run were charged and assembled in the recovery trailer. The impinger buckets were marked as Train A, B, C, or D. Tared impingers were used. Approximately 300 mL of the absorbing reagent was transferred to the first impinger and 200 mL to the second impinger. The first impinger of each train was of a Greenburg-Smith design and all remaining impingers were of the modified Greenburg-Smith design. The third impinger was empty, 200 to 300 g of silica gel was placed in the fourth impinger and 400 g of charcoal was placed in the fifth impinger. A water jacketed condenser was placed between the outlet of the first impinger and the inlet to the second impinger to promote cooling and minimize evaporative losses of toluene from the first impinger. Fifteen (15) mL of the spiking solution was pipetted into the first impinger of Trains A and B. Openings were covered with Teflon® film or aluminum foil after the assembly of the trains.

Final assembly of the sampling trains occurred at the sampling location. The complete train configuration is shown in Figure 3-3. Thermocouples were attached to measure the stack temperature and probe outlet and impinger outlet temperatures. Crushed ice was added to each impinger bucket, and the probe heaters were turned on and allowed to stabilize at $120^{\circ} \pm 12^{\circ}\text{C}$ ($248^{\circ} \pm 25^{\circ}\text{F}$).

The isocyanate trains were leak checked before and after each sampling run, as required in EPA Method 5. To leak check the assembled train, the nozzle end was capped off and the sampling train evacuated to a vacuum of 15 inches of Hg. After the system was evacuated and the pump isolated from the train, the volume of gas flowing through the system was timed for 60 seconds. The leak rate is required to be




Figure 3-3. Sampling Train for Isocyanate

less than 0.02 acfm or 4% of the average sampling rate, whichever is less. After the leak rate was determined, the cap was slowly removed from the nozzle end until the vacuum in the train returned to atmospheric pressure and then the pump was turned off.

The leak rates and sampling start and stop times were recorded on the sampling task log. Also, any other events that occur during sampling were recorded on the task log (such as pitot cleaning, thermocouple malfunctions, heater malfunctions, and any other unusual occurrences). A nominal sample size of 30 cubic feet was collected in all sampling train. This was accomplished by sampling at a flowrate of 0.5 cubic feet per minute for 60 minutes. The sample volumes for each train by QUAD run are presented in Table 3-3.

3.5.6 Sample Recovery

The sample bottles containing the probe and nozzle washings and the impinger portion of the sampling trains were moved to the recovery trailer.

Each impinger was carefully removed from the impinger bucket, the outside was wiped dry, and the final impinger weight was determined and recorded to calculate stack moisture. The isocyanate sample was then collected in the following two fractions:

- First impinger contents, toluene rinses from the nozzle/probe liner and toluene/acetonitrile rinses of the first impinger and connecting glassware; and
- Contents and toluene/acetonitrile rinses from the second and third impingers and the condenser.

Recovery procedures are detailed in this section. All recovery bottles were wide mouth amber glass with Teflon® lined lids.

Table 3-3.

Quad Train Sample Volumes

Date	Run Number	Train A Vm @ 68° (ft ³)	Train B Vm @ 68° (ft ³)	Train C Vm @ 68° (ft ³)	Train D Vm @ 68° (ft ³)
2/22/93	1	33.42	33.89	33.02	33.04
2/22/93	2	29.07	29.65	28.67	28.40
2/23/93	3	34.24	35.15	33.75	33.01
2/23/93	4	30.60	31.17	30.35	29.54
2/24/93	5	34.14	34.70	34.46	32.59
2/24/93	6	35.10	35.17	34.49	33.78
2/25/93	7	31.11	31.94	30.14	29.91
2/25/93	8	30.89	29.73	30.49	31.95

Container 1 - Probe and First Impinger Contents

The contents and rinses of each of the first impingers and first impinger connectors were combined with the corresponding probe/nozzle washing solution. The entire contents of the first impinger were recovered as a single sample, even if two phases were present. The first impinger and connecting tubing were rinsed three times with 15 mL aliquots of toluene. A final rinse of the impinger with acetonitrile was also necessary to remove any water left on the impinger wall and to recover any remaining derivatized TDI.

Container 2 - Second and Third Impinger Contents/Condenser Rinse

The contents and toluene/acetonitrile rinses of the second and third impingers and the condenser of each train were collected in the same manner used for the first impinger described above. The contents of these impingers were analyzed separately from the contents collected in the first impinger to check for breakthrough; therefore, care was taken to avoid physical carryover from the first impinger to the second. The contents of the fourth and fifth impingers were weighed as previously described and then discarded.

Field Blanks

Four field blanks were prepared and recovered during the test, one on each day of testing. The four field blanks were prepared using Trains A, B, C, and D from the two sets of glassware used during the testing. A sampling train was assembled in the staging area, taken to the sampling location, and leak-checked. The probe of the blank train was heated during the generation of the field blank, but no gas sample was passed through the sampling train. The sampling train for the field blank was recovered with the same procedure described for authentic source samples.

Reagent Blank(s)

Aliquots of each lot of toluene, acetonitrile and absorbing reagent were collected daily to be analyzed as reagent blanks.

Sample Storage and Shipping

Sample containers were checked to ensure that complete labels had been affixed. The labels identified Trains A, B, C, or D, as appropriate. Teflon® lids were tightened and secured with Teflon® tape. The sample bottles were stored in a cooler packed with ice and were returned to Radian's laboratory in these coolers at the end of the field test.

3.6 Quality Control

The following quality control measures were implemented during the field testing phase of this program:

- All dry gas meters were calibrated. Calibration procedures were followed for the pitot tube/probe assembly and all thermocouple readout devices.
- Temperatures of the sampling train were maintained at the specified setting ($120 \pm 12^{\circ}\text{C}$) during each sampling run at levels prescribed in the test plan.
- Sampling trains were leak-checked both prior to and after sampling.
- All glassware was washed and oven-baked following appropriate method protocol, given in the test plan.
- All recovery solvents were HPLC grade and an aliquot of each was collected daily as reagent blanks.
- One field blank was collected for every two sampling runs.

- Chain of Custody forms and log books were filled in at the completion of each day of sampling.

4.0 ANALYTICAL PROCEDURES

4.1 Sample Preparation

The samples were received in the laboratory in screw-capped glass bottles with Teflon®-lined caps, sealed with Teflon® tape and stored in coolers packed with ice. Samples were logged into the laboratory sample tracking system and stored in a secure, refrigerated (4°C) sample storage area prior to analysis. Samples were prepared for analysis within 30 days of collection and analyzed within 30 days of preparation.

All labware was washed with detergent and water and rinsed with hot tap water, rinsed with deionized water, baked at 300°C, rinsed with acetonitrile and toluene prior to use. Solvents used were HPLC grade or equivalent.

Each of the two recovered samples from each train was transferred along with rinses to separate 500 mL round bottom flasks and then evaporated to dryness under vacuum in a 65°C water bath. Each round-bottom flask was then rinsed three times with separate two (2) mL aliquots of acetonitrile (ACN) and the rinses transferred to a 10-mL volumetric flask. The sample was then brought to volume with ACN and transferred to a 15-mL vial and sealed with a Teflon®-lined lid. The vial was stored in a refrigerated sample storage area at 4°C until analysis.

4.2 Chromatographic Analyses

The procedures for the HPLC analyses of the samples are described in the following sections.

4.2.1 Standard Preparation

A 300 µg/mL stock solution of TDI piperazine urea derivative was prepared by dissolving 7.5 mg of the purified crystals of the derivatized TDI in 25 mL of

ACN. [The derivatized TDI was previously prepared by adding 1 g of the neat TDI to a solution of 1-(2-pyridyl) piperazine in ACN, evaporating to dryness and recrystallizing the urea derivative three times from ACN.] Working standards for the calibration curve were made from this stock at six concentration levels in ACN ranging from 0 to 50 $\mu\text{g}/\text{mL}$. This concentration range covered the amount of TDI expected to be collected at the host facility. This stock solution was also used to prepare the field spiking solution. A check standard was prepared from a separately prepared stock solution. This check standard fell in the middle of the calibration curve.

4.2.2 Analysis

HPLC System

The HPLC system operating parameters for analysis of standards and samples were as follows:

Instrument:	RAININ HPXL Delivery System Waters 710B WISP autosampler
Data System:	Nelson 2600 (1 volt)
Column:	Zorbax ODS (4.6 mm ID x 25 cm)
Mobile Phase:	Acetonitrile/0.1M Ammonium Acetate Buffer
Gradient:	25:75 ACN/0.1 m ammonium acetate buffer, pH 6.2, hold 2 minutes, then to 60:40 by 19.5 minutes.
Detector:	RAININ Dynamax Dual-Wavelength, Ultraviolet at 254 nm
Flow Rate:	2 mL/min
Injector Volume:	50 μL
Retention Time:	2,4-TDI, 10.2 min.; 2,6-TDI 8.5 min.

Instrument Calibration

Calibration standards were prepared at seven levels as described in Section 4.2.1. Each calibration standard was injected in duplicate. Linear regression analysis of peak area response versus concentrations of TDI was used to prepare a calibration curve. Linearity of the calibration curve was confirmed by visual inspection and verified by a correlation coefficient of 0.9995. After an initial calibration curve was obtained, the calibration check standard described in Section 4.2.1 was analyzed. This standard was injected after every 3 samples, and was used for daily calibration. This check standard consistently agreed to within 10% of the true value.

All samples were analyzed in triplicate on the HPLC. An acetonitrile blank was analyzed once per day to ensure that the system was not contaminated. A check standard was analyzed prior to sample analysis, after every 3 samples, and at the end of the sample analysis each day.

4.3 Qualitative Identification

Analytes were identified by retention time. The retention time for 2,4-TDI was 10.2 min and 8.5 min for 2,6-TDI. Figures 4-1 and 4-2 show chromatograms from the analysis of first impinger contents from QUAD run number 4 for the unspiked and spiked trains respectively. As seen in the chromatograms, the TDI peaks are well separated from the peak for unreacted 1-2 PP. The peak at 17.5 min. was not identified.

4.4 Calculations

4.4.1 Calculation of the Amount of Isocyanate Collected

A least squares linear regression analysis of the calibration data was used to calculate a correlation coefficient, slope, and intercept. Concentration was used as the independent or X-variable and response was used as the dependent or Y-variable.

Unspiked Train
Quad Run Number 4




Figure 4-1. Chromatogram of Unspiked Train




Figure 4-2. Chromatogram of Spiked Train

The concentration of isocyanate (as the derivative) in the concentrated samples was then calculated as follows:

$$\text{Concentration} = \frac{(\text{Sample Response} - \text{Intercept})}{\text{Slope}} \quad 4-1$$

The total amount (μg) collected in a sample was then calculated by multiplying the concentration ($\mu\text{g}/\text{mL}$) times the final volume (10 mL) of ACN used to redissolve the concentrated sample.

$$\text{Amount TDI derivative} = \text{Concentration } (\mu\text{g}/\text{mL}) \times \text{Final Volume (10 mL)} \quad 4-2$$

The equivalent amount of TDI required to generate this much derivative was calculated by multiplying the ratio of the molecular weights of TDI (174) and the TDI derivative (501) times the amount of TDI derivative (determined by using equation 4-2).

The total amount of 2,4-TDI (underivatized) collected in the unspiked and spiked trains is given in Table 4-1 and Table 4-2 respectively.

4.4.2 Normalization of the Amount of Isocyanate Collected

In order to simplify the comparison of the analytical results of the four trains in each QUAD run for subsequent calculations of bias and precision, the test plan called for the collected of 30 ft^3 of sample in each train. Due to operational variabilities inherent to each train, accurate but slightly differing sample volumes resulted as shown in Table 3-3. Therefore, it was necessary to normalize the data presented in Tables 4-1 and 4-2 to a common sample volume. The sample volume to which all data were normalized was selected to be 35.31 ft^3 which is equivalent to 1 m^3 . The following stepwise calculations were used to normalize the data. The data from QUAD run number 1 are used as an example.

SENT BY:

0-21-00 0-0/NE

ANALYSIS


INSTRUMENT

Data File = E:\S3253F6.PTS Printed on 09-10-1993 at 12:29:41

Start time: 0.00 min. Stop time: 20.00 min. Offset: 0 cts

Full Range: 50 K-Counts

Preliminary Data



Prelim Run # I
Impinge 1

MDI 1233 cts Total


Rakhi
15 checks
10
check in folder

SEMI DT:

0-21-00 9 07-01-00 1

Areas, times, and heights stored in: E:\S3253F7.ATB
Data File = E:\S3253F7.PTS Printed on 09-10-1993 at 13:01:05
Start time: 0.00 min. Stop time: 20.00 min. Offset: 0 cts
Full Range: 50 K-Counts

Preliminary Data



SENT BY:
Data File:
Start time:
Full Range:

0:1002507 1:11 0:21:00 0-0:00:00
0.00 min. Stop time: 20.00 min. Offset:
50 K-Counts

0 cts

Preliminary Data

*Quantitative Standard
23 ug each*




Table 4-1

2,4-TDI Detected in Unspiked Trains, µg

Train ¹	QUAD Run No.											
	1			2			3			4		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	--	--	--	5114	61	5175	--	--	--	1832	16	1848
B	--	--	--	5224	40	5264	--	--	--	1864	24	1888
C	4409 ²	18	4427	--	--	--	3281	32	3313	--	--	--
D	4416	85	4501	--	--	--	2928	33	2960	--	--	--

¹The unspiked trains alternated from run to run, C and D then A and B.

²All values are in micrograms of underivatized TDI.

Table 4-1 (Continued)

Train ¹	QUAD Run No.											
	5			6			7			8		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	--	--	--	7880	105	7993	--	--	--	3521	53	3574
B	--	--	--	7488	89	7577	--	--	--	3805	50	3855
C	4810	17	4827	--	--	--	2160	23	2183	--	--	--
D	5054	42	5096	--	--	--	2180	36	2216	--	--	--

¹The unspiked trains alternated from run to run, C and D then A and B.

²All values are in micrograms of underivatized TDI.

Table 4-2
2,4-TDI Detected in Spiked Trains, µg

Train ¹	QUAD Run No.											
	1			2			3			4		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	11943 ²	64	12007	--	--	--	11488	36	11524	--	--	--
B	11301	28	11329	--	--	--	12024	38	12062	--	--	--
C	--	--	--	12045	35	12080	--	--	--	9329	58	9387
D	--	--	--	12454	49	12503	--	--	--	9429	26	9455

¹The spiked trains alternated from run to run, A and B then C and D.

²All values are in micrograms of underivatized TDI.

Table 4-2 (Continued)

Train ¹	QUAD Run No.											
	5			6			7			8		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	12014	45	12059	--	--	--	10094	46	10140	--	--	--
B	12588	37	12625	--	--	--	9003	40	9043	--	--	--
C	--	--	--	15201	88	15289	--	--	--	10561	45	10606
D	--	--	--	15173	96	15269	--	--	--	10315	44	10359

¹The spiked trains alternated from run to run, A and B then C and D.

²All values are in micrograms of underivatized TDI.

Step 1 Normalize unspiked Trains C and D first impinger amounts (μg) to the sample volume collected (cubic feet) in spiked Train A;

$$\text{Train C} \quad \frac{33.42 \text{ ft}^3}{33.02 \text{ ft}^3} \times 4409 \mu\text{g} = 4462 \mu\text{g} \quad 4-3A$$

$$\text{Train D} \quad \frac{33.42 \text{ ft}^3}{33.04 \text{ ft}^3} \times 4416 \mu\text{g} = 4467 \mu\text{g} \quad 4-3B$$

Step 2 Average the normalized, unspiked train amounts from step 1 above. Assuming the collection efficiency of all trains to be the same, this value would also be the amount of TDI that would be collected by Train A due to sampling the stack gas;

$$\frac{4462 \mu\text{g} + 4467 \mu\text{g}}{2} = 4465 \mu\text{g} \quad 4-4$$

Step 3 Subtract the average value (step 2) from the uncorrected amount (sampled amount plus spike) for spiked Train A, first impinger, to get recovered spike amount;

$$11943 \mu\text{g} - 4465 \mu\text{g} = 7478 \mu\text{g} \quad 4-5$$

Step 4 Normalize the amount collected in spiked Train A, first impinger to 35.31 ft^3 using the sample volume for Train A and the value obtained in step 2;

$$\frac{35.31 \text{ ft}^3}{33.42 \text{ ft}^3} \times 4465 \mu\text{g} = 4718 \mu\text{g} \quad 4-6$$

Step 5 Normalize the amount collected in the second impinger of spiked Train A to 35.31 ft^3 using the sample volume for Train A and the amount determined by HPLC;

$$\frac{35.31 \text{ ft}^3}{33.42 \text{ ft}^3} \times 63.9 \text{ } \mu\text{g} = 67.5 \text{ } \mu\text{g} \quad 4-7$$

Step 6 Sum the values determined from steps 3, 4 and 5 to get the total amount of TDI found in spiked Train A, normalized to 35.31 ft³;

$$7478 \text{ } \mu\text{g} + 4718 \text{ } \mu\text{g} + 67.5 \text{ } \mu\text{g} = 12264 \text{ } \mu\text{g} \quad 4-8$$

Steps 1-6 can be repeated for similar calculations for spiked Train B. The total amount of TDI collected in each of the unspiked trains can be determined by first normalizing the amounts found in the two impingers of each train to 1m³ and then summing the two values. The raw and normalized data for all analysis results are presented in Appendix A. The resulting normalized values are summarized in Tables 4-3 and 4-4.

4.5 Quality Control

Quality control procedures that were implemented for this program include:

- Adhering to applicable sampling and analysis protocols;
- Collecting and analyzing field blanks, trip blanks, reagent blanks, and laboratory blanks;
- Tracking samples from collection to analysis;
- Calibrating all analytical equipment prior to use;
- Maintaining accurate and complete written documentation;
- If any changes were made to the analytical system (i.e., column changed, column maintenance), a calibration check was performed to verify the validity of the calibration curve. If the calibration check did not meet acceptance criteria, the analytical system was recalibrated.

Table 4-3

Normalized Amount of 2,4-TDI Detected in Unspiked Trains, µg

Train ¹	QUAD Run No.							
	1	2	3	4	5	6	7	8
A	--	6287	--	2132	--	8042	--	4086
B	--	6270	--	2139	--	7608	--	4579
C	4735 ²	--	3466	--	4947	--	2557	--
D	4811	--	3166	--	5522	--	2616	--

¹The unspiked trains alternated from run to run, C and D then A and B.

²All values are in micrograms of underivatized TDI, normalized to a sample volume of 35.31 ft³ (1m³).

Table 4-4
Normalized Amount of 2,4-TDI Detected in Spiked Trains, μg

Train ¹	QUAD Run No.							
	1	2	3	4	5	6	7	8
A	12264 ²	--	11625	--	12233	--	10450	--
B	11520	--	12078	--	12717	--	9290	--
C	--	13258	--	9694	--	15471	--	11197
D	--	13733	--	9805	--	15610	--	10947

¹The spiked trains alternated from run to run, A and B then C and D.

²All values are in micrograms of underivatized TDI, normalized to a sample volume of 35.31 ft³ (1m³).

- Analysis of field spiked QC samples; and
- Analysis of check standards every 3 samples.

This section presents the results of the eight sampling runs relative to the criteria for method precision and bias. Fractional results are also presented to show the amount of isocyanate breakthrough occurring in the impinger train. All sample fractions were prepared and analyzed for toluene diisocyanate at Radian's Research Triangle Park laboratory.

5.1

Bias and Precision

Table 5-1 is a summary table which presents the results of the statistical evaluation of the test data following the EPA Method 301 criteria showing the method precision and bias for 2-4 TDI. Method 301 requires valid data from a minimum of six QUAD runs. Table 5-1 presents data from all eight runs. Precision is shown as the percent relative standard deviation of the measured amounts of TDI in the samples. Results for precision of both the spiked and unspiked samples were less than 5 percent RSD, which is well within the limits of acceptable precision (upper limit of 50%) given in EPA Method 301.

Using the data from all eight QUAD runs, method bias was measured at -395 micrograms. This value was determined to be statistically significant at the 95% confidence level, using the t statistic calculated for the analytical data. A correction factor of 1.053 was calculated for use with the method to compensate for the bias should the method be used to measure TDI emissions from similar sources.

Using the data from only seven QUAD runs (eliminating run 8 because this run had the lowest average % recovery and the final leak check for one of the trains was questionable), the method bias was -295 micrograms. This bias was not statistically significant and therefore no correction factor was calculated. In either case, the criteria for an acceptable method were met (i.e., a correction factor between 0.7 and 1.3).

Table 5-1**Summary of Method 301 Statistical Calculations**

Parameter	Spiked Trains		Unspiked Trains	
	7 Runs	8 Runs	7 Runs	8 Runs
Spiked Amount ¹	7828	7828	-	-
RSD, %	3.6	3.4	4.7	5.2
Average Bias ¹	-295	-395	-	-
Bias Significant?	No	Yes	-	-
Correction Factor	1.0	1.053	-	-

¹Values are presented as μg of underivatized TDI

This section presents details of the breakthrough and recovery results for the field samples, as well as recovery information for the spiked compound (2,4-TDI).

5.2.1 Breakthrough

Tables 4-1 and 4-2 provide a summary of the combined total mass of 2,4-TDI collected in the probe/first impinger and second/third impinger samples for the unspiked and spiked trains, respectively. These totals are used as a basis for calculating breakthrough of the TDI from the first impinger to the second impinger. The mass of compound found in the probe/first impinger fraction and in the second impinger fraction were each divided by the total mass of TDI for that train and then multiplied by 100 to yield the percent of the total TDI found in the separate train sections. The results are presented in Table 5-2 and 5-3 for the spiked and unspiked trains respectively.

The average breakthrough for the spiked trains was 1.5% and for the unspiked trains 1.1%. More than 98% of the TDI was collected in the first impinger under the sampling conditions used in this study.

The amount of the toluene contained in the first impingers of each of the trains was reduced by approximately 25% (by weight) during the sampling run due to evaporation. The second impingers showed, on the average, a net gain of approximately 5%. The remainder was collected in the silica gel and the charcoal, both of which showed net weight gains. The total weight gained in the train components following the first impinger more than compensate for losses from the first impinger, probably due to the collection of a small amount of moisture. The loss of toluene from the first impinger was minimized by keeping the impingers in an ice bath and placing a water cooled condenser between the outlet of the first impinger and the inlet of the second impinger.

Table 5-2

Distribution of 2,4-TDI Within the Spiked Trains

Train ¹	Impinger No.	QUAD Run No.							
		1	2	3	4	5	6	7	8
A	1	98.5 ²	--	99.0	--	99.0	--	98.0	--
	2	1.5	--	1.0	--	1.0	--	2.0	--
B	1	99.2	--	99.1	--	99.2	--	97.0	--
	2	0.8	--	0.9	--	0.8	--	3.0	--
C	1	--	99.2	--	96.4	--	98.8	--	98.4
	2	--	0.8	--	3.6	--	1.2	--	1.6
D	1	--	99.0	--	98.5	--	98.7	--	98.4
	2	--	1.0	--	1.5	--	1.3	--	1.6
Average/ % RSD	1	98.5/0.81							
	2	1.5/54.4							

¹Spiked Trains alternate from run to run, A and B, then C and D.

²Values are a percentage of the total amount of 2-4 TDI determined to be in each train.

Table 5-3

Distribution of 2,4-TDI Within the Unspiked Trains

Train ¹	Impinger No.	QUAD Run No.							
		1	2	3	4	5	6	7	8
A	1	--	98.8	--	99.1	--	98.7	--	98.5
	2	--	1.2	--	0.9	--	1.3	--	1.5
B	1	--	99.2	--	98.8	--	98.8	--	98.7
	2	--	0.8	--	1.2	--	1.2	--	1.3
C	1	99.6 ²	--	99.0	--	99.6	--	99.0	--
	2	0.4	--	1.0	--	0.4	--	1.0	--
D	1	99.1	--	98.9	--	99.2	--	98.4	--
	2	1.9	--	1.1	--	0.8	--	1.6	--
Average/ % RSD	1	98.9/0.41							
	2	1.1/37.1							

¹Unspiked Trains alternate from run to run, C and D, then A and B.

²Values are a percentage of the total amount of 2,4-TDI determined to be in each train.

One of the objectives of this test program was to obtain bias and precision data to validate the proposed test method for isocyanates. Samples from two of the four trains of each quad assembly were spiked with TDI before each sampling run. The estimation of method bias is based on the percentage of the TDI spikes recovered. Analytical results used for this calculation are the averages of the triplicate analysis results for each spiked sample. A summary of the spiked TDI recovery percentages is presented in Table 5-4.

The percent recovery was calculated for each spiked train for each run following the calculation procedures outlined in steps 1-3 of Section 5.0. The value obtained at step 3, the amount of spike recovered, is divided by the actual amount of TDI spiked, 7827 μg , multiplied by 100. An average recovery was determined by averaging the 16 individual run recoveries.

The recovery for TDI ranged between 83 and 112 percent and averaged 95 percent with a %RSD of 8.2.

5.3

Quality Assurance/Quality Control

As a part of the testing for Work Assignment No. 55, Radian designed and implemented a quality assurance/quality control (QA/QC) effort tailored to meet the specific needs of this project. The testing was conducted in accordance with QA/QC procedures described in the Quality Assurance Project Plan (QAPP). The results of the QA/QC effort demonstrate that the data are reliable and meet project objectives for completeness and representativeness. The data met the QA objectives for precision and accuracy and there are no data quality issues that effect conclusions regarding the objectives of this project.

Table 5-4

Percent Recovery of the Spiked 2,4-TDI

Train ¹	QUAD Run No.							
	1	2	3	4	5	6	7	8
A	96 ²	--	106	--	89	--	100	--
B	86	--	112	--	96	--	86	--
C	--	89	--	97	--	98	--	88
D	--	95	--	98	--	99	--	83
Average	95							
% RSD	8.2							

¹Spiked Trains alternated from run to run, A and B, then C and D.

²Values are a percentage based upon a spiked amount of 7827.8 µg as 2,4-TDI.

The primary objectives of the QA/QC effort were to control, assess, and document data quality. In order to accomplish these objectives, the QA/QC approach consisted of the following key elements:

- Definition of data quality objectives that reflect the overall technical objectives of the project;
- Design of a sampling, analytical, QA/QC, and data analysis system to meet these objectives; and
- Initiation of corrective action when measurement system performance did not meet the specifications.

These elements include the use of selected standard sampling and analytical procedures as components of the overall approach in addition to, specified calibration requirements, QC checks, data reduction and validation procedures, and sample tracking.

A summary of analysis results for QA/QC samples, which includes measures of precision and accuracy and limitations in the use of these data is presented in this section.

5.3.1 Overview of Data Quality

The QAPjP established specific QA objectives for precision (15% RSD), accuracy ($\pm 30\%$), and completeness (100%) for the determination of TDI emissions. The statistical results presented in Table 5-1 and the % recovery values given in Table 5-4 show that the objectives were met. The data quality acceptance criteria and the experimental results are summarized in Table 5-5. Results for spike/spike duplicates and triplicate analyses were compared with the criteria. In all cases the criteria were met. Other data quality indicators for each type of analysis are also presented throughout the remainder of Section 5.3.

There are no cases where data quality issues impair the study's conclusions with respect to the validity of the sampling and analytical test method procedures. With

Table 5-5

Data Quality Acceptance Criteria and Results

Parameter	Criteria	Results
TDI Spike Recovery	70 - 130%	83 - 112%
TDI Analysis Results QUAD Train, % RSD	15%	5%
Individual DGM Correction Factor Agreement	±2% of Avg	<2%
Analytical Balance	≤0.1 g of Class S Weights	<0.1 g
HPLC Linearity Correlation Coeff.	>0.995	0.9995
HPLC Retention Time Variation	±15%	±10%
HPLC Calibration Check	±10% of Curve	±9%
HPLC System Blank	<0.1% Analyte level	<0.1%
HPLC Replicate Analyses	±10% of 1st injection	±2%
HPLC Method Spikes	±20% of theoretical	±5%

exception of a limited number of samples, the quality of measurement data generated for the test parameters fully meets the data quality objectives outlined in the QAPjP.

5.3.2 Sampling Quality Control

Quality control activities associated with the field sampling are described in the QAPjP. These activities include adherence to accepted reference method protocols, use of standardized data recording sheets, equipment calibration, and collection of field blanks.

Stack sampling QC data, including sampling rates, sample volume collected, maximum recorded leak rate, and maximum allowable leak rate, are summarized in Table 5-6 for each run. All of the data quality indicators are within acceptable limits, with the exception of a slightly high leak rate value for Train C Run 8. However, this train was leak checked at a vacuum of 7 inches of mercury which was almost twice that achieved during sampling and the leak would therefore have very little, if any, effect on the data. The leak rate criterion is $<4\%$ of the average sampling rate or 0.02 dscf, whichever is less.

5.3.3 Sample Storage and Holding Time

Sample hold times specified in the QAPP were met for all samples. All samples were prepared within 30 days of collection and analyzed within 30 days of preparation.

5.3.4 Analytical Quality Control

Results for method spikes, field spikes, field blanks, reagent blanks and method blanks are summarized in Table 5-7. These samples served the dual purpose of controlling and assessing measurement data quality, and providing the basis for precision and accuracy estimates. The QC acceptance criteria for each of these types of samples

Table 5-6

Sampling Train Leak Summary

Run Number	Std. Metered Volume (dscf)	Average Sampling Rate (dscfm)	Maximum Leak Check (dscf @ in Hg)	4% Sample Rate (dscfm)	Acceptable ^a Leak Rate?
1A	33.42	0.743	0.010 @ 10	0.030	Yes
1B	33.89	0.753	0.010 @ 15	0.030	Yes
1C	33.02	0.734	0.010 @ 8	0.029	Yes
1D	33.04	0.734	0.020 @ 10	0.029	Yes
2A	29.07	0.727	0.016 @ 8	0.029	Yes
2B	29.65	0.741	0.009 @ 8	0.030	Yes
2C	28.67	0.717	0.010 @ 7	0.029	Yes
2D	28.40	0.710	0.010 @ 8	0.028	Yes
3A	34.24	0.571	0.012 @ 10	0.023	Yes
3B	35.15	0.586	0.010 @ 8	0.023	Yes
3C	33.75	0.563	0.009 @ 8	0.023	Yes
3D	33.01	0.550	0.020 @ 5	0.022	Yes
4A	30.60	0.765	0.012 @ 8	0.031	Yes
4B	31.17	0.779	0.012 @ 7	0.031	Yes
4C	30.35	0.759	0.008 @ 7	0.030	Yes
4D	29.54	0.739	0.015 @ 10	0.030	Yes
5A	34.14	0.569	0.014 @ 10	0.023	Yes
5B	34.70	0.578	0.012 @ 8	0.023	Yes
5C	34.46	0.574	0.012 @ 8	0.023	Yes
5D	32.59	0.543	0.016 @ 7	0.022	Yes
6A	35.10	0.780	0.007 @ 7	0.031	Yes
6B	35.17	0.782	0.010 @ 8	0.031	Yes
6C	34.49	0.766	0.008 @ 7	0.031	Yes
6D	33.78	0.751	0.008 @ 10	0.030	Yes
7A	31.11	0.778	0.015 @ 9	0.031	Yes
7B	31.94	0.799	0.011 @ 8	0.032	Yes
7C	30.14	0.754	0.009 @ 7	0.030	Yes
7D	29.91	0.748	0.014 @ 10	0.030	Yes
8A	30.89	0.772	0.009 @ 10	0.031	Yes
8B	29.73	0.743	0.011 @ 8	0.030	Yes
8C	30.49	0.762	0.021 @ 7	0.030	No
8D	31.95	0.799	0.018 @ 8	0.032	Yes

^aThe maximum acceptable leak rate is the lesser of 0.020 dscfm or 4% of the average sampling rate.

Table 5-7

Summary of Analytical Quality Control Results

Sample ID	Total Detected μg	Theoretical μg	Percent Error %
Field Blank A	2.5	NA ⁴	NA
Field Blank B	8.3	NA	NA
Field Blank C	6.4	NA	NA
Field Spike 1	7570	7828	96.7
Field Spike 2	7686	7828	98.2
Method Spike 1	8120	7828	104
Method Spike 2	7838	7828	100
Method Spike 3	7890	7828	101
Method Spike 4	7945	7828	101
Toluene Reagent Blank ¹	0.5	NA	NA
ACN Reagent Blank ²	0.4	NA	NA
Method Blank ³	10.2	NA	NA

¹Average of four, ranging from 0.1 to 1.2 μg

²Average of four, ranging from 0.1 to 0.8 μg

³Average of three, ranging from 0.3 to 20.7 μg

⁴NA, Not Applicable

were met as shown in Table 5-5. Field blanks were collected by assembling a sampling train as if to collect a sample, transporting to the sampling location, leak checking and returning the train to the onsite laboratory for recovery. Field spikes and method spikes were prepared by spiking approximately 300 mL of the toluene 1,2-PP solution with 15 mL of the field spiking solution. Method and reagent blanks were prepared by evaporating approximately 300 mL of solvent to dryness and dissolving any residue with 10 mL of ACN. All spikes and blanks met the data acceptance criteria listed in Table 5-5.

No blank contamination problems were identified during the analysis of field and laboratory blanks and no blank corrections were performed for the reported data. All blank analysis data are presented along with other QC and field sample results in Appendix A.

APPENDIX A

Analytical Data for Samples, Blanks, Spikes and
Quality Control Samples

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Dins %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ISO-SCF-32293-4	1263013	5.90	5.40641	9%										
ISO-SCF-32293-4	1253783	5.86	5.40641	8%										
ISO-SCF-32293-4	1249399	5.84	5.40641	8%										
ARL-1	1277072	5.97			2000	11931.6	11942.9	33.42	1.05669	12196.0	12263.5	7827.81	95.69%	I-A-1
ARL-1	1276918	5.97			2000	11930.1								
ARL-1	1280852	5.98			2000	11966.8				67.5				I-A-2
ARL-2	135291	0.64			100	64.1	63.9	33.42	1.05669					
ARL-2	135913	0.64			100	64.4								
ARL-2	133152	0.63			100	63.1								
ARL-3	1196354	5.59			2000	11178.7	11300.8	33.89	1.04204	11491.1	11520.1	7827.81	86.19%	I-D-1
ARL-3	1214532	5.67			2000	11348.3								
ARL-3	1217429	5.69			2000	11375.3								
ARL-4	59159	0.29			100	28.6	27.8	33.89	1.04204	29.0				I-D-2
ARL-4	57134	0.28			100	27.7								
ARL-4	56201	0.27			100	27.2								
ISO-SCF-32293-4	1255771	5.87	5.40641	9%										
ISO-SCF-32293-4	1251918	5.85	5.40641	8%										
ISO-SCF-32293-4	1242330	5.80	5.40641	7%										
ARL-5	471546	2.21			2000	4418.4	4409.3	33.02	1.06949	4715.7	4735.0			I-C-1
ARL-5	470785	2.21			2000	4411.1								
ARL-5	469380	2.20			2000	4398.2								
ARL-6	35898	0.18			100	17.8	18.1	33.02	1.06949	19.3				I-C-2
ARL-6	37029	0.18			100	18.3								
ARL-6	36906	0.18			100	18.2								
ARL-7	469526	2.20			2000	4399.5	4416.1	33.04	1.06885	4720.1	4811.1			I-D-1
ARL-7	461467	2.16			2000	4324.4								
ARL-7	482909	2.26			2000	4524.4								
ARL-8	180144	0.85			100	85.0	85.1	33.04	1.06885	90.9				I-D-2
ARL-8	179633	0.85			100	84.8								
ARL-8	181047	0.85			100	85.4								
ISO-SCF-32293-4	1238919	5.79	5.40641	7%										
ISO-SCF-32293-4	1245039	5.82	5.40641	8%										
ISO-SCF-32293-4	1235673	5.77	5.40641	7%										

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-9	544346	2.55			2000	5097.4	5114.2	29.07	1.21481	6212.9	6287.4			2-A-1
ARL-9	548157	2.57			2000	5132.9								
ARL-9	54954	2.56			2000	5112.4								
ARL-10	130306	0.62			100	61.8	61.4	29.07	1.21481	74.6				2-A-2
ARL-10	130910	0.62			100	62.1								
ARL-10	127140	0.60			100	60.3								
ARL-11	567669	2.66			2000	5314.9	5224.4	29.65	1.19105	6222.5	6269.9			2-B-1
ARL-11	563460	2.64			2000	5275.7								
ARL-11	542754	2.54			2000	5082.6								
ARL-12	83414	0.40			100	39.9	39.8	29.65	1.19105	47.4				2-B-2
ARL-12	83620	0.40			100	40.0								
ARL-12	82217	0.39			100	39.4								
ISO-SCF-32293-4	1220899	5.70	5.40641	6%	1	5.7								
ISO-SCF-32293-4	1232005	5.76	5.40641	6%	1	5.8								
ISO-SCF-32293-4	1230936	5.75	5.40641	6%	1	5.8								
ARL-13	1287864	6.02			2000	12032.2	12045.3	28.67	1.23176	13215.1	13258.2	7827.81	89.16%	2-C-1
ARL-13	1288870	6.02			2000	12041.6								
ARL-13	1291043	6.03			2000	12061.9								
ARL-14	71522	0.34			100	34.4	35.0	28.67	1.23176	43.1				2-C-2
ARL-14	73423	0.35			100	35.3								
ARL-14	73513	0.35			100	35.3								
ARL-15	1335291	6.24			2000	12474.6	12454.1	28.40	1.24347	13671.5	13732.6	7827.81	95.22%	2-D-1
ARL-15	1334709	6.23			2000	12469.2								
ARL-15	1329284	6.21			2000	12418.6								
ARL-16	103190	0.49			100	49.1	49.1	28.40	1.24347	61.1				2-D-2
ARL-16	103848	0.49			100	49.4								
ARL-16	102349	0.49			100	48.7								
ISO-SCF-32293-4	1246426	5.82	5.40641	8%	1	5.8								
ISO-SCF-32293-4	1237852	5.78	5.40641	7%	1	5.8								
ISO-SCF-32293-4	1239959	5.79	5.40641	7%	1	5.8								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bins %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-17	1229980	5.75			2000	11492.4	11487.9	34.24	1.03139	11587.8	11624.8	7827.81	106.14%	3-A-1
ARL-17	1214060	5.67			2000	11343.9								
ARL-17	1244450	5.81			2000	11627.3								
ARL-18	75825	0.36			100	36.4	35.9	34.24	1.03139	37.0				3-A-2
ARL-18	74917	0.36			100	36.0								
ARL-18	73672	0.35			100	35.4								
ARL-19	1282836	5.99			2000	11985.3	12024.4	35.15	1.00468	12039.7	12077.7	7827.81	111.93%	3-B-1
ARL-19	1289518	6.02			2000	12047.7								
ARL-19	1288725	6.02			2000	12040.3								
ARL-20	79007	0.38			100	37.9	37.8	35.15	1.00468	38.0				3-B-2
ARL-20	78713	0.38			100	37.7								
ARL-20	79021	0.38			100	37.9								
ISO-SCF-32293-4	1263449	5.90	5.40641	9%	1	5.9								
ISO-SCF-32293-4	1253499	5.86	5.40641	8%	1	5.9								
ISO-SCF-32293-4	1260480	5.89	5.40641	9%	1	5.9								
ARL-21	351376	1.65			2000	3297.6	3281.0	33.75	1.04636	3433.1	3466.4			3-C-1
ARL-21	343323	1.61			2000	3222.4								
ARL-21	354099	1.66			2000	3323.0								
ARL-22	65492	0.32			100	31.6	31.8	33.75	1.04636	33.3				3-C-2
ARL-22	66002	0.32			100	31.8								
ARL-22	66603	0.32			100	32.1								
ARL-23	319713	1.50			2000	3002.2	2927.6	33.01	1.06982	3132.0	3165.7			3-D-1
ARL-23	310818	1.46			2000	2919.3								
ARL-23	304609	1.43			2000	2861.4								
ARL-24	65115	0.31			100	31.4	31.5	33.01	1.06982	33.7				3-D-2
ARL-24	66054	0.32			100	31.8								
ARL-24	64767	0.31			100	31.2								
ISO-SCF-32293-4	1223529	5.72	5.40641	6%	1	5.7								
ISO-SCF-32293-4	1220297	5.70	5.40641	5%	1	5.7								
ISO-SCF-32293-4	1183133	5.70	5.40641	5%	1	5.7								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-25	198810	0.94			2000	1874.6	1831.7	30.60	1.15407	2113.9	2132.1			4-A-1
ARL-25	195931	0.92			2000	1847.7								
ARL-25	187088	0.89			2000	1772.7								
ARL-26	33336	0.17			100	16.6	15.8	30.60	1.15407	18.3				4-A-2
ARL-26	32875	0.16			100	16.3								
ARL-26	29079	0.15			100	14.6								
ARL-27	200805	0.95			2000	1893.2	1864.2	31.17	1.13297	2112.1	2138.7			4-B-1
ARL-27	200538	0.95			2000	1890.7								
ARL-27	191767	0.90			2000	1808.9								
ARL-28	48281	0.24			100	23.5	23.5	31.17	1.13297	26.6				4-B-2
ARL-28	49506	0.24			100	24.1								
ARL-28	46705	0.23			100	22.8								
ISO-SCF-32293-4	1202635	5.62	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1219147	5.70	5.40641	5%	1	5.7								
ARL-29	1001159	4.68			2000	9358.1	9329.4	30.35	1.16358	9626.4	9693.9	7827.81	96.56%	4-C-1
ARL-29	987039	4.61			2000	9226.4								
ARL-29	1006035	4.70			2000	9403.6								
ARL-30	124507	0.59			100	59.1	58.0	30.35	1.16358	67.5				4-C-2
ARL-30	122754	0.58			100	58.3								
ARL-30	119182	0.57			100	56.6								
ARL-31	1004933	4.70			2000	9393.3	9328.7	29.54	1.19549	9774.2	9804.7	7827.81	97.97%	4-D-1
ARL-31	1018359	4.76			2000	9518.5								
ARL-31	1002870	4.69			2000	9374.1								
ARL-32	53598	0.26			100	26.0	25.5	29.54	1.19549	30.5				4-D-2
ARL-32	53113	0.26			100	25.8								
ARL-32	50832	0.25			100	24.7								
ISO-SCF-32293-4	1200453	5.61	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1203115	5.63	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1189454	5.56	5.40641	3%	1	5.6								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-31	1109769	6.12			2000	12236.5	12014.2	34.14	1.03441	12187.3	12233.3	7827.81	89.41%	5-A-1
ARL-33	1323802	6.18			2000	12367.4								
ARL-33	1224229	5.72			2000	11438.7								
ARL-34	103486	0.49			100	49.3	44.5	34.14	1.03441	46.1				5-B-1
ARL-34	103836	0.49			100	49.4								
ARL-34	72585	0.35			100	34.9								
ARL-35	1369996	6.40			2000	12798.3	12388.1	34.70	1.01771	12678.6	12716.7	7827.81	95.59%	5-B-1
ARL-35	1382908	6.46			2000	12918.7								
ARL-35	1289467	6.02			2000	12047.2								
ARL-36	83360	0.40			100	40.4	37.4	34.70	1.01771	38.0				5-B-2
ARL-36	85164	0.41			100	40.7								
ARL-36	64462	0.31			100	31.1								
ISO-SCF-32293-4	1198549	5.60	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1178529	5.31	5.40641	2%	1	5.5								5-C-1
ARL-37	511915	2.40			2000	4794.9	4809.8	34.46	1.02480	4929.1	4946.9			
ARL-37	520667	2.44			2000	4876.5								
ARL-37	507945	2.38			2000	4757.9								
ARL-38	36452	0.18			100	18.0	17.4	34.46	1.02480	17.8				5-C-2
ARL-38	36462	0.18			100	18.0								
ARL-38	32321	0.16			100	16.1								
ARL-39	532851	2.50			2000	4990.2	5034.0	32.59	1.08360	5476.5	5521.9			5-D-1
ARL-39	544154	2.55			2000	5095.6								
ARL-39	542060	2.54			2000	5076.1								
ARL-40	90692	0.43			100	43.3	41.9	32.59	1.08360	45.4				5-D-2
ARL-40	82975	0.40			100	39.7								
ARL-40	89246	0.43			100	42.6								
ISO-SCF-32293-4	1187611	5.55	5.40641	3%	1	5.5								
ISO-SCF-32293-4	1199484	5.60	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1183133	5.53	5.40641	2%	1	5.5								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-41	861252	4.03			2000	8053.2	7887.9	35.10	1.00612	7936.1	8041.6			6-A-1
ARL-41	860232	4.02			2000	8043.7								
ARL-41	809094	3.78			2000	7566.7								
ARL-42	227095	1.07			100	106.9	104.8	35.10	1.00612	105.4				6-A-2
ARL-42	228142	1.07			100	107.4								
ARL-42	212430	1.00			100	100.1								
ARL-43	815730	3.81			2000	7628.6	7488.0	35.17	1.00411	7518.8	7607.6			6-B-1
ARL-43	825689	3.86			2000	7721.5								
ARL-43	760533	3.56			2000	7113.8								
ARL-44	193894	0.91			100	91.4	88.5	35.17	1.00411	88.8				6-B-2
ARL-44	197908	0.93			100	93.3								
ARL-44	170746	0.81			100	80.6								
ISO-SCF-32293-4	1189088	5.56	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1190921	5.56	5.40641	3%	1	5.6								
ARL-45	1656820	7.74			2000	15173.5	15201.1	34.49	1.02391	15381.5	15471.2	7827.81	97.69%	6-C-1
ARL-45	1652121	7.71			2000	15429.7								
ARL-45	1573883	7.35			2000	14700.0								
ARL-46	187832	0.89			100	88.6	87.6	34.49	1.02391	89.7				6-C-2
ARL-46	195647	0.92			100	92.3								
ARL-46	173379	0.82			100	81.9								
ARL-47	1649873	7.70			2000	15408.7	15173.2	33.78	1.04543	15509.0	15609.8	7827.81	99.46%	6-D-1
ARL-47	1634325	7.63			2000	15263.7								
ARL-47	1589678	7.42			2000	14847.3								
ARL-48	220417	1.04			100	103.8	96.3	33.78	1.04543	100.7				6-D-2
ARL-48	206802	0.97			100	97.5								
ARL-48	186023	0.88			100	87.8								
ISO-SCF-32293-4	1205054	5.63	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1195876	5.59	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1183664	5.53	5.40641	2%	1	5.5								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-49	1081312	5.05			2000	10105.7	10094.4	31.11	1.13515	10398.3	10450.0	7827.81	100.45%	7-A-1
ARL-49	1074952	5.02			2000	10016.4								
ARL-49	1084020	5.07			2000	10131.0								
ARL-50	98427	0.47			100	46.9	45.6	31.11	1.13515	51.8				7-A-2
ARL-50	96270	0.46			100	45.9								
ARL-50	92145	0.44			100	44.0								
ARL-51	963252	4.50			2000	9001.6	9002.6	31.94	1.10566	9246.5	9290.2	7827.81	85.63%	7-B-1
ARL-51	970463	4.54			2000	9071.8								
ARL-51	955412	4.47			2000	8931.4								
ARL-52	83965	0.40			100	40.2	39.5	31.94	1.10566	43.6				7-B-2
ARL-52	83998	0.40			100	40.2								
ARL-52	79455	0.38			100	38.1								
ISO-SCF-32293-4	1194001	5.58	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1201282	5.61	5.40641	4%	1	5.6								
ARL-53	230346	1.08			2000	2168.7	2159.8	30.14	1.17169	2530.6	2557.9			7-C-1
ARL-53	232911	1.10			2000	2192.6								
ARL-53	224911	1.06			2000	2118.0								
ARL-54	49290	0.24			100	24.0	23.3	30.14	1.17169	27.3				7-C-2
ARL-54	49749	0.24			100	24.2								
ARL-54	44499	0.22			100	21.8								
ARL-55	237247	1.12			2000	2233.1	2180.2	29.91	1.18070	2574.2	2616.4			7-D-1
ARL-55	228829	1.08			2000	2154.5								
ARL-55	228660	1.08			2000	2153.0								
ARL-56	75486	0.36			100	36.2	35.8	29.91	1.18070	42.3				7-D-2
ARL-56	75034	0.36			100	36.0								
ARL-58	73273	0.35			100	35.2								
ISO-SCF-32293-4	1201622	5.61	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1192039	5.57	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1184261	5.53	5.40641	2%	1	5.5								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-57	374801	1.76			2000	3516.0	3520.7	30.89	1.14324	4025.0	4086.0			8-A-1
ARL-57	377410	1.77			2000	3540.4								
ARL-57	373681	1.75			2000	3505.6								
ARL-58	111353	0.53			100	52.9	53.4	30.89	1.14324	61.0				8-A-2
ARL-58	112493	0.53			100	53.5								
ARL-58	113066	0.54			100	53.7								
ARL-59	406883	1.91			2000	3815.3	3805.4	29.73	1.18785	4520.2	4579.2			8-B-1
ARL-59	401924	1.88			2000	3769.0								
ARL-59	408657	1.92			2000	3811.8								
ARL-60	105005	0.50			100	50.0	49.7	29.73	1.18785	59.0				8-B-2
ARL-60	104950	0.50			100	50.0								
ARL-60	102971	0.49			100	49.0								
ISO-SCF-32293-4	1197542	5.59	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1200068	5.61	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1190471	5.56	5.40641	3%	1	5.6								
ARL-61	1137017	5.31			2000	10625.3	10561.2	30.49	1.15824	11344.9	11197.4	7827.81	88.46%	8-C-1
ARL-61	1120589	5.24			2000	10471.9								
ARL-61	1132853	5.29			2000	10586.4								
ARL-62	94047	0.45			100	45.2	45.3	30.49	1.15824	52.5				8-C-2
ARL-62	95991	0.46			100	45.8								
ARL-62	94335	0.45			100	45.0								
ARL-63	1108755	5.18			2000	10361.7	10314.5	31.95	1.10531	10721.6	10770.2	7827.81	83.01%	8-D-1
ARL-63	1098270	5.12			2000	10245.2								
ARL-63	1106072	5.17			2000	10336.7								
ARL-64	92259	0.44			100	44.0	44.0	31.95	1.10531	48.6				8-D-2
ARL-64	92558	0.44			100	44.2								
ARL-64	91667	0.44			100	43.8								
ISO-SCF-32293-4	1186551	5.54	5.40641	3%	1	5.5								
ISO-SCF-32293-4	1187157	5.55	5.40641	3%	1	5.5								
ISO-SCF-32293-4	1196473	5.59	5.40641	3%	1	5.6								

Sample Name	FILE	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ISO-SCF-32293-4	S3083F4	1263013	5.90	5.41	9%	1	5.9	5.9			QC
ISO-SCF-32293-4	S3083F5	1253783	5.86	5.41	8%	1	5.9				
ISO-SCF-32293-4	S3083F6	1249399	5.84	5.41	8%	1	5.8				FBA
ARL-81	S3083F19	30452	0.15			10	1.5	1.6			
ARL-81	S3083F20	31446	0.16			10	1.6				
ARL-81	S3083F21	33523	0.17			10	1.7				
ARL-104	S3083F22	809699	3.79			2000	7572.4	7569.9	7827.81	97%	FS-1
ARL-104	S3083F23	808659	3.78			2000	7562.7				
ARL-104	S3083F24	809952	3.79			2000	7574.7				QC
ISO-SCF-32293-4	S3083F25	1255771	5.87	5.41	9%	1	5.9	5.8			
ISO-SCF-32293-4	S3083F26	1251918	5.85	5.41	8%	1	5.8				
ISO-SCF-32293-4	S3083F27	1242330	5.80	5.41	7%	1	5.8				FBA
ARL-82	S3083F40	16055	0.08			10	0.8	0.9			
ARL-82	S3083F41	16597	0.09			10	0.9				
ARL-82	S3083F42	16113	0.09			10	0.9				
ARL-105	S3083F43	832058	3.89			2000	7780.9	7686.3	7827.81	98%	FS-2
ARL-105	S3083F44	822507	3.85			2000	7691.8				
ARL-105	S3083F45	811167	3.79			2000	7586.1				QC
ISO-SCF-32293-4	S3083F46	1238919	5.79	5.41	7%	1	5.8	5.8			
ISO-SCF-32293-4	S3083F47	1245039	5.82	5.41	8%	1	5.8				
ISO-SCF-32293-4	S3083F48	1235673	5.77	5.41	7%	1	5.8				
ARL-83	S3084F13	163746	0.77			10	7.7	7.7			FBB
ARL-83	S3084F14	162706	0.77			10	7.7				
ARL-83	S3084F15	164806	0.78			10	7.8				
ARL-106	S3084F16	869707	4.07			2000	8132.1	8120.1	7827.81	104%	MS-1
ARL-106	S3084F17	867360	4.06			2000	8110.2				
ARL-106	S3084F18	868206	4.06			2000	8118.1				
ISO-SCF-32293-4	S3084F19	1220899	5.70	5.41	6%	1	5.7	5.7			QC
ISO-SCF-32293-4	S3084F20	1232005	5.76	5.41	6%	1	5.8				
ISO-SCF-32293-4	S3084F21	1230936	5.75	5.41	6%	1	5.8				
ARL-84	S3084F34	33054	0.16			10	1.6	1.6			FBB
ARL-84	S3084F35	32381	0.16			10	1.6				
ARL-84	S3084F36	32300	0.16			10	1.6				

Sample Name	FILE	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ARL-107	S3084F37	829745	3.88			2000	7759.3	7837.5	7827.81	100%	MS-2
ARL-107	S3084F38	838117	3.92			2000	7837.4				
ARL-107	S3084F39	846508	3.96			2000	7915.7				
ISO-SCF-32293-4	S3084F40	1246426	5.82	5.41	8%	1	5.8	5.8			QC
ISO-SCF-32293-4	S3084F41	1237852	5.78	5.41	7%	1	5.8				
ISO-SCF-32293-4	S3084F42	1239959	5.79	5.41	7%	1	5.8				
ARL-85	S3085F19	75475	0.36			10	3.6	3.6			FBC
ARL-85	S3085F20	75608	0.36			10	3.6				
ARL-85	S3085F21	72681	0.35			10	3.5				
ARL-108	S3085F22	847084	3.96			2000	7921.1	7890.2	7827.81	101%	MS-3
ARL-108	S3085F23	816897	3.91			2000	7826.0				
ARL-108	S3085F24	847337	3.96			2000	7923.4				
ISO-SCF-32293-4	S3085F25	1263449	5.90	5.41	9%	1	5.9	5.9			QC
ISO-SCF-32293-4	S3085F26	1251499	5.86	5.41	8%	1	5.9				
ISO-SCF-32293-4	S3085F27	1260480	5.89	5.41	9%	1	5.9				
ARL-86	S3085F40	59577	0.29			10	2.9	2.8			FBC
ARL-86	S3085F41	56343	0.27			10	2.7				
ARL-86	S3085F42	59626	0.29			10	2.9				
ARL-109	S3085F43	851309	3.98			2000	7960.5	7944.8	7827.81	101%	MS-4
ARL-109	S3085F44	850793	3.98			2000	7955.6				
ARL-109	S3085F45	846800	3.96			2000	7918.4				
ISO-SCF-32293-4	S3085F46	1245663	5.82	5.41	8%	1	5.8	4.0			QC
ISO-SCF-32293-4	S3085F47	0	0.01	5.41	-100%	1	0.0				
ISO-SCF-32293-4	S3085F48	1296988	6.06	5.41	12%	1	6.1				
ISO-SCF-32293-4	S3098F1	1158548	5.41	5.41	0%	1	5.4				
ARL-89	S3098F2	0	0.01			10	0.1	0.1			T-RB1
ARL-89	S3098F3	0	0.01			10	0.1				
ARL-89	S3098F4	0	0.01			10	0.1				
ARL-90	S3098F5	0	0.01			10	0.1				
ARL-90	S3098F6	5758.5	0.04			10	0.1	0.3			T-RB2
ARL-90	S3098F7	5867.5	0.04			10	0.4				
ARL-91	S3098F8	0	0.01			10	0.1	0.2			T-RB3
ARL-91	S3098F9	3273	0.03			10	0.3				
ARL-91	S3098F10	0	0.01			10	0.1				

Sample Name	FILE	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ARL-92	S3098F11	26248	0.13			10	1.3	1.2			T-RB4
ARL-92	S3098F12	22909.08	0.12			10	1.2				
ARL-92	S3098F13	22154	0.11			10	1.1				
ISO-SCF-32293-4	S3098F14	1202.88	5.62	5.41	4%	1	5.6	5.7			QC
ISO-SCF-32293-4	S3098F15	1212015	5.66	5.41	5%	1	5.7				
ISO-SCF-32293-4	S3098F16	1220989	5.70	5.41	6%	1	5.7				
ARL-94	S3098F17	0	0.01			10	0.1	0.2			A-RB1
ARL-94	S3098F18	5431	0.04			10	0.4				
ARL-94	S3098F19	0	0.01			10	0.1				
ARL-95	S3098F20	0	0.01			10	0.1	0.1			A-RB2
ARL-95	S3098F21	0	0.01			10	0.1				
ARL-95	S3098F22	0	0.01			10	0.1				
ARL-96	S3098F23	6352.5	0.04			10	0.4	0.4			A-RB3
ARL-96	S3098F24	6438	0.04			10	0.4				
ARL-96	S3098F25	5888	0.04			10	0.4				
ARL-97	S3098F26	25806	0.13			10	1.3	0.8			A-RB4
ARL-97	S3098F27	21834	0.11			10	1.1				
ARL-97	S3098F28	0	0.01			10	0.1				
ISO-SCF-32293-4	S3098F29	1164624	5.44	5.41	1%	1	5.4	5.4			QC
ISO-SCF-32293-4	S3098F30	1159319	5.42	5.41	0%	1	5.4				
ISO-SCF-32293-4	S3098F31	1149310	5.37	5.41	-1%	1	5.4				
ARL-99	S3098F32	0	0.01			10	0.1	0.1			ADS-RB
ARL-99	S3098F33	0	0.01			10	0.1				
ARL-99	S3098F34	0	0.01			10	0.1				
ARL-100	S3098F35	0	0.01			10	0.1	0.1			ADS-RB
ARL-100	S3098F36	0	0.01			10	0.1				
ARL-100	S3098F37	0	0.01			10	0.1				
ARL-101	S3098F38	15010.13	0.08			10	0.8	0.9			ADS-RB
ARL-101	S3098F39	15823	0.08			10	0.8				
ARL-101	S3098F40	23127	0.12			10	1.2				
ARL-102	S3098F41	0	0.01			10	0.1	0.1			ADS-RB
ARL-102	S3098F42	0	0.01			10	0.1				
ARL-102	S3098F43	0	0.01			10	0.1				

Sample Name	FILE	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount		Avg Amt Sample	Amount		Train ID
							Sample	Spiked		Sample	Spiked	
ISO-SCF-32293-4	S3098F44	1187727	5.55	5.41	3%	1	5.5	5.6	5.6		QC	
ISO-SCF-32293-4	S3098F45	1199251	5.60	5.41	4%	1	5.6					
ISO-SCF-32293-4	S3098F46	1208008	5.63	5.41	4%	1	5.6					
ARL-117	S3098F47	4701	0.03			10	0.3	0.3			MB-1	
ARL-117	S3098F48	4880.5	0.03			10	0.3					
ARL-117	S3098F49	5001	0.03			10	0.3					
ARL-118	S3098F50	204900	0.96			10	9.6	9.7			MB-2	
ARL-118	S3098F51	207157	0.98			10	9.8					
ARL-118	S3098F52	207481	0.98			10	9.8					
ARL-119	S3098F53	446217.5	2.09			10	20.9	20.7			MB-3	
ARL-119	S3098F54	427833.1	2.01			10	20.1					
ARL-119	S3098F55	452112	2.12			10	21.2					
ISO-SCF-4893-1	S3098F56	1164164	5.44	5.41	1%	1	5.4	5.5			QC	
ISO-SCF-4893-1	S3098F57	1176245	5.50	5.41	2%	1	5.5					
ISO-SCF-4893-3	S3098F58	1160212	5.42	5.41	0%	1	5.4					

2,4-TDI Summary Information

Amount of 2,4-TDI Spiked into the trains: 7827.81 ug

Percent Recovery for Spiked Quad Trains

Quad No. Train ID	1		2		3		4		5		6		7		Average	RSD	
	A	B	C	D	A	B	C	D	A	B	C	D	A	B			C
% Recovery	95.69%	86.10%	89.16%	95.22%	106.14%	111.93%	96.56%	97.97%	89.41%	95.59%	97.69%	99.46%	100.45%	85.63%	88.40%	83.01%	8%
Total ug	12283	11520	13258	13733	11625	12070	9694	9805	12233	12717	15471	15810	10450	9290	11197	10770	11962

Amount Collected in Unspiked Quad Trains

Quad No. Train ID	1		2		3		4		5		6		7		Average	RSD	
	C	D	A	B	C	D	A	B	C	D	A	B	C	D			
Total ug	4735	4811	6287	6270	3466	3166	2132	2139	4947	5522	6042	7608	2558	2818	4088	4579	4560

Percent Carry over from 1st Impinger in Spiked Quad Trains

Quad No. Train ID	1		2		3		4		5		6		7		Average	RSD	
	A	B	C	D	A	B	C	D	A	B	C	D	A	B			C
1st Impinger	98.40%	99.21%	99.21%	98.97%	99.02%	99.11%	96.38%	98.46%	98.95%	99.22%	98.83%	98.71%	98.03%	97.02%	98.44%	98.35%	98.52%
2nd Impinger	1.52%	0.79%	0.79%	1.03%	0.98%	0.89%	3.62%	1.54%	1.05%	0.70%	1.17%	1.20%	1.97%	2.08%	1.56%	1.65%	1.40%

Percent Carry over from 1st Impinger in Unspiked Quad Trains

Quad No. Train ID	1		2		3		4		5		6		7		Average	RSD	
	C	D	A	B	C	D	A	B	C	D	A	B	C	D			
1st Impinger	99.59%	98.11%	98.81%	99.24%	99.04%	98.94%	99.14%	90.76%	99.84%	99.18%	98.69%	98.83%	98.03%	98.38%	98.51%	98.71%	98.91%
2nd Impinger	0.41%	1.89%	1.19%	0.76%	0.96%	1.06%	0.86%	1.24%	0.38%	0.82%	1.31%	1.17%	1.07%	1.82%	1.49%	1.20%	1.09%

AREAL WA 55 -- Method 301 Results
Using Modified Data

Run #	Train			Amount Spiked	Precision of UNSpiked Samples				
	A	B	C		D	Diff	STDu	STDm	RSD
1	12263.0	11520.0	4735.0	4811.0	7827.81	-76.00	216.596	30.942	4.721
2	6287.0	6270.0	13258.0	13733.0	7827.81	17.00			
3	11625.0	12078.0	3466.0	3166.0	7827.81	300.00			
4	2132.0	2139.0	9694.0	9805.0	7827.81	-7.00			
5	12233.0	12717.0	4947.0	5522.0	7827.81	-575.00			
6	8084.0	7608.0	15471.0	15610.0	7827.81	476.00			
7	10450.0	9290.0	2557.0	2616.0	7827.81	-59.00			

AREAL WA 55 -- Method 301 Results
Using Modified Data

Run #	Train			Amount			Precision of Spiked Samples				Bias			
	A	B	C	D	Spiked	Diff	SDs	SDm	RSD	Run	Compound	SD	t Test	CF
1	12263.0	11520.0	4735.0	4811.0	7827.81	743.00	430.48	162.71	3.55	-709.31	-295.41	481.90	-1.622	N/A
2	6287.0	6270.0	13258.0	13733.0	7827.81	-475.00				-610.81				
3	11625.0	12078.0	3466.0	3166.0	7827.81	-453.00				707.69				
4	2132.0	2139.0	9694.0	9805.0	7827.81	-111.00				-213.81				
5	12233.0	12717.0	4947.0	5522.0	7827.81	-484.00				-587.31				
6	8084.0	7608.0	15471.0	15610.0	7827.81	-139.00				-133.31				
7	10450.0	9290.0	2557.0	2616.0	7827.81	1160.00				-544.31				

AREAL WA 55 -- Method 301 Results
Using Modified Data


Run #	Train			Amount			Precision of UNSpiked Samples		
	A	B	C	D	Spiked	Diff	STDu	STDm	RSD
1	12263.0	11520.0	4735.0	4811.0	7827.81	-76.00	237.150	29.644	5.205
2	6287.0	6270.0	13258.0	13733.0	7827.81	17.00			
3	11625.0	12078.0	3466.0	3166.0	7827.81	300.00			
4	2132.0	2139.0	9694.0	9805.0	7827.81	-7.00			
5	12233.0	12717.0	4947.0	5522.0	7827.81	-575.00			
6	8084.0	7608.0	15471.0	15610.0	7827.81	476.00			
7	10450.0	9290.0	2557.0	2616.0	7827.81	-59.00			
8	4086.0	4579.0	11197.0	10947.0	7827.81	-493.00			

REAL WA 55 -- Method 301 Results
Using Modified Data

Run	Train				Amount Spiked	Precision of Spiked Samples			Bias					
	A	B	C	D		Diff	SDs	SDm	RSD	Run	Compound	SD	t Test	CF
1	12263.0	11520.0	4733.0	4811.0	7827.81	743.00	407.50	144.07	3.40	-709.31	-394.53	471.48	-2.367	1.053
2	6287.0	6270.0	13258.0	13733.0	7827.81	-475.00				-610.81			^	
3	11625.0	12078.0	3466.0	3166.0	7827.81	-453.00				707.69				
4	2132.0	2139.0	9694.0	9805.0	7827.81	-111.00				-213.81			critical Value	
5	12233.0	12717.0	4947.0	5522.0	7827.81	-484.00				-587.31			is 2.131	
6	8084.0	7608.0	15471.0	15610.0	7827.81	-139.00				-133.31				
7	10450.0	9290.0	2557.0	2616.0	7827.81	1160.00				-544.31				
8	4086.0	4579.0	11197.0	10947.0	7827.81	250.00				-1088.31				



APPENDIX K
CALCULATION EQUATIONS



		LP - SACOLA		Report No. 6-8024	
		Sagola, Michigan			
Oxides of Nitrogen					
LB/HR Calculations					
<i>E-Tube Outlet</i>					
RUN	NOX ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	3.2	103228	3.82E-07	2.37	817.7
2	2.4	103158	2.87E-07	1.77	827.9
3	1.7	103160	2.03E-07	1.26	832.5
AVG	2.43			1.80	826.0
<i>Dryer RTO Stack</i>					
RUN	NOX ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	2.5	99560	2.98E-07	1.78	92.0
2	2.8	100405	3.34E-07	2.01	102.4
3	3.2	100405	3.82E-07	2.30	105.5
AVG	2.83			2.03	100.0
<i>Press RTO Inlet</i>					
RUN	NOX ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	8.2	64300	9.79E-07	3.78	1.4
2	7.6	68979	9.07E-07	3.76	1.6
3	6.2	72300	7.4E-07	3.21	1.4
AVG	7.33			3.58	1.5
<i>Press RTO Stack</i>					
RUN	NOX ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	36.3	77990	4.33E-06	20.28	6.5
2	34.3	76250	4.1E-06	18.74	8.0
3	34.9	77090	4.17E-06	19.27	7.0
AVG	35.17			19.43	7.2
Carbon Monoxide					
LB/HR Calculations					
<i>E-Tube Outlet</i>					
RUN	CO ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	1817	103228	0.000132		
2	1841	103158	0.000134		
3	1851	103160	0.000134		
AVG	1836				
<i>Dryer RTO Stack</i>					
RUN	CO ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	212	99560	1.54E-05		
2	234	100405	1.7E-05		
3	241	100405	1.75E-05		
AVG	229				
<i>Press RTO Inlet</i>					
RUN	CO ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	5.0	64300	3.63E-07		
2	5.3	68979	3.85E-07		
3	4.4	72300	3.2E-07		
AVG	4.9				
<i>Press RTO Stack</i>					
RUN	CO ppm	Flow	LB/DSCF	LB/HR	LB/HR
1	19.2	77990	1.4E-06		
2	24.2	76250	1.76E-06		
3	20.8	77090	1.51E-06		
AVG	21.4				

LOUISIANA PACIFIC CORPORATION										Report No. 6-8024
SAGOLA, MICHIGAN										
Total Hydrocarbons Calculations										
Primary Cyclone Exhaust 1										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)			(GR/DSCF)
2	1	24.9	1937	26838	129.34					0.5622716
	2	24.3	1796	27141	120.32					0.51721
	3	24.3	1677	27140	112.35					0.4829406
						1803.3333	120.6706			
Primary Cyclone Exhaust 2										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)			(GR/DSCF)
2	1	25.1	2165	28278	152.73					0.6301335
	2	22.4	2125	29969	153.35					0.5969716
	3	22.4	1840	29970	132.79					0.5169072
						2043.3333	146.2888			
Primary Cyclone Exhaust 3										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)			(GR/DSCF)
2	1	22.7	3498	27973	236.53					0.9864994
	2	20.8	2595	27234	166.74					0.7142803
	3	20.8	3474	27230	223.18					0.9562273
						3189	208.8168			

		Total Hydrocarbons Calculations				Report No. 6-8024	
		MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)
Dryer RTO Stack							
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)
2	1	22.9	24.5	99560	5.91		
	2	23.5	8.0	100405	1.96		
	3	23.5	18.8	100405	4.61		
						17.1	4.161398
Press RTO Inlet							
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)
8	1	3.9	705	64300	88.14		
	2	2.9	764.0	68979	101.41		
	3	3	744	72300	103.62		
						737.66667	97.72591
Press RTO Stack							
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)
8	1	2.9	11.9	77990	1.79		
	2	3.3	19.4	76250	2.86		
	3	3.4	6.8	77090	1.01		
						12.7	1.886125

LOUISIANA PACIFIC - SAGOLA					Report No. 6-8024				
Sagola, Michigan									
Gas Concentration Correction Calculations									
PCE#1	THC Calculations								
	Cbar				Cma				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	665.39	8.6	1	4.80	287	310	287	299	645.52
3	580.81	2.4	0	1.20	287	270	288	279	598.81
4	547.44	7.65	2.4	5.03	287	280	287	284	559.02
PCE #2									
	Cbar				Cma				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	705.39	5.5	1	3.25	287	282	283	283	721.63
3	694.91	4	1	2.50	287	282	284	283	708.46
4	586.96	4	1	2.50	287	270	282	276	613.31
PCE #3									
	Cbar				Cma				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	1124.87	1	2	1.50	287	269	287	278	1166.03
3	844.41	10	0	5.00	287	280	287	284	865.03
4	1143.93	0	0	0.00	287	284	283	284	1158.05
Dryer RTO Stack									
	Cbar				Cma				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	27.37	0	0	0.00	30	27	30	29	28.81
3	12.36	1	0	0.50	30	29	30	30	12.27
4	22.21	2	0	1.00	30	27	30	29	23.14
Press RTO Inlet									
	Cbar				Cma				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
1	233.39	0	0	0.00	285	281	285	283	235.04
2	255.7	1	0	0.50	285	287	285	286	254.75
3	252.27	0	0	0.00	285	292	287	290	248.35
Press RTO Stack									
	Cbar				Cma				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
1	6.30	0	0.4	0.20	30.4	28.6	30.7	30	6.30
2	8.45	0	0	0.00	30.4	28.8	29.5	29	8.81
3	5.11	1.5	0	0.75	30.4	29.2	30.0	30	4.59

Gas Concentration Correction Calculations										
NOx Calculations										
E-Tube Outlet										
	Cbar				Cma					
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale			
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas	
2	4.26	1.3	0.9	1.10	91.9	92.9	91.7	92	3.18	
3	3.66	1.3	1.3	1.30	91.9	92.5	92.9	93	2.37	
4	2.53	0.4	1.3	0.85	91.9	92.0	92.5	92	1.69	
Dryer RTO Stack										
	Cbar				Cma					
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale			
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas	
2	3.46	1	1	1.00	90.6	90.6	90.6	91	2.49	
3	3.79	1	1	1.00	90.6	90.6	90.6	91	2.82	
4	3.23	-1	1	0.00	90.6	90.6	90.6	91	3.23	
Press RTO Inlet										
	Cbar				Cma					
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale			
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas	
1	9.18	2	0	1.00	90.6	93	90.6	92	8.16	
2	8.1	1	0	0.50	90.6	90.6	90.6	91	7.64	
3	7.16	1	1	1.00	90.6	92.6	90.6	92	6.16	
Press RTO Stack										
	Cbar				Cma					
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale			
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas	
1	36.43	0.2	0.2	0.20	91.9	92.4	91.4	92	36.31	
2	34.51	-0.1	0.2	0.05	91.9	92.5	92.4	92	34.27	
3	34.88	-0.6	-0.1	-0.35	91.9	92.3	92.5	92	34.91	

LP - Sagola									
Gas Concentration Correction Calculations									
CO Calculations									
E-Tube Outlet									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	1805	3	-1	1.00	620	617	616	617	1817.19
3	1824	1	3	2.00	620	614	617	616	1841.30
4	1829	0	1	0.50	620	612.0	614	613	1850.89
Dryer RTO Stack									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	210.73	0	2	1.00	147	146	147	147	211.89
3	232.69	0	0	0.00	147	146	146	146	234.28
4	242.44	0	0	0.00	147	150.0	146	148	240.80
Press RTO Inlet									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
1	5.01	0	0	0.00	147	145	147	146	5.04
2	5.23	0	0	0.00	147	144	145	145	5.32
3	4.32	0	0	0.00	147	145.0	144	145	4.39
Press RTO Stack									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(ppm,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
1	18.88	0	0	0.00	143.3	140.2	141.5	141	19.21
2	23.37	-0.6	0	-0.30	143.3	139.8	140.2	140	24.18
3	19.73	-0.6	-0.6	-0.60	143.3	139.6	139.8	140	20.76

Gas Concentration Correction Calculations									
O2 Calculations									
<i>E-Tube Outlet</i>									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(%v/v,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	17.38	0	0	0.00	13.5	13.4	13.5	13	17.44
3	17.29	0	0	0.00	13.5	13.4	13.4	13	17.42
4	17.34	0	0	0.00	13.5	13.4	13.4	13	17.47
<i>Dryer RTO Stack</i>									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(%v/v,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	16.95	0	0	0.00	13.5	13.5	13.5	14	16.95
3	16.98	0	0	0.00	13.5	13.6	13.5	14	16.92
4	16.54	0	0	0.00	13.5	13.5	13.5	14	16.54

Gas Concentration Correction Calculations									
CO2 Calculations									
<i>E-Tube Outlet</i>									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(%v/v,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	3.17	0.2	0	0.10	10.8	10.9	10.8	11	3.08
3	3.12	0.2	0.2	0.20	10.8	10.9	10.9	11	2.95
4	3.05	0.2	0.2	0.20	10.8	10.8	10.9	11	2.89
<i>Dryer RTO Stack</i>									
	<i>Cbar</i>				<i>Cma</i>				
	OUR CONC	ZERO	ZERO		CONC	Upscale	Upscale		
RUN #	(%v/v,d)	(Final)	(Initial)	Co	(Upscale)	(Final)	(Initial)	Cm	Cgas
2	3.44	0	0	0.00	10.8	10.8	10.8	11	3.44
3	3.44	0	0	0.00	10.8	10.7	10.8	11	3.46
4	3.37	0	0	0.00	10.8	10.7	10.8	11	3.39

METHOD 2
CALCULATION EQUATIONS

$$\bar{V}_s = 85.49 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60 (1 - B_{ws}) \bar{V}_s A \left(\frac{528}{T_{s(avg)}} \right) \left(\frac{P_s}{29.92} \right)$$

$$Q_a = 60 \bar{V}_s A$$

$$\dot{m}_s = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} - 0.0003641 P_s (T_{db} - T_{wb})) / vp_{twb}$$

$$B_{ws}^* = RH(vp_{twb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

SYMBOLS

A	=	Cross Sectional area of stack, SQ. FT.
A_n	=	Cross sectional area of nozzle, SQ. FT.
B_{ws}	=	Water vapor in gas stream, proportion by volume
C_p	=	Pitot tube coefficient, dimensionless
C_a	=	Concentration of particulate matter in stack gas, wet basis, GR/ACF
C_s	=	Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	=	Excess air, percent by volume
γ	=	Dry test meter correction factor, dimensionless
G_d	=	Specific gravity (relative to air), dimensionless
I	=	Isokinetic variation, percent by volume
M_d	=	Molecular weight of stack gas, dry basis, g/g - mole.
m_g	=	Mass flow of wet flue gas, LB/HR
m_p	=	Particulate mass flow, LB/HR
M_s	=	Molecular weight of stack gas, wet basis, g/g mole.
M_p	=	Total amount of particulate matter collected, g
P_{bar}	=	Atmospheric pressure, IN. HG. (uncompensated)
P_g	=	Stack static gas pressure, IN. WC.
P_s	=	Absolute pressure of stack gas, IN. HG.
P_{std}	=	Standard absolute pressure, 29.92 IN. HG.
A_s	=	Actual volumetric stack gas flow rate, ACFM
$Q_{s,d}$	=	Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
RH	=	Relative humidity, %

032294-G:\STACK\WPMETHODS-EQ.15

T_{db}	=	Dry bulb temperature of stack gas, °F
T_{wb}	=	Wet bulb temperature of stack gas, °F
$T_{m(avg)}$	=	Absolute average dry gas meter temperature, °R
$T_{s(avg)}$	=	Absolute average stack temperature, °R
T_{std}	=	Standard absolute temperature, 528 °R (68 °F)
θ	=	Total sampling time, min.
V_{lc}	=	Total volume of liquid collected in impingers and silica gel, ml
V_m	=	Volume of gas sample as measured by dry gas meter, CF
$V_{m(std)}$	=	Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
$V_{w(std)}$	=	Volume of water vapor in the gas sample corrected to standard conditions, SCF
\bar{V}_s	=	Average actual stack gas velocity, FT/SEC
vp_{adb}	=	Vapor pressure at T_{db} , IN. HG.
vp_{awb}	=	Vapor pressure at T_{wb} , IN. HG.
$\overline{\Delta H}$	=	Average pressure differential across the orifice meter, IN. WC.
ΔP	=	Velocity pressure of stack gas, IN. WC.
γ	=	Dry test meter correction coefficient, dimensionless
ρ	=	Actual gas density, LB/ACF

METHOD 3
CALCULATION EQUATIONS

$$\%EA = \frac{100(\%O_2 - 0.5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (I - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

METHOD 5
CALCULATION EQUATIONS

$$V_{m(std)} = 17.65 V_m \gamma \left(\frac{P_{bar} + \overline{\Delta H}/13.6}{T_{m(avg)}} \right)$$

$$V_{w(std)} = 0.0472 V_{Is}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$I = 0.0944 \left(\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (I - B_{ws})} \right)$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_a = \frac{272.3 M_p P_s}{T_{s(avg)} (V_{w(std)} + V_{m(std)})}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_s d$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{\theta A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

CALCULATION EQUATIONS

METHOD 6

$$V_{std} = 17.64 \frac{V_m P_b \gamma}{T_m} \text{ (MIDGET IMPINGER VERSION)}$$

$$V_{std} = \frac{17.64 V_m (P_b + \frac{\Delta H}{13.6}) \gamma}{T_m} \text{ (LARGE IMPINGER VERSION)}$$

$$MEQ = (V_i - V_d) N \left(\frac{V_{soln}}{V_a} \right) DF$$

$$C_s = \frac{7.06 \times 10^{-3} MEQ}{V_{std}}$$

$$E = \frac{20.90 C_s F_d}{20.90 - \bar{B}'_{O_2}} = \frac{F_c C_s}{\bar{B}'_{CO_2}}$$

$$C_s \text{ (MG/DSCM)} = 1.60186 \times 10^7 C_s$$

$$C_s \text{ (GR/DSCF)} = 7000 C_s$$

$$C_s \text{ (ppm, dry)} = 6.02119 \times 10^6 C_s$$

$$C_s \text{ (ppm, wet)} = 6.02119 \times 10^6 C_s \left(1 - \frac{MC}{100} \right)$$

GASTACK\WP\METHODS\EQ.M6

SYMBOLS

\bar{B}_{O_2}	=	Average oxygen content in flue gas, % v/v, dry
\bar{B}_{CO_2}	=	Average carbon dioxide content in flue gas, % v/v, dry
C_s	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, LB/DSCF
C_s (GR/DSCF)	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, GR/DSCF
C_s (MG/DSCM)	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, MG/DSCM
DF	=	Dilution Factor
E	=	Emission factor, LB of $SO_2/10^6$ BTU
F _d	=	Dry oxygen F-Factor for given fuel type, DSCF/ 10^6 BTU
F _c	=	Carbon dioxide F-Factor for given fuel type, DSCF/ 10^6 BTU
ΔH	=	Average pressure drop across calibrated orifice. IN. W.C.
γ	=	Dry test meter correction factor, dimensionless
MC	=	Moisture content of flue gas, % v/v
MEQ	=	Total milliequivalents of SO_2 in gas sample
N	=	Normality of barium perchlorate titrant
P_b	=	Barometric pressure at the dry gas meter, IN. HG.
C_s (ppm-dry)	=	Concentration of sulfur dioxide in flue gas, dry basis, (v/v), ppm
C_s (ppm-wet)	=	Concentration of sulfur dioxide in flue gas, wet basis, (v/v), ppm
T_m	=	Absolute average dry gas meter temperature, °R
V_a	=	Volume of sample aliquot titrated, cc
V_m	=	Dry gas volume as measured by the dry gas meter, DCF
V_{std}	=	Dry gas volume as measured by the dry gas meter, corrected to standard conditions (at 68 °F and 1 atmosphere), DSCF

012694-GASTACK\WP\METHODS\EQ.M6(2)

- V_{soln} = Total volume of the solution in which the sulfur dioxide sample is contained, cc
- V_t = Volume of barium perchlorate titrant used for the sample, cc (average of replicate titrations)
- V_{tb} = Volume of barium perchlorate titrant used for the blank, cc

CALCULATION EQUATIONS

METHOD 7

$$V_{m(std)} = 17.64 (V_f - 25) \left[\frac{P_f}{T_f} - \frac{P_i}{T_i} \right]$$

$$C_s = 6.243 \times 10^{-5} \frac{M}{V_{m(std)}}$$

$$E = \frac{2090 C_s F}{20.9 - \bar{B}'_{O_2}}$$

$$C_s (GR/DSCF) = 7000 C_s$$

$$C_s (MG/DSCM) = 1.60186 \times 10^7 C_s$$

$$C_s (ppm-dry) = 8.37552 \times 10^6 C_s$$

$$C_s (ppm-3\% O_2) = 8.37552 \times 10^6 C_s \left\{ 1 + \left[\frac{\bar{B}'_{O_2} - 3}{20.9 - \bar{B}'_{O_2}} \right] \right\}$$

$$C_s (ppm-wet) = 8.37552 \times 10^6 C_s \left(1 - \frac{MC}{100} \right)$$

SYMBOLS

$\bar{B} O_2$	=	Average oxygen content in flue gas, % v/v
C_s	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, LB/DSCF
C_s (GR/DSCF)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, GR/DSCF
C_s (MG/DSCM)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, MG/DSCM
E	=	Emission factor, LB/10 ⁶ BTU
F	=	F-Factor for given fuel type, DSCF/10 ⁴ BTU
M	=	Mass of nitrogen oxides as nitrogen dioxide in gas sample, ug
MC	≈	Moisture content of flue gas, %
P_f	=	Final absolute pressure in flask, IN. HG
P_i	=	Initial absolute pressure in flask, IN. HG
C_s (ppm-dry)	=	Concentration of nitrogen oxides in flue gas, dry basis, (v/v), ppm
C_s (ppm-3% O ₂)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to 3% O ₂ , (v/v) ppm
C_s (ppm-wet)	=	Concentration of nitrogen oxides in flue gas, wet basis, (v/v), ppm
T_f	≈	Final absolute temperature in flask, °R
T_i	=	Initial absolute temperature in flask, °R
V_f	=	Volume of flask and valve, cc
$V_{m(std)}$	=	Sample volume at standard conditions, dry basis, cc

G:\STACK\WPMETHODS\EQ.M7

CALCULATION EQUATIONS

METHOD 10

$$CO\text{-}PPM\text{-}DRY = CO_{CO_2} - \text{free, dry, avg} (1 - CO_{2,d}/100)$$

$$CO\text{-}PPM\text{-}WET = CO\text{-}PPM\text{-}DRY (1 - MC/100)$$

$$GR/DSCF = 5.0885 \times 10^{-4} (CO\text{-}PPM\text{-}DRY)$$

$$mg/dscm = 1.165 (CO\text{-}PPM\text{-}DRY)$$

$$\dot{m} = 8.5714 \times 10^{-3} (GR/DSCF) (Q_{s,d})$$

$$E = \frac{2.9857 \times 10^{-3} F_d (GR/DSCF)}{20.9 - O_{2,d}}$$

where:

$CO_{CO_2} - \text{free, dry, avg}$

= average of two determinations of carbon monoxide on a dry, CO_2 - free integrated flue gas sample reported in ppm by volume

$CO_{2,d}$

= carbon dioxide concentration of flue gas on a dry percent by volume basis

$O_{2,d}$

= oxygen concentration of flue gas on a dry percent by volume basis

MC	=	moisture content of flue gas on a percent by volume basis
CO·PPM·DRY	=	carbon monoxide concentration in ppm by volume on a dry basis
CO·PPM·WET	=	carbon monoxide concentration in ppm by volume on a wet or actual basis
GR/DSCF	=	concentration of carbon monoxide in flue gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
mg/dscm	=	concentration of carbon monoxide in flue gas on a milligrams per dry standard cubic meter basis (60 °F, 29.92 IN. HG.)
\dot{m}	=	emissions or mass rate of carbon monoxide on a LB/HR basis
$Q_{s,d}$	=	volumetric flow rate of flue gas in dry standard cubic feet per minute
E	=	emission factor of carbon monoxide in pounds of carbon monoxide emitted per million BTU heat input (LB/MMBTU)
F_d	=	F-Factor of respective fuel in dry standard cubic feet of exhaust gas at 0% oxygen per million BTU of heat input (DSCF/MMBTU)

METHOD 25A

Total Gaseous Organics Calculation Equation

GR C/SCF = 2.180×10^{-4} (ppm, w)

GR C/DSCF = 2.180×10^{-4} (ppm, w)/(1-MC/100)

LB C/HR = 8.5714×10^{-3} (GR/DSCF) (DSCFM)

where:

GR C/SCF = grains of total gaseous organics as carbon per actual (wet) standard cubic foot

GR C/DSCF = grains of total gaseous organics as carbon per dry standard cubic foot

LB C/HR = pounds of total gaseous organics as carbon emitted per hour

Note 1: The Rattfisch Model RS 55 Heated FID Analyzer as normally operated with a heated filter, sample line and heated detector oven gives ppm, w.

Note 2: ppm, C = ppm as carbon = 3(ppm propane)

CALCULATION EQUATIONS

Gas Chromatographic Method for Phenol in Air

$$\text{PPM-DRY} = \frac{9.03 \times 10^{-3} m}{V_{\text{std}}}$$

$$\text{PPM-WET} = \text{PPM-DRY} (1-\text{MC}/100)$$

$$\text{GR/DSCF} = 1.709 \times 10^{-3} (\text{PPM-DRY})$$

$$\text{mg/dscm} = 3.913 (\text{PPM-DRY})$$

$$m = 8.5714 \times 10^{-3} (\text{GR/DSCF}) (Q_{s,d})$$

where:

PPM-DRY = concentration of phenol in gas in parts per million by volume on a dry basis

PPM-WET = concentration of phenol in gas in parts per million by volume on an actual or wet basis

MC = moisture content of gas on a percent by volume basis

GR/DSCF = concentration of phenol in gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)

m = emission or mass rate of phenol in pounds per hour (LB/HR)

$Q_{s,d}$ = volumetric flow rate of stack gas in dry standard cubic feet per minute (DSCFM)

030994-G:STACK\WPMETHODSIS-EQ.01

CALCULATION EQUATIONS

Chromotropic Acid Method for Formaldehyde

$$m_t = \frac{m_a V_{soln}}{V_{aliqu}}$$

where:

m_t	=	mass of formaldehyde in total sample in ug
m_a	=	mass of formaldehyde in aliquot in ug
V_{soln}	=	volume of total sample in cc (500 cc normally)
V_{aliqu}	=	volume of aliquot taken for analysis in cc
PPM·DRY	=	$\frac{0.0283 m_t}{V_{std}}$
PPM·WET	=	PPM·DRY (1-MC/100)
GR/DSCF	=	5.45×10^{-4} (PPM·DRY)
mg/dscm	=	1.249 (PPM·DRY)
\dot{m}	=	8.5714×10^{-3} (GR/DSCF) ($Q_{g,d}$)

where:

PPM·DRY	=	concentration of formaldehyde in parts per million by volume on a dry basis
PPM·WET	=	concentration of formaldehyde in parts per million by volume on an actual or wet basis
MC	=	moisture content of gas on a percent by volume basis
GR/DSCF	=	concentration of formaldehyde in gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
\dot{m}	=	emission or mass rate of formaldehyde in pounds per hour (LB/HR)
V_{std}	=	dry gas volume as measured by the dry gas meter, corrected to standard conditions (at 68 °F and 1 atmosphere) DSCF


031894-G:STACK\WPMETHODS-EQ.03

Concentration Calculation Equations for MDI

1. Structure:	2. Molecular weight: <u>250.26</u> g/g-mole
<p>3. Mass/volume Concentration:</p> $C_{ug/Nm^3} = \frac{35.314 \text{ m}}{V_{std}}$ <p>where m = Total mass of <u>MDI</u> in sample in micrograms (ug), and</p> <p>Vstd = Total volume of exhaust gas or air sampled in dry standard cubic feet (DSCF).</p>	
<p>4. Volume/volume Concentration:</p> $C_{ppmv} = \left(\frac{24.054 \mu l}{250.26 \mu g} \right) \left(\frac{1/Nm^3}{1000 L} \right) \left(\frac{35.314 m}{V_{std}} \right)$ $C_{ppmv} = (9.612 \times 10^{-5}) C_{ug/Nm^3}$	
<p>5. Notes: * see Excel spreadsheet: G:\STACK\EXCEL\TEMPLATE\MDI.TEM</p>	
Derived by: <u>Shari P.</u>	Date: <u>4-27-95</u>

APPENDIX L

SAMPLING TRAIN CALIBRATION DATA



EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP SAGOLA Date 7-24-96
Operator S. BAINVILLE Module No. 4

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 24.31 in.Hg $\theta =$.9957 $\Delta H@$ 1.78 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(933.00)		
2.5	934.87	71	64
5.0	936.75	73	68
7.5	938.65	73	68
10	940.66	74	69
	$V_m = 7.66$	$Avg(t_m) = 70$	°F

Calculate Y_{m} as follows:

$$Y_{m} = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{m} = \frac{1.786}{(.9957)(7.66)} \left[\frac{(70) + 460}{(24.31)} \right]^{0.5}$$

$$Y_{m} = \underline{1.013}$$

If Y_{m} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job L.P. Sagola Date 7-22-96
Operator EJ Module No. 5

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.32 in.Hg $\theta =$ 1.0032 $\Delta H@$ 1.73 in.WC

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	<u>356.50</u>		
2.5	<u>358.49</u>	<u>93</u>	<u>89</u>
5.0	<u>360.46</u>	<u>95</u>	<u>89</u>
7.5	<u>362.45</u>	<u>97</u>	<u>90</u>
10	<u>364.44</u>	<u>98</u>	<u>91</u>
	$V_m =$ <u>7.94</u>	$Avg(t_m) =$ <u>92.75</u>	$^{\circ}F$

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_s} \right]^{0.5}$$

$$Y_m = \frac{1.786}{(1.0032)(7.94)} \left[\frac{(92.75) + 460}{(28.32)} \right]^{0.5}$$

$$Y_m = \underline{\underline{0.991}}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP/Sagola, MI Date 7-23-96
 Operator D. Hullemann Module No. 5

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.33 in.Hg $\theta =$ 1.0056 $\Delta H@$ 1.80 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(<u>929.60</u>)		
2.5	<u>931.55</u>	<u>66</u>	<u>63</u>
5.0	<u>933.47</u>	<u>68</u>	<u>63</u>
7.5	<u>935.42</u>	<u>72</u>	<u>64</u>
10	<u>937.35</u>	<u>74</u>	<u>65</u>
	$V_m =$ <u>7.75</u>	$Avg(t_m) =$ <u>67.12</u>	$^{\circ}F$

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)^{1.05}}{P_b} \right]$$

$$Y_m = \frac{1.786}{(1.0056)(7.75)} \left[\frac{(67.12 + 460)^{1.05}}{(28.33)} \right]$$

$$Y_m = \underline{\underline{.99}}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job L.P. / Sagola, MI Date 7-23-96
 Operator M. Kachler Module No. 10

Instructions:

Operate the control module at a flow rate equal to $\Delta H @$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.35 in.Hg $\theta =$.9973 $\Delta H @$ 1.93 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(529.00)		
2.5	530.98	70	70
5.0	532.97	70	70
7.5	534.95	72	70
10	536.93	74	70
	$V_m = 7.93$	$Avg(t_m) = 70.75$	°F

Calculate Y_{m} as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{1.05}$$

$$Y_m = \frac{1.786}{(.9973)(7.93)} \left[\frac{(70.75) + 460}{(28.35)} \right]^{1.05}$$

$$Y_m = \underline{.977}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

INTERPOLL LABORATORIES, INC.
(612) 786-6020

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job L.P. / Sagala, MI Date 7-21-96
 Operator M. Kachler Module No. 10

Instructions:

Operate the control module at a flow rate equal to $\Delta H @$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.31 in.Hg $\theta =$.9973 $\Delta H @$ 1.93 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(840.60)		
2.5	842.58	76	77
5.0	844.53	80	77
7.5	846.50	83	77
10	848.39	85	77
	$V_m =$ <u>7.79</u>	$Avg(t_m) =$ <u>79.25</u> °F	

Calculate Y_{cm} as follows:

$$Y_{cm} = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cm} = \frac{1.786}{(.9973)(7.79)} \left[\frac{(79.25) + 460}{(28.31)} \right]^{0.5}$$

$$Y_{cm} = \underline{1.003}$$

If Y_{cm} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

INTERPOLL LABORATORIES, INC.
(612) 786-6020

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job L.P. / Sagala, MI Date 7-25-96
 Operator M. Kaehler Module No. 10

Instructions:

Operate the control module at a flow rate equal to $\Delta H @$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.41 in.Hg $\theta =$.9973 $\Delta H @$ 1.93 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(8.40)		
2.5	10.43	77	77
5.0	12.33	78	77
7.5	14.26	80	77
10	16.18	81	77
	$V_m =$ <u>7.78</u>	$\bar{Avg}(t_m) =$ <u>78.00</u> °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(.9973)(7.78)} \left[\frac{(78.00) + 460}{(29.41)} \right]^{0.5}$$

$$Y_{cn} = \underline{1.001}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP/Sample Date 7-22-96
Operator S. F. Lutz Module No. 13

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.33 in.Hg $\theta =$ 1.0029 $\Delta H@$ 1.84 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(702.50)		
2.5	704.45	88	88
5.0	706.36	91	88
7.5	708.33	93	88
10	710.24	96	88
	$V_m = 7.74$	$Avg(t_m) = 90$	°F

Calculate Y_{cm} as follows:

$$Y_{cm} = \frac{1.786}{\theta V_m} \left[\frac{(t_m - 460)}{P_s} \right]^{0.5}$$

$$Y_{cm} = \frac{1.786}{() ()} \left[\frac{() + 460}{()} \right]^{0.5}$$

$$Y_{cm} = \underline{1.01377}$$

If Y_{cm} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP/SAGOLA Date 7-23-96
Operator J.B Module No. 15

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 28.31 in.Hg $\theta =$ 19964 $\Delta H@$ 1.79 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(519.21)		
2.5	521.12	68	68
3.0	523.04	69	69
7.5	524.95	71	70
10	526.87	72	71
	$V_m = 526.87$	Avg(t_m) = 70	°F

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

234001675

$$Y_m = \frac{1.786}{() ()} \left[\frac{() + 460}{()} \right]^{0.5}$$

$$Y_m = \underline{1.012}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No. : 4 (Rockwell Dry Test Meter Serial No. 964552)

Date of Last Calibration: June 28, 1996

Calibration Technician: L. Hansen

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
July 24, 1996	6-8024	933.00	1453.77	520.77	520.77

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No. : 5 (Rockwell Dry Test Meter Serial No. 949230)

Date of Last Calibration: April 23, 1996

Calibration Technician: S. Fjelsta

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
July 16, 1996	6-7992	385.00	929.05	544.05	544.05
July 23, 1996	6-8024	929.60	1278.95	349.35	893.40

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No. : 10 (Rockwell Dry Test Meter Serial No. 1334112)

Date of Last Calibration: June 7, 1996

Calibration Technician: L. Hansen

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/job (cu. ft.)	Total Volume* (cu. ft.)
June 20, 1996	6-7863	493.20	500.78	7.58	7.58
July 23, 1996	6-8024	529.00	1320.30	791.30	798.88

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No. : 13 (Rockwell Dry Test Meter Serial No. 1334119)

Date of Last Calibration: March 25, 1996
Calibration Technician: E. Trowbridge
Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
July 22, 1996	6-8024	702.50	1092.18	389.68	389.68

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No. : 14 (Rockwell Dry Test Meter Serial No. 1334123)

Date of Last Calibration: May 10, 1996

Calibration Technician: S. Fjelsta

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/job (cu. ft.)	Total Volume* (cu. ft.)
July 25, 1996	6-8024	979.90	1125.76	145.86	145.86

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No. : 15 (Rockwell Dry Test Meter Serial No. 1334118)

Date of Last Calibration: March 26, 1996

Calibration Technician: E. Trowbridge

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
April 11, 1996	6-7558	336.01	439.73	103.72	381.83
April 16, 1996	6-7588	449.04	765.54	316.50	698.33
May 02, 1996	6-7648	787.00	903.40	116.40	814.73
June 24, 1996	6-7870	907.00	1044.88	137.88	952.61
June 27, 1996	6-7908	1051.50	1233.85	182.35	1134.96
July 11, 1996	6-7959	1253.00	1384.97	131.97	1266.93
July 23, 1996	6-8024	1393.33	1698.75	305.42	1572.35

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: August 5, 1996

Meter Box No.: 17 (Rockwell Dry Test Meter Serial No. 1334113)

Date of Last Calibration: February 29, 1996
Calibration Technician: S. Kelker
Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
July 23, 1996	6-8024	356.50	719.98	363.48	363.48

* Total volume through meter since last calibration.

Meter Calibration Sheet EPA/Method 5

Date 6/28/96 Control Module No. 4
 Bar. Press. 29.03 IN.HG Serial No. DTM 964553
 Wet Test Meter No. AL-20 Technician SK LLI

ΔH (IN.WC)	Nominal	Actual	Gas Volume Wet Test Meter (ft³)	* Cal. Index φ (%)	* Diff. Wet Test Meter ΔP _w (IN.WC.)	Gas Temperatures			Time θ (Min/Sec)	Meter Coeff.	Orifice Const.	C _f
						Wet Test T _w (°F)	Dry Test T _d (°F)	T _{db} (°F)				
0.5	0.5	0.5	908.91	99.05	0.01	72	79	76	4/35	1.0025	1.74	
1.2	1.2	1.2	911.93	99.91	0.025	72	80	77	4/51	0.9949	1.80	
2.0	2.0	2.0	904.86	99.93	0.055	72	80	76	3/44	0.9921	1.78	
3.1	3.3	3.3	915.58	100.00	0.09	72	84	78	4/52	0.9943	1.79	
4.7	4.7	4.7	922.05	100.02	0.12	72	88	80	4/06	0.9945	1.79	
									AVG	0.9957	1.78	

Positive leak check performed by L. Hansen Meter was not in tolerance
 Meter was in tolerance Meter was not in tolerance
 Approved by [Signature] Date 7/2/96
 *Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

Meter Calibration Sheet EPA/Method 5

Date: 4-23-96 Control Module No. 5
 Bar. Press. 29.31 IN.HG Serial No. DTM 949230
 Wet Test Meter No. AL-20 Technician SF

Nominal ΔP (IN.WC)	Actual ΔP (IN.WC)	Gas Volume Wet Test Meter (ft ³)	Cal. Index ϕ (%)	Diff. Wet Test Meter ΔP_w (IN.WC.)	Gas Volume Dry Test Meter (ft ³)		Wet Test t_w ($^{\circ}F$)	Gas Temperatures		Time θ (Min/Sec)	Meter Coeff.	Orifice Const.	C_1
					V_{dt}	V_{dt}		t_w ($^{\circ}F$)	Dry Test t_w ($^{\circ}F$)				
0.5	0.5	2	99.85	0.01	353.86	355.89	65	86	71	5/02	1.0078	1.758	
1.2	1.2	3	99.91	0.025	356.41	359.48	65	90	72	4/53	1.0030	1.755	
2.0	2.0	3	99.93	0.055	351.79	362.86	65	93	73	3/51	1.0048	1.811	
3.3	3.3	5	100.00	0.09	363.78	368.86	65	90	75	5/01	1.0085	1.825	
4.7	4.7	5	100.02	0.12	369.37	374.48	65	95	75	4/15	1.0038	1.857	
											1.0056	1.801	AVB

Positive leak check performed by SF : readjusted linkage
 Meter was in tolerance : changed dry test meter
 Approved by [Signature] Date 5/7/96
 *Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co. 031794-G:15TACKWPAFORMS5-0102RR

Meter Calibration Sheet EPA/Method 5

Date 6-7-96 Control Module No. 10
 Bar. Press. 29.13 IN.HG Serial No. DTM 1334112
 Wet Test Meter No. AL-20 Technician L. Hansen

Nominal	Actual	Gas Volume Wet Test Meter (ft ³)	Cal. Index ϕ (%)	Diff. Wet Test Meter ΔP_w (IN.WC.)	Gas Volume Dry Test Meter (ft ³)		Gas Temperatures			Time θ (Min/Sec)	Meter Coeff.	Orifice Const. $\Delta F @$	C ₁
					V _{dt}	V _{dt}	Wet Test T _w (°F)	Dry Test T _d (°F)	T _{db} (°F)				
0.5	0.5	2	99.85	0.01	485.725	487.750	68	82	72	5:06	1.002	1.84	
1.2	1.2	3	99.91	0.025	481.680	484.720	68	82	72	5:03	.9997	1.83	
2.0	2	3	99.93	0.055	464.595	467.630	68	75	69	3:56	.9869	1.96	
3.3	3.3	5	100.00	0.09	468.635	473.650	68	75	70	5:06	.9970	1.96	
4.7	4.7	5	100.02	0.12	474.650	479.661	68	81	71	4:18	1.001	1.97	
										AVG	.9973	1.93	

Positive leak check performed by L. Hansen Meter was not in tolerance
 Meter was in tolerance Meter was not in tolerance
 Approved by [Signature] Date 7/2/96
 *Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.




INCORPORATED A BTR Company
805 Liberty Blvd., DuBois, PA 15801

TEST METER PERFORMANCE

METER SIZE: R-275 STD
SERIAL NUMBER: 1334119
CUSTOMER NAME: CONTROLS & METERS INC
ORDER NUMBER: 613-73640-001

*Meter Box #
13*

P E R C E N T E R R O R (%)



CERTIFIED AS TO
ACTUAL TEST DATA
J.A. Danks
DATE: July 7, 1992

CURVE NUMBER 9

Meter Calibration Sheet EPA/Method 5

Date 5-10-96 Control Module No. 14
 Bar. Press. 29.18 IN.HG Serial No. DIM 1334123
 Wet Test Meter No. AL-20 Technician SF

Nominal ΔH (IN.WC)	Actual	Gas Volume Wet Test Meter (ft ³)	Cal. Index ϕ (%)	Diff. Wet Test Meter ΔP_w (IN.WC)	Gas Volume Dry Test Meter (ft ³)		Gas Temperatures			Time θ (Min/Sec)	Meter Coeff.	Orifice Const.	C ₁
					V _u	V _m	Wet Test T _w (°F)	Dry Test T _d (°F)	T _u (°F)				
0.5	0.5	2	99.85	0.01	956.03	958.01	68	74	66	4/55	1.0111	1.732	
1.2	1.2	3	99.91	0.025	959.21	962.24	68	82	67	4/54	.99830	1.817	
2.0	2.0	3	99.93	0.055	962.75	965.80	68	85	68	3/49	.99360	1.830	
3.3	3.3	5	100.00	0.09	966.84	971.91	68	89	69	4/59	.99821	1.842	
4.7	4.7	5	100.02	0.12	972.75	977.78	68	92	70	4/12	1.0064	1.856	
											1.00152	1.815	
											Avg		

Positive leak check performed by SF
 Meter was in tolerance
 Approved by [Signature]
 *Based on Al-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

Meter was not in tolerance
 Meter was not in tolerance
 Date 5/14/96
 readjusted linkage
 changed dry test meter



INCORPORATED A BTR Company
805 Liberty Blvd., DuBois, PA 15801

TEST METER PERFORMANCE

METER SIZE: R-275 STD

SERIAL NUMBER: 1334-123


CUSTOMER NAME: CONTROLS & METERS, INC.

ORDER NUMBER: G13-73640-001

Meter Box #
14

CURVE NUMBER 12

P E R C E N T E R R O R (%)



CERTIFIED AS TO
ACTUAL TEST DATA

J.A. Conklin

DATE: July 7, 1992

FLOWRATE PERCENT OF CAPACITY, AIR (%)

Meter Calibration Sheet EPA/Method 5

Date: 3-26-96
Bar. Press. 29.49
Wet Test Meter No. AL-20

Control Module No. 15
Serial No. DTM 1334118
Technician E. P. Schaefer

Alt (ft-WC)	Gas Volume Wet Test Meter (ft ³)	Cal. Index ϕ (%)	Diff. Wet Test Meter ΔP_w (IN.WC.)	Gas Volume Dry Test Meter (ft ³)		Wet Test T_w (°F)	Gas Temperatures		Time θ (Min/Sec)	Meter Coeff.	Coinc. Const. $\Delta H @$	G	
				V _{in}	V _{dr}		Dry Test T_d (°F)	T_{in} (°F)					
0.5	2	99.85	0.01	302.000	304.030	65	74	65	5/00	9909	1.75		
1.2	3	99.91	0.025	304.500	307.933	65	78	66	4/53	9983	1.77		
2.0	1	99.93	0.055	298.500	301.531	65	73	65	3/49	9985	1.82		
3.3	5	100.00	0.09	305.000	313.060	65	84	67	4/56	9994	1.78		
4.7	5	100.02	0.12	313.500	318.556	65	87	68	4/12	1.0018	1.83		
									1000				
									AVG		9904	1.79	

Meter was not in tolerance readjusted linkage
Meter was not in tolerance changed dry test meter
Date 3/19/96

Positive leak check performed by E.P.
Meter was in tolerance
Approved by E.P. Schaefer

*Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.



INCORPORATED A BTR Company
805 Liberty Blvd., DuBois, PA 15801

CURVE NUMBER 11

Meter Box #
15

TEST METER PERFORMANCE

METER SIZE: R-275 STD
SERIAL NUMBER: 1334122
CUSTOMER NAME: CONTROLS & METERS, INC.
ORDER NUMBER: 913-73640-001

CERTIFIED AS TO
ACTUAL TEST DATA
J.A. COBLE
DATE: July 7, 1992

P E R C E N T
E R R O R (%)

+1/2

0

-1/2

0

20


40

60

80

100

FLOWRATE PERCENT OF CAPACITY, AIR (%)



MET TEST METER

DIFFERENTIAL INCHES H2O

Calibrated with a 10 ft. American DeJ
 Prover, Serial No. 3157. Traceable to
 the Bureau of Standards. Reference No.
 524906B, PI-TAPE.

AL-20 American Met Test Meter
 Serial No. 2717
 Stainless Steel w/Removable Back
 Calibrated w/Saturated Air
 Water Temp. 74° F.
 Air Temp. 74° F.
 Inlet Pressure 2" H2O Constant
 Calibration Rate: 60 CFH Per/Hr.
 Capacity Rate: 120 CFH Per/Hr.
 Restricted Outlet for Rate Deviation

PROOF

PROOF

CORRECT VOLUME INDEX READING x PROOF = 100

DATA BANK

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-25-96
Technician: Mark Kaehler
Nozzle Number: 1-5

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.181
2	0.181
3	0.181
Average	0.181

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-23-96
Technician: Scott Fjelsta
Nozzle Number: 4-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.189
2	0.189
3	0.189
Average	0.189

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-23-96
Technician: Duane Van Hoever
Nozzle Number: 6-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.178
2	0.179
3	0.181
Average	0.179

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-23-96
Technician: Ed Juers
Nozzle Number: 8-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.189
2	0.189
3	0.188
Average	0.189

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-23-96
Technician: Jamie Bainville
Nozzle Number: 5-2

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.245
2	0.244
3	0.245
Average	0.245

Nozzle Calibration Data Sheet

Date of Calibration: 7-23-96
Technician: Jamie Bainville
Nozzle Number: Glass

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.270
2	0.270
3	0.270
Average	0.270

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-23-96
Technician: Mark Kaehler
Nozzle Number: 2-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.188
2	0.188
3	0.187
Average	0.188

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-24-96
Technician: Mark Kaehler
Nozzle Number: 6-4

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.225
2	0.227
3	0.228
Average	0.227

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-24-96
Technician: Mark Kaehler
Nozzle Number: 2-4

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.252
2	0.250
3	0.252
Average	0.251

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 7-25-96
Technician: Mark Kaehler
Nozzle Number: G-4

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.240
2	0.241
3	0.241
Average	0.241

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor

Model

Range

Date of Calibration

Method of Calibration:

WAUCATLAK

DM23XT

0-1700 °F

3-13-96

Serial Number

50610065

Thermocouple Type

K

Technician

E. BRUNVILLE

PDT No.

MULTIMETER 50610065

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	0	0	
100	100	95	5	106.89
200	200	199	1	0.15
300	300	297	3	0.39
400	400	395	5	0.58
500	500	494	6	0.63
600	600	597	3	0.28
700	700	698	2	0.02 0.17
800	800	802	2	.16
900	900	905	5	.37
1000	1000	1010	10	.68
1100	1100	1114	14	.90
1200	1200	1220	20	1.20
1300	1300	1321	21	1.19
1400	1400	1425	25	1.34
1500	1500	1523	23	1.77
1600	1600	1625	25	1.21
1700	1700	1720	20	.93
1800	1800	1818	18	.80
1900	1900	1910	10	.42
2000	OF	OF	OF	OF
2100	OF	OF	OF	OF
Averages:			10.9	.673

OF = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

Unit in tolerance

Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:STACKWPFFORMS5-433

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor

Omega

Model

14HEP

Serial Number

735X1495

Range

0 - 2100 °F

Thermocouple Type

K

Date of Calibration

7-11-96

Technician

D. Hulleman

Method of Calibration:

PDT No.

#31

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add \pm degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-3	3	0.65
100	100	97	3	0.53
200	200	200	0	0.00
300	300	298	2	0.26
400	400	397	3	0.35
500	500	498	2	0.21
600	600	598	2	0.19
700	700	698	2	0.17
800	800	800	0	0.00
900	900	899	1	0.07
1000	1000	999	1	0.07
1100	1100	1097	3	0.19
1200	1200	1199	1	0.06
1300	1300	1296	4	0.23
1400	1400	1400	0	0.00
1500	1500	1498	2	0.10
1600	1600	1601	1	0.05
1700	1700	1699	1	0.04
1800	1800	1800	0	0.00
1900	1900	1899	1	0.04
2000	2000	2000	0	0.00
2100	2100	2095	5	0.20
		Averages:		

OF = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

Unit in tolerance

Unit was not in tolerance: recalibrated - See new calibration sheet.

Temperature Measurement Device Calibration Sheet

Unit Under Test: 35
 Vendor: OMEGA
 Model: HH81 Serial Number: 74JX0332
 Range: 0 - 2100 °F Thermocouple Type: K
 Date of Calibration: 2/20/96 Technician: MARK PETERSEN
 Method of Calibration: PDT No. 35

Comparison against ASTM mercury in glass thermometer using a thermostated and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
 Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			at (°F)	(%)
0	0	-3	3	0.65
100	100	98	2	0.36
200	200	200	0	0
300	300	298	2	0.26
400	400	398	2	0.23
500	500	499	1	0.10
600	600	600	0	0
700	700	699	1	0.09
800	800	801	1	0.08
900	900	900	0	0
1000	1000	1000	0	0
1100	1100	1100	0	0
1200	1200	1201	1	0.06
1300	1300	1299	1	0.06
1400	1400	1402	2	0.11
1500	1500	1500	0	0
1600	1600	1603	3	0.15
1700	1700	1701	1	0.05
1800	1800	1803	3	0.13
1900	1900	1901	1	0.04
2000	2000	2001	1	0.04
2100	2100	2099	1	0.04
		Averages:	1.18	0.111

OF - off scale response by unit under test (°F)

$$\% \text{ dev} = 100 \Delta t / (460 + t)$$

☐ Unit in tolerance

☐ Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-GASTACK\WP\FORMS\5-433

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor

Model

Range

Date of Calibration

Method of Calibration:

Omega

HM 81

0-2100

4-8-96

Serial Number

Thermocouple Type

Technician

PDT No.

743 X 1119

K

SF

40

Comparison against ASTM mercury in glass thermometer using a thermostated and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.

Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-4	4	0.869
100	100	97	3	0.536
200	200	199	1	0.152
300	300	297	3	0.395
400	400	397	3	0.349
500	500	498	2	0.208
600	600	599	1	0.0943
700	700	698	2	0.172
800	800	800	0	0.000
900	900	899	1	0.0735
1000	1000	1000	0	0.000
1100	1100	1098	2	0.128
1200	1200	1201	1	0.0602
1300	1300	1298	2	0.114
1400	1400	1401	1	0.0538
1500	1500	1500	0	0.000
1600	1600	1602	2	0.0971
1700	1700	1701	1	0.0463
1800	1800	1803	3	0.133
1900	1900	1901	1	0.0424
2000	2000	2004	1	0.0407
2100	2100	2099	1	0.0391
		Averages:	1.59	0.101

OF = off scale response by unit under test (°F)

Unit in tolerance

% dev = $100 \Delta t / (460 + t)$

Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:STACKIWPFORMS-433

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor: Omega
 Model: HH 81
 Range: -160 - 1372 °C
 Date of Calibration: 5-20-96
 Method of Calibration: Comparison against ASTM mercury in glass thermometer using a thermostated and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
 Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Serial Number: 745X1327
 Thermocouple Type: K
 Technician: ES
 PDT No.: 72

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-1	1	.22
100	100	100	0	0
200	200	202	2	.30
300	300	300	0	0
400	400	400	0	0
500	500	500	0	0
600	600	602	2	.19
700	700	700	0	0
800	800	803	3	.24
900	900	902	2	.15
1000	1000	1003	3	.21
1100	1100	1100	0	0
1200	1200	1202	2	.12
1300	1300	1301	1	.06
1400	1400	1404	4	.22
1500	1500	1502	2	.10
1600	1600	1604	4	.19
1700	1700	1703	3	.14
1800	1800	1804	4	.18
1900	1900	1902	2	.08
2000	2000	2003	3	.12
2100	2100	2100	0	0
		Averages:	1.72	.11

OF = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

Unit in tolerance

Unit was not in tolerance: recalibrated - See new calibration sheet.

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor: Omega
 Model: HH81 Serial Number: 74JX1560
 Range: _____ °F Thermocouple Type: K
 Date of Calibration: 7-11-92 Technician: D. Hullemann
 Method of Calibration: PDT No. 45

- Comparison against ASTM mercury in glass thermometer using a thermostated and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δ (°F)	(%)
0	0	-3	3	3.65
100	100	98	2	3.35
200	200	200	0	0.00
300	300	298	2	0.26
400	400	398	2	0.23
500	500	498	2	0.21
600	600	600	0	0.00
700	700	698	2	0.17
800	800	801	1	0.08
900	900	899	1	0.07
1000	1000	1000	0	0.00
1100	1100	1100	0	0.00
1200	1200	1200	0	0.00
1300	1300	1298	2	0.11
1400	1400	1401	1	0.05
1500	1500	1499	1	0.05
1600	1600	1602	2	0.10
1700	1700	1700	0	0.00
1800	1800	1802	2	0.16
1900	1900	1900	0	0.00
2000	2000	2000	0	0.00
2100	2100	2099	1	0.04
		Averages:	1.09	0.11

OF = off scale response by unit under test (°F)

% dev = $100 \Delta / (460 + t)$

Unit in tolerance

Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:STACKWPAFORMS5-433

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor	<u>Omega</u>	Serial Number	_____
Model	<u>HH 81</u>	Thermocouple Type	<u>K</u>
Range	<u>-160 - +1372 °C</u>	Technician	<u>ES</u>
Date of Calibration	<u>5-20-96</u>	PDT No.	<u>47</u>

Method of Calibration:

Comparison against ASTM mercury in glass thermometer using a thermostated and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge. Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	0	0	0
100	100	99	1	.18
200	200	201	1	.15
300	300	299	1	.13
400	400	399	1	.12
500	500	499	1	.10
600	600	600	0	0
700	700	700	0	0
800	800	802	2	.16
900	900	900	0	0
1000	1000	1001	1	.07
1100	1100	1100	0	0
1200	1200	1201	1	.06
1300	1300	1300	0	0
1400	1400	1402	2	.11
1500	1500	1501	1	.05
1600	1600	1604	4	.19
1700	1700	1701	1	.05
1800	1800	1803	3	.13
1900	1900	1901	1	.04
2000	2000	2001	1	.04
2100	2100	2099	1	.04
		Averages:	1.0	.07

OF = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

Unit in tolerance

Unit was not in tolerance: recalibrated - See new calibration sheet.

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 22-4

Pitot tube dimensions:

1. External tubing diameter (D) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z $< .125"$.01
9. W $< .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .760 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-9-84

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 22-5

Pitot tube dimensions:

1. External tubing diameter (D) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z <.125" .02
9. W <.0625" .02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-8-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No 23-5

Pitot tube dimensions:

1. External tubing diameter (D) _____, 3.16 IN.
2. Base to Side A opening plane (P_A) _____, 4.60 IN.
3. Base to Side B opening plane (P_B) _____, 4.60 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z < .125" .02
9. W < .0625" .01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle _____, .760 IN.
11. Pitot to probe sheath _____, 3.0 IN.
12. Pitot to thermocouple (parallel to probe) _____, 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) _____, .760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

2/8-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Probe or Pitot Tube No. 27-5

Pitot tube dimensions:

1. External tubing diameter (D) .312 IN.
2. Base to Side A opening plane (P_A) .4675 IN.
3. Base to Side B opening plane (P_B) .4515 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 410° $0^\circ 35'$
5. $\alpha_2 < 10^\circ$ 410° $0^\circ 35'$

6. $B_1 < 5^\circ$ 45° $0^\circ 0' 30''$
7. $B_2 < 5^\circ$ 45° $0^\circ 50'$

8. Z $< .125''$ $4125''$
9. W $< .0625''$ $40625''$ A $.013''$ B $.001''$

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle $3/4''$.750''
11. Pitot to probe sheath $4 3/8''$ 4.380
12. Pitot to thermocouple (parallel to probe) 3'' 2.956''
13. Pitot to thermocouple (perpendicular to probe) NA

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

8-1-95

Inspected by:

Nancy Blunk

S-Type Pitot Tube Inspection Sheet

Probe or Pitot Tube No 27-10

Pitot tube dimensions:

1. External tubing diameter (D) 3/2 IN.
2. Base to Side A opening plane (P_A) 4.67 IN.
3. Base to Side B opening plane (P_B) 4.64 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ $< 10^\circ$ $2^\circ 5'$
5. $\alpha_2 < 10^\circ$ $< 10^\circ$ $1^\circ 0'$

6. $\beta_1 < 5^\circ$ $< 5^\circ$ $0^\circ 25'$
7. $\beta_2 < 5^\circ$ $< 5^\circ$ $1^\circ 0'$

8. Z $< .125"$ $< .125"$
9. W $< .0625"$ $< .0625"$ A $.019"$ B $.011"$

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle $3/4"$ $.764"$
11. Pitot to probe sheath $4 3/8"$ $4.385"$
12. Pitot to thermocouple (parallel to probe) $3"$ $2.954"$
13. Pitot to thermocouple (perpendicular to probe) NA

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

8-1-95

Inspected by:

Gary Blankens

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. MM5-8

Pitot tube dimensions:

1. External tubing diameter (D) 1.316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 2
7. $B_2 < 5^\circ$ 2

8. Z $< .125"$.02
9. W $< .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle 1.750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-93

Inspected by:

[Signature]

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 10-17-95
Technician R.R.
Mercury Column Barometer No. NOVA-1
Aneroid Barometer No. 560209

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} - P _{bm})
28.91	82	.14	28.77	28.76	.01

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____

BAROMETER HAS BEEN REPAIRED

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 4-8-96
Technician SF
Mercury Column Barometer No. F. 110 ~~20901010~~ Room
Aneroid Barometer No. 20901010

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference ($P_{ba} - P_{bm}$)
<u>29.310</u> 29.310	<u>70</u>	<u>.111</u>	<u>29.199</u>	<u>29.21</u>	<u>0.011</u>

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____
NO

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 7-8-96
Technician E. SVCS
Mercury Column Barometer No. _____
Aneroid Barometer No. 10729004

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} - P _{bm})
28.93	74	.119	28.81	28.91	.1

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____

offset - .119
Slope 0.251

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 7-11-96
Technician Mark Hasbeler
Mercury Column Barometer No. LAB 1
Aneroid Barometer No. 21029004

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} - P _{bm})
29.13	80	.137	29.043	29.05	.007

Has this barometer shown any consistent problems with calibration? Yes No If yes, explain. _____

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 5/9/96
Technician D. Van Hoever
Mercury Column Barometer No. _____
Aneroid Barometer No. DVH'S

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference ($P_{ba} - P_{bm}$)
<u>29.19</u>	<u>69</u>	<u>.109</u>	<u>29.08</u>	<u>29.06</u>	<u>-.02</u>

Has this barometer shown any consistent problems with calibration? Yes No. If yes, explain. _____

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.