

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

#19

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020
FAX: (612) 786-7854

FILE COPY

**RESULTS OF THE JULY 12 - 15, 1994
AIR EMISSION COMPLIANCE TESTS
AT THE LOUISIANA PACIFIC OSB
PLANT IN HAYWARD, WISCONSIN**

Submitted to:

LOUISIANA PACIFIC CORPORATION
Route 8, Box 8263
Hayward, Wisconsin 54843

Attention:

Sue Somers

Approved by:



Daniel J. Despen
Manager
Stationary Source Testing Department

Report Number 4-3366
August 9, 1994
SP/slp

TABLE OF CONTENTS

	ABBREVIATIONS	iii
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	6
3	RESULTS	34
	3.1 Results of Orsat and Moisture Determinations	35
	3.2 Results of Particulate Determinations	46
	3.3 Results of Oxides of Nitrogen Determinations	53
	3.4 Results of Opacity Observations	59
	3.5 Results of Carbon Monoxide Determinations	62
	3.6 Results of Formaldehyde Determinations	69
	3.7 Results of Phenol Determinations	72
	3.8 PAH Sampling Data	75

APPENDICES:

- A - Volumetric Flow Rate Determinations
- B - Location of Test Ports
- C - Line 1 RTO Field Data Sheets
- D - Line 2 RTO Field Data Sheets
- E - Interpoll Laboratories Analytical Results
- F - THC Stripcharts/Data Logger Printouts
- G - Analyzer Specifications
- H - Measurement Systems Performance Specifications
- I - Calibration Gas Certification Sheets
- J - Process Rate Information
- K - Procedures
- L - Calculation Equations
- M - Sampling Train Calibration Data

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.

1 INTRODUCTION

During the Period July 12 - 15, 1994 Interpoll Laboratories personnel conducted air emission compliance tests on the following sources at the Louisiana Pacific Corporation (LP) OSB Plant located in Hayward, Wisconsin.

<u>Source</u>	<u>Parameters</u>
Line 1 Dryer RTO Outlet	PM,NO _x ,VE,CO,CH ₂ O,Benzene,Phenol,PAH's,THC's
Line 1 Surface Dryer RTO Inlet (Primary Cyclone Outlet)	PM,NO _x ,CO,THC's
Line 1 Core Dryer RTO Inlet (Primary Cyclone Outlet)	PM,NO _x ,CO,THC's
Line 2 Dryer RTO Outlet	PM,NO _x ,VE,CO,CH ₂ O,Benzene,Phenol,PAH's,THC's
Line 2 Surface Dryer RTO Inlet (Multicyclone Outlet)	PM,NO _x ,CO,THC's
Line 2 Core Dryer RTO Inlet (Multicyclone Outlet)	PM,NO _x ,CO,THC's

On-site testing was performed by Ed Trowbridge, Ron Rosenthal, Mark Kaehler, Bob Aschenbach, Dennis Marso, Jon Johnson, Jeff Scriptor, and Ken Nuessmeier. Coordination between testing activities and plant operation was provided by Sue Somers, Del Salquist, and Mark Becker of LP, and Gary Geisler of Wheelabrator Huntington Energy Systems. The test was witnessed by Jim Ross and Brad Pyle of the Wisconsin Department of Natural Resources.

The Line 1 Surface and Core Dryers tested are Model 1248T dryers manufactured by MEC Company. Each dryer is equipped with a wood-dust fired McConnell cyclonic suspension burner with a rated heat input capacity of 36 10⁶BTU/HR. Emissions from each dryer are controlled by an electrified filter bed manufactured by E.F.B, Inc. installed in series with a regenerative thermal oxidizer manufactured by Huntington Energy Systems.

Testing on the Line 1 Dryer RTO Outlet was conducted from two test ports oriented at 90 degrees on the stack. These test ports are located 7 stack diameters downstream of the nearest flow disturbance and 5 stack diameters upstream of the stack exit. A 16-point traverse was used to collect the particulate, formaldehyde, and PAH samples. Each traverse point was sampled 4 minutes for a total of 64 minutes per run. A 3-point traverse was used

to collect representative benzene and phenol samples. Each point was sampled for 20 minutes for a total of 60 minutes per run.

Testing at the site referred to as the Line 1 Surface Dryer RTO Inlet was conducted at the outlet of the primary cyclone. The purpose in testing this point was to determine removal efficiencies of the EFB and RTO.

Testing on the Line 1 Surface Dryer RTO Inlet (primary cyclone outlet) was conducted from two test ports oriented at 90 degrees. A 24-point traverse was used to collect the particulate samples. Each traverse point was sampled 2.5 minutes for a total of 60 minutes per run.

Testing at the site referred to as the Line 1 Core Dryer RTO Inlet was conducted at the outlet of the primary cyclone. The purpose in testing this point was to determine removal efficiencies of the EFB and RTO.

Testing on the Line 1 Core Dryer RTO Inlet (primary cyclone outlet) was conducted from two test ports oriented at 90 degrees. A 24-point traverse was used to collect the particulate samples. Each traverse point was sampled 2.5 minutes for a total of 60 minutes per run.

The Line 2 Surface and Core Dryers tested are Model 1248T dryers manufactured by MEC Company. Each dryer is equipped with a wood-dust fired McConnell cyclonic suspension burner with a rated heat input capacity of 36×10^6 BTU/HR. Particulate emissions from each dryer are controlled by a primary cyclone product separator followed by a secondary multicyclone in series with an electrified filter bed also manufactured by E.F.B., Inc. installed in series with a regenerative thermal oxidizer manufactured by Huntington Energy Systems.

Testing on the Line 2 Dryer RTO Outlet was conducted from two test ports oriented at 90 degrees on the stack. These test ports are located 7 stack diameters downstream of the nearest flow disturbance and 5 stack diameters upstream of the stack exit. A 16-point traverse was used to collect the particulate, formaldehyde, and PAH samples. Each traverse point was sampled 4 minutes for a total of 64 minutes per run. A 3-point traverse was used

to collect representative benzene and phenol samples. Each point was sampled for 20 minutes for a total of 60 minutes per run.

Testing at the sites referred to as Line 2 Surface and Core Dryer Inlets was conducted at the outlet of the multicyclones. One goal of this testing program was to determine the efficiency of the total collection system (multicyclones, EFB and RTO) however a suitable test site prior to the multicyclone was not possible. Therefore a site at the multicyclone outlets was used. Total system particulate efficiencies were estimated by adding the multiclone dust catch to the test result.

Testing on the Line 2 Surface Dryer RTO Inlet (multicyclone outlet) was conducted from two test ports oriented at 90 degrees. A 24-point traverse was used to collect the particulate samples. Each traverse point was sampled 2.5 minutes for a total of 60 minutes per run.

Testing on the Line 2 Core Dryer RTO Inlet (multicyclone outlet) was conducted from two test ports oriented at 90 degrees. A 24-point traverse was used to collect the particulate samples. Each traverse point was sampled 2.5 minutes for a total of 60 minutes per run.

Particulate evaluations were performed in accordance with EPA Methods 2-5, CFR Title 40, Part 60, Appendix A (revised July 1, 1993). A preliminary determination of the gas linear velocity profile was made at each test location before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with Wisconsin DNR protocol.

Carbon monoxide and oxides of nitrogen determinations were performed in accordance with Methods 7E and 10. A slip stream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry

gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice which was used to ensure that the flow from the stack exceeds the requirements of the analyzers. A three-way valve on the probe was used to introduce standard gas for the "system bias check".

The analog response of the analyzers was recorded with a strip chart recorder. The analyzer was calibrated with Scott Specialty, National Specialty, and Linde Gases (EPA Protocol 1) and Certified Master standard gases. The instrument was calibrated before and after each run as per EPA Methods 7E and 10. The sample probe was moved through a three-point traverse (1/6, 3/6, 5/6 of the stack diameter) to measure oxides of nitrogen and carbon monoxide concentrations.

Formaldehyde samples were collected using EPA Method 0011 (SW 846 3rd Ed.). The samples were collected isokinetically using a Method 5 sampling train with an aqueous acidic 2,4-dinitrophenylhydrazine absorbing solution and analyzed by high performance liquid chromatography.

Total gaseous hydrocarbon concentrations were determined instrumentally using a Ratfisch Model RS55 heated flame ionization detector (HFID) calibrated against propane in air standards. The THC concentration was continuously monitored by extracting a slipstream of exhaust gas by means of a heated probe and filter holder. A heat-traced teflon line was used to transport the sample gas from the filter holder outlet to the analyzer inlet.

Phenol concentrations were determined from the Press Vent using a Method 5 sampling train with neutral buffered absorbing reagent followed by extraction with methylene chloride and direct analysis by GC/MS with no concentration (EPA Method 8270). The samples were field spiked with 5.33 mg of phenol d5.

Polyaromatic hydrocarbons sampling was conducted using the EPA Modified Method 5 sampling procedure as per EPA Method 0010 SW 846. The four-part sample and field blank were extracted, concentrated to 1000 ul and cleaned up as required (column chromatography as per Interpoll Labs Method II-8904-2 or GPC) prior to final concentration and analysis. The samples were then further concentrated to 100 ul and analyzed in accordance with EPA Method 8270 by HRGC/LRMS using electron impact (EI) with total ion

monitoring (TIM). Quantification was performed using the six standard M-8270 internal standards. Each XAD-2 resin cartridge was field spiked with 20 ug of d₁₀-fluoranthene in order to document overall collection and analytical efficiency and recovery. Analytical accuracy and recovery for extraction and cleanup was documented using the six m-8270-recommended surrogate standards.

Benzene samples were collected in accordance with EPA Method 18 Section 7.4. Charcoal tubes were used for sampling with analysis by GC/FID.

Integrated flue gas samples were extracted simultaneously with each of the above-referenced sampling trains at the dryer test site using a specially designed gas sampling system. Integrated flue gas samples were collected in 44-liter Tedlar bags housed in a protective aluminum container. After sampling was complete, the bags were sealed and returned to the laboratory for Orsat analysis. Prior to sampling, the Tedlar bags are leak checked at 15 IN.HG. vacuum with an in-line rotameter. Bags with any detectable inleakage are discarded. The integrated flue gas samples collected at the Line 1 and Line 2 Core Dryer RTO Inlet test sites were also analyzed for carbon monoxide in accordance with EPA Method 10. (NDIR)

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The results of the air emission compliance tests are summarized in Tables 1 - 16. An overview of the results is presented in the Table below:

PARAMETER **MEASURED**

Line 1 Surface Dryer RTO Inlet (Primary Cyclone Outlet)

Particulate	
..... (GR/DSCF)	0.244
..... (LB/HR)	55
Oxides of Nitrogen	
..... (ppm,d)	40
..... (LB/HR)	7.7
Carbon Monoxide	
..... (ppm,d)	433
..... (LB/HR)	51
Total Hydrocarbons	
..... (ppmC,w)	490
..... (LB/HR)	32

Line 1 Core Dryer RTO Inlet (Primary Cyclone Outlet)

Particulate	
..... (GR/DSCF)	0.255
..... (LB/HR)	51
Oxides of Nitrogen	
..... (ppm,d)	24
..... (LB/HR)	4.1
Carbon Monoxide	
..... (ppm,d)	443
..... (LB/HR)	46
Total Hydrocarbons	
..... (ppmC,w)	339
..... (LB/HR)	21

PARAMETER MEASURED

Line 1 Dryer RTO Outlet

*PM Removal Efficiency** (%) 86
*THC Removal Efficiency** (%) 87

Particulate
 (GR/DSCF) 0.0296
 (LB/HR) 14.8

Opacity (%) 0

Oxides of Nitrogen
 (ppm,d) 29
 (LB/HR) 12

Carbon Monoxide
 (ppm,d) 152
 (LB/HR) 39

Total Hydrocarbons
 (ppmC,w) 49
 (LB/HR) 7.1

Formaldehyde
 (ppm,d) 4.7
 (LB/HR) 1.3

Phenol
 (ppb,d) < 176
 (10³LB/HR) < 148

Benzene
 (ppm,d) 0.067
 (LB/HR) 0.047

* Efficiencies take into account the EFB and RTO. Testing was conducted prior to the EFB at the outlet of the primary cyclone.

PARAMETER **MEASURED**

Line 2 Surface Dryer RTO Inlet (Multicyclone Outlet)

Particulate		
..... (GR/DSCF)	0.152	+ 40.3
..... (LB/HR)	43	
Oxides of Nitrogen		
..... (ppm,d)	19	
..... (LB/HR)	4.5	
Carbon Monoxide		
..... (ppm,d)	164	
..... (LB/HR)	23	
Total Hydrocarbons		
..... (ppmC,w)	168	
..... (LB/HR)	12.1	

Line 2 Core Dryer RTO Inlet (Multicyclone Outlet)

Particulate		
..... (GR/DSCF)	0.301	+ 36.8
..... (LB/HR)	65	
Oxides of Nitrogen		
..... (ppm,d)	22	
..... (LB/HR)	4	
Carbon Monoxide		
..... (ppm,d)	635	
..... (LB/HR)	69	
Total Hydrocarbons		
..... (ppmC,w)	425	
..... (LB/HR)	26.4	

PARAMETER **MEASURED**

Line 2 Dryer RTO Outlet

PM Removal Efficiency* (%)	87
PM Removal Efficiency** (%)	92
(total system efficiency)	
THC Removal Efficiency* (%)	91

Particulate

. (GR/DSCF)	0.0281
. (LB/HR)	15
Opacity (%)	0

Oxides of Nitrogen

. (ppm,d)	24
. (LB/HR)	11

Carbon Monoxide

. (ppm,d)	146
. (LB/HR)	40

Total Hydrocarbons

. (ppmC,w)	21
. (LB/HR)	3.3

Formaldehyde

. (ppm,d)	3.9
. (LB/HR)	1.2

Phenol

. (ppb,d)	< 174
. (10 ⁻³ LB/HR)	< 166

Benzene

. (ppm,d)	0.018
. (LB/HR)	0.014

** Efficiency calculated considering the collection of the EFB and RTO only*

*** Efficiency estimated for the entire collection system, adding the multicyclone dust catch (36.8 LB/HR for the Core and 40.3 LB/HR for the Surface as reported by LP to the test result*

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples which were conducted by Interpoll Labs. On the basis of these facts and a complete review of the data and results, it is our opinion that the results reported herein are accurate and closely reflect the actual values which existed at the time the test was performed.

Table Ia. Summary of the Results of the July 12, 1994 Particulate Emission Compliance Test on the Line 2 Surface Dryer RTO Inlet* at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

IIEM	Run 1	Run 2	Run 3
Date of test	07-12-94	07-12-94	07-12-94
Time runs were done (HRS)	1017/1204	1305/1409	1500/1611
Volumetric flow actual (ACFM)	55681	55744	56059
standard (DSCFM)	32179	32898	33198
Gas temperature (DEG-F)	207	205	205
Moisture content (%V/V)	20.63	19.15	18.90
Gas composition (%V/V, dry)			
carbon dioxide	3.00	2.60	2.60
oxygen	18.30	18.60	18.60
nitrogen	78.70	78.80	78.80
Isokinetic variation (%)	97.8	96.3	98.8
Particulate concentration actual (GR/ACF)	0.106	.0890	.0714
standard (GR/DSCF)	0.184	0.151	0.121
Part. emission rate (LB/HR)	50.82	42.56	34.31

55828
32758

Note: Dry + Organic/Inorganic Wet Catch

* Multicyclone Outlet

Table 1b. Summary of the Results of the July 12, 1994 Particulate Emission Compliance Test on the Line 2 Surface Dryer RTO Inlet* at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-12-94	07-12-94	07-12-94
Time runs were done (HRS)	1017/1204	1305/1409	1500/1611
Volumetric flow actual (ACFM)	55681	55744	56059
standard (DSCFM)	32179	32898	33198
Gas temperature (DEG-F)	207	205	205
Moisture content (%V/V)	20.63	19.15	18.90
Gas composition (%V/V, dry)			
carbon dioxide	3.00	2.60	2.60
oxygen	18.30	18.60	18.60
nitrogen	78.70	78.80	78.80
Isokinetic variation (%)	97.8	96.3	98.8
Particulate concentration			
actual (GR/ACF)	.0730	.0698	.0499
standard (GR/DSCF)	0.126	0.118	.0843
Part. emission rate (LB/HR)	34.84	33.38	23.99

Note: Dry Catch Only

* Multicyclone Outlet

Table 2a. Summary of the Results of the July 12, 1994 Particulate Emission Compliance Test on the Line 2 Core Dryer RTO Inlet*at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-12-94	07-12-94	07-12-94
Time runs were done (HRS)	1017/1206	1303/1410	1500/1611
Volumetric flow actual (ACFM)	49342	47584	49047
standard (DSCFM)	26211	23955	25392
Gas temperature (DEG-F)	233	240	240
Moisture content (%V/V)	24.15	27.36	25.36
Gas composition (%V/V, dry)			
carbon dioxide	3.40	4.50	3.80
oxygen	17.40	16.40	17.10
nitrogen	79.20	79.10	79.10
Isokinetic variation (%)	104.9	107.4	101.5
Particulate concentration			
actual (GR/ACF)	0.173	0.147	0.149
standard (GR/DSCF)	0.325	0.292	0.287
Part. emission rate (LB/HR)	73.09	60.05	62.52

48658
37779

Note: Dry + Organic/Inorganic Wet Catch

* Multicyclone Outlet

Table 2b. Summary of the Results of the July 12, 1994 Particulate Emission Compliance Test on the Line 2 Core Dryer RTO Inlet* at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-12-94	07-12-94	07-12-94
Time runs were done (HRS)	1017/1206	1303/1410	1500/1611
Volumetric flow actual (ACFM)	49342	47584	49047
standard (DSCFM)	26211	23955	25392
Gas temperature (DEG-F)	233	240	240
Moisture content (%V/V)	24.15	27.36	25.36
Gas composition (%V/V, dry)			
carbon dioxide	3.40	4.50	3.80
oxygen	17.40	16.40	17.10
nitrogen	79.20	79.10	79.10
Isokinetic variation (%)	104.9	107.4	101.5
Particulate concentration			
actual (GR/ACF)	0.105	.0952	.0899
standard (GR/DSCF)	0.197	0.189	0.174
Part. emission rate (LB/HR)	44.32	38.85	37.83

Note: Dry Catch Only

* Multicyclone Outlet

Table 3a. Summary of the Results of the July 12, 1994 Particulate Emission Compliance Test on the Line 2 Dryer RTO Outlet at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-12-94	07-12-94	07-12-94
Time runs were done (HRS)	1000/1210	1305/1410	1500/1611
Volumetric flow actual (ACFM)	129206	127531	127788
standard (DSCFM)	64004	63029	63455
Gas temperature (DEG-F)	340	339	345
Moisture content (%V/V)	21.66	21.99	20.99
Gas composition (%V/V, dry)			
carbon dioxide	3.41	3.56	3.43
oxygen	17.07	16.95	17.06
nitrogen	79.52	79.49	79.51
Isokinetic variation (%)	99.5	100.1	98.7
Particulate concentration			
actual (GR/ACF)	.0271	.00809	.00649
standard (GR/DSCF)	.0548	.0164	.0131
Part. emission rate (LB/HR)	30.07	8.84	7.12

Note: Dry + Organic/Inorganic Wet Catch

Table 3b. Summary of the Results of the July 12, 1994 Particulate Emission Compliance Test on the Line 2 Dryer RTO Outlet at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-12-94	07-12-94	07-12-94
Time runs were done. (HRS)	1000/1210	1305/1410	1500/1611
Volumetric flow actual (ACFM)	129206	127531	127788
standard (DSCFM)	64004	63029	63455
Gas temperature (DEG-F)	340	339	345
Moisture content (%V/V)	21.66	21.99	20.99
Gas composition (%V/V.dry)			
carbon dioxide	3.41	3.56	3.43
oxygen	17.07	16.95	17.06
nitrogen	79.52	79.49	79.51
Isokinetic variation (%)	99.5	100.1	98.7
Particulate concentration actual (GR/ACF)	.0212	.00499	.00366
standard (GR/DSCF)	.0429	.0101	.00737
Part. emission rate (LB/HR)	23.54	5.46	4.01

Note: Dry Catch Only

Table 4a. Summary of the Results of the July 14, 1994 Particulate Emission Compliance Test on the Line 1 Surface Dryer RTO Inlet* at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-14-94	07-14-94	07-15-94
Time runs were done (HRS)	1625/1842	2230/2400	48/ 151
Volumetric flow actual (ACFM)	51724	51456	49872
standard (DSCFM)	26310	27727	25659
Gas temperature (DEG-F)	261	274	268
Moisture content (%V/V)	26.08	20.30	24.44
Gas composition (%V/V, dry)			
carbon dioxide	4.30	3.50	3.80
oxygen	16.50	17.40	17.10
nitrogen	79.20	79.10	79.10
Isokinetic variation (%)	103.9	95.9	104.2
Particulate concentration			
actual (GR/ACF)	0.148	0.115	0.117
standard (GR/DSCF)	0.290	0.213	0.228
Part. emission rate (LB/HR)	65.43	50.61	50.15

5/017

268

Note: Dry + Organic/Inorganic Wet Catch

* Primary Cyclone Outlet

Table 4b. Summary of the Results of the July 14, 1994 Particulate Emission Compliance Test on the Line 1 Surface Dryer RTO Inlet*at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-14-94	07-14-94	07-15-94
Time runs were done (HRS)	1625/1842	2230/2400	48/ 151
Volumetric flow actual (ACFM) standard (DSCFM)	51724 26310	51456 27727	49872 25659
Gas temperature (DEG-F)	261	274	268
Moisture content (%V/V)	26.08	20.30	24.44
Gas composition (%V/V, dry) carbon dioxide oxygen nitrogen	4.30 16.50 79.20	3.50 17.40 79.10	3.80 17.10 79.10
Isokinetic variation (%)	103.9	95.9	104.2
Particulate concentration actual (GR/ACF) standard (GR/DSCF)	0.109 0.215	.0731 0.136	.0887 0.172
Part. emission rate (LB/HR)	48.43	32.27	37.92

Note: Dry Catch Only

*Primary Cyclone Outlet

Table 5a. Summary of the Results of the July 14 & 15, 1994 Particulate Emission Compliance Test on the Line 1 Core Dryer RTO Inlet*at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-14-94	07-14-94	07-15-94
Time runs were done (HRS)	1625/1840	2230/2400	48/ 151
Volumetric flow actual (ACFM)	44841	45337	46284
standard (DSCFM)	23320	23138	23614
Gas temperature (DEG-F)	251	251	250
Moisture content (%V/V)	25.82	27.13	27.34
Gas composition (%V/V, dry)			
carbon dioxide	4.30	4.50	3.70
oxygen	16.60	16.30	17.10
nitrogen	79.10	79.20	79.20
Isokinetic variation (%)	92.8	92.0	90.2
Particulate concentration			
actual (GR/ACF)	0.126	0.172	.0951
standard (GR/DSCF)	0.242	0.336	0.186
Part. emission rate (LB/HR)	48.42	66.69	37.73

Note: Dry + Organic/Inorganic Wet Catch

* Primary Cyclone Outlet

Table 5b. Summary of the Results of the July 14 & 15, 1994 Particulate Emission Compliance Test on the Line 1 Core Dryer RTO Inlet* at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-14-94	07-14-94	07-15-94
Time runs were done (HRS)	1625/1840	2230/2400	48/ 151
Volumetric flow actual (ACFM)	44841	45337	46284
standard (DSCFM)	23320	23138	23614
Gas temperature (DEG-F)	251	251	250
Moisture content (%V/V)	25.82	27.13	27.34
Gas composition (%V/V, dry)			
carbon dioxide	4.30	4.50	3.70
oxygen	16.60	16.30	17.10
nitrogen	79.10	79.20	79.20
Isokinetic variation (%)	92.8	92.0	90.2
Particulate concentration			
actual (GR/ACF)	.0817	0.109	.0688
standard (GR/DSCF)	0.157	0.214	0.135
Part. emission rate (LB/HR)	31.41	42.41	27.29

Note: Dry Catch Only

* Primary Cyclone Outlet

Table 6a. Summary of the Results of the July 14 & 15, 1994 Particulate Emission Compliance Test on the Line 1 Dryer RTO Outlet at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-14-94	07-14-94	07-15-94
Time runs were done (HRS)	1625/1840	2230/2358	48/ 154
Volumetric flow actual (ACFM)	122399	121001	122342
standard (DSCFM)	58322	57883	59575
Gas temperature (DEG-F)	340	348	351
Moisture content (%V/V)	25.05	23.97	22.37
Gas composition (%V/V, dry)			
carbon dioxide	4.53	4.08	3.60
oxygen	16.42	16.71	17.17
nitrogen	79.05	79.21	79.23
Isokinetic variation (%)	101.2	101.9	97.4
Particulate concentration actual (GR/ACF)	.0240	.0127	.00564
standard (GR/DSCF)	.0504	.0267	.0116
Part. emission rate (LB/HR)	25.20	13.22	5.92

Note: Dry + Organic/Inorganic Wet Catch

Table 6b. Summary of the Results of the July 14 & 15, 1994 Particulate Emission Compliance Test on the Line 1 Dryer RTO Outlet at the Louisiana Pacific Corporation Plant Located in Hayward, Wisconsin.

ITEM	Run 1	Run 2	Run 3
Date of test	07-14-94	07-14-94	07-15-94
Time runs were done (HRS)	1625/1840	2230/2358	48/ 154
Volumetric flow actual (ACFM)	122399	121001	122342
standard (DSCFM)	58322	57883	59575
Gas temperature (DEG-F)	340	348	351
Moisture content (%V/V)	25.05	23.97	22.37
Gas composition (%V/V,dry)			
carbon dioxide	4.53	4.08	3.60
oxygen	16.42	16.71	17.17
nitrogen	79.05	79.21	79.23
Isokinetic variation (%)	101.2	101.9	97.4
Particulate concentration			
actual (GR/ACF)	.00928	.00576	.00466
standard (GR/DSCF)	.0195	.0120	.00957
Part. emission rate (LB/HR)	9.74	5.97	4.89

Note: Dry Catch Only

Table 7a. Summary of the Results of the July, 1994 **Oxides of Nitrogen** Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

<u>Date</u>	<u>Time (HRS)</u>	<u>Concentration (ppm,d)</u>	<u>Emission Rate (LB/HR)</u>
(Line 1 Surface Dryer RTO Inlet - Primary Cyclone Outlet)			
7-14-94	1625-1840	48	9.0
7-14-94	2230-2400	34	6.8
7-14-94	0048-0151	39	7.2
Avg		40	7.7
(Line 1 Core Dryer RTO Inlet - Primary Cyclone Outlet)			
7-14-94	1625-1840	23	3.8
7-14-94	2230-2400	28	4.6
7-14-94	0048-0151	22	3.9
Avg		24	4.1
(Line 1 Dryer RTO Outlet)			
7-14-94	1625-1840	29	12.1
7-14-94	2230-2400	29	12.0
7-14-94	0048-0151	28	11.9
Avg		29	12.0

Table 7b. Summary of the Results of the July, 1994 Oxides of Nitrogen Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

<u>Date</u>	<u>Time (HRS)</u>	<u>Concentration (ppm,d)</u>	<u>Emission Rate (LB/HR)</u>
(Line 2 Surface Dryer RTO Inlet - Multicyclone Outlet)			
7-12-94	1000-1210	17	3.9
7-12-94	1305-1410	25	5.9
7-12-94	1500-1611	16	3.8
Avg		19	4.5
(Line 2 Core Dryer RTO Inlet - Multicyclone Outlet)			
7-12-94	1000-1210	24	4.5
7-12-94	1305-1410	24	4.1
7-12-94	1500-1611	19	3.5
Avg		22	4.0
(Line 2 Dryer RTO Outlet)			
7-12-94	1000-1210	24	11.0
7-12-94	1305-1410	24	10.8
7-12-94	1500-1611	23	10.5
Avg		24	10.8

Table 8a. Summary of the Results of the July, 1994 Carbon Monoxide Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
(Line 1 Surface Dryer RTO Inlet - Primary Cyclone Outlet)			
7-14-94	1625-1840	510	59
7-14-94	2230-2400	410	50
7-14-94	0048-0154	380	43
Avg		433	51
(Line 1 Core Dryer RTO Inlet - Primary Cyclone Outlet)			
7-14-94	1625-1840	480	49
7-14-94	2230-2400	580	59
7-14-94	0048-0154	270	29
Avg		443	46
(Line 1 Dryer RTO Outlet)			
7-14-94	1625-1840	191	49
7-14-94	2230-2400	174	44
7-14-94	0048-0154	92	24
Avg		152	39

Table 8b. Summary of the Results of the July, 1994 Carbon Monoxide Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

<u>Date</u>	<u>Time (HRS)</u>	<u>Concentration (ppm,d)</u>	<u>Emission Rate (LB/HR)</u>
(Line 2 Surface Dryer RTO Inlet - Multicyclone Outlet)			
7-12-94	1000-1210	210	29
7-12-94	1305-1410	140	20
7-12-94	1500-1611	142	21
Avg		164	23
(Line 2 Core Dryer RTO Inlet - Multicyclone Outlet)			
7-12-94	1000-1210	430	49
7-12-94	1305-1410	925	97
7-12-94	1500-1611	550	61
Avg		635	69
(Line 2 Dryer RTO Outlet)			
7-12-94	1000-1210	140	39
7-12-94	1305-1410	149	41
7-12-94	1500-1611	148	41
Avg		146	40

Table 9. Summary of the July, 1994 **Formaldehyde** Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

<u>Date</u>	<u>Time (HRS)</u>	<u>Concentration (ppm.d)</u>	<u>Emission Rate (LB/HR)</u>
(Line 1 Dryer RTO Outlet)			
7-13-94	1200-1307	2.6	0.72
7-13-94	1427-1533	3.7	0.99
7-13-94	1612-1720	7.9	2.16
Avg.		4.7	1.29
(Line 2 Dryer RTO Outlet)			
7-12-94	1830-1940	3.3	1.02
7-12-94	2015-2121	4.4	1.34
7-12-94	2155-2305	3.9	1.22
Avg.		3.9	1.19

Table 10. Summary of the July, 1994 **Phenol** Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

Date	Time (HRS)	Concentration (ppb,d)	Emission Rate (10 ³ LB/HR)
(Line 1 Dryer RTO Outlet)			
7-15-94	0922-1025	< 175	< 151
7-15-94	1257-1357	< 175	< 146
7-15-94	1408-1508	< 177	< 147
Avg.		< 176	< 148
(Line 2 Dryer RTO Outlet)			
7-13-94	0856-0956	< 171	< 166
7-13-94	1120-1220	< 176	< 170
7-13-94	1301-1401	< 174	< 163
Avg.		< 174	< 166

Table 11a. Summary of the July, 1994 Total Hydrocarbon Emission Compliance Tests at the Louisiana Pacific Plant in Hayward, Wisconsin.

Date	Time (HRS)	Concentration (ppmC,w)	Emission Rate (LB/HR)
(Line 1 Surface Dryer RTO Inlet - Primary Cyclone Outlet)			
7-15-94	0841-0959	609	39
7-15-94	1313-1421	651	43
7-15-94	1445-1553	208	13
Avg.		490	32
(Line 1 Core Dryer RTO Inlet - Primary Cyclone Outlet)			
7-15-94	0841-0959	433	26
7-15-94	1313-1421	282	17
7-15-94	1445-1553	302	20
Avg.		339	21
(Line 1 Dryer RTO Outlet)			
7-15-94	0841-0959	64	9.33
7-15-94	1313-1421	50	7.19
7-15-94	1445-1553	34	4.80
Avg.		49	7.11

Table 11b. Summary of the July, 1994 Total Hydrocarbon Emission Compliance Tests at the Louisiana Pacific Plant in Hayward, Wisconsin.

Date	Time (HRS)	Concentration (ppmC,w)	Emission Rate (LB/HR)
(Line 2 Surface Dryer RTO Inlet - Multicyclone Outlet)			
7-12-94	1824-1932	112	8.0
7-12-94	2005-2120	175	12.7
7-12-94	2141-2300	218	15.7
Avg.		168	12.1
(Line 2 Core Dryer RTO Inlet - Multicyclone Outlet)			
7-12-94	1824-1932	408	26.8
7-12-94	2005-2120	496	28.9
7-12-94	2141-2300	371	23.5
Avg.		425	26.4
(Line 2 Dryer RTO Outlet)			
7-12-94	1824-1932	22	3.4
7-12-94	2005-2120	20	3.1
7-12-94	2141-2300	22	3.5
Avg.		21	3.3

Table 12. Summary of the July, 1994 Benzene Emission Compliance Tests at the Louisiana Pacific OSB Plant in Hayward, Wisconsin.

<u>Date</u>	<u>Time (HRS)</u>	<u>Concentration (ppm,d)</u>	<u>Emission Rate (LB/HR)</u>
(Line 1 Dryer RTO Outlet)			
7-15-94	0922-1025	0.075	0.054
7-15-94	1257-1357	0.076	0.053
7-15-94	1408-1508	0.051	0.035
Avg.		0.067	0.047
(Line 2 Dryer RTO Outlet)			
7-13-94	0856-0956	0.011	0.009
7-13-94	1120-1220	0.025	0.020
7-13-94	1301-1401	0.018	0.014
Avg.		0.018	0.014

Table 13 Summary of the Results of the July 15, 1994 PAH Determinations on the Line 1 Dryer RTO Outlet at the Louisiana Pacific Plant Located in Hayward, Wisconsin.

Item	RUN 1	RUN 2	RUN 3
(Concentration ug/Nm³)			
Naphthalene	27	30	29
Acenaphthylene	1.6	1.7	.53<
Acenaphthene	.56<	.56<	.58<
Fluorene	.56<	.56<	.58<
Phenanthrene	1.1	.73	.53<
Anthracene	.44<	.45<	.47<
Fluoranthene	.67<	.68<	.70<
Pyrene	.83<	.84<	.88<
Benzo-a-anthracene	1<	1.0<	1.1<
Chrysene	.5<	.51<	.53<
Benzo-b-fluoranthene	.56<	.56<	.58<
Benzo-k-fluoranthene	.94<	.96<	.99<
Benzo-a-pyrene	.72	.79	.70
Dibenzo-a,h-anthracene	.5<	.51<	.53<
Benzo-g,h,i-perylene	.67<	.68<	.70<
Indeno,1,2,3-pyrene	.5<	.51<	.53<
1-Methyl naphthalene	1.7	1.2	.88
2-Methyl naphthalene	4.6<	4.7<	4.8<

(Emission Rate 10⁻⁶g/sec)

Naphthalene	742	818	778
Acenaphthylene	43	45	14<
Acenaphthene	15<	15<	16<
Fluorene	15<	15<	16<
Phenanthrene	29	20	14<
Anthracene	12<	12<	12<
Fluoranthene	19<	18<	19<
Pyrene	23<	23<	23<
Benzo-a-anthracene	28<	27<	28<
Chrysene	14<	14<	14<
Benzo-b-fluoranthene	15<	15<	16<
Benzo-k-fluoranthene	26<	26<	26<
Benzo-a-pyrene	20	21	19
Dibenzo-a,h-anthracene	14<	14<	14<
Benzo-g,h,i-perylene	19<	18<	19<
Indeno,1,2,3-pyrene	14<	14<	14<
1-Methyl naphthalene	48	33	23
2-Methyl naphthalene	128<	126<	129<

Table 14. Summary of the Results of the July 13, 1994 PAH Determinations on the Line 2 Dryer RTO Outlet at the Louisiana Pacific Plant in Hayward, Wisconsin.

Item	RUN 1	RUN 2	RUN 3
(Concentration ug/Nm³)			
Naphthalene	11	20	13
Acenaphthylene	.45<	.44<	.45<
Acenaphthene	.50<	.49<	.51<
Fluorene	.50<	.49<	.51<
Phenanthrene	.45<	.44<	.45<
Anthracene	.40<	.39<	.40<
Fluoranthene	.60<	.59<	.61<
Pyrene	.75<	.74<	.76<
Benzo-a-anthracene	.90<	.88<	.90<
Chrysene	.45<	.44<	.45<
Benzo-b-fluoranthene	.50<	.49<	.51<
Benzo-k-fluoranthene	.85<	.84<	.86<
Benzo-a-pyrene	.60<	.59<	.61<
Dibenzo-a,h-anthracene	.45<	.44<	.45<
Benzo-g,h,i-perylene	.60<	.59<	.61<
Indeno,1,2,3-pyrene	.45<	.44<	.45<
1-Methyl naphthalene	.40<	.39<	.40<
2-Methyl naphthalene	4.2<	4.1<	4.2<
(Emission Rate 10⁻⁶g/sec)			
Naphthalene	329	627	381
Acenaphthylene	14<	14<	14<
Acenaphthene	16<	15<	15<
Fluorene	16<	15<	15<
Phenanthrene	14<	14<	14<
Anthracene	13<	12<	12<
Fluoranthene	19<	18<	18<
Pyrene	23<	23<	23<
Benzo-a-anthracene	28<	28<	27<
Chrysene	14<	14<	14<
Benzo-b-fluoranthene	16<	15<	15<
Benzo-k-fluoranthene	27<	26<	26<
Benzo-a-pyrene	19<	18<	18<
Dibenzo-a,h-anthracene	14<	14<	14<
Benzo-g,h,i-perylene	19<	18<	18<
Indeno,1,2,3-pyrene	14<	14<	14<
1-Methyl naphthalene	13<	12<	12<
2-Methyl naphthalene	130<	127<	126<

3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition (orsat and moisture) are presented first followed by the computer printout of the particulate, oxides of nitrogen, opacity, carbon monoxide, formaldehyde, phenol, and PAH sampling data. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in Extended BASIC specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The emission rates have been calculated using the product of the concentration times flow method.

3.1 Results of Orsat and Moisture Determinations

Test No. 1
Line 2 Dryer RTO Outlet
(PM/NOx/CO)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-12-94	Run 2 07-12-94	Run 3 07-12-94
Dry basis (orsat)			
carbon dioxide.....	3.41	3.56	3.43
oxygen.....	17.07	16.95	17.06
nitrogen.....	79.52	79.49	79.51
Wet basis (orsat)			
carbon dioxide.....	2.67	2.78	2.71
oxygen.....	13.37	13.22	13.48
nitrogen.....	62.29	62.01	62.82
water vapor.....	21.66	21.99	20.99
Dry molecular weight.....	29.23	29.25	29.23
Wet molecular weight.....	26.80	26.77	26.87
Specific gravity.....	0.926	0.925	0.928
Water mass flow.....(LB/HR)	49653	49823	47286
FO	1.123	1.110	1.120

Test No. 2
Line 2 Surface Dryer RTO Inlet

(PM/NOx/CO)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-12-94	Run 2 07-12-94	Run 3 07-12-94
Dry basis (orsat)			
carbon dioxide.....	3.00	2.60	2.60
oxygen.....	18.30	18.60	18.60
nitrogen.....	78.70	78.80	78.80
Wet basis (orsat)			
carbon dioxide.....	2.38	2.10	2.11
oxygen.....	14.52	15.04	15.08
nitrogen.....	62.46	63.71	63.90
water vapor.....	20.63	19.15	18.90
Dry molecular weight.....	29.21	29.16	29.16
Wet molecular weight.....	26.90	27.02	27.05
Specific gravity.....	0.929	0.933	0.934
Water mass flow.....(LB/HR)	23465	21852	21706
FO	0.867	0.885	0.885

Test No. 3
Line 2 Core Dryer RTO Inlet
(PM/NOx/CO)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-12-94	Run 2 07-12-94	Run 3 07-12-94
Dry basis (orsat)			
carbon dioxide.....	3.40	4.50	3.80
oxygen.....	17.40	16.40	17.10
nitrogen.....	79.20	79.10	79.10
Wet basis (orsat)			
carbon dioxide.....	2.58	3.27	2.84
oxygen.....	13.20	11.91	12.76
nitrogen.....	60.07	57.46	59.04
water vapor.....	24.15	27.36	25.36
Dry molecular weight.....	29.24	29.38	29.29
Wet molecular weight.....	26.53	26.26	26.43
Specific gravity.....	0.916	0.907	0.913
Water mass flow.....(LB/HR)	23414	25305	24202
FO	1.029	1.000	1.000

Test No. 7
Line 2 Dryer RTO Outlet
(Formaldehyde)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-12-94	Run 2 07-12-94	Run 3 07-12-94
Dry basis (orsat)			
carbon dioxide.....	3.90	3.80	3.80
oxygen.....	17.00	17.00	17.00
nitrogen.....	79.10	79.20	79.20
Wet basis (orsat)			
carbon dioxide.....	3.09	2.96	2.99
oxygen.....	13.45	13.23	13.36
nitrogen.....	62.59	61.65	62.22
water vapor.....	20.87	22.16	21.44
Dry molecular weight.....	29.30	29.29	29.29
Wet molecular weight.....	26.95	26.79	26.87
Specific gravity.....	0.931	0.925	0.928
Water mass flow.....(LB/HR)	0.00	0.00	0.00
FO	1.000	1.026	1.026

Test No. 8
Line 2 Dryer RTO Outlet
(PAH's)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-13-94	Run 2 07-13-94	Run 3 07-13-94
Dry basis (orsat)			
carbon dioxide.....	3.20	3.50	3.70
oxygen.....	17.40	17.10	17.00
nitrogen.....	79.40	79.40	79.30
Wet basis (orsat)			
carbon dioxide.....	2.57	2.78	2.89
oxygen.....	13.98	13.59	13.28
nitrogen.....	63.78	63.08	61.94
water vapor.....	19.68	20.55	21.89
Dry molecular weight.....	29.21	29.24	29.27
Wet molecular weight.....	27.00	26.93	26.80
Specific gravity.....	0.933	0.930	0.926
Water mass flow.....(LB/HR)	0.00	0.00	0.00
FO	1.094	1.086	1.054

Test No. 11
Line 1 Dryer RTO Outlet
(Formaldehyde)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-13-94	Run 2 07-13-94	Run 3 07-13-94
Dry basis (orsat)			
carbon dioxide.....	4.30	4.30	4.30
oxygen.....	16.60	16.60	16.50
nitrogen.....	79.10	79.10	79.20
Wet basis (orsat)			
carbon dioxide.....	3.28	3.23	3.21
oxygen.....	12.66	12.47	12.33
nitrogen.....	60.31	59.41	59.20
water vapor.....	23.75	24.89	25.25
Dry molecular weight.....	29.35	29.35	29.35
Wet molecular weight.....	26.66	26.53	26.48
Specific gravity.....	0.921	0.916	0.915
Water mass flow.....(LB/HR)	0.00	0.00	0.00
FO	1.000	1.000	1.023

Test No. 13
Line 1 Surface Dryer RTO Inlet
(PM/NOx/CO)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-14-94	Run 2 07-14-94	Run 3 07-15-94
Dry basis (orsat)			
carbon dioxide.....	4.30	3.50	3.80
oxygen.....	16.50	17.40	17.10
nitrogen.....	79.20	79.10	79.10
Wet basis (orsat)			
carbon dioxide.....	3.18	2.79	2.87
oxygen.....	12.20	13.87	12.92
nitrogen.....	58.54	63.05	59.77
water vapor.....	26.08	20.30	24.44
Dry molecular weight.....	29.35	29.26	29.29
Wet molecular weight.....	26.39	26.97	26.53
Specific gravity.....	0.912	0.932	0.916
Water mass flow.....(LB/HR)	26039	19805	23281
FO	1.023	1.000	1.000

Test No. 14
Line 1 Dryer RTO Outlet

(PM/NOx/CO)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-14-94	Run 2 07-14-94	Run 3 07-15-94
Dry basis (orsat)			
carbon dioxide.....	4.53	4.08	3.60
oxygen.....	16.42	16.71	17.17
nitrogen.....	79.05	79.21	79.23
Wet basis (orsat)			
carbon dioxide.....	3.40	3.10	2.79
oxygen.....	12.31	12.70	13.33
nitrogen.....	59.24	60.22	61.51
water vapor.....	25.05	23.97	22.37
Dry molecular weight.....	29.38	29.32	29.26
Wet molecular weight.....	26.53	26.61	26.74
Specific gravity.....	0.916	0.919	0.924
Water mass flow.....(LB/HR)	54690	51193	48147
FO	0.989	1.027	1.036

Test No. 15
Line 1 Core Dryer RTO Inlet

(PM/NO_x/CO)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94

Dry basis (orsat)

carbon dioxide.....	4.30	4.50	3.70
oxygen.....	16.60	16.30	17.10
nitrogen.....	79.10	79.20	79.20

Wet basis (orsat)

carbon dioxide.....	3.19	3.28	2.69
oxygen.....	12.31	11.88	12.42
nitrogen.....	58.68	57.71	57.54
water vapor.....	25.82	27.13	27.34

Dry molecular weight.....	29.35	29.37	29.28
Wet molecular weight.....	26.42	26.29	26.19
Specific gravity.....	0.913	0.908	0.905
Water mass flow.....(LB/HR)	22771	24164	24928

FO	1.000	1.022	1.027
----	-------	-------	-------

Test No. 20
Line 1 Dryer RTO Outlet
(PAH's)

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 07-15-94	Run 2 07-15-94	Run 3 07-15-94
Dry basis (orsat)			
carbon dioxide.....	4.10	4.30	4.10
oxygen.....	16.60	16.30	16.50
nitrogen.....	79.30	79.40	79.40
Wet basis (orsat)			
carbon dioxide.....	3.09	3.18	3.07
oxygen.....	12.50	12.05	12.37
nitrogen.....	59.71	58.68	59.50
water vapor.....	24.70	26.10	25.06
Dry molecular weight.....	29.32	29.34	29.32
Wet molecular weight.....	26.52	26.38	26.48
Specific gravity.....	0.916	0.911	0.915
Water mass flow.....(LB/HR)	0.00	0.00	0.00
FO	1.049	1.070	1.073

3.2 Results of Particulate Determinations

Test No. 13
Line 1 Surface Dryer RTO Inlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94
Time run start/end.....(HRS)	1625/1842	2230/2400	48/ 151
Static pressure.....(IN.WC)	-10.20	-10.20	-10.20
Cross sectional area (SQ.FT)	9.62	9.62	9.62
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	246.0	181.0	237.0
desiccant.....(GRAMS)	36.0	17.0	16.0
total.....(GRAMS)	282.0	198.0	253.0
Total particulate material..collected(grams)	0.7086	0.5060	0.5450
Gas meter coefficient.....	0.9930	0.9930	0.9930
Barometric pressure..(IN.HG)	28.85	28.85	28.85
Avg. orif.pres.drop..(IN.WC)	1.18	1.10	1.10
Avg. gas meter temp..(DEF-F)	83.8	86.0	81.0
Volume through gas meter.... at meter conditions...(CF)	40.43	39.50	39.37
standard conditions.(DSCF)	37.68	36.66	36.88
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.195	.195	.195
Avg.stack gas temp ..(DEG-F)	261	274	268
Volumetric flow rate..... actual.....(ACFM)	51724	51456	49872
dry standard.....(DSCFM)	26310	27727	25659
Isokinetic variation.....(%)	103.9	95.9	104.2
Particulate concentration... actual.....(GR/ACF)	0.14752	0.11471	0.11727
dry standard.....(GR/DSCF)	0.29014	0.21296	0.22803
Particle mass rate...(LB/HR)	65.429	50.612	50.151

Test No. 15
Line 1 Core Dryer RTO Inlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94
Time run start/end.....(HRS)	1625/1840	2230/2400	48/ 151
Static pressure.....(IN.WC)	-8.40	-8.40	-8.40
Cross sectional area (SQ.FT)	9.62	9.62	9.62
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	321.0	344.0	346.0
desiccant.....(GRAMS)	21.0	16.0	18.0
total.....(GRAMS)	342.0	360.0	364.0
Total particulate material..collected(grams)	0.7272	0.9936	0.5509
Gas meter coefficient.....	0.9974	0.9974	0.9974
Barometric pressure..(IN.HG)	28.85	28.85	28.85
Avg. orif.pres.drop..(IN.WC)	1.76	1.66	1.66
Avg. gas meter temp..(DEF-F)	84.5	78.9	76.4
Volume through gas meter....			
at meter conditions...(CF)	49.47	48.20	47.99
standard conditions.(DSCF)	46.32	45.59	45.60
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.243	.243	.243
Avg.stack gas temp ..(DEG-F)	251	251	250
Volumetric flow rate.....			
actual.....(ACFM)	44841	45337	46284
dry standard.....(DSCFM)	23320	23138	23614
Isokinetic variation.....(%)	92.8	92.0	90.2
Particulate concentration...			
actual.....(GR/ACF)	0.12592	0.17155	0.09506
dry standard.....(GR/DSCF)	0.24222	0.33627	0.18639
Particle mass rate...(LB/HR)	48.417	66.691	37.727

Test No. 14
Line 1 Dryer RTO Outlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94
Time run start/end.....(HRS)	1625/1840	2230/2358	48/ 154
Static pressure.....(IN.WC)	-0.50	-0.50	-0.50
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	231.0	218.0	194.0
desiccant.....(GRAMS)	11.0	10.0	11.0
total.....(GRAMS)	242.0	228.0	205.0
Total particulate material..collected(grams)	0.1115	0.0589	0.0252
Gas meter coefficient.....	0.9962	0.9962	0.9962
Barometric pressure..(IN.HG)	28.85	28.85	28.85
Avg. orif.pres.drop..(IN.WC)	1.03	1.01	0.98
Avg. gas meter temp..(DEF-F)	87.9	82.2	81.0
Volume through gas meter....			
at meter conditions...(CF)	36.79	36.37	35.71
standard conditions.(DSCF)	34.13	34.10	33.55
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.245	.245	.245
Avg.stack gas temp ..(DEG-F)	340	348	351
Volumetric flow rate.....			
actual.....(ACFM)	122399	121001	122342
dry standard.....(DSCFM)	58322	57883	59575
Isokinetic variation.....(%)	101.2	101.9	97.4
Particulate concentration...			
actual.....(GR/ACF)	0.02401	0.01275	0.00564
dry standard.....(GR/DSCF)	0.05041	0.02666	0.01159
Particle mass rate...(LB/HR)	25.198	13.225	5.919

Test No. 2
Line 2 Surface Dryer RTO Inlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1017/1204	1305/1409	1500/1611
Static pressure.....(IN.WC)	-16.30	-16.30	-16.30
Cross sectional area (SQ.FT)	9.62	9.62	9.62
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	203.0	169.0	179.0
desiccant.....(GRAMS)	26.0	41.0	35.0
total.....(GRAMS)	229.0	210.0	214.0
Total particulate material..collected(grams)	0.4960	0.4090	0.3383
Gas meter coefficient.....	0.9947	0.9947	0.9947
Barometric pressure..(IN.HG)	28.72	28.72	28.72
Avg. orif.pres.drop..(IN.WC)	1.78	1.83	1.94
Avg. gas meter temp..(DEF-F)	82.5	91.3	92.8
Volume through gas meter....			
at meter conditions...(CF)	44.51	45.53	47.25
standard conditions.(DSCF)	41.53	41.81	43.29
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.197	.197	.197
Avg.stack gas temp ..(DEG-F)	207	205	205
Volumetric flow rate.....			
actual.....(ACFM)	55681	55744	56059
dry standard.....(DSCFM)	32179	32898	33198
Isokinetic variation.....(%)	97.8	96.3	98.8
Particulate concentration...			
actual.....(GR/ACF)	0.10645	0.08904	0.07138
dry standard.....(GR/DSCF)	0.18426	0.15093	0.12059
Particle mass rate...(LB/HR)	50.823	42.560	34.314

Test No. 3
Line 2 Core Dryer RTO Inlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1017/1206	1303/1410	1500/1611
Static pressure.....(IN.WC)	-16.40	-16.40	-16.40
Cross sectional area (SQ.FT)	9.62	9.62	9.62
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	199.0	233.0	203.0
desiccant.....(GRAMS)	17.0	6.0	13.0
total.....(GRAMS)	216.0	239.0	216.0
Total particulate material..			
.....collected(grams)	0.6743	0.5672	0.5580
Gas meter coefficient.....	0.9962	0.9962	0.9962
Barometric pressure..(IN.HG)	28.71	28.71	28.71
Avg. orif.pres.drop..(IN.WC)	1.01	0.87	0.85
Avg. gas meter temp..(DEF-F)	78.1	89.7	91.3
Volume through gas meter....			
at meter conditions...(CF)	34.02	32.53	32.68
standard conditions.(DSCF)	31.98	29.92	29.97
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.185	.185	.185
Avg.stack gas temp ..(DEG-F)	233	240	240
Volumetric flow rate.....			
actual.....(ACFM)	49342	47584	49047
dry standard.....(DSCFM)	26211	23955	25392
Isokinetic variation.....(%)	104.9	107.4	101.5
Particulate concentration...			
actual.....(GR/ACFM)	0.17276	0.14718	0.14866
dry standard.....(GR/DSCFM)	0.32535	0.29248	0.28727
Particle mass rate...(LB/HR)	73.094	60.054	62.523

Test No. 1
Line 2 Dryer RTO Outlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1000/1210	1305/1410	1500/1611
Static pressure.....(IN.WC)	-0.61	-0.61	-0.61
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	205.0	208.0	189.0
desiccant.....(GRAMS)	11.0	10.0	15.0
total.....(GRAMS)	216.0	218.0	204.0
Total particulate material..			
.....collected(grams)	0.1308	0.0387	0.0307
Gas meter coefficient.....	0.9930	0.9930	0.9930
Barometric pressure..(IN.HG)	28.71	28.71	28.71
Avg. orif.pres.drop..(IN.WC)	1.12	1.13	1.11
Avg. gas meter temp..(DEF-F)	89.2	100.3	100.8
Volume through gas meter....			
at meter conditions...(CF)	40.10	40.52	40.26
standard conditions.(DSCF)	36.82	36.47	36.21
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.245	.245	.245
Avg.stack gas temp ..(DEG-F)	340	339	345
Volumetric flow rate.....			
actual.....(ACFM)	129206	127531	127788
dry standard.....(DSCFM)	64004	63029	63455
Isokinetic variation.....(%)	99.5	100.1	98.7
Particulate concentration...			
actual.....(GR/ACF)	0.02714	0.00809	0.00649
dry standard.....(GR/DSCF)	0.05481	0.01637	0.01308
Particle mass rate...(LB/HR)	30.067	8.845	7.116

3.3 Results of Oxides of Nitrogen Determinations

Test No. 2
Line 2 Surface Dryer RTO Inlet

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 1A	Run 1B	Run 1C	Run 1D
Date of run.....	07-12-94	07-12-94	07-12-94	07-12-94
Time of run.....(HRS)	1017	1034	1128	1150
Flask number.....	1	2	3	4
Volume of flask.....(ML)	2086	2063	2055	2116
Data: time of sampling				
flask temperature..(DEG-F)	100.00	101.00	101.00	103.00
bar. press.....(IN.HG)	28.72	28.72	28.72	28.72
flask vacuum.....(IN.HG)	26.40	26.40	26.40	26.50
flask abs. press...(IN.HG)	2.32	2.32	2.32	2.22
Data: Time of Flask Opening				
flask temperature..(DEG-F)	75.00	75.00	75.00	75.00
lab. bar. press...(IN.HG)	28.96	28.96	28.96	28.96
flask static press.(IN.HG)	-3.00	-1.60	-0.40	-3.00
flask abs. press...(IN.HG)	25.96	27.36	28.56	25.96
Volume gas sampled....(DSML)	1613	1689	1763	1644
Moisture content.....(%V/V)	20.63	20.63	20.63	20.63
Nitrate in gas sample...(JG)	71.0	83.0	73.0	62.0
NO2 in gas sample.....(JG)	52.7	61.6	54.2	46.0
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0143	0.0159	0.0134	0.0122
(MG/DSCM).....	33	36	31	28
(PPM-DRY).....	17	19	16	15
(PPM-WET).....	14	15	13	12
NOX Emission rate....(LB/HR)	3.94	4.39	3.70	3.37

Test No. 2
Line 2 Surface Dryer RTO Inlet

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 2A	Run 2B	Run 2C	Run 2D
Date of run.....	07-12-94	07-12-94	07-12-94	07-12-94
Time of run.....(HRS)	1310	1330	1345	1400
Flask number.....	5	6	7	9
Volume of flask.....(ML)	2057	2100	2081	2080
Data: time of sampling				
flask temperature..(DEG-F)	104.00	103.00	104.00	103.00
bar. press.....(IN.HG)	28.72	28.72	28.72	28.72
flask vacuum.....(IN.HG)	26.30	26.40	26.30	26.40
flask abs. press...(IN.HG)	2.42	2.32	2.42	2.32
Data: Time of Flask Opening				
flask temperature..(DEG-F)	75.00	75.00	75.00	75.00
lab. bar. press...(IN.HG)	28.96	28.96	28.96	28.96
flask static press.(IN.HG)	-0.20	-0.30	-4.60	-0.80
flask abs. press...(IN.HG)	28.76	28.66	24.36	28.16
Volume gas sampled....(DSML)	1773	1810	1495	1758
Moisture content.....(%V/V)	19.15	19.15	19.15	19.15
Nitrate in gas sample...(JG)	130.0	140.0	80.0	98.0
NO2 in gas sample.....(JG)	96.5	103.9	59.4	72.7
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0238	0.0251	0.0173	0.0181
(MG/DSCM).....	54	57	40	41
(PPM-DRY).....	28	30	21	22
(PPM-WET).....	23	24	17	17
NOX Emission rate....(LB/HR)	6.71	7.07	4.89	5.10

Test No. 2
Line 2 Surface Dryer RTO Inlet

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 3A	Run 3B	Run 3C	Run 3D
Date of run.....	07-12-94	07-12-94	07-12-94	07-12-94
Time of run.....(HRS)	1505	1520	1545	1600
Flask number.....	10	11	12	28
Volume of flask.....(ML)	2063	2062	2111	2031
Data: time of sampling				
flask temperature..(DEG-F)	101.00	101.00	100.00	100.00
bar. press.....(IN.HG)	28.72	28.72	28.72	28.72
flask vacuum.....(IN.HG)	26.40	26.30	26.30	26.20
flask abs. press...(IN.HG)	2.32	2.42	2.42	2.52
Data: Time of Flask Opening				
flask temperature..(DEG-F)	75.00	75.00	75.00	75.00
lab. bar. press...(IN.HG)	28.96	28.96	28.96	28.96
flask static press.(IN.HG)	-3.50	-1.60	-0.10	-3.90
flask abs. press...(IN.HG)	25.46	27.36	28.86	25.06
Volume gas sampled....(DSML)	1562	1682	1826	1498
Moisture content.....(%V/V)	18.90	18.90	18.90	18.90
Nitrate in gas sample...(JG)	100.0	60.0	60.0	51.0
NO2 in gas sample.....(JG)	74.2	44.5	44.5	37.8
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0208	0.0116	0.0107	0.0110
(MG/DSCM).....	48	26	24	25
(PPM-DRY).....	25	14	13	13
(PPM-WET).....	20	11	10	11
NOX Emission rate....(LB/HR)	5.91	3.29	3.03	3.14

Test No. 13
Line 1 Surface Dryer RTO Inlet

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 1A	Run 1B	Run 1C	Run 1D
Date of run.....	07-14-94	07-14-94	07-14-94	07-14-94
Time of run.....(HRS)	1630	1645	1715	1830
Flask number.....	19	20	21	22
Volume of flask.....(ML)	2069	2060	2068	2031
Data: time of sampling				
flask temperature..(DEG-F)	97.00	97.00	95.00	95.00
bar. press.....(IN.HG)	28.85	28.85	28.85	28.85
flask vacuum.....(IN.HG)	26.30	26.30	26.20	26.10
flask abs. press...(IN.HG)	2.55	2.55	2.65	2.75
Data: Time of Flask Opening				
flask temperature..(DEG-F)	75.00	75.00	75.00	75.00
lab. bar. press....(IN.HG)	28.96	28.96	28.96	28.96
flask static press.(IN.HG)	-0.40	-0.70	-3.50	-0.90
flask abs. press...(IN.HG)	28.56	28.26	25.46	28.06
Volume gas sampled....(DSML)	1759	1732	1543	1680
Moisture content.....(%V/V)	26.08	26.08	26.08	26.08
Nitrate in gas sample...(JG)	100.0	180.0	350.0	180.0
NO2 in gas sample.....(JG)	74.2	133.6	259.7	133.6
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0184	0.0337	0.0736	0.0347
(MG/DSCM).....	42	77	168	79
(PPM-DRY).....	22	40	88	42
(PPM-WET).....	16	30	65	31
NOX Emission rate....(LB/HR)	4.16	7.60	16.59	7.83

Test No. 13
Line 1 Surface Dryer RTO Inlet

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 2A	Run 2B	Run 2C	Run 2D
Date of run.....	07-14-94	07-14-94	07-14-94	07-14-94
Time of run.....(HRS)	2035	2050	2110	2125
Flask number.....	23	24	13	14
Volume of flask.....(ML)	2056	2031	2060	2048

Data: time of sampling

flask temperature..(DEG-F)	77.00	77.00	77.00	77.00
bar. press.....(IN.HG)	28.85	28.85	28.85	28.85
flask vacuum.....(IN.HG)	26.10	26.20	26.30	26.30
flask abs. press...(IN.HG)	2.75	2.65	2.55	2.55

Data: Time of Flask Opening

flask temperature..(DEG-F)	75.00	75.00	75.00	75.00
lab. bar. press...(IN.HG)	28.96	28.96	28.96	28.96
flask static press.(IN.HG)	-1.90	0.00	-1.00	-1.90
flask abs. press...(IN.HG)	27.06	28.96	27.96	27.06
Volume gas sampled....(DSML)	1628	1741	1705	1635
Moisture content.....(%V/V)	20.30	20.30	20.30	20.30
Nitrate in gas sample...(JG)	110.0	200.0	140.0	140.0
NO2 in gas sample.....(JG)	81.6	148.4	103.9	103.9

NOx Concentration

(GR/DSCF).....	0.0219	0.0373	0.0266	0.0278
(MG/DSCM).....	50	85	61	64
(PPM-DRY).....	26	45	32	33
(PPM-WET).....	21	36	25	26
NOX Emission rate....(LB/HR)	5.21	8.86	6.33	6.60

Test No. 13
Line 1 Surface Dryer RTO Inlet

Results of Oxides of Nitrogen (NOx) Determinations-----Method 7

	Run 3A	Run 3B	Run 3C	Run 3D
Date of run.....				
Time of run.....(HRS)	2235	2250	2310	2350
Flask number.....	15	16	17	18
Volume of flask.....(ML)	2045	2067	2054	2045
Data: time of sampling				
flask temperature..(DEG-F)	72.00	71.00	70.00	70.00
bar. press.....(IN.HG)	28.85	28.85	28.85	28.85
flask vacuum.....(IN.HG)	26.30	26.20	26.30	26.40
flask abs. press...(IN.HG)	2.55	2.65	2.55	2.45
Data: Time of Flask Opening				
flask temperature..(DEG-F)	75.00	75.00	75.00	75.00
lab. bar. press...(IN.HG)	28.96	28.96	28.96	28.96
flask static press.(IN.HG)	-1.20	-1.10	-0.80	-0.40
flask abs. press...(IN.HG)	27.76	27.86	28.16	28.56
Volume gas sampled....(DSML)	1678	1696	1711	1737
Moisture content.....(%V/V)	24.44	24.44	24.44	24.44
Nitrate in gas sample...(JG)	77.0	150.0	270.0	190.0
NO2 in gas sample.....(JG)	57.1	111.3	200.3	141.0
<u>NOx Concentration</u>				
(GR/DSCF).....	0.0149	0.0287	0.0512	0.0355
(MG/DSCM).....	34	66	117	81
(PPM-DRY).....	18	34	61	42
(PPM-WET).....	13	26	46	32
NOX Emission rate....(LB/HR)	3.27	6.31	11.25	7.80

3.4 Results of Opacity Observations

Test No. 14
 Line 1 Dryer RTO Outlet

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	100.00
5	0.0223	0.00
10	0.0458	0.00
15	0.0706	0.00
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac 0.00	Avg OD 0.0000	Time average

Observer: Edward W. Trowbridge
 Cert. Date: 04-07-94
 Date of Observation: 07-14-94
 Time of Observation: 1642/1742

Test No. 1
Line 2 Dryer RTO Outlet

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	100.00
5	0.0223	0.00
10	0.0458	0.00
15	0.0706	0.00
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac 0.00	Avg OD 0.0000	Time average

Observer: Edward W. Trowbridge
Cert. Date: 04-07-94
Date of Observation: 07-12-94
Time of Observation: 1500/1600

3.5 Results of Carbon Monoxide Determinations

Test No. 13
Line 1 Surface Dryer RTO Inlet

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94
Time run start/end.....(HRS)	1625/1842	2230/2400	0048/0151
Total sampling time....(MIN)	64.0	64.0	64.0
Moisture content.....(%V/V)	26.08	20.30	24.44
O2 Concentration.....(%V/V)	16.50	17.40	17.10
Volumetric flow rate (DSCFM)	26310	27727	25659
CO concentration.....			
(GR/DSCF).....	0.2595	0.2086	0.1934
(MG/DSCM).....	594.15	477.65	442.70
(PPM-WET).....	376.99	326.77	287.13
(PPM-DRY).....	510.00	410.00	380.00
(PPM-DRY @ 7% O2).....	%1586.67	%1594.44	%1364.10
CO emission rate.....(LB/HR)	58.521	49.580	42.525

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 15
Line 1 Core Dryer RTO Inlet

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94
Time run start/end.....(HRS)	1625/1840	2230/2400	0048/0151
Total sampling time....(MIN)	64.0	64.0	64.0
Moisture content.....(%V/V)	25.82	27.13	24.21
O2 Concentration.....(%V/V)	16.54	16.54	17.09
Volumetric flow rate (DSCFM)	23320	23138	24468
CO concentration.....			
(GR/DSCF).....	0.2442	0.2951	0.1374
(MG/DSCM).....	559.20	675.70	314.55
(PPM-WET).....	356.06	422.65	204.63
(PPM-DRY).....	480.00	580.00	270.00
(PPM-DRY @ 7% O2).....	1506.	1820..	966.75
CO emission rate.....(LB/HR)	48.819	58.530	28.813

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 14
Line 1 Dryer RTO Outlet

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-14-94	07-14-94	07-15-94
Time run start/end.....(HRS)	1625/1840	2230/2358	0048/0154
Total sampling time....(MIN)	64.0	64.0	64.0
Moisture content.....(%V/V)	25.05	23.97	22.37
O2 Concentration.....(%V/V)	16.42	16.71	17.17
Volumetric flow rate (DSCFM)	58322	57883	59575
CO concentration.....			
(GR/DSCF).....	0.0972	0.0885	0.0468
(MG/DSCM).....	222.51	202.71	107.18
(PPM-WET).....	143.15	132.29	71.42
(PPM-DRY).....	191.00	174.00	92.00
(PPM-DRY @ 7% O2).....	583.84	567.83	336.29
CO emission rate.....(LB/HR)	48.583	43.926	23.904

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 2
Line 2 Surface Dryer RTO Inlet

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1017/1204	1305/1409	1500/1611
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	20.63	19.15	18.90
O2 Concentration.....(%V/V)	18.30	18.60	18.60
Volumetric flow rate (DSCFM)	32179	32898	33198
CO concentration.....			
(GR/DSCF).....	0.1069	0.0712	0.0723
(MG/DSCM).....	244.65	163.10	165.43
(PPM-WET).....	166.68	113.19	115.16
(PPM-DRY).....	210.00	140.00	142.00
(PPM-DRY @ 7% O2).....	*1088.89	816.67	828.33
CO emission rate.....(LB/HR)	29.472	20.087	20.560

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 3
Line 2 Core Dryer RT0 Inlet

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1017/1204	1305/1409	1500/1611
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	24.15	27.36	25.36
O2 Concentration.....(%V/V)	17.45	16.57	16.90
Volumetric flow rate (DSCFM)	26211	23955	25392
CO concentration.....			
(GR/DSCF).....	0.2188	0.4707	0.2799
(MG/DSCM).....	500.95	1077.	640.75
(PPM-WET).....	326.16	671.92	410.52
(PPM-DRY).....	430.00	925.00	550.00
(PPM-DRY @ 7% O2).....	1695.	2923.	1878.
CO emission rate.....(LB/HR)	49.156	96.640	60.909

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Test No. 1
Line 2 Dryer RTO Outlet

Results of CO Determinations -----Method 10

	Run 1	Run 2	Run 3
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1000/1210	1305/1410	1500/1611
Total sampling time....(MIN)	64.0	64.0	64.0
Moisture content.....(%V/V)	21.66	21.99	20.99
O2 Concentration.....(%V/V)	17.07	16.95	17.06
Volumetric flow rate (DSCFM)	64004	63029	63455
CO concentration.....			
(GR/DSCF).....	0.0712	0.0758	0.0753
(MG/DSCM).....	163.10	173.58	172.42
(PPM-WET).....	109.68	116.23	116.93
(PPM-DRY).....	140.00	149.00	148.00
(PPM-DRY @ 7% O2).....	498.73	515.06	525.89
CO emission rate.....(LB/HR)	39.080	40.959	40.959

CO = Carbon monoxide

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

3.6 Results of Formaldehyde Determinations

Test No. 7
Line 2 Dryer RTO Outlet

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1 07-12-94	Run 2 07-12-94	Run 3 07-12-94
Date of run	07-12-94	07-12-94	07-12-94
Time run start/end.....(HRS)	1830/1940	2015/2121	2155/2305
Static pressure.....(IN.WC)	-0.61	-0.61	-0.61
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	290.0	320.0	312.0
desiccant.....(GRAMS)	36.0	31.0	32.0
total.....(GRAMS)	326.0	351.0	344.0
Formaldehyde in sample..(uG)	6760	9010	8120
Gas meter coefficient.....	0.9930	0.9930	0.9930
Barometric pressure..(IN.HG)	28.71	28.71	28.71
Avg. orif.pres.drop..(IN.WC)	2.84	2.82	2.90
Avg. gas meter temp..(DEF-F)	97.3	96.1	90.0
Volume through gas meter....			
at meter conditions...(CF)	64.13	63.83	64.53
standard conditions.(DSCF)	58.29	58.14	59.44
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.303	.303	.303
Avg.stack gas temp ..(DEG-F)	349	349	346
Volumetric flow rate.....			
actual.....(ACFM)	133385	132901	136344
dry standard.....(DSCFM)	65964	64723	67196
Isokinetic variation.....(%)	100.0	101.6	100.1
CH2O concentration.....			
(GR/DSCF).....	0.0018	0.0024	0.0021
(MG/DSCM).....	4.13	5.51	4.86
(PPM-DRY).....	3.31	4.42	3.89
(PPM-WET).....	2.62	3.44	3.06
CH2O emission rate...(LB/HR)	1.01870	1.33560	1.22255

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value 70

Test No. 11
Line 1 Dryer RTO Outlet

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	07-13-94	07-13-94	07-13-94
Time run start/end.....(HRS)	1200/1307	1427/1533	1612/1720
Static pressure.....(IN.WC)	-0.48	-0.48	-0.48
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	327.0	334.0	337.0
desiccant.....(GRAMS)	36.0	30.0	35.0
total.....(GRAMS)	363.0	364.0	372.0
Formaldehyde in sample..(uG)	4910	6650	14400
Gas meter coefficient.....	0.9962	0.9962	0.9962
Barometric pressure..(IN.HG)	28.94	28.94	28.94
Avg. orif.pres.drop..(IN.WC)	2.61	2.34	2.35
Avg. gas meter temp..(DEF-F)	79.0	85.3	84.4
Volume through gas meter....			
at meter conditions...(CF)	57.85	55.20	55.25
standard conditions.(DSCF)	54.95	51.79	51.92
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.303	.303	.303
Avg.stack gas temp ..(DEG-F)	339	338	336
Volumetric flow rate.....			
actual.....(ACFM)	123868	120823	122114
dry standard.....(DSCFM)	60324	57988	58497
Isokinetic variation.....(%)	103.0	101.0	100.4
CH2O concentration.....			
(GR/DSCF).....	0.0014	0.0020	0.0043
(MG/DSCM).....	3.18	4.56	9.87
(PPM-DRY).....	2.55	3.65	7.91
(PPM-WET).....	1.94	2.75	5.91
CH2O emission rate...(LB/HR)	0.71740	0.99028	2.16163

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

3.7 Results of Phenol Determinations

Test No. 19
Line 1 Dryer RTO Outlet

Results of Phenol Determinations -----

	Run 1	Run 2	Run 3
Date of run	07-15-94	07-15-94	07-15-94
Time run start/end.....(HRS)	0922/1025	1257/1357	1408/1508
Barometric pressure..(IN.HG)	28.86	28.86	28.86
Meter temperature....(DEG-F)	81.00	91.00	100.00
Meter correction coefficient	0.9974	0.9974	0.9974
Volume through gas meter.... at meter conditions...(CF)	45.950	46.900	46.960
standard conditions (DSCF)	43.339	43.432	42.789
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	24.70	26.10	25.06
Volumetric flow rate (DSCFM)	59055	57018	56588
Phenol in sample.....(uG)	840.00<	840.00<	840.00<
Phenol concentration..... (GR/10 ³ DSCF).....	0.2991<	0.2984<	0.3029<
(uG/DSCM).....	684.96<	683.49<	693.77<
(PPB-DRY).....	175.04<	174.66<	177.29<
(PPB-WET).....	131.80<	129.07<	132.86<
Phenol emis. rate(10 ⁻³ LB/HR)	151.375<	145.840<	146.916<

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Analysis performed according to NIOSH Method 3502

Test No. 10
Line 2 Dryer RTO Outlet

Results of Phenol Determinations -----

	Run 1	Run 2	Run 3
Date of run	07-13-94	07-13-94	07-13-94
Time run start/end.....(HRS)	0856/0956	1120/1220	1301/1401
Barometric pressure..(IN.HG)	28.94	28.94	28.94
Meter temperature....(DEG-F)	78.92	86.13	86.54
Meter correction coefficient	0.9974	0.9974	0.9974
Volume through gas meter.... at meter conditions...(CF)	46.650	46.130	46.560
standard conditions (DSCF)	44.291	43.219	43.589
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	19.68	20.55	21.89
Volumetric flow rate (DSCFM)	66295	65988	63855
Phenol in sample.....(uG)	840.00<	840.00<	840.00<
Phenol concentration..... (GR/10 ³ DSCF).....	0.2926<	0.2999<	0.2973<
(uG/DSCM).....	670.24<	686.86<	681.03<
(PPB-DRY).....	171.27<	175.52<	174.03<
(PPB-WET).....	137.57<	139.45<	135.94<
Phenol emis. rate(10 ⁻³ LB/HR)	166.281<	169.616<	162.740<

A trailing '<' symbol indicates that the true value is less than or equal to the reported value

Analysis performed according to NIOSH Method 3502

3.8 PAH Sampling Data

Test No. 8
Line 2 Dryer RTO Outlet

Sampling Data for PAH Determinations-----SW846 Method 0010

	Run 1	Run 2	Run 3
Date of run	07-13-94	07-13-94	07-13-94
Time run start/end.....(HRS)	848/1058	1150/1402	1505/1717
Static pressure.....(IN.WC)	-0.40	-0.40	-0.40
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	0.840	0.840	0.840
Water in sample gas			
condenser.....(ML)	347.0	372.0	394.0
impingers.....(GRAMS)	0.0	0.0	0.0
desiccant.....(GRAMS)	20.0	23.0	22.0
total.....(GRAMS)	367.0	395.0	416.0
Gas meter coefficient.....	0.9930	0.9930	0.9930
Barometric pressure..(IN.HG)	28.94	28.94	28.94
Avg. orif.pres.drop..(IN.WC)	0.99	1.06	1.01
Avg. gas meter temp..(DEF-F)	79.9	91.1	94.0
Volume through gas meter....			
at meter conditions...(CF)	74.93	77.93	76.15
standard conditions.(DSCF)	70.53	71.88	69.86
standard conditions..(NM ³)	1.997	2.035	1.978
Total sampling time....(MIN)	128.00	128.00	128.00
Nozzle diameter.....(IN)	.237	.237	.237
Avg.stack gas temp ..(DEG-F)	338	345	344
Volumetric flow rate.....			
actual.....(ACFM)	129160	131111	128877
dry standard.....(DSCFM)	66295	65988	63855
Isokinetic variation.....(%)	98.3	100.7	101.1


Test No. 20
Line 1 Dryer RTO Outlet

Sampling Data for PAH Determinations-----SW846 Method 0010

	Run 1	Run 2	Run 3
Date of run	07-15-94	07-15-94	07-15-94
Time run start/end.....(HRS)	800/1015	1258/1509	1545/1754
Static pressure.....(IN.WC)	-0.54	-0.54	-0.54
Cross sectional area (SQ.FT)	36.23	36.23	36.23
Pitot tube coefficient.....	0.840	0.840	0.840
Water in sample gas			
condenser.....(ML)	423.0	449.0	411.0
impingers.....(GRAMS)	0.0	0.0	0.0
desiccant.....(GRAMS)	20.0	21.0	19.0
total.....(GRAMS)	443.0	470.0	430.0
Gas meter coefficient.....	0.9962	0.9962	0.9962
Barometric pressure..(IN.HG)	28.87	28.87	28.87
Avg. orif.pres.drop..(IN.WC)	0.88	0.87	0.82
Avg. gas meter temp..(DEG-F)	82.2	94.7	99.5
Volume through gas meter...			
at meter conditions...(CF)	67.80	68.35	66.62
standard conditions.(DSCF)	63.58	62.65	60.53
standard conditions..(NM ³)	1.800	1.774	1.714
Total sampling time....(MIN)	128.00	128.00	128.00
Nozzle diameter.....(IN)	.237	.237	.237
Avg.stack gas temp ..(DEG-F)	350	356	360
Volumetric flow rate.....			
actual.....(ACFM)	124823	123681	121693
dry standard.....(DSCFM)	59055	57018	56588
Isokinetic variation.....(%)	99.5	101.6	98.9

APPENDIX A


VOLUMETRIC FLOW RATE DETERMINATIONS



INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Source L.P. / Hayward, Cal
 Test Line 1 Draper RTD / Stack
 Run Date 12-14-94
 Stack Dimen. 81.5 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure _____ IN.HG
 Static Pressure -1.50 IN.WC
 Operators M. Campbell + R. ...
 Plot No. 290-D C₀ 101



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
			Port Length: <u>6.25</u> IN.	Time Start: _____ HRS	
4-1	.032	2.01	5.86		
2	.105	9.56	14.91		
3	.194	15.81	22.06		
4	.323	26.32	32.57		
5	.677	55.14	61.43		
6	.806	65.69	71.94		
7	.895	72.94	79.19		
8	.965	79.89	85.14		
B-1					
2					
3					
4					
5					
6					
7					
8					

Temp. Meas. Device & S/N: PDI-31 ITC Time End: _____ HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayswood, Wis Date 7-14-94 Test 14 Run 1
 Source Line 1 Dryer H.P. / Stack No. of traverse points 16
 Method 5 Filter holder: 6123 Filter type: 4" G.F.
 Sample Train Leak Check:

Prerest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 40.02 cfm at 9 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

6745

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles:
 Sample recovered by:

1
M. Kuchler + K. Nussmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	737	506	231
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1440	1429	11
Total			242

Integrated Gas Sampling Data:

Bag Pump No. 238
 Bag Material: 5-layer Aluminized Tedlar
 Prerest leak check: 0
 Time start: 1825
 Sampling rate: 400

Box No. 12 Bag No. 1
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 1840 (HRS)
 cc/min Operator: M. Kuchler

S/N of O₂ Analyzer used to monitor train outlet: 3

INTERPOL LABORATORIES IN METHOD 5 FIELD DATA SHEET

Job No. 2-19-94 / 104
 Supply Point No. 104
 Sampling Time (min) 104

Operator AS
 Inspector AS
 Date 2-19-94

Pilot No. 250
 Bur. Order No. 104
 Horally No. 3-4

Supply Point No.	Sampling Time (min)	Supply Volume (ml)	Volume Added (ml)	Detector Response (mV)	Det. Vol. (ml)	Yield (%)	Blank	Piebb	Temp. (°F)	Temp. (°F)	Case No.	Case No.	Case No.
B-8	1625	328.10	.61	1.04	0.39	4.5	335	242	250	48	94	94	16.2
2	4	360.40	.62	1.10	2.78	4.5	337	247	245	45	97	95	16.5
6	8	392.73	.64	1.14	5.23	5	336	240	252	45	97	95	15.9
5	12	385.19	.61	1.08	2.61	5	337	235	257	45	94	79	16.4
4	16	387.53	.60	1.04	9.91	5	335	233	251	44	86	80	17.0
3	20	309.86	.62	1.08	2.26	5	336	238	246	44	88	81	16.6
2	24	392.20	.64	1.11	4.65	5	338	235	257	44	90	84	16.6
1	28	394.65	.57	1.02	6.71	4	335	233	257	44	91	85	16.6
8	32	396.66	.50	1.06	8.83	4	340	232	252	39	89	85	16.8
7	36	398.80	.65	1.13	12.4	5	343	236	250	39	89	85	16.4
6	40	401.17	.68	1.17	3.70	5.5	348	241	247	41	91	85	16.4
5	44	403.65	.64	1.11	6.09	5	345	244	251	41	92	86	15.9
4	48	406.07	.60	1.04	8.42	5	344	240	254	41	94	87	16.1
3	52	408.45	.52	.92	0.60	4	335	245	256	40	84	83	16.7
2	56	410.65	.50	.86	2.20	4	344	249	258	40	87	84	17.0
1	60	412.73	.53	.91	4.86	4	348	247	252	40	89	84	16.1
	64	414.89											
	1840												
												avg. = 82.9	

2004
10/21
12/30/22

9-23

Down
17/36
18/35
19/36
20/36
21/36
22/36

11 203

v = 36.79

0 = 64

avg. = 82.9

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job A.P. / Hwy work, etc
 Source Line 1 Dyeing RTD / Stack
 Method 5 Filter holder: Glass
 Sample Train Leak Check:

Date 7-14-94 Test 19 Run 2
 No. of traverse points 16
 Filter type: 4" G.F.

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 6 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

6746

Recovery solvent(s)

Acetone _____
 other(s) _____

No. of probe wash bottles:
 Sample recovered by:

1
M. Kachler + R. Messmer

Handwritten: **VOIDED**

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	700	504	196
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1496	1486	10
Total			206

Integrated Gas Sampling Data:

Bag Pump No. 23 B
 Bag Material: 5-layer Aluminized Tedlar
 Prerest leak check: 0
 Time start: 2030
 Sampling rate: 400

Box No. 12 Bag No. 2
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 2138 (HRS)
 cc/min Operator: M. Kachler
3

S/N of O₂ Analyzer used to monitor train outlet:

INTEGRAL CONTAINERS in Method 2 - ELL with Seal
 Job No. 2-24-94 / Haggerty, 661
 Operator's Name: [Handwritten] / [Handwritten]
 Operator Box No. 289 / [Handwritten]
 Date: 2-24-94 / [Handwritten]

Converter Point No.	Sampling Time (min)	Supply Volume (cc)	Volume Flow (L/min)	Dilution Factor (times)	Dilution Volume (cc)	VAC. Inflg	Temperature (°F)				Gas In (cc/v)	Gas Out (cc/v)	Oxygen (cc/v)
							Probe	Down	Top	Up			
A-8	20:30	415.10	.52	.90	7.35	4	330	242	237	45	79	80	13.0
	4	417.58	.64	1.09	9.90	4	332	247	244	45	82	80	12.7
	8	419.92	.66	1.12	2.18	4	336	241	250	44	84	81	17.7
	12	422.29	.65	1.11	4.66	4	333	249	247	45	86	81	17.9
	16	424.65	.58	.99	6.92	4	330	254	238	44	88	82	12.8
	20	426.94	.56	.95	9.13	4	335	250	241	44	89	83	12.4
	24	429.10	.55	.94	1.33	4	339	247	244	44	90	84	17.4
	28	431.32	.52	.88	3.46	3.5	341	245	249	44	90	84	17.1
	32	433.42	.60	1.02	5.76	4	340	240	253	46	88	83	12.5
B-8	36	435.73	.61	1.04	8.07	4	339	250	256	46	90	84	17.3
	40	438.02	.60	1.02	0.36	4	342	253	257	46	90	85	17.7
	44	440.30	.61	1.04	2.67	4	343	249	257	47	91	85	17.4
	48	442.62	.61	1.03	4.98	4	347	255	252	47	92	85	17.4
	52	444.99	.62	1.05	7.31	4	348	251	250	45	91	85	17.4
	56	447.30	.57	.96	9.53	4	350	253	247	44	91	85	17.4
	60	449.53	.55	.93	1.72	4	350	250	245	44	91	85	17.6
	64	451.71											
	21:38												
<p style="text-align: center;">RUN VALID</p>													
<p style="text-align: right;">Avg. = 85.7</p>													
<p style="text-align: right;">Vol. = 36.31</p>													
<p style="text-align: right;">O = 64</p>													

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayward, cal Date 7-14-94 Test 14 Run 3
 Source Line 1 Dryer RTD / 4ack No. of traverse points 16
 Method 5 Filter holder: 6/ecs Filter type: 4" G.F.
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 7 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

6747

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles:

1
Mikaehler + K. Nuessmeier

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	718	500	218
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1450	1440	10
Total			228

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 12 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 6 cc/min at 15 in. Hg.
 Time start: 2230 (HRS) Time end: 2358 (HRS)
 Sampling rate: 400 cc/min Operator: Mikaehler

S/N of O₂ Analyzer used to monitor train outlet: 3

INTERPOLL LABORATORIES TO METHOD B FIELD DATA SHEET

Job Lab. / Hayward, CA
 Survey Line 1, Doger, RTR / Street
 Date 7-19-94

Operator Max Guebert & Associates
 Meter Box No. 11110
 Counter 11110

Pilot No. 24V-3 CP
 Bar. 11110 H2O 22.37
 Horiz. No. 3-4 Horiz. Dia. 245

Converter Point No.	Sampling Time (min)	Supply Volume (cfs)	Velocity Head (ft)	Orifice Meter (ft)	Obs. Vol. (cfs)	VAC. InHg	Temperature (°F)				Oxygen (XY%)		
							Probe	Down	Temp.	Cust/Dst			
β-8	(2230)	452.00	.57	1.02	428	4	349	240	247	45	78	78	17.2
7	4	454.28	.55	.97	650	4	348	243	251	45	80	78	17.5
6	8	456.50	.58	1.02	877	4	350	248	246	45	82	78	17.2
5	12	458.76	.53	.93	0.95	4	350	245	250	44	83	79	17.5
4	16	460.92	.58	1.02	3.24	4	351	247	256	44	84	80	17.1
3	20	463.21	.59	1.05	5.55	4	348	243	252	44	85	80	17.8
2	24	465.51	.60	1.06	7.88	4	349	244	257	45	86	80	17.2
1	28	467.88	.58	1.02	0.17	4	352	246	251	46	87	80	18.2
A-8	32	470.18	.58	1.03	2.46	4	350	242	255	46	85	81	17.7
7	36	472.47	.57	1.02	4.75	4	344	242	252	43	87	81	17.6
6	40	474.86	.64	1.14	7.17	4.5	345	243	256	43	88	82	17.8
5	44	477.15	.61	1.09	9.53	4	347	240	253	43	89	82	17.4
4	48	479.50	.60	1.07	1.87	4	350	237	250	43	89	82	17.0
3	52	481.86	.53	.95	4.08	4	344	242	246	45	93	81	17.7
2	56	484.03	.53	.94	6.28	4	345	245	246	45	82	80	17.7
1	60	486.25	.59	.87	8.39	4	348	241	249	45	93	80	17.1
	64	488.57											
	(2358)												
Σ = 64											Avg. = 82.2		

2550
 2530
 2510
 2490
 2470
 2450
 2430
 2410
 2390
 2370
 2350
 2330
 2310
 2290
 2270
 2250
 2230
 2210
 2190
 2170
 2150
 2130
 2110
 2090
 2070
 2050
 2030
 2010
 1990
 1970
 1950
 1930
 1910
 1890
 1870
 1850
 1830
 1810
 1790
 1770
 1750
 1730
 1710
 1690
 1670
 1650
 1630
 1610
 1590
 1570
 1550
 1530
 1510
 1490
 1470
 1450
 1430
 1410
 1390
 1370
 1350
 1330
 1310
 1290
 1270
 1250
 1230
 1210
 1190
 1170
 1150
 1130
 1110
 1090
 1070
 1050
 1030
 1010
 990
 970
 950
 930
 910
 890
 870
 850
 830
 810
 790
 770
 750
 730
 710
 690
 670
 650
 630
 610
 590
 570
 550
 530
 510
 490
 470
 450
 430
 410
 390
 370
 350
 330
 310
 290
 270
 250
 230
 210
 190
 170
 150
 130
 110
 90
 70
 50
 30
 10

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job LIP. / Hammond, WI Date 7-14-94 Test 14 Run 4
 Source Line 1. Dyeon RTO / Stack No. of traverse points 16
 Method 5 Filter holder: Glass Filter type: 4" G.F.F.

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac)
 Posttest: 20.02 cfm at 7 in. Hg. (vac)

Particulate Catch Data:

No.s of filters used: 6749 Recovery solvent(s)
 acetone
 other(s)
 No. of probe wash bottles: 1
 Sample recovered by: M. Koshler + R. Moysmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	685	491	194
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1507	1496	11
Total			205

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 28 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 0043 (HRS) Time end: 0154 (HRS)
 Sampling rate: 400 cc/min Operator: M. Koshler
 S/N of O₂ Analyzer used to monitor train outlet: 3

CF-023

INTERPOLL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job L.P. / Myself, et
 Source Line 1 Diner 1001
 Date 2-17-94 14 4

Operator Richard L. K...
 Meter Box No. 110
 Corruptor Code 4782

Pitot No. 2-1-V-8
 Bar. Pres. 29.85
 Muzzle No. 304
 City BV
 InHg 14.20
 H₂O 24.2 X
 Muzzle Dia. 3/16
 In.

Transfer Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (inHg)	Orifice Wgts (inHG)	Dep. Vol. (cc)	VAC. inHg	Temperature (°F)				Gas/In	Gas/Out	Oxygen (xv/v)
							Stack	Probe	Duct	Inlet			
A-8	00 44	432.60	.50	.04	0.67	3.5	350	237	240	48	75	75	18.2
7	8	440.61	.55	.91	2.81	4	347	242	245	48	28	76	18.1
6	12	492.93	.65	1.08	5.15	4	350	248	250	47	29	76	17.9
5	16	495.12	.63	1.04	2.85	4	352	252	243	46	91	77	18.2
4	20	497.51	.62	1.03	9.74	4	351	253	240	46	93	77	17.9
3	24	499.69	.54	.90	1.89	4	352	250	245	46	84	77	18.4
2	28	501.00	.52	.87	3.99	4	353	247	249	46	84	78	17.9
1	32	503.91	.51	.85	6.07	4	351	249	249	45	94	79	18.5
B-8	36	506.01	.54	.90	8.22	4	350	253	245	45	94	79	17.9
7	40	508.74	.58	.97	0.45	4	349	254	247	45	86	79	18.3
6	44	510.47	.62	1.04	2.76	4	349	247	250	43	86	80	18.4
5	48	512.78	.64	1.08	5.11	4	350	244	253	43	97	80	18.1
4	52	515.08	.64	1.08	7.46	4	350	247	251	42	97	80	18.1
3	56	517.40	.61	1.02	9.75	4	351	250	255	42	87	80	18.2
2	60	519.71	.62	1.04	2.06	4	352	253	250	42	87	80	18.0
1	64	522.00	.59	.99	4.31	4	353	249	245	42	89	80	18.1
		504.31											
<u>0154</u>													
<u>Q = 64</u>													
<u>V₀ = 35.71</u>													
<u>H = 98</u>													
<u>Avg. = 81.0</u>													


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAYWARD
 Source LINE 1 CYCLE DEBR INLET
 Test 15 Run Date 7-14-94
 Stack Dimen. 42 IN.
 Dry Bulb 25.5 °F Wet bulb 14.3 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.85 IN.HG
 Static Pressure -3.4 IN.WC
 Operators DM + J.E
 Pitor No. 23U-G C, 340
PM/CO/NOx



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: <u>8</u> IN.			Time Start: <u>1445</u> HRS		
A 1	.1032	1.34	9.34	1.00	
2	.105	4.41	12.41	1.10	
3	.194	8.15	16.15	1.20	
4	.323	13.57	21.57	1.30	
5	.677	28.43	36.43	1.55	247
6	.806	33.85	41.85	1.50	
7	.895	37.59	45.59	1.60	
8	.968	40.66	48.66	1.30	
B 1	.032	1.34	9.34	.82	
2	.105	4.41	12.41	.98	
3	.194	8.15	16.15	1.0	
4	.323	13.57	21.57	1.1	
5	.677	28.43	36.43	1.5	247
6	.806	33.85	41.85	1.65	
7	.895	37.59	45.59	1.4	
8	.968	40.66	48.66	1.3	
Temp. Meas. Device & S/N: <u>POT 38</u>				Time End: <u>1455</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

TEMPERATURE RECORDS - FIELD WITH BUREAU

Dr. J. H. HAYWARD
Supt. of Lab. & Coll. Dist. Wash. D.C.
Date 7-17-27

Operator's Name J. J. Hay
Volume Box No. 2
Coulometer Serial No. 9974

Pilot No. 231-4
Bar. Pressure 30.0
Hourly No. 244
Temp. 120
Date July 18, 1927

Coulometer No.	Supply Time (min)	Supply Volume (c.c.)	Vol. of H ₂ (c.c.)	Vol. of O ₂ (c.c.)	Density (g./cc.)	Density (g./cc.)	Vol. (c.c.)	Vol. (c.c.)	V.M.C.	Temperature (°F)				Coul. No.	Coul. Dpt.	Ox. No.
										Blkch	Prbby	Dvbn	Temp.			
4	(1625)	346.80	1.60	2.03	0.08	8	247	237	42	28	76	17.3				
	4	353.10	1.40	1.99	3.35	9	247	240	42	84	76	16.3				
	8	356.45	1.55	2.22	6.81	10	250	240	42	87	76	15.8				
	12	359.68	1.30	1.85	9.17	10	258	241	43	89	77	17.0				
	16	362.62	1.10	1.56	2.87	9	257	245	43	91	77	16.8				
	20	365.57	1.15	1.64	5.88	9	255	250	43	93	78	16.3				
	24	364.60	1.10	1.57	8.8	10	256	250	43	93	77	16.5				
	28	371.74	1.20	1.72	1.87	11	255	248	43	94	79	16.5				
	32	375.26	1.60	2.29	5.41	14	225	251	43	94	77	16.4				
	36	378.75	1.50	2.15	8.84	14	255	251	43	90	79	16.2				
	40	381.95	1.30	1.85	2.01	13	256	247	45	90	80	16.4				
	44	384.87	1.10	1.58	4.85	12	250	250	45	93	80	16.10				
	48	387.95	1.98	1.42	7.74	9	246	255	44	93	80	15.7				
	52	390.76	1.0	1.46	0.57	10	241	242	46	96	82	15.8				
	56	393.54	1.0	1.47	3.41	10	243	245	46	93	82	16.2				
	60	396.27	1.93	1.35	6.13	10	242	245	46	90	82	16.2				
	64															
	(1840)															

v. = 49.47
v. = 17.6
v. = 34.5

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P./HAYWARD Date 7-14-94 Test 15 Run 1
 Source LINE 1 CARL DRYER INLET No. of traverse points 16
 Method 5 Filter holder: SS Filter type: SS
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s) _____

SS # 37

acetone _____

other(s) _____

No. of probe wash bottles: _____

Sample recovered by: _____

1

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	1116	795	321
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1480 1511	1500 1490	21
Total			342

Integrated Gas Sampling Data:

Bag Pump No. 394
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1625
 Sampling rate: 400

Box No. 33 Bag No. 1
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 1840 (HRS)
 cc/min Operator: 0.11

S/N of O₂ Analyzer used to monitor train outlet: _____

5

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / Hayward Date 7-14-94 Test 15 Run 2
 Source Line Core Dryer Exit No. of traverse points 16
 Method 5 Filter holder: SS Filter type: SS
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 10 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: SS #35 Recovery solvent(s):
 Acetone _____
 other(s) _____
 No. of probe wash bottles: _____
 Sample recovered by: DH

*RUN
VOIDED*

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			297
Impinger No. 3			
Condenser			
Desiccant	1405	1385	20
Total			317

Integrated Gas Sampling Data:

Bag Pump No. 29A Box No. 30 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 2031 (HRS) Time end: 2136 (HRS)
 Sampling rate: 400 cc cc/min Operator: DH

S/N of O₂ Analyzer used to monitor train outlet: 5

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job: LP / Hwy ward
 Site: 1001315
 Date: 7-14-84
 Operator: DM + JJ
 Meter Box No: 2
 Meter No: 122
 Time: 12:24
 Pict No: 230-6
 Bar. Pres. 33.5
 Humidity: 84
 Wind Dir: 232
 Wind Spd: 10

Temp. Point No.	Sampling Time (min)	Supply Volume (cft)	Velocity Head (ft)	Drifts Meter (ft)	Dep. Vol. (cft)	VAD. (ft)	Temperature (°F)				Cust. Cnt/Dpt	Kv/Vd
							Blank	Probe	Dry	Wet		
8	2030	387.10	1.50	1.97	0.32	7	251	240	43	81	78	17.5
7	4	400.31	1.60	1.10	3.74	9	247	241	43	85	78	17.5
6	8	403.59	1.40	1.84	6.89	10	248	239	43	85	78	17.2
5	12	406.84	1.20	1.58	9.82	9	248	245	44	87	77	17.4
4	16	409.85	1.10	1.44	11.62	9	250	245	45	88	77	17.0
3	20	412.58	1.05	1.38	13.36	9	247	243	44	89	77	17.0
2	24	415.30	1.00	1.32	18.09	9	246	250	46	90	77	17.1
1	28	417.94	.96	1.27	20.62	9	245	250	46	87	77	16.5
8	32	420.67	1.50	1.98	23.95	13	245	245	46	82	77	17.0
7	36	423.78	1.30	1.71	27.00	14	248	251	47	53	78	16.6
6	40	427.90	1.30	1.71	30.05	14	250	250	46	57	77	16.6
5	44	429.95	1.35	1.77	33.15	15	249	247	46	56	77	16.4
4	48	433.02	1.10	1.45	36.96	15	247	245	48	55	77	16.4
3	52	436.00	1.20	1.58	40.88	15	246	245	48	54	78	16.5
2	56	438.95	1.20	1.57	44.80	16	249	250	48	53	77	16.6
1	60	441.89	1.20	1.57	48.71	16	250	255	49	53	77	15.7
	64	444.86	1.20	1.57								
<p><i>Handwritten:</i> 2/4/84 40102</p>												
											avg. =	36.5

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Hawwood Date 7-14-94 Test 15 Run 3
 Source Line 1 - 1000 Dwyer RTO Filter No. of traverse points 16
 Method 5 Filter holder: SS Filter type: SS
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 17 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

Set # 38

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles:
 Sample recovered by:

1
DM

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	1144	800	344
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1526	1510	16
Total			360

Integrated Gas Sampling Data:

Bag Pump No. 29 A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 2:25
 Sampling rate: 400 cc

Box No. 30 Bag No. 3
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 2:57 (HRS)
 cc/min Operator: DM

S/N of O₂ Analyzer used to monitor train outlet:

705
539

5

INTERPOL LABORATORIES EPA METHOD 8 FIELD DATA SHEET

Job: LP/Hog Wash
Supply Point No: 2
Date: 12/15/85
Operator: DM
Pilot No: 230-6
Bar. Press: 28.85
Bar. No: 24

Operator Box No: 2
Generator coil: 2
Time: 1:22
Temp: 49.74

Supply Point No: 2
Supply Flow (gpm): 2230
Supply Volume (gal): 448.53
Supply Volume (gal): 451.69
Supply Volume (gal): 454.78
Supply Volume (gal): 457.77
Supply Volume (gal): 460.75
Supply Volume (gal): 463.62
Supply Volume (gal): 466.62
Supply Volume (gal): 469.60
Supply Volume (gal): 472.77
Supply Volume (gal): 475.55
Supply Volume (gal): 479.15
Supply Volume (gal): 482.23
Supply Volume (gal): 485.18
Supply Volume (gal): 488.01
Supply Volume (gal): 490.73
Supply Volume (gal): 493.50

Supply Point No.	Supplying Flow (gpm)	Supply Volume (gal)	Velocity Head (in H ₂ O)	Orifice Meter (in H ₂ O)	Diff. Vols. (gal)	Vac. In Hg	Blank	Probe	Temp. (°F)	Bar. No.	Bar. Press.	Ox. Vol. (XV/V)
2	2230	448.53	1.60	2.16	8.73	8	249	240	43	74	18	16.2
2	4	451.69	1.40	1.85	1.89	9	250	243	43	80	77	16.2
6	13	454.78	1.40	1.84	5.04	10	255	250	44	89	77	16.1
5	16	457.77	1.20	1.59	7.97	10	255	250	44	86	76	16.7
4	20	460.75	1.10	1.46	8.78	11	252	247	44	88	76	16.7
3	24	463.62	1.20	1.60	3.73	11	250	251	45	88	76	16.8
3	28	466.62	1.10	1.47	6.56	11	251	247	44	88	76	16.3
1	32	469.60	1.20	1.60	9.50	13	250	255	46	87	76	17.1
8	36	472.77	1.20	1.87	2.80	14	250	257	46	86	76	16.8
7	40	475.55	1.40	1.87	5.97	16	250	248	45	84	75	16.4
4	44	479.15	1.40	1.85	7.14	17	253	251	45	83	75	16.7
5	48	482.23	1.20	1.59	2.06	17	253	250	45	83	75	16.7
4	52	485.18	1.10	1.46	4.87	15	251	255	44	89	74	17.0
3	56	488.01	1.10	1.45	7.66	15	251	254	44	79	75	16.7
3	60	490.73	1.10	1.46	0.46	13	247	247	45	74	74	16.5
1	64 (2400)	493.50	1.05	1.37	3.17	14	254	248	46	77	71	17.0

Avg. = 78.9

ΔH = 1.66

V. = 48.20

Q = 69

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / Hayward Date 7-14-91 Test: 15 Run 4
 Source Line 1 Cont. Degas RTO Inlet No. of traverse points 16
 Method 5 Filter holder: 55 Filter type: 50
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 50.00 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

55 # 33

Recovery solvent(s)

acetone _____
 other(s) _____

No. of probe wash bottles:
 Sample recovered by:

1
D.M.

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	1148	502	346
Impinger No. 2	1148		346
Impinger No. 3			
Condenser			
Desiccant	1378	1360	18
Total			346 364

Integrated Gas Sampling Data:

Bag Pump No. 39A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 0048
 Sampling rate: 400

Box No. 25 Bag No. 1
 Size: 4.5
15 in. Hg.
 (HRS) Time end: 0151 (HRS)
 cc/min Operator: D.M.

S/N of O₂ Analyzer used to monitor train outlet:

692 503
501 300

5


INTERPOLL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job: LP / Highway 1
 Sample Line: 1
 Date: 5-15-84
 Operator: Rife
 Meter Box No: 279-241
 Counter No: 279-241
 Pipet No: 230-6
 Bar. Press: 30.0
 Humidity: 84%
 Bar. No: 279-241
 Date: 5-15-84
 Time: 11:27 AM

Traverse Point No.	Sampling Time (min)	Sample Volume (lit)	Velocity Head (cmH ₂ O)	Orifice Meter (cmH ₂ O)	Dep. Vol. (lit)	VAD. Initial	Blank	Prob	Dybn	Inpg.	Cherlin	Gas/Dpt	Oxygpn (XV/V)	
														Temp (°F)
2	09:48	497.28	1.40	1.78	7.30	7	250	241	43	72	72	70	17.9	
7	2	450.30	1.30	1.69	0.25	7	248	242	43	72	72	70	17.8	
6	13	503.27	1.40	1.76	3.31	7	249	243	43	72	72	70	17.3	
5	16	506.27	1.35	1.70	6.0	8	251	252	44	72	72	70	17.6	
4	20	509.06	1.05	1.33	9.00	7	250	255	44	72	72	70	17.4	
3	24	511.66	1.0	1.27	1.61	7	249	241	45	72	72	70	17.7	
2	28	514.20	.98	1.25	4.21	7	248	239	45	72	72	70	17.5	
1	33	517.26	.98	1.25	6.80	7	249	251	44	72	72	70	18.0	
2	36	520.29	1.50	1.91	0.00	9	250	255	43	72	72	70	17.8	
7	40	523.52	1.60	2.04	3.31	11	249	249	43	72	72	70	17.7	
6	44	526.75	1.50	1.91	6.51	11	252	250	45	72	72	70	18.1	
5	48	529.97	1.40	1.78	9.61	11	250	257	47	72	72	70	17.4	
4	52	532.90	1.30	1.66	2.59	10	250	261	47	72	72	70	17.7	
3	56	536.00	1.50	1.91	5.80	11	245	257	43	72	72	70	17.9	
2	60	539.14	1.35	1.72	8.84	11	249	255	43	72	72	70	17.4	
1	64	542.19	1.30	1.65	1.23	11	250	250	48	72	72	70	17.4	
	(0151)													
												v. = 47.99	w. = 1.66	avg. = 76.4

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LP (HAYWARD)
 Source LINE 1 Surface Dryer ETO DRYER
 Test 16 Run 1 Date 7-15-94
 Stack dimen. 42.0 IN.
 Dry bulb 269 °F Wet bulb 155 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.57 in Hg
 Static pressure -10.80 in WC
 Operators B. Baker, L. J. Johnson
 Pitot No. 270-6 C_p .84



Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>8</u> in.		Time start: <u>1000</u> hrs	
A	1			<u>1.50</u>	
	2			<u>1.32</u>	
	3			<u>1.47</u>	
	4			<u>1.24</u>	
	5			<u>1.42</u>	
	6			<u>1.58</u>	
	7			<u>1.82</u>	
	8			<u>1.50</u>	
B	1			<u>1.27</u>	
	2			<u>1.38</u>	
	3			<u>1.34</u>	
	4			<u>1.50</u>	
	5			<u>1.67</u>	
	6			<u>2.21</u>	
	7			<u>1.85</u>	
	8			<u>1.12</u>	
Temp. meas. device & S/N: <u>DDT 32</u>				Time end: <u>1010</u> hrs	

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LP STAYWARD
 Source LINE 1 Sv. Rec. Drg. PTO Pile
 Test 16 Run Z Date 2-15-94
 Stack dimen. 42 IN.
 Dry bulb 274 °F Wet bulb 162 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.57 in Hg
 Static pressure -10.48 in WC
 Operators B. Schuler
 Pitot No. 27L-6 Cp .86

Cross-section View SEE Run <u>1</u>	Elevation View
--	--

Drawing of Test Site _____

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
			Port length: <u>80</u> in.	Time start: <u>1320</u> hrs	
B	1			1.31	
	2			1.28	
	3			1.36	
	4			1.21	274
	5			1.22	
	6			1.30	
	7			1.50	
	8			1.90	
A	1			1.60	
	2			2.21	
	3			2.07	
	4			1.31	276
	5			1.84	
	6			1.85	
	7			1.73	
	8			1.89	
Temp. meas. device & S/N: <u>PPT 22</u>				Time end: <u>1330</u> hrs	

Test No. 1
Line 2 Dryer RTO Outlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	752
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81.5
Duct area.....(SQ.FT)	36.23
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.61
Avg. gas temp.....(DEG-F)	324
Moisture content.....(% V/V)	21.66
Avg. linear velocity.....(FT/SEC)	59.4
Gas density.....(LB/ACF)	.04490
Molecular weight.....(LB/LBMOLE)	29.23
Mass flow of gas.....(LB/HR)	347932
Volumetric flow rate.....	
actual.....(ACFM)	129156
dry standard.....(DSCFM)	65280

Test No. 2
Line 2 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	846
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-16.3
Avg. gas temp.....(DEG-F)	199
Moisture content.....(% V/V)	20.63
Avg. linear velocity.....(FT/SEC)	94.5
Gas density.....(LB/ACF)	.05148
Molecular weight.....(LB/LBMOLE)	29.21
Mass flow of gas.....(LB/HR)	168433
Volumetric flow rate.....	
actual.....(ACFM)	54530
dry standard.....(DSCFM)	31896

Test No. 3
Line 2 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	846
Barometric pressure.....(IN.HG)	28.71
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-16.4
Avg. gas temp.....(DEG-F)	235
Moisture content.....(% V/V)	24.15
Avg. linear velocity.....(FT/SEC)	87.7
Gas density.....(LB/ACF)	.04811
Molecular weight.....(LB/LBMOLE)	29.24
Mass flow of gas.....(LB/HR)	146123
Volumetric flow rate.....	
actual.....(ACFM)	50626
dry standard.....(DSCFM)	26816

Test No. 5
Line 2 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	1854
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-17.1
Avg. gas temp.....(DEG-F)	209
Moisture content.....(% V/V)	21.36
Avg. linear velocity.....(FT/SEC)	91.8
Gas density.....(LB/ACF)	.05039
Molecular weight.....(LB/LBMOLE)	29.17
Mass flow of gas.....(LB/HR)	160247
Volumetric flow rate.....	
actual.....(ACFM)	53003
dry standard.....(DSCFM)	30194

Test No. 5
Line 2 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	2018
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-17.1
Avg. gas temp.....(DEG-F)	210
Moisture content.....(% V/V)	22.63
Avg. linear velocity.....(FT/SEC)	93.1
Gas density.....(LB/ACF)	.05005
Molecular weight.....(LB/LBMOLE)	29.17
Mass flow of gas.....(LB/HR)	161380
Volumetric flow rate.....	
actual.....(ACFM)	53741
dry standard.....(DSCFM)	30077

Test No. 5
Line 2 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	2100
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-16.4
Avg. gas temp.....(DEG-F)	211
Moisture content.....(% V/V)	20.00
Avg. linear velocity.....(FT/SEC)	92.1
Gas density.....(LB/ACF)	.05062
Molecular weight.....(LB/LBMOLE)	29.17
Mass flow of gas.....(LB/HR)	161416
Volumetric flow rate.....	
actual.....(ACFM)	53147
dry standard.....(DSCFM)	30767

Test No. 6
Line 2 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	1834
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-15.4
Avg. gas temp.....(DEG-F)	225
Moisture content.....(% V/V)	24.72
Avg. linear velocity.....(FT/SEC)	85.7
Gas density.....(LB/ACF)	.04893
Molecular weight.....(LB/LBMOLE)	29.30
Mass flow of gas.....(LB/HR)	145194
Volumetric flow rate.....	
actual.....(ACFM)	49461
dry standard.....(DSCFM)	26463

Test No. 6
Line 2 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	2039
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-15.3
Avg. gas temp.....(DEG-F)	253
Moisture content.....(% V/V)	20.29
Avg. linear velocity.....(FT/SEC)	79.0
Gas density.....(LB/ACF)	.04791
Molecular weight.....(LB/LBMOLE)	29.30
Mass flow of gas.....(LB/HR)	131085
Volumetric flow rate.....	
actual.....(ACFM)	45605
dry standard.....(DSCFM)	24829

Test No. 6
Line 2 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-12-94
Time of Determination.....(HRS)	2159
Barometric pressure.....(IN.HG)	28.72
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	24
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-15.2
Avg. gas temp.....(DEG-F)	239
Moisture content.....(% V/V)	24.92
Avg. linear velocity.....(FT/SEC)	84.4
Gas density.....(LB/ACF)	.04793
Molecular weight.....(LB/LBMOLE)	29.30
Mass flow of gas.....(LB/HR)	140084
Volumetric flow rate.....	
actual.....(ACFM)	48710
dry standard.....(DSCFM)	25486

Test No. 11
Line 1 Dryer RTO Outlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-13-94
Time of Determination.....(HRS)	820
Barometric pressure.....(IN.HG)	28.94
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	81.5
Duct area.....(SQ.FT)	36.23
Direction of flow.....	UP
Static pressure.....(IN.WC)	-.48
Avg. gas temp.....(DEG-F)	342
Moisture content.....(% V/V)	23.75
Avg. linear velocity.....(FT/SEC)	49.2
Gas density.....(LB/ACF)	.04403
Molecular weight.....(LB/LBMOLE)	29.35
Mass flow of gas.....(LB/HR)	282777
Volumetric flow rate.....	
actual.....(ACFM)	107049
dry standard.....(DSCFM)	51914

Test No. 13
Line 1 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-14-94
Time of Determination.....(HRS)	1445
Barometric pressure.....(IN.HG)	28.85
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-10.2
Avg. gas temp.....(DEG-F)	262
Moisture content.....(% V/V)	26.08
Avg. linear velocity.....(FT/SEC)	85.6
Gas density.....(LB/ACF)	.04707
Molecular weight.....(LB/LBMOLE)	29.35
Mass flow of gas.....(LB/HR)	139553
Volumetric flow rate.....	
actual.....(ACFM)	49418
dry standard.....(DSCFM)	25089

Test No. 15
Line 1 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-14-94
Time of Determination.....(HRS)	1445
Barometric pressure.....(IN.HG)	28.85
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-8.399999
Avg. gas temp.....(DEG-F)	247
Moisture content.....(% V/V)	25.82
Avg. linear velocity.....(FT/SEC)	78.4
Gas density.....(LB/ACF)	.04835
Molecular weight.....(LB/LBMOLE)	29.35
Mass flow of gas.....(LB/HR)	131248
Volumetric flow rate.....	
actual.....(ACFM)	45242
dry standard.....(DSCFM)	23650

Test No. 16
Line 1 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-15-94
Time of Determination.....(HRS)	1000
Barometric pressure.....(IN.HG)	28.87
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-10.8
Avg. gas temp.....(DEG-F)	269
Moisture content.....(% V/V)	26.34
Avg. linear velocity.....(FT/SEC)	87.4
Gas density.....(LB/ACF)	.04646
Molecular weight.....(LB/LBMOLE)	29.30
Mass flow of gas.....(LB/HR)	140623
Volumetric flow rate.....	
actual.....(ACFM)	50441
dry standard.....(DSCFM)	25252

Test No. 16
Line 1 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-15-94
Time of Determination.....(HRS)	1320
Barometric pressure.....(IN.HG)	28.87
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-10.48
Avg. gas temp.....(DEG-F)	275
Moisture content.....(% V/V)	31.96
Avg. linear velocity.....(FT/SEC)	91.2
Gas density.....(LB/ACF)	.04501
Molecular weight.....(LB/LBMOLE)	29.30
Mass flow of gas.....(LB/HR)	142135
Volumetric flow rate.....	
actual.....(ACFM)	52629
dry standard.....(DSCFM)	24160

Test No. 16
Line 1 Surface Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-15-94
Time of Determination.....(HRS)	1340
Barometric pressure.....(IN.HG)	28.87
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-8.3
Avg. gas temp.....(DEG-F)	272
Moisture content.....(% V/V)	25.20
Avg. linear velocity.....(FT/SEC)	84.0
Gas density.....(LB/ACF)	.04681
Molecular weight.....(LB/LBMOLE)	29.30
Mass flow of gas.....(LB/HR)	136212
Volumetric flow rate.....	
actual.....(ACFM)	48502
dry standard.....(DSCFM)	24718

Test No. 18
Line 1 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-15-94
Time of Determination.....(HRS)	1010
Barometric pressure.....(IN.HG)	28.87
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-7.21
Avg. gas temp.....(DEG-F)	234
Moisture content.....(% V/V)	21.02
Avg. linear velocity.....(FT/SEC)	77.4
Gas density.....(LB/ACF)	.05045
Molecular weight.....(LB/LBMOLE)	29.34
Mass flow of gas.....(LB/HR)	135271
Volumetric flow rate.....	
actual.....(ACFM)	44691
dry standard.....(DSCFM)	25437

Test No. 18
Line 1 Core Dryer RTO Inlet

Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-15-94
Time of Determination.....(HRS)	1330
Barometric pressure.....(IN.HG)	28.87
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-8.82
Avg. gas temp.....(DEG-F)	252
Moisture content.....(% V/V)	18.51
Avg. linear velocity.....(FT/SEC)	80.6
Gas density.....(LB/ACF)	.04948
Molecular weight.....(LB/LBMOLE)	29.34
Mass flow of gas.....(LB/HR)	138086
Volumetric flow rate.....	
actual.....(ACFM)	46510
dry standard.....(DSCFM)	26512


Test No. 18
Line 1 Core Dryer RTO Inlet


Results of Volumetric Flow Rate Determination-----Method 2

Date of Determination.....	07-15-94
Time of Determination.....(HRS)	1350
Barometric pressure.....(IN.HG)	28.87
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	16
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-9.58
Avg. gas temp.....(DEG-F)	260
Moisture content.....(% V/V)	18.91
Avg. linear velocity.....(FT/SEC)	90.2
Gas density.....(LB/ACF)	.04875
Molecular weight.....(LB/LBMOLE)	29.34
Mass flow of gas.....(LB/HR)	152244
Volumetric flow rate.....	
actual.....(ACFM)	52046
dry standard.....(DSCFM)	29134


APPENDIX B

LOCATION OF TEST PORTS







HAYWARD, WI
 DRAWING 1
 RTO GENERAL
 PLANT ARRANGEMENT





HAYWARD, WI
 DRAWING 2
 DRYER RTO STACK
 (TYPICAL FOR BOTH LINES)
 ELEVATION



HAYWARD, WI
 DRAWING 3
 GAS FLOW FROM
 LINE 1 DRYERS
 TO RTO
 ELEVATION








HAYWARD
DRAWING 6
GAS FLOW FROM...
LINE 1 DRYERS
TO RTO
PLAN

APPENDIX C


LINE 1 RTO FIELD DATA SHEETS



INTERPOLL LABORATORIES, INC.
 (612) 786-6020
 EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAZWCLD
 Source LINE 1 DRYER LTD - STACK
 Test 11 Run 2 Date 7-13-94
 Stack Dimen. 81.5 IN.
 Dry Bulb 342 °F Wet bulb 154 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.94 IN.HG
 Static Pressure -.48 IN.WC
 Operators E. TRUWICK/DAA
 Pitot No. 4445-8 C₂ 1840



CH₂O

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6.25</u> IN.		Time Start: <u>0820</u> HRS	
A 1	.072	2.61	9.85	.40	
2	.105	4.56	14.80	.55	
3	.144	15.81	22.06	.60	
4	.323	26.32	32.51	.59	342
5	.677	55.17	61.42	.61	
6	.806	65.68	71.93	.60	
7	.895	72.94	79.19	.57	
8	.968	78.89	85.14	.55	
B 1				.30	
2				.25	
3				.28	
4				.43	342
5				.40	
6				.43	
7				.42	
8				.41	

Temp. Meas. Device & S/N:

POT-38

Time End: 0833 HRS

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/HAYWARD Date 7-13-94 Test 11 Run 1
 Source LINE 1 DRUM RTD - STATIC No. of traverse points 16
 Method 5001 Filter holder: NA Filter type: NA
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 7 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: NA Recovery solvent(s)
 acetone
 Other(s) MICL₂
 No. of probe wash bottles: 1
 Sample recovered by: FT

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		{ 200 }	
Impinger No. 2	527		327
Impinger No. 3			
Condenser			
Desiccant	1504	1468	36
Total			363

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 6 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1201 (HRS) Time end: 1306 (HRS)
 Sampling rate: 400 cc/min Operator: FT
 S/N of O₂ Analyzer used to monitor train outlet: 3

INTERPOLL LABORATORIES - PA METHOD 5 FIELD DATA SHEET

Job LA Highway
 Sample EXP. CONC TO STACK
 Date 2-13-82

Operator ET-JS
 Meter Box No. 4
 Recorder 4022

Pilot No. 205
 Bar. Pres. 28.99
 Meters No. 4252

Cp .87
 InHg 120
 In. 18

Traverse Point No.	Sampling Time (min)	Sample Volume (gts)	Velocity (ft/min)	Droplet Miter (min)	Des. Vol. (gts)	VAD. (inHg)	Temperature (°F)						Oxygcn (X/V)
							Block	Probe	Dry	Wet	Case In	Case Out	
B	800	197.90	1.65	2.77	1.02	6	228	248	45	71	70	16.8	
8	4	201.60	1.70	2.90	5.40	7	230	251	45	74	71	16.8	
7	8	205.40	1.48	2.90	9.20	7	230	253	45	76	71	16.9	
6	12	209.15	1.66	2.85	8.91	7	228	249	42	77	72	17.0	
5	16	212.80	1.58	2.49	6.49	6	229	251	42	80	73	17.0	
4	20	216.40	1.54	2.30	9.89	6	230	248	43	81	74	17.4	
3	24	219.90	1.50	2.14	3.17	5	230	252	43	83	74	16.6	
2	28	223.15	1.50	2.15	4.46	5	228	250	43	83	75	16.6	
1	32	226.45	1.57	2.45	9.97	6	231	252	48	83	75	16.7	
A	34	229.98	1.48	2.91	5.80	7	233	251	48	86	78	17.0	
8	40	233.74	1.48	2.92	7.64	7	230	250	48	87	79	17.2	
7	44	237.60	1.46	2.82	1.42	7	235	255	52	87	79	16.7	
6	48	241.38	1.44	2.78	5.17	7	233	253	52	87	79	16.5	
5	52	245.18	1.62	2.67	8.85	7	234	250	51	88	80	16.9	
4	56	248.90	1.56	2.40	7.54	6	232	249	51	88	80	17.1	
3	60	252.39	1.53	2.25	5.72	6	230	247	50	89	81	16.7	
2	64	255.75											
1	64												
(1307)													
		V ₁ = 57.85									AVG. = 790		
		Q = 64											

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/HAYWARD Date 7-13-84 Test 11 Run 2
 Source LINE 1 DRINK BTO STACK No. of traverse points 16
 Method SOOL Filter holder: NA Filter type: NA
 Sample Train Leak Check:

Pre-test: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 7 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: NA Recovery solvent(s)
 acetone _____
 other(s) MECL
 No. of probe wash bottles: 1
 Sample recovered by: ET

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		{ 100 }	
Impinger No. 2	<u>154</u>		
Impinger No. 3			
Condenser			
Desiccant	<u>1535</u>	<u>1505</u>	<u>30</u>
Total			<u>364</u>

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 6 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1428 (HRS) Time end: 1532 (HRS)
 Sampling rate: 400 cc/min Operator: ET
 S/N of O₂ Analyzer used to monitor train outlet: 3

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job: 61/HAYWARD
Source: LINE 1 DRILL RTO STACK
Date: 7-13-82 1061 H
HPI: 2

Operator: J.A.S.
Motor Box No.: 9
Computer Unit: 182 TN MC
1226 R

Pilot No. 4258
But. Press: 28.74
Motor No. 4258
City: OROVILLE
State: CA

Traverse Point No.	Sampling Time (min)	Supply Volume (gal)	Velocity Head (inH ₂ O)	Driftless Water (inH ₂ O)	Des. Vbl. (gal)	VAC. (inH ₂ O)	Stack	Probe	Dye	Temp. (°F)	Temp. (°F)	Cus/In	Cus/Dvt	Oxygen (X%/V)
A 8	1427	258.60	1.54	2.15	1.89	✓	346	232	248	46	83	78	15.9	
7	4	261.94	1.58	2.32	5.31	6	344	232	251	46	85	79	15.5	
4	12	268.80	1.60	2.41	8.80	6	344	235	249	46	88	80	16.2	
5	16	272.30	1.62	2.57	2.37	6	339	230	252	45	88	81	15.7	
4	20	275.75	1.58	2.34	5.82	6	343	232	250	45	89	81	15.7	
3	24	279.29	1.62	2.50	9.39	6	343	230	253	46	89	81	17.4	
2	28	282.77	1.55	2.24	2.77	6	338	230	251	46	89	82	16.4	
1	32	286.04	1.52	2.11	6.05	5	339	231	250	46	89	82	18.0	
B 8	34	289.65	1.60	2.46	9.59	6	332	228	229	57	90	83	17.3	
7	36	293.25	1.68	2.75	3.34	6.5	342	232	260	57	90	83	16.7	
6	39	297.00	1.66	2.70	7.05	6.5	335	232	259	52	90	83	16.0	
5	42	301.62	1.64	2.61	0.70	6	337	229	257	50	90	83	16.7	
4	48	304.01	1.54	2.20	4.05	6	337	231	254	51	90	83	16.9	
3	52	307.31	1.52	2.14	7.36	5	332	230	255	51	90	83	16.8	
2	60	310.62	1.50	2.06	0.60	5	331	228	252	50	91	83	17.1	
1	64 (1533)	313.80	1.48	1.98	3.78	5	330	229	250	50	91	83	17.1	
<div style="display: flex; justify-content: space-between;"> V = 55,20 W = 2.34 Avg. = 85.3 </div>														

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/HAYWARD Date 7-13-54 Test 11 Run 3
 Source LAND FRYING OIL STACK No. of traverse points 16
 Method SABO Filter holder: NA Filter type: NA
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 6 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone
 other(s) MCCl₄

No. of probe wash bottles:

1

Sample recovered by:

ET

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		100	337
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1427	1392	35
Total			372

Integrated Gas Sampling Data:

Bag Pump No. 238
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1613
 Sampling rate: 400

Box No. 0 Bag No. 3
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 1719 (HRS)
 cc/min Operator: ET

S/N of O₂ Analyzer used to monitor train outlet: 3

INTERPOL LABORATORIES - PD METHOD 2 FIELD DATA SHEET

Job CP/MA/DMAP
 Source LINE 1 PAPER R70 - STAC
 Date 2-25-94 1981 11 Nov 3
 Operator CP/MA
 Motor Box No 4
 Counter Volt. 9402
 Pilot No. 243-3
 Bar. Press. 29.8
 Moist. No. 255
 Op. 184
 InHg 1120
 RH 33

Gravity Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (inHg)	Drifting Meter (inHg)	Dep. Vol. (cc)	VAC. InHg	Temperature (°F)						Oxygen (x/v)
							Stack	Prubb	Dry	Impy.	Gas/In	Gas/Out	
B	1612	319.10	165	2.59	7.73	4	231	248	48	81	79	17.3	
	4	317.80	148	2.70	1.42	6	232	253	48	82	79	16.3	
	8	321.45	170	2.74	5.13	6	255	250	49	85	80	16.5	
	12	325.17	164	2.53	8.71	6	235	252	51	84	81	16.5	
	16	328.84	152	2.05	1.94	6	234	251	51	87	81	16.0	
	20	332.05	150	1.98	5.11	5	232	250	52	87	81	16.3	
	24	335.25	148	1.92	8.24	5	230	253	51	88	81	16.6	
	28	338.28	148	1.92	1.57	5	230	251	51	88	82	16.5	
	32	341.40	158	2.31	1.80	6	235	248	50	88	82	16.2	
A	36	344.90	162	2.47	9.34	6	231	249	51	88	82	16.6	
	40	348.40	164	2.56	1.94	6	233	255	51	88	82	16.1	
	44	351.90	160	2.55	5.54	6	230	253	51	89	83	16.0	
	48	355.50	160	2.47	9.05	6	234	250	50	90	83	16.4	
	52	359.06	162	2.47	8.60	6	231	248	50	90	83	16.3	
	56	362.65	158	2.33	6.05	6	229	247	50	90	83	16.6	
	60	366.10	152	2.09	9.32	5	230	246	50	90	83	15.8	
	64	369.35											
	(1720)												
	0 = 64	V = 55.25		11 20.35									
												Avy. = 87.4	

INTERPOLL LABORATORIES

Method 18 Field Data Sheet

Job LP/Hayward
 Source Line 7 Dyeing KTC 3 tank
 Date 7-15-94 Test 12 Run 1

Operator(s) DM + KN
 Meter Box No. 25 Meter coef. 1.078
 Barometric Pressure 29.96 in.Hg

Sample Train Leak Check:
 Pretest: 0 cc/min at 20 in.Hg
 Posttest: 0 cc/min at 15 in.Hg

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Sample Rate (cc/min)	VAC. (inHg)	Temperature (oF)		
					Stack	Probe	Gasmeter
	(0922)	(483.200)					
A 3	5	483.401	1000	4	350	240	74
3	10	483.608	1000	4	351	242	74
3	15	483.750	1000	4	353	247	75
3	20	483.929	1000	4	353	245	77
2	25	484.105	1000	4	353	250	79
2	30	484.282	1000	4	352	251	80
2	35	484.462	1000	4	342	241	82
2	40	484.646	1000	4	342	241	84
1	45	484.827	1000	4	342	257	85
1	50	484.990	1000	4	345	255	87
1	55	485.164	1000	4	345	250	88
(1025)	60	485.338	1000	4	345	251	90
	$\theta = 60$	$V_m = 2.138$					$t_m = 81$

$\sqrt{STD} = 2.029$

INTERPOLL LABORATORIES

Method 18 Field Data Sheet

Job LP/Hayward
 Source Line 1 Dryer RTO Stack
 Date 7-15-94 Test 12 Run 2

Operator(s) DM + KN
 Meter Box No. 25 Meter coef. 1.0079
 Barometric Pressure 28.86 in.Hg

Sample Train Leak Check:

Pretest: 6 cc/min at 20 in.Hg
 Posttest: 0 cc/min at 15 in.Hg

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Sample Rate (cc/min)	VAC. (inHg)	Temperature (oF)		
					Stack	Probe	Gasmeter
	(1257)	485.530					
0	3	485.685	1000	4	357	251	88
	3	485.834	1000	5	357	249	88
	3	485.982	1000	6	348	245	88
	3	486.135	1000	6	348	245	90
	2	486.285	1000	6	353	250	93
	2	486.455	1000	6	348	252	94
	2	486.579	1000	2	348	252	94
	2	486.744	1000	8	351	248	96
	1	486.988	1000	7	362	250	96
	1	487.053	1000	8	363	251	97
	1	487.215	1000	8	360	248	99
	1	487.384	1000	8	360	250	100
	0 = 60	Vm = 1.854					tm = 94

(1357)

VSTD = 1.718

INTERPOLL LABORATORIES

Method 18 Field Data Sheet

Job LP / Hayward
 Source Line 1 Dryer RTD Stack
 Date 7-15-94 Test 2 Run 3

Operator(s) DM + KN
 Meter Box No. 23 Meter coef. 1.0078
 Barometric Pressure 28.86 in.Hg

Sample Train Leak Check:
 Pretest: 0 cc/min at 20 in.Hg
 Posttest: 0 cc/min at 15 in.Hg

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Sample Rate (cc/min)	VAC. (inHg)	Temperature (oF)		
					Stack	Probe	Gasmeter
	(1408)	487.509					
C 3	5	487.605	1000	4	351	248	104
3	10	487.829	1000	4	366	250	104
3	15	487.990	1000	7	366	250	104
3	20	488.159	1000	7	346	255	105
3	25	488.327	1000	7	348	256	105
2	30	488.491	1000	8	351	247	106
2	35	488.659	1000	8	366	250	106
2	40	488.841	1000	8	351	248	108
1	45	488.991	1000	7	351	248	108
1	50	489.156	1000	7	355	251	108
1	55	489.325	1000	7	357	249	110
1	60	489.477	1000	7	353	255	110
	$\theta = 60$	$V_m = 1.977$					$t_m = 106.5$

(1508)

$V_{STD} = 1.791$

EPA Method 2 Field Data Sheet

Drawing of Test Site

Location LP / HAYWARD
 Source Level 1 Surface Piped RTO Inlet
 Test 13 Run Date 7-14-94
 Stack Dimen. 42 IN.
 Dry Bulb 262 °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.85 IN.HG
 Static Pressure -10.2 IN.WC
 Operators B. Aschenberg
 Pitot No. 294-S C_s .84

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>8.0</u>	IN.	Time Start: <u>1445</u>	HRS
A-8	.032	1.344	9.344	2.20	
7	.105	4.410	12.410	2.20	
6	.194	8.148	16.148	2.10	
5	.323	13.566	21.566	2.00	
4	.677	28.434	36.434	1.50	262
3	.806	33.852	41.852	1.20	
2	.895	37.590	45.590	.68	
1	.968	40.656	48.656	1.20	
B-8				2.00	
7				2.20	
6				1.80	
5				1.50	262
4				1.60	
3				.85	
2				.70	
1				.65	

Temp. Meas. Device & S/N: TM PDT 33

Time End: 1500 HRS

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP / Hayward Date 7-14-94 Test 13 Run 1
 Source Line 1 Surface Drain PTO Inlet No. of traverse points 16
 Method 5 Filter holder: SS Filter type: SS 6µm 61p
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 26 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: 29; 26; 255 filters
44; 17 5(4)
 Recovery solvent(s):
 acetone _____
 other(s) _____

No. of probe wash bottles: _____
 Sample recovered by: Bob

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	446	200	246
Impinger No. 3			
Condenser			
Desiccant	1473	1442	36
Total			282

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 6 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0.0 cc/min at 15 in. Hg.
 Time start: 1605 (HRS) Time end: 1841 (HRS)
 Sampling rate: 400 cc/min Operator: Bob

S/N of O₂ Analyzer used to monitor train outlet: 6

INTERPOL LABORATORIES - METHOD 5 FIELD DATA SHEET

Job: CP / Hwy 6022
Sample Site: (Systech) Box 510 Rd 7
Date: 5-24-94
Pilot No.: 2705
Box: 510
Hwy: 6022
City: July
Mo: 22
Yr: 94

Operator: SA JS
Station: 137 TR MC
Hwy: 6022
Date: 5-24-94

Apparatus: SA JS
Master Box No.: 60
Recorder: 60
Date: 5-24-94

Priority Point No.	Sampling Time (min)	Sample Volume (L)	Velocity Head (in H ₂ O)	Drift Rate (in H ₂ O)	Dry Vol. (cc)	VAC. (in Hg)	Temperature (°F)				Oxygen (XV/V)
							Probe	Dry	Wet	Dry/Wet	
B-8	(1625)	(81.80)	2.10	1.98	4.61	9	255	48	78	27	16.5
7	8	84.40	2.00	1.44	7.40	8	253	47	85	78	17.5
6	12	90.12	2.10	1.52	6.89	13	262	47	88	78	16.8
5	16	92.88	1.70	1.23	2.89	14	261	47	89	79	16.7
4	20	95.37	1.50	1.09	5.34	15	261	47	89	79	16.9
3	24	97.80	1.50	1.09	2.80	16	260	46	88	80	16.5
2	28	100.10	1.30	.95	10.09	16	268	46	88	80	16.6
1	32	102.37	1.30	.95	2.37	17	259	45	88	80	16.5
A-8	36	105.16	2.00	1.96	5.26	11	260	45	86	81	16.9
7	40	107.79	2.10	1.53	8.10	14	259	44	92	82	16.6
6	44	110.61	1.80	1.32	6.81	17	259	44	92	82	15.8
5	48	112.41	1.70	1.25	3.43	20	260	45	90	82	16.0
4	52	115.60	1.40	1.02	5.81	6	240	45	86	84	16.8
3	56	117.53	1.30	.95	8.10	17	260	45	84	83	16.6
2	60	120.00	1.15	.83	0.25	20	262	45	84	83	17.6
1	64	122.23	1.40	.73	2.25	22	268	45	84	83	16.6
											AVG. 83.8

0 = 64
V. = 90.43
11/18

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CPI HARVARD Date 7-19-74 Test 13 Run 2
 Source Line 1 Surface Layer RTO Plant No. of traverse points 16
 Method 5 Filter holder: Glass Filter type: 4" GFF
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 10 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

1 (5743)

Recovery solvent(s)

acetone _____
 other(s) _____

RUN VOIDED

No. of probe wash bottles:
 Sample recovered by:

1
B&B

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>280</u>	<u>200</u>	<u>80</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1415</u>	<u>1405</u>	<u>10</u>
			<u>90</u>
Total			

Integrated Gas Sampling Data:

Bag Pump No. 29B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.0
 Time start: 2030
 Sampling rate: 400

Box No. 6 Bag No. 2
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 2136 (HRS)
 cc/min Operator: 60

S/N of O₂ Analyzer used to monitor train outlet: 6

INTERCELL LABORATORIES "A" RECORD - FEBRUARY 1953

Job No. 2-1524
 Supply Line / Section 2-1524
 Operator 2-1524
 Date 2-15-53

Operator's Name W. J. HAYWARD
 Motor Box No. 6105
 Recorder Code 77
 Recorder No. 7930

Pistol No. 2925
 Bar Pressure 1120
 Nozzle No. 523
 Nozzle Dia. 1.55
 Tip

Spray Point No.	Sampling Time (min)	Supply Volume (cc)	Velocity (ft/min)	Density (lb/ft ³)	Diff. Bar (inches)	Diff. Vbl. (ft)	VAC. inches	Temperature (°F)				Oxygen (%)	
								Block	Probe	Dry	Wet		
A-8	(2030)	(122.40)	2.00	1.33	5.10	5		261	245	253	45	81	19.3
	4	105.21	2.16	1.39	7.86	5		260	248	250	45	84	19.2
	8	127.95	1.80	1.19	0.42	4		261	248	250	45	88	19.4
	12	130.42	1.50	1.00	2.28	4		260	249	251	45	90	19.7
	16	138.80	1.40	1.00	5.12	4		264	247	253	43	92	19.3
	20	135.15	1.50	1.00	7.40	4		265	250	248	43	93	19.3
	24	137.48	1.60	1.00	0.15	4		265	247	253	43	92	20.1
	28	140.20	1.16	1.00	2.17	3		265	250	248	43	94	20.8
	32	142.20	2.10	1.41	4.96	4		263	248	251	43	94	19.3
	36	144.85	2.00	1.33	7.68	5		268	248	249	42	96	19.3
B-8	40	147.67	1.80	1.06	0.26	5		269	248	249	43	97	19.4
	44	150.20	1.60	1.07	2.70	5		268	248	249	42	97	18.9
	48	152.78	1.53	1.03	5.10	4.5		269	248	249	42	98	19.4
	52	155.26	1.50	1.05	7.47	4		267	247	252	41	98	20.2
	56	157.60	1.60	1.07	9.92	4		268	247	252	41	98	20.2
	60	159.98	1.50	1.00	2.27	4		268	247	252	41	98	20.3
	64	162.34	1.50	1.00		4		268	247	252	41	98	20.3
	(2136)												
<p style="text-align: center;">VOIDED</p>													
											AVG. =	88	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / HAYWARD Date 7-14-94 Test 13 Run 3
 Source Line 1 Surface Vapor DTE PILET No. of traverse points 16
 Method 5 Filter holder: CB55 Filter type: 4" GFF
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

()

Recovery solvent(s)

acetone _____
 other(s) _____

No. of probe wash bottles:
 Sample recovered by:

Bob

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	381	200	181
Impinger No. 3			
Condenser			
Desiccant	1490	1473	17
Total			198

Integrated Gas Sampling Data:

Bag Pump No. 29B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.0
 Time start: 2230
 Sampling rate: 400

Box No. 6 Bag No. 5
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 2400 (HRS)
 cc/min Operator: 605

S/N of O₂ Analyzer used to monitor train outlet: 6

INTERPOL LABORATORIES - PO METHOD B FIELD DATA SHEET

Job CP / Hwy 209 / Shaker Pkwy. PTO. DIST
Supervisor 209 / Shaker Pkwy. PTO. DIST
Date 2-14-84
Operator DA JS
Meter Box No. 10
Recorder Code 2930
Pilot No. 29-5 CP 84
Bar. Press. 2885
Horiz. No. 533
Inch 172
In. HC
Date 120 25 7
Date 195 11

Traverse Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (in.HC)	Drifts Meter (in.HC)	Dep. Vol. (cc)	VAD. (in.HC)	Temperature (°F)						Oxygen (Kv/v)
							Blank	Probe	Depth	Bar	Ingy	Exstn	
6-8	(2230)	163.10	2.00	1.31	5.74	5	272	250	246	42	82	83	17.4
7	4	165.85	1.80	1.20	8.31	5	274	248	249	42	84	82	17.6
6	8	168.34	1.90	1.27	0.95	5	274	248	249	42	87	82	16.5
5	12	170.93	1.30	1.87	3.15	4.5	275	250	251	41	89	81	17.1
4	16	173.16	1.30	.87	5.34	4.5	275	248	252	40	90	82	17.6
3	20	175.30	1.40	.94	7.62	5	274	248	252	40	91	82	17.7
2	24	177.60	1.20	.81	9.73	5	275	250	252	40	92	81	17.0
1	28	179.72	1.10	.74	1.76	5	274	250	249	41	92	81	17.6
A-8	32	181.76	2.10	1.41	4.55	6	274	251	249	41	91	81	17.5
7	36	184.62	2.05	1.38	7.31	7	275	251	252	40	93	82	17.4
6	40	187.22	1.80	1.28	9.97	7	273	251	252	40	93	82	17.1
5	44	189.90	1.20	1.22	2.57	7	272	248	250	41	93	82	17.5
4	48	192.60	1.20	1.14	5.09	6.5	275	248	250	41	93	83	18.8
3	52	195.23	1.50	1.01	7.46	6	275	248	250	40	90	83	18.5
2	56	197.55	1.80	1.41	0.85	6	269	250	249	40	89	83	
1	60	200.50	1.95	.74	2.58		270				91	83	
	64	202.60											
	(2100)												

AVG. = 86.2

AVG. = 1.10

V.S. = 6.4

CF-011

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job CP/HAYWARD
 Source Low Surface RTO Duct
 Method 5 Filter holder: GLASS

Date 7-14-94 Test 13 Run 4
 No. of traverse points 16
 Filter type: 4" GFF

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac)
 Posttest: 8 cfm at 10 in. Hg. (vac)

Particulate Catch Data:

No.s of filters used: _____ Recovery solvent(s)
 _____ acetone _____
 _____ other(s) _____
 No. of probe wash bottles: _____
 Sample recovered by: _____

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	437	300	237
Impinger No. 3			
Condenser			
Desiccant	1431	1415	
			16
Total			253

Integrated Gas Sampling Data:

Bag Pump No. 296 Box No. 25 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0.0 cc/min at 15 in. Hg.
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: 400 cc/min Operator: SOB
 S/N of O₂ Analyzer used to monitor train outlet: 6

CF-023

S-0046RR

INTERPOL LABORATORIES A METHOD 5 FIELD DATA SHEET

Job CP / HAYWARD Operator DA 33 Pilot No. 27003 Cp 84
 Source CP 1 SW 1/4 RTO RUC Meter Box No. 70 HF 1.77 IN MC 2883 INHG H2O 81 X
 Date 7-23-84 Computer cost. .9930 Nozzle No. 533 Nozzle Dia. 2.85 IN.

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (INWG)	Drifts Meter (INWG)	Dsp. Vbl. (cf)	VAC. INHG	Temperature (°F)				Gas/In	Gas/Out	Oxygen (XV/V)
							Stack	Probe	Dryn	Wet			
A - 8	4	204.50	1.90	1.41	7.28	5	265	250	249	42	81	81	17.5
	8	207.70	1.70	1.25	7.90	5	264				85	80	17.6
	12	212.45	1.50	1.10	2.37	5	266	249	252	41	87	80	17.2
	16	214.80	1.45	1.07	4.79	5	268				89	80	17.2
	20	217.08	1.30	1.76	7.09	5	268	247	250	40	90	80	17.1
	24	219.36	1.30	.76	9.38	5	270				91	80	17.7
	28	221.74	1.40	1.03	1.77	5	269	249	249	41	91	80	16.6
	32	224.25	1.50	1.11	4.24	5.5	269				92	80	17.4
B - 8	36	226.07	1.70	1.25	6.88	5	269	251	252	40	91	81	17.3
	40	229.60	2.10	1.53	9.80	5	268				92	81	17.2
	44	232.30	1.50	1.11	2.28	7	269	250	250	39	92	81	17.0
	48	234.55	1.30	.96	4.58	6	271				93	82	17.1
	52	236.85	1.30	.96	6.89	6	269	248	247	40	93	82	17.2
	56	239.25	1.40	1.03	9.29	6	271				93	82	17.2
	60	241.53	1.38	.96	1.60	6.5	270	251	248	39	93	82	17.2
	64	243.87	1.20	.89	3.82	6	267				92	82	17.5
(0151)													
V = 64													
AVG = 81.0													

Interpoll Laboratories
(612)786-6020

EPA Method 7 Sample Collection
Field Data Sheet

Job LP Hayward W. H. Date 7/12/04 Bar. Pressure 28.5 IN.HG.
 Test Location Line 1 Fuel Type Wood Sample Train No. Green
Surface Orner PTO DALET Technician J.P.L. Pump No. 27B

No.	Test Run Point	Flask No.	Time (HRS)	Vacuum (IN.HG.)	Flask Temp. (°F)	Leak Rate <0.4 IN.HG./MIN.
1	13-1-1	19	1630	26.3	97	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
2	13-1-2	20	1645	26.3	97	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3	13-1-3	21	1715	26.2	95	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
4	13-1-4	22	1830	26.1	95	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
5	13-2-1	23	2035	26.1	77	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
6	13-2-2	24	2050	26.2	77	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
7	13-2-3	13	2110	26.3	77	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
8	13-2-4	14	2125	26.3	77	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
9	13-3-1	15	2235	26.3	72	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
10	13-3-2	16	2250	26.2	71	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
11	13-3-3	17	2310	26.3	70	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
12	13-3-4	18	2350	26.4	70	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
13						<input type="checkbox"/> Yes <input type="checkbox"/> No
14						<input type="checkbox"/> Yes <input type="checkbox"/> No
15						<input type="checkbox"/> Yes <input type="checkbox"/> No
16						<input type="checkbox"/> Yes <input type="checkbox"/> No
17						<input type="checkbox"/> Yes <input type="checkbox"/> No
18						<input type="checkbox"/> Yes <input type="checkbox"/> No
19						<input type="checkbox"/> Yes <input type="checkbox"/> No
20						<input type="checkbox"/> Yes <input type="checkbox"/> No
21						<input type="checkbox"/> Yes <input type="checkbox"/> No
22						<input type="checkbox"/> Yes <input type="checkbox"/> No
23						<input type="checkbox"/> Yes <input type="checkbox"/> No
24						<input type="checkbox"/> Yes <input type="checkbox"/> No
25						<input type="checkbox"/> Yes <input type="checkbox"/> No
26						<input type="checkbox"/> Yes <input type="checkbox"/> No
27						<input type="checkbox"/> Yes <input type="checkbox"/> No

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET


Job CP / HAYWARD
 Source Line 1 Core Dioxin PTO Inlet
 Test 16 Run 3 Date 7-15-86
 Stack dimen. 42-0 IN.
 Dry bulb 274 °F Wet bulb 154 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.87 in Hg
 Static pressure -8.30 in WC
 Operators B. Beckerbach & J. Johnson
 Pitot No. 270-6 Cp 24

Cross-section View	Elevation View
Drawing of Test Site	

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
Port length: <u>6-0</u> in.				Time start: _____ hrs	
A	1			1.35	
	2			1.49	
	3			1.62	
	4			1.54	
	5			1.33	272
	6			1.12	
	7			1.26	
	8			1.42	
B	1			1.34	
	2			1.39	
	3			1.20	
	4			1.21	
	5			1.30	
	6			1.59	
	7			1.54	
	8			1.75	
Temp. meas. device & S/N: <u>POT 30</u>				Time end: _____ hrs	

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LP / HAYWARD
 Source LEL / COIC DRY PIT INLET
 Test 18 Run 1 Date 7-15-96
 Stack dimen. 42 IN.
 Dry bulb 233 °F Wet bulb 146 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.57 in Hg
 Static pressure -7.21 in WC
 Operators B Aschbacher J Johnson
 Pitot No. 270-6 C_p .84



Drawing of Test Site

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>50</u> in.		Time start: <u>1010</u> hrs	
A	1			1.18	
	2			1.30	
	3			1.50	
	4			1.21	
	5			1.20	233
	6			1.40	
	7			1.20	
	8			1.07	
B	1			1.12	
	2			1.10	
	3			1.22	
	4			1.30	235
	5			1.43	
	6			1.25	
	7			1.33	
	8			1.74	
Temp. meas. device & S/N: <u>POT</u>				Time end: <u>1020</u> hrs	

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LP HAYWARD
 Source LINE 1 CORE DRAIN RTO INLET
 Test 18 Run 2 Date 7-15-94
 Stack dimen. 42.0 IN.
 Dry bulb 253 °F Wet bulb 143 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.87 in Hg
 Static pressure -8.82 in WC
 Operators SASchenbach J Scriber
 Pitot No. 270-6 C_p .84

Cross-section View	Elevation View
Drawing of Test Site	

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: _____ in.		Time start: <u>1330</u> hrs	
<u>B</u>	<u>1</u>			<u>1.10</u>	
	<u>2</u>			<u>1.54</u>	
	<u>3</u>			<u>1.22</u>	
	<u>4</u>			<u>1.04</u>	<u>251</u>
	<u>5</u>			<u>1.37</u>	
	<u>6</u>			<u>1.65</u>	
	<u>7</u>			<u>1.46</u>	
	<u>8</u>			<u>1.47</u>	
<u>A</u>	<u>1</u>			<u>1.15</u>	
	<u>2</u>			<u>1.25</u>	
	<u>3</u>			<u>1.30</u>	
	<u>4</u>			<u>1.24</u>	<u>253</u>
	<u>5</u>			<u>1.41</u>	
	<u>6</u>			<u>1.28</u>	
	<u>7</u>			<u>1.44</u>	
	<u>8</u>			<u>1.47</u>	
Temp. meas. device & S/N: <u>PDT 32</u>				Time end: <u>1340</u> hrs	

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LD/HAYWARD
 Source Core Dept. RTO Inlet
 Test 18 Run 3 Date 7-5-94
 Stack dimen. 42 IN.
 Dry bulb 26.0 °F Wet bulb 14.4 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.87 in Hg
 Static pressure -9.58 in WC
 Operators W. B. TRUBAK H.
 Pitot No. 270-6 C_p .84

Cross-section View	Elevation View
Drawing of Test Site	

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>8.0</u> in.		Time start: _____ hrs	
A	8			1.80	
	7			2.15	
	6			2.02	
	5			1.63	
	4			1.79	
	3			1.63	
	2			1.84	
	1			1.40	
B	8			1.40	
	7			2.20	
	6			2.00	
	5			1.55	
	4			1.66	
	3			1.50	
	2			1.35	
	1			1.12	
Temp. meas. device & S/N: <u>PST 32</u>				Time end: _____ hrs	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Hayward Date 7-15-94 Test 19 Run 1
 Source Line 1 Dyer RTO Stack No. of traverse points 3
 Method Phenol Filter holder: Glass Filter type: 4" GF
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 10 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____
 other(s) _____

No. of probe wash bottles:

Sample recovered by:

0
DM + KU

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1 <u>A</u>	<u>415</u>	<u>269</u>	<u>146</u>
Impinger No. 2 <u>B</u>	<u>421</u>	<u>267</u>	<u>154</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1509</u>	<u>1506</u>	<u>3</u>
Total			<u>303</u>

Integrated Gas Sampling Data: 7.11 Taken during test 20 Run 1 POM

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ in. Hg.
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: 9

INTERPOL LABORATORIES %A METHOD B FIELD DATA SHEET

Job LP/H
 Survey Name
 Date 2-15-74

Operator UM & KU
 Meter Box No 2
 Counter Post 19

Unit No. NA
 Bar Code NA
 Meter No. NA

Pilot No. NA
 Bar Code NA
 Meter No. NA

Property Point No.	Sampling Time (min)	Sample Volume (cfs)	Velocity Head (ft)	Orifice Meter (ft)	Dep. Vgt. (ft)	VAD. (ft)	Temperature (°F)			Gas/In	Gas/Dpt	Oxygen (xv/v)	
							Probe	Down	Temp.				
A	(5922)	(551.20)	1.77	1.77	NA	7	350	245	251	42	77	68	16.6
	5	554.41	1.77	1.77		7	351	247	243	42	84	68	15.8
	10	558.76	1.77	1.77		7	353	249	239	43	85	70	18.1
	15	562.154	1.77	1.77		7	353	250	241	43	88	71	17.4
	20	565.37 570.20	1.77	1.77		7	353	251	242	43	89	72	16.7
	25	574.04	1.77	1.77		7	352	249	253	43	91	73	16.6
	30	587.88	1.77	1.77		7	342	251	247	44	91	74	16.2
	35	581.73	1.77	1.77		7	342	247	257	44	92	75	16.9
	40	585.58	1.77	1.77		7	342	251	249	44	92	75	16.7
	45	589.42	1.77	1.77		7	345	255	245	44	93	76	16.3
	50	592.30	1.77	1.77		7	345	257	249	45	93	77	16.6
	55	597.15	1.77	1.77		7	345	251	242	45	93	78	16.1
	60												
	(1025)												
											Avy. =	81	

v = 45.95
 0 = 60
 11 = 1.77

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LD/Hayward Date 7-15-94 Test 19 Run 2
 Source Line 1 Dryer RTO Stack No. of traverse points NA
 Method Personal Filter holder: NA Filter type: NA
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____

other(s) _____

No. of probe wash bottles: _____

Sample recovered by: _____

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1 <u>A</u>	<u>424</u>	<u>272</u>	<u>152</u>
Impinger No. 2	<u>422</u>	<u>267</u>	<u>155</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1544</u>	<u>1527</u>	<u>17</u>
Total			<u>324</u>

Integrated Gas Sampling Data: NA

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ in. Hg.
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

9

INTERPOLL LABORATORIES A METHOD 5 FIELD DATA SHEET

Job LP / Hayward Operator DM & KA Pict. No. NA CP NA
 Sample Line 1 Meter Box No. 20 Meter No. 8886 Meter No. NA
 Date 7-15-94 Recorder 19 Hum 2 Time 11:22 Inlet No. 9974 Inlet No. NA

Traverse Point No.	Sampling Time (min)	Supply Volume (cub)	Velocity Head (cmH ₂ O)	Orifice Meter (cmH ₂ O)	Dev. Vol. (cub)	VAC. Inlet	Temperature (°F)				Dust/Dpt	Dust/In	Dust/Out	Dust/In (xv/v)
							Exh. Inlet	Probe	Duct	Temp.				
B	(12:57)	(597.49)	NA	1.77	NA	7	357	249	238	43	83	80	80	16.7
	5	601.23	NA	1.77		7	357	248	240	43	88	80	80	16.7
	10	605.06		1.77		7	348	251	235	43	90	81	81	16.7
	15	608.90		1.77		8	348	245	241	40	95	82	82	16.5
	20	612.77		1.77		8	353	256	241	40	100	85	85	15.6
	25	616.50		1.77		8	348	252	244	40	99	85	85	15.7
	30	620.51		1.77		8	348	252	250	42	101	86	86	15.8
	35	624.05		1.77		8	351	248	261	42	102	86	86	15.3
	40	628.17		1.77		8	362	250	260	43	102	87	87	15.4
	45	632.05		1.77		8	362	251	255	44	102	87	87	15.9
	50	635.95		1.77		8	360	248	257	44	102	87	87	16.1
	55	639.84		1.77		8	360	250	260	44	102	88	88	15.7
	60	644.39				8								
	(13:57)													
													Av. =	91

∑V = 46.90

∑V = 60

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / Hayward Date 7-15-84 Test 19 Run 3
 Source Line 1 Dryer RTO Stack No. of traverse points NA
 Method Phenol Filter holder: NA Filter type: NA
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____
 other(s) _____

No. of probe wash bottles:

Sample recovered by: _____

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1 A	437	270	167
Impinger No. 2 B	364	268	96
Impinger No. 3			
Condenser			
Desiccant	1397	1377	20
Total			283

Integrated Gas Sampling Data: NA

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ in. Hg.
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

9

TEMPERATURE LOGS FOR PILES 25 METHOD 2 FIELD DATA SHEET

Job: LP (Hayward)
 Spiling Line: 100 ft
 Date: 7-15-94
 Operator: M. J. Oyster
 Motor Box No.: 2
 Recorder coil: 2
 Pile No.: NA
 Ref. Pile: 28
 Horiz. No.: NA
 Ep. No.: NA
 Horiz. No.: NA
 Pile No.: NA
 Ref. Pile: NA
 Horiz. No.: NA


Temperature Point No.	Sampling Time (min)	Sample Volume (cfs)	Velocity Head (ft)	Orifice Meter (ft)	VAC. (ft)	Temperature (°F)				Ox. Vol. (XV/V)			
						Stack	Probb	Dyno	Impy.				
C	(140.87)	(649.70)	NA	1.77	NA	7	351	248	255	41	98	88	16.3
	5	648.55		1.77		8	366	250	250	41	102	89	16.1
	10	652.42		1.77		8	366	250	250	41	104	89	16.1
	15	656.35		1.77		8	346	255	241	43	105	89	16.1
	20	660.34		1.77		8	348	256	247	43	107	90	16.5
	25	664.10		1.77		8	351	247	253	44	108	91	16.1
	30	668.00		1.77		8	366	250	241	44	108	92	16.5
	35	671.89		1.77		8	351	248	248	46	110	94	16.5
	40	675.84		1.77		8	351	248	258	46	111	95	16.6
	45	679.79		1.77		8	355	251	251	47	112	95	16.9
	50	683.72		1.77		8	357	249	249	46	112	96	17.1
	55	687.50		1.77		8	353	255	254	47	110	95	17.0
	60	691.66		1.77		8							
	(150.8)	(46.96)											
							Σ = 46.96						
							Σ = 1.77						
											Avg. = 100		

20

INTERPOL LABORATORIES, INC.
 (612) 786-6020
 EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Hayward, WI
 Source Line 1 Dryer RTO / Stack
 Test 20 Run on Date 7-15-94
 Stack Dimen. 01.5 IN.
 Dry Bulb 350 °F Wet bulb 159 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.87 IN.HG
 Static Pressure -0.54 IN.WC
 Operators M. Koehler + K. Nussmeier
 Pitot No. 23V-9 C, 104



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6.25</u> IN.	Time Start: <u>NA</u> HRS		
<u>Refer to CH₂O Test</u>					
<u>for pts and flows</u>					
					Time End: <u>NA</u> HRS
Temp. Meas. Device & S/N: <u>PDT-31 / TC</u>					

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES EPA MODIFIED METHOD 5 SAMPLE LOG SHEET

Job L.P. / Hayward, CA
 Source Line 1 Dryer #10 / Stack
 Cyclone: Yes No Filter holder: MMS
 Analytes: PCM
 Field recovery spike added: Yes No

Date 7-15-94 Test 20 Run 1
 No. of traverse points 16 X 2
 Filter type: 4" Glass fiber
 XAD-2 resin: g Batch No.
 Reference: EPA SW-846 Method 0010

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. (vac)
 Posttest: < 0.02 cfm at 7 in. Hg. (vac)

Semivolatile Catch Data:

No.s of filters used: 3006 Recovery solvent(s)
 MeCl₂ * ~~MeOH (50:50 v/v)~~
 other(s) Acetone
 No. of bottles for condensate trap catch: 1
 Samples recovered by: M. Kuebler

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Condensate trap	699	266	423
Condensate trap			
Condensate trap			
Impingers			
Desiccant	1460	1440	20
Total			443

Integrated Gas Sampling Data:

Bag Pump No. 23 B Box No. 12 Bag No. 1
 Bag Material: 4-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 0900 (HRS) Time end: 1014 (HRS)
 Sampling rate: 200 cc/min O₂ Analyzer S/N: 3

INTERPOLL LABORATORIES EPA MODIFIED METHOD 5 SAMPLE LOG SHEET

Job L.P. / Hayward, CA
 Source Line 1 Dryer (RTO) / Struck
 Cyclone: Yes No Filter holder: MMS
 Analytes: PC-M
 Field recovery spike added: Yes No

Date 7-15-94 Test 20 Run 1
 No. of traverse points 16
 Filter type: 4" Glass fiber
 XAD-2 resin: g Batch No.
 Reference: EPA SW-846 Method 0010

Sample Train Leak Check:

Pretest: 0.02 cfm at 15 in. Hg. (vac)
 Posttest: 0 cfm at 7 in. Hg. (vac)

Semivolatile Catch Data:

No. of filters used: 3007 Recovery solvent(s)
 MeCl₂ * MeOH (50:50 v/v)
 other(s) Acetone
 No. of bottles for condensate trap catch: 1
 Samples recovered by: Mike Koshlar

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Condensate trap			
Condensate trap	<u>715</u>	<u>266</u>	<u>449</u>
Condensate trap			
Impingers			
Desiccant	<u>1403</u>	<u>1382</u>	<u>21</u>
Total			<u>470</u>

Integrated Gas Sampling Data:

Bag Pump No. 255 Box No. 12 Bag No. 2
 Bag Material: 4-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 0801 (HRS) Time end: 1014 (HRS)
 Sampling rate: 200 cc/min O₂ Analyzer S/N: 3

INTERPOL LABORATORIES EPA MODIFIED METHOD 3 FIELD DATA SHEET

JOB L.P./Hesswood CA1 OPERATOR M. Kuebler + K. Alexander No. 01116 No. 01116 P1101 No. 231-B
 SOURCE Line 1 Down RTD / Stack MOTOR BOX NO. 233 NO. 233 CP 23
 DATE 2-15-94 TIME 10:00 RUN 2 GAS MOTOR COEFF. .9762 BAR. PRES. 29.57 10.14 10.14 H₂O 2.57 %

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (INHG)	Orifice Meter (INHG)	Dens. Vol. (cf)	VAC. INHG	Temperatures (°F)						Oxygen (XY/Y)	
							Stack	Probe	Oven	XAD2	Imp.	Meter (in/out)		
A-8	68	638.05	.50	.75	8.08	4	358	243	241	46	45	98	93	14.9
8	72	640.05	.53	.79	0.12	4.5	359	238	235	46	45	99	93	15.6
7	26	642.30	.68	1.00	2.41	5	366	239	240	46	45	100	94	14.6
7	80	644.62	.65	.96	4.66	5	368	235	243	46	46	100	95	15.2
6	84	646.91	.67	1.00	6.95	5	356	239	240	47	46	101	95	15.5
6	88	649.19	.67	1.01	9.65	5	356	234	245	47	46	101	95	15.1
5	92	651.42	.63	.94	1.47	5	363	243	242	47	46	101	96	15.1
5	96	653.70	.63	.94	3.70	5	363	240	244	47	47	101	95	14.9
4	100	655.05	.65	.96	5.95	5	366	242	240	47	47	100	95	15.0
4	104	658.22	.58	.86	8.07	5	366	238	243	47	47	101	95	15.6
3	108	660.19	.57	.86	0.10	5	357	246	240	47	47	102	96	15.5
3	112	662.24	.58	.88	2.35	5	357	243	247	48	48	102	96	15.5
2	116	664.40	.57	.77	4.37	4.5	348	243	250	48	48	102	96	15.6
2	120	666.30	.50	.76	6.37	4.5	348	245	253	48	48	102	97	15.6
1	124	668.29	.50	.75	8.37	4.5	353	240	245	48	48	102	96	16.0
1	128	670.25	.44	.66	0.24	4	353	240	243	48	48	103	97	16.1
(1509)														

AVG. = 94.7

INTERPOLL LABORATORIES EPA MODIFIED METHOD 5 SAMPLE LOG SHEET

Job L.P. / Hayward, WI Date 7-15-94 Test 20 Run 3
 Source line 1 Dwyer RTO / Stack No. of traverse points 16 x 2
 Dilution: Yes No Filter holder: MM5 Filter type: 4" Glass fiber
 Analytes: PM XAD-2 resin: g Batch No.
 Field recovery spike added: Yes No Reference: EPA SW-846 Method 0010

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. (vac)
 Posttest: 20.02 cfm at 8 in. Hg. (vac)

Semivolatile Catch Data:

No. of filters used: 3008 Recovery solvent(s):
 MeCl₂ * ~~100% (50:50 v/v)~~
 other(s) Acetone
 No. of bottles for condensate trap catch: 1
 Samples recovered by: M. Kaehler

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Condensate trap	676	265	411
Condensate trap			
Condensate trap			
Impingers			
Desiccant	1386	1367	19
Total			430

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 12 Bag No. 3
 Bag Material: 4-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1545 (HRS) Time end: 1754 (HRS)
 Sampling rate: 200 cc/min O₂ Analyzer S/N: 3

INTERPOL LABORATORIES EPA M01 ED METHOD 3 FIELD DATA SHEET

Job B.P. / Highway d. 101 Operator M. Sauerhager t.K. Messmer Notice No. ED-4 P1101 No. 23V-8
 Source Ameyer / LTO / Stage 4 Motor Box No. 231 Notice DI. 231 In. 97 Cp. 97
 Date 2-15-97 Motor 1891 20 RUN 3 Gasometer Const. .9862 Bar. Pres. 29.87 In. Hg. 14.9 H₂O 24.7 %

Traverse Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (ft)	Orifice Meter (ft)	Det. Vol. (cc)	VAC. In. Hg.	Temperature (°F)					Oxygen (%/V)		
							Stack	Probe	Oven	XAD2	Imp.		Motor (In/Out)	
							355	252	250	51	50		102	
B-8	68	705.58	.56	.82	5.58	7	355	252	250	51	50	102	97	15.5
8	72	707.81	.56	.82	7.66	7	355	253	250	50	50	103	98	15.4
7	76	709.75	.59	.86	9.79	7	359	250	254	50	50	103	98	15.9
7	80	711.02	.57	.83	1.89	7	359	253	248	48	49	103	98	15.6
6	84	714.00	.62	.89	4.06	7	369	255	244	42	49	104	98	15.5
6	88	716.13	.57	.82	6.15	7	369	252	242	42	47	104	98	15.5
5	92	718.20	.59	.85	8.27	7	373	248	250	42	47	103	98	15.7
5	96	720.27	.57	.82	2.34	7	373	245	248	42	47	104	98	15.6
4	100	722.43	.62	.90	4.53	7.5	359	242	244	46	47	104	98	15.9
4	104	724.63	.60	.88	4.68	7.5	359	244	248	46	46	104	98	15.9
3	108	726.75	.59	.84	6.80	7	376	242	245	46	46	104	98	15.5
3	112	728.88	.57	.81	8.87	7	376	245	251	46	46	104	97	15.6
2	116	731.00	.61	.88	1.03	7.5	371	242	250	46	46	104	98	15.6
2	120	733.00	.55	.79	3.07	7	371	242	255	46	46	103	98	16.3
1	124	735.00	.80	.73	5.04	7	359	245	251	48	47	104	98	16.2
1	128 (1754)	737.02	.52	.76	7.04	7	352	248	248	48	48	104	98	16.0

Rev. 1
 Page 1 of 2
 CF-023


Visible Emissions Form

Test 14

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME			
LOUISIANA PACIFIC CORP			7-14-94				1642		1742			
ADDRESS			SEC				SEC					
			MIN	0	15	30	45	MIN	0	15	30	45
			1	0	0	0	0	31	0	0	0	0
			2	0	0	0	0	32	0	0	0	0
CITY	STATE	ZIP	3	0	0	0	0	33	0	0	0	0
HAYWARD	WISCONSIN		4	0	0	0	0	34	0	0	0	0
PHONE	SOURCE ID NUMBER		5	0	0	0	0	35	0	0	0	0
PROCESS EQUIPMENT		OPERATING MODE	6	0	0	0	0	36	0	0	0	0
LINE 1 DRYER STACK			7	0	0	0	0	37	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE	8	0	0	0	0	38	0	0	0	0
RTO			9	0	0	0	0	39	0	0	0	0
DESCRIBE EMISSION POINT			10	0	0	0	0	40	0	0	0	0
START LOW END METAL STACK STOP ✓			11	0	0	0	0	41	0	0	0	0
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER		12	0	0	0	0	42	0	0	0	0
START 800' STOP ✓	START 100' STOP ✓		13	0	0	0	0	43	0	0	0	0
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER	14	0	0	0	0	44	0	0	0	0
START 300' STOP ✓		START NE STOP ✓	15	0	0	0	0	45	0	0	0	0
DESCRIBE EMISSIONS			16	0	0	0	0	46	0	0	0	0
START NONE STOP ✓			17	0	0	0	0	47	0	0	0	0
EMISSION COLOR	PLUME TYPE: CONTINUOUS <input type="checkbox"/>		18	0	0	0	0	48	0	0	0	0
START None STOP	FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		19	0	0	0	0	49	0	0	0	0
WATER DROPLETS PRESENT:	IF WATER DROPLET PLUME:		20	0	0	0	0	50	0	0	0	0
NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>	ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>		21	0	0	0	0	51	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			22	0	0	0	0	52	0	0	0	0
START 8' above stack STOP ✓			23	0	0	0	0	53	0	0	0	0
DESCRIBE BACKGROUND			24	0	0	0	0	54	0	0	0	0
START SKY STOP ✓			25	0	0	0	0	55	0	0	0	0
BACKGROUND COLOR	SKY CONDITIONS		26	0	0	0	0	56	0	0	0	0
START 8/10/10 STOP ✓	START 5/10/21/10 STOP ✓		27	0	0	0	0	57	0	0	0	0
WIND SPEED	WIND DIRECTION		28	0	0	0	0	58	0	0	0	0
START 8 STOP 10	START W STOP ✓		29	0	0	0	0	59	0	0	0	0
AMBIENT TEMP.	WET BULB TEMP.	RH. percent	30	0	0	0	0	60	0	0	0	0
START 80 STOP 79	63	34	<div data-bbox="231 1365 743 1764" data-label="Diagram"> <p>Source Layout Sketch Draw North Arrow</p> </div>									
COMMENTS			AVERAGE OPACITY FOR HIGHEST PERIOD				NUMBER OF READINGS ABOVE % WERE					
			RANGE OF OPACITY READINGS				RANGE OF OPACITY READINGS					
			MINIMUM				MAXIMUM					
			OBSERVER'S NAME (PRINT) Edward W. Lowbridge									
			OBSERVER'S SIGNATURE Edward W. Lowbridge								DATE 7-14-94	
			ORGANIZATION INTERPOLL LABS									
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE			CERTIFIED BY ETA				DATE 7-7-94					
			TITLE			DATE			VERIFIED BY			DATE

APPENDIX D

LINE 2 RTO FIELD DATA SHEETS




INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Location L.P. / Highway, WI
 Source Line 2 Dope RTG / Outlet
 Test 1 Run Date 7-12-84
 Stack Dimen. 81.5 IN.
 Dry Bulb 32.7 °F Wet bulb 15.4 °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 28.71 IN.HG
 Static Pressure -1.61 IN.WC
 Operators M. Kachler & K. Niesmeier
 Pitot No. 29V-S C₂ 84



PM/CO/NO_x

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: 6.25 IN.			Time Start: 0752 HRS		
A-1	.032	2.61	8.96	.50	
2	.105	9.56	14.81	.68	
3	.194	15.81	22.06	.73	
4	.323	26.32	32.57	.70	
5	.677	59.18	61.43	.71	
6	.806	65.59	71.94	.72	
7	.895	72.94	78.19	.68	
8	.968	79.99	85.14	.65	
B-1				.54	324
2				.72	
3				.70	
4				.69	
5				.71	
6				.71	
7				.72	
8				.60	
Temp. Meas. Device & S/N: <u>PDT-31/1C</u>				Time End: <u>0757</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayward, WI Date 7-12-94 Test 1 Run 1
 Source LINE 2 DRYER RD / outlet No. of traverse points 16
 Method 5 Filter holder: Glass Filter type: 4" G.F.
 Sample Train Leak Check: _____

Prerest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.01 cfm at 9 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

6781

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles:
 Sample recovered by:

1
M. Kachler + K. Rosenthal

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	205	500	205
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1524	1513	11
Total			216

Integrated Gas Sampling Data:

Bag Pump No. 29B
 Bag Material: 5-layer Aluminized Tedlar
 Prerest leak check: 0
 Time start: 1000
 Sampling rate: 400

Box No. 30 Bag No. 1
 Size: 15 in. Hg.
 cc/min at (HRS) Time end: 1210 (HRS)
 cc/min Operator: M. Kachler

S/N of O₂ Analyzer used to monitor train outlet: 9

TEMPERATURE LABORATORIES - 26 METHOD 5 FIELD DATA SHEET

Job: L.P. / Hayward 4/1 OUTLET 1
 Sampling Point No.: 7-12-94
 Sampling Date: 2/28/94
 Operator: Mr. K. A. Adams
 Title: Lab. Asst.
 Date: 2/28/94
 Station No.: 10
 Plot No.: 290-8
 Bar. Press.: 28.71
 Humidity: 3.4
 Bar. Dia.: 28
 Bar. No.: 354
 Humidity No.: 245

Inventory Point No.	Sampling Time (min)	Supply Volume (cu ft)	Velocity Hood (ft/min)	Ductile Meter (ft/min)	Dye Vol. (cu ft)	VAC. (inHg)	Stack	Probe	Dye	Temperature (°F)			Gas/Dpt	Oxygen (xv/v)
										Insp.	Dye	Insp.		
B-8	4	514.40	.59	1.97	6.69	4	341	241	233	45	95	82	12.1	
	8	516.65	.67	1.14	9.20	4.5	335	235	237	45	81	83	16.8	
	12	519.11	.70	1.20	1.77	5	327	239	244	44	84	83	17.2	
	16	521.21	.69	1.16	4.30	5	346	242	248	44	90	84	16.7	
	20	526.27	.68	1.14	6.62	4.5	349	245	245	44	92	84	16.5	
	24	529.42	.72	1.25	9.46	5	328	241	251	44	89	85	17.0	
	28	531.89	.66	1.16	1.96	4.5	342	237	249	45	92	85	16.2	
	32	534.39	.65	1.12	4.45	4.5	334	235	246	45	95	83	17.3	
A-8	36	536.91	.64	1.09	6.92	4.5	345	231	240	47	94	83	16.8	
	40	539.45	.70	1.19	9.50	5	342	234	247	47	98	84	16.7	
	44	542.13	.71	1.23	2.12	5.5	332	233	245	47	100	86	17.5	
	48	544.74	.70	1.19	4.71	5.5	348	237	244	48	101	85	16.9	
	52	547.35	.71	1.23	2.34	6	337	232	246	48	94	91	16.8	
	56	549.93	.66	1.13	9.86	5.5	348	230	246	48	95	90	17.0	
	60	552.32	.59	1.01	2.24	5	344	229	243	48	97	91	16.3	
	64	554.50	.48	.83	4.41	4	336	233	245	49	100	91	17.1	
<p>Hold (1036) <u>1036</u> <u>1036</u> <u>1036</u> Hold (1036) <u>1036</u> <u>1036</u> <u>1036</u> Hold (1128) <u>1128</u> <u>1128</u> <u>1128</u> Hold (1153) <u>1153</u> <u>1153</u> <u>1153</u></p>													avg. = 89.2	
<p>o = 64 v = 40.10 11 A/12</p>														

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayward, WI
 Source Line 2 Deger R70 / Stack
 Method 5 Filter holder: Glass
 Sample Train Leak Check:

Date 7-12-84 Test 1 Run 2
 No. of traverse points 16
 Filter type: 4" G.F.

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 10 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

6792

Recovery solvent(s)

Acetone _____
 other(s) _____

No. of probe wash bottles:
 Sample recovered by:

1
M. Kaehler + K. Nussmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	704	496	208
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1449	1439	10
Total			218

Integrated Gas Sampling Data:

Bag Pump No. 2913
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1305
 Sampling rate: 400

Box No. 30 Bag No. 2
 Size: 4.4 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 1410 (HRS)
 cc/min Operator: M. Kaehler

S/N of O₂ Analyzer used to monitor train outlet: 9

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / Hayward, WI Date 2-11-94 Test 1 Run 3
 Source Line 2 Dryer RTO / Stack No. of traverse points 16
 Method 5 Filter holder: Glass Filter type: 4" G.F.
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 9 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: 6783 Recovery solvent(s):
 Acetone _____
 other(s) _____
 No. of probe wash bottles: 1
 Sample recovered by: M. Kachler + K. Nelson Sherl

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	691	502	189
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1539	1524	15
Total			204

Integrated Gas Sampling Data:

Bag Pump No. 298 Box No. 30 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1500 (HRS) Time end: 1611 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kachler
 S/N of O₂ Analyzer used to monitor train outlet: 9

INTERPOL LABORATORIES PO METHOD 2 FIELD DATA SHEET


Job L.P. Hayward, Ill. Pitot No. 290.2 CP BY
 Sample Line Dryer #10 Bar. Press. 28.7 InHg 22.7
 Date 2-12-94 Moisture No. 2-Y Monthly Dry 253 H.

Gravity Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (inHg)	Drifts Meter (inHg)	Def. Vol. (%)	VAC. InHg	Temperature (°F)				Oxygen (cc/vol)								
							Stack	Pruby	Dryer	Inpy.		Gas/In	Gas/Out						
	1500	595.60																	
B-0	4	597.90	.59	1.02	0.01	Y	227	233	45	97	98	17.1							
	8	600.34	.57	.99	0.38	Y	231	240	45	99	97	17.1							
	12	603.00	.70	1.21	3.00	S	226	239	44	102	97	17.5							
	16	605.54	.69	1.17	5.58	S	230	242	44	104	96	16.8							
	20	608.14	.68	1.17	0.16	S	230	238	44	105	96	17.3							
	24	610.72	.66	1.15	0.72	S	231	236	44	106	95	17.6							
	28	613.25	.66	1.13	3.07	S	230	242	44	106	96	17.2							
	32	615.02	.65	1.11	5.70	S	233	245	44	108	95	17.0							
A-0	36	618.25	.65	1.12	8.31	S	229	243	46	104	96	12.6							
	40	620.07	.72	1.25	0.98	6	239	249	46	103	96	17.5							
	44	623.54	.71	1.24	3.63	6	246	257	47	106	96	17.6							
	48	626.15	.69	1.20	6.65	5.5	248	255	47	107	96	17.1							
	52	628.70	.63	1.09	0.75	5.5	247	257	47	108	97	17.2							
	56	631.18	.60	1.06	1.21	5.5	250	260	47	109	97	17.3							
	60	633.66	.63	1.11	3.24	5.5	239	253	47	110	98	17.5							
	64	635.86	.46	.81	5.89	4.5	242	250	48	110	98	16.6							
	1611																		
Σ = 64											Avg. = 100.8								

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP / HAYWARD
 Source LINE 2 SURFACER DRYER RTO INLET
 Test 2 Run 2 Date 7-12-94
 Stack Dimen. 42 IN.
 Dry Bulb 199 °F Wet bulb 142 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.72 IN.HG
 Static Pressure -16.30 IN.WC
 Operators B. A. HENRICH J.
 Pitot No. 27V-4 C. 84



PM10/NOx

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4</u> IN.		Time Start: <u>0846</u> HRS	
A - 1	.021	.882	4.882	1.50	
2	.067	2.814	6.814	1.80	
3	.118	4.956	8.956	1.85	
4	.177	7.434	11.434	1.80	
5	.250	10.500	14.500	1.70	
6	.356	14.952	18.952	1.55	199
7	.644	27.048	31.048	1.95	
8	.750	31.500	35.500	2.10	
9	.823	34.566	38.566	2.15	
10	.882	37.044	41.044	2.10	
11	.933	39.186	43.186	1.80	
12	.979	41.118	45.118	1.95	
B - 1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					

Time End: 0850 HRS

Temp. Meas. Device & S/N: TM POT 33

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / HAYWARD Date 7-12-84 Test 2 Run 1
 Source SURFACE DRYER PTO INLET No. of traverse points 24
 Method 5 Filter holder: GLASS Filter type: 4" GFF
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

1 (6635)

Recovery solvent(s)

Acetone _____
 other(s) _____

No. of probe wash bottles:

Sample recovered by:

BOB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	703	3200	203
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1482	1456	26
Total			229

Integrated Gas Sampling Data:

Bag Pump No. 27B
 Bag Material: 3-layer Aluminized Tedlar
 Pretest leak check: 0.0
 Time start: 1017
 Sampling rate: 400

Box No. 28 Bag No. 1
 Size: 4" I
 cc/min at 400 in. Hg.
 (HRS) Time end: 1204 (HRS)
 cc/min Operator: BOB

S/N of O₂ Analyzer used to monitor train outlet: 5

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job: CP / Highway 2
 Site: 3500 Sufferer Drive, Reno, NV 89512
 Date: 7-12-84
 Operator: BA JS
 Method: EPA 5
 Trip No.: 220-4
 Bar. Press. 29.22
 Bottle No. 5-3
 Trip Date: July 12, 1984
 Bottle Date: July 12, 1984

Traverse Point No.	Sampling Time (min)	Sample Volume (ml)	Volatility (mM)	Distillation Water (mM)	Det. Vol. (%)	VAD. Integ.	Temperature (°F)				Oxygen (kPa)	
							Stack	Flue	Dry	Wet		
A-12	10:17	853.90	1.80	1.56	5.62	7	206	245	255	50	74	18.2
11	7.5	855.53	1.85	1.62	7.58	8	206	247	252	47	74	18.2
10	7.5	859.04	1.96	1.66	9.16	8	208	247	252	47	75	18.1
9	10	860.82	1.85	1.62	0.93	8	207	250	250	45	76	18.2
8	12.5	862.58	1.75	1.54	2.65	8	207	250	250	45	76	17.8
7	15	864.35	1.90	1.67	4.45	8	207	246	251	43	77	17.9
6	12.5	866.19	2.10	1.85	6.34	8.5	208	246	251	43	77	18.1
5	20	868.13	2.15	1.90	8.25	9.5	208	250	249	45	78	17.8
4	22.5	870.07	2.20	1.95	6.19	9	207	250	249	45	79	17.7
3	25	872.02	2.15	1.90	2.11	9.5	207	247	251	43	79	17.8
2	22.5	873.92	2.00	1.76	3.96	9	208	247	251	43	79	17.9
1	30	875.79	1.95	1.72	5.79	9	208	248	253	41	80	18.1
B-12	32.5	877.82	2.45	2.17	7.84	9	208	248	253	41	80	18.2
11	35	878.83	2.50	2.22	9.91	10	206	250	255	41	81	17.7
10	32.5	881.84	2.45	2.18	1.97	11	207	250	255	41	81	17.6
9	40	883.90	2.50	2.23	4.06	11	207	249	251	40	82	17.8
8	42.5	886.00	2.25	2.01	6.04	11	205	249	251	40	83	18.0
7	45	887.95	2.20	1.96	8.00	11	207	247	250	40	83	17.7
6	47.5	889.87	1.95	1.74	9.85	11	207	247	250	40	84	17.9
5	50	891.60	1.70	1.52	1.58	9.5	207	247	250	39	82	18.1
4	52.5	893.28	1.60	1.42	3.25	8	208	247	251	40	83	17.6
3	55	895.03	1.90	1.70	5.07	8.5	205	250	249	39	84	17.7
2	57.5	896.72	1.80	1.61	6.84	9	207	250	249	39	85	17.6
1	60	898.41	1.40	1.25	8.41	9	207	250	249	39	85	17.5
Total Sample Volume = 44.5 l Total O2 = 60											82.5	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP / HAYWARD
 Source SURFACE DRAIN PTO INLET
 Method 5 Filter holder: GLASS
 Sample Train Leak Check:

Date 7-2-84 Test 2 Run 2
 No. of traverse points 24
 Filter type: 4" GFF

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 16 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

(6636) 1

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles:
 Sample recovered by:

(1)
663

Condensate Data:

Item	Weight (g)		Difference
	Final	Tare	
Impinger No. 1	369	200	169
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1421	1380	41
Total			216

Integrated Gas Sampling Data:

Bag Pump No. 27B
 Bag Material: 5-layer Aluminized Tedlar
 Prerest leak check: 0-0
 Time start: 1305
 Sampling rate: 400

Box No. 28 Bag No. 2
 Size: 4 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 1409 (HRS)
 cc/min Operator: 663
5

S/N of O₂ Analyzer used to monitor train outlet:

INTERPULL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

CP / MAYNARD
3-12-84
1081

Operator
Halter Box No
Cassette No

Pilot No. 22-4
Run 135
2947

Op. 84
July 1120
207
187

Gravity Point No.	Sampling Time (min)	Supply Volume (cc)	Velocity (ft/min)	Drift (ft/min)	Dev. Vol. (%)	VAC. (inHg)	Temperature (°F)				Oxygen (kV/v)	
							Stack	Probe	Duct	Imp.		
B-12	(1305) 2.5	898.70	2.56	2.22	0.77	8	205	245	251	44	83	17.9
11	5	900.84	2.65	2.36	2.91	9	205	247	251	44	83	17.9
10	7.5	905.06	2.70	2.41	5.08	9	204	247	251	44	88	17.9
9	10	907.07	2.46	2.15	2.13	9	205	249	249	43	90	18.2
8	12.5	909.05	2.26	1.97	9.69	8.5	205	249	249	43	91	18.3
7	15	911.00	2.16	1.89	1.62	8	204	249	253	42	92	18.4
6	17.5	912.88	2.16	1.89	2.73	8	205	249	253	42	93	18.5
5	20	914.67	1.75	1.58	4.71	8	206	246	251	41	94	18.0
4	22.5	916.47	1.70	1.53	6.45	8	206	246	251	41	94	18.0
3	25	918.19	1.80	1.62	8.24	8	205	249	250	40	95	18.2
2	27.5	919.93	1.76	1.53	9.98	8	206	249	250	40	96	18.7
1	30	921.63	1.40	1.26	1.57	7	206	249	250	40	97	18.8
A-12	32.5	923.56	1.90	1.72	3.41	8.5	207	251	248	40	93	18.3
11	35	925.23	1.90	1.71	5.25	8	206	250	251	39	96	18.0
10	37.5	927.06	2.00	1.81	7.14	8.5	206	250	251	39	97	18.0
9	40	928.87	1.75	1.57	8.91	8.5	205	248	253	39	98	17.7
8	42.5	930.65	1.70	1.54	6.66	8.5	206	248	253	39	98	17.7
7	45	932.55	1.90	1.72	2.51	9	206	248	250	38	98	17.8
6	47.5	934.23	2.80	1.64	4.32	9	205	248	250	38	99	17.8
5	50	936.20	2.26	2.00	6.31	10	204	250	250	39	99	17.6
4	52.5	938.17	2.25	2.05	8.32	11	205	250	250	39	99	17.5
3	55	940.14	2.20	2.01	6.32	11	206	247	251	39	99	17.9
2	57.5	942.20	2.00	1.82	2.22	11	205	247	251	39	99	18.0
1	60	944.23	2.20	2.00	4.21	11	206				99	
		1409									avg.	96.5
		0 = 60										
		45.53										

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / HAYWARD Date 7-12-84 Test 2 Run 3
 Source SUN-FACER DRYER PROJECT No. of traverse points 24
 Method 5 Filter holder Class Filter type: 4" GFF
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 25 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: (2) 6637 Recovery solvent(s) _____
5157 Gasstone _____
 other(s) _____
 No. of probe wash bottles: 1
 Sample recovered by: SAR

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	379	3200	179
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1517	1482	35
Total			214

Integrated Gas Sampling Data:

Bag Pump No. 27B Box No. 28 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 4.4 L
 Pretest leak check: 0.0 75 in. Hg.
 Time start: 1500 (HRS) Time end: 1611 (HRS)
 Sampling rate: 900 cc/min Operator: SAR

S/N of O₂ Analyzer used to monitor train outlet: 5

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job: LP / HOYKARD Operator: DA Pilot No.: 22-4 Ep: 84
 Equip: 2-12-54 Model: 200 Box No.: 200 Bar. Press.: 28.2 Inlet H₂O: 30 °F
 Date: 7-12-54 Run: 3 Sample: 2 Humidity: 53 Nozzle Dia: 22 in.

Sample Point No.	Sampling Time (min)	Sample Volume (cfs)	Velocity Head (in H ₂ O)	Orifice Meter (in H ₂ O)	Dep. Vol. (cfs)	VAD. Inlet	Temperature (°F)				Oxygen (xv/v)			
							Blank	Probe	Down	Inlet		Gas In	Gas Out	
A-12	2.5	944.55	2.10	1.90	6.44	7.5	205	247	250	40	88	87	17.9	
11	5	948.22	1.80	1.68	8.26	7.5	207				91	87	18.2	
10	7.5	950.10	1.96	1.78	0.13	8	205	249	249	41	92	88	18.0	
9	10	951.95	2.00	1.87	2.05	8	207				94	89	18.0	
8	12.5	953.90	1.95	1.84	3.96	8	204	247	251	40	95	89	18.1	
7	15	955.80	2.10	1.98	5.23	8.5	205				96	89	17.8	
6	17.5	957.80	2.00	1.89	7.87	9	204	250	250	39	97	89	18.3	
5	20	957.85	2.20	2.07	9.87	10	206				97	90	17.8	
4	22.5	961.60	2.20	2.08	1.92	10	205	247	252	40	97	90	18.0	
3	25	963.76	2.00	1.87	3.86	11	205				97	90	18.3	
2	27.5	965.50	1.90	1.79	5.74	15	206	250	249	39	97	91	18.2	
1	30	967.00	1.70	1.61	7.53	16	205				95	90	17.6	
B-12	32.5	970.50	2.35	2.21	0.42	9	206	245	251	39	92	90	18.1	
11	35	972.18	2.50	2.35	2.28	10	204				94	90	17.6	
10	37.5	974.40	2.60	2.45	4.47	11	205	247	250	38	94	90	17.9	
9	40	976.61	2.60	2.45	6.67	11	205				95	91	18.4	
8	42.5	977.82	2.70	2.54	7.91	11.5	206	247	249	39	96	91	18.0	
7	45	981.00	2.60	2.45	1.12	11.5	205				96	91	17.9	
6	47.5	982.91	2.90	1.89	3.05	9	205	250	251	39	97	91	18.1	
5	50	984.60	1.70	1.61	4.84	9	204				97	91	18.1	
4	52.5	986.50	1.70	1.61	6.63	9	205	249	253	40	98	92	18.0	
3	55	988.40	1.70	1.61	8.42	9	204				99	92	17.1	
2	57.5	990.04	1.50	1.42	0.10	8	205	250	250	39	100	92	17.4	
1	60	991.80	1.60	1.52	1.85	10	204				100	93	17.4	
							v ₀ = 47.25				AVG. = 92.4			
							v ₁₁ = 1.94							

Change Filters or Part Change
 Teleclic Check

Part 5 on

Interpoll Laboratories
(612)786-6020

EPA Method 7 Sample Collection
Field Data Sheet

Job CP1 HAYWARD
Test Location Interpoll Supercenter
Project RTO Duct

Date 7-12-94
Fuel Type NAT GAS
Technician TEFF

Bar. Pressure 28.72 IN.HG.
Sample Train No. 06007
Pump No. 27B

No.	Test Run Point	Flask No.	Time (HRS)	Vacuum (IN.HG.)	Flask Temp. (°F)	Leak Rate < 0.4 IN.HG./MIN.
1	2-1-1	1	10:17	26.4	100°	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
2	2-1-2	2	10:34	26.4	101°	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3	2-1-3	3	11:28	26.4	101°	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
4	2-1-4	4	11:50	26.5	103°	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
5	2-2-1	5	13:10	26.3	104	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
6	2-2-2	6	13:30	26.4	103	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
7	2-2-3	7	13:45	26.3	104	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
8	2-2-4	9	14:00	26.4	103	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
9	2-3-1	10	15:05	26.4	101	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
10	2-3-2	11	15:20	26.3	101	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
11	2-3-3	12	15:45	26.3	100	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
12	2-3-4	28	16:00	26.2	100	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
13						<input type="checkbox"/> Yes <input type="checkbox"/> No
14						<input type="checkbox"/> Yes <input type="checkbox"/> No
15						<input type="checkbox"/> Yes <input type="checkbox"/> No
16						<input type="checkbox"/> Yes <input type="checkbox"/> No
17						<input type="checkbox"/> Yes <input type="checkbox"/> No
18						<input type="checkbox"/> Yes <input type="checkbox"/> No
19						<input type="checkbox"/> Yes <input type="checkbox"/> No
20						<input type="checkbox"/> Yes <input type="checkbox"/> No
21						<input type="checkbox"/> Yes <input type="checkbox"/> No
22						<input type="checkbox"/> Yes <input type="checkbox"/> No
23						<input type="checkbox"/> Yes <input type="checkbox"/> No
24						<input type="checkbox"/> Yes <input type="checkbox"/> No
25						<input type="checkbox"/> Yes <input type="checkbox"/> No
26						<input type="checkbox"/> Yes <input type="checkbox"/> No
27						<input type="checkbox"/> Yes <input type="checkbox"/> No


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / Hayward
 Source Line 3 Core Dryer Stack
 Test 3 Run Date 7-19-94
 Stack Dimen. 42 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.71 IN.HG
 Static Pressure -11.4 IN.WC
 Operators D.M.
 Pitot No. 290-4 C₂ 370



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)	
		Port Length: <u>4</u> IN.		Time Start: <u>0846</u>	HRS	
A	1	.021	.88	4.88	.90	
	2	.067	2.81	6.81	1.25	
	3	.118	4.96	8.96	1.20	
	4	.177	7.43	11.43	1.20	
	5	.250	10.50	14.50	1.10	
	6	.356	14.95	18.95	1.40	
	7	.644	27.05	31.05	1.70	235
	8	.750	31.50	35.50	1.90	
	9	.823	34.57	38.57	2.10	
	10	.882	37.04	41.04	2.10	
	11	.933	39.19	43.19	2.15	
	12	.979	41.12	45.12	2.30	
B	1	.021	.81	4.88	1.55	
	2	.067	2.81	6.81	1.55	
	3	.118	4.96	8.96	1.70	
	4	.177	7.43	11.43	1.70	
	5	.250	10.50	14.50	1.40	
	6	.356	14.95	18.95	1.20	
	7	.644	27.05	31.05	1.30	235
	8	.750	31.50	35.50	1.30	
	9	.823	34.57	38.57	1.90	
	10	.882	37.04	41.04	1.70	
	11	.933	39.19	43.19	1.70	
	12	.979	41.12	45.19	1.90	

Temp. Meas. Device & S/N: PDT 33

0856 Time End: HRS

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Hammond Date 7-12-94 Test 3 Run 1
 Source Line 3 Core Driven Stack No. of traverse points 24
 Method 5 Filter holder: 4" Glass Filter type: 4" GFF
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 1 cfm at 8 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: 6720 Recovery solvent(s):
 acetone _____
 other(s) _____
 No. of probe wash bottles: 1
 Sample recovered by: DM

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		{ 100 }	
Impinger No. 2	344	{ 100 }	199
Impinger No. 3		{ 0 }	
Condenser			
Desiccant	1460	1443	17
Total			216

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 15 Bag No. 1
 Bag Material: 3-layer Aluminized Tedlar Size: 15 in. Hg.
 Pretest leak check: 0 cc/min at _____
 Time start: 10:17 (HRS) Time end: 12:04 (HRS)
 Sampling rate: 400 cc/min Operator: DM
 S/N of O₂ Analyzer used to monitor train outlet: NA

INTERPOLL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job L.P. HAYWARD
 Sampling Point No. 3
 Date 7-1-89
 Operator AP
 Order No. 840
 Sample No. 231-4
 Batch No. 120
 Station No. 183
 Facility No. 403-110

Inverter Point No.	Sampling Time (min)	Supply Volume (gals)	Velocity Hood (ft/min)	Orifice Meter (ft/min)	VOC Vol. (%)	VAD, Inlet	Temperature (°F)				Oxygen (%)		
							Block	Probe	Duct	Top			
A	10:17	84.10	1.65	1.08	5.55	5	235	245	265	45	75	74	17.5
	2.5	85.44	1.65	1.08	7.01	5	239	241	267	45	77	74	17.6
	5	87.00	1.20	1.45	8.77	7	233	240	262	45	70	75	10.6
	7.5	88.45	1.85	1.20	0.25	6	245		260		80	75	
	10	90.00	1.65	1.07	1.71	6	247	241	263	46	80	75	
	12.5	91.48	1.40	1.93	3.07	6	235		263		82	76	
	15	92.35	1.30	1.86	4.38	6	235	250	257	47	83	77	
	17.5	94.22	1.05	1.70	5.56	6	235		262	48	84	77	
	20	95.75	1.10	1.73	6.28	5	235	251	262		80	78	
	22.5	96.69	1.20	1.61	8.05	5	222		252	48	83	79	
	25	98.23	1.10	1.75	9.28	5	217	249	252		83	79	
	27.5	99.46	1.20	1.83	0.56	5	212	240	255	49	85	80	
B	30	100.64	1.90	1.28	2.17	7	227	244	260		85	80	
	32.5	102.40	1.70	1.14	3.68	7	232	244	260	49	86	81	
	35	103.87	1.70	1.14	5.20	6	232	238	257	49	88	82	
	37.5	105.25	1.90	1.28	6.80	7	234	238	260		89	82	
	40	106.87	1.30	1.88	8.13	8	232	240	260	50	89	82	
	42.5	108.27	1.2	1.81	9.41	6	233	240	260		89	83	
	45	109.54	1.2	1.81	0.69	6	233	245	261	50	89	83	
	47.5	110.83	1.4	1.13	2.07	7	233	245	261		85	83	
	50	112.19	1.7	1.13	3.56	7	238	240	262	51	87	83	
	52.5	113.67	1.55	1.04	6.61	8	238	240	262		88	83	
	55	115.20	1.55	1.04	8.06	8	235	240	262		88	83	
	57.5	116.20	1.55	1.04	8.06	8	235	240	262		88	83	
	60	118.12	1.55	1.04	8.06	8	235	240	262		88	83	
											Avg. = 78.1		
											v = 34.02		
											σ = 60		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Hayward Date 7-12-94 Test 3 Run 2
 Source Line 3 Core Drac Stack No. of traverse points 24
 Method 5 Filter holder: Glass Filter type: 4" GPF
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 2 cfm at 8 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:
6744

Recovery solvent(s)
 Acetone _____
 Other(s) _____
DM

No. of probe wash bottles:
 Sample recovered by: _____

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		(100)	
Impinger No. 2	433	(100)	233
Impinger No. 3		(0)	
Condenser			
Desiccant	1464	1458	6
Total			239

Integrated Gas Sampling Data:

Bag Pump No. 23 B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1303
 Sampling rate: 400 cc

Box No. 15 Bag No. 2
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 1410 (HRS)
 cc/min Operator: DM
NA

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

7360

Job No. 4 P. L. Hwy
 Sample Line 2
 Date 7-13-94
 Operator DM
 Meter Box No. 55
 Recorder Model 9763

Plot No. 23 V. 4
 Bur. File No. 3307
 Mobile No. 7-3
 EP 840
 Date 7-13-94

Traverse Point No.	Supplying Trip (min)	Supply Volume (gal)	Velocity Head (ft)	Driftless Meter (ft)	VAC. (ft)	Obs. Vol. (gal)	Temperature (°F)				Oxygen (KPa)	
							Block	Probe	Dry	Wet		
8	13.03	118.84	1.70	.73	0.04	4	234	270	250	46	84	83
	2.5	120.12	1.60	.97	1.44	4	241	250	250	46	85	83
	5	121.49	1.65	1.01	2.87	5	241	241	253	46	87	83
	7.5	122.98	1.50	.91	4.22	5	241	244	260	47	88	84
	10	124.30	1.2	.73	5.44	5	241	244	260	47	89	84
	12.5	125.55	1.91	.56	6.51	4	241	250	254	47	90	85
	15	126.60	1.2	.74	7.73	4	240	250	254	47	91	86
	17.5	127.65	1.5	.92	9.09	4	240	261	253	48	92	86
	20	129.20	1.65	1.06	10.53	5	240	257	243	49	92	86
	22.5	130.64	1.35	.83	12.33	6	240	257	243	49	94	86
	25	131.95	1.35	.83	3.13	5	241	265	245	49	94	87
	27.5	133.26	1.5	1.58	5.47	5	241	265	245	49	94	87
	30	135.60	1.95	1.20	7.03	7	241	263	250	49	95	88
A 12	32.5	136.64	1.17	1.17	8.57	7	241	259	248	50	96	89
	35	138.17	1.18	1.15	10.08	7	241	255	253	50	96	89
	37.5	143.89	1.6	.99	1.50	7	240	257	248	50	96	90
	40	141.20	1.4	1.11	3.01	7	241	255	253	50	96	90
	42.5	142.78	1.2	.74	4.34	6	241	257	249	50	96	90
	45	144.10	1.97	.56	5.31	5	240	255	249	50	96	90
	47.5	145.25	1.92	.57	6.40	5	241	257	249	50	96	90
	50	146.40	1.97	.60	7.51	5	241	255	249	50	96	90
	52.5	147.54	1.00	.62	8.63	5	240	255	249	50	96	90
	55	148.68	1.10	.68	9.82	5	240	255	249	50	96	90
	57.3	149.88	1.10	.68	9.82	5	240	255	249	50	96	90
	60	151.37	1.3	.81	1.10	6	240	255	249	50	97	90

va = 52.53

vo = 60

av = 59.7

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP Hayward Date 7-12-94 Test 3 Run 3
 Source Unit 3 Core Drive Tank No. of traverse points 2-4
 Method 5 Filter holder: 2" GTS-3 Filter type: 2" GF
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 13 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

6743

Recovery solvent(s)

Acetone _____
 Other(s) _____

No. of probe wash bottles: _____
 Sample recovered by: DM

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		<u>100</u>	
Impinger No. 2	<u>403</u>	<u>100</u>	<u>203</u>
Impinger No. 3		<u>0</u>	
Condenser			
Desiccant	<u>1493</u>	<u>1485</u>	<u>13</u>
Total			<u>216</u>

Integrated Gas Sampling Data:

Bag Pump No. 23B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: P
 Time start: 1500
 Sampling rate: 4.00

Box No. 15 Bag No. 3
 Size: 4.5 L
 cfm/min at 15 in. Hg.
 (HRS) Time end: 1611 (HRS)
 cfm/min Operator: DM

S/N of O₂ Analyzer used to monitor train outlet: NA

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET


Job LP / Hayward Operator DM - JZ Pibal No. 230-9 Cp. 890
 Sample Line 2 Date 10/23/87 Hdr. 3 Hdr. Box No. 4 Hdr. Proc. 230-9 Hdr. Proc. 17X
 Date 7-12-87 Recorder 1061 Hdr. 3 Hdr. No. 2-3 Hdr. No. 230-9 Hdr. No. 11

Traverse Point No.	Sampling Time (min)	Supply Volume (cfs)	Velocity Head (inHg)	Orifice Meter (inHg)	Orifice Vbl. (cfs)	VAC. InHg	Temperature (°F)				Oxygen (XV/V)	
							Stack	Probe	Duct	Inph.		
A	(1500)	(151.55)	2.1	1.24	3.15	7	238	242	257	46	87	86
	2.5	153.37	1.9	1.09	4.64	6	239	252	261	46	86	86
	5	154.81	2.0	1.15	6.16	6	240	252	261	46	90	87
	7.5	156.53	1.8	1.04	7.61	6	239	250	257	47	90	87
	10	158.08	1.6	.92	8.98	6	240	250	257	47	91	87
	12.5	159.47	1.5	.86	10.31	5	240	256	262	47	92	88
	15	160.67	1.1	.63	11.44	5	239	256	262	47	93	88
	17.5	161.99	1.2	.69	12.63	5	240	242	271	46	93	89
	20	163.70	1.2	.69	13.82	5	240	250	266	46	94	88
	22.5	164.42	1.0	.58	14.91	5	239	250	266	46	94	89
	25	165.56	1.0	.58	16.00	5	240	254	255	47	95	89
	27.5	166.70	1.0	.58	17.09	5	240	254	255	47	95	89
	30	167.78	1.3	.75	18.33	6	240	249	261	47	95	89
B	32.5	168.19	1.8	1.04	19.76	7	241	249	261	47	93	89
	35	170.63	1.5	.87	21.11	7	241	251	257	48	92	89
	37.5	172.00	1.5	.87	22.45	7	240	251	257	48	94	90
	40	173.30	1.3	.75	23.69	7	240	247	263	48	94	90
	42.5	174.55	1.2	.70	24.88	7	241	247	263	48	96	90
	45	175.76	1.5	.87	26.22	8	240	244	255	48	96	91
	47.5	176.16	1.5	.87	27.55	8	239	244	255	48	96	91
	50	178.39	1.4	.81	28.85	10	240	244	255	48	96	91
	52.5	179.70	1.4	.81	30.14	10	240	246	256	49	97	91
	55	180.09	1.7	.99	31.56	11	240	246	256	49	97	91
	57.5	182.44	1.8	1.05	33.02	13	239	246	256	49	97	91
	60	184.23	1.8	1.05	34.02	13	240				97	91
	(1611)										avg. =	91.3

North

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job CP / HAYWARD
 Source LINE 2 SURFACE DRAIN PTD INLET
 Test 5 Run 1 Date 7-12-96
 Stack dimen. 42 IN.
 Dry bulb 209 °F Wet bulb 144 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.72 in Hg
 Static pressure -17.10 in WC
 Operators B. Aschbacher & J. Johnson
 Pitot No. 270-4 Cp -84




Drawing of Test Site

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
Port length: <u>4.0</u> in.				Time start: <u>1854</u> hrs	
<u>B</u>	<u>12</u>			<u>1.95</u>	
	<u>11</u>			<u>2.30</u>	
	<u>10</u>			<u>2.40</u>	
	<u>9</u>			<u>2.25</u>	
	<u>8</u>			<u>2.10</u>	
	<u>7</u>			<u>1.70</u>	
	<u>6</u>			<u>1.40</u>	
	<u>5</u>			<u>1.55</u>	
	<u>4</u>			<u>1.45</u>	
	<u>3</u>			<u>1.50</u>	
	<u>2</u>			<u>1.75</u>	
	<u>1</u>			<u>1.65</u>	
<u>A</u>	<u>12</u>			<u>1.60</u>	
	<u>11</u>			<u>1.85</u>	
	<u>10</u>			<u>1.95</u>	
	<u>9</u>			<u>1.70</u>	
	<u>8</u>			<u>1.95</u>	
	<u>7</u>			<u>1.80</u>	
	<u>6</u>			<u>1.90</u>	
	<u>5</u>			<u>2.00</u>	
	<u>4</u>			<u>1.90</u>	
	<u>3</u>			<u>2.10</u>	
	<u>2</u>			<u>1.45</u>	
	<u>1</u>			<u>1.40</u>	
Temp. meas. device & S/N: <u>PDT 33</u>				Time end: <u>1906</u> hrs	

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job CD / HAYWARD
 Source Line 2 Surface Pryer RTO Ret
 Test 5 Run 2 Date 7-12-94
 Stack dimen. 42 IN.
 Dry bulb 71.0 °F Wet bulb 46 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.72 in Hg
 Static pressure -17.10 in WC
 Operators B. Scherlock & J. Scripser
 Pitot No. 270-4 Cp .84



Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>4</u> in.		Time start <u>2015</u> hrs	
<u>B</u>	<u>1</u>			<u>1.65</u>	
	<u>2</u>			<u>1.40</u>	
	<u>3</u>			<u>1.55</u>	
	<u>4</u>			<u>1.55</u>	
	<u>5</u>			<u>1.60</u>	
	<u>6</u>			<u>1.35</u>	
	<u>7</u>			<u>1.60</u>	
	<u>8</u>			<u>2.00</u>	
	<u>9</u>			<u>2.25</u>	
	<u>10</u>			<u>2.40</u>	
	<u>11</u>			<u>2.45</u>	
	<u>12</u>			<u>2.20</u>	
<u>A</u>	<u>1</u>			<u>1.60</u>	
	<u>2</u>			<u>1.60</u>	
	<u>3</u>			<u>1.70</u>	
	<u>4</u>			<u>1.50</u>	
	<u>5</u>			<u>1.55</u>	
	<u>6</u>			<u>1.75</u>	
	<u>7</u>			<u>2.00</u>	
	<u>8</u>			<u>2.20</u>	
	<u>9</u>			<u>2.25</u>	
	<u>10</u>			<u>2.15</u>	
	<u>11</u>			<u>2.10</u>	
	<u>12</u>			<u>2.00</u>	
Temp. meas. device & S/N: <u>PPT 33</u>				Time end: <u>2075</u> hrs	

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET


Job CP / HIGHWAY
 Source LDG 2 Sullivan Hwy RTO Inlet
 Test 5 Run 3 Date 7-12-76
 Stack dimen. 42 IN.
 Dry bulb 84 °F Wet bulb 42 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.72 in Hg
 Static pressure -16.40 in WC
 Operators B. Schmitt J. Johnson
 Pitot No. 270-4 Cp -84

Cross-section View	Elevation View
Drawing of Test Site	

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>4</u> in.		Time start: _____ hrs	
<u>B</u>	<u>1</u>			<u>2.00</u>	
	<u>2</u>			<u>1.80</u>	
	<u>3</u>			<u>1.50</u>	
	<u>4</u>			<u>1.60</u>	
	<u>5</u>			<u>1.60</u>	
	<u>6</u>			<u>1.45</u>	
	<u>7</u>			<u>1.50</u>	
	<u>8</u>			<u>1.80</u>	
	<u>9</u>			<u>2.15</u>	
	<u>10</u>			<u>2.30</u>	
	<u>11</u>			<u>2.40</u>	
	<u>12</u>			<u>2.25</u>	
<u>A</u>	<u>1</u>			<u>1.20</u>	
	<u>2</u>			<u>1.80</u>	
	<u>3</u>			<u>1.85</u>	
	<u>4</u>			<u>2.00</u>	
	<u>5</u>			<u>1.95</u>	
	<u>6</u>			<u>1.70</u>	
	<u>7</u>			<u>1.65</u>	
	<u>8</u>			<u>1.75</u>	
	<u>9</u>			<u>1.95</u>	
	<u>10</u>			<u>2.20</u>	
	<u>11</u>			<u>1.80</u>	
	<u>12</u>			<u>1.65</u>	
Temp. meas. device & S/N:				Time end: _____ hrs	

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET


Job CP / HAYWARD
 Source LINE 2 COLE DRYER PTO INLET
 Test 6 Run 1 Date 7-12-86
 Stack dimen. 42 IN.
 Dry bulb 225 °F Wet bulb 150 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 78.72 in Hg
 Static pressure -15.40 in WC
 Operators B. SCHENBERG John Johnson
 Pitot No. 2704 Cp .84



Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
			Port length: <u>4.0</u> in.	Time start: <u>1834</u> hrs	
<u>B</u>	<u>12</u>			<u>1.50</u>	
	<u>11</u>			<u>1.85</u>	<u>225</u>
	<u>10</u>			<u>1.70</u>	
	<u>9</u>			<u>1.50</u>	<u>223</u>
	<u>8</u>			<u>1.40</u>	
	<u>7</u>			<u>1.20</u>	<u>226</u>
	<u>6</u>			<u>1.45</u>	
	<u>5</u>			<u>1.65</u>	<u>225</u>
	<u>4</u>			<u>1.85</u>	
	<u>3</u>			<u>1.80</u>	<u>225</u>
	<u>2</u>			<u>1.80</u>	
	<u>1</u>			<u>1.50</u>	<u>224</u>
<u>A</u>	<u>12</u>			<u>1.60</u>	
	<u>11</u>			<u>1.85</u>	<u>225</u>
	<u>10</u>			<u>2.00</u>	
	<u>9</u>			<u>1.85</u>	
	<u>8</u>			<u>1.80</u>	
	<u>7</u>			<u>1.55</u>	
	<u>6</u>			<u>1.35</u>	
	<u>5</u>			<u>1.30</u>	
	<u>4</u>			<u>1.15</u>	
	<u>3</u>			<u>1.20</u>	
	<u>2</u>			<u>1.10</u>	
	<u>1</u>			<u>1.10</u>	
Temp. meas. device & S/N: <u>PDT 33</u>				Time end: <u>1840</u> hrs	

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LP / HAYWARD
 Source Line 2 Core River RTO Inlet
 Test 6 Run 2 Date 7-12-96
 Stack dimen. 42 IN.
 Dry bulb 153 °F Wet bulb 145 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.72 in Hg
 Static pressure -15.30 in WC
 Operators B. Schauback J. Scriber
 Pitot No. 270-4 C. 84



Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>4</u> in.		Time start: <u>2039</u> hrs	
<u>13</u>	<u>1</u>			<u>1.10</u>	
	<u>2</u>			<u>1.75</u>	
	<u>3</u>			<u>1.60</u>	
	<u>4</u>			<u>1.50</u>	
	<u>5</u>			<u>1.25</u>	
	<u>6</u>			<u>1.15</u>	
	<u>7</u>			<u>1.05</u>	
	<u>8</u>			<u>1.10</u>	
	<u>9</u>			<u>1.30</u>	
	<u>10</u>			<u>1.50</u>	
	<u>11</u>			<u>1.65</u>	
	<u>12</u>			<u>1.60</u>	
	<u>1</u>			<u>.90</u>	
	<u>2</u>			<u>.95</u>	
	<u>3</u>			<u>.95</u>	
	<u>4</u>			<u>1.00</u>	
	<u>5</u>			<u>.93</u>	
	<u>6</u>			<u>.85</u>	
	<u>7</u>			<u>1.15</u>	
	<u>8</u>			<u>1.30</u>	
	<u>9</u>			<u>1.60</u>	
	<u>10</u>			<u>1.60</u>	
	<u>11</u>			<u>1.45</u>	
	<u>12</u>			<u>1.50</u>	
Temp. meas. device & S/N: <u>PDT 33</u>				Time end: <u>2045</u> hrs	

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job LD HAYWARD
 Source Case 2 Core Drift R10 Inlet
 Test 6 Run 3 Date 7-12-54
 Stack dimen. 42 IN.
 Dry bulb 239 °F Wet bulb 151 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 28.72 in Hg
 Static pressure -15.20 in WC
 Operators B. Aschbacher & J. Johnson
 Pitot No. 270-4 Cp -84

Cross-section View	Elevation View
Drawing of Test Site	

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
Port length: <u>4.0</u> in.			Time start: <u>2:59</u> hrs		
B	1			1.70	
	2			1.65	
	3			1.60	
	4			1.55	
	5			1.35	
	6			1.20	
	7			1.10	
	8			1.35	
	9			1.50	
	10			1.65	
	11			1.70	
	12			1.40	
A	1			1.05	
	2			1.10	
	3			1.30	
	4			1.20	
	5			.90	
	6			1.05	
	7			1.40	
	8			1.65	
	9			1.70	
	10			1.95	
	11			2.10	
	12			1.90	
Temp. meas. device & S/N: <u>PPT 33</u>				Time end: <u>2:05</u> hrs	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. HAYWARD Date 7-12-94 Test 7 Run 1
 Source LINE 2 DAYTON STAX No. of traverse points 16
 Method 0011 Filter holder: NA Filter type: N/A
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 8 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: NA Recovery solvent(s):
 Acetone
 Other(s) MeCl₂
 No. of probe wash bottles: 0
 Sample recovered by: DM + K. Nussmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			290
Impinger No. 3			
Condenser			
Desiccant	1480	1444	36
Total			320

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 12 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1931 (HRS) Time end: 1939 (HRS)
 Sampling rate: 400 cc/min Operator: DM
 S/N of O₂ Analyzer used to monitor train outlet: 9

INTERPOL LABORATORY DATA SHEET

Job LP/MAYAGUEZ
 Sample LINE 2 PAPER AND STRIP
 Date 7-12-84 RUN 1

Operator DM
 Mailing Box No. 10
 Computer Code 1

TRM 677
 Run 9830

Pilot No. 4012-8
 Ref. Prod. 3821
 Roll No. GLASS
 Roll No. 303

Traverse Point No.	Sampling Time (min)	Supply Volume (cc)	Vol. Inlet (inlet)	Detector Response (mV)	Det. Vol. (cc)	VAC. (mmHg)	Sample	Blank	Flow	Temp. (°C)	Temp. (°F)	Out/Det	Oxy (v/v)
A	(1830)	(636,70)	.70	2.86	0.72	5	356	227	248	55	17.1	91	17.1
	4	640,12	.77	3.12	4.88	6	347	231	246	58	17.2	91	17.2
	8	644,42	.72	2.87	6.89	6	363	233	245	58	16.9	91	16.9
	12	647,39	.75	3.07	3.03	6	343	231	245	58	17.4	91	17.4
	16	651,20	.68	2.81	7.00	7	337	230	251	59	17.7	90	17.7
	20	655,20	.70	2.81	0.97	7	361	231	247	59	17.3	91	17.3
	24	659,45	.63	2.57	4.77	8	351	232	243	59	17.1	91	17.1
	28	664,51	.60	2.45	8.49	6	351	231	245	59	17.3	91	17.3
	32	668,34	.65	2.65	2.36	6	352	231	252	59	17.3	92	17.3
	36	672,08	.74	3.18	6.52	7	341	229	257	58	17.4	93	17.4
	40	676,20	.75	3.08	0.68	8	348	230	255	58	18.1	93	18.1
	44	680,50	.75	2.85	4.69	8	356	233	270	59	17.8	92	17.8
	48	684,62	.75	3.09	8.87	8	345	230	270	58	17.7	94	17.7
	52	688,80	.72	3.01	2.99	8	336	229	269	56	17.7	94	17.7
	56	692,95	.71	2.90	7.05	8	354	232	268	54	18.1	95	18.1
	60	697,10	.55	2.27	0.64	7	350	235	269	57	17.3	95	17.3
	64	700,83											
	(1940)												
	0 = 64	V = 64.13		2.84								97.3	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / Hayward Date 7-12 Test 2 Run 2
 Source Line 2 Dryer R00 Outlet No. of traverse points 16
 Method 0011 Filter holder: N/A Filter type: NA
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: ≤ 0.02 cfm at 15 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone
 other(s) Methyl Chloride

No. of probe wash bottles:
 Sample recovered by:

1
E. Troubridge E. K. Nussmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	787	467	320
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	411	380	31
Total			351

Integrated Gas Sampling Data:

Bag Pump No. 29B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 2015
 Sampling rate: 400 cc

Box No. 12 Bag No. 2
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 2121 (HRS)
 cc/min Operator: DM

S/N of O₂ Analyzer used to monitor train outlet:

9

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP / Hayward Date 7-12-94 Test 7 Run 3
 Source AINE 2 DRUM RTO-STACK No. of traverse points 16
 Method CO II Filter holder: N/A Filter type: N/A
 Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0 cfm at 7 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:

N/A

Recovery solvent(s)

acetone
 other(s) Methyl Chloride

No. of probe wash bottles:

0

Sample recovered by:

DM

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			312
Impinger No. 3			
Condenser			
Desiccant	1447	1415	32
Total			344

Integrated Gas Sampling Data:

Bag Pump No. 29B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 2156
 Sampling rate: 400 cc/min

Box No. 12 Bag No. 3
 Size: 44 L
 cc/min at 15 in. Hg.
 (HRS) Time end: 2304 (HRS)
 cc/min Operator: D. Maxo

S/N of O₂ Analyzer used to monitor train outlet:

29B 9

INTERPOLL LABORATORIES RA METHOD & FIELD DATA SHEET

3266

Job 40 / Hwy ward
Supplier - Lane 3 Dryer RTO Outlet
Date 7-18-94

Operator DM + KM
Motor Box No. 10 (H) 5.77 IN HC
Generator coil. ID 930

Pilot No. 445-8 CP 8.90
Buc. Press. 1827 InHg 22.77
Hortls No. 655 Horls Dir 303 H.

Transfer Point No.	Sampling Time (min)	Supply Volume (cu)	Velocity Head (INHG)	Orifice Meter (INHG)	Diff. Vbl. (cu)	VAC. InHg	Temperature (°F)				GAS IN	GAS OUT	Oxygen (xy/v)
							Stack	Probe	Dryn	Tap			
A	8	765.60	.73	2.95	9.67	6	337	229	250	55	87	86	18.0
	7	769.50	.71	2.76	3.68	7	354	231	251	54	92	85	18.2
	6	773.42	.72	2.86	7.56	7	340	232	251	55	93	85	18.4
	5	777.42	.80	3.19	1.77	7	337	233	261	54	94	85	18.4
	4	781.50	.73	2.84	5.74	7	338	231	254	56	95	85	18.2
	3	785.58	.73	2.88	9.74	7	350	229	255	56	96	85	17.9
	3	789.67	.69	2.72	3.63	7	350	231	244	55	97	85	18.3
	1	793.84	.62	2.48	7.36	7	338	230	240	55	97	85	18.1
B	8	797.74	.70	3.08	1.50	7	338	229	237	56	97	85	17.6
	7	801.76	.77	3.08	5.64	7	339	231	240	56	92	87	17.9
	6	805.83	.79	3.15	9.82	7	338	233	243	56	95	84	18.5
	5	809.95	.78	3.05	3.93	7	355	235	246	48	96	84	18.2
	4	814.00	.75	2.96	7.99	7	348	231	246	49	97	84	18.3
	3	818.09	.75	2.96	2.04	7	349	234	260	48	97	85	18.5
	2	822.18	.75	2.96	5.97	7	358	231	266	48	98	85	18.6
	1	826.25	.69	2.72	9.87	7	353	230	253	49	97	85	18.2
		830.13											

v_a = 64.53

v_s = 64.53


0 = 64

AVG = 92.0

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Highway road, etc
 Source Line 2 Dwyer RTD / stack
 Test 6 Run Date 7-13-94
 Stack Dimen. 91.5 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.94 IN.HG
 Static Pressure -1.40 IN.WC
 Operators D. Manno & H. Winterspiller
 Pitot No. 22V-E C₂ 134



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
Port Length: <u>6.25</u> IN.			Time Start: _____ HRS		
A-1	.032	2.61	8.86		
2	.105	3.56	14.81		
3	.194	15.61	23.06		
4	.323	26.32	32.57		
5	.677	55.18	61.43		
6	.806	65.69	71.94		
7	.895	72.94	79.19		
8	.968	78.89	85.14		
B-1					
2					
3					
4					
5					
6					
7					
8					
Temp. Meas. Device & S/N: <u>PDT-31 / TC</u>				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES EPA MODIFIED METHOD 5 SAMPLE LOG SHEET

Job LP/Hayward
 Source Line 2 Dyer RTO Outlet
 Cyclone: Yes No Filter holder: MMS
 Analytes: PM10
 Field recovery spike added: Yes No

Date 7-13-94 Test 8 Run 1
 No. of traverse points 16
 Filter type: 4" Glass fiber
 XAD-2 resin: g Batch No.
 Reference: EPA SW-846 Method 0010

Sample Train Leak Check:

Pretest: < 0.02 cfm at 15 in. Hg. (vac)
 Posttest: ≤0.02 cfm at 10 in. Hg. (vac)

Semivolatile Catch Data:

No.s of filters used: 3002 Recovery solvent(s)
 MeCl2 ~~MeOH (50:50 v/v)~~
 other(s) Acetone

No. of bottles for condensate trap catch: 1
 Samples recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Condensate trap	607	267	347
Condensate trap			
Condensate trap			
Impingers			
Desiccant	1465	1445	20
Total			367

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 28 Bag No. 1
 Bag Material: 4-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 0848 (HRS) Time end: 1058 (HRS)
 Sampling rate: 200 cc/min O2 Analyzer S/N:

INTERPOL LABORATORIES EPA M02 ED METHOD 3 FIELD DATA SHEET

Job LP/ Hayward
 Source Line 2 Over Rte. Over
 Date 2-13-94

Operator OM + K.M.
 Motor Box No. 59936
 Governor Code 10

Notice No. 80-4 P1101 No. 22-8
 Notice Dia. 332 In. Cp 540
 Bar. Prob. 33.54 To. Hg 3.2 %

Traverse Point No.	Sampling Time (min)	Sample Volume (cft)	Velocity Head (1/HMC)	Orifice Meter (1/HMC)	Dis. Vol. (cft)	VAC. 1/Hg	Temperatures (°F)						Oxygen (AV/R)	
							Stack	P/O/S	Overn	XAD2	Imp.	Motor (In./Out)		Wet Bulb
8	68	878.15	.67	.99	7.42	9	337	231	235	49	45	86	74	17.9
8	72	879.99	.65	.96	9.71	8	337	232	237	49	44	88	75	18.2
7	76	882.82	.65	.96	3.00	8	340	235	240	48	46	88	74	17.9
7	80	885.22	.75	1.13	4.48	9	327	229	230	48	45	70	76	17.8
6	84	887.63	.74	1.11	6.95	9	333	243	230	49	46	91	76	17.8
6	88	889.21	.72	1.08	9.38	8	333	243	230	49	46	91	76	17.2
5	92	892.40	.70	1.05	1.78	8	335	245	231	48	45	91	76	17.9
5	96	894.89	.73	1.07	4.20	9	349	249	230	48	45	93	78	17.8
4	100	897.29	.68	1.00	6.59	8	349	250	235	49	46	93	78	18.1
4	104	899.67	.68	1.00	8.90	8	349	250	235	49	46	93	78	17.4
3	108	901.76	.69	1.03	1.28	8	336	251	233	48	45	93	79	18.0
3	112	904.41	.71	1.06	3.71	8	336	251	233	48	45	94	80	18.2
2	116	906.77	.70	1.02	6.09	8	356	255	239	49	47	95	80	17.9
2	120	908.91	.60	.88	8.29	8	356	255	239	49	47	95	81	17.5
1	124	911.28	.60	.91	0.54	8	327	250	243	49	47	95	81	17.2
1	128	913.48	.61	.92	2.80	8	330	252	243	49	47	96	82	17.4
	(1058)	(74.93)												

INTERPOLL LABORATORIES EPA MODIFIED METHOD 5 SAMPLE LOG SHEET

Job LP/Hayward
 Source Line 2 Dryer RTO Outlet
 Cyclone: Yes No Filter holder: MMS
 Analytes: None
 Field recovery spike added: Yes No

Date 7-13-94 Test 8 Run 2
 No. of traverse points 16
 Filter type: 4" Glass fiber
 XAD-2 resin: g Batch No.
 Reference: EPA SW-846 Method 0010

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac)
 Posttest: 50.02 cfm at 10 in. Hg. (vac)

Semivolatile Catch Data:

No.s of filters used: 3003 Recovery solvent(s)
 MeCl₂ * ~~MeOH (50:50 v/v)~~
 other(s) Acetone
 No. of bottles for condensate trap catch: 1
 Samples recovered by: M. Kachler

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Condensate trap	639	267	372
Condensate trap			
Condensate trap			
Impingers			
Desiccant	1340	1317	23
Total			395

Integrated Gas Sampling Data:

Bag Pump No. 29B Box No. 28 Bag No. 2
 Bag Material: 4-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1150 (HRS) Time end: 1402 (HRS)
 Sampling rate: 200 cc/min O₂ Analyzer S/N:

INTERPOL LABORATORIES EPA MOD 10 METHOD 3 FIELD DATA SHEET

Job LP / Hayward Operator D M & K M P1101 No. 82-0
 SOURCE Hayward Meter Box No. 10 CP 840
 DATE 5-13-77 MON 8 Gage Motor Count. 4430 Bar. Pres. 25.94 In. Hg 30 %

Traverse Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (in Hg)	Orifice Meter (in Hg)	Des. Vol. (cc)	VAC. In Hg	Temperatures (°F)				Oxygen (X% / V%)			
							Stack	Probe	Oven	XRAD		Imp. Meter (In/Out)		
	(1150)	913.90												
8	4	916.20	.78	1.09	6.33	5	353	231	242	47	43	86	82	17.9
8	8	918.58	.69	1.05	8.72	6	353	231	242	47	43	90	82	17.5
7	12	921.91	.70	1.07	1.16	6	353	234	241	47	43	91	82	17.6
7	16	923.55	.73	1.12	3.65	6	354	235	230	47	43	93	82	17.6
6	20	926.03	.73	1.12	6.13	6	353	258	235	48	44	94	82	17.6
6	24	928.55	.73	1.12	8.63	6	353	258	235	48	44	95	82	18.0
5	28	931.09	.75	1.18	1.18	7	334	251	241	47	44	95	83	17.6
5	32	933.69	.71	1.12	3.67	7	334	251	241	47	44	96	83	17.7
4	36	936.20	.70	1.10	6.15	7	335	255	243	47	45	97	83	17.5
4	40	938.72	.72	1.14	8.66	7	335	255	243	48	45	97	84	17.7
3	44	941.16	.65	1.02	1.04	7	338	249	251	48	45	97	84	17.9
3	48	943.55	.65	1.02	3.42	7	338	249	251	48	45	97	84	17.4
2	52	945.94	.65	1.02	5.80	7	340	253	248	47	44	98	85	17.3
2	56	948.28	.60	.93	8.04	7	352	253	248	47	44	98	86	17.1
1	60	951.18	.70	1.02	0.54	7	352	261	241	48	44	98	85	17.9
1	64	953.16	.67	1.04	2.95	7	346	261	241	48	44	99	86	17.6

θ = _____ Vn = _____ H = _____ Avg. = _____

INTERPOL LABORATORIES EPA MODIFIED METHOD 3 FIELD DATA SHEET

JOB LP/Hwy Ward Operator DM + KN Nozzle No. 80-4 P1101 No. 22-8
 SOURCE Leach 2 Over RFD on High Meter Box No. 10 Nozzle Dia. 1.37 In. CP 240
 DATE 7-13-84 10:11 AM 2 MIN 2 Gasometer Coeff. .9932 Bar. Pres. 22.94 In. Hg H₂O 30 %

Traverse Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Head (1/4 NC)	Orifice Meter (1/4 NC)	Dep. Vol. (cc)	VAC. in Hg	Stack	Temperature (°F)				Motor (In/Out)	Oxygen (% V/V)	
								Probe	Oven	XRD2	Imp.			
A	8	955.50	.62	.97	5.27	7	346	251	257	49	45	95	86	17.8
	8	957.75	.55	.86	7.46	6	346	251	257	49	45	95	86	17.0
	7	956.05	.69	1.08	9.91	7	338	256	230	49	46	98	86	17.4
	7	962.56	.69	1.09	2.38	7	338	256	230	49	46	98	87	17.9
	6	965.01	.72	1.12	4.87	7	352	256	232	48	46	98	87	16.9
	6	967.47	.70	1.09	7.33	7	352	261	235	48	46	99	87	17.5
	5	960.98	.73	1.15	9.87	7	338	253	235	49	45	99	87	17.7
	5	972.42	.65	1.03	2.26	7	332	253	235	49	45	100	87	17.5
	4	974.85	.65	1.00	4.63	7	357	246	230	50	46	100	87	17.3
	4	977.22	.70	1.08	7.09	7	357	246	230	50	46	100	87	17.8
	3	979.79	.70	1.09	9.55	7	352	256	232	50	47	100	87	17.5
	3	982.25	.68	1.06	1.99	7	346	250	232	50	47	100	88	17.1
	2	984.63	.69	1.08	4.45	7	346	252	237	51	47	100	88	17.5
	2	987.06	.70	1.10	6.93	7	346	240	235	51	48	101	88	17.6
	1	989.45	.64	1.01	9.31	7	338	240	235	51	48	101	88	17.9
	1	991.83	.64	1.01	16.9	7	338	251	230	51	48	101	88	17.5
	(402)													

10 = 120 VA = 77.93 H = 1.06 RVG = 9/1.1

RAY OF 020 S-405

INTERPOLL LABORATORIES EPA MODIFIED METHOD 5 SAMPLE LOG SHEET

Job L.P. Hayward, CA Date 7-13-94 Test 2 Run 3
 Source Line 2 Duce PTA / Stack No. of traverse points 16
 Clone: Yes No Filter holder: MMS Filter type: 4" Glass fiber
 Analytes: PM10 XAD-2 resin: g Batch No.
 Field recovery spike added: Yes No Reference: EPA SW-846 Method 0010

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac) R
 Posttest: 20.02 cfm at 8 in. Hg. (vac) R

Semivolatile Catch Data:

No.s of filters used: 3004 Recovery solvent(s)
 MeCl₂ * ~~MeOH~~ (50:50 v/v)
 other(s) Acetone
 No. of bottles for condensate trap catch: 1
 Samples recovered by: Am. Kachler

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Condensate trap	661	267	394
Condensate trap			
Condensate trap			
Impingers			
Desiccant	1387	1365	22
Total			416

Integrated Gas Sampling Data:

Bag Pump No. 288 Box No. 28 Bag No. 3
 Bag Material: 4-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1505 (HRS) Time end: 1717 (HRS)
 Sampling rate: 200 cc/min O₂ Analyzer S/N:

INTERPOL LABORATORIES EPA NO 1ED METHOD 3 FIELD DATA SHEET

JOB LP / Hwy 24 10/11/8 8 AM 3
 SOURCE Line 2 Open RTG ex file
 DO 10 7-13-74 1011 8 AM 3

Operator D.M. & K.M.
 Notice No. 8D-4
 Notice Date 7-13-74 In. Hg
 Bar. Pres. 29.94 In. Hg


P1101 No. 84-8
 Cp 1840
 H₂O 21 %

Traverse Point No.	Sampling Time (min)	Sample Volume (cc)	Velocity Hood (fpm)	Orifice Meter (fpm)	Det. Vol. (cc)	VAC. In Hg	Temperatures (°F)				Oxygen (X/Y/V)		
							Stack	Probe	Oven	XAD2		Inp.	Water (In/Du1)
B	68	1032.04	.63	.97	2.01	6	348	239	50	46	99	89	17.1
8	72	1034.40	.65	.99	4.36	6	348	238	50	46	99	89	17.3
7	76	1036.85	.72	1.12	6.86	7	337	251	50	45	102	89	17.5
7	80	1039.35	.72	1.12	9.37	7	337	252	51	45	103	90	16.8
6	84	1041.84	.71	1.10	1.86	7	339	259	51	46	103	90	16.9
6	88	1044.34	.70	1.09	4.33	7	339	260	51	46	103	91	17.3
5	92	1046.82	.72	1.10	6.82	7	353	260	49	45	103	91	17.0
5	96	1049.32	.72	1.10	9.31	7	353	260	49	45	104	91	17.1
4	100	1051.82	.72	1.13	1.83	7	334	251	51	47	104	91	17.5
4	104	1054.33	.70	1.10	4.31	7	334	250	52	48	104	92	17.2
3	108	1056.71	.65	.99	6.68	7	354	245	52	48	103	91	17.3
3	112	1059.09	.65	.99	9.04	7	354	248	53	48	103	91	17.5
2	116	1061.45	.64	.98	1.40	7	348	240	53	47	103	92	17.3
2	120	1063.83	.65	1.00	3.77	7	348	242	51	46	103	92	17.2
1	124	1066.13	.60	.92	6.05	7	348	240	52	47	103	92	17.1
1	128	1068.35	.56	.86	8.26	7	349	241	52	47	102	92	17.6
	(717)												

AVG. = 94.0
 V_h = 76.15
 H = 1.01
 θ = 128

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job L.P. / Hayward, CA
 Source Line 2 Dryer RTD / Stack
 Test 9 Run 0 Date 7-13-94
 Stack dimen. 91.5 IN.
 Dry bulb 32.7 °F Wet bulb 15.4 °F
 Manometer: Reg. Exp. Elec.
 Barometric pressure 29.94 in Hg
 Static pressure -1.40 in WC
 Operators Michael R. K. MASSARIEK
 Pitot No. NA Cp NA



Drawing
of Test Site

Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>6.25</u> in.		Time start: <u>NA</u> hrs	
	1/6	13.58	19.53		
	3/6	40.75	47.00		
	5/6	67.92	74.17		
Temp. meas. device & S/N: <u>PDI-31/TC</u>				Time end: <u>NA</u> hrs	

INTERPOLL LABORATORIES

Benzene Field Data Sheet

Job L.P. / Hayward, WI
 Source Line 2 Dryer RTD / Stack
 Date 7-13-94 Test 9 Run 1

Operator(s) M. Kuebler + K. Nussmeier
 Meter Box No. 25 Meter coef. 1.0078
 Barometric Pressure 28.94 in.Hg

Sample Train Leak Check:

Pretest: 0 cc/min at 15 in.Hg
 Posttest: 0 cc/min at 15 in.Hg

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Sample Rate (cc/min)	VAC. (inHg)	Temperature (°F)		
					Stack	Probe	Gasmeter
	0956	475.900					
B-3	5	475.993	1000	4	330	243	94
3	10	476.185	1000	4	330	240	96
3	15	476.370	1000	4	330	242	96
3	20	476.570	1000	4	350	245	88
2	25	476.757	1000	4	350	244	90
2	30	476.948	1000	4	335	249	90
2	35	477.136	1000	4	344	245	92
2	40	477.326	1000	4	348	245	92
C-1	45	477.515	1000	4	336	242	92
1	50	477.703	1000	4	336	247	92
1	55	477.900	1000	4	342	250	92
1	60	478.095	1000	4	340	252	93
	$\theta = 60$	$v_m = 2.145$					$t_m = 89.8$

(0956)

$V_{STD} = 2.149$

INTERPOLL LABORATORIES

Benzene Field Data Sheet

Job 6.P. / Hayward, WI
 Source Lined Dryer RTD / Stack
 Date 2-13-94 Test 9 Run 2

Operator(s) M. Kachala + K. Wessmeyer
 Meter Box No. 25 Meter coef. 1.0078
 Barometric Pressure 28.94 in.Hg

Sample Train Leak Check:
 Pretest: 0 cc/min at 15 in.Hg
 Posttest: 0 cc/min at 15 in.Hg

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Sample Rate (cc/min)	VAC. (inHg)	Temperature (°F)		
					Stack	Probe	Gasmeter
	(1120)	478.310					
C 3	5	478.51	1000	4	333	240	86
3	10	478.79	1000	4	335	238	86
3	15	478.87	1000	4	334	242	86
3	20	479.06	1000	4	339	245	88
2	25	479.251	1000	4	347	247	89
2	30	479.443	1000	4	347	242	89
2	35	479.631	1000	4	345	248	90
2	40	479.820	1000	4	340	250	91
1	45	480.006	1000	4	344	253	92
1	50	480.193	1000	4	349	255	92
1	55	480.380	1000	4	352	251	93
1	60	480.568	1000	4	334	251	93
	$\theta = 60$	$V_m = 2.258$					$t_m = 89.6$

(1220)

$V_{STD} = 2.114$

INTERPOLL LABORATORIES

Benzene Field Data Sheet

Job L.P. / Hayward, CA
 Source Line 2 Dryer RW / 1st flk
 Date 2-13-44 Test 9 Run 3

Operator(s) M. Kuehler + K. Uessmeyer
 Meter Box No. 25 Meter coef. 1.0078
 Barometric Pressure 28.94 in.Hg

Sample Train Leak Check:
 Pretest: 0 cc/min at 15 in.Hg
 Posttest: 0 cc/min at 13 in.Hg

Trav. Point No.	Samp. Time (min)	Sample Volume (cf)	Sample Rate (cc/min)	VAC. (inHg)	Temperature (oF)		
					Stack	Probe	Gasmeter
	<u>1300</u>	<u>480.800</u>					
<u>B-3</u>	<u>5</u>		<u>1000</u>	<u>4</u>	<u>352</u>	<u>247</u>	<u>94</u>
<u>3</u>	<u>10</u>	<u>481.182</u>	<u>1000</u>	<u>4</u>	<u>357</u>	<u>250</u>	<u>94</u>
<u>3</u>	<u>15</u>	<u>481.371</u>	<u>1000</u>	<u>4</u>	<u>338</u>	<u>245</u>	<u>94</u>
<u>3</u>	<u>20</u>	<u>481.560</u>	<u>1000</u>	<u>4</u>	<u>352</u>	<u>249</u>	<u>93</u>
<u>2</u>	<u>25</u>	<u>481.751</u>	<u>1000</u>	<u>4</u>	<u>352</u>	<u>247</u>	<u>93</u>
<u>2</u>	<u>30</u>	<u>481.937</u>	<u>1000</u>	<u>4</u>	<u>338</u>	<u>250</u>	<u>94</u>
<u>2</u>	<u>35</u>	<u>482.130</u>	<u>1000</u>	<u>4</u>	<u>357</u>	<u>252</u>	<u>94</u>
<u>2</u>	<u>40</u>	<u>482.319</u>	<u>1000</u>	<u>4</u>	<u>357</u>	<u>249</u>	<u>95</u>
<u>1</u>	<u>45</u>	<u>482.508</u>	<u>1000</u>	<u>4</u>	<u>352</u>	<u>250</u>	<u>96</u>
<u>1</u>	<u>50</u>	<u>482.497</u>	<u>1000</u>	<u>4</u>	<u>346</u>	<u>245</u>	<u>97</u>
<u>1</u>	<u>55</u>	<u>482.898</u>	<u>1000</u>	<u>4</u>	<u>340</u>	<u>249</u>	<u>98</u>
<u>1</u>	<u>60</u>	<u>483.077</u>	<u>1000</u>	<u>4</u>	<u>342</u>	<u>251</u>	<u>98</u>
	<u>θ=60</u>	<u>Vm=2.277</u>					<u>tm=95.0</u>

(1301)


$V_{STD} = 2.112$



EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Hayward, WI
 Source Line 2 Dryer RTO / Stack
 Test 10 Run 0 Date 7-13-94
 Stack Dimen. 81.5 IN.
 Dry Bulb 345 °F Wet bulb 155 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.94 IN.HG
 Static Pressure -.40 IN.WC
 Operators M. Kaehler + K. Nussmeier
 Pitot No. 29V-B C₂ BY BY



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>6.25</u> IN.	Time Start: <u>NA</u> HRS		
	<u>1/6</u>	<u>13.58</u>	<u>19.83</u>		
	<u>2/6</u>	<u>40.75</u>	<u>47.00</u>		
	<u>5/6</u>	<u>67.92</u>	<u>74.17</u>		
Temp. Meas. Device & S/N: <u>PDT-31/TC</u>				Time End: <u>NA</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayward, WI Date 7-13-94 Test 10 Run 1
 Source Line 2 Dryer RTD / stack No. of traverse points 3
 Method Direct Filter holder: Glass Filter type: 4" G.F.
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 40.0 cfm at 12 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: NA Recovery solvent(s):
 acetone _____
 other(s) _____
 No. of probe wash bottles: 0
 Sample recovered by: Michael + K. Messmer

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. A	417	268	149
Impinger No. B	327	268	59
Impinger No. C			
Condenser			
Desiccant	1317	1304	13
Total			221

Integrated Gas Sampling Data: Hook Bus Sample During Run 1 POM

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ in. Hg.
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPULL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job As P. Hayward, w/
 Supply Line Dyer R/R / Stack
 Date 2-13-94 10

Operator Mr. Koehler
 No. 1170
 Date 2-13-94

Pilot No. 29U-B
 Buf. Press. 28.94
 Hoz. No. 228

IP 04
 H2O NA
 Air NA

Traverse Point No.	Sampling Time (min)	Supply Volume (cfs)	Velocity Head (cm)	Orifice Meter (cm)	Dip. Vbl. (cfs)	V.M.C. (cm)	Temperature (°F)					Oxygen (cfs)	
							Stack	Pipe	Duct	Imp.	Gas/Dpt		
13-3	0956	193.50	NA	1.77	NA	7	330	242	250	44	20	69	17.6
3	5	197.40		1.77		7	330	245	247	44	77	69	17.8
3	10	201.27		1.77		7	330	243	249	44	82	70	18.0
3	15	205.25		1.77		7.5	350	242	247	45	85	70	17.9
3	20	209.02		1.77		7.5	350	245	246	45	86	72	17.7
2	25	212.92		1.77		7.5	335	248	243	45	87	75	17.5
2	30	216.82		1.77		7.5	344	251	245	45	88	74	18.0
2	35	220.74		1.77		7.5	348	250	249	45	89	74	17.8
2	40	224.64		1.77		7.5	336	239	244	46	88	75	18.0
C-1	45	228.53		1.77		7.5	336	244	250	46	89	75	18.1
1	50	232.40		1.77		7.5	341	248	250	46	88	76	17.7
1	55	236.27		1.77		7.5	340	245	247	46	90	76	18.3
1	60	240.15		1.77		7.5							
	(0956)												
		<u>46.65</u>		<u>1.77</u>									
		<u>0 = 60</u>											<u>78.92</u>

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayward, WI Date 2-13-74 Test 10 Run 2
 Source Line 2 Dryer P10 / Stack No. of traverse points 3
 Method Phenol Filter holder: Glass Filter type: 4" G.F.
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.02 cfm at 12 in. Hg. (vac)

Particulate Catch Data:

No. of filters used: NA Recovery solvent(s)
 acetone _____
 other(s) _____

No. of probe wash bottles: 0
 Sample recovered by: Michael + K. Nussmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	398	268	130
Impinger No. 2	362	268	94
Impinger No. 3			
Condenser			
Desiccant	1496	1480	16
Total			240

Integrated Gas Sampling Data: Sample Taken During Run 2, POM

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ in. Hg.
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job LP/Hayward
Sampling Date 11-10-84
Operator Mike Beckler
Site # 1177
Pilot No. 23V-8
Bar. No. 28.97
Moist. No. 222
CP # 1120 224
Moist. Dia 224

Inventory Point No.	Sampling Time (min)	Sample Volume (vol)	Velocity Head (ft/sec)	Distance Meter (ft/sec)	Wind Vel. (ft)	Wind Dir.	Temperature (°F)				GWS/Dir	Dry Bulb (XXV/V)		
							Stack	Probs	Dryn	Insp.			Grain	
C-3	(1120)	(210.89)	NA	1.77	7		333	240	250	45	85	76	17.6	
	5	244.52		1.77	7		335	241	252	45	86	77	17.7	
	10	248.35		1.77	7		334	243	250	45	90	77	17.5	
	15	252.22		1.77	7		339	239	255	45	93	78	16.1	
	20	256.63		1.77	2.5		342	240	250	45	94	28	18.0	
	25	259.09		1.77	2.5		347	245	252	46	94	79	18.0	
	30	263.73		1.77	2.5		345	249	248	46	95	80	17.5	
	35	267.57		1.77	2.5		340	253	245	47	95	80	17.7	
	40	271.42		1.77	2.5		344	250	247	47	95	81	17.2	
	45	275.28		1.77	2.5		349	247	252	47	96	82	17.4	
	50	279.21		1.77	2.5		352	245	257	48	96	82	17.5	
	55	283.14		1.77	2.5		334	250	257	48	96	82	17.9	
	60	287.07		1.77	2.5									
	(220)													
Σ				11.77										
VΣ = 46.13														
V = 60														
VΣ = 26.13														

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Hayward, WI Date 7-13-74 Test 20 Run 3
 Source Line 2 Dyer RD / Stock No. of traverse points 3
 Method Phenol Filter holder: Glass Filter type: 4" G.F.
 Sample Train Leak Check: _____

Pretest: ≤ 0.02 cfm at 15 in. Hg. (vac)
 Post test: 0.06 cfm at 12 in. Hg. (vac)

Particulate Catch Data:

No. of filters used:
NA

Recovery solvent(s)
 acetone _____
 other(s) _____

No. of probe wash bottles:
 Sample recovered by:

0
M. Kachler + R. Nussmeier

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. <u>A</u>	<u>395</u>	<u>270</u>	<u>125</u>
Impinger No. <u>B</u>	<u>357</u>	<u>268</u>	<u>89</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1487</u>	<u>1472</u>	<u>15</u>
Total			<u>229</u>

Integrated Gas Sampling Data: Sample Taken During Run 2 POM

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ in. Hg.
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job L.P. Hayward, WV Operator K. Messinger Pilot No. 29 U. 8 Ep BY
 Sample 2.13.94 Dyer RD / SF Vol % Box No. 2 Nozzle No. 28.94 Inlet H₂O 24
 Date 2-13-94 RPM 3 Coefficient 9.74 Nozzle Dia AA In.

Transfer Point No.	Sampling Time (min)	Sample Volume (cft)	Velocity (ft/min)	Orifice Meter (inches)	Avg. Vel. (ft)	VAC. (inHg)	Temperature (°F)				Cust/Del	Dry Bulb (°F)
							Stack	Probe	Duct	Inlet		
B-3	13:00	207.40	NA	1.77	NA	7	352	243	250	47	82	17.6
3	5	291.32		1.77		2.5	357	240	253	47	84	18.1
3	10	295.24		1.77		2.5	338	245	249	47	87	17.8
3	15	299.01		1.77		7.5	352	248	252	47	80	17.7
3	20	302.91		1.77		7.5	352	250	255	48	91	18.0
2	25	306.76		1.77		7.5	338	252	259	48	93	17.3
2	30	310.60		1.77		7.5	357	248	261	48	94	17.1
2	35	314.40		1.77		7.5	357	250	267	48	95	17.6
2	40	318.30		1.77		2.5	352	253	264	48	96	17.1
1	45	322.22		1.77		2.5	346	250	261	46	96	17.6
1	50	326.13		1.77		2.5	340	253	260	46	97	17.3
1	55	330.04		1.77		2.5	342	250	255	46	97	17.9
1	60	333.96		1.77		2.5						
	(1401)											
		V _s = 46.56		11.77						Avg. = 86.54		

Visible Emissions Form

Just 1

SOURCE NAME <i>LOUISIANA PACIFIC CORP</i>			OBSERVATION DATE <i>7-12-94</i>			START TIME <i>1500</i>			STOP TIME <i>1600</i>				
ADDRESS <i>11</i>			SEC	0	15	30	45	SEC	0	15	30	45	
			MIN					MIN					
			1	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	31	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
			2	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	32	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
CITY <i>HAYWARD</i>	STATE <i>CALIF</i>	ZIP	3	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	33	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
PHONE	SOURCE ID NUMBER		4	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	34	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
PROCESS EQUIPMENT <i>LINE 2 DRILL</i>		OPERATING MODE	5	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	35	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
CONTROL EQUIPMENT <i>RTO</i>		OPERATING MODE	6	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	36	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
DESCRIBE EMISSION POINT START <i>ROUND METAL STACK</i> STOP			7	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	37	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
HEIGHT ABOVE GROUND LEVEL START <i>100'</i> STOP		HEIGHT RELATIVE TO OBSERVER START <i>100'</i> STOP	8	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	38	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
DISTANCE FROM OBSERVER START <i>300'</i> STOP ✓		DIRECTION FROM OBSERVER START <i>NE</i> STOP ✓	9	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	39	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
DESCRIBE EMISSIONS START <i>NONE</i> STOP ✓			10	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	40	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
EMISSION COLOR START <i>NONE</i> STOP ✓		PLUME TYPE: CONTINUOUS <input type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	11	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	41	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
WATER DROPLETS PRESENT: NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>	12	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	42	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>8' ABOVE STACK</i> STOP ✓			13	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	43	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
DESCRIBE BACKGROUND START <i>SKY</i> STOP ✓			14	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	44	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
BACKGROUND COLOR START <i>BLUE</i> STOP ✓		SKY CONDITIONS START <i>50% cloudy</i> STOP ✓	15	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	45	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
WIND SPEED START <i>10</i> STOP <i>5</i>		WIND DIRECTION START <i>NW</i> STOP ✓	16	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	46	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
AMBIENT TEMP. START <i>82</i> STOP <i>83</i>		WET BULB TEMP. <i>65</i>	17	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	47	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
		RH. percent <i>39</i>	18	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	48	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
<p>Source Layout Sketch Draw North Arrow</p> <p>Sun → Wind → Plume and Stack</p> <p>Observers Position</p> <p>140°</p> <p>Location Line</p>			19	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	49	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
			20	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	50	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
			21	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	51	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			22	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	52	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			23	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	53	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			24	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	54	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			25	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	55	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			26	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	56	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			27	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	57	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			28	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	58	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			29	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	59	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
			30	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	60	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
AVERAGE OPACITY FOR HIGHEST PERIOD								NUMBER OF READINGS ABOVE % WERE					
RANGE OF OPACITY READINGS								MINIMUM MAXIMUM					
OBSERVER'S NAME (PRINT) <i>Edward M. Trowbridge</i>													
OBSERVER'S SIGNATURE <i>E. Trowbridge</i>										DATE <i>7-12-94</i>			
ORGANIZATION <i>INTERPOLL LABS</i>													
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE								CERTIFIED BY <i>E. T.</i>		DATE <i>4-7-94</i>			
TITLE			DATE			VERIFIED BY			DATE				

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Edward J. Kowbrdy

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

Thermon Fore
President

Will [Signature]
Vice President

David B. Savage, Jr.
Program Manager

243006
Certificate Number

Minneapolis
Location


April 7, 1994
Date of Issue

APPENDIX E

INTERPOLL LABORATORIES ANALYTICAL DATA

TABLE OF CONTENTS

Orsat	1
Particulate	5
Oxides of Nitrogen	27
Formaldehyde	31
Benzene	32
Phenol	45
PAH's	48
Sample Deposition Sheets	50



EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job L.P. Hayward

Source Line 2 Core Dryer

Team Leader DM
Date Submitted 7-18-94
Test No. 3
Date of Analysis 7-18-94

Test Site Inlet
Date of Test 7-12-94
No. of Runs Completed 3
Technician C. Helgeson

Test/Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
3/1	3366-20	1	0.00	3.40	20.80	3.40	17.40	1.03
		2	0.00	3.40	20.80	3.40	17.40	1.03
		Avg	████████████████████			3.40	17.40	████
3/2	-21	1	0.00	4.50	20.90	4.50	16.40	1.00
		2	0.00	4.50	20.90	4.50	16.40	1.00
		Avg	████████████████████			4.50	16.40	████
3/3	-22	1	0.00	3.80	20.90	3.80	17.10	1.00
		2	0.00	3.80	20.90	3.80	17.10	1.00
		Avg	████████████████████			3.80	17.10	████
		1						
		2						
		Avg	████████████████████					████
		1						
		2						
		Avg	████████████████████					████
		1						
		2						
		Avg	████████████████████					████
		1						
		2						
		Avg	████████████████████					████
		1						
		2						
		Avg	████████████████████					████

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F=Flask (250 cc all glass)
B=Tedlar Bag (5-layer)

EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job L.P. Hayward
 Team Leader BA
 Date Submitted 7-18-94
 Test No. 13
 Date of Analysis 7-18-94

Source Local Surface Dryer
 Test Site RTO Inlet
 Date of Test 7-14-94
 No. of Runs Completed 4
 Technician C. Helgeson

Test/Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
13/1	3366-99 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.30	20.80	4.30	16.50	1.02
		2	0.00	4.30	20.80	4.30	16.50	1.02
		Avg	████████████████████			4.30	16.50	████
13/2	-100 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	1.40	20.90	1.40	19.50	1.00
		2	0.00	1.40	20.90	1.40	19.50	1.00
		Avg	████████████████████			1.40	19.50	████
13/3	-101 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	3.50	20.90	3.50	17.40	1.00
		2	0.00	3.50	20.90	3.50	17.40	1.00
		Avg	████████████████████			3.50	17.40	████
13/4	-102 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	3.80	20.90	3.80	17.10	1.00
		2	0.00	3.80	20.90	3.80	17.10	1.00
		Avg	████████████████████			3.80	17.10	████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

F=Flask (250 cc all glass)
 B=Tedlar Bag (5-layer)

EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job L.P. Hayward Source Line 1 Core Dryer
 am Leader DM Test Site RTO Inlet
 te Submitted 7-18-94 Date of Test 7-14-94
 Test No. 15 No. of Runs Completed 4
 Date of Analysis 7-18-94 Technician C. Helgeson

Test/Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
15/1	3366-28 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.30	20.90	4.30	16.60	1.00
		2	0.00	4.30	20.90	4.30	16.60	1.00
		Avg	████████████████████			4.30	16.60	████
15/2	-29 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.20	20.80	4.20	16.60	1.02
		2	0.00	4.20	20.80	4.20	16.60	1.02
		Avg	████████████████████			4.20	16.60	████
15/3	-30 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.50	20.80	4.50	16.30	1.02
		2	0.00	4.50	20.80	4.50	16.30	1.02
		Avg	████████████████████			4.50	16.30	████
15/4	-31 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	3.70	20.80	3.70	17.10	1.02
		2	0.00	3.70	20.80	3.70	17.10	1.02
		Avg	████████████████████			3.70	17.10	████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	████████████████████					████

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

F=Flask (250 cc all glass)
B=Tedlar Bag (5-layer)

EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job L. P. Hayward Source Line 1 Dryer RTO
 Team Leader MK Test Site Stack
 Date Submitted 7-18-94 Date of Test 7-15-94
 Test No. 20 No. of Runs Completed 3
 Date of Analysis 7-18-94 Technician C. Heber

Test/Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F _o
			Zero Pt.	After CO ₂	After O ₂			
20/1	3366-107 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.10	20.70	4.10	16.60	1.05
		2	0.00	4.10	20.70	4.10	16.60	1.05
		Avg	██			4.10	16.60	████
20/2	-108 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.30	20.60	4.30	16.30	1.07
		2	0.00	4.30	20.60	4.30	16.30	1.07
		Avg	██			4.30	16.30	████
20/3	-109 <input checked="" type="checkbox"/> B <input type="checkbox"/> F	1	0.00	4.10	20.60	4.10	16.50	1.07
		2	0.00	4.10	20.60	4.10	16.50	1.07
		Avg	██			4.10	16.50	████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	██					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	██					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	██					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	██					████
	<input type="checkbox"/> B <input type="checkbox"/> F	1						
		2						
		Avg	██					████

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F_o Within EPA M-3 Guidelines for fuel type.

Where $F_o = \frac{20.9 - O_2}{CO_2}$

F=Flask (250 cc all glass)
B=Tedlar Bag (5-layer)

EPA Method 3 Guidelines	
Fuel Type	F _o Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Impinger Catch/Wisconsin Protocol

Job L.P. Hayward Source Line 2 Dryer RTO
 Team Leader MK Test Site Stack
 Date Submitted 7-18-94 Date of Test 7-16-94
 Test No. 1 No. of Runs Completed 3
 Date of Analysis 7-21-94 Technician C. Helgeson

	Solvent Phase	Aqueous Phase
0	Test <u>1</u> Run <u>0</u> Field Blank Log Number <u>3366-32T</u> Comments _____ Dish No. <u>55</u> Dish Tare Wt. <u>47.7754</u> g Dish+Sample Wt. <u>47.7756</u> g Sample Wt. <u>0.0002</u> g	Dish No. <u>328</u> Dish Tare Wt. <u>41.9670</u> g Dish+Sample Wt. <u>41.9674</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>1</u> Run <u>1</u> Log Number <u>-33T</u> Comments _____ Dish No. <u>54</u> Dish Tare Wt. <u>49.6664</u> g Dish+Sample Wt. <u>49.6754</u> g Sample Wt. <u>0.0090</u> g	Dish No. <u>340</u> Dish Tare Wt. <u>47.9150</u> g Dish+Sample Wt. <u>47.9350</u> g Sample Wt. <u>0.0200</u> g
2	Test <u>1</u> Run <u>2</u> Log Number <u>-34T</u> Comments _____ Dish No. <u>63</u> Dish Tare Wt. <u>50.4220</u> g Dish+Sample Wt. <u>50.4298</u> g Sample Wt. <u>0.0078</u> g	Dish No. <u>401</u> Dish Tare Wt. <u>49.5262</u> g Dish+Sample Wt. <u>49.5338</u> g Sample Wt. <u>0.0076</u> g
3	Test <u>1</u> Run <u>3</u> Log Number <u>-35T</u> Comments _____ Dish No. <u>98</u> Dish Tare Wt. <u>47.2108</u> g Dish+Sample Wt. <u>47.2168</u> g Sample Wt. <u>0.0060</u> g	Dish No. <u>405</u> Dish Tare Wt. <u>48.4897</u> g Dish+Sample Wt. <u>48.4977</u> g Sample Wt. <u>0.0080</u> g
4	Test _____ Run _____ Log Number _____ Comments _____ Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____ Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


Results Solvent Phases:

Field Blk.	Run 1	Run 2	Run 3	Blank Solvent Wt. <u>0.0002</u> g	Run 4	Run 5
	<u>0.0088</u>	<u>0.0076</u>	<u>0.0058</u>			

Results Aqueous Phases:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	<u>0.0196</u>	<u>0.0072</u>	<u>0.0076</u>	<u>E-5</u>	

LSC-03WYR



Interpoll Laboratories
(312) 786-6020

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job L.P. Hayward Source Line 2 Dryer RTO
 Team Leader MK Test Site Stack
 Date Submitted 7-18-94 Date of Test 7-12-94
 Test No. 1 No. of Runs Completed 3
 Date of Analysis 7-21-94 Technician C. Helgeson
 Transport Leakage None _____ ml Solvent Acetone

0	Test <u>1</u> Run <u>0</u> Field Blank Log Number <u>3366-32P</u> Vol. of Solvent <u>100 ml</u> *Solvent Residue <u>4.00 ug/ml</u>	Dish No. <u>12</u> Dish Tare Wt. <u>48.1481</u> g Dish+Sample Wt. <u>48.1485</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>1</u> Run <u>1</u> Vol. of Solvent <u>200 ml</u> Log Number <u>-33P</u> Comments _____	Dish No. <u>13</u> Dish Tare Wt. <u>45.7199</u> g Dish+Sample Wt. <u>45.8215</u> g Sample Wt. <u>0.1016</u> g
2	Test <u>1</u> Run <u>2</u> Vol. of Solvent <u>230 ml</u> Log Number <u>-34P</u> Comments _____	Dish No. <u>17</u> Dish Tare Wt. <u>48.3900</u> g Dish+Sample Wt. <u>48.4116</u> g Sample Wt. <u>0.0216</u> g
3	Test <u>1</u> Run <u>3</u> Vol. of Solvent <u>220 ml</u> Log Number <u>35P</u> Comments _____	Dish No. <u>18</u> Dish Tare Wt. <u>49.9873</u> g Dish+Sample Wt. <u>50.0010</u> g Sample Wt. <u>0.0137</u> g
4	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


*Solvent Residue 4.00 ug/ml = [(Sample Wt. 0.0004 g) (10⁶)] / Vol. of Sol. 100 ml
 EPA-MS Acetone Residue Blank Spec. (7.3 ug/ml)

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.1008	0.0207	0.0128	E-6	
--	--------	--------	--------	-----	--

LSC-01YR



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics


Job L.P. Hayward Source Line 2 Dryer RTD
 Team Leader MK Test Site Stack
 Date Submitted 7-18-94 Date of Test 7-12-94
 Test No. 1 No. of Runs Completed 3
 Date of Analysis 6-20-94 Technician C. Helgeson

0	Test <u>1</u> Run <u>0</u> Field Blank Log Number <u>3366-32F</u> Comments _____	Filter No. <u>6784</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9367</u> g Filter+Sample Wt. <u>0.9367</u> g Sample Wt. <u>0.0000</u> g
1	Test <u>1</u> Run <u>1</u> Log Number <u>33F</u> Comments _____	Filter No. <u>6781</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9519</u> g Filter+Sample Wt. <u>0.9535</u> g Sample Wt. <u>0.0016</u> g
2	Test <u>1</u> Run <u>2</u> Log Number <u>34F</u> Comments _____	Filter No. <u>6782</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9330</u> g Filter+Sample Wt. <u>0.9362</u> g Sample Wt. <u>0.0032</u> g
3	Test <u>1</u> Run <u>3</u> Log Number <u>35F</u> Comments _____	Filter No. <u>6783</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9508</u> g Filter+Sample Wt. <u>0.9553</u> g Sample Wt. <u>0.0045</u> g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.0016	0.0032	0.0045		

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.1308	0.0387	0.0307		



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Impinger Catch/Wisconsin Protocol

Job L.P. Hayward Source Line 2 Surface Drger
 Team Leader BA Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-12-94
 Test No. 2 No. of Runs Completed 3
 Date of Analysis 7-21-94 Technician C. Helgeson

	Solvent Phase	Aqueous Phase
0	Test <u>2</u> Run <u>0</u> Field Blank Log Number <u>3366-36E</u> Comments _____ Dish No. <u>306</u> Dish Tare Wt. <u>42.8328</u> g Dish+Sample Wt. <u>42.8330</u> g Sample Wt. <u>0.0002</u> g	Dish No. <u>23</u> Dish Tare Wt. <u>46.0851</u> g Dish+Sample Wt. <u>46.0855</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>2</u> Run <u>1</u> Log Number <u>-37E</u> Comments _____ Dish No. <u>603</u> Dish Tare Wt. <u>48.3673</u> g Dish+Sample Wt. <u>46.4036</u> g Sample Wt. <u>0.0363</u> g	Dish No. <u>407</u> Dish Tare Wt. <u>47.9932</u> g Dish+Sample Wt. <u>46.1135</u> g Sample Wt. <u>0.1203</u> g
2	Test <u>2</u> Run <u>2</u> Log Number <u>-38E</u> Comments _____ Dish No. <u>611</u> Dish Tare Wt. <u>50.0068</u> g Dish+Sample Wt. <u>50.0315</u> g Sample Wt. <u>0.0247</u> g	Dish No. <u>409</u> Dish Tare Wt. <u>46.1910</u> g Dish+Sample Wt. <u>46.2551</u> g Sample Wt. <u>0.0641</u> g
3	Test <u>2</u> Run <u>3</u> Log Number <u>-39E</u> Comments _____ Dish No. <u>612</u> Dish Tare Wt. <u>49.6231</u> g Dish+Sample Wt. <u>49.6561</u> g Sample Wt. <u>0.0330</u> g	Dish No. <u>415</u> Dish Tare Wt. <u>45.0838</u> g Dish+Sample Wt. <u>45.1532</u> g Sample Wt. <u>0.0694</u> g
4	Test _____ Run _____ Log Number _____ Comments _____ Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____ Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g

Results Solvent Phases:
Field Blk. Run 1 Run 2 Run 3


Blank Solvent Wt. 0.0002 g
Run 4 Run 5

	<u>0.0361</u>	<u>0.0245</u>	<u>0.0328</u>		
--	---------------	---------------	---------------	--	--

Results Aqueous Phase:
Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	<u>0.1194</u>	<u>0.0637</u>	<u>0.0690</u>	<u>E-8</u>	
--	---------------	---------------	---------------	------------	--

LSC-03WYR



Interpoll Laboratories
(612) 795-6000

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job LeP. Hayward Source Line 2 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-12-94
 Test No. 2 No. of Runs Completed 3
 Date of Analysis 7-21-94 Technician C. Helgeson
 Transport Leakage None _____ ml Solvent Acetone


0	Test <u>2</u> Run <u>0</u> Field Blank Log Number <u>3366-36P</u> Vol. of Solvent <u>100</u> ml *Solvent Residue <u>4.00</u> ug/ml	Dish No. <u>41</u> Dish Tare Wt. <u>45.3212</u> g Dish+Sample Wt. <u>45.3216</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>2</u> Run <u>1</u> Vol. of Solvent <u>90</u> ml Log Number <u>-37P</u> Comments _____	Dish No. <u>59</u> Dish Tare Wt. <u>44.7329</u> g Dish+Sample Wt. <u>44.8138</u> g Sample Wt. <u>0.0809</u> g
2	Test <u>2</u> Run <u>2</u> Vol. of Solvent <u>130</u> ml Log Number <u>-38P</u> Comments _____	Dish No. <u>84</u> Dish Tare Wt. <u>49.0998</u> g Dish+Sample Wt. <u>49.1893</u> g Sample Wt. <u>0.0895</u> g
3	Test <u>2</u> Run <u>3</u> Vol. of Solvent <u>120</u> ml Log Number <u>-39P</u> Comments _____	Dish No. <u>325</u> Dish Tare Wt. <u>47.6619</u> g Dish+Sample Wt. <u>47.7725</u> g Sample Wt. <u>0.1106</u> g
4	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g

*Solvent Residue 4.00 ug/ml = [(Sample Wt. 0.0004 g) (10⁶)] / Vol. of Sol. 100 ml
 EPA-M5 Acetone Residue Blank Spec. { 7.3 ug/ml

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0805	0.0890	0.1101	E-9	
--	--------	--------	--------	-----	--



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics


Job L.P. Hayward Source Line 2 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted _____ Date of Test 7-12-94
 Test No. 2 No. of Runs Completed 3
 Date of Analysis 7-20-94 Technician C. Helgeson

0	Test <u>2</u> Run <u>0</u> Field Blank Log Number <u>3366-36F</u> Comments _____	Filter No. <u>5746</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9257</u> g Filter+Sample Wt. <u>0.9257</u> g Sample Wt. <u>0.000</u> g
1	Test <u>2</u> Run <u>1</u> Log Number <u>-37F</u> Comments _____	Filter No. <u>6635</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9313</u> g Filter+Sample Wt. <u>1.1908</u> g Sample Wt. <u>0.2595</u> g
2	Test <u>2</u> Run <u>2</u> Log Number <u>-38F</u> Comments _____	Filter No. <u>6636</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9326</u> g Filter+Sample Wt. <u>1.1644</u> g Sample Wt. <u>0.2318</u> g
3	Test <u>2</u> Run <u>3</u> Log Number <u>-39F</u> Comments <u>One of Two filters</u>	Filter No. <u>6637</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9411</u> g Filter+Sample Wt. <u>1.0675</u> g Sample Wt. <u>0.1264</u> g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.2595	0.2318	0.1264		
--	--------	--------	--------	--	--



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job L.P. Hayward Source Line 2 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-12-94
 Test No. 2 No. of Runs Completed 3
 Date of Analysis 7-20-94 Technician C. Helgeson

0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____g Filter+Sample Wt. _____g Sample Wt. _____g
1	Test <u>Run</u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____g Filter+Sample Wt. _____g Sample Wt. _____g
2	Test <u>Run</u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____g Filter+Sample Wt. _____g Sample Wt. _____g
3	Test <u>2</u> Run <u>3</u> Log Number <u>3366-39F</u> Comments <u>Zrf 2</u>	Filter No. <u>5157</u> Filter Type <u>4" 6F</u> Filter Tare Wt. <u>0.6955</u> g Filter+Sample Wt. <u>1.0454</u> g Sample Wt. <u>0.1504</u> g
4	Test <u>Run</u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____g Filter+Sample Wt. _____g Sample Wt. _____g
5	Test <u>Run</u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____g Filter+Sample Wt. _____g Sample Wt. _____g


Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

			0.1504		
--	--	--	--------	--	--

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.4960	0.4090	0.4887		
--	--------	--------	--------	--	--



Interpoll Laboratories
(312) 786-6000

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash


Job LP/Hayward Source Line1 Core Dryer
 Team Leader Dm Test Site Inlet
 Date Submitted 7-18-94 Date of Test 7-12-94
 Test No. 3 No. of Runs Completed 3
 Date of Analysis 7-22-94 Technician B. Jule
 Transport Leakage None _____ ml Solvent Acetone

0	Test <u>3</u> Run <u>0</u> Field Blank Log Number <u>3366-16P</u> Vol. of Solvent <u>100</u> ml *Solvent Residue <u>4.00</u> ug/ml	Dish No. <u>62A</u> Dish Tare Wt. <u>50.8890</u> g Dish+Sample Wt. <u>50.8894</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>3</u> Run <u>1</u> Vol. of Solvent <u>120</u> ml Log Number <u>-17P</u> Comments _____	Dish No. <u>35</u> Dish Tare Wt. <u>51.0917</u> g Dish+Sample Wt. <u>51.2015</u> g Sample Wt. <u>0.1098</u> g
2	Test <u>3</u> Run <u>2</u> Vol. of Solvent <u>130</u> ml Log Number <u>-18P</u> Comments _____	Dish No. <u>48</u> Dish Tare Wt. <u>47.8851</u> g Dish+Sample Wt. <u>47.9853</u> g Sample Wt. <u>0.0972</u> g
3	Test <u>3</u> Run <u>3</u> Vol. of Solvent <u>150</u> ml Log Number <u>-19P</u> Comments _____	Dish No. <u>313</u> Dish Tare Wt. <u>46.4584</u> g Dish+Sample Wt. <u>46.5395</u> g Sample Wt. <u>0.0811</u> g
4	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g

*Solvent Residue 4.00 ug/ml = [(Sample Wt. 0.0004g) (10⁶) / Vol. of Sol. 100 ml]
 EPA-MS Acetone Residue Blank Spec. (7.3 ug/ml)

Results:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.1093	0.0967	0.0805	E-13	



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics


Job L. P. Hayward Source Line 2 Coke Dryer
 Team Leader CT Test Site Inlet
 Date Submitted _____ Date of Test 7-12-94
 Test No. 3 No. of Runs Completed 3
 Date of Analysis 7-20-94 Technician C. Helgeson

0	Test <u>3</u> Run <u>0</u> Field Blank Log Number <u>3366-16 F</u> Comments _____	Filter No. <u>6748</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9385</u> g Filter+Sample Wt. <u>0.9386</u> g Sample Wt. <u>0.0001</u> g
1	Test <u>3</u> Run <u>1</u> Log Number <u>-17 F</u> Comments _____	Filter No. <u>6720</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.4340</u> g Filter+Sample Wt. <u>1.2336</u> g Sample Wt. <u>0.2996</u> g
2	Test <u>3</u> Run <u>2</u> Log Number <u>-18 F</u> Comments _____	Filter No. <u>6744</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9581</u> g Filter+Sample Wt. <u>1.2283</u> g Sample Wt. <u>0.2702</u> g
3	Test <u>3</u> Run <u>3</u> Log Number <u>-19 F</u> Comments _____	Filter No. <u>6743</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>0.9401</u> g Filter+Sample Wt. <u>1.1972</u> g Sample Wt. <u>0.2571</u> g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.2996	0.2702	0.2571		

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.6743	0.5672	0.5580		



EPA Method 5 Data Reporting Sheet
Impinger Catch/Wisconsin Protocol

Job L.P. Hayward Source Line 1 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 13 No. of Runs Completed 4
 Date of Analysis 7-21-94 Technician C. Helgeson

	Solvent Phase	Aqueous Phase
0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>13 Run 1</u> Log Number <u>3366-95I</u> Comments _____	Dish No. <u>53</u> Dish Tare Wt. <u>47.4060</u> g Dish+Sample Wt. <u>47.4530</u> g Sample Wt. <u>0.0470</u> g
2	Test <u>13 Run 2</u> Log Number <u>-96I</u> Comments _____	Dish No. <u>56</u> Dish Tare Wt. <u>47.7558</u> g Dish+Sample Wt. <u>47.7723</u> g Sample Wt. <u>0.0165</u> g
3	Test <u>13 Run 3</u> Log Number <u>-97I</u> Comments _____	Dish No. <u>80</u> Dish Tare Wt. <u>49.6258</u> g Dish+Sample Wt. <u>49.6686</u> g Sample Wt. <u>0.0428</u> g
4	Test <u>13 Run 4</u> Log Number <u>-98I</u> Comments _____	Dish No. <u>81</u> Dish Tare Wt. <u>48.8534</u> g Dish+Sample Wt. <u>48.8874</u> g Sample Wt. <u>0.0340</u> g
5	Test <u>Run</u> Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


Results Solvent Phases:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5	Blank Solvent Wt. <u>0.0002</u> g
	<u>0.0468</u>	<u>0.0163</u>	<u>0.0426</u>	<u>0.0338</u>		

Results Aqueous Phases:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	<u>0.1373</u>	<u>0.0387</u>	<u>0.1408</u>	<u>0.0991</u>	<u>E-15</u>

LSC-03WYP



EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job L.P. Hayward Source Line 1 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 13 No. of Runs Completed 4
 Date of Analysis 7-21-94 Technician C. Helgeson
 Transport Leakage None _____ ml Solvent Acetone


0	Test <u>13</u> Run <u>0</u> Field Blank Log Number <u>3366-94P</u> Vol. of Solvent <u>100</u> ml *Solvent Residue <u>4.00</u> ug/ml	Dish No. <u>35</u> Dish Tare Wt. <u>51.0915</u> g Dish+Sample Wt. <u>51.0919</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>13</u> Run <u>1</u> Vol. of Solvent <u>80</u> ml Log Number <u>-95P</u> Comments _____	Dish No. <u>38</u> Dish Tare Wt. <u>48.6498</u> g Dish+Sample Wt. <u>48.7308</u> g Sample Wt. <u>0.0810</u> g
2	Test <u>13</u> Run <u>2</u> Vol. of Solvent <u>70</u> ml Log Number <u>-96P</u> Comments _____	Dish No. <u>40</u> Dish Tare Wt. <u>47.6424</u> g Dish+Sample Wt. <u>47.7142</u> g Sample Wt. <u>0.0718</u> g
3	Test <u>13</u> Run <u>3</u> Vol. of Solvent <u>80</u> ml Log Number <u>-97P</u> Comments _____	Dish No. <u>43</u> Dish Tare Wt. <u>47.3906</u> g Dish+Sample Wt. <u>47.4211</u> g Sample Wt. <u>0.0305</u> g
4	Test <u>13</u> Run <u>4</u> Vol. of Solvent <u>90</u> ml Log Number <u>-98P</u> Comments _____	Dish No. <u>45</u> Dish Tare Wt. <u>48.1514</u> g Dish+Sample Wt. <u>48.2054</u> g Sample Wt. <u>0.0540</u> g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g

*Solvent Residue 4.00 ug/ml = [(Sample Wt. 0.0004 g) (100)] / Vol. of Sol. 100 ml
 EPA-M5 Acetone Residue Blank Spec. { 7.3 ug/ml

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	<u>0.0807</u>	<u>0.0715</u>	<u>0.0302</u>	<u>0.0536</u>	<u>E-16</u>
--	---------------	---------------	---------------	---------------	-------------



Interpoll Laboratories
(612) 786-6020


EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job <u>L.P. Hayward</u>	Source <u>Line 1 Surface Dryer</u>
Team Leader <u>BA</u>	Test Site <u>RTO Inlet</u>
Date Submitted _____	Date of Test <u>7-14-94</u>
Test No. <u>13</u>	No. of Runs Completed <u>1</u>
Date of Analysis <u>7-21-94</u>	Technician <u>C. Helgeson</u>

0	Test <u>13</u> Run <u>0</u> Field Blank Log Number <u>3366-94F</u> Comments _____	Filter No. <u>41</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>40.5604</u> g Filter+Sample Wt. <u>40.5606</u> g Sample Wt. <u>0.0002</u> g
1	Test <u>13</u> Run <u>1</u> Log Number <u>95F</u> Comments <u>1 of 4</u>	Filter No. <u>29</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>40.9841</u> g Filter+Sample Wt. <u>41.0187</u> g Sample Wt. <u>0.0346</u> g
2	Test <u>13</u> Run <u>2</u> Log Number <u>96F</u> Comments _____	Filter No. <u>5743</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9261</u> g Filter+Sample Wt. <u>1.0862</u> g Sample Wt. <u>0.1601</u> g
3	Test <u>13</u> Run <u>3</u> Log Number <u>97F</u> Comments _____	Filter No. <u>5744</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9243</u> g Filter+Sample Wt. <u>1.2167</u> g Sample Wt. <u>0.2924</u> g
4	Test <u>13</u> Run <u>4</u> Log Number <u>98F</u> Comments _____	Filter No. <u>5745</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9201</u> g Filter+Sample Wt. <u>1.2786</u> g Sample Wt. <u>0.3585</u> g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.0346	0.1601	0.2924	0.3585	E-17



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics


Job L.P. Hayward Source Line 1 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted _____ Date of Test 7-14-94
 Test No. 13 No. of Runs Completed 1
 Date of Analysis 7-21-94 Technician C. Helgeson

0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>13</u> Run <u>1</u> Log Number <u>3366-95 F</u> Comments <u>2 of 4</u>	Filter No. <u>26</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>41.1517</u> g Filter+Sample Wt. <u>41.3405</u> g Sample Wt. <u>0.1888</u> g
2	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
3	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	<u>0.1888</u>	<u>E-18</u>			
--	---------------	-------------	--	--	--



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics


Job L.P. Hayward Source Line 1 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted _____ Date of Test 7-14-94
 Test No. 13 No. of Runs Completed 1
 Date of Analysis 7-21-94 Technician C. Helgeson

0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>13</u> Run <u>1</u> Log Number <u>3366-95F</u> Comments <u>3 of 4</u>	Filter No. <u>14</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>38.0068</u> g Filter+Sample Wt. <u>38.1252</u> g Sample Wt. <u>0.1184</u> g
2	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
3	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.1184		E-19		
--	--------	--	------	--	--



EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job L.P. Hayward Source Line 1 Surface Dryer
 Team Leader BA Test Site RTO Inlet
 Date Submitted _____ Date of Test 7-14-94
 Test No. 13 No. of Runs Completed 1
 Date of Analysis 7-21-94 Technician C. Helgeson

0	Test <u> </u> Run <u>0</u> Field Blank Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>13</u> Run <u>1</u> Log Number <u>3366-95 F</u> Comments <u>4.84</u>	Filter No. <u>17</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>40.4499</u> g Filter+Sample Wt. <u>40.5519</u> g Sample Wt. <u>0.1020</u> g
2	Test <u> </u> Run <u> </u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
3	Test <u> </u> Run <u> </u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
4	Test <u> </u> Run <u> </u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test <u> </u> Run <u> </u> Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g


Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.1020				
--	--------	--	--	--	--

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.7086	0.2866	0.5060	0.5450	
--	--------	--------	--------	--------	--



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Impinger Catch/Wisconsin Protocol

Job L.P. Hayward Source Line 1 Dryer RTO
 Team Leader MK Test Site Speck
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 14 No. of Runs Completed 4
 Date of Analysis 7-21-94 Technician C. Helgeson

	Solvent Phase	Aqueous Phase
0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>14 Run 1</u> Log Number <u>3366-110I</u> Comments _____	Dish No. <u>19</u> Dish Tare Wt. <u>48.9568</u> g Dish+Sample Wt. <u>48.9668</u> g Sample Wt. <u>0.0100</u> g
2	Test <u>14 Run 2</u> Log Number <u>-111E</u> Comments _____	Dish No. <u>25</u> Dish Tare Wt. <u>44.3438</u> g Dish+Sample Wt. <u>44.3513</u> g Sample Wt. <u>0.0075</u> g
3	Test <u>14 Run 3</u> Log Number <u>-112S</u> Comments _____	Dish No. <u>32</u> Dish Tare Wt. <u>57.8075</u> g Dish+Sample Wt. <u>57.8145</u> g Sample Wt. <u>0.0070</u> g
4	Test <u>14 Run 4</u> Log Number <u>-113T</u> Comments _____	Dish No. <u>33</u> Dish Tare Wt. <u>47.9438</u> g Dish+Sample Wt. <u>47.9464</u> g Sample Wt. <u>0.0026</u> g
5	Test <u>Run</u> Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


Results Solvent Phase: Blank Solvent Wt. 0.0002 g

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	<u>0.0098</u>	<u>0.0073</u>	<u>0.0068</u>	<u>0.0024</u>	

Results Aqueous Phase:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	<u>0.0586</u>	<u>0.0136</u>	<u>0.0255</u>	<u>0.0020</u>	<u>E-21</u>

LSC-03WYF



Interpoll Laboratories
(312) 786-6000

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job LP/Hayward Source Line 1 Dryer RTO
 Team Leader MK Test Site Stack
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 14 No. of Runs Completed 4
 Date of Analysis 7-22-94 Technician B. Dale
 Transport Leakage None _____ ml Solvent Acetone

0	Test _____ Run @ _____ Field Blank Log Number _____ Vol. of Solvent _____ ml *Solvent Residue <u>4.00</u> ug/ml	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>14</u> Run <u>1</u> Vol. of Solvent <u>190</u> ml Log Number <u>3366-110P</u> Comments _____	Dish No. <u>52</u> Dish Tare Wt. <u>50.8897</u> g Dish+Sample Wt. <u>50.9257</u> g Sample Wt. <u>0.0360</u> g
2	Test <u>14</u> Run <u>2</u> Vol. of Solvent <u>190</u> ml Log Number <u>-111P</u> Comments _____	Dish No. <u>93</u> Dish Tare Wt. <u>53.9847</u> g Dish+Sample Wt. <u>54.0155</u> g Sample Wt. <u>0.0308</u> g
3	Test <u>14</u> Run <u>3</u> Vol. of Solvent <u>200</u> ml Log Number <u>-112P</u> Comments _____	Dish No. <u>115</u> Dish Tare Wt. <u>45.0678</u> g Dish+Sample Wt. <u>45.0856</u> g Sample Wt. <u>0.0178</u> g
4	Test <u>14</u> Run <u>4</u> Vol. of Solvent <u>190</u> ml Log Number <u>-113P</u> Comments _____	Dish No. <u>311</u> Dish Tare Wt. <u>43.8112</u> g Dish+Sample Wt. <u>43.8256</u> g Sample Wt. <u>0.0144</u> g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


*Solvent Residue _____ ug/ml = [(Sample Wt. _____ g) (10⁶) / Vol. of Sol. _____ ml]
 EPA-MS Acetone Residue Blank Spec. { 7.3 ug/ml

Results:

Field Bk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0352	0.0300	0.0170	0.0136	E-22
--	--------	--------	--------	--------	------

LSC-01YR



EPA Method 5 Data Reporting Sheet
Filter Gravimetrics


Job L.P. Hayward Source Line1 dryer RTO
 Team Leader MC Test Site Stack
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 14 No. of Runs Completed 4
 Date of Analysis 7-25-94 Technician C. GIERKE

0	Test <u> </u> Run <u>0</u> Field Blank Log Number <u> </u> Comments <u> </u>	Filter No. <u> </u> Filter Type <u> </u> Filter Tare Wt. <u> </u> g Filter+Sample Wt. <u> </u> g Sample Wt. <u> </u> g
1	Test <u>14</u> Run <u>1</u> Log Number <u>3366 -110F</u> Comments <u> </u>	Filter No. <u>6745</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9442</u> g Filter+Sample Wt. <u>.9521</u> g Sample Wt. <u>0.0079</u> g
2	Test <u>14</u> Run <u>2</u> Log Number <u>-111F</u> Comments <u> </u>	Filter No. <u>6746</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9267</u> g Filter+Sample Wt. <u>.9320</u> g Sample Wt. <u>0.0053</u> g
3	Test <u>14</u> Run <u>3</u> Log Number <u>-112F</u> Comments <u> </u>	Filter No. <u>6747</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9376</u> g Filter+Sample Wt. <u>.9472</u> g Sample Wt. <u>0.0096</u> g
4	Test <u>14</u> Run <u>4</u> Log Number <u>-113F</u> Comments <u> </u>	Filter No. <u>6749</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.9247</u> g Filter+Sample Wt. <u>.9319</u> g Sample Wt. <u>0.0072</u> g
5	Test <u> </u> Run <u> </u> Log Number <u> </u> Comments <u> </u>	Filter No. <u> </u> Filter Type <u> </u> Filter Tare Wt. <u> </u> g Filter+Sample Wt. <u> </u> g Sample Wt. <u> </u> g

Results:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.0079	0.0053	0.0096	0.0072	

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.1115	0.0562	0.0589	0.0252	



EPA Method 5 Data Reporting Sheet
Impinger Catch/Wisconsin Protocol

Job L. P. Hayward Source Line 1 Core Dryer
 Team Leader DM Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 15 No. of Runs Completed 4
 Date of Analysis 7-21-94 Technician C. Helgeson


	Solvent Phase	Aqueous Phase
0	Test <u>15</u> Run <u>0</u> Field Blank Log Number <u>3366-23T</u> Comments _____ Dish No. <u>48</u> Dish Tare Wt. <u>47.8879</u> g Dish+Sample Wt. <u>47.8881</u> g Sample Wt. <u>0.0002</u> g	Dish No. <u>119</u> Dish Tare Wt. <u>47.7649</u> g Dish+Sample Wt. <u>47.7653</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>15</u> Run <u>1</u> Log Number <u>-24T</u> Comments _____ Dish No. <u>50</u> Dish Tare Wt. <u>45.4662</u> g Dish+Sample Wt. <u>45.5273</u> g Sample Wt. <u>0.0611</u> g	Dish No. <u>1</u> Dish Tare Wt. <u>51.9704</u> g Dish+Sample Wt. <u>52.1654</u> g Sample Wt. <u>0.1950</u> g
2	Test <u>15</u> Run <u>2</u> Log Number <u>-25T</u> Comments _____ Dish No. <u>52</u> Dish Tare Wt. <u>49.8082</u> g Dish+Sample Wt. <u>49.8724</u> g Sample Wt. <u>0.0642</u> g	Dish No. <u>20</u> Dish Tare Wt. <u>48.8144</u> g Dish+Sample Wt. <u>49.0298</u> g Sample Wt. <u>0.2154</u> g
3	Test <u>15</u> Run <u>3</u> Log Number <u>-26T</u> Comments _____ Dish No. <u>200</u> Dish Tare Wt. <u>44.9374</u> g Dish+Sample Wt. <u>45.0118</u> g Sample Wt. <u>0.0744</u> g	Dish No. <u>21</u> Dish Tare Wt. <u>47.5283</u> g Dish+Sample Wt. <u>47.8163</u> g Sample Wt. <u>0.2880</u> g
4	Test <u>15</u> Run <u>4</u> Log Number <u>-27T</u> Comments _____ Dish No. <u>203</u> Dish Tare Wt. <u>46.8704</u> g Dish+Sample Wt. <u>46.9034</u> g Sample Wt. <u>0.0330</u> g	Dish No. <u>29</u> Dish Tare Wt. <u>48.8867</u> g Dish+Sample Wt. <u>49.0067</u> g Sample Wt. <u>0.1200</u> g
5	Test _____ Run _____ Log Number _____ Comments _____ Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g

Results Solvent Phase: Blank Solvent Wt. _____ g

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.0609	0.0640	0.0742	0.0328	

Results Aqueous Phases:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.1946	0.2150	0.2876	0.1196	E-24



Interpoll Laboratories
(612) 786-8020

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job LP/Hayward Source Line 1 Core Dryer
 Team Leader DM Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 15 No. of Runs Completed 4
 Date of Analysis 7-22-94 Technician B. Dube
 Transport Leakage None _____ ml Solvent Acetone

0	Test <u>15</u> Run <u>0</u> Field Blank Log Number <u>3366-23P</u> Vol. of Solvent <u>100</u> ml *Solvent Residue <u>4.00</u> ug/ml	Dish No. <u>62</u> Dish Tare Wt. <u>43.1560</u> g Dish+Sample Wt. <u>43.1564</u> g Sample Wt. <u>0.0004</u> g
1	Test <u>15</u> Run <u>1</u> Vol. of Solvent <u>60</u> ml Log Number <u>-24P</u> Comments _____	Dish No. <u>36</u> Dish Tare Wt. <u>43.5651</u> g Dish+Sample Wt. <u>43.6358</u> g Sample Wt. <u>0.0707</u> g
2	Test <u>15</u> Run <u>2</u> Vol. of Solvent <u>80</u> ml Log Number <u>-25P</u> Comments _____	Dish No. <u>39</u> Dish Tare Wt. <u>49.4379</u> g Dish+Sample Wt. <u>49.5310</u> g Sample Wt. <u>0.0931</u> g
3	Test <u>15</u> Run <u>3</u> Vol. of Solvent <u>100</u> ml Log Number <u>-26P</u> Comments _____	Dish No. <u>44</u> Dish Tare Wt. <u>47.6197</u> g Dish+Sample Wt. <u>47.7548</u> g Sample Wt. <u>0.1351</u> g
4	Test <u>15</u> Run <u>4</u> Vol. of Solvent <u>80</u> ml Log Number <u>-27P</u> Comments _____	Dish No. <u>47</u> Dish Tare Wt. <u>48.4667</u> g Dish+Sample Wt. <u>48.5176</u> g Sample Wt. <u>0.0509</u> g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


*Solvent Residue 4.00 ug/ml = [(Sample Wt. 0.0004 g) (10⁶) / Vol. of Sol. 100 ml]
 EPA-M5 Acetone Residue Blank Spec. { 7.3 ug/ml

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	<u>0.0705</u>	<u>0.0928</u>	<u>0.1347</u>	<u>0.0506</u>	<u>E-25</u>
--	---------------	---------------	---------------	---------------	-------------

LSC-014R



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job LP Hayward Source Line 1 Core Dryer
 Team Leader DM Test Site RTO Inlet
 Date Submitted 7-18-94 Date of Test 7-14-94
 Test No. 15 No. of Runs Completed 4
 Date of Analysis 7-22-94 Technician B. DRAKE

0	Test <u> </u> Run <u>0</u> Field Blank Log Number <u> </u> Comments <u> </u>	Filter No. <u> </u> Filter Type <u> </u> Filter Tare Wt. <u> </u> g Filter+Sample Wt. <u> </u> g Sample Wt. <u> </u> g
1	Test <u>15</u> Run <u>1</u> Log Number <u>3366-24F</u> Comments <u> </u>	Filter No. <u>37</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>41.9341</u> g Filter+Sample Wt. <u>42.3353</u> g Sample Wt. <u>0.4012</u> g
2	Test <u>15</u> Run <u>2</u> Log Number <u>-25F</u> Comments <u> </u>	Filter No. <u>35</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>42.0361</u> g Filter+Sample Wt. <u>42.4896</u> g Sample Wt. <u>0.4535</u> g
3	Test <u>15</u> Run <u>3</u> Log Number <u>-26F</u> Comments <u> </u>	Filter No. <u>38</u> Filter Type <u>SS Thimble</u> Filter Tare Wt. <u>43.3965</u> g Filter+Sample Wt. <u>43.8936</u> g Sample Wt. <u>0.4971</u> g
4	Test <u>15</u> Run <u>4</u> Log Number <u>-27F</u> Comments <u> </u>	Filter No. <u>33</u> Filter Type <u>35 Thimble</u> Filter Tare Wt. <u>40.8107</u> g Filter+Sample Wt. <u>41.1586</u> g Sample Wt. <u>0.3479</u> g
5	Test <u> </u> Run <u> </u> Log Number <u> </u> Comments <u> </u>	Filter No. <u> </u> Filter Type <u> </u> Filter Tare Wt. <u> </u> g Filter+Sample Wt. <u> </u> g Sample Wt. <u> </u> g

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.4012	0.4535	0.4971	0.3479	
--	--------	--------	--------	--------	--

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.7272	0.8253	0.9436	0.5509	
--	--------	--------	--------	--------	--

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (I)

*****SOURCE*****
Job LP / Hayward
*****RECOVERY*****
Date of Recovery 7-21-94
*****ANALYTICAL*****
Date of Analysis 7-26-94
Source Line 2 Sur-facer-Dryer-RTO Inlet Recovered by C. GIERKE
Analyst KGG
Date of Sampling 7-12-94
Recovery volume 500 ml
Eluent AS4A
Test No(s) 2
Barometric at time 28.955 IN.HG. Chromatograph: Dionex System 4000i

Samples collected in accordance with EPA Method 7, CFR Title 40, Part 60, Appendix A. Samples analyzed in accordance with EPA Method 7A by ion chromatography. Mercury manometers used to measure flask pressures/vacuums in sampling and in recovery. Thommen Model TX 19 jewel barometer calibrated against laboratory mercury in glass barometer used to measure field barometric pressure. Three field blanks are prepared and the average used to correct measured nitrate concentrations. All samples are analyzed as a batch using a Dionex Model 4270 Chromatograph Data Integrator. The integrator is programmed to give the actual concentration of the 500 ml recovered sample even if a subsequent dilution was made. The dilution is indicated here as well as on the chromatogram.

$$C_{RS} = DF(C_{DS}) \quad M_{NO_3} = (C_{RS} - \bar{C}_B)V_R \quad \bar{C}_B = (C_{B1} + C_{B2} + C_{B3})/3$$

where: C_{RS} = concentration of nitrate in 500 ml recovered sample in ug/ml

DF = dilution factor

C_{DS} = concentration of nitrate of a 500 ml recovered sample which has been diluted by a factor of DF to bring it into the proper range for the ion chromatograph. This value is an intermediate number and is not outputted by the electronic integrator which is programmed to output the concentration of the original undiluted 500 ml recovered sample.

MNO_3 = total mass of nitrate in micrograms in the 500 ml recovered sample and/or in the 2L flask.

C_B = average conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

C_{B1}, C_{B2}, C_{B3} = conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

V_R = recovery volume for samples and field blanks in ml

Interpoll Laboratories
(612) 786-6020

EPA Method 7A Recovery and Analysis Data Sheet (2)

Sample Log ID No.	Flask No.	Test/Run	Final Flask Conditions			Chrom Run No.	DF	Nitrate Concentration (ug/ml)		Total nitrate in Sample (ug) (MNO ₃)
			t _f (DF)	+	-			Δ Pg (IN.HG.)	Uncorr. for blank CRS	
1 3366-43	1	2/1/1	75°	-	-	3.0	1	0.1414	0.1414	71
2 -44	2	2/1/2		-	-	1.6	1	0.11667	0.11667	83
3 -45	3	2/1/3		-	-	0.4	1	0.1454	0.1454	73
4 -46	4	2/1/4		-	-	3.0	1	0.1245	0.1245	102
5 -47	5	2/2/1		-	-	0.2	1	0.2698	0.2698	130
6 -48	6	2/2/2		-	-	0.3	1	0.2881	0.2881	150
7 -49	7	2/2/3		-	-	4.6	1	0.1590	0.1590	80
8 -50	9	2/2/4		-	-	0.8	1	0.19105	0.19105	88
9 -51	10	2/3/1		-	-	3.5	1	0.2057	0.2057	100
10 -52	11	2/3/2		-	-	1.6	1	0.1204	0.1204	100
11 -53	12	2/3/3		-	-	0.1	1	0.1201	0.1201	100
12 -54	28	2/3/4	✓	-	-	3.9	1	0.1011	0.1011	51
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
Blank 1							1	CB1		CB =
Blank 2							1	CB2		
Blank 3							1	CB3		

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (1)

*****SOURCE*****
Job LP / Hayward
*****RECOVERY*****
Date of Recovery 7-21-94
*****ANALYTICAL*****
Date of Analysis 7-26-94
Source Line 1 Surfer Dryer RTD Inlet Recovered by C. Gierck Analyst KSG
Recovery volume 500 ml Eluent AS4FA
Date of Sampling 7-14-94 Barometric at time 28.955 IN.HG. Chromatograph: Dionex System 4000i
Test No(s) 13

Samples collected in accordance with EPA Method 7, CFR Title 40, Part 60, Appendix A. Samples analyzed in accordance with EPA Method 7A by ion chromatography. Mercury manometers used to measure flask pressures/vacuums in sampling and in recovery. Thommen Model IX 19 jewel barometer calibrated against laboratory mercury in glass barometer used to measure field barometric pressure. Three field blanks are prepared and the average used to correct measured nitrate concentrations. All samples are analyzed as a batch using a Dionex Model 4270 Chromatograph Data Integrator. The integrator is programmed to give the actual concentration of the 500 ml recovered sample even if a subsequent dilution was made. The dilution is indicated here as well as on the chromatogram.

F-20

$$C_{RS} = DF(C_{DS}) \quad M_{NO_3} = (C_{RS} - \bar{C}_B)V_R \quad \bar{C}_B = (C_{B1} + C_{B2} + C_{B3})/3$$

where: C_{RS} = concentration of nitrate in 500 ml recovered sample in ug/ml

DF = dilution factor

C_{DS} = concentration of nitrate of a 500 ml recovered sample which has been diluted by a factor of DF to bring it into the proper range for the ion chromatograph. This value is an intermediate number and is not outputted by the electronic integrator which is programmed to output the concentration of the original undiluted 500 ml recovered sample.

M_{NO_3} = total mass of nitrate in micrograms in the 500 ml recovered sample and/or in the 2L flask.

C_B = average conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

C_{B1}, C_{B2}, C_{B3} = conc. of nitrate in 500 ml recovered samples from the three field blanks (ug/ml)

V_R = recovery volume for samples and field blanks in ml

Interpoll Laboratories
(612)786-6020

EPA Method 7A Recovery and Analysis Data Sheet (2)

Sample Log ID No.	Flask No.	Test/Run	Final Flask Conditions		Chrom Run No.	DF	Nitrate Concentration (ug/ml)		Total nitrate in Sample (ug) (MNO ₃)
			t _f (°F)	Δ Pg (IN.HG.)			Uncorr. for blank CRS	Corr. for blank (CRS - C _B)	
3366-55	19	13/1/1	75°	-		1	0.2049	0.2049	102
-56	20	13/1/2		-		1	0.3495	0.3495	75
-57	21	13/1/3		-		1	0.3017	0.3017	353
-58	22	13/1/4		-		1	0.3585	0.3585	180
-54	23	13/2/1		-		1	0.2134	0.2134	110
-60	24	13/2/2		No Pressure		1	0.2938	0.2938	200
-61	13	13/2/3		-		1	0.2800	0.2800	140
-62	14	13/2/4		-		1	0.2814	0.2814	140
-63	15	13/3/1		-		1	0.1534	0.1534	77
-64	16	13/3/2		-		1	0.3003	0.3003	150
-65	17	13/3/3		-		1	0.5304	0.5304	270
-66	18	13/3/4		-		1	0.3730	0.3730	190
Blank 1						1	C _{B1}		
Blank 2						1	C _{B2}		
Blank 3						1	C _{B3}		

C_B = _____

INTERPOLL LABORATORIES INC.

Formaldehyde Results Using EPA Method 0011
 For Dept. 20/LP Hayward Wi. Collected 7/12-13/94

Log #	Mass (ug)*	Field Spike		% Recovery	Test: 7			Source: Line 2 RTO Dryer Stack			
		Actual	Found		Run 0	Run 1	Run 2	Run 3	Run 0	Run 1	Run 2
	750		(3366-68)	90.9	(3366-67)	1.49	6760	9010	8120	(3366-70)	(3366-71)

Log #	Mass (ug)*	Field Spike		% Recovery	Test: 11			Source: Line 1 RTO Dryer Stack			
		Actual	Found		Run 0	Run 1	Run 2	Run 3	Run 0	Run 1	Run 2
					(3366-90)	< 0.05	4910	6650	14400	(3366-92)	(3366-93)

* = Total Mass of formaldehyde in the sample in ug.

Reviewed by:

Gregg W. Holman
 Gregg W. Holman
 Laboratory Director

EPA Method 10 NDIR Analyzers

Job Name L.P. Hayward NDIR Analyzer: Fugl ACS Model 3300
 Source Line 1 Core Dryer RTO Inlet Mon. Lab Model 8310
 Date of Analysis 7-18-94 Dasibi Model 3003
 Technician C. Helgeson Range: 0 - 200 ppm
 Flow rate: 100 cc/min

Pretest Calibration				Post-test Calibration			
Conc.	Reading	Vendor	Cyl. Number	Conc.	Reading	Vendor	Cyl. Number
Zero gas: 0	0	Scott	AAL17431	Zero gas: 0	0	Scott	AAL17431
Upscale gas: 41.5	41.5	National	CC 52502	Upscale gas: 41.5	41.0	National	CC 52502
Upscale gas: 204	209	↓	CC 81624	Upscale gas: 204	209.5	↓	CC 81624
Upscale gas: 204	209			Upscale gas: 204	209.5		

Sample Description Test/Run	Sample Log Number	CO Conc. (ppm, Dry)		Sample Description Test/Run	Sample Log Number	CO Conc. (ppm, Dry)	
		Dilution Factor	Reading			Actual ppm	Dilution Factor
15-1	3266-28	5.0	96.5				
15-2	-29	5.0	110.2				
15-3	-30	5.0	115.5				
15-4	-31	5.0	53.4				

Note 1: If sample dilution is required the sample is diluted with CO-free gas prior to analysis.
 Note 2: The Fugl ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000:1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000:1 and thus CO₂ removal prior to analysis is not required.
 Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

EPA Method 10 NDIR Analysis

Job Name L.P. Hayward
 Source Sioux Core Pryer Inlet
 Date of Analysis 7-18-94
 Technician C. Helgeson

NDIR Analyzer: Fugl ACS Model 3300
 Mon. Lab Model 8310
 Dasibi Model 3003
 Range: 0 - 200 ppm
 Flow rate: 1000 cc/min

Pretest Calibration				Post-test Calibration			
Conc.	Reading	Vendor	Cyl. Number	Conc.	Reading	Vendor	Cyl. Number
Zero gas: 0	ppm 0	Scott	AAAL 17431	Zero gas: 0	ppm 0	Scott	4AL 17431
Upscale gas: 415	ppm 415	National	CC 52502	Upscale gas: 415	ppm 420	National	CC 52502
Upscale gas: 209	ppm 209	↓	CC 81624	Upscale gas: 204	ppm 201.6	↓	CC 81624
Upscale gas: _____	ppm _____	_____	_____	Upscale gas: _____	ppm _____	_____	_____

Sample Description Test/Run	Sample Log Number	CO Conc. (ppm, Dry)		
		Dilution Factor	Reading	Actual ppm
3-1	3366-20	5.0	26	430
3-2	-21	5.0	185	925
3-3	-22	5.0	109	550

Note 1: If sample dilution is required the sample is diluted with CO-free gas prior to analysis.
 Note 2: The Fugl ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000; 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000; 1 and thus CO₂ removal prior to analysis is not required.
 Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

7-29

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: D 020/CP Hayward

Sample Collected: _____

Sample Received: _____

Sample Log #: 3366-76

Sample Description: _____

T9 R1 Tube A
LCII

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>MMIX</u>	<u>x 2.1</u>	<u>23</u>	<u>< 2.1</u>	<u>.61</u>	<u>< .61</u>	<u>< .61</u>
Toluene	Total ug	<u>7-21-94</u>						
o-xylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug		<u>20</u>	<u>94</u>	<u>< 90</u>	<u>27</u>		<u>67</u>
Dilution factor			<u>MMIX</u>	<u>7-26</u>				

Footnotes: _____

In-House Comments: _____

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: 1D020/LP Hayward

Sample Collected: _____

Sample Received: _____

Sample Log #: 3366-77

Sample Description: _____

T9R1 Tube B

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	MMA	<2.1	<2.1	<2.1	.61	<.61	<.61
Toluene	Total ug	F-2194						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug		90		90	27		27
			MMA	F-2694				
Dilution factor								

Footnotes: _____

In-House Comments: _____

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: 1D020/LP Hayward

Sample Collected: _____

Sample Received: _____

Sample Log #: 3366-78

Sample Description: _____

Test 9 Run 2 Tube A
LCI

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>MMH</u>	<u>< 2.1</u>	<u>4.8</u>	<u>< 2.1</u>	<u>.61</u>	<u>< .61</u>	<u>< .61</u>
Toluene	Total ug	<u>7-21-94</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: 17020 / LP Hayward

Sample Collected: _____

Sample Received: _____

Sample Log #: 3366-79

Sample Description: _____

T9 R2 Tube B

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>MMH</u>	<u>2.1</u>	<u><2.1</u>	<u><2.1</u>	<u>.61</u>	<u><.61</u>	<u><.61</u>
Toluene	Total ug	<u>7-21-94</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: ID 050 / LP Hayward

Sample Collected: _____

Sample Received: _____

Sample Log #: 3366-80

Sample Description: _____

CTI ^{*TAR*}
TAR3 Tube A

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<i>MIN</i>	<i>2.1</i>	<i>3.4</i>	<i>6.1</i>	<i>1.61</i>	<i><.61</i>	<i>2.61</i>
Toluene	Total ug	<i>7-21-94</i>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: 1D020/LP Hayward

Sample Collected: _____
 Sample Received: _____
 Sample Log #: 3366-81
 Sample Description: T9R3 Tube B

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>MMW</u>	<u>2.1</u>	<u><2.1</u>	<u>2.1</u>	<u>.61</u>	<u><.61</u>	<u><.61</u>
Toluene	Total ug	<u>7-2-94</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Dup 7/15/94

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 030 L.P. Hayward

Sample Collected: 7/15/94

Sample Received: 7/15/94

Sample Log #: 3366-09

Sample Description: charcoal tube

~~TR~~ RO
12 SLP

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	7/15/94	2.1	<2.1	2.1	.661	<.661	<.661
Toluene	Total ug	7-19-94						
ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Due 7/15/94

Interpoll Laboratories, Inc.
(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 020 L.P. Hayward

Sample Collected: 7/15/94
Sample Received: 7/15/94

Sample Log #: 3366-10
Sample Description: charcoal tube

~~TX~~ RI Tube |
12 SUP

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>MMH</u>	<u>2.1</u>	<u>14</u>	<u><2.1</u>	<u>.61</u>	<u><.61</u>	<u><.61</u>
Toluene	Total ug	<u>PPH</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Due 7/15/94

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 020 L.P. Hayward

Sample Collected: 7/15/94
Sample Received: 7/15/94

Sample Log #: 3366-11
Sample Description: Charcoal Tube

~~TX~~ R1 Tube 2
12 SLIP

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	MTH	2.1	<2.1	<2.1	.101	<.101	<.101
Toluene	Total ug	7-1994						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Due 7/29/94

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 020 L.P. Hayward

Sample Collected: 7/15/94

Sample Received: 7/18/94

Sample Log #: 3366-12

Sample Description: Charcoal Tube

~~TKR2~~ Tube 1
12 SW

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>N.M.A.U.</u>	<u>2.1</u>	<u>12</u>	<u><2.1</u>	<u>.601</u>	<u><.601</u>	<u><.601</u>
Toluene	Total ug	<u>7-1994</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Due 7/29/94

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 020 C.P. Hayward

Sample Collected: 7/15/94

Sample Received: 7/18/94

Sample Log #: 3366-13

Sample Description: Charcoal Tube

TV R2 Tube 2
12 sec

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>JJH</u>	<u>.21</u>	<u><.21</u>	<u><.21</u>	<u>.61</u>	<u><.61</u>	<u><.61</u>
Toluene	Total ug	<u>7-19-94</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Due 7/15/94

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 020 L.P. Hayward

Sample Collected: 7/15/94

Sample Received: 7/15/94

Sample Log #: 3366-14

Sample Description: charcoal tube

TKR3 Tube
12 sep

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	<u>MMN</u>	<u>2.1</u>	<u>8.4</u>	<u><2.1</u>	<u>.661</u>	<u><.661</u>	<u>2.661</u>
Toluene	Total ug	<u>41994</u>						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

Due 7/29/94

Interpoll Laboratories, Inc.

(612)786-6020

BTEX/THC as Gas in Air Samples (Charcoal Tubes) by NIOSH Method 1501 Data Reporting Sheet

Client: J.D. 020 C.P. Hayward

Sample Collected: 7/15/94
Sample Received: 7/18/94
Sample Log #: 3366-15
Sample Description: charcoal tube

TXR3 Tube 2
12 SLP

Parameter	Units	Analysis Date & Initials	FRONT			BACK		
			Detection Limit Front	Analytical Result Front	Method Blank Front	Detection Limit Back	Analytical Result Back	Method Blank Back
Benzene	Total ug	177X	2.1	<2.1	<2.1	.61	<.61	<.61
Toluene	Total ug	199X						
Ethylbenzene	Total ug							
Xylenes	Total ug							
Dilution factor								
Total hydrocarbons as gasoline	Total ug							
Dilution factor								

Footnotes: _____

In-House Comments: _____

INTERPOLL LABORATORIES INC.


Phenol Result By EPA Method 8270
For Dept. 20/LP Hayward, Collected 7/15/94

	Detection Limit	Test: 10				Source: Line 2 RTO Dryer Stack
		Run 0	Run 1	Run 2	Run 3	
Log #		3366-82/83	3366-84/85	3366-86/87	3366-88/89	
Phenol*	840	BDL	BDL	BDL	BDL	
Surrogates						
2-Fluorophenol**		63.3	19.4	17.2	19.4	
D6-Phenol***		24.2	12.6	12.3	10.6	
2,4,6-Tribromophenol***		62.3	66.4	52.7	60.2	

	Detection Limit	Test: 19				Source: Line 1 RTO Dryer Stack
		Run 0	Run 1	Run 2	Run 3	
Log #		3366-01/02	3366-03/04	3366-05/06	3366-07/08	
Phenol*	840	BDL	BDL	BDL	BDL	
Surrogates						
2-Fluorophenol**		54.3	12.9	15.4	11.6	
D6-Phenol***		22.4	11.2	12.7	10.4	
2,4,6-Tribromophenol***		45.3	52.1	64.6	52.0	

- * = Total mass of the specified compound in the sample in ug.
- ** = Percent recovery of the field surrogate.
- *** = Percent recovery of the lab surrogates.

Reviewed By:



Gregg W. Holman
Laboratory Director

Interpoll Laboratories
(612) 786-6020

IMPINGER CATCHES

Project Name: L. P. Hayward Order Date: _____
Date Required: 7/8/94 Delivery Date: 7/8/94

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
D-6 Phenol (P-67)	5.3316 mg/mL	1.0 mL	5.3316 mg
2-fluorophenol (P-68)	49.8140 mg/mL	1.2 mL	59.7768 mg

SPECIAL REQUIREMENTS

WNO 7/8/94

**Please return this form with the samples.

XAD-2 & VOST Trap Preparation Work
Order Form

Project Name: L.P. Hayward Order Date: _____
Date Required: 7/8/94 Delivery Date: 7/8/94

Number of XAD-2 Traps Required: 8

Number of VOST Tubes Required: _____ Tenax
_____ Tenax/Charcoal

XAD-2 TRAP HISTORY

XAD-2 Lot Number: 1992 Date of Spiking: 7/8/94
XAD-2 Lot Date: _____ Technician: B. J. Baker
XAD-2 Lot Technician: Alltech

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
Dio-Fluorathene	4.0 ug/ μ l	5.0 μ l	20.0 ug

VOST TUBE HISTORY

Date of Thermal Desorption: _____ Technician: _____
Total Hydrocarbon Analysis: _____ ppm

SPECIAL REQUIREMENTS

**Please return this form with the samples.

INTERPOLL LABORATORIES INC.

Polycyclic Organic Matter Results By EPA Method 8270
For Dept. 20/ LP Hayward

	Detection Limit	Test : 8				Source: Line 2 Dryer RTO Stack			
		Run 0	Run 1	Run 2	Run 3	Run 0	Run 1	Run 2	Run 3
Date Collected		7/12/94	7/13/94	7/13/94	7/13/94				
Log #		3366-72	3366-73	3366-74	3366-75				
Compounds of Interest*									
Naphthalene	1.5	42	21	41	25				
1-Methyl naphthalene	0.8	< 0.8	< 0.8	< 0.8	< 0.8				
2-Methyl naphthalene	8.3	< 8.3	< 8.3	< 8.3	< 8.3				
Acenaphthylene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Acenaphthene	1.0	< 1.0	< 1.0	< 1.0	< 1.0				
Fluorene	1.0	< 1.0	< 1.0	< 1.0	< 1.0				
Phenanthrene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Anthracene	0.8	< 0.8	< 0.8	< 0.8	< 0.8				
Fluoranthene	1.2	< 1.2	< 1.2	< 1.2	< 1.2				
Pyrene	1.5	< 1.5	< 1.5	< 1.5	< 1.5				
Benzo-a-anthracene	1.8	< 1.8	< 1.8	< 1.8	< 1.8				
Chrysene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Benzo-b-fluoranthene	1.0	< 1.0	< 1.0	< 1.0	< 1.0				
Benzo-k-fluoranthene	1.7	< 1.7	< 1.7	< 1.7	< 1.7				
Benzo-a-pyrene	1.2	< 1.2	< 1.2	< 1.2	< 1.2				
Benzo-a,h-anthracene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Benzo-g,h,i-perylene	1.2	< 1.2	< 1.2	< 1.2	< 1.2				
Indeno-1,2,3-pyrene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Field Surrogate Recovery									
D10-Fluoranthene**		68.5	52.5	80.5	43.0				
Lab Surrogate Recovery									
2-Fluorophenol***		52.5	26.5	57.4	14.7				
Phenol-D6***		46.8	25.6	54.2	14.2				
Nitrobenzene-D6***		61.6	28.0	65.4	15.7				
2-Fluorobiphenyl***		64.8	27.0	73.0	16.0				
2,4,6-Tribromophenol***		10.6	31.3	65.4	16.3				
D14-Terphenyl***		103	57.4	96.0	20.1				

- * = Total mass of the specified compound in the sample in ug.
- ** = Percent recovery of the field surrogate.
- *** = Percent recovery of the lab surrogates.

Reviewed By:

Gregg W. Holman
Gregg W. Holman
Laboratory Director

INTERPOLL LABORATORIES INC.

Polycyclic Organic Matter Results By EPA Method 8270
For Dept. 20/ LP Hayward


	Detection Limit	Test : 20				Source: Line 1 Dryer RTO Stack			
		Run 0	Run 1	Run 2	Run 3				
Date Collected		7/14/94	7/15/94	7/15/94	7/15/94				
Log #		3366-103	3366-104	3366-105	3366-106				
Compounds of Interest*									
Naphthalene	1.5	32	48	54	50				
1-Methyl naphthalene	0.8	< 0.8	3.1	2.2	1.5				
2-Methyl naphthalene	8.3	< 8.3	< 8.3	< 8.3	< 8.3				
Acenaphthylene	0.9	< 0.9	2.8	3.0	< 0.9				
Acenaphthene	1.0	< 1.0	< 1.0	< 1.0	< 1.0				
Fluorene	1.0	< 1.0	< 1.0	< 1.0	< 1.0				
Phenanthrene	0.9	< 0.9	1.9	1.3	< 0.9				
Anthracene	0.8	< 0.8	< 0.8	< 0.8	< 0.8				
Fluoranthene	1.2	< 1.2	< 1.2	< 1.2	< 1.2				
Pyrene	1.5	< 1.5	< 1.5	< 1.5	< 1.5				
Benzo-a-anthracene	1.8	< 1.8	< 1.8	< 1.8	< 1.8				
Chrysene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Benzo-b-fluoranthene	1.0	< 1.0	< 1.0	< 1.0	< 1.0				
Benzo-k-fluoranthene	1.7	< 1.7	< 1.7	< 1.7	< 1.7				
Benzo-a-pyrene	1.2	< 1.2	1.3	1.4	1.2				
Dibenzo-a,h-anthracene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Benzo-g,h,i-perylene	1.2	< 1.2	< 1.2	< 1.2	< 1.2				
Indeno-1,2,3-pyrene	0.9	< 0.9	< 0.9	< 0.9	< 0.9				
Field Surrogate Recovery									
D10-Fluoranthene**		91.0	74.0	85.0	83.5				
Lab Surrogate Recovery									
2-Fluorophenol***		51.1	63.0	72.2	71.4				
Phenol-D6***		53.7	60.7	71.7	78.6				
Nitrobenzene-D6***		62.6	78.0	86.8	83.8				
2-Fluorobiphenyl***		63.2	67.8	75.2	73.4				
2-Fluorobiphenyl***		4.3	59.8	58.4	57.4				
D14-Terphenyl***		90.8	94.0	55.7	101				

* = Total mass of the specified compound in the sample in ug.

** = Percent recovery of the field surrogate.

*** = Percent recovery of the lab surrogates.

Reviewed By:



Gregg W. Holman
Laboratory Director

Sample Chain of Custody

Job Field Engineer Source A.P. Hayward, MI Date of Test 2-12-94 Site Stach Log No. 3366
 Field Engineer Mark Saehler Source Line 2 Dryer #70 Test No. 1 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3+1	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₄ <input type="checkbox"/> DI Water	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
3+1	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
3+1	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 1.3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 12.4 DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MIN Protocol <input checked="" type="checkbox"/> MVI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> Acid Gases		
3	Integrated Gas: <input checked="" type="checkbox"/> Cellar Bag <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____		Analyzed in Excel
-	Oxides of Nitrogen: <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
-	Particle Sizing: <input type="checkbox"/> _____	<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> Cascade Imp		
-	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas Other _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Saehler / Interpoll Labs</u>	<u>Mark Saehler / Interpoll</u>	<u>7/18/94 0900</u>

INTERPOIL LABORATORIES, INC.

(612) 786-6020

Line 2 Sample Chain of Custody

Log No. 3366
No. of Runs 3

Site ATO DUST

Source SURFACE DRYER


Test No. 2

Date of Test 7-12-94

Job LP / HAYWARD
Field Engineer BOB

No. Items	Sample Type	Analysis	Sequence No.	Comments
4	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/>	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		3 Sample 1 blank
5	Filters: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		4 Sample 1 blank
4	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 12,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/>	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/>		3 Sample 1 blank
3	Integrated Gas: <input checked="" type="checkbox"/> Cellar Bag <input type="checkbox"/>	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/>		
12	Oxides of Nitrogen: <input type="checkbox"/>	<input checked="" type="checkbox"/> EPA M-7A <input type="checkbox"/>		7-18-94 0800
1	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
1	Particle Sizing: <input type="checkbox"/>	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/>		
1	Miscellaneous: <input type="checkbox"/>	<input type="checkbox"/>		

Fuel Type: Coal: Bituminous Anthracite Lignite
Wood: Wood Waste Dust Bark
Oil: Waste Oil No. 2 No. 6
Misc: Natural Gas RDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Paul Interpoll</u>	<u>7/15/94 0900</u>

Sample Chain of Custody

Log No. 3366
No. of Runs 3

Line of Source Line 3 Core Drift Site
Date of Test 7-12-94 Test No. 3

Job LP / Heavy metal
Field Engineer DPA

No. Items	Sample Type	Analysis	Sequence No.	Comments
4	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
4	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
4	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 12.4 DNPH	<input type="checkbox"/> MN Protocol <input checked="" type="checkbox"/> MVI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases		
3	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____		
3	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
	Particle Sizing:	<input type="checkbox"/> X-Ray Sedgraph <input type="checkbox"/> _____		
	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood Waste Wood Dust Bark
 Natural Gas LORDF _____

Relinquished by/Affiliation <u>Dennis G. Marco Interpoll Labs</u>	Accepted by/Affiliation <u>Richard J. Trappell</u>	Date <u>7/18/94 0700</u>
--	---	-----------------------------

Sample Chain of Custody

LOG No. 3366
 No. of Runs 3

LOG No. _____
 No. of Runs _____

Source Line 2 Dyer RD Site Street
 Date of Test 7-12-94 Test No. 7

Field Engineer L.P. Hayward/ML Mikachler

No. Items	Sample Type	Analysis	Sequence No.	Comments
3 Sp. Kc Blank	Probe Wash: <input type="checkbox"/> DI Water <input type="checkbox"/> Acetone <input checked="" type="checkbox"/> MeCl ₂ Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> 5S Thimble	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17 <input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		<u>Added to Dyer rd Lnsc.</u>
3 Sp. Kc Blank	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____ Integrated Gas: <input checked="" type="checkbox"/> Wetlar Bag <input type="checkbox"/> _____ Oxides of Nitrogen: <input type="checkbox"/> _____ <input type="checkbox"/> _____	<input type="checkbox"/> MIN Protocol <input type="checkbox"/> IWI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per S-0163		
—	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate Particle Sizing: <input type="checkbox"/> _____ <input type="checkbox"/> _____ Miscellaneous: <input type="checkbox"/> _____ <input type="checkbox"/> _____	<input type="checkbox"/> MIN Protocol <input checked="" type="checkbox"/> IIA Protocol <input type="checkbox"/> IWI Protocol <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> Acid Gases <input checked="" type="checkbox"/> EPA M-10 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per S-0163		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc.: Natural Gas RDF _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Gardner / Unemployed</u>	<u>ML Mikachler</u>	<u>7/12/94 0905</u>

Interpoll Laboratories
(612) 786-6020

SAMPLE CHAIN OF CUSTODY

Job L.P. / Hennings, et al Source Line 2, Dept. 110 Site Stack
 Field Engineer M. Kuchler Date of Test 7-13-94 Test No. 9 No. of Runs 3

# ITEMS	SAMPLE TYPE	ANALYSIS	LOG NUMBER	COMMENTS
-	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29	<input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____	
-	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A	<input type="checkbox"/> EPA M-17 _____	
6	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> Charcoal Tubes	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases	<input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> <u>Asbestos</u>	
-	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-10 _____	
-	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
-	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____	<input type="checkbox"/> Cascade Imp _____	
-	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Wood Wood Waste Oil: Waste Oil Natural Gas
 Anthracite Dust NO. 2 IRDF
 Lignite Bark NO. 6 _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Gachow / Interpoll Labs</u>	<u>[Signature] Interpoll</u>	<u>7/18/94 0900</u>

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

LOG No. 3366
No. of Runs 3

Job Field Engineer A. P. / Haysward, III Source Ames Dryer #10 Site Stark
Date of Test 2-13-74 Test No. 10

No. Items	Sample Type	Analysis	Sequence No.	Comments
576	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____		
-	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass		
371	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> Phenol A+B		
-	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> _____		
-	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Per S-0163		
-	Particle Sizing:	<input type="checkbox"/> X-Ray Scigraph <input type="checkbox"/> _____		
-	Miscellaneous:	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous
 Anthracite
 Lignite

Wood: Wood Waste
 Dust
 Bark

Oil: Waste Oil
 No. 2
 No. 6

Misc: Natural Gas
 RDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Baender / Interpoll Labs</u>	<u>See Interpoll</u>	<u>7/18/74 0900</u>

Sample Chain of Custody

Job Field Engineer C. Phayward Source Line 1 Diner RTO Date of Test 7-13-94 Log No. 3366
E. J. Lawrence Test No. 11 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
7	Probe Wash: <input type="checkbox"/> DI Water <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> MIPCL ₂	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> MN Protocol <input checked="" type="checkbox"/> MWI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6, B <input type="checkbox"/> Acid Gases <input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-7A <input type="checkbox"/> Per S-0163 <input type="checkbox"/> X-Ray Sulgraph <input type="checkbox"/> Cascade Imp <input type="checkbox"/>		
3	Integrated Gas: <input checked="" type="checkbox"/> Xcellar Bag Oxides of Nitrogen: Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate Particle Sizing: Miscellaneous: <input type="checkbox"/>	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-7A <input type="checkbox"/> Per S-0163 <input type="checkbox"/> X-Ray Sulgraph <input type="checkbox"/> Cascade Imp <input type="checkbox"/>		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF

Relinquished by/Affiliation: E. J. Lawrence / Interpol Lab
 Accepted by/Affiliation: W. J. Lawrence / Interpol Lab
 Date: 7/18/94 0900

INTERPOIL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

3366

Job Field Engineer Bob Source Line 1 Subsector Site Dyer 1870 Duet Log No. 13
 Date of Test 7-14-94 Test No. 13 No. of Runs

No. Items	Sample Type	Analysis	Sequence No.	Comments
5	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
5-55	Filter: <input checked="" type="checkbox"/> 4" Glass <input checked="" type="checkbox"/> SS Thimble	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
4	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input checked="" type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases		
4	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____		
12	Oxides of Nitrogen:	<input checked="" type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		7-18-94 0500
1	Fuel Lab: <input type="checkbox"/> Fuel Sample	1 Per 5-0163		
1	Particle Sizing:	<input type="checkbox"/> X-Ray Scigraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade Imp		
1	Miscellaneous:	<input type="checkbox"/> _____		

Fuel Type: Coal Bituminous Anthracite Lignite
 Wood Wood Waste Dust Bark
 Oil Waste Oil No. 2 No. 6
 Natural Gas RDF Misc:

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<i>[Signature]</i>	<i>[Signature]</i>	7/18/94 0900

INTERPOLLAB LABORATORIES, INC.

(612) 233-6020

Sample Chain of Custody

Log No. 3366
No. of Runs 3

Job L.P. / Hesperian, Inc. Source Area 1 Dept. 1172 Site Stack
Field Engineer M. Kachur Date of Test 2-14-94 Test No. 18

No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> _____		
3	Filter: <input checked="" type="checkbox"/> 1" Glass <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
3	Inspingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input checked="" type="checkbox"/> HWI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> _____		
3	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____		
-	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
-	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp <input type="checkbox"/> _____		
-	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood Waste Wood Waste Oil Natural Gas
 Dust No. 2 MISC RDF
 Bank No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Gardner / Interpoll Labs</u>	<u>Bob / Interpoll</u>	<u>7/18/94 0900</u>

INTERPOL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer DM Source Line 1 core Dyse Site Log No. 3366
 Date of Test 7-14-94 Test No. 15 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
5	Probe Wash: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		
4	Filter: <input type="checkbox"/> 4" Glass <input checked="" type="checkbox"/> SS Thimble	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
9	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input checked="" type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M-6,8 <input type="checkbox"/> Acid Gases		
4	Integrated Gas: <input checked="" type="checkbox"/> Tedlar Bag	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10		Box 33 / 1/2, 3 Box 85 - 1
1	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A		
1	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Per S-0163		
1	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
1	Miscellaneous:	<input type="checkbox"/>		

Fuel Type: Coal: Bituminous
 Anthracite
 Lignite
 Wood: Wood Waste
 Dust
 Bark
 Oil: Waste Oil
 No. 2
 No. 6
 Misc: Natural Gas
 RDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Dennis S. Manso</u>	<u>Adrian J. Turpil</u>	<u>7/18/94 0700</u>

INTERPOLLA LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Log No. 3366
No. of Runs 3

Source Line 1 Dryer BTO Site Stack
Date of Test 7-15-94 Test No. 19

Job LP/Hayward
Field Engineer D. Marso

No. Items	Sample Type	Analysis	Sequence No.	Comments
—	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____		
—	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass		
✓ 8	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 13% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> Phenol solution	3366 01-08	
—	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> _____		
—	Oxides of Nitrogen:	<input type="checkbox"/> _____		
—	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Aggregate		
—	Particle Sizing:	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____		
—	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Wood Waste
 Anthracite Dust
 Lignite Bark
Oil: Waste Oil No. 2 No. 6
Misc: Natural Gas RDF _____

Relinquished by/Affiliation <u>Dennis S. Marso</u>	Accepted by/Affiliation <u>Bob Long, Interpolla</u>	Date <u>7/15/94 0700</u>

INTERPOL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Log No. 3366
No. of Runs 3

Source Line 1 Dryer RTO Site
Test No. 19

Date of Test 7-15-94

Field Engineer D. Marsa

Job LP/Hayward


No. Items	Sample Type	Analysis	Sequence No.	Comments
—	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29	<input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____
—	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A	<input type="checkbox"/> EPA M-17
78	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> Charcoal Tubes	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases	<input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> Method 18
—	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-10
—	Oxides of Nitrogen:		<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____	
—	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Aggregate	<input type="checkbox"/> Per 5-0163	
—	Particle Sizing:		<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____	<input type="checkbox"/> Cascade Imp
—	Miscellaneous:	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF

Relinquished by/Affiliation <u>Dennis H. Marsa</u>	Accepted by/Affiliation <u>Bob Long, Director</u>	Date <u>7/18/94 0700</u>

APPENDIX F

TOTAL HYDROCARBONS STRIPCHARTS / DATA LOGGER PRINTOUTS



Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP15
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	16:25:00	23.2	9442	3.80	16.67
195	16:27:00	22.7	370	3.90	16.51
195	16:28:00	22.5	368	3.97	16.49
195	16:29:00	23.7	424	4.20	16.22
195	16:30:00	22.8	466	4.27	16.15
195	16:43:00	22.2	410	4.11	16.35
195	16:44:00	21.7	447	4.16	16.30
195	16:45:00	23.1	499	4.32	16.10
195	16:46:00	24.5	538	4.60	15.88
195	16:47:00	25.6	666	4.62	15.77
195	16:48:00	27.0	524	4.33	16.06
195	16:49:00	25.3	448	3.83	16.60
195	16:50:00	24.8	332	3.64	16.88
195	16:51:00	24.3	323	3.53	16.96
195	16:52:00	24.8	302	3.32	17.23
195	16:53:00	20.5	315	3.75	16.79
195	16:54:00	20.5	346	3.95	16.59
195	16:55:00	21.6	460	4.21	16.24
195	16:56:00	21.5	450	4.17	16.30
195	16:57:00	22.5	487	4.27	16.18
195	16:58:00	23.6	528	4.46	15.98
195	16:59:00	24.6	630	4.51	15.93
195	17:00:00	24.5	617	4.47	15.94
195	17:01:00	26.0	572	4.30	16.12
195	17:02:00	25.6	492	4.16	16.29
195	17:03:00	24.4	444	3.96	16.48
195	17:04:00	23.4	359	3.80	16.75
195	17:05:00	22.7	428	4.20	16.29
195	17:06:00	23.0	490	4.23	16.24
195	17:07:00	22.8	519	4.27	16.16
195	17:08:00	15.6	454	2.38	17.76
195	17:09:00	4.1	36.5	0.08	20.74
195	17:10:00	2.5	0.5	0.06	20.75
195	17:11:00	2.0	0.2	0.06	20.75

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP15
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	17:12:00	1.7	0.2	0.05	20.76
195	17:13:00	8.7	70.5	2.39	18.72
195	17:14:00	15.5	381	3.98	16.52
195	17:15:00	22.8	434	4.24	16.21
195	17:16:00	22.3	400	4.03	16.42
195	17:17:00	23.1	392	4.03	16.45
195	17:18:00	22.5	375	3.85	16.65
195	17:19:00	22.6	346	3.75	16.75
195	17:20:00	21.3	342	3.99	16.55
195	17:21:00	22.8	434	4.22	16.25
195	17:22:00	23.2	470	4.33	16.14
195	17:23:00	23.8	524	4.34	16.07
195	17:24:00	23.6	449	4.16	16.32
195	17:25:00	24.7	451	4.25	16.20
195	17:26:00	24.2	441	4.17	16.30
195	17:27:00	23.5	422	4.15	16.33
195	17:28:00	22.8	432	4.16	16.34
195	17:29:00	23.7	438	4.22	16.24
195	17:30:00	24.1	425	4.30	16.18
195	17:31:00	24.0	428	4.18	16.27
195	17:32:00	23.2	382	4.10	16.40
195	17:33:00	23.2	469	4.45	16.01
195	17:34:00	24.7	521	4.49	15.96
195	17:35:00	25.1	538	4.61	15.86
195	18:28:00	26.8	651	4.72	15.73
195	18:29:00	27.3	686	4.88	15.59
195	18:30:00	27.7	715	4.87	15.58
195	18:31:00	28.8	768	5.08	15.41
195	18:32:00	28.3	801	4.83	15.59
195	18:33:00	26.9	699	4.73	15.72
195	18:34:00	27.4	682	4.62	15.80
195	18:35:00	27.2	581	4.46	15.97
195	18:36:00	27.3	527	4.36	16.05
195	18:37:00	29.5	452	4.41	16.07

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP15
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	18:38:00	26.5	563	4.42	15.99
195	18:39:00	25.4	478	4.30	16.17
Run Average		22.5	576	3.94	16.54

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP153
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	22:31:00	36.2	%-9999.0	4.81	15.78
195	22:32:00	35.8	%-9999.0	4.70	15.84
195	22:33:00	34.6	920	4.33	16.22
195	22:34:00	35.4	841	4.42	16.17
195	22:35:00	34.7	905	4.40	16.17
195	22:36:00	33.7	853	4.37	16.22
195	22:37:00	34.5	962	4.53	16.03
195	22:38:00	34.5	947	4.48	16.08
195	22:39:00	34.7	875	4.38	16.20
195	22:40:00	35.3	900	4.44	16.11
195	22:41:00	32.2	717	3.96	16.61
195	22:42:00	31.3	545	4.01	16.66
195	22:43:00	30.7	586	4.00	16.65
195	22:44:00	31.2	544	3.99	16.64
195	22:45:00	30.3	530	3.92	16.73
195	22:46:00	31.7	540	4.10	16.55
195	22:47:00	31.5	596	4.11	16.51
195	22:48:00	32.0	626	4.23	16.39
195	22:49:00	32.0	743	4.31	16.26
195	22:50:00	33.4	819	4.55	16.05
195	22:51:00	34.7	951	4.56	16.00
195	22:52:00	34.8	920	4.59	15.98
195	22:53:00	36.5	918	4.42	16.12
195	22:54:00	35.5	769	4.23	16.32
195	22:55:00	32.3	576	3.68	16.96
195	22:56:00	30.9	427	3.76	16.92
195	22:57:00	29.2	402	3.53	17.16
195	22:58:00	28.7	382	3.74	16.97
195	22:59:00	29.1	447	3.79	16.89
195	23:00:00	30.4	506	4.11	16.55
195	23:01:00	10.2	458	1.36	19.04
195	23:02:00	0.5	19.7	-0.08	21.19
195	23:03:00	-0.0	-1.2	-0.10	21.20
195	23:04:00	-0.1	-1.2	-0.10	21.19

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP153
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	23:05:00	14.0	274	3.82	17.37
195	23:06:00	22.5	730	4.34	16.20
195	23:07:00	26.0	849	4.23	16.27
195	23:08:00	26.6	719	4.25	16.33
195	23:09:00	28.0	762	4.25	16.25
195	23:10:00	26.8	703	4.19	16.36
195	23:11:00	25.7	678	4.01	16.53
195	23:12:00	25.7	570	4.07	16.51
195	23:13:00	25.2	653	4.08	16.46
195	23:14:00	24.4	646	4.11	16.44
195	23:15:00	25.3	681	4.13	16.40
195	23:16:00	25.6	789	4.38	16.10
195	23:17:00	25.7	810	4.16	16.31
195	23:18:00	24.6	617	3.93	16.58
195	23:19:00	26.1	496	3.79	16.74
195	23:20:00	24.9	386	3.37	17.18
195	23:21:00	23.7	281	3.13	17.48
195	23:22:00	22.6	268	3.42	17.22
195	23:23:00	22.6	322	3.56	17.03
195	23:24:00	21.8	373	3.75	16.84
195	23:49:00	20.2	322	3.76	16.89
195	23:50:00	25.8	454	3.91	16.69
195	23:51:00	25.3	568	4.13	16.44
195	23:52:00	23.1	649	4.17	16.41
195	23:53:00	24.0	754	4.31	16.21
195	23:54:00	24.7	752	4.24	16.30
195	23:55:00	25.0	755	4.20	16.34
195	23:56:00	24.5	694	4.08	16.47
195	23:57:00	23.8	539	3.75	16.84
195	23:58:00	22.6	449	3.84	16.80
195	23:59:00	22.0	485	3.88	16.75
196	00:00:00	21.9	510	3.86	16.73
Run Average		28.1	> 647	4.05	16.54

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP154
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
196	00:49:00	24.0	349	3.52	16.86
196	00:50:00	24.5	253	3.27	17.21
196	00:51:00	25.3	236	3.11	17.34
196	00:52:00	22.6	215	3.31	17.20
196	00:53:00	21.5	232	3.53	16.96
196	00:54:00	19.7	289	3.84	16.61
196	00:55:00	20.5	303	3.72	16.71
196	00:56:00	21.8	286	3.73	16.71
196	00:57:00	22.8	282	3.56	16.85
196	00:58:00	21.8	239	3.54	16.94
196	00:59:00	24.0	233	3.34	17.10
196	01:00:00	23.0	230	3.46	17.02
196	01:01:00	22.8	254	3.42	17.00
196	01:02:00	21.9	223	3.36	17.14
196	01:03:00	21.2	243	3.57	16.91
196	01:04:00	21.1	249	3.65	16.81
196	01:05:00	21.4	272	3.64	16.80
196	01:06:00	21.5	267	3.61	16.83
196	01:07:00	24.4	244	3.39	17.06
196	01:08:00	23.2	230	3.35	17.10
196	01:09:00	23.6	217	3.15	17.31
196	01:10:00	20.0	217	3.47	17.04
196	01:11:00	19.8	251	3.58	16.89
196	01:12:00	19.0	292	3.91	16.55
196	01:13:00	21.3	326	3.60	16.77
196	01:14:00	23.7	227	3.19	17.25
196	01:15:00	26.9	195	2.98	17.47
196	01:16:00	26.6	183	2.96	17.53
196	01:17:00	24.6	193	3.08	17.42
196	01:18:00	19.6	218	3.46	17.05
196	01:19:00	9.4	222	1.42	18.78
196	01:20:00	1.4	11.0	-0.12	20.91
196	01:21:00	0.3	-1.9	-0.13	20.92
196	01:22:00	0.0	-2.2	-0.13	20.91

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP154
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Core Dryer RTO Inlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
196	01:23:00	16.0	86.4	2.67	18.23
196	01:24:00	20.4	199	3.00	17.48
196	01:25:00	22.9	214	3.08	17.37
196	01:26:00	22.3	205	3.36	17.18
196	01:27:00	20.2	296	4.00	16.45
196	01:28:00	20.5	357	3.78	16.58
196	01:29:00	25.1	258	3.22	17.18
196	01:30:00	32.4	210	2.57	17.81
196	01:31:00	33.5	220	2.27	18.17
196	01:32:00	29.0	159	2.58	17.94
196	01:33:00	22.9	183	3.13	17.41
196	01:34:00	17.9	219	3.62	16.87
196	01:35:00	18.0	294	3.81	16.65
196	01:36:00	18.3	344	3.97	16.43
196	01:37:00	19.3	350	3.90	16.48
196	01:38:00	23.3	277	3.28	17.13
196	01:39:00	25.8	230	3.11	17.34
196	01:40:00	26.6	204	2.97	17.51
196	01:41:00	25.6	190	3.04	17.42
196	01:42:00	20.2	204	3.41	17.11
196	01:43:00	21.4	244	3.36	17.06
196	01:44:00	20.1	245	3.57	16.90
196	01:45:00	21.9	258	3.44	16.97
196	01:46:00	22.4	220	3.36	17.13
196	01:47:00	21.6	264	3.72	16.74
196	01:48:00	21.2	313	3.77	16.66
196	01:49:00	22.4	301	3.60	16.81
196	01:50:00	21.6	275	3.73	16.73
196	01:51:00	23.2	342	3.89	16.54
Run Average		22.3	247	3.37	17.09

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT1
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	16:26:00	29.4	164	4.49	16.62
195	16:27:00	31.1	203	4.42	16.56
195	16:28:00	28.4	146	4.29	16.65
195	16:29:00	27.4	134	4.26	16.79
195	16:30:00	29.4	131	4.40	16.73
195	16:43:00	30.5	212	4.37	16.53
195	16:44:00	27.8	147	4.17	16.75
195	16:45:00	26.5	152	4.42	16.60
195	16:46:00	28.2	161	4.47	16.56
195	16:47:00	30.7	219	4.68	16.31
195	16:48:00	28.5	191	4.56	16.31
195	16:49:00	27.3	171	4.39	16.54
195	16:50:00	27.7	138	4.20	16.86
195	16:51:00	30.3	195	4.40	16.58
195	16:52:00	28.4	170	4.32	16.55
195	16:53:00	27.0	169	4.11	16.83
195	16:54:00	27.9	131	4.24	16.85
195	16:55:00	30.4	197	4.44	16.53
195	16:56:00	28.8	170	4.51	16.37
195	16:57:00	27.0	183	4.49	16.47
195	16:58:00	29.3	171	4.67	16.41
195	16:59:00	31.5	270	4.78	16.13
195	17:00:00	29.3	218	4.74	16.14
195	17:01:00	27.4	212	4.56	16.37
195	17:02:00	29.4	172	4.54	16.51
195	17:03:00	31.7	235	4.61	16.33
195	17:04:00	28.9	185	4.48	16.39
195	17:05:00	27.0	174	4.41	16.57
195	17:06:00	28.6	165	4.55	16.52
195	17:07:00	30.9	251	4.66	16.29
195	17:08:00	28.5	201	4.53	16.35
195	17:09:00	26.5	184	4.44	16.52
195	17:10:00	28.9	159	4.45	16.61
195	17:11:00	31.3	229	4.63	16.34

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT1
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	17:12:00	28.9	194	4.42	16.42
195	17:13:00	26.8	172	4.29	16.68
195	17:14:00	28.5	152	4.45	16.63
195	17:15:00	30.7	229	4.55	16.39
195	17:16:00	29.1	188	4.56	16.31
195	17:17:00	26.5	178	4.34	16.56
195	17:18:00	27.7	147	4.32	16.74
195	17:19:00	29.7	209	4.29	16.64
195	17:20:00	27.7	153	4.23	16.67
195	17:21:00	26.1	157	4.38	16.57
195	17:22:00	28.0	152	4.49	16.57
195	17:23:00	30.7	235	4.57	16.32
195	17:24:00	28.7	181	4.47	16.39
195	17:25:00	26.7	173	4.39	16.55
195	17:26:00	28.5	149	4.43	16.64
195	17:27:00	31.2	225	4.58	16.34
195	17:28:00	29.2	190	4.59	16.29
195	17:29:00	28.2	203	4.73	16.20
195	17:30:00	30.1	191	4.68	16.34
195	17:31:00	33.1	277	4.94	15.98
195	17:32:00	30.5	242	4.82	16.02
195	17:33:00	28.7	242	4.83	16.12
195	17:34:00	30.8	213	4.83	16.20
195	17:35:00	33.2	290	4.87	16.03
195	18:28:00	29.7	203	4.75	16.07
195	18:29:00	27.7	213	4.77	16.12
195	18:30:00	28.3	183	4.65	16.31
195	18:31:00	31.5	231	4.49	16.42
195	18:32:00	30.0	185	4.42	16.41
195	18:33:00	27.8	172	4.46	16.47
195	18:34:00	27.0	157	4.61	16.45
195	18:35:00	33.5	220	4.90	15.98
195	18:36:00	34.4	236	4.98	15.88
195	18:37:00	30.7	212	4.91	15.86

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT1
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	18:38:00	29.6	198	4.75	16.13
195	18:39:00	29.8	191	4.50	16.48
195	18:40:00	31.6	203	4.59	16.46
Run Average		29.2	191	4.53	16.42

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT3
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	22:31:00	29.4	270	4.35	16.49
195	22:32:00	28.8	238	4.43	16.32
195	22:33:00	28.2	206	4.21	16.51
195	22:34:00	31.4	177	4.03	16.82
195	22:35:00	30.7	185	4.19	16.49
195	22:36:00	28.0	163	4.08	16.67
195	22:37:00	27.0	174	4.31	16.63
195	22:38:00	31.2	248	4.43	16.42
195	22:39:00	30.7	259	4.29	16.41
195	22:40:00	29.7	177	4.11	16.62
195	22:41:00	28.9	153	4.22	16.50
195	22:42:00	29.9	161	4.03	16.89
195	22:43:00	30.0	186	4.17	16.58
195	22:44:00	27.6	163	4.02	16.71
195	22:45:00	26.6	137	3.69	17.18
195	22:46:00	30.0	136	3.99	16.94
195	22:47:00	32.3	155	4.18	16.38
195	22:48:00	29.4	130	4.25	16.41
195	22:49:00	27.9	142	4.20	16.59
195	22:50:00	28.8	170	3.89	17.02
195	22:51:00	29.1	215	3.98	16.92
195	22:52:00	28.2	190	4.22	16.59
195	22:53:00	28.8	186	4.42	16.35
195	22:54:00	32.2	183	4.33	16.41
195	22:55:00	31.2	197	4.26	16.38
195	22:56:00	28.4	128	4.00	16.70
195	22:57:00	26.3	117	3.73	17.07
195	22:58:00	27.8	118	3.52	17.39
195	22:59:00	28.3	139	3.63	17.27
195	23:00:00	27.5	121	3.85	16.95
195	23:01:00	27.2	125	4.05	16.75
195	23:02:00	29.9	152	4.14	16.72
195	23:03:00	30.4	199	4.11	16.54
195	23:04:00	27.9	146	3.79	16.95

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT3
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	23:05:00	25.6	133	3.81	17.07
195	23:06:00	28.8	164	4.17	16.81
195	23:07:00	30.6	242	4.23	16.46
195	23:08:00	28.9	170	3.91	16.82
195	23:09:00	27.0	139	3.97	16.86
195	23:10:00	29.2	170	4.21	16.72
195	23:11:00	30.5	243	4.25	16.42
195	23:12:00	29.0	157	3.66	17.07
195	23:13:00	26.2	125	3.90	17.01
195	23:14:00	28.6	163	4.10	16.85
195	23:15:00	30.7	235	4.47	16.29
195	23:16:00	28.6	210	4.29	16.41
195	23:17:00	27.3	185	4.07	16.69
195	23:18:00	29.1	168	3.88	16.98
195	23:19:00	30.5	178	3.90	16.85
195	23:20:00	28.0	136	3.98	16.80
195	23:21:00	26.1	137	3.77	16.98
195	23:22:00	28.6	125	3.77	17.12
195	23:23:00	30.2	157	3.90	16.81
195	23:24:00	27.6	119	3.67	17.03
195	23:25:00	26.5	118	3.89	16.96
195	23:26:00	28.0	134	4.10	16.77
195	23:27:00	31.2	230	4.52	16.27
195	23:28:00	29.7	217	4.38	16.31
195	23:29:00	28.9	220	4.51	16.27
195	23:30:00	30.0	216	4.34	16.46
195	23:31:00	32.6	248	4.00	16.71
195	23:32:00	28.9	156	3.96	16.76
195	23:33:00	26.9	158	4.12	16.66
195	23:34:00	28.1	151	4.13	16.75
195	23:35:00	30.6	224	4.14	16.57
195	23:36:00	30.5	150	3.66	17.04
195	23:37:00	26.2	124	3.79	17.06
195	23:38:00	26.6	131	3.99	16.92

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP10UT3
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
195	23:39:00	29.9	193	4.04	16.71
195	23:40:00	28.2	153	3.89	16.80
195	23:41:00	27.1	137	4.03	16.79
195	23:42:00	27.9	158	4.29	16.62
195	23:43:00	31.1	269	4.55	16.27
195	23:44:00	29.2	241	4.41	16.29
195	23:45:00	28.3	218	4.13	16.55
195	23:46:00	28.6	125	3.66	17.24
195	23:47:00	30.0	149	3.97	16.90
195	23:48:00	28.6	156	4.04	16.66
195	23:49:00	27.1	169	4.09	16.70
195	23:50:00	27.1	140	3.92	16.96
195	23:51:00	29.9	183	4.00	16.84
195	23:52:00	28.7	161	4.04	16.70
195	23:53:00	27.3	176	4.36	16.49
195	23:54:00	28.5	186	4.47	16.46
195	23:55:00	32.4	311	4.63	16.16
195	23:56:00	29.9	237	4.18	16.47
195	23:57:00	28.0	176	3.80	16.93
195	23:58:00	26.5	118	3.77	17.23
Run Average		28.9	174	4.08	16.71

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT4
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
196	00:49:00	29.7	148	4.18	16.47
196	00:50:00	28.6	108	3.49	17.12
196	00:51:00	28.5	73.4	3.27	17.51
196	00:52:00	29.6	68.2	3.25	17.61
196	00:53:00	30.6	81.5	3.54	17.22
196	00:54:00	27.5	77.5	3.68	17.07
196	00:55:00	26.4	86.9	3.72	17.02
196	00:56:00	27.6	91.4	3.68	17.18
196	00:57:00	29.3	108	3.78	16.93
196	00:58:00	27.6	85.5	3.59	17.12
196	00:59:00	27.2	76.6	3.51	17.27
196	01:00:00	28.2	79.8	3.54	17.33
196	01:01:00	29.5	101	3.82	16.93
196	01:02:00	28.6	87.0	3.53	17.16
196	01:03:00	27.0	76.3	3.48	17.30
196	01:04:00	27.8	76.9	3.62	17.28
196	01:05:00	29.0	113	4.03	16.77
196	01:06:00	27.3	116	3.94	16.75
196	01:07:00	27.0	96.3	3.56	17.16
196	01:08:00	29.0	80.7	3.39	17.47
196	01:09:00	32.3	87.6	3.42	17.34
196	01:10:00	27.6	71.9	3.54	17.27
196	01:11:00	25.4	90.7	3.83	16.95
196	01:12:00	27.4	102	3.82	17.00
196	01:13:00	29.6	117	3.90	16.80
196	01:14:00	27.5	91.9	3.56	17.08
196	01:15:00	28.0	72.9	3.33	17.46
196	01:16:00	27.3	68.9	3.32	17.61
196	01:17:00	29.6	94.8	3.50	17.29
196	01:18:00	28.7	74.5	3.38	17.32
196	01:19:00	28.0	75.2	3.44	17.34
196	01:20:00	26.2	73.8	3.66	17.29
196	01:21:00	28.2	133	4.00	16.73
196	01:22:00	26.2	111	3.70	16.99

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP1OUT4
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 1 Dryer RTO Outlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
196	01:23:00	25.9	111	3.72	17.06
196	01:24:00	28.2	96.1	3.49	17.33
196	01:25:00	31.8	92.8	3.43	17.39
196	01:26:00	28.8	84.4	3.52	17.14
196	01:27:00	28.5	75.8	3.49	17.36
196	01:28:00	26.1	87.9	3.91	17.03
196	01:29:00	27.8	146	3.90	16.80
196	01:30:00	28.0	98.2	3.53	17.10
196	01:31:00	28.9	79.7	3.26	17.49
196	01:32:00	30.8	59.1	2.96	17.90
196	01:33:00	31.9	72.6	3.38	17.46
196	01:34:00	28.4	79.8	3.55	17.13
196	01:35:00	27.3	80.1	3.60	17.20
196	01:36:00	25.9	86.0	3.68	17.19
196	01:37:00	29.1	120	3.83	16.93
196	01:38:00	26.9	105	3.83	16.83
196	01:39:00	28.6	91.3	3.33	17.35
196	01:40:00	27.8	64.1	3.32	17.59
196	01:41:00	30.4	90.2	3.49	17.28
196	01:42:00	28.5	78.6	3.51	17.17
196	01:43:00	27.1	79.8	3.55	17.22
196	01:44:00	26.2	73.3	3.53	17.35
196	01:45:00	28.9	111	3.75	17.02
196	01:46:00	28.0	96.7	3.69	16.97
196	01:47:00	26.6	95.8	3.75	17.00
196	01:48:00	26.3	89.5	3.73	17.11
196	01:49:00	29.7	120	3.61	17.18
196	01:50:00	28.1	97.9	3.61	17.06
196	01:51:00	27.0	92.6	3.66	17.10
196	01:52:00	26.0	91.3	3.80	17.10
196	01:53:00	29.7	139	3.70	16.96
196	01:54:00	30.1	90.4	3.36	17.29
Run Average		28.2	92.0	3.60	17.17

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP2OUT1
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	10:18:00	23.3	120	3.15	17.43
193	10:19:00	24.0	104	3.27	17.33
193	10:20:00	23.8	116	3.28	17.17
193	10:21:00	24.4	129	3.45	17.06
193	10:22:00	26.5	181	3.75	16.67
193	10:23:00	25.8	160	3.51	16.88
193	10:24:00	24.7	121	3.05	17.53
193	10:25:00	24.1	93.2	3.29	17.34
193	10:26:00	24.2	139	3.46	17.00
193	10:27:00	24.3	172	3.63	16.85
193	10:28:00	25.1	214	3.67	16.74
193	10:29:00	25.2	150	3.49	17.00
193	10:30:00	24.3	115	3.26	17.37
193	10:31:00	23.8	116	3.38	17.13
193	10:32:00	23.8	114	3.23	17.33
193	10:33:00	24.9	173	3.61	16.79
193	10:34:00	24.6	164	3.42	16.90
193	10:35:00	23.6	123	3.24	17.41
193	10:57:00	21.5	136	3.01	17.29
193	10:58:00	22.2	112	2.98	17.45
193	10:59:00	21.8	119	3.30	17.04
193	11:00:00	22.1	136	3.16	17.21
193	11:01:00	23.0	173	3.33	16.88
193	11:02:00	22.4	135	3.26	17.02
193	11:03:00	22.1	103	2.82	17.61
193	11:04:00	22.7	74.7	2.98	17.55
193	11:05:00	22.1	101	3.21	17.14
193	11:06:00	24.4	114	3.32	17.07
193	11:07:00	24.9	144	3.54	16.82
193	11:08:00	23.8	137	3.15	17.09
193	11:09:00	23.4	98.4	2.98	17.50
193	11:10:00	23.0	95.8	3.32	17.19
193	11:11:00	22.6	109	3.17	17.33
193	11:12:00	23.3	134	3.31	17.06

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP2OUT1
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	11:13:00	24.6	126	3.37	17.08
193	11:14:00	23.0	133	3.17	17.33
193	11:15:00	23.1	120	3.29	17.25
193	11:16:00	23.1	138	3.62	16.86
193	11:17:00	23.7	162	3.59	16.88
193	11:18:00	25.2	207	3.96	16.46
193	11:19:00	24.8	180	3.27	16.94
193	11:20:00	24.6	95.1	3.04	17.53
193	11:21:00	24.9	91.1	3.13	17.35
193	11:22:00	25.8	108	4.00	16.88
193	11:23:00	22.7	120	4.09	17.60
193	11:24:00	24.4	132	3.93	16.88
193	11:25:00	23.7	137	3.68	17.22
193	11:26:00	23.4	132	3.55	17.33
193	11:27:00	21.6	126	3.85	17.27
193	11:54:00	24.8	138	3.17	17.11
193	11:55:00	24.4	119	3.34	17.02
193	11:56:00	24.4	157	3.46	16.85
193	11:57:00	25.5	228	3.62	16.55
193	11:58:00	25.9	178	3.29	16.90
193	11:59:00	25.1	131	3.33	17.16
193	12:00:00	24.8	136	3.51	16.94
193	12:01:00	25.0	185	3.69	16.67
193	12:02:00	26.8	251	3.97	16.31
193	12:03:00	27.7	268	3.90	16.33
193	12:04:00	25.8	192	3.54	16.82
193	12:05:00	25.5	136	3.26	17.17
193	12:06:00	25.4	113	3.40	17.02
193	12:07:00	24.7	125	3.30	17.12
193	12:08:00	25.4	162	3.54	16.78
193	12:09:00	27.4	147	3.73	16.70
193	12:10:00	25.7	122	3.19	17.17
Run Average		24.2	140	3.41	17.07

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP2OUT2
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	13:06:00	24.5	108	3.11	17.37
193	13:07:00	24.5	156	3.54	16.89
193	13:08:00	22.7	163	3.22	17.15
193	13:09:00	22.8	225	3.24	17.18
193	13:10:00	25.0	152	3.45	16.93
193	13:11:00	25.6	108	3.24	17.09
193	13:12:00	24.2	115	3.23	17.25
193	13:13:00	24.3	143	3.42	16.98
193	13:14:00	24.8	190	3.57	16.85
193	13:15:00	26.6	215	3.25	17.06
193	13:16:00	25.9	130	3.45	16.89
193	13:17:00	23.6	95.8	3.04	17.45
193	13:18:00	24.0	110	3.36	17.23
193	13:19:00	23.4	132	3.28	17.15
193	13:20:00	23.5	202	3.48	17.15
193	13:21:00	24.9	240	3.72	16.62
193	13:22:00	24.9	129	3.21	17.26
193	13:23:00	24.5	131	3.41	17.07
193	13:24:00	24.1	109	3.42	17.13
193	13:25:00	24.1	147	3.60	16.91
193	13:26:00	26.1	216	3.87	16.59
193	13:27:00	27.3	208	4.01	16.35
193	13:28:00	26.1	141	3.67	16.89
193	13:29:00	25.1	157	3.57	16.92
193	13:30:00	24.7	113	3.03	17.45
193	13:31:00	21.2	126	3.20	17.46
193	13:32:00	25.6	114	2.91	17.53
193	13:33:00	25.1	60.1	3.34	17.23
193	13:34:00	24.5	99.3	3.32	17.22
193	13:35:00	23.8	121	3.84	16.81
193	13:36:00	23.8	178	3.91	16.55
193	13:37:00	25.1	266	4.11	16.34
193	13:38:00	24.9	230	3.91	16.51
193	13:39:00	23.8	169	3.52	17.07

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP2OUT2
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	13:40:00	23.1	105	3.10	17.51
193	13:41:00	22.5	80.1	3.25	17.32
193	13:42:00	24.7	94.8	3.28	17.26
193	13:43:00	24.6	148	3.75	16.79
193	13:44:00	25.6	143	3.69	16.76
193	13:45:00	25.1	134	3.68	16.90
193	13:46:00	24.2	137	3.93	16.68
193	13:47:00	23.9	158	3.91	16.60
193	13:48:00	24.5	216	3.82	16.72
193	13:49:00	25.2	197	3.96	16.53
193	13:50:00	23.7	143	3.48	17.10
193	13:51:00	24.1	102	3.11	17.48
193	13:52:00	23.5	78.0	3.50	17.20
193	13:53:00	23.4	130	3.63	16.90
193	13:54:00	23.5	165	3.84	16.64
193	13:55:00	23.5	150	3.61	16.95
193	13:56:00	24.9	141	3.85	16.77
193	13:57:00	23.3	125	3.71	16.89
193	13:58:00	23.2	139	3.75	16.80
193	13:59:00	25.5	174	3.81	16.66
193	14:00:00	26.1	176	3.91	16.60
193	14:01:00	25.3	139	3.76	16.79
193	14:02:00	24.7	144	3.77	16.84
193	14:03:00	23.6	136	3.81	16.81
193	14:04:00	22.7	164	3.85	16.78
193	14:05:00	23.8	226	3.90	16.58
193	14:06:00	24.3	184	3.88	16.58
193	14:07:00	24.8	126	3.42	17.23
193	14:08:00	23.5	117	3.58	17.06
193	14:09:00	23.5	128	3.60	16.98
193	14:10:00	23.6	182	3.89	16.68
Run Average		24.3	149	3.56	16.95

Interpoll Laboratories, Inc.

(612) 786-6020

Printout of ESC Model 80 DAS

for CEM Trailer No. 2

- 1994 -

File Name: LP2OUT3

Job Number: 4-3366

Client: Louisiana Pacific Corporation

Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	15:01:00	25.1	244	3.92	16.52
193	15:02:00	24.8	168	3.80	16.69
193	15:03:00	23.9	148	3.44	17.10
193	15:04:00	23.1	113	3.51	17.13
193	15:05:00	22.5	129	3.45	17.12
193	15:06:00	23.2	189	3.59	16.90
193	15:07:00	23.7	160	3.61	16.90
193	15:08:00	22.9	131	3.23	17.30
193	15:09:00	22.9	108	3.46	17.17
193	15:10:00	22.0	108	3.33	17.19
193	15:11:00	22.8	135	3.56	17.01
193	15:12:00	24.0	182	3.75	16.66
193	15:13:00	24.3	144	3.52	16.85
193	15:14:00	22.8	119	3.17	17.42
193	15:15:00	22.5	105	3.47	17.14
193	15:16:00	21.9	110	3.30	17.28
193	15:17:00	22.2	152	3.49	17.02
193	15:18:00	23.2	172	3.59	16.80
193	15:19:00	21.7	114	3.11	17.42
193	15:20:00	21.9	101	3.19	17.36
193	15:21:00	21.9	83.5	3.30	17.29
193	15:22:00	22.7	136	3.38	17.07
193	15:23:00	25.4	151	3.48	16.93
193	15:24:00	24.3	139	3.65	16.78
193	15:25:00	24.1	137	3.10	17.39
193	15:26:00	22.4	100	3.42	17.28
193	15:27:00	21.4	134	3.30	17.16
193	15:28:00	22.0	163	3.65	16.93
193	15:29:00	23.5	215	3.39	16.95
193	15:30:00	23.5	119	3.21	17.33
193	15:31:00	22.8	121	3.13	17.36
193	15:32:00	23.3	106	3.30	17.29
193	15:33:00	22.1	175	3.54	16.91
193	15:34:00	23.5	224	3.57	16.85

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP2OUT3
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	15:35:00	23.7	195	3.68	16.70
193	15:36:00	22.3	138	3.12	17.40
193	15:37:00	22.1	99.9	3.14	17.50
193	15:38:00	22.2	118	3.36	17.12
193	15:39:00	23.3	142	3.36	17.17
193	15:40:00	23.1	222	3.75	16.68
193	15:41:00	24.3	162	3.09	17.25
193	15:42:00	23.1	108	3.27	17.42
193	15:43:00	22.8	139	3.33	17.05
193	15:44:00	22.6	108	3.33	17.31
193	15:45:00	24.0	186	3.51	16.85
193	15:46:00	25.0	153	3.53	16.83
193	15:47:00	23.2	142	3.44	17.08
193	15:48:00	22.9	129	3.35	17.20
193	15:49:00	22.9	135	3.59	16.92
193	15:50:00	23.0	179	3.26	17.14
193	15:51:00	23.4	160	3.53	17.05
193	15:52:00	23.3	172	3.25	16.98
193	15:53:00	22.8	101	3.21	17.49
193	15:54:00	22.0	126	3.28	17.17
193	15:55:00	22.7	113	3.20	17.33
193	15:56:00	23.9	189	3.75	16.68
193	15:57:00	24.8	193	3.39	16.95
193	15:58:00	22.4	130	3.28	17.20
193	15:59:00	22.9	110	3.13	17.49
193	16:00:00	23.0	132	3.53	16.99
193	16:01:00	23.1	172	3.44	16.99
193	16:02:00	23.8	176	3.54	16.96
193	16:03:00	23.9	176	3.67	16.71
193	16:04:00	23.9	140	3.31	17.27
193	16:05:00	23.2	140	3.69	16.89
193	16:06:00	22.9	150	3.39	17.07
193	16:07:00	24.8	220	4.00	16.47
193	16:08:00	26.1	265	3.93	16.40

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 2
- 1994 -

File Name: LP2OUT3
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Dryer RTO Outlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	16:09:00	24.5	157	3.36	17.08
193	16:10:00	24.0	135	3.59	16.98
193	16:11:00	23.6	135	3.40	17.07
Run Average		23.2	148	3.43	17.06

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP31
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	10:18:00	24.0	357	3.55	16.80
193	10:19:00	24.4	290	3.63	16.76
193	10:20:00	22.8	297	3.72	16.73
193	10:21:00	23.4	360	3.69	16.76
193	10:22:00	24.6	411	3.79	16.65
193	10:23:00	25.9	688	3.90	16.41
193	10:24:00	25.8	560	3.84	16.49
193	10:25:00	24.1	402	3.70	16.72
193	10:26:00	24.8	446	3.97	16.45
193	10:27:00	24.7	558	3.78	16.63
193	10:28:00	25.5	484	3.87	16.54
193	10:29:00	26.2	500	3.61	16.81
193	10:30:00	26.8	570	3.61	16.69
193	10:31:00	28.8	380	3.65	16.64
193	10:32:00	27.1	343	3.30	16.97
193	10:33:00	23.7	318	2.70	17.51
193	10:34:00	19.8	229	2.10	18.09
193	10:35:00	17.1	196	1.74	18.54
193	10:36:00	14.8	146	1.48	18.89
193	10:37:00	12.7	135	1.29	19.14
193	10:38:00	11.2	105	1.10	19.37
193	10:39:00	11.0	98.3	1.05	19.45
193	10:40:00	16.0	163	1.50	18.88
193	10:41:00	6.1	134	0.51	20.08
193	10:42:00	3.5	23.1	0.46	20.24
193	10:43:00	4.5	61.1	1.43	19.43
193	10:44:00	13.8	381	2.99	17.43
193	10:45:00	18.4	368	3.59	16.89
193	10:46:00	23.2	457	3.71	16.73
193	10:47:00	23.6	485	3.54	16.93
193	10:48:00	25.7	369	3.32	17.12
193	10:49:00	24.0	382	3.54	16.83
193	10:50:00	24.5	348	3.69	16.75
193	10:51:00	23.7	325	3.73	16.70

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP31
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	10:52:00	25.4	315	3.72	16.72
193	10:53:00	25.7	292	3.69	16.76
193	10:54:00	26.3	291	3.76	16.71
193	10:55:00	25.3	298	3.64	16.85
193	10:56:00	28.2	419	3.75	16.61
193	10:57:00	27.0	390	3.82	16.57
193	10:58:00	26.6	337	3.76	16.63
193	10:59:00	25.8	297	3.65	16.83
193	11:00:00	26.5	375	3.83	16.58
193	11:01:00	26.4	292	3.81	16.67
193	11:02:00	26.5	349	3.76	16.69
193	11:03:00	26.5	320	3.62	16.79
193	11:04:00	26.8	232	3.62	16.86
193	11:05:00	26.5	290	3.72	16.72
193	11:06:00	27.6	303	3.57	16.83
193	11:07:00	25.8	349	3.82	16.62
193	11:08:00	27.1	370	4.03	16.45
193	11:09:00	24.6	404	3.33	16.85
193	11:10:00	16.0	208	1.50	19.22
193	11:11:00	22.3	353	3.46	17.10
193	11:12:00	23.2	312	3.43	17.06
193	11:13:00	25.8	353	3.65	16.82
193	11:14:00	28.1	470	3.86	16.55
193	11:15:00	28.6	383	3.82	16.63
193	11:16:00	27.3	467	3.33	16.94
193	11:17:00	24.2	303	2.73	17.60
193	11:18:00	19.2	308	1.70	18.57
193	11:19:00	8.0	64.8	0.76	20.01
193	11:20:00	10.9	150	2.39	18.41
193	11:21:00	14.6	223	3.02	17.48
193	11:22:00	17.3	213	3.47	17.10
193	11:23:00	19.7	302	3.50	17.02
193	11:24:00	22.4	339	3.83	16.66
193	11:25:00	25.4	467	4.05	16.40

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP31
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	11:26:00	27.5	498	4.06	16.37
193	11:27:00	27.1	485	4.06	16.43
193	11:28:00	28.3	527	4.00	16.47
193	11:29:00	27.7	462	4.05	16.46
193	11:30:00	28.7	534	3.97	16.48
193	11:31:00	28.3	467	4.03	16.44
193	11:32:00	18.7	298	1.67	18.70
193	11:33:00	19.2	398	3.77	16.96
193	11:34:00	19.8	381	3.69	16.89
193	11:35:00	22.9	439	3.83	16.77
193	11:36:00	24.0	630	3.94	16.54
193	11:37:00	25.3	663	3.91	16.50
193	11:38:00	26.1	501	3.99	16.44
193	11:39:00	27.2	488	4.17	16.34
193	11:40:00	27.8	551	4.14	16.39
193	11:41:00	28.6	870	4.24	16.19
193	11:42:00	29.8	767	4.28	16.17
193	11:43:00	29.9	717	4.10	16.35
193	11:44:00	28.2	2.0	4.16	16.33
193	11:45:00	27.8	567	4.03	16.50
193	11:46:00	26.6	495	3.99	16.61
193	11:47:00	26.3	645	4.08	16.43
193	11:48:00	26.0	610	4.02	16.45
193	11:49:00	26.3	491	4.31	16.29
193	11:50:00	27.3	764	4.36	16.19
193	11:51:00	28.0	751	4.08	16.44
193	11:52:00	28.1	734	4.36	16.13
193	11:53:00	28.3	744	4.30	16.19
193	11:54:00	28.0	646	4.06	16.51
193	11:55:00	27.7	662	4.10	16.43
193	11:56:00	28.0	613	4.12	67.58
193	11:57:00	28.0	473	4.12	16.48
193	11:58:00	28.8	637	4.26	16.33
193	11:59:00	28.6	808	4.16	16.34

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP31
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 1

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	12:00:00	28.5	625	4.17	16.37
193	12:01:00	28.5	618	4.34	16.25
193	12:02:00	28.7	854	4.13	16.35
193	12:03:00	29.3	670	4.38	16.18
193	12:04:00	29.1	722	4.14	16.46
193	12:05:00	28.6	667	4.05	16.50
193	12:06:00	27.7	515	3.97	16.64
Run Average		24.0	424	3.49	17.45

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP32
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	13:04:00	18.6	691	4.06	16.66
193	13:05:00	19.6	810	4.08	16.66
193	13:06:00	21.1	938	4.12	16.58
193	13:07:00	23.2	848	4.46	16.27
193	13:08:00	23.0	786	3.98	16.73
193	13:09:00	24.1	787	4.10	16.61
193	13:10:00	22.9	572	3.80	17.06
193	13:11:00	22.8	505	3.98	16.87
193	13:12:00	22.8	717	4.00	16.80
193	13:13:00	25.0	736	4.33	16.45
193	13:14:00	26.8	913	4.63	16.23
193	13:15:00	25.9	962	4.18	16.56
193	13:16:00	25.8	872	4.15	16.63
193	13:17:00	24.7	641	3.86	17.07
193	13:18:00	25.5	702	4.30	16.56
193	13:19:00		778	4.22	16.70
193	13:20:00	26.5	936	4.58	16.24
193	13:21:00	26.1	*-9999.0	4.56	16.25
193	13:22:00	24.0	772	4.01	16.86
193	13:23:00	26.0	721	4.43	16.45
193	13:24:00	25.3	695	4.26	16.74
193	13:25:00	26.2	876	4.44	16.46
193	13:26:00	25.4	999	4.63	16.29
193	13:27:00	25.7	*-9999.0	4.98	15.96
193	13:28:00	25.8	*-9999.0	5.03	15.89
193	13:29:00	25.8	*-9999.0	4.61	16.24
193	13:30:00	24.0	896	4.21	16.69
193	13:31:00	22.1	584	3.98	17.00
193	13:32:00	22.1	486	3.90	17.10
193	13:33:00	22.2	328	3.90	17.21
193	13:34:00	22.3	515	4.36	16.69
193	13:35:00	23.6	924	4.68	16.33
193	13:36:00	24.2	1050	4.90	16.09
193	13:37:00	16.3	*-9999.0	2.68	17.91

* Please note: The negative numbers are numbers that went off scale. They were not included in the average.

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP32
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 2

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	13:38:00	20.3	421	3.53	18.36
193	13:39:00	26.8	%-9999.0	4.74	16.16
193	13:40:00	23.7	819	3.93	17.07
193	13:41:00	22.7	356	3.96	17.17
193	13:42:00	22.7	441	4.08	17.03
193	13:43:00	24.1	666	4.65	16.42
193	13:44:00	24.2	941	4.77	16.29
193	13:45:00	24.9	1026	5.04	16.04
193	13:46:00	25.4	%-9999.0	5.07	16.00
193	13:47:00	26.2	%-9999.0	5.05	15.99
193	13:48:00	26.0	%-9999.0	4.95	16.12
193	13:49:00	25.7	1070	4.78	16.29
193	13:50:00	24.7	1040	4.52	16.50
193	13:51:00	23.5	669	4.10	17.02
193	13:52:00	23.3	460	4.27	16.92
193	13:53:00	23.1	659	4.35	16.74
193	13:54:00	22.8	543	4.25	16.90
193	13:55:00	23.3	620	4.59	16.58
193	13:56:00	24.8	821	4.74	16.39
193	13:57:00	23.9	933	4.76	16.39
193	13:58:00	22.9	995	4.79	16.33
193	13:59:00	23.4	934	4.80	16.35
193	14:00:00	23.3	986	4.83	16.33
193	14:01:00	23.1	986	4.85	16.35
193	14:02:00	22.5	1057	4.87	16.27
193	14:03:00	22.2	1062	4.83	16.35
193	14:04:00	22.8	1039	4.76	16.38
193	14:05:00	22.3	1001	4.72	16.42
193	14:06:00	22.3	981	4.79	16.38
193	14:07:00	22.5	999	4.72	16.48
193	14:08:00	22.4	1006	4.82	16.36
193	14:09:00	22.5	1046	4.84	16.34
193	14:10:00	23.4	1049	4.78	16.41
Run Average		23.7	> 831	4.43	16.57

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP33
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	15:01:00	16.4	603	4.08	16.67
193	15:02:00	17.1	625	4.16	16.56
193	15:03:00	16.7	690	4.02	16.65
193	15:04:00	16.9	511	4.08	16.71
193	15:05:00	17.2	730	4.14	16.55
193	15:06:00	18.0	688	4.23	16.45
193	15:07:00	18.0	659	3.94	16.86
193	15:08:00	19.2	756	3.96	16.58
193	15:09:00	17.9	452	3.91	16.98
193	15:10:00	17.8	516	3.61	17.18
193	15:11:00	17.5	381	3.86	16.87
193	15:12:00	17.5	419	3.81	17.02
193	15:13:00	18.0	414	3.98	16.84
193	15:14:00	17.5	558	3.87	16.87
193	15:15:00	17.2	431	3.89	16.94
193	15:16:00	17.8	496	3.86	16.93
193	15:17:00	18.0	508	3.76	16.97
193	15:18:00	18.8	416	4.06	16.77
193	15:19:00	17.8	529	3.56	17.23
193	15:20:00	17.6	281	3.58	17.24
193	15:21:00	17.5	284	3.64	17.27
193	15:22:00	17.6	451	3.75	16.91
193	15:23:00	18.1	417	3.95	16.93
193	15:24:00	19.1	606	4.06	16.70
193	15:25:00	19.3	657	4.03	16.67
193	15:26:00	19.1	584	3.79	16.96
193	15:27:00	19.2	516	50.68	16.80
193	15:28:00	19.7	521	3.93	16.89
193	15:29:00	19.9	705	3.96	16.67
193	15:30:00	20.1	541	4.00	16.75
193	15:31:00	19.5	652	3.81	16.90
193	15:32:00	20.0	512	4.01	16.80
193	15:33:00	16.8	707	3.36	16.90
193	15:34:00	8.8	316	0.40	21.03

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP33
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	15:35:00	17.0	298	3.92	17.10
193	15:36:00	18.7	514	3.77	17.07
193	15:37:00	18.3	440	3.61	17.16
193	15:38:00	18.5	359	3.81	17.03
193	15:39:00	19.0	477	3.97	16.85
193	15:40:00	19.5	695	4.13	16.58
193	15:41:00	20.2	755	4.12	16.58
193	15:42:00	20.0	677	3.90	16.84
193	15:43:00	20.6	569	4.03	16.68
193	15:44:00	21.0	527	3.50	17.37
193	15:45:00	19.6	461	3.54	17.22
193	15:46:00	20.0	392	3.95	16.82
193	15:47:00	20.0	567	3.89	16.83
193	15:48:00	19.9	539	4.02	16.82
193	15:49:00	20.5	662	4.07	16.67
193	15:50:00	20.3	725	4.06	16.63
193	15:51:00	20.4	606	3.87	16.98
193	15:52:00	21.2	729	4.09	16.55
193	15:53:00	20.7	488	3.62	17.29
193	15:54:00	19.5	502	3.64	17.08
193	15:55:00	20.3	444	3.93	16.84
193	15:56:00	21.0	537	3.98	16.84
193	15:57:00	21.0	662	4.01	16.70
193	15:58:00	20.7	611	4.02	16.72
193	15:59:00	20.6	591	3.89	16.94
193	16:00:00	20.9	724	4.16	16.52
193	16:01:00	20.7	752	4.13	16.58
193	16:02:00	19.8	643	3.85	16.97
193	16:03:00	20.4	583	3.93	16.85
193	16:04:00	20.6	661	4.16	16.55
193	16:05:00	19.8	715	3.90	16.87
193	16:06:00	19.9	575	3.83	16.96
193	16:07:00	21.0	601	4.33	16.46
193	16:08:00	21.1	1001	4.19	16.54

Interpoll Laboratories, Inc.
(612) 786-6020

Printout of ESC Model 80 DAS
for CEM Trailer No. 1
- 1994 -

File Name: LP33
Job Number: 4-3366
Client: Louisiana Pacific Corporation
Location: Hayward, Wisconsin

Line 2 Core Dryer RTO Inlet -- Run 3

Julian Date	Time (Hrs)	Conc. (dry basis unless noted)			
		NOx (ppmv)	CO (ppmv)	CO2 (%v/v)	O2 (%v/v)
193	16:09:00	21.0	903	4.04	16.60
193	16:10:00	20.6	606	3.89	17.02
Run Average		19.0	567	4.54	16.90

Core →


← Surface

← Core


Surface →

LP-Hayward
Line 1 Surface Dyer
Line 1 Core Dyer
(Alets)

THC's



Surface = red
Core = purple




LP-Hayward
 Line 1 Core Dye
 Line 1 Surface Dye

THC's

End Run 2

Surface System 1204




Core →

← Surface

Run 2 Start →

LP- Hayward
Final Core Dye
Line / Surface Dye
THC's



Surface
PPT


← CORE

JP-Hayward
Line 1 Core PPT
Line 1 Surface PPT
(Polets)

THC's

CHART NO. 44407-00

NOCTWELL



JP Hayward

TAC's →

*Line 1 Orger
RTD output
TAC's*


TAC's

FL-36

CHART NO. 4046707-008

INCHES

CHART NO. 4046707-008



LP
Hayward
Scale 0-100

Line Paper
RTO Outlet

THC's

Fill at plug

ARRIHT INHIBIT MODE

CC

CC


CC

CC


CHART NO. 4486707-04

CONTROL

CHART NO. 4486707-08 TEL



THC




J.P. Hayward
TAC's
Line 1 Paper Outlet

Run No. 2 1010 hrs

4 13 11 00	15 JUL 1954	PRINT INHIBIT MODE	1		
4 13 05 00	15 JUL 1954	PRINT INHIBIT MODE	100	10 HOUR	PPM
4 13 03 00	15 JUL 1954	PRINT INHIBIT MODE	100	10 HOUR	PPM
4 12 53 00	15 JUL 1954	PRINT INHIBIT MODE	100	10 HOUR	PPM


10
17
TK



Run No. 3 1455 145

1	14	40	14	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70
2	14	40	14	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70
3	14	40	14	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70
4	14	33	00	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70
5	14	33	00	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70
6	14	26	00	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70
7	14	26	00	15	JUL	1954	PRINT INHIBIT MODE	100	PAPER	70

SYSTEM DATA No. 4




L.P. Hayward
THC 5

NO. 1 Oxygen RTD output

10021001

CHART NO. 44887-02



SP Hybrid
No. 1 Oxygen Outlet

THC's →

Run No. 3 *44887-02*

4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70
4-14-40-00	15 JUL 1994	PRINT	INHIBIT MODE	100	NOX	PAPER	70

F-41


13	00	00	15	JUL	1994	PRINT INHIBIT MODE	PPM	100.0
14	00	00	17	JUL	1994	PRINT INHIBIT MODE	PPM	100.0
15	00	00	20	JUL	1994	PRINT INHIBIT MODE	PPM	100.0
16	00	00	21	JUL	1994	PRINT INHIBIT MODE	PPM	100.0
17	00	00	25	JUL	1994	PRINT INHIBIT MODE	PPM	100.0

SYSTEM DIAS No. 5

GP Hayward

NO 1 Experiment

THC's →



THC

Row No. 1 1820 HRS

0 20 40 60 80 100

SURFACE

301 ppm

CORE SYSTEM NO. 2

1 meter

0 20 40 60 80 100

Row No. 1 1735

0 20 40 60 80 100

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

0 20 40 60 80 100

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm

301 ppm


CHART NO. B355AW NN

Scale

J.P. Hayward
Line 2 Core Dye
Line 2 Surface Dye
(Inlets)

L.P. HAYWARD LINE NO. 2
CORE & SURFACE OUTFEEDS

THIC AS PROGRAM



Run!
End →


Line 2
Surface
Angle
Sheet

Line 2
Core
Sheet

Run!
Start →

LP Hayward
TFC's
Scale 0-1000

Run 2
End →




YP-Hayward
TAC's

Line 2 Core Dye
Line 2 Surface Dye

Year 3
End →

Surface →

Year 3
Start →



LP Hayward

Line 2 Core
(Inlet)

Line 2 Surface
(Inlet)

THC'S

CONTROL

UNIT NO. 462707-00

CONTROL

2/2

0.00 10.00

2/1

2/3

2/2

2/1

1/3

1/2

1/1

0.00 10.00

LP Hayward
Line 2 R/W outlet

0.00 10.00

THC'S

THC'S

THC

THC'S

THC'S

THC'S

THC'S

PPM 100.0

PPM 500

PPM 100

PPM 100.0

PPM 500

PPM 100

PPM 100.0

PPM 500

1045722

(CD) THC PPM 100.0

Run No 2 2005 HRS

13 JUL 1994 PRINT INHIBIT MODE

3.1 PM

13 JUL 1994 PRINT INHIBIT MODE

ZERO

System Run No. 3

13 JUL 1994 PRINT INHIBIT MODE

Run 1 End

(CD) PPM 100.0

JP Hayward
No. 2 RTB Outlet

THC'S

Range 1000

(CD) THC PPM 100.0

2/3

2/2

2/1

2/3

2/2

2/1

20.00


F-48

(CD) PPM 100.0

CHART NO. 482870-00

INSTRUMENT

GAUGE NO. 4452707-08



L.P. Hayward
Lab. 2 210 outlet

THC'S

POST T.H.C.S.

THC'S

CONTROL

CHART NO. 448707-00

CONTROL

Run No. 3 2146 HR

12 JUL 1954 PRINT INHIBIT MODE 31 PPT 500

ZERO

SYSTEM ORN No. 4

End June 2

THC PPM 100.0

DL 00 SEP 20.00

THC PPM 500

THC'S

JP Hayward
Line ERTO output

THC PPM 100.0

THC PPM 100.0


DL 00 SEP 20.00

THC PPM 500

F-50

PORTWELL

CHART NO. 4848703-002




*YP Hayward
Line No. 2 RTO outlet*

Run No. 3-214-100

12 JUL 1954 PRINT INHIBIT NONE (4) PPM 500


F-51

PORTWELL



APPENDIX G

ANALYZER SPECIFICATIONS



Servomex

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1420
Oxygen Analyser
Instruction Manual

Ref : 01420/001A/0

Order as part No. 01420001A

was (7982-2842)

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1.3 Sampling System

The sampling system of the analyser includes a combination filter/automatic flow control device, designed to keep a constant flow of sample gas through the measuring cell for varying input pressures and to prevent the entrance of particulate matter into the measuring cell. Excess flow is vented to the by-pass.

1.4 Specification

Performance Specification (typical)

Repeatability: Better than $\pm 0.2\%$ O₂ under constant conditions.

Drift: Less than 0.2% O₂ per week under constant conditions. (Excluding variation due to barometric pressure changes; reading is proportional to barometric pressure.)

Outputs

Display: 3 1/2 digit LCD reading 0.0 to 100.0% oxygen with overrange capability.

Output: 0 to 1V (non-isolated) for 0 to 100% oxygen available on 'D' type connector located on the back panel of the instrument. Output impedance is less than 10 ohms.

Option: 4 - 20mA isolated, Max impedance 500 ohms.

Flow alarm output: Change over relay contact rated at 3A/115V ac, 1A/240V ac or 1A/28V dc. 4 sets of single pole changeover contacts. Alarm becomes active when sample gas flow through the analyser fails.

Sample requirements

Condition: Clean, dry gas with dew point 5 deg C below ambient temperature.

Inlet pressure: 0.5 to 3psig (3.5 to 21kPa). Inlet pressure changes within this range will change the reading by less than 0.1% O₂. May be operated up to 10psig (70kPa) with degraded stability.

Flowrate: 1.5 to 6 litres/minute approximately depending on sample pressure.

Filtering: 0.6 micron replaceable filter integral to the automatic flow control device.

Response time: Less than 15 secs. to 90% at an inlet pressure of 3psig (21kPa).

Inlet/vent connections: 1/4 inch OD tube (stainless steel) suitable for 6mm ID flexible tubing or 1/4 inch OD compression fittings.

Materials exposed to the sample: Stainless steel, Pyrex glass, brass, platinum, epoxy resin, Viton, polypropylene and glass fibre filter.

Physical Characteristics

Case: Steel and aluminium finished in epoxy powder paint.

Case classification: IP 20 (IEC 529) when fitted into the Servomex 1400 series 19 inch case.

Dimensions: See Figure 2.1.

Weight: 10Kg (22lb) approximately.

Electrical

AC Supply: 110 to 120V AC or 220 to 240V AC, +/-10%, 48 to 62Hz. Voltage selected by a voltage selector integral to the IEC supply plug.

Power required: 15VA maximum.

Environmental Limits

Operating ambient temperature: 0 to +40 deg C (32 to 104 deg F)

Storage temp. range: -20 to +70 deg C (-4 to 158 deg F)

Relative humidity: 0-85%, non-condensing.

SPECIFICATIONS FOR ACS MODEL 3300 CO₂ NDIR

Measuring principle	NDIR single beam method
Measurable gas components and measuring range	0 - 20%
Reproducibility	±0.5% of full scale
Stability	Zero drift; ±% of full scale/24H Span drift; ±% of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500Ω max.)
Linearity	Better than ±2% of full scale (when linearizer is used)
Power supply	AC 115 V ± 10%, 60 Hz

Power consumption	Approx. 30 VA
Materials of gas-contacting parts	Measuring cell; SUS304 Window; CaF ₂ Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.

SPECIFICATIONS FOR MODEL 10A
ROCK MOUNTED CHEMILUMINESCENT
NO-NO_x GAS ANALYZER

Sensitivity	Each instrument is equipped with the following ranges: 0 - 2.5 ppm 0 - 10 ppm 0 - 25 ppm 0 - 100 ppm 0 - 250 ppm 0 - 1000 ppm 0 - 2500 ppm 0 - 10000 ppm
Accuracy	Derived from the NO or NO ₂ calibration gas, ±1% of fullscale
Response time (0-90%) Typical	1.5 seconds - NO Mode 1.7 seconds - NO _x Mode
Output	0 - 10mV and 0 - 10V
Zero Drift	Negligible after 1/2-hour warm-up
Linearity	±1% of full scale
Input Power Requirements	115v/50Hz; 115v/60Hz



TECHNICAL DATA

MAINS : 115V/60H

RECORDER OUTPUT : 0 - 5 V / 4 - 20mA

MODEL: Manual switching
 Solenoid valves

HOUSING: Case, 19" - Rack

MEASURING RANGES:	1 = 0 - 10	C ₁
	2 = 0 - 100	C ₁
	3 = 0 - 1,000	C ₁
	4 = 0 - 10,000	C ₁

SPECIAL OPTIONS :

- Flame out alarm
- 1 Alarm
- Sample line
-

ANALYZER CONDITIONS :

Temperature : ..160.°C


Zero Point : ..3,90...


Gain :7,70.....

Pressure Setting: Sample/Spangas/Zerogas : 200 mbar
 Fuel: Hydrogen :0,35 bar
 Combustion Air :0,80 bar

Span Gases : ..300. ppm C₁
 24.000. ppm C₁


CALIBRATION DIAGRAMM





- 1 Druckregler
pressure regulator
- 2 Manometer
- 3 Filter
- 4 Magnetventil/
Magnetic valve
- 5 3 Wege Ventil/
3 way valve
- 6 Kapillare
capillary
- 7 Magnetventil/
Magnetic valve
- 8 Pumpe
pump
- 9 Druckregler
pressure regulator

- Zündventil/
Ignition valve
- P-A angezogen
energized
- R-A Stromlos
at rest




FLAMMEN IONISATIONS DETEKTOR
Flame Ionization Detector

Fließplan
Flow diagram


RS 55
13.04.88 dr

Handumkehrung
Manual switching



APPENDIX H

MEASUREMENT SYSTEMS PERFORMANCE SPECIFICATIONS



INTERPOLL LABORATORIES, INC.
 (612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAYWARD
 Source LINE No. 2 DRYER RTO OUTLET
 Test 1 Run Date 7-12-94
 Stack Dimen. _____ IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 28.70 IN.HG
 Static Pressure _____ IN.WC
 Operators Don Rosenthal
 Pitot No. C. 840

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start:	HRS
1	.4m				
2	1.2m				
3	2.0m				
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
 (612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAYWARD 3366
 Source LINE No. 2 DRYER RTO OUTLET
 Test 4 Run Date 7-12-94
 Stack Dimen. _____ IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure _____ IN.HG
 Static Pressure _____ IN.WC
 Operators _____
 Pitot No. _____ C_p _____

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: _____ IN.	Time Start: _____ HRS		
1	.4m				
2	1.2m				
3	2.0m				
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAYWARD 3366
 Source LINE No. 2 SURFACE DRYER OUTLET
 Test S Run 42 Date 7-12-94
 Stack Dimen. _____ IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure _____ IN.HG
 Static Pressure _____ IN.WC
 Operators _____
 Pitot No. _____ C_p _____

Cross-section View	Elevation View
--------------------	----------------

W/G Channel No. 1

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4</u> IN.		Time Start: _____ HRS	
<u>1</u>	<u>1/6</u>	<u>7.00</u>	<u>11.00</u>		
<u>2</u>	<u>3/6</u>	<u>21.00</u>	<u>25.00</u>		
<u>3</u>	<u>5/6</u>	<u>35.00</u>	<u>39.00</u>		
Temp. Meas. Device & S/N:				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAYWARD 3366
 Source LINE No. 2 COPE DRYER OUTLET
 Test 6 Run Date 7-12-94
 Stack Dimen. 42 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure _____ IN.HG
 Static Pressure _____ IN.WC
 Operators _____
 Pitot No. Cp



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length: <u>4</u> IN.		Time Start:	HRS
<u>1</u>	<u>1/6</u>	<u>7.00</u>	<u>11.00</u>		
<u>2</u>	<u>2/6</u>	<u>21.00</u>	<u>25.00</u>		
<u>3</u>	<u>5/6</u>	<u>35.00</u>	<u>39.00</u>		
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.
 (612) 786-6020
 EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/HAYWARD 3366
 Source LINE No. 1 DRYER R70 OUTLET
 Test 14 Run Date 7-14-94
 Stack Dimen. 8.5 IN.
 Dry Bulb °F Wet bulb °F
 Manometer Reg. Exp Elec.
 Barometric Pressure IN.HG
 Static Pressure IN.WC
 Operators R.R.
 Pitot No. C_p

Cross-section View	Elevation View
-----------------------	-------------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
1		Port Length: <u>6.25</u> IN.		Time Start: _____ HRS	
1	1/6	13.58	19.83		
2	7/6	40.75	47.00		
3	5/6	67.92	74.17		
Temp. Meas. Device & S/N: _____				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES

Calibration Error Check

Job LP/HAYWARD 3366

Test 1 Run Date 7-12-94

Operator R.Ro

CO
SO₂ Calibration: Time (HRS) 730

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	1	1	500	.2
Mid level	150.5	151	1	500	.2
High level	300.8	303	3	500	.6

NO_x Calibration: Time (HRS) 730

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	250	0
Mid level	50.5	52	1.5	250	.45
High level	140.5	140	1.5	250	.45

23103

O₂ Calibration: Time (HRS) 730

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	25	.0
Mid level	13.5	13.5	0	25	0
High level	21.0	21.0	0	25	0

CO₂ Calibration: Time (HRS) 730

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	.1	.1	20	.5
Mid level	11.1	10.95	.2	20	1.0
High level	17.0	16.8	.2	20	1.0

Must be within 2% of the span for each calibration gas

S-420-10

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO System Bias Check

3366

Job
Test
Operator

CP/HAYWARD
1 Run Date 7-12-94
R.R.

Source LINE No. 2 DRYER RTO
Site OUTLET

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	150	1	500	.2
2	910	Zero Gas	0	1	1	0	500	0
		Upscale	150.5	151	149	2	500	.4
3	1215	Zero Gas	0	1	1	0	500	0
		Upscale	150.5	151	148	3	500	.6
4	1415	Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	149	2	500	.4
5	1615	Zero Gas	0	1	1	0	500	0
		Upscale	150.5	151	149	2	500	.2
6		Zero Gas	0					
		Upscale						
7	I.G.S PRETEST	Zero Gas	0		1			
		Upscale			154			
8	I.G.S POSTEST	Zero Gas	0		1			
		Upscale			152			
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

RUN TIME

1000
1214
1305
1412

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

NO_x System Bias Check

3366

Job LP/HAYWARD Source L2NE No. 2
 Test 1 Run Date 7-12-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	0	1	1	100	1
		Upscale	50.5	52	51	1	100	1
2	910	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	51	1	100	1
3	1215	Zero Gas	0	0	2	2	100	2
		Upscale	50.5	52	54	2	100	2
4	1415	Zero Gas	0	0	2	2	100	2
		Upscale	50.5	52	52	0	100	0
5	1615	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	52	0	100	0
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

O₂ System Bias Check 3366

Job LP/HAYWARD Source LINE No. 2 DRYER R
 Test 1 Run 1 Date 7-12-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
2	910	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
3	1215	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
4	1415	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
5	1615	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
6		Zero Gas	0					
		Upscale						
7	I.G.S PRETEST	Zero Gas	0		.1			
		Upscale			13.5			
8	I.G.S POSTEST	Zero Gas	0		.1			
		Upscale			13.5			
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check 3366

Job LP/ HAYWARD Source LTNE No. 2 DRYER RTO
 Test 1 Run _____ Date 7-12-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	.1	.1	0	20	0
		Upscale	11.1	10.9	10.9	0	20	0
2	910	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
3	1215	Zero Gas	0	.1	0.1	0	20	0
		Upscale	11.1	10.9	10.9	0	20	0
4	1415	Zero Gas	0	.1	.1	0	20	0
		Upscale	11.1	10.9	10.9	0	20	0
5	1615	Zero Gas	0	.1	.1	0	20	0
		Upscale	11.1	10.9	10.9	0	20	0
6		Zero Gas	0					
		Upscale						
7	I.G.S. PRETEST	Zero Gas	0		0			
		Upscale			10.9			
8	I.G.S. POSTEST	Zero Gas	0		.1			
		Upscale			11.0			
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

CO System Bias Check

Job LP HAWK D Source Core 2 main line 2
 Test Run Date 7-12-80 Site Fuller
 Operator [Signature]

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (PPM)	% of span
				Cal Err	Sys Bias			
1	0845	Zero gas	0	0	0	0	1000	0
		Upscale	594	596	594	2	1000	.2
2	1248	Zero gas	0	0	0	0	1000	0
		Upscale	594	596	594	2	1000	.2
3	1415	Zero gas	0	0	1	1	1000	.1
		Upscale	594	596	592	4	1000	.4
4	1625	Zero gas	0	0	0	0	1000	0
		Upscale	594	596	594	2	1000	.2
5		Zero gas	0					
		Upscale						
6		Zero gas	0					
		Upscale						
7		Zero gas	0					
		Upscale						
8		Zero gas	0					
		Upscale						
9		Zero gas	0					
		Upscale						
10		Zero gas	0					
		Upscale						
11		Zero gas	0					
		Upscale						
12		Zero gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES
(612) 785-6020

NOx System Bias Check

Job LP/Dunham Source Core Diner
 Test Run 5 Date 2-12-94 Site Falls
 Operator [Signature]

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (PPM)	% of span
				Cal Err	Sys Bias			
1	0838	Zero gas	0	0	0	0	500	0
		Upscale	239	238	235	3	500	.6
2	1255	Zero gas	0	0	0	0	500	0
		Upscale	75	75	76	2	500	.4
3	1415	Zero gas	0	0	1	1	500	.2
		Upscale	78	76	77	1	500	.2
4	1625	Zero gas	0	0	0	0	100	0
		Upscale	78	78	75	3	100	.6
5		Zero gas	0					
		Upscale						
6		Zero gas	0					
		Upscale						
7		Zero gas	0					
		Upscale						
8		Zero gas	0					
		Upscale						
9		Zero gas	0					
		Upscale						
10		Zero gas	0					
		Upscale						
11		Zero gas	0					
		Upscale						
12		Zero gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

S420-11R

02 System Bias Check

Job LP/HAYWARD Source LINE 2 CORE DRYER
 Test Run Date 2-12-94 Site FMET
 Operator [Signature]

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (PPM)	% of span
				Cal Err	Sys Bias			
1	0832	Zero gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
2	1235	Zero gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
3	1415	Zero gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
4	1625	Zero gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
5		Zero gas	0					
		Upscale						
6		Zero gas	0					
		Upscale						
7		Zero gas	0					
		Upscale						
8		Zero gas	0					
		Upscale						
9		Zero gas	0					
		Upscale						
10		Zero gas	0					
		Upscale						
11		Zero gas	0					
		Upscale						
12		Zero gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

CO2 System Bias Check

Job SP / HAWAII Source 1.000 2. Core. Dwyer
 Test Run Date 7-12-80 Site Outlet
 Operator _____

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (PPM)	% of span
				Cal Err	Sys Bias			
1	0632	Zero gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
2	1235	Zero gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
3	1415	Zero gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.0	.1	20	.5
4	1625	Zero gas	0	0	.1	.1	20	.5
		Upscale	11.1	11.1	11.1	0	20	0
5		Zero gas	0					
		Upscale						
6		Zero gas	0					
		Upscale						
7		Zero gas	0					
		Upscale						
8		Zero gas	0					
		Upscale						
9		Zero gas	0					
		Upscale						
10		Zero gas	0					
		Upscale						
11		Zero gas	0					
		Upscale						
12		Zero gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

THC System Bias Check

Job LP/HAYWARD 3366 Source 12NE No.2 DRYER RTO
 Test 4 Run _____ Date 7-12-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span	Run Time
				Cal. Err.	Sys. Bias				
1		Zero Gas	0	1.1	.5	.5	100	.5	
		Upscale	31.2	31.2	31	0	100	0	
2	1815	Zero Gas	0	1.1	.5	.5	100	.5	1830
		Upscale	31.2	31.2	31.5	0	100	0	1935
3	1950	Zero Gas	0	1.1	1.2	0	100	0	2015
		Upscale	31.2	31.2	31.7	.5	100	.5	2125
4	2130	Zero Gas	0	1.1	-.3	1.5	100	1.5	2155
		Upscale	31.2	31.2	30.7	.5	100	.5	2300
5	2305	Zero Gas	0	1.1	.3	.5	100	.5	
		Upscale	31.2	31.2	30.2	1.0	100	1.0	
6		Zero Gas	0						
		Upscale							
7		Zero Gas	0						
		Upscale							
8		Zero Gas	0						
		Upscale							
9		Zero Gas	0						
		Upscale							
10		Zero Gas	0						
		Upscale							
11		Zero Gas	0						
		Upscale							
12		Zero Gas	0						
		Upscale							

Must be within 5% of the span for the zero or upscale cal. gas.

Dscfm

033194-G:STACK\WP\FORMS\420-11

VZG

INTERPOLL LABORATORIES, INC
(612) 786-6020

THC System Bias Check

Job LP/HAYWARD Source LINE No. 2 SURFACE DRYER
 Test 5 Run _____ Date 7-12-94 Site CUTLET
 Operator R.R. _____ CHANNEL No. 1

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1710	Zero Gas	0	1	1	0	1000	0
		Upscale	301	306	301	5	1000	.50
2		Zero Gas	0	1	2	1	1000	.18
		Upscale	301	306	302	4	1000	.40
3	1950	Zero Gas	0	1	2	1	1000	.18
		Upscale	301	306	301	5	1000	.50
4	2130	Zero Gas	0	1	1	0	1000	0
		Upscale	301	306	306	0	1000	0
5	2213	Zero Gas	0	1	3	2	1000	.02
		Upscale	301	306	307	1	1000	.01
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

THC System Bias Check CORE

RAT

Job LP/HAYWARD 3366 Source 1/2 INCH No. 2 CORE DRYER
 Test 6 Run _____ Date 7-10-94 Site OUTLET
 Operator P.R

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1655	Zero Gas	0	0	1	1	1000	.01
		Upscale	301	304	305	1	1000	.01
2		Zero Gas	0	0	2	2	1000	.02
		Upscale	301	304	301	3	1000	.03
3	1945	Zero Gas	0	0	2	2	1000	.02
		Upscale	301	304	300	4	1000	.04
4		Zero Gas	0	0	2	2	1000	.02
		Upscale	301	304	305	1	1000	.01
5	2206	Zero Gas	0	0	4	4	1000	.04
		Upscale	301	304	305	1	1000	.01
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

CO System Bias Check

Job LP/HAYWARD 3366 Source LINE No. 1 DRYER RTO
 Test 14 Run Date 7-14-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1445	Zero Gas	0	1	1	0	500	0
		Upscale	150.5	151	151	0	500	0
2	1846	Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	150	1	500	.2
3	2200	Zero Gas	0	1	0	1	500	.2
		Upscale	150.5	151	145	5	500	1.0
4	19	Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	152	1	500	.2
5	200	Zero Gas	0	1	0	1	500	.2
		Upscale	150.5	151	151	0	500	0
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11	I.G.S PRE TEST	Zero Gas	0		2			
		Upscale			152			
12	I.G.S POST TEST	Zero Gas	0		2			
		Upscale			153			

RUN TIME
1625
1840

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

NO_x System Bias Check

Job LP/HAYWARD 3366 Source LINE No. 1 DRYER RTO
 Test 14 Run Date 7-14-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1445	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	50	2	100	2
2	1846	Zero Gas	0	0	1	1	100	1
		Upscale	50.5	52	54	2	100	2
3	2200	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	53	1	100	1
4	019	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	54	2	100	2
5	200	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	54	2	100	2
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

O₂ System Bias Check

Job LP/HAYWARD 3366 Source LINE No.1 DRYER RTO
 Test 14 Run Date 7-14-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1445	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
2	1846	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
3	2200	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.4	.1	25	.4
4	019	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
5	200	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.4
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11	I.G.S PRETEST	Zero Gas	0		0			
		Upscale			13.4			
12	I.G.S POSTEST	Zero Gas	0		.1			
		Upscale			13.4			

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check

Job LP/HAYWARD 3366 Source L2WE No.2 DRYER RTO
 Test 14 Run _____ Date 7-14-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	1445	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
2	1846	Zero Gas	0	.1	.2	.1	20	.5
		Upscale	11.1	10.9	11.0	.1	20	.5
3	2300	Zero Gas	0	.1	.2	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
4	019	Zero Gas	0	.1	0.	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
5	200	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11	I.G.S. PRETEST	Zero Gas	0		0			
		Upscale			160			
12	I.G.S. POSTEST	Zero Gas	0		.1			
		Upscale			10.9			

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020
System Bias Check

Job LP/HAYWARD 3366 Source _____
 Test Run _____ Date 7-15-94 Site _____
 Operator _____

00
02
03
04
05
06

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	I.G.S. PRETEST	Zero Gas	0		2			
		Upscale			153			
2	I.G.S. PRETEST	Zero Gas	0		.1			
		Upscale			13.5			
3	I.G.S. PRETEST	Zero Gas	0		0			
		Upscale			10.9			
4	I.G.S. POSTEST	Zero Gas	0		2			
		Upscale			149			
5	I.G.S. POSTEST	Zero Gas	0		.1			
		Upscale			13.4			
6	I.G.S. POSTEST	Zero Gas	0		.1			
		Upscale			10.9			
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO System Bias Check

Job C.P. HAYWARD Source LINDI COLE DRINK
 Test 15 Run Date 7-14-94 Site INLET
 Operator [Signature]

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (ppm)	% of Span
				Cal Err	Sys Bias			
1	1800	Zero Gas	0	0	0	0	1000	0
		Upscale	594	596	594	2	1000	.2
2	1445	Zero Gas	0	0	1	1	1000	.1
		Upscale	594	590	595	1	1000	.1
3	1845	Zero Gas	0	0	1	1	1000	.1
		Upscale	594	590	595	1	1000	.1
4	2142	Zero Gas	0	0	1	1	1000	.1
		Upscale	594	596	593	3	1000	.3
5	0006	Zero Gas	0	0	2	2	1000	.2
		Upscale	594	596	596	0	1000	0
6	0157	Zero Gas	0	0	3	3	1000	.3
		Upscale	594	596	594	2	1000	.2
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

G:\STACK\WP\FORMS\S420-11R

INTERPOLL LABORATORIES, INC

(612) 786-6020

NOX System Bias Check

Job LPI/HAYWARD Source LINE 1 COLE DAPT
 Test 15 Run Date 7-14-74 Site INLET
 Operator [Signature]

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (ppm)	% of Span
				Cal Err	Sys Bias			
1	0800	Zero Gas	0	0	0	0	100	0
		Upscale	78	78	77	1	100	1
2	1445	Zero Gas	0	0	.6	.6	100	.6
		Upscale	78	78	78	78	100	0
3	1845	Zero Gas	0	0	.2	.2	100	.2
		Upscale	78	78	78	0	100	0
4	2142	Zero Gas	0	0	0	0	100	0
		Upscale	78	78	78	0	100	0
5	0006	Zero Gas	0	0	0	0	100	0
		Upscale	78	78	77	1	100	1
6	0157	Zero Gas	0	0	0	0	100	0
		Upscale	78	78	77	1	100	1
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

G:\STACK\WPA\FORMS\420-11R

INTERPOLL LABORATORIES, INC

(612) 786-6020

02 System Bias Check

Job CP HAYWARD Source LINE 1 COPE DRYER
 Test 15 Run Date 7-14-04 Site INLET
 Operator [Signature]

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (ppm)	% of Span
				Cal Err	Sys Bias			
1	0900	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
2	1445	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
3	1945	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.4
4	2142	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.6	.1	25	.4
5	0006	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.5	0	25	0
6	0157	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

G:\STACK\WPF\FORMS\420-11R

INTERPOL LABORATORIES, INC

(612) 786-6020

CO2 System Bias Check

Job
Test
Operator

2P/HAYWARD
15 Run Date 7-14-94
E. T. ...

Source LINE 1 CO2 DRIP
Site INLET

Run	Time (HRS)	***	Cylinder Value (ppm)	Analyzer Resp (ppm)		Diff. CE-SB (ppm)	Span Val (ppm)	% of Span
				Cal Err	Sys Bias			
1	0500	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
2	1445	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
3	1845	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
4	2142	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
5	0006	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.1	0	20	0
6	0157	Zero Gas	0	0	0	0	20	0
		Upscale	11.1	11.1	11.0	.1	20	.5
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

G:\STACK\WP\FORMS\420-11R

CORE

TAC System Bias Check

Job LP/HA/HA/AD Source Line 1 Core Driver
 Test 16+17 Run 1-3 Date 7-15-90 Site RTO INLET
 Operator Bob

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	0	3	3	1000	.3
		Upscale	301	304	302	2	1000	.2
2	1100	Zero Gas	0	0	3	3	1000	.3
		Upscale	301	304	304	0	1000	0
3	1256	Zero Gas	0	0	2	2	1000	.2
		Upscale	301	304	301	3	1000	.3
4	1437	Zero Gas	0	0	4	4	1000	.4
		Upscale	301	304	306	2	1000	.2
5	1554	Zero Gas	0	0	3	3	1000	.3
		Upscale	301	304	300	4	1000	.4
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

THC System Bias Check

Job LP/HAYWARD Source CFE / SURFACE Layer
 Test Run 1 Date 7-15-96 Site RTO INLET
 Operator S.B.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1		Zero Gas	0	1	2	1	1000	.1
		Upscale	301	306	301	5	1000	.5
2	1100	Zero Gas	0	1	2	1	1000	.1
		Upscale	301	306	298	8	1000	.8
3	1300	Zero Gas	0	1	2	1	1000	.1
		Upscale	301	306	305	1	1000	.1
4	1425	Zero Gas	0	1	2	1	1000	.1
		Upscale	301	306	302	4	1000	.4
5	1600	Zero Gas	0	1	3	2	1000	.2
		Upscale	301	306	300	6	1000	.6
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO System Bias Check

Job LP/HAYWARD 3366 Source LINE No. 1 DRYER R70
 Test 17 Run Date 7-15-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	815	Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	149	2	500	.4
2	1105	Zero Gas	0	1	3	2	500	.4
		Upscale	150.5	151	149	2	500	.4
3	1255	Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	149	2	500	.4
4	1425	Zero Gas	0	1	2	1	500	.2
		Upscale	150.5	151	149	2	500	.4
5	1600	Zero Gas	0	1	1	0	500	0
		Upscale	150.5	151	148	3	500	.6
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

033194-G:STACK\WP\FORMS\S-20-11

INTERPOLL LABORATORIES, INC
(612) 786-6020

NO_x System Bias Check

Job LP/HAYWARD 3366 Source LZNE No.1 DRYER RTO
 Test 17 Run Date 7-15-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	815	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	52	0	100	0
2	1105	Zero Gas	0	0	0	0	100	0
		Upscale	50.5	52	51	1	100	1
3	1255	Zero Gas	0	0	1	1	100	1
		Upscale	50.5	52	51	1	100	1
4	1425	Zero Gas	0	0	1	1	100	1
		Upscale	50.5	52	53	1	100	1
5	1600	Zero Gas	0	0	2	2	100	2
		Upscale	50.5	52	53	1	100	1
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

O₂ System Bias Check

Job LP/HAYWARD 3366 Source LINE No. 1 DRYER RTO
 Test 17 Run Date 7-15-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	815	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.4
2	1105	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.4
3	1255	Zero Gas	0	0	.1	.1	25	.4
		Upscale	13.5	13.5	13.5	0	25	0
4	1425	Zero Gas	0	0	0	0	25	0
		Upscale	13.5	13.5	13.4	.1	25	.4
5	1600	Zero Gas	0	0	.2	.2	25	.8
		Upscale	13.5	13.5	13.6	.1	25	.4
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO₂ System Bias Check

Job LP/HAYWARD 3366 Source LINE No. 1 DRYER RTD
 Test 17 Run _____ Date 7-15-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	815	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
2	1105	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
3	1255	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
4	1425	Zero Gas	0	.1	.2	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
5	1600	Zero Gas	0	.1	0	.1	20	.5
		Upscale	11.1	10.9	10.9	0	20	0
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

THC System Bias Check

Job LP/HAYWARD 3366 Source LINE No. 1 DRYER RTO
 Test 17 Run Date 7-15-94 Site OUTLET
 Operator R.R.

Run	Time (HRS)	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
				Cal. Err.	Sys. Bias			
1	815	Zero Gas	0	1.1	.5	.6	100	.6
		Upscale	31.2	31.2	31.1	.1	100	.1
2	1105	Zero Gas	0	1.1	.6	.5	100	.5
		Upscale	31.2	31.2	30.9	.3	100	.3
3	1255	Zero Gas	0	1.1	.8	.3	100	.3
		Upscale	31.2	31.2	31.1	.1	100	.1
4	1430	Zero Gas	0	1.1	.4	.7	100	.7
		Upscale	31.2	31.2	31.2	0	100	0
5	1600	Zero Gas	0	1.1	.9	.2	100	.2
		Upscale	31.2	31.2	31.7	.5	100	.5
6		Zero Gas	0					
		Upscale						
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

850
1110
1315
1420
1445
1553

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES
Calibration Error Check

Job LP/HAYWARD

Test _____ Run _____ Date 7-12-54

Operator [Signature]

CO Calibration:

Time (HRS) 0715

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	1000	0
Mid level	249	249	0	1000	0
High level	594	596	2	1000	.2

NO_x Calibration:

Time (HRS) 0745

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	500	0
Mid level	239	238	1	500	.2
High level	476	476	0	500	0

O₂ Calibration:

Time (HRS) 0730

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	25	0
Mid level	13.5	13.5	0	25	0
High level	21.1	21.0	.1	25	.4

CO₂ Calibration:

Time (HRS) 0730

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	0	0	20	0
Mid level	11.1	11.1	0	20	0
High level	17.0	17.0	0	20	0

Must be within 2% of the span for each calibration gas

S-420-10

INTERPOLL LABORATORIES

Calibration Error Check

Job LP/HAYWARD

Test _____ Run _____ Date 7-12-94
 Operator R.R.

~~SO₂~~ Calibration:

Time (HRS) 1400

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	1.1		100	
Mid level	31.2	31.2		100	
High level	303	308		1000	
	3038	3040		1000	

NO_x Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

CO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

Must be within 2% of the span for each calibration gas

S-420-10

INTERPOLL LABORATORIES

Calibration Error Check

Job LP Hayward

Test 5 Run _____ Date _____

Operator _____

~~SO₂~~ Calibration: ^{THC}

Time (HRS) 1500

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0	1		100	
¹⁰⁰ Mid level	27.9	28		100	
¹⁰⁰⁰ High level	301	306		1000	

High level 3038 3030 1000

NO_x Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					


CO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (ppm)	Analyzer Response (ppm)	Difference (ppm)	Span Value (ppm)	Percent of Span
Zero gas	0				
Mid level					
High level					


Must be within 2% of the span for each calibration gas

S-420-10



APPENDIX J

PROCESS RATE INFORMATION



Hayward Dryer testing July 12-15, 1994

CONTENTS

	page
Test schedule	2
Line 1 process data summary	3
Line 2 process data summary	4
LINE 1 DRYER TESTING JULY 13, 1994	
Formaldehyde	
Board Weights / Production	5
Press Report	6
Press Charts	7-8
Dryer readings	9-10
Dryer Charts	11-12
EFB readings	13-14
Dryer RTO Readings	15
Dryer RTO Chart	16
moistures	17
trim %	18
LINE 1 DRYER TESTING JULY 14, 1994	
PM, CO, NOx	
Board Weights / Production	19
Press Reports	20-21
Press Charts	22-24
Dryer readings	25-27
Dryer Charts	28-31
EFB readings	32-34
Dryer RTO Readings	35-36
Dryer RTO Chart	37
moistures	38
LINE 1 DRYER TESTING JULY 15, 1994	
VOC, PHENOL, POM	
Board Weights / Production	39-40
Press Reports	41
Press Charts	42-43
Dryer readings	44-45
Dryer Charts	46-47
EFB readings	48-49
Dryer RTO Readings	50-51
Dryer RTO Chart	52
moistures	53
LINE 2 DRYER TESTING JULY 12, 1994	
VOC, Formaldehyde, PM, CO, NOx	
Board Weights / Production	54-55
Press Reports	56-57
Press Charts	58-60
Dryer readings	61-63
Dryer Charts	64-67
EFB readings	68-70
Dryer RTO Readings	71-73
Dryer RTO Chart	74
Weight of multicyclone dust catch	75
moistures	76
trim %	77
LINE 2 DRYER TESTING JULY 13, 1994	
PHENOL, POM	
Board Weights / Production	78-79
Press Reports	80
Press Charts	81-82
Dryer readings	83-84
Dryer Charts	85-86
EFB readings	87-88
Dryer RTO Readings	89-90
Dryer RTO Chart	91
moistures	92

Hayward Dryer testing July 12-15, 1994
 Test schedule

Line 1 Dryer testing

	<u>POLLUTANT</u>	<u>RUN #1</u>	<u>RUN #2</u>	<u>RUN #3</u>
7-13	HCHO	1200-1307	1427-1533	1612-1720
7-14	PM, CO, NOX	1625-1631 1642-1736 1827-1840	2030-2138	2230-2334 2332-2338 2350-2358
7-15	VOC	0847-1032	1315-1418	1445-1550
7-15	PHENOL + <i>Benzene</i>	0922-1025	1257-1357	1408-1508
7-15	POM	0800-1015	1258-1509	1545-1754

Note Run # 2 for PM, CO, NOx, not used due to suspected leak

Line 2 Dryer testing

<u>DATE</u>	<u>POLLUTANT</u>	<u>RUN #1</u>	<u>RUN #2</u>	<u>RUN #3</u>
7-12	PM	1000-1210	1305-1410	1500-1611
7-12	CO	1000-1210	1305-1410	1500-1611
7-12	NOX	1000-1210	1305-1410	1500-1611
7-12	VOC	1824-1932	2005-2120	2141-2300
7-12	HCHO	1830-1940	2015-2121	2155-2305
7-13	PHENOL + <i>Benzene</i>	0856-0956	1120-1220	1300-1401
7-13	POM	0848-1058	1150-1402	1505-1717

Hayward Dryer testing July 12-15, 1994
Line 1 process data summary

LINE 1 DRYER TESTING JULY 13, 1994 FORMALDEHYDE

19.93 = Press Production rate in Tons per hour
46,733 = Production rate of both dryers in pounds per hour
2.21 = Surface fuel burned in tons per hour
1.23 = Core fuel burned in tons per hour
3.43 = Total fuel (both dryers) burned in tons per hour
48.0% = average incoming moisture percent (both dryers)
5.5% = average dry moisture percent (both dryers)
1444 = average inlet temperature (both dryers)

LINE 1 DRYER TESTING JULY 14, 1994 PM, CO, NOx

19.56 = Press Production rate in Tons per hour
45,438 = Production rate of both dryers in pounds per hour
1.69 = Surface fuel burned in tons per hour
1.47 = Core fuel burned in tons per hour
3.16 = Total fuel (both dryers) burned in tons per hour
46.4% = average incoming moisture percent (both dryers)
5.3% = average dry moisture percent (both dryers)
1343 = average inlet temperature (both dryers)

1311° Surf
1375° Core

LINE 1 DRYER TESTING JULY 15, 1994 VOC and PHENOL + Benzene

19.82 = Press Production rate in Tons per hour
47,952 = Production rate of both dryers in pounds per hour
2.22 = Surface fuel burned in tons per hour
1.93 = Core fuel burned in tons per hour
4.15 = Total fuel (both dryers) burned in tons per hour
48.4% = average incoming moisture percent (both dryers)
4.2% = average dry moisture percent (both dryers)
1406 = average inlet temperature (both dryers)

LINE 1 DRYER TESTING JULY 15, 1994 POM

19.83 = Press Production rate in Tons per hour
47,920 = Production rate of both dryers in pounds per hour
2.18 = Surface fuel burned in tons per hour
1.94 = Core fuel burned in tons per hour
4.13 = Total fuel (both dryers) burned in tons per hour
48.0% = average incoming moisture percent (both dryers)
4.5% = average dry moisture percent (both dryers)
1391 = average inlet temperature (both dryers)

Hayward Dryer testing July 12-15, 1994
Line 2 process data summary

LINE 2 DRYER TESTING JULY 12, 1994 PM, CO, NOx
18.90 = PressProduction rate in Tons per hour
45,630 = Production rate of both dryers in pounds per hour
1.83 = Surface fuel burned in tons per hour
2.09 = Core fuel burned in tons per hour
3.92 = Total fuel (both dryers) burned in tons per hour
46.1% = average incoming moisture percent (both dryers)
5.0% = average dry moisture percent (both dryers)
1203 = average inlet temperature (both dryers) *1090 Face 1317 ~~1277~~ core*

LINE 2 DRYER TESTING JULY 12, 1994 VOC, Formaldehyde
18.83 = PressProduction rate in Tons per hour
44,992 = Production rate of both dryers in pounds per hour
1.76 = Surface fuel burned in tons per hour
1.91 = Core fuel burned in tons per hour
3.67 = Total fuel (both dryers) burned in tons per hour
47.6% = average incoming moisture percent (both dryers)
5.2% = average dry moisture percent (both dryers)
1192 = average inlet temperature (both dryers)

LINE 2 DRYER TESTING JULY 13, 1994 PHENOL + *Benzene*
17.83 = PressProduction rate in Tons per hour
43,149 = Production rate of both dryers in pounds per hour
1.91 = Surface fuel burned in tons per hour
1.84 = Core fuel burned in tons per hour
3.74 = Total fuel (both dryers) burned in tons per hour
46.9% = average incoming moisture percent (both dryers)
6.0% = average dry moisture percent (both dryers)
1117 = average inlet temperature (both dryers)

LINE 2 DRYER TESTING JULY 13, 1994 POM
17.90 = PressProduction rate in Tons per hour
43460 = Production rate of both dryers in pounds per hour
1.89 = Surface fuel burned in tons per hour
1.94 = Core fuel burned in tons per hour
3.83 = Total fuel (both dryers) burned in tons per hour
46.9% = average incoming moisture percent (both dryers)
5.5% = average dry moisture percent (both dryers)
1137 = average inlet temperature (both dryers)

LINE 1 DRYER TESTING JULY 13, 1994
DATA TIME: START= 12:00

FORMALDEHYDE
END= 17:30 HOURS= 5.50

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)
7/16

189	189	191	192	191	191.2 lb=average
193	192	192	190	188	untrimmed
192	185	191	190	191	mat weight
198	188	190	192	190	
200	189	192	191	192	179.2 lb=average
196	188	195	196	191	finished board
191	190	191	190	189	weight
196	189	195	191	189	(untrimmed mat
189	189	197	187	188	weight-weight
189	193	193	190	190	of trim)

6.3% =trim %

PLANT PRODUCTION RATE

5.50 =hours during testing
102 =pressloads
1224 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
219,280 =lbs of finished product (boards produced x weight of finished board)
39869 =lbs of finished product per hour (lbs of finished product / hours)
19.93 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

10 =SURFACE fuel calibration in pounds per count
2426 =SURFACE counts during testing hours
24260 =SURFACE lbs of fuel burned during testing
5.50 =hours during testing
4411 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
2.21 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8600 =estimated BTU content per pound of dry fuel,
37.9 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
1446 =average inlet temperature
48.0% =average incoming moisture percent
5.1% =average dry moisture percent

CORE

10 =CORE fuel calibration in pounds per count
1349 =CORE counts during testing hours
13490 =CORE lbs of fuel burned during testing
5.50 =hours during testing
2453 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
1.23 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
8600 =estimated BTU content per pound of dry fuel,
21.1 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
1442 =average inlet temperature
48.0% =average incoming moisture percent
5.9% =average dry moisture percent

DRYER THROUGHPUT RATE

6864 =Total pounds of fuel burned per hour in Core and Surface Dryer
39869 =lbs of finished product per hour (lbs of finished product / hours)
46733 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
2681 = weight of trim per hour at 6.3% of finished product
4183 =weight of screened fines per hour (total fuel - trim)
8.95% =resulting loss to fines as percentage of dryer throughput

OPERATOR Fitch SHIFT AM GEN A DATE 7-3-
 THICKNESS: 15/32 PRESS LOADS 19 1/2 39 1/4 75 90
 OVERALL TIMER: 148 DECOMPRESSION TIME 12
 PRESS TEMP: 210 TOTAL REELS:


LINE SPEED	FROM	TO
42	700	825
60	825	1035
40	1035	1100
60	1100	700

LOG COUNT: 7511
 F.C.O.S. HYD RADIATOR 805 AM
 Closed Blender Starts & Stops 900 AM
 Closed Ductile Coils 129 PM
 Press Blow Down 700 AM
 Headers Cleared YES (NO)
 How Many
 Power Hyd Radiator 124 PM

DOWNTIME		DOWNTIME (Mins)			X E Y	REASONS FOR DOWNTIME
FROM	TO	M	E	O		
928	933	5				<u>AM OP STOPS</u>
1033	1034	1				<u>STOPS</u>
	1034					
121	122	1				<u>FALSE GAP (WEST END)</u>
521	524	3				<u>ITS DROPPED</u>

Downtime Code: M - Mechanical E - Electrical O - Operator

LINE I
 PRESS CHART
 7-13-94
 0700-1500




1100

1200-1500 = 56

7

LINE 1
PRESS CHART
7-13-94
1500-2300



1900

1500-1730 = 46

8

Hayward Dryer Testing

LINE T

DATE JULY 13, 1994

BY PAGE 1 OF 2

FUEL CALIBRATION: face = lb./count core = lb./count

TIME	FACE			FACE			FACE			CORE			CORE			CORE WETBIN LEVEL	DRYBIN LEVEL		EVERY HOUR FLAKE MOISTURE	
	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	WETBIN LEVEL	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	WETBIN LEVEL	FACE	LEVEL	FACE		LEVEL	IN	OUT	
11:20	285	42	1270	252	1056	75	270	36	1206	200	1512	70	60	60						
11:30	280	42	1463	279	1128	75	270	36	1694	214	1554	70	60	65						
11:40	280	43	1396	280	1182	65	270	36	1496	261	1610	65	60	65						
11:50	280	42	1361	279	1247	65	270	36	1527	269	1672	65	60	65						
12:00	280	42	1429	277	1318	65	268	36	1502	269	1732	60	65	70						
12:10	280	42	1404	280	1381	70	268	37	1508	265	1787	65	65	70						
12:20	280	42	1447	281	1453	65	267	36	1475	267	1851	65	65	70						
12:30	280	42	1435	282	1521	65	267	37	1475	265	1904	60	70	70						
12:40	280	42	1465	278	1614	65	267	37	1474	266	1975	60	75	70						
12:50	280	42	1455	278	1671	65	267	37	1377	266	2612	60	75	70						
1:00	280	42	1465	274	1751	65	267	37	1341	266	2059	60	75	70						
1:10	280	42	1475	279	1812	60	267	36	1350	264	2091	65	75	70						
1:20	278	44	1425	275	1887	65	267	42	1356	269	2135	70	75	70						
1:30	278	45	1508	275	1972	65	267	42	1462	264	2183	70	75	65						
1:40	278	44	1510	276	2048	65	267	42	1485	265	2232	70	75	65						
1:50	278	44	1515	273	2122	65	267	42	1529	264	2277	75	80	65						
2:00	278	45	1549	276	2202	65	267	42	1536	266	2319	80	80	70						
2:10	278	43	1464	269	2268	60	267	42	1576	265	2360	80	85	70						
2:20	278	43	1464	282	2336	65	267	42	1501	251	2404	80	85	70						
2:30	278	43	1486	272	2411	70	267	42	1479	256	2443	80	85	70						
2:40	278	42	1597	278	2493	75	267	42	1351	252	2479	80	85	70						
2:50	278	42	1495	277	2565	75	268	42	1268	252	2515	85	85	70						
3:00	278	42	1328	277	2623	75	268	41	1413	255	2549	85	85	70						
3:10	278	38	1392	274	2703	80	268	41	1532	266	2597	80	80	70						
3:20	278	38	1420	278	2774	80	268	40	1521	269	2639	80	80	70						
3:30	278	39	1385	276	2839	80	268	41	1505	270	2669	85	80	70						
3:40	278	39	1380	277	2913	75	268	40	1456	266	2697	80	80	75						
3:50	278	38	1325	276	2981	75	268	40	1476	268	2732	80	80	75						
4:00	278	39	1348	276	3046	75	268	41	1451	266	2769	75	80	75						
4:10	278	39	1362	278	3114	75	268	41	1397	269	2812	75	80	75						

Hayward Dryer Testling

LINE I

DATE 7/13
 BY Hayward L. J. I.
 PAGE 2 OF 2

FUEL CALIBRATION: face = ___ lb./count core = ___ lb./count


TIME	FACE		FACE		FACE		CORE		CORE		CORE		CORE		CORE		EVERY HOUR FLAKE MOISTURE IN FACE OUT CORE OUT
	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	FACE WET BIN LEVEL	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	WET BIN LEVEL	FACE TEMP	OUTLET TEMP	FUEL COUNT	WET BIN LEVEL	
4:20	278	40	1408	278	3191	80	268	41	1430	269	2857	75	80	75	80	75	
4:30	278	40	1401	277	3269	80	268	41	1418	269	2899	75	80	75	80	75	
4:40	278	40	1463	281	3348	75	268	41	1401	268	2941	70	80	75	80	75	
4:50	278	40	1425	277	3410	75	268	41	1410	266	2968	70	80	75	80	75	
5:00	278	40	1456	273	3486	85	268	41	1362	262	2996	70	80	75	80	75	
5:10	278	40	1463	271	3568	90	268	40	1388	269	3022	75	80	75	80	75	
5:20	278	40	1541	287	3654	90	268	41	1369	270	3049	80	80	75	80	75	
5:30	278	40	1490	272	3744	90	268	41	1457	270	3081	80	80	75	80	75	

SURFACE DRYER CHART

7-13-94

0700 - 1900


1900 / 0700



HAYWARD DRYERS
LI JULY 13-14-15

LINE 1
CORE DRYER CHART
7-13-94
0700-1900

1900 / 0700



EFB READINGS

DATE JULY 13, 1994

BY _____

LANT: HAYWARD LINE I

TIME	*A* SIDE				*B* SIDE				Surface	
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.	EFB PRESS.	BAG H. PRESS.
11:20	9.5	.05	34.2	2.7	3	.05	25	1.9	5/2.8	4.2
11:30	11.5	.03	37.5	1.7	4.5	.04	25	2.2	5.1/2.2	4.4
11:40	10.5	.04	36.0	1.4	4.5	.04	25	2.1	5.0/2.4	4.2
11:50	10.4	.03	37.0	1.4	6.9	.05	23.9	1.9	5.0/2.5	4.2
12:00	10.4	.03	38.5	1.9	9.9	.06	25	2.2	4.9/2.4	4.3
12:10	10.5	.03	38	1.7	9.5	.075	25	2.0	4.7/2.8	4.2
12:20	11.2	.03	39	1.8	10.5	.06	25	1.9	4.9/2.7	4.2
12:30	12	.025	39	1.6	10	.07	25	1.9	4.7/2.7	4.3
12:40	12	.03	39	1.7	9.5	.09	25	1.8	4.8/2.8	4.7
12:50	12.5	.03	39	1.8	9.5	.08	25	1.8	4.95/2.7	4.7
1:00	11.4	.03	39	1.7	10.25	.075	25	1.9	5.1/2.7	turned off
1:10	11	.025	38.5	1.6	10.25	.06	25	1.8	5.0/2.8	3.6
1:20	11.5	.025	39	1.8	9.5	.1	25	1.6	5.0/2.4	3.7
1:30	11	.025	39	1.6	9.5	.1	25	1.6	4.9/2.5	3.6
1:40	11	.025	39	1.6	9.5	.1	25	1.6	4.7/2.4	3.8
1:50	10.5	.04	38.5	1.5	9	.1	25.5	1.4	4.6/2.6	3.6
2:00	11	.03	39	1.7	10.5	.1	26	1.6	4.5/2.5	turned off
2:10	10	.02	39	1.6	11	.06	25	1.8	4.5/2.4	3.6
2:20	12	.01	Down	Down	10	.12	25.5	1.5	4.6/2.7	3.7
2:30	10	.03	39	1.7	10	.13	26	1.4	4.5/2.6	3.7
2:40	10.5	.02	33	1	10	.12	25.5	1.6	4.5/2.4	3.8
2:50	10.5	.02	33	.9	9	.14	26	1.4	4.6/2.5	3.8
3:00	10	.03	33	1	10	.12	23	1	4.5/2.6	3.8
3:10	10.5	.02	34	1	9	.14	25	1	4.7/2.7	3.7
3:20	10.5	.02	34	1	10	.1	23	1.1	4.4/2.8	3.8
3:30	10.5	.02	34	.8	10.5	.1	23	1	4.3/2.5	3.8
3:40	10.5	.02	34	.8	11	.09	23	1	4.2/2.6	3.9
3:50	10	.02	34	.8	10.5	.1	24	1	4.3/2.5	4.0
4:00	10	.02	35	1	10.5	.1	25	1	4.3/2.4	3.8
4:10	11	.02	37	1.1	10.5	.1	25	1.3	4.2/2.4	4.0

EFB READINGS

DATE 7/13
 BY _____

PLANT: Hayward Line T

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
4:20	10.5	.02	37	1	10.5	.10	25	1.3	4.2 2.6	3.9
4:30	10.5	.02	39	1.5	10.5	.11	25	1.4	4.2 2.7	3.8
4:40	10.5	.02	39.5	1.6	10.5	.11	25.5	1.3	4.2 2.4	4.0
4:50	10.5	.02	40	1.6	10	.12	25	1.2	4.2 2.6	4.0
5:00	10.5	.02	39	1.6	10	.13	26	1.2	4.1 2.5	4.0
5:10	11	.02	39	1.6	10	.13	26	1.1	4.0 2.6	3.9
5:20	11	.01	39	1.8	10.5	.10	26	1.2	4.2 2.4	4.0
5:30	11	.02	40	1.6	9.0	.15	27	1.0	4.1 2.6	4.0
5:40										


JULY 15, 1999

HAYWARD LINE I RTO
EVERY 15 MINUTES

	#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	A AMP.	GAS
11:05	4169	470	461	476	469	3.8	1549	1552	237	1577	321	27.1	28410
11:20	4161	477	476	470	496	6.1	1532	1527	206	1576	330	25.5	28412
11:35	4162	468	485	464	499	3.6	1500	1543	229	1557	338	25.9	28414
12:00	4441	473	492	450	510	4.3	1545	1551	234	1583	325	25.7	28416
12:15	409	486	532	415	515	5.8	1615	1538	239	1567	325	25.2	28418
12:30	427	479	511	424	530	4.8	1540	1561	241	1579	329	25.4	28420
12:45	439	480	507	434	524	5.5	1530	1637	243	1572	332	24.8	28421
1:00	453	476	502	445	512	4.8	1513	1541	243	1557	340	25.2	28423
1:15	432	484	530	431	507	6.1	1641	1538	242	1569	328	25.3	28424
1:30	438	482	521	432	529	5.9	1517	1540	241	1565	333	25.4	28426
1:45	456	471	513	439	520	4.5	1528	1554	239	1568	348	25.2	28428
2:00	426	454	540	423	569	5.6	1541	1536	239	1585	325	24.4	28430
2:15	427	478	535	418	554	3.7	1515	1554	238	1568	344	24.9	28432
2:30	435	482	514	425	530	4.4	1557	1532	234	1588	327	25.1	28434
2:45	431	478	518	422	536	4.2	1547	1533	235	1590	327	24.3	28435
3:00	441	475	504	429	511	4.2	1519	1556	235	1584	331	25.2	28437
3:15	449	471	498	435	501	4.7	1536	1562	236	1577	332	25.1	28439
3:30	454	467	496	439	499	4.5	1520	1551	237	1564	335	25.5	28440
3:45	450	470	497	441	505	4.2	1514	1541	237	1561	335	25.2	28442
4:00	461	468	490	446	494	3.6	1522	1552	238	1564	336	25.7	28443
4:15	462	472	485	450	491	4.1	1550	1552	238	1583	330	25.0	28445
4:30	471	470	511	437	525	4.7	1536	1562	239	1572	342	24.9	28449
4:45	451	470	503	436	510	4.8	1533	1564	239	1574	339	25.4	28448
5:00	455	471	493	443	490	3.9	1554	1552	239	1570	328	24.7	28450
5:15	446	471	509	430	523	3.7	1511	1541	237	1560	336	25.5	28452
5:30	453	470	499	439	505	4.9	1534	1564	234	1575	337	25.4	28453

15

LINE I
DRYER RTU CHART
7-13-94



HAYWARD OSB
LINE I
JULY 13, 1994

FLAKE MOISTURE

	WET	DRY
10:00 AM	C 47.9 S 44.2	C 5.8 S 7.3
11:00 AM	C 44.9 S 47.5	C 6.1 S 9.0
12:00 PM	C 44.3 S 45.6	C 4.4 S 7.1
1:00 PM	C 48.7 S 47.0	C 5.0 S 4.1
2:00 PM	C 50.4 S 50.6	C 6.0 S 3.1
3:00 PM	C 48.2 S 50.4	C 6.2 S 4.6
4:00 PM	C 45.6 S 47.9	C 6.4 S 5.1
5:00 PM	C 50.2 S 47.2	C 7.6 S 6.5

~~196LB~~
~~194LB~~
~~197LB~~
~~196LB~~
~~197LB~~
~~199LB~~
~~199LB~~
~~199LB~~
~~201LB~~
~~197LB~~
~~200LB~~
~~198LB~~
~~196LB~~
~~201LB~~
~~196LB~~
~~195LB~~
~~200LB~~
~~200LB~~
~~195LB~~
~~200LB~~
~~195LB~~

Line I
 Palled At 196.00 +
 4:30 PM 197.00 +
 7/14/94 199.00 +
 199.00 +
 199.00 +
 201.00 +
 197.00 +
 200.00 +
 198.00 +
 196.00 +
 201.00 +
 196.00 +
 Before Saws 2,379.00 *

2237 lb After Saws

Weight After Saws - 2,237 lb

6.3%
142 lb trim

LINE 1 DRYER TESTING JULY 14, 1994

PM, CO, NOx

DATA TIME:	START=	16:20	END=	17:30	HOURS=	1.17
	START=	18:30	END=	18:40	HOURS=	0.17
	START=	22:30	END=	02:00	HOURS=	3.50
						4.83

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)
7/16

193	195	190	198	193.3 lb=average
191	198	186	197	untrimmed
193	193	196	195	mat weight
194	191	198	195	
197	188	194	195	181.1 lb=average
191	191	203	198	finished board
188	184	198	193	weight
191	184	199	191	(untrimmed mat
193	185	198	197	weight-weight
192	188	196	195	of trim)
				6.3% =trim %

PLANT PRODUCTION RATE

4.83 =hours during testing
 87 =pressloads
 1044 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
 189,089 =lbs of finished product (boards produced x weight of finished board)
 39122 =lbs of finished product per hour (lbs of finished product / hours)
 19.56 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE


10 =SURFACE fuel calibration in pounds per count
 1632 =SURFACE counts during testing hours
 16320 =SURFACE lbs of fuel burned during testing
 4.83 =hours during testing
 3377 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
 1.69 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
 8600 =estimated BTU content per pound of dry fuel,
 29.0 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
 1311 =average inlet temperature
 46.4% =average incoming moisture percent
 4.3% =average dry moisture percent

CORE

10 =CORE fuel calibration in pounds per count
 1421 =CORE counts during testing hours
 14210 =CORE lbs of fuel burned during testing
 4.83 =hours during testing
 2940 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
 1.47 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
 8600 =estimated BTU content per pound of dry fuel,
 25.3 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
 1375 =average inlet temperature
 46.4% =average incoming moisture percent
 6.2% =average dry moisture percent

DRYER THROUGHPUT RATE

6,317 =Total pounds of fuel burned per hour in Core and Surface Dryer
 39,122 =lbs of finished product per hour (lbs of finished product / hours)
 45,438 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
 2,630 = weight of trim per hour at 6.3% of finished product
 3,686 =weight of screened fines per hour (total fuel - trim)
 8.11% =resulting loss to fines as percentage of dryer throughput



LINE 1 DRYER TESTING JULY 14, 1994

PM, CO, NOx

DATA TIME:	START=	16:20	END=	17:30	HOURS=	1.17
	START=	18:30	END=	18:40	HOURS=	0.17
	START=	22:30	END=	02:00	HOURS=	3.50
						4.83

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)
7/16

193	195	190	198	193.3 lb=average
191	198	186	197	untrimmed
193	193	196	195	mat weight
194	191	198	195	
197	188	194	195	181.1 lb=average
191	191	203	198	finished board
188	184	198	193	weight
191	184	199	191	(untrimmed mat
193	185	198	197	weight-weight
192	188	196	195	of trim)
				6.3% =trim %

PLANT PRODUCTION RATE

- 4.83 =hours during testing
- 87 =pressloads
- 1044 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 189,089 =lbs of finished product (boards produced x weight of finished board)
- 39122 =lbs of finished product per hour (lbs of finished product / hours)
- 19.56 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 1632 =SURFACE counts during testing hours
- 16320 =SURFACE lbs of fuel burned during testing
- 4.83 =hours during testing
- 3377 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.69 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 29.0 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1311 =average inlet temperature
- 46.4% =average incoming moisture percent
- 4.3% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 1421 =CORE counts during testing hours
- 14210 =CORE lbs of fuel burned during testing
- 4.83 =hours during testing
- 2940 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.47 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 25.3 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1375 =average inlet temperature
- 46.4% =average incoming moisture percent
- 6.2% =average dry moisture percent

DRYER THROUGHPUT RATE

- 6,317 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 39,122 =lbs of finished product per hour (lbs of finished product / hours)
- 45,438 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 2,630 = weight of trim per hour at 6.3% of finished product
- 3,686 =weight of screened fines per hour (total fuel - trim)
- 8.11% =resulting loss to fines as percentage of dryer throughput

OPERATOR Fitch SHIFT Days CEN A DATE 2-14-60
 THICKNESS: 1/2 PRESS LOADS 2 1/2 917 7/16
 OVERALL TIME: 245 DECOMPRESSION TIME 26
 PRESS TEMP: 210°C TOTAL REELS: _____
 LOG COUNT: 4286

LINE SPEED	FROM	TO
40	7:00	110
46	110	300
50	300	512
60	512	525
65	525	625
60	625	700

F.C.O.S. HYD RADIATOR 4:15 PM
 Closed Header Struts & Tracts 2:00 PM
 Closed Drive Chains 2:30 PM
 Press Blow Down 1:00 PM
 Headers Cleaned YES/NO
 How Many _____
 Power Hyd Radiator 2:25 PM Time

DOWNTIME		DOWNTIME (Mins)			KEY	REASONS FOR DOWNTIME
FROM	TO	M	E	O		
724	1012	2	1	4		DEBHOUSE DOWN (SCHEDULED)
1022	1052	30				↑ SAME (SCHEDULED)
1056	1106	12				JAW W/ SADS
1108	1109	1				TUNING & LIMITS SADS
1135	1235	60				BASEHOUSE DOWN AGAIN self
554	555	1				NO AUTO ADVANCE #6 coil
645						"

Downtime Code: M - Mechanical E - Electrical O - Operator


OPERATOR Morgan SHIFT Nights GEN C DATE 7-14-94
 THICKNESS: 7/16 PRESS LOADS 212 7/16
 OVERALL TIMER: 150 DECOMPRESSION TIME 15
 PRESS TEMP: 210°C TOTAL REELS: _____

LINE SPEED	FROM	TO
60	7:00	7:52
64	7:52	7:00


LOG COUNT: 7,267
 P.C.O.S. HYD RADIATOR 4:30 TH
 Cleaned Blender Strands & Tracks YES
 Cleaned Decile Gates YES
 Press Allow Down YES
 Hoopbars Cleaned YES/NO
 How Many _____
 Former Hyd Radiator 2:30 Time

DOWNTIME		DOWNTIME (Mins)			KEY	REASONS FOR DOWNTIME
FROM	TO	M	E	O		
8:24	8:26	2				Checking vibration at gearbox & Motor for second Saw feedworks.
9:56	10:05	9	-			Changed bad Coupler at 2nd Feedworks at saws. Also changed bad brake pad at #5 conv. brake.
11:39	11:45	6				Lost Tach. Feedback, reset drive for loader Room.
11:59	12:01	2				Screen balled up at #5 conv.
12:38	12:42	4				" " " "
						Replaced screen.
2:50	2:54	4				Bd. Stacker jam up.

LINE I
PRESS CHART
7-14-94
0700 - 1500




LINE L
 PRESS CHART
 7-14-94
 1500 - 2300



1620 - 1730 = 22
 1830 - 1840 = 4
 2230 - 2300 = 9

LINE I
PRESS CHART
7-14-94
2300-0700

8/2300
0



2300-0200 = 52

29

Hayward Dryer Testing

LINE 1

DATE JULY 14, 1994

FUEL CALIBRATION: face = lb./count core = lb./count


BY PAGE 2 OF 3

TIME	FACE		FACE		FACE WET BIN LEVEL	CORE OUT. SET POINT	CORE FEED RATE	CORE INLET TEMP	CORE OUTLET TEMP	CORE FUEL COUNT	CORE WET BIN LEVEL	CORE		FACE		EVERY HOUR FLAKE MOISTURE	
	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP								FACE WET BIN LEVEL	FACE FUEL COUNT	IN	OUT		
8:15	285	33	1020	277	85	280	42	1318	279	438	85	438	65	40			
8:25	285	35	1171	285	85	280	42	1290	279	488	85	488	65	90			
8:35	288	35	1149	285	90	280	42	1214	278	538	90	538	65	85			
8:45	288	37	1161	287	90	280	42	1234	278	593	90	593	65	85			
8:55	288	37	1212	284	85	281	42	1341	284	670	90	670	65	85			
9:05	288	37	1167	287	85	281	42	1366	281	718	90	718	65	85			
9:15	290	37	1164	291	85	281	42	1363	283	776	90	776	65	85			
9:25	290	37	1127	288	85	281	42	1422	281	852	90	852	65	85			
9:35	290	36	1130	289	85	281	42	1471	278	910	85	910	65	80			
9:45	290	37	1151	288	85	281	42	1496	282	977	85	977	65	80			
9:55	290	37	1177	289	80	281	42	1452	278	1061	85	1061	65	85			
10:05	290	35	1161	289	80	281	42	1512	283	1121	85	1121	70	85			
10:15	290	35	1184	289	80	281	42	1507	279	1192	85	1192	75	85			
10:25	290	36	1202	290	80	281	42	1537	279	1277	80	1277	75	85			
10:35	290	36	1223	290	75	281	42	1545	283	1337	70	1337	75	80			
10:45	290	36	1255	291	70	281	42	1466	283	1397	70	1397	80	80			
10:55	290	36	1254	289	65	281	43	1483	285	1471	70	1471	80	80			
11:05	290	36	1239	290	65	281	42	1443	278	1524	65	1524	80	80			
11:15	288	36	1236	287	65	281	42	1459	280	1593	65	1593	80	80			
11:25	288	35	1276	287	65	281	42	1412	273	1672	65	1672	85	85			
11:35	288	35	1270	286	65	281	42	1472	283	1720	65	1720	85	85			
11:45	288	35	1485	290	60	281	42	1475	282	1792	65	1792	90	90			
11:55	288	36	1315	291	60	281	42	1458	285	1868	65	1868	90	90			
12:05	288	35	1274	288	60	281	43	1421	276	1914	60	1914	90	90			
12:15	288	35	1266	288	60	281	42	1322	275	1991	60	1991	90	90			
12:25	288	35	1249	287	60	281	42	1450	286	2065	60	2065	90	90			
12:35	288	36	1254	288	70	281	42	1437	277	2114	60	2114	90	90			
12:45	288	33	1267	288	70	281	39	1367	277	2182	60	2182	90	90			
12:55	288	33	1220	287	70	281	40	1329	274	2248	60	2248	90	90			
1:05	288	33	1216	287	75	281	40	1297	279	2296	60	2296	90	90			

↑ = so full it covered the window

LINER
SURFACE DRYER
CHART
7-14-94
0700-1900


0700
1900



LINE 7
CORE DRYER
CHART
7-14-94
0700 - 1900


0700

1900




LINE I
SURFACE DRYE
CHART
7-14-94
1900-0700

0700 / 1900



LINC I
CORE DRYER
CHART
1900 - 0700
7-14-94

0700 1900



EFB READINGS

DATE JULY 14, 1994

BY _____

PLANT: HAYWARD LINE I

1 OF 3

TIME	"A" SIDE				"B" SIDE				5	
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.	EFB PRESS.	BAG H. PRESS.
3:15	12	.04	25	1.6	11.5	.16	24.5	1.4	4.2/3.0	4.0
3:25	12.5	.03	25	1.6	11.5	.16	24	1.4	4.2/2.6	4.0
3:35	12.5	.04	27	1.6	12.5	.07	25	2.2	4.2/2.4	4.0
3:45	12.5	.03	27	1.7	11.5	.11	25	1.8	4.3/2.1	4.0
3:55	13	.02	27.5	2.2	11.5	.10	25	1.8	4.2/2.2	4.0
4:05	12.75	.03	27.5	1.8	12	.10	25	1.9	4.1/2.1	3.9
4:15	12.5	.03	27.5	1.7	11	.13	26	1.8	4.0/2.0	4.0
4:25	12.5	.02	27	1.6	11	.15	26	1.8	4.0/2.1	4.0
4:35	13	.02	28	1.6	11.5	.12	26	1.9	4.2/2.4	4.0
4:45	12.75	.03	28	1.6	11.5	.12	26.5	1.8	4.3/2.2	4.0
4:55	12	.02	26.5	1.4	10	.11	26	1.7	4.4/2.2	3.9
5:05	12.5	.02	28	1.4	11	.14	26.5	1.7	4.4/2.0	4.0
5:15	12	.03	28	1.6	11.5	.14	27	1.7	4.3/2.6	4.0
5:25	12.5	.02	28	1.4	11	.14	26	1.6	4.2/2.2	4.0
5:35	12.5	.03	30	1.8	10.5	.16	26.5	1.4	4.4/2.0	4.1
5:45	12.5	.03	31	1.5	11	.13	26	1.5	4.4/2.2	4.1
5:55	13.5	.01	28	2.4	11	.13	26	1.6	4.2/2.0	4.0
6:05	12.5	.01	27.5	2.2	11	.13	26	1.5	4.1/2.1	4.1
6:15	12.0	.01	27	2.4	11	.12	26	1.5	4.1/2.6	4.0
6:25	12.5	.03	31	1.7	11.5	.12	26	1.6	4.3/2.0	4.1
6:35	12.5	.03	30.5	1.6	11	.14	27	1.5	4.2/2.0	4.1
6:45	12.5	.03	31	1.7	11.5	.14	27	1.6	4.3/2.6	4.0
6:55	12.5	.03	31	1.8	11	.16	27	1.5	4.3/2.1	4.0
7:05	12.5	.03	30	1.7	12	.10	26	1.8	4.2/2.2	4.0
7:15	12.5	.03	31	1.8	- RESET -				4.2/2.2	4.2
7:25	11.5	.03	31	1.7	- Down -				4.2/1.8	4.1
7:35	12.5	.03	31	1.6	Down				4.2/2.2	4.1
7:45	12.5	.02	31	1.6	Down				4.1/2.3	4.1
7:55	12.5	.02	31	1.4	Down				4.1/2.5	4.0
8:05	12.5	.02	31	1.6	Down				3.9/3.2	4.1

EFB READINGS

DATE JULY 14, 1994

BY _____

PLANT: HAYWARD LINE I

2 OF 3

TIME	"A" SIDE				"B" SIDE				S	
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.	EFB PRESS.	BAG H. PRESS.
8:15	13	.02	31	1.6	4.5	.26	21.5	1.4	3.8 / 2.6	4.1
8:25	13	.02	31	1.6	10.5	.36	24	1.6	4.1 / 2.2	4.0
8:35	13	.02	31	1.4	12.5	.18	24	1.6	4.1 / 2.5	3.9
8:45	13	.02	32	1.4	12.5	.14	24	1.4	4.3 / 2.4	4.1
8:55	13	.02	32	1.6	12.5	.14	24	1.4	4.2 / 2.0	4.1
9:05	13	.02	32	1.6	13.5	.10	24	1.4	4.2 / 2.1	4.0
9:15	13	.02	32	1.6	13	.12	24	1.3	4.1 / 2.0	4.0
9:25	13	.02	32	1.3	13.5	.11	24	1.4	4.1 / 2.3	4.0
9:35	12.5	.03	32.5	1.4	12	.10	25	1.3	4.0 / 2.2	4.0
9:45	12.5	.02	32	1.5	12	.11	25	1.7	4.0 / 2.0	4.0
9:55	13	.02	33	1.5	12	.10	25	1.4	4.0 / 2.1	4.1
10:05	12.5	.02	32.5	1.2	12	.10	25	1.3	4.0 / 1.8	4.0
10:15	12.5	.03	33	1.2	12.5	.09	25	1.3	4.0 / 1.9	4.1
10:25	13	.03	33	1.4	12.5	.11	25	1.2	3.9 / 2.2	4.1
10:35	13	.02	34	1.2	12.5	.11	25	1.4	4.0 / 2.2	4.0
10:45	13	.02	33	1.4	12.5	.10	25	1.4	4.0 / 2.3	4.1
10:55	13	.02	33	1.4	12.5	.11	25	1.3	4.1 / 2.2	4.1
11:05	13	.02	33	1.4	12.5	.11	25	1.3	4.1 / 2.2	4.1
11:15	13	.02	33.5	1.4	12	.12	25	1.2	3.9 / 2.4	4.2
11:25	13	.02	33	1.4	12.5	.12	25	1.2	4.0 / 2.2	4.1
11:35	13	.02	33	1.4	12.5	.10	25	1.3	4.0 / 2.2	4.0
11:45	13	.02	33	1.4	12	.10	25	1.2	4.0 / 2.2	4.0
11:55	13	.02	33.5	1.2	12.5	.11	25	1.2	4.0 / 2.1	4.2
12:05	13	.02	34	1.4	12.5	.10	25	1.2	3.9 / 2.4	4.2
12:15	13	.02	33	1.4	12.5	.10	25	1.3	4.0 / 2.5	4.2
12:25	13	.01	33	1.4	12	.10	25	1.2	4.2 / 2.2	4.1
12:35	13	.02	33	1.2	12	.10	25	1.2	4.2 / 2.2	4.1
12:45	13	.02	33	1.4	12.5	.09	25	1.2	4.3 / 2.2	4.1
12:55	13	.01	32	1.6	13	.09	25	1.2	4.1 / 2.2	4.1
1:05	13.5	.01	33	1.7	12.5	.10	25	1.2	4.1 / 2.2	4.2

EFB READINGS

DATE JULY 14, 1994

BY _____

PLANT: HAYWARD LINE I

3 OF 3

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
1:15	13.5	.01	32	1.6	12.5	.09	25	1.3	4.2 2.2	4.2
1:25	13.5	.01	33	1.4	12.5	.09	25	1.5	4.1 2.2	4.1
1:35	13.5	.02	33	1.4	12.5	.09	25	1.6	4.2 2.1	4.1
1:45	13.5	.01	33	1.4	12.5	.09	25	1.5	4.2 2.0	4.1
1:55	13.5	.01	32	1.6	13	.08	25	1.5	4.2 2.1	4.1

HAYWARD LINE I RIO

EVERY 15 MINUTES

JULY 14, 1994
10F2

TIME	#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	AMP.	GAS
3 ⁰⁰	457	456	486	436	482	6.1	1525	1562	228	1567	324	18.4	28606
3 ¹⁵	462	458	479	442	478	3.9	1513	1541	226	1554	328	26.4	28607
3 ³⁰	459	462	464	447	482	3.5	1515	1545	230	1555	330	25.9	28609
3 ⁴⁵	464	459	464	452	474	2.7	1515	1548	236	1556	331	26.5	28611
4 ⁰⁰	468	461	461	457	467	4.1	1539	1562	235	1568	323	26.1	28613
4 ¹⁵	466	461	473	453	488	4.0	1504	1541	236	1557	330	26.4	28614
4 ³⁰	459	462	478	446	490	4.1	1528	1561	237	1564	333	26.2	28616
4 ⁴⁵	464	463	472	450	480	4.1	1537	1565	237	1569	328	25.9	28618
5 ⁰⁰	466	468	471	453	482	5.2	1541	1534	238	1569	335	25.7	28620
5 ¹⁵	471	465	471	456	480	4.1	1522	1537	239	1557	338	26.3	28621
5 ³⁰	479	461	470	461	470	4.2	1533	1567	239	1569	330	26.1	28623
5 ⁴⁵	478	464	469	463	470	3.5	1542	1551	239	1571	326	25.2	28625
6 ⁰⁰	478	468	468	465	473	3.9	1555	1530	240	1577	335	25.8	28627
6 ¹⁵	481	461	474	463	476	2.5	1517	1559	239	1557	335	26.7	28629
6 ³⁰	483	461	470	466	470	4.5	1531	1561	239	1565	322	26.0	28630
6 ⁴⁵	449	473	497	443	523	5.1	1542	1535	240	1568	331	25.8	28632
7 ⁰⁰	458	468	492	443	507	2.9	1510	1541	242	1554	339	25.7	28634
7 ¹⁵	468	467	484	452	489	3.6	1536	1565	244	1567	334	26.3	28636
7 ³⁰	465	475	487	452	500	3.1	1590	1530	244	1582	332	26.8	28637
7 ⁴⁵	468	475	486	455	497	4.6	1545	1533	241	1567	336	27.3	28639
8 ⁰⁰	471	466	484	457	490	1.7	1554	1540	225	1526	334	29.2	28641
8 ¹⁵	477	462	471	460	471	3.1	1550	1551	210	1571	317	27.2	28643
8 ³⁰	471	459	462	458	469	5.9	1550	1530	213	1571	326	26.4	28645
8 ⁴⁵	472	454	461	459	468	4.2	1528	1535	228	1556	330	26.7	28647
9 ⁰⁰	480	458	463	463	466	3.0	1518	1551	238	1557	330	26.1	28648
9 ¹⁵	486	455	462	469	461	3.5	1541	1562	242	1568	327	25.9	28650

HAYWARD LINE I RTO


EVERY 15 MINUTES

JULY 14, 1994
2 OF 2

TIME	#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ AMP.	GAS
9:00	472	464	478	461	487	3.8	1558	1530	245	1578	334	26.0	28652
9:15	473	459	488	459	494	4.5	1523	1587	246	1566	337	26.0	28654
10:00	478	462	486	462	488	4.0	1538	1667	248	1572	335	26.0	28656
10:15	477	468	487	463	495	4.3	1534	1535	249	1565	342	26.9	28657
10:30	485	464	488	467	488	3.4	1572	1541	248	1575	341	25.4	28659
10:45	491	465	480	474	477	4.6	1544	1561	248	1569	332	25.6	28660
11:00	493	466	483	477	482	4.3	1549	1537	250	1566	343	25.4	28662
11:15	496	470	481	480	491	5.0	1518	1536	250	1558	345	25.5	28664
11:30	495	470	482	481	481	3.7	1541	1561	250	1575	336	25.6	28666
11:45	493	474	480	482	483	4.0	1554	1541	250	1578	336	25.6	28667
12:00	499	466	483	482	481	4.5	1524	1552	250	1565	344	26.0	28669
12:15	470	478	502	464	516	3.9	1555	1538	249	1579	336	25.7	28671
12:30	476	478	494	468	503	4.3	1558	1529	249	1579	341	25.2	28672
12:45	480	473	499	469	509	3.3	1514	1543	249	1555	345	25.6	28674
1:00	483	472	492	471	495	4.5	1531	1566	249	1568	344	25.4	28676
1:15	484	475	490	473	493	3.6	1549	1559	248	1579	337	25.5	28678
1:30	487	471	492	472	492	5.2	1526	1561	249	1563	341	25.8	28679
1:45	493	472	485	477	481	4.3	1535	1567	249	1567	336	25.7	28681
2:00	494	478	480	480	478	3.3	1578	1530	249	1582	338	25.8	28683
2:15													
2:30													
2:45													
3:00													
3:15													
3:30													
3:45													

✓

LINE I
DRYER RTC CHART
7-14-99



HAYWARD OSB
LINE II
JULY 14, 1994

FLAKE MOISTURE

	WET	DRY
8:00 AM	C 47.2 S 45.7	C 6.0 S 5.8
9:00 AM	C 46.2 S 44.0	C 5.2 S 6.1
10:00 AM	C 47.6 S 46.1	C 5.2 S 4.1
11:00 AM	C 47.2 S 45.4	C 5.6 S 3.9
12:00 PM	C 48.6 S 49.0	C 5.0 S 6.8
1:00 PM	C 52.8 S 45.6	C 5.9 S 5.2
2:00 PM	C 46.2 S 46.0	C 5.8 S 7.4
3:00 PM	C 46.4 S 45.7	C 4.0 S 6.0

LINE 1 DRYER TESTING JULY 15, 1994

VOC and PHENOL

DATA TIME: START= 08:40 END= 10:40 HOURS= 2.00
 START= 12:50 END= 15:50 HOURS= 3.00

5.00

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)

7/16

192	193	193	190	195	193.74 lb=average
192	200	189	194	195	untrimmed
191	198	192	194		mat weight
192	198	191	196		
190	199	189	196	181.5 lb=average	
189	196	191	201	finished board	
196	192	199	193	weight	
194	193	188	196	(untrimmed mat	
192	196	189	193	weight-weight	
198	196	188	198	of trim)	
				6.3% =trim %	

PLANT PRODUCTION RATE

- 5.00 =hours during testing
- 91 =pressloads
- 1092 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 198,231 =lbs of finished product (boards produced x weight of finished board)
- 39646 =lbs of finished product per hour (lbs of finished product / hours)
- 19.82 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 2223 =SURFACE counts during testing hours
- 22230 =SURFACE lbs of fuel burned during testing
- 5.00 =hours during testing
- 4446 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.22 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 38.2 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1384 =average inlet temperature
- 48.4% =average incoming moisture percent
- 4.2% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 1930 =CORE counts during testing hours
- 19300 =CORE lbs of fuel burned during testing
- 5.00 =hours during testing
- 3860 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.93 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 33.2 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1427 =average inlet temperature
- 48.4% =average incoming moisture percent
- 4.2% =average dry moisture percent

DRYER THROUGHPUT RATE

- 8,306 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 39,646 =lbs of finished product per hour (lbs of finished product / hours)
- 47,952 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 2,666 = weight of trim per hour at 6.3% of finished product
- 5,640 =weight of screened fines per hour (total fuel - trim)
- 11.76% =resulting loss to fines as percentage of dryer throughput

LINE 1 DRYER TESTING JULY 15, 1994

POM

DATA TIME: START= 08:40 END= 10:40 HOURS= 2.00
 START= 12:50 END= 18:00 HOURS= 5.17

7.17

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)

7/16

192	193	193	190	195	193	192.98 lb=average
192	200	189	194	195	183	untrimmed
191	198	192	194	198	187	mat weight
192	198	191	196	195	186	
190	199	189	196	195	192	180.8 lb=average
189	196	191	201	196	187	finished board
196	192	199	193	194	192	weight
194	193	188	196	194	186	(untrimmed mat
192	196	189	193	189		weight-weight
198	196	188	198	189		of trim)
						6.3% =trim %

PLANT PRODUCTION RATE

- 7.17 =hours during testing
- 131 =pressloads 62.88
- 1572 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 284,249 =lbs of finished product (boards produced x weight of finished board)
- 39663 =lbs of finished product per hour (lbs of finished product / hours)
- 19.83 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 3131 =SURFACE counts during testing hours
- 31310 =SURFACE lbs of fuel burned during testing
- 7.17 =hours during testing
- 4369 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.18 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 37.6 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1356 =average inlet temperature
- 48.0% =average incoming moisture percent
- 4.2% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 2787 =CORE counts during testing hours
- 27870 =CORE lbs of fuel burned during testing
- 7.17 =hours during testing
- 3889 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.94 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 33.4 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1426 =average inlet temperature
- 48.0% =average incoming moisture percent
- 4.8% =average dry moisture percent

DRYER THROUGHPUT RATE

- 8,258 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 39,663 =lbs of finished product per hour (lbs of finished product / hours)
- 47,920 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 2,667 = weight of trim per hour at 6.3% of finished product
- 5,591 =weight of screened fines per hour (total fuel - trim)
- 11.67% =resulting loss to fines as percentage of dryer throughput

OPERATOR Fitch SHIFT Days OPEN A DATE 7-15-94
 THICKNESS: 7/16 PRESS LOADS 211 4/16
 OVERALL TIMER: 143 DECOMPRESSION TIME 15
 PRESS TEMP: 210°c TOTAL REELS:

LINE SPEED	FROM	TO
64	7:00	1045
50	1045	120
64+	120	700


LOG COUNT: 1337
 F.C.O.S. HYD RADIATOR 8:30 AM
 Cleaned Header Straps & Bands 9:00 AM
 Cleaned Deckle Chairs 12:5 PM
 Press Blow Down 7:45 AM
 Headbars Cleaned YES/NO
 How Many
 Former Hyd Radiator 1:00 PM Time

DOWNTIME		DOWNTIME (Mins)			KEY	REASONS FOR DOWNTIME
FROM	TO	M	E	O		
1248	1254	6			COOLER FEED DRIVE LOADER FROM TRIP	
528	529		1			

Downtime Code: M - Mechanical E - Electrical O - Operator
 FIMKT'S

LINE I
 PRESS CHART
 7-15-94
 0700 - 1500


1500 0700



$1100 - 0840 - 1040 = 37$

$1250 - 1500 = 38$

LINE 4
 PRESS CHART
 7-15-94
 1500-2300




1500 - 1550 = 16
 1500 - 1800 = 56

43


LINE I
SURFACE DRYER
CHART
7-15-94
0700-1900

0700
1900



LINE I
CORE DRYER
CHART
7-15-94
0700-1900

1900 0700



EFB READINGS

DATE 7/15

BY

PLANT: Hayward OSB Line I

1 OF 2

TIME	"A" SIDE				"B" SIDE				E	
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.	EFB PRESS.	BAG H. PRESS.
8:05	13	.01	36	1.8	5.0	.94	28	1.2	4.3 2.4	4.3
8:15	12.5	.01	36	1.4	12.0	.12	29	1.2	4.4 2.2	4.2
8:25	12.5	.01	37	1.5	12.0	.11	28	1.3	4.4 2.4	4.2
8:35	12.5	.01	37	1.3	12.0	.11	28.5	1.2	4.4 2.4	4.2
8:45	12.5	.01	36	1.3	12.0	.09	28.5	1.1	4.5 2.4	4.2
8:55	12.0	.01	36	1.3	11.5	.12	29	1.0	4.4 2.4	4.1
9:05	12.0	.02	36.5	1.4	11	.15	29	1.0	4.7 2.4	4.2
9:15	12.0	.02	32	.6	11.5	.16	30	1.0	4.6 2.2	4.2
9:25	11.5	.02	31	.7	11.5	.15	28	.6	4.2 2.2	4.1
9:35	11.5	.02	31	.6	11.5	.14	27.5	.6	4.4 2.2	4.1
9:45	11.0	.03	32	.6	12	.15	28	.6	4.2 2.4	4.3
9:55	11.0	.03	34	1.0	11.5	.12	29.5	.9	4.2 2.3	4.1
10:05	11.0	.03	34	1.0	12	.11	29.5	.9	4.2 2.2	4.2
10:15	11.5	.02	34	1.0	12	.12	30	1.0	4.2 2.2	4.1
10:25	11.5	.03	35	1.2	11.5	.14	30	1.0	4.2 2.2	4.2
10:35	10.5	.04	35	1.2	11.5	.13	30	1.0	4.1 2.5	4.2
10:45	11.0	.03	36	1.0	12	.12	30	1.0	4.3 2.2	4.0
10:55	11.0	.04	36	1.6	11.5	.14	30	1.0	4.1 2.4	4.1
11:05	11.5	.03	36	1.2	11.5	.15	28	1.6	4.1 2.3	4.1
11:15	11.0	.04	36	1.1	Down				4.4 1.8	4.1
11:25	11.5	.03	36	1.1	10.5	.22	26	1.5	4.2 3.2	4.1
11:35	11.5	.03	36	1.1	Down				4.1 2.5	4.1
11:45	11.0	.02	36	1.2	9.0	.32	No Reading		4.0 2.5	4.0
11:55	11.0	.02	36	1.1	11.0	.18	25	1.0	4.0 2.2	4.1
12:05	12.0	.02	35	1.0	10.5	.14	27	.95	4.0 2.6	4.1
12:15	11.5	.02	36	1.1	11	.17	27	.8	4.2 2.6	4.1
12:25	11.5	.03	36	1.0	11	.16	27.5	.6	4.2 2.7	4.1
12:35	12.0	.03	36	1.0	11	.16	27.0	.6	4.3 2.6	4.1
12:45	12.0	.01	35	1.2	11	.14	27.5	.6	4.3 2.4	4.1
12:55	13.5	.01	34	3.1	11.5	.10	27	.6	4.3 2.4	4.1

EFB READINGS

DATE 7/15/94
 BY _____

PLANT: Hayward OSB Line T

2 OF 2

TIME	*A* SIDE				*B* SIDE				C/S		BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.	EFB PRESS.		
1:05	12	.02	35	1.2	11.5	.12	30	.8	4.2	2.4	4.1
1:15	12	.02	36	1.1	11.5	.12	30	1.1	4.2	2.4	4.2
1:25	12	.02	37	1.1	11	.13	30	1.0	4.2	2.4	4.1
1:35	12	.02	36	1.0	10.5	.14	31	1.0	4.4	2.6	4.0
1:45	11	.02	35	1.2	10.5	.11	30	.8	4.4	2.6	4.0
1:55	12	.02	35	1.2	11	.11	30	.9	4.4	2.5	4.1
2:05	12	.02	36	1.2	11	.12	31	1.0	4.3	2.3	4.0
2:15	12	.02	36	1.2	11.5	.10	30	1.0	4.2	2.8	4.0
2:25	12	.02	36	1.0	11	.11	31	1.0	4.3	2.3	4.0
2:35	12	.02	36	1.0	11	.12	31	.9	4.4	2.4	4.1
2:45	12	.02	36	1.0	11	.09	30	1.0	4.3	2.4	4.1
2:55	12	.02	36	1.2	12	.07	30	1.0	4.4	2.5	4.0
3:05	12	.02	36	1.2	12	.07	30	1.0	4.2	2.5	4.1
3:15	12	.02	35	1.2	11.5	.08	28	.8	4.2	2.4	4.1
3:25	12	.01	36	1	11.5	.08	30	.9	4.2	2.4	4.2
3:35	12	.02	35	1.1	11.5	.08	30	1	4.2	2.4	4.1
3:45	12	.02	35	1	11.5	.08	30	1.2	4.1	2.4	4
3:55	12	.02	36	1	12	.08	31	1.1	4.1	2.3	4.2
4:05	12	.02	36	1.1	11.5	.08	31	1.1	4.1	2.6	4.2
4:15	13	.02	36	1.1	11.5	.07	30	1.0	4.2	2.4	4.2
4:20	12	.02	36	1.1	11.5	.07	30	1.0	4.2	2.6	4.0
4:30	12	.02	36	1.1	11.0	.07	31	1.2	4.1	2.4	4.0
4:40	12	.01	36	1.1	11.5	.07	31	1.2	4.0	2.4	4.0
4:55	12.5	.01	36	1.2	11.5	.09	32	1.2	4.2	2.4	4.1
5:05	12	.02	36	1.1	11.5	.09	32	1.2	4.0	2.2	4.1
5:15	11.5	.01	37	1.2	11.5	.09	32	1.2	4.1	2.4	4.1
5:25	12.5	.02	36.5	1.0	11.5	.09	32	1.2	4.2	2.4	4.1
5:35	12.5	.01	37	1.2	11.5	.10	32	1.2	4.2	2.8	4.2
5:45	12.5	.01	36	1.0	12	.09	32	1.4	4.3	2.6	4.1
5:55	12.5	.01	36	1.2	12	.09	30	1.0	4.2	2.6	4.1

JULY 15, 1994

10E2

HAYWARD LINE I DRYER RTO


TIME

#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ	GAS
8:00	471	471	496	464	5.1	1528	1561	242	1568	333	25.9	02872.4
.15	481	475	492	477	6.0	1547	1529	243	1572	341	25.2	02872.5
.30	475	478	491	475	5.0	1530	1561	243	1568	336	25.8	02872.7
.45	481	472	494	470	3.5	1552	2216	244	1575	330	26.1	02872.8
9:00	475	477	493	471	4.5	1533	1541	244	1570	339	25.7	02873.0
.15	482	478	490	479	4.2	1530	1535	244	1567	346	27.8	02873.1
.30	478	473	494	466	3.0	1546	1561	239	1577	329	26.4	02873.3
.45	474	469	494	461	4.1	1540	1564	230	1678	324	26.1	02873.5
10:00	471	468	490	463	3.9	1517	1541	231	1558	336	25.9	02873.6
.15	467	468	489	461	3.1	1525	1552	234	1564	333	27.5	02873.8
.30	467	467	489	459	4.5	1531	1559	235	1549	329	26.0	02874.0
.45	470	464	491	458	3.5	1552	1545	235	1576	325	24.6	02874.1
11:00	466	473	495	470	4.3	1514	1543	236	1555	337	25.7	02874.3
.15	465	487	472	483	4.5	1636	1554	237	1580	336	23.0	02874.5
.30	465	484	472	475	5.4	1503	1559	234	1593	331	25.3	02874.7
.45	470	489	470	488	3.7	1514	1547	232	1574	336	26.5	02874.8
12:00	473	488	470	486	3.5	1626	1555	226	1600	327	25.8	02874.9
.15	473	482	471	480	4.0	1561	1533	225	1585	327	25.4	02875.1
.30	458	489	472	464	5.6	1520	1548	232	1572	330	25.3	02875.3
.45	455	496	472	470	5.3	1504	1549	240	1590	329	25.2	02875.5
1:00	462	506	461	495	3.4	1511	1542	242	1564	340	25.8	02875.6
.15	470	498	464	496	5.2	1523	1530	244	1565	341	25.0	02875.8
.30	462	512	462	504	4.5	1497	1547	247	1571	366	24.6	02876.0
.45	475	531	440	511	4.3	1510	1542	247	1571	344	24.9	02876.1
2:00	474	520	446	523	3.7	1508	1541	248	1568	319	26.0	02876.3

HAWAIIAN LINE T DRYER RTO 2057 JULY 15, 1992

#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ	GAS
.15	431	480	578	418	597	4.1	1518	1517	248	371	24.7	228765
.30	426	481	566	411	579	4.1	1531	1566	249	359	24.7	028767
.45	442	482	551	419	556	3.8	1515	1556	250	355	25.2	028769
.30	455	479	536	429	535	5.1	1515	1544	250	354	25.2	028770
.15	459	489	522	439	525	4.2	1562	1535	250	342	25.0	028771
.30	465	486	523	413	529	5.2	1534	1588	251	345	24.7	028774
.45	465	483	533	442	512	5.7	1515	1549	253	341	24.8	028776
.40	457	481	538	434	540	5.0	1514	1546	254	356	25.2	028778
.15	466	483	523	441	520	4.7	1526	1562	254	352	24.9	28779
.30	468	490	517	416	525	5.0	1545	1538	254	347	25.0	28781
.45	474	490	508	452	511	3.9	1556	1539	254	345	24.2	28783
.50	478	483	511	453	507	3.9	1617	1565	255	353	25.0	28185
.15	481	495	571	418	602	5.5	1535	1546	255	337	24.9	28788
.30	482	494	568	412	590	5.3	1514	1542	255	345	25.0	28188
.45	444	497	541	421	555	5.5	1561	1533	255	341	24.7	28790
.60												
.15												
.30												
.45												
.70												

DRYER RTD CHART
7-15-94



3075517
HONEYWELL
DRYER
Truline
WASHINGTON, PA U.S.A.

3075517
HONEYWELL
DRYER
Truline
WASHINGTON, PA U.S.A.

HAYWARD OSB
 LINE I
 JULY 15, 1994

FLAKE MOISTURE

	WET	DRY
8:00 AM	C 47.5 S 47.6	C 3.6 S 3.2
9:00 AM	C 54.6 S 54.0	C 6.7 S 3.4
10:00 AM	C 49.3 S 46.4	C 11.4 S 5.2
11:00 AM	C 48.6 S 48.2	C 6.8 S 4.0
12:00 PM	C 44.6 S 48.2	C 4.2 S 11.2
1:00 PM	C 44.8 S 46.0	C 2.8 S 3.2
2:00 PM	C 48.8 S 47.2	C 3.0 S 3.8
3:00 PM	C 46.6 S 46.4	C 3.6 S 5.2
4:00 PM	C 46.8 S 45.0	C 3.6 S 3.8
5:00 PM	C 47.6 S 48.4	C 2.8 S 5.0
6:00 PM	C 45.8 S 46.6	C 3.0 S 2.6

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)

7/16

206	188	196	186	200	194.3 lb=average
206	186	192	192	200	untrimmed
198	194	190	190	200	mat weight
202	192	194	198	194	
196	192	198	194	192	179.7 lb=average
194	188	194	196	196	finished board
192	190	202	200	194	weight
190	184	198	198	192	(untrimmed mat
198	190	186	196	196	weight-weight
198	180	194	190	188	of trim)
196	196	194	206	194	

7.5% =trim %

PLANT PRODUCTION RATE

- 6.33 =hours during testing
- 111 =pressloads
- 1332 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 239,387 =lbs of finished product (boards produced x weight of finished board)
- 37798 =lbs of finished product per hour (lbs of finished product / hours)
- 18.90 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 2318 =SURFACE counts during testing hours
- 23180 =SURFACE lbs of fuel burned during testing
- 6.33 =hours during testing
- 3660 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.83 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 31.5 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1090 =average inlet temperature
- 46.1% =average incoming moisture percent
- 5.5% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 2642 =CORE counts during testing hours
- 26420 =CORE lbs of fuel burned during testing
- 6.33 =hours during testing
- 4172 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.09 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 35.9 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1317 =average inlet temperature
- 46.1% =average incoming moisture percent
- 4.5% =average dry moisture percent

DRYER THROUGHPUT RATE

- 7832 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 37798 =lbs of finished product per hour (lbs of finished product / hours)
- 45630 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 3065 = weight of trim per hour at 7.5% of finished product
- 4767 =weight of screened fines per hour (total fuel - trim)
- 10.45% =resulting loss to fines as percentage of dryer throughput

LINE 2 DRYER TESTING JULY 12, 1994
DATA TIME: START= 18:20

VOC, Formaldehyde
END= 23:00 HOURS= 4.67

4.67

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)
7/16

192	204	184	196	190.75 lb=average untrimmed mat weight
190	198	188	188	
184	192	184	186	
180	208	192	192	
186	190	178	184	176.4 lb=average finished board weight (untrimmed mat weight-weight of trim)
180	192	190	186	
190	200	188	190	
194	200	196	188	
200	194	190	188	
196	194	194	184	7.5% =trim %

PLANT PRODUCTION RATE

- 4.67 =hours during testing
- 83 =pressloads
- 996 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 175,734 =lbs of finished product (boards produced x weight of finished board)
- 37657 =lbs of finished product per hour (lbs of finished product / hours)
- 18.83 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 1644 =SURFACE counts during testing hours
- 16440 =SURFACE lbs of fuel burned during testing
- 4.67 =hours during testing
- 3523 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.76 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 30.3 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1093 =average inlet temperature
- 47.6% =average incoming moisture percent
- 5.5% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 1779 =CORE counts during testing hours
- 17790 =CORE lbs of fuel burned during testing
- 4.67 =hours during testing
- 3812 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.91 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 32.8 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1291 =average inlet temperature
- 47.6% =average incoming moisture percent
- 4.8% =average dry moisture percent

DRYER THROUGHPUT RATE

- 7335 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 37657 =lbs of finished product per hour (lbs of finished product / hours)
- 44992 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 3053 = weight of trim per hour at 7.5% of finished product
- 4282 =weight of screened fines per hour (total fuel - trim)
- 9.52% =resulting loss to fines as percentage of dryer throughput

OPERATOR WAS SCATEL SHIFT 10 A.M.S GEN 10 DATE 2-12-54
 THICKNESS: 1/2 7/16 PRESS LOADS 8 1/2 19.5 1/4
 OVERALL TMR: 170-144 DECOMPRESSION TIME 15-12
 PRESS TEMP: 210 TOTAL REELS: =
 LOG COUNT: 7313

LINE SPEED	FROM	TO
53	7:29	
57	7:25	
50	7:43	
67	8:58	
50	9:34	
62	9:59	

F.C.O.S. HD RADIATOR 10:00 II
 Cleaned Blender Struts & Tracks =
 Cleaned Decile Chains =
 Press Blow Down 10:00
 Headers Cleaned = YES/NO =
 How Many =
 Former Hyd Radiator = Time

DOWNTIME		DOWNTIME (Mins)			X E Y I	REASONS FOR DOWNTIME
FROM	TO	H	E	O		
10:58	11:59				1	#6 TAKEOVER
2:20	2:21				1	DROPPED H.B. #4 LOADER
17:35	12:36				1	DELAY AT SAWS
1:45	1:48				3	BAG-HOUSE DOWN
6:40						DELAY AT SAW, UNIT TAKEN ON TRACK
-	-	-	-	-	-	

Downtime Code: M - Mechanical E - Electrical O - Operator

OPERATOR Halsverson SHIFT 2nd CON B DATE 7-12-94
 THICKNESS: 7/10 PRESS LOADS 210^{7/10}
 OVERALL TIMER: 143 DECOMPRESSION TIME 12/
 PRESS TEMP: 210 TOTAL REBBS: 1
 LOG COUNT: 7684

LINE SPEED	FROM	TO
62 f	7:00	4:00
60 f	4:00	5:30
12 f	5:30	7:00

moisture

F.C.O.S. HD RADIATOR II
 Cleaned Blender Strands & Bands
 Cleaned Debris Chain
 Press Allow Down
 Headers Cleaned YES/NO
 How Many 1
 Former Hyd Radiator Time

DOWNTIME		DOWNTIME (Mins)			X E O	REASONS FOR DOWNTIME
FROM	TO	M	E	O		
2:38	3:39	1				Lug-drive dropped screen #8
5:40	1:42	2				Screen billed up on cone #4
6:05	1:07	2				" " " cone #5
6:30	1:31	1				Delay at SAWS

Downtime Code: M - Mechanical E - Electrical O - Operator

LINE II
 PRESS CHART
 7-12-94
 0700 - 1500

1500 8:00 0700

1400

10800


300

1000000


1200

1100

1000-1500 = 88




LINE 4
 PRESS CHART
 1500 - 1900
 7-12-94



LINE II
PRESS CHART
7-12-94
1900-0300

8/1900




1900-2300 = 72

2300


60

HAYWARD DRYERS
LINE II JULY 12+13


LINE II
SURFACE DRYER
CHART
7-12-94
0700 - 1900




LINE II
CORE DRYER
CHART
7-12-94
0700-1900



LINE II
SURFACE DRYER
CHART
7-12-94
1900 - 0700



LINE II
CORE DRYER
CHART
7-12-94
1900 - 0700



EVERY 10 MINUTES

EFB READINGS

DATE JULY 12, 1994

BY _____

PLANT: HAYWARD

SOURCE: LINE II

readings every 10 minutes

C S

A.m

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
8:40	12	.01	20.1	2	28 12	.01	28	1.8	4.2/4.1	2.1
8:50	12.5	.01	22	1	12.5	.01	28	1.5	4.2/4.1	2
9:00	12.5	.01	22	1.5	12.5	.01	28	1.5	4.2/4.1	2
9:10	12.5	.01	21	1	13	.01	28	1.5	4.2/4.1	2
9:20	12.5	.01	21	1	12.5	.01	28	1	4.1/4	2
9:30	12.5	.01	22	1.5	13	.01	29	1.5	4.2/4.2	2
9:40	12.5	.01	22	1.5	12.5	.01	28	1	4.2/4.2	2
9:50	12.5	.01	22	1	12	.01	28	1	4.2/4.2	2
10:00	12.5	.01	22	1	12.5	.01	28	1	4.1/4.1	2
10:10	13	.01	22	1.5	12	.01	25	1	4.2/4.2	2
10:20	13	.01	22	1	12	.01	26	1	4.2/4.2	2
10:30	13	.01	22	1	12.5	.01	26	1	4.2/4.2	2
10:40	13	.01	22	1	12	.01	26	1	4.2/4.2	2
10:50	12.5	.01	22	1	12.5	.01	0	.01	4.2/4.3	2
11:00	12.5	.01	21.5	1	12	.01	26	1	4.2/4.2	2
11:10	12	.01	22	1	12	.01	26	1	4.3/4.4	2
11:20	12.5	.01	26	1	12.5	.01	26	1	4.3/4.4	2
11:30	12.5	.01	26	1	12	.01	0	.01	4.3/4.3	2
11:40	12	.01	28	1	12	.01	28	1	4.4/4.2	2
11:50	12	.01	28	1	12	.01	28	1.5	5/4.3	2
12:00	12.5	.01	28	1.5	12.5	.01	28	1.5	5.1/4.5	2
12:10	12.5	.01	28	1	12.5	.01	28	1.5	5.1/4.4	2
12:20	12.5	.01	28	1.5	12.5	.01	28	1.5	5.2/4.4	2
12:30	12.5	.01	28	1	12.5	.01	28	1.5	5.3/4.4	2
12:40	12.5	.01	28	1	12.5	.01	28	1.5	5.3/4.2	2
12:50	12	.01	28	1	12.5	.01	28	1.5	5.5/4.5	2
1:00	12	.01	28	1.5	12.5	.01	28	1.5	5.5/4.3	2
1:10	12	.01	28	1	12.5	.01	28	1.5	6/4.3	2
1:20	12	.01	28	1.5	12.5	.01	28	1.5	6.1/4.4	2
1:30	12	.01	28	1.5	12.5	.01	0	.01	6.2/4.3	2

P.m.

EFB READINGS

DATE July 12, 1994

BY _____

PLANT: Hayward

SOURCE: Line II

readings every 10 minutes

C S

P.M.

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
1:40	12	.01	28	1.5	12.5	.01	28	1.5	6.4/5	2
1:50	12	.01	28	1.5	12.5	.01	28	1.5	6.4/4.4	2.1
2:00	12	.01	28	1.5	13	.01	26	1	7/4.1	2
2:10	12	.01	28	1.6	13	.01	28	1.5	7.1/4.4	2
2:20	12	.01	18	1	12.5	.01	28	1.6	7.2/4.4	2
2:30	12	.01	18	1.9	12.5	.01	28	1.8	7.4/4.4	2
2:40	12	.01	18	1	12.5	.01	28	1.8	7.3/4.3	2.1
2:50	12	.01	18	.09	12.5	.01	28	1.8	6.3/4.4	2.2
3:00	12.5	.01	18	.06	12.5	.01	28	1.5	6.1/4.4	2.1
3:10	12.5	.01	28	1.5	12.5	.01	28	1.5	6/5	2
3:20	12.5	.01	28	1.5	12.5	.01	28	1.5	6/5	2
3:30	12.5	.01	30	1.8	13	.01	28	1.5	5.4/4.3	2
3:40	12.5	.01	29	1.8	13	.01	28	1.5	6/4.3	2
3:50	12.5	.01	30	1.8	13	.01	28	1.5	6/4.4	1.9
4:00	12	.01	30	1.5	13	.01	28	1.5	6/4.4	2
4:10	12.5	.01	30	1.5	12.5	.01	28	1.5	5.4/4.4	2
4:20	12.5	.01	30	1.5	12.5	.01	0	.01	5.4/4.2	1.9
4:30	12	.01	30	1.5	12.5	.01	26	1	5.4/4.3	1.9
4:40	12.5	.01	30	1.5	13	.01	26	1	5.3/4.3	1.9
4:50	12.5	.01	30	1.5	13	.01	26	1	5.4/4.4	2
5:00	12.5	.01	30	1.5	12.5	.01	26	1	5.3/4.4	2
5:10	12.5	.01	29	1.5	12.5	.01	28	1	5.3/4.2	2
5:20	12.5	.01	29	1.5	12.5	.01	0	^{1.5} 0	5.3/4.3	1.9
5:30	12.5	.01	29	1.5	12.5	.01	28	1	5.3/4.4	1.9
5:40	12.5	.01	29	1.5	13	.01	29	1	5.4/4.4	1.9
5:50	12	.01	30	1.5	12.5	.01	29	1	5.3/4.4	1.9
6:00	12.5	.01	30	1.5	13	.01	28	1	5.2/4.3	2
6:10	12.5	.01	29	1.5	13	.01	0	.01	5.3/4.3	1.9
6:20	12.5	.01	30	1.5	13	.01	28	1.5	5.3/4.3	1.9
6:30	12.5	.01	30	1.5	13	.01	28	1.5	5.3/5	1.9

EFB READINGS

DATE July 12, 1994
BY _____

PLANT: Hayward
SOURCE: Line II

readings every 10 minutes
C S

P.M.

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
6:40	12.5	.01	30	1.5	13	.01	28	1	5.3/4.4	2
6:50	12.5	.01	30	1.5	13	.01	28	1	5.2/4.3	2
7:00	13	.01	30	1.5	13	.01	28	1	5.3/4.3	1.9
7:10	12.5	.01	30	1.5	13	.01	28	1	5.2/4.3	2
7:20	12.5	.01	30	1.5	13	.01	28	1	5.2/5	2
7:30	12.5	.01	30	1.5	13	.01	28	1	5.2/4.3	1.9
7:40	12	.01	30	1.5	13	.01	28	1	5.2/4.4	2
7:50	12	.01	30	1.5	13	.01	28	1	5.3/4.4	1.9
8:00	12	.01	30	1.5	13	.01	28	1	5.3/4.4	1.9
8:10	12	.01	30	1.5	13	.01	28	1	5.2/5	2
8:20	12	.01	30	1.5	13	.01	28	1	5.2/4.4	1.9
8:30	12	.01	30	1.5	12	.01	28	.01	5.2/4.2	2
8:40	12.5	.03	31	1.4	13	.05	28	1.2	5.5/4.5	1.8
8:50	12	.02	30	1.5	13	.05	29	1	5.3/4.2	2
9:00	12	.04	30	1.5	13	.04	28	1.1	5.2/4.4	1.8
9:10	12.5	.03	31	1.4	12	.05	28	1	5.3/4.2	2
9:20	12	.04	31	1.5	13	.05	28	1	5.4/4.5	2
9:30	12.5	.03	31	1.4	13	.04	27	1.2	5.5/4.5	1.8
9:40	12	.04	30.5	1.4	12.5	.05	29	1.3	5.5/4.5	1.7
9:50	12.5	.04	31	1.5	12.5	.05	28	1.2	5.5/4.7	1.8
10:00	12.5	.04	30.5	1.4	12.5	.07	28.5	1.2	5.7/4.5	1.7
10:10	12.3	.03	31	1.4	12.5	.04	28	1.1	5.6/4.8	1.7
10:20	12.5	.03	30	1.4	12.6	.05	28.5	1.2	5.7/5.0	1.6
10:30	12.5	.03	31	1.4	13	.05	28	1.3	5.7/4.8	1.7
10:40	12.5	.03	30	1.4	13	.04	28	1.2	5.8/4.5	1.8
10:50	12.5	.03	31	1.4	13.5	.05	29	1.3	5.7/4.8	1.7
11:00	12.6	.025	31	1.4	13	.04	28	1.2	5.6/4.6	1.7
11:10	12.5	.02	31	1.4	13	.04	28	1.4	5.6/4.7	1.8
11:20										
11:30										

LINE II DRYER RTO (EVERY 15 MINUTES)

JULY 16, 1991

	#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ	GAS
05	446	517	413	469	491	5.2	1576	1536	214	1596	319	23.0	-
10	462	496	459	470	483	5.4	1527	1544	221	1582	341	23.3	
15	457	516	445	482	476	5.7	1570	1536	233	1631	319	23.2	
20	448	521	455	467	504	5.2	1581	1533	224	1598	324	22.2	
25	465	501	467	470	491	5.3	1528	1541	225	1586	347	23.1	
30	462	512	457	480	480	5.4	1555	1541	225	1617	332	23.1	
35	448	529	454	471	501	6.3	1578	1527	225	1626	319	23.0	
40	465	502	472	468	495	5.3	1527	1544	225	1592	348	23.0	
45	464	511	462	478	483	5.3	1557	1544	225	1624	324	23.0	
50	450	524	463	465	510	5.2	1579	1533	225	1599	325	23.1	
55	454	516	470	461	512	4.8	1576	1536	225	1590	330	23.2	
60	462	516	458	479	483	5.7	1567	1538	224	1629	327	22.8	
65	451	528	456	473	497	5.2	1577	1522	223	1625	319	23.0	
70	451	522	465	462	511	5.6	1675	1533	223	1588	325	23.0	
75	466	508	466	474	485	5.0	1558	1541	223	1603	337	22.7	
80	458	524	454	480	484	5.4	1556	1540	224	1637	324	22.5	
85	453	532	452	480	490	3.9	1585	1528	224	1633	323	22.7	
90	462	511	471	468	500	2.6	1518	1541	225	1578	348	22.6	
95	460	524	456	483	484	5.5	1553	1549	225	1637	327	21.7	
100	455	532	454	482	488	6.3	1582	1538	226	1643	325	22.0	
105	459	516	472	467	506	5.3	1516	1535	225	1568	350	22.1	
110	464	517	466	478	488	5.1	1532	1542	225	1596	340	21.5	
115	446	542	453	476	503	5.1	1578	1524	225	1612	319	21.3	
120	456	521	469	468	509	5.2	1534	1538	224	1570	253	21.3	
125	453	525	469	467	511	5.6	1545	1541	225	1576	250	21.8	

July 12, 1994

EVERY 15 MINUTES

LINE II ARYER RTO


#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ TEMP.	GAS
448	543	450	480	498	5.4	1575	1521	225	1618	319	22.6	-
445	543	453	475	505	6.2	1581	1527	225	1613	320	22.2	
446	539	457	471	511	5.7	1581	1525	225	1593	327	22.4	
463	516	466	477	491	5.1	1533	1540	226	1589	347	22.4	
447	537	459	471	512	5.6	1584	1531	226	1603	325	22.3	
461	515	473	468	506	4.2	1517	1544	227	1580	350	22.7	
455	534	454	482	492	5.4	1571	1532	226	1640	325	22.7	
448	540	457	473	509	6.1	1581	1520	226	1601	322	22.3	
457	519	473	466	513	4.6	1523	1541	226	1576	353	22.6	
464	515	470	473	496	4.9	1531	1541	225	1598	347	22.4	
448	537	460	470	515	5.5	1584	1531	225	1603	326	22.3	
463	513	475	468	508	4.0	1514	1537	226	1573	350	22.8	
466	516	467	479	491	4.6	1542	1562	226	1613	339	22.6	
453	537	455	480	502	5.2	1568	1521	225	1622	323	22.1	
465	518	464	481	490	5.6	1550	1548	226	1619	337	22.6	
468	511	470	477	495	5.0	1532	1539	226	1589	344	22.6	
451	534	460	474	509	5.1	1576	1520	226	1613	320	22.6	
451	529	465	468	518	5.5	1581	1529	226	1605	326	22.6	
459	512	477	464	519	4.5	1637	1541	226	1579	351	22.6	
463	518	463	480	491	5.6	1540	1544	226	1631	332	22.6	
453	522	469	464	521	5.5	1579	1536	225	1595	328	22.9	
468	505	475	470	503	4.7	1525	1541	226	1581	352	22.4	
467	508	470	474	497	4.8	1536	1639	225	1590	341	22.8	
459	520	460	478	495	5.6	1568	1542	225	1639	326	23.0	
455	515	475	459	523	5.5	1565	1537	225	1575	336	23.1	

July 12, 1994

LINE II ARPER RTO (EVERY 15 MINUTES)

#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	TEMP.	GAS
5	464	502	481	463	5.1	1518	1539	225	1574	346	23.1	-
30	450	517	474	459	4.8	1574	1529	224	1579	330	23.2	
15	458	505	479	461	4.4	1621	1540	224	1673	347	23.1	
15	461	512	465	477	5.2	1655	1647	225	1617	335	22.7	
15	446	529	463	469	6.2	1578	1623	224	1603	319	22.8	
30	446	529	462	470	6.1	1575	1522	225	1605	318	22.9	
15	461	513	464	478	5.5	1555	1549	224	1622	334	22.9	
30	463	504	477	467	5.7	1518	1540	225	1575	349	23.1	
15	464	504	476	468	4.5	1524	1536	225	1578	350	22.6	
30												
45												
60												

LINE II
DRYER RTO CHART
7-12-94



HAYWARD OSB
 LINE II
 JULY 12, 1994

SECONDARIES

CORE				SURFACE			
TIME	BARREL FULL	BARREL EMPTY	TOTAL WEIGHT	TIME	BARREL FULL	BARREL EMPTY	TOTAL WEIGHT
10:17	STARTING TIME			10:17	STARTING TIME		
10:47	39.0	18.4	20.6	10:47	52.2	31.2	21.0
11:17	54.2	33.8	20.4	11:17	52.6	31.4	21.2
11:47	38.4	18.4	20.0	11:47	53.9	31.2	22.7
12:17	53.2	33.6	19.6	12:17	52.2	31.4	20.8
12:47	36.2	18.4	17.8	12:47	51.7	31.2	20.5
1:17	52.7	33.2	19.5	1:17	49.4	31.4	18.0
1:47	36.0	18.2	17.8	1:47	51.8	31.2	20.6
2:17	49.4	32.6	16.8	2:17	49.2	31.4	17.8
2:47	34.6	18.4	16.2	2:47	50.4	31.2	19.2
3:17	49.6	31.8	17.8	3:17	52.8	31.4	21.4
3:47	34.6	18.4	16.2	3:47	50.2	31.2	19.0
4:17	49.6	31.8	17.8	4:17	51.2	31.4	19.8

36.75

40.33

75

HAYWARD OSB
 LINE II
 JULY 12, 1994

FLAKE MOISTURE

	WET	DRY
8:00 AM	C 44.4 S 47.9	C 5.8 S 5.6
9:00 AM	C 46.3 S 45.3	C 5.4 S 5.7
10:00 AM	C 43.6 S 42.0	C 4.0 S 5.6
11:00 AM	C 44.0 S 45.9	C 4.5 S 5.3
12:00 PM	C 48.7 S 45.3	C 6.0 S 4.9
1:00 PM	C 46.5 S 47.4	C 5.2 S 5.9
2:00 PM	C 48.4 S 48.2	C 3.9 S 5.7
3:00 PM	C 47.8 S 47.3	C 3.8 S 4.9
4:00 PM	C 45.0 S 44.4	C 3.8 S 6.0
5:00 PM	C 48.9 S 45.6	C 3.4 S 4.4
6:00 PM	C 47.5 S 44.8	C 4.8 S 4.5
7:00 PM	C 47.6 S 44.7	C 5.2 S 4.7
8:00 PM	C 48.6 S 48.1	C 4.3 S 5.6
9:00 PM	C 50.1 S 48.3	C 4.9 S 4.5
10:00 PM	C 48.4 S 47.9	C 5.2 S 6.0
11:00 PM	C 45.1 47.5	C 4.6 S 6.7

AVERAGE 46.6

JULY 12, 1968

LINE II
PRESS WTS
7/16
TRIM %

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

2296
2136 AFTER SAWS
160 lbs trim
7.5%

LINE 2 DRYER TESTING JULY 13, 1994 PHENOL
 DATA TIME: START= 08:40 END= 14:00 HOURS= 5.33

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)
 7/16

194	184	194	184	186	190.4 lb=average
196	192	186	190	184	untrimmed
190	192	192	190		mat weight
194	198	190	190		
182	192	190	194	176.1 lb=average	finished board
198	190	188	194		weight
192	196	192	192		(untrimmed mat
196	160	192	192		weight-weight
190	196	190	188		of trim)
192	198	190	190		
188	190	192	188		

7.5% =trim %

PLANT PRODUCTION RATE

- 5.33 =hours during testing
- 90 =pressloads
- 1080 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 190,199 =lbs of finished product (boards produced x weight of finished board)
- 35662 =lbs of finished product per hour (lbs of finished product / hours)
- 17.83 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 2033 =SURFACE counts during testing hours
- 20330 =SURFACE lbs of fuel burned during testing
- 5.33 =hours during testing
- 3812 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.91 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 32.8 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1108 =average inlet temperature
- 46.9% =average incoming moisture percent
- 5.4% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 1960 =CORE counts during testing hours
- 19600 =CORE lbs of fuel burned during testing
- 5.33 =hours during testing
- 3675 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.84 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 31.6 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1127 =average inlet temperature
- 46.9% =average incoming moisture percent
- 6.6% =average dry moisture percent

DRYER THROUGHPUT RATE

- 7487 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 35662 =lbs of finished product per hour (lbs of finished product / hours)
- 43149 =Pounds of material produced by the dryer per hour (dry basis, assumming fuel balances)
- 2892 = weight of trim per hour at 7.5% of finished product
- 4595 =weight of screened fines per hour (total fuel - trim)
- 10.65% =resulting loss to fines as percentage of dryer throughput

78

LINE 2 DRYER TESTING JULY 13, 1994 POM
 DATA TIME: START= 08:40 END= 17:20 HOURS= 8.67

BOARD WEIGHTS - LBS

weights of approximately every 25th untrimmed board (from press tapes)

194	192	192	190	192	198	
196	192	190	194	196	202	191.5 lb=average
190	198	190	194	188	196	untrimmed
194	192	188	192	192	194	mat weight
182	190	192	192	192	186	
198	196	192	188	190	194	177.1 lb=average
192	160	190	190	188	194	finished board
196	196	190	188	194	198	weight
190	198	192	186	196	188	(untrimmed mat
192	190	184	184	206	192	weight-weight
188	194	190	188	196	192	of trim)
184	186	190	186	198	192	

7.5% =trim %

PLANT PRODUCTION RATE

- 8.67 =hours during testing
- 146 =pressloads
- 1752 =no. of 8'x16' boards produced (pressloads x 12 boards per load)
- 310,297 =lbs of finished product (boards produced x weight of finished board)
- 35803 =lbs of finished product per hour (lbs of finished product / hours)
- 17.90 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

SURFACE

- 10 =SURFACE fuel calibration in pounds per count
- 3274 =SURFACE counts during testing hours
- 32740 =SURFACE lbs of fuel burned during testing
- 8.67 =hours during testing
- 3778 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.89 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 32.5 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1099 =average inlet temperature
- 46.9% =average incoming moisture percent
- 5.5% =average dry moisture percent

CORE

- 10 =CORE fuel calibration in pounds per count
- 3362 =CORE counts during testing hours
- 33620 =CORE lbs of fuel burned during testing
- 8.67 =hours during testing
- 3879 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 1.94 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8600 =estimated BTU content per pound of dry fuel,
- 33.4 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1174 =average inlet temperature
- 46.9% =average incoming moisture percent
- 5.5% =average dry moisture percent

DRYER THROUGHPUT RATE

- 7657 =Total pounds of fuel burned per hour in Core and Surface Dryer
- 35803 =lbs of finished product per hour (lbs of finished product / hours)
- 43460 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 2903 = weight of trim per hour at 7.5% of finished product
- 4754 =weight of screened fines per hour (total fuel - trim)
- 10.94% =resulting loss to fines as percentage of dryer throughput

OPERATOR Lester SHIFT 7am - 7pm CSM A DATE 7-13-

THICKNESS: 7/652 PRESS LOADS 203

OVERALL TIMER: 143 DECOMPRESSION TIME 12

PRESS TEMP: 210° TOTAL REVERS: 0

LINE SPEED	FROM	TO
62	7:00	7:00

LOG COUNT: 7144

F.C.O.S. HD RADIATOR 10115

Classed Header Screens & Blades

Classed Double Cones

Press Blow Down 9:45

Header Guard YES/NO

How Many


Former End Radiator

$3/8 = 363,786$

DOWNTIME		DOWNTIME (Mins)			X E Y	REASONS FOR DOWNTIME
FROM	TO	M	E	O		
8:30	1:37	✓			5	Board stuck in press #1.
8:43	1:45	✓			2	Equalizer feed chine limit worn/broken.
9:33	1:36	✓	-		3	Screen walked up #3B cone.
3:12	1:17	✓			5	Screen slipping #4 cone. *
3:31	1:33	✓			2	" " " " *
4:32	1:34	✓			2	" " " " *
5:52	1:54	✓			2	" " " " *
6:01	1:03	✓			2	" " " " *
						* Screens slipping due to oil
						flowing from press and
						saturating the belts on 3A, 3B,
						and #4 cones.

Downtime Code: M - Mechanical E - Electrical O - Operator


LINE II
 PRESS CHART
 7-13-94
 0700 - 1500



0840-1400 = 90
 0840-1500 = 108

81

LINE II
PRESS CHART
7-13-94
1500 - 2300



$1500 - 1720 = 38$

82

DATE JULY 13 1999

Hayward Dryer Testing

LINE II

FUEL CALIBRATION: face= lb/count core= lb/count

Table with columns: TIME, FACE (OUT.SET POINT, FEED RATE, INLET TEMP, OUTLET TEMP, FUEL COUNT, WET BIN LEVEL), CORE (OUT.SET POINT, FEED RATE, INLET TEMP, OUTLET TEMP, FUEL COUNT, WET BIN LEVEL), DRY BIN (FACE, LEVEL, CORE), EVERY HOUR FLAKE MOISTURE (FACE OUT, CORE OUT).

00 00

Hayward Dryer Testing Line II

DATE 7-13-94

BY


FUEL CALIBRATION: face = lb./count core = lb./count

PAGE 2 OF 2


TIME	FACE			FACE			CORE			CORE			CORE			WET BIN		CORE		DRY BIN		EVERY HOUR		
	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	FACE WET BIN LEVEL	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	WET BIN LEVEL	OUT. SET POINT	FEED RATE	INLET TEMP	OUTLET TEMP	FUEL COUNT	WET BIN LEVEL	FACE	LEVEL	FACE	LEVEL	FLAKE MOISTURE	FLAKE MOISTURE
13:00	263	46	1079	261	2110	80	280	45	1156	279	2162	80	280	45	1156	279	2162	80	85	70				
13:10	263	47	1092	262	2175	80	281	45	1168	280	2228	75	281	45	1168	280	2228	75	85	70				
13:20	263	47	1097	261	2244	70	281	46	1170	281	2297	70	281	46	1170	281	2297	70	85	70				
13:30	263	46	1089	262	2307	75	281	46	1150	278	2360	70	281	46	1150	278	2360	70	85	70				
13:40	263	47	1074	261	2376	75	281	46	1170	279	2429	75	281	46	1170	279	2429	75	85	70				
13:50	263	47	1083	261	2436	80	281	45	1155	279	2492	80	281	45	1155	279	2492	80	85	70				
14:00	263	47	1076	261	2497	85	281	46	1166	280	2556	85	281	46	1166	280	2556	85	85	70				
14:10	263	47	1068	261	2560	85	281	46	1184	280	2626	85	281	46	1184	280	2626	85	85	70				
14:20	263	46	1081	261	2623	85	281	45	1196	281	2694	85	281	45	1196	281	2694	85	85	70				
14:30	263	47	1107	262	2685	85	281	45	1209	281	2763	85	281	45	1209	281	2763	85	85	70				
14:40	263	47	1109	261	2752	80	281	46	1219	280	2833	85	281	46	1219	280	2833	85	85	70				
14:50	263	46	1088	260	2816	80	281	45	1204	280	2901	85	281	45	1204	280	2901	85	85	65				
15:00	263	46	1098	261	2879	85	280	46	1209	280	2969	85	280	46	1209	280	2969	85	85	65				
15:10	263	47	1135	261	2947	85	280	47	1208	279	3038	80	280	47	1208	279	3038	80	85	70				
15:20	263	46	1142	262	3012	80	280	46	1257	280	3108	80	280	46	1257	280	3108	80	85	70				
15:30	263	46	1160	261	3075	75	280	46	1280	280	3179	85	280	46	1280	280	3179	85	85	70				
15:40	263	46	1135	261	3144	80	280	46	1266	279	3252	80	280	46	1266	279	3252	80	85	70				
15:50	262	44	1178	262	3212	85	280	47	1257	279	3320	85	280	47	1257	279	3320	85	85	75				
16:00	262	42	1140	259	3276	80	279	46	1259	279	3388	85	279	46	1259	279	3388	85	85	75				
16:10	262	41	1096	260	3333	80	279	46	1280	279	3458	85	279	46	1280	279	3458	85	85	75				
16:20	263	40	1059	260	3393	80	279	46	1279	279	3533	80	279	46	1279	279	3533	80	85	76				
16:30	263	39	1053	262	3452	80	279	47	1278	278	3602	85	279	47	1278	278	3602	85	85	75				
16:40	263	39	1025	260	3507	80	279	46	1302	278	3674	85	279	46	1302	278	3674	85	85	75				
16:50	265	37	1009	263	3562	85	279	47	1295	278	3744	85	279	47	1295	278	3744	85	85	75				
17:00	265	38	1021	261	3622	85	279	46	1287	279	3815	85	279	46	1287	279	3815	85	85	75				
17:10	265	38	1014	263	3680	85	279	46	1268	277	3885	85	279	46	1268	277	3885	85	85	80				
17:20	265	38	998	261	3738	85	279	45	1271	277	3959	85	279	45	1271	277	3959	85	85	80				
17:30																								
17:40																								
17:50																								

22

LINE II
CORE DRYER
CHART
7-13-94
0700 - 1900



LINE II
SURFACE DRYER
CHART
7-13-94
0700 - 1900



EFB READINGS

DATE 7-13-94

BY _____

PLANT: - Hayward - LINE II

C/S

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
8:10	11.5	.01	30	1.5	12	.01	20	2	5/4.2	2
8:20	12	.01	30	1.5	12.5	.01	22	1.5	5.1/4.2	2
8:30	11	.01	30	1.5	12.5	.01	24	2	5/4.3	2
8:40	12	.01	30	1.5	12.5	.01	22	2	5.1/4.3	2
8:50	12	.01	30	1.5	13	.01	24	2	5/4.3	2
9:00	11.5	.01	30	1.5	12.5	.01	26	2	5/4.1	1.9
9:10	12	.01	28	3	12.5	.01	26	2	5/4.3	1.9
9:20	11.5	.01	28	3	12.5	.01	26	2	5/4.3	1.9
9:30	12	.01	28	3	12.5	.01	26	2	4.4/4.3	1.9
9:40	11.5	.01	28	3	13	.01	26	2	5/4.2	1.9
9:50	12	.01	28	3	13	.01	26	2	5/4.4	2
10:00	12	.01	30	2.5	13	.01	26	2	5/4.3	1.9
10:10	11.5	.01	28	2.5	13	.01	26	2	5/4.3	1.9
10:20	12	.01	28	3	13	.01	28	2	5/4.3	1.9
10:30	12	.01	28	2.5	13	.01	26	2	5/4.3	1.9
10:40	11.5	.01	28	2.5	12.5	.01	26	2	5/4.4	1.9
10:50	11	.01	30	2.5	13	.01	28	2	5/4.3	1.9
11:00	11	.01	30	2	13	.01	26	2	5/4.4	2
11:10	10	.01	30	2.5	13	.01	28	2	5/4.2	2
11:20	12	.01	30	2.5	13	.01	28	1.9	5/4.2	1.9
11:30	12	.01	30	2	12.5	.01	28	1.5	4.4/4.4	2
11:40	11.5	.01	30	2	13	.01	28	2	5/4.3	1.9
11:50	12	.01	30	2	13	.01	28	2	5/4.2	1.9
12:00	12	.01	30	2	13	.01	28	1.5	5/4.3	1.9
12:10	11.5	.01	30	2	13	.01	28	1.5	5/4.4	1.9
12:20	11.5	.01	30	2	13	.01	28	1.9	5/5	1.9
12:30	12	.01	30	2	13	.01	28	1.5	5/4.3	1.5
12:40	12	.01	30	2	13	.01	28	1.5	5/4.2	2
12:50	11.5	.01	30	2	13	.01	28	1.9	5/4.4	2

EFB READINGS

DATE 7-13-94
 BY _____

PLANT: Hayward Line II

c/s

TIME	"A" SIDE				"B" SIDE				EFB PRESS.	BAG H. PRESS.
	BED VOLT	BED CURR.	ION VOLT	ION CURR.	BED VOLT	BED CURR.	ION VOLT	ION CURR.		
13:00	12	.01	30	2	13	.01	28	1.9	4.3/4.4	1.9
13:10	11	.01	30	2	13	.01	28	1.9	4.4/4.4	1.9
13:20	11.5	.01	30	2	13	.01	28	2	4.4/4.3	2
13:30	11.5	.01	30	2	13	.01	28	1.5	4.4/4.2	2
13:40	11	.01	30	2	13	.01	28	1.5	4.4/4.2	1.5
13:50	11	.01	30	2	13	.01	28	1.9	5/4.4	2
14:00	11.5	.01	29	2	13	.01	28	1.9	4.4/4.3	1.9
14:10	11.5	.01	30	2	13	.01	28	1.5	4.4/4.2	2
14:20	11.5	.01	30	2	13	.01	29	1.5	4.4/4.3	1.9
14:30	11.5	.01	30	2	13	.01	29	1.5	5/4.3	2
14:40	11	.01	30	2	13	.01	29	1.9	4.4/4.4	1.9
14:50	11	.01	30	2	13	.01	29	1.5	4.4/4.2	2
15:00	11	.01	30	2	13	.01	29	1.5	4.4/4.1	1.9
15:10	11	.01	30	2	13	.01	29	1.5	4.4/4.3	2
15:20	11	.01	30	2	13	.01	29	1.5	5/4.3	1.9
15:30	11	.01	30	2	13	.01	29	1.5	4.4/4.4	1.9
15:40	11	.01	30	2	13	.01	29	1.5	4.4/4.2	1.9
15:50	11	.01	30	2	13	.01	29	1.5	5/4.3	1.9
16:00	11	.01	30	2	13	.01	29	1.5	5/4.2	1.9
16:10	11	.01	30	2	13	.01	29	1.5	4.4/4.4	1.9
16:20	11	.01	30	2	13	.01	29	1.9	4.4/4.4	1.8
16:30	11	.01	30	2	13	.01	29	1.5	4.3/4.3	1.9
16:40	11	.01	30	2	13	.01	28	1.5	4.4/4.4	1.9
16:50	11	.01	30	2	13	.01	28	1.5	4.4/4.3	1.9
17:00	11	.01	30	2	13	.01	28	2	4.4/4.4	1.9
17:10	11	.01	30	2	13	.01	29	1.5	4.4/4.4	1.9
17:20	11	.01	30	2	13	.01	28	2	4.4/4.3	1.9
17:30										
17:40										
17:50										

LINE II RTO DRYER

July 13 1994

#1	#2	#3	#4	#5	INLET PRESS.	BURNERS		INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ	GAS
						B #1	B #2					
451	514	444	473	493	6.1	1672	1538	211	1647	316	23.3	-
457	493	455	463	493	4.7	1528	1542	213	1579	339	23.1	
438	515	445	459	512	5.6	1577	1526	218	1593	318	23.1	
451	497	459	459	508	4.7	1520	1540	221	1571	343	23.3	
451	498	460	461	508	4.5	1514	1538	221	1575	344	23.4	
441	520	442	475	498	5.1	1571	1523	221	1620	314	23.9	
441	512	454	464	514	5.4	1571	1535	222	1588	323	23.4	
455	499	463	479	483	4.9	1549	1551	222	1615	329	23.4	
440	519	446	476	499	5.0	1573	1521	221	1614	314	23.4	
448	498	464	467	506	4.4	1521	1541	222	1571	345	23.4	
437	514	455	467	514	5.4	1575	1524	222	1583	321	23.4	
436	519	448	478	498	4.9	1573	1521	221	1634	315	23.7	
446	494	467	470	501	3.9	1511	1537	221	1549	343	23.3	
444	507	450	487	483	5.5	1561	1541	221	1629	323	23.1	
433	518	448	479	501	4.9	1575	1524	221	1619	314	23.2	
441	497	466	468	509	4.3	1523	1541	221	1572	347	23.1	
445	500	456	485	485	5.2	1548	1545	221	1609	331	23.2	
431	514	457	471	514	5.4	1578	1528	221	1590	321	23.3	
446	493	465	478	493	4.5	1529	1545	221	1594	342	23.1	
446	492	468	475	500	5.5	1518	1540	221	1575	344	23.3	
430	516	453	477	508	6.1	1676	1521	220	1600	314	23.0	
430	511	458	470	516	5.4	1576	1533	221	1598	322	23.3	
441	503	454	486	486	5.4	1556	1546	221	1623	329	23.0	
432	509	461	470	516	5.6	1576	1530	222	1582	324	23.3	
442	494	469	471	507	4.3	1508	1541	223	1572	344	23.3	


July 13 1994

RTO DRYER

LINE II

#1	#2	#3	#4	#5	INLET PRESS.	BURNERS B #1	BURNERS B #2	INLET TEMP.	COMBUST. CHAMBER TEMP.	EXHAUST TEMP.	Δ	GAS
445	497	461	483	489	4.3	1541	1546	222	1606	334	232	
431	518	450	481	502	5.1	1572	1519	223	1604	316	22.7	
443	493	470	470	506	3.8	1511	1540	223	1575	343	23.0	
441	505	452	486	487	5.5	1559	1544	223	1631	327	23.5	
420	515	456	473	514	5.4	1573	1527	223	1597	220	22.6	
438	498	468	468	514	4.3	1528	1570	223	1668	349	22.8	
440	506	452	487	489	5.6	1565	1546	223	1642	325	22.8	
430	513	456	473	516	6.5	1578	1527	223	1595	321	22.8	
438	496	467	469	516	4.3	1527	1544	223	1573	348	23.0	
443	492	468	474	507	2.6	1511	1536	223	1571	345	23.2	
429	517	449	480	508	4.9	1575	1522	223	1413	314	23.1	
437	495	464	471	516	4.4	1519	1538	223	1569	347	23.1	
445	492	462	481	495	4.9	1530	1541	223	1590	340	23.0	
442	498	455	487	490	5.4	1543	1541	223	1604	332	23.1	

LINE II
DRYER RTO
CHART
7-13-94




HAYWARD OSB
LINE II
JULY 13, 1994

FLAKE MOISTURE

	WET	DRY
8:00 AM	C 48.7 S 48.4	C 6.6 S 5.0
9:00 AM	C 47.5 S 48.6	C 4.9 S 5.7
10:00 AM	C 46.8 S 46.0	C 6.5 S 5.2
11:00 AM	C 47.9 S 46.6	C 6.1 S 5.3
12:00 PM	C 46.3 S 46.0	C 6.5 S 5.6
1:00 PM	C 47.6 S 46.2	C 7.8 S 5.9
2:00 PM	C 46.8 S 46.0	C 6.2 S 5.6
3:00 PM	C 49.8 S 47.9	C 6.8 S 5.4
4:00 PM	C 44.4 S 47.5	C 4.7 S 6.2
5:00 PM	C 44.3 S 46.4	C 4.6 S 5.0

APPENDIX K

PROCEDURES



Particulate Loading and Emission Rates

The particulate emission rates were determined per EPA Methods 1 - 5, CFR Title 40, Part 60, Appendix A (revised July 1, 1992). In this procedure, a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass or stainless steel-lined sampling probe equipped with a Type S pitot and a thermocouple. The probe is attached to a sampling module which houses the all-glass in line filter holder in a temperature controlled oven. In addition, the sampling module also houses the impinger case and a Drierite drying column. The sampling module is connected by means of an umbilical cord to the control module which houses the dry test gas meter, the calibrated orifice, a leakless pump, two inclined manometers, and all controls required for operating the sampling train.

Particulate samples were collected as follows: The sample gas was drawn in through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter. The particulates were removed at this point and collected on the filter. The gases then passed through an ice-cooled impinger train and a desiccant-packed drying column which quantitatively absorb all moisture from the sample gas stream after which the sample gas passes through the pump and the dry test gas meter which integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gas meter provides instantaneous flow rate data.

A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each site such that an isokinetic sampling condition prevails. Nomographs are used to aid in the rapid determination of the sampling rate.

Particulate Loading and Emission Rates

After sampling is complete, the filter is removed and placed in a clean container. The nozzle and inlet side of the filter holder are quantitatively washed with acetone and the washings are stored in a second container. A brush is often used in the cleaning step to help dislodge deposits. The samples are returned to the laboratory where they are logged in and analyzed. The volume of the acetone rinse ("probe wash") is noted and then the rinse is quantitatively transferred to a tared 120 cc porcelain evaporating dish and the acetone evaporated off at 97-105 °F. This temperature is used to prevent condensation of atmospheric moisture due to the cooling effect induced by the evaporation of acetone. The acetone-free sample is then transferred to an oven and dried at 105 °C for 30 minutes, cooled in a desiccator over Drierite, and then weighed to the nearest .01 mg. The filter sample is quantitatively transferred to a 6-inch watch glass and dried in an oven at 105 °C for two hours. The filter and watch glass are then cooled in a desiccator and the filter weighed to the nearest .01 mg. All weighings are performed in a balance room where the relative humidity is hydrostatted to less than 50% relative humidity. Microscopic examination of the samples is performed if any unusual characteristics are observed. The weight of the acetone rinse is corrected for the acetone blank. The Drierite column is weighed on-site and the water collected by Drierite is added to the condensate so that the total amount of absorbed water may be ascertained.

Integrated flue gas samples for Orsat analysis were collected simultaneously with each pollutant sample. The samples were collected in 15-liter gas sampling bags at a constant flow rate throughout each particulate run. The bags were at a constant flow rate throughout each particulate run. The bags were then returned to the laboratory and analyzed by Orsat analysis. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen).

Condensible Organic Compounds Analysis

(State of Wisconsin - EPA Method 5)

Method II-8672-WI

Equipment: Separatory funnel - 500 cc with Teflon stopcock

Powder funnel - 75 mm ID with a glass wool plug

Evaporating dish(es) - 200 cc or 250 cc beaker

Reagents: Methylene chloride

Sodium sulfate - (ACS) granular anhydrous (purified by heating for four hours in a shallow tray)

SAMPLING

An all-glass impinger assembly is used in the back half of the EPA Method 5 sampling train when an organic wet catch is to be collected. The impinger assembly consists of a modified impinger, a Greenburg Smith impinger followed by another modified impinger. The third impinger should have a temperature measuring device at the outlet upstream of a final impinger or desiccant column to monitor the temperature of the outlet gas stream. Prior to the start of the test, each of the first two impingers should be charged with 100 g of Class I water. The Method 5 train should be operated as provided for in EPA Method 5. Ice should be added to the impinger bath to keep the temperature of the gas at the outlet at or less than 68°F. After the post test leak check, the impinger train is removed and impinger contents poured into a tared all-glass sample bottle and closed with a Teflon-lined cap. The sample bottle is then weighed and the total condensate calculated by subtraction of the bottle tare weight and the weight of initial water added to the impingers (200 g). A label is affixed and the sample is returned to the laboratory for analysis. The sample should be stored at 4°C if the analysis is not conducted within 48 hours.

030894-G:\STACK\WPMETHODS\II-8672.WI

ANALYSIS

1. Sample bottles are removed from storage and the contents quantitatively transferred to a clean 500 cc separatory funnel equipped with a Teflon stopcock.
2. Rinse the sample container with distilled water and add to separatory funnel.
3. Then rinse the sample container with acetone and pour through sodium sulfate into a tare beaker marked A.
4. The sample is then extracted consecutively with three 50 cc aliquots of methylene chloride. The extraction is performed according to normal laboratory practice observing the customary safety precaution of releasing excess pressure after each shaking.
5. After each of the three extractions are completed, the organic solvent should be dried by passing it through a funnel containing anhydrous sodium sulfate and collecting it and two 50 cc rinses in the tared beaker marked A (the same one used to catch the acetone container rinse).
6. Evaporate to dryness in a hood at 70°F or less. Do not evaporate so quickly as to allow evaporative cooling to lower the temperature of the container below the dew point otherwise water will be condensed in the container.
7. Desiccate for two hours in a sealed desiccator and final weigh. Report all results in grams. All weighings should be made to nearest 0.1 mg (four places).
8. The remaining liquid in the separatory funnel is then transferred to a tared beaker marked B and is evaporated to dryness at 220°F ± 10°F. The analyst may take an aliquot of the sample, transferring it to a tared beaker and evaporate to dryness at 220°F ± 10°F. If an aliquot is used, the weight of the sample and aliquot will have to be taken to correct for the total sample weight.

030894-G:\STACK\WPMETHODS\II-8672.WI


9. After the drying step, the sample is cooled in a desiccator and weighted to a constant weight to the nearest 0.1 mg.

Calculation (if aliquot is taken):

$$\text{grams} = \frac{(\text{grams recovered from aliquot}) \times (\text{total volume (ml) or grams of sample})}{(\text{aliquot volume (ml) or grams used})}$$

If volume is used, it must be used for both the aliquot and sample. The same goes for using weight.

10. A field blank should be analyzed in an identical manner. If a field blank is not submitted, take an aliquot of Class I water equal in volume to the samples and analyze in a similar manner.
11. The results for container A are to be marked in the organic section of Interpoll Form #LSC-03G.
12. The results for container B are to be marked in the inorganic section of Interpoll Form #LSC-03G.



Particulate-sampling train.

Flow

Flow determinations were carried out in accordance with EPA Method 2, CFR Title 40, Part 60, Appendix A (Revised July 1, 1987). A type S pitot was used to sense velocity pressure and an inclined manometer was used to measure velocity pressures. Gas temperatures were measured using a calibrated Type K thermocouple and digital temperature meter. Gas density (i.e. molecular weight) was calculated from the composition of the gas which was determined by Orsat.

Gas Flow Density

Gas compositions were determined as per Method 3 by Orsat analysis of an integrated gas sample collected from the stack during the oxides of nitrogen determinations. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen).


Oxides of Nitrogen

Oxides of nitrogen concentrations were collected in accordance with EPA Method 7 (see above-cited reference) with a specially designed all glass manifold and valving assembly and a heated stainless steel-lined probe. Samples were collected in two-liter evacuated insulated flasks which contained 25 cc of acidified peroxide solution (Method 7 reagent). Nine sets or more of three samples each were collected over a period of 4.5 to 5 hours.

The sampling train was leak checked through the probe at the beginning and end of the test and, in addition, the system leak checked at the time of evacuation of each flask. Before the samples were collected, the probe was purged to eliminate dead volume effects and to raise the temperature of the probe outlet and manifold assembly to minimize condensation of moisture. A plug of microfiber glass wool inserted in the probe inlet was used to prevent particulate material from entering into the flask. The temperature of the flask, vacuum in the

flask and barometric pressure at the time of sampling was recorded for each flask. After sampling was complete, as evidenced by the in-line vacuum gauge, the flask valve was closed, the flask assembly disconnected from the manifold/valve assembly and the flask shook for several minutes to promote oxidation and absorption. The recovered oxides of nitrogen samples were returned to the laboratory and analyzed immediately by ion chromatography as per EPA 7A.

The internal volume of each numbered flask assembly has been measured prior to initial use by filling with water, weighing before and after and then converting the weight of water to volume by means of the density of water at room temperature. Flask volumes are stored in the computer and recalled automatically in the computer calculation.



Sampling train, flask valve, and flask.

METHOD 7E—DETERMINATION OF NITROGEN
OXIDES EMISSIONS FROM STATIONARY
SOURCES (INSTRUMENTAL ANALYZER PRO-
CEDURE)

1. *Applicability and Principle*

1.1 *Applicability.* This method is applicable to the determination of nitrogen oxides (NO_x) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 *Principle.* A gas sample is continuously extracted from a stack, and a portion of the sample is conveyed to an instrumental chemiluminescent analyzer for determination of NO_x concentration. Performance specifications and test procedures are provided to ensure reliable data.

2. *Range and Sensitivity*

Same as Method 6C, Sections 2.1 and 2.2.

3. *Definitions*

3.1 *Measurement System.* The total equipment required for the determination of NO_x concentration. The measurement system consists of the following major subsystems:

3.1.1 *Sample Interface, Gas Analyzer, and Data Recorder.* Same as Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.1.2 *NO_x to NO Converter.* A device that converts the nitrogen dioxide (NO_2) in the sample gas to nitrogen oxide (NO).

3.2 *Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, and Response Time.* Same as Method 6C, Sections 3.2 through 3.8.

3.3 *Interference Response.* The output response of the measurement system to a

component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 Measurement System. Any measurement system for NO_x that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 Sample Probe, Sample Line, Calibration Valve Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder. Same as Method 6C, Sections 5.1.1 through 5.1.9, and 5.1.11.

5.1.2 NO_x to NO Converter. That portion of the system that converts the nitrogen dioxide (NO₂) in the sample gas to nitrogen oxide (NO). An NO₂ to NO converter is not necessary if data are presented to demonstrate that the NO₂ portion of the exhaust gas is less than 5 percent of the total NO_x concentration.

5.1.3 NO_x Analyzer. An analyzer based on the principles of chemiluminescence, to determine continuously the NO_x concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer.

5.2 NO_x Calibration Gases. The calibration gases for the NO_x analyzer shall be NO in N₂. Three calibration gases, as specified in Sections 5.3.1 through 5.3.3. of Method 6C, shall be used. Ambient air may be used for the zero gas.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Gas Concentration Verification. Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 7, and change all 5 percent performance values to 10 percent (or 10 ppm, whichever is greater).

6.2 Interference Response. Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 Measurement System Preparation. Analyzer Calibration Error, and Sample System Bias Check. Follow Sections 6.2 through 6.4 of Method 6C.

6.4 NO₂ to NO Conversion Efficiency. Unless data are presented to demonstrate that the NO₂ concentration within the sample stream is not greater than 5 percent of the NO_x concentration, conduct an NO₂ to NO conversion efficiency test in accordance with Section 5.6 of Method 20.

7. Emission Test Procedure

7.1 Selection of Sampling Site and Sampling Points. Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 7.

7.2 Sample Collection. Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the system calibration drift test. Maintain constant rate sampling (i.e., ±10 percent) during the entire run. The sampling time per run shall be the same as the total time required to perform a run using Method 7, plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed, to determine the average effluent concentration.

7.3 Zero and Calibration Drift Test. Follow Section 7.4 of Method 6C.

8. Emission Calculation

Follow Section 8 of Method 6C.

9. Bibliography

Same as bibliography of Method 6C.

4.2 Performance Evaluation Tests. The owner of a lidar system shall subject such a lidar system to the performance verification tests described in Section 3, prior to first use of this method. The annual calibration shall be performed for three separate, complete runs and the results of each should be recorded. The requirements of Section 3.3.1 must be fulfilled for each of the three runs.

Once the conditions of the annual calibration are fulfilled the lidar shall be subjected to the routine verification for three separate complete runs. The requirements of Section 3.3.2 must be fulfilled for each of the three runs and the results should be recorded. The Administrator may request that the results of the performance evaluation be submitted for review.

5. References

5.1 The Use of Lidar for Emissions Source Opacity Determination, U.S. Environmental Protection Agency, National Enforcement Investigations Center, Denver, CO. EPA-330/1-79-003-R, Arthur W. Dybdahl, current edition [NTIS No. PB81-246662].

5.2 Field Evaluation of Mobile Lidar for the Measurement of Smoke Plume Opacity, U.S. Environmental Protection Agency, National Enforcement Investigations Center, Denver, CO. EPA/NEIC-TS-128, February 1976.

5.3 Remote Measurement of Smoke Plume Transmittance Using Lidar, C. S. Cook, G. W. Bethke, W. D. Conner (EPA/RTP), Applied Optics 11, pg 1742, August 1972.

5.4 Lidar Studies of Stack Plumes in Rural and Urban Environments, EPA-650/4-73-002, October 1973.

5.5 American National Standard for the Safe Use of Lasers ANSI Z 136.1-176, March 8, 1976.

5.6 U.S. Army Technical Manual TB MED 279, Control of Hazards to Health from Laser Radiation, February 1969.

5.7 Laser Institute of America Laser Safety Manual, 4th Edition.

5.8 U.S. Department of Health, Education and Welfare, Regulations for the Administration and Enforcement of the Radiation Control for Health and Safety Act of 1968, January 1976.

5.9 Laser Safety Handbook, Alex Mallow, Leon Chabot, Van Nostrand Reinhold Co., 1978.

METHOD 10—DETERMINATION OF CARBON MONOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and Applicability

1.1 Principle. An integrated or continuous gas sample is extracted from a sampling point and analyzed for carbon monoxide

(CO) content using a Luft-type nondispersive infrared analyzer (NDIR) or equivalent.

1.2 Applicability. This method is applicable for the determination of carbon monoxide emissions from stationary sources only when specified by the test procedures for determining compliance with new source performance standards. The test procedure will indicate whether a continuous or an integrated sample is to be used.

2. Range and Sensitivity

2.1 Range. 0 to 1,000 ppm.

2.2 Sensitivity. Minimum detectable concentration is 20 ppm for a 0 to 1,000 ppm span.

3. Interferences

Any substance having a strong absorption of infrared energy will interfere to some extent. For example, discrimination ratios for water (H₂O) and carbon dioxide (CO₂) are 3.5 percent H₂O per 7 ppm CO and 10 percent CO₂ per 10 ppm CO, respectively, for devices measuring in the 1,500 to 3,000 ppm range. For devices measuring in the 0 to 100 ppm range, interference ratios can be as high as 3.5 percent H₂O per 25 ppm CO and 10 percent CO₂ per 50 ppm CO. The use of silica gel and ascarite traps will alleviate the major interference problems. The measured gas volume must be corrected if these traps are used.

4. Precision and Accuracy

4.1 Precision. The precision of most NDIR analyzers is approximately ± 2 percent of span.

4.2 Accuracy. The accuracy of most NDIR analyzers is approximately ± 5 percent of span after calibration.

5. Apparatus

5.1 Continuous Sample (Figure 10-1).

5.1.1 Probe. Stainless steel or sheathed Pyrex¹ glass, equipped with a filter to remove particulate matter.

5.1.2 Air-Cooled Condenser or Equivalent. To remove any excess moisture.

5.2 Integrated Sample (Figure 10-2).

5.2.1 Probe. Stainless steel or sheathed Pyrex glass, equipped with a filter to remove particulate matter.

5.2.2 Air-Cooled Condenser or Equivalent. To remove any excess moisture.

5.2.3 Valve. Needle valve, or equivalent, to adjust flow rate.

5.2.4 Pump. Leak-free diaphragm type, or equivalent, to transport gas.

5.2.5 Rate Meter. Rotameter, or equivalent, to measure a flow range from 0 to 1.0 liter per min (0.035 cfm).

¹ Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

5.2.6 Flexible Bag. Tedlar, or equivalent, with a capacity of 60 to 90 liters (2 to 3 ft³). Leak-test the bag in the laboratory before using by evacuating bag with a pump followed by a dry gas meter. When evacuation is complete, there should be no flow through the meter.

5.2.7 Pitot Tube. Type S, or equivalent, attached to the probe so that the sampling rate can be regulated proportional to the stack gas velocity when velocity is varying with the time or a sample traverse is conducted.

5.3 Analysis (Figure 10-3).

5.3.1 Carbon Monoxide Analyzer. Nondispersive infrared spectrometer, or equivalent. This instrument should be demonstrated, preferably by the manufacturer, to meet or exceed manufacturer's specifications and those described in this method.

5.3.2 Drying Tube. To contain approximately 200 g of silica gel.

5.3.3 Calibration Gas. Refer to section 6.1.

5.3.4 Filter. As recommended by NDIR manufacturer.




Figure 10-1. Continuous sampling train.




Figure 10-2. Integrated gas sampling train.

5.3.5 CO₂ Removal Tube. To contain approximately 500 g of ascarite.

5.3.6 Ice Water Bath. For ascarite and silica gel tubes.

5.3.7 Valve. Needle valve, or equivalent, to adjust flow rate

5.3.8 Rate Meter. Rotameter or equivalent to measure gas flow rate of 0 to 1.0 liter per min (0.035 cfm) through NDIR.

5.3.9 Recorder (optional). To provide permanent record of NDIR readings.

6. Reagents

6.1 Calibration Gases. Known concentration of CO in nitrogen (N₂) for instrument span, prepurified grade of N₂ for zero, and two additional concentrations corresponding approximately to 60 percent and 30 percent span. The span concentration shall not exceed 1.5 times the applicable source performance standard. The calibration gases shall be certified by the manufacturer to be within ± 2 percent of the specified concentration.




Figure 10-3. Analytical equipment.

6.2 Silica Gel. Indicating type, 6 to 16 mesh, dried at 175° C (347° F) for 2 hours.

6.3 Ascarite. Commercially available.

7. Procedure

7.1 Sampling.

7.1.1 Continuous Sampling. Set up the equipment as shown in Figure 10-1 making sure all connections are leak free. Place the probe in the stack at a sampling point and purge the sampling line. Connect the analyzer and begin drawing sample into the analyzer. Allow 5 minutes for the system to stabilize, then record the analyzer reading as required by the test procedure. (See section 7.2 and 8). CO₂ content of the gas may be determined by using the Method 3 integrated sample procedure, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.1.2 Integrated Sampling. Evacuate the flexible bag. Set up the equipment as shown in Figure 10-2 with the bag disconnected. Place the probe in the stack and purge the sampling line. Connect the bag, making sure that all connections are leak free. Sample at a rate proportional to the stack velocity. CO₂ content of the gas may be determined by using the Method 3 integrated sample procedures, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentra-

tion from the gas volume sampled and the weight gain of the tube.

7.2 CO Analysis. Assemble the apparatus as shown in Figure 10-3, calibrate the instrument, and perform other required operations as described in section 8. Purge analyzer with N₂ prior to introduction of each sample. Direct the sample stream through the instrument for the test period, recording the readings. Check the zero and span again after the test to assure that any drift or malfunction is detected. Record the sample data on Table 10-1.

8. Calibration

Assemble the apparatus according to Figure 10-3. Generally an instrument requires a warm-up period before stability is obtained. Follow the manufacturer's instructions for specific procedure. Allow a minimum time of 1 hour for warm-up. During this time check the sample conditioning apparatus, i.e., filter, condenser, drying tube, and CO₂ removal tube, to ensure that each component is in good operating condition. Zero and calibrate the instrument according to the manufacturer's procedures using, respectively, nitrogen and the calibration gases.

TABLE 10-1—FIELD DATA

Comments	
Location.....	
Test.....	
Date.....	
Operator.....	
Clock time	Rotameter setting, liters per minute (cubic feet per minute)

9. Calculation

Calculate the concentration of carbon monoxide in the stack using Equation 10-1.

$$C_{CO \text{ stack}} = C_{CO \text{ NDIR}}(1 - F_{CO_2})$$

Eq. 10-1

Where:

C_{CO stack} = Concentration of CO in stack, ppm by volume (dry basis).

C_{CO NDIR} = Concentration of CO measured by NDIR analyzer, ppm by volume (dry basis).

F_{CO₂} = Volume fraction of CO₂ in sample, i.e., percent CO₂ from Orsat analysis divided by 100.

10. Alternative Procedures

10.1 Interference Trap. The sample conditioning system described in Method 10A sections 2.1.2 and 4.2, may be used as an alternative to the silica gel and ascarite traps.

11. Bibliography

1. McElroy, Frank, The Intertech NDIR-CO Analyzer. Presented at 11th Methods Conference on Air Pollution, University of California, Berkeley, CA. April 1, 1970.
2. Jacobs, M. B., et al., Continuous Determination of Carbon Monoxide and Hydrocarbons in Air by a Modified Infrared Analyzer, J. Air Pollution Control Association, 9(2): 110-114. August 1959.
3. MSA LIRA Infrared Gas and Liquid Analyzer Instruction Book, Mine Safety Appliances Co., Technical Products Division, Pittsburgh, PA.
4. Models 215A, 315A, and 415A Infrared Analyzers, Beckman Instruments, Inc., Beckman Instructions 1635-B, Fullerton, CA. October 1967.
5. Continuous CO Monitoring System, Model A5611, Intertech Corp., Princeton, NJ.
6. UNOR Infrared Gas Analyzers, Bendix Corp., Ronceverte, WV

ADDENDA

A. PERFORMANCE SPECIFICATIONS FOR NDIR CARBON MONOXIDE ANALYZERS

Range (minimum).....	0-1000 ppm.
Output (minimum).....	0-10mV.
Minimum detectable sensitivity.	20 ppm.
Rise time, 90 percent (maximum).	30 seconds.
Fall time, 90 percent (maximum).	30 seconds.
Zero drift (maximum).....	10% in 8 hours.
Span drift (maximum).....	10% in 8 hours.
Precision (minimum).....	±2% of full scale.
Noise (maximum).....	±1% of full scale.
Linearity (maximum deviation)	2% of full scale.
Interference rejection ratio.....	CO ₂ —1000 to 1, H ₂ O—500 to 1.

B. Definitions of Performance Specifications.

Range—The minimum and maximum measurement limits.

Output—Electrical signal which is proportional to the measurement; intended for connection to readout or data processing devices. Usually expressed as millivolts or milliamps full scale at a given impedance.

Full scale—The maximum measuring limit for a given range.

Minimum detectable sensitivity—The smallest amount of input concentration that can be detected as the concentration approaches zero.

EPA
METHOD 0011

RECEIVED

SAMPLING FOR FORMALDEHYDE EMISSIONS FROM STATIONARY SOURCES JUL 16 1990

INTERPOLL LABORATORIES

1.0 SCOPE AND APPLICATION

1.1 This method is applicable to the determination of Destruction and Removal Efficiency (DRE) of formaldehyde, CAS Registry number 50-00-0, and possibly other aldehydes and ketones from stationary sources as specified in the regulations. The methodology has been applied specifically to formaldehyde; however, many laboratories have extended the application to other aldehydes and ketones. Compounds derivatized with 2,4-dinitrophenylhydrazine can be detected as low as 6.4×10^{-8} lbs/cu ft (1.8 ppbv) in stack gas over a 1 h sampling period, sampling approximately 45 cu ft.

2.0 SUMMARY OF METHOD

2.1 Gaseous and particulate pollutants are withdrawn isokinetically from an emission source and are collected in aqueous acidic 2,4-dinitrophenylhydrazine. Formaldehyde present in the emissions reacts with the 2,4-dinitrophenylhydrazine to form the formaldehyde dinitrophenylhydrazone derivative. The dinitrophenylhydrazone derivative is extracted, solvent-exchanged, concentrated, and then analyzed by high performance liquid chromatography.

3.0 INTERFERENCES

3.1 A decomposition product of 2,4-dinitrophenylhydrazine, 2,4-dinitroaniline, can be an analytical interferent if concentrations are high. 2,4-dinitroaniline can coelute with the 2,4-dinitrophenylhydrazone of formaldehyde under high performance liquid chromatography conditions which may be used for the analysis. High concentrations of highly oxygenated compounds, especially acetone, that have the same retention time or nearly the same retention time as the dinitrophenylhydrazone of formaldehyde and that also absorb at 360 nm will interfere with the analysis.

Formaldehyde, acetone, and 2,4-dinitroaniline contamination of the aqueous acidic 2,4-dinitrophenylhydrazine (DNPH) reagent is frequently encountered. The reagent must be prepared within five days of use in the field and must be stored in an uncontaminated environment both before and after sampling in order to minimize blank problems. Some level of acetone contamination is unavoidable, because acetone is ubiquitous in laboratory and field operations. However, the acetone contamination must be minimized.

4.0 APPARATUS AND MATERIALS

4.1 A schematic of the sampling train is shown in Figure 1. This sampling train configuration is adapted from EPA Method 5 procedures. The sampling train consists of the following components: Probe Nozzle, Pitot Tube, Differential Pressure Gauge, Metering System, Barometer, and Gas Density Determination Equipment.

4.1.1 Probe Nozzle: Quartz or glass with sharp, tapered (30° angle) leading edge. The taper shall be on the outside to preserve a constant inner diameter. The nozzle shall be buttonhook or elbow design. A range of nozzle sizes suitable

INTERPOLL LABORATORIES

4500 BALL ROAD N.E.

CIRCLE PINES, MN 55014-1819

(612) 788-8020

K-15

for isokinetic sampling should be available in increments of 0.16 cm (1/16 in), e.g., 0.32 to 1.27 cm (1/8 to 1/2 in), or larger if higher volume sampling trains are used. Each nozzle shall be calibrated according to the procedures outlined in Section 8.1.

4.1.2 Probe Liner: Borosilicate glass or quartz shall be used for the probe liner. The tester should not allow the temperature in the probe to exceed $120 \pm 14^\circ\text{C}$ ($248 \pm 25^\circ\text{F}$).

4.1.3 Pitot Tube: The Pitot tube shall be Type S, as described in Section 2.1 of EPA Method 2, or any other appropriate device. The pitot tube shall be attached to the probe to allow constant monitoring of the stack gas velocity. The impact (high pressure) opening plane of the pitot tube shall be even with or above the nozzle entry plane (see EPA Method 2, Figure 2-6b) during sampling. The Type S pitot tube assembly shall have a known coefficient, determined as outlined in Section 4 of EPA Method 2.

4.1.4 Differential Pressure Gauge: The differential pressure gauge shall be an inclined manometer or equivalent device as described in Section 2.2 of EPA Method 2. One manometer shall be used for velocity-head readings and the other for orifice differential pressure readings.

4.1.5 Impingers: The sampling train requires a minimum of four impingers, connected as shown in Figure 1, with ground glass (or equivalent) vacuum-tight fittings. For the first, third, and fourth impingers, use the Greenburg-Smith design, modified by replacing the tip with a 1.3-cm inside diameter (1/2 in) glass tube extending to 1.3 cm (1/2 in) from the bottom of the flask. For the second impinger, use a Greenburg-Smith impinger with the standard tip. Place a thermometer capable of measuring temperature to within 1°C (2°F) at the outlet of the fourth impinger for monitoring purposes.

4.1.6 Metering System: The necessary components are a vacuum gauge, leak-free pump, thermometers capable of measuring temperature within 3°C (5.4°F), dry-gas meter capable of measuring volume to within 1%, and related equipment as shown in Figure 1. At a minimum, the pump should be capable of 4 cfm free flow, and the dry gas meter should have a recording capacity of 0-999.9 cu ft with a resolution of 0.005 cu ft. Other metering systems may be used which are capable of maintaining sampling rates within 10% of isokinetic collection and of determining sample volumes to within 2%. The metering system may be used in conjunction with a pitot tube to enable checks of isokinetic sampling rates.

4.1.7 Barometer: The barometer may be mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in Hg). In many cases, the barometric reading may be obtained from a nearby National Weather Service Station, in which case the station value (which is the absolute barometric pressure) is requested and an adjustment for elevation differences between the weather station and sampling point is applied at a rate of minus 2.5 mm Hg (0.1 in Hg) per 30 m (100 ft) elevation increase (vice versa for elevation decrease).

4.1.8 Gas Density Determination Equipment: Temperature sensor and pressure gauge (as described in Sections 2.3 and 2.4 of EPA Method 2), and gas analyzer, if necessary (as described in EPA Method 3). The temperature sensor ideally should be permanently attached to the pitot tube or sampling probe in a fixed

configuration such that the tip of the sensor extends beyond the leading edge of the probe sheath and does not touch any metal. Alternatively, the sensor may be attached just prior to use in the field. Note, however, that if the temperature sensor is attached in the field, the sensor must be placed in an interference-free arrangement with respect to the Type S pitot tube openings (see EPA Method 2, Figure 2-7). As a second alternative, if a difference of no more than 1% in the average velocity measurement is to be introduced, the temperature gauge need not be attached to the probe or pitot tube.

4.2 Sample Recovery

4.2.1 Probe Liner: Probe nozzle and brushes; Teflon® bristle brushes with stainless steel wire handles are required. The probe brush shall have extensions of stainless steel, Teflon®, or inert material at least as long as the probe. The brushes shall be properly sized and shaped to brush out the probe liner, the probe nozzle, and the impingers.

4.2.2 Wash Bottles: Three wash bottles are required. Teflon® or glass wash bottles are recommended; polyethylene wash bottles should not be used because organic contaminants may be extracted by exposure to organic solvents used for sample recovery.

4.2.3 Graduated Cylinder and/or Balance: A graduated cylinder or balance is required to measure condensed water to the nearest 1 mL or 1 g. Graduated cylinders shall have divisions not >2 mL. Laboratory balances capable of weighing to ±0.5 g are required.

4.2.4 Amber Glass Storage Containers: One-liter wide-mouth amber flint glass bottles with Teflon®-lined caps are required to store impinger water samples. The bottles must be sealed with Teflon® tape.

4.2.5 Rubber Policeman and Funnel: A rubber policeman and funnel are required to aid in the transfer of materials into and out of containers in the field.

5.0 REAGENTS

Reagent grade chemicals or better grades shall be used in all tests. Unless otherwise indicated, all reagents shall conform to the specifications of the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available.

5.1 Water: HPLC-grade water is used in preparation of DNPH reagent and in all other applications in the sampling train.

5.2 Silica Gel: Silica gel shall be indicating type, 6-16 mesh. If the silica gel has been used previously, dry at 175°C (350°F) for 2 h before using. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used.

5.3 Crushed Ice: Quantities ranging from 10-50 lb may be necessary during a sampling run, depending upon ambient temperature. Samples which have been taken must be stored and shipped cold; sufficient ice for this purpose must be allowed.

5.4 2,4-Dinitrophenylhydrazine Reagent: The 2,4-dinitrophenylhydrazine reagent must be prepared in the laboratory within five days of sampling use in the field. Preparation of DNPH can also be done in the field, with consideration of appropriate procedures required for safe handling of solvent in the field. When a container of prepared DNPH reagent is opened in the field, the contents of the opened container should be used within 48 hours. All laboratory glassware must be washed with detergent and water and rinsed with water, methanol, and methylene chloride prior to use.

NOTE: The glassware must not be rinsed with acetone or unacceptable levels of acetone contamination will be introduced. If field preparation of DNPH is performed, caution must be exercised in avoiding acetone contamination.

Reagent bottles for storage of cleaned DNPH derivatizing solution must be rinsed with acetonitrile and dried before use. Baked glassware is not essential for preparation of DNPH reagent.

NOTE: DNPH crystals or DNPH solution should be handled with plastic gloves at all times, with prompt and extensive use of running water in case of skin exposure.

5.4.1 Preparation of Aqueous Acidic DNPH: The following materials and reagents are required for preparation of the reagent.

5.4.1.1 Bottles/Caps: amber 1- or 4 L bottles with Teflon®-lined caps are required for storing cleaned DNPH solution. Additional 4-L bottles are required to collect waste organic solvents.

5.4.1.2 Large Glass Container: at least one large glass container (8 to 16 L) is required for mixing the aqueous acidic DNPH solution.

5.4.1.3 Stir Plate/Large Stir Bars/Stir Bar Retriever: a magnetic stir plate and large stir bar are required for the mixing of the aqueous acidic DNPH solution. A stir bar retriever is needed for removing the stir bar from the large container holding the DNPH solution.

5.4.1.4 Buchner Filter/Filter Flask/Filter Paper: a large filter flask (2-4 L) with a buchner filter, appropriate rubber stopper, filter paper, and connecting tubing are required for filtering the aqueous acidic DNPH solution prior to cleaning.

5.4.1.5 Separatory Funnels: at least one large separatory funnel (2 L) is required for cleaning the DNPH prior to use.

5.4.1.6 Beakers: beakers (150 mL, 250 mL, and 400 mL) are useful for holding/measuring organic liquids when cleaning the aqueous acidic DNPH solution and for weighing DNPH crystals.

5.4.1.7 Funnels: at least one large funnel is needed for pouring the aqueous acidic DNPH into the separatory funnel.

5.4.1.8 Graduated Cylinders: at least one large graduated cylinder (1 to 2 L) is required for measuring HPLC-grade water and acid when preparing the DNPH solution.

5.4.1.9 Top-Loading Balance: a one-place top loading balance is needed for weighing out the DNPH crystals used to prepare the aqueous acidic DNPH solution.

5.4.1.10 Spatulas: spatulas are needed for weighing out DNPH when preparing the aqueous DNPH solution.

5.4.1.11 HPLC-Grade Water: water (HPLC-grade) is required to mix the aqueous DNPH solution.

5.4.1.12 Hydrochloric Acid: reagent grade hydrochloric acid (approximately 12N) is required for acidifying the aqueous DNPH solution.

5.4.1.13 2,4-Dinitrophenylhydrazine: a supply of moist solid 2,4-dinitrophenylhydrazine (DNPH) is required for preparation of aqueous acidic DNPH solution. The quantity of water may vary from 10 to 30%. Reagent grade or equivalent is required.

5.4.1.14 Methylene Chloride: methylene chloride (suitable for residue and pesticide analysis, GC/MS, HPLC, GC, Spectrophotometry or equivalent) is required for cleaning the aqueous acidic DNPH solution, rinsing glassware, and recovery of sample trains.

5.4.1.15 Cyclohexane: cyclohexane (HPLC grade) is required for cleaning the aqueous acidic DNPH solution.

NOTE: Do not use spectroanalyzed grades of cyclohexane if this sampling methodology is extended to aldehydes and ketones with four or more carbon atoms.

5.4.1.16 Methanol: methanol (HPLC grade or equivalent) is required for rinsing glassware.

5.4.1.17 Acetonitrile: acetonitrile (HPLC grade or equivalent) is required for rinsing glassware.

5.4.1.18 Formaldehyde: Analytical grade or equivalent formaldehyde is required for preparation of standards. If other aldehydes or ketones are used, analytical grade or equivalent is required.

5.4.2 Preparation of Aqueous Acidic DNPH Derivatizing Reagent: Each batch of DNPH reagent should be prepared and purified within five days of sampling, according to the procedure described below.

5.4.2.1 Place an 8-L container under a fume hood on a magnetic stirrer. Add a large stir bar and fill the container half full of HPLC-grade water. Save the empty bottle from HPLC-grade water. Start the stirring bar and adjust the stir rate to be as fast as possible. Using a graduated cylinder, measure 1.4 mL of concentrated hydrochloric acid. Slowly pour the acid into the stirring water. Fumes may be generated and the water may become warm. Weigh the DNPH crystals on a one-place balance (see Table 1 for approximate amounts) and add to the stirring acid solution. Fill the 8 L container to the 8 L mark with HPLC water and stir overnight. If all of the DNPH crystals have dissolved overnight, add additional DNPH and stir for two more hours. Continue the process of adding DNPH with additional stirring until a saturated solution has been formed. Filter the DNPH solution using vacuum filtration. Gravity filtration may be used, but a

much longer time is required. Store the filtered solution in an amber bottle at room temperature.

TABLE 1. APPROXIMATE AMOUNT OF CRYSTALLINE DNPH USED TO PREPARE A SATURATED SOLUTION

Amount of Moisture in DNPH	Weight Required per 8 L of Solution
10 weight percent	31 g
15 weight percent	33 g
30 weight percent	40 g

Within five days of proposed use, place about 1.6 L of the DNPH reagent in a 2 L separatory funnel. Add approximately 200 mL of methylene chloride and stopper the funnel. Wrap the stopper of the funnel with paper towels to absorb any leakage. Invert and vent the funnel. Then shake vigorously for 3 minutes. Initially, the funnel should be vented frequently (every 10 - 15 sec). After the layers have separated, discard the lower (organic) layer.

Extract the DNPH a second time with methylene chloride and finally with cyclohexane. When the cyclohexane layer has separated from the DNPH reagent, the cyclohexane layer will be the top layer in the separatory funnel. Drain the lower layer (the cleaned extracted DNPH reagent solution) into an amber bottle that has been rinsed with acetonitrile and allowed to dry.

5.4.3 Quality Control: Take two aliquots of the extracted DNPH reagent. The size of the aliquots is dependent upon the exact sampling procedure used, but 100 mL is reasonably representative. To ensure that the background in the reagent is acceptable for field use, analyze one aliquot of the reagent according to the procedure of EPA Draft Method 8315. Save the other aliquot of aqueous acidic DNPH for use as a method blank when the analysis is performed.

5.4.4 Shipment to the Field: Tightly cap the bottle containing extracted DNPH reagent using a Teflon®-lined cap. Seal the bottle with Teflon® tape. After the bottle is labeled, the bottle may be placed in a friction-top can (paint can or equivalent) containing a 1 -2 inch layer of granulated charcoal and stored at ambient temperature until use.

If the DNPH reagent has passed the Quality Control criteria, the reagent may be packaged to meet necessary shipping requirements and sent to the sampling area. If the Quality Control criteria are not met, the reagent solution may be re-extracted or the solution may be re-prepared and the extraction sequence repeated.

If the DNPH reagent is not used in the field within five days of extraction, an aliquot may be taken and analyzed as described Draft Method 8315. If the reagent meets the Quality Control requirements, the reagent may be used. If the reagent does not meet Quality Control requirements, the reagent must be discarded and new reagent must be prepared and tested.

5.4.5 Calculation of Acceptable Levels of Impurities in DNPB Reagent: The acceptable impurity level (AIL, $\mu\text{g/mL}$) is calculated from the expected analyte level in the sampled gas (EAL, ppbv), the volume of air that will be sampled at standard conditions (SVOL, L), the formula weight of the analyte (FW, g/mol), and the volume of DNPB reagent that will be used in the impingers (RVOL, mL):

$$\text{AIL} = 0.1 \times [\text{EAL} \times \text{SVOL} \times \text{FW}/22.4 \times (\text{FW} + 180)/\text{FW}]/(\text{RVOL} \times 1000)$$

where 0.1 is the acceptable contaminant level, 22.4 is a factor relating ppbv to g/L, 180 is a factor relating the underivatized analyte to the derivatized analyte, and 1000 is a unit conversion factor.

5.4.6 Disposal of Excess DNPB Reagent: Excess DNPB reagent may be returned to the laboratory and recycled or treated as aqueous waste for disposal purposes. 2,4-Dinitrophenylhydrazine is a flammable solid when dry so water should not be evaporated from the solution of the reagent.

5.5 Field Spike Standard Preparation: To prepare a formaldehyde field spiking standard at 4.01 mg/mL, use a 500 μL syringe to transfer 0.5 mL of 37% by weight of formaldehyde (401 mg/mL) to a 50 mL volumetric flask containing approximately 40 mL of methanol. Dilute to 50 mL with methanol.

6.0 SAMPLE COLLECTION, PRESERVATION, AND HANDLING

6.1 Because of the complexity of this method, field personnel should be trained in and experienced with the test procedures in order to obtain reliable results.

6.2 Laboratory Preparation:

6.2.1 All the components shall be maintained and calibrated according to the procedure described in APTD-0576, unless otherwise specified.

6.2.2 Weigh several 200- to 300-g portions of silica gel in airtight containers to the nearest 0.5 g. Record on each container the total weight of the silica gel plus containers. As an alternative to preweighing the silica gel, it may instead be weighed directly in the impinger or sampling holder just prior to train assembly.

6.3 Preliminary Field Determinations:

6.3.1 Select the sampling site and the minimum number of sampling points according to EPA Method 1 or other relevant criteria. Determine the stack pressure, temperature, and range of velocity heads using EPA Method 2. A leak-check of the pitot lines according to EPA Method 2, Section 3.1, must be performed. Determine the stack gas moisture content using EPA Approximation Method 4 or its alternatives to establish estimates of isokinetic sampling-rate settings. Determine the stack gas dry molecular weight, as described in EPA Method 2, Section 3.6. If integrated EPA Method 3 sampling is used for molecular weight determination, the integrated bag sample shall be taken simultaneously with, and for the same total length of time as, the sample run.

6.3.2 Select a nozzle size based on the range of velocity heads so that it is not necessary to change the nozzle size in order to maintain isokinetic sampling rates below 28 L/min (1.0 cfm). During the run, do not change the nozzle.

Ensure that the proper differential pressure gauge is chosen for the range of velocity heads encountered (see Section 2.2 of EPA Method 2).

6.3.3 Select a suitable probe liner and probe length so that all traverse points can be sampled. For large stacks, to reduce the length of the probe, consider sampling from opposite sides of the stack.

6.3.4 A minimum of 45 ft³ of sample volume is required for the determination of the Destruction and Removal Efficiency (DRE) of formaldehyde from incineration systems (45ft³ is equivalent to one hour of sampling at 0.75 dscf). Additional sample volume shall be collected as necessitated by the capacity of the DNPH reagent and analytical detection limit constraints. To determine the minimum sample volume required, refer to sample calculations in Section 10.

6.3.5 Determine the total length of sampling time needed to obtain the identified minimum volume by comparing the anticipated average sampling rate with the volume requirement. Allocate the same time to all traverse points defined by EPA Method 1. To avoid timekeeping errors, the length of time sampled at each traverse point should be an integer or an integer plus 0.5 min.

6.3.6 In some circumstances (e.g., batch cycles) it may be necessary to sample for shorter times at the traverse points and to obtain smaller gas-volume samples. In these cases, careful documentation must be maintained in order to allow accurate calculation of concentrations.

6.4 Preparation of Collection Train:

6.4.1 During preparation and assembly of the sampling train, keep all openings where contamination can occur covered with Teflon® film or aluminum foil until just prior to assembly or until sampling is about to begin.

6.4.2 Place 100 mL of cleaned DNPH solution in each of the first two impingers, and leave the third impinger empty. If additional capacity is required for high expected concentrations of formaldehyde in the stack gas, 200 mL of DNPH per impinger may be used or additional impingers may be used for sampling. Transfer approximately 200 to 300 g of pre-weighed silica gel from its container to the fourth impinger. Care should be taken to ensure that the silica gel is not entrained and carried out from the impinger during sampling. Place the silica gel container in a clean place for later use in the sample recovery. Alternatively, the weight of the silica gel plus impinger may be determined to the nearest 0.5 g and recorded.

6.4.3 With a glass or quartz liner, install the selected nozzle using a Viton-A O-ring when stack temperatures are <260°C (500°F) and a woven glass-fiber gasket when temperatures are higher. See APTD-0576 (Rom, 1972) for details. Other connecting systems utilizing either 316 stainless steel or Teflon® ferrules may be used. Mark the probe with heat-resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point.

6.4.4 Assemble the train as shown in Figure 1. During assembly, do not use any silicone grease on ground-glass joints upstream of the impingers. Use Teflon® tape, if required. A very light coating of silicone grease may be used on ground-glass joints downstream of the impingers, but the silicone grease should be limited to the outer portion (see APTD-0576) of the ground-glass joints to

minimize silicone grease contamination. If necessary, Teflon[®] tape may be used to seal leaks. Connect all temperature sensors to an appropriate potentiometer/display unit. Check all temperature sensors at ambient temperature.

6.4.5 Place crushed ice all around the impingers. . .

6.4.6 Turn on and set the probe heating system at the desired operating temperature. Allow time for the temperature to stabilize.

6.5 Leak-Check Procedures:

6.5.1 Pre-test Leak Check:

6.5.1.1 After the sampling train has been assembled, turn on and set the probe heating system at the desired operating temperature. Allow time for the temperature to stabilize. If a Viton-A O-ring or other leak-free connection is used in assembling the probe nozzle to the probe liner, leak-check the train at the sampling site by plugging the nozzle and pulling a 381-mm Hg (15 in Hg) vacuum.

NOTE: A lower vacuum may be used, provided that the lower vacuum is not exceeded during the test.

6.5.1.2 If an asbestos string is used, do not connect the probe to the train during the leak check. Instead, leak-check the train by first attaching a carbon-filled leak check impinger to the inlet and then plugging the inlet and pulling a 381-mm Hg (15 in Hg) vacuum. (A lower vacuum may be used if this lower vacuum is not exceeded during the test.) Then connect the probe to the train and leak-check at about 25 mm Hg (1 in Hg) vacuum. Alternatively, leak-check the probe with the rest of the sampling train in one step at 381 mm Hg (15 in Hg) vacuum. Leakage rates in excess of 4% of the average sampling rate or $>0.00057 \text{ m}^3/\text{min}$ (0.02 cfm), whichever is less, are acceptable.

6.5.1.3 The following leak check instructions for the sampling train described in APTD-0576 and APTD-0581 may be helpful. Start the pump with the fine-adjust valve fully open and coarse-adjust valve completely closed. Partially open the coarse-adjust valve and slowly close the fine-adjust valve until the desired vacuum is reached. Do not reverse direction of the fine-adjust valve, as liquid will back up into the train. If the desired vacuum is exceeded, either perform the leak check at this higher vacuum or end the leak check, as shown below, and start over.

6.5.1.4 When the leak check is completed, first slowly remove the plug from the inlet to the probe. When the vacuum drops to 127 mm (5 in) Hg or less, immediately close the coarse-adjust valve. Switch off the pumping system and reopen the fine-adjust valve. Do not reopen the fine-adjust valve until the coarse-adjust valve has been closed to prevent the liquid in the impingers from being forced backward into the sampling line and silica gel from being entrained backward into the third impinger.

6.5.2 Leak Checks During Sampling Runs:

6.5.2.1 If, during the sampling run, a component change (i.e., impinger) becomes

necessary, a leak check shall be conducted immediately after the interruption of sampling and before the change is made. The leak check shall be done according to the procedure described in Section 6.5.1, except that it shall be done at a vacuum greater than or equal to the maximum value recorded up to that point in the test. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable. If a higher leakage rate is obtained, the tester must void the sampling run.

NOTE: Any correction of the sample volume by calculation reduces the integrity of the pollutant concentration data generated and must be avoided.

6.5.2.2 Immediately after a component change and before sampling is re-initiated, a leak check similar to a pre-test leak check must also be conducted.

6.5.3 Post-test Leak Check:

6.5.3.1 A leak check is mandatory at the conclusion of each sampling run. The leak check shall be done with the same procedures as the pre-test leak check, except that the post-test leak check shall be conducted at a vacuum greater than or equal to the maximum value reached during the sampling run. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable. If, however, a higher leakage rate is obtained, the tester shall record the leakage rate and void the sampling run.

6.6 Sampling Train Operation:

6.6.1 During the sampling run, maintain an isokinetic sampling rate to within 10% of true isokinetic, below 28 L/min (1.0 cfm). Maintain a temperature around the probe of 120° ± 14°C (248° ± 25°F).

6.6.2 For each run, record the data on a data sheet such as the one shown in Figure 2. Be sure to record the initial dry-gas meter reading. Record the dry-gas meter readings at the beginning and end of each sampling time increment, when changes in flow rates are made, before and after each leak check, and when sampling is halted. Take other readings required by Figure 2 at least once at each sample point during each time increment and additional readings when significant adjustments (20% variation in velocity head readings) necessitate additional adjustments in flow rate. Level and zero the manometer. Because the manometer level and zero may drift due to vibrations and temperature changes, make periodic checks during the traverse.

6.6.3 Clean the stack access ports prior to the test run to eliminate the chance of sampling deposited material. To begin sampling, remove the nozzle cap, verify that the filter and probe heating systems are at the specified temperature, and verify that the pitot tube and probe are properly positioned. Position the nozzle at the first traverse point, with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Nomographs, which aid in the rapid adjustment of the isokinetic sampling rate without excessive computations, are available. These nomographs are designed for use when the Type S pitot tube coefficient is 0.84 ± 0.02 and the stack gas equivalent density (dry molecular weight) is equal to 29 ± 4. APFD-0576 details the procedure for using the nomographs. If the stack gas molecular weight and

the pitot tube coefficient are outside the above ranges, do not use the nomographs unless appropriate steps are taken to compensate for the deviations.

6.6.4 When the stack is under significant negative pressure (equivalent to the height of the impinger stem), take care to close the coarse-adjust valve before inserting the probe into the stack in order to prevent liquid from backing up through the train. If necessary, the pump may be turned on with the coarse-adjust valve closed.

6.6.5 When the probe is in position, block off the openings around the probe and stack access port to prevent unrepresentative dilution of the gas stream.

6.6.6 Traverse the stack cross section, as required by EPA Method 1, being careful not to bump the probe nozzle into the stack walls when sampling near the walls or when removing or inserting the probe through the access port, in order to minimize the chance of extracting deposited material.

6.6.7 During the test run, make periodic adjustments to keep the temperature around the probe at the proper levels. Add more ice and, if necessary, salt, to maintain a temperature of $<20^{\circ}\text{C}$ (68°F) at the silica gel outlet. Also, periodically check the level and zero of the manometer.

6.6.8 A single train shall be used for the entire sampling run, except in cases where simultaneous sampling is required in two or more separate ducts or at two or more different locations within the same duct, or in cases where equipment failure necessitates a change of trains. An additional train or additional trains may also be used for sampling when the capacity of a single train is exceeded.

6.6.9 When two or more trains are used, separate analyses of components from each train shall be performed. If multiple trains have been used because the capacity of a single train would be exceeded, first impingers from each train may be combined, and second impingers from each train may be combined.

6.6.10 At the end of the sampling run, turn off the coarse-adjust valve, remove the probe and nozzle from the stack, turn off the pump, record the final dry gas meter reading, and conduct a post-test leak check. Also, leak check the pitot lines as described in EPA Method 2. The lines must pass this leak check in order to validate the velocity-head data.

6.6.11 Calculate percent isokineticity (see Method 2) to determine whether the run was valid or another test should be made.

7.0 SAMPLE RECOVERY

7.1 Preparation:

7.1.1 Proper cleanup procedure begins as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool. When the probe can be handled safely, wipe off all external particulate matter near the tip of the probe nozzle and place a cap over the tip to prevent losing or gaining particulate matter. Do not cap the probe tip tightly while the sampling train is cooling because a vacuum will be created, drawing liquid from the impingers back through the sampling train.

7.1.2 Before moving the sampling train to the cleanup site, remove the probe from the sampling train and cap the open outlet, being careful not to lose any condensate that might be present. Remove the umbilical cord from the last impinger and cap the impinger. If a flexible line is used, let any condensed water or liquid drain into the impingers. Cap off any open impinger inlets and outlets. Ground glass stoppers, Teflon® caps, or caps of other inert materials may be used to seal all openings.

7.1.3 Transfer the probe and impinger assembly to an area that is clean and protected from wind so that the chances of contaminating or losing the sample are minimized.

7.1.4 Inspect the train before and during disassembly, and note any abnormal conditions.

7.1.5 Save a portion of all washing solutions (methylene chloride, water) used for cleanup as a blank. Transfer 200 mL of each solution directly from the wash bottle being used and place each in a separate, pre-labeled sample container.

7.2 Sample Containers:

7.2.1 Container 1: Probe and Impinger Catches. Using a graduated cylinder, measure to the nearest mL, and record the volume of the solution in the first three impingers. Alternatively, the solution may be weighed to the nearest 0.5 g. Include any condensate in the probe in this determination. Transfer the impinger solution from the graduated cylinder into the amber flint glass bottle. Taking care that dust on the outside of the probe or other exterior surfaces does not get into the sample, clean all surfaces to which the sample is exposed (including the probe nozzle, probe fitting, probe liner, first impinger, and impinger connector) with methylene chloride. Use less than 500 mL for the entire wash (250 mL would be better, if possible). Add the washings to the sample container.

7.2.1.1 Carefully remove the probe nozzle and rinse the inside surface with methylene chloride from a wash bottle. Brush with a Teflon® bristle brush, and rinse until the rinse shows no visible particles or yellow color, after which make a final rinse of the inside surface. Brush and rinse the inside parts of the Swagelok® fitting with methylene chloride in a similar way.

7.2.1.2 Rinse the probe liner with methylene chloride. While squirting the methylene chloride into the upper end of the probe, tilt and rotate the probe so that all inside surfaces will be wetted with methylene chloride. Let the methylene chloride drain from the lower end into the sample container. The tester may use a funnel (glass or polyethylene) to aid in transferring the liquid washes to the container. Follow the rinse with a Teflon® brush. Hold the probe in an inclined position, and squirt methylene chloride into the upper end as the probe brush is being pushed with a twisting action through the probe. Hold the sample container underneath the lower end of the probe, and catch any methylene chloride, water, and particulate matter that is brushed from the probe. Run the brush through the probe three times or more. With stainless steel or other metal probes, run the brush through in the above prescribed manner at least six times since there may be small crevices in which particulate matter can be entrapped. Rinse the brush with methylene chloride or water, and quantitatively collect these washings in the sample container. After the brushings, make a final rinse

of the probe as described above.

NOTE: Two people should clean the probe in order to minimize sample losses. Between sampling runs, brushes must be kept clean and free from contamination.

7.2.1.3 Rinse the inside surface of each of the first three impingers (and connecting tubing) three separate times. Use a small portion of methylene chloride for each rinse, and brush each surface to which sample is exposed with a Teflon® bristle brush to ensure recovery of fine particulate matter. Water will be required for the recovery of the impingers in addition to the specified quantity of methylene chloride. There will be at least two phases in the impingers. This two-phase mixture does not pour well, and a significant amount of the impinger catch will be left on the walls. The use of water as a rinse makes the recovery quantitative. Make a final rinse of each surface and of the brush, using both methylene chloride and water.

7.2.1.4 After all methylene chloride and water washings and particulate matter have been collected in the sample container, tighten the lid so that solvent, water, and DNPH reagent will not leak out when the container is shipped to the laboratory. Mark the height of the fluid level to determine whether leakage occurs during transport. Seal the container with Teflon® tape. Label the container clearly to identify its contents.

7.2.1.5 If the first two impingers are to be analyzed separately to check for breakthrough, separate the contents and rinses of the two impingers into individual containers. Care must be taken to avoid physical carryover from the first impinger to the second. The formaldehyde hydrazone is a solid which floats and froths on top of the impinger solution. Any physical carryover of collected moisture into the second impinger will invalidate a breakthrough assessment.

7.2.2 Container 2: Sample Blank. Prepare a blank by using an amber flint glass container and adding a volume of DNPH reagent and methylene chloride equal to the total volume in Container 1. Process the blank in the same manner as Container 1.

7.2.3 Container 3: Silica Gel. Note the color of the indicating silica gel to determine whether it has been completely spent and make a notation of its condition. The impinger containing the silica gel may be used as a sample transport container with both ends sealed with tightly fitting caps or plugs. Ground-glass stoppers or Teflon® caps may be used. The silica gel impinger should then be labeled, covered with aluminum foil, and packaged on ice for transport to the laboratory. If the silica gel is removed from the impinger, the tester may use a funnel to pour the silica gel and a rubber policeman to remove the silica gel from the impinger. It is not necessary to remove the small amount of dust particles that may adhere to the impinger wall and are difficult to remove. Since the gain in weight is to be used for moisture calculations, do not use water or other liquids to transfer the silica gel. If a balance is available in the field, the spent silica gel (or silica gel plus impinger) may be weighed to the nearest 0.5 g.

7.2.4 Sample containers should be placed in a cooler, cooled by although not in contact with ice. Sample containers must be placed vertically and, since they are glass, protected from breakage during shipment. Samples should be cooled during shipment so they will be received cold at the laboratory.

8.0 CALIBRATION

8.1 Probe Nozzle: Probe nozzles shall be calibrated before their initial use in the field. Using a micrometer, measure the inside diameter of the nozzle to the nearest 0.025 mm (0.001 in). Make measurements at three separate places across the diameter and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.004 in). When the nozzles become nicked or corroded, they shall be replaced and calibrated before use. Each nozzle must be permanently and uniquely identified.

8.2 Pitot tube: The Type S pitot tube assembly shall be calibrated according to the procedure outlined in Section 4 of EPA Method 2, or assigned a nominal coefficient of 0.84 if it is not visibly nicked or corroded and if it meets design and intercomponent spacing specifications.

8.3 Metering system:

8.3.1 Before its initial use in the field, the metering system shall be calibrated according to the procedure outlined in APTD-0576. Instead of physically adjusting the dry-gas meter dial readings to correspond to the wet-test meter readings, calibration factors may be used to correct the gas meter dial readings mathematically to the proper values. Before calibrating the metering system, it is suggested that a leak check be conducted. For metering systems having diaphragm pumps, the normal leak check procedure will not detect leakages within the pump. For these cases, the following leak check procedure will apply: make a ten-minute calibration run at 0.00057 m³/min (0.02 cfm). At the end of the run, take the difference of the measured wet-test and dry-gas meter volumes and divide the difference by 10 to get the leak rate. The leak rate should not exceed 0.00057 m³/min (0.02 cfm).

8.3.2 After each field use, check the calibration of the metering system by performing three calibration runs at a single intermediate orifice setting (based on the previous field test). Set the vacuum at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet-test meter and the inlet of the metering system. Calculate the average value of the calibration factor. If the calibration has changed by more than 5%, recalibrate the meter over the full range of orifice settings, as outlined in APTD-0576.

8.3.3 Leak check of metering system: The portion of the sampling train from the pump to the orifice meter (see Figure 1) should be leak-checked prior to initial use and after each shipment. Leakage after the pump will result in less volume being recorded than is actually sampled. Use the following procedure: Close the main valve on the meter box. Insert a one-hole rubber stopper with rubber tubing attached into the orifice exhaust pipe. Disconnect and vent the low side of the orifice manometer. Close off the low side orifice tap. Pressurize the system to 13 - 18 cm (5 - 7 in) water column by blowing into the rubber tubing. Pinch off the tubing and observe the manometer for 1 min. A loss of pressure on the manometer indicates a leak in the meter box. Leaks must be corrected.

NOTE: If the dry-gas-meter coefficient values obtained before and after a test series differ by >5%, either the test series must be voided or calculations for test series must be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

8.4 Probe heater: The probe heating system must be calibrated before its initial use in the field according to the procedure outlined in APTD-0576. Probes constructed according to APTD-0581 need not be calibrated if the calibration curves in APTD-0576 are used.

8.5 Temperature gauges: Each thermocouple must be permanently and uniquely marked on the casting. All mercury-in-glass reference thermometers must conform to ASTM E-1 63C or 63F specifications. Thermocouples should be calibrated in the laboratory with and without the use of extension leads. If extension leads are used in the field, the thermocouple readings at ambient air temperatures, with and without the extension lead, must be noted and recorded. Correction is necessary if the use of an extension lead produces a change $>1.5\%$.

8.5.1 Impinger and dry-gas meter thermocouples: For the thermocouples used to measure the temperature of the gas leaving the impinger train, three-point calibration at ice water, room air, and boiling water temperatures is necessary. Accept the thermocouples only if the readings at all three temperatures agree to $\pm 2^{\circ}\text{C}$ (3.6°F) with those of the absolute value of the reference thermometer.

8.5.2 Probe and stack thermocouple: For the thermocouples used to indicate the probe and stack temperatures, a three-point calibration at ice water, boiling water, and hot oil bath temperatures must be performed. Use of a point at room air temperature is recommended. The thermometer and thermocouple must agree to within 1.5% at each of the calibration points. A calibration curve (equation) may be constructed (calculated) and the data extrapolated to cover the entire temperature range suggested by the manufacturer.

8.6 Barometer: Adjust the barometer initially and before each test series to agree to within ± 2.5 mm Hg (0.1 in Hg) of the mercury barometer or the corrected barometric pressure value reported by a nearby National Weather Service Station (same altitude above sea level).

8.7 Triple-beam balance: Calibrate the triple-beam balance before each test series, using Class S standard weights. The weights must be within $\pm 0.5\%$ of the standards, or the balance must be adjusted to meet these limits.

9.0 CALCULATIONS

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

9.1 Calculation of Total Formaldehyde:

To determine the total formaldehyde in μg , use the following equation:

$$\text{Total mg formaldehyde} = C_d \times V \times DF \times$$

$$\left(\frac{[\text{g/mole aldehyde}]}{[\text{g/mole DNPH derivative}]} \right) \times$$

$$10^{-3} \text{ mg}/\mu\text{g}$$

where:

C_d - measured concentration of DNPH-formaldehyde derivative, $\mu\text{g}/\text{mL}$.

V - organic extract volume, mL

DF - dilution factor

9.2 Formaldehyde concentration in stack gas:

Determine the formaldehyde concentration in the stack gas using the following equation:

$$C_f = K \left[\text{total formaldehyde, mg} \right] / V_{m(\text{std})}$$

where:

$K = 35.31 \text{ ft}^3/\text{m}^3$ if $V_{m(\text{std})}$ is expressed in English units

$= 1.00 \text{ m}^3/\text{m}^3$ if $V_{m(\text{std})}$ is expressed in metric units

$V_{m(\text{std})}$ - volume of gas sample as measured by dry gas meter, corrected to standard conditions, dscm (dscf)

9.3 Average Dry Gas Meter Temperature and Average Orifice Pressure Drop are obtained from the data sheet.

9.4 Dry Gas Volume: Calculate $V_{m(\text{std})}$ and adjust for leakage, if necessary, using the equation in Section 6.3 of EPA Method 5.

9.5 Volume of Water Vapor and Moisture Content: Calculate the volume of water vapor and moisture content from equations 5-2 and 5-3 of EPA Method 5.

10.0 DETERMINATION OF VOLUME TO BE SAMPLED

To determine the minimum sample volume to be collected, use the following sequence of equations.

10.1 From prior analysis of the waste feed, the concentration of formaldehyde (FORM) introduced into the combustion system can be calculated. The degree of destruction and removal efficiency that is required is used to determine the maximum amount of FORM allowed to be present in the effluent. This amount may be expressed as:

Max FORM₁ Mass -

$$[(WF) (FORM_1 \text{ conc}) (100 - \%DRE)] / 100$$

where:

WF - mass flow rate of waste feed per h, g/h (lb/h)

FORM₁ - concentration of FORM (wt %) introduced into the combustion process

DRE - percent Destruction and Removal Efficiency required

Max FORM - mass flow rate (g/h [lb/h]) of FORM emitted from the combustion source

10.2 The average discharge concentration of the FORM in the effluent gas is determined by comparing the Max FORM with the volumetric flow rate being exhausted from the source. Volumetric flow rate data are available as a result of preliminary EPA Method 1 - 4 determinations:

$$\text{Max FORM}_1 \text{ conc} = [\text{Max FORM}_1 \text{ Mass}] / DV_{\text{eff(Std)}}$$

where:

DV_{eff(Std)} - volumetric flow rate of exhaust gas, dscm (dscf)

FORM₁ conc - anticipated concentration of the FORM in the exhaust gas stream, g/dscm (lb/dscf)

10.3 In making this calculation, it is recommended that a safety margin of at least ten be included.

$$[\text{LDL}_{\text{FORM}} \times 10] / [\text{FORM}_1 \text{ conc}] = V_{\text{tbc}}$$

where:

LDL_{FORM} - detectable amount of FORM in entire sampling train

V_{tbc} - minimum dry standard volume to be collected at dry-gas meter

10.4 The following analytical detection limits and DNPH Reagent Capacity (based on a total volume of 200 mL in two impingers) must also be considered in determining a volume to be sampled.

Table 2. Instrument Detection Limits and Reagent Capacity for Formaldehyde Analysis¹

Analyte	Detection Limit, ppbv ²	Reagent Capacity, ppmv
formaldehyde	1.8	66
acetaldehyde	1.7	70
acrolein	1.5	75
acetone/propionaldehyde	1.5	75
butyraldehyde	1.5	79
methyl ethyl ketone	1.5	79
valeraldehyde	1.5	84
isovaleraldehyde	1.4	84
hexaldehyde	1.3	88
benzaldehyde	1.4	84
o-/m-/p-tolualdehyde	1.3	89
dimethylbenzaldehyde	1.2	93

¹ Oxygenated compounds in addition to formaldehyde are included for comparison with formaldehyde; extension of the methodology to other compounds is possible.

² Detection limits are determined in solvent. These values therefore represent the optimum capability of the methodology.

11.0 QUALITY CONTROL

11.1 Sampling: See EPA Manual 600/4-77-027b for Method 5 quality control.

11.2 Analysis: The quality assurance program required for this method includes the analysis of field and method blanks, procedure validations, and analysis of field spikes. The assessment of combustion data and positive identification and quantitation of formaldehyde are dependent on the integrity of the samples received and the precision and accuracy of the analytical methodology. Quality Assurance procedures for this method are designed to monitor the performance of the analytical methodology and to provide the required information to take corrective action if problems are observed in laboratory operations or in field sampling activities.

11.2.1 Field Blanks: Field blanks must be submitted with the samples collected at each sampling site. The field blanks include the sample bottles containing aliquots of sample recovery solvents, methylene chloride and water, and unused DNPH reagent. At a minimum, one complete sampling train will be assembled in the field staging area, taken to the sampling area, and leak-checked at the beginning and end of the testing (or for the same total number of times as the actual sampling train). The probe of the blank train must be heated during the sample test. The train will be recovered as if it were an actual test sample. No gaseous sample will be passed through the Blank sampling train.

11.2.2 Method Blanks: A method blank must be prepared for each set of analytical operations, to evaluate contamination and artifacts that can be derived from glassware, reagents, and sample handling in the laboratory.

11.2.3 Field Spike: A field spike is performed by introducing 200 μ L of the Field Spike Standard into an impinger containing 200 mL of DNPH solution. Standard impinger recovery procedures are followed and the field spike sample is returned to the laboratory for analysis. The field spike is used as a check on field handling and recovery procedures. An aliquot of the field spike standard is retained in the laboratory for derivatization and comparative analysis.

12.0 METHOD PERFORMANCE

12.1 Method performance evaluation: The following expected method performance parameters for precision, accuracy, and detection limits are provided in Table 3.


Table 3. Expected Method Performance for Formaldehyde

Parameter	Precision	¹ Accuracy ²	Detection Limit ³
Matrix: Dual trains	$\pm 15\%$ RPD	$\pm 20\%$	1.5×10^{-7} lb/ft ³ (1.8 ppbv)

¹ Relative percent difference limit for dual trains.


² Limit for field spike recoveries.

³ The lower reporting limit having less than 1% probability of false positive detection.



Formaldehyde Sampling Train

Ambient Temperature _____
 Barometric Pressure _____
 Assumed Moisture % _____
 Probe Length, m(ft) _____
 Nozzle Identification No. _____
 Average Calibrated Nozzle Diameter, cm (in) _____
 Probe Heating Setting _____
 Leak Rate, m³/min. (cfm) _____
 Probe Liner Material _____
 Static Pressure, mm Hg (in. Hg) _____
 Filter No. _____



Schematic of Stack Cross Section

Location _____
 Operator _____
 Date _____
 Run No. _____
 Sample Box No. _____
 Meter Box No. _____
 Meter H₂O _____
 C Factor _____
 Pilot Tube Coefficient C_p _____

Traverse Point Number	Sampling Time (t) Min.	Vacuum mm Hg (in. Hg)	Stack Temperature (T _s) °C(°F)	Velocity Head (P _v) mm (in) H ₂ O	Pressure Differential Across Orifice Meter mm (in) H ₂ O	Gas Sample Volume m ³ (ft ³)	Gas Sample Temp. at Dry Gas Meter		Filter Holder Temperature °C(°F)	Temperature of Gas Leaving Last Impinger °C(°F)
							Inlet °C(°F)	Outlet °C(°F)		
Total										
Average										

Figure 2. Field Data Sheet

PHENOL

Phenol samples were collected using a Method 5 sampling train at 0.75 CFM using neutral-buffered absorbing reagent. The first impinger in each sampling was spiked with isotopically-labeled phenol (phenol-d₅) and 2-fluorophenol for sampling and recovery efficiency surrogates. The recovered samples were extracted and the extracts analyzed by GC/MS for phenol, phenol-d₅ and 2-fluorophenol as per EPA Method 8270. The recoveries of phenol-d₅ and 2-fluorophenol were used to adjust the measured phenol concentrations.

Interpoll Laboratories
4500 Ball Road N.E.
Circle Pines, Minnesota 55014

Telephone (612)786-6020
Facsimile (612)786-7854

COLLECTION OF SEMIVOLATILE COMPOUNDS

EPA METHOD 0010

(Interpoll Method II-8788 - Version 1.0)

EPA Method SW846 USEPA Office of Solid Waste and Emergency Response 3rd
Ed., November 1986: Test Methods for Evaluating Solid Waste Volume 2:
Field Manual Physical/Chemical Methods Method 0010.

METHOD 0010

MODIFIED METHOD 5 SAMPLING TRAIN

1.0 SCOPE AND APPLICATION

1.1 This method is applicable to the determination of Destruction and Removal Efficiency (DRE) of semivolatile Principal Organic Hazardous Compounds (POHCs) from incineration systems (PHS, 1967). This method also may be used to determine particulate emission rates from stationary sources as per EPA Method 5 (see References at end of this method).

2.0 SUMMARY OF METHOD

2.1 Gaseous and particulate pollutants are withdrawn from an emission source at an isokinetic sampling rate and are collected in a multicomponent sampling train. Principal components of the train include a high-efficiency glass- or quartz-fiber filter and a packed bed of porous polymeric adsorbent resin. The filter is used to collect organic-laden particulate materials and the porous polymeric resin to adsorb semivolatile organic species. Semivolatile species are defined as compounds with boiling points $>100^{\circ}\text{C}$.

2.2 Comprehensive chemical analyses of the collected sample are conducted to determine the concentration and identity of the organic materials.

3.0 INTERFERENCES

3.1 Oxides of nitrogen (NO_x) are possible interferents in the determination of certain water-soluble compounds such as dioxane, phenol, and urethane; reaction of these compounds with NO_x in the presence of moisture will reduce their concentration. Other possibilities that could result in positive or negative bias are (1) stability of the compounds in methylene chloride, (2) the formation of water-soluble organic salts on the resin in the presence of moisture, and (3) the solvent extraction efficiency of water-soluble compounds from aqueous media. Use of two or more ions per compound for qualitative and quantitative analysis can overcome interference at one mass. These concerns should be addressed on a compound-by-compound basis before using this method.

4.0 APPARATUS AND MATERIALS

4.1 Sampling train:

4.1.1 A schematic of the sampling train used in this method is shown in Figure 1. This sampling train configuration is adapted from EPA Method 5 procedures, and, as such, the majority of the required equipment




Figure 1. Modified Method 5 Sampling Train.

is identical to that used in EPA Method 5 determinations. The new components required are a condenser coil and a sorbent module, which are used to collect semivolatile organic materials that pass through the glass- or quartz-fiber filter in the gas phase.

4.1.2 Construction details for the basic train components are given in APTD-0581 (see Martin, 1971, in Section 13.0, References); commercial models of this equipment are also available. Specifications for the sorbent module are provided in the following subsections. Additionally, the following subsections list changes to APTD-0581 and identify allowable train configuration modifications.

4.1.3 Basic operating and maintenance procedures for the sampling train are described in APTD-0576 (see Rom, 1972, in Section 13.0, References). As correct usage is important in obtaining valid results, all users should refer to APTD-0576 and adopt the operating and maintenance procedures outlined therein unless otherwise specified. The sampling train consists of the components detailed below.

4.1.3.1 Probe nozzle: Stainless steel (316) or glass with sharp, tapered (30° angle) leading edge. The taper shall be on the outside to preserve a constant I.D. The nozzle shall be buttonhook or elbow design and constructed from seamless tubing (if made of stainless steel). Other construction materials may be considered for particular applications. A range of nozzle sizes suitable for isokinetic sampling should be available in increments of 0.16 cm (1/16 in.), e.g., 0.32-1.27 cm (1/8-1/2 in.), or larger if higher volume sampling trains are used. Each nozzle shall be calibrated according to the procedures outlined in Paragraph 9.1.

4.1.3.2 Probe liner: Borosilicate or quartz-glass tubing with a heating system capable of maintaining a gas temperature of $120 \pm 14^\circ\text{C}$ ($248 \pm 25^\circ\text{F}$) at the exit end during sampling. (The tester may opt to operate the equipment at a temperature lower than that specified.) Because the actual temperature at the outlet of the probe is not usually monitored during sampling, probes constructed according to APTD-0581 and utilizing the calibration curves of APTD-0576 (or calibrated according to the procedure outlined in APTD-0576) are considered acceptable. Either borosilicate or quartz-glass probe liners may be used for stack temperatures up to about 480°C (900°F). Quartz liners shall be used for temperatures between 480 and 900°C (900 and 1650°F). (The softening temperature for borosilicate is 820°C (1508°F), and for quartz 1500°C (2732°F .) Water-cooling of the stainless steel sheath will be necessary at temperatures approaching and exceeding 500°C .

4.1.3.3 Pitot tube: Type S, as described in Section 2.1 of EPA Method 2, or other appropriate devices (Vollaro, 1976). The pitot tube shall be attached to the probe to allow constant monitoring of the stack-gas velocity. The impact (high-pressure) opening plane of the pitot tube shall be even with or above the nozzle entry plane (see EPA Method 2, Figure 2-6b) during sampling. The Type S pitot tube assembly shall have a known coefficient, determined as outlined in Section 4 of EPA Method 2.

0010 - 3

Revision 0
Date September 1986

4.1.3.4 Differential pressure gauge: Inclined manometer or equivalent device as described in Section 2.2 of EPA Method 2. One manometer shall be used for velocity-head (ΔP) readings and the other for orifice differential pressure (ΔH) readings.

4.1.3.5 Filter holder: Borosilicate glass, with a glass frit filter support and a sealing gasket. The sealing gasket should be made of materials that will not introduce organic material into the gas stream at the temperature at which the filter holder will be maintained. The gasket shall be constructed of Teflon or materials of equal or better characteristics. The holder design shall provide a positive seal against leakage at any point along the filter circumference. The holder shall be attached immediately to the outlet of the cyclone or cyclone bypass.

4.1.3.6 Filter heating system: Any heating system capable of maintaining a temperature of $120 \pm 14^\circ\text{C}$ ($248 \pm 25^\circ\text{F}$) around the filter holder during sampling. Other temperatures may be appropriate for particular applications. Alternatively, the tester may opt to operate the equipment at temperatures other than that specified. A temperature gauge capable of measuring temperature to within 3°C (5.4°F) shall be installed so that the temperature around the filter holder can be regulated and monitored during sampling. Heating systems other than the one shown in APTD-0581 may be used.

4.1.3.7 Organic sampling module: This unit consists of three sections, including a gas-conditioning section, a sorbent trap, and a condensate knockout trap. The gas-conditioning system shall be capable of conditioning the gas leaving the back half of the filter holder to a temperature not exceeding 20°C (68°F). The sorbent trap shall be sized to contain approximately 20 g of porous polymeric resin (Rohm and Haas XAD-2 or equivalent) and shall be jacketed to maintain the internal gas temperature at $17 \pm 3^\circ\text{C}$ ($62.5 \pm 5.4^\circ\text{F}$). The most commonly used coolant is ice water from the impinger ice-water bath, constantly circulated through the outer jacket, using rubber or plastic tubing and a peristaltic pump. The sorbent trap should be outfitted with a glass well or depression, appropriately sized to accommodate a small thermocouple in the trap for monitoring the gas entry temperature. The condensate knockout trap shall be of sufficient size to collect the condensate following gas conditioning. The organic module components shall be oriented to direct the flow of condensate formed vertically downward from the conditioning section, through the adsorbent media, and into the condensate knockout trap. The knockout trap is usually similar in appearance to an empty impinger directly underneath the sorbent module; it may be oversized but should have a shortened center stem (at a minimum, one-half the length of the normal impinger stems) to collect a large volume of condensate without bubbling and overflowing into the impinger train. All surfaces of the organic module wetted by the gas sample shall be fabricated of borosilicate glass, Teflon, or other inert materials. Commercial versions of the

complete organic module are not currently available, but may be assembled from commercially available laboratory glassware and a custom-fabricated sorbent trap. Details of two acceptable designs are shown in Figures 2 and 3 (the thermocouple well is shown in Figure 2).

4.1.3.8 Impinger train: To determine the stack-gas moisture content, four 500-mL impingers, connected in series with leak-free ground-glass joints, follow the knockout trap. The first, third, and fourth impingers shall be of the Greenburg-Smith design, modified by replacing the tip with a 1.3-cm (1/2-in.) I.D. glass tube extending about 1.3 cm (1/2 in.) from the bottom of the outer cylinder. The second impinger shall be of the Greenburg-Smith design with the standard tip. The first and second impingers shall contain known quantities of water or appropriate trapping solution. The third shall be empty or charged with a caustic solution, should the stack gas contain hydrochloric acid (HCl). The fourth shall contain a known weight of silica gel or equivalent desiccant.

4.1.3.9 Metering system: The necessary components are a vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 3°C (5.4°F), dry-gas meter capable of measuring volume to within 1%, and related equipment, as shown in Figure 1. At a minimum, the pump should be capable of 4 cfm free flow, and the dry-gas meter should have a recording capacity of 0-999.9 cu ft with a resolution of 0.005 cu ft. Other metering systems capable of maintaining sampling rates within 10% of isokineticity and of determining sample volumes to within 2% may be used. The metering system must be used in conjunction with a pitot tube to enable checks of isokinetic sampling rates. Sampling trains using metering systems designed for flow rates higher than those described in APTD-0581 and APTD-0576 may be used, provided that the specifications of this method are met.

4.1.3.10 Barometer: Mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg). In many cases the barometric reading may be obtained from a nearby National Weather Service station, in which case the station value (which is the absolute barometric pressure) is requested and an adjustment for elevation differences between the weather station and sampling point is applied at a rate of minus 2.5 mm Hg (0.1 in. Hg) per 30-m (100 ft) elevation increase (vice versa for elevation decrease).

4.1.3.11 Gas density determination equipment: Temperature sensor and pressure gauge (as described in Sections 2.3 and 2.4 of EPA Method 2), and gas analyzer, if necessary (as described in EPA Method 3). The temperature sensor ideally should be permanently attached to the pitot tube or sampling probe in a fixed configuration such that the tip of the sensor extends beyond the leading edge of the probe sheath and does not touch any metal.

~6.5 in.
or
168 mm




Figure 2. Adsorbent Sampling System.

0010 - 6

Revision 0
Date September 1986




Figure 3. Adsorbent Sampling System.

0010 - 7

Revision 0
Date September 1986

Alternatively, the sensor may be attached just prior to use in the field. Note, however, that if the temperature sensor is attached in the field, the sensor must be placed in an interference-free arrangement with respect to the Type S pitot tube openings (see EPA Method 2, Figure 2-7). As a second alternative, if a difference of no more than 1% in the average velocity measurement is to be introduced, the temperature gauge need not be attached to the probe or pitot tube.

4.1.3.12 Calibration/field-preparation record: A permanently bound laboratory notebook, in which duplicate copies of data may be made as they are being recorded, is required for documenting and recording calibrations and preparation procedures (i.e., filter and silica gel tare weights, clean XAD-2, quality assurance/quality control check results, dry-gas meter, and thermocouple calibrations, etc.). The duplicate copies should be detachable and should be stored separately in the test program archives.

4.2 Sample Recovery:

4.2.1 Probe liner: Probe nozzle and organic module conditioning section brushes; nylon bristle brushes with stainless steel wire handles are required. The probe brush shall have extensions of stainless steel, Teflon, or inert material at least as long as the probe. The brushes shall be properly sized and shaped to brush out the probe liner, the probe nozzle, and the organic module conditioning section.

4.2.2 Wash bottles: Three. Teflon or glass wash bottles are recommended; polyethylene wash bottles should not be used because organic contaminants may be extracted by exposure to organic solvents used for sample recovery.

4.2.3 Glass sample storage containers: Chemically resistant, borosilicate amber and clear glass bottles, 500-mL or 1,000-mL. Bottles should be tinted to prevent action of light on sample. Screw-cap liners shall be either Teflon or constructed so as to be leak-free and resistant to chemical attack by organic recovery solvents. Narrow-mouth glass bottles have been found to exhibit less tendency toward leakage.

4.2.4 Petri dishes: Glass, sealed around the circumference with wide (1-in.) Teflon tape, for storage and transport of filter samples.

4.2.5 Graduated cylinder and/or balances: To measure condensed water to the nearest 1 mL or 1 g. Graduated cylinders shall have subdivisions not >2 mL. Laboratory triple-beam balances capable of weighing to ± 0.5 g or better are required.

4.2.6 Plastic storage containers: Screw-cap polypropylene or polyethylene containers to store silica gel.

4.2.7 Funnel and rubber policeman: To aid in transfer of silica gel to container (not necessary if silica gel is weighed in field).

4.2.8 Funnels: Glass, to aid in sample recovery.

4.3 Filters: Glass- or quartz-fiber filters, without organic binder, exhibiting at least 99.95% efficiency (<0.05% penetration) on 0.3-um dioctyl phthalate smoke particles. The filter efficiency test shall be conducted in accordance with ASTM standard method D2986-71. Test data from the supplier's quality control program are sufficient for this purpose. In sources containing SO₂ or SO₃, the filter material must be of a type that is unreactive to SO₂ or SO₃. Reeve Angel 934 AH or Schleicher and Schuell #3 filters work well under these conditions.

4.4 Crushed ice: Quantities ranging from 10-50 lb may be necessary during a sampling run, depending on ambient air temperature.

4.5 Stopcock grease: Solvent-insoluble, heat-stable silicone grease. Use of silicone grease upstream of the module is not permitted, and amounts used on components located downstream of the organic module shall be minimized. Silicone grease usage is not necessary if screw-on connectors and Teflon sleeves or ground-glass joints are used.

4.6 Glass wool: Used to plug the unfritted end of the sorbent module. The glass-wool fiber should be solvent-extracted with methylene chloride in a Soxhlet extractor for 12 hr and air-dried prior to use.

5.0 REAGENTS

5.1 Adsorbent resin: Porous polymeric resin (XAD-2 or equivalent) is recommended. These resins shall be cleaned prior to their use for sample collection. Appendix A of this method should be consulted to determine appropriate precleaning procedure. For best results, resin used should not exhibit a blank of higher than 4 mg/kg of total chromatographable organics (TCO) (see Appendix B) prior to use. Once cleaned, resin should be stored in an airtight, wide-mouth amber glass container with a Teflon-lined cap or placed in one of the glass sorbent modules tightly sealed with Teflon film and elastic bands. The resin should be used within 4 wk of the preparation.

5.2 Silica gel: Indicating type, 6-16 mesh. If previously used, dry at 175°C (350°F) for 2 hr before using. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used, subject to the approval of the Administrator.

5.3 Impinger solutions: Distilled organic-free water (Type II) shall be used, unless sampling is intended to quantify a particular inorganic gaseous species. If sampling is intended to quantify the concentration of additional species, the impinger solution of choice shall be subject to Administrator approval. This water should be prescreened for any compounds of interest. One hundred mL will be added to the specified impinger; the third impinger in the train may be charged with a basic solution (1 N sodium hydroxide or sodium acetate) to protect the sampling pump from acidic gases. Sodium acetate should be used when large sample volumes are anticipated because sodium hydroxide will react with carbon dioxide in aqueous media to form sodium carbonate, which may possibly plug the impinger.

0010 - 9

Revision 0
Date September 1986

5.4 Sample recovery reagents:

5.4.1 Methylene chloride: Distilled-in-glass grade is required for sample recovery and cleanup (see Note to 5.4.2 below).

5.4.2 Methyl alcohol: Distilled-in-glass grade is required for sample recovery and cleanup.

NOTE: Organic solvents from metal containers may have a high residue blank and should not be used. Sometimes suppliers transfer solvents from metal to glass bottles; thus blanks shall be run prior to field use and only solvents with low blank value ($<0.001\%$) shall be used.

5.4.3 Water: Water (Type II) shall be used for rinsing the organic module and condenser component.

6.0 SAMPLE COLLECTION, PRESERVATION, AND HANDLING

6.1 Because of complexity of this method, field personnel should be trained in and experienced with the test procedures in order to obtain reliable results.

6.2 Laboratory preparation:

6.2.1 All the components shall be maintained and calibrated according to the procedure described in APTD-0576, unless otherwise specified.

6.2.2 Weigh several 200- to 300-g portions of silica gel in airtight containers to the nearest 0.5 g. Record on each container the total weight of the silica gel plus containers. As an alternative to preweighing the silica gel, it may instead be weighed directly in the impinger or sampling holder just prior to train assembly.

6.2.3 Check filters visually against light for irregularities and flaws or pinhole leaks. Label the shipping containers (glass Petri dishes) and keep the filters in these containers at all times except during sampling and weighing.

6.2.4 Desiccate the filters at $20 \pm 5.6^{\circ}\text{C}$ ($68 \pm 10^{\circ}\text{F}$) and ambient pressure for at least 24 hr, and weigh at intervals of at least 6 hr to a constant weight (i.e., $<0.5\text{-mg}$ change from previous weighing), recording results to the nearest 0.1 mg. During each weighing the filter must not be exposed for more than a 2-min period to the laboratory atmosphere and relative humidity above 50%. Alternatively (unless otherwise specified by the Administrator), the filters may be oven-dried at 105°C (220°F) for 2-3 hr, desiccated for 2 hr, and weighed.

0010 - 10

Revision 0
Date September 1986

6.3 Preliminary field determinations:

6.3.1 Select the sampling site and the minimum number of sampling points according to EPA Method 1 or as specified by the Administrator. Determine the stack pressure, temperature, and range of velocity heads using EPA Method 2. It is recommended that a leak-check of the pitot lines (see EPA Method 2, Section 3.1) be performed. Determine the stack-gas moisture content using EPA Approximation Method 4 or its alternatives to establish estimates of isokinetic sampling-rate settings. Determine the stack-gas dry molecular weight, as described in EPA Method 2, Section 3.6. If integrated EPA Method 3 sampling is used for molecular weight determination, the integrated bag sample shall be taken simultaneously with, and for the same total length of time as, the sample run.

6.3.2 Select a nozzle size based on the range of velocity heads so that it is not necessary to change the nozzle size in order to maintain isokinetic sampling rates. During the run, do not change the nozzle. Ensure that the proper differential pressure gauge is chosen for the range of velocity heads encountered (see Section 2.2 of EPA Method 2).

6.3.3 Select a suitable probe liner and probe length so that all traverse points can be sampled. For large stacks, to reduce the length of the probe, consider sampling from opposite sides of the stack.

6.3.4 A minimum of 3 dscm (105.9 dscf) of sample volume is required for the determination of the Destruction and Removal Efficiency (DRE) of POHCs from incineration systems. Additional sample volume shall be collected as necessitated by analytical detection limit constraints. To determine the minimum sample volume required, refer to sample calculations in Section 10.0.

6.3.5 Determine the total length of sampling time needed to obtain the identified minimum volume by comparing the anticipated average sampling rate with the volume requirement. Allocate the same time to all traverse points defined by EPA Method 1. To avoid timekeeping errors, the length of time sampled at each traverse point should be an integer or an integer plus one-half min.

6.3.6 In some circumstances (e.g., batch cycles) it may be necessary to sample for shorter times at the traverse points and to obtain smaller gas-sample volumes. In these cases, the Administrator's approval must first be obtained.

6.4 Preparation of collection train:

6.4.1 During preparation and assembly of the sampling train, keep all openings where contamination can occur covered with Teflon film or aluminum foil until just prior to assembly or until sampling is about to begin.

6.4.2 Fill the sorbent trap section of the organic module with approximately 20 g of clean adsorbent resin. While filling, ensure that the trap packs uniformly, to eliminate the possibility of channeling. When freshly cleaned, many adsorbent resins carry a static charge, which will cause clinging to trap walls. This may be minimized by filling the trap in the presence of an antistatic device. Commercial antistatic devices include Model-204 and Model-210 manufactured by the 3M Company, St. Paul, Minnesota.

6.4.3 If an impinger train is used to collect moisture, place 100 mL of water in each of the first two impingers, leave the third impinger empty (or charge with caustic solution, as necessary), and transfer approximately 200-300 g of preweighed silica gel from its container to the fourth impinger. More silica gel may be used, but care should be taken to ensure that it is not entrained and carried out from the impinger during sampling. Place the container in a clean place for later use in the sample recovery. Alternatively, the weight of the silica gel plus impinger may be determined to the nearest 0.5 g and recorded.

6.4.4 Using a tweezer or clean disposable surgical gloves, place a labeled (identified) and weighed filter in the filter holder. Be sure that the filter is properly centered and the gasket properly placed to prevent the sample gas stream from circumventing the filter. Check the filter for tears after assembly is completed.

6.4.5 When glass liners are used, install the selected nozzle using a Viton-A O-ring when stack temperatures are $<260^{\circ}\text{C}$ (500°F) and a woven glass-fiber gasket when temperatures are higher. See APTD-0576 (Rom, 1972) for details. Other connecting systems utilizing either 316 stainless steel or Teflon ferrules may be used. When metal liners are used, install the nozzle as above, or by a leak-free direct mechanical connection. Mark the probe with heat-resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point.

6.4.6 Set up the train as in Figure 1. During assembly, do not use any silicone grease on ground-glass joints that are located upstream of the organic module. A very light coating of silicone grease may be used on all ground-glass joints that are located downstream of the organic module, but it should be limited to the outer portion (see APTD-0576) of the ground-glass joints to minimize silicone-grease contamination. Subject to the approval of the Administrator, a glass cyclone may be used between the probe and the filter holder when the total particulate catch is expected to exceed 100 mg or when water droplets are present in the stack. The organic module condenser must be maintained at a temperature of $17 \pm 3^{\circ}\text{C}$. Connect all temperature sensors to an appropriate potentiometer/display unit. Check all temperature sensors at ambient temperature.

6.4.7 Place crushed ice around the impingers and the organic module condensate knockout.

0010 - 12

Revision 0
Date September 1986

6.4.8 Turn on the sorbent module and condenser coil coolant recirculating pump and begin monitoring the sorbent module gas entry temperature. Ensure proper sorbent module gas entry temperature before proceeding and again before any sampling is initiated. It is extremely important that the XAD-2 resin temperature never exceed 50°C (122°F), because thermal decomposition will occur. During testing, the XAD-2 temperature must not exceed 20°C (68°F) for efficient capture of the semivolatiles of interest.

6.4.9 Turn on and set the filter and probe heating systems at the desired operating temperatures. Allow time for the temperatures to stabilize.

6.5 Leak-check procedures

6.5.1 Pre-test leak-check:

6.5.1.1 Because the number of additional intercomponent connections in the Semi-VOST train (over the M5 Train) increases the possibility of leakage, a pre-test leak-check is required.

6.5.1.2 After the sampling train has been assembled, turn on and set the filter and probe heating systems at the desired operating temperatures. Allow time for the temperatures to stabilize. If a Viton A O-ring or other leak-free connection is used in assembling the probe nozzle to the probe liner, leak-check the train at the sampling site by plugging the nozzle and pulling a 381-mm Hg (15-in. Hg) vacuum.

(NOTE: A lower vacuum may be used, provided that it is not exceeded during the test.)

6.5.1.3 If an asbestos string is used, do not connect the probe to the train during the leak-check. Instead, leak-check the train by first attaching a carbon-filled leak-check impinger (shown in Figure 4) to the inlet of the filter holder (cyclone, if applicable) and then plugging the inlet and pulling a 381-mm Hg (15-in. Hg) vacuum. (Again, a lower vacuum may be used, provided that it is not exceeded during the test.) Then, connect the probe to the train and leak-check at about 25-mm Hg (1-in. Hg) vacuum; alternatively, leak-check the probe with the rest of the sampling train in one step at 381-mm Hg (15-in. Hg) vacuum. Leakage rates in excess of 4% of the average sampling rate or $>0.00057 \text{ m}^3/\text{min}$ (0.02 cfm), whichever is less, are unacceptable.

6.5.1.4 The following leak-check instructions for the sampling train described in APTD-0576 and APTD-0581 may be helpful. Start the pump with fine-adjust valve fully open and coarse-adjust valve completely closed. Partially open the coarse-adjust valve and slowly close the fine-adjust valve until the desired vacuum is reached. Do not reverse direction of the fine-adjust valve; this will cause water to back up into the organic module. If the desired vacuum is exceeded, either leak-check at this higher vacuum or end the leak-check, as shown below, and start over.

0010 - 13

Revision 0
Date September 1986

CROSS SECTIONAL VIEW
Leak Testing Apparatus




Figure 4. Leak-check impinger.

0010 - 14

Revision 0
Date September 1986

6.5.1.5 When the leak-check is completed, first slowly remove the plug from the inlet to the probe, filter holder, or cyclone (if applicable). When the vacuum drops to 127 mm (5 in.) Hg or less, immediately close the coarse-adjust valve. Switch off the pumping system and reopen the fine-adjust valve. Do not reopen the fine-adjust valve until the coarse-adjust valve has been closed. This prevents the water in the impingers from being forced backward into the organic module and silica gel from being entrained backward into the third impinger.

6.5.2 Leak-checks during sampling run:

6.5.2.1 If, during the sampling run, a component (e.g., filter assembly, impinger, or sorbent trap) change becomes necessary, a leak-check shall be conducted immediately after the interruption of sampling and before the change is made. The leak-check shall be done according to the procedure outlined in Paragraph 6.5.1, except that it shall be done at a vacuum greater than or equal to the maximum value recorded up to that point in the test. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable, and no correction will need to be applied to the total volume of dry gas metered. If a higher leakage rate is obtained, the tester shall void the sampling run. (It should be noted that any "correction" of the sample volume by calculation reduces the integrity of the pollutant concentrations data generated and must be avoided.)

6.5.2.2 Immediately after a component change, and before sampling is reinitiated, a leak-check similar to a pre-test leak-check must also be conducted.

6.5.3 Post-test leak-check:

6.5.3.1 A leak-check is mandatory at the conclusion of each sampling run. The leak-check shall be done with the same procedures as those with the pre-test leak-check, except that it shall be conducted at a vacuum greater than or equal to the maximum value reached during the sampling run. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable, and no correction need be applied to the total volume of dry gas metered. If, however, a higher leakage rate is obtained, the tester shall either record the leakage rate, correct the sample volume (as shown in the calculation section of this method), and consider the data obtained of questionable reliability, or void the sampling run.

6.6 Sampling-train operation:

6.6.1 During the sampling run, maintain an isokinetic sampling rate to within 10% of true isokinetic, unless otherwise specified by the Administrator. Maintain a temperature around the filter of 120 ± 14°C (248 ± 25°F) and a gas temperature entering the sorbent trap at a maximum of 20°C (68°F).

0010 - 15

Revision 0
Date September 1986

6.6.2 For each run, record the data required on a data sheet such as the one shown in Figure 5. Be sure to record the initial dry-gas meter reading. Record the dry-gas meter readings at the beginning and end of each sampling time increment, when changes in flow rates are made before and after each leak-check, and when sampling is halted. Take other readings required by Figure 5 at least once at each sample point during each time increment and additional readings when significant changes (20% variation in velocity-head readings) necessitate additional adjustments in flow rate. Level and zero the manometer. Because the manometer level and zero may drift due to vibrations and temperature changes, make periodic checks during the traverse.

6.6.3 Clean the stack access ports prior to the test run to eliminate the chance of sampling deposited material. To begin sampling, remove the nozzle cap, verify that the filter and probe heating systems are at the specified temperature, and verify that the pitot tube and probe are properly positioned. Position the nozzle at the first traverse point, with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Nomographs, which aid in the rapid adjustment of the isokinetic sampling rate without excessive computations, are available. These nomographs are designed for use when the Type S pitot-tube coefficient is 0.84 ± 0.02 and the stack-gas equivalent density (dry molecular weight) is equal to 29 ± 4 . APTD-0576 details the procedure for using the nomographs. If the stack-gas molecular weight and the pitot-tube coefficient are outside the above ranges, do not use the nomographs unless appropriate steps (Shigehara, 1974) are taken to compensate for the deviations.

6.6.4 When the stack is under significant negative pressure (equivalent to the height of the impinger stem), take care to close the coarse-adjust valve before inserting the probe into the stack, to prevent water from backing into the organic module. If necessary, the pump may be turned on with the coarse-adjust valve closed.

6.6.5 When the probe is in position, block off the openings around the probe and stack access port to prevent unrepresentative dilution of the gas stream.

6.6.6 Traverse the stack cross section, as required by EPA Method 1 or as specified by the Administrator, being careful not to bump the probe nozzle into the stack walls when sampling near the walls or when removing or inserting the probe through the access port, in order to minimize the chance of extracting deposited material.

6.6.7 During the test run, make periodic adjustments to keep the temperature around the filter holder and the organic module at the proper levels; add more ice and, if necessary, salt to maintain a temperature of $<20^{\circ}\text{C}$ (68°F) at the condenser/silica gel outlet. Also, periodically check the level and zero of the manometer.

6.6.8 If the pressure drop across the filter or sorbent trap becomes too high, making isokinetic sampling difficult to maintain, the filter/sorbent trap may be replaced in the midst of a sample run. Using another complete filter holder/sorbent trap assembly is recommended, rather than attempting to change the filter and resin themselves. After a new filter/sorbent trap assembly is installed, conduct a leak-check. The total particulate weight shall include the summation of all filter assembly catches.

6.6.9 A single train shall be used for the entire sample run, except in cases where simultaneous sampling is required in two or more separate ducts or at two or more different locations within the same duct, or in cases where equipment failure necessitates a change of trains. In all other situations, the use of two or more trains will be subject to the approval of the Administrator.

6.6.10 Note that when two or more trains are used, separate analysis of the front-half (if applicable) organic-module and impinger (if applicable) catches from each train shall be performed, unless identical nozzle sizes were used on all trains. In that case, the front-half catches from the individual trains may be combined (as may the impinger catches), and one analysis of front-half catch and one analysis of impinger catch may be performed.

6.6.11 At the end of the sample run, turn off the coarse-adjust valve, remove the probe and nozzle from the stack, turn off the pump, record the final dry-gas meter reading, and conduct a post-test leak-check. Also, leak-check the pitot lines as described in EPA Method 2. The lines must pass this leak-check in order to validate the velocity-head data.

6.6.12 Calculate percent isokineticity (see Section 10.8) to determine whether the run was valid or another test run should be made.

7.0 SAMPLE RECOVERY

7.1 Preparation:

7.1.1 Proper cleanup procedure begins as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool. When the probe can be safely handled, wipe off all external particulate matter near the tip of the probe nozzle and place a cap over the tip to prevent losing or gaining particulate matter. Do not cap the probe tip tightly while the sampling train is cooling down because this will create a vacuum in the filter holder, drawing water from the impingers into the sorbent module.

7.1.2 Before moving the sample train to the cleanup site, remove the probe from the sample train and cap the open outlet, being careful not to lose any condensate that might be present. Cap the filter inlet.

Remove the umbilical cord from the last impinger and cap the impinger. If a flexible line is used between the organic module and the filter holder, disconnect the line at the filter holder and let any condensed water or liquid drain into the organic module.

7.1.3 Cap the filter-holder outlet and the inlet to the organic module. Separate the sorbent trap section of the organic module from the condensate knockout trap and the gas-conditioning section. Cap all organic module openings. Disconnect the organic-module knockout trap from the impinger train inlet and cap both of these openings. Ground-glass stoppers, Teflon caps, or caps of other inert materials may be used to seal all openings.

7.1.4 Transfer the probe, the filter, the organic-module components, and the impinger/condenser assembly to the cleanup area. This area should be clean and protected from the weather to minimize sample contamination or loss.

7.1.5 Save a portion of all washing solutions (methanol/methylene chloride, Type II water) used for cleanup as a blank. Transfer 200 mL of each solution directly from the wash bottle being used and place each in a separate, pre-labeled glass sample container.

7.1.6 Inspect the train prior to and during disassembly and note any abnormal conditions.

7.2 Sample containers:

7.2.1 Container no. 1: Carefully remove the filter from the filter holder and place it in its identified Petri dish container. Use a pair or pairs of tweezers to handle the filter. If it is necessary to fold the filter, ensure that the particulate cake is inside the fold. Carefully transfer to the Petri dish any particulate matter or filter fibers that adhere to the filter-holder gasket, using a dry nylon bristle brush or sharp-edged blade, or both. Label the container and seal with 1-in.-wide Teflon tape around the circumference of the lid.

7.2.2 Container no. 2: Taking care that dust on the outside of the probe or other exterior surfaces does not get into the sample, quantitatively recover particulate matter or any condensate from the probe nozzle, probe fitting, probe liner, and front half of the filter holder by washing these components first with methanol/methylene chloride (1:1 v/v) into a glass container. Distilled water may also be used. Retain a water and solvent blank and analyze in the same manner as with the samples. Perform rinses as follows:

7.2.2.1 Carefully remove the probe nozzle and clean the inside surface by rinsing with the solvent mixture (1:1 v/v methanol/-methylene chloride) from a wash bottle and brushing with a nylon bristle brush. Brush until the rinse shows no visible particles; then make a final rinse of the inside surface with the solvent mix. Brush and rinse the inside parts of the Swagelok fitting with the solvent mix in a similar way until no visible particles remain.

7.2.2.2 Have two people rinse the probe liner with the solvent mix by tilting and rotating the probe while squirting solvent into its upper end so that all inside surfaces will be wetted with solvent. Let the solvent drain from the lower end into the sample container. A glass funnel may be used to aid in transferring liquid washes to the container.

7.2.2.3 Follow the solvent rinse with a probe brush. Hold the probe in an inclined position and squirt solvent into the upper end while pushing the probe brush through the probe with a twisting action; place a sample container underneath the lower end of the probe and catch any solvent and particulate matter that is brushed from the probe. Run the brush through the probe three times or more until no visible particulate matter is carried out with the solvent or until none remains in the probe liner on visual inspection. With stainless steel or other metal probes, run the brush through in the above-prescribed manner at least six times (metal probes have small crevices in which particulate matter can be entrapped). Rinse the brush with solvent and quantitatively collect these washings in the sample container. After the brushing, make a final solvent rinse of the probe as described above.

7.2.2.4 It is recommended that two people work together to clean the probe to minimize sample losses. Between sampling runs, keep brushes clean and protected from contamination.

7.2.2.5 Clean the inside of the front half of the filter holder and cyclone/cyclone flask, if used, by rubbing the surfaces with a nylon bristle brush and rinsing with methanol/methylene chloride (1:1 v/v) mixture. Rinse each surface three times or more if needed to remove visible particulate. Make a final rinse of the brush and filter holder. Carefully rinse out the glass cyclone and cyclone flask (if applicable). Brush and rinse any particulate material adhering to the inner surfaces of these components into the front-half rinse sample. After all solvent washings and particulate matter have been collected in the sample container, tighten the lid on the sample container so that solvent will not leak out when it is shipped to the laboratory. Mark the height of the fluid level to determine whether leakage occurs during transport. Label the container to identify its contents.

7.2.3 Container no. 3: The sorbent trap section of the organic module may be used as a sample transport container, or the spent resin may be transferred to a separate glass bottle for shipment. If the sorbent trap itself is used as the transport container, both ends should be sealed with tightly fitting caps or plugs. Ground-glass stoppers or Teflon caps may be used. The sorbent trap should then be labeled, covered with aluminum foil, and packaged on ice for transport to the laboratory. If a separate bottle is used, the spent resin should be quantitatively transferred from the trap into the clean bottle. Resin that adheres to the walls of the trap should be recovered using a rubber policeman or spatula and added to this bottle.

0010 - 20

Revision 0
Date September 1986

7.2.4 Container no. 4: Measure the volume of condensate collected in the condensate knockout section of the organic module to within +1 mL by using a graduated cylinder or by weighing to within +0.5 g using a triple-beam balance. Record the volume or weight of liquid present and note any discoloration or film in the liquid catch. Transfer this liquid to a prelabeled glass sample container. Inspect the back half of the filter housing and the gas-conditioning section of the organic module. If condensate is observed, transfer it to a graduated or weighing bottle and measure the volume, as described above. Add this material to the condensate knockout-trap catch.

7.2.5 Container no. 5: All sampling train components located between the high-efficiency glass- or quartz-fiber filter and the first wet impinger or the final condenser system (including the heated Teflon line connecting the filter outlet to the condenser) should be thoroughly rinsed with methanol/methylene chloride (1:1 v/v) and the rinsings combined. This rinse shall be separated from the condensate. If the spent resin is transferred from the sorbent trap to a separate sample container for transport, the sorbent trap shall be thoroughly rinsed until all sample-wetted surfaces appear clean. Visible films should be removed by brushing. Whenever train components are brushed, the brush should be subsequently rinsed with solvent mixture and the rinsings added to this container.

7.2.6 Container no. 6: Note the color of the indicating silica gel to determine if it has been completely spent and make a notation of its condition. Transfer the silica gel from the fourth impinger to its original container and seal. A funnel may make it easier to pour the silica gel without spilling. A rubber policeman may be used as an aid in removing the silica gel from the impinger. It is not necessary to remove the small amount of dust particles that may adhere strongly to the impinger wall. Because the gain in weight is to be used for moisture calculations, do not use any water or other liquids to transfer the silica gel. If a balance is available in the field, weigh the container and its contents to 0.5 g or better.

7.3 Impinger water:

7.3.1 Make a notation of any color or film in the liquid catch. Measure the liquid in the first three impingers to within +1 mL by using a graduated cylinder or by weighing it to within +0.5 g by using a balance (if one is available). Record the volume or weight of liquid present. This information is required to calculate the moisture content of the effluent gas.

7.3.2 Discard the liquid after measuring and recording the volume or weight, unless analysis of the impinger catch is required (see Paragraph 4.1.3.7). Amber glass containers should be used for storage of impinger catch, if required.

7.3.3 If a different type of condenser is used, measure the amount of moisture condensed either volumetrically or gravimetrically.

7.4 Sample preparation for shipment: Prior to shipment, recheck all sample containers to ensure that the caps are well secured. Seal the lids of all containers around the circumference with Teflon tape. Ship all liquid samples upright on ice and all particulate filters with the particulate catch facing upward. The particulate filters should be shipped unrefrigerated.

8.0 ANALYSIS

8.1 Sample preparation:

8.1.1 General: The preparation steps for all samples will result in a finite volume of concentrated solvent. The final sample volume (usually in the 1- to 10-mL range) is then subjected to analysis by GC/MS. All samples should be inspected and the appearance documented. All samples are to be spiked with surrogate standards as received from the field prior to any sample manipulations. The spike should be at a level equivalent to 10 times the MDL when the solvent is reduced in volume to the desired level (i.e., 10 mL). The spiking compounds should be the stable isotopically labeled analog of the compounds of interest or a compound that would exhibit properties similar to the compounds of interest, be easily chromatographed, and not interfere with the analysis of the compounds of interest. Suggested surrogate spiking compounds are: deuterated naphthalene, chrysene, phenol, nitrobenzene, chlorobenzene, toluene, and carbon-13-labeled pentachlorophenol.

8.1.2 Condensate: The "condensate" is the moisture collected in the first impinger following the XAD-2 module. Spike the condensate with the surrogate standards. The volume is measured and recorded and then transferred to a separatory funnel. The pH is to be adjusted to pH 2 with 6 N sulfuric acid, if necessary. The sample container and graduated cylinder are sequentially rinsed with three successive 10-mL aliquots of the extraction solvent and added to the separatory funnel. The ratio of solvent to aqueous sample should be maintained at 1:3. Extract the sample by vigorously shaking the separatory funnel for 5 min. After complete separation of the phases, remove the solvent and transfer to a Kuderna-Danish concentrator (K-D), filtering through a bed of pre-cleaned, dry sodium sulfate. Repeat the extraction step two additional times. Adjust the pH to 11 with 6 N sodium hydroxide and reextract combining the acid and base extracts. Rinse the sodium sulfate into the K-D with fresh solvent and discard the desiccant. Add Teflon boiling chips and concentrate to 10 mL by reducing the volume to slightly less than 10 mL and then bringing to volume with fresh solvent. In order to achieve the necessary detection limit, the sample volume can be further reduced to 1 mL by using a micro column K-D or nitrogen blow-down. Should the sample start to exhibit precipitation, the concentration step should be stopped and the sample redissolved with fresh solvent taking the volume to some finite amount. After adding a standard (for the purpose of quantitation by GC/MS), the sample is ready for analysis, as discussed in Paragraph 8.2.

0010 - 22

Revision 0
Date September 1986

8.1.3 Impinger: Spike the sample with the surrogate standards; measure and record the volume and transfer to a separatory funnel. Proceed as described in Paragraph 8.1.2.

8.1.4 XAD-2: Spike the resin directly with the surrogate standards. Transfer the resin to the all-glass thimbles by the following procedure (care should be taken so as not to contaminate the thimble by touching it with anything other than tweezers or other solvent-rinsed mechanical holding devices). Suspend the XAD-2 module directly over the thimble. The glass frit of the module (see Figure 2) should be in the up position. The thimble is contained in a clean beaker, which will serve to catch the solvent rinses. Using a Teflon squeeze bottle, flush the XAD-2 into the thimble. Thoroughly rinse the glass module with solvent into the beaker containing the thimble. Add the XAD-2 glass-wool plug to the thimble. Cover the XAD-2 in the thimble with a precleaned glass-wool plug sufficient to prevent the resin from floating into the solvent reservoir of the extractor. If the resin is wet, effective extraction can be accomplished by loosely packing the resin in the thimble. If a question arises concerning the completeness of the extraction, a second extraction, without a spike, is advised. The thimble is placed in the extractor and the rinse solvent contained in the beaker is added to the solvent reservoir. Additional solvent is added to make the reservoir approximately two-thirds full. Add Teflon boiling chips and assemble the apparatus. Adjust the heat source to cause the extractor to cycle 5-6 times per hr. Extract the resin for 16 hr. Transfer the solvent and three 10-mL rinses of the reservoir to a K-D and concentrate as described in Paragraph 8.1.2.

8.1.5 Particulate filter (and cyclone catch): If particulate loading is to be determined, weigh the filter (and cyclone catch, if applicable). The particulate filter (and cyclone catch, if applicable) is transferred to the glass thimble and extracted simultaneously with the XAD-2 resin.

8.1.6 Train solvent rinses: All train rinses (i.e., probe, impinger, filter housing) using the extraction solvent and methanol are returned to the laboratory as a single sample. If the rinses are contained in more than one container, the intended spike is divided equally among the containers proportioned from a single syringe volume. Transfer the rinse to a separatory funnel and add a sufficient amount of organic-free water so that the methylene chloride becomes immiscible and its volume no longer increases with the addition of more water. The extraction and concentration steps are then performed as described in Paragraph 8.1.2.

8.2 Sample analysis:

8.2.1 The primary analytical tool for the measurement of emissions from hazardous waste incinerators is GC/MS using fused-silica capillary GC columns, as described in Method 8270 in Chapter Four of this manual. Because of the nature of GC/MS instrumentation and the cost associated

with sample analysis, prescreening of the sample extracts by gas chromatography/flame ionization detection (GC/FID) or with electron capture (GC/ECD) is encouraged. Information regarding the complexity and concentration level of a sample prior to GC/MS analysis can be of enormous help. This information can be obtained by using either capillary columns or less expensive packed columns. However, the FID screen should be performed with a column similar to that used with the GC/MS. Keep in mind that GC/FID has a slightly lower detection limit than GC/MS and, therefore, that the concentration of the sample can be adjusted either up or down prior to analysis by GC/MS.

8.2.2 The mass spectrometer will be operated in a full scan (40-450) mode for most of the analyses. The range for which data are acquired in a GC/MS run will be sufficiently broad to encompass the major ions, as listed in Chapter Four, Method 8270, for each of the designated POHCs in an incinerator effluent analysis.

8.2.3 For most purposes, electron ionization (EI) spectra will be collected because a majority of the POHCs give reasonable EI spectra. Also, EI spectra are compatible with the NBS Library of Mass Spectra and other mass spectral references, which aid in the identification process for other components in the incinerator process streams.

8.2.4 To clarify some identifications, chemical ionization (CI) spectra using either positive ions or negative ions will be used to elucidate molecular-weight information and simplify the fragmentation patterns of some compounds. In no case, however, should CI spectra alone be used for compound identification. Refer to Chapter Four, Method 8270, for complete descriptions of GC conditions, MS conditions, and quantitative and quantitative identification.

9.0 CALIBRATION

9.1 Probe nozzle: Probe nozzles shall be calibrated before their initial use in the field. Using a micrometer, measure the inside diameter of the nozzle to the nearest 0.025 mm (0.001 in.). Make measurements at three separate places across the diameter and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.004 in.). When nozzles become nicked, dented, or corroded, they shall be reshaped, sharpened, and recalibrated before use. Each nozzle shall be permanently and uniquely identified.

9.2 Pitot tube: The Type S pitot tube assembly shall be calibrated according to the procedure outlined in Section 4 of EPA Method 2, or assigned a nominal coefficient of 0.84 if it is not visibly nicked, dented, or corroded and if it meets design and intercomponent spacing specifications.

9.3 Metering system:

9.3.1 Before its initial use in the field, the metering system shall be calibrated according to the procedure outlined in APTD-0576. Instead of physically adjusting the dry-gas meter dial readings to correspond to the wet-test meter readings, calibration factors may be used to correct the gas meter dial readings mathematically to the proper values. Before calibrating the metering system, it is suggested that a leak-check be conducted. For metering systems having diaphragm pumps, the normal leak-check procedure will not detect leakages within the pump. For these cases the following leak-check procedure is suggested: Make a 10-min calibration run at $0.00057 \text{ m}^3/\text{min}$ (0.02 cfm); at the end of the run, take the difference of the measured wet-test and dry-gas meter volumes and divide the difference by 10 to get the leak rate. The leak rate should not exceed $0.00057 \text{ m}^3/\text{min}$ (0.02 cfm).

9.3.2 After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single intermediate orifice setting (based on the previous field test). The vacuum shall be set at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet-test meter and the inlet of the metering system. Calculate the average value of the calibration factor. If the calibration has changed by more than 5%, recalibrate the meter over the full range of orifice settings, as outlined in APTD-0576.

9.3.3 Leak-check of metering system: That portion of the sampling train from the pump to the orifice meter (see Figure 1) should be leak-checked prior to initial use and after each shipment. Leakage after the pump will result in less volume being recorded than is actually sampled. The following procedure is suggested (see Figure 6): Close the main valve on the meter box. Insert a one-hole rubber stopper with rubber tubing attached into the orifice exhaust pipe. Disconnect and vent the low side of the orifice manometer. Close off the low side orifice tap. Pressurize the system to 13-18 cm (5-7 in.) water column by blowing into the rubber tubing. Pinch off the tubing and observe the manometer for 1 min. A loss of pressure on the manometer indicates a leak in the meter box. Leaks, if present, must be corrected.

NOTE: If the dry-gas-meter coefficient values obtained before and after a test series differ by >5%, either the test series shall be voided or calculations for test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

9.4 Probe heater: The probe-heating system shall be calibrated before its initial use in the field according to the procedure outlined in APTD-0576. Probes constructed according to APTD-0581 need not be calibrated if the calibration curves in APTD-0576 are used.




Figure 8. Leak check of meter box.

9.5 Temperature gauges: Each thermocouple must be permanently and uniquely marked on the casting; all mercury-in-glass reference thermometers must conform to ASTM E-1 63C or 63F specifications. Thermocouples should be calibrated in the laboratory with and without the use of extension leads. If extension leads are used in the field, the thermocouple readings at ambient air temperatures, with and without the extension lead, must be noted and recorded. Correction is necessary if the use of an extension lead produces a change $>1.5\%$.

9.5.1 Impinger, organic module, and dry-gas meter thermocouples: For the thermocouples used to measure the temperature of the gas leaving the impinger train and the XAD-2 resin bed, three-point calibration at ice-water, room-air, and boiling-water temperatures is necessary. Accept the thermocouples only if the readings at all three temperatures agree to $+2^{\circ}\text{C}$ (3.6°F) with those of the absolute value of the reference thermometer.

9.5.2 Probe and stack thermocouple: For the thermocouples used to indicate the probe and stack temperatures, a three-point calibration at ice-water, boiling-water, and hot-oil-bath temperatures must be performed; it is recommended that room-air temperature be added, and that the thermometer and the thermocouple agree to within 1.5% at each of the calibration points. A calibration curve (equation) may be constructed (calculated) and the data extrapolated to cover the entire temperature range suggested by the manufacturer.

9.6 Barometer: Adjust the barometer initially and before each test series to agree to within $+25$ mm Hg (0.1 in. Hg) of the mercury barometer or the corrected barometric pressure value reported by a nearby National Weather Service Station (same altitude above sea level).

9.7 Triple-beam balance: Calibrate the triple-beam balance before each test series, using Class-S standard weights; the weights must be within $\pm 0.5\%$ of the standards, or the balance must be adjusted to meet these limits.

10.0 CALCULATIONS

10.1 Carry out calculations. Round off figures after the final calculation to the correct number of significant figures.

10.2 Nomenclature:

A_n = Cross-sectional area of nozzle, m^2 (ft^2).

B_{ws} = Water vapor in the gas stream, proportion by volume.

C_d = Type S pitot tube coefficient (nominally 0.84 ± 0.02), dimensionless.

I = Percent of isokinetic sampling.

- L_a = Maximum acceptable leakage rate for a leak-check, either pre-test or following a component change; equal to $0.00057 \text{ m}^3/\text{min}$ (0.02 cfm) or 4% of the average sampling rate, whichever is less.
- L_i = Individual leakage rate observed during the leak-check conducted prior to the "ith" component change ($i = 1, 2, 3 \dots n$) m^3/min (cfm).
- L_p = Leakage rate observed during the post-test leak-check, m^3/min (cfm).
- M_d = Stack-gas dry molecular weight, g/g-mole (lb/lb-mole).
- M_w = Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).
- P_{bar} = Barometric pressure at the sampling site, mm Hg (in. Hg).
- P_s = Absolute stack-gas pressure, mm Hg (in. Hg).
- P_{std} = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).
- R = Ideal gas constant, $0.06236 \text{ mm Hg} \cdot \text{m}^3/\text{K} \cdot \text{g-mole}$ (21.85 in. Hg-ft³/^{°R}-lb-mole).
- T_m = Absolute average dry-gas meter temperature (see Figure 6), K (^{°R}).
- T_s = Absolute average stack-gas temperature (see Figure 6), K (^{°R}).
- T_{std} = Standard absolute temperature, 293K (528^{°R}).
- V_{lc} = Total volume of liquid collected in the organic module condensate knockout trap, the impingers, and silica gel, mL.
- V_m = Volume of gas sample as measured by dry-gas meter, dscm (dscf).
- $V_m(\text{std})$ = Volume of gas sample measured by the dry-gas meter, corrected to standard conditions, dscm (dscf).
- $V_w(\text{std})$ = Volume of water vapor in the gas sample, corrected to standard conditions, scm (scf).
- V_s = Stack-gas velocity, calculated by Method 2, Equation 2-9, using data obtained from Method 5, m/sec (ft/sec).
- W_a = Weight of residue in acetone wash, mg.
- γ = Dry-gas-meter calibration factor, dimensionless.
- ΔH = Average pressure differential across the orifice meter (see Figure 2), mm H₂O (in. H₂O).

P_w = Density of water, 0.9982 g/mL (0.002201 lb/mL).

θ = Total sampling time, min.

θ_1 = Sampling time interval from the beginning of a run until the first component change, min.

θ_i = Sampling time interval between two successive component changes, beginning with the interval between the first and second changes, min.

θ_p = Sampling time interval from the final (n^{th}) component change until the end of the sampling run, min.

13.6 = Specific gravity of mercury.

60 = sec/min.

100 = Conversion to percent.

10.3 Average dry-gas-meter temperature and average orifice pressure drop: See data sheet (Figure 5, above).

10.4 Dry-gas volume: Correct the sample measured by the dry-gas meter to standard conditions (20°C, 760 mm Hg [68°F, 29.92 in. Hg]) by using Equation 1:

$$V_{m(\text{std})} = V_m \gamma \frac{T_{\text{std}}}{T_m} \frac{P_{\text{bar}} + \Delta H/13.6}{P_{\text{std}}} = K_1 V_m \gamma \frac{P_{\text{bar}} + \Delta H/13.6}{T_m} \quad (1)$$

where:

$K_1 = 0.3858 \text{ K/mm Hg}$ for metric units, or
 $K_1 = 17.64^\circ\text{R/in. Hg}$ for English units.

It should be noted that Equation 1 can be used as written, unless the leakage rate observed during any of the mandatory leak-checks (i.e., the post-test leak-check or leak-checks conducted prior to component changes) exceeds L_a . If L_p or L_i exceeds L_a , Equation 1 must be modified as follows:

- a. Case I (no component changes made during sampling run): Replace V_m in Equation 1 with the expression:

$$V_m - (L_p - L_a)$$

- b. Case II (one or more component changes made during the sampling run): Replace V_m in Equation 1 by the expression:

$$V_m = (L_1 - L_a)\theta_1 - \sum_{i=2}^n (L_i - L_a)\theta_i - (L_p - L_a)\theta_p$$

and substitute only for those leakage rates (L_1 or L_p) that exceed L_a .

10.5 Volume of water vapor:

$$V_{w(std)} = V_{lc} \frac{P_w}{M_w} \frac{RT_{std}}{P_{std}} = K_2 V_{lc} \quad (2)$$

where:

$K_2 = 0.001333 \text{ m}^3/\text{mL}$ for metric units, or
 $K_2 = 0.04707 \text{ ft}^3/\text{mL}$ for English units.

10.6 Moisture content:

$$B_{ws} = \frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}} \quad (3)$$

NOTE: In saturated or water-droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one from the impinger analysis (Equation 3) and a second from the assumption of saturated conditions. The lower of the two values of B_w shall be considered correct. The procedure for determining the moisture content based upon assumption of saturated conditions is given in the Note to Section 1.2 of Method 4. For the purposes of this method, the average stack-gas temperature from Figure 6 may be used to make this determination, provided that the accuracy of the in-stack temperature sensor is $\pm 1^\circ\text{C}$ (2°F).

10.7 Conversion factors:

<u>From</u>	<u>To</u>	<u>Multiply by</u>
scf	m^3	0.02832
g/ft^3	gr/ft^3	15.43
g/ft^3	lb/ft^3	2.205×10^{-3}
g/ft^3	g/m^3	35.31

0010 - 30

Revision 0
 Date September 1986

10.8 Isokinetic variation:

10.8.1 Calculation from raw data:

$$I = \frac{100 T_s [K_3 F_{1c} + (V_m/T_m) (P_{bar} + \Delta H/13.6)]}{60 B V_s P_s A_n} \quad (4)$$

where:

$K_3 = 0.003454 \text{ mm Hg-m}^3/\text{mL-K}$ for metric units, or
 $K_3 = 0.002669 \text{ in. Hg-ft}^3/\text{mL-}^\circ\text{R}$ for English units.

10.8.2 Calculation for intermediate values:

$$I = \frac{T_s V_m(\text{std}) P_{\text{std}} 100}{T_{\text{std}} V_s \theta A_n P_s 60 (1 - B_{ws})} \quad (5)$$
$$= K_4 \frac{T_s V_m(\text{std})}{P_s V_s A_n \theta (1 - B_{ws})}$$

where:

$K_4 = 4.320$ for metric units, or
 $K_4 = 0.09450$ for English units.

10.8.3 Acceptable results: If $90\% \leq I \leq 110\%$, the results are acceptable. If the results are low in comparison with the standard and I is beyond the acceptable range, or if I is less than 90%, the Administrator may opt to accept the results.

10.9 To determine the minimum sample volume that shall be collected, the following sequence of calculations shall be used.

10.9.1 From prior analysis of the waste feed, the concentration of POHCs introduced into the combustion system can be calculated. The degree of destruction and removal efficiency that is required is used to determine the maximum amount of POHC allowed to be present in the effluent. This may be expressed as:

$$\frac{(WF) (\text{POHC}_1 \text{ conc})}{100} \frac{(100 - \%DRE)}{100} = \text{Max POHC}_1 \text{ Mass} \quad (6)$$

where:

WF = mass flow rate of waste feed per hr, g/hr (lb/hr).

POHC₁ = concentration of Principal Organic Hazardous Compound (wt %) introduced into the combustion process.

0010 - 31

Revision 0
Date September 1986

DRE = percent Destruction and Removal Efficiency required.

Max POHC = mass flow rate (g/hr [lb/hr]) of POHC emitted from the combustion source.

10.9.2 The average discharge concentration of the POHC in the effluent gas is determined by comparing the Max POHC with the volumetric flow rate being exhausted from the source. Volumetric flow rate data are available as a result of preliminary Method 1-4 determinations:

$$\frac{\text{Max POHC}_i \text{ Mass}}{DV_{\text{eff}}(\text{std})} = \text{Max POHC}_i \text{ conc} \quad (7)$$

where:

$DV_{\text{eff}}(\text{std})$ = volumetric flow rate of exhaust gas, dscm (dscf).

$\text{POHC}_i \text{ conc}$ = anticipated concentration of the POHC in the exhaust gas stream, g/dscm (lb/dscf).

10.9.3 In making this calculation, it is recommended that a safety margin of at least ten be included:

$$\frac{LDL_{\text{POHC}} \times 10}{\text{POHC}_i \text{ conc}} = V_{\text{TBC}} \quad (8)$$

where:

LDL_{POHC} = detectable amount of POHC in entire sampling train.

NOTE: The whole extract from an XAD-2 cartridge is seldom if ever, injected at once. Therefore, if aliquoting factors are involved, the LDL_{POHC} is not the same as the analytical (or column) detection limit.

V_{TBC} = minimum dry standard volume to be collected at dry-gas meter.

10.10 Concentration of any given POHC in the gaseous emissions of a combustion process:

1) Multiply the concentration of the POHC as determined in Method 8270 by the final concentration volume, typically 10 mL.

$$C_{\text{POHC}} (\text{ug/mL}) \times \text{sample volume (mL)} = \text{amount (ug) of POHC in sample} \quad (9)$$

where:

C_{POHC} = concentration of POHC as analyzed by Method 8270.

2) Sum the amount of POHC found in all samples associated with a single train.

$$\text{Total (ug)} = \text{XAD-2 (ug)} + \text{condensate (ug)} + \text{rinses (ug)} + \text{impinger (ug)} \quad (10)$$

3) Divide the total ug found by the volume of stack gas sampled (m³).

$$(\text{Total ug}) / (\text{train sample volume}) = \text{concentration of POHC (ug/m}^3\text{)} \quad (11)$$

11.0 QUALITY CONTROL

11.1 Sampling: See EPA Manual 600/4-77-027b for Method 5 quality control.

11.2 Analysis: The quality assurance program required for this study includes the analysis of field and method blanks, procedure validations, incorporation of stable labeled surrogate compounds, quantitation versus stable labeled internal standards, capillary column performance checks, and external performance tests. The surrogate spiking compounds selected for a particular analysis are used as primary indicators of the quality of the analytical data for a wide range of compounds and a variety of sample matrices. The assessment of combustion data, positive identification, and quantitation of the selected compounds are dependent on the integrity of the samples received and the precision and accuracy of the analytical methods employed. The quality assurance procedures for this method are designed to monitor the performance of the analytical method and to provide the required information to take corrective action if problems are observed in laboratory operations or in field sampling activities.

11.2.1 Field Blanks: Field blanks must be submitted with the samples collected at each sampling site. The field blanks include the sample bottles containing aliquots of sample recovery solvents, unused filters, and resin cartridges. At a minimum, one complete sampling train will be assembled in the field staging area, taken to the sampling area, and leak-checked at the beginning and end of the testing (or for the same total number of times as the actual test train). The filter housing and probe of the blank train will be heated during the sample test. The train will be recovered as if it were an actual test sample. No gaseous sample will be passed through the sampling train.

11.2.2 Method blanks: A method blank must be prepared for each set of analytical operations, to evaluate contamination and artifacts that can be derived from glassware, reagents, and sample handling in the laboratory.

11.2.3 Refer to Method 8270 for additional quality control considerations.

0010 - 33

Revision 0
Date September 1986

12.0 METHOD PERFORMANCE

12.1 Method performance evaluation: Evaluation of analytical procedures for a selected series of compounds must include the sample-preparation procedures and each associated analytical determination. The analytical procedures should be challenged by the test compounds spiked at appropriate levels and carried through the procedures.

12.2 Method detection limit: The overall method detection limits (lower and upper) must be determined on a compound-by-compound basis because different compounds may exhibit different collection, retention, and extraction efficiencies as well as instrumental minimum detection limit (MDL). The method detection limit must be quoted relative to a given sample volume. The upper limits for the method must be determined relative to compound retention volumes (breakthrough).

12.3 Method precision and bias: The overall method precision and bias must be determined on a compound-by-compound basis at a given concentration level. The method precision value would include a combined variability due to sampling, sample preparation, and instrumental analysis. The method bias would be dependent upon the collection, retention, and extraction efficiency of the train components. From evaluation studies to date using a dynamic spiking system, method biases of -13% and -16% have been determined for toluene and 1,1,2,2-tetrachloroethane, respectively. A precision of 19.9% was calculated from a field test data set representing seven degrees of freedom which resulted from a series of paired, unspiked Semivolatile Organic Sampling trains (Semi-VOST) sampling emissions from a hazardous waste incinerator.

13.0 REFERENCES

1. Addendum to Specifications for Incinerator Testing at Federal Facilities, PHS, NCAPC, December 6, 1967.
2. Bursey, J., Homolya, J., McAllister, R., and McGangley, J., Laboratory and Field Evaluation of the Semi-VOST Method, Vols. 1 and 2, U.S. Environmental Protection Agency, EPA/600/4-851/075A, 075B (1985).
3. Martin, R.M., Construction Details of Isokinetic Source-Sampling Equipment, Research Triangle Park, NC, U.S. Environmental Protection Agency, April 1971, PB-203 060/BE, APTD-0581, 35 pp.
4. Rom, J.J., Maintenance, Calibration, and Operation of Isokinetic Source-Sampling Equipment, Research Triangle Park, NC, U.S. Environmental Protection Agency, March 1972, PB-209 022/BE, APTD-0576, 39 pp.
5. Schlickerrieder, L.M., Adams, J.W., and Thrun, K.E., Modified Method 5 Train and Source Assessment Sampling System: Operator's Manual, U.S. Environmental Protection Agency, EPA/600/8-85/003, (1985).

6. Shigehara, R.T., Adjustments in the EPA Nomography for Different Pitot Tube Coefficients and Dry Molecular Weights, Stack Sampling News, 2:4-11 (October 1974).
7. U.S. Environmental Protection Agency, CFR 40 Part 60, Appendix A, Methods 1-5.
8. Vollaro, R.F., A Survey of Commercially Available Instrumentation for the Measurement of Low-Range Gas Velocities, Research Triangle Park, NC, U.S. Environmental Protection Agency, Emissions Measurement Branch, November 1976 (unpublished paper).

0010 - 35

Revision 0
Date September 1986

PREPARATION OF XAD-2 SORBENT RESIN

1.0 SCOPE AND APPLICATION

1.1 XAD-2 resin as supplied by the manufacturer is impregnated with a bicarbonate solution to inhibit microbial growth during storage. Both the salt solution and any residual extractable monomer and polymer species must be removed before use. The resin is prepared by a series of water and organic extractions, followed by careful drying.

2.0 EXTRACTION

2.1 Method 1: The procedure may be carried out in a giant Soxhlet extractor. An all-glass thimble containing an extra-coarse frit is used for extraction of XAD-2. The frit is recessed 10-15 mm above a crenellated ring at the bottom of the thimble to facilitate drainage. The resin must be carefully retained in the extractor cup with a glass-wool plug and stainless steel screen because it floats on methylene chloride. This process involves sequential extraction in the following order.

<u>Solvent</u>	<u>Procedure</u>
Water	Initial rinse: Place resin in a beaker, rinse once with Type II water, and discard. Fill with water a second time, let stand overnight, and discard.
Water	Extract with H ₂ O for 8 hr.
Methyl alcohol	Extract for 22 hr.
Methylene chloride	Extract for 22 hr.
Methylene chloride (fresh)	Extract for 22 hr.

2.2 Method 2:

2.2.1 As an alternative to Soxhlet extraction, a continuous extractor has been fabricated for the extraction sequence. This extractor has been found to be acceptable. The particular canister used for the apparatus shown in Figure A-1 contains about 500 g of finished XAD-2. Any size may be constructed; the choice is dependent on the needs of the sampling programs. The XAD-2 is held under light spring tension between a pair of coarse and fine screens. Spacers under the bottom screen allow for even distribution of clean solvent. The three-necked flask should be of sufficient size (3-liter in this case) to hold solvent




Figure A-1. XAD-2 cleanup extraction apparatus.

0010 - A - 2

Revision 0
 Date September 1986

equal to twice the dead volume of the XAD-2 canister. Solvent is refluxed through the Snyder column, and the distillate is continuously cycled up through the XAD-2 for extraction and returned to the flask. The flow is maintained upward through the XAD-2 to allow maximum solvent contact and prevent channeling. A valve at the bottom of the canister allows removal of solvent from the canister between changes.

2.2.2 Experience has shown that it is very difficult to cycle sufficient water in this mode. Therefore the aqueous rinse is accomplished by simply flushing the canister with about 20 liters of distilled water. A small pump may be useful for pumping the water through the canister. The water extraction should be carried out at the rate of about 20-40 mL/min.

2.2.3 After draining the water, subsequent methyl alcohol and methylene chloride extractions are carried out using the refluxing apparatus. An overnight or 10- to 20-hr period is normally sufficient for each extraction.

2.2.4 All materials of construction are glass, Teflon, or stainless steel. Pumps, if used, should not contain extractable materials. Pumps are not used with methanol and methylene chloride.

3.0 DRYING

3.1 After evaluation of several methods of removing residual solvent, a fluidized-bed technique has proved to be the fastest and most reliable drying method.

3.2 A simple column with suitable retainers, as shown in Figure A-2, will serve as a satisfactory column. A 10.2-cm (4-in.) Pyrex pipe 0.6 m (2 ft) long will hold all of the XAD-2 from the extractor shown in Figure A-1 or the Soxhlet extractor, with sufficient space for fluidizing the bed while generating a minimum resin load at the exit of the column.

3.3 Method 1: The gas used to remove the solvent is the key to preserving the cleanliness of the XAD-2. Liquid nitrogen from a standard commercial liquid nitrogen cylinder has routinely proved to be a reliable source of large volumes of gas free from organic contaminants. The liquid nitrogen cylinder is connected to the column by a length of precleaned 0.95-cm (3/8-in.) copper tubing, coiled to pass through a heat source. As nitrogen is bled from the cylinder, it is vaporized in the heat source and passes through the column. A convenient heat source is a water bath heated from a steam line. The final nitrogen temperature should only be warm to the touch and not over 40°C. Experience has shown that about 500 g of XAD-2 may be dried overnight by consuming a full 160-liter cylinder of liquid nitrogen.

3.4 Method 2: As a second choice, high-purity tank nitrogen may be used to dry the XAD-2. The high-purity nitrogen must first be passed through a bed




Figure A-2. XAD-2 fluidized-bed drying apparatus.

0010 - A - 4

Revision 0
Date September 1986

of activated charcoal approximately 150 mL in volume. With either type of drying method, the rate of flow should gently agitate the bed. Excessive fluidization may cause the particles to break up.

4.0 QUALITY CONTROL PROCEDURES

4.1 For both Methods 1 and 2, the quality control results must be reported for the batch. The batch must be reextracted if the residual extractable organics are >20 ug/mL by TCO analysis or the gravimetric residue is >0.5 mg/20 g XAD-2 extracted. (See also section 5.1, Method 0010.)

4.2 Four control procedures are used with the final XAD-2 to check for (1) residual methylene chloride, (2) extractable organics (TCO), (3) specific compounds of interest as determined by GC/MS, as described in Section 4.5 below, and (4) residue (GRAV).

4.3 Procedure for residual methylene chloride:

4.3.1 Description: A $1+0.1$ -g sample of dried resin is weighed into a small vial, 3 mL of toluene are added, and the vial is capped and well shaken. Five uL of toluene (now containing extracted methylene chloride) are injected into a gas chromatograph, and the resulting integrated area is compared with a reference standard. The reference solution consists of 2.5 uL of methylene chloride in 100 mL of toluene, simulating 100 ug of residual methylene chloride on the resin. The acceptable maximum content is 1,000 ug/g resin.

4.3.2 Experimental: The gas chromatograph conditions are as follows:

6-ft x 1/8-in. stainless steel column containing 10% OV-101 on 100/120 Supelcoport;

Helium carrier at 30 mL/min;

FID operated on 4×10^{-11} A/mV;

Injection port temperature: 250°C;

Detector temperature: 305°C;

Program: 30°C(4 min) 40°C/min 250°C (hold); and

Program terminated at 1,000 sec.

4.4 Procedure for residual extractable organics:

4.4.1 Description: A $20+0.1$ -g sample of cleaned, dried resin is weighed into a precleaned alundum or cellulose thimble which is plugged with cleaned glass wool. (Note that 20 g of resin will fill a thimble, and the

TOTAL CHROMATOGRAPHABLE ORGANIC MATERIAL ANALYSIS

1.0 SCOPE AND APPLICATION

1.1 In this procedure, gas chromatography is used to determine the quantity of lower boiling hydrocarbons (boiling points between 90° and 300°C) in the concentrates of all organic solvent rinses, XAD-2 resin and LC fractions - when Method 1 is used (see References, Method 0010) - encountered in Level 1 environmental sample analyses. Data obtained using this procedure serve a twofold purpose. First, the total quantity of the lower boiling hydrocarbons in the sample is determined. Then whenever the hydrocarbon concentrations in the original concentrates exceed 75 ug/m³, the chromatography results are reexamined to determine the amounts of individual species.

The extent of compound identification is limited to representing all materials as normal alkanes based upon comparison of boiling points. Thus the method is not qualitative. In a similar manner, the analysis is semiquantitative; calibrations are prepared using only one hydrocarbon. They are replicated but samples routinely are not.

1.2 Application: This procedure applies solely to the Level 1 C7-C16 gas chromatographic analysis of concentrates of organic extracts, neat liquids, and of LC fractions. Throughout the procedure, it is assumed the analyst has been given a properly prepared sample.

1.3 Sensitivity: The sensitivity of this procedure, defined as the slope of a plot of response versus concentration, is dependent on the instrument and must be verified regularly. TRW experience indicates the nominal range is of the order of 77 uV·V·sec·uL/ng of n-heptane and 79 uV·sec·uL/ng of n-hexadecane. The instrument is capable of perhaps one hundredfold greater sensitivity. The level specified here is sufficient for Level 1 analysis.

1.4 Detection limit: The detection limit of this procedure as written is 1.3 ng/uL for a 1 uL injection of n-decane. This limit is arbitrarily based on defining the minimum detectable response as 100 uv·sec. This is an easier operational definition than defining the minimum detection limit to be that amount of material which yields a signal twice the noise level.

1.5 Range: The range of the procedure will be concentrations of 1.3 ng/uL and greater.

1.6 Limitations

1.6.1 Reporting limitations: It should be noted that a typical environmental sample will contain compounds which: (a) will not elute in the specified boiling ranges and thus will not be reported, and/or (b)

resin will float out unless well plugged.) The thimble containing the resin is extracted for 24 hr with 200-mL of pesticide-grade methylene chloride (Burdick and Jackson pesticide-grade or equivalent purity). The 200-mL extract is reduced in volume to 10-mL using a Kuderna-Danish concentrator and/or a nitrogen evaporation stream. Five μ L of that solution are analyzed by gas chromatography using the TCO analysis procedure. The concentrated solution should not contain >20 μ g/mL of TCO extracted from the XAD-2. This is equivalent to 10 μ g/g of TCO in the XAD-2 and would correspond to 1.3 mg of TCO in the extract of the 130-g XAD-2 module. Care should be taken to correct the TCO data for a solvent blank prepared (200 mL reduced to 10 mL) in a similar manner.

4.4.2 Experimental: Use the TCO analysis conditions described in the revised Level 1 manual (EPA 600/7-78-201).

4.5 GC/MS Screen: The extract, as prepared in paragraph 4.4.1, is subjected to GC/MS analysis for each of the individual compounds of interest. The GC/MS procedure is described in Chapter Four, Method 8270. The extract is screened at the MDL of each compound. The presence of any compound at a concentration >25 μ g/mL in the concentrated extract will require the XAD-2 to be recleaned by repeating the methylene chloride step.

4.6 Methodology for residual gravimetric determination: After the TCO value and GC/MS data are obtained for the resin batch by the above procedures, dry the remainder of the extract in a tared vessel. There must be <0.5 mg residue registered or the batch of resin will have to be extracted with fresh methylene chloride again until it meets this criterion. This level corresponds to 25 μ g/g in the XAD-2, or about 3.25 mg in a resin charge of 130 g.

0010 - A - 6

Revision 0
Date September 1986

will not elute from the column at all and thus will not be reported. Consequently, the organic content of the sample as reported is a lower bound and should be regarded as such.

1.6.2 Calibration limitations: Quantitation is based on calibration with n-decane. Data should therefore be reported as, e.g., mg C₈/m³ as n-decane. Since response varies linearly with carbon number (over a wide range the assumption may involve a 20% error), it is clear that heptane (C₇) detected in a sample and quantitated as decane will be overestimated. Likewise, hexadecane (C₁₆) quantitated as decane will be underestimated. From previous data, it is estimated the error involved is on the order of 6-7%.

1.6.3 Detection limitations: The sensitivity of the flame ionization detector varies from compound to compound. However, n-alkanes have a greater response than other classes. Consequently, using an n-alkane as a calibrant and assuming equal responses of all other compounds tends to give low reported values.

2.0 SUMMARY OF METHOD

2.1 A mL aliquot of all 10-mL concentrates is disbursed for GC-TCO analysis. With boiling point-retention time and response-amount calibration curves, the data (peak retention times and peak areas) are interpreted by first summing peak areas in the ranges obtained from the boiling point-retention time calibration. Then, with the response-amount calibration curve, the area sums are converted to amounts of material in the reported boiling point ranges.

2.2 After the instrument is set up, the boiling point-retention time calibration is effected by injecting a mixture of n-C₇ through n-C₁₆ hydrocarbons and operating the standard temperature program. Response-quantity calibrations are accomplished by injecting n-decane in n-pentane standards and performing the standard temperature program.

2.3 Definitions

2.3.1 GC: Gas chromatography or gas chromatograph.

2.3.2 C₇-C₁₆ n-alkanes: Heptane through hexadecane.

2.3.3 GCA temperature program: 4 min isothermal at 60°C, 10°C/min from 60° to 220°C.

2.3.4 TRW temperature program: 5 min isothermal at room temperature, then program from 30°C to 250°C at 15°C/min.

3.0 INTERFERENCES

Not applicable.

0010 - 8 - 2

Revision 0
Date September 1986

4.0 APPARATUS AND MATERIALS

4.1 Gas chromatograph: This procedure is intended for use on a Varian 1860 gas chromatograph, equipped with dual flame ionization detectors and a linear temperature programmer. Any equivalent instrument can be used provided that electrometer settings, etc., be changed appropriately.

4.2 Gases:

4.2.1 Helium: Minimum quality is reactor grade. A 4A or 13X molecular sieve drying tube is required. A filter must be placed between the trap and the instrument. The trap should be recharged after every third tank of helium.

4.2.2 Air: Zero grade is satisfactory.

4.2.3 Hydrogen: Zero grade.

4.3 Syringe: Syringes are Hamilton 701N, 10 uL, or equivalent.

4.4 Septa: Septa will be of such quality as to produce very low bleed during the temperature program. An appropriate septum is Supelco Microsep 138, which is Teflon-backed. If septum bleed cannot be reduced to a negligible level, it will be necessary to install septum swingers on the instrument.

4.5 Recorder: The recorder of this procedure must be capable of not less than 1 mV full-scale display, a 1-sec time constant and 0.5 in. per min chart rate.

4.6 Integrator: An integrator is required. Peak area measurement by hand is satisfactory but too time-consuming. If manual integration is required, the method of "height times width at half height" is used.

4.7 Columns:

4.7.1 Preferred column: 6 ft x 1/8 in. O.D. stainless steel column of 10% OV-101 on 100/120 mesh Supelcoport.

4.7.2 Alternate column: 6 ft x 1/8 in. O.D. stainless steel column of 10% OV-1 (or other silicon phase) on 100/120 mesh Supelcoport.

4.8 Syringe cleaner: Hamilton syringe cleaner or equivalent connected to a suitable vacuum source.

5.0 REAGENTS

5.1 Pentane: "Distilled-in-Glass" (reg. trademark) or "Nanograde" (reg. trademark) for standards and for syringe cleaning.

0010 - B - 3

Revision 0
Date September 1986

5.2 Methylene chloride: "Distilled-in-Glass" (reg. trademark) or "Nanograde" (reg. trademark) for syringe cleaning.

6.0 SAMPLING HANDLING AND PRESERVATION

6.1 The extracts are concentrated in a Kuderna-Danish evaporator to a volume less than 10 mL. The concentrate is then quantitatively transferred to a 10-mL volumetric flask and diluted to volume. A 1-mL aliquot is taken for both this analysis and possible subsequent GC/MS analysis and set aside in the sample bank. For each GC-TCO analysis, obtain the sample sufficiently in advance to allow it to warm to room temperature. For example, after one analysis is started, return that sample to the sample bank and take the next sample.

7.0 PROCEDURES

7.1 Setup and checkout: Each day, the operator will verify the following:

7.1.1 That supplies of carrier gas, air and hydrogen are sufficient, i.e., that each tank contains > 100 psig.

7.1.2 That, after replacement of any gas cylinder, all connections leading to the chromatograph have been leak-checked.

7.1.3 That the carrier gas flow rate is 30 ± 2 mL/min, the hydrogen flow rate is 30 ± 2 mL/min, and the air flow rate is 300 ± 20 mL/min.

7.1.4 That the electrometer is functioning properly.

7.1.5 That the recorder and integrator are functioning properly.

7.1.6 That the septa have been leak-checked (leak-checking is effected by placing the soap bubble flow meter inlet tube over the injection port adaptors), and that no septum will be used for more than 20 injections.

7.1.7 That the list of samples to be run is ready.

7.2 Retention time calibration:

7.2.1 To obtain the temperature ranges for reporting the results of the analyses, the chromatograph is given a normal boiling point-retention time calibration. The n-alkanes, their boiling points, and data reporting ranges are given in the table below:

	<u>NBP, °C</u>	<u>Reporting Range, °C</u>	<u>Report As</u>
n-heptane	98	90-110	C7
n-octane	126	110-140	C8
n-nonane	151	140-160	C9
n-decane	174	160-180	C10
n-undecane	194	180-200	C11
n-dodecane	214	200-220	C12
n-tridecane	234	220-240	C13
n-tetradecane	252	240-260	C14
n-pentadecane	270	260-280	C15
n-hexadecane	288	280-300	C16

7.2.2 Preparation of standards: Preparing a mixture of the C7-C16 alkanes is required. There are two approaches: (1) use of a standards kit (e.g., Polyscience Kit) containing bottles of mixtures of selected n-alkanes which may be combined to produce a C7-C16 standard; or (2) use of bottles of the individual C7-C16 alkanes from which accurately known volumes may be taken and combined to give a C7-C16 mixture.

7.2.3 Procedure for retention time calibration: This calibration is performed at the start of an analytical program; the mixture is chromatographed at the start of each day. To attain the required retention time precision, both the carrier gas flow rate and the temperature program specifications must be observed. Details of the procedure depend on the instrument being used. The general procedure is as follows:

7.2.3.1 Set the programmer upper limit at 250°C. If this setting does not produce a column temperature of 250°C, find the correct setting.

7.2.3.2 Set the programmer lower limit at 30°C.

7.2.3.3 Verify that the instrument and samples are at room temperature.

7.2.3.4 Inject 1 µL of the n-alkane mixture.

7.2.3.5 Start the integrator and recorder.

7.2.3.6 Allow the instrument to run isothermally at room temperature for five min.

7.2.3.7 Shut the oven door.

7.2.3.8 Change the mode to Automatic and start the temperature program.

7.2.3.9 Repeat Steps 1-9 a sufficient number of times so that the relative standard deviation of the retention times for each peak is <5%.

0010 - B - 5

Revision 0
Date September 1986

7.3 Response calibration:

7.3.1 For the purposes of a Level 1 analysis, response-quantity calibration with n-decane is adequate. A 10- μ L volume of n-decane is injected into a tared 10 mL volumetric flask. The weight injected is obtained and the flask is diluted to the mark with n-pentane. This standard contains about 730 ng n-decane per μ L n-pentane. The exact concentration depends on temperature, so that a weight is required. Two serial tenfold dilutions are made from this standard, giving standards at about 730, 73, and 7.3 ng n-decane per μ L n-pentane, respectively.

7.3.2 Procedure for response calibration: This calibration is performed at the start of an analytical program and monthly thereafter. The most concentrated standard is injected once each day. Any change in calibration necessitates a full calibration with new standards. Standards are stored in the refrigerator locker and are made up monthly.

7.3.2.1 Verify that the instrument is set up properly.

7.3.2.2 Set electrometer at 1×10^{-10} A/mV.

7.3.2.3 Inject 1 μ L of the highest concentration standard.

7.3.2.4 Run standard temperature program as specified above.

7.3.2.5 Clean syringe.

7.3.2.6 Make repeated injections of all three standards until the relative standard deviations of the areas of each standard are $\leq 5\%$.

7.4 Sample analysis procedure:

7.4.1 The following apparatus is required:

7.4.1.1 Gas chromatograph set up and working.

7.4.1.2 Recorder, integrator working.

7.4.1.3 Syringe and syringe cleaning apparatus.

7.4.1.4 Parameters: Electrometer setting is 1×10^{-10} A/mV; recorder is set at 0.5 in./min and 1 mV full-scale.

7.4.2 Steps in the procedure are:

7.4.2.1 Label chromatogram with the data, sample number, etc.

7.4.2.2 Inject sample.

7.4.2.3 Start integrator and recorder.

7.4.2.4 After isothermal operation for 5 min, begin temperature program.

7.4.2.5 Clean syringe.

7.4.2.6 Return sample; obtain new sample.

7.4.2.7 When analysis is finished, allow instrument to cool. Turn chromatogram and integrator output and data sheet over to data analyst.

7.5 Syringe cleaning procedure:

7.5.1 Remove plunger from syringe.

7.5.2 Insert syringe into cleaner; turn on aspirator.

7.5.3 Fill pipet with pentane; run pentane through syringe.

7.5.4 Repeat with methylene chloride from a separate pipet.

7.5.5 Flush plunger with pentane followed by methylene chloride.

7.5.6 Repeat with methylene chloride.

7.6 Sample analysis decision criterion: The data from the TCO analyses of organic extract and rinse concentrates are first used to calculate the total concentration of C7-C16 hydrocarbon-equivalents (Paragraph 7.7.3) in the sample with respect to the volume of air actually sampled, i.e., ug/m^3 . On this basis, a decision is made both on whether to calculate the quantity of each n-alkane equivalent present and on which analytical procedural pathway will be followed. If the total organic content is great enough to warrant continuing the analysis -- $>500 \text{ ug}/\text{m}^3$ -- a TCO of less than $75 \text{ ug}/\text{m}^3$ will require only LC fractionation and gravimetric determinations and IR spectra to be obtained on each fraction. If the TCO is greater than $75 \text{ ug}/\text{m}^3$, then the first seven LC fractions of each sample will be reanalyzed using this same gas chromatographic technique.

7.7 Calculations:

7.7.1 Boiling Point - Retention Time Calibration: The required data for this calibration are on the chromatogram and on the data sheet. The data reduction is performed as follows:

7.7.1.1 Average the retention times and calculate relative standard deviations for each n-hydrocarbon.

7.7.1.2 Plot average retention times as abscissae versus normal boiling points as ordinates.

7.7.1.3 Draw in calibration curve.

7.7.1.4 Locate and record retention times corresponding to boiling ranges 90-100, 110-140, 140-160, 160-180, 180-200, 200-220, 220-240, 240-260, 260-280, 280-300°C.

7.7.2 Response-amount calibration: The required data for this calibration are on the chromatogram and on the data sheet. The data reduction is performed as follows:

7.7.2.1 Average the area responses of each standard and calculate relative standard deviations.

7.7.2.2 Plot response (uv-sec) as ordinate versus ng/uL as abscissa.

7.7.2.3 Draw in the curve. Perform least squares regression and obtain slope (uV·sec·uL/ng).

7.7.3 Total C7-C16 hydrocarbons analysis: The required data for this calculation are on the chromatogram and on the data sheet. The data reduction is performed as follows:

7.7.3.1 Sum the areas of all peaks within the retention time range of interest.

7.7.3.2 Convert this area (uV·sec) to ng/uL by dividing by the weight response for n-decane (uV·sec·uL/ng).

7.7.3.3 Multiply this weight by the total concentrate volume (10 mL) to get the weight of the C7-C16 hydrocarbons in the sample.

7.7.3.4 Using the volume of gas sampled or the total weight of sample acquired, convert the result of Step 7.7.3.3 above to ug/m³.

7.7.3.5 If the value of total C7-C16 hydrocarbons from Step 7.7.3.4 above exceeds 75 ug/m³, calculate individual hydrocarbon concentrations in accordance with the instructions in Paragraph 7.7.5.5 below.

7.7.4 Individual C7-C16 n-Alkane Equivalent Analysis: The required data from the analyses are on the chromatogram and on the data sheet. The data reduction is performed as follows:

7.7.4.1 Sum the areas of peaks in the proper retention time ranges.

0010 - B - 8

Revision 0
Date September 1986

7.7.4.2 Convert areas (uV·sec) to ng/uL by dividing by the proper weight response (uV·sec·uL/ng).

7.7.4.3 Multiply each weight by total concentrate volume (10 mL) to get weight of species in each range of the sample.

7.7.4.4 Using the volume of gas sampled on the total weight of sample acquired, convert the result of Step 7.7.4.3 above to ug/m³.

8.0 QUALITY CONTROL

8.1 Appropriate QC is found in the pertinent procedures throughout the method.

9.0 METHOD PERFORMANCE


9.1 Even relatively comprehensive error propagation analysis is beyond the scope of this procedure. With reasonable care, peak area reproducibility of a standard should be of the order of 1% RSD. The relative standard deviation of the sum of all peaks in a fairly complex waste might be of the order of 5-10%. Accuracy is more difficult to assess. With good analytical technique, accuracy and precision should be of the order of 10-20%.

10.0 REFERENCES


1. Emissions Assessment of Conventional Stationary Combustion Systems: Methods and Procedure Manual for Sampling and Analysis, Interagency Energy/Environmental R&D Program, Industrial Environmental Research Laboratory, Research Triangle Park, NC 27711, EPA-600/7-79-029a, January 1979.

0010 - B - 9

Revision 0
Date September 1986



APPENDIX L
CALCULATION EQUATIONS



METHOD 2
CALCULATION EQUATIONS

$$\bar{V}_s = 85.49 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60 (1 - B_{ws}) \bar{V}_s A \left(\frac{528}{T_{s(avg)}}\right) \left(\frac{P_s}{29.92}\right)$$

$$Q_a = 60 \bar{V}_s A$$

$$\dot{m}_s = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} - 0.0003641 P_s (T_{db} - T_{wb})) / vp_{adb}$$

$$B_{ws}^* = RH(vp_{adb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

SYMBOLS

A	=	Cross Sectional area of stack, SQ. FT.
A_n	=	Cross sectional area of nozzle, SQ. FT.
B_{ws}	=	Water vapor in gas stream, proportion by volume
C_p	=	Pitot tube coefficient, dimensionless
C_s	=	Concentration of particulate matter in stack gas, wet basis, GR/ACF
C_s	=	Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	=	Excess air, percent by volume
γ	=	Dry test meter correction factor, dimensionless
G_d	=	Specific gravity (relative to air), dimensionless
I	=	Isokinetic variation, percent by volume
M_d	=	Molecular weight of stack gas, dry basis, g/g - mole.
m_s	=	Mass flow of wet flue gas, LB/HR
m_p	=	Particulate mass flow, LB/HR
M_s	=	Molecular weight of stack gas, wet basis, g/g mole.
M_p	=	Total amount of particulate matter collected, g
P_{bar}	=	Atmospheric pressure, IN. HG. (uncompensated)
P_g	=	Stack static gas pressure, IN. WC.
P_s	=	Absolute pressure of stack gas, IN. HG.
P_{std}	=	Standard absolute pressure, 29.92 IN. HG.
A_a	=	Actual volumetric stack gas flow rate, ACFM
$Q_{s,d}$	=	Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
RH	=	Relative humidity, %

032294-G:STACK\WPMETHODS-EQ.15

T_{db}	=	Dry bulb temperature of stack gas, °F
T_{wb}	=	Wet bulb temperature of stack gas, °F
$T_{m(avg)}$	=	Absolute average dry gas meter temperature, °R
$T_{s(avg)}$	=	Absolute average stack temperature, °R
T_{std}	=	Standard absolute temperature, 528 °R (68 °F)
θ	=	Total sampling time, min.
V_{lc}	=	Total volume of liquid collected in impingers and silica gel, ml
V_m	=	Volume of gas sample as measured by dry gas meter, CF
$V_{m(std)}$	=	Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
$V_{w(std)}$	=	Volume of water vapor in the gas sample corrected to standard conditions, SCF
\bar{V}_s	=	Average actual stack gas velocity, FT/SEC
vp_{tdb}	=	Vapor pressure at T_{db} , IN. HG.
vp_{twb}	=	Vapor pressure at T_{wb} , IN. HG.
$\overline{\Delta H}$	=	Average pressure differential across the orifice meter, IN. WC.
ΔP	=	Velocity pressure of stack gas, IN. WC.
γ	=	Dry test meter correction coefficient, dimensionless
ρ	=	Actual gas density, LB/ACF

METHOD 3
CALCULATION EQUATIONS

$$\%EA = \frac{100(\%O_2 - 0.5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (I - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

METHOD 5
CALCULATION EQUATIONS

$$V_{m(std)} = 17.65 V_m \gamma \left(\frac{P_{bar} + \overline{\Delta H}/13.6}{T_{m(avg)}} \right)$$

$$V_{w(std)} = 0.0472 V_{Ls}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$I = 0.0944 \left(\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (I - B_{ws})} \right)$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_a = \frac{272.3 M_p P_s}{T_{s(avg)} (V_{w(std)} + V_{m(std)})}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_{s,d}$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{\theta A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

CALCULATION EQUATIONS

METHOD 7

$$V_{m(std)} = 17.64 (V_f - 25) \left[\frac{P_f}{T_f} - \frac{P_i}{T_i} \right]$$

$$C_s = 6.243 \times 10^{-5} \frac{M}{V_{m(std)}}$$

$$E = \frac{2090 C_s F}{20.9 - \bar{B}_{O_2}}$$

$$C_s (GR/DSCF) = 7000 C_s$$

$$C_s (MG/DSCM) = 1.60186 \times 10^7 C_s$$

$$C_s (ppm-dry) = 8.37552 \times 10^6 C_s$$

$$C_s (ppm-3\% O_2) = 8.37552 \times 10^6 C_s \left(1 + \left[\frac{\bar{B}_{O_2} - 3}{20.9 - \bar{B}_{O_2}} \right] \right)$$

$$C_s (ppm-wet) = 8.37552 \times 10^6 C_s \left(1 - \frac{MC}{100} \right)$$

SYMBOLS

$\bar{B} O_2$	=	Average oxygen content in flue gas, % v/v
C_s	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, LB/DSCF
C_s (GR/DSCF)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, GR/DSCF
C_s (MG/DSCM)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, MG/DSCM
E	=	Emission factor, LB/10 ⁶ BTU
F	=	F-Factor for given fuel type, DSCF/10 ⁶ BTU
M	=	Mass of nitrogen oxides as nitrogen dioxide in gas sample, ug
MC	=	Moisture content of flue gas, %
P_f	=	Final absolute pressure in flask, IN. HG
P_i	=	Initial absolute pressure in flask, IN. HG
C_s (ppm-dry)	=	Concentration of nitrogen oxides in flue gas, dry basis, (v/v), ppm
C_s (ppm-3% O ₂)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to 3% O ₂ , (v/v) ppm
C_s (ppm-wet)	=	Concentration of nitrogen oxides in flue gas, wet basis, (v/v), ppm
T_f	=	Final absolute temperature in flask, °R
T_i	=	Initial absolute temperature in flask, °R
V_f	=	Volume of flask and valve, cc
$V_{m(std)}$	=	Sample volume at standard conditions, dry basis, cc

CALCULATION EQUATIONS

METHOD 10

$$CO\text{-}PPM\text{-}DRY = CO_{CO_2} - \text{free, dry, avg} (1 - CO_{2,d}/100)$$

$$CO\text{-}PPM\text{-}WET = CO\text{-}PPM\text{-}DRY (1 - MC/100)$$

$$GR/DSCF = 5.0885 \times 10^{-4} (CO\text{-}PPM\text{-}DRY)$$

$$mg/dscm = 1.165 (CO\text{-}PPM\text{-}DRY)$$

$$\dot{m} = 8.5714 \times 10^{-3} (GR/DSCF) (Q_{s,d})$$

$$E = \frac{2.9857 \times 10^{-3} F_d (GR/DSCF)}{20.9 - O_{2,d}}$$

where:

$CO_{CO_2} - \text{free, dry, avg}$

= average of two determinations of carbon monoxide on a dry, CO_2 - free integrated flue gas sample reported in ppm by volume

$CO_{2,d}$ = carbon dioxide concentration of flue gas on a dry percent by volume basis

$O_{2,d}$ = oxygen concentration of flue gas on a dry percent by volume basis

- MC = moisture content of flue gas on a percent by volume basis
- CO-PPM-DRY = carbon monoxide concentration in ppm by volume on a dry basis
- CO-PPM-WET = carbon monoxide concentration in ppm by volume on a wet or actual basis
- GR/DSCF = concentration of carbon monoxide in flue gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
- mg/dscm = concentration of carbon monoxide in flue gas on a milligrams per dry standard cubic meter basis (60 °F, 29.92 IN. HG.)
- \dot{m} = emissions or mass rate of carbon monoxide on a LB/HR basis
- $Q_{s,d}$ = volumetric flow rate of flue gas in dry standard cubic feet per minute
- E = emission factor of carbon monoxide in pounds of carbon monoxide emitted per million BTU heat input (LB/MMBTU)
- F_d = F-Factor of respective fuel in dry standard cubic feet of exhaust gas at 0% oxygen per million BTU of heat input (DSCF/MMBTU)

CALCULATION EQUATIONS

Chromotropic Acid Method for Formaldehyde

$$m_t = \frac{m_a V_{soln}}{V_{aliq}}$$

where:

m_t	=	mass of formaldehyde in total sample in ug
m_a	=	mass of formaldehyde in aliquot in ug
V_{soln}	=	volume of total sample in cc (500 cc normally)
V_{aliq}	=	volume of aliquot taken for analysis in cc
PPM·DRY	=	$\frac{0.0283 m_t}{V_{std}}$
PPM·WET	=	PPM·DRY (1-MC/100)
GR/DSCF	=	5.45×10^{-4} (PPM·DRY)
mg/dscm	=	1.249 (PPM·DRY)
\dot{m}	=	8.5714×10^{-3} (GR/DSCF) ($Q_{g,d}$)

where:

PPM·DRY	=	concentration of formaldehyde in parts per million by volume on a dry basis
PPM·WET	=	concentration of formaldehyde in parts per million by volume on an actual or wet basis
MC	=	moisture content of gas on a percent by volume basis
GR/DSCF	=	concentration of formaldehyde in gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
\dot{m}	=	emission or mass rate of formaldehyde in pounds per hour (LB/HR)
V_{std}	=	dry gas volume as measured by the dry gas meter, corrected to standard conditions (at 68 °F and 1 atmosphere) DSCF

031894-G:\STACK\WPMETHODS\EQ.03

CALCULATION EQUATIONS

Gas Chromatographic Method for Phenol in Air

$$\text{PPM·DRY} = \frac{9.03 \times 10^{-3} m}{V_{\text{std}}}$$

$$\text{PP·WET} = \text{PPM·DRY} (1-\text{MC}/100)$$

$$\text{GR/DSCF} = 1.709 \times 10^{-3} (\text{PPM·DRY})$$

$$\text{mg/dscm} = 3.913 (\text{PPM·DRY})$$

$$m = 8.5714 \times 10^{-3} (\text{GR/DSCF}) (Q_{s, d})$$

where:

PPM·DRY = concentration of phenol in gas in parts per million by volume on a dry basis

PPM·WET = concentration of phenol in gas in parts per million by volume on an actual or wet basis

MC = moisture content of gas on a percent by volume basis

GR/DSCF = concentration of phenol in gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)

m = emission or mass rate of phenol in pounds per hour (LB/HR)

$Q_{s, d}$ = volumetric flow rate of stack gas in dry standard cubic feet per minute (DSCFM)

CALCULATION OF PAH EMISSION RATES

in g/sec and 10⁻⁶g/sec

\dot{m} (g/sec)

$$= 4.716 \times 10^{-10} C_s (\text{ug/m}^3) Q_{s,d} (\text{DSCFM})$$

\dot{m} (10⁻³g/sec)

$$= 4.716 \times 10^{-7} C_a (\text{ug/m}^3) Q_{s,d} (\text{DSCFM})$$

\dot{m} (10⁻⁶g/sec)

$$= 4.716 \times 10^{-4} C_s (\text{ug/m}^3) Q_{s,d} (\text{DSCFM})$$

where:

$$Q_s = \text{ug/dsm}^3$$

$$Q_{s,d} = \text{DSCF/MIN}$$

LP-HAYWARD									
Oxides of Nitrogen									
LB/HR Calculations									
Report No. 4-3366									
Line 1 Surface Dryer RTO Inlet									
RUN	NOx ppm	Flow	LB/DSCF	LB/HR		NOx ppm	Flow	LB/DSCF	LB/HR
1	48	26310	5.73E-06	9.046965		23	23320	2.75E-06	3.842353
2	34	27727	4.06E-06	6.753403		28	23138	3.34E-06	4.64114
3	39	25659	4.66E-06	7.168779		22	24468	2.63E-06	3.856222
AVG	40	26565		7.656382		24	23672		4.113238
Line 2 Surface Dryer RTO Inlet									
RUN	NOx ppm	Flow	LB/DSCF	LB/HR		NOx ppm	Flow	LB/DSCF	LB/HR
1	29	58322	3.46E-06	12.11633		17	32179	2.03E-06	3.918883
2	29	57883	3.46E-06	12.02513		25	32898	2.98E-06	5.891832
3	28	59575	3.34E-06	11.94986		16	33198	1.91E-06	3.805158
AVG	29	58573		12.03044		19	32758		4.538625
Line 2 Core Dryer RTO Inlet									
RUN	NOx ppm	Flow	LB/DSCF	LB/HR		NOx ppm	Flow	LB/DSCF	LB/HR
1	24	26211	2.87E-06	4.506462		24	64004	2.87E-06	11.00422
2	24	23955	2.87E-06	4.118587		24	63029	2.87E-06	10.83659
3	19	25392	2.27E-06	3.45614		23	63455	2.75E-06	10.45525
AVG	22	25186		4.027063		24	63496		10.76535

LP - HAYWARD

BENZENE CALCULATIONS

Line 2 Dryer RTO Outlet

Test/Run	Mass (ug)	Vstd (DSCF)	Concentration (ppm,d)	Concentration (LB/DSCF)	Flow DSCFM	Mass Rate (LB/HR)
9/1	2.2	2.149	0.011149	2.26E-09	66300	0.008978
9/2	4.8	2.114	0.024728	5.01E-09	65990	0.01982
9/3	3.4	2.112	0.017533	3.55E-09	65990	0.014052


Line 1 Dryer RTO Outlet

Test/Run	Mass (ug)	Vstd (DSCF)	Concentration (ppm,d)	Concentration (LB/DSCF)	Flow DSCFM	Mass Rate (LB/HR)
12/1	14	2.029	0.075146	1.52E-08	59060	0.053905
12/2	12	1.718	0.076071	1.54E-08	57020	0.052683
12/3	8.4	1.791	0.051079	1.03E-08	57020	0.035375

Report No. 4-3366									
LOUISIANA-PACIFIC - Hayward									
Line 2 Dryer Outlet									
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)	(GR/DSCF)	
4	1	20.87	22.1	65964	3.44			0.0060885	
	2	22.16	19.6	64723	3.05			0.0054892	
	3	21.44	21.7	67196	3.47			0.0060216	
				65961		21.133333	3.318639		
Line 2 Surface Dryer RTO Inlet									
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)	(GR/DSCF)	
5	1	21.36	111.8	30194	8.02			0.0309924	
	2	22.63	174.6	30077	12.68			0.0491958	
	3	20	217.9	30767	15.66			0.0693778	
				30346		168.1	12.12088		
Line 2 Core Dryer RTO Inlet									
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)	(GR/DSCF)	
6	1	24.72	408.3	26463	26.82			0.1182378	
	2	20.29	496	24829	28.87			0.1356517	
	3	24.92	371.1	25486	23.64			0.1077515	
				25592		425.13333	26.40899		
Line 1 Surface Dryer RTO Inlet									
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)	(GR/DSCF)	
16	1	26.34	609.3	25252	39.03			0.180325	
	2	31.96	651.3	24160	43.21			0.2086764	
	3	25.2	207.9	24718	12.84			0.0605912	
						489.5	31.69384		
Line 1 Dryer RTO Outlet									
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)	(GR/DSCF)	
17	1	24.7	63.7	59055	9.33			0.0184417	
	2	26.1	49.9	57018	7.19			0.0147202	
	3	25.1	34	56588	4.80			0.0098959	
						49.2	7.109621		
Line 1 Core Dryer RTO Inlet									
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	(LB/HR)	(GR/DSCF)	
18	1	21.02	432.6	25437	26.03			0.1194059	
	2	18.51	282	26512	17.14			0.0754389	
	3	18.91	302.4	29134	20.30			0.0812963	
						339	21.15959		

APPENDIX M

SAMPLING TRAIN CALIBRATION DATA



INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job LP / Hayward
 Operator DM

Date 7-13-74
 Module No. 2

Instructions: Operate the control module at a flow rate equal to \dot{V}_{He} for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.94 in. Hg. $\tau =$.9974 \dot{V}_{He} 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	185.6		
2.5	187.52	65	63
5.0	189.45	74	63
7.5	191.39	77	64
10	193.30	79	64
	$V_m = 7.7$	Avg(t_m) = 68.6 °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(.9974)(7.7)} \left[\frac{(68.6) + 460}{(28.94)} \right]^{0.5}$$

$$Y_{cn} = \underline{.994}$$

If Y_{cn} is not within the range of 0.97 to 1.03, the volume metering system should be investigated before beginning.

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job CP / HAYWARD
 Operator BOB

Date 7-14-84
 Module No. 2

Instructions: Operate the control module at a flow rate equal to \dot{V}_m for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.85 in. Hg. $\tau =$.9974 \dot{V}_m 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	1338.70		
2.5	340.64	77	64
5.0	342.55	77	64
7.5	344.52	79	64
10	346.42	80	64
	$V_m = 7.72$	Avg(t_m) = 70.4 °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(.9974)(7.72)} \left[\frac{(70.4) + 460}{(28.85)} \right]^{0.5}$$

$$Y_{cn} = \underline{.995}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job LP / Hayward
 Operator D. H.

Date 7-15-94
 Module No. 2

Instructions: Operate the control module at a flow rate equal to $\Delta H\theta$ for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.86 in. Hg. $\tau =$ 9974 $\Delta H\theta$ 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	1542.00		
2.5	544.55	72	65
5.0	546.78	74	65
7.5	548.69	77	65
10	550.64	80	65
	$V_m = 7.74$	Avg(t_m) = 70.4 °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(9974)(7.74)} \left[\frac{(70.4) + 460}{(28.86)} \right]^{0.5}$$

$$Y_{cn} = \underline{.997}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job ~~LP~~ LP / Hayward
 Operator DM

Date 7-12-94
 Module No. 4

Instructions: Operate the control module at a flow rate equal to \dot{V}_m for 10 minutes before attaching the umbilical. Record the following data:

Bar press 23.71 in. Hg. $T =$ 99.62 \dot{V}_m 1.89 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
1.5	<u>74.50</u>	72	68
2.5	<u>76.40</u>	<u>72</u>	<u>68</u>
5.0	<u>78.29</u>	<u>74</u>	<u>69</u>
7.5	<u>80.17</u>	<u>76</u>	<u>70</u>
10	<u>82.04</u>	<u>77</u>	<u>71</u>
10	$V_m =$ <u>7.58</u>	Avg(t_m) = <u>72</u> °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{T V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(99.62)(7.58)} \left[\frac{(72) + 460}{(23.71)} \right]^{0.5}$$

$$Y_{cn} = \underline{1.02}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job LPI HAYWARD
 Operator E. T. [Signature]

Date 7-12-94
 Module No. 4

Instructions: Operate the control module at a flow rate equal to \dot{V}_{He} for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.94 in. Hg. $\tau =$.9862 \dot{V}_{He} 1.89 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
████████	(190.00)	████████	████████
2.5	191.90	68	63
5.0	193.80	70	64
7.5	195.77	72	65
10	197.76	73	66
████████	$V_m = 7.76$	Avg(t_m) = <u>67.6</u> °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{() ()} \left[\frac{(67.6) + 460}{(28.94)} \right]^{0.5} = 4.269$$

$$Y_{cn} = \underline{.9862}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job L.P. / Hayward, 100
 Operator M. Sample

Date 7-14-94
 Module No. 4

Instructions: Operate the control module at a flow rate equal to ΔH_e for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.95 in. Hg. $\tau =$ 9962 ΔH_e 1.89 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
████████	(369.70)	████████	████████
2.5	371.63	62	62
5.0	373.54	63	62
7.5	375.45	67	63
10	377.37	69	63
████████	$V_m = 7.67$	Avg(t_m) = 63.975 °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(9962)(7.67)} \left[\frac{(63.975) + 460}{(28.95)} \right]^{0.5}$$

$$Y_{cn} = \underline{.996}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job LP/Hayward
Operator DM

Date 7-15-84
Module No. 4

Instructions: Operate the control module at a flow rate equal to $\pm 10\%$ for 10 minutes before attaching the umbilical. Record the following data:

Bar press 25.57 in. Hg. $\tau =$.9965 $\pm 10\%$ 1.84 in. W.C.

Time (min)	Volume (CF)	Meter Temp. ($^{\circ}$ F)	
		Inlet	Outlet
	(525.78)		
2.5	527.93	70	66
5.0	529.18	71	67
7.5	531.06	72	67
10	533.00	73	68
	$V_m = 7.7$	Avg (t_m) = 69.3 $^{\circ}$ F	

Calculate Y_{en} as follows:

$$Y_{en} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{en} = \frac{1.786}{(.9965)(7.7)} \left[\frac{(69.3) + 460}{(28.87)} \right]^{0.5}$$

$$Y_{en} = \underline{.997}$$

If Y_{en} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job CP / HAYWARD
 Operator Bob

Date 7-12-94
 Module No. 2

Instructions: Operate the control module at a flow rate equal to $\Delta H\theta$ for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.71 in. Hg. $\tau =$.9947 $\Delta H\theta$ 1.95 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	<u>846.00</u>		
<u>2.5</u>	<u>847.93</u>	<u>72</u>	<u>68</u>
<u>5.0</u>	<u>849.87</u>	<u>74</u>	<u>68</u>
<u>7.5</u>	<u>851.80</u>	<u>76</u>	<u>71</u>
<u>10</u>	<u>853.73</u>	<u>77</u>	<u>72</u>
	$V_m =$ <u>7.73</u>	Avg(t_m) = <u>72.25</u> °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(.9947)(7.73)} \left[\frac{(72.25 + 460)}{(28.71)} \right]^{0.5}$$

$$Y_{cn} = \underline{.9999}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job 2.P. / Hayward, WI
 Operator M. Kaehler

Date 7-12-94
 Module No. 10

Instructions: Operate the control module at a flow rate equal to ΔH_0 for 10 minutes before attaching the umbilical. Record the following data:

Bar press 29.71 in. Hg. $\tau =$.9930 ΔH_0 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	(506.60)		
2.5	508.57	77	70
5.0	510.54	78	70
7.5	512.50	78	71
10	514.36	78	72
	$V_m = 7.76$	Avg (t_m) = 74.25 °F	

Calculate Y_{en} as follows:

$$Y_{en} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{en} = \frac{1.786}{(.9930)(7.76)} \left[\frac{(74.25) + 460}{(29.71)} \right]^{0.5}$$

$$Y_{en} = \underline{1.000}$$

If Y_{en} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job LP / Hayward
 Operator DM

Date 7-13
 Module No. 10

Instructions: Operate the control module at a flow rate equal to \hat{H}_0 for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.94 in. Hg. $\tau =$ 9930 \hat{H}_0 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
████████	1930.60	████████	████████
2.5	832.58	69	62
5.0	834.52	72	62
7.5	836.49	74	63
10	838.41	75	63
████████	$V_m = 7.81$	Avg(t_m) = <u>67.5</u> °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(9930)(7.81)} \left[\frac{(67.5) + 460}{(28.94)} \right]^{0.5}$$

$$Y_{cn} = \underline{.983}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job LP / Hazardous
 Operator DM

Date 7-14-94
 Module No. 10

Instructions: Operate the control module at a flow rate equal to \dot{V}_{He} for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.85 in. Hg. $\tau =$.9930 \dot{V}_{He} 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	(69.20)		
2.5	71.12	70	64
5.0	72.03	71	64
7.5	74.95	71	64
10	76.92	73	64
	$V_m = 7.72$	Avg(t_m) = 67.6 °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(.9930)(7.72)} \left[\frac{(67.6) + 460}{(28.85)} \right]^{0.5}$$

$$Y_{cn} = \underline{.996}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: July 20, 1994

Meter Box No. : 2 (Rockwell Dry Test Meter Serial No. 964551)

Date of Last Calibration: March 24, 1994
Calibration Technician: E. Trowbridge
Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
March 30, 1994	4-2559	994.50	1149.99	155.49	155.49
April 6, 1994	4-2598	1160.80	1592.09	431.29	586.78
June 8, 1994	4-3097	1781.90	2184.95	403.05	989.83
July 13, 1994	4-3366	2193.50	2691.66	498.16	1487.99

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: July 20, 1994

Meter Box No. : 4 (Rockwell Dry Test Meter Serial No. 964552)

Date of Last Calibration: July 07, 1994

Calibration Technician: S. Bainville

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
July 12, 1994	4-3366	84.10	703.50	619.40	619.40

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: July 20, 1994

Meter Box No. : 7 (Rockwell Dry Test Meter Serial No. 9655550)

Date of Last Calibration: April 26, 1994

Calibration Technician: E. Trowbridge

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
July 06, 1994	4-3289	737.70	843.74	106.04	106.04
July 12, 1994	4-3366	853.90	991.80	137.90	243.94

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
 (612) 786-6020

Meter Box Calibration and Usage Status

Date of Report, July 20, 1994

Meter Box No. : 10 (Rockwell Dry Test Meter Serial No. 1334112)

Date of Last Calibration: May 31, 1994

Calibration Technician: E. Trowbridge

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
June 01, 1994	4-3020	104.50	570.30	465.80	465.80
June 09, 1994	4-3097	578.60	717.65	139.05	604.85
June 14, 1994	4-3117	726.90	1578.75	851.85	1456.70
June 21, 1994	4-3188	1580.20	1846.88	266.68	1723.38
June 22, 1994	4-3189	1847.30	1947.16	99.86	1823.24
June 28, 1994	4-3255	1957.30	2068.23	110.93	1934.17
June 29, 1994	4-3256	2076.63	2196.50	119.87	2054.04
June 30, 1994	4-3257	2198.20	2310.51	112.31	2166.35
July 06, 1994	4-3287	2319.50	2423.53	104.03	2270.38
July 07, 1994	4-3288	2424.00	2498.60	74.6	2344.98
July 12, 1994	4-3366	2514.40	3243.87	729.47	3074.45

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: July 20, 1994

Meter Box No. : 2-S (Rockwell Dry Test Meter Serial No. 69185)

Date of Last Calibration: January 13, 1994

Calibration Technician: S. Bainville

Wet Test Meter No.: American Meter AL-17 (0.05 CF/REV)

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
January 20, 1994	4-2118	396.000	398.532	2.532	2.532
March 04, 1994	4-2384	406.300	433.333	27.033	29.565
May 11, 1994	4-2839	434.450	436.850	2.400	31.965
June 09, 1994	4-3097	436.910	443.688	6.778	38.743
June 23, 1994	4-3193	443.705	447.205	3.500	42.243
June 29, 1994	4-3250	448.375	473.392	25.017	67.260
July 13, 1994	4-3366	478.310	489.477	11.167	78.427

* Total volume through meter since last calibration.

INTERPOLL LABORATORIES, INC.
METER CALIBRATION SHEET

Control Module No. 2
Serial No. DTH 964551
Wet Test Meter No. AL-20
Technician [Signature]

Date 3-24-94
Bar. Press. 29.00 in. Hg
EPA METHOD 6

ΔH (in. WC)	Nominal	actual	Gas Volume Wet Test Meter (ft ³)	Cal. Index (±)	Diff. Wet Test Meter AP _w (in. WC)	Gas Volume Dry Test Meter (ft ³)			Gas Temperatures			Time θ (min/sec)	Meter Coeff.	Orifice Const.	C _f
						V _{d1}	V _{d2}	V _{d3}	Wet Test T _w (°F)	Dry Test T _{d1} (°F)	Dry Test T _{d2} (°F)				
0.5		1.5	2	99.85	0.01	965.500	965.25	965.25	63	68	68	4/58	1.0028	1.75	
1.2		1.2	3	99.91	0.025	962.000	965.050	965.050	66	67	67	4/46	0.9936	1.72	
2.0		2.0	3	99.93	0.055	968.000	971.061	971.061	66	90	70	3/46	1.0022	1.77	
3.3		3.3	5	100.00	0.09	971.500	976.642	976.642	66	96	72	4/56	0.9976	1.79	
4.7		4.7	5	100.02	0.12	979.000	982.661	982.661	66	99	73	4/10	0.9939	1.81	

Positive leak check performed by [Signature]
 Meter was in tolerance
 Meter was not in tolerance ; readjusted linkage
 Meter was not in tolerance ; changed dry test meters

Approved by [Signature] Date 4/4/94

* Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

Date 7-7-94 Control Module No. 4
Serial No. DIN 264552
Meter Test Meter No. AL-20
Technician S. BAWVICK

INTERPOLL LABORATORIES, INC.
METER CALIBRATION SHEET
EPA METHOD 6

Bar. Press. 28.82 in. Hg

Nominal	Actual	AH (in. WC)	Gas Volume Test Meter (ft ³)	Cal. Index (%)	Diff. Meter Test Meter (in. WC)	Gas Volume Dry Test Meter (ft ³)		Gas Temperatures			Time θ (min/sec)	Meter Coeff.	Orifice Const.	C _f
						V _{di}	V _{dt}	Met Test T _w (°F)	Dry Test T _{di} (°F)	T _{do} (°F)				
0.5	0.5	2	29.500	31.510	0.01	73	83	79	923	1.89				
1.2	1.2	3	44.900	47.575	0.025	73	90	83	9963	1.84				
2.0	2.0	3	26.000	29.041	0.055	73	83	79	9954	1.89				
3.3	3.3	5	39.000	44.092	0.09	73	93	83	10009	1.90				
4.7	4.7	5	33.000	38.072	0.12	73	89	81	9959	1.94				

Positive leak check performed by SLB

Meter was in tolerance

Meter was not in tolerance readjusted linkage

Meter was not in tolerance changed dry test meters

Approved by [Signature] Date 7/7/94

* Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

7

Control Module No. 904550
Serial No. DIM
Wet Test Meter No. AL-20
Technician E. J. [Signature]

INTERPOL LABORATORIES, INC.
METER CALIBRATION SHEET
EPA METHOD 6

Date 4-26-94
Bar. Press. 28.36 in. Hg

AH (in. WC)	Gas Volume Wet Test Meter (ft ³)	Cal. Index (Z)	Diff. Wet Test Meter ΔPw (in. WC)	Gas Volume Dry test meter (ft ³)		Gas Temperatures		Time (min/sec)	Meter Coeff.	Orifice Const.	G _f
				V _{d1}	V _{d2}	Wet Test T _w (°F)	Dry Test T _d (°F)				
0.5	2	99.85	0.01	693.700	695.728	69	80	75	5/02	9992	1.85
1.2	3	99.91	0.025	690.500	693.557	69	79	75	4/58	9928	1.92
2.0	3	99.93	0.055	696.000	699.060	69	84	77	3/54	9957	1.96
3.3	5	100.00	0.09	700.000	705.124	69	89	78	5/06	9938	1.98
4.7	5	100.02	0.12	705.500	710.686	69	90	79	4/20	9949	2.02

Positive leak check performed by [Signature]
Meter was in tolerance
Meter was not in tolerance I readjusted linkage
Meter was not in tolerance I changed dry test meters

Approved by [Signature] Date 5/2/94

* Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

Control Module No. 10
 Serial No. DTM 1334112
 Wet Test Meter No. AL-20
 Technician [Signature]

INTERPOL LABORATORIES, INC.
 METER CALIBRATION SHEET
 EPA METHOD 5

Date 5-31-94
 Bar. Press. 29.12 in. Hg


ΔH (in. WC)	Gas Volume Test Water (ft ³)	Cal. Index (%)	Diff. Wet Test Meter AP _w (in. WC)	Gas Volume Dry test meter (ft ³)		Gas Test Temp (°F)	Gas temperatures		Time θ min/sec	Meter Coeff.	Drift/Corst.	C _f
				V _{d1}	V _{d2}		Cal (°F)	Dry Test (°F)				
0.5	2	99.85	0.01	91.00	93.059	69	89	73	4/56	.9906	1.72	
1.2	3	99.91	0.025	87.000	87.073	69	88	74	4/52	.9916	1.77	
2.0	3	99.93	0.055	87.500	90.536	69	92	72	3/46	.9999	1.77	
3.3	5	100.00	0.09	93.500	98.640	69	95	74	4/55	.9927	1.79	
4.7	5	100.02	0.12	99.000	104.104	69	99	76	4/09	.9902	1.80	
										.9930	1.77	

Positive leak check performed by [Signature]
 Meter was in tolerance
 Meter was not in tolerance ; readjusted linkage
 Meter was not in tolerance ; changed dry test meters

Approved by [Signature] Date 6/6/94

* Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

DIFFERENTIAL PRESSURE PROOF CALIBRATION CURVE



Data obtained on an American 5 Ft. Bell Prover, Serial No. 2260. Traceable to the Bureau of Standards. Reference No. 106870, PI-TAPE.

AL-17 American Wet Test Meter
 Serial No. P-718
 Stainless Steel w/Removable Back
 Calibrated with Saturated Air
 Water Temp. 74° F.
 Air Temp. 74° F.
 Inlet Pressure 2" H₂O Constant
 Calibration Rate: 4 CFH Air
 Capacity Rate: 8 CFH Air
 Restricted Outlet for Rate Deviation.


CORRECT VOLUME INDEX READING x PROOF = 100

DAVID BANKS
 AUGUST, 1989


FLOW RATE - CUBIC FEET OF AIR PER HOUR

M-22

PROOF 101 100 99



DIFFERENTIAL PRESSURE TEST METER



DIFFERENTIAL INCHES H₂O

FLOW RATE - CUBIC FEET OF AIR PER HOUR

Calibrated with a 10 Ft. American Bell
 Prover, Serial No. 3157. Traceable to
 the Bureau of Standards. Reference No.
 5249068, PI-TAPE.

AL-20 American Met Test Meter
 Serial No. P-2717
 Stainless Steel w/Removable Back
 Calibrated w/Saturated Air
 Water Temp. 74° F.
 Air Temp. 74° F.
 Inlet Pressure 2" H₂O Constant
 Calibration Rate: 60 CFH Per/Hr.
 Capacity Rate: 120 CFH Per/Hr.
 Restricted Outlet for Rate Deviation

DAVID BANKS

November, 1991

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-12-94

Nozzle Number 3-4

Technician: Mark Kaehler

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.246
2	.246
3	.244
Average:	.245

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-12-94

Nozzle Number 5-3

Technician: Bob Aschenbach

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.195
2	.195
3	.197
Average:	.195

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-12-94

Nozzle Number 7-3

Technician: Dennis Marso

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.185
2	.184
3	.186
Average:	.185

Interpoll Laboratories, Inc.
(612) 786-6020

**Nozzle Calibration
Data Sheet**

Date of Calibration: 07-12-94
Technician: Mark Kaehler

Nozzle Number Glass

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.303
2	.302
3	.303
Average:	.303

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-13-94

Nozzle Number 8D-4

Technician: Mark Kaehler

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.237
2	.237
3	.237
Average:	.237

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-13-94

Nozzle Number Glass

Technician: Ed Trowbridge

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.303
2	.303
3	.302
Average:	.303

Interpoll Laboratories, Inc.
(612) 786-6020

**Nozzle Calibration
Data Sheet**

Date of Calibration: 07-14-94

Nozzle Number 3-4

Technician: Mark Kaehler

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.246
2	.246
3	.244
Average:	.245

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 07-14-94

Nozzle Number 5-3

Technician: Bob Aschenbach

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.195
2	.195
3	.197
Average:	.195

Interpoll Laboratories, Inc.
(612) 786-6020

**Nozzle Calibration
Data Sheet**

Date of Calibration: 07-14-94

Nozzle Number 8-4

Technician: Dennis Marso

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.243
2	.243
3	.243
Average:	.243

Interpoll Laboratories, Inc.
(612) 786-6020

**Nozzle Calibration
Data Sheet**

Date of Calibration: 07-15-94

Nozzle Number 8D-4

Technician: Mark Kaehler

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.237
2	.237
3	.237
Average:	.237

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test:

Vendor Omega Serial Number 735X1495 PDT-3
 Model HH81 Thermocouple Type K
 Range 0 - 2000 °F Technician Mark Jackson
 Date of Calibration 7-8-94

Method of Calibration:

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100 °F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	0	0	0
100	100	100	0	0
200	200	202	2	.30
300	300	300	0	0
400	400	399	1	.12
500	500	500	0	0
600	600	601	1	.09
700	700	700	0	0
800	800	802	2	.16
900	900	901	1	.07
1000	1000	1001	1	.07
1100	1100	1100	0	0
1200	1200	1201	1	.06
1300	1300	1299	1	.06
1400	1400	1402	2	.11
1500	1500	1500	0	0
1600	1600	1602	2	.10
1700	1700	1701	1	.05
1800	1800	1802	2	.09
1900	1900	1901	1	.04
2000	2000	2001	1	.04
2100	2100	2099	1	.04
		Averages:	.909	.06

OF = off scale response by unit under test (°F)
 $\% \text{ dev} = 100 \Delta t / (460 + t)$

- Unit in tolerance
 Unit was not in tolerance: recalibrated - See new calibration sheet.

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test:

Vendor OMEGA
 Model HH81 Serial Number 74JX0223 #33
 Range -160 - 2372 C °F Thermocouple Type K
 Date of Calibration 4-18-94 Technician BoB

Method of Calibration:

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100 °F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-1.0	-1.0	-.21
100	100	99.5	1.5	.26
200	200	200.3	.3	.04
300	300	298.6	1.4	.18
400	400	398	2	.23
500	500	499	1	.10
600	600	600	0	0
700	700	699	1	.08
800	800	801	1	.07
900	900	900	0	0
1000	1000	1001	1	.06
1100	1100	1099	1	.06
1200	1200	1201	1	.06
1300	1300	1299	1	.05
1400	1400	1402	2	.01
1500	1500	1500	0	0
1600	1600	1603	3	.14
1700	1700	1701	1	.04
1800	1800	1803	3	.13
1900	1900	1901	1	.04
2000	2000	2001	1	.04
2100	2100	2099	1	.03
		Averages:	1.05	.064

OF = off scale response by unit under test (°F)
 % dev = $100 \Delta t / (450 + t)$

- Unit in tolerance
 Unit was not in tolerance; recalibrated - See new calibration sheet.

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

E.T.'s

Unit under test: # 34

Vendor Omega
 Model HH 81 Serial Number 747X0343
 Range 0-2000 °F Thermocouple Type K
 Date of Calibration 4-21-94 Technician E. TROWBRIDGE

Method of Calibration:

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100 °F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-1.9	-1.9	.41
100	100	-97.5	-2.5	.45
200	200	199.7	-1.3	.05
300	300	297.5	-2.5	.33
400	400	397	-3	.35
500	500	498	-2	.20
600	600	600	0	0
700	700	699	-1	.08
800	800	801	+1	.08
900	900	900	0	0
1000	1000	1001	+1	.07
1100	1100	1098	-2	.13
1200	1200	1201	+1	.06
1300	1300	1299	-1	.05
1400	1400	1402	+2	.11
1500	1500	1500	0	0
1600	1600	1603	+3	.14
1700	1700	1701	+1	.05
1800	1800	1804	+4	.18
1900	1900	1901	+1	.04
2000	2000	2001	+1	.04
2100	2100	2099	-1	0
		Averages:	1.46	.128

OF = off scale response by unit under test (°F)
 % dev = $100 \Delta t / (460 + t)$

- Unit in tolerance
- Unit was not in tolerance; recalibrated - See new calibration sheet.

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test: # 58

Vendor Omega
 Model HH 51 Serial Number 745X 2474
 Range 0 - °F Thermocouple Type K
 Date of Calibration 5-5-94 Technician E TROWBRIDGE

Method of Calibration:

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100 °F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-2	-2.0	.43
100	100	99.0	-1	.18
200	200	200	0	0
300	300	298	-2	.26
400	400	399	-2	.23
500	500	499	-1	.10
600	600	600	0	0
700	700	699	-1	.09
800	800	802	+2	.16
900	900	900	0	0
1000	1000	1001	+1	.07
1100	1100	1100	0	0
1200	1200	1201	+1	.06
1300	1300	1299	-1	.05
1400	1400	1402	+2	.10
1500	1500	1500	0	0
1600	1600	1603	+3	.14
1700	1700	1701	+1	.05
1800	1800	1802	+2	.09
1900	1900	1901	+1	.04
2000	2000	2001	+1	.04
2100	2100	2099	-1	.04
		Averages:	1.14	.09

OF = off scale response by unit under test (°F)
 % dev = $100 \Delta t / (460 + t)$

Unit in tolerance
 Unit was not in tolerance; recalibrated - See new calibration sheet.

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 22-8

Pitot tube dimensions:

1. External tubing diameter (D) _____ .316 IN.
2. Base to Side A opening plane (P_A) _____ .460 IN.
3. Base to Side B opening plane (P_B) _____ .460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z $< .125"$.0
9. W $< .0625"$.01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle _____ .760 IN.
11. Pitot to probe sheath _____ 3.0 IN.
12. Pitot to thermocouple (parallel to probe) _____ 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) _____ .760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

1-8-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 23-6

Pitot tube dimensions:

1. External tubing diameter (D) _____, 316 IN.
2. Base to Side A opening plane (P_A) _____, 460 IN.
3. Base to Side B opening plane (P_B) _____, 460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. B₁ < 5° 0
7. B₂ < 5° 0

8. Z < .125" .02
9. W < .0625" .025

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle _____, 750 IN.
11. Pitot to probe sheath _____, 3.0 IN.
12. Pitot to thermocouple (parallel to probe) _____, 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) _____, 760 IN.

- Meets all EPA design criteria thus C_p = 0.84
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
C_p = _____

Date of Inspection:

4-8-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 23-8

Pitot tube dimensions:

1. External tubing diameter (D) _____, 316 IN.
2. Base to Side A opening plane (P_A) _____, 460 IN.
3. Base to Side B opening plane (P_B) _____, 460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z < .125" .03
9. W < .0625" .02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle _____, 760 IN.
11. Pitot to probe sheath _____, 3.0 IN.
12. Pitot to thermocouple (parallel to probe) _____, 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) _____, 760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-8-84

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 27-4

Pitot tube dimensions:

1. External tubing diameter (D_e) 1.316 IN.
2. Base to Side A opening plane (P_A) 4.60 IN.
3. Base to Side B opening plane (P_B) 4.60 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0
6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0
8. Z $< .125''$.02
9. W $< .0625''$.01

Distance from Pitot to Probe Components:


10. Pitot to 0.500 IN. nozzle 1.750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 1.760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:



S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 27-6

Pitot tube dimensions:

1. External tubing diameter (D_t) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. α_1 < 10° 0
5. α_2 < 10° 0

6. B_1 < 5° 0
7. B_2 < 5° 0

8. Z < .125" .01
9. W < .0625" .02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 29-4

Pitot tube dimensions:

1. External tubing diameter (D) _____, 3.16 IN.
2. Base to Side A opening plane (P_A) _____, 4.60 IN.
3. Base to Side B opening plane (P_B) _____, 4.60 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z $< .125"$.02
9. W $< .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle _____, 7.50 IN.
11. Pitot to probe sheath _____, 3.0 IN.
12. Pitot to thermocouple (parallel to probe) _____, 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) _____, 7.60 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 29-5

Pitot tube dimensions:

1. External tubing diameter (D) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. α_1 < 10° 0
5. α_2 < 10° 0

6. B₁ < 5° 0
7. B₂ < 5° 0

8. Z < .125" .02
9. W < .0625" .01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- Meets all EPA design criteria thus C_p = 0.84
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
C_p = _____

Date of Inspection:

1-7-84

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 29-8

Pitot tube dimensions:

1. External tubing diameter (D) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. α_1 < 10° 0
5. α_2 < 10° 0

6. B₁ < 5° 0
7. B₂ < 5° 0

8. Z < .125" .01
9. W < .0625" .02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- Meets all EPA design criteria thus C_p = 0.84
- Does not meet EPA design criteria - thus calibrate in wind tunnel.
C_p = _____

Date of Inspection:

4-7-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 4M5-8

Pitot tube dimensions:

1. External tubing diameter (D) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z $< .125"$ 0
9. W $< .0625"$ 0.2

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-93

Inspected by:

[Signature]

INTERPOLL LABORATORIES

(612)786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 7-7-94
 Technician Bob
 Mercury Column Barometer No. LAB
 Aneroid Barometer No. 107 23629

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (Pba-Pbm)
28.98	28	.129	28.85	28.84	.01

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. NO

Has problem been alleviated? Yes/No. How? _____

*Note

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

INTERPOLL LABORATORIES

(612)786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 7-8-94
 Technician Mark Haehler
 Mercury Column Barometer No. Lab 1
 Aneroid Barometer No. ~~560273~~ 21029004 MK

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} -P _{bm})
28.910	74	.119	28.791	28.78	.01

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____

Has problem been alleviated? Yes/No. How? _____

*Note

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

S-312

INTERPOLL LABORATORIES

(612)786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 11-15-93
 Technician R. Rosenthal
 Mercury Column Barometer No. NOVA - 1
 Aneroid Barometer No. _____

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} -P _{bm})
29.36	72	.116	29.244	29.24	0

Has this barometer shown any consistent problems with calibration? Yes/No. No. If yes, explain. _____

Has problem been alleviated? Yes/No. How? _____

*Note

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

S-312

INTERPOLL LABORATORIES
(612)786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

ET'S

Date 5-31-94
Technician E. T. [Signature]
Mercury Column Barometer No. LAB 1
Aneroid Barometer No. Weather model 12 SN-01002084

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} -P _{bm})
29.230	72	.115	29.115	29.12	.005

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. no

Has problem been alleviated? Yes/No. How? _____

*Note

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

S-312