

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

# **EMISSIONS TESTING OF A PRESS REGENERATIVE THERMAL OXIDIZER**

*Presented to*

**Louisiana-Pacific Corporation**  
Houlton, Maine

*Prepared by*

**TRC Environmental Corporation**  
Windsor, Connecticut

Raymond Potter  
Manager, Emissions Measurement Group

TRC Project No. 19624  
January, 1996

**TRC Environmental Corporation**  
5 Waterside Crossing  
Windsor, CT 06095  
Telephone: (860) 289-8631  
Facsimile: (860) 298-6399

# Table of Contents

<u>SECTION</u>		<u>PAGE</u>
1.0	INTRODUCTION .....	1
2.0	SUMMARY AND DISCUSSION OF RESULTS .....	2
2.1	Regenerative Thermal Oxidizer Emissions .....	2
2.1.1	Formaldehyde Emissions .....	2
2.1.2	NO <sub>x</sub> and CO Emissions .....	2
2.1.3	Volumetric Flowrate .....	5
3.0	PROCESS DESCRIPTION .....	6
3.1	Regenerative Thermal Oxidizer .....	6
4.0	SAMPLING AND ANALYTICAL METHODS .....	7
4.1	EPA Methods 7E and 10 - NO <sub>x</sub> and CO Measurements .....	7
4.1.1	Sample Collection System .....	7
4.1.2	NO <sub>x</sub> Analyzer .....	9
4.1.3	CO Analyzer .....	9
4.1.4	O <sub>2</sub> Analyzer .....	9
4.1.5	Data Acquisition and Handling .....	9
4.1.6	CEM Calibrations .....	10
4.2	NCASI Acetylacetone Method - Formaldehyde Measurements .....	10
4.2.1	Sample Collection .....	10
4.2.2	Sample Recovery .....	12
4.2.3	Sample Analysis .....	12
4.3	EPA Method 2 - Flowrate Measurements .....	13
4.4	Sampling Locations .....	13
4.4.1	Regenerative Thermal Oxidizer .....	13
5.0	QUALITY ASSURANCE .....	16
5.1	Sampling Quality Assurance .....	16
5.2	Analytical Quality Control .....	17

## List of Figures

<u>FIGURE</u>		<u>PAGE</u>
4-1	CEM Diagram .....	8
4-2	Formaldehyde Sampling Train .....	11
4-3	EPA Method 1 - RTO Inlet .....	14
4-4	EPA Method 1 - RTO Outlet .....	15

## List of Tables

### TABLE

### PAGE

2-1	Summary of Formaldehyde, NO <sub>x</sub> and CO Emissions - RTO Inlet .....	3
2-2	Summary of Formaldehyde, NO <sub>x</sub> and CO Emissions - RTO Outlet .....	4

## Appendices

A	Field Data
B	Analytical Data and Data Summaries
C	Process Data
D	Calibration Data

## 1.0 INTRODUCTION

TRC Environmental Corporation (TRC) was retained by Louisiana-Pacific Corporation to conduct an emissions measurement program on the regenerative thermal oxidizer (RTO) at the Louisiana-Pacific facility in New Limerick, Maine. The purpose of this program was to measure emissions of formaldehyde, oxides of nitrogen (NO<sub>x</sub>), and carbon monoxide (CO) at the inlet and outlet of the RTO. Emissions measurements for NO<sub>x</sub> and CO were conducted in accordance with accepted USEPA test methodologies. Formaldehyde testing was conducted using the NCASI Acetylacetone Method for measuring formaldehyde in water.

The test program was conducted on December 14, 1995 and was supervised by Mr. Raul Baez of TRC. Ms. Sue Somers and Mr. Mark Stile, both of Louisiana-Pacific, provided the process and logistical support during the program.

Section 2.0 of this test report presents a summary and discussion of the test results. Section 3.0 describes the process and associated control equipment and the parameters that were monitored during testing. Section 4.0 details the test methods to be used, and Section 5.0 presents TRC's quality control plan for this program.

## 2.0 SUMMARY AND DISCUSSION OF RESULTS

The purpose of this program was to measure emissions of formaldehyde, oxides of nitrogen (NO<sub>x</sub>), and carbon monoxide (CO) at the inlet and outlet of the regenerative thermal oxidizer (RTO). Emissions measurements for NO<sub>x</sub> and CO were conducted in accordance with accepted USEPA test methodologies. Formaldehyde testing was conducted using the NCASI Acetylacetone Method for measuring formaldehyde in water. The following sections provide the results for each pollutant.

### 2.1 Regenerative Thermal Oxidizer Emissions

Emissions measurements were conducted at the inlet and outlet of the regenerative thermal oxidizer (RTO) to determine inlet and outlet concentrations of formaldehyde, NO<sub>x</sub> and CO. Triplicate 60-minute formaldehyde tests were conducted at each location in accordance with the NCASI Acetylacetone Method for measurement of formaldehyde in water. Triplicate 20-minute NO<sub>x</sub> and CO tests were conducted at each location in accordance with EPA Methods 7E and 10, respectively. In addition, TRC measured the volumetric flowrate, concentration of oxygen, and moisture content of the exhaust gases at each location in accordance with EPA Methods 1-4. The results of the inlet and outlet tests are presented in Tables 2-1 and 2-2, respectively. All associated field data are presented in Appendix A.

#### 2.1.1 Formaldehyde Emissions

The results of the formaldehyde testing indicate that the average inlet concentration was 6.6 parts per million (ppm) and that the average inlet loading rate was 2.25 lb/hr. The average outlet concentration was 0.3 ppm and the average outlet emission rate was 0.10 lb/hr. The average removal efficiency of formaldehyde was 95.5 %.

#### 2.1.2 NO<sub>x</sub> and CO Emissions

The results of the continuous emissions monitoring for NO<sub>x</sub> and CO at the inlet of the RTO indicate that the average NO<sub>x</sub> concentration was 1.6 ppm and the average inlet loading rate was 0.83 lb/hr. The average CO concentration was 9.8 ppm and the average inlet loading rate was 3.10 lb/hr.

Table 2-1

Summary of Formaldehyde, NOx, and CO Loading  
at the RTO Inlet

Louisiana-Pacific Corporation  
New Limerick, Maine  
December 14, 1995

Test Number	In-1	In-2	In-3	Average
Time	1035-1135	1200-1300	1338-1438	
Location	RTO -Inlet	RTO -Inlet	RTO -Inlet	
<b>Stack Conditions</b>				
Stack Temperature (°F)	102	104	104	103
CO <sub>2</sub> (%)	0.00	0.00	0.00	0.00
O <sub>2</sub> (%)	20.8	20.9	20.8	20.8
Moisture (%)	1.33	1.37	1.40	1.36
Volumetric Flowrate, Actual (ACFM)	78432	79065	79364	78954
Volumetric Flowrate, Standard (SCFM) <sup>a</sup>	73109	73420	73688	73406
Volumetric Flowrate, Dry Std. (DSCFM) <sup>b</sup>	72137	72415	72660	72404
<b>Formaldehyde Emissions</b>				
Concentration (ppm)	5.9	6.5	7.6	6.6
Mass Emission Rate (lb/hr) <sup>c</sup>	1.98	2.20	2.57	2.25
<b>NOx Emissions</b>				
Concentration (ppm)	1.8	2.1	0.9	1.6
Mass Emission Rate (lb/hr) <sup>c</sup>	0.93	1.09	0.47	0.83
<b>CO Emissions</b>				
Concentration (ppm)	16.3	7.1	6.1	9.8
Mass Emission Rate (lb/hr) <sup>c</sup>	5.13	2.24	1.93	3.10

a - ACFM Actual Cubic Feet per Minute.

b - DSCFM Dry Standard Cubic Feet per Minute at 68°F and 29.92 in. Hg.

c - lb/hr = conc(ppm) x MW x flow(DSCFM) x 15.58E-08

MW Formaldehyde = 30

MW NO<sub>x</sub> = 46

MW CO = 28

Table 2-2

Summary of Formaldehyde, NOx, and CO Emissions  
at the RTO Outlet

Louisiana-Pacific Corporation  
New Limerick, Maine  
December 14, 1995

Test Number	out-1	out-2	out-3	Average
Time	1035-1135	1200-1300	1335-1435	
Location	RTO-outlet	RTO-outlet	RTO-outlet	
<b>Stack Conditions</b>				
Stack Temperature (°F)	232	234	235	233
CO <sub>2</sub> (%)	0.00	0.00	0.00	0.00
O <sub>2</sub> (%)	20.3	20.4	20.4	20.4
Moisture (%)	2.11	2.04	2.42	2.19
Volumetric Flowrate, Actual (ACFM)	95318	94835	96425	95526
Volumetric Flowrate, Standard (SCFM) <sup>a</sup>	72896	72370	73477	72914
Volumetric Flowrate, Dry Std. (DSCFM) <sup>b</sup>	71357	70891	71700	71316
<b>Formaldehyde Emissions</b>				
Concentration (ppm)	0.3	0.3	0.3	0.3
Mass Emission Rate (lb/hr) <sup>c</sup>	0.10	0.10	0.11	0.10
<b>NOx Emissions</b>				
Concentration (ppm)	15.9	16.0	15.6	15.8
Mass Emission Rate (lb/hr) <sup>c</sup>	8.13	8.13	8.02	8.09
<b>CO Emissions</b>				
Concentration (ppm)	16.5	15.8	16.6	16.3
Mass Emission Rate (lb/hr) <sup>c</sup>	5.14	4.89	5.19	5.07

a - ACFM Actual Cubic Feet per Minute.

b - DSCFM Dry Standard Cubic Feet per Minute at 68°F and 29.92 in. Hg.

c - lb/hr = conc(ppm) x MW x flow(DSCFM) x 15.58E-08

MW Formaldehyde = 30

MW NOx = 46

MW CO = 28

The results of the continuous emissions monitoring for NO<sub>x</sub> and CO at the outlet of the RTO indicate that the average NO<sub>x</sub> concentration was 15.8 ppm and the average emission rate was 8.09 lb/hr. The average CO concentration was 16.3 ppm and the average inlet loading rate was 5.07 lb/hr.

### 2.1.3 Volumetric Flowrate

Volumetric flowrate measurements were conducted at the inlet and outlet of the RTO in accordance with EPA Method 2. The results indicated that the inlet flowrate was approximately 1000 DSCFM greater than the outlet flowrate. However, the outlet flowrate should have been greater than the inlet flowrate due to the addition of combustion air. This error can be partially explained by the accuracy of the EPA Method 2. EPA Method 2 has an accuracy of +/- 10%. It is possible that the inlet measurement was biased high and the outlet may have been biased low.



### 3.0 PROCESS DESCRIPTION

The Houlton, Maine facility operates one oriented strandboard line including two wafer dryers, a press, and two thermal oil heaters.

#### 3.1 Regenerative Thermal Oxidizer

The regenerative thermal oxidizer (RTO) is used to control emissions of volatile organic compounds and particulate matter from the press operation. The RTO is fired on natural gas. During testing the plant operated at approximately 90% of the daily production rate of 440 tons per day. Plant personnel monitored and recorded the following data:

Panels/Hour

Panel Weight

Press Temp.

Tons/Hour

Copies of the recorded process data are presented in **Appendix C**.

#### 4.0 SAMPLING AND ANALYTICAL METHODS

Emissions measurements were conducted at the inlet and outlet of the RTO in accordance with the following methods.


##### 4.1 NO<sub>x</sub> and CO Emissions Measurements - EPA Methods 7E and 10

Triplicate 20-minute tests were conducted at the inlet and outlet of the RTO to measure concentrations of NO<sub>x</sub> and CO. Testing was conducted in accordance with EPA Methods 7E and 10, respectively. Diluent concentrations of oxygen were measured in accordance with EPA Method 3A. A schematic of the measurement system is presented in Figure 4-1. A single CEMS was used to evaluate inlet and outlet concentrations. A three way valve was placed in line prior to the conditioning system, which allowed the operator to switch from the inlet to the outlet location and vice versa. Each sampling location had a dedicated sampling probe and heated sample line prior to the three way valve and conditioning system.

All CEM data was recorded by a Yokogawa Model 2300 strip chart/data logger which is capable of integrating 5-minute and 20-minute averages. The CEM system was housed in the TRC Mobile Environmental Laboratory (MEL) which was parked at the base of the RTO.

##### 4.1.1 Sample Conditioning System

An in-stack Alundum thimble filter with a stainless steel nozzle facing away from the stack gas flow was used to remove any PM from the sample gas stream. The thimble filter was mounted on the end of a stainless steel sampling probe. The sample was then drawn through 100 feet of heated (325°F ± 25°F) Teflon sample line through a condenser system to remove the moisture from the gas stream. The sample was drawn through the tubing by a leak-free Teflon double-diaphragm pump to a stainless steel sample manifold with an atmospheric bypass rotameter. The analyzers then drew their samples from the manifold.



**TRC Environmental Corporation**

5 Waterside Crossing  
Windsor, CT 06095  
(203) 289-8631

**FIGURE 4-1.  
CONTINUOUS EMISSION MONITORING  
SYSTEM SCHEMATIC**

#### 4.1.2 NO<sub>x</sub> Analyzer

A Thermo-Electron Corporation Model 10A Chemiluminescent NO/NO<sub>x</sub> analyzer was used to determine NO<sub>x</sub> concentrations. The chemiluminescent reaction of NO and O<sub>3</sub> (ozone) provides the basis for the analytical method ( $\text{NO} + \text{O}_3 \rightarrow \text{NO}_2 + \text{O}_2 + \text{light}$ ). A photomultiplier-electrometer-amplifier produces a current proportional to the NO concentration. The output of the amplifier provides a signal for direct readout on a meter indicator, or for outputs to a recorder or computer.

#### 4.1.3 CO Analyzer

A TECO Model 48 nondispersive infrared gas analyzer was used to measure CO concentrations. The analyzer contains an infrared detector that uses the signal nondispersive beam technique with alternate modulations of the sample and reference cells. Radiation absorbed by CO in the sample cell results in a capacitance change in the detector which is proportional to the CO concentration.

#### 4.1.4 O<sub>2</sub> Analyzer

A Horiba Model PMA-200 O<sub>2</sub> analyzer was used to determine the concentration of O<sub>2</sub> in the stack gas. This instrument uses the paramagnetic principle, whereby the magnetic susceptibility of the gas volume is measured by the force acting on a nonmagnetic test body suspended in a magnetic field. The force is converted to an output current proportional to the O<sub>2</sub> concentration.

#### 4.1.5 Data Acquisition and Handling

All CEM data was monitored by a Yokagawa Model 2400 automatic data logger. Emissions data was "viewed" by the data logger every six seconds, averaged, and printed at 5-minute intervals and 20-minute intervals.

#### 4.1.6 CEM Calibrations

Calibrations (zero, low, mid, and high of span) of each analyzer were performed using EPA Protocol 1 gases at the beginning and end of each test period. Calibration gases were introduced to the system through a three-way valve at the back of the sample probe. The gas concentrations used were approximately 30%, 60%, and 90% of each analyzer's range. Each analyzer was multi-point calibrated at the beginning of the test program to establish linearity of each instrument.


#### 4.2 Formaldehyde Measurements - NCASI Method

Triplicate 60-minute tests were conducted at the inlet and outlet of the RTO to measure concentrations of formaldehyde. Testing was conducted in accordance with the NCASI Acetylacetone Method (Determination of Formaldehyde in Water), with inlet and outlet testing conducted simultaneously. The sampling system describe in the NCASI method was modified by TRC. TRC's modification was to use a standard EPA Method 5 train with standard impingers instead of mini-impingers. This modification allowed for more accurate measurement of sample volume and the use of heated probes and filters.

##### 4.2.1 Sample Collection

Formaldehyde sampling was accomplished by use of an EPA Method 5 train. The sample train is shown schematically in Figure 4-2 and consisted of a nozzle, probe, filter, four impingers, a vacuum pump, dry-gas meter, and an orifice flow meter.

A stainless steel nozzle was attached to a glass-lined stainless steel probe which was heated to prevent condensation. Teflon mat filter papers supported in 4½-inch glass filter holders were used to remove particulate matter from the gas stream. The filter assembly was enclosed in a heated box to maintain temperatures at  $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$ . A thermocouple located inside the back half of the filter holder monitored the gas stream temperature and verified that the temperature was kept at  $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$ .



**TRC**  
 TRC Environmental Corporation  
 5 Waterside Crossing  
 Windsor, CT 06095  
 (203) 269-8631

Figure 4-2  
 NCASI Formaldehyde Train

An ice bath containing four impingers was attached to the back end of the filter. The first and second impingers contained 100 milliliters (ml) each of HPLC grade deionized water. The third impinger was empty, and the fourth impinger contained silica gel to remove any remaining moisture. Flexible tubing, a vacuum gauge, a needle valve, a leakless vacuum pump, a bypass valve, a dry-gas meter calibration orifice, and an inclined manometer completed the sampling train. The stack velocity pressure and temperature were monitored by an S-type pitot and a thermocouple connected to a potentiometer. A check valve was not used in the TRC sampling train.

Sampling flow was adjusted by means of the bypass valve. Before and after each particulate test run, the sampling train was leak checked to meet the 0.02 cfm limit. All pertinent test data were recorded on the appropriate field data sheets.

#### 4.2.2 Sample Recovery

Two sample containers were used, as follows:

- Container No. 1: The impinger contents were measured volumetrically to the nearest milliliter and deposited into a sample jar. Each impinger was rinsed three times with HPLC grade deionized water. The water rinses were also deposited into the sample jar.
- Container No. 2: Silica gel from the fourth impinger was transferred to its original container and weighed to the nearest 0.5 milligram (mg).

#### 4.2.3 Sample Analysis

The samples were transported to TRC's laboratory, where the following analyses were performed:

- Container No. 1: The impinger contents were analyzed in accordance with the NCASI Acetylacetone Method.

Container No. 2: Silica gel was weighed to the nearest 0.5 mg. The weight of the moisture entrapped in the silica gel, along with the impingers, was used to calculate the moisture content of the stack gas.

#### 4.3 Flowrate and Moisture Measurements

Flowrate measurements were conducted according to EPA Method 2. An S-type pitot and an inclined manometer were used to measure the velocity pressure head, and a thermocouple was used to monitor gas stream temperature.

#### 4.4 Sampling Locations

Sampling points for isokinetic and/or flowrate measurements at each location were determined in accordance with EPA Method 1.

##### 4.4.1 Regenerative Thermal Oxidizer Inlet and Outlet

Inlet sampling was conducted from two ports in the 54-inch diameter stack. The ports were located 2.8 diameters downstream from any flow disturbances and 5.4 diameters upstream from any flow disturbances. Twenty four traverse points were sampled with each flowrate measurement. The inlet sampling point locations are presented in **Figure 4-3**.

Outlet sampling was conducted from two ports in the 76-inch diameter stack. The ports were located 10.4 diameters downstream from any flow disturbances and 6.9 diameters upstream from the stack exhaust. Twelve traverse points were sampled with each flowrate measurement. The outlet sampling point locations are presented in **Figure 4-4**.



Figure 4-3



TRC Environmental Corporation

EPA Method 1 Data Sheet

Firm Louisiana-Pacific  
 Location RTO Inlet  
 Diameters Upstream 5.4  
 Diameters Downstream 2.8  
 Nipple Size (in.) 6

Total Traverse Points Required 24  
 Number of Ports 2  
 Points Per Port 12  
 Traverse (Horizontal or Vertical) Horizontal/Vertical

Minimum Number of Traverse Points For Particulate and Non-Particulate Traverses



Cross-Sectional Layout For Rectangular Stacks	
Total Traverse Points	Matrix
9	3x3
12	4x3
16	4x4
20	5x4
25	5x5

Location of Points on a Circular Stack

Point Number On a Diameter	(Percent of Stack Diameter from Inside Wall to Traverse Point)			
	No. of Traverse Points on a Diameter)			
	4	8	10	12
1	6.7	3.2	2.6	2.1
2	25.0	10.5	8.2	6.7
3	75.0	19.4	14.6	11.8
4	93.3	32.3	22.6	17.7
5		67.7	34.2	25.0
6		80.6	65.8	35.6
7		89.5	77.4	64.4
8		96.8	85.4	75.0
9			91.8	82.3
10			97.4	88.2
11				93.3
12				97.9

Traverse Point Location

Point Number	Distance From Wall	Total Distance
1	1.1	7.1
2	3.6	9.6
3	6.4	12.4
4	9.6	15.6
5	13.5	19.5
6	19.2	25.2
7	34.8	40.8
8	40.5	46.5
9	44.4	50.4
10	47.6	53.6
11	50.4	56.4
12	52.9	58.9

Figure 4-4



TRC Environmental Corporation

EPA Method 1 Data Sheet

Firm	Louisiana-Pacific
Location	RTO Outlet
Diameters Upstream	6.9
Diameters Downstream	10.4
Nipple Size (in.)	6

Total Traverse Points Required	12
Number of Ports	2
Points Per Port	6
Traverse (Horizontal or Vertical)	Horizontal

Minimum Number of Traverse Points For Particulate and Non-Particulate Traverses



Duct Diameters Downstream From Flow Disturbance

Cross-Sectional Layout For Rectangular Stacks	
Total	
Traverse Points	Matrix
9	3x3
12	4x3
16	4x4
20	5x4
25	5x5

Location of Points on a Circular Stack

Point Number On a Diameter	(Percent of Stack Diameter from Inside Wall to Traverse Point)			
	No. of Traverse Points on a Diameter			
	4	8	10	12
1	6.7	3.2	2.6	2.1
2	25.0	10.5	8.2	6.7
3	75.0	19.4	14.6	11.8
4	93.3	32.3	22.6	17.7
5		67.7	34.2	25.0
6		80.6	65.8	35.6
7		89.5	77.4	64.4
8		96.8	85.4	75.0
9			91.8	82.3
10			97.4	88.2
11				93.3
12				97.9

Traverse Point Location

Point Number	Distance From Wall	Total Distance
1	3.3	9.3
2	11.1	17.1
3	22.5	28.5
4	53.5	59.5
5	64.9	70.9
6	72.7	78.7
7		
8		
9		
10		
11		
12		

## 5.2 Analytical Quality Control


Compressed gases used as fuels and carriers were purchased at specific purities, according to application. Compressed gases used as calibration standards are always National Institute for Standards and Technology (NIST) traceable, either directly or indirectly.

In the TRC and subcontract laboratories, all QC samples including field blank samples, reagent and filter blanks, and any audit samples were analyzed with the actual test samples. Each laboratory maintains a continuous QC program to monitor instrument response and analyst proficiency and to ensure the precision and accuracy of all analytical results. These programs were developed in consultation with EPA, NIOSH, and various state departments of health.

TRC used some or all of the following quality control procedures during the field and laboratory sampling program:

*Field Blanks*—For each set of samples taken, a field blank was also be collected. Field blanks included filter materials and solutions used for sample collection and recovery.

*Replicates*—When the analytical procedure permitted, a prescribed number of the analyses were duplicated to indicate the precision of the method used.



Appendix A

Field Data

ISOKINETIC SAMPLING DATA

PLANT NAME, CITY, STATE		SAMPLING LOCATION				Method No.		RUN NUMBER		TEST DATE		Notes	
OPERATORS	Static P. (In. H <sub>2</sub> O)	Ambient T. (°F)	Filter Type & Filter Number(s)	Stack (ID (In.))	Pilot Tube Cp	Probe Length and Liner Type	Nozzle Number	Diagrams	DGM Temp. (°F)	DGM In.	DGM Out	Sample Train Vacuum (In. Hg)	XAD Trap Temp. (°F)
S.D. RB	DGM CAL Y	Assumed Moist. %	Stack Therm. No.	Impinger Therm. No.	Leak Check (In. Hg)	Leak Check (In. Hg)	AUX Temp. (°F)		AUX Temp. (°F)	DGM In.	DGM Out		
PITOT LEAK CHECK	DGM No.	DRY GAS METER READING (Cubic Feet)	AP Velocity (In. H <sub>2</sub> O)	Stack Temp. (°F)	Probe Temp. (°F)	Filter Oven Temp. (°F)	Impinger Temp. (°F)						
OK	ELAPSED TEST TIME (min)	CLOCK TIME (24-hour)	AP Velocity (In. H <sub>2</sub> O)	AH Office (In. H <sub>2</sub> O)	Stack Temp. (°F)	Probe Temp. (°F)	Impinger Temp. (°F)						
POINT NUMBER	1	10:35	0	11.000	1.88	100	240	235	25	33	30	3	
	5	11:00	14.700	1.88	100	244	240	240	24	36	31	3	
	10	11:30	18.300	1.88	100	242	245	245	30	38	32	3	
	15	12:00	23.900	1.88	100	244	246	246	34	39	33	3	
	20	12:30	25.600	1.88	100	248	250	250	30	43	34	3	
	25	13:00	29.200	1.88	100	240	254	254	38	45	36	3	
	30	13:30	32.800	1.88	100	235	255	255	40	47	37	3	
	35	14:00	36.300	1.88	100	230	255	255	40	48	38	3	
	40	14:30	39.800	1.88	100	235	257	257	40	49	39	3	
	45	15:00	43.300	1.88	100	235	257	257	42	49	40	3	
	50	15:30	46.900	1.88	100	230	258	258	45	49	40	3	
	55	16:00	50.300	1.88	100	230	257	257	48	49	41	3	
STOP	60	16:35	53.663	1.88	100	230	257	257	48	49	41	3	
		DGM Volume		Stack Temp.		Ave. SQR AP		Ave. DGM Temp.		40			
Total Run Time		60		42.663									

TRC

ISOKINETIC SAMPLING DATA

PLANT NAME, CITY, STATE		SAMPLING LOCATION			RUN NUMBER		TEST DATE		Notes				
Kosmin Paper		Inlet			11# 2		12/14/95		Forumkshp.de				
OPERATORS	Stand P (in H <sub>2</sub> O)	Ambient T (°F)	Filter Type & Filter Number(s)	Stack (D. in.)	Pilot Tube Sp	Probe Length and Liner Type	Nozzle Number	Diameter	K Factor	DGM In	DGM Out	Sample Train Vacuum (in Hg)	XAD Trap Temp. (°F)
PITOT LEAK CHECK	DGM CAL	DGM	AP	AH	Probe Temp. (°F)	Filter Oven Temp. (°F)	Impinger Temp. (°F)	ALOX Temp. (°F)	DGM In	DGM Out	Sample Train Vacuum (in Hg)	XAD Trap Temp. (°F)	
OK	1.88	100	2	1.88	10	0.001	5	0.000	39	38	3	N/A	
CLOCK TIME (24-hour)	ELAPSED TEST TIME (min)	DRY GAS METER READING (Cubic Feet)	AP Velocity (in. H <sub>2</sub> O)	AH Office (in. H <sub>2</sub> O)	Probe Temp. (°F)	Filter Oven Temp. (°F)	Impinger Temp. (°F)	ALOX Temp. (°F)	DGM In	DGM Out	Sample Train Vacuum (in Hg)	XAD Trap Temp. (°F)	
12:00	0	53,500	1.88	1.88	225	230	36	N/A	39	38	3	N/A	
	5	57,400	1.88	1.88	225	230	35		39	38	3		
	10	60,900	1.88	1.88	236	240	35		41	37	3		
	15	64,400	1.88	1.88	236	240	36		42	37	3		
	20	67,900	1.88	1.88	240	238	40		44	37	3		
	25	71,400	1.88	1.88	240	237	40		44	37	3		
	30	74,900	1.88	1.88	242	243	39		45	37	3		
	35	77,200	1.88	1.88	240	247	39		46	38	3		
	40	81,600	1.88	1.88	238	252	38		46	38	3		
	45	85,100	1.88	1.88	236	254	37		46	38	3		
	50	88,500	1.88	1.88	248	256	37		47	39	3		
	55	91,900	1.88	1.88	249	257	37		47	39	3		
STOP	13:00	95,312											

Total Run Time	60	DGM Volume	41,512	Average ΔH		Stack Temp	
Ave. DGM Temp.			A1				

TRC

ISOKINETIC SAMPLING DATA

PLANT NAME, CITY, STATE		SAMPLING LOCATION				METHOD No.		RUN NUMBER		TEST DATE		Notes	
L.P. Houlton ME.		Inlet						ln# 3		12/4/95			
OPERATORS	Beometric (in. Hg)	Stack P. (in. H2O)	Ambient T. (°F)	Filter Type & Filter Number(s)	Stack I.D. (in.)	Pilot Tube G2	Probe Length and Line Type	Marzel Number	Marzel Diameter	Impinger Therm. No.	Leak Check (in. Hg)	Leak Check (in. Hg)	K Factor
PITOT LEAK CHECK	DGM No.	DGM CAL	Assumed Mult. %	Pilot No.	Stack Therm. No.	Impinger Temp. (°F)	Probe Temp. (°F)	ADJ Temp. (°F)	DGM Temp. (°F)	DGM In	DGM Out	Sample Train Vacuum (in. Hg)	KAD Trap Temp. (°F)
OK	80823	188	1.00	2	C-7	188	100	236	240	35	NA	35	NA
ELAPSED TEST TIME (min)	GLOCK TIME (24-hour)	METER READING (Cubic Feet)	DRY GAS	AP Velocity (in. H2O)	AH Office (in. H2O)	Stack Temp. (°F)	Filter Oven Temp. (°F)	Impinger Temp. (°F)	DGM Temp. (°F)	DGM In	DGM Out	Sample Train Vacuum (in. Hg)	KAD Trap Temp. (°F)
5		99.200			1.88	100	238	241	39	36	35	3	
10		102.900			1.88	100	242	241	40	38	35	3	
15		106.600			1.88	100	241	239	43	40	35	3	
20		110.300			1.88	100	242	244	45	42	35	3	
25		114.000			1.88	100	238	248	47	43	35	3	
30		117.700			1.88	100	240	257	48	44	36	3	
35		121.400			1.88	100	239	256	50	45	36	3	
40		125.100			1.88	100	238	257	50	45	36	3	
45		128.800			1.88	100	236	259	52	46	37	3	
50		132.500			1.88	100	241	260	53	46	37	3	
55		135.700			1.88	100	238	262	54	46	37	3	
60		139.067											
STOP	14:38												
Total Run Time		DGM Volume		Ave. SORT AP		Average AH		Stack Temp		Ave. DGM Temp			
43.667		43.667								139		TRC	



ISOKINETIC SAMPLING DATA

PLANT NAME, CITY, STATE		SAMPLING LOCATION				METHOD NO.		RUN NUMBER		TEST DATE		Notes			
Louisiana Pacific		Oriskany - 11255				0001		1-007		12/13/95		Feedwater hydr			
OPERATIONS	Barometric (in. Hg)	Static P. (in. H2O)	Ambient T. (°F)	Filter Type & Filter Number(s)	Stack I.D. (in.)	Pilot No.	Stack Therm. No.	Impinger Therm. No.	Probe Temp. (°F)	Leak Check (in. Hg)	Leak Check (in. Hg)	Leak Check (in. Hg)	Probe Length and Line Type	Nozzle Number	Nozzle Diameter
R. Over/under	30.02	-0.42	15	—	77					0.001	8	0.000	5		
PITOT LEAK CHECK	DGM No.	DGM Y	DGM CAL	Assumed Moist. %	AH	AP	Stack Therm. No.	Stack Therm. No.	Probe Temp. (°F)	Leak Check (in. Hg)	Filter Oven Temp. (°F)	Impinger Temp. (°F)	AUX Temp. (°F)	DGM Temp. (°F)	DGM In. Vacuum (in. Hg)
	50136	175	1.00		175				230	0.001	245	32		41	5
POINT NUMBER	CLOCK TIME (24-hour)	ELAPSED TEST TIME (min)	DRY GAS METER READING (Cubic Feet)	AP Velocity (in. H2O)	AH Velocity (in. H2O)	AP Velocity (in. H2O)	Stack Temp. (°F)	Stack Temp. (°F)	Probe Temp. (°F)	Leak Check (in. Hg)	Filter Oven Temp. (°F)	Impinger Temp. (°F)	AUX Temp. (°F)	DGM Temp. (°F)	DGM In. Vacuum (in. Hg)
1	1025	0	742.953		175		230	236	240	0.001	245	32		41	5
	1040	5	746.091				236	236	250		250	33		41	5
	1045	10	749.46				236	236	250		250	34		41	5
	1050	15	752.91				236	236	250		250	36		41	5
	1055	20	754.41				236	236	250		250	38		43	5
	1100	25	759.62				236	236	250		250	39		48	5
	1105	30	763.19				236	236	250		250	40		50	5
	1110	35	766.69				236	236	250		250	41		51	5
	1115	40	770.32				236	236	251		242	42		53	5
	1120	45	774.07				236	236	251		237	45		53	5
	1125	50	777.36				236	236	251		237	49		53	5
	1130	55	780.84				236	236	250		244	51		53	5
	1135	60	784.300												
Total Run Time		DGM Volume		Avg. BOBT AP		Average Δt		Stack Temp		Avg. DGM Temp					
		41.347								44					

ISOKINETIC SAMPLING DATA

PLANT NAME, CITY, STATE		SAMPLING LOCATION			METHOD No.		RUN NUMBER		TEST DATE		Notes						
Horseshoe Park		Duct			10		2		12/14/85								
OPERATORS	Barometric (in Hg)	Static P. (in H2O)	Ambient T. (°F)	Filter Type & Filter Numbers	Stack ID (in)	Pilot Tube Sp.	Probe Length and Dist. Type		Nozzle Number	Diameter							
							1/2	1/2									
BAFL/Bake	30.02	-0.42	10		7A	10	10	0.000	3"	2.000							
PITOT LEAK CHECK	DGM CAL	DGM CAL Y	Assumed Moist. %	Pilot No.	Stack Therm. No.	Leak Check (in)	Leak Check (in)	Leak Check (in)	K Factor								
	30.36	1.75	10	5"		10	0.000	3"	2.000								
POINT NUMBER	CLOCK TIME (24-hour)	ELAPSED TEST TIME (min)	DRY GAS METER READING (Cubic Feet)	AP Velocity (in H2O)	AH Office (in H2O)	Stack Temp. (°F)	Filter Oven Temp. (°F)	Impinger Temp. (°F)	AUX Temp. (°F)	DGM Temp. (°F)	DGM In (in Hg)	DGM Out (in Hg)	Sample Train Vacuum (in Hg)	RAD Trap Temp. (°F)			
															1	2	3
1	1210	0	754.45		1.75	230	233	33		40	45	3					
	1205	5	748.31		1.73	230	233	33		40	45	3					
	1210	10	741.65		1.71	230	235	33		40	45	3					
	1215	15	745.40		1.75	230	240	33		40	45	3					
	1220	20	748.30		1.75	230	243	33		40	45	3					
	1225	25	801.72		1.75	230	242	34		40	45	3					
	1230	30	805.27		1.75	230	243	34		40	45	3					
	1235	35	808.77		1.75	230	242	38		40	45	3					
	1240	40	812.30		1.75	230	242	40		40	46	3					
	1245	45	815.84		1.75	230	242	40		40	46	3					
	1250	50	819.42		1.75	230	243	43		40	46	3					
	1255	55	823.0		1.75	230	242	45		40	46	3					
	1300	60	827.45		1.75	230	242	45		40	46	3					
												Avg DGM Temp.		47			
												Total Run Time		43.00			
												Avg. ROBT AP		Average AH		Stack Temp	

TRC

ISOKINETIC SAMPLING DATA

PLANT NAME, CITY, STATE		SAMPLING LOCATION					TEST DATE					Notes																					
Louisiana Power		Wulf-		Method No.			#3		12/14/95			Formaldehyde																					
OPERATORS	Barometric (In. Hg)	Static P (In. H2O)	Ambient T (°F)	Filter Type & Filter Assembly	Stack ID (In.)	Phot. Tube Or	Probe Length and Liner Type		Nozzle Number	Diameter	K Factor	Notes																					
							Leak Check (In. Hg)	Leak Check (In. Hg)																									
EXE2/BANU	29.99	-0.12	10		77	081		5																									
PITOT LEAK CHECK	DGM No.	AW	Assumed Moist %	Pitot No.	Stack Therm. No.	Impinger Therm. No.	Leak Check (In. Hg)	Filter	AUX Temp (°F)	DGM Temp (°F)	DGM In (In. Hg)	DGM Out (In. Hg)	Impinger Temp (°F)	Filter Oven Temp (°F)	Probe Temp (°F)	Stack Temp (°F)	AH Office (In. H2O)	AP Velocity (In. H2O)	DRY GAS METER READING (Cubic Feet)	ELAPSED TEST TIME (min)	CLOCK TIME (24-hour)	POINT NUMBER	Sample Train Vacuum (In. Hg)	XAD Trap Temp (°F)									
✓	8236	1.77	1.0	3			0.001	10	5	0.000			29	200	215	230	1.75		826.600	0	1338	1	2										
													32	238	245	230	1.75		830.10	5	1343		2										
													34	240	249	230	1.75		833.45	10	1348		2										
													35	242	249	230	1.75		836.89	15	1353		2										
													36	242	250	230	1.75		840.23	20	1358		2										
													38	240	250	230	1.75		843.68	25	1403		2										
													40	243	250	230	1.75		847.17	30	1408		2										
													43	242	250	230	1.75		850.46	35	1413		2										
													43	242	251	230	1.75		853.93	40	1418		2										
													48	243	250	230	1.75		857.45	45	1423		2										
													50	242	250	280	1.75		860.96	50	1428		2										
													50	245	250	230	1.75		864.51	55	1433		2										
													50	245	250	230	1.75		868.044	60	1438		2										
																					Total Run Time		DGM Volume		Ave. FORT AP		Average AH		Stack Temp		Ave. DGM Temp		
																					41.444										45		

PLANT LP  
 DATE 12-14-95 9:30AM  
 LOCATION Press - Inlet - stack  
 STACK DIMENSIONS 54.6" AREA \_\_\_\_\_ ft<sup>2</sup>  
 BAROMETRIC PRESSURE, P<sub>b</sub> = 30.04 in. Hg  
 STACK STATIC PRESSURE, P<sub>g</sub> = ± -4.5 in. H<sub>2</sub>O  
 STACK GAS MOLECULAR WEIGHT (Wet), M<sub>w</sub> 28.9  
 STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = 10%  
 PITOT NO. \_\_\_\_\_ Cp = 0.99  
 TESTER \_\_\_\_\_

SCHMATIC OF TRAVERSE POINT LOCATION  
 + θ Clockwise  
 Cyclonic Flow Angle - θ Counterclockwise

PORT	POINT	ΔP Inch H <sub>2</sub> O	√ΔP	T <sub>sr</sub> (°F)	± θ	Pitots reversed for Negative Flow?	√ΔP · COS θ
A	1	1.5		90			
	2	1.7		100			
	3	1.9		100			
	4	2.0		100			
	5	2.2		105			
	6	2.2		105			
	7	2.3		105			
	8	2.4		105			
B	1	1.3		100			
	2	1.4		102			
	3	2.2		100			
	4	2.2		100			
	5	1.9		100			
	6	1.9		100			
	7	1.8		100			
	8	1.7		103			
Average		2.756		T <sub>s</sub> = 101°F T <sub>sr</sub> = 561°R	*		

\*Avg. of absolute values including zeroes

Absolute Gas Temperature, T<sub>sr</sub> = T<sub>s</sub> + 460° = 29.709

Absolute Gas Pressure, P<sub>s</sub> = P<sub>b</sub> + P<sub>g</sub>/13.6 = 30.01

Gas Velocity, V<sub>s</sub> = (85.49) C<sub>p</sub> (√ΔP · COS θ) avg = 79.98 ft/sec (59.47)

Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = 16780 ACFM (5003)  
 Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub> (528°R / T<sub>sr</sub>) (P<sub>s</sub> / 29.92) (100 - % H<sub>2</sub>O / 100) = 30464 DSCFM

PLANT LP  
 DATE 12-14-85 1200  
 LOCATION Inlet  
 STACK DIMENSIONS 54.5 AREA \_\_\_\_\_ ft<sup>2</sup>  
 BAROMETRIC PRESSURE, P<sub>b</sub> = 30.04 in. Hg  
 STACK STATIC PRESSURE, P<sub>g</sub> = ± -4.6 in. H<sub>2</sub>O  
 STACK GAS MOLECULAR WEIGHT (Wet), M<sub>w</sub> 28.9  
 STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = \_\_\_\_\_  
 PITOT NO. \_\_\_\_\_ C<sub>p</sub> = 0.84  
 TESTER \_\_\_\_\_

SCHEMATIC OF TRAVERSE POINT LOCATION  
 + θ Clockwise  
 Cyclonic Flow Angle - θ Counterclockwise

PORT	POINT	ΔP Inch H <sub>2</sub> O	√ΔP	T <sub>s</sub> (°F)	± θ	Pitots reversed for Negative Flow?	√ΔP · COS θ
A	1	1.6		100			
	2	1.7		100			
	3	1.9		100			
	4	2.1		100			
	5	2.2		105			
	6	2.2		102			
	7	2.3		106			
	8	2.4		107			
B	1	1.4		100			
	2	1.4		100			
	3	2.2		102			
	4	2.2		103			
	5	1.9		104			
	6	1.9		105			
	7	1.8		107			
	8	1.7		104			
Average			1.385	T <sub>s</sub> = 103°F	*		
				T <sub>sr</sub> = 763°R			

\*Avg. of absolute values including zeroes


Absolute Gas Temperature, T<sub>sr</sub> = T<sub>s</sub> + 460°

Absolute Gas Pressure, P<sub>s</sub> = P<sub>b</sub> + P<sub>g</sub>/13.6 = 29.70

Gas Velocity, V<sub>s</sub> = (85.49) C<sub>p</sub> (√ΔP · COSθ) avg  $\sqrt{\frac{T_{sr} \text{ avg}}{P_s M_w}}$  = 80.57 ft/sec

Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = 16502 ACFM

Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub>  $\left(\frac{528^\circ R}{T_{sr}}\right) \left(\frac{P_s}{29.92}\right) \left(\frac{100 - \% H_2O}{100}\right)$  = 15053 DSCFM



PLANT LD

DATE 12/14/82

LOCATION INLET

STACK DIMENSIONS AREA 545 ft<sup>2</sup>

BAROMETRIC PRESSURE, P<sub>b</sub> = 30.01 in. Hg

STACK STATIC PRESSURE, P<sub>g</sub> = -4.7 in. H<sub>2</sub>O

STACK GAS MOLECULAR WEIGHT (M<sub>w</sub>) 28.9

STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = \_\_\_\_\_

PILOT NO. 084

TESTER \_\_\_\_\_

**SCHMATIC OF TRAVERSE POINT LOCATION**

+ θ Clockwise

- θ Counterclockwise

PORT	POINT	AP Inch H <sub>2</sub> O	√AP	(P <sub>s</sub> ) in. Hg	± θ	Pilots reversed for Negative Flow?	√AP · COS θ
A	1	1.6	1.26	1.02			
	2	1.9	1.37	1.02			
	3	1.8	1.34	1.02			
	4	1.9	1.37	1.02			
	5	2.2	1.48	1.02			
	6	2.2	1.48	1.02			
	7	2.3	1.52	1.02			
	8	2.4	1.55	1.02			
B	9	1.5	1.22	1.02			
	2	1.1	1.05	1.02			
	3	2.2	1.48	1.02			
	4	2.2	1.48	1.02			
	5	2.2	1.48	1.02			
	6	2.2	1.48	1.02			
	7	2.2	1.48	1.02			
	8	1.8	1.34	1.02			
	7	1.9	1.37	1.02			
	6	1.9	1.37	1.02			
	5	2.2	1.48	1.02			
	4	2.2	1.48	1.02			
	3	2.2	1.48	1.02			
	2	2.2	1.48	1.02			
	1	1.6	1.26	1.02			

PORT	POINT	AP Inch H <sub>2</sub> O	√AP	(P <sub>s</sub> ) in. Hg	± θ	Pilots reversed for Negative Flow?	√AP · COS θ
A	1	1.6	1.26	1.02			
	2	1.9	1.37	1.02			
	3	1.8	1.34	1.02			
	4	1.9	1.37	1.02			
	5	2.2	1.48	1.02			
	6	2.2	1.48	1.02			
	7	2.3	1.52	1.02			
	8	2.4	1.55	1.02			
B	9	1.5	1.22	1.02			
	2	1.1	1.05	1.02			
	3	2.2	1.48	1.02			
	4	2.2	1.48	1.02			
	5	2.2	1.48	1.02			
	6	2.2	1.48	1.02			
	7	2.2	1.48	1.02			
	8	1.8	1.34	1.02			
	7	1.9	1.37	1.02			
	6	1.9	1.37	1.02			
	5	2.2	1.48	1.02			
	4	2.2	1.48	1.02			
	3	2.2	1.48	1.02			
	2	2.2	1.48	1.02			
	1	1.6	1.26	1.02			

\* Avg. of absolute values  
including zeroes

Absolute Gas Temperature, T<sub>ST</sub> = T<sub>s</sub> + 460°

Absolute Gas Pressure, P<sub>s</sub> = P<sub>b</sub> + P<sub>g</sub> / 13.6 =

Gas Velocity, V<sub>s</sub> = (85.49) C<sub>d</sub> (√AP · COS θ) avg √(P<sub>s</sub> / T<sub>ST</sub> avg) M<sup>W</sup> / P<sub>s</sub> ft/sec

Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = ACRM

Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub> (P<sub>s</sub> / 14.7) (T<sub>ST</sub> / 528) (29.92 / 100) (100 - % H<sub>2</sub>O) = DSCFM

PLANT \_\_\_\_\_  
DATE 12/14/95  
LOCATION 1400  
STACK DIMENSIONS \_\_\_\_\_  
AREA \_\_\_\_\_ ft<sup>2</sup>  
BAROMETRIC PRESSURE, P<sub>b</sub> = \_\_\_\_\_ in. Hg  
STACK STATIC PRESSURE, P<sub>g</sub> = ± \_\_\_\_\_ in. H<sub>2</sub>O  
STACK GAS MOLECULAR WEIGHT (wet), M<sub>w</sub> \_\_\_\_\_  
STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = \_\_\_\_\_  
PILOT NO. \_\_\_\_\_  
TESTER \_\_\_\_\_

**SCHMATIC OF TRAVERSE POINT LOCATION**

+ ☉ Clockwise  
- ☉ Counterclockwise  
Cyclonic Flow Angle

POINT	AP Inch H <sub>2</sub> O	√P (ft)	± ☉	Pitots reversed for Negative Flow?	√P · COS ☉
1	1.4	100			
2	1.8	101			
3	1.9	102			
4	1.8	103			
5	1.9	104			
6	2.0	105			
7	2.1	105			
8	2.2	105			
1	1.6	100			
2	2.15	101			
3	2.3	103			
4	2.3	104			
5	2.2	104			
6	2.0	104			
7	1.7	105			
8	1.7	105			

\*AVG. of absolute values  
including zeroes

Absolute Gas Temperature, T<sub>st</sub> = T<sub>s</sub> + 460°  
Absolute Gas Pressure, P<sub>s</sub> = P<sub>b</sub> + P<sub>g</sub>/13.6 = \_\_\_\_\_  
Gas Velocity, V<sub>s</sub> = (85.49) C<sub>p</sub> (√P<sub>g</sub> · COS ☉) AVG  $\sqrt{\frac{T_{st}}{P_s} \frac{M_w}{V_s}}$  ft/sec

Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = \_\_\_\_\_  
Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub>  $\left(\frac{P_s}{P_{st}}\right) \left(\frac{T_{st}}{T_{std}}\right) \left(\frac{100}{100 - \% H_2O}\right)$  ACFM  
DSCFM = \_\_\_\_\_



PLANT LP  
 DATE 12-14-95  
 LOCATION DO/PT  
 STACK DIMENSIONS 73 1/4 AREA ft<sup>2</sup>  
 BAROMETRIC PRESSURE, P<sub>b</sub> = 30.02 in. Hg  
 STACK STATIC PRESSURE, P<sub>g</sub> = -0.42 in. H<sub>2</sub>O  
 STACK GAS MOLECULAR WEIGHT (Wet), M<sub>w</sub> \_\_\_\_\_  
 STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = \_\_\_\_\_  
 PILOT NO. \_\_\_\_\_  
 TESTER \_\_\_\_\_

SCHMATIC OF TRAVERSE POINT LOCATION  
 + θ Clockwise  
 - θ Counterclockwise  
 Cylonic Flow Angle

PORT	POINT	AP Inch H <sub>2</sub> O	√AP	T <sub>s</sub> (°F)	± θ	Pilots reversed for Negative Flow?	√AP · COS θ
------	-------	-----------------------------	-----	---------------------	-----	--	-------------

A	1	0.46		220			
	2	0.55		233			
	3	0.55		233			
	4	0.60		234			
5	5	0.60		236			
	6	0.60		236			
	7	0.61		230			
	8	0.65		236			
	1	0.42		227			
	2	0.45		227			
	3	0.57		220			
	4	0.59		220			
	5	1.01		184			
	6	0.62		236			
	7	0.67		233			
	8	0.65		233			
	Average						
				T <sub>s</sub> = 220°F			
				T <sub>st</sub> = 642°R			

\*Avg. of absolute values including zeroes

Absolute Gas Temperature, T<sub>st</sub> = T<sub>s</sub> + 460°  
 Absolute Gas Pressure, P<sub>s</sub> = P<sub>b</sub> + P<sub>g</sub> / 13.6 = 30.01  
 Gas Velocity, V<sub>s</sub> = (85.49) C<sub>p</sub> (√ΔP · COS θ) AVG √(T<sub>st</sub> / P<sub>s</sub> M<sub>w</sub>) = 48.60 ft/sec  
 Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = 1694.3 ACFM  
 Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub> = 7511 DSCFM  
 DSCFM = 7555

PLANT LP  
DATE 12/14/95  
LOCATION OUTLET  
STACK DIMENSIONS 77 1/4 AREA ft<sup>2</sup>  
BAROMETRIC PRESSURE,  $P_b =$  30.02 in. Hg  
STACK STATIC PRESSURE,  $P_g =$  -0.12 in. H<sub>2</sub>O  
STACK GAS MOLECULAR WEIGHT (Wet),  $M_w$  25.9  
STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = 10  
PILOT NO. \_\_\_\_\_  
TESTER \_\_\_\_\_

SCHMATIC OF TRAVERSE POINT LOCATION  
+ @ Clockwise  
- @ Counterclockwise  
Cyclonic Flow Angle

PORT	POINT	AP Inch H <sub>2</sub> O	$\sqrt{AP}$	$T_s$ (°F)	± @	Pitots reversed for Negative Flow?	$\sqrt{AP} \cdot \cos \theta$
A	1	0.44		230			
	2	0.55		231			
	3	0.55		232			
	4	0.60		230			
	5	0.60		231			
	6	0.61		235			
	7	0.61		236			
B	8	0.65		237			
	1	0.42		230			
	2	0.93		231			
	3	0.45		232			
	4	0.57		234			
	5	0.57		235			
	6	0.61		231			
	7	0.67		231			
	8	0.66		225			

\*Ave. of absolute values  
including zeroes

Absolute Gas Temperature,  $T_{st} = T_s + 460$   
 Absolute Gas Pressure,  $P_s = P_b + P_g / 13.6 = 10.01$   
 Gas Velocity,  $V_s = (85.49) C_d (\sqrt{AP \cdot \cos \theta})_{avg} \sqrt{\frac{T_{st}}{P_s} \frac{M_w}{M}}$  = 48.25 ft/sec  
 Actual Gas Flowrate,  $Q_a = (V_s)(A) = 9.862$  ACFM  
 Standard Gas Flowrate,  $Q_{std} = Q_a \left( \frac{5280 R}{P_s} \right) \left( \frac{29.92}{P_s} \right) \left( \frac{100}{100 - \% H_2O} \right) = 7513$  DSCFM

PLANT \_\_\_\_\_  
 DATE 12/14/95  
 LOCATION PART 1  
 STACK DIMENSIONS AREA 7.714 ft<sup>2</sup>  
 BARROMETRIC PRESSURE, p<sub>b</sub> = 30.02 in. Hg  
 STACK STATIC PRESSURE, p<sub>g</sub> = -0.42 in. H<sub>2</sub>O  
 STACK GAS MOLECULAR WEIGHT (Wet), M<sub>w</sub> 28.9  
 STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = 10  
 PILOT NO. Cp = 0.84  
 TESTER \_\_\_\_\_

SCHMATIC OF TRAVERSE POINT LOCATION  
 + θ Clockwise  
 - θ Counterclockwise  
 Cyclonic Flow Angle

PORT	POINT	AP Inch H <sub>2</sub> O	√VAP	T <sub>s</sub> (°F)	± θ	Pilots reversed for Negative Flow?	√AP · CDS θ
A	1	0.47	0.54	230			
	2	0.54	0.54	231			
	3	0.54	0.54	231			
	4	0.54	0.54	231			
	5	0.60	0.60	231			
	6	0.61	0.61	232			
	7	0.62	0.62	233			
	8	0.61	0.61	233			
	5	0.72	0.72	233			
	2	0.49	0.49	236			
B	3	0.49	0.49	236			
	4	0.56	0.56	236			
	5	0.60	0.60	236			
	6	0.61	0.61	237			
	7	0.66	0.66	237			
	8	0.66	0.66	237			
	Average						
	T <sub>s</sub> = OF						
	T <sub>SI</sub> = OR						

\*Avg. of absolute values  
 including zeroes

Absolute Gas Temperature, T<sub>SI</sub> = T<sub>s</sub> + 460°  
 Absolute Gas Pressure, p<sub>s</sub> = p<sub>b</sub> + p<sub>g</sub>/13.6 = \_\_\_\_\_ ft/sec  
 Gas Velocity, V<sub>s</sub> = (85.49) C<sub>p</sub> (√AP · CDS θ) AVG  
 Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = \_\_\_\_\_ ACFM  
 Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub> (P<sub>s</sub> / 14.7) (T<sub>SI</sub> / 528) (100 / (100 - % H<sub>2</sub>O)) = \_\_\_\_\_ DSCFM

PLANT LI  
 DATE 12/19/85  
 LOCATION Outlet  
 STACK DIMENSIONS AREA 14.00 ft<sup>2</sup>  
 BAROMETRIC PRESSURE, P<sub>b</sub> = \_\_\_\_\_ in. Hg  
 STACK STATIC PRESSURE, P<sub>g</sub> = ± \_\_\_\_\_ in. H<sub>2</sub>O  
 STACK GAS MOLECULAR WEIGHT (wet), M<sub>w</sub> \_\_\_\_\_  
 STACK GAS MOISTURE CONTENT, % H<sub>2</sub>O = \_\_\_\_\_  
 PILOT NO. \_\_\_\_\_  
 TESTER \_\_\_\_\_

SCHMATIC OF TRAVERSE POINT LOCATION  
 + θ Clockwise  
 - θ Counterclockwise  
 Cylonic Flow Angle

PORT	POINT	ΔP Inch H <sub>2</sub> O	√AP	T <sub>S</sub> (F)	± θ	Pitot's reversed for Negative Flow?	√AP · COS θ
	1	0.45		232			
	2	0.47		230			
	3	0.66		230			
	4	0.66		233			
	5	0.67		230			
	6	0.67		233			
	7	0.67		237			
	8	0.7		230			
	9	0.60		232			
	2	0.52		232			
	3	0.63		248			
	4	0.69		241			
	5	0.60		241			
	7	0.62		241			
	7	0.59		241			
	8	0.60		241			
	Average						
				T <sub>ST</sub> = °R			
				T <sub>ST</sub> = °F	*		

\*Avg. of absolute values  
including zeroes

Absolute Gas Temperature, T<sub>ST</sub> = T<sub>s</sub> + 460°

Absolute Gas Pressure, P<sub>s</sub> = P<sub>b</sub> + P<sub>g</sub>/13.6

Gas Velocity, V<sub>s</sub> = (85.49) C<sub>p</sub> √(ΔP / (V<sub>AP</sub> · COS θ))

$$C_p = \frac{\sqrt{\frac{T_{ST}}{T_{ST, AVG}}}}{M_s} \frac{p_s}{p_s M_s}$$

Actual Gas Flowrate, Q<sub>a</sub> = (V<sub>s</sub>) (60) (A) = \_\_\_\_\_

Standard Gas Flowrate, Q<sub>std</sub> = Q<sub>a</sub> (P<sub>s</sub>) (T<sub>ST</sub>) (29.92) (100 - % H<sub>2</sub>O) / (100) \_\_\_\_\_

DSCFM

T-1 Inlet

3171

Refer

after

3184

13

Inlet

T-2

3126

Refer

after

3139

13

Inlet

T-3

3109

Refer

after

3123

14

Outlet

3187

3207

20

Outlet

3185

3205

20

Outlet

3113

3130

23

**TRC Environmental Corporation**  
CEM Data Sheet

Firm: L Pacific  
 Location: Houllon, ME  
 Tester: S. Paterson  
 Test No.: Inlet-1  
 Sample Loc.: RTO Inlet Duct  
 Date: December 14, 1995  
 TIME: 1035-1055

Ambient Temp, deg. F = 10  
 MEL Temp, deg. F = 70  
 Bar. Pressure, in Hg = 30.28  
 Vacuum Gauge = 10  
 Pressure Gauge =  
 % Moisture =

Calibration Gases			
Mid Cal	High Cal	Mid	High
9.1	20.8	ALM037884	ALM057653
142	451	ALM010642	AAL 20965
49.5	88.6	ALM43797	ALM43127

	Calibration Data				Emissions Summary				
	Initial Values		Final Values						
O <sub>2</sub>	Zero	0.1	0.0	0.14	0.3	0.3	25	20.8	20.8
	Upscale	20.9	20.8	20.78	-0.5	0.1	%	-	-
CO <sub>2</sub>	Zero		0.0		0.0	0.0	20	-	ERR
	Upscale		0.0		0.0	0.0		-	-
CO	Zero	0.3	0.6	-5.5	-1.2	-1.2	500	13.6	16.3
	Upscale	451.8	448.3	437.3	-2.9	-2.2			
SO <sub>2</sub>	Zero		0.0		0.0	0.0	1000	-	ERR
	Upscale		0.0		0.0	0.0		-	-
NOx	Zero	0.2	0.9	1.5	1.3	0.6		3.0	1.8
	Upscale	89.2	89.2	90.8	1.6	1.6	100	-	-
THC	Zero		0		0	0	100	-	ERR
	Upscale		0		0	0		-	-
		LIMITS							
		+/- 5%		+/- 5%		+/- 3%		+/- 2%	

Comments:  
 NOx (lb/hr) = K x ppm x MMW x Flow  
 NOx (lb/hr) = 0.19  
 CO (lb/hr) = K x ppm x MMW x Flow  
 CO (lb/hr) = 0.76  
 K = 2.59E-09  
 MMW for NOx = 46.01 g/gmol  
 Flow (scfm) = 15.028  
 MMW for CO = 20.00 g/gmol

	ZERO		MID	HIGH	
	ZERO Cal Gas Analyzer Response	Analyzer Calib. Error		Cal. Gas Analyzer Response	Analyzer Calib. Error
O <sub>2</sub>	0.1	0.2	9.1	0.2	20.9
CO <sub>2</sub>		0.0		0.0	0.0
CO	0.3	0.1	140.7	-0.3	451.8
SO <sub>2</sub>		0.0		0.0	0.0
NOx	0.2	0.2	47.6	-1.9	89.2
THC		0.0		0.0	0.0
		LIMIT		+/- 2%	

**TRC Environmental Corporation**  
CEM Data Sheet

Firm: L Pacific  
Location: Houston, ME  
Tester: S. Paterson  
Test No.: Inlet 2  
Sample Loc.: RTO Inlet Duct  
Date: December 14, 1995  
TIME: 12:00 - 12:20

Ambient Temp, deg. F = 10  
MEL Temp, deg. F = 70  
Bar. Pressure, in Hg = 30.28  
Vacuum Gauge = 10  
Pressure Gauge =  
% Moisture =

Calibration Gases			
	Mid Cal	High Cal	Tank ID
O <sub>2</sub>	9.1	20.8	ALM037894 ALM057653
CO <sub>2</sub>			
CO	142	451	ALM010642 AAL 20965
SO <sub>2</sub>			
NOx	49.5	88.6	ALM43797 ALM43127
THC			

	Calibration Data				Emissions Summary			
	Initial Values	Final Values	Drift	Analyzer Units & Range		Measured Average Gas Conc.	Corrected Effluent Gas Conc.	
O <sub>2</sub>	Zero Response	0.14	0.3	0.4	0.1	-	-	
	Upscale	20.9	-0.5	-0.7	-0.2	25	20.8	20.9
CO <sub>2</sub>	Zero		0.0	0.0	0.0			
	Upscale		0.0	0.0	0.0	20		ERR
CO	Zero	0.3	-1.2	-2.1	-0.9	500	-0.8	7.1
	Upscale	451.8	-2.9	-4.1	-1.2	500		
SO <sub>2</sub>	Zero		0.0	0.0	0.0	1000		ERR
	Upscale		0.0	0.0	0.0	1000		ERR
NOx	Zero	0.2	1.3	2.0	0.7	100	4.0	2.1
	Upscale	89.2	1.6	2.7	1.1	100		
THC	Zero		0	0	0	ppm		
	Upscale		0	0	0	100		ERR
		LIMITS						
				+/- 5%		+/- 3%		

Comments:  
NOx (lb/hr) = K x ppm x MW x Flow  
NOx (lb/hr) = 0.23  
CO (lb/hr) = K x ppm x MW x Flow  
CO (lb/hr) = 0.33  
K = 2.59E-09  
MW for NOx = 46.01 g/gmol  
Flow (dscfm) = 15,091  
MW for CO = 20.00 g/gmol

	ZERO		MID	HIGH	
	Cal Gas Analyzer Response	Analyzer Calib. Error		Cal Gas Analyzer Response	Analyzer Calib. Error
O <sub>2</sub>	0.1	0.2	9.1	0.2	20.9
CO <sub>2</sub>		0.0		0.0	
CO	0.3	0.1	140.7	-0.3	451.8
SO <sub>2</sub>		0.0		0.0	
NOx	0.2	0.2	47.6	-1.9	89.2
THC		0.0		0.0	
		LIMIT		+/- 2%	
				+/- 2%	

**TRC Environmental Corporation**  
CEM Data Sheet

Firm: L Pacific  
 Location: Houllon, ME  
 Tester: S. Paterson  
 Test No.: Inlet-3  
 Sample Loc.: RTO Inlet Duct  
 Date: December 14, 1995  
 TIME: 13:38 - 13:58

Ambient Temp, deg. F = 10  
 MEL Temp, deg. F = 70  
 Bar. Pressure, in Hg = 30.28  
 Vacuum Gauge = 10  
 Pressure Gauge =  
 % Moisture =

Calibration Gases				
Mid Cal	High Cal	Mid	High	Tank ID
O <sub>2</sub>	9.1	20.8	ALM037884	ALM057653
CO <sub>2</sub>	142	451	ALM010642	PAAL 20965
CO	49.5	88.6	ALM43797	ALM43127
SO <sub>2</sub>				
NOx				
THC				

	Calibration Data				Emissions Summary		
	Initial Values		Final Values		Analyzer Units & Range	Measured Average Gas Conc.	Corrected Effluent Gas Conc.
O <sub>2</sub>	Zero	0.1	0.2	0.4	0.3	-0.1	-
	Upscale	20.9	20.7	-0.7	20.68	-0.2	20.7
CO <sub>2</sub>	Zero			0.0	0.0	0.0	-
	Upscale			0.0	0.0	0.0	-
CO	Zero	0.3	1.4	0.2	-1.7	-0.4	-
	Upscale	450.7	448.3	-0.5	442.3	-1.7	5.9
SO <sub>2</sub>	Zero			0.0	0.0	0.0	-
	Upscale			0.0	0.0	0.0	-
NOx	Zero	0.2	2.2	2.0	2.2	0.0	-
	Upscale	89.2	91.9	2.7	91.8	-0.1	3.1
THC	Zero			0	0	0	-
	Upscale			0		0	-
		LIMITS				ERR	
		+/- 5%				+/- 3%	

Comments:  
 NOx (lb/hr) = K x ppm x MW x Flow  
 NOx (lb/hr) = 0.10  
 CO (lb/hr) = K x ppm x MW x Flow  
 CO (lb/hr) = 0.29  
 SO<sub>2</sub> (lb/hr) =  
 NOx (lb/hr) =  
 K = 2.59E-09  
 MW for NOx = 46.01 g/mol  
 Flow (dscfm) = 15,143  
 MW for CO = 20.00 g/mol

	ZERO		MID		HIGH		
	ZERO Cal. Gas Analyzer Response	Analyzer Calib. Error	MID Cal. Gas Analyzer Response	Analyzer Calib. Error	HIGH Cal. Gas Analyzer Response	Analyzer Calib. Error	
O <sub>2</sub>	0.1	0.2	9.1	0.2	20.9	0.4	
CO <sub>2</sub>	0.0	0.0		0.0		0.0	
CO	0.3	0.1	140.6	-0.3	450.7	-0.1	
SO <sub>2</sub>	0.0	0.0		0.0		0.0	
NOx	0.2	0.2	47.6	-1.9	89.2	0.6	
THC	0.0	0.0		0.0		0.0	
		LIMIT				+/- 2%	
		+/- 2%				+/- 2%	



**TRC Environmental Corporation**  
CEM Data Sheet

Firm: L Pacific  
Location: Houliou, ME  
Tester: S. Paterson  
Test No.: Outlet - 1  
Sample Loc.: RTO Stack  
Date: December 14, 1995  
TIME: 1100 - 1120

Ambient Temp, deg. F = 10  
MEL Temp, deg. F = 70  
Bar. Pressure, in Hg = 30.28  
Vacuum Gauge = 10  
Pressure Gauge =  
% Moisture =

O<sub>2</sub>  
CO<sub>2</sub>  
CO  
SO<sub>2</sub>  
NOX  
THC

Calibration Gases				Tank ID	
Mid Cal	High Cal	Mid	High	Mid	High
9.1	20.8	ALM037884	ALM057653		
142	451	ALM010642	AAL 20965		
49.5	88.6	ALM43797	ALM43127		

	Calibration Data				Analyzer Units & Range	Emissions Summary	
	Initial Values	Final Values	System Cal Bias % of Span	System Cal Response		Measured Average Gas Conc.	Corrected Effluent Gas Conc.
O <sub>2</sub>	Zero Upscale	0.1 20.9	0.3 -1.0	0.18 20.56	% 25	- 20.1	- 20.3
CO <sub>2</sub>	Zero Upscale	0.1 20.7	0.0 0.0	0.0 0.0	% 20	- -	- ERR
CO	Zero Upscale	0.3 451.8	-0.1 -1.6	-4.2 433.8	ppm 500	- 13.9	- 16.5
SO <sub>2</sub>	Zero Upscale	0.2 89.2	0.0 -0.9	0.0 89.8	ppm 1000	- -	- ERR
NOX	Zero Upscale	0.2 89.2	0.6 -0.9	1.8 89.8	ppm 100	- 17.0	- 15.9
THC	Zero Upscale	0 -	0 -	0 -	ppm 100	- -	- ERR
		LIMITS					
		+/- 5%		+/- 3%			

Comments:  
NOX (lb/hr) = K x ppm x MW x Flow  
NOX (lb/hr) = 0.86  
CO (lb/hr) = K x ppm x MW x Flow  
CO (lb/hr) = 0.39  
K = 2.59E-09  
MW for NOX = 46.01 g/mol  
Flow (dscfm) = 7.555  
MW for CO = 20.00 g/mol

	ZERO		MID		HIGH		
	Cal. Gas Analyzer Response	Analyzer Calib. Error	Cal. Gas Analyzer Response	Analyzer Calib. Error	Cal. Gas Analyzer Response	Analyzer Calib. Error	
O <sub>2</sub>	0.1	0.2	9.1	0.2	20.9	0.4	
CO <sub>2</sub>	0.0	0.0	0.0	0.0	0.0	0.0	
CO	0.3	0.1	140.7	-0.3	451.8	0.2	
SO <sub>2</sub>	0.0	0.0	0.0	0.0	0.0	0.0	
NOX	0.2	0.2	47.6	-1.9	89.2	0.6	
THC	0.0	0.0	0.0	0.0	0.0	0.0	
		LIMIT					
		+/- 2%		+/- 2%		+/- 2%	

**TRC Environmental Corporation**  
CEM Data Sheet

Firm: L Pacific  
 Location: Houilton, ME  
 Tester: S. Paterson  
 Test No.: Outlet 2  
 Sample Loc.: RTO Stack  
 Date: December 14, 1995.  
 TIME: 12:25 - 12:45

Ambient Temp, deg. F = 10  
 MEL Temp, deg. F = 70  
 Bar. Pressure, in Hg = 30.28  
 Vacuum Gauge = 10  
 Pressure Gauge =  
 % Moisture =

Calibration Gases			
Mid Cal	High Cal	Mid	Tank ID High
9.1	20.8	ALM037884	ALM057653
142	451	ALM010642	AAL 20965
49.5	88.6	ALM43797	ALM43127

	Initial Values			Final Values			Emissions Summary
	(Rack) Analyzer Cal. Response	System Cal. Response	System Cal. Bias % of Span	System Cal. Response	System Cal. Bias % of Span	Drift % of Span	
O <sub>2</sub>	0.1	0.18	0.5	0.17	0.4	-0.0	
CO <sub>2</sub>	20.9	20.56	-1.4	20.59	-1.3	0.1	25 20.2
CO	Upscale	Upscale	0.0	Upscale	0.0	0.0	20
SO <sub>2</sub>	0.3	-4.2	-0.9	-9.6	-2.0	-1.1	500 8.4
NOx	Upscale	433.8	-3.6	425.7	-5.2	-1.6	1000 ERR
THC	Upscale	0.2	0.0	2.3	0.0	0.0	100 17.9
	Upscale	89.2	0.6	90.2	1.0	0.4	100 ERR
	Upscale		0		0	0	100 ERR
	Upscale		0		0	0	ERR

EMITS: +/-5%

EMITS: +/-3%

Comments:  
 NOx (lb/hr) = K x ppm x MW x Flow  
 NOx (lb/hr) = 0.86  
 CO (lb/hr) = K x ppm x MW x Flow  
 CO (lb/hr) = 0.37  
 K = 2.59E-09  
 MW for NOx = 46.01 g/gmol  
 Flow (dsctm) = 7.506  
 MW for CO = 20.00 g/gmol

	ZERO		MID		HIGH	
	ZERO Cal. Gas Analyzer Response	Analyzer Calib. Error	MID Cal. Gas Analyzer Response	Analyzer Calib. Error	HIGH Cal. Gas Analyzer Response	Analyzer Calib. Error
O <sub>2</sub>	0.1	0.2	9.1	0.2	20.9	0.4
CO <sub>2</sub>	0.1	0.0		0.0		0.0
CO	0.3	0.1	140.7	-0.3	451.8	0.2
SO <sub>2</sub>	0.2	0.0	47.6	0.0		0.0
NOx	0.2	0.2		-1.9	89.2	0.6
THC	0.0	0.0		0.0		0.0

EMITS: +/-2%

EMITS: +/-2%

EMITS: +/-2%

TRC Environmental Corporation  
CEM Data Sheet

Firm: L Pacific  
 Location: Houliou, ME  
 Tester: S. Paterson  
 Test No.: Outlet -3  
 Sample Loc.: RTO Stack  
 Date: December 14, 1995  
 TIME: 14:03 - 14:23

Ambient Temp, deg. F = 10  
 MEL Temp, deg. F = 70  
 Bar. Pressure, in Hg = 30.28  
 Vacuum Gauge = 10  
 Pressure Gauge =  
 % Moisture =

Calibration Gases			
	High Cal	Mid	Tank ID High
O <sub>2</sub>	9.1	20.8	ALM037884 ALM057653
CO <sub>2</sub>	142	451	ALM010642 AAL 20965
CO	49.5	88.6	ALM43797 ALM43127
SO <sub>2</sub>			
NOX			
THC			

	Calibration Data				Emissions Summary			
	Initial Values		Final Values					
(Rack) Analyzer Cal	System Cal Response	System Cal Bias % of Span	System Cal Response	System Cal Bias % of Span	Drift % of Span	Analyzer Units & Range	Measured Average Gas Conc.	Corrected Effluent Gas Conc.
O <sub>2</sub> Zero	0.1	0.2	0.4	0.18	0.5	%	-	-
Upscale	20.9	20.6	-1.3	20.57	-1.4	25	20.1	20.4
CO <sub>2</sub> Zero			0.0		0.0	%	-	-
Upscale			0.0		0.0	20	-	ERR
CO Zero	0.0	1.6	0.3	-0.2	-0.0	ppm	-	-
Upscale	450.7	447.5	-0.6	437.4	-2.7	500	17.0	16.6
SO <sub>2</sub> Zero			0.0		0.0	ppm	-	-
Upscale			0.0		0.0	1000	-	ERR
NOX Zero	0.2	2.3	2.1	2.4	2.2	ppm	-	-
Upscale	89.2	90.2	1.0	91.2	2.0	100	17.9	15.6
THC Zero			0		0	ppm	-	-
Upscale			0		0	100	-	ERR

LIMITS +/- 5%

LIMITS +/- 5% +/- 3%

ZERO	MID	HIGH
Cal Gas Analyzer Response	Cal Gas Analyzer Response	Cal Gas Analyzer Response
Analyzer Calib. Error	Analyzer Calib. Error	Analyzer Calib. Error
O <sub>2</sub> 0.1	9.1	20.9
CO <sub>2</sub> 0.0	140.6	450.7
CO 0.0	47.6	89.2
SO <sub>2</sub> 0.2		
NOX 0.0		
THC 0.0		

Comments:  
 NOX (lb/hr) = K x ppm x MW x Flow  
 NOX (lb/hr) = 0.85  
 CO (lb/hr) = K x ppm x MW x Flow  
 CO (lb/hr) = 0.39  
 K = 2.59E-09  
 MW for NOX = 46.01 g/gmol  
 Flow (dsctm) = 7.615  
 MW for CO = 20.00 g/gmol

LIMIT +/- 2%

LIMIT +/- 2%

LIMIT +/- 2%

	0	10	20	30	40	50	60	70	80	90	100
MANUAL											
DP	0.04%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%
CO	85PPM	86PPM	86PPM	86PPM	86PPM	86PPM	86PPM	86PPM	86PPM	86PPM	86PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.06%	0.06%	0.06%	0.06%	0.06%	0.06%	0.06%	0.06%	0.06%	0.06%	0.06%
CO	90PPM	90PPM	90PPM	90PPM	90PPM	90PPM	90PPM	90PPM	90PPM	90PPM	90PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.08%	0.08%	0.08%	0.08%	0.08%	0.08%	0.08%	0.08%	0.08%	0.08%	0.08%
CO	96PPM	96PPM	96PPM	96PPM	96PPM	96PPM	96PPM	96PPM	96PPM	96PPM	96PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.10%	0.10%	0.10%	0.10%	0.10%	0.10%	0.10%	0.10%	0.10%	0.10%	0.10%
CO	102PPM	102PPM	102PPM	102PPM	102PPM	102PPM	102PPM	102PPM	102PPM	102PPM	102PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.12%	0.12%	0.12%	0.12%	0.12%	0.12%	0.12%	0.12%	0.12%	0.12%	0.12%
CO	108PPM	108PPM	108PPM	108PPM	108PPM	108PPM	108PPM	108PPM	108PPM	108PPM	108PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.14%	0.14%	0.14%	0.14%	0.14%	0.14%	0.14%	0.14%	0.14%	0.14%	0.14%
CO	114PPM	114PPM	114PPM	114PPM	114PPM	114PPM	114PPM	114PPM	114PPM	114PPM	114PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.16%	0.16%	0.16%	0.16%	0.16%	0.16%	0.16%	0.16%	0.16%	0.16%	0.16%
CO	120PPM	120PPM	120PPM	120PPM	120PPM	120PPM	120PPM	120PPM	120PPM	120PPM	120PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.18%	0.18%	0.18%	0.18%	0.18%	0.18%	0.18%	0.18%	0.18%	0.18%	0.18%
CO	126PPM	126PPM	126PPM	126PPM	126PPM	126PPM	126PPM	126PPM	126PPM	126PPM	126PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w
MANUAL											
DP	0.20%	0.20%	0.20%	0.20%	0.20%	0.20%	0.20%	0.20%	0.20%	0.20%	0.20%
CO	132PPM	132PPM	132PPM	132PPM	132PPM	132PPM	132PPM	132PPM	132PPM	132PPM	132PPM
NOx	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w	20w

System Cal Filter

NOx span

Zero

CO mid

NOx mid

O<sub>2</sub> mid

CO span

NOx span

O<sub>2</sub> span

Zero

Booster machine

Back Cal

12/19/97

MANUAL	10	Dec 14 95	09:29	44.40ppm	NOx 50	60.1ppm	70.5m	80.45%	90	100
D2	10	14% 20	00	30	44.40ppm	NOx 5m	4.72%	245ppm		
CD 5m		43ppm								
NDx 20m										

MANUAL	10	Dec 14 95	08:27	88ppm	NOx 50	7.21%	287ppm			
D2	10	14% 20	00	30	88ppm	NOx 5m	2.93%	43ppm		
CD 5m		11ppm								
NDx 20m		63ppm								

MANUAL	10	Dec 14 95	08:26	11ppm	NOx 50	0.13%	392ppm			
D2	10	11% 20	00	30	11ppm	NOx 5m	2.03%	47ppm		
CD 5m		2ppm								
NDx 20m		31ppm								

MANUAL	10	Dec 14 95	08:24	28ppm	NOx 50	2.42%	367ppm			
D2	10	10% 20	00	30	28ppm	NOx 5m	0.94%	1ppm		
CD 5m		241ppm								
NDx 20m		1ppm								

Suspension for coat rack

MANUAL	10	Dec 14 95	08:14	41.40ppm	NOx 50	60.1ppm	70.5m	80.52%	90	100
D2	10	10% 20	00	30	41.40ppm	NOx 5m	8.17%	52ppm		
CD 5m		34ppm								
NDx 20m		93ppm								

TRE ENVIRONMENTAL

MANUAL	10	Dec 14 95	08:11	11ppm	NOx 50	20.41%	35ppm			
D2	10	14% 20	00	30	11ppm	NOx 5m	8.54%	50ppm		
CD 5m		11ppm								
NDx 20m		53ppm								

MANUAL	10	Dec 14 95	08:10	42.40ppm	NOx 50	8.94%	37ppm			
D2	10	13% 20	00	30	42.40ppm	NOx 5m	3.41%	1ppm		
CD 5m		0ppm								
NDx 20m		51ppm								

NOx span

O2 span

CO span

25.00

500 ppm

Dec. 14 1945

MANUAL 10 09:53  
 02 0.14% 10 09 30  
 CD 5W 113PPM NOX 5W  
 NOX 20W 27PPM

MANUAL 10 09:58  
 02 0.13% 10 09 30  
 CD 5W 122PPM NOX 5W  
 NOX 20W 30PPM

MANUAL 10 09:56  
 02 0.14% 20 09 30  
 CD 5W 112PPM NOX 5W  
 NOX 20W 34PPM

MANUAL 10 09:54  
 02 0.13% 10 09 30  
 CD 5W 127PPM NOX 5W  
 NOX 20W 40PPM

MANUAL 10 09:49  
 02 0.14% 10 09 30  
 CD 5W 110PPM NOX 5W  
 NOX 20W 41PPM

MANUAL 10 09:48  
 02 0.15% 10 09 30  
 CD 5W 110PPM NOX 5W  
 NOX 20W 40PPM

MANUAL 10 09:47  
 02 0.15% 10 09 30  
 CD 5W 110PPM NOX 5W  
 NOX 20W 38PPM

MANUAL 10 09:45  
 02 0.15% 10 09 30  
 CD 5W 110PPM NOX 5W  
 NOX 20W 38PPM

MANUAL 10 09:29  
 02 0.14% 20 09 30  
 CD 5W 114PPM NOX 5W  
 NOX 20W 49PPM

MANUAL 10 09:29  
 02 0.14% 20 09 30  
 CD 5W 114PPM NOX 5W  
 NOX 20W 49PPM

Time	Temp	Humidity	Wind	Pressure	CO2	CO	NOx	SO2	PM10	PM2.5
00:00	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:05	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:10	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:15	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:20	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:25	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:30	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:35	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:40	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:45	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:50	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
00:55	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:00	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:05	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:10	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:15	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:20	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:25	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:30	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:35	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:40	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:45	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:50	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
01:55	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00
02:00	10	100%	0	1013.25	0.08%	0.00	0.00	0.00	0.00	0.00

not  
5  
5

2000

SI

00  
span

00  
mid

02  
span

not  
span

not  
span

not  
span

not  
span

not  
span

not  
span

MANUAL	Dec. 14 95	10:21	443.04PPM	N0X	02 200m	1.09%	69ppm	100
D2	0.13%							
CD 5m	34ppm							
N0X 20m	240ppm							

CO  
5ppm

MANUAL	Dec. 14 95	10:25	-2.17PPM	N0X	02 200m	4.36%	49ppm	100
D2	20.65%							
CD 5m	0ppm							
N0X 20m	27ppm							

O2  
5ppm

MANUAL	Dec. 14 95	10:24	0.27PPM	N0X	02 200m	4.15%	54ppm	100
D2	0.13%							
CD 5m	0ppm							
N0X 20m	25ppm							

N2  
47A

MANUAL	Dec. 14 95	10:23	-0.28PPM	N0X	02 200m	0.13%	60ppm	100
D2	0.13%							
CD 5m	0ppm							
N0X 20m	23ppm							

2000

MANUAL	Dec. 14 95	10:19	0.98PPM	N0X	02 200m	3.2%	95ppm	100
D2	0.06%							
CD 5m	24ppm							
N0X 20m	30ppm							

15ppm  
5ppm

MANUAL	Dec. 14 95	10:17	443.38PPM	N0X	02 200m	0.09%	73ppm	100
D2	0.13%							
CD 5m	448ppm							
N0X 20m	26ppm							

CO  
5ppm

MANUAL	Dec. 14 95	10:16	-2.17PPM	N0X	02 200m	6.55%	0ppm	100
D2	20.76%							
CD 5m	0ppm							
N0X 20m	40ppm							


O2  
5ppm

MANUAL	Dec. 14 95	10:12	0.77PPM	N0X	02 200m	11.54%	11ppm	100
D2	1.13%							
CD 5m	1ppm							
N0X 20m	10							

CO  
5ppm

AN STOP CAL  
O2 10.1





closed

500.0 PPM  
1000 PPM

500.0 PPM


1000 PPM

500.0 PPM

1000 PPM

500.0 PPM

1000 PPM



MANUAL	Dec. 14 95	11:33	5	11:30	451	08PM	NOX	02 200m	11.80%	02 50m	62.9ppm
CD 50m	0.14%	NOX 50m	21PM	NOX	02 200m	11.80%	CD 200m	8.70%			
CD 50m	1.29	0.06PM	17PPM								
NDK 20m											

Summit of station cell

MANUAL	Dec. 14 95	11:30	451	08PM	NOX	02 200m	11.98%	02 50m	0.15%	02 50m	66.8ppm
CD 50m	0.17%	NOX 50m	21PM	NOX	02 200m	11.98%	CD 200m	0.15%			
CD 50m	43.5ppm	21PPM									
NDK 20m											

CO span

MANUAL	Dec. 14 95	11:28	6	5PM	NOX	02 200m	12.69%	02 50m	0.15%	02 50m	24.7ppm
CD 50m	20.96%	NOX 50m	5PM	NOX	02 200m	12.69%	CD 200m	0.15%			
CD 50m	0.5ppm	26PPM									
NDK 20m											

CO span

MANUAL	Dec. 14 95	11:27	4	4PM	NOX	02 200m	13.50%	02 50m	0.15%	02 50m	80.00%
CD 50m	0.17%	NOX 50m	4PM	NOX	02 200m	13.50%	CD 200m	0.15%			
CD 50m	3.8ppm	23PPM									
NDK 20m											

NO span

MANUAL	Dec. 14 95	11:25	34	3PM	NOX	02 200m	15.42%	02 50m	5.42%	02 50m	37.8ppm
CD 50m	0.18%	NOX 50m	3PM	NOX	02 200m	15.42%	CD 200m	5.42%			
CD 50m	37.5ppm	15PPM									
NDK 20m											

CO span

4000 ppm  
CO span

MANUAL	Dec. 14 95	11:20	13	3PM	NOX	02 200m	17.7ppm	02 50m	1.7ppm	02 50m	17.7ppm
CD 50m	0.18%	NOX 50m	3PM	NOX	02 200m	17.7ppm	CD 200m	1.7ppm			
CD 50m	13.5ppm	13.7ppm									
NDK 20m											

CO span



20 03x  
 CD 5mm  
 Dec. 14 12:10  
 -0.1ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 12:20  
 -0.5ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 12:30  
 -0.8ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 12:40  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 12:50  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 13:00  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 13:10  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 13:20  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 13:30  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 13:40  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 13:50  
 -0.9ppm  
 NOx 5mm  
 SPPM

20 03x  
 CD 5mm  
 Dec. 14 14:00  
 -0.9ppm  
 NOx 5mm  
 SPPM


400x  
 Jan 12-2

UB  
 5000  
 ppm


00  
 5000  
 ppm

NOx  
 5000  
 ppm

2000



CHALEL SYSTEM CAL



Time	CO (%)	NOx (ppm)	O2 (%)
0	0.17%	0.18%	20.53%
10	1.2%	2.3ppm	20.97ppm
50	13.68%	23.03ppm	-
100	-	-	20.97ppm

MAN	DEC	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.16%	NOX 5m	2.4ppm	0.2 20m	2.1ppm	CD 5m	2.29%	CD 20m	2.29%
NOX 20m	2.4ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.14%	NOX 5m	2.4ppm	0.2 20m	2.2ppm	CD 5m	4.30%	CD 20m	4.30%
NOX 20m	1.4ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.13%	NOX 5m	2.4ppm	0.2 20m	2.1ppm	CD 5m	5.18%	CD 20m	5.18%
NOX 20m	1.5ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.17%	NOX 5m	2.5ppm	0.2 20m	2.3ppm	CD 5m	9.96%	CD 20m	9.96%
NOX 20m	1.7ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	22.4ppm	NOX 5m	2.5ppm	0.2 20m	11.0ppm	CD 5m	42.5ppm	CD 20m	42.5ppm
NOX 20m	1.7ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.13%	NOX 5m	2.4ppm	0.2 20m	2.3ppm	CD 5m	9.46%	CD 20m	9.46%
NOX 20m	1.9ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.16%	NOX 5m	2.4ppm	0.2 20m	2.2ppm	CD 5m	9.93%	CD 20m	9.93%
NOX 20m	1.7ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.16%	NOX 5m	2.4ppm	0.2 20m	2.2ppm	CD 5m	11.84%	CD 20m	11.84%
NOX 20m	1.5ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.16%	NOX 5m	2.4ppm	0.2 20m	2.2ppm	CD 5m	10.41%	CD 20m	10.41%
NOX 20m	1.5ppm								
MANUAL	Dec. 14 95	CO	NOX	NOX	NOX	NOX	NOX	NOX	NOX
CD 5m	0.16%	NOX 5m	2.4ppm	0.2 20m	2.2ppm	CD 5m	10.41%	CD 20m	10.41%
NOX 20m	1.5ppm								

CO  
5ppm

CO  
9ppm

CO  
5ppm

CO  
5ppm


CO  
5ppm

CO  
5ppm

CO  
5ppm






CO  
5ppm

CO  
5ppm




*Shift out 101-3*

*Shift out 102-3*







NOX  
NOX Spikes  
2000

20 804	Dec. 14 13:38	6.5PPM	NDX 20	3.4PPM	60	70	80	90	100
200 794	Dec. 14 13:30	6.0PPM	NDX 50	3.2PPM	60	70	80	90	100

*Handwritten:* 5 ppm filter - 3

8 464	Dec. 14 13:18	165.7PPM	NDX 50	3.1PPM	60	70	80	90	100
-------	---------------	----------	--------	--------	----	----	----	----	-----

MANUAL	Dec. 14 95	13:14	447.8PPM	NDX	2.2PPM	60	70	80	90	100
D2	0.18%	CO	5.1PPM	NDX 200	5.98%	60	70	80	90	100
CD 50M	1.72-0PPM	NDX 50M	5.1PPM	NDX 200	5.98%	60	70	80	90	100
NDX 20M	2.8PPM									

MANUAL	Dec. 14 95	13:12	1.0PPM	NDX	2.1PPM	60	70	80	90	100
D2	0.21%	CO	5.8PPM	NDX 200	7.27%	60	70	80	90	100
CD 50M	9.0.2PPM	NDX 50M	5.8PPM	NDX 200	7.27%	60	70	80	90	100
NDX 20M	2.5PPM									

MANUAL	Dec. 14 95	13:09	447.8PPM	NDX	2.3PPM	60	70	80	90	100
D2	0.68%	CO	2.5PPM	NDX 200	4.80%	60	70	80	90	100
CD 50M	4.1.0PPM	NDX 50M	2.5PPM	NDX 200	4.80%	60	70	80	90	100
NDX 20M	2.5PPM									

MANUAL	Dec. 14 95	13:08	1.4PPM	NDX	2.1PPM	60	70	80	90	100
D2	0.68%	CO	2.6PPM	NDX 200	6.72%	60	70	80	90	100
CD 50M	84.7PPM	NDX 50M	2.6PPM	NDX 200	6.72%	60	70	80	90	100
NDX 20M	2.6PPM									

MANUAL	Dec. 14 95	13:05	1.4PPM	NDX	2.1PPM	60	70	80	90	100
D2	0.18%	CO	1.90.6PPM	NDX	2.1PPM	60	70	80	90	100
CD 50M	136.3PPM	NDX 50M	2.4PPM	NDX 200	2.29%	60	70	80	90	100
NDX 20M	2.4PPM									

MANUAL	Dec. 14 95	13:04	451.7PPM	NDX	2.2PPM	60	70	80	90	100
D2	0.14%	CO	1.30%	NDX	2.2PPM	60	70	80	90	100

TIRE ENVIRONMENTAL

*Handwritten:* 4 ppm

*Handwritten:* 2 ppm

*Handwritten:* 2 ppm

*Handwritten:* US wind

Appendix B

Analytical Data and Data Summaries

RTO Inlet  
Formaldehyde, NOx, and CO Emissions


TEST	*****	In-1	In-2	In-3
LOCATION	*****	RTO -Inlet	RTO -Inlet	RTO -Inlet
FIRM	*****	LP	LP	LP
TIME	*****	1035-1135	1200-1300	1338-1438
DATE	*****	12-14-95	12-14-95	12-14-95
PROJECT NO.	*****	19624	19624	19624
BAROMETRIC PRESSURE	in. Hg	30.02	30.02	30.02
STACK AREA	ft <sup>2</sup>	16.22	16.22	16.22
NOZZLE DIAMETER	in.			
SAMPLING TIME	min.	60	60	60
DRY GAS METER CAL FACTOR [Y]	*****	1.00	1.00	1.00
PITOT COEFFICIENT	*****	0.84	0.84	0.84
AVG. SQUARE DELTA P	in. H <sub>2</sub> O	1.382	1.390	1.395
AVG. DELTA H	in. H <sub>2</sub> O	1.88	1.88	1.88
AVG. METER TEMP.	oF	40	41	39
STATIC PRESSURE	in. H <sub>2</sub> O	-4.55	-4.65	-4.70
AVG. STACK TEMPERATURE	oF	102	104	104
SAMPLE VOLUME	ft <sup>3</sup>	42.66	41.51	43.67
WATER COLLECTED	ml	13.0	13.0	14.0
CO 2	%	0	0	0
O 2	%	20.8	20.9	20.8
NOx	ppm	1.8	2.1	0.9
CO	ppm	16.3	7.1	6.1
N 2	%	79.2	79.1	79.2
TOTAL FORMALDEHYDE CATCH	mg	9.25	9.96	12.212
SAMPLE VOLUME DRY	DSCF	45.41	44.10	46.57
MOISTURE	%	1.3	1.4	1.4
MOLECULAR WEIGHT OF STACK GAS	lb/lb-mole	28.69	28.69	28.68
STACK VELOCITY	FPM	4836	4875	4893
VOLUMETRIC FLOWRATE, ACTUAL	ACFM	78432	79065	79364
VOLUMETRIC FLOWRATE, STANDARD	SCFM	73109	73420	73688
VOLUMETRIC FLOWRATE, DRY STD.	DSCFM	72137	72415	72660
ISOKINETIC RATIO	%	ERR	ERR	ERR
FORMALDEHYDE EMISSION CONC	ppm	5.8680	6.5139	7.5622
FORMALDEHYDE EMISSION RATE	lb/hour	1.979	2.205	2.568
NOx EMISSION RATE	lb/hr	0.931	1.090	0.469
CO EMISSION RATE	lb/hr	5.129	2.243	1.934

RTO Outlet  
Formaldehyde, NOx, and CO Emissions

TEST	*****	out-1	out-2	out-3
LOCATION	*****	RTO-outlet	RTO-outlet	RTO-outlet
FIRM	*****	LP	LP	LP
TIME	*****	1035-1135	1200-1300	1338-1438
DATE	*****	12-14-95	12-14-95	12-14-95
PROJECT NO.	*****	19624	19624	19624
BAROMETRIC PRESSURE	in. Hg	30.02	30.02	30.02
STACK AREA	ft <sup>2</sup>	32.59	32.59	32.59
NOZZLE DIAMETER	in.			
SAMPLING TIME	min.	60	60	60
DRY GAS METER CAL FACTOR [Y]	*****	1.00	1.00	1.00
PITOT COEFFICIENT	*****	0.84	0.84	0.84
AVG. SQUARE DELTA P	in. H <sub>2</sub> O	0.756	0.751	0.763
AVG. DELTA H	in. H <sub>2</sub> O	1.75	1.75	1.75
AVG. METER TEMP.	°F	44	47	45
STATIC PRESSURE	in. H <sub>2</sub> O	-0.42	-0.42	-0.42
AVG. STACK TEMPERATURE	°F	232	234	235
SAMPLE VOLUME	ft <sup>3</sup>	41.35	43.00	41.44
WATER COLLECTED	ml	20.0	20.0	23.0
CO 2	%	0	0	0
O 2	%	20.3	20.4	20.4
NOx	ppm	15.9	16	15.6
CO	ppm	16.5	15.8	16.6
N 2	%	79.7	79.6	79.6
TOTAL FORMALDEHYDE CATCH	mg	0.442	0.451	0.495
SAMPLE VOLUME DRY	DSCF	43.65	45.12	43.66
MOISTURE	%	2.1	2.0	2.4
MOLECULAR WEIGHT OF STACK GAS	lb/lb-mole	28.58	28.59	28.55
STACK VELOCITY	FPM	2925	2910	2959
VOLUMETRIC FLOWRATE, ACTUAL	ACFM	95318	94835	96425
VOLUMETRIC FLOWRATE, STANDARD	SCFM	72896	72370	73477
VOLUMETRIC FLOWRATE, DRY STD.	DSCFM	71357	70891	71700
ISOKINETIC RATIO	%	ERR	ERR	ERR
FORMALDEHYDE EMISSION CONC	ppm	0.2917	0.2883	0.3270
FORMALDEHYDE EMISSION RATE	lb/hour	0.097	0.096	0.110
NOx EMISSION RATE	lb/hr	8.131	8.129	8.016
CO EMISSION RATE	lb/hr	5.136	4.886	5.192



**Calibration Curve**  
Formaldehyde



**FORMALDEHYDE**

(µg/2mls)	(Absorbance)
0	0
1	0.058
3	0.19
7	0.448
10	0.61
15	0.83

Regression Output:


Constant	0.016786
Std Err of Y Est	0.030724
R Squared	0.993018
No. of Observations	6
Degrees of Freedom	4

X Coefficient(s)	0.056536
Std Err of Coef.	0.00237

SAMPLE #	VOLUME	aliquot	Abs @ 42	pH of Sodium Sulfite
FORM-IN-1	250 mls.	2.0 0.2	Over Cal 0.435	9.72 <del>NO Good</del>
FORM-IN-2	200 mls.	2.0 0.2	Over Cal 0.580	pH 12.48 after adding 10 mls. of formaldehyde sol'n. 25 mls. of Formaldehyde sol'n.
FORM-IN-3	172 mls.	2.0 0.2	Over Cal 0.182	
FORM-OUT-1	228 mls.	2.0	0.236	(1) 9.92 pH of Sodium Sulfite took 5 mls. of Sodium Sulfite and got
FORM-OUT-2	208 mls.	2.0	0.262	12.27 pH after adding 10 mls. of formaldehyde stock.
Out 2 dup		2.0 mls	0.260	
FORM-OUT-3	221 mls.	2.0	0.270	(2) 9.97 pH of 5 mls. of Sodium Sulfite sol'n.
HPLC BLANK	149 mls.	2.0	0.000	12.25 pH after adding 2 mls. of formaldehyde stock. 12

Calculation

Linear Regression  $x = \mu\text{g}/2\text{mls}$   
 $y = \text{Absorbance}$



from Sample enter Absorbance  
 get equivalent  $\mu\text{g}/2\text{ml}$  Formaldehyde.

$$\mu\text{g Formaldehyde in Sample} = \frac{\mu\text{g}}{2\text{ml}} \times \text{Total Volume} \times \left(\frac{2\text{ml}}{\text{aliquot}}\right)$$

Limit of detection for 0.01 Abs = ~ 0.2  $\mu\text{g}/2\text{ml}$

Total 0.2 mls. sample + 1.8 mls. of DI H<sub>2</sub>O +  
 2 mls. Acetylacetone reagent

Witnessed & Understood by me,

Date

Invented by

Recorded by

Date

*Mary Ann L...*



Standardize  $\text{CH}_2\text{O}$  Mettler 3500 N105H

Book No. \_\_\_\_\_

No. \_\_\_\_\_ 12-22-8

17.8 ml 37% Form aldehyde  $\rightarrow$  12  $\text{H}_2\text{O}$

1.13M Sodium Sulfite

NW:  $\text{Na}_2\text{SO}_3 = 126.04$

$\therefore$  1.13M = 142.4 g/l or 14.24 g/100 ml

Trant 0.02003N  $\text{HgSO}_4$

Standardization

25 + 25 + 25 - pH only 11.51

No Good

1 ml of Formaldehyde stock 23.25 ml titrant 2 Ave 23.22 ml  
 2 ml " " 23.18 ml titrant

mg/ml Formaldehyde =  $\frac{30.0(0.02003)(23.22 \text{ ml})}{2.0 \text{ ml aliquot}}$

= 6.98 mg/ml Formaldehyde

= 6980  $\mu\text{g/ml}$

to prepare 10.0  $\mu\text{g/ml}$  Working Solution dilute 1.753 ml stock to 1.0 liter water

$\frac{10 \mu\text{g}}{6980} = 0.00143 = 10 \mu\text{g/ml}$

Known Standard (X)	ml WS (10 $\mu\text{g/ml}$ )	Abs 412nm (Y)
0 $\mu\text{g}$ / 2 ml	0	0.000
1	0.1	0.058
3	0.3	0.190 (0.196) ok
7	0.7	0.448
10	1.0	0.610
15	1.5	0.820 0.83 $\mu\text{g}$

To Page No. \_\_\_\_\_

① FORM-IN-1

$$x = \frac{y-b}{m}$$

$y = \text{Absorbance}$   
 $b = \text{constant}$   
 $m = x \text{ coefficient (s)}$

$$\frac{0.435 - 0.016786}{0.056536} = 7.40 / 2 \text{ ml/s. of sample}$$

$$\frac{7.40}{2 \text{ ml/s.}} \times 250 \text{ ml/s.} \times \frac{2 \text{ ml/s.}}{0.2 \text{ ml/s.}} = \boxed{9,250 \text{ ug Formaldehyde}}$$

② FORM-IN-2

$$x = \frac{y-b}{m}$$

$$\frac{0.580 - 0.016786}{0.056536} = 9.96 / 2 \text{ ml/s. of sample}$$

$$\frac{9.96}{2 \text{ ml/s.}} \times 200 \text{ ml/s.} \times \frac{2 \text{ ml/s.}}{0.2 \text{ ml/s.}} = \boxed{9,960 \text{ ug Formaldehyde}}$$

③ FORM-IN-3

$$\frac{0.820 - 0.016786}{0.056536} = 14.20 / 2 \text{ ml/s. of sample}$$

$$\frac{14.20}{2 \text{ ml/s.}} \times 172 \text{ ml/s.} \times \frac{2 \text{ ml/s.}}{0.2 \text{ ml/s.}} = \boxed{12,212 \text{ ug Formaldehyde}}$$

④ FORM-OUT-1

$$\frac{0.236 - 0.016786}{0.056536} = 3.88 \text{ ug} / 2 \text{ ml/s. of sample}$$

$$\frac{3.88}{2 \text{ ml/s.}} \times 228 \text{ ml/s.} \times \frac{2 \text{ ml/s.}}{2 \text{ ml/s.}} = \boxed{442 \text{ ug Formaldehyde}}$$

⑤ FORM-OUT-2

$$\frac{0.262 - 0.016786}{0.056536} = 4.34 / 2 \text{ ml/s. of sample}$$

To Page

Witnessed &amp; Understood by me,

Date

Invented by

Date

Recorded by

Lance Catta

12/27/95

Page No. \_\_\_\_\_

$$\frac{4.34}{2 \text{ mls.}} \times 208 \text{ mls.} \times \frac{2 \text{ mls.}}{2 \text{ mls.}} = \boxed{451 \text{ ug Formaldehyde}}$$

FORM-OUT-3

$$\frac{0.270 - 0.016786}{0.056536} = 4.48 / 2 \text{ mls. of sample}$$

$$\frac{4.48}{2 \text{ mls.}} \times 221 \text{ mls.} \times \frac{2 \text{ mls.}}{2 \text{ mls.}} = \boxed{495 \text{ ug Formaldehyde}}$$

HPLC Blank

$$\frac{0.00 - 0.016786^{\text{unc}}}{0.056536} = \frac{0.2 \text{ ug}}{2 \text{ mls.}} \times 199 \text{ mls.} \times \frac{2 \text{ mls.}}{2 \text{ mls.}} = \boxed{\text{nd} \sim 150 \text{ Formaldehyde}}$$

FORM-OUT-2 (duplicate)

$$\frac{0.260 - 0.016786}{0.056536} = 4.30 / 2 \text{ mls. of sample}$$

$$\frac{4.30}{2 \text{ mls.}} \times 208 \text{ mls.} \times \frac{2 \text{ mls.}}{2 \text{ mls.}} = \boxed{447 \text{ ug Formaldehyde}}$$

To Page No. \_\_\_\_\_

Read &amp; Understood by me,

Date

Invented by

Date

CHAIN OF CUSTODY RECORD

PROJECT NO.	PROJECT NAME	PARAMETERS	REMARKS
19624	LOWRY AREA Pacific		16322
SAMPLERS: (Signature) <i>[Signature]</i>		NO. OF CONTAINERS <i>M202</i>	
FIELD SAMPLE NUMBER	DATE	TIME	COMP.
TD-M202-1	12/17		
TD-M202-2			
TD-M202-3			
TD-Blank	12/13		
Form-IN-1	12/14		
Form-IN-2			
Form-IN-3			
Form-H2O			
Relinquished by: (Signature) <i>[Signature]</i>	Date / Time	Received by: (Signature)	Date / Time
<i>[Signature]</i>	12/15/97/1800	<i>[Signature]</i>	
(Printed) <i>[Name]</i>		(Printed)	
Relinquished by: (Signature) <i>[Signature]</i>	Date / Time	Received for Laboratory by: (Signature)	Date / Time
<i>[Signature]</i>		<i>[Signature]</i>	12/15/97/12:00a
(Printed)		(Printed)	
		Received by: (Signature)	Date / Time
		<i>[Signature]</i>	
		(Printed)	
		Relinquished by: (Signature)	Date / Time
		<i>[Signature]</i>	
		(Printed)	
		Received by: (Signature)	Date / Time
		<i>[Signature]</i>	
		(Printed)	

---

Appendix C

Process Data

RTO TESTING readings every 10 minutes -

Fuel type \_\_\_\_\_

Any meter conversion factors? \_\_\_\_\_

meter readings in Cu. ft. for nat. gas \_\_\_\_\_ meter readings in gal. for propane \_\_\_\_\_

TIME	BED TEMPERATURES					INLET PRES. SURE	DURHER TEMP. #1	DURHER TEMP. #2	INLET TEMP	COMBUSTION CHAMBER TEMP	EXHAUST TEMP	PRESSURE DROP	GAS METER READING
	#1	#2	#3	#4	#5								
9:40	325	307	307	347	307	4.7	1558	1559	165	1581	214	0.16	7917988
9:50	327	304	318	337	310	4.7	1554	1537	163	1535	217	0.16	
10:00	328	305	316	340	309	4.5	1549	1545	163	1533	215	17	
10:10	323	307	315	334	318	4.6	1537	1544	163	1531	219	17	
10:20	325	307	317	332	318	4.5	1536	1544	161	1545	218	17	
10:30	324	305	319	331	317	4.6	1531	1538	163	1543	218	17	70
10:35	323	309	311	339	316	4.8	1536	1537	163	1541	218	16	7918200
10:45	323	309	309	345	313	4.6	1525	1530	161	1531	218	17	
10:55	325	310	307	348	311	4.4	1530	1544	162	1542	218	16	
11:05	326	307	321	332	316	4.6	1532	1538	164	1542	218	18	
11:15	328	306	321	337	310	4.6	1538	1534	161	1541	215	18	
11:25	325	308	319	334	318	4.5	1536	1545	165	1549	219	16	
11:35	324	310	316	340	316	4.7	1538	1545	166	1547	220	16	7922650
11:45	325	310	319	339	317	4.5	1540	1545	166	1548	222	16	
11:50	326	313	312	351	311	4.2	1527	1538	167	1541	221	16	
12:00	327	310	322	337	319	4.5	1537	1545	165	1548	221	16	7923363
12:10	331	309	323	342	310	4.5	1543	1541	166	1545	218	18	
12:20	332	310	322	345	309	4.6	1548	1546	166	1553	218	17	
12:30	329	310	325	335	316	4.6	1530	1532	167	1538	220	17	
12:40	327	312	321	339	317	4.5	1536	1547	167	1549	223	16	
12:50	326	314	317	346	316	4.8	1540	1542	168	1547	221	16	

ALAN JONES  
By Mark Chamberlain  
Date: 12-14-95

Sheet ONE of

S

F

S

2

RTO TESTING readings every 10 minutes -

Fuel type \_\_\_\_\_ Any meter conversion factors? \_\_\_\_\_

meter readings in Cu. ft. for nat. gas \_\_\_\_\_ meter readings in gal. for propane \_\_\_\_\_

DATE 12-14-95

By: Mark Chamberlain - ALAN JONES

Sheet TWO of

TIME	DEED TEMPERATURES					INLET PRES. SURE	BURHER TEMP.		INLET TEMP	COMBUSTION CHAMBER TEMP	EXHAUST TEMP	PRESSURE DROP	GAS METER READING
	#1	#2	#3	#4	#5		#1	#2					
1:00	330	319	316	354	309	4.6	1541	1550	108	1561	222	16	7925725
1:10	332	312	322	348	309	4.7	1554	1555	109	1565	219	17	
1:20	332	311	322	343	312	4.5	1544	1537	109	1547	220	16	
1:30	331	310	328	339	316	4.2	1531	1527	108	1535	221	16	
1:38	332	311	329	340	316	4.1	1532	1526	109	1535	221	16	7927233
1:48	329	312	327	339	319	4.4	1531	1535	111	1544	223	18	
1:58	328	314	322	344	319	4.5	1537	1545	109	1547	224	16	
2:08	332	316	317	350	315	4.8	1532	1532	109	1535	221	17	
2:18	327	316	318	350	316	4.9	1530	1530	109	1532	221	17	
2:28	333	312	326	347	318	4.2	1532	1526	109	1535	219	17	
2:38	333	312	330	341	315	4.3	1534	1527	108	1535	220	17	7928640
2:40	328	315	322	344	319	4.6	1541	1545	109	1549	224		

F

1

5

3

F

#1

	Time	load	temp	speed
start	10:35	61	215	61
half	11:05	69	214	61
End	11:35	78	215	61

#2

start	12:00	84	213	61
half	12:30	93	215	61
End	1:00	101	215	61

#3

start	1:38	111	215	61
half	2:08	120	215	61
End	2:38	129	215	61



COMPLIANCE TESTING  
PRESS RTO

WAX & ~~RESIN~~ USAGE

BOARD THICKNESS 7/16 DATE 12-14-95

READINGS TAKEN BY Chip Cameron LINE SPEED \_\_\_\_\_

WAX \_\_\_\_\_ MDI \_\_\_\_\_ PF RESIN \_\_\_\_\_

TIME Hourly	WAX DAY TANK LEVEL	SL WAX FLOW RATE IN GAL	MDI DAY TANK LEVEL	MDI FLOW RATE IN GAL	PF RESIN DAY TANK	PF RESIN FLOW IN GAL
1:35 AM	34 1/2"					
1:35 AM	27 1/2" / 7" used	7" x 139# / in =		973#		
1:35 PM	19 3/8" / 8 1/8" used refilled to 38"			1129#		
3:35 PM	31 1/4" / 6 3/4" used			938#		
3:35 PM	22 1/2" / 8 3/4" used refilled to 33 1/2"			1216#		
Testing complete						
		AVERAGE =		1094.3		
Total	30 5/8"					
	30.63					
	1562.13#					

POUNDS OF PF RESIN / HOUR: \_\_\_\_\_  
 POUNDS OF MDI / HOUR: \_\_\_\_\_  
 POUNDS OF WAX / HOUR: 1094.3

RTO COMPLIANCE TEST  
~~WAX~~ & RESIN USAGE

page \_\_\_\_ of \_\_\_\_

DATE 12-14-95

READINGS BY K. Bloke

BOARD THICKNESS 7/16

LINE SPEED 61'

SPECS: WAX \_\_\_\_\_ MDI \_\_\_\_\_ PF \_\_\_\_\_

TIME	WAX	MDI	PF
#1 Start 10:35		Rate 0.5020 / 146	Rate 1.657 / 481
Finish 11:35		176 / TOTAL USED 30 GAL	575 / TOTAL USED 94 GAL
#2 Start 12:00		0.5070 / 190	1.603 / 615
Finish 1:00		218 / 28 USED GAL	708 / 90 USED GAL
#3 Start 1:38		0.5052 / 235	1.661 / 766
Finish 2:38		266 / 31 GAL	860 / 94 GAL
		Avg 29.666	92.666

POUNDS OF PF RESIN / HOUR: 963.7  
 POUNDS OF MDI / HOUR: 297  
 POUNDS OF WAX / HOUR: \_\_\_\_\_

Phenolic - Total x 10.4 = pounds  
 MDI - Total x 10.3 = pounds

Appendix D  
Calibration Data

UNIT: ICL...  
 DGM SERIAL NO. 2713311  
 BAROMETRIC PRESSURE (P<sub>b</sub>) 29.92 in. Hg  
 STANDARD METER P 697  
 DATE 12-16-95 NAME S. Boyko

MODULE ORIFICE SETTING : ΔH (in H <sub>2</sub> O)	STANDARD METER			MODULE METER			Y	ΔH@ (in H <sub>2</sub> O)	
	VOLUME V <sub>s</sub> (ft <sup>3</sup> )	FACTOR Y <sub>s</sub>	TEMPERATURE t <sub>s</sub> (°F)	PRESSURE ΔP <sub>s</sub> (in H <sub>2</sub> O)	VOLUME V <sub>m3</sub> (ft <sup>3</sup> )	TEMPERATURE t <sub>mo</sub> (°F)			TIME θ (min.)
0.5	5	1.00	67	-0.28	4.948	67	1.01	1.82	
1.0	5			-0.40	4.882	66	1.01	1.86	
1.5	10			-0.52	9.823	66	1.01	1.96	
2.0	10			-0.62	9.831	67	1.01	1.96	
3.0	10			-0.80	9.855	67	1.01	1.96	
							AVERAGE	1.01	1.91

FOR CHECK, USE THE AVERAGE ΔH@ FOR ΔH:

ACCEPTANCE CRITERIA:

$$Y = \frac{V_m (P_b + \frac{P}{13.6}) (t_m + 460) Y_s}{V_s (P_b + \frac{P}{13.6}) (t_s + 460) Y_s}$$

Each Y must be 1.00 ± 0.01

$$\Delta H@ = \left[ \frac{(0.0317) \Delta H}{P_b (t_m + 460)} \right] \left[ \frac{(t_s + 460) \theta}{V_s Y_s} \right]^2$$

Average ΔH@ must be 1.84 ± 0.25

Each ΔH@ must be within 0.15 of the average ΔH@

TC Readout Calibrated with Constant Voltage Source

t<sub>mi</sub> 66 °F t<sub>mo</sub> 66 °F Reference Thermometer 65.8 °F

Module Leak Check OK

Heater Box Control OK Probe Heater Control OK

Module Cleaned OK Pitot Tube Manometer Leak Check OK

Calibrated and Checked by Stephen Boyko Date 12-16-95

Reviewed by \_\_\_\_\_ Date \_\_\_\_\_

METHOD 5 MODULE CALIBRATION

80836

MODULE ORIFICE SETTING ΔH (in Hg)	STANDARD METER		DRY GAS METER	
	VOL <sub>Final</sub>	VOL <sub>Initial</sub>	VOL <sub>Final</sub>	VOL <sub>Initial</sub>
		Air Leak HG →	883.112	878.053 =
1.0			887.994	883.112 = 4.882
1.5			897.863	888.040 = 9.823
2.0			907.694	897.863 = 9.831
		Timer HG →	(917.549	907.694) =
3.0			927.404	917.549 = 9.85
0.5			932.352	927.404 = 4.948

Operator S. Payko

Date 12-16-95

Status (Circle One):  Green  Red

Was Any Maintenance Performed (Circle One):  Yes  No HPB

If Yes, Please Describe in Detail Below:  
Heat Controller for the filter was changed & calibrated

ORIFICE/MODULE NO. 80823 DGM SERIAL NO. 2547143  
 BAROMETRIC PRESSURE (P<sub>b</sub>) 29.40 in. Hg STANDARD METER P-697  
 DATE 12-22-95 NAME S. Boyko

MODULE ORIFICE SETTING ΔH (in H <sub>2</sub> O)	STANDARD METER			MODULE METER			Y	ΔH@ (in H <sub>2</sub> O)
	VOLUME V <sub>s</sub> (ft <sup>3</sup> )	FACTOR Y <sub>s</sub>	TEMPERATURE t <sub>s</sub> (°F)	PRESSURE ΔP <sub>s</sub> (in H <sub>2</sub> O)	VOLUME V <sub>m3</sub> (ft <sup>3</sup> )	TEMPERATURE t <sub>m3</sub> (°F)		
0.5	5	1.00	70	-0.30	5.008	71	12.96	1.91
1.0	5		70	-0.40	5.018	72	9.25	1.95
1.5	10		70	-0.54	10.063	72	14.91	1.90
2.0	10		70	-0.62	10.047	74	12.87	1.88
3.0	10		70	-0.90	10.112	74	10.06	1.72
							AVERAGE	1.87

FOR CHECK, USE THE AVERAGE ΔH@ FOR ΔH:

$$Y = \frac{V_s (P_b + \frac{P}{13.6}) (t_m + 460) Y_s}{V_m (P_b + \frac{\Delta H}{13.6}) (t_s + 460)}$$

Each Y must be 1.00 ± 0.01

$$\Delta H@ = \left[ \frac{(0.0317) \Delta H}{P_b (t_m + 460)} \right] \left[ \frac{(t_s + 460) \theta}{V_s Y_s} \right]^2$$


Average ΔH@ must be 1.84 ± 0.25  
 Each ΔH@ must be within 0.15 of the average ΔH@

TC Readout Calibrated with Constant Voltage Source \_\_\_\_\_  
 t<sub>m</sub> 72 °F t<sub>m3</sub> 72 °F Reference Thermometer 72.2 °F  
 Module Leak Check OK  
 Heater Box Control OK Probe Heater Control OK  
 Module Cleaned OK Pitot Tube Manometer Leak Check OK

Calibrated and Checked by Step Boyko Date 12-22-95  
 Revised by \_\_\_\_\_

**TRC  
NOZZLE CALIBRATION DATA SHEET**

NOZZLE SET NO. SS SET 3    DATE 7-20-95    TECHNICIAN J Michewick



NOZZLE NO.	DIAMETER*	A	B	C	AVERAGE**
3-1		.189	.191	.192	.191
3-2		.256	.254	.255	.255
3-3		.378	.379	.378	.378
3-4		.507	.509	.506	.507
3-5		.129	.128	.127	.128
3-6		.740	.742	.741	.741
3-8		.323	.323	.323	.323

\* Measure to nearest .001"

\*\* Three measurements must be within .004" of each other

RTO ENGINEERING TEST  
LOUISIANA PACIFIC CORP.  
HOULTON, MAINE  
12/14/95






TABLE OF CONTENTS

Contents	Page
Title Page	
Table of Contents	i
Engineering Test Data Summary Sheet	1
Production Data Work Sheet	2
Press Chart - 12/14/95 "A" Crew	3
Press Report - 12/14/95 "A" Crew "AM"	4
Press Report - 12/14/95 "D" Crew "PM"	5
Daily Tonnage Worksheet - 12/14/95	6
Shift Operating Report - 12/14/95 "A Crew"	7
Shift Operating Report - 12/14/95 "D Crew"	8
RTO Operator's Log #1	9
RTO Operator's Log #2	10
Trim Ratio (worksheet) 12/2/95	11
Daily Production Report	12
RTO Circular Chart - 12/14/95	13 & 14
RTO Testing - 12/14/95 Page 1	15
RTO Testing - 12/14/95 Page 2	16
Wax Usage (worksheet)	17
Resin Usage (worksheet)	18
Press Operator's Notes 12/14/95	19

**ENGINEERING TEST DATA SUMMARY SHEET  
FOR THE PRESS  
HOULTON, MAINE**

Prepared by: Mark Stile

February 1, 1996

Press: Washington Iron Works: 12 opening 8X16 ft  
Control Device: RTO Mfg. by Wheelabrator (5 cell)  
RTO fuel: HD5 Propane

A. General Information

Pollutant: VOC, PM, CO, NOx Methods: 1-5, 19, 202  
Wood species & percent mix: Poplar 90% Hardwoods 10%  
Permitted capacity: 443 Ton/day (Finished Product)

B. Run Specific Information - Process Parameters

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
Time Start/Stop	1035/1135	1200/1300	1338/1438
Production TFP/hr	20.33	20.75	19.59
Press Loads	17.917	17.667	17.583
Board Thickness: Average QC Testing -	0.444 inch		(7/16")
Board Density: Average QC Testing -	40.5 #/ft <sup>3</sup>		
Press Temp. °C.	214.6	214.3.	215
PF Resin #/hr@100% solids:	595.4	570	595.4
MDI Resin #/hr	312	291.2	322.4
Wax #/hr	973	938	1216

C. Monitored Control Equipment Parameters

	1541.9	1548.7	1537.5
RTO combustion chamber temp:			
Burner firing rate - Btu/hr:	16.744	8.875	9.078
Burner fuel usage - cu ft:	4450	2362	2407
Burner fuel usage - Gal:	183	97	99
Combustion chamber set point: 1535 °F.			
36.39 cu ft propane vapor @ 60°F / Gal liquid			

D. Run Specific Information - Emissions

Pollutant detected ?	_____	_____	_____
Pollutant lb/hr:	_____	_____	_____
Pollutant mg/m <sup>3</sup>	_____	_____	_____
Pollutant ppm wet	_____	_____	_____
Pollutant ppm dry	_____	_____	_____
Pollutant gr/dscf	_____	_____	_____
Permit Limit:	_____	_____	_____
Control Device Effic	_____	_____	_____
Control Device acfm	_____	_____	_____
Control Device scfm	_____	_____	_____
Control Device dscfm	_____	_____	_____

PRODUCTION DATA WORK SHEET  
FOR THE PRESS  
HOULTON, MAINE

Prepared by: Mark Stile


February 1, 1996

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
TIME Start/Stop:	1035/1135	1200/1300	1338/1438
Press Loads:	17.917	17.667	17.583
Total Wt Untrim (kg):	19,971.3	20,391.1	19,243.7
Total Wt Trimmed (kg):	18,437.5	18,825.1	17,765.8
Pressload Wt Untrim (kg):	1114.7	1154.2	1094.4
Pressload Wt Trimmed (kg):	1029.1	1065.5	1010.4
Board Wt Untrim (kg):	92.9	96.2	91.2
Board Wt Untrim (kg):	85.8	88.8	84.2
Produc. Untrimmed (tons):	22.02	22.48	21.22
Produc. Trimmed (tons):	20.33	20.75	19.59
Produc. Untrimmed (lbs):	44,036.7	44,962.4	42,432.4
Produc. Trimmed (lbs):	40,654.7	41,509.3	39,173.6
Production (sq ft):	27,520	27,136	27,008
Production (sq ft 3/8"):	23,588	23,259	23,149
Line speed (fpm):	61	61	61
Press time to position:	Not documented. Overall timer: 148 sec		

Notes:

Trim Ratio: 7.68 %  
 Board weights are from scale conveyor printout.  
 Propane vapor volume figured at 8 psi  
 Resin Usage (worksheet) figures from flowmeter in batch mode.  
 Wax Usage (worksheet) figures from tank measurements.  
 RTO chart pen identification and ranges:

- 1) Combustion Temp. 0-1800 °F
- 2) Exhaust Temp. 0-500 °F
- 3) Inlet Temp. 0-500 °F
- 4) Bed Delta Press. 0-25"wc



10-39  
Humiflex Phantom Chart  
Am  
Black  
A  
121495  
89785  
THE FOLGORD COMPANY  
FOLGORD MASS.  
U.S.A.

LOUISIANA-PACIFIC CORP.  
HOULTON, MAINE

PRESS REPORT

57.714

OPERATOR K. BLAKE SHIFT (AM) PM CREW A DATE 12-14-54

LINE SPEED	FROM	TO	THICK- NESS	PRESS LOADS	PRESS TEMP	OVERALL TIMER	DECOMP. TIMER	REASON FOR LINESPEED CHANGE
38	700	715	$\frac{23}{32}$	3	215	260	19.1	Start
61	715	330	$\frac{7}{16}$	140	215	148	13.1	
56	330	6:45	$\frac{7}{16}$	51	215	162	13.1	DRYER REE struggling
45	6:45	7:00	$\frac{7}{16}$	3	215	195	13.1	Surface Dryer down

TOTALS 197 (3/8" FOOTAGE) = 356490

FLKR STROKES 1732 TDT 18 mins PEAB OIL BRNR: On → DEBARKER DT 5.44 SANDER DT 1:32

KONUS #1 2741 KONUS #2 2538 SURFACE OIL BURNER On CORE OIL BURNER On

DOWNTIME (MINS) REASON FOR DOWN TIME

FROM	TO	DEPARTMENTS				REASON FOR DOWN TIME
		M	E	O	QC	
7:40	7:42			2		T06 UN
11:43	11:47		4			#4 limit stuck on unloader
11:50	11:52		2			change wzd on limit.
1:32	6:42			10		Bungle's

6 12

\*\*\* MAINTENANCE / LOCK-OUT LOG \*\*\*

MOTOR #	FROM	TO	BRIEF DESCRIPTION OF WORK BEING DONE	INITIALS OF PERSON LOCKING OUT
	3	23/32 TO	8832	
	194	7/6	347658	

LOUISIANA-PACIFIC CORP.  
HOULTON, MAINE

PRESS REPORT

OPERATOR K.P. SHIFT AM (PM) CREW D DATE 12/14/95

LINE SPEED	FROM	TO	THICK-NESS	PRESS LOADS	PRESS TEMP	OVERALL TIMER	DECOMP. TIMER	REASON FOR LINESPEED CHANGE
45'	700	755	7/16	13	215°	210	19.1	Start
37'	755	643	23/32	113	215°	260	19.1	Scheduled
40'	643	647	7/16	1	215°	260	19.1	7/16 Changeout

TOTALS 127 (3/8" FOOTAGE) = 357767  
 FLKR STROKES 1591 TDT 36 PEAB OIL BRNR: 0 DEBARKER DT 3.25 SANDER DT 12hr.  
 KONUS #1 2289 KONUS #2 2908 SURFACE OIL BURNER 0 CORE OIL BURNER 0

DOWNTIME		DOWNTIME(MINS)				REASON FOR DOWN TIME
FROM	TO	M	E	O	QC	
115	146			36		FCOS Baghouse Plugged.
647	700			13		Down

\*\*\* MAINTENANCE / LOCK-OUT LOG \*\*\*

MOTOR # LOCKED OUT	FROM	TO	BRIEF DESCRIPTION OF WORK BEING DONE	INITIALS OF PERSON LOCKING OUT
			14 7/16 - 25089	7:26 K.C. 455
			113 23/32 - 382678	8:27 K.C.
				24 5 141 47
				44.91

12/14/95  
DATE

DAILY TONNAGE WORKSHEET Dec-95

BOARD SIZE	TONS / LOAD	DAY LOADS	DAY TONS	NIGHT LOADS	NIGHT TONS	TOTAL LOADS	TOTAL TONS
1/4	0.6763						
1/4 S1S	0.7787						
1/4 S2S	0.8192						
5/16	0.7980						
3/8	1.0086						
3/8 WEB	1.0191						
7/16	1.1141	194	216.1	14	15.6	208	231.7
7/16 S1S	1.1692						
15/32	1.2396						
1/2	1.2821						
19/32 SE	1.5009						
19/32 T&G	1.5366						
23/32 SE	1.7364						
23/32 T&G	1.7804	3	5.3	113	201.2	116	206.5
7/8 SE	2.1711						
7/8 T&G	2.1711						
1 SE	2.4345						
1 T&G	2.3514						
1.125 SE	2.5862						
1.125 T&G	2.7437						

TOTAL TONNAGE FOR THE DAY

—>>>

438.2

1. LIST PRESSLOADS AND TONS PRODUCED.
2. ROUND OFF THE TONNAGE FIGURES TO ONE DECIMAL POINT. (i.e., 436.3454 = 436.3, & 438.4678 = 438.5, etc.)
3. LIMIT PRODUCTION NOT TO EXCEED 438.5 TONS / DAY.

LOUISIANA-PACIFIC  
HOULTON, MAINE

SHIFT OPERATING REPORT

SUPERVISOR Mc Birch SHIFT \_\_\_\_\_

AM  
PM

CREW A

DATE 12-14-95

PRESS OPERATION:

THICKNESS	PRESSLOADS	3/8" FTG	DOWNTIME (Mins)			
			M	E	O	OC
<u>2 3/4</u>	<u>3</u>	<u>8872</u>				
<u>7/16</u>	<u>194</u>	<u>347658</u>				
TOTAL	<u>197</u>	<u>356490</u>	<u>-</u>	<u>6</u>	<u>12</u>	<u>-</u>

YARD OPERATIONS:

FIRE DUMP CLEANED <u>5</u> TIMES		
TRUCKS USED DIRECT _____ TRUCKS		
BARK TRUCKS LOADED _____ TRAILERS		
MISCELLANEOUS _____		
KONUS FURNACE	HRS. FUEL USAGE WOOD	HRS. FUEL USAGE OIL
#1	<u>12 Hours</u>	<u>0</u>
#2	<u>12 Hours</u>	<u>0</u>

DRYER OPERATION:

	DRY FUEL USAGE LBS.	OIL FUEL USAGE HRS.	AVE. INLET TEMP	RUNNING TIME MINS.	DOWN TIME	AVG. WET MOISTURE	AVG. DRY MOISTURE	REASON FOR OIL USAGE
CORE	<u>6,370</u>	<u>0</u>	<u>956</u>	<u>720</u>	<u>0</u>	<u>38.8%</u>	<u>5.1%</u>	<u>None Used</u>
SURFACE	<u>6,755</u>	<u>0</u>	<u>745</u>	<u>708</u>	<u>12</u>	<u>36.4%</u>	<u>9.5%</u>	<u>None Used</u>

# OF UNITS	1/4	5/16	3/8	7/16	15/32	1/2	19/32	23/32	OTHER
A				<u>104</u>				<u>3-25 per</u>	
A 1/2 UNITS									
U				<u>2 per</u>					
E & X									

IF LESS THAN 99.5%, WHY?

\*\*\*MAINTENANCE/LOCK-OUT LOG\*\*\*

MOTOR # LOCKED OUT	FROM	TO	BRIEF DESCRIPTION OF WORK BEING DONE	INITIALS OF PERSON LOCKING OUT

PERSONNEL COMMENTS/CONCERNS:

ABSENT/TARDY	REASON	EXTRA PERSONNEL	REASON



LOUISIANA-PACIFIC  
BOULTON, MAINE

SHIFT OPERATING REPORT

S.M.C.

SUPERVISOR T. Tenner

SHIFT

AM  
PM

CREW

DATE 12/14/95

PRESS OPERATION:

THICKNESS	PRESSLOADS	3/8" FTG	DOWNTIME (Mins)			
			M	E	O	QC
7/16	14	25089				
5/32	113	332678				
TOTAL	<u>1227</u>	<u>357767</u>			<u>36</u>	

YARD OPERATIONS:

FIRE DUMP CLEANED	<u>2</u>	TIMES
TRUCKS USED DIRECT		TRUCKS
BARK TRUCKS LOADED		TRAILERS
MISCELLANEOUS		
KONUS FURNACE	HRS. FUEL USAGE	HRS. FUEL USAGE
	WOOD	OIL
#1	<u>12 hrs.</u>	<u>0</u>
#2	<u>12 hrs.</u>	<u>0</u>

RYER OPERATION:

	DRY FUEL USAGE LBS.	OIL FUEL USAGE HRS.	AVE. INLET TEMP	RUNNING TIME MINS.	DOWN TIME	AVG. WET MOISTURE	AVG. DRY MOISTURE	REASON FOR OIL USAGE
ORE	<u>10570</u>	<u>0</u>	<u>1040</u>	<u>710</u>	<u>10</u>	<u>42.0%</u>	<u>4.8%</u>	<u>None listed</u>
SURFACE	<u>7060</u>	<u>0</u>	<u>840</u>	<u>714</u>	<u>6</u>	<u>43.0%</u>	<u>9.0%</u>	<u>None listed</u>

# OF UNITS	1/4	5/16	3/8	7/16	15/32	1/2	19/32	23/32	OTHER
A				<u>7 + 28 pcs</u>				<u>98 + 50 pcs</u>	
1/2 UNITS									
U								<u>5 pcs</u>	
E & X									

LESS THAN 99.5%, WHY?

\*\*\*MAINTENANCE/LOCK-OUT LOG\*\*\*

MOTOR #	LOCKED OUT	FROM	TO	BRIEF DESCRIPTION OF WORK BEING DONE	INITIALS OF PERSON LOCKING OUT

PERSONNEL COMMENTS/CONCERNS:

ABSENT/TARDY	REASON	EXTRA PERSONNEL	REASON

RTO OPERATOR'S LOG #1

HOULTON, ME.

Date: 12-14

Shift Electrician inspect the RTO outside and take the following readings every two hours. Press Lineman to fill in when Electrician is busy.

DataLiner:

Recovery Chamber  
Temperatures

Inlet  
Press.  
W.C.

Inlet  
Temp

Comb.  
Chamber  
Temp.

Exh.  
Temp.

1 2 3 4 5

	1	2	3	4	5	Inlet Press. W.C.	Inlet Temp	Comb. Chamber Temp.	Exh. Temp.
317	304	304	342	311	4.1	97	1541	212	
326	307	321	332	316	4.6	104	1542	218	
332	313	318	350	310	4.8	109	1564	223	
335	312	324	346	314	4.5	107	1555	219	
332	309	326	341	313	4.5	105	1543	217	
324	312	316	344	316	4.7	104	1541	220	

by Shift (at 12 AM): Propane tank #1 63 \* Tank #2 55 \*

startup/shutdown times, problems, maintenance items, etc.:  
(Use chart recorder time)

RTO OPERATOR'S LOG #2

HOULTON, ME.

Date: 12-14

Shift Electrician inspect the RTO outside and take the following readings every FOUR hours. Press Lineman to fill in when Electrician is busy. Propane readings: 3 X per shift, Vaporizer: 1 X per shift.

RTO Delta P	Press. Inlet Duct	Burner		Motor Amps	Propane Pressures		Temperature Vaporizer
		Temperature #1	Output % #2		RTO In	Vaporizer Out	

17	5	1546	1560	6	1.7	123	7	40	8	136
17	5	1532	1538	5.2	41.2	118	<del>6.5</del>	<del>42</del>	<del>8</del>	<del>136</del>
17	5	1548	1539	29.7	40.1	115				
17	5.5	1548	1548	16.3	40.0	115	6.5	42	8	136
17	5	1555	1532	1.5	4.4	116				
17	5	1540	1549	21.0	6.5	113				

Burner Setpoints: 1) 1535

BTUE SYSTEM: ON  OFF

2) 1535

Readings taken by: DAY

Richard Lyons

NITE

Steve Tracy

TRIM RATIO

7/16 WEIGHTS

12 2 95

#1

~~9.2%~~

90.1

$$\frac{90.1 - 83.3}{90.1} = 0.0755 = 7.55\%$$

#2

~~8.2%~~

88.5  
82.2

$$= 0.0712$$

#3

~~7.2%~~

87.4  
83.2

#4

~~6.2%~~

86.4  
83.7

#5

~~5.2%~~

85.9  
81.6

#6

~~4.2%~~

84.6  
82.1

$$\frac{495.1}{536.3} = 0.9231 = 0.0768$$

AVERAGE

7.68%

HOULTON DAILY PRODUCTION REPORT THU DEC 14 1995

SHIFT	TYPE	NO OF PRESS LOADS	NO OF PANELS	SURFACE FOOTAGE	3/8 in. FOOTAGE	SCHED RUN HOURS	NET RUN HOURS	% RUN TIME EFF	PLANT CAPC 240T/DAY	% of A GRADE	FLAKER STROKES	HOURS ON OIL	HOURS ON OIL	
CREW	1/4		0	0	0							KONUS 1:	0.00	
	5/16		0	0	0							KONUS 2:	0.00	
	3/8		0	0	0							COREDRIYER	0.00	
	7/16	194	9312	297984	347658							SURFDRIYER:	0.00	
	15/32		0	0	0									
AM	1/2		0	0	0									
	19/32		0	0	0									
	23/32 T&G	3	144	4608	8832									
	1 SE		0	0	0									
TOTAL		197	9456	302592	356490	12.00	11.71	97.60%	185.67	99.98	1732			
CREW	1/4		0	0	0								KONUS 1:	0.00
	5/16		0	0	0								KONUS 2:	0.00
	3/8		0	0	0								COREDRIYER:	0.00
	7/16	14	672	21504	25089								SURFDRIYER:	0.00
	15/32		0	0	0									
PH	1/2		0	0	0									
	19/32 T&G		0	0	0									
	23/32 T&G	113	5424	173568	332678									
	1 SE		0	0	0									
TOTAL		127	6096	195072	357767	12.00	11.20	93.30%	186.34	99.89	1591			
DAILY TOTALS		324	15552	497664	714257	24.00	22.91	95.45%	186.00	99.93	3323			
WEEK TO DATE					3907978	120.00	111.98	93.32%	172.29	99.89	15208			
MONTH TO DATE					12843259	447.10	429.11	95.98%	179.54	99.73	56768			
					YTD= 244865153									

KONUS 1 0.40  
KONUS 2 0.00  
COREDRYER= 0.02  
SURFDRIYER= 0.00



23500000 GOAL \*\*  
10656741 LEFT TO PRODUCE TO MEET GOAL\*\*  
761196 PROD. NEEDED/DAY \*\*\*\*\*  
14.00 DAYS LEFT  
380598 PROD. NEEDED/SHIFT\*


MAJOR DOWNTIME:  
MCNINCH:SCREENS JAMMED(10 M)  
TOWER:FCOS BACHOUSE PLUGGED(36 M)

MINUTES	MECH	ELECT	OPER	QUALITY
DAILY	0	6	61	0
WTD	248	149	65	27
MTD	361	254	265	228

FOREMAN	% RUN TIME EFF	% PLANT CAPACITY	A GRADE	FLAKER STROKES	MTD
MCNINCH	97.15%	187.30	99.93	15719	3572808
SCHOOLS	97.13%	184.26	99.85	14179	3152429
FITZ	96.95%	179.86	99.32	13253	3053092
TOWER	93.92%	175.13	99.79	13617	3130403

- 1 - COMBUSTION TEMPERATURE
- 2 - EXHAUST TEMPERATURE
- 3 - INLET TEMPERATURE
- 4 - BED DENSITY PRESSURE





RTO TESTING readings every 10 minutes -  
 Fuel type \_\_\_\_\_ Any meter conversion factors? \_\_\_\_\_

ALAN JONES  
 BY Mark Wambach  
 Date: 12-14-98  
 Sheet ONE of

meter readings in Cu. Ft. for nat. gas, meter readings in gal. for propane

TIME	DEB TEMPERATURES					INLET PRES. SURE	BURNER TEMP.		INLET TEMP	COMBUSTION CHAMBER TEMP	EXHAUST TEMP	PRESSURE DROP	GAS METER READINGS
	#1	#2	#3	#4	#5		#1	#2					
9:40	325	307	307	347	307	4.7	1558	1559	165	1521	214	0.16	790988
9:50	327	304	318	337	310	4.7	1554	1537	163	1535	217	0.16	
10:00	328	305	316	340	309	4.5	1549	1545	163	1533	215	0.16	
10:10	323	307	315	334	318	4.6	1537	1544	163	1531	219	0.17	
10:20	325	307	317	332	318	4.4	1536	1544	161	1545	218	0.17	
10:30	326	305	319	331	317	4.6	1531	1534	163	1543	218	0.17	76
10:35	323	309	311	339	316	4.8	1536	1537	163	1541	218	0.16	7918200
10:45	323	309	309	345	313	4.6	1525	1530	161	1531	218	0.17	
10:55	325	310	307	348	311	4.4	1530	1544	162	1542	214	0.16	
11:05	326	307	321	332	316	4.6	1532	1538	164	1542	218	0.18	
11:15	324	306	321	337	310	4.6	1538	1534	164	1541	215	0.18	
11:25	325	308	319	334	318	4.5	1538	1545	165	1549	219	0.16	
11:35	324	310	316	340	316	4.7	1538	1545	166	1547	220	0.16	7922650
11:45	325	310	319	339	317	4.5	1540	1545	166	1548	222	0.16	
11:50	326	313	312	351	311	4.3	1527	1538	167	1541	221	0.16	
12:00	327	310	322	337	319	4.5	1537	1545	165	1548	221	0.16	7923363
12:10	331	309	323	343	310	4.5	1543	1541	166	1545	218	0.18	
12:20	332	310	322	345	309	4.6	1548	1546	166	1553	218	0.17	
12:30	329	310	325	335	316	4.6	1530	1532	167	1538	220	0.17	
12:40	327	312	321	339	317	4.5	1536	1547	167	1549	223	0.16	
12:50	326	314	317	346	316	4.8	1540	1542	168	1547	221	0.16	

1  
5  
1  
5  
F  
5



RTO TESTING readings every 10 minutes -

Fuel type \_\_\_\_\_ Any meter conversion factors? \_\_\_\_\_

meter readings in Cu. Ft. for nat. gas meter readings in gal. for propane

DATE 12-14-95

By: Mark Charnick - ALAN JONES

Sheet T10 of

TIME	OED TEMPERATURES					INLET PRES-SURE	BURIER TEMP.		INLET TEMP	COMBUSTION CHAMBER TEMP	EXHAUST TEMP	PRESSURE DROP	GAS METER READING
	#1	#2	#3	#4	#5		#1	#2					
1:00	330	319	316	354	309	4.6	1541	1550	108	1561	222	16	7925725
1:10	332	312	322	342	309	4.7	1554	1555	109	1565	219	17	
1:20	332	311	322	343	312	4.5	1544	1537	109	1547	220	16	
1:30	331	310	328	339	316	4.2	1531	1527	108	1535	221	16	
1:38	332	311	329	340	316	4.1	1532	1526	109	1535	221	16	7927233
1:48	329	312	327	339	319	4.4	1531	1535	111	1544	223	18	
1:58	328	314	322	344	319	4.5	1531	1545	109	1547	224	16	
2:08	332	316	317	350	315	4.8	1532	1532	109	1535	221	17	
2:18	327	316	318	350	316	4.9	1530	1530	109	1532	221	17	
2:28	333	312	326	347	318	4.2	1532	1526	109	1535	219	17	
2:38	333	312	330	344	315	4.3	1534	1527	108	1535	220	17	7928640
2:40	328	315	322	344	319	4.6	1541	1545	109	1549	221		

~~COMPLIANCE TESTING~~  
PRESS RTO

WAX & ~~RESIN~~ USAGE

BOARD THICKNESS 7/16 DATE 12-14-95

READINGS TAKEN BY Chip Cameron LINE SPEED \_\_\_\_\_

WAX \_\_\_\_\_ MDI \_\_\_\_\_ PF RESIN \_\_\_\_\_

TIME Hourly	WAX DAY TANK LEVEL	SL WAX FLOW RATE IN GAL	MDI DAY TANK LEVEL	MDI FLOW RATE IN GAL	PF RESIN DAY TANK	PF RESIN FLOW IN GAL
Start 7:35 Am	34 1/2"					
7:35 Am	27 1/2" / 7" used	7" x 139 #/in =	973 #			
7:35 P.M.	19 3/8" / 8 1/8" used refilled to 38"		1129 #			
7:35 P.M.	31 1/4" / 6 3/4" used		938 #			
7:35 P.M.	22 1/2" / 8 3/4" used refilled to 33 1/2"		1216 #			
Testing complete						
		AVERAGE =	<del>1064</del>			
			1064			
			AVERAGE			
Total	30 5/8"					
	30.63					
	1562.13 #					

POUNDS OF PF RESIN / HOUR: \_\_\_\_\_

POUNDS OF MDI / HOUR: \_\_\_\_\_

POUNDS OF WAX / HOUR: 1064 AVERAGE

ENGINEERING

RTO COMPLIANCE TEST  
~~RESIN~~ RESIN USAGE

page 1 of 1

DATE 12-14-95

READINGS BY K. Blake

BOARD THICKNESS 7/16

LINE SPEED 61'

SPECS: WAX \_\_\_\_\_ MDI \_\_\_\_\_ PF \_\_\_\_\_

TIME WAX MDI PF

TIME	WAX	MDI	PF
Start 10:35	Rate 0.5020 / 146	Rate 1.657 / 481	
Finish 11:35	176 / TOTAL USED 30 GAL = 312 #	575 / TOTAL USED 94 GAL = 968.2 #	
Start 12:00	0.5070 / 190	1.603 / 615	
Finish 1:00	218 / 28 USED GAL = 291.2 #	708 / 90 USED GAL = 927 #	
Start 1:38	0.5052 / 235	1.661 / 760	
Finish 2:38	266 / 31 GAL = 322.4 #	860 / 94 GAL = 968.2 #	
Ave 29.666 GAL		92.666 GAL.	

1.5% Solids

POUNDS OF PF RESIN / HOUR: 954.5 AVG Phenolic-Total x 10.4-pounds  
 POUNDS OF MDI / HOUR: 308.5 AVG MDI-Total x 10.3-pounds  
 POUNDS OF WAX / HOUR: \_\_\_\_\_

Press Operation Notes

#1

	Time	load	temp	speed
start	10:35	61	215	61
half	11:05	69	214	61
end	11:35	78	215	61

12/14/95

Test Blk

Acker

#2

start	12:00	84	213	61
half	12:30	93	215	61
end	1:00	101	215	61

#3

start	1:38	111	215	61
half	2:08	120	215	61
end	2:38	129	215	61