

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

**REPORT OF  
AIR EMISSIONS TESTS  
AND VOC REMOVAL EFFICIENCY  
FOR  
LOUISIANA PACIFIC CORPORATION  
CORRIGAN OSB FACILITY**

**Corrigan, Texas  
June 2, 1995**

**Louisiana Pacific Corporation  
Old Mill Road  
Corrigan, Texas 75939**

**ph: 409/398-2581  
contact: John Knierim**

**Prepared for  
Louisiana Pacific Corporation  
Post Office Box 3107  
Conroe, Texas 77305**

**ph: 409/760-5921  
Contact: Dr. James T. Boswell**

***Performed By:  
Environmental Monitoring Laboratories  
Ridgeland, Mississippi  
< 601/856-3092 >***



**Louisiana-Pacific Corporation**

111 S.W. Fifth Avenue  
Portland, Oregon 97204  
503/221-0800  
FAX: 503/796-0204

August 21, 1995

Mr. Michael F. Wood, Director  
Mr. Laxmi Kesari  
Multi Media Enforcement & Strategic  
Planning Division  
U.S. EPA  
Aerials Rios Blvd.  
1200 Pennsylvania N.W., 7th Floor  
Room 3119C  
Washington, D.C. 20004

Re: Clean Air Enforcement Action - United States v. Louisiana-Pacific Corporation, No. CV 93-0869 (W.D. La.)

Dear Gentlemen:

Louisiana-Pacific Corporation submits as specified in Section C., Part iii., Paragraph 64 for the above referenced Consent Decree, the Air Emission Test Report for the Corrigan, Texas Oriented Strandboard plant. Testing was conducted June 2, 1995.

Please contact the Environmental Affairs Department if you have any questions regarding the Report.

Sincerely,

*Elizabeth T. Smith*

Elizabeth T. Smith, Director  
Environmental Affairs

ETS:mjv

Enclosure

# ENVIRONMENTAL MONITORING LABORATORIES, INC.

P.O. Box 655 • 624 Ridgewood Road

phone: 601/856-3092

Ridgeland, Mississippi 39158

fax : 601/853-2151

July 18, 1995

Subject: Louisiana Pacific Corporation  
Corrigan, Texas

On June 2, 1995, Environmental Monitoring Laboratories performed air emissions testing for Louisiana Pacific Corporation's oriented strand board (OSB) facility in Corrigan, Texas. L.P. operates three OSB dryers which exhaust to a single regenerative thermal oxidizer (RTO) for emissions control. Testing was performed to determine emissions of particulate matter (PM), volatile organic compounds (VOC), formaldehyde (HCOH) nitrogen oxides (NOx), and carbon monoxide (CO) from the (RTO). Testing was also performed at each of the three dryer inlets to determine removal efficiency.

Test Results:

*FILT. ONLY*

	PM		VOC as C		HCOH		CO		NOx	
	#/hr.	gr/dscf	#/hr.	ppm	#/hr.	ppm	#/hr.	ppm	#/hr.	ppm
<b>RTO OUTLET</b>	<b>8.28</b>	<b>0.009</b>	<b>3.48</b>	<b>17.8</b>	<b>0.68</b>	<b>1.39</b>	<b>102.6</b>	<b>216</b>	<b>19.21</b>	<b>25</b>
Dryer No. 1	31.05	0.124	53.58	940	0.91	8.2	25.92	201	4.64	22
Dryer No. 2	26.85	0.102	44.83	736	0.74	4.9	6.97	52	5.13	24
Dryer No. 3	23.20	0.098	34.58	649	0.61	4.5	16.59	138	3.81	20
<b>INLET TOTAL (#/hr)</b>	<b>81.10</b>		<b>133.0</b>		<b>2.46</b>		<b>49.48</b>		<b>13.58</b>	
<b>REMOVAL EFFICIENCY</b>	<b>89.8</b>		<b>97.4</b>		<b>72.4</b>		<b>N/A</b>		<b>N/A</b>	

The testing project was coordinated by Dr. James T. Boswell of Louisiana Pacific Corporation. Danny Russell of Environmental Monitoring laboratories coordinated sample collection and analysis and report preparation. Danny Russell of Environmental Monitoring laboratories coordinated sample collection and analysis and report preparation. Armstrong Environmental performed testing at the RTO inlets. RTO outlet formaldehyde samples were shipped to Oxford Laboratories in Wilmington, North Carolina, for analysis. Otherwise custody of the outlet samples was limited to Mr. Russell.

Following is a report of the test.

REPORT OF AIR EMISSIONS TESTS FOR  
LOUISIANA PACIFIC CORPORATION  
CORRIGAN OSB FACILITY  
CORRIGAN, TEXAS  
JUNE 2, 1995


CONTENTS

1.0	TEST RESULTS	page	1
2.0	SOURCE DESCRIPTION		6
3.0	TEST PROCEDURES		6
4.0	DATA REDUCTION		7
5.0	NOMENCLATURE		12
6.0	CALIBRATION		13
7.0	APPENDICES:		14
	A. Field and Laboratory Data		
	B. Calibrations		
	C. Instrument Recorder Traces/Data Log		
	D. HCHO Analysis Report (Oxford Laboratories)		
	E. Armstrong Environmental Report		

REPORT CERTIFICATION

I certify that I have examined the information submitted herein,  
and based upon my inquires of those responsible for obtaining the  
data or upon my direct acquisition of data, I believe the submitted  
information is true, accurate and complete.

Signed



Daniel G. Russell



**1.0 TEST RESULTS:** The following tables present the measured flow parameters and test results for air emissions and inlet loading samples taken on June 2, 1995, for the RTO and three dryer outlets at Louisiana Pacific Corporation 's OSB facility in Corrigan, Texas.

## 1.0 OSB RTO

### 1.1.2 PM/NO<sub>x</sub>/CO Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/2/95	6/2/95	6/2/95	-----
Time Start .....		0830	1013	1147	---
Time End .....		0933	1116	1250	----
PARTICULATE EMISSIONS	#/hr	10.12	8.44	6.28	8.28
PARTICULATE EMISSIONS	gr/dscf	0.011	0.009	0.006	0.009
CO EMISSIONS	#/hr	111.68	125.36	70.64	102.56
CO EMISSIONS	ppm	240	263	144	216
NO <sub>x</sub> EMISSIONS	#/hr	20.34	17.79	19.50	19.21
NO <sub>x</sub> EMISSIONS	ppm	27	23	24	25
VOLUMETRIC FLOWRATE	acfm	204230	205711	207776	205906
VOLUMETRIC FLOWRATE	dscfm	106675	109275	112858	109603
VELOCITY	ft./sec.	68.4	68.9	69.6	69.0
STACK TEMPERATURE	°F	361	361	370	364
MOISTURE	%	18.1	16.8	14.0	16.3
SAMPLE RATE	% isokinetic	105	103	98	102

## OSB RTO

## 1.1.2 HCHO/VOC Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/2/95	6/2/95	6/2/95	—
Time Start .....		0831	1014	1148	—
Time End .....		0934	1117	1257	—
FORMALDEHYDE EMISSIONS	#/hr	0.728	0.853	0.458	0.680
FORMALDEHYDE EMISSIONS	ppm	1.49	1.78	0.91	1.39
VOC EMISSIONS	#/hr	3.70	4.34	2.40	3.48
VOC EMISSIONS	ppm as C	18.9	22.7	11.9	17.8
VOLUMETRIC FLOWRATE	acfm	199152	193778	199933	197621
VOLUMETRIC FLOWRATE	dscfm	104758	102215	107755	104909
VELOCITY	ft./sec.	66.7	64.9	67.0	66.2
STACK TEMPERATURE	°F	362	362	368	364
MOISTURE	%	17.5	16.8	14.4	16.2
SAMPLE RATE	% isokinetic	105	103	100	103

**1.2 Dryer Outlets:** Inlet testing was performed by Armstrong Environmental. Results of that testing are presented in summary tables here and the entire report of that testing is provided as Appendix E of this report. RTO inlet testing was performed at a location between the primary cyclones exhausts and the inlets to the multicyclones.

### 1.2.1 Dryer No. 1

#### 1.2.1.1 PM/NO<sub>x</sub>/CO Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/1/95	6/1/95	6/1/95	-----
Time Start .....		1025	1445	1625	---
Time End .....		1131	1554	1730	---
PARTICULATE EMISSIONS	#/hr	24.96	36.17	32.03	31.05
PARTICULATE EMISSIONS	gr/dscf	0.0905	0.1502	0.1301	0.1236
CO EMISSIONS	#/hr	26.57	29.28	21.91	25.92
CO EMISSIONS	ppm	189	239	175	201
NO <sub>x</sub> EMISSIONS	#/hr	4.18	5.01	4.73	4.64
NO <sub>x</sub> EMISSIONS	ppm	18	25	23	22
VOLUMETRIC FLOWRATE	acfm	48155	45817	45905	46626
VOLUMETRIC FLOWRATE	dscfm	32169	28087	28723	29660
VELOCITY	ft./sec.	39.6	37.7	37.8	38.4
STACK TEMPERATURE	°F	197	196	195	196
MOISTURE	%	14.7	21.9	20.3	19.0
SAMPLE RATE	% isokinetic	104	105	99	103

#### 1.2.1.2 HCHO/VOC Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/2/95	6/2/95	6/2/95	-----
Time Start .....		0831	1013	1150	---
Time End .....		0933	1120	1255	---
FORMALDEHYDE EMISSIONS	#/hr	1.15	1.30	0.29	0.91
FORMALDEHYDE EMISSIONS	ppm	10.4	11.7	2.6	8.2
VOC EMISSIONS	#/hr	43.96	61.23	55.56	53.58
VOC EMISSIONS	ppm as C	989	932	898	940
VOLUMETRIC FLOWRATE	acfm	45215	45129	45434	45259
VOLUMETRIC FLOWRATE	dscfm	23770	23807	25643	24407
VELOCITY	ft./sec.	37.2	37.1	37.4	37.2
STACK TEMPERATURE	°F	195	197	195	196
MOISTURE	%	33.1	32.9	29.2	31.7
SAMPLE RATE	% isokinetic	110	109	103	107

## 1.2.2 Dryer No. 2

1.2.2.1 PM/NO<sub>x</sub>/CO Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/1/95	6/1/95	6/1/95	---
Time Start .....		0830	1013	1147	---
Time End .....		0937	1119	1252	---
PARTICULATE EMISSIONS	#/hr	23.81	32.48	24.27	26.85
PARTICULATE EMISSIONS	gr/dscf	0.0873	0.1268	0.0929	0.1023
CO EMISSIONS	#/hr	7.22	7.32	6.36	6.97
CO EMISSIONS	ppm	52	56	48	52
NO <sub>x</sub> EMISSIONS	#/hr	---	3.96	6.30	5.13
NO <sub>x</sub> EMISSIONS	ppm	---	18	29	24
VOLUMETRIC FLOWRATE	acfm	51267	51144	50518	50976
VOLUMETRIC FLOWRATE	dscfm	31797	29874	30469	30713
VELOCITY	ft./sec.	43.0	42.9	42.4	42.8
STACK TEMPERATURE	°F	214	213	217	215
MOISTURE	%	18.8	22.8	19.8	20.5
SAMPLE RATE	% isokinetic	109	106	102	106

## 1.2.2.2 HCHO/VOC Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/2/95	6/2/95	6/2/95	---
Time Start .....		0830	1013	1147	---
Time End .....		0937	1119	1252	---
FORMALDEHYDE EMISSIONS	#/hr	1.25	0.67	0.31	0.74
FORMALDEHYDE EMISSIONS	ppm	8.21	4.40	2.04	4.9
VOC EMISSIONS	#/hr	26.20	51.30	56.99	44.83
VOC EMISSIONS	ppm as C	430	842	936	736
VOLUMETRIC FLOWRATE	acfm	52520	50624	52444	51863
VOLUMETRIC FLOWRATE	dscfm	32591	32150	33588	32776
VELOCITY	ft./sec.	44.0	42.5	44.0	43.5
STACK TEMPERATURE	°F	209	208	209	209
MOISTURE	%	18.4	17.0	16.3	17.2
SAMPLE RATE	% isokinetic	102	99	91	97

## 1.2.3 Dryer No. 3

1.2.3.1 PM/NO<sub>x</sub>/CO Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/1/95	6/1/95	6/1/95	-----
Time Start .....		1023	0443	1625	----
Time End .....		1138	0548	1730	----
PARTICULATE EMISSIONS	#/hr	25.84	22.29	21.46	23.20
PARTICULATE EMISSIONS	gr/dscf	0.1081	0.0944	0.0927	0.0984
CO EMISSIONS	#/hr	25.68	11.43	12.67	16.59
CO EMISSIONS	ppm	211	95	108	138
NO <sub>x</sub> EMISSIONS	#/hr	3.50	3.95	3.98	3.81
NO <sub>x</sub> EMISSIONS	ppm	18	20	21	20
VOLUMETRIC FLOWRATE	acfm	38965	38865	38435	38755
VOLUMETRIC FLOWRATE	dscfm	27882	27542	26989	27471
VELOCITY	ft./sec.	67.5	67.3	66.6	67.1
STACK TEMPERATURE	°F	145	148	152	148
MOISTURE	%	15.8	16.3	16.5	16.2
SAMPLE RATE	% isokinetic	102	103	103	103

## 1.2.3.2 HCHO/VOC Emissions Test

Run No. ....		1	2	3	AVG.
Date .....		6/2/95	6/2/95	6/2/95	-----
Time Start .....		0830	1013	1145	----
Time End .....		0936	1116	1249	----
FORMALDEHYDE EMISSIONS	#/hr	0.64	0.71	0.47	0.61
FORMALDEHYDE EMISSIONS	ppm	4.8	5.3	3.5	4.5
VOC EMISSIONS	#/hr	31.19	35.57	36.97	34.58
VOC EMISSIONS	ppm as C	586	668	694	649
VOLUMETRIC FLOWRATE	acfm	42880	42010	41557	42149
VOLUMETRIC FLOWRATE	dscfm	28490	27552	27490	27844
VELOCITY	ft./sec.	74.3	72.8	72.0	73.0
STACK TEMPERATURE	°F	191	189	190	190
MOISTURE	%	16.3	17.6	16.8	16.9
SAMPLE RATE	% isokinetic	105	105	104	105

**2.0 SOURCE DESCRIPTION:** Louisiana Pacific Corporation operates an Oriented Strand Board (OSB) plant in Corrigan, Texas. Process description here is limited to a brief description of the emissions sources and their sampling locations. Detailed descriptions of the processes, the pollution control equipment, and records of operating rates and conditions during testing may be supplied by Louisiana Pacific Corporation.

Three rotary dryers are used for drying wood flakes. Each dryer exhausts to a primary cyclone, then to high efficiency multicyclones. Exhausts from the multicyclones are directed to a mixing chamber then to a regenerative thermal oxidizer (RTO). RTO inlet sampling was done at the inlets to the multicyclones. The RTO exhausts to the atmosphere by way of a vertical 95.5 inch diameter stack. Two sample ports are provided at a location that is 2.0 diameters downstream of the inlet duct and 2.3 diameters below the stack exit. Sketches of the stacks and sampling locations are provided in Appendix A.

**3.0 TEST PROCEDURES:** Test procedures used are those described in 40 CFR, Part 60, Appendix A and in Part 266, Appendix IX.

Particulate sampling was done as described in Method 5. An exception was the inclusion of the condenser section particulate. Reported particulate is based on three fractions: the front half, the back half organic (methylene chloride extraction), and the back half aqueous. The contribution of each fraction can be reviewed in Section 4.0.

Carbon monoxide concentrations were continuously monitored as described in Method 10. A TECO Model 48H gas correlation filter NDIR was used to monitor CO. Instrument calibration and bias checks were performed prior to and following each series of tests, and a mid range system bias check was made following each run by directing calibration to the gas sampling probe.

Nitrogen oxides were continuously monitored as described in Method 7E using a TECO Model 10S analyzer. Instrument calibration was performed prior to and following each series of tests, and a mid range system bias check was made prior to and following each run by directing calibration to the gas sampling probe.

VOC concentrations were measured using Method 25A (continuous monitoring with a flame ionization detector) with a TECO Model 51 heated FID. The 0 to 100 ppm scale was used for calibrations using zero air, and appropriate low, mid and high range concentrations of EPA protocol propane in nitrogen. Since calibrations are made with propane ( $C_3H_8$ ), results as methane ( $CH_4$ ) (or as carbon) are determined by increasing the measured concentration by a factor of three. A continuous trace of VOC as propane was recorded and manually integrated for each 60 minute test period. Instrument calibration was performed initially, and following each 60 minute test period. Any necessary adjustments were made after recording the response of the mid range calibration gas, which was introduced at the inlet to the VOC sampling probe. The gas samples were directed to the heated FID analyzers by way of heated teflon sample lines maintained at a minimum temperature of 250°F.

Instrument calibrations were made with Protocol 1 cylinder gas and with the aid of an Environics Model 2020 gas diluter. (Carbon monoxide cylinder gas was certified rather than Protocol 1). All calibrations were made by introducing calibration gas at the probe inlet.

Formaldehyde was measured using the procedure described in CFR 40, Part 266, Appendix IX, Method 0011. For the outlet sampling, reagent preparation and sample analysis was performed by Oxford Laboratories of Wilmington, North Carolina.

Inlet sampling was done simultaneously with outlet sampling in order to determine removal efficiency or additional pollutant contribution. Armstrong Engineering of Dallas, Texas, performed the inlet sampling at the dryer outlets. A copy of Armstrong Environmental's report is provided in Appendix E of this report.

## 4.0 DATA REDUCTION

Louisiana Pacific Corporation - Corrigan, Texas  
 OSB RTO  
 PM/NOx/CO Emissions Test - June 2, 1995

Collected Test Data:

	RUN 1	RUN 2	RUN 3	
Date :	6/2/95	6/2/95	6/2/95	
Time start :	0830	1013	1147	
Time end :	0933	1116	1250	
1. As : sq ft	49.7432	49.7432	49.7432	
2. Dn : in.	0.245	0.245	0.245	
3. Cp : dimensionless	0.84	0.84	0.84	
4. Theta : minutes	60.00	60.00	60.00	
5. Y : dimensionless	1.00	1.00	1.00	
6. Pbar : in. Hg	29.69	29.69	29.69	
7. Pg : in. H2O	-0.03	-0.03	-0.03	
8. Vm : cf (dry gas)	47.175	47.933	47.313	
9. $\text{sqrt}(DP)_{\text{avg}}$ : in.H2O <sup>.5</sup>	0.9424	0.9512	0.9618	
10. DH : in. H2O	1.9979	1.9979	2.0375	
11. ts : degrees F	361.17	360.79	369.91	363.96
12. tm : degrees F	101.83	108.88	112.38	
13. Vlc : ml	208	190	150	
14. CO2 : percent	2.00	1.50	2.00	
15. O2 : percent	18.50	19.00	18.50	
16. CO : percent	0.02	0.03	0.01	
17. CO : ppm	240.0	263.0	143.5	215.5
18. M,PM : milligrams				
front half	22.8	22.4	14.4	
back half organic	6.1	3	3.3	
back half aqueous	2.8	0.5	0.6	
19. NOx : ppm	26.7	22.8	24.2	25



Louisiana Pacific Corporation - Corrigan, Texas  
 OSB RTO  
 PM/NOx/CO Emissions Test - June 2, 1995

**Calculations:**

		RUN 1	RUN 2	RUN 3	AVG.
1. Pm	: in.Hg (DH/13.6)+Pbar	29.8369	29.8369	29.8398	
2. Ps	: in. Hg (Pg/13.6)+Pbar	29.6878	29.6878	29.6878	
3. An	: sq ft ((Dn/24) <sup>2</sup> )(3.1416)	3.27E-04	3.27E-04	3.27E-04	
4. Vmstd	: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	44.211	44.365	43.528	
5. Vwstd	: scf (.04707cf/ml)(Vlc)	9.791	8.943	7.061	
6. Bws	: dimensionless Vwstd/(Vwstd+Vmstd)	0.1813	0.1678	0.1396	0.1629
7. Md	: mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.06	29	29.06	
8. Ms	: mol.wt. wet basis Md(1-Bws)+18 Bws	27.05	27.15	27.52	
9. Vs	: ft/sec Kp Cp (sqrtDP)sqrt(Ts/(Ps Ms))	68.43	68.92	69.62	68.99
10. Q	: cfm Vs As(60 sec/min)	204230	205711	207776	205906
11. Qstw	: scfm Q(Ps/Pstd)(Tstd/Ts)	130298	131303	131164	130922
12. Qstd	: dscfm Qstw(1-Bws)	106675	109275	112858	109603
13. I	: percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm))/(60 theta Vs Ps An)	104.96	102.82	97.68	101.82

**Particulate Emissions**

14. E,PM	: pounds/hr (M,PM/Vmstd)(Qstd)(60)(453590)				
front half		7.277	7.298	4.939	6.505
back half organic		1.947	0.977	1.132	1.352
back half aqueous		0.894	0.163	0.206	0.421
Total		10.118	8.439	6.276	8.277
15. C,PM	: grains/dscf (M,PM/Vmstd)(.0154 grains/mg)				
front half		0.0079	0.0078	0.0051	0.0069
back half organic		0.0021	0.0010	0.0012	0.0014
back half aqueous		0.0010	0.0002	0.0002	0.0005
Total		0.0110	0.0090	0.0065	0.0088

**CO Emissions**

16. E,CO	: pounds/hr (C,CO)(7.27e-8)(Qstd)(60)	111.68	125.36	70.64	102.56
----------	--	--------	--------	-------	--------

**NOx Emissions**

17. E,NOx	: pounds/hr C,NOx(1.19e-7)(Qstd)(60)	20.34	17.79	19.50	19.21
-----------	---	-------	-------	-------	-------

Louisiana Pacific Corporation - Corrigan, Texas  
 OSB RTO  
 HCHO/VOC Emissions Test - June 2, 1995

Collected Test Data:

RUN 1

RUN 2

RUN 3

	RUN 1	RUN 2	RUN 3
Date :	6/2/95	6/2/95	6/2/95
Time start :	0831	1014	1148
Time end :	0934	1117	1257
1. As : sq ft	49.7432	49.7432	49.7432
2. Dn : in.	0.256	0.256	0.256
3. Cp : dimensionless	0.84	0.84	0.84
4. Theta : minutes	60.00	60.00	60.00
5. Y : dimensionless	1.00	1.00	1.00
6. Pbar : in. Hg	29.69	29.52	29.52
7. Pg : in. H2O	-0.03	-0.03	-0.03
8. Vm : cf (dry gas)	49.929	48.598	49.772
9. $\text{sqr(DP),avg}$ : in.H2O <sup>.5</sup>	0.9199	0.8929	0.9233
10. DH : in. H2O	2.1146	2.0217	2.1330
11. ts : degrees F	361.58	361.79	367.75
12. tm : degrees F	96.73	99.04	102.60
13. Vlc : ml	213	195	165
14. CO2 : percent	2.00	1.50	2.00
15. O2 : percent	18.50	19.00	18.50
16. CO : percent	0	0	0
17. M,HCOH : micrograms	2480	2870	1490
18. C,VOC : ppm as CH <sub>4</sub>	5.2	6.3	3.4

363.71

Louisiana Pacific Corporation - Corrigan, Texas  
 OSB RTO  
 HCHO/VOC Emissions Test - June 2, 1995

<i>Calculations:</i>		RUN 1	RUN 2	RUN 3	AVG.
1. Pm	: in.Hg $(DH/13.6)+Pbar$	29.8455	29.6687	29.6768	
2. Ps	: in. Hg $(Pg/13.6)+Pbar$	29.6878	29.5178	29.5178	
3. An	: sq ft $((Dn/24)^2)(3.1416)$	3.57E-04	3.57E-04	3.57E-04	
4. Vmstd	: dscf $Vm Y(Pm/Pstd)(Tstd/Tm)$	47.234	45.514	46.331	
5. Vwstd	: scf $(.04707cf/ml)(Vlc)$	10.026	9.179	7.767	
6. Bws	: dimensionless $Vwstd/(Vwstd+Vmstd)$	0.1751	0.1678	0.1436	0.1622
7. Md	: mol.wt. dry basis .44 CO <sub>2</sub> + .32 O <sub>2</sub> + .28(CO+N <sub>2</sub> )	29.06	29	29.06	
8. Ms	: mol.wt. wet basis $Md(1-Bws)+18 Bws$	27.12	27.15	27.47	
9. Vs	: ft/sec $Kp Cp (sqrDP)sqr(Ts/(Ps Ms))$	66.73	64.93	66.99	66.21
10. Q	: cfm $Vs As(60 sec/min)$	199152	193778	199933	197621
11. Qstw	: scfm $Q(Ps/Pstd)(Tstd/Ts)$	126994	122829	125817	125214
12. Qstd	: dscfm $Qstw(1-Bws)$	104758	102215	107755	104909
13. I	: percent $[(100 Ts)(.002669 Vlc+(Vm Pm/Tm))/(60 theta Vs Ps An)]$	104.59	103.29	99.74	102.54

**Formaldehyde Emissions**

14. E,HCOH	: pounds/hr $(M,HCOH/Vmstd)(Qstd)(60)(453590000)$	0.728	0.853	0.458	0.680
15. C,HCOH	: ppm $(M,HCOH/Vmstd)(.0283)$	1.49	1.78	0.91	1.39

**VOC Emissions**

16. C,VOC	: ppm as Carbon, dry $((C,VOC)*3)(1-Bws)$	18.91	22.71	11.91	17.84
17. E,VOC	: pounds/hr $(C,VOC)(3.116e-8)(Qstd)(60)$	3.70	4.34	2.40	3.48

## 5.0 NOMENCLATURE

SYMBOL	UNITS	DESCRIPTION
An	ft <sup>2</sup>	Nozzle cross sectional area
As	ft <sup>2</sup>	Stack cross sectional area
Bws	dimensionless	Wet gas fraction
CO <sub>2</sub>	percent	Carbon dioxide content by volume
CO	percent	Carbon monoxide content by volume
Cp	dimensionless	Pitot correction factor
C,X	as labeled	Concentration of pollutant X
DGF	dimensionless	Dry gas fraction
Dn	inches	Nozzle diameter
ΔH (delta H)	in. H <sub>2</sub> O	Pressure drop across meter orifice
ΔP (delta P)	in. H <sub>2</sub> O	Stack gas velocity pressure
E,X	#/hr	Emission rate of pollutant X
EX	#/MM Btu	Emission rate of pollutant X
F	dscf	Volume of flue gas per MM Btu
I	percent	Nozzle velocity/stack gas velocity
Kp	consistent	Pitot tube constant
M,X	milligrams	Sample weight of pollutant X
Md	## mole	Dry molecular weight of stack gas
Ms	## mole	Wet molecular weight of stack gas
N <sub>2</sub>	percent	Nitrogen content by volume, dry basis
O <sub>2</sub>	percent	Oxygen content by volume, dry basis
Pbar	in. Hg	Barometric pressure
Pg	in. Hg	Stack static pressure
Pm	in. Hg	Total pressure at meter (Pbar+(DH/13.6))
Ps	in. Hg	Total stack pressure (Pbar+(Pg/13.6))
Pstd	in. Hg	Standard barometric pressure = 29.92
Q	acfm	Volumetric flow rate at stack conditions
Qstd	dscfm	Volumetric flow rate at standard conditions, dry basis
Qstdw	scfm	Volumetric flow rate at standard conditions, wet basis
θ (theta)	minutes	Sample duration
tm	°F	Meter temperature (Tm denotes °R)
ts	°F	Stack temperature (Ts denotes °R)
Tstd	°R	Standard temperature = 528°R
Vlc	ml	volume of water collected
Vm	ft <sup>3</sup>	Volume of dry gas sampled through meter
Vmstd	dscf	Sample volume at standard conditions
Vwstd	scf	Sample volume of water vapor
Y	dimensionless	Meter coefficient
Xsair	percent	Excess air

## 6.0 CALIBRATIONS:

Measurement devices used by Environmental Monitoring Laboratories and subject to changes in measurement precision are initially calibrated prior to use. Those instruments for which calibration factors are subject to change or for which calibration checks are required, are calibrated following each field use or as otherwise directed and noted. Calibration procedures for specific equipment are as follows.

### Dry Gas Meter:

Dry gas meters are periodically removed from the sampling consoles and cleaned and repaired (new gaskets etc. as required). Following the overhaul of a meter, the measuring precision is checked by the Bell Prover Method and adjusted when necessary to read to within 2% of 100% accuracy. This service is provided by Big Three Meter Company in Jackson, Mississippi. Overhaul service or any six month period is followed by a five point calibration described in APTD-0576 using either a wet test meter or calibrated dry gas meter (used exclusively for calibrations) as a standard reference. Following field use, a gas meter calibration is checked in one of two ways. [1] Three calibration checks at intermediate orifice settings are performed or [2] orifice meter coefficients are used.

If a meter coefficient obtained from pre-test and post-test checks differs by more than 5%, the coefficient (Y) giving the lower sample volume is used in the calculations.

### Orifice:

The orifice coefficient is initially determined and is rechecked following a major gas meter repair and calibration.

### Nozzles:

Nozzles are checked before each field use with a precision (.001 in.) dial caliper. Three measurements on different axes are made; an average of those three readings is used in calculations. If the tolerance among measurements exceeds 0.004 inches (highest to lowest reading) the nozzle is repaired and recalibrated or discarded.

### Pitot Tubes:

Pitot tubes meeting EPA geometry standards are assigned a coefficient of 0.84. Pitot tubes are visually inspected for damage before, during and after use. Those pitot tubes not meeting the geometry standards are assigned a coefficient from the manufacturer's calibration which it retains unless damaged. All pitot tubes used by Environmental Monitoring Laboratories are manufactured by NAPP, Inc.

### Temperature Measuring Instruments:

Most temperature measurements are made with a type K thermocouple and an Omega digital thermocouple thermometer which has an initial calibration traceable to NBS. Other measurements are made using bimetallic dial thermometers. The thermocouples and dial thermometers are checked following or during a test series against an ASTM mercury in glass thermometer.

### Barometer:

Aneroid field barometers are checked against and adjusted to readings from a mercury barometer or readings obtained from local weather authorities.

### Differential Pressure Gauges:

Velocity head ( $\Delta P$ ) and orifice pressure differential ( $\Delta H$ ) measurements are made using water manometers of the appropriate range unless otherwise noted in the test data. Manometers do not require calibration.

## 7.0 APPENDICES

- A. Field and Laboratory Data
- B. Calibrations
- C. Instrument Recorder Traces/Data Log
- D. HCOH Analysis Report (Oxford Laboratories)
- E. Armstrong Environmental Report


7.0 APPENDICES

APPENDIX A.

SAMPLING AND ANALYTICAL DATA

# STACK CONFIGURATION AND SAMPLE POINT LAYOUT FOR CIRCULAR STACKS

**PLANT:** Louisiana Pacific Corporation **Date:** 6-1-95  
**SOURCE:** RTO outlet  
**TEST FOR:** Ph Setting  
**TEST OPERATORS:** Russell



**PERCENT OF DIAMETER**

points on a diameter

point no.	2	4	6	8	10	12	14	16
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5
5			85.4	67.7	34.2	25.0	20.1	16.9
6			95.6	80.6	65.8	35.6	26.9	22.0
7				89.5	77.4	64.4	36.6	28.3
8				96.8	85.4	75.0	63.4	37.5
9					91.8	82.3	73.1	62.5
10					97.4	88.2	79.9	71.7
11						93.3	85.4	78.0
12						97.9	90.1	83.1
13							94.3	87.5
14							98.2	91.5
15								95.1
16								98.4

Point No.	inches from wall	velocity head	
		$\frac{v}{2}$	$\frac{v^2}{2g}$
1	2.0	.75	<5
2	6.4	.75	"
3	11.3	.70	"
4	16.9	.65	"
5	23.9	.62	"
6	34.0	.66	"
7	61.5	.85	"
8	71.6	1.0	"
9	78.6	1.1	"
10	87.2	1.3	"
11	89.1	1.2	"
12	93.5	1.0	"

**STACK DIAMETER:** 95.5"

Distance from ports to disturbance:

A. to upstream disturbance 192"

B. to downstream disturbance 216"

Upstream diameters: 2.01

Downstream diameters: 2.26


Minimum No. sample points required: 24

No. sample points selected: 12 x 2

Port Length: 7"

Port Type: 4" pipe nipple

Port Access: manholes



Pitot ID: \_\_\_\_\_ Pitot Cp: \_\_\_\_\_ Stack Temp: \_\_\_\_\_

Remarks:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Plant LOUISIANA PACIFIC CORRIEAD, TX.  
 Sampling Location DEVERS RD EXHAUST  
 Test For PM / CO / NOx / VOC  
 Test Operators BRO MCKENRY, C. MCKENRY

RUN No. 1  
 Date 6-2-95  
 Time start 0830 end 0933

Meter Box	<u>RAC</u>	No. Sample Pts.	<u>12x2</u>	Gas Analysis	<u>Pipette</u>	Remarks: <u>DN</u> <u>0.245</u> <u>0.246</u> } <u>.245"</u> <u>0.244</u>
Sample Box	<u>NO.</u>	Minutes/Pt.	<u>2.5</u>	CO <sub>2</sub>	<u>2.0</u>	
Probe/Pitot	<u>845.5</u>	NOMOGRAPH		O <sub>2</sub>	<u>18.5</u>	
Pitot Cp	<u>.84</u>	ΔH@	<u>1.90</u>	CO		
Nozzle Dia.	<u>.245</u>	Meter Temp.	<u>100</u>	Time		
Filter No.		% H <sub>2</sub> O	<u>17</u>	Condensate:		
Amb. Temp. °F	<u>65</u>	C-Factor	<u>.89</u>	tare	<u>200</u> fin <u>395</u>	
Bar. Press. "Hg	<u>29.69</u>	Stack Temp.	<u>375</u>	Silica gel:		
Static Press. "H <sub>2</sub> O	<u>-.03</u>	Ref. ΔP	<u>.84</u>	tare	<u>654</u> fin <u>667</u>	

Port Point	El. Time, Min.	DGM Reading, Ft. <sup>3</sup>		Velocity Head ΔP, in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Stack Temp. °F	Meter Temp., °F		Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg	
		In	Out				In	Out				
1	1	0.00	1.68	1.70	0.72	1.60	352	86	81	252	60	2
2	2	2.30	1.69	.8	0.72	1.60	357	86	82	249	60	2
3	3	5.00	1.71	.7	0.65	1.50	355	88	82	251	60	2
4	4	7.30	1.73	.5	0.65	1.40	360	92	85	258	60	2
5	5	10.00	1.75	.0	0.66	1.45	362	100	82	250	60	2
6	6	12.30	1.76	.6	0.60	1.30	369	101	89	251	60	2
7	7	15.00	1.78	.2	0.98	2.15	370	109	81	252	60	2
8	8	17.30	1.80	.3	1.10	2.40	368	109	82	254	60	2
9	9	20.00	1.82	.3	1.10	2.40	359	112	89	249	60	2
10	10	22.30	1.84	.3	1.10	2.40	353	114	89	248	60	2
11	11	25.00	1.86	.5	0.98	2.15	347	117	90	249	60	2
12	12	27.30	1.88	.6	1.00	2.20	356	120	91	248	60	2
14	2	30.00	1.90	.780	0.60	1.30	351	118	92	249	60	2
16	2	2.30	1.92	.4	0.65	1.45	357	115	93	252	60	2
17	3	5.00	1.94	.0	0.65	1.45	363	116	91	255	61	2
18	4	7.30	1.95	.9	0.60	1.30	373	120	93	251	61	2
19	5	10.00	1.97	.5	0.62	1.35	370	120	95	248	61	2
20	6	12.30	1.99	.1	0.40	2.00	371	120	98	254	61	2
21	7	15.00	2.01	.1	1.20	2.65	370	122	100	250	61	2
22	8	17.30	2.03	.5	1.30	2.90	370	126	99	250	61	2
23	9	20.00	2.05	.6	1.30	2.90	360	125	99	253	60	2
24	10	22.30	2.08	.2	1.50	3.30	355	127	100	252	60	2
25	11	25.00	2.10	.7	1.10	2.40	350	130	101	250	60	2
26	12	27.30	2.13	.0	1.10	2.40	370	130	101	250	65	2
27	END	30.00	2.15	.351								

LEAK CHECK: 0.05 → .010 = .005 *check*

*total va 6.2*  
*total va 6.0*

47.175    .9424    1.9979    361.17    101.83

Plant LOUISIANA PACIFIC ORRIGAN TX.  
 Sampling Location DRIVERS RD OUTLET  
 Test For PM 10 / NOx / VOC  
 Test Operators B. MCKNIGHT, L. CARENTH  
 RUN No. 2  
 Date 6-2-95  
 Time start 1013 end 1118

Meter Box	<u>RAC</u>	No. Sample Pts.	<u>12 yr</u>	Gas Analysis	<u>FYRME</u>	Remarks:
Sample Box	<u>NO. 4</u>	Minutes/Pt.	<u>2.5</u>	CO <sub>2</sub>	<u>1.5</u>	
Probe/Pitot	<u>8455</u>	NOMOGRAPH		O <sub>2</sub>	<u>19</u>	
Pitot Cp	<u>.84</u>	ΔH@	<u>1.90</u>	CO		
Nozzle Dia.	<u>.245</u>	Meter Temp.	<u>100</u>	Time		
Filter No.		% H <sub>2</sub> O	<u>17</u>	Condensate:		
Amb. Temp. °F	<u>68</u>	C-Factor	<u>88</u>	tare	<u>200</u> fin <u>376</u>	
Bar. Press. "Hg	<u>29.69</u>	Stack Temp.	<u>375</u>	Silica gel:		
Static Press. "H <sub>2</sub> O	<u>-.03</u>	Ref. ΔP	<u>.89 / .85</u>	tare	<u>700</u> fin <u>714</u>	

Port Point	El. Time, Min.	DGM Reading, Ft. <sup>3</sup>	Velocity Head ΔP, in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Stack Temp. °F	Meter Temp., °F		Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
						In	Out			
1	000	215.665	0.77	1.70	248	96	93	253	58	2
2	200	217.5	0.80	1.70	348	97	96	251	58	2
3	500	219.2	0.76	1.56	368	100	95	251	58	2
4	700	221.0	0.68	1.45	366	102	96	250	58	2
5	1000	222.8	0.64	1.35	367	108	92	255	58	2
6	1200	224.6	0.64	1.35	359	108	93	258	58	2
7	1500	226.4	0.72	1.55	357	111	100	250	58	2
8	1700	228.1	0.86	1.85	350	115	95	252	58	2
9	2000	230.0	1.10	2.40	363	119	96	255	58	2
10	2200	232.0	1.30	2.80	368	120	99	255	58	2
11	2500	234.4	1.30	2.80	369	124	98	255	58	2
12	2700	236.8	1.20	2.60	360	128	100	256	58	2
2	3000	239.321	0.60	1.30	353	121	100	257	58	2
2	200	240.9	0.67	1.45	365	122	98	255	58	2
3	500	242.6	0.60	1.30	365	122	102	255	58	2
4	700	244.5	0.66	1.30	364	122	101	249	58	2
5	1000	246.0	0.70	1.50	357	124	101	250	59	2
6	1200	247.7	0.72	1.55	355	123	101	248	59	2
7	1500	249.5	0.90	1.90	359	124	101	248	59	2
8	1700	251.2	1.50	3.20	363	127	102	254	59	2
9	2000	253.6	1.50	3.20	363	128	104	253	59	2
10	2200	256.3	1.50	3.20	375	132	107	258	59	2
11	2500	258.7	1.10	2.40	361	135	106	251	59	2
12	2700	261.0	1.20	2.60	360	135	107	257	59	2
END	4000	263.598								

LEAK CHECK: .057 → 0.91 = .004 dm/d 7/16  
 + pilot rd 6.5  
 - pilot rd 4.8

47.933 .9512 1.9529 360.29 108.88

Plant LOUISIANA PACIFIC CORP., TX  
 Sampling Location RTO OUTLET  
 Test For PM / CO / NOx / SO2  
 Test Operators B. MCKNIGHT / L. CALVERT

RUN No. 3  
 Date 6-2-95  
 Time start 1147 end 1250

Meter Box RAC  
 Sample Box NO. 1  
 Probe/Pitot 84 S.S.  
 Pitot Cp .84  
 Nozzle Dia. .245  
 Filter No. \_\_\_\_\_  
 Amb. Temp. °F 75°  
 Bar. Press. "Hg 29.69  
 Static Press. "H<sub>2</sub>O -.03

No. Sample Pts. 10x2  
 Minutes/Pt. 2.5  
 NOMOGRAPH  
 ΔH@ 1.90  
 Meter Temp. 100  
 % H<sub>2</sub>O 17  
 C-Factor .88  
 Stack Temp. 775  
 Ref. ΔP .75

Gas Analysis FLUTE  
 CO<sub>2</sub> 2  
 O<sub>2</sub> 18.5  
 CO \_\_\_\_\_  
 Time \_\_\_\_\_  
 Condensate:  
 tare 200 fin 338  
 Silica gel:  
 tare 649 fin 661

Remarks: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Port Point	El. Time, Min.	DGM Reading, Ft. <sup>2</sup>	Velocity Head ΔP, in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Stack Temp. °F	Meter Temp., °F		Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
						in	Out			
1	000	263.788	0.73	1.60	374	105	100	250	60	2
2	030	265.4	0.70	1.50	365	104	100	248	60	2
3	500	267.3	0.68	1.45	363	106	101	251	60	2
4	730	269.0	0.68	1.45	367	108	102	250	60	2
5	1000	270.8	0.70	1.50	370	110	99	248	60	2
6	1230	272.8	0.70	1.50	375	113	97	245	60	2
7	1500	274.1	0.77	1.65	373	113	103	253	60	2
8	1730	275.9	0.90	1.90	380	117	95	252	60	2
9	2000	277.7	1.20	2.60	375	121	100	255	60	2
10	2230	279.9	1.20	2.60	365	120	104	250	60	2
11	2500	282.2	1.30	2.80	355	123	107	247	61	2
12	2730	289.5	1.10	2.40	356	124	105	249	66	2
14	300	286.805	0.65	1.40	375	120	105	250	60	2
2	230	288.5	0.65	1.40	358	128	104	248	66	2
3	500	290.1	0.63	1.35	366	122	104	240	66	2
4	730	291.7	0.60	1.30	369	123	108	260	66	2
5	1000	293.2	0.70	1.50	376	124	105	231	65	2
6	1230	295.0	0.94	2.00	367	123	110	257	65	2
7	1500	296.8	1.30	2.80	377	125	107	255	65	2
8	1730	299.1	1.40	3.00	388	128	107	250	62	2
9	2000	301.5	1.40	3.00	376	131	108	250	62	2
10	2230	309.0	1.50	3.20	374	132	107	250	62	2
11	2500	306.5	1.20	2.60	369	130	109	250	62	2
12	2730	308.8	1.10	2.40	364	138	111	250	62	2
END	4000	311.101								

LEAK CHECK: 096 → 095 = 005 cm @ 9 1/4"

+ pitot @ 6.3  
 - pitot @ 6.5

47.313 .5618 2.0325 369.91 112.38

Plant L.P. Corrigan, TX  
 Sampling Location RTO outlet  
 Test For HCOH  
 Test Operators B. McKnight / G. McKnight / D. Russell / G. Carruth

RUN No. 01  
 Date 6-2-95  
 Time start 0831 end 0934

Meter Box ANDERSON  
 Sample Box NO.  
 Probe/Pitot SP.S.S.  
 Pitot Cp .84  
 Nozzle Dia. .256 OR  
 Filter No. \_\_\_\_\_  
 Amb. Temp. °F 65  
 Bar. Press. "Hg 29.69  
 Static Press. "H<sub>2</sub>O -.03

No. Sample Pts. 24(2112)  
 Minutes/Pt. 2.5  
 NOMOGRAPH  
 ΔH@ 1.75  
 Meter Temp. 100  
 % H<sub>2</sub>O 17  
 C-Factor .81  
 Stack Temp. 375  
 Ref. ΔP .77

Gas Analysis  
 CO<sub>2</sub> 15  
 O<sub>2</sub> \_\_\_\_\_  
 CO \_\_\_\_\_  
 Time \_\_\_\_\_  
 Condensate:  
 tare REMARKS fin \_\_\_\_\_  
 Silica gel:  
 tare REMARKS fin \_\_\_\_\_

Remarks:  

impingers	TARE	FW
DNPH	575	722
DNPH	604	644
MT	483	491
S. GEL	689	257

  
DN  
0.256  
0.256 } .256  
0.256

Port Point	El. Time, Min.	DGM Reading, Ft. <sup>3</sup>		Velocity Head Δ P, in. H <sub>2</sub> O	Orifice Δ H in. H <sub>2</sub> O	Stack Temp. °F	Meter Temp., °F		Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
		In	Out				In	Out			
1	0000	202	692	0.82	2.00	371	79	78	NA	582	
2	230	204	6	0.80	1.40	355	81	78		582	
3	500	206	5	1.40	3.40	359	85	79		582	
4	730	209	0	1.40	3.40	254	92	80		582	
5	1000	211	5	1.10	2.70	351	96	81		582	
6	1230	213	9	1.05	2.60	359	99	83		582	
7	1500	216	4	0.88	2.15	353	101	85		582	
8	1730	218	4	0.90	2.20	370	102	87		582	
9	2000	220	5	0.60	1.45	366	103	89		592	
10	2230	222	3	0.57	1.40	371	103	91		582	
11	2500	224	1	0.60	1.45	361	103	93		582	
12	2730	225	9	0.56	1.40	360	104	95		582	
13											
14	1 3000	227	709	1.10	2.70	370	99	97		592	
15	2 230	229	9	1.10	2.70	359	104	98		582	
16	3 500	232	2	1.20	3.00	354	106	98		582	
17	4 730	234	8	1.10	2.70	350	108	99		582	
18	5 1000	237	3	0.87	2.10	363	109	100		582	
19	6 1230	239	5	0.80	1.95	359	108	100		582	
20	7 1500	241	4	0.72	1.65	368	107	101		582	
21	8 1730	243	5	0.66	1.65	365	108	101		582	
22	9 2000	245	1	0.65	1.60	320	109	102		582	
23	10 2230	247	1	0.62	1.55	370	106	102		592	
24	11 2500	248	8	0.62	1.55	350	106	102		592	
25	12 2730	250	6	0.62	1.55	360	106	103		592	
26	END 0000	252	621								
27											
28											
29											
30											
31											
32											
33											
34											
35											
36											
37											
38											
39											
40											
41											
42											
43											
44											
45											
46											
47											
48											
49											
50											
51											
52											
53											
54											
55											
56											
57											
58											
59											
60											
61											
62											
63											
64											
65											
66											
67											
68											
69											
70											
71											
72											
73											
74											
75											
76											
77											
78											
79											
80											
81											
82											
83											
84											
85											
86											
87											
88											
89											
90											
91											
92											
93											
94											
95											
96											
97											
98											
99											
100											

LEAK CHECK: 058 → 060 = 002 change 6 Hg  
 + pitot 0 .9.3  
 - pitot 0 6.4

49.929 .9199 2.11% 361.58 96.78

Plant L.P. COLLIERIA, TX.  
 Sampling Location RTO BULLET  
 Test For HCOH  
 Test Operators B. & G. McKnight / D. Russell / L. Caruth

RUN No. 2  
 Date 6-2-95  
 Time start 1014 end 1117

Meter Box ANDERSON  
 Sample Box NO. 3  
 Probe/Pitot 8 FT. TOR.  
 Pitot Cp .84  
 Nozzle Dia. .256  
 Filter No. \_\_\_\_\_  
 Amb. Temp. °F 68  
 Bar. Press. "Hg 29.69  
 Static Press. "H<sub>2</sub>O -.03

No. Sample Pts. 24 (12/12)  
 Minutes/Pt. 2.5  
 NOMOGRAPH  
 ΔH@ 1.75  
 Meter Temp. 100  
 % H<sub>2</sub>O 17  
 C-Factor .81  
 Stack Temp. 375  
 Ref. ΔP .771.78

Gas Analysis  
 CO<sub>2</sub> \_\_\_\_\_  
 O<sub>2</sub> \_\_\_\_\_  
 CO \_\_\_\_\_  
 Time \_\_\_\_\_  
 Condensate:  
 tare REMARKS fin \_\_\_\_\_  
 Silica gel:  
 tare REMARKS fin \_\_\_\_\_

Remarks:

Impingers	TARE	FIN
DNPH	595	729
DNPH	598	687
MT	494	504
S. GEL	692	704

Port Point	El. Time, Min.	DGM Reading, Ft. <sup>3</sup>		Velocity Head ΔP, in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Stack Temp. °F	Meter Temp., °F		Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
							In	Out			
1	0:00	253	331	1.20	3.00	356	85	88	NA	60	2
2	2:30	255	.63	1.30	3.10	357	88	88		60	2
2	5:00	258	.0	1.35	3.30	357	92	87		61	2
4	7:30	206	.7	1.40	3.40	364	105	87		61	2
5	10:00	263	.4	1.40	3.40	360	100	88		61	2
6	13:30	266	.0	1.20	2.90	370	103	89		61	2
7	15:00	268	.6	0.98	2.35	373	106	90		61	2
8	18:30	270	.8	0.70	1.70	359	105	92		61	2
9	20:00	272	.8	0.55	1.30	360	104	93		61	2
10	22:30	274	.3	0.50	1.20	354	103	94		61	2
11	25:00	276	.1	0.49	1.15	352	102	95		61	2
12	27:30	277	.5	0.57	1.35	357	102	96		60	2
1	20:00	279	488	1.20	2.90	350	99	97		60	2
2	2:30	281	.7	1.20	2.90	359	104	99		60	2
3	5:00	284	.2	1.10	2.50	359	107	99		59	2
4	7:30	286	.6	1.00	2.40	356	108	100		59	2
5	10:00	288	.8	1.00	2.40	369	108	100		59	2
6	12:30	291	.0	0.57	1.35	377	109	101		59	2
7	15:00	292	.8	0.45	1.15	368	106	101		59	2
8	17:30	294	.4	0.35	0.82	368	105	101		59	2
9	20:00	295	.9	0.40	0.95	368	104	102		59	2
10	22:30	297	.2	0.42	1.00	370	104	102		59	2
11	25:00	298	.8	0.40	0.95	365	105	103		59	2
12	27:30	300	.2	0.45	1.05	358	105	103		59	2
end	10:00	301	929								
leak check: 075 → 678 = 003 cfm @ 2" Hg											
pitot + 62											
pitot - 93											
48.598 .8929 2.0217 361.79 99.04											

Plant LOUISIANA PACIFIC COALFIRED TV  
 Sampling Location RTO OUTLET  
 Test For HCOH  
 Test Operators B. MCKNIGHT G. MCKNIGHT

RUN No. 3  
 Date 6-2-95  
 Time start 1148 end 1257

Meter Box ANDERSON  
 Sample Box N<sup>o</sup>.  
 Probe/Pitot SH-S-S  
 Pitot Cp .84  
 Nozzle Dia. 25F  
 Filter No. \_\_\_\_\_  
 Amb. Temp. °F 75  
 Bar. Press. "Hg 29.69  
 Static Press. "H<sub>2</sub>O -0.03

No. Sample Pts. 1252  
 Minutes/Pt. 2.5  
 NOMOGRAPH  
 ΔH@ 1.75  
 Meter Temp. 100  
 % H<sub>2</sub>O 17  
 C-Factor .81  
 Stack Temp. 375  
 Ref. ΔP .78

Gas Analysis  
 CO<sub>2</sub> \_\_\_\_\_  
 O<sub>2</sub> \_\_\_\_\_  
 CO \_\_\_\_\_  
 Time \_\_\_\_\_  
 Condensate:  
 tare REMARKS fin \_\_\_\_\_  
 Silica gel:  
 tare REMARKS fin \_\_\_\_\_

Remarks:

IMPUSOR	TARE	AW
DNPH	575	660
PNPH	606	664
MT	483	488
S.BEL	704	721

Port Point	El. Time, Min.	DGM Reading, Ft. <sup>3</sup>		Velocity Head ΔP, in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Stack Temp. °F	Meter Temp., °F		Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
							in	Out			
1	000	302	208	1.20	2.90	375	90	93	d/a	60	2
2	230	304	3	1.50	3.60	377	95	94		60	2
3	500	307	3	1.60	3.90	376	93	94		60	2
4	730	310	1	0.74	1.75	352	93	94		60	2
5	1000	312	0	1.30	3.10	364	105	93		60	2
6	1230	314	.4	0.90	2.20	366	107	94		60	2
7	1500	316	.5	0.72	1.65	359	107	94		60	2
8	1730	318	.4	0.56	1.35	365	107	95		60	2
9	2000	320	.1	0.48	1.15	365	107	96		60	2
10	2230	321	.8	0.45	1.05	381	108	97		60	2
11	2500	323	.4	0.44	1.05	372	108	98		60	2
12	2730	325	.4	0.44	1.05	370	108	98		60	2
14	3000	326	.525	1.46	3.40	350	103	99		60	2
2	230	328	.8	1.30	3.20	348	108	101		60	2
3	500	331	.6	1.30	3.20	350	110	101		60	2
4	730	334	.2	1.10	2.60	370	112	101		60	2
5	1000	336	.4	0.90	2.20	368	112	102		60	2
6	1230	338	.7	0.86	1.90	370	112	102		60	2
7	1500	340	.7	0.74	1.80	370	112	102		60	2
8	1730	342	.8	0.75	1.80	371	112	103		60	2
9	2000	344	.5	0.65	1.55	372	113	103		60	2
10	2230	346	.4	0.65	1.55	383	113	103		61	2
11	2500	348	.4	0.65	1.55	374	113	104		61	2
12	2730	349	.9	0.70	1.70	375	113	102		61	2
END	6000	352	.986								

LEAK CHECK: 034 → 034 = 005 cm<sup>3</sup> / Hg

+ photo G.P  
 - photo G.I

49.772      .9233      2.133      36.775      102.60

# BACK HALF PARTICULATE CATCH ANALYSIS

Methylene Chloride Extraction

SAMPLES: L.P. - Corvair RTO exhaust  
 DATE TAKEN: 6-2-94 DATE ANALYZED: 6-4-95  
 DELIVERED BY: DB RECEIVED BY: DCR  
 ANALYZED BY: MCR/DCR

(Attach chain of custody if additional exchanges occur)

RUN NO.	1	2	3	
CONTAINER I.D.	LPCOR R1 BAK	LPCOR R2 BAK	L.P. COR R3 BAK	
VOLUME INTACT?	✓	✓	✓	
VOLUME, ml	420	395	360	

## Organic Fraction

	(E)	(F)	(H)	( )
TARE WEIGHT, gms.	99.1359	97.5712	96.7794	
	99.1422	97.5742	96.7830	
	99.1420	97.5742	96.7827	
FINAL WEIGHT, gms.	99.1420	97.5742	96.7827	
less blank, gms.				
NET GAIN, milligrams	6.1	3.0	3.3	

## Aqueous Fraction

	(B)	(2)	(27)	( )
TARE WEIGHT, gms.	101.6408	104.7528	98.8409	
	101.6440	104.7530	98.8412	
	101.6436	104.7533	98.8415	
FINAL WEIGHT, gms.	101.6436	104.7533	98.8415	
less blank, gms.				
NET GAIN, milligrams	2.8	0.5	0.6	

**PARTICULATE CATCH ANALYSIS**

SAMPLES: L.P. Corvign - RTO  
 DATE TAKEN: 6-2-95 DATE ANALYZED: 6-4-95  
 DELIVERED BY: DGR RECEIVED BY: DGR  
 ANALYZED BY: DCQ

(Attach chain of custody if additional exchanges occur)

FILTERS: \_\_\_\_\_  
 \_\_\_\_\_

RUN NO.	1	2	3	
FILTER NO.	2749	2748	2789	
FILTER TARE, gms.	.5675	.5700	.5699	
	.5818	.5833	.5811	
	.5820	.5832	.5811	
FINAL WEIGHT, gms.	.5820	.5832	.5811	
NET GAIN, gms.	.0145	.0132	.0112	

PROBE WASH: \_\_\_\_\_  
 \_\_\_\_\_

RUN NO.	1	2	3	
CONTAINER I.D.	LP Cor R1	LP Cor R2	LP Cor R3	
VOLUME INTACT?	✓	✓	✓	
VOLUME, ml	140	150	200	
	(4)	(24)	(86)	( )
TARE WEIGHT, gms.	108.4556	105.3520	108.1485	
	108.4638	105.3615	108.1516	
	108.4633	105.3612	108.1517	
FINAL WEIGHT, gms.	108.4633	105.3612	108.1517	
NET GAIN, gms.	.0083	.0092	.0032	
LESS BLANK, gms.				

**PARTICULATE SAMPLE WEIGHT:**

RUN NO.	1	2	3	
filter + probe, mg.	22.8	22.4	14.4	



APPENDIX B.

CALIBRATION DATA

## DRY GAS METER CALIBRATION

**Meter ID** RAC  
**Calibration Method** DGM/DGM      **By** DGR  
**Calibration Meter ID** 651729      **Pbar** 30.05  
**Date** 2/18/95

Vol.	DH	Time	Calibrating Meter			Field Meter				Y	Q	K	DH@		
			VI	VF	Temp	Temp. in		Temp. out							
			ft <sup>3</sup>	ft <sup>3</sup>	°F	init.	final	init.	final						
1	5.00	12.50	772.047	787.047	59	612.402	627.716	59	98	58	69	0.990	1.2	0.694	1.911
1	4.00	19.25	787.047	807.415	59	627.716	648.935	96	111	68	77	1.004	1.08	0.691	1.929
1	3.00	13.45	807.415	819.741	62	648.935	661.985	109	114	77	82	0.998	0.94	0.692	1.921
1	2.00	18.00	819.741	832.838	62	661.985	675.978	110	108	81	84	0.992	0.75	0.676	2.015
1	1.00	21.00	832.838	844.241	62	675.978	688.173	106	111	84	87	0.995	0.57	0.716	1.795
Averages:												1.00			1.91

$$Y = [V_{cal}(P_{bar})(T_{dgm})] / [(V_{dgm})(P_m)(T_{cal})]$$

$$K = Q(\sqrt{P_m M_m}) / ((T_m \text{ out})(DH))$$

$$Q = ((V_{mi} - V_{mf}) / \text{min.}) (T_{M, out} / T_{m, avg})(Y)$$

$$DH@ = 0.921 / K^2$$

Where:

Y = Meter correction factor, dimensionless

V<sub>cal</sub> = Volume of gas through calibrating meter, cubic feet

V<sub>dgm</sub> = Volume of gas through field dry gas meter, cubic feet

P<sub>bar</sub> = Barometric pressure, in. Hg

P<sub>m</sub> = Meter pressure, (P<sub>bar</sub> - DH/13.6)

T<sub>dgm</sub> = Average dry gas meter temp, degrees R

T<sub>cal</sub> = Temperature of gas at calibrating meter, degrees R

## DRY GAS METER CALIBRATION

**Meter ID** RAC  
**Calibration Method** DGM/DGM      **By** GNM  
**Calibration Meter ID** 651729      **Pbar** 29.76  
**Date** 7/13/95

Vol. in. Hg	DH in.	Time min.	Calibrating Meter			Field Meter				Y	Q	K	DH@		
			V <sub>i</sub> ft <sup>3</sup>	V <sub>f</sub> ft <sup>3</sup>	Temp °F	Temp. in		Temp. out							
						init.	final	init.	final						
1	5.00	8.50	432.392	442.521	76	569.427	579.951	91	103	91	92	0.983	1.21	0.682	1.982
1	4.00	9.50	442.521	452.659	83	579.951	590.419	103	120	92	97	0.994	1.08	0.676	2.013
1	3.00	11.00	452.659	462.725	86	590.419	600.891	117	128	97	104	0.999	0.93	0.671	2.049
1	2.00	13.50	462.725	472.804	88	600.891	611.460	126	135	104	111	1.003	0.77	0.673	2.036
1	1.00	18.25	472.804	482.837	89	611.460	622.042	132	135	109	117	1.005	0.57	0.703	1.862
Averages:												1.00			1.99

$$Y = [V_{cal}(P_{bar})(T_{dgm})] / [(V_{dgm})(P_m)(T_{cal})]$$

$$K = Q(\sqrt{(P_m M_m)} / ((T_m \text{ out})(DH)))$$

$$Q = ((V_{mi} - V_{mf}) / \text{min.})(T_{M, \text{out}} / T_{m, \text{avg}})(Y)$$

$$DH@ = 0.921 / K^2$$

Where:

Y = Meter correction factor, dimensionless

V<sub>cal</sub> = Volume of gas through calibrating meter, cubic feet

V<sub>dgm</sub> = Volume of gas through field dry gas meter, cubic feet

P<sub>bar</sub> = Barometric pressure, in. Hg

P<sub>m</sub> = Meter pressure, (P<sub>bar</sub> = DH/13.6)

T<sub>dgm</sub> = Average dry gas meter temp, degrees R

T<sub>cal</sub> = Temperature of gas at calibrating meter, degrees R

## DRY GAS METER CALIBRATION

**Meter ID** Andersen  
**Calibration Method** DGM/DGM      **By** WBM  
**Calibration Meter ID** 651729      **Pbar** 29.95  
**Date** 7/14/95

Vol.	DH	Time	Calibrating Meter			Field Meter						Y	Q	K	DH@
			Vi	Vf	Temp	Vi		Temp. in		Temp. out					
						ft <sup>3</sup>	ft <sup>3</sup>	in.	out	in.	out				
in. Hg	in. H <sub>2</sub> O	min	ft <sup>3</sup>	ft <sup>3</sup>	°F	ft <sup>3</sup>	ft <sup>3</sup>	in.	out	in.	out				
2	2.00	15.00	483.913	496.161	74	364.061	376.451	86	105	85	88	1.015	0.83	0.74	1.668
2	2.00	19.00	496.161	511.716	78	376.451	392.400	98	119	88	103	1.014	0.84	0.75	1.657
2	2.00	15.00	511.716	523.976	80	392.400	405.126	111	123	102	109	1.014	0.85	0.75	1.645
Averages:												1.01			1.66

$$Y = [V_{cal}(P_{bar})(T_{dgm})] / [(V_{dgm})(P_m)(T_{cal})]$$

$$K = Q(\sqrt{(P_m M_m)} / ((T_m \text{ out})(DH)))$$

$$Q = ((V_{mi} - V_{mf}) / \text{min.})(T_{M, out} / T_{m, avg})(Y)$$

$$DH@ = 0.921 / K^2$$

Where:

Y = Meter correction factor, dimensionless

V<sub>cal</sub> = Volume of gas through calibrating meter, cubic feet

V<sub>dgm</sub> = Volume of gas through field dry gas meter, cubic feet

P<sub>bar</sub> = Barometric pressure, in. Hg

P<sub>m</sub> = Meter pressure, (P<sub>bar</sub> = DH/13.6)

T<sub>dgm</sub> = Average dry gas meter temp, degrees R

T<sub>cal</sub> = Temperature of gas at calibrating meter, degrees R

## DRY GAS METER CALIBRATION

**Meter ID** Andersen  
**Calibration Method** DGM/DGM      **By** DGR  
**Calibration Meter ID** 651729      **Pbar** 30.05  
**Date** 2/18/95

Var. in. Hg	DH in. H <sub>2</sub> O	Time min	Calibrating Meter			Field Meter				Y	Q	K	DH@		
			V <sub>i</sub> ft <sup>3</sup>	V <sub>f</sub> ft <sup>3</sup>	Temp °F	Temp. in		Temp. out							
						init.	final	init.	final						
1	5.00	10.00	705.781	718.433	70	142.259	154.458	55	82	55	62	1.012	1.22	0.713	1.810
1	4.00	14.00	718.433	734.176	70	154.458	169.964	72	88	62	73	1.013	1.11	0.716	1.798
1	3.00	14.00	734.176	747.841	70	169.964	183.706	83	88	73	80	1.008	0.98	0.724	1.755
1	2.00	15.00	747.841	759.444	70	183.706	195.595	84	86	80	83	0.995	0.79	0.707	1.841
1	1.00	17.50	759.444	769.343	70	195.595	205.763	86	84	82	85	0.997	0.58	0.734	1.711
Averages:												1.00			1.78

$$Y = [V_{cal}(P_{bar})(T_{dgm})] / [(V_{dgm})(P_m)(T_{cal})]$$

$$K = Q(\sqrt{(P_m M_m)} / ((T_m \text{ out})(DH)))$$

$$Q = ((V_{mi} - V_{mf}) / \text{min.})(T_{M,out} / T_{M,avg})(Y)$$

$$DH@ = 0.921 / K^2$$

Where:

Y = Meter correction factor, dimensionless

V<sub>cal</sub> = Volume of gas through calibrating meter, cubic feet

V<sub>dgm</sub> = Volume of gas through field dry gas meter, cubic feet

P<sub>bar</sub> = Barometric pressure, in. Hg

P<sub>m</sub> = Meter pressure, (P<sub>bar</sub> = DH/13.6)

T<sub>dgm</sub> = Average dry gas meter temp, degrees R

T<sub>cal</sub> = Temperature of gas at calibrating meter, degrees R



# Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX:(810) 589-2134

15311 Propane

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

**Customer**  
ENVIRONMENTAL MON  
242 INGLESIDE DRIVE  
MADISON, MS 39110

**Assay Laboratory**  
Scott Specialty Gases, Inc  
1290 Combermere  
Troy, MI 48083

**Purchase Order :** DRV0116  
**Scott Project # :** 576120

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Concentration Standards, Procedure G1, September, 1993.

**Cylinder Number :** ALM049194  
**Cylinder Pressure + :** 1900 psig

**Certificate Date :** 2/1/95  
**Previous Certificate Date :** None

**Expiration Date :** 2/1/98

### ANALYZED CYLINDER

**Components**  
Propane

**Certified Concentration**  
953.4 ppm

**Analytical Uncertainty\***  
±1% NIST Directly Traceable

**Balance Gas:** Nitrogen

\*Do not use when cylinder pressure is below 150 psig.

\*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

### REFERENCE STANDARD

**Type**  
NTRM 1668

**Expiration Date**  
6/7/96

**Cylinder Number**  
ALM-032015

**Concentration**  
95.5 ppm Propane in Air.

### INSTRUMENTATION

**Instrument/Model/Serial #**  
Prop: Beckman/400/1002059

**Last Date Calibrated**  
1/19/95

**Analytical Principle**  
Flame Ionization Detection

### ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**Components**  
Propane

#### First Triad Analysis

Date: 2/1/95 Response Units: mv  
Z1=0.00 R1=14.40 T1=143.00  
R2=14.40 Z2=0.00 T2=143.00  
Z3=0.00 T3=143.00 R3=14.40  
Avg. Conc. of Cust. Cyl. 953.4 ppm

#### Second Triad Analysis

#### Calibration Curve

Concentration=A+Bx+Cx<sup>2</sup>+Dx<sup>3</sup>+Ex<sup>4</sup>  
r=1.00000 NTRM 1668  
Constants: A=-0.237940000  
B=6.669000000 C=0.000000000  
D=0.000000000 E=0.000000000

Special Notes

Analyst



# Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX: (810) 589-2134

12.3 Propane

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

**Customer:**  
ENVIRONMENTAL MON  
242 INGLESIDE DRIVE  
MADISON, MS 39110

**Assay Laboratory**  
Scott Specialty Gases, Inc  
1290 Combermere  
Troy, MI 48083

**Purchase Order :** DRV0116  
**Scott Project # :** 576120

### ANALYTICAL INFORMATION

Certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous  
Reference Standards, Procedure G1, September, 1993.

**Cylinder Number :** ALM016861  
**Cylinder Pressure + :** 1900 psig

**Certificate Date :** 1/27/95  
**Previous Certificate Date :** None

**Expiration Date :** 1/27/98

### ANALYZED CYLINDER

**Components**  
Propane

**Certified Concentration**  
475.3 ppm

**Analytical Uncertainty\***  
±1% NIST Directly Traceable

**Balance Gas:** Air

Do not use when cylinder pressure is below 150 psig.

Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

### REFERENCE STANDARD

**Expiration Date**  
NTRM 1668 6/7/96

**Cylinder Number**  
ALM-032015

**Concentration**  
95.5 ppm Propane in Air.

### INSTRUMENTATION

**Instrument/Model/Serial #**  
Pro/Beckman/400/1002059

**Last Date Calibrated**  
1/19/95

**Analytical Principle**  
Flame Ionization Detection

### ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**Components**  
Propane

#### First Triad Analysis

Date: 1/27/95	Response Units: mv		
Z1=0.00	R1=14.40	T1=71.30	
R2=14.40	Z2=0.00	T2=71.30*	
Z3=0.00	T3=71.30	R3=14.40	
Avg. Conc. of Cust. Cyl. 475.3 ppm			

#### Second Triad Analysis

Blank area for Second Triad Analysis.

#### Calibration Curve

Concentration=A+Bx+Cx <sup>2</sup> +Dx <sup>3</sup> +Ex <sup>4</sup>	
r=1.00000	NTRM 1668
Constants:	A=-0.237940000
B=6.669000000	C=0.000000000
D=0.000000000	E=0.000000000

**Special Notes**

**Analyst**



# Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX: (810) 589-2134

90.46 Propane

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

**Customer**  
ENVIRONMENTAL MON  
242 INGLESIDE DRIVE  
MADISON, MS 39110

**Assay Laboratory**  
Scott Specialty Gases, Inc  
1290 Combermere  
Troy, MI 48083

**Purchase Order :** DRV0116  
**Scott Project # :** 576120

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

**Cylinder Number :** ALM016008  
**Cylinder Pressure + :** 1900 psig

**Certificate Date :** 1/27/95  
**Previous Certificate Date :** None

**Expiration Date :** 1/27/98

### ANALYZED CYLINDER

**Components**  
Propane

**Certified Concentration**  
90.46 ppm

**Analytical Uncertainty\***  
±1% NIST Directly Traceable

**Balance Gas:** Air

\*Do not use when cylinder pressure is below 150 psig.

Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

### REFERENCE STANDARD

**Type**  
NTRM 1668

**Expiration Date**  
6/7/96

**Cylinder Number**  
ALM-032015

**Concentration**  
95.5 ppm Propane in Air

### INSTRUMENTATION

**Instrument/Model/Serial #**  
Propane : Beckman/400/1002059

**Last Date Calibrated**  
1/19/95

**Analytical Principle**  
Flame Ionization Detector

### ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**Components**  
Propane

#### First Triad Analysis

Date: 1/27/95 Response Units: mv  
Z1=0.00 R1=95.50 T1=90.50  
R2=95.50 Z2=0.00 T2=90.40  
Z3=0.00 T3=90.50 R3=95.50  
Avg. Conc. of Cust. Cyl. 90.46 ppm

#### Second Triad Analysis

#### Calibration Curve

Concentration =  $A + Bx + Cx^2 + Dx^3 + Ex^4$   
r=1.00000 NTRM 1668  
Constants: A=-0.086524000  
B=1.000900000 C=0.000000000  
D=0.000000000 E=0.000000000

**Special Notes**

Analyst



2410 NOx



# Scott Specialty Gases, Inc.

500 WEAVER PARK ROAD, LONGMONT, CO 80501 (303) 442-4700, (303) 651-3094 FAX (303) 772-7873

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

**Customer**  
ENVIRONMENTAL MONITORING  
242 INGLESIDE DRIVE  
MADISON, MS 39110

**Assay Laboratory**  
Scott Specialty Gases, Inc.  
500 Weaver Park Road  
Longmont, CO 80501

**Purchase Order** DRV0826  
**Scott Project #** 0815606  
**CGA Fitting** 660  
**QC Number** 11039435  
**File Number** 15606-01

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol for Assay and certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

**Cylinder Number** ALM-043125      **Certification Date** 08/30/94      **Expiration Date** 08/30/96  
**Cylinder Pressure** 2000 psig      **Previous Certification Dates** None

### ANALYZED CYLINDER

Component	Certified Concentration
NO	2400 ppm
NO <sub>2</sub>	2410 ppm
Balance	

**Analytical Uncertainty\***  
±1% NIST Directly Traceable  
Reference Value Only

\*Analytical uncertainty is inclusive of usual known error sources which at least include precision of the measurement processes.

### REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
NTRM 2631	06/18/95	ALM-022283	2814.0ppm NO / N <sub>2</sub>
GMS	NONE	AAL-19328	2170.0ppm NO / N <sub>2</sub>

### INSTRUMENTATION

Instrument/Model/Serial #	Last Date Calibrated	Analytical Principle
Monitor Cabs 8840-857	08/22/94	Chemiluminescence

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components (Numeric Codes)	First Triad Analysis	Second Triad Analysis	Calibration Curve
	Date: 12/22/93      Response Units: mv Z1 = 0.0000    R1 = 0.4316    T1 = 0.4785 R2 = 0.4316    Z2 = 0.0000    T2 = 0.4785 Z3 = 0.0000    T3 = 0.4785    R3 = 0.4316 Avg. Conc. of Cust. Cyl. = 2401.1 ppm	Date: 08/30/94      Response Units: mv Z1 = 0.0000    R1 = 0.4316    T2 = 0.4786 R2 = 0.4318    Z2 = 0.0000    T2 = 0.4786 Z3 = 0.0000    T3 = 0.4786    R3 = 0.4316 Avg. Conc. of Cust. Cyl. = 2401.8 ppm	Concentration = A+Bx+Cx <sup>2</sup> +Dx <sup>3</sup> +Ex <sup>4</sup> r = 0.999997      NTRM 2631 Constants:      A = -11.764180 B = 5151.8900      C = -232.7234 D = 0      E = 0


**Special Notes** Do not use when cylinder pressure is below 150 psig.

*Diana L. Beehler*  
Analyst: Diana L. Beehler

SCOTT SPECIALTY GASES



# Scott Specialty Gases, Inc.

102.0NOx

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX:(810) 589-2134

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

**Customer:**  
ENVIRONMENTAL MONITORING  
242 INGLESIDE DRIVE  
MADISON, MS 39110

**Assay Laboratory**  
Scott Specialty Gases, Inc  
1290 Combermere  
Troy, MI 48083

**Purchase Order :** DRV0826  
**Scott Project # :** 570523

### ANALYTICAL INFORMATION

Certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

**Cylinder Number :** ALM036349  
**Cylinder Pressure + :** 1900 psig

**Certificate Date :** 8/30/94  
**Previous Certificate Date :** None

**Expiration Date :** 8/30/96

### ANALYZED CYLINDER

**Components**  
Nitric Oxide  
Total Oxides of Nitrogen

**Certified Concentration**  
99.90 ppm  
102.0 ppm

**Analytical Uncertainty\***  
±1% NIST Directly Traceable  
Reference Value Only

**Balance Gas:** Nitrogen

\*Do not use when cylinder pressure is below 150 psig.

\*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

### REFERENCE STANDARD

**Type**  
NTRM 1684

**Expiration Date**  
4/1/96

**Cylinder Number**  
ALM-024582

**Concentration**  
95.2 ppm Nitric Oxide in Nitrogen

### INSTRUMENTATION

**Instrument/Model/Serial #**  
NO Horiba/OPE-235/483814

**Last Date Calibrated**  
8/24/94

**Analytical Principle**  
Chemiluminescence

### ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**Components**  
Nitric Oxide

#### First Triad Analysis

Date: 3/28/94			Response Units: mv		
Z1=0.00	R1=95.20	T1=99.80			
R2=95.20	Z2=0.00	T2=99.80			
Z3=0.00	T3=99.80	R3=95.20			
Avg. Conc. of Cust. Cyl. 99.80 ppm					

#### Second Triad Analysis

Date: 8/30/94			Response Units: mv		
Z1=0.00	R1=95.20	T1=100.00			
R2=95.20	Z2=0.00	T2=100.00			
Z3=0.00	T3=100.00	R3=95.20			
Avg. Conc. of Cust. Cyl. 100.0 ppm					

#### Calibration Curve

Concentration=A+Bx+Cx <sup>2</sup> +Dx <sup>3</sup> +Ex <sup>4</sup>	
r=0.99999	NTRM 1684
Constants:	A=0.000000000
B=1.000000000	C=0.000000000
D=0.000000000	E=0.000000000

Special Notes

*Don E. [Signature]*  
Analyst



# Scott Specialty Gases, Inc.

12.90 NOx

1290 COMBERMERE STREET, TROY, MI 48063

(313) 589-2950 FAX: (313) 589-2134

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

**Customer**  
ENVIROMENTAL MONITORING  
242 INGLESIDE DRIVE  
MADISON MS 39110

**Assay Laboratory**  
Scott Specialty Gases, Inc.  
1290 Combermere  
Troy, MI 48083

**Purchase Order** 0630DR  
**Scott Project #** 553186

### ANALYTICAL INFORMATION

Required to exceed the minimum specifications of EPA Protocol 1 Procedure # G1, Section Number 3.0.4

**Cylinder Number** ALM022478  
**Cylinder Pressure** 1900 psig

**Certification Date** 7-19-93  
**Previous Certification Dates** None

**General Exp. Date** 7-19-95  
**Acid Rain Exp. Date** 7-19-95

### ANALYZED CYLINDER

**Components**  
Nitric Oxide

**Certified Concentration**  
12.90 ppm

**Analytical Uncertainty\***  
±1% NIST Directly Traceable

**Equal Oxides of Nitrogen**  
**Balance Gas:** Nitrogen

12.90 ppm

Reference Value Only

\*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

### REFERENCE STANDARD

**Type**  
SRM 2629A

**Expiration Date**  
1-4-95

**Cylinder Number**  
FF-28502

**Concentration**  
19.40 ppm NO in N<sub>2</sub>

### INSTRUMENTATION

**Instrument/Model/Serial #**  
NO: Horiba/OPE-235/560543082

**Last Date Calibrated**  
5-18-93

**Analytical Principle**  
Chemiluminescence

### ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**Components**

**First Triad Analysis**

**Second Triad Analysis**

**Calibration Curve**

Nitric Oxide

Date: 7-11-93 Response Units: mv  
Z1=0.00 R1=19.40 T1=12.90  
R2=19.40 Z2=0.00 T2=12.90  
Z3=0.00 T3=12.90 R3=19.40  
Avg. Conc. of Cust. Cyl. 12.90 ppm

Date: 7-19-93 Response Units: mv  
Z1=0.00 R1=19.40 T1=12.90  
R2=19.40 Z2=0.00 T2=12.90  
Z3=0.00 T3=12.90 R3=19.40  
Avg. Conc. of Cust. Cyl. 12.90 ppm

Concentration=A+Bx+Cx<sup>2</sup>+Dx<sup>3</sup>+Ex<sup>4</sup>  
r=0.99999 SRM 2629A  
Constants: A=0.01381712  
B=0.9992878 C=0  
D=0 E=0

Concentration=A+Bx+Cx<sup>2</sup>+Dx<sup>3</sup>+Ex<sup>4</sup>

Concentration=A+Bx+Cx<sup>2</sup>+Dx<sup>3</sup>+Ex<sup>4</sup>

### Special Notes

If this product is used for Acid Rain Rule Compliance, the Acid Rain Expiration Date noted above applies per 40 CFR Part 75, Appendix H. Otherwise, the General Expiration Date applies.

*F. P. Doran*  
Analyst Frank P. Doran



# Scott Specialty Gases, Inc.

Shipped From: 3714 LAPAS DRIVE  
 HOUSTON TX 77023  
 Phone: 713-644-4820 Fax: 713-644-0244

## CERTIFICATE OF ANALYSIS

ENVIRONMENTAL MONITORING  
 DANNY RUSSELL  
 P O BOX 655

PROJECT #: 04-43388-001  
 PO#: DRV0517  
 ITEM #: 04024315 2AL  
 DATE: 5/26/95

RIDGELAND MS 39158

CYLINDER #: ALM055984

ANALYTICAL ACCURACY: +/- 1%  
 PRODUCT EXPIRATION: 5/24/96

BLEND TYPE : ACUBLEND MASTER GAS

### COMPONENT

CARBON MONOXIDE  
 OXYGEN  
 NITROGEN

### REQUESTED GAS

CONC MOLES  
 452. PPM  
 11. %  
 BALANCE

### ANALYSIS

(MOLES)  
 453. PPM  
 11.01 %  
 BALANCE

2000 PSI

*453*

THIS PRODUCT IS TRACEABLE TO  
 DOCUMENTATION BY BOTH THE  
 NUMBERS IDENTIFIED ON THIS

ALL PRODUCTION & ANALYTICAL  
 PROJECT & CYLINDER SERIAL  
 CERTIFICATE OF ANALYSIS.

ANALYST: \_\_\_\_\_



# Scott Specialty Gases, Inc.

Shipped From: 3714 LAPAS DRIVE  
 HOUSTON TX 77023  
 Phone: 713-644-4820 Fax: 713-644-0244

## CERTIFICATE OF ANALYSIS



ENVIRONMENTAL MONITORING  
 DAN RUSSELL  
 P O BOX 655

PROJECT #: 04-29381-003  
 PO#: DRV-0107  
 ITEM #: 04021453 2AL  
 DATE: 1/11/94

RIDGELAND MS 39158

CYLINDER #: ALM007930 ANALYTICAL ACCURACY: +/- 1%  
 FILL PRESSURE: 2000 PSI PRODUCT EXPIRATION: 1/11/95  
 BLEND TYPE : ACUBLEND MASTER GAS

COMPONENT	REQUESTED GAS		ANALYSIS	
	CONC	MOLES	(MOLES)	
CARBON MONOXIDE	4,500.	PPM	4,540.	PPM
NITROGEN		BAL		BAL

ANALYST:  APPROVED BY: 



# Scott Specialty Gases, Inc.

Shipped From: 3714 LAPAS DRIVE  
 HOUSTON TX 77023  
 Phone: 713-644-4820 Fax: 713-644-0244

## CERTIFICATE OF ANALYSIS

ENVIRONMENTAL MONITORING PROJECT #: 04-39907-002  
 DANNY RUSSELL PO#: DRV0116  
 P O BOX 655 ITEM #: 04024520 2AL  
 DATE: 1/27/95  
 RIDGELAND MS 39158

CYLINDER #: AAL19761 ANALYTICAL ACCURACY: +/-1%  
 PRODUCT EXPIRATION: 1/27/96  
 BLEND TYPE : ACUBLEND MASTER GAS

COMPONENT	REQUESTED GAS		ANALYSIS	
	CONC	MOLES	(MOLES)	
CARBON DIOXIDE	12.	%	12.08	%
CARBON MONOXIDE	955.	PPM	953.	PPM
OXYGEN	3.	%	3.03	%
NITROGEN		BALANCE		BALANCE

2000 PSI

THIS PRODUCT IS TRACEABLE TO ALL PRODUCTION & ANALYTICAL  
 DOCUMENTATION BY BOTH THE PROJECT & CYLINDER SERIAL  
 NUMBERS IDENTIFIED ON THIS CERTIFICATE OF ANALYSIS.


ANALYST:


APPENDIX C.

INSTRUMENT RECORDER TRACES/DATA LOG

NO<sub>x</sub> AND CO TRACE








PART NO. LD/80T

PRINTED IN U.S.A.



40ppm NO

250ppm

275ppm

ENV02 R 3 @ 1251

LINEEIS

START R 200

C 1/14/7

250

40ppm

PRINTED IN U.S.A.  
PART NO. LD/8011

VOC TRACE


Chart No. 2293-2

Chart No. 2293-2

1828

Chart No. 2293-2

Chart No. 2293-2



-50ppm 43ft


-10 ppm (Clean Environment)  
2000 Cycles

END RI  
AVG 5.2 ppm  
for TECO S1 Data Logger

L.P. - Corrigan  
Payne RCO Test for VOC  
TECO Model S1  
Chart = 0-100 ppm  
Chart speed = 20 c/ft

START RI  
0 0 230

6/2/95 LP 0-100



start 10/11/70

Zero  
10 ppm 65/70

FD 0 R2  
C 117 63 ppm  
per T&E M&S  
D&P 10/6


SPT @ 1013

Chart No. 1-2307-7

Chart No. 1-2307-7

1970

1970



10 ppm      25 ppm      50 ppm      75 ppm

AVG 34 ppm ENB R 301117

start  
R301117

2000  
10 ppm 25K1

EN 0 R2  
C 117      65 ppm  
PA TEE2 MUESI  
DRAKLOG

CHART NO. CI-2987-2

Chart No.

CHART NO. CI-2987-2

CHART

APPENDIX D.

HCHO ANALYSIS REPORT (OXFORD LABS)





Analytical and Consulting Chemists

1316 South Fifth Street  
Wilmington, N.C. 28401  
(910) 763-9793  
Fax (910) 343-9688

DATE RECEIVED 06-06-95  
DATE REPORTED 06-12-95  
95W7216

PAGE 2 OF 2

ENVIRONMENTAL MONITORING  
242 INGLE SIDE DR.  
MADISON, MS 39110

P.O. # DR0604

ATTENTION: DANNY RUSSELL

SAMPLE DESCRIPTION: 10 FORMALDEHYDE

- 7. LPC R1
- 8. LPC R2
- 9. LPC R3
- 10. BLANK

RESULTS

	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Formaldehyde, as HCHO, Total ug	2480	2870	1490	37.9

*Ann McMillan*  
ANN MCMILLAN, ANALYST

APPENDIX E.

ARMSTRONG ENVIRONMENTAL REPORT

Exhaust Emission Sampling  
**Louisiana Pacific, Corrigan, TX**  
Dryers #1, #2 & #3  
June 1 & 2, 1995  
*Armstrong Environmental, Inc.*  
Project W-1696-95

Report Prepared For:  
Mr. Dan Russel  
EMS  
PO Box 655  
Ridgeland, MS 39158

Report Prepared June 9, 1995 By:  
*Armstrong Environmental, Inc.*  
7715 Sovereign Row  
Dallas, Texas 75247  
(214) 631-0021

## TABLE OF CONTENTS

	<b>Page</b>
<b>I. Introduction</b>	<b>1</b>
<b>II. Summary</b>	<b>2 - 9</b>
<b>III. Procedures</b>	<b>10 - 12</b>
<b>IV. Appendices</b>	
<b>A. Calculation Summaries</b>	<b>13 - 27</b>
<b>B. Analytical Summaries</b>	<b>28 - 49</b>
<b>C. Continuous CEM Recordings</b>	<b>50 - 135</b>
<b>D. Field Data Sheets</b>	<b>136 - 154</b>
<b>E. Equipment Calibrations</b>	<b>155 - 179</b>
<b>F. Standard Gas Certifications</b>	<b>180 - 197</b>

## I. INTRODUCTION

A series of tests were performed on the exhausts associated with Dryers #1, #2 and #3 at the Louisiana Pacific facility located in Corrigan, TX on June 1 and 2, 1995.


The purpose of this test series was to determine the emission rates of particulate, Nox, CO, VOC and Formaldehyde in terms of lbs/hr simultaneously with the sampling performed on the RTO exhaust. Sampling for VOC and Formaldehyde was performed concurrently with the exhaust sampling on June 2, particulate, Nox and CO testing was performed non-concurrently on June 1.

Testing followed procedures detailed in Title 40: Code of Federal Regulations (40:CFR).

Sampling was performed by Richard Taylor, Matt Taylor, John Dahlem, Danny Barrera, Joe Barrera, Jerry Salinas and Tom Armstrong of Armstrong Environmental, Inc. using an 3 Apex Method 5 Sampling Trains, three FUJI continuous CO analyzers and three TECO Model 51 continuous FID analyzers.

Three one hour repetitions were performed on June 1 commencing at 10:25 am and ending at 5:30 pm for PM, Nox and CO, and three one hour repetitions were performed on June 2, commencing at 8:30 am and ending at 12:55 pm.

Submitted by:  
*Armstrong Environmental, Inc.*

  
Tom Armstrong  
President

## II. SUMMARY

A series of tests were performed on the exhaust associated with Dryers #1, #2 and #3 at the Louisiana Pacific facility in Corrigan, TX on June 1 and 2, 1995.

Sampling was performed following procedures detailed in Title 40: Code of Federal Regulations.

Results of this test series are summarized in Table 1-6.

Results indicate the following emission rates:

Component/Run#	1	2	3	Ave.
<b>Dryer #1 Exhaust</b>				
Particulate, lbs/hr	28.53	39.91	36.36	34.93
Nox, lbs/hr	4.18	5.01	4.73	4.64
CO, lbs/hr	26.57	29.28	21.91	25.92
VOC as C - *DB, lbs/hr	43.96	61.63	55.56	53.72
Formaldehyde, lbs/hr	1.151	1.30	0.293	0.914
*DB - Dry Basis				
<b>Dryer #2 Exhaust</b>				
Particulate, lbs/hr	28.61	38.77	32.02	33.13
Nox, lbs/hr	7.22	3.95	6.29	5.12
CO, lbs/hr	7.22	7.31	6.36	6.96
VOC as C - DB, lbs/hr	26.20	51.30	56.99	44.83
Formaldehyde, lbs/hr	1.252	0.671	0.311	0.745
Nox, lbs/hr	5.01	4.66	6.33	5.33
<b>Dryer #3 Exhaust</b>				
Particulate, lbs/hr	27.14	24.81	23.54	25.16
Nox, lbs/hr	3.50	3.95	3.98	3.81
CO, lbs/hr	25.68	11.43	12.67	16.59
VOC as C - DB, lbs/hr	31.19	35.57	36.97	34.57
Formaldehyde, lbs/hr	0.644	0.712	0.471	0.609

Based on the results of this test series, the following comments can be made:

1. Power was lost about 7 minutes before the completion of Run#1 on June 1. Particulate sampling continued as soon as power cords could be strung, however, the CEM data did not continue, although a post span was performed after power came back up.

2. Nox sampling on Dryer #2 was repeated during the VOC and Formaldehyde runs on June 2 as the Nox analyzer was not performing in a stable manner on June 1.

3. VOC is reported on a dry basis as C (Carbon), although measurements were taken on a wet basis. Concentrations on wet basis were adjusted up for these calculations.

4. Field blanks and spiked blanks were taken in the field. The spike consisted of a 1 ml aliquot of 1.004 mg/ml formaldehyde in water added to the DNPH reagent. Results yielded 1.143 mg, within the +/- 20% given in Method 0011. Field blanks showed no formaldehyde detected.

5. Particulate data is reported as two varieties; "Front-Half" and "Back-Half". Front half is the probe wash and filter, which is what USEPA calls particulate. "Back-Half" is the residue in the impinger solutions, which the Texas Natural Resources Conservation Commission requests added to the "Front-Half".

**SUMMARY OF EMISSIONS TEST DATA**

Table : 1

Plant : Louisiana Pacific, Corrigan, TX

Location : Dryer #1 Exhaust

Operator : J. Dahlem, C. Jefferson, T. Armstrong

Test Date : 1-Jun-95

Repetition :	1	2	3
<b>STACK GAS</b>			
Temperature, F	196.8	195.5	194.9
Velocity, fps	39.63	37.71	37.78
Volume Flow, acfm	48155.2	45817.1	45905.3
scfm	32169.0	28087.2	28722.6
scfh	1930141	1685234	1723356
Moisture, %	14.66%	21.87%	20.33%
CO <sub>2</sub> , %	2.50	4.00	3.50
O <sub>2</sub> , %	16.50	16.00	14.00
<b>SAMPLE</b>			
Start Time, hrs:min	10:25 AM	2:45 PM	4:25 PM
Finish Time, hrs:min	11:31 AM	3:54 PM	5:30 PM
Sample Volume, scf	35.012	31.101	29.921
Isokinetic Ratio, %	103.5112	105.3125	99.07621
<b>PARTICULATE</b>			
Front Half			
Sample Weight, mg	205.35	302.76	252.20
Concentration, gr/scf	0.0905	0.150209	0.130058
Emissions, lbs/hr	24.96205	36.17421	32.02983
Back Half			
Sample Weight, mg	29.35	31.28	34.10
Concentration, gr/scf	0.012935	0.015519	0.017585
Emissions, lbs/hr	3.567744	3.73738	4.330759
Total Particulate, lbs/hr	28.5298	39.91159	36.36059
<b>CARBON MONOXIDE</b>			
Concentration, ppm	189.36	239	174.9
Emissions, lbs/hr	26.56741	29.27722	21.9097
<b>NITROGEN OXIDE AS NO<sub>2</sub></b>			
Concentration, ppm	18.13	24.9	23
Emissions, lbs/hr	4.178867	5.011077	4.733412



### SUMMARY OF EMISSIONS TEST DATA

Table : 2

Plant : Louisiana Pacific, Corrigan, TX

Location : Dryer #1 Exhaust

Operator : J. Dahlem, C. Jefferson, T. Armstrong

Test Date : 2-Jun-95

Repetition :	1	2	3
<b>STACK GAS</b>			
Temperature, F	195.2	196.6	195.4
Velocity, fps	37.21	37.14	37.39
Volume Flow, acfm	45215.1	45128.5	45433.5
scfm	23770.0	23806.7	25643.4
scfh	1426202	1428404	1538601
Moisture, %	33.10%	32.82%	28.19%
CO <sub>2</sub> , %	4.50	4.00	4.00
O <sub>2</sub> , %	16.00	16.00	16.00
<b>SAMPLE</b>			
Start Time, hrs:min	8:31 AM	10:13 AM	11:50 AM
Finish Time, hrs:min	9:33 AM	11:20 AM	12:55 PM
Sample Volume, scf	45.571	45.309	45.879
Isokinetic Ratio, %	109.9145	109.1144	102.5739
<b>VOC</b>			
Concentration as C <sub>3</sub> H <sub>8</sub> - WB	220.62	310.60	299.30
Concentration as C - WB, ppm	661.86	931.8	897.9
Concentration as C - DB	989.3909	1387.061	1250.445
Emissions as C, lbs/hr - DB	43.9586	61.62707	55.55722
<b>FORMALDEHYDE</b>			
Sample Weight, mg	16.69	18.84	4.25
Concentration, ppm	10.35575	11.69142	2.636573
Emissions, lbs/hr	1.151414	1.299922	0.29315

**SUMMARY OF EMISSIONS TEST DATA**

Table : 3

Plant : Louisiana Pacific, Corrigan, TX  
 Location : Dryer #2 Exhaust  
 Operator : M. Taylor, D. Barrera, R. Taylor  
 Test Date : 1-Jun-95

Repetition :	1	2	3
<b>STACK GAS</b>			
Temperature, F	213.5	213.2	216.8
Velocity, fps	42.99	42.88	42.36
Volume Flow, acfm	51267.3	51143.7	50517.6
scfm	31796.9	29874.0	30468.5
scfh	1907813	1792441	1828112
Moisture, %	18.75%	22.75%	19.77%
CO2, %	4.00	3.50	4.50
O2, %	18.00	17.00	16.50
<b>SAMPLE</b>			
Start Time, hrs:min	8:30 AM	10:13 AM	11:47 AM
Finish Time, hrs:min	9:37 AM	11:19 AM	12:52 PM
Sample Volume, scf	37.551	34.066	33.712
Isokinetic Ratio, %	109.2673	105.5088	102.3729
<b>PARTICULATE</b>			
Front Half			
Sample Weight, mg	212.56	279.97	203.00
Concentration, gr/scf	0.087343	0.12681	0.092914
Emissions, lbs/hr	23.81256	32.48193	24.27318
Back Half			
Sample Weight, mg	42.78	54.19	64.79
Concentration, gr/scf	0.017579	0.024545	0.029655
Emissions, lbs/hr	4.792535	6.287088	7.747091
Total Particulate, lbs/hr	28.60509	38.76902	32.02027
<b>CARBON MONOXIDE</b>			
Concentration, ppm	52.04	56.17	47.83
Emissions, lbs/hr	7.216804	7.318482	6.35587
<b>NITROGEN OXIDE AS NO2</b>			
Concentration, ppm	NM	18.49	28.84
Emissions, lbs/hr	NM	3.957795	6.296072

**SUMMARY OF EMISSIONS TEST DATA**

Table : 4

Plant : Louisiana Pacific, Corrigan, TX

Location : Dryer #2 Exhaust

Operator : M. Taylor, D. Barrera, R. Taylor

Test Date : 2-Jun-95

Repetition :	1	2	3
<b>STACK GAS</b>			
Temperature, F	208.8	208.1	208.5
Velocity, fps	44.04	42.45	43.97
Volume Flow, acfm	52519.5	50623.7	52443.5
scfm	32590.5	32149.6	33588.1
scfh	1955433	1928975	2015284
Moisture, %	18.36%	16.96%	16.31%
CO <sub>2</sub> , %	4.00	4.50	4.50
O <sub>2</sub> , %	17.50	16.00	17.00
<b>SAMPLE</b>			
Start Time, hrs:min	8:30 AM	10:13 AM	11:47 AM
Finish Time, hrs:min	9:37 AM	11:19 AM	12:52 PM
Sample Volume, scf	53.176	50.948	49.139
Isokinetic Ratio, %	101.875	98.94475	91.344
<b>VOC</b>			
Concentration as C <sub>3</sub> H <sub>8</sub> - WB	117.04	233.10	260.97
Concentration as C - WB, ppm	351.12	699.3	782.91
Concentration as C - DB	430.0947	842.1464	935.5245
Emissions as C, lbs/hr - DB	26.20004	51.30096	56.98926
<b>FORMALDEHYDE</b>			
Sample Weight, mg	15.44	8.27	3.83
Concentration, ppm	8.21453	4.399805	2.039271
Emissions, lbs/hr	1.25226	0.670726	0.310876
<b>NITROGEN OXIDE AS NO<sub>2</sub></b>			
Concentration, ppm	21.44	20.25	26.29
Emissions, lbs/hr	5.006558	4.664695	6.327009

**SUMMARY OF EMISSIONS TEST DATA**

Table : 5

Plant : Louisiana Pacific, Corrigan, TX

Location : Dryer #3 Exhaust

Operator : J. Salinas, J. Barrera

Test Date : 1-Jun-95

Repetition :	1	2	3
<b>STACK GAS</b>			
Temperature, F	145.3	147.6	151.8
Velocity, fps	67.50	67.33	66.58
Volume Flow, acfm	38964.6	38865.4	38434.7
scfm	27882.2	27541.8	26988.8
scfh	1672935	1652511	1619329
Moisture, %	15.84%	16.26%	16.49%
CO <sub>2</sub> , %	2.00	2.00	1.50
O <sub>2</sub> , %	18.00	17.50	17.00
<b>SAMPLE</b>			
Start Time, hrs:min	10:23 AM	2:43 PM	4:25 PM
Finish Time, hrs:min	11:38 AM	3:48 PM	5:30 PM
Sample Volume, scf	37.750	37.548	36.702
Isokinetic Ratio, %	102.3584	103.0676	102.8105
<b>PARTICULATE</b>			
Front Half			
Sample Weight, mg	264.45	229.64	220.60
Concentration, gr/scf	0.10809	0.094369	0.092743
Emissions, lbs/hr	25.84097	22.28509	21.46136
Back Half			
Sample Weight, mg	13.30	26.03	21.45
Concentration, gr/scf	0.005436	0.010697	0.009018
Emissions, lbs/hr	1.299621	2.526045	2.086791
Total Particulate, lbs/hr	27.14059	24.81114	23.54815
<b>CARBON MONOXIDE</b>			
Concentration, ppm	211.17	95.12	107.64
Emissions, lbs/hr	25.67929	11.42583	12.67011
<b>NITROGEN OXIDE AS NO<sub>2</sub></b>			
Concentration, ppm	17.51	20.02	20.56
Emissions, lbs/hr	3.498136	3.950753	3.975848

**SUMMARY OF EMISSIONS TEST DATA**

Table : 6

Plant : Louisiana Pacific, Corrigan, TX

Location : Dryer #3 Exhaust

Operator : J. Salinas, J. Barrera

Test Date : 2-Jun-95

Repetition :	1	2	3
<b>STACK GAS</b>			
Temperature, F	190.6	188.9	189.6
Velocity, fps	74.28	72.77	71.99
Volume Flow, acfm	42880.3	42009.5	41557.1
scfm	28489.5	27552.0	27489.8
scfh	1709370	1653123	1649385
Moisture, %	16.31%	17.62%	16.81%
CO <sub>2</sub> , %	1.50	2.50	2.50
O <sub>2</sub> , %	19.50	18.00	18.00
<b>SAMPLE</b>			
Start Time, hrs:min	8:30 AM	10:13 AM	11:45 AM
Finish Time, hrs:min	9:36 AM	11:16 AM	12:49 PM
Sample Volume, scf	58.097	56.241	55.359
isokinetic Ratio, %	105.3788	105.4835	104.064
<b>VOC</b>			
Concentration as C <sub>3</sub> H <sub>8</sub> - WB	163.38	183.44	192.50
Concentration as C - WB, ppm	490.14	550.32	577.5
Concentration as C - DB	585.6845	667.9986	694.169
Emissions as C, lbs/hr - DB	31.18853	35.57186	36.96548
<b>FORMALDEHYDE</b>			
Sample Weight, mg	9.94	10.99	7.26
Concentration, ppm	4.83918	5.347926	3.532017
Emissions, lbs/hr	0.644877	0.712673	0.470682

### III. PROCEDURES

The procedure for emissions sampling followed USEPA test methods as detailed in Title 40: Code of Federal Regulations. The following methods were used:

<u>Method</u>	<u>Title</u>
1	Sample and Velocity Traverses for Stationary Sources
2	Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)
3	Gas Analysis for CO <sub>2</sub> , O <sub>2</sub> , Excess Air and Dry Molecular Weight
4	Determination of Moisture Content in Stack Gases
5	Determination of Particulate Emissions from Stationary Sources
7E	Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure)
10	Determination of Carbon Monoxide Emission from Stationary Sources
25A	Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer
0011	Sampling for Aldehyde and Ketone Emissions from Stationary Sources

O<sub>2</sub> and CO<sub>2</sub> were determined using Fyrite Analyzers.

Sampling was performed on the three dryer exhausts using the following test matrix:


Dryer #	1	2	3
<b>PM, Nox, CO</b>			
Sample Train	Apex	Apex	Apex
Sample Points	25	20	16
Duration, minutes	62.5	60	64
Minutes/point	2.5	3	4
Nozzle Size, inches	0.250	0.2563	0.191
Nozzle Material	Stainless	Stainless	Stainless
Probe Liner	Teflon	Teflon	Teflon
Impinger Solution	H <sub>2</sub> O	H <sub>2</sub> O	H <sub>2</sub> O
<b>VOC, Formaldehyde</b>			
Sample Train	Apex	Apex	Apex
Sample Points	25	20	16

Duration, minutes	62.5	60	60
Minutes/point	2.5	3	3.75
Nozzle Size, inches	0.322	0.312	0.2386
Nozzle Material	Glass	Glass	Glass
Probe Liner	Teflon	Teflon	Teflon
Impinger Solution	DNPH	DNPH	DNPH

CEM data was taken using heated teflon sample lines and manifolds. The following matrix was used:

Dryer #	1	2	3
CO Analyzer	Fuji NDIR	Fuji NDIR	Fuji NDIR
CO Standards, ppm in N2	391	400	400
(Certified +/- 2%)	250	100	98
	98	50.5	50.5
Nox Analyzer	Teco 10	Teco 10	Teco 10
Nox Standards, NO in N2, ppm	112	95.8	95.8
(EPA Protocol 1)	254	50.8	50.8
VOC analyzer (FID)	Teco 51	Teco 51	Teco 51
VOC Standards, C3H8 in N2, ppm	495	909	200
(EPA Protocol 1)	203	495	104.8
	50.5	200	29.98

All analyzers were zeroed with N2. A schematic of CEM flow is included.





APPENDIX A

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #1 Exhaust  
 RUN# : 1

TEST DURATION (MINUTES) :	62.5	LIQUID COLLECTED (mls) :	127.8
NOZZLE DIAMETER (INCH.) :	0.25	PARTICULATE WEIGHT (Front half mg) :	205.35
METER COEFFICIENT (Y) :	1.01279	PARTICULATE WEIGHT (Back half mg) :	29.35
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-8.7
GAS METER VOL.(Cu.Ft.) :	35.326	PERCENT CO2 :	2.5
BAROMETRIC PRESSURE :	29.85	PERCENT O2 :	16.5
		PERCENT CO :	0

FOR CIRCULAR STACK		FOR RECTANGULAR STACK	
STACK DIAMETER (Inch):	20.25	STACK LENGTH(Inchs) :	54
STACK AREA (Sq.Ft.) :	2.236544	STACK WIDTH(Inchs) :	54
NOZZLE AREA (feet):	0.000341	STACK AREA (Sq.Ft.):	20.25

ENTER THE STACK AREA SHOWN ABOVE: 20.25

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	35.0116
VOLUME OF WATER VAPOR (STD. CU.FT.):	6.0155
FRACTIONAL MOISTURE CONTENT (%):	0.1466
DRY BASE:	81.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.0600
MOLECULAR WT. OF STACK GAS (WET BASE):	27.4383
STACK PRESSURE (inch Hg):	29.1368
STACK GAS VELOCITY (ft/sec.):	39.6339
ACTUAL STACK GAS FLOW RATE (ACFM):	48155.1949
STANDARD STACK GAS FLOW RATE (SCFH):	1930141.47

**PARTICULATE**

FRONT HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0905
PARTICULATE CONCENTRATION (LBS/SCF):	1.29E-05
PARTICULATE EMISSION (LBS/HR):	24.9621

BACK HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0129
PARTICULATE CONCENTRATION (LBS/SCF):	1.85E-06
PARTICULATE EMISSION (LBS/HR):	3.5677

ISOKINETIC RATIO (%): 103.5112

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	196	0.18	0.424264	0.45	75	74	
2	197	0.18	0.424264	0.45	75	74	
3	197	0.19	0.435889	0.46	76	74	
4	198	0.23	0.479583	0.55	76	74	
5	198	0.25	0.5	0.60	77	75	
6	196	0.22	0.469042	0.53	78	75	
7	197	0.24	0.489898	0.57	78	75	
8	197	0.26	0.509902	0.62	79	76	
9	198	0.33	0.574456	0.79	80	76	
10	197	0.39	0.6245	0.94	81	76	
11	196	0.23	0.479583	0.55	80	76	
12	197	0.24	0.489898	0.57	81	77	
13	198	0.31	0.556776	0.74	82	78	
14	197	0.43	0.655744	1.00	82	78	
15	197	0.54	0.734847	1.30	82	79	
16	196	0.35	0.591608	0.84	83	79	
17	197	0.49	0.7	1.20	82	80	
18	198	0.54	0.734847	1.30	83	80	
19	197	0.65	0.806226	1.60	84	80	
20	196	0.68	0.824621	1.60	84	80	
21	196	0.41	0.640312	0.98	85	81	
22	197	0.46	0.678233	1.10	85	81	
23	196	0.57	0.754983	1.40	85	81	METER T.
24	196	0.65	0.806226	1.60	85	82	AVERAGE
25	196	0.70	0.83666	1.70	85	82	
	196.84		0.6089	0.9376	80.9200	77.7200	79.3200

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-85  
 PLACE : Dryer #1 Exhaust  
 RUN# : 2

TEST DURATION (MINUTES) :	62.5	LIQUID COLLECTED (mls) :	184.9
NOZZLE DIAMETER (INCH.) :	0.25	PARTICULATE WEIGHT (Front half mg) :	302.76
METER COEFFICIENT (Y) :	1.01279	PARTICULATE WEIGHT (Back half mg) :	31.28
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9.6
GAS METER VOL.(Cu.Ft.) :	31.874	PERCENT CO2 :	4
BAROMETRIC PRESSURE :	29.85	PERCENT O2 :	16
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK		
STACK DIAMETER (Inch):	20.25	STACK LENGTH(inches) :	
STACK AREA (Sq.Ft.) :	2.236544	STACK WIDTH(inches) :	
NOZZLE AREA (feet):	0.000341	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 20.25

**FLOW**

SAMPLED VOLUME (STD. CU.FT.):	31.1006
VOLUME OF WATER VAPOR (STD. CU.FT.):	8.7032
FRACTIONAL MOISTURE CONTENT (%):	0.2187
DRY BASE:	80.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.2800
MOLECULAR WT. OF STACK GAS (WET BASE):	26.8136
STACK PRESSURE (inch Hg):	29.1441
STACK GAS VELOCITY (ft/sec.):	37.7096
ACTUAL STACK GAS FLOW RATE (ACFM):	45817.1425
STANDARD STACK GAS FLOW RATE (SCFH):	1685233.98

**PARTICULATE**

FRONT HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.1502
PARTICULATE CONCENTRATION (LBS/SCF):	2.15E-05
PARTICULATE EMISSION (LBS/HR):	36.1742

BACK HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0155
PARTICULATE CONCENTRATION (LBS/SCF):	2.22E-06
PARTICULATE EMISSION (LBS/HR):	3.7374

ISOKINETIC RATIO (%): 105.3125

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	196	0.12	0.34841	0.26	82	82
2	197	0.13	0.360555	0.29	84	84
3	194	0.16	0.4	0.35	85	84
4	195	0.19	0.43589	0.42	86	84
5	197	0.23	0.479583	0.50	87	85
6	195	0.16	0.4	0.35	87	85
7	194	0.18	0.424264	0.40	87	85
8	196	0.25	0.5	0.55	88	85
9	197	0.35	0.591608	0.77	88	85
10	195	0.35	0.591608	0.77	89	85
11	195	0.22	0.469042	0.48	88	85
12	196	0.23	0.479583	0.50	88	86
13	197	0.32	0.565685	0.70	88	86
14	197	0.40	0.632456	0.88	89	87
15	196	0.49	0.7	1.10	90	87
16	195	0.30	0.547723	0.66	90	87
17	194	0.33	0.574456	0.72	90	88
18	194	0.42	0.648074	0.92	91	88
19	195	0.53	0.728011	1.20	91	88
20	196	0.65	0.806226	1.40	91	89
21	195	0.38	0.616441	0.83	92	89
22	196	0.44	0.663325	0.96	92	89
23	195	0.56	0.748331	1.20	92	89
24	195	0.63	0.793725	1.40	92	89
25	196	0.69	0.830662	1.50	92	89
	195.52		0.5733	0.7644	88.7600	86.4000
						87.5900

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #1 Exhaust  
 RUN# : 3

TEST DURATION (MINUTES) :	62.5	LIQUID COLLECTED (mls) :	162.2
NOZZLE DIAMETER (INCH.) :	0.25	PARTICULATE WEIGHT (Front half mg) :	252.2
METER COEFFICIENT (Y) :	1.01279	PARTICULATE WEIGHT (Back half mg) :	34.1
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9.6
GAS METER VOL.(Cu.Ft.) :	30.807	PERCENT CO2 :	3.5
BAROMETRIC PRESSURE :	29.85	PERCENT O2 :	14
		PERCENT CO :	0

FOR CIRCULAR STACK		FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	20.25	STACK LENGTH(inchs) :	
STACK AREA (Sq.Ft.) :	2.236544	STACK WIDTH(inchs) :	
NOZZLE AREA (feet):	0.000341	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 20.25

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	29.9208
VOLUME OF WATER VAPOR (STD. CU.FT.):	7.6348
FRACTIONAL MOISTURE CONTENT (%):	0.2033
DRY BASE:	82.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.1200
MOLECULAR WT. OF STACK GAS (WET BASE):	26.8594
STACK PRESSURE (inch Hg):	29.1441
STACK GAS VELOCITY (ft/sec.):	37.7822
ACTUAL STACK GAS FLOW RATE (ACFM):	45905.3124
STANDARD STACK GAS FLOW RATE (SCFH):	1723355.52

**PARTICULATE**

FRONT HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.1301
PARTICULATE CONCENTRATION (LBS/SCF):	1.86E-05
PARTICULATE EMISSION (LBS/HR):	32.0298

BACK HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0176
PARTICULATE CONCENTRATION (LBS/SCF):	2.51E-06
PARTICULATE EMISSION (LBS/HR):	4.3308

ISOKINETIC RATIO (%): 99.0762

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	196	0.18	0.424264	0.41	88	88	
2	197	0.15	0.387298	0.35	89	88	
3	197	0.16	0.4	0.37	89	88	
4	197	0.18	0.424264	0.41	89	88	
5	196	0.26	0.509902	0.59	90	88	
6	197	0.19	0.43589	0.44	91	88	
7	196	0.20	0.447214	0.46	91	88	
8	196	0.26	0.509902	0.46	91	88	
9	195	0.32	0.565685	0.60	92	88	
10	195	0.40	0.632456	0.92	92	89	
11	195	0.20	0.447214	0.46	93	89	
12	196	0.22	0.469042	0.51	93	89	
13	195	0.26	0.509902	0.59	92	89	
14	195	0.36	0.6	0.83	92	89	
15	194	0.47	0.685565	1.10	92	89	
16	194	0.32	0.565685	0.73	92	90	
17	194	0.30	0.547723	0.69	92	90	
18	195	0.37	0.608276	0.85	92	90	
19	194	0.52	0.72111	1.20	92	90	
20	193	0.65	0.806226	1.50	92	90	
21	194	0.41	0.640312	0.94	92	90	
22	193	0.44	0.663325	1.00	92	90	
23	193	0.56	0.748331	1.30	92	90	METER T.
24	193	0.66	0.812404	1.60	92	90	AVERAGE
25	192	0.67	0.818535	1.60	91	89	
	194.88		0.5752	0.7964	91.3200	89.0000	90.1600

### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 2-Jun-95  
 PLACE : Dryer #1 Exhaust  
 RUN# : 3

TEST DURATION (MINUTES) :	62.5	LIQUID COLLECTED (mls) :	382.7
NOZZLE DIAMETER (INCH.) :	0.322	PARTICULATE WEIGHT (Front half mg) :	0
METER COEFFICIENT (Y) :	1.01279	PARTICULATE WEIGHT (Back half mg) :	0
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9.6
GAS METER VOL.(Cu.Ft.) :	46.989	PERCENT CO2 :	4
BAROMETRIC PRESSURE :	29.9	PERCENT O2 :	16
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	0	STACK LENGTH(inchs) :
STACK AREA (Sq.Ft.) :	0	STACK WIDTH(inchs) :
NOZZLE AREA (feet):	0.000566	STACK AREA (Sq.Ft.) :

ENTER THE STACK AREA SHOWN ABOVE: 20.25

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	45.8793
VOLUME OF WATER VAPOR (STD. CU.FT.):	18.0137
FRACTIONAL MOISTURE CONTENT (%):	0.2819
DRY BASE:	80.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.2800
MOLECULAR WT. OF STACK GAS (WET BASE):	26.0998
STACK PRESSURE (inch Hg):	29.1941
STACK GAS VELOCITY (ft/sec.):	37.3939
ACTUAL STACK GAS FLOW RATE (ACFM):	45433.5442
STANDARD STACK GAS FLOW RATE (SCFH):	1538601.19
ISOKINETIC RATIO (%):	102.5739

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	197	0.19	0.43589	0.94	88	88	
2	196	0.17	0.412311	0.84	88	88	
3	196	0.18	0.424264	0.89	88	88	
4	196	0.23	0.479583	1.10	89	88	
5	195	0.25	0.5	1.20	89	88	
6	195	0.16	0.4	0.79	89	88	
7	196	0.17	0.412311	0.85	89	88	
8	197	0.25	0.5	1.20	89	88	
9	196	0.31	0.556776	1.50	90	88	
10	195	0.35	0.591608	1.70	90	88	
11	194	0.24	0.489898	1.20	91	88	
12	195	0.30	0.547723	1.50	91	89	
13	196	0.40	0.632456	1.90	91	89	
14	194	0.35	0.591608	1.70	91	89	
15	195	0.34	0.583095	1.70	91	89	
16	194	0.30	0.547723	1.50	91	89	
17	195	0.35	0.591608	1.70	91	89	
18	196	0.40	0.632456	1.90	91	89	
19	197	0.40	0.632456	1.90	91	89	
20	195	0.45	0.67082	2.20	90	89	
21	194	0.32	0.565685	1.60	90	89	
22	196	0.33	0.574456	1.60	90	89	
23	196	0.51	0.714143	2.50	90	89	METER T.
24	196	0.60	0.774597	2.90	90	89	AVERAGE
25	194	0.60	0.774597	2.90	90	89	
	195.44		0.5614	1.5884	89.9200	88.5600	89.2400

### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 2-Jun-95  
 PLACE : Dryer #1 Exhaust  
 RUN# : 2

TEST DURATION (MINUTES) :	62.5	LIQUID COLLECTED (mls) :	470.3
NOZZLE DIAMETER (INCH.) :	0.322	PARTICULATE WEIGHT (Front half mg) :	0
METER COEFFICIENT (Y) :	1.01279	PARTICULATE WEIGHT (Back half mg) :	0
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9.3
GAS METER VOL.(Cu.Ft.) :	46.181	PERCENT CO2 :	4
BAROMETRIC PRESSURE :	29.9	PERCENT O2 :	16
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK		
STACK DIAMETER (Inch):	0	STACK LENGTH(inches) :	
STACK AREA (Sq.Ft.) :	0	STACK WIDTH(inches) :	
NOZZLE AREA (feet):	0.00057	STACK AREA (Sq.Ft.):	0

ENTER THE STACK AREA SHOWN ABOVE: 20.25

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	45.3087
VOLUME OF WATER VAPOR (STD. CU.FT.):	22.1370
FRACTIONAL MOISTURE CONTENT (%):	0.3282
DRY BASE:	80.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.2800
MOLECULAR WT. OF STACK GAS (WET BASE):	25.5777

STACK PRESSURE (inch Hg):	29.2162
STACK GAS VELOCITY (ft/sec.):	37.1428
ACTUAL STACK GAS FLOW RATE (ACFM):	45128.5459
STANDARD STACK GAS FLOW RATE (SCFH):	1428404

ISOKINETIC RATIO (%): 109.1144

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	197	0.12	0.34641	0.60	82	82	
2	196	0.13	0.36056	0.65	85	83	
3	197	0.15	0.3873	0.75	85	83	
4	198	0.18	0.42426	0.90	86	83	
5	197	0.29	0.53852	1.40	87	84	
6	198	0.16	0.4	0.80	88	84	
7	197	0.17	0.41231	0.84	88	84	
8	197	0.24	0.4899	1.20	87	84	
9	196	0.32	0.56569	1.60	87	85	
10	197	0.37	0.60828	1.80	88	85	
11	196	0.22	0.46904	1.10	88	85	
12	195	0.20	0.44721	1.00	88	85	
13	197	0.26	0.5099	1.30	88	85	
14	198	0.40	0.63246	2.00	89	85	
15	195	0.44	0.66332	2.20	90	86	
16	196	0.32	0.56569	1.60	90	86	
17	196	0.29	0.53852	1.40	89	86	
18	195	0.36	0.6	1.80	89	86	
19	196	0.54	0.73485	2.70	89	86	
20	196	0.50	0.70711	2.50	89	87	
21	197	0.34	0.5831	1.70	89	87	
22	198	0.33	0.57446	1.60	89	87	
23	198	0.43	0.65574	2.10	90	87	METER T.
24	196	0.59	0.76811	3.00	90	87	AVERAGE
25	195	0.66	0.8124	3.30	91	87	
	196.56		0.5518	1.5936	88.0400	85.1600	86.6000

### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 2-Jun-95  
 PLACE : Dryer #1 Exhaust  
 RUN# : 1

TEST DURATION (MINUTES) :	62.5	LIQUID COLLECTED (mls) :	479.1
NOZZLE DIAMETER (INCH.) :	0.322	PARTICULATE WEIGHT (Front half mg) :	0
METER COEFFICIENT (Y) :	1.01279	PARTICULATE WEIGHT (Back half mg) :	0
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9.8
GAS METER VOL.(Cu.Ft.) :	45.813	PERCENT CO2 :	4.5
BAROMETRIC PRESSURE :	29.9	PERCENT O2 :	16
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK		
STACK DIAMETER (inch):	0	STACK LENGTH(inchs) :	
STACK AREA (Sq.Ft.) :	0	STACK WIDTH(inchs) :	
NOZZLE AREA (feet):	0.000566	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 20.25

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	45.5705
VOLUME OF WATER VAPOR (STD. CU.FT.):	22.5512
FRACTIONAL MOISTURE CONTENT (%):	0.3310
DRY BASE:	79.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.3600
MOLECULAR WT. OF STACK GAS (WET BASE):	25.5994
STACK PRESSURE (inch Hg):	29.1794
STACK GAS VELOCITY (ft/sec.):	37.2140
ACTUAL STACK GAS FLOW RATE (ACFM):	45215.0558
STANDARD STACK GAS FLOW RATE (SCFH):	1426201.85
ISOKINETIC RATIO (%):	109.9145

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	195	0.18	0.424264	0.89	75	74	
2	195	0.15	0.387298	0.75	76	74	
3	196	0.23	0.479583	1.10	76	74	
4	196	0.25	0.5	1.20	78	75	
5	195	0.26	0.509902	1.30	79	75	
6	194	0.21	0.458258	1.00	79	76	
7	195	0.18	0.424264	0.89	80	76	
8	195	0.20	0.447214	0.99	81	77	
9	196	0.28	0.52915	1.40	81	77	
10	195	0.36	0.6	1.80	81	77	
11	196	0.22	0.469042	1.10	81	78	
12	196	0.23	0.479583	1.10	81	78	
13	196	0.25	0.5	1.20	81	78	
14	195	0.37	0.608276	1.80	81	78	
15	195	0.44	0.663325	2.20	81	78	
16	194	0.23	0.479583	1.10	82	79	
17	195	0.25	0.5	1.20	82	79	
18	196	0.31	0.556776	1.50	82	79	
19	195	0.40	0.632456	1.90	82	79	
20	194	0.60	0.774597	2.90	82	79	
21	195	0.35	0.591608	1.70	82	80	
22	195	0.33	0.574456	1.60	82	80	
23	196	0.43	0.655744	2.10	83	80	METER T.
24	195	0.61	0.781025	3.00	83	80	AVERAGE
25	196	0.65	0.806226	3.20	83	80	
	195.24		0.5533	1.5568	80.5600	77.6000	79.0800

### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Comgan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #2 Exhaust  
 RUN# : 1

TEST DURATION (MINUTES) :	60	LIQUID COLLECTED (mls) :	184.1
NOZZLE DIAMETER (INCH.) :	0.2563	PARTICULATE WEIGHT (Front half mg) :	212.56
METER COEFFICIENT (Y) :	1.00418	PARTICULATE WEIGHT (Back half mg) :	42.78
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9.1
GAS METER VOL.(Cu.Ft.) :	38.172	PERCENT CO2 :	4
BAROMETRIC PRESSURE :	29.8	PERCENT O2 :	18
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	0	STACK LENGTH(inchs) : 53.5
STACK AREA (Sq.Ft.) :	0	STACK WIDTH(inchs) : 53.5
NOZZLE AREA (feet):	0.000358	STACK AREA (Sq.Ft.) : 19.87674

ENTER THE STACK AREA SHOWN ABOVE: 19.877

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	37.5509
VOLUME OF WATER VAPOR (STD. CU.FT.):	8.6656
FRACTIONAL MOISTURE CONTENT (%):	0.1875
DRY BASE:	78.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.3600
MOLECULAR WT. OF STACK GAS (WET BASE):	27.2300
STACK PRESSURE (inch Hg):	29.1309
STACK GAS VELOCITY (ft/sec.):	42.9871
ACTUAL STACK GAS FLOW RATE (ACFM):	51267.3263
STANDARD STACK GAS FLOW RATE (SCFH):	1907813.38

#### PARTICULATE

FRONT HALF	
PARTICULATE CONCENTRATION (GR./SCF):	0.0873
PARTICULATE CONCENTRATION (LBS/SCF):	1.25E-05
PARTICULATE EMISSION (LBS/HR):	23.8126
BACK HALF	
PARTICULATE CONCENTRATION (GR./SCF):	0.0176
PARTICULATE CONCENTRATION (LBS/SCF):	2.51E-06
PARTICULATE EMISSION (LBS/HR):	4.7925
ISOKINETIC RATIO (%):	109.2673

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	230	0.47	0.685565	2.00	70	70
2	229	0.64	0.8	1.90	74	70
3	224	0.61	0.781025	1.80	78	71
4	202	0.60	0.774597	1.70	80	71
5	210	0.31	0.556776	1.00	78	72
6	230	0.41	0.640312	1.30	80	73
7	226	0.49	0.7	1.50	82	73
8	173	0.59	0.768115	2.00	84	74
9	226	0.22	0.469042	0.70	80	75
10	232	0.32	0.565685	0.80	83	75
11	228	0.43	0.655744	1.30	85	76
12	158	0.58	0.761577	1.70	87	76
13	219	0.21	0.458258	0.70	81	77
14	232	0.27	0.519615	0.90	84	77
15	228	0.41	0.640312	1.40	87	78
16	183	0.55	0.74162	1.50	88	78
17	218	0.18	0.424264	0.80	85	79
18	222	0.35	0.591608	0.80	87	79
19	226	0.46	0.678233	1.30	79	78
20	173	0.61	0.781025	1.70	83	78
	213.45		0.6497	1.3400	81.7500	75.0000 78.3750



### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Comigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #2 Exhaust  
 RUN# : 2

TEST DURATION (MINUTES) :	60	LIQUID COLLECTED (mls) :	213.1
NOZZLE DIAMETER (INCH.) :	0.2563	PARTICULATE WEIGHT (Front half mg) :	279.97
METER COEFFICIENT (Y) :	1.00418	PARTICULATE WEIGHT (Back half mg) :	54.19
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-13
GAS METER VOL.(Cu.Ft.) :	35.263	PERCENT CO2 :	3.5
BAROMETRIC PRESSURE :	29.8	PERCENT O2 :	17
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	0	STACK LENGTH(inches) : 53.5
STACK AREA (Sq.Ft.) :	0	STACK WIDTH(Inches) : 53.5
NOZZLE AREA (feet):	0.000358	STACK AREA (Sq.Ft.) : 19.87674

ENTER THE STACK AREA SHOWN ABOVE: 19.877

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	34.0662
VOLUME OF WATER VAPOR (STD. CU.FT.):	10.0306
FRACTIONAL MOISTURE CONTENT (%):	0.2275
DRY BASE:	79.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.2400
MOLECULAR WT. OF STACK GAS (WET BASE):	26.6833
STACK PRESSURE (inch Hg):	28.8441
STACK GAS VELOCITY (ft/sec.):	42.8835
ACTUAL STACK GAS FLOW RATE (ACFM):	51143.6602
STANDARD STACK GAS FLOW RATE (SCFH):	1792440.92

#### PARTICULATE

FRONT HALF	
PARTICULATE CONCENTRATION (GR./SCF):	0.1268
PARTICULATE CONCENTRATION (LBS/SCF):	1.81E-05
PARTICULATE EMISSION (LBS/HR):	32.4819
BACK HALF	
PARTICULATE CONCENTRATION (GR./SCF):	0.0245
PARTICULATE CONCENTRATION (LBS/SCF):	3.51E-06
PARTICULATE EMISSION (LBS/HR):	6.2871
ISOKINETIC RATIO (%):	105.5088

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	225	0.60	0.774597	1.60	81	81
2	223	0.61	0.781025	1.60	83	81
3	225	0.56	0.748331	1.50	87	82
4	193	0.59	0.768115	1.60	89	82
5	210	0.31	0.556776	0.80	87	83
6	230	0.41	0.640312	1.10	90	83
7	228	0.46	0.678233	1.20	92	84
8	144	0.64	0.8	1.70	93	84
9	211	0.21	0.458258	0.60	88	85
10	229	0.29	0.538516	0.80	91	85
11	225	0.42	0.648074	1.10	94	86
12	198	0.54	0.734847	1.50	95	86
13	217	0.20	0.447214	0.50	89	87
14	231	0.27	0.519615	0.70	93	87
15	228	0.42	0.648074	1.10	94	87
16	161	0.52	0.72111	1.40	95	87
17	200	0.22	0.469042	0.60	90	87
18	231	0.27	0.519615	0.70	93	87
19	228	0.41	0.640312	1.10	96	88
20	227	0.46	0.678233	1.20	97	88
	213.2		0.6385	1.1200	90.8500	85.0000
						87.9250

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #2 Exhaust  
 RUN# : 3

TEST DURATION (MINUTES) :	60	LIQUID COLLECTED (mls) :	176.5
NOZZLE DIAMETER (INCH.) :	0.2563	PARTICULATE WEIGHT (Front half mg)	203
METER COEFFICIENT (Y) :	1.00418	PARTICULATE WEIGHT (Back half mg)	64.79
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-13.2
GAS METER VOL. (Cu.Ft.) :	35.02	PERCENT CO2 :	4.5
BAROMETRIC PRESSURE :	29.8	PERCENT O2 :	16.5
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK		
STACK DIAMETER (inch):	0	STACK LENGTH(inchs):	
STACK AREA (Sq.Ft.) :	0	STACK WIDTH(inchs):	
NOZZLE AREA (feet):	0.00036	STACK AREA (Sq.Ft.):	0

ENTER THE STACK AREA SHOWN ABOVE: 19.877

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	33.7117
VOLUME OF WATER VAPOR (STD. CU.FT.):	8.3079
FRACTIONAL MOISTURE CONTENT (%):	0.1977
DRY BASE:	79.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.3800
MOLECULAR WT. OF STACK GAS (WET BASE):	27.1300
STACK PRESSURE (inch Hg):	28.8294
STACK GAS VELOCITY (ft/sec.):	42.3585
ACTUAL STACK GAS FLOW RATE (ACFM):	50517.5821
STANDARD STACK GAS FLOW RATE (SCFH):	1828112.4

**PARTICULATE**

FRONT HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0929
PARTICULATE CONCENTRATION (LBS/SCF):	1.33E-05
PARTICULATE EMISSION (LBS/HR):	24.2732

BACK HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0297
PARTICULATE CONCENTRATION (LBS/SCF):	4.24E-06
PARTICULATE EMISSION (LBS/HR):	7.7471

ISOKINETIC RATIO (%): 102.3729

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	222	0.61	0.78102	1.60	87	86
2	230	0.58	0.76158	1.60	89	86
3	229	0.55	0.74162	1.50	91	86
4	222	0.49	0.7	1.30	93	86
5	228	0.41	0.64031	1.10	88	86
6	230	0.46	0.67823	1.20	91	86
7	220	0.39	0.6245	1.10	94	86
8	193	0.52	0.72111	1.40	95	86
9	221	0.20	0.44721	0.50	90	87
10	233	0.31	0.55678	0.80	93	87
11	227	0.40	0.63246	1.10	95	87
12	195	0.61	0.78102	1.60	97	88
13	222	0.19	0.43589	0.50	91	88
14	233	0.25	0.5	0.60	93	88
15	228	0.41	0.64031	1.10	95	88
16	152	0.51	0.71414	1.40	97	88
17	205	0.20	0.44721	0.50	90	88
18	232	0.26	0.50999	0.70	93	88
19	228	0.42	0.64807	1.10	95	88
20	185	0.52	0.72111	1.40	96	88
	216.75		0.6341	1.1050	92.6500	87.0500
						89.8500

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #3 Exhaust  
 RUN# : 3

TEST DURATION (MINUTES) :	64	LIQUID COLLECTED (mls) :	154
NOZZLE DIAMETER (INCH.) :	0.191	PARTICULATE WEIGHT (Front half mg) :	220.6
METER COEFFICIENT (Y) :	0.98893	PARTICULATE WEIGHT (Back half mg) :	21.45
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-8.8
GAS METER VOL.(Cu.Ft.) :	39.594	PERCENT CO2 :	1.5
BAROMETRIC PRESSURE :	29.8	PERCENT O2 :	17
		PERCENT CO :	0

FOR CIRCULAR STACK		FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	42	STACK LENGTH(inchs) :	
STACK AREA (Sq.Ft.) :	9.62113	STACK WIDTH(inchs) :	
NOZZLE AREA (feet):	0.0002	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 9.62113

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	36.7022
VOLUME OF WATER VAPOR (STD. CU.FT.):	7.2488
FRACTIONAL MOISTURE CONTENT (%):	0.1649
DRY BASE:	81.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	28.9200
MOLECULAR WT. OF STACK GAS (WET BASE):	27.1190
STACK PRESSURE (inch Hg):	29.1529
STACK GAS VELOCITY (ft/sec.):	66.5805
ACTUAL STACK GAS FLOW RATE (ACFM):	38434.7406
STANDARD STACK GAS FLOW RATE (SCFH):	1619328.95

**PARTICULATE**

FRONT HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0927
PARTICULATE CONCENTRATION (LBS/SCF):	1.33E-05
PARTICULATE EMISSION (LBS/HR):	21.4614

BACK HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0090
PARTICULATE CONCENTRATION (LBS/SCF):	1.29E-06
PARTICULATE EMISSION (LBS/HR):	2.0868

ISOKINETIC RATIO (%): 102.8105

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	159	1.00	1	1.09	98	98
2	165	1.10	1.04881	1.20	100	98
3	166	1.20	1.09545	1.31	104	98
4	167	1.20	1.09545	1.31	105	98
5	164	1.20	1.09545	1.31	107	98
6	155	1.10	1.04881	1.20	107	99
7	139	1.10	1.04881	1.20	108	99
8	110	0.82	0.90554	0.90	107	100
9	145	0.82	0.90554	0.90	100	100
10	160	1.30	1.14018	1.42	105	100
11	159	1.30	1.14018	1.42	102	100
12	161	1.30	1.14018	1.42	109	101
13	156	1.20	1.09545	1.31	109	101
14	153	1.20	1.09545	1.31	109	101
15	139	1.10	1.04881	1.20	108	101
16	131	0.92	0.95917	1.01	108	102
	151.8125		1.0540	1.2194	105.3750	99.6250 102.5000

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #3 Exhaust  
 RUN# : 2

TEST DURATION (MINUTES) :	64	LIQUID COLLECTED (mls) :	154.9
NOZZLE DIAMETER (INCH.) :	0.191	PARTICULATE WEIGHT (Front half mg) :	229.64
METER COEFFICIENT (Y) :	0.98893	PARTICULATE WEIGHT (Back half mg) :	26.03
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-9
GAS METER VOL.(Cu.Ft.) :	40.246	PERCENT CO2 :	2
BAROMETRIC PRESSURE :	29.8	PERCENT O2 :	17.5
		PERCENT CO :	0

FOR CIRCULAR STACK		FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	42	STACK LENGTH(inches) :	
STACK AREA (Sq.Ft.) :	9.62113	STACK WIDTH(inches) :	
NOZZLE AREA (feet):	0.0002	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 9.62113

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	37.5479
VOLUME OF WATER VAPOR (STD. CU.FT.):	7.2911
FRACTIONAL MOISTURE CONTENT (%):	0.1626
DRY BASE:	80.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.0200
MOLECULAR WT. OF STACK GAS (WET BASE):	27.2281
STACK PRESSURE (inch Hg):	29.1382
STACK GAS VELOCITY (ft/sec.):	67.3266
ACTUAL STACK GAS FLOW RATE (ACFM):	38865.4496
STANDARD STACK GAS FLOW RATE (SCFH):	1652510.63

**PARTICULATE**

<b>FRONT HALF</b>	
PARTICULATE CONCENTRATION (GR./SCF):	0.0944
PARTICULATE CONCENTRATION (LBS/SCF):	1.35E-06
PARTICULATE EMISSION (LBS/HR):	22.2851
<b>BACK HALF</b>	
PARTICULATE CONCENTRATION (GR./SCF):	0.0107
PARTICULATE CONCENTRATION (LBS/SCF):	1.53E-06
PARTICULATE EMISSION (LBS/HR):	2.5260
ISOKINETIC RATIO (%):	103.0676

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	154	1.00	1	1.09	92	92
2	151	1.30	1.14018	1.42	95	92
3	152	1.30	1.14018	1.42	99	92
4	151	1.30	1.14018	1.42	100	93
5	149	1.20	1.09545	1.31	102	94
6	152	1.10	1.04881	1.20	103	95
7	142	1.10	1.04881	1.20	103	95
8	136	0.84	0.91652	0.92	104	96
9	144	1.00	1	1.09	98	97
10	149	1.20	1.09545	1.31	103	97
11	146	1.30	1.14018	1.42	105	98
12	150	1.20	1.09545	1.31	106	98
13	155	1.20	1.09545	1.31	106	99
14	149	1.20	1.09545	1.31	105	99
15	148	1.30	1.14018	1.42	105	99
16	134	0.90	0.94868	0.98	105	99
	147.625		1.0713	1.2581	101.9375	95.9375 98.9375

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 1-Jun-95  
 PLACE : Dryer #3 Exhaust  
 RUN# : 1

TEST DURATION (MINUTES) :	64	LIQUID COLLECTED (mls) :	150.9
NOZZLE DIAMETER (INCH.) :	0.191	PARTICULATE WEIGHT (Front half mg) :	264.45
METER COEFFICIENT (Y) :	0.98893	PARTICULATE WEIGHT (Back half mg) :	13.3
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-8.7
GAS METER VOL.(Cu.Ft.) :	39.854	PERCENT CO2 :	2
BAROMETRIC PRESSURE :	29.8	PERCENT O2 :	18
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK		
STACK DIAMETER (inch):	42	STACK LENGTH(inchs) :	
STACK AREA (Sq.Ft.) :	9.62113	STACK WIDTH(inchs) :	
NOZZLE AREA (feet):	0.0002	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 9.62113

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	37.7505
VOLUME OF WATER VAPOR (STD. CU.FT.):	7.1029
FRACTIONAL MOISTURE CONTENT (%):	0.1584
DRY BASE:	80.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.0400
MOLECULAR WT. OF STACK GAS (WET BASE):	27.2917
STACK PRESSURE (inch Hg):	29.1603
STACK GAS VELOCITY (ft/sec.):	67.4984
ACTUAL STACK GAS FLOW RATE (ACFM):	38964.6445
STANDARD STACK GAS FLOW RATE (SCFH):	1672934.94

**PARTICULATE**

<b>FRONT HALF</b>	
PARTICULATE CONCENTRATION (GR./SCF):	0.1081
PARTICULATE CONCENTRATION (LBS/SCF):	1.54E-05
PARTICULATE EMISSION (LBS/HR):	25.8410
<b>BACK HALF</b>	
PARTICULATE CONCENTRATION (GR./SCF):	0.0054
PARTICULATE CONCENTRATION (LBS/SCF):	7.77E-07
PARTICULATE EMISSION (LBS/HR):	1.2996
ISOKINETIC RATIO (%):	102.3584

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	157	1.10	1.04881	1.17	86	82
2	154	1.30	1.14018	1.38	87	83
3	135	1.30	1.14018	1.38	90	83
4	154	1.40	1.18322	1.48	92	84
5	158	1.30	1.14018	1.38	95	85
6	149	1.20	1.09545	1.27	95	86
7	142	1.00	1	1.06	96	87
8	148	0.89	0.9434	0.94	96	87
9	146	0.85	0.92195	0.90	91	86
10	147	1.30	1.14018	1.38	94	88
11	146	1.40	1.18322	1.48	97	89
12	148	1.40	1.18322	1.48	92	90
13	143	1.30	1.14018	1.38	99	90
14	146	1.20	1.09545	1.27	99	91
15	129	0.99	0.99499	1.05	100	91
16	122	0.80	0.89443	0.85	94	91
	145.25		1.0778	1.2406	93.9375	87.0625
					90.5000	

### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 2-Jun-95  
 PLACE : Dryer #3 Exhaust  
 RUN# : 1

TEST DURATION (MINUTES) :	60	LIQUID COLLECTED (mls) :	240.6
NOZZLE DIAMETER (INCH.) :	0.2386	PARTICULATE WEIGHT (Front half mg)	0
METER COEFFICIENT (Y) :	0.98893	PARTICULATE WEIGHT (Back half mg) :	0
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-8.6
GAS METER VOL.(Cu.Ft.) :	61.079	PERCENT CO2 :	1.5
BAROMETRIC PRESSURE :	29.9	PERCENT O2 :	19.5
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK		
STACK DIAMETER (inch):	42	STACK LENGTH(inchs) :	
STACK AREA (Sq.Ft.) :	9.621128	STACK WIDTH(inchs) :	
NOZZLE AREA (feet):	0.000311	STACK AREA (Sq.Ft.):	0

ENTER THE STACK AREA SHOWN ABOVE: 9.621128

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	58.0971
VOLUME OF WATER VAPOR (STD. CU.FT.):	11.3250
FRACTIONAL MOISTURE CONTENT (%):	0.1631
DRY BASE:	79.0000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.0200
MOLECULAR WT. OF STACK GAS (WET BASE):	27.2223
STACK PRESSURE (inch Hg):	29.2676
STACK GAS VELOCITY (ft/sec.):	74.2814
ACTUAL STACK GAS FLOW RATE (ACFM):	42880.2546
STANDARD STACK GAS FLOW RATE (SCFH):	1709370.18
ISOKINETIC RATIO (%):	105.3788

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	186	1.40	1.183216	2.92	88	88	
2	195	1.40	1.183216	2.92	90	87	
3	196	1.40	1.183216	2.92	92	88	
4	194	1.40	1.183216	2.92	94	88	
5	195	1.30	1.140175	2.71	94	89	
6	196	1.30	1.140175	2.71	95	89	
7	196	1.35	1.161895	2.81	95	90	
8	178	0.98	0.989949	2.00	96	90	
9	191	1.40	1.183216	2.92	98	90	
10	192	1.40	1.183216	2.92	96	90	
11	191	1.40	1.183216	2.92	97	91	
12	194	1.40	1.183216	2.92	92	91	
13	197	1.40	1.183216	2.92	92	91	
14	197	1.30	1.140175	2.71	92	91	
15	191	1.30	1.140175	2.71	99	92	
16	160	0.91	0.953939	1.89	99	92	
	190.5625		1.1447	2.7388	94.3125	89.8125	92.0625

### EMISSION TEST SUMMARY

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 2-Jun-95  
 PLACE : Dryer #3 Exhaust  
 RUN# : 2

TEST DURATION (MINUTES) :	60	LIQUID COLLECTED (mls) :	255.5
NOZZLE DIAMETER (INCH.) :	0.2386	PARTICULATE WEIGHT (Front half mg) :	0
METER COEFFICIENT (Y) :	0.98893	PARTICULATE WEIGHT (Back half mg) :	0
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-8.5
GAS METER VOL.(Cu.Ft.) :	59.819	PERCENT CO2 :	2.5
BAROMETRIC PRESSURE :	29.9	PERCENT O2 :	18
		PERCENT CO :	0

FOR CIRCULAR STACK	FOR RECTANGULAR STACK
STACK DIAMETER (inch):	42 STACK LENGTH(inches) :
STACK AREA (Sq.Ft.) :	9.621128 STACK WIDTH(inches) :
NOZZLE AREA (feet):	0.000311 STACK AREA (Sq.Ft.) :
	0

ENTER THE STACK AREA SHOWN ABOVE: 9.621128

#### FLOWS

SAMPLED VOLUME (STD. CU.FT.):	56.2410
VOLUME OF WATER VAPOR (STD. CU.FT.):	12.0264
FRACTIONAL MOISTURE CONTENT (%):	0.1762
DRY BASE:	79.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.1200
MOLECULAR WT. OF STACK GAS (WET BASE):	27.1610
STACK PRESSURE (inch Hg):	29.2750
STACK GAS VELOCITY (ft/sec.):	72.7730
ACTUAL STACK GAS FLOW RATE (ACFM):	42009.5163
STANDARD STACK GAS FLOW RATE (SCFH):	1653122.55
ISOKINETIC RATIO (%):	105.4835

POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET	
1	192	1.30	1.140175	2.71	91	91	
2	191	1.35	1.161895	2.81	97	92	
3	194	1.30	1.140175	2.71	100	92	
4	194	1.30	1.140175	2.71	102	93	
5	195	1.30	1.140175	2.71	102	93	
6	195	1.40	1.183216	2.92	103	94	
7	189	1.20	1.095445	2.50	103	94	
8	159	0.85	0.921954	1.77	104	95	
9	192	1.40	1.183216	2.92	98	95	
10	194	1.40	1.183216	2.92	102	95	
11	194	1.30	1.140175	2.71	104	96	
12	196	1.30	1.140175	2.71	105	96	
13	194	1.40	1.183216	2.92	105	96	
14	192	1.30	1.140175	2.71	106	97	
15	187	1.20	1.095445	2.50	106	97	
16	165	0.92	0.959166	1.92	107	97	
	188.9375		1.1217	2.6344	102.1875	94.5625	98.3750

**EMISSION TEST SUMMARY**

PLANT : Louisiana Pacific, Corrigan, TX  
 DATE : 2-Jun-95  
 PLACE : Dryer #3 Exhaust  
 RUN# : 3

TEST DURATION (MINUTES) :	60	LIQUID COLLECTED (mls) :	237.6
NOZZLE DIAMETER (INCH.) :	0.2386	PARTICULATE WEIGHT (Front half mg) :	0
METER COEFFICIENT (Y) :	0.98893	PARTICULATE WEIGHT (Back half mg) :	0
PITOT COEFFICIENT (Cp) :	0.84	STATIC PRESSURE (in. H2O) :	-8.6
GAS METER VOL.(Cu.Ft.) :	59.237	PERCENT CO2 :	2.5
BAROMETRIC PRESSURE :	29.9	PERCENT O2 :	18
		PERCENT CO :	0

FOR CIRCULAR STACK		FOR RECTANGULAR STACK	
STACK DIAMETER (inch):	42	STACK LENGTH(inchs) :	
STACK AREA (Sq.Ft.) :	9.62113	STACK WIDTH(inchs) :	
NOZZLE AREA (feet):	0.00031	STACK AREA (Sq.Ft.) :	0

ENTER THE STACK AREA SHOWN ABOVE: 9.62113

**FLOWS**

SAMPLED VOLUME (STD. CU.FT.):	55.3588
VOLUME OF WATER VAPOR (STD. CU.FT.):	11.1838
FRACTIONAL MOISTURE CONTENT (%):	0.1681
DRY BASE:	79.5000
MOLECULAR WT. OF STACK GAS (DRY BASE):	29.1200
MOLECULAR WT. OF STACK GAS (WET BASE):	27.2511
STACK PRESSURE (inch Hg):	29.2676
STACK GAS VELOCITY (ft/sec.):	71.9892
ACTUAL STACK GAS FLOW RATE (ACFM):	41557.0629
STANDARD STACK GAS FLOW RATE (SCFH):	1649385.01

**PARTICULATE**

FRONT HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0000
PARTICULATE CONCENTRATION (LBS/SCF):	0.00E+00
PARTICULATE EMISSION (LBS/HR):	0.0000

BACK HALF

PARTICULATE CONCENTRATION (GR./SCF):	0.0000
PARTICULATE CONCENTRATION (LBS/SCF):	0.00E+00
PARTICULATE EMISSION (LBS/HR):	0.0000

ISOKINETIC RATIO (%): 104.0640


POINTS	STACK T. deg F	DELTA P	QUAR D.	DELTA H	METER T. INLET	METER T. OUTLET
1	192	1.40	1.18322	2.92	96	96
2	195	1.30	1.14018	2.71	100	96
3	193	1.35	1.1619	2.81	101	96
4	194	1.40	1.18322	2.92	104	97
5	192	1.20	1.09545	2.50	105	97
6	191	1.20	1.09545	2.50	105	98
7	191	1.10	1.04881	2.29	106	98
8	169	0.92	0.95917	1.92	107	99
9	191	1.50	1.22474	3.13	109	99
10	196	1.40	1.18322	2.92	105	99
11	194	1.40	1.18322	2.92	106	99
12	192	1.30	1.14018	2.71	107	100
13	189	1.20	1.09545	2.50	107	100
14	192	1.30	1.14018	2.71	107	100
15	182	0.96	0.9798	2.00	107	100
16	180	0.92	0.95917	1.92	107	101
	189.5625		1.1108	2.5863	104.9375	98.4375
						101.6875




APPENDIX B

Summary of Formaldehyde Analysis				
Plant:	Louisiana Pacific, Corrigan, TX			
			Formaldehyde, mg	
Run#/Location		1	2	3
Field Spike, 1 mg		1.143 mg		
Dryer #1		16.685	18.837	4.248
Dryer #2		15.444	8.272	3.834
Dryer #3		9.94	10.985	7.255


Description : Channel 1  
 Conditions : 150 ng/ml Formaldehyde  
 Date : 06/03/1995  
 Time : 07:22:45




Description : Channel 1  
 Conditions : 100 ng/ml Formaldehyde  
 Date : 06/03/1995  
 Time : 07:41:47




Description : Channel 1  
 Conditions : 50 ng/ml formaldehyde  
 Date : 06/03/1995  
 Time : 07:55:39




Description : Channel 1  
 Conditions : Field Spike  
 : Vol 250 mls  
 : Dil 1/100  
 Date : 06/03/1995  
 Time : 08:18:28



Description : Channel 1  
 Conditions : R2 Dryer 1  
 : Vol 300 mls  
 : Dil 1/1000  
 Date : 06/03/1995  
 Time : 08:52:23




Description : Channel 1  
 Conditions : R3 Dryer 1  
 : Vol 250 mls  
 : Dil 1/1000  
 Date : 06/03/1995  
 Time : 09:05:29







Description : Channel 1  
 Conditions : R1 Dryer 1  
               : Vol 250 mls  
               : Dil 1/1000  
 Date : 06/03/1995  
 Time : 09:16:31




Description : Channel 1  
 Conditions : R1 Dryer 2  
               : Vol 400 mls  
               : Dil 1/1000  
 Date : 06/03/1995  
 Time : 09:35:10




Description : Channel 1  
 Conditions : R2 Dryer 2  
 : Vol 400 mls  
 : Dil 1/1000  
 Date : 06/03/1995  
 Time : 09:44:34




Description : Channel 1  
 Conditions : R3 Dryer 2  
               : Vol 300 mls  
               : Dil 1/1000  
 Date : 06/03/1995  
 Time : 09:54:30




Description : Channel 1  
 Conditions : R1 Dryer 3  
               : Vol 500 mls  
               : Dil 1/1000  
 Date : 06/03/1995  
 Time : 10:05:27




Description : Channel 1  
 Conditions : R2 Dryer 3  
 : Vol 500 mls  
 : Dil 1/1000  
 Date : 06/03/1995  
 Time : 10:14:47



Description : Channel 1  
 Conditions : R3 Dryer 3  
               : Vol 500 mls  
               : Dil 1/1000  
 Date : 06/03/1995  
 Time : 10:24:39



Description : Channel 1  
 Conditions : Field Blank  
 : Vol 250 mls  
 : Dil 1/1000  
 Date : 06/03/1995  
 Time : 10:34:45







**AccuStandard Inc.**

25 Science Park  
New Haven, CT 06511

# CERTIFICATE OF PRODUCT DATA

**PRODUCT:** M-8315-02

**DESCRIPTION:** Aldehyde Solution

**LOT #:** 074-280

**SOLVENT:** water


**EXPIRATION:** On-going Stability  
Program

Component	CAS #	Purity % (GC/FID)	Gravimetric Concentration <sup>1</sup> (µg/mL)	Analyte Concentration <sup>2</sup> (µg/mL)
Formaldehyde	50-00-0	35.0	2868 *	1004

\* Weight compensated to 100% purity

- \* All weights are traceable through National Bureau of Standards Test No. 731/243669 's'
- Analyte Conc. = Purity x Gravimetric Conc.

Certified by: 

Certified by: 

This product was manufactured to meet the quality system requirements of ISO 9001

**PARTICULATE ANALYTICAL DATA FORM**

Company: LP Corigan  
 Date: 6/1/95  
 Location: Dryer 1 PW

	Run 1	Run 2	Run 3
Density (Pa)	<u>.7854</u>	<u>.7854</u>	<u>.7854</u>
Blank Concentration (Ca)			
Rinse Volume (Vaw)	<u>150</u>	<u>180</u>	<u>235</u>
Residue in Rinse (Wa) = Ca*Vaw*Pa	<u>0.45 mg</u>	<u>0.54 mg</u>	<u>0.70 mg</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>111.3787</u>	<u>115.3917</u>	<u>106.8730</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>111.3787</u>	<u>115.3917</u>	<u>106.8732</u>
Average Gross Weight	<u>111.3787</u>	<u>115.3917</u>	<u>106.8731</u>
Less Blank Residue (Wa) <sup>add</sup>	<u>.00045</u>	<u>.00054</u>	<u>.00070</u>
Tare Weight <sup>Blank</sup>	<u>111.3110</u>	<u>115.2935</u>	<u>106.797</u>
Weight of Particulate in Rinse	<u>.06815</u>	<u>.09766</u>	<u>.0747</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Filter Weight	<u>.6158</u>	<u>.7035</u>	<u>.6576</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Filter Weight	<u>.6158</u>	<u>.7037</u>	<u>.6578</u>
Average Gross Weight	<u>.6158</u>	<u>.7036</u>	<u>.6577</u>
Filter Tare Weight	<u>.4786</u>	<u>.4985</u>	<u>.4802</u>
Weight of Particulate on Filter	<u>.1372</u>	<u>.2051</u>	<u>.1775</u>
Total Weight of Particulate	<u>0.20535</u>	<u>0.30276</u>	<u>0.2522</u>

**ACETONE BLANK ANALYTICAL DATA FORM**

Blank Volume	<u>100</u>
Date of Weighing	<u>6/3</u>
Gross Weight	<u>106.2804</u>
Date of Weighing	<u>6/3</u>
Gross Weight	<u>106.2804</u>
Average Gross Weight	<u>106.2804</u>
Tare Weight	<u>106.2801</u>
Weight of Blank (Ma)	<u>.0003</u>
Ca = ma/(Va*Pa) = mg/g	<u>.0038</u>

Note: In no case should a blank residue greater than 0.01 mg/g or 0.001% of the blank weight be subtracted from the sample weight.

**PARTICULATE ANALYTICAL DATA FORM**

Company: LP Corigan  
 Date: 6/1/95  
 Location: Dryer 1 Imps 100ml aliquots

	Run 1	Run 2	Run 3
Density (Pa)	<u>1.0</u>	<u>1.0</u>	<u>1.0</u>
Blank Concentration ( <del>Ca</del> Vol <sub>s</sub> )	<u>345</u>	<u>396</u>	<u>348</u>
Rinse Volume (Vav) Vol <sub>a</sub>	<u>100</u>	<u>100</u>	<u>100</u>
Residue in Rinse (Wa) = Ca*Vav*Pa			
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>105.7737</u>	<u>97.6128</u>	<u>112.9203</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>105.7737</u>	<u>97.6128</u>	<u>112.9205</u>
Average Gross Weight	<u>105.7737</u>	<u>97.6128</u>	<u>112.9204</u>
Less Blank Residue (Wa)			
Tare Weight	<u>105.7652</u>	<u>97.6049</u>	<u>112.9106</u>
Weight of Particulate in Rinse	<u>0.0085</u>	<u>0.0079</u>	<u>0.0098</u>
Date of Weighing			
Gross Filter Weight			
Date of Weighing			
Gross Filter Weight			
Average Gross Weight			
Filter Tare Weight			
Weight of Particulate on Filter			
Total Weight of Particulate	<u>x3.45 29.35</u>	<u>x3.96 31.28</u>	<u>x3.48 34.10</u>

**ACETONE BLANK ANALYTICAL DATA FORM**

Blank Volume \_\_\_\_\_  
 Date of Weighing \_\_\_\_\_  
 Gross Weight \_\_\_\_\_  
 Date of Weighing \_\_\_\_\_  
 Gross Weight \_\_\_\_\_  
 Average Gross Weight \_\_\_\_\_  
 Tare Weight \_\_\_\_\_  
 Weight of Blank (Ma) \_\_\_\_\_  
 Ca = ma/(Va\*Pa) = mg/g \_\_\_\_\_

Note: In no case should a blank residue greater than 0.01 mg/g or 0.001% of the blank weight be subtracted from the sample weight.

**PARTICULATE ANALYTICAL DATA FORM**

Company: LP Corigan  
 Date: 6/1/85  
 Location: Dryer 2 Imps

	Run 1	Run 2	Run 3
Density (Pa)	<u>1.0</u>	<u>1.0</u>	<u>1.0</u>
Blank Concentration (Ca) <i>Vols</i>	<u>441</u>	<u>409</u>	<u>388</u>
Rinse Volume (Vav) <i>Vols</i>	<u>100</u>	<u>100</u>	<u>100</u>
Residue in Rinse (Wa) = Ca*Vav*Pa			
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>96.8868</u>	<u>102.4907</u>	<u>106.1128</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>96.8868</u>	<u>102.4908</u>	<u>106.1128</u>
Average Gross Weight	<u>96.8868</u>	<u>102.49075</u>	<u>106.1128</u>
Less Blank Residue (Wa)			
Tare Weight	<u>96.8770</u>	<u>102.4775</u>	<u>106.0961</u>
Weight of Particulate in Rinse	<u>.0097</u>	<u>0.01325</u>	<u>0.0167</u>
Date of Weighing			
Gross Filter Weight			
Date of Weighing			
Gross Filter Weight			
Average Gross Weight			
Filter Tare Weight			
Weight of Particulate on Filter			
Total Weight of Particulate x 4.41	<u>42.78</u>	<u>54.19</u>	<u>64.79</u>

**ACETONE BLANK ANALYTICAL DATA FORM**

Blank Volume	_____
Date of Weighing	_____
Gross Weight	_____
Date of Weighing	_____
Gross Weight	_____
Average Gross Weight	_____
Tare Weight	_____
Weight of Blank (Ma)	_____
Ca = ma/(Va*Pa) = mg/g	_____

Note: In no case should a blank residue greater than 0.01 mg/g or 0.001% of the blank weight be subtracted from the sample weight.

**PARTICULATE ANALYTICAL DATA FORM**

Company: LP Corigan  
 Date:  
 Location: Dryer 2 PW

	Run 1	Run 2	Run 3
Density (Pa)	<u>.7854</u>	<u>.7854</u>	<u>.7854</u>
Blank Concentration (Ca)	<u>.01 mg/ml</u>	<u>01</u>	
Rinse Volume (Vaw)	<u>175</u>	<u>230</u>	<u>125</u>
Residue in Rinse (Wa) = Ca*Vaw*Pa	<u>1.27 mg</u>	<u>1.8 mg</u>	<u>1.45</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>99.5692</u>	<u>106.5340</u>	<u>112.6998</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>99.5692</u>	<u>106.5339</u>	<u>112.6998</u>
Average Gross Weight	<u>99.5692</u>	<u>106.53395</u>	<u>112.6998</u>
Less Blank Residue (Wa)	<u>0.00014</u>	<u>0.00018</u>	<u>0.00015</u>
Tare Weight	<u>99.5197</u>	<u>106.4807</u>	<u>112.6487</u>
Weight of Particulate in Rinse	<u>0.04936</u>	<u>0.05307</u>	<u>0.03095</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Filter Weight	<u>.6376</u>	<u>.7267</u>	<u>.6219</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Filter Weight	<u>.6378</u>	<u>.7269</u>	<u>.6220</u>
Average Gross Weight	<u>.6377</u>	<u>.7268</u>	<u>.62195</u>
Filter Tare Weight	<u>.4747</u>	<u>.4999</u>	<u>.4499</u>
Weight of Particulate on Filter	<u>.1630</u>	<u>.2269</u>	<u>.17205</u>
Total Weight of Particulate	<u>212.56 mg</u>	<u>279.97</u>	<u>203.0</u>

**ACETONE BLANK ANALYTICAL DATA FORM**

Blank Volume	<u>100</u>
Date of Weighing	<u>6/3</u>
Gross Weight	<u>90.8210</u>
Date of Weighing	<u>6/3</u>
Gross Weight	<u>90.8210</u>
Average Gross Weight	<u>90.8210</u>
Tare Weight	<u>90.8192</u>
Weight of Blank (Ma)	<u>.0008</u>
Ca = ma/(Va*Pa) = mg/g	<u>0.01</u>

Note: In no case should a blank residue greater than 0.01 mg/g or 0.001% of the blank weight be subtracted from the sample weight.

**PARTICULATE ANALYTICAL DATA FORM**

Company: LP Corigan  
 Date: 6/1/95  
 Location: Dryer 3, 1 mps

	Run 1	Run 2	Run 3
Density (Pa)	<u>1.0</u>	<u>1.0</u>	<u>1.0</u>
Blank Concentration (Ca) <i>Vols</i>	<u>341</u>	<u>359</u>	<u>346</u>
Rinse Volume (Vav) <i>Vola</i>	<u>100</u>	<u>100</u>	<u>100</u>
Residue in Rinse (Wa) = Ca*Vav*Pa			
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>103.8116</u>	<u>103.5587</u>	<u>103.2657</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>103.8114</u>	<u>103.5588</u>	<u>103.2657</u>
Average Gross Weight	<u>103.8115</u>	<u>103.55876</u>	<u>103.2657</u>
Less Blank Residue (Wa)			
Tare Weight	<u>103.8076</u>	<u>103.5515</u>	<u>103.2595</u>
Weight of Particulate in Rinse	<u>0.00395<sup>r</sup></u>	<u>0.00725</u>	<u>0.0062</u>
Date of Weighing	_____	_____	_____
Gross Filter Weight	_____	_____	_____
Date of Weighing	_____	_____	_____
Gross Filter Weight	_____	_____	_____
Average Gross Weight	_____	_____	_____
Filter Tare Weight	_____	_____	_____
Weight of Particulate on Filter	_____	_____	_____
Total Weight of Particulate	<u>13.30 mg</u>	<u>26.03 mg</u>	<u>21.45 mg</u>

**ACETONE BLANK ANALYTICAL DATA FORM**

Blank Volume	_____
Date of Weighing	_____
Gross Weight	_____
Date of Weighing	_____
Gross Weight	_____
Average Gross Weight	_____
Tare Weight	_____
Weight of Blank (Ma)	_____
Ca = ma/(Va*Pa) = mg/g	_____

Note: In no case should a blank residue greater than 0.01 mg/g or 0.001% of the blank weight be subtracted from the sample weight.

**PARTICULATE ANALYTICAL DATA FORM**

Company: LP Corigan  
 Date: \_\_\_\_\_  
 Location: Dryer 3 PW

	Run 1	Run 2	Run 3
Density (Pa)	<u>.7854</u>	<u>.7854</u>	<u>.7854</u>
Blank Concentration (Ca)	<u>.0051</u>	<u>.0051</u>	<u>.0051</u>
Rinse Volume (Vaw)	<u>200</u>	<u>190</u>	<u>200</u>
Residue in Rinse (Wa) = Ca*Vaw*Pa	<u>0.80mg</u>	<u>0.76mg</u>	<u>0.80mg</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>93.5500</u>	<u>99.9950</u>	<u>93.3496</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Weight	<u>93.5501</u>	<u>99.9952</u>	<u>93.3496</u>
Average Gross Weight	<u>93.55005</u>	<u>99.9951</u>	<u>93.3496</u>
Less Blank Residue (Wa) <i>Add Blank</i>	<u>.0008</u>	<u>0.0006</u>	<u>0.0008</u>
Tare Weight	<u>93.4008</u>	<u>99.8910</u>	<u>93.2103</u>
Weight of Particulate in Rinse	<u>0.14845</u>	<u>0.1034</u>	<u>0.1085</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Filter Weight	<u>.6151</u>	<u>.6039</u>	<u>.5971</u>
Date of Weighing	<u>6/3</u>	<u>6/3</u>	<u>6/3</u>
Gross Filter Weight	<u>.6151</u>	<u>.6039</u>	<u>.5969</u>
Average Gross Weight	<u>.6151</u>	<u>.6039</u>	<u>.5970</u>
Filter Tare Weight	<u>.4991</u>	<u>.4777</u>	<u>.4849</u>
Weight of Particulate on Filter	<u>.1160</u>	<u>.1262</u>	<u>.1121</u>
Total Weight of Particulate	<u>264.45</u>	<u>229.64</u>	<u>220.6</u>

**ACETONE BLANK ANALYTICAL DATA FORM**

Blank Volume	<u>100</u>
Date of Weighing	<u>6/3</u>
Gross Weight	<u>91.7682</u>
Date of Weighing	<u>6/3</u>
Gross Weight	<u>91.7682</u>
Average Gross Weight	<u>91.7682</u>
Tare Weight	<u>91.7619</u>
Weight of Blank (Ma)	<u>.0004</u>
Ca = ma/(Va*Pa) = mg/g	<u>.0051</u>


Note: In no case should a blank residue greater than 0.01 mg/g or 0.001% of the blank weight be subtracted from the sample weight.

APPENDIX C



Nox CO Calibration  
Dryer #1 5/8/95

Nox & CO Calibration



9:13  
am

9:19  
am

9:23  
am

FILENA a:cal1

LOGGIN 1


START LOGGING  
LAST SAMPLE @

#####  
#####

ACTIVE MODULE SAMPLE UNITS:	1A Voltage 5 sec Volts	1B Voltage 5 sec Volts	NOx ppm	2A Voltage 5 sec Volts	CO ppm	2B Voltage 4 hrs Volts	
	1	0.0	0.0	0.5	0.0	1.5	0.7
	2	0.0	0.0	0.8	0.0	1.0	
	3	0.0	0.0	0.8	0.0	0.5	
	4	0.0	0.0	0.8	0.0	1.0	
	5	0.0	0.0	0.8	0.0	0.5	
	6	0.0	0.0	0.8	0.0	0.5	
	7	0.0	0.0	0.8	0.0	0.5	
	8	0.0	0.0	0.8	0.0	0.5	
	9	0.0	0.0	0.8	0.0	0.5	
	10	0.0	0.0	0.8	0.0	1.0	
09:13	11	0.0	0.4	10.0	0.0	0.5	
	12	0.0	1.8	44.0	0.0	0.5	
	13	0.0	2.5	62.6	0.0	0.5	
	14	0.0	3.0	78.0	0.0	0.0	
	15	0.0	3.5	87.0	0.0	0.0	
	16	0.0	3.8	95.3	0.0	0.0	
	17	0.0	4.1	101.3	0.0	0.0	
	18	0.0	4.3	108.3	0.0	-0.5	
	19	0.0	4.4	109.0	0.0	0.0	
	20	0.0	4.5	112.0	0.0	-1.0	
	21	0.0	4.6	114.8	0.0	-0.5	
	22	0.0	4.7	117.0	0.0	-0.5	
	23	0.0	4.7	118.3	0.0	-1.0	
	24	0.0	4.8	118.8	0.0	-0.5	
	25	0.0	4.7	118.3	0.0	-0.5	
	26	0.0	4.6	114.6	0.0	-0.5	
	27	0.0	4.6	114.3	0.0	-0.5	
	28	0.0	4.6	114.8	0.0	-1.0	
	29	0.0	4.6	115.0	0.0	-1.0	
	30	0.0	4.6	114.6	0.0	-0.5	
	31	0.0	4.2	105.3	0.0	-0.5	
	32	0.0	2.6	65.8	0.0	-1.0	
	33	0.0	1.5	36.5	0.0	-0.5	
	34	0.0	0.8	20.0	0.0	-0.5	
	35	0.0	0.5	11.3	0.0	-0.5	
	36	0.0	0.3	6.5	0.0	0.5	
	37	0.0	0.2	4.0	0.0	0.0	
	38	0.0	0.1	2.6	0.0	0.0	
	39	0.0	0.1	1.8	0.0	0.0	
	40	0.0	0.1	1.5	0.0	-0.5	
	41	0.0	0.0	1.0	0.0	0.0	
	42	0.0	0.0	1.0	0.0	0.0	
09:18	43	0.0	1.5	36.5	0.0	-0.5	
	44	0.0	3.9	97.0	0.0	-0.5	
	45	0.0	5.3	133.5	0.0	-0.5	
	46	0.0	6.4	160.0	0.0	0.0	
	47	0.0	7.4	184.5	0.0	0.5	
	48	0.0	8.1	203.0	0.0	-0.5	
	49	0.0	8.9	215.0	0.0	-0.5	
	50	0.0	9.0	225.3	0.0	0.0	
	51	0.0	9.2	231.0	0.0	0.5	
	52	0.0	9.5	236.8	0.0	-0.5	
	53	0.0	9.7	241.8	0.0	-0.5	
	54	0.0	9.8	245.0	0.0	-0.5	
	55	0.0	9.9	248.5	0.0	-0.5	
	56	0.0	10.0	250.0	0.0	-0.5	
	57	0.0	10.0	250.5	0.0	-1.0	
	58	0.0	10.1	251.5	0.0	-0.5	
	59	0.0	10.0	251.0	0.0	-0.5	
	60	0.0	10.1	251.3	0.0	-0.5	
	61	0.0	10.1	252.3	0.0	0.5	
	62	0.0	10.0	250.5	0.0	0.0	
	63	0.0	9.1	227.0	0.0	0.0	
	64	0.0	5.6	139.8	0.0	-0.5	
	65	0.0	3.1	77.8	0.0	0.0	
	66	0.0	1.7	42.8	0.0	-0.5	
	67	0.0	1.0	24.0	0.0	0.0	
	68	0.0	0.5	13.5	0.0	-0.5	
	69	0.0	0.3	7.8	0.0	-1.0	
	70	0.0	0.2	4.8	0.0	-0.5	
	71	0.0	0.1	3.0	0.0	-1.0	
	72	0.0	0.1	2.3	0.0	-1.5	
09:18	73	0.0	0.1	1.8	0.0	-1.0	
	74	0.0	0.1	1.3	0.0	13.5	
	75	0.0	0.1	1.3	0.2	111.5	
	76	0.0	0.1	1.3	0.4	190.0	
	77	0.0	0.1	1.3	0.5	241.0	
	78	0.0	0.0	1.0	0.6	278.5	
	79	0.0	0.0	1.0	0.6	321.0	
	80	0.0	0.0	1.0	0.7	341.0	
	81	0.0	0.0	1.0	0.7	360.5	
	82	0.0	0.0	0.8	0.8	375.5	
	83	0.0	0.0	0.8	0.8	385.5	
	84	0.0	0.0	0.8	0.8	392.5	
	85	0.0	0.0	0.8	0.8	395.0	
	86	0.0	0.0	1.0	0.8	398.0	
	87	0.0	0.0	1.0	0.8	397.0	
	88	0.0	0.0	1.0	0.8	397.0	
	89	0.0	0.0	0.8	0.8	397.0	
	90	0.0	0.0	0.8	0.8	397.5	
	91	0.0	0.0	0.8	0.8	398.5	
	92	0.0	0.0	0.5	0.8	397.5	
	93	0.0	0.0	0.5	0.8	397.5	

	94	0.0	0.0	0.5	0.8	387.0
	95	0.0	0.0	0.8	0.5	271.5
	96	0.0	0.0	0.5	0.3	135.0
	97	0.0	0.0	0.8	0.1	67.0
	98	0.0	0.0	0.8	0.1	33.0
	99	0.0	0.0	0.8	0.0	16.5
	100	0.0	0.0	0.5	0.0	17.0
09:21	101	0.0	0.0	0.5	0.2	100.5
	102	0.0	0.0	0.5	0.3	144.5
	103	0.0	0.0	0.5	0.3	174.5
	104	0.0	0.0	0.5	0.4	200.5
	105	0.0	0.0	0.5	0.4	215.0
	106	0.0	0.0	0.5	0.4	224.0
	107	0.0	0.0	0.5	0.5	234.5
	108	0.0	0.0	0.5	0.5	242.0
	109	0.0	0.0	0.5	0.5	245.0
	110	0.0	0.0	0.8	0.5	248.0
	111	0.0	0.0	0.5	0.5	247.0
	112	0.0	0.0	0.8	0.5	247.5
	113	0.0	0.0	0.5	0.6	247.0
	114	0.0	0.0	0.6	0.5	247.5
	115	0.0	0.0	0.6	0.5	247.5
	116	0.0	0.0	0.6	0.5	247.5
	117	0.0	0.0	0.6	0.6	247.0
	118	0.0	0.0	0.5	0.5	247.5
	119	0.0	0.0	0.6	0.5	247.0
	120	0.0	0.0	0.5	0.5	240.0
	121	0.0	0.0	0.3	0.3	159.5
	122	0.0	0.0	0.3	0.2	81.0
	123	0.0	0.0	0.5	0.1	38.5
	124	0.0	0.0	0.5	0.0	18.0
	125	0.0	0.0	0.5	0.0	8.5
	126	0.0	0.0	0.8	0.0	8.0
09:23	127	0.0	0.0	0.5	0.1	37.5
	128	0.0	0.0	0.8	0.1	58.0
	129	0.0	0.0	0.8	0.1	70.5
	130	0.0	0.0	0.8	0.2	78.5
	131	0.0	0.0	0.8	0.2	84.5
	132	0.1	0.0	0.8	0.2	87.0
	133	0.1	0.0	0.5	0.2	90.0
	134	0.1	0.0	0.8	0.2	93.0
	135	0.1	0.0	0.5	0.2	94.5
	136	0.1	0.0	0.5	0.2	95.5
	137	0.1	0.0	0.5	0.2	95.5
	138	0.1	0.0	0.5	0.2	95.0
	139	0.1	0.0	0.5	0.2	95.0
	140	0.1	0.0	0.5	0.2	95.5
	141	0.1	0.0	0.5	0.2	95.0
	142	0.1	0.0	0.5	0.2	95.0
	143	0.1	0.0	0.5	0.2	95.5
	144	0.1	0.0	0.5	0.2	95.5
	145	0.0	0.0	0.5	0.2	95.0
	146	0.0	0.0	0.5	0.2	94.5
	147	0.0	0.0	0.5	0.1	74.5
	148	0.0	0.0	0.5	0.1	38.5
	149	0.0	0.0	0.5	0.0	18.0
	150	0.0	0.0	0.3	0.0	8.0
09:25	151	0.0	0.0	0.5	0.0	3.0
	152	0.0	0.0	0.5	0.0	0.5
	153	0.0	0.0	0.5	0.0	-2.5
	154	0.0	0.0	0.5	0.0	-3.0
	155	0.0	0.0	0.5	0.0	-2.5
	156	0.0	0.0	0.5	0.0	-3.0

Run #1 Dryer #1



Lost Power  
11:22

Average Nox 189.13  
Average CO 112.36  
53

Dryer #1 CO & Nox			
Start Run#1		NOx ppm	CO ppm
10:25		20.75	162.5
		18.75	165.5
		18.25	165
		18.75	173.5
		18.25	170.5
		18	171.5
		17.75	172.5
		18.25	170.5
		18.25	176
		17.5	174
		18	174
		18.75	166.5
		19.25	157
		19.25	154.5
		19.25	153
		18.75	160.5
		18.25	163.5
		19	176.5
		17.75	193
		16.75	201
		16.25	215.5
		16.25	206.5
		16	208
		15.5	213
		14.75	221
		15.5	225.5
		16.5	220
		16.5	214.5
		16.25	227
		16	219.5
		16.75	216
		17.5	206
		19.25	198
		18.25	197.5
		18.75	192
		19.25	197
		19.25	188.5
		19.75	187.5
		18.5	190.5
		17.25	199.5
		18.25	195
		18.75	186.5
		20.5	175
		20.5	176
		19.5	191.5
		17.75	202.5

Sheet1

			15		209.5
			16.75		207.5
			15.5		212
			16.75		210.5
			16.5		207
			19		200
			20.75		179.5
			20.5		180.5
			21.25		176.5
			20.25		176
			20		176
			20.5		177.5
Stop Run 1					
11:22					
		0.1	3.3	0.0	6.0
		0.1	3.0	0.0	6.5
		0.1	3.0	0.0	6.5
		0.1	3.3	0.0	6.0
		0.1	3.0	0.0	6.0
		0.1	3.3	0.0	5.5
		0.1	3.3	0.0	5.5
		0.1	3.3	0.0	5.5
		0.2	4.8	0.0	5.0
		2.6	64.8	0.0	5.0
		3.4	86.0	0.0	5.0
		3.7	92.8	0.0	5.0
		3.8	94.3	0.0	4.5
		4.0	99.5	0.0	4.0
		4.1	102.3	0.0	4.5
		4.2	104.3	0.0	4.0
		2.5	61.3	0.0	4.0
		0.7	18.3	0.0	4.0
		0.3	7.8	0.0	4.0
		0.2	5.3	0.1	48.5
		0.2	4.5	0.4	192.0
		0.2	4.5	0.5	234.0
		0.2	4.5	0.5	247.5
		0.2	4.3	0.5	251.5
		0.2	4.8	0.5	252.0
		0.2	4.5	0.5	252.0
		0.2	4.5	0.5	251.5
		0.2	4.3	0.2	117.0
		0.2	4.5	0.1	34.0
		0.2	4.3	0.0	11.5
		0.2	4.3	0.0	5.5
		0.2	4.3	0.0	3.0
		0.2	4.3	0.0	2.5
		0.2	4.0	0.0	2.0
		0.2	4.0	0.0	1.5
Average NOx					
Average CO					

		18.12931		189.3621	
--	--	----------	--	----------	--

09:22:31 1.00 0.50 -2.50  
 09:22:36 1.00 0.50 -3.00

TIME IVOC EX INOX ICO IO2

10:09:16	-2.00	0.75	2.00
10:09:31	-2.00	0.75	1.50
10:09:46	-2.00	0.75	1.50
10:10:01	-2.00	0.75	1.50
10:10:16	-2.00	0.75	2.00
10:10:31	-2.00	0.75	1.50
10:10:46	-2.00	1.00	1.50
10:11:01	-2.00	1.00	1.50
10:11:16	-2.00	0.75	2.00
10:11:31	-2.00	0.75	1.50
10:11:46	-2.00	6.00	90.50
10:12:01	-2.00	13.50	202.00
10:12:16	-2.00	14.75	217.50
10:12:31	-2.00	14.00	214.50
10:12:46	-2.00	16.00	217.00
10:13:01	-2.00	14.75	209.00
10:13:16	-2.00	15.25	209.00
10:13:31	-2.00	16.00	209.50
10:13:46	-2.00	16.00	217.00
10:14:01	-2.00	16.25	207.50
10:14:16	-2.00	16.50	210.50
10:14:31	-2.00	16.50	214.00
10:14:46	-2.00	16.00	209.50
10:15:01	-2.00	15.50	209.00
10:15:16	-2.00	15.75	208.50
10:15:31	-2.00	16.25	202.00
10:15:46	-2.00	17.00	196.50
10:16:01	-2.00	17.25	197.00
10:16:16	-2.00	16.75	191.00
10:16:31	-2.00	16.75	198.50
10:16:46	-2.00	17.25	201.50
10:17:01	-2.00	17.00	204.00
10:17:16	-2.00	17.00	206.50
10:17:31	-2.00	17.25	200.50
10:17:46	-2.00	16.75	203.00
10:18:01	-2.00	17.50	197.50
10:18:16	-2.00	17.75	194.00
10:18:31	-2.00	17.50	191.50
10:18:46	-2.00	18.00	184.50
10:19:01	1.00	19.00	181.00
10:19:16	-2.00	19.00	187.00
10:19:31	1.00	19.25	182.50
10:19:46	1.00	19.50	182.50
10:20:01	1.00	20.00	179.50
10:20:16	-2.00	20.00	170.50
10:20:31	-2.00	20.25	165.00
10:20:46	-2.00	20.50	160.50
10:21:01	-2.00	20.75	157.00
10:21:16	-2.00	20.75	158.00
10:21:31	-2.00	20.50	159.00
10:21:46	-2.00	20.50	160.00
10:22:01	-2.00	20.75	162.50
10:22:16	-2.00	20.75	161.50
10:22:31	-2.00	18.75	162.50
10:22:46	-2.00	18.75	162.00
10:23:01	-2.00	18.75	165.50
10:23:16	-2.00	19.50	165.00

In Stack

Start Run #1

Dryer #1

LP 6/1/95



10:23:46	-2.00	18.50	164.50
10:24:01	-2.00	18.25	165.00

TIME	IVOC EX	INOX	IC0	IC2
------	---------	------	-----	-----

10:24:16	-2.00	18.50	167.50
10:24:31	-2.00	18.50	167.00
10:24:46	-2.00	18.50	170.00
10:25:01	-2.00	18.75	173.50
10:25:16	-2.00	18.25	170.00
10:25:31	-2.00	18.00	170.00
10:25:46	-2.00	18.25	171.50
10:26:01	-2.00	18.00	171.50
10:26:16	-2.00	18.25	170.50
10:26:31	-2.00	18.25	170.00
10:26:46	-2.00	17.75	171.00
10:27:01	-2.00	17.75	172.50
10:27:16	-2.00	18.25	172.50
10:27:31	-2.00	18.50	174.50
10:27:46	-2.00	18.50	170.00
10:28:01	-2.00	18.25	170.50
10:28:16	-2.00	18.25	173.00
10:28:31	-2.00	18.50	171.00
10:28:46	-2.00	18.50	170.50
10:29:01	-2.00	18.25	176.00
10:29:16	-2.00	17.50	176.00
10:29:31	-2.00	17.25	175.50
10:29:46	-2.00	17.00	174.50
10:30:01	-2.00	17.50	174.00
10:30:16	-2.00	18.50	174.50
10:30:31	-2.00	18.75	173.50
10:30:46	-2.00	18.50	175.50
10:31:01	-2.00	18.00	174.00
10:31:16	-2.00	18.50	172.50
10:31:31	-2.00	18.50	169.00
10:31:46	-2.00	18.75	166.00
10:32:01	-2.00	18.75	166.50
10:32:16	-2.00	19.00	165.00
10:32:31	1.00	19.25	158.50
10:32:46	1.00	19.00	155.50
10:33:01	1.00	19.25	157.00
10:33:16	1.00	19.25	158.50
10:33:31	1.00	19.25	156.50
10:33:46	1.00	19.25	158.50
10:34:01	1.00	19.25	154.50
10:34:16	1.00	19.00	157.50
10:34:31	1.00	19.00	159.00
10:34:46	1.00	19.00	156.00
10:35:01	1.00	19.25	153.00
10:35:16	1.00	18.75	156.50
10:35:31	1.00	18.75	162.50
10:35:46	1.00	19.00	158.50
10:36:01	1.00	18.75	160.50
10:36:16	1.00	18.75	161.50
10:36:31	1.00	18.75	159.00
10:36:46	1.00	18.25	160.50
10:37:01	-2.00	18.25	163.50
10:37:16	-2.00	18.25	168.50
10:37:31	-2.00	18.75	173.00
10:37:46	-2.00	18.50	174.00
10:38:01	-2.00	19.00	176.50
10:38:16	-2.00	19.00	179.00

10:38:46	-2.00	18.50	191.00
10:39:01	-2.00	18.25	188.50

TIME	IVOC EX	INOX	ICO	IO2
------	---------	------	-----	-----

10:39:16	-2.00	18.00	188.00
10:39:31	-2.00	18.00	190.00
10:39:46	-2.00	17.50	191.50
10:40:01	-2.00	17.75	193.00
10:40:16	-2.00	17.50	192.50
10:40:31	-2.00	17.00	196.00
10:40:46	-2.00	17.00	203.00
10:41:01	-2.00	16.75	201.00
10:41:16	-2.00	16.50	198.00
10:41:31	-2.00	16.00	200.50
10:41:46	-2.00	16.50	206.50
10:42:01	-2.00	16.25	215.50
10:42:16	-2.00	15.25	212.00
10:42:31	-2.00	15.75	206.50
10:42:46	-2.00	16.25	204.50
10:43:01	-2.00	16.25	206.50
10:43:16	-2.00	18.00	205.00
10:43:31	-2.00	18.25	210.00
10:43:46	-2.00	16.75	208.50
10:44:01	-2.00	16.00	208.00
10:44:16	-2.00	15.25	208.50
10:44:31	-2.00	16.00	209.50
10:44:46	-2.00	16.25	213.00
10:45:01	-2.00	15.50	213.00
10:45:16	-2.00	16.00	212.00
10:45:31	-2.00	16.00	214.50
10:45:46	-2.00	15.25	220.00
10:46:01	-2.00	14.75	221.00
10:46:16	-2.00	15.75	217.50
10:46:31	1.00	16.25	214.00
10:46:46	2.00	16.25	220.50
10:47:01	1.00	15.50	225.50
10:47:16	1.00	15.25	225.50
10:47:31	1.00	15.50	222.00
10:47:46	1.00	15.50	216.50
10:48:01	1.00	16.50	220.00
10:48:16	1.00	16.25	216.00
10:48:31	1.00	15.50	219.50
10:48:46	1.00	16.25	218.00
10:49:01	2.00	16.50	214.50
10:49:16	2.00	16.00	216.00
10:49:31	2.00	15.25	218.50
10:49:46	2.00	16.00	218.50
10:50:01	2.00	16.25	227.00
10:50:16	1.00	16.50	228.50
10:50:31	1.00	16.00	229.50
10:50:46	1.00	17.25	224.50
10:51:01	1.00	16.00	219.50
10:51:16	1.00	16.75	216.00
10:51:31	1.00	16.50	220.00
10:51:46	1.00	16.00	219.00
10:52:01	1.00	16.75	216.00
10:52:16	1.00	16.75	207.50
10:52:31	1.00	17.50	205.00
10:52:46	1.00	18.00	208.50
10:53:01	1.00	17.50	206.00
10:53:16	1.00	18.00	201.50

10:53:46	1.00	18.75	196.50
10:54:01	1.00	19.25	198.00

TIME	IVOC EX	INOX	IC0	IC2
------	---------	------	-----	-----

10:54:16	1.00	19.00	201.00
10:54:31	1.00	18.50	199.50
10:54:46	1.00	18.50	197.50
10:55:01	1.00	18.25	197.50
10:55:16	1.00	18.50	202.50
10:55:31	1.00	18.50	201.00
10:55:46	1.00	18.75	197.00
10:56:01	1.00	18.75	192.00
10:56:16	1.00	18.50	193.50
10:56:31	1.00	19.00	192.00
10:56:46	1.00	19.75	189.50
10:57:01	1.00	19.25	197.00
10:57:16	1.00	19.50	201.50
10:57:31	1.00	19.25	194.50
10:57:46	1.00	19.25	191.50
10:58:01	1.00	19.25	188.50
10:58:16	1.00	19.75	186.50
10:58:31	1.00	18.75	184.50
10:58:46	-2.00	19.25	186.50
10:59:01	-2.00	19.75	187.50
10:59:16	-2.00	19.25	190.50
10:59:31	-2.00	18.75	189.50
10:59:46	1.00	18.50	191.50
11:00:01	1.00	18.50	190.50
11:00:16	1.00	18.75	189.50
11:00:31	1.00	17.75	194.00
11:00:46	1.00	18.00	196.00
11:01:01	1.00	17.25	199.50
11:01:16	1.00	17.25	201.50
11:01:31	1.00	17.25	199.00
11:01:46	1.00	18.00	198.50
11:02:01	1.00	18.25	195.00
11:02:16	1.00	17.25	194.00
11:02:31	1.00	17.50	198.50
11:02:46	1.00	17.25	199.00
11:03:01	1.00	18.75	186.50
11:03:16	1.00	19.50	177.00
11:03:31	1.00	20.50	172.00
11:03:46	1.00	20.25	171.50
11:04:01	1.00	20.50	175.00
11:04:16	1.00	20.75	172.50
11:04:31	1.00	20.75	170.50
11:04:46	1.00	20.00	173.00
11:05:01	1.00	20.50	176.00
11:05:16	1.00	21.00	176.00
11:05:31	1.00	20.75	180.50
11:05:46	1.00	20.50	183.00
11:06:01	1.00	19.50	191.50
11:06:16	1.00	19.00	190.50
11:06:31	1.00	18.50	191.00
11:06:46	1.00	18.50	193.50
11:07:01	1.00	17.75	202.50
11:07:16	1.00	19.00	211.50
11:07:31	1.00	17.50	216.00
11:07:46	1.00	16.25	219.50
11:08:01	-2.00	15.00	209.00
11:08:16	-2.00	14.75	208.00

11:08:46	-2.00	15.25	206.50
11:09:01	-2.00	16.75	207.50

TIME	IVOC EX	INOX	ICD	IO2
------	---------	------	-----	-----


11:09:16	-2.00	16.00	213.00
11:09:31	-2.00	14.50	215.50
11:09:46	-2.00	14.50	214.50
11:10:01	1.00	15.50	212.00
11:10:16	1.00	15.25	215.50
11:10:31	1.00	16.75	212.50
11:10:46	1.00	17.00	214.00
11:11:01	1.00	16.75	210.50
11:11:16	1.00	17.75	213.50
11:11:31	1.00	16.50	219.00
11:11:46	1.00	18.00	209.50
11:12:01	1.00	16.50	207.00
11:12:16	1.00	17.50	206.00
11:12:31	-2.00	17.50	202.50
11:12:46	-2.00	18.25	201.00
11:13:01	-2.00	19.00	200.00
11:13:16	-2.00	20.25	191.50
11:13:31	-2.00	20.50	189.00
11:13:46	-2.00	20.50	182.50
11:14:01	-2.00	20.75	179.50
11:14:16	-2.00	21.00	177.50
11:14:31	-2.00	20.75	174.50
11:14:46	-2.00	20.75	176.00
11:15:01	-2.00	20.50	180.50
11:15:16	-2.00	19.75	182.00
11:15:31	-2.00	20.50	186.50
11:15:46	-2.00	21.00	180.50
11:16:01	-2.00	21.25	176.50
11:16:16	-2.00	22.00	185.50
11:16:31	-2.00	21.25	186.00
11:16:46	-2.00	20.50	182.00
11:17:01	-2.00	20.25	176.00
11:17:16	-2.00	20.25	174.00
11:17:31	-2.00	20.25	171.50
11:17:46	-2.00	19.75	172.50
11:18:01	-2.00	20.00	176.00
11:18:16	-2.00	20.00	173.00
11:18:31	-2.00	21.00	174.50
11:18:46	-2.00	21.25	182.00
11:19:01	1.00	20.50	177.50
11:19:16	1.00	19.25	181.00
11:19:31	1.00	19.00	187.00

TIME	IVOC EX	INOX	CO	CO2
12:11:45	-2.00	3.25	5.50	
12:12:00	-1.00	3.25	5.50	
12:12:15	-2.00	4.75	5.00	
12:12:30	-2.00	64.75	5.00	
12:12:45	-2.00	86.00	5.00	
12:13:00	-2.00	92.75	5.00	
12:13:15	-2.00	94.25	4.50	
12:13:30	-2.00	99.50	4.00	
12:13:45	-2.00	102.25	4.50	
12:14:00	-2.00	104.25	4.00	
12:14:15	-2.00	61.25	4.00	
12:14:30	-2.00	18.25	4.00	
12:14:45	-2.00	7.75	4.00	
12:15:00	15.00	5.25	48.50	
12:15:15	1.00	4.50	192.00	
12:15:30	1.00	4.50	234.00	
12:15:45	1.00	4.50	247.50	
12:16:00	1.00	4.25	251.50	
12:16:15	1.00	4.75	252.00	
12:16:30	1.00	4.50	252.00	
12:16:45	1.00	4.50	251.50	
12:17:00	1.00	4.25	117.00	
12:17:15	1.00	4.50	34.00	
12:17:30	1.00	4.25	11.50	
12:17:45	-2.00	4.25	5.50	
12:18:00	1.00	4.25	3.00	
12:18:15	1.00	4.25	2.50	
12:18:30	1.00	4.00	2.00	
12:18:45	1.00	4.00	1.50	

112 ppm NO

250 ppm CO

Run#2 Dryer 1



Start -  
2:45 pm

Page 1

STOP  
3:49 pm

Average Nox 24.9  
Average CO 239.0

FILE NAME:

LOGGING SESSION:            START LOGGING @    #####  
 LAST SAMPLE @            ######

ACTIVE C	1B		2A		2B	
MODULE	Voltage		Voltage		Voltage	
SAMPLE	15 sec		15 sec		4 hrs	
UNITS:	Volts	NOx, ppm	Volts	CO, ppm	Volts	
	1	0.9	22.0	0.2	112.5	0.9
	2	0.9	22.8	0.2	117.0	
	3	0.9	22.8	0.2	120.5	
	4	0.9	22.8	0.2	124.5	
	5	0.9	22.8	0.3	132.0	
	6	0.9	22.6	0.3	142.0	
	7	0.9	22.3	0.3	151.5	
	8	0.9	22.0	0.3	161.5	
	9	0.9	22.3	0.3	169.5	
	10	0.9	22.0	0.4	180.0	
	11	0.8	21.0	0.4	189.0	
	12	0.8	20.0	0.4	196.0	
	13	0.8	19.5	0.4	204.0	
Start Run2	14	0.7	17.8	0.4	217.0	
2:44	15	0.7	17.8	0.4	220.0	
	16	0.7	17.8	0.4	224.5	
	17	0.7	17.8	0.5	228.5	
	18	0.7	16.3	0.4	223.5	
	19	0.7	16.8	0.5	229.0	
	20	0.7	18.0	0.5	226.5	
	21	0.7	17.5	0.5	230.0	
	22	0.7	18.3	0.5	228.0	
	23	0.7	18.0	0.5	249.0	
	24	0.7	17.3	0.5	247.5	
	25	0.7	17.8	0.5	245.0	
	26	0.8	19.0	0.5	249.6	
	27	0.8	18.8	0.5	249.6	
	28	0.7	18.0	0.6	253.6	
	29	0.7	18.0	0.5	271.5	
	30	0.7	18.3	0.6	279.5	
	31	0.8	18.8	0.6	281.0	
	32	0.7	18.3	0.6	283.0	
	33	0.7	18.5	0.6	277.5	
	34	0.8	20.8	0.5	271.0	
	35	0.9	21.3	0.5	270.0	
	36	0.8	20.8	0.6	287.0	
	37	0.8	20.0	0.5	269.0	
	38	0.8	21.0	0.6	254.5	
	39	0.8	20.8	0.6	255.0	
	40	0.9	21.5	0.6	249.0	
	41	0.9	21.8	0.6	253.6	
	42	0.9	22.0	0.6	254.5	
	43	0.9	22.8	0.5	264.5	
	44	0.9	21.8	0.5	264.0	
	45	0.9	22.0	0.5	244.0	
	46	0.9	22.8	0.5	250.0	
	47	0.8	21.0	0.5	254.5	
	48	0.9	22.8	0.5	253.0	
	49	0.9	21.8	0.5	260.5	
	50	0.9	22.0	0.5	288.5	
	51	0.9	23.5	0.5	259.0	
	52	1.0	24.3	0.5	255.0	
	53	0.9	22.8	0.5	263.5	
	54	1.0	25.3	0.5	254.5	
	55	0.9	23.5	0.5	253.0	
	56	0.9	23.5	0.5	257.0	
	57	1.0	23.8	0.5	253.6	
	58	1.0	24.8	0.6	256.0	
	59	1.0	25.3	0.5	249.5	
	60	1.0	24.8	0.5	240.0	
	61	1.0	24.8	0.5	243.5	
	62	1.0	24.8	0.5	249.5	
	63	1.0	24.8	0.5	243.0	
	64	1.0	25.8	0.5	234.0	
	65	1.1	27.0	0.5	227.5	
	66	1.1	26.3	0.4	222.5	
	67	1.1	26.5	0.4	217.0	
	68	1.1	26.8	0.4	216.5	
	69	1.1	26.3	0.4	216.0	
	70	1.0	26.0	0.4	206.0	
	71	1.1	27.8	0.4	201.0	
	72	1.1	26.0	0.4	200.5	
	73	1.1	27.3	0.4	202.5	
	74	1.0	28.0	0.4	208.0	
	75	1.0	25.8	0.4	207.0	
	76	1.1	27.0	0.4	210.5	
	77	1.0	26.0	0.5	252.6	
	78	1.0	25.3	0.5	239.6	
	79	1.0	25.0	0.5	239.0	
	80	1.0	24.5	0.5	240.5	
	81	0.9	23.5	0.5	244.5	
	82	0.9	23.0	0.5	241.5	
	83	1.0	24.0	0.5	233.5	
	84	1.0	25.3	0.5	245.0	
	85	1.0	25.0	0.5	255.0	
	86	0.9	23.3	0.5	259.5	
	87	0.9	22.3	0.5	252.0	
	88	0.9	21.8	0.5	255.5	
	89	0.9	22.5	0.5	260.0	
	90	0.9	23.5	0.5	251.5	
	91	1.0	24.5	0.5	263.5	

92	0.9	23.0	0.6	269.5
93	1.0	24.5	0.6	267.5
94	0.9	22.8	0.5	267.5
95	0.9	22.5	0.5	265.0
96	0.9	23.0	0.5	268.0
97	1.0	24.5	0.5	258.0
98	1.0	24.8	0.5	266.0
99	1.0	24.0	0.5	268.0
100	1.0	24.0	0.5	264.5
101	1.0	24.8	0.5	256.5
102	1.0	25.0	0.5	263.0
103	1.0	26.0	0.6	264.0
104	1.0	25.8	0.5	263.0
105	1.0	26.0	0.6	269.0
106	1.0	24.8	0.6	266.5
107	1.0	24.5	0.6	278.5
108	1.0	26.5	0.5	267.0
109	1.0	25.0	0.6	278.0
110	1.1	26.5	0.5	265.5
111	1.1	26.8	0.6	280.5
112	1.0	25.8	0.5	272.5
113	1.0	25.5	0.6	269.0
114	1.1	26.8	0.5	274.0
115	1.1	26.8	0.6	271.5
116	1.1	26.8	0.6	274.5
117	1.0	25.8	0.5	264.0
118	1.0	25.5	0.5	269.0
119	1.0	25.3	0.5	270.0
120	1.0	25.3	0.5	265.0
121	1.1	26.3	0.5	270.5
122	1.1	26.6	0.5	271.0
123	1.1	27.3	0.5	270.0
124	1.1	27.3	0.5	266.5
125	1.0	26.0	0.5	265.0
126	1.0	24.8	0.5	265.5
127	1.0	24.3	0.5	266.5
128	1.1	26.6	0.6	265.0
129	1.0	25.8	0.6	261.5
130	1.0	25.5	0.5	260.5
131	1.0	25.5	0.6	267.5
132	1.1	26.8	0.5	259.5
133	1.0	25.0	0.5	253.5
134	1.1	26.3	0.5	252.5
135	1.0	24.3	0.5	255.5
136	1.0	25.8	0.5	261.0
137	1.0	25.3	0.5	264.5
138	1.0	24.3	0.5	252.5
139	1.0	25.5	0.5	249.0
140	1.0	26.5	0.5	250.0
141	1.0	26.0	0.5	254.5
142	1.0	26.0	0.6	266.0
143	1.0	25.8	0.5	272.0
144	1.0	24.6	0.6	264.0
145	1.0	25.8	0.5	253.5
146	1.0	25.0	0.5	253.5
147	1.1	26.5	0.5	246.0
148	1.1	26.5	0.5	249.0
149	1.0	26.0	0.5	251.0
150	1.0	25.8	0.5	251.0
151	1.0	24.8	0.5	255.0
152	1.0	25.5	0.6	253.0
153	1.1	26.3	0.6	249.0
154	1.0	25.0	0.5	248.0
155	1.0	24.6	0.6	243.0
156	1.0	24.5	0.6	246.5
157	1.0	23.8	0.6	244.5
158	1.0	23.8	0.6	244.5
159	1.0	25.8	0.5	235.0
160	1.0	25.8	0.5	237.5
161	1.0	24.5	0.5	246.5
162	1.0	25.8	0.5	240.0
163	1.0	25.0	0.5	249.0
164	1.0	25.3	0.6	254.0
165	1.0	24.5	0.5	267.0
166	1.0	25.5	0.5	261.5
167	1.0	25.0	0.5	250.5
168	1.0	25.8	0.5	245.0
169	1.0	25.8	0.5	247.5
170	1.0	25.5	0.5	252.5
171	1.0	26.0	0.5	245.5
172	1.1	26.5	0.5	235.5
173	1.1	26.3	0.4	221.5
174	1.0	26.0	0.4	213.0
175	1.1	26.8	0.4	204.5
176	1.1	27.3	0.4	204.5
177	1.2	28.8	0.4	193.5
178	1.2	29.0	0.4	193.5
179	1.1	28.5	0.4	187.0
180	1.1	28.3	0.4	184.0
181	1.2	29.3	0.3	174.0
182	1.2	29.0	0.3	174.0
183	1.1	28.5	0.3	170.5
184	1.2	31.0	0.3	168.5
185	1.2	29.8	0.3	174.0
186	1.2	28.8	0.4	175.0
187	1.2	29.3	0.4	175.0
188	1.1	28.0	0.4	213.0
189	1.1	28.8	0.4	222.0
190	1.1	28.8	0.4	215.0
191	1.1	27.0	0.4	215.0
192	1.1	28.5	0.4	218.0
193	1.0	24.0	0.4	224.5
194	1.0	25.0	0.4	217.5



195	1.0	24.3	0.4	221.0
196	1.0	24.3	0.4	219.5
197	1.0	24.0	0.4	223.0
198	1.0	24.3	0.5	228.0
199	1.0	25.0	0.5	227.0
200	1.0	24.3	0.4	224.0
201	1.1	28.3	0.4	217.0
202	1.0	26.0	0.4	214.5
203	1.0	25.5	0.4	221.0
204	1.0	24.5	0.5	229.0
205	1.0	26.0	0.5	229.5
206	1.0	25.0	0.5	234.0
207	1.0	25.8	0.4	223.5
208	1.0	25.8	0.4	223.5
209	1.0	25.3	0.5	237.5
210	1.0	28.0	0.5	238.0
211	1.0	24.8	0.5	231.5
212	1.0	26.3	0.5	229.0
213	1.1	27.3	0.4	221.0
214	1.0	28.0	0.5	227.5
215	1.0	25.3	0.5	238.0
216	1.0	26.0	0.5	233.5
217	1.0	26.0	0.5	234.5
218	1.0	29.0	0.5	232.5
219	1.1	26.5	0.5	237.5
220	1.1	26.8	0.5	232.5
221	1.1	26.8	0.5	232.5
222	1.1	26.5	0.5	237.0
223	1.1	26.5	0.5	241.5
224	1.1	26.3	0.5	245.0
225	1.0	25.3	0.5	246.0
226	1.1	26.8	0.5	241.5
227	1.1	26.5	0.5	239.5
228	1.1	27.3	0.5	238.0
229	1.1	26.8	0.5	235.5
230	1.0	25.5	0.5	245.0
231	1.1	27.0	0.5	238.5
232	1.1	27.5	0.5	243.0
233	1.1	28.3	0.5	233.5
234	1.1	27.8	0.5	233.0
235	1.1	27.3	0.5	236.0
236	1.1	26.5	0.5	247.5
237	1.0	26.0	0.5	243.5
238	1.0	26.0	0.5	243.0
239	1.1	26.8	0.5	238.0
240	1.1	27.0	0.5	232.0
241	1.1	26.8	0.5	232.5
242	1.1	27.5	0.5	238.5
243	1.0	28.0	0.5	246.5
244	1.1	26.6	0.6	242.0
245	1.1	27.3	0.5	227.0
246	1.1	27.8	0.4	216.5
247	1.1	28.0	0.4	214.0
248	1.1	26.5	0.4	221.5
249	1.0	25.8	0.4	221.5
250	1.0	25.8	0.4	219.5
251	1.0	25.5	0.4	219.5
252	1.1	26.5	0.4	217.5
253	1.1	27.3	0.4	218.5
254	1.0	26.0	0.4	219.5
255	1.0	25.5	0.5	226.5
256	1.1	26.5	0.4	222.0
257	1.1	26.5	0.4	220.0
258	1.1	26.5	0.4	217.5
259	1.1	27.0	0.4	213.5
260	1.1	26.3	0.4	210.0
261	1.0	25.8	0.4	209.5
262	1.0	26.0	0.4	211.5
263	1.0	26.0	0.4	209.0
264	1.1	27.8	0.4	210.5
265	1.1	26.8	0.4	211.0
266	1.1	27.8	0.4	210.0
267	1.0	26.8	0.4	211.0
268	1.0	26.8	0.4	213.0
269	1.1	28.3	0.4	208.5
270	1.1	26.5	0.4	203.5
271	1.1	26.5	0.4	202.5
272	1.2	28.8	0.4	201.0
273	1.2	28.8	0.4	194.5
274	0.8	19.8	0.2	80.0


Stop Run2  
3:49

275	0.8	13.8	0.0	20.0
276	0.5	11.5	0.0	-1.5
277	0.4	10.3	0.0	-6.5
278	0.4	9.3	0.0	-11.5
279	0.4	8.0	0.0	2.5
280	0.3	8.5	0.0	1.5
281	0.3	8.0	0.0	1.5
282	0.3	7.8	0.0	2.0
283	0.3	7.5	0.0	1.5
284	0.3	7.5	0.0	1.5
285	0.3	7.5	0.0	2.0
286	0.3	7.8	0.0	2.0
287	0.3	7.6	0.0	1.6
288	0.3	7.5	0.0	2.0
289	0.3	7.5	0.0	1.5
290	0.3	7.3	0.0	1.6
291	0.3	7.0	0.0	1.5
292	0.3	6.8	0.0	1.5
293	0.3	6.5	0.0	2.0
294	0.3	6.3	0.0	1.5

295	0.2	6.0	0.0	1.5
296	0.2	6.0	0.0	1.0
297	0.2	5.8	0.0	1.5
298	0.2	6.5	0.0	1.5
299	0.2	5.3	0.0	2.0
300	0.2	5.3	0.0	2.0
301	0.2	5.0	0.0	1.5
302	0.2	5.0	0.0	2.0
303	0.2	4.8	0.0	1.0
304	0.2	4.5	0.0	1.6
305	0.2	4.5	0.0	1.6
306	0.2	4.5	0.0	1.5
307	0.2	4.5	0.0	1.5
308	0.2	4.5	0.0	1.6
309	0.2	4.5	0.0	1.5
310	0.2	4.5	0.0	1.5
311	0.8	19.5	0.0	1.5
312	3.3	83.6	0.0	1.0
313	4.2	104.3	0.0	1.0
314	4.4	110.3	0.0	1.0
315	4.5	111.5	0.0	1.5
316	4.5	111.8	0.0	1.5
317	4.5	112.3	0.0	1.0
318	2.2	54.0	0.0	1.5
319	0.5	13.5	0.1	36.0
320	0.3	7.5	0.3	174.0
321	0.2	5.3	0.4	223.5
322	0.2	4.8	0.5	245.0
323	0.2	4.5	0.5	249.0
324	0.2	4.5	0.5	250.0
325	0.2	4.5	0.5	249.0
326	0.2	4.8	0.4	202.5
327	0.2	4.3	0.1	44.0
328	0.2	4.3	0.0	12.0
329	0.2	4.5	0.0	5.0
330	0.2	4.0	0.0	3.0

Average NOx      Average CO  
 24.9                      239.0

Run #3 Dryer #1



Start  
4:24

STOP  
5:30

Average NOx 23.0  
Average CO 174.9

RUN3

FILE NAME:

LOGGING SESSION:

START LOGGING @ #####  
LAST SAMPLE @ #####

ACTIVE C MODULE SAMPLE UNITS:	1B Voltage 15 sec Volts	NOx ppm	2A Voltage 15 sec Volts	CO ppm	2B Voltage 4 hrs Volts	
	1	0.8	20.8	0.4	187.5	1.1
	2	0.9	21.3	0.4	200.0	
Start Run3 424	3	0.8	19.5	0.4	204.5	
	4	0.8	20.0	0.5	225.0	
	5	0.8	18.5	0.5	230.0	
	6	0.8	20.5	0.5	225.0	
	7	0.8	20.3	0.5	231.0	
	8	0.8	20.8	0.5	229.5	
	9	0.8	21.0	0.5	235.5	
	10	0.8	21.0	0.5	243.5	
	11	0.8	20.8	0.5	262.5	
	12	0.9	22.6	0.6	263.0	
	13	0.9	22.5	0.6	262.5	
	14	0.9	23.5	0.5	250.0	
	15	0.9	23.5	0.5	242.5	
	16	1.0	23.8	0.5	244.5	
	17	1.0	23.8	0.5	254.0	
	18	1.0	24.5	0.5	253.5	
	19	1.0	24.5	0.5	240.0	
	20	1.0	24.5	0.5	249.0	
	21	1.0	24.3	0.5	266.0	
	22	1.0	24.0	0.5	271.5	
	23	1.0	24.3	0.5	274.0	
	24	1.0	24.3	0.6	282.0	
	25	1.0	24.0	0.5	268.0	
	26	1.0	24.8	0.5	273.5	
	27	1.0	24.8	0.6	265.5	
	28	1.0	25.3	0.8	276.0	
	29	1.1	25.3	0.6	267.0	
	30	1.0	25.3	0.5	269.0	
	31	1.0	24.5	0.5	260.0	
	32	1.0	24.8	0.5	248.0	
	33	1.0	24.8	0.5	249.0	
	34	1.0	24.8	0.5	240.5	
	35	1.0	25.3	0.5	238.0	
	36	1.0	24.5	0.5	236.5	
	37	0.9	23.3	0.5	240.5	
	38	1.0	24.5	0.5	231.0	
	39	0.9	23.3	0.4	219.0	
	40	0.9	22.8	0.4	212.5	
	41	0.9	22.8	0.4	211.5	
	42	0.9	22.5	0.4	203.0	
	43	1.0	24.0	0.4	187.5	
	44	0.9	22.8	0.4	182.0	
	45	0.9	23.3	0.3	174.0	
	46	0.9	22.3	0.4	198.5	
	47	0.9	22.8	0.4	193.0	
	48	1.0	24.0	0.4	183.0	
	49	1.0	24.0	0.4	179.0	
	50	1.0	23.8	0.3	174.5	
	51	1.0	24.8	0.3	161.0	
	52	0.9	23.3	0.3	156.0	
	53	0.9	23.0	0.3	161.0	
	54	1.0	25.0	0.3	148.0	
	55	1.0	25.0	0.3	147.0	
	56	1.0	25.8	0.3	146.0	
	57	1.0	26.0	0.3	144.5	
	58	1.0	26.0	0.3	138.5	
	59	1.0	26.5	0.3	135.0	
	60	1.0	25.3	0.3	140.0	
	61	1.0	25.5	0.3	152.0	
	62	1.0	25.3	0.3	168.0	
	63	1.1	25.3	0.3	161.5	
	64	1.1	25.5	0.3	161.0	
	65	1.1	25.3	0.3	160.5	
	66	1.0	25.8	0.3	150.0	
	67	1.1	25.3	0.3	148.0	
	68	1.0	25.0	0.3	145.5	
	69	1.0	25.5	0.3	148.0	
	70	1.0	24.5	0.4	176.0	
	71	0.9	23.5	0.4	181.5	
	72	0.9	23.0	0.4	176.5	
	73	1.0	24.3	0.3	165.5	
	74	0.9	22.5	0.3	165.0	
	75	0.9	21.5	0.3	167.5	
	76	0.9	22.0	0.3	167.0	
	77	0.9	21.8	0.3	164.5	
	78	0.9	21.3	0.3	174.5	
	79	0.9	21.8	0.3	173.0	
	80	0.8	20.8	0.3	170.5	
	81	0.9	21.8	0.3	166.5	
	82	0.9	21.5	0.3	167.0	
	83	0.9	22.3	0.3	163.0	
	84	0.9	22.5	0.3	157.5	
	85	0.9	22.5	0.3	168.0	
	86	0.9	23.0	0.3	168.5	
	87	0.9	22.3	0.3	168.0	
	88	0.9	22.5	0.3	162.0	
	89	0.9	21.5	0.3	171.5	
	90	0.9	22.8	0.3	167.5	
	91	0.9	21.8	0.4	180.5	

RUNS

92	0.9	21.5	0.4	191.5
93	0.9	21.5	0.4	196.0
94	0.9	22.0	0.4	194.0
95	0.9	21.5	0.4	194.5
96	0.9	22.3	0.4	191.0
97	0.9	23.5	0.4	187.5
98	0.9	22.0	0.4	187.5
99	0.9	22.8	0.4	179.5
100	0.9	22.5	0.3	172.0
101	0.9	22.0	0.3	189.5
102	1.0	24.0	0.3	189.0
103	0.9	23.5	0.3	170.5
104	0.8	22.3	0.3	171.0
105	0.9	23.5	0.3	171.5
106	0.9	23.0	0.3	189.5
107	0.9	22.8	0.3	186.0
108	1.0	23.8	0.3	182.5
109	1.0	24.8	0.3	156.0
110	0.9	23.5	0.3	159.5
111	0.9	22.5	0.3	165.5
112	1.0	23.8	0.3	169.0
113	0.9	22.5	0.3	174.5
114	0.9	21.5	0.3	171.6
115	0.9	22.3	0.3	168.0
116	0.9	23.5	0.3	161.0
117	0.9	22.8	0.3	161.5
118	0.9	23.5	0.3	158.5
119	0.9	23.5	0.3	156.5
120	1.0	25.3	0.3	159.0
121	1.0	25.0	0.3	187.5
122	1.1	25.3	0.3	191.5
123	1.0	25.0	0.3	160.0
124	1.0	24.8	0.3	160.0
125	1.1	27.0	0.3	153.5
126	1.0	25.0	0.3	150.0
127	1.0	24.5	0.3	149.5
128	1.0	26.0	0.3	148.5
129	1.0	25.8	0.3	150.0
130	1.0	24.5	0.3	155.5
131	1.0	25.0	0.3	163.0
132	1.0	23.8	0.3	161.5
133	1.0	24.8	0.3	154.0
134	1.0	24.5	0.3	155.5
135	0.9	23.3	0.3	158.0
136	0.9	23.3	0.3	163.0
137	0.9	22.5	0.3	162.0
138	1.0	24.5	0.3	155.5
139	0.9	23.3	0.3	160.5
140	0.9	22.0	0.3	158.0
141	1.0	23.8	0.3	164.5
142	0.9	23.3	0.3	164.5
143	0.9	21.3	0.3	168.0
144	0.9	22.3	0.3	170.0
145	0.9	23.3	0.3	170.5
146	0.9	22.8	0.4	175.5
147	0.9	23.0	0.3	170.0
148	1.0	23.8	0.3	196.0
149	1.0	24.5	0.3	182.0
150	0.9	22.8	0.3	182.0
151	0.9	21.3	0.3	157.5
152	0.9	21.8	0.3	154.5
153	0.9	22.0	0.3	158.0
154	0.9	23.0	0.3	151.0
155	0.9	23.5	0.3	149.0
156	0.9	22.0	0.3	148.0
157	1.0	24.0	0.3	150.0
158	0.9	22.8	0.3	154.0
159	0.8	20.0	0.3	165.0
160	0.8	20.5	0.3	170.0
161	0.8	21.0	0.3	164.0
162	0.8	20.8	0.3	170.5
163	0.8	20.5	0.3	173.0
164	0.8	20.8	0.3	168.0
165	0.8	20.3	0.3	172.5
166	0.8	19.8	0.4	179.5
167	0.8	20.3	0.4	181.5
168	0.8	20.5	0.4	177.0
169	0.8	20.3	0.4	179.5
170	0.8	20.5	0.4	182.5
171	0.8	20.5	0.4	178.5
172	0.8	21.3	0.4	175.0
173	0.8	20.8	0.3	174.5
174	0.8	20.8	0.4	175.0
175	0.8	20.3	0.4	178.5
176	0.8	19.8	0.4	179.0
177	0.8	20.5	0.3	170.5
178	0.8	20.3	0.3	180.0
179	0.8	20.8	0.3	158.5
180	0.9	22.5	0.3	182.0
181	0.9	22.8	0.3	180.5
182	0.9	22.5	0.3	155.5
183	0.9	21.3	0.3	153.5
184	0.9	22.8	0.3	163.0
185	0.9	22.8	0.3	164.5
186	0.9	22.8	0.3	161.5
187	1.0	24.0	0.3	162.5
188	1.0	24.8	0.3	147.0
189	1.0	24.8	0.3	144.0
190	1.0	26.0	0.3	138.0
191	1.0	25.3	0.3	135.0
192	1.0	25.8	0.3	134.5
193	1.0	25.0	0.3	137.5
194	1.1	26.3	0.3	140.5


RUNS

196	1.0	25.8	0.3	140.0
196	1.1	25.3	0.3	140.5
197	1.0	25.8	0.3	138.5
198	1.0	25.8	0.3	141.0
199	1.0	25.5	0.3	142.0
200	1.0	25.0	0.3	138.5
201	1.1	28.3	0.3	137.5
202	1.1	28.8	0.3	137.5
203	1.1	28.5	0.3	144.0
204	1.1	27.5	0.3	140.5
205	1.1	28.5	0.3	138.5
206	1.1	28.5	0.3	138.0
207	1.1	28.5	0.3	132.5
208	1.1	28.8	0.3	129.0
209	1.1	27.5	0.3	129.5
210	1.1	27.0	0.3	131.5
211	1.1	27.3	0.3	128.5
212	1.1	27.8	0.3	131.0
213	1.1	27.5	0.3	134.5
214	1.1	28.8	0.3	136.0
215	1.1	28.5	0.3	138.5
216	1.0	28.0	0.3	142.0
217	1.0	25.8	0.3	145.5
218	1.0	25.5	0.3	148.5
219	1.0	25.3	0.3	148.5
220	1.0	28.0	0.3	147.0
221	1.0	25.3	0.3	152.5
222	1.0	24.5	0.3	156.0
223	0.9	22.3	0.3	156.0
224	0.9	21.3	0.3	156.5
225	0.9	23.0	0.3	158.0
226	0.9	22.8	0.3	155.0
227	0.8	20.6	0.3	160.5
228	0.8	20.8	0.3	162.5
229	0.8	20.6	0.3	158.5
230	0.8	18.0	0.3	160.0
231	0.8	19.5	0.3	160.0
232	0.8	20.5	0.3	163.0
233	0.8	18.8	0.3	164.5
234	0.8	19.5	0.3	162.5
235	0.8	18.8	0.3	160.0
236	0.7	18.3	0.3	165.0
237	0.8	18.5	0.3	163.0
238	0.7	18.5	0.3	167.0
239	0.8	18.5	0.3	163.0
240	0.7	18.0	0.3	164.5
241	0.7	16.3	0.4	177.0
242	0.7	17.0	0.3	173.5
243	0.7	17.8	0.3	173.5
244	0.7	18.6	0.3	171.0
245	0.7	17.5	0.4	176.5
246	0.7	16.8	0.4	180.0
247	0.7	17.5	0.4	187.5
248	0.7	17.5	0.4	195.5
249	0.7	18.0	0.4	195.5
250	0.8	19.0	0.4	194.0
251	0.8	19.0	0.4	190.0
252	0.8	19.0	0.4	182.5
253	0.5	12.5	0.2	89.0
Stop Runs 5:30				
254	0.3	8.5	0.1	28.5
255	0.3	7.0	0.0	8.5
256	0.3	6.8	0.0	1.5
257	0.3	6.3	0.0	-2.5
258	0.2	5.8	0.0	-3.0
259	0.2	5.5	0.0	6.5
260	0.2	5.8	0.0	3.0
261	0.2	6.0	0.0	3.5
262	3.1	77.5	0.0	3.0
263	4.0	100.5	0.0	1.0
264	4.4	109.3	0.0	1.0
265	4.6	112.8	0.0	1.0
266	4.8	114.3	0.0	1.0
267	4.8	115.3	0.0	1.0
268	4.6	115.5	0.0	1.0
269	4.6	115.5	0.0	0.5
270	4.6	115.5	0.0	1.0
271	1.8	43.8	0.0	1.0
272	0.7	16.3	0.0	1.0
273	0.4	9.0	0.3	128.5
274	0.3	7.0	0.4	204.5
275	0.3	7.0	0.5	233.0
276	0.3	6.8	0.5	243.5
277	0.3	6.5	0.5	248.0
278	0.3	6.5	0.9	248.5
279	0.3	6.5	0.6	248.5
280	0.3	6.3	0.5	247.5
281	0.3	6.3	0.5	228.5
282	0.3	6.3	0.1	68.0
283	0.2	5.3	0.0	22.0
284	0.2	5.3	0.0	8.5
285	0.2	5.0	0.0	3.5
286	0.2	5.0	0.0	2.5

Average NOx 23.0      Average CO 174.8

Dryer #1

VOC Calibration, 6/2/95



7:40 am -  
7:43 -  
7:45 -

VOCCAL


FILE NAM a:voccal

LOGGING 1

ACTIVE C	1A	
MODULE	Voltage	
SAMPLE	15 sec	
UNITS:	Volts	VOC ppm
1	0.1	3.5
2	0.1	3.5
3	0.1	3.5
4	0.1	3.5
5	0.1	3.5
6	0.1	3.5
7	0.0	-1
8	0.0	-1
9	0.0	-1
10	0.0	0.5
11	0.0	1
12	0.0	-1
13	0.0	-1
14	0.1	5
15	0.0	-1
16	0.0	-1
17	0.0	-1
18	0.0	-1
19	0.1	4
20	7.4	371
21	7.5	372.5
22	9.9	495
23	9.9	494
24	9.9	493.5
25	9.9	492.5
26	9.8	492
27	9.4	471
28	0.1	6.5
29	0.5	27
30	4.0	200.5
31	4.0	200
32	4.0	200
33	4.0	200
34	4.0	199.5
35	4.0	197.5
36	3.9	196.5
37	0.1	6
38	0.4	21.5
39	1.0	49
40	1.0	49
41	1.0	49
42	1.0	49
43	1.0	49.5
44	1.0	51
45	0.2	8.5
46	0.1	6.5



Run #1 Dryer #1 6/2/95



Start  
8:30  
↳

STOP  
-  
~~10:55~~  
9:35

Average VOC 220.62

● VOC, ppm

FILE NAM e:voc1

LOGGING 1

ACTIVE C 1A  
 MODULE Voltage  
 SAMPLE 15 sec  
 UNITS: Volts VOC, ppm

1	0.0	2
2	0.1	2.6
3	0.1	2.6
4	0.0	2
5	0.0	2
6	3.7	185
7	4.3	214
8	4.4	218
9	4.6	225.5
10	4.6	225
11	4.6	230.5
12	4.7	237
13	4.6	226.6
14	4.7	237
15	4.8	237.6
16	4.6	229
17	4.6	226
18	4.6	231.5
19	4.6	230.5
20	4.6	223.5
21	4.7	235
22	4.8	239
23	4.7	238.5
24	4.9	244
25	5.1	252.5
26	4.8	238
27	4.9	246.5
28	6.2	291
29	5.1	266
30	5.2	269.5
31	5.3	264
32	5.1	253.5
33	5.0	249
34	5.0	251.5
35	5.2	259
36	5.1	253.5
37	6.0	251.5
38	5.0	251
Short Run1 8:30		
47	3.8	191
48	4.3	216.5
49	3.5	173.5
50	4.6	225.5
51	4.6	230.5
75	4.3	214.5
76	4.9	246
77	5.3	269.5
78	5.2	267.5
79	6.1	293.5
80	6.3	283
84	3.6	182
85	3.3	166
86	5.1	253
87	5.4	271.6
88	5.0	251
89	5.1	252.5
90	5.2	261
91	4.9	247
92	5.2	267.5
93	5.4	270
94	5.2	258
95	6.3	285
97	3.8	191
100	4.0	202
101	6.0	249
102	4.3	216.5
106	3.3	163
112	4.8	240
113	4.9	245
114	4.8	242
116	5.0	248
116	5.1	255.5
117	3.2	162
118	4.6	229
119	2.3	112.5
120	4.3	213
121	2.6	129.5
122	4.4	217.5
123	4.3	217
124	4.3	218.6
125	4.2	212
126	4.3	214.6
127	4.6	224
128	3.9	198
129	4.2	210
130	3.0	152
131	3.1	157
132	3.1	156.6
133	3.0	151
134	4.2	210
135	4.5	225.5
136	4.5	225.5


138	3.8	190.5
139	4.6	227.5
141	4.5	224
142	4.5	223.5
143	4.3	215.5
144	4.2	212
145	4.5	223.5
146	0.4	20.5
147	4.2	210
148	4.6	232
150	4.4	219
151	4.5	232
152	4.9	243.5
153	4.9	242.5
154	4.7	235
165	4.9	245.5
166	6.6	331.5
167	5.0	299
168	5.7	282.5
189	3.8	180.5
171	3.5	175.5
172	5.0	261.5
173	6.0	301.5
174	6.2	310.5
176	5.5	275
177	5.4	288
178	5.1	255
179	4.7	237
180	5.0	251
181	4.3	214
182	4.5	224
183	5.3	266.5
184	4.7	234.5
185	2.2	109.5
186	4.9	242.5
187	4.6	231.5
197	4.7	237
198	4.6	227.5
199	4.2	208
200	5.2	257.5
201	4.1	205
202	4.9	246
203	3.7	187
204	5.0	248.5
205	4.9	248
206	4.2	207.5
207	5.0	247.5
208	2.5	122.5
211	4.2	210.5
212	5.0	250
213	4.9	247
214	5.1	256
215	5.3	265
218	3.5	176.5
219	5.1	256
220	4.8	241.5
221	2.8	142
222	5.2	261
223	4.0	200.5
224	5.1	255
225	5.3	265
226	4.6	231.5
228	5.2	257.5
229	4.3	214.5
230	4.9	242.5
231	4.8	239.5
232	4.9	245.5
233	5.1	255
234	5.0	250.5
235	3.8	188.5
237	4.8	242
238	4.8	238.5
239	4.9	247
240	4.8	239.5
241	4.9	245
242	4.9	245
243	4.9	245
244	2.3	113.5
245	3.1	154.5
246	5.0	247.5
247	3.8	192
248	4.9	246
249	5.0	248
250	4.6	225
251	4.8	238
252	4.9	248.5
253	4.3	218
254	4.9	247
255	5.0	251.5
256	5.1	254
257	5.0	249
258	3.9	194.5
259	4.8	240.5
260	4.8	241
261	4.8	245.5
262	4.8	239.5
270	4.0	198.5
271	3.6	179.5
272	3.5	175
273	3.6	176
274	3.5	180
275	3.7	185
276	3.6	179

277	3.8	188.5
278	3.7	182.5
279	3.7	182.5
280	3.4	171.5
281	3.7	186
282	3.7	187
283	3.8	188.5
284	4.0	189
285	3.9	197
286	3.8	191.5
287	3.9	196
288	3.9	196
289	3.9	195.5
290	2.9	145.6
291	3.7	184.6
292	3.9	196
293	4.1	203.6
294	4.2	212
295	4.3	213
296	4.4	221
297	4.6	228
298	4.5	224.6
299	4.1	204.5
300	4.6	231
301	4.3	212.6
302	4.5	226.5
303	4.8	231.5
304	4.5	224
305	4.5	223.5
306	4.5	226
307	4.6	228
Stop Run 1		Average VOC
10:35		220.628
308	1.7	85
308	0.0	-1
310	0.0	-1
311	0.0	-1
312	0.0	-1
313	0.0	-1
314	0.0	-1
315	1.1	54.5
316	1.1	54
317	0.8	40.5
318	0.7	34
319	0.6	31
320	0.6	29
321	0.5	26
322	0.2	11
323	0.5	22.5
324	0.5	26.5
325	0.5	22.5
326	0.4	20
327	0.4	19
328	0.4	18
329	0.4	17.5
330	0.3	17
331	0.3	12.5
332	0.3	12.6
333	0.2	12
334	0.2	11
335	0.2	11
336	0.2	10.5
337	0.2	10
338	0.2	11
339	0.2	10.5
340	0.2	9.5
341	0.2	9
342	0.2	9
343	0.2	8.5
344	0.2	8.5
345	0.2	8.5
346	0.2	8.5
347	0.2	8
348	0.2	7.5
349	0.2	10
350	0.2	10.5
351	0.1	7
352	0.1	7
353	0.1	7
354	0.1	6.5
355	0.1	6.5
356	0.1	7
357	0.1	6
358	0.1	6
359	0.1	7
360	0.1	6.5
361	0.1	6
362	0.1	6
363	0.1	6
364	0.1	5.5
365	0.1	5.5
366	0.1	5.5
367	0.1	6
368	0.1	5.5
369	0.5	24
370	0.7	36.5
371	3.6	173
372	3.9	197
373	4.0	201
374	4.1	204.6
375	4.0	197.5
376	3.9	194.5
377	3.9	197

VOC1

378	1.5	73.5
379	0.6	30

Run #2 Dryer #1 6/2/95



Average 310.6

Start  
~~10:00~~  
10:13

1 1

STOP -  
11:20

FILE NAM a:voc2

LOGGING 1

ACTIVE C MODULE SAMPLE UNITS:	1A Voltage 15 sec Volts	VOC ppm
1	1.7	87.0
2	1.7	83.0
3	1.0	51.5
4	0.3	16.0
5	3.5	177.0
6	4.1	204.0
7	4.4	220.5
8	4.4	218.5
9	4.5	224.0
10	4.8	238.5
11	5.1	256.0
12	5.2	257.5
13	4.7	236.0

Start Run2  
10:13

14	5.0	251.0
15	5.3	283.5
16	5.4	269.0
17	5.1	256.6
18	6.0	251.5
19	4.9	245.0
20	5.1	255.6
21	5.3	264.5
22	5.4	271.5
23	5.5	275.5
24	5.5	272.5
25	5.3	264.5
26	5.8	278.0
27	5.5	275.5
28	5.7	283.5
29	6.0	299.5
30	5.8	289.5
31	6.0	297.5
32	6.1	303.0
33	6.0	299.5
34	5.8	291.5
35	10.0	499.0
36	5.9	294.5
37	6.1	305.0
38	5.7	283.5
39	5.8	287.5
40	5.9	285.5
41	5.9	293.5
42	5.9	282.5
43	5.5	277.0
44	5.5	274.5
45	5.6	278.0
46	5.4	272.0
47	5.4	270.5
48	5.5	275.5
49	5.5	280.5
50	5.9	295.0
51	5.9	296.5
52	6.1	304.5
53	5.9	293.5
54	5.5	274.0
55	5.6	277.5
56	5.8	289.0
57	5.9	293.5
58	5.8	287.5
59	5.9	297.0
60	6.0	300.0
61	2.7	134.5
62	5.5	275.5
63	5.7	284.0
64	5.6	280.5
65	5.7	284.5
66	5.7	287.0
67	5.1	253.0
68	5.3	265.0
69	5.4	269.5
70	5.4	267.5
71	5.7	289.0
72	5.5	277.0
73	6.0	299.0
74	6.2	309.5
75	5.9	295.0
76	5.9	296.0
77	5.6	279.5
78	5.4	271.5
79	5.5	275.5
80	5.5	274.5
81	5.8	287.5
82	5.7	283.0
83	5.1	253.0
84	5.5	275.5
85	5.8	278.5
86	1.1	53.5
87	5.1	256.0
88	5.5	273.5
89	5.8	281.5
90	5.8	280.0
91	5.8	282.0

82	6.0	300.5
83	6.0	301.5
84	6.2	308.0
85	5.6	280.0
86	3.0	151.0
87	5.8	287.5
88	5.8	290.0
89	5.6	280.5
90	5.8	290.5
91	6.1	305.5
92	6.2	309.5
93	5.6	281.0
94	5.9	293.5
95	6.0	297.5
96	6.0	298.5
97	6.1	302.5
98	6.3	312.5
99	6.1	305.5
100	6.0	304.5
101	6.2	308.0
102	5.7	283.5
103	6.0	299.0
104	6.2	308.5
105	6.2	311.5
106	5.9	295.0
107	6.0	298.5
108	6.1	302.5
109	1.4	68.5
110	6.4	318.5
111	6.3	313.0
112	6.4	318.0
113	6.6	328.5
114	6.3	312.5
115	6.0	299.0
116	6.1	302.5
117	6.1	303.5
118	6.0	302.0
119	6.2	311.0
120	6.4	320.0
121	6.2	311.0
122	6.5	325.5
123	1.5	72.5
124	6.0	298.5
125	6.1	304.0
126	6.5	323.0
127	6.5	323.5
128	6.8	336.5
129	6.4	320.0
130	6.7	334.5
131	6.4	317.5
132	6.5	326.5
133	6.7	336.0
134	6.7	336.0
135	6.8	339.0
136	6.8	338.5
137	6.6	331.0
138	6.6	332.0
139	6.2	310.0
140	6.3	314.0
141	4.2	210.0
142	6.4	321.5
143	6.6	328.0
144	6.6	332.0
145	6.4	317.5
146	6.0	300.5
147	5.9	298.5
148	6.2	308.0
149	6.2	309.5
150	6.2	310.5
151	5.6	278.5
152	5.7	284.0
153	5.8	290.5
154	5.9	298.5
155	6.1	303.0
156	6.2	311.5
157	6.4	320.5
158	6.7	334.0
159	6.8	338.5
160	6.3	312.5
161	6.2	307.5
162	6.6	327.0
163	5.6	281.0
164	5.9	294.0
165	6.2	311.0
166	6.0	300.0
167	5.8	291.5
168	6.2	308.5
169	6.4	317.5
170	6.1	303.5
171	6.4	317.5
172	6.2	308.5
173	6.5	323.5
174	6.7	336.0
175	6.8	338.5
176	6.8	340.5
177	7.0	350.5
178	6.8	340.5
179	6.8	337.5
180	7.2	357.5
181	6.8	339.5
182	6.8	339.0
183	6.8	342.0
184	7.0	348.5



VOC2

195	6.5	323.5
196	6.9	343.5
197	6.7	335.0
198	6.7	336.0
199	7.2	358.5
200	7.5	376.5
201	7.2	360.0
202	7.5	373.5
203	7.9	395.0
204	7.1	357.0
205	7.2	360.5
206	7.6	380.5
207	7.7	383.5
208	7.6	378.0
209	6.6	328.5
210	6.8	338.5
211	7.1	353.5
212	7.3	363.5
213	7.8	391.0
214	8.0	399.0
215	8.0	397.5
216	8.3	412.5
217	7.3	363.0
218	7.4	369.0
219	7.5	375.0
220	7.6	377.5
221	7.9	392.6
222	7.7	388.6
223	7.7	389.0
224	7.9	396.5
225	7.7	383.5
226	7.9	392.6
227	7.0	349.0
228	6.7	334.0
229	6.8	341.5
230	0.9	43.5
231	7.1	356.5
232	7.0	344.0
233	7.0	348.0
234	6.6	328.0
235	6.9	346.0
236	7.1	357.0
237	6.8	339.0
238	6.4	317.5
239	6.6	325.5
240	6.3	316.0
241	6.4	319.5
242	4.5	223.0
243	6.9	345.5
244	7.0	351.0
245	6.9	342.5
246	6.8	336.0
247	6.5	327.0
248	6.6	331.5
249	7.0	349.0
250	7.0	350.5
251	7.1	352.5
252	7.3	365.5
253	7.5	374.5
254	6.3	314.0
255	5.8	289.0
256	4.3	213.5
257	6.2	310.5
258	6.7	284.5
259	6.1	307.0
260	6.3	317.0
261	6.5	325.5
262	6.9	342.5
263	7.0	347.5
264	7.0	350.5
265	7.3	367.0
266	7.5	377.0
267	7.7	385.0
268	7.6	381.5
269	4.8	241.0
270	6.2	312.0
271	6.0	301.0
272	6.4	320.0
273	5.7	285.5
274	6.1	302.5
275	6.8	337.5
276	7.0	350.5
277	7.6	380.0
278	8.0	400.5
279	8.2	408.0
280	6.7	334.0
281	4.9	248.0
282	6.2	306.5
283	6.8	339.0
284	7.2	360.5
285	7.3	364.0
286	7.2	362.0

Stop Run2  
11:20


Average VOC  
310.6

287	1.2	57.5
288	2.7	138.5
289	1.7	87.0
290	1.4	72.0
291	1.3	64.0
292	1.1	56.5
293	1.0	62.0
294	1.0	48.5
295	0.9	48.0

296	0.9	43.0
297	0.8	41.5
298	0.7	36.0
299	0.7	36.0
300	0.7	34.0
301	0.7	33.0
302	0.6	31.0
303	0.6	29.6
304	0.6	28.6
306	0.6	28.0
308	0.6	27.0
307	0.6	26.5
308	0.6	25.6
309	0.3	16.0
310	0.6	28.6
311	0.6	23.6
312	0.6	22.5
313	0.4	22.0
314	0.4	21.0
315	0.4	21.0
316	0.4	20.0
317	0.4	20.0
318	0.4	19.0
319	0.3	14.5
320	0.3	14.5
321	0.3	14.0
322	0.3	14.0
323	0.3	13.5
324	0.3	13.0
325	0.3	13.0
326	0.3	14.5
327	0.3	13.0
328	0.3	12.6
329	0.2	11.6
330	0.2	11.0
331	0.2	12.0
332	0.2	11.0
333	0.2	11.0
334	0.2	11.6
335	0.3	12.6
336	0.2	11.0
337	0.3	13.0
338	0.2	10.6
339	0.2	10.0
340	0.2	9.6
341	0.2	9.0
342	0.2	9.0
343	0.2	10.6
344	0.2	10.6
345	0.2	9.6
346	3.0	149.6
347	3.4	172.0
348	3.7	184.6
349	3.8	187.6
350	3.9	192.6
351	3.6	177.0
352	3.6	181.6
353	3.7	184.0
354	2.6	130.0
355	0.4	18.0
356	0.3	13.6
357	0.3	12.6
358	0.2	11.6
359	0.1	6.0
360	0.1	6.6
361	0.2	9.0
362	0.2	8.6

Run #3 VOC

Run #3 Dryer #1 6/2/96



Average 299.3 ppm

FILE NAM avoc3

LOGGING 1 \*\*\*\*\*  
\*\*\*\*\*

ACTIVE C 1A  
MODLLE Voltage  
SAMPLE 15 sec  
UNITS: Volts VOC, ppm

1	9.8	489.5
2	8.6	328.5
3	0.1	6.0
4	0.1	5.0
5	8.4	418.0
6	7.9	394.5
Start Run 3		
11:45		
7	7.5	375.0
8	7.6	379.6
9	8.4	421.0
10	7.3	367.0
11	6.7	335.6
12	7.5	375.6
13	7.3	365.5
14	6.7	335.0
15	7.1	354.0
16	7.1	353.5
17	7.1	353.0
18	7.2	358.5
19	7.0	351.0
20	6.8	332.0
21	7.8	388.5
22	7.4	371.0
23	7.0	352.0
24	7.6	379.5
25	7.1	354.5
26	7.0	351.5
27	7.5	373.5
28	7.9	392.5
29	7.8	388.5
30	7.1	355.0
31	7.8	388.5
32	7.5	373.6
33	7.5	375.6
34	7.8	379.6
35	7.2	358.5
36	7.0	352.0
37	7.2	360.5
38	6.4	319.0
39	6.6	330.5
40	7.2	358.5
41	6.8	341.5
42	6.8	342.0
43	7.0	350.0
44	6.8	330.5
45	6.6	327.5
46	6.5	327.0
47	6.4	319.5
48	6.3	314.5
49	6.4	321.5
50	6.3	315.0
51	6.3	313.5
52	6.4	318.5
53	6.2	310.5
54	5.8	290.5
55	6.1	304.0
56	5.9	294.0
57	5.7	286.0
58	6.2	311.0
59	6.2	308.5
60	6.0	299.0
61	6.1	305.0
62	6.5	323.0
63	6.5	325.0
64	6.1	307.0
65	6.7	335.0
66	6.5	328.0
67	6.7	338.5
68	6.8	341.0
69	6.8	341.0
70	6.7	334.5
71	6.5	323.5
72	6.1	302.5
73	6.3	313.5
74	6.1	306.0
75	6.8	282.0
76	5.7	285.0
77	5.8	292.0
78	5.7	285.0
79	5.9	293.0
80	5.9	298.6
81	6.1	303.0
82	5.6	282.0
83	5.9	294.5
84	5.9	294.0
85	5.8	288.5
86	5.7	282.5
87	5.6	280.0
88	5.4	270.0
89	5.4	270.5
90	5.6	277.5
91	5.8	280.5

VOCs

82	5.2	251.5
83	4.9	245.0
94	6.0	247.5
95	4.7	237.0
96	4.7	235.0
97	4.7	233.5
98	5.0	250.0
99	5.3	254.0
100	5.3	256.0
101	5.1	255.5
102	5.1	254.5
103	5.0	249.5
104	5.9	294.0
105	5.6	280.0
106	5.2	251.0
107	5.8	287.5
108	5.4	270.5
109	5.4	258.0
110	5.8	287.5
111	6.0	301.0
112	5.7	263.0
113	5.8	290.0
114	6.1	305.5
115	5.7	283.0
116	6.0	299.5
117	6.0	301.0
118	6.9	293.0
119	6.1	305.5
120	6.4	318.5
121	6.0	301.0
122	6.5	326.5
123	6.8	332.0
124	6.1	305.0
125	6.0	299.0
126	6.8	338.0
127	6.9	345.5
128	4.3	214.5
129	7.8	379.0
130	8.1	405.0
131	8.3	414.5
132	8.6	425.0
133	8.8	441.0
134	7.7	384.6
135	7.7	383.0
136	7.7	385.0
137	7.1	354.0
138	7.1	355.0
139	7.0	349.0
140	6.3	315.0
141	6.3	314.5
142	6.6	329.0
143	6.1	304.0
144	6.1	305.5
145	6.3	313.5
146	6.0	299.0
147	5.9	294.0
148	6.6	329.0
149	6.6	328.5
150	6.1	302.5
151	6.5	323.5
152	6.8	341.0
153	6.4	319.5
154	5.9	292.5
155	6.8	340.5
156	6.5	325.5
157	5.7	287.0
158	6.9	347.0
159	6.7	336.0
160	6.5	325.5
161	7.2	361.5
162	6.8	341.0
163	6.4	320.0
164	6.8	342.0
165	6.6	330.0
166	6.4	318.0
167	6.8	341.0
168	6.8	340.5
169	6.2	311.5
170	7.3	367.0
171	7.9	393.5
172	6.9	344.0
173	6.7	336.5
174	6.0	401.0
175	6.1	403.5
176	7.4	368.5
177	7.8	388.5
178	7.3	354.0
179	7.1	357.0
180	7.5	376.5
181	7.2	358.0
182	7.4	372.0
183	7.8	388.5
184	7.3	366.0
185	6.7	337.0
186	6.6	331.5
187	6.7	338.5
188	6.1	305.5
189	6.0	301.0
190	6.3	317.0
191	5.9	295.0
192	5.9	294.5
193	5.9	295.5
194	5.2	260.5

VOCs

195	5.4	271.6	
196	5.8	288.0	
197	5.4	272.0	
198	4.7	233.6	
199	5.6	279.0	
200	5.5	277.0	
201	5.0	250.0	
202	5.5	276.5	
203	5.0	251.5	
204	4.6	230.5	
205	5.2	261.5	
206	5.3	267.0	
207	5.2	260.0	
208	5.3	264.0	
209	4.8	241.0	
210	5.0	252.0	
211	4.8	240.5	
212	4.7	232.5	
213	4.6	227.5	
214	4.5	227.0	
215	4.5	224.5	
216	4.2	211.0	
217	4.1	202.5	
218	0.6	29.6	
219	3.7	183.5	
220	3.7	185.0	
221	4.3	213.0	
222	4.0	200.5	
223	3.9	195.5	
224	4.1	202.6	
225	4.0	199.5	
226	3.9	192.5	
227	4.1	203.5	
228	4.0	202.0	
229	4.1	205.0	
230	4.1	207.0	
231	4.3	217.0	
232	3.9	197.0	
233	3.9	194.0	
234	4.0	197.5	
235	3.9	196.5	
236	3.9	194.0	
237	3.9	193.0	
238	3.9	193.0	
239	3.8	188.0	
240	3.8	188.5	
241	3.6	181.5	
242	3.5	175.5	
243	3.4	171.5	
244	3.5	175.0	
245	3.4	169.5	Average VOC
246	3.3	165.0	299.3
247	3.4	168.5	
248	3.2	162.0	
249	3.2	160.6	
Stop Run#3			
12:45			
250	0.6	32.0	
251	0.3	17.0	
252	0.3	16.5	
253	0.3	14.0	
254	0.3	13.0	
255	0.2	12.0	
256	0.2	11.5	
257	0.2	11.0	
258	0.2	11.0	
259	0.2	10.5	
260	0.2	10.0	
261	0.2	10.0	
262	0.2	10.0	
263	0.2	10.0	
264	0.2	9.5	
265	0.2	10.0	
266	0.2	9.5	
267	0.2	9.5	
268	0.2	9.5	
269	0.2	10.0	
270	0.1	5.0	
271	0.1	4.5	
272	0.1	4.5	
273	0.1	4.5	
274	0.2	8.5	
275	0.2	8.0	
276	0.2	8.5	
277	3.9	184.0	
278	3.9	184.5	
279	3.9	184.5	
280	3.9	184.0	
281	3.9	184.0	
282	3.9	183.5	
283	3.9		

Dmc #2

10:25 - 11:23

Run 1

11  
9  
10  
10.5  
14  
10.5  
10.5  
13  
10  
13.5  
10.5  
7  
8.5  
4  
12  
15  
12  
11.5  
9.5  
11  
10.5  
11  
10.5  
9  
9  
10  
11

$281 \div 27$

$\rightarrow 10.4 \times 5$

$\rightarrow 52.04 \text{ ppm}$

LP Corrigan  
#2 Inlet 6/1/95

CO  
2:45 - 3:45  
Run 2

12  
12.5  
12  
14  
15.5  
16.5  
18.5  
14.5  
11  
11  
12  
10  
10  
10  
10  
13  
12  
11.5  
11.5  
10  
11  
14  
11.5  
10  
10  
10  
11  
11.5  
13  
12.5

$(352 \div 30) \times 0.5$

$\rightarrow 11.23 \times 5$

$\rightarrow 56.17 \text{ ppm}$

4:27 - 5:27

Run 3

14  
14  
13  
13  
11  
8  
7  
12  
10  
9  
8  
10  
9  
9  
9  
9  
7  
13.5  
12  
9  
10  
8  
8.5  
9  
8  
12  
10  
7  
8  
9  
10

$289 \div 30$

$\rightarrow 9.567 \times 5$

$\rightarrow 47.83 \text{ ppm}$

Dip #2

LP Carigan  
#2 Inlet

6/1.95

NOX  
2.45-3.45

Run 1

Run 2

Run 3

D

14

24

A

14

26

T

17

27

A

13

25

N

12

26

O

15

32

O

17

28

O

17

27

G

18

27

O

22

25

O

21

29

D

17

27

P

17

29

O

17

29

O

15

27

R

15

32

R

16

30

S

15

27

E

14

32

N

12

30

S

6

28

S

14

31

I

14

28

T

14

34

I

14

31

V

13.5

29

I

13.5

29

T

11

33

Y

10

29

Y

11

32

kont-0325

$(441 \div 30) - 12$

$(869 \div 30) - 2$

$\rightarrow 13.7 \times 1.35$

$\rightarrow 26.96 \times 1.07$

$\rightarrow 18.49 \text{ ppm}$   
18.49

$\rightarrow 28.84 \text{ ppm}$



Dmcut#2

830 - 9:34

LP Comgan  
#2 Inlet 6/2/95  
NOX

Run 1

Run 2

Run 3

29  
27  
29  
28  
27  
27  
25  
28  
27  
25  
25  
29  
25  
24  
22  
23  
24  
23  
15  
12  
18  
17  
18  
23  
24  
24  
24  
23  
24

24  
24  
23  
26  
24  
24  
25  
22  
21  
22  
23  
22  
19  
17  
17  
15  
16  
18  
18  
20  
15  
17  
23  
23  
24  
19  
23  
27  
21  
24  
21  
26

27  
26  
25  
27  
30  
30  
27  
29  
29  
27  
30  
29  
31  
30  
32  
33  
27  
27  
26  
28  
31  
28  
27  
32  
31

$(600 \div 30) \cdot 0.5$   
 $21.95 \times .977$

21.44 ppm

$(685 \div 30) \cdot 0.5$   
20.25 ppm

$807.5 \div 30$

$26.91 \times .977$

26.29 ppm

Dry #2)  
830-932

LP Corrigan  
#2 Inlet 6/2/95  
VOL

Run 1	Run 2 10:13 - 11:23	Run 3
22 23	19 23	14 29
14 12	23 23	16 27
8 20	23 23	15 29
5 14	24 23	17 27
4 18.5	23 23.5	16 27
4 10	23 20	16 27
3 14	24 24	15 27
4 8	25 24	15 25
3 6	23 26	17 30
3 16	26 25	18 30
6 26	25 22.5	18 30
5 25	25 25	18 29
2 24	28 23	17 30
2.5 26	26 23	19 31
3 23	26 22	20 30
3 23	29 21	21 32
2.5 22	29 21	22 33
2 22	28 22	22 27
2 4.5	27 22	24.5 27
2.5 19	29 23	22 24
4 23	28 23	23 29
4 23	29 23.5	23 29
4 22	26.5 23.5	24 27
4.5 23	28 23.5	24 26
6	26 23	24 26
4	25 21	23 28
7	24 20.5	22 27
10	25 20.5	25 27
20	26	25 25
21	23	26 23

$(632 \div 54)$


$(1381 \div 58) - 0.5$

$6.35 \times (1448.5 \div 60)$

117 x 10  
117.04 ppm

23.31 x 10  
233.1 ppm

24.14 x 10.81  
260.97 ppm








CHART NO. RC-3135


A1092


CHANGED TO 5ml capacity tube

POWER OFF









8:45  
START RUN @

646-1-109


50.8


100 K.8


29.7 MIN. REST


12














END




RC-3135

A1372



























AUSTIN, TEXAS CHART TYPE RC-3135 PRINTED IN U.S.A.



HOUSTON INSTRUMENT

AUSTIN, TEXAS


CHART TYPE RC-3135

PRINTED IN U.S.A.


STATION Run A 10/13



HOUSTON INSTRUMENT








HOUSTON INSTRUMENT

AUSTIN, TEXAS

CHART TYPE RC-3135

PRINTED IN U.S.A.

10/10/50



HOUSTON INSTRUMENT

AUSTIN, TEXAS

LP Compen  
 #3 Inlet (Dye #3) 6/1/55  
 CO

Run 1

Run 2

Run 3

21  
 23  
 25  
 26  
 25  
 26.5  
 25  
 23  
 23  
 22  
 23.5  
 23  
 23  
 21  
 22  
 21  
 18  
 19.5  
 19  
 20.5  
 21  
 20  
 22  
 19  
 19  
 19  
 18.5  
 20  
 22  
 20

17  
 17  
 17  
 17  
 19  
 15  
 14.5  
 12  
 11.5  
 13  
 13  
 12.5  
 11.5  
 12  
 14  
 14.5  
 16  
 16  
 14  
 13  
 13  
 13  
 13  
 13  
 12  
 12.5  
 14  
 15  
 15.5  
 16.5  
 17  
 17  
 12.5

10  
 10  
 9.5  
 10  
 9.5  
 9.5  
 9.5  
 10  
 11.5  
 12  
 11.5  
 10  
 13  
 13  
 13  
 13  
 11  
 11.5  
 11  
 12  
 14  
 13  
 13  
 13  
 13  
 13.5  
 12.5  
 12  
 9  
 9.5  
 8  
 9  
 10  
 9.5

$633.5 \div 30$

$\rightarrow 21.12 \times 30$

$\rightarrow 211.17 \text{ ppm}$

$486.5 \div 34 = 14.31$

$13.31 \times 9.75$

$\rightarrow 75.12 \text{ ppm}$

$(391.5 \div 34) = 11.51$

$10.76 \times 10$

LP Compar  
 #3 Inlet (Inu#3) 6/1/95  
 NOX

Run 1	Run 2	Run 3
22	22	17
23	18	17.5
24	19	17
26	20	18.5
26	19	18
27	18	20
25	18	22
24	16	22.5
24	15	22
25	17	22
25	16	23
25	15	23
15	17	21.5
14	14	21
12.5	13	21
12	14.5	22
10	13	21
9	13.5	19.5
9	12	19
9	12.5	19
8	11.5	18.5
8	9	17
8	9	20
8	9.5	17.5
8	9.5	19
6.5	9	17
6.5	12	24
7	10.5	20
6.5	9	19
6	10	19
	10.5	20
	11.5	16
	11	22

$(451 \div 30) - 1$   
 $14.03 \times 1.165$

17.51 ppm

$(454.5 \div 37) + 6.25$   
 $20.02 \times 1$

20.02 ppm

$678.5 \div 33$

20.56 ppm

LP Corrigan  
 #3 Inlet Pmc #3 6295  
 VOC

Run 1

26 27  
 23 25  
 24 25  
 24 22  
 25 26  
 25 27  
 24 28  
 24 29  
 25 29  
 24 31  
 24 31  
 25 30  
 27 29  
 26 30  
 27 29  
 30 30  
 30 30  
 29 29  
 30 27  
 29 26  
 29 24  
 29 22  
 27 21  
 25 20  
 25 27  
 24 26  
 26 24  
 27 23  
 29 23  
 28 24  
 26 27  
 28 29  
 29 27

Run 2

28 38  
 26 37  
 25.5 37  
 25 36  
 26 35  
 30 37  
 32 39  
 33 39  
 35 40  
 35 41  
 37 42  
 36 43  
 36 38  
 36 40  
 38 38  
 36 38  
 39 39  
 40 36  
 39 35  
 33 24  
 37 34  
 36 24  
 35 34  
 36 24  
 30 37  
 31 31  
 30 38  
 30 40  
 32 42  
 36 46  
 38 48  
 38 58

Run 3

45 33  
 44 37  
 43 47  
 43 45  
 41 40  
 39 36  
 38 38  
 34 47  
 31 49  
 30 49  
 30 44  
 33 45  
 36 45  
 40 45  
 41 44  
 41 42  
 42 41  
 42 40  
 42 41  
 42 36  
 42 34  
 42 33  
 44 32  
 46 34  
 50 36  
 52 35  
 47 33  
 42 33  
 38 32  
 34 32

2310 ÷ 10

38.5 x 5

113  
 2050 ÷ 66


2288.5 ÷ 64


35.75 x 513

31 x 5.26  
 163.38 ppm


183.44 ppm

192.5 ppm






P.O. BOX 3, San Marcos, Tx 78667 Tel. 512-6291400









Start Run #2

2:45

4.1

Max





01

5

3

1

2

5

7

5

2

1

0

5/27/57 Ken W B


4:27


N25


Adjust Stem  
400 PPM (0)

29.7 NOK


29.7 PPM  
NOK





















CHART NO. RC-3135









CHART NO. RC-3135




APPENDIX D

# PARTICULATE FIELD DATA


$V_{std} = 34.856$   
 $V_{std} = 7.192$   
 $B_{ws} = 17.10$   
 $Vel = 37.43$   
 $I = 109.49$

PLANT: LP-Corrigan  
 DATE: 6-1-95  
 REPETITION: 1  
 LOCATION: Corrigan, TX  
 OPERATOR: TA JDC CS  
 STACK #: #1 cyclone inlet  
 SAMPLE BOX #: 10  
 METER BOX #: 11  
 AMBIENT TEMPERATURE: 80  
 BAROMETRIC PRESSURE: 29.85  
 ASSUMED MOISTURE: 12  
 PROBE LENGTH: 6'  
 NOZZLE IDAMETER: 1/4" .251, .249, .250 (.000341)  
 STACK DIAMETER: 54" x 54"  
 METER H: 1.559635  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.012793



IMPINGERS	
Initial	Final
#1:	210
#2:	105
#3:	
#4:	212.8
#5:	127.8

COMMENTS  
 $CO_2$  2.5%  
 $O_2$  16.5%



FILTER TARE:  
 PRE-TEST LEAK CHECK  
 Meter: .005 cu. ft. 15 in. HG  
 Pitots: ✓

POST-TEST LEAK CHECK  
 Meter: .006 cu. ft. 10 in. HG  
 Pitots: ✓

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
A1	10:25	-9.7	196	.18		.45	533.621	75	74	260	59	1
2			197	.18		.45	534.6	75	74	261	59	1
3	30		197	.19		.46	535.6	76	74	260	59	1
4			198	.23		.55	536.6	76	74	262	59	1
5	35		198	.25		.60	537.7	77	75	261	60	1
B1	37/38		196	.22		.53	539.9	78	75	260	60	1
2			197	.24		.57	539.9	78	75	261	60	1
3	43		197	.26		.62	541.1	79	76	260	60	1
4			198	.33		.79	542.3	80	76	261	60	1
5	48		197	.39		.94	543.6	81	76	260	60	1
C1	51/52		196	.23		.55	545.1	80	76	261	61	1
2			197	.24		.57	546.2	81	77	259	61	1
3	57		198	.31		.74	547.4	82	78	258	61	1
4			197	.43		1.0	548.6	82	78	260	61	1
5	1102		197	.54		1.3	550.2	82	79	261	61	1
D1	04/05		196	.35		.84	551.8	83	79	260	61	1
2			197	.49		1.2	553.2	82	80	261	62	1
3	10		198	.54		1.3	554.9	83	80	260	62	1
4			197	.65		1.6	556.5	84	80	259	62	1
5	15		196	.68		1.6	558.4	84	80	259	62	1
E1	17/18		196	.41		.98	560.4	85	81	256	62	1
2			197	.46		1.1	561.8	85	81	256	62	1
3	23		196	.57		1.4	563.4	85	81	256	62	1
4			196	.65		1.6	565.2	85	82	256	62	1
5	1128		196	.70		1.7	567.0	85	82	257	62	1
AV	11:31		196.9			.689	568.947		79.32			



# PARTICULATE FIELD DATA

Umsstd: 31.198  
 Vwstd: 9.886  
 Bues: .2359  
 Vel: 35.267  
 I =

PLANT: LP Corrigan  
 DATE: 6-1-95  
 REPETITION: 2

LOCATION: Inlet  
 OPERATOR: JSA TA  
 STACK #: Dayer #1  
 SAMPLE BOX #: 9  
 METER BOX #: 11  
 AMBIENT TEMPERATURE: 87°  
 BAROMETRIC PRESSURE: 29.85  
 ASSUMED MOISTURE: 2.0%  
 PROBE LENGTH: 6'  
 NOZZLE ID DIAMETER: 1/4" x 5/16"  
 STACK DIAMETER: 54 x 54"  
 METER # : 1-559635  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.012793

IMPINGERS		Initial	Final
#1:	100 mL	> H2O	268
#2:	100 mL	> H2O	108
#3:	-		
#4:	200 g	56	208.9
#5:			184.9

COMMENTS

O<sub>2</sub>      CO<sub>2</sub>  
 16.0%      4.0%

FILTER TARE: 4.985  
PRE-TEST LEAK CHECK  
 Meter: .009 cu. ft. 14 in. HG  
 Pitots: LL in. H2O

POST-TEST LEAK CHECK

Meter: .010 cu. ft. 10 in. HG  
 Pitots: in. H2O

P	⊖	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP OUTLET TEMP.	VAC (IN)
A1		2.95	196	.12		.26	569.387	82	82	250	60	1.0
2			197	.13		.29	70.157	84	84	255	60	1.0
3			194	.16		.35	70.9	85	84	251	60	1.0
4			195	.19		.42	71.44	86	84	253	60	1.0
5			197	.23		.50	72.8	87	84	251	60	1.0
B1			195	.16		.35	73.881	87	85	255	60	1.0
2			194	.18		.40	74.7	87	85	255	60	1.0
3			196	.25		.55	75.71	88	85	254	60	1.0
4			197	.35		.77	76.82	88	85	256	60	1.0
5			195	.35		.77	78.145	89	85	255	60	1.0
C1			195	.22		.48	79.460	88	85	256	60	1.0
2			196	.23		.50	80.503	88	85	257	60	1.0
3			197	.32		.70	81.579	88	86	257	60	1.0
4			197	.40		.88	82.8	89	86	251	60	1.0
5			196	.49		1.18	87.234	90	87	256	60	1.0
D1			195	.30		.66	85.790	90	87	251	60	1.0
2			194	.33		.72	87.000	90	87	253	60	1.0
3			194	.42		.92	88.2	90	88	256	60	1.0
4		9.6-	195	.53		1.2	89.7	91	88	251	60	1.0
5			196	.65		1.4	91.34	91	88	256	60	1.0
E1			195	.38		.83	93.44	92	89	256	60	1.0
2			196	.44		.96	94.51	92	89	253	60	1.0
3			195	.56		1.2	95.945	92	89	255	60	1.0
4			195	.63		1.4	97.6	92	89	254	61	1.0
5			196	.69		1.5	99.41	92	89	256	61	1.0
AV		3.54				.5783	1601.261					

# PARTICULATE FIELD DATA

PLANT: LP-Corrigan  
 DATE: 6-1-95  
 REPETITION: 3

LOCATION: Inlet  
 OPERATOR: GJO, TA  
 STACK #: Dryer #2  
 SAMPLE BOX #: 10  
 METER BOX #: 11  
 AMBIENT TEMPERATURE: 93°  
 BAROMETRIC PRESSURE: 29.85  
 ASSUMED MOISTURE: 20%  
 PROBE LENGTH: 6'  
 NOZZLE IDAMETER: 1/4  
 STACK DIAMETER: 54x54  
 METER H: 1.55 9635  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.012793

IMPINGERS

	<u>Initial</u>	<u>Final</u>
#1: 100 mL		218
#2: 100 mL > 160		130
#3: —		
#4: 200, 56		214.2
#5:		162.2

COMMENTS

O<sub>2</sub> 14%    CO<sub>2</sub> 3.5%

FILTER TARE: 04802

PRE-TEST LEAK CHECK

Meter: .005 cu. ft. 15 in. HG  
 Pitots: ✓ in. H2O

POST-TEST LEAK CHECK

Meter: .005 cu. ft. 10 in. HG  
 Pitots: ✓ in. H2O

P	Θ	STATIC PRES.	Ts OF	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
A1	4.25	-9.6	196	.18		.41	601.55	88	88	250	59	160
2			197	.15		.35	602.5	89	88	251	59	1
3	30		197	.16		.37	603.4	89	88	250	59	1
4			197	.18		.41	604.3	89	88	249	59	1
5	35		196	.26		.59	605.3	90	88	255	59	1
B1	37.5/39		197	.19		.44	606.4	91	88	254	60	1
2			196	.20		.46	608.4	91	88	250	60	1
3	44		196	.26		.46	610.5	91	88	251	60	1
4			195	.32		.60	611.6	92	88	251	60	1
5	49		195	.40		.92	612.9	92	89	250	60	1
C	51.5/53		195	.20		.46	614.4	93	89	260	61	1
2			196	.22		.51	615.4	93	89	256	61	1
3	58		195	.26		.59	616.5	92	89	250	61	1
4			195	.36		.83	617.6	92	89	251	61	1
5	503		194	.47		1.1	619.0	92	89	250	61	1
D1	05.5/06		194	.32		.73	620.6	92	90	251	62	1
2			194	.30		.69	621.8	92	90	252	62	1
3	11		195	.37		.85	623.1	92	90	251	62	1
4			194	.52		1.2	624.5	92	90	253	62	1
5	16		193	.65		1.5	626.1	92	90	251	62	1
E1	18.5/19		194	.41		.94	627.9	92	90	255	62	1
2			193	.44		1.0	629.4	92	90	260	63	1
3	24		193	.56		1.3	630.9	92	90	261	63	1
4			193	.66		1.6	632.6	92	90	265	63	1
5	29		192	.67		1.6	634.5	91	89	261	63	1
AV	5:32.34						636.358					

# PARTICULATE FIELD DATA

PLANT: LP Corrigan  
 DATE: 6-2-95  
 REPETITION: 1

10

0 - 1.3391  
 1 - 2.7714  
 2 - 2.5

LOCATION: Corrigan TX  
 OPERATOR: JD <sup>CO-TA</sup>  
 STACK #: #1 inlet  
 SAMPLE BOX #: 10  
 METER BOX #: 11  
 AMBIENT TEMPERATURE: 80  
 BAROMETRIC PRESSURE: 29.9  
 ASSUMED MOISTURE: 20%  
 PROBE LENGTH: 6'  
 NOZZLE ID DIAMETER: 5/16 .322, .323, .321 (.322)  
 STACK DIAMETER: 54 x 54 (20.25 FT)  
 METER H: 1.559635  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.012793

IMPINGERS

	Initial	Final
#1:	200 ml	318
#2:	200 ml	300
#3:		48
#4:	200g SG	213.1
#5:		479.1

COMMENTS

=  $\frac{CO_2}{4.5}$   $\frac{O_2}{16}$

FILTER TARE:

PRE-TEST LEAK CHECK

Meter: .005 cu. ft. 15 in. HG  
 Pitots: ✓ in. H2O

POST-TEST LEAK CHECK

Meter: .015 cu. ft. 15 in. HG  
 Pitots: ✓ in. H2O

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP OUTLET TEMP.	VAC (IN)
A1	8:31	-9.8	195	.18		.89	638.3031	75	74	261	59	1
2			195	.15		.75	639.2	76	74	260	59	1
3	36		196	.23		1.1	640.5	76	74	261	59	1
4			196	.25		1.2	642.1	78	75	260	59	1
5	41		195	.26		1.3	643.8	79	75	263	59	1
B1	43.5/44		194	.21		1.0	645.5	79	76	262	59	1
2			195	.18		.89	647.0	80	76	260	60	2
3	49		195	.20		.99	648.5	81	77	259	60	3
4			196	.28		1.4	649.9	81	77	265	60	3
5	54		195	.36		1.8	651.7	81	77	261	60	4
B1	56.5/57		196	.22		1.1	653.7	81	78	260	60	5
2			196	.23		1.1	655.3	81	78	263	60	5
3	902		196	.25		1.2	656.9	81	78	260	61	5
4			195	.37		1.8	658.6	81	78	261	61	5
5	07		195	.47		2.2	660.6	81	78	260	61	5
D1	09.5/10		194	.23		1.1	662.8	82	79	261	61	6
2			195	.25		1.2	664.4	82	79	263	62	6
3	15		196	.31		1.5	666.1	82	79	261	62	7
4			195	.40		1.9	667.9	82	79	260	62	7
5	20		194	.60		2.9	670.1	82	79	262	62	8
E1	22.5/23		195	.35		1.7	672.7	82	80	260	62	10
2			195	.33		1.6	674.7	82	80	260	62	13
3	28		196	.43		2.1	676.6	83	80	262	62	15
4			195	.61		3.0	678.8	83	80	261	62	15
5	33		196	.65		3.2	681.4	83	80	263	63	15
AV	933.5		195.2			.5533	1.5568	684.116		79.08		

# PARTICULATE FIELD DATA

PLANT: LP Corrigan  
 DATE: 6-2-95  
 REPETITION:

LOCATION: Inlet  
 OPERATOR: JDTA  
 STACK #: Dryer #1  
 SAMPLE BOX #: 9  
 METER BOX #: 11  
 AMBIENT TEMPERATURE: 85°  
 BAROMETRIC PRESSURE: 29.9  
 ASSUMED MOISTURE: 20%  
 PROBE LENGTH: 6'  
 NOZZLE ID DIAMETER: 5/16 (.32)  
 STACK DIAMETER: 54" x 54"  
 METER H: 1.559635  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.012793

IMPINGERS

	<u>Initial</u>	<u>Final</u>
#1: 200 mL	> DNPH	324
#2: 200 mL		289
#3:		35
#4: 2009 SG		222.3
#5:		470.3

COMMENTS

O<sub>2</sub> 16.0%  
 CO<sub>2</sub> 4.0%

FILTER TARE: N/A

PRE-TEST LEAK CHECK

Meter: 0.2 cu. ft. 12 in. HG  
 Pitots: in. H2O

POST-TEST LEAK CHECK

Meter: 0.11 cu. ft. 15 in. HG  
 Pitots: 1 in. H2O

P	θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.³	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
#1	10.13		197	.12		1.00	1089.575	82	82	250	57	1.0
2			196	.13		1.05	85.734	85	83	256	57	1.0
3			197	.15		1.25	86.741	85	83	252	58	1.0
4			198	.18		1.30	88.238	86	83	256	58	1.0
5			197	.29		1.41	89.658	87	84	266	58	1.0
B#			198	.16		1.8	91.961	88	84	259	58	1.0
2			197	.17		1.84	92.80	88	84	256	59	1.0
3			197	.24		1.2	99.18	87	84	251	59	1.0
4			196	.32		1.6	95.8	87	85	256	60	1.0
5			197	.37		1.8	97.719	88	85	257	60	1.0
C 1		-9.3	196	.22		1.1	699.75	85	85	249	60	1.0
2			195	.20		1.0	701.32	88	85	251	60	1.0
30 3			197	.26		1.3	702.817	88	85	256	60	1.0
4			198	.40		2.0	704.52	89	85	251	60	1.0
35 5			195	.14		2.2	616.41	90	86	251	61	1.0
D 1			196	.32		1.6	8.862	90	86	256	61	1.0
40 2			196	.24		1.4	10.756	89	86	265	61	2.0
3			195	.36		1.8	12.55	89	86	256	61	2.0
45 4			196	.54		2.17	14.567	89	86	256	61	2.0
5			196	.50		2.5	17.027	89	87	251	61	2.0
50 E 1			197	.34		1.7	19.315	89	87	256	61	2.0
2			198	.33		1.6	21.347	89	87	253	62	2.0
35 3			198	.45		2.1	23.270	90	87	254	62	2.0
4			196	.59		3.0	25.465	90	87	253	62	2.0
6 5			195	1.06		3.3	28.036	91	87	254	62	2.0
62.5 AV	11:20						730.756					

# PARTICULATE FIELD DATA

PLANT: LP - Corrigan  
 DATE: 6-2-95  
 REPETITION: 3

LOCATION: Corrigan, TX  
 OPERATOR: JD COSTA  
 STACK #: #1 Dryer inlet  
 SAMPLE BOX #: 10  
 METER BOX #: 11  
 AMBIENT TEMPERATURE: 88  
 BAROMETRIC PRESSURE: 29.9  
 ASSUMED MOISTURE: 20%  
 PROBE LENGTH: 6'  
 NOZZLE IDAMETER: 5/16, .325, .322, .321  
 STACK DIAMETER: 54 x 54  
 METER H: 1.559635  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.012793

IMPINGERS

	Initial	Final
#1:	200 ml	286
#2:	200 ml	272
#3:	—	13
#4:	200 g	211.7
#5:		382.7

COMMENTS

CO<sub>2</sub>    O<sub>2</sub>  
 —————  
 16        4

FILTER TARE:

PRE-TEST LEAK CHECK

Meter: .010 cu. ft. 15 in. HG  
 Pitots: ✓✓ in. H2O

POST-TEST LEAK CHECK


Meter: .005 cu. ft. 10 in. HG  
 Pitots: ✓✓ in. H2O

P	⊖	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP. OUTLET TEMP.	VAC (IN)
A1	1150	-9.6	197	.19		.94	731.094	88	88	260	60	1
2			196	.17		.84	737.5	88	88	255	60	1
3	55		196	.18		.89	733.9	88	88	261	60	1
4			196	.23		1.1	735.3	89	88	260	60	1
5	1200		195	.25		1.2	736.9	89	88	256	60	1
B1	2.5/031		195	.16		.79	738.6	89	88	253	61	1
2	/		196	.17		.85	739.9	89	88	251	61	1
3	08		197	.25		1.2	741.3	89	88	261	61	1
4			196	.31		1.5	743.0	90	88	260	61	1
5	13		195	.35		1.7	744.9	90	88	255	61	1
C1	15.5/16		194	.24		1.2	746.8	91	89	260	61	1
2	/		195	.30		1.5	748.5	91	89	259	62	2
3	21		196	.40		1.9	750.3	91	89	260	62	2
4			194	.35		1.7	752.5	91	89	260	62	3
5	26		195	.34		1.7	754.4	91	89	255	62	3
D1	28.5/29		194	.30		1.5	756.4	91	89	254	62	3
2	/		195	.35		1.7	758.2	91	89	251	62	3
3	34		196	.40		1.9	760.2	91	89	250	62	3
4			197	.40		1.9	762.3	91	89	251	62	3
5	39		195	.45		2.2	764.4	90	89	250	63	3
E1	41.5/42		194	.32		1.6	766.7	90	89	251	63	3
2	/		196	.33		1.6	768.6	90	89	251	63	3
3	47		196	.51		2.5	770.5	90	89	250	63	3
4			196	.60		2.9	772.9	90	89	250	63	3
5	52		194	.60		2.9	775.5	90	89	251	63	3
AV	1254.5						778.083					

PLANT: L.R. Corral  
 DATE: 6-2-95  
 REPETITION: 1

BWS 18.396  
 ISU 102.55

LOCATION: Inlet #2  
 OPERATOR: MT, DB  
 STACK #: Inlet #2  
 SAMPLE BOX #: HCHO  
 METER BOX #: 12  
 AMBIENT TEMPERATURE: 85°  
 BAROMETRIC PRESSURE: 27.7  
 ASSUMED MOISTURE: 20?  
 PROBE LENGTH: 6  
 NOZZLE ID DIAMETER: .311, .312, .313 (312)  
 STACK DIAMETER: 535 x 53.5  
 METER H: 1.590721  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.004179



DRAINERS		Initial	Final
#1:	100 gals DnPH		234
#2:	100		176
#3:	Knock out		31
#4:	200g. Silica Gel		213.1
#5:			254.1

COMMENTS  
 CO2 4%  
 O2 17.5%

FILTER TARE: —  
 PRE-TEST LEAK CHECK  
 Meter: 0.000 cu. ft. 7 in. HG  
 Pitots: ✓ in. H2O

POST-TEST LEAK CHECK  
 Meter: 0.000 cu. ft. 7 in. HG  
 Pitots: in. H2O

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP. OUTLET TEMP.	VAC (IN)
A 1	8:30		230	.54		3.1	457.116	69	69	250	55	5
2	8:33		235	.61		3.6	60.2	75	70	250	55	5
3	8:36		226	.60		3.5	63.3	78	70	255	55	5
4	8:39		150	.62		3.6	66.4	81	72	250	55	5
B 1	42/44		230	.32		1.9	69.6	78	73	255	55	5
2	8:47		236	.42		2.4	71.9	82	73	257	55	5
3	8:50		230	.44		2.6	74.5	84	74	256	56	5
4	8:53	-13.5	127	.83		4.8	77.2	85	74	260	56	5
C 1	56/58		232	.23		1.3	80.9	80	76	257	56	5
2	9:01		235	.29		1.7	82.8	83	76	258	56	3
3	9:04		229	.45		2.6	85.0	83	76	260	56	3
4	9:07		144	.60		3.5	87.7	86	76	258	56	5
D 1	9:10/9:12		215	.23		1.3	90.9	80	77	250	56	3
2	9:15		232	.28		1.6	92.8	84	77	255	56	3
3	9:18		222	.40		2.3	94.9	86	77	250	56	3
4	9:21		220	.60		3.5	97.6	86	77	250	56	3
E 1	9:24/25		196	.23		1.3	100.7	83	77	257	56	3
2	9:28		228	.26		1.5	102.6	87	78	257	56	3
3	9:31		222	.38		2.2	104.7	87	78	257	56	3
4	9:34		137	.88		5.1	107.2	89	78	260	56	3
	9:37						110.33					
AV			208.8			664	267	53.97	87.2			

PARTICULATE FIELD DATA

PLANT: LP Corrosion  
 DATE: 6-2-95  
 REPETITION: 2

BWS 17.162  
 ISO 99.125%

LOCATION: Inside  
 OPERATOR: MTi DB  
 STACK #: Inlet #2  
 SAMPLE BOX #: H614  
 METER BOX #: 12  
 AMBIENT TEMPERATURE: 75  
 BAROMETRIC PRESSURE: 29.75  
 ASSUMED MOISTURE:  
 PROBE LENGTH: 4'  
 NOZZLE ID METER: 5/16  
 STACK DIAMETER: 53.5 x 53.5  
 METER # : 1590121  
 C FACTOR: .94  
 METER CO-EFFICIENT: 1004179

IMPINGERS

	<u>Initial</u>	<u>Final</u>
#1: 100mls		247
#2: 100mls > DNPH		145
#3: Knockout		16
#4: 200g. Silica Gel		212.1
#5:		221.1

COMMENTS

CO<sub>2</sub> 45%  
 O<sub>2</sub> 16%

FILTER TARE: —

PRE-TEST LEAK CHECK

Meter: 0.000 cu. ft. 15" in. HG  
 Pitots: ✓ in. H2O

POST-TEST LEAK CHECK

Meter: 0.000 cu. ft. 4" in. HG  
 Pitots: ✓ in. H2O

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP OUTLET TEMP.	VAC (IN)
A 1	10:13		225	.64		3.7	515.014	82	79	250	60	2.5
2	16		230	.66		3.8	19.0	87	80	260	60	2.5
3	19		219	.61		3.5	22.3	85	80	255	60	2.5
4	22		160	.55		3.2	25.5	90	80	260	60	2.5
B 1	10:25/10:27		214	.34		1.9	28.5	85	80	250	60	2.5
2	30		228	.45		2.6	30.9	89	80	250	60	3
3	33		230	.49		2.8	33.6	89	80	249	60	3
4	36		165	.60		3.5	36.4	89	81	250	60	3
C 1	10:37/10:39		215	.22		1.2	539.614	89	81	250	60	3
2	42		7.10	.26		1.5	41.5	89	81	256	61	2.5
3	45 - 11.5		189	.35		2.0	43.6	89	81	257	61	2.5
4	48		167	.52		3.0	45.9	90	81	254	61	2.5
D 1	10:51/10:53		224	.22		1.2	48.9	90	82	253	61	2.5
2	56		240	.27		1.6	50.8	90	82	250	61	2.5
3	59		233	.40		2.3	52.9	91	81	250	61	3.0
4	11:02		169	.52		3.0	55.5	91	82	255	61	3.0
E 1	11:05/11:07		220	.24		1.4	58.4	93	82	250	61	2.5
2	11:10		224	.30		1.7	60.4	94	83	250	61	2.5
3	11:13		230	.42		2.4	62.6	94	83	250	61	2.5
4	11:16		170	.50		2.9	65.2	96	84	250	61	3.0
	11:19						668.135					
AV			2081			2.46	52.72		85.37			

# PARTICULATE FIELD DATA

PLANT: CD  
 DATE: 6-2-95  
 REPETITION: 3

LOCATION: Corral Gul  
 OPERATOR: MT DB RT  
 STACK #: Inlet # 2  
 SAMPLE BOX #: He No  
 METER BOX #: 12  
 AMBIENT TEMPERATURE: 82°  
 BAROMETRIC PRESSURE: 29.75  
 ASSUMED MOISTURE:  
 PROBE LENGTH: 6'  
 NOZZLE ID METER: 5/16  
 STACK DIAMETER: 53.5733.5  
 METER H: 1.590721  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.004179

IMPINGERS

<u>Initial</u>	<u>Final</u>
#1: 100 wls	246
#2: 100 wls > DNP H	134
#3: Knock out	8
#4: 200g. 56	215.5
#5:	203.5

COMMENTS

O<sub>2</sub> 17%  
 CO<sub>2</sub> 4.5%

FILTER TARE: -

PRE-TEST LEAK CHECK

Meter: 0.000 cu. ft. 15 in. H<sub>2</sub>O  
 Pitots: ✓

POST-TEST LEAK CHECK


Meter: 0.000 cu. ft. 8 in. H<sub>2</sub>O  
 Pitots: ✓

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
A1	11:47		212	.64		3.7	568.911	82	82	250	60	6
2	11:50		230	.66		3.8	72.1	85	82	250	60	6
3	53		227	.60		3.5	75.4	87	82	256	60	6
4	56		132	.80		4.6	78.6	87	82	250	60	6
B1	11:59/1200		232	.30		1.7	82.2	87	83	250	60	6
2	03		240	.45		2.6	84.4	88	83	250	60	6
3	06		226	.40		2.8	87.1	90	83	250	60	6
4	09		145	.81		4.7	89.9	92	83	250	60	6
C1	12:12/1212		209	.27		1.5	93.5	94	84	250	60	6
2	16		224	.32		1.8	95.6	89	84	260	60	6
3	19		222	.39		2.2	96.6	91	84	261	60	6
4	22		136	.60		3.5	99.1	92	84	260	60	6
D1	12:25/127		226	.21		1.2	602.290	89	85	250	60	6
2	12:30		235	.27		1.6	04.1	90	85	251	60	6
3	33 11.0		280	.42		2.4	06.2	90	86	250	60	6
4	36		162	.58		3.4	08.9	89	86	250	60	6
E1	12:39/1240		237	.25		1.4	11.9	89	86	250	60	6
2	43		240	.28		1.6	14.0	89	85	249	60	6
3	46		235	.32		1.8	16.1	90	85	250	60	6
4	49		171	.68		3.9	18.4	90	85	251	60	
	12:52						619.447					
AV							50.536					




# PARTICULATE FIELD DATA


PLANT: Comman LP  
 DATE: 6/1/85  
 REPETITION: 1



As 19.87



LOCATION: #2 Inlet Dryer  
 OPERATOR: MT DB  
 STACK #: 2  
 SAMPLE BOX #: pm  
 METER BOX #: 12  
 AMBIENT TEMPERATURE: 70  
 BAROMETRIC PRESSURE: 29.75  
 ASSUMED MOISTURE: 20%  
 PROBE LENGTH: 5' .256 .255  
 NOZZLE IDAMETER: 1/4" (.256) .252  
 STACK DIAMETER: 57.5 x 53.5  
 METER H: 1.5907  
 C FACTOR: .84  
 METER CO-EFFICIENT: 1.0042



	Initial	Final
#1: 100 ml H <sub>2</sub> O		247
#2: 100 ml H <sub>2</sub> O		176
#3:		8
#4: 200g SG		213.1
#5:		184.1

COMMENTS  
 CO<sub>2</sub> 4.1%  
 O<sub>2</sub> 16.4%

FILTER TARE: 4747  
 PRE-TEST LEAK CHECK  
 Meter: 0.008 cu. ft.  
 Pitots: ✓

STO 0 = .9265  
 STO 1 = 3.2  
 STO 2 = 3.0

POST-TEST LEAK CHECK  
 Meter: 0.010 cu. ft.  
 Pitots: ✓

pts 180  
 3 min/ft 199  
 208  
 219  
 185  
 208  
 226  
 210  
 180  
 200  
 219  
 202  
 189  
 224  
 220  
 226  
 181  
 213  
 227  
 205

P	θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
A1	10:25		230	.47		2.0	346.724	70	70	251	67	2
2	10:28		229	.64		1.9	349.107	74	70	253	67	2
3	10:31		224	.61		1.8	351.393	78	71	252	67	2
4	10:34		202	.60		1.7	353.679	80	71	254	68	2
B1	10:37	9.1	210	.31		1.0	355.801	78	72	250	68	2
2	10:41		230	.41		1.3	357.514	80	73	253	68	2
3	10:44		226	.49		1.5	359.428	82	73	253	68	2
4	10:47		173	.59		2.0	361.504	84	74	250	68	2
C1	10:50		226	.22		.7	363.888	80	75	251	68	2
2	10:54		232	.32		.8	365.275	83	75	257	68	2
3	10:57		228	.43		1.3	366.789	85	76	253	68	2
4	11:00		158	.58		1.7	368.728	87	76	255	69	2
D1	11:03	11.04	219	.21		.7	374.911	81	77	255	69	2
2	11:07		232	.27		.9	372.265	84	77	253	69	2
3	11:10		228	.41		1.4	373.838	87	78	254	69	2
4	11:13		183	.55		1.5	375.801	88	78	253	69	2
E1	11:16	11.17	218	.18		.8	377.832	85	79	251	69	2
2	11:20		222	.35		.8	379.284	87	79	252	69	2
*3	11:40		226	.46		1.3	380.797	79	78	255	68	2
4	11:43		173	.61		1.7	382.712	83	78	254	69	2
	11:46						384.896					
AV			213.45	.4721	1.6497	1.34	38.172			77.62		

\* Lost Power  
 TS 675 Tm 500 .00034 MS PS 920

# PARTICULATE FIELD DATA

17.88

PLANT: Corrigan LP  
 DATE: 6-1-95  
 REPETITION: 2

LOCATION: Driver inlet  
 OPERATOR: DB.MT  
 STACK #: #2  
 SAMPLE BOX #: 8  
 METER BOX #: 12  
 AMBIENT TEMPERATURE: 80  
 BAROMETRIC PRESSURE: 29.75  
 ASSUMED MOISTURE: 10%  
 PROBE LENGTH: 5'  
 NOZZLE ID DIAMETER: 1/4" .2563  
 STACK DIAMETER: 53.5" X 53.5  
 METER # : 159072  
 C FACTOR: 184  
 METER CO-EFFICIENT: 1.0042

IMPINGERS

	<u>Initial</u>	<u>Final</u>
#1:	<u>100mls</u>	<u>242</u>
#2:	<u>100mls</u> } <u>H<sub>2</sub>O</u>	<u>149</u>
#3:	<u>        </u>	<u>10</u>
#4:	<u>200 gr. S.G.</u>	<u>212.1</u>
#5:	<u>        </u>	<u>213.1</u>

COMMENTS

LOZ      OL  
354%      17%

FILTER TARE: 4999  
PRE-TEST LEAK CHECK

Meter: 0.012 cu. ft.15      in. HG  
 Pitots:                              in. H<sub>2</sub>O

POST-TEST LEAK CHECK

Meter:                              cu. ft.      in. HG  
 Pitots:                              in. H<sub>2</sub>O

3  
6  
9  
12  
15  
18  
21  
24  
27  
30  
33  
36  
39  
42  
45  
48  
51  
54  
57  
60

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP OUTLET TEMP.	VAC (IN)
A1	2:45		225	.60		1.6	385.144	81	81	252	67	2
2	2:48		223	.61		1.6	387.282	83	81	251	67	3
3	2:51		225	.56		1.5	389.439	87	82	251	67	3
4	2:54	<u>13P</u>	193	.59		1.6	391.506	89	82	252	67	3
B1	2:57		210	.31		.8	393.627	87	83	254	68	2
2	2:58		230	.41		1.1	395.164	90	83	251	68	2
3	3:01		228	.46		1.2	396.932	92	84	252	68	2
4	3:04		144	.64		1.7	398.805	93	84	252	68	2
C1	3:07		211	.21		.6	401.014	89	85	255	68	2
2	3:11		229	.29		.8	402.779	91	85	253	68	2
3	3:14		225	.42		1.1	403.766	94	86	252	68	2
4	3:17		198	.54		1.5	405.556	95	86	254	68	2
D1	3:20		217	.20		.5	407.585	89	87	253	69	2
2	3:25		231	.27		.7	408.820	93	87	252	69	2
3	3:27		228	.42		1.1	410.255	94	87	253	69	2
4	3:30		161	.52		1.4	412.044	95	87	252	69	2
E1	3:33		200	.22		.6	414.036	90	87	254	69	2
2	3:36		231	.27		.7	415.331	93	87	252	69	2
3	3:40		228	.41		1.1	416.766	96	88	252	69	2
4	3:43		227	.46		1.2	418.534	97	88	253	69	2
	3:46						420.407					
	3:49											
AV			213.2		.6385	1.12	35263		87.725			

# PARTICULATE FIELD DATA

PLANT: COMMISSION LP  
DATE: 6-1-95  
REPETITION: 3

LOCATION: Dryer inlet  
OPERATOR: DB, MT  
STACK #: #2  
SAMPLE BOX #: \_\_\_\_\_  
METER BOX #: 12  
AMBIENT TEMPERATURE: 82°  
BAROMETRIC PRESSURE: 29.75  
ASSUMED MOISTURE: 20%  
PROBE LENGTH: 5'  
NOZZLE ID DIAMETER: 1/4"  
STACK DIAMETER: 32.5 x 53.5  
METER H: 1.5907  
C FACTOR: .84  
METER CO-EFFICIENT: 1.0042

### IMPINGERS

	<u>Initial</u>	<u>Final</u>
229 124 8	#1: <u>100 m/s</u> } H <sub>2</sub> O #2: <u>100 m/s</u> } #3: _____ #4: <u>200 g/s</u> } S.G #5: _____	<u>229</u> <u>224</u> <u>80</u> <u>215.5</u> <u>176.5</u>

### COMMENTS

CO2      O2  
4%              16.5%

FILTER TARE: .4499

### PRE-TEST LEAK CHECK

Meter: 0.008 cu. ft. / 5      in. HG  
Pitots: \_\_\_\_\_      in. H2O

### POST-TEST LEAK CHECK

Meter: 0.009 cu. ft. / 7      in. HG  
Pitots: \_\_\_\_\_      in. H2O


3  
6  
9  
12  
15  
18  
21  
24  
27  
30  
33  
36  
39  
42  
45  
48  
51  
54  
57  
60  
63  
66

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
A1	4:25		222	.161		1.6	420.715	87	87	254	67	2
2	4:28		230	.58		1.6	422.871	89	86	254	67	2
3	4:31		229	.55		1.5	424.974	91	86	253	67	2
4	4:34		222	.49		1.3	427.022	93	86	254	67	2
<del>P1</del>	<del>4:37</del>		<del>228</del>	<del>.41</del>		<del>1.1</del>	<del>428.955</del>	<del>88</del>	<del>86</del>	<del>255</del>	<del>67</del>	<del>2</del>
2	4:41		230	.46		1.7	430.723	91	86	254	67	2
3	4:44		220	.39		1.1	432.896	94	86	254	68	2
4	4:47	-13.2	193	.52		1.4	434.321	95	86	254	68	2
<del>C1</del>	<del>4:50</del>		<del>221</del>	<del>.20</del>		<del>.5</del>	<del>436.312</del>	<del>90</del>	<del>87</del>	<del>255</del>	<del>68</del>	<del>2</del>
2	4:55		233	.31		1.8	437.546	93	87	254	68	2
3	4:58		227	.40		1.1	439.084	95	87	256	68	2
4	5:01		195	.61		1.6	440.831	97	88	255	68	2
<del>D1</del>	<del>5:04</del>		<del>222</del>	<del>.19</del>		<del>.5</del>	<del>442.987</del>	<del>91</del>	<del>88</del>	<del>256</del>	<del>69</del>	<del>2</del>
2	5:08		233	.25		1.6	444.191	93	88	254	69	2
3	5:11		228	.41		1.1	445.571	95	88	255	69	2
4	5:14		152	.51		1.4	447.339	97	88	253	69	2
<del>E1</del>	<del>5:17</del>		<del>205</del>	<del>.20</del>		<del>.5</del>	<del>449.311</del>	<del>90</del>	<del>88</del>	<del>255</del>	<del>69</del>	<del>2</del>
2	5:23		232	.26		1.7	450.546	93	88	254	69	2
3	5:26		228	.42		1.1	451.954	95	88	255	69	2
4	5:29		185	.52		1.4	453.714	96	88	253	69	2
	5:32						455.735					
AV							35.020					

2.3  
4.4  
8.1  
13.5  
28.4  
33.8  
37.6  
40.6  
Final  
221  
120  
209.9  
150.9  
151

PLANT: L.P  
DATE: 5-1-95  
REPETITION: 1

LOCATION: Inlet #3  
OPERATOR: J.S  
STACK #:   
SAMPLE BOX #:   
METER BOX #: 10  
AMBIENT TEMPERATURE: 80  
BAROMETRIC PRESSURE:   
ASSUMED MOISTURE: 10  
PROBE LENGTH: 6  
NOZZLE IDAMETER: .91, .92, .90, (.191)  
STACK DIAMETER: 42"  
METER H: 1.485547  
C FACTOR: .84  
METER CO-EFFICIENT: .9889339



IMPINGERS

Initial  
#1: 100 } m/s H<sub>2</sub>O  
#2: 100 }  
#3: 0  
#4: 200 grms s.g  
#5:

COMMENTS

CO<sub>2</sub> 0%  
O<sub>2</sub> 18%

FILTER TARE: .4991  
PRE-TEST LEAK CHECK

Meter: 0.00 cu. ft.  
Pitots: 15 <sup>195</sup>/<sub>185</sub>

in. HG  
in. H<sub>2</sub>O

STO 0 = .5778  
STO 1 = 3.187  
STO 2 = 4

POST-TEST LEAK CHECK

Meter: 0.00 cu. ft.  
Pitots: 15

in. HG  
in. H<sub>2</sub>O

4 min per Point

P	Θ	STATIC PRES.	T <sub>S</sub> °F	Reyn		ΔH	V <sub>m</sub> FT.3	T <sub>m</sub> INLET	T <sub>m</sub> OUTLET	OVEN TEMP.	IMP OUTLET TEMP.	VAC (IN)
				ΔP	√ΔP							
1	10:23	-8.7	157	.11	1.1/109	1.17	218.274	86	82	258	68	2
2	10:27		154	1.3	1.4/123	1.38	220.7	87	83	257	70	2
3	10:31		135	1.3	1.3/116	1.38	223.3	90	83	262	70	2
4	10:35		154	1.4	1.5/118	1.48	225.9	92	84	255	70	3
5	10:39		128	1.3	1.4/105	1.38	228.7	95	85	252	70	2
6	10:43		149	1.2	1.4/107	1.27	231.3	95	86	261	70	2
7	10:47		142	1.0	1.1/109	1.06	233.8	96	87	257	70	2
8	10:51		148	.89	.88/106	.94	236.1	96	87	259	70	2
B1	<del>10:55</del> 10:56		146	.85	.92/118	.90	238.360	91	86	260	70	2
2	11:00		147	1.3	1.4/154	1.38	240.5	94	88	259	70	2
3	11:04		146	1.4	1.5/159	1.48	243.1	97	89	260	70	3
4	11:08		148	1.4	1.5/160	1.48	245.8	98	90	261	70	3
5	11:12	lost	143	1.3	1.4/152	1.38	248.6	99	90	256	70	3
6	11:16	power	146	1.2	1.2/150	1.27	251.2	99	91	259	70	2
7	11:20	11:21	129	.99	1.2/154	1.05	253.7	100	91	260	70	2
8	11:38	11:35	122	.80	.85/133	.85	256.0	94	91	250	70	2
							258.128					
AV			143.4	1.078		1.24	39.854		90.69			

# PARTICULATE FIELD DATA

PLANT: U.P  
 DATE: 6-1-95  
 REPETITION: 2

LOCATION: Inlet #3

OPERATOR: J.S

STACK #:

SAMPLE BOX #: 11

METER BOX #: 10

AMBIENT TEMPERATURE: 90°

BAROMETRIC PRESSURE:

ASSUMED MOISTURE:

PROBE LENGTH: 6'

NOZZLE IDIAMETER: .191

STACK DIAMETER: 42"

METER # : 1485547

C FACTOR: .84

METER CO-EFFICIENT: .9889339

FILTER TARE: .4777

PRE-TEST LEAK CHECK

Meter: 0.00 cu. ft. 15

Pitots: ✓

in. HG

in. H2O

IMPINGERS

Initial

Final

#1: 100 ) wts. H2O  
 #2: 100  
 #3: 0  
 #4: 200 grms. S.G.  
 #5: 0

202  
121  
16  
215.9

COMMENTS

154.9

CO<sub>2</sub> 0.0%  
 O<sub>2</sub> 17.5%

POST-TEST LEAK CHECK

Meter: 0.00 cu. ft. 7

Pitots: ✓

in. HG

in. H2O

P	Θ	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT. <sup>3</sup>	Tm INLET	Tm OUTLET	OVEN TEMP.	IMP OUTLET TEMP.	VAC (IN)
B1	2:43		154	1.0		1.09	260.127	92	92	255	70	2
2	2:47		151	1.3		1.12	262.4	95	92	265	70	2
3	2:51	-9.0	152	1.3		1.12	265.1	99	92	263	70	2
4	2:55		151	1.3		1.12	267.8	100	93	258	70	2
5	2:59		149	1.2		1.31	270.5	102	94	263	70	2
6	3:03		152	1.1		1.20	273.0	103	95	255	70	2
7	3:07		142	1.1		1.20	275.5	103	95	263	70	2
8	3:11		136	.84		.92	278.0	107	96	264	70	2
A1	<del>3:15</del> 3:16		144	1.0		1.09	280.155	98	97	263	70	2
2	3:20		149	1.2		1.31	282.5	103	97	258	70.	2
3	3:24		146	1.3		1.42	285.0	105	98	255	70	3
4	3:28		150	1.2		1.31	287.7	106	98	256	70	2
5	3:32		155	1.2		1.31	290.3	106	99	261	70	2
6	3:36		149	1.2		1.31	292.8	105	99	254	70	5
7	3:40		148	1.3		1.42	295.4	105	99	255	70	5
8	3:44		134	.90		.98	298.1	105	99	260	70	5
	3:48						300.373					
AV			147.6		1.071	1.258	40.246		98.97			



# PARTICULATE FIELD DATA

PLANT: L.P.  
 DATE: 6-2-95  
 REPETITION: 1

LOCATION: Inlet #3 Dryer

OPERATOR: JS

STACK #:

SAMPLE BOX #: 11

METER BOX #: 10

AMBIENT TEMPERATURE: 87°

BAROMETRIC PRESSURE: 29.89

ASSUMED MOISTURE: 15%

PROBE LENGTH: 5'

NOZZLE ID DIAMETER: .237, .238, .239. (.2386)

STACK DIAMETER: 42" (C.000310678)

METER H: 1.485547

C FACTOR: .84

METER CO-EFFICIENT: .9889339

FILTER TARE:

PRE-TEST LEAK CHECK

Meter: 0.00 cu. ft. / s

Pitots:

in. HG

in. H2O

St-0 = .88878

St-1 = 2.64229

IMPINGERS

Initial

Final

#1: 100 m/s DNPH 284

#2: 100 m/s DNPH 131

#3: -

#4: 200 g. S.G. 225.6

#5: 240.6

COMMENTS

CO<sub>2</sub> 1.5%  
 O<sub>2</sub> 19.5%

POST-TEST LEAK CHECK

Meter: 0.00 cu. ft. / s

Pitots:

in. HG

in. H2O

P	⊖	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
B1	8:30		186	1.4		2.92	340.785	88	88	255	68	7
2	8:34		195	1.4		2.92	344.7	90	87	260	68	8
3	8:38		196	1.4		2.92	348.6	92	88	266	68	8
4	8:42		194	1.4		2.92	352.6	94	88	263	68	9
5	8:46	-8.6	195	1.3		2.71	356.5	94	89	262	68	9
6	8:50		196	1.3		2.71	360.3	95	89	262	68	9
7	8:54		196	1.35		2.81	364.1	95	90	257	69	9
8	8:59		178	.98		2.0	368.0	96	90	258	69	9
A1	9:03		191	1.4		2.92	371.331	92	90	263	70	8
2	9:08		192	1.4		2.92	375.2	96	90	259	70	8
3	9:12		191	1.4		2.92	379.2	97	91	266	70	8
4	9:16		194	1.4		2.92	383.1	98	91	265	70	8
5	9:20		197	1.4		2.92	387.1	98	91	259	70	8
6	9:24		197	1.3		2.71	391.0	98	91	253	70	8
7	9:28		191	1.3		2.71	394.8	99	92	261	70	8
8	9:32		160	.91		1.89	398.6	99	92	255	70	7
	9:36						401.829					
AV			190.6		1.1447	2.739	61.079			92.44		

# PARTICULATE FIELD DATA

PLANT: L.P  
 DATE: 6-2-95  
 REPETITION: 2

LOCATION: Inlet #3  
 OPERATOR: JS  
 STACK #:  
 SAMPLE BOX #: 1  
 METER BOX #: 10  
 AMBIENT TEMPERATURE: 90°  
 BAROMETRIC PRESSURE: 29.91  
 ASSUMED MOISTURE:  
 PROBE LENGTH: 5'  
 NOZZLE ID METER: (6.2386)  
 STACK DIAMETER: 42"  
 METER H : 1.485547  
 C FACTOR: .84  
 METER CO-EFFICIENT: .9889339

IMPINGERS

<u>Initial</u>	<u>Final</u>
#1: 100 ml DNPH	292
#2: 100 ml DNPH	142
#3: -	7
#4: 200 ml SG	214.5
#5: -	255.5

COMMENTS

CO<sub>2</sub>    O<sub>2</sub>  
 25%    18.0%

FILTER TARE:

PRE-TEST LEAK CHECK

Meter: 0.00 cu. ft. / 5      in. H<sub>2</sub>O  
 Pitots:                              in. H<sub>2</sub>O

POST-TEST LEAK CHECK

Meter: 0.00 cu. ft. / 7      in. H<sub>2</sub>O  
 Pitots:                              in. H<sub>2</sub>O

P	θ	STATIC PRES.	T <sub>s</sub> °F	ΔP	√ΔP	ΔH	V <sub>m</sub> FT.3	T <sub>m</sub> INLET	T <sub>m</sub> OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
A1	10:13		192	1.3		2.71	402.322	91	91	260	70	3
2			191	1.35		2.81	406.1	97	92	258	70	3
3			194	1.3		2.71	409.9	100	92	255	70	3
4			194	1.3		2.71	413.7	102	93	254	70	3
5		8.5	195	1.3		2.71	417.5	102	93	266	70	3
6			195	1.4		2.92	421.4	103	94	260	70	3
7			189	1.2		2.50	425.3	103	94	255	70	3
8			159	.85		1.77	428.9	104	95	265	70	4
B1	<del>10:43</del> 10:46		192	1.4		2.92	432.00	98	95	264	70	4
2			194	1.4		2.92	436.0	102	95	255	70	4
3			194	1.3		2.71	439.9	104	96	260	70	4
4			196	1.3		2.71	443.7	105	96	256	70	4
5			194	1.4		2.92	447.5	105	96	259	70	4
6			192	1.3		2.71	451.5	106	97	253	70	4
7			187	1.2		2.50	455.2	106	97	255	70	4
8			165	.92		1.92	458.9	107	97	251	70	3
	11:16						462.141					
AV							59.819					

3.5  
7.0  
10.5  
14  
17.5  
22  
25.5



# PARTICULATE FIELD DATA

PLANT: L.P  
 DATE: 6-2-95  
 REPETITION: 3

LOCATION: Inlet #3

OPERATOR: J.S

STACK #:

SAMPLE BOX #: 11

METER BOX #: 10

AMBIENT TEMPERATURE: 95°

BAROMETRIC PRESSURE: 29.88

ASSUMED MOISTURE:

PROBE LENGTH: 5'

NOZZLE ID DIAMETER: (.2386)

STACK DIAMETER: 42"

METER H: 1.485547

C FACTOR: 184

METER CO-EFFICIENT: .9889334

FILTER TARE: —

PRE-TEST LEAK CHECK

Meter: 0.00 cu. ft. 15

Pitots: ✓

in. HG

in. H2O

IMPINGERS

Initial

Final

#1: 100  $\mu$ ls DNP14 262  
 #2: 100  $\mu$ ls 139  
 #3: — 20  
 #4: 100  $\mu$ g. Sb 216.6  
 #5: —

COMMENTS

CO<sub>2</sub> O<sub>2</sub>  
 2.5% 18%

237.6

POST-TEST LEAK CHECK

Meter: 0.00 cu. ft. 10

Pitots: ✓

in. HG

in. H2O

3.45  
 7.30  
 11.15  
 15.0  
 19.15  
 22.30  
 26.15

P	⊖	STATIC PRES.	Ts °F	ΔP	√ΔP	ΔH	Vm FT.3	Tm INLET	Tm OUTLET	OVEN TEMP	IMP OUTLET TEMP	VAC (IN)
At	11:45		192	1.4		2.92	462.456	96	96	258	70	7
2			195	1.3		2.71	466.4	100	96	260	70	7
3			193	1.35		2.81	470.2	101	96	260	70	7
4			194	1.4		2.92	474.0	104	97	253	70	7
5			192	1.2		2.50	478.0	105	97	258	70	7
6		-8.6	191	1.2		2.50	481.6	105	98	259	70	7
7			191	1.1		2.29	485.3	106	98	264	70	7
8			169	.92		1.92	488.8	107	99	260	70	5
R1	12:15		191	1.5		3.13	492.010	103	99	258	70	8
2			196	1.4		2.92	496.1	105	99	263	70	8
3			194	1.4		2.92	500.0	106	99	264	70	8
4			192	1.3		2.71	504.0	107	100	260	70	8
5			189	1.2		2.50	507.7	107	100	262	70	7
6			192	1.3		2.71	511.4	107	100	261	70	7
7			182	.96		2.0	515.2	107	100	264	70	6
8			180	.92		1.92	518.5	107	101	260	70	6
	12:49						521.693					
AV							59.237					

# Preliminary Traverse

P	⊖	STATIC PRES	TS OF	ΔP	√ΔP
A1		-9.7	196	.48	
2				.58	
3				.66	
4				.74	
5				.75	
B1				.40	
2				.41	
3				.45	
4				.65	
5				.69	
C1				.28	
2				.30	
3				.33	
4				.45	
5				.61	
D1				.23	
2				.23	
3				.29	
4				.40	
5				.44	
E1				.20	
2				.21	
3				.23	
4				.28	
5				.38	
AV					

ΔP - .4268 (.43)  
 TS - 656  
 MS - 27.84  
 PS - 30.57  
  
 msps - 851.07  
  
 Vel - 41.34

$\frac{O_2}{19.5/0}$      $\frac{CO_2}{2.5/0}$

PLANT: LP Corrigan  
 DATE: 6-1-95  
 REPETITION:

LOCATION:  
 OPERATOR: TA CJ & D  
 STACK #: #1 inlet  
 SAMPLE BOX #:  
 METER BOX #:  
 AMBIENT TEMPERATURE:  
 BAROMETRIC PRESSURE: 1011    29.85  
 ASSUMED MOISTURE: 12  
 PROBE LENGTH:  
 NOZZLE DIAMETER:  
 STACK DIAMETER:  
 METER H :  
 C FACTOR:

APPENDIX E

SUMMARY OF POST METER BOX CALIBRATION

METER BOX NUMBER : 12  
CALIBRATION DATE: 6/03/95  
CALIBRATED BY: Dan Barrera  
BAROMETRIC PRESSURE (inch Hg): 29.65

\*\*\*\*\*  
\*  
\* DELTA H = ORFICE PRESSURE \*  
\* VW = VOLUME OF WET GAS METER \*  
\* TW = AVERAGED TEMPERATURE OF WET METER \*  
\* VD = VOLUME OF DRY GAS METER \*  
\* TD = AVERAGED TEMPERATURE OF DRY GAS METER \*  
\* TIME = DURATION OF EACH POINT RUN \*  
\*  
\*\*\*\*\*

POINT 1  
DELTA H = 1 VW = 10 TW = 81  
VD = 9.623999 TD = 79.75 TIME = 16.26 TEST METER Y = .9701  
METER BOX Y = 1.003184  
METER BOX H = 1.532772

POINT 2  
DELTA H = 1 VW = 10 TW = 81.5  
VD = 9.659001 TD = 80.75 TIME = 16.21 TEST METER Y = .9701  
METER BOX Y = 1.000476  
METER BOX H = 1.523354

POINT 3  
DELTA H = 1 VW = 10 TW = 82  
VD = 9.659001 TD = 82.25 TIME = 16.23 TEST METER Y = .9701  
METER BOX Y = 1.002326  
METER BOX H = 1.525705

AVERAGE Y = 1.001995  
AVERAGE H = 1.527277

Post-Test  
Meter Box Calibration

Dry Gas Meter #: 12  
 Calibrated by: *Don Barrery*  
 Date: 6-3-95  
 Barometric Pressure: 29.65

Orifice ΔH	Test Meter Volume V <sub>w</sub>	Dry Gas Meter Volume V <sub>d</sub>	Temperature				Time θ	Y	ΔH@
			Test Meter T <sub>w</sub>	Dry Gas Meter					
				Inlet T <sub>di</sub>	Outlet T <sub>do</sub>	Ave T <sub>d</sub>			
1.0	10	9.624	81	82/85	75/77	79.75	16.26	.9701	
1.0	10	9.659	81.5	82/86	77/78	80.75	16.21	.9701	
1.0	10	9.659	82	84/88	78/79	82.25	16.23	.9701	

$$Y = \frac{V_w P_{bar} (T_d + 460)}{V_d (P_{bar} + \Delta H) (T_w + 460)}$$

$$\Delta H@ = \frac{0.0317 \Delta H}{P_{bar} (T_d + 460)} \left[ \frac{(T_w + 460) \theta}{V_w} \right]^2$$

P<sub>bar</sub> = Barometric Pressure

AKMSIRUNG ENVIRONMENTAL, INC.

DRY GAS METER #: 12

DATE: 6-3-95

$\Delta H$	VW	TW	VD	TDT	TDO	$\Delta TD$	$\phi$
1.0 (10FT <sup>3</sup> )	335.0	81/81	631.706	82	75		
	325.0	81/81	622.082	85	77		
	10	81	9.624		→	79.75	16.26
1.0 (10FT <sup>3</sup> )	345.0	81/81	641.365	82	77		
	335.0	82/82	631.706	86	78		
	10	81.5	9.659		→	80.75	16.21
1.0 (10FT <sup>3</sup> )	355.0	82/82	651.024	84	78		
	345.0	82/82	641.365	88	79		
	10	82	9.659		→	82.25	16.23

Temperature Meter Calibration Form

Meter # 12

6-3-95

Emtech K  
Thermocouple Checker

Meter Reading

P1 32 F + 460 = 492 R

35 + 460 = 495 R

P2 212 F + 460 = 672 R

213 + 460 = 673 R

P3 752 F + 460 = 1212 R

753 + 460 = 1213 R

Divide smaller number by larger number in degrees R and multiply by 100.

Subtract that number from 100 to get % variation.

Variation limit is +/- 2%.

% Variation

P1

-1.6

P2

-1

P3

-1

SUMMARY OF POST METER BOX CALIBRATION

METER BOX NUMBER : 10  
CALIBRATION DATE: 6/03/95  
CALIBRATED BY: Dan Barrera  
BAROMETRIC PRESSURE (inch Hg): 29.65

\*\*\*\*\*  
\*  
\* DELTA H = ORFICE PRESSURE \*  
\* VW = VOLUME OF WET GAS METER \*  
\* TW = AVERAGED TEEMPERATURE OF WET METER \*  
\* VD = VOLUME OF DRY GAS METER \*  
\* TD = AVERAGED TEMPERATURE OF DRY GAS METER \*  
\* TIME = DURATION OF EACH POINT RUN \*  
\*  
\*\*\*\*\*

POINT 1  
DELTA H = 1 VW = 10 TW = 82  
VD = 9.656999 TD = 86.5 TIME = 15.58 TEST METER Y = .9701  
METER BOX Y = 1.010391  
METER BOX H = 1.395012

POINT 2  
DELTA H = 1 VW = 10 TW = 82.5  
VD = 9.693 TD = 89 TIME = 15.66 TEST METER Y = .9701  
METER BOX Y = 1.010311  
METER BOX H = 1.405547

POINT 3  
DELTA H = 1 VW = 10 TW = 83  
VD = 9.701 TD = 90.5 TIME = 15.59 TEST METER Y = .9701  
METER BOX Y = 1.011304  
METER BOX H = 1.391775

AVERAGE Y = 1.010669  
AVERAGE H = 1.397444



Post-Test  
Meter Box Calibration

Dry Gas Meter #: 10  
 Calibrated by: *Dan Barrer*  
 Date: 6-3-95  
 Barometric Pressure: 29.65

Orifice ΔH	Test Meter Volume V <sub>w</sub>	Dry Gas Meter Volume V <sub>d</sub>	Temperature			Time θ	Y	ΔH@
			Test meter T <sub>w</sub>	Dry Gas Meter				
				Inlet T <sub>di</sub>	Outlet T <sub>do</sub>			
1.0	10	9.657	82	<del>85</del> 95	<del>82</del> 85	86.5	15.58	.9701
1.0	10	9.693	82.5	<del>90</del> 95	<del>85</del> 86	89	15.66	.9701
1.0	10	9.701	83	<del>92</del> 96	<del>87</del> 87	90.5	15.59	.9701

$$Y = \frac{V_w P_{bar} (T_d + 460)}{V_d (P_{bar} + \frac{\Delta H}{13.6}) (T_w + 460)}$$

$$\Delta H@ = \frac{0.0317 \Delta H}{P_{bar} (T_d + 460)} \left[ \frac{(T_w + 460) \theta}{V_w} \right]^2$$

P<sub>bar</sub> = Barometric Pressure

AKMSIKONG ENVIRONMENTAL, INC.

DRY GAS METER #: 10

DATE: 6-3-95

$\Delta H$	VW	TW	VD	TDT	TDO	$\Delta TD$	$\phi$
1.0 (10FT <sup>3</sup> )	365.0	82/82	533.828	85	82		
	355.0	82/82	524.171	94	85		
	10	82	9.657		→	86.5	15.58
1.0 (10FT <sup>3</sup> )	375.0	82/82	543.521	90	85		
	365.0	83/83	533.828	95	86		
	10	82.5	9.693		→	89	15.66
1.0 (10FT <sup>3</sup> )	385.0	83/83	553.222	92	87		
	375.0	83/83	543.521	96	87		
	10	83	9.701		→	90.5	15.59

Temperature Meter Calibration Form

Meter # 10

6-3-95

	Emtech K Thermocouple Checker	Meter Reading
P1	32 F + 460 = 492 R	<u>33</u> + 460 = <u>493</u> R
P2	212 F + 460 = 672 R	<u>214</u> + 460 = <u>674</u> R
P3	752 F + 460 = 1212 R	<u>753</u> + 460 = <u>1213</u> R

Divide smaller number by larger number in degrees R and multiply by 100.  
 Subtract that number from 100 to get % variation.  
 Variation limit is +/- 2%.

	% Variation
P1	<u>0.2</u>
P2	<u>0.3</u>
P3	<u>0.1</u>

L

SUMMARY OF POST METER BOX CALIBRATION

METER BOX NUMBER : 11  
CALIBRATION DATE: 6/03/95  
CALIBRATED BY: Dan Barrera  
BAROMETRIC PRESSURE (inch Hg): 29.65

\*\*\*\*\*  
\*  
\* DELTA H = ORFICE PRESSURE \*  
\* VW = VOLUME OF WET GAS METER \*  
\* TW = AVERAGED TEEMPERATURE OF WET METER \*  
\* VD = VOLUME OF DRY GAS METER \*  
\* TD = AVERAGED TEMPERATURE OF DRY GAS METER \*  
\* TIME = DURATION OF EACH POINT RUN \*  
\*  
\*\*\*\*\*

POINT 1  
DELTA H = 1 VW = 10 TW = 80  
VD = 9.63 TD = 79.25 TIME = 16.43 TEST METER Y = .9701  
METER BOX Y = 1.003485  
METER BOX H = 1.560656

POINT 2  
DELTA H = 1 VW = 10 TW = 80.5  
VD = 9.271 TD = 81.25 TIME = 16.36 TEST METER Y = .9701  
METER BOX Y = 1.045241  
METER BOX H = 1.544524

POINT 3  
DELTA H = 1 VW = 10 TW = 81  
VD = 9.635 TD = 82.5 TIME = 16.36 TEST METER Y = .9701  
METER BOX Y = 1.007144  
METER BOX H = 1.543817

AVERAGE Y = 1.018623  
AVERAGE H = 1.549666

Post-Test  
Meter Box Calibration

Dry Gas Meter #: 11  
 Calibrated by: *Don Barrera*  
 Date: 6-3-95  
 Barometric Pressure: 29.65

Orifice ΔH	Test Meter Volume V <sub>w</sub>	Dry Gas Meter Volume V <sub>d</sub>	Temperature				Time θ	γ	ΔH@
			Test meter T <sub>w</sub>	Dry Gas Meter					
				Inlet T <sub>di</sub>	Outlet T <sub>do</sub>	Ave T <sub>d</sub>			
1.0	10	9.630	80	<del>78</del> 83	<del>77</del> 79	79.25	16.43	.9701	
1.0	10	9.271	80.5	<del>81</del> 85	<del>79</del> 80	81.25	16.36	.9701	
1.0	10	9.635	81	<del>83</del> 86	<del>80</del> 81	82.5	16.36	.9701	

$$\gamma = \frac{V_w P_{bar} (T_d + 460)}{V_d (P_{bar} + \Delta H) (T_w + 460)}$$

$$\Delta H@ = \frac{0.0317 \Delta H 13.6}{P_{bar} (T_d + 460)} \left[ \frac{(T_w + 460) \theta}{V_w} \right]^2$$

P<sub>bar</sub> = Barometric Pressure

ARMSTRONG ENVIRONMENTAL, INC.

DRY GAS METER #: //

DATE: 6-3-95

ΔH	VW	TW	VD	TDT	TDO	ΔTD	φ
1.0 (10FT <sup>3</sup> )	305.0	80/80	793.159	78	77		
	295.0	80/80	793.529	83	79		
	10	80	9.630		→	79.25	16.43
1.0 (10FT <sup>3</sup> )	315.0	80/80	802.800	81	79		
	305.0	81/81	793.529	85	80		
	10	80.5	9.271		→	81.25	16.36
1.0 (10FT <sup>3</sup> )	325.0	81/81	812.435	83	80		
	315.0	81/81	802.800	86	81		
	10	81	9.635		→	82.5	16.36

**Temperature Meter Calibration Form**

Meter # 11      6-3-95

Emtech K  
Thermocouple Checker

Meter Reading

P1	32 F + 460 = 492 R	<u>29</u> + 460 = <u>489 R</u>
P2	212 F + 460 = 672 R	<u>209</u> + 460 = <u>669 R</u>
P3	752 F + 460 = 1212 R	<u>747</u> + 460 = <u>1207 R</u>

Divide smaller number by larger number in degrees R and multiply by 100.  
Subtract that number from 100 to get % variation.  
Variation limit is +/- 2%.

	<b>% Variation</b>
P1	<u>.6</u>
P2	<u>.4</u>
P3	<u>.4</u>

ATMOSPHERIC CALIBRATIONS

Watch Checked against Princo Instruments Hg Barometer

Model #453 Serial #10030

DATE	TIME	TEMPERATURE	WATCH READING	ACTUAL READING	% DIFFERENCE	WATCH OWNER
1-5-94	11:40	71°	30.24	30.24	0.0%	J. Dahlem
1-13-95	4:40	70°	29.65	29.65	0	J. Salinas
2-7-95	4:03	70°	30.00	30.15	0.5%	J. Dahlem
2-10-95	2:30	70	29.53	29.50	.03%	J. Barrera
2/21/95	10:57	71°	30.06	30.05	.01	John
2/21/95	10:59	71	30.15	30.05	.1	John
3-9-95	2:30	70	30.19	30.11	.08	DAN
3-9-95	2:45	70	30.03	30.11	.08	Richard Taylor
3/14/95	4:10	71	29.62	29.64	.02	Richard Taylor
3/27/95	12:15	70	29.91	29.92	.01	Joe Barrera
4/11/95	3:33	71°	29.7	29.7	0.00	H
4/11/95			29.76	29.56	0	H
4/11/95	8:00	71	29.56	29.56	0	H
4/28/95	2:35	71	29.65	29.65	0	H
5/9/95	1:35	77	29.95	29.95	0	H
5/15/95	8:00	75	29.7	29.7	0	H
5/16/95	10:06	76.5	29.55	29.54	.01	J. Barrera
5/19/95	2:11 PM	75	29.74	29.74	0	T. Armstrong
5/30/95	11:05 AM	76	29.75	29.7	-	Richard Taylor
6/3/95	11:35 AM	77	29.65	29.64	0.0003	T. Armstrong
5/5/95	2:50 PM	78	29.4	29.58		
6/10/95	9:30 AM	77	29.65	29.62		



SUMMARY OF PRE METER BOX CALIBRATION

METER BOX NUMBER: 10  
CALIBRATION DATE: 5/2/95  
CALIBRATED BY: Jerry Salinas  
BAROMETRIC PRESSURE: 29.84

\*\*\*\*\*  
\*  
\* DELTA H = ORFICE PRESSURE \*  
\* VW = VOLUME OF WET GAS METER \*  
\* TW = AVERAGED TEMPERATURE OF WET METER \*  
\* VD = VOLUME OF DRY GAS METER \*  
\* TD = AVERAGED TEMPERATURE OF DRY GAS METER \*  
\* TIME = DURATION OF EACH POINT RUN \*  
\*  
\*\*\*\*\*

POINT 1

DELTA H = .5 VW = 5 TW = 72.5  
VD = 4.961 TD = 71.75 TIME = 11.37 TEST METER Y = .9701  
METER BOX Y = .9751477  
METER BOX H = 1.464681

POINT 2

DELTA H = 1 VW = 5 TW = 73  
VD = 4.908 TD = 73.5 TIME = 7.923 TEST METER Y = .9701  
METER BOX Y = .9867799  
METER BOX H = 1.42043

POINT 3

DELTA H = 1.5 VW = 10 TW = 73  
VD = 9.82 TD = 75.75 TIME = 13.215 TEST METER Y = .9701  
METER BOX Y = .9893221  
METER BOX H = 1.475633

POINT 4

DELTA H = 2 VW = 10 TW = 73  
VD = 9.814999 TD = 76.25 TIME = 11.55 TEST METER Y = .9701  
METER BOX Y = .9895352  
METER BOX H = 1.501556

POINT 5

DELTA H = 3 VW = 10 TW = 73  
VD = 9.765001 TD = 77 TIME = 9.316 TEST METER Y = .9701  
METER BOX Y = .9935568  
METER BOX H = 1.463258

POINT 6

DELTA H = 4 VW = 10 TW = 73.5  
VD = 9.689999 TD = 77.75 TIME = 8.402001 TEST METER Y = .9701  
METER BOX Y = .9992614  
METER BOX H = 1.587722

Meter Box Calibration

Dry Gas Meter #: 10  
 Calibrated by: Jerry  
 Date: 5-2-95  
 Barometric Pressure: 29.84

Orifice $\Delta H$	Test Meter Volume $V_w$	Dry Gas Meter Volume $V_d$	Test Meter $T_w$	Temperature			Time $e$	$\gamma$	$\Delta H_{20}$
				Dry Gas Meter					
				Inlet $T_{di}$	Outlet $T_{dc}$	Ave $T_d$			
.5	5.0	4.961	72.5	70 76	70 71	71.75	11.370	.9701	
1.0	5.0	4.908	73	73 79	71 71	73.5	7.923	.9701	
1.5	10.0	9.82	73	77 81	73 73	75.75	13.215	.9701	
2.0	10.0	9.815	73	76 82	73 74	76.25	11.550	.9701	
3.0	10.0	9.765	73	77 83	74 74	77	9.316	.9701	
4.0	10.0	9.69	73.5	78 84	74 75	77.75	8.402	.9701	

$$\gamma = \frac{V_w P_{bar} (T_d + 460)}{V_d (P_{bar} + \frac{\Delta H}{13.6}) (T_w + 460)}$$

$$\Delta H_{20} = \frac{0.0317 \Delta H}{P_{bar} (T_d + 460)} \left[ \frac{(T_w + 460) e}{V_w} \right]^2$$

$P_{bar}$  = Barometric Pressure

# ARMSTRONG ENVIRONMENTAL, INC.

DRY GAS METER #: 10

DATE: 5-2-95

ΔH	VW	TW	VD	TDT	TDO	ΔTD	ϕ
.5 (5FT <sup>3</sup> )	970.000	72/72	679.812	70	70		
	965.000	73/73	674.851	76	71		
	5.000	72.5	4.961		→	71.75	11.370
1.0 (5FT <sup>3</sup> )	975.000	73/73	684.720	73	71		
	970.000	73/73	679.812	79	71		
	5.000	73	4.908		→	73.5	7.923
1.5 (10 FT <sup>3</sup> )	985.000	73/73	694.540	77	72		
	975.000	73/73	684.720	81	73		
	10.000	73	4.82		→	75.75	13.215
2.0 (10FT <sup>3</sup> )	995.000	73/73	704.355	76	73		
	985.000	73/73	694.540	82	74		
	10.000	73	4.815		→	76.25	11.550
3.0 (10FT <sup>3</sup> )	1005.000	73/73	714.120	77	74		
	995.000	73/73	704.355	83	74		
	10.000	73	9.765		→	77	9.316
4.0 (10FT <sup>3</sup> )	1015.000	73/73	723.810	78	74		
	1005.000	74/74	714.120	84	75		
	10.000	73.5	9.69		→	77.75	8.402
			170				

Temperature Meter Calibration Form

# 10

5/2/95

24

Extech K Thermocouple Checker:

Meter Reading

P1 :  $32^{\circ}\text{F} + 460 = 492^{\circ}\text{R}$

32 + 460 = 492 °R

P2 :  $212^{\circ}\text{F} + 460 = 672^{\circ}\text{R}$

212 + 460 = 672 °R

P3 :  $752^{\circ}\text{F} + 460 = 1,212^{\circ}\text{R}$

751 + 460 = 1211 °R

...  
 Divide smaller number by larger number in degrees R and multiply by 100.  
 Subtract that number from 100 to get % variation.  
 Variation limit is + or - 2%

% Variation

P1 :

0%

P2 :

0%

P3 :

- .08%

Average

171

Meter Box Calibration

Dry Gas Meter #: 11  
 Calibrated by: Jerry Salinas  
 Date: 5-3-95  
 Barometric Pressure: 29.56

Orifice ΔH	Test Meter Volume V <sub>w</sub>	Dry Gas Meter Volume V <sub>d</sub>	Temperature			Time e	γ	ΔH
			Test Meter T <sub>w</sub>	Dry Gas Meter				
				Inlet T <sub>di</sub>	Outlet T <sub>do</sub>			
1.5	5	4.829	66	63/66	63/64	66	11.72	.9701
1.0	5	4.807	66.5	66/69	65/66	66.5	8.24	.9701
1.5	10	9.583	67	68/71	66/67	68	13.62	.9701
2.0	10	9.542	67	70/73	67/68	69.5	11.73	.9701
3.0	10	9.514	67	72/74	68/69	70.75	9.67	.9701
4.0	10	9.481	67	72/74	69/69	71	8.40	.9701

$$\gamma = \frac{V_w P_{bar} (T_d + 460)}{V_d (P_{bar} - \frac{\Delta H}{13.6}) (T_w + 460)}$$

$$\Delta H = \frac{0.0317 \Delta H}{P_{bar} (T_d + 460)} \left[ \frac{(T_w + 460) e}{V_w} \right]^2$$

P<sub>bar</sub> = Barometric Pressure

# ARMSTRONG ENVIRONMENTAL, INC.

DRY GAS METER #: 11

DATE: 5-3-95

ΔH	VW	TW	VD	TDT	TDO	ΔTD	θ
.5 (5FT <sup>3</sup> )	20.000	66/66	490.571	63	63		
	15.000	66/66	485.742	66	64		
	5.000	66	4.829		→	66	11.721
1.0 (5FT <sup>3</sup> )	25.000	66/66	495.378	66	65		
	20.000	67/67	490.571	69	66		
	5.000	66.5	4.807		→	66.5	8.237
1.5 (10FT <sup>3</sup> )	35.000	67/67	504.961	68	66		
	25.000	67/67	495.378	67	67		
	10.000	67	9.583		→	68	13.617
2.0 (10FT <sup>3</sup> )	45.000	67/67	514.503	70	67		
	35.000	67/67	504.961	73	68		
	10.000	67	9.542		→	69.5	11.734
3.0 (10FT <sup>3</sup> )	55.000	67/67	524.017	72	68		
	45.000	67/67	514.503	74	69		
	10.000	67	9.514		→	70.75	9.674
4.0 (10FT <sup>3</sup> )	65.000	67/67	533.498	72	69		
	55.000	67/67	524.017	74	69		
	10.000	67	9.481		→	71	8.402
174							

Temperature Meter Calibration Form

# 11 5/3/95

Exttech K Thermocouple Checker:

Meter Reading

P1 :  $32^{\circ}\text{F} + 460 = 492^{\circ}\text{R}$        $\underline{28} + 460 = \underline{488}^{\circ}\text{R}$   
P2 :  $212^{\circ}\text{F} + 460 = 672^{\circ}\text{R}$        $\underline{208} + 460 = \underline{668}^{\circ}\text{R}$   
P3 :  $752^{\circ}\text{F} + 460 = 1,212^{\circ}\text{R}$        $\underline{746} + 460 = \underline{1206}^{\circ}\text{R}$

...  
Divide smaller number by larger number in degrees R and multiply by 100.  
Subtract that number from 100 to get % variation.  
Variation limit is + or - 2%

% Variation

P1 :                       $\underline{.8}$   
P2 :                       $\underline{.6}$   
P3 :                       $\underline{.5}$

Average

SUMMARY OF PRE METER BOX CALIBRATION

METER BOX NUMBER: 12  
CALIBRATION DATE: 5/26/95  
CALIBRATED BY: Dan Barrera  
BAROMETRIC PRESSURE: 29.75

\*\*\*\*\*  
\*  
\* DELTA H = ORFICE PRESSURE \*  
\* VW = VOLUME OF WET GAS METER \*  
\* TW = AVERAGED TEMPERATURE OF WET METER \*  
\* VD = VOLUME OF DRY GAS METER \*  
\* TD = AVERAGED TEMPERATURE OF DRY GAS METER \*  
\* TIME = DURATION OF EACH POINT RUN \*  
\*  
\*\*\*\*\*

POINT 1  
DELTA H = .5 VW = 5 TW = 80  
VD = 4.84 TD = 78 TIME = 11.59 TEST METER Y = .9701  
METER BOX Y = .9972253  
METER BOX H = 1.551581

POINT 2  
DELTA H = 1 VW = 5 TW = 80.5  
VD = 4.851 TD = 79.75 TIME = 8.24 TEST METER Y = .9701  
METER BOX Y = .9960476  
METER BOX H = 1.566338

POINT 3  
DELTA H = 1.5 VW = 10 TW = 81  
VD = 9.655 TD = 81.5 TIME = 13.61 TEST METER Y = .9701  
METER BOX Y = 1.001978  
METER BOX H = 1.600206

POINT 4  
DELTA H = 2 VW = 10 TW = 81.5  
VD = 9.662 TD = 83.5 TIME = 11.99 TEST METER Y = .9701  
METER BOX Y = 1.002788  
METER BOX H = 1.652867

POINT 5  
DELTA H = 3 VW = 10 TW = 82  
VD = 9.583 TD = 84.75 TIME = 9.59 TEST METER Y = .9701  
METER BOX Y = 1.009961  
METER BOX H = 1.585375

POINT 6  
DELTA H = 4 VW = 10 TW = 82.5  
VD = 9.497 TD = 85.5 TIME = 8.310001 TEST METER Y = .9701  
METER BOX Y = 1.017074  
METER BOX H = 1.587959

AVERAGE Y = 1.004179  
AVERAGE H = 1.590721



Meter Box Calibration

Dry Gas Meter #: 12  
 Calibrated by: *Don Correia*  
 Date: *5-26-95*  
 Barometric Pressure: 29.75

Orifice $\Delta H$	Test Meter Volume $V_w$	Dry Gas Meter Volume $V_d$	Temperature				Time $\theta$	$\gamma$	$\Delta H_{\theta}$
			Test Meter $T_w$	Dry Gas Meter					
				Inlet $T_{di}$	Outlet $T_{do}$	Ave $T_d$			
1.5	5	4.840	80	<del>76</del> 83	<del>76</del> 77	78	11.59	.9701	
1.0	5	4.851	80.5	<del>80</del> 84	<del>77</del> 78	79.75	8.24	.9701	
1.5	10	9.655	81	<del>80</del> 89	<del>78</del> 79	81.5	13.61	.9701	
2.0	10	9.662	81.5	<del>85</del> 90	<del>79</del> 80	83.5	11.99	.9701	
3.0	10	9.583	82	<del>87</del> 91	<del>80</del> 81	84.75	9.59	.9701	
4.0	10	9.497	82.5	<del>87</del> 92	<del>81</del> 82	85.5	8.31	.9701	

$$\gamma = \frac{V_w P_{\text{bar}} (T_d + 460)}{V_d (P_{\text{bar}} + \frac{\Delta H}{13.6}) (T_w + 460)}$$

$$\Delta H_{\theta} = \frac{0.0317 \Delta H}{P_{\text{bar}} (T_d + 460)} \left[ \frac{(T_w + 460) \theta}{V_w} \right]^2$$

$P_{\text{bar}}$  = Barometric Pressure

ARMSTRONG ENVIRONMENTAL, INC.

DRY GAS METER #: 12

DATE: 5-26-95

$\Delta H$	VW	TW	VD	TDT	TDO	$\Delta TD$	$\theta$
.5 (5FT <sup>3</sup> )	217.0	80/80	303.274	76	76		
	212.0	80/80	298.434	83	77		
	5	80	4.840		→	78	11.59
1.0 (5FT <sup>3</sup> )	222.0	80/80	308.125	80	77		
	217.6	81/81	303.274	84	78		8.24
	5	80.5	4.851		→	79.75	
1.5 (10 FT <sup>3</sup> )	232.0	81/81	317.780	80	78		
	222.0	81/81	308.125	89	79		
	10	81	9.655		→	81.5	13.61
2.0 (10FT <sup>3</sup> )	242.0	81/81	327.442	85	79		
	232.0	82/82	317.780	90	80		
	10	81.5	9.662		→	83.5	11.99
3.0 (10FT <sup>3</sup> )	252.0	82/82	337.025	87	80		
	242.0	82/82	327.442	91	81		
	10	82	9.583		→	84.75	9.59
4.0 (10FT <sup>3</sup> )	262.0	82/82	346.522	87	81		
	252.0	83/83	337.025	92	82		
	10	82.5	9.497		→	85.5	8.31
			178				

Temperature Meter Calibration Form

Meter # 12 5-2695

	Emtech K Thermocouple Checker	Meter Reading
P1	32 F + 460 = 492 R	<u>28</u> + 460 = <u>488 R</u>
P2	212 F + 460 = 672 R	<u>212</u> + 460 = <u>672 R</u>
P3	752 F + 460 = 1212 R	<u>758</u> + 460 = <u>1218 R</u>

Divide smaller number by larger number in degrees R and multiply by 100.  
 Subtract that number from 100 to get % variation.  
 Variation limit is +/- 2%.

	% Variation
P1	<u>18</u>
P2	<u>0</u>
P3	<u>0.5</u>

APPENDIX F

Air Products and Chemicals, Inc.  
SPECIALTY GAS DEPARTMENT  
12722 S. WENTWORTH AVENUE  
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of 1

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

APCI  
3415 BANNING ST  
DALLAS, TX. TX 75233

Notes:

Order No: 360-047885  
Batch No: 861-23327

Cylinder No: SG9127028B1  
Cylinder Pressure\*: 2000 psig  
Certification Date: 01/28/95  
Expiration Date: 01/28/98

PO: Reli

\*\*\* Certified Concentration \*\*\* \*\*\*\*\* Reference Standards \*\*\*\*\* Analytical Instrumentation \*\*\*\*\*

Component	Certified Concentration	Cylinder #	Standard Number	Concentration	Make/Model	Instrument	Serial Number	Last Calibration	Measurement Principle
PROPANE	495 ±1.3 PPM	SG9128635BAL	GMIS	505.1000 PPM	GOW-Mac	750	59405U	01/18/94 GC-FID	

Balance Gas: Nitrogen

\* Standard should not be used below 150 psig

180

Analyst:

*Richard Vandyke*  
Richard Vandyke

Approved By:

*Robert McNear*  
Robert McNear

To: Airco Dist. & Cty. Gases

Expiration Date: 01/12/99  
 Customer P.O.: R11747  
 Balance Gas: Nitrogen  
 CAS 7127-31-9

Certification of Analysis - EPA Protocol Gas  
 Performed According to Section 3.0.4

Certified per Traceability Procedure 4 G1  
 Certified Accuracy 1% NIST Protocol 4.1

Sept Number: 72709  
 Cylinder Number: CC29750  
 File Number: 0106795  
 Cylinder Pressure: 2000 PSIG  
 Certification Date: 01/12/95  
 Location: Royal Oak, M.I.

Component	Certified Concentration	SRM No.	SRM Conc.	Cylinder Number	Analytical Information	Serial Number	Analytical Procedure	Model	Calibration Date
Propane	50.5 ppm	2683a	99.1 ppm	9X20443	Flame Ionization Detector	4189	4093	74-98-6	12/23/94

First Analysis Analyt: L. Cooney Date: 01/12/95

Zero Gas	Reference Gas	Sample Gas	Concentration
00.0	99.1	50.4	50.4 ppm
00.0	99.0	50.4	50.5 ppm
00.0	99.0	50.4	50.5 ppm
Average-			50.5 ppm

Second Analysis Analyt: L. Cooney Date: 01/12/95

Zero Gas	Reference Gas	Sample Gas	Concentration
00.0	99.1	50.4	50.4 ppm
00.0	99.0	50.3	50.5 ppm
00.0	99.0	50.3	50.5 ppm
Average-			50.5 ppm

This Calibration Standard has been certified versus EPA Traceability Procedure 4.1, and Analysis performed per section 3.0.4  
 Certified Concentration: Balance - Nitrogen, Propane-50.5 ppm

APPROVED BY M. Kelly Laboratory Manager

**EPRA PRO**



# Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063

(313) 589-2950 FAX: (313) 589-2134

## CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer:  
CRIMINAL ENVIRONMENTAL  
LABORATORY  
1715 S. VERMONT AVE  
DALLAS, TX 75210

Assay Laboratory  
Scott Specialty Gases, Inc.  
1290 Combermere  
Troy, MI 48083

Purchase Order: 1349  
Scott Project #: 501299

### ANALYTICAL INFORMATION

Required to exceed the minimum specifications of EPA Protocol I Procedure #G1, Section Number 3.0.4

Cylinder Number: ALM013040  
Cylinder Pressure: 1900 psig

Certification Date: 2-2-94  
Previous Certification Dates: None

Expiration Date: 2-2-97

### ANALYZED CYLINDER

Components  
Propane

Certified Concentration  
29.98 ppm

Analytical Uncertainty\*  
±1% NIST Directly Traceable

Balance Gas: Nitrogen

\*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

### REFERENCE STANDARD

Type: SRM 2643A  
Expiration Date: 10-14-95

Cylinder Number  
SX-20305

Concentration  
99.12 ppm Propane in N<sub>2</sub>

### INSTRUMENTATION

Instrument/Model/Serial #  
Prop: Beckman/400/1002059

Last Date Calibrated  
1-8-94

Analytical Principle  
Flame Ionization Detector

### ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
Propane	Date: 2-2-94      Response Units: mv Z1=0.00    R1=99.10    T1=30.00 R2=99.10    Z2=0.00    T2=30.00 Z3=0.00    T3=30.00    R3=99.10 Avg. Conc. of Cust. Cyl. 29.98 ppm		$Concentration = A + Bx + Cx^2 + Dx^3 + Ex^4$ $r = 0.99999$ SRM 2643A Constants:      A = -0.03442105 B = 1.000549      C = 0 D = 0              E = 0
			$Concentration = A + Bx + Cx^2 + Dx^3 + Ex^4$
			$Concentration = A + Bx + Cx^2 + Dx^3 + Ex^4$

Special Notes: NO OTHER HYDROCARBONS DETECTED ON G.C.

*F. P. Doran*  
Analyst Frank P. Doran

Air Products and Chemicals, Inc.  
 SPECIALITY GAS DEPARTMENT  
 12722 S. WENTWORTH AVENUE  
 CHICAGO, IL 60628

**Certificate of Analysis - EPA Protocol Gas Standard**


PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G  
 Customer: ARMSTRONG ENVIRONMENTAL Order No: 36A-00598  
 7715 SOVEREIGN ROW Notes: Batch No: 861-18145  
 DALLAS TX 75247


Cylinder No: 8G9132456  
 Cylinder Pressure: 2000 psig  
 Certification Date: 05/09/94  
 Expiration Date: 05/09/97

PO: 1371	Rel:	Reference Standards	Standard	Concentration	Instrument	Analytical Instrumentation	Serial	Last	Measurement
Component	Concentration	Cylinder #	Number	Concentration	Make/Model	Number	Calibration	Principle	
PROPANE	909 ±2.2 PPM	SG9128533BAL	GMIS	1025.0000 PPM	GOW-Mac 750	59405U	05/05/94	GC-FID	

Balance Gas: Nitrogen

\* Standard should not be used below 150 psig

Analyst:   
 James Laas

Approved By:   
 Robert McNear



To: BOC GASES-DIST.-TEKINS  
 Expiration Date: 04/07/98  
 Customer P.O.: K11851  
 Balance Gas: Nitrogen  
 CAS 7727-37-9

**Certification of Analysis - EPA Protocol Gas**  
 Performed According to Section 3.0.4

Certified Per Traceability Procedure 4 G1  
 Certified Accuracy 11 NIST Protocol 4.1

Cylinder Number: 69358  
 Serial Number: C019188  
 Date: 04/03/95  
 Cylinder Pressure: 2000 PSIG  
 Certification Date: 04/07/95  
 Location: Royal Oak, M.I.

Component	Certified Concentration	SRM No.	SRM Conc.	Cylinder Number	Serial Number	Analytical Procedure	Analytical Information	Make	Model	Calibration Date
Propane	104.8 ppm	2644	244.2 ppm	CAU3122	RAPID 4189	Flame Ionization Detector	Beckman	400	03/12/95	CAS 74-98-6

First Analysis      Analyst: L. Corey      Date: 04/07/95

Zero Gas	Reference Gas	Sample Gas	Concentration
00.0	81.4	35.0	105.0 ppm
00.0	81.6	35.0	104.7 ppm
00.0	81.8	35.0	104.5 ppm
Average-			104.7 ppm

Second Analysis      Analyst: L. Corey      Date: 04/07/95

Zero Gas	Reference Gas	Sample Gas	Concentration
00.0	81.4	35.0	105.0 ppm
00.0	81.7	35.0	104.5 ppm
00.0	81.5	35.0	104.9 ppm
Average-			104.8 ppm

This Calibration Standard has been Certified versus EPA Traceability Protocol 4.1, Procedure 61, and Analysis performed per section 3.0.4  
 Certified Concentration: Balance - Nitrogen, Propane-104.8 ppm

APPROVED BY M. Kelly  
 Laboratory Manager

EPA 821-R-95-010

AIR PRODUCTS  
4822 INDUSTRY LANE  
DURHAM, NC 27713

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-23473

CYLINDER #:SG9113690 CYL PRESSURE: 2000PSIG

EXPIRATION DATE:4-7-96

LAST ANALYSIS DATE: 4-7-93

BATCH# 05867

CUSTOMER: AIR PRODUCTS  
DALLAS, TX 75233

P.O.#

METHOD: EPA PROTOCOL # 1 3.0.4. G-1

STANDARD:

SRM #: 2644

CYL #: FF39583

CONC.: 244.5 PPM

VALID DATE:7-13-90

EXPIR. DATE:7-18-94

INSTRUMENT:

COMPONENT: BECKMAN THC

MODEL #: 400

SERIAL #: 1003052

LAST CAL.: 4-2-93

COMP: C3H8  
MEAN CONC: 203 PPM

REPLICATE CONC.

DATE: 4-7-93

DATE:

203 PPM

203 PPM

204 PPM

COMP:  
MEAN CONC:

REPLICATE CONC.

DATE:

DATE:

COMP:  
MEAN CONC:

REPLICATE CONC.

DATE:

DATE:

BALANCE GAS: NITROGEN

185

REPLICATE DATA

DATE: 4-7-93

Z	0	R	425	C	352.9
R	426	Z	0	C	353.7
Z	0	C	354.6	R	425

REPLICATE DATA

DATE:

Z		R		C
R		Z		C
Z		C		R

REPLICATE DATA

DATE:

Z		R		C
R		Z		C
Z		C		R

COMPONENT:

C3H8

DATE:

Z		R		C
R		Z		C
Z		C		R

COMPONENT:

DATE:

Z		R		C
R		Z		C
Z		C		R

COMPONENT:

DATE:

Z		R		C
R		Z		C
Z		C		R

Z=ZERO C=CANDIDATE R=REFERENCE

ANALYST:

*David G.*

APPROVED BY:

*Arthur J. Sullivan*

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, AIR PRODUCTS SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE. ANY USE OF THIS REPORT OR THE INFORMATION CONTAINED HEREIN SHALL BE AT THE SOLE RISK OF THE USER."

Air Products and Chemicals, Inc.  
SPECIALTY GAS DEPARTMENT  
12722 S. WENTWORTH AVENUE  
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer: ARMSTRONG ENVIRONMENTAL 7715 SOVEREIGN ROW DALLAS TX 75247

Notes: Order No: 36A-006058-861-18185  
Batch No: 861-18185  
Cylinder No: SG9132377BA  
Cylinder Pressure: 2000 psig  
Certification Date: 05/07/94  
Expiration Date: 05/07/97

PO: 1372 Reli

\*\*\* Certified Concentration \*\*\* Reference Standards \*\*\*\*\* Analytical Instrumentation \*\*\*\*\*

Component	Certified Concentration	Cylinder #	Standard Number	Concentration	Instrument Make/Model	Serial Number	Last Calibration	Measurement Principle
PROPANE	200 ±1.0	PPH SG9128591BAL	GMIS	201.1000 PPM	GC-Mac 750	59405U	04/14/94	GC-FID

Balance Gas: Nitrogen

\* Standard should not be used below 140 psig

Analyst: Jamey Laab  
Jamey Laab

Approved By: Robert McNear  
Robert McNear

**Air Products and Chemicals, Inc.**  
 SPECIALTY GAS DEPARTMENT  
 12722 S. WENTWORTH AVENUE  
 CHICAGO, IL 60628

**Certificate of Analysis - EPA Protocol #1 Gases**

PERFORMED ACCORDING TO SECTION 3.0.4 (Procedure #G1)

Order No: 36A-004394-  
 Batch No: 861-16363

Customer:  
 SOUTHWESTERN ELECTRIC POWER COMPAN  
 WELSH POWER PLANT  
 FM RD 1735  
 CASON TX 75636

Cylinder No: SG9121051BA1  
 Cylinder Pressure: 2000 psig  
 Certification Date: 01/24/04  
 Expiration Date: 01/24/96

PO: 53909 Rel: \*\*\*\*\*  
 \*\*\* Certified Concentration \*\*\* Reference Standards \*\*\*\*\*  
 Certified Standard Instrument Make/Model Analytical Instrumentation \*\*\*\*\*  
 Component Concentration Cylinder # Number Concentration Make/Model Serial Last Calibration Measurement  
 NITRIC OXIDE 254 PPM SG9113409BAL GMIS 234.6000 PPM Rosemount 951a 6101877 10/29/93 CHEMILUMINESCEN  
 Balance Gas: Nitrogen  
 Contaminant  
 Nitrogen Dioxide .800 PPM

**Analytical Data\***

Component: NITRIC OXIDE				Second Analysis Date: 01/24/04			
First Analysis Date: 01/17/94				Zero *** Test Gas ***			
Zero	*** Test Gas ***	*** Ref. Gas ***	***	Zero	*** Test Gas ***	*** Ref. Gas ***	***
mV	mV	PPM	PPM	mV	mV	PPM	PPM
.000	104	254	235	.030	104	254	235
.010	104	254	235	.040	104	254	235
.000	104	255	235	.050	104	254	235
Average:		254		Average:		254	

\* Calculations performed per Section 3.0.4 subsection 4.1.7

Analyst: *James Laas*  
 James Laas

Approved By: *Robert McNear*  
 Robert McNear

**Air Products and Chemicals, Inc.**  
SPECIALTY GAS DEPARTMENT  
12722 S. WENTWORTH AVENUE  
CHICAGO, IL 60628

**EPA Protocol Gas Standard**

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND  
CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #01)

Customer:	Cylinder No: SG9128617BAL
ARMSTRONG ENVIRONMENTAL	Cylinder Pressure: 2000 psig
7715 SOVEREIGN ROW	Certification Date: 04/18/94
DALLAS TX 75247-	Expiration Date: 04/18/96
	Analyst: James Laas

Contact:  
Telephone: ( )

Component: NITRIC OXIDE	Reference Standard
Certified Concentration: 112 ± 0.5 PPM	Standard: GMIS
Analytical Method: CHEMILUMINESCENCE	Cylinder: SG9113408BAL
	Concentration: 146.9000PPM

Balance Gas: Nitrogen

Air Products and Chemicals, Inc.  
SPECIALTY GAS DEPARTMENT  
12722 S. WENTWORTH AVENUE  
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1  
Customer: APCI 3415 BANNING ST DALLAS, TX. TX 75233 Notes: Order No: 360-047885 Batch No: 861-23143


Cylinder No: SG91330798  
Cylinder Pressure\*: 2000 psig  
Certification Date: 01/22/95  
Expiration Date: 01/22/97

PO: Rel: \*\*\* Certified Concentration \*\*\* Reference Standards \*\*\*\*\* Analytical Instrumentation \*\*\*\*\*  
Component Concentration Cylinder # Standard Number Concentration Make/Model Instrument Serial Last Measurement  
NITRIC OXIDE 50.8 t.26 PPM SG9113412BAL GMTS 59.0900 PPM Rosemount 951a 0101877 01/13/95 CHEMILUMINESCE

Balance Gas: Nitrogen  
Contaminant Nitrogen Dioxide .200 PPM

\* Standard should not be used below 150 psig

190

Analyst:   
Richard Vandyke

Approved By:   
Robert McNear

Air Products and Chemicals, Inc.  
SPECIALTY GAS DEPARTMENT  
12722 S. WENTWORTH AVENUE  
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G

Customer: ARMSTRONG ENVIRONMENTAL

7715 SOVEREIGN ROW

DALLAS TX 75247

Notes:

Order No: 36A-006051  
Batch No: 861-18318

Cylinder No: SG91323701

Cylinder Pressure\*: 2000 psig

Certification Date: 05/25/94

Expiration Date: 05/25/96

PO: 1372 Rel: Reference Standards \*\*\*\*\* Analytical Instrumentation \*\*\*\*\*

\*\*\* Certified Concentration \*\*\*  
Certified Concentration


Component Concentration Cylinder # Number Concentration Make/Model Instrument Serial Last Measurement  
NITRIC OXIDE 95.8 ±.42 PPM SG9103337BAL GMS 93.6000 PPM Rosemount 951a 0101877 05/04/94 CHEMILUMINESC


Balance Gas: Nitrogen

Contaminant

Nitrogen Dioxide .500 PPM

\* Standard should not be used below 150 psig

Analyst:   
Richard Vandyke

Approved By:   
Robert McNear





60231+

**Airco Special Gases**  
4551 North Access Road  
Chattanooga  
Tennessee 37415

Telephone: 615-877-4387  
FAX: 615-877-8694

**ANALYTICAL REPORT**

To: BOC Gases  
2615 Joe Field Road  
Dallas, TX 75229

Date Reported: 11-16-94  
Test Number: 41269  
Fill Date: 11-16-94

Material Submitted: 100 ppm Carbon Monoxide, Balance Nitrogen  
Specification Number: BOC Specifications  
Method of Analysis: Non-Dispersive Infrared Analyzer

Analyzed: Cylinder No. CC71796      Size 1S2, CGA 350      1650 psi

<u>Component</u>	<u>Specification</u>	<u>Concentration</u>
Carbon Monoxide	100 ppm	98.0 ppm
Nitrogen	Balance	Balance

by   
\_\_\_\_\_  
AUTHORIZED SIGNATURE

662#13



Airco Special Gases  
4551 North Access Road  
Chattanooga  
Tennessee 37415  
Telephone: 615-877-4387  
FAX: 615-877-8824

**ANALYTICAL REPORT**

To: BOC Gases  
2615 Joe Field Road  
Dallas, TX 75247

Date Reported: 11-16-94  
Test Number: 41267  
Fill Date: 11-16-94

Material Submitted: 400 pps Carbon Monoxide, Balance Nitrogen  
Specification Number: BOC Specifications  
Method of Analysis: Non-Dispersive Infrared Analyzer

Analyzed: Cylinder No. CC6529      Size 152, CGA 350      2000 psi

<u>Component</u>	<u>Specification</u>	<u>Concentration</u>
Carbon Monoxide	400 pps	391 pps
Nitrogen	Balance	Balance

by   
AUTHORIZED SIGNATURE

**BOC GASES**

**BOC GASES**  
1075 Cindare Drive  
Port Allen  
Louisiana 70767  
Telephone: 504-388-0900

FAX: 504-388-0959

BOC Gases  
Division of the BOC Group, Inc.  
1075 Cindare Drive  
Port Allen, LA 70767

Date Reported: 01/05/95

Customer Order No.: R11733

Shipper No.: 671251

Test No.: 0195-021

ANALYTICAL REPORT

To: BOC RETAIL  
DALLAS, TX

Material Submitted: CARBON MONOXIDE IN NITROGEN

Information Requested: CARBON MONOXIDE CONCENTRATION

Method of Analysis: NON-DISPERSIVE INFRARED

Result of Investigation: Cyl.No.: CC90936

<u>Component</u>	<u>Specification</u>	<u>Concentration</u>
CARBON MONOXIDE	250 PPM	250 PPM
NITROGEN	BALANCE	BALANCE

Principal Analyst: C. Monari



# Scott Specialty Gases, Inc.

Shipped  
From:

3714 LAPAS DRIVE  
HOUSTON TX 77023  
Phone: 713-644-4820

Fax: 713-644-0244

## CERTIFICATE OF ANALYSIS

ARMSTRONG ENVIRONMENTAL

7715 SOVEREIGN ROW

DALLAS

TX 75247

PROJECT #: 04-31603-001

PO#: 1365

ITEM #: 04021453 2AL

DATE: 4/05/94

CYLINDER #: ALM028262

ANALYTICAL ACCURACY: +-1%

PRODUCT EXPIRATION: 4/04/95

BLEND TYPE : ACUBLEND MASTER GAS

COMPONENT

CARBON MONOXIDE  
NITROGEN

REQUESTED GAS

CONC MOLES  
400. PPM  
BAL

ANALYSIS

(MOLES)  
400. PPM  
BAL

2000 PSI

ANALYST: 

APPROVED BY: 

195



# Scott Specialty Gases, Inc.

Shipped  
From:

3714 LAPAS DRIVE  
HOUSTON TX 77023  
Phone: 713-644-4820

Fax: 713-644-0244

## CERTIFICATE OF ANALYSIS

ARMSTRONG ENVIRONMENTAL

PROJECT #: 04-29795-001

7715 SOVEREIGN ROW

PO#: 1349

ITEM #: 04021453 2AL

DATE: 1/27/94

DALLAS

TX 75247

CYLINDER #: ALM022671

ANALYTICAL ACCURACY: +/- 1%

PRODUCT EXPIRATION: 1/27/95

BLEND TYPE : ACUBLEND MASTER GAS

COMPONENT

CARBON MONOXIDE  
NITROGEN

REQUESTED GAS

CONC MOLES

100. PPM  
BAL

ANALYSIS

(MOLES)

100. PPM  
BAL

2000 PSI

ANALYST: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_

196



# Scott Specialty Gases, Inc.

Shipped  
From:

3714 LAPAS DRIVE  
HOUSTON TX 77023  
Phone: 713-644-4820

Fax: 713-644-0244

## CERTIFICATE OF ANALYSIS

ARMSTRONG ENVIRONMENTAL

PROJECT #: 04-27582-003

7715 SOVEREIGN ROW

PO#: 1323

ITEM #: 04021412 2AL

DALLAS

TX 75247

DATE: 10/26/93

CYLINDER #: AAL16005

ANALYTICAL ACCURACY: +/- 1%

FILL PRESSURE: 2000 PSI

PRODUCT EXPIRATION: 10/25/94

BLEND TYPE : ACUBLEND MASTER GAS

### COMPONENT

CARBON MONOXIDE  
AIR

### REQUESTED GAS

CONC MOLES  
50. PPM  
BAL

### ANALYSIS

(MOLES)  
50.5 PPM  
BAL

ANALYST: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_

197

# CORRIGAN TEXAS OSB STACK TEST OPERATIONAL SUMMARY

06/01/95

## DRYER R-T-O

ALL  
INLET  
PM/CO/NOX/  
CO<sub>2</sub>

	DRYER 1	DRYER 2	DRYER 3
Dry Furnish Moisture (%)	7.4 - 9.6 8.5	5.0 - 6.4 5.7	6.4 - 7.6 7.0
Inlet Temp. (°F)	700 - 1250 925	250 - 1000 625	300 - 1050 675
Outlet Temp. (°F)	190 - 205 198	255 - 265 260	205 - 220 213
Production (lbs/hr)	14,200 7.1	10,800 5.4	10,400 5.2

## 14 PLATEN PRESS\*

Press Temp. (°F)	400 - 420°
Thickness (in)	0.438**
Density (nominal, lbs/cu ft)	45

**PRODUCTION** (Finished 3/8 in basis) 18,816 ft<sup>2</sup>/hr\*\*\*  
26,460 lbs/hr

\*No press stack samples were collected per accepted sampling protocol - currently no control on press emissions.

\*\*Nominal Thickness = 7/16 inch

\*\*\*Annualized Production of 164,828,160 ft<sup>2</sup> 3/8 basis (8760 hrs)

# CORRIGAN TEXAS OSB STACK TEST OPERATIONAL SUMMARY

06/02/95

## DRYER R-T-O

	DRYER 1	DRYER 2	DRYER 3
Dry Furnish Moisture (%)	6.6 - 7.0 <i>6.8</i>	4.4 - 5.6 <i>5</i>	6.6 - 10.2 <i>8.4</i>
Inlet Temp. (°F)	350 - 1375 <i>863</i>	150 - 950 <i>550</i>	300 - 1000 <i>650</i>
Outlet Temp. (°F)	200 - 205 <i>203</i>	255 - 265 <i>250</i>	210 - 225 <i>218</i>
Production (lbs/hr)	14,600 <i>7.3</i>	10,800 <i>5.4</i>	11,200 <i>5.0</i>

## 14 PLATEN PRESS\*

Press Temp. (°F)	400 - 420°
Thickness (in)	0.438**
Density (nominal, lbs/cu ft)	45

**PRODUCTION** (Finished 3/8 in basis)

18,973 ft<sup>2</sup>/hr \*\*\*  
26,681 lbs/hr

\*No press stack samples were collected per accepted sampling protocol - currently no control on press emissions.

\*\*Nominal Thickness = 7/16 inch

\*\*\*Annualized Production of 166,203,480 ft<sup>2</sup> 3/8 basis (8760 hrs)

ALL  
RTO  
OUTLET

ALL  
INLET  
VOC/110013/  
CO2