

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

38

4-59

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020

FAX: (612) 786-7854

**RESULTS OF THE AUGUST 27 - 29, 1996
AIR EMISSION COMPLIANCE TESTS
AT THE LOUISIANA PACIFIC OSB PLANT
NEWBERRY, MICHIGAN**

Submitted to:

LOUISIANA-PACIFIC CORPORATION

Route 8, Box 8263

Hayward, Wisconsin 54843

Attention:

Sue Somers

Approved by:



Daniel J. Despen

Manager

Stationary Source Testing Department

Report Number 6-8201

October 2, 1996

SL/sll

TABLE OF CONTENTS

	ABBREVIATIONS	iii
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	5
3	RESULTS	21
	3.1 Results of Orsat & Moisture Determinations	22
	3.2 Results of Particulate Determinations	32
	3.3 Results of Sulfur Dioxide Determinations	37
	3.4 Results of Oxides of Nitrogen Determinations	39
	3.5 Results of Opacity Observations	44
	3.6 Results of Carbon Monoxide Determinations	48
	3.7 Results of Total Hydrocarbons Determinations	53
	3.8 Results of Formaldehyde Determinations	58
	3.9 Results of MDI Determinations	63
4	RESULTS OF FUEL ANALYSES	65

APPENDICES:

- A - Results of Volumetric Flow Rate Determinations
- B - Location of Test Ports
- C - Field Data Sheets
- D - Interpoll Laboratories Analytical Results
- E - Computer Datalogger Printouts
- F - Analyzer Specifications
- G - Measurement Systems Performance Specifications
- H - Calibration Gas Certification Sheets
- I - Process Rate Information
- J - Procedures
- K - Calculation Equations
- L - Sampling Train Calibration Data

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.

1 INTRODUCTION

During the period of August 27 - 29, 1996 Interpoll Laboratories personnel conducted Air Emission Compliance tests at the Louisiana Pacific Corporation (LP) OSB Plant Located in Newberry, Michigan on the following sources:

<u>Source</u>	<u>Parameters</u>
Dryer Primary Cyclone Exhaust	PM,NO _x ,CO,THC's,CH ₂ O
E-Tube Outlet	PM,NO _x ,CO,THC's,CH ₂ O
Dryer RTO Outlet	PM,SO ₂ ,NO _x ,VE,CO,THC's,CH ₂ O
Press Vents	PM,NO _x ,VE,CO,THC's,CH ₂ O,MDI

On-site testing was performed by Mark Kaehler, Scott Fjelsta, Jamie Bainville, Ed Juers, Bob Aschenbach, Mark Petersen, Jim Lorenz, and Dan Hulleman. Coordination between testing activities and plant operation was provided by Keith Seelig of LP. The tests were not witnessed by a member of the Michigan Department of Natural Resources.

Particulate evaluations were performed in accordance with EPA Methods 2-5, CFR Title 40, Part 60, Appendix A (revised July 1, 1995). A preliminary determination of the gas linear velocity profile was made at each test location before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with EPA Method 202.

An integrated flue gas sample was extracted using a specially designed gas sampling system. Integrated flue gas samples were collected in 44-liter Tedlar bags housed in a protective aluminum container. After sampling was complete, the bags were sealed and returned to the laboratory for Orsat analysis. Prior to sampling, the Tedlar bags are leak-checked at 15 IN.HG. vacuum with an in-line rotameter. Bags with any detectable in-leakage are discarded. Integrated flue gas samples collected during each particulate sampling were also analyzed for carbon monoxide as per EPA Method 10 (NDIR).

Oxides of nitrogen, carbon monoxide, oxygen, and carbon dioxide concentrations at the **Dryer Primary Cyclone Exhaust, E-Tube Outlet, and Press Vents** were determined in accordance with Methods 7E, 10, and 3A (Ibid). A slip stream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice which was used to ensure that the flow from the stack exceeds the requirements of the analyzers. A three-way valve on the probe was used to introduce standard gas for the "system bias check".

Oxides of nitrogen, carbon monoxide, oxygen, and carbon dioxide evaluations at the **Dryer RTO Outlet** were performed in accordance with EPA Methods 7E, 10, and 3A, CFR Title 40, Part 60, Appendix A (revised July 1, 1995). For oxygen analysis, a slip stream of sample gas was withdrawn from the exhaust gas stream using test ports (provided by the plant) on the stack adjacent to the CEMS using a heat-traced probe and filter assembly. After passing through the filter, the gas passed through two condenser-type moisture removal systems operating in series. The particulate-free dry gas was then transported to the oxygen analyzer with the excess exhausted to the atmosphere through a calibrated orifice which was used to ensure that the flow from the stack exceeds the requirements of the two analyzers. A three-way valve on the probe was used to introduce standard gas for the "system bias check". For NO_x , CO, and CO_2 analysis, a dilution probe based system was used. In this system a slip stream of exhaust gas is drawn from the exhaust gas stream using an EPM dilution probe. The sample stream is filtered and diluted (approximate dilution during these tests was 300:1) before delivery to the NO_x , CO, and CO_2 analyzers. The analog response of the analyzers in both systems was recorded using a computer data logger and backed up with a strip chart recorder. The analyzers were calibrated with National Specialty Gases and Air Products and Chemicals standard gases.

The analog response of each analyzer was recorded with a computer datalogger and backed up with a strip chart recorder. The NO_x , CO, O_2 and CO_2 analyzers were calibrated with National Specialty Gases and Air Products and Chemicals standard gases. The instrument was calibrated before and after each run as per EPA Method 7E, 10, and 3A. The

sample probe was moved through a three-point traverse (1/6, 3/6, 5/6 of the stack diameter) to measure oxides of nitrogen and carbon monoxide concentrations.

Formaldehyde samples were collected using EPA Method 0011 (SW 846 3rd Ed.). The samples were collected isokinetically using a Method 5 sampling train with an aqueous acidic 2,4-dinitrophenylhydrazine absorbing solution and analyzed by high performance liquid chromatography.

Total gaseous hydrocarbon concentrations were determined instrumentally using a Ratfisch Model RS55 heated flame ionization detector (HFID) calibrated against propane in air standards. The THC concentration was continuously monitored by extracting a slipstream of exhaust gas by means of a heated probe and filter holder. A heat-traced teflon line was used to transport the sample gas from the filter holder outlet to the analyzer inlet.

MDI concentrations were determined in accordance with the 1,2-PP Method as developed by Radian Corporation under contract to USEPA. This method employs collection of MDI with 1,2-PP in toluene reagent, with analysis by HPLC.

Testing on the Primary Cyclone Outlet Exhaust was conducted from two test ports oriented at 90 degrees. These test ports are located 7.4 diameters downstream and 14.9 diameters upstream of the nearest flow disturbances. A 12-point traverse was used to collect representative particulate and formaldehyde samples. Each traverse point was sampled 5 minutes to give a total sampling time of 60 minutes per run.

Testing on the E-Tube Outlet was conducted from two test ports oriented at 90 degrees. These test ports are located approximately 8 diameters downstream and 2 diameters upstream of the nearest flow disturbances. A 12-point traverse was used to collect representative particulate and formaldehyde samples. Each traverse point was sampled for 5 minutes to give a total sampling time of 60 minutes per run.

Testing on the Dryer RTO Outlet was conducted from two test ports oriented at 90 degrees. These test ports are located approximately 6.6 diameters downstream and 5.6 diameters upstream of the nearest flow disturbances. A 16-point traverse was used to collect

representative particulate and formaldehyde samples. Each traverse point was sampled for 4 minutes to give a total sampling time of 64 minutes per run. Visible emission determinations were performed at this site by Steve Kelker, an EPA-certified observer.

Testing on the Press Vents was conducted as one source by performing one half of the test run in one vent and one half of the test run in the second vent. Sampling was performed from a set of eight test ports (four on each vent) situated horizontally on a vertical section of each duct. A 24-point traverse was used to collect particulate and formaldehyde samples. Each traverse point was sampled three minutes for a total sampling time of 72 minutes per run. A 6-point traverse was used to collect MDI samples. Each traverse point was sampled 10 minutes to give a total sampling time of 60 minutes per run. Visible emission determinations were performed on each vent by Mark Petersen, an EPA-certified observer.

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The important results of the particulate emission compliance tests are summarized in Tables 1 - 4. The particulate results have been calculated using the dry plus method 202 condensible wet catch ("a" Tables) and again with the dry catch only ("b" Tables). An overview of all results is presented in the tables on the following pages:

<u>PARAMETER</u>	<u>MEASURED</u>
<u>DRYER PRIMARY CYCLONE EXHAUST</u>	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.366
. (LB/HR)	102
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.279
. (LB/HR)	77.5
Oxides of Nitrogen	
. (ppm,d)	28
. (LB/HR)	6.5
Carbon Monoxide	
. (ppm,d)	568
. (LB/HR)	80
TGNMO's	
. (ppmC,w)	292
. (LBC/HR)	22.7
Formaldehyde	
. (ppm,d)	4.8
. (LB/HR)	0.69
<u>E-TUBE OUTLET</u>	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.0340
. (LB/HR)	10.5
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.0110
. (LB/HR)	3.4
Oxides of Nitrogen	
. (ppm,d)	15
. (LB/HR)	3.9
Carbon Monoxide	
. (ppm,d)	513
. (LB/HR)	80
TGNMO's	
. (ppmC,w)	175
. (LBC/HR)	16
Formaldehyde	
. (ppm,d)	19
. (LB/HR)	3.3

* *Note: TGNMO's = Total Gaseous Non-Methane Organics.*

<u>PARAMETER</u>	<u>MEASURED</u>
DRYER RTO OUTLET	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.00673
. (LB/HR)	2.1
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.00153
. (LB/HR)	0.47
Sulfur Dioxide	
. (ppm,d)	< 1
. (LB/HR)	< 0.36
Oxides of Nitrogen	
. (ppm,d)	24
. (LB/HR)	6.1
Opacity (%)	
	0.31
Carbon Monoxide	
. (ppm,d)	54
. (LB/HR)	8.4
TGNMO's	
. (ppmC,w)	≤ 2.6
. (LBC/HR)	≤ 0.23
Formaldehyde	
. (ppm,d)	1.2
. (LB/HR)	0.21
PRESS VENTS	
Particulate	
<i>DRY + WET CATCH</i> (GR/DSCF)	0.00551
. (LB/HR)	9.0
<i>DRY CATCH ONLY</i> (GR/DSCF)	0.00462
. (LB/HR)	7.6
Oxides of Nitrogen	
. (ppm,d)	1.3
. (LB/HR)	1.8
Opacity	
West (%)	2.4
East (%)	2.4
Carbon Monoxide	
. (ppm,d)	3.9
. (LB/HR)	3.3
TGNMO's	
. (ppmC,w)	5.2
. (LBC/HR)	2.0
Formaldehyde	
. (ppm,d)	2.6
. (LB/HR)	2.2
MDI	
. (ppm,d)	0.0162
. (LB/HR)	0.13

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples which were conducted by Interpoll Labs. On the basis of these facts and a complete review of the data and results, it is our opinion that the results reported herein are accurate and closely reflect the actual values which existed at the time the test was performed.

Table 1a Summary of the Results of the August 27, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-27-96	08-27-96	08-27-96
Time runs were done (HRS)	1645/1751	1940/2042	2135/2337
Process rate (LB/TFP)	12.9	12.9	12.9
Volumetric flow actual (ACFM)	58888	58474	60583
standard (DSCFM)	31359	31613	34409
Gas temperature (DEG-F)	253	255	253
Moisture content (%V/V)	24.22	22.84	19.19
Gas composition (%V/V, dry)			
carbon dioxide	4.30	4.00	4.10
oxygen	16.10	16.60	16.50
nitrogen	79.60	79.40	79.40
Isokinetic variation (%)	101.6	98.9	96.7
Particulate concentration actual (GR/ACF)	0.213	0.191	0.195
standard (GR/DSCF)	0.400	0.353	0.344 ³⁶⁶
Part. emission rate (LB/HR)	107.4	95.74	101.5

Note: Dry + Method 202 Condensible Particulate Material

Table 1b Summary of the Results of the August 27, 1996 Particulate Emission Compliance Test of the Dryer Primary Cyclone Exhaust at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-27-96	08-27-96	08-27-96
Time runs were done (HRS)	1645/1751	1940/2042	2135/2337
Process rate (LB/TFP)	12.9	12.9	12.9
Volumetric flow actual (ACFM)	58888	58474	60583
standard (DSCFM)	31359	31613	34409
Gas temperature (DEG-F)	253	255	253
Moisture content (%V/V)	24.22	22.84	19.19
Gas composition (%V/V, dry)			
carbon dioxide	4.30	4.00	4.10
oxygen	16.10	16.60	16.50
nitrogen	79.60	79.40	79.40
Isokinetic variation (%)	101.6	98.9	96.7
Particulate concentration actual (GR/ACF)	0.168	0.144	0.146
standard (GR/DSCF)	0.315	0.266	0.256
Part. emission rate (LB/HR)	84.69	72.08	75.59

Note: Dry Catch Only

Table 2a Summary of the Results of the August 27, 1996 Particulate Emission Compliance Test of the E-Tube Outlet at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-27-96	08-27-96	08-27-96
Time runs were done (HRS)	1645/1750	1940/2045	2135/2347
Process rate (LB/TFP)	12.9	12.9	12.9
Volumetric flow actual (ACFM)	58959	60166	59448
standard (DSCFM)	35023	37164	36184
Gas temperature (DEG-F)	164	161	158
Moisture content (%V/V)	27.53	25.05	26.47
Gas composition (%V/V, dry)			
carbon dioxide	3.90	3.60	3.70
oxygen	16.50	16.90	16.80
nitrogen	79.60	79.50	79.50
Isokinetic variation (%)	105.2	99.0	101.1
Particulate concentration actual (GR/ACF)	.0258	.0133	.0226
standard (GR/DSCF)	.0434	.0216	.0371
Part. emission rate (LB/HR)	13.04	6.88	11.52

Note: Dry + Method 202 Condensable Particulate Material

Table 2b Summary of the Results of the August 27, 1996 Particulate Emission Compliance Test of the E-Tube Outlet at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-27-96	08-27-96	08-27-96
Time runs were done (HRS)	1645/1750	1940/2045	2135/2347
Process rate (LB/TFP)	12.9	12.9	12.9
Volumetric flow:			
actual (ACFM)	58959	60166	59448
standard (DSCFM)	35023	37164	36184
Gas temperature (DEG-F)	164	161	158
Moisture content (%V/V)	27.53	25.05	26.47
Gas composition (%V/V, dry)			
carbon dioxide	3.90	3.60	3.70
oxygen	16.50	16.90	16.80
nitrogen	79.60	79.50	79.50
Isokinetic variation (%)	105.2	99.0	101.1
Particulate concentration:			
actual (GR/ACF)	.007760	.005798	.006305
standard (GR/DSCF)	.0131	.009390	.0104
Part. emission rate (LB/HR)	3.92	2.99	3.21

Note: Dry Catch Only

Table 3a Summary of the Results of the August 27, 1996 Particulate Emission Compliance Test of the Dryer RTO Outlet at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-27-96	08-27-96	08-27-96
Time runs were done (HRS)	1645/1750	1940/2046	2135/2339
Process rate (LB/TFP)	12.9	12.9	12.9
Volumetric flow actual (ACFM)	68601	66597	67050
standard (DSCFM)	36861	34827	35163
Gas temperature (DEG-F)	281	273	273
Moisture content (%V/V)	22.84	25.67	25.47
Gas composition (%V/V, dry)			
carbon dioxide	3.00	4.00	4.00
oxygen	17.50	16.30	16.40
nitrogen	79.50	79.70	79.60
Isokinetic variation (%)	99.7	103.2	101.7
Particulate concentration actual (GR/ACF)	.004056	.003719	.002897
standard (GR/DSCF)	.007552	.007114	.005526
Part. emission rate (LB/HR)	2.39	2.12	1.67

Note: Dry + Method 202 Condensable Particulate Material

Table 3b Summary of the Results of the August 27, 1996 Particulate Emission Compliance Test of the Dryer RTO Outlet at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-27-96	08-27-96	08-27-96
Time runs were done (HRS)	1645/1750	1940/2046	2135/2339
Process rate (LB/TFP)	12.9	12.9	12.9
Volumetric flow actual (ACFM)	68601	66597	67050
standard (DSCFM)	36861	34827	35163
Gas temperature (DEG-F)	281	273	273
Moisture content (%V/V)	22.84	25.67	25.47
Gas composition (%V/V, dry)			
carbon dioxide	3.00	4.00	4.00
oxygen	17.50	16.30	16.40
nitrogen	79.50	79.70	79.60
Isokinetic variation (%)	99.7	103.2	101.7
Particulate concentration actual (GR/ACF)	.000779	.000935	.000713
standard (GR/DSCF)	.001451	.001790	.001360
Part. emission rate (LB/HR)	0.458	0.534	0.410

Note: Dry Catch Only

Table 4a Summary of the Results of the August 28, 1996 Particulate Emission Compliance Test of the Press Vents at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-28-96	08-28-96	08-28-96
Time runs were done (HRS)	1215/1318	1450/1552	1615/1717
Process rate (LB/TFP)	12.2	12.2	12.2
Volumetric flow actual (ACFM)	214034	211526	218092
standard (DSCFM)	191539	188269	193848
Gas temperature (DEG-F)	108	109	112
Moisture content (%V/V)	1.23	1.57	1.10
Gas composition (%V/V, dry)			
carbon dioxide	0.03	0.03	0.03
oxygen	20.90	20.90	20.90
nitrogen	79.07	79.07	79.07
Isokinetic variation (%)	99.3	100.3	99.9
Particulate concentration actual (GR/ACF)	.004471	.006435	.003813
standard (GR/DSCF)	.004999	.007233	.004292
Part. emission rate (LB/HR)	8.21	11.67	7.13

Note: Dry + Method 202 Condensable Particulate Material

Table 4b Summary of the Results of the August 28, 1996 Particulate Emission Compliance Test of the Press Vents at the Louisiana Pacific Plant in Newberry, Michigan.

ITEM	Run 1	Run 2	Run 3
Date of test	08-28-96	08-28-96	08-28-96
Time runs were done (HRS)	1215/1318	1450/1552	1615/1717
Process rate (LB/TFP)	12.2	12.2	12.2
Volumetric flow actual (ACFM)	214034	211526	218092
standard (DSCFM)	191539	188269	193848
Gas temperature (DEG-F)	108	109	112
Moisture content (%V/V)	1.23	1.57	1.10
Gas composition (%V/V, dry)			
carbon dioxide	0.03	0.03	0.03
oxygen	20.90	20.90	20.90
nitrogen	79.07	79.07	79.07
Isokinetic variation (%)	99.3	100.3	99.9
Particulate concentration actual (GR/ACF)	.003710	.005672	.002973
standard (GR/DSCF)	.004147	.006375	.003346
Part. emission rate (LB/HR)	6.81	10.29	5.56

Note: Dry Catch Only

Table 5. Summary of the Results of the August 27, 1996 Sulfur Dioxide Emission Compliance Tests at the Louisiana Pacific Plant in Newberry, Michigan.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
Dryer RTO Outlet			
8-27-96	1646-1756	< 1	< 0.37
8-27-96	1951-2055	< 1	< 0.35
8-27-96	2136-2336	< 1	< 0.35
Avg		< 1	< 0.36

Table 6. Summary of the Results of the August 27 & 29, 1996 Oxides of Nitrogen Emission Compliance Tests at the Louisiana Pacific Plant in Newberry, Michigan.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
Dryer Primary Cyclone Exhaust			
8-27-96	1646-1756	39	8.8
8-27-96	1951-2055	20	4.5
8-27-96	2136-2336	25	6.3
Avg		28	6.5
E-Tube Outlet			
8-27-96	1646-1756	13	3.3
8-27-96	1951-2055	14	3.7
8-27-96	2136-2335	18	4.6
Avg		15	3.9
Dryer RTO Outlet			
8-27-96	1646-1756	22	5.9
8-27-96	1951-2055	26	6.5
8-27-96	2136-2336	23	5.9
Avg		24	6.1
Press Vents			
8-29-96	0900-1000	0.8	1.2
8-29-96	1036-1136	1.6	2.2
8-29-96	1211-1311	1.4	2.0
Avg		1.3	1.8


Table 7. Summary of the Results of the August 27 & 29, 1996 Carbon Monoxide Emission Compliance Tests at the Louisiana Pacific Plant in Newberry, Michigan.

Date	Time (HRS)	Concentration (ppm.d)	Emission Rate (LB/HR)
Dryer Primary Cyclone Exhaust			
8-27-96	1646-1756	873	119
8-27-96	1951-2055	409	56
8-27-96	2136-2336	422	63
Avg		568	80
E-Tube Outlet			
8-27-96	1645-1750	770	118
8-27-96	1940-2045	356	58
8-27-96	2135-2347	412	65
Avg		513	80
Dryer RTO Outlet			
8-27-96	1646-1756	78	12.5
8-27-96	1951-2055	53	8.1
8-27-96	2136-2336	30	4.6
Avg		54	8.4
Press Vents			
8-29-96	0900-1000	6.2	5.2
8-29-96	1036-1136	3.2	2.6
8-29-96	1211-1311	2.4	2.0
Avg		3.9	3.3

Table 8. Summary of the Results of the August 27 & 29, 1996 TGNMO's Emission Compliance Tests at the Louisiana Pacific Plant in Newberry, Michigan.

Date	Time (HRS)	Concentration (ppmC,w)	Emission Rate (LBC/HR)
Dryer Primary Cyclone Exhaust			
8-27-96	1646-1756	321	24.8
8-27-96	1951-2055	276	21.1
8-27-96	2136-2336	280	22.3
Avg		292	22.7
E-Tube Outlet			
8-27-96	1646-1756	245	22.1
8-27-96	1951-2055	148	13.7
8-27-96	2136-2336	131	12.1
Avg		175	16.0
Dryer RTO Outlet			
8-27-96	1646-1756	5.8	0.51
8-27-96	1951-2055	< 1	< 0.09
8-27-96	2136-2336	< 1	< 0.09
Avg		≤ 2.6	≤ 0.23
Press Vents			
8-29-96	0900-1000	1.9	0.7
8-29-96	1036-1136	10.4	4.0
8-29-96	1211-1311	3.4	1.3
Avg		5.2	2.0

Corrected for methane



* TGNMO's = Total Gaseous Non-Methane Organics

Table 9. Summary of the Results of the August 27 & 28, 1996 Formaldehyde Emission Compliance Tests at the Louisiana Pacific Plant in Newberry, Michigan.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
Dryer Primary Cyclone Exhaust			
8-28-96	0930-1132	4.0	0.59
8-28-96	1215-1332	3.6	0.53
8-28-96	1500-1618	6.8	0.96
Avg		4.8	0.69
E-Tube Outlet			
8-28-96	0930-1115	19	3.5
8-28-96	1215-1317	19	3.2
8-28-96	1500-1604	19	3.1
Avg		19	3.3
Dryer RTO Outlet			
8-28-96	0930-1120	1.0	0.17
8-28-96	1215-1327	1.3	0.23
8-28-96	1500-1605	1.4	0.23
Avg		1.2	0.21
Press Vents			
8-27-96	1450-1616	4.7	3.7
8-27-96	1645-1809	1.0	0.9
8-27-96	1835-1959	2.2	1.9
Avg		2.6	2.2

Table 10. Summary of the Results of the August 29, 1996 MDI Emission Compliance Tests at the Louisiana Pacific Plant in Newberry, Michigan.

Date	Time (HRS)	Concentration (ppm,d)	Emission Rate (LB/HR)
Press Vents			
8-29-96	0900-1002	0.0237	0.19
8-29-96	1035-1136	0.0204	0.16
8-29-96	1210-1311	0.0044	0.03
Avg		0.0162	0.13

3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Orsat (gas composition) and moisture is presented first followed by the computer printout of the particulate, sulfur dioxide, oxides of nitrogen, opacity, carbon monoxide, total hydrocarbons, formaldehyde, and MDI results. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in Extended BASIC specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The emission rates have been calculated using the product of the concentration times flow method.

3.1 Results of Orsat and Moisture Determinations

Test No. 1
Dryer Primary Cyclone Exhaust

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-27-96	Run 2 08-27-96	Run 3 08-27-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	4.30	4.00	4.10
oxygen.....	16.10	16.60	16.50
nitrogen.....	79.60	79.40	79.40

Wet basis (orsat)

carbon dioxide.....	3.26	3.09	3.31
oxygen.....	12.20	12.81	13.33
nitrogen.....	60.32	61.26	64.16
water vapor.....	24.22	22.84	19.19
Dry molecular weight.....	29.33	29.30	29.32
Wet molecular weight.....	26.59	26.72	27.14
Specific gravity.....	0.918	0.923	0.938
Water mass flow.....(LB/HR)	28119	26256	22920

FO	1.116	1.075	1.073
----	-------	-------	-------

Test No. 1
E-Tube Outlet

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-27-96	Run 2 08-27-96	Run 3 08-27-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.90	3.60	3.70
oxygen.....	16.50	16.90	16.80
nitrogen.....	79.60	79.50	79.50

Wet basis (orsat)

carbon dioxide.....	2.83	2.70	2.72
oxygen.....	11.96	12.67	12.35
nitrogen.....	57.69	59.58	58.45
water vapor.....	27.53	25.05	26.47
Dry molecular weight.....	29.28	29.25	29.26
Wet molecular weight.....	26.18	26.43	26.28
Specific gravity.....	0.904	0.913	0.908
Water mass flow.....(LB/HR)	37317	34847	36547

FO	1.128	1.111	1.108
----	-------	-------	-------

Test No. 1
 Dryer RTO Outlet

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-27-96	Run 2 08-27-96	Run 3 08-27-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.00	4.00	4.00
oxygen.....	17.50	16.30	16.40
nitrogen.....	79.50	79.70	79.60

Wet basis (orsat)

carbon dioxide.....	2.31	2.97	2.98
oxygen.....	13.50	12.12	12.22
nitrogen.....	61.34	59.24	59.33
water vapor.....	22.84	25.67	25.47
Dry molecular weight.....	29.18	29.29	29.30
Wet molecular weight.....	26.63	26.39	26.42
Specific gravity.....	0.920	0.912	0.913
Water mass flow.....(LB/HR)	30601	33745	33708

FO	1.133	1.150	1.125
----	-------	-------	-------

Test No. 3
Dryer Primary Cyclone Exhaust

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-28-96	Run 2 08-28-96	Run 3 08-28-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.90	3.90	4.20
oxygen.....	16.60	16.60	16.10
nitrogen.....	79.50	79.50	79.70

Wet basis (orsat)

carbon dioxide.....	2.98	2.92	3.10
oxygen.....	12.69	12.45	11.87
nitrogen.....	60.78	59.61	58.75
water vapor.....	23.55	25.01	26.29
Dry molecular weight.....	29.29	29.29	29.32
Wet molecular weight.....	26.63	26.46	26.34
Specific gravity.....	0.920	0.914	0.910
Water mass flow.....(LB/HR)	0.00	0.00	0.00

FO	1.103	1.103	1.143
----	-------	-------	-------

Test No. 3
E-Tube Outlet

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-28-96	Run 2 08-28-96	Run 3 08-28-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	4.00	4.20	4.40
oxygen.....	16.70	16.50	16.30
nitrogen.....	79.30	79.30	79.30

Wet basis (orsat)

carbon dioxide.....	3.04	3.12	3.20
oxygen.....	12.70	12.28	11.86
nitrogen.....	60.30	58.99	57.71
water vapor.....	23.96	25.61	27.23
Dry molecular weight.....	29.31	29.33	29.36
Wet molecular weight.....	26.60	26.43	26.26
Specific gravity.....	0.919	0.913	0.907
Water mass flow.....(LB/HR)	0.00	0.00	0.00

FO	1.050	1.048	1.045
----	-------	-------	-------

Test No. 3
Dryer RTO Outlet

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-28-96	Run 2 08-28-96	Run 3 08-28-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	3.50	3.80	4.00
oxygen.....	16.70	16.50	16.20
nitrogen.....	79.80	79.70	79.80

Wet basis (orsat)

carbon dioxide.....	2.65	2.84	2.94
oxygen.....	12.63	12.33	11.92
nitrogen.....	60.37	59.55	58.71
water vapor.....	24.35	25.29	26.43
Dry molecular weight.....	29.23	29.27	29.29
Wet molecular weight.....	26.49	26.42	26.30
Specific gravity.....	0.915	0.913	0.909
Water mass flow.....(LB/HR)	0.00	0.00	0.00

FO	1.200	1.158	1.175
----	-------	-------	-------

Test No. 5
Press Vents

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-29-96	Run 2 08-29-96	Run 3 08-29-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07

Wet basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.57	20.64	20.59
nitrogen.....	77.83	78.09	77.91
water vapor.....	1.57	1.24	1.47
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.67	28.71	28.68
Specific gravity.....	0.990	0.992	0.991
Water mass flow.....(LB/HR)	0.00	0.00	0.00

Test No. 7
 Press Vents

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-27-96	Run 2 08-27-96	Run 3 08-27-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07

Wet basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.66	20.62	20.63
nitrogen.....	78.15	78.03	78.04
water vapor.....	1.16	1.32	1.30
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.71	28.70	28.70
Specific gravity.....	0.992	0.991	0.991
Water mass flow.....(LB/HR)	0.00	0.00	0.00

Test No. 8
Press Vents

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 08-28-96	Run 2 08-28-96	Run 3 08-28-96
-------------	-------------------	-------------------	-------------------

Dry basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.90	20.90	20.90
nitrogen.....	79.07	79.07	79.07

Wet basis (orsat)

carbon dioxide.....	0.03	0.03	0.03
oxygen.....	20.64	20.57	20.67
nitrogen.....	78.10	77.83	78.20
water vapor.....	1.23	1.57	1.10
Dry molecular weight.....	28.84	28.84	28.84
Wet molecular weight.....	28.71	28.67	28.72
Specific gravity.....	0.992	0.990	0.992
Water mass flow.....(LB/HR)	6687	8423	6043

3.2 Results of Particulate Determinations

Test No. 1
Dryer Primary Cyclone Exhaust

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	08-27-96	08-27-96	08-27-96
Time run start/end.....(HRS)	1645/1751	1940/2042	2135/2337
Static pressure.....(IN.WC)	-11.60	-11.60	-11.60
Cross sectional area (SQ.FT)	9.62	9.62	9.62
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	241.0	215.0	185.0
desiccant.....(GRAMS)	13.0	16.0	12.0
total.....(GRAMS)	254.0	231.0	197.0
Total particulate material..			
.....collected(grams)	0.9703	0.8423	0.8727
Gas meter coefficient.....	1.0007	1.0007	1.0007
Barometric pressure..(IN.HG)	29.26	29.26	29.26
Avg. orif.pres.drop..(IN.WC)	1.37	1.32	1.48
Avg. gas meter temp..(DEF-F)	91.7	100.7	93.1
Volume through gas meter....			
at meter conditions...(CF)	39.88	39.80	41.73
standard conditions.(DSCF)	37.46	36.78	39.11
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.186	.186	.186
Avg.stack gas temp ..(DEG-F)	253	255	253
Volumetric flow rate.....			
actual.....(ACFM)	58888	58474	60583
dry standard.....(DSCFM)	31359	31613	34409
Isokinetic variation.....(%)	101.6	98.9	96.7
Particulate concentration...			
actual.....(GR/ACF)	0.21273	0.19094	0.19545
dry standard.....(GR/DSCF)	0.39962	0.35332	0.34427
Particle mass rate...(LB/HR)	107.417	95.737	101.536

Test No. 1
E-Tube Outlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	08-27-96	08-27-96	08-27-96
Time run start/end.....(HRS)	1645/1750	1940/2045	2135/2347
Static pressure.....(IN.WC)	-3.50	-3.50	-3.50
Cross sectional area (SQ.FT)	12.57	12.57	12.57
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	263.0	233.0	241.0
desiccant.....(GRAMS)	10.0	7.0	16.0
total.....(GRAMS)	273.0	240.0	257.0
Total particulate material..			
.....collected(grams)	0.0954	0.0474	0.0810
Gas meter coefficient.....	0.9929	0.9929	0.9929
Barometric pressure..(IN.HG)	29.26	29.26	29.26
Avg. orif.pres.drop..(IN.WC)	1.10	1.08	1.07
Avg. gas meter temp..(DEF-F)	90.5	84.2	78.4
Volume through gas meter....			
at meter conditions...(CF)	36.30	35.85	35.26
standard conditions.(DSCF)	33.89	33.85	33.65
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.188	.188	.188
Avg.stack gas temp ..(DEG-F)	164	161	158
Volumetric flow rate.....			
actual.....(ACFM)	58959	60166	59448
dry standard.....(DSCFM)	35023	37164	36184
Isokinetic variation.....(%)	105.2	99.0	101.1
Particulate concentration...			
actual.....(GR/ACF)	0.02579	0.01334	0.02260
dry standard.....(GR/DSCF)	0.04344	0.02161	0.03714
Particle mass rate...(LB/HR)	13.041	6.882	11.519

Test No. 1
Dryer RTO Outlet

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	08-27-96	08-27-96	08-27-96
Time run start/end.....(HRS)	1645/1750	1940/2046	2135/2339
Static pressure.....(IN.WC)	-0.51	-0.51	-0.51
Cross sectional area (SQ.FT)	22.34	22.34	22.34
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	214.0	247.0	245.0
desiccant.....(GRAMS)	13.0	12.0	10.0
total.....(GRAMS)	227.0	259.0	255.0
Total particulate material..			
.....collected(grams)	0.0177	0.0163	0.0126
Gas meter coefficient.....	0.9976	0.9976	0.9976
Barometric pressure..(IN.HG)	29.26	29.26	29.26
Avg. orif.pres.drop..(IN.WC)	1.19	1.12	1.09
Avg. gas meter temp..(DEF-F)	95.8	87.0	76.4
Volume through gas meter....			
at meter conditions...(CF)	38.92	37.45	36.55
standard conditions.(DSCF)	36.16	35.35	35.18
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.251	.251	.251
Avg.stack gas temp ..(DEG-F)	281	273	273
Volumetric flow rate.....			
actual.....(ACFM)	68601	66597	67050
dry standard.....(DSCFM)	36861	34827	35163
Isokinetic variation.....(%)	99.7	103.2	101.7
Particulate concentration...			
actual.....(GR/ACF)	0.00406	0.00372	0.00290
dry standard.....(GR/DSCF)	0.00755	0.00711	0.00553
Particle mass rate...(LB/HR)	2.386	2.124	1.666

Test No. 8
Press Vents

Results of Particulate Loading Determinations-----Method 5

	Run 1	Run 2	Run 3
Date of run	08-28-96	08-28-96	08-28-96
Time run start/end.....(HRS)	1215/1318	1450/1552	1615/1717
Static pressure.....(IN.WC)	-2.30	-2.30	-2.30
Cross sectional area (SQ.FT)	48.35	48.35	48.35
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	3.0	4.0	5.0
desiccant.....(GRAMS)	8.0	10.0	5.0
total.....(GRAMS)	11.0	14.0	10.0
Total particulate material..collected(grams)	0.0135	0.0194	0.0118
Gas meter coefficient.....	1.0007	1.0007	1.0007
Barometric pressure..(IN.HG)	29.31	29.31	29.31
Avg. orif.pres.drop..(IN.WC)	1.78	1.79	1.89
Avg. gas meter temp..(DEF-F)	84.1	93.4	101.2
Volume through gas meter....			
at meter conditions...(CF)	43.63	44.07	45.80
standard conditions.(DSCF)	41.67	41.39	42.42
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.180	.180	.180
Avg.stack gas temp ..(DEG-F)	108	109	112
Volumetric flow rate.....			
actual.....(ACFM)	214034	211526	218092
dry standard.....(DSCFM)	191539	188269	193848
Isokinetic variation.....(%)	99.3	100.3	99.9
Particulate concentration...			
actual.....(GR/ACF)	0.00447	0.00643	0.00381
dry standard.....(GR/DSCF)	0.00500	0.00723	0.00429
Particle mass rate...(LB/HR)	8.206	11.672	7.131

3.3 Results of Sulfur Dioxide Determinations

Test No. 2
Dryer RTO Outlet

Results of Sulfur Dioxide Determinations **Method 6C**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.8	25.7	25.5
Oxygen content (%V/V)	17.5	16.3	16.4
Volumetric flow rate (DSCFM)	36861	34827	35163
SO₂ concentration ppm,dry	< 1	< 1	< 1
SO₂ emission rate (LB/HR)	< 0.37	< 0.35	< 0.35

3.4 Results of Oxides of Nitrogen Determinations

Test No. 2
Dryer Primary Cyclone Outlet

Results of Oxides of Nitrogen Determinations-----**Method 7E**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	24.2	22.8	19.2
Oxygen content (%V/V)	16.1	16.6	16.5
Volumetric flow rate (DSCFM)	31359	31613	34409
NO_x concentration ppm,dry	39.0	19.8	25.5
NO_x emission rate (LB/HR)	8.8	4.5	6.3

Test No. 2
E-Tube Outlet

Results of Oxides of Nitrogen Determinations _____ **Method 7E**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	27.5	25.1	26.5
Oxygen content (%V/V)	16.5	16.9	16.8
Volumetric flow rate (DSCFM)	35023	37164	36184
NO_x concentration ppm,dry	13.2	14.1	17.7
NO_x emission rate (LB/HR)	3.3	3.7	4.6

Test No. 2
Dryer RTO Outlet

Results of Oxides of Nitrogen Determinations-----**Method 7E**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.8	25.7	25.5
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	36861	34824	35163
NO_x concentration ppm,dry	22.3	26.1	23.4
NO_x emission rate (LB/HR)	5.9	6.5	5.9

Test No. 9
Press Vents

Results of Oxides of Nitrogen Determinations **Method 7E**

	Run 1	Run 2	Run 3
Date of run	8-29-96	8-29-96	8-29-96
Time run start/end (HRS)	0900-1000	1036-1136	1211-1311
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	1.6	1.2	1.5
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	202257	205362	201740
NO_x concentration			
ppm,dry	0.8	1.6	1.4
NO_x emission rate (LB/HR)	1.2	2.2	2.0

3.5 Results of Opacity Observations

Test No. 1
 Dryer RTO Outlet

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	94.16
5	0.0223	5.42
10	0.0458	0.42
15	0.0706	0.00
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac 0.31	Avg OD 0.0014	Time average

Observer: Steve Kelker
 Cert. Date: 04-03-96
 Date of Observation: 08-27-96
 Time of Observation: 1640-1740

Test No. 1-1
Press Vent - West Stack

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	54.58
5	0.0223	42.50
10	0.0458	2.92
15	0.0706	0.00
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00

Avg Opac 2.42	Avg OD 0.0108	Time average
---------------	---------------	--------------

Observer: Mark Peterson
Cert. Date: 04-03-96
Date of Observation: 08-28-96
Time of Observation: 1450-1550

Test No. 1-2
Press Vent - East Stack

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	54.58
5	0.0223	42.92
10	0.0458	2.08
15	0.0706	0.42
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac 2.42	Avg OD 0.0108	Time average

Observer: Mark Peterson
Cert. Date: 04-03-96
Date of Observation: 08-28-96
Time of Observation: 1450-1550

3.6 Results of Carbon Monoxide Determinations

Test No. 2
Dryer Primary Cyclone Outlet

Results of Carbon Monoxide Determinations **Method 10**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	24.2	22.8	19.2
Oxygen content (%V/V)	16.1	16.6	16.5
Volumetric flow rate (DSCFM)	31359	31613	34409
CO concentration			
ppm,dry	873	409	422
CO emission rate (LB/HR)	119	56	63

Test No. 2
E-Tube Outlet

Results of Carbon Monoxide Determinations-----**Method10**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1645-1750	1940-2045	2135-2347
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	27.5	25.1	26.5
Oxygen content (%V/V)	16.5	16.9	16.8
Volumetric flow rate (DSCFM)	35023	37164	36184
CO concentration			
ppm,dry	770	356	412
CO emission rate (LB/HR)	118	58	65

Test No. 2
Dryer RTO Outlet

Results of Carbon Monoxide Determinations **Method 10**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.8	25.7	25.5
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	36861	34824	35163
CO concentration			
ppm,dry	77.8	53.2	29.9
CO emission rate (LB/HR)	12.5	8.1	4.6

Test No. 9
Press Vents

Results of Carbon Monoxide Determinations-----**Method10**

	Run 1	Run 2	Run 3
Date of run	8-29-96	8-29-96	8-29-96
Time run start/end (HRS)	0900-1000	1036-1136	1211-1311
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	1.6	1.2	1.5
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	202257	205362	201740
CO concentration			
ppm,dry	6.2	3.2	2.4
CO emission rate (LB/HR)	5.2	2.6	2.0

3.7 Results of Total Hydrocarbons Determinations

Test No. 2
Dryer Primary Cyclone Outlet

Results of TGNMO's Determinations **Method25A**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	24.2	22.8	19.2
Oxygen content (%V/V)	16.1	16.6	16.5
Volumetric flow rate (DSCFM)	31359	31613	34409
TGNMO's concentration			
ppmC,wet	321	276	280
TGNMO's emission rate (LBC/HR)	24.8	21.1	22.3

Test No. 2
E-Tube Outlet


Results of TGNMO's Determinations **Method25A**

	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1645-1750	1940-2045	2135-2347
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	27.5	25.1	26.5
Oxygen content (%V/V)	16.5	16.9	16.8
Volumetric flow rate (DSCFM)	35023	37164	36184
TGNMO's concentration			
ppmC,wet	245	148	131
TGNMO's emission rate (LBC/HR)	22.1	13.7	12.1

Test No. 2
Dryer RTO Outlet

Results of TGNMO's Determinations ----- **Method 25A**


	Run 1	Run 2	Run 3
Date of run	8-27-96	8-27-96	8-27-96
Time run start/end (HRS)	1646-1756	1951-2055	2136-2335
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	22.8	25.7	25.5
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	36861	34824	35163
TGNMO's concentration			
ppmC, wet	5.75	< 1	< 1
TGNMO's emission rate (LBC/HR)	0.51	< 0.09	< 0.09




Test No. 9
Press Vents

Results of TGNMO's Determinations **Method25A**

	Run 1	Run 2	Run 3
Date of run	8-29-96	8-29-96	8-29-96
Time run start/end (HRS)	0900-1000	1036-1136	1211-1311
Total sampling time (MIN)	60	60	60
Moisture content (%V/V)	1.6	1.2	1.5
Oxygen content (%V/V)	20.9	20.9	20.9
Volumetric flow rate (DSCFM)	202257	205362	201740
TGNMO's concentration			
ppmC,wet	1.9	10.4	3.4
TGNMO's emission rate (LBC/HR)	0.7	4.0	1.3



3.8 Results of Formaldehyde Determinations




Test No. 3
Dryer Primary Cyclone Exhaust

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	08-28-96	08-28-96	08-28-96
Time run start/end.....(HRS)	930/1132	1215/1332	1500/1618
Static pressure.....(IN.WC)	-11.60	-11.60	-11.60
Cross sectional area (SQ.FT)	9.62	9.62	9.62
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	295.0	315.0	324.0
desiccant.....(GRAMS)	15.0	19.0	24.0
total.....(GRAMS)	310.0	334.0	348.0
Formaldehyde in sample..(uG)	6600	6000	11000
Gas meter coefficient.....	0.9945	0.9945	0.9945
Barometric pressure..(IN.HG)	29.31	29.31	29.31
Avg. orif.pres.drop..(IN.WC)	1.38	1.39	1.40
Avg. gas meter temp..(DEF-F)	70.1	82.0	88.3
Volume through gas meter....			
at meter conditions...(CF)	48.74	49.59	48.89
standard conditions.(DSCF)	47.44	47.21	46.01
Total sampling time....(MIN)	72.00	72.00	72.00
Nozzle diameter.....(IN)	.190	.190	.190
Avg.stack gas temp ..(DEG-F)	256	257	258
Volumetric flow rate.....			
actual.....(ACFM)	59451	59709	58660
dry standard.....(DSCFM)	31880	31381	30239
Isokinetic variation.....(%)	101.1	102.2	103.3
CH2O concentration.....			
(GR/DSCF).....	0.0022	0.0020	0.0037
(MG/DSCM).....	4.93	4.51	8.48
(PPM-DRY).....	3.95	3.61	6.79
(PPM-WET).....	3.02	2.71	5.00
CH2O emission rate...(LB/HR)	0.58839	0.52912	0.95915

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value




Test No. 3
E-Tube Outlet

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	08-28-96	08-28-96	08-28-96
Time run start/end.....(HRS)	930/1115	1215/1317	1500/1604
Static pressure.....(IN.WC)	-3.50	-3.50	-3.50
Cross sectional area (SQ.FT)	12.57	12.57	12.57
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	341.0	345.0	378.0
desiccant.....(GRAMS)	12.0	28.0	21.0
total.....(GRAMS)	353.0	373.0	399.0
Formaldehyde in sample..(uG)	36000	34000	33000
Gas meter coefficient.....	0.9929	0.9929	0.9929
Barometric pressure..(IN.HG)	29.31	29.31	29.31
Avg. orif.pres.drop..(IN.WC)	2.60	2.48	2.34
Avg. gas meter temp..(DEF-F)	77.7	85.2	76.7
Volume through gas meter....			
at meter conditions...(CF)	54.97	53.93	52.25
standard conditions.(DSCF)	52.82	51.10	50.27
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.230	.230	.230
Avg.stack gas temp ..(DEG-F)	158	161	164
Volumetric flow rate.....			
actual.....(ACFM)	61007	59499	59001
dry standard.....(DSCFM)	38475	36529	35275
Isokinetic variation.....(%)	99.7	101.6	103.5
CH2O concentration.....			
(GR/DSCF).....	0.0106	0.0103	0.0102
(MG/DSCM).....	24.23	23.65	23.33
(PPM-DRY).....	19.41	18.94	18.68
(PPM-WET).....	14.76	14.09	13.60
CH2O emission rate...(LB/HR)	3.48917	3.23347	3.07931

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value




Test No. 3
Dryer RTO Outlet

Results of Formaldehyde Tests ----- EPA Method 0011

	Run 1	Run 2	Run 3
Date of run	08-28-96	08-28-96	08-28-96
Time run start/end.....(HRS)	930/1120	1215/1327	1500/1605
Static pressure.....(IN.WC)	-0.29	-0.29	-0.29
Cross sectional area (SQ.FT)	22.34	22.34	22.34
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	316.0	346.0	356.0
desiccant.....(GRAMS)	22.0	28.0	23.0
total.....(GRAMS)	338.0	374.0	379.0
Formaldehyde in sample..(uG)	1800	2400	2400
Gas meter coefficient.....	0.9976	0.9976	0.9976
Barometric pressure..(IN.HG)	29.31	29.31	29.31
Avg. orif.pres.drop..(IN.WC)	2.15	2.47	2.27
Avg. gas meter temp..(DEF-F)	77.6	95.4	100.0
Volume through gas meter....			
at meter conditions...(CF)	51.32	55.76	53.71
standard conditions.(DSCF)	49.50	52.10	49.75
Total sampling time....(MIN)	64.00	64.00	64.00
Nozzle diameter.....(IN)	.298	.298	.298
Avg.stack gas temp ..(DEG-F)	272	275	271
Volumetric flow rate.....			
actual.....(ACFM)	65988	70631	67822
dry standard.....(DSCFM)	35232	37131	35294
Isokinetic variation.....(%)	101.3	101.2	101.7
CH2O concentration.....			
(GR/DSCF).....	0.0006	0.0007	0.0007
(MG/DSCM).....	1.29	1.64	1.71
(PPM-DRY).....	1.03	1.31	1.37
(PPM-WET).....	0.78	0.98	1.01
CH2O emission rate...(LB/HR)	0.17028	0.22751	0.22637

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value




Test No. 7
Press Vents

Results of Formaldehyde Tests ----- EPA Method 0011


	Run 1	Run 2	Run 3
Date of run	08-27-96	08-27-96	08-27-96
Time run start/end.....(HRS)	1450/1616	1645/1809	1835/1959
Static pressure.....(IN.WC)	-2.40	-2.40	-2.40
Cross sectional area (SQ.FT)	48.35	48.35	48.35
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	-6.0	-3.0	-2.0
desiccant.....(GRAMS)	18.0	18.0	17.0
total.....(GRAMS)	12.0	15.0	15.0
Formaldehyde in sample..(uG)	8000	1900	4100
Gas meter coefficient.....	0.9945	0.9945	0.9945
Barometric pressure..(IN.HG)	29.26	29.26	29.26
Avg. orif.pres.drop..(IN.WC)	1.63	1.88	1.90
Avg. gas meter temp..(DEF-F)	96.8	97.4	93.0
Volume through gas meter....			
at meter conditions...(CF)	51.95	57.28	57.68
standard conditions.(DSCF)	48.09	53.00	53.80
Total sampling time....(MIN)	72.00	72.00	72.00
Nozzle diameter.....(IN)	.190	.190	.190
Avg.stack gas temp ..(DEG-F)	108	110	105
Volumetric flow rate.....			
actual.....(ACFM)	186515	202956	204472
dry standard.....(DSCFM)	166695	180352	183195
Isokinetic variation.....(%)	98.4	100.3	100.2
CH2O concentration.....			
(GR/DSCF).....	0.0026	0.0006	0.0012
(MG/DSCM).....	5.90	1.27	2.71
(PPM-DRY).....	4.73	1.02	2.17
(PPM-WET).....	4.67	1.01	2.14
CH2O emission rate...(LB/HR)	3.68125	0.85883	1.85467

CH2O = Formaldehyde

A trailing '<' symbol indicates that the true value is less than or equal to the reported value




3.9 Results of MDI Determinations



Test No. 5
Press Vents

Results of MDI Determinations.....Method 1,2 PP

	Run 1	Run 2	Run 3
Date of run	08-29-96	08-29-96	08-29-96
Time run start/end.....(HRS)	900/1002	1035/1136	1210/1311
Static pressure.....(IN.WC)	-2.37	-2.37	-2.37
Cross sectional area (SQ.FT)	48.35	48.35	48.35
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	-46.0	-52.0	-50.0
desiccant.....(GRAMS)	61.0	64.0	64.0
total.....(GRAMS)	15.0	12.0	14.0
MDI in sample.....(ug)	310	270	57
Gas meter coefficient.....	1.0007	1.0007	1.0007
Barometric pressure..(IN.HG)	29.29	29.29	29.29
Avg. orif.pres.drop..(IN.WC)	1.97	2.05	2.01
Avg. gas meter temp..(DEF-F)	83.9	94.0	96.5
Volume through gas meter....			
at meter conditions...(CF)	46.49	47.90	47.40
standard conditions.(DSCF)	44.41	44.93	44.26
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.180	.180	.180
Avg.stack gas temp ..(DEG-F)	100	101	106
Volumetric flow rate.....			
actual.....(ACFM)	223818	227182	225514
dry standard.....(DSCFM)	202257	205362	201740
Isokinetic variation.....(%)	100.2	99.8	100.1
MDI Concentration.....(ppm)	0.0237	0.0204	0.0044
MDI Emission Rate.....(LB/HR)	0.187	0.163	0.034



4 RESULTS OF FUEL ANALYSES



INTERPOLL LABORATORIES, INC.
Fuel Laboratory
(612) 786-6020

Date: 9/27/96
Client: LOUISIANA-PACIFIC, NEWBERRY, MI
Laboratory Log Number: 8312-01-0516
Sample Collected: 8/27/96
Sample Received: 9/16/96
Sample Identification: WOOD WASTE

Ultimate Analysis WT %


Parameter	Moisture & Ash Free	Moisture Free	As Received
Moisture, Total			2.02
Ash		1.42	1.40
Carbon	52.92	52.16	51.11
Hydrogen	6.66	6.57	6.43
Nitrogen	0.26	0.26	0.25
Oxygen (calculated)	40.15	39.58	38.78
Sulfur	0.01	0.01	0.01
Heating Value, BTU/LB	8578	8456	8285

Respectfully submitted,




David J. Schneider, Manager
Chemistry Department

10118



APPENDIX A


RESULTS OF VOLUMETRIC FLOW RATE DETERMINATIONS



Test No. 1
Dryer Primary Cyclone Exhaust


Results of Volumetric Flow Rate Determination-----Method 2


Date of Determination.....	08-27-96
Time of Determination.....(HRS)	810
Barometric pressure.....(IN.HG)	29.26
Pitot tube coefficient.....	.84
Number of sampling ports.....	2
Total number of points.....	12
Shape of duct.....	Round
Stack diameter.....(IN)	42
Duct area.....(SQ.FT)	9.62
Direction of flow.....	UP
Static pressure.....(IN.WC)	-11.6
Avg. gas temp.....(DEG-F)	254
Moisture content.....(% V/V)	24.22
Avg. linear velocity.....(FT/SEC)	97.6
Gas density.....(LB/ACF)	.04848
Molecular weight.....(LB/LBMOLE)	29.33
Mass flow of gas.....(LB/HR)	163915
Volumetric flow rate.....	
actual.....(ACFM)	56357
dry standard.....(DSCFM)	29983




APPENDIX B

LOCATION OF TEST PORTS







A-3 plan view of dryer control equipment




A-4 elevation of dryer control equipment



A-5 detail of port location
 Stack P002 RTO stack site A




A-6 plan view of press vent and stack



PLAN VIEW


Site D - Press vents
 2 vents treated as 1 source
 estimated stack conditions
 acfm(each) = 30,000-40,000
 temp deg. f = 80-140
 size = 58" square



PRESS & UNLOADER VENTS

A-7 detail of port location
 Stack P006 Press Vents site D


N.T.S. FIELD VERIFIED 1-7-92




A-8 plan view of Thermal Oil Heater and control equipment

APPENDIX C

FIELD DATA SHEETS






INTERPOL LABORATORIES, INC.
 (612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Newberry, MI
 Source Dryer Primary Cyclone / Exhaust
 Test 1 Run 2 Date 8-27-96
 Stack Dimen. 42 IN.
 Dry Bulb 254 °F Wet bulb 126 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.26 IN.HG
 Static Pressure -11.6 IN.WC
 Operators M. Kochlar + M. Petersen
 Pitot No. 7745 C_p .04



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
Port Length: *			9.0 IN.	Time Start:	0810 HRS
A-1	.044	1.05	10.05	1.53	
2	.146	6.13	15.13	1.65	
3	.296	12.43	21.43	2.10	
4	.704	29.57	38.57	2.18	
5	.854	35.87	44.87	2.20	↑
6	.956	40.15	49.15	2.30	↓
B-1				2.43	254
2				1.39	
3				2.25	↓
4				2.10	
5				1.85	
6				1.65	

Temp. Meas. Device & S/N: PDT-45 ITC Time End: 0817 HRS

R or nothing = reg. manometer; S = expanded; E = electronic

* includes ventrick portclamp

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newberry, MI Date 8-27-96 Test 1 Run 1
 Source Dryer Primary Cyclone/Exhaust No. of traverse points 12
 Method 5 Filter holder: Glass Filter type: 1" G.F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

0315

Recovery solvent(s)

Acetone _____
 Other(s) MeCl₂

VOLD
RUN

No. of probe wash bottles:

1

Sample recovered by:

M. Koehler + M. Petersen

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	636	501	135
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1367	1354	13
Total			148

Integrated Gas Sampling Data:

Bag Pump No. 313 Box No. 23 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1115 (HRS) Time end: 1143 (HRS)
 Sampling rate: 400 cc/min Operator: M. Koehler

S/N of O₂ Analyzer used to monitor train outlet: 11

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job L.P. Newberry, #11
Source Dye Primary Cyclone / Exhaust
Date 8-8-27 Test 1 Run 1

Operators M. K. G. K. T. M. P. B. G. S. G. A.
Meter Box No. 10-AL-193 in. WC
Gas meter Coef. 1.0000

Nozzle No. 1-3
Nozzle Dia. .136 in.
Bar. Press. 29.26 in. Hg

Pilot No. 271-5
C_p 0.91
H₂O 12 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Stack	Gas/In	Gas/Out	Oxygen (% v/v)
							Probe	Oven	Imp.	Gas/In				
A-6	1115	501.90	2.23	1.71	5.57	10	247	263	49	77	77	77	16.3	
	5	505.35	2.25	1.72	9.26	11	241	257	46	79	73	73	16.1	
	10	509.06	2.25	1.73	2.95	11	237	261	46	81	72	72	15.9	
	15	512.94	1.81	1.39	6.27	10	245	260	47	84	73	73	16.3	
	20	516.10	1.90	1.45	9.66	10.5	253	258	47	85	73	73	16.5	
	15	519.48	1.35	1.04	2.53	9	247	255	46	87	74	74	16.2	
	30	522.60	2.20	1.70	6.21	13	245	251	48	86	73	73	15.8	
B-6	35	526.15												
	40	(1143)												
	45													
	50													
	55													
	60													

RUN ABORETTED

VD

194 11111 ACK 111111111111111111

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P./Newberry, MI Date 8-22-76 Test 1 Run 2
 Source Dryer Primary Cyclone/Exhaust No. of traverse points 12
 Method 5 Filter holder: Glass Filter type: 4"61F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

0333

Recovery solvent(s)

Acetone
 Other(s) MeCl

No. of probe wash bottles:

1
M. Kaehler + M. Peterson

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	721	502	219
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1534	1520	14
Total			233

Integrated Gas Sampling Data:

Bag Pump No. 31B Box No. 23 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1415 (HRS) Time end: 1519 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kaehler

S/N of O₂ Analyzer used to monitor train outlet: 11

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newberry, MI Date 8-27-96 Test 1 Run 3
 Source Dryer Primary Cyclone/Exhaust No. of traverse points 12
 Method 5 Filter holder: Glass Filter type: 4" 61F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

0340

Recovery solvent(s)

Acetone _____
 Other(s) Mecl

No. of probe wash bottles:

1

Sample recovered by:

M. Kachler + M. Petersen

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	715	474	241
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1300	1367	13
Total			254

Integrated Gas Sampling Data:

Bag Pump No. 31 B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1645
 Sampling rate: 400

Box No. 23 Bag No. 2
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 1751 (HRS)
 cc/min Operator: M. Kachler

S/N of O₂ Analyzer used to monitor train outlet: 11

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job A.P. / Newbury, MI Date 8-27-96 Test 2 Run 4
 Source Dryer Primary Cyclone / Exhaust No. of traverse points 12
 Method 5 Filter holder: Glass Filter type: 4" G/F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 14 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

8363

Acetone

Other(s) MeCl₂

No. of probe wash bottles:

1

Sample recovered by:

M. Kachler + M. Peterson

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	709	494	215
Impinger No. 2			
Impinger No. 3			
Condenser			1
Desiccant	1550	1534	16
Total			231

Integrated Gas Sampling Data:

Bag Pump No. 31 B Box No. 23 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1940 (HRS) Time end: 2042 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kachler

S/N of O₂ Analyzer used to monitor train outlet: 11

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newbury, MI Date 8-27-96 Test 2 Run 5
 Source Dryer Primary Cyclone / Exhaust No. of traverse points 12
 Method 5 Filter holder: Glass Filter type: 4" G/F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.62 cfm at 15 IN. HG (vac)

Particulate Catch Data:

No. of filters used: 0399 Recovery solvent(s): Acetone
MeCl₂

No. of probe wash bottles: 1
 Sample recovered by: M. Kachler + M. Peterson

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	686	501	185
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1342	1300	12
Total			197

Integrated Gas Sampling Data:


Bag Pump No. 31B Box No. 5 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 2135 (HRS) Time end: 2237 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kachler

S/N of O₂ Analyzer used to monitor train outlet: 11

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP / new bunk
 Source DRYER ETUBE OUTLET
 Test 1 Run 0 Date 8-27-96
 Stack Dimen. 4.8 IN.
 Dry Bulb 150 °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.26 IN.HG
 Static Pressure -3.5 IN.WC
 Operators S.B. / D.H.
 Pitot No. V27-5 Cp -84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas (°F)
		Port Length:	IN.	Time Start:	HRS
1	.044	2.11	8.11	69 1.50	
2	.146	7.01	13.01	75 1.40	
3	.296	14.21	20.21	86 1.55	
4	.704	33.79	39.99	78 1.75	
5	.854	40.99	46.99	83 1.80	
6	.956	45.89	51 45.89	80 1.50	
1					
2					
3					
4					
5					
6					
Temp. Meas. Device & S/N: <u>PDT # 2</u>				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP NEWBERRY
 Source DRYER TUBE OUTLET
 Method 5/17 Filter holder: GLASS

Date 8-27-96 Test 1 Run 1
 No. of traverse points 12
 Filter type: 4" GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8273

Recovery solvent(s)

Acetone _____
 Other(s) MCTD

VOID RUN

No. of probe wash bottles:

1
55

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant			
Total			

Integrated Gas Sampling Data:

NO BAG RUN 1

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-GASTACKWPAFORMSS-0046RR

EPA Method 5 .ield Data Sheet

9-3

Pilot No. U27-5

Nozzle No. 1.08
Nozzle Dia. 29.26 in. Hg
Bar. Press. 29.26 in. Hg

Stack In. 0.4
Stack Out. 2.4

Operators S.D./O.H.

Meter Box No. 14 ΔH@ 1.82 in.WC
Gas meter Coeff. .9929

Job LP/Newberry

Source 8-18-B TUBS OUTLET

Date 8-27-96 Test 1 Run 1

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)					Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.	Gas/In		Gas/Out
1	(11:15)	585.75	1.40	1.03	8.62	2	150	226	230	35	73	72	16.7
2	5	586.60	1.40	1.01	1.48	2	160	228	237	35	75	72	16.9
3	10	591.51	1.70	1.23	4.64	2	161	231	245	37	78	73	16.7
4	15	594.74	1.80	1.30	7.89	2	164	248	239	36	80	73	16.7
5	20	598.00	1.70	1.23	1.06	2	163	245	242	37	81	74	17.2
6	25	601.14	1.65	1.20	4.19	2	164	242	237	37	82	74	17.0
7	30	604.26	1.60	1.17	7.28	2	161	239	240	38	83	74	17.0
8	35	605.97											
9	40												
10	45												
11	50												
12	55												
13	60												
Ave. =													
V _m = 20.22													

11:50

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP

Date 8-27-96 Test 1 Run 2

Source DMER TUBE OUTLET

No. of traverse points 12

Method 5/202 Filter holder: GLASS

Filter type: 4" GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

7975

Recovery solvent(s)

Acetone
 Other(s) MCM

VOLD
RUN

No. of probe wash bottles:

1
55

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	711	495	216
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1515	1510	5
Total			221

Integrated Gas Sampling Data:

Bag Pump No. 56
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 13 55
 Sampling rate: 400

Box No. 17 Bag No. 1
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 15 00 (HRS)
 cc/min Operator: 55

S/N of O₂ Analyzer used to monitor train outlet: 9

052394-G:\STACK\WP\FORMS\S-00462.R

(614) 46-6020

EPA Method 5 - Field Data Sheet

Job LP newberry Date 8-27-76 Test 1 Run 2

Source PMEN ETUBE outst

Operators SS/PH Meter Box No. 14 ΔH @ 1.02 in. WC Gasmeter Coeff. 0.929

Nozzle No. 9-3 Bar. Press. 29.26 in. Hg

Pilot No. V27-5 C_p 0.64 H_2O 2.4 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)			Gas/in	Gas/Out	Oxygen (% v/v)
							Probe	Oven	Imp.			
1	(1555)	606.13	1.55	1.14	9.17	2.5	227	40	80	78	17.2	
2	5	609.18	1.45	1.06	2.11	2	230	40	86	78	17.6	
3	10	612.14	1.80	1.35	5.44	3	232	41	87	79	17.8	
4	15	615.40	1.75	1.31	8.73	3	237	40	89	79	17.9	
5	20	618.70	1.95	1.46	2.20	3.5	235	41	90	79	17.9	
6	25	622.023	1.35	1.00	5.08	3	241	42	90	80	17.9	
1	30	625.13	1.40	1.04	8.02	3	245	43	90	81	17.7	
2	35	628.07	1.50	1.11	1.05	3	243	43	90	81	17.8	
3	40	631.000	1.45	1.07	4.03	3	244	44	91	82	17.6	
4	45	634.001	1.55	1.15	7.11	3	241	44	92	82	17.7	
5	50	637.008	1.70	1.26	0.34	3.5	250	44	92	82	17.7	
6	55	640.30	1.80	1.33	3.66	3.5	252	45	92	83	17.6	
6	60	643.61										
	(1500)											
	$t = 60$	$V_m = 37.46$		$1.19 \Delta H$						89.5 AVG.		

Handwritten signature/initials

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP NEWBERRY Date 8-27-94 Test 1 Run 3
 Source DUMPER TUBE ATWT No. of traverse points 12
 Method 5/20 Filter holder: GLASS Filter type: 4" GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8558

Recovery solvent(s)

Acetone
 Other(s) METH

No. of probe wash bottles:

1
33

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	753	495	263
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1539	1529	10
Total			273

Integrated Gas Sampling Data:

Bag Pump No. 56 Box No. 19 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: ~~1355~~ 1645 (HRS) Time end: ~~1505~~ (HRS) 1750
 Sampling rate: 400 cc/min Operator: 50

S/N of O₂ Analyzer used to monitor train outlet: 8

052394-GASTACKIWP\FORMS\S-0046RR

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP new sample Date 8-27-96 Test 1 Run 4

Source DRYER EXHAUST OUTLET No. of traverse points 12

Method 5/20 Filter holder: GLASS Filter type: 4" GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8429

Recovery solvent(s)

Acetone

Other(s) MTH

No. of probe wash bottles:

1

Sample recovered by:

SS

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	724	491	233
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1463	1456	7
Total			240

Integrated Gas Sampling Data:

Bag Pump No. 56

Box No. 19 Bag No. 3

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: 0

cc/min at 15 IN.HG

Time start: 1940

(HRS) Time end: 2055 (HRS)

Sampling rate: 400

cc/min Operator: SS

S/N of O₂ Analyzer used to monitor train outlet: 8

(612) 5-6020

EPA Method 5 Field Data Sheet

Pilot No. U27-5
 C_p .84
 H₂O 26 %

Nozzle No. 9-3
 Nozzle Dia. .100 in.
 Bar. Press. 29.26 in.Hg

Operators S.B. PH
 Meter Box No. 14 AH 100 in.WC
 Gasmer Coeff. 1.029

Job UP NEW BURNING
 Source RYAN B TUBS OUTLOT
 Date 027-96 Test 1 Run H

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/h
1	(1440)	684.64	1.65	1.16	7.77	2	162	245	253	39	82	17.6
2	5	687.60	1.55	1.09	6.77	2	160	247	252	39	83	17.4
3	10	690.68	1.65	1.16	3.87	2	161	244	254	39	83	17.4
4	15	693.69	1.60	1.13	6.92	2	161	243	253	40	82	17.5
5	20	696.88	1.35	.95	9.73	2	161	240	251	40	82	17.6
6	25	699.66	1.20	.85	2.38	2	161	250	253	41	82	17.5
1	30	702.28	1.80	1.27	5.62	3	160	247	255	41	82	17.4
2	35	705.61	1.50	1.06	8.58	2.5	162	245	250	40	82	17.7
3	40	708.60	1.30	.92	1.34	2	161	249	251	41	82	17.9
4	45	711.38	1.60	1.13	4.40	3	161	252	254	42	82	17.7
5	50	714.40	1.70	1.20	7.55	3	161	248	257	42	82	17.8
6	55	717.54	1.45	1.07	0.47	3	161	249	257	42	82	17.7
6	60	720.49										
(2045)												
		V _m - 35.45										
		60										
		0 -										
		1.06	ΔH -									
											AVG. - 84.2	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP newberry Date 8-27-94 Test 1 Run 5
 Source DRYER BTUBE OUTLET No. of traverse points 12
 Method 5/202 Filter holder: GLASS Filter type: 4" GLASS

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8421

Recovery solvent(s)

Acetone _____
 Other(s) MECA

No. of probe wash bottles:

1
SD

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	720	487	241
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1496	1480	16
Total			257

Integrated Gas Sampling Data:

Bag Pump No. 86 Box No. N/A Bag No. 1
 Bag Material: 3-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 0135 400 (HRS) Time end: 23:47 (HRS)
 Sampling rate: 400 cc/min Operator: SD

S/N of O₂ Analyzer used to monitor train outlet: 8

612) 16-6020

EPA Method 5 Field Data Sheet

Job LP New Burny Operator S-B / D-H Nozzle No. 9-3 Pilot No. V27-5
 Source DYER ENGINE OUTF Meter Box No. 14 ΔH @ 1.82 in. WC in. .188 C_p .64
 Date 8-27-96 Test 1 Run 5 Gasmeter Coeff. 9789 Bar. Press. 29.26 in. Hg in. H₂O 25 %


Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/In
1	(2135) 5	(721.95)	1.30	.94	4.73	2	157	243	237	79	79	17.6
2	10	727.40	1.40	1.01	7.61	2	157	240	246	79	78	17.5
3	15	730.40	1.45	1.04	0.53	2	158	252	250	80	78	17.6
4	20	733.50	1.70	1.23	3.69	3	157	250	247	81	77	17.7
5	25	736.55	1.60	1.15	6.76	3	157	257	244	81	77	17.6
6	30	739.29	1.15	.83	9.37	2	157	251	246	82	77	17.7
1	35	742.20	1.45	1.04	2.29	3	158	255	247	82	77	17.7
2	40	745.27	1.60	1.16	5.37	3	155	250	251	80	78	17.3
3	45	746.39	1.75	1.26	6.58	3	157	253	248	78	75	17.5
4	50	751.34	1.50	1.07	1.54	3	159	256	250	80	74	17.6
5	55	754.45	1.70	1.21	4.68	3	162	252	247	82	75	17.3
6	60	757.21	1.30	.93	7.44	3	161	252	249	83	75	17.4
(2317)												
	60	V _m - 35.26		1.07 ΔH -						AVG. -	78.4	

~20
 2245
 2250
 2215
 2215

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job LP/Newberry
 Source Dryer RTO Stack
 Test 1 Run Date 8-27-96
 Stack Dimen. 64 IN.
 Dry Bulb 265 °F Wet bulb 200 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.26 IN.HG
 Static Pressure -.51 IN.WC
 Operators Scott Fjelstad & Steve Kalken
 Pitot No. V31-6 C_p 0.84



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>6.5</u>	IN.	Time Start:	HRS
A - 1	.032	2.05	8.55	.39	
2	.105	6.22	13.22	.53	
3	.194	12.42	18.92	.53	265
4	.323	20.67	27.17	.54	
5	.677	43.33	49.83	.62	
6	.806	51.58	58.08	.63	
7	.895	57.28	63.78	.65	
8	.968	61.95	68.45	.55	265
B - 1					
2					
3					
4					
5					
6					
7					
Temp. Meas. Device & S/N: <u>PDT-#32</u>				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Newsberry Date 8-27-96 Test _____ Run 1
 Source Dryer RTG Stack No. of traverse points 16
 Method 5 Filter holder: 6/120 Filter type: 4" 6F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.00 cfm at 8 IN. HG (vac)

PZTOTS @ 3 IN W.C.

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

8615

Acetone _____
 Other(s) Meth (Imp Rinse)

VOLD RUN

No. of probe wash bottles:

1

Sample recovered by:

SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	632	507	125
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant			
	1527	1519	8
Total			133

Integrated Gas Sampling Data:

Bag Pump No. TR A
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.00
 Time start: 1116
 Sampling rate: 400

Box No. 120 Bag No. 1
 Size: 44 L
 cc/min at 23 IN.HG
 (HRS) Time end: 1146 (HRS)
 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 5

EPA Method 5 Field Data Sheet

Job LP/Number 8-27-94 Test Run 1 Operators SF/sks Meter Box No. 7 $\Delta H @ 1.95$ in.WC Gasmeter Coeff. .976
 Source Dryer RTD stack Nozzle No. 9-4 Pilot No. V31-L
 Date 8-27-94 Bar. Press. 28.26 in.Hg H₂O 2.3 in. Hg C_p 0.84
 Traverse Point No. 8 Nozzle Dia. .257 in. O₂ 16.7 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (ft ³)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (ft ³)	VAC. (in.Hg)	Temperatures (°F)				Gas/Out	Oxygen (% v/v)
							Stack	Probe	Oven	Imp.		
A-8	(1115)	672.91	.56	1.22	5.33	4	276	241	249	40	66	16.7
	4	675.33	.60	1.26	7.78	4	278	245	250	40	67	16.6
	8	677.74	.70	1.48	0.42	5	278	248	252	42	68	16.4
	12	680.40	.65	1.38	2.99	4.5	278	243	250	42	70	16.4
	16	682.97	.60	1.29	5.47	4	276	244	251	44	80	16.8
	20	685.44	.62	1.33	8.00	4	278	244	247	46	82	16.8
	24	687.98	.55	1.18	0.39	4	278	245	248	45	84	16.5
	28	690.39	.45	0.97	2.55	3	278	248	249	47	85	16.4
	32	692.58										
B-8	36											
	40											
	44											
	48											
	52											
	56											
	60											
	64											
	(1147)											
	0-64	V _m = 18.67		1.26 ΔH =							AVG. = 73.5	

(1147)

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Newberry Date 8-27-96 Test 1 Run 2
 Source Dryer Rto Stack No. of traverse points 16
 Method 5 Filter holder: Glass Filter type: 4" 6P

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.00 cfm at 8 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

8616

Recovery solvent(s)

Acetone
 Other(s) MeCl₂

VOLD
RUN

No. of probe wash bottles:

1

Sample recovered by:

SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	731	507	224
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1456	1443	13
Total			237

Integrated Gas Sampling Data:

Bag Pump No. TR A Box No. 12 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0.00 cc/min at 23 IN.HG
 Time start: 1416 (HRS) Time end: 1520 (HRS)
 Sampling rate: 400 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 5

(612) 786-6020

EPA Method 5 Field Data Sheet

Job LP/Number 9-4 Pilot No. 021-6
 Source Dryer RTA stacks Nozzle No. 251 C_p 0.84
 Date 8-27-76 Test 1 Run 2 Bar. Press. 29.46 in.Hg H₂O 24 %
 Operators SF/sk Nozzle Dia. 2.51 in. Gas/In 80
 Meter Box No. 7 AIH@ 1.95 in.WC Oven 251 Imp. 43 Gas/Out 80
 Gasmeter Coeff. .9976 VAC. (in.Hg) Stack 276 Probe 249 Temperatures (°F) 251 O₂ (% v/v) 17.2

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
B - 8	4	693.10	.45	.94	5.22	3	276	249	251	43	80	80	17.2
7	8	695.23	.43	.91	7.32	3	279	247	253	44	85	80	16.7
6	12	697.37	.36	.76	9.25	3	279	243	250	46	88	84	16.9
5	16	699.23	.41	.88	1.33	3	278	245	251	47	90	85	17.0
4	20	701.36	.71	1.53	4.07	5	275	246	248	47	93	86	17.2
3	24	704.07	.75	1.62	6.89	5	276	246	249	48	95	86	17.1
2	28	706.97	.73	1.58	9.69	4	276	250	252	49	96	87	17.5
1	32	712.25	.64	1.39	2.81	4	274	251	250	51	97	88	17.1
A - 8	36	714.94	.65	1.42	4.96	4	274	246	249	43	98	90	17.2
7	40	717.63	.68	1.48	7.67	4.5	276	248	247	43	100	91	17.1
6	44	720.38	.68	1.48	0.39	4.5	278	250	248	45	102	92	16.8
5	48	723.20	.72	1.57	3.19	5	278	251	248	45	103	92	16.6
4	52	725.91	.69	1.50	5.93	4.5	281	253	252	46	104	93	16.5
3	56	728.51	.62	1.35	8.53	4	281	254	253	47	104	94	16.8
2	60	731.14	.64	1.40	1.17	4.5	282	255	252	47	104	94	16.8
1	64	733.57	.51	1.11	7.54	4	282	253	250	48	107	96	16.5
		(1521)											
		V _m - 40.47											
		0-64											
		1.31											
		AFT -											
		92.6											
		AVG. -											

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Newberry Date 8-27-96 Test 1 Run 2/1
 Source Diner RTO Stack No. of traverse points 16
 Method 5 Filter holder: glass Filter type: 4" GF

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.0 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: 8619 Recovery solvent(s) acetone
 other(s) Mecl₂ (Imp Rmn)

No. of probe wash bottles: 1
 Sample recovered by: SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	<u>410</u>	<u>496</u>	<u>214</u>
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	<u>1540</u>	<u>1527</u>	<u>13</u>
Total			<u>227</u>

Integrated Gas Sampling Data:

Bag Pump No. TR A Box No. 12 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0.00 cc/min at 23 IN.HG
 Time start: 1645 (HRS) Time end: 1750 (HRS)
 Sampling rate: 400 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 5

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Newberry Date 8-27-96 Test 1 Run AV
 Source Dryer Pto Stack No. of traverse points 16
 Method 5 Filter holder: 6655 Filter type: 4" 6F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.0 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

8621

Acetone
 Other(s) MeCl₂ (Imp Reverse)

No. of probe wash bottles:

1

Sample recovered by:

SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	^{SF} 737	486	249
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1468	1456	12
Total			259

Integrated Gas Sampling Data:

Bag Pump No. TR A Box No. 12 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0.00 cc/min at 23 IN.HG
 Time start: 1941 (HRS) Time end: 2045 (HRS)
 Sampling rate: 400 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 5

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP/Newsbury Date 7-27-96 Test 1 Run 3
 Source Dryer RTO Stack No. of traverse points 16
 Method 5 Filter holder: Glass Filter type: 4" 6F

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.0 cfm at 8 IN. HG (vac)

Particulate Catch Data:

No. of filters used: 8622 Recovery solvent(s) Acetone
Other(s) MeCl₂ (Imp. Rinse)

No. of probe wash bottles: 1
 Sample recovered by: SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	745	500	245
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1550	1540	10
Total			255

Integrated Gas Sampling Data:

Bag Pump No. TRA Box No. 25 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0.00 cc/min at 23 IN.HG
 Time start: 2:36 (HRS) Time end: _____ (HRS)
 Sampling rate: 400 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 5

EPA Method 5 Field Data Sheet

Job CO/Newbury Operators SF/SK Meter Box No. 7 $\Delta H @$ 1.95 in. WC Gasmeter Coeff. .9976
 Source Orge Refu Stack Nozzle No. 9-7 Nozzle Dia. .257 in. Pitot No. 031-1
 Date 8-27-96 Test 1 Run 8 Bar. Press. 29.26 in. Hg C_p 2.4 H_2O 2.4 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)												
							Stack	Probe	Oven	Insp.		Gas/In	Gas/Out										
	(2.135)	810.40																					
A-8	4	812.74	.50	1.08	2.70	4		274	237	242	41	73	73	73	73	16.9							
7	8	815.16	.58	1.22	5.11	4		275	239	243	41	76	74	74	74	16.8							
6	12	817.68	.63	1.33	7.63	4		276	240	245	42	80	74	74	74	16.8							
5	14	820.14	.60	1.27	0.11	4		274	241	244	42	83	76	76	76	17.1							
4	20	822.66	.63	1.34	2.65	4		274	243	245	43	84	77	77	77	17.0							
3	24	825.03	.52	1.11	4.97	4		274	243	248	45	86	76	76	76	17.0							
2	28	827.27	.48	1.03	7.21	4		271	244	245	46	86	77	77	77	17.0							
1	32	829.34	.43	.92	9.32	4		274	243	246	47	86	77	77	77	17.2							
B-8	36	831.42	.42	.90	1.41	3		274	240	243	48	86	77	77	77	17.2							
7	40	833.43	.38	.81	3.40	3		273	238	241	47	71	70	70	70	16.6							
6	44	835.35	.36	.76	5.31	3		264	238	240	45	70	68	68	68	16.6							
5	48	837.28	.37	.77	7.23	3		273	237	240	44	73	69	69	69	16.4							
4	52	839.62	.58	1.22	9.64	4		270	239	242	44	75	70	70	70	16.2							
3	56	842.10	.58	1.22	2.06	4		273	240	245	43	79	71	71	71	16.0							
2	60	844.43	.58	1.22	4.48	4		274	242	245	45	80	71	71	71	16.3							
1	64	846.95	.41	1.29	6.97	4		273	241	244	46	82	73	73	73	16.2							
	(2.339)																						
	0-64	$V_m = 36.55$		1.09 $\Delta H =$																			

CO/NEWBURY
 8-27-96
 1
 8
 333


INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

b
 Source L.P. Newberry
 Test Dryer Primary Cyclone Exhaust
 Run 3 Date 8-28-96
 Stack Dimen. 42 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 29.31 IN.HG
 Static Pressure -11.6 IN.WC
 Operators E. Jurek & J. Lorenz
 Pitot No. 27V-4 C_p .840



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	IN.	Time Start: HRS	
A 1	.046	1.85	10.85		
2	.146	6.13	15.13		
3	.296	12.43	21.43		
4	.704	29.57	38.57		
5	.854	35.87	44.87		
6	.956	40.14	49.15		
Temp. Meas. Device & S/N: <u>PDT 42</u>				Time End: HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\IS-392.1

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Newberry Date 8-28-96 Test 3 Run 1

Source Dryer Primary Cyclone/Exhaust No. of traverse points 12

Method 001 Filter holder: - Filter type: -

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 12 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 Other(s) MeCl₂ (Imp Rinsl + P.W) ~~Added~~
to Top Catch

No. of probe wash bottles: _____

Sample recovered by: _____

1
ES SF J.L

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	850	555	295
Impinger No. 3			
Condenser			
Desiccant	1485	1470	15
Total			310

Integrated Gas Sampling Data:

Bag Pump No. 29B
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 0930
 Sampling rate: 400

Box No. 16 Bag No. 1
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 1137 (HRS)
 cc/min Operator: ES

S/N of O₂ Analyzer used to monitor train outlet: 29B

EPA Method 5 Field Data Sheet

Job Source: C.P. Newberry Date: 8-28-96 Test: 3 Run: 1
 Operator: DL Meter Box No.: 4 Altitude: 175 in. WC Gasmeter Coeff.: .9945
 Nozzle No.: Glass Nozzle Dia.: .190 in. Bar. Press.: 29.31 in. Hg
 Pitot No.: 27V-5 C_p: .840 H₂O: 23 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)								
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out						
	(0930)	(117.64)																	
B	3	119.90	2.35	1.51	9.78	9	253	236	-	45	62	62	17.1						
	6	122.04	2.65	1.64	1.98	9	253	242	-	46	65	63	17.1						
S	9	124.26	2.95	1.83	4.30	10	255	256	-	46	67	63	17.3						
	12	126.52	2.95	1.83	6.63	10	255	256	-	46	68	63	17.1						
4	15	128.68	2.3	1.42	8.69	10	259	256	-	46	69	64	17.2						
	18	130.76	2.25	1.40	0.73	10	258	254	-	49	70	65	17.1						
3	21	132.78	2.2	1.38	2.75	10	255	254	-	49	71	65	17.0						
	24	134.79	2.2	1.38	4.78	9.5	255	260	-	51	72	66	17.1						
2	27	136.77	1.95	1.22	6.69	9	257	260	-	51	72	66	16.5						
	30	138.74	2.1	1.32	8.67	9	251	257	-	50	67	66	17.0						
1	33	140.55	1.75	1.09	0.47	9	259	257	-	50	68	66	12.5						
	36	142.46	1.75	1.09	2.27	9	257	256	-	45	70	67	17.3						
A	39	144.62	2.5	1.56	4.43	10	256	256	-	45	72	68	17.1						
	42	146.71	2.5	1.57	6.60	10	257	256	-	44	72	68	17.2						
S	45	148.78	2.40	1.51	8.72	11	256	250	-	44	74	69	17.2						
	48	150.88	2.4	1.51	0.85	11	256	256	-	46	75	70	17.4						
4	50	152.95	2.25	1.41	2.91	11	258	246	-	46	76	70	17.4						
	54	155.05	2.3	1.45	5.00	11	256	256	-	47	77	70	17.3						
3	57	157.07	2.25	1.42	7.07	11	256	249	-	47	78	71	17.4						
	60	159.13	2.2	1.39	9.12	11	255	256	-	45	78	72	17.3						
2	63	161.15	1.9	1.20	1.02	9.5	256	256	-	45	78	72	17.3						
	66	163.11	1.9	1.20	2.93	9	256	260	-	49	79	72	17.2						
1	69	164.72	1.35	.85	4.54	6.5	256	260	-	49	80	73	17.3						
	72	166.38	1.35	.86	6.15	6.5	257				81	73	17.3						
	(1132)																		
	0-72	V _{in} = 48.74		ΔFT = 1.58															AVG. = 70.1

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Newberry Date 8-28-96 Test 3 Run 2

Source Dryer Primary Cyclone/Exhaust No. of traverse points 12

Method CO11 Filter holder: — Filter type: —

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 0.02 cfm at 13 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____

other(s) mecl2 P.V. + Imp Rmsr

No. of probe wash bottles: _____

Sample recovered by: _____

1
ES SF JL

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	867	552	315
Impinger No. 3			
Condenser			
Desiccant	1439	1420	19
Total			334

Integrated Gas Sampling Data:

Bag Pump No. 29B

Bag Material: 5-layer Aluminized Tedlar

Pretest leak check: 0

Time start: 1215

Sampling rate: 900

Box No. 16 Bag No. 2

Size: 44 L

cc/min at 15 IN.HG

(HRS) Time end: 1332 (HRS)

cc/min Operator: ET

S/N of O₂ Analyzer used to monitor train outlet: 29B

052394-C:\STACK\WP\FORMS\S-0046RR

EPA Method 5 Field Data Sheet

Job L.P. Newberry Operators ES JC Pilot No. 270-5
 Source Dryer Primary Cyclones Meter Box No. 4 ΔH @ 1.75 in. WC Nozzle No. 61-55
 Date 9-28-96 Test 3 Run 2 Gasmeter Coeff. 0.9945 Nozzle Dia. .190 in. Gas/In 74
 Bar. Press. 21.3 in. Hg H₂O 870 % O₂ 23.5

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)							
							Stack	Probe	Oven	Inp.		Gas/In	Gas/Out					
	(1215)	(167.81)																
B 6	3	169.87	2.5	1.57	9.96	8	237	74	74	74	74	16.1						
	6	172.02	2.5	1.57	2.13	9	242	78	76	76	76	16.4						
S	9	174.15	2.5	1.56	4.31	7.5	260	81	76	76	76	16.4						
	12	176.31	2.6	1.63	6.53	10	239	82	76	76	76	16.5						
4	15	178.50	2.45	1.53	8.69	10.5	264	83	77	77	77	17.1						
	18	180.66	2.5	1.57	0.88	10.5	192	83	77	77	77	16.8						
3	21	182.89	2.4	1.51	3.02	10.5	260	84	78	78	78	16.8						
	24	185.14	2.4	1.51	5.17	10.5	260	84	78	78	78	16.8						
2	27	187.17	2.2	1.39	7.23	10	256	85	78	78	78	16.9						
	30	189.26	2.15	1.36	9.27	10	259	85	78	78	78	16.8						
1	33	191.19	1.75	1.11	1.11	9	257	85	79	79	79	17.0						
	36	193.07	1.75	1.11	2.95	9	257	85	79	79	79	16.9						
A 6	38	195.14	2.35	1.49	5.09	10.5	256	85	80	80	80	16.2						
	42	197.24	2.3	1.45	7.20	10.5	252	85	80	80	80	16.6						
5	45	199.34	2.3	1.46	9.31	10.5	258	86	80	80	80	16.6						
	48	201.31	2.25	1.42	1.40	10.5	252	86	81	81	81	16.0						
4	51	203.53	2.3	1.47	3.52	10.5	252	87	81	81	81	16.0						
	54	205.56	2.35	1.50	5.67	10.5	252	87	81	81	81	16.2						
3	57	207.72	2.4	1.53	7.82	10.5	252	87	82	82	82	16.0						
	60	209.05	2.45	1.50	9.96	10.5	252	88	82	82	82	16.1						
2	63	212.09	2.0	1.28	1.97	10.0	252	88	82	82	82	16.2						
	66	214.12	1.95	1.25	3.97	9.5	251	89	83	83	83	16.2						
1	69	215.81	1.25	0.8	5.5	6.5	243	89	83	83	83	16.2						
	72	217.40	1.25	0.8	7.08	6	243	89	83	83	83	16.2						
	(1732)																	
	0-72	49.69		1.39														
		V _m =		ΔH														

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. Newberry Date 8-28-96 Test 3 Run 3
 Source dryer cyclone / exhaust No. of traverse points 12
 Method can Filter holder: - Filter type: -

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 40.07 cfm at 12 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 other(s) MeCl₂ (P₂O₅ + Imp. Pinst)

No. of probe wash bottles: 1

Sample recovered by: EJ JL SF

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>871</u>	<u>547</u>	<u>324</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1509</u>	<u>1485</u>	<u>24</u>
Total			<u>348</u>

Integrated Gas Sampling Data:

Bag Pump No. 298 Box No. 16 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: 400 cc/min Operator: EJ

S/N of O₂ Analyzer used to monitor train outlet: 2913

052394-C:\STACK\WP\FORMS\S-0046RR

EPA Method 5 Field Data Sheet

Job L.P. Newberry Operators FJ JC Pilot No. 2703
 Source Myer Primary Systems Exhaust Meter Box No. 1.75 in. W.C. 1.90 in. 840
 Date 8-28-96 Test 3 Run 3 Gasmeter Coeff. .945 Bar. Press. 29.81 in. Hg 11.0 %
 Nozzle No. 61-55 Probe 239 Gas/In 82 Gas/Out 82
 Nozzle Dia. .190 in. Imp. 42 Oxygen (% v/v) 16.0

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. W.C.)	Orifice Meter (in. W.C.)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)												
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out										
	(1400)	(218.40)																					
B 6	3	220.41	2.55	1.56	0.59	8	239	239	42	82	82	82	16.0										
	6	222.53	2.4	1.49	2.73	8.5	246	246	44	82	82	82	16.4										
S	9	224.55	2.45	1.52	4.88	9	246	246	44	82	82	82	16.4										
	12	226.73	2.4	1.49	7.02	10	249	249	44	82	82	82	16.4										
4	15	228.92	2.5	1.56	9.21	11	249	249	44	82	82	82	16.4										
	18	231.11	2.5	1.57	1.40	11.5	260	260	44	82	82	82	16.2										
3	21	233.31	2.45	1.54	3.58	12	256	256	44	82	82	82	16.2										
	24	235.51	2.4	1.52	5.74	12	256	256	44	82	82	82	16.2										
2	27	237.54	1.7	1.08	7.57	9.2	253	253	47	84	84	84	16.3										
	30	239.35	1.6	1.02	9.34	8.5	253	253	46	85	85	85	16.2										
1	33	241.15	1.6	1.01	1.11	8	249	249	46	85	85	85	16.1										
	36	242.94	1.6	1.01	2.88	8	252	252	49	86	86	86	16.2										
A 6	39	245.10	2.4	1.52	5.05	11	256	256	49	88	88	88	16.0										
	42	247.28	2.4	1.52	7.22	11	256	256	44	87	87	87	16.0										
S	45	249.43	2.5	1.59	9.49	11	256	256	44	88	88	88	16.1										
	48	251.65	2.4	1.53	1.62	11	254	254	49	88	88	88	16.2										
4	51	253.83	2.4	1.52	3.79	11.1	252	252	49	89	89	89	16.2										
	54	256.10	2.2	1.51	5.97	11	260	260	50	88	88	88	16.1										
3	57	258.29	2.15	1.37	8.03	10.5	259	259	50	89	89	89	16.1										
	60	260.43	2.2	1.40	0.12	10	259	259	51	90	90	90	16.1										
2	63	262.85	1.75	1.12	1.99	8	256	256	51	90	90	90	16.2										
	66	264.29	1.8	1.16	3.89	7.5	252	252	50	90	90	90	16.4										
1	69	265.70	1.15	.74	5.42	5	252	252	50	91	91	91	16.4										
	72	268.29	1.1	.71	6.90	5	252	252	96	91	91	91	16.8										
	(1618)																						
	0-72	V _{in} = 48.89		1.40																			

INTERPOLL LABORATORIES, INC

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP Newberry Date 8-29-96 Test 3 Run 1
 Source DMYON ETUBE OUTLET No. of traverse points 12
 Method 011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

N/A

Recovery solvent(s)

acetone _____
 other(s) MCTH

No. of probe wash bottles:

N/A

Sample recovered by:

SD/DH

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	770	488	282
Impinger No. 2	231	172	59
Impinger No. 3			
Condenser			
Desiccant	1507	1495	12
Total			353

Integrated Gas Sampling Data:

Bag Pump No. 06 Box No. 9 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 930 (HRS) Time end: 1115 (HRS)
 Sampling rate: 400 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 8

052394-G:STACKIWPAFORMS-S-0046RR

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP/Newberry
 Source DRYER EXHAUST OUTLET
 Method 011 Filter holder: N/A

Date 8-18-96 Test 3 Run 2
 No. of traverse points 12
 Filter type: N/A

Sample Train Leak Check:
 Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 10 IN. HG (vac)

Particulate Catch Data:
 No. of filters used: _____

Recovery solvent(s)
 acetone _____
 Other(s) MCTH

No. of probe wash bottles: _____
 Sample recovered by: _____

N/A
35/DM

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	821	476	345
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1492	1464	28
Total			373

Integrated Gas Sampling Data:

Bag Pump No. 36
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0.00
 Time start: 9:30-12:15
 Sampling rate: 400

Box No. 9 Bag No. 2
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 13:17 (HRS)
 cc/min Operator: SF

S/N of O₂ Analyzer used to monitor train outlet: 8

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 5 Field Data Sheet

Job: LP NEWBERRY Operators: S.B./OH/SC Nozzle No.: 61455 Pilot No.: 6-76F60
 Source: DRYER TUBE OUTLET Meter Box No.: 14 ΔH@ 1.42 in.WC VAC. (in.Hg): 3 Nozzle Dia.: 0.30 in. C_p: 0.84
 Date: 6-26-96 Test: 3 Run: 2 Gasmeter Coeff.: 9929 Bar. Press.: 29.31 in.Hg H₂O: 24 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Gas/Out	Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.			
	(1215)	816.50											
1	5	822.39	1.30	2.13	2.65	3		240	38	80		16.9	
2	10	826.85	1.45	2.40	7.07	4		241	38	84		17.6	
3	15	831.71	1.70	2.86	1.85	5		245	38	85		17.9	
4	20	836.50	1.70	2.79	6.62	5		247	39	87		17.9	
5	25	840.61	1.20	1.98	0.65	4		250	42	90		17.9	
6	30	844.87	.97	1.61	4.29	3		253	43	90		17.9	
7	35	849.08	1.70	2.82	9.11	5		250	44	90		18.1	
8	40	853.73	1.60	2.66	3.78	5		248	44	92		17.5	
9	45	858.49	1.60	2.45	8.45	5		245	45	93		12.7	
10	50	863.23	1.65	2.73	3.19	5		247	46	94		17.7	
11	55	867.92	1.60	2.65	7.87	5		247	47	95		17.3	
12	60	872.43	1.55	2.57	2.47	5		248	48	95		17.4	
	(1317)												
	0 - 60	V _m = 53.93		2.90 ΔH =						AVG. = 85.2			

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LP new sunny Date 8-24-96 Test 3 Run 3
 Source DRYER ETUPE WICES No. of traverse points 12
 Method 0011 Filter holder: N/A Filter type: N/A

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at ∞ IN. HG (vac)

Particulate Catch Data:

No. of filters used:

N/A

Recovery solvent(s)

acetone
 other(s) METH

No. of probe wash bottles:

Sample recovered by:

56 / DM

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	783	486	297
Impinger No. 2	253	172	81
Impinger No. 3			
Condenser			
Desiccant	1553	1532	21
Total			399

Integrated Gas Sampling Data:

Bag Pump No. 06 Box No. 9 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 1500 (HRS) Time end: 1604 (HRS)
 Sampling rate: 400 cc/min Operator: SD

S/N of O₂ Analyzer used to monitor train outlet: 8

EPA Method 5 Field Data Sheet

Job LP Newberry Nozzle No. 61233 Pilot No. 6-TC PLW
 Source DRYBN ETAGE OUTLET Nozzle Dia. .230 in. C_p -.94
 Date 8-29-76 Test 3 Run 3 Bar. Press. 27.31 in.Hg H₂O 25 %
 Operators SP/SD/PA Meter Box No. 14 in.WC Gasmeter Coeff. 4229

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
A1	(1500)	(874.00)	1.40	2.27	8.32	3	160	247	NA	40	77	76	16.6
2	5	878.21	1.50	2.43	2.78	3-5	162	245		40	82	77	17.0
3	10	882.38	1.35	2.17	6.98	3	161	246		40	84	77	17.2
4	15	886.73	1.65	2.65	1.63	4	163	243		41	86	77	17.2
5	20	891.33	1.55	2.49	6.13	4	162	248		42	86	78	17.3
6	25	896.90	1.45	2.32	0.44	4	161	250		42	88	79	17.3
B1	30	900.30	1.40	2.26	4.79	4	165	251		42	91	80	17.5
2	35	904.58	1.55	2.49	7.31	4	168	247		42	93	81	17.5
3	40	909.15	1.60	2.57	3.90	4	170	250		43	93	81	17.5
4	45	913.78	1.35	2.16	6.12	4	168	253		43	92	80	17.7
5	50	918.00	1.40	2.25	2.43	4	168	255		43	93	80	17.5
6	55	922.28	1.25	2.01	6.50	4	167	251	→	44	93	80	17.5
6	60	926.25											
0	60	V _m = 52.25		2.34								76.7	
				ΔH =									

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Source LP/Newberry
 Test Dwyer RTO Stack
 Stack Dimen. 3 Run 64 Date 8-28-96 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.31 IN.HG
 Static Pressure -0.29 IN.WC
 Operators BA SK
 Pitot No. 40V-6 Cp .84

Cross-section View	Elevation View
--------------------	----------------

* Formaldehyde *

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
Port Length: _____ IN.			Time Start: _____ HRS		
Temp. Meas. Device & S/N:				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WPI\FORMS\S-392.1

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP/ Newberry Date 8-28-96 Test 3 Run 1

Source Dryer RTO STACK No. of traverse points 16

Method 1011 Filter holder: Bios Bypass Filter type: MA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: 6.0 cfm at 12 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

MA

Recovery solvent(s)

acetone _____
 other(s) MeCL

No. of probe wash bottles:

MA

Sample recovered by:

MA

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	782	466	316
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1492	1470	22
Total			338

Integrated Gas Sampling Data:

Done for TR7

Bag Pump No. _____

Box No. _____ Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____ IN.HG

Time start: _____

(HRS) Time end: _____ (HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

5

052394-G:STACKWPF:FORMS:00462R

EPA Method 5 field Data Sheet

Job IP / Newbury Pilot No. 100-6
 Source Dryc RTO Stack Nozzle Dia. .298 in. 84
 Date 5-28-86 Test 3 Run 1 Bar. Press. 29.31 in.Hg 23

Operators BA SK Glass
 Meter Box No. 7 1110195 in.WC
 Gasmeter Coeff. .9976

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Inp.		Gas/In	Gas/Out
B-8	0730	855.50	1.36	1.54	8.17	4	270	245	251	58	63	63	16.5
B-7	4	858.21	1.42	1.70	1.07	4.5	271	250	247	55	69	64	14.7
B-6	8	861.06	1.38	1.61	3.82	4.5	272	247	250	55	73	66	16.7
B-5	12	863.73	1.56	2.12	6.98	5.5	274	253	252	53	76	67	14.8
B-4	16	866.87	1.49	2.08	6.13	5.5	274	249	251	53	80	69	16.7
B-3	20	870.08	1.48	2.05	3.25	5.5	276	253	247	51	82	69	16.5
B-2	24	873.29	1.51	2.19	6.47	6	274	247	251	50	84	71	16.6
B-1	28	876.31	1.35	1.52	9.17	4.5	267	253	249	53	75	72	16.7
A-8	32	879.12	1.56	2.41	2.58	6	267	254	251	52	80	74	17.0
A-7	36	882.52	1.60	2.57	6.10	6.5	270	250	248	50	85	75	16.7
A-6	40	886.01	1.62	2.70	9.70	7	269	247	251	52	88	76	16.9
A-5	44	889.61	1.63	2.74	3.34	7	271	249	251	51	90	78	16.8
A-4	48	893.23	1.60	2.61	6.90	7	274	252	253	49	91	79	16.9
A-3	52	896.83	1.54	2.35	0.28	6.5	275	252	247	48	93	80	16.9
A-2	56	900.24	1.49	2.13	3.50	6	278	250	252	48	94	81	16.8
A-1	60	903.53	1.50	2.19	6.77	6	275	252	249	47	95	82	16.8
	64	906.82											
	(126)												
	0-64	V _m - 51.32		2.16									
				AVG. - 72.6									

INTERPOLL LABORATORIES, INC

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP Newberry Date 8-28-96 Test 3 Run 2
 Source Dye/ RTO STACK No. of traverse points 16
 Method 001 Filter holder: Class Bypass Filter type: HA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.0 cfm at 10 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

HA

acetone
 Other(s) Hex

No. of probe wash bottles:

14

Sample recovered by:

SA

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	816	470	346
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1523	1495	28
Total			374

Integrated Gas Sampling Data:

Done In TR7

Bag Pump No. _____

Box No. _____

Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: _____

44 L

Pretest leak check: _____

cc/min at _____

IN.HG

Time start: _____

(HRS) Time end: _____

(HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

5

052394-G:STACKWPAFORMSS-0046RR

EPA Method 5 Field Data Sheet

Job CPI Newberry Pilot No. 40-6
 Source Dye, PTO SPCS Nozzle No. 86less
 Date 6-28-76 Test 3 Run 2 Nozzle Dia. 2.98 in. 84
 Meter Box No. 7 in. WC 1.93 in. Hg 29.31
 Gasmeter Coeff. 9926 Bar. Press. 29.31 in. Hg 24
 % 24

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)	
							Probe	Oven	Imp.					
	(1215)	907.00												
A-5	4	910.42	.58	2.48	6.44	5.5	245	251	52	82	83	16.4		
2	8	913.77	.55	2.35	3.91	5.5	249	247	51	91	85	16.5		
4	12	917.45	.65	2.81	7.51	7	252	249	51	95	87	16.4		
5	16	921.07	.62	2.67	1.13	7	247	253	50	78	87	16.6		
4	20	924.66	.61	2.63	4.73	7	251	248	48	99	88	16.7		
3	24	928.22	.56	2.42	8.18	6.5	247	249	47	100	89	16.7		
2	28	931.82	.57	2.55	1.73	6.5	251	251	49	101	90	17.0		
1	32	934.99	.45	1.95	4.84	5	253	247	48	102	90	16.8		
B-9	36	938.65	.68	2.96	8.67	7	247	246	51	99	92	16.5		
7	40	942.06	.51	2.22	1.98	6	251	249	50	103	95	16.1		
6	44	945.15	.45	1.96	5.11	5.5	249	253	48	104	92	16.2		
5	48	948.45	.50	2.18	8.40	6	246	247	49	105	94	15.7		
4	52	952.11	.64	2.79	2.13	7	250	247	49	106	94	15.9		
3	56	955.90	.68	2.95	5.97	7.5	247	251	47	107	95	15.9		
2	60	959.61	.62	2.70	9.64	7	253	249	48	108	95	15.9		
1	64	963.76	.43	1.89	2.72	5.5	249	253	48	108	96	15.8		
	(1327)													
	0-64	V _m = 55.76		2.47							AVG. = 95.4			

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job CP1 Newberry Date 5-28-90 Test 3 Run 3
 Source Diner RTO Stack No. of traverse points 16
 Method coll Filter holder: Loss Bypass Filter type: 19

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0 cfm at 11 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

6A

Recovery solvent(s)

acetone _____
 other(s) HELL

No. of probe wash bottles:

NK

Sample recovered by:

GA

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	788	472	316
Impinger No. 2	310	270	40
Impinger No. 3			
Condenser			
Desiccant	1496	1467	23
Total			379

Integrated Gas Sampling Data:

Done for TR7

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet:

5

EPA Method 5 Field Data Sheet

Job CP Newberry Operator BA SK Nozzle No. 6155 Pilot No. Y00-E
 Source Dyes - RTD SMC Meter Box No. 7 AH @ 1.55 Nozzle Dia. .298 C_p 58
 Date 8-28-96 Test 3 Run 3 Gasmeter Coeff. .9726 Bar. Press. 29.31 in. Hg 35
 in. WC 7.26 in. Hg 35 % 35

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)						Oxygen (% v/v)
							Stack	Probe	Oven	Imp.	Gas/In	Gas/Out	
2-8	4	963.00	.45	1.76	6.11	5	257	251	247	56	90	90	16.2
7	8	966.11	.41	1.77	7.06	4.5	256	248	250	54	93	90	16.3
6	12	971.85	.35	1.51	1.77	4	261	252	249	52	97	92	16.0
5	16	975.22	.55	2.36	5.20	6	267	250	249	51	99	93	16.0
4	20	978.31	.43	1.84	8.23	5	269	249	253	50	102	94	15.7
3	24	981.82	.63	2.70	1.87	6.5	272	252	251	48	102	94	15.8
2	28	985.76	.57	2.44	5.38	6.5	272	247	246	48	104	95	15.8
1	32	988.73	.52	2.24	4.72	6	271	248	249	49	105	96	15.8
A-2	36	992.31	.60	2.69	2.32	6	270	248	253	51	105	96	16.0
7	40	995.94	.63	2.68	5.78	7	279	251	249	50	107	97	16.1
6	44	999.59	.66	2.57	5.78	7	277	248	253	48	108	98	15.8
5	48	1003.23	.64	2.75	9.57	7	277	249	251	48	110	98	15.5
4	52	1006.73	.54	2.33	3.28	6.5	276	252	248	46	111	99	16.0
3	56	1010.14	.53	2.28	6.70	6	278	249	253	47	112	100	16.2
2	60	1013.50	.50	2.16	1.09	6	276	246	250	46	111	100	16.2
1	64	1016.72	.48	2.08	3.39	6	274	250	247	46	112	100	16.0
					6.63	5.5							
	0-64	$v_m = 53.7$		$\Delta P =$								Avg. = 100	

INTERPOLL LABORATORIES, INC.
 (612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Newbury, MI
 Source Press / vents
 Test 5 Run 0 Date 8-29-96
 Stack Dimen. 59 x 55 (2 stacks) IN.
 Dry Bulb 110 °F Wet bulb 68 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.25 IN.HG
 Static Pressure -2.37 IN.WC
 Operators M. Koehler + M. Petersen
 Pitot No. 31V-6 C, 197

Cross-section View	Elevation View
-----------------------	-------------------

MOI

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	5.5 IN.	Time Start:	NA HRS
	1/6	9.83	15.33		
	3/6	29.50	35.00		110
	5/6	49.17	54.67		

Temp. Meas. Device & S/N: PDT-95 / TC Time End: NA HRS
 R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newberry, MI Date 8-29-96 Test 5 Run 1
 Source Press / Vent No. of traverse points 12
 Method MDI Filter holder: NA Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____
 other(s) Acet.
Toluene + Acetonitrile

No. of probe wash bottles:

Added to Impinger

Sample recovered by:

M. Kaskler + M. Peterson

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	475	526	(51)
Impinger No. 2	444	439	5
Impinger No. 3			
Condenser			
Desiccant	1544	1527	17
Charcoal	1497	1453	44
Total			15

Integrated Gas Sampling Data:

Bag Pump No. 3R 13 Box No. 9 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 IN.HG
 Time start: 0900 (HRS) Time end: 1002 (HRS)
 Sampling rate: 400 cc/min Operator: M. Kaskler

S/N of O₂ Analyzer used to monitor train outlet: NA

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newberry, MI
 Source Press / vents
 Method MD1 Filter holder: NA

Date 8-29-96 Test 5 Run 2
 No. of traverse points 12
 Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

NA

Recovery solvent(s)

acetone _____
 other(s) Toluene + Acetonitrile

No. of probe wash bottles:

Added to Impinger
with Kuebler + M. Peterson

Sample recovered by:

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	474	527	(53)
Impinger No. 2	439	438	1
Impinger No. 3			
Condenser			
Desiccant	1412	1393	19
Charcoal	1485	1440	45
Total			12

Integrated Gas Sampling Data:

Bag Pump No. TR B
 Bag Material: 3-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1035
 Sampling rate: 400

Box No. 9 Bag No. 2
 Size: 44 L
 cc/min at 15 IN.HG
 (HRS) Time end: 1136 (HRS)
 cc/min Operator: M. Kuebler

S/N of O₂ Analyzer used to monitor train outlet:

NA

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newberry, MI
 Source Press / vents
 Method MD1 Filter holder: NA

Date 8-29-96 Test 5 Run 3
 No. of traverse points 12
 Filter type: NA

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

NA

acetone
 Other(s) Toluene + Acetonitrile

No. of probe wash bottles:

Added to Impinger

Sample recovered by:

M. Kuebler + M. P. Harman

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	474	526	(52)
Impinger No. 2	443	441	2
Impinger No. 3			
Condenser			
Desiccant	1565	1544	21
Charcoal	1494	1451	43
Total			14

Integrated Gas Sampling Data:

Bag Pump No. TR-13
 Bag Material: 5-layer Aluminized Tedlar
 Pretest leak check: 0
 Time start: 1210
 Sampling rate: 400

Box No. 9 Bag No. 3
 Size: 44 L
 cc/min at 05 IN.HG
 (HRS) Time end: 1311 (HRS)
 cc/min Operator: M. Kuebler


S/N of O₂ Analyzer used to monitor train outlet:

NA

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. Newberry
 Source Press Vents
 Test 7 Run 0 Date 8-27-96
 Stack Dimen. 59x59 (2 stacks) IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.26 IN.HG
 Static Pressure -2.4 IN.WC
 Operators E. Juers J. Lorenz
 Pitot No. 29V-6 C_p .840



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>5.5</u> IN.	Time Start: _____ HRS		
A 1	<u>1/6</u>	<u>9.83</u>	<u>15.33</u>		
2	<u>3/6</u>	<u>29.50</u>	<u>35</u>		
3	<u>5/6</u>	<u>49.17</u>	<u>54.67</u>		
B 1					
2					
3					
C 1					
2					
3					
D 1					
2					
3					
E 1					
2					
3					
F 1					
2					
3					
G 1					
2					
3					
H 1					
2					
3					
Temp. Meas. Device & S/N: <u>PDT 47</u>				Time End: _____ HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job C.P. Newberry Date 5-27-96 Test 7 Run 1
 Source Press Vents No. of traverse points 24
 Method 0011 Filter holder: - Filter type: -

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 4.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: -

Recovery solvent(s)

acetone

Other(s) meCl₂ Imp. Rinse (Added to Imp. Catch + P.V.)

No. of probe wash bottles: -

Sample recovered by: -

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	544	550	-6
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1422	1404	18
Total			12

Integrated Gas Sampling Data: Ambient Air

Bag Pump No. 20 Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-G:STACKIWPF:FORMS:0046RR

612' '86-6020

EPA Method 5 field Data Sheet

Job L.P. Newberry Pilot No. 2976
 Source Bress Van XS Nozzle No. 6655
 Date 8-27-96 Test 7 Run 1 Nozzle Dia. .190 in. 840
 Meter Box No. H Alt @ 1.75 in. WC Gas In. 1.5
 Gasmeter Coeff. .9945 Bar. Press. 29.26 in. Hg

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)
							Probe	Oven	Imp.	Stack			
H	(1450)	930.20	1.2	1.54	2.37	4	246	266	43	90	89	Ambient Air	
	3	932.38	1.7	2.18	4.97	5	243	272	46	92	90		
	6	934.90	1.1	1.41	7.07	4	246	253	50	98	91		
	9	937.02	1.5	1.97	9.51	4.5	227	243	45	99	93		
	12	939.46	1.75	2.28	2.18	3	232	256	49	101	94		
	15	942.11	.62	.81	3.78	4	249	260	51	97	93		
	18	943.87	1.3	1.69	6.08	4	225	242	49	99	94		
	21	946.16	2.0	2.67	8.94	16	236	252	52	100	96		
	24	948.02	1.25	1.61	1.19	4	240	256	53	101	96		
	27	951.28	1.25	.14	1.86	4	230	252	54	102	96		
	30	951.98	.65	.83	3.47	2.5	225	242	49	101	96		
	33	953.52	.14	.14	4.23	1	236	252	52	102	95		
	36	954.31	.19	.14	7.18	6.5	240	256	53	103	96		
	39	957.21	2.15	2.76	9.94	6	230	252	54	104	96		
	42	959.99	1.85	2.42	1.48	3	226	252	53	104	96		
	45	961.49	.58	.75	1.48	3	240	256	53	104	96		
	48	964.31	1.9	2.47	4.27	6	230	252	54	102	96		
	51	968.02	1.8	2.33	6.98	5.5	226	252	53	103	96		
	54	969.13	1.1	1.41	9.10	3.5	230	252	54	104	96		
	57	971.90	1.9	2.49	1.90	6	226	252	53	104	96		
	60	974.58	1.8	2.33	4.61	5.5	226	252	53	104	96		
	63	975.79	.34	.44	5.80	2	226	252	53	104	96		
	66	978.13	1.4	1.82	8.20	4	235	260	54	103	97		
	69	980.74	1.6	2.08	0.76	3	235	260	54	103	97		
	72	982.14	.98	.62	2.17	2				104	97	↓	
	(1616)												
	0-72	V _{in} - 51.95		ΔH - 16.3						AVG. -	96.8		

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job C.P. Newberry

Date 8-27-96 Test 7 Run 2

Source Press Vents

No. of traverse points 24

Method 0011 Filter holder: -

Filter type: _____

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)

Post test: ≤ 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____

Other(s) MeCl₂ (Imp. Ring & P.W. combined with imp-catch)

No. of probe wash bottles: _____

Sample recovered by: ET

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	548	551	-3
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1479	1461	18
Total			18

Integrated Gas Sampling Data:

Ambient

Bag Pump No. _____

Box No. _____

Bag No. _____

Bag Material: 5-layer Aluminized Tedlar

Size: 44 L

Pretest leak check: _____

cc/min at _____ IN.HG

Time start: _____

(HRS) Time end: _____ (HRS)

Sampling rate: _____

cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

EPA Method 5 Field Data Sheet

Job C.P. Newberry
Source Press Vents
Date 8-27-96 Test 7 Run 2

Operators EJ JLC
Meter Box No. 4 ΔH @ 1.75 in.WC
Gas meter Coeff. 9945

Nozzle No. 6155
Nozzle Dia. .190 in.
Bar. Press. 29.26 in.Hg

Pilot No. 29V-6
 C_p .840
 H_2O 1.2 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in.WC)	Orifice Meter (in.WC)	Des. Vol. (cf)	VAC. (in.Hg)	Temperatures (°F)				Oxygen (% v/v)		
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out
A	(1645)	(982.40)	1.2	1.58	4.62	4	103	246	230	42	92	91	Ambient
	3	984.57	1.7	2.17	7.22	5.5	114				95	92	Air 20.9
	6	987.15	.36	.45	8.42	2	119	224	245	43	98	93	
	9	988.39	1.9	2.47	1.20	6	106				98	94	
B	12	993.80	1.75	2.20	3.83	5.5	127	237	249	46	100	94	
	15	995.96	1.10	1.43	5.95	4	108				101	95	
	18	998.78	1.95	2.53	8.77	6	111	245	250	47	98	93	
	21	1001.49	1.75	2.28	1.44	6	106				102	95	
	24	1003.73	1.3	1.68	3.74	4	115	239	247	49	102	95	
	27	1006.60	2.0	2.59	6.59	6	112				101	95	
D	30	1009.49	2.0	2.59	9.45	6	111	256	243	46	103	96	
	33	1011.97	1.5	1.93	1.92	5.5	116				102	95	
	36	1013.97	.94	1.22	3.88	3	113	265	251	46	99	95	
	39	1016.78	2.1	2.70	6.79	6.5	116				101	95	
	42	1018.12	.41	.53	8.08	2	116	259	256	47	103	96	
	45	1020.74	1.7	2.22	0.73	5	108				101	94	
F	48	1023.48	1.8	2.37	3.46	6	108	270	258	47	102	95	
	51	1026.03	1.6	2.06	6.01	5	116				103	96	
	54	1028.03	.97	1.27	8.01	3.5	109	265	260	46	101	95	
	57	1030.72	1.85	2.43	0.77	6	103				101	95	
	60	1032.67	.89	1.16	2.69	3	107	273	259	45	102	95	
	63	1034.23	.57	.75	4.24	2.5	101				100	95	
H	66	1037.07	1.95	2.88	7.08	6.5	100	269	256	46	102	95	
	69	1039.68	1.5	1.97	9.57	5	106				102	95	
	72												
	(1809)												
	0-72	$v_m =$ 57.25		$\Delta H =$ 1.88								AVG. = 97.9	

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job C.P. New berry Date 8-27-96 Test 7 Run 3
 Source Press Vents No. of traverse points 24
 Method 0011 Filter holder: — Filter type: —

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 7 IN. HG (vac)

Particulate Catch Data:

No. of filters used: _____

Recovery solvent(s)

acetone _____
 other(s) MeCl₂ (Imp. Rings + P.W. Combined with Imp. Catch)

No. of probe wash bottles: _____

Sample recovered by: _____

ES

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	550	552	-2
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1500	1483	17
Total			15

Integrated Gas Sampling Data:

Ambient

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

EPA Method 5 Field Data Sheet

Job Source C.P. Nanberry Press vents
 Date 8-27-96 Test 7 Run 3

Operator EJ JL
 Meter Box No. 4 ΔH @ 1.75 in. WC
 Gas meter Coeff. .9945

Nozzle No. Glass
 Nozzle Dia. .190 in.
 Bar. Press. 29.26 in. Hg


Pilot No. 29V-6
 C₁ .840
 H₂O 1.3 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cl)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)	
							Stack	Probe	Oven	Imp.		Gas/In
4	3	1039.90	.85	1.12	1.77	3	228	258	43	90	90	Ambient 20.9
2	6	1041.77	2.0	2.67	4.62	6.5	245	249	46	91	90	
1	9	1044.64	1.6	2.07	7.16	5	237	256	39	93	90	
6	12	1049.42	1.2	1.56	9.36	4	248	253	41	96	91	
2	15	1052.19	1.85	2.42	2.10	6	228	245	39	96	91	
1	18	1054.19	.96	1.25	4.08	3.5	230	237	40	96	91	
3	21	1056.35	1.1	1.44	6.20	4	227	241	42	95	90	
2	24	1059.17	2.05	2.68	9.09	6.5	248	253	41	96	91	
1	27	1061.70	1.65	2.12	1.60	5	228	245	39	97	91	
3	30	1063.86	1.05	1.38	3.75	3.5	230	237	40	96	91	
2	33	1066.20	1.4	1.82	6.13	4	227	241	42	97	91	
1	36	1067.31	.28	.36	7.20	2	248	244	41	97	91	
3	39	1069.71	1.5	1.95	9.66	5	252	249	44	97	91	
2	42	1072.58	2.0	2.56	2.49	6	256	247	43	95	90	
1	45	1074.69	1.5	1.48	4.64	4	248	244	41	96	91	
3	48	1077.46	1.9	2.43	7.39	6	252	249	44	97	91	
2	51	1080.13	1.9	2.31	0.08	5.5	256	247	43	95	90	
1	54	1082.25	1.1	1.41	2.18	3.5	256	247	43	94	90	
3	57	1084.83	1.7	2.19	4.79	5	264	256	45	97	91	
2	60	1087.57	1.8	2.33	7.98	6	264	256	45	98	91	
1	63	1090.08	1.55	2.02	9.99	5	230	262	41	96	90	
3	66	1092.73	1.75	2.26	2.65	5.5	230	262	41	96	90	
2	69	1095.45	1.8	2.36	5.36	5.5	230	262	41	96	90	
1	72	1097.58	1.1	1.44	7.98	3.5	230	262	41	97	91	
	1959											
	0-72	V _m = 57.68		ΔH = 1.90						AVG. =	93.0	

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Newberry, MI
 Source Dress / vents
 Test 0 Run 0 Date 0-20-96
 Stack Dimen. (59 X 59) 2 stacks IN.
 Dry Bulb 110 °F Wet bulb 0.7 °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 29.31 IN.HG
 Static Pressure -2.30 IN.WC
 Operators M. Kaehler & M. Peterson
 Pitot No. 310-5 MLC, 184
310-6 DM



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	5.5 IN.	Time Start:	NA HRS
A-1	1/6	9.83	15.33		
2	3/6	29.50	35		110
3	5/6	49.17	54.67		
B-1					
2					
3					
C-1					
2					
3					
D-1					
2					
3					
E-1					
2					
3					
F-1					
2					
3					
G-1					
2					
3					
H-1					
2					
3					

Temp. Meas. Device & S/N: PDT-45 / TC Time End: NA HRS
 R or nothing = reg. manometer; S = expanded; E = electronic

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job IP / Newberry, MI Date 8-24-96 Test 9 Run 1
 Source Press / Vent No. of traverse points 24
 Method 5 Filter holder: Glass Filter type: 4" G.F.

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 6 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

0457

Recovery solvent(s)

Acetone _____
 Other(s) Methyl

No. of probe wash bottles:

1

Sample recovered by:

M. Kachler + M. Peterson

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	507	504	3
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1400	1392	8
Total			11

Integrated Gas Sampling Data:

~~70A / Ambient~~ NA / Ambient
 Bag Pump No. 31 B Box No. 9 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: A cc/min at 15 IN.HG
 Time start: 1215 (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

EPA Method 5 Field Data Sheet

Job A.P. / Newberry, MI
Source Press / Vents
Date 8-28-96 Test 0 Run 1

Operators M. Kaehler & M. Peterson
Meter Box No. 10 ΔH @ 1.93 in WC
Gas meter Coeff. 1.0007

Nozzle No. 2-3
Nozzle Dia. .100 in.
Bar. Press. 29.31 in. Hg

Pilot No. 310-6
C_p .07
H₂O 1.3 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Oxygen (% v/v)																
							Stack	Probe	Oven	Imp.		Gas/In	Gas/Out														
A-3	1215	704.20																									
	215	206.17	1.70	1.99	6.07	4																					
2	5	200.15	1.83	3.04	9.02	4																					
1	215	209.18	.53	.59	9.08	2																					
B-3	10	211.22	1.25	1.97	1.00	4																					
2	1215	212.98	1.70	1.91	2.09	4																					
1	15	214.16	.64	.71	4.06	2																					
C-3	1215	216.23	1.80	2.01	6.00	4																					
2	20	217.99	1.80	2.02	7.96	4																					
1	2215	219.94	1.68	1.86	9.84	4																					
D-3	25	221.46	.97	1.07	1.26	2																					
2	2215	212.99	1.20	1.35	3.97	3																					
1	30	224.36	1.88	1.80	4.25	2																					
E-3	3215	226.51	2.10	2.36	6.37	4																					
2	35	228.82	2.27	2.56	8.58	4																					
1	3215	229.73	.95	.51	9.57	2																					
F-3	40	231.64	1.25	1.97	1.57	3																					
2	4215	233.85	1.83	2.08	3.50	4																					
1	45	235.73	1.61	1.80	5.36	3																					
G-3	4215	237.61	1.90	2.13	7.38	4																					
2	50	239.57	1.90	2.13	9.41	4																					
1	5215	241.44	1.80	2.09	1.41	4																					
2	55	243.55	2.32	2.68	3.68	4																					
H-3	5215	245.70	1.90	2.20	5.75	4																					
1	60	247.83	1.57	1.82	7.63	3																					
	1318																										
	0-60																										
		$V_m = 43.63$		$1.78 \Delta H$																							

AVG. = 84.1

INTERPOLL LABORATORIES, INC

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job LIP. / Newbury, MI Date 8-28-96 Test 8 Run 2
 Source Press / vents No. of traverse points 24
 Method 5 Filter holder: Glass Filter type: 4"6"

Sample Train Leak Check:

Pretest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 6 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

0465

Recovery solvent(s)

Acetone _____
 Other(s) MeCl₂

No. of probe wash bottles:

1

Sample recovered by:

M. Koehler M. Peterson

Condensate Data:


Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	<u>430</u>	<u>476</u>	<u>4</u>
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	<u>1520</u>	<u>1510</u>	<u>10</u>
Total			<u>14</u>

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____ Box No. _____ Bag No. _____
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: _____ cc/min at _____ IN.HG
 Time start: _____ (HRS) Time end: _____ (HRS)
 Sampling rate: _____ cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____



EPA Method 5 field Data Sheet

Job L.P. / Newberry, MI Pitot No. 310-6
 Source Press/Vent Nozzle No. 2-3
 Date 8-28-96 Test 0 Run 2 Nozzle Dia. .180 in.
 Meter Box No. 10 ΔH @ 1.0000 in.WC Bar. Press. 29.31 in.Hg
 Gasmeter Coeff. 1.0000 in.Hg

Traverse Point No.	Sampling Time (min)	Sample Vol. (cf)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)
							Probe	Oven	Insp.	Stack			
H-3	14.50	748.00	2.35	2.70	0.26	4	98	232	241	47	86	20.9	
2	2.5	750.27	1.67	1.90	2.17	3	107				88		
1	5	752.26	1.80	2.08	4.16	3	98	240	250	49	90		
6-3	7.5	754.32	1.23	2.00	6.12	3	99				91		
2	10	756.34	1.23	2.00	6.12	3	98	235	253	48	92		
1	12.5	758.27	1.25	2.03	8.10	3	100				95		
1	15	759.94	1.43	2.65	9.88	3	100	241	257	46	96		
F-3	17.5	762.05	2.00	2.32	1.99	3.5	107	241	257	46	96		
2	20	764.20	1.83	2.10	4.01	3.5	113	235	253	46	97		
1	22.5	765.99	1.65	1.88	5.91	3	113				98		
1	25	768.30	2.15	2.44	8.09	4	110	231	247	45	100		
2	27.5	770.23	1.97	2.14	0.12	3.5	113	227	250	44	100		
1	30	771.23	1.63	2.2	1.30	2	112	227	250	44	98		
2	32.5	772.30	1.54	1.82	2.40	2	112	230	245	46	101		
1	35	773.20	1.86	1.98	3.78	2	112	230	245	46	101		
1	37.5	775.31	1.85	1.97	5.16	2	112	230	245	46	101		
2	40	777.19	1.20	1.95	2.11	3	111	237	241	48	101		
2	42.5	779.10	1.85	2.12	9.14	2.5	111	237	241	48	102		
1	45	781.20	1.71	1.94	1.08	3	119				103		
1	47.5	783.15	1.25	1.96	3.04	3	125	233	240	49	104		
2	50	785.11	1.82	2.11	5.06	3	107	229	245	51	104		
1	52.5	786.99	1.63	1.90	6.99	3	105	229	245	51	105		
1	55	789.83	1.30	1.50	8.70	2.5	112	237	241	51	105		
2	57.5	790.65	1.60	1.85	0.60	3	111	237	241	51	105		
1	60	792.07	1.90	1.83	2.02	2	115				106		
(1552)													
0-60		V _m = 44.07		ΔH = 4.79							AVG. = 93.4		

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Interpoll Laboratories EPA Method 5/17 Sample Log Sheet

Job L.P. / Newberry, MI
 Source Process / Waste
 Method 5 Filter holder: Glass

Date 8-28-96 Test 8 Run 3
 No. of traverse points 24
 Filter type: 4" G.F.

Sample Train Leak Check:

Prerest: ≤ 0.02 cfm at 15 IN.HG (vac)
 Post test: 0.02 cfm at 6 IN. HG (vac)

Particulate Catch Data:

No. of filters used:

Recovery solvent(s)

0474

Racetone _____
 Other(s) MeCl₂

No. of probe wash bottles:

1

Sample recovered by:

M. Kachler + M. Petersen

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	500	495	5
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1405	1400	5
Total			10

Integrated Gas Sampling Data:

NA / Ambient

Bag Pump No. _____
 Bag Material: 5-layer Aluminized Tedlar
 Prerest leak check: _____
 Time start: _____
 Sampling rate: _____

Box No. _____ Bag No. _____
 Size: 44 L
 cc/min at _____ IN.HG
 (HRS) Time end: _____ (HRS)
 cc/min Operator: _____

S/N of O₂ Analyzer used to monitor train outlet: _____

052394-C:\STACK\WPA\FORMS\0046RR

1911 2100 (612) 76-6020

EPA Method 5 Field Data Sheet

Job L.P. Numbers All Pilot No. 3/V-6
 Source Cross Links Meter Box No. 12 AH @ 1.93 in WC Nozzle No. 2-3
 Date 8-28-96 Test B Run 3 Gasmeter Coeff. 1.0007 Nozzle Dia. 1.80 in. 1.81
 Bar. Press. 29.3 in. Hg H₂O 1.6 %

Traverse Point No.	Sampling Time (min)	Sample Vol. (cl)	Velocity Head (in. WC)	Orifice Meter (in. WC)	Des. Vol. (cf)	VAC. (in. Hg)	Temperatures (°F)				Gas/In	Gas/Out	Oxygen (% v/v)
							Stack	Probe	Oven	Imp.			
A-3	1615	792.40	.63	.71	3.58	2	111	243	44	257	96	94	20.9
	2.15	793.59	.80	.91	4.91	2	110	282	46	250	97	94	
	5	794.87	.67	.75	6.13	2	118				99	94	
B-3	10	798.03	1.64	1.86	9.03	3	115	240	46	256	101	93	
	12.5	799.96	1.60	1.84	9.93	3	109				103	93	
	15	801.91	1.65	1.87	1.04	3	118	235	48	257	105	94	
C-3	17.5	803.94	1.73	1.96	3.00	3	118				105	94	
	20	805.07	1.75	2.02	5.79	3.1	108				106	94	
	22.5	807.22	1.60	1.81	7.67	3	120	233	47	250	107	95	
D-3	25	809.71	1.72	1.97	9.04	3	114				107	95	
	27.5	811.63	1.45	1.67	1.46	3	110	230	46	255	107	95	
	30	813.22	1.20	1.38	3.10	2.5	113				108	96	
E-3	32.5	815.41	2.00	2.27	5.22	3.5	110	227	46	254	107	96	
	35	817.47	2.25	2.59	7.47	4	112				109	96	
	37.5	818.99	1.00	1.14	0.98	2	116	223	44	247	109	97	
F-3	40	820.07	1.20	1.45	0.94	3	115				109	97	
	42.5	822.91	1.28	2.09	2.96	3	107	230	45	249	109	97	
	45	824.91	1.80	2.07	4.98	3	113				110	97	
G-3	47.5	827.00	1.90	2.16	7.04	3.5	121	237	47	241	109	98	
	50	829.14	1.01	2.30	9.17	4	118				110	98	
	52.5	831.20	1.85	2.18	1.24	3.5	102	239	49	248	111	98	
H-3	55	833.61	1.40	2.02	3.60	4.5	103				110	94	
	57.5	836.22	2.55	2.99	6.03	5	103	240	53	245	111	100	
	60	838.20	1.80	2.13	9.08	3.6	100				110	100	
	(1717)												
	0-60	V _m - 45.80		1.89								AVG. - 101.2	

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One) Method 9 203A 203B Other: _____

Company Name
Louisiana Pacific

Facility Name
Newberry USB Plant

Street Address

City Newberry State MI Zip

Process Press vent Unit # NA Operating Mode Auto

Control Equipment NA Operating Mode NA

Describe Emission Point
The west stack of two tan stacks on top of the 500' towards the south end

Height of Emiss. Pt. Start ~65' End same

Distance to Emiss. Pt. Start ~180' End same

Direction to Emiss. Pt. (Degrees) Start 20° End same

Remot. Angle to Obs. Pt. Start -20° End same

Direction to Obs. Pt. (Degrees) Start 20° End same

Distance and Direction to Observation Point from Emission Point
at 3' Above stack End same

Describe Emissions
Start rising up End same

Emission Color white End same

Water Droplet Plume Attached Detached None

Describe Plume Background
Start sky End same


Background Color Blue End same

Wind Speed ~0 to 4 mph End same

Wind Direction southwest End same

Ambient Temp. 79° End 83°

Wet Bulb Temp. 65° RH Percent 46%



Longitude _____ Latitude _____ Declination _____

Additional Information
West stack

Observation Date	Time Zone	Start Time	End Time		
<u>8-28-96</u>	<u>EDST</u>	<u>14:50</u>	<u>15:20</u>		
Sec	0	15	30	45	Comments
1	0	5	0	0	
2	5	5	5	0	
3	0	0	0	0	
4	0	0	0	0	
5	5	0	5	5	
6	5	5	0	0	
7	0	0	0	0	
8	0	0	0	5	
9	5	5	10	5	
10	10	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	5	5	5	0	
14	5	0	0	0	
15	0	0	0	5	
16	5	5	5	10	
17	5	5	5	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	5	10	
21	5	10	5	0	
22	0	0	0	0	
23	0	5	5	5	
24	5	5	10	5	
25	5	5	0	0	
26	0	0	0	0	
27	0	0	5	5	
28	5	5	5	5	
29	5	0	0	0	
30	0	0	5	5	

Observer's Name (Print) Mark Petersen

Observer's Signature Mark Petersen Date 8/28/96

Organization Interpoll Laboratories Inc.

Certified By Eastern Technical Associates. Date 4-3-96

VISIBLE EMISSION OBSERVATION FORM 1

Form Number Page 2 of 2
 Continued on VEO Form Number

Log Used (Circle One) Method 2 2038 2038 Other: _____

Company Name
Louisiana Pacific
 Facility Name
Newberry OSB Plant
 Facility Address
Newberry State MI Zip

Process
Press vent Unit # NA Operating Mode Auto.
 Equipment NA Operating Mode NA

Describe Emission Point
The west stack of 2 tan stacks on top

of the south side of the roof

Height of Emiss. Pt.
~65' End same Height of Emiss. Pt. Rel. to Observer
 Start ~65' End same
 Direction to Emiss. Pt. (Degrees)
~180' End same Start 20° End same

Direction to Obs. Pt. (Degrees)
~20° End same Start 20° End same

Distance and Direction to Observation Point from Emission Point
3' Above stack End same


Describe Emissions
straight up End same
 Emission Color
white End Water Droplet Plume
 Attached Detached None

Time Background
sky End same

Ground Color
Blue End same Sky Conditions
 Start clear End same

Wind Speed
~0 to 4 mph End same Wind Direction
 Start southwest End same

Air Temp. 83° End same Wet Bulb Temp. 68° RH Percent 46%



Latitude _____ Longitude _____

Additional Information
West stack

Observation Date	Time Zone	Start Time	End Time				
8-28-96	EDST	15:20	15:50				
Sec	0	15	30	45	Comments		
Min	0	5	5	5			
1	0	5	5	5			
2	10	5	5	0			
3	0	0	0	0			
4	0	0	5	5			
5	5	5	5	5			
6	5	5	5	0			
7	0	0	0	0			
8	0	0	0	5			
9	5	5	5	5			
10	5	0	0	0			
11	0	0	0	5			
12	5	5	5	5			
13	5	5	5	5			
14	0	0	0	0			
15	0	0	0	0			
16	0	5	5	5			
17	5	5	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	5	5	5	5			
21	5	5	5	5			
22	0	0	0	0			
23	0	5	0	5			
24	0	5	5	5			
25	5	5	5	0			
26	0	0	0	0			
27	0	0	5	5			
28	5	5	5	5			
29	5	5	0	0			
30	0	0	0	0			

Observer's Name (Print)
Mark Petersen
 Observer's Signature
Mark Peter Date 8/28/96
 Organization
Interpoll Laboratories Inc.
 Certified by
Eastern Technical Associates Date 4-3-96

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)
 Method 9 203A 203B Other _____

Company Name
 Louisiana Pacific

Facility Name
 Newberry OSB Plant

City
 Newberry State MI Zip _____

Process
 Press vent Unit # NA Operating Mode AUTO.

Control Equipment
 NA Operating Mode NA

Describe Emission Point
 the east stack of 2 4m stacks on top of south side of roof

Height of Emiss. Pt.
 Start ~65' End same
 Distance to Emiss. Pt.
 Start ~140' End same

Direction to Emiss. Pt. (Degrees)
 Start 22° End same
 Direction to Obs. Pt. (Degrees)
 Start 22° End same

Distance and Direction to Observation Point from Emission Point
 Start 3' Above End same

Describe Emissions
 Start straight up End same

Emission Color
 Start white End same

Water Droplet Plume
 Attached Detached None

Describe Plume Background
 Start sky End same

Background Color
 Start Blue End same


Sky Conditions
 Start clear End same

Wind Speed
 Start 0 to 4 mph End same

Wind Direction
 Start southwest End same

Ambient Temp.
 Start 79° End 83°

Wet Bulb Temp.
 Start 65° RH Percent 46%



Observer's Position
 Latitude _____ Declination _____

Additional Information
 East stack

Form Number _____ Page 1 of 2
 Continued on VEO Form Number _____

Observation Date	Time Zone	Start Time	End Time		
8-28-96	EAST	14:50	15:20		
Sec Mn	0	15	30	45	Comments
1	0	5	0	0	
2	5	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	5	0	5	5	
6	5	5	0	0	
7	0	0	0	0	
8	0	0	0	5	
9	5	5	10	5	
10	5	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	5	5	5	0	
14	5	0	0	0	
15	0	0	0	5	
16	5	5	5	10	
17	5	5	5	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	5	15	
21	5	10	5	0	
22	0	0	0	0	
23	0	5	5	5	
24	5	5	10	5	
25	5	5	0	0	
26	0	0	0	0	
27	0	0	5	5	
28	5	5	5	5	
29	5	0	0	0	
30	0	0	5	5	

Observer's Name (Print)
 Mark Peterson
 Observer's Signature
 Mark Peterson Date 8/28/96
 Organization
 Interpoll Laboratories, Inc.
 Certified By
 Eastern Technical Associates Date 4-3-96

VISIBLE EMISSION OBSERVATION FORM 1

Use Label (Circle One) Method 9 203A 203B Other: _____

Company Name
Louisiana Pacific
City Name
Newberry OSB Plant
Street Address

City
Newberry State
MI Zip

Process
Press vent Unit #
NA Operating Mode
Auto.
Other Equipment
NA Operating Mode
NA


Visible Emission Point
The east stack of 2 tan stacks on top of south side of roof

Height of Emiss. Pt. Rel. to Observer
~65' End same Start ~65' End same
Direction to Emiss. Pt. (Degrees)
~190' End same Start 220' End same

Vertical Angle to Obs. Pt.
~190' End same Start 220' End same
Distance and Direction to Observation Point from Emission Point
~3' above End same

Visible Emissions
Plume Color
straight up End same
Plume Color
white End same
Water Droplet Plume
Attached Detached None

Plume Background
sky End same
Background Color
Blue End same Sky Conditions
clear End same
Wind Speed
~0 to 4 mph End same Wind Direction
southwest End same
Wet Bulb Temp.
83° End same Wet Bulb Temp.
60° RH Percent
46%



Latitude Longitude Destination

Additional Information
EAST stack

Form Number _____ Page 2 of 2
Continued on VEO Form Number _____

Observation Date	Time Zone	Start Time	End Time				
8-28-96	EDST	15:20	15:50				
Sec	0	15	30	45	Comments		
Min	0	5	5	5			
1	0	5	5	5			
2	10	5	5	0			
3	0	0	0	0			
4	0	0	5	5			
5	5	5	5	5			
6	5	5	5	0			
7	0	0	0	0			
8	0	0	5	5			
9	5	5	5	5			
10	5	0	0	0			
11	0	0	0	5			
12	5	5	5	5			
13	5	5	5	5			
14	0	0	0	0			
15	0	0	0	0			
16	0	5	5	5			
17	5	5	0	0			
18	0	0	0	0			
19	0	0	0	5			
20	5	5	5	5			
21	5	5	5	5			
22	0	0	0	0			
23	0	5	0	5			
24	0	5	5	5			
25	5	5	5	0			
26	0	0	0	0			
27	0	5	5	5			
28	5	5	5	5			
29	5	0	0	0			
30	0	0	0	0			

Observer's Name (Print)
Mark Petersen
Observer's Signature
Mark Peter Date
8/28/96
Organization
Interpoll Laboratories, Inc.
Certified By
Eastern Technical Associates Date
4-3-96

VISIBLE EMISSION OBSERVATION FORM 1

Method used (Circle One) Method 9 202A 2028 Other: _____

Company Name: TR/Newsberry
 Facility Name: _____
 Street Address: _____
 City: Newberry State: MAI Zip: _____


Process: Dryer Unit #: _____ Operating Mode: _____
 Control Equipment: RTU & EQ Operating Mode: _____

Describe Emission Point: Large silver stack on S. side of plant ^{NW of} behind RTU
 Height of Emiss. Pt. Start: ~80ft End: ~80ft Height of Emiss. Pt. Rel. to Observer Start: ~70ft End: ~70ft
 Distance to Emiss. Pt. Start: ~340ft End: ~340 Direction to Emiss. Pt. (Degrees) Start: ~60° End: ~60°

Vertical Angle to Obs. Pt. Start: _____ End: _____ Direction to Obs. Pt. (Degrees) Start: ~60° End: ~60°
 Distance and Direction to Observation Point from Emission Point Start: ~6ft up End: same

Describe Emissions: Start: occasional faint gray whisp End: _____
 Emission Color: gray or colorless Water Droplet Plume: _____
 Start: gray End: same Attached: Detached: None:

Describe Plume Background: Start: SKY End: SKY
 Background Color: Start: Blue End: Blue Sky Conditions: Start: Clear End: _____
 Wind Speed: Start: 5-10 End: 5-10 Wind Direction: Start: SSE End: SAME
 Ambient Temp: Start: 70 End: 70 Wet Bulb Temp: 60 RH Percent: 54



Longitude: _____ Latitude: _____ Declination: _____

Additional Information: _____

Form Number: _____ Page: 1 of 2
 Continued on VEO Form Number: _____

Sec Min	Time Zone: <u>East</u>				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	5	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	5	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	5	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	5	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	5	
24	0	0	0	5	
25	0	0	0	0	
26	0	0	5	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Stephen P Kelker
 Observer's Signature: [Signature] Date: 8/27/96
 Organization: Interpoll Labs
 Certified By: ETA Date: 4/3/96

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Stephen Kelker

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation of white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

[Signature]
President

[Signature]
Secretary

David B. Savage, Jr.
Program Manager

252750
Certificate Number

Minneapolis Minnesota
Issued at


April 3, 1996
Date of Issue

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Mark Petersen

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeds 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.



President



Program Manager


252753

Certificate Number

Minneapolis, Minnesota

April 3, 1996

Date of Issue




APPENDIX D

INTERPOLL LABORATORIES ANALYTICAL DATA

TABLE OF CONTENTS

Orsat	1
Particulate	7
Carbon Monoxide	25
Methane	28
Formaldehyde	32
MDI	33
Spiking Information	34
Sample Deposition Sheets	36



EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP/Newberry
 Team Leader MK
 Date Submitted 8-30-96
 Test No. 1
 Date of Analysis 9-6-96

Source Dryer Primary cyclone
 Test Site Exhaust
 Date of Test 8-27-96
 No. of Runs Completed 3
 Technician SLB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/3	8201-68	1	0.00	4.3	20.4	4.3	16.1	1.12
		2	0.00	4.3	20.4	4.3	16.1	1.12
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.3	16.1	
1/4	-69	1	0.00	4.0	20.6	4.0	16.6	1.08
		2	0.00	4.0	20.6	4.0	16.6	1.08
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.0	16.6	
1/5	-70	1	0.00	4.1	20.6	4.1	16.5	1.07
		2	0.00	4.1	20.6	4.1	16.5	1.07
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.1	16.5	
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)
 B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job
Team Leader
Date Submitted
Test No.
Date of Analysis

LP-New Barry
JTB
8-30-96
1
9-6-96

Source
Test Site
Date of Test
No. of Runs Completed
Technician

DRYER E-TUBE
OUTLET
8-28-96
2
SCB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/3	8205-50	1	0.00	3.9	20.4	3.9	16.5	1.13
		2	0.00	3.9	20.4	3.9	16.5	1.13
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg				3.9	16.5
1/4	-51	1	0.00	3.6	20.5	3.6	16.9	1.11
		2	0.00	3.6	20.5	3.6	16.9	1.11
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg				3.6	16.9
1/5	-52	1	0.00	3.7	20.5	3.7	16.8	1.11
		2	0.00	3.7	20.5	3.7	16.8	1.11
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.7	16.8
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

EPA Method 3 Guidelines

Fuel Type	F0 Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where F₀ = $\frac{20.9 \cdot O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

INTERPOL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP - Newburg
 Team Leader SF
 Date Submitted 8-20-96
 Test No. 1
 Date of Analysis 9-6-96

Source Dryd Kto
 Test Site STACK
 Date of Test 8-27-96
 No. of Runs Completed 4
 Technician SLD

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/2	8201-	1	0.00	3.5	20.3	3.5	16.8	1.17
		2	0.00	3.5	20.3	3.5	16.8	1.17
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.5	16.8	
1/3	8201	1	0.00	3.0	20.5	3.0	17.5	1.17
		2	0.00	3.0	20.5	3.0	17.5	1.13
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.0	17.5	
1/4	8201	1	0.00	4.0	20.3	4.0	16.3	1.15
		2	0.00	4.0	20.3	4.0	16.3	1.15
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.0	16.3	
1/5	8201	1	0.00	4.0	20.7	4.0	16.4	1.13
		2	0.00	4.0	20.4	4.0	16.4	1.13
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.0	16.4	
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines
 for fuel type.

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job LP - Newberry
 Team Leader EJ
 Date Submitted 8-30-96
 Test No. 3
 Date of Analysis 9-6-96

Source DRY- PRIMARY CYCLONE
 Test Site TEANAUST
 Date of Test 8-28-96
 No. of Runs Completed 3
 Technician SLB

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
3/1	8201	1	0.00	3.9	20.5	3.9	16.6	1.10
		2	0.00	3.9	20.5	3.9	16.6	1.10
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.9	16.6
3/2	8201	1	0.00	3.9	20.5	3.9	16.6	1.10
		2	0.00	3.9	20.5	3.9	16.6	1.10
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.9	16.6
3/3	8201	1	0.00	4.2	20.3	4.2	16.1	1.14
		2	0.00	4.2	20.3	4.2	16.1	1.14
		<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.2	16.1
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					
		1						
		2						
		<input type="checkbox"/> B <input type="checkbox"/> F	Avg					

Ambient Air QA Check

Orsat Analyzer System Leak Check

F₀ Within EPA M-3 Guidelines for fuel type.

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job L.P. Newbern, MI
 Team Leader J. Baranville
 Date Submitted 8-29-96
 Test No. 3
 Date of Analysis 8-29-96

Source Dryer 'E' Tube #
 Test Site Outlet
 Date of Test 8-29-96
 No. of Runs Completed 3
 Technician Mark Kachler

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
3/1	8201	1	0.00	4.00	20.70	4.00	16.70	1.050
		2	0.00	4.00	20.70	4.00	16.70	1.050
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.00	16.70	
3/2	8201	1	0.00	4.20	20.70	4.20	16.50	1.048
		2	0.00	4.20	20.70	4.20	16.50	1.048
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.20	16.40	
3/3	8201	1	0.00	4.40	20.70	4.40	16.30	1.045
		2	0.00	4.40	20.70	4.40	16.30	1.045
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.40	16.30	
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						

- Ambient Air QA Check
- Orsat Analyzer System Leak Check
- F₀ Within EPA M-3 Guidelines for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)

B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

EPA Method 3 Data Reporting Sheet - Orsat Analysis

Job L.P. / Newberry, MI
 Team Leader B. Aichenbach
 Date Submitted 8-29-96
 Test No. 3
 Date of Analysis 8-30-96

Source Dryer LTD
 Test Site Stack
 Date of Test 8-29-96
 No. of Runs Completed 3
 Technician Mark Ischler

Test/Run	Sample Log No. and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
3/1	B201	1	0.00	3.50	20.20	3.50	16.70	1.200
		2	0.00	3.50	20.20	3.50	16.70	1.200
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.50	16.70	
3/2	B201	1	0.00	3.50	20.30	3.80	16.50	1.158
		2	0.00	3.50	20.30	3.80	16.50	1.158
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				3.80	16.50	
3/3	B201	1	0.00	3.50	20.20	4.00	16.20	1.175
		2	0.00	3.50	20.20	4.00	16.20	1.175
	<input checked="" type="checkbox"/> B <input type="checkbox"/> F	Avg				4.00	16.20	
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						
		1						
		2						
	<input type="checkbox"/> B <input type="checkbox"/> F	Avg						

Ambient Air QA Check
 Orsat Analyzer System Leak Check
 F₀ Within EPA M-3 Guidelines for fuel type.

Where F₀ = $\frac{20.9 - O_2}{CO_2}$

F - Flask (250 cc all glass)
 B - Tedlar Bag (5 layer)

EPA Method 3 Guidelines

Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.130

Impinger Catcher Data Reporting Sheet

612) 786-6020
REVIEWED
 SEP 12 1996
 Source/Site
 Test No.
 Technician


Protocol: Minnesota Wisconsin Iowa EPA Method 202 Other
 Job: LP/Newberry
 Date Submitted: 9-3-96
 Date of Analysis: 9-5-96
 Source/Site: Dryer Primary Cyclone/Exhaust
 Test No.: 1
 Technician: B.J.

		Solvent Phase		Aqueous Phase	
Test: 1	Run: 0	Dish No: 520		Dish No: 788	
Log No: 8201-62I		Dish + Sample Wt: 48.5298 g		Dish + Sample Wt: 45.4003 g	
Color & Appearance:		Dish Tare Wt: 48.5286 g		Dish Tare Wt: 45.4003 g	
		Fraction Wt: 0.0002 g		Fraction Wt: 0.0000 g	
Comments:		Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333		Smpl Vol: 200 ml, Alqt: 150 ml, Factor: 1.333	
		Sample Wt: 0.0003 g		Sample Wt: 0.0000 g	
Test: 1	Run: 3	Dish No: 601		Dish No: 814	
Log No: -652		Dish + Sample Wt: 47.7186 g		Dish + Sample Wt: 46.7599 g	
Color & Appearance:		Dish Tare Wt: 47.6672 g		Dish Tare Wt: 46.6369 g	
		Fraction Wt: 0.0514 g		Fraction Wt: 0.1230 g	
Comments:		Smpl Vol: 330 ml, Alqt: 280 ml, Factor: 1.179		Smpl Vol: 330 ml, Alqt: 280 ml, Factor: 1.179	
		Sample Wt: 0.0606 g		Sample Wt: 0.1450 g	
Test: 1	Run: 4	Dish No: 606		Dish No: 818	
Log No: -662		Dish + Sample Wt: 48.6550 g		Dish + Sample Wt: 46.6030 g	
Color & Appearance:		Dish Tare Wt: 48.5729 g		Dish Tare Wt: 45.9034 g	
		Fraction Wt: 0.0821 g		Fraction Wt: 0.0996 g	
Comments:		Smpl Vol: 390 ml, Alqt: 340 ml, Factor: 1.147		Smpl Vol: 390 ml, Alqt: 340 ml, Factor: 1.147	
		Sample Wt: 0.0942 g		Sample Wt: 0.1142 g	
Test: 1	Run: 5	Dish No: 607		Dish No: 826	
Log No: -672		Dish + Sample Wt: 47.4562 g		Dish + Sample Wt: 48.7081 g	
Color & Appearance:		Dish Tare Wt: 47.3970 g		Dish Tare Wt: 48.5741 g	
		Fraction Wt: 0.0592 g		Fraction Wt: 0.1340 g	
Comments:		Smpl Vol: 370 ml, Alqt: 320 ml, Factor: 1.156		Smpl Vol: 370 ml, Alqt: 320 ml, Factor: 1.156	
		Sample Wt: 0.0685 g		Sample Wt: 0.1549 g	

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. 0.0003 g

	RUN 0	RUN 3	RUN 4	RUN 5
Results of Solvent Phase g	0.0003	0.0603	0.0939	0.0682
Results of Aqueous Phase g	0.0000	0.1450	0.1142	0.1549



INTERPOL LABORATORIES, INC.

(612) 786-6020

Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job: LP. Newberry Source/Site: Phygen Primary Chemical Exhaust
 Date Submitted: 8-29-96 Test No.: 1
 Date of Analysis: 9-20-96 Technician: SLB
 Transport Leakage: None _____ ml Solvent: ACETONE

Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>57</u>
Log No: <u>8201-62P</u>		Dish + Sample Wt: <u>49.2924</u> g
Volume of Solvent: <u>70</u> ml		Dish Tare Wt: <u>49.2120</u> g
*Solvent Residue: _____ ug/ml		Sample Wt: <u>0.0004</u> g
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>51</u>
Vol. of Solvent: <u>130</u> ml		Dish + Sample Wt: <u>44.9029</u> g
Log Number: <u>-632</u>		Dish Tare Wt: <u>44.7340</u> g
Comments:		Sample Wt: <u>0.0689</u> g
Test: <u>1</u>	Run: <u>4</u>	Dish No: <u>879</u>
Vol. of Solvent: <u>100</u> ml		Dish + Sample Wt: <u>38.7569</u> g
Log Number: <u>-64P</u>		Dish Tare Wt: <u>38.6576</u> g
Comments:		Sample Wt: <u>0.0993</u> g
Test: <u>1</u>	Run: <u>5</u>	Dish No: <u>875</u>
Vol. of Solvent: <u>100.1</u>		Dish + Sample Wt: <u>39.0430</u> g
Log Number: <u>-64P</u>		Dish Tare Wt: <u>38.9877</u> g
Comments:		Sample Wt: <u>0.0553</u> g

*Solvent Residue 5.71 ug/ml = [(Sample Wt. 0.0004 g) (10⁶)] / Vol. of Sol. 70 ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

VSL

	RUN	RUN 3	RUN 4	RUN 5
Results of Solvent Rinse g		<u>0.0682</u>	<u>0.0987</u>	<u>0.0547</u>



	A	B	C	D	E	F	G	H	I	J
1	EPA Method 202 Calculations									
2	Job: LOUISIANA PACIFIC - NEWBERRY									
3	Date: 27-Aug-96									
4	<i>Dryer Primary Cyclone Exhaust</i>									
5		Vic	Sulfate	MC	Mr	Mi	Mo	Mb	CPM	ENTER IN
6	RUN	(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER
7	1	330	6.95E-04	0.04	145	144.96	60.6	0.3	205.26	(g)
8	2	390	5.11E-04	0.04	114.2	114.16	94.2	0.3	208.06	0.2052578
9	3	370	1.23E-03	0.08	154.9	154.82	68.5	0.3	223.02	0.208063331
10										0.223016262
11										
12	EPA Method 201A/202 Totals									
13		Probe	Filter	CPM	Total					
14		(mg)	(mg)	(mg)	(mg)					
15	RUN									
16	1	68.2	696.8	205.26	970.2578					
17	2	98.7	535.5	208.06	842.2633					
18	3	54.7	595	223.02	872.7163					

Report No. 6-8201


Impinger Catch Data Reporting Sheet

Protocol: Minnesota Wisconsin Iowa EPA Method 202 Other _____
 Job: LP/Newberry Source/Site: Dryer E Take 1/outlet
 Date Submitted: 8-30-96 Test No.: _____
 Date of Analysis: 9-5-96 Technician: [Signature] B.O. _____

		Solvent Phase		Aqueous Phase	
Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>911</u>	Dish No: <u>311</u>		
Log No: <u>8201-44I</u>	Dish + Sample Wt: <u>44.8260</u> g	Dish + Sample Wt: <u>43.8124</u> g			
Color & Appearance:	Dish Tare Wt: <u>44.8258</u> g	Dish Tare Wt: <u>43.8124</u> g			
	Fraction Wt: <u>0.0002</u> g	Fraction Wt: <u>0.0000</u> g			
Comments:	Smpl Vol: <u>200</u> ml, Alqt: <u>150</u> ml, Factor: <u>1.333</u>	Smpl Vol: <u>200</u> ml, Alqt: <u>150</u> ml, Factor: <u>1.333</u>			
	Sample Wt: <u>0.0003</u> g	Sample Wt: <u>0.0000</u> g			
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>912</u>	Dish No: <u>314</u>		
Log No: <u>-47I</u>	Dish + Sample Wt: <u>46.5374</u> g	Dish + Sample Wt: <u>44.0673</u> g			
Color & Appearance:	Dish Tare Wt: <u>46.5097</u> g	Dish Tare Wt: <u>44.0353</u> g			
	Fraction Wt: <u>-0.0277</u> g	Fraction Wt: <u>0.0320</u> g			
Comments:	Smpl Vol: <u>455</u> ml, Alqt: <u>405</u> ml, Factor: <u>1.123</u>	Smpl Vol: <u>455</u> ml, Alqt: <u>405</u> ml, Factor: <u>1.123</u>			
	Sample Wt: <u>0.0311</u> g	Sample Wt: <u>0.0359</u> g			
Test: <u>1</u>	Run: <u>4</u>	Dish No: <u>913</u>	Dish No: <u>340</u>		
Log No: <u>-48I</u>	Dish + Sample Wt: <u>46.4597</u> g	Dish + Sample Wt: <u>47.9271</u> g			
Color & Appearance:	Dish Tare Wt: <u>46.4464</u> g	Dish Tare Wt: <u>47.9165</u> g			
	Fraction Wt: <u>0.0133</u> g	Fraction Wt: <u>0.0106</u> g			
Comments:	Smpl Vol: <u>430</u> ml, Alqt: <u>380</u> ml, Factor: <u>1.132</u>	Smpl Vol: <u>430</u> ml, Alqt: <u>380</u> ml, Factor: <u>1.132</u>			
	Sample Wt: <u>0.0151</u> g	Sample Wt: <u>0.0120</u> g			
Test: <u>1</u>	Run: <u>5</u>	Dish No: <u>914</u>	Dish No: <u>716</u>		
Log No: <u>-49I</u>	Dish + Sample Wt: <u>45.0833</u> g	Dish + Sample Wt: <u>45.6752</u> g			
Color & Appearance:	Dish Tare Wt: <u>45.0650</u> g	Dish Tare Wt: <u>45.6417</u> g			
	Fraction Wt: <u>0.0183</u> g	Fraction Wt: <u>0.0335</u> g			
Comments:	Smpl Vol: <u>425</u> ml, Alqt: <u>375</u> ml, Factor: <u>1.133</u>	Smpl Vol: <u>425</u> ml, Alqt: <u>375</u> ml, Factor: <u>1.133</u>			
	Sample Wt: <u>0.0207</u> g	Sample Wt: <u>0.0380</u> g			

Note: Factor = Sample Volume/Aliquot Volume Blank Solvent Wt: 0.0003 g

	RUN <u>0</u>	RUN <u>3</u>	RUN <u>4</u>	RUN <u>5</u>
Results of Solvent Phase g	<u>0.0003</u>	<u>0.0308</u>	<u>0.0148</u>	<u>0.0204</u>
Results of Aqueous Phase g	<u>0.0000</u>	<u>0.0359</u>	<u>0.0120</u>	<u>0.0380</u>



INTERPOLL LABORATORIES, INC.

(612) 786-6020

Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash

EPA Method 29 Probe Wash

EPA Method 202 Cup & Tube Wash

Job LR Newbury
 Date Submitted 8-29-06
 Date of Analysis 8-29-06

Source/Site DRYING TUBE OUTLET
 Test No. 1
 Technician SLB

Transport Leakage None _____ ml


Solvent Acetone

Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>1</u>
Log No: <u>8201-44P</u>		Dish + Sample Wt: <u>60.4727</u> g
Volume of Solvent <u>115</u> ml		Dish Tare Wt: <u>60.4724</u> g
*Solvent Residue _____ ug/ml		Sample Wt: <u>.0003</u> g
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>77</u>
Vol. of Solvent <u>250</u> ml		Dish + Sample Wt: <u>64.1200</u> g
Log Number <u>-45P</u>		Dish Tare Wt: <u>64.1087</u> g
Comments		Sample Wt: <u>.0113</u> g
Test: <u>1</u>	Run: <u>4</u>	Dish No: <u>85</u>
Vol. of Solvent <u>250</u> ml		Dish + Sample Wt: <u>73.9613</u> g
Log Number <u>-46P</u>		Dish Tare Wt: <u>73.9514</u> g
Comments		Sample Wt: <u>.0099</u> g
Test: <u>1</u>	Run: <u>5</u>	Dish No: <u>87</u>
Vol. of Solvent <u>160</u> ml		Dish + Sample Wt: <u>73.3628</u> g
Log Number <u>-47P</u>		Dish Tare Wt: <u>73.3532</u> g
Comments		Sample Wt: <u>.0094</u> g

*Solvent Residue 2.61 ug/ml = [(Sample Wt. .0003g) (10⁶)]/Vol. of Sol. 115 ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

✓SLB

	RUN <u>0</u>	RUN <u>3</u>	RUN <u>4</u>	RUN <u>5</u>
Results of Solvent Rinse g		<u>0.0106</u>	<u>0.0092</u>	<u>0.0092</u>



	A	B	C	D	E	F	G	H	I	J
19	EPA Method 202 Calculations									
20	Job: LOUISIANA PACIFIC - NEWBERRY									
21	Date: 27-Aug-96									
22	E-Tube Outlet									
23		Vic	Sulfate	MC	MI	MO	MI	MO	MI	MO
24	RUN	(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)
25	1	455	3.49E-04	0.03	35.9	35.87	31.1	0.3	66.67	0.066670782
26	2	430	2.81E-04	0.02	12	11.98	15.1	0.3	26.78	0.026777767
27	3	425	2.50E-04	0.02	38	37.98	20.7	0.3	58.38	0.05838045
28										
29										
30	EPA Method 201A/202 Totals									
31										
32		Probe	Filter	CPM	Total					
33	RUN	(mg)	(mg)	(mg)	(mg)					
34	1	10.6	18.1	66.67	95.37078					
35	2	9.2	11.4	26.78	47.37777					
36	3	9.2	13.4	58.38	80.98045					

REVIEWED

(61) 786 602

Impinger Catch Data Reporting Sheet

Protocol: Minnesota Wisconsin Iowa Method 202 Other

Job: LP/Newberry Source/Site: Dryer RT0 / Stack

Date Submitted: 8-30-96 Test No. 1


Date of Analysis: 9-5-96 Technician: [Signature] B.D.

		Solvent Phase		Aqueous Phase	
Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>864</u>	Dish No: <u>4</u>		
Log No: <u>8201-01I</u>		Dish + Sample Wt: <u>44.9330</u> g	Dish + Sample Wt: <u>47.3815</u> g		
Color & Appearance:		Dish Tare Wt: <u>44.9328</u> g	Dish Tare Wt: <u>47.3815</u> g		
		Fraction Wt: <u>0.0002</u> g	Fraction Wt: <u>0.0000</u> g		
Comments:		Smpl Vol: <u>200</u> ml, Alqt: <u>150</u> ml, Factor: <u>1.333</u>	Smpl Vol: <u>200</u> ml, Alqt: <u>150</u> ml, Factor: <u>1.333</u>		
		Sample Wt: <u>0.0003</u> g	Sample Wt: <u>0.0000</u> g		
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>867</u>	Dish No: <u>5</u>		
Log No: <u>-04I</u>		Dish + Sample Wt: <u>45.6135</u> g	Dish + Sample Wt: <u>39.2430</u> g		
Color & Appearance:		Dish Tare Wt: <u>45.6061</u> g	Dish Tare Wt: <u>39.2375</u> g		
		Fraction Wt: <u>0.0074</u> g	Fraction Wt: <u>0.0055</u> g		
Comments:		Smpl Vol: <u>415</u> ml, Alqt: <u>365</u> ml, Factor: <u>1.137</u>	Smpl Vol: <u>415</u> ml, Alqt: <u>365</u> ml, Factor: <u>1.137</u>		
		Sample Wt: <u>0.0084</u> g	Sample Wt: <u>0.0062</u> g		
Test: <u>1</u>	Run: <u>4</u>	Dish No: <u>869</u>	Dish No: <u>6</u>		
Log No: <u>-05I</u>		Dish + Sample Wt: <u>47.4006</u> g	Dish + Sample Wt: <u>48.2792</u> g		
Color & Appearance:		Dish Tare Wt: <u>47.3962</u> g	Dish Tare Wt: <u>48.2726</u> g		
		Fraction Wt: <u>0.0044</u> g	Fraction Wt: <u>0.0066</u> g		
Comments:		Smpl Vol: <u>430</u> ml, Alqt: <u>380</u> ml, Factor: <u>1.132</u>	Smpl Vol: <u>430</u> ml, Alqt: <u>380</u> ml, Factor: <u>1.132</u>		
		Sample Wt: <u>0.0050</u> g	Sample Wt: <u>0.0075</u> g		
Test: <u>1</u>	Run: <u>5</u>	Dish No: <u>871</u>	Dish No: <u>14</u>		
Log No: <u>-06I</u>		Dish + Sample Wt: <u>48.8032</u> g	Dish + Sample Wt: <u>37.7667</u> g		
Color & Appearance:		Dish Tare Wt: <u>48.7995</u> g	Dish Tare Wt: <u>37.7617</u> g		
		Fraction Wt: <u>0.0037</u> g	Fraction Wt: <u>0.0050</u> g		
Comments:		Smpl Vol: <u>450</u> ml, Alqt: <u>400</u> ml, Factor: <u>1.125</u>	Smpl Vol: <u>450</u> ml, Alqt: <u>400</u> ml, Factor: <u>1.125</u>		
		Sample Wt: <u>0.0042</u> g	Sample Wt: <u>0.0056</u> g		

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. 0.0003 g

		RUN <u>0</u>	RUN <u>3</u>	RUN <u>4</u>	RUN <u>5</u>
Results of Solvent Phase	g	<u>0.0003</u>	<u>0.0081</u>	<u>0.0047</u>	<u>0.0039</u>
Results of Aqueous Phase	g	<u>0.0000</u>	<u>0.0062</u>	<u>0.0075</u>	<u>0.0056</u>



INTERPOL LABORATORIES, INC.
(612) 786-6020
Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash


Job: LP - Newbury Source/Site: Dryer RTO STACK
 Date Submitted: 8-29-96 Test No.: 1
 Date of Analysis: 9-20-96 Technician: SW
 Transport Leakage None _____ ml Solvent: Acetone

Test: <u>1</u>	Run: <u>0</u>	Dish No: <u>40</u>
Log No: <u>8201-012</u>		Dish + Sample Wt: <u>41.2746</u> g
Volume of Solvent: <u>125</u> ml		Dish Tare Wt: <u>41.2742</u> g
*Solvent Residue: _____ ug/ml		Sample Wt: <u>1.0004</u> g
Test: <u>1</u>	Run: <u>3</u>	Dish No: <u>119</u>
Vol. of Solvent: <u>100</u> ml		Dish + Sample Wt: <u>47.7218</u> g
Log Number: <u>-022</u>		Dish Tare Wt: <u>47.7686</u> g
Comments:		Sample Wt: <u>.0022</u> g
Test: <u>1</u>	Run: <u>4</u>	Dish No: <u>29</u>
Vol. of Solvent: <u>130</u> ml		Dish + Sample Wt: <u>48.8920</u> g
Log Number: <u>-012</u>		Dish Tare Wt: <u>48.8891</u> g
Comments:		Sample Wt: <u>.0029</u> g
Test: <u>1</u>	Run: <u>5</u>	Dish No: <u>793</u>
Vol. of Solvent: <u>150</u> ml		Dish + Sample Wt: <u>45.9572</u> g
Log Number: <u>-042</u>		Dish Tare Wt: <u>45.9555</u> g
Comments:		Sample Wt: <u>.0017</u> g

*Solvent Residue 3.20 ug/ml = [(Sample Wt. .0004 g) (10⁶)]/Vol. of Sol. 125 ml
 EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

SW

	RUN	RUN 3	RUN 4	RUN 5
Results of Solvent Rinse		<u>0.0019</u>	<u>0.0025</u>	<u>0.0012</u>



INTERPOLL LABORATORIES, INC.
(612) 786-6020
Filter Gravimetrics Reporting Sheet

Filter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: L.F. Newburg
Date Submitted: 8-29-86
Date of Analysis: 9-20-86

Source/Site: PAPER RTD Stack
Test No.: 1
Technician: Sub

Test: 1	Run: 0	Filter No: 8620
Field Blank:		Filter Type: 4" G.F.
Log No: 8201 - 01F		Filter + Sample Wt: .9486 g
Color:		Filter Tare Wt: .9482 g
		Sample Wt: .0004 g
Test: 1	Run: 3	Filter No: 8619
Log No:		Filter Type: 4" G.F.
Color: -01F		Filter + Sample Wt: .9593 g
		Filter Tare Wt: .9678 g
		Sample Wt: .0015 g
Test: 1	Run: 4	Filter No: 8621
Log No: -05F		Filter Type: 4" G.F.
Color: -		Filter + Sample Wt: .9527 g
		Filter Tare Wt: .9511 g
		Sample Wt: .0016 g
Test: 1	Run: 3	Filter No: 8622
Log No: -06F		Filter Type: 4" G.F.
Color:		Filter + Sample Wt: .9526 g
		Filter Tare Wt: .9507 g
		Sample Wt: .0019 g

VGL

	RUN 0	RUN 3	RUN 4	RUN 5
Results of Filter Analysis g		0.0015	0.0016	0.0019


	RUN	RUN	RUN	RUN
Total Mass g				

	A	B	C	D	E	F	G	H	I	J
37	EPA Method 202 Calculations									
38	Job: LOUISIANA PACIFIC - NEWBERRY									
39	Date: 27-Aug-96									
40	Dryer RTO Stack									
41		Vic	Sulfate	MC	MR	MI	MO	Mb	CPM	ENTER IN COMPUTER (g)
42	RUN	(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	
43	1	415	1.34E-04	0.01	6.2	6.19	8.4	0.3	14.29	
44	2	430	1.41E-04	0.01	7.5	7.49	5	0.3	12.19	0.012188844
45	3	450	4.13E-04	0.03	5.6	5.57	4.2	0.3	9.47	0.009465804
46										
47										
48	EPA Method 201A/202 Totals									
49		Probe	Filter	CPM	Total					
50		(mg)	(mg)	(mg)	(mg)					
51	RUN									
52	1	1.9	1.5	14.29	17.68977					
53	2	2.5	1.6	12.19	16.28884					
54	3	1.2	1.9	9.47	12.5658					

Report No. 6-8201

(612) 786-6020

Impinger Catcher Data Reporting Sheet




Protocol: Minnesota Wisconsin Iowa EPA Method 202 Other _____
 Job: LP/Newberry Source/Site: Press/Vents
 Date Submitted: 9-3-96 Test No.: 8
 Date of Analysis: 9-5-96 Technician: B.D.

		Solvent Phase		Aqueous Phase	
Test: _____	Run: _____	Dish No: _____	Dish No: _____	Dish No: _____	Dish No: _____
Log No: _____		Dish + Sample Wt: _____ g	Dish + Sample Wt: _____ g	Dish + Sample Wt: _____ g	Dish + Sample Wt: _____ g
Color & Appearance: _____		Dish Tare Wt: _____ g	Dish Tare Wt: _____ g	Dish Tare Wt: _____ g	Dish Tare Wt: _____ g
		Fraction Wt: _____ g	Fraction Wt: _____ g	Fraction Wt: _____ g	Fraction Wt: _____ g
Comments: _____		Smpl Vol: _____ ml, Alqt: _____ ml, Factor: _____	Smpl Vol: _____ ml, Alqt: _____ ml, Factor: _____	Smpl Vol: _____ ml, Alqt: _____ ml, Factor: _____	Smpl Vol: _____ ml, Alqt: _____ ml, Factor: _____
		Sample Wt: _____ g	Sample Wt: _____ g	Sample Wt: _____ g	Sample Wt: _____ g
Test: <u>8</u>	Run: <u>1</u>	Dish No: <u>873</u>	Dish No: <u>829</u>	Dish No: <u>829</u>	Dish No: <u>829</u>
Log No: <u>8201-80I</u>		Dish + Sample Wt: <u>40.4159</u> g	Dish + Sample Wt: <u>45.6938</u> g	Dish + Sample Wt: <u>45.6938</u> g	Dish + Sample Wt: <u>45.6938</u> g
Color & Appearance: _____		Dish Tare Wt: <u>40.4149</u> g	Dish Tare Wt: <u>45.6928</u> g	Dish Tare Wt: <u>45.6928</u> g	Dish Tare Wt: <u>45.6928</u> g
		Fraction Wt: <u>0.0010</u> g	Fraction Wt: <u>0.0010</u> g	Fraction Wt: <u>0.0010</u> g	Fraction Wt: <u>0.0010</u> g
Comments: _____		Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>	Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>	Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>	Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>
		Sample Wt: <u>0.0013</u> g	Sample Wt: <u>0.0013</u> g	Sample Wt: <u>0.0013</u> g	Sample Wt: <u>0.0013</u> g
Test: <u>8</u>	Run: <u>2</u>	Dish No: <u>888</u>	Dish No: <u>833</u>	Dish No: <u>833</u>	Dish No: <u>833</u>
Log No: <u>-81I</u>		Dish + Sample Wt: <u>37.9010</u> g	Dish + Sample Wt: <u>46.3349</u> g	Dish + Sample Wt: <u>46.3349</u> g	Dish + Sample Wt: <u>46.3349</u> g
Color & Appearance: _____		Dish Tare Wt: <u>37.9000</u> g	Dish Tare Wt: <u>46.3340</u> g	Dish Tare Wt: <u>46.3340</u> g	Dish Tare Wt: <u>46.3340</u> g
		Fraction Wt: <u>0.0010</u> g	Fraction Wt: <u>0.0009</u> g	Fraction Wt: <u>0.0009</u> g	Fraction Wt: <u>0.0009</u> g
Comments: _____		Smpl Vol: <u>185</u> ml, Alqt: <u>135</u> ml, Factor <u>1.370</u>	Smpl Vol: <u>185</u> ml, Alqt: <u>135</u> ml, Factor <u>1.370</u>	Smpl Vol: <u>185</u> ml, Alqt: <u>135</u> ml, Factor <u>1.370</u>	Smpl Vol: <u>185</u> ml, Alqt: <u>135</u> ml, Factor <u>1.370</u>
		Sample Wt: <u>0.0014</u> g	Sample Wt: <u>0.0012</u> g	Sample Wt: <u>0.0012</u> g	Sample Wt: <u>0.0012</u> g
Test: <u>8</u>	Run: <u>3</u>	Dish No: <u>890</u>	Dish No: <u>836</u>	Dish No: <u>836</u>	Dish No: <u>836</u>
Log No: <u>-82I</u>		Dish + Sample Wt: <u>36.0849</u> g	Dish + Sample Wt: <u>45.0731</u> g	Dish + Sample Wt: <u>45.0731</u> g	Dish + Sample Wt: <u>45.0731</u> g
Color & Appearance: _____		Dish Tare Wt: <u>36.0840</u> g	Dish Tare Wt: <u>45.0718</u> g	Dish Tare Wt: <u>45.0718</u> g	Dish Tare Wt: <u>45.0718</u> g
		Fraction Wt: <u>0.0009</u> g	Fraction Wt: <u>0.0013</u> g	Fraction Wt: <u>0.0013</u> g	Fraction Wt: <u>0.0013</u> g
Comments: _____		Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>	Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>	Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>	Smpl Vol: <u>205</u> ml, Alqt: <u>155</u> ml, Factor <u>1.323</u>
		Sample Wt: <u>0.0012</u> g	Sample Wt: <u>0.0017</u> g	Sample Wt: <u>0.0017</u> g	Sample Wt: <u>0.0017</u> g

Note: Factor = Sample Volume/Aliquot Volume

Blank Solvent Wt. 0.0003 g

	RUN	RUN 1	RUN 2	RUN 3
Results of Solvent Phase g		<u>0.0010</u>	<u>0.0011</u>	<u>0.0009</u>
Results of Aqueous Phase g		<u>0.0013</u>	<u>0.0012</u>	<u>0.0017</u>



INTERPOLL LABORATORIES, INC.

(612) 786-6020

Solvent Rinse Data Reporting Sheet

EPA Method 5 Probe Wash EPA Method 29 Probe Wash EPA Method 202 Cup & Tube Wash

Job: L.P. New Bury Source/Site: Pearson Vents
 Date Submitted: 8-29-96 Test No.: 6
 Date of Analysis: 9-20-96 Technician: SCB
 Transport Leakage None _____ ml Solvent: Acetone

Test: <u>8</u>	Run: <u>0</u>	Dish No:	
Log No:		Dish + Sample Wt:	<u>VOID</u> g
Volume of Solvent	ml	Dish Tare Wt:	g
*Solvent Residue	ug/ml	Sample Wt:	g
Test: <u>8</u>	Run: <u>1</u>	Dish No: <u>35</u>	
Vol. of Solvent	<u>110</u> ml	Dish + Sample Wt:	<u>51.0981</u> g
Log Number		Dish Tare Wt:	<u>51.0912</u> g
Comments		Sample Wt:	<u>.0069</u> g
Test: <u>8</u>	Run: <u>2</u>	Dish No: <u>738</u>	
Vol. of Solvent	<u>110</u> ml	Dish + Sample Wt:	<u>44.9368</u> g
Log Number		Dish Tare Wt:	<u>44.9207</u> g
Comments		Sample Wt:	<u>.0161</u> g
Test: <u>8</u>	Run: <u>3</u>	Dish No: <u>765</u>	
Vol. of Solvent	<u>90</u> ml	Dish + Sample Wt:	<u>44.1959</u> g
Log Number		Dish Tare Wt:	<u>44.1905</u> g
Comments		Sample Wt:	<u>.0054</u> g

*Solvent Residue _____ ug/ml = [(Sample Wt. _____ g) (10⁶)] / Vol. of Sol. _____ ml

EPA-M5 Acetone Residue Blank Spec. ≤ 7.8 ug/ml

VSU

	RUN	RUN 1	RUN 2	RUN 3
Results of Solvent Rinse g		<u>0.0063</u>	<u>0.0155</u>	<u>0.0049</u>



INTERPOLL LABORATORIES, INC.
 (612) 786-6020
Filter Gravimetrics Reporting Sheet

Filter Type: EPA Method 5 EPA Method 29 EPA Method 202 Other _____

Job: LP - Newburg Source/Site: Press VENTS
 Date Submitted: 8-29-96 Test No.: 8
 Date of Analysis: 9-20-96 Technician: SLB

Test: <u>8</u>	Run: <u>1</u>	Filter No: <u>8457</u>
Field Blank: <u>8201-80F</u>		Filter Type: <u>4" G.F.</u>
Log No:		Filter + Sample Wt: <u>9.521</u> g
Color:		Filter Tare Wt: <u>.9472</u> g
		Sample Wt: <u>.0049</u> g
Test: <u>8</u>	Run: <u>2</u>	Filter No: <u>8465</u>
Log No: <u>-81F</u>		Filter Type: <u>4" G.F.</u>
Color:		Filter + Sample Wt: <u>.9585</u> g
		Filter Tare Wt: <u>.9569</u> g
		Sample Wt: <u>.0016</u> g
Test: <u>8</u>	Run: <u>3</u>	Filter No: <u>8471</u>
Log No: <u>-82F</u>		Filter Type: <u>4" G.F.</u>
Color:		Filter + Sample Wt: <u>.9975</u> g
		Filter Tare Wt: <u>.9932</u> g
		Sample Wt: <u>.0043</u> g
Test:	Run:	Filter No:
Log No:		Filter Type:
Color:		Filter + Sample Wt: g
		Filter Tare Wt: g
		Sample Wt: g

VSL

	RUN	RUN <u>1</u>	RUN <u>2</u>	RUN <u>3</u>
Results of Filter Analysis g		<u>0.0049</u>	<u>0.0016</u>	<u>0.0043</u>

	RUN	RUN	RUN	RUN
Total Mass g				

	A	B	C	D	E	F	G	H	I	J
55	EPA Method 202 Calculations									
56	Job: LOUISIANA PACIFIC - NEWBERRY									
57	Date: 27-Aug-96									
58	Press Vents									
59		Vic	Sulfate	MC	Mf	Ml	MO	Mb	CPM	ENTER IN
60	RUN	(ml)	(mg/ml)	(mg)	(mg)	(mg)	(mg)	(mg)	(mg)	COMPUTER
61	1	205	2.26E-04	0.01	1.3	1.29	1.3	0.3	2.29	(g)
62	2	185	2.00E-04	0.01	1.2	1.19	1.4	0.3	2.29	0.002291475
63	3	205	1.77E-04	0.01	1.7	1.69	1.2	0.3	2.59	0.002293192
64										0.002593324
65										
66	EPA Method 201A/202 Totals									
67		Probe	Filter	CPM	Total					
68		(mg)	(mg)	(mg)	(mg)					
69	RUN									
70	1	6.3	4.9	2.29	13.49148					
71	2	15.5	1.6	2.29	19.39319					
72	3	4.9	4.3	2.59	11.79332					

Report No. 6-8201

9/12/96

Interpoll Laboratories, Inc.
(612)786-6020

Ion Chromatography Laboratory

DIONEX MODEL 4000i WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: MB

Date of Analysis: 9/12/96

Job: 1D020/LP Newberry

Source: Dryer RTO

Site: Stock

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient (List program below)

REVIEWED

Gradient Program	Time (Min.)									
Eluent	0.0									
* A										
* B										

SEP 10 1996

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate	
Imp. Catch T ₁₂	8201-01	200	1.0	0.143	28.6	0.00060	
+ Imp. Rinse T ₁₂	-04	415 2134	1.0	0.134	55.6	0.0012	
Drier Stock C-Tube outlet	T ₁₂	430	1.0	0.141	60.6	0.0013	
	T ₁₂ V	450	1.0	0.413	186	0.0039	
	T ₁₂	8201-44	200	1.0	0.0764	15.3	0.00032
	T ₁₂	-47	455	1.0	0.349	159	0.0033
	T ₁₂	430	1.0	0.281	121	0.0025	
	T ₁₂ V	425	1.0	0.250	106	0.0022	

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
 meq = Total ug / 48000

LSC-08RR

9/13/96

Ion Chromatography Laboratory

DIONEX MODEL 4000i WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: MLC

Date of Analysis: 9/16/96 9/12/96

Job: ID020 / Newberry

Source: Dryer 1^o

Site: Exhaust

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	ml/min	12.5 mM Sulfuric Acid
X AS4A	2 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient (List program below)

Gradient Program	Time (Min)
Eluent	0.0
% A	
% B	

REVIEWED

SEP 10 1996

[Signature]

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
Imp. Catch T ₁₆₀	8201-62	200	1.0	0.120	24	0.00050
+ 1 ^o Rinse	T ₁₆₃ 65	330 330	1.0	0.695	229	0.0048
Dryer Primery Cyclone outlet	T ₁₂₄ 66	390	1.0	0.511	199	0.0041
	T ₁₆₅ 67	370	1.0	1.23	455	0.0095
	T ₁₆₁ 80	205	1.0	0.226	46.3	0.00096
Prep Joints	T ₁₆₂ 81	185	1.0	0.200	185	0.0009 0.0009 9/16/96
	T ₁₆₃ 82	205	1.0	0.177	36.3	0.00076

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

LSC-08RR

EPA Method 10 NDIR Analysis

Job Name LP-Newberry
 Source Dryer Primary Cyclone Exhaust
 Date of Analysis 9-6-96
 Technician SLB

NDIR Analyzer:

Range: 0 - 1000 PPM
 Flow rate: 1000 cc/min

Fuji ACS Model 3300
 Mon. Lab Model 8310
 Dasibi Model 3003

Pretest Calibration						
	Concentration		Reading		Vendor	Cyl. No.
Zero Gas	0	PPM	0	PPM	TCD	MM2356B
Upscale Gas	300.8	PPM	300	PPM	TCD	ALMD14239
Upscale Gas	590	PPM	592	PPM	TCD	HA 3980
Upscale Gas		PPM		PPM		

Sample Description Test/Run	Sample Log No.	CO Conc. (PPM, Dry)		
		Dilution Factor	Reading	Actual PPM
Y3	8201-68	-	734	734
Y4	-69	-	337	337
Y5	-70	-	406	406

Post-Test Calibration				
	Conc.		Reading	
Zero Gas	0	PPM	0	PPM
Upscale Gas	300.8	PPM	300	PPM
Upscale Gas	590.	PPM	591	PPM
Upscale Gas		PPM		PPM

Note 1: If sample dilution is required, the sample is diluted with CO-free gas prior to analysis.
 Note 2: The Fuji ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000: 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000: 1 and thus CO₂ removal prior to analysis is not required.
 Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

EPA Method 10 NDIR Analysis

Job Name LP-NEWBOENY
 Source DRY & F-TURE OUTLET
 Date of Analysis 9-6-90
 Technician S-B

NDIR Analyzer: Fugl ACS Model 3300
 Mon. Lab Model 8310
 Dasibi Model 3003
 Range: 0 - 1000 PPM
 Flow rate: 1000 cc/min

Pretest Calibration						
	Concentration		Reading		Vendor	Cyl. No.
Zero Gas	0	PPM	0	PPM	TLO	MUM 235613
Upscale Gas	300.8	PPM	300	PPM	TLO	MUM 014274
Upscale Gas	590	PPM	592	PPM	TLO	HA3980
Upscale Gas		PPM		PPM		

Sample Description Test/Run	Sample Log No.	CO Conc. (PPM, Dry)		
		Dilution Factor	Reading	Actual PPM
1/3	801-50	-	665	665
1/4	-51	-	790	790
1/5	-52	-	754	754

Post-Test Calibration				
	Conc.		Reading	
Zero Gas	0	PPM	0	PPM
Upscale Gas	300.8	PPM	300	PPM
Upscale Gas	590	PPM	591	PPM
Upscale Gas		PPM		PPM

- Note 1: If sample dilution is required, the sample is diluted with CO-free gas prior to analysis.
- Note 2: The Fugl ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000: 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000: 1 and thus CO₂ removal prior to analysis is not required.
- Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

EPA Method 10 NDIR Analysis

Job Name LP - Newberry
 Source Dryer RO Stack
 Date of Analysis 9-8-96
 Technician SLB

NDIR Analyzer Fugii ACS Model 3300
 Mon. Lab Model 8310
 Dasibi Model 3003
 Range: 0 - 10000 PPM
 Flow rate: 1000 cc/min

Pretest Calibration				
	Concentration	Reading	Vendor	Cyl. No.
Zero Gas	0 PPM	0 PPM	TCO	MAN 235613
Upscale Gas	300.8 PPM	300 PPM	TCO	MAN 014279
Upscale Gas	590 PPM	592 PPM	TCO	MA 3990
Upscale Gas	PPM	PPM		

Sample Description Test/Run	Sample Log No.	CO Conc. (PPM, Dry)		
		Dilution Factor	Reading	Actual PPM
1/2	8201	—	45	45
1/3	8201	—	33	33
1/4	8201	—	41	41
1/5	8201	—	31	31

Post-Test Calibration				
	Conc.		Reading	
Zero Gas	0	PPM	0	PPM
Upscale Gas	300.8	PPM	300	PPM
Upscale Gas	590	PPM	591	PPM
Upscale Gas		PPM		PPM

- Note 1: If sample dilution is required, the sample is diluted with CO-free gas prior to analysis.
- Note 2: The Fugii ACS model 3300 has a rejection ratio for CO to CO₂ greater than 100,000: 1 and the Mon. Labs Model 8310 and Dasibi Model 3003 have rejection ratios greater than 200,000: 1 and thus CO₂ removal prior to analysis is not required.
- Note 3: The analyzer must be zeroed and spanned immediately before and after sample analysis. Additional checks may be performed between sample analyses if required.

Data Reporting Sheet
(With Regulatory Limits)

CLIENT: 10020 / LP Newberry

JOB: _____

CLIENT NO: _____

P.O. NO: _____

PROJECT MGR: _____

PHONE: _____

DATE: _____

CONTACT: _____

LABORATORY REPORT #: _____

SAMPLES COLLECTED: _____

SAMPLES RECEIVED: _____

Dryer Primary cyclone exhaust

SAMPLE I.D:

1/3	1/4	1/5	
1.G.S.	1.G.S.	1.G.S.	
8201-68	-69	-70	

SAMPLE TYPE:

LOG NO:

Invoicing Signature Report Routing

PL
Lab Mgr
InO Mgr
Org Mgr

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PARAMETER	UNITS	DET. LIMIT	REG. LIMIT	ANALYSIS DATE & INITIALS	METHOD				
Methane	ppmv	1.0		9/6/96 AWY	M-25	13.7	6.1	6.9	

Footnotes:

SEP 11 1996

In-House Comments:

Benny M. Holman

Due Date: 9/12/96

Interpoll Laboratories
(612)786-6020

Data Reporting Sheet
(With Regulatory Limits)

CLIENT: 1D020/LP Newberry

 PHONE: _____
 CONTACT: _____

JOB: _____
 CLIENT NO: _____
 P.O. NO: _____
 PROJECT MGR: _____
 DATE: _____

LABORATORY REPORT #: _____
 SAMPLES COLLECTED: _____
 SAMPLES RECEIVED: _____

SAMPLE I.D:

E-Tube outlet

1/3	1/4	1/5	
1.G.S.			
8102-50	-51	-52	

SAMPLE TYPE:

LOG NO:

Invoicing Signature Report Routing

PL	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lab Mgr	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
InO Mgr	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Org Mgr	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PARAMETER	UNITS	DET. LIMIT	REG. LIMIT	ANALYSIS DATE & INITIALS	METHOD				
<u>Methane</u>	<u>ppmV</u>	<u>1.0</u>		<u>9/12/96</u> <u>mm</u>	<u>M-25</u>	<u>10.7</u>	<u>4.9</u>	<u>2.0</u>	

REVIEW
REVIEW

SEP 11 1996

Footnotes:

In-House Comments:

Henry M. Adams

Data Reporting Sheet
(With Regulatory Limits)

CLIENT: 10020/CP Newberry

 PHONE: _____
 CONTACT: _____

JOB: _____
 CLIENT NO: _____
 P.O. NO: _____
 PROJECT MGR: _____
 DATE: _____

LABORATORY REPORT #: _____
 SAMPLES COLLECTED: _____
 SAMPLES RECEIVED: _____

Dryer PTO Stack

SAMPLE I.D.: _____
 SAMPLE TYPE: _____
 LOG NO: _____

^{ANAL} 1/3	^{ANAL} 1/4	^{ANAL} 1/5
1-G.S. →		
8201-07	-08	-09

Invoicing Signature Report Routing

PL	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lab Mgr	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
InD Mgr	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Org Mgr	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PARAMETER	UNITS	DET. LIMIT	REG. LIMIT	ANALYSIS DATE & INITIALS	METHOD			
Methane	ppmv	1.0		9/9/96 ANAL	M25	20.2	29.9	25.1

Analyzed by: _____
 SEP 11 1996

Footnotes:

In-House Comments: Runs 1,2 are invalid per samples (do not analyze) ANAL

Data Reporting Sheet
(With Regulatory Limits)

CLIENT: 1D020/LP Newberry

JOB: _____

CLIENT NO: _____

P.O. NO: _____

PROJECT MGR: _____

PHONE: _____

DATE: _____

CONTACT: _____

LABORATORY REPORT #: _____

SAMPLES COLLECTED: _____

SAMPLES RECEIVED: _____

Press vents

SAMPLE I.D:

5/1	5/2	5/3	
1.G.S.	→		
8201-77	-78	-79	

SAMPLE TYPE:

LOG NO:


Invoicing Signature Report Routing

PL
Lab Mgr
InO Mgr
Org Mgr

PARAMETER	UNITS	DET. LIMIT	REG. LIMIT	ANALYSIS DATE & INITIALS	METHOD				
<u>Methane</u>	<u>ppmv</u>	<u>1.0</u>		<u>9/10/96</u> <u>AWA</u>	<u>M-25</u>	<u>2.3</u>	<u>2.0</u>	<u>3.2</u>	

Footnotes:

In-House Comments:



INTERPOLL LABORATORIES INC.

Formaldehyde Results Using EPA Method 0011
For Dept. 20/Louisiana-Pacific, Newberry, MI
Collected 8/27 and 8/28/96

	Field Spike			Test: 3				Source: Dryer RTO Stack
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3	
Log #		(8201-10)		(8201-11)	(8201-12)	(8201-13)	(8201-14)	
Mass (ug)*	750	610	81.3	0.95	1800	2400	2400	

	Field Spike			Test: 3				Source: Primary Cyclone Dryer Exhaust
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3	
Log #		(8201-20)		(8201-19)	(8201-21)	(8201-22)	(8201-23)	
Mass (ug)*	750	570	76.0	2.2	6600	6000	11000	

	Field Spike			Test: 7				Source: Press Vents
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3	
Log #		(8201-28)		(8201-27)	(8201-29)	(8201-30)	(8201-31)	
Mass (ug)*	750	670	89.3	2.4	8000	1900	4100	

	Field Spike			Test: 3				Source: E-Tube Outlet
	Actual	Found	% Recovery	Run 0	Run 1	Run 2	Run 3	
Log #		(8201-54)		(8201-53)	(8201-55)	(8201-56)	(8201-57)	
Mass (ug)*	750	540	72.0	12	36000	34000	33000	

* = Total Mass of formaldehyde in the sample in ug.

Reviewed by:



David J. Schneider, Manager
Chemistry Department

INTERPOLL LABORATORIES INC.

4,4-Methylenebis(phenyl isocyanate) Results
 For Dept. 20/Louisiana-Pacific, Newberry, MI
 Collected 8/29/96

Item	Field Spike			Test: 5			Source: Press Vents	
	Actual	Found	% Rec.	Run 0	Run 00	Run 1	Run 2	Run 3
<i>EPA Draft Method 1,2-PP</i>								
Log #		8201-73		8201-72	8201-71	8201-74	8201-75	8201-76
MDI (ug)*	297	280	94.3	8.0	< 6.2	310	270	57

* = Total mass of MDI in the sample in ug.

Reviewed by:



David J. Schneider, Manager
 Chemistry Department

Interpoll Laboratories, Inc.

(612)786-6020

Impinger Catch Preparation Work

Order Form

Project Name: LP/Newberry

Order Date: 8-16-96

Date Required: 8-23-96

Delivery Date: 8-21-96

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
MDI 95204-83-A	297 µg/mL	1.0 mL	297 µg

SPECIAL REQUIREMENTS

Spiked 8-21-96 B.D.
Verified & YRS 8/21/96

**Please return this form with the samples.

LOA-34
g:/chem/excel/forms/loa-34.xls

Interpoll Laboratories, Inc.

(612)786-6020

Impinger Catch Preparation Work

Order Form

Project Name: LP/Newberry

Order Date: 8-16-96

Date Required: 8-23-96

Delivery Date: 8-22-96

Nature of Spiking Material	Spike Concentration	Spike Volume	Total Mass of Spike
Formaldehyde in ACN #95082-59-A	3.75 mg/mL	200 µl	750 µg

SPECIAL REQUIREMENTS

Prepared four (4) Field Spikes B.D. 8-22-96
Verified 8/22/96 YJT

**Please return this form with the samples.

LOA-34
g:/chem/excel/forms/loa-34.xls

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Newberry, III Source Dyer Primary Cyclone Site Date of Test 8-27-96 Test No. 1

Log No. 2201
No. of Runs 5

No. Items	Sample Type	Analysis	Sequence No.	Comments
5+1	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		Do not Analyze Runs 1+2 see A. Luscantel
5+1	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		Do not Analyze Runs 1+2 see A. Luscantel
5+1	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases		Do not Analyze Runs 1+2 see A. Luscantel
4	Integrated Gas: <input checked="" type="checkbox"/> Petlar Bag	<input type="checkbox"/> EPA M-3 <input checked="" type="checkbox"/> Methane <input type="checkbox"/> EPA M-7A		Do not Analyze Run 2
-	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-10		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Per S-0163		
-	Particle Sizing:	<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> Cascade Imp		
-	Miscellaneous:	<input type="checkbox"/>		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood Waste Wood Waste Oil Natural Gas
 Dust No. 2 ORDF
 Bark No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Gabeler / Interpoll Labs</u>	<u>CG</u> <u>FLI</u>	<u>9/3/96</u> <u>1000</u>


INTERPOL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer LP Source S. BARNVILLE Date of Test 8-27-96 Site OUTLET Log No. 8201
 No. of Runs 5

No. Items	Sample Type	Analysis	Sequence No.	Comments
6	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water	<input checked="" type="checkbox"/> EPA M-5 <input checked="" type="checkbox"/> EPA M-29 (ZINC)	1/0-5	RUN #1 LOG #NO HOLD RUN #2 11 11 11
6	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input checked="" type="checkbox"/> EPA M-29 (ZINC) <input type="checkbox"/> EPA M-201A	1/0-5	11 11
6	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26	1/0-5	11 11
3	Integrated Gas: <input checked="" type="checkbox"/> Filter Bag Oxides of Nitrogen: <input type="checkbox"/> _____ Fuel Lab: <input type="checkbox"/> Fuel Sample Particle Sizing: <input type="checkbox"/> _____ Miscellaneous: <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input checked="" type="checkbox"/> METAL-5 (3-5) <input type="checkbox"/> EPA M-7A <input type="checkbox"/> Per S-0163 <input checked="" type="checkbox"/> EPA M-10 <input checked="" type="checkbox"/> CD RUN 3+4 only	1/3-5	

Fuel Type: Coal: Bituminous Wood; Wood Waste Natural Gas
 Anthracite Dust No. 2 RDF
 Lignite Bark No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Oni / JUE</u>	8/30/96

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer BA Source Dryer (BTD) Street Site 17th & Log No. 8201
 Date of Test 8-27-96 Test No. 2 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
6	Probe Wash: <input checked="" type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29	<input type="checkbox"/> EPA M-201A <input type="checkbox"/> _____
6	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> 55 Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A	<input type="checkbox"/> EPA M-17
6 Imp 6 Rinse	Inpingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> MeCl ₂ (2-pkts)	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,0 <input type="checkbox"/> Acid Cases	<input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____
4	Integrated Gas: <input checked="" type="checkbox"/> Cedar Bag	<input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input checked="" type="checkbox"/> Methane & Zinc	<input type="checkbox"/> EPA M-10 <input type="checkbox"/> _____
1	Oxides of Nitrogen:		<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____	
1	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163	
1	Particle Sizing:		<input type="checkbox"/> X-Ray Scdgraph <input type="checkbox"/> _____	<input type="checkbox"/> Cascade Imp
1	Miscellaneous:	<input checked="" type="checkbox"/> MeCl ₂	<input checked="" type="checkbox"/> Imp Rinse (m-202)	

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas IRDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Carl / LLC</u>	<u>8/30/96</u>
	<u>0900</u>	

INTERPOLL LABORATORIES, INC.


(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Newberry Source Asst Primary Cyclor Exhaust Site Exhaust Log No. 8201
 Date of Test 8-28-96 Test No. 3 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: <input type="checkbox"/> Acetone <input checked="" type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> EPA M-17		
5	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> IN NaOH <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6.B <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input checked="" type="checkbox"/> Normaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____		
3	Integrated Gas: <input checked="" type="checkbox"/> Cellar Bag <input type="checkbox"/> _____ Oxides of Nitrogen: <input type="checkbox"/> _____	<input checked="" type="checkbox"/> EPA M-3 <input type="checkbox"/> _____ <input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____ <input type="checkbox"/> Per S-0163		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> _____ <input type="checkbox"/> Cascade- Imp <input type="checkbox"/> _____		
	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> Waste Oil <input type="checkbox"/> No. 2 <input type="checkbox"/> No. 6		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Oil: Wood Waste Dust Bark
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation 	Accepted by/Affiliation <u>Interpoll Labs</u>	Date <u>8-30-96</u>
--	--	------------------------

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job CP number 4 Source OUTLET


Field Engineer 5-677-9000 Date of Test 8-28-96 Test No. 3

Log No. 9201

No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
1	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂	<input type="checkbox"/> DI Water <input type="checkbox"/> _____		
1	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass		
7	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 4-DNPH	<input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	3/1-3	150245 1 BLANK 5 REAPP (ATM)
	Integrated Gas: <input type="checkbox"/> Tedlar Bag	<input type="checkbox"/> _____		
	Oxides of Nitrogen:			
	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> Aggregate		
	Particle Sizing:			
3	Miscellaneous:	<input checked="" type="checkbox"/> METAL-CL	3/1-3	

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation	Accepted by/Affiliation	Date
	<u>Carl / ICI</u>	<u>8/30/96</u>
		<u>1100</u>

INTERPOL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer Bob CP Newberry Source Dryer RTO Site SOAIC Log No. 8201
 Date of Test 8-28-96 Test No. 3 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: Top R. side <input type="checkbox"/> Acetone <input checked="" type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass		
6	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> IN NaOH <input checked="" type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10 <input type="checkbox"/> EPA M-7A <input type="checkbox"/> Per S-0163		
1	Integrated Gas: <input type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____			
1	Oxides of Nitrogen: <input type="checkbox"/> _____			
1	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate			
1	Particle Sizing: <input type="checkbox"/> _____	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
1	Miscellaneous: <input type="checkbox"/> _____			

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation <u>Bob Newberry</u>	Accepted by/Affiliation <u>CP Newberry</u>	Date <u>8/30/96</u>
--	---	------------------------

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Newberry Source Press Date of Test 8-29-96 Site Vent Test No. 5 Log No. 0201 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
1	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		<u>Added to sample runs</u>
1	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
1 2 3 3 3	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input checked="" type="checkbox"/> 1-2 PP	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input type="checkbox"/> Formaldehyde <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input checked="" type="checkbox"/> MOI		
3	Integrated Gas: <input type="checkbox"/> Medlar Bag	<input type="checkbox"/> EPA M-3 <input checked="" type="checkbox"/> Methane <input type="checkbox"/> EPA M-7A		
1	Oxides of Nitrogen:	<input type="checkbox"/> Per S-0163		
1	Fuel Lab: <input type="checkbox"/> Fuel Sample	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp		
1	Particle Sizing:			
1	Miscellaneous: <input type="checkbox"/>			

Fuel Type: NA Coal: Bituminous Wood Waste Wood Oil: Waste Oil Natural Gas
 Anthracite Dust No. 2 IRDF
 Lignite Bark No. 6 No. 6

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mark Siedler / Interpoll Labs</u>	<u>CSJ / ILS</u>	<u>9/3/96 1000</u>

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Newberry Source Press Date of Test 8-27-96 Site Vents Test No. 7 Log No. 8201 No. of Runs 3

No. Items	Sample Type	Analysis	Sequence No.	Comments
	Probe Wash: <input type="checkbox"/> Acetone <input type="checkbox"/> MeCl ₂ <input type="checkbox"/> DI Water <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
	Filter: <input type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble <input type="checkbox"/> Pallflex <input type="checkbox"/> 2.5" Glass	<input type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		
5	Impingers: <input type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input checked="" type="checkbox"/> 2,4-DNPH <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ /H ₂ O ₂ <input type="checkbox"/> KMnO ₄ /H ₂ SO ₄ <input type="checkbox"/> _____	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases <input type="checkbox"/> IA Protocol <input checked="" type="checkbox"/> Formaldehyde 00 K <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-26 <input type="checkbox"/> _____		
	Integrated Gas: <input type="checkbox"/> Tedlar Bag <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10		
	Oxides of Nitrogen: <input type="checkbox"/> _____	<input type="checkbox"/> EPA M-7A <input type="checkbox"/> _____		
	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
	Particle Sizing: <input type="checkbox"/> _____	<input type="checkbox"/> X-Ray Sdgraph <input type="checkbox"/> Cascade Imp <input type="checkbox"/> _____		
	Miscellaneous: <input type="checkbox"/> _____	<input type="checkbox"/> _____		

Fuel Type: Coal: Bituminous Anthracite Lignite
 Wood: Wood Waste Dust Bark
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF _____

Relinquished by/Affiliation <u>[Signature]</u> Interpoll	Accepted by/Affiliation <u>[Signature]</u> ILI	Date 8-30-96
---	---	-----------------

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Sample Chain of Custody

Job Field Engineer L.P. Newberry, JR Source Press Site Units Log No. 8201
M. Kaufel Date of Test 8-29-96 Test No. 8 No. of Runs 3


No. Items	Sample Type	Analysis	Sequence No.	Comments
3	Probe Wash: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> MeCl ₂	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29		<u>2u</u>
3	Filter: <input checked="" type="checkbox"/> 4" Glass <input type="checkbox"/> SS Thimble	<input checked="" type="checkbox"/> EPA M-5 <input type="checkbox"/> EPA M-29 <input type="checkbox"/> EPA M-201A		<u>2u</u>
3	Impingers: <input checked="" type="checkbox"/> DI Water <input type="checkbox"/> 3% H ₂ O ₂ <input type="checkbox"/> 1N NaOH <input type="checkbox"/> 2,4-DNPH	<input type="checkbox"/> MN Protocol <input type="checkbox"/> WI Protocol <input checked="" type="checkbox"/> EPA M-202 <input type="checkbox"/> EPA M6,8 <input type="checkbox"/> Acid Gases		
3	Integrated Gas: <input type="checkbox"/> N ₂ / N ₂ Bag	<input type="checkbox"/> EPA M-3 <input type="checkbox"/> EPA M-10		<u>Ambient Air</u>
-	Oxides of Nitrogen:	<input type="checkbox"/> EPA M-7A		
-	Fuel Lab: <input type="checkbox"/> Fuel Sample <input type="checkbox"/> Aggregate	<input type="checkbox"/> Per S-0163		
-	Particle Sizing:	<input type="checkbox"/> X-Ray Scigraph <input type="checkbox"/> Cascade Imp		
-	Miscellaneous:	<input type="checkbox"/>		

Fuel Type: NA Coal: Bituminous Anthracite Lignite
 Oil: Waste Oil No. 2 No. 6
 Misc: Natural Gas RDF

Relinquished by/Affiliation	Accepted by/Affiliation	Date
<u>Mash. Gaubert / Interpoll Labs</u>	<u>Q.S. / I.L.L.</u>	<u>8/31/96 1000</u>

APPENDIX E

COMPUTER DATALOGGER PRINTOUTS



L.P.
 NEWBERRY, MI
 DRYER PRIMARY CYCLONE
 EXHAUST
 TEST 1 / RUN 3 (1)
 16:46:00 - 17:56:00

NOX PPM	O2 %	CO PPM	CO2 %	THC PPM
21.05	15.26	880.98	4.44	107.27
22.54	15.30	771.92	4.45	110.44
25.91	15.47	696.89	4.39	99.86
25.95	15.52	616.98	4.39	95.55
26.48	15.21	767.61	4.72	114.10
27.05	15.29	941.03	4.62	104.66
31.98	15.40	742.63	4.58	100.51
29.58	15.30	865.92	4.68	110.61
28.07	15.35	832.39	4.64	109.87
29.17	15.74	757.52	4.52	99.48
28.21	16.11	769.81	4.90	105.72
30.82	16.16	880.00	4.57	119.88
29.39	16.36	911.17	4.32	115.41
30.76	16.31	855.50	4.24	110.28
31.04	16.22	838.82	4.33	115.41
30.61	16.26	848.47	4.36	110.77
29.94	16.09	896.60	4.78	115.98
20.34	16.09	1000.44	4.89	119.80
33.05	16.01	983.19	4.90	118.34
37.16	15.94	1062.53	4.97	120.37
39.32	16.21	857.13	4.74	107.27
41.07	16.22	862.31	4.75	101.90
41.78	16.05	880.97	4.93	113.86
46.62	16.12	946.65	4.85	114.76
48.98	15.99	914.34	5.02	117.77
49.60	15.96	1108.35	5.04	122.32
49.21	16.15	941.85	4.89	107.51
49.13	16.10	848.99	4.85	112.64
48.42	15.98	977.41	4.80	115.33
72.40	15.89	944.37	4.81	106.78
61.21	15.86	1033.97	4.78	119.15
52.46	15.93	1038.12	4.64	125.74
48.50	15.95	1007.93	4.53	118.99
48.42	16.00	920.52	4.45	117.03
41.01	15.81	1038.93	4.52	129.32
41.25	15.88	1105.01	4.41	122.81
40.77	15.83	1080.19	4.43	123.22
39.79	15.88	1011.26	4.43	122.98
40.30	15.76	1076.86	4.56	127.86
38.22	15.81	1052.20	4.88	115.16
37.43	15.83	984.98	4.67	121.43
37.08	16.00	920.04	4.50	113.54
38.67	16.03	898.88	4.50	114.02
37.10	16.07	691.28	4.48	110.12
37.67	16.05	694.04	4.46	106.70
37.25	16.13	808.27	4.42	100.68
37.98	16.05	633.90	4.51	105.89
38.65	15.89	811.15	4.62	113.54
39.89	15.96	817.09	4.57	108.16
40.97	16.01	715.45	4.52	108.57
50.80	15.96	710.08	4.59	109.22
53.97	15.85	875.52	4.66	118.79
51.91	15.95	792.35	4.59	111.58
46.73	16.10	686.64	4.44	103.93
47.64	15.81	793.65	4.75	122.41
46.33	15.89	1062.37	4.64	120.21
46.32	15.87	975.46	4.54	112.56
39.63	16.39	493.93	4.18	93.92
57.86	16.10	507.76	4.90	110.85
51.90	16.11	830.42	4.37	109.12

AVERAGE	AVERAGE	AVERAGE	AVERAGE	AVERAGE
<u>39.70</u>	<u>15.91</u>	<u>861.31</u>	<u>4.60</u>	<u>112.67</u>

LA
 NEWBERRY, MI
 DRYER PRIMARY CYCLONE
 EXHAUST
 TEST 1 / RUN 4 (2)
 19:51:00 - 20:55:00

NOX PPM	O2 %	CO PPM	CO2 %	THC PPM
28.40	16.67	322.05	4.40	76.75
27.79	16.77	281.61	4.29	73.33
27.01	16.73	255.82	4.34	75.21
26.99	16.66	299.35	4.29	72.28
28.84	16.63	311.48	4.35	79.19
31.98	16.51	339.31	4.38	85.70
30.41	16.48	359.41	4.22	81.55
26.95	16.50	311.64	4.19	82.12
25.08	16.50	344.35	4.23	84.73
23.86	16.37	376.74	4.28	86.84
24.86	16.41	354.85	4.23	83.10
25.81	16.20	418.00	4.40	114.92
25.28	16.22	440.95	4.34	86.88
25.30	16.29	425.08	4.24	91.32
25.45	16.20	468.05	4.33	149.26
28.44	16.01	693.07	4.47	145.03
28.68	16.28	574.82	4.20	115.00
28.90	16.62	322.62	3.93	89.45
27.58	16.48	255.24	4.05	88.47
26.71	16.41	293.90	4.09	79.93
27.58	16.38	299.92	4.13	85.13
29.29	16.29	332.55	4.22	88.98
30.02	16.49	314.32	4.02	85.62
31.26	16.58	256.14	3.95	84.32
32.81	16.73	207.31	3.79	73.82
32.22	16.58	213.17	3.96	75.45
34.09	16.54	235.79	3.99	79.60
32.95	16.34	311.31	4.16	83.26
33.56	16.30	363.88	4.16	91.56
34.07	16.42	313.51	4.10	87.01
32.87	16.39	307.24	4.11	84.32
32.22	16.40	303.91	4.10	85.21
32.36	16.35	305.21	4.12	85.21
32.00	16.46	304.58	4.08	83.67
37.90	16.39	285.03	4.14	85.46
38.32	16.50	278.27	3.99	79.76
32.51	16.50	258.50	4.00	78.18
34.13	16.41	286.82	4.07	82.69
42.25	16.37	318.28	4.11	79.76
16.37	16.32	337.27	4.24	90.10
9.54	16.37	347.45	4.18	77.65
7.54	16.28	346.22	4.27	87.09
8.11	16.28	379.26	4.28	90.18
6.79	16.32	350.86	4.24	86.27
6.20	16.22	376.82	4.32	83.34
7.09	16.19	380.00	4.38	90.99
6.57	16.09	437.04	4.46	96.53
6.04	16.05	463.90	4.56	113.78
5.75	15.63	802.12	4.90	129.65
5.02	15.72	864.37	4.82	127.45
7.32	15.63	949.09	4.53	139.41
7.68	15.73	898.80	4.84	126.98
2.66	16.10	549.11	4.54	113.45
2.48	16.07	551.30	4.55	114.67
2.15	15.96	619.91	4.66	119.88
1.97	16.07	592.16	4.53	117.60
2.25	16.17	537.88	4.50	112.88
2.19	16.12	523.39	4.50	117.77
2.27	16.27	447.05	4.35	108.00
1.87	16.12	488.71	4.49	115.52

AVERAGE	AVERAGE	AVERAGE	AVERAGE	AVERAGE
<u>21.51</u>	<u>16.32</u>	<u>403.25</u>	<u>4.28</u>	<u>94.65</u>

LP
 NEWBERRY, MI
 DRYER PRIMARY CYCLONE
 EXHAUST
 TEST 1 / RUN 5 (3)
 21:38:00 - 23:35:00

NOX PPM	O2 %	CO PPM	CO2 %	THC PPM
18.28	16.31	451.04	3.86	107.19
26.18	16.48	348.10	3.78	101.90
25.00	16.52	342.56	3.85	94.90
23.31	16.59	366.08	3.94	107.78
24.67	16.43	498.49	4.18	119.07
26.46	16.62	517.86	3.93	103.61
27.48	16.66	345.65	3.95	97.99
29.13	16.63	355.52	3.98	98.56
34.11	16.65	358.27	4.01	96.69
33.36	16.56	384.88	4.09	103.28
32.34	16.51	424.51	4.14	111.34
30.69	16.60	426.71	4.05	103.12
28.11	16.57	394.32	4.03	102.22
29.41	16.69	332.15	3.91	94.90
30.06	16.73	285.92	3.85	87.25
30.21	16.79	245.31	3.88	85.05
29.33	16.66	295.85	3.97	87.66
26.77	16.66	289.10	3.96	87.41
23.51	16.63	304.48	4.00	92.13
23.78	16.56	307.41	4.04	87.66
24.92	16.60	307.16	3.99	90.99
25.89	16.69	273.96	3.82	83.75
25.43	16.63	268.59	4.00	85.21
26.48	16.85	239.29	3.87	77.57
24.84	16.73	272.98	3.97	85.13
24.98	16.76	249.22	3.94	84.40
25.28	16.71	253.61	3.98	83.99
24.83	16.64	281.77	4.07	84.24
25.20	16.69	280.31	4.03	83.26
25.40	16.73	266.31	3.98	81.96
25.32	16.78	247.59	3.95	80.33
26.36	16.80	235.30	3.97	80.49
24.77	16.68	266.55	4.07	80.74
25.83	16.78	268.91	4.00	79.93
26.04	16.69	262.32	4.07	84.24
26.10	16.73	300.13	4.03	83.11
32.16	16.41	631.60	4.32	123.84
33.40	16.45	461.84	4.30	122.07
35.09	16.26	596.11	4.44	134.36
36.57	16.32	676.52	4.41	141.68
29.49	16.66	332.04	4.30	84.07
28.23	16.57	297.05	4.43	85.45
27.62	16.53	384.37	4.46	87.08
28.11	16.39	369.31	4.64	91.63
28.58	16.43	418.67	4.55	91.63
28.03	16.37	387.05	4.68	89.60
25.85	16.09	544.69	4.83	101.89
24.65	16.23	517.34	4.72	121.42
24.65	16.11	555.19	4.83	104.82
24.88	16.09	665.78	4.69	109.62
25.93	15.99	656.76	4.96	107.75
26.75	15.96	760.51	4.85	113.69
26.24	16.19	648.53	4.76	105.96
26.22	16.09	611.58	4.85	110.43
27.24	16.16	652.92	4.77	109.78
27.91	16.15	583.59	4.80	109.54
27.87	16.11	600.51	4.86	112.14
27.72	16.05	684.09	4.87	116.78
27.40	16.07	733.98	4.86	117.43
27.23	16.21	700.45	4.73	112.81

AVERAGE	AVERAGE	AVERAGE	AVERAGE	AVERAGE
27.30	16.49	416.87	4.26	98.41

LP / NEWBERRY
 TEST 2 RUN 3
 8/27/96
 E-TUBE OUTLET

TIME	NOX	O2	CO	CO2
443.01	13.022	16.59	838.18	3.8842
444.01	13.26	16.558	812.7	3.8713
445.01	13.312	16.576	709.15	3.9354
446.01	13.665	16.633	791.63	3.8093
447.01	13.395	16.691	677.69	3.7859
448.01	12.752	16.825	650.84	3.6996
449.01	12.617	16.848	544.19	3.6663
450.01	13.178	16.579	604.78	3.9347
451.01	12.949	16.637	840.29	3.8266
452.01	13.022	16.72	678.06	3.7972
453.01	13.022	16.594	729.7	3.8711
454.01	13.354	16.659	764.4	3.8331
455.01	12.835	16.721	686.73	3.7599
456.01	12.368	16.691	657.06	3.8241
457.01	12.877	16.521	746.01	3.973
458.01	13.707	16.651	854.04	3.8354
459.01	13.105	16.646	739.75	3.8127
460.01	12.825	16.567	714.64	3.9372
461.01	13.53	16.641	822.79	3.7997
462.01	13.458	16.669	665.24	3.8201
463.01	12.908	16.624	713.34	3.8451
464.01	12.856	16.579	786.38	3.8972
465.01	13.603	16.528	788.21	3.9273
466.01	13.281	16.582	799.89	3.8801
467.01	12.596	16.552	835.98	3.9282
468.01	13.395	16.636	822.59	3.7916
469.01	14.174	16.649	650.92	3.8501
470.01	12.472	16.751	701.01	3.6914
471.01	12.295	16.866	536.34	3.6588
472.01	12.534	16.738	600.3	3.7525
473.01	12.742	16.525	700.28	3.9631
474.01	13.261	16.466	960.53	3.9656
475.01	14.028	16.538	878.09	3.9241
476.01	13.53	16.455	899.37	3.9599
477.01	13.343	16.697	810.99	3.7671
478.01	12.731	16.733	585.69	3.7695
479.01	12.877	16.564	714.15	3.8939
480.01	12.939	16.556	829.43	3.8834
481.01	12.586	16.564	768.72	3.8989
482.01	12.638	16.499	923.06	3.9273
483.01	14.008	16.57	858.85	3.8672
484.01	13.52	16.588	716.92	3.8729
485.01	13.074	16.565	835.73	3.8858
486.01	13.084	16.524	803.1	3.9307
487.01	14.36	16.452	923.01	3.9582
488.01	13.696	16.504	904.7	3.9347
489.01	12.908	16.546	898.64	3.8777
490.01	13.053	16.593	805.18	3.881
491.01	14.34	16.434	876.75	3.9982
492.01	14.402	16.511	997.31	3.9142
493.01	13.354	16.505	922.36	3.907
494.01	13.686	16.574	875.94	3.8996
495.01	14.713	16.482	929.97	3.9396
496.01	14.495	16.608	949.91	3.8307
497.01	12.804	16.597	823	3.8549
498.01	14.132	16.74	831.22	3.693
499.01	14.516	16.82	623.82	3.6882
500.01	13.997	16.821	599.12	3.6531
501.01	13.416	16.841	593.34	3.6426
502.01	14.194	16.906	538.57	3.6066
503.01	14.827	16.827	527.83	3.6824
504.01	14.049	16.709	662.43	3.7656
505.01	9.2761	16.707	705.4	4.5476

AVERAGES

13.285 16.628 762.48 3.8521

LP / NEWBERRY
 TEST 2 RUN 4
 8/27/96
 E-TUBE OUTLET

TIME	NOX	O2	CO	CO2
740	12.43	17.236	257.53	3.4863
741	13.219	17.296	250.69	3.4415
742	13.426	17.322	256.51	3.4132
743	13.281	17.357	224.41	3.3936
744	14.06	17.346	228.84	3.3797
745	13.707	17.3	226.07	3.4383
746	12.575	17.336	255.9	3.3985
747	12.908	17.388	228.07	3.3814
748	13.011	17.218	254.44	3.5334
749	13.178	17.206	328.17	3.5262
750	12.721	17.241	298.05	3.4832
751	12.897	17.232	306.97	3.4986
752	14.983	17.313	290.57	3.4106
753	13.509	17.335	255.17	3.4506
754	12.544	17.287	288.25	3.4488
755	13.354	17.254	296.39	3.5076
756	14.526	17.184	328.04	3.566
757	15.408	17.144	358.44	3.557
758	13.966	17.194	309.53	3.5498
759	14.557	17.14	340.58	3.6011
760	15.72	17.051	375.57	3.654
761	15.305	17.127	370.08	3.5945
762	14.08	16.972	394.45	3.741
763	15.253	16.991	468.91	3.6997
764	15.325	17.081	443.97	3.6027
765	14.184	17.126	436.56	3.6239
766	13.759	16.943	695.68	3.7355
767	16.394	17.134	647.46	3.5334
768	15.118	17.455	383.38	3.2674
769	14.039	17.44	246.99	3.3576
770	13.748	17.356	281.17	3.3936
771	13.966	17.322	285.52	3.422
772	14.568	17.36	309.69	3.4059
773	16.322	17.457	317.14	3.2878
774	16.778	17.498	245.77	3.2639
775	15.44	17.664	215.01	3.1315
776	12.991	17.563	186.52	3.2593
777	13.956	17.494	223.55	3.3145
778	13.427	17.297	273.07	3.4758
779	13.177	17.232	357.99	3.4962
780	12.814	17.344	313.88	3.4245
781	14.018	17.323	306.27	3.4367
782	14.412	17.336	294.27	3.4179
783	13.426	17.324	296.18	3.4536
784	13.344	17.332	298.99	3.404
785	13.79	17.332	276.9	3.4538
786	14.734	17.447	284.95	3.3154
787	13.478	17.429	235.03	3.3593
788	12.783	17.322	258.95	3.4505
789	14.163	17.311	311.65	3.4693
790	13.676	17.202	321.98	3.5709
791	13.499	17.227	358.97	3.4961
792	13.52	17.177	336.26	3.5732
793	14.392	17.171	384.97	3.5506
794	14.101	17.248	362.26	3.5214
795	13.458	17.2	367.35	3.5507
796	14.319	17.18	364.99	3.5748
797	15.014	17.098	409.1	3.6303
798	14.174	17.086	455.61	3.7102
799	14.111	16.676	738.89	4.0014
800	15.356	16.687	909.3	3.9615
801	16.975	16.605	990.19	4.0496
802	16.031	16.621	1027.6	4.0291

AVERAGES

14.117 17.231 359.46 3.51

LP / NEWBERRY
 TEST 2 RUN 5
 8/27/96
 E-TUBE OUTLET

TIME	NOX	O2	CO	CO2
935.01	15.305	17.215	341.27	3.4147
936.01	14.848	17.143	428.96	3.4303
937.01	16.042	17.262	356.57	3.3358
938.01	16.301	17.215	324.42	3.3807
939.01	14.693	17.193	345.87	3.4295
940.01	13.904	17.003	447.92	3.5969
941.01	15.087	17.146	531.37	3.3797
942.01	15.564	17.232	333.58	3.3895
943.01	15.263	17.184	359.9	3.4114
944.01	15.523	17.185	344.24	3.418
945.01	16.446	17.143	337.65	3.4709
946.01	16.736	17.044	407.02	3.5319
947.01	15.201	17.13	432.86	3.4578
948.01	15.149	17.161	380.01	3.4254
949.01	16.674	17.29	321.9	3.2901
950.01	16.705	17.382	253.66	3.2234
951.01	15.004	17.444	206.42	3.2088
952.01	15.699	17.309	241.41	3.3071
953.01	17.473	17.323	258.38	3.2949
954.01	17.131	17.273	279.83	3.3251
955.01	16.218	17.244	280.44	3.3732
956.01	17.037	17.263	294.92	3.3218
957.01	19.413	17.335	262.04	3.265
958.01	17.847	17.297	241.58	3.3243
959.01	16.747	17.391	235.64	3.247
960.01	17.152	17.285	241.29	3.3243
961.01	18.127	17.336	238.32	3.2843
962.01	16.757	17.322	230.31	3.3105
963.01	15.325	17.219	251.59	3.3903
964.01	16.031	17.271	266.56	3.3406
965.01	17.152	17.336	250.77	3.2704
966.01	15.336	17.412	228.64	3.2095
967.01	16.072	17.47	210.77	3.1902
968.01	16.114	17.284	227.91	3.3447
969.01	16.747	17.348	254.48	3.2868
970.01	15.097	17.296	230.1	3.3292
971.01	11.538	16.77	610.15	3.8118
972.01	12.327	16.842	668.38	3.6815
973.01	12.41	16.929	443.2	3.6979
974.01	12.586	16.723	545.9	3.8541
975.01	13.261	16.726	683.59	3.8086
976.01	19.351	17.069	279.83	3.5936
977.01	21.8	17.135	293.99	3.4888
978.01	20.482	17.019	253.95	3.6597
979.01	19.206	16.915	371.18	3.6881
980.01	19.6	16.772	352.58	3.8753
981.01	22.485	16.805	446.74	3.7899
982.01	23.107	16.728	387.78	3.9234
983.01	20.804	16.519	545.74	4.0218
984.01	20.887	16.654	530.52	3.9241
985.01	22.858	16.58	540.57	4.0022
986.01	22.589	16.533	651.81	4.0104
987.01	20.876	16.514	667.85	4.0828
988.01	21.593	16.448	758.67	4.0601
989.01	23.813	16.663	672.97	3.9117
990.01	23.637	16.603	592.41	3.9835
991.01	21.738	16.676	661.46	3.9069
992.01	22.962	16.678	582.56	3.9054
993.01	25.577	16.657	583.98	3.954
994.01	24.01	16.613	667.97	3.9761
995.01	21.26	16.607	719.4	3.9501
996.01	22.08	16.748	708.13	3.8282
997.01	24.892	16.915	530.6	3.7183

AVERAGES

17.931 17.035 406.83 3.5658

INTERPOL LABS
DILUTION CEM

LP\NEWBERRY
DRYER RTO STACK
NEWBERRY, MI
TEST1 RUN3

DATE	TIME	SO2 (ppm)	NOX (ppm)	O2 (%)	CO (ppm)	CO2 (%)
8/27/96	4:45:59 PM	0.69	18.43	15.95	54.24	4.31
	4:46:59 PM	0.79	19.89	16.06	51.33	4.45
	4:47:59 PM	0.87	18.33	16.10	58.52	4.31
	4:48:59 PM	0.66	17.60	16.09	58.14	4.10
	4:49:59 PM	0.66	17.62	16.15	52.02	4.03
	4:50:59 PM	0.96	17.33	16.21	55.96	4.01
	4:51:59 PM	1.01	17.17	16.32	64.84	4.07
	4:52:59 PM	1.09	17.73	16.32	58.86	4.06
	4:53:59 PM	2.29	17.73	16.07	51.55	3.96
	4:54:59 PM	1.01	17.40	16.10	59.25	3.92
	4:55:59 PM	0.47	17.14	16.17	66.45	3.92
	4:56:59 PM	0.50	17.38	16.11	58.43	3.89
	4:57:59 PM	0.61	17.28	16.13	54.03	3.82
	4:58:59 PM	0.64	16.93	16.21	64.21	3.74
	4:59:59 PM	0.37	16.83	16.19	69.16	3.72
	5:00:59 PM	0.23	17.67	16.03	57.74	3.92
	5:01:59 PM	0.44	17.74	16.12	50.04	3.90
	5:02:59 PM	0.54	17.40	16.16	59.48	3.82
	5:03:59 PM	0.69	17.31	16.10	62.28	3.87
	5:04:59 PM	0.56	17.68	16.19	52.55	3.87
	5:05:59 PM	0.48	17.47	16.21	50.52	3.81
	5:06:59 PM	0.48	17.02	16.16	59.04	3.83
	5:07:59 PM	0.50	17.49	16.11	57.59	3.96
	5:08:59 PM	0.49	17.95	16.08	47.15	3.93
	5:09:59 PM	0.48	17.80	16.09	47.11	3.87
	5:10:59 PM	0.38	17.30	16.08	55.75	3.91
	5:11:59 PM	0.34	17.40	16.18	53.48	3.86
	5:12:59 PM	0.41	17.64	16.18	46.51	3.84
	5:13:59 PM	0.58	17.48	16.32	50.16	3.86
	5:14:59 PM	0.10	17.28	16.40	56.54	3.92
	5:15:59 PM	0.24	17.77	16.26	51.17	3.97
	5:16:59 PM	0.26	18.08	16.01	45.41	3.95
	5:17:59 PM	0.33	17.70	15.95	49.08	3.97
	5:18:59 PM	0.20	17.31	16.06	52.05	3.89
	5:19:59 PM	0.22	17.73	16.05	64.34	3.86
	5:20:59 PM	0.28	16.90	16.21	169.74	3.78
	5:21:59 PM	0.15	15.95	16.23	323.67	3.66
	5:22:59 PM	0.24	15.90	16.13	341.92	3.75
	5:23:59 PM	0.21	16.70	16.11	218.93	3.91
	5:24:59 PM	0.25	17.63	16.09	104.73	4.05
	5:25:59 PM	0.21	17.71	16.07	63.07	3.98
	5:26:59 PM	0.19	17.88	16.15	58.97	3.98

INTERPOL LABS
DILUTION CEM

5:27:59 PM	0.14	17.33	16.15	53.26	3.88
5:28:59 PM	0.15	17.09	16.13	46.88	3.82
5:29:59 PM	0.14	16.70	16.07	53.81	3.89
5:30:59 PM	0.12	16.97	16.05	56.73	3.93
5:31:59 PM	0.20	17.19	16.04	49.85	3.93
5:32:59 PM	0.19	17.25	16.11	48.08	3.97
5:33:59 PM	0.28	17.22	16.11	51.79	3.93
5:34:59 PM	0.22	17.52	16.02	48.23	3.88
5:35:59 PM	0.27	17.40	16.04	44.02	3.91
5:36:59 PM	0.41	17.20	16.08	41.36	3.93
5:37:59 PM	0.41	17.72	16.10	27.80	3.98
5:38:59 PM	0.57	18.15	16.06	24.02	3.98
5:39:59 PM	0.48	17.83	16.14	32.73	3.95
5:40:59 PM	0.60	17.38	16.16	32.80	3.91
5:41:59 PM	0.55	18.01	16.32	31.95	3.99
5:42:59 PM	0.64	18.50	16.37	22.13	3.97
5:43:59 PM	0.49	18.22	16.39	26.01	3.95
5:44:59 PM	0.56	17.80	16.40	39.42	3.91
AVERAGES	0.47	17.50	16.14	65.95	3.93

INTERPOLL LABS
DILUTION CEM

LP\NEWBERRY
DRYER RTO STACK
NEWBERRY, MI
TEST1 RUN4

DATE	TIME	SO2 (ppm)	NOX (ppm)	O2 (%)	CO (ppm)	CO2 (%)
8/27/96	7:40:03 PM	0.51	24.80	16.75	206.84	2.92
	7:42:03 PM	0.48	22.86	16.87	68.45	3.04
	7:44:03 PM	0.20	20.11	16.65	30.18	3.47
	7:46:03 PM	0.13	17.42	16.67	32.25	3.61
	7:48:03 PM	0.14	19.30	16.67	42.37	3.32
	7:50:03 PM	0.11	18.49	16.65	33.19	3.39
	7:52:03 PM	0.95	18.05	16.57	40.53	3.49
	7:54:03 PM	0.21	18.44	16.56	37.40	3.45
	7:56:03 PM	0.21	18.72	16.64	39.15	3.49
	7:58:03 PM	0.07	18.39	16.59	38.31	3.50
	8:00:03 PM	0.13	18.65	16.51	36.67	3.59
	8:01:59 PM	0.08	18.36	16.49	34.90	3.57
	8:02:59 PM	0.15	18.76	16.45	45.08	3.53
	8:03:59 PM	0.18	19.42	16.40	41.07	3.49
	8:04:59 PM	1.10	18.79	16.41	36.92	3.53
	8:05:59 PM	0.31	18.68	16.34	39.47	3.57
	8:06:59 PM	0.17	19.35	16.30	41.63	3.60
	8:07:59 PM	0.24	20.41	16.38	38.55	3.65
	8:08:59 PM	0.03	20.46	16.42	31.72	3.62
	8:09:59 PM	0.06	19.99	16.29	34.29	3.66
	8:10:59 PM	0.10	20.46	16.41	37.04	3.71
	8:11:59 PM	0.07	21.04	16.70	24.70	3.71
	8:12:59 PM	0.08	20.68	16.82	12.98	3.78
	8:13:59 PM	0.43	20.57	16.76	24.91	3.82
	8:14:59 PM	0.18	21.13	16.73	43.93	3.76
	8:15:59 PM	0.16	21.29	16.67	36.10	3.71
	8:16:59 PM	0.13	20.92	16.70	24.76	3.82
	8:17:59 PM	0.07	20.86	16.77	36.93	3.73
	8:18:59 PM	0.07	20.45	16.87	127.42	3.48
	8:19:59 PM	0.20	19.03	16.87	240.15	3.35
	8:20:59 PM	0.10	18.79	16.78	242.60	3.42
	8:21:59 PM	0.06	18.70	16.65	143.19	3.46
	8:22:59 PM	0.11	19.16	16.55	28.79	3.50
	8:23:59 PM	0.20	20.05	16.61	1.25	3.49
	8:24:59 PM	0.18	21.41	16.62	4.11	3.41
	8:25:59 PM	0.17	21.12	16.63	14.62	3.32
	8:26:59 PM	0.08	19.54	16.63	30.13	3.28
	8:27:59 PM	0.07	19.01	16.65	35.98	3.37
	8:28:59 PM	0.07	19.54	16.64	13.93	3.49
	8:29:59 PM	0.54	19.31	16.70	0.00	3.59
	8:30:59 PM	0.60	18.92	16.74	0.98	3.56
	8:31:59 PM	0.05	19.12	16.66	9.40	3.54

INTERPOLL LABS
DILUTION CEM

8:32:59 PM	0.11	19.85	16.60	18.59	3.53
8:33:59 PM	0.13	19.54	16.55	13.07	3.53
8:34:59 PM	0.06	18.78	16.54	28.62	3.51
8:35:59 PM	0.22	19.14	16.50	27.16	3.51
8:36:59 PM	0.15	19.63	16.46	21.16	3.47
8:37:59 PM	0.48	19.38	16.51	13.23	3.43
8:38:59 PM	0.75	19.08	16.51	5.26	3.49
8:39:59 PM	0.12	19.53	16.48	10.43	3.56

AVERAGES	0.22	19.71	16.60	44.41	3.52
-----------------	-------------	--------------	--------------	--------------	-------------

INTERPOLL LABS
DILUTION CEM

LP\NEWBERRY
DRYER RTO STACK
NEWBERRY, MI
TEST1 RUN5

DATE	TIME	SO2 (ppm)	NOX (ppm)	O2 (%)	CO (ppm)	CO2 (%)
8/27/96	9:36:00 PM	4.10	0.87	16.59	5.48	0.02
	9:37:00 PM	6.12	0.72	16.56	0.40	0.02
	9:38:00 PM	3.77	0.50	16.64	3.42	0.02
	9:39:00 PM	2.31	0.36	16.61	10.23	0.02
	9:40:00 PM	2.07	0.40	16.64	0.00	0.02
	9:41:00 PM	0.61	4.65	16.70	0.00	0.51
	9:42:00 PM	0.32	17.06	16.67	1.52	2.33
	9:43:00 PM	0.13	20.66	16.61	13.44	3.14
	9:44:00 PM	0.01	20.13	16.50	13.56	3.28
	9:45:00 PM	0.00	20.79	16.62	18.96	3.31
	9:46:00 PM	0.26	20.69	16.66	3.55	3.31
	9:47:00 PM	0.04	19.84	16.65	5.54	3.35
	9:48:00 PM	0.00	20.44	16.64	29.29	3.31
	9:49:00 PM	0.00	21.16	16.59	36.61	3.35
	9:50:00 PM	0.00	20.70	16.53	41.26	3.41
	9:51:00 PM	0.00	20.10	16.58	44.83	3.53
	9:52:00 PM	0.00	20.45	16.64	28.22	3.46
	9:53:00 PM	0.00	20.95	16.76	12.36	3.39
	9:54:00 PM	0.00	20.75	16.85	39.87	3.42
	9:55:00 PM	0.36	20.40	16.90	50.76	3.43
	9:56:00 PM	0.00	21.12	16.81	8.89	3.47
	9:57:00 PM	0.00	22.02	16.78	2.01	3.54
	9:58:00 PM	0.00	21.35	16.75	27.71	3.52
	9:59:00 PM	0.00	20.66	16.71	66.58	3.46
	10:00:00 PM	0.00	21.38	16.72	46.01	3.37
	10:01:00 PM	0.00	21.84	16.76	39.62	3.29
	10:02:00 PM	0.00	20.75	16.74	71.24	3.24
	10:03:00 PM	0.09	20.40	16.79	43.50	3.30
	10:04:00 PM	0.00	21.62	16.76	2.96	3.33
	10:05:00 PM	0.00	22.54	16.77	2.45	3.36
	10:06:00 PM	0.00	21.84	16.74	23.87	3.38
	10:07:00 PM	0.11	22.08	16.68	41.95	3.39
	10:08:00 PM	0.00	23.44	16.71	24.63	3.36
	10:09:00 PM	0.00	23.86	16.78	34.10	3.37
	10:10:00 PM	0.16	22.71	16.91	56.30	3.34
	10:11:00 PM	0.00	22.30	16.95	45.14	3.37
	10:12:00 PM	0.00	22.99	16.81	37.90	3.36
	10:13:00 PM	0.00	22.57	16.78	30.40	3.37
	10:14:00 PM	0.21	21.27	16.74	39.30	3.42
	10:15:00 PM	0.00	21.19	16.77	34.88	3.40
	10:16:00 PM	0.00	21.91	16.82	8.63	3.34
	10:17:00 PM	0.00	21.42	17.84	20.46	3.26

INTERPOLL LABS
DILUTION CEM

10:18:00 PM	0.04	20.59	19.49	45.99	3.19
10:19:00 PM	0.00	21.05	20.20	46.74	3.30
10:20:00 PM	0.00	21.66	20.38	66.08	3.34
10:21:00 PM	0.00	21.40	20.34	69.34	3.36
10:22:00 PM	0.18	20.27	20.19	33.47	3.34
10:23:00 PM	0.00	21.18	20.27	32.36	3.30
10:24:00 PM	0.00	23.33	20.37	41.69	2.72
10:25:00 PM	0.00	18.87	20.41	31.84	1.24
10:26:00 PM	0.10	11.83	20.45	10.98	0.64
10:27:00 PM	0.03	9.91	20.45	11.48	0.52
10:28:00 PM	0.00	9.93	20.39	28.94	0.48
10:29:00 PM	0.00	10.39	20.36	18.08	0.52
10:30:00 PM	0.00	10.77	20.38	11.72	0.58
10:31:00 PM	0.18	8.98	20.40	20.92	0.48
10:32:00 PM	0.00	8.90	20.39	9.69	0.42
AVERAGES	0.37	17.75	17.68	27.14	2.60

INTERPOLL LABS

LP\NEWBERRY
 NEWBERRY, MI
 8/27/96
 THC

TEST2 RUN3

TIME	E-TUBE OUTLET	DRYER RTO STACK
1646	76.7	5.885
	77.69	7.674
	72.76	9.256
	71.24	7.501
	86.19	6.39
	80.92	8.178
	77.86	9.314
	83.73	8.328
	83.2	6.34
	78.08	7.799
	80.75	9.498
	89.58	7.945
	81.79	6.397
	79.27	8.396
	86.96	10.04
	78.31	6.718
	78.63	6.994
	81.37	10.19
	83.48	8.647
	84.7	6.471
	84.34	7.748
	86.94	10.47
	77.94	8.189
	77.5	6.863
	66.05	20.14
	66.51	24.42
	74.95	11.91
	89.07	8.05
	90.54	8.141
	87.63	9.686
	90.4	8.582
	77.03	6.278
	75.81	7.928
	86.29	9.764
	83.56	7.243
	89.2	6.405
	89.37	9.784
	82.16	8.743
	84.75	6.179
	85.61	6.78
	90.79	10.01
	91.64	7.972
	92.26	6.153

INTERPOLL LABS

	89.53	8.167
	90.47	9.49
	98.89	7.847
	93.6	7.202
	93.84	8.22
	94	9.775
	97.92	8.8
	89.27	8.5
	92.3	8.245
	81.89	9.983
	80.84	8.232
	79.47	6.476
	77.94	8.685
	75.27	10.26
	81.43	6.576
	86.71	6.766
1745	70.38	10.3
AVERAGE	83.455	8.65

INTERPOLL LABS

LP\NEWBERRY
 NEWBERRY, MI
 8/27/96
 THC

TEST2 RUN4

TIME	E-TUBE OUTLET	DRYER RTO STACK
1921	29.98	8.071
	30.49	7.104
	32.09	4.883
	32	6.753
	34.02	8.158
	39.35	6.94
	27.81	12.97
	24.64	16.18
	28.26	10.15
	31.34	5.527
	30.88	5.318
	32.94	8.637
	57.3	7.398
	60.66	5.147
	49.81	6.014
	45.48	8.802
	40.06	6.747
	38.3	4.934
	45.79	6.945
	48.53	8.13
	48.02	6.357
	46.62	6.088
	46.65	6.67
	46.02	8.143
	48.86	7.198
	47.54	4.861
	46.89	6.713
	53.62	8.171
	53.71	6.754
	52.41	5.084
	52.37	7.422
	50.26	8.584
	51.77	5.39
	52.19	5.389
	54.85	8.786
	57.13	7.115
	55.42	4.784
	55.8	5.966
	58.42	8.752
	61.57	6.401
	57.91	4.669
	66.62	6.855
	67.22	7.939

INTERPOLL LABS

	66.33	6.058
	89.97	5.66
	90.4	6.713
	72.98	8.642
	49.96	14.61
	50.03	8.595
	55.16	7.905
	58.16	8.161
	60.29	6.655
	54.99	4.94
	52.66	6.863
	47.86	8.795
	51.38	5.255
	53.22	4.9
	59.44	8.288
	60.01	6.888
2020	57.11	4.527
AVERAGE	50.35917	7.2059

INTERPOLL LABS

LP\NEWBERRY
 NEWBERRY, MI
 8/27/96
 THC

TEST2 RUN5

TIME	E-TUBE OUTLET	DRYER RTO STACK
2136	74.67	9.55
	69.93	6.377
	70.85	6.559
	74.89	9.725
	85.05	8.354
	71.21	5.998
	71.07	6.813
	70.06	9.825
	69.06	7.745
	73.88	5.83
	77.06	7.408
	72.39	9.515
	69.6	7.679
	64.4	5.892
	59.65	8.121
	58.6	9.166
	62.19	7.205
	62.57	6.608
	63.05	7.719
	65.3	8.915
	63.26	7.202
	59.68	6.419
	61.66	7.383
	58.15	8.814
	60.6	7.545
	58.43	5.597
	59.53	7.623
	62.85	8.968
	60.7	7.212
	58.7	5.77
	55.35	7.776
	55.73	9.5
	61.35	6.375
	60.38	5.906
	62.54	9
	59.94	8.205
	58.2	5.953
	42.27	6.322
	18.74	9.418
	14.21	8.162
	10.43	6.236
	10.42	7.12
	10.08	10.37

INTERPOLL LABS

	9.973	8.557
	5.792	6.492
	4.471	8.129
	3.653	9.776
	3.609	8.431
	7.103	7.029
	6.945	8.753
	6.628	9.994
	6.346	8.158
	5.985	7.544
	4.78	8.202
	5.633	10.15
	4.41	8.835
	3.82	6.675
	2.896	8.083
	2.746	10.22
2235	9.18	8.79
AVERAGE	43.3775	7.861633

L.P.
 NEWBERRY, MI
 PRESS / VENTS
 TEST 9 / RUN 1
 8/23/96

TIME	NOX PPM	CO PPM	THC PPM
900.09	0.828	5.673	1.372
901.09	0.665	5.673	2.023
902.09	0.624	5.673	2.47
903.09	1.072	5.266	2.351
904.09	0.746	5.266	2.104
905.09	0.706	5.266	2.267
906.09	0.908	5.469	1.819
907.09	0.99	5.469	1.494
908.09	0.828	5.266	1.697
909.09	0.624	5.673	1.819
910.09	0.99	5.469	1.738
911.09	1.072	6.69	2.796
912.09	0.787	5.876	2.977
913.09	0.624	5.876	1.372
914.09	0.99	6.079	1.697
915.09	0.828	6.079	1.25
916.09	0.787	5.876	1.819
917.09	0.746	6.079	1.657
918.09	0.99	5.876	2.145
919.09	0.746	6.486	0.802
920.09	0.828	6.283	2.552
921.09	0.787	6.69	1.901
922.09	1.072	6.486	1.738
923.09	0.628	6.283	1.575
924.09	0.868	6.486	2.104
925.09	0.95	6.486	2.348
926.09	0.868	6.69	1.616
927.09	0.909	6.486	1.901
928.09	0.868	6.69	1.25
929.09	1.072	6.486	1.209
932.09	1.031	7.504	1.25
933.09	1.316	7.097	1.941
934.09	0.99	5.876	0.558
935.09	0.909	7.504	0.151
936.09	0.909	7.707	0.395
937.09	1.031	7.3	0.843
938.09	0.99	6.69	0.924
939.09	0.868	6.69	0.232
940.09	0.909	6.486	1.046
941.09	0.99	6.486	1.006
942.09	0.99	6.486	0.721
943.09	0.909	6.486	0.883
944.09	1.031	6.486	0.354
945.09	1.112	6.079	0.883
946.09	0.99	6.283	1.372
947.09	1.072	6.486	0.436
948.09	1.112	6.486	0.517
949.09	1.194	6.486	1.209
950.09	1.153	8.317	0.639
951.09	1.153	8.928	1.046
952.09	1.153	8.521	0.436
953.09	1.194	9.131	1.982
954.09	1.153	8.928	0.273
955.09	1.316	8.724	1.168
956.09	1.357	8.521	0.843
957.09	1.357	8.317	0.924
958.09	1.397	8.114	0.395
959.09	1.397	8.724	1.046
1000.09	1.479	8.521	0.721
1001.09	1.438	7.91	0.924

<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>
<u>0.9917</u>	<u>6.72</u>	<u>1.35</u>

LP
 NEWBERRY, MI
 PRESS / VENTS
 TEST 9 / RUN 2
 8/29/96

TIME	NOX PPM	CO PPM	THC PPM
1035.19	0.99	3.638	1.616
1036.19	1.641	3.638	2.145
1037.19	2.089	4.452	3.121
1038.19	1.275	4.045	2.308
1039.19	1.194	4.045	2.389
1040.19	1.763	4.859	2.796
1041.19	1.601	5.062	3.65
1042.19	1.112	4.452	1.982
1043.19	1.438	4.248	2.348
1044.19	1.682	4.452	3.203
1045.19	1.601	4.248	4.139
1046.19	1.072	4.248	1.982
1047.19	1.641	3.841	2.389
1048.19	1.886	4.248	2.918
1049.19	1.519	3.841	3.976
1050.19	1.194	3.841	1.209
1051.19	1.723	3.841	1.738
1052.19	1.723	4.452	4.098
1053.19	1.316	4.655	3.61
1054.19	1.501	4.045	2.257
1055.19	1.845	4.452	2.959
1056.19	1.886	4.452	3.935
1057.19	1.357	3.841	1.819
1058.19	1.723	4.045	2.877
1059.19	2.008	4.045	2.348
1100.19	1.682	4.452	4.627
1101.19	1.357	4.045	1.901
1102.19	2.048	4.045	3.813
1103.19	2.13	4.452	4.464
1104.19	1.397	4.248	3.366
1107.19	1.601	3.638	2.755
1108.19	1.56	4.859	4.179
1109.19	1.967	4.655	3.854
1110.19	2.415	4.859	5.359
1111.19	2.008	4.859	6.377
1112.19	1.519	4.859	4.139
1113.19	2.292	4.859	4.852
1114.19	2.537	5.266	6.214
1115.19	1.926	5.062	7.841
1116.19	1.641	4.655	3.885
1117.19	2.618	4.859	5.276
1118.19	2.496	5.266	6.539
1119.19	1.845	5.062	6.295
1120.19	1.886	4.248	4.424
1121.19	2.537	5.266	6.214
1122.19	2.252	5.469	7.882
1123.19	1.763	4.452	4.79
1124.19	2.415	4.859	4.098
1125.19	2.659	5.469	7.597
1126.19	2.089	5.469	8.086
1127.19	1.845	5.673	5.4
1128.19	2.537	5.266	4.668
1129.19	2.659	5.673	7.841
1130.19	2.252	5.876	8.452
1131.19	2.008	5.062	3.406
1132.19	2.821	5.062	6.499
1133.19	2.618	6.283	9.144
1134.19	2.008	6.486	6.214
1135.19	2.13	5.062	4.671
1136.19	2.781	5.876	7.679

AVERAGE

1.89

AVERAGE

4.68


AVERAGE

4.35

L.P.
NEWBERRY, MI
PRESS / VENTS
TEST 9 / RUN 3
8/29/96


TIME	NOX PPM	CO PPM	THC PPM
1210.39	1.153	6.69	3.772
1211.39	1.235	6.079	4.983
1212.39	1.275	6.079	3.569
1213.39	1.357	6.486	3.772
1214.39	1.235	6.283	3.65
1215.39	1.316	6.486	3.772
1216.39	1.357	6.486	2.959
1217.39	1.438	6.486	1.738
1218.39	1.438	6.079	2.308
1219.39	1.438	6.079	3.081
1220.39	1.682	6.486	2.837
1221.39	1.438	6.283	1.616
1222.39	1.479	6.89	4.261
1223.39	1.479	6.486	1.535
1224.39	1.601	6.69	1.901
1225.39	1.479	6.69	2.47
1226.39	1.641	7.3	4.179
1227.39	1.641	7.504	1.86
1228.39	1.723	7.91	1.657
1229.39	1.763	7.504	5.278
1230.39	1.682	8.114	5.766
1231.39	1.641	6.69	0.721
1232.39	1.519	6.486	0.883
1233.39	1.926	6.283	3.04
1234.39	2.089	6.893	2.308
1235.39	1.926	6.486	4.22
1236.39	1.886	6.486	2.918
1237.39	2.17	6.486	3.61
1238.39	1.967	6.893	3.895
1239.39	2.008	7.91	5.156
1242.39	1.967	8.317	1.616
1243.39	1.886	5.266	-0.012
1244.39	1.926	5.469	0.558
1245.39	2.17	5.876	1.657
1246.39	2.048	5.876	3.081
1247.39	1.967	5.876	1.087
1248.39	2.17	5.673	1.29
1249.39	2.455	6.486	3.976
1250.39	2.17	6.486	3.447
1251.39	2.089	6.283	1.982
1252.39	2.048	6.283	0.477
1253.39	2.089	5.876	0.558
1254.39	2.13	5.673	1.897
1255.39	2.374	5.876	1.412
1256.39	2.496	5.876	2.511
1257.39	2.252	5.876	1.412
1258.39	2.496	5.673	1.25
1259.39	2.537	5.876	1.697
100.39	2.415	6.283	2.755
101.39	2.333	5.673	0.965
102.39	2.496	5.876	0.883
103.39	2.74	5.876	2.348
104.39	2.415	6.283	1.453
105.39	2.455	5.266	6.924
106.39	2.781	5.876	2.592
107.39	2.74	5.673	3.772
108.39	2.537	6.079	2.348
109.39	2.74	5.266	1.657
110.39	2.984	5.876	2.532
111.39	2.781	5.876	3.203

<u>AVERAGE</u>	<u>AVERAGE</u>	<u>AVERAGE</u>
<u>1.98</u>	<u>6.33</u>	<u>2.48</u>



APPENDIX F

ANALYZER SPECIFICATIONS



MODEL 42 CHEMILUMINESCENCE NO-NO₂-NO_x ANALYZER

C. SPECIFICATIONS (* denotes EPA designed parameters)

Ranges	0-50*, 100*, 200*, 500*, 1000*, 2000, 5000, 10000 20000 PPB
Noise	0.25 PPB RMS (60 sec. time setting)
Minimum Detectable Limit	0.50 PPB (60 sec. time constant)
Zero Drift (24 hour)	0.50 PPB
Span Drift (24 hour)	+/- 1% Full Scale
Rise, Fall Times (0-95%):	
10 sec. average*	40 seconds
60 sec. average*	80 seconds
300 sec. average*	300 seconds
Precision	+/- 0.5 PPB
Linearity	+/- 1% Full Scale
Sample Flow Rate	0.7 Liters per minute
Interference Equivalent (PPB)	Each < 10 PPB Total < 20 PPB
Operating Temperature	15°-35° C* (may be safely operated over the range 5-40° C)
Power Requirements	105-125 VAC, 60 Hz* 220-240 VAC, 50 Hz 300 Watts
Physical Dimensions	17" W x 8-3/4" H x 23"D
Weight	53 lbs.
Outputs	NO, NO ₂ , NO _x Selectable Voltage 4-20 mA, RS-232(Optional)

THERMO ENVIRONMENTAL INSTRUMENTS INC.

II. SPECIFICATIONS

MODEL 43B PULSED FLUORESCENCE SO₂ ANALYZER

Ranges
 Standard Mode 0-0.1, 0.2, 0.5, 1, 2, 5, and 10 ppm
 High Range Mode 0-1, 2, 5, 10, 20, 50, and 100 ppm

Signal Averaging Time For:
 Noise (RMS value when sampling zero air)
 Lower Detectable Limit (LDL)
 Analyzer Response Time

10 SEC	60 SEC	300 SEC
1.0 ppb	0.5 ppb	0.25 ppb
2.0 ppb	1.0 ppb	0.5 ppb
80 sec	110 sec	320 sec

Linearity ±1 % of fullscale
 Precision 1% of Reading or 1 ppb
 Zero Drift Less than 1 ppb per day
 Span Drift ± 1% per day
 Interferences per EPA levels
 NO Less than LDL except for the following
 M-Xylene Less than 3 ppb
 H₂O Less than 2 ppb
 Less than 2% of reading
 Temperature Dependence
 Zero ± 0.1 ppb/°C
 Span ± 0.1% / °C
 Flow 0.5 LPM (Standard), 1 LPM (optional)
 Standard Output Dual: Selectable Voltage
 Optional: Two additional analog outputs Selectable Voltage, 4-20 mA isolated,
 4-20 mA non-isolated
 Optional: Digital Output RS-232
 Line Power 115 V/60 Hz and 220 V/50 Hz versions
 Average Power Consumption 100 Watts
 Maximum Steady A.C. Line Current 1.3 Amp (115 V)
 Size and Weight 17"W x 8 3/4"H x 23"D 44 lbs.

MODEL 43 GFC AMBIENT CO ANALYZER

C. SPECIFICATIONS

Ranges	0-1, 2, 5, 10, 20, 50, 100, 200, 500, 1000 PPM
Noise	0.05 PPM RMS - with time constant of 30 seconds
Minimum Detectable Limit	0.10 PPM
Zero Drift, 24 hours	+/- 0.2 PPM
Span Drift, 24 hours	+/- 1% Full Scale
Rise, Fall Times (0-95%) (at 1 lpm flow, 30 second response time)	1 Minutes
Precision	+/- 0.1 PPM
Linearity	+/- 1%
Flow Rate	0.5 - 2 lpm
Rejection Ration	Negligible interference from water and CO ₂ .
Operating Temperature	Performance specifications maintained over the range 15-35°C (may be operated safely over the range 5-45°C)
Power Requirements	105 - 125 VAC, 60 Hz 220 - 240 VAC, 50 Hz 100 Watts
Physical Dimensions	17"W x 8 3/4"H x 23"D
Weight	45 lbs.
Dual Outputs (Standard)	Individually selectable to 0-10mv, 0-100mv, 0-1V, 0-5V, 0-10V, digital display, 1 hour integrated value. Other outputs available upon request (4-20ma)

THERMO ENVIRONMENTAL INSTRUMENTS INC.

I-10

C. SPECIFICATIONS

Ranges	Model 41	0-0.2, 0.5, 1.0, 2, 5, 10, 20, 100, 200 PPM
	Model 41H	0-5, 10, 20, 50, 100, 200, 500, 2000, 5000 PPM
Noise	Model 41	3 PPB RMS - with time constant of 5 minutes
	Model 41H	50 PPB RMS - with time constant of 5 minutes
Minimum Detectable Limit	Model 41	5 PPB
	Model 41H	100 PPB
Zero Drift, 24 hours	Model 41	+/- 0.02 PPM
	Model 41H	+/- 0.05 PPM
Span Drift, 24 hours		+/- 2% Full Scale
Rise, Fall Times (0-95%) (at 1 lpm flow, 30 second response time)		1.5 Minutes
Precision		±1%
Linearity		+/- 1.5%
Flow Rate		0.5 - 2 lpm
Rejection Ratio		Negligible interference from water and CO
Operating Temperature		Performance specifications maintained over the range 15-35°C (may be operated safely over the range 5-45°C)
Power Requirements		100 Watt at 105 to 125 VAC, 60 Hz or 200 to 240 VAC, 50 Hz 100 Watts
Physical Dimensions		17"W x 8 3/4"H x 23"D
Weight		45 lbs.
Dual Outputs (Standard)		Individually selectable to 0-10mv, 0-100mv, 0-1V, 0-5V, 0-10V, digital display, 1 hour integrated value. Other outputs available upon request (4-20ma)

SPECIFICATIONS FOR SO₂ ANALYZER
WESTERN RESEARCH MODEL 721ATZ

Measuring principle	NDUV double beam method which uses 285 nm UV light for SO ₂ measurement and 585 nm visible light to compensate for contamination of all windows, detector drift or changes in the intensity of the radiation source
Range	SO ₂ : 0 - 500 ppm and 0 - 1000 ppm; but low range may be reduced to 0 - 100 ppm with full scale analog output; total dynamic range of 0 - 5000 ppm with 1 ppm readability
Accuracy	±2% f.s., worst case. Typically better than ±1% f.s.
Temperature drift	≤0.5% f.s./°C
Noise	0.5% of full scale, worst case
Ambient temperature	0 to 40 °C
Ambient humidity	Less than 100% RH
Response time (90% of final reading)	<5 seconds
Optical cell length	35 cm
Output signal	Panel display is digital - direct reading in ppm,w; output signal: 7 field-selectable potentiometric outputs of 1V, 2V, 5V, 10V DC and 100, 200, 500 mV DC. Two outputs per range are provided at the rear of the

instrument, standard. Unit equipped also with 4 - 20 mA

Interferences

No known interferences from O₂, CO₂, CO or hydrocarbons; internally compensated for NO interference

Linearity

±1.5% of full scale

Power supply

AC 115 V ± 10%, 60 Hz

Power consumption

Less than 575 watts

Electronic span value

Nominal 766 @ 77 °F and 29.92 in Hg

Sample gas flow

1.0 - 5.0 LPM to give desired response time

Sample gas temperature

0 to 40 °C

Warmup time

Approximately 30 minutes

External dimensions

7 x 19 x 22 (H x W x D) inch

Weight

40 LB

SPECIFICATIONS FOR MODEL 10A
ROCK MOUNTED CHEMILUMINESCENT
NO-NO_x GAS ANALYZER

Sensitivity	Each instrument is equipped with the following ranges: 0 - 2.5 ppm 0 - 10 ppm 0 - 25 ppm 0 - 100 ppm 0 - 250 ppm 0 - 1000 ppm 0 - 2500 ppm 0 - 10000 ppm
Accuracy	Derived from the NO or NO ₂ calibration gas, ±1% of fullscale
Response time (0-90%) Typical	1.5 seconds - NO Mode 1.7 seconds - NO _x Mode
Output	0 - 10mV and 0 - 10V
Zero Drift	Negligible after 1/2-hour warm-up
Linearity	±1% of full scale
Input Power Requirements	115v/50Hz; 115v/60Hz

Servomex

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1420 Oxygen Analyser Instruction Manual

Ref : 01420/001A/0

Order as part No. 01420001A

was (7982-2842)

INTERPOLL LABORATORIES
4500 BALL ROAD N.E.
CIRCLE PINES, MN 55014-1819
(612) 786-6020

1.3 Sampling System

The sampling system of the analyser includes a combination filter/automatic flow control device, designed to keep a constant flow of sample gas through the measuring cell for varying input pressures and to prevent the entrance of particulate matter into the measuring cell. Excess flow is vented to the by-pass.

1.4 Specification

Performance Specification (typical)

Repeatability: Better than $\pm 0.2\%$ O₂ under constant conditions.

Drift: Less than 0.2% O₂ per week under constant conditions. (Excluding variation due to barometric pressure changes; reading is proportional to barometric pressure.)

Outputs

Display: 3 1/2 digit LCD reading 0.0 to 100.0% oxygen with overrange capability.

Output: 0 to 1V (non-isolated) for 0 to 100% oxygen available on 'D' type connector located on the back panel of the instrument. Output impedance is less than 10 ohms.

Option: 4 - 20mA isolated, Max impedance 500 ohms.

Flow alarm output: Change over relay contact rated at 3A/115V ac, 1A/240V ac or 1A/28V dc. 4 sets of single pole changeover contacts. Alarm becomes active when sample gas flow through the analyser fails.

Sample requirements

Condition: Clean, dry gas with dew point 5 deg C below ambient temperature.

Inlet pressure: 0.5 to 3psig (3.5 to 21kPa). Inlet pressure changes within this range will change the reading by less than 0.1% O₂. May be operated up to 10psig (70kPa) with degraded stability.

Flowrate: 1.5 to 6 litres/minute approximately depending on sample pressure.

Filtering: 0.6 micron replaceable filter integral to the automatic flow control device.

Response time: Less than 15 secs. to 90% at an inlet pressure of 3psig (21kPa).

Inlet/vent connections: 1/4 inch OD tube (stainless steel) suitable for 6mm ID flexible tubing or 1/4 inch OD compression fittings.

Materials exposed to the sample: Stainless steel, Pyrex glass, brass, platinum, epoxy resin, Viton, polypropylene and glass fibre filter.

Physical Characteristics

Case: Steel and aluminium finished in epoxy powder paint.

Case classification: IP 20 (IEC 529) when fitted into the Servomex 1400 series 19 inch case.

Dimensions: See Figure 2.1.

Weight: 10Kg (22lb) approximately.

Electrical

AC Supply: 110 to 120V AC or 220 to 240V AC, +/-10%, 48 to 62Hz. Voltage selected by a voltage selector integral to the IEC supply plug.

Power required: 15VA maximum.

Environmental Limits

Operating ambient temperature: 0 to +40 deg C (32 to 104 deg F)

Storage temp. range: -20 to +70 deg C (-4 to 158 deg F)

Relative humidity: 0-85%, non-condensing.

SPECIFICATIONS FOR ACS MODEL 3300 CO₂ NDIR

Measuring principle	NDIR single beam method
Measurable gas components and measuring range	0 - 20%
Reproducibility	±0.5% of full scale
Stability	Zero drift; ±% of full scale/24H Span drift; ±% of full scale/24H
Noise	0.5% of full scale
Ambient temperature	-5 to 45°C
Ambient humidity	Less than 90% RH
Response time (90% of final reading)	Electrical system; 2 sec, 3 sec, 5 sec (selectable with connector) Response of actual gas; Within 15 sec (depending on cell length)
Indicator	100 linear division
Output signal	OUTPUT 1; DC 0 - 1 V OUTPUT 2; DC 0 - 10 mV or DC 0 - 100 mV or DC 0 - 1 V or DC 4 - 20 mA (Allowable load resistance 500Ω max.)
Linearity	Better than ±2% of full scale (when linearizer is used)
Power supply	AC 115 V ± 10%, 60 Hz

Power consumption	Approx. 30 VA
Materials of gas-contacting parts	Measuring cell; SUS304 Window; CaF ₂ Piping; Polyethylene
Sample gas flow rate	1ℓ/min ± 0.5ℓ/min
Sample gas temperature	0 to 55°C
Purging gas flow rate	1ℓ/min (to be flowed as occasion demands)
Warmup time	Approx. 2 hours
External dimensions	200 x 250 x 541 (H x W x D) mm
Weight	Approx. 11 kg
Finish Color	MUNSELL N1.5
Remarks:	For combinations of measuring ranges for the dualcomponent analyzer, inquiry should be made to the manufacturer.



TOTAL HYDROCARBON ANALYZER (FLAME IONIZATION)
Model RS 55

TECHNICAL DATA

MAINS : 115V/60H

RECORDER OUTPUT : 0 - 5 V / 4-20mA

MODEL: Manual switching
 Solenoid valves

HOUSING: Case, 19"-Rack

MEASURING RANGES:	1 = 0 - 10	C ₁
	2 = 0 - 100	C ₁
	3 = 0 - 1,000	C ₁
	4 = 0 - 10,000	C ₁

SPECIAL OPTIONS :

- .. Flame out alarm
- .. 1 Alarm
- .. Sample line
-

ANALYZER CONDITIONS :

Temperature : ..160.°C

Zero Point : ..3,90....

Gain :7,70....

Pressure Setting: Sample/Spangas/Zerogas: 200 mbar


Fuel: Hydrogen :... ..0,35 bar


Combustion Air :.....0,80 bar

Span Gases : ..300. ppm C₁

24.000. ppm C₁

CALIBRATION DIAGRAM





- 1 Inductor / Induktoren
- 2 Pressure regulator / Druckregulator
- 3 Manometer / Manometer
- 4 Gauge / Waage
- 5 Valve / Ventil
- 6 Needle valve / Nadelventil
- 7 3 way valve / 3 Wege Ventil
- 8 Capillary / Kapillare
- 9 Capillary / Kapillare
- 10 Magnet valve / Magnetventil
- 11 Solenoid valve / Solenoidventil
- 12 Gauge / Waage
- 13 Fuel distributor / Kraftstoffverteilungsregler
- 14 Back pressure regulator / Rückdruckregulator

- Zündventil / Ignition valve
- F-A energized / E-A activated
- E-A starter / E-A starter


Raffisch		FLAMMEN IONISATIONS DETECTOR	
FID		Flame Ionization detector	
Flowmeter		KS 55	
Flowmeter		D.O.M. 11	

Handumstellung
Manual switching



APPENDIX G


MEASUREMENT SYSTEMS PERFORMANCE SPECIFICATIONS



EPA Method 2 Field Data Sheet

Drawing of Test Site

Job 617 / Newberry, MI
 Source Dryer Primary Cyclone / Exhaust
 Test 2 Run 0 Date 6-27-96
 Stack Dimen. 42 IN.
 Dry Bulb 255 °F Wet bulb 155 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.26 IN.HG
 Static Pressure -11.6 IN.WC
 Operators M. Kaehler + M. Petersen
 Pitot No. INST C_p NA



Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length: <u>9.0⁺</u> <u>6.0</u> IN.		Time Start: <u>NA</u> HRS	
<u>C-1</u>		<u>7.00</u>	<u>16.00</u>		
<u>2</u>		<u>21.00</u>	<u>30.00</u>		<u>255</u>
<u>3</u>		<u>35.00</u>	<u>44.00</u>		
Temp. Meas. Device & S/N: <u>PPT-45/TC</u>				Time End: <u>NA</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

* includes vertical port clamp

Calibration Error Check

Job L.P. / Newberry, MI
 Test 2 Run 0 Date 8-26-96
 Operator M. Kaskler

SO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

NO₂ Calibration:

Time (HRS) 2012

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0.1	0.1	500	.02
Mid Level	139.7	140.4	0.7	500	.14
High Level	239	239.3	0.3	500	.06

O₂ Calibration:

Time (HRS) 2012

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0.0	0.0	25%	0
Mid Level	13.5				
High Level	20.8	20.8	0.0	25%	0

CO₂ Calibration

Time (HRS) 2012

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0.0	0.0	25%	0
Mid Level	10.8				
High Level	16.6	16.6	0.0	25%	0

CO Calibration

Time (HRS) 2012

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	1	1	1,000	.1
Mid Level	289	296	7	1,000	.7
High Level	620	617	3	1,000	.3

INTERPOLL LABORATORIES, INC

(612) 786-6020

EPA Method 25 A

Calibration Error Check & Drift Determination

Job L.P. / Newberry, MI
 Test 2 Run 0 Date 9-26-96
 Operator M. Kaebler

THC Calibration (Low Range): Time (HRS) 1946

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	100	0
Low Level	30.5	30	.5	100	.5
Mid Level	286	284	2	1,000	12
High Level	2960	3000	40	10,000	.4

THC Calibration (High Range): Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Span					

O₂ Calibration: Time (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

CO₂ Calibration: Time: (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

Must be within 2% of the span for each calibration gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020
System Bias Check

Job L.P. / Newberry, MI Source Dryer Primary Cyclone
 Test 2 Run 0 Date 9-26-96 Site Exhaust
 Operator M. Kuehler

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
NO _x	Zero Gas	0	0.1	1-3	1.2	250	.48
	Upscale	139.7	140.4	139.5	0.9	250	.36
O ₂	Zero Gas	0	0.0	0.0	0	25%	0
	Upscale	20.9	20.8	20.6	0.2	25%	.90
CO	Zero Gas	0	0.0	0.3	3	1,000	.3
	Upscale	289	296	300	4	1,000	.4
CO ₂	Zero Gas	0	0.0	0.1	0.1	20%	.5
	Upscale	16.6	16.6	16.6	0	20%	0
THC	Zero Gas	0	0.0	0	0	1,000	0
	Upscale	286 30.5	284	290	6	1,000	.6
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

NOx Cal Drift Check

Job L.P. / Newberry, MI Source Near Primary Cyclone
 Test Run 1, 2, 3, 4, 5 Date 8-27-96 Site Exhaust
 Operator M. Kaebler

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1		Zero Gas	0	0.1				
		Upscale	139.7	139.9				
2		Zero Gas	0	0.5				
		Upscale	139.7	140.8				
3	2/1 VOID	Zero Gas	0	0.3	0.5	0.4		
		Upscale	139.7	141.0	140.4		140.7	
4		Zero Gas	0	0.5				
		Upscale	139.7	140.4 140.4				
5	2/2 VOID	Zero Gas	0	0.2	5.7	2.95		
		Upscale	139.7	140.3	141.0		140.65	
6	2/3 39.70	Zero Gas	0	1.0	0.3	0.65		
		Upscale	139.7	141.0	140.4		140.7	38.95
7	2/4 21.51	Zero Gas	0	0.3	3.0	1.65		
		Upscale	139.7	140.4	143.1		141.75	19.80
8	2/5 27.30	Zero Gas	0	3.0	1.1	2.05		
		Upscale	139.7	140.4	140.5		140.45	25.49
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC
(612) 786-6020

O₂ Cal Drift Check

Job L.P. / Newberry, MI Source Dryer Primary Cyclone
 Test 1 Run 1, 2, 3, 4, 5 Date 8-27-96 Site Exhaust
 Operator M. Kachler

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0.0				
		Upscale	20.8	20.8				
2		Zero Gas	0	0.0				
		Upscale	20.8	20.5				
3 2/1	VOID	Zero Gas	0	0.0	0.0	6.0		
		Upscale	20.8	20.8	20.8		20.8	
4		Zero Gas	0	0.0				
		Upscale	20.8	20.8				
5 2/2	VOID	Zero Gas	0	0.0	0.0	0.0		
		Upscale	20.8	20.8	20.8		20.8	
6 2/3	15.91	Zero Gas	0	0.0	0.0	0.0		
		Upscale	20.8	20.8	20.9		20.85	15.87
7 2/4	16.32	Zero Gas	0	0.0	0.3	0.15		
		Upscale	20.8	20.9	20.9		20.9	16.21
8 2/5	16.49	Zero Gas	0	0.3	0.1	0.2		
		Upscale	20.8	20.9	20.9		20.9	16.37
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC
(612) 786-6020

CO2 Cal Drift Check

Job L.P. / Nebraska #1
 Test 2 Run 1,2,3,4,5 Date 8-27-96
 Operator M. Knobel

Source Dryer Primary Cyclone
 Site Exhaust

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _s	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0.0				
		Upscale	16.6	16.6				
2		Zero Gas	0	0.0				
		Upscale	16.6	16.6				
3 2/1	VOID	Zero Gas	0	0.0	0.2	0.1		
		Upscale	16.6	16.6	16.6		16.6	
4		Zero Gas	0	0.1				
		Upscale	16.6	16.6				
5 2/2	VOID & ML	Zero Gas	0	0.0	0.2	0.1		
		Upscale	16.6	16.6	16.5		16.55	
6 2/3	66.3 ML 4.60	Zero Gas	0	0.1	0.0	0.05		
		Upscale	16.6	16.6	16.6		16.6	4.56
7 2/4	405.25 ML 4.28	Zero Gas	0	0.0	0.1	0.05		
		Upscale	16.6	16.6	16.5		16.55	4.26
8 2/5	416.8 ML 4.26	Zero Gas	0	0.1	0.1	0.1		
		Upscale	16.6	16.5	16.8		16.65	4.17
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO Cal Drift Check

Job L.P./Newberry, MI
 Test 2 Run 1, 2, 3, 4, 5 Date 6-27-86
 Operator M. Kasler

Source Dryer Primary Cyclone
 Site Fabast

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	1			██████	
		Upscale	289	290		██████		
2		Zero Gas	0	1			██████	
		Upscale	289	290		██████		
3 2/1	VOID	Zero Gas	0	1	7	4	██████	
		Upscale	289	290	289	██████	289.5	
4		Zero Gas	0	7			██████	
		Upscale	289	289		██████		
5 2/2	VOID	Zero Gas	0	7	15	11	██████	
		Upscale	289	289	291	██████	290	
6 2/3	361.31	Zero Gas	0	3	10	6.5	██████	
		Upscale	289	291	288	██████	289.5	872.93
7 2/4	403.25	Zero Gas	0	10	6	8	██████	
		Upscale	289	288	286	██████	287	409.42
8 2/5	416.87	Zero Gas	0	6	3	4.5	██████	
		Upscale	289	286	283	██████	287	421.86
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

THC Cal Drift Check

Job L.P. / Newberry, MI Source Dryer Primary Cyclone
 Test Run 1, 2, 3, 4, 5 Date 8-27-96 Site Exhaust
 Operator M. Karkler

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0			██████	
		Upscale	286	288		██████		
2		Zero Gas	0	0			██████	
		Upscale	286	289		██████		
3 2/1	VOID	Zero Gas	0	0	4	2	██████	
		Upscale	286	288	299	██████	293.5	
4		Zero Gas	0	3			██████	
		Upscale	286	287		██████		
5 2/2	VOID	Zero Gas	0	1	3	2	██████	
		Upscale	286	287	283	██████	285	
6 2/3	112.67	Zero Gas	0	3	5	4	██████	
		Upscale	286	283	281	██████	282	111.80
7 2/4	94.65	Zero Gas	0	5	3	4	██████	
		Upscale	286	281	278	██████	279.5 279.5 ML	94.10
8 2/5	98.41	Zero Gas	0	3	5	4	██████	
		Upscale	286	278	295	██████	286.5	95.58
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC.

(612) 786-6020

EPA Method 2 Field Data Sheet

Drawing of Test Site

Job CP NEWBERRY
 Source DMER ETUBE OUTLET
 Test 2 Run 2 Date 8-27-96
 Stack Dimen. 4.8 IN.
 Dry Bulb _____ °F Wet bulb _____ °F
 Manometer Reg. Exp. Elec.
 Barometric Pressure 29.26 IN.HG
 Static Pressure _____ IN.WC
 Operators SB-10-H
 Pitot No. C_p

Cross-section View	Elevation View
--------------------	----------------

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	<u>6</u> IN.	Time Start:	HRS
<u>1</u>	<u>.16</u>	<u>8.00</u>	<u>14.00</u>		
<u>2</u>	<u>.50</u>	<u>24.00</u>	<u>30.00</u>		
<u>3</u>	<u>.83</u>	<u>40.00</u>	<u>46.00</u>		
Temp. Meas. Device & S/N: <u>PDT # 2</u>				Time End:	HRS

R or nothing = reg. manometer; S = expanded; E = electronic

032594-G:\STACK\WP\FORMS\IS-392.1

Calibration Error Check

Job LP number 27
 Test 2 Run 0 Date 8-27-96
 Operator S. BAZZELLE

TML
 Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	100	0
Low Level	29.9	29.94	-0.4	1000	-0.04%
Mid Level	294.4	292.6	1.8	10000	0.002%
High Level	2990	2990	0	10000	0

NO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	250	0
Mid Level	90.6	91	-0.4	250	0.2%
High Level	143	143	0	250	0

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	25%	0
Mid Level	13.5	13.5	0	25%	0
High Level	21.1	21.5	0	25%	0

CO₂ Calibration

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	20%	0
Mid Level	10.7	10.7	0	20%	0
High Level	16.6	16.6	0	20%	0

CO Calibration

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	1000	0
Mid Level	147	148	1	1000	0.1%
High Level	279	279	0	1000	0

INTERPOL LABORATORIES, INC
(612) 786-6020
System Bias Check

Job LP NEW BERRY Source DMETHANE TUBE
 Test 2 Run 0 Date 8-27-96 Site OUTLET
 Operator S. B. A. UDELE

Instrument	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		Diff. CE-SB (PPM)	Span Val. (PPM)	% of Span
			Cal. Err.	Sys. Bias			
CO	Zero Gas	0	0	0	0	1000	0
	Upscale	147	148	147	1	1000	.18
NOx	Zero Gas	0	0	0	0	250	0
	Upscale	90.6	91	91	0	250	0
O2	Zero Gas	0	0	0	0	25%	0
	Upscale	13.5	13.5	13.5	0	25%	0
CO2	Zero Gas	0	0	0	0	20%	0
	Upscale	10.7	10.7	10.7	0	20%	0
THC	Zero Gas	0	0	0	0	1000.00	0%
	Upscale	29.9	29.94	29.81	.14	1000.00	.018
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						
	Zero Gas	0					
	Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

CO Cal Drift Check

Job CP Newbury Source DRYER ETUPE OUTLET
 Test 2 Run 0 Date 8-27-96 Site OUTLET
 Operator J.D. / D.H.

OTUE
ON
OFF
ON
ON
ON

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₄
				Initial	Final			
1	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	147	147	147	██████	147	
2	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	147	147	144	██████	145.5	
3	762.48	Zero Gas	0	0	0	0	██████	770.34
		Upscale	147	147	144	██████	145.5	
4	355.46	Zero Gas	0	0	-4	-2	██████	356.11
		Upscale	147	147	150	██████	148.5	
5	406.53	Zero Gas	0	0	3	1.5	██████	412.34
		Upscale	147	147	145	██████	146	
6		Zero Gas	0			.	██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

NOX Cal Drift Check

Job LP number 47 Source DMYER ETUBE-OUT
 Test 2 Run 0 Date 8-27-46 Site OUTLET
 Operator S.D. / DM

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	90.6	91	91	██████	91	
2	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	90.6	91	91	██████	91	
3	13.24	Zero Gas	0	0	0	0	██████	13.23
		Upscale	90.6	91	91	██████	91	
4	14.12	Zero Gas	0	0	0	0	██████	14.05
		Upscale	90.6	91	91	██████	91	
5	17.93	Zero Gas	0	0	0	0	██████	17.66
		Upscale	90.6	91	93	██████	92	
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

02 Cal Drift Check

Job
Test
Operator

LP new bench
2 Run 0 Date 8-27-96
SD / DTT

Source DMIER ETUDE
Site OUTLET

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _s	C _m	C ₂₅
				Initial	Final			
1	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.5	██████	13.5	
2	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	13.5	13.5	13.4	██████	13.45	
3	16.63	Zero Gas	0	0	0	0	██████	16.89
		Upscale	13.5	13.5	13.4	██████	13.45	
4	17.23	Zero Gas	0	0	-1	.05	██████	17.12
		Upscale	13.5	13.5	13.7	██████	13.6	
5	17.04	Zero Gas	0	0	.2	.1	██████	17.06
		Upscale	13.5	13.5	13.5	██████	13.5	
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

Cal Drift Check

Job

LP Newberry

Source

DRYER E TUBE

Test

Run 0 Date 8-27-96

Site

OUTLET

Operator

SD / O.H.

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	10.7	10.7	10.7	██████	10.7	
2	VOID	Zero Gas	0	0	0	0	██████	
		Upscale	10.7	10.7	10.6	██████	10.65	
3	3.85	Zero Gas	0	0	0	0	██████	3.85
		Upscale	10.7	10.7	10.7	██████	10.7	
4	3.51	Zero Gas	0	0	0	0	██████	3.51
		Upscale	10.7	10.7	10.7	██████	10.7	
5	3.57	Zero Gas	0	0	0	0	██████	3.57
		Upscale	10.7	10.7	10.7	██████	10.7	
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

TML Cal Drift Check

Job

LP new bench

Source

DMEA ETUBE

Test

2 Run 0 Date 8-27-96

Site

OUTLET

Operator

SB-10-M

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _s	C _m	C ₂₅
				Initial	Final			
1	VAD	Zero Gas	0	1	.13	.57	██████	
		Upscale	29.9	30.5	29.13	██████	29.82	
2	VAD	Zero Gas	0	0	.52	.26	██████	
		Upscale	29.9	29.13	29.07	██████	29.50	
3	83.46	Zero Gas	0	.52	.68	.60	██████	85.23
		Upscale	29.9	29.87	29.47	██████	29.67	
4	50.36	Zero Gas	0	.68	0	.34	██████	50.87
		Upscale	29.9	29.47	30.0	██████	29.74	
5	43.38	Zero Gas	0	0	1	.5	██████	44.21
		Upscale	29.9	30.0	29.00	██████	29.50	
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

1-46-1756
~~1-5-1755~~
 1451
 2055
 2136
 2135

INTERPOLL LABORATORIES, INC

(612) 786-6020

EPA Method 25 A

Calibration Error Check & Drift Determination

Job LP/ Newberry
 Test 2 Run _____ Date 2-27-96
 Operator Bug

THC Calibration (Low Range): Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	100	
Low Level	29.9	30	.1	100	
Mid Level	294.4	300	5.6	1000	
High Level	2990	2980	10	1000	

THC Calibration (High Range): Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0				
Span					

O₂ Calibration: Time (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

CO₂ Calibration: Time: (HRS) _____

***	Cylinder Value (%)	Analyzer Response (%)	Difference (%)	Span Value (%)	Percent of Span
Zero Gas	0				
Mid Level					
High Level					

Must be within 2% of the span for each calibration gas.

052394-G:\STACK\WP\FORMS\5-420-14

Calibration Error Check

Job LP / Newbury
 Test 2 Run _____ Date 5-26-96
 Operator DOB

SO₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	200	
Mid Level	82.1	82.51	.40	200	
High Level	116.4	116.79	1.61	200	

NO_x Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	200	
Mid Level	73.7	73.63	.07	200	
High Level	148.	149.52	1.52	200	

O₂ Calibration:

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	0	0	25	
Mid Level	13.4	13.35	.05	25	
High Level	20.8	20.83	.03	25	

CO₂ Calibration

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	.01	-.01	20	
Mid Level	10.8	11.0	.2	20	
High Level	16.8	16.7	.1	20	

CO Calibration

Time (HRS) _____

***	Cylinder Value (PPM)	Analyzer Response (PPM)	Difference (PPM)	Span Value (PPM)	Percent of Span
Zero Gas	0	4	4	500	
Mid Level	140	140.12	-.12	500	
High Level	296	290	6	500	

INTERPOLL LABORATORIES, INC

(612) 786-6020

SO₂ Cal Drift Check

Job

CPI New Brkly

Source

Prep RTO

Test

Run

Date 6-27-86

Site

GTREC

Operator

613

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1	VOID	Zero Gas	0	.07	.34			
		Upscale	82.1	83.73	83.30			
2	VOID	Zero Gas	0	.34	1			
		Upscale	82.1	83.3	85			
3	0.47	Zero Gas	0	1	0.5	0.75		< 1
		Upscale	82.1	85	82.79			
4	0.22	Zero Gas	0	.5	0.56	0.53		< 1
		Upscale	82.1	82.79	85-85			
5	0.37	Zero Gas	0	.56	.63	0.60		< 1
		Upscale	82.1	85-85	82.72			
6		Zero Gas	0	.63	0			
		Upscale	82.1	83.72	80.41			
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

111-

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC
(612) 786-6020

NOx Cal Drift Check

Job CP/ Mamber Source Dryer RTO
 Test 2 Run 8-25-92 Date 8-25-92 Site STACK
 Operator Bos

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C _{gas}
				Initial	Final			
1	VOID	Zero Gas	0	0	0			
		Upscale	73.7	74.14	73.45			
2	VOID	Zero Gas	0	0	0			
		Upscale	73.7	73.93	74.68			
3	17.50	Zero Gas	0	0	0			
		Upscale	73.7	74.68	74.98		74.83	17.24
4	19.71	Zero Gas	0	0	0			
		Upscale	73.7	74.98	74.49		74.74	19.44
5	17.75	Zero Gas	0	0	0			
		Upscale	73.7	74.49	76		75.25	17.39
6		Zero Gas	0	0	0			
		Upscale	73.7	76	75.39			
7		Zero Gas	0					
		Upscale						
8		Zero Gas	0					
		Upscale						
9		Zero Gas	0					
		Upscale						
10		Zero Gas	0					
		Upscale						
11		Zero Gas	0					
		Upscale						
12		Zero Gas	0					
		Upscale						

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO Cal Drift Check

Job CP/ Newbury Source Oxyel RTO
 Test 2 Run Date 8-27-96 Site SFFAC
 Operator Benz

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	VOID	Zero Gas	0	8	1		██████	
		Upscale	140	136	144	██████		
2	VOID	Zero Gas	0	1	6	██████	██████	
		Upscale	140	144	145	██████		
3	65.95	Zero Gas	0	6	6	6.0	██████	60.09
		Upscale	140	145	146.36	██████	145.68	
4	44.41	Zero Gas	0	6	3	4.5	██████	39.50
		Upscale	140	146.32	145.53	██████	145.95	
5	27.14	Zero Gas	0	3	6	4.5	██████	22.28
		Upscale	140	145.53	148	██████	146.77	
6		Zero Gas	0	6	3		██████	
		Upscale	140	148	138	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

02 Cal Drift Check

Job (P) Newbury
 Test 2 Run _____ Date 6-27-86
 Operator Bob

Source Pryer RTO
 Site STAC

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _s	C _m	C ₂₅
				Initial	Final			
1		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.36	13.37	██████		
2		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.37	13.37	██████		
3		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.37	13.37	██████		
4		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.37	13.34	██████		
5		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.34	13.4	██████		
6		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.4	13.34	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO2 Cal Drift Check

Job LPI Newberry Source Dryer RTO
 Test 2 Run Date 5-27-96 Site SMAC
 Operator Buz

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _g	C _m	C ₂₂
				Initial	Final			
1		Zero Gas	0	0	101		██████	
		Upscale	10.8	10.88	10.72	██████		
2		Zero Gas	0	.01	.01		██████	
		Upscale	10.8	10.72	10.75	██████		
3		Zero Gas	0	.01	0		██████	
		Upscale	10.8	10.75	10.72	██████		
4		Zero Gas	0	0	0		██████	
		Upscale	10.8	10.72	10.74	██████		
5		Zero Gas	0	0	102		██████	
		Upscale	10.8	10.74	10.78	██████		
6		Zero Gas	0	.02	0		██████	
		Upscale	10.8	10.74	.06	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC

(612) 786-6020

THC Cal Drift Check

Job

191 Moberg

Source

Dryer RTO

Test

2 Run

Date 2-22-96

Site

STACK

Operator

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1	VOID	Zero Gas	0	.87	.5		██████	
		Upscale	29.94	29.77	27.69	██████		
2	VOID	Zero Gas	0	.5	.5		██████	
		Upscale	29.94	29	29.5	██████		
3	15.26	Zero Gas	0	.5	.5	0.50	██████	15.16
		Upscale	29.94	29.5	29.81	██████	29.66	
4	7.21	Zero Gas	0	.5	.4	0.45	██████	6.90
		Upscale	29.94	29.81	29.76	██████	29.79	
5	7.86	Zero Gas	0	.4	.5	0.45	██████	7.67
		Upscale	29.94	29.76	29.0	██████	29.30	
6		Zero Gas	0	.5	.63		██████	
		Upscale	29.94	29	28.27	██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

O₂ Cal Drift Check

Job LP1 Number Source Dryer RTO
 Test 344 Run Date 8-28-96 Site STACIL
 Operator _____

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.37	13.38	██████		
2		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.38	13.37	██████		
3		Zero Gas	0	0	0		██████	
		Upscale	13.4	13.37	13.4	██████		
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

CO₂ Cal Drift Check

Job

CP/ Newberry

Source

Dryer RTO

Test

3-4 Run Date 8-28-91

Site

STATIC

Operator

GIS

Run	C	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1		Zero Gas	0	0	1.02		██████	
		Upscale	10.8	10.74	10.6	██████		
2		Zero Gas	0	.02	.04		██████	
		Upscale	10.8	10.6	10.60	██████		
3		Zero Gas	0	.04	.02		██████	
		Upscale	10.8	10.6	10.6	██████		
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC.
(612) 786-6020
EPA Method 2 Field Data Sheet

Drawing of Test Site

Job L.P. / Newberry, MI
 Source Pase / Ventr
 Test 9 Run Q Date 8-29-96
 Stack Dimen. (59 x 59) 2 stacks IN.
 Dry Bulb 110 °F Wet bulb 64 °F
 Manometer Reg. Exp Elec.
 Barometric Pressure 29.29 IN.HG
 Static Pressure -2.37 IN.WC
 Operators M. Kachlert M. Petersen
 Pitot No. INST C. NA

Cross-section View	Elevation View
--------------------	----------------

NOx/CO/THC's

Traverse Point No.	Fraction of Diameter	Distance From Stack Wall (IN.)	Distance From End of Port (IN.)	Velocity	Temp. of Gas
		Port Length:	<u>5.5</u> IN.	Time Start:	<u>NA</u> HRS
	<u>1/6</u>	<u>9.83</u>	<u>15.33</u>		
	<u>3/6</u>	<u>29.50</u>	<u>35.00</u>		
	<u>5/6</u>	<u>49.17</u>	<u>54.67</u>		
Temp. Meas. Device & S/N: <u>PDT-31/TC</u>				Time End: <u>NA</u> HRS	

R or nothing = reg. manometer; S = expanded; E = electronic

INTERPOLL LABORATORIES, INC

(612) 786-6020

NUC Cal Drift Check

Job A.P. / Newberry, 111
 Test 9 Run 1, 2, 3 Date 6-29-91
 Operator M. Kaebler

Source D-558
 Site vents

0400
1002
1035
1136

Run	\bar{c}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1 a/l	.9917	Zero Gas	0	0.2	0.1	0.15	██████	0.84
		Upscale	91.9	92.6	91.5	██████	92.05	
2 u/v	1.09	Zero Gas	0	0.1	0.5	0.3	██████	1.61
		Upscale	91.9	91.5	91.0	██████	91.25	
3 9/3	1.08	Zero Gas	0	0.5	0.7	0.6	██████	1.41
		Upscale	91.9	91.0	90.0	██████	90.5	
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOLL LABORATORIES, INC

(612) 786-6020

C.O Cal Drift Check

Job L.P. / Newberry - M1 Source Parsi
 Test 9 Run 1, 2, 3 Date 8-29-96 Site Vents
 Operator M. Kuehler

Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C _o	C _m	C _{gas}
				Initial	Final			
1 9/11	6.72	Zero Gas	0	1	0	0.5	██████	6.19
		Upscale	143.3	145	144	██████	144.5	
2 9/12	4.60	Zero Gas	0	0	3	1.5	██████	3.18
		Upscale	143.3	144	146	██████	145	
3 9/13	6.33	Zero Gas	0	3	5	4	██████	2.4
		Upscale	143.3	146	146	██████	146	
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.

INTERPOL LABORATORIES, INC


(612) 786-6020

THC Cal Drift Check

Job L.P. / Newberry MI Source Press
 Test 9 Run 1, 2, 3 Date 9-29-96 Site Vents
 Operator M. Kuchler


Run	\bar{C}	***	Cylinder Value (PPM)	Analyzer Resp (PPM)		C ₀	C _m	C ₂₅
				Initial	Final			
1 9/1	1.35	Zero Gas	0	0.3	-0.4	-0.05	██████	1.40
		Upscale	30.5	30.7	30.4	██████	30.55	
2 9/2	4.35	Zero Gas	0	0.2	0.4	0.3	██████	4.12
		Upscale	30.5	30.4	30.1	██████	30.25	
3 9/3	2.48	Zero Gas	0	0.4	0.3	0.35	██████	2.20
		Upscale	30.5	30.1	29.7	██████	29.9	
4		Zero Gas	0				██████	
		Upscale				██████		
5		Zero Gas	0				██████	
		Upscale				██████		
6		Zero Gas	0				██████	
		Upscale				██████		
7		Zero Gas	0				██████	
		Upscale				██████		
8		Zero Gas	0				██████	
		Upscale				██████		
9		Zero Gas	0				██████	
		Upscale				██████		
10		Zero Gas	0				██████	
		Upscale				██████		
11		Zero Gas	0				██████	
		Upscale				██████		
12		Zero Gas	0				██████	
		Upscale				██████		

Must be within 5% of the span for the zero or upscale cal. gas.



APPENDIX H

CALIBRATION GAS CERTIFICATION SHEETS



NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS • EPA PROTOCOL MIXTURES

REFERENCE #: 88-46472 CYLINDER #: 2600 PSIG P.O. #: 22209
EXP. DATE: 3/14/99 LAST ANALYSIS DATE: 3/14/96 CYL. PRESSURE: TWIN CITY OXYGEN
METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993.G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG). CUSTOMER: 2000 PSIG TWIN CITY OXYGEN

COMPONENT: CARBON DIOXIDE		COMPONENT: OXYGEN		COMPONENT: NITROGEN	
STANDARD	SRM #: 1675B	STANDARD	SRM #: 2659A	STANDARD	SRM #: 2659A
	CYL. #: CLM16481		CYL. #: CLM16737		CYL. #: CLM16737
	CONC: 14.01 %		CONC: 20.72 %		CONC: 20.72 %
INSTRUMENT: ROSEMOUNT NDIR	MODEL #: 980	INSTRUMENT: BECKMAN PARAMAGNETIC	MODEL #: 755	INSTRUMENT: BECKMAN PARAMAGNETIC	MODEL #: 755
SERIAL #: 2600418	LAST CAL.: 2/20/96	SERIAL #: 1001419	LAST CAL.: 3/1/96	SERIAL #: 1001419	LAST CAL.: 3/1/96
MEAN CONC.: 16.6% +/-	0.13 %	MEAN CONC.: 21.1% +/-	0.17 %	MEAN CONC.: 21.1% +/-	0.17 %
REPLICATE CONC.	DATE: 3/14/96	REPLICATE CONC.	DATE: 3/14/96	REPLICATE CONC.	DATE: 3/14/96
DATE: 16.6 %		DATE: 21.1 %		DATE: 21.1 %	
DATE: 16.7 %		DATE: 21.0 %		DATE: 21.0 %	
DATE: 16.6 %		DATE: 21.1 %		DATE: 21.1 %	

BALANCE GAS: NITROGEN		BALANCE GAS: NITROGEN	
REPLICATE DATA	REPLICATE DATA	REPLICATE DATA	REPLICATE DATA
DATE: 3/14/96	DATE: 3/14/96	DATE: 3/14/96	DATE: 3/14/96
Z 0 R 14.1 C 16.7	Z 0 R 400.3 C 407.7	Z 0 R 400.2 C 407.5	Z 0 R 400.3 C 407.7
R 14.1 Z 0 C 16.8	Z 0 R 400.3 C 407.7	R 400.2 Z 0 C 407.5	R 400.2 Z 0 C 407.5
Z 0 C 16.6 R 14.0	Z 0 R 400.3 C 407.7	Z 0 R 400.2 C 407.5	Z 0 R 400.3 C 407.7
DATE: R 14.1 Z 0 C 16.6	DATE: Z 0 R 400.3 C 407.7	DATE: R 400.2 Z 0 C 407.5	DATE: Z 0 R 400.3 C 407.7
Z R C	Z R C	Z R C	Z R C
Z R C	Z R C	Z R C	Z R C
Z R C	Z R C	Z R C	Z R C

ANALYST: *Robert M...* APPROVED BY: *Laura J. Hartline*
Z = ZERO C-CANDIDATE R-REFERENCE

THE ANALYST'S SIGNATURE AND THE RESULTS OF THE ANALYSIS ARE VALID FOR THE ANALYSIS DATE AND ONLY FOR THE ANALYSIS DATE. THIS REPORT HAS BEEN MADE TO THE BEST OF OUR KNOWLEDGE AND BELIEF. NATIONAL SPECIALTY GASES, INC. DURHAM, NC 27713. 4/19/94 577

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #:	88-48212	CYLINDER #:	CC 52399	CYL. PRESSURE:	2000 PSIG	P.O. #:	23662
EXP. DATE:	6/21/96	LAST ANALYSIS DATE:	6/21/96	CUSTOMER:	TWIN CITY OXYGEN		

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG).

COMPONENT: CARBON DIOXIDE		COMPONENT: OXYGEN	
STANDARD		STANDARD	
SRM #:	1675D	SRM #:	2659A
CYL. #:	CLM 6481	CYL. #:	CLM 6777
CONC:	14.01 %	CONC:	20.72 %
INSTRUMENT: ROSEMOUNT NDIR		INSTRUMENT: BECKMAN PARAMAGNETIC	
MODEL #:	880	MODEL #:	755
SERIAL #:	2000418	SERIAL #:	1001419
LAST CAL.:	6/20/96	LAST CAL.:	6/19/96

MEAN CONC.:	10.7 %	+/-	0.09 %	MEAN CONC.:	13.5 %	+/-	0.11 %
REPLICATE CONC.				REPLICATE CONC.			
DATE:	6/21/96	DATE:	6/21/96	DATE:	6/21/96	DATE:	6/21/96
10.7 %	%	13.5 %	%	13.5 %	%	13.4 %	%
10.8 %	%						
10.7 %	%						

BALANCE GAS: NITROGEN				BALANCE GAS: OXYGEN			
REPLICATE DATA				REPLICATE DATA			
DATE:	6/21/96	DATE:	6/21/96	DATE:	6/21/96	DATE:	6/21/96
Z 0	R 209	C 160		Z 0	R 312	C 203	
R 209	Z 0	C 161		R 312	Z 0	C 203	
Z 0	C 159	R 208		Z 0	C 202	R 313	

ANALYST: *James Rags*
APPROVED BY: *Richard Sykes*
Z= ZERO C=CANDIDATE R=REFERENCE

THIS REPORT STATES ACCURATELY THE RESULTS OF THE INVESTIGATION. HOWEVER, THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT WILL BE MADE TO IDENTIFY AND CORRECTLY THE INFORMATION PROVIDED. HOWEVER, IN CONNECTION WITH THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE. ASAYED AT: NATIONAL SPECIALTY GASES, 630 UNITED DRIVE, DURHAM, NC 27713 401931-173

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #: 88-16473 CYLINDER #: CC 61410 CYL. PRESSURE: 2000 PSIG P.O. #: 22349
EXP. DATE: 3/14/96 LAST ANALYSIS DATE: 3/14/96 CUSTOMER: TWIN CITY OXYGEN

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993(G-1) THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG)

COMPONENT: CARBON DIOXIDE		COMPONENT: OXYGEN	
STANDARD	STANDARD	STANDARD	STANDARD
SRM #: 1675B	SRM #: 2639A	SRM #: 2639A	SRM #:
CYL #: CLM 6481	CYL #: CLM 6737	CYL #: CLM 6737	CYL #:
CONC: 14.01 %	CONC: 20.72 %	CONC: 20.72 %	CONC:
INSTRUMENT: ROSEMOUNT NDIR	INSTRUMENT: BECKMAN PARAMAGNETIC	INSTRUMENT: BECKMAN PARAMAGNETIC	INSTRUMENT:
MODEL #: 880	MODEL #: 755	MODEL #: 755	MODEL #:
SERIAL #: 2060418	SERIAL #: 1601419	SERIAL #: 1601419	SERIAL #:
LAST CAL.: 2/20/96	LAST CAL.: 3/1/96	LAST CAL.: 3/1/96	LAST CAL.:
MEAN CONC.: 10.8% ±4	MEAN CONC.: 13.4% ±4	MEAN CONC.: 13.4% ±4	MEAN CONC.:
REPLICATE CONC.	REPLICATE CONC.	REPLICATE CONC.	REPLICATE CONC.
DATE: 3/14/96	DATE: 3/14/96	DATE: 3/14/96	DATE:
10.8 %	13.4 %	13.4 %	
10.9 %	13.5 %	13.5 %	
10.8 %	13.4 %	13.4 %	

BALANCE GAS: NITROGEN

REPLICATE DATA		REPLICATE DATA		REPLICATE DATA	
DATE: 3/14/96	DATE: 3/14/96	DATE: 3/14/96	DATE:	DATE:	DATE:
Z 0 R 14.0 C 10.8	Z 0 R 400.3 C 258.9	Z 0 R 400.3 C 258.9	Z	Z	Z
R 14.1 Z 0 C 11.0	R 400.2 Z 0 C 260.7	R 400.2 Z 0 C 260.7	R	R	R
Z 0 C 10.9 R 14.1	Z 0 C 358.9 R 400.4	Z 0 C 358.9 R 400.4	Z	Z	Z
DATE	DATE:	DATE:	DATE:	DATE:	DATE:
Z R C	Z R C	Z R C	Z	Z	Z
R C C	R C C	R C C	R	R	R
Z C R	Z C R	Z C R	Z	Z	Z

ANALYST: *[Signature]* APPROVED BY: *[Signature]*
 THIS CERTIFICATE ANALYZED THE RESULTS OF THE DIVISION'S INSTRUMENTS SUBMITTED TO THE CHEMICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO OBTAIN THE MOST ACCURATE RESULTS POSSIBLE. THE PERCENTAGE OF ANALYTICAL IMPURITY SHALL HAVE IMPACTED THE RESULTS OF THIS ANALYSIS. NATIONAL SPECIALTY GASES, DURHAM, NC 27713 (919)544-3772

NATIONAL SPECIALTY GASES
 630 UNITED DRIVE
 DURHAM, NC 27713
 (919)544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-40607 CYLINDER #:CC46348 CYL. PRESSURE:2000PSIG
 EXPIRATION DATE: 6/2/98 LAST ANALYSIS DATE:6/2/95
 CUSTOMER: TWIN CITY OXYGEN P.O.# 17405

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION
 OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1.
 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0
 MEGAPASCALS (150 PSIG).

STANDARD: INSTRUMENT:BECKMAN NDIR BECKMAN PARAMAGNETIC
 SRM #: 1675B 2659A MODEL #:880 755
 CYL #: CLM6413 CLM6737 SERIAL #:2000418 1001419
 CONC.: 14.01% 20.72% LAST CAL.:5/22/95 6/1/95

COMPONENT:CO2	COMPONENT: O2	COMPONENT:
MEAN CONC:16.8%	MEAN CONC: 21.0%	MEAN CONC:
REPLICATE CONC.	REPLICATE CONC.	REPLICATE CONC.
DATE:6/2/95 DATE:	DATE:6/2/95 DATE:	DATE: DATE:
16.8%	21.0%	
16.8%	21.0%	
16.9%	21.1%	

BALANCE GAS:N2

REPLICATE DATA

DATE: 6/2/95				
Z 0 R	168.0	C	201.5	
R 168.5 Z	0	C	202.1	
Z 0 C	203.9	R	169.0	

COMPONENT:CO2

DATE:		
Z R		C
R Z		C
Z C		R

REPLICATE DATA

DATE: 6/2/95				
Z 0 R	210.0	C	212.8	
R 210.5 Z	0	C	213.0	
Z 0 C	214.9	R	211.0	

COMPONENT:O2

DATE:		
Z R		C
R Z		C
Z C		R

REPLICATE DATA

DATE:		
Z R		C
R Z		C
Z C		R

COMPONENT:

DATE:		
Z R		C
R Z		C
Z C		R

Z=ZERO C=CANDIDATE R=REFERENCE

ANALYST: *Mary A. Savage*

APPROVED BY: *Jana Rowe*

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY, THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

**NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713**

(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #: 88-45052 CYLINDER #: CYL. PRESSURE: 2000PSIG P.O. #: TWIN CITY OXYGEN
 EXP. DATE: 1/5/99 LAST ANALYSIS DATE: 1/5/96 CUSTOMER:

METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG).

COMPONENT: STANDARD	COMPONENT: STANDARD
SRM #: 1680B	SRM #:
CYL. #: PF 34077	CYL. #
CONC: 477 PPM	CONC:
INSTRUMENT: MODEL #: 880A	INSTRUMENT: MODEL #:
SERIAL #: 2000172	SERIAL #:
LAST CAL.: 12/13/95	LAST CAL.:

MEAN CONC.: 289 PPM	MEAN CONC.: 2.31 PPM
REPLICATE CONC.:	REPLICATE CONC.:
DATE: 12/28/95	DATE: 1/5/96
289 PPM	289 PPM
289 PPM	289 PPM
290 PPM	289 PPM

BALANCE GAS: NITROGEN

REPLICATE DATA	REPLICATE DATA	REPLICATE DATA
DATE: 12/28/95	DATE:	DATE:
Z 0 R 478 C 289.6	R C	Z R C
R 477 Z 0 C 289.0	Z C	R Z C
Z 0 C 290.0 R 477	Z C	Z C R
DATE: 1/5/96	DATE:	DATE:
Z 0 R 478 C 289.6	R C	Z R C
R 477 Z 0 C 289	Z C	R Z C
Z 0 C 289.6 R 478	Z C	Z C R

ANALYST: *Jim Hare* Z= ZERO C=CANDIDATE R=REFERENCE APPROVED BY: *Nama J. Hare*
 THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED, HOWEVER, IN CONNECTION WITH THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS METAL BRIDG CHARGE FOR THE SERVICE ASSAYED AT. NATIONAL SPECIALTY GASES, 630 UNITED DRIVE DURHAM, NC 27713 (919)544-3772

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC 27713
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-25249 CYLINDER #:CC44391 CYL. PRESSURE: 200PSG

EXPIRATION DATE: 7-7-96 LAST ANALYSIS DATE:7-7-93

CUSTOMER:TWIN CITY OXYGEN

P.O.# 5337

METHOD: EPA PROTOCOL # 13.0.4.G-1

STANDARD:

SRM #:1681B

CYL #:CLM4470

CONC.:975PPM

INSTRUMENT:

BECKMAN

COMPONENT: NDIR

MODEL #: 865

SERIAL #: 0103409

LAST CAL: 4-2-93

COMPONENT: CO

MEAN CONC: 620PPM

REPLICATE CONC.

DATE: 6-30-93 DATE: 7-7-93

623PPM 618PPM

620PPM 616PPM

621PPM 619PPM

COMPONENT:

MEAN CONC:

REPLICATE CONC.

DATE: DATE:

COMPONENT:

MEAN CONC:

REPLICATE CONC.

DATE: DATE:

BALANCE GAS:N2

Air Products and Chemicals, Inc.
 SPECIALTY GAS DEPARTMENT
 12722 S. WENTWORTH AVENUE
 CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:
 AIR PRODUCTS & CHEMICALS, INC.
 373 CANTERBURY ROAD
 SHAKOPEE MN 55379

Notes:


Cylinder No: SG9151275BAL
 Cylinder Pressure*: 2000 psig
 Certification Date: 05/27/95
 Expiration Date: 05/27/98


PO: Rel: ******* Reference Standards ***** Analytical Instrumentation *******

*** Certified Concentration ***	Standard	Instrument	Serial	Last	Measurement
Concentration	Number	Make/Model	Number	Calibration	Principal
140 ±0.4 PPM	CGMIS	151.5000 PPM	Horiba VIA-510	405079	05/20/95
					INFRARED HORIBA

Balance Gas: Nitrogen

* Standard should not be used below 150 psig

Analyst: 
 James Laas

Approved By: 
 Robert McNear

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of 1

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

PO: Rel:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****

Certified

Component Concentration Cylinder #
CARBON MONOXIDE 147 ±0.4 PPM SG9113611BAL

Standard

Number Concentration
151.5000 PPM

Instrument

Make/Model Number Calibration
151.5000 PPM Horiba VIA-510 405079 05/20/95

Serial

Last Measurement
Principal

Measurement

Order No: CSS-188055-01
Batch No: 861-26103
Cylinder No: SG9150306BAL
Cylinder Pressure*: 2000 psig
Certification Date: 06/13/95
Expiration Date: 06/13/98

Balance Gas: Nitrogen

H
1
00

* Standard should not be used below 150 psig

Analyst:

Shaker Aboor

Shaker Aboor

Approved By:

Robert McNear

Robert McNear

air standards and chemicals, inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of 1

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-411663-01
Batch No: 861-31683

Cylinder No: SG9136041BAL
Cylinder Pressure*: 2000 psig
Certification Date: 04/29/96
Expiration Date: 04/29/98

PO: Rel: *** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****
Certified Standard

Component	Concentration	Cylinder #	Number	Concentration	Make/Model	Instrument	Serial	Last	Measurement
NITRIC OXIDE	90.6 ±.27	PPM SG9148169BAL	GMIS	96.0200	PPM Rosemount 951a	0101877	04/19/96	CHEMILUMINESCENCE	

Balance Gas: NITROGEN

Contaminant

Nitrogen Dioxide .400 PPM


* Standard should not be used below 150 psig

Analyst:

James Laas

Approved By:

Richard Fry



Certificate of Analysis for Standard Gas

Vendor Air Products
Cylinder No. SG 916 2775
Date of Preparation 11-9-95
Label Nitric Oxide
Blend Specification 145 ppm Balance N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run	NOx	
4-5-96	1	143.3031	
4-5-96	2	142.8554	
4-5-96	3	142.9570	
	4		
	5		
	6		
	Avg	143.0385	-1.35%

Analyst Boz A

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: April 5, 1996
Approved by: [Signature]

INTERPOL LABS

TANK CERT
 TANK NUMBER SG9162775
 4/5/96

4/5/96	12:29:00 PM			
0	144.809	0	0	0
4/5/96	12:29:06 PM			
0	144.809	0	0	0
4/5/96	12:29:12 PM			
0	144.809	0	0	0
4/5/96	12:29:18 PM			
0	143.995	0	0	0
4/5/96	12:29:24 PM			
0	143.588	0	0	0
4/5/96	12:29:30 PM			
0	143.181	0	0	0
4/5/96	12:29:36 PM			
0	143.995	0	0	0
4/5/96	12:29:42 PM			
0	143.181	0	0	0
4/5/96	12:29:48 PM			
0	143.588	0	0	0
4/5/96	12:29:54 PM			
0	142.774	0	0	0
4/5/96	12:30:00 PM			
0	143.588	0	0	0
4/5/96	12:30:06 PM			
0	142.774	0	0	0
4/5/96	12:30:12 PM			
0	142.367	0	0	0
4/5/96	12:30:18 PM			
0	142.774	0	0	0
4/5/96	12:30:24 PM			
0	142.774	0	0	0
4/5/96	12:30:30 PM			
0	142.774	0	0	0
4/5/96	12:30:36 PM			
0	142.367	0	0	0
4/5/96	12:30:42 PM			
0	143.181	0	0	0
4/5/96	12:30:48 PM			
0	142.367	0	0	0
4/5/96	12:30:54 PM			
0	142.367	0	0	0

143.3031

INTERPOLLABS

TANK CERT
 TANK NUMBER SG9162775
 4/5/96

4/5/96	12:36:00 PM			
0	144.402	0	0	0
4/5/96	12:36:06 PM			
0	144.809	0	0	0
4/5/96	12:36:12 PM			
0	143.181	0	0	0
4/5/96	12:36:18 PM			
0	143.588	0	0	0
4/5/96	12:36:24 PM			
0	143.181	0	0	0
4/5/96	12:36:30 PM			
0	142.367	0	0	0
4/5/96	12:36:36 PM			
0	142.367	0	0	0
4/5/96	12:36:42 PM			
0	142.774	0	0	0
4/5/96	12:36:48 PM			
0	143.181	0	0	0
4/5/96	12:36:54 PM			
0	142.367	0	0	0
4/5/96	12:37:00 PM			
0	143.181	0	0	0
4/5/96	12:37:06 PM			
0	142.367	0	0	0
4/5/96	12:37:12 PM			
0	142.367	0	0	0
4/5/96	12:37:18 PM			
0	142.367	0	0	0
4/5/96	12:37:24 PM			
0	142.367	0	0	0
4/5/96	12:37:30 PM			
0	142.367	0	0	0
4/5/96	12:37:36 PM			
0	142.367	0	0	0
4/5/96	12:37:42 PM			
0	141.96	0	0	0
4/5/96	12:37:48 PM			
0	142.774	0	0	0
4/5/96	12:37:54 PM			
0	142.774	0	0	0

142.8554

INTERPOL LABS

TANK CERT
 TANK NUMBER SG9162775
 4/5/96

4/5/96	12:42:00 PM			
0	144.809	0	0	0
4/5/96	12:42:06 PM			
0	144.402	0	0	0
4/5/96	12:42:12 PM			
0	143.995	0	0	0
4/5/96	12:42:18 PM			
0	143.181	0	0	0
4/5/96	12:42:24 PM			
0	143.588	0	0	0
4/5/96	12:42:30 PM			
0	143.995	0	0	0
4/5/96	12:42:36 PM			
0	142.774	0	0	0
4/5/96	12:42:42 PM			
0	143.181	0	0	0
4/5/96	12:42:48 PM			
0	142.367	0	0	0
4/5/96	12:42:54 PM			
0	142.774	0	0	0
4/5/96	12:43:00 PM			
0	142.367	0	0	0
4/5/96	12:43:06 PM			
0	141.96	0	0	0
4/5/96	12:43:12 PM			
0	143.181	0	0	0
4/5/96	12:43:18 PM			
0	142.774	0	0	0
4/5/96	12:43:24 PM			
0	142.367	0	0	0
4/5/96	12:43:30 PM			
0	142.367	0	0	0
4/5/96	12:43:36 PM			
0	142.367	0	0	0
4/5/96	12:43:42 PM			
0	142.367	0	0	0
4/5/96	12:43:48 PM			
0	141.96	0	0	0
4/5/96	12:43:54 PM			
0	142.367	0	0	0

142.95715

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

TWIN CITY OXYGEN (MAIN ACCT.)
305 2ND STREET NW
NEW BRIGHTON MN 55112-

Notes:

Order No: CSS-296700-01
Batch No: 861-28757

Cylinder No: SG9162775BAL
Cylinder Pressure*: 2000 psig
Certification Date: 11/09/95
Expiration Date: 11/09/97

PO: 20013 Rel:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****
Certified Standard Instrument Serial Last Measurement

Component Concentration Cylinder #
NITRIC OXIDE 145 ±1.0 PPM SG9151688BAL GMIS 145.5000 PPM Rosemount: 951a 0101877 10/19/95 CHEMILUMINESCENCE


Balance Gas: NITROGEN

Contaminant


Nitrogen Dioxide 1.80 PPM

* Standard should not be used below 150 psig

Analyst:


Sherah Aboor

Approved By:


Richard Fry

Certificate of Analysis for Standard Gas

Vendor AIR PRODUCTS
Cylinder No. SG 9168059
Date of Preparation ~~4-4-96~~ 12-12-95
Label Nitric Oxide
Blend Specification 141 ppm Balance N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run	NO _x	
4-5-96	1	140.0888	
4-5-96	2	139.9667	
4-5-96	3	139.9463	
	4		
	5		
	6		
	Avg	140.0006	.7130

Analyst LAB A

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: April 5, 1996
Approved by: [Signature]

INTERPOLL LABS

TANK CERT
 TANK NUMBER SG9168059
 4/5/96

4/5/96	9:31:00 AM			
0	139.926	0	0	0
4/5/96	9:31:06 AM			
0	139.926	0	0	0
4/5/96	9:31:12 AM			
0	140.74	0	0	0
4/5/96	9:31:18 AM			
0	140.333	0	0	0
4/5/96	9:31:24 AM			
0	140.333	0	0	0
4/5/96	9:31:30 AM			
0	140.333	0	0	0
4/5/96	9:31:36 AM			
0	140.74	0	0	0
4/5/96	9:31:42 AM			
0	139.519	0	0	0
4/5/96	9:31:48 AM			
0	139.926	0	0	0
4/5/96	9:31:54 AM			
0	140.74	0	0	0
4/5/96	9:32:00 AM			
0	139.926	0	0	0
4/5/96	9:32:06 AM			
0	140.333	0	0	0
4/5/96	9:32:12 AM			
0	139.926	0	0	0
4/5/96	9:32:18 AM			
0	139.926	0	0	0
4/5/96	9:32:24 AM			
0	139.926	0	0	0
4/5/96	9:32:30 AM			
0	140.333	0	0	0
4/5/96	9:32:36 AM			
0	140.333	0	0	0
4/5/96	9:32:42 AM			
0	139.519	0	0	0
4/5/96	9:32:48 AM			
0	139.519	0	0	0
4/5/96	9:32:54 AM			
0	139.519	0	0	0

140.0888

INTERPOLLABS

TANK CERT
 TANK NUMBER GG9168058
 4/5/96

4/5/96	9:46:00 AM			
0	140.333	0	0	0
4/5/96	9:46:06 AM			
0	139.926	0	0	0
4/5/96	9:46:12 AM			
0	140.333	0	0	0
4/5/96	9:46:18 AM			
0	139.926	0	0	0
4/5/96	9:46:24 AM			
0	139.926	0	0	0
4/5/96	9:46:30 AM			
0	139.519	0	0	0
4/5/96	9:46:36 AM			
0	140.333	0	0	0
4/5/96	9:46:42 AM			
0	139.112	0	0	0
4/5/96	9:46:48 AM			
0	139.926	0	0	0
4/5/96	9:46:54 AM			
0	139.926	0	0	0
4/5/96	9:47:00 AM			
0	139.926	0	0	0
4/5/96	9:47:06 AM			
0	140.333	0	0	0
4/5/96	9:47:12 AM			
0	139.519	0	0	0
4/5/96	9:47:18 AM			
0	139.926	0	0	0
4/5/96	9:47:24 AM			
0	140.333	0	0	0
4/5/96	9:47:30 AM			
0	139.926	0	0	0
4/5/96	9:47:36 AM			
0	139.926	0	0	0
4/5/96	9:47:42 AM			
0	139.519	0	0	0
4/5/96	9:47:48 AM			
0	140.333	0	0	0
4/5/96	9:47:54 AM			
0	139.926	0	0	0

139.94635

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-320131-01
Batch No: 861-29293

Cylinder No: SG9168059BAL
Cylinder Pressure*: 2000 psig
Certification Date: 12/12/95
Expiration Date: 12/12/97

PO: Rel: ******* Reference Standards ***** Analytical Instrumentation *******


Component	Concentration	Cylinder #	Standard	Instrument	Serial	Last	Measurement		
NITRIC OXIDE	141 ±0.9 PPM	SG9151688BAL	GMIS	Concentration	145.5000 PPM	Rosemount 951a	0101877	11/20/95	CHEMILUMINESCENCE


Balance Gas: NITROGEN

Contaminant

Nitrogen Dioxide .400 PPM

* Standard should not be used below 150 psig

Analyst: 
James Laas

Approved By: 
Richard Fry

Certificate of Analysis for Standard Gas

Vendor SCOTT SPECIALTY GASES
Cylinder No. ALM 030977
Date of Preparation 11-2-92
Label NITRIC OXIDE
Blend Specification 144.1 PPM BALANCE N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run		
4-24-96	1	140.12	
4-24-96	2	138.04	
4-24-96	3	139.48	
4-24-96	4	140.30	
4-24-96	5	140.58	
4-24-96	6	139.47	
	Avg	139.738	

Analyst JAMES BANVILLE

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: APRIL 24, 1996
Approved by: [Signature]

Shipped From : Scott Michigan

Our Project # : 542740

Your P.O. # : 40543

Expiration Date : 4-19-94

Cylinder Number : ALM030977

Cylinder Pressure : 1900 ... psia

Certification Date : 10-19-92

1 of 1 Component(s)

Customer : GENEX
2455 CLEVELAND AVENUE
ROSEVILLE MN 55113

*** CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES ***

PERFORMED ACCORDING TO SECTION 3.0.4

Certified Per Traceability Procedure # 1

LAB # 5299

Certified Accuracy 1% NIST Traceable

ANALYZED CYLINDER
COMPONENT
NITRIC OXIDE
BALANCE GAS : NITROGEN

REFERENCE STANDARDS
CYLINDER NUMBER
ALM-008716
ALM-010464

INSTRUMENTATION
INSTRUMENT/SERIAL #
BECKMAN 951A
270-0828998

ANALYTICAL PRINCIPLE
CHEMILUMINESCENCE

NITROGEN DIOXIDE 1.00 PPM (FROM SECOND ANALYSIS)

FIRST ANALYSIS

DATE : 10-13-92

ZERO GAS (mV)	TEST GAS (mV)	REFERENCE GAS CONCENTR.	CURVE RESULTS PPM	ZERO GAS (mV)	TEST GAS (mV)	REFERENCE GAS CONCENTR.	CURVE RESULTS PPM
0.00	57.60	250.3 PPM	144.2	0.00	57.60	250.3 PPM	144.2
0.00	57.50	100.0	143.9	0.00	57.60	100.0	144.2
0.00	57.50	100.0	143.9	0.00	58.00 NOX	145.2	145.2
CALCULATED RESULTS				CALCULATED RESULTS			
AVERAGE : 144.0 PPM				AVERAGE : 144.2 PPM			

SECOND ANALYSIS

DATE : 10-19-92

CURVE RESULTS PPM	REFERENCE GAS CONCENTR.	TEST GAS (mV)	CURVE RESULTS PPM	CURVE RESULTS PPM	REFERENCE GAS CONCENTR.	TEST GAS (mV)	CURVE RESULTS PPM
250.3	250.3 PPM	57.60	144.2	250.3	250.3 PPM	57.60	144.2
250.3	100.0	57.60	144.2	250.3	100.0	57.60	144.2
250.3	100.0	58.00 NOX	145.2	250.3	145.2 PPM NOX	58.00 NOX	145.2
CALCULATED RESULTS				CALCULATED RESULTS			
AVERAGE : 144.0 PPM				AVERAGE : 144.2 PPM			

CALIBRATION CURVE 1st DEGREE

SRM # (CRM #)	CONC. PPM	SPLIT PT (%)	DVN (mV)	FITTED VALUE	PERCENT ERROR
1685	250.3	100	100.0	250.3	0.00
1684	95.26	38	38.05	95.24	-0.02
	0.0000	0	0.0000	0.0000	0.00
		0		0.00	0.00
		0		0.00	0.00
		0		0.00	0.00
1684	95.26	LOW	38.05	95.24	-0.02
1685	250.3	HIGH	100.0	250.3	0.00

* GHS - GAS MANUFACTURER'S INTERNAL STANDARD

Analyst :

Approved By :

Don Eickler
Shapiro

DON EICKLER, JR

Revised : 3/31/92 RML

Certificate of Analysis for Standard Gas

Vendor Air Products
Cylinder No. SG 915 16 92
Date of Preparation ~~4-4-96~~ 6-2-95
Label Nitric Oxide
Blend Specification 73.7 ppm, Balance N₂

Results of Analysis of Standard Gas			
Date of Analysis	Run	NO _x	
4-4-96	1	72.4614	
4-4-96	2	72.3393	
4-4-96	3	72.6038	
	4		
	5		
	6		
	Avg	72.4682	1.67%

Analyst BOB

- Results are within 2% of the vendor tag value; use tag value.
- Results are not within 2% of the vendor tag value; conduct another set of triplicate analyses.
- All results within $\pm 2\%$ of the average; relabel as above.
- All results not within $\pm 2\%$ of the average; perform another set of triplicate analyses.

Date: April 4, 1996
Approved by: [Signature]

INTERPOLL LABS

TANK CEWRT
 TANK NUMBER SG9151692
 4/4/96

4/4/96	1:20:00 PM			
0	71.973	0	0	0
4/4/96	1:20:06 PM			
0	74.008	0	0	0
4/4/96	1:20:12 PM			
0	73.601	0	0	0
4/4/96	1:20:18 PM			
0	73.194	0	0	0
4/4/96	1:20:24 PM			
0	72.787	0	0	0
4/4/96	1:20:30 PM			
0	72.38	0	0	0
4/4/96	1:20:36 PM			
0	71.973	0	0	0
4/4/96	1:20:42 PM			
0	72.787	0	0	0
4/4/96	1:20:48 PM			
0	72.38	0	0	0
4/4/96	1:20:54 PM			
0	71.566	0	0	0
4/4/96	1:21:00 PM			
0	72.38	0	0	0
4/4/96	1:21:06 PM			
0	72.38	0	0	0
4/4/96	1:21:12 PM			
0	72.787	0	0	0
4/4/96	1:21:18 PM			
0	73.194	0	0	0
4/4/96	1:21:24 PM			
0	71.16	0	0	0
4/4/96	1:21:30 PM			
0	72.38	0	0	0
4/4/96	1:21:36 PM			
0	72.38	0	0	0
4/4/96	1:21:42 PM			
0	71.973	0	0	0
4/4/96	1:21:48 PM			
0	72.38	0	0	0
4/4/96	1:21:54 PM			
0	71.566	0	0	0

72.46145

INTERPOLLABS

TANK CERT
 TANK NUMBER SG9151692
 4/4/96

4/4/96	1:41:05 PM			
0	72.38	0	0	0
4/4/96	1:41:11 PM			
0	72.787	0	0	0
4/4/96	1:41:17 PM			
0	73.194	0	0	0
4/4/96	1:41:23 PM			
0	72.38	0	0	0
4/4/96	1:41:29 PM			
0	72.787	0	0	0
4/4/96	1:41:35 PM			
0	73.194	0	0	0
4/4/96	1:41:41 PM			
0	71.973	0	0	0
4/4/96	1:41:47 PM			
0	71.973	0	0	0
4/4/96	1:41:53 PM			
0	71.973	0	0	0
4/4/96	1:41:59 PM			
0	73.194	0	0	0
4/4/96	1:42:05 PM			
0	71.973	0	0	0
4/4/96	1:42:11 PM			
0	72.787	0	0	0
4/4/96	1:42:17 PM			
0	71.973	0	0	0
4/4/96	1:42:23 PM			
0	72.787	0	0	0
4/4/96	1:42:29 PM			
0	72.787	0	0	0
4/4/96	1:42:35 PM			
0	73.194	0	0	0
4/4/96	1:42:41 PM			
0	73.601	0	0	0
4/4/96	1:42:47 PM			
0	72.787	0	0	0
4/4/96	1:42:53 PM			
0	71.973	0	0	0
4/4/96	1:42:59 PM			
0	72.38	0	0	0

72.60385

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-174990-01
Batch No: 861-25878

Cylinder No: SG9151692BAL
Cylinder Pressure*: 2000 psig
Certification Date: 06/02/95
Expiration Date: 06/02/97

PO: Rel:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****

Component	Certified Concentration	Cylinder #	Standard Number	Instrument Make/Model	Serial Number	Last Calibration	Measurement
NITRIC OXIDE	73.7 ±0.64 PPM	SG9119927BAL	GMIS	93.7200 PPM Rosemount 951a	0101877	05/18/95	CHEMILUMINESCENCE


Balance Gas: Nitrogen

Contaminant


Nitrogen Dioxide .300 PPM

* Standard should not be used below 150 psig

Analyst:


Richard VanDyke

Approved By:


Robert McNear

ALL PRODUCTS and Chemicals, INC.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of 1

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-411663-01
Batch No: 861-31683

Cylinder No: SG9169061BAL
Cylinder Pressure*: 2000 psig
Certification Date: 04/29/96
Expiration Date: 04/29/98

PO: Rel:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****
Certified Standard Instrument Serial Last Measurement

Component Concentration Cylinder # Number Concentration Make/Model Number Calibration Principal
NITRIC OXIDE 91.9 ±.39 PPM SG9148169BAL GMIS 96.0200 PPM Rosemount 951a 0101877 04/19/96 CHEMILUMINESCENCE


Balance Gas: NITROGEN

Contaminant

Nitrogen Dioxide 1.40 PPM


* Standard should not be used below 150 psig

Analyst:



James Laas

Approved By:



Richard Fry

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

PO: Rel:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****

Component	Concentration	Cylinder #	Standard	Number	Concentration	Make/Model	Instrument	Serial	Last	Measurement
PROPANE	30.4 ±.22	PPM	SG9128572BAL	GMIS	30.4000	PPM	Gow-Mac 750	59405U	05/30/95	GC-FID

Balance Gas: AIR

Oxygen Concentration 20.1 %

* Standard should not be used below 150 psig

Order No:


Batch No: 861-26235


Cylinder No: SG9152374BAL

Cylinder Pressure*: 2000 psig

Certification Date: 06/13/95

Expiration Date: 06/13/98

Analyst: 
James Laas

Approved By: 
Robert McNear

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-41643 CYLINDER #: CC46326 CYL. PRESSURE: 2000PSIG CUSTOMER: TWIN CITY
 EXPIRATION DATE: 7/25/98 LAST ANALYSIS DATE: 7/25/95 P.O.#: SHELIA
 METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION
 STANDARDS-SEPTEMBER 1993-G-1. THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150PSIG).

STANDARD: STANDARD:
 SRM #: 1667B SRM #:
 CYL #: CLM5293 CYL. #:
 CONC.: 47.3PPM CONC.:
 INSTRUMENT: ROSEMOUNT THC INSTRUMENT:
 MODEL #: 400A MODEL #:
 SERIAL #: 20000335 SERIAL #:
 LAST CAL.: 7/14/95 LAST CAL.:

COMPONENT: PROPANE COMPONENT:
 MEAN CONC: 30.5 ± 0.31PPM MEAN CONC:
 REPLICATE CONC. REPLICATE CONC.
 DATE: 7/25/95 DATE:
 30.5PPM
 30.5PPM
 30.6PPM

BALANCE GAS: AIR

COMPONENT: PROPANE		COMPONENT: PROPANE		COMPONENT: PROPANE	
REPLICATE DATA		REPLICATE DATA		REPLICATE DATA	
DATE:	7/25/95	DATE:	7/25/95	DATE:	7/25/95
Z	0	R	47.3	C	30.5
R	47.3	Z	0	C	30.5
Z	0	C	30.6	R	47.3
DATE:		DATE:		DATE:	
Z		R		C	
R		Z		Z	
Z		C		R	

Z=ZERO C=CANDIDATE R=REFERENCE

ANALYST: *Richard Sykes* APPROVED BY: *Anne Hare*

"THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED; HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE."

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS, INC.
373 CANTERBURY ROAD
SHAKOPEE MN 55379

Notes:

Order No: CSS-320133-01
Batch No: 861-29310

Cylinder No: SG9170128BAL
Cylinder Pressure*: 2000 psig
Certification Date: 12/04/95
Expiration Date: 12/04/98

PO: Rel:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****
Certified Standard Instrument Serial Last Measurement

Component Concentration Cylinder # Number Concentration Make/Model
PROPANE 286 ±3.2 PPM SG9128611BAL GMIS 351.5000 PPM Gow-Mac 750 59405U 11/14/95 GC-FID

Balance Gas: AIR
Oxygen Concentration 20.1 %

* Standard should not be used below 150 psig

Analyst:



Richard VanDyke

Approved By:


Richard Fry

APPENDIX I

PROCESS RATE INFORMATION



Louisiana-Pacific Corporation

Northern Division
 Rt. 8, Box 8263
 Hayward, Wisconsin 54843
 (715) 634-3454

LETTER OF TRANSMITTAL

Date: 9/24/96	
TO:	Kathy Eickstadt
RE:	

To Interpoll Laboratories
4500 Ball Road NE
Circle Pines, MN

WE ARE SENDING YOU

- Attached Under separate cover via _____ the following items:
- Shop Drwgs. Prints Plans Samples Specifications
 Copy of Letter Change Order 3.5" disk 11" x 17" sketches

COPIES	REV.	NO.	DESCRIPTION
1			Process Data for Newberry's Compliance

THESE ARE TRANSMITTED as checked below:

- For approval Approved as submitted Submit _____ copies for distribution
 For your use Approved as noted Return _____
 As requested Return for corrections For your information
 For review & comment Resubmit _____ copies for approval Construction Issue
 For bids due _____

REMARKS:

Copy to: _____ File, _____ Signed: Sue Somers / *Sue Somers* / D.P.

NEWBERRY DRYER & PRESS TESTS

<u>CONTENTS</u>	<u>PAGE</u>
GENERAL DESCRIPTION	<u>a</u>
TEST SCHEDULES	1
GENERAL INFORMATION SUMMARY	2-3
DRYER TEST, AUGUST 27, 1996	
NOX,CO,VOC,PM	
PRODUCTION/SUMMARY	4
PRESS CHART	5-6
SHIFT PRODUCTION SUMMARY	7
DRYER CHART	8
DRYER REPORT	9-10
DRYER DATA	11-13
E- TUBE CHART	14
E- TUBE DATA SHEET	15-17
E- TUBE OPERATING REPORT	18
RTO CHART	19
RTO DATA SHEET	20-22
RTO DAILY OPERATING REPORT	23
TRIM PERCENT / PAPER WEIGHTS SHEET	24
BOARD WEIGHTS	25
PRESS TEST, AUGUST 27, 1996	
MDI:HCHO	
PRODUCTION/SUMMARY	26-27
PRESS CHART	28-29
SHIFT PRODUCTION SUMMARY	30
MDI/WAX USAGES	31-32
ZINC BORATE USAGES	33-34
KONUS CHECKLIST	35-36
DRYER TEST, AUGUST 28, 1996	
HCHO,PHENOL,METHANOL	
PRODUCTION/SUMMARY	37
PRESS CHART	38
SHIFT PRODUCTION SUMMARY	39
DRYER CHART	40
DRYER REPORT	41
DRYER DATA	42-43
E- TUBE CHART	44
E- TUBE DATA SHEET	45-46
E- TUBE OPERATING REPORT	47
RTO CHART	48
RTO DATA SHEET	49-50
RTO DAILY OPERATING REPORT	51
BOARD WEIGHTS	52

PRESS TEST, AUGUST 28, 1996

PHENOL,METHANE	
PRODUCTION/SUMMARY	53
PRESS CHART	54
MDI/WAX USAGES	55-56
ZINC BORATE USAGES	57-58
KONUS CHECKLIST	59

PRESS TEST, AUGUST 29, 1996

PM,CO,NOX,VOC	
PRODUCTION/SUMMARY	60
PRESS CHART	61
SHIFT PRODUCTION SUMMARY	62
MDI/WAX USAGES	63
ZINC BORATE USAGES	64
KONUS CHECKLIST	65
BOARD WEIGHTS	66

DYNO FACE PAPER MSDS SHEETS	67-70
DYNO BACKER PAPER MSDS SHEETS	71-74
MDI MSDS SHEETS	75-81
BORDEN WAX MSDS SHEETS	82-86
BOROGARD ZB MSDS SHEETS	87-90

GENERAL DESCRIPTION

NEWBERRY DRYER & PRESS TESTING
AUGUST 27-29, 1996

All testing was conducted using 100% hardwoods with the RTO btu enhancement on. The finished product was 7/16" 4' x 9' panel siding.

NEWBERRY TEST SCHEDULE AUGUST 27-29, 1996

Dryer

	<u>POLLUTANT</u>	<u>RUN #1</u>	<u>RUN #2</u>	<u>RUN #3</u>
8-27	PM,CO,NOX,VOC	1640-1749	1940-2055	2135-2210 2315-2350
8-28	HCHO,PHENOL METHANOL	0930-0955 1040-1133	1215-1332	1500-1618

Press

8-27	MDI	1005-1108	1117-1219	1230-1250 1320-1405
8-27	HCHO	1450-1609	1645-1809	1835-1958
8-28	PHENOL,METHANE	1215-1317	1450-1552	1615-1717
8-29	PM,CO,NOX,VOC	0900-1000	1035-1135	1210-1310

NEWBERRY TESTING AUGUST 27-29, 1996

Process data summary

DRYER AUGUST 27, 1996 - PM,CO,NOX,VOC

- 12.85 =PressProduction rate in Tons per hour
- 29,265 =Production rate of both dryers in pounds per hour
- 2.40 =Total fuel burned in tons per hour
- 47.85% =average incoming moisture percent
- 3.49% =average dry moisture percent
- 1,013 =average inlet temperature
- 1,543 =average RTO burner temperature #1
- 1,543 =average RTO burner temperature #2

PRESS AUGUST 27, 1996 - MDI

- 12.81 =Plant Production rate in Tons per hour
- 875 =MDI resin usage in pounds per hour
- 3.41% =MDI resin usage as % of finished product
- 220 =Wax usage in pounds per hour
- 0.86% =Wax usage as % of finished product
- 395 =Zinc Borate usage in pounds per hour
- 1.54% =Zinc Borate as % of finished product
- 981 =Face paper usage in pounds per hour
- 247 =Backer paper usage in pounds per hour

PRESS AUGUST 27, 1996 - HCHO

- 12.37 =Plant Production rate in Tons per hour
- 897 =MDI resin usage in pounds per hour
- 3.63% =MDI resin usage as % of finished product
- 229 =Wax usage in pounds per hour
- 0.92% =Wax usage as % of finished product
- 378 =Zinc Borate usage in pounds per hour
- 1.53% =Zinc Borate as % of finished product
- 947 =Face paper usage in pounds per hour
- 238 =Backer paper usage in pounds per hour

DRYER AUGUST 28, 1996 - HCHO,PHENOL,METHANOL

- 12.21 =PressProduction rate in Tons per hour
- 28,472 =Production rate of both dryers in pounds per hour
- 2.61 =Total fuel burned in tons per hour
- 48.73% =average incoming moisture percent
- 3.55% =average dry moisture percent
- 1,020 =average inlet temperature
- 1,541 =average RTO burner temperature #1
- 1,537 =average RTO burner temperature #2

PRESS AUGUST 28, 1996 - PHENOL, METHANE

12.26 =Plant Production rate in Tons per hour
957 =MDI resin usage in pounds per hour
3.90% =MDI resin usage as % of finished product
239 =Wax usage in pounds per hour
0.97% =Wax usage as % of finished product
343 =Zinc Borate usage in pounds per hour
1.40% =Zinc Borate as % of finished product
944 =Face paper usage in pounds per hour
237 =Backer paper usage in pounds per hour

PRESS AUGUST 29, 1996 - PM, CO, NOX, VOC

11.99 =Plant Production rate in Tons per hour
902 =MDI resin usage in pounds per hour
3.76% =MDI resin usage as % of finished product
223.00 =Wax usage in pounds per hour
0.93% =Wax usage as % of finished product
335 =Zinc Borate usage in pounds per hour
1.40% =Zinc Borate as % of finished product
936 =Face paper usage in pounds per hour
235 =Backer paper usage in pounds per hour

DRYER AUGUST 27, 1996

PM,CO,NOX,VOC

DATA TIME:	START=	16:40	END=	17:49	HOURS=	1.15
	START=	19:40	END=	20:55	HOURS=	1.25
	START=	21:35	END=	22:10	HOURS=	0.58
	START=	23:15	END=	23:50	HOURS=	<u>0.58</u>
				TOTAL=		3.57

BOARD WEIGHTS - LBS

average weights determined by taking every 25th untrimmed board (from press tapes)

7/16"		119.3 lb= average
lb per/ 4' x 9'	55.49	untrimmed
lb per/ 4' x 18'	110.98	mat weight

lb weight of 74.15
 paper overlay
 (per msf) 6.97% =trim %

PLANT PRODUCTION RATE

- 3.57 =hours during testing
- 59 =pressloads (see press chart)
- 826 =no. of 4'x18' boards produced (pressloads x 14 boards per load)
- 59,472 =volume produced in surface footage (pressloads x 4'x18'x14 openings)
- 69,386 =volume produced 3/8" basis (pressloads x 4'x18'x 14 openings x 1.1667)
- 91,666 =lbs of finished product (boards produced x weight of finished board)
- 25,701 =lbs of finished product per hour (lbs of finished product / hours)
- 12.85 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT

- 4.5 =fuel calibration in pounds per count
- 3,805 =counts during testing hours
- 17,123 = lbs of fuel burned during testing
- 3.57 =hours during testing
- 4,801 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.40 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 40.8 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1,013 =average inlet temperature
- 47.85 =average incoming moisture percent
- 3.49 =average dry moisture percent

Handwritten:
 $\frac{25701}{2000} = 12.8505$
 12.8505

DRYER THROUGHPUT RATE


- 4,801 =Total pounds of fuel burned per hour in Dryer
- 25,701 =lbs of finished product per hour (lbs of finished product / hours)
- 1,236 =lbs of face & backer paper per hour (surf. ftge.prod. per hour x lbs of paper per M/1000)
- 24,464 =lbs of finished product per hour less paper (lbs of finished product / hours- paper)
- 29,265 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 4,801 =weight of screened fines per hour (total fuel)
- 16.40% =resulting loss to fines as percentage of dryer throughput

7

PRESS CHART

8/27/96

0700-1900



TEST TIMES

PRESSLOADS

1640-1749

21

1940-2055

20


2135-2210

9

2315-2350

9

PRESS CHART
NEWBERRY
8/27/96
1900-C





LOUISIANA-PACIFIC CORPORATION
NEWBERRY, MICHIGAN

DATE: 8/27/96

SHIFT	TYPE	# OF PRESS LOADS	A-GRADE	FOOTAGE	SCHED. RUN TIME	DOWNTIME MINUTED	% RUN TIME	% A-GRADE	WOOD USAGE
A.M. TO P.M.	7/16 P.S. 4x18	176		206,976	720	47	93.4	96.7	KONUS #1 #2 10.4 DRYER 1ST 49,176
P.M. TO A.M.	7/16 P.S. 4x18 8PM	160		188,160	720	78	89.1	98.2	KONUS #1 #2 10.6 DRYER 2ND 32,783
TOTAL DAILY				395,136					

PRODUCTION M.T.D. 1,573,656

1ST SHIFT 637,728

2ND SHIFT 935,928

W.T.D.

M.T.D.

Y.T.D.

DAILY PRESS VENT CHECK
TIME CHECKED 9:30 AM

TOTAL 1,573,656

CREW A: 206,976

CREW B: 430,752

CREW C: 188,160

CREW D: 747,268

TOTAL 1,573,656

MAJOR DOWNTIME:


LOG COUNT	DAILY	W.T.D.	M.T.D.
CREW A	5120	5120	5120
CREW B			
CREW C	7280	7280	7280
CREW D			

FOREMAN	% RT
CHRIS VOGEL	93.4
BILL MAGNUSON	
KIRK BOWLER	89.1
BOBBY CRANDELL	

NEWBERRY
SHIFT PRODUCTION
Summary
8/27/96

A-CREW 46 MIN FILLING NET BUN (STACE TESTING - PURPOSES)
C-CREW 69 MIN " " " " " "

DRYER CHART
8/27/96



8

LOUISIANA-PACIFIC CORPORATION
NEWBERRY, MI

DRYER REPORT

OPERATOR: James Depard SHIFT: 7am-7pm CREW: A DATE: 8-27-96

TIME	WET BIN LEVEL	FEED SPEED %	INLET TEMP %F	OUTLET TEMP %F	OUTLET MOIST. %	DRY FUEL USED LB.	SET POINT
7:15	19.0	430	894	276	3.2-3.4	313	256-256
11:22	32.4	410	1090	278	3.4-3.4	3992	259-257
						10,928	
						x 4.5	
			AVE: ---	AVE: ---	AVE: ---	TOT: ---	AVE: ---

49,176

ONCE PER SHIFT:

WET WAFER MOIST. % 52.8
 DRYER FUEL MOIST. % 2.2
 #1 BAGHOUSE MAGNEHELIC 3.0
 MCCONNELL GAS METER 4679

HAMMERMILL MAGNET CLEANED: X
 WOOD FUEL FILTER CLEANED: X
 CROSS TRANSFER GAS METER 5322
 PANEL OVEN GAS METER 3652

TIMES AND REASONS FOR DOWNTIME: _____

OTHER PROBLEMS: _____

DRYER REPORT

OPERATOR: Robert Marsh SHIFT: 7:11 AM CREW: C DATE: 8-27-96

TIME	WET BIN LEVEL	FEED SPEED %	INLET TEMP %F	OUTLET TEMP %F	OUTLET MOIST. %	DRY FUEL USED LB.	SET POINT
7:10	18.4	400	981	282	37-3.4	456	260-261
9:03	27.1	440	995	281	33-3.0	2310	261-261
						7285	
						x 4.5	
						32,783	
					35-3.2		261-261
			AVE: 988	AVE: 282	AVE: _____	TOT: _____	AVE: _____

ONCE PER SHIFT:

WET WAFER MOIST. % 45.8 - 45.2
 DRYER FUEL MOIST. % 2.4
 #1 BAGHOUSE MAGNEHELIC 3.5
 MCCONNELL GAS METER 4481

HAMMERMILL MAGNET CLEANED:
 WOOD FUEL FILTER CLEANED:
 CROSS TRANSFER GAS METER 5333
 PANEL OVEN GAS METER 3679

TIMES AND REASONS FOR DOWNTIME: _____

OTHER PROBLEMS: 7:30 solid test

8/27/96

NEWBERRY DRYER DATA
(FUEL CALIB. LB/COUNT)

DRYER DATA
NEWBERRY

Wood ① 2+3

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
10:05	256	440	878	293	2699	29.3	27.1		3.1
10:15	256	440	919	277	2835	29.7	27.2		3.5
10:25	256	440	958	273	3006	31.2	27.2		3.3
10:35	257	445	979	272	3174	32.2	27.2		3.7
10:45	257	445	1004	275	3341	32.1	27.1		3.6
10:55	257	445	1058	272	3511	31.8	27.2		3.5
11:05	257	430	1021	275	3681	32.7	28.1		3.4
11:15	257	430	1102	270	3850	32.4	28.3		3.9
11:25	257	410	1094	278	4040	32.0	28.0		3.4
11:35	257	410	1014	283	4215	30.5	28.1	51.7	3.3
11:45	257	420	1083	273	4397	31.5	27.7		4.1
11:55	257	420	1157	280	4589	33.0	27.4		3.6
12:05	258	410	1155	276	4775	31.1	28.2		3.7
12:15	258	410	1157	281	4965	29.9	28.2		3.4
12:25	258	410	1080	284	5149	23.3	28.1		3.5
12:35	258	420	1034	283	5336	16.1	27.3		3.4
12:45	258	440	1017	281	5499	8.0	26.6		3.5
12:55	258	440	909	290	5657	5.0	27.9		3.2
1:05	258	360	316	253	5663	17.2	25.5		3.5
1:15	258	360	349	257	5717	17.2	30.5		4.9
1:25	258	390	888	281	5902	32.8	28.9		5.0
1:35	258	410	1070	286	6085	34.3	27.9		3.6
1:45	258	410	1155	276	6279	30.0	26.4		4.0
1:55	258	410	1165	283	6470	25.3	24.9		3.6
2:05	258	405	1120	286	6662	27.1	25.3		3.1
2:15	258	405	1047	278	6859	31.4	24.3		3.6
2:25	258	405	997	282	7047	3.14	24.7		3.5

8/27/96

NEWBERRY DRYER DATA
(FUEL CALIB. LB/COUNT)

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
2:35	258	405	907	285	7207	30.8	24.5	3.4	3.4
2:45	255	405	915	277	7365	30.6	24.5		3.7
2:55	255	405	922	276	7524	32.1	24.4		4.0
3:05	255	406	1025	274	7698	32.0	24.8		3.8
3:15	255	405	1013	276	7870	32.5	24.8	3.8	3.8
3:25	285	400	1196	274	7977	33.3	24.6	51.8	3.1
3:35	285	400	1108	269	7977	30.3	25.7		4.4
3:45	285	400	1210	274	7977	30.5	25.8		4.2
3:55	257	400	1165	289	7995	32.5	25.8		4.0
4:05	257	420	1078	296	8176	34.0	26.0		3.5
4:15	257	430	1092	283	8349	31.2	26.3		3.9
4:25	259	430	1126	281	8520	29.3	25.9		4.0
4:35	259	430	1180	282	8710	32.2	25.10		4.0
4:45	259	430	1130	285	8884	30.9	26.9		3.7
4:55	261	440	1094	283	9058	28.1	27.4		4.2
5:05	261	440	1104	281	9238	29.0	27.9	49.9	3.9
5:15	261	440	1108	280	9405	29.3	28.5		3.9
5:25	262	440	1113	282	9602	30.3	28.6		3.6
5:35	262	440	1127	280	9779	31.5	28.8		3.6
5:45	262	440	1068	283	9944	32.8	28.8		3.7
5:55	262	405	1043	298	10143	28.4	28.9		2.9
6:05	260	405	965	281	10291	22.1	29.3		3.9
6:15	260	405	939	283	10451	21.2	28.6		3.8
6:25	260	440	1002	286	10634	24.4	27.9		3.8
6:35	260	440	1066	279	10802	26.1	27.9		3.6
6:45	260	440	1095	282	10920	49	28.0		3.4
6:55	260	440	927	281	219	26.0	28.0		3.5

GAS


WOOD

8/27/86

NEWBERRY DRYER DATA
(FUEL CALIB. LB/COUNT)

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
7:05	259	430	960	282	430	17.7	24/29		3.8
7:15	269	380	930	290	535	17.8	24/28		3.4
7:25	257	380	863	280	688	21.4	26/26		3.9
7:35	268	420	945	290	840	23.7	26/24		3.6
7:45	267	440	952	288	949	27.4	26/23		3.1
7:55	260	440	975	280	1134	29.6	25/24	45.8	3.5
8:05	265	440	995	281	1382	31.1	24/35		3.2
8:15	266	440	948	286	1503	33.1	26/25		3.2
8:25	263	440	962	282	1669	29.4	21/27		3.2
8:35	257	440	997	276	1819	31.2	23/28		3.5
8:45	265	440	1075	282	2093	28.4	21/24		3.1
8:55	264	440	1016	280	2219	27.2	23/29	45.8	3.2
9:05	261	440	995	280	2332	27.8	28/27		3.4
9:15	261	440	1007	279	2524	30.5	28/27		3.5
9:25	263	440	984	281	2661	29.2	30/24		3.1
9:35	262	440	954	279	2872	30.2	29/26		3.3
9:45	261	440	936	279	2989	26.8	28/26		3.3
9:55	261	440	927	281	3157	18.7	28/29		3.2
10:05	262	440	919	283	3328	12.4	28/30		3.2
10:15	258	360	812	259	3432	12.8	29/31		4.4
10:25	241	360	267	269	3433	22.2	29/31	45.2	3.5
10:35	260	360	237	253	3455	28.0	29/30		3.7
10:45	267	420	844	288	3598	28.9	28/27		3.9
10:55	265	440	1005	285	3826	31.5	28/25		3.3
11:05	263	440	1036	284	3998	32.5	27/26		3.5
11:15	262	440	1001	282	4232	25.2	26/27		3.4
11:25	259	440	1081	279	4364	27.1	26/28		3.4
11:35	261	440	1074	278	4576	29.6	26/28		3.4

E-TUBE CHART
8/27/96



14

every 10 min

8/27/96

NEWBERRY E-TUBE DATA SHEET								
TIME	SOUTH TR SET			NORTH TR SET			outlet QUENCH inlet	
	KV	MA	SPARK RATE	KV	MA	SPARK RATE	INLET	OUTLET
10:00	44	200	29.8	46	130	30.0	135	246
10:10	43	150	29.8	44	180	29.7	138	239
10:20	46	180	29.8	46	200	29.8	140	234
10:30	46	180	29.9	46	160	29.8	140	234
10:40	45	200	30.0	45	180	29.9	235	140
10:50	46	180	29.8	46	220	29.9	235	142
11:00	46	185	29.8	46	135	29.9	236	141
11:10	45	100	29.9	46	100	29.7	234	142
11:20	46	210	29.9	48	130	29.7	236	143
11:30	46	198	29.9	46	125	29.8	240	142
11:40	45	110	29.8	47	110	29.8	236	143
11:50	46	138	29.8	45	122	29.8	235	145
12:00	46	140	29.9	47	130	29.8	235	144
12:10	47	140	29.9	46	145	29.9	235	146
12:20	48	130	29.6	47	138	29.7	242	144
12:30	47	170	29.8	46	120	29.9	240	142
12:40	46	210	29.9	46	145	29.8	240	142
12:50	48	440	29.8	43	350	29.9	228	108
1:05	41	210	29.8	41	145	29.9	233	99
1:15	47	140	29.8	48	168	29.8	236	128
1:25							235	139
1:35	48	48	48	48	48		237	144
1:45	46	170	29.8	47	100	29.8	233	146
1:55	45	180	29.8	47	100	30.1	239	145
2:05	48	230	29.8	45	100	29.6	240	143
2:15	48	220	29.9	47	100	29.9	236	142
2:25	47	120	29.9	47	110	29.8	239	139
2:35	47	190	29.6	46	150	29.6	241	136
2:45	38	40	30.2	46	165	30.0	234	137
2:55	46	205	29.4	47	110	29.6	233	139
3:05	46	195	29.7	46	100	29.8	233	140

119 lbs. tons of

17 press loads

18 press loads

238

27289

12:30 started 43 tons

start

8/27/96

8/27/96

NEWBERRY E-TUBE DATA SHEET								
TIME	SOUTH TR SET #2			NORTH TR SET #2			QUENCH	
	KV	MA	SPARK RATE	KV	MA	SPARK RATE	INLET	OUTLET
3:15	48	160	29.9	46	110	29.9	233	142
3:25	47	270	29.9	46	265	29.9	246	143
3:35	46	300	29.8	46	210	29.8	228	143
3:45	46	340	29.8	45	280	29.8	228	144
3:55	48	140	30.0	48	165	29.9	232	143
4:05	47	250	29.8	47	60	29.8	247	143
4:15	46	280	30.0	18	20	30.1	239	144
4:25	47	245	30.0	47	100	29.6	237	146
4:35	47	162	29.7	47	110	29.8	240	147
4:45	46	220	29.7	47	105	29.9	242	144
4:55	48	150	29.9	46	180	29.9	239	145
5:05	46	73	29.9	43	70	29.8	239	144
5:15	48	108	29.8	51	82	29.9	238	144
5:25	52	91	29.8	44	44	29.9	239	146
5:35	54	117	30.0	50	123	29.8	238	144
5:45	43	58	29.8	52	88	29.9	241	144
5:55	50	70	29.9	53	97	29.9	248	136
6:05	55	141	29.7	53	108	29.8	241	140
6:15	50	82	29.9	49	70	29.8	239	141
6:25	53	114	29.9	46	47	29.9	241	143
6:35	55	138	29.9	50	67	29.9	238	144
6:45	51	100	29.8	50	76	29.8	243	141
6:55	51	161	29.8	51	135	29.9	240	139
7:05	48	105	29.9	56	126	29.8	238	142
7:15	53	176	29.8	50	138	29.9	246	138
7:25	51	132	29.9	51	155	29.9	240	136
7:35	54	114	29.9	54	144	29.9	245	139
7:45	53	102	29.9	56	137	29.9	244	142
7:55	53	100	29.8	54	144	29.9	239	142
8:05	53	91	29.9	54	132	29.8	240	141
8:15	55	114	29.9	54	123	29.9	242	141

16

E-TUBE OPERATING REPORT

Days	Nights	Operator	Crew	Date
		DART	A	8-27-96
		WALKER	C	

Time	TR CONTROL PANEL DIGITAL TRANSFORMER/RECTIFIERS				Meat Pad A P	ZYCOM			Beginning & End of Shift on the Vessel			
	No. 1	No. 2	KV	mA		INLET deg. F	OUTLET deg. F	In IPO	In IPO	Flush Water total gal.	Make-up Water total gal.	Vessel PSI
7:00 AM	40	193	47	334	.4	236	138	11	21	112793	535684	
8:00 AM	41	223	40	222	.4	239	135	11	25	1136274	541077	
9:00 AM	40	129	43	155	.4	241	142	11	25			
10:00 AM	40	163	44	110	.4	245	136	11	26			
11:00 AM	44	168	45	103	.4	235	143	11	25			
12:00 PM	45	111	47	121	.4	238	145	11	25			
1:00 PM	44	95	48	125	DOWN							
2:00 PM	45	95	46	104	.4	240	144	10	25			
3:00 PM	47	149	47	129	.4	242	144	11	25			
4:00 PM	41	86	45	57	.4	238	145	11	26			
5:00 PM	45	104	46	146	.4	248	140	11	27			
6:00 PM	45	135	43	111	.4	243	139	10	26			
7:00 PM	47	169	45	82	.4	237	143	10	26			
8:00 PM	46	155	45	120	.4	238	140	11	27			
9:00 PM	46	165	45	192	.4	243	141	11	26			
10:00 PM	47	181	44	142	.4	245	144	10	25			
11:00 PM	43	186	45	181	.4	259	142	11	25			
12:00 AM	46	160	44	163	DOWN				26			
1:00 AM	47	130	45	131	.4	240	138	11	27			
2:00 AM	44	107	45	173	.4	233	138	11	27			
3:00 AM	47	127	44	173	.4	234	137	10	26			
4:00 AM												
5:00 AM												
6:00 AM												
Total Hours	Dryer Operating on Natural Gas								Total:	1136274	541077	

Recycle Water Solids %

Time

6.6

7.5%

7.34%

Spark Rate Transformer/Rectifier

NO. 1

NO. 2

* Change Chart : 7:00 a.m.


- Check caustic level
 - Check Defoamer level
 - Clean recycle line strainer
 - Solids Test
 - Record time started new tote
- Day
- Night

RECYCLER BLOWDOWN

Estimated Gallons

Gallons Used	Caustic	Defoamer
Start:	985	1079
End:	3000	1128
Total:	3	49

RTO CHART
8/27/96



19

NEWBERRY DRYER RTO

every 10 minutes

8/27/96

TIME 5 MINUTES	CHAMBER TEMPS.					INLET TEMP.	BURNERS		COMB. TEMP.	EXHAUST TEMP.	PRESS. DROP.	GAS USAGE	OPACITY
	#1	#2	#3	#4	#5		#1	#2					
8:30	492												
8:40													
8:50													
9:00													
9:10													
9:20													
9:30	496	471	448	466	480	131	1521	1517	1531	270	22.5		
9:40													
9:50													
10:00	481	476	440	460	473	148	1516	1509	1513	267	21.4	42139	0
10:10	487	470	444	454	480	151	1517	1528	1527	271	20.1		1
10:20	493	470	446	459	477	153	1522	1522	1532	272	18.9		1
10:30	491	471	449	456	482	153	1514	1523	1529	276	21.5		0
10:40	492	477	446	466	473	154	1524	1516	1523	277	21.0		1
10:50	491	476	451	457	483	157	1513	1527	1521	278	19.5		0
11:00	497	473	451	466	474	156	1526	1518	1524	278	21.5		0
11:10	495	478	452	459	483	156	1510	1524	1517	280	21.2		0
11:20	496	479	451	468	476	157	1522	1515	1522	278	19.9		0
11:30	497	479	452	468	476	157	1522	1517	1524	279	19.3		0
11:40	501	473	454	461	482	158	1522	1523	1530	280	20.9		0
11:50	496	483	453	467	480	159	1524	1513	1518	280	19.9		0
12:00	501	477	458	462	487	160	1519	1547	1533	283	21.5		0
12:10	503	482	457	475	480	159	1526	1516	1523	284	20.5		0
12:20	504	486	459	477	484	158	1531	1516	1528	286	21.1		0
12:30	508	482	464	473	484	158	1528	1530	1531	284	21.2		0
12:40	508	483	464	475	487	157	1533	1518	1529	284	20.5		0
12:50	501	491	465	470	496	152	1507	1506	1507	288	22.0		0
1:00	498	490	463	464	491	180	1506	1513	1506	283	26		0
1:10	501	476	462	468	478	158	1531	1530	1533	283	21		0
1:20													
1:30													
1:40	496	483	463	462	489	159	1505	1527	1512	284	20.5		0
1:50	502	478	464	468	482	159	1532	1527	1530	283	20.3		0

NEWBERRY DRYER RTO

8/27/90

TIME 5 MINUTES	CHAMBER TEMPS.					INLET TEMP.	BURNERS		COMB. TEMP.	EXHAUST TEMP.	PRESS. DROP	GAS USAGE	OPACITY
	#1	#2	#3	#4	#5		#1	#2					
2:05	498	487	461	473	482	158	1522	1505	1518	285	20.5	0	
2:15	501	481	465	466	489	157	1514	1535	1533	288	22.0	0	
2:25	499	488	461	474	483	156	1518	1504	1515	286	20.4	0	
2:35	497	488	460	473	482	147	1522	1509	1510	282	22.0	1	
2:45	500	479	463	465	486	148	1518	1529	1532	282	21	0	
2:55	495	486	460	468	484	158	1508	1512	1506	285	21.5	0	
3:05	494	487	459	467	484	154	1507	1509	1507	286	21.0	0	
3:15	499	480	463	463	482	156	1527	1532	1531	285	21.5	0	
3:25	498	481	463	462	488	158	1510	1529	1531	284	20.4	0	
3:35	503	479	464	466	484	157	1528	1531	1537	287	22.3	0	
3:45	502	481	463	469	481	160	1539	1531	1544	287	20.5	0	
3:55	499	483	464	462	489	157	1563	1544	1546	286	20.5	0	
4:05	503	482	461	470	480	160	1549	1540	1551	285	20.0	0	
4:15	496	488	459	466	484	161	1552	1556	1558	287	18.8	0	
4:25	502	478	460	464	480	163	1561	1552	1562	285	20.5	0	
4:35	498	484	457	469	477	163	1552	1548	1552	285	18.9	0	
4:45	498	485	457	470	478	162	1549	1543	1544	284	19.5	0	
4:55	501	479	461	463	485	162	1552	1554	1563	286	19.0	0	
5:05	500	485	458	471	479	162	1551	1546	1549	285	19.5	0	
5:15	502	481	463	469	482	162	1550	1555	1562	286	19.5	0	
5:25	505	480	463	467	486	162	1555	1549	1557	284	19.3	0	
5:35	499	487	462	468	490	162	1544	1554	1553	287	20.5	0	
5:45	506	481	463	474	484	161	1555	1549	1553	285	19.5	0	
5:55	503	485	466	468	494	167	1541	1548	1554	285	20.5	0	
6:05	500	490	463	472	492	159	1538	1548	1541	285	19.8	0	
6:15	507	483	465	472	491	159	1552	1544	1552	283	20.2	0	
6:25	508	483	466	472	491	160	1553	1542	1550	284	21	0	
6:35	508	486	467	472	492	161	1552	1547	1554	282	19.9	0	
6:45	508	486	465	480	487	161	1544	1541	1544	283	18.5	0	
6:55	508	487	465	480	487	158	1555	1549	1547	281	18.5	0	
7:05	510	486	465	480	487	159	1552	1546	1548	280	18.5	0	
7:15	510	487	465	480	488	157	1548	1542	1546	280	18.5	0	
7:25	511	485	465	479	488	156	1552	1547	1558	280	18.6	0	

NEWBERRY DRYER RTO

8/27/96

DRYER RTO DATA

TIME 5 MINUTES	CHAMBER TEMPS.					INLET TEMP.	BURNERS		COMB. TEMP.	EXHAUST TEMP.	PRESS. DROP	GAS USAGE	OPACITY
	#1	#2	#3	#4	#5		#1	#2					
7:35	506	487	467	471	497	156	1548	1552	1554	279	19.5	42575	0
7:45	504	490	465	473	495	154	1536	1544	1544	282	18.5	42575	0
7:55	508	490	463	480	490	160	1546	1541	1546	280	18.0		0
8:05	512	484	466	476	492	161	1552	1547	1554	279	18.5	42587	0
8:15	511	487	464	480	488	159	1551	1546	1546	279	17.0		0
8:25	511	484	466	474	494	160	1549	1545	1552	280	18.0	42603	0
8:35	506	494	463	478	493	160	1542	1540	1541	283	19.0		0
8:45	512	485	465	477	493	163	1540	1543	1544	280	17.0	42617	0
8:55	505	494	464	476	497	161	1531	1535	1532	285	19.5		0
9:05	506	491	466	472	500	161	1534	1546	1545	283	18.0	42631	0
9:15	513	486	467	474	496	161	1545	1541	1546	280	17.5		0
9:26	510	490	464	481	492	161	1542	1535	1526	280	18.0		0
9:36	510	487	468	471	500	158	1539	1543	1547	281	19.5	42650	0
9:46	509	492	464	480	492	159	1541	1536	1539	281	19.0	42665	0
9:55	509	489	466	492	500	157	1532	1542	1542	280	17.0	42665	0
10:06	508	488	467	472	500	158	1531	1541	1544	280	18.5		0
10:15	512	488	463	481	490	137	1539	1534	1535	280	20.5	42679	1
10:25	511	481	464	473	492	125	1547	1542	1543	270	21.0		1
10:35	502	480	460	464	493	122	1544	1540	1540	265	21.0	42692	1
10:45	501	476	465	481	488	157	1540	1534	1539	271	19.0		1
10:55	494	474	458	464	493	157	1528	1535	1536	276	20.0	42705	1
11:05	503	477	460	467	490	160	1545	1542	1545	282	17.5		0
11:15	499	487	458	474	490	160	1537	1530	1530	275	16.5	42718	0
11:25	505	480	462	470	493	162	1546	1542	1546	275	18.0	42731	0
11:35	501	486	463	468	499	161	1531	1539	1538	280	17.5	42731	0
11:45	503	484	464	468	500	163	1542	1547	1548	278	17.0	42736	0
11:55													

A-Days C-Nights

Date: 8-27-76

Time	6:00 AM	10:00 AM	12:00 PM	2:00 PM	4:00 PM	6:00 PM	8:00 PM	10:00 PM	12:00 AM	2:00 AM	4:00 AM	6:00 AM
Burner S.P.	1520	1520	1520	1520	1520	1540						
Brn #1 temp	1537	1510	1527	1533	1520	1539						
Brn #1 out	24.0	24.2	17.1	35.1	35.1	8.1						
Brn #2 temp	1528	1511	1514	1529	1547	1547						
Brn #2 out	19.5	19.6	11.4	32.3	32.3	.2						
Inlet temp	150	149	158	158	162	157						
Chamber temp	1543	1521	1530	1541	1558	1543						
Exhaust temp	270	271	280	285	284	286						
RTO Diff Press	20w/c	23w/c	21w/c	23w/c	21w/c	22						
VFD Amps	477	525	507	530	500	495						
VFD RPM	1270	1350	1337	1380	1327	1331						
PN setpoint	1.2	1.3	1.0	1.0	1.1	1.1						
PN out	61.8	64.7	66.6	69.9	64.6	67.3						
Chr #1 B.O. temp	491	487	502	500	500	502						
Chr #2 B.O. temp	471	473	475	482	483	491						
Chr #3 B.O. temp	457	490	457	465	453	463						
Chr #4 B.O. temp	460	464	462	465	470	475						
Chr #5 B.O. temp	489	471	483	490	477	489						
Fan brg #1 temp	82	87	96	105	105	104						
Fan brg #2 temp	73	82	88	101	100	76						
Motor brg #1 temp	84	73	101	113	112	108						
Motor brg #2 temp	79	83	91	102	102	98						
Dryer to RTO	yes	yes	yes	yes	yes	yes						
Panel Line to RTO												
Lap Line to RTO												
Chamber Prg Fan	ON	ON	ON	ON	ON	ON						
BTUE Pressure	16	16	16	D	2	21						
BTUE Flow DP	42049	42138	42221	42328	42447	42500						

Comments:

Roll Gas Usage:

Interdepartmental Communication

date: 9/13/96

to: Joel Anderson

location:

Hayward

from: Stephanie Browne

location:

Newberry

subject: Paper Weights and Trim Percentage

The paper weight of backer paper per 1000 sq. ft. is 14.9. The paper weight of the top surface face paper per 1000 sq. ft. is 59.25. These numbers were given to me by Quality Control. During compliance testing from 8/27/96 to 8/29/96, Quality Control compared mat and finished product weights which resulted in a 6.97% weight reduction due to trimming. If you have any questions, please contact me.

Sincerely,

Stephanie Browne

Stephanie Browne
Asst. Env. Manager

08/27/96

NEWBERRY BOARD WEIGHTS
(lbs./4x18 panel every 25th mat)
APPROXIMATE TIMES

PRESS MDI

1005-1108

120
120
119
118
118
120
117
118

1117-1219

120
123
120
119

1230-1250

121
120

1320-1405

118
120
123
121
119
123

AVE

119.82

PRESS HCHO

1450-1609

1645-1809

1835-1958

AVE

114
116
118
118
119
117
117
119
117
117
116
117
115
116
119
118
120
120
123
124
123
122
119
122
125
124
126
126
124
121
121
120
121
119
120
120

119.81

DRYER PM

1640-1749

1940-2055

2135-2210

2315-2350

AVE

116
117
118
120
121
118
120
118
122
121
118
116
119
116
117
119
115
119
117
123
122
119
119
120
122
122
124
121
122

119.29

PRESS AUGUST 27, 1996

MDI

DATA TIME:	START=	10:05	END=	11:08	HOURS=	1.05
	START=	11:17	END=	12:19	HOURS=	1.03
	START=	12:30	END=	12:50	HOURS=	0.33
	START=	13:20	END=	14:05	HOURS=	<u>0.75</u>
					TOTAL=	3.17

BOARD WEIGHTS - LBS

average weights determined by taking every 25th untrimmed board (from press tapes)

7/16"		119.8 lb= average
lb per/ 4' x 9'	55.73	untrimmed
lb per/ 4' x 18'	111.47	mat weight

lb weight of paper overlay (per msf) 74.15 6.97% =trim %

PLANT PRODUCTION RATE

- 3.17 =hours during testing
- 52 =pressloads (see press chart)
- 728 =no. of 4'x18' boards produced (pressloads x 14 boards per load)
- 52,416 =volume produced in surface footage (pressloads x 4'x18'x14 openings)
- 61,154 =volume produced 3/8" basis (pressloads x 4'x18'x 14 openings x 1.1667)
- 81,148 =lbs of finished product (boards produced x weight of finished board)
- 25,626 =lbs of finished product per hour (lbs of finished product / hours)
- 12.81 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

RESIN USAGE TAKEN FROM TOTALIZERS

<u>TIME</u>	<u>MDI</u>	<u>WAX</u>	<u>ZINC BOR.</u>
10:05-11:08	948	234	390
11:17-12:19	953	242	437
12:30-12:50	236	59	137
13:20-14:05	634	162	288
ave. lbs/hr.	875	220	395
100% solids			

25,626 =average lbs. per hour finished product produced during testing
 875 =average lbs. per hour of MDI resin used during testing
 3.41% = MDI resin used as % of finished product

220 =average lbs. per hour of wax (100% solids) used during testing
 0.86% =wax used as % of finished product

395 =Zinc Borate usage in pounds per hour
 1.54% =Zinc Borate as % of finished product

PRESS AUGUST 27, 1996

HCHO

DATA TIME:	START=	14:50	END=	16:09	HOURS=	1.32
	START=	16:45	END=	18:09	HOURS=	1.40
	START=	18:35	END=	19:58	HOURS=	<u>1.38</u>
				TOTAL=		4.10

BOARD WEIGHTS - LBS

average weights determined by taking every 25th untrimmed board (from press tapes)

7/16"		119.8 lb= average
lb per/ 4' x 9'	55.73	untrimmed
lb per/ 4' x 18'	111.46	mat weight

lb weight of 74.15
paper overlay
(per msf) 6.97% =trim %

PLANT PRODUCTION RATE

- 4.10 =hours during testing
- 65 =pressloads (see press chart)
- 910 =no. of 4'x18' boards produced (pressloads x 14 boards per load)
- 65,520 =volume produced in surface footage (pressloads x 4'x18'x14 openings)
- 76,442 =volume produced 3/8" basis (pressloads x 4'x18'x 14 openings x 1.1667)
- 101,424 =lbs of finished product (boards produced x weight of finished board)
- 24,738 =lbs of finished product per hour (lbs of finished product / hours)
- 12.37 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

RESIN USAGE TAKEN FROM TOTALIZERS

TIME	MDI	WAX	ZINC BOR.
14:50-16:09	1,173	300	503
16:45-18:09	1,230	313	513
18:35-19:58	1,275	324	532
ave. lbs/hr.	897	229	378
100% solids			

24,738 =average lbs. per hour finished product produced during testing
897 =average lbs. per hour of MDI resin used during testing
3.63% = MDI resin used as % of finished product

229 =average lbs. per hour of wax (100% solids) used during testing
0.92% =wax used as % of finished product


378 =Zinc Borate usage in pounds per hour
1.53% =Zinc Borate as % of finished product

PRESS CHART

8/27/96

0700 - 1900

1300



MAI

TEST TIMES

PRESSROADS


1005 - 1108	18
1117 - 1219	18
1230 - 1250	5
1320 - 1405	11

28

PRESS CHART

8/27/96

1900-0700



HCHO

TEST TIMES PRESS LOAD

1450-1609	21
1645-1809	21
1835-1958	23



LOUISIANA-PACIFIC CORPORATION
NEWBERRY, MICHIGAN

DATE: 8/27/96

SHIFT	TYPE	# OF PRESS LOADS	A-GRADE	FOOTAGE	SCHED. RUN TIME	DOWNTIME MINUTES	% RUN TIME	% A-GRADE	WOOD USAGE
A.M. TO P.M. A CREW	7/16 P.S. 4x18	176		206,976	720	47	93.4	96.7	KONUS #1 _____ #2 <u>10.4</u> DRIVER 1ST <u>49,176</u>
P.M. TO A.M. A CREW	7/16 P.S. 4x18 EAB	160		188,160	720	78	89.1	98.2	KONUS #1 _____ #2 <u>10.6</u> DRIVER 2ND <u>32,783</u>
TOTAL DAILY				395,136					

PRODUCTION M.T.D. _____

DAILY PRESS VENT CHECK
TIME CHECKED 9:30 AM

1ST SHIFT 637,728

2ND SHIFT 935,928

TOTAL 1,573,656

CREW A: 206,976

CREW B: 430,752

CREW C: 188,160

CREW D: 747,268

TOTAL 1,573,656

LOG COUNT	DAIRY	W.T.D.	M.T.D.
CREW A	5120	5120	5120
CREW B			
CREW C	7280	7280	7280
CREW D			

FOREMAN	% RT
CHRIS VOGEL	93.4
BILL MAGNUSON	
KIRK BOWLER	89.1
BOBBY CRANDELL	

MAJOR DOWNTIME:

A-CREW 46 MIN FILLING NET BIN (STACE TESTING - PURPOSES)
C-CREW 69 MIN " " " " " "

30

NEWBERRY
SHIFT PRODUCTION
SUMMARY
8/27/96



Louisiana-Pacific Corporation

Newberry OSB Plant

Date 8-27-96

TIME	PRESS TEMP.	MDI USAGE SURFACE	MDI USAGE CORE	WAX USAGE SURFACE	WAX USAGE CORE
10:05	403	1331	1157	5783	494
10:15		1420	1240	615	529
10:25		1490	1299	645	553
10:35		1578	1379	683	587
10:45		1662	1453	720	617
10:55		1749	1529	757	650
11:05	405	1835	1601	793	680
11:15		1920	1673	830	711
11:25		2001	1745	865	743
11:35		2086	1817	904	774
11:45		2177	1898	945	810
11:55		2261	1972	981	841
12:05	407	2343	2045	1018	872
12:15		2428	2118	1056	903
12:25		2515	2192	1096	935
12:35		2607	2268	1138	968
12:45		2688	2337	1174	998
12:55		2734	2377	1193	1015
1:05	409	2734	2377	1193	1015
1:15		2742	2385	1197	1019
1:25		2821	2449	1232	1047
1:35		2907	2523	1270	1079
1:45		2993	2598	1308	1112
1:55		3078	2669	1347	1143
2:05	406	3162	2742	1383	1175
2:15		3257	2823	1423	1210
2:25		3335	2903	1456	1244
2:35		3426	2976	1497	1275
2:45		3542	3050	1536	1307
2:55		3605	3126	1574	1339
3:05	408	3684	3195	1608	1367
3:15		3764	3265	1641	1397
3:25		3861	3346	1684	1432
3:35		3923	3397	1710	1453
3:45		4002	3461	1745	1481



Louisiana-Pacific Corporation

Newberry OSB Plant

Date 8/27/96

TIME	PRESS TEMP.	MDI USAGE SURFACE	MDI USAGE CORE	WAX USAGE SURFACE	WAX USAGE CORE
3:55	477	4086	3531	1782	1312
4:05		4166	3599	1818	1542
4:15		4257	3672	1857	1574
4:25		4337	3752	1893	1609
4:35		4421	3825	1929	1637
4:45		4497	3897	1962	1669
4:55	410	4582	3969	2000	1699
5:05		4666	4041	2039	1730
5:15		4752	4111	2076	1759
5:25		4836	4178	2115	1788
5:35		4915	4242	2150	1815
5:45		4994	4305	2183	1843
5:55	410	5090	4384	2227	1878
6:05		5171	4453	2263	1908
6:15		5257	4528	2302	1941
6:25		5355	4615	2345	1978
6:35		5427	4678	2378	2005
6:45		5510	4747	2414	2035
6:55		3888	3488	1888	1488
7:05		148	127	67	53
7:15		203	175	92	73
7:25		298	262	134	111
7:35		371	334	171	140
7:45		449	392	200	167
7:55		540	478	244	201
8:05					
8:15					
8:25					
8:35					
8:45					
8:55					
9:05					

ZERO OUT
 5464 / 4796 / 2440

END PRESS H410
 758



Louisiana-Pacific Corporation

Newberry OSB Plant

Date 8-27-96

	TIME	SCALE READING SURFACE	SCALE READING CORE	SCALE READING ZINC BORATE
Start 10:05 PL	10:00	24725.6	19685.3	2640
	10:10	24726.7	19686.2	2578
	10:20	24727.8	19687.2	2505
	10:30	24728.7	19688.0	2444
	10:40	24729.9	19689.0	2375
FINISH 11:06 P1	10:50	24730.9	19689.9	2311
Start 11:05 START	11:00	24731.8	19690.7	2250
	11:10	24732.8	19691.5	2188
	11:20	—	—	—
	11:30	24734.9	19693.4	2055
	11:40	24736.0	19694.3	1974
	11:50	24737.0	19695.2	1904
FINISH P 19 P2	12:00	24738.1	19696.2	1838
	12:10	24739.2	19697.1	1763
	12:20	24740.4	19698.1	1695
Start P3 12:30 START 12:50 S1	12:30	24741.4	19698.9	1623
	12:40	24742.6	19699.9	1545
	12:50	24743.5	19700.7	1496
	1:00	24743.5	19700.7	1475
stop 12:50 P3	1:10	24743.5	19700.7	1475
	1:20	—	—	—
Start P3 1:20	1:30	—	—	—
	1:40	24746.3	19703.0	1304
Finish P3 2:05	1:50	24747.2	19703.8	1246
	2:00	24748.3	19704.8	1176
	2:10	24749.4	19705.7	1102
Start 2:15 stack 1	2:20	24750.4	19706.7	1031
	2:30	24751.4	19707.6	968
	2:40	24752.6	19708.5	893
Start 14:50 P4	2:50	24753.5	19709.4	802
	3:00	24754.6	19710.4	754
Finish S1 14:00	3:10	24755.6	19711.2	691
	3:20	24757.0	19712.4	667
	3:30	24757.6	19712.9	573
	3:40	24758.8	19713.8	507

} Down



Louisiana-Pacific Corporation

Newberry OSB Plant

Date

8-27-96

start p4
14:53
HCON

START
Dryer 2
4:40

Finish p4
16:16

Start
16:45 PS

Finish
Dryer 2
5:50

Finish
18:09 PS

Start
Start
18:35
18:35

Start
Dryer 3
7:40

FINISH
19:59 p6

End
Dryer 3
8:55

Start
Dryer 4
9:35
hold
19:10
Restart

TIME	SCALE READING SURFACE	SCALE READING CORE	SCALE READING ZINC BORATE
3:50	24759.9	19714.8	423
4:00	—	—	—
4:10	24761.5	19716.1	319
4:20	24762.8	19717.2	309
4:30	24763.8	19718.2	2725
4:40	24764.9	19719.2	2610
4:50	24765.7	19719.9	2576
5:00	24767.0	19720.9	2498
5:10	24767.9	19721.6	2448
5:20	—	—	—
5:30	24769.9	19723.3	2338
5:40	24771.0	19724.2	2283
5:50	24772.1	19725.0	2223
6:00	24773.0	19725.8	2168
6:10	24774.4	19727.0	2097
6:20	24775.4	19727.8	2042
6:30	24776.2	19728.6	2004
6:40	—	—	—
6:50	24778.6	19730.6	1869
7:00	24779.4	19731.2	1928
7:10	24780.6	19732.3	1761
7:20	24781.8	19733.0	1683
7:30	24782.7	19734.1	1646
7:40	24783.7	19734.9	1588
7:50	24784.4	19735.9	1526
8:00	24785.8	19736.8	1473
8:10			
8:20			
8:30			
8:40			
8:50			
9:00			
9:10			
9:15			
9:20			

stack #2
BTUE on
COMB CHAMB
TEMP
↑ to 1550°

END OF TEST



Louisiana-Pacific Corporation

Northern Division

KONUS CHECKLIST

OPERATOR D Edgak

SHIFT DAYS

CREW A

DATE 8-27-96

THERMAL OIL LEVEL - FT. 2'

FUEL OIL INCHES #1 <u>Full</u> #2 <u>Full</u>		
MILLTRONICS		
CLARK BINS (QUARTERS)	BARK BIN	
EMERGENCY DIESEL	CHECKED	FILLED
FUEL LEVEL	<input checked="" type="checkbox"/>	
EMERGENCY DIESEL	CHECKED	FILLED
OIL LEVEL	<input checked="" type="checkbox"/>	
EMERGENCY COOLING TANK	CHECKED	FILLED
EMERGENCY DIESEL	YES	NO
RUN EACH SHIFT	<input checked="" type="checkbox"/>	
T.O. PUMP PRESSURE	SUCTION	DISCHARGE
	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
PRIMARY PUMP I	<u>OK</u>	
PRIMARY PUMP II	<u>OFF OK</u>	
PRIMARY PUMP III	<u>OFF</u>	
ECONOMIZER PUMP I	<u>OK</u>	
ECONOMIZER PUMP II	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

LEVEL E-TUBE BLOW DOWN TANK

7:00 34" 1:00 48"

POND SET POINT OFF

POND TEMP #1 #2

	SET POINT	RETURN	OUTLET
KONUS I	<u>OFF</u>		
KONUS II	<u>500</u>	<u>490</u>	<u>510</u>
SPACE HEAT	<u>OFF</u>		
ECONOMIZER	<u>500</u>		
FLUE GAS	#1 <u> </u>	#2 <u>700</u>	
BLEND AIR	#1 <u> </u>	#2 <u>334</u>	
KONUS ROOM BLOWN DOWN		YES	NO
KONUS ROOM SWEEP		<input checked="" type="checkbox"/>	NO

KONUS BAGHOUSE (TWICE A SHIFT)

SAWTRIM BAGHOUSES (TWICE A SHIFT)

KONUS FUEL	I	II
WOOD HRS.	<input checked="" type="checkbox"/>	<u>12</u>
OIL HRS.	<input checked="" type="checkbox"/>	<u>0</u>
WOOD FUEL IN TONS	<input checked="" type="checkbox"/>	<u>10.4</u>

COUNTER	SCALE	
BEGINNING	<u>87235</u>	<u>8856320</u>
END	<u>8733.9</u>	<u>8807616</u>
TOTAL		



Louisiana-Pacific Corporation

Northern Division

KONUS CHECKLIST

OPERATOR J. SeatonSHIFT DITESCREW CDATE 8-27-96THERMAL OIL LEVEL - FT. 1.57:15 pm

LEVEL E-TUBE BLOW DOWN TANK

7:00 41" 1:00 41"POND-SET POINT POND TEMP #1 #2

FUEL OIL INCHES #1	<u>46"</u>	#2	<u>46 1/2"</u>
MILLTRONICS			
CLARK BINS (QUARTERS)	BARK BIN		
EMERGENCY DIESEL	<u>CHECKED</u>	FILLED	
FUEL LEVEL	<u>3/4</u>		
EMERGENCY DIESEL	<u>CHECKED</u>	FILLED	
OIL LEVEL			
EMERGENCY COOLING TANK	<u>CHECKED</u>	FILLED	
EMERGENCY DIESEL RUN EACH SHIFT	<u>YES</u>	NO	
T.O. PUMP PRESSURE	SUCTION	DISCHARGE	

PRIMARY PUMP I 8 120PRIMARY PUMP II 2 132PRIMARY PUMP III offECONOMIZER PUMP I 27 64ECONOMIZER PUMP II off

	SET POINT	RETURN	OUTLET
KONUS I	<u>off</u>		
KONUS II	<u>520</u>	<u>493</u>	<u>520</u>
SPACE HEAT	<u>off</u>		
ECONOMIZER	<u>550</u>		
FLUE GAS	#1 <u> </u>	#2 <u>715</u>	
BLEND AIR	#1 <u> </u>	#2 <u>345</u>	
KONUS ROOM BLOWN DOWN	YES	NO	
KONUS ROOM SWEPT	YES	NO	

KONUS FUEL	I	II
WOOD HRS.	<u>X</u>	<u>12</u>
OIL HRS.	<u>X</u>	<u>0</u>
WOOD FUEL IN TONS	<u>X</u>	<u>10.4</u>

KONUS BAGHOUSE (TWICE A SHIFT) SAWTRIM BAGHOUSES (TWICE A SHIFT)

COUNTER	SCALE	
BEGINNING	<u>8733.9</u>	<u>8857616</u>
END	<u>8744.5</u>	<u>8858963</u>
TOTAL	<u>10.6</u>	

DRYER AUGUST 28, 1996

HCHO, PHENOL, METHANOL

DATA TIME:	START=	09:30	END=	09:55	HOURS=	0.42
	START=	10:40	END=	11:33	HOURS=	0.88
	START=	12:15	END=	13:32	HOURS=	1.28
	START=	15:00	END=	16:18	HOURS=	<u>1.30</u>
					TOTAL=	3.88

BOARD WEIGHTS - LBS

average weights determined by taking every 25th untrimmed board (from press tapes)

7/16"		119.4 lb= average untrimmed mat weight
lb per/ 4' x 9'	55.54	
lb per/ 4' x 18'	111.09	

lb weight of paper overlay (per msf) 74.15 6.97% =trim %

PLANT PRODUCTION RATE

- 3.88 =hours during testing
- 61 =pressloads (see press chart)
- 854 =no. of 4'x18' boards produced (pressloads x 14 boards per load)
- 61,488 =volume produced in surface footage (pressloads x 4'x18'x14 openings)
- 71,738 =volume produced 3/8" basis (pressloads x 4'x18'x 14 openings x 1.1667)
- 94,870 =lbs of finished product (boards produced x weight of finished board)
- 24,430 =lbs of finished product per hour (lbs of finished product / hours)
- 12.21 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

FUEL BURNING RATE ESTIMATED BY DRY FUEL INPUT


- 4.5 =fuel calibration in pounds per count
- 4,501 =counts during testing hours
- 20,255 = lbs of fuel burned during testing
- 3.88 =hours during testing
- 5,216 =lbs of dry fuel burned per hour during testing (pounds of dry fuel / testing hours)
- 2.61 =tons of dry fuel burned per hour during testing (pounds of dry fuel / 2000 lbs)
- 8,500 =estimated BTU content per pound of dry fuel,
- 44.3 =estimated mmbtu input per hour (lbs of dry fuel per hour x btu content)
- 1,020 =average inlet temperature
- 48.73 =average incoming moisture percent
- 3.55 =average dry moisture percent

Handwritten:
 $\frac{24,430}{2000} = 12.215$

DRYER THROUGHPUT RATE

- 5,216 =Total pounds of fuel burned per hour in Dryer
- 24,430 =lbs of finished product per hour (lbs of finished product / hours)
- 1,174 =lbs of face & backer paper per hour (surf. ftge.prod. per hour x lbs of paper per M/1000)
- 23,256 =lbs of finished product per hour less paper (lbs of finished product / hours- paper)
- 28,472 =Pounds of material produced by the dryer per hour (dry basis, assuming fuel balances)
- 5,216 =weight of screened fines per hour (total fuel)
- 18.32% =resulting loss to fines as percentage of dryer throughput

FRESS CHART
 8/28/96
 0700-1900



0700/1900

TEST TIMES	PRESSLOAD
0930 - 0955	6
1040 - 1133	14
1215 - 1332	20
1500 - 1618	21



LOUISIANA - PACIFIC CORPORATION
NEWBERRY, MICHIGAN

DATE: 8/28/96

SHIFT PRODUCTION
Summary
8/28/96

SHIFT	TYPE	# OF PIECES LOADS	A-GRADE	FOOTAGE	SCHED. RUN TIME	DOWNTIME % MINUTED	% 'A' GRADE	WOOD USAGE
A.M. TO P.M. A CREW	7/16 P.S. 4x18	160		188,160	720	104	98.2	KONUS #1 _____ #2 <u>11.8</u> DRYER 16T <u>44,977</u>
P.M. TO A.M. C CREW	7/16 P.S. 4x18	179		210,504	720	14	96.7	KONUS #1 _____ #2 <u>13.8</u> DRYER END <u>39,951</u>
TOTAL DAILY				398,664				
PRODUCTION M.T.D.								
1ST SHIFT <u>825,888</u>								
2ND SHIFT <u>1,146,432</u>								
TOTAL <u>1,972,320</u>								
CREW A: <u>325,136</u>								
CREW B: <u>430,752</u>								
CREW C: <u>398,664</u>								
CREW D: <u>247,768</u>								
TOTAL <u>1,972,320</u>								

DAILY PRESS VERT CHECK
TIME CHECKED 2:50 PM

HOURS DOWN	HOURS RUN
10T	
END	

W.T.D.
M.T.D.
Y.T.D.

LOG COUNT	DAILY	W.T.D.	M.T.D.
CREW A	9117	14,237	14,237
CREW B			
CREW C	11,100	18,380	18,380
CREW D			


FOREMAN	% IVT
CURTIS VOGEL	87.5
BILL MAGNUSON	
KIRK BOWLER	93.6
BODDY GRANDELL	

TOTAL 1,972,320
CREW A: 325,136
CREW B: 430,752
CREW C: 398,664
CREW D: 247,768
TOTAL 1,972,320

MAJOR DOWNTIME: A-CREW 103 MIN FILLING INST BUS (STACK TESTING PURCHASES), #2 B.M.
BAGS CHARGED

DRYER CHART

8/28/94



40

DRYER REPORT

OPERATOR: JAMES DEACU SHIFT: 7am-7pm CREW: A DATE: 8-28-96

TIME	WET BIN LEVEL	FEED SPEED %	INLET TEMP %F	OUTLET TEMP %F	OUTLET MOIST. %	DRY FUEL USED LB.	SET POINT
7:45	27.7	440	1132	284	3.2-3.2	1072	265-262
1:21	25.5	430	1136	286	4.0-3.8	6360	267-261
6:21	27.7	420	869	283	3.8-3.8	9741	259-261
						9995	
						X 4.5	263-261
	23.6	430	AVE:1045	AVE:284	AVE:3.6-3.6	TOT: <u>44977</u>	AVE: ..

ONCE PER SHIFT:

WET WAFER MOIST. % 49.7 - 49.1 - 47.7 HAMMERMILL MAGNET CLEANED: X
 DRYER FUEL MOIST. % 2.0 WOOD FUEL FILTER CLEANED: X
 # 1 BAGHOUSE MAGNEHELIC 3.0 CROSS TRANSFER GAS METER 5343
 MCCONNEL GAS METER 4694 PANEL OVEN GAS METER 3707

TIMES AND REASONS FOR DOWNTIME: _____

OTHER PROBLEMS: Fuel bin baghouse is plugging every so often. Have to keep checking it.

NEWBERRY DRYER DATA
(FUEL CALIB. LB/COUNT)

8/28/96

DRYER DATA

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
9:30	262	440	1043	290	2921	20.8	26.1/30.5		3.3
9:40	262	445	982	287	3060	21.4	25.4/30.1		3.5
9:50	262	445	1024	282	3232	18.9	25.5/31.8		3.9
10:00	262	405	965	291	3399	12.4	30.6/27.5	49.7	3.3
10:10	262	405	318	266	3412	11.1	29.0/25.5		3.2
10:20	262	360	235	245	3121	23.9	25.4/22.7		3.3
10:30	262	400	835	284	3555	27.9	25.2/24.4		5.0
10:40	262	445	1030	294	3735	27.4	23.3/25.0		3.4
10:50	262	445	957	288	3898	29.7	24.4/25.3		3.5
11:00	262	445	976	284	4053	29.9	25.2/24.3		3.3
11:10	262	445	946	284	4238	27.2	25.2/24.6		3.5
11:20	262	445	962	282	4386	28.0	24.4/26.4		3.5
11:30	262	445	971	280	4550	28.1	23.6/27.7		3.6
11:40	261	445	753	261	4702	25.9	27.2/26.4		3.7
11:50	261	360	270	252	4702	25.8	27.1/29.0		2.5
12:00	261	340	229	240	4713	25.8	27.2/28.9		2.5
12:10	261	390	928	294	4867	25.2	23.9/28.1		4.2
12:20	261	430	994	289	5031	24.2	26.4/26.8		3.8
12:30	261	440	961	286	5245	21.8	25.8/23.4		3.6
12:40	261	440	943	286	5396	19.0	27.5/22.7		3.5
12:50	261	450	1008	281	5590	20.8	25.4/22.2	49.1	3.8
1:00	261	450	1093	282	5770	24.0	25.0/22.2		3.4
1:10	261	450	1151	268	5949	25.3	24.7/22.1		4.0
1:20	261	430	1143	278	6130	25.0	22.5/24.3		3.8
1:30	261	440	1115	287	6324	25.5	23.1/25.3		3.5
1:40	261	440	1065	286	6487	20.2	22.6/22.8		3.7
1:50	261	440	966	27	6567	17.4	22.1/22.7		4.2

6.45
6.45
6.45


DRYER DATA

NEWBERRY DRYER DATA
(FUEL CALIB. LB/COUNT)

8/28/96

TIME	OUT. SET POINT	FEED RATE	INLET TEMP.	OUTLET TEMP.	FUEL COUNT	WET BIN LEVEL	DRY BIN LEVEL	MOIST. IN	MOIST. OUT
2:00	261	440	263	243	4567	32.0	32.0/32.5		3.5
2:10	261	440	228	227	4567	30.3	32.4/32.1		3.5
2:20	261	440	213	185	4567	25.3	32.4/32.5		2.5
2:30	261	440	206	175	4567	25.3	32.4/32.5		2.5
2:40	261	440	206	228	4599	25.3	32.2/32.4		2.5
2:50	261	350	729	272	6724	32.0	29.3/27.8		4.9
3:00	261	405	959	293	6904	30.0	28.7/27.2		3.9
3:10	261	430	1072	287	7102	33.0	24.8/27.1		3.3
3:20	261	440	1109	281	7282	33.3	27.1/26.4		3.5
3:30	261	440	1142	283	7459	31.1	28.3/27.1		3.4
3:40	261	440	1114	284	7670	33.4	27.2/27.4	47.4	3.3
3:50	261	440	1117	282	7857	30.4	27.2/28.0		3.4
4:00	261	440	1091	282	7996	31.8	29.0/29.5		3.4
4:10	261	440	1059	284	868	30.9	28.9/27.1		3.2
4:20	261	440	1029	283	8340	29.6	28.1/29.5		3.2
4:30	261	400	1091	300	8345	30.5	28.1/29.0		3.2
4:40	261	400	1047	289	8345	29.9	29.5/31.1		4.2
4:50	261	400	987	279	8345	26.9	26.1/31.2		4.5
5:00	261	405	970	282	8436	26.2	27.2/29.2		3.9
5:10	261	410	970	282	8672	26.4	26.9/30.3		3.6
5:20	261	410	981	284	8806	29.5	26.5/29.7		3.7
5:30	261	410	968	284	8883	30.2	26.2/29.9		3.5
5:40	261	410	950	279	9108	33.0	26.9/28.0		3.7
5:50	261	410	965	281	9266	32.8	26.9/29.5		3.6
6:00	261	410	923	286	9418	28.4	25.5/30.0		3.5
6:10	261	410	879	287	9555	22.1	24.4/30.3		3.7
6:20									

8/28/96



NEWBERRY E-TUBE DATA SHEET

8/28/94 TIME	#1			#2			QUENCH	
	KV	MA	SPARK RATE	KV	MA	SPARK RATE	INLET	OUTLET
9:30	46	170	25.8	47	140	25.8	244	140
9:35	45	160	29.9	46	120	29.9	244	141
9:45	45	180	29.9	46	140	29.8	239	141
9:55	46	300	29.8	44	200	29.9	244	139
10:05	43	280	29.9	46	240	29.9	232	100
10:15	42	130	25.7	42	120	25.6	223	96
10:25	44	120	25.6	46	110	25.6	236	125
10:35	46	130	25.5	44	100	25.6	246	139
10:45	24	80	25.8	40	100	25.6	244	139
10:55	46	180	25.6	46	160	25.6	240	140
11:05	46	180	25.5	46	100	25.6	241	139
11:15	47	170	25.6	45	120	25.6	240	140
11:25	46	180	25.6	46	180	25.6	238	139
11:35	46	220	25.6	44	120	25.6	220	110
11:45	40	200	25.6	42	280	25.6	225	97
11:55	40	200	25.6	40	220	25.6	228	95
12:05	43	44	25.6	48	73	25.6	233	132
12:15	45	140	25.5	47	130	25.5	244	138
12:25	47	190	25.6	44	40	25.9	243	139
12:35	47	180	25.6	47	160	25.5	242	140
12:45	46	160	25.5	47	170	25.6	235	142
12:55	47	170	25.6	48	160	25.5	241	144
1:05	48	200	25.6	48	180	25.7	231	145
1:15	47	200	25.7	48	160	25.5	240	145
1:25	47	180	25.5	47	160	25.6	240	145
1:35	46	190	25.6	47	140	25.6	240	145
1:45	44	240	25.6	42	220	25.6	238	104
1:55	40	260	25.5	42	260	25.7	219	97
2:05	38	220	25.7	38	180	25.5	188	90
2:15	38	160	25.6	38	140	25.6	169	84
2:25	40	120	25.6	42	140	25.6	160	82

45

NEWBERRY E-TUBE DATA SHEET

7/28/96 TIME	#1			#2			QUENCH	
	KV	MA	SPARK RATE	KV	MA	SPARK RATE	INLET	OUTLET
	2:35	42	120	25.7	42	100	25.6	198
2:45	46	140	25.6	46	140	25.5	219	115
2:55	45	120	25.5	45	130	25.5	241	138
3:05	46	180	25.6	46	180	25.5	243	142
3:15	47	190	25.5	47	160	25.6	241	144
3:25	46	140	25.6	47	180	25.5	243	144
3:35	48	210	25.5	48	190	25.6	242	144
3:45	48	220	25.5	47	180	25.5	241	143
4:05 3:55	47	200	25.6	48	190	25.6	241	144
4:15 4:05	47	200	25.6	47	140	25.5	243	141
4:25 4:15	48	200	25.5	46	160	25.7	241	142
4:25	45	220	25.5	45	210	25.6	249	142
4:35	46	220	25.5	47	180	25.7	244	142
4:45	48	240	25.5	47	240	25.6	235	143
4:55	47	240	25.5	48	140	25.6	238	141
5:05	36	80	27.7	38	60	27.6	240	142
5:15	46	200	27.3	47	140	27.5	241	141
5:25	46	180	27.5	48	170	27.5	242	140
5:35	47	210	27.5	47	150	27.5	240	140
5:45	46	200	27.5	47	160	27.5	240	141
5:55	47	180	27.5	48	190	27.5	243	138
6:05	47	160	27.5	46	140	27.6	243	137
6:15								

46

Louisiana-Pacific Corporation
Newberry, Michigan

E-TUBE OPERATING REPORT

Days	CART		Crew	A		Date	8-28-96	
Nights	WARREN			C				

Time	TIR CONTROL PANEL, DIGITAL TRANSFORMER/RECTIFIERS				Meat Pad A P	ZYCOM			Beginning & End of Shift on the Vessel			
	No. 1	No. 2	KV	mA		INLET deg. F	OUTLET deg. F	in IPO	in IPO	Flush Water total gal.	Make-up Water total gal.	Vessel PSI
7:00 AM	45	153	45	129	3.5	239	193	11	26	1136362	541077	
8:00 AM	45	121	45	108	3.5	240	195	11	26			
9:00 AM	45	121	45	147	3.5	243	141	11	26			
10:00 AM	45	137	45	152	3.5	241	142	11	26			
11:00 AM	46	167	45	120	3.5	241	139	11	27			
12:00 PM					DEVIERS DOWN							
1:00 PM	45	136	47	162	3.5	242	144	12	26			
2:00 PM					DEVIERS DOWN							
3:00 PM	45	154	45	145	3.5	243	141	11	27			
4:00 PM	45	200	44	119	3.5	241	144	11	25			
5:00 PM	46	206	46	119	3.5	239	141	11	26			
6:00 PM	44	203	45	141	3.5	243	138	11	26			
7:00 PM	45	144	45	140	3.5	239	141	11	26			
8:00 PM	42	204	44	180	2.5	249	171	11	27			
9:00 PM	43	214	44	182	3.5	249	176	11	25			
10:00 PM	43	117	45	240	3.5	238	139	11	26			
11:00 PM	43	134	45	140	3.5	244	142	11	26			
12:00 AM	37	158	44	85	3.5	244	144	11	27			
1:00 AM	44	114	46	145	3.5	244	144	11	26			
2:00 AM	47	212	47	135	2.5	237	145	11	26			
3:00 AM	47	251	48	139	2.5	250	142	11	26			
4:00 AM	44	146	47	150	2.5	232	142	11	26			
5:00 AM	41	181	42	158	3.5	242	147	11	26			
6:00 AM	44	147	47	184	2.5	235	140	11	27	1144363	547420	
Total Hours	Operating on Natural Gas								Total:	7801	6343	

Recycle Water Solids %	6.3%	8.0	Day	Night
Time	11:25	7:50		
Spark Rate Transformer/Rectifier	25.6	25.4		
	NO. 1	NO. 2		

RECYCLE BLOWDOWN	
Estimated Gallons	
Gallons Used	
Caustic	3053
Defoamer	1128
Start:	3049
Find:	1172
Total:	414

Check caustic level

Check Defoamer level

Clean recycle line strainer


Solids Test

Record time started new tote

Age Chart: 7:00 a.m.

57

RTO CHART
NEWBERRY
8/28/96



NEWBERRY DRYER RTO

2/25/96

TIME /0 MINUTES	CHAMBER TEMPS.					INLET TEMP.	BURNERS		COMB. TEMP.	EXHAUST TEMP.	PRESS. DROP	GAS USAGE	OPACITY
	#1	#2	#3	#4	#5		#1	#2					
9:25	507	481	465	472	498	158	1532	1542	1534	275	1.0	43151	0
9:35	508	481	464	475	494	158	1538	1535	1545	280	1.0	43160	0
9:45	501	489	461	478	495	159	1538	1533	1540	280	1.0	43167	0
9:55	507	481	465	478	497	158	1541	1538	1539	281	1.0	43174	0
10:05	505	483	465	478	502	137	1524	1537	1530	283	1.1	43180	0
10:15	501	483	457	478	486	121	1544	1536	1540	269	1.2	43182	0
10:25	502	475	457	478	486	127	1547	1539	1547	265	1.2	43196	0
10:35	494	479	453	478	483	157	1540	1533	1542	267	1.2	43204	0
10:45	499	476	454	478	482	155	1539	1531	1540	273	1.0	43211	0
10:55	500	470	456	478	484	155	1547	1542	1530	275	1.3	43218	0
11:05	503	475	460	473	489	156	1545	1539	1537	276	.9	43229	0
11:15	504	475	460	472	490	156	1547	1540	1533	276	1.1	43231	0
11:25	503	477	461	471	493	158	1540	1540	1549	280	1.4	43240	0
11:35	505	477	459	477	487	157	1542	1537	1549	281	.7	43245	0
11:45	504	480	457	480	481	133	1540	1534	1539	277	1.7	43254	0
11:55	497	479	458	467	493	122	1532	1542	1536	275	1.1	43262	0
12:05	496	470	451	470	477	141	1552	1542	1543	263	2.0	43271	0
12:15	487	475	467	464	486	152	1529	1542	1537	271	1.9	43280	0
12:25	495	475	467	477	479	164	1543	1537	1547	275	2.0	43289	0
12:35	499	476	464	473	483	155	1546	1541	1534	275	2.1	43294	0
12:45	500	474	463	477	485	156	1549	1537	1537	279	2.1	43300	0
12:55	495	481	463	480	484	158	1541	1537	1544	279	2.1	43307	0
1:05	495	482	466	475	491	161	1530	1543	1537	280	1.9	43312	0
1:15	500	478	460	473	495	161	1533	1541	1540	283	2.0	43321	0
1:25	505	477	460	481	487	161	1546	1538	1548	282	2.0	43328	0
1:35	501	484	459	483	489	160	1535	1521	1535	282	2.0	43334	0
1:45	507	476	463	478	494	153	1536	1532	1542	283	2.1	43341	0
1:55	502	481	467	482	487	124	1534	1536	1543	277	2.2	43347	0
2:05	500	471	464	474	482	117	1544	1538	1543	268	2.5	43358	0
2:15	494	464	453	465	479	110	1545	1541	1547	260	2.3	43368	0
2:25	483	470	446	465	474	107	1536	1529	1537	258	2.2	43379	0
2:35	481	461	447	454	475	109	1534	1544	1543	256	2.2	43386	0
2:45	481	458	446	452	473	142	1540	1543	1547	257	1.9	43396	0

476
476
470
470
474

NEWBERRY DRYER RTO

8/28/96

TIME MINUTES	CHAMBER TEMPS.					INLET TEMP.	BURNERS		COMB. TEMP.	EXHAUST TEMP.	PRESS. DROP	GAS USAGE	OPACITY
	#1	#2	#3	#4	#5		#1	#2					
2:53	480	464	444	462	468	148	1538	1524	1542	263	19	43402	-
3:05	482	469	448	466	475	157	1640	1626	1543	270	18	43407	-
3:15	487	467	452	462	482	159	1533	1542	1542	273	18	43412	-
3:25	490	469	456	469	484	160	1544	1538	1539	276	18	43420	-
3:35	493	475	464	477	487	160	1542	1538	1539	279	19	43425	-
3:45	496	481	480	478	486	161	1537	1535	1541	280	19	43432	-
3:55	498	479	487	480	486	161	1540	1536	1543	280	18	43437	-
4:05	503	476	491	474	492	160	1538	1539	1548	287	18	43442	-
4:15	505	477	490	479	487	157	1546	1535	1547	280	19	43450	-
4:25	506	478	494	480	488	161	1549	1546	1532	287	18	43457	-
4:35	508	483	494	480	492	157	1532	1529	1531	287	19	43464	-
4:45	500	480	496	479	484	160	1533	1530	1534	283	19	43472	-
4:55	499	487	492	478	497	159	1529	1534	1532	287	18	43479	-
5:05	501	488	490	483	493	159	1538	1533	1539	280	18	43484	-
5:15	501	486	492	481	497	152	1532	1539	1535	278	18	43494	-
5:25	503	484	491	481	494	157	1539	1534	1541	276	18	43500	-
5:35	504	483	494	482	490	157	1540	1533	1543	278	19	43508	-
5:45	502	477	494	476	493	158	1544	1537	1538	276	18	43515	-
5:55	508	477	494	479	494	156	1542	1538	1549	277	18	43522	-
6:05	504	480	495	472	499	152	1533	1542	1539	278	18	43529	-

* TEST PROBC IN PATH OF MONITOR

DRYER RTO DATA

Louisiana-Pacific Corporation
Newberry, MI

Whioelabrator Clean Air Systems
RTO

A-Crew days
C crew Nights

Date:	8-28-96											
Time	8:00 AM	10:00 AM	12:00 PM	2:00 PM	4:00 PM	6:00 PM	8:00 PM	10:00 PM	12:00 AM	2:00 AM	4:00 AM	6:00 AM
Burner S.P.	1538	1538	1538	1538	1538	1538	1538	1538	1538	1538	1538	1538
Bnr #1 temp	1532	1528	1534	1538	1530	1537	1531	1531	1547	1541	1533	1530
Bnr #1 out	17.5	28.3	24.0	24.5	17.2	16.0	19.6	18.8	7.7	13.7	6.3	18.2
Bnr #2 temp	1542	1544	1543	1545	1548	1542	1541	1537	1547	1542	1538	1541
Bnr #2 out	6.0	14.6	15.6	15.2	5.1	9.1	10.1	12.8	1.6	3.2	6.3	4.6
Inlet temp	161	130	122	110	160	158	150	153	153	159	158	157
Chamber temp	1538	1534	1537	1543	1536	1544	1549	1542	1556	1548	1540	1538
Exhaust temp	280	279	274	262	280	277	303	304	306	302	304	304
RTO Diff Press	1700	2600	2700	2700	2200	2100	2100	2300	1800	2141	1900	1800
VFD Amps	458	570	604	614	480	482	487	522	462	485	480	457
VFD RPM	1232	1409	1429	1417	1303	1298	1312	1345	1245	1315	1261	1250
PN setpoint	1.4	1.0	1.1	1.0	1.1	1.0	1.0	1.0	1.1	1.0	1.1	1.0
PN out	58.1	72.1	75.0	72.5	1.1	1.1	66.5	67.6	53.7	60.2	61.2	60.1
Chr #1 B.O. temp	501	500	495	486	501	501	505	504	508	502	493	501
Chr #2 B.O. temp	489	491	484	473	480	486	478	478	481	482	492	481
Chr #3 B.O. temp	459	461	456	451	459	461	464	462	467	463	461	458
Chr #4 B.O. temp	477	475	473	464	481	475	467	472	469	468	473	475
Chr #5 B.O. temp	471	498	490	483	486	493	493	489	499	488	500	497
Fan brg #1 temp	84	96	106	113	110	107	102	96	92	91	87	86
Fan brg #2 temp	75	86	94	105	103	97	99	94	81	80	76	75
Motor brg #1 temp	86	97	110	120	118	112	107	101	93	94	89	87
Motor brg #2 temp	77	88	100	108	108	102	96	90	83	91	79	77
Dryer to RTO	yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	yes	yes
Panel Line to RTO												
Lap Line to RTO												
Chamber Prq Fan	010	010	010	010	010	010	010	010	010	010	010	010
BTUE Pressure	19	18	18	18	18	18	18	18	18	18	18	18
BTUE Flow DP	43096	43181	43261	43361	43442	43515	43614	43691	43766	43867	43951	44035
Comments:												
Daily Gas Usage:												

51

08/28/96 NEWBERRY BOARD WEIGHTS
 (lbs./4x18 panel every 25th mat)
 APPROXIMATE TIMES

<i>DRYER HCHO</i>		<i>PRESS PHENOL</i>	
0930-0955	115	1215-1317	122
1040-1133	118		121
	120	1450-1552	118
	119		119
1215-1332	118		117
	121		119
1500-1618	117		118
	118		120
	116		123
	119		123
	120		120
	121	1615-1717	121
	122		120
	121		119
	120		116
	122		116
	123		114
AVE	<u>119.41</u>		118
			118
			120
		AVE	<u>119.10</u>

PRESS AUGUST 28, 1996

PHENOL, METHANE

DATA TIME:	START=	12:15	END=	13:17	HOURS=	1.03
	START=	14:50	END=	15:52	HOURS=	1.03
	START=	16:15	END=	17:17	HOURS=	<u>1.03</u>
				TOTAL=		3.10

BOARD WEIGHTS - LBS

average weights determined by taking every 25th untrimmed board (from press tapes)

7/16"		119.1 lb= average
lb per/ 4' x 9'	55.40	untrimmed
lb per/ 4' x 18'	110.80	mat weight
lb weight of	74.15	6.97% =trim %
paper overlay		
(per msf)		

PLANT PRODUCTION RATE

- 3.10 =hours during testing
- 49 =pressloads (see press chart)
- 686 =no. of 4'x18' boards produced (pressloads x 14 boards per load)
- 49,392 =volume produced in surface footage (pressloads x 4'x18'x14 openings)
- 57,626 =volume produced 3/8" basis (pressloads x 4'x18'x 14 openings x 1.1667)
- 76,008 =lbs of finished product (boards produced x weight of finished board)
- 24,519 =lbs of finished product per hour (lbs of finished product / hours)
- 12.26 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

RESIN USAGE TAKEN FROM TOTALIZERS


TIME	MDI	WAX	ZINC BOR.
12:15-13:17	1,022	255	341
14:50-15:52	999	247	354
16:15-17:17	945	238	369
ave. lbs/hr.	957	239	343
100% solids			

- 24,519 =average lbs. per hour finished product produced during testing
- 957 =average lbs. per hour of MDI resin used during testing
- 3.90% = MDI resin used as % of finished product

- 239 =average lbs. per hour of wax (100% solids) used during testing
- 0.97% =wax used as % of finished product

- 343 =Zinc Borate usage in pounds per hour
- 1.40% =Zinc Borate as % of finished product

PRESS CHART
 8/28/96
 0700-1900



<u>TEST TIMES</u>	<u>PRESSLOADS</u>
1215 - 1317	16
1450 - 1552	17
1615 - 1717	16



Louisiana-Pacific Corporation

Newberry OSB Plant

Date 8/28/96

TIME	PRESS TEMP.	MDI USAGE SURFACE	MDI USAGE CORE	WAX USAGE SURFACE	WAX USAGE CORE
9:30	408	1304	1128	568	484
9:40		1373	1187	599	509
9:50		1433	1254	634 634	539
10:00		1523	1316	664	564
10:10		1606	1387	701	596
10:20		1643	1419	717	609
10:30	411	1661	1433	725	615
10:40		1742	1503	760	645
10:50		1820	1570	794	673
11:00		1895	1636	827	701
11:10		1997	1721	873	739
11:20		2072	1785	905	767
11:30	410	2154	1852	942	796
11:40		2218	1907	969	819
11:50		2218	1907	969	819
12:00		2218	1907	969	819
12:10		2283	1964	999	844
12:20		2362	2031	1035	874
12:30	411	2466	2119	1080	911
12:40		2537	2183	1111	938
12:50		2638	2269	1157	974
1:00		2724	2344	1194	1005
1:10		2808	2417	1231	1036
1:20		2908	2507	1275	1073
1:30	408	2971	2560	1300	1094
1:40		3003	2589	1315	1105
1:50		3003	2589	1315	1105
2:00		3003	2589	1315	1105
2:10		3003	2589	1315	1105
2:20		3003	2589	1315	1105
2:30	401	3003	2589	1315	1105
2:40		3003	2589	1315	1105
2:50		3090	2664	1353	1135
3:00		3178	2737	1391	1164
3:10		3274	2819	1433	1200



Louisiana-Pacific Corporation

Newberry OSB Plant

Date

8-28-96

Dryer 1
 start 9:30a
 stop 9:55a
 Knife change
 start 10:40
 Finish 11:33
 Dryer 1

START
 Dryer 2
 12:15
 START
 Press 1
 12:15
 Finish
 Press 1
 12:47
 Finish
 Dryer 2
 1:32

START
 Press 2
 2:00
 START
 Dryer 2
 3:00

TIME	SCALE READING SURFACE	SCALE READING CORE	SCALE READING ZINC BORATE
9:25	24858.2	19798.5	989
9:35	24859.2	19799.4	934
9:45	24860.4	19800.3	889
9:55	INTERNAL WAITING ON SUPPLIES	VIA FED EX	
10:05			
10:15			
10:25			
10:35			
10:45			
10:55			
11:05			
11:15			
11:25			
11:35			
11:45			
11:55	Switched Analytes PM	VOC (condensibles)	
12:05	24870.5	19809.9	2883
12:15	x 24871.5	19809.7	2832
12:25	24872.6	19810.6	2784
12:35	24873.9	19811.8	2709
12:45	24874.7	19812.5	2664
12:55	24875.9	19813.4	2601
1:05	24877.1	19814.4	2543
1:15	x 24878.1	19815.3	2491
1:25	24879.0	19816.1	2434
1:35	24879.9	19816.9	2378
1:45	24879.9	19816.9	2379
1:55			
2:05			
2:15			
2:25			
2:35			
2:45	x 24881.0	19817.8	2344
2:55	24881.5	19818.2	2312
3:05	24882.6	19819.1	2244



Louisiana-Pacific Corporation

Newberry OSB Plant

Date

8-28-96

TIME	SCALE READING		SCALE READING	
	SURFACE	CORE	ZINC BORATE	
3:15	24883.9	19800.1	2172	
3:25	24884.5	19820.7	2136	
3:35	24885.6	19821.7	2076	
3:45	x 24886.6	19822.5	2012	
3:55	24887.7	19823.4	1958	
4:05	24888.9	19824.4	1887	
4:15	x 24890.0	19825.3	1819	
4:25	24890.9	19826.1	1766	
4:35	24892.2	19827.2	1700	
4:45	24893.6	19828.7	1617	
5:05	24895.4	19830.0	1588	
5:17	(24896.4)	(19830.8)	(1550)	
5:25				
5:35				
5:45				
5:55				
6:05				
6:15				
6:25				
6:35				
6:45				
6:55				
7:05				
7:15				
7:25				
7:35				
7:45				
7:55				
8:05				
8:15				
8:25				
8:35				
8:45				
8:55				

357 #
 END
 4 1/2 stall
 press #1
 END
 #4
 5 1/2 stall
 press #1
 END
 #4



Louisiana-Pacific Corporation

Northern Division

KONUS CHECKLIST

OPERATOR D. EDGAR SHIFT DAYS CREW A DATE 8-28-96

THERMAL OIL LEVEL - FT. 2

FUEL OIL INCHES #1 <u>Full</u> #2 <u>Full</u>		
MILLTRONICS		
CLARK BINS (QUARTERS)	BARK BIN	
EMERGENCY DIESEL	CHECKED	FILLED
FUEL LEVEL		
EMERGENCY DIESEL	CHECKED	FILLED
OIL LEVEL		
EMERGENCY COOLING TANK	CHECKED	FILLED
EMERGENCY DIESEL RUN EACH SHIFT	YES	NO
T.O. PUMP PRESSURE	SUCTION	DISCHARGE
PRIMARY PUMP I		
PRIMARY PUMP II		
PRIMARY PUMP III	OFF	
ECONOMIZER PUMP I		
ECONOMIZER PUMP II	OFF	

LEVEL E-TUBE BLOW DOWN TANK:
 7:00 43" 1:00 45"
 POND SET POINT OFF
 POND TEMP #1 - #2 -

	SET POINT	RETURN	OUTLET
KONUS I	OFF		
KONUS II	500	464	520
SPACE HEAT	OFF		
ECONOMIZER	500		
FLUE GAS	#1 <u>-</u>	#2	582
BLEND AIR	#1 <u>-</u>	#2	359
KONUS ROOM BLOWN DOWN	YES	NO	
KONUS ROOM SWEPT	YES	NO	

KONUS BAGHOUSE (TWICE A SHIFT)
SAWTRIM BAGHOUSES (TWICE A SHIFT)

KONUS FUEL	I	II
WOOD HRS.		12
OIL HRS.		0
WOOD FUEL IN TONS		11.8

COUNTER	SCALE	
BEGINNING	8744.5	8858763
END	8756.3	8860385
TOTAL		

PRESS AUGUST 29, 1996

PM,CO,NOX,VOC

DATA TIME:	START=	09:00	END=	10:00	HOURS=	1.00
	START=	10:35	END=	11:35	HOURS=	1.00
	START=	12:10	END=	13:10	HOURS=	<u>1.00</u>
					TOTAL=	3.00

BOARD WEIGHTS - LBS

average weights determined by taking every 25th untrimmed board (from press tapes)

7/16"		117.6 lb= average
lb per/ 4' x 9'	54.69	untrimmed
lb per/ 4' x 18'	109.38	mat weight

lb weight of 74.15
paper overlay
(per msf) 6.97% =trim %

PLANT PRODUCTION RATE

3.00 =hours during testing
47 =pressloads (see press chart)
658 =no. of 4'x18' boards produced (pressloads x 14 boards per load)
47,376 =volume produced in surface footage (pressloads x 4'x18'x14 openings)
55,274 =volume produced 3/8" basis (pressloads x 4'x18'x 14 openings x 1.1667)
71,970 =lbs of finished product (boards produced x weight of finished board)
23,990 =lbs of finished product per hour (lbs of finished product / hours)
11.99 =tons of finished product per hour (lbs of finished product per hour / 2000 lb)

RESIN USAGE TAKEN FROM TOTALIZERS

TIME	MDI	WAX	ZINC BOR.
09:00-10:00	929	222	287
10:35-11:35	934	231	394
12:10-13:10	843	216	325
ave. lbs/hr.	902	223	335

100% solids

23,990 =average lbs. per hour finished product produced during testing
902 =average lbs. per hour of MDI resin used during testing
3.76% = MDI resin used as % of finished product

223 =average lbs. per hour of wax (100% solids) used during testing
0.93% =wax used as % of finished product

335 =Zinc Borate usage in pounds per hour
1.40% =Zinc Borate as % of finished product

60



LOUISIANA-PACIFIC CORPORATION
NEWBERY, MICHIGAN

DATE: 8/29/96

SHIFT	TYPE	# OF PIESS LOADS	A-GRADE	FOOTAGE	8 CHIED. RUN TIME	DOWNTIME MINUTES	% RUN TIME	% A-GRADE	WOOD USAGE
A.M. TO P.M. A CREW	7/16 P.S. 4x18	174		204,624	718	250 49 MIN 51	93.1	98.3	KOHUS #1 #2 12.7 DIYER 1ST 36,661
P.M. TO A.M. C CREW	7/16 P.S. 4x18	187		219,912	720	2	99.0	100%	KOHUS #1 #2 12.55 DIYER 2ND 54,111
TOTAL DAILY				424,536					

PRODUCTION M.T.D.

1ST SHIFT 1,038,512

2ND SHIFT 1,366,344

TOTAL 2,396,856

CREW A: 599,760

CREW B: 430,252

CREW C: 618,576

CREW D: 247,268

TOTAL 2,396,856

W.T.D.

M.T.D.

Y.T.D.

2,396,856

2,396,856

81,938,166

HOURS DOWN	HOURS RUN
10T	
21D	

DAILY PRESS VENT CHECK
TIME CHECKED 10:00 AM

FOREMAN	% INT
CHRIS VOGEL	90.7
BILL MAGNUSON	
KIHK BOWLER	95.4
BOBBY SPANDELL	

LOG COUNT	DAILY	W.T.D.	M.T.D.
CREW A	9353	23,550	23,550
CREW B			
CREW C	3900	23,280	23,280
CREW D			

W.T. 10
M.T. 10
Y.T. 10
W.T. 10
M.T. 10
Y.T. 10

MAJOR DOWNTIME:

A-CREW 1/6 MIN - FILLING BINS (START TESTING PURPOSES)



Louisiana-Pacific Corporation

Newberry OSB Plant

Date

8/29/96

TIME	PRESS TEMP.	MDI USAGE SURFACE	MDI USAGE CORE	WAX USAGE SURFACE	WAX USAGE CORE
9:00		632	541	267	227
9:10		705	609	294	254
9:20		790	678	333	283
9:30		878	753	369	312
9:40		964	828	406	342
9:50		1043	898	441	308
10:00	405	1125	977	476	401
10:10		1220	1052	520	434
10:20		1314	1137	560	470
10:30		1405	1225	599	509
10:40		1477	1296	633	538
10:50		1570	1381	673	572
11:00	407	1671	1466	720	606
11:10		1778	1560	768	646
11:20		1816	1599	783	663
11:30		1892	1672	815	692
11:40		2020	1766	875	740
11:50		2108	1829	898	767
12:00	410	2156	1906	938	790
12:10		2236	1973	974	818
12:20		2318	2049	1010	849
12:30		2379	2101	1038	869
12:40		2475	2180	1083	903
12:50		2543	2238	1113	928
1:00	410	2624	2306	1152	959
1:10		2690	2362	1183	983
1:20					
1:30					
1:40					
1:50					
2:00					

ST # 1 900

E # 1 1000

S # 2 1055

E # 2 1135

S # 3 1210



Louisiana-Pacific Corporation

Newberry OSB Plant

Date

8/29/98

TIME	SCALE READING		SCALE READING		SCALE READING
	SURFACE		CORE		ZINC BORATE
9:00	24987.4		19904.7		5617
9:10	24988.2		19905.5		578
9:20	24989.3		19906.5		498
9:30	24990.0		19906.9		463
9:40	24991.2		19908.2		2918
9:50	24992.1		19908.7		2876
10:00	24993.3		19909.9		2830
10:10	24994.5		19910.9		2760
10:20	24995.6		19911.8		2708
10:30	—		—		—
10:40	24997.4		19913.5		2600
10:50	24998.5		19914.4		2528
11:00	24999.5		19915.2		2480
11:10	25000.6		19916.3		2421
20	25001.5		19917.0		2367
30	25002.7		19918.1		2300
40	25003.9		19919.1		2234
50	—		—		—
1200	—		—		—
10	25007.0		19921.8		2050
20	25008.1		19922.8		1989
30	25008.9		19923.3		1940
40	25009.8		19924.1		1886
50	25010.7		19924.9		1828
1300	25011.7		19925.5		1785
10	25012.7		19926.5		1725
20					
30					
40					
50					
1400					

1003

ST. # 1 9:00

KRASS #2500
BAG #1
END 10:00

#2 10:35

#2 11:30
2200

ST. # 3 12:00

#3 1:10



Louisiana-Pacific Corporation

Northern Division

KONUS CHECKLIST

OPERATOR D. EdgAKSHIFT DAYSCREW ADATE 2-29-96THERMAL OIL LEVEL - FT. 2'

FUEL OIL INCHES #1 <u>FULL</u> #2 <u>FULL</u>		
MILLTRONICS		
CLARK BINS (QUARTERS)	BARK BIN	
EMERGENCY DIESEL FUEL LEVEL	CHECKED	FILLED
EMERGENCY DIESEL OIL LEVEL	CHECKED	FILLED
EMERGENCY COOLING TANK	CHECKED	FILLED
EMERGENCY DIESEL RUN EACH SHIFT	YES	NO
T.O. PUMP PRESSURE	SUCTION	DISCHARGE
PRIMARY PUMP I	<u>✓</u>	<u>✓</u>
PRIMARY PUMP II	<u>✓</u>	<u>✓</u>
PRIMARY PUMP III	<u>OFF</u>	
ECONOMIZER PUMP I	<u>✓</u>	<u>✓</u>
ECONOMIZER PUMP II	<u>OFF</u>	

LEVEL E-TUBE BLOW DOWN TANK

7:00 49" 1:00 52"POND-SET POINT OFFPOND TEMP #1 --- #2 ---

	SET POINT	RETURN	OUTLET
KONUS I	<u>OFF</u>		
KONUS II	<u>500</u>	<u>486</u>	<u>510</u>
SPACE HEAT	<u>OFF</u>		
ECONOMIZER	<u>500</u>		
FLUE GAS	#1 <u>---</u>	#2 <u>773</u>	
BLEND AIR	#1 <u>---</u>	#2 <u>350</u>	
KONUS ROOM BLOWN DOWN	YES	NO	
KONUS ROOM SWEEP	<u>YES</u>	NO	

KONUS BAGHOUSE (TWICE A SHIFT)

SAWTRIM BAGHOUSES (TWICE A SHIFT)

KONUS FUEL	I	II
WOOD HRS.	<u>X</u>	<u>12</u>
OIL HRS.	<u>X</u>	<u>0</u>
WOOD FUEL IN TONS	<u>X</u>	<u>12.7</u>

COUNTER	SCALE	
BEGINNING	<u>8770.1</u>	<u>8862/60</u>
END	<u>8782.8</u>	<u>8863670</u>
TOTAL		

65

08/29/96

NEWBERRY BOARD WEIGHTS
(lbs./4x18 panel every 25th mat)
APPROXIMATE TIMES

PRESS PM

0900-1000	110
	115
	117
	116
	115
	118
	121
	121
	122
1035-1135	118
	118
	120
	120
	116
	118
	117
	116
	115
	118
1210-1310	114
	117
	117
	116
	115
	125
	118
	119
	120
AVE	<u>117.57</u>

66

Issue Date: 03/18/91
 Revised Date: 04/20/94
 Page 1 of 4

SECTION I - PRODUCT IDENTIFICATION

Product Code: 42-500 - 42-509
 Trade Name: DYNOPREG Paint Base Overlay
 Product Class: Paper impregnated with phenol-formaldehyde resin
 C.A.S. Number: Not Applicable

SECTION II - HAZARDOUS INGREDIENTS

<u>Ingredients</u>	<u>CAS #</u>	<u>Weight Max. %</u>	<u>Exposure Limits</u>
Phenol	108-95-2	<0.25	5.0 ppm ACGIH TLV
Formaldehyde	50-00-0	<0.1	.75 ppm ACGIH TLV

SECTION III - PHYSICAL DATA

Boiling Point: N/A	Vapor Density: Non-volatile
Volatile %: N/A	Specific Grav: N/A
Appearance: Non-volatile	Appearance: Powder

SECTION IV - FIRE AND EXPLOSION HAZARD DATA

Flammability Class: N/A

Flash Point: N/A

LEL: N/A

EXTINGUISHING MEDIA:

Water spray, carbon dioxide or foam.

SPECIAL FIRE FIGHTING PROCEDURES:

None known.

UNUSUAL FIRE & EXPLOSION HAZARDS:

Fire fighters should wear self-contained breathing apparatus to avoid inhalation of smoke or vapors.

SECTION V - HEALTH HAZARD DATA

PERMISSIBLE EXPOSURE LEVEL:

Phenol: The OSHA PEL and the ACGIH TLV for phenol is currently set at 5 ppm for an 8-hour TWA.

SECTION V - HEALTH HAZARD DATA (cont.)

PERMISSIBLE EXPOSURE LEVEL (cont.)

Formaldehyde: OSHA has established a .75 ppm PEL for formaldehyde as an 8-hour time weighted average (TWA) and a 2 ppm 15-minute short term exposure limit (STEL). OSHA has also set 0.5 ppm as an action level for formaldehyde. See OSHA regulation at 21 CFR 1910.1048 for information on workplace requirements if these levels are exceeded. ACGIH TLV for formaldehyde is .75 ppm for an 8-hour TWA.

EFFECTS OF
OVEREXPOSURE:

Contact with skin may cause irritation or rash. Eye contact may cause slight irritation or redness. Heated vapors may cause irritation of the respiratory tract.

Repeated or prolonged skin contact with this formaldehyde-containing material may cause an allergic skin reaction (i.e. sensitization) in some individuals.

FIRST AID:

If skin contact, wash with soap and water at once. If eye contact, flush with water for 15 minutes and call a physician. If fumes or heated vapors are inhaled, remove victim to fresh air.

PRIMARY ROUTE(S)
OF ENTRY:

Inhalation of dust or heated fumes. Phenol may be absorbed through the skin.

CARCINOGENICITY:

Formaldehyde is listed as a potential carcinogen by the National Toxicology Program (NTP) and the International Agency for Research on Cancer (IARC).

SECTION VI - REACTIVITY DATA

STABILITY:

Unstable Stable

HAZARDOUS POLYMERIZATION:

May occur Will not occur

INCOMPATIBILITY:

None Known.

CONDITIONS TO AVOID:

Warm storage and ignition sources.

HAZARDOUS
DECOMPOSITION
PRODUCTS:

Under severe thermal degradation toxic fumes, carbon dioxide, carbon monoxide, and formaldehyde may be formed.

Issue Date: 03/18/91
Revised Date: 04-20-94

Product Code: 42-500 - 42-509
Page 3 of 4

SECTION VII - SPILL OR LEAK PROCEDURES

STEPS TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED: Sweep up and place in a closed container. Wear a dust mask if dust is created.

WASTE DISPOSAL METHOD: At this time, this material or its containers would not be considered hazardous wastes as defined under the federal RCRA regulations (40 CFR 261) if discarded. Care should be taken to ensure that the material or its containers are disposed of in an approved facility in accordance with current federal, state, and local regulations.

For further information, contact your state or local solid waste agency or the United States Environmental Protection Agency's RCRA hotline (1-800-424-9346 or 202-382-3000).

SECTION VIII - SPECIAL PROTECTION INFORMATION

- RESPIRATORY PROTECTION:** Should be worn to avoid breathing dust or heated fumes.
- VENTILATION:** Local exhaust and general ventilation recommended.
- PROTECTIVE GLOVES:** Suitable protective gloves must be worn to prevent skin contact.
- EYE PROTECTION:** Safety glasses or goggles are recommended.
- OTHER PROTECTIVE EQUIPMENT:** As required to prevent prolonged or repeated skin contact.

SECTION IX - SPECIAL PRECAUTIONS

- PRECAUTIONS TO BE TAKEN IN HANDLING AND STORING:** Avoid prolonged or repeated skin contact. Store in a cool, dry location.
- OTHER PRECAUTIONS:** Consult Product Bulletin prior to using this material.

69

Issue Date: 03-18-91
Revised Date: 04-20-94

Product Code: 42-500 - 42-509
Page 4 of 4

SECTION X - SUPPLEMENTAL INFORMATION

SARA STATUS: One or more of the chemical substances listed in Section II of this MSDS is subject to the reporting requirements of Section 313 of the Superfund Amendments and Reauthorization Act (SARA) of 1986 and 40 CFR 372.

This material has been categorized as having the following hazard(s) as defined by SARA Title III Regulations (40 CFR 370): acute, chronic.

DOT PROPER SHIPPING NAME: Not regulated by DOT

UN NUMBER: None

DOT HAZARD CLASS: None

THE INFORMATION CONTAINED HEREIN IS BASED ON THE DATA AVAILABLE TO US AND IS BELIEVED TO BE CORRECT. HOWEVER, DYNQ MAKES NO WARRANTY, EXPRESSED OR IMPLIED REGARDING THE ACCURACY OF THESE DATA OR THE RESULTS TO BE OBTAINED FROM THE USE THEREOF. DYNQ ASSUMES NO RESPONSIBILITY FOR INJURY FROM THE USE OF THE PRODUCT DESCRIBED HEREIN.

70

DYNO**MATERIAL SAFETY
DATA SHEET****Dyno Overlays, Inc.****SECTION I - PRODUCT IDENTIFICATION**

Product Code: 42-270 - 42271
 Trade Name: DYNOPREG - Phenolic Backer Overlay [OSB Siding Application]
 Product Class: HDO
 C.A.S. Number: Article
 MSDS Preparation: 13 June, 1995

SECTION II - HAZARDOUS INGREDIENTS

<u>Ingredients</u>	<u>CAS #</u>	<u>Weight % Max.</u>	<u>Exposure Limits</u>
Phenol	108-95-2	<0.10 %	5.0 PPM ACGIH
Formaldehyde	50-00-0	<2.00 %	0.75 PPM ACGIH
Methanol	67-56-1	NA	200 PPM ACGIH

SECTION III - PHYSICAL DATA

Boiling Point:	N/A	Specific Gravity:	N/A
Volatile %:	N/A	Micro Chamber Analysis:	
Evaporation Rate:	Non-Volatile	* Methanol:	NA
Vapor Density:	Non-Volatile	* Formaldehyde:	NA
Appearance:	Brown Paper Coated Gray Top Side	* Phenol:	NA

SECTION IV - FIRE AND EXPLOSION DATA

Flammability Class: N/A
 Flash Point: N/A
 LFL: N/A

MSDS [42-270]

DYNO OVERLAYS INC.

PAGE 2 OF 4

Extinguishing Media: Water Spray, Carbon Dioxide, or Foam

Special Fire Fighting Procedures: None known

Unusual Fire and Explosion Hazards: Fire fighters should wear self contained breathing apparatus to avoid inhalation of smoke and vapors.

SECTION V. HEALTH HAZARD DATA

When heated the paper will give off small amounts of volatile chemicals, primarily formaldehyde, phenol and methanol.

Permissible Exposure Levels:

Phenol: The OSHA PEL (Permissible Exposure Limit) and the ACGIH TLV (Threshold Limit Value) for phenol is currently set at 5 PPM for an 8-hour TWA.

Formaldehyde: OSHA has established a 0.75 PPM PEL for formaldehyde as an 8-hour TWA and a 2 PPM 15 minute STEL (Short Term Exposure Limit). OSHA has also set a 0.5 PPM action level for formaldehyde (see OSHA regulation 21 CFR 1910.1048 for specific information regarding work place requirements). ACGIH TLV for formaldehyde is 0.75 PPM for an 8-hour TWA.

Methanol: The OSHA PEL and the ACGIH TLV for methanol is currently set at 200 PPM for an 8-hour TWA.

Effects of Over Exposure:

Contact with skin may cause irritation or rash. Eye contact may cause slight irritation or redness. Heated vapors may cause irritation of the respiratory tract.

First Aid:

Skin contact: Wash with soap and water at once.

Eye Contact: Flush with water for 15 minutes and call a physician if irritation persists.

Inhalation: If fumes or heated vapors are inhaled, remove victim to fresh air.

Primary Route(s) of Entry:

Inhalation of dust or fumes. Phenol may be absorbed through the skin.

MSDS (42-270)

DYNO OVERLAYS INC.

PAGE 3 OF 4

Carcinogenicity:

Formaldehyde, a component of this product, is listed by the NTP (National Toxicology Program) in their third annual report as a substance that may be reasonably be anticipated to be a carcinogen. Formaldehyde is classified as a "probable carcinogen to humans" by the IARC (International Agency for Research on Cancer). TLV's have been established by the ACGIH. OSHA standard 1910.1048 also requires exposure

monitoring in the work place. For the purpose of this standard, formaldehyde concentrations greater than .1% require initial monitoring to determine if the action level has been exceeded. If the Monitoring levels are in excess of the action level, periodic monitoring will be required as stated in the OSHA standard. The free formaldehyde content in this product is listed in the physical data section of this MSDS.

SECTION VI - REACTIVITY DATA

Stability: Unstable Stable

Hazardous Polymerization: May Occur Will Not Occur

Incompatibility: None known

Conditions to Avoid: Warm storage and ignition sources.

Hazardous Decomposition Products: Under severe thermal degradation, toxic fumes carbon dioxide, carbon monoxide and formaldehyde may be formed.

SECTION VII - SPILL OR LEAK PROCEDURES**Material Release:**

Sweep up and place in a closed container. Proper PPE (Personal Protective Equipment) should be worn per Section VIII of this MSDS.

Waste Disposal Method:

At this time, this material is not would not be considered a hazardous waste as defined under the federal RCRA regulations (40 CFR 261) if discarded. However caution should be taken as these regulations can change and state and local regulations may vary to reclassify this waste as hazardous. Material should always be disposed of in accordance with federal, state and local regulations.

For further information, contact your state or local solid waste disposal agency of the United States Environmental Protection Agency's RCRA hot-line (800-424-9346 or 202-382-3000).

MSDS [42-270]

DYNOL OVERLAYS INC.

PAGE 4 OF 4

SECTION VIII - SPECIAL PROTECTION INFORMATION

Respiratory Protection: Should be worn to prevent breathing dust or heated fumes.

Ventilation: Local exhaust and general ventilation recommended.

Protective Gloves: Suitable protective gloves should be worn to protect against skin contact and to prevent paper cuts.

Eye Protection: Safety glasses or goggles are recommended.

Other Protective Equipment: As required to prevent prolonged or repeated skin contact.

SECTION IX - SPECIAL PRECAUTIONS**Handling and Storage:** -

Avoid prolonged or repeated skin contact. Store in a cool, dry location.

Other Precautions:

Consult Product Bulletin prior to using this product.

SECTION X - SECTION 313 SUPPLIER NOTIFICATION

This product contains the following toxic chemicals subject to the reporting requirements of "Section 313 of the Emergency Planning and Community Right to Know Act" of 1986 (40 CFR 372). This page must remain attached to this MSDS.

<u>CAS #</u>	<u>Chemical Name</u>	<u>Percent by Weight</u>
50-00-0	Formaldehyde	<2.00 %
108-95-2	Phenol	<0.10 %

We can not anticipate all conditions under which this information and our products, the products of other manufactures in combination with our products, may be used. We accept no responsibility for results obtained by the application of this product or the safety and suitability of our products, either alone or in conjunction with other products. Users are advised to make their own determinations, through testing as to the safety and suitability of each product or product combination for their own purposes. Unless otherwise agreed to in writing, we sell the products without warranty. Buyers and users assume all responsibility and liability for loss or damage arising from the handling and use of our products, whether used alone or in conjunction with other products.

This information is provided in accordance with OSHA Hazard Communication Standard 29 CFR 1910.1200.

The information contained herein is based on the data available to us and is believed to be correct. However, Dynol makes no warranty, expressed or implied regarding the accuracy of these data or the results to be obtained therefrom. Dynol assumes no responsibility for injury from the use of the product described herein.

Material Safety Data Sheet

EMERGENCY CONTACTS:

Spills, Leaks, Fire or Exposure Call Chemtrec: (800) 424-9300
Medical Emergency Information: (800) 561-3636

SECTION 1 - CHEMICAL PRODUCT AND COMPANY IDENTIFICATION

Product Name: RUBINATE* 1840

Product Use: Component of a polyurethane.

Company:

ICI Polyurethanes Group (a business unit of ICI Americas Inc.)

286 Mantua Grove Road

West Deptford, NJ 08066-1723

For Polyurethanes product information/assistance:

West Deptford: (800) 257-5547 Sterling Heights: (800) 553-8624 Canadian Office: (905) 678-9150

*RUBINATE is a registered trademark of ICI Americas Inc.

SECTION 2 - COMPOSITION / INFORMATION ON INGREDIENTS

HAZARDOUS INGREDIENT(S)	% (w/w)	ACGIH TLV	CAS NO.
Polymeric Diphenylmethane Diisocyanate (polymeric MDI)	100	Not Listed.	9016-87-9
CONTAINS: 4,4'-Diphenylmethane Diisocyanate (4,4' MDI) (approx. 45%)		0.005 ppm	101-68-8
MDI isomers/oligomers		Not Listed.	9016-87-9

SECTION 3 - HAZARDS IDENTIFICATION

EMERGENCY OVERVIEW

Health Hazards: Irritating to eyes, respiratory system and skin. Risk of serious damage to respiratory system. May cause sensitization by inhalation and skin contact. Repeated inhalation of aerosol at levels above the occupational exposure limit could cause respiratory sensitization. The onset of the respiratory symptoms may be delayed for several hours after exposure. A hyper-reactive response to even minimal concentrations of MDI may develop in sensitized persons.

Physical Hazards: Reacts slowly with water to produce carbon dioxide which may rupture closed containers. This reaction accelerates at higher temperatures.

Appearance: Dark brown viscous liquid.

Odor: Slightly aromatic.

Read the entire MSDS for a more thorough evaluation of the hazards.

SECTION 4 - FIRST AID MEASURES

General: In case of accident or if you feel unwell, seek medical advice IMMEDIATELY (show the label where possible).

Inhalation: Remove patient from exposure, keep warm and at rest. Obtain medical attention. Treatment is symptomatic for primary irritation or bronchospasm. If breathing is labored, oxygen should be administered by qualified personnel. Apply artificial respiration if breathing has ceased or shows signs of failing.

Skin Contact: Remove contaminated clothing. Wash affected areas thoroughly with soap and water. If irritation, redness, or a burning sensation develops and persists, obtain medical advice. Contaminated clothing should be thoroughly cleaned before reuse.

Eye Contact: Immediately flush eyes with running water for a minimum of 15 minutes. Hold eyelids open during flushing. If irritation persists, repeat flushing. Obtain medical attention IMMEDIATELY.

Ingestion: Do NOT induce vomiting. Provided the patient is conscious, wash out mouth with water then give 1 or 2 glasses of water to drink. Refer person to medical personnel for immediate attention.

*** **Note to Physicians:** Symptomatic and supportive therapy as needed. Following severe exposure medical follow-up should be monitored for at least 48 hours.

SECTION 5 - FIRE-FIGHTING MEASURES

Fire and Explosion Hazards: Containers may burst under intense heat. Due to reaction with water, a hazardous build-up of pressure could result if contaminated containers are re-sealed.

Extinguishing Media: Carbon dioxide, dry chemical, or appropriate foam. If water is used, very large quantities are required. Reaction between water and hot isocyanate may be vigorous. Contain run-off water with temporary barriers.

Fire Fighting Procedures: As appropriate for surrounding materials/equipment.

Fire Fighting Protective Equipment: Use self-contained breathing apparatus and full protective clothing (Bunker gear).

Flash Point: 425°F (218°C) (COC)

Flammable Limits (Lower): Not available.

Flammable Limits (Upper): Not available.

Auto Ignition Temperature: 240°C (464°F) (4,4'- Diphenylmethane Diisocyanate)

Decomposition Temperature: Not available.

Rate of Burning: Not available.

Explosive Power: None.

Sensitivity to Mechanical Impact: None.

Sensitivity to Static Discharge: None.

Combustion Products: Carbon monoxide, carbon dioxide, nitrogen oxides and some HCN.

SECTION 6 - ACCIDENTAL RELEASE MEASURES

For major spills call Chemtrec (800-424-9300).

Spills, Leaks, or Releases: Clean-up should only be performed by trained personnel. People dealing with major spillages should wear full protective clothing including respiratory protection. Evacuate the area. Prevent further leakage, spillage or entry into drains.

Contain and absorb large spillages onto an inert, non-flammable adsorbent carrier (such as earth or sand). Shovel into open-top drums or plastic bags for further decontamination, if necessary. Wash the spillage area clean with liquid decontaminant. Test atmosphere for MDI vapor. Neutralize small spillages with decontaminant. Remove and dispose of residues. Notify applicable government authorities if release is reportable.

Preparation of Decontamination Solution: Prepare a decontamination solution of 0.2-0.5% liquid detergent and 3-8% concentrated ammonium hydroxide in water (5-10% sodium carbonate may be substituted for the ammonium hydroxide). Follow the precautions on the supplier's material safety data sheets when preparing and using solution.

Use of Decontamination Solution: Allow deactivated material to stand for at least 30 minutes before shoveling into drums. Do not tighten the bungs. Mixing with wet earth is also effective, but slower.

SECTION 7 - HANDLING AND STORAGE

Handling: Avoid personal contact with the product or reaction mixture. Use only with adequate ventilation to ensure that the defined occupational exposure limit is not exceeded. The efficiency of the ventilation must be monitored regularly because of the possibility of blockage. Avoid breathing aerosols, mists and vapors. When the product is sprayed or heated, an approved MSHA/NIOSH positive-pressure, supplied-air respirator may be required.

Storage Requirements: Keep containers properly sealed and when stored indoors, in a well ventilated area. Keep contents away from moisture. Due to reaction with water, producing CO₂-gas, a hazardous build-up of pressure could result if contaminated containers are re-sealed. Do not store in containers made of copper, copper alloys or galvanized surfaces. If a container is contaminated, do not reseal it. Reseal containers only after placing under a nitrogen blanket.

Storage Temperature: Ideal storage temperature is 16-38°C (60-100°F).

Keep stocks of decontaminant (See Section 6) readily available.

SECTION 8 - EXPOSURE CONTROLS/PERSONAL PROTECTION

PREVENTIVE MEASURES:

Conditions of use, adequacy of engineering or other control measures, and actual exposures will dictate the need for specific protective devices at your workplace.

Engineering Controls: Use local exhaust ventilation to maintain airborne concentrations below the TLV. Suitable respiratory equipment should be used in cases of insufficient ventilation or where operational procedures demand it. Follow guidelines in the ACGIH publication "Industrial Ventilation".

Personal Protective Equipment:

Eye Protection: Chemical safety goggles. If there is a potential for splashing, use a full face shield.

Skin Protection: The following protective materials are recommended:

Gloves - neoprene, nitrile-butadiene rubber, butyl rubber. Thin disposable gloves should be avoided for repeated or long term use.

Protective clothing should be selected and used in accordance with "Guidelines for the Selection of Chemical Protective Clothing" published by ACGIH.

Respiratory Protection: Use a NIOSH/MSHA-approved positive pressure air-supplied respirator equipped with a full facepiece, or an air-supplied hood, if airborne concentrations exceed or are expected to exceed the TLV. Air purifying (cartridge type) respirators are not approved for protection against diisocyanates.

EXPOSURE GUIDELINES:

Medical supervision of all employees who handle or come in contact with respiratory sensitizers is recommended. Persons with asthmatic-type conditions, chronic bronchitis, other chronic respiratory diseases or recurrent skin eczema or sensitization should be excluded from working with this product. Once a person is diagnosed as sensitized, no further exposure to the material that caused the sensitization should be permitted.

HAZARDOUS INGREDIENT(S):

4,4'-Diphenylmethane Diisocyanate:	
ACGIH TLV	0.005 ppm (8-hour, 40 hours/week)
OSHA PEL CEILING	0.02 ppm
NIOSH TLV	0.005 ppm (10-hour, 40 hours/week)
NIOSH STEL	0.02 ppm (15-minute)

NOTE: The Occupational Exposure Limits listed for isocyanates do not apply to previously sensitized individuals.

SECTION 9 - PHYSICAL AND CHEMICAL PROPERTIES

Alternate Name(s): Polymeric MDI

Chemical Name: Not applicable (mixture).

Chemical Family: Diisocyanate.

Molecular Formula: Not applicable (mixture).

Appearance: Dark brown viscous liquid.

Odor: Slightly aromatic.

Odor Threshold (ppm): 0.4 (4,4'-Diphenylmethane Diisocyanate)

pH: Not applicable.

Flash Point: 425°F (218°C) (COC)

Vapor Pressure (mm Hg at 25°C): < 0.0003

Vapor Density (Air=1): 8.5 approx.

Boiling Point: Not applicable.

Melting Point: Not available.

Solubility (Water): (Reacts with water)

Solubility (Other): Soluble in most organic solvents.
Specific Gravity: 1.2
Evaporation Rate: Not available.

SECTION 10 - STABILITY AND REACTIVITY

Hazardous Decomposition Products: Highly unlikely under normal industrial use. See Section 5.
Chemical Stability: Stable at room temperature.
Conditions to Avoid: Avoid high temperatures. Avoid freezing.
Incompatibility with other Substances: This product will react with any materials containing active hydrogens such as water, alcohol, amines, bases and acids. The reaction with water is very slow under 50°C (122°F) but is accelerated at higher temperatures.
Hazardous Polymerization: Polymerization may occur at elevated temperatures in the presence of alkalis, tertiary amines and metal compounds.

SECTION 11 - TOXICOLOGICAL INFORMATION

TOXICOLOGICAL DATA:

Polymeric MDI:

Oral LD50 (rat) > 5,000 mg/kg
Dermal LD50 (rabbit) > 5,000 mg/kg
Inhalation LC50 (rat) = 490 mg/m³/4H (respirable aerosol)

POTENTIAL HEALTH EFFECTS:

Inhalation: This product is a respiratory irritant and potential respiratory sensitizer. Repeated inhalation of vapor or aerosol at levels above the occupational exposure limit could cause respiratory sensitization. Symptoms may include irritation to the eyes, nose, throat and lungs, possibly combined with dryness of the throat, tightness of chest and difficulty in breathing. The onset of the respiratory symptoms may be delayed for several hours after exposure. A hyper-reactive response to even minimal concentrations of MDI may develop in sensitized persons.

Skin Contact: Moderate irritant. Repeated and/or prolonged contact may cause skin sensitization. Animal studies have shown that respiratory sensitization can be induced by skin contact with known respiratory sensitizers including diisocyanates. These results emphasize the need for protective clothing including gloves to be worn at all times when handling these chemicals or in maintenance work.

Eye Contact: The aerosol, vapor or liquid will irritate human eyes following contact.

Ingestion: Ingestion may cause irritation of the gastrointestinal tract. Based on the oral LD50, this product is considered practically non-toxic by ingestion.

Chronic Effects: A study where groups of rats were exposed for 6 hours/day, 5 days/week for a lifetime to atmospheres of respirable polymeric MDI aerosol. Overall, the tumor incidence, both benign and malignant, and the number of animals with tumors were not different from controls. Only at the top level (6 mg/m³), there was a significant incidence of a benign tumor of the lung (adenoma) and one malignant tumor (adenocarcinoma). There were no lung tumors at 1 mg/m³ and no effects at 0.2 mg/m³. The increased incidence of lung tumors is associated with prolonged respiratory irritation and the concurrent accumulation of yellow material in the lung, which occurred throughout the study. In the absence of prolonged exposure to high concentrations leading to chronic irritation and lung damage, it is highly unlikely that tumor formation will occur.

There are reports that chronic exposure may result in permanent decrease in lung function.

Carcinogenicity: The ingredients of this product are not classified as carcinogenic by ACGIH or IARC, not regulated as carcinogens by OSHA, and not listed as carcinogens by NTP.

Mutagenicity: There is no substantial evidence of mutagenic potential.

Reproductive Effects: No adverse reproductive effects are anticipated.

*** **Teratogenicity and Fetotoxicity:** No birth defects were seen in two independent animal (rat) studies. Fetotoxicity was observed at doses that were extremely toxic (including lethal) to the mother. Fetotoxicity was not observed at doses that were not maternally toxic. The doses used in these studies were maximal, respirable concentrations well in excess of the defined occupational limits.

SECTION 12 - ECOLOGICAL INFORMATION

Environmental Fate and Distribution: It is unlikely that significant environmental exposure in the air or water will arise, based on consideration of the production and use of the substance.

Persistence and Degradation: Immiscible with water, but will react with water to produce inert and non-biodegradable solids.

Toxicity: Polymeric MDI.
LC0 (Zebra Fish) > 1000 mg/l
EC50 (Daphnia magna) (24 hour) > 1000 mg/l
EC50 (E. Coli) > 100 mg/l

SECTION 13 - DISPOSAL CONSIDERATIONS

The generation of waste should be avoided or minimized wherever possible.

Disposal should be in accordance with local, state, provincial or national regulations. This material is not a hazardous waste under RCRA 40 CFR 261. Small quantities should be treated with a decontaminant solution (See Section 6). The treated waste is not a hazardous material under RCRA 40 CFR 261. Chemical waste, even small quantities, should never be poured down drains, sewers or waterways.

Empty containers should be decontaminated and either passed to an approved drum recycler or destroyed.

SECTION 14 - TRANSPORT INFORMATION

DOT: Not regulated.

Transportation Emergency Telephone Number: 1-800-424-9300 (CHEMTREC)

TDG: Not regulated.

IMO: Not regulated.

IATA/ICAO Class: Not regulated.

SECTION 15 - REGULATORY INFORMATION

USA CLASSIFICATION:

OSHA Classification:

- Physical: Not regulated.
- Health: Highly toxic. Respiratory sensitizer. Skin sensitizer. Irritant.
- Target Organ: Respiratory tract. Skin.

TSCA (Toxic Substances Control Act) Regulations: All ingredients are on the TSCA Chemical Substance Inventory.

*** EPCRA Section 313 (40 CFR 372): This product contains the following chemical(s) subject to reporting requirements: ~100% Diisocyanate compounds (No CAS number assigned).

This product does not contain nor is it manufactured with ozone depleting substances.

Other Regulations/Legislation which apply to this product:

Massachusetts Right-to-Know, Pennsylvania Right-to-Know, New Jersey Right-to-Know, CERCLA.

CANADIAN CLASSIFICATION:

This product has been classified in accordance with the hazard criteria of the CPR (Controlled Products Regulations) and this MSDS (Material Safety Data Sheet) contains all the information required by the CPR.

Controlled Products Regulations (WHMIS) Classification: D- 1A: Very Toxic (acute effects). D-2A: Very Toxic. D-2B: Toxic.

CEPA / Canadian Domestic Substances List (DSL): The substance(s) in this product is/are on the Canadian Domestic Substances List (CEPA DSL).

SECTION 16 - OTHER INFORMATION

Glossary:	ACGIH -	American Conference of Governmental Industrial Hygienists
	IARC -	International Agency for Research on Cancer
	NTP -	National Toxicology Program
	OSHA -	Occupational Safety and Health Administration

*** FOR YOUR PROTECTION: The information and recommendations in this publication are, to the best of our knowledge, reliable.

The toxicity and risk characteristics of products made by ICI Polyurethanes Group will necessarily differ from the toxicity and risk characteristics that occur when such products are used with other materials during a manufacturing process. The resulting risk characteristics should be determined and made known to ultimate end-users and processors. ICI Polyurethanes Group MAKES NO WARRANTIES OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING THOSE OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

Prepared By: "Polyurethanes Applied Toxicology/Regulatory Services" (609) 423-8518

***This line or section contains revisions or new statements since the last issue date.



IF IT'S BORDEN-IT'S GOT TO BE GOOD

MATERIAL SAFETY DATA SHEET

Borden, Inc.

Packaging and Industrial Products Division

180 EAST BROAD STREET, COLUMBUS, OHIO 43215



Emergency Telephone (614) 431-6600

THE OSHA HAZARD COMMUNICATION STANDARD 29 CFR 1910.1200 REQUIRES THAT THE INFORMATION CONTAINED ON THESE SHEETS BE MADE AVAILABLE TO YOUR WORKERS INSTRUCT YOUR WORKERS TO HANDLE THIS PRODUCT PROPERLY. FOR INDUSTRIAL USE ONLY

LOUISIANA-PACIFIC CORP
ATTN: KURT CHAMBERLAIN
461 MILLER STREET
NEWBERRY, MI 49868

NON-EMERGENCY TELEPHONE
(503) 746-8461

DESCRIPTION: CASCOPHEN OS57H
PRODUCT TYPE: LIQUID PF RESIN
APPLICATION: ORIENTED STRANDBOARD FACE RESIN

PAGE 1
CUR ISS 18-OCT-93

SIGNAL WORD
WARNING!

This material is a "health hazard" and/or a "physical hazard" as determined when reviewed according to the requirements of the Occupational Safety and Health Administration 29 CFR Part 1910.1200 "Hazard Communication" Standard.

CHEMICAL HAZARD RATING
HEALTH=3(high)
FIRE=0(least)
REACTIVITY=1(slight)
CHRONIC=*

29CFR1910.1200 HAZARDOUS INGREDIENTS/REPORTED HEALTH EFFECTS

CAS/REGISTRY NO. MATERIAL DESCRIPTION % RANGE

The ingredients listed below have been associated with one or more of the listed immediate and/or delayed(*) health hazards. Risk of damage and effects depends upon duration and level of exposure. BEFORE USING OR HANDLING, READ AND UNDERSTAND THE MSDS.

50-00-0 *FORMALDEHYDE
NOTE REVISED OSHA PEL

< 0.1

POTENTIAL CANCER HAZARD.
Rats chronically exposed to 14 ppm formaldehyde contracted nasal cancers. Based on animal data and limited epidemiological evidence, NTP and IARC have listed formaldehyde as a probable human carcinogen. OSHA regulates formaldehyde as a potential human carcinogen.

May cause allergic skin reaction. Some reports suggest that formaldehyde may cause respiratory sensitization, such as asthma, and that pre-existing respiratory and skin disorders may be

82



IF IT'S BORDEN-IT'S GOT TO BE GOOD

MATERIAL SAFETY DATA SHEET

Emergency Telephone
(614) 431-6600

Borden, Inc.

Packaging and Industrial Products Division

180 EAST BROAD STREET, COLUMBUS, OHIO 43215

PAGE 2

CUR ISS 18-OCT-93

DESCRIPTION: CASCOPHEN 0S57H
PRODUCT TYPE: LIQUID PF RESIN
APPLICATION: ORIENTED STRANDBOARD FACE RESIN

=====

29CFR1910.1200 HAZARDOUS INGREDIENTS/REPORTED HEALTH EFFECTS

CAS/REGISTRY NO.	MATERIAL DESCRIPTION	% RANGE
------------------	----------------------	---------

=====

aggravated by exposure.

OSHA has identified 0.5 ppm as the "Action Level", 29CFR 1910.1048. Please refer to the OSHA Standard for guidance applicable to your specific operations.

OSHA has stated that a concentration of 100 ppm is immediately dangerous to life and health and that the odor threshold for formaldehyde is 0.8-1 ppm, OSHA Occupational Exposure to Formaldehyde, 59 Fed. Reg. 22290, et seq.

ACGIH TLV: 0.3 PPM (0.37 MG/M3) CEILING
OSHA PEL: 0.75 PPM(0.9 MG/M3) TWA; 2 PPM(2.5MG/M3)15MIN STEL
NIOSH DOCUMENT NUMBER: 77-126

=====

PHYSICAL DATA

FORM. FREE PF WAMTA11.1	<0.1%
PHENOL FREE, GC (OCF)	<0.5%
STG. LIFE	2 WEEKS @ 21C (70F)
PH @ 25C	~11.07
APPEARANCE	CLEAR LIQUID
COLOR	REDDISH BROWN
ODOR	SLIGHT AROMATIC
BOILING POINT	~102C
EVAPORATION RATE	~0.4 (N-BUTYL ACETATE=1)
FLASH POINT	NOT APPLICABLE
FREEZING POINT	<0C
AUTOIGNITION TEMPERATURE	NOT APPLICABLE
LOWER EXPLOSION LIMIT	NOT APPLICABLE
PERCENT VOLATILE BY WEIGHT	~43% @ 105C
SOLUBILITY IN WATER	INFINITE
SPECIFIC GRAVITY	~1.2
UPPER EXPLOSION LIMIT	NOT APPLICABLE
VAPOR DENSITY	NOT APPLICABLE
VAPOR PRESSURE	~50MM HG @ 21C

=====

IMMEDIATE HEALTH HAZARD DATA

SKIN ABSORPTION: No hazards known to Borden.
INGESTION: No hazards known to Borden.
INHALATION: Not expected to be harmful under normal conditions of use. However, if allowed to become airborne, may cause irritation of nose, throat and lungs. A similar product was found to be non-toxic by inhalation when tested as described in 16 CFR Part 1500.3 (c) (1) and (2).

=====

83

READ NEXT PAGE



MATERIAL SAFETY DATA SHEET

Emergency Telephone (614) 431-6600

Borden, Inc.

Packaging and Industrial Products Division

180 EAST BROAD STREET, COLUMBUS, OHIO 43215

IF ITS BORDEN-ITS GOT TO BE GOOD

DESCRIPTION: CASCOPHEN OS57H
PRODUCT TYPE: LIQUID PF RESIN
APPLICATION: ORIENTED STRANDBOARD FACE RESIN

PAGE 3
CUR ISS 18-OCT-93

IMMEDIATE HEALTH HAZARD DATA

SKIN: May cause irritation on prolonged or repeated contact. A similar product was not a primary irritant (primary skin irritation index less than 5.0/8.0) when tested as described in 16 CFR Part 1500.41.
EYES: Causes chemical burns. A similar product was severely irritating when tested as described in 16 CFR Part 1500.42.

HANDLING PRECAUTIONS

INHALATION: Avoid prolonged or repeated breathing of vapor.
SKIN: Avoid prolonged or repeated contact with skin.
EYES: Do not get in eyes.
Handle in accordance with good industrial hygiene and safety practices. These practices include avoiding unnecessary exposure and removal of the material from eyes, skin and clothing.
Wash thoroughly after handling.

EMERGENCY AND FIRST AID PROCEDURES

INGESTION: If accidentally swallowed, dilute by drinking large quantities of water. Immediately contact poison control center or hospital emergency room for any other additional treatment directions.
INHALATION: Remove to fresh air.
SKIN CONTACT: In case of irritation, flush with water.
EYE CONTACT: Immediately flush eyes with plenty of water for at least 15 minutes. Eyelids should be held apart during irrigation to insure water contact with entire surface of eyes and lids. Call a physician.

FIRE AND EXPLOSION HAZARD DATA

Will not burn unless water has evaporated.
In case of fire, water should be used to keep fire-exposed containers cool.

REACTIVITY DATA

Normally stable, but may become unstable at high temperatures or may react with water.
Hazardous polymerization:
May occur.
Incompatibilities:
Oxidizers, acids.
Decomposition products may include:
CO, CO2, aldehydes (including formaldehyde), particulate matter and other organic compounds.

84



IF IT'S BORDEN-IT'S GOT TO BE GOOD

MATERIAL SAFETY DATA SHEET

Borden, Inc.
Packaging and Industrial Products Division
180 EAST BROAD STREET, COLUMBUS, OHIO 43215

Emergency Telephone
(614) 431-6600

PAGE 4
CUR ISS 18-OCT-93

DESCRIPTION: CASCOPHEN 0S57H
PRODUCT TYPE: LIQUID PF RESIN
APPLICATION: ORIENTED STRANDBOARD FACE RESIN

CONTROL MEASURES

If airborne contaminants are generated when the material is heated or handled, sufficient ventilation in volume and air flow patterns should be provided to keep air contaminant concentration levels below acceptable criteria.

ENGINEERING CONTROLS: The following exposure control techniques may be used to effectively minimize employee exposure: local exhaust ventilation, enclosed system design, process isolation and remote control in combination with appropriate use of personal protective equipment and prudent work practices. These techniques may not necessarily address all issues pertaining to your operations. We, therefore, recommend that you consult with experts of your choice to determine whether or not your programs are adequate.

PERSONAL PROTECTION INFORMATION

Use goggles if contact is likely.
Wear impervious gloves as required to prevent skin contact.

SPILL OR LEAK PROCEDURES

Large quantities: Enclose with diking material to prevent seepage into natural bodies of water, then consult Borden, Inc.
Small quantities: Soak up with absorbent material and remove to a chemical disposal area.

WASTE DISPOSAL

Recover free liquid. Absorb residue and dispose of according to local, state/provincial, and federal requirements.

STORAGE PRECAUTIONS

Store at 70 F or lower. Keep tightly closed.

TRANSPORT INFORMATION

REFER TO YOUR BILL OF LADING FOR PROPER DOT DESCRIPTION

040 45-0S57H-. PREVIOUS ISSUE:
PRINT DATE: 16-Dec-93 10:58 AM

CURRENT ISSUE:18-OCT-93

THIS IS THE LAST PAGE

85



IF IT'S BORDEN-IT'S GOT TO BE GOOD

MATERIAL SAFETY DATA SHEET

Borden, Inc.

Packaging and Industrial Products Division

180 EAST BROAD STREET, COLUMBUS, OHIO 43215

Emergency Telephone
(614) 431-6600

SARA TITLE III SECTION 313 AND 40 CFR Part 372 TOXIC CHEMICAL NOTIFICATION SHEET

CASCOPHEN 0957H

This product contains the following toxic chemical(s) subject to the reporting requirements of Section 313 of Title III of the Superfund Amendments and Reauthorization Act of 1986, and Subpart C-Supplier Notification Requirement of 40 CFR Part 372.

CAS Registry Number	Chemical Name	Pct. By Weight
---------------------	---------------	----------------

None required per SARA TITLE III SECTION 313

This Toxic Chemical Notification Sheet must not be detached from the Material Safety Data Sheet (MSDS). Any copying and redistribution of the MSDS shall include copying and redistribution of this notification sheet attached to copies of the MSDS subsequently redistributed.

040 45-0957H-

PRINT DATE: 16-Dec-93 10:58 AM

86



MATERIAL SAFETY DATA SHEET

USBORAX

EFFECTIVE DATE: May 1, 1993
Supersedes October 1991 Version

1 CHEMICAL PRODUCT AND COMPANY IDENTIFICATION

Product Name: BOROGARD ZB
 Grades: Regular, Fine
 Chemical Formula: $2ZnO \cdot 3B_2O_3 \cdot 3.5H_2O$
 Chemical Name/Synonyms: Zinc Borate 2335
 Chemical Family: Inorganic Borates
 CAS Registry Number: 138265-88-0 (or 12447-61-9)
 TSCA Inventory Number: 1332-07-6 (anhydrous form)

MANUFACTURER: U.S. Borax Inc.*
 26877 Toumey Rd.
 Valencia, CA 91355
 *Formerly United States Borax & Chemical Corporation

EMERGENCY PHONE NUMBERS:
 24 Hour Info. Service: (800) 228-5635 EXT. 144
 CHEMTREC: (800) 424-9300

BOROGARD is a registered trademark of U.S. Borax Inc.

2 COMPOSITION/INFORMATION ON INGREDIENTS, OSHA HAZARDS

This product contains greater than 99 percent (%) Zinc Borate ($2ZnO \cdot 3B_2O_3 \cdot 3.5H_2O$) CAS No. 138265-88-0. There are no studies of Zinc Borate indicating that this compound is hazardous under the OSHA Hazard Communication Standard.

However, animal chronic toxicity studies of Boric Acid and Zinc trigger requirements of the OSHA Hazard Communication Standard.

3 HAZARD IDENTIFICATION

EMERGENCY OVERVIEW:

Zinc Borate is a white odorless, powdered substance that is not flammable, combustible, or explosive, and it presents no unusual hazard if involved in a fire. Zinc Borate presents little or no hazard (to humans) and has low acute oral and dermal toxicities. Care should be taken to minimize the amount of Zinc Borate released to the environment to avoid ecological effects.

POTENTIAL ECOLOGICAL EFFECTS:

Large amounts of Zinc Borate can be harmful to boron-sensitive plants and other ecological systems.

POTENTIAL HEALTH EFFECTS:

Routes of Exposure: Inhalation is the most significant route of exposure in occupational and other settings. Dermal exposure is not usually a concern because Zinc Borate is not absorbed through intact skin.

Inhalation: Irritation effects may occur from inhalation of Zinc Borate dusts at levels greater than 10 mg/m³.

Eye Contact: Zinc Borate is non-irritating to eyes in normal industrial use.

Skin Contact: Zinc Borate does not cause irritation to intact skin.

Ingestion: Products containing Zinc Borate are not intended for ingestion. Zinc Borate has a relatively low acute toxicity. Small amounts (e.g. a teaspoonful) swallowed accidentally are not likely to cause effects; swallowing amounts larger than that may cause gastrointestinal symptoms.

Cancer: Zinc Borate has not been tested for carcinogenicity.
Reproductive: Zinc Borate has not been tested for reproductive toxicity. Animal studies of Boric Acid have demonstrated reproductive effects in male animals; a human study of occupational exposure to borate dust showed no adverse effect to reproduction.

Developmental: Zinc Borate has not been tested for developmental toxicity. Animal feeding studies with Boric Acid, and similar studies with Zinc compounds, have both demonstrated effects.

Target Organs: No target organ has been identified in humans.

Signs and Symptoms of Exposure: Symptoms of accidental over-exposure to Zinc Borate may be similar to those observed from borate or zinc products. These may include nausea, vomiting, and diarrhea, with delayed effects of skin redness and peeling.

Refer to Section 11 for details on Toxicological Data.

4 FIRST AID MEASURES

Inhalation: No specific treatment is necessary since Zinc Borate is not likely to be hazardous by inhalation. Prolonged exposure to dust levels in excess of regulatory limits should always be avoided.

Eye Contact: Use eye wash fountain or fresh water to cleanse eye. If irritation persists for more than 30 minutes, seek medical attention.

Skin Contact: No treatment necessary because non-irritating.

Ingestion: Swallowing less than one teaspoon will cause no harm to healthy adults. If larger amounts are swallowed, give two glasses of water to drink and seek medical attention.

NOTE TO PHYSICIANS: Observation only is required for adult ingestion of a few grams of Zinc Borate. For ingestion in excess of a few grams, maintain adequate kidney function and force fluids. Gastric lavage is recommended for symptomatic patients only. Hemodialysis should be reserved for massive acute ingestion or patients with renal failure. Boron analyses of urine or blood are only useful for documenting exposure and should not be used to evaluate severity of poisoning or to guide treatment. (Further Information: Litovitz T.L., Norman, S.A., Veltri, J. C., Annual Report of the American Association of Poison Control Centers Data Collection System. Am. J. Emerg. Med. 1986; 4:427-458). 24 hour Medical consultation is available at (800) 228-5635 EXT. 144.

5 FIRE-FIGHTING MEASURES

General Hazard: None, because Zinc Borate is not flammable, combustible or explosive. The product is itself a flame retardant.

Extinguishing Media: Any fire extinguishing media may be used on nearby fires.

Flammability Classification (29 CFR 1910.1200):
Non-flammable solid.

6 ACCIDENTAL RELEASE MEASURES

General: Zinc Borate is a slightly soluble white powder that may cause damage to trees or vegetation by root absorption. (Refer to Ecological Information Section 12 for specific information).

Land Spill: Vacuum, shovel or sweep up Zinc Borate and place in containers for disposal in accordance with applicable local regulations. Avoid contamination of water bodies during clean up and disposal. No personal protective equipment is needed to clean up land spills.

Water Spill: Zinc Borate will cause localized contamination

of surrounding waters depending on the quantity dissolved in these waters. At high concentrations some damage to local vegetation, fish and other aquatic life may be expected. (Refer to Sections 12, 13 and 15 for additional information).

Zinc Borate is a non-hazardous waste when spilled or disposed of, as defined in the Resource Conservation and Recovery Act (RCRA) regulations (40 CFR 261). (Refer to Regulatory Information Section 15 for additional references and information regarding EPA and California regulations.)

7 HANDLING AND STORAGE

Storage Temperature: Ambient

Storage Pressure: Atmospheric

Special Sensitivity: Moisture (Caking)

General: No special handling precautions are required, but dry, indoor storage is recommended. To maintain package integrity and to minimize caking of the product, bags should be handled on a "first-in first-out" basis. Good housekeeping procedures should be followed to minimize dust generation and accumulation.

8 EXPOSURE CONTROLS/PERSONAL PROTECTION

Engineering Controls: Use local exhaust ventilation to keep airborne concentrations of Zinc Borate dust below permissible exposure levels.

Personal Protection: Where airborne concentrations are expected to exceed exposure limits, NIOSH/MSHA certified respirators must be used. Eye goggles and gloves are not required for normal industrial exposures, but may be warranted if environment is excessively dusty.

Occupational Exposure Limits:

Zinc Borate is listed/regulated by OSHA, Cal OSHA and ACGIH as "Particulate Not Otherwise Classified" or "Nuisance Dust."

OSHA: PEL* - 15 mg/m³ total dust and
- 5 mg/m³ respirable dust
ACGIH: TLV** - 10 mg/m³
Cal OSHA: PEL* - 10 mg/m³

*PEL = "Permissible Exposure Limit"

** TLV = "Threshold Limit Value"

9 PHYSICAL AND CHEMICAL PROPERTIES

Appearance: White, odorless powder
Specific Gravity: 2.7
Vapor Pressure: Negligible @ 20°C
Solubility in Water: 0.3% @ 24°C
Melting Point: Phase change @ 650°C (1202°F)

Viscosity: Not applicable
Boiling Point: Not applicable
Flash Point: None
Formula Weight: 434.66

10 STABILITY AND REACTIVITY

General: Zinc Borate is a stable product.
Incompatible Materials and Conditions to Avoid:
Reaction with strong reducing agents such as metal hydrides

or alkali metals will generate hydrogen gas which could create an explosive hazard.

Hazardous Decomposition: None

88

11

TOXICOLOGICAL INFORMATION

INGESTION (ACUTE ORAL TOXICITY): Low acute oral toxicity; LD₅₀ of Zinc Borate in rats is greater than 10000 mg/kg of body weight.

SKIN (ACUTE DERMAL TOXICITY): Low acute dermal toxicity; LD₅₀ of Zinc Borate in rabbits is greater than 10000 mg/kg of body weight. Zinc Borate is not absorbed through intact skin.

PRIMARY SKIN IRRITATION INDEX: 0 (zero). Zinc Borate is non-corrosive.

EYE: Draize test in rabbits produces mild eye irritation effects. Many years of occupational exposure history reflect no indication of human eye injury from exposure to Zinc Borate.

DERMAL SENSITIZATION: Zinc Borate is not a sensitizer, based on a delayed contact hypersensitivity study in guinea pigs.

NOTE: Zinc Borate can decompose, under biological conditions, to form Zinc Hydroxide and Boric Acid. While there are no chronic toxicity studies of Zinc Borate, the following information is derived from chronic studies of Zinc compounds or Boric Acid.

INHALATION: No data is available on inhalation effects of Zinc Borate dust. Human occupational studies show no increase in pulmonary disease with chronic exposure to Sodium Borate dust.

Inhalation studies of Zinc Oxide dust show some pulmonary damage in both humans and animals.

CARCINOGENICITY: Zinc Borate has not been tested for carcinogenic activity. Carcinogenicity and mutagenicity tests were negative for Boric Acid. Limited epidemiology studies have shown no relationship between cancer in humans and occupational exposure to Zinc compounds.

REPRODUCTIVE TOXICITY (FERTILITY): No data is available on the potential reproductive toxicity of Zinc Borates. Animal studies indicate that Boric Acid reduces sperm production and causes testicular atrophy. These animal feeding studies were conducted under chronic exposure conditions at doses well above those that occur through inhalation of dust in occupational settings.

DEVELOPMENTAL TOXICITY: No studies are reported on the potential developmental toxicity of Zinc Borates. Animal feedings studies of Boric Acid in mice, rats, and rabbits have shown reductions in fetal weight and increased skeletal malformations, with the lowest observed adverse effect level at 78 mg/kg/day of Boric Acid in the rat study. Animal studies have also demonstrated developmental toxicity due to excess zinc levels, including increased fetal resorption and reduced fetal weights.

12

ECOLOGICAL INFORMATION

ECOTOXICITY DATA:

Phytotoxicity: Zinc Borate can decompose, under certain environmental conditions, to form Zinc hydroxide and Boric Acid. Boric Acid is known to be harmful to plants at high exposure levels. Care should be taken to minimize the amount of Zinc Borate product released to the environment.

Fish Toxicity: Zinc Borate toxicity to fish varies considerably among fish species. In a laboratory study the acute toxicity (96-hr LC₅₀) for Rainbow Trout (*Salmo gairdneri*) was determined to be 2.4 mg/L. In a similar study, the same 96-hr LC₅₀ acute toxicity value for Bluegill (*Lepomis macrochirus*) was determined to be greater than 335 mg/L.

Invertebrate Toxicity: The acute toxicity (48-hour LC₅₀) of Zinc Borate to Daphnids (*Daphnia magna* Straus) is 76 mg/L.

ENVIRONMENTAL FATE DATA:

Persistence/Degradation: Under certain environmental conditions, Zinc Borate will slowly hydrolyze to form other inorganic chemicals such as Zinc Hydroxide and Boric Acid.

Soil Mobility: The product is partially soluble in water and may be leachable through certain soils depending on pH conditions.

13

DISPOSAL CONSIDERATIONS

Disposal Guidance: Small quantities of Zinc Borate can usually be disposed of at Municipal Landfill sites. No special disposal treatment is required, but refer to state and local regulations for applicable site-specific requirements. Tonnage quantities of product are not recommended to be sent to landfills. Such product should, if possible, be re-used for an appropriate application.

RCRA (40 CFR 261): Zinc Borate is not listed under any sections of the Federal Resource Conservation and Recovery Act (RCRA).

California Hazardous Waste Designation: Zinc Borate waste material is considered a "hazardous waste" in the State of California because it is a zinc compound with a zinc concentration exceeding the total threshold limit concentration (TTLC) of 5000 mg/kg. (CCR Title 22 § 66261.24) Refer to Section 15 for additional regulatory information.

89

14

TRANSPORT INFORMATION

DOT Hazardous Material Classification: Zinc Borate is not a U.S. Department of Transportation (DOT) Hazardous Material.

DOT Hazardous Substances Classification: Zinc Borate is classified by DOT as a Hazardous Substance with a reportable quantity (RQ) of 1000 lbs (454kg), 49 CFR 172.1011 (c) (9), Table 1.

International Transportation: Zinc Borate has no U.N. Number, and is not regulated under international rail, highway, water or air transport regulations. However, Zinc Borate does have a reportable quantity (RQ) of 1,000 pounds (454 kg), which should always be included in the bill of lading.

15

REGULATORY INFORMATION

TSCA No.: Zinc Borate appears on the EPA TSCA inventory list under the CAS No. 1332-07-6, which represents the anhydrous form of this inorganic salt.

RCRA: Zinc Borate is not listed as a hazardous waste under any sections of the Resource Conservation and Recovery Act or regulations (40 CFR 261 et seq.).

Superfund: CERCLA/SARA. Zinc Borate 2335 is not listed under CERCLA (the Comprehensive Environmental Response Compensation and Liability Act). Zinc Borate appears on the SARA (the Superfund Amendments and Reauthorization Act) Section 313 Toxic Chemical Release Inventory under Zinc compounds, 42 USC 11023, 40 CFR 372.65. Zinc Borate is not listed under Section 302 of SARA, Extremely Hazardous Substances, 42 USC 11002, 40 CFR 9604, 40 CFR 302.

Safe Drinking Water Act: Zinc Borate is not regulated under the SDWA, 42 USC 300g-1, 40 CFR 141 et seq. Consult state and local regulations for possible water quality advisories regarding boron.

Clean Water Act (Federal Water Pollution Control Act): 33 USC 1251 et seq.

(a) Zinc Borate is not itself a discharge covered by any water quality criteria of Section 304 of the CWA, 33 USC 1314.

(b) It is not on the Section 307 List of Priority Pollutants, 33 USC 1317, 40 CFR 129.

(c) It is on the Section 311 List of Hazardous Substances, 33 USC 1321, 40 CFR 116.

OSHA/Cal OSHA: This MSDS document meets the requirements of both OSHA (29 CFR 1910.1200) and Cal OSHA (Title 8 CCR 5194(g)) hazard communication standards. Refer to Section 8 for regulatory exposure limits.

IARC: The International Agency for Research on Cancer (of the World Health Organization) does not list or categorize Zinc Borate as a carcinogen.

NTP Annual Report on Carcinogens: Zinc Borate is not listed.

OSHA Carcinogen: Zinc Borate is not listed.

California Proposition 65: Zinc Borate is not listed on any Proposition 65 lists of carcinogens or reproductive toxicants.

CONEG Model Legislation: Zinc Borate meets all the CONEG requirements relating to heavy metal limitations on components of packaging materials.

Clean Air Act: Zinc Borate was not manufactured with and does not contain any Class I or Class II ozone depleting substances, as defined by EPA.

16

OTHER INFORMATION

Product Label Text Hazard Information:

- May be harmful if swallowed.
- May cause reproductive harm or birth defects based on animal data.
- Avoid contamination of food or feed.
- Not for food, drug or pesticidal use.
- Refer to MSDS.
- KEEP OUT OF REACH OF CHILDREN.

National Fire Protection Association (NFPA) Classification:

Health	0
Flammability	0
Reactivity	0

Hazardous Materials Information Systems (HMIS):

Red: (Flammability)	0
Yellow: (Reactivity)	0
Blue: (Acute Health)	0*

* Chronic Effects


**Contact U.S. Borax Inc.
Occupational Health &
Product Safety Department
for further information:**

(805) 287-6050

90

APPENDIX J

PROCEDURES



Particulate Loading and Emission Rates

The particulate emission rates were determined per EPA Methods 1 - 5, CFR Title 40, Part 60, Appendix A (revised July 1, 1995). In this procedure a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass-lined sampling probe equipped with a Type S pitot and a thermocouple. The probe is attached to a sampling module which houses the all-glass in line filter holder in a temperature controlled oven. The sampling module also houses the impinger case and a Drierite filled column. The sampling module is connected by means of an umbilical cord to the control module. The control module houses the dry test gas meter, the calibrated orifice, a leakless pump, two inclined manometers, and all controls required for operating the sampling train.

Particulate samples are collected as follows: The sample gas is drawn through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter where particulates are removed. The sample gas is then passed through an ice-cooled impinger train and a desiccant-packed column which absorbs remaining moisture. The sample gas then passes through a vacuum pump followed by a dry test gas meter. The gas meter integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gasmeter provides real time flow rate data.

A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each test point maintaining isokinetic sampling conditions. Nomographs are used for rapid determination of the sampling rate.

Particulate Loading and Emission Rates

After sampling is complete, the filter is removed and placed in a clean container. The nozzle and inlet side of the filter holder are quantitatively washed with acetone and the washings are stored in a second container. A brush is often used in the cleaning step to help dislodge deposits. The samples are returned to the laboratory where they are logged in and analyzed. The volume of the acetone rinse ("probe wash") is noted and then the rinse is quantitatively transferred to a tared 120 cc porcelain evaporating dish and the acetone evaporated off at 97-105 °F. This temperature is used to prevent condensation of atmospheric moisture due to the cooling effect induced by the evaporation of acetone. The acetone-free sample is then transferred to an oven and dried at 105 °C for 30 minutes, cooled in a desiccator over Drierite, and then weighed to the nearest .01 mg. The filter sample is quantitatively transferred to a 6-inch watch glass and dried in an oven at 105 °C for two hours. The filter and watch glass are then cooled in a desiccator and the filter weighed to the nearest .01 mg. All weighings are performed in a balance room where the relative humidity is hydrostated to less than 50% relative humidity. Microscopic examination of the samples is performed if any unusual characteristics are observed. The weight of the acetone rinse is corrected for the acetone blank. The Drierite column is weighed on-site and the water collected by Drierite is added to the condensate so that the total amount of absorbed water may be ascertained.

Integrated flue gas samples for Orsat analysis were collected simultaneously with each pollutant sample. The samples were collected in 15-liter gas sampling bags at a constant flow rate throughout each particulate run. The bags were at a constant flow rate throughout each particulate run. The bags were then returned to the laboratory and analyzed by Orsat analysis. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen).

**ENVIRONMENTAL PROTECTION
AGENCY**

40 CFR Part 51

[AD-FRL-3977-4]

**Preparation, Adoption, and Submittal
of State Implementation Plans, Method
for Measurement of Condensible
Particulate Emissions From Stationary
Sources**

AGENCY: Environmental Protection
Agency (EPA).

ACTION: Final rule.

SUMMARY: Method 202 for the measurement of condensible particulate matter (CPM) was proposed in the Federal Register on October 12, 1990, at (55 FR 41546). This action promulgates this method. On April 17, 1990 at (55 FR 14246) EPA promulgated two methods for measuring particulate matter (PM) with an aerodynamic diameter of 10 μm or less (PM₁₀). Since CPM emissions form very fine particles in the PM₁₀ size range and are considered PM₁₀ emissions, the Agency is adding a method for measuring CPM emissions from stationary sources to appendix M in 40 CFR part 51. The purpose of this

rule is to provide the States with a method for measuring CPM.

EFFECTIVE DATE: December 17, 1991.

ADDRESSES: Background Information Document. The Background Information Document for the promulgated test methods may be obtained from Candace Sorrell or Peter Westlin, MD-19, U.S. EPA, Research Triangle Park, North Carolina 27711, telephone number (919) 341-1064. Please refer to "Summary of Comments and Responses for Method 202."

Docket, Docket No. A-90-03, containing materials relevant to this rulemaking, is available for public inspection and copying between 8:30 a.m. to 12 Noon and 1:30 to 3:30 p.m., Monday through Friday, at EPA's Air Docket Section, Waterside Mall, room M1500, 1st Floor, Gallery 1, 401 M Street SW., Washington, DC 20460. A reasonable fee may be charged for copying.

FOR FURTHER INFORMATION CONTACT: Candace Sorrell or Peter Westlin, Emission Measurement Branch (MD-19), Technical Support Division, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina 27711, telephone number (919) 541-1064.

SUPPLEMENTARY INFORMATION:

I. The Rulemaking

The EPA is proposing to add a method for measuring CPM emissions to appendix M in 40 CFR part 51 to provide a method that States can use in their State implementation plans.

II. Public Participation

The opportunity to hold a public hearing on November 2, 1990 at 10 a.m. was presented in the proposal notice, but no one desired to make an oral presentation. The public comment period was from October 12, 1990 to December 17, 1990.

III. Significant Comments and Changes to the Proposed Rulemaking

Six comment letters were received from the proposal rulemaking. A detailed discussion of these comments is contained in the background document entitled "Summary of Comments and Responses for Method 202" which is referred to in the ADDRESSES section of this preamble. The major comments raised in these letters and the Agency's responses follow.

One commenter suggests that EPA determine the chemical composition of the material collected in the sampling train to verify that it will form ambient condensibles.

The EPA believes that material will collect in the impingers only by

condensation or dissolution. Dissolved gases will evaporate during analysis and will not be measured unless the gases react to form a solid or liquid while they are in solution. The EPA has designed Method 202 to prevent the formation of reaction materials from dissolved gases. The EPA believes that any remaining material collected and measured by Method 202 represents the material that would condense in the ambient air. Additional analysis of chemical composition is not necessary.

Another comment raises the concern that the method may collect some portion of the sulfur dioxide (SO₂) as condensible.

The dissolution of SO₂ in water does not lead immediately to the formation of sulfuric acid (H₂SO₄), but tends to lower the solution pH, which further inhibits sulfate or H₂SO₄ formation. The method includes a purging procedure which effectively removes SO₂ before significant oxidation occurs. No additional revisions are necessary.

The commenter feels that if EPA is allowing Method 202 to be used in conjunction with Method 201 or 201A or another dry catch procedure to determine the total PM₁₀ measurement, the combined methods should be tested for precision.

The imprecision associated with combining Method 202 with Method 201 or 201A or any other dry catch procedure is not additive because each train provides a separate measurement. Since the total precision associated with the combined methods cannot be larger than the least precise sampling method, a precision evaluation of a combined sampling system is unnecessary.

A commenter suggests that EPA add specific language to the applicability section of the method stating that Method 202 cannot be used on wet sources. He notes that Method 17 is excluded from use on wet sources, and Methods 201 and 201A are not recommended for wet sources.

The EPA agrees that Method 202 with an in-stack filter is not recommended for wet sources, and such a statement has been added to the applicability. However, a heated Method 5 filter could be used in Method 202 instead of the in-stack filter which would allow application to wet sources.

One commenter requests that EPA clearly state that Method 202 should not be used for assessing compliance with emission limits set on the basis of data derived from a different measurement approach.

The EPA agrees that a violation must be shown, in the first instance, by means of measurements made with the

applicable test method. Once such a showing is made, however, section 113(e) of the Clean Air Act allows the Agency to rely on any credible evidence, including evidence other than the applicable test method, to establish the duration of the period of noncompliance for the purposes of assessing a penalty.

A commenter believes that the sample collection efficiency and method precision may be affected by the sampling conditions such as impinger temperature and sampling flow rate and the method should address this possibility.

The EPA agrees that the nature of the material in the sample gas may affect collection efficiency. For example, a field demonstration of Method 202 at an oil-fired boiler resulted in about 75 percent impinger collection efficiency. This collection efficiency can be improved with the addition of a second filter place between the second and third impinger. This option has been included in the method with a discussion of applicability.

The commenter feels the 1-hour nitrogen (N₂) purge is too long. He believes the majority of the SO₂ is removed in the first few minutes. He suggests the method be revised to reduce the purge time in conjunction with maintaining the sample under cold conditions and analyzing it within 48 hours.

The EPA does not agree with reducing the purge time. Laboratory tests have shown that a 1-hour purge time is necessary to ensure the adequate removal of SO₂ from the impinger solution.

Another commenter suggests that the method should be revised to give credit for ammonium sulfate ((NH₄)₂SO₄) dihydrate and other condensible particulate matter formed in the gas stream due to ammonia (NH₃) injection used to enhance the efficiency of a control device.

The EPA does not agree. The condensible particulate matter formed in the gas stream due to NH₃ injection is emitted to the atmosphere. The EPA believes that condensible particulate matter emitted from the source should be counted as such even if it is a product of a pollution-control technique.

The commenter suggests that EPA consider an alternative to MeCl₂ consistent with the Montreal Protocol.

The EPA investigated the effectiveness of a chloroform-ether extraction during the method development phase. The chloroform-ether was not as effective as the MeCl₂ in removing organic materials; however, the chloroform-ether procedure was

found to be acceptable for organic extraction. The method has been revised to allow a chloroform-ether extraction.

The commenter supports the exclusion of ammonium chloride as a condensible; however, he expresses concern about $(\text{NH}_4)_2\text{SO}_4$ forming in the impingers.

The N_2 purge removes SO_2 before significant oxidation occurs. If NH_3 is present in the flue gas, the $(\text{NH}_4)_2\text{SO}_4$ formed in the impingers would not be counted as a condensible, although the H_2SO_4 , which reacted with NH_3 , would be counted as a condensible. Method 202 corrects for the NH_3 by measuring the sulfate using an IC analysis and subtracting out the ammonium ion (NH_4^+) mass.

The commenter agrees that the NH_3 added during the titration should be subtracted from the final weight. However, he does not agree with adding back in the water removed by the acid-base reaction.

Because H_2SO_4 is hygroscopic, the H_2SO_4 mass found in the atmosphere would have the water attached to it. The method has been revised to allow the source to correct for only the NH_4^+ or for both NH_4^+ and water as an option depending on the basis for the regulation.

A. Docket

The docket is an organized and complete file of all the information submitted to or otherwise considered by EPA in the development of this proposed rulemaking. The principle purposes of the docket are to: (1) Allow interested parties to identify and locate documents so that they can effectively participate in the rulemaking process, and (2) serve as the record in case of judicial review except for interagency review materials (Section 307(d)(7)(A)).

B. Office of Management and Budget Review

Under Executive Order 12291, EPA must judge whether a regulation is "major" and, therefore, subject to the requirement of a regulatory impact analysis. This rulemaking would not result in any of the adverse economic effects set forth in Section 1 of the Order as grounds for finding a "major rule." It will neither have an annual effect on the economy of \$100 million or more, nor will it result in a major increase in costs or prices. There will be no significant adverse effects on competition, employment, investment, productivity, innovation, or on the ability of U.S.-based enterprises to compete with foreign-based enterprises in domestic or export markets. This rulemaking was submitted to the Office of Management

and Budget (OMB) for review as required by Executive Order 12291.

C. Regulatory Flexibility Act Compliance

Pursuant to the provisions of 5 U.S.C. 605(b), I hereby certify that this attached rule, if promulgated, will not have any economic impact on small entities because no additional costs will be incurred.

This rule does not contain any information collection requirements subject to OMB review under the Paperwork Reduction Act of 1980, 44 U.S.C. 3501 *et seq.*

Dated: December 6, 1991.

F. Henry Habicht II
Acting Administrator.

List of Subjects in 40 CFR Part 51

Administrative practice and procedure.
Air pollution control.
Carbon Monoxide.
Inter-governmental relations.
Lead.
Nitrogen dioxide.
Ozone.
Particulate matter.
Reporting and recordkeeping requirements.
Sulfur Oxides.
Volatile Organic Compounds.

The EPA amends title 40, chapter I, part 51 of the Code of Federal Regulations as follows:

PART 51—[AMENDED]

1. The authority citation for part 51 continues to read as follows:

Authority: Section 110 of the Clean Air Act as amended (42 U.S.C. 7410).

2. Appendix M, to part 51 Table of Contents is amended by adding an entry to read as follows:

Method 202—Determination of Condensible Particulate Emissions From Stationary Sources

3. By adding Method 202 to Appendix M to part 51 to read as follows:

Method 202—Determination of Condensible Particulate Emissions From Stationary Sources

1. Applicability and Principle

1.1 Applicability. 1.1.1 This method applies to the determination of condensible particulate matter (CPM) emissions from stationary sources. It is intended to represent condensible matter as material that condenses after passing through a filter and as measured by this method (Note: The filter catch can be analyzed according to the appropriate method).

1.1.2 This method may be used in conjunction with Method 201 or 201A if the

probes are glass-lined. Using Method 202 in conjunction with Method 201 or 201A, only the impinger train configuration and analysis is addressed by this method. The sample train operation and front end recovery and analysis shall be conducted according to Method 201 or 201A.

1.1.3 This method may also be modified to measure material that condenses at other temperatures by specifying the filter and probe temperature. A heated Method 5 out-of-stack filter may be used instead of the in-stack filter to determine condensible emissions at wet sources.

1.2 Principle. 1.2.1 The CPM is collected in the impinger portion of a Method 17 (appendix A, 40 CFR part 60) type sampling train. The impinger contents are immediately purged after the run with nitrogen (N_2) to remove dissolved sulfur dioxide (SO_2) gases from the impinger contents. The impinger solution is then extracted with methylene chloride (MeCl_2). The organic and aqueous fractions are then taken to dryness and the residues weighed. The total of both fractions represents the CPM.

1.2.2 The potential for low collection efficiency exist at oil-fired boilers. To improve the collection efficiency at these type of sources, an additional filter placed between the second and third impinger is recommended.

2. Precision and Interference

2.1 Precision. The precision based on method development tests at an oil-fired boiler and a catalytic cracker were 11.7 and 4.8 percent, respectively.

2.2 Interference. Ammonia. In sources that use ammonia injection as a control technique for hydrogen chloride (HCl), the ammonia interferes by reacting with HCl in the gas stream to form ammonium chloride (NH_4Cl) which would be measured as CPM. The sample may be analyzed for chloride and the equivalent amount of NH_4Cl can be subtracted from the CPM weight. However, if NH_4Cl is to be counted as CPM, the inorganic fraction should be taken to near dryness (less than 1 ml liquid) in the oven and then allowed to air dry at ambient temperature to prevent any NH_4Cl from vaporizing.

3. Apparatus

3.1 Sampling Train. Same as in Method 17, section 2.1, with the following exceptions noted below (see Figure 202-1). Note: Mention of trade names or specific products does not constitute endorsement by EPA.

3.1.1 The probe extension shall be glass-lined or Teflon.

3.1.2 Both the first and second impingers shall be of the Greenburg-Smith design with the standard tip.

3.1.3 All sampling train glassware shall be cleaned prior to the test with soap and tap water, water, and rinsed using tap water, water, acetone, and finally, MeCl_2 . It is important to completely remove all silicone grease from areas that will be exposed to the MeCl_2 during sample recovery.

3.2 Sample Recovery. Same as in Method 17, section 2.2, with the following additions:

3.2.1 N_2 Purge Line. Inert tubing and fittings capable of delivering 0 to 28 liters/min of N_2 gas to the impinger train from a

standard gas cylinder (see Figure 202-2). Standard 0.95 cm (3/8-inch) plastic tubing and compression fittings in conjunction with an adjustable pressure regulator and needle valve may be used.

3.2.2 Rotameter. Capable of measuring gas flow at 20 liters/min.

3.3 Analysis. The following equipment is necessary in addition to that listed in Method 17, section 2.3:

3.3.1 Separatory Funnel. Glass, 1-liter.

3.3.2 Weighing Tins. 350-ml.

3.3.3 Dry Equipment. Hot plate and oven with temperature control.

3.3.4 Pipets. 5-ml.

3.3.5 Ion Chromatograph. Same as in Method 5F, Section 2.1.6.

4. Reagents

Unless otherwise indicated, all reagents must conform to the specifications established by the Committee on Analytical Reagents of the American Chemical Society. Where such specifications are not available, use the best available grade.

4.1 Sampling. Same as in Method 17, section 3.1, with the addition of deionized distilled water to conform to the American Society for Testing and Materials Specification D 1193-74, Type II and the omission of section 3.1.4.

4.2 Sample Recovery. Same as in Method 17, section 3.2, with the following additions:

4.2.1 N₂ Gas. Zero N₂ gas at delivery pressures high enough to provide a flow of 20 liters/min for 1 hour through the sampling train.

4.2.2 Methylene Chloride. ACS grade. Blanks shall be run prior to use and only methylene chloride with low blank values (0.001 percent) shall be used.

4.2.3 Water. Same as in section 4.1.

4.3 Analysis. Same as in Method 17, section 3.3, with the following additions:

4.3.1 Methylene Chloride. Same as section 4.2.2.

4.3.2 Ammonium Hydroxide. Concentrated (14.8 M) NH₄OH.

4.3.3 Water. Same as in section 4.1.

4.3.4 Phenolphthalein. The pH indicator solution, 0.05 percent in 50 percent alcohol.

5. Procedure

5.1 Sampling. Same as in Method 17, section 4.1, with the following exceptions:

5.1.1 Place 100 ml of water in the first three impingers.

5.1.2 The use of silicone grease in train assembly is not recommended because it is very soluble in MeCl₂, which may result in sample contamination. Teflon tape or similar means may be used to provide leak-free connections between glassware.

5.2 Sample Recovery. Same as in Method 17, section 4.2 with the addition of a post-test N₂ purge and specific changes in handling of individual samples as described below.

5.2.1 Post-test N₂ Purge for Sources Emitting SO₂. (Note: This step is recommended, but is optional. With little or no SO₂ is present in the gas stream, i.e., the pH of the impinger solution is greater than 4.5, purging has been found to be unnecessary.) As soon as possible after the post-test leak check, detach the probe and filter from the impinger train. Leave the ice in

the impinger box to prevent removal of moisture during the purge. If necessary, add more ice during the purge to maintain the gas temperature below 20 °C. With no flow of gas through the clean purge line and fittings, attach it to the input of the impinger train (see Figure 202-2). To avoid over- or under-pressurizing the impinger array, slowly commence the N₂ gas flow through the line while simultaneously opening the meter box pump valve(s). When using the gas cylinder pressure to push the purge gas through the sample train, adjust the flow rate to 20 liters/min through the rotameter. When pulling the purge gas through the sample train using the meter box vacuum pump, set the orifice pressure differential to ΔH₂ and maintain an overflow rate through the rotameter of less than 2 liters/min. This will guarantee that the N₂ delivery system is operating at greater than ambient pressure and prevents the possibility of passing ambient air (rather than N₂) through the impingers. Continue the purge under these conditions for 1 hour, checking the rotameter and ΔH value(s) periodically. After 1 hour, simultaneously turn off the delivery and pumping systems.

5.2.2 Sample Handling.

5.2.2.1 Container Nos. 1, 2, and 3. If filter catch is to be determined, as detailed in Method 17, section 4.2.

5.2.2.2 Container No. 4 (Impinger Contents). Measure the liquid in the first three impingers to within 1 ml using a clean graduated cylinder or by weighing it to within 0.5 g using a balance. Record the volume or weight of liquid present to be used to calculate the moisture content of the effluent gas. Quantitatively transfer this liquid into a clean sample bottle (glass or plastic); rinse each impinger and the connecting glassware, including probe extension, twice with water, recover the rinse water, and add it to the same sample bottle. Mark the liquid level on the bottle.

5.2.2.3 Container No. 5 (MeCl₂ Rinse). Follow the water rinses of each impinger and the connecting glassware, including the probe extension with two rinses of MeCl₂; save the rinse products in a clean, glass sample jar. Mark the liquid level on the jar.

5.2.2.4 Container No. 6 (Water Blank). Once during each field test, place 500 ml of water in a separate sample container.

5.2.2.5 Container No. 7 (MeCl₂ Blank). Once during each field test, place in a separate glass sample jar a volume of MeCl₂ approximately equivalent to the volume used to conduct the MeCl₂ rinse of the impingers.

5.3 Analysis. Record the data required on a sheet such as the one shown in Figure 202-3. Handle each sample container as follows:

5.3.1 Container Nos. 1, 2, and 3. If filter catch is analyzed, as detailed in Method 17, section 4.3.

5.3.2 Container Nos. 4 and 5. Note the level of liquid in the containers and confirm on the analytical data sheet whether leakage occurred during transport. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Measure the liquid in Container No. 4 either volumetrically to ±1 ml or gravimetrically to ±0.5 g. Remove a 5-ml aliquot and set aside for later ion

chromatographic (IC) analysis of sulfates. (Note: Do not use this aliquot to determine chlorides since the HCl will be evaporated during the first drying step; Section 8.2 details a procedure for this analysis.)

5.3.2.1 Extraction. Separate the organic fraction of the sample by adding the contents of Container No. 4 (MeCl₂) to the contents of Container No. 4 in a 1000-ml separatory funnel. After mixing, allow the aqueous and organic phases to fully separate, and drain off most of the organic/MeCl₂ phase. Then add 75 ml of MeCl₂ to the funnel, mix well, and drain off the lower organic phase. Repeat with another 75 ml of MeCl₂. This extraction should yield about 250 ml of organic extract. Each time, leave a small amount of the organic/MeCl₂ phase in the separatory funnel ensuring that no water is collected in the organic phase. Place the organic extract in a tared 350-ml weighing tin.

5.3.2.2 Organic Fraction Weight Determination (Organic Phase from Container Nos. 4 and 5). Evaporate the organic extract at room temperature and pressure in a laboratory hood. Following evaporation, desiccate the organic fraction for 24 hours in a desiccator containing anhydrous calcium sulfate. Weigh to a constant weight and report the results to the nearest 0.1 mg.

5.3.2.3 Inorganic Fraction Weight Determination. (Note: If NH₄Cl is to be counted as CPM, the inorganic fraction should be taken to near dryness (less than 1 ml liquid) in the oven and then allow to air dry at ambient temperature. If multiple acid emissions are suspected, the ammonia titration procedure in section 8.1 may be preferred.) Using a hot plate, or equivalent, evaporate the aqueous phase to approximately 50 ml; then, evaporate to dryness in a 105 °C oven. Redissolve the residue in 100 ml of water. Add five drops of phenolphthalein to this solution; then, add concentrated (14.8 M) NH₄OH until the sample turns pink. Any excess NH₄OH will be evaporated during the drying step. Evaporate the sample to dryness in a 105 °C oven, desiccate the sample for 24 hours, weigh to a constant weight, and record the results to the nearest 0.1 mg. (Note: The addition of NH₄OH is recommended, but is optional when little or no SO₂ is present in the gas stream, i.e., when the pH of the impinger solution is greater than 4.5, the addition of NH₄OH is not necessary.)

5.3.2.4 Analysis of Sulfate by IC to Determine Ammonium Ion (NH₄⁺) Retained in the Sample. (Note: If NH₄OH is not added, omit this step.) Determine the amount of sulfate in the aliquot taken from Container No. 4 earlier as described in Method 5F (appendix A, 40 CFR part 60). Based on the IC SO₄²⁻ analysis of the aliquot, calculate the correction factor to subtract the NH₄⁺ retained in the sample and to add the combined water removed by the acid-base reaction (see section 7.2).

5.3.3 Analysis of Water and MeCl₂ Blanks (Container Nos. 6 and 7). Analyze these sample blanks as described above in sec 5.3.2.3 and 5.3.2.2, respectively.

5.3.4 Analysis of Acetone Blank (Container No. 8). Same as in Method 17, section 4.3.

Calibration

Same as in Method 17, section 5, except for the following:

8.1 IC Calibration. Same as Method 5F, section 5.

8.2 Audit Procedure. Concurrently, analyze the audit sample and a set of compliance samples in the same manner to evaluate the technique of the analyst and the standards preparation. The same analyst, analytical reagents, and analytical system shall be used both for compliance samples and the EPA audit sample. If this condition is met, auditing of subsequent compliance analyses for the same enforcement agency within 30 days is not required. An audit sample set may not be used to validate different sets of compliance samples under the jurisdiction of different enforcement agencies, unless prior arrangements are made with both enforcement agencies.

8.3 Audit Samples. Audit Sample Availability. Audit samples will be supplied only to enforcement agencies for compliance tests. The availability of audit samples may be obtained by writing:

Source Test Audit Coordinator (MD-77B), Quality Assurance Division, Atmospheric Research and Exposure Assessment Laboratory, U.S. Environmental Protection Agency, Research Triangle, Park, NC 27711

or by calling the Source Test Audit Coordinator (STAC) at (919) 541-7834. The request for the audit sample must be made at least 30 days prior to the scheduled compliance sample analysis.

8.4 Audit Results. Calculate the audit sample concentration according to the calculation procedure described in the audit instructions included with the audit sample. Fill in the audit sample concentration and the analyst's name on the audit response form included with the audit instructions. Send one copy to the EPA Regional Office or the appropriate enforcement agency and a second copy to the STAC. The EPA Regional Office or the appropriate enforcement agency will report the results of the audit to the laboratory being audited. Include this response with the results of the compliance samples in relevant reports to the EPA Regional Office or the appropriate enforcement agency.

7. Calculations

Same as in Method 17, section 8, with the following additions:

7.1 Nomenclature. Same as in Method 17, section 8.1 with the following additions.

C_{com} = Concentration of the CPM in the stack gas, dry basis, corrected to standard conditions, g/dscm (g/dscf).

C_{SO_4} = Concentration of SO_4^{-2} in the sample, mg/ml.

m_w = Sum of the mass of the water and $MeCl_2$ blanks, mg.

m_a = Mass of the NH_4^+ added to sample to form ammonium sulfate, mg.

m_i = Mass of inorganic CPM matter, mg.

m_o = Mass of organic CPM, mg.

m_d = Mass of dried sample from inorganic fraction, mg.

V_a = Volume of aliquot taken for IC analysis, ml.

V_{ic} = Volume of impinger contents sample, ml.

7.2 Correction for NH_4^+ and H_2O .

Calculate the correction factor to subtract the NH_4^+ retained in the sample based on the IC SO_4^{-2} and if desired, add the combined water removed by the acid-base reaction.

$$m_c = K C_{com} V_a \quad \text{Eq. 202-1}$$

where:

$K = 0.0205$, when correcting for NH_4^+ and H_2O .

$= 0.1840$, when only correcting for NH_4^+ .

7.3 Mass of Inorganic CPM.

$$m_i = m_c \frac{V_a}{V_{ic} - V_a} - m_o \quad \text{Eq. 202-2}$$

7.4 Concentration of CPM.

$$C_{com} = \frac{m_o + m_i - m_a}{V m_{tot}} \quad \text{Eq. 202-3}$$

8. Alternative Procedures

8.1 Determination of NH_4^+ Retained in Sample by Titration.

8.1.1 An alternative procedure to determine the amount of NH_4^+ added to the inorganic fraction by titration may be used. After dissolving the inorganic residue in 100 ml of water, titrate the solution with 0.1 N NH_4OH to a pH of 7.0, as indicated by a pH meter. The 0.1 N NH_4OH is made as follows: Add 7 ml of concentrated (14.8 M) NH_4OH to 1 liter of water. Standardize against standardized 0.1 N H_2SO_4 and calculate the exact normality using a procedure parallel to that described in section 5.5 of Method 8 (appendix A, 40 CFR part 80). Alternatively, purchase 0.1 N NH_4OH that has been standardized against a National Institute of Standards and Technology reference material.

8.1.2 Calculate the concentration of SO_4^{-2} in the sample using the following equation.

$$C_{SO_4} = \frac{48.03 V_t N}{100} \quad \text{Eq. 202-4}$$

where

N = Normality of the NH_4OH , mg/ml.

V_t = Volume of NH_4OH titrant, ml.

48.03 = mg/meq.

100 = Volume of solution, ml.

8.3.1 Calculate the CPM as described in section 7.

8.2 Analysis of Chlorides by IC. At the conclusion of the final weighing as described in section 5.3.2.3, redissolve the inorganic fraction in 100 ml of water. Analyze an aliquot of the redissolved sample for chlorides by IC using techniques similar to those described in Method 5F for sulfates. Previous drying of the sample should have

removed all HCl. Therefore, the remaining chlorides measured by IC can be assumed to be NH_4Cl , and this weight can be subtracted from the weight determined for CPM.

8.3 Air Purge to Remove SO_2 from Impinger Contents. As an alternative to the post-test N_2 purge described in section 5.2.1, the tester may opt to conduct the post-test purge with air at 20 liter/min. Note: The use of an air purge is not as effective as a N_2 purge.

8.4 Chloroform-ether Extraction. As an alternative to the methylene chloride extraction described in section 5.3.2.1, the tester may opt to conduct a chloroform-ether extraction. Note: The Chloroform-ether was not as effective as the $MeCl_2$ in removing the organics, but it was found to be an acceptable organic extractant. Chloroform and diethylether of ACS grade, with low blank values (0.001 percent), shall be used. Analysis of the chloroform and diethylether blanks shall be conducted according to Section 5.3.3 for $MeCl_2$.

8.4.1 Add the contents of Container No. 4 to a 1000-ml separatory funnel. Then add 75 ml of chloroform to the funnel, mix well, and drain off the lower organic phase. Repeat two more times with 75 ml of chloroform. Then perform three extractions with 75 ml of diethylether. This extraction should yield approximately 450 ml of organic extraction. Each time, leave a small amount of the organic/ $MeCl_2$ phase in the separatory funnel ensuring that no water is collected in the organic phase.

8.4.2 Add the contents of Container No. 5 to the organic extraction. Place approximately 300 ml of the organic extract in a tared 350-ml weighing tin while storing the remaining organic extract in a sample container. As the organic extract evaporates, add the remaining extract to the weighing tin.

8.4.3 Determine the weight of the organic phase as described in Section 5.3.2.2.

8.5 Improving Collection Efficiency. If low impinger collection efficiency is suspected, the following procedure may be used.

8.5.1 Place an out-of-stock filter as described in Method 8 between the second and third impingers.

8.5.2 Recover and analyze the filter according to Method 17, Section 4.2. Include the filter holder as part of the connecting glassware and handle as described in sections 5.2.2.2 and 5.2.2.3.

8.5.3 Calculate the Concentration of CPM as follows:

$$C_{com} = \frac{m_o + m_i + m_f - m_a}{V m_{tot}} \quad \text{Eq. 202-5}$$

where:

m_f = amount of CPM collected on out-of-stock filter, mg.

8.6 Wet Source Testing. When testing at a wet source, use a heated out-of-stock filter as described in Method 5.

9. Bibliography

- DeWees, W.D., S.C. Steinsberger, G.M. Plummer, L.T. Lay, G.D. McAlister, and R.T.

Shigenara. "Laboratory and Field Evaluation of the EPA Method 5 Impinger Catch for Measuring Condensable Matter from Stationary Sources." Paper presented at the 1989 EPA/AWMA International Symposium on Measurement of Toxic and Related Air Pollutants. Raleigh, North Carolina. May 1-5, 1989.

2. DeWees, W.D. and K.C. Steinsberger. "Method Development and Evaluation of Draft Protocol for Measurement of Condensable Particulate Emissions." Draft Report, November 17, 1988.

3. Texas Air Control Board, Laboratory Division. "Determination of Particulate in Stack Gases Containing Sulfuric Acid and/or Sulfur Dioxide." *Laboratory Methods for Determination of Air Pollutants*. Modified December 3, 1978.

4. Nothstein, Greg. Masters Thesis. University of Washington. Department of Environmental Health. Seattle, Washington.

5. "Particulate Source Test Procedures Adopted by Puget Sound Air Pollution Control Agency Board of Directors." Puget Sound Air Pollution Control Agency.

Engineering Division. Seattle, Washington. August 11, 1983.

6. Commonwealth of Pennsylvania. Department of Environmental Resources. Chapter 139, Sampling and Testing (Title 25, Rules and Regulations, Part I, Department of Environmental Resources, Subpart C, Protection of Natural Resources, Article III, Air Resources). January 8, 1960.

7. Wisconsin Department of Natural Resources. *Air Management Operations Handbook, Revision 3*. January 11, 1988.

BILLING CODE 6680-20-2




Figure 202-1. Schematic of condensible particulate sampling train.




Figure 202-2. Schematic of post-test nitrogen purge system.

Moisture Determination

Volume or weight of liquid in impingers: _____ ml or g

Weight of moisture in silica gel: _____ g

Sample Preparation (Container No. 4)

Amount of liquid lost during transport: _____ ml

Final volume: _____ ml

pH of sample prior to analysis: _____

Addition of NH_4OH required: _____

Sample extracted 2X with 75 ml MeCl_2 : _____

For Titration of Sulfate

Normality of NH_4OH : _____ N

Volume of sample titrated: _____ ml

Volume of titrant: _____ ml

Sample Analysis

Container number	Weight of condensable particulate, mg		
	Final weight	Tare weight	Weight gain
4 (Inorganic) _____			
4 & 5 (Organic) _____			

Total: _____

Less Blank: _____

Weight of Condensable Particulate: _____

Figure 202-3. Analytical data sheet


[FR Doc. 91-29957 Filed 12-18-91; 8:45 am]

BILLING CODE 6550-60-M

Interpoll Laboratories
 (612) 786-6020

PARTICULATE SAMPLING TRAIN

MPINGER TRAIN OPTIONAL MAY BE REPLACED BY AN EQUIVALENT CONDENSER



Method 6C—Determination of Sulfur Dioxide Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 **Applicability.** This method is applicable to the determination of sulfur dioxide (SO₂) concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations.

1.2 **Principle.** A gas sample is continuously extracted from a stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of SO₂ gas concentration using an ultraviolet (UV), nondispersive infrared (NDIR), or fluorescence analyzer. Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

2.1 **Analytical Range.** The analytical range is determined by the instrumental design. For this method, a portion of the analytical range is selected by choosing the span of the monitoring system. The span of the monitoring system shall be selected such that the pollutant gas concentration equivalent to the emission standard is not less than 30 percent of the span. If at any time during a run the measured gas concentration exceeds the span, the run shall be considered invalid.

2.2 **Sensitivity.** The minimum detectable limit depends on the analytical range, span, and signal-to-noise ratio of the measurement system. For a well designed system, the minimum detectable limit should be less than 2 percent of the span.

3. Definitions

3.1 **Measurement System.** The total equipment required for the determination of gas concentration. The measurement system consists of the following major subsystems:

3.1.1 **Sample Interface.** That portion of a system used for one or more of the following: sample acquisition, sample transport, sample conditioning, or protection of the analyzers from the effects of the stack effluent.

3.1.2 **Gas Analyzer.** That portion of the system that senses the gas to be measured and generates an output proportional to its concentration.

3.1.3 **Data Recorder.** A strip chart recorder, analog computer, or digital recorder for recording measurement data from the analyzer output.

3.2 **Span.** The upper limit of the gas concentration measurement range displayed on the data recorder.

3.3 **Calibration Gas.** A known concentration of a gas in an appropriate diluent gas.

3.4 Analyzer Calibration Error. The difference between the gas concentration exhibited by the gas analyzer and the known concentration of the calibration gas when the calibration gas is introduced directly to the analyzer.

3.5 Sampling System Bias. The difference between the gas concentrations exhibited by the measurement system when a known concentration gas is introduced at the outlet of the sampling probe and when the same gas is introduced directly to the analyzer.

3.6 Zero Drift. The difference in the measurement system output reading from the initial calibration response at the zero concentration level after a stated period of operation during which no unscheduled maintenance, repair, or adjustment took place.

3.7 Calibration Drift. The difference in the measurement system output reading from the initial calibration response at a mid-range calibration value after a stated period of operation during which no unscheduled maintenance, repair, or adjustment took place.

3.8 Response Time. The amount of time required for the measurement system to display 95 percent of a step change in gas concentration on the data recorder.

3.9 Interference Check. A method for detecting analytical interferences and excessive biases through direct comparison of gas concentrations provided by the measurement system and by a modified Method 6 procedure. For this check, the modified Method 6 samples are acquired at the sample by-pass discharge vent.

3.10 Calibration Curve. A graph or other systematic method of establishing the relationship between the analyzer response and the actual gas concentration introduced to the analyzer.

4. Measurement System Performance Specifications

4.1 Analyzer Calibration Error. Less than ± 2 percent of the span for the zero, mid-range, and high-range calibration gases.

4.2 Sampling System Bias. Less than ± 5 percent of the span for the zero, and mid— or high-range calibration gases.

4.3 Zero Drift. Less than ± 3 percent of the span over the period of each run.

4.4 Calibration Drift. Less than ± 3 percent of the span over the period of each run.

4.5 Interference Check. Less than ± 7 percent of the modified Method 6 result for each run.

5. Apparatus and Reagents

5.1 Measurement System. Any measurement system for SO₂ that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1. The essential components of the measurement system are described below:

5.1.1 Sample Probe. Glass, stainless steel, or equivalent, of sufficient length to traverse the sample points. The sampling probe shall be heated to prevent condensation.

5.1.2 Sample Line. Heated (sufficient to prevent condensation) stainless steel or Teflon tubing, to transport the sample gas to the moisture removal system.

5.1.3 Sample Transport Lines. Stainless steel or Teflon tubing, to transport the sample from the moisture removal system to the sample pump, sample flow rate control, and sample gas manifold.

5.1.4 Calibration Valve Assembly. A three—way valve assembly, or equivalent, for blocking the sample gas flow and introducing calibration gases to the measurement system at the outlet of the sampling probe when in the calibration mode.

5.1.5 Moisture Removal System. A refrigerator-type condenser or similar device (e.g., permeation dryer), to remove condensate continuously from the sample gas while maintaining minimal contact between the condensate and the sample gas. The moisture removal system is not necessary for analyzers that can measure gas concentrations on a wet basis; for these analyzers, (1) heat the sample line and all interface components up to the inlet of the analyzer sufficiently to prevent condensation, and (2) determine the moisture content and correct the measured gas concentrations to a dry basis using appropriate methods, subject to the approval of the Administrator. The determination of sample moisture content is not necessary for pollutant analyzers that measure concentrations on a wet basis when (1) a wet basis CO₂ analyzer operated according to Method 3A is used to obtain simultaneous measurements, and (2) the pollutant/CO₂ measurements are used to determine emissions in units of the standard.

5.1.6 Particulate Filter. An in-stack or heated (sufficient to prevent water condensation) out—of—stack filter. The filter shall be borosilicate or quartz glass wool, or glass fiber mat. Additional filters at the inlet or outlet of the moisture removal system and inlet of the analyzer may be used to prevent accumulation of particulate material in the measurement system and extend the useful life of the components. All filters shall be fabricated of materials that are nonreactive to the gas being sampled.

5.1.7 Sample Pump. A leak-free pump, to pull the sample gas through the system at a flow rate sufficient to minimize the response time of the measurement system. The pump may be constructed of any material that is nonreactive to the gas being sampled.

5.1.8 Sample Flow Rate Control. A sample flow rate control valve and rotameter, or equivalent, to maintain a constant sampling rate within 10 percent.

(Note: The tester may elect to install a back-pressure regulator to maintain the sample gas manifold at a constant pressure in order to protect the analyzer(s) from over pressurization, and to minimize the need for flow rate adjustments.)

5.1.9 Sample Gas Manifold. A sample gas manifold, to divert a portion of the sample gas stream to the analyzer, and the remainder to the by-pass discharge vent. The sample gas manifold should also include provisions for introducing calibration gases directly to the analyzer. The manifold may be constructed of any material that is nonreactive to the gas being sampled.

5.1.10 Gas Analyzer. A UV or NDIR absorption or fluorescence analyzer, to determine continuously the SO₂ concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer.

(Note: Housing the analyzer(s) in a clean, thermally-stable, vibration-free environment will minimize drift in the analyzer calibration.)

5.1.11 Data Recorder. A strip chart recorder, analog computer, or digital recorder, for recording measurement data. The data recorder resolution (i.e., readability) shall be 0.5 percent of span. Alternatively, a digital or analog meter having a resolution of 0.5 percent of span may be used to obtain the analyzer responses and the readings may be recorded manually. If this alternative is used, the readings shall be obtained at equally spaced intervals over the duration of the sampling run. For sampling run durations of less than 1 hour, measurements at 1—minute intervals or a minimum of 30 measurements, whichever is less restrictive, shall be obtained. For sampling run durations greater than 1 hour, measurements at 2—minute intervals or a minimum of 96 measurements, whichever is less restrictive, shall be obtained.

5.2 Method 6 Apparatus and Reagents. The apparatus and reagents described in Method 6, and shown by the schematic of the sampling train in Figure 6C-2, to conduct the interference check.

5.3 SO₂ Calibration Gases. The calibration gases for the gas analyzer shall be SO₂ in N₂ or SO₂ in air. Alternatively, SO₂/CO₂, SO₂/O₂, or SO₂/CO₂/O₂ gas mixtures in N₂ may be used. For fluorescence-based analyzers, the O₂ and CO₂ concentrations of the calibration gases as introduced to the analyzer shall be within 1 percent (absolute) O₂ and 1 percent (absolute) CO₂ of the O₂ and CO₂ concentrations of the effluent samples as introduced to the analyzer. Alternatively, for fluorescence-based analyzers, use calibration blends of SO₂ in air and the nomographs provided by the vendor to determine the quenching correction factor (the effluent O₂ and CO₂ concentrations must be known). Use three calibration gases as specified below:

5.3.1 High-Range Gas. Concentration equivalent to 80 to 100 percent of the span.

5.3.2 Mid-Range Gas. Concentration equivalent to 40 to 60 percent of the span.

5.3.3 Zero Gas. Concentration of less than 0.25 percent of the span. Purified ambient air may be used for the zero gas by passing air through a charcoal filter, or through one or more impingers containing a solution of 3 percent H₂O₂.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Gas Concentration Verification. There are two alternatives for establishing the concentrations of calibration gases. Alternative Number 1 is preferred.

6.1.1 Alternative Number 1—Use of calibration gases that are analyzed following the Environmental Protection Agency Traceability Protocol Number 1 (see Citation 1 in the Bibliography). Obtain a certification from the gas manufacturer that Protocol Number 1 was followed.

6.1.2 Alternative Number 2—Use of calibration gases not prepared according to Protocol Number 1. If this alternative is chosen, obtain gas mixtures with a manufacturer's tolerance not to exceed ± 2 percent of the tag value. Within 6 months before the emission test, analyze each of the calibration gases in triplicate using Method 6. Citation 2 in the Bibliography describes procedures and techniques that may be used for this analysis. Record the results on a data sheet (example is shown in Figure 6C-3). Each of the individual SO₂ analytical results for each calibration gas shall be within 5 percent (or 5 PPM, whichever is greater) of the triplicate set average; otherwise, discard the entire set, and repeat the triplicate analyses. If the average of the triplicate analyses is within 5 percent of the calibration gas manufacturer's cylinder tag value, use the tag value; otherwise, conduct at least three additional analyses until the results of six consecutive runs agree with 5 percent (or 5 PPM, whichever is greater) of their average. Then use this average for the cylinder value.

6.2 Measurement System Preparation. Assemble the measurement system by following the manufacturer's written instructions for preparing and preconditioning the gas analyzer and, as applicable, the other system components. Introduce the calibration gases in any sequence, and make all necessary adjustments to calibrate the analyzer and the data recorder. Adjust system components to achieve correct sampling rates.

6.3 Analyzer Calibration Error. Conduct the analyzer calibration error check by introducing calibration gases to the measurement system at any point upstream of the gas analyzer as follows:

6.3.1 After the measurement system has been prepared for use, introduce the zero, mid-range, and high-range gases to the analyzer. During this check, make no adjustments to the system except those necessary to achieve the correct calibration gas flow rate at the analyzer. Record the analyzer responses to each calibration gas on a form similar to Figure 6C-4.

Note: A calibration curve established prior to the analyzer calibration error check may be used to convert the analyzer response to the equivalent gas concentration introduced to the analyzer. However, the same correction procedure shall be used for all effluent and calibration measurements obtained during the test.

6.3.2 The analyzer calibration error check shall be considered invalid if the gas concentration displayed by the analyzer exceeds ± 2 percent of the span for any of the calibration gases. If an invalid calibration is exhibited, take corrective action, and repeat the analyzer calibration error check until acceptable performance is achieved.

6.4 Sampling System Bias Check. Perform the sampling system bias check by introducing calibration gases at the calibration valve installed at the outlet of the sampling probe. A zero gas and either the mid-range or high-range gas, whichever most closely approximates the effluent concentrations, shall be used for this check as follows:

6.4.1 Introduce the upscale calibration gas, and record the gas concentration displayed by the analyzer on a form similar to Figure 6C-5. Then introduce zero gas, and record the gas concentration displayed by the analyzer. During the sampling system bias check, operate the system at the normal sampling rate, and make no adjustments to the measurement system other than those necessary to achieve proper calibration gas flow rates at the analyzer. Alternately introduce the zero and upscale gases until a stable response is achieved. The tester shall determine the measurement system response time by observing the times required to achieve a stable response for both the zero and upscale gases. Note the longer of the two times as the response time.

6.4.2 The sampling system bias check shall be considered invalid if the difference between the gas concentrations displayed by the measurement system for the analyzer calibration error check and for the sampling system bias check exceeds ± 5 percent of the span for either the zero or upscale calibration gas. If an invalid calibration is exhibited, take corrective action, and repeat the sampling system bias check until acceptable performance is achieved. If adjustment to the analyzer is required, first repeat the analyzer calibration error check, then repeat the sampling system bias check.

7. Emission Test Procedure

7.1 Selection of Sampling Site and Sampling Points. Select a measurement site and sampling points using the same criteria that are applicable to Method 6.

7.2 Interference Check Preparation. For each individual analyzer, conduct an interference check for at least three runs during the initial field test on a particular source category. Retain the results, and report them with each test performed on that source category. If an interference check is being performed, assemble the modified Method 6 train (flow control valve, two midjet impingers containing 3 percent H_2O_2 , and dry gas meter) as shown in Figure 6C-2. Install the sampling train to obtain a sample at the measurement system sample by-pass discharge vent. Record the initial dry gas meter reading.

7.3 Sample Collection. Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the sampling system bias check. Maintain constant rate sampling (i.e., ± 10 percent) during the entire run. The sampling time per run shall be the same as for Method 6 plus twice the system response time. For each run, use only those measurements obtained after twice response time of the measurement system has elapsed, to determine the average effluent concentration. If an interference check is being performed, open the flow control valve on the modified Method 6 train concurrent with the initiation of the sampling period, and adjust the flow to 1 liter per minute (± 10 percent).

(Note: If a pump is not used in the modified Method 6 train, caution should be exercised in adjusting the flow rate since overpressurization of the impingers may cause leakage in the impinger train, resulting in positively biased results).

7.4 Zero and Calibration Drift Tests. Immediately preceding and following each run, or if adjustments are necessary for the measurement system during the run, repeat the sampling system bias check procedure described in Section 6.4 (Make no adjustments to the measurement system until after the drift checks are completed.) Record and analyzer's responses on a form similar to Figure 6C-5.

7.4.1 If either the zero or upscale calibration value exceeds the sampling system bias specification, then the run is considered invalid. Repeat both the analyzer calibration error check procedure (Section 6.3) and the sampling system bias check procedure (Section 6.4) before repeating the run.

7.4.2 If both the zero and upscale calibration values are within the sampling system bias specification, then use the average of the initial and final bias check values to calculate the gas concentration for the run. If the zero or upscale calibration drift value exceeds the drift limits, based on the difference between the sampling system bias check responses immediately before and after the run, repeat both the analyzer calibration error check procedure (Section 6.3) and the sampling system bias check procedure (Section 6.4) before conducting additional runs.

7.5 Interference Check (if performed). After completing the run, record the final dry gas meter reading, meter temperature, and barometric pressure. Recover and analyze the contents of the midjet impingers, and determine the SO₂ gas concentration using the procedures of Method 6. (It is not necessary to analyze EPA performance audit samples for Method 6.) Determine the average gas concentration exhibited by the analyzer for the run. If the gas concentrations provided by the analyzer and the modified Method 6 differ by more than 7 percent of the modified Method 6 result, the run is invalidated.

8. Emission Calculation

The average gas effluent concentration is determined from the average gas concentration displayed by the gas analyzer, and is adjusted for the zero and upscale sampling system bias checks, as determined in accordance with Section 7.4. The average gas concentration displayed by the analyzer may be determined by integration of the area under the curve for chart recorders, or by averaging all of the effluent measurements. Alternatively, the average may be calculated from measurements recorded at equally spaced intervals over the entire duration of the run. For sampling run durations of less than 1 hour, measurements at 1—minute intervals or a minimum of 30 measurements, whichever is less restrictive, shall be used. For sampling run durations greater than 1 hour, measurements at 2—minute intervals or a minimum of 96 measurements, whichever is less restrictive, shall be used. Calculate the effluent gas concentration using Equation 6C-1.

$$\bar{C}_{gas} = (C_m - C_o) \frac{C_{ma}}{C_m - C_o} \text{ Eq. 6C - 1}$$

Where:

C_{gas} = Effluent gas concentration, dry basis, PPM.

\bar{C} = Average gas concentration indicated by gas analyzer, dry basis, PPM.

C_o = Average of initial and final system calibration bias check responses for the zero gas, PPM.

C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, PPM.

C_{ma} = Actual concentration of the upscale calibration gas, PPM.

9. Bibliography

1. Traceability Protocol for Establishing True Concentrations of Gases Used for Calibrations and Audits of Continuous Source Emission Monitors: Protocol Number 1. U.S. Environmental Protection Agency, Quality Assurance Division. Research Triangle Park, NC. June 1978.

2. Westlin, Peter R. and J. W. Brown. Methods for Collecting and Analyzing Gas Cylinder Samples. Source Evaluation Society Newsletter. 3(3):5-15. September 1978.

|_See_CFR_paper_publication_for_illustration_0809

|_See_CFR_paper_publication_for_illustration_0810

Method 7E—Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Procedure)

1. Applicability and Principle

1.1 **Applicability.** This method is applicable to the determination of nitrogen oxides (NO_x) concentrations in emissions from stationary sources only when specified within the regulations.

1.2 **Principle.** A gas sample is continuously extracted from a stack, and a portion of the sample is conveyed to an instrumental chemiluminescent analyzer for determination of NO_x concentration. Performance specifications and test procedures are provided to ensure reliable data.

2. Range and Sensitivity

Same as Method 6C, Sections 2.1 and 2.2.

3. Definitions

3.1 **Measurement System.** The total equipment required for the determination of NO_x concentration. The measurement system consists of the following major subsystems:

3.1.1 **Sample Interface, Gas Analyzer, and Data Recorder.** Same as Method 6C, Sections 3.1.1, 3.1.2, and 3.1.3.

3.1.2 **NO_2 to NO Converter.** A device that converts the nitrogen dioxide (NO_2) in the sample gas to nitrogen oxide (NO).

3.2 **Span, Calibration Gas, Analyzer Calibration Error, Sampling System Bias, Zero Drift, Calibration Drift, and Response Time.** Same as Method 6C, Sections 3.2 through 3.8.

3.3 **Interference Response.** The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

4. Measurement System Performance Specifications

Same as Method 6C, Sections 4.1 through 4.4.

5. Apparatus and Reagents

5.1 **Measurement System.** Any measurement system for NO_x that meets the specifications of this method. A schematic of an acceptable measurement system is shown in Figure 6C-1 of Method 6C. The essential components of the measurement system are described below:

5.1.1 Sample Probe, Sample Line, Calibration Valve Assembly, Moisture Removal System, Particulate Filter, Sample Pump, Sample Flow Rate Control, Sample Gas Manifold, and Data Recorder. Same as Method 6C, Sections 5.1.1 through 5.1.9, and 5.1.11.

5.1.2 NO₂ to NO Converter. That portion of the system that converts the nitrogen dioxide (NO₂) in the sample gas to nitrogen oxide (NO). An NO₂ to NO converter is not necessary if data are presented to demonstrate that the NO₂ portion of the exhaust gas is less than 5 percent of the total NO_x concentration.

5.1.3 NO_x Analyzer. An analyzer based on the principles of chemiluminescence, to determine continuously the NO_x concentration in the sample gas stream. The analyzer shall meet the applicable performance specifications of Section 4. A means of controlling the analyzer flow rate and a device for determining proper sample flow rate (e.g., precision rotameter, pressure gauge downstream of all flow controls, etc.) shall be provided at the analyzer.

5.2 NO_x Calibration Gases. The calibration gases for the NO_x analyzer shall be NO in N₂. Three calibration gases, as specified in Sections 5.3.1 through 5.3.3. of Method 6C, shall be used. Ambient air may be used for the zero gas.

6. Measurement System Performance Test Procedures

Perform the following procedures before measurement of emissions (Section 7).

6.1 Calibration Gas Concentration Verification. Follow Section 6.1 of Method 6C, except if calibration gas analysis is required, use Method 7, and change all 5 percent performance values to 10 percent (or 10 PPM, whichever is greater).

6.2 Interference Response. Conduct an interference response test of the analyzer prior to its initial use in the field. Thereafter, recheck the measurement system if changes are made in the instrumentation that could alter the interference response (e.g., changes in the gas detector). Conduct the interference response in accordance with Section 5.4 of Method 20.

6.3 Measurement System Preparation, Analyzer Calibration Error, and Sample System Bias Check. Follow Sections 6.2 through 6.4 of Method 6C.

6.4 NO₂ to NO Conversion Efficiency. Unless data are presented to demonstrate that the NO₂ concentration within the sample stream is not greater than 5 percent of the NO_x concentration, conduct an NO₂ to NO conversion efficiency test in accordance with Section 5.6 of Method 20.

7. Emission Test Procedure

7.1 Selection of Sampling Site and Sampling Points. Select a measurement site and sampling points using the same criteria that are applicable to tests performed using Method 7.

7.2 Sample Collection. Position the sampling probe at the first measurement point, and begin sampling at the same rate as used during the system calibration drift test. Maintain constant rate sampling (i.e., ± 10 percent) during the entire run. The sampling time per run shall be the same as the total time required to perform a run using Method 7, plus twice the system response time. For each run, use only those measurements obtained after twice the response time of the measurement system has elapsed, to determine the average effluent concentration.

7.3 Zero and Calibration Drift Test. Follow Section 7.4 of Method 6C.

8. Emission Calculation

Follow Section 8 of Method 6C.

9. Bibliography

Same as bibliography of Method 6C.

Method 10—Determination of Carbon Monoxide Emissions From Stationary Sources

1. Principle and Applicability

1.1 **Principle.** An integrated or continuous gas sample is extracted from a sampling point and analyzed for carbon monoxide (CO) content using a Luft-type nondispersive infrared analyzer (NDIR) or equivalent.

1.2 **Applicability.** This method is applicable for the determination of carbon monoxide emissions from stationary sources only when specified by the test procedures for determining compliance with new source performance standards. The test procedure will indicate whether a continuous or an integrated sample is to be used.

2. Range and Sensitivity

2.1 **Range.** 0 to 1,000 PPM.

2.2 **Sensitivity.** Minimum detectable concentration is 20 PPM for a 0 to 1,000 PPM span.

3. Interferences

Any substance having a strong absorption of infrared energy will interfere to some extent. For example, discrimination ratios for water (H₂O) and carbon dioxide (CO₂) are 3.5 percent H₂O per 7 PPM CO and 10 percent CO₂ per 10 PPM CO, respectively, for devices measuring in the 1,500 to 3,000 PPM range. For devices measuring in the 0 to 100 PPM range, interference ratios can be as high as 3.5 percent H₂O per 25 PPM CO and 10 percent CO₂ per 50 PPM CO. The use of silica gel and ascarite traps will alleviate the major interference problems. The measured gas volume must be corrected if these traps are used.

4. Precision and Accuracy

4.1 **Precision.** The precision of most NDIR analyzers is approximately ± 2 percent of span.

4.2 **Accuracy.** The accuracy of most NDIR analyzers is approximately ± 5 percent of span after calibration.

5. Apparatus

5.1 **Continuous Sample** (Figure 10-1).

5.1.1 **Probe.** Stainless steel or sheathed Pyrex\1\ glass, equipped with a filter to remove particulate matter.

5.1.2 **Air-Cooled Condenser or Equivalent.** To remove any excess moisture.

5.2 **Integrated Sample** (Figure 10-2).

042694-G:\STACK\WPMETHODS\METH.10

5.2.1 **Probe.** Stainless steel or sheathed Pyrex glass, equipped with a filter to remove particulate matter.

5.2.2 **Air-Cooled Condenser or Equivalent.** To remove any excess moisture.

5.2.3 **Valve.** Needle valve, or equivalent, to adjust flow rate.

5.2.4 **Pump.** Leak-free diaphragm type, or equivalent, to transport gas.

5.2.5 **Rate Meter.** Rotameter, or equivalent, to measure a flow range from 0 to 1.0 liter per min (0.035 cfm).

5.2.6 **Flexible Bag.** Tedlar, or equivalent, with a capacity of 60 to 90 liters (2 to 3 ft³). Leak-test the bag in the laboratory before using by evacuating bag with a pump followed by a dry gas meter. When evacuation is complete, there should be no flow through the meter.

5.2.7 **Pitot Tube.** Type S, or equivalent, attached to the probe so that the sampling rate can be regulated proportional to the stack gas velocity when velocity is varying with the time or a sample traverse is conducted.

5.3 Analysis (Figure 10-3).

5.3.1 **Carbon Monoxide Analyzer.** Nondispersive infrared spectrometer, or equivalent. This instrument should be demonstrated, preferably by the manufacturer, to meet or exceed manufacturer's specifications and those described in this method.

5.3.2 **Drying Tube.** To contain approximately 200 g of silica gel.

5.3.3 **Calibration Gas.** Refer to section 6.1.

5.3.4 **Filter.** As recommended by NDIR manufacturer.

|_See_CFR_paper_publication_for_illustration__18A

5.3.5 **CO₂ Removal Tube.** To contain approximately 500 g of ascarite.

5.3.6 **Ice Water Bath.** For ascarite and silica gel tubes.

5.3.7 **Valve.** Needle valve, or equivalent, to adjust flow rate

5.3.8 **Rate Meter.** Rotameter or equivalent to measure gas flow rate of 0 to 1.0 liter per min (0.035 cfm) through NDIR.

5.3.9 **Recorder (optional).** To provide permanent record of NDIR readings.

6. Reagents

6.1 **Calibration Gases.** Known concentration of CO in nitrogen (N₂) for instrument span, prepurified grade of N₂ for zero, and two additional concentrations corresponding approximately to 60 percent and 30 percent span. The span concentration shall not exceed 1.5 times the applicable source performance standard. The calibration gases shall be certified by the manufacturer to be within ± 2 percent of the specified concentration.

|_See_CFR_paper_publication_for_illustration_19A

6.2 **Silica Gel.** Indicating type, 6 to 16 mesh, dried at 175°C (347°F) for 2 hours.

6.3 **Ascarite.** Commercially available.

7. Procedure

7.1 **Sampling.**

7.1.1 **Continuous Sampling.** Set up the equipment as shown in Figure 10-1 making sure all connections are leak free. Place the probe in the stack at a sampling point and purge the sampling line. Connect the analyzer and begin drawing sample into the analyzer. Allow 5 minutes for the system to stabilize, then record the analyzer reading as required by the test procedure. (See section 7.2 and 8). CO₂ content of the gas may be determined by using the Method 3 integrated sample procedure, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.1.2 **Integrated Sampling.** Evacuate the flexible bag. Set up the equipment as shown in Figure 10-2 with the bag disconnected. Place the probe in the stack and purge the sampling line. Connect the bag, making sure that all connections are leak free. Sample at a rate proportional to the stack velocity. CO₂ content of the gas may be determined by using the Method 3 integrated sample procedures, or by weighing the ascarite CO₂ removal tube and computing CO₂ concentration from the gas volume sampled and the weight gain of the tube.

7.2 **CO Analysis.** Assemble the apparatus as shown in Figure 10-3, calibrate the instrument, and perform other required operations as described in section 8. Purge analyzer with N₂ prior to introduction of each sample. Direct the sample stream through the instrument for the test period, recording the readings. Check the zero and span again after the test to assure that any drift or malfunction is detected. Record the sample data on Table 10-1.

8. Calibration

Assemble the apparatus according to Figure 10-3. Generally an instrument requires a warm-up period before stability is obtained. Follow the manufacturer's instructions for specific procedure. Allow a minimum time of 1 hour for warm-up. During this time check the sample conditioning apparatus, i.e., filter, condenser, drying tube, and CO₂ removal tube, to ensure that each component is in good operating condition. Zero and calibrate the instrument according to the manufacturer's procedures using, respectively, nitrogen and the calibration gases.

Table 10-1—Field data

Comments _____

Location _____

Test _____

Date _____

Operator _____

Clock time	Rotameter setting, liters per minute (cubic feet per minute)
------------	---

9. Calculation

Calculate the concentration of carbon monoxide in the stack using Equation 10-1:

$$\text{CCO stack} = \text{CCO NDIR}(1-\text{FCO}_2) \quad \text{Eq. 10-1}$$

Where:

CCO stack = Concentration of CO in stack, PPM by volume (dry basis).

CCO NDIR = Concentration of CO measured by NDIR analyzer, PPM by volume (dry basis).

FCO₂ = Volume fraction of CO₂ in sample, i.e., percent CO₂ from Orsat analysis divided by 100.

10. Alternative Procedures

10.1 **Interference Trap.** The sample conditioning system described in Method 10A, sections 2.1.2 and 4.2, may be used as an alternative to the silica gel and ascarite traps.

11. Bibliography

1. McElroy, Frank, The Intertech NDIR-CO Analyzer, Presented at 11th Methods Conference on Air Pollution, University of California, Berkeley, CA. April 1, 1970.
2. Jacobs, M. B., et al., Continuous Determination of Carbon Monoxide and Hydrocarbons in Air by a Modified Infrared Analyzer, J. Air Pollution Control Association, 9(2): 110-114. August 1959.
3. MSA LIRA Infrared Gas and Liquid Analyzer Instruction Book, Mine Safety Appliances Co., Technical Products Division, Pittsburgh, PA.
4. Models 215A, 315A, and 415A Infrared Analyzers, Beckman Instruments, Inc., Beckman Instructions 1635-B, Fullerton, CA. October 1967.
5. Continuous CO Monitoring System, Model A5611, Intertech Corp., Princeton, NJ.
6. UNOR Infrared Gas Analyzers, Bendix Corp., Ronceverte, WV

Agenda

A. Performance Specifications for NDIR Carbon Monoxide Analyzers

Range (minimum)	0—1000 PPM.
Output (minimum)	0—10mV.
Minimum detectable sensitivity	20 PPM.
Rise time, 90 percent (maximum)	30 seconds.
Fall time, 90 percent (maximum)	30 seconds.
Zero drift (maximum)	10% in 8 hours.
Span drift (maximum)	10% in 8 hours.
Precision (minimum)	± 2% of full scale.
Noise (maximum)	± 1% of full scale.
Linearity (maximum deviation)	2% of full scale.
Interference rejection ratio	CO ₂ —1000 to 1, H ₂ O—500 to 1.

B. Definitions of Performance Specifications.

Range—The minimum and maximum measurement limits.

Output—Electrical signal which is proportional to the measurement; intended for connection to readout or data processing devices. Usually expressed as millivolts or milliamps full scale at a given impedance.

Full scale—The maximum measuring limit for a given range.

Minimum detectable sensitivity—The smallest amount of input concentration that can be detected as the concentration approaches zero.

Accuracy—The degree of agreement between a measured value and the true value; usually expressed as \pm percent of full scale.

Time to 90 percent response—The time interval from a step change in the input concentration at the instrument inlet to a reading of 90 percent of the ultimate recorded concentration.

Rise Time (90 percent)—The interval between initial response time and time to 90 percent response after a step increase in the inlet concentration.

Fall Time (90 percent)—The interval between initial response time and time to 90 percent response after a step decrease in the inlet concentration.

Zero Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is zero; usually expressed as percent full scale.

Span Drift—The change in instrument output over a stated time period, usually 24 hours, of unadjusted continuous operation when the input concentration is a stated upscale value; usually expressed as percent full scale.

Precision—The degree of agreement between repeated measurements of the same concentration, expressed as the average deviation of the single results from the mean.

Noise—Spontaneous deviations from a mean output not caused by input concentration changes.

Linearity—The maximum deviation between an actual instrument reading and the reading predicted by a straight line drawn between upper and lower calibration points.

Method 10A—Determination of Carbon Monoxide Emissions in Certifying Continuous Emission Monitoring Systems at Petroleum Refineries

1. Applicability and Principle

1.1 Applicability. This method applies to the measurement of carbon monoxide (CO) at petroleum refineries. This method serves as the reference method in the relative accuracy test for nondispersive infrared (NDIR) CO continuous emission monitoring systems (CEMS's) that are required to be installed in petroleum refineries on fluid catalytic cracking unit catalyst regenerators [40 CFR Part 60.105(a)(2)].

1.2 Principle. An integrated gas sample is extracted from the stack, passed through an alkaline permanganate solution to remove sulfur and nitrogen oxides, and collected in a Tedlar bag. The CO concentration in the sample is measured spectrophotometrically using the reaction of CO with p-sulfaminobenzoic acid.

1.3. Range and Sensitivity.

1.3.1 Range. Approximately 3 to 1800 PPM CO. Samples having concentrations below 400 PPM are analyzed at 425 nm, and samples having concentrations above 400 PPM are analyzed at 600 nm.

1.3.2 Sensitivity. The detection limit is 3 PPM based on three times the standard deviation of the mean reagent blank values.

Method 25A-Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer

1. Applicability and Principle

1.1 Applicability. This method applies to the measurement of total gaseous organic concentration of vapors consisting primarily of alkanes, alkenes, and/or arenes (aromatic hydrocarbons). The concentration is expressed in terms of propane (or other appropriate organic calibration gas) or in terms of carbon.

1.2 Principle. A gas sample is extracted from the source through a heated sample line, if necessary, and glass fiber filter to a flame ionization analyzer (FIA). Results are reported as volume concentration equivalents of the calibration gas or as carbon equivalents.

2. Definitions

2.1 Measurement Systems. The total equipment required for the determination of the gas concentration. The system consists of the following major subsystems:

2.1.1 Sample Interface. That portion of the system that is used for one or more of the following: sample acquisition, sample transportation, sample conditioning, or protection of the analyzer from the effects of the stack effluent.

2.1.2 Organic Analyzer. That portion of the system that senses organic concentration and generates an output proportional to the gas concentration.

2.2 Span Value. The upper limit of a gas concentration measurement range that is specified for affected source categories in the applicable part of the regulations. The span value is established in the applicable regulation and is usually 1.5 to 2.5 times the applicable emission limit. If no span value is provided, use a span value equivalent to 1.5 to 2.5 times the expected concentration. For convenience, the span value should correspond to 100 percent of the recorder scale.

2.3 Calibration Gas. A known concentration of a gas in an appropriate diluent gas.

2.4 Zero Drift. The difference in the measurement system response to a zero level calibration gas before and after a stated period of operation during which no unscheduled maintenance, repair, or adjustment took place.

2.5 Calibration drift. The difference in the measurement system response to a midlevel calibration gas before and after a stated period of operation during which no unscheduled maintenance, repair or adjustment took place.

2.6 Response Time. The time interval from a step change in pollutant concentration at the inlet to the emission measurement system to the time at which 95 percent of the corresponding final value is reached as displayed on the recorder.

2.7 **Calibration Error.** The difference between the gas concentration indicated by the measurement system and the known concentration of the calibration gas.

3. Apparatus

A schematic of an acceptable measurement system is shown in Figure 25A-1. The essential components of the measurement system are described below:

3.1 **Organic Concentration Analyzer.** A flame ionization analyzer (FIA) capable of meeting or exceeding the specifications in this method.

3.2 **Sample Probe.** Stainless steel, or equivalent, three-hole rake type. Sample holes shall be 4 mm in diameter or smaller and located at 16.7, 50, and 83.3 percent of the equivalent stack diameter. Alternatively, a single opening probe may be used so that a gas sample is collected from the centrally located 10 percent area of the stack cross-section.

3.3 **Sample Line.** Stainless steel or Teflon * tubing to transport the sample gas to the analyzer. The sample line should be heated, if necessary, to prevent condensation in the line.

3.4 **Calibration Valve Assembly.** A three way valve assembly to direct the zero and calibration gases to the analyzers is recommended. Other methods, such as quick-connect lines, to route calibration gas to the analyzers are applicable.

3.5 **Particulate Filter.** An in-stack or an out-of-stack glass fiber filter is recommended if exhaust gas particulate loading is significant. An out-of-stack filter should be heated to prevent any condensation.

* Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

3.6 **Recorder.** A strip-chart recorder, analog computer, or digital recorder for recording measurement data. The minimum data recording requirement is one measurement value per minute. Note: This method is often applied in highly explosive areas. Caution and care should be exercised in choice of equipment and installation.

4. Calibration and Other Gases.

Gases used for calibrations, fuel, and combustion air (if required) are contained in compressed gas cylinders. Preparation of calibration gases shall be done according to the procedure in Protocol No. 1, listed in Citation 2 of Bibliography. Additionally, the manufacturer of the cylinder should provide a recommended shelf life for each calibration gas cylinder over which the concentration does not change more than ± 2 percent from the certified value. For calibration gas values not generally available (i.e., organics between 1 and 10 percent by volume), alternative methods for preparing calibration gas mixtures, such as dilution systems, may be used with prior approval of the Administrator.

Calibration gases usually consist of propane in air or nitrogen and are determined in terms of the span value. Organic compounds other than propane can be used following the above guidelines and making the appropriate corrections for response factor.

4.1 **Fuel.** A 40 percent H₂/60 percent N₂ gas mixture is recommended to avoid an oxygen synergism effect that reportedly occurs when oxygen concentration varies significantly from a mean value.

4.2 **Zero Gas.** High purity air with less than 0.1 parts per million by volume (PPMv) of organic material (propane or carbon equivalent) or less than 0.1 percent of the span value, whichever is greater.

4.3 **Low-level Calibration Gas.** An organic calibration gas with a concentration equivalent to 25 to 35 percent of the applicable span value.

4.4 **Mid-level Calibration Gas.** An organic calibration gas with a concentration equivalent to 45 to 55 percent of the applicable span value.

4.5 **High-level Calibration Gas.** An organic calibration gas with a concentration equivalent to 80 to 90 percent of the applicable span value.

5. Measurement System Performance Specifications

5.1 **Zero Drift.** Less than ± 3 percent of the span value.

5.2 **Calibration Drift.** Less than ± 3 percent of span value.

5.3 **Calibration Error.** Less than ± 5 percent of the calibration gas value.

6. Pretest Preparations

6.1 **Selection of Sampling Site.** The location of the sampling site is generally specified by the applicable regulation or purpose of the test; i.e., exhaust stack, inlet line, etc. The sample port shall be located at least 1.5 meters or 2 equivalent diameters upstream of the gas discharge to the atmosphere.

6.2 **Location of Sample Probe.** Install the sample probe so that the probe is centrally located in the stack, pipe, or duct and is sealed tightly at the stack port connection.

6.3 **Measurement System Preparation.** Prior to the emission test, assemble the measurement system following the manufacturer's written instructions in preparing the sample interface and the organic analyzer. Make the system operable.

FIA equipment can be calibrated for almost any range of total organics concentrations. For high concentrations of organics (> 1.0 percent by volume as propane) modifications to most commonly available analyzers are necessary. One accepted method of equipment modification is to decrease the size of the sample to the analyzer through the use of a smaller diameter sample capillary. Direct and continuous measurement of organic concentration is a necessary consideration when determining any modification design.

6.4 Calibration Error Test. Immediately prior to the test series, (within 2 hours of the start of the test) introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level responses. Then introduce low-level and mid-level calibration gases successively to the measurement system. Record the analyzer responses for low-level and mid-level calibration gases and determine the differences between the measurement system responses and the predicted responses. These differences must be less than 5 percent of the respective calibration gas value. If not, the measurement system is not acceptable and must be replaced or repaired prior to testing. No adjustments to the measurement system shall be conducted after the calibration and before the drift check (Section 7.3). If adjustments are necessary before the completion of the test series, perform the drift checks prior to the required adjustments and repeat the calibration following the adjustments. If multiple electronic ranges are to be used, each additional range must be checked with a mid-level calibration gas to verify the multiplication factor.

6.5 Response Time Test. Introduce Zero gas into the measurement system at the calibration valve assembly. When the system output has stabilized, switch quickly to the high-level calibration gas. Record the time from the concentration change to the measurement system response equivalent to 95 percent of the step change. Repeat the test three times and average the results.

7. Emission Measurement Test Procedure

7.1 Organic Measurement. Begin sampling at the start of the test period, recording time and any required process information as appropriate. In particular, note on the recording chart periods of process interruption or cyclic operation.

7.2 Drift Determination. Immediately following the completion of the test period and hourly during the test period, reintroduce the zero and mid-level calibration gases, one at a time, to the measurement system at the calibration valve assembly. (Make no adjustments to the measurement system until after both the zero and calibration drift checks are made.) Record the analyzer response. If the drift values exceed the specified limits, invalidate the test results preceding the check and repeat the test following corrections to the measurement system. Alternatively, recalibrate the test measurement system as in Section 6.4 and report the results using both sets of calibration data (i.e., data determined prior to the test period and data determined following the test period).

8. Organic Concentration calculations

Determine the average organic concentration in terms of PPMv as propane or other calibration gas. The average shall be determined by the integration of the output recording over the period specified in the applicable regulation. If results are required in terms of PPMv as carbon, adjust measured concentrations using Equation 25A-1.

$$C_c = K C_{\text{meas}} \quad \text{Eq. 25A-1}$$

Where:

- C_c = Organic concentration as carbon, PPMv.
- C_{meas} = Organic concentration as measured, PPMv.
- K = Carbon equivalent correction factor.
 - $K = 2$ for ethane.
 - $K = 3$ for propane.
 - $K = 4$ for butane.
 - K = Appropriate response factor for other organic calibration gases.

9. Bibliography

1. Measurement of Volatile Organic Compounds-Guideline Series. U.S. Environmental Protection Agency. Research Triangle Park, NC. Publication No. EPA-450/2-78-041. June 1978. p. 46-54.
2. Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors (Protocol No. 1). U.S. Environmental Protection Agency, Environmental Monitoring and Support Laboratory. Research Triangle Park, NC. June 1978.
3. Gasoline Vapor Emission Laboratory Evaluation-Part 2. U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards. Research Triangle Park, NC. EMB Report No. 75-GAS-6. August 1975.

DRAFT

DCN No.: 93-275-065-55-07
Radian No.: 275-065-55
EPA NO.: 68-D1-0010

This document is a preliminary draft.
It has not been formally released by EPA
and should not at this stage be construed
to represent Agency policy. It is being
circulated for comment on its technical
accuracy and for any implications.

**FIELD TEST OF A GENERIC METHOD FOR
SAMPLING AND ANALYSIS OF ISOCYANATES**

Interim Report
(Work Assignment 55)

Prepared for:

Frank Wilshire
Atmospheric Research and Exposure Assessment Laboratory
Methods Research and Development Division
Source Methods Research Branch
U.S. Environmental Protection Agency
Research Triangle Park, NC 27711

Prepared by:

J. F. McGaughey
S. C. Foster
R. G. Merrill

RADIAN
CORPORATION

P.O. Box 13000
Research Triangle Park, NC 27709

July 1993

DRAFT

This document is a preliminary draft
It has not been formally released by EPA
and should not at this stage be construed
to represent Agency policy. It is being
circulated for comment on its technical
accuracy and policy implications.

DISCLAIMER

The information in this document has been funded wholly by the United States Environmental Protection Agency under EPA Contract Number 68-D1-0010 to Radian. It has been subjected to the Agency's peer and administrative review, and it has been approved for publication as an EPA document. Mention of trade names or commercial products does not constitute endorsement or recommendation for use.

ACKNOWLEDGEMENT

We wish to acknowledge the contributions of the following individuals to the success of this program: Mark Owens, Danny Harrison, Darrell Doerle and Jim Southerland

EXECUTIVE SUMMARY

Isocyanates are used extensively in the production of polyurethane materials such as flexible foam, enamel wire coatings, paint formulations and in binders for the pressed board industry. Because of their widespread use and known adverse physiological effects, several isocyanates have been listed in Title III of the Clean Air Act Amendments of 1990. The isocyanates of interest are: 2,4-toluene diisocyanate (TDI), methylene diphenyl diisocyanate (MDI), 1,6-hexamethylene diisocyanate (HDI) and methyl isocyanate (MI). Previously, no validated sampling and analytical methodology for these compounds relative to stationary sources existed.

The field validation study presented in this report is a culmination of laboratory investigations, performed under previous work assignments, which were designed to develop and evaluate a viable approach for the determination of isocyanate emissions from stationary sources. After the successful completion of the laboratory studies, the sampling and analysis approach was formulated and a field validation test was initiated. At the direction of the EPA, TDI was selected as the primary analyte.

The test site selected was a flexible foam manufacturing facility in High Point, North Carolina, which used TDI in the manufacturing process. The approximate level of TDI in the emission stream was determined by the analysis of samples collected during a presurvey. A sampling scheme was then designed to ensure the collection of sufficient samples to yield statistically valid data. Following the EPA Method 301 protocol, quadruplicate trains (QUAD) were operated simultaneously with four co-located probes. Two of the trains were spiked with TDI and two were unspiked. Samples from eight QUAD runs (minimum of six valid runs required by Method 301) were returned to the laboratory and analyzed according to the analytical procedure developed in laboratory studies. These data were statistically evaluated following Method 301 protocol to determine the performance of the method relative to bias and precision. These results are summarized in the following table. The precision for both the spiked and unspiked trains was less than 5% RSD, which is well within the precision criteria (% RSD < 50)

Method Validation Statistical Summary

Precision ^a	
% RSD for Spiked Samples	3.55 ^b
% RSD for Unspiked Samples	4.72 ^b
Accuracy ^a	
Bias:	-295 μ g
Significant?	No
Correction Factor	1.0 ^c
Recovery ^a	
Amount Spiked (as TDI)	7828 μ g
Average Percent Recovered	95

^aResults are based on the average of seven QUAD runs (14 spiked trains and 14 unspiked trains). TDI was present in the stack emissions and was therefore collected as background in the unspiked trains as well as in the spiked trains.

^bEPA Method 301 requires the precision to be <50% RSD for the method to be acceptable.

^cEPA Method 301 requires the calculated Correction Factor to be between 0.7 and 1.3 for the method to be acceptable.

for an acceptable method as tested. Using the data from all eight runs, the bias was found to be significant at the 95% level of confidence thus requiring the use of a correction factor of 1.053. Using the data from only seven runs (eliminating run number eight due to a questionable leak check for one of the trains) the bias was not significant and therefore did not require the calculation of a correction factor. In either case, the method was well within the bias acceptance criteria (correction factor between 0.7 and 1.3) for an acceptable method as tested.

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1-1
2.0 CONCLUSIONS AND RECOMMENDATIONS	2-1
3.0 FIELD TEST	3-1
3.1 Site Description	3-1
3.2 Sampling Location	3-1
3.3 Test Schedule	3-3
3.4 Sample Collection	3-3
3.4.1 Quad Probe	3-3
3.4.2 Quad-Train Assembly	3-6
3.5 Sampling Preparation	3-6
3.5.1 Glassware Preparation	3-6
3.5.2 Preparation of Impinger Absorbing Solution	3-8
3.5.3 Preparation of TDI Spiking Solution	3-8
3.5.4 Sampling Equipment Preparation	3-9
3.5.5 Sampling Operations	3-10
3.5.6 Sample Recovery	3-13
3.6 Quality Control	3-16
4.0 ANALYTICAL PROCEDURES	4-1
4.1 Sample Preparation	4-1
4.2 Chromatographic Analyses	4-1
4.2.1 Standard Preparation	4-1
4.2.2 Analysis	4-2
4.3 Qualitative Identification	4-3
4.4 Calculations	4-3
4.4.1 Calculation of the Amount of Isocyanate Collected	4-3
4.4.2 Normalization of the Amount of Isocyanate Collected	4-6
4.5 Quality Control	4-12

TABLE OF CONTENTS, continued

	Page
5.0 RESULTS AND DISCUSSION	5-1
5.1 Bias and Precision	5-1
5.2 Breakthrough and Recovery	5-3
5.2.1 Breakthrough	5-3
5.2.2 Recovery	5-6
5.3 Quality Assurance/Quality Control	5-6
5.3.1 Overview of Data Quality	5-8
5.3.2 Sampling Quality Control	5-10
5.3.3 Sample Storage and Holding Time	5-10
5.3.4 Analytical Quality Control	5-10

LIST OF TABLES

	Page
1-1 Isocyanates Listed in the Clean Air Act Amendments'of 1990	1-2
3-1 Test Schedule	3-4
3-2 Sampling Train Test Matrix	3-7
3-3 Quad Train Sample Volumes	3-14
4-1 2,4-TDI Detected in Unspiked Trains, μg	4-7
4-2 2,4-TDI Detected in Spiked Trains, μg	4-9
4-3 Normalized Amount of 2,4-TDI Detected in Unspiked Trains, μg	4-13
4-4 Normalized Amount of 2,4-TDI Detected in Spiked Trains, μg	4-14
5-1 Summary of Method 301 Statistical Calculations	5-2
5-2 Distribution of 2,4-TDI Within the Spiked Trains	5-4
5-3 Distribution of 2,4-TDI Within the Unspiked Trains	5-5
5-4 Percent Recovery of the Spiked 2,4-TDI	5-7
5-5 Data Quality Acceptance Criteria and Results	5-9
5-6 Sampling Train Leak Check Summary	5-11
5-7 Summary of Analytical Quality Control Results	5-12

LIST OF FIGURES

	Page
3-1 Sample Location	3-2
3-2 Schematic of Quad Train Setup	3-5
3-3 Sampling Train for Isocyanate	3-12
4-1 Chromatogram of Unspiked Train	4-4
4-2 Chromatogram of Spiked Train	4-5

Sampling and analytical methods for a particular analyte or group of analytes can be evaluated and validated by demonstrating their performance in field tests, thereby establishing the precision and bias of the methods experimentally. Few methods have been fully validated for sampling and analyzing the organic compounds listed in Title III of the Clean Air Act Amendments of 1990. For some analytes, methods have been validated for sample analysis, but not for sample collection. Full validation for both sampling and analytical methods, for both field and laboratory operations, is available for fewer than 10 percent of the analytes listed in Title III of the Clean Air Act Amendments at any source category. Field validation may be performed by side-by-side comparison of a candidate method to a validated method to establish comparable performance for the same analytes in the same matrix (same source category). Another procedure for validation of a method is to spike known quantities of analytes into the collection apparatus in the field so that the precision and bias of the method can be demonstrated from sample collection through analysis.

EPA, under the authority of Title III of the Clean Air Act Amendments (CAAA) of 1990, requires the identification and validation of sampling and analytical methods for the isocyanate compounds which are listed among the 189 hazardous air pollutants identified in Title III. These isocyanate compounds are listed in Table 1-1. Development of sampling and analytical methods for these four compounds was accomplished under Work Assignments 11, 21, and 40 on EPA Contract No. 68-D1-0010. At the direction of EPA, initial efforts were directed to the measurement of 2,4-toluene diisocyanate (TDI) emissions.

The objective of this work assignment was to validate the isocyanate sampling and analytical test method through field testing at an operating stationary source. The method was validated by collecting flue gas samples for the analysis of 2,4-TDI, and evaluating the data for bias and precision. EPA Method 301, "Field Validation of Pollutant Measurement Methods from Various Waste Media," was used as

Table 1-1

Isocyanates Listed in the Clean Air Act Amendments of 1990

Hexamethylene-1,6-diisocyanate (HDI)

2,4-Toluene diisocyanate (TDI)*

Methylene diphenyl diisocyanate (MDI)

Methyl isocyanate (MI)

*The 2,6 TDI isomer may also be present but is not listed in the CAAA.

a model for the validation protocol. Analyte spiking was used with quadruplicate sampling trains to generate the required data. The field validation was performed at an industrial facility which manufactures flexible foam products. Only two of the quadruplicate trains were spiked for each run. The two unspiked trains were used to establish the background level of target compound in the stack gas.

The sampling method utilizes a Method 5-type sampling train, which operates with a solution of 1-(2-pyridyl) piperazine and toluene in the impingers. Stack gas is extracted from the source through a heated probe and drawn through the impingers. TDI present in the stack gas reacts with the piperazine to form an isocyanate derivative. The quantity of isocyanate is determined by solvent exchange of the toluene solution with acetonitrile followed by high pressure liquid chromatographic (HPLC) analysis.

This report discusses the details of the field validation study. Section 2.0, Conclusions and Recommendations, summarizes the results and provides recommendations for future work. Sections 3.0 and 4.0 provide details of the sampling and analysis procedures respectively. Section 5.0 is a detailed discussion of the procedures, calculations and quality control.

CONCLUSIONS AND RECOMMENDATIONS

Based on the results presented in Section 6.0 of this report, the following conclusions can be made concerning the validity of the method as tested under the conditions described in this report:

- The calculated values for precision (%RSD) for both the spiked and unspiked trains, 3.55 and 4.72 respectively, are both well within the acceptance criteria of less than 50% RSD found in Section 6.3 of the EPA Method 301. Therefore, the method as tested at the source category described meets the precision requirements;
- The method bias, at the concentration levels tested, was found to be significantly different from zero at the 95% level of confidence when the data from all eight runs (minimum of six runs required) were used in the calculations. A correction factor of 1.053 would be required if all eight runs are included in the bias calculation. Good technical reasons exist for excluding one of eight QUAD runs. If this run is eliminated, no bias correction is required. In either case the correction factor is well within the acceptance criteria of 0.7 to 1.3 found in Section 1.2 of the EPA Method 301. Therefore, the method as tested at the source category described meets the bias and correction factor requirements; and
- The method as tested is sufficiently robust to allow testing at sources similar to the source tested in this study where the stack gas moisture is less than 1% by volume, the stack temperature is less than 30 degrees C and the presence of other compounds that may interfere with the analysis are minimal.

Recommendations for future testing and validation of the method for the sampling and analysis of isocyanates include the following:

- Identify a source for testing that has more than one isocyanate present in the stack gas;
- Spike as many of the four CAAA target isocyanates as possible into the train before sampling in order to gain as much information as possible from the field test; and

- Design the condenser between the first and second impinger of the train to more efficiently reduce the loss of toluene from the first impinger and minimize compound breakthrough due entrained aerosols.

3.0 FIELD TEST

The objective of this program was to perform a field test to establish the bias and precision of a sampling and analytical method for isocyanate compounds listed in Title III of the Clean Air Act Amendments of 1990. The method evaluation in this test series resulted from extensive literature reviews, industry consultation and laboratory development. To achieve the test objective, an industrial source with known emissions of TDI was selected as a field test site. Factors in the site selection were easy access, ample space for the quadruple sampling trains and proximity to Radian's office and laboratory in Research Triangle Park, North Carolina.

3.1 Site Description

The field validation test was performed at a flexible foam production plant located in High Point, North Carolina. In the manufacturing process starting materials (TDI, water, a polyether resin, methylene chloride, an amine catalyst, and coloring additives) are blended and continuously fed onto a conveyer belt. The TDI reacts with water and releases CO₂, which causes foaming in the resin material. Dichloromethane (DCM) can be added as a supplemental "blowing" or foaming agent. The heat from the reaction of TDI and water causes the DCM to vaporize, resulting in increased foaming. The density of the foam is controlled by the amount of TDI, water and DCM added. The foaming action continues as the material proceeds down the conveyer belt. Finished product is then allowed to cure and degas for 24 to 48 hours.

3.2 Sampling Location

Figure 3-1 presents a schematic view of the sampling location. Three induced draft (ID) fans are used to exhaust TDI and DCM vapors from the production process through three separate uninsulated sheet metal ducts that extend through the roof. Two of the ducts are connected by a 30-foot horizontal duct, 34 inches in diameter, which then extends vertically to a height of 25 feet above the roof top. A 6 inch




Figure 3-1. Sample Location

diameter sampling port is located in the horizontal duct midway between vertical ducts number 2 and 3, approximately 5 feet above the roof level. The roof level is approximately 15 feet above the ground.

A recovery trailer was located on the ground immediately in front of the sampling area, allowing easy communication between the sampling crew and recovery area. Two-way radio communication between the facility production personnel and the sampling crew allowed coordination between production startup and the start of each sampling run.

3.3 Test Schedule

The recovery trailer and test equipment were mobilized on Saturday, February 20, 1993. Equipment setup took place Saturday afternoon and Sunday, and testing began Monday morning.

The sampling schedule is shown in Table 3-1. Eight runs were completed, which included two extra runs above the required minimum of six.

3.4 Sample Collection

3.4.1 Quad Probe

Sampling was performed by withdrawing stack gas from a single port in the stack through a quad probe, then directing the sampled gas simultaneously to four independently operated sampling trains. The quad probe contains four similar heated sampling probes that were inserted into the stack as one unit, as shown in Figure 3-2. The front end of the quad probe was positioned in the center of the stack and remained

Table 3-1
Test Schedule

Run	Date	Start Time	Stop Time
1	2-22-93	1215	1300
2	2-22-93	1330	1410
3	2-23-93	0945	1085
4	2-23-93	1335	1415
5	2-24-93	1010	1110
6	2-24-93	1335	1420
7	2-25-93	1215	1255
8	2-25-93	1315	1355




Figure 3-2. Schematic of Quad Train Setup

in that location during each test. The stack was not traversed nor were stack gas velocity measurements made, because determination of the true concentration and emission rate of the target compound in the stack gas was not required to meet the objectives of this program.

Method 301 of 40 CFR Part 63 describes field validation procedures and details the criteria for the quadruple sampling probe tip arrangement. This method requires the inside edge of sampling probe tips to be situated in a 6.0 cm x 6.0 cm square area. The area encompassed by the probe tip arrangement should occupy less than 5% of the stack cross-sectional area. The cross-sectional area of the probe tip arrangement used in this test was 5.8 square inches as measured from the probe/nozzle centerlines. This area is less than 1% of the stack cross-sectional area of 908 square inches, which satisfies the Method 301 criterion.

3.4.2 Quad-Train Assembly

Four independent sampling trains made up the quad-train assembly. Although four meter boxes were required, the velocity head (ΔP) was determined using only one set of pitot tubes. The sampling trains were identified as Train A, B, C, and D. Two of the four trains were spiked before each run. The spiking compound was added to the first impinger of these trains in the field for bias determination. The sampling train test matrix is given in Table 3-2.

3.5 Sampling Preparation

3.5.1 Glassware Preparation

All glassware used for sampling was thoroughly cleaned prior to use. This included the probe, impingers, all sample bottles and all utensils used during sample recovery. All glassware was washed with hot soapy water, rinsed with hot tap water, rinsed with distilled water and baked in a oven at 300 °C for four hours. The glassware

Table 3-2

Sampling Train Test Matrix

Run #	Train Designation	
	Spiked	Unspiked
1	A, B	C, D
2	C, D	A, B
3	A, B	C, D
4	C, D	A, B
5	A, B	C, D
6	C, D	A, B
7	A, B	C, D
8	C, D	A, B

was then triple-rinsed with HPLC grade acetonitrile, followed by triple-rinsing with HPLC grade toluene. Open ends of glassware were covered with aluminum foil to minimize potential contamination during transportation and set-up.

3.5.2 Preparation of Impinger Absorbing Solution

Historical data available from the host test site facility and data resulting from the collection of preliminary samples by Radian indicated that the concentration of TDI in the process exhaust was 1 ppm or less, depending on the density of foam being produced on any given day. At this concentration, a 30 cubic foot sample size would result in the collection of approximately 7 mg of TDI. Using the reaction stoichiometry of two moles of 1,2-PP per mole of TDI, the piperazine in toluene solution was then prepared at a concentration level three times the calculated minimum needed, or 133 $\mu\text{g}/\text{mL}$. This would provide a total of approximately 40 mg of 1,2-PP in 300 mL of impinger solution in the first impinger available for reaction with TDI. At this concentration, approximately 22 mg of TDI could be collected in the first impinger before the reagent was exhausted. This solution was prepared in the laboratory just prior to use in the field, and was used within 10 days of preparation.

3.5.3 Preparation of TDI Spiking Solution

The TDI spiking solution was prepared at a concentration of 1.5 mg of the derivatized TDI per 1 mL of acetonitrile. Fifteen mL of this spiking solution was spiked into the first impinger of two of the four trains prior to each QUAD run. This spiking scheme resulted in a total spike amount of derivatized TDI of 22.5 mg, which is equivalent to 7.83 mg of underivatized TDI. This is an amount equivalent to the amount of TDI expected to be collected in the train from the stack gas based on presurvey samples. Therefore, the amount present in the two spiked trains was designed to be at least twice the amount present in the two unspiked trains.

3.5.4 Sampling Equipment Preparation

Final sampling train preparations included calibration and leak checking of all the train equipment, including meter boxes, thermocouples, nozzles, pitot tubes, and umbilicals. Reference calibration procedures were followed when available, and the results were properly documented and archived. If a referenced calibration technique for a particular piece of apparatus was not available, then a state-of-the-art technique was used. A discussion of the techniques used to calibrate this equipment is presented below.

S-Type Pitot Tube Calibration

The EPA has specified guidelines concerning the construction and geometry of an acceptable S-Type pitot tube. If the specified design and construction guidelines are met, a pitot tube coefficient of 0.84 can be used. Information pertaining to the design and construction of the Type-S pitot tube is presented in detail in Section 4.1.1 of EPA Document 600/4-77027b. Only S-Type pitot tubes meeting the required EPA specifications were used. Pitot tubes were inspected and documented as meeting EPA specifications prior to field sampling.

Sampling Nozzle Calibration

Glass nozzles were used for sampling. All nozzles were thoroughly cleaned, visually inspected for damage, and calibrated according to the procedure outlined in Section 4.4.2 of EPA Document 600/4-77-027b.

Dry Gas Meter Calibration

Dry gas meters (DGMs) were used in the sample trains to measure the sample volume and sampling rate. All DGMs were calibrated to document the volume correction factor prior to the departure of the equipment to the field. Post-test

calibration checks were performed after the equipment was returned to Radian's laboratory. Pre- and post-test calibrations agreed to within 5 percent.

Prior to calibration, a positive pressure leak check of the system was performed using the procedure outlined in Section 4.3.2 of EPA Document 600/4-77-23b. The system was placed under approximately 10 inches of water pressure and an oil manometer was used to determine if the pressure decreased over a one-minute period.

After the sampling console was assembled and leak checked, the pump was allowed to run for 15 minutes to allow the pump and DGM to warm up. The valve was then adjusted to obtain the desired flow rate. For the pre-test calibrations, data were collected at the orifice manometer settings (ΔH) of 0.5, 1.0, 1.5, 2.0, 3.0, and 4.0 inches of water. Gas volumes of 5 ft³ were used for the two lower orifice settings, and volumes of 10 ft³ were used for the higher settings. The individual gas meter correction factors (γ_i) were calculated for each orifice setting and averaged. The method requires that each of the individual correction factors fall within $\pm 2\%$ of the average correction factor or the meter must be cleaned, adjusted, and recalibrated. In addition, Radian requires that the average correction factor be 1.00 ± 1 percent. For the post-test calibration, the meter was calibrated three times at the average orifice setting and vacuum which were used during the actual test.

Dry gas meter calibrations were performed at Radian's laboratory using an American[®] wet test meter as an intermediate standard. The intermediate standard is calibrated every six months against the EPA spirometer at EPA's Emission Measurement Laboratory in Research Triangle Park (RTP), North Carolina.

3.5.5 Sampling Operations

Vent gas samples were collected isokinetically from a single sampling point located in the center of the duct. Preliminary information about the stack gas velocity useful in selecting nozzle size and calculating the K-factor was obtained during the

pre-site survey. Prior to testing, a leak check of pitot lines was performed according to EPA Method 2. Oxygen (O₂) and carbon dioxide (CO₂) concentrations were ambient levels as determined by EPA Method 3. The stack gas moisture data was measured by the host facility as the relative humidity.

Preparation of Sampling Train

The four sampling trains for each QUAD run were charged and assembled in the recovery trailer. The impinger buckets were marked as Train A, B, C, or D. Tared impingers were used. Approximately 300 mL of the absorbing reagent was transferred to the first impinger and 200 mL to the second impinger. The first impinger of each train was of a Greenburg-Smith design and all remaining impingers were of the modified Greenburg-Smith design. The third impinger was empty, 200 to 300 g of silica gel was placed in the fourth impinger and 400 g of charcoal was placed in the fifth impinger. A water jacketed condenser was placed between the outlet of the first impinger and the inlet to the second impinger to promote cooling and minimize evaporative losses of toluene from the first impinger. Fifteen (15) mL of the spiking solution was pipetted into the first impinger of Trains A and B. Openings were covered with Teflon® film or aluminum foil after the assembly of the trains.

Final assembly of the sampling trains occurred at the sampling location. The complete train configuration is shown in Figure 3-3. Thermocouples were attached to measure the stack temperature and probe outlet and impinger outlet temperatures. Crushed ice was added to each impinger bucket, and the probe heaters were turned on and allowed to stabilize at $120^{\circ} \pm 12^{\circ}\text{C}$ ($248^{\circ} \pm 25^{\circ}\text{F}$).

The isocyanate trains were leak checked before and after each sampling run, as required in EPA Method 5. To leak check the assembled train, the nozzle end was capped off and the sampling train evacuated to a vacuum of 15 inches of Hg. After the system was evacuated and the pump isolated from the train, the volume of gas flowing through the system was timed for 60 seconds. The leak rate is required to be




Figure 3-3. Sampling Train for Isocyanate

less than 0.02 acfm or 4% of the average sampling rate, whichever is less. After the leak rate was determined, the cap was slowly removed from the nozzle end until the vacuum in the train returned to atmospheric pressure and then the pump was turned off.

The leak rates and sampling start and stop times were recorded on the sampling task log. Also, any other events that occur during sampling were recorded on the task log (such as pitot cleaning, thermocouple malfunctions, heater malfunctions, and any other unusual occurrences). A nominal sample size of 30 cubic feet was collected in all sampling train. This was accomplished by sampling at a flowrate of 0.5 cubic feet per minute for 60 minutes. The sample volumes for each train by QUAD run are presented in Table 3-3.

3.5.6 Sample Recovery

The sample bottles containing the probe and nozzle washings and the impinger portion of the sampling trains were moved to the recovery trailer.

Each impinger was carefully removed from the impinger bucket, the outside was wiped dry, and the final impinger weight was determined and recorded to calculate stack moisture. The isocyanate sample was then collected in the following two fractions:

- First impinger contents, toluene rinses from the nozzle/probe liner and toluene/acetonitrile rinses of the first impinger and connecting glassware; and
- Contents and toluene/acetonitrile rinses from the second and third impingers and the condenser.

Recovery procedures are detailed in this section. All recovery bottles were wide mouth amber glass with Teflon® lined lids.

Table 3-3.

Quad Train Sample Volumes

Date	Run Number	Train A Vm @ 68° (ft ³)	Train B Vm @ 68° (ft ³)	Train C Vm @ 68° (ft ³)	Train D Vm @ 68° (ft ³)
2/22/93	1	33.42	33.89	33.02	33.04
2/22/93	2	29.07	29.65	28.67	28.40
2/23/93	3	34.24	35.15	33.75	33.01
2/23/93	4	30.60	31.17	30.35	29.54
2/24/93	5	34.14	34.70	34.46	32.59
2/24/93	6	35.10	35.17	34.49	33.78
2/25/93	7	31.11	31.94	30.14	29.91
2/25/93	8	30.89	29.73	30.49	31.95

Container 1 - Probe and First Impinger Contents

The contents and rinses of each of the first impingers and first impinger connectors were combined with the corresponding probe/nozzle washing solution. The entire contents of the first impinger were recovered as a single sample, even if two phases were present. The first impinger and connecting tubing were rinsed three times with 15 mL aliquots of toluene. A final rinse of the impinger with acetonitrile was also necessary to remove any water left on the impinger wall and to recover any remaining derivatized TDI.

Container 2 - Second and Third Impinger Contents/Condenser Rinse

The contents and toluene/acetonitrile rinses of the second and third impingers and the condenser of each train were collected in the same manner used for the first impinger described above. The contents of these impingers were analyzed separately from the contents collected in the first impinger to check for breakthrough; therefore, care was taken to avoid physical carryover from the first impinger to the second. The contents of the fourth and fifth impingers were weighed as previously described and then discarded.

Field Blanks

Four field blanks were prepared and recovered during the test, one on each day of testing. The four field blanks were prepared using Trains A, B, C, and D from the two sets of glassware used during the testing. A sampling train was assembled in the staging area, taken to the sampling location, and leak-checked. The probe of the blank train was heated during the generation of the field blank, but no gas sample was passed through the sampling train. The sampling train for the field blank was recovered with the same procedure described for authentic source samples..

Reagent Blank(s)

Aliquots of each lot of toluene, acetonitrile and absorbing reagent were collected daily to be analyzed as reagent blanks.

Sample Storage and Shipping

Sample containers were checked to ensure that complete labels had been affixed. The labels identified Trains A, B, C, or D, as appropriate. Teflon® lids were tightened and secured with Teflon® tape. The sample bottles were stored in a cooler packed with ice and were returned to Radian's laboratory in these coolers at the end of the field test.

3.6 Quality Control

The following quality control measures were implemented during the field testing phase of this program:

- All dry gas meters were calibrated. Calibration procedures were followed for the pitot tube/probe assembly and all thermocouple readout devices.
- Temperatures of the sampling train were maintained at the specified setting ($120 \pm 12^\circ\text{C}$) during each sampling run at levels prescribed in the test plan.
- Sampling trains were leak-checked both prior to and after sampling.
- All glassware was washed and oven-baked following appropriate method protocol, given in the test plan.
- All recovery solvents were HPLC grade and an aliquot of each was collected daily as reagent blanks.
- One field blank was collected for every two sampling runs.

- Chain of Custody forms and log books were filled in at the completion of each day of sampling.

4.0 ANALYTICAL PROCEDURES

4.1 Sample Preparation

The samples were received in the laboratory in screw-capped glass bottles with Teflon®-lined caps, sealed with Teflon® tape and stored in coolers packed with ice. Samples were logged into the laboratory sample tracking system and stored in a secure, refrigerated (4°C) sample storage area prior to analysis. Samples were prepared for analysis within 30 days of collection and analyzed within 30 days of preparation.

All labware was washed with detergent and water and rinsed with hot tap water, rinsed with deionized water, baked at 300°C, rinsed with acetonitrile and toluene prior to use. Solvents used were HPLC grade or equivalent.

Each of the two recovered samples from each train was transferred along with rinses to separate 500 mL round bottom flasks and then evaporated to dryness under vacuum in a 65°C water bath. Each round-bottom flask was then rinsed three times with separate two (2) mL aliquots of acetonitrile (ACN) and the rinses transferred to a 10-mL volumetric flask. The sample was then brought to volume with ACN and transferred to a 15-mL vial and sealed with a Teflon®-lined lid. The vial was stored in a refrigerated sample storage area at 4°C until analysis.

4.2 Chromatographic Analyses

The procedures for the HPLC analyses of the samples are described in the following sections.

4.2.1 Standard Preparation

A 300 µg/mL stock solution of TDI piperazine urea derivative was prepared by dissolving 7.5 mg of the purified crystals of the derivatized TDI in 25 mL of

ACN. [The derivatized TDI was previously prepared by adding 1 g of the neat TDI to a solution of 1-(2-pyridyl) piperazine in ACN, evaporating to dryness and recrystallizing the urea derivative three times from ACN.] Working standards for the calibration curve were made from this stock at six concentration levels in ACN ranging from 0 to 50 $\mu\text{g}/\text{mL}$. This concentration range covered the amount of TDI expected to be collected at the host facility. This stock solution was also used to prepare the field spiking solution. A check standard was prepared from a separately prepared stock solution. This check standard fell in the middle of the calibration curve.

4.2.2 Analysis

HPLC System

The HPLC system operating parameters for analysis of standards and samples were as follows:

Instrument:	RAININ HPXL Delivery System Waters 710B WISP autosampler
Data System:	Nelson 2600 (1 volt)
Column:	Zorbax ODS (4.6 mm ID x 25 cm)
Mobile Phase:	Acetonitrile/0.1M Ammonium Acetate Buffer
Gradient:	25:75 ACN/0.1 m ammonium acetate buffer, pH 6.2, hold 2 minutes, then to 60:40 by 19.5 minutes.
Detector:	RAININ Dynamax Dual-Wavelength, Ultraviolet at 254 nm
Flow Rate:	2 mL/min
Injector Volume:	50 μL
Retention Time:	2,4-TDI, 10.2 min.; 2,6-TDI 8.5 min.

Instrument Calibration

Calibration standards were prepared at seven levels as described in Section 4.2.1. Each calibration standard was injected in duplicate. Linear regression analysis of peak area response versus concentrations of TDI was used to prepare a calibration curve. Linearity of the calibration curve was confirmed by visual inspection and verified by a correlation coefficient of 0.9995. After an initial calibration curve was obtained, the calibration check standard described in Section 4.2.1 was analyzed. This standard was injected after every 3 samples, and was used for daily calibration. This check standard consistently agreed to within 10% of the true value.

All samples were analyzed in triplicate on the HPLC. An acetonitrile blank was analyzed once per day to ensure that the system was not contaminated. A check standard was analyzed prior to sample analysis, after every 3 samples, and at the end of the sample analysis each day.

4.3 Qualitative Identification

Analytes were identified by retention time. The retention time for 2,4-TDI was 10.2 min and 8.5 min for 2,6-TDI. Figures 4-1 and 4-2 show chromatograms from the analysis of first impinger contents from QUAD run number 4 for the unspiked and spiked trains respectively. As seen in the chromatograms, the TDI peaks are well separated from the peak for unreacted 1-2 PP. The peak at 17.5 min. was not identified.

4.4 Calculations

4.4.1 Calculation of the Amount of Isocyanate Collected

A least squares linear regression analysis of the calibration data was used to calculate a correlation coefficient, slope, and intercept. Concentration was used as the independent or X-variable and response was used as the dependent or Y-variable.

Unspiked Train
Quad Run Number 4




Figure 4-1. Chromatogram of Unspiked Train




Figure 4-2 Chromatogram of Spiked Train

The concentration of isocyanate (as the derivative) in the concentrated samples was then calculated as follows:

$$\text{Concentration} = \frac{(\text{Sample Response} - \text{Intercept})}{\text{Slope}} \quad 4-1$$

The total amount (μg) collected in a sample was then calculated by multiplying the concentration ($\mu\text{g}/\text{mL}$) times the final volume (10 mL) of ACN used to redissolve the concentrated sample.

$$\text{Amount TDI derivative} = \text{Concentration } (\mu\text{g}/\text{mL}) \times \text{Final Volume (10 mL)} \quad 4-2$$

The equivalent amount of TDI required to generate this much derivative was calculated by multiplying the ratio of the molecular weights of TDI (174) and the TDI derivative (501) times the amount of TDI derivative (determined by using equation 4-2).

The total amount of 2,4-TDI (underivatized) collected in the unspiked and spiked trains is given in Table 4-1 and Table 4-2 respectively.

4.4.2 Normalization of the Amount of Isocyanate Collected

In order to simplify the comparison of the analytical results of the four trains in each QUAD run for subsequent calculations of bias and precision, the test plan called for the collected of 30 ft^3 of sample in each train. Due to operational variabilities inherent to each train, accurate but slightly differing sample volumes resulted as shown in Table 3-3. Therefore, it was necessary to normalize the data presented in Tables 4-1 and 4-2 to a common sample volume. The sample volume to which all data were normalized was selected to be 35.31 ft^3 which is equivalent to 1m^3 . The following stepwise calculations were used to normalize the data. The data from QUAD run number 1 are used as an example.

SENT BY:


U-21-31 + 0-3/MS

E:\S3253F6.PTS Printed on 09-10-1993 at 12:29:41

Offset: 0 cts

Data File =
Start time: 0.00 min.
Full Range: 50 K-Counts

Preliminary Data



Radiation
10 checks
10
Total in Table

Preliminary Data

Quantitative Standard
23 ug each




Table 4-1

2,4-TDI Detected in Unspiked Trains, µg

Train ¹	QUAD Run No.											
	1			2			3			4		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	--	--	--	5114	61	5175	--	--	--	1832	16	1848
B	--	--	--	5224	40	5264	--	--	--	1864	24	1888
C	4409 ²	18	4427	--	--	--	3281	32	3313	--	--	--
D	4416	85	4501	--	--	--	2928	33	2960	--	--	--

¹The unspiked trains alternated from run to run, C and D then A and B.

²All values are in micrograms of underivatized TDI.

Table 4-1 (Continued)

Train ¹	QUAD Run No.											
	5			6			7			8		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	--	--	--	7880	105	7993	--	--	--	3521	53	3574
B	--	--	--	7488	89	7577	--	--	--	3805	50	3855
C	4810	17	4827	--	--	--	2160	23	2183	--	--	--
D	5054	42	5096	--	--	--	2180	36	2216	--	--	--

¹The unspiked trains alternated from run to run, C and D then A and B.

²All values are in micrograms of underivatized TDI.

Table 4-2
2,4-TDI Detected in Spiked Trains, µg

Train ¹	QUAD Run No.											
	1			2			3			4		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	11943 ²	64	12007	--	--	--	11488	36	11524	--	--	--
B	11301	28	11329	--	--	--	12024	38	12062	--	--	--
C	--	--	--	12045	35	12080	--	--	--	9329	58	9387
D	--	--	--	12454	49	12503	--	--	--	9429	26	9455

¹The spiked trains alternated from run to run, A and B then C and D.

²All values are in micrograms of underivatized TDI.

Table 4-2 (Continued)

Train ¹	QUAD Run No.											
	5			6			7			8		
	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total	Imp 1	Imp 2	Total
A	12014	45	12059	--	--	--	10094	46	10140	--	--	--
B	12588	37	12625	--	--	--	9003	40	9043	--	--	--
C	--	--	--	15201	88	15289	--	--	--	10561	45	10606
D	--	--	--	15173	96	15269	--	--	--	10315	44	10359

¹The spiked trains alternated from run to run, A and B then C and D.

²All values are in micrograms of underivatized TDI.

Step 1 Normalize unspiked Trains C and D first impinger amounts (μg) to the sample volume collected (cubic feet) in spiked Train A;

$$\text{Train C} \quad \frac{33.42 \text{ ft}^3}{33.02 \text{ ft}^3} \times 4409 \mu\text{g} = 4462 \mu\text{g} \quad 4-3A$$

$$\text{Train D} \quad \frac{33.42 \text{ ft}^3}{33.04 \text{ ft}^3} \times 4416 \mu\text{g} = 4467 \mu\text{g} \quad 4-3B$$

Step 2 Average the normalized, unspiked train amounts from step 1 above. Assuming the collection efficiency of all trains to be the same, this value would also be the amount of TDI that would be collected by Train A due to sampling the stack gas;

$$\frac{4462 \mu\text{g} + 4467 \mu\text{g}}{2} = 4465 \mu\text{g} \quad 4-4$$

Step 3 Subtract the average value (step 2) from the uncorrected amount (sampled amount plus spike) for spiked Train A, first impinger, to get recovered spike amount;

$$11943 \mu\text{g} - 4465 \mu\text{g} = 7478 \mu\text{g} \quad 4-5$$

Step 4 Normalize the amount collected in spiked Train A, first impinger to 35.31 ft^3 using the sample volume for Train A and the value obtained in step 2;

$$\frac{35.31 \text{ ft}^3}{33.42 \text{ ft}^3} \times 4465 \mu\text{g} = 4718 \mu\text{g} \quad 4-6$$

Step 5 Normalize the amount collected in the second impinger of spiked Train A to 35.31 ft^3 using the sample volume for Train A and the amount determined by HPLC;

$$\frac{35.31 \text{ ft}^3}{33.42 \text{ ft}^3} \times 63.9 \text{ } \mu\text{g} = 67.5 \text{ } \mu\text{g} \quad 4-7$$

Step 6 Sum the values determined from steps 3, 4 and 5 to get the total amount of TDI found in spiked Train A, normalized to 35.31 ft³;

$$7478 \text{ } \mu\text{g} + 4718 \text{ } \mu\text{g} + 67.5 \text{ } \mu\text{g} = 12264 \text{ } \mu\text{g} \quad 4-8$$

Steps 1-6 can be repeated for similar calculations for spiked Train B. The total amount of TDI collected in each of the unspiked trains can be determined by first normalizing the amounts found in the two impingers of each train to 1m³ and then summing the two values. The raw and normalized data for all analysis results are presented in Appendix A. The resulting normalized values are summarized in Tables 4-3 and 4-4.

4.5 Quality Control

Quality control procedures that were implemented for this program include:

- Adhering to applicable sampling and analysis protocols;
- Collecting and analyzing field blanks, trip blanks, reagent blanks, and laboratory blanks;
- Tracking samples from collection to analysis;
- Calibrating all analytical equipment prior to use;
- Maintaining accurate and complete written documentation;
- If any changes were made to the analytical system (i.e., column changed, column maintenance), a calibration check was performed to verify the validity of the calibration curve. If the calibration check did not meet acceptance criteria, the analytical system was recalibrated.

Table 4-3
Normalized Amount of 2,4-TDI Detected in Unspiked Trains, μg

Train ¹	QUAD Run No.							
	1	2	3	4	5	6	7	8
A	--	6287	--	2132	--	8042	--	4086
B	--	6270	--	2139	--	7608	--	4579
C	4735 ²	--	3466	--	4947	--	2557	--
D	4811	--	3166	--	5522	--	2616	--

¹The unspiked trains alternated from run to run, C and D then A and B.

²All values are in micrograms of underivatized TDI, normalized to a sample volume of 35.31 ft³ (1m³).

Table 4-4

Normalized Amount of 2,4-TDI Detected in Spiked Trains, μg

Train ¹	QUAD Run No.							
	1	2	3	4	5	6	7	8
A	12264 ²	--	11625	--	12233	--	10450	--
B	11520	--	12078	--	12717	--	9290	--
C	--	13258	--	9694	--	15471	--	11197
D	--	13733	--	9805	--	15610	--	10947

¹The spiked trains alternated from run to run, A and B then C and D.

²All values are in micrograms of underivatized TDI, normalized to a sample volume of 35.31 ft³ (1m³).

- Analysis of field spiked QC samples; and
- Analysis of check standards every 3 samples.

This section presents the results of the eight sampling runs relative to the criteria for method precision and bias. Fractional results are also presented to show the amount of isocyanate breakthrough occurring in the impinger train. All sample fractions were prepared and analyzed for toluene diisocyanate at Radian's Research Triangle Park laboratory.

5.1 Bias and Precision

Table 5-1 is a summary table which presents the results of the statistical evaluation of the test data following the EPA Method 301 criteria showing the method precision and bias for 2-4 TDI. Method 301 requires valid data from a minimum of six QUAD runs. Table 5-1 presents data from all eight runs. Precision is shown as the percent relative standard deviation of the measured amounts of TDI in the samples. Results for precision of both the spiked and unspiked samples were less than 5 percent RSD, which is well within the limits of acceptable precision (upper limit of 50%) given in EPA Method 301.

Using the data from all eight QUAD runs, method bias was measured at -395 micrograms. This value was determined to be statistically significant at the 95% confidence level, using the t statistic calculated for the analytical data. A correction factor of 1.053 was calculated for use with the method to compensate for the bias should the method be used to measure TDI emissions from similar sources.

Using the data from only seven QUAD runs (eliminating run 8 because this run had the lowest average % recovery and the final leak check for one of the trains was questionable), the method bias was -295 micrograms. This bias was not statistically significant and therefore no correction factor was calculated. In either case, the criteria for an acceptable method were met (i.e., a correction factor between 0.7 and 1.3).

Table 5-1

Summary of Method 301 Statistical Calculations

Parameter	Spiked Trains		Unspiked Trains	
	7 Runs	8 Runs	7 Runs	8 Runs
Spiked Amount ¹	7828	7828	--	--
RSD, %	3.6	3.4	4.7	5.2
Average Bias ¹	-295	-395	--	--
Bias Significant?	No	Yes	--	--
Correction Factor	1.0	1.053	--	--

¹Values are presented as μg of underivatized TDI

This section presents details of the breakthrough and recovery results for the field samples, as well as recovery information for the spiked compound (2,4-TDI).

5.2.1 Breakthrough

Tables 4-1 and 4-2 provide a summary of the combined total mass of 2,4-TDI collected in the probe/first impinger and second/third impinger samples for the unspiked and spiked trains, respectively. These totals are used as a basis for calculating breakthrough of the TDI from the first impinger to the second impinger. The mass of compound found in the probe/first impinger fraction and in the second impinger fraction were each divided by the total mass of TDI for that train and then multiplied by 100 to yield the percent of the total TDI found in the separate train sections. The results are presented in Table 5-2 and 5-3 for the spiked and unspiked trains respectively.

The average breakthrough for the spiked trains was 1.5% and for the unspiked trains 1.1%. More than 98% of the TDI was collected in the first impinger under the sampling conditions used in this study.

The amount of the toluene contained in the first impingers of each of the trains was reduced by approximately 25% (by weight) during the sampling run due to evaporation. The second impingers showed, on the average, a net gain of approximately 5%. The remainder was collected in the silica gel and the charcoal, both of which showed net weight gains. The total weight gained in the train components following the first impinger more than compensate for losses from the first impinger, probably due to the collection of a small amount of moisture. The loss of toluene from the first impinger was minimized by keeping the impingers in an ice bath and placing a water cooled condenser between the outlet of the first impinger and the inlet of the second impinger.

Table 5-2

Distribution of 2,4-TDI Within the Spiked Trains

Train ¹	Impinger No.	QUAD Run No.							
		1	2	3	4	5	6	7	8
A	1	98.5 ²	--	99.0	--	99.0	--	98.0	--
	2	1.5	--	1.0	--	1.0	--	2.0	--
B	1	99.2	--	99.1	--	99.2	--	97.0	--
	2	0.8	--	0.9	--	0.8	--	3.0	--
C	1	--	99.2	--	96.4	--	98.8	--	98.4
	2	--	0.8	--	3.6	--	1.2	--	1.6
D	1	--	99.0	--	98.5	--	98.7	--	98.4
	2	--	1.0	--	1.5	--	1.3	--	1.6
Average/ % RSD	1	98.5/0.81							
	2	1.5/54.4							

¹Spiked Trains alternate from run to run, A and B, then C and D.

²Values are a percentage of the total amount of 2-4 TDI determined to be in each train.

Table 5-3

Distribution of 2,4-TDI Within the Unspiked Trains

Train ¹	Impinger No.	QUAD Run No.							
		1	2	3	4	5	6	7	8
A	1	--	98.8	--	99.1	--	98.7	--	98.5
	2	--	1.2	--	0.9	--	1.3	--	1.5
B	1	--	99.2	--	98.8	--	98.8	--	98.7
	2	--	0.8	--	1.2	--	1.2	--	1.3
C	1	99.6 ²	--	99.0	--	99.6	--	99.0	--
	2	0.4	--	1.0	--	0.4	--	1.0	--
D	1	99.1	--	98.9	--	99.2	--	98.4	--
	2	1.9	--	1.1	--	0.8	--	1.6	--
Average/ % RSD	1	98.9/0.41							
	2	1.1/37.1							

¹Unspiked Trains alternate from run to run, C and D, then A and B.

²Values are a percentage of the total amount of 2,4-TDI determined to be in each train.

One of the objectives of this test program was to obtain bias and precision data to validate the proposed test method for isocyanates. Samples from two of the four trains of each quad assembly were spiked with TDI before each sampling run. The estimation of method bias is based on the percentage of the TDI spikes recovered. Analytical results used for this calculation are the averages of the triplicate analysis results for each spiked sample. A summary of the spiked TDI recovery percentages is presented in Table 5-4.

The percent recovery was calculated for each spiked train for each run following the calculation procedures outlined in steps 1-3 of Section 5.0. The value obtained at step 3, the amount of spike recovered, is divided by the actual amount of TDI spiked, 7827 μg , multiplied by 100. An average recovery was determined by averaging the 16 individual run recoveries.

The recovery for TDI ranged between 83 and 112 percent and averaged 95 percent with a %RSD of 8.2.

5.3

Quality Assurance/Quality Control

As a part of the testing for Work Assignment No. 55, Radian designed and implemented a quality assurance/quality control (QA/QC) effort tailored to meet the specific needs of this project. The testing was conducted in accordance with QA/QC procedures described in the Quality Assurance Project Plan (QAPP). The results of the QA/QC effort demonstrate that the data are reliable and meet project objectives for completeness and representativeness. The data met the QA objectives for precision and accuracy and there are no data quality issues that effect conclusions regarding the objectives of this project.

Table 5-4
Percent Recovery of the Spiked 2,4-TDI

Train ¹	QUAD Run No.							
	1	2	3	4	5	6	7	8
A	96 ²	--	106	--	89	--	100	--
B	86	--	112	--	96	--	86	--
C	--	89	--	97	--	98	--	88
D	--	95	--	98	--	99	--	83
Average	95							
% RSD	8.2							

¹Spiked Trains alternated from run to run, A and B, then C and D.

²Values are a percentage based upon a spiked amount of 7827.8 µg as 2,4-TDI.

The primary objectives of the QA/QC effort were to control, assess, and document data quality. In order to accomplish these objectives, the QA/QC approach consisted of the following key elements:

- Definition of data quality objectives that reflect the overall technical objectives of the project;
- Design of a sampling, analytical, QA/QC, and data analysis system to meet these objectives; and
- Initiation of corrective action when measurement system performance did not meet the specifications.

These elements include the use of selected standard sampling and analytical procedures as components of the overall approach in addition to, specified calibration requirements, QC checks, data reduction and validation procedures, and sample tracking.

A summary of analysis results for QA/QC samples, which includes measures of precision and accuracy and limitations in the use of these data is presented in this section.

5.3.1 Overview of Data Quality

The QAPjP established specific QA objectives for precision (15% RSD), accuracy ($\pm 30\%$), and completeness (100%) for the determination of TDI emissions. The statistical results presented in Table 5-1 and the % recovery values given in Table 5-4 show that the objectives were met. The data quality acceptance criteria and the experimental results are summarized in Table 5-5. Results for spike/spike duplicates and triplicate analyses were compared with the criteria. In all cases the criteria were met. Other data quality indicators for each type of analysis are also presented throughout the remainder of Section 5.3.

There are no cases where data quality issues impair the study's conclusions with respect to the validity of the sampling and analytical test method procedures. With

Table 5-5

Data Quality Acceptance Criteria and Results

Parameter	Criteria	Results
TDI Spike Recovery	70 - 130%	83 - 112%
TDI Analysis Results QUAD Train, % RSD	15%	5%
Individual DGM Correction Factor Agreement	±2% of Avg	<2%
Analytical Balance	≤0.1 g of Class S Weights	<0.1 g
HPLC Linearity Correlation Coeff.	>0.995	0.9995
HPLC Retention Time Variation	±15%	±10%
HPLC Calibration Check	±10% of Curve	±9%
HPLC System Blank	<0.1% Analyte level	<0.1%
HPLC Replicate Analyses	±10% of 1st injection	±2%
HPLC Method Spikes	±20% of theoretical	±5%

exception of a limited number of samples, the quality of measurement data generated for the test parameters fully meets the data quality objectives outlined in the QAPP.

5.3.2 Sampling Quality Control

Quality control activities associated with the field sampling are described in the QAPP. These activities include adherence to accepted reference method protocols, use of standardized data recording sheets, equipment calibration, and collection of field blanks.

Stack sampling QC data, including sampling rates, sample volume collected, maximum recorded leak rate, and maximum allowable leak rate, are summarized in Table 5-6 for each run. All of the data quality indicators are within acceptable limits, with the exception of a slightly high leak rate value for Train C Run 8. However, this train was leak checked at a vacuum of 7 inches of mercury which was almost twice that achieved during sampling and the leak would therefore have very little, if any, effect on the data. The leak rate criterion is <4% of the average sampling rate or 0.02 dscf, whichever is less.

5.3.3 Sample Storage and Holding Time

Sample hold times specified in the QAPP were met for all samples. All samples were prepared within 30 days of collection and analyzed within 30 days of preparation.

5.3.4 Analytical Quality Control

Results for method spikes, field spikes, field blanks, reagent blanks and method blanks are summarized in Table 5-7. These samples served the dual purpose of controlling and assessing measurement data quality, and providing the basis for precision and accuracy estimates. The QC acceptance criteria for each of these types of samples

Table 5-6

Sampling Train Leak Summary

Rm Number	Std. Metered Volume (dscf)	Average Sampling Rate (dscfm)	Maximum Leak Check (dscf @ in Hg)	4% Sample Rate (dscfm)	Acceptable ^a Leak Rate?
1A	33.42	0.743	0.010 @ 10	0.030	Yes
1B	33.89	0.753	0.010 @ 15	0.030	Yes
1C	33.02	0.734	0.010 @ 8	0.029	Yes
1D	33.04	0.734	0.020 @ 10	0.029	Yes
2A	29.07	0.727	0.016 @ 8	0.029	Yes
2B	29.65	0.741	0.009 @ 8	0.030	Yes
2C	28.67	0.717	0.010 @ 7	0.029	Yes
2D	28.40	0.710	0.010 @ 8	0.028	Yes
3A	34.24	0.571	0.012 @ 10	0.023	Yes
3B	35.15	0.586	0.010 @ 8	0.023	Yes
3C	33.75	0.563	0.009 @ 8	0.023	Yes
3D	33.01	0.550	0.020 @ 5	0.022	Yes
4A	30.60	0.765	0.012 @ 8	0.031	Yes
4B	31.17	0.779	0.012 @ 7	0.031	Yes
4C	30.35	0.759	0.008 @ 7	0.030	Yes
4D	29.54	0.739	0.015 @ 10	0.030	Yes
5A	34.14	0.569	0.014 @ 10	0.023	Yes
5B	34.70	0.578	0.012 @ 8	0.023	Yes
5C	34.46	0.574	0.012 @ 8	0.023	Yes
5D	32.59	0.543	0.016 @ 7	0.022	Yes
6A	35.10	0.780	0.007 @ 7	0.031	Yes
6B	35.17	0.782	0.010 @ 8	0.031	Yes
6C	34.49	0.766	0.008 @ 7	0.031	Yes
6D	33.78	0.751	0.008 @ 10	0.030	Yes
7A	31.11	0.778	0.015 @ 9	0.031	Yes
7B	31.94	0.799	0.011 @ 8	0.032	Yes
7C	30.14	0.754	0.009 @ 7	0.030	Yes
7D	29.91	0.748	0.014 @ 10	0.030	Yes
8A	30.89	0.772	0.009 @ 10	0.031	Yes
8B	29.73	0.743	0.011 @ 8	0.030	Yes
8C	30.49	0.762	0.021 @ 7	0.030	No
8D	31.95	0.799	0.018 @ 8	0.032	Yes

^aThe maximum acceptable leak rate is the lesser of 0.020 dscfm or 4% of the average sampling rate.

Table 5-7

Summary of Analytical Quality Control Results

Sample ID	Total Detected µg	Theoretical µg	Percent Error %
Field Blank A	2.5	NA ⁴	NA
Field Blank B	8.3	NA	NA
Field Blank C	6.4	NA	NA
Field Spike 1	7570	7828	96.7
Field Spike 2	7686	7828	98.2
Method Spike 1	8120	7828	104
Method Spike 2	7838	7828	100
Method Spike 3	7890	7828	101
Method Spike 4	7945	7828	101
Toluene Reagent Blank ¹	0.5	NA	NA
ACN Reagent Blank ²	0.4	NA	NA
Method Blank ³	10.2	NA	NA

¹Average of four, ranging from 0.1 to 1.2 µg

²Average of four, ranging from 0.1 to 0.8 µg

³Average of three, ranging from 0.3 to 20.7 µg

⁴NA, Not Applicable

were met as shown in Table 5-5. Field blanks were collected by assembling a sampling train as if to collect a sample, transporting to the sampling location, leak checking and returning the train to the onsite laboratory for recovery. Field spikes and method spikes were prepared by spiking approximately 300 mL of the toluene 1,2-PP solution with 15 mL of the field spiking solution. Method and reagent blanks were prepared by evaporating approximately 300 mL of solvent to dryness and dissolving any residue with 10 mL of ACN. All spikes and blanks met the data acceptance criteria listed in Table 5-5.

No blank contamination problems were identified during the analysis of field and laboratory blanks and no blank corrections were performed for the reported data. All blank analysis data are presented along with other QC and field sample results in Appendix A.

APPENDIX A

**Analytical Data for Samples, Blanks, Spikes and
Quality Control Samples**

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ISO-SCF-32293-4	1263013	5.90	5.40641	9%	2000	11931.6	11942.9	33.42	1.05669	12196.0	12261.5	7827.81	95.69%	I-A-1
ISO-SCF-32293-4	1251783	5.86	5.40641	8%	2000	11930.1								
ISO-SCF-32293-4	1249399	5.84	5.40641	8%	2000	11966.8								
ARL-1	1277072	5.97			100	64.1	63.9	33.42	1.05669	67.5				I-A-2
ARL-1	1276918	5.97			100	64.4								
ARL-1	1280852	5.98			100	63.1								
ARL-2	135291	0.64			2000	11178.7								
ARL-2	135913	0.64			2000	11348.3								
ARL-2	133152	0.63			2000	11375.3								
ARL-3	1196354	5.59			100	28.6	27.8	33.89	1.04204	29.0	11520.1	7827.81	86.19%	I-D-1
ARL-3	1214532	5.67			100	27.7								
ARL-3	1217429	5.69			100	27.2								
ARL-4	59159	0.29			2000	4418.4	4409.3	33.02	1.06949	4715.7	4735.0			I-C-1
ARL-4	57134	0.28			2000	4411.3								
ARL-4	56201	0.27			2000	4398.2								
ISO-SCF-32293-4	1255771	5.87	5.40641	9%	100	17.8	18.1	33.02	1.06949	19.3				I-C-2
ISO-SCF-32293-4	1251918	5.85	5.40641	8%	100	18.3								
ISO-SCF-32293-4	1242330	5.80	5.40641	7%	100	18.2								
ARL-5	471546	2.21			2000	4399.5	4416.1	33.01	1.06885	4720.1	4811.1			I-D-1
ARL-5	470785	2.21			2000	4324.4								
ARL-5	469380	2.20			2000	4524.4								
ARL-6	35898	0.18			100	85.0	85.1	33.01	1.06885	90.9				I-D-2
ARL-6	37029	0.18			100	84.8								
ARL-6	36906	0.18			100	85.4								
ARL-7	469526	2.20			2000	4399.5	4416.1	33.01	1.06885	4720.1	4811.1			I-D-1
ARL-7	461467	2.16			2000	4324.4								
ARL-7	482909	2.26			2000	4524.4								
ARL-8	180144	0.85			100	85.0	85.1	33.01	1.06885	90.9				I-D-2
ARL-8	179633	0.85			100	84.8								
ARL-8	181047	0.85			100	85.4								
ISO-SCF-32293-4	1238919	5.79	5.40641	7%										
ISO-SCF-32293-4	1245039	5.82	5.40641	8%										
ISO-SCF-32293-4	1235673	5.77	5.40641	7%										

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-9	544346	2.55			2000	5097.4	5114.2	29.07	1.21481	6212.9	6287.4			2-A-1
ARL-9	548157	2.57			2000	5132.9								
ARL-9	545934	2.56			2000	5112.4	61.4	29.07	1.21481	74.6				2-A-2
ARL-10	170306	0.62			100	61.8								
ARL-10	170910	0.62			100	62.1								
ARL-10	127110	0.60			100	60.3								2-B-1
ARL-11	567669	2.66			2000	5314.9	5224.4	29.65	1.19105	6222.5	6269.9			
ARL-11	561460	2.64			2000	5275.7								
ARL-11	542754	2.54			2000	5082.6	39.8	29.65	1.19105	47.4				2-B-2
ARL-12	81414	0.40			100	40.0								
ARL-12	81620	0.40			100	39.4								
ARL-12	82237	0.39			100	39.4								
ISO-SCF-32293-4	1220899	5.70	5.40641	6%	1	5.7								
ISO-SCF-32293-4	1232805	5.76	5.40641	6%	1	5.8								
ISO-SCF-32293-4	1210936	5.75	5.40641	6%	1	5.8								
ARL-13	1287864	6.02			2000	12032.2	12045.3	28.67	1.23176	13215.1	13258.2	7827.81	89.16%	2-C-1
ARL-13	1288870	6.02			2000	12041.6								
ARL-13	1291013	6.03			2000	12061.9								
ARL-14	71522	0.34			100	34.4	35.0	28.67	1.23176	43.1				2-C-2
ARL-14	73423	0.35			100	35.3								
ARL-14	73513	0.35			100	35.3								
ARL-15	1135291	6.24			2000	12474.6	12454.1	28.40	1.24347	13671.5	13732.6	7827.81	95.22%	2-D-1
ARL-15	1144709	6.23			2000	12469.2								
ARL-15	1329284	6.21			2000	12418.6								
ARL-16	103190	0.49			100	49.1	49.1	28.40	1.24347	61.1				2-D-2
ARL-16	103848	0.49			100	49.1								
ARL-16	102349	0.49			100	48.7								
ISO-SCF-32293-4	1246426	5.82	5.40641	8%	1	5.8								
ISO-SCF-32293-4	1217852	5.78	5.40641	7%	1	5.8								
ISO-SCF-32293-4	1239959	5.79	5.40641	7%	1	5.8								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-17	1229990	5.75			2000	11497.4	11487.9	34.24	1.03139	11587.8	11624.8	7827.81	106.14%	3-A-1
ARL-17	1214060	5.67			2000	11343.9								
ARL-17	1244450	5.81			2000	11627.3								
ARL-18	75825	0.36			100	36.4	35.9	34.24	1.03139	37.0				3-A-2
ARL-18	74917	0.36			100	36.0								
ARL-18	73672	0.35			100	35.4								
ARL-19	1282836	5.99			2000	11985.3	12024.4	35.15	1.00468	12039.7	12077.7	7827.81	111.91%	3-B-1
ARL-19	1289518	6.02			2000	12047.7								
ARL-19	1288725	6.02			2000	12040.3								
ARL-20	79007	0.38			100	37.9	37.8	35.15	1.00468	38.0				3-B-2
ARL-20	78713	0.38			100	37.7								
ARL-20	79021	0.38			100	37.9								
ISO-SCF-32293-4	1263449	5.90	5.40641	9%	1	5.9								
ISO-SCF-32293-4	1253499	5.86	5.40641	8%	1	5.9								
ISO-SCF-32293-4	1260480	5.89	5.40641	9%	1	5.9								
ARL-21	351376	1.65			2000	3297.6	3281.0	33.75	1.04636	3433.1	3466.4			3-C-1
ARL-21	343323	1.61			2000	3222.4								
ARL-21	354099	1.66			2000	3323.0								
ARL-22	65492	0.32			100	31.6	31.8	33.75	1.04636	33.3				3-C-2
ARL-22	66002	0.32			100	31.8								
ARL-22	66603	0.32			100	32.1								
ARL-23	319713	1.50			2000	3002.2	2927.6	33.01	1.06982	3132.0	3165.7			3-D-1
ARL-23	310818	1.46			2000	2919.3								
ARL-23	304609	1.43			2000	2861.4								
ARL-24	65115	0.31			100	31.4	31.5	33.01	1.06982	33.7				3-D-2
ARL-24	66054	0.32			100	31.8								
ARL-24	64767	0.31			100	31.2								
ISO-SCF-32293-4	1223529	5.72	5.40641	6%	1	5.7								
ISO-SCF-32293-4	1220297	5.70	5.40641	5%	1	5.7								
ISO-SCF-32293-4	1163133	5.70	5.40641	5%	1	5.7								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Dias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-25	198810	0.94			2000	1874.6	1831.7	30.60	1.15407	2113.9	2132.1			4-A-1
ARL-25	195931	0.92			2000	1847.7								
ARL-25	187888	0.89			2000	1772.7								4-A-2
ARL-26	33336	0.17			100	16.6	15.8	30.60	1.15407	18.3				
ARL-26	32875	0.16			100	16.3								
ARL-26	29079	0.15			100	14.6								
ARL-27	200805	0.95			2000	1891.2	1864.2	31.17	1.13297	2112.1	2138.7			4-B-1
ARL-27	200518	0.95			2000	1890.7								
ARL-27	191767	0.90			2000	1808.9								4-B-2
ARL-28	48281	0.24			100	23.5	23.5	31.17	1.13297	26.6				
ARL-28	49506	0.24			100	24.1								
ARL-28	46705	0.23			100	22.8								
ISO-SCF-32291-4	1202615	5.62	5.40641	4%	1	5.6								
ISO-SCF-32291-4	1219147	5.70	5.40641	5%	1	5.7								
ARL-29	1001159	4.68			2000	9158.1	9129.4	30.35	1.16358	9626.4	9693.9	7827.81	96.56%	4-C-1
ARL-29	987039	4.61			2000	9226.4								
ARL-29	1008035	4.70			2000	9403.6								
ARL-30	124507	0.59			100	59.1	58.0	30.35	1.16358	67.5				4-C-2
ARL-30	122754	0.58			100	58.3								
ARL-30	119182	0.57			100	56.6								
ARL-31	1004933	4.70			2000	9191.1	9128.7	29.54	1.19549	9774.2	9804.7	7827.81	97.97%	4-D-1
ARL-31	1018359	4.76			2000	9518.5								
ARL-31	1002870	4.69			2000	9371.1								
ARL-32	51598	0.26			100	26.0	25.5	29.54	1.19549	30.5				4-D-2
ARL-32	53113	0.26			100	25.8								
ARL-32	50832	0.25			100	24.7								
ISO-SCF-32293-4	1200453	5.61	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1204115	5.63	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1189454	5.56	5.40641	3%	1	5.6								

Sample Name	AREA	AMOUNT ug/ml.	QC Con ug/mL	QC Bins %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-31	1109769	6.12			2000	12236.5	12014.2	34.14	1.01441	12187.3	12233.3	7827.81	89.41%	5-A-1
ARL-33	1323802	6.18			2000	12367.4								
ARL-33	1224229	5.72			2000	11438.7								
ARL-34	101486	0.49			100	49.3	44.5	34.14	1.03441	46.1				5-D-1
ARL-34	103836	0.49			100	49.4								
ARL-34	72585	0.35			100	34.9								
ARL-35	1169996	6.40			2000	12798.3	12588.1	34.70	1.01771	12678.6	12716.7	7827.81	95.59%	5-D-1
ARL-35	1382908	6.46			2000	12918.7								
ARL-35	1289467	6.02			2000	12047.2								
ARL-36	81360	0.40			100	40.4	37.4	34.70	1.01771	38.0				5-D-2
ARL-36	85164	0.41			100	40.7								
ARL-36	84482	0.31			100	31.1								
ISO-SCF-32293-4	1198549	5.60	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1178529	5.51	5.40641	2%	1	5.5								
ARL-37	511915	2.40			2000	4791.9	4809.8	34.46	1.02480	4929.1	4946.9			5-C-1
ARL-37	520867	2.44			2000	4876.5								
ARL-37	507945	2.18			2000	4757.9								
ARL-38	36452	0.18			100	18.0	17.4	34.46	1.02480	17.8				5-C-2
ARL-38	36462	0.18			100	18.0								
ARL-38	32321	0.16			100	16.1								
ARL-39	532851	2.50			2000	4990.2	5054.0	32.59	1.08360	5476.5	5521.9			5-D-1
ARL-39	544154	2.55			2000	5095.6								
ARL-39	542068	2.54			2000	5076.1								
ARL-40	90692	0.43			100	43.3	41.9	32.59	1.08360	45.4				5-D-2
ARL-40	82975	0.40			100	39.7								
ARL-40	89246	0.43			100	42.6								
ISO-SCF-32293-4	1167611	5.55	5.40641	3%	1	5.5								
ISO-SCF-32293-4	1190484	5.60	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1183133	5.53	5.40641	2%	1	5.5								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Fl	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-41	861252	4.03			2000	8053.2	7887.9	35.10	1.00612	7936.1	8041.6			6-A-1
ARL-41	860232	4.02			2000	8043.7								
ARL-41	809094	3.78			2000	7566.7								
ARL-42	227095	1.07			100	106.9	104.8	35.10	1.00612	105.4				6-A-2
ARL-42	228142	1.07			100	107.4								
ARL-42	212430	1.00			100	100.1								
ARL-43	815730	3.81			2000	7628.6	7488.0	35.17	1.00411	7518.8	7607.6			6-B-1
ARL-43	825689	3.86			2000	7721.5								
ARL-43	760533	3.56			2000	7113.8								
ARL-44	193894	0.91			100	91.4	88.5	35.17	1.00411	88.8				6-D-2
ARL-44	197908	0.93			100	93.1								
ARL-44	170746	0.81			100	80.6								
ISO-SCF-32293-4	1189088	5.56	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1190921	5.56	5.40641	3%	1	5.6								
ARL-45	1656820	7.74			2000	15473.5	15201.1	34.49	1.02391	15381.5	15471.2	7827.81	97.69%	6-C-1
ARL-45	1652121	7.71			2000	15429.7								
ARL-45	1573883	7.35			2000	14700.0								
ARL-46	187832	0.89			100	88.6	87.6	34.49	1.02391	89.7				6-C-2
ARL-46	195647	0.92			100	92.3								
ARL-46	173379	0.82			100	81.9								
ARL-47	1649873	7.70			2000	15408.7	15171.2	33.78	1.04543	15509.0	15609.8	7827.81	99.46%	6-D-1
ARL-47	1634325	7.63			2000	15263.7								
ARL-47	1589678	7.42			2000	14847.3								
ARL-48	220417	1.04			100	103.8	96.3	33.78	1.04543	100.7				6-D-2
ARL-48	206802	0.97			100	97.5								
ARL-48	186023	0.88			100	87.8								
ISO-SCF-32293-4	1205054	5.63	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1195876	5.59	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1183684	5.53	5.40641	2%	1	5.5								

Sample Name	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Dias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-49	1081312	5.05			2000	10105.7	10094.4	31.11	1.13515	10398.3	10450.0	7827.81	100.45%	7-A-1
ARL-49	1074952	5.02			2000	10046.4								
ARL-49	1004020	5.07			2000	10131.0								
ARL-50	98427	0.47			100	46.9	45.6	31.11	1.13515	51.8				7-A-2
ARL-50	96270	0.46			100	45.9								
ARL-50	92145	0.44			100	44.0								
ARL-51	963252	4.50			2000	9001.6	9002.6	31.94	1.10566	9246.5	9290.2	7827.81	85.63%	7-B-1
ARL-51	970463	4.54			2000	9071.8								
ARL-51	955412	4.47			2000	8931.4								
ARL-52	83965	0.40			100	40.2	39.5	31.94	1.10566	43.6				7-B-2
ARL-52	83998	0.40			100	40.2								
ARL-52	79455	0.38			100	38.1								
ISO-SCF-32293-4	1194001	5.58	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1201282	5.61	5.40641	4%	1	5.6								
ARL-53	230346	1.08			2000	2168.7	2159.8	30.14	1.17169	2530.6	2557.9			7-C-1
ARL-53	232911	1.10			2000	2192.6								
ARL-53	224911	1.06			2000	2118.0								
ARL-54	49290	0.24			100	24.0	23.3	30.14	1.17169	27.3				7-C-2
ARL-54	49749	0.24			100	24.2								
ARL-54	44489	0.22			100	21.8								
ARL-55	237247	1.12			2000	2231.1	2180.2	29.91	1.18070	2574.2	2616.4			7-D-1
ARL-55	228829	1.08			2000	2154.5								
ARL-55	228680	1.08			2000	2153.0								
ARL-56	75486	0.36			100	36.2	35.8	29.91	1.18070	42.3				7-D-2
ARL-56	75014	0.36			100	36.0								
ARL-56	73273	0.35			100	35.2								
ISO-SCF-32293-4	1201622	5.61	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1197019	5.57	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1184261	5.53	5.40641	2%	1	5.5								

Sample Name	AREA	AMOUNT ug/ml.	QC Con ug/ml.	QC Dias %	Dilution Factor	Amount Sample ug	Avg Amt Sample ug	Volume Sampled Cu Ft	Sampling Factor	Adjusted Avg ug	Total Train ug	Amount Spiked ug	Spike Recovery %	Train ID
ARL-57	374801	1.76			2000	3516.0	(3520.7	30.89	1.14324	4025.0	4086.0			8-A-1
ARL-57	377410	1.77			2000	3540.4								
ARL-57	373681	1.75			2000	3505.6								
ARL-58	111353	0.53			100	52.9	53.4	30.89	1.14324	61.0				8-A-2
ARL-58	112493	0.53			100	53.5								
ARL-58	113066	0.54			100	53.7								
ARL-59	406883	1.91			2000	3815.3	3805.4	29.73	1.18785	4520.2	4579.2			8-B-1
ARL-59	401924	1.88			2000	3769.0								
ARL-59	408657	1.92			2000	3811.8								
ARL-60	105005	0.50			100	50.0	49.7	29.73	1.18785	59.0				8-B-2
ARL-60	104950	0.50			100	50.0								
ARL-60	102071	0.49			100	49.0								
ISO-SCF-32293-4	1187542	5.59	5.40641	3%	1	5.6								
ISO-SCF-32293-4	1200088	5.61	5.40641	4%	1	5.6								
ISO-SCF-32293-4	1190471	5.56	5.40641	3%	1	5.6								
ARL-61	1137017	5.31			2000	10625.3	10561.2	30.49	1.15824	11144.9	11197.4	7827.81	88.46%	8-C-1
ARL-61	1120589	5.24			2000	10471.9								
ARL-61	1132853	5.29			2000	10386.4								
ARL-62	04647	0.45			100	45.2	45.3	30.49	1.15824	52.5				8-C-2
ARL-62	05891	0.46			100	45.8								
ARL-62	04335	0.45			100	45.0								
ARL-63	1108755	5.18			2000	10361.7	10314.5	31.95	1.10531	10721.6	10770.2	7827.81	83.01%	8-D-1
ARL-63	1096270	5.12			2000	10215.2								
ARL-63	1106072	5.17			2000	10336.7								
ARL-64	02259	0.44			100	44.0	44.0	31.95	1.10531	48.6				8-D-2
ARL-64	02550	0.44			100	44.2								
ARL-64	01667	0.44			100	43.8								
ISO-SCF-32293-4	1186551	5.54	5.40641	3%	1	5.5								
ISO-SCF-32293-4	1187157	5.55	5.40641	3%	1	5.5								
ISO-SCF-32293-4	1196473	5.59	5.40641	3%	1	5.6								

Sample Name	FILE	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ISO-SCF-32293-4	S3083F4	1263013	5.90	5.41	9%	1	5.9	5.9			QC
ISO-SCF-32293-4	S3083F5	1253783	5.86	5.41	8%	1	5.9				
ISO-SCF-32293-4	S3083F6	1249399	5.84	5.41	8%	1	5.8				
ARL-81	S3083F19	30452	0.15			10	1.5	1.6			FDA
ARL-81	S3083F20	31446	0.16			10	1.6				
ARL-81	S3083F21	33523	0.17			10	1.7				
ARL-104	S3083F22	809699	3.79			2000	7572.4	7569.9	7827.81	97%	FS-1
ARL-104	S3083F23	808659	3.78			2000	7562.7				
ARL-104	S3083F24	809952	3.79			2000	7574.7				
ISO-SCF-32293-4	S3083F25	1255771	5.87	5.41	9%	1	5.9	5.8			QC
ISO-SCF-32293-4	S3083F26	1251918	5.85	5.41	8%	1	5.8				
ISO-SCF-32293-4	S3083F27	1242330	5.80	5.41	7%	1	5.8				
ARL-82	S3083F40	16055	0.08			10	0.8	0.9			FDA
ARL-82	S3083F41	16597	0.09			10	0.9				
ARL-82	S3083F42	16113	0.09			10	0.9				
ARL-105	S3083F43	832058	3.89			2000	7780.9	7686.3	7827.81	98%	FS-2
ARL-105	S3083F44	822507	3.85			2000	7691.8				
ARL-105	S3083F45	811167	3.79			2000	7586.1				
ISO-SCF-32293-4	S3083F46	1238919	5.79	5.41	7%	1	5.8	5.8			QC
ISO-SCF-32293-4	S3083F47	1245039	5.82	5.41	8%	1	5.8				
ISO-SCF-32293-4	S3083F48	1235673	5.77	5.41	7%	1	5.8				
ARL-83	S3084F13	163746	0.77			10	7.7	7.7			FDD
ARL-83	S3084F14	162706	0.77			10	7.7				
ARL-83	S3084F15	164806	0.78			10	7.8				
ARL-106	S3084F16	869707	4.07			2000	8132.1	8120.1	7827.81	104%	MS-1
ARL-106	S3084F17	867360	4.06			2000	8110.2				
ARL-106	S3084F18	868206	4.06			2000	8118.1				
ISO-SCF-32293-4	S3084F19	1220899	5.70	5.41	6%	1	5.7	5.7			QC
ISO-SCF-32293-4	S3084F20	1232005	5.76	5.41	6%	1	5.8				
ISO-SCF-32293-4	S3084F21	1230936	5.75	5.41	6%	1	5.8				
ARL-84	S3084F34	33054	0.16			10	1.6	1.6			FDD
ARL-84	S3084F35	32381	0.16			10	1.6				
ARL-84	S3084F36	32300	0.16			10	1.6				

Sample Name	FILE	ARI:A	AMOUNT ug/mL	QC Con ug/mL	QC Bias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ARL-107	S1084F37	829745	3.88			2000	7759.3	7837.5	7827.81	100%	MS-2
ARL-107	S3084F38	838117	3.92			2000	7837.4				
ARL-107	S3084F39	846508	3.96			2000	7915.7				
ISO-SCF-32293-4	S3084F40	1246426	5.82	5.41	8%	1	5.8	5.8			QC
ISO-SCF-32293-4	S3084F41	1237852	5.78	5.41	7%	1	5.8				
ISO-SCF-32293-4	S3084F42	1239959	5.79	5.41	7%	1	5.8				
ARL-85	S3085F19	75475	0.36			10	3.6	3.6			FBC
ARL-85	S3085F20	75608	0.36			10	3.6				
ARL-85	S3085F21	72681	0.35			10	3.5				
ARL-108	S3085F22	847084	3.96			2000	7921.1	7890.2	7827.81	101%	MS-3
ARL-108	S3085F23	836897	3.91			2000	7826.0				
ARL-108	S3085F24	847337	3.96			2000	7923.4				
ISO-SCF-32293-4	S3085F25	1263449	5.90	5.41	9%	1	5.9	5.9			QC
ISO-SCF-32293-4	S3085F26	1253499	5.86	5.41	8%	1	5.9				
ISO-SCF-32293-4	S3085F27	1260480	5.89	5.41	9%	1	5.9				
ARL-86	S3085F40	59577	0.29			10	2.9	2.8			FBC
ARL-86	S3085F41	56343	0.27			10	2.7				
ARL-86	S3085F42	59626	0.29			10	2.9				
ARL-109	S3085F43	851309	3.98			2000	7960.5	7944.8	7827.81	101%	MS-4
ARL-109	S3085F44	850793	3.98			2000	7955.6				
ARL-109	S3085F45	846800	3.96			2000	7918.4				
ISO-SCF-32293-4	S3085F46	1245663	5.82	5.41	8%	1	5.8	4.0			QC
ISO-SCF-32293-4	S3085F47	0	0.01	5.41	-100%	1	0.0				
ISO-SCF-32293-4	S3085F48	1296988	6.06	5.41	12%	1	6.1				
ISO-SCF-32293-4	S3088F1	1158548	5.41	5.41	0%	1	5.4				
ARL-89	S3098F2	0	0.01			10	0.1	0.1			T-RB1
ARL-89	S3098F3	0	0.01			10	0.1				
ARL-89	S3098F4	0	0.01			10	0.1				
ARL-90	S3098F5	0	0.01			10	0.1	0.3			T-RB2
ARL-90	S3098F6	5768.5	0.04			10	0.4				
ARL-90	S3098F7	5867.5	0.04			10	0.4				
ARL-91	S3098F8	0	0.01			10	0.1	0.2			T-RB3
ARL-91	S3098F9	3273	0.03			10	0.3				
ARL-91	S3098F10	0	0.01			10	0.1				

Sample Name	FILE	AREA	AMOUNT ng/mL	QC Con ng/mL	QC Bias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ARL-92	S3098F11	26240	0.13			10	1.3	1.2			T-RB4
ARL-92	S3098F12	22909.08	0.12			10	1.2				
ARL-92	S3098F13	22154	0.11			10	1.1				
ISO-SCF-32293-4	S3098F14	1202.980	5.62	5.41	4%	1	5.6	5.7			QC
ISO-SCF-32293-4	S3098F15	1212015	5.66	5.41	5%	1	5.7				
ISO-SCF-32293-4	S3098F16	1220989	5.70	5.41	6%	1	5.7				
ARL-94	S3098F17	0	0.01			10	0.1	0.2			A-RB1
ARL-94	S3098F18	5431	0.04			10	0.4				
ARL-94	S3098F19	0	0.01			10	0.1				
ARL-95	S3098F20	0	0.01			10	0.1	0.1			A-RB2
ARL-95	S3098F21	0	0.01			10	0.1				
ARL-95	S3098F22	0	0.01			10	0.1				
ARL-96	S3098F23	6352.5	0.04			10	0.4	0.4			A-RB1
ARL-96	S3098F24	6436	0.04			10	0.4				
ARL-96	S3098F25	5888	0.04			10	0.4				
ARL-97	S3098F26	25606	0.13			10	1.3	0.8			A-RB4
ARL-97	S3098F27	21934	0.11			10	1.1				
ARL-97	S3098F28	0	0.01			10	0.1				
ISO-SCF-32293-4	S3098F29	1164624	5.44	5.41	1%	1	5.4	5.4			QC
ISO-SCF-32293-4	S3098F30	1159319	5.42	5.41	0%	1	5.4				
ISO-SCF-32293-4	S3098F31	1149310	5.37	5.41	-1%	1	5.4				
ARL-99	S3098F32	0	0.01			10	0.1	0.1			ADS-RB
ARL-99	S3098F33	0	0.01			10	0.1				
ARL-99	S3098F34	0	0.01			10	0.1				
ARL-100	S3098F35	0	0.01			10	0.1	0.1			ADS-RB
ARL-100	S3098F36	0	0.01			10	0.1				
ARL-100	S3098F37	0	0.01			10	0.1				
ARL-101	S3098F38	15010.13	0.08			10	0.8	0.9			ADS-RB
ARL-101	S3098F39	15823	0.08			10	0.8				
ARL-101	S3098F40	23127	0.12			10	1.2				
ARL-102	S3098F41	0	0.01			10	0.1	0.1			ADS-RB
ARL-102	S3098F42	0	0.01			10	0.1				
ARL-102	S3098F43	0	0.01			10	0.1				

Sample Name	FILE	AREA	AMOUNT ug/mL	QC Con ug/mL	QC Dias %	Dilution Factor	Amount Sample	Avg Amt Sample	Amount Spiked	Spike Recovery	Train ID
ISO-SCF-32203-4	S3098F44	1187727	5.55	5.41	3%	1	5.5	5.6			QC
ISO-SCF-32203-4	S3098F45	1189251	5.60	5.41	4%	1	5.6				
ISO-SCF-32203-4	S3098F46	1206006	5.63	5.41	4%	1	5.6				
ARL-117	S3098F47	4701	0.03			10	0.3	0.3			MB-1
ARL-117	S3098F48	4880.5	0.03			10	0.3				
ARL-117	S3098F49	5001	0.03			10	0.3				
ARL-118	S3098F50	204900	0.96			10	9.6	9.7			MB-2
ARL-118	S3098F51	207157	0.98			10	9.8				
ARL-118	S3098F52	207481	0.98			10	9.8				
ARL-119	S3098F53	448217.5	2.09			10	20.9	20.7			MB-3
ARL-119	S3098F54	427833.1	2.01			10	20.1				
ARL-119	S3098F55	452112	2.12			10	21.2				
ISO-SCF-4893-1	S3098F56	1164164	5.44	5.41	1%	1	5.4	5.5			QC
ISO-SCF-4893-1	S3098F57	1176245	5.50	5.41	2%	1	5.5				
ISO-SCF-4893-3	S3098F58	1160212	5.42	5.41	0%	1	5.4				

2,4-TDI Summary Information

Amount of 2,4-TDI Spiked Into the Train: 7827.81 ug

Percent Recovery for Spiked Quad Trains

Quad No. Train ID	1				2				3				4				5				6				7				Average		RSD
	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	
% Recovery	95.69%	96.19%	99.10%	95.22%	106.14%	111.93%	96.56%	97.97%	96.56%	97.97%	96.56%	97.97%	89.41%	95.59%	97.69%	99.46%	100.45%	85.63%	88.46%	83.01%	88.46%	83.01%	88.46%	83.01%	100.45%	85.63%	88.46%	83.01%	88.46%	83.01%	
Total ug	12283	11520	13258	13733	11625	12078	9694	9805	9694	9805	9694	9805	12233	12717	15471	15610	10450	9290	11197	10770	11197	10770	11197	10770	10450	9290	11197	10770	11197	10770	

Amount Collected in Unspiked Quad Trains

Quad No. Train ID	1				2				3				4				5				6				7				Average		RSD
	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	
Total ug	4735	4811	6287	6270	6287	6270	6287	6270	3468	3166	2132	2139	2132	2139	2132	2139	4947	5522	8042	7608	8042	7608	8042	7608	2558	2816	4086	4579	4086	4579	

Percent Carry over from 1st Impinger in Spiked Quad Trains

Quad No. Train ID	1				2				3				4				5				6				7				Average		RSD
	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	
1st Impinger	98.46%	99.21%	99.21%	98.97%	99.21%	98.97%	99.02%	99.11%	99.02%	99.11%	96.38%	99.46%	98.05%	99.22%	98.83%	98.71%	98.03%	97.02%	98.44%	98.35%	98.83%	98.71%	98.83%	98.71%	98.03%	97.02%	98.44%	98.35%	98.44%	98.35%	
2nd Impinger	1.52%	0.79%	0.79%	1.03%	0.79%	1.03%	0.98%	0.89%	0.98%	0.89%	3.62%	1.54%	1.05%	0.78%	1.17%	1.20%	1.07%	2.98%	1.56%	1.65%	1.17%	1.20%	1.17%	1.20%	1.07%	2.98%	1.56%	1.65%	1.48%	54.36%	

Percent Carry over from 1st Impinger in Unspiked Quad Trains

Quad No. Train ID	1				2				3				4				5				6				7				Average		RSD
	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	
1st Impinger	99.59%	98.11%	99.81%	99.24%	99.81%	99.24%	99.04%	98.94%	99.04%	98.94%	99.14%	98.76%	99.84%	99.16%	98.69%	98.83%	99.93%	98.38%	98.51%	98.71%	98.69%	98.83%	98.69%	98.83%	99.93%	98.38%	98.51%	98.71%	98.91%	0.41%	
2nd Impinger	0.41%	1.89%	1.19%	0.76%	1.19%	0.76%	0.96%	1.06%	0.96%	1.06%	0.66%	1.24%	0.36%	0.92%	1.31%	1.17%	1.07%	1.62%	1.49%	1.29%	1.31%	1.17%	1.31%	1.17%	1.07%	1.62%	1.49%	1.29%	1.09%	37.05%	

AREAL WA 55 -- Method 301 Results
Using Modified Data

Run #	Train			Amount			Precision of UNSpiked Samples		
	A	B	C	D	Spiked	Diff	STDu	STDm	RSD
1	12263.0	11520.0	4735.0	4811.0	7827.81	-76.00	216.396	30.942	4.721
2	6287.0	6270.0	13258.0	13733.0	7827.81	17.00			
3	11625.0	12078.0	3466.0	3166.0	7827.81	300.00			
4	2132.0	2139.0	9694.0	9805.0	7827.81	-7.00			
5	12233.0	12717.0	4947.0	5522.0	7827.81	-575.00			
6	8084.0	7608.0	15471.0	15610.0	7827.81	476.00			
7	10450.0	9290.0	2557.0	2616.0	7827.81	-59.00			

AREAL WA 55 -- Method 301 Results
Using Modified Data

Run #	Train			Amount Spiked	Precision of Spiked Samples			RSD	Run	Bias		I Test	CF	
	A	B	C		D	Diff	SDs			SDm	Compound			SD
1	12263.0	11520.0	4735.0	4811.0	7827.81	743.00	430.48	162.71	3.53	-709.31	-295.41	481.90	-1.622	N/A
2	6287.0	6270.0	13258.0	13733.0	7827.81	-475.00				-610.81			^	
3	11625.0	12078.0	3466.0	3166.0	7827.81	-453.00				707.69				
4	2132.0	2139.0	9694.0	9805.0	7827.81	-111.00				-213.81			critical Value	
5	12233.0	12717.0	4947.0	5522.0	7827.81	-484.00				-587.31			is 2.160	
6	8084.0	7608.0	15471.0	15610.0	7827.81	-139.00				-133.31				
7	10450.0	9290.0	2557.0	2616.0	7827.81	1160.00				-544.31				

AREAL WA 55 -- Method 301 Results
Using Modified Data

Run #	Train			Amount Spiked	Precision of UNSpiked Samples				
	A	B	C		D	Diff	STDu	STDm	RSD
1	12263.0	11520.0	4735.0	4811.0	7827.81	-76.00	237.150	29.644	5.205
2	6287.0	6270.0	13258.0	13733.0	7827.81	17.00			
3	11625.0	12078.0	3466.0	3166.0	7827.81	300.00			
4	2132.0	2139.0	9694.0	9805.0	7827.81	-7.00			
5	12233.0	12717.0	4947.0	5522.0	7827.81	-575.00			
6	8084.0	7608.0	15471.0	15610.0	7827.81	476.00			
7	10450.0	9290.0	2557.0	2616.0	7827.81	-59.00			
8	4086.0	4579.0	11197.0	10947.0	7827.81	-493.00			

BAL WA 55 -- Method 301 Results
 Sing Modified Data

A	Train				Amount				Precision of Spiked Samples				Bias			
	B	C	D	Spiked	Spiked	Diff	SDs	SDm	RSD	Run	Compound	SD	t Test	CF		
12263.0	11520.0	4733.0	4811.0	7827.81	743.00	407.50	144.07	3.40	-789.31	-394.53	471.48	-2.367	1.053			
6267.0	6270.0	13258.0	13733.0	7827.81	-475.00				-610.81							
11625.0	12078.0	3466.0	3166.0	7827.81	-453.00				707.69							
2132.0	2139.0	9694.0	9805.0	7827.81	-111.00				-213.81							
12233.0	12717.0	4947.0	5522.0	7827.81	-484.00				-587.31							
8084.0	7608.0	15471.0	15610.0	7827.81	-139.00				-133.31							
10450.0	9290.0	2537.0	2616.0	7827.81	1160.00				-544.31							
4086.0	4579.0	11197.0	10947.0	7827.81	250.00				-1088.31							

critical Value
 is 2.131

JUL 16 1990

SAMPLING FOR FORMALDEHYDE EMISSIONS FROM STATIONARY SOURCES

INTERPOLL LABORATORIES

1.0 SCOPE AND APPLICATION

1.1 This method is applicable to the determination of Destruction and Removal Efficiency (DRE) of formaldehyde, CAS Registry number 50-00-0, and possibly other aldehydes and ketones from stationary sources as specified in the regulations. The methodology has been applied specifically to formaldehyde; however, many laboratories have extended the application to other aldehydes and ketones. Compounds derivatized with 2,4-dinitrophenylhydrazine can be detected as low as 6.4×10^{-8} lbs/cu ft (1.8 ppbv) in stack gas over a 1 h sampling period, sampling approximately 45 cu ft.

2.0 SUMMARY OF METHOD

2.1 Gaseous and particulate pollutants are withdrawn isokinetically from an emission source and are collected in aqueous acidic 2,4-dinitrophenylhydrazine. Formaldehyde present in the emissions reacts with the 2,4-dinitrophenylhydrazine to form the formaldehyde dinitrophenylhydrazone derivative. The dinitrophenylhydrazone derivative is extracted, solvent-exchanged, concentrated, and then analyzed by high performance liquid chromatography.

3.0 INTERFERENCES

3.1 A decomposition product of 2,4-dinitrophenylhydrazine, 2,4-dinitroaniline, can be an analytical interferent if concentrations are high. 2,4-dinitroaniline can coelute with the 2,4-dinitrophenylhydrazone of formaldehyde under high performance liquid chromatography conditions which may be used for the analysis. High concentrations of highly oxygenated compounds, especially acetone, that have the same retention time or nearly the same retention time as the dinitrophenylhydrazone of formaldehyde and that also absorb at 360 nm will interfere with the analysis.

Formaldehyde, acetone, and 2,4-dinitroaniline contamination of the aqueous acidic 2,4-dinitrophenylhydrazine (DNPH) reagent is frequently encountered. The reagent must be prepared within five days of use in the field and must be stored in an uncontaminated environment both before and after sampling in order to minimize blank problems. Some level of acetone contamination is unavoidable, because acetone is ubiquitous in laboratory and field operations. However, the acetone contamination must be minimized.

4.0 APPARATUS AND MATERIALS

4.1 A schematic of the sampling train is shown in Figure 1. This sampling train configuration is adapted from EPA Method 5 procedures. The sampling train consists of the following components: Probe Nozzle, Pitot Tube, Differential Pressure Gauge, Metering System, Barometer, and Gas Density Determination Equipment.

4.1.1 Probe Nozzle: Quartz or glass with sharp, tapered (30° angle) leading edge. The taper shall be on the outside to preserve a constant inner diameter. The nozzle shall be buttonhook or elbow design. A range of nozzle sizes suitable

for isokinetic sampling should be available in increments of 0.16 cm (1/16 in), e.g., 0.32 to 1.27 cm (1/8 to 1/2 in), or larger if higher volume sampling trains are used. Each nozzle shall be calibrated according to the procedures outlined in Section 8.1.

4.1.2 Probe Liner: Borosilicate glass or quartz shall be used for the probe liner. The tester should not allow the temperature in the probe to exceed $120 \pm 14^{\circ}\text{C}$ ($248 \pm 25^{\circ}\text{F}$).

4.1.3 Pitot Tube: The Pitot tube shall be Type S, as described in Section 2.1 of EPA Method 2, or any other appropriate device. The pitot tube shall be attached to the probe to allow constant monitoring of the stack gas velocity. The impact (high pressure) opening plane of the pitot tube shall be even with or above the nozzle entry plane (see EPA Method 2, Figure 2-6b) during sampling. The Type S pitot tube assembly shall have a known coefficient, determined as outlined in Section 4 of EPA Method 2.

4.1.4 Differential Pressure Gauge: The differential pressure gauge shall be an inclined manometer or equivalent device as described in Section 2.2 of EPA Method 2. One manometer shall be used for velocity-head readings and the other for orifice differential pressure readings.

4.1.5 Impingers: The sampling train requires a minimum of four impingers, connected as shown in Figure 1, with ground glass (or equivalent) vacuum-tight fittings. For the first, third, and fourth impingers, use the Greenburg-Smith design, modified by replacing the tip with a 1.3-cm inside diameter (1/2 in) glass tube extending to 1.3 cm (1/2 in) from the bottom of the flask. For the second impinger, use a Greenburg-Smith impinger with the standard tip. Place a thermometer capable of measuring temperature to within 1°C (2°F) at the outlet of the fourth impinger for monitoring purposes.

4.1.6 Metering System: The necessary components are a vacuum gauge, leak-free pump, thermometers capable of measuring temperature within 3°C (5.4°F), dry-gas meter capable of measuring volume to within 1%, and related equipment as shown in Figure 1. At a minimum, the pump should be capable of 4 cfm free flow, and the dry gas meter should have a recording capacity of 0-999.9 cu ft with a resolution of 0.005 cu ft. Other metering systems may be used which are capable of maintaining sampling rates within 10% of isokinetic collection and of determining sample volumes to within 2%. The metering system may be used in conjunction with a pitot tube to enable checks of isokinetic sampling rates.

4.1.7 Barometer: The barometer may be mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in Hg). In many cases, the barometric reading may be obtained from a nearby National Weather Service Station, in which case the station value (which is the absolute barometric pressure) is requested and an adjustment for elevation differences between the weather station and sampling point is applied at a rate of minus 2.5 mm Hg (0.1 in Hg) per 30 m (100 ft) elevation increase (vice versa for elevation decrease).

4.1.8 Gas Density Determination Equipment: Temperature sensor and pressure gauge (as described in Sections 2.3 and 2.4 of EPA Method 2), and gas analyzer, if necessary (as described in EPA Method 3). The temperature sensor ideally should be permanently attached to the pitot tube or sampling probe in a fixed

configuration such that the tip of the sensor extends beyond the leading edge of the probe sheath and does not touch any metal. Alternatively, the sensor may be attached just prior to use in the field. Note, however, that if the temperature sensor is attached in the field, the sensor must be placed in an interference-free arrangement with respect to the Type S pitot tube openings (see EPA Method 2, Figure 2-7). As a second alternative, if a difference of no more than 1% in the average velocity measurement is to be introduced, the temperature gauge need not be attached to the probe or pitot tube.

4.2 Sample Recovery

4.2.1 Probe Liner: Probe nozzle and brushes; Teflon® bristle brushes with stainless steel wire handles are required. The probe brush shall have extensions of stainless steel, Teflon®, or inert material at least as long as the probe. The brushes shall be properly sized and shaped to brush out the probe liner, the probe nozzle, and the impingers.

4.2.2 Wash Bottles: Three wash bottles are required. Teflon® or glass wash bottles are recommended; polyethylene wash bottles should not be used because organic contaminants may be extracted by exposure to organic solvents used for sample recovery.

4.2.3 Graduated Cylinder and/or Balance: A graduated cylinder or balance is required to measure condensed water to the nearest 1 mL or 1 g. Graduated cylinders shall have divisions not >2 mL. Laboratory balances capable of weighing to ±0.5 g are required.

4.2.4 Amber Glass Storage Containers: One-liter wide-mouth amber flint glass bottles with Teflon®-lined caps are required to store impinger water samples. The bottles must be sealed with Teflon® tape.

4.2.5 Rubber Policeman and Funnel: A rubber policeman and funnel are required to aid in the transfer of materials into and out of containers in the field.

5.0 REAGENTS

Reagent grade chemicals or better grades shall be used in all tests. Unless otherwise indicated, all reagents shall conform to the specifications of the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available.

5.1 Water: HPLC-grade water is used in preparation of DNPH reagent and in all other applications in the sampling train.

5.2 Silica Gel: Silica gel shall be indicating type, 6-16 mesh. If the silica gel has been used previously, dry at 175°C (350°F) for 2 h before using. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used.

5.3 Crushed Ice: Quantities ranging from 10-50 lb may be necessary during a sampling run, depending upon ambient temperature. Samples which have been taken must be stored and shipped cold; sufficient ice for this purpose must be allowed.

5.4 2,4-Dinitrophenylhydrazine Reagent: The 2,4-dinitrophenylhydrazine reagent must be prepared in the laboratory within five days of sampling use in the field. Preparation of DNPH can also be done in the field, with consideration of appropriate procedures required for safe handling of solvent in the field. When a container of prepared DNPH reagent is opened in the field, the contents of the opened container should be used within 48 hours. All laboratory glassware must be washed with detergent and water and rinsed with water, methanol, and methylene chloride prior to use.

NOTE: The glassware must not be rinsed with acetone or unacceptable levels of acetone contamination will be introduced. If field preparation of DNPH is performed, caution must be exercised in avoiding acetone contamination.

Reagent bottles for storage of cleaned DNPH derivatizing solution must be rinsed with acetonitrile and dried before use. Baked glassware is not essential for preparation of DNPH reagent.

NOTE: DNPH crystals or DNPH solution should be handled with plastic gloves at all times, with prompt and extensive use of running water in case of skin exposure.

5.4.1 Preparation of Aqueous Acidic DNPH: The following materials and reagents are required for preparation of the reagent.

5.4.1.1 Bottles/Caps: amber 1- or 4 L bottles with Teflon®-lined caps are required for storing cleaned DNPH solution. Additional 4-L bottles are required to collect waste organic solvents.

5.4.1.2 Large Glass Container: at least one large glass container (8 to 16 L) is required for mixing the aqueous acidic DNPH solution.

5.4.1.3 Stir Plate/Large Stir Bars/Stir Bar Retriever: a magnetic stir plate and large stir bar are required for the mixing of the aqueous acidic DNPH solution. A stir bar retriever is needed for removing the stir bar from the large container holding the DNPH solution.

5.4.1.4 Buchner Filter/Filter Flask/Filter Paper: a large filter flask (2-4 L) with a buchner filter, appropriate rubber stopper, filter paper, and connecting tubing are required for filtering the aqueous acidic DNPH solution prior to cleaning.

5.4.1.5 Separatory Funnels: at least one large separatory funnel (2 L) is required for cleaning the DNPH prior to use.

5.4.1.6 Beakers: beakers (150 mL, 250 mL, and 400 mL) are useful for holding/measuring organic liquids when cleaning the aqueous acidic DNPH solution and for weighing DNPH crystals.

5.4.1.7 Funnels: at least one large funnel is needed for pouring the aqueous acidic DNPH into the separatory funnel.

5.4.1.8 Graduated Cylinders: at least one large graduated cylinder (1 to 2 L) is required for measuring HPLC-grade water and acid when preparing the DNPH solution.

5.4.1.9 Top-Loading Balance: a one-place top loading balance is needed for weighing out the DNPH crystals used to prepare the aqueous acidic DNPH solution.

5.4.1.10 Spatulas: spatulas are needed for weighing out DNPH when preparing the aqueous DNPH solution.

5.4.1.11 HPLC-Grade Water: water (HPLC-grade) is required to mix the aqueous DNPH solution.

5.4.1.12 Hydrochloric Acid: reagent grade hydrochloric acid (approximately 12N) is required for acidifying the aqueous DNPH solution.

5.4.1.13 2,4-Dinitrophenylhydrazine: a supply of moist solid 2,4-dinitrophenylhydrazine (DNPH) is required for preparation of aqueous acidic DNPH solution. The quantity of water may vary from 10 to 30%. Reagent grade or equivalent is required.

5.4.1.14 Methylene Chloride: methylene chloride (suitable for residue and pesticide analysis, GC/MS, HPLC, GC, Spectrophotometry or equivalent) is required for cleaning the aqueous acidic DNPH solution, rinsing glassware, and recovery of sample trains.

5.4.1.15 Cyclohexane: cyclohexane (HPLC grade) is required for cleaning the aqueous acidic DNPH solution.

NOTE: Do not use spectroanalyzed grades of cyclohexane if this sampling methodology is extended to aldehydes and ketones with four or more carbon atoms.

5.4.1.16 Methanol: methanol (HPLC grade or equivalent) is required for rinsing glassware.

5.4.1.17 Acetonitrile: acetonitrile (HPLC grade or equivalent) is required for rinsing glassware.

5.4.1.18 Formaldehyde: Analytical grade or equivalent formaldehyde is required for preparation of standards. If other aldehydes or ketones are used, analytical grade or equivalent is required.

5.4.2 Preparation of Aqueous Acidic DNPH Derivatizing Reagent: Each batch of DNPH reagent should be prepared and purified within five days of sampling, according to the procedure described below.

5.4.2.1 Place an 8-L container under a fume hood on a magnetic stirrer. Add a large stir bar and fill the container half full of HPLC-grade water. Save the empty bottle from HPLC-grade water. Start the stirring bar and adjust the stir rate to be as fast as possible. Using a graduated cylinder, measure 1.4 mL of concentrated hydrochloric acid. Slowly pour the acid into the stirring water. Fumes may be generated and the water may become warm. Weigh the DNPH crystals on a one-place balance (see Table 1 for approximate amounts) and add to the stirring acid solution. Fill the 8 L container to the 8 L mark with HPLC water and stir overnight. If all of the DNPH crystals have dissolved overnight, add additional DNPH and stir for two more hours. Continue the process of adding DNPH with additional stirring until a saturated solution has been formed. Filter the DNPH solution using vacuum filtration. Gravity filtration may be used, but a

much longer time is required. Store the filtered solution in an amber bottle at room temperature.

TABLE 1. APPROXIMATE AMOUNT OF CRYSTALLINE DNPH USED TO PREPARE A SATURATED SOLUTION

Amount of Moisture in DNPH	Weight Required per 8 L of Solution
10 weight percent	31 g
15 weight percent	33 g
30 weight percent	40 g

Within five days of proposed use, place about 1.6 L of the DNPH reagent in a 2 L separatory funnel. Add approximately 200 mL of methylene chloride and stopper the funnel. Wrap the stopper of the funnel with paper towels to absorb any leakage. Invert and vent the funnel. Then shake vigorously for 3 minutes. Initially, the funnel should be vented frequently (every 10 - 15 sec). After the layers have separated, discard the lower (organic) layer.

Extract the DNPH a second time with methylene chloride and finally with cyclohexane. When the cyclohexane layer has separated from the DNPH reagent, the cyclohexane layer will be the top layer in the separatory funnel. Drain the lower layer (the cleaned extracted DNPH reagent solution) into an amber bottle that has been rinsed with acetonitrile and allowed to dry.

5.4.3 Quality Control: Take two aliquots of the extracted DNPH reagent. The size of the aliquots is dependent upon the exact sampling procedure used, but 100 mL is reasonably representative. To ensure that the background in the reagent is acceptable for field use, analyze one aliquot of the reagent according to the procedure of EPA Draft Method 8315. Save the other aliquot of aqueous acidic DNPH for use as a method blank when the analysis is performed.

5.4.4 Shipment to the Field: Tightly cap the bottle containing extracted DNPH reagent using a Teflon®-lined cap. Seal the bottle with Teflon® tape. After the bottle is labeled, the bottle may be placed in a friction-top can (paint can or equivalent) containing a 1 -2 inch layer of granulated charcoal and stored at ambient temperature until use.

If the DNPH reagent has passed the Quality Control criteria, the reagent may be packaged to meet necessary shipping requirements and sent to the sampling area. If the Quality Control criteria are not met, the reagent solution may be re-extracted or the solution may be re-prepared and the extraction sequence repeated.

If the DNPH reagent is not used in the field within five days of extraction, an aliquot may be taken and analyzed as described Draft Method 8315. If the reagent meets the Quality Control requirements, the reagent may be used. If the reagent does not meet Quality Control requirements, the reagent must be discarded and new reagent must be prepared and tested.

5.4.5 Calculation of Acceptable Levels of Impurities in DNPH Reagent: The acceptable impurity level (AIL, µg/mL) is calculated from the expected analyte level in the sampled gas (EAL, ppbv), the volume of air that will be sampled at standard conditions (SVOL, L), the formula weight of the analyte (FW, g/mol), and the volume of DNPH reagent that will be used in the impingers (RVOL, mL):

$$AIL = 0.1 \times [EAL \times SVOL \times FW/22.4 \times (FW + 180)/FW]/(RVOL \times 1000).$$

where 0.1 is the acceptable contaminant level, 22.4 is a factor relating ppbv to g/L, 180 is a factor relating the underivatized analyte to the derivatized analyte, and 1000 is a unit conversion factor.

5.4.6 Disposal of Excess DNPH Reagent: Excess DNPH reagent may be returned to the laboratory and recycled or treated as aqueous waste for disposal purposes. 2,4-Dinitrophenylhydrazine is a flammable solid when dry so water should not be evaporated from the solution of the reagent.

5.5 Field Spike Standard Preparation: To prepare a formaldehyde field spiking standard at 4.01 mg/mL, use a 500µL syringe to transfer 0.5 mL of 37% by weight of formaldehyde (401 mg/mL) to a 50 mL volumetric flask containing approximately 40 mL of methanol. Dilute to 50 mL with methanol.

6.0 SAMPLE COLLECTION, PRESERVATION, AND HANDLING

6.1 Because of the complexity of this method, field personnel should be trained in and experienced with the test procedures in order to obtain reliable results.

6.2 Laboratory Preparation:

6.2.1 All the components shall be maintained and calibrated according to the procedure described in APTD-0576, unless otherwise specified.

6.2.2 Weigh several 200- to 300-g portions of silica gel in airtight containers to the nearest 0.5 g. Record on each container the total weight of the silica gel plus containers. As an alternative to preweighing the silica gel, it may instead be weighed directly in the impinger or sampling holder just prior to train assembly.

6.3 Preliminary Field Determinations:

6.3.1 Select the sampling site and the minimum number of sampling points according to EPA Method 1 or other relevant criteria. Determine the stack pressure, temperature, and range of velocity heads using EPA Method 2. A leak-check of the pitot lines according to EPA Method 2, Section 3.1, must be performed. Determine the stack gas moisture content using EPA Approximation Method 4 or its alternatives to establish estimates of isokinetic sampling-rate settings. Determine the stack gas dry molecular weight, as described in EPA Method 2, Section 3.6. If integrated EPA Method 3 sampling is used for molecular weight determination, the integrated bag sample shall be taken simultaneously with, and for the same total length of time as, the sample run.

6.3.2 Select a nozzle size based on the range of velocity heads so that it is not necessary to change the nozzle size in order to maintain isokinetic sampling rates below 28 L/min (1.0 cfm). During the run, do not change the nozzle.

Ensure that the proper differential pressure gauge is chosen for the range of velocity heads encountered (see Section 2.2 of EPA Method 2).

6.3.3 Select a suitable probe liner and probe length so that all traverse points can be sampled. For large stacks, to reduce the length of the probe, consider sampling from opposite sides of the stack.

6.3.4 A minimum of 45 ft³ of sample volume is required for the determination of the Destruction and Removal Efficiency (DRE) of formaldehyde from incineration systems (45ft³ is equivalent to one hour of sampling at 0.75 dscf). Additional sample volume shall be collected as necessitated by the capacity of the DNPH reagent and analytical detection limit constraints. To determine the minimum sample volume required, refer to sample calculations in Section 10.

6.3.5 Determine the total length of sampling time needed to obtain the identified minimum volume by comparing the anticipated average sampling rate with the volume requirement. Allocate the same time to all traverse points defined by EPA Method 1. To avoid timekeeping errors, the length of time sampled at each traverse point should be an integer or an integer plus 0.5 min.

6.3.6 In some circumstances (e.g., batch cycles) it may be necessary to sample for shorter times at the traverse points and to obtain smaller gas-volume samples. In these cases, careful documentation must be maintained in order to allow accurate calculation of concentrations.

6.4 Preparation of Collection Train:

6.4.1 During preparation and assembly of the sampling train, keep all openings where contamination can occur covered with Teflon® film or aluminum foil until just prior to assembly or until sampling is about to begin.

6.4.2 Place 100 mL of cleaned DNPH solution in each of the first two impingers, and leave the third impinger empty. If additional capacity is required for high expected concentrations of formaldehyde in the stack gas, 200 mL of DNPH per impinger may be used or additional impingers may be used for sampling. Transfer approximately 200 to 300 g of pre-weighed silica gel from its container to the fourth impinger. Care should be taken to ensure that the silica gel is not entrained and carried out from the impinger during sampling. Place the silica gel container in a clean place for later use in the sample recovery. Alternatively, the weight of the silica gel plus impinger may be determined to the nearest 0.5 g and recorded.

6.4.3 With a glass or quartz liner, install the selected nozzle using a Viton-A O-ring when stack temperatures are <260°C (500°F) and a woven glass-fiber gasket when temperatures are higher. See APTD-0576 (Rom, 1972) for details. Other connecting systems utilizing either 316 stainless steel or Teflon® ferrules may be used. Mark the probe with heat-resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point.

6.4.4 Assemble the train as shown in Figure 1. During assembly, do not use any silicone grease on ground-glass joints upstream of the impingers. Use Teflon® tape, if required. A very light coating of silicone grease may be used on ground-glass joints downstream of the impingers, but the silicone grease should be limited to the outer portion (see APTD-0576) of the ground-glass joints to

necessary, a leak check shall be conducted immediately after the interruption of sampling and before the change is made. The leak check shall be done according to the procedure described in Section 6.5.1, except that it shall be done at a vacuum greater than or equal to the maximum value recorded up to that point in the test. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable. If a higher leakage rate is obtained, the tester must void the sampling run.

NOTE: Any correction of the sample volume by calculation reduces the integrity of the pollutant concentration data generated and must be avoided.

6.5.2.2 Immediately after a component change and before sampling is re-initiated, a leak check similar to a pre-test leak check must also be conducted.

6.5.3 Post-test Leak Check:

6.5.3.1 A leak check is mandatory at the conclusion of each sampling run. The leak check shall be done with the same procedures as the pre-test leak check, except that the post-test leak check shall be conducted at a vacuum greater than or equal to the maximum value reached during the sampling run. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4% of the average sampling rate (whichever is less), the results are acceptable. If, however, a higher leakage rate is obtained, the tester shall record the leakage rate and void the sampling run.

6.6 Sampling Train Operation:

6.6.1 During the sampling run, maintain an isokinetic sampling rate to within 10% of true isokinetic, below 28 L/min (1.0 cfm). Maintain a temperature around the probe of 120° ± 14°C (248° ± 25°F).

6.6.2 For each run, record the data on a data sheet such as the one shown in Figure 2. Be sure to record the initial dry-gas meter reading. Record the dry-gas meter readings at the beginning and end of each sampling time increment, when changes in flow rates are made, before and after each leak check, and when sampling is halted. Take other readings required by Figure 2 at least once at each sample point during each time increment and additional readings when significant adjustments (20% variation in velocity head readings) necessitate additional adjustments in flow rate. Level and zero the manometer. Because the manometer level and zero may drift due to vibrations and temperature changes, make periodic checks during the traverse.

6.6.3 Clean the stack access ports prior to the test run to eliminate the chance of sampling deposited material. To begin sampling, remove the nozzle cap, verify that the filter and probe heating systems are at the specified temperature, and verify that the pitot tube and probe are properly positioned. Position the nozzle at the first traverse point, with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Nomographs, which aid in the rapid adjustment of the isokinetic sampling rate without excessive computations, are available. These nomographs are designed for use when the Type S pitot tube coefficient is 0.84 ± 0.02 and the stack gas equivalent density (dry molecular weight) is equal to 29 ± 4. APTD-0576 details the procedure for using the nomographs. If the stack gas molecular weight and

minimize silicone grease contamination. If necessary, Teflon® tape may be used to seal leaks. Connect all temperature sensors to an appropriate potentiometer/display unit. Check all temperature sensors at ambient temperature.

6.4.5 Place crushed ice all around the impingers. . .

6.4.6 Turn on and set the probe heating system at the desired operating temperature. Allow time for the temperature to stabilize.

6.5 Leak-Check Procedures:

6.5.1 Pre-test Leak Check:

6.5.1.1 After the sampling train has been assembled, turn on and set the probe heating system at the desired operating temperature. Allow time for the temperature to stabilize. If a Viton-A O-ring or other leak-free connection is used in assembling the probe nozzle to the probe liner, leak-check the train at the sampling site by plugging the nozzle and pulling a 381-mm Hg (15 in Hg) vacuum.

NOTE: A lower vacuum may be used, provided that the lower vacuum is not exceeded during the test.

6.5.1.2 If an asbestos string is used, do not connect the probe to the train during the leak check. Instead, leak-check the train by first attaching a carbon-filled leak check impinger to the inlet and then plugging the inlet and pulling a 381-mm Hg (15 in Hg) vacuum. (A lower vacuum may be used if this lower vacuum is not exceeded during the test.) Then connect the probe to the train and leak-check at about 25 mm Hg (1 in Hg) vacuum. Alternatively, leak-check the probe with the rest of the sampling train in one step at 381 mm Hg (15 in Hg) vacuum. Leakage rates in excess of 4% of the average sampling rate or >0.00057 m³/min (0.02 cfm), whichever is less, are acceptable.

6.5.1.3 The following leak check instructions for the sampling train described in APTD-0576 and APTD-0581 may be helpful. Start the pump with the fine-adjust valve fully open and coarse-adjust valve completely closed. Partially open the coarse-adjust valve and slowly close the fine-adjust valve until the desired vacuum is reached. Do not reverse direction of the fine-adjust valve, as liquid will back up into the train. If the desired vacuum is exceeded, either perform the leak check at this higher vacuum or end the leak check, as shown below, and start over.

6.5.1.4 When the leak check is completed, first slowly remove the plug from the inlet to the probe. When the vacuum drops to 127 mm (5 in) Hg or less, immediately close the coarse-adjust valve. Switch off the pumping system and reopen the fine-adjust valve. Do not reopen the fine-adjust valve until the coarse-adjust valve has been closed to prevent the liquid in the impingers from being forced backward into the sampling line and silica gel from being entrained backward into the third impinger.

6.5.2 Leak Checks During Sampling Runs:

6.5.2.1 If, during the sampling run, a component change (i.e., impinger) becomes

the pitot tube coefficient are outside the above ranges, do not use the nomographs unless appropriate steps are taken to compensate for the deviations.

6.6.4 When the stack is under significant negative pressure (equivalent to the height of the impinger stem), take care to close the coarse-adjust valve before inserting the probe into the stack in order to prevent liquid from backing up through the train. If necessary, the pump may be turned on with the coarse-adjust valve closed.

6.6.5 When the probe is in position, block off the openings around the probe and stack access port to prevent unrepresentative dilution of the gas stream.

6.6.6 Traverse the stack cross section, as required by EPA Method 1, being careful not to bump the probe nozzle into the stack walls when sampling near the walls or when removing or inserting the probe through the access port, in order to minimize the chance of extracting deposited material.

6.6.7 During the test run, make periodic adjustments to keep the temperature around the probe at the proper levels. Add more ice and, if necessary, salt, to maintain a temperature of $<20^{\circ}\text{C}$ (68°F) at the silica gel outlet. Also, periodically check the level and zero of the manometer.

6.6.8 A single train shall be used for the entire sampling run, except in cases where simultaneous sampling is required in two or more separate ducts or at two or more different locations within the same duct, or in cases where equipment failure necessitates a change of trains. An additional train or additional trains may also be used for sampling when the capacity of a single train is exceeded.

6.6.9 When two or more trains are used, separate analyses of components from each train shall be performed. If multiple trains have been used because the capacity of a single train would be exceeded, first impingers from each train may be combined, and second impingers from each train may be combined.

6.6.10 At the end of the sampling run, turn off the coarse-adjust valve, remove the probe and nozzle from the stack, turn off the pump, record the final dry gas meter reading, and conduct a post-test leak check. Also, leak check the pitot lines as described in EPA Method 2. The lines must pass this leak check in order to validate the velocity-head data.

6.6.11 Calculate percent isokineticity (see Method 2) to determine whether the run was valid or another test should be made.

7.0 SAMPLE RECOVERY

7.1 Preparation:

7.1.1 Proper cleanup procedure begins as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool. When the probe can be handled safely, wipe off all external particulate matter near the tip of the probe nozzle and place a cap over the tip to prevent losing or gaining particulate matter. Do not cap the probe tip tightly while the sampling train is cooling because a vacuum will be created, drawing liquid from the impingers back through the sampling train.

7.1.2 Before moving the sampling train to the cleanup site, remove the probe from the sampling train and cap the open outlet, being careful not to lose any condensate that might be present. Remove the umbilical cord from the last impinger and cap the impinger. If a flexible line is used, let any condensed water or liquid drain into the impingers. Cap off any open impinger inlets and outlets. Ground glass stoppers, Teflon® caps, or caps of other inert materials may be used to seal all openings.

7.1.3 Transfer the probe and impinger assembly to an area that is clean and protected from wind so that the chances of contaminating or losing the sample are minimized.

7.1.4 Inspect the train before and during disassembly, and note any abnormal conditions.

7.1.5 Save a portion of all washing solutions (methylene chloride, water) used for cleanup as a blank. Transfer 200 mL of each solution directly from the wash bottle being used and place each in a separate, pre-labeled sample container.

7.2 Sample Containers:

7.2.1 Container 1: Probe and Impinger Catches. Using a graduated cylinder, measure to the nearest mL, and record the volume of the solution in the first three impingers. Alternatively, the solution may be weighed to the nearest 0.5 g. Include any condensate in the probe in this determination. Transfer the impinger solution from the graduated cylinder into the amber flint glass bottle. Taking care that dust on the outside of the probe or other exterior surfaces does not get into the sample, clean all surfaces to which the sample is exposed (including the probe nozzle, probe fitting, probe liner, first impinger, and impinger connector) with methylene chloride. Use less than 500 mL for the entire wash (250 mL would be better, if possible). Add the washings to the sample container.

7.2.1.1 Carefully remove the probe nozzle and rinse the inside surface with methylene chloride from a wash bottle. Brush with a Teflon® bristle brush, and rinse until the rinse shows no visible particles or yellow color, after which make a final rinse of the inside surface. Brush and rinse the inside parts of the Swagelok® fitting with methylene chloride in a similar way.

7.2.1.2 Rinse the probe liner with methylene chloride. While squirting the methylene chloride into the upper end of the probe, tilt and rotate the probe so that all inside surfaces will be wetted with methylene chloride. Let the methylene chloride drain from the lower end into the sample container. The tester may use a funnel (glass or polyethylene) to aid in transferring the liquid washes to the container. Follow the rinse with a Teflon® brush. Hold the probe in an inclined position, and squirt methylene chloride into the upper end as the probe brush is being pushed with a twisting action through the probe. Hold the sample container underneath the lower end of the probe, and catch any methylene chloride, water, and particulate matter that is brushed from the probe. Run the brush through the probe three times or more. With stainless steel or other metal probes, run the brush through in the above prescribed manner at least six times since there may be small crevices in which particulate matter can be entrapped. Rinse the brush with methylene chloride or water, and quantitatively collect these washings in the sample container. After the brushings, make a final rinse

of the probe as described above.

NOTE: Two people should clean the probe in order to minimize sample losses. Between sampling runs, brushes must be kept clean and free from contamination.

7.2.1.3 Rinse the inside surface of each of the first three impingers (and connecting tubing) three separate times. Use a small portion of methylene chloride for each rinse, and brush each surface to which sample is exposed with a Teflon® bristle brush to ensure recovery of fine particulate matter. Water will be required for the recovery of the impingers in addition to the specified quantity of methylene chloride. There will be at least two phases in the impingers. This two-phase mixture does not pour well, and a significant amount of the impinger catch will be left on the walls. The use of water as a rinse makes the recovery quantitative. Make a final rinse of each surface and of the brush, using both methylene chloride and water.

7.2.1.4 After all methylene chloride and water washings and particulate matter have been collected in the sample container, tighten the lid so that solvent, water, and DNPH reagent will not leak out when the container is shipped to the laboratory. Mark the height of the fluid level to determine whether leakage occurs during transport. Seal the container with Teflon® tape. Label the container clearly to identify its contents.

7.2.1.5 If the first two impingers are to be analyzed separately to check for breakthrough, separate the contents and rinses of the two impingers into individual containers. Care must be taken to avoid physical carryover from the first impinger to the second. The formaldehyde hydrazone is a solid which floats and froths on top of the impinger solution. Any physical carryover of collected moisture into the second impinger will invalidate a breakthrough assessment.

7.2.2 Container 2: Sample Blank. Prepare a blank by using an amber flint glass container and adding a volume of DNPH reagent and methylene chloride equal to the total volume in Container 1. Process the blank in the same manner as Container 1.

7.2.3 Container 3: Silica Gel. Note the color of the indicating silica gel to determine whether it has been completely spent and make a notation of its condition. The impinger containing the silica gel may be used as a sample transport container with both ends sealed with tightly fitting caps or plugs. Ground-glass stoppers or Teflon® caps may be used. The silica gel impinger should then be labeled, covered with aluminum foil, and packaged on ice for transport to the laboratory. If the silica gel is removed from the impinger, the tester may use a funnel to pour the silica gel and a rubber policeman to remove the silica gel from the impinger. It is not necessary to remove the small amount of dust particles that may adhere to the impinger wall and are difficult to remove. Since the gain in weight is to be used for moisture calculations, do not use water or other liquids to transfer the silica gel. If a balance is available in the field, the spent silica gel (or silica gel plus impinger) may be weighed to the nearest 0.5 g.

7.2.4 Sample containers should be placed in a cooler, cooled by although not in contact with ice. Sample containers must be placed vertically and, since they are glass, protected from breakage during shipment. Samples should be cooled during shipment so they will be received cold at the laboratory.

8.0 CALIBRATION

8.1 Probe Nozzle: Probe nozzles shall be calibrated before their initial use in the field. Using a micrometer, measure the inside diameter of the nozzle to the nearest 0.025 mm (0.001 in). Make measurements at three separate places across the diameter and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.004 in). When the nozzles become nicked or corroded, they shall be replaced and calibrated before use. Each nozzle must be permanently and uniquely identified.

8.2 Pitot tube: The Type S pitot tube assembly shall be calibrated according to the procedure outlined in Section 4 of EPA Method 2, or assigned a nominal coefficient of 0.84 if it is not visibly nicked or corroded and if it meets design and intercomponent spacing specifications.

8.3 Metering system:

8.3.1 Before its initial use in the field, the metering system shall be calibrated according to the procedure outlined in APTD-0576. Instead of physically adjusting the dry-gas meter dial readings to correspond to the wet-test meter readings, calibration factors may be used to correct the gas meter dial readings mathematically to the proper values. Before calibrating the metering system, it is suggested that a leak check be conducted. For metering systems having diaphragm pumps, the normal leak check procedure will not detect leakages within the pump. For these cases, the following leak check procedure will apply: make a ten-minute calibration run at 0.00057 m³/min (0.02 cfm). At the end of the run, take the difference of the measured wet-test and dry-gas meter volumes and divide the difference by 10 to get the leak rate. The leak rate should not exceed 0.00057 m³/min (0.02 cfm).

8.3.2 After each field use, check the calibration of the metering system by performing three calibration runs at a single intermediate orifice setting (based on the previous field test). Set the vacuum at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet-test meter and the inlet of the metering system. Calculate the average value of the calibration factor. If the calibration has changed by more than 5%, recalibrate the meter over the full range of orifice settings, as outlined in APTD-0576.

8.3.3 Leak check of metering system: The portion of the sampling train from the pump to the orifice meter (see Figure 1) should be leak-checked prior to initial use and after each shipment. Leakage after the pump will result in less volume being recorded than is actually sampled. Use the following procedure: Close the main valve on the meter box. Insert a one-hole rubber stopper with rubber tubing attached into the orifice exhaust pipe. Disconnect and vent the low side of the orifice manometer. Close off the low side orifice tap. Pressurize the system to 13 - 18 cm (5 - 7 in) water column by blowing into the rubber tubing. Pinch off the tubing and observe the manometer for 1 min. A loss of pressure on the manometer indicates a leak in the meter box. Leaks must be corrected.

NOTE: If the dry-gas-meter coefficient values obtained before and after a test series differ by >5%, either the test series must be voided or calculations for test series must be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

8.4 Probe heater: The probe heating system must be calibrated before its initial use in the field according to the procedure outlined in APTD-0576. Probes constructed according to APTD-0581 need not be calibrated if the calibration curves in APTD-0576 are used.

8.5 Temperature gauges: Each thermocouple must be permanently and uniquely marked on the casting. All mercury-in-glass reference thermometers must conform to ASTM E-1 63C or 63F specifications. Thermocouples should be calibrated in the laboratory with and without the use of extension leads. If extension leads are used in the field, the thermocouple readings at ambient air temperatures, with and without the extension lead, must be noted and recorded. Correction is necessary if the use of an extension lead produces a change >1.5%.

8.5.1 Impinger and dry-gas meter thermocouples: For the thermocouples used to measure the temperature of the gas leaving the impinger train, three-point calibration at ice water, room air, and boiling water temperatures is necessary. Accept the thermocouples only if the readings at all three temperatures agree to $\pm 2^{\circ}\text{C}$ (3.6°F) with those of the absolute value of the reference thermometer.

8.5.2 Probe and stack thermocouple: For the thermocouples used to indicate the probe and stack temperatures, a three-point calibration at ice water, boiling water, and hot oil bath temperatures must be performed. Use of a point at room air temperature is recommended. The thermometer and thermocouple must agree to within 1.5% at each of the calibration points. A calibration curve (equation) may be constructed (calculated) and the data extrapolated to cover the entire temperature range suggested by the manufacturer.

8.6 Barometer: Adjust the barometer initially and before each test series to agree to within ± 2.5 mm Hg (0.1 in Hg) of the mercury barometer or the corrected barometric pressure value reported by a nearby National Weather Service Station (same altitude above sea level).

8.7 Triple-beam balance: Calibrate the triple-beam balance before each test series, using Class S standard weights. The weights must be within $\pm 0.5\%$ of the standards, or the balance must be adjusted to meet these limits.

9.0 CALCULATIONS

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

9.1 Calculation of Total Formaldehyde:

To determine the total formaldehyde in mg, use the following equation:

$$\text{Total mg formaldehyde} = C_d \times V \times \text{DF} \times \\ \left(\frac{[\text{g/mole aldehyde}]}{[\text{g/mole DNPH derivative}]} \right) \times \\ 10^{-3} \text{ mg}/\mu\text{g}$$

where:

C_d - measured concentration of DNPH-formaldehyde derivative, $\mu\text{g}/\text{mL}$.

V - organic extract volume, mL

DF - dilution factor

9.2 Formaldehyde concentration in stack gas:

Determine the formaldehyde concentration in the stack gas using the following equation:

$$C_g = K \left[\frac{\text{total formaldehyde, mg}}{V_{m(\text{std})}} \right]$$

where:

$K = 35.31 \text{ ft}^3/\text{m}^3$ if $V_{m(\text{std})}$ is expressed in English units

$= 1.00 \text{ m}^3/\text{m}^3$ if $V_{m(\text{std})}$ is expressed in metric units

$V_{m(\text{std})}$ - volume of gas sample as measured by dry gas meter, corrected to standard conditions, dscm (dscf)

9.3 Average Dry Gas Meter Temperature and Average Orifice Pressure Drop are obtained from the data sheet.

9.4 Dry Gas Volume: Calculate $V_{m(\text{std})}$ and adjust for leakage, if necessary, using the equation in Section 6.3 of EPA Method 5.

9.5 Volume of Water Vapor and Moisture Content: Calculate the volume of water vapor and moisture content from equations 5-2 and 5-3 of EPA Method 5.

10.0 DETERMINATION OF VOLUME TO BE SAMPLED

To determine the minimum sample volume to be collected, use the following sequence of equations.

10.1 From prior analysis of the waste feed, the concentration of formaldehyde (FORM) introduced into the combustion system can be calculated. The degree of destruction and removal efficiency that is required is used to determine the maximum amount of FORM allowed to be present in the effluent. This amount may be expressed as:

Max FORM₁ Mass -

$$[(WF) (FORM_1 \text{ conc}) (100 - XDRE)] / 100$$

where:

WF - mass flow rate of waste feed per h, g/h (lb/h)

FORM₁ - concentration of FORM (wt %) introduced into the combustion process

DRE - percent Destruction and Removal Efficiency required

Max FORM - mass flow rate (g/h [lb/h]) of FORM emitted from the combustion source

10.2 The average discharge concentration of the FORM in the effluent gas is determined by comparing the Max FORM with the volumetric flow rate being exhausted from the source. Volumetric flow rate data are available as a result of preliminary EPA Method 1 - 4 determinations:

$$\text{Max FORM}_1 \text{ conc} = [\text{Max FORM}_1 \text{ Mass}] / DV_{\text{eff(Std)}}$$

where:

DV_{eff(Std)} - volumetric flow rate of exhaust gas, dscm (dscf)

FORM₁ conc - anticipated concentration of the FORM in the exhaust gas stream, g/dscm (lb/dscf)

10.3 In making this calculation, it is recommended that a safety margin of at least ten be included.

$$[\text{LDL}_{\text{FORM}} \times 10] / [\text{FORM}_1 \text{ conc}] = V_{\text{tbc}}$$

where:

LDL_{FORM} - detectable amount of FORM in entire sampling train

V_{tbc} - minimum dry standard volume to be collected at dry-gas meter

10.4 The following analytical detection limits and DNPH Reagent Capacity (based on a total volume of 200 mL in two impingers) must also be considered in determining a volume to be sampled.

Table 2. Instrument Detection Limits and Reagent Capacity for Formaldehyde Analysis¹

Analyte	Detection Limit, ppbv ²	Reagent Capacity, ppmv
formaldehyde	1.8	66
acetaldehyde	1.7	70
acrolein	1.5	75
acetone/propionaldehyde	1.5	75
butyraldehyde	1.5	79
methyl ethyl ketone	1.5	79
valeraldehyde	1.5	84
isovaleraldehyde	1.4	84
hexaldehyde	1.3	88
benzaldehyde	1.4	84
o-/m-/p-tolualdehyde	1.3	89
dimethylbenzaldehyde	1.2	93

¹ Oxygenated compounds in addition to formaldehyde are included for comparison with formaldehyde; extension of the methodology to other compounds is possible.

² Detection limits are determined in solvent. These values therefore represent the optimum capability of the methodology.

11.0 QUALITY CONTROL

11.1 Sampling: See EPA Manual 600/4-77-027b for Method 5 quality control.

11.2 Analysis: The quality assurance program required for this method includes the analysis of field and method blanks, procedure validations, and analysis of field spikes. The assessment of combustion data and positive identification and quantitation of formaldehyde are dependent on the integrity of the samples received and the precision and accuracy of the analytical methodology. Quality Assurance procedures for this method are designed to monitor the performance of the analytical methodology and to provide the required information to take corrective action if problems are observed in laboratory operations or in field sampling activities.

11.2.1 Field Blanks: Field blanks must be submitted with the samples collected at each sampling site. The field blanks include the sample bottles containing aliquots of sample recovery solvents, methylene chloride and water, and unused DNPH reagent. At a minimum, one complete sampling train will be assembled in the field staging area, taken to the sampling area, and leak-checked at the beginning and end of the testing (or for the same total number of times as the actual sampling train). The probe of the blank train must be heated during the sample test. The train will be recovered as if it were an actual test sample. No gaseous sample will be passed through the Blank sampling train.

11.2.2 Method Blanks: A method blank must be prepared for each set of analytical operations, to evaluate contamination and artifacts that can be derived from glassware, reagents, and sample handling in the laboratory.

11.2.3 Field Spike: A field spike is performed by introducing 200 μ L of the Field Spike Standard into an impinger containing 200 mL of DNPH solution. Standard impinger recovery procedures are followed and the field spike sample is returned to the laboratory for analysis. The field spike is used as a check on field handling and recovery procedures. An aliquot of the field spike standard is retained in the laboratory for derivatization and comparative analysis.

12.0 METHOD PERFORMANCE

12.1 Method performance evaluation: The following expected method performance parameters for precision, accuracy, and detection limits are provided in Table 3.


Table 3. Expected Method Performance for Formaldehyde

Parameter	Precision	¹ Accuracy ²	Detection Limit ³
Matrix: Dual trains	$\pm 15\%$ RPD	$\pm 20\%$	1.5×10^{-7} lb/ft ³ (1.8 ppbv)

¹ Relative percent difference limit for dual trains.


² Limit for field spike recoveries.

³ The lower reporting limit having less than 1% probability of false positive detection.



Formaldehyde Sampling Train

Ambient Temperature _____
 Barometric Pressure _____
 Assumed Moisture % _____
 Probe Length, m(ft) _____
 Nozzle Identification No. _____
 Average Calibrated Nozzle Diameter, cm (in) _____
 Probe Heating Setting _____
 Leak Rate, m³/min. (cfm) _____
 Probe Liner Material _____
 Static Pressure, mm Hg (in. Hg) _____
 Filter No. _____




Schematic of Stack Cross Section

Plant _____
 Location _____
 Operator _____
 Date _____
 Run No. _____
 Sample Box No. _____
 Meter Box No. _____
 Meter Hi@ _____
 C Factor _____
 Pilot Tube Coefficient C_p _____


Traverse Point Number	Sampling Time (t) Min.	Vacuum mm Hg (in. Hg)	Stack Temperature (T _s) °C (°F)	Velocity Head (P _v) mm (in) H ₂ O	Pressure Differential Across Orifice Meter mm (in H ₂ O)	Gas Sample Volume m ³ (ft ³)	Gas Sample Temp. at Dry Gas Meter		Filter Holder Temperature °C (°F)	Temperature of Gas Leaving Last Impinger °C (°F)
							Inlet °C (°F)	Outlet °C (°F)		
Total										
Average								Avg.	Avg.	

Figure 2. Field Data Sheet



APPENDIX K

CALCULATION EQUATIONS



METHOD 2
CALCULATION EQUATIONS

$$\bar{V}_s = 85.49 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60 (1 - B_{ws}) \bar{V}_s A \left(\frac{528}{T_{s(avg)}}\right) \left(\frac{P_s}{29.92}\right)$$

$$Q_d = 60 \bar{V}_s A$$

$$\dot{m}_s = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} - 0.0003641 P_s (T_{db} - T_{wb})) / vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

SYMBOLS

A	=	Cross Sectional area of stack, SQ. FT.
A_n	=	Cross sectional area of nozzle, SQ. FT.
B_{ws}	=	Water vapor in gas stream, proportion by volume
C_p	=	Pitot tube coefficient, dimensionless
C_s	=	Concentration of particulate matter in stack gas, wet basis, GR/ACF
C_s	=	Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	=	Excess air, percent by volume
γ	=	Dry test meter correction factor, dimensionless
G_d	=	Specific gravity (relative to air), dimensionless
I	=	Isokinetic variation, percent by volume
M_d	=	Molecular weight of stack gas, dry basis, g/g - mole.
\dot{m}_g	=	Mass flow of wet flue gas, LB/HR
\dot{m}_p	=	Particulate mass flow, LB/HR
M_s	=	Molecular weight of stack gas, wet basis, g/g mole.
M_p	=	Total amount of particulate matter collected, g
P_{bar}	=	Atmospheric pressure, IN. HG. (uncompensated)
P_g	=	Stack static gas pressure, IN. WC.
P_s	=	Absolute pressure of stack gas, IN. HG.
P_{std}	=	Standard absolute pressure, 29.92 IN. HG.
A_s	=	Actual volumetric stack gas flow rate, ACFM
$Q_{s,d}$	=	Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
RH	=	Relative humidity, %

032294-G:STACKWPMETHODS-EQ.15

T_{db}	=	Dry bulb temperature of stack gas, °F
T_{wb}	=	Wet bulb temperature of stack gas, °F
$T_{m(avg)}$	=	Absolute average dry gas meter temperature, °R
$T_{s(avg)}$	=	Absolute average stack temperature, °R
T_{std}	=	Standard absolute temperature, 528 °R (68 °F)
θ	=	Total sampling time, min.
V_{lc}	=	Total volume of liquid collected in impingers and silica gel, ml
V_m	=	Volume of gas sample as measured by dry gas meter, CF
$V_{m(std)}$	=	Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
$V_{w(std)}$	=	Volume of water vapor in the gas sample corrected to standard conditions, SCF
\bar{V}_s	=	Average actual stack gas velocity, FT/SEC
vp_{adb}	=	Vapor pressure at T_{db} , IN. HG.
vp_{awb}	=	Vapor pressure at T_{wb} , IN. HG.
$\overline{\Delta H}$	=	Average pressure differential across the orifice meter, IN. WC.
ΔP	=	Velocity pressure of stack gas, IN. WC.
γ	=	Dry test meter correction coefficient, dimensionless
ρ	=	Actual gas density, LB/ACF

METHOD 3
CALCULATION EQUATIONS

$$\%EA = \frac{100(\%O_2 - 0.5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (I - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

METHOD 5
CALCULATION EQUATIONS

$$V_{m(std)} = 17.65 V_m \gamma \left(\frac{P_{bar} + \overline{\Delta H}/13.6}{T_{m(avg)}} \right)$$

$$V_{w(std)} = 0.0472 V_{Is}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$I = 0.0944 \left(\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (I - B_{ws})} \right)$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_a = \frac{272.3 M_p P_s}{T_{s(avg)} (V_{w(std)} + V_{m(std)})}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_{s,d}$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{\theta A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

CALCULATION EQUATIONS

METHOD 6

$$V_{std} = 17.64 \frac{V_m P_b \gamma}{T_m} \text{ (MIDGET IMPINGER VERSION)}$$

$$V_{std} = \frac{17.64 V_m (P_b + \frac{\Delta H}{13.6}) \gamma}{T_m} \text{ (LARGE IMPINGER VERSION)}$$

$$MEQ = (V_i - V_d) N \left(\frac{V_{soln}}{V_a} \right) DF$$

$$C_s = \frac{7.06 \times 10^{-5} MEQ}{V_{std}}$$

$$E = \frac{20.90 C_s F_d}{20.90 - \bar{B}'_{O_2}} = \frac{F_c C_s}{\bar{B}'_{CO_2}}$$

$$C_s \text{ (MG/DSCM)} = 1.60186 \times 10^7 C_s$$

$$C_s \text{ (GR/DSCF)} = 7000 C_s$$

$$C_s \text{ (ppm, dry)} = 6.02119 \times 10^6 C_s$$

$$C_s \text{ (ppm, wet)} = 6.02119 \times 10^6 C_s \left(1 - \frac{MC}{100} \right)$$

G:\STACK\WPMETHODS\EQ.M6

SYMBOLS

$\bar{B} O_2$	=	Average oxygen content in flue gas, % v/v, dry
$\bar{B} CO_2$	=	Average carbon dioxide content in flue gas, % v/v, dry
C_s	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, LB/DSCF
C_s (GR/DSCF)	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, GR/DSCF
C_s (MG/DSCM)	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, MG/DSCM
DF	=	Dilution Factor
E	=	Emission factor, LB of $SO_2/10^6$ BTU
F _d	=	Dry oxygen F-Factor for given fuel type, DSCF/ 10^6 BTU
F _c	=	Carbon dioxide F-Factor for given fuel type, DSCF/ 10^6 BTU
ΔH	=	Average pressure drop across calibrated orifice, IN. W.C.
Y	=	Dry test meter correction factor, dimensionless
MC	=	Moisture content of flue gas, % v/v
MEQ	=	Total milliequivalents of SO_2 in gas sample
N	=	Normality of barium perchlorate titrant
P_b	=	Barometric pressure at the dry gas meter, IN. HG.
C_s (ppm-dry)	=	Concentration of sulfur dioxide in flue gas, dry basis, (v/v), ppm
C_s (ppm-wet)	=	Concentration of sulfur dioxide in flue gas, wet basis, (v/v), ppm
T_m	=	Absolute average dry gas meter temperature, °R
V_a	=	Volume of sample aliquot titrated, cc
V_m	=	Dry gas volume as measured by the dry gas meter, DCF
V_{std}	=	Dry gas volume as measured by the dry gas meter, corrected to standard conditions (at 68 °F and 1 atmosphere), DSCF

012694-G:\STACK\WP\METHODS\EQ.M6(2)

- V_{soln} = Total volume of the solution in which the sulfur dioxide sample is contained, cc
- V_t = Volume of barium perchlorate titrant used for the sample, cc (average of replicate titrations)
- V_{tb} = Volume of barium perchlorate titrant used for the blank, cc

CALCULATION EQUATIONS

METHOD 7

$$V_{m(std)} = 17.64 (V_f - 25) \left[\frac{P_f}{T_f} - \frac{P_i}{T_i} \right]$$

$$C_s = 6.243 \times 10^{-5} \frac{M}{V_{m(std)}}$$

$$E = \frac{2090 C_s F}{20.9 - \bar{B}'_{O_2}}$$

$$C_s \text{ (GR/DSCF)} = 7000 C_s$$

$$C_s \text{ (MG/DSCM)} = 1.60186 \times 10^7 C_s$$

$$C_s \text{ (ppm-dry)} = 8.37552 \times 10^6 C_s$$

$$C_s \text{ (ppm-3\% } O_2) = 8.37552 \times 10^6 C_s \left\{ 1 + \left[\frac{\bar{B}'_{O_2} - 3}{20.9 - \bar{B}'_{O_2}} \right] \right\}$$

$$C_s \text{ (ppm-wet)} = 8.37552 \times 10^6 C_s \left(1 - \frac{MC}{100} \right)$$

G:\STACK\WPMETHODS\EQ.M7

SYMBOLS

$\bar{B} O_2$	=	Average oxygen content in flue gas, % v/v
C_s	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, LB/DSCF
C_s (GR/DSCF)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, GR/DSCF
C_s (MG/DSCM)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to standard conditions, MG/DSCM
E	=	Emission factor, LB/10 ⁶ BTU
F	=	F-Factor for given fuel type, DSCF/10 ⁶ BTU
M	=	Mass of nitrogen oxides as nitrogen dioxide in gas sample, ug
MC	=	Moisture content of flue gas, %
P_f	=	Final absolute pressure in flask, IN. HG
P_i	=	Initial absolute pressure in flask, IN. HG
C_s (ppm-dry)	=	Concentration of nitrogen oxides in flue gas, dry basis, (v/v), ppm
C_s (ppm-3% O ₂)	=	Concentration of nitrogen oxides in flue gas, dry basis, corrected to 3% O ₂ , (v/v) ppm
C_s (ppm-wet)	=	Concentration of nitrogen oxides in flue gas, wet basis, (v/v), ppm
T_f	=	Final absolute temperature in flask, °R
T_i	=	Initial absolute temperature in flask, °R
V_f	=	Volume of flask and valve, cc
$V_{m(std)}$	=	Sample volume at standard conditions, dry basis, cc

CALCULATION EQUATIONS

METHOD 10

$$CO\text{-}PPM\text{-}DRY = CO_{CO_2} - \text{free, dry, avg} (1 - CO_{2,d}/100)$$

$$CO\text{-}PPM\text{-}WET = CO\text{-}PPM\text{-}DRY (1 - MC/100)$$

$$GR/DSCF = 5.0885 \times 10^{-4} (CO\text{-}PPM\text{-}DRY)$$

$$mg/dscm = 1.165 (CO\text{-}PPM\text{-}DRY)$$

$$\dot{m} = 8.5714 \times 10^{-3} (GR/DSCF) (Q_{s,d})$$

$$E = \frac{2.9857 \times 10^{-3} F_d (GR/DSCF)}{20.9 - O_{2,d}}$$

where:

$CO_{CO_2} - \text{free, dry, avg}$

= average of two determinations of carbon monoxide on a dry, CO_2 - free integrated flue gas sample reported in ppm by volume

$CO_{2,d}$

= carbon dioxide concentration of flue gas on a dry percent by volume basis

$O_{2,d}$

= oxygen concentration of flue gas on a dry percent by volume basis

MC	=	moisture content of flue gas on a percent by volume basis
CO-PPM-DRY	=	carbon monoxide concentration in ppm by volume on a dry basis
CO-PPM-WET	=	carbon monoxide concentration in ppm by volume on a wet or actual basis
GR/DSCF	=	concentration of carbon monoxide in flue gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
mg/dscm	=	concentration of carbon monoxide in flue gas on a milligrams per dry standard cubic meter basis (60 °F, 29.92 IN. HG.)
m	=	emissions or mass rate of carbon monoxide on a LB/HR basis
$Q_{s,d}$	=	volumetric flow rate of flue gas in dry standard cubic feet per minute
E	=	emission factor of carbon monoxide in pounds of carbon monoxide emitted per million BTU heat input (LB/MMBTU)
F_d	=	F-Factor of respective fuel in dry standard cubic feet of exhaust gas at 0% oxygen per million BTU of heat input (DSCF/MMBTU)

METHOD 25A

Total Gaseous Organics Calculation Equation

$$\begin{aligned} \text{GR C/SCF} &= 2.180 \times 10^{-4} \text{ (ppm, w)} \\ \text{GR C/DSCF} &= 2.180 \times 10^{-4} \text{ (ppm, w)/(1-MC/100)} \\ \text{LB C/HR} &= 8.5714 \times 10^{-3} \text{ (GR/DSCF) (DSCFM)} \end{aligned}$$

where:

$$\begin{aligned} \text{GR C/SCF} &= \text{grains of total gaseous organics as carbon per actual (wet) standard cubic foot} \\ \text{GR C/DSCF} &= \text{grains of total gaseous organics as carbon per dry standard cubic foot} \\ \text{LB C/HR} &= \text{pounds of total gaseous organics as carbon emitted per hour} \end{aligned}$$

Note 1: The Ratfisch Model RS 55 Heated FID Analyzer as normally operated with a heated filter, sample line and heated detector oven gives ppm, w.

Note 2: ppm, C = ppm as carbon = 3(ppm propane)

CALCULATION EQUATIONS

Chromotropic Acid Method for Formaldehyde

$$m_t = \frac{m_a V_{soln}}{V_{aliqu}}$$

where:

m_t	=	mass of formaldehyde in total sample in ug
m_a	=	mass of formaldehyde in aliquot in ug
V_{soln}	=	volume of total sample in cc (500 cc normally)
V_{aliqu}	=	volume of aliquot taken for analysis in cc
PPM·DRY	=	$\frac{0.0283 m_t}{V_{std}}$
PPM·WET	=	PPM·DRY (1-MC/100)
GR/DSCF	=	5.45×10^{-4} (PPM·DRY)
mg/dscm	=	1.249 (PPM·DRY)
\dot{m}	=	8.5714×10^{-3} (GR/DSCF) ($Q_{s,d}$)

where:

PPM·DRY	=	concentration of formaldehyde in parts per million by volume on a dry basis
PPM·WET	=	concentration of formaldehyde in parts per million by volume on an actual or wet basis
MC	=	moisture content of gas on a percent by volume basis
GR/DSCF	=	concentration of formaldehyde in gas on a grains per dry standard cubic foot basis (68 °F, 29.92 IN. HG.)
\dot{m}	=	emission or mass rate of formaldehyde in pounds per hour (LB/HR)
V_{std}	=	dry gas volume as measured by the dry gas meter, corrected to standard conditions (at 68 °F and 1 atmosphere) DSCF

031894-G:\STACK\WPMETHODSS-EQ.03

Concentration Calculation Equations for MDI

1. Structure:	2. Molecular weight: <u>250.26</u> g/g-mole
<p>3. Mass/volume Concentration:</p> $C_{ug/Nm^3} = \frac{35.314 \text{ m}}{V_{std}}$ <p>where m = Total mass of <u>MDI</u> in sample in micrograms (ug), and</p> <p>Vstd = Total volume of exhaust gas or air sampled in dry standard cubic feet (DSCF).</p>	
<p>4. Volume/volume Concentration:</p> $C_{ppmv} = \left(\frac{24.054 \text{ ul}}{250.26 \text{ ug}} \right) \left(\frac{1/Nm^3}{1000L} \right) \left(\frac{35.314 \text{ m}}{V_{std}} \right)$ $C_{ppmv} = (9.612 \times 10^{-5}) C_{ug/Nm^3}$	
<p>5. Notes: * see Excel spreadsheet: G:\STACK\EXCEL\TEMPLATE\MDI.TEM</p>	
Derived by: <u>Shari P.</u>	Date: <u>4-27-95</u>

INTERPOLL LABORATORIES, INC.
(612) 786-6020

Average Gas Concentration (Eq. 6C - 1)

$$C_{gas} = (\bar{C} - C_o) \frac{C_{MA}}{(C_M - C_o)}$$

$$C_o = \frac{C_{oi} + C_{of}}{2}$$

where: C_{oi} : Initial zero response
 C_{of} : Final zero response

$$C_M = \frac{C_{si} + C_{sf}}{2}$$

where: C_{si} : Initial span response
 C_{sf} : Final span response

C_{MA} = Span tank concentration

\bar{C} = Data logger average


		LOUISIANA PACIFIC CORPORATION		Report No. 6-8201			
		Newberry, Michigan					
PRESS VENTS							
	8/29/96						
MDI CALCULATIONS							
TIME	Vstd	Mass	Flow	Conc	Mass Rate		
(HRS)	(DSCF)	(ug)	DSCFM	(mg/Nm3)	(LB/HR)		
1	0900-1002	44.41	310	202257	0.246	0.0237	0.1867
2	1035-1136	44.93	270	205362	0.212	0.0204	0.1632
3	1210-1311	44.26	57	201740	0.045	0.0044	0.0344
AVG			212		0.168		0.1281

		LOUISIANA PACIFIC		Report No. 6-8201	
TEST 2		Newberry, Michigan			
DRYER RTO OUTLET					
Sulfur Dioxide					
		Flow	LB/DSCF	LB/HR	
SO2 ppm					
RUN					
1	<	36861	1.66E-07	<	0.368
2	<	34827	1.66E-07	<	0.347
3	<	35163	1.66E-07	<	0.351
AVG	<			<	0.355
Oxides of Nitrogen					
		Flow	LB/DSCF	LB/HR	
NOX ppm					
RUN					
1		36861	2.66E-06		5.889
2		34827	3.12E-06		6.512
3		35163	2.79E-06		5.894
AVG					6.098
Carbon Monoxide					
		Flow	LB/DSCF	LB/HR	
CO ppm					
RUN					
1		36861	6.34E-05		119.3406
2		34827	2.97E-05		56.42628
3		35163	3.07E-05		63.283
AVG					79.6833
DRYER PRIMARY CYCLONE EXHAUST					
TEST 2					
Oxides of Nitrogen					
		Flow	LB/DSCF	LB/HR	
NOX ppm					
RUN					
1		38.95	4.65E-06		8.75005
2		19.80	2.36E-06		4.484063
3		25.49	3.04E-06		6.283227
AVG		28.08			6.50578
Carbon Monoxide					
		Flow	LB/DSCF	LB/HR	
CO ppm					
RUN					
1		872.93	6.34E-05		119.3406
2		409.42	2.97E-05		56.42628
3		421.86	3.07E-05		63.283
AVG		568.07			79.6833
E-TUBE OUTLET					
TEST 2					
Oxides of Nitrogen					
		Flow	LB/DSCF	LB/HR	
NOX ppm					
RUN					
1		13.23	1.58E-06		3.319358
2		14.05	1.68E-06		3.740586
3		17.66	2.11E-06		4.577708
AVG		14.98			3.879217
Carbon Monoxide					
		Flow	LB/DSCF	LB/HR	
CO ppm					
RUN					
1		770.34	5.6E-05		117.6203
2		356.11	2.59E-05		57.697
3		412.34	3E-05		65.04571
AVG		512.93			80.12102
PRESS VENTS					
TEST 9					
Oxides of Nitrogen					
		Flow	LB/DSCF	LB/HR	
NOX ppm					
RUN					
1		0.84	1E-07		1.152597
2		1.61	1.92E-07		2.171429
3		1.41	1.68E-07		1.958039
AVG		1.29			1.760688
Carbon Monoxide					
		Flow	LB/DSCF	LB/HR	
CO ppm					
RUN					
1		6.19	4.5E-07		5.168857
2		3.18	2.31E-07		2.610073
3		2.40	1.74E-07		2.028239
AVG		3.92			3.269056

6-8201.WET


		ILP/NEWBERRY				Report No. 6-8201			
		DRYER RTO OUTLET							
		TEST 2							
		NOX		NOX		CO		CO	
RUN	WET	MC	DRY	WET	DRY	WET	DRY	MC	DRY
1	17.2	22.8	22.3	60.09	77.8	1	22.8	22.8	77.8
2	19.4	25.7	26.1	39.5	53.2	2	25.7	25.7	53.2
3	17.4	25.5	23.4	22.28	29.9	3	25.5	25.5	29.9
AVG	18.0		23.9	40.6	53.6	AVG			53.6

Report No. 6-8201										
LOUISIANA PACIFIC CORPORATION NEWBERRY, MICHIGAN										
Total HydroCarbons Calculations										
Dryer Primary Cyclone Exhaust										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)	(GR/DSCF)		
2	1	24.2	321	31359	24.81			0.0923193		
	2	22.8	276	31613	21.12			0.0779378		
	3	19.2	280	34409	22.28			0.0755446		
						292.33333	22.73793			
E-Tube Outlet										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)	(GR/DSCF)		
2	1	27.5	245	35023	22.12			0.0736669		
	2	25.1	148	37164	13.72			0.0430761		
	3	26.5	131	36184	12.05			0.0388544		
						174.66667	15.96251			
Dryer RTO Outlet										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)	(GR/DSCF)		
2	1	22.8	5.75	36861	0.51			0.0016237		
	2	25.7	< 1	34824	< 0.09			0.0002934		
	3	25.5	< 1	35163	< 0.09			0.0002926		
						2.5833333	0.229594			
Press Vents										
TEST #	RUN	MC%	CONC (ppmC,w)	GASFLOW (DSCFM)	MASSRATE (LB/HR)	AVERAGE (ppmC,w)	AVERAGE (LB/HR)	(GR/DSCF)		
9	1	1.6	1.9	202257	0.73			0.0004209		
	2	1.2	10.4	205362	4.04			0.0022947		
	3	1.5	3.4	201740	1.30			0.0007525		
						5.2333333	2.023409			



APPENDIX L

SAMPLING TRAIN CALIBRATION DATA



EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job L.P. Newberry Date 8-27-96
Operator E. J. Module No. 4

Instructions:

Operate the control module at a flow rate equal to $\Delta H @$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.26 in.Hg $\theta =$.9945 $\Delta H @$ 1.78 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(782.30)		
2.5	784.19	59	55
5.0	786.06	61	57
7.5	787.95	62	57
10	789.81	64	58
	$V_m = 7.5$	Avg(t_m) =	59.13 °F

Calculate Y_m as follows:


$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_m = \frac{1.786}{(.9945)(7.5)} \left[\frac{(59.13) + 460}{(29.26)} \right]^{0.5} (1.2)$$

$$Y_m = \underline{1.00}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1



INTERPOLL LABORATORIES, INC.
(612) 786-6020

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job C.P. Newberry Date 8-28-96
Operator EJ Module No. 4

Instructions:

Operate the control module at a flow rate equal to $\Delta H @$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.31 in.Hg $\theta =$.9945 $\Delta H @$ 1.75 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(110.00)		
2.5	111.90	64	61
5.0	113.80	66	62
7.5	115.72	67	62
10	117.64	69	63
	$V_m = 7.64$	Avg(t_m) =	64.25 °F

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(.9945)(7.64)} \left[\frac{(64.25) + 460}{(29.31)} \right]^{0.5} = 4.23$$

$$Y_{cn} = \underline{.994}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP/NEWHERY Date 8-27-98
Operator R. ROSENTHAL Module No. 7

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.26 in.Hg $\theta =$.9976 $\Delta H@$ 1.95 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(665.20)		
2.5	667.06	64	58
5.0	668.92	67	59
7.5	670.78	71	60
10	672.72	71	61
	$V_m = 7.52$	Avg(t_m) =	63.8 °F

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$= \frac{1.786}{(0.9976)(7.52)} \left[\frac{(63.8 + 460)}{(29.26)} \right]^{0.5}$$

$$= \frac{1.786}{7.49} \left[\frac{523.8}{29.26} \right]^{0.5}$$

$$= \frac{1.786}{7.49} \left[18.24 \right]^{0.5}$$

$$= \frac{1.786}{7.49} (4.27)$$

$$Y_m = \underline{1.007}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP/NEWBERRY Date 8-28-96
 Operator R. ROSENTHAL Module No. 7

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.36 in.Hg $\theta =$ 1.95 $\Delta H@$.9976 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(847.90)		
2.5	849.82	61	58
5.0	851.68	67	60
7.5	853.55	70	60
10	855.41	72	61
	$V_m = 7.51$	Avg(t_m) =	63.6 °F

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$\frac{7.492}{.2384} \quad 4.223$

$$Y_m = \frac{1.786}{() ()} \left[\frac{() + 460}{()} \right]^{0.5}$$

$Y_m = \underline{1.006}$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job LP/NEWBERRY Date 8-28-96
Operator R. ROSENTHAL Module No. 9

Instructions:

Operate the control module at a flow rate equal to $\Delta H @$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.36 in.Hg $\theta =$ 1.80 $\Delta H @$ 1.0034 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(212.30)		
2.5	214.17	59	56
5.0	216.05	60	57
7.5	217.92	61	57
10	219.80	64	58
	$V_m = 7.50$	Avg(t_m) = 59	°F

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$= \frac{1.786}{7.525 \cdot 1.2373} \left[\frac{(\quad) + 460}{(\quad)} \right]^{0.5}$$

$$Y_m = \underline{.997}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

INTERPOLL LABORATORIES, INC.
(612) 786-6020

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job A.P. / Liberty, MI Date 8-27-96
 Operator M. Kowalek Module No. 10

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.26 in.Hg $\theta =$ 1.0007 $\Delta H@$ 1.93 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(494.30)		
2.5	496.22	75	74
5.0	498.05	76	73
7.5	499.90	77	72
10	501.73	79	72
	$V_m = 7.43$	$Avg(t_m) = 74.75$ °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{(1.0007)(7.43)} \left[\frac{(74.75) + 460}{(29.26)} \right]^{0.5}$$

$$Y_{cn} = \underline{1.027}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

EPA Method 5 Gas Metering System Quality Control Check Data Sheet

Job Louisiana Pacific / Newberry Date 8-26-96
 Operator Mark Petersen Module No. 14

Instructions:

Operate the control module at a flow rate equal to $\Delta H@$ for 10 minutes before attaching the umbilical.

Record the following data:

Bar press 29.20 in.Hg $\theta =$.9929 $\Delta H@$ 1.82 in.WC.

Time (min)	Volume (CF)	Meter Temp (°F)	
		Inlet	Outlet
	(575.00)		
2.5	576.88	82	73
5.0	578.76	83	73
7.5	580.65	84	73
10	582.53	85	73
	$V_m = 7.53$	$Avg(t_m) = 78.25$	°F

Calculate Y_m as follows:

$$Y_m = \frac{1.786}{\theta V_m} \left[\frac{(t_m + 460)}{P_s} \right]^{0.5}$$

$$Y_m = \frac{1.786}{(0.9929)(7.53)} \left[\frac{(78.25) + 460}{(29.20)} \right]^{0.5}$$

$$Y_m = \underline{1.026}$$

If Y_m is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: September 3, 1996

Meter Box No. : 4 (Rockwell Dry Test Meter Serial No. 964552)

Date of Last Calibration: August 6, 1996

Calibration Technician: S. Fjelsta

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
August 23, 1996	6-8194	648.20	775.56	127.36	127.36
August 27, 1996	6-8201	782.30	1280.64	498.34	625.70

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: September 3, 1996

Meter Box No. : 7 (Rockwell Dry Test Meter Serial No. 964550)

Date of Last Calibration: February 7, 1996

Calibration Technician: S. Kelker

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter		Final Meter		Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
		Reading	Reading	Reading	Reading		
March 22, 1996	6-7452	719.60	821.88	821.88	102.28	102.28	
May 02, 1996	6-7648	831.50	942.71	942.71	111.21	213.49	
June 18, 1996	6-7862	953.10	1584.11	1584.11	631.01	844.50	
August 20, 1996	6-8174	1586.00	1662.73	1662.73	76.73	921.23	
August 27, 1996	6-8201	1665.20	2016.73	2016.73	351.53	1272.76	

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: September 3, 1996

Meter Box No. : 9 (Rockwell Dry Test Meter Serial No. 964549)

Date of Last Calibration: January 15, 1996

Calibration Technician: S. Fjelsta

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
August 8, 1996	6-8085	660.50	954.80	294.30	294.30
August 20, 1996	6-8173	959.20	1210.89	251.69	545.99
August 28, 1996	6-8201	1212.30	1219.80	7.50	553.49

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: September 3, 1996

Meter Box No. : 10 (Rockwell Dry Test Meter Serial No. 1334112)

Date of Last Calibration: August 23, 1996

Calibration Technician: D. Van Hoever

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
August 27, 1996	6-8201	494.30	981.60	487.30	487.30

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: September 3, 1996

Meter Box No. : 14 (Rockwell Dry Test Meter Serial No. 1334123)

Date of Last Calibration: August 5, 1996

Calibration Technician: S. Fjelsta

Wet Test Meter No.: American Meter AL-20


Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
August 8, 1996	6-8085	256.00	559.76	303.76	303.76
August 27, 1996	6-8201	575.00	926.25	351.25	655.01

* Total volume through meter since last calibration.

Meter Calibration Sheet EPA/Method 5

Date: 8-6-96 Control Module No. 4
 Bar. Press. 29.98 IN.HG Technician 9 JSSZ
 Wet Test Meter No. AL-20 SF

Delta H (IN.WC) Nominal	Delta H (IN.WC) Actual	Gas Volume Wet Test Meter (ft³)	* Cal. Index φ (%)	* Diff. Wet Test Meter ΔP _w (IN.WC.)	Gas Temperatures			Time θ (Min/Sec)	Meter Coeff.	Orifice Const. ΔH ₀	C _i	
					Wet Test T _w (°F)	Dry Test T _d (°F)	T _{amb} (°F)					
0.5	0.5	2	99.85	0.01	V _d : 626.37	V _w : 638.40	T _w : 73	T _d : 86	T _{amb} : 80	4/53	1.00090	1.711
1.2	1.2	3	99.91	0.025	V _d : 642.57	V _w : 645.58	T _w : 73	T _d : 89	T _{amb} : 82	4/50	.99612	1.778
2.0	2.0	3	99.93	0.055	V _d : 629.20	V _w : 632.27	T _w : 73	T _d : 88	T _{amb} : 79	3/43	.99059	1.758
3.3	3.3	5	100.00	0.09	V _d : 617.00	V _w : 622.07	T _w : 73	T _d : 85	T _{amb} : 77	4/48	.99246	1.747
4.7	4.7	5	100.02	0.12	V _d : 623.60	V _w : 628.68	T _w : 73	T _d : 89	T _{amb} : 79	4/04	.99262	1.775
AVG										11/72	.9945	1.75

Positive leak check performed by SF : readjusted linkage
 Meter was in tolerance : Meter was not in tolerance
 Approved by  Date 8/6/96 : changed dry test meter
 *Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

Meter Calibration Sheet EPA/Method 5

Date: 2/27/96 Control Module No. 7
Bar. Press. 28.6 IN.HG Serial No. DIM 964550
Wet Test Meter No. AL-20 Technician Steve Keller

ΔH (IN.WC)	Nominal	Actual	Gas Volume Wet Test Meter (ft ³)	Cal. Index ϕ (%)	Diff. Wet Test Meter ΔP_w (IN.WC.)	Gas Volume Dry Test Meter (ft ³)			Gas Temperatures				Time t_0 (Min/Sec)	Meter Ccoeff.	Orifice Const.	C_1
						V_w	V_d	V_H	Wet Test t_w ($^{\circ}$ F)	Dry Test	t_d ($^{\circ}$ F)	t_{do} ($^{\circ}$ F)				
	0.5		2	99.85	0.01	684.210	686.212		70	74	71	5/03	1.0009	1.869		
	1.2		3	99.91	0.025	680.194	683.208		70	71	70	4/58	.9923	1.933		
	2.0		3	99.93	0.055	676.205	679.287		69.8	75	71	3/54	.9961	1.915		
	3.3		5	100.00	0.09	688.198	693.199		70	80	72	5/03	.9930	1.973		
	4.7		5	100.02	0.12	695.190	700.191		70	86	73	4/17	1.0055	1.989		
													AVG	.9976	1.95	

Positive leak check performed by SK
Meter was in tolerance
Approved by _____ Date 2/28/96
*Based on AI-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.
 Meter was not in tolerance
 Meter was not in tolerance
 readjusted linkage
 changed dry test meter

Meter Calibration Sheet EPA/Method 5

Date 8/23/96
Bar. Press. 29.33
Wet Test Meter No. AL-20

Control Module No. 10
Serial No. DTM 137412
Technician J. Santorice

ΔH (IN.WC)		Gas Volume Wet Test Meter (ft ³)	Cal. Index φ (%)	* Diff. Wet Test Meter ΔP _w (IN.WC.)	Gas Volume Dry Test Meter (ft ³)		Gas Temperatures			Time θ (Min/Sec)	Meter Coeff.	Orifice Const.	C ₁
Nominal	Actual				V _w	V _d	Wet Test T _w (°F)	Dry Test T _d (°F)	T _{db} (°F)				
0.5	1.5	21.5	99.05	0.01	490.375	491.905	70.5	87	73	3:48	9932	1.81	
1.2	1.2	21.5	99.91	0.025	487.33	489.86	70.5	89	73	4:15	10037	1.95	
2.0	2.0	3	99.93	0.055	473.84	476.84	71.5	79	67	3:56	9970	1.97	
3.3	3.3	53.5	100.00	0.09	477.34	480.84	71.5	84	69	3:34	10009	1.95	
4.7	4.7	5	100.02	0.12	481.83	486.83	70.5	90	71	4:18	10069	1.96	
											1007	1.93	
											AVG		

Meter was not in tolerance : readjusted linkage
 Meter was not in tolerance : changed dry test meter
 Date 8/23/96


Positive leak check performed by [Signature]
 Meter was in tolerance
 Approved by [Signature]
 *Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS traceable) - Carl Poe Co.

INTERPOL LABORATORIES, INC.
(612) 706-6020

Meter Calibration Sheet EPA/Method 5

Date: 8-5-96 Control Module No. 14
 Bar. Press. 28.87 IN.HG Technician SF
 Wet Test Meter No. AL-20 Serial No. DTM 1334123

Nominal ΔH (IN.WC)	Actual	Gas Volume Wet Test Meter (ft ³)	Cal. Index φ (%)	* Diff. Wet Test Meter ΔP _w (IN.WC.)	Gas Volume Dry Test Meter (ft ³)		Wet Test T _w (°F)	Gas Temperatures			Time θ (Min/Sec)	Meter Coeff.	Orifice Const.	C ₁	
					V _{d1}	V _{d2}		I ₁₁ (°F)	I ₁₂ (°F)	I ₁₆ (°F)					
0.5	.5	2	99.85	0.01	247.74	249.80	71	90	78		4/55	.99882	1.725		
1.2	1.2	3	99.91	0.025	244.31	247.41	71	93	78		4/55	.99018	1.833		
2.0	2.0	3	99.93	0.055	227.22	230.28	71	87	76		3/48	.99388	1.837		
3.3	3.3	5	100.00	0.09	231.21	236.33	74	93	77		4/57	.99373	1.837		
4.7	4.7	5	100.02	0.12	238.05	243.17	71	97	78		4/11	.99489	1.855		
												.9948	1.837		
AVG													.9927	1.818	

Positive leak check performed by SF Meter was not in tolerance ; readjusted linkage
 Meter was in tolerance ; changed dry test meter
 Approved by  Date 8-6-96
 *Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.



INCORPORATED A BTR Company
805 Liberty Blvd., DuBois, PA 15801

TEST METER PERFORMANCE

METER SIZE: R-275 STD
SERIAL NUMBER: 1334123
CUSTOMER NAME: CONTROLS & METERS, INC.
ORDER NUMBER: 913-73640-001


Meter Box #
14

CURVE NUMBER 12

PERCENT ERROR (%)

CERTIFIED AS TO
ACTUAL TEST DATA
J.A. Conkle
DATE: Yoct 7, 1992

0 20 40 60 80 100
FLOWRATE PERCENT OF CAPACITY, AIR (%)



Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor

Wauetek

Model

OM23XT

Range

0 - 1900 °F

Serial Number

50610065 #2

Thermocouple Type

K

Date of Calibration

8-5-76

Technician

Mark Peterson

Method of Calibration:

PDT No.

UB

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add \pm degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	1	1	0.22
100	100	98	2	0.36
200	200	202	2	.30
300	300	300	0	0
400	400	397	3	.35
500	500	497	3	.31
600	600	600	0	0
700	700	700	0	0
800	800	806	6	.48
900	900	908	8	.59
1000	1000	1013	13	.89
1100				
1200				
1300				
1400				
1500				
1600				
1700				
1800				
1900				
2000				
2100				
		Averages:	3.45	0.38

Off = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

Unit in tolerance

Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:STACKIWPFORMS-433

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Model: Omega HH91 Serial Number: NC-737X1493
 Range: 0-2100 °F Thermocouple Type: K
 Date of Calibration: 5/22/96 Technician: Steve Kalkreuth
 Method of Calibration: PDT No. 37

- Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-4	4	.870
100	100	97	3	.536
200	200	198	2	.303
300	300	297	3	.395
400	400	396	4	.465
500	500	497	3	.313
600	600	598	2	.189
700	700	698	2	.172
800	800	800	0	0
900	900	899	1	.074
1000	1000	999	1	.068
1100	1100	1097	3	.192
1200	1200	1199	1	.060
1300	1300	1297	3	.170
1400	1400	1400	0	0
1500	1500	1498	2	.102
1600	1600	1600	0	0
1700	1700	1698	2	.093
1800	1800	1800	0	0
1900	1900	1897	3	.127
2000	2000	1998	2	.081
2100	2100	2095	5	.195
		Averages:	2.09	.200

* Unit in tolerance
 OF = off scale response by unit under test (°F)

% dev = $100 \Delta t / (460 + t)$

Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:STACKWP\FORM55-33

Temperature Measurement Device Calibration Sheet

Unit Under Test:

Vendor: Omega

Model: HHS1

Range: _____ °F

Date of Calibration: 7-11-92

Method of Calibration:

Serial Number: 745x1560

Thermocouple Type: K

Technician: O. Hullemann

PDT No.: 45

- Comparison against ASTM mercury in glass thermometer using a thermostated and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees). The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	-3	3	2.65
100	100	98	2	3.35
200	200	200	0	0.00
300	300	298	2	0.26
400	400	398	2	0.23
500	500	498	2	0.21
600	600	600	0	0.00
700	700	698	2	0.17
800	800	801	1	0.08
900	900	899	1	0.07
1000	1000	1000	0	0.00
1100	1100	1100	0	0.00
1200	1200	1200	0	0.00
1300	1300	1298	2	0.11
1400	1400	1401	1	0.05
1500	1500	1499	1	0.05
1600	1600	1602	2	0.10
1700	1700	1700	0	0.00
1800	1800	1802	2	0.16
1900	1900	1900	0	0.00
2000	2000	2000	0	0.00
2100	2100	2099	1	0.04
		Averages:	1.09	0.11

OF = off scale response by unit under test (°F)

Unit in tolerance

% dev = $100 \Delta t / (460 + t)$


Unit was not in tolerance: recalibrated - See new calibration sheet.

011995-G:STACKWPAFORMSS-433

NET TEST SUBJECT

PULSATYON RANGE

DIFFERENTIAL - INCHES H₂O



Calibrated with a 10 ft. American Bell Prover, Serial No. 3157. Traceable to the Bureau of Standards. Reference No. 5249060, PI-TAPE.

AL-20 American Met Test Meter
 Serial No. p. 211
 Stainless Steel w/Removable Back
 Calibrated w/Saturated Air
 Water Temp. 74° F.
 Air Temp. 74° F.
 Inlet Pressure 2" H₂O Constant
 Calibration Rate: 60 CFH Per/Mr.
 Capacity Rate: 120 CFH Per/Mr.
 Restricted Outlet for Rate Deviation

DAVID DARKS

FLOW RATE CUBIC FEET OF AIR PER MINUTE

S-Type Pitot Tube Inspection Sheet

Probe or Pitot Tube No. 27-4A (Glass)

Pitot tube dimensions:

1. External tubing diameter (D) .312 IN.
2. Base to Side A opening plane (P_A) .4665 IN.
3. Base to Side B opening plane (P_B) .470 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ $< 10^\circ$ $10'$
5. $\alpha_2 < 10^\circ$ $< 10^\circ$ $0^\circ 55'$

6. $B_1 < 5^\circ$ $< 5^\circ$ $0^\circ 50'$
7. $B_2 < 5^\circ$ $< 5^\circ$ $0^\circ 15'$

8. Z $< .125''$ $< .125''$ $.029''$
9. W $< .0625''$ $< .0625''$ A. $.0175$ B. $.015$

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle $\frac{3}{4}''$ $.764''$
11. Pitot to probe sheath $\frac{3}{8}''$ $.4572$
12. Pitot to thermocouple (parallel to probe) $3''$ $3''$ TO CENTER OF HOLE
13. Pitot to thermocouple (perpendicular to probe) NA

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

8-1-95

Inspected by:

George Blenbach

S-Type Pitot Tube Inspection Sheet

Probe or Pitot Tube No. 27-5

Pitot tube dimensions:

1. External tubing diameter (D) .312 IN.
2. Base to Side A opening plane (P_A) .4675 IN.
3. Base to Side B opening plane (P_B) .4515 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 410° $0^\circ 35'$
5. $\alpha_2 < 10^\circ$ 410° $0^\circ 35'$

6. $B_1 < 5^\circ$ 45° $0^\circ 0' 30''$
7. $B_2 < 5^\circ$ 45° $0^\circ 50'$

8. Z $< .125''$ $4125''$
9. W $< .0625''$ $40625''$ A $.013''$ B $.001''$

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle $\frac{3}{4}''$.750''
11. Pitot to probe sheath $\frac{3}{8}''$ 4.380
12. Pitot to thermocouple (parallel to probe) $3''$ 2.956''
13. Pitot to thermocouple (perpendicular to probe) NA

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

8-1-95

Inspected by:

Harry Blankenship

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 29-6

Pitot tube dimensions:

1. External tubing diameter (D_e) _____ 1.316 IN.
2. Base to Side A opening plane (P_A) _____ 1.460 IN.
3. Base to Side B opening plane (P_B) _____ 1.460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z $< .125"$.02
9. W $< .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle _____ 1.750 IN.
11. Pitot to probe sheath _____ 3.0 IN.
12. Pitot to thermocouple (parallel to probe) _____ 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) _____ 1.760 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

[Signature]

S-Type Pitot Tube Inspection Sheet

Pitot Tube No. 31-6

Pitot tube dimensions:

1. External tubing diameter (D_v) 1.316 IN.
2. Base to Side A opening plane (P_A) 1.460 IN.
3. Base to Side B opening plane (P_B) 1.460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0

6. $B_1 < 5^\circ$ 0
7. $B_2 < 5^\circ$ 0

8. Z $< .125"$.01
9. W $< .0625"$.01

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle 1.750 IN.
11. Pitot to probe sheath 3.0 IN.
12. Pitot to thermocouple (parallel to probe) 3.0 IN.
13. Pitot to thermocouple (perpendicular to probe) 1.750 IN.

- Meets all EPA design criteria thus $C_p = 0.84$
 Does not meet EPA design criteria - thus calibrate in wind tunnel.
 $C_p =$ _____

Date of Inspection:

4-7-94

Inspected by:

E. [Signature]

Nozzle Calibration Data Sheet

Date of Calibration: 8-27-96
Technician: Scott Fjelsta
Nozzle Number: 9-4

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.251
2	0.249
3	0.252
Average	0.251

Nozzle Calibration Data Sheet

Date of Calibration: 8-28-96
Technician: Scott Fjelsta
Nozzle Number: 1-7

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.230
2	0.231
3	0.230
Average	0.230

Nozzle Calibration Data Sheet

Date of Calibration: 8-27-96
Technician: Mark Kaehler
Nozzle Number: 1-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.184
2	0.186
3	0.187
Average	0.186

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 8-28-96
Technician: Mark Kaehler
Nozzle Number: 2-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.180
2	0.181
3	0.179
Average	0.180

Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 8-27-96
Technician: Jamie Bainville
Nozzle Number: 9-3

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.190
2	0.187
3	0.188
Average	0.188


Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 8-28-96
Technician: Bob Aschenbach
Nozzle Number: 1-6

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.298
2	0.298
3	0.297
Average	0.298



Interpoll Laboratories
(612) 786-6020

Nozzle Calibration Data Sheet

Date of Calibration: 8-28-96
Technician: Ed Juers
Nozzle Number: 1-5

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	0.189
2	0.190
3	0.191
Average	0.190

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 7-8-96
 Technician E. SURS
 Mercury Column Barometer No. 1
 Aneroid Barometer No. 10724004

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} - P _{bm})
28.93	74	.119	28.81	28.91	.1

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____

offset - .119
slope 0.251

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 8-12-96
Technician SF
Mercury Column Barometer No. Room 125
Aneroid Barometer No. 20901010

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference ($P_{ba} - P_{bm}$)
29.26	79	.135	29.13	29.21	0.08

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____

No

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 10-17-95
Technician R.R.
Mercury Column Barometer No. NOVA-1
Aneroid Barometer No. 560209

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} - P _{am})
28.91	82	.14	28.77	28.76	.01

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. _____

BAROMETER HAS BEEN REPAIRED

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

INTERPOLL LABORATORIES, INC.

(612) 786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 7-11-96
 Technician Mark Hashler
 Mercury Column Barometer No. LAB 1
 Aneroid Barometer No. 21029004

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} - P _{bm})
29.13	30	.137	29.043	29.05	.007

Has this barometer shown any consistent problems with calibration? Yes No If yes, explain. _____

Has problem been alleviated? Yes/No. How? _____

Note: Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20 - 30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

