

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Koppers Industries, Inc.
Pittsburgh, Pennsylvania

**Susquehanna Wood Treating
Facilities
Vacuum Pump Emissions
Study**

April 1994



CHESTER
ENVIRONMENTAL

[Faded header text]

KOPPERS INDUSTRIES, INC.
Pittsburgh, Pennsylvania

**Susquehanna Wood Treating Facilities
Vacuum Pump Emissions Study**

April 1994

Prepared by: Jordan Dern

Project No.: 4705-15



CHESTER
ENVIRONMENTAL

P.O. Box 15851 · Pittsburgh, PA 15244
412-269-5700 · Fax 412-269-5749

[Faded footer text]

**SUSQUEHANNA WOOD TREATING FACILITIES
VACUUM PUMP EMISSIONS STUDY
TABLE OF CONTENTS**

	Page No.
SECTION 1.0	
Introduction	1-1
SECTION 2.0	
Discussions	2-1
2.1 Process Description	2-1
2.2 Test Methodologies	2-3
2.3 Sampling Procedure	2-3
2.3.1 Volumetric Flow Rate and Moisture Content	2-3
2.3.2 PAHs	2-5
2.3.3 Quality Control	2-6
SECTION 3.0	
Results and Conclusions	3-1
3.1 Results	3-1
3.1.1 Testing Results	3-1
3.1.2 Data Quality Assessment.....	3-3
3.2 Conclusions	3-4
3.2.1 Wood Conditioning	3-4
3.2.2 Air Release.....	3-5
3.2.3 Final Vacuum.....	3-5
3.2.4 Summary of Conclusion	3-5
Figure 1 Creosote Treatment Process Flow Diagram.....	2-2
Figure 2 Summary of Test Program.....	2-4
Figure 3 Flow During Air Release Vacuum Pump Emissions.....	3-2

**SUSQUEHANNA WOOD TREATING FACILITIES
VACUUM PUMP EMISSIONS STUDY
TABLE OF CONTENTS (CONT.)**

Page No.

Table 1	Vacuum Pump Emissions.....	3-6
Table 2	Vacuum Pump Emissions.....	3-7
Table 3	Air Release Vacuum Pump Emission	3-8
Table 4	Final Vacuum Vacuum Pump Emissions	3-9
Table 5	Summary of Emission Factors for Vacuum Pump Emissions	3-10

SUSQUEHANNA WOOD TREATING FACILITIES

VACUUM PUMP EMISSIONS STUDY

SECTION 1.0

INTRODUCTION

During period of May 24 through May 25, 1990, a testing program was conducted at the Koppers Industries, Inc. Susquehanna wood treating plant. An EPA Modified Method 5 program for the determination of emissions from stationary sources, utilizing an XAD adsorbent canister connected into sample train, was conducted by Keystone Environmental Resources, Inc., at that time a subsidiary of Chester Environmental. The testing program involved the sampling of gases exhausted from a treating cylinder during each step of the wood treating cycle. The compounds of interest, Polynuclear Aromatic Hydrocarbons (PAHs), were collected in the sample train, which included an XAD adsorbent. EPA Method 4 was used for moisture determinations and Methods 1 & 2 were used to determine stack flow characteristics. The results of the testing are listed in Section 3.0 and Tables 1 through 4 of this report, with a summary in Table 5.

Testing was performed by the Air Quality Division of Keystone Environmental Resources, Inc. The test crew was comprised of Mark Grunebach and Pat Stockton. The purpose of the test program was to document the emissions of creosote components from this process source.

This document is a revision of a report which was originally published in August 1990 to support the development of emissions values to be used in calculating releases under SARA Title III. This report has been requested to address a broader spectrum of PAH compounds than was originally reported, as well as to correct some errors in calculations which were noted in the original report.

The objective of this revised document is to develop the collected data into a series of emission factors applicable to treating of wood with creosote. The results were compared to the recently proposed emission factors for wood preserving in AP-42 - Compilation of Air Pollution Emissions Factors, Section 10.8 - Wood Preserving.

SUSQUEHANNA WOOD TREATING FACILITIES

VACUUM PUMP EMISSIONS STUDY

SECTION 2.0

DISCUSSION

2.1 PROCESS DESCRIPTION

The following is a description of the wood treatment steps and pollution control measures at the Koppers Industries, Inc., Susquehanna, Pennsylvania plant, as shown in the attached Flow Diagram (Figure 1).

The wood treatment facility typically operates 24 hours per day, 5 days per week, 215 days per year. The facility treats green ties, flanges, and lumber and dry ties, flanges and bridges and lumber. A total of 1,668,770 cubic feet of wood was treated in 1991. Steam for heating in the treating process is supplied by a wood waste boiler. The fuel used for the boiler is creosote-treated cross ties. The plant has three creosote treating cylinders (8 ft. dia. x 140 ft. long).

60/40 creosote-coal tar solution is delivered to the plant by heated rail car or truck tankers and stored in three storage/work tanks. Two tanks are 48,100 gallon capacity and one tank is 63,200 gallon capacity.

The Boulton process, the first step in wood treating, is used to "condition", i.e., remove moisture from green wood prior to treatment with creosote. In this process, the cylinder is filled with creosote and a 25-inch Hg vacuum is pulled on the cylinder. Vapors from the cylinder are condensed in a shell and tube condenser, and the condensate is transferred to the wastewater treatment system. Boultonizing lasts from 8 to 18 hours depending on the amount of moisture in the wood and the species of the wood to be treated. After Boultonizing, the creosote is transferred from the cylinder and returned to the work tank.

After conditioning by Boultonizing, the wood is treated with creosote using the Rueping process. The cylinder is initially pressurized with air to 50-55 psi for 1/2 hour. Creosote is then added to the cylinder to displace the air and heated. The cylinder is then further pressurized to 145 psi, and the pressure is maintained for 1-1/2 to 4 hours, until the desired product retention is reached. After pressurization, the creosote is transferred from the cylinder and returned to the work tank.

Following the treating step, a final vacuum step is performed, during which a 22-inch Hg final vacuum is pulled on the cylinder for a period of 2 hours. The final vacuum is maintained by a vacuum pump. Vapors from the cylinder are condensed in the condenser and the condensate is processed through the wastewater treatment system.




FIGURE 1
 CREOSOTE TREATMENT
 PROCESS FLOW DIAGRAM
 KOPPERS INDUSTRIES, INC.
 SUSQUEHANNA PLANT
 MONTGOMERY, PA

11/19/92 C69387



During the testing program on May 24 and 25, 1990, wood treating was accomplished in two cylinders. The specific process schedule and the associated testing sequence are shown in Figure 2.

2.2 TEST METHODOLOGIES

The execution of the test program required the use of several promulgated procedures. This section outlines the sampling and analytical procedures utilized. Methodologies are summarized in the following table.

Parameter	Sampling and Analytical Procedure
Location of Traverse Points	EPA Method 1
Gas Velocity & Volumetric Flow Rate	EPA Method 2
Gas Moisture Content	EPA Method 4
Polynuclear Aromatic Hydrocarbons	EPA Method 5 - Modified

Determination of the volumetric flow rate was performed in accordance with EPA Reference Methods during each test run. Due to the small size of the pipeline, the volumetric flow rate measurement was performed through a single sampling point.

The velocity head pressures were measured with a Type S Pitot tube. Temperature measurements were performed concurrently with the velocity measurements using a type K thermocouple.

Since the "gas" which is removed from the wood in the Boultonizing process is air, the molecular weight was assumed to be 28.8 (20% oxygen and 80% nitrogen).

2.3 SAMPLING PROCEDURE

2.3.1 Volumetric Flow Rate and Moisture Content

Gas velocities, volumetric flow rates, and moisture content of the exhaust gas were determined in accordance with EPA Stationary Source Sampling Methods 1, 2, and 4 respectively. The volumetric flow rate of each source was calculated using a stack velocity determination, dry gas molecular weight, and moisture content in accordance

FIGURE 2			
SUMMARY OF TEST PROGRAM			
KOPPERS INDUSTRIES, INC.			
SUSQUEHANNA, PA			
	CYLINDER #1	CYLINDER #2	
	BATCH K-289	BATCH K-290	SAMPLES
TIME	2380 CF	3470 CF	COLLECTED
09:00 AM	BOULTON START		
09:30 AM			
10:00 AM			
10:30 AM			
11:00 AM			
11:30 AM			
12:00 PM			
12:30 PM			
01:00 PM		BOULTON START	
01:30 PM			
02:00 PM			
02:30 PM			✓ IFC-1, OFC-1
03:00 PM			IFC-1, OFC-1
03:30 PM	BOULTON END		IFC-1, OFC-1
04:00 PM	INITIAL AIR, PRESSURE @50 psi		
04:30 PM	AIR RELEASE		
05:00 PM	CREOSOTE IN		
05:30 PM	PRESSURE @ 200 psi		✓ IFC-2, OFC-2
06:00 PM			IFC-2, OFC-2
06:30 PM		BOULTON END	IFC-2, OFC-2
07:00 PM	INITIAL AIR, PRESSURE @50 psi		
07:30 PM		AIR RELEASE	✓ IFC-3, OFC-3
08:00 PM	CREOSOTE BACK	CREOSOTE IN	
08:30 PM	FINAL VACUUM	PRESSURE @ 200 psi	
09:00 PM			IFC-4, OFC-4
09:30 PM			IFC-4, OFC-4
10:00 PM			IFC-4, OFC-4
10:30 PM	RECOVER DRIPPINGS		
11:00 PM			
11:30 PM			
12:00 AM			
12:30 AM		CREOSOTE BACK	
01:00 AM		FINAL VACUUM	
01:30 AM			
02:00 AM			
02:30 AM			
03:00 AM		RECOVER DRIPPINGS	
<u>SUMMARY OF SAMPLES COLLECTED</u>			
IFC-1, OFC-1 - BOTH CYLINDER #1 AND CYLINDER #2 BOULTONIZING			
IFC-2, OFC-2 - BOULTONIZING IN CYLINDER #2 ONLY			
IFC-3, OFC-3 - AIR PRESSURE RELEASE IN CYLINDER #2 ONLY			
IFC-4, OFC-4 - FINAL VACUUM IN CYLINDER #1 ONLY			

one 1-hr sample on each cylinder

with EPA Method 2 and reported in terms of actual cubic feet per minute (ACFM), standard cubic feet per minute (SCFM), and dry standard cubic feet per minute (DSCFM). Moisture determination was accomplished by gravimetric analysis of the moisture sampling train. The impingers were weighed prior to and following each test to the nearest 0.1 gram. Calculation of the moisture content, in percent by volume, was performed in accordance with EPA Method 4.

2.3.2 PAHs

EPA Modified Method 5 involved the determination of PAH compounds using an XAD collection medium in the Method 5 sample train. A sampling probe was inserted into the sampling port of the stack and a known volume of gas passed through the XAD canister where the PAH compounds were collected. The XAD was then sealed to prevent any contamination or PAH loss. Water portions of the sample train were extracted and combined with the XAD extract. The resultant sample was analyzed in accordance with EPA Method 610. The following is a list of PAHs for which analyses were performed.

- Carbazole
- Naphthalene
- Acenaphthalene
- Acenaphthene
- Fluorene
- Phenanthrene
- Anthracene
- Fluoranthene
- Pyrene
- Benzo(a)Anthracene
- Chrysene
- Benzo(b)Fluoranthene
- Benzo(k)Fluoranthene
- Benzo(a)Pyrene
- Dibenzo(a,h)Anthracene
- Benzo(g,h,i)Perylene
- Indeno(1,2,3-cd)Pyrene
- Dibenzofuran

The analytical results are contained in Appendix B.

2.3.3 Quality Control

All Pitot tubes, thermocouples, differential pressure gauges and scales used in the test program are calibrated on a routine basis and inspected prior to their use. Pitot tubes, connecting tubing and differential pressure gauges were leak checked on-site before and after each velocity measurement. Upon completion of the program, a calibration check of the equipment actually used in the testing was performed.

**SUSQUEHANNA WOOD TREATING FACILITIES
VACUUM PUMP EMISSIONS STUDY
SECTION 3.0
RESULTS AND CONCLUSIONS**

The test program presented above addressed emissions from each step of the wood treating cycle during which emissions from the vacuum system can occur, including the wood conditioning step at the beginning of the treating cycle; the air release step following pressurization; and the final vacuum step prior to removing the treated wood from the treating cylinder. Among the purposes of the test program in 1990 was that of determining the control efficiency of the condenser downstream of the vacuum pumps. Based upon a review of the test results, that specific objective was not accomplished. Among the reasons for that conclusion were the following:

- 1) Some concentrations at the exit of the condenser were higher than inlet concentrations;
- 2) flow measurements were inconsistent, which may have been caused by the use of different measurement methods for flow rate on the inlet (Pitot tube) and outlet (hot wire anemometer); and
- 3) emissions from the condenser showed wide variations compared to emissions from the vacuum pump, which were fairly consistent.

On the basis of these results, no further evaluation of the emissions out of the vacuum pump condenser was performed. However, the results that apply to the emissions from the vacuum pump during the wood conditioning step, the air release step and the final vacuum step are valid.

3.1 RESULTS

3.1.1 Testing Results


Appendix A consists of the Stack Sampling Data Sheets which were completed during the testing on May 24 & 25, 1990 in accordance with the procedures outlined in Section 2. The data were reduced using appropriate equations in EPA Method 2 to determine the average stack gas velocity and average gas flow rate during the wood conditioning step and the final vacuum step. Sample calculations are shown in Appendix D. In the case of the air release step, the volumetric discharge over the entire air release step was determined by calculations (See Figure 3).

Appendix B contains the results of the PAH analysis of the samples collected in the Modified Method 5 sampling train. The analyses were performed by High

**FIGURE 3
FLOW DURING AIR RELEASE
VACUUM PUMP EMISSIONS**

**KOPPERS INDUSTRIES, INC.
PAH EMISSIONS FROM WOOD TREATING
SUSQUEHANNA PLANT**

ELAPSED TIME min	FLOW TO CONDENSER DSCFM	MEASURED OR INTERPOLATED	FLOW TO CONDENSER DSCF
0	0		98
1	195	measured	212
2	228	interpolated	245
3	261	interpolated	278
4	294	interpolated	311
5	327	measured	373
6	418	interpolated	464
7	510	interpolated	556
8	601	interpolated	647
9	693	interpolated	738
10	784	measured	795
11	806	interpolated	817
12	828	interpolated	839
13	850	interpolated	861
14	872	interpolated	883
15	894	measured	820
16	745	interpolated	671
17	596	interpolated	522
18	447	interpolated	373
19	298	interpolated	224
20	149	measured	75
21	0	measured	0
TOTAL FLOW DURING AIR RELEASE in DSCF			10796



Performance Liquid Chromatography (HPLC). The results were reported as mg of PAH compound/total sample. That information, when divided by the sample size (see "Meter Reading" column of Stack Sampling Data Sheet) to provide the sample concentration.

Appendix C contains the Koppers' data sheets for the wood treating batches during the period of testing. By comparing the data in Appendix C with the "Time" column of Stack Sampling Data Sheet, the specific operations occurring during the sampling program can be determined. Furthermore, by combining the hours of treatment and amount of wood treated in Appendix C with the sample concentration and air flow, an emission factor can be calculated.

3.1.2 Data Quality Assessment

An assessment of the quality of the data was made based on the criteria contained in Section 3. - GENERAL DATA REVIEW AND ANALYSIS - of *EMISSION FACTOR DOCUMENTATION FOR AP-42 SECTION 10.8*. Each of the criteria used to screen data were evaluated.

Literature Search and Screening

1. Emission testing must be from a primary source - All data developed during this study was original.
2. Study must contain results based upon more than one test run - A total of four runs were performed. While these runs may have been for different steps in the wood treating cycle, the consistency of procedures and results indicate the validity of the test conclusions.
3. The report must contain data to evaluate test procedures and operating conditions - Original data on both the testing and operating procedures are included to document the conclusions.

Emission Data Quality Rating System

Based upon the five criteria for data exclusion presented, none of the data would be excluded. (Note that two of the criteria apply to control devices which are not applicable because this study addressed uncontrolled emissions.

The data produced by this study have a data rating of "A" because multiple tests using accepted methodologies were performed and, because of the following evaluation:

1. Source operation - well documented as being within typical parameters

2. Sampling procedures - generally accepted methodologies were utilized
3. Sampling and process data - variations within the data set (consistent with the natural variation of creosote) are reasonable
4. Laboratory analysis and calculations - original chromatograms are available upon request.

Emission Factor Quality Rating System

The quality of the emission factors developed from this study were rated as D--Below Average. Although the data itself is A-rated, only one facility was tested, even though this facility is considered to be typical of the fourteen facilities operated by Koppers Industries, Inc.

(It should also be noted that the ratings in the Emission Factor Documentation show a data rating of "C" and an Emission Factor rating of "E--Poor" for the emission factors which have been proposed.

3.2 CONCLUSIONS

3.2.1 Wood Conditioning

Tables 1 & 2 summarize the results of the emission testing during the wood conditioning step. Table 1, "Boultonizing on Two Cylinders", shows an emission factor for all creosote components of 2.58×10^{-4} lb creosote / cubic foot of wood treated. Table 2, "Boultonizing on One Cylinder", shows an emission factor of 3.2×10^{-5} lb creosote / cubic foot of wood treated. Individual creosote components are shown on the respective tables.

Among the possible reasons for the difference in the results from the two tests are the following:

- Each test was conducted at a different elapsed time in the wood conditioning step;
- Condensation of PAHs on the uninsulated pipeline surfaces may have been greater while Boultonizing on one cylinder than on two cylinders;
- Subtle differences in the composition of the creosote, the characteristics of the wood, or weather conditions may have contributed to the difference in emission factors.

In any event, in light of the small amount of emissions from the wood conditioning process, these different values may not be significantly different.

In any event, in light of the small amount of emissions from the wood conditioning process, these different values may not be significantly different.

3.2.2 Air Release

Table 3 summarizes the results of the emission testing during the air release step. It shows an emission factor for all creosote components of 7.60×10^{-5} lb creosote / cubic foot of wood treated.

3.2.3 Final Vacuum

Table 4 summarizes the results of the emission testing during the final vacuum step. It shows an emission factor for all creosote components of 4.66×10^{-6} lb creosote / cubic foot of wood treated.

3.2.4 Summary of Conclusions

It is Chester's recommendation that the values found in Table 5 be used for emission factors for the wood conditioning step, the air release step and the final vacuum step in the wood treating process.

TABLE 1				
BOULTONIZING IN TWO CYLINDERS				
VACUUM PUMP EMISSIONS				
KOPPERS INDUSTRIES, INC.				
PAH EMISSIONS FROM WOOD TREATING				
SUSQUEHANNA PLANT				
SAMPLE SIZE in cu ft	DSCF	17.8		
AIR FLOW in DSCFM		227		
WOOD TREATED in cu ft		5852		
HOURS OF OPERATION in hrs		17.9		
SAMPLE NO:		SUS-FC1-I		
PAH	ANALYTICAL RESULTS	SAMPLE CONCEN.	PROCESS MASS EMISSION	CALCULATED EMISSION FACTOR
		(1)	(2)	(3)
	mg/TS	-lb/cf	lb/hr	lb/cf
	mg/total sample	lb/ DSCF		lb/ft ³ of wood treated
CARBAZOLE				
NAPHTHALENE	24.7	3.06E-06	4.16E-02	1.27E-04
ACENAPHTHYLENE	9.22	1.14E-06	1.55E-02	4.75E-05
ACENAPHTHENE	2.93	3.63E-07	4.94E-03	1.51E-05
FLUORENE	0.827	1.02E-07	1.39E-03	4.26E-06
PHENANTHRENE	0.217	2.69E-08	3.66E-04	1.12E-06
ANTHRACENE	0.036	4.45E-09	6.07E-05	1.86E-07
FLUORANTHENE				
PYRENE				
BENZO(a)ANTHRACENE				
CHRYSENE	0.0126	1.56E-09	2.12E-05	6.50E-08
BENZO(b)FLUORANTHENE				
BENZO(k)FLUORANTHENE				
BENZO(a)PYRENE				
DIBENZO(a,h)ANTHRACENE				
BENZO(g,h,i)PERYLENE				
INDENO(1,2,3-cd)PYRENE				
DIBENZOFURAN	12.1	1.50E-06	2.04E-02	6.24E-05
	TOTAL	6.19E-06	8.43E-02	2.58E-04
(1) - Sample concentration = Analytical Results / Sample Size				
(2) - Process Mass Emission = Sample Concentration * Air Flow				
(3) Calculated Emission Factor = Process Mass Emissions / Wood Treated				

TABLE 2				
BOULTONIZING IN ONE CYLINDER				
VACUUM PUMP EMISSIONS				
KOPPERS INDUSTRIES, INC.				
PAH EMISSIONS FROM WOOD TREATING				
SUSQUEHANNA PLANT				
SAMPLE SIZE in cu ft	37.76			
AIR FLOW in DSCFM	228.9			
WOOD TREATED in cu ft	3412			
HOURS OF OPERATION in hrs	17.9			
SAMPLE NO:	SUS-FC2-I			
	ANALYTICAL	SAMPLE	PROCESS	CALCULATED
PAH	RESULTS	CONCEN.	MASS	EMISSION
			EMISSION	FACTOR
		(1)	(2)	(3)
	mg/TS	lb/cf	lb/hr	lb/cf
CARBAZOLE	0.223	1.30E-08	1.79E-04	9.37E-07
NAPHTHALENE	5.07	2.96E-07	4.06E-03	2.13E-05
ACENAPHTHALENE				
ACENAPHTHENE				
FLUORENE	0.807	4.71E-08	6.47E-04	3.39E-06
PHENANTHRENE	0.507	2.96E-08	4.06E-04	2.13E-06
ANTHRACENE	0.007	4.08E-10	5.61E-06	2.94E-08
FLUORANTHENE				
PYRENE				
BENZO(a)ANTHRACENE				
CHRYSENE	0.0126	7.35E-10	1.01E-05	5.30E-08
BENZO(b)FLUORANTHENE				
BENZO(k)FLUORANTHENE				
BENZO(a)PYRENE				
DIBENZO(a,h)ANTHRACENE				
BENZO(g,h,i)PERYLENE				
INDENO(1,2,3-cd)PYRENE				
DIBENZOFURAN	0.984	5.74E-08	7.88E-04	4.14E-06
	TOTAL	4.44E-07	6.10E-03	3.20E-05
(1) - Sample concentration = Analytical Results / Sample Size				
(2) - Process Mass Emission = Sample Concentration * Air Flow				
(3) Calculated Emission Factor = Process Mass Emissions / Wood Treated				

EMISSION RATES AND FACTORS ARE
 INCONSISTENT. THEY ARE BASED ON
 A GAS FLOW RATE OF 10796 DSCFM.
 ACTUALLY 10796 IS THE TBM VOLUME
 OF GAS FLOW OVER THE 22-MIN AIR
 RELEASE CYCLE.

TABLE 3				
AIR RELEASE				
VACUUM PUMP EMISSIONS				
KOPPERS INDUSTRIES, INC.				
PAH EMISSIONS FROM WOOD TREATING				
SUSQUEHANNA PLANT				
SAMPLE SIZE in cu-ft ^{DSCF}	11.54			
AIR FLOW in DSCF	10796			
WOOD TREATED in cu ft	3472			
SAMPLE NO:	SUS-FV1-I			
PAH	ANALYTICAL RESULTS	SAMPLE CONCEN.	PROCESS MASS EMISSION	CALCULATED EMISSION FACTOR
		(1)	(2)	(3)
	mg/TS	lb/cf	lb/hr	lb/cf
CARBAZOLE				
NAPHTHALENE	1.04	1.99E-07	1.29E-01	3.70E-05
ACENAPHTHALENE				
ACENAPHTHENE	0.213	4.07E-08	2.63E-02	7.58E-06
FLUORENE	0.0083	1.58E-09	1.03E-03	2.96E-07
PHENANTHRENE	0.0799	1.53E-08	9.88E-03	2.85E-06
ANTHRACENE	0.0183	3.49E-09	2.26E-03	6.52E-07
FLUORANTHENE	0.0342	6.53E-09	4.23E-03	1.22E-06
PYRENE	0.0282	5.38E-09	3.49E-03	1.00E-06
BENZO(a)ANTHRACENE	0.0065	1.24E-09	8.04E-04	2.31E-07
CHRYSENE	0.0069	1.32E-09	8.53E-04	2.46E-07
BENZO(b)FLUORANTHENE	0.0063	1.20E-09	7.79E-04	2.24E-07
BENZO(k)FLUORANTHENE	0.0024	4.58E-10	2.97E-04	8.55E-08
BENZO(a)PYRENE	0.0032	6.11E-10	3.96E-04	1.14E-07
DIBENZO(a,h)ANTHRACENE				
BENZO(g,h,i)PERYLENE				
INDENO(1,2,3-cd)PYRENE				
DIBENZOFURAN	0.686	1.31E-07	8.48E-02	2.44E-05
	TOTAL	4.07E-07	2.64E-01	7.60E-05
(1) - Sample concentration = Analytical Results / Sample Size				
(2) - Process Mass Emission = Sample Concentration * Air Flow ⁶⁰ $lb/cf * dscfm = lb/hr$				
(3) Calculated Emission Factor = Process Mass Emissions / Wood Treated $lb/hr / cf = lb/cf$				

TABLE 4				
FINAL VACUUM				
VACUUM PUMP EMISSIONS				
KOPPERS INDUSTRIES, INC.				
PAH EMISSIONS FROM WOOD TREATING				
SUSQUEHANNA PLANT				
SAMPLE SIZE in cu ft	28.63			
AIR FLOW in DSCFM	162			
WOOD TREATED in cu ft	2380			
HOURS OF OPERATION in hr	2			
SAMPLE NO:	SUS-FV1-I			
PAH	ANALYTICAL RESULTS	SAMPLE CONCEN.	PROCESS MASS EMISSION	CALCULATED EMISSION FACTOR
		(1)	(2)	(3)
	mg/TS	lb/cf	lb/hr	lb/cf
CARBAZOLE				
NAPHTHALENE	4.72	3.63E-07	3.53E-03	2.97E-06
ACENAPHTHALENE				
ACENAPHTHENE	0.7	5.39E-08	5.23E-04	4.40E-07
FLUORENE	0.0359	2.76E-09	2.68E-05	2.26E-08
PHENANTHRENE	0.333	2.56E-08	2.49E-04	2.09E-07
ANTHRACENE	0.0062	4.77E-10	4.64E-06	3.90E-09
FLUORANTHENE				
PYRENE				
BENZO(a)ANTHRACENE				
CHRYSENE	0.0055	4.23E-10	4.11E-06	3.46E-09
BENZO(b)FLUORANTHENE				
BENZO(k)FLUORANTHENE				
BENZO(a)PYRENE				
DIBENZO(a,h)ANTHRACENE				
BENZO(g,h,i)PERYLENE				
INDENO(1,2,3-cd)PYRENE				
DIBENZOFURAN	1.62	1.25E-07	1.21E-03	1.02E-06
	TOTAL	5.71E-07	5.55E-03	4.66E-06
(1) - Sample concentration = Analytical Results / Sample Size				
(2) - Process Mass Emission = Sample Concentration * Air Flow				
(3) Calculated Emission Factor = Process Mass Emissions / Wood Treated				

TABLE 5			
SUMMARY OF EMISSION FACTORS			
VACUUM PUMP EMISSIONS			
KOPPERS INDUSTRIES, INC.			
PAH EMISSIONS FROM WOOD TREATING			
SUSQUEHANNA PLANT			
PAH	WOOD CONDITIONING EMISSION FACTOR	AIR RELEASE EMISSION FACTOR	FINAL VACUUM EMISSION FACTOR
	lb/cf	lb/cf	lb/cf
CARBAZOLE	4.69E-07		
NAPHTHALENE	7.43E-05	3.70E-05	2.97E-06
ACENAPHTHALENE	2.38E-05		
ACENAPHTHENE	7.55E-06	7.58E-06	4.40E-07
FLUORENE	3.83E-06	2.96E-07	2.26E-08
PHENANTHRENE	1.62E-06	2.85E-06	2.09E-07
ANTHRACENE	1.08E-07	6.52E-07	3.90E-09
FLUORANTHENE		1.22E-06	
PYRENE		1.00E-06	
BENZO(a)ANTHRACENE		2.31E-07	
CHRYSENE	5.90E-08	2.46E-07	3.46E-09
BENZO(b)FLUORANTHENE		2.24E-07	
BENZO(k)FLUORANTHENE		8.55E-08	
BENZO(a)PYRENE		1.14E-07	
DIBENZO(a,h)ANTHRACENE			
BENZO(g,h,i)PERYLENE			
INDENO(1,2,3-cd)PYRENE			
DIBENZOFURAN	3.33E-05	2.44E-05	1.02E-06
	1.45E-04	7.60E-05	4.66E-06

APPENDIX A
RAW FIELD DATA SHEETS



STACK SAMPLING DATA SHEET

PLANT: Susquehanna - Koppers Intermediate DATE: 5/24/90 HOT BOX NO.: Bucket
 LOCATION: Inlet to Final Condensate TEST NO.: SUS-1055 METER CORRECTION: -9778 COLD BOX NO.: Bucket
 ACTIVITY NO.: Belt Driv. by Process NOZZLE: 3/8 SS Tubing PITOT CORRECTION: -.84 PROBE NO.: Teflon + Stainless St.
 CONTROL BOX OPERATOR: MG STATIC PRESSURE PS: 0.6 CONTROL BOX NO.: 3 FILTER NO.: —
 PROBE HANDLER: Non-existent PORT DIRECTION: Non-existent NOMOGRAPH SET POINT: 8.0" STACK DIA.: 8.0"
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.60 LENGTHS OF UMBILICAL: X x 25' x 50'

Point	Time	Meter Reading (dry) CF	Velocity I/D in. H ₂ O	Orifice a H in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Imp. Temp. XRD EX-T °F PF	Hot Box Bucket °F Down	Comments
				Req.	Act.	In	Out						
6" IN	1440	748.913	.05	.60	.60	83	75	5.0	106	noilent	42	468	60 min / point
			.05	.60	.60	91	77	5.0	105		41		
			.05	.60	.60	92	79	5.0	105		42		
			.05	.60	.60	95	79	5.0	105		40		
			.045	.60	.60	95	80	5.0	105		43		
			.045	.60	.60	98	81	5.0	104		44		
			.045	.60	.60	99	83	5.0	104		42		
			.05	.60	.60	99	83	5.0	105		44		
			.05	.60	.60	98	83	5.0	105		42		10.17% H ₂ O
			.05	.60	.60	98	82	5.0	106		41		
	1540		.045	.60	.60	98	82	5.0	105		41		
	1540	776.713	.045	.60	.60	98	82	5.0	105		41		

LEAK CHECK

in. Hg.	Rate
6.0	4.02 CFM
7.0	4.02 CFM

ORSAT

CO ₂	1	2
O ₂		
CO		
N		

PITOT LEAK CHECK

POS.	NEG.
0.15 sec	0.15 sec

Impinger No. Final Initial Difference

1	0.04	479.70	438.8	40.9
2	room	580.1	566.3	13.8
3	cond	974.3	966.5	7.8
4	0.04	378.6	378.4	.2

XRD 1148.9-114
51.601
685.7-67





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter--											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.8	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.8	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	39.8
13							94.3	87.5	81.2	75.0	68.5	60.2
14								96.2	91.5	85.4	79.6	67.7
15									95.1	89.1	83.5	72.8
16									98.4	92.5	87.1	77.0
17										95.6	90.3	80.6
18										98.6	93.3	83.9
19											96.1	86.8
20											98.7	89.5
21												96.5
22												94.5
23												96.8
24												98.9

Number of traverse points	Metre layout
8	35
12	43
16	51
20	59
24	67
28	75
32	83
36	91
40	99
44	107
48	115

STACK SAMPLING DATA SHEET

PLANT: Susquehanna-Koppers Inert Date: 5/24/90 ΔH@: 1.277 12/27/89
 LOCATION: Outlet to FISA (Cable) Process METER CORRECTION: 1.6350
 ACTIVITY NO.: Boilering Process NOZZLE: _____
 CONTROL BOX OPERATOR: gjt STATIC PRESSURE PS.: 0.5 in. H₂O CONTROL BOX NO.: 1
 PROBE HANDLER: _____ PORT DIRECTION: Horizontal NOMOGRAPH SET POINT: _____
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.60 LENGTHS OF UMBILICAL: _____ x 25' x 50' High Pressure Line

HOT BOX NO.: 5
 COLD BOX NO.: 5
 PROBE NO.: Teflon Line 1/4"
 FILTER NO.: _____
 STACK DIA.: 4.0"

Point	Time	Meter Reading (dry) CF	Velocity FPM	Orifice ΔH in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Temp-Temp XAD Exit °FF	Hot Box °F	Comments
				Req.	Act.	In	Out						
	14:40	1040.655	275 FPM	0.6	0.6	76	74	5.0	78		43		
	14:45			0.6	0.6	81	75	5.0	78		43		
	14:50			0.6	0.6	84	77	5.0	78		43		
	14:55			0.6	0.6	85	78	5.5	79		45		
	15:00		250 FPM	0.6	0.6	86	79	5.5	78		39		
	15:05			0.6	0.6	88	80	5.5	78		40		
	15:10			0.6	0.6	89	81	5.5	78		40		
	15:15			0.6	0.6	90	82	5.5	78		41		
	15:20			0.6	0.6	90	83	5.5	78		40		
	15:25			0.6	0.6	90	83	5.5	78		38		
	15:30			0.6	0.6	91	84	6.0	78		38		
	15:35		260 FPM	0.6	0.6	91	84	6.0	78		39		

15:40 1066.648

LEAK CHECK

in. Hg.	Rate
5.0	4.07 CFM
7.0	4.07 CFM

ORSAT

CO ₂	1	2
O ₂		
CO		
N		

PITOT LEAK CHECK

POS.	NEG.

Impinger No. XAD COND.

1	1186.1	Final
2	446.3	Initial
3	516.1662.5	Difference
4		

6.38% H₂O





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
 [Percent of stack diameter from inside wall to traverse point]

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.6	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.8	26.9	22.0	18.6	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	36.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	39.8
13							94.3	87.5	81.2	75.0	66.5	60.2
14							96.2	91.5	85.4	79.6	73.8	67.7
15								95.1	89.1	83.5	78.2	72.6
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												96.9
24												98.9

Number of traverse points	Matrix layout
9	3x3
12	3x4
16	4x4
20	4x5
25	5x5
30	6x5
36	6x6
42	7x6
48	7x7



STACK SAMPLING DATA SHEET

PLANT Sasquehanna Koppers DATE: 5/24/90 HOT BOX NO: Buget 1
 LOCATION: INLET TO Final Condensate TEST NO: 545-IFC-2 COLD BOX NO: 1
 ACTIVITY NO: Boltan: zidy Process NOZZLE: 3/8" SS Tubing PROBE NO: Telling SS. Tubing
 CONTROL BOX OPERATOR: _____ STATIC PRESSURE Ps: +1.60 FILTER NO: None
 PROBE HANDLER: _____ PORT DIRECTION: (HORIZ) STACK DIA: 8.0
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.60 x 25' LENGTHS OF UMBILICAL x 50'

Point	Time	Meter Reading (dry) CF	Velocity HD in. H ₂ O	Orifice 411 in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Imp. Temp. XAD °C/F	Hot Box °F	Comments
				Reg.	Act.	In	Out						
6" IN	1720	776.951	.05	.60	.60	83	77	5.0	109	None	41	None	COM. NAME POINT
			.05	.60	.60	89	76	5.0	110		41		NOTE TRAVEL WAS THE
			.05	.60	.60	92	77	5.0	110		39		SAME VEL AT
			.05	.60	.60	93	77	5.0	110		40		ALL POINTS
			.05	.60	.60	94	78	5.0	110		41		
			.05	.60	.60	94	78	5.0	110		41		
			.055	.60	.60	94	79	5.0	111		42		
			.055	.60	.60	94	79	5.0	111		41		
			.05	.60	.60	95	79	5.0	111		42		12.73%
			.05	.60	.60	95	79	5.0	111		43		
	1820	804.708	.055	.60	.60	95	80	5.0	111		42		

LEAK CHECK

in. Hg.	Rate
before	6.0
after	6.5

PITOT LEAK CHECK

POS.	NEG.
15 sec	15 sec
0.1k	0.1k

ORSAT

CO ₂	2
O ₂	
CO	
N	

Impinger No. 100M H₂O

Final	Initial	Difference
1 100M H ₂ O 666.3	595.6	65.7
2 XAD 1151.7	1141.0	10.7
3 5.16 x 1 689.3	685.6	3.7
4		

% H₂O 12.67





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
 (Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	38.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	39.6
13							94.3	87.5	81.2	75.0	68.5	60.2
14							98.2	91.5	85.4	79.6	73.6	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												96.6
24												98.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Man's layout
8	
12	
16	
20	
24	



STACK SAMPLING DATA SHEET

PLANT Susquehanna-Koppers Inc DATE: 5/24/90 ΔH@: 1.777 12/27/89 HOT BOX NO.: 5
 LOCATION: Outlet to Final Compressor TEST NO.: SUS-OFC-2 METER CORRECTION: 1.0350 COLD BOX NO.: 5
 ACTIVITY NO.: Bottling process NOZZLE: _____ PITOT CORRECTION: _____ PROBE NO.: Teflon Line 1/4"
 CONTROL BOX OPERATOR: JK STATIC PRESSURE Ps: .05 CONTROL BOX NO.: 1 FILTER NO.: _____
 PROBE HANDLER: _____ PORT DIRECTION: Horizontal NOMOGRAPH SET POINT: _____ STACK DIA: 4.0"
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.60 LENGTHS OF UMBILICAL x 25' x 50' High Pressure Line

Point	Time	Meter Reading (dry) CF	Velocity $\frac{ft}{min}$	Orifice 4 H ₂ O in. H ₂ O	Meter Temp °F	Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Temp. XAD Exit °F	Hot Box °F	Comments
	1720	1066.776	250 FPM	0.6	74	5.0	79		47		
	1725			0.6	73	5.0	80		47		
	1730			0.6	82	5.0	80		45		
	1735			0.6	84	5.5	80		40		
	1740			0.6	86	5.5	81		40		
	1745			0.6	87	5.5	80		42		
	1750		290 FPM	0.6	87	5.5	79		41		
	1755			0.6	88	5.5	78		41		
	1800			0.6	89	5.5	79		41		
	1805			0.6	89	5.5	79		42		
	1810			0.6	89	5.5	78		43		
	1815		265 FPM	0.6	90	5.5	78		41		

1820 1094.130

ORSAT

CO ₂	1	2
O ₂		
CO		
N		

LEAK CHECK

in. Hg.	Rate
5.0	4.08 CFM
6.0	4.03 CFM

Impinger No. Final Initial Difference

1 DAY	461.3	447.2	14.1
2 Cell Cond.	1174.2	1160.2	14
351.6el	671.6	662.5	9.1
4			37.2 g

6.026^g
H₂O





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.6	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	36.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	36.6
13							94.3	87.5	81.2	75.0	66.5	60.2
14								96.2	91.5	85.4	79.6	67.7
15									95.1	89.1	83.5	72.8
16									98.4	92.5	87.1	77.0
17										95.6	90.3	80.6
18										98.6	93.3	83.9
19											98.1	86.8
20											98.7	84.0
21												98.5
22												98.9
23												98.9
24												98.8

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Matrix layout
9	3 3 3
12	3 3 3 3
16	4 4 4
20	4 4 4 4
25	5 5 5
30	5 5 5 5
36	6 6 6
42	6 6 6 6
48	7 7 7



Sus-IFC-3
SUS-ARI-3

STACK SAMPLING DATA SHEET

PLANT Susquahanna-Koppers Indust. DATE: 5/25/90 HOT BOX NO.: 1
 LOCATION: INLET TO FINAL COND TEST NO.: SUS-FFC-3 METER CORRECTION: 19778
 ACTIVITY NO.: AIR RELEASE NOZZLE: 3/8 SS TUBING PITOT CORRECTION: 184
 CONTROL BOX OPERATOR: MG STATIC PRESSURE Ps: .60 CONTROL BOX NO.: 3 FILTER NO.: ---
 PROBE HANDLER: --- PORT DIRECTION: HORZ NOMOGRAPH SET POINT: 8.0"
 CLEAN UP: --- BAROMETRIC PRESSURE: 29.75 LENGTHS OF UMBILICAL x 25' x 50'

Point	Time	Meter Reading (dry) CF	Velocity HD in. H ₂ O	Orifice & II in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Temp. Temp. XA-D °F	Hot Box °F	Comments
				Req.	Act.	In	Out						
6" IN	715	804.836	.03	.80	.80	58	52	5.0	54	NO HEAT	41		ONE POINT
			.08	.80	.80	65	52	5.0	65				
			.48	.80	.80	72	55	5.0	86				
			.62	.80	.80	74	56	5.0	96		40		AIR
	736	816.376	.01	.80	.80	75	56	5.0	96				STOPPED
		816.376											19 mins
													RAN 21 mins

LEAK CHECK

in. Hg.	Rate
before 6.0	4.6 CFM
after 6.5	4.0 CFM

ORSAT

	1	2
CO ₂		
O ₂	20.5	
CO		
N	79.5	

PITOT LEAK CHECK

POS.	NEG.
------	------

Impinger No. Final Initial Difference

1 100 ml. H ₂ O	598.4	595.4	3
2 XA-D	1140.2	1139.8	.4
3 51.621	690.8	689.3	1.5
4			

2.02°/h
H₂O





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
 (Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter--											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	60.4	40.7	36.8
13							94.3	87.5	81.2	75.0	66.5	60.2
14							96.2	91.5	85.4	79.8	73.8	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												96.8
24												98.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Matrix layout
9	
12	
16	
20	
25	
30	
40	
60	

STACK SAMPLING DATA SHEET

SUS-0FC-3
SUS-ARO-3

PLANT Susquehanna-Koppers DATE: 5/25/90 ΔH@: 1.777 12/27/89 HOT BOX NO.: 5
 LOCATION: Air Release Outlet TEST NO.: SUS-ARO-3 0FC-3 COLD BOX NO.: 5
 ACTIVITY NO.: _____ NOZZLE: SUS-ARO-3 PITOT CORRECTION: _____ PROBE NO.: Teflon Line 1/4"
 CONTROL BOX OPERATOR: fyb STATIC PRESSURE PS: _____ FILTER NO.: _____
 PROBE HANDLER: _____ PORT DIRECTION: Horizontal NOMOGRAPH SET POINT: _____ STACK DIA.: 4.0"
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.75 LENGTHS OF UMBILICAL x 25' X x 50' High Pressure Line _____

Point	Time	Meter Reading (dry) CF	Velocity #D-hr-H ₂ O FPM	Orifice ΔH in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Temp. XAD Exit % Δ°F	Hot Box °F	Comments
				Reg.	Act.	In	Out						
2" IN	7:15	94.212	210 FPM	0.8	0.8	57	53	6.0	53		44		
	7:20			0.8	0.8	60	54	6.0	54		43		
	7:25			0.8	0.8	62	55	6.0	71		43		
	7:30			0.8	0.8	65	58	6.0	70		42		
	7:35		410 FPM	0.8	0.8	67	59	6.0	69		41		
	7:40	1048.300		0.8	0.8	68	60	6.0	67		42		
	7:45												

LEAK CHECK

in. Hg.	Rate
5.0	4.02 FPM
7.0	4.02 FPM

ORSAT

	1	2
CO ₂		
O ₂		
CO		
N		

PITOT LEAK CHECK

POS.	NEG.

Impinger No. Final Initial Difference

1 100ml H ₂ O	545.9	544.1	1.8
2 XAD COND	1157.7	1157.3	0.4
3 5.16ul	674.1	671.6	2.5
4			

H₂O .02





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		83.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.6	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	86.2	79.9	71.7	61.8	38.9	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12							97.9	90.1	83.1	76.4	69.4	39.8
13								94.3	87.5	81.2	75.0	68.5
14									98.2	91.5	85.4	78.6
15										95.1	89.1	83.5
16											96.1	78.2
17												95.4
18												
19												
20												
21												
22												
23												
24												

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Matrix layout
9	3 3 3
12	4 3 5
16	5 4 7
20	6 5 9
25	7 6 12
30	8 7 15
36	9 8 18
42	10 9 21
48	11 10 24

STACK SAMPLING DATA SHEET

PLANT Susquehanna-Koppers Inc. DATE: 5/25/90 12/28/89
 LOCATION: FEMA/Vacuum TEST NO.: SUS-FVZ-4 METER CORRECTION: .9778
 ACTIVITY NO.: _____ NOZZLE: 3/8" SS Tubing PITOT CORRECTION: .84
 CONTROL BOX OPERATOR: MG STATIC PRESSURE Ps: +1.55 CONTROL BOX NO.: 3
 PROBE HANDLER: _____ PORT DIRECTION: Horizontal NOMOGRAPH SET POINT: _____
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.75 LENGTHS OF UMBILICAL _____ x 25' X x 50'

HOT BOX NO.: 1
 COLD BOX NO.: 1
 PROBE NO.: Teflon Tubing
 FILTER NO.: _____
 STACK DIA.: 8.0"

Point	Time	Meter Reading (dry) CF	Velocity HD in. H ₂ O	Orifice 4 H in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Temp. XAD Exit °F/F	Hot Box Iced Down °F	Comments
				Reg.	Act.	In	Out						
6" IN	0845	816.480	.05	.60	.60	67	59	4.0	69	NO READ	42		
			.035	.60	.60	71	59	4.0	70		40		
			.02	.60	.60	76	60	4.0	74		40		
			.02	.60	.60	78	61	4.0	74		40		
			.02	.60	.60	79	62	4.0	74		41		
			.015	.60	.60	81	63	4.0	76		40		
			.015	.60	.60	82	64	4.0	78		42		
			.015	.60	.60	82	65	4.0	79		42		
			.015	.60	.60	84	66	4.0	80		43		3.4770
			.015	.60	.60	86	68	4.0	81		42		
			.015	.60	.60	86	68	4.0	82		42		
	0945	845.112	.015	.60	.60	87	69	4.0	82		43		

LEAK CHECK

in. Hg.	Rate
6.0	4.02 CFM
6.5	4.02 CFM

ORSAT

CO ₂	1	2
O ₂	20.5	
CO		
N	79.5	

PITOT LEAK CHECK

POS.	NEG.
15cc	15cc

Impinger No.

Final	Initial	Difference
611.0	598.4	12.6
1157.7	1152.5	5.2
677.4	674.1	3.3

3.50 °C





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
 [Percent of stack diameter from inside wall to traverse point]

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.8	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.8	13.2
7				89.5	77.4	64.4	36.8	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	66.4	40.7	36.6
13							94.3	87.5	81.2	75.0	66.5	40.2
14							98.2	91.5	85.4	79.6	73.8	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												96.8
24												98.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Matrix layout
8	
12	
16	
20	
24	



US F 4 SUS = FV0-4

STACK SAMPLING DATA SHEET

PLANT: Saguycharwa Copper EXXOR DATE: 5/25/90 AHH#: 1.777 12-27-90 HOT BOX NO.: 5
 LOCATION: FINAL Vacuum Outlet TEST NO.: SUS-840-4 METER CORRECTION: 1.035 COLD BOX NO.: 5
 ACTIVITY NO.: Outlet NOZZLE: 7 Tc Flon Tubing PITOT CORRECTION: --- PROBE NO.: 4" TEIKON
 CONTROL BOX OPERATOR: PH STATIC PRESSURE PS: --- CONTROL BOX NO.: 1 FILTER NO.: NONE
 PROBE HANDLER: --- PORT DIRECTION: Horizontal NOMOGRAPH SET POINT: --- STACK DIA.: 4"
 CLEAN UP: --- BAROMETRIC PRESSURE: 29.75 LENGTHS OF UMBILICAL: x 25' X x 50' High Pressure Line

Point	Time	Meter Reading (dry) CF	Velocity $\frac{ft}{min}$	Orifice a H ₂ O		Meter Temp		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Jmp- Temp. XAD Exit %PF	Hot Box Temp °F	Comments
				Req.	Act.	In	Out						
2' IN	8:45	105.125	150 FPM	0.6	0.6	64	61	3.5	72		42	Ice on Down	
	8:50			0.6	0.6	69	62	3.5	72		42		
	8:55			0.6	0.6	71	64	3.5	69		41		
	9:00			0.6	0.6	73	66	3.5	71		41		
	9:05			0.6	0.6	75	67	3.5	70		42		
	9:10			0.6	0.6	76	68	4.0	70		41		
	9:15		140 FPM	0.6	0.6	78	70	4.0	71		41		
	9:20			0.6	0.6	80	71	4.0	72		42		
	9:25			0.6	0.6	81	73	4.0	75		41		
	9:30			0.6	0.6	83	75	4.0	76		41		
	9:35			0.6	0.6	85	77	4.0	78		42		
	9:40		100 FPM	0.6	0.6	87	79	4.0	79		41		
	9:45	130.850											

Impinger No. 81 Initial 544.6 Final 557.6 Difference 13
 1 100ml H₂O
 2 XAD COND. 1149.8
 3 316cl 634.3
 4 634.3

Initial 1142.9 Final 628.6 Difference 514.3
 1 100ml H₂O
 2 XAD COND. 1149.8
 3 316cl 634.3
 4 634.3

ORSAT

CO ₂	1	2
O ₂		
CO		
N		

PITOT LEAK CHECK

POS.	NEG.

LEAK CHECK

in. Hg.	Rate
10.0	1.02 FPM
	1.02 FPM





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
 [Percent of stack diameter from inside wall to traverse point]

Traverse point number on a diameter	Number of traverse points on a diameter—																
	2	4	6	8	10	12	14	16	18	20	22	24					
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1					
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2					
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5					
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9					
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5					
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2					
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1					
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4					
9					91.6	82.3	73.1	62.5	36.2	30.6	26.2	23.0					
10					97.4	86.2	78.9	71.7	61.8	38.8	31.5	27.2					
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3					
12						97.9	90.1	83.1	76.4	66.4	60.7	39.6					
13							94.3	87.5	81.2	75.0	68.5	60.2					
14								91.5	85.4	79.6	73.8	67.7					
15								98.2	95.1	89.1	83.5	78.2					
16									98.4	92.5	87.1	82.0					
17										95.6	90.3	85.4					
18											96.4	91.3					
19												96.8					
20													96.5				
21														96.5			
22															96.5		
23																96.9	
24																	96.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Measure layout
9	
12	
16	
20	
25	
30	
36	
42	
48	
72	



STACK SAMPLING DATA SHEET

PLANT Roasoke-Koppers Industate DATE: 5/23/90 HOT BOX NO.: Bucket #1
 LOCATION: Final Vacuum-Cyclones TEST NO.: Roasoke-FV-Cyc. #2 COLD BOX NO.: Bucket #1
 ACTIVITY NO.: _____ NOZZLE: 3/8" stainless tubing PITOT CORRECTION: .84 PROBE NO.: TeFlow + Stainless S1
 CONTROL BOX OPERATOR: _____ STATIC PRESSURE PS: _____ CONTROL BOX NO.: _____ FILTER NO.: _____
 PROBE HANDLER: Hospital PORT DIRECTION: Horizontal NOMOGRAPH SET POINT: _____ STACK DIA.: 4"
 CLEAN UP: _____ BAROMETRIC PRESSURE: 29.10 LENGTHS OF UMBILICAL _____ x 25' x 50'

Point	Time	Meter Reading (dry) CF	Velocity HD in. H ₂ O	Orifice ΔH in. H ₂ O		Meter Temp °F		Vacuum in. Hg	Stack Temp °F	Probe Temp °F	Temp. Temp. XAD Exit 8PF	Comments
				Reg.	Act.	In	Out					
	8:37	1015.400	15	0.0	0.0	66	64	16.0	262		43°F	Bucket Hor-Box Iced Down
	8:42		15	0.0	0.0	68	65	16.0	226		43	
	8:47		15	0.0	0.0	69	66	16.0	257		43	
	8:52		15	0.0	0.0	71	67	16.0	274		45	
	8:57		15	0.0	0.0	71	68	16.0	275		44	98% H ₂ O
	9:02		15	0.0	0.0	71	69	16.0	268		50	
	9:07		15	0.0	0.0	72	70	16.0	272		50	
	9:12		15	0.0	0.0	73	72	16.0	278		52	
	9:17		15	0.0	0.0	73	72	16.0	284		51	0 difference
	9:22		15	0.0	0.0	74	73	16.0	280		51	300.4
	9:27		15	0.0	0.0	75	75	16.0	281		53	(5) 39
	9:32		15	0.0	0.0	76	76	16.0	210		54	(7) 30

9:37 1017.785

LEAK CHECK

in. Hg.	Rate
10.0	1.02 CFM
16.0	1.02 CFM

ORSAT

CO ₂	1	2
O ₂		
CO		
N		

PITOT LEAK CHECK

POS.	NEG.
------	------

Impinger No.

1 DAY	831.2
2 100ml H ₂ O	954.9
3 DAY	902.9
4 Coll Cond.	1903.4

Initial 438.8 **Final** 564.6 **Difference** 125.8

Initial 448.5 **Final** 960.4 **Difference** 511.9

Initial 51 **Final** 54 **Difference** 3





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.8	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.6	82.3	73.1	62.5	36.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.6	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	39.8
13							94.3	87.5	81.2	75.0	68.5	60.2
14							98.2	91.5	85.4	79.6	73.9	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.9	88.4	83.9
19										98.1	91.3	86.8
20										98.7	94.0	89.5
21											98.5	92.1
22											98.9	94.5
23												98.8
24												98.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Meets layout
9	83
12	83
16	84
20	85
25	86
30	86
36	86
42	76
48	77





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—												
	2	4	6	8	10	12	14	16	18	20	22	24	
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1	
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2	
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5	
4		83.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9	
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5	
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2	
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1	
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.6	19.4	
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0	
10						97.4	79.9	71.7	61.8	38.8	31.5	27.2	
11							93.3	85.4	78.0	70.4	61.2	39.3	32.3
12							97.9	90.1	83.1	76.4	69.4	60.7	39.8
13								94.3	87.5	81.2	75.0	68.5	60.2
14								98.2	91.5	85.4	79.6	73.8	67.7
15									95.1	89.1	83.5	78.2	72.8
16									98.4	92.5	87.1	82.0	77.0
17										95.6	90.3	85.4	80.6
18										98.6	93.3	88.4	83.9
19											96.1	91.3	86.8
20											98.7	94.0	89.5
21												96.5	92.1
22												98.9	94.5
23													96.8
24													98.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Major layout
9	30
12	40
16	50
20	60
25	75
30	90
40	120
48	150





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
 (Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.8	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		83.3	70.4	32.3	22.6	17.7	14.6	12.5	10.6	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.6	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.9	85.4	78.0	70.4	61.2	39.3	32.3
12						97.6	90.1	83.1	76.4	69.4	60.7	38.8
13							94.3	87.5	81.2	75.0	66.5	60.2
14							98.2	91.5	85.4	78.6	73.9	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												98.8
24												98.9

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Matrix layout
9	3 3 3
12	4 3 5
16	5 4 6
18	6 5 6
20	7 6 7
25	8 7 8
30	9 8 9
36	10 9 10
42	11 10 11
48	12 11 12

APPENDIX B
ANALYTICAL RESULTS

**ORGANIC PAH ANALYSIS
CASE NARRATIVE
FOR
KOPPERS INDUSTRIES, INC.**

WORK ORDER #M90-06.87

Problems Encountered During Login:

- o None.

Problems Encountered During Extraction:

- o All samples were extracted by the Air Group. The following Samples M90-06.87-003, M90-06.87-004, M90-06.87-005, M90-06.87-006 and M90-06.87-007, Client I.D.s SUS-FCI-1, SUS-FCO-1, SUS-FCI-2, SUS-FCO-2 and SUS-ARI-3 were concentrated to 4 mls. Sample M90-06.87-008, Client I.D. SUS-ARO-3, had a twenty fold dilution done by extraction, then it was concentrated to 1 ml.

Problems Encountered During Analysis:

- o The three XAD blanks submitted with the samples all exhibited positive results for various analytes that were analyzed for.
- o When samples were originally submitted for analysis in June of 1990, analytes requested were naphthane, dibenzofuran and anthracene only. Upon the request for reworking the chromatographs for all PAH components, Sample M90-06.87-007, Client I.D. SUS-ARI-3, has the analytes fluoranthene, benzo(b)fluoranthene, benzo(k)fluoranthene and benzo(a)pyrene quantitated using values outside of the calibration curve. Sample M90-06.87-013, Client I.D. RO-FV-1, has the analyte carbazole quantitated from a value outside of the calibration curve. This is noted on the Data Report.

General Comments:

- o All 610 identifications are from retention time only.


Melinda S. Harty
Project Manager

#R3839

WORK ORDER M90-06.87
ANALYTICAL RESULTS
KOPPERS INDUSTRIES, INC.

Chester I.D.	Samples				
	87-003	87-004	87-005	87-006	87-007
	24-MAY-1990	24-MAY-1990	24-MAY-1990	24-MAY-1990	25-MAY-1990
Date Sampled					
Customer I.D.	SUS-FCI-1	SUS-FCO-1	SUS-FCI-2	SUS-FCO-2	SUS-ARI-3

Parameters	Units					
LC610						
Carbazole	mg/TS	<1.60	0.108	0.223	<0.800	<0.800
Naphthalene	mg/TS	24.7	1.48	5.07	11.0	1.04
Acenaphthylene	mg/TS	9.22	<0.800	<0.800	<0.800	<0.800
Acenaphthene	mg/TS	2.93	0.2	<0.800	1.20	0.213
Fluorene	mg/TS	0.827	0.041	0.807	0.152	0.0083
Phenanthrene	mg/TS	0.217	0.0587	0.507	0.0951	0.0799
Anthracene	mg/TS	0.036	0.0096	0.007	0.0184	0.0183
Fluoranthene	mg/TS	<0.008	<0.008	<0.008	<0.008	0.0342 *
Pyrene	mg/TS	<0.008	<0.008	<0.008	<0.008	0.0282
Benzo(a)anthracene	mg/TS	<0.0008	<0.0008	<0.0008	<0.0008	0.0065
Chrysene	mg/TS	0.0126	<0.006	<0.006	<0.006	0.0069
Benzo(b)fluoranthene	mg/TS	<0.0008	<0.0008	<0.0008	<0.0008	0.0063 *
Benzo(k)fluoranthene	mg/TS	<0.0008	<0.0008	<0.0008	<0.0008	0.0024 *
Benzo(a)pyrene	mg/TS	<0.0008	<0.0008	<0.0008	<0.0008	0.0032 *
Dibenzo(a,h)anthracen	mg/TS	<0.0012	<0.0012	<0.0012	<0.0012	<0.012
Benzo(g,h,i)perylene	mg/TS	<0.002	<0.002	<0.002	<0.002	<0.020
Indeno(1,2,3-cd)pyren	mg/TS	<0.002	<0.002	<0.002	<0.002	<0.020
Dibenzofuran	mg/TS	12.1	0.736	0.984	4.58	0.686
LC610 Surrogates						
2-Fluorobiphenyl	% Rec.	Matrix Int.	Matrix Int.	Matrix Int.	Matrix Int.	Matrix Int.
Benzo-e-pyrene	% Rec.	96.8	Diluted Out	Diluted Out	Diluted Out	110

NOTES:

mg/TS - Milligram per total sample.

* - Analytes quantitated from values outside calibration curve.

WORK ORDER M90-06.87
ANALYTICAL RESULTS
KOPPERS INDUSTRIES, INC.

Chester I.D.	Samples				
	87-008	87-009	87-010	87-011	87-012
	25-MAY-1990	25-MAY-1990	25-MAY-1990	23-MAY-1990	23-MAY-1990
Date Sampled					
Customer I.D.	SUS-ARO-3	SUS-FVI-4	SUS-FVO-4	RO-BOL-1	RO-HV-1

Parameters	Units					
LC610						
Carbazole	mg/TS	4.44	<0.200	<0.200	2.87	0.663
Naphthalene	mg/TS	569	4.72	2.24	20.7	19.8
Acenaphthylene	mg/TS	<80.0	<0.200	<0.200	3.26	<2.00
Acenaphthene	mg/TS	107	0.700	0.300	4.00	3.33
Fluorene	mg/TS	<8.00	0.0359	<0.020	0.365	0.336
Phenanthrene	mg/TS	10.8	0.0333	0.0206	0.124	0.094
Anthracene	mg/TS	3.04	0.0062	0.0036	0.060	0.0218
Fluoranthene	mg/TS	<8.00	0.0037	<0.002	0.0123	0.0052
Pyrene	mg/TS	1.03	<0.0020	<0.002	0.0128	<0.002
Benzo(a)anthracene	mg/TS	0.374	<0.0002	0.0012	<0.002	<0.0002
Chrysene	mg/TS	0.402	0.0055	<0.0015	<0.015	<0.0015
Benzo(b)fluoranthene	mg/TS	0.239	<0.0002	<0.0002	<0.002	<0.0002
Benzo(k)fluoranthene	mg/TS	0.102	<0.0002	<0.0002	<0.002	<0.0002
Benzo(a)pyrene	mg/TS	0.107	<0.0002	<0.0002	<0.002	<0.0002
Dibenzo(a,h)anthracen	mg/TS	0.280	<0.0003	<0.0003	<0.003	<0.0003
Benzo(g,h,i)perylene	mg/TS	0.0923	<0.0005	<0.0005	<0.005	<0.0005
Indeno(1,2,3-cd)pyren	mg/TS	0.0442	<0.0005	<0.0005	<0.005	<0.0005
Dibenzofuran	mg/TS	221	1.62	0.634	12.8	11.4
LC610 Surrogates						
2-Fluorobiphenyl	% Rec.	Matrix Int.	Matrix Int.	Matrix Int.	Matrix Int.	Matrix Int.
Benzo-e-pyrene	% Rec.	Matrix Int.	123	Diluted Out	Diluted Out	Diluted Out

NOTES:

mg/TS - Milligram per total sample.

* - Analytes quantitated from values outside calibration curve.

WORK ORDER M90-06.87
ANALYTICAL RESULTS
KOPPERS INDUSTRIES, INC.

		Samples			
Chester I.D.		87-013	87-014	87-015	87-016
Date Sampled		23-MAY-1990	25-MAY-1990	25-MAY-1990	23-MAY-1990
Customer I.D.		RO-FV-1	XAD-BLK LOT 42, 44, 45, 46	XAD-BLK LOT A	XAD-BLK KPX-90-1
Parameters	Units				
LC610					
Carbazole	mg/TS	3.71 *	<0.002	<0.002	<0.002
Naphthalene	mg/TS	83.0	0.0035	<0.002	<0.002
Acenaphthylene	mg/TS	<20.0	<0.002	<0.002	<0.002
Acenaphthene	mg/TS	20.0	0.0079	<0.002	0.0045
Fluorene	mg/TS	2.91	0.0002	<0.0002	<0.0002
Phenanthrene	mg/TS	0.792	0.00088	0.00075	0.00124
Anthracene	mg/TS	0.193	<0.0005	<0.0005	<0.0005
Fluoranthene	mg/TS	<0.020	<0.0002	<0.0002	0.00032
Pyrene	mg/TS	<0.020	<0.0002	<0.0002	<0.0002
Benzo(a)anthracene	mg/TS	0.0009	<0.00002	<0.00002	<0.00002
Chrysene	mg/TS	0.0023	<0.00015	<0.00015	<0.00015
Benzo(b)fluoranthene	mg/TS	0.00024	<0.00002	<0.00002	<0.00002
Benzo(k)fluoranthene	mg/TS	<0.0002	<0.00002	<0.00002	<0.00002
Benzo(a)pyrene	mg/TS	<0.0002	<0.00002	<0.00002	<0.00002
Dibenzo(a,h)anthracen	mg/TS	<0.0003	<0.00003	<0.00003	<0.00003
Benzo(g,h,i)perylene	mg/TS	<0.0005	<0.00005	<0.00005	<0.00005
Indeno(1,2,3-cd)pyren	mg/TS	<0.0005	<0.00005	<0.00005	<0.00005
Dibenzofuran	mg/TS	57.6	0.010	<0.002	0.002
LC610 Surrogates					
2-Fluorobiphenyl	% Rec.	Matrix Int.	75.8	76.4	73.1
Benzo-e-pyrene	% Rec.	Diluted Out	76.4	78.8	61.4

NOTES:

mg/TS - Milligram per total sample.

* - Analytes quantitated from values outside calibration curve.

APPENDIX C
CHARGING INFORMATION

CHARGE REPORT KOPPERS INDUSTRIES, INC.

CYCLE	PRESSURE OR VACUUM	TEMP. °F	TIME STARTED	TIME COMPLETED	LAPSED TIME (HOURS)
CONDITIONING					
1. STEAMING	LB.			M	M
2. VACUUM	IN.			M	M
3. PRESERVATIVE IN				M	M
4. HEATING IN OIL				M	M
5. BOULTON VACUUM	IN.			M	M
6. PRESERVATIVE BACK				M	M
TREATING					
7. INITIAL VACUUM	IN.			M	M
8. INITIAL AIR	65 LB.		4 00 A M	4 05 M	02
9. PRESERVATIVE IN			4 05 M	4 30 M	42
10. PRESSURE	200 LB.		4 30 A M	8 00 A M	3 50
11. EXPANSION BATH				M	M
12. PRESERVATIVE BACK			8 00 A M	8 30 A M	50
13. FINAL VACUUM	23 IN.		8 30 A M	10 30 A M	2 00
14. RECOVERING DRIPPINGS			10 30 A M	10 40 A M	17
15. SECONDARY STEAM	LB.			M	M
16. SECONDARY VACUUM	IN.			M	M
17. CHANGING TIME					33
TOTAL TIME					7 00

MEASURING TANK READINGS	TANK FEET	TEMP °F	CORRECTION FACTOR	TANK FEET AT 100° F	OIL OR SOLUTION	
					GALLONS	POUNDS
1. BEFORE INTRODUCING PRESERVATIVE		176°				370.00
2. AFTER FILLING CYLINDER		182°				65.00
3. AT END OF PRESSURE PERIOD		209				50.00
4. AFTER RELEASING PRESSURE		209				60.00
5. AFTER FORCING BACK		193				362.00
6. AFTER FINAL VACUUM		158				363.40
7. PRESERVATIVE RETAINED (1-6)						13.00

TANK NO. #1 GAL./FT. OIL OR SOLUTION _____ LB./GAL. AT 100° _____ PERCENT CHEMICALS IN SOLUTION _____

TRACK SCALE READINGS: GROSS _____ TARE _____ NET _____ CONDENSATE _____

HEATING SUPERVISOR _____ SUPERINTENDENT _____		PRESERVATIVE RETAINED IN CHARGE				
OPERATOR(S) <u>WJR. KKH</u>		CREOSOTE TYPE PRESERVATIVE		OIL OR WATER BORNE PRESERVATIVE		
		GALLONS	POUNDS	GALLONS	POUNDS	
INSPECTOR _____		TOTAL	19,600			
		PER CU. FT.	8.23			
SALES ORDER NUMBER _____						
CUSTOMER <u>KCR</u>						
INDICATE "TSD" OR "KOPPERS" _____						
SEASONED CONDITION <u>Boulton Boulton</u>						
SPECIES <u>TA</u>						
COMMODITY <u>Fl. CR.</u>						
SPECIFIED RETENTION PER CU. FT. <u>8+</u>						
QUANTITIES: PIECES AND/OR SIZES						
<input type="checkbox"/> FBM (NOM.) OR <input checked="" type="checkbox"/> DR.F.		<u>115</u>	<u>143</u>			
CUBIC FEET		<u>1217</u>	<u>16418</u>	TOTALS		
PERCENTAGE OF TOTAL		<u>43%</u>	<u>57%</u>	<u>285%</u>		
PRESERVATIVE REQUIRED <input type="checkbox"/> GAL. OR <input type="checkbox"/> LB.						
USED <input type="checkbox"/> GAL. OR <input checked="" type="checkbox"/> LB.		<u>8428</u>	<u>11172</u>	<u>19,600</u>		
CYLINDER HOURS: CONDITIONING		<u>9.5</u>	<u>12.5</u>	<u>21.50</u>		
TREATING		<u>3.01</u>	<u>3.99</u>	<u>7.00</u>		
DATE COMMENCED <u>5-25-90</u>	DATE COMPLETED <u>5-25-90</u>	PLANT <u>Sulphurhanna</u>	CYLINDER NO. <u>#1</u>			
SPECIFIED TREATMENT <u>60/40</u>	PRESERVATIVE <u>Boulton</u>	CONDITIONING <u>Boulton</u>	TREATING PROCESS <u>KMP</u>	CHARGE NO. <u>K-289</u>		

CHARGE NO.		CYLINDER NO.	CUSTOMER			DATE	
K-280		#1	KCR			5-24-90	
GALLONS OF WATER TO BE REMOVED		PCS OR BF	MATERIAL	CU. FT.	SPECIES		
2025		258	BR. + F1.	2380	TA		
HRS	TIME AM OR PM	GALLONS PER 1/4 HOUR	CUMULATIVE	SIDE TEMP	VACUUM	BOTTOM TEMP	HRS
1	9:00 AM	202	202	189	13"	189	1
2	9:30	31	233	191	13 1/2"	191	2
3	10:00	60	293	193	14 1/2"	193	3
4	10:30	94	387	193	17"	193	4
5	11:00	89	476	195	17"	195	5
6	11:30	39	565	196	20 1/2"	196	6
7	12:00	39	654	196	21 1/2"	196	7
8	12:30	28	692	192	21 1/2"	192	8
9	1:00	59	741	192	21 1/2"	192	9
10	1:30	59	800	176	21 1/2"	196	10
11	2:00	60	860	197	21 1/2"	197	11
12	2:30	30	990	197	21 1/2"	197	12
13	3:00	60	1050	195	21 1/2"	195	13
14	3:30	30	1080	114	21 1/2"	194	14
15	4:00	59	1139	113	21 1/2"	193	15
16	4:30	44	1183	190	21 1/2"	190	16
17	5:00	43	1226	190	21 1/2"	190	17
18	5:30	30	1256	191	21 1/2"	191	18
19	6:00	59	1213	194	21 1/2"	194	19
20	6:30	44	1257	195	21 1/2"	195	20
21	7:00	44	1301	196	21 1/2"	196	21
22	7:30	54	1360	196	21 1/2"	196	22
23	8:00	30	1390	194	21 1/2"	194	23
24	8:30	45	1435	191	21 1/2"	191	24
25	9:00	45	1480	190	21 1/2"	190	25
26	9:30	30	1510	189	21 1/2"	189	26
27	10:00	58	1568	190	21 1/2"	190	27
28	10:30	30	1598	193	21 1/2"	193	28
29	11:00	58	1656	193	21 1/2"	193	29
30	11:30	30	1626	193	21 1/2"	193	30
31	12:00/AM	9	174	195	21 1/2"	195	31
32	12:30	9	1774	195	21 1/2"	195	32
33	1:00	9	1804	195	21 1/2"	195	33
34	1:30	9	1833	194	21 1/2"	194	34
35	2:00	9	1843	196	21 1/2"	196	35
36	2:30	9	1852	190	21 1/2"	190	36
37	3:00	9	1881	192	21 1/2"	192	37
38	3:30	9	2040	192	21 1/2"	192	38
39							39
40							40
41							41
42							42
43							43
44							44
45							45
46							46
47							47
48							48

	START	END	WATER REMOVED		TANK NO.	TEMP.
FILL	6:00	7:00	HEAT	2000	011021	BEFORE FILL
HEAT	7:20	3:00	VACUUM		170000	AFTER FILL
P.B.			FIN. VAC.	175		AFTER P.B.
VACUUM			TOTAL	7.74		DIFFERENCE
			LBS/CU. FT.	7.74		
BOULTON TIME						

CHARGE REPORT KOPPERS INDUSTRIES, INC.

CYCLE	PRESSURE OR VACUUM	TEMP. °F	TIME STARTED	TIME COMPLETED	LAPSED TIME (HOURS)
CONDITIONING					
1. STEAMING	LB.		M	M	
2. VACUUM	IN.		M	M	
3. PRESERVATIVE IN			M	M	
4. HEATING IN OIL			M	M	
5. BOULTON VACUUM	IN.		M	M	
6. PRESERVATIVE BACK			M	M	
TREATING					
7. INITIAL VACUUM	IN.		M	M	
8. INITIAL AIR	65 LB.		7 25 AM	7 30 AM	08
9. PRESERVATIVE IN			7 30 AM	7 50 AM	33
10. PRESSURE	200 LB.		7 50 AM	12 20 PM	4 50
11. EXPANSION BATH			M	M	
12. PRESERVATIVE BACK			12 20 PM	12 50 PM	50
13. FINAL VACUUM	19 1/2 IN.		12 50 PM	2 50 PM	2 00
14. RECOVERING DRIPPINGS			2 50 PM	3 00 PM	17
15. SECONDARY STEAM	LB.		M	M	
16. SECONDARY VACUUM	IN.		M	M	
17. CHANGING TIME					33
TOTAL TIME					7 91

MEASURING TANK READINGS	TANK FEET	CYL. TEMP °F	CORRECTION FACTOR	TANK FEET AT 100° F	OIL OR SOLUTION	
					GALLONS	POUNDS
1. BEFORE INTRODUCING PRESERVATIVE		180				380,000
2. AFTER FILLING CYLINDER		180				163,000
3. AT END OF PRESSURE PERIOD		210				146,000
4. AFTER RELEASING PRESSURE		210				154,400
5. AFTER FORCING BACK		200				375,000
6. AFTER FINAL VACUUM		180				379,000
7. PRESERVATIVE RETAINED (1-6)					13,000	12,000

TANK NO. #2 GAL./FT. OIL OR SOLUTION _____ LB./GAL. AT 100° _____ PERCENT CHEMICALS IN SOLUTION _____

TRACK SCALE READINGS: GROSS _____ TARE _____ NET _____ CONDENSATE _____

HEATING SUPERVISOR OR SUPERINTENDENT _____	PRESERVATIVE RETAINED IN CHARGE				
	CREOSOTE TYPE PRESERVATIVE		OIL OR WATER BORNE PRESERVATIVE		
	GALLONS	POUNDS	GALLONS	POUNDS	DRY CHEMICAL POUNDS
OPERATOR(S) <u>Kah</u>	TOTAL	25,000			
INSPECTOR _____	PER CU. FT.	7.20			

SALES ORDER NUMBER			
CUSTOMER	KCR		
INDICATE "TSD" OR "KOPPERS"			
SEASONED CONDITION	BOULTON		
SPECIES	TA		
COMMODITY	X-TCS		
SPECIFIED RETENTION PER CU. FT.	7		
QUANTITIES: PIECES AND/OR SIZES	959		TOTALS
<input type="checkbox"/> FBM (NOM.) OR <input type="checkbox"/> L.F.			
CUBIC FEET	3472		3472
PERCENTAGE OF TOTAL	100%		100%
PRESERVATIVE REQUIRED <input type="checkbox"/> GAL. OR <input type="checkbox"/> LB.			
USED <input type="checkbox"/> GAL. OR <input checked="" type="checkbox"/> LB.	25,000		25,000
CYLINDER HOURS: CONDITIONING	21.00		21.00
TREATING	7.91		7.91

DATE COMMENCED <u>5-25-90</u>	DATE COMPLETED <u>5-25-90</u>	PLANT <u>Surguherman</u>	CYLINDER NO. <u>#2</u>
SPECIFIED TREATMENT PRESERVATIVE <u>60140</u>	CONDITIONING <u>Boulton</u>	TREATING PROCESS <u>Ruef</u>	CHARGE NO. <u>K-290</u>

CHARGE NO.		CYLINDER NO.		CUSTOMER		DATE			
K-290		#2		KCR		5/24/90			
GALLONS OF WATER TO BE REMOVED		PCS OR BF		MATERIAL		CU. FT.		SPECIES	
290		959		X-Tics		3412		TA	
HRS	TIME AM or PM	GALLONS PER 1/4 HOUR		CUMULATIVE		SIDE TEMP	VACUUM	BOTTOM TEMP	HRS
1	1:00 PM	50	50	130	130	180	180	180	1
2	1:30	47	97	130	170	180	180	180	2
3	2:00	48	145	130	170	180	180	180	3
4	2:30	25	170	130	170	180	180	180	4
5	3:00	73	243	185	190	185	185	185	5
6	3:30	50	293	185	190	185	185	185	6
7	4:00	76	369	185	190	185	185	185	7
8	4:30	64	433	185	190	185	185	185	8
9	5:00	63	496	190	190	185	185	185	9
10	5:30	52	548	190	190	185	185	185	10
11	6:00	78	626	190	190	185	185	185	11
12	6:30	77	703	190	190	185	185	185	12
13	7:00	76	779	195	195	185	185	185	13
14	7:30	74	853	195	195	185	185	185	14
15	8:00	50	903	195	195	185	185	185	15
16	8:30	49	952	195	195	185	185	185	16
17	9:00	50	1002	195	195	185	185	185	17
18	9:30	52	1054	190	190	185	185	185	18
19	10:00	26	1080	190	190	185	185	185	19
20	10:30	50	1130	190	190	185	185	185	20
21	11:00	50	1180	190	190	185	185	185	21
22	11:30	69	1249	190	190	185	185	185	22
23	12:00	68	1317	190	190	185	185	185	23
24	12:30	67	1384	190	190	185	185	185	24
25	1:00	70	1454	190	190	185	185	185	25
26	1:30	66	1520	190	190	185	185	185	26
27	2:00	68	1588	190	190	185	185	185	27
28	2:30	69	1657	190	190	185	185	185	28
29	3:00	67	1724	190	190	185	185	185	29
30	3:30	66	1790	190	190	185	185	185	30
31	4:00	53	1843	190	190	185	185	185	31
32	4:30	67	1910	190	190	185	185	185	32
33	5:00	72	1982	190	190	185	185	185	33
34	5:30	55	2037	190	190	185	185	185	34
35	6:00	52	2089	190	190	185	185	185	35
36	6:30	55	2144	190	190	185	185	185	36
37									37
38									38
39									39
40									40
41									41
42									42
43									43
44									44
45									45
46									46
47									47
48									48

	START	END	WATER REMOVED		#2	TANK NO.	TEMP.
FILL	10:00 AM	10:30 AM	HEAT	2024	403,000	BEFORE FILL	150
HEAT	10:30 AM	6:30 PM	VACUUM		272,000	AFTER FILL	175
P.B.	6:30	7:23 PM	FIN. VAC.	260	390,000	AFTER P.B.	150
VACUUM			TOTAL	2,244	13,500	DIFFERENCE	
			LBS/CU. FT.				

BOULTON TIME

APPENDIX D
CALCULATIONS



SAMPLE SUS-IFC-1

$$N_s = k_p c_p \sqrt{\Delta P_{avg}} \sqrt{\frac{T_s}{P_s M_s}}$$

$$k_p = 85.49 \text{ ft/sec}$$

$$c_p = 0.84$$

$$\Delta P_{avg} = .0479$$

$$T_s = 460 + 105$$

$$P_s = 29.60 + 0.4/13.6 = 28.64$$

$$M_s = 28.8(1 - 0.102) + 18(0.102) = 27.7$$

$$N_s = (85.49)(0.84)(\sqrt{.0479}) \left(\sqrt{\frac{565}{(29.64)(27.7)}} \right)$$

$$N_s = (85.49)(0.84)(0.2188)(.8295)$$

$$N_s = 13.03 \frac{\text{ft}}{\text{sec}} \times 60 \frac{\text{sec}}{\text{min}} = 782.06 \frac{\text{ft}}{\text{min}}$$

$$Q = 782.06 \frac{\text{ft}}{\text{min}} \times 0.35 \text{ ft}^2 = 273.7 \text{ ACFM}$$

$$Q_s = 273.7 \text{ ACFM} \left(\frac{528}{565} \right) \left(\frac{29.64}{29.92} \right) = 253.4 \text{ SCFM}$$

$$Q_{SD} = 253.4 \text{ SCFM} (1 - 0.102) = 227 \text{ DSCFM}$$



SAMPLE SUS-IFC-2

$$N_s = K_p C_p \sqrt{\Delta P_{avg}} \sqrt{\frac{T_s}{P_s M_s}}$$

$$K_p = 85.49 \text{ ft/sec}$$

$$C_p = 0.84$$

$$\Delta P_{avg} = 0.05125$$

$$T_s = 460 + 110 = 570$$

$$P_s = 29.60 + \frac{0.6}{13.6} = 29.64$$

$$M_s = 28.8(1 - 0.1273) + (18)(0.1273) = 27.43$$

$$N_s = (85.49)(0.84) \left(\sqrt{0.05125} \right) \left(\sqrt{\frac{570}{(29.64)(27.43)}} \right)$$

$$N_s = (85.49)(0.84)(0.226)(0.8371)$$

$$N_s = 13.61 \frac{\text{ft}}{\text{sec}} \times 60 \frac{\text{sec}}{\text{min}} = 816.7 \frac{\text{ft}}{\text{min}}$$

$$A = 0.35 \text{ ft}^2$$

$$Q = 816.7 \frac{\text{ft}}{\text{min}} \times 0.35 \text{ ft}^2 = 285.8 \text{ ACFM}$$

$$Q_s = 285.8 \text{ ACFM} \left(\frac{528}{570} \right) \left(\frac{29.64}{29.92} \right) = 262.3 \text{ SCFM}$$

$$Q_{50} = 262.3 \text{ SCFM} (1 - 0.1273) = 228.9 \text{ DSCFM}$$