



**am test inc.**

4900 9TH AVENUE N.W., • SEATTLE, WASHINGTON 98107-3697 • 206/783-4700

**ATMOSPHERIC  
EMISSION  
EVALUATION**

**AUGUST 5, 1985**

**Prepared For:**

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

**LAKESIDE INDUSTRIES  
MADSON ASPHALT PAVING PLANT  
LACEY, WASHINGTON  
JULY 18, 1985**

**Submitted by:**

**KRIS A. HANSEN  
DIRECTOR, AIR QUALITY DIVISION  
AM TEST, INC.  
SEATTLE, WASHINGTON**

## INTRODUCTION

The purpose of this atmospheric emission evaluation performed at Lakeside Industries' Madson asphalt paving plant located in Lacey, Washington was to determine the particulate emission concentration of the baghouse exhaust gas. Three (3) particulate emission concentration compliance tests were performed on July 18, 1985 utilizing the Environmental Protection Agency's (EPA) Method 5 procedures. Mr. James A. Guenthoer of Am Test, Inc., Seattle, Washington performed the field sampling and laboratory analysis. Mr. Kris A. Hansen of Am Test performed data reduction. Mr. Harold Nickel of Lakeside Industries coordinated this project. Mr. Bob Smith, Lakeside Industries' Lacey plant foreman, coordinated plant operations. Mr. Jim Wilson of the Olympic Air Pollution Control Authority (OAPCA) observed the field testing.

## SUMMARY OF RESULTS

The results of the three (3) Method 5 compliance tests for determining particulate emission concentration, collected July 18, 1985 at Lakeside Industries' Lacey, Washington facility, are summarized in Table 1 below:

Table 1. Summary of particulate emission concentration test results.

| SAMPLE<br>RUN<br># | AM TEST<br>LAB<br># | PARTIC.<br>CONC.<br>gr/dscf | MASS<br>EMISSION<br>RATE<br>lbs/hr | ST. OF WA.<br>PARTIC.<br>STD<br>gr/dscf | AIR<br>FLOW<br>dscf/m |
|--------------------|---------------------|-----------------------------|------------------------------------|-----------------------------------------|-----------------------|
| =====              | =====               | =====                       | =====                              | =====                                   | =====                 |
| 1                  | 92151               | 0.056                       | 15.49                              | 0.10                                    | 32209                 |
| 2                  | 92152               | 0.058                       | 17.35                              | 0.10                                    | 34695                 |
| 3                  | 92153               | 0.056                       | 16.44                              | 0.10                                    | 34459                 |
| AVERAGE            |                     | 0.056                       | 16.43                              | 0.10                                    | 33788                 |

The average particulate mass emission rate of 0.056 grains per dry standard cubic foot (gr/dscf) was within the Olympic Air Pollution Control Authority (OAPCA) standard of 0.10 gr/dscf for this particular asphalt paving plant. Computer printouts which detail the complete results immediately follow the "Calculation of Results" section of this report. An acceptable leak check followed each run. The percentage isokinetics were within the acceptable limits of  $100 \pm 10\%$  for each run. Run 1 was nearly completed when Lakeside personnel signaled that the holding silo was full and they were stopping the process. The test was stopped at 59.3 minutes into the run. During run 3 the probe-to-filter connecting glassware was broken when switching from port 3 to port 4 after 45 minutes of sampling time. The plant was near the end of its' production day when this breakage occurred, therefore, Mr. Guenthoer of Am Test and Mr. Wilson of OAPCA decided that it would be appropriate to discontinue sampling. The filter and condenser section of the Method 5 train were leak-checked and found to be within the acceptable EPA criteria.

## DISCUSSION

### SAMPLING PROCEDURES - OVERVIEW

Sampling procedures specified in the July 1, 1984 Title 40 Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A, Methods 1-5, were followed throughout this project. Methodology suggested in the Environmental Protection Agency's (EPA's) Air Pollution Training Institute "Course 450 - Source Sampling for Particulate Pollutants" and quality assurance procedures outlined in the EPA's reference manual titled Quality Assurance Handbook for Air Pollution Measurement Systems, Volume 3, EPA-600/4-77-0276, along with current updates, were used for supplemental information with respect to quality assurance and testing protocol.

### SAMPLING PROCEDURES - SPECIFIC

The 31 inch by 37 inch rectangular stack had four (4) sampling ports located at equal distances along the 37 inch side. The sampling ports were located 3 feet upstream and 15 feet downstream from the nearest flow disturbance. Four (4) traverses of six (6) points each were selected according to Method 1 criteria (40 CFR 60, July 1, 1984). Each point was sampled for 2.5 minutes, for a total sampling time for each Method 5 run of 60 minutes. Both the sample probe and the support plank were marked with felt pen to indicate the proper point location.

Stack condition measurements were performed prior to testing. A sample nozzle was chosen and isokinetic operating parameters were established utilizing a Hewlett-Packard 41CX programmable calculator. The sampling nozzle, probe and prefilter connective glassware were acetone cleaned prior to use. The sample train was assembled and determined to be leak free following the procedures outlined in

Method 5. Before each test a final check was made to assure that the plant was operating at the desired production rate and the desired operating parameters. A final check was made of the box and probe heat. Ice was added to the condenser section. The sample nozzle was positioned in the stack at the first sample point. The sample pump was then turned on and the sampling rate adjusted for isokinetic sampling. Sampling proceeded isokinetically at each of the 6 traverse points. The pump was then turned off and the sample train was moved to the second port. Care was taken to assure that the nozzle tip did not touch the port nipple. The nozzle was then positioned at the first point of the second traverse, the pump was again turned on and isokinetic sampling was performed at the 6 traverse points. Upon completion of the second traverse the probe was removed from the stack and the third and fourth sampling ports were traversed. A post-test leak check was performed according to Method 5 procedures.

#### SAMPLE TRAIN

The sample train used was an EPA Method 5 design with modifications as shown in Figure 1. The stainless steel button hook nozzle used had a diameter of 0.183 inches as measured on-site with inside calipers. A three (3) foot stainless steel probe with a heated liner was used for these tests. The probe was equipped with S-type pitot tubes and a thermocouple sensor. The pitot tubes have been recently calibrated at the State of Washington Department of Ecology (DOE) wind tunnel. A thermocouple probe was used to measure the stack gas temperature. The Fluke thermocouple indicator has been certified by the manufacturer to be accurate within 1 degree Fahrenheit. A field check with 32 degree icewater was performed. A glass filter assembly with a 125 millimeter glassfiber filter was enclosed in a temperature controlled heated box. The average box temperature was maintained at  $248^{\circ}\text{ F} \pm 25^{\circ}\text{ F}$ . The nozzle, probe liner, prefilter connective glassware and

glassfiber filter is often referred to as the "fronthalf" of the sample train. Following the filter is a condenser section which, by convention, is referred to as the "backhalf". The condenser section consisted of a modified Smith-Greenburg bubbler containing 100 milliliters (ml) of deionized, distilled water, an impinger also containing 100 ml of deionized, distilled water, an empty bubbler, and a bubbler containing indicating silica gel desiccant. The backhalf was maintained at a temperature below 70<sup>0</sup> F. The sample train was connected to a control box by means of an umbilical cord which contains a vacuum hose, pitot lines, thermocouple wires and a 4-wire electrical cord. The control box (meter box) was used to monitor stack conditions and to facilitate isokinetic sampling. The control box consists of a diaphragm pump used to pull the stack gas through the sample train, fine and course metering valves to control the sampling rate, a vacuum gauge which measures the pressure drop from the sampling nozzle to the metering valves, and a dry gas meter. The dry gas meter has been recently calibrated on a spirometer at the State of Washington Department of Ecology. At the outlet of the dry gas meter is a critical orifice which is used to isokinetically control the flow of gas through the metering system. The pressure drop across the orifice was monitored with both low and high range magnehelic gauges. The pitot tubes utilized to measure stack gas velocity are connected to the control box via the umbilical cord. The control box contains low and high range magnehelic gauges which are used for the velocity measurement.

#### SAMPLE CLEAN-UP AND ANALYSIS

Following sample collection, the Method 5 sample box was transferred to a room free from air disturbances and airborne particulate. The glassfiber filter was transferred to a petri dish labeled with the sample date, client name and run number. This portion of the particulate catch is referred to as the "A" section.

Care was taken to assure that any loose particulate matter and filter mat were quantitatively transferred to the petri dish. The filters were then placed in an oven and baked at  $103^{\circ}\text{C}$  for 2 hours, then they were transferred to a desiccator containing indicating silica gel for 24 hours of desiccation prior to obtaining final weights. The tare and final weights were made using a Mettler AE163 electronic balance set to a time integrating mode with a readability of 0.1 milligrams. The filters containing particulate matter were weighed to a constant weight of  $\pm 0.5$  milligrams. The interval between weighings was at least 6 hours. These weights were recorded in a bound laboratory notebook.

The contents of the nozzle, probe liner and prefilter connective glassware were quantitatively transferred to the "B" section storage container labeled with sample date, client name, and run number. Several rinses of acetone, with simultaneous loosening of particulate matter using a clean nylon brush, were used for the fronthalf clean-up. An iodine flask with a female ball joint end was attached to the male ball joint end of the probe to assure that no particulate matter was lost during the cleaning of the probe. This contents of this "B" section acetone rinse were transferred to tared 150 milliliter beakers. The volume of acetone in the beaker was recorded and the beakers were placed on a hot plate with the temperature set on low. The acetone was evaporated under close supervision at a temperature lower than the boiling point of acetone. A tared beaker with 100 milliliters of acetone was handled in an identical fashion to the "B" section samples as a control. The tare and final weights of the beakers were obtained following 2 hours of heating to  $103^{\circ}\text{C}$  and 24 hours of desiccation, as with the filters described above. The samples and acetone blanks were weighed to a constant weight of  $\pm 0.5$  milligrams at 6 hour or greater intervals.

The bubblers and impingers utilized for the condenser section, or "backhalf" of the sample train were weighed with an accuracy of  $\pm 0.1$  grams before and after sampling on a triple beam balance. The difference between the initial and final weights of the condenser section constitute the amount of moisture gain during the run. The percent moisture was calculated and did not exceed the theoretical psychrometric chart value. The particulate weights are included on the "Method 5-Particulate Emission Concentration Results" computer printouts which immediately follow the "Calculation of Results" section of this report.

## QUALITY ASSURANCE

A strict quality assurance program was followed throughout preparation, sampling, analysis, and report preparation. This program includes recent equipment calibrations, careful chain-of-custody procedures, and use of ACS quality or better reagents.

The sample nozzle was calibrated on-site before sampling using inside calipers accurate to  $\pm 0.001$  inch. The dry gas meter was recently calibrated on a spirometer at the Washington State Department of Ecology (DOE). The "S" type pitot tubes have been recently calibrated at the DOE laboratory utilizing a wind tunnel and a standard "P" type pitot tube. The Fluke thermocouple indicator has an accuracy of  $\pm 1$  degree Fahrenheit.

In addition to quantitative clean-up and analysis procedures, acetone and filter blanks were carried throughout the laboratory procedures. The Method 5 filters and beakers were weighed to a constant weight of  $\pm 0.5$  milligrams. Additional

information with respect to the Am Test, Inc. laboratory quality assurance and quality control protocol is included in the Appendix of this report.

## **CALCULATION OF RESULTS**

The results of these tests were calculated using the equations found in the 40 CFR 60 Methods 1-5. These equations are included in the Appendix. Final result calculations were performed using Hewlett-Packard 110 and 150 computer systems. A by-hand sample calculation for the Method 5 runs was performed on a Hewlett-Packard 41CX calculator, and may be found in the Appendix of this report.

## **APPENDIX**

## TABLE OF CONTENTS

|                                                         | <u>Pages</u> |
|---------------------------------------------------------|--------------|
| INTRODUCTION                                            | 1            |
| SUMMARY OF RESULTS                                      | 1-2          |
| DISCUSSION                                              | 3-7          |
| Sampling Procedures - Overview                          | 3            |
| Sampling Procedures - Specific                          | 3-4          |
| Sampling Train                                          | 4-5          |
| Sample Clean-Up and Analysis                            | 5-7          |
| QUALITY ASSURANCE                                       | 7-8          |
| CALCULATION OF RESULTS                                  | 8            |
| Method 5 - Particulate Emission Concentration Printouts | 9-11         |
| APPENDIX                                                |              |
| Method 1 - Location of Traverse Points                  | 12-13        |
| Method 2 - Stack Gas Velocity                           | 14           |
| Method 3 - Molecular Weight and Excess Air Calc.        | 14           |
| Method 4 - Stack Gas Moisture                           | 15           |
| Method 5 - Particulate Emission Conc. Calc.             | 16-17        |
| Sample Calculation Sheet - Method 5                     | 18           |
| Figure 1. Method 5 Sample Train Schematic               | 19           |
| Professional Resumes                                    | 20-21        |
| Am Test Laboratory - Information and Services           | 22-24        |
| Am Test Laboratory Quality Assurance & Quality Control  | 25-28        |
| Field Data Sheets                                       | 29-31        |
| Source Test Observation Checklist                       | 32           |

METHOD: PARTICULATE EMISSION CONCENTRATION RESULTS  
AM TEST, INC. - AIR QUALITY DEPARTMENT

9

FILE NAME: LKSD\_R1 LAB #: 92151  
CLIENT: LAKESIDE INDUSTRIES START TIME: 0749 0'CLOCK  
LOCATION: LACEY, WASHINGTON STOP TIME: 0856 0'CLOCK  
SAMPLE SITE: BAGHOUSE OUTLET SAMPLE TIME: 59.3 MINUTES  
SAMPLE DATE: JULY 18, 1985 PRODUCTION RATE: 250 TONS/HR  
RUN #: 1-METHOD 5 MIXED REFUSE  
OPERATORS: JIM GUENTHOER  
CONTACT: BOB SMITH  
CONTACT: HAROLD NICKEL

FRONTHALF PARTICULATE MASS LOADING

FILTER NUMBER: #125-008  
TARE WEIGHT OF FILTER IN GRAMS: 0.6082  
FINAL WEIGHT OF FILTER IN GRAMS: 0.6796  
NET WEIGHT OF PARTIC. MATTER IN GRAMS: 0.0714

BEAKER NUMBER: #85-354  
TARE WEIGHT OF BEAKER IN GRAMS: 68.2786  
FINAL WEIGHT OF BEAKER IN GRAMS: 68.3625  
NET WEIGHT OF PARTIC. MATTER IN GRAMS: 0.0839  
VOLUME OF ACETONE IN MILLILITERS: 110.0

FINAL WT. INIT. WT. NET WT.  
OF H2O G. OF H2O G. OF H2O G.  
679.1 577.4 101.7  
592.4 573.3 19.1  
466.6 464.7 1.9  
838.0 829.0 9.0  
TOTAL H2O GAIN: 131.7  
TOTAL VOLUME (SCF) 6.20  
PERCENT MOISTURE: 12.69  
Bws: 0.1269  
PITOT Cp: 0.845  
NOZZLE DIA INCHES: 0.183  
NOZZLE AREA FT^2: 0.0002  
STACK DIA. INCHES: 31"X37"  
STACK AREA FT^2: 7.965  
METER TEMP. DEG F: 72.0  
BAROM. PRES. "HG: 29.96  
STATIC PRES. "H2O: 3.00  
STACK PRES. "HG: 30.18  
ORIFICE PRES "H2O: 0.98  
METER PRES. "HG: 30.25

TARE WEIGHT OF ACETONE IN GRAMS: 66.8075  
FINAL WEIGHT OF ACETONE IN GRAMS: 66.8077  
VOLUME OF ACETONE IN MILLILITERS: 100.0  
NET CONTRIBUTION OF ACETONE IN MG/ML: 0.0020  
TOTAL FRONTHALF PARTIC. MATTER IN GRAMS: 0.1551

INIT. METER VOLUME 250.611  
FINAL METER VOLUME 293.003  
VOLUME SAMPLED: 42.392  
STD VOLUME (DSCF): 42.652  
STD VOLUME (DSCM): 1.507  
Y FACTOR: 1.010

AVERAGE % CO2: 8.2  
AVERAGE % O2: 10.3  
AVERAGE % CO: .0  
STACK GAS MW. DRY: 29.72  
STACK GAS MW. WET: 28.23

JAW

$$C_{p, \text{corrected}} = \frac{12}{\% \text{CO}_2} \times C_p (\text{uncorr.})$$

$$= \frac{12}{8.2} \times .056 = 0.082$$

\*\*\*\*\*  
SAMPLE VELOCITY TEMPERATURE SAMPLE VELOCITY TEMPERATURE  
POINT " OF H2O DEGREES F. POINT " OF H2O DEGREES F.

|   |      |     |   |      |     |
|---|------|-----|---|------|-----|
| 1 | 0.75 | 155 | 1 | 1.00 | 156 |
| 2 | 1.35 | 155 | 2 | 1.30 | 159 |
| 3 | 2.00 | 156 | 3 | 1.70 | 159 |
| 4 | 2.80 | 156 | 4 | 2.20 | 159 |
| 5 | 3.00 | 156 | 5 | 3.00 | 159 |
| 6 | 3.00 | 156 | 6 | 3.50 | 159 |
| 1 | 0.95 | 156 | 1 | 1.20 | 159 |
| 2 | 1.70 | 156 | 2 | 1.50 | 160 |
| 3 | 2.00 | 158 | 3 | 1.90 | 161 |
| 4 | 2.80 | 158 | 4 | 2.40 | 158 |
| 5 | 3.50 | 158 | 5 | 3.00 | 159 |
| 6 | 3.50 | 156 | 6 | 3.00 | 159 |

\*\*\*\*\*

PERCENT ISOINETICS: 97 %  
STACK TEMPERATURE: 157.6 DEG. F. 617.6 DEG. R.  
AVERAGE VELOCITY HEAD: 2.12 " OF H2O  
STACK GAS VELOCITY: 88.63 AFT/SEC 89.52 FT/SEC.  
STACK GAS AIR FLOW: 42359.21 ACF/M 32209.3 DSCF/M  
PARTICULATE CONCENTRATION: 0.056 GR/DSCF  
POLLUTANT MASS RATE (CONCENTRATION METHOD): 15.49 LB/HR

$$0.082 \text{ gr./DSCF @ } 12\% \text{ CO}_2$$

MET<sub>MOD</sub> 5 - PARTICULATE EMISSION CONCENTRATION RESULTS  
AM TEST, INC. - AIR QUALITY DEPARTMENT

10

FILE NAME: LKSD\_R2 LAB #: 92152  
CLIENT: LAKESTE INDUSTRIES START TIME: 1055 O'CLOCK  
LOCATION: LACEY, WASHINGTON STOP TIME: 1204 O'CLOCK  
SAMPLE SITE: BAGHOUSE OUTLET SAMPLE TIME: 60.0 MINUTES  
SAMPLE DATE: JULY 18, 1985 PRODUCTION RATE: 250 TONS/HR  
RUN #: 2-METHOD 5 MIXED REFUSE  
OPERATORS: JIM GUENTHOER  
CONTACT: BOB SMITH  
CONTACT: HAROLD NICKEL

FRONTHALF PARTICULATE MASS LOADING

FILTER NUMBER: #125-009  
TARE WEIGHT OF FILTER IN GRAMS: 0.6103  
FINAL WEIGHT OF FILTER IN GRAMS: 0.7031  
NET WEIGHT OF PARTIC. MATTER IN GRAMS: 0.0928

BEAKER NUMBER: #85-355  
TARE WEIGHT OF BEAKER IN GRAMS: 65.0917  
FINAL WEIGHT OF BEAKER IN GRAMS: 65.1744  
NET WEIGHT OF PARTIC. MATTER IN GRAMS: 0.0827  
VOLUME OF ACETONE IN MILLILITERS: 115.0

FINAL WT. INIT. WT. NET WT.  
OF H2O G. OF H2O G. OF H2O G.  
  
713.4 600.5 112.9  
609.1 591.1 18.0  
477.7 475.3 2.4  
849.1 836.7 12.4  
TOTAL H2O GAIN: 145.7  
TOTAL VOLUME (SCF) 6.86  
PERCENT MOISTURE: 12.89  
BWS: 0.1289  
PITOT Cp: 0.845  
NOZZLE DIA INCHES: 0.183  
NOZZLE AREA FT^2: 0.0002  
STACK DIA. INCHES: 31"X37"  
STACK AREA FT^2: 7.965  
METER TEMP. DEG F: 81.0  
BAROM. PRES. "HG: 29.96  
STATIC PRES. "H2O: 3.00  
STACK PRES. "HG: 30.18  
ORIFICE PRES "H2O: 1.11  
METER PRES. "HG: 30.26

TARE WEIGHT OF ACETONE IN GRAMS: 66.8075  
FINAL WEIGHT OF ACETONE IN GRAMS: 66.8077  
VOLUME OF ACETONE IN MILLILITERS: 100.0  
NET CONTRIBUTION OF ACETONE IN MG/ML: 0.0020

TOTAL FRONTHALF PARTIC. MATTER IN GRAMS: 0.1753

INIT. METER VOLUME 293.576  
FINAL METER VOLUME 340.420  
VOLUME SAMPLED: 46.844  
STD VOLUME (DSCF): 46.363  
STD VOLUME (DSCM): 1.638  
Y FACTOR: 1.010

AVERAGE % CO2: 2.3  
AVERAGE % O2: 17.9  
AVERAGE % CO: 0.0  
STACK GAS MW. DRY: 29.09  
STACK GAS MW. WET: 27.66

$$C_p = \frac{1.058 \times 12.}{2.3} = 0.30$$

\*\*\*\*\*  
SAMPLE VELOCITY TEMPERATURE SAMPLE VELOCITY TEMPERATURE  
POINT " OF H2O DEGREES F. POINT " OF H2O DEGREES F.

|   |      |     |   |      |     |
|---|------|-----|---|------|-----|
| 1 | 1.50 | 142 | 1 | 1.20 | 153 |
| 2 | 2.00 | 143 | 2 | 2.00 | 155 |
| 3 | 2.10 | 145 | 3 | 2.90 | 156 |
| 4 | 2.50 | 147 | 4 | 3.20 | 157 |
| 5 | 3.00 | 148 | 5 | 3.50 | 157 |
| 6 | 3.00 | 150 | 6 | 3.50 | 157 |
| 1 | 1.30 | 150 | 1 | 1.10 | 156 |
| 2 | 1.60 | 152 | 2 | 1.60 | 157 |
| 3 | 2.00 | 153 | 3 | 2.80 | 159 |
| 4 | 2.20 | 153 | 4 | 3.30 | 159 |
| 5 | 3.00 | 154 | 5 | 3.50 | 159 |
| 6 | 3.00 | 154 | 6 | 3.50 | 159 |

\*\*\*\*\*  
PERCENT ISOKINETICS: 97 %  
STACK TEMPERATURE: 153.1 DEG. F. 613.1 DEG. R.  
AVERAGE VELOCITY HEAD: 2.40 " OF H2O  
STACK GAS VELOCITY: 94.02 AFT/SEC 95.94 FT/SEC.  
STACK GAS AIR FLOW: 44934.23 ACF/M 34694.5 DSCF/M  
PARTICULATE CONCENTRATION: 0.058 GR/DSCF  
POLLUTANT MASS RATE (CONCENTRATION METHOD): 17.35 LB/HR

METHOD 5 - PARTICULATE EMISSION CONCENTRATION RESULTS  
AM TEST, INC. - AIR QUALITY DEPARTMENT

11

FILE NAME: LKSD\_R3 LAB #: 92153 FRONTHALF PARTICULATE MASS LOADING  
CLIENT: LAKESTIDE INDUSTRIES START TIME: 1330 O'CLOCK  
LOCATION: LACEY, WASHINGTON STOP TIME: 1430 O'CLOCK  
SAMPLE SITE: BAGHOUSE OUTLET SAMPLE TIME: 45.0 MINUTES  
SAMPLE DATE: JULY 18, 1985 PRODUCTION RATE: 250 TONS/HR  
RUN #: 3-METHOD 5 MIXED REFUSE  
OPERATORS: JIM GUENTHOER  
CONTACT: BOB SMITH  
CONTACT: HAROLD NICKEL

FILTER NUMBER: #125-010  
TARE WEIGHT OF FILTER IN GRAMS: 0.6084  
FINAL WEIGHT OF FILTER IN GRAMS: 0.6632  
NET WEIGHT OF PARTIC. MATTER IN GRAMS: 0.0548

BEAKER NUMBER: #85-356  
TARE WEIGHT OF BEAKER IN GRAMS: 65.6246  
FINAL WEIGHT OF BEAKER IN GRAMS: 65.6961  
NET WEIGHT OF PARTIC. MATTER IN GRAMS: 0.0715  
VOLUME OF ACETONE IN MILLILITERS: 105.0

FINAL WT. INIT. WT. NET WT. PITOT Cp: 0.845  
OF H2O G. OF H2O G. OF H2O G. NOZZLE DIA INCHES: 0.183  
NOZZLE AREA FT^2: 0.0002  
669.3 575.0 94.3 STACK DIA. INCHES: 31"X37"  
592.2 577.6 14.6 STACK AREA FT^2: 7.965  
482.3 480.9 1.4 METER TEMP. DEG F: 89.1  
754.4 745.6 8.8 BAROM. PRES. "HG: 29.92  
TOTAL H2O GAIN: 119.1 STATIC PRES. "H2O: 3.00  
TOTAL VOLUME (SCF) 5.61 STACK PRES. "HG: 30.14  
PERCENT MOISTURE: 13.83 ORIFICE PRES "H2O: 1.14  
Bws: 0.1383 METER PRES. "HG: 30.22

TARE WEIGHT OF ACETONE IN GRAMS: 66.8075  
FINAL WEIGHT OF ACETONE IN GRAMS: 66.8077  
VOLUME OF ACETONE IN MILLILITERS: 100.0  
NET CONTRIBUTION OF ACETONE IN MG/ML: 0.0020

TOTAL FRONTHALF PARTIC. MATTER IN GRAMS: 0.1261

INIT. METER VOLUME 340.688  
FINAL METER VOLUME 376.571 AVERAGE % CO2: 2.3  
VOLUME SAMPLED: 35.883 AVERAGE % O2: 17.9  
STD VOLUME (DSCF): 34.946 AVERAGE % CO: 0.0  
STD VOLUME (DSCM): 1.235 STACK GAS MW, DRY: 29.09  
Y FACTOR: 1.010 STACK GAS MW, WET: 27.55

\*\*\*\*\*  
SAMPLE VELOCITY TEMPERATURE SAMPLE VELOCITY TEMPERATURE  
POINT " OF H2O DEGREES F. POINT " OF H2O DEGREES F.

|   |      |     |   |      |     |
|---|------|-----|---|------|-----|
| 1 | 1.30 | 146 | 1 | 1.20 | 163 |
| 2 | 1.90 | 150 | 2 | 1.50 | 162 |
| 3 | 2.90 | 152 | 3 | 1.90 | 164 |
| 4 | 3.20 | 154 | 4 | 2.20 | 166 |
| 5 | 3.50 | 156 | 5 | 3.00 | 164 |
| 6 | 3.50 | 157 | 6 | 3.00 | 165 |
| 1 | 1.20 | 161 | 1 |      |     |
| 2 | 1.80 | 162 | 2 |      |     |
| 3 | 2.90 | 163 | 3 |      |     |
| 4 | 3.00 | 163 | 4 |      |     |
| 5 | 3.70 | 163 | 5 |      |     |
| 6 | 3.70 | 162 | 6 |      |     |

\*\*\*\*\*  
PERCENT ISOKINETICS: 98 %  
STACK TEMPERATURE: 159.6 DEG. F. 619.6 DEG. R.  
AVERAGE VELOCITY HEAD: 2.44 " OF H2O  
STACK GAS VELOCITY: 95.28 AFT/SEC 97.47 FT/SEC.  
STACK GAS AIR FLOW: 45537.04 ACF/M 34459.3 DSCF/M  
PARTICULATE CONCENTRATION: 0.056 GR/DSCF  
POLLUTANT MASS RATE (CONCENTRATION METHOD): 16.44 LB/HR

## **APPENDIX**

## METHOD 1 - LOCATION OF TRAVERSE POINTS

### Circular Stacks




Figure 1-3. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points indicated.

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

[Percent of stack diameter from inside wall to traverse point]

| Traverse point number on a diameter | Number of traverse points on a diameter— |      |      |      |      |      |      |      |      |      |      |      |
|-------------------------------------|------------------------------------------|------|------|------|------|------|------|------|------|------|------|------|
|                                     | 2                                        | 4    | 6    | 8    | 10   | 12   | 14   | 16   | 18   | 20   | 22   | 24   |
| 1                                   | 14.6                                     | 6.7  | 4.4  | 3.2  | 2.6  | 2.1  | 1.8  | 1.6  | 1.4  | 1.3  | 1.1  | 1.1  |
| 2                                   | 85.4                                     | 25.0 | 14.6 | 10.5 | 8.2  | 6.7  | 5.7  | 4.9  | 4.4  | 3.9  | 3.5  | 3.2  |
| 3                                   |                                          | 75.0 | 29.6 | 19.4 | 14.6 | 11.8 | 9.9  | 8.5  | 7.5  | 6.7  | 6.0  | 5.5  |
| 4                                   |                                          | 93.3 | 70.4 | 32.3 | 22.6 | 17.7 | 14.6 | 12.5 | 10.9 | 9.7  | 8.7  | 7.9  |
| 5                                   |                                          |      | 85.4 | 67.7 | 34.2 | 25.0 | 20.1 | 16.9 | 14.6 | 12.9 | 11.6 | 10.5 |
| 6                                   |                                          |      | 95.6 | 80.6 | 65.8 | 35.6 | 26.9 | 22.0 | 18.8 | 16.5 | 14.6 | 13.2 |
| 7                                   |                                          |      |      | 89.5 | 77.4 | 64.4 | 36.6 | 28.3 | 23.6 | 20.4 | 18.0 | 16.1 |
| 8                                   |                                          |      |      | 96.8 | 85.4 | 75.0 | 63.4 | 37.5 | 29.6 | 25.0 | 21.8 | 19.4 |
| 9                                   |                                          |      |      |      | 91.8 | 82.3 | 73.1 | 62.5 | 38.2 | 30.6 | 26.2 | 23.0 |
| 10                                  |                                          |      |      |      | 97.4 | 88.2 | 79.9 | 71.7 | 61.8 | 38.8 | 31.5 | 27.2 |
| 11                                  |                                          |      |      |      |      | 93.3 | 85.4 | 78.0 | 70.4 | 61.2 | 39.3 | 32.1 |
| 12                                  |                                          |      |      |      |      | 97.9 | 90.1 | 83.1 | 76.4 | 69.4 | 60.7 | 39.8 |
| 13                                  |                                          |      |      |      |      |      | 94.3 | 87.5 | 81.2 | 75.0 | 68.5 | 60.2 |
| 14                                  |                                          |      |      |      |      |      | 98.2 | 91.5 | 85.4 | 79.6 | 73.8 | 67.7 |
| 15                                  |                                          |      |      |      |      |      |      | 95.1 | 89.1 | 83.5 | 78.2 | 72.8 |
| 16                                  |                                          |      |      |      |      |      |      | 98.4 | 92.5 | 87.1 | 82.0 | 77.0 |
| 17                                  |                                          |      |      |      |      |      |      |      | 95.6 | 90.3 | 85.4 | 80.6 |
| 18                                  |                                          |      |      |      |      |      |      |      | 98.6 | 93.3 | 88.4 | 83.9 |
| 19                                  |                                          |      |      |      |      |      |      |      |      | 96.1 | 91.3 | 86.8 |
| 20                                  |                                          |      |      |      |      |      |      |      |      | 98.7 | 94.0 | 89.5 |
| 21                                  |                                          |      |      |      |      |      |      |      |      |      | 96.5 | 92.1 |
| 22                                  |                                          |      |      |      |      |      |      |      |      |      | 98.9 | 94.5 |
| 23                                  |                                          |      |      |      |      |      |      |      |      |      |      | 96.8 |
| 24                                  |                                          |      |      |      |      |      |      |      |      |      |      | 98.9 |

### Rectangular Stacks

For a rectangular cross section, an equivalent diameter ( $D_e$ ) shall be calculated from the following equation, to determine the upstream and downstream distances:

$$D_e = \frac{2LW}{(L+W)}$$

where  $L$ =length and  $W$ =width.






Figure 1-4. Example showing rectangular stack cross section divided into 12 equal areas, with a traverse point at centroid of each area.

## METHOD 1 - MINIMUM NUMBER OF TRAVERSE POINTS



## METHOD 2 - STACK GAS VELOCITY AND VOLUMETRIC FLOW CALCULATIONS

### Nomenclature.

$A$  = Cross-sectional area of stack,  $m^2$  ( $ft^2$ ).  
 $B_{ws}$  = Water vapor in the gas stream (from Method 5 or Reference Method 4), proportion by volume.  
 $C_p$  = Pitot tube coefficient, dimensionless.  
 $K_p$  = Pitot tube constant.

$$34.97 \frac{m}{sec} \left[ \frac{(g/g\text{-mole})(mm\ Hg)}{(^{\circ}K)(mm\ H_2O)} \right]^{1/2}$$

for the metric system and

$$85.49 \frac{ft}{sec} \left[ \frac{(lb/lb\text{-mole})(in.\ Hg)}{(^{\circ}R)(in.\ H_2O)} \right]^{1/2}$$

for the English system.

$M_d$  = Molecular weight of stack gas, dry basis (see Section 3.6)  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).  
 $M_s$  = Molecular weight of stack gas, wet basis,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).  
 $= M_d(1 - B_{ws}) + 18.0 B_{ws}$

Equation 2-5

$P_{bar}$  = Barometric pressure at measurement site,  $mm\ Hg$  ( $in.\ Hg$ ).

$P_g$  = Stack static pressure,  $mm\ Hg$  ( $in.\ Hg$ ).

$P_t$  = Absolute stack gas pressure,  $mm\ Hg$  ( $in.\ Hg$ ).

$= P_{bar} + P_g$

Equation 2-6

$P_{std}$  = Standard absolute pressure,  $760\ mm\ Hg$  ( $29.92\ in.\ Hg$ ).

$Q_{sd}$  = Dry volumetric stack gas flow rate corrected to standard conditions,  $dscm/hr$  ( $dscf/hr$ ).

$t_s$  = Stack temperature,  $^{\circ}C$  ( $^{\circ}F$ ).

$T_s$  = Absolute stack temperature,  $^{\circ}K$ , ( $^{\circ}R$ ).

$= 273 + t_s$  for metric

Equation 2-7

$= 460 + t_s$  for English

Equation 2-8

$T_{std}$  = Standard absolute temperature,  $293\ ^{\circ}K$  ( $528\ ^{\circ}R$ ).

$v_s$  = Average stack gas velocity,  $m/sec$  ( $ft/sec$ ).

$\Delta p$  = Velocity head of stack gas,  $mm\ H_2O$  ( $in.\ H_2O$ ).

$3,600$  = Conversion factor,  $sec/hr$ .

$18.0$  = Molecular weight of water,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).

$5.2$  = Average stack gas velocity.

$$v_s = K_p C_p (\sqrt{\Delta p})^{0.5} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

Equation 2-9

5.3 Average stack gas dry volumetric flow rate.

$$Q_{sd} = 3,600 (1 - B_{ws}) v_s A \left( \frac{T_{std}}{T_{s(avg)}} \right) \left( \frac{P_s}{P_{std}} \right)$$

Equation 2-10

## METHOD 3 - MOLECULAR WEIGHT AND EXCESS AIR CALCULATIONS

### Nomenclature.

$M_d$  = Dry molecular weight,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).

$\%EA$  = Percent excess air.

$\%CO_2$  = Percent  $CO_2$  by volume (dry basis).

$\%O_2$  = Percent  $O_2$  by volume (dry basis).

$\%CO$  = Percent  $CO$  by volume (dry basis).

$\%N_2$  = Percent  $N_2$  by volume (dry basis).

$0.264$  = Ratio of  $O_2$  to  $N_2$  in air,  $v/v$ .

$0.280$  = Molecular weight of  $N_2$  or  $CO$ , divided by  $100$ .

$0.320$  = Molecular weight of  $O_2$ , divided by  $100$ .

$0.440$  = Molecular weight of  $CO$ , divided by  $100$ .

6.2 Percent Excess Air. Calculate the percent excess air (if applicable), by substituting the appropriate values of percent  $O_2$ ,  $CO$ , and  $N_2$  (obtained from Section 4.1.3 or 4.2.4) into Equation 3-1.

$$\%EA = \left[ \frac{\%CO_2 - 0.5\%CO}{0.264\%N_2 + (\%CO_2 - 0.5\%CO)} \right] 100$$

Equation 3-1

NOTE: The equation above assumes that ambient air is used as the source of  $O_2$ , and that the fuel does not contain appreciable amounts of  $N_2$  (as do coke oven or blast furnace gases). For those cases when appreciable amounts of  $N_2$  are present (coal, oil, and natural gas do not contain appreciable amounts of  $N_2$ ) or when oxygen enrichment is used, alternate methods, subject to approval of the Administrator, are required.

6.3 Dry Molecular Weight. Use Equation 3-2 to calculate the dry molecular weight of the stack gas

$$M_d = 0.440(\%CO_2) + 0.320(\%O_2) + 0.280(\%N_2 + \%CO)$$

Equation 3-2

## METHOD 4 - STACK GAS MOISTURE CALCULATIONS

### Nomenclature.

- $B_w$  = Proportion of water vapor, by volume, in the gas stream.
- $M_w$  = Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).
- $P_m$  = Absolute pressure (for this method, same as barometric pressure) at the dry gas meter, mm Hg (in. Hg).
- $P_{std}$  = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).
- $R$  = Ideal gas constant, 0.06236 (mm Hg) (m<sup>3</sup>)/(g-mole) (°K) for metric units and 21.85 (in. Hg) (ft<sup>3</sup>)/(lb-mole) (°R) for English units.
- $T_m$  = Absolute temperature at meter, °K (°R).
- $T_{std}$  = Standard absolute temperature, 293° K (528°R).
- $V_u$  = Dry gas volume measured by dry gas meter, dcm (dcf).
- $\Delta V_m$  = Incremental dry gas volume measured by dry gas meter at each traverse point, dcm (dcf).
- $V_{m(std)}$  = Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf).
- $V_{w(std)}$  = Volume of water vapor condensed corrected to standard conditions, scm (scf).
- $V_{wsg(std)}$  = Volume of water vapor collected in silica gel corrected to standard conditions, scm (scf).
- $V_f$  = Final volume of condenser water, ml.
- $V_i$  = Initial volume, if any, of condenser water, ml.
- $W_f$  = Final weight of silica gel or silica gel plus impinger, g.
- $W_i$  = Initial weight of silica gel or silica gel plus impinger, g.
- $Y$  = Dry gas meter calibration factor.
- $\rho_w$  = Density of water, 0.9982 g/ml (0.002201 lb/ml).
- 2.3.2 Volume of water vapor condensed.

$$V_{w(std)} = \frac{(V_f - V_i) \rho_w R T_{std}}{P_{std} M_w} = K_1 (V_f - V_i)$$

Equation 4-1

where:

$$K_1 = 0.001333 \text{ m}^3/\text{ml for metric units}$$

$$= 0.04707 \text{ ft}^3/\text{ml for English units}$$

2.3.3 Volume of water vapor collected in silica gel.

$$V_{wsg(std)} = \frac{(W_f - W_i) R T_{std}}{P_{std} M_w} = K_2 (W_f - W_i)$$

Equation 4-2

where:

$$K_2 = 0.001335 \text{ m}^3/\text{g for metric units}$$

$$= 0.04715 \text{ ft}^3/\text{g for English units}$$

2.3.4 Sample gas volume.

$$V_m(std) = V_m Y \frac{(P_m)(T_{std})}{(P_{std})(T_m)} = K_3 Y \frac{V_m P_m}{T_m}$$

Equation 4-3

where:

$$K_3 = 0.3858 \text{ } ^\circ\text{K}/\text{mm Hg for metric units}$$

$$= 17.64 \text{ } ^\circ\text{R}/\text{in. Hg for English units}$$

NOTE: If the post-test lead rate (Section 2.2.6) exceeds the allowable rate, correct the value of  $V_m$  in Equation 4-3, as described in Section 6.3 of Method 5.

2.3.5 Moisture Content.

$$B_w = \frac{V_{wc(std)} + V_{wsg(std)}}{V_{wc(std)} + V_{wsg(std)} + V_m(std)}$$

Equation 4-4

NOTE: In saturated or moisture droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one using a value based upon the saturated conditions (see Section 1.2), and another based upon the results of the impinger analysis. The lower of these two values of  $B_w$  shall be considered correct.

## METHOD 5 - PARTICULATE EMISSION CONCENTRATION CALCULATIONS - (1)

## Nomenclature

$A_n$  = Cross-sectional area of nozzle,  $m^2$  ( $ft^2$ ).  
 $B_{wv}$  = Water vapor in the gas stream, proportion by volume.  
 $C_o$  = Acetone blank residue concentration,  $mg/g$ .  
 $c$  = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions,  $g/dscm$  ( $g/dscf$ ).  
 $I$  = Percent of isokinetic sampling.  
 $L_o$  = Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to  $0.0057 m^3/min$  ( $0.02 cfm$ ) or 4 percent of the average sampling rate, whichever is less.  
 $L_i$  = Individual leakage rate observed during the leak check conducted prior to the " $i^{th}$ " component change ( $i=1, 2, 3, \dots, n$ ),  $m^3/min$  ( $cfm$ ).  
 $L_p$  = Leakage rate observed during the post-test leak check,  $m^3/min$  ( $cfm$ ).  
 $m_n$  = Total amount of particulate matter collected,  $mg$ .  
 $M_w$  = Molecular weight of water,  $18.0 g/g\text{-mole}$  ( $18.0 lb/lb\text{-mole}$ ).  
 $m_o$  = Mass of residue of acetone after evaporation,  $mg$ .  
 $P_{bs}$  = Barometric pressure at the sampling site,  $mm\text{ Hg}$  ( $in. Hg$ ).  
 $P_s$  = Absolute stack gas pressure,  $mm\text{ Hg}$  ( $in. Hg$ ).  
 $P_{std}$  = Standard absolute pressure,  $760 mm\text{ Hg}$  ( $29.92 in. Hg$ ).  
 $R$  = Ideal gas constant,  $0.06236 mm\text{ Hg}\cdot m^3 / ^\circ K\cdot g\text{-mole}$  ( $21.85 in. Hg\cdot ft^3 / ^\circ R\cdot lb\text{-mole}$ ).  
 $T_m$  = Absolute average dry gas meter temperature (see Figure 5-2),  $^\circ K$  ( $^\circ R$ ).  
 $T_s$  = Absolute average stack gas temperature (see Figure 5-2),  $^\circ K$  ( $^\circ R$ ).  
 $T_{std}$  = Standard absolute temperature,  $293^\circ K$  ( $528^\circ R$ ).  
 $V_o$  = Volume of acetone blank,  $ml$ .  
 $V_{wv}$  = Volume of acetone used in wash,  $ml$ .  
 $V_{lc}$  = Total volume of liquid collected in impingers and silica gel (see Figure 5-3),  $ml$ .  
 $V_m$  = Volume of gas sample as measured by dry gas meter,  $dcm$  ( $dscf$ ).  
 $V_{m(Std)}$  = Volume of gas sample measured by the dry gas meter, corrected to standard conditions,  $dscm$  ( $dscf$ ).  
 $V_{wv(Std)}$  = Volume of water vapor in the gas sample, corrected to standard conditions,  $scm$  ( $scf$ ).  
 $v$  = Stack gas velocity, calculated by Method 2, Equation 2-9, using data obtained from Method 5,  $m/sec$  ( $ft/sec$ ).  
 $W_o$  = Weight of residue in acetone wash,  $mg$ .  
 $Y$  = Dry gas meter calibration factor.  
 $\Delta H$  = Average pressure differential across the orifice meter (see Figure 5-2),  $mm\text{ H}_2\text{O}$  ( $in. H_2O$ ).  
 $\rho_o$  = Density of acetone,  $mg/ml$  (see label on bottle).

$\rho_w$  = Density of water,  $0.9982 g/ml$  ( $0.002201 lb/ml$ ).

$\theta$  = Total sampling time,  $min$ .

$\theta_1$  = Sampling time interval, from the beginning of a run until the first component change,  $min$ .

$\theta_i$  = Sampling time interval, between two successive component changes, beginning with the interval between the first and second changes,  $min$ .

$\theta_n$  = Sampling time interval, from the final ( $n^{th}$ ) component change until the end of the sampling run,  $min$ .

$13.6$  = Specific gravity of mercury.

$60$  =  $Sec/min$ .

$100$  = Conversion to percent.

6.2 Average dry gas meter temperature and average orifice pressure drop. See data sheet (Figure 5-2).

6.3 Dry Gas Volume. Correct the sample volume measured by the dry gas meter to standard conditions ( $20^\circ C$ ,  $760 mm\text{ Hg}$  or  $68^\circ F$ ,  $29.92 in. Hg$ ) by using Equation 5-1.

$$\begin{aligned}
 V_{m(Std)} &= V_m Y \left( \frac{T_{std}}{T_m} \right) \left[ \frac{P_{bs} + \frac{\Delta H}{13.6}}{P_{std}} \right] \\
 &= K_1 V_m Y \frac{P_{bs} + (\Delta H/13.6)}{T_m}
 \end{aligned}$$

Equation 5-1

where:

$K_1 = 0.3858 ^\circ K/mm\text{ Hg}$  for metric units  
 $= 17.64 ^\circ R/in. Hg$  for English units

NOTE: Equation 5-1 can be used as written unless the leakage rate observed during any of the mandatory leak checks (i.e., the post-test leak check or leak checks conducted prior to component changes) exceeds  $L_o$ . If  $L_p$  or  $L_i$  exceeds  $L_o$ , Equation 5-1 must be modified as follows:

(a) Case I. No component changes made during sampling run. In this case, replace  $V_m$  in Equation 5-1 with the expression:

$$V_m - (L_p - L_o)\theta$$

(b) Case II. One or more component changes made during the sampling run. In this case, replace  $V_m$  in Equation 5-1 by the expression:

$$\begin{aligned}
 &\left[ V_m - (L_i - L_o)\theta_i \right. \\
 &\quad \left. - \sum_{i=2}^n (L_i - L_o)\theta_i - (L_p - L_o)\theta_n \right]
 \end{aligned}$$

## METHOD 5 - PARTICULATE EMISSION CONCENTRATION CALCULATIONS - (2)

and substitute only for those leakage rates ( $L_s$  or  $L_p$ ) which exceed  $L_a$ .

6.4 Volume of water vapor.

$$V_{w(sat)} = V_{1c} \left( \frac{\rho_w}{M_w} \right) \left( \frac{RT_{sat}}{P_{sat}} \right) = K_2 V_{1c}$$

Equation 5-2

where:

$K_2 = 0.001333 \text{ m}^3/\text{ml}$  for metric units  
 $= 0.04707 \text{ ft}^3/\text{ml}$  for English units.

6.5 Moisture Content.

$$B_w = \frac{V_{w(sat)}}{V_{m(sat)} + V_{w(sat)}}$$

Equation 5-3

NOTE: In saturated or water droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one from the impinger analysis (Equation 5-3), and a second from the assumption of saturated conditions. The lower of the two values of  $B_w$  shall be considered correct. The procedure for determining the moisture content based upon assumption of saturated conditions is given in the Note of Section 1.2 of Method 4. For the purposes of this method, the average stack gas temperature from Figure 5-2 may be used to make this determination, provided that the accuracy of the in-stack temperature sensor is  $\pm 1^\circ \text{C}$  ( $2^\circ \text{F}$ ).

6.6 Acetone Blank Concentration.

$$C_a = \frac{m_a}{V_a \rho_a}$$

Equation 5-4

6.7 Acetone Wash Blank.

$$W_a = C_a V_{aw} \rho_a$$

Equation 5-5

6.8 Total Particulate Weight. Determine the total particulate catch from the sum of the weights obtained from containers 1 and 2 less the acetone blank (see Figure 5-3).

NOTE: Refer to Section 4.1.5 to assist in calculation of results involving two or more filter assemblies or two or more sampling trains.

6.9 Particulate Concentration.

$$c_p = (0.001 \text{ g/mg}) (m_p / V_{m(sat)})$$

Equation 5-6

### 6.10 Conversion Factors:

| From             | To                | Multiply by           |
|------------------|-------------------|-----------------------|
| scf              | m <sup>3</sup>    | 0.02832               |
| g/h <sup>3</sup> | gr/h <sup>3</sup> | 15.43                 |
| g/h <sup>3</sup> | lb/h <sup>3</sup> | $2.205 \cdot 10^{-3}$ |
| g/h <sup>3</sup> | g/m <sup>3</sup>  | 35.31                 |

6.11 Isokinetic Variation.

6.11.1 Calculation From Raw Data.

$$I = \frac{100 T_s [K_1 V_{1c} + (V_{m(sat)} T_m) (P_{bar} + \Delta H/13.6)]}{60 \theta v_s P_s A_n}$$

Equation 5-7

where:

$K_1 = 0.003454 \text{ mm Hg} \cdot \text{m}^3/\text{ml} \cdot \text{K}$  for metric units.

$= 0.002869 \cdot \text{in. Hg} \cdot \text{ft}^3/\text{ml} \cdot \text{R}$  for English units.

6.11.2 Calculation From Intermediate Values.

$$I = \frac{T_s V_{m(sat)} P_{sat} 100}{T_{sat} v_s \theta A_n P_s 60 (1 - B_{ws})}$$

$$= K_1 \frac{T_s V_{m(sat)}}{P_s V_s A_n \theta (1 - B_{ws})}$$

Equation 5-8

where:

$K_1 = 4.320$  for metric units  
 $= 0.09450$  for English units.

6.12 Acceptable Results. If 90 percent  $I < 110$  percent, the results are acceptable. If the results are low in comparison to the standard and  $I$  is beyond the acceptable range, or, if  $I$  is less than 90 percent, the Administrator may opt to accept the results.

Client: Lakeside IndustriesRun #:     Date: 7-18-81Particulate concentration

$$V_m = 17.647 * \underline{42.392} * \underline{1.010} * (\underline{29.96} + (\underline{0.98}/13.6)) / \underline{532} \quad \text{Equation 5-1}$$

$$V_m = \underline{42.652} \quad \text{dscf}$$

$$W_a = m_a * v_{aw} / v_a$$

Substitution of Equation 5-4 into 5-5

$$W_a = \underline{.2} * \underline{110} / \underline{100}$$

$$W_a = \underline{.22} \quad \text{mg}$$

$$m_n = (\text{net weight filter catch}) + (\text{net weight "B" section}) - W_a + (\text{Backhalf})$$

$$m_n = \underline{155.1} \quad \text{mg} = \underline{71.4} + \underline{83.9} - \underline{.22} + \underline{NA}$$

$$c_s = [(0.001 \text{g/mg}) * (15.43 \text{gr/ft}) * \underline{155.1} / \underline{42.652}] \quad \text{Equation 5-6}$$

$$c_s = \underline{.056} \quad \text{gr/dscf or } \underline{NA} \quad \text{gr/dscf@12\% CO}_2 = c_s * 12\% / \underline{NA} \%$$

Moisture

$$V_w(\text{std}) = 0.04707 * \underline{131.7} \quad \text{ml or grams of water condensed} \quad \text{Equation 5-2}$$

$$V_w(\text{std}) = \underline{6.2} \quad \text{scf}$$

$$B_{ws} = (\underline{6.2}) / (\underline{6.2} + \underline{42.652}) \quad \text{Equation 5-3}$$

$$B_{ws} = \underline{.1269} \quad \% \text{H}_2\text{O} = \underline{12.69} \%$$

Molecular weight

$$M_d = 0.440(\underline{8.2}) + 0.320(\underline{10.3}) + 0.280(\underline{81.5}) \quad \text{Equation 3-2}$$

$$M_d = \underline{29.72} \quad \text{g/g-mole}$$

$$M_s = \underline{29.72} * (1 - \underline{.1269}) + 18.0 * \underline{.1269}$$

$$M_s = \underline{28.23} \quad \text{g/g-mole}$$

Stack gas velocity and volumetric flow rate

$$v_s = 85.49 * \underline{.845} * \underline{1.455} * \sqrt{\underline{617.6} / \underline{28.23} / \underline{30.18}} \quad \text{Equation 2-9}$$

$$v_s = \underline{89.52} \quad \text{ft/sec (std) or } \underline{88.63} \text{ afps} = 2.9 * \underline{1.455} * \underline{.845} * \sqrt{\underline{617.6}} \quad (\text{apx.})$$

$$Q_{sd} = 3600 * (1 - \underline{.1269}) * \underline{89.52} * \underline{7.965} * (\underline{528} / \underline{617.6}) * (\underline{30.18} / \underline{29.92}) \quad \text{Equation 2-10}$$

$$Q_{sd} = \underline{1932540} \quad \text{dscf/hr} / 60 \text{ min/hr}$$

$$Q_{sd} = \underline{32209} \quad \text{dscf/min or } \underline{42359} \text{ acfm} = \underline{88.63} \text{ afps} * \underline{7.965} \text{ sf} * \underline{60} \quad (\text{apx.})$$

Isokinetic variation

$$I = 0.09450 * \underline{42.652} * \underline{617.6} / (\underline{30.18} * \underline{89.52} * \underline{59.3} * \underline{.0001827} * (1 - \underline{.1269})) \quad \text{Equation 5-8}$$

$$I = \underline{97} \%$$

\* All of the above equations are from the 40CFR60 and assume English units.



**am test inc.**

4900 9TH AVENUE N.W., • SEATTLE, WASHINGTON 98107-3697 • 206/783-4700

19




Figure 1. EPA Method 5 particulate sampling train

1. Sampling nozzle
2. Sampling probe sheath
3. Heated sample probe liner
4. Cyclone assembly (proposed regulations do not require this cyclone)
5. Out of stack filter assembly
6. Heated filter compartment maintained  $120^{\circ}\text{C} \pm 14^{\circ}\text{C}$  ( $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$ )  
(or temperature specified in 40CFR subpart)
7. Impinger case
8. First impinger filled with  $\text{H}_2\text{O}$  (100 ml)
9. Greenburg-Smith (or modified Greenburg-Smith) impinger filled with  $\text{H}_2\text{O}$  (100 ml)
10. Third impinger—dry
11. Fourth impinger—filled with  $\text{H}_2\text{O}$  absorption media (200-300 gm)
12. Impinger exit gas thermometer
13. Check valve to prevent back pressure
14. Umbilical cord—vacuum line
15. Pressure gage
16. Coarse adjustment valve
17. Leak free pump
18. By-pass valve
19. Dry gas meter with inlet and outlet dry gas meter thermometer
20. Orifice meter with manometer
21. Type S pitot tube with manometer
22. Stack temperature sensor



# am test inc.

4900 9TH AVENUE N.W., • SEATTLE, WASHINGTON 98107-3697 • 206/783-4700

29

Lab # 92151

## TRAVERSE SAMPLING DATA

Page 1 of 1

Client Lakeside (Lacey)  
 Date 7-18-85  
 Sample Location baghouse  
airlet stack -  
 Operators JAG  
 Sample Box # 1  
 Run# 1

### SCHEMATIC TRAVERSE LAYOUT



Stack Diameter 31" x 37" (33.6")  
 Distance Upstream 15'  
 Distance Downstream 3'

Start Time 0749  
 Stop Time 0856  
 Barometric Pressure "Hg 29.96  
 Static Pres "H<sub>2</sub>O +3"  
 Production Rate 250 tph

### EQUIPMENT CHECKS

Initial/Final

Leak Rate Cfm 1.02/1.01  
 Leak Test Vac 24/15  
☒ Pitots, Pretest  
☒ Pitots, Posttest  
☒ Orsat Sampling System  
☒ Tedlar Bag  
☒ Thermocouple @ \_\_\_\_\_ °F

Filter # 125008 tare \_\_\_\_\_ mgs  
 Final Initial Net  
 Wt. Wt. Wt.  
 #1 Bubbler 679.1 - 577.4 =  
 #2 Impinger 592.4 - 573.3 =  
 #3 Bubbler 466.6 - 464.7 =  
 #4 Silica Gel 838.0 - 829.0 =

TOTAL WATER VOLUME \_\_\_\_\_

### NOMOGRAPH SETUP

% Moisture 15  
 Meter Temp. 90  
 Stack Temp. 150  
 ΔH@ .944 Y 1.01  
 Pitot# 3' Side# A  
 Cp .845  
 Nozzle Diameter 0.183  
 C Factor \_\_\_\_\_  
 Reference ΔP 3.5

| Sample Point | Elap Time Min. | Dry Gas Meter Reading Cu. Ft. | Pitot Reading (ΔP), In. H <sub>2</sub> O | Orifice Setting (ΔH), In H <sub>2</sub> O | Gas Meter Temp °F | Pump Vacuum In. Hg | Filter Box Temp °F | Imp. Exit Temp °F | Stack Temp °F | Opacity or Orsat Values |
|--------------|----------------|-------------------------------|------------------------------------------|-------------------------------------------|-------------------|--------------------|--------------------|-------------------|---------------|-------------------------|
| A 1          | 0              | 250.611                       | .75                                      | .33                                       | 65                | 1                  | 224                | 59                | 155           | 17.6/170                |
| 2            | 24             |                               | 1.35                                     | .60                                       | 66                | 1                  | 232                | 53                | 155           | 17.7/171                |
| 3            | 5              |                               | 2.0                                      | .88                                       | 68                | 2                  | 235                | 50                | 156           | 17.9/193                |
| 4            | 74             |                               | 2.8                                      | 1.24                                      | 69                | 3                  | 234                | 48                | 156           | 18.0/134                |
| 5            | 10             |                               | 3.0                                      | 1.31                                      | 71                | 3                  | 272                | 47                | 156           | 17.8/192                |
| 6            | 124            |                               | 3.0                                      | 1.31                                      | 73                | 3                  | 232                | 47                | 156           | 17.8/191                |
| B 1          | 15             |                               | .95                                      | .42                                       | 70                | 1                  | 277                | 54                | 156           | 17.4/163                |
| 2            | 174            |                               | 1.7                                      | .74                                       | 72                | 2                  | 242                | 51                | 156           | 17.5/160                |
| 3            | 20             |                               | 2.0                                      | .88                                       | 73                | 2                  | 245                | 50                | 158           | 17.5/186                |
| 4            | 224            |                               | 2.8                                      | 1.23                                      | 75                | 3                  | 247                | 49                | 158           | 17.7/194                |
| 5            | 25             |                               | 3.5                                      | 1.53                                      | 77                | 4                  | 248                | 48                | 158           | 17.7/197                |
| 6            | 274            |                               | 3.5                                      | 1.53                                      | 79                | 4                  | 249                | 49                | 156           | 18.1/192                |
| C 1          | 30             |                               | 1.0                                      | .45                                       | 75                | 1                  | 253                | 57                | 156           | 17.8/198                |
| 2            | 324            |                               | 1.3                                      | .58                                       | 75                | 1 1/2              | 248                | 54                | 159           | 17.6/196                |
| 3            | 35             |                               | 1.7                                      | .76                                       | 76                | 2                  | 252                | 53                | 159           | 17.8/194                |
| 4            | 374            |                               | 2.2                                      | .98                                       | 77                | 3                  | 252                | 53                | 159           | 17.8/180                |
| 5            | 40             |                               | 3.0                                      | 1.33                                      | 79                | 3 1/2              | 258                | 52                | 159           | 17.8/193                |
| 6            | 424            |                               | 3.5                                      | 1.55                                      | 80                | 4                  | 258                | 52                | 159           | 17.9/191                |
| D 1          | 45             |                               | 1.2                                      | .53                                       | 77                | 1                  | 266                | 59                | 159           | 17.8/159                |
| 2            | 474            |                               | 1.5                                      | .67                                       | 78                | 2                  | 267                | 55                | 160           | 17.6/153                |
| 3            | 50             |                               | 1.9                                      | .84                                       | 78                | 2                  | 264                | 54                | 161           | 17.6/133                |
| 4            | 524            |                               | 2.4                                      | 1.06                                      | 79                | 3                  | 262                | 55                | 158           | 17.7/142                |
| 5            | 55             |                               | 3.0                                      | 1.33                                      | 81                | 3 1/2              | 256                | 56                | 159           | 17.1                    |
| 6            | 574            |                               | 3.0                                      | 1.33                                      | 82                | 3 1/2              | 252                | 58                | 159           | 17.1                    |
| 59.3         |                | 293.003                       | 1.455                                    | .975                                      | 72                |                    |                    |                   |               | 17.7                    |



# am test inc.

30

4900 9TH AVENUE N.W., • SEATTLE, WASHINGTON 98107-3697 • 206/783-4700

Lab # 92152

## TRAVERSE SAMPLING DATA

Page 1 of 1

Client Lakeside (Lacey)  
 Date 7-18-85  
 Sample Location Dughome outlet stack  
 Operators JAG  
 Sample Box # 1  
 Run# 2

## EQUIPMENT CHECKS

Initial/Final

Leak Rate Cfm 2.01 / 2.01Leak Test Vac 15 / 17

Pitots, Pretest

Pitots, Posttest

Orsat Sampling System

Tedlar Bag

Thermocouple @ \_\_\_\_\_ °F

## SCHEMATIC TRAVERSE LAYOUT

Stack Diameter 31 x 37Distance Upstream 15'Distance Downstream 31Filter # 12509 tare \_\_\_\_\_ mgs

Final Initial Net

713.4 Wt. Wt. Wt.

#1 Bubbler 609.1 - 600.5 = \_\_\_\_\_#2 Impinger 609.1 - 591.1 = \_\_\_\_\_#3 Bubbler 477.7 - 475.7 = \_\_\_\_\_#4 Silica Gel 849.1 - 836.7 = \_\_\_\_\_

TOTAL WATER VOLUME \_\_\_\_\_

Start Time 1055Stop Time 1204

Barometric

Pressure "Hg 29.96Static Pres "H<sub>2</sub>O +3"

Production Rate \_\_\_\_\_

## NOMOGRAPH SETUP

% Moisture 15Meter Temp. 80Stack Temp. 150K<sub>ms</sub> .944 Y 1.01Pitot# 3 Side# ACp .845Nozzle Diameter .183

C Factor \_\_\_\_\_

Reference ΔP 35

| Sample Point | Elap Time Min. | Dry Gas Meter Reading Cu. Ft. | Pitot Reading (ΔP), In. H <sub>2</sub> O | Orifice Setting (ΔH), In H <sub>2</sub> O | Gas Meter Temp °F | Pump Vacuum In. Hg | Filter Box Temp °F | Imp. Exit Temp °F | Stack Temp °F | Opacity or Orsat Values |
|--------------|----------------|-------------------------------|------------------------------------------|-------------------------------------------|-------------------|--------------------|--------------------|-------------------|---------------|-------------------------|
| D 1          | 0              | 293.576                       | 1.5                                      | .69                                       | 76                | 46                 | 265                | 63                | 142           | 18.1/63                 |
| 2            | 24             |                               | 2.0                                      | .91                                       | 77                | 5                  | 260                | 55                | 143           | 18.0/62                 |
| 3            | 5              |                               | 2.1                                      | .95                                       | 78                | 6                  | 256                | 54                | 145           | 17.9/62                 |
| 4            | 7 1/2          |                               | 2.5                                      | 1.13                                      | 80                | 7                  | 255                | 54                | 147           | 17.9/62                 |
| 5            | 10             |                               | 3.0                                      | 1.36                                      | 81                | 8                  | 254                | 54                | 148           | 17.9/62                 |
| 6            | 12 1/2         |                               | 3.0                                      | 1.35                                      | 82                | 8                  | 255                | 54                | 150           | 18.0/63                 |
| C 1          | 15             |                               | 1.3                                      | .59                                       | 81                | 7                  | 249                | 62                | 150           | 17.8/62                 |
| 2            | 17 1/2         |                               | 1.6                                      | .72                                       | 82                | 5                  | 254                | 59                | 152           | 17.8/62                 |
| 3            | 20             |                               | 2.0                                      | .90                                       | 82                | 6                  | 254                | 59                | 153           | 17.9/62                 |
| 4            | 22 1/2         |                               | 2.2                                      | .99                                       | 83                | 7                  | 254                | 59                | 153           | 17.9/62                 |
| 5            | 25             |                               | 3.0                                      | 1.34                                      | 85                | 8                  | 255                | 58                | 154           | 18.1/62                 |
| 6            | 27 1/2         |                               | 3.0                                      | 1.34                                      | 86                | 8                  | 255                | 58                | 154           | 17.9/62                 |
| B 1          | 30             |                               | 4.2                                      | .54                                       | 83                | 4                  | 262                | 67                | 153           | 17.8/62                 |
| 2            | 32 1/2         |                               | 2.0                                      | .90                                       | 84                | 5 1/2              | 245                | 62                | 155           | 17.7/62                 |
| 3            | 35             |                               | 2.9                                      | 1.29                                      | 84                | 8                  | 264                | 61                | 156           | 17.8/62                 |
| 4            | 37 1/2         |                               | 3.2                                      | 1.43                                      | 85                | 8 1/2              | 263                | 61                | 157           | 17.9/62                 |
| 5            | 40             |                               | 3.5                                      | 1.56                                      | 87                | 9                  | 261                | 62                | 157           | 18.0/62                 |
| 6            | 42 1/2         |                               | 3.5                                      | 1.56                                      | 88                | 9                  | 261                | 62                | 157           | 18.0/62                 |
| A 1          | 45             |                               | 1.1                                      | .49                                       | 84                | 7                  | 262                | 67                | 156           | 17.9/62                 |
| 2            | 47 1/2         |                               | 1.6                                      | .71                                       | 84                | 5                  | 257                | 67                | 157           | 17.8/62                 |
| 3            | 50             |                               | 2.8                                      | 1.25                                      | 85                | 8                  | 252                | 67                | 159           | 18.0/62                 |
| 4            | 52 1/2         |                               | 3.3                                      | 1.47                                      | 86                | 9                  | 249                | 66                | 159           | 18.1/62                 |
| 5            | 55             |                               | 3.5                                      | 1.56                                      | 88                | 10                 | 239                | 65                | 159           | 17.9/62                 |
| 6            | 57 1/2         |                               | 3.5                                      | 1.56                                      | 89                | 10                 | 240                | 66                | 159           | 17.9/62                 |
| 60           |                | 340.420                       |                                          |                                           |                   |                    |                    |                   |               |                         |

1.11 81

17.9 125



# am test inc.

4900 9TH AVENUE N.W., • SEATTLE, WASHINGTON 98107-3697 • 206/783-4700

31

Lab# 92153

## TRAVERSE SAMPLING DATA

Page 1 of 1

Client Lapide (Lacy)  
 Date 7-18-85  
 Sample Location baghouse outlet stack  
 Operators DAK  
 Sample Box # 1  
 Run# 3

### EQUIPMENT CHECKS

Initial/Final

Leak Rate Cfm 4.01 / 4.01  
 Leak Test Vac 15 / 15  
☒ Pitots, Pretest  
☒ Pitots, Posttest  
☒ Orsat Sampling System  
☒ Tedlar Bag  
☒ Thermocouple @ \_\_\_\_\_ °F

### SCHEMATIC TRAVERSE LAYOUT

Stack Diameter 31" X 37"  
 Distance Upstream 15 ft  
 Distance Downstream 3 ft

Filter # 625010 tare \_\_\_\_\_ mgs  
 Final Initial Net  
 Wt. Wt. Wt.  
 #1 Bubbles 469.3 - 575.0 = \_\_\_\_\_  
 #2 Impinger 582.2 - 577.6 = \_\_\_\_\_  
 #3 Bubbles 482.3 - 480.9 = \_\_\_\_\_  
 #4 Silica Gel 754.4 - 745.6 = \_\_\_\_\_  
 TOTAL WATER VOLUME \_\_\_\_\_

Start Time 1338  
 Stop Time 1430  
 Barometric Pressure "Hg 29.92  
 Static Pres "H<sub>2</sub>O +3.0  
 Production Rate 250 tph

### NOMOGRAPH SETUP

% Moisture 15  
 Meter Temp. 90  
 Stack Temp. 155  
 Km<sup>2</sup> .944 y 1.01  
 ΔH<sub>e</sub> \_\_\_\_\_  
 Pitot# 3 Side# A  
 Cp .845  
 Nozzle Diameter .183  
 C Factor \_\_\_\_\_  
 Reference ΔP 3.5

| Sample Point | Elap Time Min. | Dry Gas Meter Reading Cu. Ft. | Pitot Reading (ΔP), In. H <sub>2</sub> O | Orifice Setting (ΔH), In H <sub>2</sub> O | Gas Meter Temp °F | Pump Vacuum In. Hg Guage | Filter Box Temp °F | Imp. Exit Temp °F | Stack Temp °F | Opacity or Orsat Values |
|--------------|----------------|-------------------------------|------------------------------------------|-------------------------------------------|-------------------|--------------------------|--------------------|-------------------|---------------|-------------------------|
| A 1          | 0              | 340.68                        | 1.3                                      | .55                                       | 84                | 2                        | 204                | 54                | 140           | 16.7/283                |
| 2            | 2h             |                               | 1.9                                      | .86                                       | 85                | 3                        | 234                | 47                | 150           | 17.1/229                |
| 3            | 5              |                               | 2.9                                      | 1.32                                      | 86                | 4                        | 240                | 45                | 152           | 18.0/257                |
| 4            | 7h             |                               | 3.2                                      | 1.45                                      | 88                | 4                        | 241                | 46                | 154           | 18.1/274                |
| 5            | 10             |                               | 3.5                                      | 1.59                                      | 90                | 4 1/2                    | 245                | 48                | 156           | 18.1/292                |
| 6            | 12h            |                               | 3.5                                      | 1.59                                      | 91                | 4 1/2                    | 246                | 50                | 157           | 18.1/267                |
| B 1          | 15             |                               | 1.2                                      | .54                                       | 90                | 2                        | 259                | 56                | 141           | 17.9/298                |
| 2            | 17h            |                               | 1.8                                      | .82                                       | 90                | 3                        | 264                | 53                | 162           | 17.9/297                |
| 3            | 20             |                               | 2.9                                      | 1.30                                      | 91                | 5                        | 264                | 53                | 163           | 18.0/293                |
| 4            | 24h            |                               | 3.0                                      | 1.35                                      | 93                | 5                        | 263                | 55                | 163           | 18.0/293                |
| 5            | 25             |                               | 3.7                                      | 1.66                                      | 95                | 7                        | 256                | 59                | 163           | 18.3/350                |
| 6            | 27h            |                               | 3.7                                      | 1.66                                      | 96                | 7                        | 255                | 58                | 162           | 18.1/337                |
| C 1          | 30             |                               | 1.2                                      | .54                                       | 92                | 2                        | 296                | 60                | 163           | 18.8/106                |
| 2            | 32h            |                               | 1.5                                      | .67                                       | 93                | 3                        | 247                | 60                | 162           | 17.7/126                |
| 3            | 35             |                               | 1.9                                      | .85                                       | 93                | 3                        | 245                | 58                | 164           | 17.9/118                |
| 4            | 37h            |                               | 2.2                                      | .99                                       | 94                | 4                        | 265                | 60                | 166           | 17.8/151                |
| 5            | 40             |                               | 3.0                                      | 1.35                                      | 95                | 5                        | 268                | 61                | 164           | 18.1/227                |
| 6            | 42h            |                               | 3.0                                      | 1.35                                      | 94                | 5                        | 265                | 61                | 165           | 18.2/251                |
| STOP         |                | 376.571                       |                                          |                                           |                   |                          |                    |                   |               |                         |

\* 45

1.135 89.1

17.9 26

L. 'eside  
LACEY - PLANT-79<sup>32</sup>

Source Test Observation Checklist  
Asphalt Batch Plants

Process

Asphalt Paving Plant Madson Lakeside (Lacey)  
Drum Mix Description 9' x 32'  
Madson NR 642  
Identification No. NR 642 5056008-72 Installed June 1985  
Process Rate 250 + Tons/hr Firing Rate 275 Gal/hr  
Type of Fuel Diesel Smoke Point optional  
Injection Location FRONT OF DEGR  
Asphalt Discharge Temp. 325 °F Gravel Moisture 4 %  
Fines In Gravel (<200 mesh) 6%  
Operation Personnel Freeman - oiler - Loader op.  
Asphalt Supplier U.S. Oil  
Density optional #/gal Flash Point optional °F

Class B-

Control Equipment

Description or Name Wag Baghouse  
Water Press N/A PSI Rate N/A Gal/min  
Water: Reused, Clean? N/A  
Venturi Press  $\Delta P$  = N/A Inch  
Static = N/A Inch  
Air Flow Method 5 test  
Saturated Stack



SOURCE TEST  
SUMMARY OF EMISSIONS TO ATMOSPHERE

Report No. 87-10  
Report Date 8-21-87  
Test Date 7-7-87

Name of plant Lakeside Industries  
Location of plant Lacey  
Person contacted Morris Johnston  
Type of operation Asphalt Plant  
Source tested Dryer Stack  
Requesting Agency Olympic Air Pollution Control Authority  
Purpose Measure Particulate Emissions  
Applicable Standard OAPCA Regulation 1

SUMMARY OF MEASUREMENTS

| Pollutant   | Measured Emission | Allowable Emission | Emission/Process Factor | Methods                   |
|-------------|-------------------|--------------------|-------------------------|---------------------------|
| Particulate | .009 gr/DSCF      | .04 gr/DSCF        |                         | Ecology*<br>Ecol Method 5 |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |
|             |                   |                    |                         |                           |

TEST ENGINEER

John Drabek *John Drabek*

FIELD PERSONNEL

John Drabek

Tom Harris

LAB ANALYSIS

Susan Davis

Test Witnessed by:

Gregory Conner (OAPCA)

I. Purpose

The purpose of the test was to measure particulate emissions from the dryer stack at the Lakeside Industries asphalt plant in Lacey. Results will be used by the Olympic Air Pollution Control Authority in determining compliance.

II. Description of Unit Tested

This plant is located off Hagum Bay Road and is visible from the I-5 freeway in Lacey. The hot mix asphalt paving batch plant consisted of a rotary dryer, screening and classifying systems, weigh boxes for asphalt cement and aggregate, a pug mill mixer, and the necessary conveying equipment of bucket elevators and belt conveyors. The dryer was fired by diesel oil from U.S. Oil, Tacoma, and heated the aggregate to 325°F. The dried aggregate is conveyed by a bucket elevator to the screening equipment where it is classified and dumped into elevated storage bins. Selected amounts of the proper size aggregate are dropped from the storage bins to the weigh hopper. The weighed aggregate is then dropped into the mixer along with hot asphalt cement, forming a final class B mix of 5.0 percent asphalt and 5/8 inch minus aggregate. The batch is then dumped into waiting trucks for transportation to the paving site. Production was 260 tons per hour.

Drier emissions are controlled by a multiclone and a baghouse containing 1120 bags. Dust collection from secondary sources, that is, the elevator, vibrating screens, hot aggregate bins, weigh hopper and mixer are controlled by connection through branch ducting to the main exhaust system. The pressure drop across the pulse jet baghouse was 4 inches water gauge as measured by Ecology at the wall surface and baghouse temperature was 230°F. The pulse jet air pressure was 110 psi. Collected solids are recycled. Gases pass through a 250 amp, 900 rpm fan and then to the atmosphere through a rectangular stack.

### III. Test Procedure

Two Ecology Method 5 particulate samples were collected using a heated probe and filter as shown in Figure 1. A third sample could not be collected due to lack of plant operating time. A 64 minute 16 point traverse was made for each sample to representative points in the stack. An integrated bag sample was taken concurrently with particulate sampling and was subsequently analyzed for carbon dioxide and oxygen using an orsat analyzer according to Ecology Method 3. Moisture condensed in the impingers was used to determine the water vapor content.

### IV. Results

Results are shown on Page 4. The average measured particulate concentrations was .009 grains per dry standard cubic foot.

### V. Comments

Problems in the particulate control equipment were observed during an Ecology inspection in September, 1984. The problems and current status are listed below.

1. 1984: An oil water removal system was bypassed  
1987: A new commercial compressor system has been installed with an integral oil-water removal arrangement.
2. 1984: Moisture may have been condensing on the bags.  
1987: The baghouse temperature is monitored and was 230°F during testing.
3. 1984: Fugitive emissions were observed from the solids discharge pit hopper and elevator.  
1987: All solids discharged are recycled while the dryer is operating. Visible emissions were not observed from the secondary sources.

254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000

Test No. 87-10

### Gas Flow Data

### Sample Information

| Results | PARTICULATE | Front Half |
|---------|-------------|------------|
| 100     | 100         | 100        |
| 90      | 90          | 90         |
| 80      | 80          | 80         |
| 70      | 70          | 70         |
| 60      | 60          | 60         |
| 50      | 50          | 50         |
| 40      | 40          | 40         |
| 30      | 30          | 30         |
| 20      | 20          | 20         |
| 10      | 10          | 10         |
| 0       | 0           | 0          |

|                         |       |       |       |
|-------------------------|-------|-------|-------|
| Conc., Gr/SDCF          | 0.007 | 0.010 | 0.009 |
| Conc., Gr/SDCF @ 02     | 0.043 | 0.034 | 0.039 |
| Conc., Gr/SDCF @ 1% CO2 | 0.039 | 0.071 | 0.055 |
| Emission Rate, lb/Hr    | 2.1   | 2.7   | 2.4   |
| Emission Factor, lb/Ton | 0.008 | 0.010 | 0.009 |





FIGURE 1. PARTICULATE SAMPLING TRAIN



TEST NO. \_\_\_\_\_  
DATE 7-7-87

## METHOD 5— PARTICULATE SAMPLING WITH A HEATED FILTER WITH IMPINGER

PLANT Lakeside Industries  
SAMPLING LOCATION Lacey  
SAMPLE TYPE part.  
RUN NUMBER 1 OPERATOR J.D.  
AMBIENT TEMPERATURE \_\_\_\_\_  
BAROMETRIC PRESSURE 29.91  
STATIC PRESSURE \_\_\_\_\_  
STACK DIAMETER 32 x 38 Area \_\_\_\_\_ ft<sup>2</sup>



PROBE LENGTH, TYPE, FACTOR 6' SS, .797  
NOZZLE I.D. .1875  
ASSUMED MOISTURE, % 20  
SAMPLE BOX NUMBER 1 METER 2  
WATER VOLUME COLLECTED 226.0 + 15.3 = 241.3 ml  
ORSAT CO<sub>2</sub> 2.3% O<sub>2</sub> 18.5 CO \_\_\_\_\_  
Impingers Silica Gel

### PARTICULATE WEIGHT

|          | WASH         | FILTER       | IMPINGERS |
|----------|--------------|--------------|-----------|
| I.D. NO. |              | <u>D-20A</u> |           |
| FINAL    |              | <u>.7775</u> |           |
| TARE     |              | <u>.7665</u> |           |
| GAIN     | <u>.0116</u> | <u>.0110</u> |           |

total weight = .0226

| TRAVERSE<br>POINT<br>NUMBER | CLOCK TIME<br>(24 hr.<br>clock)<br>SAMPLING<br>TIME, min. | GAS METER READING<br>(V <sub>m</sub> ), ft <sup>3</sup> | VELOCITY<br>HEAD<br>(P <sub>s</sub> in H <sub>2</sub> O<br>mm H <sub>2</sub> O) | ORIFICE PRESSURE<br>DIFFERENTIAL<br>(H <sub>2</sub> O) |        | STACK<br>TEMP<br>(T <sub>s</sub> ), °F | PROBE<br>TEMP<br>°F | SAMPLE<br>BOX<br>TEMP<br>°F | IMPINGER<br>TEMP<br>°F |     | DRY GAS METER<br>TEMPERATURE        |                                   | PUMP<br>VACUUM<br>in. Hg |
|-----------------------------|-----------------------------------------------------------|---------------------------------------------------------|---------------------------------------------------------------------------------|--------------------------------------------------------|--------|----------------------------------------|---------------------|-----------------------------|------------------------|-----|-------------------------------------|-----------------------------------|--------------------------|
|                             |                                                           |                                                         |                                                                                 | DESIRED                                                | ACTUAL |                                        |                     |                             | OUT                    | IN  | OUTLET<br>(T <sub>m out</sub> ), °F | INLET<br>(T <sub>m in</sub> ), °F |                          |
| 1                           | 0                                                         | 532.97                                                  | 130                                                                             |                                                        | 45     | 175                                    | 277                 | 254                         | 54                     | 121 | 61                                  | 62                                | 5                        |
| 2                           | 4                                                         | 537.5                                                   | 75                                                                              |                                                        | 27     | 174                                    | 322                 | 281                         | 48                     | 127 | 61                                  | 65                                | 3                        |
| 3                           | 8                                                         | 540.3                                                   | 44                                                                              |                                                        | 16     | 182                                    | 275                 | 291                         | 47                     | 169 | 63                                  | 68                                | 2                        |
| 4                           | 12                                                        | 542.7                                                   | 36                                                                              |                                                        | 13     | 189                                    | 256                 | 290                         | 46                     | 184 | 65                                  | 71                                |                          |
| 5                           | 16                                                        | 544.95                                                  | 118                                                                             |                                                        | 41     | 189                                    | 248                 | 246                         | 46                     | 167 | 66                                  | 67                                | 5                        |
| 6                           | 20                                                        | 548.7                                                   | 86                                                                              |                                                        | 30     | 200                                    | 260                 | 231                         | 44                     | 160 | 66                                  | 70                                | 4                        |
| 7                           | 24                                                        | 552.2                                                   | 55                                                                              |                                                        | 19     | 203                                    | 266                 | 237                         | 45                     | 189 | 67                                  | 74                                | 3                        |
| 8                           | 28                                                        | 555.1                                                   | 42                                                                              |                                                        | 14     | 201                                    | 261                 | 248                         | 45                     | 192 | 69                                  | 75                                | 2                        |
| 9                           | 32                                                        | 557.18                                                  | 120                                                                             |                                                        | 42     | 205                                    | 250                 | 248                         | 46                     | 186 | 70                                  | 76                                | 5                        |
| 10                          | 36                                                        | 561                                                     | 92                                                                              |                                                        | 32     | 206                                    | 244                 | 280                         | 44                     | 211 | 71                                  | 79                                |                          |
| 11                          | 40                                                        | 564.9                                                   | 52                                                                              |                                                        | 18     | 206                                    | 243                 | 290                         | 45                     | 217 | 73                                  | 80                                | 2                        |
| 12                          | 44                                                        | 567                                                     | 38                                                                              |                                                        | 13     | 205                                    | 241                 | 281                         | 48                     | 207 | 74                                  | 81                                |                          |
| 13                          | 48                                                        | 569.8                                                   | 76                                                                              |                                                        | 26     | 212                                    | 237                 | 247                         | 50                     | 191 | 75                                  | 77                                | 3                        |
| 14                          | 52                                                        | 572.8                                                   | 80                                                                              |                                                        | 28     | 217                                    | 286                 | 234                         | 47                     | 195 | 75                                  | 81                                | 4                        |
| 15                          | 56                                                        | 576.6                                                   | 60                                                                              |                                                        | 21     | 218                                    | 254                 | 227                         | 47                     | 187 | 75                                  | 81                                | 3                        |
| 16                          | 60                                                        | 578.8                                                   | 48                                                                              |                                                        | 16     | 219                                    | 236                 | 225                         | 48                     | 187 | 76                                  | 82                                | 2                        |

METHOD 5 CALCULATIONS  
Data Input

Plant LAKESIDE INDUSTRIES, LACEY  
Sampling Location DRYER STACK  
Sample Type PARTICULATE  
Run Number 1  
Bar Pressure 29.91  
Static Pressure 0.0  
Stack Dia. Area 3.44  
Length 32.00 Width 35.00  
Operating Rate 260.00 Tons/hr  
Sample Time 64.00 Min

Pitot Fact 1.7970  
Nozzle ID 0.1975 inches  
H2O Weight 141.30  
Orsat CO2 2.30 O2 18.50  
Particulate Weight  
Filter Impingers  
I.D. NO. D-20A  
Final 0.7775  
Tare 0.7665  
Gain 0.0116 0.0110

| Point | Del P | Del H | Stack | Temperature<br>Meter | Start Vol | 532.97 | Final Vol | 531.35 | Moisture Fraction | 0.1941 | Mole Weight | 29.2664 | Po | 1.04 | Stack Flow est, acfm | 51,337 | sqrt(dp) | Vel    |
|-------|-------|-------|-------|----------------------|-----------|--------|-----------|--------|-------------------|--------|-------------|---------|----|------|----------------------|--------|----------|--------|
| 1     | 130.0 | 45.0  | 175   | 62                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 2.57     | 136.47 |
| 2     | 75.0  | 27.0  | 174   | 65                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.73     | 103.57 |
| 3     | 44.0  | 16.0  | 182   | 68                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.32     | 79.83  |
| 4     | 36.0  | 13.0  | 189   | 71                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.20     | 72.60  |
| 5     | 118.0 | 41.0  | 189   | 67                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 2.15     | 131.44 |
| 6     | 86.0  | 30.0  | 200   | 70                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.85     | 113.16 |
| 7     | 55.0  | 19.0  | 203   | 74                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.43     | 90.70  |
| 8     | 42.0  | 14.0  | 201   | 75                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.29     | 79.14  |
| 9     | 120.0 | 42.0  | 205   | 76                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 2.18     | 134.18 |
| 10    | 92.0  | 32.0  | 206   | 79                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.91     | 117.57 |
| 11    | 52.0  | 18.0  | 206   | 80                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.44     | 98.39  |
| 12    | 38.0  | 13.0  | 205   | 81                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.27     | 75.51  |
| 13    | 76.0  | 26.0  | 212   | 77                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.74     | 107.34 |
| 14    | 80.0  | 28.0  | 217   | 81                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.8      | 110.5  |
| 15    | 60.0  | 21.0  | 218   | 81                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.54     | 95.80  |
| 16    | 48.0  | 16.0  | 219   | 82                   |           |        |           |        |                   |        |             |         |    |      |                      |        | 1.38     | 85.75  |

Average 25.1 200.1 74.31 1.66 101.38



TEST NO. 7-7-87  
DATE

# METHOD 5— PARTICULATE SAMPLING WITH A HEATED FILTER WITH IMPINGER

PLANT Lakeside Industries  
SAMPLING LOCATION Lacey  
SAMPLE TYPE part.  
RUN NUMBER 2 OPERATOR  
AMBIENT TEMPERATURE 65  
BAROMETRIC PRESSURE 29.91  
STATIC PRESSURE 32 x 38 Area  
STACK DIAMETER 32 x 38 ft<sup>2</sup>

PROBE LENGTH, TYPE, FACTOR 6' SS .797  
NOZZLE I.D. .1475  
ASSUMED MOISTURE, % 20  
SAMPLE BOX NUMBER 2 METER 2  
WATER VOLUME COLLECTED 236.0 + 15.6 = 251.6 ml  
ORSAT CO<sub>2</sub> 1.7 O<sub>2</sub> 16.8 CO

PARTICULATE WEIGHT  
WASH  
FILTER  
IMPINGERS  
I.D. NO. D-103  
FINAL .7908  
TARE .7789  
GAIN .0119

total weight = .0295 gm.

| TRAVERSE<br>POINT<br>NUMBER | CLOCK TIME<br>(24 hr.<br>Clock)<br>SAMPLING<br>TIME, min. | GAS METER READING<br>(V <sub>m</sub> ), ft <sup>3</sup> | VELOCITY<br>HEAD<br>(P <sub>1</sub> ), in. H <sub>2</sub> O | ORIFICE PRESSURE<br>DIFFERENTIAL<br>(H), in. H <sub>2</sub> O |        | STACK<br>TEMP<br>(T <sub>s</sub> ), °F | PROBE<br>TEMP<br>°F | SAMPLE<br>BOX<br>TEMP<br>°F | IMPINGER<br>TEMP<br>°F |     | DRY GAS METER<br>TEMPERATURE       |                                  | PUMP<br>VACUUM<br>in. Hg. |
|-----------------------------|-----------------------------------------------------------|---------------------------------------------------------|-------------------------------------------------------------|---------------------------------------------------------------|--------|----------------------------------------|---------------------|-----------------------------|------------------------|-----|------------------------------------|----------------------------------|---------------------------|
|                             |                                                           |                                                         |                                                             | DESIRED                                                       | ACTUAL |                                        |                     |                             | OUT                    | IN  | OUTLET<br>(T <sub>m</sub> out), °F | INLET<br>(T <sub>m</sub> in), °F |                           |
| 1                           | 0                                                         | 7.57                                                    | 581.55                                                      |                                                               | 38     | 221                                    | 260                 | 301                         | 57                     | 214 | 73                                 | 72                               | 3                         |
| 2                           | 4                                                         |                                                         | 585.5                                                       |                                                               | 22     | 222                                    | 295                 | 280                         | 53                     | 256 | 73                                 | 75                               | 4                         |
| 3                           | 8                                                         |                                                         | 38                                                          |                                                               | 13     | 224                                    | 245                 | 274                         | 51                     | 230 | 73                                 | 77                               | 2                         |
| 4                           | 12                                                        |                                                         | 40                                                          |                                                               | 14     | 226                                    | 225                 | 277                         | 52                     | 236 | 74                                 | 78                               | 7                         |
| 5                           | 16                                                        |                                                         | 135                                                         |                                                               | 46     | 227                                    | 248                 | 274                         | 55                     | 241 | 76                                 | 82                               | 4                         |
| 6                           | 20                                                        |                                                         | 80                                                          |                                                               | 27     | 229                                    | 261                 | 274                         | 55                     | 244 | 76                                 | 82                               | 3                         |
| 7                           | 24                                                        |                                                         | 40                                                          |                                                               | 14     | 229                                    | 263                 | 272                         | 56                     | 237 | 77                                 | 83                               | 5                         |
| 8                           | 28                                                        |                                                         | 72                                                          |                                                               | 11     | 228                                    | 274                 | 261                         | 58                     | 231 | 78                                 | 81                               | 4                         |
| 9                           | 32                                                        |                                                         | 105                                                         |                                                               | 35     | 218                                    | 273                 | 236                         | 60                     | 184 | 68                                 | 65                               | 3                         |
| 10                          | 36                                                        |                                                         | 85                                                          |                                                               | 29     | 174                                    | 224                 | 229                         | 54                     | 167 | 68                                 | 68                               | 4                         |
| 11                          | 40                                                        |                                                         | 50                                                          |                                                               | 17     | 175                                    | 218                 | 224                         | 50                     | 195 | 68                                 | 70                               | 4                         |
| 12                          | 44                                                        |                                                         | 25                                                          |                                                               | 8      | 181                                    | 262                 | 224                         | 50                     | 180 | 69                                 | 73                               | 4                         |
| 13                          | 48                                                        |                                                         | 78                                                          |                                                               | 26     | 186                                    | 280                 | 239                         | 53                     | 218 | 70                                 | 77                               | 4                         |
| 14                          | 52                                                        |                                                         | 85                                                          |                                                               | 29     | 196                                    | 263                 | 255                         | 49                     | 232 | 72                                 | 82                               | 3                         |
| 15                          | 56                                                        |                                                         | 60                                                          |                                                               | 20     | 209                                    | 239                 | 275                         | 50                     | 215 | 74                                 | 81                               | 3                         |
| 16                          | 60                                                        |                                                         | 1                                                           |                                                               | 12     | 211                                    | 253                 | 274                         | 52                     | 215 | 74                                 | 81                               | 3                         |

METHOD 5 CALCULATIONS  
Data Input

Plant LAKESIDE INDUSTRIES, LACEY  
Sampling Location DRYER STACK  
Sample Type PARTICULATE  
Run Number 0  
Bar Pressure 30.08  
Static Pressure  
Stack Dia Area 8.44  
Length 32.00 Width 38.00  
Operating Rate 260 Tons/hr  
Sample Time 64.00 min

Pitot Fact 0.7970  
Nozzle ID 0.1875 inches  
H2O Weight 251.60  
Orsat CO2 1.70 O2 10.50  
Particulate Weight  
Wash Filter Impingers  
I.D. NO. D-103  
Final 0.7908  
Tare 0.7789  
Gain 0.0176 0.0119

| Point | Del P | Del H | Temperature |       | Start Vol            | 581.55  | sqrt(dp) | Vel    |
|-------|-------|-------|-------------|-------|----------------------|---------|----------|--------|
|       |       |       | Stack       | Meter |                      |         |          |        |
| 1     | 110.0 | 38.0  | 221         | 72    | Final Vol            | 628.21  | 2.99     | 130.00 |
| 2     | 65.0  | 22.0  | 222         | 75    |                      |         | 1.61     | 100.01 |
| 3     | 38.0  | 13.0  | 224         | 77    | Moisture Fraction    | 0.2064  | 1.23     | 76.58  |
| 4     | 40.0  | 14.0  | 226         | 79    | Mole Weight          | 29.1070 | 1.26     | 78.68  |
| 5     | 135.0 | 46.0  | 227         | 78    | Fa                   | 2.41    | 2.31     | 144.65 |
| 6     | 80.0  | 27.0  | 229         | 82    | Stack Flow Wet, acfm | 49,354  | 1.78     | 111.51 |
| 7     | 40.0  | 14.0  | 229         | 82    |                      |         | 1.26     | 78.65  |
| 8     | 32.0  | 11.0  | 228         | 83    |                      |         | 1.13     | 70.48  |
| 9     | 105.0 | 35.0  | 218         | 81    |                      |         | 2.04     | 126.73 |
| 10    | 85.0  | 29.0  | 174         | 65    |                      |         | 1.84     | 110.26 |
| 11    | 50.0  | 17.0  | 175         | 68    |                      |         | 1.41     | 84.64  |
| 12    | 25.0  | 8.0   | 191         | 70    |                      |         | 1.00     | 60.13  |
| 13    | 78.0  | 26.0  | 186         | 73    |                      |         | 1.76     | 106.62 |
| 14    | 85.0  | 29.0  | 196         | 77    |                      |         | 1.84     | 112.16 |
| 15    | 60.0  | 20.0  | 209         | 80    |                      |         | 1.54     | 95.16  |
| 16    | 35.0  | 12.0  | 213         | 81    |                      |         | 1.18     | 72.90  |

Average 22.8 209.9 76.44

1.58 97.46

## SOURCE TEST CALCULATIONS

## APPENDIX-B CALCULATIONS

## SAMPLE CALCULATION RUN 1

Volume Sampled

The volume sampled is normally expressed in standard dry cubic feet (sometimes in standard dry liters), and is determined by correction of the meter volume to standard conditions.

$$V_s = V_m \frac{520}{460 + T_m} \frac{P_m}{29.92} = 47.10 \text{ DSCF}$$

48.38      29.91  
74

Particulate Concentration

The concentration of particulate is determined by dividing the weight of particulate collected by the volume sample and expressed in grains per standard cubic foot.

$$C_p = \frac{(.01543 \text{ gr/mg}) (W_p)}{V_s} = .0074 \frac{\text{gr}}{\text{ft}^3}$$

22.6 mg  
47.10

Gas Pollutant

To determine the volumetric concentration of gaseous pollutants, find the number of moles of pollutants per  $10^6$  moles of gas. The result is expressed in parts per million, ppm.

$$C_{\text{gas}} = \frac{M_p}{M_{Wp}} \frac{MV}{V_s} \times 10^6$$

Excess Air

The excess air is determined by the concentration of  $O_2$  in the gas stream at the sample point, divided by the concentration of  $O_2$  used for combustion, with adjustments for carbon monoxide.

$$EA = \frac{\%O_2 - 0.5\% CO}{0.264 (\%N_2) - \%O_2 + 0.5 (\%CO)} \times 100$$

 $O_2$  Correction

To adjust the pollutant concentration to a 7%  $O_2$  standard, the concentration is multiplied by the  $O_2$  in the air, minus 7%  $O_2$ , and divided by the  $O_2$  in the air minus the  $O_2$  in the gas stream.

$$C_7 = \frac{(21.0 - 7.0)}{(21.0 - \%O_2)} C = \frac{14.0 C}{21.0 - \%O_2}$$



### Stack Gas Flow Rate, Standard

The stack gas flow rate under standard conditions is expressed as standard dry cubic feet per minute, and obtained by adjusting the stack gas flow rate to standard temperature and pressure and subtracting the volume of the water vapor.

$$Q_s = \frac{520}{460 + T_s} \frac{(P_s)}{(29.92)} (1 - F_m) Q_d = 32,600 \text{ SDCFM}$$

206

### Emission Rate

Emission rate is calculated from the product of the concentration and the flow rate, and normally expressed in pounds per hour.

Particulate - 32,600

$$R_p = \frac{C_p (Q_{std}) (60 \text{ Min./Hr})}{7000 \text{ Gr./Lb.}} = 2.07$$

$$R_{gas} = C_{gas} \frac{(Q_{std}) (MW_p)}{(MVE)} \frac{(60 \text{ Min.})}{(\text{Hr.})}$$

### Isokinetic Rate

The isokinetic rate ratio of the velocity of gas through the nozzle to the velocity of gas passed the nozzle and normally expressed as percent.

$$I = \frac{0.138 V_s (460 + T_s)}{A_n P_s (1 - F_m) V_{ave}}$$

$$I = \frac{\text{Velocity of Nozzle}}{\text{Velocity of Stack}}$$

$$= \frac{V_s (460 + T_s)}{60 \cdot (A_n) 520^\circ R V_{ave} P_s (1 - F_s)}$$

$$= \frac{47.10 (460 + 206) 29.92}{60 (64 \text{ min}) 0.0019 \text{ ft}^2 (520^\circ R) 101 \frac{\text{ft}}{\text{sec}} 29.92 (1 - .19)}$$

$$= 1.00$$

USER: John Drabek

DATE: Post weighed 7-14-87 by Susan Davis

[illegible]

3-AUG-87

EPA Region X Lab Management System  
\*\*\* Lab Analysis Report \*\*\*

Page 1

*John Drabek*

Transaction #: 08031148 Seq #: 01

(15) Solids - Specified

(WE) DOE, Manchester

Was

Prj: LAKESIDE ASPHALT

(DOE-582A) 212

JWD

Par: Solids Total mg

(Par# 500 S)

Instrument: GRAV Gravimetric Measurement

Method: EP1-160.3 Residue, Total, Gravimetric, Dried at 103-105 Deg-C

Chemist: (DKS) Solberg, Keith DOE Hours Worked:

Lab Prep:( ) Unspecified Date Preprd: Date Anlyzd: 870714

Matrix: (10) Water-Total Units: (52) mg

| Line | Sample #  | Result | Sample Location/Description | Volume ml | #Days to Anl |
|------|-----------|--------|-----------------------------|-----------|--------------|
| 1    | 87 287044 | 11.6   | RUN 1, LACEY                | 575       | 870707 ( 7)  |
| 2    | 87 287045 | 17.9   | RUN 2, LACEY                | 420       | 870707 ( 7)  |
| 3    | 87 287046 | 58.6   | RUN 1, ABERDEEN             | 550       | 870708 ( 6)  |
| 4    | 87 287047 | 47.6   | RUN 2, ABERDEEN             | 500       | 870708 ( 6)  |
| 5    | 87 287048 | 31.6   | RUN 3, ABERDEEN             | 350       | 870708 ( 6)  |

Record Type: TRNIN2

Date Verified: 8/4/87

By: W. Z. Light

Transaction Status: New Transaction...First Printing...Unverified.

Processed: 3-AUG-87 11:53:21 Status: N Batch: (In CUR DB)



# VISIBLE EMISSION OBSERVATION FORM

| OBSERVATION DATE |   |    |    |    | START TIME |   |    |    |    | STOP TIME |  |  |  |  |
|------------------|---|----|----|----|------------|---|----|----|----|-----------|--|--|--|--|
| 7-8-87           |   |    |    |    | 1525 DLT   |   |    |    |    | 1628      |  |  |  |  |
| SEC              | 0 | 15 | 30 | 45 | SEC        | 0 | 15 | 30 | 45 |           |  |  |  |  |
| 1                |   |    |    |    | 31         |   |    |    |    |           |  |  |  |  |
| 2                |   |    |    |    | 32         |   |    |    |    |           |  |  |  |  |
| 3                |   |    |    |    | 33         |   |    |    |    |           |  |  |  |  |
| 4                |   |    |    |    | 34         |   |    |    |    |           |  |  |  |  |
| 5                |   |    |    |    | 35         |   |    |    |    |           |  |  |  |  |
| 6                |   |    |    |    | 36         |   |    |    |    |           |  |  |  |  |
| 7                |   |    |    |    | 37         |   |    |    |    |           |  |  |  |  |
| 8                |   |    |    |    | 38         |   |    |    |    |           |  |  |  |  |
| 9                |   |    |    |    | 39         |   |    |    |    |           |  |  |  |  |
| 10               |   |    |    |    | 40         |   |    |    |    |           |  |  |  |  |
| 11               |   |    |    |    | 41         |   |    |    |    |           |  |  |  |  |
| 12               |   |    |    |    | 42         |   |    |    |    |           |  |  |  |  |
| 13               |   |    |    |    | 43         |   |    |    |    |           |  |  |  |  |
| 14               |   |    |    |    | 44         |   |    |    |    |           |  |  |  |  |
| 15               |   |    |    |    | 45         |   |    |    |    |           |  |  |  |  |
| 16               |   |    |    |    | 46         |   |    |    |    |           |  |  |  |  |
| 17               |   |    |    |    | 47         |   |    |    |    |           |  |  |  |  |
| 18               |   |    |    |    | 48         |   |    |    |    |           |  |  |  |  |
| 19               |   |    |    |    | 49         |   |    |    |    |           |  |  |  |  |
| 20               |   |    |    |    | 50         |   |    |    |    |           |  |  |  |  |
| 21               |   |    |    |    | 51         |   |    |    |    |           |  |  |  |  |
| 22               |   |    |    |    | 52         |   |    |    |    |           |  |  |  |  |
| 23               |   |    |    |    | 53         |   |    |    |    |           |  |  |  |  |
| 24               |   |    |    |    | 54         |   |    |    |    |           |  |  |  |  |
| 25               | 3 | 0  | 0  | 0  | 55         |   |    |    |    |           |  |  |  |  |
| 26               | 0 | 0  | 0  | 0  | 56         |   |    |    |    |           |  |  |  |  |
| 27               | 0 | 0  | 0  | 0  | 57         |   |    |    |    |           |  |  |  |  |
| 28               | 0 | 0  | 0  | 0  | 58         |   |    |    |    |           |  |  |  |  |
| 29               |   |    |    |    | 59         |   |    |    |    |           |  |  |  |  |
| 30               |   |    |    |    | 60         |   |    |    |    |           |  |  |  |  |

COMPANY Aluminum Co. of America  
 ADDRESS Aluminum Co. of America  
 LOCATION Aluminum Co. of America  
 WIND DIRECTION \_\_\_\_\_  
 CLOUD COVER \_\_\_\_\_

DIAGRAM:  
 EMISSION POINT

AVERAGE OPACITY DURING THE PERIOD OF

1525 THROUGH 1628 WAS 0 %

OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE

DATE

I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS

SIGNATURE

TITLE

DATE

**SOURCE  
EMISSION  
EVALUATION**


September 8, 1994

Prepared For:


**LAKESIDE INDUSTRIES  
HOT MIX ASPHALT BATCH PLANT  
BAGHOUSE STACK  
METHOD 5 TESTING  
LACEY, WASHINGTON  
AUGUST 24, 1994**

**RECEIVED  
SEP 15 1994  
OAPCA**

Submitted by:

  
Kris A. Hansen  
Project Manager

  
E. Ray Lawrence  
Sr. Air Quality Specialist

  
Angela F. Blaisdell  
Sr. Technical Writer

**Am Test-Air Quality, Inc.  
Preston, Washington**

*We certify that the information contained herein is accurate and complete  
to the best of our knowledge.*

## TABLE OF CONTENTS

|                                                             | <u>Pages</u> |
|-------------------------------------------------------------|--------------|
| 1.0 INTRODUCTION                                            | 1-2          |
| 2.0 SUMMARY OF RESULTS                                      | 3-5          |
| Summary of Results - Methods 1, 2, 3A, 4 and 5              | 5            |
| 3.0 PROJECT OVERVIEW/EXCEPTIONS                             | 6            |
| 4.0 SOURCE OPERATION                                        | 7            |
| 5.0 SAMPLING AND ANALYSIS PROCEDURES                        | 8-13         |
| 5.1 EPA Methods 1 and 2 - Velocity, Temperature and Airflow | 8            |
| 5.2 EPA Method 3A - Gas Composition                         | 8-9          |
| 5.3 EPA Method 4 - Moisture                                 | 9            |
| 5.4 EPA Method 5 - Particulate Matter                       | 9-13         |
| 6.0 QUALITY ASSURANCE PLAN                                  | 14-17        |
| 6.1 Calibration Procedures and Frequency                    | 14-16        |
| 6.2 Sample Recovery and Field Documentation                 | 16           |
| 6.3 Data Reduction, Validation and Reporting                | 17           |
| 7.0 METHODOLOGY REFERENCES                                  | 18           |
| APPENDIX A - Computer Printouts of Results                  | 19-22        |
| Methods 1, 2, 3A, 4 and 5                                   | 20-22        |
| APPENDIX B - Example Calculations and Field Data Sheets     | 23-35        |
| Example Calculation - Methods 1, 2, 3A, 4 and 5             | 24-26        |
| Stack Schematic and Location of Sample Points               | 27           |
| Field Data Sheets for Methods 1, 2, 3A, 4 and 5             | 28-33        |
| Method 5 Laboratory Analysis                                | 34           |
| Sample Train Information                                    | 35           |
| Gas Bag Sample Data Sheet                                   | 36           |
| APPENDIX C - Supporting Information                         | 37-69        |
| Source and Process Information                              | 38-39        |
| Figure 1. Location of Sampling Points and Traverse Points   | 40           |
| Figure 2. Method 5 Sample Train                             | 41           |
| Method 1 - Location of Traverse Points                      | 42           |
| Method 1 - Minimum Number of Traverse Points                | 43           |
| Method 2 - Velocity & Volumetric Flow Calculations          | 44           |
| Method 3 - Molecular Weight and Excess Air Calculations     | 44           |
| Method 4 - Stack Gas Moisture Calculations                  | 45           |
| Method 5 - Particulate Emission Calculations                | 46-47        |
| Nomenclature for Method 1-5 Calculations                    | 48-49        |
| Dry Gas Meter Calibration Information                       | 50-55        |
| Type S Pitot Tube Inspection Data Forms                     | 56           |
| Stack Temperature Sensor Calibration Data Forms             | 57           |
| Professional Resumes of Project Personnel                   | 58-64        |
| Am Test-Air Quality, Inc. - Capabilities                    | 65-66        |
| Am Test, Inc. Capabilities                                  | 67-69        |

## 1.0

### INTRODUCTION

---

The purpose of this source emission evaluation was to quantify particulate and condensible matter emissions from a hot mix asphalt batch plant located at Lakeside Industries' facility in Lacey, Washington. The asphalt plant was manufactured by Madson and is equipped with a WAG baghouse to control particulate matter emissions prior to exhausting to the atmosphere. Lakeside Industries contracted Am Test-Air Quality Inc. based in Preston, Washington to conduct these source tests. These tests were performed to demonstrate compliance with a regulatory order from the Olympic Air Pollution Control Authority (OAPCA).

Testing and analysis procedures used for this project are presented in the July 1, 1993 edition of the Environmental Protection Agency (EPA) document Title 40, Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A, Methods 1, 2, 3A, 4, 5 and the OAPCA back-half method. Methods 1 and 2 were performed to measure the stack gas temperature and velocity for calculating volumetric flow rate. Method 3A was performed to determine the molecular weight of the stack gas based on measurements of the oxygen (O<sub>2</sub>), carbon dioxide (CO<sub>2</sub>) and carbon monoxide (CO) concentration in the stack gas. Method 4 was performed to measure the moisture content of the stack gas. Method 5 was performed to quantify particulate and condensible matter emissions. OAPCA requires that the condensible particulate matter present in the gas stream be quantified by performing an extraction of the back-half portion of the Method 5 sample train. Three (3) Method 1, 2, 3A, 4 and 5 tests were performed at the baghouse stack on August 24, 1994.

Mr. E. Ray Lawrence and Mr. Aaron Porter of Am Test-Air Quality, Inc. performed the field sampling. Sample recovery and gravimetric laboratory analysis of the Method 5 samples were performed by Ms. Stacy Akin and Ms. Annika M. Woehr of Am Test-Air Quality, Inc. Data reduction, quality assurance review and final report preparation were performed by Mr. Kris A. Hansen, Ms. Angela F. Blaisdell and Ms. Amy M. Brotherton of Am Test. This testing program was coordinated by Mr. Forest Lane of Lakeside Industries. Mr. Robert Moody of OAPCA observed the testing.

## 2.0

### SUMMARY OF RESULTS

---

The following section of this report presents results from the particulate and condensible matter emissions testing performed at the hot mix asphalt batch plant baghouse stack. Refer to the Table of Contents to locate specific information for each type of test. The summary table in this section contains information obtained from computer printouts of results for each individual run which are included in Appendix A of this report. Appendix B of this report contains example calculations of results and copies of the original field data sheets. Appendix C of this report contains miscellaneous supporting information.

The results of the three (3) Method 5 tests for quantifying particulate and condensible matter emissions at the hot mix asphalt batch plant baghouse exhaust are summarized in Table 2.0 below, and on the following computer printout titled "Summary of Results - Methods 1, 2, 3A, 4 and 5".

**Table 2.0.** Summary of particulate and condensible matter emissions test results from samples collected on August 24, 1994 at the hot mix asphalt batch plant stack at Lakeside Industries' facility in Lacey, Washington.

| Sample Run # | Front-half P.M. Emission Conc. (gr/dscf) | Back-half P.M. Emission Conc. (gr/dscf) | Total P.M. Emission Conc. (gr/dscf) | Total P.M. Emission Conc. (mg/dscm) | Total P.M. Emission Rate (lb/hr) |
|--------------|------------------------------------------|-----------------------------------------|-------------------------------------|-------------------------------------|----------------------------------|
| 1            | 0.045 ✓                                  | 0.003 ✓                                 | 0.049 ✓                             | 111.4                               | 11.0                             |
| 2            | 0.046 ✓                                  | 0.004 ✓                                 | 0.050 ✓                             | 114.7                               | 11.4                             |
| 3            | 0.042 ✓                                  | 0.007 ✓                                 | 0.049 ✓                             | 113.2                               | 11.0                             |
| Average      | 0.044                                    | 0.005                                   | 0.049                               | 113.1                               | 11.1                             |

The front-half, back-half and total particulate matter emission concentration is presented in units of grains per dry standard cubic foot (gr/dscf) and milligrams per dry standard cubic meter (mg/dscm) of gas sampled. The particulate matter emission standard for this source is 0.04 gr/dscf. The particulate matter emission rate is presented in units of pounds per hour (lb/hr).



SUMMARY OF RESULTS - METHODS 1, 2, 3A, 4 AND 5  
AM TEST - AIR QUALITY, INC.

FILE NAME: R311\LKLCSUM  
CLIENT: LAKESIDE INDUSTRIES, INC.  
LOCATION: LACEY, WASHINGTON

HOT MIX ASPHALT BATCH PLANT STACK

|                                                   | RUN #1    | RUN #2    | RUN #3    | AVERAGE |
|---------------------------------------------------|-----------|-----------|-----------|---------|
| LAB #:                                            | 6506      | 6507      | 6508      |         |
| DATE:                                             | 8/24/94   | 8/24/94   | 8/24/94   |         |
| START TIME:                                       | 10:15     | 12:33     | 14:43     |         |
| STOP TIME:                                        | 11:35     | 13:45     | 15:54     |         |
| SAMPLE LENGTH (minutes):                          | 60.0      | 60.0      | 60.0      |         |
| VOLUME SAMPLED (cubic feet):                      | 58.496    | 58.678    | 60.990    | 59.388  |
| VOLUME SAMPLED (dry std. cubic feet):             | 58.576    | 57.668    | 59.478    | 58.574  |
| VOLUME SAMPLED (dry std. cubic meters):           | 1.659     | 1.633     | 1.684     | 1.659   |
| STACK GAS MOISTURE (percent):                     | 26.40     | 27.37     | 28.80     | 27.52   |
| BAROMETRIC PRESSURE (inches of Hg):               | 29.95     | 29.95     | 29.95     | 29.95   |
| STATIC PRESSURE (inches of H2O):                  | 0.26      | 0.26      | 0.26      | 0.260   |
| STACK PRESSURE (inches of Hg):                    | 29.97     | 29.97     | 29.97     | 29.97   |
| STACK TEMPERATURE (degrees F.):                   | 228.5     | 231.0     | 233.7     | 231.1   |
| STACK TEMPERATURE (degrees R.):                   | 688.5     | 691.0     | 693.7     | 691.1   |
| CARBON DIOXIDE (percent):                         | 5.5       | 5.8       | 5.8       | 5.7     |
| OXYGEN (percent):                                 | 13.0      | 12.8      | 12.5      | 12.8    |
| MOLECULAR WEIGHT (dry, lb/lb-mole):               | 29.40     | 29.44     | 29.43     | 29.42   |
| MOLECULAR WEIGHT (wet, lb/lb-mole):               | 26.39     | 26.31     | 26.14     | 26.28   |
| AVERAGE VELOCITY HEAD (inches of H2O):            | 2.08      | 2.15      | 2.16      | 2.13    |
| PITOT TUBE Cp:                                    | 0.84      | 0.84      | 0.84      |         |
| STACK GAS VELOCITY (feet per second):             | 96.7      | 98.7      | 99.3      | 98.2    |
| STACK DIAMETER (inches):                          | 37.375x31 | 37.375x31 | 37.375x31 |         |
| STACK AREA (square feet):                         | 8.05      | 8.05      | 8.05      |         |
| STACK GAS AIRFLOW (dry std. cubic feet per min.): | 26402.8   | 26479.4   | 26025.4   | 26302.5 |
| STACK GAS AIRFLOW (actual cubic feet per min.):   | 46703.7   | 47637.5   | 47944.0   | 47428.4 |
| NOZZLE DIAMETER (inches):                         | 0.238     | 0.238     | 0.238     |         |
| ISOKINETICS (percent):                            | 96        | 95        | 99        |         |
| FRONT-HALF PARTICULATE EMISSION CONC. (gr/dscf):  | 0.045     | 0.046     | 0.042     | 0.044   |
| BACK-HALF PARTICULATE EMISSION CONC. (gr/dscf):   | 0.003     | 0.004     | 0.007     | 0.005   |
| TOTAL PARTICULATE EMISSION CONC. (gr/dscf):       | 0.049     | 0.050     | 0.049     | 0.049   |
| TOTAL PARTICULATE EMISSION CONC. (mg/dscm):       | 111.4     | 114.7     | 113.2     | 113.1   |
| TOTAL PARTICULATE MATTER EMISSION RATE (lb/hr):   | 11.0      | 11.4      | 11.0      | 11.1    |

**3.0****PROJECT OVERVIEW/EXCEPTIONS**

---

An acceptable leak check of less than 0.02 cfm at the highest vacuum rate (or greater) used during the test preceded and followed each run. The average percentage isokinetics for each run were within the acceptable limits of  $100 \pm 10\%$ . Process and production conditions were considered to be representative, according to plant personnel.

## 4.0

### SOURCE OPERATION

---

Lakeside Industries operates a Madsen hot mix asphalt batch plant in Lacey, Washington. Emissions are controlled by a WAG Model 8 reverse pulse baghouse prior to exhausting to the atmosphere. The baghouse contains 1180 14-ounce Nomex bags. The pressure drop across the baghouse averaged 5.5 inches of water column ("H<sub>2</sub>O) on the day of testing. According to plant personnel, the plant operated at an average asphalt production rate of 270 tons per hour (tph), with a gravel moisture content of 4-6% and gravel containing 5-7% fines. The plant was fired with diesel at a rate of 590 gallons per hour (gph). Process information sheets, completed by Mr. Forest Lane of Lakeside Industries, are included in Appendix C of this report.

## **5.0**

### **SAMPLING AND ANALYSIS PROCEDURES**

---

#### **5.1 EPA Methods 1 and 2 - Velocity, Temperature and Airflow**

EPA Method 1 procedures were used to assure that representative measurements of volumetric flow rate were obtained by dividing the cross-section of the stack or duct into a number of equal areas, and then locating a traverse point within each of the equal areas. Refer to the "Stack Schematic and Location of Sample Points" data sheet and/or the figure titled, "Location of Sampling Ports and Traverse Points", located in the appendices of this report for a schematic of the stack and the point locations selected for testing. Method 2 was performed to measure the stack gas velocity using a type S or a standard pitot tube, and the gas temperature using a calibrated thermocouple probe connected to a digital thermocouple indicator. The type S pitot tubes were connected with tubing to an oil-filled inclined manometer, a hook gauge manometer or magnehelic gauges to obtain velocity measurements. The pitot tube lines were leak-checked and the pressure measurement device was leveled and zeroed prior to use. Calibration information for each pressure and temperature measurement device used are included in the appendices of this report.

#### **5.2 EPA Method 3A - Molecular Weight**

The stack gas composition was evaluated during each Method 5 test by collecting integrated samples of the stack gas in multilayer bags. The integrated bag samples were analyzed using a paramagnetic analyzer to measure the percent (%) O<sub>2</sub>, a non-dispersive infrared (NDIR) analyzer to measure the % carbon dioxide (CO<sub>2</sub>), and an NDIR or a gas filter correlation NDIR analyzer to measure the parts per million (ppm) carbon monoxide (CO) in the gas stream. The manufacturer and model

number of each of the analyzers used is included in the appendices of this report on the "Continuous Analyzer Checklist" and/or the "Gas Bag Sample Data Sheet". The average measured O<sub>2</sub> concentration and CO<sub>2</sub> concentration were used to calculate the molecular weight of the stack gas.

### **5.3 EPA Method 4 - Moisture**

The percent moisture in the gas stream was quantified by weighing the impingers to 0.1 grams before and after each Method 5 run on a digital top-loading balance. The net weight (final minus initial) was used to calculate the amount of moisture condensed from the known volume of stack gas collected.

### **5.4 EPA Method 5 - Particulate Matter**

The sample train used for particulate matter sampling was an EPA Method 5 design as illustrated in the figure titled "Method 5 Sample Train" in the appendices of this report. The "Sample Train Information Sheet" (also in the appendices) details the type of nozzle, probe, probe liner and filter used along with the contents of the sample train impingers. The probe was equipped with S-type pitot tubes for measuring gas velocity and a thermocouple sensor for measuring stack gas temperature. The thermocouple sensor was connected to a digital thermocouple indicator which was used to measure the stack gas temperature at each sample point. A glass filter assembly was enclosed in a temperature-controlled heated sample box. The average box temperature was maintained at 248° F  $\pm$  25° F. The nozzle, probe liner, prefilter connective glassware and filter are referred to as the "front-half" of the sample train. Following the filter is a condenser section which, by convention, is referred to as the "back-half". The back-half was maintained at a temperature below 68° F by adding ice to the condenser section during sampling. Note: Some subparts or methods specify alternate temperatures for the probe liner,

filter holder box and impinger ice bath. The "Sample Train Information Sheet" details any exceptions.

The Method 5 sample train was connected to a control box by means of an umbilical cord which contained a vacuum hose, pitot lines, thermocouple wires and a 4-wire electrical cord. The control box (meter box) was used to monitor stack conditions and to facilitate isokinetic sampling. The control box consisted of a diaphragm pump used to pull the stack gas through the sample train, fine and coarse metering valves to control the sampling rate, a vacuum gauge to measure the pressure drop from the sample nozzle to the metering valves, and a calibrated dry gas meter readable to 0.001 cubic feet. At the outlet of the dry gas meter was a calibrated orifice which was used to isokinetically control the flow of gas through the metering system. The pitot tubes utilized to measure stack gas velocity were connected to the control box via the umbilical cord. The control box contained a manometer or magnehelic gauges which were used for the velocity measurement and for monitoring orifice pressure.

Stack condition measurements were made prior to collecting a sample, including measurements of velocity, temperature and a check for cyclonic flow in the stack. A sample nozzle was chosen and isokinetic operating parameters were established utilizing a Hewlett-Packard programmable calculator. The sampling nozzle, probe and prefilter connective glassware were cleaned and rinsed prior to use. The sample train was assembled and determined to be leak free following the procedures outlined in Method 5. Before each test, a final check was made to assure that the process was operating at the desired production rate and operating parameters. A final check was made of the sample box and probe heat temperatures. Crushed ice was added to the condenser section. The sample nozzle

was positioned in the stack at the first sample point. The sample pump was then turned on and the gas sampling rate was adjusted for isokinetic sampling. Isokinetic sampling proceeded at each of the traverse points. Upon completion of the test, the sample probe was removed from the stack and a post-test leak check was performed according to Method 5 procedures. Care was taken to assure that the nozzle tip did not touch the port nipple.

Following sample collection, the Method 5 sample trains were transferred to an area free from air disturbances and airborne particulate matter. The filters were transferred to petri dishes labeled with the sample date, client name and run number. Am Test refers to the front-half filter portion of the particulate catch as the "A" section. Care was taken to assure that any loose particulate matter and filter mat were quantitatively transferred to the petri dish. In the laboratory, the filters were placed in an oven and baked at 105° C for two (2) hours, then transferred to a constant humidity desiccator containing silicon dioxide ( $\text{SiO}_2$ ) for at least 24 hours of desiccation prior to obtaining weights. The same weighing procedures were followed to obtain the tare weights for the filters. The tare and final weights were made using an electronic balance set to a time integrating mode with a readability of 0.1 milligrams. The filters were weighed to a constant weight of  $\pm 0.5$  milligrams. The interval between weighings was at least 6 hours. These weights were recorded in a bound laboratory notebook.

Following each run, the contents of the nozzle, probe liner and prefilter connective glassware were quantitatively transferred to the "B" section storage container labeled with sample date, client name and run number. Several rinses of acetone, with simultaneous loosening of particulate matter using a clean nylon brush, were used for the front-half clean-up. An iodine flask with a female ball joint end was

attached to the male ball joint end of the probe to assure that no particulate matter was lost during the rinsing and brushing of the probe. The contents of the iodine flask were quantitatively transferred to the "B" section storage container. In the laboratory, the "B" section acetone rinse was transferred to a tared, graduated 150 milliliter (mL) beaker. The volume of acetone was recorded and the beakers were placed in an evaporation chamber at a temperature of approximately 75-80° F until dry. Note: Some subparts or methods specify alternate "B" section cleanup solvents. The "Sample Train Information Sheet" details any exceptions.

The bubblers and impingers utilized for the condenser section, or "back-half" of the sample train were weighed with a readability of 0.1 grams before and after sampling using an electronic top loading balance. The difference between the initial and final weights of the condenser section constitute the amount of moisture gain during the run. The contents of the bubblers and impingers were transferred to a 1000 mL graduated cylinder. The bubblers and impingers were rinsed with deionized water into the graduated cylinder and the liquid level was recorded. A 20 milliliter aliquot of each impinger catch was archived for potential future analysis. The remaining impinger catch was extracted and the C and C<sub>x</sub> section net weights were factored to represent the total impinger catch. This liquid was transferred to a separatory funnel and the contents were extracted with three (3) 50 mL portions of dichloromethane (CH<sub>2</sub>Cl<sub>2</sub>). The organic layer was transferred to a tared 150 mL beaker labeled the "C<sub>x</sub>" section and was allowed to evaporate to dryness in an evaporation chamber at a temperature of 75-80° F. The water layer was transferred to a tared 150 mL beaker with glass boiling beads labeled the "C" section, and was heated on a drum plate to boiling until approximately 20 mL remained in the beaker. The remaining 20 mL in the beaker was evaporated to dryness in an evaporation chamber set at 105° C. The bubblers, impingers and graduated

cylinder were given a final rinse with acetone into another tared, graduated beaker ("D" Section) and was allowed to evaporate to dryness in an evaporation chamber at 75-80° F. Sample blanks containing deionized water, dichloromethane, and acetone were analyzed in an identical fashion as the representative "section". All beakers were desiccated for at least 24 hours and weighed to constant weights of  $\pm 0.5$  milligrams at 6 hour or greater intervals. This is the same procedure used to obtain tare weights for each beaker. The total particulate matter weight is the sum of the net weights of the particulate matter found on the filter, plus the net weights found in the B, C, Cx and D section beakers, minus the acetone, water, and dichloromethane blank contributions. The particulate matter weights are included on the Method 5 computer printouts and in copies of the laboratory analysis forms in the appendices of this report. Note: Some subparts or methods specify alternate back-half section cleanup solvents. The "Sample Train Information Sheet" details any exceptions.

## 6.0

### QUALITY ASSURANCE PLAN

---

The purpose of the quality assurance plan is to provide guidelines for achieving quality control in air pollution measurements. The detailed procedures which are utilized are included in the Environmental Protection Agency's (EPA's) reference manual titled Quality Assurance Handbook for Air Pollution Measurement Systems, Volume 3, EPA-600/4-77-027b. These procedures are followed throughout equipment preparation, field sampling, sample recovery, analysis and data reduction. Am Test-Air Quality, Inc.'s quality assurance procedures are discussed below.

#### 6.1 Calibration Procedures and Frequency

Field equipment utilized for on-site measurements is calibrated at a frequency recommended by the equipment manufacturer or industry practice. Prior to field use, each instrument is calibrated and the calibration value is recorded. If any measuring or test device requiring calibration cannot immediately be removed from service, the Project Manager may extend the calibration cycle providing a review of the equipment's history warrants the issuance of an extension. No equipment will be extended more than twice a calibration cycle, nor will the extension exceed one-half the prescribed calibration cycle. Test equipment consistently found to be out of calibration will be repaired or replaced.

The sample nozzles used to collect isokinetic samples are calibrated on-site before sampling using digital inside calipers readable to 0.001 inch. Three (3) measurements were taken at varying points around the inside of the nozzle tip and

averaged. The dry gas meters used to accurately measure sample volumes are calibrated using a standard laboratory dry gas meter. The type S pitot tubes utilized for velocity determination are calibrated using Method 2, Section 4.1, and are inspected regularly for wear. The magnehelic gauges used for pressure measurements are checked against an oil-filled manometer. The digital thermocouple indicator used for temperature measurement has a readability of 1 degree Fahrenheit and is periodically re-certified by the manufacturer. Each thermocouple probe used to monitor temperature is checked periodically at three (3) temperature settings. Copies of calibration information for each measurement device used are included in the appendices of this report. A barometer readable to 0.01 inches of mercury is used in the field to obtain barometric pressure readings.

In the laboratory reagent blanks are carried throughout the gravimetric analysis procedures. The samples were weighed to constant weights of  $\pm 0.5$  milligrams following desiccation in a cabinet desiccator. This desiccator is an electronic dehumidifier which automatically maintains the humidity inside the desiccator. The dehumidifier automatically recharges the internal desiccant every 5.5 hours. An Airguide humidity indicator accurate to  $\pm 1\%$  is used to check the humidity inside the desiccator when obtaining tare and final weights. A small container of indicating silica gel is placed in the desiccators to maintain the desired humidity. The Mettler AE163 electronic balance used to obtain weights is set to a time integrating mode (100,000 readings per minute) with a readability of 0.01 milligrams. The balance is calibrated prior to every weighing session and an audit is performed with class S weights once a week. The calibration of Am Test's Mettler balances is checked by the manufacturer on a yearly basis:

Support equipment is defined as all equipment, not previously discussed, that is required for completing an environmental monitoring or measurement task. This equipment may include storage and transportation containers, sample recovery glassware, and communications gear. Support equipment is periodically inspected to maintain the performance standards necessary for proper and efficient execution of all tasks and responsibilities.

During a project, a systems audit is performed, consisting of an on-site qualitative inspection and review of the total measurement system. This inspection is conducted on a daily basis by the Project Leader. During the systems audit, the auditor observes the procedures and techniques of the field team in the following general areas:

- Setting up and leak testing the sample train
- Isokinetic sampling check
- Final leak check of the sample train
- Sample recovery

Visual inspections of pitot tubes, glassware, and other equipment are also made. The main purpose of a systems audit is to ensure that the measurement system will generate valid data, if operated properly.

## **6.2 Sample Recovery and Field Documentation**

Data collected during each test, are immediately inspected for completeness and placed under the custody of the Project Leader until custody is transferred when the samples were returned to the Air Quality laboratory. Sample recovery is carried out in a suitable area free from particulate matter contamination. Each sample is assigned an identifying lab number to assist the chemists in tracking the sample.

### **6.3 Data Reduction, Validation and Reporting**

Raw data are handled according to strict guidelines when being transposed into computer files or to other logs. The guidelines include document receipt control procedures, file review, and sign-off by a project assistant. Raw data are entered into the appropriate computer spreadsheet by a "processor", then the entered figures are checked for accuracy by a "checker", different from the "processor". Any mistakes are corrected, and figures are rechecked and signed off by the "checker". In addition, a by-hand calculation check of each spreadsheet is made using a hand-held calculator to validate the computer output. All data generated by each phase of a laboratory or field sampling program are reviewed by the senior reviewer. The data package is signed off by the senior reviewer prior to releasing the data for report preparation.

The test results are calculated in accordance with current EPA 40 CFR 60 criteria. Copies of the pertinent equations used to derive the results for this test are included in the appendices of this report. Standard conditions are 29.92 inches of mercury and 68° F.

## 7.0

### METHODOLOGY REFERENCES

---

EPA. Title 40 Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A, Reference Methods 1, 2, 3A, 4 and 5. July 1, 1993.

EPA. EPA 450/2-79-006, APTI Course, "Course 450 - Source Sampling For Particulate Pollutants", December 1979.

EPA. Quality Assurance Handbook for Air Pollution Measurement Systems, Volume 3, EPA-60/4-77-027b.

Attachment 1, Olympic Air Pollution Control Authority Particulate Test Procedure (OAPCA method).

**APPENDIX A**  
**Computer Printouts of Results**

METHODS 1, 2, 3A, 4 AND 5  
AM TEST-AIR QUALITY, INC.

FILE NAME: R311\LKPLACE51  
CLIENT: LAKESIDE INDUSTRIES  
LOCATION: LACEY, WASHINGTON  
SAMPLE SITE: HOT MIX ASPHALT  
BATCH PLANT STACK  
SAMPLE DATE: AUGUST 24, 1994  
RUN #: 1 - METHOD 5  
OPERATORS: R. LAWRENCE

LAB #: 6506  
START TIME: 10:15 o'clock  
STOP TIME: 11:35 o'clock  
SAMPLE LENGTH: 60.0 minutes

FRONT-HALF PARTICULATE MATTER MASS LOADING

-----  
FILTER NUMBER: #110-582  
TARE WEIGHT OF FILTER (grams): 0.8136  
FINAL WEIGHT OF FILTER (grams): 0.9294  
NET WEIGHT OF PARTICULATE MATTER (grams): 0.1158 ✓

BEAKER NUMBER: #150-1608  
TARE WEIGHT OF BEAKER (grams): 65.4787  
FINAL WEIGHT OF BEAKER (grams): 65.5349  
NET WEIGHT OF PARTICULATE MATTER (grams): 0.0562 ✓  
VOLUME OF ACETONE (milliliters): 140.0 ✓  
WT./VOL. OF ACETONE BLANK (milligrams/ml): 0.0029 ✓  
NET WEIGHT OF PARTIC. DUE TO ACETONE (grams): 0.0004 ✓

TOTAL FRONT-HALF PARTICULATE MATTER (grams): 0.1716 ✓

BACK-HALF PARTICULATE MATTER MASS LOADING

-----  
"C" SECTION - CONDENSER PARTICULATE #150-1623  
TARE WEIGHT OF BEAKER (grams): 65.2250  
FINAL WEIGHT OF BEAKER (grams): 65.2392  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0142  
TOTAL VOLUME OF WATER (milliliters): 760.0  
VOLUME OF WATER CONDENSED (milliliters): 423.4 ✓  
NET VOLUME OF WATER FOR BLANK (milliliters): 336.6  
WT./VOL. OF WATER BLANK (milligrams/ml): 0.0024  
NET WEIGHT OF PARTIC. DUE TO WATER (grams): 0.0008

"Cx" SECTION - HYDROCARBON EXTRACTION #150-1610  
TARE WEIGHT OF BEAKER (grams): 65.6427  
FINAL WEIGHT OF BEAKER (grams): 65.6427  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0000  
TOTAL VOLUME OF CH<sub>2</sub>Cl<sub>2</sub> (milliliters): 150.0  
WT./VOL. OF CH<sub>2</sub>Cl<sub>2</sub> BLANK (milligrams/ml): 0.000  
NET WEIGHT OF PARTIC. DUE TO CH<sub>2</sub>Cl<sub>2</sub> (grams): 0.0000

"D" SECTION - ACETONE RINSE OF CONDENSER #150-1609  
TARE WEIGHT OF BEAKER (grams): 65.5389  
FINAL WEIGHT OF BEAKER (grams): 65.5389  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0000  
TOTAL VOLUME OF ACETONE (milliliters): 70.0  
WT./VOL. OF ACETONE BLANK (milligrams/ml): 0.0029  
NET WEIGHT OF PARTIC. DUE TO ACETONE (grams): 0.0002

TOTAL BACK-HALF PARTICULATE MATTER (grams): 0.0132  
TOTAL WEIGHT OF PARTICULATE MATTER (grams): 0.1848 ✓

IMPINGER WEIGHTS

| FINAL                        | INITIAL | NET    |
|------------------------------|---------|--------|
| grams                        | grams   | grams  |
| 971.1                        | 661.4   | 309.7  |
| 744.6                        | 643.5   | 101.1  |
| 571.3                        | 558.7   | 12.6   |
| 870.4                        | 848.2   | 22.2   |
| TOTAL H <sub>2</sub> O GAIN: |         | 445.6  |
| TOTAL VOLUME (scf):          |         | 21.01  |
| PERCENT MOISTURE:            |         | 26.40  |
| Bws:                         |         | 0.2640 |

INIT. METER VOLUME: 139.262  
FINAL METER VOLUME: 197.758  
VOLUME SAMPLED: 58.496  
STD VOLUME (dscf): 58.576  
STD VOLUME (dscm): 1.659  
Y FACTOR: 1.002

PITOT TUBE Cp: 0.84  
NOZZLE DIAMETER: 0.238 inches  
NOZZLE AREA: 0.0003 sq. feet  
STACK DIAMETER: 37.375x31 inches  
STACK AREA: 8.05 sq. feet  
METER TEMPERATURE: 70.9 degrees F  
BAROMETRIC PRES.: 29.95 inches Hg  
STATIC PRESSURE: 0.26 inches H<sub>2</sub>O  
STACK PRESSURE: 29.97 inches Hg  
ORIFICE PRESSURE: 1.568 inches H<sub>2</sub>O  
METER PRESSURE: 30.07 inches Hg

AVERAGE CONC. CO<sub>2</sub>: 5.5 percent  
AVERAGE CONC. O<sub>2</sub>: 13.0 percent  
AVERAGE CONC. CO: NA ppm  
MOLECULAR WEIGHT: 29.40 g/g-mole-dry  
MOLECULAR WEIGHT: 26.39 g/g-mole-wet  
Fo FACTOR: 1.436

| SAMPLE POINT | VELOCITY " OF H2O | TEMPERATURE °F | SAMPLE POINT | VELOCITY " OF H2O | TEMPERATURE °F |
|--------------|-------------------|----------------|--------------|-------------------|----------------|
| A 1          | 0.90              | 223            | C 1          | 0.84              | 228            |
| 2            | 1.09              | 224            | 2            | 1.08              | 230            |
| 3            | 1.54              | 225            | 3            | 1.77              | 229            |
| 4            | 2.18              | 227            | 4            | 2.68              | 228            |
| 5            | 4.10              | 229            | 5            | 3.48              | 230            |
| 6            | 4.80              | 230            | 6            | 3.49              | 229            |
| B 1          | 0.94              | 228            | D 1          | 1.02              | 228            |
| 2            | 0.96              | 228            | 2            | 1.40              | 228            |
| 3            | 1.45              | 229            | 3            | 2.05              | 229            |
| 4            | 2.35              | 229            | 4            | 2.62              | 230            |
| 5            | 3.90              | 231            | 5            | 2.39              | 231            |
| 6            | 4.35              | 232            | 6            | 2.35              | 230            |

PERCENT ISOKINETICS: 96 %  
STACK TEMPERATURE: 228.5 degrees F  
AVERAGE VELOCITY HEAD: 2.08 " of H<sub>2</sub>O  
STACK GAS VELOCITY: 96.7 ft/second  
STACK GAS AIR FLOW: 46703.7 acf/min  
PARTICULATE EMISSION CONCENTRATION (front-half): 26402.8 dscf/min  
PARTICULATE EMISSION CONCENTRATION (back-half): 0.045 gr/dscf  
TOTAL PARTICULATE EMISSION CONC. (front & back-half): 0.003 gr/dscf  
TOTAL PARTICULATE EMISSION CONCENTRATION: 0.049 gr/dscf  
TOTAL PARTICULATE MATTER EMISSION RATE: 111.4 mg/dscm  
11.0 lb/hr

METHODS 1, 2, 3A, 4 AND 5  
AM TEST-AIR QUALITY, INC.

FILE NAME: R311\KLACE52  
CLIENT: LAKESIDE INDUSTRIES  
LOCATION: LACEY, WASHINGTON  
SAMPLE SITE: HOT MIX ASPHALT  
BATCH PLANT STACK  
SAMPLE DATE: AUGUST 24, 1994  
RUN #: 2 - METHOD 5  
OPERATORS: R. LAWRENCE

LAB #: 6507  
START TIME: 12:33 o'clock  
STOP TIME: 13:45 o'clock  
SAMPLE LENGTH: 60.0 minutes

IMPINGER WEIGHTS  
FINAL INITIAL NET  
grams grams grams  
-----  
950.8 645.8 305.0  
759.1 638.0 121.1  
546.1 534.5 11.6  
872.2 848.9 23.3

TOTAL H2O GAIN: 461.0  
TOTAL VOLUME (scf): 21.74  
PERCENT MOISTURE: 27.37  
Bws: 0.2737

INIT. METER VOLUME: 198.162  
FINAL METER VOLUME: 256.840  
VOLUME SAMPLED: 58.678  
STD VOLUME (dscf): 57.668  
STD VOLUME (dscm): 1.633  
Y FACTOR: 1.002

PITOT TUBE Cp: 0.84  
NOZZLE DIAMETER: 0.238 inches  
NOZZLE AREA: 0.0003 sq. feet  
STACK DIAMETER: 37.375x31 inches  
STACK AREA: 8.05 sq. feet  
METER TEMPERATURE: 81.0 degrees F  
BAROMETRIC PRES.: 29.95 inches Hg  
STATIC PRESSURE: 0.26 inches H2O  
STACK PRESSURE: 29.97 inches Hg  
ORIFICE PRESSURE: 1.615 inches H2O  
METER PRESSURE: 30.07 inches Hg

AVERAGE CONC. CO2: 5.8 percent  
AVERAGE CONC. O2: 12.8 percent  
AVERAGE CONC. CO: NA ppm  
MOLECULAR WEIGHT: 29.44 g/g-mole-dry  
MOLECULAR WEIGHT: 26.31 g/g-mole-wet  
Fo FACTOR: 1.397

| SAMPLE POINT | VELOCITY " OF H2O | TEMPERATURE °F | SAMPLE POINT | VELOCITY " OF H2O | TEMPERATURE °F |
|--------------|-------------------|----------------|--------------|-------------------|----------------|
| A 1          | 1.01              | 230            | C 1          | 0.97              | 229            |
| 2            | 1.15              | 229            | 2            | 1.25              | 231            |
| 3            | 1.49              | 229            | 3            | 1.62              | 231            |
| 4            | 2.35              | 230            | 4            | 2.55              | 233            |
| 5            | 3.80              | 232            | 5            | 3.78              | 233            |
| 6            | 4.50              | 231            | 6            | 3.85              | 234            |
| B 1          | 0.85              | 230            | D 1          | 1.28              | 232            |
| 2            | 1.05              | 230            | 2            | 1.58              | 231            |
| 3            | 1.50              | 230            | 3            | 2.19              | 232            |
| 4            | 2.45              | 230            | 4            | 2.55              | 232            |
| 5            | 3.90              | 230            | 5            | 2.49              | 232            |
| 6            | 4.62              | 231            | 6            | 2.38              | 232            |

PERCENT ISOKINETICS: 95 %  
STACK TEMPERATURE: 231.0 degrees F 691.0 degrees R  
AVERAGE VELOCITY HEAD: 2.15 " of H2O  
STACK GAS VELOCITY: 98.7 ft/second  
STACK GAS AIR FLOW: 47637.5 acf/min 26479.4 dscf/min  
PARTICULATE EMISSION CONCENTRATION (front-half): 0.046 gr/dscf  
PARTICULATE EMISSION CONCENTRATION (back-half): 0.004 gr/dscf  
TOTAL PARTICULATE EMISSION CONC. (front & back-half): 0.050 gr/dscf  
TOTAL PARTICULATE EMISSION CONCENTRATION: 114.7 mg/dscm  
TOTAL PARTICULATE MATTER EMISSION RATE: 11.4 lb/hr

FRONT-HALF PARTICULATE MATTER MASS LOADING

FILTER NUMBER: #110-589  
TARE WEIGHT OF FILTER (grams): 0.8177  
FINAL WEIGHT OF FILTER (grams): 0.9345  
NET WEIGHT OF PARTICULATE MATTER (grams): 0.1168 ✓

BEAKER NUMBER: #150-1611  
TARE WEIGHT OF BEAKER (grams): 66.7606  
FINAL WEIGHT OF BEAKER (grams): 66.8159  
NET WEIGHT OF PARTICULATE MATTER (grams): 0.0553 ✓  
VOLUME OF ACETONE (milliliters): 170.0  
WT./VOL. OF ACETONE BLANK (milligrams/ml): 0.0029  
NET WEIGHT OF PARTIC. DUE TO ACETONE (grams): 0.0005 ✓

TOTAL FRONT-HALF PARTICULATE MATTER (grams): 0.1716 ✓

BACK-HALF PARTICULATE MATTER MASS LOADING

"C" SECTION - CONDENSER PARTICULATE #150-1624  
TARE WEIGHT OF BEAKER (grams): 65.1514  
FINAL WEIGHT OF BEAKER (grams): 65.1680  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0166 ✓  
TOTAL VOLUME OF WATER (milliliters): 740.0  
VOLUME OF WATER CONDENSED (milliliters): 437.7  
NET VOLUME OF WATER FOR BLANK (milliliters): 302.3 ✓  
WT./VOL. OF WATER BLANK (milligrams/ml): 0.0024  
NET WEIGHT OF PARTIC. DUE TO WATER (grams): 0.0007 ✓

"Cx" SECTION - HYDROCARBON EXTRACTION #150-1613  
TARE WEIGHT OF BEAKER (grams): 66.9948  
FINAL WEIGHT OF BEAKER (grams): 66.9948  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0000 ✓  
TOTAL VOLUME OF CH2Cl2 (milliliters): 150.0  
WT./VOL. OF CH2Cl2 BLANK (milligrams/ml): 0.000 ✓  
NET WEIGHT OF PARTIC. DUE TO CH2Cl2 (grams): 0.0000 ✓

"D" SECTION - ACETONE RINSE OF CONDENSER #150-1612  
TARE WEIGHT OF BEAKER (grams): 67.3012  
FINAL WEIGHT OF BEAKER (grams): 67.3012  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0000  
TOTAL VOLUME OF ACETONE (milliliters): 75.0  
WT./VOL. OF ACETONE BLANK (milligrams/ml): 0.0029  
NET WEIGHT OF PARTIC. DUE TO ACETONE (grams): 0.0002 ✓

TOTAL BACK-HALF PARTICULATE MATTER (grams): 0.0157 ✓  
TOTAL WEIGHT OF PARTICULATE MATTER (grams): 0.1873 ✓

METHODS 1, 2, 3A, 4 AND 5  
AM TEST-AIR QUALITY, INC.

FILE NAME: R311\KLACE53  
CLIENT: LAKESIDE INDUSTRIES  
LOCATION: LACEY, WASHINGTON  
SAMPLE SITE: HOT MIX ASPHALT  
BATCH PLANT STACK  
SAMPLE DATE: AUGUST 24, 1994  
RUN #: 3 - METHOD 5  
OPERATORS: R. LAWRENCE

LAB #: 6508  
START TIME: 14:43 o'clock  
STOP TIME: 15:54 o'clock  
SAMPLE LENGTH: 60.0 minutes

FRONT-HALF PARTICULATE MATTER MASS LOADING

-----  
FILTER NUMBER: #110-583  
TARE WEIGHT OF FILTER (grams): 0.8202  
FINAL WEIGHT OF FILTER (grams): 0.9156  
NET WEIGHT OF PARTICULATE MATTER (grams): 0.0954 ✓

BEAKER NUMBER: #150-1614  
TARE WEIGHT OF BEAKER (grams): 66.9630  
FINAL WEIGHT OF BEAKER (grams): 67.0306  
NET WEIGHT OF PARTICULATE MATTER (grams): 0.0676 ✓  
VOLUME OF ACETONE (milliliters): 230.0  
WT./VOL. OF ACETONE BLANK (milligrams/ml): 0.0029  
NET WEIGHT OF PARTIC. DUE TO ACETONE (grams): 0.0007 ✓

TOTAL FRONT-HALF PARTICULATE MATTER (grams): 0.1623 ✓

BACK-HALF PARTICULATE MATTER MASS LOADING

-----  
"C" SECTION - CONDENSER PARTICULATE #150-1625  
TARE WEIGHT OF BEAKER (grams): 65.1549  
FINAL WEIGHT OF BEAKER (grams): 65.1843  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0294  
TOTAL VOLUME OF WATER (milliliters): 840.0  
VOLUME OF WATER CONDENSED (milliliters): 488.0  
NET VOLUME OF WATER FOR BLANK (milliliters): 352.0  
WT./VOL. OF WATER BLANK (milligrams/ml): 0.0024  
NET WEIGHT OF PARTIC. DUE TO WATER (grams): 0.0008

"Cx" SECTION - HYDROCARBON EXTRACTION #150-1616  
TARE WEIGHT OF BEAKER (grams): 65.7992  
FINAL WEIGHT OF BEAKER (grams): 65.7992  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0000  
TOTAL VOLUME OF CH2Cl2 (milliliters): 150.0  
WT./VOL. OF CH2Cl2 BLANK (milligrams/ml): 0.000  
NET WEIGHT OF PARTIC. DUE TO CH2Cl2 (grams): 0.0000

"D" SECTION - ACETONE RINSE OF CONDENSER #150-1615  
TARE WEIGHT OF BEAKER (grams): 65.8874  
FINAL WEIGHT OF BEAKER (grams): 65.8874  
NET WEIGHT OF PARTIC. MATTER (grams): 0.0000  
TOTAL VOLUME OF ACETONE (milliliters): 95.0  
WT./VOL. OF ACETONE BLANK (milligrams/ml): 0.0029  
NET WEIGHT OF PARTIC. DUE TO ACETONE (grams): 0.0003

TOTAL BACK-HALF PARTICULATE MATTER (grams): 0.0283 ✓  
TOTAL WEIGHT OF PARTICULATE MATTER (grams): 0.1906 ✓

IMPINGER WEIGHTS  
FINAL INITIAL NET  
grams grams grams  
-----  
785.7 593.8 191.9  
888.6 640.3 248.3  
589.5 541.7 47.8  
791.4 769.2 22.2  
TOTAL H2O GAIN: 510.2  
TOTAL VOLUME (scf): 24.06  
PERCENT MOISTURE: 28.80  
Bws: 0.2880

INIT. METER VOLUME: 257.697  
FINAL METER VOLUME: 318.687  
VOLUME SAMPLED: 60.990  
STD VOLUME (dscf): 59.478  
STD VOLUME (dscm): 1.684  
Y FACTOR: 1.002

PITOT TUBE Cp: 0.84  
NOZZLE DIAMETER: 0.238 inches  
NOZZLE AREA: 0.0003 sq. feet  
STACK DIAMETER: 37.375x31 inches  
STACK AREA: 8.05 sq. feet  
METER TEMPERATURE: 85.2 degrees F  
BAROMETRIC PRES.: 29.95 inches Hg  
STATIC PRESSURE: 0.26 inches H2O  
STACK PRESSURE: 29.97 inches Hg  
ORIFICE PRESSURE: 1.618 inches H2O  
METER PRESSURE: 30.07 inches Hg

AVERAGE CONC. CO2: 5.8 percent  
AVERAGE CONC. O2: 12.5 percent  
AVERAGE CONC. CO: NA ppm  
MOLECULAR WEIGHT: 29.43 g/g-mole-dry  
MOLECULAR WEIGHT: 26.14 g/g-mole-wet  
Fo FACTOR: 1.448

| SAMPLE POINT | VELOCITY " OF H2O | TEMPERATURE °F | SAMPLE POINT | VELOCITY " OF H2O | TEMPERATURE °F |
|--------------|-------------------|----------------|--------------|-------------------|----------------|
| A 1          | 0.97              | 232            | C 1          | 0.96              | 235            |
| 2            | 1.05              | 233            | 2            | 1.19              | 232            |
| 3            | 1.52              | 233            | 3            | 1.79              | 233            |
| 4            | 2.29              | 234            | 4            | 2.65              | 233            |
| 5            | 4.15              | 236            | 5            | 3.61              | 234            |
| 6            | 4.71              | 236            | 6            | 3.60              | 234            |
| B 1          | 0.83              | 232            | D 1          | 1.10              | 230            |
| 2            | 1.05              | 233            | 2            | 1.65              | 230            |
| 3            | 1.55              | 235            | 3            | 2.15              | 232            |
| 4            | 2.49              | 235            | 4            | 2.55              | 232            |
| 5            | 4.19              | 237            | 5            | 2.73              | 236            |
| 6            | 4.20              | 236            | 6            | 2.46              | 236            |

PERCENT ISOKINETICS: 99 %  
STACK TEMPERATURE: 233.7 degrees F 693.7 degrees R  
AVERAGE VELOCITY HEAD: 2.16 " of H2O  
STACK GAS VELOCITY: 99.3 ft/second  
STACK GAS AIR FLOW: 47944.0 acf/min 26025.4 dscf/min  
PARTICULATE EMISSION CONCENTRATION (front-half): 0.042 gr/dscf  
PARTICULATE EMISSION CONCENTRATION (back-half): 0.007 gr/dscf  
TOTAL PARTICULATE EMISSION CONC. (front & back-half): 0.049 gr/dscf  
TOTAL PARTICULATE EMISSION CONCENTRATION: 113.2 mg/dscm  
TOTAL PARTICULATE MATTER EMISSION RATE: 11.0 lb/hr

## **APPENDIX B**

### **Example Calculations and Field Data Sheets**

**EXAMPLE CALCULATION SHEET  
EPA METHODS 1, 2, 3A, 4 AND 5**

CLIENT: Lakeside Industries LOCATION: Lacey, Washington DATE: 8/24/94  
 RUN #: 3 LAB #: 6508 SITE LOCATION: Hot Mix Asphalt Batch Plant Stack

**Particulate Matter Emission Concentration - Equation 5-1**

$$\begin{aligned}
 Vm_{std} &= 17.647^\circ R / "Hg_{(constant)} * \text{volume sampled} * Y_{factor} * (P_B + \Delta H / 13.6) / (460 + T_m) \\
 &= 17.647^\circ R / "Hg * \underline{60.990} \text{ ft}^3 * \underline{1.002} * (\underline{29.95} "Hg + (\underline{1.618} "H_2O / 13.6)) / (460 + \underline{85.2}^\circ F) \\
 &= \underline{59.478} \text{ dscf} \\
 dscm &= \underline{59.478} \text{ dscf} / 35.31 \text{ ft}^3/\text{m}^3 \\
 &= \underline{1.684} \text{ dscm}
 \end{aligned}$$

Substitution of Equation 5-4 into 5-5

$$W_a = \text{mg/ml blank} * \text{ml sample} = \text{mg sample due to acetone blank}$$

$$W_a = \underline{0.7} \text{ mg} = \underline{0.0029} \text{ mg/ml} * \underline{230} \text{ ml}$$

$$M_n = (\text{net weight filter catch}) + (\text{net weight "B" section}) - W_a + \text{Back-half}$$

$$= \underline{190.6} \text{ mg} = \underline{95.4} \text{ mg} + \underline{67.6} \text{ mg} - \underline{0.7} \text{ mg} + \underline{28.3} \text{ mg}$$

$$C_s = (0.001 \text{ g/mg}) * (15.43 \text{ grains/gram}) * M_n / Vm_{std}$$

$$\begin{aligned}
 C_s &= (0.001 \text{ g/mg}) * (15.43 \text{ grains/gram}) * \underline{190.6} \text{ mg} / \underline{59.478} \text{ dscf} \\
 &= \underline{0.049} \text{ gr/dscf (Equation 5-6)}
 \end{aligned}$$

$$\begin{aligned}
 \text{gr/dscf @ } \underline{\quad} \% O_2 &= \underline{\quad} \text{ gr/dscf} * (20.9\% - \underline{\quad} \% O_2) / (20.9\% - \underline{\quad} \% O_2) \\
 &\quad \quad \quad \% \text{ correction} \quad \quad \quad \% \text{ measured} \\
 &= \underline{N/A} \text{ gr/dscf @ } \underline{\quad} \% O_2
 \end{aligned}$$

$$\begin{aligned}
 \text{gr/dscf @ } \underline{\quad} \% CO_2 &= \underline{\quad} \text{ gr/dscf} * \underline{\quad} \% / \underline{\quad} \% CO_2 \\
 &\quad \quad \quad \% \text{ correction} \quad \quad \quad \% \text{ measured} \\
 &= \underline{N/A} \text{ gr/dscf @ } \underline{\quad} \% CO_2
 \end{aligned}$$

$$\begin{aligned}
 \text{mg/dscm} &= \underline{190.6} \text{ mg} / \underline{1.684} \text{ dscm} \\
 &= \underline{113.2} \text{ mg/dscm}
 \end{aligned}$$

**Particulate Matter Emission Rate**

$$\text{pounds/hour} = C_s * \text{dscf/min} * 60 \text{ min/hr} * 1 \text{ lb/7000 grains}$$

$$\begin{aligned}
 \text{pounds/hour} &= \underline{0.049} \text{ gr/dscf} * \underline{2025.4} \text{ dscf/min} * 60 \text{ min/hr} * 1 \text{ lb/7000 grains} \\
 &= \underline{11.0} \text{ lb/hr}
 \end{aligned}$$

EXAMPLE CALCULATION SHEET (continued)  
EPA METHODS 1, 2, 3A, 4 and 5

**Moisture - Equation 5-2 and 5-3**

$$V_{wstd} = 0.04715 \text{ ft}^3/\text{g} * 510.2 \text{ grams of H}_2\text{O collected in impingers}$$

$$= 24.1 \text{ scf}$$

$$B_{ws} = (24.1 \text{ scf}) / (24.1 \text{ scf} + 59.478 \text{ dscf})$$

$$= 0.2880$$

$$\% \text{ Moisture} = 28.80 \% = B_{ws} * 100$$

**Molecular weight - Equation 3-2**

$$M_d = 0.440 * (5.8 \% \text{CO}_2) + 0.320 * (12.5 \% \text{O}_2) + 0.280 * (100\% - 5.8 \% \text{CO}_2 - 12.5 \% \text{O}_2 (\% \text{CO} + \% \text{N}_2))$$

$$= 29.43 \text{ g/g-mole (dry)}$$

$$M_s = M_d * (1 - B_{ws}) + 18.0 * B_{ws} = 29.43 \text{ g/g-mole} * (1 - 0.2880) + 18.0 \text{ g/g-mole} * 0.2880$$

$$= 26.14 \text{ g/g-mole (wet)}$$

$$F_o = 1.448 = (20.9 - 12.5) \% \text{O}_2 / 5.8 \% \text{CO}_2$$

**Stack gas velocity and volumetric flow rate - Equation 2-9 and 2-10**

$$V_s = 85.49 * C_p * \sqrt{\Delta P * T_s / (M_s * P_s)}$$

$$V_s = 85.49 * 0.84 * \sqrt{2.16 * 693.7^\circ \text{R} / (26.14 \text{ g/g-mole} * 29.97 \text{ "Hg})}$$

$$V_s = 99.3 \text{ ft/sec (std)}$$

$$Q_{sd} = 3600 * (1 - B_{ws}) * V_s * A_s * (T_{std}/T_s) * (P_s / P_{std}) / 60 \text{ min/hr}$$

$$Q_{sd} = 3600 * (1 - 0.2880) * 99.3 \text{ ft/sec} * 8.05 \text{ ft}^2 * (528^\circ \text{R} / 693.7^\circ \text{R}) * (29.97 \text{ "Hg} / 29.92 \text{ "Hg}) / 60$$

$$= 26025.4 \text{ dscf/min (dry standard cubic feet per minute)}$$

$$\text{acfm} = 99.3 \text{ ft/sec} * 8.05 \text{ ft}^2 * 60 \text{ sec/min}$$

$$= 47944.0 \text{ acfm (actual cubic feet per minute)}$$

**Isokinetic variation - Equation 5-8**

$$I = 0.09450 * V_{mstd} * T_s \div [P_s * V_s * \text{sample time} * A_n * (1 - B_{ws})]$$

$$I = 0.09450 * 59.478 \text{ dscf} * 693.7^\circ \text{R} / [29.97 \text{ "Hg} * 99.3 \text{ ft/sec} * 60 \text{ min} * 0.0003 \text{ ft}^2 * (1 - 0.2880)]$$

$$I = 99 \%$$

All of the above numbered equations are from the 40 CFR 60 and assume English units.

**EXAMPLE CALCULATION SHEET (continued)**  
**EPA METHODS 1, 2, 3A, 4 and 5**

**BACKHALF PARTICULATE**

**"C" Section**

| <u>Final Wt</u> | <u>Initial Wt</u> | <u>Net Wt</u> |
|-----------------|-------------------|---------------|
| 785.7           | 593.8             | = 191.9       |
| 888.6           | 640.3             | = 248.3       |
| 589.5           | 541.7             | = 47.8        |
|                 |                   | <u>488.0</u>  |

- a 29.4 mg particulate in "C" Section Beaker
- b 840 ml of water in condensers, including rinses
- c 488 ml condensation in 1<sup>st</sup>, 2<sup>nd</sup> and 3<sup>rd</sup> bubblers (final wt - initial wt, assumes 1g/1ml water density)
- d 352 ml DI water used in bubblers including rinses =  $b - c$
- e 0.0024 mg/ml blank particulate = 0.6 mg blank / 250 ml blank
- f 0.8 mg blank particulate =  $e * d$
- 28.6 mg of "C" particulate =  $a - f = 29.4 \text{ mg} - 0.8 \text{ mg}$

**"Cx" Section**

- a 0.0 mg particulate in "Cx" Section Beaker
- b 150 ml CH<sub>2</sub>Cl<sub>2</sub> used for sample
- c 0.0 mg/ml blank particulate = 0.0 mg blank / 150 ml blank
- d 0.0 mg blank particulate =  $b * c$
- 0.0 mg of "Cx" particulate =  $a - d = 0.0 \text{ mg} - 0.0 \text{ mg}$

**"D" Section**


- a 0.0 mg particulate in "D" Section Beaker
- b 95 ml Acetone used for sample
- c 0.0029 mg/ml blank particulate (Same as "B" Section)
- d 0.3 mg blank particulate =  $b * c$
- 0.3 mg of "D" particulate =  $a - d = 0.0 \text{ mg} - 0.3 \text{ mg}$

**TOTAL BACK-HALF PARTICULATE**

- + 28.6 mg "C" Section Particulate
- + 0.0 mg "Cx" Section Particulate
- + -0.3 mg "D" Section Particulate
- + N/A mg Back-half Filter Particulate (If applicable)

= 28.3 mg Back-half Particulate

# STACK SCHEMATIC AND LOCATION OF SAMPLE POINTS



Client LAND-CONLocation LAKE ELYSampling Location PORTAL GALLERYInside of far wall to outside  
of port (distance, X) 71.25"Inside of near wall to outside  
of port (distance, Y) 4"Stack I.D. (distance X - distance Y)  
37.375"

Schematic of Sampling  
Location

RECTANGULAR STACK  
37.375" X 31"

| 1<br>Traverse Point # | 2<br>Fractional Percent of Stack I.D. | 3<br>Stack I.D. inches | 4<br>Column 2 x 3 | 5<br>Distance Y | 6<br>Traverse Point Location from Outside of Port columns 4 + 5 |
|-----------------------|---------------------------------------|------------------------|-------------------|-----------------|-----------------------------------------------------------------|
| 1                     |                                       | 37.375                 | 3.12              | 4"              | 7.12                                                            |
| 2                     |                                       |                        | 9.36              |                 | 13.36                                                           |
| 3                     |                                       |                        | 15.60             |                 | 19.60                                                           |
| 4                     |                                       |                        | 21.84             |                 | 25.84                                                           |
| 5                     |                                       |                        | 28.08             |                 | 32.08                                                           |
| 6                     |                                       |                        | 34.32             |                 | 38.32                                                           |
| 7                     |                                       |                        |                   |                 |                                                                 |
| 8                     |                                       |                        |                   |                 |                                                                 |
| 9                     |                                       |                        |                   |                 |                                                                 |
| 10                    |                                       |                        |                   |                 |                                                                 |
| 11                    |                                       |                        |                   |                 |                                                                 |
| 12                    |                                       |                        |                   |                 |                                                                 |


CROSS SECTION



EQ DIA = 33.89"

Distance A = 23.5" downstream  
Distance B = 23.5" upstream

STACK, CONTROL DEVICE AND PROCESS  
FLOW DIAGRAM



6506

Client Lakeside  
Location LACEY WA  
Sample Site BAG House Outlet

---

Stack Diameter 37.375 X 3/4  
Date 8-24-74  
Operators BR  
Run I.D. R-1 MS BH

## QA FORMS COMPLETED

Stack Schematic ✓  
Sample Train ✓  
Pitot Tube Insp. ✓  
Magnehelic Cal. ✓  
Temp. Probe Cal. ~~TPD~~  
Gas Meter Calib. ✓

Start Time 10 15  
Stop Time 11 35  
Barometric  
Pressure "Hg 29.95  
Static Pres "H<sub>2</sub>O + .25  
Production Rate

Filter #                      Box # S-1

## SAMPLING PARAMETERS

## EQUIPMENT CHECKS

Initial/Final

Leak Rate cfm 0.05 / 0.04

Leak Test Vacuum 11" / 9"

☒ Pitots, Pre Leak Ck

☒ Pitots, Post Leak Ck

☐ Gas Sampling System

☒ Integrated Bag

M5 Rinse Acetone/H<sub>2</sub>O/Other

|                               | Final        | Initial        | Net            |
|-------------------------------|--------------|----------------|----------------|
|                               | Wt.          | Wt.            | Wt.            |
|                               | gram         | gram           | gram           |
| #1 Imp.                       | <u>971.1</u> | <u>- 661.4</u> | = <u>309.7</u> |
| #2 Imp.                       | <u>744.6</u> | <u>- 643.5</u> | = <u>101.1</u> |
| #3 Imp.                       | <u>571.3</u> | <u>- 558.7</u> | = <u>12.6</u>  |
| #4 Imp.                       | <u>-</u>     | <u>-</u>       | = <u>423</u>   |
| #5 Imp.                       | <u>-</u>     | <u>-</u>       | =              |
| #6 S.G.                       | <u>870.4</u> | <u>- 848.2</u> | = <u>22.2</u>  |
| Total H <sub>2</sub> O Volume |              |                | <u>445.6</u>   |

% Moisture 26.7  
Meter Temp. 65 78  
Stack Temp. 215 225  
 $\Delta H@$  .805 Y 1.002  
Pitot # P563 Side #       
Cp .84  
Nozzle Diameter .238 inch  
D<sub>1</sub> .238 D<sub>2</sub> .238 D<sub>3</sub> .237  
K Factor 1.688

| Sample Point | Elap Time Min. | Dry Gas Meter Reading Cu.Ft. | Pitot Reading Δ P " H <sub>2</sub> O | Orifice Setting (Δ H) " H <sub>2</sub> O |        | Gas Meter Temp °F |     | Pump Vac. Gauge " Hg | Filter Box Temp °F | Imp. Exit Temp °F | Stack Temp °F | O <sub>2</sub> %     |
|--------------|----------------|------------------------------|--------------------------------------|------------------------------------------|--------|-------------------|-----|----------------------|--------------------|-------------------|---------------|----------------------|
|              |                |                              |                                      | Ideal                                    | Actual | In                | Out |                      |                    |                   |               |                      |
|              |                |                              |                                      |                                          |        |                   |     |                      |                    |                   |               |                      |
| A1           | 0              | 139.262                      | .90                                  | .62                                      | .62    | 61                | 62  | 3                    | 253                | 67                | 223           |                      |
| 2            | 2½             | 140.85-                      | 1.09                                 | .75                                      | .75    | 61                | 64  | 3                    | 253                | 63                | 224           |                      |
| 3            | 5              | 142.58-                      | 1.54                                 | 1.06                                     | 1.06   | 65                | 61  | 4½                   | 247                | 61                | 225           |                      |
| 4            | 7½             | 144.57-                      | 2.18                                 | 1.74                                     | 1.71   | 68                | 62  | 5                    | 248                | 58                | 227           |                      |
| 5            | 10             | 148.10                       | 4.10                                 | 2.82                                     | 2.82   | 73                | 63  | 5                    | 249                | 57                | 229           |                      |
| 6            | 12½            | 151.50                       | 4.80                                 | 3.33                                     | 3.33   | 76                | 64  | 7                    | 247                | 63                | 230           | CO <sub>2</sub> 5.5% |
| B1           | 15             | 155.-                        | .94                                  | .65                                      | .65    | 70                | 65  | 3                    | 247                | 67                | 228           | CO 13.0%             |
| 2            | 17½            | 156.76                       | .96                                  | .67                                      | .67    | 71                | 65  | 3                    | 249                | 65                | 228           | CO NA                |
| 3            | 20             | 158.36                       | 1.45                                 | 1.00                                     | 1.00   | 72                | 68  | 4                    | 250                | 61                | 229           |                      |
| 4            | 22½            | 160.31                       | 2.35                                 | 1.63                                     | 1.67   | 74                | 66  | 4½                   | 243                | 56                | 229           |                      |
| 5            | 25             | 162.77                       | 3.90                                 | 2.71                                     | 2.71   | 78                | 67  | 6                    | 250                | 53                | 231           |                      |
| 6            | 27½            | 165.92                       | 4.35                                 | 3.04                                     | 3.04   | 80                | 68  | 8                    | 244                | 53                | 232           |                      |
| C1           | 30             | 169.484                      | .84                                  | .59                                      | .59    | 73                | 69  | 2½                   | 249                | 60                | 228           |                      |
| 2            | 32½            | 171.02                       | 1.08                                 | .76                                      | .76    | 74                | 70  | 3                    | 244                | 54                | 230           |                      |
| 3            | 35             | 172.76                       | 1.77                                 | 1.24                                     | 1.24   | 74                | 70  | 4                    | 247                | 53                | 229           |                      |
| 4            | 37½            | 174.94                       | 2.68                                 | 1.88                                     | 1.88   | 76                | 70  | 5                    | 248                | 51                | 228           |                      |
| 5            | 40             | 177.67                       | 3.48                                 | 2.43                                     | 2.43   | 79                | 71  | 6                    | 251                | 51                | 230           |                      |
| 6            | 42½            | 180.69                       | 3.49                                 | 2.44                                     | 2.44   | 81                | 71  | 6                    | 251                | 52                | 229           |                      |
| D1           | 45             | 183.813                      | 1.02                                 | .71                                      | .71    | 75                | 71  | 3                    | 247                | 58                | 228           |                      |
| 2            | 47½            | 185.51                       | 1.40                                 | .98                                      | .98    | 76                | 72  | 3½                   | 252                | 55                | 228           |                      |
| 3            | 50             | 187.47                       | 2.05                                 | 1.43                                     | 1.43   | 78                | 72  | 4                    | 248                | 53                | 229           |                      |
| 4            | 52½            | 189.87                       | 2.62                                 | 1.83                                     | 1.83   | 80                | 72  | 5                    | 249                | 53                | 230           |                      |
| 5            | 55             | 192.55                       | 2.39                                 | 1.67                                     | 1.67   | 81                | 73  | 5                    | 249                | 53                | 231           |                      |
| 6            | 57½            | 195.18                       | 2.35                                 | 1.64                                     | 1.64   | 82                | 73  | 5                    | 250                | 54                | 230           |                      |
| (END)        | 60             | 197.7580✓                    | 2.097<br>(Δ P) <sup>2</sup>          | 1.568                                    | 1.568  | 70                | 70  |                      |                    |                   | 228.5         |                      |

METHOD 5  
LABORATORY ANALYSIS

Client Lakeside Industries-lacey Run Number 1  
 Sample Location Baghouse outlet  
 Date 8-24-94

"A" Section (Filter)

Filter # 110-582 Tare Weight 0.8136 grams  
 Final Weight 0.9294 grams  
 Net Weight 0.1158 grams ✓

"B" Section (Probe Wash)

Beaker # 150-1608 Tare Weight 65.4787 grams  
 Volume Acetone 140 mls Final Weight 65.5349 grams  
 Net Weight 0.0562 grams ✓

$$140 \times 0.0029 / 1000 = 0.0004g$$

$$\begin{array}{r} -0.0004 \\ 0.0562 \\ \hline 0.0558 \end{array}$$

$$0.1716g \text{ per } 1000$$

"C" Section (Condenser Particulate - Inorganic Catch)

Beaker # 150-1623 Tare Weight 65.2250 grams  
 Volume Water 740/760 mls Final Weight 65.2388 grams  
 Net Weight 0.0138 grams ✓

$$1000 - 0.0008 \quad 760/740 = 1.027$$

$$\begin{array}{r} 0.0138 \\ -0.0008 \\ \hline 0.0142 \end{array} \quad 1.027 = 0.0134$$

"Cx" Section (Condenser Particulate - Organic Catch)

Beaker # 150-1610 Tare Weight 65.6427 grams  
 Volume CH<sub>2</sub>Cl<sub>2</sub> 150 mls Final Weight 65.6424 grams  
 Net Weight 0 grams ✓

$$\begin{array}{r} 0.1858g \\ -0.0002 \\ \hline 0.1856 \end{array}$$

"D" Section (Final Acetone Rinse of Impingers)

Beaker # 150-1609 Tare Weight 65.5389 grams  
 Volume Acetone 70 mls Final Weight 65.5381 grams  
 Net Weight 0 grams ✓

$$70 \times 0.0029 / 1000 = 0.0002$$

$$\begin{array}{r} 0.0134 \\ -0.0002 \\ \hline 0.0132 \\ 0.1716 \\ \hline 0.1848 \end{array} \quad \begin{array}{l} \text{Back} \\ \text{Inout} \\ +41 \end{array}$$

Client Lakeside  
 Location Lacey WA  
 Sample Site BAH House out  
 Stack Diameter 37.375 X 31  
 Date 8-24  
 Operators EAR  
 Run I.D. R-2 m5/814

## QA FORMS COMPLETED

Stack Schematic \_\_\_\_\_  
 Sample Train \_\_\_\_\_  
 Pitot Tube Insp. \_\_\_\_\_  
 Magnahelic Cal. \_\_\_\_\_  
 Temp. Probe Cal. \_\_\_\_\_  
 Gas Meter Calib. \_\_\_\_\_

Start Time 1233  
 Stop Time 1345  
 Barometric \_\_\_\_\_  
 Pressure "Hg 29.95  
 Static Pres "H<sub>2</sub>O +2.6  
 Production Rate \_\_\_\_\_

## EQUIPMENT CHECKS

Initial/Final  
 Leak Rate cfm .002 / .008  
 Leak Test Vacuum 9" / 14"  
☒ Pitots, Pre Leak Ck  
☒ Pitots, Post Leak Ck  
☐ Gas Sampling System  
☒ Integrated Bag  
 M5 Rinse Acetone/H<sub>2</sub>O/Other \_\_\_\_\_

Filter # \_\_\_\_\_ Box # S-2

|                               | Final          | Initial      | Net  |
|-------------------------------|----------------|--------------|------|
|                               | Wt.            | Wt.          | Wt.  |
|                               | gram           | gram         | gram |
| #1 Imp.                       | <u>950.8</u>   | <u>645.8</u> | =    |
| #2 Imp.                       | <u>759.1</u>   | <u>638.0</u> | =    |
| #3 Imp.                       | <u>546.1</u>   | <u>534.5</u> | =    |
| #4 Imp.                       | _____          | _____        | =    |
| #5 Imp.                       | _____          | _____        | =    |
| #6 S.G.                       | <u>872.2</u>   | <u>848.9</u> | =    |
| Total H <sub>2</sub> O Volume | <u>461</u> ✓ g |              |      |

## SAMPLING PARAMETERS

% Moisture 26%  
 Meter Temp. 78  
 Stack Temp. 225  
 Δ H@ 1805 Y 1.002  
 Pitot # \_\_\_\_\_ Side # \_\_\_\_\_  
 Cp .84  
 Nozzle Diameter .238 inch  
 D<sub>1</sub> .238 D<sub>2</sub> .239 D<sub>3</sub> .237  
 K Factor \_\_\_\_\_

| Sample Point | Elap Time Min. | Dry Gas Meter Reading Cu.Ft. | Pitot Reading Δ P " H <sub>2</sub> O | Orifice Setting (Δ H) " H <sub>2</sub> O |        | Gas Meter Temp °F |     | Pump Vac. Gauge " Hg | Filter Box Temp °F | Imp. Exit Temp °F | Stack Temp °F | O <sub>2</sub> % |                      |
|--------------|----------------|------------------------------|--------------------------------------|------------------------------------------|--------|-------------------|-----|----------------------|--------------------|-------------------|---------------|------------------|----------------------|
|              |                |                              |                                      | Ideal                                    | Actual | In                | Out |                      |                    |                   |               |                  |                      |
| A            | 1              | 0                            | 198.162                              | 1.01                                     | .71    | .71               | 73  | 73                   | 3                  | 256               | 67            | 230              |                      |
|              | 2              | 2½                           | 199.99                               | 1.15                                     | .80    | .80               | 75  | 73                   | 3                  | 242               | 60            | 229              |                      |
|              | 3              | 5                            | 201.7                                | 1.44                                     | 1.04   | 1.04              | 76  | 73                   | 4                  | 242               | 58            | 229              |                      |
|              | 4              | 7½                           | 203.74                               | 2.35                                     | 1.64   | 1.64              | 79  | 73                   | 5                  | 252               | 54            | 230              |                      |
|              | 5              | 10                           | 206.17                               | 3.80                                     | 2.65   | 2.65              | 82  | 74                   | 7                  | 247               | 52            | 232              |                      |
|              | 6              | 12½                          | 209.34                               | 3.84                                     | 3.14   | 3.14              | 83  | 74                   | 8                  | 246               | 52            | 231              | CO <sub>2</sub> 5.8% |
| B            | 1              | 15                           | 212.78                               | .85                                      | .59    | .59               | 80  | 75                   | 3                  | 240               | 60            | 230              | O <sub>2</sub> 12.8% |
|              | 2              | 17½                          | 214.41                               | 1.05                                     | .73    | .73               | 81  | 76                   | 3                  | 230               | 57            | 230              | CO NA                |
|              | 3              | 20                           | 216.11                               | 1.50                                     | 1.05   | 1.05              | 81  | 76                   | 4                  | 244               | 56            | 230              |                      |
|              | 4              | 22½                          | 218.16                               | 2.45                                     | 1.71   | 1.71              | 83  | 76                   | 4                  | 239               | 56            | 230              |                      |
|              | 5              | 25                           | 219.99                               | 3.90                                     | 2.74   | 2.74              | 86  | 77                   | 7½                 | 234               | 54            | 230              |                      |
|              | 6              | 27½                          | 223.78                               | 4.62                                     | 3.26   | 3.26              | 89  | 78                   | 9                  | 221               | 55            | 231              |                      |
| C            | 1              | 30                           | 227.485                              | .97                                      | .69    | .69               | 84  | 78                   | 3                  | 231               | 57            | 229              |                      |
|              | 2              | 32½                          | 229.14                               | 1.25                                     | .88    | .88               | 85  | 78                   | 4                  | 232               | 56            | 231              |                      |
|              | 3              | 35                           | 231.02                               | 1.62                                     | 1.14   | 1.14              | 85  | 79                   | 4                  | 234               | 57            | 231              |                      |
|              | 4              | 37½                          | 233. —                               | 2.55                                     | 1.80   | 1.80              | 87  | 79                   | 6                  | 233               | 57            | 233              |                      |
|              | 5              | 40                           | 235.97                               | 3.78                                     | 2.67   | 2.67              | 90  | 79                   | 8                  | 240               | 59            | 233              |                      |
|              | 6              | 42½                          | 238.98                               | 3.85                                     | 2.72   | 2.72              | 92  | 80                   | 8                  | 236               | 63            | 234              |                      |
| D            | 1              | 45                           | 242.991                              | 1.28                                     | .90    | .90               | 87  | 80                   | 4                  | 232               | 65            | 232              |                      |
|              | 2              | 47½                          | 244.18                               | 1.58                                     | 1.12   | 1.12              | 88  | 81                   | 4½                 | 232               | 67            | 231              |                      |
|              | 3              | 50                           | 246.32                               | 2.19                                     | 1.55   | 1.55              | 89  | 82                   | 5½                 | 232               | 64            | 232              |                      |
|              | 4              | 52½                          | 248.79                               | 2.55                                     | 1.80   | 1.80              | 90  | 82                   | 6                  | 230               | 63            | 232              |                      |
|              | 5              | 55                           | 251.50                               | 2.49                                     | 1.76   | 1.76              | 91  | 82                   | 6                  | 245               | 62            | 232              |                      |
|              | 6              | 57½                          | 254. —                               | 2.39                                     | 1.68   | 1.68              | 91  | 82                   | 6                  | 235               | 61            | 232              |                      |
| End          | 60             | 256.940                      | 2.154                                | 1.615                                    | 1.615  | 81                | 81  |                      |                    |                   | 231           |                  |                      |
|              |                | 58.678                       | (Δ P) 2                              |                                          |        |                   |     |                      |                    |                   |               |                  |                      |

METHOD 5  
LABORATORY ANALYSIS

Client Lakeside Industries - Lacey Run Number 2  
 Sample Location Baghouse Outlet  
 Date 8-24-94

"A" Section (Filter)

Filter # 110-589 Tare Weight 0.8177 grams  
 Final Weight 0.9345 grams  
 Net Weight 0.1168 grams

"B" Section (Probe Wash)

Beaker # 150-1611 Tare Weight 66.7606 grams  
 Volume Acetone 170 mls Final Weight 66.8159 grams  
 Net Weight 0.0553 grams

$$170 \times 0.0029 / 1000 = 0.0005g$$

"C" Section (Condenser Particulate - Inorganic Catch)

Beaker # 150-1624 Tare Weight 65.1514 grams  
 Volume Water 720/740 mls Final Weight 65.1675 grams  
 Net Weight 0.0161 grams \* 1.028  
0.0166

$$\frac{740}{720} = 1.028$$

"Cx" Section (Condenser Particulate - Organic Catch)

Beaker # 150-1613 Tare Weight 66.9948 grams  
 Volume CH<sub>2</sub>Cl<sub>2</sub> 150 mls Final Weight 66.9939 grams  
 Net Weight 0 grams \* 1.028

"D" Section (Final Acetone Rinse of Impingers)

Beaker # 150-1612 Tare Weight 67.3012 grams  
 Volume Acetone 75 mls Final Weight 67.3004 grams  
 Net Weight 0 grams

$$75 \times 0.0029 / 1000 = 0.0002g$$

$$\begin{aligned} &+ 0.1168 \\ &+ 0.0548 \\ &+ 0.0166 \\ &+ 0.0002 \\ &= 0.1884 \end{aligned}$$

$$\begin{aligned} &+ 0.0166 \\ &- 0.0007 \\ &- 0.0002 \\ &= 0.0157g \text{ back} \end{aligned}$$

Client LAKE SIDE  
 Location LACEY  
 Sample Site B&H House  
outlet  
 Stack Diameter 37.325 x 31  
 Date 8-24-94  
 Operators BAL  
 Run I.D. R-3 MS/BH

## EQUIPMENT CHECKS

Initial/Final  
 Leak Rate cfm .015 / .007  
 Leak Test Vacuum 9" / 12"  
☒ Pitots, Pre Leak Ck  
☒ Pitots, Post Leak Ck  
☐ Gas Sampling System  
☒ Integrated Bag  
 M5 Rinse Acetone/H<sub>2</sub>O/Other

## QA FORMS COMPLETED

Stack Schematic \_\_\_\_\_  
 Sample Train \_\_\_\_\_  
 Pitot Tube Insp. \_\_\_\_\_  
 Magnehelic Cal. \_\_\_\_\_  
 Temp. Probe Cal. \_\_\_\_\_  
 Gas Meter Calib. \_\_\_\_\_

Filter # \_\_\_\_\_ Box # W-4

|                               | Final    | Initial | Net  |
|-------------------------------|----------|---------|------|
|                               | Wt.      | Wt.     | Wt.  |
|                               | gram     | gram    | gram |
| #1 Imp.                       | 785.7    | 593.8   | =    |
| #2 Imp.                       | 888.6    | 640.3   | =    |
| #3 Imp.                       | 589.5    | 541.7   | =    |
| #4 Imp.                       | -        | -       | =    |
| #5 Imp.                       | 741.4    | 769.2   | =    |
| #6 S.G.                       | 720      | 769.2   | =    |
| Total H <sub>2</sub> O Volume | 510.20 g |         |      |

Start Time 14:43  
 Stop Time 15:54  
 Barometric Pressure "Hg 29.95  
 Static Pres "H<sub>2</sub>O +2.5  
 Production Rate \_\_\_\_\_

## SAMPLING PARAMETERS

% Moisture 26%  
 Meter Temp. 78  
 Stack Temp. 225  
 Δ H@ .805 Y 1.002  
 Pitot # \_\_\_\_\_ Side # \_\_\_\_\_  
 Cp .84  
 Nozzle Diameter .238 inch  
 D<sub>1</sub> .238 D<sub>2</sub> .237 D<sub>3</sub> .239  
 K Factor \_\_\_\_\_

| Sample Point | Elap Time Min. | Dry Gas Meter Reading Cu.Ft. | Pitot Reading Δ P " H <sub>2</sub> O | Orifice Setting (Δ H) " H <sub>2</sub> O |        | Gas Meter Temp °F |     | Pump Vac. Gauge " Hg | Filter Box Temp °F | Imp. Exit Temp °F | Stack Temp °F | O <sub>2</sub> % |       |
|--------------|----------------|------------------------------|--------------------------------------|------------------------------------------|--------|-------------------|-----|----------------------|--------------------|-------------------|---------------|------------------|-------|
|              |                |                              |                                      | Ideal                                    | Actual | In                | Out |                      |                    |                   |               |                  |       |
| A 1          | 0              | 257.697                      | .97                                  | .68                                      | .68    | 79                | 79  | 5                    | 235                | 62                | 232           |                  |       |
| 2            | 2 1/2          | 260.29                       | 1.05                                 | .73                                      | .73    | 81                | 80  | 7                    | 234                | 55                | 233           |                  |       |
| 3            | 5              | —                            | 1.52                                 | 1.06                                     | 1.06   | 84                | 80  | 4                    | 241                | 53                | 233           |                  |       |
| 4            | 7 1/2          | —                            | 2.89                                 | 1.61                                     | 1.61   | 85                | 80  | 5                    | 234                | 53                | 234           |                  |       |
| 5            | 10             | 267.75                       | 4.15                                 | 2.92                                     | 2.92   | 88                | 80  | 11                   | 233                | 53                | 236           |                  |       |
| 6            | 12 1/2         | 270.91                       | 4.71                                 | 3.31                                     | 3.1    | 91                | 81  | 11                   | 234                | 54                | 236           | CO <sub>2</sub>  | 5.8%  |
| B 1          | 15             | 274.411                      | .83                                  | .58                                      | .58    | 86                | 80  | 3                    | 239                | 57                | 232           | O <sub>2</sub>   | 12.5% |
| 2            | 17 1/2         | 275.72                       | 1.05                                 | .74                                      | .74    | 82                | 80  | 3                    | 238                | 56                | 233           | CO               | NA    |
| 3            | 20             | 277.63                       | 1.55                                 | 1.09                                     | 1.09   | 84                | 82  | 4                    | 234                | 57                | 235           |                  |       |
| 4            | 22 1/2         | 279.70                       | 2.49                                 | 1.76                                     | 1.76   | 88                | 82  | 6 1/2                | 241                | 55                | 235           |                  |       |
| 5            | 25             | 282. —                       | 4.19                                 | 2.97                                     | 2.97   | 91                | 83  | 11 1/2               | 233                | 53                | 237           |                  |       |
| 6            | 27 1/2         | —                            | 4.20                                 | 2.97                                     | 2.97   | 93                | 83  | 11 1/2               | 231                | 55                | 235           |                  |       |
| C 1          | 30             | 289.134                      | .86                                  | .68                                      | .68    | 88                | 83  | 3 1/2                | 234                | 61                | 235           |                  |       |
| 2            | 32 1/2         | 290.69                       | 1.19                                 | .84                                      | .84    | 88                | 84  | 4                    | 230                | 59                | 232           |                  |       |
| 3            | 35             | 292.55                       | 1.79                                 | 1.27                                     | 1.27   | 88                | 84  | 4                    | 233                | 59                | 233           |                  |       |
| 4            | 37 1/2         | 294.82                       | 2.65                                 | 1.88                                     | 1.88   | 89                | 84  | 7                    | 232                | 58                | 233           |                  |       |
| 5            | 40             | 297.91                       | 3.61                                 | 2.56                                     | 2.56   | 91                | 84  | 10                   | 232                | 58                | 234           |                  |       |
| 6            | 42 1/2         | 300.45                       | 3.60                                 | 2.55                                     | 2.55   | 93                | 84  | 10                   | 232                | 60                | 234           |                  |       |
| D 1          | 45             | 303.922                      | 1.10                                 | .78                                      | .78    | 87                | 83  | 4                    | 236                | 61                | 230           |                  |       |
| 2            | 47 1/2         | 305.69                       | 1.65                                 | 1.17                                     | 1.17   | 88                | 84  | 5                    | 232                | 62                | 230           |                  |       |
| 3            | 50             | 307.88                       | 2.15                                 | 1.52                                     | 1.52   | 88                | 84  | 6 1/2                | 234                | 61                | 232           |                  |       |
| 4            | 52 1/2         | 310.6 —                      | 2.95                                 | 1.81                                     | 1.81   | 89                | 84  | 7                    | 234                | 57                | 233           |                  |       |
| 5            | 55             | 313.87                       | 2.73                                 | 1.93                                     | 1.93   | 90                | 84  | 8                    | 234                | 56                | 236           |                  |       |
| 6            | 57 1/2         | 315. —                       | 2.46                                 | 1.74                                     | 1.74   | 91                | 83  | 8                    | 236                | 54                | 236           |                  |       |
| END          | 60             | 318.887                      |                                      |                                          |        |                   |     |                      |                    |                   |               |                  |       |
|              |                | 60.990                       | 2.16                                 | 1.018                                    | 1.018  | 85.2              |     |                      |                    |                   | 233.7         |                  |       |

METHOD 5  
LABORATORY ANALYSIS

Client Lakeside Industries - Lacey Run Number 3  
 Sample Location Beghouse Outlet  
 Date 8-24-94

"A" Section (Filter)

Filter # 110-583 Tare Weight 0.8202 grams  
 Final Weight 0.9156 grams  
 Net Weight 0.0954 grams

"B" Section (Probe Wash)

Beaker # 150-1614 Tare Weight 66.9630 grams  
 Volume Acetone 230 mls Final Weight 67.0306 grams  
 Net Weight 0.0676 grams

$230 \text{ ml} \times 0.00029 \text{ ug/ml} / 1000 = 0.0007 \text{ g}$  due to blank  
"C" Section (Condenser Particulate - Inorganic Catch)  
 $0.0669 \text{ g} + 0.0954 = 0.1623 \text{ g}$   
 (front half)

Beaker # 150-1625 Tare Weight 65.1549 grams  
 Volume Water 820/840 mls Final Weight 65.1836 grams  
 Net Weight 0.0287 grams \* 1.024  
 $840/820 = 1.024$   
 $0.0287 \times 1.024 = 0.0294$  ✓

"Cx" Section (Condenser Particulate - Organic Catch)  
 $0.0294$   
 $0.0294 + 0.0954 = 0.1248$   
 $0.0294 + 0.0954 = 0.1248$   
 $0.0294 + 0.0954 = 0.1248$

Beaker # 150-1616 Tare Weight 65.7992 grams  
 Volume  $\text{CH}_2\text{Cl}_2$  150 mls Final Weight 65.7990 grams  
 Net Weight 0 grams \* 1.024

"D" Section (Final Acetone Rinse of Impingers)

Beaker # 150-1615 Tare Weight 65.8874 grams  
 Volume Acetone 95 mls Final Weight 65.8872 grams  
 Net Weight -0.0002 grams

$95 \times 0.00029 / 1000 = 0.0003$

$0.1623 \text{ g F}$   
 $+ 0.0283 \text{ g B}$   
 $\text{total} = 0.1906 \text{ g}$



LAKESIDE  
LACEY

34

METHOD 5  
LABORATORY ANALYSIS

Acetone Blank

Beaker # 150-1617  
Volume Acetone 140 mls

Tare Weight 66.4545 grams  
Final Weight 66.4549 grams  
Net Weight 0.0004 grams

~~140.4549 ml / 66.4545 g~~

Distilled, Deionized Water Blank

$$0.4 \text{ mg} / 140 \text{ ml} = 0.0029 \text{ mg/ml}$$

Beaker # 150-1626  
Volume Water 250 mls

Tare Weight 65.1471 grams  
Final Weight 65.1477 grams  
Net Weight 0.0006 grams

~~250.0024 ml / 65.1471 g~~

$$0.6 \text{ mg} / 250 \text{ ml} = 0.0024 \text{ mg/ml}$$

Methylene Chloride (CH<sub>2</sub>Cl<sub>2</sub>) Blank

Beaker # 150-1618  
Volume CH<sub>2</sub>Cl<sub>2</sub> 150 mls

Tare Weight 66.9341 grams  
Final Weight 66.9331 grams  
Net Weight -0.0010 grams

0.0

**SAMPLE TRAIN INFORMATION**

Fill out one sheet per site and per test type.

CLIENT: LAKEVIEW INDUSTRIES  
LOCATION: LAKESIDE, VA  
SITE: Bldg 1000  
TEST TEAM: Ray [unclear] DATE(S): MS 6/84  
RUN #S: 1, 2, 3, 4 TYPE: MS 6/84  
Probe/Filter Temperature: ☒ 248+25 F ☐ 320 F ☐ Other  
Impinger Temperature: ☒ <68 F ☐ Other

THIMBLE: ☐ yes ☒ no NOZZLE TYPE: ☐ quartz ☒ steel ☐ none

PROBE LINER: ☐ quartz ☐ glass ☒ steel ☐ teflon

PROBE TYPE: ☒ regular ☐ water-cooled

FRONT-HALF FILTER: ☒ yes ☐ no SIZE (mm): ☐ 90 ☒ 110 ☐ 125 ☐ other

FRONT-HALF FILTER MEDIA: ☒ quartz fiber ☐ glass fiber ☐ teflon

SUPPORT: ☐ steel ☐ glass frit ☒ teflon GASKET: ☒ silicon ☐ teflon

BACK-HALF FILTER: ☐ yes ☒ no

BACK-HALF FILTER MEDIA: ☐ quartz fiber ☐ glass fiber ☐ teflon ☐ tared ☐ untared

NOTE: Show the back-half filter location with an arrow on the table below.

| CONTENTS            | Initial Volume (mL) | Clean-up Solution Used | Bottle Type | Comments |
|---------------------|---------------------|------------------------|-------------|----------|
| Nozzle/Probe Rinse  |                     | ACETONE                | 500mL W.M.  |          |
| Filter              |                     |                        |             |          |
| #1 H <sub>2</sub> O | 100                 | H <sub>2</sub> O/ACE   | 1L/250mL    |          |
| #2 H <sub>2</sub> O | 100                 | ↓                      | ↓           |          |
| #3 M.T.             | -                   | ↓                      | ↓           |          |
| #4 SG.              | -                   |                        |             |          |
| #5                  |                     |                        |             |          |
| #6                  |                     |                        |             |          |
| #7                  |                     |                        |             |          |

IF THIS INFORMATION IS NOT ACCURATE FOR ALL RUNS, NOTE ALL EXCEPTIONS.

**GAS BAG SAMPLE DATA SHEET**

CLIENT: LAKE SIDE

LOCATION: LACEY

SAMPLE SITE: BAGHOUSE outlet

DATE: 8-24

NUMBER/TYPE OF TESTS: 1, 2, 3 NUMBER OF BAGS: 3

SAMPLED BY: ERL

SUBMITTED BY: ERL

ANALYZED BY: ERL DATE: 8/23

| BAG NUMBER/IDENTIFICATION | CO <sub>2</sub><br>% | O <sub>2</sub><br>% | CO<br>ppm | F <sub>o</sub> | NOTES |
|---------------------------|----------------------|---------------------|-----------|----------------|-------|
| R-1                       | 5.5                  | 13.0                |           | 1.44           |       |
| R-2                       | 5.8                  | 12.8                |           | 1.40           |       |
| R-3                       | 5.8                  | 12.5                |           | 1.45           |       |
|                           |                      |                     |           |                |       |
|                           |                      |                     |           |                |       |
|                           |                      |                     |           |                |       |

CO<sub>2</sub> ANALYZER: SERVOMEX

CALIBRATION GAS: 5.98 - 12.01

O<sub>2</sub> ANALYZER: SERVOMEX

CALIBRATION GAS: 14.28 - 19.03

CO ANALYZER: \_\_\_\_\_

CALIBRATION GAS: \_\_\_\_\_

**APPENDIX C**  
**Supporting Information**

**SOURCE AND PROCESS INFORMATION**

CLIENT: Lakeside Industries  
LOCATION: Lacey  
SAMPLE SITE: stack  
TEST DATE: 24 Aug 94  
  
CLIENT CONTACT: Forest Lane  
OPERATION PERSONNEL: "Smokey"  
AGENCY REPRESENTATIVE: Ray Lawrence  
AM TEST-AIR QUALITY PERSONNEL: Robert Moody ↗  
  
TYPE OF PROCESS: Hot-mix Asphalt  
EQUIPMENT MANUFACTURER: Madson  
MODEL: \_\_\_\_\_ CONSTRUCTED/INSTALLED: 1977?  
IDENTIFICATION NO.: \_\_\_\_\_ DATE LAST TESTED: 1989  
PROCESS RATE: 270 TPH  
FUEL FIRING RATE: 590 gal/hour TYPE OF FUEL: Diesel  
  
TYPE OF EMISSION CONTROL DEVICE: Baghouse  
EQUIPMENT MANUFACTURER: W.A.G.  
PURPOSE OF TESTING: Routine 5-yr test.  
EMISSION STANDARD (in units): .04 gr/DSCM

**PROCESS DESCRIPTION:**

- ① aggregate dried in drum dryer
- ② elevated to batch tower
- ③ sorted and mixed with asphalt.
- ④ asphalt elevated to silo.
- ⑤ fines exhaust from ~~baghouse~~ dryer to baghouse
- ⑥ fines from baghouse routed back to mix or to collection bin.


PROCESS SHUTDOWNS/PROBLEMS: \_\_\_\_\_

Forest Lane  
AUTHORIZED SIGNATURE

SOURCE TEST OBSERVATION CHECKLIST  
ASPHALT PLANTS WITH BAGHOUSE

39  
AMTEST  
AIR QUALITY, INC

CLIENT: Lakeside Industries  
LOCATION: Lacey  
SAMPLE SITE: stack  
TEST DATE: 24 Aug 94  
TYPE OF PLANT: Hot-Mix Batch Plant  
EQUIPMENT MANUFACTURER: Madson  
MODEL: \_\_\_\_\_ CONSTRUCTED/INSTALLED: 1977?  
IDENTIFICATION NO.: \_\_\_\_\_ DATE LAST TESTED: \_\_\_\_\_  
PROCESS RATE: 270 TPH DISCHARGE TEMP °F: \_\_\_\_\_  
FUEL FIRING RATE: 590 gal/hr TYPE OF FUEL: diesel  
A/C INJECTION LOCATION: pug mill  
FINES IN GRAVEL (-200 mesh): 5-7 %  
GRAVEL MOISTURE: 4-6 % ASPHALT TYPE: AR 4000  
DENSITY \_\_\_\_\_ lb/gal FLASHPOINT °F 450°  
TYPE OF EMISSION CONTROL DEVICE: Baghouse  
EQUIPMENT MANUFACTURER: W.A.G. MODEL: Model 8  
IDENTIFICATION NO.: \_\_\_\_\_  
BAG MATERIAL: Nomex 14 oz. NO. OF BAGS: 1180  
BAG SIZE: 8' DATE BAGS LAST CHANGED: 1990  
TYPE OF BAG CLEANING: Reverse Pulse  
BAGHOUSE PRESSURE  $\Delta P$  = 5.5 " H<sub>2</sub>O (OR PRESSURE DROP ACROSS BAGHOUSE)  
CLEANING CYCLE DURATION: \_\_\_\_\_  
DISPOSITION OF COLLECTED DUST: Return to mix / collection bin  
ADDITIONAL INFORMATION: \_\_\_\_\_




Joey Dane  
AUTHORIZED SIGNATURE

# **CROSS SECTIONAL AREA**

| Traverse Point | Distance (inches) |
|----------------|-------------------|
| 1              | 7.12              |
| 2              | 13.36             |
| 3              | 19.60             |
| 4              | 25.84             |
| 5              | 32.08             |
| 6              | 38.32             |

| Port | Distance (inches) |
|------|-------------------|
| A    | 3.88              |
| B    | 11.63             |
| C    | 19.38             |
| D    | 27.13             |



# **STACK DIMENSIONS**

37.375 inch x 31 inch rectangular vent

4 ports located along the 31 inch side

A = 23.5 inches downstream

B = 281 inches upstream




Figure 1. Location of sampling ports and traverse points.




Figure 2 . Method 5 Sample Train.

1. Sampling nozzle
2. Sampling probe sheath
3. Heated sample probe liner
4. Out of stack filter assembly
5. Heated filter compartment maintained at  $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$   
(or temperature specified in 40 CFR subpart)
6. Impinger case - contains ice during sampling
7. First impinger containing 100 ml  $\text{H}_2\text{O}$
8. Modified Greenburg-Smith impinger containing 100 ml  $\text{H}_2\text{O}$
9. Third impinger - empty
10. Fourth impinger containing indicating silica gel desiccant
11. Impinger exit gas temperature sensor
12. Umbilical cord - vacuum line
13. Vacuum gauge
14. Fine and coarse adjustment valves
15. Leak free pump
16. By-pass valve
17. Dry gas meter with inlet and outlet temperature sensors
18. Orifice meter with magnehelic gauges
19. S-type pitot tube with magnehelic gauges
20. Fluke multi-channel digital thermocouple indicator

## METHOD 1 - LOCATION OF TRAVERSE POINTS

### Circular Stacks




Figure 1-3. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points indicated.

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

(Percent of stack diameter from inside wall to traverse point)

| Traverse point number on a diameter | Number of traverse points on a diameter— |      |      |      |      |      |      |      |      |      |      |      |
|-------------------------------------|------------------------------------------|------|------|------|------|------|------|------|------|------|------|------|
|                                     | 2                                        | 4    | 6    | 8    | 10   | 12   | 14   | 16   | 18   | 20   | 22   | 24   |
| 1                                   | 14.6                                     | 6.7  | 4.4  | 3.2  | 2.6  | 2.1  | 1.8  | 1.6  | 1.4  | 1.3  | 1.1  | 1.1  |
| 2                                   | 85.4                                     | 25.0 | 14.6 | 10.5 | 8.2  | 6.7  | 5.7  | 4.9  | 4.4  | 3.9  | 3.5  | 3.2  |
| 3                                   |                                          | 75.0 | 29.6 | 19.4 | 14.6 | 11.8 | 9.9  | 8.5  | 7.5  | 6.7  | 6.0  | 5.5  |
| 4                                   |                                          | 93.3 | 70.4 | 32.3 | 22.6 | 17.7 | 14.6 | 12.5 | 10.9 | 9.7  | 8.7  | 7.9  |
| 5                                   |                                          |      | 85.4 | 67.7 | 34.2 | 25.0 | 20.1 | 16.9 | 14.6 | 12.9 | 11.6 | 10.5 |
| 6                                   |                                          |      | 95.6 | 80.6 | 65.8 | 35.6 | 26.9 | 22.0 | 18.8 | 16.5 | 14.6 | 13.2 |
| 7                                   |                                          |      |      | 89.5 | 77.4 | 64.4 | 36.6 | 28.3 | 23.6 | 20.4 | 18.0 | 16.1 |
| 8                                   |                                          |      |      | 96.8 | 85.4 | 75.0 | 63.4 | 37.5 | 29.6 | 25.0 | 21.8 | 19.4 |
| 9                                   |                                          |      |      |      | 91.8 | 82.3 | 73.1 | 62.5 | 38.2 | 30.6 | 26.2 | 23.0 |
| 10                                  |                                          |      |      |      | 97.4 | 88.2 | 79.9 | 71.7 | 61.8 | 38.8 | 31.5 | 27.2 |
| 11                                  |                                          |      |      |      |      | 93.3 | 85.4 | 78.0 | 70.4 | 61.2 | 39.3 | 32.3 |
| 12                                  |                                          |      |      |      |      | 97.9 | 90.1 | 83.1 | 76.4 | 69.4 | 60.7 | 39.8 |
| 13                                  |                                          |      |      |      |      |      | 94.3 | 87.5 | 81.2 | 75.0 | 68.5 | 60.2 |
| 14                                  |                                          |      |      |      |      |      | 98.2 | 91.5 | 85.4 | 79.6 | 73.8 | 67.7 |
| 15                                  |                                          |      |      |      |      |      |      | 95.1 | 89.1 | 83.5 | 78.2 | 72.8 |
| 16                                  |                                          |      |      |      |      |      |      | 98.4 | 92.5 | 87.1 | 82.0 | 77.0 |
| 17                                  |                                          |      |      |      |      |      |      |      | 95.6 | 90.3 | 85.4 | 80.6 |
| 18                                  |                                          |      |      |      |      |      |      |      | 98.6 | 93.3 | 88.4 | 83.9 |

### Rectangular Stacks

For a rectangular cross section, an equivalent diameter ( $D_e$ ) shall be calculated from the following equation, to determine the upstream and downstream distances:

$$D_e = \frac{2LW}{(L+W)}$$

where  $L$ =length and  $W$ =width.




Figure 1-4. Example showing rectangular stack cross section divided into 12 equal areas, with a traverse point at centroid of each area.

## METHOD 1 - MINIMUM NUMBER OF TRAVERSE POINTS




Figure 1-1. Minimum number of traverse points for particulate traverses.




Figure 1-2. Minimum number of traverse points for velocity (nonparticulate) traverses.

## METHOD 2 - STACK GAS VELOCITY AND VOLUMETRIC FLOW CALCULATIONS

### 5.1 Nomenclature.

$A$  = Cross-sectional area of stack,  $m^2$  ( $ft^2$ ).  
 $B_w$  = Water vapor in the gas stream (from Method 5 or Reference Method 4), proportion by volume.  
 $C_p$  = Pitot tube coefficient, dimensionless.  
 $K_p$  = Pitot tube constant.

$$34.97 \frac{m}{sec} \left[ \frac{(g/g\text{-mole})(mm\ Hg)}{(^{\circ}K)(mm\ H_2O)} \right]^{1/2}$$

for the metric system and

$$85.49 \frac{ft}{sec} \left[ \frac{(lb/lb\text{-mole})(in.\ Hg)}{(^{\circ}R)(in.\ H_2O)} \right]^{1/2}$$

for the English system.

$M_d$  = Molecular weight of stack gas, dry basis (see Section 3.6)  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).  
 $M_w$  = Molecular weight of stack gas, wet basis,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).  
 $= M_d(1 - B_w) + 18.0 B_w$

Eq. 2-5

$P_{bar}$  = Barometric pressure at measurement site, mm Hg (in. Hg).

$P_s$  = Stack static pressure, mm Hg (in. Hg).

$P_t$  = Absolute stack gas pressure, mm Hg (in. Hg).

$= P_{bar} + P_s$

Eq. 2-6

Eq. 2-6

$P_{std}$  = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).

$Q_{std}$  = Dry volumetric stack gas flow rate corrected to standard conditions,  $dscm/hr$  ( $dscf/hr$ ).

$t_s$  = Stack temperature,  $^{\circ}C$  ( $^{\circ}F$ ).

$T_s$  = Absolute stack temperature,  $^{\circ}K$ , ( $^{\circ}R$ ).  
 $= 273 + t_s$  for metric.

Eq. 2-7

$= 460 + t_s$  for English.

Eq. 2-8

$T_{std}$  = Standard absolute temperature, 293  $^{\circ}K$  (528  $^{\circ}R$ ).

$v_s$  = Average stack gas velocity,  $m/sec$  ( $ft/sec$ ).

$\Delta p$  = Velocity head of stack gas, mm  $H_2O$  (in.  $H_2O$ ).

3,600 = Conversion factor,  $sec/hr$ .

18.0 = Molecular weight of water,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).

5.2 Average Stack Gas Velocity.

$$v_s = K_p C_p (\sqrt{\Delta p})^{0.5} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

Equation 2-9

5.3 Average Stack Gas Dry Volumetric Flow Rate.

$$Q_{std} = 3,600(1 - B_w)v_s A \left( \frac{T_{std}}{T_s (avg)} \right) \left( \frac{P_s}{P_{std}} \right)$$

Eq. 2-10

## METHOD 3 - MOLECULAR WEIGHT AND EXCESS AIR CALCULATIONS

### 6.1 Nomenclature.

$M_d$  = Dry molecular weight,  $g/g\text{-mole}$  ( $lb/lb\text{-mole}$ ).

%EA = Percent excess air.

%CO<sub>2</sub> = Percent CO<sub>2</sub> by volume (dry basis).

%O<sub>2</sub> = Percent O<sub>2</sub> by volume (dry basis).

%CO = Percent CO by volume (dry basis).

%N<sub>2</sub> = Percent N<sub>2</sub> by volume (dry basis).

0.264 = Ratio of O<sub>2</sub> to N<sub>2</sub> in air,  $v/v$ .

0.280 = Molecular weight of N<sub>2</sub> or CO, divided by 100.

0.320 = Molecular weight of O<sub>2</sub>, divided by 100.

0.440 = Molecular weight of CO<sub>2</sub>, divided by 100.

6.2 Percent Excess Air. Calculate the percent excess air (if applicable), by substituting the appropriate values of percent O<sub>2</sub>, CO, and N<sub>2</sub> (obtained from Section 4.1.3 or 4.2.4) into Equation 3-1.

% EA =

$$\frac{\%O_2 - 0.5\% CO}{0.264\% N_2 (\%O_2 - 0.5\% CO)} \times 100$$

Eq. 3-1

NOTE: The equation above assumes that ambient air is used as the source of O<sub>2</sub>, and that the fuel does not contain appreciable amounts of N<sub>2</sub> (as do coke oven or blast furnace gases). For those cases when appreciable amounts of N<sub>2</sub> are present (coal, oil, and natural gas do not contain appreciable amounts of N<sub>2</sub>) or when oxygen enrichment is used, alternate methods, subject to approval of the Administrator, are required.

6.3 Dry Molecular Weight. Use Equation 3-2 to calculate the dry molecular weight of the stack gas

$$M_d = 0.440(\%CO_2) + 0.320(\%O_2) + 0.280(\%N_2 + \%CO)$$

Eq. 3-2

## METHOD 4 - STACK GAS MOISTURE CALCULATIONS

### 2.3.1 Nomenclature.

$B_w$  = Proportion of water vapor, by volume, in the gas stream.

$M_w$  = Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).

$P_m$  = Absolute pressure (for this method, same as barometric pressure) at the dry gas meter, mm Hg (in. Hg).

$P_{std}$  = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).

$R$  = Ideal gas constant, 0.06236 (mm Hg) (m<sup>3</sup>)/(g-mole) (°K) for metric units and 21.85 (in. Hg) (ft<sup>3</sup>)/(lb-mole) (°R) for English units.

$T_m$  = Absolute temperature at meter, °K (°R).

$T_{std}$  = Standard absolute temperature, 293° K (528°R).

$V_m$  = Dry gas volume measured by dry gas meter, dcm (dcf).

$\Delta V_m$  = Incremental dry gas volume measured by dry gas meter at each traverse point, dcm (dcf).

$V_{m(std)}$  = Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf).

$V_{w(std)}$  = Volume of water vapor condensed corrected to standard conditions, scm (scf).

$V_{w(std)}$  = Volume of water vapor collected in silica gel corrected to standard conditions, scm (scf).

$V_f$  = Final volume of condenser water, ml.

$V_i$  = Initial volume, if any, of condenser water, ml.

$W_f$  = Final weight of silica gel or silica gel plus impinger, g.

$W_i$  = Initial weight of silica gel or silica gel plus impinger, g.

$Y$  = Dry gas meter calibration factor.

$\rho_w$  = Density of water, 0.9982 g/ml (0.002201 lb/ml).

### 2.3.2 Volume of Water Vapor Condensed.

$$V_{w(std)} = \frac{(V_f - V_i) \rho_w R T_{std}}{P_{std} M_w}$$

$$= K_1 (V_f - V_i)$$

Eq. 4-1

$K_1 = 0.001333 \text{ m}^3/\text{ml}$  for metric units

$= 0.04707 \text{ ft}^3/\text{ml}$  for English units

### 2.3.3 Volume of Water Vapor Collected in Silica Gel.

$$V_{w(std)} = \frac{(W_f - W_i) R T_{std}}{P_{std} M_w}$$

$$= K_2 (W_f - W_i)$$

Eq. 4-2

Where:

$K_2 = 0.001335 \text{ m}^3/\text{g}$  for metric units

$= 0.04715 \text{ ft}^3/\text{g}$  for English units

### 2.3.4 Sample Gas Volume.

$$V_{m(std)} = V_m Y \frac{(P_m)(T_{std})}{(P_{std})(T_m)}$$

$$= K_3 Y \frac{V_m P_m}{T_m}$$

Eq. 4-3

Where:

$K_3 = 0.3858 \text{ °K/mm Hg}$  for metric units

$= 17.64 \text{ °R/in. Hg}$  for English units

NOTE: If the post-test leak rate (Section 2.2.6) exceeds the allowable rate, correct the value of  $V_m$  in Equation 4-3, as described in Section 6.3 of Method 5.

### 2.3.5 Moisture Content.

$$B_w = \frac{V_{w(std)} + V_{w(std)}}{V_{w(std)} + V_{w(std)} + V_{m(std)}}$$

Eq. 4-4

NOTE: In saturated or moisture droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one using a value based upon the saturated conditions (see Section 1.2), and another based upon the results of the impinger analysis. The lower of these two values of  $B_w$  shall be considered correct.

## METHOD 5 - PARTICULATE EMISSION CALCULATIONS - (1)

## 6.1 Nomenclature.

$A_n$  = Cross-sectional area of nozzle,  $m^2$  ( $ft^2$ ).  
 $B_{wt}$  = Water vapor in the gas stream, proportion by volume.  
 $C_a$  = Acetone blank residue concentration,  $mg/g$ .  
 $C_s$  = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions,  $g/dscm$  ( $g/dscf$ ).  
 $I$  = Percent of isokinetic sampling.  
 $L_m$  = Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to  $0.0057 m^3/min$  ( $0.02 cfm$ ) or 4 percent of the average sampling rate, whichever is less.  
 $L_n$  = Individual leakage rate observed during the leak check conducted prior to the " $n^{th}$ " component change ( $i=1, 2, 3, \dots, n$ ),  $m^3/min$  ( $cfm$ ).  
 $L_p$  = Leakage rate observed during the post-test leak check,  $m^3/min$  ( $cfm$ ).  
 $m_w$  = Mass of residue of acetone after evaporation,  $mg$ .  
 $m_s$  = Total amount of particulate matter collected,  $mg$ .  
 $M_w$  = Molecular weight of water,  $18.0 g/g\text{-mole}$  ( $18.0 lb/lb\text{-mole}$ ).  
 $P_{bar}$  = Barometric pressure at the sampling site,  $mm\ Hg$  ( $in. Hg$ ).  
 $P_s$  = Absolute stack gas pressure,  $mm\ Hg$  ( $in. Hg$ ).  
 $P_{std}$  = Standard absolute pressure,  $760 mm\ Hg$  ( $29.92 in. Hg$ ).  
 $R$  = Ideal gas constant,  $0.06236 mm\ Hg\text{-}m^3/K\text{-}g\text{-mole}$  ( $21.85 in. Hg\text{-}ft^3/R\text{-}lb\text{-mole}$ ).  
 $T_m$  = Absolute average dry gas meter temperature (see Figure 5-2),  $^{\circ}K$  ( $^{\circ}R$ ).  
 $T_s$  = Absolute average stack gas temperature (see Figure 5-2),  $^{\circ}K$  ( $^{\circ}R$ ).  
 $T_{std}$  = Standard absolute temperature,  $293^{\circ}K$  ( $528^{\circ}R$ ).  
 $V_a$  = Volume of acetone blank,  $ml$ .  
 $V_{aw}$  = Volume of acetone used in wash,  $ml$ .  
 $V_{lt}$  = Total volume of liquid collected in impingers and silica gel (see Figure 5-3),  $ml$ .  
 $V_m$  = Volume of gas sample as measured by dry gas meter,  $dcm$  ( $dscf$ ).  
 $V_{m(d)}$  = Volume of gas sample measured by the dry gas meter, corrected to standard conditions,  $dscm$  ( $dscf$ ).  
 $V_{w(d)}$  = Volume of water vapor in the gas sample, corrected to standard conditions,  $scm$  ( $scf$ ).  
 $v_s$  = Stack gas velocity, calculated by Method 2, Equation 2-9, using data obtained from Method 5,  $m/sec$  ( $ft/sec$ ).  
 $W_a$  = Weight of residue in acetone wash,  $mg$ .  
 $Y$  = Dry gas meter calibration factor.  
 $\Delta H$  = Average pressure differential across the orifice meter (see Figure 5-2),  $mm\ H_2O$  ( $in. H_2O$ ).  
 $\rho_a$  = Density of acetone,  $mg/ml$  (see label on bottle).

$\rho_w$  = Density of water,  $0.9982 g/ml$  ( $0.002201 lb/ml$ ).

$\theta$  = Total sampling time,  $min$ .

$\theta_1$  = Sampling time interval, from the beginning of a run until the first component change,  $min$ .

$\theta_i$  = Sampling time interval, between two successive component changes, beginning with the interval between the first and second changes,  $min$ .

$\theta_p$  = Sampling time interval, from the final ( $n^{th}$ ) component change until the end of the sampling run,  $min$ .

13.6 = Specific gravity of mercury.

60 = Sec/min.

100 = Conversion to percent.

6.2 Average Dry Gas Meter Temperature and Average Orifice Pressure Drop. See data sheet (Figure 5-2).

6.3 Dry Gas Volume. Correct the sample volume measured by the dry gas meter to standard conditions ( $20^{\circ}C$ ,  $760 mm\ Hg$  or  $68^{\circ}F$ ,  $29.92 in. Hg$ ) by using Equation 5-1.

$$V_{m(std)} = V_m Y \left( \frac{T_{std}}{T_m} \right) \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{P_{std}} \right]$$

$$= K_1 V_m Y \frac{P_{bar} + (\Delta H/13.6)}{T_m}$$

Equation 5-1

Where:

$K_1 = 0.3858^{\circ}K/mm\ Hg$  for metric units

$= 17.64^{\circ}R/in. Hg$  for English units

NOTE: Equation 5-1 can be used as written unless the leakage rate observed during any of the mandatory leak checks (i.e., the post-test leak check or leak checks conducted prior to component changes) exceeds  $L_m$ . If  $L_p$  or  $L_i$  exceeds  $L_m$ , Equation 5-1 must be modified as follows:

(a) Case I. No component changes made during sampling run. In this case, replace  $V_m$  in Equation 5-1 with the expression:

$$[V_m - (L_p - L_m)\theta]$$

(b) Case II. One or more component changes made during the sampling run. In this case, replace  $V_m$  in Equation 5-1 by the expression:

$$\left[ V_m - (L_1 - L_m)\theta_1 - \sum_{i=2}^n (L_i - L_m)\theta_i - (L_p - L_m)\theta_p \right]$$

and substitute only for those leakage rates ( $L_i$  or  $L_p$ ) which exceed  $L_m$ .

6.4 Volume of Water Vapor.

## METHOD 5 - PARTICULATE EMISSION CALCULATIONS - (2)

$$V_{w(sid)} = V_{1c} \left( \frac{P_w}{M_w} \right) \left( \frac{RT_{sid}}{P_{sid}} \right) = K_2 V_{1c} \quad \text{Equation 5-2}$$

Where:

$K_2 = 0.001333 \text{ m}^3/\text{ml}$  for metric units  
 $= 0.04707 \text{ ft}^3/\text{ml}$  for English units.

### 6.5 Moisture Content.

$$B_{ws} = \frac{V_{w(sid)}}{V_{m(sid)} + V_{w(sid)}}$$

Eq. 5-3

**NOTE:** In saturated or water droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one from the impinger analysis (Equation 5-3), and a second from the assumption of saturated conditions. The lower of the two values of  $B_w$  shall be considered correct. The procedure for determining the moisture content based upon assumption of saturated conditions is given in the Note of Section 1.2 of Method 4. For the purposes of this method, the average stack gas temperature from Figure 5-2 may be used to make this determination, provided that the accuracy of the in-stack temperature sensor is  $\pm 1^\circ \text{C}$  ( $2^\circ \text{F}$ ).

### 6.6 Acetone Blank Concentration.

$$C_a = \frac{m_a}{V_a \rho_a} \quad \text{Eq. 5-4}$$

### 6.7 Acetone Wash Blank.

$$W_a = C_a V_{aw} \rho_a \quad \text{Eq. 5-5}$$

**6.8 Total Particulate Weight.** Determine the total particulate catch from the sum of the weights obtained from Containers 1 and 2 less the acetone blank (see Figure 5-3).

**NOTE:** Refer to Section 4.1.5 to assist in calculation of results involving two or more filter assemblies or two or more sampling trains.

### 6.9 Particulate Concentration.

$$c_p = (0.001 \text{ g/mg}) (m_p / V_{m(sid)})$$

Eq. 5-6

### 6.10 Conversion Factors:

| From              | To                 | Multiply by            |
|-------------------|--------------------|------------------------|
| scf               | m <sup>3</sup>     | 0.02832                |
| g/ft <sup>3</sup> | gr/ft <sup>3</sup> | 15.43                  |
| g/ft <sup>3</sup> | lb/ft <sup>3</sup> | $2.205 \times 10^{-3}$ |
| g/ft <sup>3</sup> | g/m <sup>3</sup>   | 35.31                  |

### 6.11 Isokinetic Variation.

#### 6.11.1 Calculation From Raw Data.

$I =$

$$100 \frac{T_s [K_2 V_s + (P_m / T_m) (P_{bar} + \Delta H / 13.6)]}{60 \theta v_s P_s A_s}$$

Eq. 5-7

Where:

$K_2 = 0.003454 \text{ mm Hg} \cdot \text{m}^3/\text{ml} \cdot ^\circ \text{K}$  for metric units.  
 $= 0.002669 \text{ in. Hg} \cdot \text{ft}^3/\text{ml} \cdot ^\circ \text{R}$  for English units.

#### 6.11.2 Calculation From Intermediate Values.

$$I = \frac{T_s V_{m(sid)} P_{sid} 100}{T_{sid} v_s \theta A_s P_s 60 (1 - B_{ws})}$$

$$= K_4 \frac{T_s V_{m(sid)}}{P_s V_s A_s \theta (1 - B_{ws})}$$

Equation 5-8

where:

$K_4 = 4.320$  for metric units  
 $= 0.09450$  for English units.

**6.12 Acceptable Results.** If 90 percent  $< I < 110$  percent, the results are acceptable. If the particulate results are low in comparison to the standard, and  $I$  is over 110 percent or less than 90 percent, the Administrator may accept the results.

# NOMENCLATURE METHOD 5 CALCULATIONS

|               |   |                                                                                                                  |
|---------------|---|------------------------------------------------------------------------------------------------------------------|
| $V_{m_{std}}$ | = | Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscm (dscf).               |
| $Y$           | = | Dry gas meter calibration factor                                                                                 |
| $P_b$         | = | Barometric pressure at the sampling site, mm Hg (in. Hg)                                                         |
| $H$           | = | Average pressure differential across the orifice meter, mm H <sub>2</sub> O (in. H <sub>2</sub> O)               |
| $T_m$         | = | Absolute average dry gas meter temperature, ° K (° R)                                                            |
| dscm          | = | Dry standard cubic meters                                                                                        |
| dscf          | = | Dry standard cubic feet                                                                                          |
| $W_a$         | = | Weight of residue in acetone wash                                                                                |
| $M_a$         | = | Mass of residue of acetone after evaporation, mg                                                                 |
| $C_a$         | = | Acetone blank residue concentration, mg/g                                                                        |
| $V_a$         | = | Volume of acetone blank                                                                                          |
| $V_{aw}$      | = | Volume of acetone used in wash, ml                                                                               |
| $M_n$         | = | Total amount of particulate matter collected, mg                                                                 |
| $C_s$         | = | Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, mg/dscm (gr/dscf) |
| gr/dscf       | = | grains per dry standard cubic foot                                                                               |
| $V_{w_{std}}$ | = | Volume of water vapor in the gas sample, corrected to standard conditions, scm (scf)                             |
| $B_{ws}$      | = | Water vapor in the gas stream, proportion by volume                                                              |
| $M_d$         | = | Molecular weight of stack gas, g/g-mole on dry basis                                                             |
| $M_s$         | = | Molecular weight of stack gas, g/g-mole on wet basis                                                             |
| $V_s$         | = | Stack gas velocity, calculated by Method 2, Equation 2-9, using data obtained from Method 5, m/sec (ft/sec)      |
| $C_p$         | = | Pitot tube coefficient, dimensionless                                                                            |
| $\Delta_p$    | = | Velocity head of stack gas, mm H <sub>2</sub> O (in. H <sub>2</sub> O)                                           |
| $P_s$         | = | Absolute stack gas pressure, mm Hg (in. Hg)                                                                      |

NOMENCLATURE (continued)  
METHOD 5 CALCULATIONS

- $Q_{std}$  = Dry volumetric stack gas flow rate corrected to standard conditions, dscm/hr (dscf/hr)
- dscf/min = dry standard cubic feet per minute (also identified as dcfm or scfm)
- acfm = actual cubic feet per minute
- $l$  = Percent of isokinetic sampling
- $A_n$  = Cross-sectional area of nozzle,  $m^2$  ( $ft^2$ )

DRY GAS METER CALIBRATION  
AM TEST - AIR QUALITY, INC.

FILE NAME: RDMAG894.WK1  
METER BOX #: RED MAG (JAG)  
CALIBRATION DATE: 8-22-94  
METHOD OF CALIB.: STANDARD DRY GAS METER (Method 5 Section 7.1)

| TOTAL<br>TIME<br>min | DELTA<br>H<br>"H2O | METER<br>VOL V1<br>cf | METER<br>VOL V2<br>cf | TEMP<br>IN<br>deg F | TEMP<br>OUT<br>deg F | BARO.<br>PRES.<br>"Hg | STD<br>DGM<br>V1 | STD<br>DGM<br>V2 | ST.DGM<br>TEMP IN<br>deg F | ST.DGM<br>TEMP OUT<br>deg F | ST.DGM<br>Yds<br>FACTOR | Y FACTOR | DELTA H2O |
|----------------------|--------------------|-----------------------|-----------------------|---------------------|----------------------|-----------------------|------------------|------------------|----------------------------|-----------------------------|-------------------------|----------|-----------|
| 23.5                 | 0.50               | 853.674               | 866.938               | 72.0                | 70.0                 | 29.57                 | 686.912          | 700.037          | 74.0                       | 69.0                        | 1.001                   | 0.9883   | 0.914     |
| 15.0                 | 1.00               | 867.393               | 880.679               | 76.0                | 73.0                 | 29.57                 | 700.488          | 713.616          | 70.0                       | 69.0                        | 1.001                   | 0.9960   | 0.735     |
| 12.0                 | 1.50               | 881.254               | 893.230               | 80.0                | 75.0                 | 29.57                 | 714.186          | 726.032          | 70.0                       | 69.0                        | 1.001                   | 1.0014   | 0.863     |
| 13.5                 | 2.00               | 900.566               | 917.371               | 82.0                | 77.0                 | 29.57                 | 733.300          | 749.951          | 69.0                       | 69.0                        | 1.001                   | 1.0065   | 0.733     |
| 9.0                  | 2.50               | 930.060               | 942.199               | 86.0                | 77.0                 | 29.57                 | 762.595          | 774.652          | 69.0                       | 69.0                        | 1.001                   | 1.0114   | 0.777     |
| 10.0                 | 3.00               | 968.304               | 982.810               | 85.0                | 78.0                 | 29.57                 | 800.708          | 815.117          | 70.0                       | 69.0                        | 1.001                   | 1.0093   | 0.806     |
| AVERAGE              |                    |                       |                       |                     |                      |                       |                  |                  |                            |                             |                         | 1.002    | 0.805     |

## PRESSURE SENSOR CALIBRATION DATA FORM

Date 9-21-93 Control Box # Red Mag (JAG Red)  
 Ambient Temperature 65 °F Barometric Pressure 29.8 in Hg

|      | MAGNEHELIC<br>GUAGE # | REFERENCE<br>MANOMETER<br>READING<br>Inches H <sub>2</sub> O | MAGNEHELIC<br>GUAGE<br>READING<br>Inches H <sub>2</sub> O | PRESSURE<br>DIFFERENCE     |       |
|------|-----------------------|--------------------------------------------------------------|-----------------------------------------------------------|----------------------------|-------|
|      |                       |                                                              |                                                           | Inches<br>H <sub>2</sub> O | %     |
|      | 0-3"                  |                                                              |                                                           |                            |       |
| High |                       | 0.61                                                         | 0.62                                                      | 0.01                       | 1.6%  |
|      |                       | 1.23                                                         | 1.28                                                      | 0.05                       | 4.1%  |
|      |                       | 1.80                                                         | 1.85                                                      | 0.05                       | 2.8%  |
| Low  |                       | 2.40                                                         | 2.44                                                      | 0.04                       | 1.7%  |
|      |                       | 0.65                                                         | 0.67                                                      | 0.02                       | 3.1%  |
|      |                       | 1.20                                                         | 1.25                                                      | 0.05                       | 4.2%  |
|      |                       | 1.80                                                         | 1.84                                                      | 0.04                       | 2.2%  |
|      |                       | 2.45                                                         | 2.50                                                      | 0.05                       | 2.0%  |
|      |                       |                                                              |                                                           |                            |       |
|      |                       |                                                              |                                                           |                            |       |
|      | 0-4"                  | <del>0.82</del>                                              | <del>0.82</del>                                           |                            |       |
| High |                       | 0.82                                                         | 0.82                                                      | 0.0                        | 0.0   |
|      |                       | 1.60                                                         | 1.59                                                      | 0.01                       | 0.63% |
|      |                       | 2.35                                                         | 2.36                                                      | 0.01                       | 0.37% |
| Low  |                       | 3.20                                                         | 3.19                                                      | 0.01                       | 0.31% |
|      |                       | 0.82                                                         | 0.86                                                      | 0.04                       | 0.49% |
|      |                       | 1.62                                                         | 1.65                                                      | 0.03                       | 1.9%  |
|      |                       | 2.38                                                         | 2.41                                                      | 0.03                       | 1.3%  |
|      |                       | 3.13                                                         | 3.14                                                      | 0.01                       | 0.3%  |
|      |                       |                                                              |                                                           |                            |       |

$$\frac{(\text{ref pres. "H}_2\text{O} - \text{test pres. "H}_2\text{O})}{(\text{ref pres. "H}_2\text{O})} \times 100 \leq 5\%$$



## PRESSURE SENSOR CALIBRATION DATA FORM

Date 9-21-99 Control Box # Red Mag (JAG Red)  
 Ambient Temperature 65 °F Barometric Pressure 29.8 in Hg

|      | MAGNEHELIC<br>GUAGE # | REFERENCE<br>MANOMETER<br>READING<br>Inches H <sub>2</sub> O | MAGNEHELIC<br>GUAGE<br>READING<br>Inches H <sub>2</sub> O | PRESSURE<br>DIFFERENCE     |      |
|------|-----------------------|--------------------------------------------------------------|-----------------------------------------------------------|----------------------------|------|
|      |                       |                                                              |                                                           | Inches<br>H <sub>2</sub> O | %    |
|      | 0-1"                  |                                                              |                                                           |                            |      |
| high |                       | 0.23                                                         | 0.23                                                      | 0.00                       | 0.0% |
|      |                       | 0.42                                                         | 0.42                                                      | 0.00                       | 0.0% |
|      |                       | 0.60                                                         | 0.61                                                      | 0.01                       | 1.7% |
|      |                       | 0.82                                                         | 0.84                                                      | 0.02                       | 2.5% |
| low  |                       | 0.21                                                         | 0.22                                                      | 0.01                       | 4.8% |
|      |                       | 0.44                                                         | 0.44                                                      | 0.00                       | 0.0% |
|      |                       | 0.63                                                         | 0.66                                                      | 0.02                       | 3.2% |
|      |                       | 0.82                                                         | 0.84                                                      | 0.02                       | 2.4% |
|      | 0-2"                  |                                                              |                                                           |                            |      |
| High |                       | 0.43                                                         | 0.43                                                      | 0.00                       | 0.0% |
|      |                       | 0.82                                                         | 0.83                                                      | 0.01                       | 1.2% |
|      |                       | 1.20                                                         | 1.24                                                      | 0.04                       | 3.2% |
|      |                       | 1.63                                                         | 1.66                                                      | 0.03                       | 1.8% |
| low  |                       | 0.39                                                         | 0.39                                                      | 0.00                       | 0.0% |
|      |                       | 0.82                                                         | 0.82                                                      | 0.00                       | 0.0% |
|      |                       | 1.21                                                         | 1.24                                                      | 0.03                       | 2.5% |
|      |                       | 1.63                                                         | 1.65                                                      | 0.02                       | 1.2% |

$$\frac{(\text{ref. pres. "H}_2\text{O} - \text{test pres. "H}_2\text{O})}{(\text{ref. pres. "H}_2\text{O})} \times 100 \leq 5\%$$

STANDARD DRY GAS METER CALIBRATION DATA SUMMARY  
AMTEST AIR QUALITY, INC.

PERFORMED BY HOMER R. DULIN CO.

| Cal. DGM<br>Ind, SCFH | Primary<br>Standard<br>SCFH | Yds   |
|-----------------------|-----------------------------|-------|
| 13.5                  | 13.8                        | 1.022 |
| 25.7                  | 25.8                        | 1.004 |
| 35.9                  | 35.7                        | 0.994 |
| 46.5                  | 46.2                        | 0.994 |
| 55.9                  | 55.9                        | 1.000 |
| 66.8                  | 66.6                        | 0.997 |
| 85.5                  | 84.8                        | 0.992 |
| 99.9                  | 88.5                        | 0.997 |
| 108.6                 | 100.1                       | 1.002 |
| 113.3                 | 108.9                       | 1.003 |
|                       | 113.5                       | 1.002 |
|                       | AVG. Yds =                  | 1.001 |

# HOMER R. DULIN CO.

55

729 EAST WILLOW STREET  
LONG BEACH, CALIFORNIA 90806

(310) 424-8533 (213) 636-4096 FAX (310) 426-7707

CERT. NO. 4-304-4

## CALIBRATION CERTIFICATION

SUBMITTED BY: KRIS A. HANSEN CO.

FLOWMETER SERIAL No. 0302

MANUFACTURER EQUIMETER MFG. SERIAL No. 27688

TUBE No. FLOAT No.

MODEL NO.: T-110

REMARKS: CALIBRATED IN CFH AIR @ 14.7 PSIA & 70 DEG F.

ACCURACY: SEE DATA

| INDICATED |  | ACTUAL |  |
|-----------|--|--------|--|
| CFH       |  | CFH    |  |
| 113.3     |  | 113.5  |  |
| 108.6     |  | 108.9  |  |
| 99.9      |  | 100.1  |  |
| 88.8      |  | 88.5   |  |
| 85.5      |  | 84.8   |  |
| 66.8      |  | 66.6   |  |
| 55.9      |  | 55.9   |  |
| 46.5      |  | 46.2   |  |
| 35.9      |  | 35.7   |  |
| 25.7      |  | 25.8   |  |
| 13.5      |  | 13.8   |  |
|           |  |        |  |
|           |  |        |  |

Flowmeter Certified with HOMER R. DULIN CO.

Equipment No. 12400 Accuracy 0.2% Calib. Due 5-28-94

Procedure No. 101G

NIST Cert. No. 821/249576-92

Our standards are certified by or are traceable to the National Institute of Standards and Technology and comply with MIL-STD-45662A

P.O. No. 06330

Shipper No.

4-18-94

4-18-95

CALIBRATION DATE

RECALIBRATION DATE

*B. Richardson*  
CALIBRATION TECHNICIAN  
B. RICHARDSON

## TYPE S PITOT TUBE INSPECTION DATA FORM

Date 12-28-93 Pitot Tube # P5C5Client Lakeside IndustriesLocation Lacey, WashingtonSite(s) Hot Mix Asphalt Batch Plant Baghouse StackTest  
Date(s) August 24, 1994Pitot tube assembly level? ✓ yes        noPitot tube openings damaged?        yes (explain below) ✓ no $\alpha_1 =$  4.0  $^{\circ}$  ( $<10^{\circ}$ ),  $\alpha_2 =$  2.0  $^{\circ}$  ( $<10^{\circ}$ ),  $\beta_1 =$  3.5  $^{\circ}$  ( $<5^{\circ}$ ), $\beta_2 =$  1.5  $^{\circ}$  ( $<5^{\circ}$ ) $\gamma =$  0.5  $^{\circ}$ ,  $\theta =$  0.5  $^{\circ}$ ,  $A =$  1.113 cm (in.) $z = A \sin \gamma =$  0.00971 cm (in.);  $<0.32$  cm ( $<1/8$  in.), $w = A \sin \theta =$  0.00971 cm (in.);  $<0.08$  cm ( $<1/32$  in.) $P_A =$  0.557 cm (in.)  $P_b =$  0.556 cm (in.) $D_t =$  0.375 cm (in.)

Comments:

Calibration required?        yes\* ✓ no

\*If yes, tag and take out of service until repaired.

VP

## STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 12-29-98 Thermocouple Indicator # Red 4/FAmbient Temperature 71 °F Barometric Pressure 29.85 in Hg

| THERMOCOUPLE<br># OR<br>REFERENCE | REFERENCE<br>THERMOMETER<br>TEMPERATURE<br>°F | THERMOCOUPLE<br>TEMPERATURE<br>°F | TEMPERATURE<br>DIFFERENCE |       |
|-----------------------------------|-----------------------------------------------|-----------------------------------|---------------------------|-------|
|                                   |                                               |                                   | °F                        | %     |
| T6DJ                              |                                               |                                   |                           |       |
|                                   | 33                                            | 33                                | 0                         | 0.00% |
|                                   | 211                                           | 214                               | 3                         | 0.45% |
|                                   | 364                                           | 364                               | 0                         | 0.00% |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |
|                                   |                                               |                                   |                           |       |

$$\frac{(\text{ref temp, } ^\circ\text{F} + 460) - (\text{test therm. temp, } ^\circ\text{F} + 460)}{(\text{ref temp, } ^\circ\text{F} + 460)} \times 100 < 1.5\%$$