

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

File



JOHN ASHCROFT
Governor

G. TRACY MEHAN III
Director

Division of Energy
Division of Environmental Quality
Division of Geology and Land Survey
Division of Management Services
Division of Parks, Recreation,
and Historic Preservation

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

DIVISION OF ENVIRONMENTAL QUALITY

P.O. Box 176
Jefferson City, MO 65102

December 18, 1991

Mr. William D. Eckhoff
President, Masters & Jackson Paving Company
P. O. Box 1187
Springfield, MO 65801

Dear Mr. Eckhoff:

My staff has reviewed the report of emission tests conducted by AirSource Technologies on your Double Barrel Astec Asphalt Plant near Willard, Missouri. Testing was conducted on August 5 & 6, 1991. The reported average particulate concentration of 0.0068 gr/DSCF was less than the NSPS maximum (0.04 gr/DSCF), and the observed opacity was below the NSPS maximum (20%). Our review of the test data is in substantial agreement with these findings. In light of the foregoing, the facility was found to be in compliance at the time of the test with permit # 0391-007.

Production at the time of the test averaged 420 tons per hour which shall be the maximum permitted production rate for this facility. Pressure drop across the baghouse was not reported by AirSource Technologies, but was recorded by APCP personnel for a single run. During this run pressure drop averaged approximately 2 inches of water. To ensure continued compliance with permit conditions, a comparable level should be maintained whenever the facility is in operation. Annual production at this facility is limited to 350,000 tons.

Sincerely,

AIR POLLUTION CONTROL PROGRAM

A handwritten signature in cursive script, reading "Steve Feeler".

Steve Feeler
Compliance Unit Chief

SF:pyb



Printed on recycled paper.

JOHN ASHCROFT
Governor

G. TRACY MEHAN III
Director



STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MEMORANDUM

Division of Energy
Division of Environmental Quality
Division of Geology and Land Survey
Division of Management Services
Division of Parks, Recreation,
and Historic Preservation

DATE: December 19, 1991
TO: Greene County file
FROM: Peter Yronwode *PY*
SUBJECT: Masters & Jackson Paving Co.; Asphalt Plant Stack test

Masters & Jackson Paving Company received permit # 0391-007 to construct an Astec Double Barrel asphalt plant near Willard, Missouri. On August 5 & 6, 1991 a particulate emission test was run on the plant by AirSource Technologies.

During the test the plant was run at 420 tons per hour and pressure drop across the bag house (recorded by APCP) averaged @2 inches of water. The three test runs met isokinetic sampling criteria, reported opacity averaged less than 1%, and reported average particulate concentration was 0.0068 gr/DSCF. At the time of testing the facility was in compliance with New Source Performance Standards (0.04 gr/DSCF and 20%). Annual production is limited to 350,000 tons.

The original presentation of the report by AirSource Technologies was unsatisfactory. Important data was omitted and the required format was not followed. A better report was finally submitted five months after the test was performed in which baghouse data was still missing. Because of the extremely low emissions at this plant the report was accepted but the testing firm was warned that omission of such information in future reports would result in their rejection by APCP.



**SOURCE EMISSIONS REPORT
OF
MASTERS & JACKSON
SPRINGFIELD, MISSOURI
(Willard/Springfield Facility)**


**BY
AIRSOURCE TECHNOLOGIES
11635 WEST 83RD TERRACE
LENEXA, KANSAS 66215**

AirSource Project No. 411117/R

PREFACE

This report was prepared by AirSource Technologies in response to a test that was conducted at Masters-Jackson's Willard/Springfield, Missouri, plant on August 5 and 6, 1991. Any questions concerning this report should be directed to Mr. George Cobb, General Manager.

Approved by:



George R. Cobb
General Manager

November 25, 1991

SECTION 1

INTRODUCTION

A compliance test was conducted for particulates and opacity by AirSource Technologies on Masters- Jackson's asphalt drum mixer facility, located near Willard/Springfield, Missouri. Three 1-hour runs were conducted by George Cobb, Karl Baker and Dan Rigdon on August 5 and 6, 1991. This report presents the results and methodology used to perform these tests.

The appendices contain the following:

- Appendix A: Computer Calculatons
- Appendix B: Example Calculations
- Appendix C: Field Data Forms
- Appendix D: Laboratory Data
- Appendix E: Pretest Calibrations
- Appendix F: Posttest Calibrations
- Appendix G: Participants
- Appendix H: Process Data

PLANT NAME: Masters & Jackson

TEST UNIT: Asphalt Plant

LOCATION: Willard, MO

DATE: 8/5-6/91

RUN NO: 1

USE FOR ANY TEST WITH A SQUARE OR RECTANGULAR STACK

NUMBER OF POINTS	24	PERCENT OXYGEN	14.50
TIME, MINUTE/POINT	2.50	PERCENT CARBON DIOXIDE	5.50
LEAK RATE, FT3/MIN	0.000	PERCENT CARBON MONOXIDE	0.00
BAR PRESS, INCH Hg	29.92	Cp (PITOT COEFFICIENT)	0.840
STATIC PRESS (in H2O)	0.39	NOZZLE DIAMETER, INCHES	0.238
STACK EXIT LENGTH IN	49.00	INITIAL METER VOL, FT3	84.502
STACK EXIT WIDTH IN	33.00	FINAL METER VOL, FT3	136.482
IMPINGER H2O, ML	248.6	METER CORR FACT, Y	1.014
SILICA GEL H2O, GM	9.8	PARTIC COLLECTED, MG	31.40

PT NO	STACK TEMP (Ts)	VELOC PRESS (dPs)	ORIFICE PRESS (dH)	METER TEMP		SQR ROOT VELOC PRESS
				INLET (Tmi)	OUTLET (Tmo)	
1	204.0	1.40	3.20	102	101	1.183
2	214.0	1.40	3.15	99	100	1.183
3	219.0	1.30	2.90	101	101	1.140
4	219.0	1.20	2.70	102	101	1.095
5	215.0	1.60	3.60	103	102	1.265
6	215.0	1.60	3.60	103	101	1.265
7	212.0	1.40	3.20	106	102	1.183
8	203.0	1.10	2.50	106	102	1.049
9	201.0	1.70	3.90	104	101	1.304
10	200.0	1.30	3.00	104	102	1.140
11	201.0	1.00	2.30	105	102	1.000
12	206.0	0.94	2.15	105	102	0.970
13	214.0	1.40	3.15	104	102	1.183
14	223.0	0.98	2.20	104	102	0.990
15	227.0	0.75	1.70	107	104	0.866
16	226.0	0.60	1.35	107	104	0.775
17	225.0	1.20	2.70	107	105	1.095
18	231.0	0.94	2.10	107	105	0.970
19	231.0	0.71	1.60	108	106	0.843
20	228.0	0.62	1.40	108	106	0.787
21	224.0	0.88	1.20	108	106	0.938
22	226.0	0.88	2.00	109	107	0.938
23	225.0	0.70	1.60	110	108	0.837
24	225.0	0.58	1.30	112	109	0.762
25						
26						
27						
28						
29						
30						

AVG	217.3	1.091	2.44	105.5	103.4	1.0317
-----	-------	-------	------	-------	-------	--------

STACK GAS MOL WT. WET	27.20	AVG ABS STACK TEMP (deg R)	677.3
STACK VELOCITY (ft/sec)	67.55	AVG ABS METER TEMP (deg R)	564.4
STD VOL SAMPLED (std ft2)	49.58	METER LEAK RATE (ft3/min)	0.000
AVG METER TEMP (deg F)	104.42	SAMPLE VOL LK CORR'D (ft3)	51.98
PERCENT MOISTURE (%)	19.70	AVG ABS STACK PRESS (in Hg)	29.95
STD STACK FLOW RATE (DSCFM)	28519.71	VOL H2O IN METER GAS (std ft3)	12.16
		H2O IN GAS STREAM (vol frac)	0.197
ISOKINETIC SAMPLING RATE (%)	105.27	NOZZLE AREA (ft2)	0.00031
PARTIC EMISSION RATE (lb/hr)	2.3890	STACK AREA (ft2)	11.229
PARTICULATE CONC (gr/DSCF)	0.009773	STACK EQUIV DIAMETER (ft)	39.44

USE FOR ANY TEST WITH A SQUARE OR RECTANGULAR STACK

NUMBER OF POINTS	24	PERCENT OXYGEN	16.20
TIME, MINUTE/POINT	2.50	PERCENT CARBON DIOXIDE	6.00
LEAK RATE, FT ³ /MIN	0.000	PERCENT CARBON MONOXIDE	0.00
BAR PRESS, INCH Hg	28.85	C _p (PITOT COEFFICIENT)	0.840
STATIC PRESS (in H ₂ O)	0.39	NOZZLE DIAMETER, INCHES	0.174
STACK EXIT LENGTH IN	49.00	INITIAL METER VOL, FT ³	188.308
STACK EXIT WIDTH IN	33.00	FINAL METER VOL, FT ³	215.553
IMPINGER H ₂ O, ML	160.2	METER CORR FACT, Y	1.014
SILICA GEL H ₂ O, GM	5.3	PARTIC COLLECTED, MG	15.10

PT NO	STACK TEMP (Ts)	VELOC PRESS (dPs)	ORIFICE PRESS (dH)	METER TEMP		SQR ROOT VELOC PRESS
				INLET (T _{mi})	OUTLET (T _{mo})	
1	189	0.90	0.55	113	110	0.949
2	195	1.50	0.91	111	111	1.225
3	201	1.60	0.96	112	112	1.265
4	205	1.30	0.78	113	113	1.140
5	215	1.60	0.94	113	112	1.265
6	223	1.60	0.93	114	113	1.265
7	222	1.30	0.76	114	112	1.140
8	222	0.90	0.52	114	112	0.949
9	218	1.60	0.94	114	112	1.265
10	217	1.20	0.70	107	108	1.095
11	216	0.94	0.54	101	102	0.970
12	217	0.62	0.35	99	99	0.787
13	217	1.50	0.86	98	99	1.225
14	222	0.90	0.51	98	99	0.949
15	221	0.74	0.42	98	99	0.860
16	215	0.70	0.40	96	96	0.837
17	215	1.70	0.97	94	95	1.304
18	159	1.20	0.72	78	78	1.095
19	190	0.79	0.45	79	79	0.889
20	194	0.64	0.37	80	79	0.800
21	196	1.20	0.69	81	79	1.095
22	198	1.20	0.69	82	80	1.095
23	196	0.94	0.54	83	80	0.970
24	192	0.58	0.33	84	81	0.762
25						
26						
27						
28						
29						
30						

AVG	206.5	1.131	0.66	99.0	98.3	1.0498
-----	-------	-------	------	------	------	--------

STACK GAS MOL WT. WET	26.87	AVG ABS STACK TEMP (deg R)	666.5
STACK VELOCITY (ft/sec)	69.87	AVG ABS METER TEMP (deg R)	558.7
STD VOL SAMPLED (std ft ²)	25.21	METER LEAK RATE (ft ³ /min)	0.000
AVG METER TEMP (deg F)	98.67	SAMPLE VOL LK CORR'D (ft ³)	27.25
PERCENT MOISTURE (%)	23.61	AVG ABS STACK PRESS (in Hg)	28.88
STD STACK FLOW RATE (DSCFM)	27498.02	VOL H ₂ O IN METER GAS (std ft ³)	7.79
		H ₂ O IN GAS STREAM (vol frac)	0.236
ISOKINETIC SAMPLING RATE (%)	103.85	NOZZLE AREA (ft ²)	0.00017
PARTIC EMISSION RATE (lb/hr)	2.1788	STACK AREA (ft ²)	11.229
PARTICULATE CONC (gr/DSCF)	0.009244	STACK EQUIV DIAMETER (ft)	39.44

PLANT NAME:Masters & Jackson

TEST UNIT:Asphalt Plant

LOCATION: Willard, MO

DATE: 8/5-6/91

RUN NO: 4

USE FOR ANY TEST WITH A SQUARE OR RECTANGULAR STACK

NUMBER OF POINTS	24	PERCENT OXYGEN	14.70
TIME, MINUTE/POINT	2.50	PERCENT CARBON DIOXIDE	6.20
LEAK RATE, FT3/MIN	0.000	PERCENT CARBON MONOXIDE	0.00
BAR PRESS, INCH Hg	28.97	Cp (PITOT COEFFICIENT)	0.840
STATIC PRESS (in H2O)	0.39	NOZZLE DIAMETER, INCHES	0.238
STACK EXIT LENGTH IN	49.00	INITIAL METER VOL, FT3	218.317
STACK EXIT WIDTH IN	33.00	FINAL METER VOL, FT3	264.073
IMPINGER H2O, ML	199.1	METER CORR FACT, Y	1.014
SILICA GEL H2O, GM	14.0	PARTIC COLLECTED, MG	3.20

PT NO	STACK TEMP (Ts)	VELOC PRESS (dPs)	ORIFICE PRESS (dH)	METER TEMP		SQR ROOT VELOC PRESS
				INLET (Tmi)	OUTLET (Tmo)	
1	219	0.86	1.70	84	83	0.927
2	227	0.52	1.00	89	85	0.721
3	225	0.47	0.92	91	86	0.686
4	223	0.47	0.92	92	87	0.686
5	221	0.95	1.90	92	88	0.975
6	219	0.73	1.50	96	89	0.854
7	219	0.59	1.20	96	90	0.768
8	214	0.53	1.05	97	91	0.728
9	213	1.20	2.40	96	91	1.095
10	211	0.81	1.65	100	92	0.900
11	212	0.71	1.45	101	94	0.843
12	211	0.62	1.25	102	95	0.787
13	211	1.40	2.85	100	95	1.183
14	211	1.00	2.05	103	96	1.000
15	210	0.91	1.85	104	97	0.954
16	208	0.65	1.35	104	98	0.806
17	207	1.50	3.10	103	98	1.225
18	207	1.50	3.00	104	99	1.225
19	206	1.30	2.70	105	98	1.140
20	204	0.92	1.90	104	99	0.959
21	200	1.40	2.90	102	99	1.183
22	201	1.50	3.00	102	98	1.225
23	201	1.50	3.00	102	98	1.225
24	201	1.45	3.00	102	98	1.204
25						
26						
27						
28						
29						
30						

AVG	211.7	0.979	1.99	98.8	93.5	0.9708
-----	-------	-------	------	------	------	--------

STACK GAS MOL WT. WET	27.38	AVG ABS STACK TEMP (deg R)	671.7
STACK VELOCITY (ft/sec)	64.12	AVG ABS METER TEMP (deg R)	556.1
STD VOL SAMPLED (std ft2)	42.85	METER LEAK RATE (ft3/min)	0.000
AVG METER TEMP (deg F)	96.15	SAMPLE VOL LK CORR'D (ft3)	45.76
PERCENT MOISTURE (%)	18.97	AVG ABS STACK PRESS (in Hg)	29.00
STD STACK FLOW RATE (DSCFM)	26668.32	VOL H2O IN METER GAS (std ft3)	10.03
	✓ 27562.0	H2O IN GAS STREAM (vol frac)	0.190
ISOKINETIC SAMPLING RATE (%)	97.28	NOZZLE AREA (ft2)	0.00031
PARTIC EMISSION RATE (lb/hr)	0.2634	STACK AREA (ft2)	11.229
PARTICULATE CONC (gr/DSCF)	0.001153	STACK EQUIV DIAMETER (ft)	39.44

1
0.0067 gr/DSCF
1.61 / #/hr

SECTION 2

SUMMARY OF RESULTS

2.1 Particulate Emission and Opacity Results

Table 2-1 presents the particulate emission results and the opacity averages taken during the particulate runs.

Table 2-1

Parameters	Results		
	Run 1	Run 3	Run 4
Particulate Collected, g	0.0314	0.0151	0.0032
Particulate Concentration,			
Actual (gr/cu ft)	0.0061	0.0054	0.0007
Dry Std. (gr/scf)	0.0101	0.0092	0.0012
Emission Rate, lb/hr	2.41	2.17	0.26
Opacity, %	0.0	0.0	0.0

2.2 Sampling Train Results

Table 2-2 summarizes the sample train results as determined by measurement and calculations.

Table 2-2

Parameters	Results		
	Run 1	Run 3	Run 4
Sampling Time, min	60	60	60
Sample Volume, dscf	47.935	25.208	42.848
Isokinetics, %	104.2	103.9	97.4
Oxygen Concentration, %	14.5	16.2	24.7
Carbon Dioxide Concentration, %	5.5	6.0	6.2
Stack Gas Moisture, %	20.2	23.6	19.0
Average Stack Temp., °F	217	206	212
Actual Flow Rate, acfm	46,340	47,069	43,196
Stack Flow Rate, dscf/min	27,877	27,492	26,663

2.3 Discussion of Results

The results show the plant is within compliance of the 0.04 gr/dscf allowable particulate concentration. The opacity averages were within the 20% limit. The plant was operated at an average production rate of 450 tons per hour.

After completion of Run 2, it was determined that the filter was installed incorrectly; therefore, it was decided to run a fourth run. The field data for this run is not included in this report.

There were no plant interruptions during the testing.

SECTION 3

SOURCE OPERATION

The Willard/Springfield plant is located two miles southeast of Willard, Missouri. The unit is a Double Barrel Aztec with a capacity of 511 T/hr @ 0% moisture. No. 2 diesel is used as fuel at a rate of 420 gal/hr during operation. A schematic of the plant is shown in Figure 3-1.

During operation on August 5 and 6, 3,300 T and 1,823 T of asphalt were produced, respectively. This averages to 420 T/hr production rate.

Appendix H provides the production data provided by the plant.

MASTERS-JACKSON PAVING COMPANY

Willard/Springfield
PROCESS FLOW DIAGRAM
Double Barrel Aztec





Figure 3-1

SECTION 4

SAMPLING AND ANALYSIS

The sample ports are located 0.6 diameters upstream and 7.3 diameters downstream from disturbances. The stack dimensions are 33"x49". Four sample points per port, for a total of 24, were used to perform the test runs. Below is a summary of the port and sample point locations.



Sampling was conducted using a USEPA Method 5 sampling train. The train consists of a heat-traced borosilicate glass probe liner housed in a stainless steel sheath; a high efficiency glass fiber filter supported on a Teflon frit, mounted in a glass holder; four glass impingers; and a flow control module containing a leakless vacuum pump, a dry gas meter, an orifice meter and appropriate valves, gauges, and associated hardware to permit control and monitoring of the gas sampling rate. The four impingers are of the Greenburg-Smith design as follows:

- * The first is a modified Greenburg-Smith, containing 100 ml of distilled H_2O .
- * The second is a standard Greenburg-Smith, containing 100 ml of distilled H_2O .
- * The third and fourth impingers are of the modified Greenburg-Smith design. The third is empty, but intended to collect any carryover of moisture. The fourth contains approximately 200g of blue, indicating

A cyclone was not used because particulate emissions were expected to be low. The filter was housed in a temperature-controlled oven maintained at 248°F + 25°F.

Sampling was conducted in accordance with the procedures outlined in EPA Reference Method 5. The samples were collected isokinetically over a 60 minute traverse of the stack as required by 40 CFR 60 Appendix A, Methods 1-5. All pitot and sample train leak checks for all runs were within the method criteria.

The sample recovery from the M5 particulate train was as follows:

- * Container 1 - Filter: Teflon-coated forceps were used to remove the filter and place it in a labeled glass petri dish.
- * Container 2 - Front-half Rinse: The probe nozzle, probe liner, and all glassware, up to and including, the front-half of the filter housing were rinsed and brushed with acetone a minimum of three times.
- * The condensate and silica gel impinger were weighed using a triple beam balance.

A multipoint composite stack gas sample was taken during each test run and analyzed for percentage oxygen and carbon dioxide according to EPA Reference Method 3 (40 CFR 60). The sample was taken simultaneously with the Method 5 sampling, from the exhaust of the Method 5 sampling train console.

The particulate matter analyses were performed by AirSource Technologies according to the procedures established in EPA Reference Method 5, paragraph 4.3. The filters were desiccated for 24 hours and weighed to a constant weight. A blank filter was taken in the field and used as a control.

The front half rinses were measured volumetrically. The contents were transferred to tared beakers and evaporated to dryness at ambient temperature and pressure. The beakers were desiccated for 24 hours and weighed to a constant weight. An acetone blank was taken in the field and used as a control.

The opacity measurements were done according to EPA Reference Method 9.

APPENDIX A

COMPUTER FORMS

FILE NAME - 411117r1
RUN # - 1
LOCATION - STACK
DATE - 8/05/91
PROJECT # - 411117

PROG.=VER 06/27/89
08-21-1991 04:26:17

Initial Meter Volume (Cubic Feet)= 84.502
Final Meter Volume (Cubic Feet)= 136.482
Meter Factor= 1.014
Final Leak Rate (cu ft/min)= 0.002
Net Meter Volume (Cubic Feet)= 52.708
Gas Volume (Dry Standard Cubic Feet)= 47.935

Barometric Pressure (in Hg)= 28.92
Static Pressure (Inches H2O)= 0.39

Percent Oxygen= 14.5
Percent Carbon Dioxide= 5.5
Moisture Collected (ml)= 258.4
Percent Water= 20.2

Average Meter Temperature (F)= 104
Average Delta H (in H2O)= 2.44
Average Delta P (in H2O)= 1.091
Average Stack Temperature (F)= 217

Dry Molecular Weight= 29.46
Wet Molecular Weight= 27.14

Average Square Root of Delta P (in H2O)= 1.0317
% Isokinetic= 104.2

Pitot Coefficient= 0.84
Sampling Time (Minutes)= 60.0
Nozzle Diameter (Inches)= 0.238
Stack Axis #1 (Inches)= 33.0
Stack Axis #2 (Inches)= 49.0
Rectangular Stack
Stack Area (Square Feet)= 11.23

Stack Velocity (Actual, Feet/min)= 4,127
Flow Rate (Actual, Cubic ft/min)= 46,340
Flow rate (Standard, Wet, Cubic ft/min)= 34,955
Flow Rate (Standard, Dry, Cubic ft/min)= 27,877

Particulate Loading - Front Half

Particulate Weight (g)= 0.0314
Particulate Loading, Dry Std. (gr/scf)= 0.0101
Particulate Loading, Actual (gr/cu ft)= 0.0061
Emission Rate (lb/hr)= 2.41

Corr. to 7% O2 & 12% CO2
0.0217 0.0220

No Back Half Analysis

* * METRIC UNITS * *

FILE NAME - 411117r1
 RUN # - 1
 LOCATION - STACK
 DATE - 8/05/91
 PROJECT # - 411117

PROG.=VER 06/27/89
 08-21-1991 04:26:18

Initial Meter Volume (Cubic Meters)= 2.393
 Final Meter Volume (Cubic Meters)= 3.865
 Meter Factor= 1.014
 Final Leak Rate (cu m/min)= 0.0001
 Net Meter Volume (Cubic Meters)= 1.492
 Gas Volume (Dry Standard Cubic Meters)= 1.357

Barometric Pressure (mm Hg)= 735
 Static Pressure (mm H2O)= 10

Percent Oxygen= 14.5
 Percent Carbon Dioxide= 5.5
 Moisture Collected (ml)= 258.4
 Percent Water= 20.2

Average Meter Temperature (C)= 40
 Average Delta H (mm H2O)= 61.9
 Average Delta P (mm H2O)= 27.7
 Average Stack Temperature (C)= 103

Dry Molecular Weight= 29.46
 Wet Molecular Weight= 27.14

Average Square Root of Delta P (mm H2O)= 5.1996
 % Isokinetic= 104.2

Pitot Coefficient= 0.84
 Sampling Time (Minutes)= 60.0
 Nozzle Diameter (mm)= 6.05
 Stack Axis #1 (Meters)= 0.838
 Stack Axis #2 (Meters)= 1.245
 Rectangular Stack
 Stack Area (Square Meters)= 1.043

Stack Velocity (Actual, m/min)= 1,258
 Flow rate (Actual, Cubic m/min)= 1,312
 Flow rate (Standard, Wet, Cubic m/min)= 990
 Flow rate (Standard, Dry, Cubic m/min)= 789

Particulate Loading - Front Half

Particulate Weight (g)=	0.0314	Corr. to 7% O2 & 12% CO2
Particulate Loading, Dry Std. (mg/cu m)=	23.1	49.8 50.5
Particulate Loading, Actual (mg/cu m)=	13.9	
Emission Rate (kg/hr)=	1.09	

No Back Half Analysis

FILE NAME - 411117r1
 RUN # - 1
 LOCATION - STACK
 DATE - 8/05/91
 PROJECT # - 411117

PROG.=VER 06/27/89
 08-21-1991 04:26:33

Point #	Delta P (in. H2O)	Delta H (in. H2O)	Stack T (F)	In(F)	Meter T Out(F)
1	1.400	3.20	204	102	101
2	1.400	3.15	214	99	100
3	1.300	2.90	219	101	101
4	1.200	2.70	219	102	101
5	1.600	3.60	215	103	102
6	1.600	3.60	215	103	101
7	1.400	3.20	212	106	102
8	1.100	2.50	203	106	102
9	1.700	3.90	201	104	101
10	1.300	3.00	200	104	102
11	1.000	2.30	201	105	102
12	0.940	2.15	206	105	102
13	1.400	3.15	214	104	102
14	0.980	2.20	223	104	102
15	0.750	1.70	227	107	104
16	0.600	1.35	226	107	104
17	1.200	2.70	225	107	105
18	0.940	2.10	231	107	105
19	0.710	1.60	231	108	106
20	0.620	1.40	228	108	106
21	0.880	1.20	224	108	106
22	0.880	2.00	226	109	107
23	0.700	1.60	225	110	108
24	0.580	1.30	225	112	109

Fraction	Final Wt. (g)	Tare Wt. (g)	Blank Wt. (g)	Net Wt. (g)
DRY CATCH	0.0000	0.0000	0.0000	0.0000
FILTER	43.1663	43.1625	0.0002	0.0036

Fraction	Final Wt. (g)	Tare Wt. (g)	Vol. (ml)	Net Wt. (g)
PROBE RINSE	74.9569	74.9291	170.0	0.0278
IMPINGERS	0.0000	0.0000	0.0	0.0000
Probe Rinse Blank (mg/ml)=	0.0000			
Impinger Blank (mg/ml)=	0.0000			

FILE NAME - 411117r3
RUN # - 3
LOCATION - STACK
DATE - 8/5/91
PROJECT # - 411117

PROG.=VER 06/27/89
08-21-1991 05:07:11

Initial Meter Volume (Cubic Feet)=	188.308
Final Meter Volume (Cubic Feet)=	215.553
Meter Factor=	1.014
Final Leak Rate (cu ft/min)=	0.002
Net Meter Volume (Cubic Feet)=	27.626
Gas Volume (Dry Standard Cubic Feet)=	25.208

Barometric Pressure (in Hg)=	28.85
Static Pressure (Inches H2O)=	0.39

Percent Oxygen=	16.2
Percent Carbon Dioxide=	6.0
Moisture Collected (ml)=	165.5
Percent Water=	23.6

Average Meter Temperature (F)=	99
Average Delta H (in H2O)=	0.66
Average Delta P (in H2O)=	1.131
Average Stack Temperature (F)=	206

Dry Molecular Weight=	29.61
Wet Molecular Weight=	26.87

Average Square Root of Delta P (in H2O)=	1.0498
% Isokinetic=	103.9

Pitot Coefficient=	0.84
Sampling Time (Minutes)=	60.0
Nozzle Diameter (Inches)=	0.174
Stack Axis #1 (Inches)=	33.0
Stack Axis #2 (Inches)=	49.0
Rectangular Stack	
Stack Area (Square Feet)=	11.23

Stack Velocity (Actual, Feet/min)=	4,192
Flow Rate (Actual, Cubic ft/min)=	47,069
Flow rate (Standard, Wet, Cubic ft/min)=	35,993
Flow Rate (Standard, Dry, Cubic ft/min)=	27,492

Particulate Loading - Front Half

Particulate Weight (g)=	0.0151
Particulate Loading, Dry Std. (gr/scf)=	0.0092
Particulate Loading, Actual (gr/cu ft)=	0.0054
Emission Rate (lb/hr)=	2.17

Corr. to 7% O2 & 12% CO2
0.0269 0.0184

No Back Half Analysis

* * METRIC UNITS * *

FILE NAME - 411117r3
 RUN # - 3
 LOCATION - STACK
 DATE - 8/5/91
 PROJECT # - 411117

PROG.=VER 06/27/89
 08-21-1991 05:07:11

Initial Meter Volume (Cubic Meters)= 5.332
 Final Meter Volume (Cubic Meters)= 6.104
 Meter Factor= 1.014
 Final Leak Rate (cu m/min)= 0.0001
 Net Meter Volume (Cubic Meters)= 0.782
 Gas Volume (Dry Standard Cubic Meters)= 0.714

Barometric Pressure (mm Hg)= 733
 Static Pressure (mm H2O)= 10

Percent Oxygen= 16.2
 Percent Carbon Dioxide= 6.0
 Moisture Collected (ml)= 165.5
 Percent Water= 23.6

Average Meter Temperature (C)= 37
 Average Delta H (mm H2O)= 16.8
 Average Delta P (mm H2O)= 28.7
 Average Stack Temperature (C)= 97

Dry Molecular Weight= 29.61
 Wet Molecular Weight= 26.87

Average Square Root of Delta P (mm H2O)= 5.2908
 % Isokinetic= 103.9

Pitot Coefficient= 0.84
 Sampling Time (Minutes)= 60.0
 Nozzle Diameter (mm)= 4.42
 Stack Axis #1 (Meters)= 0.838
 Stack Axis #2 (Meters)= 1.245
 Rectangular Stack
 Stack Area (Square Meters)= 1.043

Stack Velocity (Actual, m/min)= 1,278
 Flow rate (Actual, Cubic m/min)= 1,333
 Flow rate (Standard, Wet, Cubic m/min)= 1,019
 Flow rate (Standard, Dry, Cubic m/min)= 778

Particulate Loading - Front Half

Particulate Weight (g)= 0.0151
 Particulate Loading, Dry Std. (mg/cu m)= 21.2
 Particulate Loading, Actual (mg/cu m)= 12.3
 Emission Rate (kg/hr)= 0.99

Corr. to 7% O2 & 12% CO2
 61.7 42.3

No Back Half Analysis

FILE NAME - 411117r3
 RUN # - 3
 LOCATION - STACK
 DATE - 8/5/91
 PROJECT # - 411117

PROG.=VER 06/27/89
 08-21-1991 05:07:27

Point #	Delta P (in. H2O)	Delta H (in. H2O)	Stack T (F)	Meter T In(F)	Out(F)
1	0.900	0.55	189	113	110
2	1.500	0.91	195	111	111
3	1.600	0.96	201	112	112
4	1.300	0.78	205	113	113
5	1.600	0.94	215	113	112
6	1.600	0.93	223	114	113
7	1.300	0.76	222	114	112
8	0.900	0.52	222	114	112
9	1.600	0.94	218	114	112
10	1.200	0.70	217	107	108
11	0.940	0.54	216	101	102
12	0.620	0.35	217	99	99
13	1.500	0.86	217	98	99
14	0.900	0.51	222	98	99
15	0.740	0.42	221	98	99
16	0.700	0.40	215	96	96
17	1.700	0.97	215	94	95
18	1.200	0.72	159	78	78
19	0.790	0.45	190	79	79
20	0.640	0.37	194	80	79
21	1.200	0.69	196	81	79
22	1.200	0.69	198	82	80
23	0.940	0.54	196	83	80
24	0.580	0.33	192	84	81

Fraction	Final Wt. (g)	Tare Wt. (g)	Blank Wt. (g)	Net Wt. (g)
DRY CATCH	0.0000	0.0000	0.0000	0.0000
FILTER	29.0229	29.0210	0.0002	0.0017

Fraction	Final Wt. (g)	Tare Wt. (g)	Vol. (ml)	Net Wt. (g)
PROBE RINSE	67.5795	67.5661	145.0	0.0134
IMPINGERS	0.0000	0.0000	0.0	0.0000
Probe Rinse Blank (mg/ml)=	0.0000			
Impinger Blank (mg/ml)=	0.0000			

FILE NAME - 411117r4
RUN # - 4
LOCATION - STACK
DATE - 8/6/91
PROJECT # - 411117

PROG.=VER 06/27/89
08-21-1991 04:30:35

Initial Meter Volume (Cubic Feet)= 218.317
Final Meter Volume (Cubic Feet)= 264.073
Meter Factor= 1.014
Final Leak Rate (cu ft/min)= 0.003
Net Meter Volume (Cubic Feet)= 46.397
Gas Volume (Dry Standard Cubic Feet)= 42.848

Barometric Pressure (in Hg)= 28.97
Static Pressure (Inches H2O)= 0.39

Percent Oxygen= 14.7
Percent Carbon Dioxide= 6.2
Moisture Collected (ml)= 213.1
Percent Water= 19.0

Average Meter Temperature (F)= 96
Average Delta H (in H2O)= 1.99
Average Delta P (in H2O)= 0.979
Average Stack Temperature (F)= 212

Dry Molecular Weight= 29.58
Wet Molecular Weight= 27.38

Average Square Root of Delta P (in H2O)= 0.9708
% Isokinetic= 97.4

Pitot Coefficient= 0.84
Sampling Time (Minutes)= 60.0
Nozzle Diameter (Inches)= 0.238
Stack Axis #1 (Inches)= 33.0
Stack Axis #2 (Inches)= 49.0
Rectangular Stack
Stack Area (Square Feet)= 11.23

Stack Velocity (Actual, Feet/min)= 3,847
Flow Rate (Actual, Cubic ft/min)= 43,196
Flow rate (Standard, Wet, Cubic ft/min)= 32,909
Flow Rate (Standard, Dry, Cubic ft/min)= 26,663

Particulate Loading - Front Half

Particulate Weight (g)= 0.0032
Particulate Loading, Dry Std. (gr/scf)= 0.0012
Particulate Loading, Actual (gr/cu ft)= 0.0007
Emission Rate (lb/hr)= 0.26

Corr. to 7% O2 & 12% CO2
0.0026 0.0022

No Back Half Analysis

* * METRIC UNITS * *

FILE NAME - 411117r4
 RUN # - 4
 LOCATION - STACK
 DATE - 8/6/91
 PROJECT # - 411117

PROG.=VER 06/27/89
 08-21-1991 04:30:35

Initial Meter Volume (Cubic Meters)= 6.182
 Final Meter Volume (Cubic Meters)= 7.477
 Meter Factor= 1.014
 Final Leak Rate (cu m/min)= 0.0001
 Net Meter Volume (Cubic Meters)= 1.314
 Gas Volume (Dry Standard Cubic Meters)= 1.213

Barometric Pressure (mm Hg)= 736
 Static Pressure (mm H2O)= 10

Percent Oxygen= 14.7
 Percent Carbon Dioxide= 6.2
 Moisture Collected (ml)= 213.1
 Percent Water= 19.0

Average Meter Temperature (C)= 36
 Average Delta H (mm H2O)= 50.4
 Average Delta P (mm H2O)= 24.9
 Average Stack Temperature (C)= 100

Dry Molecular Weight= 29.58
 Wet Molecular Weight= 27.38

Average Square Root of Delta P (mm H2O)= 4.8927
 % Isokinetic= 97.4

Pitot Coefficient= 0.84
 Sampling Time (Minutes)= 60.0
 Nozzle Diameter (mm)= 6.05
 Stack Axis #1 (Meters)= 0.838
 Stack Axis #2 (Meters)= 1.245
 Rectangular Stack
 Stack Area (Square Meters)= 1.043

Stack Velocity (Actual, m/min)= 1,172
 Flow rate (Actual, Cubic m/min)= 1,223
 Flow rate (Standard, Wet, Cubic m/min)= 932
 Flow rate (Standard, Dry, Cubic m/min)= 755

Particulate Loading - Front Half .

Particulate Weight (g)= 0.0032
 Particulate Loading, Dry Std. (mg/cu m)= 2.6
 Particulate Loading, Actual (mg/cu m)= 1.6
 Emission Rate (kg/hr)= 0.12

Corr. to 7% O2 & 12% CO2
 5.9 5.1

No Back Half Analysis

FILE NAME - 411117r4

RUN # - 4

LOCATION - STACK

DATE - 8/6/91

PROJECT # - 411117

PROG.=VER 06/27/89

08-21-1991 04:30:51

Point #	Delta P (in. H2O)	Delta H (in. H2O)	Stack T (F)	Meter T In(F) Out(F)
1	0.860	1.70	219	84 83
2	0.520	1.00	227	89 85
3	0.470	0.92	225	91 86
4	0.470	0.92	223	92 87
5	0.950	1.90	221	92 88
6	0.730	1.50	219	96 89
7	0.590	1.20	219	96 90
8	0.530	1.05	214	97 91
9	1.200	2.40	213	96 91
10	0.810	1.65	211	100 92
11	0.710	1.45	212	101 94
12	0.620	1.25	211	102 95
13	1.400	2.85	211	100 95
14	1.000	2.05	211	103 96
15	0.910	1.85	210	104 97
16	0.650	1.35	208	104 98
17	1.500	3.10	207	103 98
18	1.500	3.00	207	104 99
19	1.300	2.70	206	105 98
20	0.920	1.90	204	104 99
21	1.400	2.90	200	102 99
22	1.500	3.00	201	102 98
23	1.500	3.00	201	102 98
24	1.450	3.00	201	102 98

Fraction	Final Wt. (g)	Tare Wt. (g)	Blank Wt. (g)	Net Wt. (g)
DRY CATCH	0.0000	0.0000	0.0000	0.0000
FILTER	31.7917	31.7887	0.0002	0.0028

Fraction	Final Wt. (g)	Tare Wt. (g)	Vol. (ml)	Net Wt. (g)
PROBE RINSE	67.6061	67.6057	100.0	0.0004
IMPINGERS	0.0000	0.0000	0.0	0.0000
Probe Rinse Blank (mg/ml)=	0.0000			
Impinger Blank (mg/ml)=	0.0000			

APPENDIX B

EXAMPLE CALCULATIONS

NOMENCLATURE.

<u>Equation No.</u>	<u>Symbol</u>	<u>Description</u>	<u>Units</u>
1	V_i	Initial meter reading	dcf
	V_f	Final meter reading	dcf
	V_m	Volume meter, actual	dcf
2	P_b	Barometric pressure	in. Hg
	ΔH_{avg}	Average orifice pressure drop	in. H ₂ O
	$T_{m_{avg}}$	Average meter temperature	°F
	$V_{m_{std}}$	Volume meter, standard conditions	dscf
3	V_{lc}	Total moisture collected	grams
	$W_{wc_{std}}$	Volume of water vapor collected, standard conditions	ft ³
	% H ₂ O	Percent moisture by volume	-
4	M_f	Mole fraction of dry gas	-
5	% CO ₂	Percent carbon dioxide by volume, dry	-
	% O ₂	Percent oxygen by volume, dry	-
	% CO	Percent carbon monoxide by volume, dry	-
	% N ₂	Percent nitrogen by volume, dry	-
6	M_d	Molecular weight, dry stack gas	lb/lb-mole
7	M_s	Molecular weight, stack gas	lb/lb-mole
8	θ_i	Sampling time interval	minutes
	D_n	Diameter of nozzle	inches
	ΔP_s	Velocity head of S pitot	in. H ₂ O
	T_s	Temperature of stack gas	°F
	V_{m_i}	Volume of meter per sampling interval	ft ³
9	$\Delta P_{s_{avg}}$	Average velocity head of S pitot	in. H ₂ O
	$T_{s_{avg}}$	Average temperature of stack gss	°F
	P_s	Stack pressure, absolute	in. Hg
	V_s	Average stack gas velocity	fpm
10	θ	Total time of test	minutes
	% I	Percent isokinetic	-
11	ID	Inside diameter of stack	inches
	A_s	Area of stack	in ²
12	Q_s	Stack flowrate, dry standard conditions	dscfm
13	m_n	Total particulate matter collected	mg
	$C_{s_{std}}$	Concentration of particulate collected, dry basis, standard conditions	gr/dscf
14	$C_{s_{act}}$	Concentration of particulate collected, actual conditions	gr/acf
15	E_p	Particulate emission rate	lb/hr

PARTICULATE CALCULATION EQUATIONS

$$1. V_m = V_f - V_i$$

$$2. V_{m_{std}} = \frac{17.64 (V_m) \left(P_b + \frac{\Delta H_{avg}}{13.6} \right)}{T_{m_{avg}} + 460}$$

$$3. V_{wc_{std}} = 0.0471 (V_{lc})$$

$$\% H_2O = \frac{100 (V_{wc_{std}})}{V_{m_{std}} + V_{wc_{std}}}$$

$$4. M_f = \frac{100 - \% H_2O}{100}$$

$$5. \% N_2 = 100 - (\% CO_2 + \% O_2 + \% CO)$$

$$6. M_d = (\% CO_2 \times 0.44) + (\% O_2 \times 0.32) + (\% N_2 + \% CO \times 0.28)$$

$$7. M_s = (M_d \times M_f) + 18(1 - M_f)$$

$$8. V_{m_i} = \frac{5.168 (T_m + 460) (C_p) (\theta_i) (M_f) (D_n^2)}{\sqrt{P_b}} \times \sqrt{\frac{\Delta P_s}{T_s + 460}}$$

$$9. V_s = 5,128.8 (\sqrt{\Delta P_s}_{avg}) \sqrt{\frac{T_{s_{avg}} + 460}{P_s \times M_s}} \times C_p$$

$$10. \% I = \frac{1,039 (T_{s_{avg}} + 460) (V_{m_{std}})}{V_s (\theta) (P_s) (M_f) (D_n^2)}$$

PS = Meter Pressure + (0.74 x Static Pressure)

$$11. A_s = \pi \left(\frac{ID}{2} \right)^2$$

$$12. Q_s = \frac{0.122 (V_s) (A_s) (M_f) (P_s)}{T_{s_{avg}} + 460}$$

$$13. C_{s_{std}} = 0.0154 \left(\frac{m_n}{V_{m_{std}}} \right)$$

$$14. C_{s_{act}} = \frac{17.64 (C_{s_{std}}) (P_s) (M_f)}{T_{s_{avg}} + 460}$$

$$15. E_p = 0.00857 (C_{s_{std}}) (Q_s)$$

Example Calculations

Run 1

- 1) $V_m = (136.482 - 84.502)(1.014)$
 $= 52.708 \text{ dcf}$
- 2) $V_{m_{std}} = (17.64)(52.708)(28.92 + 2.44/13.6)/564$
 $= 47.935 \text{ dscf}$
- 3) $V_{wc_{std}} = (0.0471)(258.4)$
 $= 12.171 \text{ ft}^3$
 $\% \text{ H}_2\text{O} = (100)(12.171)/(47.935 + 12.171)$
 $= 20.2\%$
- 4) $M_f = (100 - 20.2)/100$
 $= 0.798$
- 5) $\% \text{ N}_2 = 100 - (5.5 + 14.5 + 0)$
 $= 80.0\%$
- 6) $M_d = (5.5)(0.44) + (14.5)(0.32) + (80.0 + 0)(0.28)$
 $= 29.46 \text{ lb/lb-mole}$
- 7) $M_s = (29.46)(0.798) + 18(1 - 0.798)$
 $= 27.14 \text{ lb/lb-mole}$
- 8) Not applicable
- 9) $V_s = (5128.8)(1.0317)\sqrt{678/(29.21)(27.14)} \quad (.84)$
 $= 4127$
- 10) $\left[\frac{\% \text{ I} = (1039)(677)(47.935)}{(0.238)^2} \right] / \left[\frac{(4127)(60)(29.21)(0.798)}{(0.238)^2} \right]$
 $= 104.2\%$
- 11) $A_s = 33 \times 49$
 $= 1617 \text{ in}^2$
- 12) $Q_s = (0.122)(4127)(1617)(0.798)(29.21)/(677)$
 $= 27,877$
- 13) $C_{s_{std}} = 0.0154 (31.4/47,935)$
 $= 0.0101 \text{ gr/dscf}$

APPENDIX C

FIELD DATA FORMS

AIRSOURCE TECHNOLOGIES

RUN NUMBER Preliminary

TRAIN -

DATE 8-5-91

PLANT Maske & Jackson - Springfield

PROJECT NUMBER 411117

SAMPLING LOCATION Stack

PROJECT LEADER Baker


CONSOLE OPERATOR Cobb

LAB PERSON Cobb

SUPPORT PERSONNEL R-sdon

TRAVERSE POINT LOCATION FOR CIRCULAR DUCTS

PLANT Masters & Jackson - Springfield
DATE 8-5-91
SAMPLING LOCATION Stack
INSIDE OF FAR WALL TO
• OUTSIDE OF NIPPLE. (DISTANCE A) 35"
INSIDE OF NEAR WALL TO
OUTSIDE OF NIPPLE. (DISTANCE B) 2"
STACK I.D.. (DISTANCE A - DISTANCE B) 33" x 49"
NEAREST UPSTREAM DISTURBANCE 24 ft
NEAREST DOWNSTREAM DISTURBANCE 24 ft
CALCULATOR Cobb




SCHEMATIC OF SAMPLING LOCATION

[illegible]

PRELIMINARY VELOCITY TRAVERSE

PLANT Mining & Jackson - Spraysfield
DATE 8-5-91
LOCATION Stack
STACK I.D. 33"
BAROMETRIC PRESSURE, IN. Hg 29.92
SITE TO BARO. ELEVATION (F.T.) 0
CORRECTED BARO. PRESSURE 29.92
TEMPERATURE METER NO. 2
THERMOCOUPLE I.D. NO. 3
PITOT(CS) 3
TIME (24 HR.) _____
OPERATORS G. L. R. Jones
STACK GAUGE PRES. (STATIC, IN. H₂O) .39
PITOT LEAK CK. AT 3" H₂O OK
REMARKS:



SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER	VELOCITY HEAD ΔP_s IN H ₂ O	STACK TEMP. T _s , °F	CYCLONIC FLOW DET.	
			ΔP_3 AT 0° REFERENCE	ANGLE (deg) WHICH YIELDS A NULL ΔP
3-1	1.5	216	.29	6
2	1.25	216	-.03	2
3	.94	219	-.05	2
4	.73	222	-.03	4
5-1	1.2	217	.28	5
2	.93	216	.05	3
3	.67	215	-.05	2
4	.56	212	-.02	8
AVERAGES	.97	217		

TRAVERSE POINT NUMBER	VELOCITY HEAD ΔP_s IN. H ₂ O	STACK TEMP T _s , °F	CYCLONIC FLOW DET.	
			ΔP_s AT 0° REFERENCE	ANGLE (deg) WHICH YIELDS A NULL ΔP
AVERAGES				

* AVERAGE OF α MUST BE 1.0 OR BETTER TO BE ACCEPTABLE

AIRSOURCE TECHNOLOGIES

RUN NUMBER 1

TRAIN Particulates

DATE 8-5-91

PLANT Master + Tanker - Springfield

PROJECT NUMBER 411117

SAMPLING LOCATION Stack

PROJECT LEADER Baker

CONSOLE OPERATOR Cobb

LAB PERSON Cobb


SUPPORT PERSONNEL R. Gordon

FIELD DATA

RUN NO. 1
 PROJECT NO. 41117
 PLANT Mentor-Jackson-Springfield
 DATE 8-5-91
 SAMPLING LOCATION Stack
 SAMPLE TYPE Particulate
 OPERATOR Cobb
 FILTER NO. A9
 RECORD DATA EVERY 2.5 MIN.
 UMBILICAL/SAMPLER HOOKUP 2

PROBE NO. P1
 PROBE LENGTH AND TYPE 5' glass
 SAMPLE BOX NO. 2
 METER BOX NO. 2
 THERMOCOUPLE I.D. NO. 1
 UMBILICAL CORD I.D. NO. 50'
 UMBILICAL CORD I.D. NO. -
 NOZZLE NO. A8

NOZZLE DIA. 1.238
 ASSUMED MOISTURE % 15
 METER ΔH₀ 1.014
 METER CORRECTION 1.859 1.014
 PITOT NO. 1
 PITOT COEFFICIENT .84
 BAROMETRIC PRESSURE 28.92
 SITE TO BANO. ELEVATION (ft.) 0
 CONNECTED B.P. (0.1 in./100 ft.) 28.92
 STATIC PRESSURE 1.39



SCHEMATIC OF TRAVERSE
POINT LAYOUT

PITOT LEAK CHECK $\geq 3''$ H₂O

	INITIAL	FINAL	INITIAL	FINAL	INITIAL	FINAL
TIME (24 hr)	1116	1244				
PASS/FAIL		Pass				

SAMPLE TRAIN LEAK CHECKS

	INITIAL	FINAL	INITIAL	FINAL	INITIAL
TIME (24 hr)	1110	1240			
VACUUM, in. Hg	$\geq 15''$	10"	$\geq 15''$		$\geq 15''$
CFM	0.003	0.002			
VOLUMES					
FINAL					
INITIAL					
DIFFERENCE					

SAMPLE TRAIN LEAK CHECKS

	FINAL	INITIAL	FINAL	INITIAL	FINAL
TIME (24 hr)					
VACUUM, in. Hg		$\geq 15''$		$\geq 15''$	
CFM					
VOLUMES					
FINAL					
INITIAL					
DIFFERENCE					

INITIAL VOLUME 84.502
 FINAL VOLUME 136.482
 LEAK CHECK VOLUME 0.0
 ADJUSTED FINAL VOLUME 136.482

COMMENTS

RUN NO. 1		SAMPLING LOCATION Stack		PROJECT NO. 41117		OPERATOR Calh								
TRAVERSE POINT NUMBER	CLOCK TIME (24-hr.)		GAS METER READING (V _m), ft ³		VELOCITY HEAD (Δp), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (Δh), in. H ₂ O		STACK TEMP. (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VAC., in. Hg	IMPINGING TEMP., °F	PROBE TEMP., °F	FILTER TEMP., °F
	SAMPLING TIME, min		INITIAL	ACTUAL		DESIRED	ACTUAL		INLET (T _m), °F	OUTLET (T _m), °F				
1-1	0	11:19	87.04	-	1.4	3.2	3.2	204	102	101	8	65	250	255
2	25	11:21	89.55	-	1.4	3.14	3.15	214	99	100	8	63	254	254
3	5	11:24	91.70	-	1.3	2.9	2.9	219	101	101	8	66	247	255
4	7.5	11:26	94.29	-	1.2	2.68	2.7	219	102	101	7	68	249	253
2-1	10	11:29	96.98	-	1.6	3.6	3.6	215	103	102	9	65	255	254
2-2	12.5	11:34	100.85	-	1.6	3.6	3.6	215	103	101	9	63	254	254
3	15	11:37	102.21	-	1.4	3.18	3.2	212	106	102	8	64	253	255
4	17.5	11:39	104.47	-	1.1	2.53	2.5	203	106	102	7	65	248	255
3-1	20	11:42	107.01	-	1.7	3.91	3.9	201	104	101	10	65	253	254
2	22.5	11:49	109.53	-	1.3	3.0	3.0	200	104	102	8	64	251	255
3	25	11:52	111.70	-	1.0	2.3	2.3	201	105	102	6	63	251	253
4	27.5	11:54	113.97	-	0.94	2.15	2.15	206	105	102	4	64	254	251
1	30	11:57	115.72	-	1.4	3.16	3.15	214	104	102	8	65	253	252
2	32.5	12:03	117.86	-	0.98	2.18	2.2	223	104	102	6	63	252	252
3	35	12:06	119.73	-	0.75	1.67	1.7	227	107	104	5	65	255	259
4	37.5	12:08	121.35	-	1.6	1.33	1.35	226	107	104	4	65	256	254
5-1	40	12:11	124.41	-	1.2	2.68	2.7	225	107	105	6	65	253	253
2	42.5	12:17	125.66	-	0.94	2.08	2.1	231	107	105	6	55	249	254
3	45	12:20	127.48	-	1.71	1.57	1.6	231	108	106	5	55	248	253
4	47.5	12:22	129.06	-	1.62	1.38	1.4	228	108	106	4	56	253	251
5	50	12:25	130.98	-	1.88	1.97	1.2	224	108	106	5	62	254	252
6-1	52.5	12:30	132.92	-	1.88	1.97	2.0	226	109	107	5	56	254	252
2	55	12:33	133.93	-	1.7	1.57	1.6	225	110	108	5	58	250	253
3	57.5	12:36	135.72	-	1.58	1.3	1.3	225	112	109	4	60	251	254
4	60	12:38	137.35	-	1.58	1.3	1.3	225						

COMMENTS at 99.67 at 123.60

PARTICULATE
(w/back half work up)

Run No. Run 1 Date: 8-5-91
Project No. 411117 Plant: Western Balkan Springfield
Recovery Person Cobb/Rogden

SAMPLE BOX NO. 2

FILTER NO. A9

Color/Condition _____

<u>IMP. 1</u> MGBS H2O 100 ml	<u>IMP. 2</u> GBS H2O 100 ml	<u>IMP. 3</u> MGBS DRY	<u>IMP. 4</u> MGBS SILICA
--	---------------------------------------	------------------------------	---------------------------------

	<u>FINAL</u>	<u>INITIAL</u>	<u>DIFFERENCE</u>	
IMP. 1	<u>797.6</u>	<u>587.5</u>	<u>210.1</u>	
IMP. 2	<u>557.3</u>	<u>520.5</u>	<u>33.8</u>	
IMP. 3	<u>487.4</u>	<u>482.7</u>	<u>4.7</u>	
IMP. 4	<u>688.3</u>	<u>678.5</u>	<u>9.8</u>	% Blue <u>60</u>
TOTAL			<u>(258.4)</u>	

Sample Bottles

	<u>FRONT HALF</u> <u>ACETONE</u>	<u>CONDENSATE</u> <u>H2O</u>
FINAL	_____	_____
INITIAL	_____	_____
DIFFERENCE	<u>()</u>	<u>()</u>
LEVEL MARKED	_____	_____

Blanks

FILTER _____ ACETONE _____ WATER _____

COMMENTS: _____

Volumes

MOISTURE VOLUME 258.4 FRONT HALF ACETONE _____
CONDENSATE H2O _____ BACK HALF RINSE _____

Reviewed by _____ Date _____

Plant Moston Jackson Springfield Run No. 1
Project No. 41412 Date 8-5-91

Sample Location Stack
Sample Type (Multi-Point, Single-Point) _____
Bag Type (Mylar, Tedlar) _____
Console No. 2

Leak Check: Before 0 After 0
Flow Meter Setting 0.5 L/min
Total Sampling Time (min.) 57
Estimated Actual Volume (liters) 28.5

[illegible]

OXYGEN AND CARBON DIOXIDE BY ORSAT

Byrd

PROJECT NO. 44417 RUN NO. 1 ORSAT LEAK CHECK BEFORE ANALYSIS:
 SAMPLE NO. 1 DATE 8-5-91 BURETTE _____ CHANGE IN 4 MIN.
 PLANT SAMPLING LOCATION Stack PIPETTES _____ CHANGE IN 4 MIN.
 ANALYSIS TIME (24hr-CLOCK) 1 PM ORSAT LEAK CHECK AFTER ANALYSIS:
 SAMPLE TYPE (BAG, GRAB) _____ BURETTE _____ CHANGE IN 4 MIN.
 OPERATOR Chubb PIPETTES _____ CHANGE IN 4 MIN.

RUN GAS	1		2		3		AVERAGE NET VOLUME
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET	
CO ₂	1 <u>5.5</u>		1 <u>5.5</u>		1 <u>5.5</u>		<u>5.5</u>
	2		2		2		
	3		3		3		
O ₂ (NET IS ACTUAL O ₂ READING MINUS ACTUAL CO ₂ READING)	1 <u>14.5</u>		1 <u>14.5</u>		1 <u>14.5</u>		<u>14.5</u>
	2		2		2		
	3		3		3		

Acceptance Criteria

CO ₂	> 4%	.3% by Volume	O ₂	≥ 15%	.2% by Volume
	≤ 4%	.2% by Volume		< 15%	.3% by Volume

Comments:

AIRSOURCE TECHNOLOGIES

RUN NUMBER 3

TRAIN Particulate

DATE 8-5-91

PLANT Masters - Jackson - Springfield

PROJECT NUMBER 411117

SAMPLING LOCATION Stack

PROJECT LEADER Baker

CONSOLE OPERATOR Cobb

LAB PERSON Cobb


SUPPORT PERSONNEL Rizdon

FIELD DATA

RUN NO. 3
 PROJECT NO. 41117
 PLANT Muskogee/Springfield
 DATE 8-5-91
 SAMPLING LOCATION Stack
 SAMPLE TYPE Particulate
 OPERATOR Cosh
 FILTER NO. 1007
 RECORD DATA EVERY 2.5 MIN.
 UMBILICAL/SAMPLER/HOOKUP 4

PROBE NO. 3
 PROBE LENGTH AND TYPE 5' glass
 SAMPLE BOX NO. 4
 METER BOX NO. 2
 THERMOCOUPLE I.D. NO. 3
 UMBILICAL CORD I.D. NO. 50
 UMBILICAL CORD I.D. NO. -
 NOZZLE NO. E3

NOZZLE DIA. 0.174
 ASSUMED MOISTURE % 20
 METER ΔH 1.859
 METER CONNECTION 1.014
 PITOT NO. 3
 PITOT COEFFICIENT .84
 BAROMETRIC PRESSURE 28.85
 SITE TO BARO. ELEVATION (ft.) 0
 CONNECTED B.P. (0.1 in./100 ft.) 28.85
 STATIC PRESSURE .39



SCHEMATIC OF TRAVERSE POINT LAYOUT

PITOT LEAK CHECK $\geq 3''$ H₂O

	INITIAL	FINAL	INITIAL	FINAL	INITIAL	FINAL
TIME (24 hr)	1543	1751				
PASS/FAIL		PASS				

SAMPLE TRAIN LEAK CHECKS

	INITIAL	FINAL	INITIAL	FINAL	INITIAL
TIME (24 hr)	1542	1752			
VACUUM, in. Hg	$\geq 15''$	3''	$\geq 15''$		$\geq 15''$
CFM	0.006	0.002			
VOLUMES					
FINAL					
INITIAL					
DIFFERENCE					

SAMPLE TRAIN LEAK CHECKS

	FINAL	INITIAL	FINAL	INITIAL	FINAL
TIME (24 hr)					
VACUUM, in. Hg		$\geq 15''$		$\geq 15''$	
CFM					
VOLUMES					
FINAL					
INITIAL					
DIFFERENCE					

INITIAL VOLUME 188.308
 FINAL VOLUME 215.553
 LEAK CHECK VOLUME 0.000
 ADJUSTED FINAL VOLUME 215.553

COMMENTS

RUN NO. 3 SAMPLING LOCATION Stark PROJECT NO. 41117
 DATE 8-5-91 OPERATOR C. Cabot

TRAVERSE POINT NUMBER	CLOCK TIME (24-hr.)		GAS METER READING (V _m), ft ³		VELOCITY HEAD (Δp), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMP. (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VAC., in. Hg	IMPINGER TEMP., °F	PROBE TEMP., °F	FILTER TEMP., °F
	SAMPLING TIME, min	1600	INITIAL	ACTUAL		DESIRED	ACTUAL		INLET (T _m), °F	OUTLET (T _m), °F				
1-1	2.5	1602	189.37	189.33	1.9	0.55	1.55	189	113	110	2	65	260	253
2	5	1605	190.74	190.70	1.5	.91	.91	195	111	111	3	63	253	252
3	7.5	1607	192.15	-	1.6	.96	.96	201	112	112	3	59	261	251
4	10	1610	193.42	193.39	1.3	.78	.78	205	113	113	2	54	249	253
2-1	12.5	1615	194.82	194.77	1.6	.94	.94	215	113	112	2	62	259	252
2	15	1618	196.21	196.10	1.6	.93	.93	223	114	113	3	58	252	252
3	17.5	1620	197.46	197.33	1.3	.76	.76	222	114	112	3	57	262	253
4	20	1623	198.50	198.397	1.9	.52	.52	222	114	112	2	58	252	251
3-1	22.5	1627	199.89	199.74	1.6	.94	.94	218	114	112	2	59	253	249
2	25	1630	201.09	200.95	1.2	.70	.7	217	107	108	2	56	244	244
27.5	1632	202.14	202.03	202.03	1.94	.54	.54	216	101	102	2	56	256	248
30	1635	202.99	202.856	202.856	1.62	.35	.35	217	99	99	1	58	244	248
32.5	1639	204.30	-	-	1.5	.86	.86	217	98	99	2	60	255	250
35	1642	205.32	205.28	205.28	1.9	.51	.51	222	98	99	2	59	251	251
37.5	1644	206.34	206.17	206.17	1.74	.42	.42	221	98	99	2	59	252	254
40	1647	207.14	207.147	207.147	1.7	.4	.4	215	96	96	2	58	245	248
42.5	1650	208.53	208.555	208.555	1.7	.97	.97	215	74	95	2	57	249	249
45	1733	209.72	209.68	209.68	1.2	.72	.72	159	78	78	2	65	256	250
47.5	1735	210.66	210.68	210.68	1.79	.45	.45	190	79	79	2	59	247	249
50	1738	211.51	211.485	211.485	1.64	.36	.37	194	80	79	2	61	258	251
52.5	1740	212.66	212.63	212.63	1.674	.69	.69	196	81	79	2	57	257	253
55	1743	213.82	-	-	1.2	.69	.69	198	82	80	2	54	247	251
57.5	1745	214.85	214.76	214.76	1.94	.54	.54	196	83	80	2	55	256	253
60	1748	215.66	215.553	215.553	1.58	.33	.33	192	84	81	2	58	250	252

COMMENTS at down due to rain 65 1.2

PARTICULATE
(w/back half work up)

Run No. 3
Project No. 41117

Date: 8-5-91
Plant: MUSKIE-Indian-Springfield

Recovery Person Cobb, R. J. Don

SAMPLE BOX NO. 4

FILTER NO. 1007

Color/Condition Clean

<u>IMP. 1</u> MGBS H2O 100 ml	<u>IMP. 2</u> GBS H2O 100 ml	<u>IMP. 3</u> MGBS DRY	<u>IMP. 4</u> MGBS SILICA
--	---------------------------------------	------------------------------	---------------------------------

	FINAL	INITIAL	DIFFERENCE	
IMP. 1	<u>756.7</u>	<u>614.4</u>	<u>142.3</u>	
IMP. 2	<u>625.9</u>	<u>591.1</u>	<u>14.8</u>	
IMP. 3	<u>501.7</u>	<u>498.0</u>	<u>3.7</u>	
IMP. 4	<u>700.9</u>	<u>695.6</u>	<u>5.3</u>	% Blue <u>50</u>

TOTAL (165.5)

Sample Bottles

	FRONT HALF ACETONE	CONDENSATE H2O
FINAL	_____	_____
INITIAL	_____	_____
DIFFERENCE	(_____)	(_____)

LEVEL MARKED _____

Blanks

FILTER _____ ACETONE _____ WATER _____

COMMENTS: _____

Volumes

MOISTURE VOLUME
CONDENSATE H2O

165.5

FRONT HALF ACETONE _____
BACK HALF RINSE _____

Reviewed by _____ Date _____

Plant Muster - Jackson Run No. 3
Project No. 41117 Date 8-5-91

Samle Location Stack
Sample Type (Multi-Point, Single-Point) _____
Bag Type (Mylar, Tedlar) _____
Console No. 2

Leak Check: Before Ø After Ø
Flow Meter Setting 15 L/min
Total Sampling Time (min.) 49
Estimated Actual Volume (liters) 24.5

[illegible]

OXYGEN AND CARBON DIOXIDE BY ORSAT

PROJECT NO. 411117 RUN NO. 3
 SAMPLE NO. 3 DATE 8-5-91
 PLANT SAMPLING LOCATION Stack
 ANALYSIS TIME (24hr-CLOCK) 1805
 SAMPLE TYPE (DAG, GRAB) GRAB
 OPERATOR cebb

ORSAT LEAK CHECK BEFORE ANALYSIS:
 BURETTE _____ CHANGE IN 4 MIN.
 PIPETTES _____ CHANGE IN 4 MIN.
 ORSAT LEAK CHECK AFTER ANALYSIS:
 BURETTE _____ CHANGE IN 4 MIN.
 PIPETTES _____ CHANGE IN 4 MIN.

RUN GAS	1		2		3		AVERAGE NET VOLUME
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET	
CO ₂	1 6 2 3		1 6 2 3		1 6 2 3		6
O ₂ (NET IS ACTUAL O ₂ READING MINUS ACTUAL CO ₂ READING)	1 16.5 2 3		1 16.0 2 3		1 16.0 2 3		16.2

Acceptance Criteria

CO₂ > 4% .3% by Volume O₂ ≥ 15% .2% by Volume
 ≤ 4% .2% by Volume < 15% .3% by Volume

Comments:

AIRSOURCE TECHNOLOGIES

RUN NUMBER

4

TRAIN

Particulate

DATE

8-6-91

PLANT

Miskin & Jackson - Springfield

PROJECT NUMBER

41117

SAMPLING LOCATION

Stack

PROJECT LEADER

Baker

CONSOLE OPERATOR

Cobb

LAB PERSON

Cobb

SUPPORT PERSONNEL


H. J. Don

FIELD DATA

RUN NO. 4
 PROJECT NO. 411117
 PLANT Master Johnson - Springfield
 DATE 8-6-91
 SAMPLING LOCATION stack
 SAMPLE TYPE Particulate
 OPERATOR Cobb
 FILTER NO. 1009
 RECORD DATA EVERY 2.5 MIN.
 UMBILICAL/SAMPLER HOOKUP 3

PROBE NO. 2
 PROBE LENGTH AND TYPE 5' glass
 SAMPLE BOX NO. 3
 METER BOX NO. 2
 THERMOCOUPLE I.D. NO. 2
 UMBILICAL CORD I.D. NO. 50
 UMBILICAL CORD I.D. NO. -
 NOZZLE NO. A8

NOZZLE DIA. 1.238
 ASSUMED MOISTURE % 20
 METER ΔH @ 1.859
 METER CONNECTION 1.014
 PITOT NO. 2
 PITOT COEFFICIENT .84
 BAROMETRIC PRESSURE 28.97
 SITE TO BARO. ELEVATION (ft.) 0
 CORRECTED B.P. (0.1 in./100 ft.) 28.97
 STATIC PRESSURE .39



SCHEMATIC OF TRAVERSE POINT LAYOUT

PITOT LEAK CHECK $\geq 3''$ H₂O

	INITIAL	FINAL	INITIAL	FINAL	INITIAL	FINAL
TIME (24 hr)	0720	0841				
PASS/FAIL		Pass				

SAMPLE TRAIN LEAK CHECKS

	INITIAL	FINAL	INITIAL	FINAL	INITIAL
TIME (24 hr)	0723	0839			
VACUUM, in. Hg	$\geq 15''$	19''	$\geq 15''$		$\geq 15''$
CFM	0.012	0.003			
VOLUMES					
FINAL					
INITIAL					
DIFFERENCE					

SAMPLE TRAIN LEAK CHECKS

	FINAL	INITIAL	FINAL	INITIAL	FINAL
TIME (24 hr)					
VACUUM, in. Hg		$\geq 15''$		$\geq 15''$	
CFM					
VOLUMES					
FINAL					
INITIAL					
DIFFERENCE					

INITIAL VOLUME 218.317
 FINAL VOLUME 264.073
 LEAK CHECK VOLUME 0.000
 ADJUSTED FINAL VOLUME 264.073

COMMENTS

RUN NO. 4 SAMPLING LOCATION Stack PROJECT NO. 411117
 DATE 8-6-91 OPERATOR Colb

TRAVERSE POINT NUMBER	CLOCK TIME (24-hr.)	GAS METER READING (V _m), ft ³		VELOCITY HEAD (ΔP _v), in. H ₂ O	ORIFICE PRESSURE (ΔH), in. H ₂ O		STACK TEMP. (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VAC., in. Hg	IMPINGER TEMP., °F	PROBE TEMP., °F	FILTER TEMP., °F
		INITIAL	ACTUAL		DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F				
6-1	25 0729	220.12	220.07	1.86	1.68	1.7	219	84	83	6	65	256	254
2	5 0732	221.53	221.60	1.52	1.01	1.0	227	89	85	4	60	256	258
3	75 0734	222.87	222.94	1.47	1.92	1.92	225	91	86	4	59	250	258
4	10 0737	224.21	224.24	1.47	1.92	1.92	223	92	87	4	59	252	257
5-1	125 0741	226.13	-	1.95	1.87	1.9	221	92	88	7	61	255	257
2	15 0744	227.82	227.68	1.73	1.45	1.5	219	96	89	6	61	253	254
3	175 0746	229.34	229.21	1.59	1.17	1.2	219	96	90	5	61	253	254
4	20 0749	230.79	230.675	1.53	1.06	1.05	214	97	91	4	63	253	254
4-1	225 0752	232.97	232.67	1.2	2.41	2.4	213	96	91	10	64	255	253
2	25 0755	234.76	234.54	1.81	1.64	1.65	211	100	92	6	64	253	254
3	275 0757	236.47	236.16	1.71	1.44	1.45	212	101	94	5	61	254	254
4	30 0800	238.05	237.714	1.62	1.26	1.25	211	102	95	5	56	253	253
3-1	325 0803	240.43	239.95	1.4	2.84	2.85	211	100	95	13	58	254	254
2	35 0806	242.44	242.03	1.0	2.04	2.05	211	103	96	9	58	254	253
3	375 0808	244.37	243.96	1.91	1.86	1.85	210	104	97	8	58	252	253
4	40 0811	246.00	-	1.65	1.33	1.35	208	104	98	5	58	254	254
2-1	425 0815	248.48	-	1.5	3.08	3.1	207	103	98	17	59	252	254
2	45 0818	250.97	250.18	1.5	3.09	3.0	207	104	99	19	60	250	250
3	475 0820	253.38	252.47	1.3	2.68	2.7	206	105	98	14	61	253	254
4	50 0823	255.24	254.524	1.92	1.90	1.9	204	104	99	7	62	250	250
1-1	525 0827	257.64	256.95	1.4	2.91	2.9	200	102	99	19	61	252	254
2	55 0830	260.13	259.32	1.5	3.11	3.0	201	102	98	19	62	250	251
3	575 0832	262.62	261.71	1.5	3.11	3.0	201	102	98	19	63	252	252
4	600 0835	265.07	264.073	1.45	3.0	3.0	201	102	98	19	63	252	253

COMMENTS

PARTICULATE

Run No. 4
Project No. 411117

Date: 8-8-91
Plant: Western Toluene Springfield

Recovery Person Chad Heston

SAMPLE BOX NO. 3

FILTER NO. 1008/1009 Color/Condition Clean

<u>IMP. 1</u>	<u>IMP. 2</u>	<u>IMP. 3</u>	<u>IMP. 4</u>
MGBS	GBS	MGBS	MGBS
H2O	H2O	DRY	SILICA
100 ml	100 ml		

	<u>FINAL</u>	<u>INITIAL</u>	<u>DIFFERENCE</u>	
IMP.1	<u>769.4</u>	<u>587.3</u>	<u>182.1</u>	
IMP.2	<u>606.8</u>	<u>593.0</u>	<u>13.8</u>	
IMP.3	<u>488.3</u>	<u>485.1</u>	<u>3.2</u>	
IMP.4	<u>641.0</u>	<u>627.0</u>	<u>14.0</u>	% Blue <u>50</u>

TOTAL (213.1)

Sample Bottles

FRONT HALF
ACETONE

FINAL
INITIAL
DIFFERENCE ()

LEVEL MARKED

Blanks

FILTER ACETONE

COMMENTS:

MOISTURE VOLUME 213.1 Volumes FRONT HALF ACETONE

Reviewed by Date

Plant Moston / Johnson - Springfield Run No. 4
Project No. 41117 Date 8-6-81

Sample Location 5 Fork
 Sample Type (Multi-Point, Single-Point) _____
 Bag Type (Mylar, Tedlar) _____
 Console No. 2

Leak Check: Before 0 After 0
Flow Meter Setting 0.5 l/min
Total Sampling Time (min.) 54 min
Estimated Actual Volume (liters) 27 L

[illegible]

OXYGEN AND CARBON DIOXIDE BY ORSAT

Fynite

PROJECT NO. 41117 RUN NO. 4
 SAMPLE NO. 4 DATE 8-6-91
 PLANT SAMPLING LOCATION Stack
 ANALYSIS TIME (24hr-CLOCK) _____
 SAMPLE TYPE (BAG, GRAB) _____
 OPERATOR CRK

ORSAT LEAK CHECK BEFORE ANALYSIS:
 BURETTE _____ CHANGE IN 4 MIN.
 PIPETTES _____ CHANGE IN 4 MIN.
 ORSAT LEAK CHECK AFTER ANALYSIS:
 BURETTE _____ CHANGE IN 4 MIN.
 PIPETTES _____ CHANGE IN 4 MIN.

GAS \ RUN	1		2		3		AVERAGE NET VOLUME
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET	
CO ₂	1 5.5 2 3		1 5.0 2 3		1 5.0 2 3		6.2
O ₂ (NET IS ACTUAL O ₂ READING MINUS ACTUAL CO ₂ READING)	1 14.5 2 3		1 15.0 2 3		1 14.5 2 3		14.7

Acceptance Criteria

CO₂ > 4% .3% by Volume O₂ ≥ 15% .2% by Volume
 ≤ 4% .2% by Volume < 15% .3% by Volume

Comments:

IOWA DEPARTMENT OF NATURAL RESOURCES

VISIBLE EMISSIONS OBSERVATIONS

		0	15	30	45	XX	0	15	30	45
PLANT NAME		0	0	0	0	30	0	0	0	0
ADDRESS		1	0	0	0	31	0	0	0	0
DATE		2	0	0	0	32	0	0	0	0
TIME OF OBSERVATION		3	0	0	0	33	0	0	0	0
BEGIN	END	4	0	0	0	34	0	0	0	0
SOURCE IDENTIFICATION		5	0	0	0	35	0	0	0	0
REGULATION(S)		6	0	0	0	36	0	0	0	0
FUEL BURNED		7	0	0	0	37	0	0	0	0
OBSERVATION POINT/POSITION OF SUN		8	0	0	0	38	0	0	0	0
		9	0	0	0	39	0	0	0	0
		10	0	0	0	40	0	0	0	0
		11	0	0	0	41	0	0	0	0
		12	0	0	0	42	0	0	0	0
		13	0	0	0	43	0	0	0	0
		14	0	0	0	44	0	0	0	0
		15	0	0	0	45	0	0	0	0
DISTANCE FROM STACK		16	0	0	0	46	0	0	0	0
DIRECTION FROM STACK		17	0	0	0	47	0	0	0	0
STACK HEIGHT		18	0	0	0	48	0	0	0	0
SKY CONDITION		19	0	0	0	49	0	0	0	0
WIND SPEED		20	0	0	0	50	0	0	0	0
WIND DIRECTION		21	0	0	0	51	0	0	0	0
TEMPERATURE		22	0	0	0	52	0	0	0	0
COLOR OF PLUME		23	0	0	0	53	0	0	0	0
ODORS		24	0	0	0	54	0	0	0	0
		25	0	0	0	55	0	0	0	0
		26	0	0	0	56	0	0	0	0
		27	0	0	0	57	0	0	0	0
		28	0	0	0	58	0	0	0	0
		29	0	0	0	59	0	0	0	0
COMMENTS										
OPACITY READINGS										
RANGE	TO	AVERAGE								
SIGNATURE OF OBSERVER										

IOWA DEPARTMENT OF NATURAL RESOURCES

VISIBLE EMISSIONS OBSERVATIONS

		0	15	30	45	XX	0	15	30	45
PLANT NAME <i>Astec Asphalt</i>		0	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	30	<i>0</i>	<i>0</i>	<i>0</i>
ADDRESS		1	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	31	<i>0</i>	<i>0</i>	<i>0</i>
DATE <i>8-5-91</i>		2	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	32	<i>0</i>	<i>0</i>	<i>0</i>
TIME OF OBSERVATION		3	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	33	<i>0</i>	<i>0</i>	<i>0</i>
BEGIN <i>0947</i>	END <i>1047</i>	4	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	34	<i>0</i>	<i>0</i>	<i>0</i>
SOURCE IDENTIFICATION <i>Asphalt Plant</i>		5	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	35	<i>0</i>	<i>0</i>	<i>0</i>
REGULATION(S) <i>Method 9</i>		6	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	36	<i>0</i>	<i>0</i>	<i>0</i>
FUEL BURNED		7	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	37	<i>0</i>	<i>0</i>	<i>0</i>
OBSERVATION POINT/POSITION OF SUN		8	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	38	<i>0</i>	<i>0</i>	<i>0</i>
STACK LOCATE SUN ON ARC		9	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	39	<i>0</i>	<i>0</i>	<i>0</i>
		10	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	40	<i>0</i>	<i>0</i>	<i>0</i>
		11	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	41	<i>0</i>	<i>0</i>	<i>0</i>
		12	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	42	<i>0</i>	<i>0</i>	<i>0</i>
DISTANCE FROM STACK <i>60 yds</i>	DIRECTION FROM STACK <i>NE</i>	13	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	43	<i>0</i>	<i>0</i>	<i>0</i>
STACK HEIGHT <i>30'</i>	SKY CONDITION <i>Clear</i>	14	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	44	<i>0</i>	<i>0</i>	<i>0</i>
WIND SPEED <i>5-10 mph</i>	WIND DIRECTION <i>SE</i>	15	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	45	<i>0</i>	<i>0</i>	<i>0</i>
TEMPERATURE <i>80°</i>	COLOR OF PLUME <i>None</i>	16	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	46	<i>0</i>	<i>0</i>	<i>0</i>
ODORS <i>11 Yes</i> <i>10 No</i>		17	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	47	<i>0</i>	<i>0</i>	<i>0</i>
COMMENTS		18	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	48	<i>0</i>	<i>0</i>	<i>0</i>
		19	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	49	<i>0</i>	<i>0</i>	<i>0</i>
		20	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	50	<i>0</i>	<i>0</i>	<i>0</i>
		21	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	51	<i>0</i>	<i>0</i>	<i>0</i>
		22	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	52	<i>0</i>	<i>0</i>	<i>0</i>
		23	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	53	<i>0</i>	<i>0</i>	<i>0</i>
		24	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	54	<i>0</i>	<i>0</i>	<i>0</i>
		25	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	55	<i>0</i>	<i>0</i>	<i>0</i>
		26	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	56	<i>0</i>	<i>0</i>	<i>0</i>
OPACITY READINGS		27	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	57	<i>0</i>	<i>0</i>	<i>0</i>
RANGE <i>0</i>	TO <i>0</i>	28	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	58	<i>0</i>	<i>0</i>	<i>0</i>
SIGNATURE OF OBSERVER <i>L. Mary</i>		29	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	59	<i>0</i>	<i>0</i>	<i>0</i>

IOWA DEPARTMENT OF NATURAL RESOURCES

VISIBLE EMISSIONS OBSERVATIONS

		0	15	30	45	XX	0	15	30	45
PLANT NAME		0	0	0	0	30	0	0	0	0
ADDRESS		1	0	0	0	31	0	0	0	0
DATE		2	0	0	0	32	0	0	0	0
TIME OF OBSERVATION		3	0	0	0	33	0	0	0	0
BEGIN	END	4	0	0	0	34	0	0	0	0
SOURCE IDENTIFICATION		5	0	0	0	35	0	0	0	0
REGULATION(S)		6	0	0	0	36	0	0	0	0
FUEL BURNED		7	0	0	0	37	0	0	0	0
OBSERVATION POINT/POSITION OF SUN		8	0	0	0	38	0	0	0	0
DISTANCE FROM STACK		9	0	0	0	39	0	0	0	0
DIRECTION FROM STACK		10	0	0	0	40	0	0	0	0
STACK HEIGHT		11	0	0	0	41	0	0	0	0
SKY CONDITION		12	0	0	0	42	0	0	0	0
WIND SPEED		13	0	0	0	43	0	0	0	0
WIND DIRECTION		14	0	0	0	44	0	0	0	0
TEMPERATURE		15	0	0	0	45	0	0	0	0
COLOR OF PLUME		16	0	0	0	46	0	0	0	0
ODORS		17	0	0	0	47	0	0	0	0
COMMENTS		18	0	0	0	48	0	0	0	0
OPACITY READINGS		19	0	0	0	49	0	0	0	0
RANGE	TO	20	0	0	0	50	0	0	0	0
AVERAGE		21	0	0	0	51	0	0	0	0
SIGNATURE OF OBSERVER		22	0	0	0	52	0	0	0	0
		23	0	0	0	53	0	0	0	0
		24	0	0	0	54	0	0	0	0
		25	0	0	0	55	0	0	0	0
		26	0	0	0	56	0	0	0	0
		27	0	0	0	57	0	0	0	0
		28	0	0	0	58	0	0	0	0
		29	0	0	0	59	0	0	0	0

APPENDIX D

LABORATORY DATA

FILTER WEIGHINGS

Project No. _____

Analyst: _____

Filter Type and Size: _____

Weight Unit: _____

Filter Treatment: _____

Tare Weighing:

Date/Time:	8-4-91/12200	8-5-91/14000	_____	_____
Balance Check:	_____	_____	_____	_____
Weight Value:	33	50	_____	_____
Initial Check:	32.9995	49.9998	_____	_____
Final Check:	32.9996	49.9997	_____	_____
Filter No.	First Weighing	Second Weighing	Third Weighing	Average
1007 ✓	29.0208	29.0211	_____	29.0210
1008	30.6414	30.6414	_____	_____
1009 ✓	31.7886	31.7887	_____	31.7887
1010 ✓	32.3480	32.3481	_____	32.3481
1011	31.2551	31.2554	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Final Weighing:

Date/Time:	8-20-91/11900	8-21-91/11530	_____	_____
Balance Check:	_____	_____	_____	_____
Weight Value:	35	35	_____	_____
Initial Check:	34.9995	34.9995	_____	_____
Final Check:	34.9995	34.9994	_____	_____
Sample/Filter No.	First Weighing	Second Weighing	Third Weighing	Average
1007	29.0230	29.0228	_____	29.0229
1009	31.7917	31.7917	_____	31.7917
1010	32.3484	32.3482	_____	32.3483
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

FILTER WEIGHINGS

Project No. 411140 Analyst: Cobb
 Filter Type and Size: Quartz 3"
 Weight Unit: g
 Filter Treatment: desiccate 24 hrs, weigh constant weight

Tare Weighing:

Date/Time:	<u>6-21-1715</u>	<u>6-22-10945</u>	<u>6-23-10930</u>	
Balance Check:				
Weight Value:	<u>40</u>	<u>40</u>	<u>40</u>	
Initial Check:	<u>39.9993</u>	<u>39.9993</u>	<u>39.9993</u>	
Final Check:	<u>39.9993</u>	<u>39.9993</u>	<u>39.9994</u>	
Filter No.	First Weighing	Second Weighing	Third Weighing	Average
<u>A8</u>	<u>42.8735</u>	<u>42.8731</u>		<u>42.8733</u>
<u>A9 ✓</u>	<u>43.1626</u>	<u>43.1624</u>		<u>43.1625</u>
<u>A10</u>	<u>44.7666</u>	<u>44.7664</u>		<u>44.7665</u>
<u>A11</u>	<u>46.2150</u>	<u>46.2144</u>	<u>46.2142</u>	<u>46.2143</u>
<u>A12 ✓</u>	<u>42.7194</u>	<u>42.7184</u>	<u>42.7184</u>	<u>42.7184</u>

Final Weighing:

Date/Time:	<u>8-20-9111900</u>	<u>1</u>	<u>1</u>	
Balance Check:				
Weight Value:	<u>35</u>			
Initial Check:	<u>34.9995</u>			
Final Check:	<u>34.9995</u>			
Sample/Filter No.	First Weighing	Second Weighing	Third Weighing	Average
<u>A8</u>				
<u>A10</u>				
<u>A11</u>				
<u>A9</u>	<u>43.1665</u>	<u>43.1660</u>		<u>43.1663</u>

Original
BEAKER WEIGHINGS

Project No. _____ Analyst: _____
Beaker Type and Size: _____
Weight Unit: _____
Beaker Treatment: _____

Tare Weighing:

Date/Time: 0230 / 8-16 5:30 / 8-16 1
Balance Check:
Weight Value: 25g 100g
Initial Check: 24.9998 99.9998
Final Check: 274.9997 99.9996
Beaker No. First Weighing Second Weighing Third Weighing Average
1053 67.5660 67.5661 67.5661
1054 67.6962 67.6966 67.6964
1055 67.6055 67.6059 67.6057
1056 67.6386 67.6389
1057 67.5585 67.5587
1058 see other sheet
1059 67.5176 67.5178

Final Weighing:

Date/Time: 8-20-91 / 1830 8-21-91 / 1500 1
Balance Check:
Weight Value: 75 75
Initial Check: 24.9990 24.9989
Final Check: 24.9989 24.9989
Sample/Beaker No. First Weighing Second Weighing Third Weighing Average Vol mls
1053 67.5796 67.5794 67.5795 145
1054 67.7007 67.7007 67.7007 100
1055 67.6062 67.6060 67.6061 100

APPENDIX E

PRETEST CALIBRATIONS

CONSOLE WORKSHEET

NAME Karl Baker K FACTOR .6405 PROJECT # _____
 DATE 8-9-91 TRAIN ID 2 PREVIOUS Y FACTOR 1.014
 ORIFICE # 7 PYROMETER # _____

RUN NUMBER

	1	2
DGM		
FINAL READING	<u>271.2</u>	<u>275.6</u>
INITIAL READING	<u>267.1</u>	<u>271.5</u>

INLET & OUTLET TEMPERATURES

INITIAL	<u>75/74</u>	<u>78/75</u>
FINAL	<u>78/75</u>	<u>81/76</u>

TIME Sec	<u>300</u>	<u>300</u>
ORIFICE RDG. ^H	<u>2.3</u>	<u>2.7</u>
BAR. PRESSURE	<u>29.13</u>	<u>29.13</u>
ROOM TEMP.	<u>73.9/73.8</u>	<u>73.8/73.7</u>
PUMP VACUUM Hg"	<u>15</u>	<u>15</u>

CONSOLE CALIBRATION

Project		Orifice number
Date	8-9-91	Orifice K factor
Operator	Baker	Previous Y factor
Console Number	2	

	°	Run 1	°	Run 2	°
	°		°		°
Final DGM Volume	°	271.200	°	275.600	°
Initial DGM Volume	°	267.100	°	271.500	°
Net DGM Volume (Vm)	°	4.100	°	4.100	°
	°		°		°

EE

In/Out DGM Temp.	°		°		°
Inlet Deg. F	°		°		°
initial	°	75.0	°	78.0	°
final	°	78.0	°	81.0	°
Outlet Deg. F	°		°		°
initial	°	74.0	°	75.0	°
final	°	75.0	°	76.0	°
Avg. DGM Temp Deg. F	°	75.5	°	77.5	°
Time, sec.	°	300.0	°	300.0	°
Orifice DH, in. H2O	°	2.30	°	2.30	°
Baro. Press., in. Hg	°	29.13	°	29.13	°
Room temp., Deg. F	°		°		°
initial	°	73.9	°	73.8	°
final	°	73.8	°	73.7	°
Avg. Room Temp.	°	73.9	°	73.8	°
Pump Vacuum, in. Hg	°	15	°	15	°
	°		°		°

EE

Vcr (std)	°	4.038	°	4.038	°
Vm (std)	°	3.957	°	3.942	°
Y Factor	°	1.020	°	1.024	°
Delta H@	°	1.981	°	1.973	°

Average Y	1.022
Average Delta H@	1.977

EE

+/- 2% criteria	°		°
Percent of Avg Y	°	.19	°
	°	PASS	°
	°		°
+/- 5% criteria	°		°
Percent of final Y	°	.81	°
	°	PASS	°

BRACKETING WORKSHEET

NAME Ka. 1 Baker K. FACTOR 1. .5683 2. .6564
PROJECT # _____ DATE 8-9-91 TRAIN I.D. 2
ORIFICE # 1. 9 2. 8

<u>DGM</u>	1	2
Final Reading	<u>284.90</u>	<u>280.7</u>
Initial reading	<u>281.3</u>	<u>276.5</u>
Difference	_____	_____

<u>INLET & OUTLET TEMP.</u>		
Initial	<u>82.77</u>	<u>81.76</u>
Final	<u>85.78</u>	<u>83.77</u>
Avg. Temp.	_____	_____
Time	<u>300</u>	<u>300</u>
Orifice rdg. ^H	<u>1.8</u>	<u>2.4</u>
Bar. Pressure	<u>29.13</u>	<u>29.13</u>
Room Temp.	<u>73.8/73.7</u>	<u>73.8/73.9</u>
Pump Vacuum	<u>15</u>	<u>15</u>

ORFICE BRACKETING

Project		Bracket Orifices:
Date	8-9-91	Orifice No. 1 9
Operator	Baker	Orifice NO.1 K factor .
Orifice Number	7	Orifice No. 2 8
Orifice Y factor	1.022	Orifice NO.2 K factor .

	°	Orifice #1	°	Orifice #2	°
	°		°		°
Final DGM Volume	°	284.900	°	280.700	°
Initial DGM Volume	°	281.300	°	276.500	°
Net DGM Volume (Vm)	°	3.600	°	4.200	°

EE

In/Out DGM Temp.	°		°		°
Inlet	°		°		°
initial	°	82.0	°	81.0	°
final	°	85.0	°	83.0	°
Outlet	°		°		°
initial	°	77.0	°	76.0	°
final	°	78.0	°	77.0	°
Avg. DGM Temp	°	80.5	°	79.3	°
Time, sec.	°	300.0	°	300.0	°
Orifice DH, in. H2O	°	1.80	°	2.40	°
Baro. Press., in. Hg	°	29.13	°	29.13	°
Room temp., Deg. F	°		°		°
initial	°	73.8	°	73.8	°
final	°	73.7	°	73.9	°
Avg. Room Temp.	°	73.8	°	73.9	°
Pump Vacuum, in. Hg	°	15	°	15	°

EE

	°		°	0	°
Vcr (std)	°	3.583	°	4.138	°
Vm (std)	°	3.438	°	4.026	°
Y Factor (brackets)	°	1.042	°	1.028	°

EE

+/- 2% criteria	°		°		°
Percent of Y	°	1.97	°	.55	°
	°	PASS	°	PASS	°

GRC 6/11/90

POSTTEST DRY GAS METER CALIBRATION DATA FORM (English Units)

OPERATOR Karl Baker DATE 8-9-91 METER BOX # 2 PLANT _____

PROJECT # _____ BAR. PRESSURE 29.13 ORIFICE # 7

PRETEST Y 1.014

ORIFICE MANOMETER (ΔH)	DRY GAS METER (Vd)	INLET TEMP. *F	OUTLET TEMP. *F	AVG. TEMP. *F	TIME MIN.	VACUUM SETTING in Hg	Yi
1. <u>2.3</u>	<u>4.1</u>	<u>77</u>	<u>75</u>	<u>75.5</u>	<u>5</u>	<u>15</u>	<u>1.020</u>
2. <u>2.3</u>	<u>4.1</u>	<u>80</u>	<u>76</u>	<u>77.5</u>	<u>5</u>	<u>15</u>	<u>1.024</u>

AVERAGE Y 1.022

ΔH = Pressure differential across orifice, H₂O

Vd = Gas volume passing through the dry gas meter

THERMOCOUPLE CALIBRATION SHEET

Date 8/20/91 Thermocouple Number U42
 Ambient Temp. 77.8 F Barometric Pressure 29.13 in. Hg
 Calibrator Blane wood Reference: mercury-in-glass ASTM
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F	Thermocouple potentiometer temperature, F	Temperature difference $\pm 2.2^\circ\text{F}$
1	Ambient	77.8	76.7	1.1°
2	Ice	34.2	32.9	1.3°

a Every 50°F for each reference point

b Type of calibration system used

c (ref temp, °F + 460) (test thermom temp, °F + 460)

ref temp, °F + 460

100 $\leq$ 1.5%.

THERMOCOUPLE CALIBRATION SHEET

Date 8/20/91 Thermocouple Number UH3
 Ambient Temp. 77.8 °F Barometric Pressure 29.13 in. Hg
 Calibrator Blake Wood Reference: mercury-in-glass Asm
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Temperature difference ± 2.2°F
1	Ambient	77.8	76.2	1.6
2	ICE	34.2	33.0	1.2

a Every 50°F for each reference point

b Type of calibration system used

c
$$\left[\frac{(\text{ref temp, } ^\circ\text{F} + 460) - (\text{test thermom temp, } ^\circ\text{F} + 460)}{\text{ref temp, } ^\circ\text{F} + 460} \right]$$

100 ≤ 1.5%.

THERMOCOUPLE CALIBRATION SHEET

Date 8-20-91 Thermocouple Number VH 4 in. Hg
 Ambient Temp. 80 F F Barometric Pressure 29.13
 Calibrator Ed Hoffman Reference: mercury-in-glass 18-89° Serial No 1946
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, ^F	Thermocouple potentiometer temperature, ^F	Temperature difference $\pm 2^{\circ}\text{F}$
<u>1</u>	<u>Ambient</u>	<u>80</u>	<u>79.4</u>	<u>0.6</u>
<u>2</u>	<u>Ice Bath</u>	<u>32</u>	<u>32.5</u>	<u>0.5</u>

a Every 50°F for each reference point

b Type of calibration system used

c $[(\text{ref temp, } ^{\circ}\text{F} + 460) - (\text{test thermom temp, } ^{\circ}\text{F} + 460)]$ 100 $\leq$ 1.5%.

ref temp, $^{\circ}\text{F} + 460$

THERMOCOUPLE CALIBRATION SHEET

Date 8-9-91 Thermocouple Number T1
 Ambient Temp. 74.0 °F Barometric Pressure 29.13 in. Hg
 Calibrator Kw Baker Reference: mercury-in-glass ASTM
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Temperature difference %
1	Ambient	74	72.7	
2	Ice	32.6	32.2	
3	Oven	120.4	120.8	

a Every 50°F for each reference point

b Type of calibration system used

c [(ref temp, °F + 460) - (test thermom temp, °F + 460)]

ref temp, °F + 460

100 ≤ 1.5%

THERMOCOUPLE CALIBRATION SHEET

Date 5-9-91 Thermocouple Number T 2
 Ambient Temp. 74° F Barometric Pressure 29.13 in. Hg
 Calibrator Karl Baker Reference: mercury-in-glass ASTM
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F	Thermocouple potentiometer temperature, F	Temperature difference %
1	Ambient	74	72.8	
2	Ice	32.6	32.4	
3	Oven	120.4	120.4	

a Every 50°F for each reference point

b Type of calibration system used

c $\left[\frac{(\text{ref temp, } ^\circ\text{F} + 460) - (\text{test thermom temp, } ^\circ\text{F} + 460)}{\text{ref temp, } ^\circ\text{F} + 460} \right]$

100 ≤ 1.5%.

THERMOCOUPLE CALIBRATION SHEET

Date 8-9-91 Thermocouple Number T-3
 Ambient Temp. 74° F Barometric Pressure 29.13 in. Hg
 Calibrator Karl Baker Reference: mercury-in-glass ASTM
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Temperature difference %
1	Ambient	74	72.8	
2	Ice	32.6	32.5	
3	Oven	120.4	120.8	

a Every 50°F for each reference point

b Type of calibration system used

c [(ref temp, °F + 460) - (test thermom temp, °F + 460)]

ref temp, °F + 460

100 ≤ 1.5%

PITOT ~~TH~~ 1
4-9-91
Hartman

Pitot tube assembly level? ✓ yes no

Pitot tube openings damaged? yes (explain below) ✓ no

$\alpha_1 = \underline{0}^\circ (<10^\circ)$, $\alpha_2 = \underline{1}^\circ (<10^\circ)$, $\beta_1 = \underline{4}^\circ (<5^\circ)$,
 $\beta_2 = \underline{3}^\circ (<5^\circ)$

$\gamma = \underline{4}^\circ$, $\theta = \underline{0.5}^\circ$, $A = \underline{0.451}$ cm (in.)

$z = A \sin \gamma = \underline{0.066}$ cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta = \underline{0.0043}$ cm (in.); <0.08 cm ($<1/32$ in.)

$P_A \underline{0.476}$ cm (in.) $P_b \underline{0.471}$ cm (in.)

$D_t = \underline{0.376}$ cm (in.)

Comments: _____

Calibration required? yes ✓ no

PITOT 2
8-9-91
Hartman

Pitot tube assembly level? ✓ yes no

Pitot tube openings damaged? yes (explain below) ✓ no

$\alpha_1 = \underline{1}^\circ (<10^\circ)$, $\alpha_2 = \underline{0.5}^\circ (<10^\circ)$, $\beta_1 = \underline{1}^\circ (<5^\circ)$,
 $\beta_2 = \underline{0.5}^\circ (<5^\circ)$

$\gamma = \underline{0.5}^\circ$, $\theta = \underline{0.5}^\circ$, $A = \underline{0.941}$ cm (in.)

$z = A \sin \gamma = \underline{0.0082}$ cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta = \underline{0.0082}$ cm (in.); <0.08 cm ($<1/32$ in.)

$P_A = \underline{.471}$ cm (in.) $P_B = \underline{.470}$ cm (in.)

$D_t = \underline{0.373}$ cm (in.)

Comments: _____

Calibration required? yes ✓ no

NOZZLE CALIBRATION

Date: 7-20-91 Calibrated by: Karl Baker
Nozzle Set: A

Nozzle Set: A

[illegible]

NOZZLE CALIBRATION

Date: 5-13-91 Calibrated by: Karl Baker
Nozzle Set: E

[illegible]

APPENDIX F

POSTTEST CALIBRATIONS

CONSOLE WORKSHEET

(check)²
 NAME Karl Baker K FACTOR .6564 PROJECT # _____
 DATE 2-30-91 TRAIN ID 2 PREVIOUS Y FACTOR 1.04.007
 ORIFICE # .875 PYROMETER # n/A .006
8

RUN NUMBER

DGM

FINAL READING

INITIAL READING

1

2

66.20

71.1

61.90

66.80

INLET & OUTLET TEMPERATURES

INITIAL

94 / 85

91 / 86

FINAL

96 / 87

96 / 89

TIME Sec

300

300

ORIFICE RDG. ^H

2.4

2.4

BAR. PRESSURE

29.84

29.84

ROOM TEMP.

84.6 / 84.2

84.8 / 85.2

PUMP VACUUM Hg"

19

19

CONSOLE CALIBRATION

Project	411052 ²⁵ <i>mc</i>	Orifice number	8
Date	7/30/91	Orifice K factor	.6564
Operator	Baker	Previous Y factor	1.006
Console Number	2		

	•	Run 1	•	Run 2	•
	•		•		•
Final DGM Volume	•	66.200	•	71.100	•
Initial DGM Volume	•	61.900	•	66.800	•
Net DGM Volume (Vm)	•	4.300	•	4.300	•
	•		•		•

EE

In/Out DGM Temp.	•		•		•
Inlet Deg. F	•		•		•
initial	•	94.0	•	91.0	•
final	•	96.0	•	96.0	•
Outlet Deg. F	•		•		•
initial	•	85.0	•	86.0	•
final	•	87.0	•	89.0	•
Avg. DGM Temp Deg. F	•	90.5	•	90.5	•
Time, sec.	•	300.0	•	300.0	•
Orifice DH, in. H2O	•	2.40	•	2.40	•
Baro. Press., in. Hg	•	29.84	•	29.84	•
Room temp., Deg. F	•		•		•
initial	•	84.6	•	84.8	•
final	•	84.7	•	85.2	•
Avg. Room Temp.	•	84.7	•	85.0	•
Pump Vacuum, in. Hg	•	19	•	19	•
	•		•		•

EE

Vcr (std)	•	4.196	•	4.195	•
Vm (std)	•	4.136	•	4.136	•
Y Factor	•	1.015		1.014	•
Delta H@	•	1.858		1.860	•

Average Y	1.014
Average Delta H@	1.859

EE

+/- 2% criteria	•		•
Percent of Avg Y	•	.02	•
	•	PASS	•
	•		•
+/- 5% criteria	•		•
Percent of final Y	•	.83	•
	•	PASS	•

BRACKETING WORKSHEET

NAME Karl Baker K. FACTOR 1. .6405 2. .8004
PROJECT # _____ DATE 7-20-91 TRAIN I.D. 2
ORIFICE # 9 7 13

<u>DGM</u>	<u>1</u>	<u>2</u>
Final Reading	<u>78.70</u>	<u>84.40</u>
Initial reading	<u>73.50</u>	<u>80.20</u>
Difference	_____	_____

<u>INLET & OUTLET TEMP.</u>		
Initial	<u>93/89</u>	<u>93/90</u>
Final	<u>96/90</u>	<u>96/91</u>
Avg. Temp.	_____	_____
Time	<u>300</u>	<u>300</u>
Orifice rdg. ^H	<u>3.6</u>	<u>2.3</u>
Bar. Pressure	<u>29.84</u>	<u>29.84</u>
Room Temp.	<u>85.4/86</u>	<u>86/86.4</u>
Pump Vacuum	<u>19</u>	<u>19</u>

ORFICE BRACKETING

Project	411125	Bracket Orfices:	
Date	7/30/91	Orifice No. 1	13
Operator	Baker	Orifice NO.1 K factor	.8004
Orifice Number	8	Orifice No. 2	7
Orifice Y factor	1.014	Orifice NO.2 K factor	.6405

	° Orifice #1 °	° Orifice #2 °
Final DGM Volume	° 78.700 °	° 84.400 °
Initial DGM Volume	° 73.500 °	° 80.200 °
Net DGM Volume (Vm)	° 5.200 °	° 4.200 °

EE

In/Out DGM Temp.	°	°	°
Inlet	°	°	°
initial	° 93.0 °	° 93.0 °	°
final	° 96.0 °	° 96.0 °	°
Outlet	°	°	°
initial	° 89.0 °	° 90.0 °	°
final	° 90.0 °	° 91.0 °	°
Avg. DGM Temp	° 92.0 °	° 92.5 °	°
Time, sec.	° 300.0 °	° 300.0 °	°
Orifice DH, in. H2O	° 3.60 °	° 2.30 °	°
Baro. Press., in. Hg	° 29.84 °	° 29.84 °	°
Room temp., Deg. F	°	°	°
initial	° 85.4 °	° 86.0 °	°
final	° 86.0 °	° 86.4 °	°
Avg. Room Temp.	° 85.7 °	° 86.2 °	°
Pump Vacuum, in. Hg	° 19 °	° 19 °	°

EE

Vcr (std)	° 5.112 °	° 4.089 °
Vm (std)	° 5.003 °	° 4.024 °
Y Factor (brackets)	° 1.022 °	° 1.016 °

EE

+/- 2% criteria	°	°	°
Percent of Y	° .78 °	° .21 °	°
	° PASS °	° PASS °	°

TERMOCOUPLE CALIBRATION SHEET

Date 6-22-91 Thermocouple Number Coosuleek #2

Ambient Temp. _____ F Barometric Pressure _____ in. Hg

Calibrator: Cobb Reference: mercury-in-glass ASTM

other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F (°C)	Thermocouple potentiometer temperature, F (°C)	Temperature difference %
1	ice	33.2	33.2	0.0%
2	Ambient	74.2	74.8	.1%

* Every 30°C (50°F) for each reference point

^b Type of calibration system used
$$c = \frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \quad 100 \leq 1.5\%$$

THERMOCOUPLE CALIBRATION SHEET

Date 6-22-91 Thermocouple Number: Boosveld #3

Ambient Temp. _____ F Barometric Pressure _____ in. Hg

Calibrator Cobbs Reference: mercury-in-glass ASTM

other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F (°C)	Thermocouple potentiometer temperature, F (°C)	Temperature difference %
1	Ice	33.2	33.1	0.02%
2	Ambient	74.2	74.8	0.1%

* Every 30°C (50°F) for each reference point

^b Type of calibration system used
$$^{\circ} \frac{(\text{ref temp, } ^{\circ}\text{C} + 273) - (\text{test thermom temp, } ^{\circ}\text{C} + 273)}{\text{ref temp, } ^{\circ}\text{C} + 273} \quad 100 \leq 1.5\%$$

THERMOCOUPLE CALIBRATION SHEET

Date 6-22-91 Thermocouple Number: Boosneck #4

Ambient Temp. _____ F Barometric Pressure ASTM in. Hg

Calibrator Cobb Reference: mercury-in-glass

other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F (°C)	Thermocouple potentiometer temperature, F (°C)	Temperature difference %
1	ice	32.6	32.5	0.02%
2	Ambient	74.0	74.8	0.15%

* Every 30°C (50°F) for each reference point

^b Type of calibration system used
$$\frac{(ref\ temp, ^\circ C + 273) - (test\ thermom\ temp, ^\circ C + 273)}{ref\ temp, ^\circ C + 273} \times 100 \leq 1.5\%$$

THERMOCOUPLE CALIBRATION SHEET

Date 2-21-91 Thermocouple Number 01
 Ambient Temp. 86.4 F Barometric Pressure 29.44 in. Hg
 Calibrator Karl Baker Reference: mercury-in-glass ASTM
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Temperature difference %
1) Ice →		32.2	32	
2) Ambient →		86.4	85.8	
3) Oven →		192.8	192.2	

a Every 50°F for each reference point

b Type of calibration system used

c [(ref temp, °F + 460) - (test thermom temp, °F + 460)]

ref temp, °F + 460

100 ≤ 1.5%.

THERMOCOUPLE CALIBRATION SHEET

Date 7-21-91 Thermocouple Number P2
 Ambient Temp. 86.4 F Barometric Pressure 29.44 in. Hg
 Calibrator Karl Baker Reference: mercury-in-glass Astm
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F	Thermocouple potentiometer temperature, F	Temperature difference %
1	ICE	32.2	32.2	
2	Ambient	86.4	86.2	
3	Oven	192.8	191.8	

a Every 50°F for each reference point

b Type of calibration system used

c
$$\frac{[(\text{ref temp, } ^\circ\text{F} + 460) - (\text{test thermom temp, } ^\circ\text{F} + 460)]}{\text{ref temp, } ^\circ\text{F} + 460}$$

100 ≤ 1.5%.

THERMOCOUPLE CALIBRATION SHEET

Date 7-21-91 Thermocouple Number 03
 Ambient Temp. 86.4 F Barometric Pressure 29.44 in. Hg
 Calibrator K. Baker Reference: mercury-in-glass ASTM
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, F	Thermocouple potentiometer temperature, F	Temperature difference %
1	ICE	32.2	32.2	0
2	Ambient	86.4	86.2	
3	Oven	192.8	192.6	

a Every 50°F for each reference point

b Type of calibration system used

c (ref temp, °F + 460) - (test thermom temp, °F + 460)

ref temp, °F + 460

100 ≤ 1.5%.

D-21-91
Pitot #1

Pitot tube assembly level? ☒ yes ☐ no

Pitot tube openings damaged? ☐ yes (explain below) ☒ no

$\alpha_1 = 1^\circ (<10^\circ)$, $\alpha_2 = 1^\circ (<10^\circ)$, $\beta_1 = 0^\circ (<5^\circ)$,
 $\beta_2 = 1^\circ (<5^\circ)$

$\gamma = 1^\circ$, $\theta = 0.5^\circ$, $A = .961$ cm (in.)

$z = A \sin \gamma = \frac{.00838 \cdot .0167}{.0162} \text{ cm (in.)}; <0.32 \text{ cm } (<1/8 \text{ in.}),$

$w = A \sin \theta = \frac{.0164}{.00838} \text{ cm (in.)}; <0.08 \text{ cm } (<1/32 \text{ in.})$

$P_A = .481$ cm (in.) $P_B = .480$ cm (in.)

$D_t = .381$ cm (in.)

Comments: _____

Calibration required? ☐ yes ☒ no

7-21-91
Pitot #2

Pitot tube assembly level? / yes no

Pitot tube openings damaged? yes (explain below) / no

$\alpha_1 = \underline{1}^\circ (<10^\circ)$, $\alpha_2 = \underline{1}^\circ (<10^\circ)$, $\beta_1 = \underline{1}^\circ (<5^\circ)$,
 $\beta_2 = \underline{0.5}^\circ (<5^\circ)$

$\gamma = \underline{1}^\circ$, $\theta = \underline{0.5}^\circ$, $A = \underline{.933}$ cm (in.)

$z = A \sin \gamma = \underline{.0162}$ cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta = \underline{.0081}$ cm (in.); <0.08 cm ($<1/32$ in.)

$P_A \underline{.467}$ cm (in.) $P_b \underline{.466}$ cm (in.)

$D_t = \underline{.323}$ cm (in.)

Comments: _____

Calibration required? yes / no

7-21-91
pitot #3

Pitot tube assembly level? ☒ yes ☐ no

Pitot tube openings damaged? ☐ yes (explain below) ☒ no

$\alpha_1 = 1^\circ (<10^\circ)$, $\alpha_2 = 1^\circ (<10^\circ)$, $\beta_1 = 1^\circ (<5^\circ)$,
 $\beta_2 = 1^\circ (<5^\circ)$

$\gamma = 1^\circ$, $\theta = 0.5^\circ$, $A = .945$ cm (in.)

$z = A \sin \gamma = .0165$ cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta = -.00883$ cm (in.); <0.08 cm ($<1/32$ in.)

$P_A = .422$ cm (in.) $P_B = .423$ cm (in.)

$D_t = .374$ cm (in.)

Comments: _____

Calibration required? ☐ yes ☒ no

EQUIPMENT USE LIST FOR SAMPLING TRAINS AND TRAVERSES

Project # 411117 Date 8/5 + 8/6-91 Operator Cobb

Barometer _____

M5

Console #	<u>2</u>	_____	_____
Pyrometer	<u>2</u>	_____	_____
Temperature Controller #	<u>2</u>	_____	_____
Probe #	<u>P1</u>	<u>P3</u>	<u>P2</u>
Nozzle #	<u>A8</u>	<u>E3</u>	<u>A8</u>
Pitot #	<u>E3 P1</u>	<u>P3</u>	<u>P2</u>
Stack Thermocouple #	<u>P1</u>	<u>P3</u>	<u>P2</u>
Sample Box #	<u>2</u>	<u>4</u>	<u>3</u>
Umbilical Hookup #	<u>2</u>	<u>4</u>	<u>3</u>
Umbilical #	_____	_____	_____
Umbilical #	_____	_____	_____

VOST

Console #	_____	_____	_____
Pyrometer	_____	_____	_____
Tenax Thermocouple #	_____	_____	_____
VOST Train Box #	_____	_____	_____
Temperature Controller #	_____	_____	_____
Probe Heater #	_____	_____	_____

Comment:: _____

APPENDIX G

PARTICIPANTS

PARTICIPANTS

George Cobb	General Manager
Karl Baker	Project Manager
Dan Rigdon	Consultant
Opacity	Craig Euritt Project Manager

APPENDIX H

PROCESS DATA

MASTERS-JACKSON PAVING CO.

P.O. BOX 1187
SPRINGFIELD, MISSOURI 65801
(417) 881-5581

Contractors for

- Asphalt Paving
- Road Resurfacing
- Site Preparation
- Road Widening

November 20, 1991

Mr. George Cobb
AirSource Technologies
11635 W. 83rd Terrace
Lenexa, Ks. 66215

RE: Astec Plant

Dear George:

This letter is to confirm our conversation today that during testing our plant was operating 450 tons per hour.

Also, copies are enclosed of the three job mixes that we ran during the days of testing.

If you have any further questions, please feel free to give me a call.

Sincerely,

MASTERS-JACKSON PAVING CO.

Donnie Mantle
Vice-President

DM/lm

Post-It™ brand fax transmittal memo 7671		# of pages > 4
To George Cobb	From Donnie	
Co.	Co. Masters Jackson	
Dept.	Phone #	
Fax #	Fax #	



Disk #5

ELF ASPHALT, INC. LABORATORY
ASPHALT CONCRETE

DATE August 7, 1989

DESIGN NO. EA-9039

PROJECT NO. City of Springfield, Missouri

CONTRACTOR: Master Jackson Paving
Springfield, MissouriPRODUCER: Master Jackson Paving
Springfield, Missouri

MATERIAL

SOURCE

% USED

1/2" Chips
ScreeningsConco Quarry at Willard, Missouri
Conco Quarry at Willard, Missouri65
35

Asphalt Cement (PAC-30)

Elf Asphalt, Inc. at Memphis, Tenn

Lab No.	1/2" chips	Sern's	Combined Aggregate	Job Formula	Req'd Spec's
Percent passing					
3/4"	100		100	100	100
1/2"	99		99	99	95-100
3/8"					
No. 4	45	100	64	64	60-90
No. 10	12	87	38	38	35-65
No. 40	7	50	22	22	10-30
No. 80					
No. 200	4.2	19.0	9.4	9	4-12
% Asphalt Cement (PAC-30)	(A/C 20)			5.0	
Mix temperature @ discharge from mixer, °F				325	±20

Tests on Asphalt Cement:

Test on Aggregates

Found	Required	Found	Required
Pen. @ 25°C	60-100	Plasticity Index	6 Max
Viscosity @ 60°C	2000-400	Sand Equivalent	40 Min
Viscosity @ 135°C	300 Min	L.A. Abrasion & Wear	40 Max
Residue from RIFO		Durability (BC)	40 Min
Viscosity @ 60°C	8000 Max	Fractured Faces	70 m/2
Ductility @ 25°C	50 Min	B150	2.674
Spec. Grv. @ 60°F	1.023	Marshall Weight	1100

TESTS ON COMPRESSED MIXTURE:

Percent Asphalt	Spec. Grav	Max. Theo	% Voids	% Voids	V.M.A.	VMA	Flow	Flow	(50 Blows)
Specimen	Spec. Grav		Voids	Req'd	(%)	Req'd	0.01 in	Req'd	Marshall
5.0	2.370	2.474	4.2	--	15.8	--	12	--	3100.7
5.5	2.396	2.456	2.4	--	15.3	--	14	--	2778.1
6.0	2.401	2.438	1.5	--	15.6	--	20	--	2461.9
6.5	2.422	2.420	1.0	--	15.3	--	23	--	2534.2

Retained Strength % Required 75 N/A Minimum


Recommended 5.0 % Asphalt Cement (PAC-30)

Compacted Mt. 109 lbs/sq.yd./1" thickness

Max. Theo. Spec. Grav. @ 5.0 % Asph. Cement is 2.474 (154.4 pcf)

MEETS SPECIFICATION REQUIREMENTS

August 7, 1989



[Handwritten signature]

MISSOURI HIGHWAY AND TRANSPORTATION DEPARTMENT - DIVISION OF MATERIALS AND RESEARCH
PLANT MIX BITUMINOUS SURFACE LEVELING

BP01-21M

PROJECT= C039-266(102M and Combinations ROUTE= 266 COUNTY= Greene DATE= 4/17/91

PRODUCT CODE / FACILITY CODE / PRODUCER-LOCATION IDENT. | SP. GR. | XABS. | FORMATION / LEDGES / X CHERT

100207SLLS / 3009800218 / Conco #2, Willard, MO 91- 1714 2.644 1.5 Burl. / 2E-1E & 5W-2W

100204SLLS / 3009800218 / Conco #2, Willard, MO 91- 1715 2.665 Burl. / 2E-1E & 5W-2W

1002HSSLKSCY / 3062300117 / Bedrock Gravel, Wentworth, MO 91- 1495 2.689 Flint Sd.

1015ACVG..0100 / 3046400127 / Total Petroleum, Arkansas City, KS 91- 477 1.003 AC-10

MATERIAL 91 91 91 91 91 91

IDENT. 1714 1715 1495 1714 1715 1495

PERCENT 55.0 30.0 15.0

3/4" 100.0 100.0 100.0 55.0 30.0 15.0

1/2" 100.0 100.0 100.0 55.0 30.0 15.0

#4 49.0 100.0 97.0 27.0 30.0 14.6

#8 15.0 97.0 66.0 8.3 29.1 9.9

#30 9.0 64.0 27.0 5.0 19.2 4.1

#200 3.7 21.0 3.0 2.0 6.3 .5

LABORATORY || D= 2.453 X Voids= 5.01

CHARACTERISTICS || d= 2.330 U.M.A. = 16.71

AASHTO T-165 || STABIL= 518 X Filled= 70.0

MIX COMPOSITION

MIN. AGG. 95.0 %

ASPHALT CONTENT 5.0 %

MISSOURI HIGHWAY AND TRANSPORTATION DEPARTMENT - DIVISION OF MATERIALS AND RESEARCH
PLANT MIX BITUMINOUS BASE

8891-156

F.A.-32-1(18)

PROJECT= F.A.-32-1(19)

ROUTE= 32

COUNTY= Polk

DATE= 9/12/91

DEC 03 '91 10:39 MASTERS JACKSON PAVING CO

PAGE 4

PRODUCT CODE / FACILITY CODE / PRODUCER-LOCATION			IDENT.	SP.GR.	XABS.	FORMATION / LEDGES / % CHERT	
1004CABBL5 / 3009B00218 / Conce Qys., Willard, MO			90-	2775	2.658	1.5	Burl. LS / 2-3

CALIBRATION NUMBER	= 00112	MASTER GAUGE BACKGROUND COUNT =	2238	CURVE COEFFICIENTS	- A1	= 4.511472
MASTER GAUGE SERIAL NO.	= 770	SAMPLE WEIGHT	= 7200		- A2	= 3.157167

PROPOSED TEST PLAN

Submitted to: Missouri Air Pollution
Control Program (APCP)
Date submitted: June 3, 1991

Attention: Doug Elley
Proposed Test Date: June 18, 1991

1. Facility Information

Name: Masters-Jackson Paving Company ^{SPRING field} (~~Joplin~~, Missouri, Facility)
Address: 4166 West Kearney, Springfield, MO 65801
Name and title of contact: Robert Wallis, Dir. of Asphalt Plant Operations
Telephone number of contact: (417)881-5581

2. Air Pollution Source Information

Type of source: Asphalt Plant
Permit number of source to be tested: 0391-007
Address of source: 2 miles Southeast of Willard, MO @ Conco Quarry ← *For quarry*
Take 160 about 4 mi. N of Springfield & cross over RR bridge & look for
Directions to source (or map attached): (See attached map.)

Initial start-up date: May 1, 1991

3. Testing Firm Information

Name of firm: AirSource Technologies
Address: 11635 W. 83rd Terrace
Lenexa, KS 66215

Name and title of contact: Craig A. Euritt, Project Coordinator
Telephone number of contact: (913)492-1613 FAX: (913)492-1012
Number of employees of firm: 6
Number of employees actually engaged in air pollution source testing: 5
Organizational chart with names & titles of personnel: (please attach)

Location and description of laboratory facilities: _____

_____ Anatech Laboratories, Ludington, Michigan _____

_____ Full line analytical. _____

Subcontractor(s) utilized by firm for source testing activities: None

Number of air pollution sources previously tested by firm: Not available.

Sources tested by firm in Missouri in past 3 years (source, test, date):

_____ Not available. _____

4. Performance Test Information


Pollutants to be sampled:

	Pollutant	Number of Sampling Points	Total Time Per Test Run	Number of Test Runs	Test Method to be Used
1	Particulate	24	1 hr.	3	1-5
2	Opacity	According	to state	DNR	9
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					

Cross sectional drawing of stack or duct showing dimensions, sampling port locations, and sampling points:


Distance from wall

1"
2.68
4.72
7.08
10.0
14.24
25.76
30.0
32.92
35.28
37.32
39.16



Nipple distance = 2"
Stack diameter = 40"

Drawing of sampling location showing stack or duct dimensions, air pollution control equipment, fans, and location(s) of disturbances which affect sampling location determination:



5. General

A. Sampling Equipment Information:

The manufacturer and model of the sampling equipment to be used by the tester for the performance tests, along with a description of any equipment which may differ from that required by the specified method(s).

Nutech Model 2010 Stack Sampler

B. Test Procedures:

A description of any test procedures to be used in the conduct of the performance tests which may differ from the specified method(s).

None, unless specified by DNR.

C. Analytical Procedures:

A description of any analytical procedures which differ from the specified method(s).

None

D. Data Sheets:

A sample of all field data sheets which do not provide the data shown on the example sheets in 40 CFR 60 for the specified method(s).

E. Air Pollution Control Equipment:

Types and manufacturers of all control equipment;

Baghouse (See Page 5)

Design or guarantee efficiency; _____

Design gas volume at full load (acfm); _____

Design pressure drop; _____

Maintenance schedule and method of recordkeeping; _____

6. Source Operation

A description of the source operation including as a minimum the following:

For Asphalt Concrete Plants

- a. Type of plant (continuous, batch, portable, permanent)
Specify if drum mix plant and give name of manufacturer and model;
Double Barrel Aztec
- b. Manufacturer and model of dryer and other major components;
Aztec
- c. Rated capacity of unit, tons/hr (specify aggregate moisture content);
450 5% Moisture
- d. Normal production rate, tons/hr;
330 tons per hour
- e. Number of burners; 1 Hawk Star Jet
- f. Type(s) of fuel (Indicate percentages of each when more than one type is burned); Natural Gas (Back-up #2 diesel fuel)
- g. Normal fuel consumption rate; 140,000 cubic ft. per hr. (800 gal. per hr. diesel)
- h. Pugmill batch size, lb; None
- i. Description of scavenger system; Aztec Cyclone/Aztec Baghouse
- j. Aggregate source; Conco Quarries
- k. Size distribution of feed for mixes with maximum percentage of fines (material passing number 200 sieve); D-Mix 10% - 200
- l. Normal operating schedule; March 1 - to Dec. 31
- m. Normal maintenance schedule for plant, along with a description of the operating difficulties encountered thus far; and Jan. 1 - Feb. 28
No difficulties.
- n. Process flow diagram showing flow of feed, asphalt, product, stack gases, fly ash, and air pollution control device liquid, where applicable.

ORGANIZATION CHART

AIRSOURCE TECHNOLOGIES

George R. Cobb	General Manager
Craig A. Euritt	Project Coordinator
Ted Hartman	Project Manager
D. Bart Gossett	Project Manager
Karl Baker	Project Manager
Rosalie Kalb	Office Manager