

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

JOHN ASHCROFT
Governor



G. TRACY MEHAN III
Director

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MEMORANDUM

Division of Energy

To: County File

DATE:

TO: County file: GREEN
Facility: MASTER-JACKSON PAVING (Springfield)
Test Location: Buffalo, MO (Dallas Co.)

FROM: Doug Zeller

SUBJECT: COMPLIANCE TEST RESULTS

Test Date: 7-21-94

Testing firm: AEROMET

Test team leader: Tom Schepers

Source tested: Astec portable asphalt plant; Permit #0594-036

Pollutants tested for: PM
Opacity

	% Iso	ft ³ samp.	lb/hr	ppm	gr/dscf	gr/dscf corr.	Allowed	Opac%
Run #1	96	59			.0036			0
Run #2	97	60			.0022			0
Run #3	96	59			.0027			0
Averages					.003		.04	0%

Rated production/operation capacity: 258 ton/hr

Production/operation rate during test: 255 ton/hr

Fuel used: #2 Fuel Oil Rate: _____ Analysis: _____

Combustion Efficiency = CE = $\frac{CO_2}{CO_2 + CO} \times 100 = \frac{\quad}{\quad} \times 100 = \quad$

Control device: Baghouse

Secondary chamber volume (measured): _____

Retention time: Run #1 _____ Run #2 _____ Run #3 _____
Av. = _____ seconds

Pressure drop(s): 4.0" H₂O

Scrubber supply line water psi: _____



RECEIVED

'94 SEP 13 AM 10 47

AIR POLLUTION
CONTROL PGM

**PARTICULATE AND VISIBLE
EMISSION TESTS FOR
MASTERS-JACKSON PAVING COMPANY**

**ASTEC DOUBLE BARREL DRUM MIX
ASPHALT PLANT
BUFFALO, MISSOURI**

JULY 1994


AEROMET ENGINEERING, INC.
1325 Aerotec Drive, Jefferson City, MO 65109
Testing • Monitoring • Consulting
(314) 636-6303

TEST CERTIFICATION

I certify that the enclosed test results are true, accurate, and authentic. I was personally responsible for all phases of the testing to determine the particulate and visible emissions from the Astec Double Barrel Drum Mix Asphalt Plant at the Ash Grove Aggregates facility, Buffalo, Mo., location.

The sampling equipment and procedures conformed to USEPA Method 1,2,3,5, and 9 for particulate and visible emissions from stationary sources. The results of this testing are the basis for this report.

AEROMET ENGINEERING, INC.



Tom Scheppers, P.E.
President

TABLE OF CONTENTS

	<u>Page</u>
Test Certification	i
Table of Contents	ii
I. Introduction	1
II. Summary of Results	1
III. Description of the Process	3
IV. Description of the Source	4
V. Plant Operating Conditions	4
VI. Test Conditions	5
VII. Test Equipment and Methods	5

TABLES:

Table I - Summary of Emission Tests	2
Table II - Summary of Asphalt Plant Daily Operations Reports	6

APPENDICES:

Appendix A - Particulate Test Analysis	A-1
Appendix B - Particulate Field Data Sheets	B-1
Appendix C - Analytical Laboratory Reports - Particulate	C-1
Appendix D - Test Equipment Calibrations - Particulate	D-1
Appendix E - Test Equipment Description - Particulate	E-1
Appendix F - USEPA Reference Method 5	F-1
Appendix G - Visible Field Data Sheets	G-1
Appendix H - Visible Emissions Certification	H-1
Appendix I - USEPA Reference Method 9	I-1
Appendix J - 40 CFR Part 60 Subpart I - (Standards of Performance for Hot Mix Asphalt Facilities)	J-1
Appendix K - Asphalt Production Records, (July 21, 1994)	K-1
Appendix L - Sample Calculations	L-1
Appendix M - Construction Permit	M-1

I. INTRODUCTION

AeroMet Engineering, Inc., has been retained by Masters-Jackson Paving Company, to determine the particulate and visible emissions from a new portable Astec asphaltic concrete production plant installed at the Ash Grove Aggregates site, Buffalo, Missouri. Performance testing is required under the condition of a construction permit (# 0594-036) which was issued to Masters-Jackson Paving Company by the Missouri Department of Natural Resources. The asphalt plant is also subject to the Code of Federal Regulation (CFR) Title 40 Part 60 New Source Performance Standards (NSPS) Subpart I - Standards of Performance for Hot Mix Asphalt Facilities. USEPA Methods 5 and 9 were used for the testing with no deviations from the standard procedures. The asphalt plant is permitted to produce an emission rate of no greater than 0.04 grains/dry standard cubic foot, and less than 20 percent visible emissions.

Source testing took place on July 21, 1994. Pre-test planning was accomplished by phone conversations with the following individuals: Doug Elley of Missouri Department of Natural Resources; Dave Foreman, Permit Coordinator for Masters-Jackson; and Tom Scheppers, P.E., of AeroMet Engineering, Inc.

The project engineer and test team crew chief during the test for AeroMet Engineering was Tom Scheppers, P.E. Two other members of the test team were Mr. Darryl Meister and Mr. Jeff Broker. Mr. Broker is an EPA certified visible emissions reader and performed the Method 9 Visible Emissions Readings. Mr. Doug Elley observed the tests representing the Air Pollution Control Program, Missouri Department of Natural Resources. All aspects of the test program were coordinated with Dave Foreman, Permit Coordinator. The plant operating data was collected by the operator at 15 minute intervals. The data is presented in Appendix K.

Weather did play a factor during the testing program, causing a three hour delay in setting up the equipment, sampling for emissions and affecting the production rates of the plant. After the rain had subsided, the sky cleared up by the start of the second run. A storm front had moved into the area in the afternoon of the 20th and had rained most of the night. Asphalt production was limited due to the high moisture content of the aggregate. The temperatures were around the upper 80's to 90's.

II. SUMMARY OF RESULTS

The results are summarized in Table I. Actual emissions results are listed for particulate and visible emissions. The results of all three runs demonstrate compliance with the allowable limit of 0.04 grains per dry standard cubic foot (gr/dscf) and 20% opacity. The asphalt plant was operated at approximately 255 tons/hr of both aggregate and asphalt. A detailed description of the process is

TABLE I

**Masters-Jackson Paving Company
Summary of Particulate and Visible Emission Test
Portable Astec Asphaltic Concrete Production Plant**

	Run 1 07/21/94	Run 2 07/21/94	Run 3 07/21/94	Ave.
<u>Process Conditions</u>				
Production Rate (ton/hr)	253	256	255	255
<u>Stack Conditions</u>				
Stack Gas Temperature (°F)	266	265	267	266
Actual Gas Flow (ACFM)	43,007	42,822	42,411	42,747
Std. Gas Flow (DSCFM)	20,488	20,288	19,808	20,174
Isokinetics (%)	96	97	96	
<u>Emissions, Actual</u>				
Visible (percent)	0	0	0	0
Particulate (lb/hr)	0.63	0.39	0.46	0.49
Particulate (gr/DSCF)	0.0036	0.0022	0.0027	0.0029

found in the next section of this report. A summary of the production rates can be found in Table II within that same section.

The isokinetic sampling rate is also shown in Table I. This rate compares the stack gas velocity to the nozzle velocity of the sampling probe. A rate of 100% represents a stack gas velocity equal to the nozzle velocity. The acceptable range is 90% to 110%. EPA has determined that sampling outside this range may cause a bias in the results based on the particle size and aerodynamic properties.

The filters from all three runs were very clean and white in appearance, although appearance does not necessarily indicate weight. All three sets of samples appeared similar in light color and low density. The appearance also coincides with other samples taken from similar asphalt plants showing good combustion.

During the one-day testing period, no abnormalities were discovered to contribute to any errors in the results of the tests.

The particulate emission results should be representative of the actual concentrations within the normal accuracies of Method 5. Although no upper limits of emissions have been established for the test method, an upper limit has not been exceeded based on acceptance of the test method on significantly higher grain loadings. The estimated accuracy of Method 5 is approximately +/- 20% based on results of collaborative tests.

III. DESCRIPTION OF THE PROCESS

Masters-Jackson purchased and moved a new asphalt plant to the Ash Grove Aggregate Quarry located near Buffalo, Mo. The asphalt plant consists of a new Astec Drum Mixer. The asphalt plant is a portable plant. The Drum Mix Asphalt Plant consists of a cold feed system (five bin hopper), conveyors, a dryer drum with an integrated dryer/mixer, asphalt storage, fuel storage, and a final product storage silo.

A process description is as follows: Virgin aggregate is transported from storage piles to five independent bins by front end loader. The bins of specific sized aggregate are fed independently and continuously onto a feed belt. The feed belt supplies the correctly proportioned aggregate to the dryer drum. Feed rates are determined by automated controllers in order to blend a proper mix meeting any required specifications.

The dryer/mixer is called a "Double Barrel" drum mixer. The interior of the rotating drum, referred as the drying zone, receives the virgin aggregate at the upper end and travels countercurrent to the combustion gases. The aggregate is heated at high temperatures with combustion fuel in the rotary drum by direct contact with the combustion gases, primarily to dry and heat the aggregate. The dried material leaves the interior of the drum, at the lower end of the rotating drum, to enter a mixing zone between the exterior wall of the drum and a stationary outer shell. In the mixing zone,

asphalt cement is added. The asphalt cement and aggregate is mixed thoroughly by paddles attached to the outer wall of the rotating drum. This design achieves excellent mixing and long residence time providing direct contact of the wet virgin materials with the hot combustion gases, mixing of asphalt cement away from the combustion gases, combustion of fume generated by mixing, and lower exhaust temperatures.

From the dryer/mixer, the mixed asphalt is transferred to a storage silo. Asphalt can be stored and dispensed to trucks without interruption of the production process.

Combustion products, moisture, and particulate fines from the process are pulled from the elevator, through and including the dryer drum. Asphalt fumes will undergo combustion in the first drum. All gases and fines from the operation will travel to a baghouse under negative pressure from an induced draft fan located at the outlet of the baghouse. The fan forces the air up a 22 foot rectangular stack to discharge to the atmosphere. Test ports are installed in the upper portion of the stack.

The entire facility uses the latest state-of-the-art technology available in controlling all process feeds, temperatures, blending, weighing, data recording, etc. The facility is automated to the extent that production runs are manufactured consistently and to specification.

IV. DESCRIPTION OF THE SOURCE

The asphalt plant exhaust gases are controlled by a baghouse prior to exiting through a rectangular stack. The gases discharge to atmosphere through a 22 foot 1 3/4 inch stack. Stack dimensions inside the wall are 40 1/4 Width by 27 1/8 inches, as measured at the test ports. The effective diameter is 32.4 inches.

The test ports (six equally spaced along one wall) are located 24.0 inches (0.74 diameter) from the stack exit, and 241.8 inches (7.4 diameters) from the last disturbance (Louvered damper). The damper is adjustable automatically in order to maintain proper air flow under any condition.

V. PLANT OPERATING CONDITIONS

The asphalt production process was operated in a normal operating manner. The average production rate during the test was approximately 255 tons/hour of finished asphalt product. Raw materials were consistent with normal materials used at this facility. The aggregate was obtained from the quarry and stored in uncovered piles. Moisture content of the aggregates was typical. Fuel used during the entire test duration was #2 fuel oil.

The plant operation data for the period July 21, 1994, is presented in Appendix K. This data has been recorded approximately every 15 minutes during each run. The data includes time, process

input weight for both aggregate and total asphalt, and temperatures. The pressure drop across the baghouse averaged approximately 4.0 inches of water. This graph is also presented in Appendix K. A summary of the production rates and baghouse pressure drops are presented in Table II. No asphalt mix was recycled during the tests.

VL TEST CONDITIONS

The Method 5 test samples were drawn from four points on each of six traverses of the stack. The traverse point locations were specified by USEPA Method 1. Samples were collected isokinetically for a total of one hour for each of three runs (2.5 minutes/point).

No problems of either the asphalt plant operations or the sampling were encountered during the tests. The asphalt plant was charged with typical aggregate mix, asphalt and fuel in a steady state manner.

A cyclonic flow test and preliminary velocity traverse was performed prior to the first Method 5 test. Stack flow conditions were acceptable for testing. Some sampling points were found to have flow angles as high as 35°. The average angle of rotation of the stack gases for the 24 points in the vertical plane was less than 20°. (Averages up to 20° are acceptable according to the USEPA procedures.)

VII. TEST EQUIPMENT AND METHODS

The test procedures and equipment used to determine the particulate and visible concentrations in the stack gases of the asphalt plant are described in Appendix E of this report. In brief, a Research Appliance Corporation stack sampling train was used to determine the particulate emissions according to USEPA Reference Method 5, and a certified visual emissions observer was used to determine the visible emissions according to USEPA Reference Method 9.

TABLE II

Summary of
Asphalt Plant Daily Operations Reports
Masters-Jackson Paving Company

Date	Run Number	Asphalt (TPH)	Baghouse Diff. Press. ("H₂O)
07/21/94	1	253	4.1
07/21/94	2	256	4.0
07/21/94	3	255	4.0
Averages During Tests		255	4.0

APPENDIX - A
PARTICULATE TEST ANALYSIS

Particulate Test Analysis

MASTERS & JACKSON
MAIN STACK
ASTEC ASPHALT PLANT

Run Number		1	2	3
Data Set		1	2	3
Date		07-21-94	07-21-94	07-21-94
Location		STACK	STACK	STACK
Start Time		10:54	13:11	15:17
End Time		12:02	14:19	16:25
Barometric Pressure	In. Hg	28.90	28.73	28.60
Static Pressure	In H2O	1.00	1.00	1.00
Volume of Condensate	ML	545.1	550.6	543.6
Volume Sampled	DCF	58.954	59.967	59.197
Pitot Tube Coefficient		0.84	0.84	0.84
Meter Correction Factor		1.00	1.00	1.00
Square Root of Delta P		1.334	1.325	1.307
Orifice Pressure	In H2O	3.33	3.33	3.26
Meter Temperature	Deg. F	103.4	110.7	115.6
Flue Temperature	Deg. F	266	265	267
Percent CO2	%	5.7	5.7	5.7
Percent O2	%	13.6	13.6	13.6
Diameter of Nozzle	In.	0.252	0.252	0.252
Area of Flue	Sq Ft	7.58	7.58	7.58
Sample Time	Min	60	60	60
Weight Gain	Grams	0.0125	0.0078	0.0092
Absolute Flue Pressure	In. Hg	28.97	28.80	28.67
Corrected Sample Volume	DSCF	53.72	53.62	52.24
Moisture in Flue Gas	%	32.3	32.6	32.9
Molecular Weight	Lb/LbMole	25.75	25.72	25.69
Velocity of Flue Gas	Fps	94.54	94.13	93.23
Volume of Flue Gas	ACFM	43,007	42,822	42,411
Volume of Flue Gas	DSCFM	20,488	20,228	19,808
Dust Concentration	Lb/DSCF	5.13E-07	3.21E-07	3.88E-07
Dust Concentration	Lbs/Hour	0.63	0.39	0.46
Dust Concentration	Grs/ACF	0.00171	0.00106	0.00127
Dust Concentration	Grs/DSCF	0.00359	0.00225	0.00272
Isokinetic Rate	%	95.7	96.8	96.3
Averages:				
Stack Temperature	DEGR F :	266		
Flue Gas Volume	ACFM :	42747	DSCFM :	20174
Dust Concentration	Lb/DSCF:	4.07E-07	Lb/Hour:	0.494
	Grs/ACF:	0.00135	Grs/DSCF :	0.00285

APPENDIX - B

PARTICULATE FIELD DATA SHEETS

Particulate Field Data Sheet

Client MASTERS - JACKSON						Date 7/21/94		Page 1 Of 1																																																																																																																																																																																																																																																																																																																																																																					
Project No. 476			Operator TOM SCHEPPERS			Orsat Analysis																																																																																																																																																																																																																																																																																																																																																																							
Sampling Location MAIN STACK					Run No. 1		CO ₂ + O ₂ O ₂ CO																																																																																																																																																																																																																																																																																																																																																																						
Filter No. 8		Acetone No. MG		Condensate 545.1		5.7		19.3 13.6 0																																																																																																																																																																																																																																																																																																																																																																					
Barometric Pressure 28.90			Static Pressure + 1.0		Probe Number P3		5.7		19.3 13.6 0																																																																																																																																																																																																																																																																																																																																																																				
Nozzle Diameter .252		Nozzle Number B250		Pitot Coefficient .84		Pitot Number P3		5.7		19.3 13.6 0																																																																																																																																																																																																																																																																																																																																																																			
Meter Corr. Factor .996			Meter-Orifice 1.83			176		5.7		19.3 13.6 0																																																																																																																																																																																																																																																																																																																																																																			
Sample Pl. Time 2.5 min / 60 min			Assumed % Moisture 30 %			Leak Test 0.003 @ 15" H₂O		Before 0.002 @ 6" H₂O																																																																																																																																																																																																																																																																																																																																																																					
<table border="1"> <thead> <tr> <th rowspan="2">10:54 Sample Point</th> <th rowspan="2">ΔP</th> <th rowspan="2">√ΔP</th> <th rowspan="2">ΔH</th> <th colspan="6">Temperature °F</th> <th rowspan="2">Vac. Pr (in. HG)</th> <th rowspan="2">Dry Gas Meter Reading in Cu. Ft.</th> </tr> <tr> <th>Stack</th> <th>Probe</th> <th>Imp. Out</th> <th>Oven</th> <th>Meter In</th> <th>Meter Out</th> </tr> </thead> <tbody> <tr><td>A 1</td><td>1.8</td><td></td><td>3.25</td><td>257</td><td>258</td><td>67</td><td>262</td><td>80</td><td>80</td><td>2</td><td>582.250</td></tr> <tr><td>2</td><td>2.1</td><td></td><td>3.78</td><td>262</td><td>259</td><td>67</td><td>266</td><td>86</td><td>80</td><td>3</td><td>584.790</td></tr> <tr><td>3</td><td>2.1</td><td></td><td>3.81</td><td>263</td><td>258</td><td>65</td><td>260</td><td>94</td><td>81</td><td>4</td><td>587.521</td></tr> <tr><td>4</td><td>1.7</td><td></td><td>3.09</td><td>266</td><td>253</td><td>64</td><td>261</td><td>100</td><td>82</td><td>3</td><td>589.888</td></tr> <tr><td>B 1</td><td>1.5</td><td></td><td>2.75</td><td>263</td><td>250</td><td>66</td><td>248</td><td>103</td><td>83</td><td>2</td><td>592.071</td></tr> <tr><td>2</td><td>1.7</td><td></td><td>3.13</td><td>262</td><td>253</td><td>66</td><td>248</td><td>106</td><td>84</td><td>3</td><td>594.425</td></tr> <tr><td>3</td><td>2.0</td><td></td><td>3.69</td><td>264</td><td>251</td><td>67</td><td>264</td><td>110</td><td>86</td><td>3</td><td>597.026</td></tr> <tr><td>4</td><td>1.6</td><td></td><td>2.96</td><td>265</td><td>249</td><td>66</td><td>261</td><td>114</td><td>87</td><td>3</td><td>599.333</td></tr> <tr><td>C 1</td><td>1.5</td><td></td><td>2.79</td><td>264</td><td>235</td><td>66</td><td>262</td><td>115</td><td>88</td><td>2</td><td>601.560</td></tr> <tr><td>2</td><td>1.5</td><td></td><td>2.80</td><td>263</td><td>236</td><td>61</td><td>261</td><td>115</td><td>90</td><td>3</td><td>603.811</td></tr> <tr><td>3</td><td>1.9</td><td></td><td>3.54</td><td>266</td><td>238</td><td>61</td><td>260</td><td>117</td><td>92</td><td>3</td><td>606.331</td></tr> <tr><td>4</td><td>1.6</td><td></td><td>2.99</td><td>266</td><td>239</td><td>57</td><td>251</td><td>120</td><td>93</td><td>3</td><td>608.610</td></tr> <tr><td>D 1</td><td>1.3</td><td></td><td>2.43</td><td>266</td><td>237</td><td>59</td><td>266</td><td>119</td><td>94</td><td>2</td><td>610.727</td></tr> <tr><td>2</td><td>1.7</td><td></td><td>3.19</td><td>265</td><td>242</td><td>58</td><td>251</td><td>119</td><td>96</td><td>3</td><td>612.100</td></tr> <tr><td>3</td><td>2.0</td><td></td><td>3.75</td><td>266</td><td>246</td><td>58</td><td>237</td><td>121</td><td>96</td><td>3</td><td>615.753</td></tr> <tr><td>4</td><td>1.8</td><td></td><td>3.39</td><td>267</td><td>246</td><td>58</td><td>243</td><td>124</td><td>98</td><td>3</td><td>618.282</td></tr> <tr><td>E 1</td><td>1.6</td><td></td><td>3.01</td><td>267</td><td>247</td><td>58</td><td>264</td><td>123</td><td>98</td><td>3</td><td>620.650</td></tr> <tr><td>2</td><td>1.5</td><td></td><td>2.82</td><td>269</td><td>247</td><td>56</td><td>262</td><td>123</td><td>100</td><td>3</td><td>622.883</td></tr> <tr><td>3</td><td>2.1</td><td></td><td>3.94</td><td>270</td><td>240</td><td>57</td><td>258</td><td>123</td><td>100</td><td>4</td><td>625.489</td></tr> <tr><td>4</td><td>2.1</td><td></td><td>3.95</td><td>271</td><td>243</td><td>57</td><td>260</td><td>125</td><td>102</td><td>4</td><td>628.254</td></tr> <tr><td>F 1</td><td>1.6</td><td></td><td>3.01</td><td>270</td><td>246</td><td>59</td><td>261</td><td>126</td><td>102</td><td>3</td><td>630.550</td></tr> <tr><td>2</td><td>1.6</td><td></td><td>3.02</td><td>269</td><td>250</td><td>58</td><td>258</td><td>124</td><td>103</td><td>3</td><td>632.921</td></tr> <tr><td>3</td><td>2.1</td><td></td><td>3.96</td><td>270</td><td>237</td><td>59</td><td>255</td><td>125</td><td>103</td><td>4</td><td>635.771</td></tr> <tr><td>4</td><td>2.6</td><td></td><td>4.90</td><td>273</td><td>242</td><td>58</td><td>261</td><td>128</td><td>104</td><td>5</td><td>638.718</td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>												10:54 Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.	Stack	Probe	Imp. Out	Oven	Meter In	Meter Out	A 1	1.8		3.25	257	258	67	262	80	80	2	582.250	2	2.1		3.78	262	259	67	266	86	80	3	584.790	3	2.1		3.81	263	258	65	260	94	81	4	587.521	4	1.7		3.09	266	253	64	261	100	82	3	589.888	B 1	1.5		2.75	263	250	66	248	103	83	2	592.071	2	1.7		3.13	262	253	66	248	106	84	3	594.425	3	2.0		3.69	264	251	67	264	110	86	3	597.026	4	1.6		2.96	265	249	66	261	114	87	3	599.333	C 1	1.5		2.79	264	235	66	262	115	88	2	601.560	2	1.5		2.80	263	236	61	261	115	90	3	603.811	3	1.9		3.54	266	238	61	260	117	92	3	606.331	4	1.6		2.99	266	239	57	251	120	93	3	608.610	D 1	1.3		2.43	266	237	59	266	119	94	2	610.727	2	1.7		3.19	265	242	58	251	119	96	3	612.100	3	2.0		3.75	266	246	58	237	121	96	3	615.753	4	1.8		3.39	267	246	58	243	124	98	3	618.282	E 1	1.6		3.01	267	247	58	264	123	98	3	620.650	2	1.5		2.82	269	247	56	262	123	100	3	622.883	3	2.1		3.94	270	240	57	258	123	100	4	625.489	4	2.1		3.95	271	243	57	260	125	102	4	628.254	F 1	1.6		3.01	270	246	59	261	126	102	3	630.550	2	1.6		3.02	269	250	58	258	124	103	3	632.921	3	2.1		3.96	270	237	59	255	125	103	4	635.771	4	2.6		4.90	273	242	58	261	128	104	5	638.718																																																
10:54 Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.																																																																																																																																																																																																																																																																																																																																																																		
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out																																																																																																																																																																																																																																																																																																																																																																				
A 1	1.8		3.25	257	258	67	262	80	80	2	582.250																																																																																																																																																																																																																																																																																																																																																																		
2	2.1		3.78	262	259	67	266	86	80	3	584.790																																																																																																																																																																																																																																																																																																																																																																		
3	2.1		3.81	263	258	65	260	94	81	4	587.521																																																																																																																																																																																																																																																																																																																																																																		
4	1.7		3.09	266	253	64	261	100	82	3	589.888																																																																																																																																																																																																																																																																																																																																																																		
B 1	1.5		2.75	263	250	66	248	103	83	2	592.071																																																																																																																																																																																																																																																																																																																																																																		
2	1.7		3.13	262	253	66	248	106	84	3	594.425																																																																																																																																																																																																																																																																																																																																																																		
3	2.0		3.69	264	251	67	264	110	86	3	597.026																																																																																																																																																																																																																																																																																																																																																																		
4	1.6		2.96	265	249	66	261	114	87	3	599.333																																																																																																																																																																																																																																																																																																																																																																		
C 1	1.5		2.79	264	235	66	262	115	88	2	601.560																																																																																																																																																																																																																																																																																																																																																																		
2	1.5		2.80	263	236	61	261	115	90	3	603.811																																																																																																																																																																																																																																																																																																																																																																		
3	1.9		3.54	266	238	61	260	117	92	3	606.331																																																																																																																																																																																																																																																																																																																																																																		
4	1.6		2.99	266	239	57	251	120	93	3	608.610																																																																																																																																																																																																																																																																																																																																																																		
D 1	1.3		2.43	266	237	59	266	119	94	2	610.727																																																																																																																																																																																																																																																																																																																																																																		
2	1.7		3.19	265	242	58	251	119	96	3	612.100																																																																																																																																																																																																																																																																																																																																																																		
3	2.0		3.75	266	246	58	237	121	96	3	615.753																																																																																																																																																																																																																																																																																																																																																																		
4	1.8		3.39	267	246	58	243	124	98	3	618.282																																																																																																																																																																																																																																																																																																																																																																		
E 1	1.6		3.01	267	247	58	264	123	98	3	620.650																																																																																																																																																																																																																																																																																																																																																																		
2	1.5		2.82	269	247	56	262	123	100	3	622.883																																																																																																																																																																																																																																																																																																																																																																		
3	2.1		3.94	270	240	57	258	123	100	4	625.489																																																																																																																																																																																																																																																																																																																																																																		
4	2.1		3.95	271	243	57	260	125	102	4	628.254																																																																																																																																																																																																																																																																																																																																																																		
F 1	1.6		3.01	270	246	59	261	126	102	3	630.550																																																																																																																																																																																																																																																																																																																																																																		
2	1.6		3.02	269	250	58	258	124	103	3	632.921																																																																																																																																																																																																																																																																																																																																																																		
3	2.1		3.96	270	237	59	255	125	103	4	635.771																																																																																																																																																																																																																																																																																																																																																																		
4	2.6		4.90	273	242	58	261	128	104	5	638.718																																																																																																																																																																																																																																																																																																																																																																		

Pitot Tube Leak Check: Before OK After OK
Integrated Bag Leak Check: Before OK After OK

Particulate Test Method 5 Impinger Volumes

Run 1 Date 7/21/94 Facility Masters

Impinger	Final	Initial	Reagent	Liquid Gain
1 MGS	<u>861.9</u> ml	<u>620.5</u> 100 ml	H ₂ O	<u>241.4</u>
M3 C4 2 GS	<u>849.6</u> ml <u>554.6</u>	<u>603.7</u> 100 ml <u>525.6</u>	H ₂ O	<u>245.9</u> <u>29.0</u>
M1 3 MGS	<u>534.8</u> ml	<u>524.70</u> ml	Empty	<u>10.1</u>
S4 4 MGS	<u>1051.1</u> g	<u>1032.4</u> g	Silica Gel	<u>18.7</u>

Total: 545.10

GS - Greenburg Smith

MGS - Modified Greenburg Smith

AEROMET ENGINEERING, INC.
Testing • Monitoring • Consulting
(314) 636-6393

Particulate Field Data Sheet

Client Masters - JACKSON						Date 7/21/94		Page 1 of 1				
Project No. 476				Operator Tom Schepers		Orsat Analysis						
Sampling Location MAIN STACK						Run No. 2		CO ₂ + O ₂ O ₂ CO				
Filter No. 09		Acetone No. M6		Condensate SSO.6		5.7		19.3 13.6 0				
Barometric Pressure 28.73				Static Pressure +1.0		Probe Number P3		5.7 19.3 13.6 0				
Nozzle Diameter .252		Nozzle Number B250		Pitot Coefficient 84		Pitot Number P3		5.7 19.3 13.6 0				
Meter Corr. Factor .996				Meter-Orifice 1.83		176		5.7 19.3 13.6 0				
Sample Pt. Time 2.5 min/pt 60 min				Assumed % Moisture 30		Leak Test Before 0.002 @ 17" H₂ After 0.003 @ 11" H₂						
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.	
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out			
												639.015
A1	1.7		3.15	256	237	63	265	93	94	4		641.440
2	2.2		4.09	257	238	52	263	98	95	5		644.200
3	2.0		3.74	259	238	51	258	108	95	5		649.915
4	1.5		2.82	260	252	56	256	114	96	4		649.225
B1	1.4		2.62	262	246	62	263	112	96	4		651.500
2	1.8		3.38	262	255	62	268	115	97	4		653.901
3	1.8		3.38	264	250	62	264	118	98	4		656.427
4	1.5		2.82	266	242	61	266	121	98	4		658.682
C1	1.3		2.45	265	250	63	265	119	100	4		660.871
2	1.6		3.01	266	254	62	267	120	100	4		663.281
3	1.9		3.56	270	256	60	264	122	101	4		665.626
4	1.5		2.82	269	252	60	255	124	102	4		668.083
D1	1.5		2.82	270	249	58	260	123	102	4		670.403
2	1.6		3.01	269	248	56	261	122	103	4		672.660
3	1.9		3.58	270	246	56	263	124	104	5		675.211
4	1.7		3.22	269	250	55	260	128	104	5		677.932
E1	1.6		3.03	268	244	58	261	126	104	4		680.159
2	1.5		2.84	269	246	55	263	126	105	4		682.500
3	2.0		3.80	267	242	56	248	127	106	5		685.321
4	2.1		3.99	267	245	56	253	128	106	6		687.955
F1	2.0		3.79	267	246	62	258	123	107	6		690.742
2	1.6		3.04	267	245	60	259	128	106	4		693.159
3	2.2		4.20	266	247	57	264	130	106	6		695.967
4	2.5		4.79	266	243	55	260	134	107	7		698.982

Pitot Tube Leak Check: Before OK After OK
Integrated Bag Leak Check: Before OK After OK

Particulate Test Method 5 Impinger Volumes

Run 2 Date 7/21/94 Facility Masters

Impinger	Final	Initial	Reagent	Liquid Gain
M4 1 MGS	<u>856.2</u> ml	<u>624.2</u> 100 ml	H ₂ O	<u>232.0</u>
M3 2 GS	<u>850.0</u> ml	<u>604.9</u> 100 ml	H ₂ O	<u>245.1</u>
C 3 MGS	<u>587.7</u> ml	<u>526.9</u> ml	Empty	60.8
M1 4 MGS	<u>530.2</u> ml	<u>526.0</u> ml	Empty	4.2
S1 4 MGS	<u>984.6</u> g	<u>976.1</u> g	Silica Gel	<u>8.5</u>

Total: 550.6

GS - Greenburg Smith

MGS - Modified Greenburg Smith

AEROMET ENGINEERING, INC.

Testing • Monitoring • Consulting
(314) 636-6393

Particulate Field Data Sheet

Client MASTERS - JACKSON						Date 7/21/94		Page 1 of 1			
Project No. 476			Operator TOM SCHEPPERS			Orsat Analysis					
Sampling Location MAIN STACK			Run No. 3			CO ₂	+ O ₂	O ₂	CO		
Filter No. 10	Acetone No. M6		Condensate 543.6			5.7	19.3	13.6	0		
Barometric Pressure 28.60			Static Pressure +1.0		Probe Number P3	5.7	19.3	13.6	0		
Nozzle Diameter .252	Nozzle Number B250		Pitot Coefficient .84		Pitot Number P3	5.7	19.3	13.6	0		
Meter Corr. Factor .996			Meter-Orifice .176			5.7	19.3	13.6	0		
Sample Pt. Time 2.5 min/pt 60 min			Assumed % Moisture 30 %			Leak Test Before 0.001 @ 16" Hg		After 0.000 @ 8" Hg			
Sample Point	ΔP	$\sqrt{\Delta P}$	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
15:17											699.275
A1	1.9		3.54	258	228	58	235	98	98	4	701.901
2	2.0		3.71	267	257	56	247	106	100	4	704.510
3	2.0		3.72	268	249	56	261	110	100	4	707.142
4	1.5		2.81	267	253	56	244	116	100	3	709.444
B1	1.5		2.81	268	258	59	255	117	100	3	711.700
2	1.8		3.39	267	255	58	261	120	102	4	714.180
3	1.9		3.59	267	258	57	248	124	102	5	716.421
4	1.4		2.66	266	260	57	235	126	104	3	718.956
C1	1.3		2.46	267	258	59	252	123	104	3	721.371
2	1.5		2.84	268	262	58	258	125	106	4	723.473
3	1.9		3.61	267	260	60	240	126	106	5	726.103
4	1.5		2.86	266	256	60	243	128	106	4	728.318
D1	1.3		2.47	267	269	60	248	128	107	4	730.490
2	1.4		2.67	266	244	59	252	126	108	4	732.708
3	1.9		3.61	268	246	58	257	128	108	5	735.233
4	1.7		3.25	267	242	60	264	130	109	5	737.747
E1	1.3		2.48	268	236	63	268	130	109	4	739.964
2	1.5		2.85	269	238	62	255	128	109	4	742.186
3	2.0		3.80	270	252	62	242	129	109	5	744.800
4	2.1		4.02	269	254	60	258	134	110	5	747.701
F1	1.8		3.45	270	252	61	264	137	111	5	750.351
2	1.5		2.88	269	256	61	243	137	112	4	752.553
3	2.1		4.04	268	253	62	248	138	112	6	755.321
4	2.5		4.83	267	256	63	255	140	113	7	758.472

Pitot Tube Leak Check: Before OK After OK
Integrated Bag Leak Check: Before OK After OK

Particulate Test Method 5 Impinger Volumes

Run 3 Date 7/21/94 Facility Mastors

Impinger	Final	Initial	Reagent	Liquid Gain
1 MGS	<u>866.3</u> ml	<u>629.0</u> <u>100</u> ml	H ₂ O	<u>237.3</u>
2 GS	<u>875.1</u> ml	<u>600.3</u> <u>100</u> ml	H ₂ O	<u>274.8</u>
	<u>539.3</u>	<u>526.6</u>		<u>12.7</u>
3 MGS	<u>529.7</u> ml	<u>525.3</u> <u>0</u> ml	Empty	<u>4.4</u>
	<u>998.2</u>	<u>983.8</u>		
4 MGS	<u> </u> g	<u>525.3</u> g	Silica Gel	<u>14.4</u>

Total: 543.6

GS - Greenburg Smith

MGS - Modified Greenburg Smith

AEROMET ENGINEERING, INC.
Testing • Monitoring • Consulting
(314) 636-6393

METHOD 1

CYCLONIC FLOW DETERMINATION

Source
Name MOSTERS

Date 7/21/94

Sampling
Location _____



SAMPLE POINT	DELTA P	ANGLE (degrees)
A 1	0	0-5
2	0	0
3	0	0
4	0	0
B 1	0	5
2	0	0
3	0	0
4	0	0
C 1	0	5
2	0	0
3	0	0
4	0	0
D 1	0	30
2	0	20
3	0	5
4	0	5
E 1	0	35
2	0	20
3	0	5
4	0	0
F 1	0	30
2	0	15
3	0	5
4	0	0

AEROMET ENGINEERING, INC.
Testing • Monitoring • Consulting
 (314) 636-6393

APPENDIX - C
ANALYTICAL LABORATORY REPORTS
(Particulate)

Client MASTERS & JACKSON Analytical Data Sheet Project No. 476 Date 7/29/94

Run No. 1
 Filter No. 08
 Acetone No. M6
 Amount liquid lost during transport 0
 Acetone blank volume, ml 250
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** 1.5×10^{-6}
 Acetone wash blank, mg (equation 5-5)** .0001

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	68.71	68.74	-.0003
2	95.1117	95.0988	+.0129
3			
Less acetone blank			.0001
Weight of particulate matter			0.0125

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final		
Initial		
Liquid collected		
Total Volume Collected		g* ml

Run No. 3
 Filter No. 10
 Acetone No. M6
 Amount liquid lost during transport 0
 Acetone blank volume, ml 250
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** 1.5×10^{-6}
 Acetone wash blank, mg (equation 5-5)** .0001

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	0.6925	06924	.0001
2	95.1316	95.1187	.0129
3			
Less acetone blank			.0001
Weight of particulate matter			0.0129

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final		
Initial		
Liquid collected		
Total Volume Collected		g* ml

Run No. 2
 Filter No. 09
 Acetone No. M6
 Amount liquid lost during transport 0
 Acetone blank volume, ml 250
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** 1.5×10^{-6}
 Acetone wash blank, mg (equation 5-5)** .0001

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	0.6857	0.6874	-.0017
2	98.0772	98.0676	.0096
3			
Less acetone blank			.0001
Weight of particulate matter			.0078

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final		
Initial		
Liquid collected		
Total Volume Collected		g* ml

Run No. BLANK
 Filter No. N/A
 Acetone No. M6
 Amount liquid lost during transport 0
 Acetone blank volume, ml 250
 Acetone wash volume, ml N/A
 Acetone blank concentration, mg/mg (equation 5-4)** 1.5×10^{-6}
 Acetone wash blank, mg (equation 5-5)** N/A

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	95.7882	95.7879	0.0003
2			
3			
Less acetone blank			
Weight of particulate matter			

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final		
Initial		
Liquid collected		
Total Volume Collected		g* ml

*Convert weight of water to volume by dividing total weight increase by density of water (1g/ml): $\frac{\text{Increase, g}}{1\text{g/ml}} = \text{Volume Water, ml}$

**See Federal Register, Method 5, 5.6, & 6.7.

APPENDIX - D
TEST EQUIPMENT CALIBRATIONS

EXPANDED RANGE DIGITAL THERMOMETER INSTRUCTIONS

Specifications

Digital Display: 4 LCD digits

Sampling Time: Less than 1 second

Resolution: 1 Degree

Fahrenheit Model

Accuracy Chart:

Temp. Range	Accuracy (+/-)
32 to 932 °F	0.75% + 2 °F
933 to 1382 °F	1% + 2 °F
1383 to 1832 °F	2% + 2 °F (typical)
1833 to 2000 °F	4% + 2 °F (typical)
31 to -4 °F	4 °F (typical)
-5 to -50 °F	6 °F (typical)

Celsius Model

Accuracy Chart:

Temp. Range	Accuracy (+/-)
0 to 500 °C	0.75% + 1 °C
501 to 750 °C	1% + 1 °C
751 to 1000 °C	2% + 1 °C (typical)
1001 to 1200 °C	4% + 3 °C (typical)
0 to -20 °C	2 °C (typical)
-21 to -40 °C	3 °C (typical)
-41 to -50 °C	4 °C (typical)

Case: ABS plastic

Failsafe: Low battery indicator

Power: 9 Volt alkaline battery

Probe Supplied: Ultra-fast response, naked bead type K thermocouple with operating temperature range to 482 °F or 250 °C, and short term usage to 572 °F or 300 °C, Cat. No. 4028.

Dry Gas Meter Calibration Sheet

Client _____ Run By _____
 Project No. _____ Date 2-23-94
 Module L-1 Barometric Press 29.13
 Orifice .176

ΔH in. H ₂ O	Vw initial	Vw final	Vw ft. ³	Vd initial	Vd final	Vd ft. ³	tw °F	tdi °F	tdo °F	Pw in. H ₂ O	Time 6 min.
.5	13.297	18.707	5.410	996.988	1002.534	5.546	69	69 86	69 75	0	14
1.0	18.707	23.792	5.085	1002.534	1007.774	5.240	70	86 98	75 78	0	9
2.0	23.792	29.259	5.467	1007.774	1013.428	5.654	70	98 106	78 82	0	7
4.0	29.259	34.635	5.376	1013.428	1019.003	5.575	70	106 112	82 84	0	5
6.0	34.635	40.090	5.455	1019.003	1024.688	5.685	70	112 116	84 88	0	4

ΔH	$\frac{\Delta H}{13.6}$	Mc (Y)	ΔH_a (For Small Orifice Only)
		$\frac{Vw Pb (td + 460)}{Vd (Pb + \Delta H/13.6) (tw + 460)}$	$\frac{0.0317 \Delta H}{Pb (td + 460)} \cdot \left[\frac{(tw + 460) \theta}{Vw} \right]^2$
.5	.0368	.984	1.908
1.0	.0737	.994	1.760
2.0	.147	1.000	1.819
4.0	.294	1.001	1.902
6.0	.441	0.999	1.761
Average		.996	1.830

- ΔH = Orifice Setting
- Vw = Volume of Gas of Wet Test Meter
- Vd = Volume of Gas of Dry Gas Meter
- Pw = Pressure of Wet Test Meter
- tw = Temperature of Fluid in Wet Test Meter
- tdi = Inlet Temperature of Dry Gas Meter
- tdo = Outlet Temperature of Dry Gas Meter
- td = Average Temperature of Dry Gas Meter
- θ = Time required to pull specified cubic feet
- Mc = Dry Gas Meter Correction Factor
- ΔH_a = Orifice setting that would pull .75 cfm of air at standard conditions

Dry Gas Meter Calibration Sheet

Client _____ Run By TOM SCHEPPERS
 Project No. _____ Date 7/29/94
 Module L-1 Barometric Press 29.40
 Orifice .176

ΔH in. H ₂ O	Vw initial	Vw final	Vw ft. ³	Vd initial	Vd final	Vd ft. ³	tw °F	tdi °F	tdo °F	Pw in. H ₂ O	Time θ min.
.5	41.588	48.701	7.113	903.784	911.161	7.377	88/	95/103	98/99	0	18
1.0	48.701	54.525	5.824	911.161	917.244	6.083	88	103/123	99/103	0	10
2.0	54.525	60.078	5.553	917.244	923.057	5.813	87	124/127	103/106	0	7
4.0	60.078	65.527	5.449	923.057	928.748	5.691	87	127/132	106/109	0	5
6.0	65.527	71.054	5.527	928.748	934.509	5.761	87	132/137	109/111	0	4

ΔH	$\frac{\Delta H}{13.6}$	Mc (Y)	ΔH_a (For Small Orifice Only)
		$\frac{Vw Pb (td + 460)}{Vd (Pb + \Delta H/13.6) (tw + 460)}$	$\frac{0.0317 \Delta H}{Pb (td + 460)} \left[\frac{(tw + 460) \theta}{Vw} \right]^2$
.5	.0368	0.981	1.879
1.0	.0737	0.988	1.705
2.0	.147	0.998	1.807
4.0	.294	1.002	1.903
6.0	.441	1.005	1.764
Average		0.995	1.811

- ΔH = Orifice Setting
- Vw = Volume of Gas of Wet Test Meter
- Vd = Volume of Gas of Dry Gas Meter
- Pw = Pressure of Wet Test Meter
- tw = Temperature of Fluid in Wet Test Meter
- tdi = Inlet Temperature of Dry Gas Meter
- tdo = Outlet Temperature of Dry Gas Meter
- td = Average Temperature of Dry Gas Meter
- θ = Time required to pull specified cubic feet
- Mc = Dry Gas Meter Correction Factor
- ΔH_a = Orifice setting that would pull .75 cfm of air at standard conditions

ANEROID BAROMETER CALIBRATION

Instrument Number BM-60


Calibrated By TOM SCHEPPERS

Date 6/19/93 - 7/29/94

[illegible]

Nozzle Calibration

Sized By TOM SCHEPPERS

[illegible]

All Dimensions are in inches.

Pitot Calibration Form

Client _____
 Project No. _____
 Test Location _____

Run By Tom SCHEPPERS
 Date 5/5/94
 Pitot No. P3

● "A" Side Calibration				
Run No.	ΔP std cm H ₂ O (in. H ₂ O)	ΔP (s) cm H ₂ O (in. H ₂ O)	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	1.0	1.41	.84	0
2	1.0	1.41	.84	0
3	1.0	1.41	.84	0
Average		$\bar{C}_p$ (Side A)	.84	0

Calculations:

$$C_p(s) = 0.99 \sqrt{\frac{\Delta P \text{ (standard)}}{\Delta P(s)}}$$

$$\text{Deviation} = C_p(s) - \bar{C}_p(A \text{ or } B)$$

$$\text{Average Deviation} = \sigma(A \text{ or } B) = \frac{1}{3} \sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ or } B)|$$

●● "B" Side Calibration				
Run No.	ΔP std cm H ₂ O (in. H ₂ O)	ΔP (s) cm H ₂ O (in. H ₂ O)	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	1.0	1.41	.84	0
2	1.0	1.41	.84	0
3	1.0	1.41	.84	0
Average		$\bar{C}_p$ (Side B)	.84	0

$$|\bar{C}_p(\text{Side A}) - \bar{C}_p(\text{Side B})| = 0$$

Nozzle size used for Calibrations (inches) .500

Intercomponent Spacings During Calibrations:

Pitot - Nozzle: > 3/4"

* Pitot - Thermocouple: ~2" back

Pitot - Probe Sheath: > 3"

* or two inches from end of thermocouple to center line of pitot tube.

Thermocouple Calibrations

(Oven, Probe)

Client AEROMET

2-9-93

Project No. -

Thermocouple Identification	Trendicator	Thermometer	Thermometer Number	Date	
THT-4-780	67	67.4	NIST-C	2-9-93	DIGITAL THERMOM.
THT-4-780	157	157.3	NIST-C	2-9-93	
THT-4-780	212	211.0	NIST-C	2-9-93	
THT-4-740	67	67.4	NIST-C	2-9-93	
THT-4-740	157	157.3	NIST-C	2-9-93	
THT-4-740	211	211.0	NIST-C	2-9-93	
G8A	67	67.4	NIST-C	2-9-93	PROBES
G8A	211	211.4	NIST-C	2-9-93	
G8B	67	67.4	NIST-C	2-9-93	
G8B	211	211.2	NIST-C	2-9-93	
L-1 OVEN	250	248	THT-4-780	2-9-93	L-1 METER BOX
L-1 DGM IN	67	67.4	NIST-C	2-9-93	
L-1 DGM OUT	68	67.4	NIST-C	2-9-93	
L-1 IMP OUT	67	67.4	NIST-C	2-9-93	
D-1 OVEN	255	253	THT-4-780	2-9-93	D-1 METER BOX
D-1 DGM IN	67	67.4	NIST-C	2-9-93	
D-1 DGM OUT	67	67.4	NIST-C	2-9-93	
D-1 IMP OUT	67	67.4	NIST-C	2-9-93	

Denver Instrument Company

Certificate of Calibration

Model A-250

Serial Number B333665

Date 12-13-91

We hereby certify that the referenced instrument was manufactured in the United States and that it has been calibrated to full capacity using NBS Class S-1 weights. This instrument has been fully inspected and has passed all quality tests as specified by Denver Instrument Company quality control guidelines.

To assure proper operation, it may be necessary to recalibrate the instrument periodically using known weights.

David West
Quality Technician

David Grigg
Quality Control Manager

Denver Instrument Company
6542 Ely Street • Avondale, Colorado 80004 • 1-800-821-7185

APPENDIX - E
TEST EQUIPMENT DESCRIPTION
(Particulate)

TESTING EQUIPMENT - EPA METHOD 5 SAMPLING TRAIN

A RAC Corporation Stack Sampler was used at the sampling location(s). The particulate sampling train consisted basically of a glass or stainless steel probe; a variable-heat-controlled filter oven with a calibrated thermometer located at the impinger outlet; a 1/2-hp shaft sealed carbon vane vacuum pump assembly with a vacuum gauge; a control unit with an elapse time indicator, a temperature indicator (potentiometer), temperature controllers, gauges, a calibrated dry gas meter, and an umbilical and various interconnecting hoses, fitting and valves. An appropriately sized glass or stainless-steel nozzle, a calibrated Type K temperature sensor, a static pressure tube, a calibrated S type pitot tube and a variable-heat-controlled stainless-steel liner are integral parts of the probe assembly.

The vacuum pump was used to control gas sampling rates. The control unit was used to control probe and oven temperatures. The control unit was also used to monitor elapsed sampling times, temperatures, velocities, static pressure, gas sampling rates and sampled gas volume.

Analyzer (Orsat)

Flue gas concentrations were determined with a Gas Analyzer (Orsat) which measures the percentage of carbon dioxide, percentage of oxygen and percentage of carbon monoxide to the nearest tenth of a percent.

Programmable Calculator

A Hewlett Packard, Model HP41CX, programmable calculator was used to determine the isokinetic sampling rate at each sampling point.

Prior to the field testing, the following procedures were performed: All instruments were checked and calibrated. Gelman Spectro Grade, glass-fiber-mat filters with 99.95 percent retention of 0.3-micron particles were individually numbered, placed in similarly numbered glass petri dishes, desiccated for 24 hours and weighed on a Sartorius analytical balance to the nearest 0.1-milligram, and weighed a minimum of every six hours until two consecutive weights within +0.5 milligram were obtained, or heated for two to three hours at 220 degrees F, cooled in a desiccator and weighed. Several 250 milliliter crucibles were desiccated for a minimum of 24 hours and weighed in the same manner as the filters and petri dishes. Also, several 200-gram quantities of Type 6-16 mesh indicating silica gel were weighed on an beam balance and placed into separate airtight storage containers.

The number of sampling points and positions of the points in the flue at the sampling location(s), and the sampling time at each point were determined prior to the particulate testing. The sampling procedures were performed in accordance with the Environmental Protection Agency's Reference Method 5, "Determination of Particulate Emissions from Stationary Sources" in the July 1, 1989 Federal Register, "Standards of Performance for New Stationary Sources" and subsequent revisions.

Before each test run a particulate sampling train was prepared in part at the sampling location(s) in the following manner: An appropriately sized sampling nozzle was installed onto the inlet of the sampling probe and capped. The probe was then dimensioned and marked at increments that corresponded with the predetermined sampling positions in the flue. A standard impinger assembly was prepared by adding 100 milliliters of distilled water to each of the first two impingers. The third impinger was left dry and the fourth was filled with approximately 200 grams of type 6-16 mesh indicating silica gel. The entire impinger assembly was then placed in an ice bath. A disc filter was removed from its petri dish and placed inside of a filter holder. The filter holder was then placed inside of a filter oven and assembled to the sampling probe outlet and the impinger unit inlet. Next, an umbilical and sampling hoses were connected to the sampling probe, filter oven, impinger unit, a vacuum pump and the control unit, accordingly. The probe and oven were then heated to and held at 248 degrees plus or minus 25 degrees.

As soon as the probe and oven temperatures had stabilized the entire sampling train assembly was leak-checked at a minimum of 15 inches of mercury vacuum for one minute and the leakage rate recorded. A leakage rate of less than .02 cfm and no vacuum loss was considered acceptable.

After the particulate sampling train had been assembled, the probe and oven heated, and the entire system leak-checked, as previously described, the particulate sampling was performed.

Three test runs were performed at the sampling location(s). The sampling data for each test run was recorded on a field test form during each of the sampling periods.

After the completion of a test run, the following procedures were performed: A final leak-check was performed at maximum vacuum or greater incurred during the test for one minute and the leakage rate recorded. The flue gas moisture collected in the first three impingers was measured and recorded. The moisture laden silica gel in the fourth impinger was weighed on site. The weight gain of the silica gel

moisture collection was added to the measured moisture condensed for that test run. The sample nozzle, probe and filter holder were capped and taken to a clean area for sample recovery. At the recovery area, the disc filter was carefully removed from the filter holder and transferred to its petri dish for later weighing.

The sampling nozzle, probe and filter holder were washed with nanograde acetone, glass components were washed three times, stainless steel components were washed six times and visually inspected for cleanliness. The acetone washing and acetone blank were collected and labeled polypropylene sample bottles and retained for later evaporation, desiccation and weighing.

Flue gas concentrations (percentage of CO_2 , percentage of O_2 , and percentage of CO) were determined by taking several Orsat samples of the gas collected, simultaneously with the particulate sampling, throughout the test run, by an integrated gas sampling train. The integrated gas sample was collected from the discharge of the particulate control unit. The sampling train was set at a predetermined constant flow rate to obtain an adequate sample or by taking direct readings from the sampling points. The concentrations for each test run were recorded on a field test form.

APPENDIX - F
USEPA REFERENCE METHOD 5

APPENDIX - G
VISIBLE FIELD DATA SHEETS

Visible Emission Observation Form

SOURCE NAME MASTERS - JACKSON PAVING				OBSERVATION DATE 7/21/94				START TIME 10:51				STOP TIME 11:51				
ADDRESS PO. Box 1187				SEC MIN				SEC MIN				SEC MIN				
				0	15	30	45	0	15	30	45	0	15	30	45	
PLANT AT BUFFALO				1	0	0	0	0	31	0	0	0	0	0	0	0
CITY SPRINGFIELD		STATE MO		ZIP 65801		2	0	0	0	0	32	0	0	0	0	
PHONE (417) 881-5581		SOURCE ID NUMBER		3	0	0	0	0	33	0	0	0	0	0	0	
PROCESS EQUIPMENT ASPHALT PLANT		OPERATING MODE NORMAL		4	0	0	0	0	34	0	0	0	0	0	0	
CONTROL EQUIPMENT BAGHOUSE		OPERATING MODE NORMAL		5	0	0	0	0	35	0	0	0	0	0	0	
DESCRIBE EMISSION POINT START MAIN STACK STOP MAIN STACK				6	0	0	0	0	36	0	0	0	0	0	0	
HEIGHT ABOVE GROUND LEVEL 20'		HEIGHT RELATIVE TO OBSERVER 20'		7	0	0	0	0	37	0	0	0	0	0	0	
DISTANCE FROM OBSERVER 100'		DIRECTION FROM OBSERVER W		8	0	0	0	0	38	0	0	0	0	0	0	
DESCRIBE EMISSIONS START CLOUDY STOP CLOUDY				9	0	0	0	0	39	0	0	0	0	0	0	
EMISSION COLOR START CLOUDY STOP		PLUME TYPE: CONTINUOUS ☐ FUGITIVE ☐ INTERMITTENT ☐		10	0	0	0	0	40	0	0	0	0	0	0	
WATER DROPLETS PRESENT: NO ☒ YES ☐		IF WATER DROPLET PLUME: ATTACHED ☐ DETACHED ☐		11	0	0	0	0	41	0	0	0	0	0	0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 1 D STOP 1 D				12	0	0	0	0	42	0	0	0	0	0	0	
DESCRIBE BACKGROUND START CLOUDY SKY STOP CLOUDY SKY				13	0	0	0	0	43	0	0	0	0	0	0	
BACKGROUND COLOR START WHITE STOP		SKY CONDITIONS START CLD STOP CLD		14	0	0	0	0	44	0	0	0	0	0	0	
WIND SPEED START STOP		WIND DIRECTION START S STOP S		15	0	0	0	0	45	0	0	0	0	0	0	
AMBIENT TEMP. START STOP		WET BULB TEMP. RH.percent		16	0	0	0	0	46	0	0	0	0	0	0	
Source Layout Sketch Draw North Arrow				17	0	0	0	0	47	0	0	0	0	0	0	
				18	0	0	0	0	48	0	0	0	0	0	0	
				19	0	0	0	0	49	0	0	0	0	0	0	
				20	0	0	0	0	50	0	0	0	0	0	0	
				21	0	0	0	0	51	0	0	0	0	0	0	
				22	0	0	0	0	52	0	0	0	0	0	0	
				23	0	0	0	0	53	0	0	0	0	0	0	
				24	0	0	0	0	54	0	0	0	0	0	0	
				25	0	0	0	0	55	0	0	0	0	0	0	
				26	0	0	0	0	56	0	0	0	0	0	0	
AVERAGE OPACITY FOR HIGHEST PERIOD 0 RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0 NUMBER OF READINGS ABOVE 0 % WERE 0 OBSERVER'S NAME (PRINT) Jeff Baker OBSERVER'S SIGNATURE [Signature] DATE 7/21/94 ORGANIZATION AEROMET ENGINEERING, INC CERTIFIED BY AEROMET ENGR - Tom S DATE 7/18/94 VERIFIED BY MODNR - DOUG ELLEY DATE 7/18/94				27	0	0	0	0	57	0	0	0	0	0	0	
				28	0	0	0	0	58	0	0	0	0	0	0	
				29	0	0	0	0	59	0	0	0	0	0	0	
				30	0	0	0	0	60	0	0	0	0	0	0	
COMMENTS				I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE				TITLE				DATE				

Visible Emission Observation Form

SOURCE NAME MASTERS - JACKSON PAVING			OBSERVATION DATE 7/21/94				START TIME 1:11		STOP TIME 2:11	
ADDRESS P.O. BOX 1187			SEC MIN		0	15	30	45	SEC MIN	
PLANT AT BUFFALO			1		0	0	0	0	31	
CITY SPRINGFIELD STATE MO ZIP 65801			2		0	0	0	0	32	
PHONE (417) 881-5581 SOURCE ID NUMBER			3		0	0	0	0	33	
PROCESS EQUIPMENT ASPHALT PLANT OPERATING MODE NORMAL			4		0	0	0	0	34	
CONTROL EQUIPMENT BAG HOUSE OPERATING MODE NORMAL			5		0	0	0	0	35	
DESCRIBE EMISSION POINT START MAIN STACK STOP MAIN STACK			6		0	0	0	0	36	
HEIGHT ABOVE GROUND LEVEL 20' HEIGHT RELATIVE TO OBSERVER 20'			7		0	0	0	0	37	
DISTANCE FROM OBSERVER 100' DIRECTION FROM OBSERVER W			8		0	0	0	0	38	
DESCRIBE EMISSIONS START clear STOP clear			9		0	0	0	0	39	
EMISSION COLOR START clear STOP clear PLUME TYPE: CONTINUOUS ☐ FUGITIVE ☐ INTERMITTENT ☐			10		0	0	0	0	40	
WATER DROPLETS PRESENT: NO YES ☐ IF WATER DROPLET PLUME: ATTACHED ☐ DETACHED ☐			11		0	0	0	0	41	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START ~ 1 Diameter STOP Same			12		0	0	0	0	42	
DESCRIBE BACKGROUND START blue sky STOP blue sky			13		0	0	0	0	43	
BACKGROUND COLOR START blue STOP blue SKY CONDITIONS START clear STOP clear			14		0	0	0	0	44	
WIND SPEED START 10 STOP 10 WIND DIRECTION START S STOP S			15		0	0	0	0	45	
AMBIENT TEMP. START STOP WET BULB TEMP. RH, percent			16		0	0	0	0	46	
Source Layout Sketch Draw North Arrow			17		0	0	0	0	47	
			18		0	0	0	0	48	
			19		0	0	0	0	49	
			20		0	0	0	0	50	
			21		0	0	0	0	51	
			22		0	0	0	0	52	
			23		0	0	0	0	53	
			24		0	0	0	0	54	
			25		0	0	0	0	55	
			26		0	0	0	0	56	
			27		0	0	0	0	57	
			28		0	0	0	0	58	
			29		0	0	0	0	59	
			30		0	0	0	0	60	
AVERAGE OPACITY FOR HIGHEST PERIOD 0			NUMBER OF READINGS ABOVE 0 % WERE 0							
RANGE OF OPACITY READINGS 0 MINIMUM 0 MAXIMUM										
OBSERVER'S NAME (PRINT) JEFF BROKER										
OBSERVER'S SIGNATURE <i>Jeff Broker</i>										
DATE 7/21/94										
ORGANIZATION AEROMET ENGR, INC.										
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE										
CERTIFIED BY AEROMET - Tom SCHEPPERS										
DATE 7/18/94										
VERIFIED BY MO DNR - DOUG ELLEY										
DATE 7/18/94										

Visible Emission Observation Form

SOURCE NAME				OBSERVATION DATE				START TIME				STOP TIME			
MASTERS - JACKSON PAVING				7/21/94				3:19				4:19			
ADDRESS				SEC				SEC							
PO. Box 1187				MIN 0 15 30 45				MIN 0 15 30 45							
PLANT AT BUFFALO				1 0 0 0 0				31 0 0 0 0							
CITY		STATE		ZIP		2 0 0 0 0		32 0 0 0 0							
SPRINGFIELD		MO		65801		3 0 0 0 0		33 0 0 0 0							
PHONE		SOURCE ID NUMBER		4 0 0 0 0		34 0 0 0 0									
(417) 881-5581				5 0 0 0 0		35 0 0 0 0									
PROCESS EQUIPMENT		OPERATING MODE		6 0 0 0 0		36 0 0 0 0									
ASPHALT PLANT		NORMAL		7 0 0 0 0		37 0 0 0 0									
CONTROL EQUIPMENT		OPERATING MODE		8 0 0 0 0		38 0 0 0 0									
BAGHOUSE		NORMAL		9 0 0 0 0		39 0 0 0 0									
DESCRIBE EMISSION POINT				10 0 0 0 0		40 0 0 0 0									
START MAIN STACK STOP MAIN STACK				11 0 0 0 0		41 0 0 0 0									
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER		12 0 0 0 0		42 0 0 0 0									
20'		20'		13 0 0 0 0		43 0 0 0 0									
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER		14 0 0 0 0		44 0 0 0 0									
50'		NW		15 0 0 0 0		45 0 0 0 0									
DESCRIBE EMISSIONS				16 0 0 0 0		46 0 0 0 0									
START CLEAR STOP CLEAR				17 0 0 0 0		47 0 0 0 0									
EMISSION COLOR		PLUME TYPE: CONTINUOUS ☐		18 0 0 0 0		48 0 0 0 0									
START CLEAR STOP		FUGITIVE ☐ INTERMITTENT ☐		19 0 0 0 0		49 0 0 0 0									
WATER DROPLETS PRESENT:		IF WATER DROPLET PLUME:		20 0 0 0 0		50 0 0 0 0									
NO ☒ YES ☐		ATTACHED ☐ DETACHED ☐		21 0 0 0 0		51 0 0 0 0									
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED				22 0 0 0 0		52 0 0 0 0									
START 10 STOP 10				23 0 0 0 0		53 0 0 0 0									
DESCRIBE BACKGROUND				24 0 0 0 0		54 0 0 0 0									
START SKY STOP SKY				25 0 0 0 0		55 0 0 0 0									
BACKGROUND COLOR		SKY CONDITIONS		26 0 0 0 0		56 0 0 0 0									
START Blue STOP Blue		START CLEAR STOP CLEAR		27 0 0 0 0		57 0 0 0 0									
WIND SPEED		WIND DIRECTION		28 0 0 0 0		58 0 0 0 0									
START 10 mph STOP 10 mph		START S STOP S		29 0 0 0 0		59 0 0 0 0									
AMBIENT TEMP.		WET BULB TEMP.		30 0 0 0 0		60 0 0 0 0									
START STOP		RH. percent													
Source Layout Sketch				AVERAGE OPACITY FOR HIGHEST PERIOD				NUMBER OF READINGS ABOVE % WERE							
Draw North Arrow				RANGE OF OPACITY READINGS				MINIMUM MAXIMUM							
				OBSERVER'S NAME (PRINT)				OBSERVER'S SIGNATURE							
				Jeff Baker				DATE 7/21/94							
COMMENTS				ORGANIZATION				DATE 7/18/94							
				AEROMET ENGINEERING, INC.				DATE 7/18/94							
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS				CERTIFIED BY				DATE 7/18/94							
SIGNATURE				AEROMET ENGINEERING				DATE 7/18/94							
TITLE				VERIFIED BY				DATE 7/18/94							
				MODNR - DOUG ELLEY											

APPENDIX - H

VISIBLE EMISSIONS CERTIFICATION

AEROMET

ENGINEERING

1325 AEROTEC DRIVE
JEFFERSON CITY, MO 65109
(314) 636-6393
(314) 636-9767 FAX

July 29, 1994


Mr. Jeff Broker
AeroMet Engineering, Inc.
1325 Aerotec Drive
Jefferson City, MO 65109

Dear Mr. Broker:

AeroMet Engineering, Inc. hereby informs you that you have successfully completed Visible Emissions Observer Training held in Jefferson City on July 18, 1994. This qualifies you for certification by the State of Missouri as a Visible Emissions Observer.

Sincerely,

AEROMET ENGINEERING, INC.



Thomas Scheppers, P.E.
President

APPENDIX - I
USEPA REFERENCE METHOD 9

APPENDIX - J

48 CFR PART 60 SUBPART I

(Standards of Performance for Hot Mix Asphalt Facilities)

APPENDIX - K
ASPHALT PRODUCTION RECORDS
(July 21, 1994)

Time	Mix Temp	Stack Temp	Diff. pres.	Tons Per hour	Moisture
10:50	315°	279°	4	250	5
11:05	311°	276°	4	250	5
11:20	315°	277°	4½	255	
11:35	305°	276°	4	255	
1:50	319°	282°	4	255	

Test #2

1:10	310°	272°	4	255	5
1:25	298°	276°	4	260	
1:40	311	275°	4	255	
1:55	312°	276°	4	255	
2:10	298°	279°	4	255	
2:25	307°	278°	4	255	

Test #3

3:15	318°	282°	4	255	
3:30	308°	276°	4	255	
3:45	303°	274°	4	255	
4:00	312°	282°	4	255	
4:15	309°	280°	4	255	
4:30					

APPENDIX - L

SAMPLE CALCULATIONS

NOMENCLATURE

acf	= actual cubic feet	P_f	= static pressure in flue in inches water, average
acfm	= actual cubic feet per minute	$\sqrt{\Delta P}$	= square root of velocity head in inches water, average
A	= effective area of flue in square feet	%S	= percent sulfur by weight, dry basis
acm	= actual cubic meters	scf	= standard cubic feet
acmm	= actual cubic meters per minute	scm	= standard cubic meters
A_n	= inside area of sampling nozzle in square feet	T_{std}	= absolute temperature of air in degrees Rankine at standard conditions (528 degrees)
B_{ws}	= water vapor in gas stream, proportion by volume	T_s	= absolute temperature of flue gas in degrees Rankine, average
%C	= percent carbon by weight, dry basis	T_m	= absolute temperature at meter in degrees Rankine, average
%CO	= percent carbon monoxide by volume, dry basis	V_s	= velocity of flue gas in feet (meters) per second
%CO ₂	= percent carbon dioxide by volume, dry basis	V_l	= volume of condensate through the impingers in milliliters
C_p	= pitot tube coefficient	V_{lc}	= volume of liquid collected in condenser in milliliters plus weight of liquid absorbed in silica gel in grams indicated as milliliters
D_l	= dust loading per heat input in pounds (grams) per million Btu (calories) per Fr constant	V_m	= volume of metered gas measured at meter conditions in cubic feet
D_l'	= dust loading per heat input in pounds (grams) per million Btu (calories) per Fr calculated	V_{ms}	= volume of metered gas corrected to dry standard conditions in cubic feet (meters)
dscf	= dry standard cubic feet	V_o	= volume of flue gas at actual conditions in cubic feet (meters) per minute
dscfh	= dry standard cubic feet per hour	Q_{sd}	= volume of flue gas corrected to dry standard conditions in cubic feet (meters) per hour
dscm	= dry standard cubic meters	V_t	= total volume of flue gas sampled at actual conditions in cubic feet (meters)
dscmh	= dry standard cubic meters per hour	V_w	= volume of water vapor in metered gas corrected to standard conditions in cubic feet (meters)
fps	= feet per second	V_{wc}	= volume of water condensed in impingers corrected to standard conditions
F_r	= ratio factor of dry flue gas volume to heat value of combusted fuel in dry standard cubic feet (meters) per million Btu (calories)	V_{wsg}	= volume of water collected in silica gel corrected to standard conditions
gms	= grams	W_a	= total weight of dust collected per unit volume in grains (grams) per actual cubic feet (meters)
gm-mole	= gram-mole	W_d	= total weight of dust collected per unit volume in pounds (grams) per dry standard cubic feet (meters)
grs	= grains	W_g	= total weight of dust collected in grams
ΔH	= orifice pressure drop in inches water, average	W_h	= total weight of dust collected per unit volume in pounds (grams) per hour, dry basis
%H	= percent hydrogen by weight, dry basis	W_p	= total weight of dust collected in pounds
H_c	= heat of combustion in Btu per pound, dry basis	W_s	= total weight of dust collected per unit volume in grains (grams) per dry standard cubic feet (meters)
hr	= hour	W_{sg}	= impinger silica gel weight gain in grams
%I	= percent isokinetic	Y	= metered gas volume correction factor
in. Hg	= inches mercury	Θ	= total elapsed sampling time in minutes
lbs	= pounds		
lb-mole	= pound-mole		
%M	= percent moisture by volume		
mmBtu	= million Btu		
mmcal	= million calories		
mm Hg	= millimeters mercury		
mps	= meters per second		
M_s	= molecular weight in pound (gram) per pound (gram) mole (wet basis)		
%N	= percent nitrogen by weight, dry basis		
%N ₂	= percent nitrogen by difference, dry basis		
%O	= percent oxygen by difference, dry basis		
%O ₂	= percent oxygen by volume, dry basis		
P_b	= barometric pressure in inches mercury		
P_{std}	= standard absolute pressure (29.92 in Hg)		
P_s	= absolute pressure in flue in inches (millimeters) mercury		

EPA DUST LOADING FORMULAS

- (1) ABSOLUTE FLUE PRESSURE (in. Hg)

$$P_s = (\pm P_i + 13.6) + P_b$$

- (2) WATER VAPOR VOLUME IN METERED GAS CORRECTED TO STANDARD CONDITIONS (scf)

$$V_{wc} = .04707 \times V_i \quad V_{wsg} = .04715 \times W_{sg}$$

$$V_w = V_{wc} + V_{wsg}$$

- (3) METERED GAS VOLUME CORRECTED TO STANDARD CONDITIONS (scf)

$$V_{ms} = 17.64 \times Y \times V_m \times \frac{P_b + (\Delta H/13.6)}{T_m}$$

- (4) PERCENT MOISTURE IN FLUE GAS

$$B_{ws} = \frac{V_w}{(V_{ms} + V_w)} \quad \%M = B_{ws} \times 100$$

- (5) AVERAGE RESULTS OF FLUE GAS ANALYSIS

$$\%N_2 \text{ dry} = 100 - (\%CO_2 + \%O_2 + \%CO)$$

- (6) APPROXIMATE MOLECULAR WEIGHT OF FLUE GAS (WET BASIS) (lb/lb-mole)

$$M_s = (18 \times B_{ws}) + \left((1.440 (\%CO_2) + .320 (\%O_2) + .280 (\%N_2 + \%CO)) \right) \times (1 - B_{ws})$$

- (7) GAS VELOCITY IN FLUE (fps)

$$V_s = 85.49 \times C_p \times (\sqrt{\Delta P}) \text{ avg. } \sqrt{\frac{T_s}{P_s \times M_s}}$$

- (8) FLUE GAS VOLUME AT ACTUAL CONDITIONS (acfm)

$$V_0 = V_s \times A \times 60$$

- (9) FLUE GAS VOLUME CORRECTED TO DRY STANDARD CONDITIONS (dscfh)

$$Q_{sd} = \frac{T_{std}}{29.92} \times \frac{P_s}{T_s} \times V_0 \times (1 - B_{ws}) \times 60$$

- (10) TOTAL FLUE GAS VOLUME SAMPLED AT ACTUAL CONDITIONS (acft)

$$V_1 = \left[V_m \times Y \times \frac{T_s}{T_m} \times \left(\frac{P_b + (\Delta H/13.6)}{P_s} \right) \right] + \left(0.00267 \times V_{lc} \times \frac{T_s}{P_s} \right)$$

EPA DUST LOADING FORMULAS (Continued)

(11) DUST CONCENTRATION FOR INDIRECT HEATING UNIT AT ACTUAL CONDITIONS AND STANDARD CONDITIONS

$$W_g = \text{gms}$$

$$W_p = 0.002205 \times W_g \quad (\text{lb})$$

$$W_d = \frac{W_p}{V_{ms}} \quad (\text{lb/dscf})$$

$$W_h = W_d \times Q_{sd} \quad (\text{lb/hr dry})$$

$$W_a = \frac{7000 \times W_p}{V_t} \quad (\text{gr/acf})$$

$$W_s = 7000 \times W_d \quad (\text{gr/dscf})$$

$$D_1 = \frac{9820 \times 20.9 \times W_d}{(20.9 - \%O_2)} \quad (\text{lb/mmBtu with constant } 9820 F_r)$$

$$F_r = \frac{10^6 \times [(3.64 \times \%H) + (1.53 \times \%C) + (0.57 \times \%S) + (0.14 \times \%N) - (0.46 \times \%O)]}{H_c} \quad (\text{dscf/mmBtu})$$

$$D_1' = \frac{20.9 \times W_d \times F_r}{(20.9 - \%O_2)} \quad (\text{lb/mmBtu with calculated } F_r)$$

(12) PERCENT OF ISOKINETIC SAMPLING

$$\%I = \frac{1.667 \times T_s \times \left\{ 0.00267 \times V_{lc} + \left[\frac{V_m \times Y}{T_m} \times (P_b + \Delta H/13.6) \right] \right\}}{\Theta \times V_s \times P_s \times A_n}$$

PLANT NAME: Masters & Jackson
 LOCATION: Buffalo, ND

TEST UNIT: Astec dbl. drum plant
 DATE: 7/21/94 RUN NO: 2

NUMBER OF POINTS 24
 TIME, MINUTE/POINT 2.50
 LEAK RATE, FT3/MIN 0.003
 BAR PRESS, INCH Hg 28.73
 STATIC PRESS (in H2O) 1.00
 STACK EXIT LENGTH IN 27.13
 STACK EXIT WIDTH IN 40.25
 INPINGER H2O, ML 550.6
 SILICA GEL H2O, GM 28.0

PERCENT OXYGEN 13.60
 PERCENT CARBON DIOXIDE 5.70
 PERCENT CARBON MONOXIDE 0.00
 Cp (PITOT COEFFICIENT) 0.840
 NOZZLE DIAMETER, INCHES 0.252
 INITIAL METER VOL, FT3 639.015
 FINAL METER VOL, FT3 698.982
 METER CORR FACT, Y 0.996
 PARTIC COLLECTED, MG 7.80

PT NO	STACK TEMP (Ts)	VELOC PRESS (dPs)	ORIFICE PRESS (dH)	METER TEMP INLET (Tm1)	METER TEMP OUTLET (Tm2)	SQR ROOT VELOC PRESS
1	256	1.70	3.15	93	94	1.304
2	257	2.20	4.09	98	95	1.483
3	259	2.00	3.74	108	95	1.414
4	260	1.50	2.82	114	96	1.225
5	262	1.40	2.62	112	96	1.183
6	262	1.80	3.38	115	97	1.342
7	264	1.80	3.38	118	98	1.342
8	266	1.50	2.82	121	98	1.225
9	265	1.30	2.45	119	100	1.140
10	266	3.01	120.00	100	96	1.735
11	270	1.90	3.58	122	101	1.378
12	269	1.50	2.82	124	102	1.225
13	270	1.50	2.82	123	102	1.225
14	269	1.60	3.01	122	103	1.265
15	270	1.90	3.58	124	104	1.378
16	269	1.70	3.22	128	104	1.304
17	268	1.60	3.03	126	104	1.265
18	269	1.50	2.84	126	105	1.225
19	267	2.00	3.80	127	106	1.414
20	267	2.10	3.99	128	106	1.449
21	267	2.00	3.79	128	107	1.414
22	267	1.60	3.04	129	106	1.265
23	266	2.20	4.20	130	106	1.483
24	266	2.50	4.79	134	107	1.581
25						
26						
27						
28						
29						
30						
AVG	265.5	1.825	3.21	119.3	101.2	1.3443

STACK GAS MOL WT. WET 25.62
 STACK VELOCITY (ft/sec) 95.71
 STD VOL SAMPLED (std ft2) 54.20
 AVG METER TEMP (deg F) 110.23
 PERCENT MOISTURE (%) 33.45
 STD STACK FLOW RATE (DSCFM) 20302.98
 ISOKINETIC VARIATION (%) 97.34
 PARTIC EMISSION RATE (lb/hr) 0.3865
 PARTICULATE CONC (gr/DSCFM) 0.002221
 FUEL F FACTOR DRY (Fd)

AVG ABS STACK TEMP (d) 725.5
 AVG ABS METER TEMP (d) 570.2
 METER LEAK RATE (ft3/ 0.000
 SAMPLE VOL LK CORR'D 59.97
 AVG ABS STACK PRESS (28.80
 VOL H2O IN METER GAS 27.24
 H2O IN GAS STREAM (vd 0.334
 NOZZLE AREA (ft2) 0.00035
 STACK AREA (ft2) 7.582
 STACK EQUIV DIAMETER 32.41
 POUNDS PER MILLION BTU 0

PLANT NAME: Masters & Jackson

TEST UNIT: Astec dbl. drum plant