

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section: 11.1

Reference Number: 379

**Title: Stack Emission Test, Payne And Dolan, Inc.,
Control 34 Plant,**

**Environmental Technology and Engineering
Corporation, Elm Grove, WI,**

July 28 and October 6, 1999.

Sec. 11.1
Ref. 379

SO₂ HQ

Report to

PAYNE & DOLAN, INC.
Waukesha, Wisconsin

for

**STACK EMISSION TEST
CONTROL 34 PLANT**

July 28 & October 6, 1999

by

ENVIRONMENTAL TECHNOLOGY & ENGINEERING CORPORATION

13000 West Bluemound Road
Elm Grove, Wisconsin 53122
Phone 262-784-2434
Fax 262-784-2436

ETE

SUMMARY

On July 28 & October 6, 1999, Environmental Technology & Engineering Corp. personnel performed stack emissions testing at the Payne & Dolan, Inc. Control 34 portable plant. The tests were performed to determine plant specific emission factors for sulfur dioxide and hydrogen chloride. All measured are shown in the following table:

TEST NO.	HYDROGEN CHLORIDE	SULFUR DIOXIDE
1	0.017 lb/hr 0.00007 lb/ton	12.64 lb/hr 0.046 lb/ton
2	0.008 0.00003	14.01 0.051
3	0.006 0.00002	11.95 0.043
AVERAGE	0.010 lb/hr 0.00004 lb/ton	12.87 lb/hr 0.047 lb/ton

1.0 GENERAL

On July 29 & October 6, 1999, Environmental Technology & Engineering Corp. (ETE) personnel performed stack emissions testing at the Payne & Dolan, Inc. Control 34 portable plant. Tests on July 29 were performed in Denmark, Wisconsin. Tests on October 6 were performed in northern Michigan. The purpose of the testing was to determine the sulfur dioxide and hydrogen chloride emissions in order to determine plant specific emission factors. On July 29 additional tests were performed for hydrogen chloride. The laboratory erred in the analysis of these samples and it became necessary to retest on October 6.

Pete Tolsma and Dennis Linsmaier of Payne & Dolan was responsible for assuring proper operating conditions throughout the testing. The plant was fired with drain oil. A log of plant activity throughout the test was kept and is included in the APPENDIX. All testing was coordinated with the plant operator. Raj Rao of the Wisconsin DNR was notified of the July 29 test and did witness. The field tests, corresponding laboratory analysis, and report preparation were performed by ETE personnel; Bill Dick was the test team leader.

The following sections of this report document the activities and results of the test program. The report presents all of the relevant data collected. Discussions on the interpretation of the data are provided where appropriate. The report, therefore, includes much necessary detail. The results, however, have been presented in the SUMMARY section at the beginning of this report for those readers not wishing to be burdened by the details.

2.0 RESULTS

Hydrogen chloride testing was performed using non-isokinetic method 26. Sulfur dioxide samples were collected and analyzed in accordance with EPA Method 6. A brief summary of the methods is included in Section 3.0 of this report.

The tests were performed in the final discharge stack at the location shown in Figure 2-1. This same figure also depicts the location of the exact test points relative to the stack wall. Detailed results of the testing to determine sulfur dioxide emissions are shown in Tables 2-1 through 2-3. Detailed results of the hydrogen chloride emissions are included as Tables 2-4 through 2-6.. The results are summarized below:

TEST NO.	HYDROGEN CHLORIDE	SULFUR DIOXIDE
1	0.017 lb/hr 0.00007 lb/ton	12.64 lb/hr 0.046 lb/ton
2	0.008 0.00003	14.01 0.051
3	0.006 0.00002	11.95 0.043
AVERAGE	0.010 lb/hr 0.00004 lb/ton	12.87 lb/hr 0.047 lb/ton

SO2 EMISSIONS CALCULATIONS

NEA CONTROL #34

FID 999901520

Sulfur in Burner Fuel

S = 0.43% by weight

Mass of Oil

Mass of one gallon oil = mass of water x specific gravity of oil
Mass = 8.34 lb/gallon x 0.8872 = 7.40 lb/gallon

Mass Flow of Sulfur Dioxide from the Burner

7.71 gallons/minute x 60 minutes/hour x 7.40 lbs/gallon x 0.43/100 sulfur/oil x 2 SO2/S =
29.44 lbs SO2/hour

Mass Flow of Sulfur Dioxide from the Plant Stack

12.87 lbs/hour

Sulfur Dioxide Capture Efficiency

EF = 100 x (Burner SO2 - Stack SO2) / Burner SO2

EF = 56.28 %

Potential to Emit SO2 = 650 gallons/hour fuel flow x 1% sulfur in fuel / 100 x 7.4 lbs/gallon x 2SO2 per S
x (1-0.5628) = 42.06 lbs/hour

comp\plt\so2test.wk1

EMISSIONS CALCULATIONS

P&D Control 34

FID 9999012520

Hydrogen Chloride in the Burner Fuel: Burner fuel was analyzed for total halogens, and was expressed as chlorine. Since air toxics considerations are related to hydrogen chloride emissions, chlorine masses and concentrations were corrected to hydrogen chloride.

Cl concentration in the burner fuel = 513 parts per million, by weight.

HCl concentration in the burner fuel = $36/35 \times 558 =$

513 parts per million, by weight

Mass of Oil

Mass of one gallon oil = mass of water x specific gravity of oil

Mass = 8.34 lb/gallon x 0.8872 = 7.40 lb/gallon

Mass Flow of Hydrogen Chloride from the Dryer Drum Burner

7.71 gallons per minute x 60 minutes per hour x 7.40 lb/gallon x 513/100000

1.76 lbs HCl/hour from the dryer drum by the combustion of waste oil

Mass Flow of Hydrogen Chloride from the Plant Stack

0.1 lbs/hour

Hydrogen Chloride Capture Efficiency

EF = $100 \times (\text{Burner HCl} - \text{Stack HCl}) / \text{Burner HCl}$

EF = 94.32 %


Potential to Emit HCl = 650 gallons/hour fuel flow rate x 7.40 lbs/gallon
x 4000 ppm halogens/1000000 x (1-0.9432) =
1.09 lbs HCl/Hour

MURPHY CONCRETE
NEW LONDON
FIGURE 2-1

SAMPLE POINT LOCATION

Point	Distance in
1	4.8
2	14.4
3	24.0
4	33.6
5	43.2

TEST PORT LOCATION



PAYNE & DOLAN

29-Jul-99

CONTROL 34

TABLE 2-1

TEST NO.	1			
BAROMETRIC PRESSURE	29.05	IN HG		
TIP DIAMETER	0.245	IN		
STACK DIMENSIONS	48	IN	48	IN
STACK AREA	16.000	FT3		
SAMPLING TIME PER POINT	2.4	MIN		
NUMBER OF POINTS	25			
METER VOLUME	42.00	FT3		
PITOT COEFFICIENT	0.84			
METER COEFFICIENT	0.999			
SO2 COLLECTED	117.6	MG		
WATER COLLECTED	380	ML		
STATIC PRESSURE	-1.30	IN H2O		
ORSAT RESULTS				
CO2	O2	CO	N2	
5.00%	10.80%	0.00%	84.20%	

POINT	STACK TEMP DEG F	DELTA P IN H2O	ORIFICE DEL P IN H2O	METER TEMP DEG F	VELOCITY AFPS
1	255	0.25	0.80	102	35.11
2	255	0.10	0.80	102	22.21
3	255	0.10	0.80	102	22.21
4	255	0.10	0.80	102	22.21
5	255	0.15	0.80	102	27.20
6	255	0.15	0.80	102	27.20
7	255	0.10	0.80	102	22.21
8	255	0.25	0.80	102	35.11
9	255	0.30	0.80	102	38.47
10	255	0.20	0.80	102	31.41
11	255	1.30	0.80	106	80.07
12	255	1.50	0.80	106	86.01
13	255	1.40	0.80	106	83.09
14	255	1.10	0.80	106	73.66
15	255	1.20	0.80	106	76.93
16	255	2.10	0.80	110	101.77
17	255	2.30	0.80	110	106.51
18	255	2.20	0.80	110	104.16
19	255	2.30	0.80	110	106.51
20	255	2.20	0.80	110	104.16
21	255	2.20	0.80	120	104.16
22	255	2.30	0.80	120	106.51
23	255	2.40	0.80	120	108.80
24	255	2.40	0.80	120	108.80
25	255	2.40	0.80	120	108.80
AVERAGE	255		0.80	108	69.73
DRY STANDARD VOLUME		41.01	SCF		
		1.16	M3		
PERCENT WATER VAPOR		30.37	% VOL		
FLOW RATE		66941	ACFM		
		33309	DSCFM		
SO2 CONCENTRATION		56599	M3/HR		
SO2 EMISSION RATE		101.3	MG/M3		
		12.64	LB/HR		

PAYNE & DOLAN

29-Jul-99

CONTROL 34

TABLE 2-2

TEST NO.	2				
BAROMETRIC PRESSURE	29.05	IN HG			
TIP DIAMETER	0.245	IN			
STACK DIMENSIONS	48	IN	48	IN	
STACK AREA	16.000	FT ²			
SAMPLING TIME PER POINT	2.4	MIN			
NUMBER OF POINTS	25				
METER VOLUME	42.30	FT ³			
PITOT COEFFICIENT	0.84				
METER COEFFICIENT	0.999				
SO ₂ COLLECTED	131.7	MG			
WATER COLLECTED	397	ML			
STATIC PRESSURE	-1.30	IN H ₂ O			

ORSAT RESULTS					
CO ₂	O ₂	CO	N ₂		
5.00%	10.80%	0.00%	84.20%		

POINT	STACK TEMP DEG F	DELTA P IN H ₂ O	ORIFICE DEL P IN H ₂ O	METER TEMP DEG F	VELOCITY AFPS
1	255	0.10	0.80	118	22.24
2	255	0.25	0.80	118	35.17
3	255	0.10	0.80	118	22.24
4	255	0.10	0.80	118	22.24
5	255	0.10	0.80	118	22.24
6	255	0.30	0.80	122	38.53
7	255	0.25	0.80	122	35.17
8	255	0.10	0.80	122	22.24
9	255	0.15	0.80	122	27.24
10	255	0.15	0.80	122	27.24
11	255	1.60	0.80	125	88.97
12	255	1.50	0.80	125	86.15
13	255	1.50	0.80	125	86.15
14	255	1.80	0.80	125	94.37
15	255	1.60	0.80	125	88.97
16	255	2.00	0.80	128	99.48
17	255	2.10	0.80	128	101.93
18	255	2.30	0.80	128	106.68
19	255	2.20	0.80	128	104.33
20	255	2.10	0.80	128	101.93
21	255	2.40	0.80	130	108.97
22	255	2.20	0.80	130	104.33
23	255	2.30	0.80	130	106.68
24	255	2.10	0.80	130	101.93
25	255	2.20	0.80	130	104.33
AVERAGE	255		0.80	125	70.39
DRY STANDARD VOLUME		41.38	SCF		
		1.17	M3		
PERCENT WATER VAPOR		31.11	% VOL		
FLOW RATE		67576	ACFM		
		33268	DSCFM		
		56530	M3/HR		
SO ₂ CONCENTRATION		112.4	MG/M3		
SO ₂ EMISSION RATE		14.01	LB/HR		

PAYNE & DOLAN

29-Jul-99

CONTROL 34

TABLE 2-3

TEST NO.	3			
BAROMETRIC PRESSURE	29.05	IN HG		
TIP DIAMETER	0.245	IN		
STACK DIMENSIONS	48	IN	48	IN
STACK AREA	16.000	FT3		
SAMPLING TIME PER POINT	2.4	MIN		
NUMBER OF POINTS	25			
METER VOLUME	42.41	FT3		
PITOT COEFFICIENT	0.84			
METER COEFFICIENT	0.999			
SO2 COLLECTED	111.6	MG		
WATER COLLECTED	384	ML		
STATIC PRESSURE	-1.30	IN H2O		

CO2	O2	CO	N2
5.00%	10.80%	0.00%	84.20%

POINT	STACK TEMP DEG F	DELTA P IN H2O	ORIFICE DEL P IN H2O	METER TEMP DEG F	VELOCITY AFPS
1	260	0.10	0.80	142	22.28
2	260	0.15	0.80	142	27.29
3	260	0.20	0.80	142	31.51
4	260	0.10	0.80	142	22.28
5	260	0.10	0.80	142	22.28
6	260	0.35	0.80	140	41.69
7	260	0.25	0.80	140	35.23
8	260	0.10	0.80	140	22.28
9	260	0.15	0.80	140	27.29
10	260	0.15	0.80	140	27.29
11	260	1.50	0.80	140	86.30
12	260	1.50	0.80	140	86.30
13	260	1.60	0.80	140	89.13
14	260	1.80	0.80	140	94.54
15	260	1.60	0.80	140	89.13
16	260	2.10	0.80	140	102.11
17	260	2.10	0.80	140	102.11
18	260	2.20	0.80	140	104.51
19	260	2.20	0.80	140	104.51
20	260	2.20	0.80	140	104.51
21	260	2.40	0.80	141	109.16
22	260	2.40	0.80	141	109.16
23	260	2.20	0.80	141	104.51
24	260	2.20	0.80	141	104.51
25	260	2.10	0.80	141	102.11
AVERAGE	260		0.80	141	70.88

DRY STANDARD VOLUME	41.57	SCF
	1.18	M3
PERCENT WATER VAPOR	30.30	% VOL
FLOW RATE	68046	ACFM
	33656	DSCFM
	57188	M3/HR
SO2 CONCENTRATION	94.8	MG/M3
SO2 EMISSION RATE	11.95	LB/HR

PAYNE & DOLAN

6-Oct-99

CONTROL 34

TABLE 2-4

TEST NO.	1			
BAROMETRIC PRESSURE	29.05	IN HG		
TIP DIAMETER	0.245	IN		
STACK DIMENSIONS	48	IN	48	IN
STACK AREA	16.000	FT ²		
SAMPLING TIME PER POINT	2.4	MIN		
NUMBER OF POINTS	25			
METER VOLUME	3.03	FT ³		
PITOT COEFFICIENT	0.84			
METER COEFFICIENT	1.026			
HCl COLLECTED	0.0116	MG		
WATER COLLECTED	17.5	ML		
STATIC PRESSURE	-0.80	IN H ₂ O		
ORSAT RESULTS				
CO ₂	O ₂	CO	N ₂	
5.00%	10.80%	0.00%	84.20%	

POINT	STACK TEMP DEG F	DELTA P IN H ₂ O	ORIFICE DEL P IN H ₂ O	METER TEMP DEG F	VELOCITY AFPS
1	235	2.80	0.20	48	113.61
2	235	3.00	0.20	48	117.59
3	235	3.00	0.20	48	117.59
4	235	2.60	0.20	48	109.47
5	235	2.40	0.20	48	105.18
6	235	2.00	0.20	48	96.02
7	235	2.20	0.20	48	100.70
8	235	2.80	0.20	48	113.61
9	235	2.30	0.20	48	102.96
10	235	1.80	0.20	48	91.09
11	235	1.00	0.20	48	67.89
12	235	0.50	0.20	48	48.01
13	235	0.60	0.20	48	52.59
14	235	0.80	0.20	48	60.73
15	235	0.90	0.20	48	64.41
16	235	0.20	0.20	48	30.36
17	235	0.20	0.20	48	30.36
18	235	0.20	0.20	48	30.36
19	235	0.10	0.20	48	21.47
20	235	0.20	0.20	48	30.36
21	235	0.10	0.20	48	21.47
22	235	0.00	0.20	48	0.00
23	235	0.00	0.20	48	0.00
24	235	0.00	0.20	48	0.00
25	235	0.10	0.20	48	21.47
AVERAGE	235		0.20	48	61.89
DRY STANDARD VOLUME		3.01	SCF		
		0.09	M ³		
PERCENT WATER VAPOR		21.47	% VOL		
FLOW RATE		59417	ACFM		
		34346	DSCFM		
		58360	M ³ /HR		
HCl CONCENTRATION		0.136	MG/M ³		
HCl EMISSION RATE		0.017	LB/HR		

PAYNE & DOLAN

6-Oct-99

CONTROL 34

TABLE 2-5

TEST NO.	2				
BAROMETRIC PRESSURE	29.05	IN HG			
TIP DIAMETER	0.245	IN			
STACK DIMENSIONS	48	IN	48	IN	
STACK AREA	16.000	FT ²			
SAMPLING TIME PER POINT	2.4	MIN			
NUMBER OF POINTS	25				
METER VOLUME	3.31	FT ³			
PITOT COEFFICIENT	0.84				
METER COEFFICIENT	1.026				
HCl COLLECTED	0.0048	MG			
WATER COLLECTED	19	ML			
STATIC PRESSURE	-1.40	IN H ₂ O			
ORSAT RESULTS					
CO ₂		CO		N ₂	
5.00%	10.80%	0.00%		84.20%	

POINT	STACK TEMP DEG F	DELTA P IN H ₂ O	ORIFICE DEL P IN H ₂ O	METER TEMP DEG F	VELOCITY AFPS
1	242	3.10	0.20	52	120.20
2	242	3.20	0.20	52	122.13
3	242	3.20	0.20	52	122.13
4	242	2.90	0.20	52	116.26
5	242	2.70	0.20	52	112.18
6	242	2.40	0.20	52	105.76
7	242	2.90	0.20	52	116.26
8	242	3.20	0.20	52	122.13
9	242	2.80	0.20	52	114.24
10	242	2.20	0.20	52	101.26
11	242	1.50	0.20	52	83.61
12	242	1.20	0.20	52	74.79
13	242	2.00	0.20	52	96.55
14	242	1.70	0.20	52	89.01
15	242	1.10	0.20	52	71.60
16	242	0.20	0.20	52	30.53
17	242	0.20	0.20	52	30.53
18	242	0.20	0.20	52	30.53
19	242	0.30	0.20	52	37.39
20	242	0.30	0.20	52	37.39
21	242	0.10	0.20	52	21.59
22	242	0.00	0.20	52	0.00
23	242	0.00	0.20	52	0.00
24	242	0.00	0.20	52	0.00
25	242	0.10	0.20	52	21.59
AVERAGE	242		0.20	52	71.11
DRY STANDARD VOLUME		3.29	SCF		
		0.09	M ³		
PERCENT WATER VAPOR		21.36	% VOL		
FLOW RATE		68262	ACFM		
		39061	DSCFM		
		66373	M ³ /HR		
HCl CONCENTRATION		0.051	MG/M ³		
HCl EMISSION RATE		0.008	LB/HR		

PAYNE & DOLAN

6-Oct-99

CONTROL 34

TABLE 2-6

TEST NO.	3			
BAROMETRIC PRESSURE	29.05	IN HG		
TIP DIAMETER	0.245	IN		
STACK DIMENSIONS	48	IN	48	IN
STACK AREA	16.000	FT ²		
SAMPLING TIME PER POINT	2.4	MIN		
NUMBER OF POINTS	25			
METER VOLUME	3.31	FT ³		
PITOT COEFFICIENT	0.84			
METER COEFFICIENT	1.026			
HCl COLLECTED	0.0040	MG		
WATER COLLECTED	19.2	ML		
STATIC PRESSURE	-1.20	IN H ₂ O		

CO ₂	O ₂	CO	N ₂
5.00%	10.80%	0.00%	84.20%

POINT	STACK TEMP DEG F	DELTA P IN H ₂ O	ORIFICE DEL P IN H ₂ O	METER TEMP DEG F	VELOCITY AFPS
1	245	2.70	0.20	58	112.43
2	245	2.80	0.20	58	114.49
3	245	3.00	0.20	58	118.51
4	245	2.80	0.20	58	114.49
5	245	2.50	0.20	58	108.18
6	245	2.20	0.20	58	101.49
7	245	2.40	0.20	58	106.00
8	245	2.90	0.20	58	116.52
9	245	2.50	0.20	58	108.18
10	245	2.00	0.20	58	96.76
11	245	1.40	0.20	58	80.96
12	245	0.90	0.20	58	64.91
13	245	1.60	0.20	58	86.55
14	245	1.30	0.20	58	78.01
15	245	1.10	0.20	58	71.76
16	245	0.20	0.20	58	30.60
17	245	0.20	0.20	58	30.60
18	245	0.20	0.20	58	30.60
19	245	0.20	0.20	58	30.60
20	245	0.30	0.20	58	37.48
21	245	0.10	0.20	58	21.64
22	245	0.00	0.20	58	0.00
23	245	0.00	0.20	58	0.00
24	245	0.00	0.20	58	0.00
25	245	0.10	0.20	58	21.64
AVERAGE	245		0.20	58	67.30

DRY STANDARD VOLUME	3.29	SCF
	0.09	M ³
PERCENT WATER VAPOR	21.53	% VOL
FLOW RATE	64604	ACFM
	36752	DSCFM
	62450	M ³ /HR
HCl CONCENTRATION	0.043	MG/M ³
HCl EMISSION RATE	0.006	LB/HR

3.0 METHODS

3.1 Sulfur Dioxide

Samples were collected and analyzed in accordance with the procedures outlined in EPA Method 6 (40 FR, Part 60, Appendix A). The sampling train consisted of a heated stainless steel probe with a glass wool plug serving as a filter. A series of four impingers followed in an ice bath. The first impinger contained 100 milliliters (ml) of 80% isopropyl alcohol, the second and third each contained 100 ml of 3% hydrogen peroxide, and the fourth was dry to serve as a trap for carry-over of any liquid. This train separates out sulfuric acid and sulfur trioxide in the first impinger and sulfur dioxide is collected in the second and third impingers. The gas then passed through a water trap and silica gel tube to trap all water vapor prior to the sampling pump and dry gas meter. A schematic of the sampling train is included as Figure 3-2.

The principle of the method was to collect a representative sample of the exhaust gas stream by placing the probe at a single point in the duct and sampling for a 60 minute period at a nominal sampling rate of 0.7 cubic feet per minute. At the completion of each test, a leak check was performed and ambient air was purged through the sampling train for approximately 15 minutes.

The first impinger contents were then discarded while the second and third impinger contents were combined along with the washings from the connected tubing. Aliquots of this solution were diluted with known quantities of isopropyl alcohol and titrated with barium perchlorate using thorin indicator. From the quantity of titrant required, the weight of sulfur dioxide was calculated. This information was combined with the volume of gas sampled to determine the sulfur dioxide concentration. The emission rates were then calculated using these concentrations and the volumetric flow rate.




FIGURE - 1 SO₂ SAMPLING TRAIN

3 - 1 HLR TESTS

3.2 Hydrogen Chloride

Samples were collected and analyzed in accordance with the procedures outlined in EPA Method 26 (40 FR, Part 60, Appendix A). The sampling train consisted of a heated glass probe followed by a heated filter. A series of five midget impingers followed in an ice bath. The first two impingers contained 15 milliliters (ml) of 0.1 N sulfuric acid, the third and fourth each contained 15 ml of 0.1 N sodium hydroxide, and the fifth contained silica gel to remove moisture. The gas then passed through a sampling pump and dry gas meter. A schematic of the sampling train is included as Figure 3-3.


The principle of the method was to collect a representative sample of the exhaust gas stream by placing the probe at a single point in the duct and sampling for a 60 minute period at a nominal sampling rate of about 1.5 liters per minute. At the completion of each test, a leak check was performed and ambient air was purged through the sampling train for approximately 15 minutes.

The first two impinger contents were then analyzed for hydrogen chloride content by ion chromatography. The analysis was performed at DAT, Inc. The laboratory information was combined with the volume of gas sampled to determine the HCl concentration. The emission rates were then calculated using these concentrations and the volumetric flowrate.

4.0 CALIBRATIONS

A dry gas meter was used to determine the sample volume obtained in the SO₂ and HCl tests. These dry gas meters were calibrated with a wet test meter. The values obtained were:

Sulfur Dioxide Meter	0.999
Hydrogen Chloride Meter	1.026



MIDGET IMPINGER SAMPLING TRAIN
FOR HCl

3. 1 MC TESTS


APPENDIX A

Field and Laboratory Data

PARTICULATE FILE'D DATA

Environments,
Technology
Engineering Corp.

PLANT	Plant 1 Duluth	AMBIENT TEMPERATURE	65°F
DATE	7-29-99	BAROMETRIC PRESSURE	29.99
LOCATION	Duluth	ASSUMED MOISTURE, %	28
OPERATOR	WJD	PROBE LENGTH, in.	10
STACK NO.	Centrif. 34	NOZZLE DIAMETER, in.	1/8
RUN NO.	3	STACK DIAMETER, in.	4 1/2
SAMPLE BOX NO.	3	PROBE HEATER SETTING	750
METER BOX NO.	2	HEATER BOX SETTING	750
METER A.H.		ORSAT RESULTS	
C FACTOR		CO2	
		O2	
		CO	
		N2	
		LE	
		PI	
		PO	
		PI	



CROSS SECTION

ASSUMED MOISTURE, %	PROBE LENGTH, in.	NOZZLE DIAMETER, in.	STACK DIAMETER, in.	PROCESS WEIGHT RATE	ORSAT RESULTS	LEAK CHECKS
20	11/16	4.87 x 1.13	7.75	100	CO2 _____ O2 _____ CO _____ N2 _____	Pre Pitot _____ Post Pitot _____ Pitot _____
						Pre Pitot _____ Post Pitot _____ Pitot _____
						Pre Pitot _____ Post Pitot _____ Pitot _____

PROBE HEATER SETTING 250 HEATER BOX SETTING 250

Plant Name: T. D c 34

ASPHALT PLANT STACK TEST DATA

Date: July 29, 1999
FID #: 999117520

Time*	Burner Setting	PSV Fuel Psetting	Production TPH	Aggregate TPH	% Moisture in Aggregate	RAP% TPH	Mix Temp	Stack Temp	Photo-helic	Magne-helic	Fuel Flow Rate	PPM	PPM
11:00	4.5		260	210	3.7	15	315	306	.75	.5	8		
11:15	6		270	215	3.7	15	305	310	.75	5	8		
11:30	6		268	220	3.7	15	300	318	.75	5	8		
11:45	6.25		275	235	3.7	15	30.3	322	.75	5	7		
12:00	6.5		276	227	3.7	15	303	322	.75	5	7		
12:15	6		270	221	3.7	15	311	324	.75	5	8		
12:30	6		273	224	3.7	15	303	322	.75	5	9		
12:45	5 1/2		277	221	3.7	15	298	318	.75	5	8		
13:00	5 1/2		275	225	3.7	15	301	319	.75	4.75	7		
13:15	5 1/2		276	223	3.7	15	301	321	.75	4.75	8		
13:30	5 1/2		279	227	3.7	15	302	318	.75	4.75	8		
13:45	5 1/2		275	226	3.7	15	308	320	.75	4.75	7		
14:00	5 1/2		271	223	3.7	15	303	323	.75	4.75	8		
14:15	5 1/2		273	221	3.7	15	310	325	.75	4.75	8		

卷之三

829 pm Hodgey's 2010-04-06

- Record data in 15-17

S. J. Rungs.

$$X = 2.7 \text{ g/mm}^2 \text{min} = 462.6 \text{ g/mm}^2$$



Payne & Dolan of Wisc., Inc.
 Attn: Peter Tolsmo
 P.O. Box 781
 Waukesha, WI 53186

A Subsidiary of Sommer-Frey Laboratories, Inc.

Received Date: 10/6/99
 Report Date: 10/07/1999

- Analytical Results -

Test	Result	Units	MDL	Analysis Date	By	Method
Lab #: 99B01621-001	Sample ID:	C34 Oil	10/06/99			
BTU	138000	BTU/Gal	100	10/07/1999	GGG	D240
Sulfur	0.43	% wt	0.04	10/07/1999	GGG	D129
Total Halogens as Cl	513	mg/Kg	100	10/07/1999	GGG	D808
Gravity	0.8789			10/07/1999	GGG	D1298
Arsenic	1.0	mg/Kg	0.5	10/07/1999	GGG	6010B
Antimony	17.2	mg/Kg		10/07/1999	GGG	
Cadmium Oil	0.6	mg/Kg	0.1	10/07/1999	GGG	6010B
Chromium Oil	1.6	mg/Kg	0.1	10/07/1999	GGG	6010B
Lead in Oil	27.3	mg/Kg	0.1	10/07/1999	GGG	6010B


 Gary G. Geipel
 Senior Analyst

6125 West National Avenue, P.O. Box 14513, Milwaukee, Wisconsin 53214
 (414) 475-6700 FAX: (414) 475-7216
 Toll-Free: 800-300-6700

• Dept. of Health State Certified Laboratory #168 • Dept. of Natural Resources State Certified Laboratory #241249360 •
 • USDA Accredited Laboratory #5581 • NIOSH Proficiency Analytical Testing Program •

PAYNE & DOLAN
CONTROL 34 PLANT
SO2 LAB RESULTS

Sample no.	Vol. Solution ml	Vol. Aliq. ml	Vol. Titrant ml	Vol. Tit. Bl. ml	N. Titrant	mg. SO2
1	560.0	5.0	3.50	0.05	0.0095	117.6
2	601.0	5.0	3.65	0.05	0.0095	131.7
3	573.0	5.0	3.25	0.05	0.0095	111.6

PAYNE & DOLAN CONTROL 34
DRUM MIX PLANT
HYDROGEN CHLORIDE RESULTS

TABLE 2-4

Sample No.	Meter Vol. ft ³	Meter Temp deg F	Standard Vol liters	HCl Captured ug	HCl Conc mg/m ³	Flow Rate m ³ /hr	HCl ER lb/hr	Production Rate TPH	Emission Factor lb/ton
C34-1	3.03	48	88.85	11.6	0.131	59417	0.017	245	0.00007
C34-2	3.31	52	96.30	4.8	0.050	68262	0.008	290	0.00003
C34-3	3.31	58	95.18	4.0	0.042	64604	0.006	290	0.00002
AVERAGE									0.00004

Meter Gama
Bar.Pressure

1.026
29.05

Calculations

Standard Volume = Meter Vol * Meter Gama*Bar.Pressure*28.32*528/(29.92*(460+Meter Temp))

Concentration = ug/liters = mg/m³

Emission Rate = mg/m³ * m³/hr/453600