

**AP42 Section: 11.1**

**Reference Number: 50**

**Title: Test Report For Air Pollution Source Testing At Macasphalt,  
Cross City, Florida,  
  
Ramcon Environmental Corporation, Memphis, TN,  
  
December 7-9, 1992.**

# RAMCON

ENVIRONMENTAL CORPORATION

Test Report for Air Pollution Source Testing

at

**MACASPHALT  
CROSS CITY, FLORIDA**

and

**NATIONAL ASPHALT PAVEMENT ASSOCIATION  
5100 FORBES BLVD., NAPA BUILDING  
LANHAM, MARYLAND**

submitted by:

**RAMCON ENVIRONMENTAL CORPORATION  
6707 FLETCHER CREEK COVE  
MEMPHIS, TENNESSEE 38133**

December 7-9, 1992

\_\_\_\_\_  
Mr. Tom Brumagin  
National Asphalt Pavement  
Association

\_\_\_\_\_  
  
William Joseph Sewell, II  
Vice President

## TABLE OF CONTENTS

|       |                                                                         |     |
|-------|-------------------------------------------------------------------------|-----|
| I.    | INTRODUCTION .....                                                      | 1   |
| II.   | TEST RESULTS .....                                                      | 2   |
| III.  | SAMPLING AND ANALYTICAL PROCEDURES .....                                | 8   |
| IV.   | SOURCE INFORMATION .....                                                | 22  |
| V.    | EQUIPMENT USED .....                                                    | 23  |
| VI.   | CALCULATIONS                                                            |     |
|       | A. Particulate — Condensibles .....                                     | 30  |
|       | B. Formaldehyde .....                                                   | 45  |
|       | C. PAH .....                                                            | 53  |
|       | D. SO <sub>2</sub> , THC, CO, NO <sub>x</sub> and CH <sub>4</sub> ..... | 69  |
| VII.  | LABORATORY ANALYSIS RESULTS                                             |     |
|       | A. Formaldehyde Analysis Results .....                                  | 79  |
|       | B. PAH Analysis Results .....                                           | 80  |
|       | C. Particulate Analysis Results .....                                   | 157 |
|       | D. Fuel Analysis Results .....                                          | 159 |
| VIII. | EQUIPMENT CALIBRATION DATA                                              |     |
|       | A. GC CALIBRATION DATA .....                                            | 162 |
|       | B. CEMS CALIBRATION DATA .....                                          | 177 |
|       | C. PARTICULATE CALIBRATION DATA .....                                   | 190 |
| IX.   | FIELD DATA                                                              |     |
|       | A. CEMS .....                                                           | 199 |
|       | B. GAS CHROMATOGRAPHY .....                                             | 256 |
|       | C. PAH .....                                                            | 265 |
|       | D. PARTICULATE .....                                                    | 271 |
|       | E. FORMALDEHYDE .....                                                   | 277 |
| X.    | PLANT OPERATING DATA .....                                              | 283 |
| XI.   | RAMCON PERSONNEL .....                                                  | 289 |

Additionally stack gas moisture, velocity, and volumetric flow rate were determined to provide data enabling conversion of flue gas concentrations to emission data. These determinations were conducted in conjunction with each of the isokinetic testing procedures.

Where possible, the testing was conducted simultaneously. This provides correlations of the various stack effluents relationships with one another. Three (3) test runs were conducted for each isokinetic testing procedure. Eleven test runs were conducted utilizing the CEM instrumental procedures for  $\text{SO}_2$ , CO, THC,  $\text{NO}_x$ ,  $\text{CO}_2$ , and  $\text{O}_2$ . Nine (9) test periods were conducted for the semi-continuous GC procedure.

The purpose of the testing project was to provide air emissions information for developing a database of information using various types of hot mix asphalt plants.

Mr. Thomas E. Brumagin representing the National Asphalt Pavement Association was present during the testing procedure(s) conducted by RAMCON Environmental Corporation.

## II. TEST RESULTS

The test results are summarized in Tables I through III. Each summary table represents the test results for particulate, formaldehyde, and PAH's respectively. The gaseous pollutants of interest, THC,  $\text{SO}_2$ ,  $\text{CO}_2$ , CO,  $\text{NO}_x$ ,  $\text{O}_2$ ,  $\text{CH}_4$ , and BTEX, test results are listed in each summary table. The test results for these gaseous compounds listed on each summary table were correlated to the isokinetic tests according to date and times. This provides a direct comparison of the test data for a specific targeted pollutant to other operational and emission data.

The summary tables provide the test results in concentration values of milligrams per dry standard cubic meter (mg/dscm) and parts per million (ppm), volume basis. The emission values of all targeted compounds are listed in pounds per hour (lb/hr).



## I. INTRODUCTION

On December 7, 8, & 9, 1992, personnel from RAMCON Environmental Corporation conducted source emissions determinations at Macasphalt located in Perry, Florida. The testing was conducted according to the National Asphalt Pavement Association (NAPA) guidelines entitled, "Protocol for Air Pollution Source Testing".

The scope of work involved testing this facility for filterable and condensible particulate matter, formaldehyde, and polynuclear aromatic hydrocarbons. These compounds were sampled according to specified isokinetic testing procedures. Reference Method 202 was employed for the particulate matter including condensibles. Method 0011/8315 issued in SW-846 was utilized for the formaldehyde extraction, collection, and analysis. The polynuclear aromatic hydrocarbons were sampled using Modified Method 5.

In addition, "real-time" continuous emission monitor (CEM) instrumentation was utilized to conduct on-site analysis for oxygen, carbon dioxide, total volatile organics, sulfur dioxide, carbon monoxide, and  $\text{NO}_x$ . Reference Methods 3A, 6C, 7E, 10, and 25A were employed for the analysis of oxygen and carbon dioxide, sulfur dioxide, nitrogen oxides, carbon monoxide, and total hydrocarbons respectively. These testing procedures utilize a sampling system to continuously extract sample gas from the source. This sample stream is routed to individual CEM's for analysis of the various targeted pollutants and diluent gases. The test results are based on the average value of one minute averages generated by the CEM instrument data acquisition during the test periods.

Methane, benzene, toluene, ethyl benzene, and xylene compounds were analyzed on a semi-continuous basis by employing a gas chromatograph to the sampling location. Reference Method 18 was used for these determinations. The gas stream is continuously sampled during the testing period(s). Periodically, a sample of the extracted gas stream is injected into the gas chromatograph for analysis. The test results are based on the average value of the injections performed during each test period.

The SO<sub>2</sub> instrument failed in its operation during the performance test. Sulfur dioxide results are provided for particulate and PAH sampling, however the formaldehyde summary table does not include SO<sub>2</sub> results.

TABLE I - Summary of Results

| Test Performed:<br>Run No.:<br>Date:<br>Time:<br>Production Rate:<br>Amount of RAP: | Part.<br>1<br>12-07-92<br>1259-1403<br>198 | Part.<br>2<br>12-07-92<br>1452-1607<br>208 | Part.<br>3<br>12-08-92<br>0830-1024<br>181 | Part.<br>Average<br>tph<br>% | Part.<br>1<br>12-07-92<br>1259-1403<br>198 | Part.<br>2<br>12-07-92<br>1452-1607<br>208 | Part.<br>3<br>12-08-92<br>0830-1024<br>181 | Part.<br>Average<br>tph<br>% | Part.<br>1<br>12-07-92<br>1259-1403<br>198 | Part.<br>2<br>12-07-92<br>1452-1607<br>208 | Part.<br>3<br>12-08-92<br>0830-1024<br>181 | Part.<br>Average<br>tph<br>% |
|-------------------------------------------------------------------------------------|--------------------------------------------|--------------------------------------------|--------------------------------------------|------------------------------|--------------------------------------------|--------------------------------------------|--------------------------------------------|------------------------------|--------------------------------------------|--------------------------------------------|--------------------------------------------|------------------------------|
| Volumetric Flow Rate (acfm)                                                         | 53479                                      | 57827                                      | 60079                                      | 57128                        | 53479                                      | 57827                                      | 60079                                      | 57128                        | 53479                                      | 57827                                      | 60079                                      | 57128                        |
| Volumetric Flow Rate (dscfm)                                                        | 20962                                      | 24641                                      | 28678                                      | 24760                        | 20962                                      | 24641                                      | 28678                                      | 24760                        | 20962                                      | 24641                                      | 28678                                      | 24760                        |
| Stack Temperature (°F)                                                              | 410                                        | 356                                        | 341                                        | 369                          | 410                                        | 356                                        | 341                                        | 369                          | 410                                        | 356                                        | 341                                        | 369                          |
| Percent Moisture                                                                    | 35.80                                      | 34.54                                      | 27.97                                      | 32.77                        | 35.80                                      | 34.54                                      | 27.97                                      | 32.77                        | 35.80                                      | 34.54                                      | 27.97                                      | 32.77                        |
| % CO <sub>2</sub>                                                                   | 8.6                                        | 7.0                                        | 5.5                                        | 7.0                          | 8.6                                        | 7.0                                        | 5.5                                        | 7.0                          | 8.6                                        | 7.0                                        | 5.5                                        | 7.0                          |
| % O <sub>2</sub>                                                                    | 11.0                                       | 11.7                                       | 13.0                                       | 11.9                         | 11.0                                       | 11.7                                       | 13.0                                       | 11.9                         | 11.0                                       | 11.7                                       | 13.0                                       | 11.9                         |
| % CO                                                                                | >0.1                                       | >0.1                                       | >0.1                                       | >0.1                         | >0.1                                       | >0.1                                       | >0.1                                       | >0.1                         | >0.1                                       | >0.1                                       | >0.1                                       | >0.1                         |
| % Excess Air                                                                        | 106.8                                      | 119.0                                      | 151.6                                      | 125.8                        | 106.8                                      | 119.0                                      | 151.6                                      | 125.8                        | 106.8                                      | 119.0                                      | 151.6                                      | 125.8                        |
|                                                                                     | mg/m <sup>3</sup>                          |                                            |                                            |                              | ppm                                        |                                            |                                            |                              | lbs/hr                                     |                                            |                                            |                              |
| CO                                                                                  | >1165.1                                    | >1165.1                                    | >1165.1                                    | >1165.1                      | >1000                                      | >1000                                      | >1000                                      | >1000                        | >91.2                                      | >107.3                                     | >124.8                                     | >107.8                       |
| SO <sub>2</sub>                                                                     | 16.8                                       | 18.9                                       | 28.8                                       | 21.5                         | 6.3                                        | 7.1                                        | 10.8                                       | 8.1                          | 1.31                                       | 1.74                                       | 3.08                                       | 2.0                          |
| NO <sub>x</sub>                                                                     | 226.2                                      | 148.5                                      | 155.0                                      | 176.6                        | 118.2                                      | 77.6                                       | 81.0                                       | 92.3                         | 17.72                                      | 13.67                                      | 16.61                                      | 16.00                        |
| Total Hydrocarbon (as CH <sub>4</sub> )                                             | 65.7                                       | 85.4                                       | 92.6                                       | 81.2                         | 98.4                                       | 128.0                                      | 138.8                                      | 121.7                        | 5.14                                       | 7.86                                       | 9.92                                       | 7.64                         |
| Methane                                                                             | 12.82                                      | 21.06                                      | 29.44                                      | 21.11                        | 19.21                                      | 31.56                                      | 44.13                                      | 31.63                        | 1.00                                       | 1.94                                       | 3.15                                       | 2.03                         |
| Benzene                                                                             | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Toluene                                                                             | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Ethyl Benzene                                                                       | 1.59                                       | BDL                                        | BDL                                        | 0.53                         | 0.36                                       | BDL                                        | BDL                                        | 0.12                         | 0.12                                       | BDL                                        | BDL                                        | 0.04                         |
| Xylene                                                                              | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Particulate Matter                                                                  | 6.88                                       | 7.57                                       | 4.59                                       | 6.35                         | N/A                                        | N/A                                        | N/A                                        | N/A                          | 0.54                                       | 0.70                                       | 0.49                                       | 0.58                         |
| Condensable Particulate                                                             | 58.01                                      | 37.60                                      | 29.58                                      | 41.73                        | N/A                                        | N/A                                        | N/A                                        | N/A                          | 4.55                                       | 3.46                                       | 3.17                                       | 3.73                         |

TABLE II — Summary of Results

| Test Performed:<br>Run No.:<br>Date:<br>Time:<br>Production Rate:<br>Amount of RAP: | Form.<br>1<br>12-09-92<br>1248-1353<br>194 | Form.<br>2<br>12-09-92<br>1424-1534<br>214 | Form.<br>3<br>12-09-92<br>1611-1706<br>222 | Form.<br>Average<br>tph<br>% | Form.<br>1<br>12-09-92<br>1248-1353<br>194 | Form.<br>2<br>12-09-92<br>1424-1534<br>214 | Form.<br>3<br>12-09-92<br>1611-1706<br>222 | Form.<br>Average<br>tph<br>% | Form.<br>1<br>12-09-92<br>1248-1353<br>194 | Form.<br>2<br>12-09-92<br>1424-1534<br>214 | Form.<br>3<br>12-09-92<br>1611-1706<br>222 | Form.<br>Average<br>tph<br>% |
|-------------------------------------------------------------------------------------|--------------------------------------------|--------------------------------------------|--------------------------------------------|------------------------------|--------------------------------------------|--------------------------------------------|--------------------------------------------|------------------------------|--------------------------------------------|--------------------------------------------|--------------------------------------------|------------------------------|
| Volumetric Flow Rate (acfm)                                                         | 54532                                      | 53115                                      | 52891                                      | 53513                        | 54532                                      | 53115                                      | 52891                                      | 53513                        | 54532                                      | 53115                                      | 52891                                      | 53513                        |
| Volumetric Flow Rate (dscfm)                                                        | 28810                                      | 26682                                      | 24521                                      | 26671                        | 28810                                      | 26682                                      | 24521                                      | 26671                        | 28810                                      | 26682                                      | 24521                                      | 26671                        |
| Stack Temperature (°F)                                                              | 267                                        | 276                                        | 336                                        | 293                          | 267                                        | 276                                        | 336                                        | 293                          | 267                                        | 276                                        | 336                                        | 293                          |
| Percent Moisture                                                                    | 27.74                                      | 30.44                                      | 30.57                                      | 29.58                        | 27.74                                      | 30.44                                      | 30.57                                      | 29.58                        | 27.74                                      | 30.44                                      | 30.57                                      | 29.58                        |
| % CO <sub>2</sub>                                                                   | 6.5                                        | 7.2                                        | 8.0                                        | 7.233                        | 6.5                                        | 7.2                                        | 8.0                                        | 7.233                        | 6.5                                        | 7.2                                        | 8.0                                        | 7.233                        |
| % O <sub>2</sub>                                                                    | 12.6                                       | 11.7                                       | 10.5                                       | 11.6                         | 12.6                                       | 11.7                                       | 10.5                                       | 11.6                         | 12.6                                       | 11.7                                       | 10.5                                       | 11.6                         |
| % CO                                                                                | >0.1                                       | >0.1                                       | >0.1                                       | >0.1                         | >0.1                                       | >0.1                                       | >0.1                                       | >0.1                         | >0.1                                       | >0.1                                       | >0.1                                       | >0.1                         |
| % Excess Air                                                                        | 142.9                                      | 119.7                                      | 94.7                                       | 119.1                        | 142.9                                      | 119.7                                      | 94.7                                       | 119.1                        | 142.9                                      | 119.7                                      | 94.7                                       | 119.1                        |
|                                                                                     | mg/m <sup>3</sup>                          |                                            |                                            |                              | ppm <sub>v</sub>                           |                                            |                                            |                              | lbs/hr                                     |                                            |                                            |                              |
| CO                                                                                  | >1165.1                                    | >1165.1                                    | >1165.1                                    | >1165.1                      | >1000                                      | >1000                                      | >1000                                      | >1000                        | >125.4                                     | >116.1                                     | >106.7                                     | >116.7                       |
| SO <sub>2</sub>                                                                     | —                                          | —                                          | —                                          | —                            | —                                          | —                                          | —                                          | —                            | —                                          | —                                          | —                                          | —                            |
| NO <sub>x</sub>                                                                     | 151.6                                      | 158.3                                      | 150.2                                      | 153.4                        | 79.2                                       | 82.7                                       | 78.5                                       | 80.1                         | 16.31                                      | 15.78                                      | 13.76                                      | 15.28                        |
| Total Hydrocarbon (as CH <sub>4</sub> )                                             | 83.0                                       | 67.1                                       | 79.5                                       | 76.5                         | 124.4                                      | 100.5                                      | 119.1                                      | 114.7                        | 8.93                                       | 6.68                                       | 7.28                                       | 7.63                         |
| Methane                                                                             | 27.0                                       | 24.0                                       | 49.3                                       | 33.4                         | 40.53                                      | 35.94                                      | 73.84                                      | 50.10                        | 2.91                                       | 2.39                                       | 4.51                                       | 3.27                         |
| Benzene                                                                             | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Toluene                                                                             | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Ethyl Benzene                                                                       | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Xylene                                                                              | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          | BDL                                        | BDL                                        | BDL                                        | BDL                          |
| Formaldehyde                                                                        | 5.96                                       | 5.73                                       | 5.27                                       | 5.65                         | 4.78                                       | 4.61                                       | 4.20                                       | 4.53                         | 0.64                                       | 0.57                                       | 0.48                                       | 0.56                         |

TABLE III-A — Summary of Results

| Test Performed:<br>Run No.:<br>Date:<br>Time:<br>Production Rate:<br>Amount of RAP: | PAH<br>1<br>12-08-92<br>1124-1237<br>185 | PAH<br>2<br>12-08-92<br>1334-1711<br>188 | PAH<br>3<br>12-09-92<br>0946-1216<br>182 | PAH<br>Average<br>tph<br>% | PAH<br>1<br>12-08-92<br>1124-1237<br>185 | PAH<br>2<br>12-08-92<br>1334-1711<br>188 | PAH<br>3<br>12-09-92<br>0946-1216<br>182 | PAH<br>Average<br>tph<br>% | PAH<br>1<br>12-08-92<br>1124-1237<br>185 | PAH<br>2<br>12-08-92<br>1334-1711<br>188 | PAH<br>3<br>12-09-92<br>0946-1216<br>182 | PAH<br>Average<br>tph<br>% |
|-------------------------------------------------------------------------------------|------------------------------------------|------------------------------------------|------------------------------------------|----------------------------|------------------------------------------|------------------------------------------|------------------------------------------|----------------------------|------------------------------------------|------------------------------------------|------------------------------------------|----------------------------|
|                                                                                     | 54857                                    | 53521                                    | 53657                                    | 54011                      | 54857                                    | 53521                                    | 53657                                    | 54011                      | 54857                                    | 53521                                    | 53657                                    | 54011                      |
| Volumetric Flow Rate (acfm)                                                         | 28779                                    | 28057                                    | 28391                                    | 28409                      | 28779                                    | 28057                                    | 28391                                    | 28409                      | 28779                                    | 28057                                    | 28391                                    | 28409                      |
| Volumetric Flow Rate (dscfm)                                                        | 259                                      | 264                                      | 270                                      | 264                        | 259                                      | 264                                      | 270                                      | 264                        | 259                                      | 264                                      | 270                                      | 264                        |
| Stack Temperature (°F)                                                              | 28.94                                    | 28.50                                    | 27.33                                    | 28.26                      | 28.94                                    | 28.50                                    | 27.33                                    | 28.26                      | 28.94                                    | 28.50                                    | 27.33                                    | 28.26                      |
| Percent Moisture                                                                    | 6.6                                      | 7.1                                      | 6.5                                      | 6.7333                     | 6.6                                      | 7.1                                      | 6.5                                      | 6.7333                     | 6.6                                      | 7.1                                      | 6.5                                      | 6.7333                     |
| % CO <sub>2</sub>                                                                   | 12.8                                     | 13.3                                     | 12.8                                     | 13.0                       | 12.8                                     | 13.3                                     | 12.8                                     | 13.0                       | 12.8                                     | 13.3                                     | 12.8                                     | 13.0                       |
| % O <sub>2</sub>                                                                    | >0.1                                     | >0.1                                     | >0.1                                     | >0.1                       | >0.1                                     | >0.1                                     | >0.1                                     | >0.1                       | >0.1                                     | >0.1                                     | >0.1                                     | >0.1                       |
| % CO                                                                                | 150.0                                    | 171.2                                    | 149.5                                    | 156.9                      | 150.0                                    | 171.2                                    | 149.5                                    | 156.9                      | 150.0                                    | 171.2                                    | 149.5                                    | 156.90                     |
| % Excess Air                                                                        | mg/m <sup>3</sup>                        |                                          |                                          |                            |                                          |                                          |                                          |                            |                                          |                                          |                                          |                            |
|                                                                                     | >1165.1                                  | >1165.1                                  | >1165.1                                  | >1165.1                    | >1000                                    | >1000                                    | >1000                                    | >1000                      | >125.3                                   | >122.1                                   | >123.6                                   | >123.7                     |
| CO                                                                                  | 18.12                                    | 20.25                                    | —                                        | 19.19                      | 6.8                                      | 7.6                                      | —                                        | 7.2                        | 1.95                                     | 2.12                                     | —                                        | 2.04                       |
| SO <sub>2</sub>                                                                     | 168.0                                    | 158.8                                    | 136.1                                    | 154.3                      | 87.8                                     | 83.0                                     | 71.1                                     | 80.6                       | 18.07                                    | 16.65                                    | 14.43                                    | 16.38                      |
| NO <sub>x</sub>                                                                     | 73.79                                    | 59.18                                    | 81.13                                    | 71.37                      | 110.6                                    | 88.7                                     | 121.6                                    | 107.0                      | 7.93                                     | 6.20                                     | 8.61                                     | 7.58                       |
| Total Hydrocarbon (as CH <sub>4</sub> )                                             | 30.40                                    | 24.42                                    | 29.92                                    | 28.2467                    | 45.57                                    | 36.60                                    | 44.85                                    | 42.34                      | 3.27                                     | 2.56                                     | 3.17                                     | 3.0000                     |
| Methane                                                                             | BDL                                      | 1.40                                     | BDL                                      | 0.4667                     | BDL                                      | 0.43                                     | BDL                                      | 0.1433                     | BDL                                      | 0.15                                     | BDL                                      | 0.0500                     |
| Benzene                                                                             | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Toluene                                                                             | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Ethyl Benzene                                                                       | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Xylene                                                                              | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |

TABLE III-B - Summary of Results

| Test Performed:<br>Run No.:<br>Date:<br>Time:<br>Production Rate:<br>Amount of RAP: | mg/m <sup>3</sup>                        |                                          |                                          |                            | ppm                                      |                                          |                                          |                            | lbs/hr                                   |                                          |                                          |                            |
|-------------------------------------------------------------------------------------|------------------------------------------|------------------------------------------|------------------------------------------|----------------------------|------------------------------------------|------------------------------------------|------------------------------------------|----------------------------|------------------------------------------|------------------------------------------|------------------------------------------|----------------------------|
| PAH's                                                                               | PAH<br>1<br>12-08-92<br>1124-1237<br>185 | PAH<br>2<br>12-08-92<br>1334-1711<br>188 | PAH<br>3<br>12-09-92<br>0946-1216<br>182 | PAH<br>Average<br>tph<br>% | PAH<br>1<br>12-08-92<br>1124-1237<br>185 | PAH<br>2<br>12-08-92<br>1334-1711<br>188 | PAH<br>3<br>12-09-92<br>0946-1216<br>182 | PAH<br>Average<br>tph<br>% | PAH<br>1<br>12-08-92<br>1124-1237<br>185 | PAH<br>2<br>12-08-92<br>1334-1711<br>188 | PAH<br>3<br>12-09-92<br>0946-1216<br>182 | PAH<br>Average<br>tph<br>% |
| Naphthalene                                                                         | 0.2493                                   | 0.2590                                   | 0.2909                                   | 0.0632                     | 0.0468                                   | 0.0486                                   | 0.0547                                   | 0.0119                     | 0.0268                                   | 0.0271                                   | 0.0309                                   | 0.0283<br>0.0066           |
| 2-Methylnaphthalene                                                                 | 0.2882                                   | 0.2969                                   | 0.3016                                   | 0.0843                     | 0.0488                                   | 0.0503                                   | 0.0511                                   | 0.0143                     | 0.0310                                   | 0.0311                                   | 0.0320                                   | 0.0314<br>0.0088           |
| 2-Chloronaphthalene                                                                 | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Acenaphthylene                                                                      | 0.0346                                   | 0.0339                                   | 0.0469                                   | 0.0385                     | 0.0055                                   | 0.0054                                   | 0.0074                                   | 0.0061                     | 0.0037                                   | 0.0036                                   | 0.0050                                   | 0.0041                     |
| Fluorene                                                                            | 0.0286                                   | 0.0290                                   | 0.0327                                   | 0.0301                     | 0.0041                                   | 0.0042                                   | 0.0047                                   | 0.0043                     | 0.0030                                   | 0.0030                                   | 0.0034                                   | 0.0031                     |
| Phenanthrene                                                                        | 0.0909                                   | 0.0926                                   | 0.1033                                   | 0.0956                     | 0.0123                                   | 0.0125                                   | 0.0140                                   | 0.0129                     | 0.0098                                   | 0.0097                                   | 0.0110                                   | 0.0102                     |
| Anthracene                                                                          | 0.0059                                   | 0.0060                                   | 0.0076                                   | 0.0065                     | 0.0008                                   | 0.0008                                   | 0.0010                                   | 0.0009                     | 0.0006                                   | 0.0006                                   | 0.0008                                   | 0.0007                     |
| Fluoranthene                                                                        | BDL                                      | BDL                                      | 0.0072                                   | 0.0024                     | BDL                                      | BDL                                      | 0.0009                                   | 0.0003                     | BDL                                      | BDL                                      | 0.0008                                   | 0.0003                     |
| Pyrene                                                                              | BDL                                      | 0.0035                                   | 0.0064                                   | 0.0033                     | BDL                                      | 0.0004                                   | 0.0008                                   | 0.0094                     | BDL                                      | 0.0004                                   | 0.0007                                   | 0.0004<br>(0.0083)         |
| Benzo(a)anthracene                                                                  | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Chrysene                                                                            | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Benzo(b)fluoranthene                                                                | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Benzo(k)fluoranthene                                                                | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Benzo(e)pyrene                                                                      | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Benzo(a)pyrene                                                                      | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Perylene                                                                            | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Indeno(1,2,3-cd)pyrene                                                              | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Dibenz(a,h)anthracene                                                               | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Benzo(g,h,i)perylene                                                                | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        | BDL                                      | BDL                                      | BDL                                      | BDL                        |
| Total PAH's                                                                         | 0.6975                                   | 0.7209                                   | 0.7966                                   | 0.3239                     | 0.1183                                   | 0.1222                                   | 0.1346                                   | 0.0601                     | 0.0749                                   | 0.0755                                   | 0.0846                                   | 0.0421                     |

0.0783

### III. SAMPLING & ANALYTICAL PROCEDURES

The following is a description of each of the test methods that were conducted during the performance test(s). In this description, a discussion of the pertinent segments including preparation, sampling, and analysis is addressed. This section will provide information supporting the validity of the samples.

#### A. Determination of Carbon Dioxide and Oxygen Emissions From Stationary Sources (Instrumental Analyzer Procedure) - US EPA Method 3A:

The collection and analysis of carbon dioxide and oxygen content at the test location was performed by US EPA Reference Method 3A. This procedure utilizes continuous emissions monitors that provide the data results from the source on a "real-time" or instantaneous basis.

All of the CEM instrumental procedures that were conducted at the outlet testing location were extracted and analyzed with similar testing strategies. Because of this similarity, a detailed description of the calibration and operation procedures of the CEM procedures is provided in the discussion of Method 3A and is referred to in the other sections concerning the additional procedures.

##### 1. Calibration.

The calibration of the instruments is performed using certified gas standards composed of a known concentration of carbon dioxide and oxygen in zero grade nitrogen. These gas standards are prepared using partial pressure/volumetric and gravimetric methods.

The prepared gas mixture is analyzed and the certification tolerance is not greater than 2% of the pollutant component. A copy of the analysis certificate for each of the certified gas mixtures used during the testing is included in the test report.

The oxygen instrument utilizes a paramagnetic detector and the carbon dioxide instrument utilizes a nondispersive infrared detector. The minimum detection limit for both gas analyzers is 0.1 %. The fullscale limitations of the oxygen and carbon dioxide analyzers is 25 and 20 % respectively.

Immediately prior to each compliance test series, a complete calibration of the instrument is performed. Each instrument has zero grade nitrogen injected into it and the zero potentiometer is adjusted, if necessary, until the proper voltage output from the analyzer is achieved.

Then a high range pollutant gas mixture, that has been prepared in the specified range percentage of the span or fullscale, is injected. After the system stabilizes, the span or fullscale potentiometer is adjusted until the voltage output from analyzer corresponds to the certification of analysis for the respective calibration gas.

When this procedure is complete and the system has responded properly to a zero and fullscale reading, a mid and/or low range certified calibration gas is injected into the system. No adjustments are made to the system except to achieve proper flow rate through the analyzer. The analyzer, after reaching a stable value, must correspond to the certified value of the calibration gas within a specified percentage of the fullscale.

This mid range calibration gas serves two purposes of quality control and quality assurance. The first is to show that the instrument analyzes and outputs data on a linear scale. The second purpose is to validate that the zero and fullscale values of the instrument are properly set.

Prior to sampling, a single calibration gas was injected into the probe inlet. This calibration gas is usually a mixture of oxygen and carbon dioxide in a balance of zero nitrogen. The system is not adjusted except to achieve proper flow through the analyzers. The calibration standard is allowed to traverse the sampling system. The response of the analyzer during this bias check must agree with the initial analyzer



response of this standard within the specified tolerances set forth in the test method. This system bias check serves to demonstrate that the sample train is leak free and causes no interference to the integrity of the sample.

## 2. Sampling.

After calibration, the system is purged with zero grade nitrogen to remove any pollutants that were injected as calibration gas. Once the system indicates that the pollutant gases have been removed, the calibration valve assembly is positioned to allow stack gas to flow through the instrument.

The sample gas is filtered at the stack position to remove any particulate matter. This prevents instruments from being contaminated and ensures reliable data acquisition.

All samples injected to the instruments are removed from the stack and delivered to the instruments via a heated probe and sample line. This prevents any condensation of water vapor and/or pollutant in the gas stream. Once the sample gas exits the sample line, the stream is separated in a sample gas manifold. The split stream enables analysis of the CEM instrumentation on both wet and dry basis as necessary.

The portion of the sample gas dedicated to the dry basis analyzers is directed into a gas conditioning system where the moisture content of the stream is removed. The sample gas that exits the gas conditioning system is then routed to the instruments for analysis on a dry basis.

To demonstrate that the instrument did not exhibit any deviation from the calibrated values set at the beginning of a test period, a sample of certified calibration gas is injected into the sampling system at the conclusion of each test run. The sample system must respond within specified tolerance limits according to the initial system bias check.

This post-test calibration serves two purposes: (1) it demonstrates that excessive calibration drift of the instrument(s) did not occur during the test period and, (2) that the system was not contaminated with any foreign material from the source to alter any results during the test period.

### 3. Data Acquisition.

The CEM monitors utilized in the testing project output a voltage signal corresponding to the pollutant concentration determined by the detector. This signal is relayed to a computerized datalogger system. This system retrieves the output signal from each monitor every 10 seconds. This data is then averaged on a per minute basis and stored on the hard drive of the computer. Additionally, a strip chart recorder is employed to record the data. This device records the instrument output on a one minute, instantaneous basis.

The data listing for all of the analyzers, for each testing period, is provided in another section. This listing provides the data results as recorded by the computerized datalogger system.

#### B. Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Procedure) - US EPA Method 7E:

The calibration, sampling, and data acquisition procedures are similar to that of Method 3A. Listed below are any deviations or differences that were incurred specifically in this testing procedure.

The calibration of the instruments is performed using certified gas standards composed of a known concentration of nitrogen oxide in zero grade nitrogen. These gas standards are prepared using partial pressure/volumetric and gravimetric methods.

The prepared gas mixture is analyzed and the certification tolerance is not greater than 2% of the pollutant component. A copy of the analysis certificate for each of the certified gas mixtures used during the testing is included in the test report.

The instrument utilizes an chemiluminescent detector. The detection limitation of the analyzer is 0.1 ppm. Multiple fullscale ranges are available for operation. A 250, 1000, 2500, and 10,000 ppm fullscale may be selected according to the concentrations of  $\text{NO}_x$  present in the gas stream. The analyzers were calibrated using standards that were the appropriate percentage of fullscale according to Method 7E.

The pre-test calibration, system bias, and post-test calibration procedures are identical to those discussed in Reference Method 3A.

C. Determination of Carbon Monoxide Emissions From Stationary Sources  
(Instrumental Analyzer Procedure) - US EPA Method 10:

1. Calibration.

The calibration of the instruments is performed using certified gas standards composed of a known concentration of carbon monoxide in zero grade nitrogen. These gas standards are prepared using partial pressure/volumetric and gravimetric methods.

The prepared gas mixture is analyzed and the certification tolerance is not greater than 2% of the pollutant component. A copy of the analysis certificate for each of the certified gas mixtures used during the testing is included in the test report.

The instrument utilizes a Luft-type nondispersive infrared detector. Immediately prior to each compliance test series, a complete calibration of the instrument is performed. Each instrument has zero grade nitrogen injected into it and the zero potentiometer is adjusted, if necessary, until the proper voltage output from the analyzer is achieved.

Then a high range pollutant gas mixture, that has been prepared in the specified range percentage of the span or fullscale, is injected. After the system stabilizes, the span or fullscale potentiometer is adjusted until the voltage output from analyzer corresponds to the certification of analysis for the respective calibration gas.

When this procedure is complete and the system has responded properly to a zero and fullscale reading, a mid and low range certified calibration gas is injected into the system. No adjustments are made to the system except to achieve proper flow rate through the analyzer. The analyzer, after reaching a stable value, must correspond to the certified value of the calibration gas within a specified percentage of the fullscale. This mid and low range calibration gas serves two purposes of quality control and quality assurance. The first is to show that the instrument analyzes and outputs data on a linear scale. The second purpose is to validate that the zero and fullscale values of the instrument are properly set.

## 2. Sampling.

After calibration of the instrument(s) has been completed, a sample bias check is performed. This involves injecting calibration gas into the sample probe inlet and allowing the calibration gas to traverse through the sample train to the analyzer(s) where it is analyzed. This analysis will correspond to the pre-test calibration analysis value of the standard within the tolerances set forth in the reference method.

Once the system indicates that the calibration gases have been removed, the calibration valve assembly is positioned to allow stack gas to flow through the instrument. The sample gas is filtered at the stack position to remove any particulate matter. This prevents instruments from being contaminated and ensures reliable data acquisition.

All samples injected to the instruments are removed from the stack and delivered to the instruments via a heated probe and sample line. This prevents any condensation of water vapor and/or pollutant in the gas stream.

To demonstrate that the instrument did not exhibit any deviation from the calibrated values set at the beginning of a test period, a sample of certified calibration gas is injected into the sampling system at the conclusion of each test run. The sample system must respond within specified tolerance limits according to the initial system bias check.

This post-test calibration serves two purposes: (1) it demonstrates that excessive calibration drift of the instrument(s) did not occur during the test period and, (2) that the system was not contaminated with any foreign material from the source to alter any results during the test period.

D. Determination of Total Gaseous Organic Emissions From Stationary Sources  
(Instrumental Analyzer Procedure) - US EPA Method 25A:

1. Calibration.

The calibration of the instruments is performed using certified gas standards composed of a known concentration of methane in zero grade nitrogen. These gas standards are prepared using partial pressure/volumetric and gravimetric methods.

The prepared gas mixture is analyzed and the certification tolerance is not greater than 2% of the pollutant component. A copy of the analysis certificate for each of the certified gas mixtures used during the testing is included in the test report.

The instrument utilizes an flame ionization detector. Immediately prior to each compliance test series, a complete calibration of the instrument is performed. Each instrument has zero grade nitrogen injected into it and the zero potentiometer is adjusted, if necessary, until the proper voltage output from the analyzer is achieved.

Then a high range pollutant gas mixture, that has been prepared in the specified range percentage of the span or fullscale, is injected. After the system stabilizes, the span or fullscale potentiometer is adjusted until the voltage output from analyzer corresponds to the certification of analysis for the respective calibration gas.

When this procedure is complete and the system has responded properly to a zero and fullscale reading, a mid and low range certified calibration gas is injected into the system. No adjustments are made to the system except to achieve proper flow rate through the analyzer. The analyzer, after reaching a stable value, must correspond to the certified value of the calibration gas within a specified percentage of the fullscale. This mid and low range calibration gas serves two purposes of quality control and quality assurance. The first is to show that the instrument analyzes and outputs data on a linear scale. The second purpose is to validate that the zero and fullscale values of the instrument are properly set.

## 2. Sampling.

After calibration, the system is purged with zero grade nitrogen to remove any pollutants that were injected as calibration gas. Once the system indicates that the pollutant gases have been removed, the calibration valve assembly is positioned to allow stack gas to flow through the instrument.

The sample gas is filtered at the stack position to remove any particulate matter. This prevents instruments from being contaminated and ensures reliable data acquisition. All samples injected to the instruments are removed from the stack and delivered to the instruments via a heated probe and sample line. This prevents any condensation of water vapor and/or pollutant in the gas stream. The data obtained from the THC analyzer is therefore on a "wet basis". The data listing must be corrected to a "dry basis" for use in emission determinations, e.g. lb/hr. This correction is conducted utilizing the moisture percentage of the flue gas stream as determined during the test run.

To demonstrate that the instrument did not exhibit any deviation from the calibrated values set at the beginning of a test period, a sample of certified calibration gas is injected into the sampling system at the conclusion of each test run. The sample system must respond within specified tolerance limits according to the initial system bias check.

This post-test calibration serves two purposes: (1) it demonstrates that excessive calibration drift of the instrument(s) did not occur during the test period and, (2) that the system was not contaminated with any foreign material from the source to alter any results during the test period.

E. Total Particulate - US EPA Reference Methods 5:

1. Preparation.

All glassware utilized in each sampling train was thoroughly cleaned and dried prior to each test series. A glass fiber filter was used that had been labeled, desiccated for a minimum of 24 hours and pre-weighed.

The impinger system configuration was assembled using the procedure outlined in Method 5. One hundred ml of deionized water was placed in the first two impingers. The third impinger was initially empty and the fourth impinger contained a pre-weighed amount of silica gel for complete moisture removal.

A stainless steel probe liner and nozzle system was utilized for the total particulate determinations. The probe housed a set of calibrated S-type pitot tubes and a calibrated thermocouple for monitoring stack temperature.

2. Sampling.

The probe and sample box were heated to an approximate temperature of 250 F. These temperatures were monitored throughout the testing. An ice bath was prepared to submerge the impinger system. The temperature of the last impinger was monitored throughout the testing to ensure adequate condensation of the water vapor in the flue gases.

A leak check was performed prior to each test run. The sample train system was subjected to a vacuum that did not exceed 0.02 cfm leakage rate. The vacuum that was established during the pre-test leak check was not exceeded during the test period(s).

When a test run had been completed, a post-test leak check was conducted prior to dismantling of the sampling train. Once this had been successfully achieved, the sample train was dismantled for sample recovery.

The probe and connecting glassware were washed with acetone. The contents of the impingers were volumetrically measured for moisture gain and transferred to a labeled sample container. The glass fiber filter was carefully transferred to its sample container.

### 3. Analysis.

The glass fiber filter was desiccated for 24 hours prior to any weighing. The acetone probe wash was transferred to a tared beaker and evaporated to dryness. The resultant residue was also desiccated prior to gravimetric analysis.

The first weighing was performed after this initial period of drying. The weights were recorded to 0.0001 g. After a minimum of 6 additional hours of desiccating, a second weighing was conducted. The weights must agree within 0.0005 g or further desiccation must be conducted until the weights stabilize.

Sample field blanks of acetone were collected, contained, labeled and analyzed in conjunction with the samples. The blank weight was deducted from the acetone probe wash residue weight determinations.



F. EPA Draft Method 202, "Determination of Filterable and Condensible Particulate Matter"

The testing procedure was conducted according to Reference Method 5 for particulate matter determination. This testing procedure was covered in a previous section. The filterable portion of the particulate matter was determined via this procedure. The condensible fraction of the sample was determined by analyzing the back half impinger catch with a methylene chloride extraction.

This extraction procedure will yield fractions of inorganic and organic condensible matter. The concentrations and emission values of both filterable particulate and condensible particulate matter have been summarized in the test results section.

G. Polynuclear Aromatic Hydrocarbons - Method SW846 8270 "Semivolatile Organic Compounds by Gas Chromatography/Mass Spectrometry (GC/MS): Capillary Column Technique"

1. Preparation.

All glassware utilized in each sampling train was thoroughly cleaned with hot soapy water and dried prior to each test series. All residue silicon grease was removed from glassware upstream of the absorbent module. A glass fiber filter was used that has been properly labeled.

The absorbent traps was packed by the analytical laboratory that conducted the final analysis.

The impinger system was assembled using 100 ml of D.I. water in impingers 1 and 2. The third impinger was initially empty and the fourth impinger contained silica gel.

In assembling the sample train, teflon tape was placed on the ball joints to ensure adequate sealing upstream of the absorbent module. All connections downstream of the module were sealed with silicon grease.

A glass probe liner and nozzle system was utilized for the collection train. The probe housed a set of calibrated S-type pitot tubes and a calibrated thermocouple for monitoring stack temperature.

## 2. Sampling.

The probe and sample box was heated to an approximate temperature of 250 F. These temperatures were monitored throughout the testing.

The probe was connected to the heated filter system with connecting glassware. This filter system was connected to the condenser by a teflon line. The condenser and absorbent module are directly connected via ground glass ball and socket.

An ice bath was prepared to submerge the impinger system into. The temperature of the last impinger was monitored throughout the testing to ensure adequate condensation of the water vapor in the flue gases.

The condenser cooling fluid was recirculated through the system by a peristaltic pump. This pump is to be started prior to the start up of the sampling system to ensure that the temperature of the absorbent material in the module does not exceed its thermal decomposition temperature. The temperature of gas entering the module was monitored to ensure that the temperature did not exceed the recommended limitation for efficient capture.

A leak check was performed prior to each test run. The entire sample train system was subjected to a vacuum that did not exceed 0.02 cfm leakage rate. The vacuum that was established during the pre-test leak check was not exceeded during the test period.

Three sample runs were conducted to constitute a complete test. The sample time was be a minimum of one hour.

When a test run had been completed, a post-test leak check was conducted prior to any dismantling of the sampling train. Once this had been successfully achieved, the sample train was dismantled for sample recovery.

### 3. Sample Analysis.

Method 8270 is used to determine the concentration of semivolatile organic compounds in extracts prepared from all types of solid waste matrices. Each compound present in the sample is separated by gas chromatography and quantified by mass spectrometry.

The detection limitation of this type of sample has been determined to be 1.0 microgram. If the samples are separated for further analysis, the detection limit will be 2.0 micrograms.

#### H. EPA Draft Method 0011, "Determination of Formaldehyde":

This sampling procedure is similar to the operational procedures found in Reference Method 5. Described in this section are the differences set forth from Method 5 to ensure that the integrity of the formaldehyde sample is maintained.

Prior to any sampling, all glassware shall be rinsed with methylene chloride to remove any contamination that may be initially on the glassware such as stopcock grease. This includes the rinsing of the glass probe liner material required for the collection of the sample.

In collecting the sample, a minimum of 45 cubic feet must be pulled isokinetically such that the extracted sample is transferred through the DNPH absorption solution. All

samples should be placed into glass amber sample containers to avoid the alteration of the sample by sunlight.

The analysis of the formaldehyde samples shall be conducted according to the procedures outlined in Method 8315. This analysis procedure provides guidance in the evaluation of formaldehyde samples by High Performance Liquid Chromatography (HPLC).

I. Determination of Gaseous Organic Emissions From Stationary Sources By Gas Chromatography - US EPA Method 18:

This procedure utilizes the technology of gas chromatography to separate, identify, and quantitate various volatile organic compounds that co-exist in a flue gas stream. In this testing project, methane and the BTEX compounds were targeted.

The gas chromatograph was first conditioned in the laboratory where ideal conditions exist for this initial calibration. This consists of conditioning the column, if necessary, and creating calibration curves based on actual data from the GC with known concentration standards. As required by EPA, three (3) standards of known concentration were used in creating the calibration curves. The concentrations of the standards bracketed the expected concentration of pollutant at the source level.

A field calibration check was performed prior to introducing any sample into the gas chromatograph. This is performed by injecting one of the known standards into the GC and comparing the result to the calibration curve. It must agree within 5 % of the previously determined response.

Analysis of the samples follow a successful field calibration. Collecting the sample consisted of extracting the sample from the stack via a heated sample line. The sample was introduced directly into the sample loop, where it was periodically injected to the instrument for analysis. This type of sampling is termed "semi-continuous".

#### IV. SOURCE INFORMATION


The emissions test was conducted after a baghouse on a stack measuring measuring 33" x 49.5" with an equivalent diameter of 39.6". Six (6) sampling ports were placed 20" down (.5 diameters upstream) from the top of the stack and 80" up (2.0 diameters downstream) from the last flow disturbance. The ports were evenly spaced on 8.25" centers. The two outside ports are 4.125" from the side walls of the stack. Thirty (30) points were sampled, five (5) through each port for two (2) minutes each for a total testing time of sixty (60) minutes.

Points  
on a  
Diameter

1  
2  
3  
4  
5

Probe  
Mark


3.3"  
9.9"  
16.5"  
23.1"  
29.7"



EQUIPMENT USED

Equipment used to conduct the particulate emissions test was:

- A. A Lear Siegler PM-100 stack sampler with appropriate auxiliary equipment and glassware (with train set up according to the schematic on the next page).
- B. An Airguide Instruments Model 211-B (uncorrected) aneroid barometer for checking the barometric pressure.
- C. Weston dial thermometers to check meter temperatures or an Analogic Model 2572 Digital Thermocouple to check stack temperatures.
- D. A Hays 621 Analyzer to measure the oxygen, carbon dioxide and carbon monoxide content of the stack gases or, for non-combustion sources, a Bacharach Instrument Company Fyrite for gas analysis.
- E. Schleicher and Schuell Type 1-HV filters with a porosity of .03 microns.
- F. Reagent- or ACS-grade acetone with a residue of  $\leq .001$ .



**SAMPLING TRAIN  
USED FOR ISOKINETIC SAMPLING**

- 1) Probe
- 2) Cyclone
- 3) Flask
- 4) Particulate Filter
- 5) Impingers (Greenburg-Smith)
- 6) Thermometer
- 7) Check Valve
- 8) Umbilical Cord
- 9) Vacuum Gauge
- 10) Coarse Flow Adjust Valve
- 11) Fine Flow Adjust Valve
- 12) Oil
- 13) Vacuum Pump
- 14) Filter
- 15) Dry Gas Meter
- 16) Orifice Tube
- 17) Incline Manometer
- 18) Solenoid Valves
- 19) Pilot
- 20) Thermocouple
- 21) Pyrometer

## MODEL 10 FOR CONTINUOUS SOURCE GAS MONITORING

## CHEMILUMINESCENT NO/NO<sub>x</sub> ANALYZER

Thermo Electron's Model 10 NO/NO<sub>x</sub> Analyzer is based on the chemiluminescent reaction between nitric oxide (NO) and ozone (O<sub>3</sub>) according to the reaction:  $\text{NO} + \text{O}_3 \rightarrow \text{NO}_2 + \text{O}_2 + h\nu$

Light emission results when the electronically excited NO<sub>2</sub> molecules revert to their ground state.


A front panel mode switch provides for either a direct readout of the NO concentration in the sample being analyzed ("NO" mode) or the total NO<sub>x</sub> concentration ("NO<sub>x</sub>" mode). When the Model 10 is placed in the "NO<sub>x</sub>" mode, the sample stream passes through a NO<sub>x</sub>-to-NO converter prior to entering the reaction chamber for subsequent analysis.

### Key Features

- Selective detection of NO or NO<sub>x</sub>
- Eight ranges, from 2.5 to 10,000 ppm FS
- Continuous monitoring with rapid response
- Linear on all ranges
- Field proven reliability
- Insensitive to changes in sample flow

As illustrated in the diagram, sample gas enters the Model 10, flows through the bypass capillary, and divides. Most of the sample flows through the flowmeter, accumulator, bypass pump, and exhausts. Only a small amount of sample flows through the sample capillary for analysis. The bypass pump in conjunction with the sample regulator maintain a constant pressure differential across the sample capillary, thus maintaining constant sample flow for analysis. This plumbing network makes the analyzer insensitive to pressure fluctuation in the sample inlet.

From the sample capillary, the sample to be analyzed is either directed through the NO<sub>x</sub> to NO converter or around it, depending on the choice of the operator. In the reaction chamber the sample reacts with ozone to produce the light emission and is exhausted. The ozone is produced internally from dry air entering through the oxygen regulator and ozonator. The light emission is sensed by the photomultiplier tube and amplified.



### Model 10 Specifications\*

|                                  |                                                                                                                               |     |          |     |
|----------------------------------|-------------------------------------------------------------------------------------------------------------------------------|-----|----------|-----|
| Ranges                           | 0-2.5                                                                                                                         | ppm | 0-250    | ppm |
|                                  | 0-10                                                                                                                          | ppm | 0-1000   | ppm |
|                                  | 0-25                                                                                                                          | ppm | 0-2500   | ppm |
|                                  | 0-100                                                                                                                         | ppm | 0-10,000 | ppm |
| Minimum Detectable Concentration | .05 ppm                                                                                                                       |     |          |     |
| Noise                            | Less than 1% of FS                                                                                                            |     |          |     |
| Reproducibility                  | 1% of FS                                                                                                                      |     |          |     |
| Operating Temperature Extremes   | 0-40°C                                                                                                                        |     |          |     |
| Response Time (0-90%)            | ~ 1.5 second NO mode                                                                                                          |     |          |     |
|                                  | ~ 1.7 second NO <sub>x</sub> mode                                                                                             |     |          |     |
| Zero Stability                   | ± 1 ppm in 24 hours                                                                                                           |     |          |     |
| Span Stability                   | ± 1% in 24 hours                                                                                                              |     |          |     |
| Linearity                        | ± 1% from 0.05 to 10,000 ppm**                                                                                                |     |          |     |
| Power Requirements               | 1000 watts, 115 ± 10 volts, 60 Hz standard.<br>Also available in 115V 50 Hz,<br>and 210 ± 15 volts, 50 Hz versions            |     |          |     |
| Physical Dimensions              | 19" wide x 17" high x 20" deep                                                                                                |     |          |     |
| Instrument Weight                | 75 lbs. (including pump)                                                                                                      |     |          |     |
| Outputs                          | Two standard outputs supplied: 1) 0-10V;<br>2) Field selectable from 0-10V, 5V, 1V, 100mV or 10mV.<br>(mA options available.) |     |          |     |

\*Specifications are typical and subject to change without notice.

\*\*With O<sub>2</sub> Feed; With dry air, linearity to 2000 ppm.



## FUJI 730 NDIR SINGLE GAS ANALYZER

This unique Mass Flow Sensor used in the Fuji 730 Single Gas Analyzer provides significant advantages over other sensors used for this purpose. The design of the Mass Flow Detector minimizes the adverse effects of vibration which is often present in harsh environments. In addition the Mass Flow Sensor System virtually eliminates interference making the Fuji 730 a powerful analytical tool for monitoring burner and boiler efficiency heat treatment fermentation well logging and many other applications which require exceptional accuracy stability high sensitivity and reliability.

### PRINCIPLE OF OPERATION

The Fuji 730 Series Analyzers use the infrared adsorption characteristic of gases to measure the concentration of gas samples. An efficient single beam design which incorporates a unique mass flow sensor system insures accurate and interference free analysis for a wide variety of applications.

A single beam of infrared energy is chopped and passed through a sample cell containing the flowing gas sample. Due to the adsorption characteristic, the amount of energy in the beam is reduced by the concentration of the measured gas in the sample. The attenuated infrared beam is passed serially through the two cavities of the mass flow sensor which contain a high concentration of the gas species the analyzer is intended to measure. The two cavity sensor performs two functions in the analyzing process, it first eliminates interference caused by other gases and water vapor by detecting and subtracting the interference component from the detector output, and secondly, produces an output signal which represents an accurate duplication of the relative infrared energy adsorption. This resultant signal is electronically processed and linearized to provide an electrical signal which drives meters and other output devices.

### STANDARD GASES:

Carbon Monoxide (CO)  
Carbon Dioxide (CO<sub>2</sub>)  
Methane (CH<sub>4</sub>)

### STANDARD RANGES:

0-500/1000 ppm  
0-1000/2000 ppm  
0-2000/5000 ppm  
0-2500/5000 ppm

0-0.5/1.0%  
0-1/2%  
0-2/5%  
0-5/10%  
1-10/20%

### PURGE GAS FITTING

Standard Equipment

### INTERNAL SPAN CHECK FEATURE

Calibration check without the use of span gases.  
Conserves gas and reduces operating costs.

### SPECIFICATIONS

|                                             |                                                                                    |
|---------------------------------------------|------------------------------------------------------------------------------------|
| <b>Repeatability:</b>                       | ±0.5% of full scale (low range)<br>±1.0% of full scale (high range)                |
| <b>Zero Drift*:</b>                         | ±1% of full scale per 24 hours                                                     |
| <b>Span Drift*:</b>                         | ±1% of full scale per 24 hours                                                     |
| <b>Linearity:</b>                           | ±2% of full scale (within linearizer)                                              |
| <b>Noise Level:</b>                         | 0.5% of full scale                                                                 |
| <b>Speed of Response:</b>                   | 90% indication                                                                     |
| <b>Electrical:</b>                          | 2, 3 or 5 seconds (field selectable)                                               |
| <b>Pneumatic:</b>                           | Less than 15 seconds (depending on cell length)                                    |
| <b>Warm-Up:</b>                             | Two hours (to ±2% full scale)                                                      |
| <b>Internal Span Check:</b>                 | Manually activated from front panel                                                |
| <b>Outputs:</b>                             | 0 to 1V DC, linear & 4-20mA DC, linear                                             |
| <b>Ambient Temperature Range:</b>           | 23 to 113°F (-5 to 45°C)                                                           |
| <b>Ambient Humidity:</b>                    | To 90% R.H. (non-condensing)                                                       |
| <b>Sample Gas Temperature:</b>              | 32 to 122°F (0 to 50°C)                                                            |
| <b>Sample Gas Flow Rate:</b>                | 2 ± 1 scfh (1.0 ± .05 slpm)                                                        |
| <b>Purge Gas Rate</b><br>(where necessary): | 2 scfh (1 slpm), when required                                                     |
| <b>Power Requirements:</b>                  | 115V AC ± 10%, 60 Hz, 30VA                                                         |
| <b>Gas Connections:</b>                     | All 1/4" compression-type tube fittings                                            |
| <b>Size and Weight:</b>                     | 7.9 (H) x 9.8 (W) x 21.3 (D) inches<br>(200 x 250 x 541 mm)<br>24.2 pounds (11 kg) |

\*constant conditions

# FUJI 760 NDIR GAS ANALYZER

25

- Unique Mass Flow Sensor System Eliminates Interference
- Wide Dynamic Range Permits Ultra-Sensitive and High Concentration Gas Analysis
- Designed for Continuous Operation and Low Maintenance
- Measures:
  - Carbon Monoxide (CO)
  - Carbon Dioxide (CO<sub>2</sub>)
  - Sulfur Dioxide (SO<sub>2</sub>)
  - Nitric Oxide (NO)
  - Methane (CH<sub>4</sub>)
- Insensitive to Vibration

This instrument is designed for stack monitoring and process control applications. Its remarkable accuracy and fast response makes it an ideal instrument for CEMS, boiler control equipment, research labs and many other monitoring applications. For usage requiring ultra sensitive measurement, the Fuji 760 delivers superior performance. Using the Non-Dispersive Infrared (NDIR) Mass Flow Detector, low concentration measurements are accurate and reliable. The Fuji 760 incorporates an Interference Compensating Detector which minimizes the effects of other gases, particularly when operating in ranges of high sensitivity.

## FEATURES OF THE FUJI-760

The Fuji 760 Analyzer uses infrared adsorption techniques to measure gas concentrations, however, many innovative patented features make this instrument far superior to conventional Non Dispersive Infrared Analyzers. Among its unique features are an optical chopper design which virtually eliminates the effects of vibration and resultant optical noise; a mass flow sensor system which reduces the effects of interfering gases to insignificant levels, thus permitting gas analysis at low concentration ranges; and a dual beam optical system derived from a single infrared source which enhances long term stability.

## PRINCIPAL OF OPERATION



A single beam of infrared energy is modulated and split into two parallel beams by a distribution cell. One beam is passed through a reference cell containing a non-absorbing gas, and the other beam is passed through a cell containing the sample gas being measured. The beam passing through the sample cell is attenuated by the amount of gas concentration in the sample and compared against the unattenuated reference beam by the mass flow detector system. One set of detectors sense the amount of sample gas as compared against the reference, the second set of detectors measure and cancel interferences in the sample. The outputs of the detectors are electronically processed and conditioned into useable signals for indicators and other output devices.

## DETECTABLE GAS RANGES

### Standard Configuration

| Component                         | Minimum Range |
|-----------------------------------|---------------|
| Carbon Monoxide (CO)              | 0 to 100 ppm  |
| Carbon Dioxide (CO <sub>2</sub> ) | 0 to 50 ppm   |
| Nitric Oxide (NO)                 | 0 to 100 ppm  |
| Sulfur Dioxide (SO <sub>2</sub> ) | 0 to 100 ppm  |
| Total Hydrocarbons                | 0 to 500 ppm  |

Other Gases can be measured.



## Specifications

### (Standard Configuration)

**Repeatability:**  $\pm 0.5\%$  of full scale

**Zero Drift:**  $\pm 2\%$  of full scale per week

**Span Drift:**  $\pm 2\%$  of full scale per week

**Linearity:**  $\pm 2\%$  of full scale

**Speed of Response:** 90% indication within 5 seconds (Electronic Response)

**Range Selection:** Either of two ranges selected by front panel switch or external contact closure.

**Warm-Up:** Four hours minimum

**Outputs:** 0 to 1V DC, linear and 4-20mA DC, linear

**Ambient Temperature Range:** 23 to 113°F (-5 to 45°C)

**Ambient Humidity:** To 90% R.H. (non-condensing)

**Sample Gas Temperature:** 32 to 122°F (0 to 50°C)

**Sample Gas Flow Rate:** 1.0  $\pm$  0.5 scfh (0.50  $\pm$  0.25 slpm) for standard configuration

**Materials in Contact with Sample:** 304 Stainless steel, neoprene rubber, silicone rubber, CaF<sub>2</sub>/sapphire, Teflon®

**Power Requirements:** 115V AC  $\pm 10\%$ , 50/60 Hz (switch selectable)  
110 VA max. (200VA max with converter)  
220V AC available

**Gas Connections:** All 1/4" compression-type tube fittings

### Size and Weight

8.66 (H) x 17.44 (W) x 16.78 (D) inches  
(220 x 443 x 350 mm)

37.4 pounds (17 kg)

## 8610 GAS CHROMATOGRAPH

### Miniature Lab GC

At a fraction of the cost, the SRI 8610 Gas Chromatograph provides the capabilities and sophistication of vastly larger and more expensive instruments in a small, lightweight and attractive package. More of a miniature laboratory GC than a true portable, the 8610 is the perfect size and weight for easy field use without sacrificing big GC features. In the lab or in the field, the 8610 Gas Chromatograph gives you up to five detectors plus a built-in purge and trap in a simple to operate, easy to trouble-shoot, and unbelievably low cost package. And, the Peaksimple Data System, provided free with every 8610 GC turns your IBM PC into a powerful chromatography integrator which also controls the 8610's temperature program and purge and trap.

### Multi-Level Temperature Programming

Temperature programming is a standard feature on every 8610 GC. Up to 15 ramp/plateau segments permit maximum flexibility. Because the temperature program is controlled by the data system, an unlimited number of different temperature programs may be permanently stored on disk and activated with a few keystrokes. The 8610's temperature program can be controlled either by the Peaksimple Data System (included free with every GC) or by any other data system or integrator which has the ability to close relay contacts at specified times during the run.

### Ultra Low Mass Column Oven

The SRI 8610's large easily accessible column oven is designed to fit all standard packed and capillary columns with diameters up to eight inches. The ultra-low mass design allows rapid heat-up and cool-down from ambient to 250 degrees centigrade. Interchangeable screw-in heater elements allow power consumption to be reduced for low temperature battery powered applications, or easy heater replacement in the event of a failure. Squirrel-cage type oven fan insures uniform heat distribution and stability to within .1 degree.

### Low Cost GC • Free Data System/Integrator

### Field Portable • Built-In Purge and Trap

### Temperature Programmable • Multiple Detectors

#### Digital Gas Flow Controllers

The carrier gas flow rate is regulated by a unique Digital Flow Controller. Precise and reproducible even at capillary flow rates below 1 cc/per minute, the carrier gas flow controller is standard equipment on every SRI 8610 GC (except low-cost student model). Digital dial allows flow rates to be adjusted without having to measure actual flows with a bubblemeter. A column head pressure gauge is provided to alert the operator to leaks or blockages in the column. The same flow controller is optionally available for hydrogen and air combustion gas flows (recommended for NPD operation). In addition, inlet pressure regulators are supplied for each gas to isolate the GC from fluctuations in gas supply pressure.

#### Direct Cool On Column Injection

The zero-dead volume on-column injector is designed for state of the art, cool on-column injections using both packed and wide-bore capillary (.53 mm). A special wide-bore adapter positions the .53 mm column so the syringe smoothly deposits the sample in the bore of the column itself. This provides a totally inert, metal and glass free sample path. Peaks are exceptionally sharp and well resolved.


#### Detectors

|                             |                              |
|-----------------------------|------------------------------|
| Thermal Conductivity (TCD)  | Photo-Ionization (PID)       |
| Flame Ionization (FID)      | Electron Capture (ECD)       |
| Nitrogen-Phosphorus (NPD)   | Hall Detector (HALL or ELCD) |
| Thermionic Ionization (TID) | Flame Photometric (FPD)      |

Up to 3 detectors may be mounted simultaneously and plumbed in series so that one injection passes through each detector and into the next. Common series configurations include:

(PID-FID), (TCD-FID), (PID-ECD),  
(PID-HALL) and (PID-ECD-FID).

D:\DONNA\8610GAS.DJB



100 NG.  
602 STD.  
Data  
plotted  
using  
Peaksimple  
Data  
System.

## HEATED TOTAL HYDROCARBON ANALYZER MODEL VE7

The J.U.M. Engineering Model VE7 is a high accuracy Total Hydrocarbon Analyzer for the measurement and analysis of organic vapors.

The VE7 utilizes a Hydrogen Flame Ionization Detector (FID) in a thermostatically controlled oven to prevent the loss of high molecular weight hydrocarbons.


### Options

Digital display with BCD output/without BCD output Remote range control and range I.D.  
Recorder output of oven temperature

- All heated components
- Integrated heated sample pump
- Permanent heated stainless steel 2 micron sample filter
- Built in burner air supply - no extra bottles needed
- Automatic fuel enrichment for ignition
- 19 inch relay rack mount
- 1% precision full scale
- Response time - 90% full scale within 1 second

### STANDARD SPECIFICATIONS:

|                       |                                                                                      |
|-----------------------|--------------------------------------------------------------------------------------|
| Analysis Method:      | Flame Ionization Detector (FID)                                                      |
| Sensitivity:          | Max. 1 ppm CH                                                                        |
| Response Time:        | 90% of full scale in less than one second                                            |
| Zero Drift:           | 1% of full scale per 24 hours                                                        |
| Span Drift:           | 1% of full scale per 24 hours                                                        |
| Linearity:            | Within 1%                                                                            |
| Oxygen Synergism:     | Less than 1% of selected range                                                       |
| Ranges:               | Any three of the following:<br>0 - 10, 100, 1000, 10,000, 100,000 ppm                |
| Outputs:              | 0 - 10 Volts D.C.                                                                    |
| Display:              | Analog Meter in ppm Hydrocarbon or in % LEL                                          |
| Zero/Span Adjust:     | Manual on front panel                                                                |
| Fuel Consumption:     | Hydrogen 20 cc/min at 22 psig (1.5 Bar)<br>Hydrogen/Helium 40/60 mix: 80 cc/min.     |
| Air Consumption:      | None Integral Air generator                                                          |
| Zero & Span Gas:      | 3 psig (200 m Bar)                                                                   |
| Sample Pump:          | All Stainless Steel, heated, 3 liters per minute at operating temperature            |
| Sample Pressure:      | By Integral Pump 3 psig (200 m Bar)                                                  |
| Sample Filter:        | Permanent all stainless steel 2 micron back-purged for cleaning                      |
| Analysis Temperature: | Adjustable 200 to 400°F (93 to 204°C)                                                |
| Power Requirements:   | 110 Volts, 60 Hertz AC 800 Watts (others on request)                                 |
| Ambient Temperature:  | 32°F to 110°F (0 to 43°C)                                                            |
| Dimensions:           | Width 483 mm (19 inches), Depth 460 mm (18-1/8 inches), Height 221 mm (8-3/4 inches) |
| Weight:               | 38.6 lbs (17.5 kg)                                                                   |
| Shipping Weight:      | 53 lbs (24 kg)                                                                       |



## PRINCIPLES OF OPERATION


### SERVOMEX 1400 SERIES GAS ANALYZERS

#### SPECIFICATION

#### OXYGEN

|                               |                                                                                                   |
|-------------------------------|---------------------------------------------------------------------------------------------------|
| Principle                     | Magneto-dynamic                                                                                   |
| Linearity                     | $\pm 0.2\% \text{ O}_2$                                                                           |
| Repeatability                 | $\pm 0.2\% \text{ O}_2$                                                                           |
| Zero Drift<br>(Per Week)      | $< 0.2\% \text{ O}_2$                                                                             |
| Signal Output                 | 0-1V non-isolated for 0-100% $\text{O}_2$                                                         |
| Alarms                        | Flow alarm. 4 sets of changeover relay contacts rated at 3A/120V AC, 1A/240V AC or 1A/28V DC      |
| Display                       | 3½ digit LCD reading 0 to 100% $\text{O}_2$                                                       |
| Response Time                 | Less than 15 seconds to 90%                                                                       |
| Operating Ambient Temperature | 32 - 104°F (0-40°C)                                                                               |
| Relative Humidity             | 0 - 85%, non-condensing                                                                           |
| Sample Pressure               | 0.2 to 0.6 barg                                                                                   |
| Sample Contact Materials      | Stainless steel, pyrex, glass, brass, platinum, epoxy resin, viton, polypropylene and glass fibre |
| AC Supply                     | 110 to 120V AC, or 220 to 240V AC, $\pm 10\%$ , 48 to 62Hz, 15VA maximum                          |
| Dimensions                    | 19" Rack - 4U case<br>Bench top - 7.1" (180mm) high, 10.1" (256mm) wide, 15.4" (390mm) deep       |


22 lbs (10kg) approximately



#### PARAMAGNETIC OXYGEN

The oxygen analyzer measures the paramagnetic susceptibility of the sample gas by means of a magneto-dynamic type measuring cell.

Oxygen is virtually unique in being a paramagnetic gas, this means that it is attracted into a magnetic field. In the Servomex measuring cell, the oxygen concentration is detected by means of a dumb-bell mounted on a torque suspension in a strong, non-linear magnetic field. The higher the concentration of oxygen, the greater the dumb-bell is deflected from its rest position. This deflection is detected by an optical system and twin photocells connected to an amplifier. Around the dumb-bell is a coil of wire. A current is passed through this coil to return the dumb-bell to its original position. The current is measured and is proportional to the oxygen concentration.



Gas Flow Diagram

#### Advantages

- Not cross sensitive to most common gases
- Long lifetime
- Rugged Design
- No routine cell maintenance

## **VI. CALCULATIONS**

### **A. Particulate — Condensibles**

NAME: APAC/MACASPHALT  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7 and 8, 1992  
SOURCE: BAGHOUSE

## SUMMARY OF TEST DATA

|                                                      |                 | Run #1<br>12-07-92 | Run #2<br>12-07-92 | Run #3<br>12-08-92 |
|------------------------------------------------------|-----------------|--------------------|--------------------|--------------------|
| <b>SAMPLING TRAIN DATA</b>                           |                 |                    |                    |                    |
|                                                      | Start           | 12:59              | 14:52              | 08:30              |
|                                                      | Finish          | 14:03              | 16:07              | 10:24              |
| 1. Sampling time, minutes                            | $\theta$        | 60.0               | 60.0               | 60.0               |
| 2. Sampling nozzle diameter, in.                     | $D_n$           | .2500              | .2500              | .2500              |
| 3. Sampling nozzle cross-sect. area, ft <sup>2</sup> | $A_n$           | .000340            | .000340            | .000340            |
| 4. Isokinetic variation                              | I               | 110                | 95                 | 91                 |
| 5. Sample gas volume - meter cond., cf.              | $V_m$           | 44.679             | 45.880             | 48.867             |
| 6. Average meter temperature, °R                     | $T_m$           | 561                | 570                | 545                |
| 7. Avg. orifice pressure drop, in. H <sub>2</sub> O  | $\Delta H$      | 1.57               | 1.93               | 2.22               |
| 8. Total particulate collected, mg.                  | $M_n$           | 8.00               | 8.90               | 6.20               |
| <b>VELOCITY TRAVERSE DATA</b>                        |                 |                    |                    |                    |
| 9. Stack area, ft. <sup>2</sup>                      | A               | 11.34              | 11.34              | 11.34              |
| 10. Absolute stack gas pressure, in. Hg.             | $P_s$           | 30.10              | 30.10              | 30.08              |
| 11. Barometric pressure, in. Hg.                     | $P_{bar}$       | 30.10              | 30.10              | 30.08              |
| 12. Avg. absolute stack temperature, R°              | $T_s$           | 870                | 816                | 801                |
| 13. Average vel. head, ( $C_p = .84$ )               | $\sqrt{dp}$     | 1.03               | 1.15               | 1.22               |
| 14. Average stack gas velocity, ft./sec.             | $V_s$           | 78.60              | 84.99              | 88.30              |
| <b>STACK MOISTURE CONTENT</b>                        |                 |                    |                    |                    |
| 15. Total water collected by train, ml.              | $V_{lc}$        | 492.50             | 471.50             | 386.80             |
| 16. Moisture in stack gas, %                         | $B_{ws}$        | 35.80              | 34.54              | 27.97              |
| <b>EMISSION DATA</b>                                 |                 |                    |                    |                    |
| 17. Stack gas flow rate, dscf/hr.                    | $Q_{sd}$        | 1258               | 1478               | 1721               |
| 18. Stack gas flow rate, cfm                         | acfm            | 53479              | 57827              | 60079              |
| 19. Particulate concentration, gr/dscf               | $C_s$           | 0.0030             | 0.0033             | 0.0020             |
| 20. Particulate concentration, lb/hr                 | E               | 0.54               | 0.70               | 0.49               |
| 21. Particulate concentration, lb/mBtu               | E'              | 0.00000            | 0.00000            | 0.00000            |
| <b>ORSAT DATA</b>                                    |                 |                    |                    |                    |
| 22. Percent CO <sub>2</sub> by volume                | CO <sub>2</sub> | 8.60               | 7.00               | 5.50               |
| 23. Percent O <sub>2</sub> by volume                 | O <sub>2</sub>  | 11.00              | 11.70              | 13.00              |
| 24. Percent CO by volume                             | CO              | .00                | .00                | .00                |
| 25. Percent N <sub>2</sub> by volume                 | N <sub>2</sub>  | 80.40              | 81.30              | 81.50              |

NAME: APAC/MACASPHALT  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 7 and 8, 1992  
 SOURCE: BAGHOUSE

### MOISTURE DETERMINATION DRY GAS VOLUME

$$V_{m(std)} = V_m \left[ \frac{T_{(std)}}{T_m} \right] \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{P_{std}} \right] - 17.64 \frac{^{\circ}R}{\epsilon. Hg} Y V_m \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right]$$

Where:

- $V_{m(std)}$  = Dry gas volume through meter at standard conditions, ft<sup>3</sup>.  
 $V_m$  = Dry gas volume measured by meter, ft<sup>3</sup>.  
 $P_{bar}$  = Barometric pressure at orifice meter, in. Hg.  
 $P_{std}$  = Standard absolute pressure, (29.92 in. Hg.).  
 $T_m$  = Absolute temperature at meter, °R.  
 $T_{std}$  = Standard absolute temperature, (528°R).  
 $\Delta H$  = Avg. pressure drop across orifice meter, in. H<sub>2</sub>O.  
 $Y$  = Dry gas meter calibration factor.  
 13.6 = Inches of water per Hg.

Run #1:

$$V_{m(std)} = (17.64)(.980)(44.679) \left[ \frac{30.10 + \frac{1.57}{13.6}}{561} \right] = 41.600 \text{ dscf}$$

Run #2:

$$V_{m(std)} = (17.64)(.980)(45.880) \left[ \frac{30.10 + \frac{1.93}{13.6}}{570} \right] = 42.081 \text{ dscf}$$

Run #3:

$$V_{m(std)} = (17.64)(.980)(48.867) \left[ \frac{30.08 + \frac{2.22}{13.6}}{545} \right] = 46.878 \text{ dscf}$$



**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7 and 8, 1992  
**SOURCE:** BAGHOUSE

### TOTAL CONTAMINANTS BY WEIGHT: GRAIN LOADING

Particulate Concentration:  $C_s$  gr/dscf

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{M_n}{V_{m(\text{std})}} \right]$$

Where:

$C_s$  = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, gr/dscf.

$M_n$  = Total amount of particulate matter collected, mg.

$V_{m(\text{std})}$  = Dry gas volume through meter at standard conditions, cu. ft.

Run #1:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{8.00}{41.600} \right] = 0.0030 \text{ gr/dscf}$$

Run #2:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{8.90}{42.081} \right] = 0.0033 \text{ gr/dscf}$$

Run #3:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{6.20}{46.878} \right] = 0.0020 \text{ gr/dscf}$$

**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7-9, 1992  
**SOURCE:** BAGHOUSE

**33**

**Particulate Matter  
CONVERSION TO mg/m<sup>3</sup>**

$$C, \text{mg/m}^3 = (C, \text{gr/dscf}) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right)$$

Where:

C,mg/m<sup>3</sup> = Concentration as milligrams per cubic meter  
C,gr/dscf = Concentration as grains per cubic foot  
35.31 = Conversion of ft<sup>3</sup> to m<sup>3</sup>  
0.0154 = Conversion from grains to milligrams

Run #1:

$$C, \text{mg/m}^3 = (0.0030) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 6.88$$

Run #2:

$$C, \text{mg/m}^3 = (0.0033) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 7.57$$

Run #3:

$$C, \text{mg/m}^3 = (0.0020) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 4.59$$

NAME: APAC/MACASTHALT  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992  
SOURCE: BAGHOUSE

34

### TOTAL CONTAMINANTS BY WEIGHT: GRAIN LOADING

Condensible Particulate Concentration:  $C_s$  gr/dscf

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{M_n}{V_{m(\text{std})}} \right]$$

Where:

$C_s$  = Concentration of condensibles in stack gas, dry basis, corrected to standard conditions, gr/dscf.

$M_n$  = Total amount of condensible matter collected, mg.

$V_{m(\text{std})}$  = Dry gas volume through meter at standard conditions, cu. ft.

Run #1:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{68.4}{41.600} \right] = 0.0253 \text{ gr/dscf}$$

Run #2:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{44.9}{42.081} \right] = 0.0164 \text{ gr/dscf}$$

Run #3:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{39.2}{46.878} \right] = 0.0129 \text{ gr/dscf}$$

**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7-9, 1992  
**SOURCE:** BAGHOUSE

**35**

**Condensible Particulate  
CONVERSION TO mg/m<sup>3</sup>**

$$C, \text{mg/m}^3 = (C, \text{gr/dscf}) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right)$$

Where:

C,mg/m<sup>3</sup> = Concentration as milligrams per cubic meter  
C,gr/dscf = Concentration as grains per cubic foot  
35.31 = Conversion of ft<sup>3</sup> to m<sup>3</sup>  
0.0154 = Conversion from grains to milligrams

Run #1:

$$C, \text{mg/m}^3 = (0.0253) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 58.01$$

Run #2:

$$C, \text{mg/m}^3 = (0.0164) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 37.60$$

Run #3:

$$C, \text{mg/m}^3 = (0.0129) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 29.58$$

**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7 and 8, 1992  
**SOURCE:** BAGHOUSE

### DRY MOLECULAR WEIGHT

$$M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%CO + \%N_2)$$

Where:

- $M_d$  = Dry molecular weight, lb/lb-mole.
- $\%CO_2$  = Percent carbon dioxide by volume, dry basis.
- $\%O_2$  = Percent oxygen by volume, dry basis.
- $\%N_2$  = Percent nitrogen by volume, dry basis.
- $\%CO$  = Percent carbon monoxide by volume, dry basis.
- 0.264 = Ratio of  $O_2$  to  $N_2$  in air, v/v.
- 0.28 = Molecular weight of  $N_2$  or CO, divided by 100.
- 0.32 = Molecular weight of  $O_2$  divided by 100.
- 0.44 = Molecular weight of  $CO_2$  divided by 100.

Run #1:

$$M_d = 0.44 (8.60\%) + 0.32 (11.00\%) + 0.28 (0.00\% + 80.40\%) = 29.82 \frac{\text{lb}}{\text{lb-mole}}$$

Run #2:

$$M_d = 0.44 (7.00\%) + 0.32 (11.70\%) + 0.28 (0.00\% + 81.30\%) = 29.59 \frac{\text{lb}}{\text{lb-mole}}$$

Run #3:

$$M_d = 0.44 (5.50\%) + 0.32 (13.00\%) + 0.28 (0.00\% + 81.50\%) = 29.40 \frac{\text{lb}}{\text{lb-mole}}$$

NAME: APAC/MACASPHALT  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 7 and 8, 1992  
 SOURCE: BAGHOUSE

### WATER VAPOR CONDENSED

$$V_{wc_{std}} = [V_f - V_i] \left[ \frac{P_w R T_{(std)}}{M_w P_{(std)}} \right] - 0.04707 [V_f - V_i]$$

$$V_{wsg_{std}} = [W_f - W_i] \left[ \frac{R T_{(std)}}{M_w P_{(std)}} \right] - 0.04715 [W_f - W_i]$$

Where:

- 0.04707 = Conversion factor, ft<sup>3</sup>/ml.
- 0.04715 = Conversion factor, ft<sup>3</sup>/g.
- V<sub>wc<sub>std</sub></sub> = Volume of water vapor condensed (std. cond.), ml.
- V<sub>wsg<sub>std</sub></sub> = Volume of water vapor collected in silica gel (standard conditions), ml.
- V<sub>f</sub> - V<sub>i</sub> = Final volume of impinger contents less initial volume, ml.
- W<sub>f</sub> - W<sub>i</sub> = Final weight of silica gel less initial weight, g.
- P<sub>w</sub> = Density of water, 0.002201 lb/ml.
- R = Ideal gas constant, 21.85 in.Hg. (cu.ft./lb-mole)(°R).
- M<sub>w</sub> = Molecular weight of water vapor, 18.0 lb/lb-mole.
- T<sub>std</sub> = Absolute temperature at standard conditions, 528°R.
- P<sub>std</sub> = Absolute pressure at standard conditions, 29.92 inches Hg.

Run 1:

$$V_{wc_{std}} = (0.04707) (480.0) - 22.6 \text{ cu.ft}$$

$$V_{wsg_{std}} = (0.04715) (12.5) - 0.6 \text{ cu.ft}$$

Run 2:

$$V_{wc_{std}} = (0.04707) (470.0) - 22.1 \text{ cu.ft}$$

$$V_{wsg_{std}} = (0.04715) (1.5) - 0.1 \text{ cu.ft}$$

Run 3:

$$V_{wc_{std}} = (0.04707) (386.0) - 18.2 \text{ cu.ft}$$

$$V_{wsg_{std}} = (0.04715) (.8) - 0.0 \text{ cu.ft}$$

**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7 and 8, 1992  
**SOURCE:** BAGHOUSE

### MOISTURE CONTENT OF STACK GASES

$$B_{ws} = \left[ \frac{V_{wc_{std}} + V_{wsg_{std}}}{V_{wc_{std}} + V_{wsg_{std}} + V_{mstd}} \right] \times 100$$

Where:

$B_{ws}$  = Proportion of water vapor, by volume, in the gas stream.

$V_m$  = Dry gas volume measured by dry gas meter, dcf.

$V_{wc_{std}}$  = Volume of water vapor condensed, corrected to standard conditions, scf.

$V_{wsg_{std}}$  = Volume of water vapor collected in silica gel corrected to std. cond., scf.

Run 1:

$$B_{ws} = \left[ \frac{22.6 + 0.6}{22.6 + 0.6 + 41.600} \right] \times 100 = 35.80\%$$

Run 2:

$$B_{ws} = \left[ \frac{22.1 + 0.1}{22.1 + 0.1 + 42.081} \right] \times 100 = 34.54\%$$

Run 3:

$$B_{ws} = \left[ \frac{18.2 + 0.0}{18.2 + 0.0 + 46.878} \right] \times 100 = 27.97\%$$

**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7 and 8, 1992  
**SOURCE:** BAGHOUSE

### MOLECULAR WEIGHT OF STACK GASES

$$M_s = M_d (1 - B_{ws}) + 18 (B_{ws})$$

Where:

$M_s$  = Molecular weight of stack gas, wet basis (lb./lb.-mole).

$M_d$  = Molecular weight of stack gas, dry basis (lb./lb.-mole).

Run #1:

$$M_s = 29.82 (1 - 35.80) + 18 (35.80) = 25.59 \text{ (lb./lb.-mole)}$$

Run #2:

$$M_s = 29.59 (1 - 34.54) + 18 (34.54) = 25.59 \text{ (lb./lb.-mole)}$$

Run #1:

$$M_s = 29.40 (1 - 27.97) + 18 (27.97) = 26.21 \text{ (lb./lb.-mole)}$$



**NAME:** APAC/MACASPHALT  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7 and 8, 1992  
**SOURCE:** BAGHOUSE

### STACK GAS VELOCITY

$$V_s = K_p C_p [\sqrt{\Delta P}]_{\text{avg}} \sqrt{\frac{T_s(\text{avg})}{P_s M_s}}$$

Where:

- $V_s$  = Average velocity of gas stream in stack, ft/sec.  
 $K_p$  = 85.49 ft/sec [(g/g·mole) - (mm Hg)/(°K)(mm H<sub>2</sub>O)]<sup>1/2</sup>  
 $C_p$  = Pitot tube coefficient, dimensionless.  
 $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O.  
 $P_{\text{bar}}$  = Barometric pressure at measurement site, in. Hg.  
 $P_g$  = Stack static pressure, in. Hg.  
 $P_s$  = Absolute stack gas pressure, in. Hg. =  $P_{\text{bar}} + P_g$   
 $P_{\text{std}}$  = Standard absolute pressure, 29.92 in. Hg.  
 $t_s$  = Stack temperature, °F.  
 $T_s$  = Absolute stack temperature, °R. = 460 +  $t_s$ .  
 $M_s$  = Molecular weight of stack gas, wet basis, lb/lb·mole.

Run #1:

$$V = (85.49) (.84) (1.03) \sqrt{\frac{870}{(30.10)(25.59)}} = 78.60 \text{ ft/sec}$$

Run #2:

$$V = (85.49) (.84) (1.15) \sqrt{\frac{816}{(30.10)(25.59)}} = 84.99 \text{ ft/sec}$$

Run #3:

$$V = (85.49) (.84) (1.22) \sqrt{\frac{801}{(30.08)(26.21)}} = 88.30 \text{ ft/sec}$$

NAME: APAC/MACASPHALT  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7 and 8, 1992  
SOURCE: BAGHOUSE

### STACK GAS FLOW RATE

$$Q_{sd} = 3600 [1 - B_{wc}] V_s A \left[ \frac{T_{std}}{T_{stk}} \right] \left[ \frac{P_s}{P_{std}} \right]$$

Where:

- $Q_{sd}$  = Dry volumetric stack gas flow rate corrected to standard conditions (dscf/hr).  
 $A$  = Cross sectional area of stack (ft<sup>2</sup>).  
 $3600$  = Conversion factor (sec/hr).  
 $T_{stk}$  = Absolute stack temperature (°R).  
 $T_{std}$  = Standard absolute temperature (528°R).  
 $P_{bar}$  = Barometric pressure at measurement site (in. Hg.).  
 $P_g$  = Stack static pressure (in. Hg.).  
 $P_s$  = Absolute stack gas pressure (in. Hg.) =  $P_{bar} + P_g$   
 $P_{std}$  = Standard absolute pressure (29.92 in. Hg.).

Run #1:

$$Q_{sd} = 3600 (1 - .3580) (78.60) (11.34) \left[ \frac{528}{870} \right] \left[ \frac{30.10}{29.92} \right] = 1257745.3 \frac{\text{dscf}}{\text{hr}}$$

Run #2:

$$Q_{sd} = 3600 (1 - .3454) (84.99) (11.34) \left[ \frac{528}{816} \right] \left[ \frac{30.10}{29.92} \right] = 1478454.8 \frac{\text{dscf}}{\text{hr}}$$

Run #3:

$$Q_{sd} = 3600 (1 - .2797) (88.30) (11.34) \left[ \frac{528}{801} \right] \left[ \frac{30.08}{29.92} \right] = 1720708.6 \frac{\text{dscf}}{\text{hr}}$$

NAME: APAC/MACASPHALT  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7 and 8, 1992  
SOURCE: BAGHOUSE

### EMISSIONS RATE FROM STACK

$$E = \left[ \frac{(C_s) (Q_{sd})}{7,000 \text{ gr/lb}} \right] = 0.0000 \text{ lb/hr}$$

Where:

E = Emissions rate, lbs/hr.

C<sub>s</sub> = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, gr/dscf.

Q<sub>sd</sub> = Dry volumetric stack gas flow rate corrected to standard conditions, dscf/hr.

Run #1:

$$E = \left[ \frac{(0.0030) (1257745.3)}{7,000} \right] = 0.54 \text{ lbs/hr}$$

Run #2:

$$E = \left[ \frac{(0.0033) (1478454.8)}{7,000} \right] = 0.70 \text{ lbs/hr}$$

Run #3:

$$E = \left[ \frac{(0.0020) (1720708.6)}{7,000} \right] = 0.49 \text{ lbs/hr}$$

NAME: APAC/MACASPHALT  
 LOCATION: CROSS CANYON, FLORIDA

DATE: December 7-9, 1992  
 SOURCE: BAGHOUSE

**Condensible Particulate  
 EMISSIONS RATE FROM STACK**

$$E = \left[ \frac{(C_s) (Q_{sd})}{7,000 \text{ gr/lb}} \right] = 0.0000 \text{ lb/hr}$$

Where:

- E = Emissions rate, lbs/hr.
- C<sub>s</sub> = Concentration of Condensibles in stack gas, dry basis, corrected to standard conditions, gr/dscf.
- Q<sub>sd</sub> = Dry volumetric stack gas flow rate corrected to standard conditions, dscf/hr.

Run #1:

$$E = \frac{(0.0253) (1,257,745.3)}{7,000} = 4.55$$

Run #2:

$$E = \frac{(0.0164) (1,478,454.8)}{7,000} = 3.46$$

Run #3:

$$E = \frac{(0.0129) (1,720,708.6)}{7,000} = 3.17$$

NAME: APAC/MACASPHALT  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7 and 8, 1992  
SOURCE: BAGHOUSE

## ISOKINETIC VARIATION

$$I = 100 T_s \left[ \frac{(0.002669) (V_{ic} + (V_m/T_m) (P_{bar} + \Delta H/13.6))}{60 \theta V_s P_s A_n} \right]$$

Where:

- I = Percent isokinetic sampling.
- 100 = Conversion to percent.
- $T_s$  = Absolute average stack gas temperature, °R.
- 0.002669 = Conversion factor, Hg - ft<sup>3</sup>/ml - °R.
- $V_{ic}$  = Total volume of liquid collected in impingers and silica gel, ml.
- $T_m$  = Absolute average dry gas meter temperature, °R.
- $P_{bar}$  = Barometric pressure at sampling site, in. Hg.
- $\Delta H$  = Average pressure differential across the orifice meter, in. H<sub>2</sub>O.
- 13.6 = Specific gravity of mercury.
- 60 = Conversion seconds to minutes.
- $\theta$  = Total sampling time, minutes.
- $V_s$  = Stack gas velocity, ft/sec.
- $P_s$  = Absolute stack gas pressure, in. Hg.
- $A_n$  = Cross sectional area of nozzle, ft<sup>2</sup>.

Run #1:

$$I = (100) (870) \left[ \frac{(0.002669) (492.50) + \frac{44.679}{561} \left[ 30.10 + \frac{1.57}{13.6} \right]}{60 (60.0) (78.60) (30.10) (.000340)} \right] = 110\%$$

Run #2:

$$I = (100) (816) \left[ \frac{(0.002669) (471.50) + \frac{45.880}{570} \left[ 30.10 + \frac{1.93}{13.6} \right]}{60 (60.0) (84.99) (30.10) (.000340)} \right] = 95\%$$

Run #3:

$$I = (100) (801) \left[ \frac{(0.002669) (386.80) + \frac{48.867}{545} \left[ 30.08 + \frac{2.22}{13.6} \right]}{60 (60.0) (88.30) (30.08) (.000340)} \right] = 91\%$$

## **VI. CALCULATIONS**

### **B. Formaldehyde**

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## SUMMARY OF TEST DATA

|                                                      |                 | Run #1<br>12-09-92 | Run #2<br>12-09-92 | Run #3<br>12-09-92 |
|------------------------------------------------------|-----------------|--------------------|--------------------|--------------------|
| <b>SAMPLING TRAIN DATA</b>                           |                 |                    |                    |                    |
|                                                      | Start           | 12:48              | 14:24              | 16:11              |
|                                                      | Finish          | 13:53              | 15:34              | 17:06              |
| 1. Sampling time, minutes                            | $\theta$        | 60.0               | 60.0               | 50.0               |
| 2. Sampling nozzle diameter, in.                     | $D_n$           | .2610              | .2610              | .2610              |
| 3. Sampling nozzle cross-sect. area, ft <sup>2</sup> | $A_n$           | .000371            | .000371            | .000371            |
| 4. Isokinetic variation                              | $I$             | 91.8               | 102.8              | 97.2               |
| 5. Sample gas volume - meter cond., cf.              | $V_m$           | 56.029             | 57.583             | 41.790             |
| 6. Average meter temperature, °R                     | $T_m$           | 567                | 563                | 563                |
| 7. Avg. orifice pressure drop, in. H <sub>2</sub> O  | $\Delta H$      | 3.04               | 3.16               | 2.36               |
| 8. Total formaldehyde collected, mg.                 | $M_n$           | 8.80               | 8.80               | 5.80               |
| <b>VELOCITY TRAVERSE DATA</b>                        |                 |                    |                    |                    |
| 9. Stack area, ft. <sup>2</sup>                      | $A$             | 11.30              | 11.30              | 11.30              |
| 10. Absolute stack gas pressure, in. Hg.             | $P_s$           | 30.12              | 30.12              | 30.12              |
| 11. Barometric pressure, in. Hg.                     | $P_{bar}$       | 30.12              | 30.12              | 30.12              |
| 12. Avg. absolute stack temperature, R°              | $T_s$           | 727                | 736                | 796                |
| 13. Average vel. head, ( $C_p = .84$ )               | $\sqrt{dp}$     | 1.17               | 1.13               | 1.08               |
| 14. Average stack gas velocity, ft./sec.             | $V_s$           | 80.43              | 78.34              | 78.01              |
| <b>STACK MOISTURE CONTENT</b>                        |                 |                    |                    |                    |
| 15. Total water collected by train, ml.              | $V_{lc}$        | 424.90             | 503.40             | 366.60             |
| 16. Moisture in stack gas, %                         | $B_{ws}$        | 27.74              | 30.44              | 30.57              |
| <b>EMISSION DATA</b>                                 |                 |                    |                    |                    |
| 17. Stack gas flow rate, dscf/hr.                    | $Q_{sd}$        | 1728               | 1600               | 1471               |
| 18. Stack gas flow rate, cfm                         | acfm            | 54532              | 53115              | 52891              |
| 19. Formaldehyde concentration, gr/dscf              | $C_s$           | 0.0026             | 0.0025             | 0.0023             |
| 20. Formaldehyde concentration, lb/hr                | $E$             | 0.64               | 0.57               | 0.48               |
| <b>ORSAT DATA</b>                                    |                 |                    |                    |                    |
| 21. Percent CO <sub>2</sub> by volume                | CO <sub>2</sub> | 6.50               | 7.20               | 8.00               |
| 22. Percent O <sub>2</sub> by volume                 | O <sub>2</sub>  | 12.60              | 11.70              | 10.50              |
| 23. Percent CO by volume                             | CO              | .00                | .00                | .00                |
| 24. Percent N <sub>2</sub> by volume                 | N <sub>2</sub>  | 80.90              | 81.80              | 81.50              |

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

### MOISTURE DETERMINATION DRY GAS VOLUME

$$V_{m(std)} = V_m \left[ \frac{T_{(std)}}{T_m} \right] \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{P_{std}} \right] - 17.64 \frac{^{\circ}R}{\text{in. Hg}} Y V_m \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right]$$

Where:

- $V_{m(std)}$  = Dry gas volume through meter at standard conditions, ft<sup>3</sup>.  
 $V_m$  = Dry gas volume measured by meter, ft<sup>3</sup>.  
 $P_{bar}$  = Barometric pressure at orifice meter, in. Hg.  
 $P_{std}$  = Standard absolute pressure, (29.92 in. Hg.).  
 $T_m$  = Absolute temperature at meter, °R.  
 $T_{std}$  = Standard absolute temperature, (528°R).  
 $\Delta H$  = Avg. pressure drop across orifice meter, in. H<sub>2</sub>O.  
 $Y$  = Dry gas meter calibration factor.  
 13.6 = Inches of water per Hg.

Run #1:

$$V_{m(std)} = (17.64)(.985)(56.029) \left[ \frac{30.12 + \frac{3.04}{13.6}}{567} \right] = 52.099 \text{ dscf}$$

Run #2:

$$V_{m(std)} = (17.64)(.985)(57.583) \left[ \frac{30.12 + \frac{3.16}{13.6}}{563} \right] = 53.940 \text{ dscf}$$

Run #3:

$$V_{m(std)} = (17.64)(.985)(41.790) \left[ \frac{30.12 + \frac{2.36}{13.6}}{563} \right] = 39.070 \text{ dscf}$$



NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## TOTAL CONTAMINANTS BY WEIGHT: GRAIN LOADING

Formaldehyde Concentration:  $C_s$  gr/dscf

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{M_n}{V_{m(\text{std})}} \right]$$

Where:

$C_s$  = Concentration of formaldehyde in stack gas, dry basis, corrected to standard conditions, gr/dscf.

$M_n$  = Total amount of formaldehyde collected, mg.

$V_{m(\text{std})}$  = Dry gas volume through meter at standard conditions, cu. ft.

Run #1:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{8.80}{52.099} \right] = 0.0026 \text{ gr/dscf}$$

Run #2:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{8.80}{53.940} \right] = 0.0025 \text{ gr/dscf}$$

Run #3:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{5.80}{39.070} \right] = 0.0023 \text{ gr/dscf}$$

NAME: MACASPHALT (Formaldehyde)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

**Formaldehyde  
CONVERSION TO mg/m<sup>3</sup>**

$$C, \text{mg/m}^3 = (C, \text{gr/dscf}) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right)$$

Where:

C,mg/m<sup>3</sup> = Concentration as milligrams per cubic meter  
C,gr/dscf = Concentration as grains per cubic foot  
35.31 = Conversion of ft<sup>3</sup> to m<sup>3</sup>  
0.0154 = Conversion from grains to milligrams

Run #1:

$$C, \text{mg/m}^3 = (0.0026) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 5.96$$

Run #2:

$$C, \text{mg/m}^3 = (0.0025) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 5.73$$

Run #3:

$$C, \text{mg/m}^3 = (0.0023) \left( \frac{35.31 \text{ ft}^3}{\text{m}^3} \right) \left( \frac{\text{mg}}{0.0154 \text{ gr}} \right) = 5.27$$

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## Emissions of Formaldehyde: PPM (PARTS PER MILLION)

$$E = \frac{C_s}{1,000 \text{ mg}} \times \frac{\text{g}}{30.03 \text{ g}} \times \frac{\text{MOL}}{\text{MOL}} \times \frac{22.4 \text{ l}}{\text{MOL}} \times \frac{293^\circ\text{K}}{273^\circ\text{K}} \times \frac{\text{ft}^3}{28.317} \times 1,000,000$$

Where:

- $C_s$  = Concentration of formaldehyde in mg/dscf.  
 1000 mg/g = Conversion to grams.  
 30.03 g/MOL = Molar conversion for formaldehyde.  
 22.4 l/MOL = Volumetric molar conversion @ 273°K.  
 293°K/273°K = Temperature correction to standard conditions.  
 28.317/ft<sup>3</sup> = Conversion to liters.  
 1,000,000 = Conversion to parts per million.

Run #1:

$$\frac{8.8 \text{ mg}}{52.099 \text{ dscf}} \times \frac{\text{g}}{1,000 \text{ mg}} \times \frac{\text{MOL}}{30.03 \text{ g}} \times \frac{22.4 \text{ l}}{\text{MOL}} \times \frac{293^\circ\text{K}}{273^\circ\text{K}} \times \frac{\text{ft}^3}{28.317} \times 1,000,000 = 4.78 \text{ ppm}$$

Run #2:

$$\frac{8.8 \text{ mg}}{53.940 \text{ dscf}} \times \frac{\text{g}}{1,000 \text{ mg}} \times \frac{\text{MOL}}{30.03 \text{ g}} \times \frac{22.4 \text{ l}}{\text{MOL}} \times \frac{293^\circ\text{K}}{273^\circ\text{K}} \times \frac{\text{ft}^3}{28.317} \times 1,000,000 = 4.61 \text{ ppm}$$

Run #3:

$$\frac{5.8 \text{ mg}}{39.070 \text{ dscf}} \times \frac{\text{g}}{1,000 \text{ mg}} \times \frac{\text{MOL}}{30.03 \text{ g}} \times \frac{22.4 \text{ l}}{\text{MOL}} \times \frac{293^\circ\text{K}}{273^\circ\text{K}} \times \frac{\text{ft}^3}{28.317} \times 1,000,000 = 4.20 \text{ ppm}$$

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## DRY MOLECULAR WEIGHT

$$M_d = 0.44 (\% \text{CO}_2) + 0.32 (\% \text{O}_2) + 0.28 (\% \text{CO} + \% \text{N}_2)$$

Where:

- $M_d$  = Dry molecular weight, lb/lb-mole.  
 $\% \text{CO}_2$  = Percent carbon dioxide by volume, dry basis.  
 $\% \text{O}_2$  = Percent oxygen by volume, dry basis.  
 $\% \text{N}_2$  = Percent nitrogen by volume, dry basis.  
 $\% \text{CO}$  = Percent carbon monoxide by volume, dry basis.  
0.264 = Ratio of  $\text{O}_2$  to  $\text{N}_2$  in air, v/v.  
0.28 = Molecular weight of  $\text{N}_2$  or  $\text{CO}$ , divided by 100.  
0.32 = Molecular weight of  $\text{O}_2$  divided by 100.  
0.44 = Molecular weight of  $\text{CO}_2$  divided by 100.

Run #1:

$$M_d = 0.44 (6.50\%) + 0.32 (12.60\%) + 0.28 (0.00\% + 80.90\%) = 29.54 \frac{\text{lb}}{\text{lb-mole}}$$

Run #2:

$$M_d = 0.44 (7.20\%) + 0.32 (11.70\%) + 0.28 (0.00\% + 81.80\%) = 29.82 \frac{\text{lb}}{\text{lb-mole}}$$

Run #3:

$$M_d = 0.44 (8.00\%) + 0.32 (10.50\%) + 0.28 (0.00\% + 81.50\%) = 29.70 \frac{\text{lb}}{\text{lb-mole}}$$

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## WATER VAPOR CONDENSED

$$V_{wc_{std}} = [V_f - V_i] \left[ \frac{P_w R T_{(std)}}{M_w P_{(std)}} \right] - 0.04707 [V_f - V_i]$$

$$V_{wsg_{std}} = [W_f - W_i] \left[ \frac{R T_{(std)}}{M_w P_{(std)}} \right] - 0.04715 [W_f - W_i]$$

Where:

0.04707 = Conversion factor, ft<sup>3</sup>/ml.0.04715 = Conversion factor, ft<sup>3</sup>/g. $V_{wc_{std}}$  = Volume of water vapor condensed (std. cond.), ml. $V_{wsg_{std}}$  = Volume of water vapor collected in silica gel (standard conditions), ml. $V_f - V_i$  = Final volume of impinger contents less initial volume, ml. $W_f - W_i$  = Final weight of silica gel less initial weight, g. $P_w$  = Density of water, 0.002201 lb/ml. $R$  = Ideal gas constant, 21.85 in.Hg. (cu.ft./lb-mole)(°R). $M_w$  = Molecular weight of water vapor, 18.0 lb/lb-mole. $T_{std}$  = Absolute temperature at standard conditions, 528°R. $P_{std}$  = Absolute pressure at standard conditions, 29.92 inches Hg.

Run 1:

$$V_{wc_{std}} = (0.04707) (419.0) - 19.7 \text{ cu.ft}$$

$$V_{wsg_{std}} = (0.04715) (5.9) - 0.3 \text{ cu.ft}$$

Run 2:

$$V_{wc_{std}} = (0.04707) (496.0) - 23.3 \text{ cu.ft}$$

$$V_{wsg_{std}} = (0.04715) (7.4) - 0.3 \text{ cu.ft}$$

Run 3:

$$V_{wc_{std}} = (0.04707) (360.0) - 16.9 \text{ cu.ft}$$

$$V_{wsg_{std}} = (0.04715) (6.6) - 0.3 \text{ cu.ft}$$

NAME: MACASPHALT (Formaldehyde)  
LOCATION: CROSS CITY, FLORIDA

52

DATE: December 9, 1992

### MOISTURE CONTENT OF STACK GASES

$$B_{ws} = \left[ \frac{V_{wc_{std}} + V_{wsg_{std}}}{V_{wc_{std}} + V_{wsg_{std}} + V_{mstd}} \right] \times 100$$

Where:

$B_{ws}$  = Proportion of water vapor, by volume, in the gas stream.

$V_m$  = Dry gas volume measured by dry gas meter, dcf.

$V_{wc_{std}}$  = Volume of water vapor condensed, corrected to standard conditions, scf.

$V_{wsg_{std}}$  = Volume of water vapor collected in silica gel corrected to std. cond., scf.

Run 1:

$$B_{ws} = \left[ \frac{19.7 + 0.3}{19.7 + 0.3 + 52.099} \right] \times 100 = 27.74\%$$

Run 2:

$$B_{ws} = \left[ \frac{23.3 + 0.3}{23.3 + 0.3 + 53.940} \right] \times 100 = 30.44\%$$

Run 3:

$$B_{ws} = \left[ \frac{16.9 + 0.3}{16.9 + 0.3 + 39.070} \right] \times 100 = 30.57\%$$

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## MOLECULAR WEIGHT OF STACK GASES

$$M_s = M_d (1 - B_{ws}) + 18 (B_{ws})$$

Where:

 $M_s$  = Molecular weight of stack gas, wet basis (lb./lb.-mole). $M_d$  = Molecular weight of stack gas, dry basis (lb./lb.-mole).

Run #1:

$$M_s = 29.54 (1 - 27.74) + 18 (27.74) = 26.34 \text{ (lb./lb.-mole)}$$

Run #2:

$$M_s = 29.82 (1 - 30.44) + 18 (30.44) = 26.22 \text{ (lb./lb.-mole)}$$

Run #1:

$$M_s = 29.70 (1 - 30.57) + 18 (30.57) = 26.12 \text{ (lb./lb.-mole)}$$

NAME: MACASPHALT (Formaldehyde)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

### STACK GAS VELOCITY

$$V_s = K_p C_p [\sqrt{\Delta P}]_{\text{avg}} \sqrt{\frac{T_s(\text{avg})}{P_s M_s}}$$

Where:

- $V_s$  = Average velocity of gas stream in stack, ft/sec.
- $K_p$  = 85.49 ft/sec [(g/g·mole) - (mm Hg)/(°K)(mm H<sub>2</sub>O)]<sup>1/2</sup>
- $C_p$  = Pitot tube coefficient, dimensionless.
- $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O.
- $P_{\text{bar}}$  = Barometric pressure at measurement site, in. Hg.
- $P_g$  = Stack static pressure, in. Hg.
- $P_s$  = Absolute stack gas pressure, in. Hg. =  $P_{\text{bar}} + P_g$
- $P_{\text{std}}$  = Standard absolute pressure, 29.92 in. Hg.
- $t_s$  = Stack temperature, °F.
- $T_s$  = Absolute stack temperature, °R. = 460 +  $t_s$ .
- $M_s$  = Molecular weight of stack gas, wet basis, lb/lb·mole.

Run #1:

$$V = (85.49) (.84) (1.17) \sqrt{\frac{727}{(30.12)(26.34)}} = 80.43 \text{ ft/sec}$$

Run #2:

$$V = (85.49) (.84) (1.13) \sqrt{\frac{736}{(30.12)(26.22)}} = 78.34 \text{ ft/sec}$$

Run #3:

$$V = (85.49) (.84) (1.08) \sqrt{\frac{796}{(30.12)(26.12)}} = 78.01 \text{ ft/sec}$$



NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## STACK GAS FLOW RATE

$$Q_{sd} = 3600 [1 - B_{wc}] V_s A \left[ \frac{T_{std}}{T_{stk}} \right] \left[ \frac{P_s}{P_{std}} \right]$$

Where:

$Q_{sd}$  = Dry volumetric stack gas flow rate corrected to standard conditions (dscf/hr).

$A$  = Cross sectional area of stack (ft<sup>2</sup>).

3600 = Conversion factor (sec/hr).

$T_{stk}$  = Absolute stack temperature (°R).

$T_{std}$  = Standard absolute temperature (528°R).

$P_{bar}$  = Barometric pressure at measurement site (in. Hg.).

$P_g$  = Stack static pressure (in. Hg.).

$P_s$  = Absolute stack gas pressure (in. Hg.) =  $P_{bar} + P_g$

$P_{std}$  = Standard absolute pressure (29.92 in. Hg.).

Run #1:

$$Q_{sd} = 3600 (1 - .2774) (80.43) (11.30) \left[ \frac{528}{727} \right] \left[ \frac{30.12}{29.92} \right] = 1728581.5 \frac{\text{dscf}}{\text{hr}}$$

Run #2:

$$Q_{sd} = 3600 (1 - .3044) (78.34) (11.30) \left[ \frac{528}{736} \right] \left[ \frac{30.12}{29.92} \right] = 1600934.5 \frac{\text{dscf}}{\text{hr}}$$

Run #3:

$$Q_{sd} = 3600 (1 - .3057) (78.01) (11.30) \left[ \frac{528}{796} \right] \left[ \frac{30.12}{29.92} \right] = 1471270.8 \frac{\text{dscf}}{\text{hr}}$$

NAME: MACASPHALT (Formaldehyde)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

### EMISSIONS RATE FROM STACK

$$E = \left[ \frac{(C_s) (Q_{sd})}{7,000 \text{ gr/lb}} \right] = 0.0000 \text{ lb/hr}$$

Where:

E = Emissions rate, lbs/hr.

C<sub>s</sub> = Concentration of formaldehyde in stack gas, dry basis, corrected to standard conditions, gr/dscf.

Q<sub>sd</sub> = Dry volumetric stack gas flow rate corrected to standard conditions, dscf/hr.

Run #1:

$$E = \left[ \frac{(0.0026) (1728581.5)}{7,000} \right] = 0.64 \text{ lbs/hr}$$

Run #2:

$$E = \left[ \frac{(0.0025) (1600934.5)}{7,000} \right] = 0.57 \text{ lbs/hr}$$

Run #3:

$$E = \left[ \frac{(0.0023) (1471270.8)}{7,000} \right] = 0.48 \text{ lbs/hr}$$

NAME: MACASPHALT (Formaldehyde)

LOCATION: CROSS CITY, FLORIDA

DATE: December 9, 1992

## ISOKINETIC VARIATION

$$I = 100 T_s \left[ \frac{(0.002669) (V_{ic} + (V_m/T_m) (P_{bar} + \Delta H/13.6))}{60 \theta V_s P_s A_n} \right]$$

Where:

- I = Percent isokinetic sampling.  
 100 = Conversion to percent.  
 T<sub>s</sub> = Absolute average stack gas temperature, °R.  
 0.002669 = Conversion factor, Hg - ft<sup>3</sup>/ml - °R.  
 V<sub>ic</sub> = Total volume of liquid collected in impingers and silica gel, ml.  
 T<sub>m</sub> = Absolute average dry gas meter temperature, °R.  
 P<sub>bar</sub> = Barometric pressure at sampling site, in. Hg.  
 ΔH = Average pressure differential across the orifice meter, in. H<sub>2</sub>O.  
 13.6 = Specific gravity of mercury.  
 60 = Conversion seconds to minutes.  
 θ = Total sampling time, minutes.  
 V<sub>s</sub> = Stack gas velocity, ft/sec.  
 P<sub>s</sub> = Absolute stack gas pressure, in. Hg.  
 A<sub>n</sub> = Cross sectional area of nozzle, ft<sup>2</sup>.

Run #1:

$$I = (100) (727) \left[ \frac{(0.002669) (424.90) + \frac{56.029}{567} \left[ 30.12 + \frac{3.04}{13.6} \right]}{60 (60.0) (80.43) (30.12) (.000371)} \right] = 91.8\%$$

Run #2:

$$I = (100) (736) \left[ \frac{(0.002669) (503.4) + \frac{57.583}{563} \left[ 30.12 + \frac{3.16}{13.6} \right]}{60 (60.0) (78.34) (30.12) (.000371)} \right] = 102.8\%$$

Run #3:

$$I = (100) (796) \left[ \frac{(0.002669) (366.6) + \frac{41.790}{563} \left[ 30.12 + \frac{2.36}{13.6} \right]}{60 (50.0) (78.01) (30.12) (.000371)} \right] = 97.2\%$$

## **VI. CALCULATIONS**

### **C. PAH**

NAME: MACASPHALT (PAH)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### SUMMARY OF TEST DATA

|                                                      |                 | Run #1<br>12-08-92 | Run #2<br>12-08-92 | Run #3<br>12-09-92 |
|------------------------------------------------------|-----------------|--------------------|--------------------|--------------------|
| <b>SAMPLING TRAIN DATA</b>                           |                 |                    |                    |                    |
|                                                      | Start           | 11:24              | 13:34              | 09:46              |
|                                                      | Finish          | 12:37              | 17:11              | 12:16              |
| 1. Sampling time, minutes                            | $\theta$        | 60.0               | 90.0               | 90.0               |
| 2. Sampling nozzle diameter, in.                     | $D_n$           | .2500              | .2500              | .2500              |
| 3. Sampling nozzle cross-sect. area, ft <sup>2</sup> | $A_n$           | .000340            | .000340            | .000340            |
| 4. Isokinetic variation                              | $I$             | 96.5               | 99.5               | 90.7               |
| 5. Sample gas volume - meter cond., cf.              | $V_m$           | 53.020             | 80.649             | 75.812             |
| 6. Average meter temperature, °R                     | $T_m$           | 557                | 562                | 573                |
| 7. Avg. orifice pressure drop, in. H <sub>2</sub> O  | $\Delta H$      | 2.71               | 2.73               | 2.56               |
| 8. Total PAH's collected, mg.                        | $M_n$           | 0.99               | 1.54               | 1.57               |
| <b>VELOCITY TRAVERSE DATA</b>                        |                 |                    |                    |                    |
| 9. Stack area, ft. <sup>2</sup>                      | $A$             | 11.30              | 11.30              | 11.30              |
| 10. Absolute stack gas pressure, in. Hg.             | $P_s$           | 30.08              | 30.08              | 30.12              |
| 11. Barometric pressure, in. Hg.                     | $P_{bar}$       | 30.08              | 30.08              | 30.12              |
| 12. Avg. absolute stack temperature, R°              | $T_s$           | 719                | 724                | 730                |
| 13. Average vel. head, ( $C_p = .84$ )               | $\sqrt{dp}$     | 1.18               | 1.15               | 1.15               |
| 14. Average stack gas velocity, ft./sec.             | $V_s$           | 80.91              | 78.94              | 79.14              |
| <b>STACK MOISTURE CONTENT</b>                        |                 |                    |                    |                    |
| 15. Total water collected by train, ml.              | $V_{ic}$        | 434.20             | 641.10             | 557.30             |
| 16. Moisture in stack gas, %                         | $B_{ws}$        | 28.94              | 28.50              | 27.33              |
| <b>EMISSION DATA</b>                                 |                 |                    |                    |                    |
| 17. Stack gas flow rate, dscf/hr.                    | $Q_{sd}$        | 1726               | 1683               | 1703               |
| 18. Stack gas flow rate, cfm                         | acfm            | 54857              | 53521              | 53657              |
| 19. PAH concentration, gr/dscf                       | $C_s$           | 0.0003             | 0.0003             | 0.0003             |
| 20. PAH concentration, lb/hr                         | $E$             | 0.074              | 0.072              | 0.073              |
| 21. PAH concentration, lb/mBtu                       | $E'$            | 0.00000            | 0.00000            | 0.00000            |
| <b>ORSAT DATA</b>                                    |                 |                    |                    |                    |
| 22. Percent CO <sub>2</sub> by volume                | CO <sub>2</sub> | 6.60               | 7.10               | 6.50               |
| 23. Percent O <sub>2</sub> by volume                 | O <sub>2</sub>  | 12.80              | 13.30              | 12.80              |
| 24. Percent CO by volume                             | CO              | .00                | .00                | .00                |
| 25. Percent N <sub>2</sub> by volume                 | N <sub>2</sub>  | 80.60              | 79.60              | 80.70              |

MOISTURE DETERMINATION  
DRY GAS VOLUME

$$V_{m(std)} = V_m \left[ \frac{T_{(std)}}{T_m} \right] \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{P_{std}} \right] - 17.64 \frac{^{\circ}R}{\epsilon. Hg} Y V_m \left[ \frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right]$$

Where:

- $V_{m(std)}$  = Dry gas volume through meter at standard conditions, ft<sup>3</sup>.
- $V_m$  = Dry gas volume measured by meter, ft<sup>3</sup>.
- $P_{bar}$  = Barometric pressure at orifice meter, in. Hg.
- $P_{std}$  = Standard absolute pressure, (29.92 in. Hg.).
- $T_m$  = Absolute temperature at meter, °R.
- $T_{std}$  = Standard absolute temperature, (528°R).
- $\Delta H$  = Avg. pressure drop across orifice meter, in. H<sub>2</sub>O.
- $Y$  = Dry gas meter calibration factor.
- 13.6 = Inches of water per Hg.

Run #1:

$$V_{m(std)} = (17.64)(.985)(53.020) \left[ \frac{30.08 + \frac{2.71}{13.6}}{557} \right] = 50.080 \text{ dscf}$$

Run #2:

$$V_{m(std)} = (17.64)(.985)(80.649) \left[ \frac{30.08 + \frac{2.73}{13.6}}{562} \right] = 75.503 \text{ dscf}$$

Run #3:

$$V_{m(std)} = (17.64)(.985)(75.812) \left[ \frac{30.12 + \frac{2.56}{13.6}}{573} \right] = 69.675 \text{ dscf}$$

NAME: MACASPHALT (PAH)  
LOCATION: CROSS CITY, FLORIDA

60  
DATE: December 8-9, 1992

**TOTAL CONTAMINANTS BY WEIGHT: GRAIN LOADING**

PAH Concentration:  $C_s$  gr/dscf

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{M_n}{V_{m(\text{std})}} \right]$$

Where:

$C_s$  = Concentration of PAH's in stack gas, dry basis, corrected to standard conditions, gr/dscf.

$M_n$  = Total amount of PAH's collected, mg.

$V_{m(\text{std})}$  = Dry gas volume through meter at standard conditions, cu. ft.

Run #1:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{0.99}{50.080} \right] = 0.0003 \text{ gr/dscf}$$

Run #2:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{1.54}{75.503} \right] = 0.0003 \text{ gr/dscf}$$

Run #3:

$$C_s = \left[ 0.0154 \frac{\text{gr}}{\text{mg}} \right] \left[ \frac{1.57}{69.675} \right] = 0.0003 \text{ gr/dscf}$$

NAME: MACASPHALT (PAH)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### DRY MOLECULAR WEIGHT

$$M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%CO + \%N_2)$$

Where:

- $M_d$  = Dry molecular weight, lb/lb-mole.
- $\%CO_2$  = Percent carbon dioxide by volume, dry basis.
- $\%O_2$  = Percent oxygen by volume, dry basis.
- $\%N_2$  = Percent nitrogen by volume, dry basis.
- $\%CO$  = Percent carbon monoxide by volume, dry basis.
- 0.264 = Ratio of  $O_2$  to  $N_2$  in air, v/v.
- 0.28 = Molecular weight of  $N_2$  or CO, divided by 100.
- 0.32 = Molecular weight of  $O_2$  divided by 100.
- 0.44 = Molecular weight of  $CO_2$  divided by 100.

Run #1:

$$M_d = 0.44 (6.60\%) + 0.32 (12.80\%) + 0.28 (0.00\% + 80.60\%) = 29.57 \frac{\text{lb}}{\text{lb-mole}}$$

Run #2:

$$M_d = 0.44 (7.10\%) + 0.32 (13.30\%) + 0.28 (0.00\% + 79.60\%) = 29.67 \frac{\text{lb}}{\text{lb-mole}}$$

Run #3:

$$M_d = 0.44 (6.50\%) + 0.32 (12.80\%) + 0.28 (0.00\% + 80.70\%) = 29.55 \frac{\text{lb}}{\text{lb-mole}}$$



NAME: MACASPHALT (PAH)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### WATER VAPOR CONDENSED

$$V_{wc_{std}} = [V_f - V_i] \left[ \frac{P_w R T_{(std)}}{M_w P_{(std)}} \right] - 0.04707 [V_f - V_i]$$

$$V_{wsg_{std}} = [W_f - W_i] \left[ \frac{R T_{(std)}}{M_w P_{(std)}} \right] - 0.04715 [W_f - W_i]$$

Where:

- 0.04707 = Conversion factor, ft<sup>3</sup>/ml.
- 0.04715 = Conversion factor, ft<sup>3</sup>/g.
- $V_{wc_{std}}$  = Volume of water vapor condensed (std. cond.), ml.
- $V_{wsg_{std}}$  = Volume of water vapor collected in silica gel (standard conditions), ml.
- $V_f - V_i$  = Final volume of impinger contents less initial volume, ml.
- $W_f - W_i$  = Final weight of silica gel less initial weight, g.
- $P_w$  = Density of water, 0.002201 lb/ml.
- $R$  = Ideal gas constant, 21.85 in.Hg. (cu.ft./lb-mole)(°R).
- $M_w$  = Molecular weight of water vapor, 18.0 lb/lb-mole.
- $T_{std}$  = Absolute temperature at standard conditions, 528°R.
- $P_{std}$  = Absolute pressure at standard conditions, 29.92 inches Hg.

Run 1:

$$\begin{aligned} V_{wc_{std}} &= (0.04707) (427.0) - 20.1 \text{ cu.ft} \\ V_{wsg_{std}} &= (0.04715) (7.2) - 0.3 \text{ cu.ft} \end{aligned}$$

Run 2:

$$\begin{aligned} V_{wc_{std}} &= (0.04707) (632.0) - 29.7 \text{ cu.ft} \\ V_{wsg_{std}} &= (0.04715) (9.1) - 0.4 \text{ cu.ft} \end{aligned}$$

Run 3:

$$\begin{aligned} V_{wc_{std}} &= (0.04707) (549.0) - 25.8 \text{ cu.ft} \\ V_{wsg_{std}} &= (0.04715) (8.3) - 0.4 \text{ cu.ft} \end{aligned}$$

NAME: MACASPHALT (PAH)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### MOISTURE CONTENT OF STACK GASES

$$B_{ws} = \left[ \frac{V_{wc_{std}} + V_{wsg_{std}}}{V_{wc_{std}} + V_{wsg_{std}} + V_{mstd}} \right] \times 100$$

Where:

$B_{ws}$  = Proportion of water vapor, by volume, in the gas stream.

$V_m$  = Dry gas volume measured by dry gas meter, dcf.

$V_{wc_{std}}$  = Volume of water vapor condensed, corrected to standard conditions, scf.

$V_{wsg_{std}}$  = Volume of water vapor collected in silica gel corrected to std. cond., scf.

Run 1:

$$B_{ws} = \left[ \frac{20.1 + 0.3}{20.1 + 0.3 + 50.080} \right] \times 100 = 28.94\%$$

Run 2:

$$B_{ws} = \left[ \frac{29.7 + 0.4}{29.7 + 0.4 + 75.503} \right] \times 100 = 28.50\%$$

Run 3:

$$B_{ws} = \left[ \frac{25.8 + 0.4}{25.8 + 0.4 + 69.675} \right] \times 100 = 27.33\%$$

NAME: MACASPHALT (PAH)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### MOLECULAR WEIGHT OF STACK GASES

$$M_s = M_d (1 - B_{ws}) + 18 (B_{ws})$$

Where:

$M_s$  = Molecular weight of stack gas, wet basis (lb./lb.-mole).

$M_d$  = Molecular weight of stack gas, dry basis (lb./lb.-mole).

Run #1:

$$M_s = 29.57 (1 - 28.94) + 18 (28.94) = 26.22 \text{ (lb./lb.-mole)}$$

Run #2:

$$M_s = 29.67 (1 - 28.50) + 18 (28.50) = 26.34 \text{ (lb./lb.-mole)}$$

Run #1:

$$M_s = 29.55 (1 - 27.33) + 18 (27.33) = 26.39 \text{ (lb./lb.-mole)}$$

NAME: MACASPHALT (PAH)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### STACK GAS VELOCITY

$$V_s = K_p C_p [\sqrt{\Delta P}]_{\text{avg}} \sqrt{\frac{T_s(\text{avg})}{P_s M_s}}$$

Where:

- $V_s$  = Average velocity of gas stream in stack, ft/sec.
- $K_p$  = 85.49 ft/sec [(g/g·mole) - (mm Hg)/(°K)(mm H<sub>2</sub>O)]<sup>1/2</sup>
- $C_p$  = Pitot tube coefficient, dimensionless.
- $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O.
- $P_{\text{bar}}$  = Barometric pressure at measurement site, in. Hg.
- $P_g$  = Stack static pressure, in. Hg.
- $P_s$  = Absolute stack gas pressure, in. Hg. =  $P_{\text{bar}} + P_g$
- $P_{\text{std}}$  = Standard absolute pressure, 29.92 in. Hg.
- $t_s$  = Stack temperature, °F.
- $T_s$  = Absolute stack temperature, °R. = 460 +  $t_s$ .
- $M_s$  = Molecular weight of stack gas, wet basis, lb/lb·mole.

Run #1:

$$V = (85.49) (.84) (1.18) \sqrt{\frac{719}{(30.08)(26.22)}} = 80.91 \text{ ft/sec}$$

Run #2:

$$V = (85.49) (.84) (1.15) \sqrt{\frac{724}{(30.08)(26.34)}} = 78.94 \text{ ft/sec}$$

Run #3:

$$V = (85.49) (.84) (1.15) \sqrt{\frac{730}{(30.12)(26.39)}} = 79.14 \text{ ft/sec}$$

NAME: MACASPHALT (PAH)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### STACK GAS FLOW RATE

$$Q_{sd} = 3600 [1 - B_{wc}] V_s A \left[ \frac{T_{std}}{T_{stk}} \right] \left[ \frac{P_s}{P_{std}} \right]$$

Where:

$Q_{sd}$  = Dry volumetric stack gas flow rate corrected to standard conditions (dscf/hr).

$A$  = Cross sectional area of stack (ft<sup>2</sup>).

3600 = Conversion factor (sec/hr).

$T_{stk}$  = Absolute stack temperature (°R).

$T_{std}$  = Standard absolute temperature (528°R).

$P_{bar}$  = Barometric pressure at measurement site (in. Hg.).

$P_g$  = Stack static pressure (in. Hg.).

$P_s$  = Absolute stack gas pressure (in. Hg.) =  $P_{bar} + P_g$

$P_{std}$  = Standard absolute pressure (29.92 in. Hg.).

Run #1:

$$Q_{sd} = 3600 (1 - .2894) (80.91) (11.30) \left[ \frac{528}{719} \right] \left[ \frac{30.08}{29.92} \right] = 1726750.6 \frac{\text{dscf}}{\text{hr}}$$

Run #2:

$$Q_{sd} = 3600 (1 - .2850) (78.94) (11.30) \left[ \frac{528}{724} \right] \left[ \frac{30.08}{29.92} \right] = 1683432.5 \frac{\text{dscf}}{\text{hr}}$$

Run #3:

$$Q_{sd} = 3600 (1 - .2733) (79.14) (11.30) \left[ \frac{528}{730} \right] \left[ \frac{30.12}{29.92} \right] = 1703478.2 \frac{\text{dscf}}{\text{hr}}$$

NAME: MACASPHALT (PAH)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### EMISSIONS RATE FROM STACK

$$E = \left[ \frac{(C_s) (Q_{sd})}{7,000 \text{ gr/lb}} \right] = 0.0000 \text{ lb/hr}$$

Where:

- $E$  = Emissions rate, lbs/hr.
- $C_s$  = Concentration of PAH's in stack gas, dry basis, corrected to standard conditions, gr/dscf.
- $Q_{sd}$  = Dry volumetric stack gas flow rate corrected to standard conditions, dscf/hr.

Run #1:

$$E = \left[ \frac{(0.0003) (1726750.6)}{7,000} \right] = 0.074 \text{ lbs/hr}$$

Run #2:

$$E = \left[ \frac{(0.0003) (1683432.5)}{7,000} \right] = 0.072 \text{ lbs/hr}$$

Run #3:

$$E = \left[ \frac{(0.0003) (1703478.2)}{7,000} \right] = 0.073 \text{ lbs/hr}$$

NAME: MACASPHALT (PAH)  
 LOCATION: CROSS CITY, FLORIDA

DATE: December 8-9, 1992

### ISOKINETIC VARIATION

$$I = 100 T_s \left[ \frac{(0.002669) (V_{ic} + (V_m/T_m) (P_{bar} + \Delta H/13.6))}{60 \theta V_s P_s A_n} \right]$$

Where:

- I = Percent isokinetic sampling.
- 100 = Conversion to percent.
- $T_s$  = Absolute average stack gas temperature, °R.
- 0.002669 = Conversion factor, Hg - ft<sup>3</sup>/ml - °R.
- $V_{ic}$  = Total volume of liquid collected in impingers and silica gel, ml.
- $T_m$  = Absolute average dry gas meter temperature, °R.
- $P_{bar}$  = Barometric pressure at sampling site, in. Hg.
- $\Delta H$  = Average pressure differential across the orifice meter, in. H<sub>2</sub>O.
- 13.6 = Specific gravity of mercury.
- 60 = Conversion seconds to minutes.
- $\theta$  = Total sampling time, minutes.
- $V_s$  = Stack gas velocity, ft/sec.
- $P_s$  = Absolute stack gas pressure, in. Hg.
- $A_n$  = Cross sectional area of nozzle, ft<sup>2</sup>.

Run #1:

$$I = (100) (719) \left[ \frac{(0.002669) (434.20) + \frac{53.020}{557} \left[ 30.08 + \frac{2.71}{13.6} \right]}{60 (60.0) (80.91) (30.08) (.000340)} \right] = 96.5\%$$

Run #2:

$$I = (100) (724) \left[ \frac{(0.002669) (641.10) + \frac{80.649}{562} \left[ 30.08 + \frac{2.73}{13.6} \right]}{60 (90.0) (78.94) (30.08) (.000340)} \right] = 99.5\%$$

Run #3:

$$I = (100) (730) \left[ \frac{(0.002669) (557.30) + \frac{75.812}{2.56} \left[ 30.12 + \frac{2.56}{13.6} \right]}{60 (90.0) (79.14) (30.12) (.000340)} \right] = 90.7\%$$

## **VI. CALCULATIONS**

### **D. SO<sub>2</sub>, THC, CO, NO<sub>x</sub> AND CH<sub>4</sub>**



NAME: MACASPHALT (Gaseous Compounds)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**TOTAL HYDROCARBON EMISSIONS** - Convert ppm (wet) to ppm (dry)

$$\text{ppm}_d = \text{ppm}_w \left( \frac{100}{100 - B_{ws}} \right)$$

Where:

$\text{ppm}_d$  = Parts per million, dry basis, as carbon.

$\text{ppm}_w$  = Parts per million, wet basis, as carbon.

$B_{ws}$  = Proportion of water vapor, by volume, in the gas stream.

Run #1 =

$$(89.9) \left( \frac{100}{100 - 27.74} \right) = 124.4 \text{ ppm}_d$$

Run #2 =

$$(69.9) \left( \frac{100}{100 - 30.44} \right) = 100.5 \text{ ppm}_d$$

Run #3 =

$$(82.7) \left( \frac{100}{100 - 30.57} \right) = 119.1 \text{ ppm}_d$$

**NAME:** MACASPHALT (Gaseous Compounds)  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7-9, 1992

70

**TOTAL METHANE EMISSIONS** - Convert ppm (wet) to ppm (dry)

$$\text{ppm}_d = \text{ppm}_w \left( \frac{100}{100 - B_{ws}} \right)$$

Where:

$\text{ppm}_d$  = Parts per million, dry basis, as carbon.

$\text{ppm}_w$  = Parts per million, wet basis, as carbon.

$B_{ws}$  = Proportion of water vapor, by volume, in the gas stream.

Run #1 =

$$(29.29) \left( \frac{100}{100 - 27.74} \right) = 40.53 \text{ ppm}_d$$

Run #2 =

$$(25.00) \left( \frac{100}{100 - 30.44} \right) = 35.94 \text{ ppm}_d$$

Run #3 =

$$(51.27) \left( \frac{100}{100 - 30.57} \right) = 73.84 \text{ ppm}_d$$

NAME: MACASPHALT (Gaseous Compounds)

LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**CO**  
**GASEOUS CONCENTRATION CONVERSION TO mg/m<sup>3</sup>**

Example Calculation

|     |                    |                 |                         |       |        |         |          |                                  |
|-----|--------------------|-----------------|-------------------------|-------|--------|---------|----------|----------------------------------|
| ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 28.01 g | 1,000 mg | = $\frac{\text{mg}}{\text{m}^3}$ |
|     | 1x10 <sup>-6</sup> | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g        |                                  |

Where:

|                    |   |                                                 |
|--------------------|---|-------------------------------------------------|
| ppm                | = | Parts per million, dry basis                    |
| 1x10 <sup>-6</sup> | = | Conversion from parts per million               |
| 28.317             | = | Conversion of liters to ft <sup>3</sup>         |
| 35.3145            | = | Conversion of ft <sup>3</sup> to m <sup>3</sup> |
| 273/293°K          | = | Temperature correction to standard conditions   |
| 22.4 ℓ             | = | Volumetric molar conversion @ 273°K             |
| 28.01 g/mole       | = | Molecular weight of pollutant                   |
| 1,000 mg/g         | = | Conversion to milligrams                        |

Run #1:

|           |                    |                 |                         |       |        |         |         |                                          |
|-----------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|------------------------------------------|
| >1000 ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 28.01 g | 1000 mg | = >1165.1 $\frac{\text{mg}}{\text{m}^3}$ |
|           | 1x10 <sup>-6</sup> | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                          |

Run #2:

|           |                    |                 |                         |       |        |         |         |                                          |
|-----------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|------------------------------------------|
| >1000 ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 28.01 g | 1000 mg | = >1165.1 $\frac{\text{mg}}{\text{m}^3}$ |
|           | 1x10 <sup>-6</sup> | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                          |

Run #3:

|           |                    |                 |                         |       |        |         |         |                                          |
|-----------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|------------------------------------------|
| >1000 ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 28.01 g | 1000 mg | = >1165.1 $\frac{\text{mg}}{\text{m}^3}$ |
|           | 1x10 <sup>-6</sup> | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                          |

NAME: MACASPHALT (Gaseous Compounds)

LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**NO<sub>x</sub>**  
**GASEOUS CONCENTRATION CONVERSION TO mg/m<sup>3</sup>**

Example Calculation

|     |                    |                 |                         |       |        |         |          |                                  |
|-----|--------------------|-----------------|-------------------------|-------|--------|---------|----------|----------------------------------|
| ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 46.01 g | 1,000 mg | = $\frac{\text{mg}}{\text{m}^3}$ |
|     | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g        |                                  |

Where:

|                    |   |                                                 |
|--------------------|---|-------------------------------------------------|
| ppm                | = | Parts per million, dry basis                    |
| $1 \times 10^{-6}$ | = | Conversion from parts per million               |
| 28.317             | = | Conversion of liters to ft <sup>3</sup>         |
| 35.3145            | = | Conversion of ft <sup>3</sup> to m <sup>3</sup> |
| 273/293°K          | = | Temperature correction to standard conditions   |
| 22.4 ℓ             | = | Volumetric molar conversion @ 273°K             |
| 46.01 g/mole       | = | Molecular weight of pollutant                   |
| 1,000 mg/g         | = | Conversion to milligrams                        |

Run #1:

|      |                    |                 |                         |       |        |         |         |                                        |
|------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|----------------------------------------|
| 79.2 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 46.01 g | 1000 mg | = 151.6 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm  | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                        |

Run #2:

|      |                    |                 |                         |       |        |         |         |                                        |
|------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|----------------------------------------|
| 82.7 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 46.01 g | 1000 mg | = 158.3 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm  | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                        |

Run #3:

|      |                    |                 |                         |       |        |         |         |                                        |
|------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|----------------------------------------|
| 78.5 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 46.01 g | 1000 mg | = 150.2 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm  | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                        |

NAME: MACASPHALT (Gaseous Compounds)

LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**TOTAL HYDROCARBONS (as CH<sub>4</sub>)  
GASEOUS CONCENTRATION CONVERSION TO mg/m<sup>3</sup>**

Example Calculation

|     |                    |                 |                         |       |        |         |          |                                  |
|-----|--------------------|-----------------|-------------------------|-------|--------|---------|----------|----------------------------------|
| ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1,000 mg | = $\frac{\text{mg}}{\text{m}^3}$ |
|     | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g        |                                  |

Where:

- ppm = Parts per million, dry basis  
 $1 \times 10^{-6}$  = Conversion from parts per million  
 28.317 = Conversion of liters to ft<sup>3</sup>  
 35,3145 = Conversion of ft<sup>3</sup> to m<sup>3</sup>  
 273/293°K = Temperature correction to standard conditions  
 22.4 ℓ = Volumetric molar conversion @ 273°K  
 16.04 g/mole = Molecular weight of pollutant (CH<sub>4</sub>)  
 1,000 mg/g = Conversion to milligrams

Run #1:

|       |                    |                 |                         |       |        |         |         |                                       |
|-------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|---------------------------------------|
| 124.4 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1000 mg | = 83.0 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm   | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                       |

Run #2:

|       |                    |                 |                         |       |        |         |         |                                       |
|-------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|---------------------------------------|
| 100.5 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1000 mg | = 67.1 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm   | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                       |

Run #3:

|       |                    |                 |                         |       |        |         |         |                                       |
|-------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|---------------------------------------|
| 119.1 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1000 mg | = 79.5 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm   | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                       |

NAME: MACASPHALT (Gaseous Compounds)

LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

# **METHANE** **GASEOUS CONCENTRATION CONVERSION TO mg/m<sup>3</sup>**

## Example Calculation

|     |                    |                 |                         |       |        |         |          |                                  |
|-----|--------------------|-----------------|-------------------------|-------|--------|---------|----------|----------------------------------|
| ppm | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1,000 mg | = $\frac{\text{mg}}{\text{m}^3}$ |
|     | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g        |                                  |

Where:

|                    |   |                                                  |
|--------------------|---|--------------------------------------------------|
| ppm                | = | Parts per million; dry basis                     |
| $1 \times 10^{-6}$ | = | Conversion from parts per million                |
| 28.317             | = | Conversion of liters to ft <sup>3</sup>          |
| 35,3145            | = | Conversion of ft <sup>3</sup> to m <sup>3</sup>  |
| 273/293°K          | = | Temperature correction to standard conditions    |
| 22.4ℓ              | = | Volumetric molar conversion @ 273°K              |
| 16.04 g/mole       | = | Molecular weight of pollutant (CH <sub>4</sub> ) |
| 1,000 mg/g         | = | Conversion to milligrams                         |

Run #1:

|       |                    |                 |                         |       |        |         |         |                                       |
|-------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|---------------------------------------|
| 40.53 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1000 mg | = 27.0 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm   | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                       |

Run #2:

|       |                    |                 |                         |       |        |         |         |                                       |
|-------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|---------------------------------------|
| 35.94 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1000 mg | = 24.0 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm   | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                       |

Run #3:

|       |                    |                 |                         |       |        |         |         |                                       |
|-------|--------------------|-----------------|-------------------------|-------|--------|---------|---------|---------------------------------------|
| 73.84 | 1                  | 28.317 ℓ        | 35.3145 ft <sup>3</sup> | 273°K | mole   | 16.04 g | 1000 mg | = 49.3 $\frac{\text{mg}}{\text{m}^3}$ |
| ppm   | $1 \times 10^{-6}$ | ft <sup>3</sup> | m <sup>3</sup>          | 293°K | 22.4 ℓ | mole    | g       |                                       |

NAME: MACASPHALT (Gaseous Compounds)

LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**TOTAL CARBON MONOXIDE EMISSIONS: POUNDS PER HOUR**

$$E = (2.59 \times 10^{-9})(M_d)(\text{ppm}_d)(Q_{sd})(K)$$

Where:

 $E$  = CO emissions rate, lbs/hr. $2.59 \times 10^{-9}$  = Conversion factor, lbs/dscf. $M_d$  = Dry molecular weight (CO = 28.01). $Q_{sd}$  = Dry volumetric stack gas flow rate  
corrected to standard conditions, dscf/hr. $\text{ppm}_d$  = Parts per million, dry basis. $K$  = Constant (typically 1).

Run #1:

$$E = (2.59 \times 10^{-9})(28.01)(>1000)(1,728,581.5) \Rightarrow 125.4 \text{ lbs/hr}$$

Run #2:

$$E = (2.59 \times 10^{-9})(28.01)(>1000)(1,600,934.5) \Rightarrow 116.1 \text{ lbs/hr}$$

Run #3:

$$E = (2.59 \times 10^{-9})(28.01)(>1000)(1,471,270.8) \Rightarrow 106.7 \text{ lbs/hr}$$

NAME: MACASPHALT (Gaseous Compounds)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**TOTAL NO<sub>x</sub> EMISSIONS: POUNDS PER HOUR**

$$E = (2.59 \times 10^{-9})(M_d)(\text{ppm}_d)(Q_{sd})(K)$$

Where:

E = NO<sub>x</sub> as NO<sub>2</sub> emissions rate, lbs/hr.

$2.59 \times 10^{-9}$  = Conversion factor, lbs/dscf.

M<sub>d</sub> = Dry molecular weight (NO<sub>2</sub> = 46.01).

Q<sub>sd</sub> = Dry volumetric stack gas flow rate  
corrected to standard conditions, dscf/hr.

ppm<sub>d</sub> = Parts per million, dry basis.

K = Constant (typically 1).

Run #1:

$$E = (2.59 \times 10^{-9}) (46.01) (79.2) (1,728,581.5) = 16.31 \text{ lbs/hr}$$

Run #2:

$$E = (2.59 \times 10^{-9}) (46.01) (82.7) (1,600,934.5) = 15.78 \text{ lbs/hr}$$

Run #3:

$$E = (2.59 \times 10^{-9}) (46.01) (78.5) (1,471,270.8) = 13.76 \text{ lbs/hr}$$



NAME: MACASPHALT (Gaseous Compounds)  
LOCATION: CROSS CITY, FLORIDA

DATE: December 7-9, 1992

**TOTAL HYDROCARBON EMISSIONS: POUNDS PER HOUR**

$$E = (2.59 \times 10^{-9})(M_d)(\text{ppm}_d)(Q_{sd})(K)$$

Where:

$E$  = THC as  $\text{CH}_4$  emissions rate, lbs/hr.

$2.59 \times 10^{-9}$  = Conversion factor, lbs/dscf.

$M_d$  = Dry molecular weight ( $\text{CH}_4 = 16.04$ ).

$Q_{sd}$  = Dry volumetric stack gas flow rate  
corrected to standard conditions, dscf/hr.

$\text{ppm}_d$  = Parts per million, dry basis.

$K$  = Constant (typically 1).

Run #1:

$$E = (2.59 \times 10^{-9})(16.04)(124.4)(1,728,581.5) = 8.93 \text{ lbs/hr}$$

Run #2:

$$E = (2.59 \times 10^{-9})(16.04)(100.5)(1,600,934.5) = 6.68 \text{ lbs/hr}$$

Run #3:

$$E = (2.59 \times 10^{-9})(16.04)(119.1)(1,471,270.8) = 7.28 \text{ lbs/hr}$$

**NAME:** MACASPHALT (Gaseous Compounds)  
**LOCATION:** CROSS CITY, FLORIDA

**DATE:** December 7-9, 1992

78

**TOTAL METHANE EMISSIONS: POUNDS PER HOUR**

$$E = (2.59 \times 10^{-9})(M_d)(\text{ppm}_d)(Q_{sd})(K)$$

Where:

$E$  =  $\text{CH}_4$  emissions rate, lbs/hr.

$2.59 \times 10^{-9}$  = Conversion factor, lbs/dscf.

$M_d$  = Dry molecular weight ( $\text{CH}_4 = 16.04$ ).

$Q_{sd}$  = Dry volumetric stack gas flow rate  
corrected to standard conditions, dscf/hr.

$\text{ppm}_d$  = Parts per million, dry basis.

$K$  = Constant (typically 1).

Run #1:

$$E = (2.59 \times 10^{-9})(16.04)(40.53)(1,728,581.5) = 2.91 \text{ lbs/hr}$$

Run #2:


$$E = (2.59 \times 10^{-9})(16.04)(35.94)(1,600,934.5) = 2.39 \text{ lbs/hr}$$

Run #3:

$$E = (2.59 \times 10^{-9})(16.04)(73.84)(1,471,270.8) = 4.51 \text{ lbs/hr}$$

## **VII. LABORATORY ANALYSIS RESULTS**

### **A. Formaldehyde Analysis Results**



8600 Kanis Road  
Little Rock, AR 72204-2322  
(501) 224-5060

Ramcon Environmental Corporation (C-488)  
6707 Fletcher Creek Cove  
Memphis, TN 38134

December 28, 1992

ATTN: Mr. Joe Sewell

Control No. 11643

Sample Description: Six (6) impinger solutions received on 12/17/92  
Plant: Mac Asphalt - NAPA; P.O. Nos. 080102, 080103

Results:

| <u>Sample Identification</u> | <u>Volume, ml</u> | <u>Formaldehyde, mg</u> |
|------------------------------|-------------------|-------------------------|
| Run 1, 12/9/92               | 530               | 8.8                     |
| Run 2, 12/9/92               | 700               | 8.8                     |
| Run 3, 12/9/92               | 685               | 5.8                     |
| Run 1, 12/4/92               | 495               | 0.063                   |
| Run 2, 12/4/92               | 495               | 4.2                     |
| Run 3, 12/4/92               | 575               | 0.60                    |

Method: 40 CFR Part 266, Appendix IX Section 3.6 Method 0011A

AMERICAN INTERPLEX CORPORATION

SL/td

By

A handwritten signature in cursive script that reads 'Steven Lovell'.

Steven Lovell  
Technical Director

## **VII. LABORATORY ANALYSIS RESULTS**

### **B. PAH Analysis Results**

Triangle Laboratories of RTP, Inc.  
801 Capitola Dr.  
Durham, NC 27713  
(919) 544-5729

Sample File : GL502  
Response File : GL500  
Date Analyzed : 01/03/93  
Date Reported : 01/06/93  
Project Number: 22651

Sample ID: RUN#1  
TLI ID: 62.25.2A-I  
Dilution Factor: 10.00

80


Quantitation Results Method 8270

| Analyte                | Area  | RF    | SCAN | ISID | Amt. Code<br>(ug) | Quan Limit | FLAG |
|------------------------|-------|-------|------|------|-------------------|------------|------|
| 1,4-Dichlorobenzene-d4 | 3036  |       | 420  | 1    | I                 |            |      |
| Naphthalene-d8         | 12952 |       | 599  | 2    | I                 |            |      |
| 2-Methylnaphthalene    | 8987  | 0.679 | 704  | 2    | 408.75 D          | 100.0      |      |
| Naphthalene            | 11458 | 1.001 | 602  | 2    | 353.52 D          | 100.0      |      |
| Acenaphthene-d10       | 7070  |       | 856  | 3    | I                 |            |      |
| Acenaphthene           | 0     | 0.957 | 0    | 3    | 1.18 ND           | 100.0      |      |
| Fluorene               | 847   | 1.180 | 938  | 3    | 40.62 E           | 100.0      |      |
| 2-Chloronaphthalene    | 0     | 0.971 | 0    | 3    | 1.17 ND           | 100.0      |      |
| Acenaphthylene         | 1455  | 1.680 | 835  | 3    | 49.02 E           | 100.0      |      |
| Phenanthrene-d10       | 13791 |       | 1076 | 4    | I                 |            |      |
| Phenanthrene           | 4093  | 0.921 | 1079 | 4    | 128.90 D          | 100.0      |      |
| Anthracene             | 271   | 0.944 | 1086 | 4    | 8.34 E            | 100.0      |      |
| Fluoranthene           | 0     | 1.115 | 0    | 4    | 0.52 ND           | 100.0      |      |
| Chrysene-d12           | 14855 |       | 1470 | 5    | I                 |            |      |
| Chrysene               | 0     | 0.995 | 0    | 5    | 0.54 ND           | 100.0      |      |
| Pyrene                 | 0     | 1.167 | 0    | 5    | 0.46 ND           | 100.0      |      |
| Benzo(a)anthracene     | 0     | 0.978 | 0    | 5    | 0.55 ND           | 100.0      |      |
| Perylene-d12           | 8969  |       | 1740 | 6    | I                 |            |      |
| Benzo(b)fluoranthene   | 0     | 1.380 | 0    | 6    | 0.65 ND           | 100.0      |      |
| Benzo(k)fluoranthene   | 0     | 1.785 | 0    | 6    | 0.50 ND           | 100.0      |      |
| Benzo(e)pyrene         | 0     | 1.423 | 0    | 6    | 0.63 ND           | 100.0      |      |
| Benzo(a)pyrene         | 0     | 1.321 | 0    | 6    | 0.68 ND           | 100.0      |      |
| Perylene               | 0     | 0.688 | 0    | 6    | 1.30 ND           | 100.0      |      |
| Indeno(1,2,3-cd)pyrene | 0     | 0.876 | 0    | 6    | 1.02 ND           | 100.0      |      |
| Dibenz(a,h)anthracene  | 0     | 0.875 | 0    | 6    | 1.02 ND           | 100.0      |      |
| Benzo(g,h,i)perylene   | 0     | 1.068 | 0    | 6    | 0.84 ND           | 100.0      |      |

| Surrogate Summary | Area | RF    | SCAN | ISID | Amount<br>(ug) | Code | %REC  |
|-------------------|------|-------|------|------|----------------|------|-------|
| Anthracene-d10    | 1904 | 0.508 | 1084 | 4    | 108.72 D       |      | 108.7 |
| Pyrene-d10        | 2762 | 1.066 | 1285 | 5    | 69.77 D        |      | 69.8  |

Received by JS Date 1.6.93  
ND - Not Detected; D - Detected; E - Estimated; I - Internal Standard

Orgrep v2.5







13 Jan 73 21:18

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: MM III (1:10 DIL.) 22651

Instrument G

Q1502 602 (12.034)

128

450560

XFS

51

64

102

127 129

M/Z

50

100

150

200

250

300

350

400

450

500

Q1502 602 (12.034) HEPTANE

128

446464

XFS

51

64

102

127 129

M/Z

50

100

150

200

250

300

350

400

450

500

Q1502 602 (12.034) Naphthalene

128

446464

XFS

51

64

102

127 129

M/Z

50

100

150

200

250

300

350

400

450

500

103-Jan-93 21:18

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: RMH #1 (1:10 DIL.)

22651


Instrument G

Q1502 764 (13.734)

100


142

386928



REFINE

376032



2-Methylnaphthalene

1000



13-Jan-93 21:10


Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: MM #1 (1:16 D.I.) Z2651


Instrument G

Q1502 835 (15.918)




483304

47872



Q1502 835 (15.918) Acenaphthylene

47872



483304

03-Jan-93 21:18


Triangle Laboratories of HPL, Inc.

(919) 544-5729


Sample: MMH #1 (1:10 HPL.) 22651

Instrument G


GLC#2 938 (17.634)



GLC#2 938 (17.634) Ref:MMH



Ref:MMH 24 (17.651) Fluorene



03-Jan-93 21:18

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: MUN #1 (1:10 DIL.)


22651

Instrument G

C15H12 1079 (19.905)

178


173056



C15H12 1079 (19.984) NHTMP

178


171000



NHTMP 26 (20.001) Phenanthrene

178

100



03 Jan-93 21:18

Triangle Laboratories of RTI, Inc.


(919) 544-5729

Sample: RMH #1 (1:10 DIL.)


22651

Instrument G


C1002 1006 (20.101)



C1002 1006 (20.101) REFINE



MULTI 27 (20.135) Anthracene



FIND

Triangle Laboratories of RTP, Inc.  
801 Capitola Dr.  
Durham, NC 27713  
(919) 544-5729

Sample File : GL503  
Response File : GL500  
Date Analyzed : 01/03/93  
Date Reported : 01/06/93  
Project Number: 22651

Sample ID: RUN#2  
TLI ID: 62.25.3A-I  
Dilution Factor: 10.00

89

Quantitation Results Method 8270


| Analyte                | Area  | RF    | SCAN | ISID | Amt. Code<br>(ug) | Quan<br>Limit | FLAG |
|------------------------|-------|-------|------|------|-------------------|---------------|------|
| 1,4-Dichlorobenzene-d4 | 3046  |       | 420  | 1    | I                 |               |      |
| Naphthalene-d8         | 13706 |       | 599  | 2    | I                 |               |      |
| 2-Methylnaphthalene    | 14772 | 0.679 | 704  | 2    | 634.94 D          | 100.0         |      |
| Naphthalene            | 18993 | 1.001 | 602  | 2    | 553.75 D          | 100.0         |      |
| Acenaphthene-d10       | 7068  |       | 856  | 3    | I                 |               |      |
| Acenaphthene           | 0     | 0.957 | 0    | 3    | 1.18 ND           | 100.0         |      |
| Fluorene               | 1293  | 1.180 | 938  | 3    | 62.05 E           | 100.0         |      |
| 2-Chloronaphthalene    | 0     | 0.971 | 0    | 3    | 1.17 ND           | 100.0         |      |
| Acenaphthylene         | 2151  | 1.680 | 834  | 3    | 72.46 E           | 100.0         |      |
| Phenanthrene-d10       | 13767 |       | 1076 | 4    | I                 |               |      |
| Phenanthrene           | 6279  | 0.921 | 1079 | 4    | 198.07 D          | 100.0         |      |
| Anthracene             | 415   | 0.944 | 1086 | 4    | 12.77 E           | 100.0         |      |
| Fluoranthene           | 0     | 1.115 | 0    | 4    | 0.52 ND           | 100.0         |      |
| Chrysene-d12           | 16042 |       | 1470 | 5    | I                 |               |      |
| Chrysene               | 0     | 0.995 | 0    | 5    | 0.50 ND           | 100.0         |      |
| Pyrene                 | 352   | 1.167 | 1287 | 5    | 7.54 E            | 100.0         |      |
| Benzo(a)anthracene     | 0     | 0.978 | 0    | 5    | 0.51 ND           | 100.0         |      |
| Perylene-d12           | 9631  |       | 1740 | 6    | I                 |               |      |
| Benzo(b)fluoranthene   | 0     | 1.380 | 0    | 6    | 0.60 ND           | 100.0         |      |
| Benzo(k)fluoranthene   | 0     | 1.785 | 0    | 6    | 0.47 ND           | 100.0         |      |
| Benzo(e)pyrene         | 0     | 1.423 | 0    | 6    | 0.58 ND           | 100.0         |      |
| Benzo(a)pyrene         | 0     | 1.321 | 0    | 6    | 0.63 ND           | 100.0         |      |
| Perylene               | 0     | 0.688 | 0    | 6    | 1.21 ND           | 100.0         |      |
| Indeno(1,2,3-cd)pyrene | 0     | 0.876 | 0    | 6    | 0.95 ND           | 100.0         |      |
| Dibenz(a,h)anthracene  | 0     | 0.875 | 0    | 6    | 0.95 ND           | 100.0         |      |
| Benzo(g,h,i)perylene   | 0     | 1.068 | 0    | 6    | 0.78 ND           | 100.0         |      |

| Surrogate Summary | Area | RF    | SCAN | ISID | Amount<br>(ug) | Code | %REC  |
|-------------------|------|-------|------|------|----------------|------|-------|
| Anthracene-d10    | 1881 | 0.508 | 1084 | 4    | 107.61 D       |      | 107.6 |
| Pyrene-d10        | 2952 | 1.066 | 1285 | 5    | 69.05 D        |      | 69.1  |

Reveiwed by JL Date 1/6/93  
ND -Not Detected; D- Detected; E- Estimated; I- Internal Standard

Orgrep v2.5

88-Jan-93 22:07 Triangle Laboratories of RTP, Inc. (919) 544-5729  
 Sample: MM #2 (1:10 dil.) 22651 Instrument G



DL 1-5-93



| NO. | Wt  | FOR | FL | Det | Mass P. Frag.       | Scan           | Or Name                       |
|-----|-----|-----|----|-----|---------------------|----------------|-------------------------------|
| 1   | 100 | 70  | 94 | 0   | 304620 bv           | 420            | 132 1,4-Dichlorobenzene-d4    |
| 2   | 98  | 75  | 94 | 0   | 1370600 bv          | 599            | 136 Naphthalene-d8            |
| 3   | 89  | 59  | 95 | -1  | 706850 bv           | 858            | 104 Acenaphthene-d10          |
| 4   | 100 | 72  | 97 | -1  | 1370800 bv          | 1076           | 188 Phenanthrene-d10          |
| 5   | 97  | 85  | 96 | -2  | 1004200 bp          | 1470           | 240 Chrysene-d12              |
| 6   | 100 | 83  | 93 | 0   | 963150 bv           | 1740           | 264 Perylene-d12              |
| 7   | 0   | 0   | 0  | 0   | 0                   | 0              | 112 1-Fluorophenol            |
| 8   | 0   | 0   | 0  | 0   | 0                   | 0              | 132 2-Chlorophenol-d4         |
| 9   | 0   | 0   | 0  | 0   | 0                   | 0              | 99 Phenol-d5                  |
| 10  | 0   | 0   | 0  | 0   | 0                   | 0              | 152 1,2-Dichlorobenzene-d4    |
| 11  | 0   | 0   | 0  | 0   | 0                   | 0              | 82 Nitrobenzene-d5            |
| 12  | 0   | 0   | 0  | 0   | 0                   | 0              | 185 1,3,5-Trichlorobenzene-d3 |
| 13  | 0   | 0   | 0  | 0   | 0                   | 0              | 240 1,4-Dibromobenzene-d4     |
| 14  | 0   | 0   | 0  | 0   | 0                   | 0              | 172 2-Fluorobiphenyl          |
| 15  | 0   | 0   | 0  | 0   | 0                   | 0              | 330 2,4,6-Tribromophenol      |
| 16  | 74  | 36  | 91 | -1  | 188160 vb           | 1084           | 188 Anthracene-d10            |
| 17  | 96  | 59  | 95 | 0   | 295220 vb           | 1285           | 212 Pyrene-d10                |
| 18  | 0   | 0   | 0  | 0   | 0                   | 0              | 244 Terphenyl-d14             |
| 19  | 100 | 78  | 99 | 0   | 1899400 vv          | 602            | 128 Naphthalene               |
| 20  | 100 | 81  | 93 | -1  | 1477300 vv          | 704            | 142 2-Methylnaphthalene       |
| 21  | 0   | 0   | 0  | 0   | 0                   | 0              | 162 2-Chloronaphthalene       |
| 22  | 71  | 32  | 90 | 0   | 215130 vv           | 834            | 152 Acenaphthylene            |
| 23  | 69  | 32  | 79 | 0   | <del>11115 vv</del> | <del>811</del> | 154 Acenaphthene              |
| 24  | 71  | 32  | 82 | 0   | 129400 vv           | 938            | 166 Fluorene                  |
| 25  | 0   | 0   | 0  | 0   | 0                   | 0              | 206 Pentachlorophenol         |
| 26  | 89  | 50  | 97 | -1  | 627900 bv           | 1079           | 178 Phenanthrene              |
| 27  | 50  | 20  | 74 | -2  | 41504 vv            | 1086           | 178 Anthracene                |
| 28  | 0   | 0   | 0  | 0   | 0                   | 0              | 202 Fluoranthene              |
| 29  | 46  | 20  | 82 | -1  | 35288 bv            | 1267           | 202 Pyrene                    |
| 30  | 0   | 0   | 0  | 0   | 0                   | 0              | 228 Benzo(a)anthracene        |
| 31  | 0   | 0   | 0  | 0   | 0                   | 0              | 228 Chrysene                  |
| 32  | 0   | 0   | 0  | 0   | 0                   | 0              | 252 Benzo(b)fluoranthene      |
| 33  | 0   | 0   | 0  | 0   | 0                   | 0              | 252 Benzo(k)fluoranthene      |
| 34  | 0   | 0   | 0  | 0   | 0                   | 0              | 252 Benzo(e)pyrene            |
| 35  | 0   | 0   | 0  | 0   | 0                   | 0              | 252 Benzo(a)pyrene            |
| 36  | 0   | 0   | 0  | 0   | 0                   | 0              | 252 Perylene                  |
| 37  | 0   | 0   | 0  | 0   | 0                   | 0              | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 0   | 0   | 0  | 0   | 0                   | 0              | 278 Dibenz(a,h)anthracene     |
| 39  | 0   | 0   | 0  | 0   | 0                   | 0              | 276 Benzo(g,h,i)perylene      |

82  
1-5-93

03-Jan-93 22:07

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: RUN #2 (1:10 DIL.)

22651

Instrument G



GL503 602 (12.034)



712704



708600

FIND  
100

03-Jan-99 22:37

Triangle Laboratories of HTP, Inc.

(919) 544-5729

Sample: MMH #2 (1:10 DIL.)


22651

Instrument 6



C13H7 704 (13.734)

142

618496



614100



P1110

03-Jan-93 22:07


Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: RUN #2 (1:10 DIL.) 22651

Instrument G

C1003 034 (15.901)




C1003 034 (15.901) REFERENCE

69632



T1110

100



03-Jan-93 22:07

Triangle Laboratories of RTP, Inc.


(919) 544-5729

Sample: RM #2 (1:10 DIL.)


22651

Instrument G


GL03 930 (17.634)



GL03 930 (17.634) REFINE



NUPAN 24 (17.651) Fluorene



RM #2 (1:10 DIL.)

03-Jan-93 22:07

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: MMH #2 (1:18 DIL.)


22651

Instrument G



GL508 1079 (19.905)

100 178

262144



260096

PHND  
100

03-Jan-93 22:07

Triangle Laboratories of RTP, Inc.


(919) 544-5729

Sample: RM #2 (1:10 DIL.)



22651

Instrument G

01503 1005 (20.181)



12096



100

03-Jan-93 22:07

Triangle Laboratories of RTP, Inc.




(919) 544-5729

Sample: MM #2 (1:10 DIL.)

22651

Instrument G

01503 1287 (23.451)





Triangle Laboratories of RTP, Inc.  
801 Capitola Dr.  
Durham, NC 27713  
(919) 544-5729

Sample File : GL504  
Response File : GL500  
Date Analyzed : 01/03/93  
Date Reported : 01/06/93  
Project Number: 22651

Sample ID: RUN#3  
TLI ID: 62.25.4A-I  
Dilution Factor: 10.00

99

Quantitation Results Method 8270

| Analyte                | Area  | RF    | SCAN | ISID | Amt. Code<br>(ug) | Quan<br>Limit | FLAG |
|------------------------|-------|-------|------|------|-------------------|---------------|------|
| 1,4-Dichlorobenzene-d4 | 2984  |       | 420  | 1    | I                 |               |      |
| Naphthalene-d8         | 13620 |       | 599  | 2    | I                 |               |      |
| 2-Methylnaphthalene    | 13758 | 0.879 | 704  | 2    | 595.05 D          | 100.0         |      |
| Naphthalene            | 19568 | 1.001 | 602  | 2    | 574.10 D          | 100.0         |      |
| Acenaphthene-d10       | 6883  |       | 856  | 3    | I                 |               |      |
| Acenaphthene           | 0     | 0.957 | 0    | 3    | 1.21 ND           | 100.0         |      |
| Fluorene               | 1311  | 1.180 | 938  | 3    | 64.56 E           | 100.0         |      |
| 2-Chloronaphthalene    | 0     | 0.971 | 0    | 3    | 1.20 ND           | 100.0         |      |
| Acenaphthylene         | 2678  | 1.680 | 835  | 3    | 92.63 E           | 100.0         |      |
| Phenanthrene-d10       | 13214 |       | 1076 | 4    | I                 |               |      |
| Phenanthrene           | 6203  | 0.921 | 1079 | 4    | 203.89 D          | 100.0         |      |
| Anthracene             | 467   | 0.944 | 1086 | 4    | 14.99 E           | 100.0         |      |
| Fluoranthene           | 520   | 1.115 | 1255 | 4    | 14.13 E           | 100.0         |      |
| Chrysene-d12           | 16696 |       | 1470 | 5    | I                 |               |      |
| Chrysene               | 0     | 0.995 | 0    | 5    | 0.48 ND           | 100.0         |      |
| Pyrene                 | 617   | 1.167 | 1287 | 5    | 12.67 E           | 100.0         |      |
| Benzo(a)anthracene     | 0     | 0.978 | 0    | 5    | 0.49 ND           | 100.0         |      |
| Perylene-d12           | 10898 |       | 1740 | 6    | I                 |               |      |
| Benzo(b)fluoranthene   | 0     | 1.380 | 0    | 6    | 0.53 ND           | 100.0         |      |
| Benzo(k)fluoranthene   | 0     | 1.785 | 0    | 6    | 0.41 ND           | 100.0         |      |
| Benzo(e)pyrene         | 0     | 1.423 | 0    | 6    | 0.52 ND           | 100.0         |      |
| Benzo(a)pyrene         | 0     | 1.321 | 0    | 6    | 0.56 ND           | 100.0         |      |
| Perylene               | 0     | 0.688 | 0    | 6    | 1.07 ND           | 100.0         |      |
| Indeno(1,2,3-cd)pyrene | 0     | 0.876 | 0    | 6    | 0.84 ND           | 100.0         |      |
| Dibenz(a,h)anthracene  | 0     | 0.875 | 0    | 6    | 0.84 ND           | 100.0         |      |
| Benzo(g,h,i)perylene   | 0     | 1.068 | 0    | 6    | 0.69 ND           | 100.0         |      |

| Surrogate Summary | Area | RF | SCAN | ISID | Amount<br>(ug) | Code | %REC |
|-------------------|------|----|------|------|----------------|------|------|
|-------------------|------|----|------|------|----------------|------|------|

|                |      |       |      |   |          |  |       |
|----------------|------|-------|------|---|----------|--|-------|
| Anthracene-d10 | 1867 | 0.508 | 1084 | 4 | 111.31 D |  | 111.3 |
| Pyrene-d10     | 2897 | 1.066 | 1285 | 5 | 65.12 D  |  | 65.1  |

Received by JL Date 1/6/93  
ND -Not Detected; D- Detected; E- Estimated; I- Internal Standard

Orgrep v2.5

03-Jan-93 22:59

Triangle Laboratories of RTP, Inc.


(919) 544-5729

Sample: MM H3 (1:10 dil.)

22651

Instrument 6

GC/MS



91-5-93

7977314  
710  
#1

| No. | mol | FOF | Pr. | Delta | Area    | Flag | Mass | Ref. | Chemical                  |
|-----|-----|-----|-----|-------|---------|------|------|------|---------------------------|
| 1   | 100 | 72  | 100 | 0     | 298400  | bb   | 410  | 152  | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 72  | 93  | 0     | 1362100 | bv   | 599  | 13c  | Naphthalene-d8            |
| 3   | 88  | 56  | 95  | -1    | 688400  | vv   | 850  | 104  | Acenaphthene-d10          |
| 4   | 95  | 69  | 95  | 1     | 1321400 | bv   | 1076 | 138  | Phenanthrene-d10          |
| 5   | 97  | 84  | 96  | -2    | 1669600 | bb   | 1470 | 240  | Chrysene-d12              |
| 6   | 100 | 82  | 93  | 0     | 1089800 | bv   | 1740 | 264  | Perylene-d12              |
| 7   | 0   | 0   | 0   | 0     | 0       |      | 0    | 112  | 2-Fluorophenol            |
| 8   | 0   | 0   | 0   | 0     | 0       |      | 0    | 132  | 2-Chlorophenol-d4         |
| 9   | 0   | 0   | 0   | 0     | 0       |      | 0    | 99   | Phenol-d5                 |
| 10  | 0   | 0   | 0   | 0     | 0       |      | 0    | 152  | 1,2-Dichlorobenzene-d4    |
| 11  | 0   | 0   | 0   | 0     | 0       |      | 0    | 82   | Nitrobenzene-d5           |
| 12  | 0   | 0   | 0   | 0     | 0       |      | 0    | 185  | 1,3,5-Trichlorobenzene-d3 |
| 13  | 0   | 0   | 0   | 0     | 0       |      | 0    | 240  | 1,4-Dibromobenzene-d4     |
| 14  | 0   | 0   | 0   | 0     | 0       |      | 0    | 172  | 2-Fluorobiphenyl          |
| 15  | 0   | 0   | 0   | 0     | 0       |      | 0    | 330  | 2,4,6-Tribromophenol      |
| 16  | 72  | 34  | 90  | -1    | 186790  | vb   | 1084 | 193  | Anthracene-d10            |
| 17  | 94  | 55  | 95  | 0     | 285760  | vv   | 1285 | 212  | Pyrene-d10                |
| 18  | 0   | 0   | 0   | 0     | 0       |      | 0    | 244  | Terphenyl-d14             |
| 19  | 100 | 76  | 99  | 0     | 1956900 | vv   | 602  | 178  | Naphthalene               |
| 20  | 100 | 80  | 93  | -1    | 1375600 | vv   | 704  | 142  | 2-Methylnaphthalene       |
| 21  | 0   | 0   | 0   | 0     | 0       |      | 0    | 162  | 2-Chloronaphthalene       |
| 22  | 73  | 34  | 92  | 1     | 267820  | vb   | 835  | 152  | Acenaphthylene            |
| 23  | 70  | 32  | 80  | 0     | 21650   | vv   | 841  | 154  | Acenaphthene              |
| 24  | 71  | 32  | 82  | 0     | 131120  | vb   | 938  | 166  | Fluorene                  |
| 25  | 0   | 0   | 0   | 0     | 0       |      | 0    | 260  | Pentachlorophenol         |
| 26  | 83  | 47  | 96  | -1    | 620330  | bv   | 1079 | 178  | Phenanthrene              |
| 27  | 51  | 20  | 75  | -2    | 46754   | vv   | 1086 | 178  | Anthracene                |
| 28  | 60  | 24  | 87  | -2    | 52044   | vb   | 1255 | 202  | Fluoranthene              |
| 29  | 65  | 25  | 79  | -1    | 61736   | bb   | 1287 | 202  | Pyrene                    |
| 30  | 0   | 0   | 0   | 0     | 0       |      | 0    | 228  | Benzo(a)anthracene        |
| 31  | 0   | 0   | 0   | 0     | 0       |      | 0    | 228  | Chrysene                  |
| 32  | 0   | 0   | 0   | 0     | 0       |      | 0    | 252  | Benzo(b)fluoranthene      |
| 33  | 0   | 0   | 0   | 0     | 0       |      | 0    | 252  | Benzo(k)fluoranthene      |
| 34  | 0   | 0   | 0   | 0     | 0       |      | 0    | 252  | Benzo(e)pyrene            |
| 35  | 0   | 0   | 0   | 0     | 0       |      | 0    | 252  | Benzo(a)pyrene            |
| 36  | 0   | 0   | 0   | 0     | 0       |      | 0    | 252  | Perylene                  |
| 37  | 0   | 0   | 0   | 0     | 0       |      | 0    | 276  | Indeno(1,2,3-cd)pyrene    |
| 38  | 0   | 0   | 0   | 0     | 0       |      | 0    | 275  | Dibenz(a,h)anthracene     |
| 39  | 0   | 0   | 0   | 0     | 0       |      | 0    | 276  | Benzo(g,h,i)perylene      |


9/1-5-93

03-Jan-93 22:59 Triangle Laboratories of RTP, Inc. (919) 544-5729  
 Sample: MMH #3 (1:10 Dil.) 22651 Instrument G


01504 602 (12.034)



01504 602 (12.034) NHPINT 757760



01504 602 (12.034) Naphthalene



03-Jan-93 22:59

Triangle Laboratories of HPL, Inc.


(919) 544-5729

Sample: RMH #3 (1:10 DIL.)

22651

Instrument G

GLC#4 704 (13.734)



03-Jan-93 22:59




Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: RM #3 (1.16 DL.) 22651

Instrument G

01504 835 (15.916)



03-Jan-93 22:59

Triangle Laboratories of RTP, Inc.


(919) 544-5729

Sample: RUN #3 (1.18 DIL.)


Z2651

Instrument G


01584 938 (17.634)



01584 938 (17.634) REFINE



01584 938 (17.634) Fluorene



03-Jan-93 22:59

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: MUM 43 (1:10 DIL.)

22651

Instrument G


GLC#04 1079 (19.905)




262144



259072



259072



259072



03-Jan-93 22:59

Triangle Laboratories of RTP, Inc.

(919) 544-5729


Sample: RUN #3 (1:10 TLL)

22651


Instrument G

GLS04 1006 (20.101)


22016



13848




17140




03-Jan-93 22:53 Triangle Laboratories of RTP, Inc. (919) 544-5729  
Sample: RUN #3 (1:10 DIL.) 22651 Instrument G


CLM4 1255 (22.910)



CLM4 1255 (22.917) REFINE



REFINE 20 (22.951) Fluoranthene



13-Jan-93 22:59

Triangle Laboratories of RTP, Inc.


(919) 544-5729

Sample: RUN #3 (1:16 DIL.)


Z2651

Instrument 6

015041287 (23.451)



015041287 (23.451) Pyrene



Pyrene

FIND

Triangle Laboratories of RTP, Inc.  
801 Capitola Dr.  
Durham, NC 27713  
(919) 544-5729

Sample File : GL471  
Response File : GL467  
Date Analyzed : 12/30/92  
Date Reported : 01/06/93  
Project Number: 22651

Sample ID: BLANK  
TLI ID: 62.25.1A-I  
Dilution Factor: 1.00

110

Quantitation Results Method 8270

| Analyte                | Area  | RF    | SCAN | ISID | Amt. Code<br>(ug) | Quan<br>Limit | FLAG |
|------------------------|-------|-------|------|------|-------------------|---------------|------|
| 1,4-Dichlorobenzene-d4 | 9674  |       | 433  | 1    | I                 |               |      |
| Naphthalene-d8         | 36186 |       | 612  | 2    | I                 |               |      |
| 2-Methylnaphthalene    | 738   | 0.449 | 718  | 2    | 1.82 E            | 10.0          |      |
| Naphthalene            | 1548  | 0.574 | 615  | 2    | 2.98 E            | 10.0          |      |
| Acenaphthene-d10       | 27440 |       | 871  | 3    | I                 |               |      |
| Acenaphthene           | 0     | 0.578 | 0    | 3    | 0.05 ND           | 10.0          |      |
| Fluorene               | 0     | 0.745 | 0    | 3    | 0.04 ND           | 10.0          |      |
| 2-Chloronaphthalene    | 0     | 0.600 | 0    | 3    | 0.05 ND           | 10.0          |      |
| Acenaphthylene         | 0     | 1.001 | 0    | 3    | 0.03 ND           | 10.0          |      |
| Phenanthrene-d10       | 60865 |       | 1091 | 4    | I                 |               |      |
| Phenanthrene           | 0     | 0.552 | 0    | 4    | 0.02 ND           | 10.0          |      |
| Anthracene             | 0     | 0.568 | 0    | 4    | 0.02 ND           | 10.0          |      |
| Fluoranthene           | 0     | 0.653 | 0    | 4    | 0.02 ND           | 10.0          |      |
| Chrysene-d12           | 73106 |       | 1488 | 5    | I                 |               |      |
| Chrysene               | 0     | 0.539 | 0    | 5    | 0.02 ND           | 10.0          |      |
| Pyrene                 | 0     | 0.759 | 0    | 5    | 0.01 ND           | 10.0          |      |
| Benzo(a)anthracene     | 0     | 0.576 | 0    | 5    | 0.02 ND           | 10.0          |      |
| Perylene-d12           | 34786 |       | 1769 | 6    | I                 |               |      |
| Benzo(b)fluoranthene   | 0     | 0.709 | 0    | 6    | 0.03 ND           | 10.0          |      |
| Benzo(k)fluoranthene   | 0     | 0.870 | 0    | 6    | 0.03 ND           | 10.0          |      |
| Benzo(e)pyrene         | 0     | 0.691 | 0    | 6    | 0.03 ND           | 10.0          |      |
| Benzo(a)pyrene         | 0     | 0.666 | 0    | 6    | 0.03 ND           | 10.0          |      |
| Perylene               | 0     | 0.395 | 0    | 6    | 0.06 ND           | 10.0          |      |
| Indeno(1,2,3-cd)pyrene | 0     | 0.612 | 0    | 6    | 0.04 ND           | 10.0          |      |
| Dibenz(a,h)anthracene  | 0     | 0.446 | 0    | 6    | 0.05 ND           | 10.0          |      |
| Benzo(g,h,i)perylene   | 0     | 0.540 | 0    | 6    | 0.04 ND           | 10.0          |      |

| Surrogate Summary | Area  | RF    | SCAN | ISID | Amount<br>(ug) | Code | %REC |
|-------------------|-------|-------|------|------|----------------|------|------|
| Anthracene-d10    | 44920 | 0.301 | 1099 | 4    | 98.08          | 0    | 98.1 |
| Pyrene-d10        | 70459 | 0.672 | 1302 | 5    | 57.37          | 0    | 57.4 |

Received by JS Date 1/6/93  
ND -Not Detected; D- Detected; E- Estimated; I- Internal Standard

Orgrep v2.5

30-Dec-92 15:24


Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: MUNK

Instrument 6

01471



df  
1-5-93

| NO. | MR  | HR | REV | Delta | Area             | Flag          | Unit      | QTY             | Name                          |
|-----|-----|----|-----|-------|------------------|---------------|-----------|-----------------|-------------------------------|
| 1   | 100 | 79 | 99  | 1     | 3.7470           | bb            |           | 433             | 157 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 79 | 90  | 0     | 3618700          | bv            |           | 812             | 136 Naphthalene-d8            |
| 3   | 80  | 56 | 95  | 1     | 2744000          | vv            |           | 871             | 164 Acenaphthene-d10          |
| 4   | 100 | 66 | 95  | 0     | 6086500          | vv            |           | 1091            | 188 Phenanthrene-d10          |
| 5   | 92  | 61 | 98  | 0     | 7310600          | vv            |           | 1488            | 240 Chrysene-d12              |
| 6   | 89  | 57 | 96  | 1     | 3478600          | bv            |           | 1769            | 264 Perylene-d12              |
| 7   | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 112 2-Fluorophenol            |
| 8   | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 132 2-Chlorophenol-d4         |
| 9   | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 99 Phenol-d5                  |
| 10  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 152 1,2-Dichlorobenzene-d4    |
| 11  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 82 Nitrobenzene-d5            |
| 12  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 185 1,3,5-Trichlorobenzene-d3 |
| 13  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 240 1,4-Dibromobenzene-d4     |
| 14  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 172 2-Fluorobiphenyl          |
| 15  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 330 2,4,6-Tribromophenol      |
| 16  | 100 | 74 | 96  | 0     | 4492000          | vv            |           | 1099            | 188 Anthracene-d10            |
| 17  | 91  | 63 | 94  | 1     | 7046000          | vv            |           | 1302            | 212 Pyrene-d10                |
| 18  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 244 Terphenyl-d14             |
| 19  | 89  | 45 | 97  | 0     | 154860           | bv            |           | 615             | 128 Naphthalene               |
| 20  | 87  | 53 | 86  | 0     | 73828            | bb            |           | 718             | 142 2-Methylnaphthalene       |
| 21  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 162 2-Chloronaphthalene       |
| 22  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 152 Acenaphthylene            |
| 23  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 154 Acenaphthene              |
| 24  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 166 Fluorene                  |
| 25  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 266 Pentachlorophenol         |
| 26  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 178 Phenanthrene              |
| 27  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 178 Anthracene                |
| 28  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 202 Fluoranthene              |
| 29  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 202 Pyrene                    |
| 30  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 228 Benzo(a)anthracene        |
| 31  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 228 Chrysene                  |
| 32  | 31  | 21 | 32  | 1     | <del>22072</del> | <del>vv</del> | <i>gt</i> | <del>1688</del> | 252 Benzo(b)fluoranthene      |
| 33  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 252 Benzo(k)fluoranthene      |
| 34  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 252 Benzo(e)pyrene            |
| 35  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 252 Benzo(a)pyrene            |
| 36  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 252 Perylene                  |
| 37  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 278 Dibenz(a,h)anthracene     |
| 39  | 0   | 0  | 0   | 0     | 0                |               |           | 0               | 276 Benzo(g,h,i)perylene      |

*gt*  
1-5-93

30-Dec-92 15:24

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: BLANK 22651

Instrument 6


GL471 615 (12.251)



GL471 615 (12.251) REFINE



NEWPAN 19 (12.250) Naphthalene



30-Dec-92 15:24

Triangle Laboratories of RTP, Inc.




(919) 544-5729

Sample: BLANK

22651

Instrument G

GL471 718 (13.967)





Triangle Laboratories of RTP, Inc.  
801 Capitola Dr.  
Durham, NC 27713  
(919) 544-5729

Sample File : GL469  
Response File : GL467  
Date Analyzed : 12/30/92  
Date Reported : 01/06/93  
Project Number: 22651

Sample ID: SBLK 122192  
TLI ID: N/A  
Dilution Factor: 1.00

115

Quantitation Results Method 8270

| Analyte                | Area  | RF    | SCAN | ISID | Amt. Code<br>(ug) | Quan FLAG<br>Limit |
|------------------------|-------|-------|------|------|-------------------|--------------------|
| 1,4-Dichlorobenzene-d4 | 11104 |       | 433  | 1    | I                 |                    |
| Naphthalene-d8         | 37296 |       | 612  | 2    | I                 |                    |
| 2-Methylnaphthalene    | 0     | 0.448 | 0    | 2    | 0.05 ND           | 10.0               |
| Naphthalene            | 715   | 0.574 | 615  | 2    | 1.34 E            | 10.0               |
| Acenaphthene-d10       | 27609 |       | 870  | 3    | I                 |                    |
| Acenaphthene           | 0     | 0.578 | 0    | 3    | 0.05 ND           | 10.0               |
| Fluorene               | 0     | 0.745 | 0    | 3    | 0.04 ND           | 10.0               |
| 2-Chloronaphthalene    | 0     | 0.600 | 0    | 3    | 0.05 ND           | 10.0               |
| Acenaphthylene         | 0     | 1.001 | 0    | 3    | 0.03 ND           | 10.0               |
| Phenanthrene-d10       | 60480 |       | 1090 | 4    | I                 |                    |
| Phenanthrene           | 0     | 0.552 | 0    | 4    | 0.02 ND           | 10.0               |
| Anthracene             | 0     | 0.568 | 0    | 4    | 0.02 ND           | 10.0               |
| Fluoranthene           | 0     | 0.653 | 0    | 4    | 0.02 ND           | 10.0               |
| Chrysene-d12           | 60538 |       | 1487 | 5    | I                 |                    |
| Chrysene               | 0     | 0.539 | 0    | 5    | 0.02 ND           | 10.0               |
| Pyrene                 | 0     | 0.759 | 0    | 5    | 0.02 ND           | 10.0               |
| Benzo(a)anthracene     | 0     | 0.576 | 0    | 5    | 0.02 ND           | 10.0               |
| Perylene-d12           | 34363 |       | 1767 | 6    | I                 |                    |
| Benzo(b)fluoranthene   | 0     | 0.709 | 0    | 6    | 0.03 ND           | 10.0               |
| Benzo(k)fluoranthene   | 0     | 0.870 | 0    | 6    | 0.03 ND           | 10.0               |
| Benzo(e)pyrene         | 0     | 0.691 | 0    | 6    | 0.03 ND           | 10.0               |
| Benzo(a)pyrene         | 0     | 0.666 | 0    | 6    | 0.03 ND           | 10.0               |
| Perylene               | 0     | 0.395 | 0    | 6    | 0.06 ND           | 10.0               |
| Indeno(1,2,3-cd)pyrene | 0     | 0.612 | 0    | 6    | 0.04 ND           | 10.0               |
| Dibenz(a,h)anthracene  | 0     | 0.446 | 0    | 6    | 0.05 ND           | 10.0               |
| Benzo(g,h,i)perylene   | 0     | 0.540 | 0    | 6    | 0.04 ND           | 10.0               |

| Surrogate Summary | Area | RF | SCAN | ISID | Amount<br>(ug) | Code | %REC |
|-------------------|------|----|------|------|----------------|------|------|
|-------------------|------|----|------|------|----------------|------|------|

|                |       |       |      |   |       |   |      |
|----------------|-------|-------|------|---|-------|---|------|
| Anthracene-d10 | 42571 | 0.301 | 1099 | 4 | 93.54 | D | 93.5 |
| Pyrene-d10     | 58100 | 0.672 | 1301 | 5 | 57.13 | D | 57.1 |


Reviewed by JL Date 1, 6, 93  
ND -Not Detected; D- Detected; E- Estimated; I- Internal Standard

Orgrep v2.5

30-Dec-92 13:41  
Sample: SBLK 122192

Triangle Laboratories of RTP, Inc.  
22651

(919) 544-5729  
Instrument G



97  
1-5-93

| NO. | MAT | FOR | REV | Delta | Area    | P.Flags | Scan | QM Name                       |
|-----|-----|-----|-----|-------|---------|---------|------|-------------------------------|
| 1   | 100 | 82  | 99  | 1     | 1110500 | bb      | 433  | 152 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 86  | 91  | 0     | 3729700 | bv      | 612  | 136 Naphthalene-d8            |
| 3   | 100 | 95  | 98  | 0     | 2760900 | bb      | 870  | 164 Acenaphthene-d10          |
| 4   | 100 | 91  | 97  | -1    | 6048000 | bv      | 1090 | 188 Phenanthrene-d10          |
| 5   | 100 | 84  | 95  | -1    | 6053700 | bv      | 1487 | 240 Chrysene-d12              |
| 6   | 100 | 88  | 94  | -1    | 3436300 | bv      | 1767 | 264 Perylene-d12              |
| 7   | 0   | 0   | 0   | 0     | 0       |         | 0    | 112 2-Fluorophenol            |
| 8   | 0   | 0   | 0   | 0     | 0       |         | 0    | 132 2-Chlorophenol-d4         |
| 9   | 0   | 0   | 0   | 0     | 0       |         | 0    | 99 Phenol-d5                  |
| 10  | 0   | 0   | 0   | 0     | 0       |         | 0    | 152 1,2-Dichlorobenzene-d4    |
| 11  | 0   | 0   | 0   | 0     | 0       |         | 0    | 82 Nitrobenzene-d5            |
| 12  | 0   | 0   | 0   | 0     | 0       |         | 0    | 185 1,3,5-Trichlorobenzene-d3 |
| 13  | 0   | 0   | 0   | 0     | 0       |         | 0    | 240 1,4-Dibromobenzene-d4     |
| 14  | 0   | 0   | 0   | 0     | 0       |         | 0    | 172 2-Fluorobiphenyl          |
| 15  | 0   | 0   | 0   | 0     | 0       |         | 0    | 330 2,4,6-Tribromophenol      |
| 16  | 100 | 87  | 95  | 0     | 4257100 | vv      | 1099 | 188 Anthracene-d10            |
| 17  | 100 | 89  | 96  | 0     | 5810100 | bv      | 1301 | 212 Pyrene-d10                |
| 18  | 0   | 0   | 0   | 0     | 0       |         | 0    | 244 Terphenyl-d14             |
| 19  | 100 | 75  | 93  | 0     | 71584   | bb      | 615  | 128 Naphthalene               |
| 20  | 0   | 0   | 0   | 0     | 0       |         | 0    | 142 2-Methylnaphthalene       |
| 21  | 0   | 0   | 0   | 0     | 0       |         | 0    | 162 2-Chloronaphthalene       |
| 22  | 0   | 0   | 0   | 0     | 0       |         | 0    | 152 Acenaphthylene            |
| 23  | 0   | 0   | 0   | 0     | 0       |         | 0    | 154 Acenaphthene              |
| 24  | 0   | 0   | 0   | 0     | 0       |         | 0    | 166 Fluorene                  |
| 25  | 0   | 0   | 0   | 0     | 0       |         | 0    | 266 Pentachlorophenol         |
| 26  | 0   | 0   | 0   | 0     | 0       |         | 0    | 178 Phenanthrene              |
| 27  | 0   | 0   | 0   | 0     | 0       |         | 0    | 178 Anthracene                |
| 28  | 0   | 0   | 0   | 0     | 0       |         | 0    | 202 Fluoranthene              |
| 29  | 0   | 0   | 0   | 0     | 0       |         | 0    | 202 Pyrene                    |
| 30  | 0   | 0   | 0   | 0     | 0       |         | 0    | 228 Benzo(a)anthracene        |
| 31  | 0   | 0   | 0   | 0     | 0       |         | 0    | 228 Chrysene                  |
| 32  | 0   | 0   | 0   | 0     | 0       |         | 0    | 252 Benzo(b)fluoranthene      |
| 33  | 0   | 0   | 0   | 0     | 0       |         | 0    | 252 Benzo(k)fluoranthene      |
| 34  | 0   | 0   | 0   | 0     | 0       |         | 0    | 252 Benzo(e)pyrene            |
| 35  | 0   | 0   | 0   | 0     | 0       |         | 0    | 252 Benzo(a)pyrene            |
| 36  | 0   | 0   | 0   | 0     | 0       |         | 0    | 252 Perylene                  |
| 37  | 0   | 0   | 0   | 0     | 0       |         | 0    | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 0   | 0   | 0   | 0     | 0       |         | 0    | 278 Dibenz(a,h)anthracene     |
| 39  | 0   | 0   | 0   | 0     | 0       |         | 0    | 276 Benzo(g,h,i)perylene      |

117

JL  
1-5-93

30-Dec-92 13:41

Sample: SBLK 122192


Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G

GL469 615 (12.251)

128


33024



GL469 615 (12.251) REFINE

128


33024



NUPAN 19 (12.250) Naphthalene

128

33024



FIND

Triangle Laboratories of RTP, Inc.  
Continuing Calibration Curve

119


CCAL File: GL500 Date of Analysis :01/03/93 Analyte List: PAH  
ICAL File: ICALGJ03

| Analyte                | Flag | RF50  | RFMEAN | %D   |
|------------------------|------|-------|--------|------|
| =====                  |      |       |        |      |
| 1,4-Dichlorobenzene-d4 | I    |       |        |      |
| Naphthalene-d8         | I    |       |        |      |
| 2-Methylnaphthalene    |      | 0.679 | 0.729  | 6.9  |
| Naphthalene            |      | 1.001 | 1.058  | 5.4  |
| Acenaphthene-d10       | I    |       |        |      |
| Acenaphthene           | C    | 0.957 | 1.019  | 6.1  |
| Fluorene               |      | 1.180 | 1.253  | 5.8  |
| 2-Chloronaphthalene    |      | 0.971 | 1.048  | 7.3  |
| Acenaphthylene         |      | 1.680 | 1.791  | 6.2  |
| Phenanthrene-d10       | I    |       |        |      |
| Phenanthrene           |      | 0.921 | 0.950  | 3.1  |
| Anthracene             |      | 0.944 | 0.959  | 1.6  |
| Fluoranthene           | C    | 1.115 | 1.152  | 3.2  |
| Chrysene-d12           | I    |       |        |      |
| Chrysene               |      | 0.995 | 1.011  | 1.6  |
| Pyrene                 |      | 1.167 | 1.176  | 0.8  |
| Benzo(a)anthracene     |      | 0.978 | 1.048  | 6.7  |
| Perylene-d12           | I    |       |        |      |
| Benzo(b)fluoranthene   |      | 1.380 | 1.575  | 12.4 |
| Benzo(k)fluoranthene   |      | 1.785 | 1.704  | -4.8 |
| Benzo(e)pyrene         |      | 1.423 | 1.497  | 4.9  |
| Benzo(a)pyrene         | C    | 1.321 | 1.424  | 7.2  |
| Perylene               |      | 0.688 | 0.755  | 8.9  |
| Indeno(1,2,3-cd)pyrene |      | 0.876 | 1.057  | 17.1 |
| Dibenz(a,h)anthracene  |      | 0.875 | 1.047  | 16.4 |
| Benzo(g,h,i)perylene   |      | 1.068 | 1.193  | 10.6 |
| =====                  |      |       |        |      |
| Surrogate              | Flag | RF50  | RFMEAN | %D   |
| =====                  |      |       |        |      |
| Anthracene-d10         | S    | 0.508 | 0.527  | 3.6  |
| Pyrene-d10             | S    | 1.068 | 1.103  | 3.4  |

Approved by: *J. L. H.* Date 1/5/93  
\*. Fails QC Criteria for %D; << - RF less than minimum QC RF; >>- RF greater than maximum QC RF

CCAL.EXE v2.5

~ 1/2/97



| NO. | NAT | FOR | REV | Delta | Area    | P.Flags | Scan | Q#  | Name                      |
|-----|-----|-----|-----|-------|---------|---------|------|-----|---------------------------|
| 1   | 100 | 85  | 100 | -1    | 305790  | bb      | 419  | 152 | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 86  | 93  | 1     | 1287900 | bb      | 599  | 136 | Naphthalene-d8            |
| 3   | 100 | 93  | 98  | -1    | 712780  | bb      | 856  | 164 | Acenaphthene-d10          |
| 4   | 100 | 91  | 96  | -1    | 1491100 | bv      | 1076 | 188 | Phenanthrene-d10          |
| 5   | 78  | 49  | 96  | -2    | 1498800 | bb      | 1470 | 240 | Chrysene-d12              |
| 6   | 100 | 89  | 93  | 0     | 670400  | bb      | 1740 | 264 | Perylene-d12              |
| 7   | 100 | 96  | 97  | 0     | 718060  | bb      | 244  | 112 | 2-Fluorophenol            |
| 8   | 93  | 61  | 99  | 0     | 635450  | bb      | 388  | 132 | 2-Chlorophenol-d4         |
| 9   | 94  | 62  | 99  | -1    | 882900  | bv      | 376  | 99  | Phenol-d5                 |
| 10  | 100 | 95  | 99  | 1     | 377340  | bb      | 440  | 152 | 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 85  | 99  | -1    | 822920  | bb      | 497  | 82  | Nitrobenzene-d5           |
| 12  | 91  | 53  | 99  | -1    | 454030  | bb      | 545  | 185 | 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 94  | 99  | 0     | 310990  | bb      | 606  | 240 | 1,4-Dibromobenzene-d4     |
| 14  | 100 | 91  | 98  | 0     | 1025600 | bb      | 761  | 172 | 2-Fluorobiphenyl          |
| 15  | 100 | 80  | 99  | 0     | 185340  | bb      | 973  | 330 | 2,4,6-Tribromophenol      |
| 16  | 100 | 84  | 96  | -1    | 947030  | vb      | 1084 | 138 | Anthracene-d10            |
| 17  | 100 | 88  | 97  | 0     | 1997200 | bb      | 1285 | 212 | Pyrene-d10                |
| 18  | 100 | 88  | 97  | 1     | 1361400 | bb      | 1319 | 244 | Terphenyl-d14             |
| 19  | 100 | 97  | 98  | 0     | 1610700 | bb      | 602  | 128 | Naphthalene               |
| 20  | 100 | 89  | 91  | -1    | 1092700 | vb      | 704  | 142 | 2-Methylnaphthalene       |
| 21  | 100 | 97  | 99  | 0     | 864960  | bb      | 774  | 162 | 2-Chloronaphthalene       |
| 22  | 100 | 94  | 97  | 1     | 1496600 | bb      | 835  | 152 | Acenaphthylene            |
| 23  | 100 | 88  | 90  | 0     | 852700  | vb      | 861  | 154 | Acenaphthene              |
| 24  | 100 | 90  | 98  | 0     | 1051000 | bb      | 938  | 166 | Fluorene                  |
| 25  | 100 | 85  | 99  | -1    | 202210  | bb      | 1049 | 266 | Pentachlorophenol         |
| 26  | 100 | 93  | 97  | -1    | 1716600 | bv*     | 1079 | 178 | Phenanthrene              |
| 27  | 100 | 94  | 98  | -1    | 1759100 | vb      | 1087 | 178 | Anthracene                |
| 28  | 100 | 96  | 99  | -2    | 2078800 | bb      | 1255 | 202 | Fluoranthene              |
| 29  | 100 | 95  | 99  | 0     | 2185800 | bb      | 1288 | 202 | Pyrene                    |
| 30  | 100 | 90  | 99  | 1     | 1832600 | bv*     | 1469 | 228 | Benzo(a)anthracene        |
| 31  | 100 | 93  | 99  | 0     | 1865000 | vv      | 1474 | 228 | Chrysene                  |
| 32  | 86  | 67  | 71  | 0     | 1159500 | bv      | 1662 | 252 | Benzo(b)fluoranthene      |
| 33  | 100 | 94  | 97  | -2    | 1500100 | vb*     | 1667 | 252 | Benzo(k)fluoranthene      |
| 34  | 100 | 95  | 98  | -1    | 1195800 | bv      | 1717 | 252 | Benzo(e)pyrene            |
| 35  | 100 | 96  | 99  | -2    | 1110400 | vv      | 1728 | 252 | Benzo(a)pyrene            |
| 36  | 100 | 98  | 99  | -1    | 578120  | vb      | 1745 | 252 | Perylene                  |
| 37  | 100 | 97  | 100 | -1    | 736080  | bv      | 1966 | 276 | Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 94  | 97  | -1    | 735290  | bv      | 1974 | 278 | Dibenz(a,h)anthracene     |
| 39  | 96  | 96  | 99  | -3    | 897850  | bv      | 2016 | 276 | Benzo(g,h,i)perylene      |


03-Jan-93 18:54

Triangle Laboratories of RTP, Inc.

(919) 544-5729

Sample: DFTPP

Instrument G





10437 117 10.1142

11157

| PK# | Mass | Abn Int | Rel Int | PK# | Mass | Abn Int | Rel Int | PK# | Mass | Abn Int | Rel Int | PK# | Mass | Abn Int | Rel Int | PK# | Mass | Abn Int | Rel Int |
|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|
| 1   | 33   | 504     | 0.33    | 34  | 94   | 714     | 0.47    | 35  | 147  | 1576    | 1.11    | 150 | 200  | 1248    | 0.32    | 153 | 353  | 148     | 0.42    |
| 2   | 35   | 5184    | 3.40    | 35  | 92   | 4416    | 2.89    | 36  | 142  | 3340    | 2.20    | 151 | 201  | 1520    | 0.40    | 154 | 363  | 1392    | 0.91    |
| 3   | 40   | 923     | 0.61    | 36  | 99   | 4233    | 2.81    | 37  | 149  | 900     | 0.59    | 152 | 203  | 740     | 0.49    | 155 | 373  | 2320    | 1.52    |
| 4   | 44   | 1056    | 0.69    | 37  | 101  | 2560    | 1.62    | 38  | 151  | 672     | 0.45    | 153 | 204  | 4524    | 2.15    | 156 | 374  | 5622    | 3.49    |
| 5   | 50   | 16340   | 10.91   | 38  | 103  | 364     | 0.57    | 39  | 153  | 758     | 0.53    | 154 | 205  | 3576    | 5.12    | 157 | 375  | 29952   | 19.43   |
| 6   | 51   | 74752   | 48.99   | 39  | 104  | 1524    | 1.04    | 40  | 154  | 328     | 0.54    | 155 | 206  | 33220   | 23.21   | 158 | 376  | 4020    | 2.67    |
| 7   | 52   | 4160    | 2.73    | 40  | 105  | 1504    | 0.99    | 41  | 155  | 1356    | 1.22    | 156 | 207  | 5056    | 3.31    | 159 | 377  | 2352    | 1.54    |
| 8   | 55   | 840     | 0.55    | 41  | 107  | 20392   | 13.76   | 42  | 156  | 3022    | 2.02    | 157 | 208  | 1296    | 0.85    | 160 | 385  | 688     | 0.43    |
| 9   | 56   | 2464    | 1.51    | 42  | 109  | 3360    | 2.20    | 43  | 157  | 712     | 0.47    | 158 | 210  | 724     | 0.47    | 161 | 394  | 6734    | 4.45    |
| 10  | 57   | 5696    | 3.73    | 43  | 109  | 648     | 0.42    | 44  | 160  | 904     | 0.59    | 159 | 211  | 2096    | 1.37    | 162 | 397  | 1104    | 0.72    |
| 11  | 61   | 956     | 0.62    | 44  | 110  | 39166   | 25.67   | 45  | 161  | 1596    | 1.11    | 160 | 216  | 680     | 0.45    | 163 | 403  | 1040    | 0.68    |
| 12  | 62   | 1016    | 0.67    | 45  | 111  | 5324    | 3.82    | 46  | 165  | 1168    | 0.77    | 161 | 217  | 7808    | 5.12    | 164 | 415  | 904     | 0.59    |
| 13  | 63   | 2752    | 1.80    | 46  | 112  | 936     | 0.55    | 47  | 166  | 964     | 0.63    | 162 | 218  | 1248    | 0.82    | 165 | 423  | 2976    | 1.95    |
| 14  | 65   | 1272    | 1.23    | 47  | 116  | 1200    | 0.79    | 48  | 167  | 4464    | 4.24    | 163 | 221  | 13388   | 9.10    | 166 | 434  | 1872    | 1.23    |
| 15  | 69   | 1088    | 0.71    | 48  | 117  | 12608   | 8.26    | 49  | 168  | 3760    | 2.46    | 164 | 222  | 1920    | 1.21    | 167 | 446  | 796     | 0.52    |
| 16  | 69   | 81920   | 53.69   | 49  | 118  | 1312    | 0.86    | 50  | 169  | 648     | 0.42    | 165 | 223  | 2054    | 1.35    | 168 | 452  | 1040    | 0.68    |
| 17  | 70   | 768     | 0.50    | 50  | 122  | 1328    | 0.87    | 51  | 174  | 1136    | 0.74    | 166 | 224  | 18944   | 12.42   | 169 | 453  | 708     | 0.46    |
| 18  | 74   | 7104    | 4.66    | 51  | 123  | 1984    | 1.30    | 52  | 175  | 2464    | 1.61    | 167 | 225  | 4800    | 3.15    | 170 | 454  | 1104    | 0.72    |
| 19  | 75   | 11456   | 7.51    | 52  | 124  | 976     | 0.63    | 53  | 176  | 836     | 0.55    | 168 | 227  | 6208    | 4.07    | 171 | 465  | 3376    | 2.21    |
| 20  | 76   | 4160    | 2.73    | 53  | 125  | 1004    | 0.66    | 54  | 177  | 1120    | 0.73    | 169 | 228  | 960     | 0.63    | 172 | 472  | 1696    | 1.11    |
| 21  | 77   | 95232   | 62.42   | 54  | 127  | 87040   | 57.05   | 55  | 179  | 3920    | 2.57    | 170 | 229  | 1712    | 1.12    | 173 | 482  | 640     | 0.42    |
| 22  | 78   | 7168    | 4.70    | 55  | 128  | 6464    | 4.24    | 56  | 180  | 3360    | 2.20    | 171 | 231  | 312     | 0.53    | 174 | 483  | 896     | 0.59    |
| 23  | 79   | 4928    | 3.23    | 56  | 129  | 27904   | 18.29   | 57  | 181  | 1616    | 1.06    | 172 | 235  | 676     | 0.44    | 175 | 491  | 772     | 0.51    |
| 24  | 80   | 3904    | 2.56    | 57  | 130  | 2592    | 1.70    | 58  | 185  | 2032    | 1.33    | 173 | 237  | 672     | 0.45    | 176 | 492  | 780     | 0.51    |
| 25  | 91   | 5676    | 3.73    | 58  | 131  | 688     | 0.45    | 59  | 186  | 19712   | 12.32   | 174 | 242  | 1088    | 0.71    | 177 | 493  | 5952    | 3.90    |
| 26  | 82   | 1744    | 1.14    | 59  | 134  | 856     | 0.56    | 60  | 187  | 5760    | 3.78    | 175 | 243  | 956     | 0.63    | 178 | 494  | 1264    | 0.83    |
| 27  | 83   | 1936    | 1.27    | 60  | 135  | 2336    | 1.53    | 61  | 189  | 948     | 0.62    | 176 | 244  | 14144   | 9.27    | 179 | 495  | 16384   | 10.74   |
| 28  | 95   | 1168    | 0.77    | 61  | 136  | 988     | 0.65    | 62  | 192  | 1392    | 0.91    | 177 | 245  | 2000    | 1.31    | 180 | 496  | 111616  | 73.15   |
| 29  | 96   | 1328    | 0.87    | 62  | 137  | 1472    | 0.96    | 63  | 193  | 1584    | 1.04    | 178 | 246  | 2240    | 1.47    | 181 | 497  | 21760   | 14.26   |
| 30  | 87   | 784     | 0.51    | 63  | 141  | 3072    | 2.01    | 64  | 196  | 4544    | 2.98    | 179 | 255  | 69632   | 45.64   | 182 | 498  | 2400    | 1.57    |
| 31  | 91   | 1152    | 0.76    | 64  | 142  | 1200    | 0.79    | 65  | 197  | 734     | 0.51    | 180 | 256  | 10176   | 6.67    |     |      |         |         |
| 32  | 92   | 1200    | 0.79    | 65  | 143  | 900     | 0.59    | 66  | 198  | 152576  | 100.00  | 181 | 257  | 940     | 0.62    |     |      |         |         |
| 33  | 93   | 7040    | 4.61    | 66  | 146  | 724     | 0.47    | 67  | 199  | 10688   | 7.01    | 182 | 258  | 3328    | 2.13    |     |      |         |         |

Raw Data File: 01499  
Date: 03-Jan-93  
Time: 18:54

| RT  | ION ABUNDANCE CRITERIA             | RELATIVE<br>ABUNDANCE | TUNE |
|-----|------------------------------------|-----------------------|------|
| 51  | 30.0 - 60.0% of mass 198           | 48.99                 | PASS |
| 63  | Less than 2.0% of mass 69          | 0.71( 1.3)1           | PASS |
| 69  | Mass 69 relative abundance         | 53.69                 | PASS |
| 70  | Less than 2.0% of mass 69          | 0.50( 0.9)1           | PASS |
| 127 | 40.0 - 60.0% of mass 198           | 57.03                 | PASS |
| 197 | Less than 1% of mass 198           | 0.51                  | PASS |
| 198 | Base peak, 100% relative abundance | 100.00                | PASS |
| 199 | 5 - 9% of mass 198                 | 7.01                  | PASS |
| 275 | 10 - 30% of mass 198               | 19.63                 | PASS |
| 365 | Greater than 1% of mass 198        | 2.21                  | PASS |
| 441 | Present, but less than mass 443    | 10.74                 | PASS |
| 442 | Greater than 40% of mass 198       | 73.15                 | PASS |
| 443 | 17 - 23% of mass 442               | 14.26( 19.5)2         | PASS |

Triangle Laboratories of RTP, Inc.  
Initial Calibration Curve

125

ICAL File: ICALGD030 Date of Analysis :12/30/92 Analyte List: PAH  
RF20 GL482 RF50 GL467 RF80 GL463  
RF120 GL484 RF180 GL465

| Analyte                | Flag | RF20  | RF50  | RF80  | RF120 | RF180 | RFMEAN | %RSD |
|------------------------|------|-------|-------|-------|-------|-------|--------|------|
| =====                  |      |       |       |       |       |       |        |      |
| 1,4-Dichlorobenzene-d4 | I    |       |       |       |       |       |        |      |
| Naphthalene-d8         | I    |       |       |       |       |       |        |      |
| 2-Methylnaphthalene    |      | 0.591 | 0.449 | 0.472 | 0.472 | 0.484 | 0.493  | 11.3 |
| Naphthalene            |      | 0.782 | 0.574 | 0.800 | 0.590 | 0.573 | 0.624  | 14.3 |
| Acenaphthene-d10       | I    |       |       |       |       |       |        |      |
| Acenaphthene           | C    | 0.722 | 0.578 | 0.573 | 0.581 | 0.593 | 0.609  | 10.4 |
| Fluorene               |      | 0.920 | 0.745 | 0.761 | 0.758 | 0.766 | 0.790  | 9.3  |
| 2-Chloronaphthalene    |      | 0.778 | 0.800 | 0.625 | 0.625 | 0.645 | 0.655  | 10.8 |
| Acenaphthylene         |      | 1.219 | 1.001 | 0.987 | 0.994 | 0.959 | 1.032  | 10.2 |
| Phenanthrene-d10       | I    |       |       |       |       |       |        |      |
| Phenanthrene           |      | 0.694 | 0.552 | 0.553 | 0.507 | 0.478 | 0.557  | 14.9 |
| Anthracene             |      | 0.695 | 0.568 | 0.567 | 0.498 | 0.468 | 0.559  | 15.7 |
| Fluoranthene           | C    | 0.769 | 0.653 | 0.648 | 0.590 | 0.535 | 0.639  | 13.6 |
| Chrysene-d12           | I    |       |       |       |       |       |        |      |
| Chrysene               |      | 0.705 | 0.539 | 0.582 | 0.554 | 0.524 | 0.577  | 12.7 |
| Pyrene                 |      | 0.948 | 0.759 | 0.791 | 0.621 | 0.519 | 0.727  | 22.6 |
| Benzo(a)anthracene     |      | 0.687 | 0.576 | 0.597 | 0.575 | 0.560 | 0.599  | 8.5  |
| Perylene-d12           | I    |       |       |       |       |       |        |      |
| Benzo(b)fluoranthene   |      | 0.644 | 0.709 | 0.734 | 0.835 | 0.882 | 0.761  | 12.7 |
| Benzo(k)fluoranthene   |      | 1.200 | 0.870 | 0.966 | 0.942 | 0.904 | 0.977  | 13.4 |
| Benzo(e)pyrene         |      | 0.740 | 0.691 | 0.745 | 0.794 | 0.831 | 0.760  | 7.1  |
| Benzo(a)pyrene         | C    | 0.770 | 0.666 | 0.728 | 0.764 | 0.780 | 0.742  | 6.3  |
| Perylene               |      | 0.670 | 0.395 | 0.431 | 0.431 | 0.393 | 0.464  | 25.1 |
| Indeno(1,2,3-cd)pyrene |      | 0.478 | 0.612 | 0.668 | 0.763 | 0.875 | 0.679  | 22.2 |
| Dibenz(a,h)anthracene  |      | 0.286 | 0.446 | 0.477 | 0.566 | 0.649 | 0.485  | 28.2 |
| Benzo(g,h,i)perylene   |      | 0.459 | 0.540 | 0.601 | 0.659 | 0.718 | 0.595  | 16.9 |
| =====                  |      |       |       |       |       |       |        |      |
| Surrogate              | Flag | RF20  | RF50  | RF80  | RF120 | RF180 | RFMEAN | %RSD |
| =====                  |      |       |       |       |       |       |        |      |
| Anthracene-d10         | S    | 0.362 | 0.301 | 0.315 | 0.309 | 0.316 | 0.321  | 7.5  |
| Pyrene-d10             | S    | 0.823 | 0.672 | 0.753 | 0.655 | 0.575 | 0.695  | 13.7 |

Approved by:

*J. Lyon*

Date

*1.5.93*

\*- Fails QC Criteria for %RSD; << - Rf less than minimum QC RF; >>- RF greater than maximum QC RF

ICAL.EXE v2.5

Triangle Laboratories of RTP, Inc.  
Continuing Calibration Curve

126

CCAL File: GL487 Date of Analysis :12/30/92 Analyte List: PAH  
ICAL File: ICALGD30

| Analyte                | Flag | RF50  | RFMEAN | %D   |
|------------------------|------|-------|--------|------|
| =====                  |      |       |        |      |
| 1,4-Dichlorobenzene-d4 | I    |       |        |      |
| Naphthalene-d8         | I    |       |        |      |
| 2-Methylnaphthalene    |      | 0.449 | 0.493  | 8.9  |
| Naphthalene            |      | 0.574 | 0.624  | 8.0  |
| Acenaphthene-d10       | I    |       |        |      |
| Acenaphthene           | C    | 0.578 | 0.609  | 5.1  |
| Fluorene               |      | 0.745 | 0.790  | 5.7  |
| 2-Chloronaphthalene    |      | 0.600 | 0.655  | 8.4  |
| Acenaphthylene         |      | 1.001 | 1.032  | 3.0  |
| Phenanthrene-d10       | I    |       |        |      |
| Phenanthrene           |      | 0.552 | 0.557  | 0.9  |
| Anthracene             |      | 0.588 | 0.559  | -1.6 |
| Fluoranthene           | C    | 0.653 | 0.639  | -2.2 |
| Chrysene-d12           | I    |       |        |      |
| Chrysene               |      | 0.539 | 0.577  | 6.6  |
| Pyrene                 |      | 0.759 | 0.727  | -4.4 |
| Benzo(a)anthracene     |      | 0.576 | 0.599  | 3.8  |
| Perylene-d12           | I    |       |        |      |
| Benzo(b)fluoranthene   |      | 0.709 | 0.761  | 6.8  |
| Benzo(k)fluoranthene   |      | 0.870 | 0.977  | 11.0 |
| Benzo(e)pyrene         |      | 0.691 | 0.760  | 9.1  |
| Benzo(a)pyrene         | C    | 0.688 | 0.742  | 10.2 |
| Perylene               |      | 0.395 | 0.464  | 14.9 |
| Indeno(1,2,3-cd)pyrene |      | 0.612 | 0.679  | 9.9  |
| Dibenz(a,h)anthracene  |      | 0.448 | 0.485  | 8.0  |
| Benzo(g,h,i)perylene   |      | 0.540 | 0.595  | 9.2  |

| Surrogate      | Flag | RF50  | RFMEAN | %D  |
|----------------|------|-------|--------|-----|
| =====          |      |       |        |     |
| Anthracene-d10 | S    | 0.301 | 0.321  | 6.2 |
| Pyrene-d10     | S    | 0.672 | 0.685  | 3.3 |

Approved by:

*J. Lyon*

Date

1.5.93


\*- Fails QC Criteria for %D; << - Rf less than minimum QC RF; >>- RF greater than maximum QC RF

CCAL.EXE v2.5

30-Dec-92 08:13  
Sample: SST0020

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G




| No. | MAT | FOR | REV | Delta | Area    | P.Flags       | Scan | Q#  | Name                      |
|-----|-----|-----|-----|-------|---------|---------------|------|-----|---------------------------|
| 1   | 100 | 82  | 99  | 1     | 605760  | bb            | 433  | 152 | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 87  | 94  | 0     | 2333500 | bb            | 612  | 136 | Naphthalene-d8            |
| 3   | 100 | 95  | 99  | 1     | 1642400 | bb            | 871  | 164 | Acenaphthene-d10          |
| 4   | 100 | 90  | 97  | 0     | 3708600 | bv            | 1091 | 188 | Phenanthrene-d10          |
| 5   | 97  | 69  | 98  | -1    | 3466100 | bv            | 1487 | 240 | Chrysene-d12              |
| 6   | 100 | 88  | 98  | -1    | 1596700 | bv            | 1767 | 264 | Perylene-d12              |
| 7   | 100 | 96  | 98  | 0     | 307160  | bb            | 257  | 112 | 2-Fluorophenol            |
| 8   | 86  | 41  | 97  | 0     | 354030  | bb            | 401  | 132 | 2-Chlorophenol-d4         |
| 9   | 86  | 52  | 96  | -1    | 379160  | bb            | 388  | 99  | Phenol-d5                 |
| 10  | 100 | 89  | 98  | 0     | 284160  | bb            | 453  | 152 | 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 83  | 99  | 0     | 352780  | bb            | 510  | 82  | Nitrobenzene-d5           |
| 12  | 100 | 64  | 97  | 0     | 348400  | bb            | 559  | 185 | 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 93  | 98  | 0     | 204100  | bb            | 620  | 240 | 1,4-Dibromobenzene-d4     |
| 14  | 100 | 91  | 98  | 0     | 762820  | bb            | 775  | 172 | 2-Fluorobiphenyl          |
| 15  | 100 | 81  | 99  | -1    | 93724   | bb            | 987  | 330 | 2,4,6-Tribromophenol      |
| 16  | 100 | 86  | 97  | 0     | 672030  | vb*           | 1099 | 188 | Anthracene-d10            |
| 17  | 100 | 85  | 97  | 0     | 1426300 | bb            | 1301 | 212 | Pyrene-d10                |
| 18  | 100 | 89  | 98  | 0     | 720310  | bb            | 1334 | 244 | Terphenyl-d14             |
| 19  | 100 | 95  | 98  | 0     | 914460  | bb            | 615  | 128 | Naphthalene               |
| 20  | 100 | 88  | 90  | 0     | 690750  | bb            | 718  | 142 | 2-Methylnaphthalene       |
| 21  | 100 | 96  | 98  | 0     | 639110  | bb            | 788  | 162 | 2-Chloronaphthalene       |
| 22  | 100 | 94  | 97  | 0     | 1001000 | bb            | 849  | 152 | Acenaphthylene            |
| 23  | 100 | 86  | 88  | 0     | 592620  | vb            | 875  | 154 | Acenaphthene              |
| 24  | 100 | 93  | 98  | 0     | 755790  | bb            | 952  | 166 | Fluorene                  |
| 25  | 100 | 84  | 98  | 0     | 92748   | bv            | 1064 | 266 | Pentachlorophenol         |
| 26  | 100 | 93  | 98  | 0     | 1287500 | bv            | 1094 | 178 | Phenanthrene              |
| 27  | 100 | 95  | 98  | -1    | 1289400 | vb*           | 1101 | 178 | Anthracene                |
| 28  | 100 | 95  | 99  | 0     | 1426100 | bb            | 1271 | 202 | Fluoranthene              |
| 29  | 100 | 91  | 98  | -1    | 1642600 | bb            | 1303 | 202 | Pyrene                    |
| 30  | 86  | 62  | 75  | 0     | 1189700 | bv            | 1486 | 228 | Benzo(a)anthracene        |
| 31  | 97  | 75  | 92  | -1    | 1222400 | vv            | 1491 | 228 | Chrysene                  |
| 32  | 81  | 68  | 71  | -1    | 514370  | b!✓           | 1686 | 252 | Benzo(b)fluoranthene      |
| 33  | 100 | 92  | 97  | -1    | 958380  | !v ✓ 12-24-92 | 1692 | 252 | Benzo(k)fluoranthene      |
| 34  | 100 | 94  | 98  | -1    | 590460  | bv            | 1743 | 252 | Benzo(e)pyrene            |
| 35  | 100 | 94  | 97  | -1    | 614730  | vv            | 1754 | 252 | Benzo(a)pyrene            |
| 36  | 91  | 69  | 77  | 0     | 534550  | vv            | 1773 | 252 | Perylene                  |
| 37  | 98  | 76  | 92  | -1    | 381320  | M             | 1993 | 276 | Indeno(1,2,3-cd)pyrene    |
| 38  | 95  | 75  | 88  | -1    | 228260  | A             | 2002 | 278 | Dibenz(a,h)anthracene     |
| 39  | 93  | 80  | 94  | -2    | 366580  | bv            | 2046 | 276 | Benzo(g,h,i)perylene      |

30-Dec-92 11:55  
Sample: SST0050

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G




| No. | MAT | FOR | REV | Delta | Area    | P.Flags      | Scan | QM Name                       |
|-----|-----|-----|-----|-------|---------|--------------|------|-------------------------------|
| 1   | 100 | 78  | 99  | 1     | 882830  | bb           | 433  | 152 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 85  | 93  | 0     | 3297000 | bv           | 612  | 136 Naphthalene-d8            |
| 3   | 100 | 95  | 99  | 0     | 2183300 | bb           | 870  | 164 Acenaphthene-d10          |
| 4   | 100 | 90  | 97  | -1    | 5186300 | bv           | 1090 | 188 Phenanthrene-d10          |
| 5   | 88  | 56  | 96  | -1    | 4784200 | bv           | 1487 | 240 Chrysene-d12              |
| 6   | 100 | 85  | 93  | -1    | 2429100 | bv           | 1767 | 264 Perylene-d12              |
| 7   | 100 | 95  | 97  | 0     | 933830  | bb           | 257  | 112 2-Fluorophenol            |
| 8   | 84  | 46  | 98  | 0     | 959140  | bb           | 401  | 132 2-Chlorophenol-d4         |
| 9   | 85  | 50  | 97  | -1    | 1234900 | bb           | 388  | 99 Phenol-d5                  |
| 10  | 100 | 80  | 94  | 0     | 729440  | bb           | 453  | 152 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 83  | 99  | 0     | 1237100 | bb           | 510  | 82 Nitrobenzene-d5            |
| 12  | 98  | 59  | 98  | 0     | 852670  | bb           | 559  | 185 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 92  | 98  | 0     | 540100  | bb           | 620  | 240 1,4-Dibromobenzene-d4     |
| 14  | 100 | 90  | 98  | 0     | 1905000 | bb           | 775  | 172 2-Fluorobiphenyl          |
| 15  | 100 | 80  | 99  | -1    | 371440  | bb           | 987  | 330 2,4,6-Tribromophenol      |
| 16  | 100 | 83  | 96  | 0     | 1949800 | vb           | 1099 | 188 Anthracene-d10            |
| 17  | 100 | 85  | 97  | 0     | 4016200 | bb           | 1301 | 212 Pyrene-d10                |
| 18  | 100 | 86  | 97  | 0     | 2578100 | bb           | 1334 | 244 Terphenyl-d14             |
| 19  | 100 | 96  | 99  | 0     | 2364900 | bb           | 615  | 128 Naphthalene               |
| 20  | 100 | 89  | 91  | -1    | 1848900 | bb           | 717  | 142 2-Methylnaphthalene       |
| 21  | 100 | 96  | 98  | 0     | 1638500 | bb           | 788  | 162 2-Chloronaphthalene       |
| 22  | 100 | 94  | 97  | 0     | 2732300 | bb           | 849  | 152 Acenaphthylene            |
| 23  | 100 | 88  | 90  | 0     | 1576600 | vb           | 875  | 154 Acenaphthene              |
| 24  | 100 | 96  | 99  | 0     | 2032500 | bb           | 952  | 166 Fluorene                  |
| 25  | 100 | 85  | 99  | -1    | 453910  | bv           | 1063 | 266 Pentachlorophenol         |
| 26  | 100 | 93  | 98  | 0     | 3581700 | bv*          | 1094 | 178 Phenanthrene              |
| 27  | 100 | 94  | 98  | 0     | 3684800 | vv*          | 1102 | 178 Anthracene                |
| 28  | 100 | 95  | 99  | 0     | 4231300 | bv           | 1271 | 202 Fluoranthene              |
| 29  | 100 | 93  | 99  | -1    | 4536900 | vv           | 1303 | 202 Pyrene                    |
| 30  | 100 | 85  | 97  | 0     | 3446200 | bv           | 1486 | 228 Benzo(a)anthracene        |
| 31  | 100 | 89  | 99  | -1    | 3222900 | vv           | 1491 | 228 Chrysene                  |
| 32  | 81  | 67  | 72  | -1    | 2151900 | bv           | 1686 | 252 Benzo(b)fluoranthene      |
| 33  | 100 | 92  | 97  | -1    | 2643000 | vv           | 1692 | 252 Benzo(k)fluoranthene      |
| 34  | 100 | 93  | 98  | -1    | 2098300 | vv           | 1743 | 252 Benzo(e)pyrene            |
| 35  | 100 | 94  | 99  | -1    | 2023500 | vv           | 1754 | 252 Benzo(a)pyrene            |
| 36  | 100 | 89  | 96  | 0     | 1198900 | vv           | 1773 | 252 Perylene                  |
| 37  | 100 | 94  | 100 | -2    | 1857500 | b? <i>me</i> | 1992 | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 90  | 97  | -2    | 1352900 | b? <i>me</i> | 2001 | 278 Dibenz(a,h)anthracene     |
| 39  | 95  | 94  | 99  | -3    | 1639700 | bv           | 2045 | 276 Benzo(g,h,i)perylene      |



38-Dec-92 09:02  
Sample: SST0080

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G




| No. | MAT | FOR | REV | Delta | Area    | P.Flags | Scan | QM Name                       |
|-----|-----|-----|-----|-------|---------|---------|------|-------------------------------|
| 1   | 100 | 76  | 99  | 1     | 764300  | bb      | 433  | 152 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 87  | 93  | 0     | 2708100 | bb      | 612  | 136 Naphthalene-d8            |
| 3   | 100 | 95  | 99  | 0     | 2006700 | bv      | 870  | 164 Acenaphthene-d10          |
| 4   | 100 | 88  | 97  | 0     | 4760500 | bv      | 1091 | 188 Phenanthrene-d10          |
| 5   | 96  | 58  | 96  | -1    | 4054900 | bv      | 1487 | 240 Chrysene-d12              |
| 6   | 100 | 82  | 93  | -1    | 1814200 | bv      | 1767 | 264 Perylene-d12              |
| 7   | 100 | 94  | 96  | 0     | 1161700 | bb      | 257  | 112 2-Fluorophenol            |
| 8   | 84  | 39  | 96  | 0     | 1294600 | bb      | 401  | 132 2-Chlorophenol-d4         |
| 9   | 84  | 49  | 95  | -1    | 1518700 | bv      | 388  | 99 Phenol-d5                  |
| 10  | 100 | 85  | 96  | 0     | 1041500 | bb      | 453  | 152 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 82  | 98  | 0     | 1781400 | bb      | 510  | 82 Nitrobenzene-d5            |
| 12  | 98  | 59  | 98  | 0     | 1386900 | bb      | 559  | 185 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 92  | 98  | 0     | 881960  | bb      | 620  | 240 1,4-Dibromobenzene-d4     |
| 14  | 100 | 90  | 98  | 0     | 2981600 | bb      | 775  | 172 2-Fluorobiphenyl          |
| 15  | 100 | 78  | 99  | -1    | 468710  | bb      | 987  | 330 2,4,6-Tribromophenol      |
| 16  | 100 | 84  | 96  | 0     | 3001400 | vv      | 1099 | 188 Anthracene-d10            |
| 17  | 100 | 86  | 96  | 0     | 6102800 | bv      | 1301 | 212 Pyrene-d10                |
| 18  | 100 | 86  | 97  | 0     | 3738300 | bb      | 1334 | 244 Terphenyl-d14             |
| 19  | 100 | 95  | 98  | 0     | 3251500 | bb      | 615  | 128 Naphthalene               |
| 20  | 100 | 89  | 91  | 0     | 2557500 | bb      | 718  | 142 2-Methylnaphthalene       |
| 21  | 100 | 95  | 98  | 0     | 2506600 | bb      | 788  | 162 2-Chloronaphthalene       |
| 22  | 100 | 93  | 97  | 0     | 3961900 | bb      | 849  | 152 Acenaphthylene            |
| 23  | 100 | 88  | 90  | 0     | 2301500 | bb      | 875  | 154 Acenaphthene              |
| 24  | 100 | 95  | 99  | 0     | 3052200 | vb      | 952  | 166 Fluorene                  |
| 25  | 100 | 84  | 99  | 0     | 594490  | bv      | 1064 | 266 Pentachlorophenol         |
| 26  | 100 | 93  | 98  | 0     | 5266600 | bv*     | 1094 | 178 Phenanthrene              |
| 27  | 100 | 93  | 98  | 0     | 5394700 | vb*     | 1102 | 178 Anthracene                |
| 28  | 100 | 94  | 99  | 0     | 6173200 | bb      | 1271 | 202 Fluoranthene              |
| 29  | 100 | 94  | 99  | 0     | 6414000 | vv      | 1304 | 202 Pyrene                    |
| 30  | 100 | 77  | 94  | 0     | 4844500 | bv      | 1486 | 228 Benzo(a)anthracene        |
| 31  | 100 | 89  | 99  | -1    | 4559800 | vv      | 1491 | 228 Chrysene                  |
| 32  | 83  | 69  | 74  | -1    | 2662000 | bv      | 1686 | 252 Benzo(b)fluoranthene      |
| 33  | 100 | 92  | 98  | -1    | 3506200 | vv      | 1692 | 252 Benzo(k)fluoranthene      |
| 34  | 100 | 93  | 98  | -1    | 2702100 | bv      | 1743 | 252 Benzo(e)pyrene            |
| 35  | 100 | 94  | 99  | -1    | 2643100 | vv      | 1754 | 252 Benzo(a)pyrene            |
| 36  | 100 | 91  | 97  | 0     | 1564400 | vv      | 1773 | 252 Perylene                  |
| 37  | 100 | 94  | 99  | -1    | 2425500 | b3      | 1993 | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 88  | 97  | -1    | 1732500 | bv      | 2002 | 278 Dibenz(a,h)anthracene     |
| 39  | 100 | 94  | 99  | -2    | 2181100 | b2      | 2046 | 276 Benzo(g,h,i)perylene      |

12.30m

30-Dec-92 09:54  
Sample: SSTDI20

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G




| No. | MAT | FOR | REV | Delta | Area    | P.Flags         | Scan | QM Name                       |
|-----|-----|-----|-----|-------|---------|-----------------|------|-------------------------------|
| 1   | 99  | 71  | 99  | 1     | 766540  | bb              | 433  | 152 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 87  | 93  | 0     | 2795600 | bv              | 612  | 136 Naphthalene-d8            |
| 3   | 100 | 93  | 99  | 0     | 1970900 | bv              | 870  | 164 Acenaphthene-d10          |
| 4   | 100 | 86  | 97  | 0     | 4722600 | bv              | 1091 | 188 Phenanthrene-d10          |
| 5   | 88  | 46  | 95  | 0     | 4362400 | bv              | 1488 | 240 Chrysene-d12              |
| 6   | 100 | 82  | 93  | 0     | 2102900 | bv              | 1768 | 264 Perylene-d12              |
| 7   | 100 | 94  | 96  | 0     | 1884100 | bb              | 257  | 112 2-Fluorophenol            |
| 8   | 84  | 39  | 96  | 0     | 1982200 | bb              | 401  | 132 2-Chlorophenol-d4         |
| 9   | 91  | 49  | 96  | 0     | 2575800 | bv              | 389  | 99 Phenol-d5                  |
| 10  | 100 | 84  | 95  | 0     | 1561900 | bb              | 453  | 152 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 82  | 98  | 0     | 2939500 | bb              | 510  | 82 Nitrobenzene-d5            |
| 12  | 96  | 56  | 98  | 0     | 2003500 | bb              | 559  | 185 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 92  | 98  | 0     | 1325900 | bb              | 620  | 240 1,4-Dibromobenzene-d4     |
| 14  | 100 | 90  | 98  | 0     | 4310300 | bb              | 775  | 172 2-Fluorobiphenyl          |
| 15  | 100 | 80  | 99  | 0     | 813340  | bv              | 988  | 330 2,4,6-Tribromophenol      |
| 16  | 100 | 84  | 96  | 0     | 4382700 | vv              | 1099 | 188 Anthracene-d10            |
| 17  | 100 | 86  | 97  | 0     | 8571700 | bb              | 1301 | 212 Pyrene-d10                |
| 18  | 100 | 86  | 97  | 0     | 6000300 | bv              | 1334 | 244 Terphenyl-d14             |
| 19  | 100 | 95  | 98  | 0     | 4952300 | bv              | 615  | 128 Naphthalene               |
| 20  | 100 | 88  | 91  | 0     | 3956800 | vb              | 718  | 142 2-Methylnaphthalene       |
| 21  | 100 | 95  | 98  | 0     | 3695300 | bb              | 788  | 162 2-Chloronaphthalene       |
| 22  | 100 | 93  | 97  | 0     | 5875400 | bb              | 849  | 152 Acenaphthylene            |
| 23  | 100 | 87  | 90  | 0     | 3434300 | bv              | 875  | 154 Acenaphthene              |
| 24  | 100 | 95  | 99  | 0     | 4482800 | bb              | 952  | 166 Fluorene                  |
| 25  | 100 | 82  | 98  | 0     | 1063900 | bv              | 1064 | 266 Pentachlorophenol         |
| 26  | 100 | 92  | 97  | 0     | 7180800 | bv*             | 1094 | 178 Phenanthrene              |
| 27  | 100 | 93  | 99  | 0     | 7059400 | vv*             | 1102 | 178 Anthracene                |
| 28  | 100 | 93  | 98  | 0     | 8357300 | bv              | 1271 | 202 Fluoranthene              |
| 29  | 100 | 92  | 98  | 0     | 8125200 | bv              | 1304 | 202 Pyrene                    |
| 30  | 100 | 81  | 99  | 0     | 7526200 | bv              | 1486 | 228 Benzo(a)anthracene        |
| 31  | 100 | 92  | 99  | 0     | 7249100 | vv              | 1492 | 228 Chrysene                  |
| 32  | 89  | 68  | 74  | 0     | 5265400 | bv              | 1687 | 252 Benzo(b)fluoranthene      |
| 33  | 100 | 91  | 97  | 0     | 5940900 | v? <i>1201</i>  | 1693 | 252 Benzo(k)fluoranthene      |
| 34  | 100 | 93  | 98  | 0     | 5011200 | vv              | 1744 | 252 Benzo(e)pyrene            |
| 35  | 100 | 94  | 99  | 0     | 4819800 | vv              | 1755 | 252 Benzo(a)pyrene            |
| 36  | 100 | 92  | 99  | 0     | 2719800 | v? <i>11-34</i> | 1773 | 252 Perylene                  |
| 37  | 100 | 94  | 99  | 0     | 4816000 | b?              | 1994 | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 90  | 98  | 0     | 3567700 | bb              | 2003 | 278 Dibenz(a,h)anthracene     |
| 39  | 100 | 94  | 99  | 0     | 4160600 | bv              | 2048 | 276 Benzo(g,h,i)perylene      |

30-Dec-92 10:46  
Sample: SSTD160

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G



| No. | MAT | FOR | REV | Delta | Area     | P.Flags          | Scan | QM  | Name                      |
|-----|-----|-----|-----|-------|----------|------------------|------|-----|---------------------------|
| 1   | 100 | 82  | 99  | 1     | 758980   | bb               | 433  | 152 | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 86  | 94  | 0     | 2826100  | bv               | 612  | 136 | Naphthalene-d8            |
| 3   | 100 | 90  | 98  | 0     | 1906200  | bv               | 870  | 164 | Acenaphthene-d10          |
| 4   | 100 | 87  | 97  | -1    | 4422300  | bv               | 1090 | 188 | Phenanthrene-d10          |
| 5   | 86  | 53  | 95  | 0     | 4440200  | bv               | 1488 | 240 | Chrysene-d12              |
| 6   | 100 | 84  | 95  | 1     | 2587000  | vv               | 1769 | 264 | Perylene-d12              |
| 7   | 100 | 94  | 96  | 0     | 2789900  | bb               | 257  | 112 | 2-Fluorophenol            |
| 8   | 85  | 40  | 96  | 0     | 2786400  | bb               | 401  | 132 | 2-Chlorophenol-d4         |
| 9   | 93  | 51  | 97  | 0     | 3948100  | bv               | 389  | 99  | Phenol-d5                 |
| 10  | 100 | 83  | 95  | 0     | 2128800  | bb               | 453  | 152 | 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 77  | 98  | 1     | 4036800  | bb               | 511  | 82  | Nitrobenzene-d5           |
| 12  | 95  | 54  | 98  | 0     | 2583100  | bb               | 559  | 185 | 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 91  | 98  | 0     | 1739900  | bb               | 620  | 240 | 1,4-Dibromobenzene-d4     |
| 14  | 100 | 89  | 98  | 0     | 5551900  | bb               | 775  | 172 | 2-Fluorobiphenyl          |
| 15  | 100 | 76  | 98  | 0     | 1248900  | bv               | 988  | 330 | 2,4,6-Tribromophenol      |
| 16  | 100 | 85  | 97  | 0     | 5675000  | bv               | 1099 | 188 | Anthracene-d10            |
| 17  | 100 | 86  | 97  | 1     | 10205000 | vv               | 1302 | 212 | Pyrene-d10                |
| 18  | 100 | 85  | 97  | 0     | 7211700  | bv               | 1334 | 244 | Terphenyl-d14             |
| 19  | 100 | 95  | 98  | 0     | 6481300  | bv               | 615  | 128 | Naphthalene               |
| 20  | 100 | 88  | 91  | 0     | 5471700  | vv               | 718  | 142 | 2-Methylnaphthalene       |
| 21  | 100 | 95  | 98  | 0     | 4920700  | bb               | 788  | 162 | 2-Chloronaphthalene       |
| 22  | 100 | 93  | 97  | 0     | 7310800  | bb               | 849  | 152 | Acenaphthylene            |
| 23  | 100 | 88  | 90  | 0     | 4524100  | bv               | 875  | 154 | Acenaphthene              |
| 24  | 100 | 91  | 97  | 0     | 5841900  | bv               | 952  | 166 | Fluorene                  |
| 25  | 100 | 82  | 98  | 0     | 1469400  | bv               | 1064 | 266 | Pentachlorophenol         |
| 26  | 100 | 91  | 97  | 0     | 8596200  | bv*              | 1094 | 178 | Phenanthrene              |
| 27  | 100 | 92  | 98  | 0     | 8404800  | vv*              | 1102 | 178 | Anthracene                |
| 28  | 100 | 92  | 97  | 0     | 9614400  | vv               | 1271 | 202 | Fluoranthene              |
| 29  | 100 | 90  | 96  | 1     | 9222100  | bv               | 1305 | 202 | Pyrene                    |
| 30  | 100 | 82  | 99  | 0     | 9945500  | bv               | 1486 | 228 | Benzo(a)anthracene        |
| 31  | 100 | 91  | 98  | 1     | 9301300  | vv               | 1493 | 228 | Chrysene                  |
| 32  | 81  | 67  | 73  | 1     | 9129500  | b! <i>117000</i> | 1688 | 252 | Benzo(b)fluoranthene      |
| 33  | 100 | 91  | 97  | 1     | 9354000  | vv               | 1694 | 252 | Benzo(k)fluoranthene      |
| 34  | 100 | 92  | 98  | 1     | 8601700  | bv               | 1745 | 252 | Benzo(e)pyrene            |
| 35  | 100 | 93  | 99  | 2     | 8073700  | vv               | 1757 | 252 | Benzo(a)pyrene            |
| 36  | 100 | 93  | 99  | 1     | 4063300  | vv               | 1774 | 252 | Perylene                  |
| 37  | 100 | 93  | 99  | 2     | 9050200  | b? <i>117000</i> | 1996 | 276 | Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 89  | 98  | 1     | 6710900  | bb               | 2004 | 278 | Dibenz(a,h)anthracene     |
| 39  | 100 | 94  | 99  | 2     | 7424800  | bv               | 2050 | 276 | Benzo(g,h,i)perylene      |

30-Dec-92 07:56  
Sample: DFTPP

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G




Table 10-10-10

139110

| PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int |
|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|
| 1   | 36   | 1440    | 0.37    | 49  | 96   | 1328    | 0.34    | 97  | 149  | 2240    | 0.53    | 145 | 202  | 3608    | 0.77    | 193 | 258  | 7424    | 1.21    |
| 2   | 37   | 1136    | 0.29    | 50  | 98   | 13440   | 3.45    | 98  | 150  | 792     | 0.20    | 146 | 202  | 676     | 0.17    | 194 | 259  | 1536    | 0.37    |
| 3   | 38   | 1136    | 0.31    | 51  | 99   | 13224   | 3.14    | 99  | 151  | 1440    | 0.37    | 147 | 203  | 2516    | 0.72    | 195 | 265  | 2930    | 0.74    |
| 4   | 39   | 19200   | 4.93    | 52  | 100  | 1296    | 0.33    | 100 | 152  | 876     | 0.23    | 148 | 204  | 12330   | 3.16    | 196 | 266  | 744     | 0.19    |
| 5   | 40   | 2394    | 0.64    | 53  | 101  | 7296    | 1.35    | 101 | 153  | 2624    | 0.67    | 149 | 205  | 20224   | 5.20    | 197 | 273  | 4864    | 1.25    |
| 6   | 41   | 812     | 0.21    | 54  | 102  | 2368    | 0.61    | 102 | 154  | 2176    | 0.56    | 150 | 206  | 79872   | 20.55   | 198 | 274  | 11392   | 2.93    |
| 7   | 44   | 1680    | 0.43    | 55  | 104  | 4224    | 1.09    | 103 | 155  | 4923    | 1.27    | 151 | 207  | 10944   | 2.81    | 199 | 275  | 60672   | 15.59   |
| 8   | 49   | 1712    | 0.44    | 56  | 105  | 3824    | 0.92    | 104 | 156  | 6784    | 1.74    | 152 | 208  | 3136    | 0.81    | 200 | 276  | 8064    | 2.07    |
| 9   | 50   | 56320   | 14.47   | 57  | 106  | 1722    | 0.46    | 105 | 157  | 1648    | 0.42    | 153 | 209  | 1408    | 0.36    | 201 | 277  | 4544    | 1.17    |
| 10  | 51   | 222152  | 58.62   | 58  | 107  | 53112   | 14.93   | 106 | 158  | 1824    | 0.47    | 154 | 210  | 2128    | 0.55    | 202 | 278  | 1056    | 0.27    |
| 11  | 52   | 12672   | 3.26    | 59  | 108  | 9216    | 2.37    | 107 | 159  | 1408    | 0.36    | 155 | 211  | 4600    | 1.23    | 203 | 283  | 800     | 0.21    |
| 12  | 53   | 928     | 0.24    | 60  | 109  | 1824    | 0.47    | 108 | 160  | 2752    | 0.71    | 156 | 212  | 1408    | 0.36    | 204 | 285  | 1232    | 0.32    |
| 13  | 55   | 1296    | 0.33    | 61  | 110  | 103424  | 26.58   | 109 | 161  | 4032    | 1.04    | 157 | 213  | 748     | 0.19    | 205 | 293  | 1360    | 0.35    |
| 14  | 56   | 6912    | 1.78    | 62  | 111  | 15372   | 4.08    | 110 | 162  | 1504    | 0.39    | 158 | 215  | 1344    | 0.35    | 206 | 296  | 14784   | 3.80    |
| 15  | 57   | 14948   | 3.82    | 63  | 112  | 2592    | 0.67    | 111 | 165  | 2656    | 0.68    | 159 | 216  | 1872    | 0.48    | 207 | 297  | 2352    | 0.60    |
| 16  | 58   | 1104    | 0.23    | 64  | 113  | 1120    | 0.29    | 112 | 166  | 2368    | 0.61    | 160 | 217  | 19712   | 5.07    | 208 | 303  | 2320    | 0.60    |
| 17  | 61   | 2480    | 0.64    | 65  | 116  | 3408    | 0.88    | 113 | 167  | 14848   | 3.32    | 161 | 218  | 3088    | 0.79    | 209 | 304  | 680     | 0.17    |
| 18  | 62   | 3056    | 0.79    | 66  | 117  | 33792   | 8.68    | 114 | 168  | 9024    | 2.32    | 162 | 220  | 732     | 0.19    | 210 | 314  | 894     | 0.23    |
| 19  | 63   | 7680    | 1.97    | 67  | 118  | 3516    | 0.93    | 115 | 169  | 1680    | 0.43    | 163 | 221  | 25112   | 6.71    | 211 | 315  | 1760    | 0.45    |
| 20  | 64   | 1328    | 0.34    | 68  | 119  | 764     | 0.20    | 116 | 170  | 900     | 0.23    | 164 | 222  | 4928    | 1.27    | 212 | 316  | 1168    | 0.30    |
| 21  | 65   | 4572    | 1.20    | 69  | 120  | 1072    | 0.28    | 117 | 171  | 848     | 0.22    | 165 | 223  | 4928    | 1.27    | 213 | 321  | 764     | 0.20    |
| 22  | 68   | 2992    | 0.77    | 70  | 122  | 3232    | 0.83    | 118 | 172  | 1376    | 0.35    | 166 | 224  | 41984   | 10.79   | 214 | 323  | 6400    | 1.64    |
| 23  | 69   | 220160  | 56.58   | 71  | 123  | 5056    | 1.30    | 119 | 173  | 2128    | 0.55    | 167 | 225  | 10752   | 2.76    | 215 | 324  | 1216    | 0.31    |
| 24  | 70   | 1840    | 0.47    | 72  | 124  | 2576    | 0.66    | 120 | 174  | 3184    | 0.82    | 168 | 226  | 1472    | 0.38    | 216 | 327  | 1072    | 0.28    |
| 25  | 71   | 1120    | 0.29    | 73  | 125  | 2448    | 0.63    | 121 | 175  | 6336    | 1.63    | 169 | 227  | 14208   | 3.65    | 217 | 334  | 3936    | 1.01    |
| 26  | 72   | 780     | 0.20    | 74  | 126  | 916     | 0.24    | 122 | 176  | 2384    | 0.64    | 170 | 228  | 2352    | 0.60    | 218 | 335  | 1104    | 0.28    |
| 27  | 73   | 1376    | 0.35    | 75  | 127  | 206848  | 53.16   | 123 | 177  | 3152    | 0.81    | 171 | 229  | 3552    | 0.91    | 219 | 341  | 688     | 0.18    |
| 28  | 74   | 19456   | 5.00    | 76  | 128  | 15552   | 4.00    | 124 | 178  | 1024    | 0.26    | 172 | 230  | 784     | 0.20    | 220 | 346  | 1200    | 0.31    |
| 29  | 75   | 31232   | 8.03    | 77  | 129  | 70656   | 18.16   | 125 | 179  | 11904   | 3.06    | 173 | 231  | 2256    | 0.58    | 221 | 352  | 1824    | 0.47    |
| 30  | 76   | 11200   | 2.98    | 78  | 130  | 6464    | 1.66    | 126 | 180  | 8640    | 2.22    | 174 | 234  | 1168    | 0.30    | 222 | 353  | 1344    | 0.35    |
| 31  | 77   | 234496  | 60.26   | 79  | 131  | 1888    | 0.49    | 127 | 181  | 4480    | 1.15    | 175 | 235  | 1360    | 0.35    | 223 | 354  | 1936    | 0.50    |
| 32  | 78   | 17408   | 4.47    | 80  | 132  | 904     | 0.23    | 128 | 182  | 732     | 0.19    | 176 | 236  | 1104    | 0.28    | 224 | 365  | 7360    | 1.89    |
| 33  | 79   | 11904   | 3.06    | 81  | 133  | 332     | 0.21    | 129 | 184  | 1008    | 0.26    | 177 | 237  | 1568    | 0.40    | 225 | 366  | 938     | 0.25    |
| 34  | 80   | 10496   | 2.70    | 82  | 134  | 2064    | 0.53    | 130 | 185  | 5888    | 1.51    | 178 | 239  | 848     | 0.22    | 226 | 371  | 728     | 0.19    |
| 35  | 81   | 14720   | 3.78    | 83  | 135  | 5312    | 1.37    | 131 | 186  | 45824   | 11.73   | 179 | 240  | 772     | 0.20    | 227 | 372  | 3360    | 0.86    |
| 36  | 82   | 4224    | 1.09    | 84  | 136  | 2672    | 0.69    | 132 | 187  | 13120   | 3.37    | 180 | 241  | 776     | 0.20    | 228 | 373  | 820     | 0.21    |
| 37  | 93   | 4258    | 1.10    | 95  | 137  | 3504    | 0.90    | 133 | 188  | 1472    | 0.38    | 181 | 242  | 2496    | 0.64    | 229 | 383  | 872     | 0.22    |
| 38  | 94   | 1088    | 0.28    | 86  | 138  | 1072    | 0.28    | 134 | 189  | 2384    | 0.61    | 182 | 243  | 2288    | 0.59    | 230 | 402  | 1200    | 0.31    |
| 39  | 95   | 2416    | 0.62    | 87  | 139  | 1276    | 0.33    | 135 | 191  | 1280    | 0.33    | 183 | 244  | 32768   | 8.42    | 231 | 403  | 1936    | 0.50    |
| 40  | 86   | 3984    | 1.02    | 88  | 140  | 844     | 0.22    | 136 | 192  | 3776    | 0.97    | 184 | 245  | 4416    | 1.13    | 232 | 404  | 684     | 0.18    |
| 41  | 87   | 2208    | 0.57    | 89  | 141  | 7936    | 2.04    | 137 | 193  | 4032    | 1.04    | 185 | 246  | 5120    | 1.32    | 233 | 421  | 1456    | 0.37    |
| 42  | 88   | 1264    | 0.32    | 90  | 142  | 2992    | 0.77    | 138 | 194  | 980     | 0.25    | 186 | 247  | 1504    | 0.39    | 234 | 422  | 1520    | 0.39    |
| 43  | 89   | 1120    | 0.29    | 91  | 143  | 2224    | 0.57    | 139 | 196  | 11264   | 2.89    | 187 | 249  | 1296    | 0.33    | 235 | 423  | 11712   | 3.01    |
| 44  | 91   | 3344    | 0.86    | 92  | 144  | 808     | 0.21    | 140 | 197  | 1534    | 0.41    | 188 | 253  | 712     | 0.19    | 236 | 424  | 2496    | 0.64    |
| 45  | 92   | 3200    | 0.82    | 93  | 145  | 876     | 0.23    | 141 | 198  | 389120  | 100.00  | 189 | 254  | 760     | 0.20    | 237 | 441  | 35328   | 9.08    |
| 46  | 93   | 19200   | 4.93    | 94  | 146  | 1728    | 0.44    | 142 | 199  | 26112   | 6.71    | 190 | 255  | 148480  | 38.16   | 238 | 442  | 229376  | 58.95   |
| 47  | 94   | 1856    | 0.46    | 95  | 147  | 4160    | 1.07    | 143 | 200  | 2976    | 0.76    | 191 | 256  | 22016   | 5.66    | 239 | 443  | 42240   | 10.86   |
| 48  | 95   | 856     | 0.22    | 96  | 148  | 8256    | 2.12    | 144 | 201  | 808     | 0.21    | 192 | 257  | 2160    | 0.56    | 240 | 444  | 4608    | 1.12    |



# DETAILED TUNE CHECK REPORT

139


Raw Data File: GL461  
Date: 30-Dec-92  
Time: 07:56

| M/E | ION ABUNDANCE CRITERIA             | RELATIVE<br>ABUNDANCE | TUNE |
|-----|------------------------------------|-----------------------|------|
| 51  | 30.0 - 60.0% of mass 198           | 58.68                 | PASS |
| 69  | Less than 2.0% of mass 69          | 0.77( 1.4)1           | PASS |
| 69  | Mass 69 relative abundance         | 56.58                 | PASS |
| 70  | Less than 2.0% of mass 69          | 0.47( 0.8)1           | PASS |
| 127 | 40.0 - 60.0% of mass 198           | 53.16                 | PASS |
| 197 | Less than 1% of mass 198           | 0.41                  | PASS |
| 198 | Base peak. 100% relative abundance | 100.00                | PASS |
| 199 | 5 - 9% of mass 198                 | 6.71                  | PASS |
| 275 | 10 - 30% of mass 198               | 15.59                 | PASS |
| 365 | Greater than 1% of mass 198        | 1.89                  | PASS |
| 441 | Present, but less than mass 443    | 9.08                  | PASS |
| 442 | Greater than 40% of mass 198       | 58.95                 | PASS |
| 443 | 17 - 23% of mass 442               | 10.86( 18.4)2         | PASS |

30-Dec-92 11:38  
Sample: DFTPP

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G



| PK# | Mass   | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK#  | Mass | Abs Int | Rel Int |
|-----|--------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|------|------|---------|---------|
| 36  | 1895   | 0.44    |         | 52  | 99   | 14203   | 3.37    | 103 | 154  | 2384    | 0.57    | 154 | 208  | 3696    | 0.88    | 1205 | 274  | 13888   | 3.27    |
| 37  | 1040   | 0.25    |         | 53  | 100  | 1776    | 0.41    | 104 | 155  | 5504    | 1.30    | 155 | 209  | 1680    | 0.40    | 1206 | 275  | 77824   | 19.45   |
| 38  | 3632   | 0.86    |         | 54  | 101  | 9089    | 2.15    | 105 | 156  | 7803    | 1.85    | 156 | 210  | 4416    | 1.05    | 1207 | 276  | 10816   | 2.56    |
| 39  | 17456  | 4.61    |         | 55  | 102  | 944     | 0.22    | 106 | 157  | 2320    | 0.55    | 157 | 211  | 4160    | 0.99    | 1208 | 277  | 5760    | 1.37    |
| 40  | 2443   | 0.58    |         | 56  | 103  | 3136    | 0.74    | 107 | 158  | 2224    | 0.53    | 158 | 212  | 688     | 0.16    | 1209 | 278  | 1360    | 0.32    |
| 41  | 782    | 0.19    |         | 57  | 104  | 5440    | 1.29    | 108 | 159  | 1488    | 0.35    | 159 | 214  | 716     | 0.17    | 1210 | 283  | 982     | 0.23    |
| 44  | 1424   | 0.34    |         | 58  | 105  | 5055    | 1.20    | 109 | 160  | 3088    | 0.73    | 160 | 215  | 1312    | 0.31    | 1211 | 284  | 860     | 0.20    |
| 45  | 708    | 0.17    |         | 59  | 106  | 2931    | 0.48    | 110 | 161  | 4416    | 1.05    | 161 | 216  | 1984    | 0.47    | 1212 | 285  | 1456    | 0.35    |
| 49  | 1472   | 0.35    |         | 60  | 107  | 67584   | 16.02   | 111 | 162  | 1648    | 0.39    | 162 | 217  | 23040   | 5.46    | 1213 | 293  | 1744    | 0.41    |
| 50  | 58624  | 13.90   |         | 61  | 108  | 10944   | 2.59    | 112 | 164  | 796     | 0.19    | 163 | 218  | 3696    | 0.88    | 1214 | 296  | 18688   | 4.43    |
| 51  | 242688 | 57.52   |         | 62  | 109  | 2258    | 0.54    | 113 | 165  | 3488    | 0.93    | 164 | 220  | 712     | 0.17    | 1215 | 297  | 2672    | 0.63    |
| 52  | 13248  | 3.14    |         | 63  | 110  | 121356  | 28.38   | 114 | 166  | 2976    | 0.71    | 165 | 221  | 30720   | 7.28    | 1216 | 303  | 2912    | 0.69    |
| 53  | 1328   | 0.31    |         | 64  | 111  | 19431   | 4.37    | 115 | 167  | 16640   | 3.94    | 166 | 222  | 5824    | 1.33    | 1217 | 304  | 832     | 0.20    |
| 55  | 1488   | 0.35    |         | 65  | 112  | 2864    | 0.68    | 116 | 168  | 10496   | 2.49    | 167 | 223  | 5888    | 1.40    | 1218 | 314  | 1280    | 0.30    |
| 56  | 7616   | 1.81    |         | 66  | 113  | 1376    | 0.33    | 117 | 169  | 2096    | 0.50    | 168 | 224  | 51200   | 12.14   | 1219 | 315  | 2448    | 0.58    |
| 57  | 16896  | 4.00    |         | 67  | 116  | 3744    | 0.89    | 118 | 170  | 864     | 0.20    | 169 | 225  | 12736   | 3.02    | 1220 | 316  | 1456    | 0.35    |
| 58  | 1264   | 0.30    |         | 68  | 117  | 38144   | 9.04    | 119 | 171  | 1040    | 0.25    | 170 | 226  | 1472    | 0.35    | 1221 | 321  | 1008    | 0.24    |
| 59  | 864    | 0.20    |         | 69  | 118  | 3792    | 0.90    | 120 | 172  | 1792    | 0.42    | 171 | 227  | 17152   | 4.07    | 1222 | 323  | 7936    | 1.82    |
| 61  | 2928   | 0.59    |         | 70  | 119  | 1020    | 0.24    | 121 | 173  | 2336    | 0.55    | 172 | 228  | 2864    | 0.68    | 1223 | 324  | 1520    | 0.36    |
| 62  | 3520   | 0.83    |         | 71  | 120  | 264     | 0.20    | 122 | 174  | 3744    | 0.89    | 173 | 229  | 4672    | 1.11    | 1224 | 327  | 1312    | 0.31    |
| 63  | 9688   | 2.15    |         | 72  | 122  | 3968    | 0.94    | 123 | 175  | 7360    | 1.74    | 174 | 230  | 1056    | 0.25    | 1225 | 328  | 808     | 0.19    |
| 64  | 1824   | 0.43    |         | 73  | 123  | 5952    | 1.41    | 124 | 176  | 2528    | 0.60    | 175 | 231  | 2528    | 0.60    | 1226 | 333  | 796     | 0.19    |
| 65  | 5568   | 1.32    |         | 74  | 124  | 2800    | 0.66    | 125 | 177  | 3456    | 0.82    | 176 | 232  | 808     | 0.19    | 1227 | 334  | 4928    | 1.17    |
| 68  | 4352   | 1.03    |         | 75  | 125  | 2736    | 0.65    | 126 | 178  | 1216    | 0.29    | 177 | 233  | 804     | 0.19    | 1228 | 335  | 1328    | 0.31    |
| 69  | 258048 | 61.17   |         | 76  | 126  | 1372    | 0.33    | 127 | 179  | 13184   | 3.13    | 178 | 234  | 1328    | 0.31    | 1229 | 341  | 960     | 0.23    |
| 70  | 1696   | 0.40    |         | 77  | 127  | 243712  | 57.77   | 128 | 180  | 9408    | 2.23    | 179 | 235  | 1952    | 0.46    | 1230 | 346  | 1600    | 0.32    |
| 73  | 2512   | 0.60    |         | 78  | 128  | 18176   | 4.31    | 129 | 181  | 4928    | 1.17    | 180 | 236  | 1248    | 0.30    | 1231 | 352  | 2432    | 0.59    |
| 74  | 22784  | 5.40    |         | 79  | 129  | 83968   | 19.90   | 130 | 182  | 1072    | 0.25    | 181 | 237  | 1968    | 0.47    | 1232 | 353  | 1872    | 0.44    |
| 75  | 36264  | 8.74    |         | 80  | 130  | 7744    | 1.84    | 131 | 184  | 1280    | 0.30    | 182 | 239  | 1040    | 0.25    | 1233 | 354  | 2640    | 0.63    |
| 76  | 13952  | 3.31    |         | 81  | 131  | 2272    | 0.54    | 132 | 185  | 6656    | 1.58    | 183 | 240  | 700     | 0.17    | 1234 | 365  | 9024    | 2.14    |
| 77  | 273528 | 66.02   |         | 82  | 132  | 1744    | 0.41    | 133 | 186  | 53504   | 12.68   | 184 | 241  | 1232    | 0.29    | 1235 | 366  | 1376    | 0.33    |
| 78  | 20480  | 4.95    |         | 83  | 134  | 2800    | 0.66    | 134 | 187  | 15104   | 3.58    | 185 | 242  | 2880    | 0.68    | 1236 | 371  | 856     | 0.20    |
| 79  | 14144  | 3.35    |         | 84  | 135  | 6656    | 1.58    | 135 | 188  | 1872    | 0.44    | 186 | 243  | 2944    | 0.70    | 1237 | 372  | 4480    | 1.06    |
| 80  | 12288  | 2.91    |         | 85  | 136  | 3040    | 0.72    | 136 | 189  | 3008    | 0.71    | 187 | 244  | 39168   | 9.28    | 1238 | 373  | 1088    | 0.26    |
| 81  | 16896  | 4.00    |         | 86  | 137  | 4224    | 1.00    | 137 | 191  | 1632    | 0.39    | 188 | 245  | 5312    | 1.26    | 1239 | 383  | 1168    | 0.23    |
| 82  | 4992   | 1.18    |         | 87  | 138  | 1552    | 0.37    | 138 | 192  | 4608    | 1.09    | 189 | 246  | 5824    | 1.38    | 1240 | 402  | 1680    | 0.40    |
| 83  | 5956   | 1.20    |         | 88  | 139  | 1004    | 0.24    | 139 | 193  | 4664    | 1.15    | 190 | 247  | 1456    | 0.35    | 1241 | 403  | 2176    | 0.52    |
| 84  | 1328   | 0.31    |         | 89  | 140  | 1520    | 0.36    | 140 | 194  | 1104    | 0.26    | 191 | 249  | 1664    | 0.39    | 1242 | 404  | 820     | 0.19    |
| 85  | 3040   | 0.72    |         | 90  | 141  | 9664    | 2.29    | 141 | 195  | 796     | 0.19    | 192 | 253  | 840     | 0.20    | 1243 | 421  | 2080    | 0.49    |
| 86  | 4416   | 1.05    |         | 91  | 142  | 3504    | 0.83    | 142 | 196  | 13696   | 3.25    | 193 | 254  | 956     | 0.23    | 1244 | 422  | 1664    | 0.35    |
| 87  | 2576   | 0.61    |         | 92  | 143  | 2800    | 0.66    | 143 | 197  | 1024    | 0.24    | 194 | 255  | 182272  | 43.20   | 1245 | 423  | 14016   | 3.32    |
| 88  | 1728   | 0.41    |         | 93  | 144  | 1024    | 0.24    | 144 | 198  | 421888  | 100.00  | 195 | 256  | 26624   | 6.31    | 1246 | 424  | 2816    | 0.67    |
| 89  | 1216   | 0.29    |         | 94  | 145  | 1088    | 0.26    | 145 | 199  | 29440   | 6.98    | 196 | 257  | 2672    | 0.53    | 1247 | 441  | 41216   | 9.77    |
| 91  | 3952   | 0.94    |         | 95  | 146  | 2000    | 0.47    | 146 | 200  | 3264    | 0.77    | 197 | 258  | 9280    | 2.20    | 1248 | 442  | 262144  | 62.14   |
| 92  | 4000   | 0.95    |         | 96  | 147  | 4928    | 1.17    | 147 | 201  | 3104    | 0.74    | 198 | 259  | 1968    | 0.47    | 1249 | 443  | 48640   | 11.53   |
| 93  | 21248  | 5.04    |         | 97  | 148  | 9664    | 2.29    | 148 | 202  | 2080    | 0.49    | 199 | 261  | 1020    | 0.24    | 1250 | 444  | 5440    | 1.29    |
| 94  | 2032   | 0.48    |         | 98  | 149  | 2696    | 0.64    | 149 | 203  | 3040    | 0.72    | 200 | 264  | 820     | 0.19    | 1251 | 445  | 960     | 0.23    |
| 95  | 1168   | 0.28    |         | 99  | 150  | 1020    | 0.24    | 150 | 204  | 13760   | 3.26    | 201 | 265  | 3824    | 0.91    |      |      |         |         |
| 96  | 2032   | 0.48    |         | 100 | 151  | 2016    | 0.48    | 151 | 205  | 23552   | 5.58    | 202 | 266  | 1168    | 0.28    |      |      |         |         |
| 97  | 928    | 0.22    |         | 101 | 152  | 1248    | 0.30    | 152 | 206  | 93184   | 22.09   | 203 | 272  | 820     | 0.19    |      |      |         |         |
| 98  | 14784  | 3.50    |         | 102 | 153  | 3216    | 0.76    | 153 | 207  | 12800   | 3.03    | 204 | 273  | 6080    | 1.44    |      |      |         |         |

OFPP TUNE CHECK REPORT

142

Raw Data File: GL466  
Date: 30-Dec-92  
Time: 11:38

| m/e | ION ABUNDANCE CRITERIA             | RELATIVE<br>ABUNDANCE | TUNE |
|-----|------------------------------------|-----------------------|------|
| 51  | 30.0 - 60.0% of mass 198           | 57.52                 | PASS |
| 63  | Less than 2.0% of mass 69          | 1.03( 1.7)1           | PASS |
| 69  | Mass 69 relative abundance         | 61.17                 | PASS |
| 70  | Less than 2.0% of mass 69          | 0.40( 0.7)1           | PASS |
| 127 | 40.0 - 60.0% of mass 198           | 57.77                 | PASS |
| 197 | Less than 1% of mass 198           | 0.24                  | PASS |
| 198 | Base peak. 100% relative abundance | 100.00                | PASS |
| 199 | 5 - 9% of mass 198                 | 6.98                  | PASS |
| 275 | 10 - 30% of mass 198               | 18.45                 | PASS |
| 365 | Greater than 1% of mass 198        | 2.14                  | PASS |
| 441 | Present, but less than mass 443    | 9.77                  | PASS |
| 442 | Greater than 40% of mass 198       | 62.14                 | PASS |
| 443 | 17 - 23% of mass 442               | 11.53( 18.6)2         | PASS |

Triangle Laboratories of RTP, Inc.  
Initial Calibration Curve

143

ICAL File: ICALGJ03 Date of Analysis :01/03/93 Analyte List: PAH  
RF20 GL497 RF50 GL498 RF80 GL495  
RF120 GL494 RF160 GL498

| Analyte                | Flag | RF20  | RF50  | RF80  | RF120 | RF160 | RFMEAN | %RSD |
|------------------------|------|-------|-------|-------|-------|-------|--------|------|
| =====                  |      |       |       |       |       |       |        |      |
| 1,4-Dichlorobenzene-d4 | I    |       |       |       |       |       |        |      |
| Naphthalene-d8         | I    |       |       |       |       |       |        |      |
| 2-Methylnaphthalene    |      | 0.684 | 0.672 | 0.714 | 0.773 | 0.802 | 0.729  | 7.7  |
| Naphthalene            |      | 1.028 | 0.975 | 1.032 | 1.109 | 1.148 | 1.058  | 6.6  |
| Acenaphthene-d10       | I    |       |       |       |       |       |        |      |
| Acenaphthene           | C    | 0.975 | 0.951 | 1.015 | 1.097 | 1.057 | 1.019  | 5.8  |
| Fluorene               |      | 1.225 | 1.176 | 1.234 | 1.320 | 1.310 | 1.253  | 4.9  |
| 2-Chloronaphthalene    |      | 1.033 | 0.982 | 1.035 | 1.114 | 1.078 | 1.048  | 4.8  |
| Acenaphthylene         |      | 1.705 | 1.683 | 1.766 | 1.952 | 1.848 | 1.791  | 6.2  |
| Phenanthrene-d10       | I    |       |       |       |       |       |        |      |
| Phenanthrene           |      | 0.976 | 0.919 | 0.922 | 0.987 | 0.947 | 0.950  | 3.2  |
| Anthracene             |      | 0.981 | 0.937 | 0.940 | 1.005 | 0.934 | 0.959  | 3.3  |
| Fluoranthene           | C    | 1.143 | 1.117 | 1.143 | 1.214 | 1.143 | 1.152  | 3.2  |
| Chrysene-d12           | I    |       |       |       |       |       |        |      |
| Chrysene               |      | 1.038 | 0.984 | 0.975 | 1.020 | 1.041 | 1.011  | 3.0  |
| Pyrene                 |      | 1.208 | 1.189 | 1.250 | 1.179 | 1.057 | 1.176  | 6.1  |
| Benzo(a)anthracene     |      | 1.052 | 0.989 | 1.058 | 1.072 | 1.068 | 1.048  | 3.2  |
| Perylene-d12           | I    |       |       |       |       |       |        |      |
| Benzo(b)fluoranthene   |      | 1.392 | 1.436 | 1.587 | 1.719 | 1.740 | 1.575  | 10.1 |
| Benzo(k)fluoranthene   |      | 1.624 | 1.727 | 1.720 | 1.718 | 1.733 | 1.704  | 2.7  |
| Benzo(e)pyrene         |      | 1.378 | 1.419 | 1.505 | 1.560 | 1.623 | 1.497  | 6.7  |
| Benzo(a)pyrene         | C    | 1.286 | 1.343 | 1.399 | 1.505 | 1.585 | 1.424  | 8.5  |
| Perylene               |      | 0.756 | 0.711 | 0.753 | 0.766 | 0.787 | 0.755  | 3.7  |
| Indeno(1,2,3-cd)pyrene |      | 0.733 | 0.877 | 1.046 | 1.234 | 1.396 | 1.057  | 25.2 |
| Dibenz(a,h)anthracene  |      | 0.770 | 0.890 | 1.007 | 1.217 | 1.349 | 1.047  | 22.6 |
| Benzo(g,h,i)perylene   |      | 0.923 | 1.046 | 1.183 | 1.341 | 1.462 | 1.193  | 18.2 |
| =====                  |      |       |       |       |       |       |        |      |
| Surrogate              | Flag | RF20  | RF50  | RF80  | RF120 | RF160 | RFMEAN | %RSD |
| =====                  |      |       |       |       |       |       |        |      |
| Anthracene-d10         | S    | 0.522 | 0.508 | 0.516 | 0.553 | 0.537 | 0.527  | 3.4  |
| Pyrene-d10             | S    | 1.081 | 1.081 | 1.162 | 1.125 | 1.085 | 1.103  | 3.6  |

Approved by:

*J. Lyon*


Date

1/5/93

\*- Fails QC Criteria for %RSD; << - Rf less than minimum QC RF; >>- RF greater than maximum QC RF


ICAL.EXE v2.5

1/31/93



| NO. | MAI | FOR | REV | Delta | Area    | P.Flags | Scan | On  | Name                      |
|-----|-----|-----|-----|-------|---------|---------|------|-----|---------------------------|
| 1   | 100 | 85  | 100 | -1    | 270610  | bb      | 419  | 152 | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 89  | 93  | 0     | 1154300 | bb      | 598  | 136 | Naphthalene-d8            |
| 3   | 100 | 94  | 97  | 0     | 630640  | bb      | 856  | 164 | Acenaphthene-d10          |
| 4   | 100 | 92  | 97  | 0     | 1301700 | bv      | 1075 | 158 | Phenanthrene-d10          |
| 5   | 95  | 68  | 96  | -2    | 1327100 | bb      | 1469 | 240 | Chrysene-d12              |
| 6   | 99  | 90  | 95  | 1     | 667600  | bb      | 1739 | 264 | Perylene-d12              |
| 7   | 100 | 97  | 97  | -1    | 263320  | bb      | 243  | 112 | 2-Fluorophenol            |
| 8   | 90  | 56  | 99  | -1    | 235130  | bb      | 387  | 132 | 2-Chlorophenol-d4         |
| 9   | 95  | 64  | 99  | -1    | 327920  | bb      | 376  | 99  | Phenol-d5                 |
| 10  | 100 | 95  | 99  | 0     | 144290  | bb      | 439  | 152 | 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 84  | 99  | 0     | 306170  | bb      | 497  | 82  | Nitrobenzene-d5           |
| 12  | 98  | 60  | 97  | 0     | 180130  | bb      | 545  | 185 | 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 96  | 99  | 0     | 117180  | bb      | 606  | 240 | 1,4-Dibromobenzene-d4     |
| 14  | 100 | 93  | 98  | 0     | 400560  | bb      | 761  | 172 | 2-Fluorobiphenyl          |
| 15  | 100 | 81  | 98  | 0     | 56244   | bb      | 973  | 330 | 2,4,6-Tribromophenol      |
| 16  | 100 | 93  | 97  | -1    | 339660  | vb      | 1083 | 188 | Anthracene-d10            |
| 17  | 100 | 87  | 96  | 1     | 717080  | bb      | 1285 | 212 | Pyrene-d10                |
| 18  | 100 | 91  | 97  | 2     | 440590  | bb      | 1319 | 244 | Terphenyl-d14             |
| 19  | 100 | 96  | 98  | 0     | 593060  | bb      | 601  | 128 | Naphthalene               |
| 20  | 100 | 89  | 90  | 0     | 395050  | bb      | 704  | 142 | 2-Methylnaphthalene       |
| 21  | 100 | 98  | 98  | 0     | 325760  | bb      | 774  | 162 | 2-Chloronaphthalene       |
| 22  | 100 | 96  | 98  | 0     | 537570  | bb      | 834  | 152 | Acenaphthylene            |
| 23  | 100 | 87  | 88  | 0     | 307360  | bb      | 861  | 154 | Acenaphthene              |
| 24  | 100 | 97  | 99  | -1    | 386320  | bb      | 937  | 166 | Fluorene                  |
| 25  | 100 | 96  | 99  | 0     | 48328   | bb      | 1049 | 266 | Pentachlorophenol         |
| 26  | 100 | 95  | 97  | 0     | 635560  | bv*     | 1079 | 178 | Phenanthrene              |
| 27  | 100 | 96  | 99  | -1    | 638590  | vb*     | 1086 | 178 | Anthracene                |
| 28  | 100 | 97  | 99  | -1    | 743660  | bb      | 1255 | 202 | Fluoranthene              |
| 29  | 100 | 96  | 99  | 0     | 801330  | bb      | 1287 | 202 | Pyrene                    |
| 30  | 97  | 79  | 88  | 1     | 697820  | bv      | 1468 | 228 | Benzo(a)anthracene        |
| 31  | 100 | 91  | 98  | 0     | 688860  | vb      | 1473 | 228 | Chrysene                  |
| 32  | 83  | 65  | 67  | 0     | 464780  | bv      | 1661 | 252 | Benzo(b)fluoranthene      |
| 33  | 100 | 95  | 95  | -1    | 542140  | vb*     | 1667 | 252 | Benzo(k)fluoranthene      |
| 34  | 100 | 97  | 98  | -1    | 459930  | bv      | 1716 | 252 | Benzo(e)pyrene            |
| 35  | 100 | 96  | 96  | -2    | 429150  | vv      | 1727 | 252 | Benzo(a)pyrene            |
| 36  | 100 | 89  | 91  | 0     | 252270  | vb      | 1745 | 252 | Perylene                  |
| 37  | 98  | 89  | 94  | -2    | 244740  | bv      | 1964 | 276 | Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 86  | 92  | -1    | 257020  | vb      | 1973 | 278 | Dibenz(a,h)anthracene     |
| 39  | 73  | 87  | 94  | -5    | 307970  | bb      | 2013 | 276 | Benzo(g,h,i)perylene      |


1/3/93






| NO. | MAT | FOR | REV | Delta | Area    | P   | Flags | Scan | Gr  | Name                      |
|-----|-----|-----|-----|-------|---------|-----|-------|------|-----|---------------------------|
| 1   | 100 | 85  | 100 | -1    | 317900  | bb  |       | 419  | 152 | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 90  | 94  | 0     | 1500600 | bb  |       | 598  | 136 | Naphthalene-d8            |
| 3   | 100 | 93  | 98  | 0     | 716270  | bb  |       | 856  | 164 | Acenaphthene-d10          |
| 4   | 100 | 91  | 97  | 0     | 1555900 | bv  |       | 1075 | 188 | Phenanthrene-d10          |
| 5   | 83  | 49  | 94  | -1    | 1342700 | bb  |       | 1470 | 240 | Chrysene-d12              |
| 6   | 100 | 89  | 95  | 0     | 671920  | bb  |       | 1740 | 264 | Perylene-d12              |
| 7   | 100 | 96  | 97  | 0     | 728240  | bb  |       | 244  | 112 | 2-Fluorophenol            |
| 8   | 93  | 61  | 99  | 0     | 651270  | bb  |       | 388  | 132 | 2-Chlorophenol-d4         |
| 9   | 94  | 62  | 99  | -1    | 894450  | bv  |       | 376  | 99  | Phenol-d5                 |
| 10  | 100 | 95  | 99  | 1     | 389120  | bb  |       | 440  | 152 | 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 85  | 99  | 0     | 825660  | bb  |       | 497  | 82  | Nitrobenzene-d5           |
| 12  | 99  | 59  | 99  | 0     | 462560  | bb  |       | 545  | 185 | 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 94  | 99  | 0     | 311620  | bb  |       | 606  | 240 | 1,4-Dibromobenzene-d4     |
| 14  | 100 | 91  | 98  | 0     | 1038800 | bb  |       | 761  | 172 | 2-Fluorobiphenyl          |
| 15  | 100 | 79  | 99  | 0     | 182360  | bb  |       | 973  | 330 | 2,4,6-Tribromophenol      |
| 16  | 100 | 84  | 96  | 0     | 987970  | vb  |       | 1084 | 188 | Anthracene-d10            |
| 17  | 100 | 88  | 97  | 0     | 2083800 | bb  |       | 1285 | 212 | Pyrene-d10                |
| 18  | 100 | 88  | 97  | 1     | 1421800 | bb  |       | 1319 | 244 | Terphenyl-d14             |
| 19  | 100 | 97  | 99  | 0     | 1584500 | bb  |       | 601  | 128 | Naphthalene               |
| 20  | 100 | 89  | 91  | 0     | 1092900 | vb  |       | 704  | 142 | 2-Methylnaphthalene       |
| 21  | 100 | 97  | 99  | 0     | 878850  | bb  |       | 774  | 162 | 2-Chloronaphthalene       |
| 22  | 100 | 95  | 98  | 0     | 1506600 | bb  |       | 834  | 152 | Acenaphthylene            |
| 23  | 100 | 88  | 89  | 0     | 851310  | vb  |       | 861  | 154 | Acenaphthene              |
| 24  | 100 | 95  | 98  | 0     | 1053000 | bb  |       | 938  | 166 | Fluorene                  |
| 25  | 100 | 86  | 99  | 0     | 195430  | bb  |       | 1049 | 266 | Pentachlorophenol         |
| 26  | 100 | 93  | 97  | 0     | 1785000 | bv* |       | 1079 | 178 | Phenanthrene              |
| 27  | 100 | 94  | 98  | 0     | 1822400 | vb* |       | 1087 | 178 | Anthracene                |
| 28  | 100 | 96  | 99  | -1    | 2172400 | bb  |       | 1255 | 202 | Fluoranthene              |
| 29  | 100 | 95  | 99  | 0     | 2292200 | bb  |       | 1288 | 202 | Pyrene                    |
| 30  | 100 | 90  | 99  | 0     | 1907600 | bv* |       | 1468 | 228 | Benzo(a)anthracene        |
| 31  | 100 | 94  | 99  | 0     | 1897700 | vv  |       | 1474 | 228 | Chrysene                  |
| 32  | 81  | 68  | 71  | -1    | 1206000 | bv  |       | 1661 | 252 | Benzo(b)fluoranthene      |
| 33  | 100 | 94  | 97  | -2    | 1450600 | vv  |       | 1667 | 252 | Benzo(k)fluoranthene      |
| 34  | 100 | 96  | 98  | -1    | 1192100 | bv  |       | 1717 | 252 | Benzo(e)pyrene            |
| 35  | 96  | 96  | 99  | -3    | 1127800 | vv  |       | 1727 | 252 | Benzo(a)pyrene            |
| 36  | 100 | 98  | 99  | -1    | 597010  | vb  |       | 1745 | 252 | Perylene                  |
| 37  | 96  | 96  | 99  | -3    | 736640  | bv  |       | 1964 | 276 | Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 94  | 98  | -2    | 747280  | vb  |       | 1973 | 278 | Dibenz(a,h)anthracene     |
| 39  | 70  | 96  | 99  | -6    | 878350  | bv  |       | 2013 | 276 | Benzo(g,h,i)perylene      |

1/3/93




| NO | MAT | FOR | REV | Delus | Area    | P. Flags | Scan | Qm Name                       |
|----|-----|-----|-----|-------|---------|----------|------|-------------------------------|
| 1  | 100 | 85  | 100 | 0     | 320710  | bb       | 420  | 152 1,4-Dichlorobenzene-d4    |
| 2  | 100 | 87  | 94  | 0     | 1358300 | bb       | 599  | 136 Naphthalene-d8            |
| 3  | 100 | 88  | 97  | -1    | 737980  | bb       | 856  | 164 Acenaphthene-d10          |
| 4  | 100 | 87  | 96  | 1     | 1638800 | bv       | 1076 | 188 Phenanthrene-d10          |
| 5  | 81  | 45  | 94  | -2    | 1549800 | bb       | 1470 | 240 Chrysene-d12              |
| 6  | 100 | 87  | 93  | 0     | 665170  | bb       | 1740 | 264 Perylene-d12              |
| 7  | 100 | 95  | 97  | -1    | 1244700 | bb       | 244  | 112 2-Fluorophenol            |
| 8  | 86  | 49  | 99  | -1    | 1124300 | bb       | 388  | 132 2-Chlorophenol-d4         |
| 9  | 96  | 66  | 99  | -1    | 1498300 | bv       | 377  | 99 Phenol-d5                  |
| 10 | 100 | 86  | 97  | 0     | 677300  | bb       | 440  | 152 1,2-Dichlorobenzene-d4    |
| 11 | 100 | 86  | 99  | -1    | 1412100 | bb       | 497  | 82 Nitrobenzene-d5            |
| 12 | 97  | 57  | 98  | 0     | 778180  | bb       | 546  | 185 1,3,5-Trichlorobenzene-d3 |
| 13 | 100 | 94  | 100 | -1    | 531860  | bb       | 606  | 240 1,4-Dibromobenzene-d4     |
| 14 | 100 | 90  | 98  | 1     | 1768300 | bb       | 762  | 172 2-Fluorobiphenyl          |
| 15 | 100 | 80  | 100 | 0     | 339710  | bb       | 973  | 330 2,4,6-Tribromophenol      |
| 16 | 100 | 86  | 97  | -1    | 1638000 | vb       | 1084 | 188 Anthracene-d10            |
| 17 | 100 | 84  | 97  | 1     | 3601800 | vb       | 1286 | 212 Pyrene-d10                |
| 18 | 100 | 88  | 97  | 1     | 2551600 | bb       | 1319 | 244 Terphenyl-d14             |
| 19 | 100 | 96  | 98  | 0     | 2756600 | bb       | 602  | 128 Naphthalene               |
| 20 | 100 | 89  | 92  | -1    | 1908600 | vb       | 704  | 142 2-Methylnaphthalene       |
| 21 | 100 | 95  | 98  | 1     | 1527100 | bb       | 775  | 162 2-Chloronaphthalene       |
| 22 | 100 | 94  | 97  | 1     | 2606600 | bb       | 835  | 152 Acenaphthylene            |
| 23 | 100 | 88  | 90  | 0     | 1498300 | bb       | 861  | 154 Acenaphthene              |
| 24 | 100 | 95  | 98  | 0     | 1821500 | bb       | 938  | 166 Fluorene                  |
| 25 | 100 | 86  | 99  | -1    | 389840  | bv       | 1049 | 266 Pentachlorophenol         |
| 26 | 100 | 93  | 98  | -1    | 3015800 | bv*      | 1079 | 178 Phenanthrene              |
| 27 | 100 | 93  | 98  | -1    | 3075000 | vb       | 1087 | 178 Anthracene                |
| 28 | 100 | 95  | 98  | -1    | 3740300 | bb       | 1256 | 202 Fluoranthene              |
| 29 | 100 | 93  | 98  | 1     | 3874800 | bb       | 1289 | 202 Pyrene                    |
| 30 | 100 | 85  | 98  | 1     | 3278900 | bv*      | 1469 | 228 Benzo(a)anthracene        |
| 31 | 100 | 93  | 99  | 0     | 3021200 | vv       | 1474 | 228 Chrysene                  |
| 32 | 83  | 68  | 72  | 0     | 2105500 | bv       | 1662 | 252 Benzo(b)fluoranthene      |
| 33 | 100 | 93  | 97  | -1    | 2280600 | vv       | 1668 | 252 Benzo(k)fluoranthene      |
| 34 | 100 | 95  | 98  | -1    | 1996400 | bv       | 1717 | 252 Benzo(e)pyrene            |
| 35 | 100 | 96  | 99  | -2    | 1856100 | vv       | 1778 | 252 Benzo(a)pyrene            |
| 36 | 100 | 97  | 99  | 0     | 999390  | vv       | 1746 | 252 Perylene                  |
| 37 | 100 | 96  | 100 | -2    | 1387200 | bv       | 1965 | 276 Indeno(1,2,3-cd)pyrene    |
| 38 | 100 | 93  | 99  | -2    | 1336200 | vv       | 1973 | 278 Dibenz(a,h)anthracene     |
| 39 | 87  | 96  | 99  | -4    | 1582100 | bv       | 2015 | 276 Benzo(g,h,i)perylene      |

~ 1/3/93



| NO. | HAZ | FOR | REV | Delta | Area    | P.Flags            | Scan | Qm  | Name                      |
|-----|-----|-----|-----|-------|---------|--------------------|------|-----|---------------------------|
| 1   | 100 | 83  | 100 | 0     | 312450  | bb                 | 420  | 152 | 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 86  | 94  | 0     | 1336100 | bb                 | 599  | 136 | Naphthalene-d8            |
| 3   | 100 | 90  | 97  | 0     | 703760  | bb                 | 857  | 164 | Acenaphthene-d10          |
| 4   | 100 | 85  | 96  | 0     | 1512500 | bv                 | 1076 | 188 | Phenanthrene-d10          |
| 5   | 73  | 32  | 94  | -1    | 1559600 | bb                 | 1471 | 240 | Chrysene-d12              |
| 6   | 100 | 86  | 95  | 0     | 776940  | bb                 | 1741 | 264 | Perylene-d12              |
| 7   | 100 | 95  | 97  | -1    | 1967600 | bv                 | 244  | 112 | 2-Fluorophenol            |
| 8   | 89  | 54  | 99  | -1    | 1814700 | bb                 | 388  | 132 | 2-Chlorophenol-d4         |
| 9   | 95  | 65  | 99  | -1    | 2378600 | bv                 | 377  | 99  | Phenol-d5                 |
| 10  | 100 | 87  | 98  | 0     | 1073100 | bb                 | 440  | 152 | 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 81  | 99  | 0     | 2239200 | bb                 | 498  | 82  | Nitrobenzene-d5           |
| 12  | 96  | 55  | 98  | 0     | 1177200 | bb                 | 546  | 185 | 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 92  | 99  | 0     | 858880  | bb                 | 607  | 240 | 1,4-Dibromobenzene-d4     |
| 14  | 100 | 89  | 98  | 0     | 2656800 | bb                 | 762  | 172 | 2-Fluorobiphenyl          |
| 15  | 100 | 77  | 99  | 0     | 544160  | bb                 | 974  | 330 | 2,4,6-Tribromophenol      |
| 16  | 100 | 86  | 97  | 0     | 2510600 | vb                 | 1085 | 188 | Anthracene-d10            |
| 17  | 100 | 86  | 97  | 0     | 5262000 | vb                 | 1286 | 212 | Pyrene-d10                |
| 18  | 100 | 85  | 96  | 1     | 3952700 | vb                 | 1320 | 244 | Terphenyl-d14             |
| 19  | 100 | 96  | 98  | 0     | 4445700 | bb                 | 602  | 128 | Naphthalene               |
| 20  | 100 | 89  | 92  | -1    | 3098300 | vb                 | 704  | 142 | 2-Methylnaphthalene       |
| 21  | 100 | 95  | 98  | 0     | 2351600 | bb                 | 775  | 162 | 2-Chloronaphthalene       |
| 22  | 100 | 94  | 97  | 0     | 4120900 | bb                 | 835  | 152 | Acenaphthylene            |
| 23  | 100 | 88  | 90  | 0     | 2316000 | bb                 | 862  | 154 | Acenaphthene              |
| 24  | 100 | 95  | 98  | -1    | 2786400 | bb                 | 938  | 166 | Fluorene                  |
| 25  | 100 | 83  | 99  | 0     | 637220  | bv                 | 1050 | 266 | Pentachlorophenol         |
| 26  | 100 | 92  | 97  | 0     | 4475700 | bv*                | 1080 | 178 | Phenanthrene              |
| 27  | 100 | 93  | 97  | 0     | 4558200 | vv*                | 1088 | 178 | Anthracene                |
| 28  | 100 | 94  | 98  | -1    | 5509800 | bb                 | 1256 | 202 | Fluoranthene              |
| 29  | 100 | 94  | 99  | 0     | 5514500 | vb                 | 1289 | 202 | Pyrene                    |
| 30  | 100 | 88  | 99  | 0     | 5017300 | bv                 | 1469 | 228 | Benzo(a)anthracene        |
| 31  | 100 | 93  | 99  | 0     | 4770100 | vv                 | 1475 | 228 | Chrysene                  |
| 32  | 88  | 68  | 72  | 0     | 4006500 | bv                 | 1663 | 252 | Benzo(b)fluoranthene      |
| 33  | 100 | 93  | 97  | -1    | 4003400 | vv                 | 1669 | 252 | Benzo(k)fluoranthene      |
| 34  | 100 | 94  | 98  | -1    | 3635900 | bv                 | 1718 | 252 | Benzo(e)pyrene            |
| 35  | 100 | 95  | 99  | -2    | 3508900 | vv                 | 1729 | 252 | Benzo(a)pyrene            |
| 36  | 100 | 95  | 99  | -1    | 1785900 | vv                 | 1746 | 252 | Perylene                  |
| 37  | 100 | 96  | 100 | -2    | 2875900 | bv                 | 1966 | 276 | Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 92  | 99  | -2    | 2837300 | bv                 | 1974 | 278 | Dibenz(a,h)anthracene     |
| 39  | 87  | 96  | 99  | -4    | 3126000 | b? <sup>2-AS</sup> | 2016 | 276 | Benzo(g,h,i)perylene      |

1/3/73




| NO. | PMI | FOR | REV | Delta | Area    | P-Flags | Scan | Or Name                       |
|-----|-----|-----|-----|-------|---------|---------|------|-------------------------------|
| 1   | 100 | 80  | 100 | -1    | 202340  | bb      | 419  | 151 1,4-Dichlorobenzene-d4    |
| 2   | 100 | 80  | 93  | 1     | 1093400 | bb      | 599  | 130 Naphthalene-d8            |
| 3   | 100 | 86  | 96  | -1    | 643100  | bb      | 856  | 164 Acenaphthene-d10          |
| 4   | 100 | 82  | 96  | 1     | 1458000 | bv      | 1076 | 180 Phenanthrene-d10          |
| 5   | 67  | 24  | 92  | -1    | 1546600 | bb      | 1471 | 240 Chrysene-d12              |
| 6   | 100 | 86  | 94  | 1     | 875380  | bb      | 1742 | 264 Perylene-d12              |
| 7   | 100 | 95  | 97  | 0     | 2240900 | bb      | 244  | 111 2-Fluorophenol            |
| 8   | 94  | 52  | 98  | 0     | 1995900 | bb      | 388  | 132 2-Chlorophenol-d4         |
| 9   | 100 | 61  | 99  | 0     | 2784000 | bv      | 377  | 99 Phenol-d5                  |
| 10  | 100 | 84  | 96  | 1     | 1187700 | bb      | 440  | 152 1,2-Dichlorobenzene-d4    |
| 11  | 100 | 79  | 99  | 0     | 2622900 | bb      | 498  | 82 Nitrobenzene-d5            |
| 12  | 95  | 54  | 98  | 0     | 1440000 | bb      | 546  | 183 1,3,5-Trichlorobenzene-d3 |
| 13  | 100 | 94  | 99  | 0     | 937220  | bb      | 606  | 240 1,4-Dibromobenzene-d4     |
| 14  | 100 | 89  | 98  | 1     | 3225400 | bb      | 762  | 172 2-Fluorobiphenyl          |
| 15  | 100 | 76  | 98  | 1     | 632330  | bb      | 974  | 330 2,4,6-Tribromophenol      |
| 16  | 100 | 85  | 97  | -1    | 3129800 | vb      | 1084 | 188 Anthracene-d10            |
| 17  | 100 | 85  | 96  | 0     | 6587000 | vb      | 1286 | 212 Pyrene-d10                |
| 18  | 100 | 85  | 96  | 1     | 4753100 | vb      | 1320 | 244 Terphenyl-d14             |
| 19  | 100 | 96  | 98  | 0     | 5023000 | bb      | 602  | 128 Naphthalene               |
| 20  | 100 | 89  | 92  | -1    | 3509500 | vb      | 704  | 142 2-Methylnaphthalene       |
| 21  | 100 | 95  | 98  | 1     | 2773900 | bb      | 775  | 162 2-Chloronaphthalene       |
| 22  | 100 | 93  | 97  | 1     | 4754400 | bb      | 835  | 152 Acenaphthylene            |
| 23  | 100 | 88  | 90  | 0     | 2718200 | bb      | 861  | 154 Acenaphthene              |
| 24  | 100 | 94  | 98  | 0     | 3370400 | bb      | 938  | 166 Fluorene                  |
| 25  | 100 | 84  | 99  | -1    | 763020  | bv      | 1049 | 266 Pentachlorophenol         |
| 26  | 100 | 91  | 97  | 0     | 5521400 | bv*     | 1080 | 178 Phenanthrene              |
| 27  | 100 | 92  | 97  | 0     | 5447000 | vb*     | 1088 | 178 Anthracene                |
| 28  | 100 | 94  | 98  | -1    | 6663900 | vv      | 1256 | 202 Fluoranthene              |
| 29  | 100 | 93  | 98  | 0     | 6540600 | vv      | 1289 | 202 Pyrene                    |
| 30  | 100 | 89  | 99  | 0     | 6604700 | bv      | 1469 | 228 Benzo(a)anthracene        |
| 31  | 100 | 92  | 98  | 1     | 6439600 | vv      | 1476 | 228 Chrysene                  |
| 32  | 86  | 67  | 71  | 0     | 6094000 | bl      | 1664 | 252 Benzo(b)fluoranthene      |
| 33  | 100 | 92  | 97  | -1    | 6066800 | vv      | 1670 | 252 Benzo(k)fluoranthene      |
| 34  | 100 | 93  | 98  | 0     | 5683500 | bv      | 1720 | 252 Benzo(e)pyrene            |
| 35  | 100 | 94  | 99  | -1    | 5551300 | vv      | 1731 | 252 Benzo(a)pyrene            |
| 36  | 100 | 94  | 97  | 0     | 2755300 | vv      | 1748 | 252 Perylene                  |
| 37  | 100 | 95  | 99  | 0     | 4887900 | bv      | 1969 | 276 Indeno(1,2,3-cd)pyrene    |
| 38  | 100 | 92  | 99  | 1     | 4723700 | bb      | 1978 | 278 Dibenz(a,h)anthracene     |
| 39  | 100 | 96  | 99  | 0     | 5120900 | bv      | 2021 | 276 Benzo(g,h,i)perylene      |

1193

03-Jan-93 12:23  
Sample: DFTTP

Triangle Laboratories of RTP, Inc.

(919) 544-5729  
Instrument G





Raw Data File: 06490  
 Date: 03-Jan-93  
 Time: 10:55

| M E | ION ABUNDANCE CRITERIA             | RELATIVE<br>ABUNDANCE | TUNE |
|-----|------------------------------------|-----------------------|------|
| 51  | 30.0 - 60.0% of mass 198           | 47.85                 | PASS |
| 62  | Less than 2.0% of mass 69          | 0.62( 1.3)1           | PASS |
| 69  | Mass 69 relative abundance         | 42.08                 | PASS |
| 70  | Less than 2.0% of mass 69          | 0.68( 1.4)1           | PASS |
| 127 | 40.0 - 60.0% of mass 198           | 52.15                 | PASS |
| 127 | Less than 1% of mass 198           | 0.42                  | PASS |
| 198 | Base peak, 100% relative abundance | 100.00                | PASS |
| 199 | 5 - 9% of mass 198                 | 7.02                  | PASS |
| 275 | 10 - 30% of mass 198               | 15.80                 | PASS |
| 365 | Greater than 1% of mass 198        | 1.56                  | PASS |
| 441 | Present, but less than mass 443    | 8.24                  | PASS |
| 442 | Greater than 40% of mass 198       | 55.21                 | PASS |
| 443 | 17 - 23% of mass 442               | 10.43( 18.9)2         | PASS |

1.47C 140 19.117

| Obs | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int | PK# | Mass | Abs Int | Rel Int |
|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|-----|------|---------|---------|
| 1   | 33   | 1091    | 0.35    | 34  | 35   | 1534    | 0.75    | 37  | 131  | 584     | 0.41    | 100 | 181  | 1614    | 1.00    | 113 | 242  | 1104    | 0.66    |
| 2   | 39   | 8400    | 3.35    | 35  | 86   | 1511    | 0.78    | 38  | 134  | 732     | 0.59    | 101 | 185  | 2304    | 1.38    | 114 | 242  | 940     | 0.56    |
| 3   | 40   | 1040    | 0.62    | 36  | 37   | 780     | 0.47    | 39  | 135  | 2320    | 1.39    | 102 | 186  | 20992   | 12.53   | 115 | 244  | 13563   | 8.13    |
| 4   | 41   | 1252    | 1.17    | 37  | 91   | 1434    | 0.55    | 40  | 136  | 1120    | 0.67    | 103 | 187  | 6208    | 3.72    | 116 | 245  | 1920    | 1.15    |
| 5   | 43   | 2160    | 1.09    | 38  | 92   | 1376    | 0.92    | 41  | 137  | 1649    | 0.99    | 104 | 189  | 954     | 0.59    | 117 | 246  | 2240    | 1.34    |
| 6   | 44   | 3110    | 1.87    | 39  | 93   | 6976    | 4.18    | 42  | 141  | 3312    | 1.93    | 105 | 192  | 1440    | 0.96    | 118 | 255  | 62976   | 37.73   |
| 7   | 50   | 18683   | 11.20   | 40  | 94   | 594     | 0.48    | 43  | 142  | 1456    | 0.87    | 106 | 193  | 1728    | 1.04    | 119 | 256  | 9152    | 5.48    |
| 8   | 51   | 79872   | 47.85   | 41  | 95   | 1000    | 0.60    | 44  | 143  | 932     | 0.50    | 107 | 196  | 4928    | 2.95    | 140 | 257  | 808     | 0.48    |
| 9   | 52   | 4415    | 2.65    | 42  | 96   | 792     | 0.47    | 45  | 146  | 728     | 0.44    | 108 | 197  | 704     | 0.42    | 141 | 258  | 3152    | 1.89    |
| 10  | 55   | 2560    | 1.53    | 43  | 97   | 1040    | 0.62    | 46  | 147  | 1950    | 1.17    | 109 | 198  | 156912  | 100.00  | 142 | 265  | 1216    | 0.73    |
| 11  | 56   | 3152    | 1.89    | 44  | 98   | 4364    | 2.91    | 47  | 148  | 3472    | 2.03    | 110 | 199  | 11712   | 7.02    | 143 | 273  | 2096    | 1.26    |
| 12  | 57   | 7620    | 4.60    | 45  | 99   | 4736    | 2.84    | 48  | 149  | 2768    | 1.66    | 111 | 200  | 1360    | 0.81    | 144 | 274  | 4928    | 2.95    |
| 13  | 51   | 1056    | 0.63    | 46  | 101  | 1572    | 1.55    | 49  | 151  | 580     | 0.41    | 112 | 201  | 1540    | 1.10    | 145 | 275  | 26368   | 15.80   |
| 14  | 60   | 1104    | 0.66    | 47  | 103  | 904     | 0.54    | 50  | 153  | 1072    | 0.64    | 113 | 203  | 1184    | 0.71    | 146 | 276  | 5424    | 2.05    |
| 15  | 63   | 3832    | 1.70    | 48  | 104  | 1648    | 0.99    | 51  | 154  | 908     | 0.54    | 114 | 204  | 5056    | 3.03    | 147 | 277  | 2016    | 1.21    |
| 16  | 65   | 2096    | 1.26    | 49  | 105  | 1808    | 1.08    | 52  | 155  | 1272    | 1.12    | 115 | 205  | 9344    | 5.60    | 148 | 296  | 5760    | 3.45    |
| 17  | 57   | 364     | 0.52    | 50  | 107  | 20992   | 12.55   | 53  | 156  | 3120    | 1.87    | 116 | 206  | 35328   | 21.17   | 149 | 297  | 860     | 0.52    |
| 18  | 62   | 1040    | 0.62    | 51  | 108  | 3616    | 2.17    | 54  | 157  | 920     | 0.45    | 117 | 207  | 4992    | 2.99    | 150 | 302  | 976     | 0.55    |
| 19  | 59   | 31200   | 49.03   | 52  | 110  | 49968   | 24.54   | 55  | 158  | 736     | 0.44    | 118 | 208  | 1376    | 0.82    | 151 | 323  | 2416    | 1.45    |
| 20  | 70   | 1136    | 0.63    | 53  | 111  | 6528    | 3.91    | 56  | 160  | 1136    | 0.68    | 119 | 210  | 1232    | 0.74    | 152 | 334  | 1696    | 1.02    |
| 21  | 71   | 1296    | 0.78    | 54  | 112  | 1040    | 0.62    | 57  | 161  | 1712    | 1.03    | 120 | 211  | 2160    | 1.29    | 153 | 346  | 692     | 0.41    |
| 22  | 73   | 712     | 0.55    | 55  | 115  | 1200    | 0.72    | 58  | 163  | 1232    | 0.74    | 121 | 216  | 788     | 0.47    | 154 | 352  | 800     | 0.48    |
| 23  | 74   | 7232    | 4.33    | 56  | 117  | 13504   | 8.09    | 59  | 166  | 1040    | 0.52    | 122 | 217  | 8256    | 4.95    | 155 | 354  | 944     | 0.57    |
| 24  | 75   | 11328   | 6.79    | 57  | 118  | 1280    | 0.77    | 60  | 167  | 6720    | 4.03    | 123 | 218  | 1212    | 0.79    | 156 | 365  | 2608    | 1.56    |
| 25  | 76   | 4224    | 2.53    | 58  | 122  | 1568    | 0.94    | 61  | 168  | 4016    | 2.41    | 124 | 221  | 14208   | 8.51    | 157 | 372  | 1296    | 0.73    |
| 26  | 77   | 94208   | 56.44   | 59  | 123  | 2256    | 1.35    | 62  | 169  | 704     | 0.42    | 125 | 222  | 2160    | 1.29    | 158 | 403  | 736     | 0.44    |
| 27  | 78   | 6592    | 3.95    | 60  | 124  | 1120    | 0.67    | 63  | 173  | 520     | 0.49    | 126 | 223  | 2272    | 1.36    | 159 | 423  | 4800    | 2.98    |
| 28  | 79   | 4992    | 2.99    | 61  | 125  | 1168    | 0.70    | 64  | 174  | 1408    | 0.84    | 127 | 224  | 18688   | 11.20   | 160 | 424  | 916     | 0.55    |
| 29  | 80   | 3340    | 2.30    | 62  | 127  | 37040   | 52.15   | 65  | 175  | 2560    | 1.53    | 128 | 225  | 4672    | 2.30    | 161 | 441  | 13760   | 8.24    |
| 30  | 81   | 6030    | 3.64    | 63  | 128  | 6592    | 3.95    | 66  | 176  | 936     | 0.56    | 129 | 227  | 6336    | 3.80    | 162 | 442  | 92160   | 55.21   |
| 31  | 82   | 1080    | 1.20    | 64  | 129  | 27648   | 16.56   | 67  | 177  | 1136    | 0.63    | 130 | 228  | 1024    | 0.61    | 163 | 443  | 17408   | 10.43   |
| 32  | 83   | 2604    | 1.57    | 65  | 130  | 2576    | 1.54    | 68  | 179  | 4288    | 2.57    | 131 | 229  | 1664    | 1.00    | 164 | 444  | 1808    | 1.08    |
| 33  | 84   | 716     | 0.43    | 66  | 131  | 768     | 0.58    | 69  | 180  | 3472    | 2.05    | 132 | 231  | 876     | 0.52    |     |      |         |         |

## **VII. LABORATORY ANALYSIS RESULTS**

### **C. Particulate Analysis Results**

## SAMPLE ANALYTICAL DATA FORM

157

Company Name NAPA METHOD 202 PWSample Location PERRYRelative Humidity in Lab 44 %Blank Volume ( $V_a$ ) 100 mlDensity of Acetone ( $\rho_a$ ) .7857 mg/mlDate/Time wt. blank 12/21 8:30AGross wt. 99.1794 gDate/Time wt. blank 12/21 2:30PGross wt. 99.1793 gAve. Gross wt. 99.1794 gTare wt. 99.1792 gWeight of blank ( $m_{ab}$ ) .0002 gAcetone blank residue concentration ( $C_a$ ): ( $C_a$ ) = ( $m_{ab}$ ) / ( $V_a$ ) ( $\rho_a$ ) = (.000003 mg/g)Acetone Blank Wt.:  $W_a = C_a V_{aw} \rho_a = (.000003)(200)(.7857) = (.0005$  g)

|                                                    | Run # 1         | Run # 2         | Run # 3        |
|----------------------------------------------------|-----------------|-----------------|----------------|
| Acetone rinse volume ( $V_{aw}$ ) ml               | <u>200</u>      | <u>200</u>      | <u>200</u>     |
| Date/Time of wt. <u>12/21 8:30A</u> Gross wt. g    | <u>104.6589</u> | <u>101.2928</u> | <u>98.6834</u> |
| Date/Time of wt. <u>12/21 2:30P</u> Gross wt. g    | <u>104.6589</u> | <u>101.2924</u> | <u>98.6831</u> |
| Average Gross wt. g                                | <u>104.6589</u> | <u>101.2926</u> | <u>98.6833</u> |
| Tare wt. g                                         | <u>104.6540</u> | <u>101.2868</u> | <u>98.6791</u> |
| Less Acetone blank wt. ( $W_a$ ) g                 | <u>.0005</u>    | <u>.0005</u>    | <u>.0005</u>   |
| Weight of particulate in acetone rinse ( $m_a$ ) g | <u>.0044</u>    | <u>.0053</u>    | <u>.0037</u>   |

| Filter Numbers                                  | # | TS6569       | TS6570       | TS6568       |
|-------------------------------------------------|---|--------------|--------------|--------------|
| Date/Time of wt. <u>12/21 8:30A</u> Gross wt. g |   | <u>.5775</u> | <u>.5748</u> | <u>.5733</u> |
| Date/Time of wt. <u>12/21 2:30P</u> Gross wt. g |   | <u>.5775</u> | <u>.5747</u> | <u>.5732</u> |
| Average Gross wt. g                             |   | <u>.5775</u> | <u>.5748</u> | <u>.5732</u> |
| Tare wt. g                                      |   | <u>.5739</u> | <u>.5722</u> | <u>.5707</u> |

|                                                    |              |              |              |
|----------------------------------------------------|--------------|--------------|--------------|
| Weight of particulate on filter ( $m_f$ ) g        | <u>.0036</u> | <u>.0026</u> | <u>.0025</u> |
| Weight of particulate in acetone rinse ( $m_a$ ) g | <u>.0044</u> | <u>.0053</u> | <u>.0037</u> |
| Total weight of particulate ( $m_n$ ) g            | <u>.0080</u> | <u>.0089</u> | <u>.0062</u> |

NOTE: In no case should a blank residue greater than 0.01 mg/g (or 0.001% of the blank weight) be subtracted from the sample weight.

Remarks:

Signature of Analyst Thomas SmithSignature of Reviewer WJ

COMPANY NAME: NAPA - PERRY, FL METHOD 202  
Methylene Chloride Extraction for EPA Method

Relative humidity in lab 42 %  
Density of Methylene Chloride 1.3255 g/ml

|                                                    |                  | RUN 1    | RUN 2    | RUN 3    |
|----------------------------------------------------|------------------|----------|----------|----------|
| Methylene Chloride rinse volume                    | ml               | 170      | 280      | 240      |
| Volume of Solution                                 |                  | 800      | 710      | 700      |
| Date/time of wt <u>12/21 8:30A</u>                 | Gross wt. g      | 101.7932 | 104.6465 | 101.1910 |
| Date/time of wt <u>12/21 2:30P</u>                 | Gross wt. g      | 101.7931 | 104.6465 | 101.1910 |
|                                                    | Avg. Gross wt. g | 101.7932 | 104.6465 | 101.1910 |
|                                                    | Tare wt. g       | 101.7757 | 104.6390 | 101.1732 |
| Less Methylene Chloride Blank                      |                  | .0001    | .0001    | .0001    |
| Wt./particulate: Methylene Chloride rinse          | g                | .0174    | .0074    | .0177    |
| Water evaporation                                  |                  |          |          |          |
| Date/time of wt <u>12/23 9:30A</u>                 | Gross wt. g      | 103.8117 | 98.3579  | 94.5994  |
| Date/time of wt <u>12/23 3:30P</u>                 | Gross wt. g      | 103.8117 | 98.3574  | 94.5992  |
|                                                    | Avg. Gross wt. g | 103.8117 | 98.3577  | 94.5993  |
|                                                    | Tare wt. g       | 103.7605 | 98.3200  | 94.5776  |
| Less H <sub>2</sub> O blank wt.                    | g                | .0002    | .0002    | .0002    |
| Weight of particulate from water (m <sub>w</sub> ) | g                | .0510    | .0375    | .0215    |
| Wt./particulate: Methylene Chloride rinse          | g                | .0174    | .0074    | .0177    |
| Total weight of particulate (m <sub>t</sub> )      | g                | .0684    | .0449    | .0392    |

NOTE: In no case should a blank residue 0.02 mg/g or 0.001% of the weight of Methylene Chloride used be subtracted from the sample weight.

Remarks:

Signature of Analyst: Thomas South

Signature of Reviewer: \_\_\_\_\_

## **VII. LABORATORY ANALYSIS RESULTS**

### **D. Fuel Analysis Results**

**THORNTON LABORATORIES, INC.**  
MARINE, ANALYTICAL AND ENVIRONMENTAL SERVICES**159**1145 EAST CASS STREET, TAMPA, FLORIDA 33602  
P.O. BOX 2880 TAMPA, FLORIDA 33601-2880  
HRS# 84147 HRS# E84100TELEPHONE (813) 223-9702  
FAX (813) 223-933224-Dec-1992  
Page 1Report For: National Asphalt Pavement  
5100 Forbes rd.  
Lanham, MD. 20706-4413

## Sample Identification:

Diesel/APAC Dixie Co. plant

Attn: Tom Brumagin

Date Received: 11-Dec-1992

Laboratory Number: 843620

## CERTIFICATE OF ANALYSIS

| Method    | Parameter                   | Result | Units   |
|-----------|-----------------------------|--------|---------|
| ASTM D287 | API Gravity @ 60 °F         | 30.9   |         |
|           | Specific Gravity @ 60/60 °F | 0.8713 |         |
| ASTM D93  | Flash Point, (PMCC)         | 144    | °F      |
| ASTM D240 | Heating Value (BTU)         | 19206  | BTU/lb  |
|           | Heating Value (BTU)         | 139340 | BTU/gal |
| ASTM D129 | Sulfur (S)                  | 0.37   | %       |

THORNTON LABORATORIES, INC.  
Fred Hartlage, Jr. Ph.D.



ANALYSES OF OFFICIAL PETROLEUM SAMPLES UNDER CHAPTER 525, FLORIDA STATUTES

LOUIS DREYFUS ENERGY CORP  
P O BOX 38  
ST MARKS, FL 32355

**TAKEN FROM:**

**32355**

Attn: Don Everett

CHRISTIAN USA  
April 23, 1965

DATE: 08/08/92

11/12/92  
J. J. J. J. J.

**HALL**  
**JAN 5 1965**

146893 • A. L. L. L.

[illegible]

## RESULTS

**Division Of Standards  
Bureau Of Petroleum Inspection  
3125 Conner Blvd., Bldg. 1  
Tallahassee, FL 32399-1650  
Phone: 904/488-9740**

*Bob Crawford*  
Bob Crawford  
Commissioner Of Agriculture





THE STATE OF FLORIDA  
DEPARTMENT OF AGRICULTURE AND CONSUMER SERVICES

Bob Crawford  
Commissioner

ANALYSES OF OFFICIAL PETROLEUM SAMPLES UNDER CHAPTER 525, FLORIDA STATUTES

MURPHY CORP  
P O BOX 98  
ST MARKS FL

32065

TAKEN FROM:

CHEVRON USA

11/16/92

11/15/92

12/15/92

W. J. HALL

127883

| SAMPLE NO. | PRODUCT NAME | PUMP OR TANK NAME AND NO. | GALLONS | Flash Point °F | DISTILLATION   |              |                 | COLOR | SULFUR WT. % | VISCOSITY cSt | FOUND BY ANALYSIS |
|------------|--------------|---------------------------|---------|----------------|----------------|--------------|-----------------|-------|--------------|---------------|-------------------|
|            |              |                           |         |                | TEMPERATURE °F | % EVAPORATED | % RESIDUE POINT |       |              |               |                   |
| 0259841    | DIESEL       | 30-1                      | 403,332 | 154            |                |              |                 |       | .38          |               | LEGAL             |
|            |              |                           |         |                |                |              |                 |       |              |               |                   |
|            |              |                           |         |                |                |              |                 |       |              |               |                   |
|            |              |                           |         |                |                |              |                 |       |              |               |                   |
|            |              |                           |         |                |                |              |                 |       |              |               |                   |

Division Of Standards  
Bureau Of Petroleum Inspection  
3125 Conner Blvd., Bldg. 1  
Tallahassee, FL 32399-1650  
Phone: 904/488-9740

*Bob Crawford*  
Bob Crawford  
Commissioner Of Agriculture

## **VIII. EQUIPMENT CALIBRATION DATA**

### **A. GC Calibration Data**

BENZENE

Date: 12-7-92 Analyst: D.S. Plant: MACASDIANT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SPI Column Used: 5% SP1200 / 1.75% DEANTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 4000 ml/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | <u>PPE</u> | Standard 1          | Standard 2                   | Standard 3 |
|----------------------------------------------|------------|---------------------|------------------------------|------------|
| First analysis/second analysis               |            |                     |                              |            |
| Standard concentration (C <sub>acc</sub> )   |            | <u>10.5</u>         | <u>10.5</u>                  | <u>1</u>   |
| Flow rate through loop (ml/min)              |            | <u>600 / 600</u>    | <u>600 / 600</u>             | <u>1</u>   |
| Liquid injection volume (tubes)              |            | <u>NA1</u>          | <u>NA1</u>                   | <u>1</u>   |
| Injection time (24-hr clock)                 |            | <u>1</u>            | <u>1</u>                     | <u>1</u>   |
| Chart speed (cm/min)                         |            | <u>NA1</u>          | <u>NA1</u>                   | <u>1</u>   |
| Detector attenuation                         |            | <u>32 / 32</u>      | <u>32 / 32</u>               | <u>1</u>   |
| Peak retention time (min)                    |            | <u>1.483 / 1.50</u> | <u>1.516 / 1.516</u>         | <u>1</u>   |
| Peak retention time range (min)              |            | <u>1.483</u>        | <u>1.516</u>                 | <u>1</u>   |
| Peak area                                    |            | <u>6.31 / 6.10</u>  | <u>6.418 / 59.91</u>         | <u>1</u>   |
| Peak area x attenuation factor               |            | <u>1</u>            | <u>1</u>                     | <u>1</u>   |
| Average peak area value (Y)                  |            | <u>6.2</u>          | <u>62.05</u>                 | <u>1</u>   |
| Percent deviation from average               |            | <u>&lt; 5%</u>      | <u>&lt; 5%</u>               | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |            | <u>10.5</u>         | <u>10.5</u>                  | <u>1</u>   |
| % deviation from actual (%D <sub>acc</sub> ) |            | <u>0</u>            | <u>0</u>                     | <u>1</u>   |
| Linear regression equation: slope (m):       |            | <u>5.91</u>         | y-intercept (b): <u>.006</u> |            |

| Sample Analysis Data                                        | <u>POST</u> | Sample 1            | Sample 2             | Sample 3 |
|-------------------------------------------------------------|-------------|---------------------|----------------------|----------|
| First analysis/second analysis                              |             |                     |                      |          |
| Sample identification                                       |             | <u>10.5</u>         | <u>10.5</u>          | <u>1</u> |
| Interface dilution factor                                   |             |                     |                      | <u>1</u> |
| Flow rate through loop (ml/min)                             |             | <u>600 / 600</u>    | <u>600 / 600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |             | <u>NA1</u>          | <u>NA1</u>           | <u>1</u> |
| Injection time (24-hr clock)                                |             | <u>1</u>            | <u>1</u>             | <u>1</u> |
| Chart speed (cm/min)                                        |             | <u>NA1</u>          | <u>NA1</u>           | <u>1</u> |
| Detector attenuation                                        |             | <u>32 / 32</u>      | <u>32 / 32</u>       | <u>1</u> |
| Peak retention time (min)                                   |             | <u>1.483 / 1.50</u> | <u>1.516 / 1.516</u> | <u>1</u> |
| Peak retention time range (min)                             |             | <u>1.483</u>        | <u>1.516</u>         | <u>1</u> |
| Peak area                                                   |             | <u>6.54 / 6.32</u>  | <u>6.418 / 6.19</u>  | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |             | <u>1</u>            | <u>1</u>             | <u>1</u> |
| Average peak area value (Y)                                 |             | <u>6.43</u>         | <u>62.69</u>         | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |             | <u>&lt; 5%</u>      | <u>&lt; 5%</u>       | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |             | <u>10.9</u>         | <u>10.61</u>         | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

ETHYL - BENZENE

Date: 12-7-92 Analyst: DS Plant: MAC ASPHALT  
 Location: PEARLY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETA  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% BENTON 3+  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 CC/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 100 Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1         | Standard 2                     | Standard 3 |
|----------------------------------------------|-----|--------------------|--------------------------------|------------|
| First analysis/second analysis               |     |                    |                                |            |
| Standard concentration (C <sub>std</sub> )   |     | <u>1.28</u>        | <u>9.7</u>                     | <u>.</u>   |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>     | <u>600/600</u>                 | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>NAI</u>         | <u>NAI</u>                     | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>           | <u>1</u>                       | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>NAI</u>         | <u>NAI</u>                     | <u>1</u>   |
| Detector attenuation                         |     | <u>32/32</u>       | <u>32/32</u>                   | <u>1</u>   |
| Peak retention time (min)                    |     | <u>2.833/2.883</u> | <u>2.883/2.883</u>             | <u>1</u>   |
| Peak retention time range (min)              |     | <u>2.833</u>       | <u>2.883</u>                   | <u>1</u>   |
| Peak area                                    |     | <u>6.91/6.86</u>   | <u>73.31/70.94</u>             | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>           | <u>1</u>                       | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>6.89</u>        | <u>72.125</u>                  | <u>1</u>   |
| Percent deviation from average               |     | <u>&lt;5%</u>      | <u>&lt;5%</u>                  | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.28</u>        | <u>9.7</u>                     | <u>1</u>   |
| % deviation from actual (%D <sub>acc</sub> ) |     | <u>0</u>           | <u>0</u>                       | <u>1</u>   |
| Linear regression equation; slope (m):       |     | <u>2.75</u>        | y-intercept (b): <u>-3.027</u> |            |

| Sample Analysis Data                                        | Post | Sample 1           | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|--------------------|--------------------|----------|
| First analysis/second analysis                              |      |                    |                    |          |
| Sample identification                                       |      | <u>1.28</u>        | <u>9.7</u>         | <u>1</u> |
| Interface dilution factor                                   |      | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>     | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>NAI</u>         | <u>NAI</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>NAI</u>         | <u>NAI</u>         | <u>1</u> |
| Detector attenuation                                        |      | <u>32/32</u>       | <u>32/32</u>       | <u>1</u> |
| Peak retention time (min)                                   |      | <u>2.833/2.883</u> | <u>2.883/2.883</u> | <u>1</u> |
| Peak retention time range (min)                             |      | <u>2.833</u>       | <u>2.883</u>       | <u>1</u> |
| Peak area                                                   |      | <u>7.13/6.92</u>   | <u>74.25/72.52</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>7.03</u>        | <u>73.39</u>       | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>2%</u>          | <u>1.7%</u>        | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.30</u>        | <u>9.86</u>        | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

TOLUENE

Date: 12-7-92 Analyst: D.S. Plant: MAC ASPHALT  
 Location: PERAY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 100 Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1         | Standard 2                    | Standard 3 |
|----------------------------------------------|-----|--------------------|-------------------------------|------------|
| First analysis/second analysis               |     |                    |                               |            |
| Standard concentration (C <sub>acc</sub> )   |     | <u>1.18</u>        | <u>11</u>                     |            |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>     | <u>600/600</u>                | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>N/A</u>         | <u>N/A</u>                    | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>           | <u>1</u>                      | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>N/A</u>         | <u>N/A</u>                    | <u>1</u>   |
| Detector attenuation                         |     | <u>32/32</u>       | <u>32/32</u>                  | <u>1</u>   |
| Peak retention time (min)                    |     | <u>5.216/5.283</u> | <u>5.3015.266</u>             | <u>1</u>   |
| Peak retention time range (min)              |     | <u>5.216</u>       | <u>5.266</u>                  |            |
| Peak area                                    |     | <u>76.219.39</u>   | <u>75.61173.67</u>            | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>           | <u>1</u>                      | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>9.51</u>        | <u>74.64</u>                  |            |
| Percent deviation from average               |     | <u>&lt; 5%</u>     | <u>2.5%</u>                   |            |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.18</u>        | <u>11</u>                     |            |
| % deviation from actual (%D <sub>acc</sub> ) |     | <u>0</u>           | <u>0</u>                      |            |
| Linear regression equation: slope (m):       |     | <u>6.632</u>       | y-intercept (b): <u>6.684</u> |            |

| Sample Analysis Data                                        | Post | Sample 1            | Sample 2            | Sample 3 |
|-------------------------------------------------------------|------|---------------------|---------------------|----------|
| First analysis/second analysis                              |      |                     |                     |          |
| Sample identification                                       |      | <u>1.18</u>         | <u>11</u>           |          |
| Interface dilution factor                                   |      |                     |                     |          |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>      | <u>600/600</u>      | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>N/A</u>          | <u>N/A</u>          | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>            | <u>1</u>            | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>N/A</u>          | <u>N/A</u>          | <u>1</u> |
| Detector attenuation                                        |      | <u>32/32</u>        | <u>32/32</u>        | <u>1</u> |
| Peak retention time (min)                                   |      | <u>7.183/7.316</u>  | <u>7.381/7.266</u>  | <u>1</u> |
| Peak retention time range (min)                             |      | <u>7.183</u>        | <u>7.266</u>        |          |
| Peak area                                                   |      | <u>10.641/11.14</u> | <u>76.701/74.36</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>            | <u>1</u>            | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>10.9</u>         | <u>75.53</u>        |          |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>12.8%</u>        | <u>1.2%</u>         |          |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.39</u>         | <u>11.13</u>        |          |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

ORTHO - XYLENE

Date: 12-7-92 Analyst: D.S. Plant: M/ACASPHALT  
 Location: PEARL FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% NENTON E 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | <u>PRE</u> | Standard 1         | Standard 2                    | Standard 3 |
|----------------------------------------------|------------|--------------------|-------------------------------|------------|
| First analysis/second analysis               |            |                    |                               |            |
| Standard concentration (C <sub>std</sub> )   |            | <u>1.18</u>        | <u>10.2</u>                   | <u>1</u>   |
| Flow rate through loop (ml/min)              |            | <u>600/600</u>     | <u>600/600</u>                | <u>1</u>   |
| Liquid injection volume (tubes)              |            | <u>NAI</u>         | <u>NAI</u>                    | <u>1</u>   |
| Injection time (24-hr clock)                 |            | <u>1</u>           | <u>1</u>                      | <u>1</u>   |
| Chart speed (cm/min)                         |            | <u>NAI</u>         | <u>NAI</u>                    | <u>1</u>   |
| Detector attenuation                         |            | <u>321 32</u>      | <u>321 32</u>                 | <u>1</u>   |
| Peak retention time (min)                    |            | <u>7.183/7.314</u> | <u>7.314/7.266</u>            | <u>1</u>   |
| Peak retention time range (min)              |            | <u>7.183</u>       | <u>7.266</u>                  | <u>1</u>   |
| Peak area                                    |            | <u>8.3418.49</u>   | <u>77.27175.64</u>            | <u>1</u>   |
| Peak area x attenuation factor               |            | <u>1</u>           | <u>1</u>                      | <u>1</u>   |
| Average peak area value (Y)                  |            | <u>8.42</u>        | <u>76.46</u>                  | <u>1</u>   |
| Percent deviation from average               |            | <u>&lt;5%</u>      | <u>&lt;5%</u>                 | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |            | <u>1.18</u>        | <u>10.2</u>                   | <u>1</u>   |
| % deviation from actual (%D <sub>acc</sub> ) |            | <u>0</u>           | <u>0</u>                      | <u>1</u>   |
| Linear regression equation: slope (m):       |            | <u>7.64</u>        | y-intercept (b): <u>-.481</u> |            |

| Sample Analysis Data                                        | <u>POST</u> | Sample 1           | Sample 2           | Sample 3 |
|-------------------------------------------------------------|-------------|--------------------|--------------------|----------|
| First analysis/second analysis                              |             |                    |                    |          |
| Sample identification                                       |             | <u>1.18</u>        | <u>10.2</u>        | <u>1</u> |
| Interface dilution factor                                   |             |                    |                    | <u>1</u> |
| Flow rate through loop (ml/min)                             |             | <u>600/600</u>     | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |             | <u>NAI</u>         | <u>NAI</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |             | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |             | <u>NAI</u>         | <u>NAI</u>         | <u>1</u> |
| Detector attenuation                                        |             | <u>321 32</u>      | <u>321 32</u>      | <u>1</u> |
| Peak retention time (min)                                   |             | <u>7.183/7.314</u> | <u>7.314/7.266</u> | <u>1</u> |
| Peak retention time range (min)                             |             | <u>7.183</u>       | <u>7.266</u>       | <u>1</u> |
| Peak area                                                   |             | <u>8.7418.95</u>   | <u>77.5475.64</u>  | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |             | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |             | <u>8.85</u>        | <u>76.4</u>        | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |             | <u>4.9%</u>        | <u>.2%</u>         | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |             | <u>1.24</u>        | <u>10.22</u>       | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

METHANE  
 Date: 12-7-92 Analyst: D.S. Plant: MACAS PHALT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: METHANE  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.25% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 CC/MIN  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 100 Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | Standard 1         | Standard 2                   | Standard 3           |
|----------------------------------------------|--------------------|------------------------------|----------------------|
| First analysis/second analysis               |                    |                              |                      |
| Standard concentration (C <sub>std</sub> )   | <u>11</u>          | <u>310</u>                   | <u>495</u>           |
| Flow rate through loop (ml/min)              | <u>600/600</u>     | <u>600/600</u>               | <u>600/600</u>       |
| Liquid injection volume (tubes)              | <u>NAI</u>         | <u>NAI</u>                   | <u>NAI</u>           |
| Injection time (24-hr clock)                 | <u>1</u>           | <u>1</u>                     | <u>1</u>             |
| Chart speed (cm/min)                         | <u>NAI</u>         | <u>NAI</u>                   | <u>NAI</u>           |
| Detector attenuation                         | <u>321/32</u>      | <u>321/32</u>                | <u>321/32</u>        |
| Peak retention time (min)                    | <u>451.45</u>      | <u>451.45</u>                | <u>466.45</u>        |
| Peak retention time range (min)              | <u>.45</u>         | <u>.45</u>                   | <u>.45</u>           |
| Peak area                                    | <u>13611/14.04</u> | <u>380.88/395.84</u>         | <u>593.85/606.70</u> |
| Peak area x attenuation factor               | <u>1</u>           | <u>1</u>                     | <u>1</u>             |
| Average peak area value (Y)                  | <u>13.83</u>       | <u>388.37</u>                | <u>600.28</u>        |
| Percent deviation from average               | <u>5.5%</u>        | <u>5.5%</u>                  | <u>5.5%</u>          |
| Calculated concentration (C <sub>std</sub> ) | <u>8.48</u>        | <u>316.60</u>                | <u>490.93</u>        |
| % deviation from actual (%D <sub>acc</sub> ) | <u>18.2%</u>       | <u>1.7%</u>                  | <u>.7%</u>           |
| Linear regression equation: slope (m):       | <u>1.214</u>       | y-intercept (b): <u>3.52</u> |                      |

| Sample Analysis Data                                        | Sample 1           | Sample 2             | Sample 3             |
|-------------------------------------------------------------|--------------------|----------------------|----------------------|
| First analysis/second analysis                              |                    |                      |                      |
| Sample identification                                       | <u>11</u>          | <u>310</u>           | <u>495</u>           |
| Interface dilution factor                                   |                    |                      |                      |
| Flow rate through loop (ml/min)                             | <u>600/600</u>     | <u>600/600</u>       | <u>600/600</u>       |
| Liquid injection volume (tubes)                             | <u>NAI</u>         | <u>NAI</u>           | <u>NAI</u>           |
| Injection time (24-hr clock)                                | <u>1</u>           | <u>1</u>             | <u>1</u>             |
| Chart speed (cm/min)                                        | <u>NAI</u>         | <u>NAI</u>           | <u>NAI</u>           |
| Detector attenuation                                        | <u>321/32</u>      | <u>321/32</u>        | <u>321/32</u>        |
| Peak retention time (min)                                   | <u>451.45</u>      | <u>451.45</u>        | <u>466.45</u>        |
| Peak retention time range (min)                             | <u>.45</u>         | <u>.45</u>           | <u>.45</u>           |
| Peak area                                                   | <u>13.51/13.54</u> | <u>381.22/395.79</u> | <u>591.05/604.30</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) | <u>1</u>           | <u>1</u>             | <u>1</u>             |
| Average peak area value (Y)                                 | <u>13.53</u>       | <u>388.51</u>        | <u>597.68</u>        |
| % deviation from average (%D <sub>avg</sub> )               | <u>2.2%</u>        | <u>.03%</u>          | <u>.4%</u>           |
| Calculated concentration (C <sub>s</sub> )                  | <u>8.23</u>        | <u>316.71</u>        | <u>488.76</u>        |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

BENTONE  
 Date: 12-8-92 Analyst: D.S. Plant: MACASPHALT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 100 Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1       | Standard 2         | Standard 3  |
|----------------------------------------------|-----|------------------|--------------------|-------------|
| First analysis/second analysis               |     |                  |                    |             |
| Standard concentration (C <sub>std</sub> )   |     | <u>10.5</u>      | <u>10.5</u>        |             |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>   | <u>600/600</u>     |             |
| Liquid injection volume (tubes)              |     | <u>NAI</u>       | <u>NAI</u>         |             |
| Injection time (24-hr clock)                 |     | <u>1</u>         | <u>1</u>           |             |
| Chart speed (cm/min)                         |     | <u>NAI</u>       | <u>NAI</u>         |             |
| Detector attenuation                         |     | <u>32/32</u>     | <u>32/32</u>       |             |
| Peak retention time (min)                    |     | <u>1.33/1.35</u> | <u>1.35/1.35</u>   |             |
| Peak retention time range (min)              |     | <u>1.333</u>     | <u>1.35</u>        |             |
| Peak area                                    |     | <u>7.33/7.13</u> | <u>69.50/70.25</u> |             |
| Peak area x attenuation factor               |     | <u>1</u>         | <u>1</u>           |             |
| Average peak area value (Y)                  |     | <u>7.23</u>      | <u>69.88</u>       |             |
| Percent deviation from average               |     | <u>&lt;5%</u>    | <u>&lt;5%</u>      |             |
| Calculated concentration (C <sub>std</sub> ) |     | <u>10.5</u>      | <u>10.5</u>        |             |
| % deviation from actual (%D <sub>act</sub> ) |     | <u>0</u>         | <u>0</u>           |             |
| Linear regression equation; slope (m):       |     | <u>6.63</u>      | y-intercept (b):   | <u>.269</u> |

| Sample Analysis Data                                        | POST | Sample 1         | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|------------------|--------------------|----------|
| First analysis/second analysis                              |      |                  |                    |          |
| Sample identification                                       |      | <u>10.5</u>      | <u>10.5</u>        |          |
| Interface dilution factor                                   |      |                  |                    |          |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>   | <u>600/600</u>     |          |
| Liquid injection volume (tubes)                             |      | <u>NAI</u>       | <u>NAI</u>         |          |
| Injection time (24-hr clock)                                |      | <u>1</u>         | <u>1</u>           |          |
| Chart speed (cm/min)                                        |      | <u>NAI</u>       | <u>NAI</u>         |          |
| Detector attenuation                                        |      | <u>32/32</u>     | <u>32/32</u>       |          |
| Peak retention time (min)                                   |      | <u>1.33/1.35</u> | <u>1.35/1.35</u>   |          |
| Peak retention time range (min)                             |      | <u>1.33</u>      | <u>1.35</u>        |          |
| Peak area                                                   |      | <u>76.0/74.4</u> | <u>73.63/72.81</u> |          |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>         | <u>1</u>           |          |
| Average peak area value (Y)                                 |      | <u>7.53</u>      | <u>73.23</u>       |          |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>.4%</u>       | <u>4.6%</u>        |          |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.00</u>      | <u>11.01</u>       |          |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$



## ANALYSIS OF METHOD 18 FIELD SAMPLES

ETHYL BENZENE  
 Date: 12-8-92 Analyst: D.S. Plant: MAC ASPHALT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: \_\_\_\_\_  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_  
 GC Used: SRI Column Used: 5% SP1200 / 1.75% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1         | Standard 2                   | Standard 3 |
|----------------------------------------------|-----|--------------------|------------------------------|------------|
| First analysis/second analysis               |     |                    |                              |            |
| Standard concentration (C <sub>std</sub> )   |     | <u>1.28</u>        | <u>9.7</u>                   |            |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>     | <u>600/600</u>               | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>NA1</u>         | <u>NA1</u>                   | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>           | <u>1</u>                     | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>NA1</u>         | <u>NA1</u>                   | <u>1</u>   |
| Detector attenuation                         |     | <u>32/32</u>       | <u>32/32</u>                 | <u>1</u>   |
| Peak retention time (min)                    |     | <u>2.516/2.550</u> | <u>2.566/2.564</u>           | <u>1</u>   |
| Peak retention time range (min)              |     | <u>2.516</u>       | <u>2.566</u>                 |            |
| Peak area                                    |     | <u>73717.84</u>    | <u>7603174.75</u>            | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>           | <u>1</u>                     | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>7.61</u>        | <u>75.39</u>                 |            |
| Percent deviation from average               |     | <u>2.5%</u>        | <u>2.5%</u>                  |            |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.28</u>        | <u>9.7</u>                   |            |
| % deviation from actual (%D <sub>act</sub> ) |     | <u>0</u>           | <u>0</u>                     |            |
| Linear regression equation; slope (m):       |     | <u>8.05</u>        | y-intercept (b): <u>-2.7</u> |            |

| Sample Analysis Data                                        | Post | Sample 1          | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|-------------------|--------------------|----------|
| First analysis/second analysis                              |      |                   |                    |          |
| Sample identification                                       |      | <u>1.28</u>       | <u>9.7</u>         |          |
| Interface dilution factor                                   |      |                   |                    |          |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>    | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>NA1</u>        | <u>NA1</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>          | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>NA1</u>        | <u>NA1</u>         | <u>1</u> |
| Detector attenuation                                        |      | <u>32/32</u>      | <u>32/32</u>       | <u>1</u> |
| Peak retention time (min)                                   |      | <u>2.516/2.55</u> | <u>2.566/2.566</u> | <u>1</u> |
| Peak retention time range (min)                             |      | <u>2.516</u>      | <u>2.566</u>       |          |
| Peak area                                                   |      | <u>8.66/8.79</u>  | <u>81.95/81.30</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>          | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>8.73</u>       | <u>82.13</u>       |          |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>12.8%</u>      | <u>8.2%</u>        |          |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.42</u>       | <u>10.54</u>       |          |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

TOLUENE

Date: 12-8-92 Analyst: DS Plant: MACASPHANT  
 Location: FERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: - Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1        | Standard 2                    | Standard 3 |
|----------------------------------------------|-----|-------------------|-------------------------------|------------|
| First analysis/second analysis               |     |                   |                               |            |
| Standard concentration (C <sub>std</sub> )   |     | <u>1.18</u>       | <u>11</u>                     | <u>.</u>   |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>    | <u>600/600</u>                | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>NA1</u>        | <u>NA1</u>                    | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>          | <u>1</u>                      | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>NA1</u>        | <u>NA1</u>                    | <u>1</u>   |
| Detector attenuation                         |     | <u>32132</u>      | <u>32132</u>                  | <u>1</u>   |
| Peak retention time (min)                    |     | <u>4.614666</u>   | <u>4.73314.733</u>            | <u>1</u>   |
| Peak retention time range (min)              |     | <u>4.6</u>        | <u>4.733</u>                  | <u>1</u>   |
| Peak area                                    |     | <u>11.4311.51</u> | <u>66.44166.93</u>            | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>          | <u>1</u>                      | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>11.47</u>      | <u>66.69</u>                  | <u>1</u>   |
| Percent deviation from average               |     | <u>&lt; 5%</u>    | <u>&lt; 5%</u>                | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.18</u>       | <u>11</u>                     | <u>1</u>   |
| % deviation from actual (%D <sub>acc</sub> ) |     | <u>0</u>          | <u>0</u>                      | <u>1</u>   |
| Linear regression equation; slope (m):       |     | <u>5.623</u>      | y-intercept (b): <u>4.835</u> |            |

| Sample Analysis Data                                        | POST | Sample 1          | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|-------------------|--------------------|----------|
| First analysis/second analysis                              |      |                   |                    |          |
| Sample identification                                       |      | <u>1.18</u>       | <u>11</u>          | <u>1</u> |
| Interface dilution factor                                   |      |                   |                    | <u>1</u> |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>    | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>NA1</u>        | <u>NA1</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>          | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>NA1</u>        | <u>NA1</u>         | <u>1</u> |
| Detector attenuation                                        |      | <u>32132</u>      | <u>32132</u>       | <u>1</u> |
| Peak retention time (min)                                   |      | <u>4.614666</u>   | <u>4.73314.733</u> | <u>1</u> |
| Peak retention time range (min)                             |      | <u>4.6</u>        | <u>4.733</u>       | <u>1</u> |
| Peak area                                                   |      | <u>12.3012.41</u> | <u>78.4778.07</u>  | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>          | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>12.36</u>      | <u>78.27</u>       | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>7.2%</u>       | <u>14.8%</u>       | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.34</u>       | <u>13.06</u>       | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_i - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

ORTHO-XYLENE

Date: 12-8-92 Analyst: D.S. Plant: MACASPHALT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound:  
 Number of Standards: 2 Date Prepared: Prepared By:

GC Used: SRI Column Used: 5% SP1200 / 1.75% BEATONE 34  
 Carrier Gas Used: Na Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: Auxiliary Gases:

| Calibration Data                             | Standard 1         | Standard 2         | Standard 3 |
|----------------------------------------------|--------------------|--------------------|------------|
| First analysis/second analysis               |                    |                    |            |
| Standard concentration (C <sub>std</sub> )   | <u>11.8</u>        | <u>10.2</u>        |            |
| Flow rate through loop (ml/min)              | <u>600/600</u>     | <u>600/600</u>     | <u>1</u>   |
| Liquid injection volume (tubes)              | <u>N/A</u>         | <u>N/A</u>         | <u>1</u>   |
| Injection time (24-hr clock)                 | <u>1</u>           | <u>1</u>           | <u>1</u>   |
| Chart speed (cm/min)                         | <u>N/A</u>         | <u>N/A</u>         | <u>1</u>   |
| Detector attenuation                         | <u>32/32</u>       | <u>32/32</u>       | <u>1</u>   |
| Peak retention time (min)                    | <u>6.314/6.446</u> | <u>6.516/6.516</u> | <u>1</u>   |
| Peak retention time range (min)              | <u>6.314</u>       | <u>6.516</u>       |            |
| Peak area                                    | <u>11.35/10.97</u> | <u>63.92/61.83</u> | <u>1</u>   |
| Peak area x attenuation factor               | <u>1</u>           | <u>1</u>           | <u>1</u>   |
| Average peak area value (Y)                  | <u>11.16</u>       | <u>62.88</u>       |            |
| Percent deviation from average               | <u>&lt;5%</u>      | <u>&lt;5%</u>      |            |
| Calculated concentration (C <sub>std</sub> ) | <u>11.8</u>        | <u>10.2</u>        |            |
| % deviation from actual (%D <sub>acc</sub> ) | <u>0</u>           | <u>0</u>           |            |
| Linear regression equation: slope (m):       | <u>5.733</u>       | y-intercept (b):   | <u>4.4</u> |

| Sample Analysis Data                                        | Sample 1           | Sample 2           | Sample 3 |
|-------------------------------------------------------------|--------------------|--------------------|----------|
| First analysis/second analysis                              |                    |                    |          |
| Sample identification                                       | <u>1.18</u>        | <u>10.2</u>        |          |
| Interface dilution factor                                   |                    |                    |          |
| Flow rate through loop (ml/min)                             | <u>600/600</u>     | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             | <u>N/A</u>         | <u>N/A</u>         | <u>1</u> |
| Injection time (24-hr clock)                                | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        | <u>N/A</u>         | <u>N/A</u>         | <u>1</u> |
| Detector attenuation                                        | <u>32/32</u>       | <u>32/32</u>       | <u>1</u> |
| Peak retention time (min)                                   | <u>6.316/6.446</u> | <u>6.516/6.516</u> | <u>1</u> |
| Peak retention time range (min)                             | <u>6.316</u>       | <u>6.516</u>       |          |
| Peak area                                                   | <u>12.04/12.35</u> | <u>77.22/77.53</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 | <u>12.2</u>        | <u>77.63</u>       |          |
| % deviation from average (%D <sub>avg</sub> )               | <u>8.5%</u>        | <u>19%</u>         |          |
| Calculated concentration (C <sub>s</sub> )                  | <u>1.36</u>        | <u>12.77</u>       |          |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{acc} = \frac{C_{std} - C_{acc}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

METHANE

Date: 12-8-92 Analyst: D.S. Plant: MAC ASPHALT  
 Location: PERRY FL. Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: METHANE  
 Number of Standards: 3 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP 1200 / 1.75% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 140 CC/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 100 Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                                   | Standard 1                    | Standard 2           | Standard 3          |
|----------------------------------------------------|-------------------------------|----------------------|---------------------|
| First analysis/second analysis                     |                               |                      |                     |
| Standard concentration (C <sub>std</sub> )         | <u>11</u>                     | <u>310</u>           | <u>495</u>          |
| Flow rate through loop (ml/min)                    | <u>600/600</u>                | <u>600/600</u>       | <u>600/600</u>      |
| Liquid injection volume (tubes)                    | <u>N/A</u>                    | <u>N/A</u>           | <u>N/A</u>          |
| Injection time (24-hr clock)                       | <u>1</u>                      | <u>1</u>             | <u>1</u>            |
| Chart speed (cm/min)                               | <u>N/A</u>                    | <u>N/A</u>           | <u>N/A</u>          |
| Detector attenuation                               | <u>321 32</u>                 | <u>321 32</u>        | <u>321 32</u>       |
| Peak retention time (min)                          | <u>4 1.383</u>                | <u>4161.416</u>      | <u>4161.416</u>     |
| Peak retention time range (min)                    | <u>.383</u>                   | <u>.416</u>          | <u>.416</u>         |
| Peak area                                          | <u>5.0315.41</u>              | <u>432.001437.44</u> | <u>701.76704.55</u> |
| Peak area x attenuation factor                     | <u>1</u>                      | <u>1</u>             | <u>1</u>            |
| Average peak area value (Y)                        | <u>15.32</u>                  | <u>434.72</u>        | <u>703.16</u>       |
| Percent deviation from average                     | <u>&lt;5%</u>                 | <u>&lt;5%</u>        | <u>&lt;5%</u>       |
| Calculated concentration (C <sub>std</sub> )       | <u>11.97</u>                  | <u>307.45</u>        | <u>496.58</u>       |
| % deviation from actual (%D <sub>act</sub> )       | <u>6.3%</u>                   | <u>.6%</u>           | <u>.2%</u>          |
| Linear regression equation: slope (m): <u>1.42</u> | y-intercept (b): <u>-1.68</u> |                      |                     |

| Sample Analysis Data                                        | Sample 1          | Sample 2           | Sample 3            |
|-------------------------------------------------------------|-------------------|--------------------|---------------------|
| First analysis/second analysis                              |                   |                    |                     |
| Sample identification                                       | <u>11</u>         | <u>310</u>         | <u>495</u>          |
| Interface dilution factor                                   |                   |                    |                     |
| Flow rate through loop (ml/min)                             | <u>600/600</u>    | <u>600/600</u>     | <u>600/600</u>      |
| Liquid injection volume (tubes)                             | <u>N/A</u>        | <u>N/A</u>         | <u>N/A</u>          |
| Injection time (24-hr clock)                                | <u>1</u>          | <u>1</u>           | <u>1</u>            |
| Chart speed (cm/min)                                        | <u>N/A</u>        | <u>N/A</u>         | <u>N/A</u>          |
| Detector attenuation                                        | <u>321 32</u>     | <u>321 32</u>      | <u>321 32</u>       |
| Peak retention time (min)                                   | <u>4 1.383</u>    | <u>4161.416</u>    | <u>4161.416</u>     |
| Peak retention time range (min)                             | <u>.383</u>       | <u>.416</u>        | <u>.416</u>         |
| Peak area                                                   | <u>15.0516.37</u> | <u>432.1436.24</u> | <u>699.54699.85</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) | <u>1</u>          | <u>1</u>           | <u>1</u>            |
| Average peak area value (Y)                                 | <u>15.72</u>      | <u>434.12</u>      | <u>699.71</u>       |
| % deviation from average (%D <sub>avg</sub> )               | <u>2.3%</u>       | <u>.1%</u>         | <u>.5%</u>          |
| Calculated concentration (C <sub>s</sub> )                  | <u>12.26</u>      | <u>307.03</u>      | <u>494.13</u>       |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

BENZENE

Date: 12-9-92 Analyst: D.S. Plant: MAC ASPHALT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min.  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1       | Standard 2                   | Standard 3 |
|----------------------------------------------|-----|------------------|------------------------------|------------|
| First analysis/second analysis               |     |                  |                              |            |
| Standard concentration (C <sub>act</sub> )   |     | <u>1.05</u>      | <u>10.5</u>                  | <u>.</u>   |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>   | <u>600/600</u>               | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>NA/1</u>      | <u>NA/1</u>                  | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>         | <u>1</u>                     | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>NA/1</u>      | <u>NA/1</u>                  | <u>1</u>   |
| Detector attenuation                         |     | <u>32/32</u>     | <u>32/32</u>                 | <u>1</u>   |
| Peak retention time (min)                    |     | <u>1.35/1.35</u> | <u>1.364/1.364</u>           | <u>1</u>   |
| Peak retention time range (min)              |     | <u>1.35</u>      | <u>1.364</u>                 | <u>1</u>   |
| Peak area                                    |     | <u>8.61/9.03</u> | <u>6252/66.33</u>            | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>         | <u>1</u>                     | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>8.82</u>      | <u>66.93</u>                 | <u>1</u>   |
| Percent deviation from average               |     | <u>&lt; 5%</u>   | <u>&lt; 5%</u>               | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.05</u>      | <u>10.5</u>                  | <u>1</u>   |
| % deviation from actual (%D <sub>act</sub> ) |     | <u>0</u>         | <u>0</u>                     | <u>1</u>   |
| Linear regression equation: slope (m):       |     | <u>6.15</u>      | y-intercept (b): <u>2.34</u> |            |

| Sample Analysis Data                                        | POST | Sample 1         | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|------------------|--------------------|----------|
| First analysis/second analysis                              |      |                  |                    |          |
| Sample identification                                       |      | <u>1.05</u>      | <u>10.5</u>        | <u>1</u> |
| Interface dilution factor                                   |      | <u>1</u>         | <u>1</u>           | <u>1</u> |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>   | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>NA/1</u>      | <u>NA/1</u>        | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>         | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>NA/1</u>      | <u>NA/1</u>        | <u>1</u> |
| Detector attenuation                                        |      | <u>32/32</u>     | <u>32/32</u>       | <u>1</u> |
| Peak retention time (min)                                   |      | <u>1.35/1.35</u> | <u>1.364/1.364</u> | <u>1</u> |
| Peak retention time range (min)                             |      | <u>1.35</u>      | <u>1.364</u>       | <u>1</u> |
| Peak area                                                   |      | <u>8.86/8.33</u> | <u>76.91/76.91</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>         | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>8.6</u>       | <u>76.91</u>       | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>2.6%</u>      | <u>13.00%</u>      | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.01</u>      | <u>12.12</u>       | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

ETHYL BENZENE

Date: 12-9-92 Analyst: D.S Plant: MAC ASPHALT  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETX  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP 1200 / 1.75 % BENTONE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 100 Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1         | Standard 2                  | Standard 3 |
|----------------------------------------------|-----|--------------------|-----------------------------|------------|
| First analysis/second analysis               |     |                    |                             |            |
| Standard concentration (C <sub>std</sub> )   |     | <u>1.28</u>        | <u>9.7</u>                  | <u>.</u>   |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>     | <u>600/600</u>              | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>NA1</u>         | <u>NA1</u>                  | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>           | <u>1</u>                    | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>NA1</u>         | <u>NA1</u>                  | <u>1</u>   |
| Detector attenuation                         |     | <u>32132</u>       | <u>32132</u>                | <u>1</u>   |
| Peak retention time (min)                    |     | <u>2.564/2.566</u> | <u>2.600/2.600</u>          | <u>1</u>   |
| Peak retention time range (min)              |     | <u>2.566</u>       | <u>2.600</u>                | <u>1</u>   |
| Peak area                                    |     | <u>91619.35</u>    | <u>7362172.96</u>           | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>           | <u>1</u>                    | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>9.26</u>        | <u>73.29</u>                | <u>1</u>   |
| Percent deviation from average               |     | <u>&lt; 5%</u>     | <u>&lt; 5%</u>              | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.28</u>        | <u>9.7</u>                  | <u>1</u>   |
| % deviation from actual (%D <sub>act</sub> ) |     | <u>0</u>           | <u>0</u>                    | <u>1</u>   |
| Linear regression equation: slope (m):       |     | <u>7.61</u>        | y-intercept (b): <u>-48</u> |            |

| Sample Analysis Data                                        | Post | Sample 1           | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|--------------------|--------------------|----------|
| First analysis/second analysis                              |      |                    |                    |          |
| Sample identification                                       |      | <u>1.28</u>        | <u>9.7</u>         | <u>1</u> |
| Interface dilution factor                                   |      | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>     | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>NA1</u>         | <u>NA1</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>NA1</u>         | <u>NA1</u>         | <u>1</u> |
| Detector attenuation                                        |      | <u>32132</u>       | <u>32132</u>       | <u>1</u> |
| Peak retention time (min)                                   |      | <u>2.564/2.566</u> | <u>2.600/2.600</u> | <u>1</u> |
| Peak retention time range (min)                             |      | <u>2.566</u>       | <u>2.600</u>       | <u>1</u> |
| Peak area                                                   |      | <u>96018.90</u>    | <u>8548183.38</u>  | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>9.25</u>        | <u>84.53</u>       | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>1%</u>          | <u>13.3%</u>       | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.28</u>        | <u>11.18</u>       | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

TOLUENE

Date: 12-9-93 Analyst: D.S. Plant: MACASPART  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CHROMED Target Compound: \_\_\_\_\_  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP 1200 / 1.75% DENTINE 34  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | <u>PRE</u> | Standard 1         | Standard 2                   | Standard 3 |
|----------------------------------------------|------------|--------------------|------------------------------|------------|
| First analysis/second analysis               |            |                    |                              |            |
| Standard concentration (C <sub>std</sub> )   |            | <u>1.18</u>        | <u>11</u>                    |            |
| Flow rate through loop (ml/min)              |            | <u>600/600</u>     | <u>600/600</u>               | <u>1</u>   |
| Liquid injection volume (tubes)              |            | <u>N/A</u>         | <u>N/A</u>                   | <u>1</u>   |
| Injection time (24-hr clock)                 |            | <u>1</u>           | <u>1</u>                     | <u>1</u>   |
| Chart speed (cm/min)                         |            | <u>N/A</u>         | <u>N/A</u>                   | <u>1</u>   |
| Detector attenuation                         |            | <u>32/32</u>       | <u>32/32</u>                 | <u>1</u>   |
| Peak retention time (min)                    |            | <u>4.66/4.66</u>   | <u>4.78/4.78</u>             | <u>1</u>   |
| Peak retention time range (min)              |            | <u>4.66</u>        | <u>4.78</u>                  |            |
| Peak area                                    |            | <u>12.85/12.82</u> | <u>73.86/72.06</u>           | <u>1</u>   |
| Peak area x attenuation factor               |            | <u>1</u>           | <u>1</u>                     | <u>1</u>   |
| Average peak area value (Y)                  |            | <u>12.84</u>       | <u>72.96</u>                 |            |
| Percent deviation from average               |            | <u>2.5%</u>        | <u>2.5%</u>                  |            |
| Calculated concentration (C <sub>std</sub> ) |            | <u>1.18</u>        | <u>11</u>                    |            |
| % deviation from actual (%D <sub>act</sub> ) |            | <u>0</u>           | <u>0</u>                     |            |
| Linear regression equation: slope (m):       |            | <u>6.12</u>        | y-intercept (b): <u>5.62</u> |            |

| Sample Analysis Data                                        | <u>POST</u> | Sample 1           | Sample 2           | Sample 3 |
|-------------------------------------------------------------|-------------|--------------------|--------------------|----------|
| First analysis/second analysis                              |             |                    |                    |          |
| Sample identification                                       |             | <u>1.18</u>        | <u>11</u>          |          |
| Interface dilution factor                                   |             |                    |                    |          |
| Flow rate through loop (ml/min)                             |             | <u>600/600</u>     | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |             | <u>N/A</u>         | <u>N/A</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |             | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |             | <u>N/A</u>         | <u>N/A</u>         | <u>1</u> |
| Detector attenuation                                        |             | <u>32/32</u>       | <u>32/32</u>       | <u>1</u> |
| Peak retention time (min)                                   |             | <u>4.66/4.66</u>   | <u>4.78/4.78</u>   | <u>1</u> |
| Peak retention time range (min)                             |             | <u>4.66</u>        | <u>4.78</u>        |          |
| Peak area                                                   |             | <u>12.11/11.23</u> | <u>76.43/75.35</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |             | <u>1</u>           | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |             | <u>11.67</u>       | <u>76.99</u>       |          |
| % deviation from average (%D <sub>avg</sub> )               |             | <u>10%</u>         | <u>5.2%</u>        |          |
| Calculated concentration (C <sub>s</sub> )                  |             | <u>.987</u>        | <u>11.66</u>       |          |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$

## ANALYSIS OF METHOD 18 FIELD SAMPLES

ORTHO - XYLENE

Date: 12-9-92 Analyst: D.S. Plant: MACASphalt  
 Location: PERRY FL Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: BETA  
 Number of Standards: 2 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200/1.75% DENTONE 34  
 Carrier Gas Used: N2 Carrier Gas Flow Rate: 40 CC/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 10C Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | PRE | Standard 1         | Standard 2                   | Standard 3 |
|----------------------------------------------|-----|--------------------|------------------------------|------------|
| First analysis/second analysis               |     |                    |                              |            |
| Standard concentration (C <sub>std</sub> )   |     | <u>1.18</u>        | <u>10.2</u>                  | <u>1</u>   |
| Flow rate through loop (ml/min)              |     | <u>600/600</u>     | <u>600/600</u>               | <u>1</u>   |
| Liquid injection volume (tubes)              |     | <u>NA1</u>         | <u>NA1</u>                   | <u>1</u>   |
| Injection time (24-hr clock)                 |     | <u>1</u>           | <u>1</u>                     | <u>1</u>   |
| Chart speed (cm/min)                         |     | <u>NA1</u>         | <u>NA1</u>                   | <u>1</u>   |
| Detector attenuation                         |     | <u>32132</u>       | <u>32132</u>                 | <u>1</u>   |
| Peak retention time (min)                    |     | <u>6.433/6.433</u> | <u>6.583/6.583</u>           | <u>1</u>   |
| Peak retention time range (min)              |     | <u>6.433</u>       | <u>6.583</u>                 | <u>1</u>   |
| Peak area                                    |     | <u>123412.51</u>   | <u>6959168.65</u>            | <u>1</u>   |
| Peak area x attenuation factor               |     | <u>1</u>           | <u>1</u>                     | <u>1</u>   |
| Average peak area value (Y)                  |     | <u>12.44</u>       | <u>69.12</u>                 | <u>1</u>   |
| Percent deviation from average               |     | <u>2.5%</u>        | <u>2.5%</u>                  | <u>1</u>   |
| Calculated concentration (C <sub>std</sub> ) |     | <u>1.18</u>        | <u>10.2</u>                  | <u>1</u>   |
| % deviation from actual (%D <sub>act</sub> ) |     | <u>0</u>           | <u>0</u>                     | <u>1</u>   |
| Linear regression equation: slope (m):       |     | <u>6.284</u>       | y-intercept (b): <u>5.02</u> |            |

| Sample Analysis Data                                        | POST | Sample 1            | Sample 2           | Sample 3 |
|-------------------------------------------------------------|------|---------------------|--------------------|----------|
| First analysis/second analysis                              |      |                     |                    |          |
| Sample identification                                       |      | <u>1.18</u>         | <u>10.2</u>        | <u>1</u> |
| Interface dilution factor                                   |      | <u>1</u>            | <u>1</u>           | <u>1</u> |
| Flow rate through loop (ml/min)                             |      | <u>600/600</u>      | <u>600/600</u>     | <u>1</u> |
| Liquid injection volume (tubes)                             |      | <u>NA1</u>          | <u>NA1</u>         | <u>1</u> |
| Injection time (24-hr clock)                                |      | <u>1</u>            | <u>1</u>           | <u>1</u> |
| Chart speed (cm/min)                                        |      | <u>NA1</u>          | <u>NA1</u>         | <u>1</u> |
| Detector attenuation                                        |      | <u>32132</u>        | <u>32132</u>       | <u>1</u> |
| Peak retention time (min)                                   |      | <u>6.433/6.433</u>  | <u>6.583/6.583</u> | <u>1</u> |
| Peak retention time range (min)                             |      | <u>6.433</u>        | <u>6.583</u>       | <u>1</u> |
| Peak area                                                   |      | <u>10.911/11.23</u> | <u>73.72/73.72</u> | <u>1</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) |      | <u>1</u>            | <u>1</u>           | <u>1</u> |
| Average peak area value (Y)                                 |      | <u>11.07</u>        | <u>73.72</u>       | <u>1</u> |
| % deviation from average (%D <sub>avg</sub> )               |      | <u>12.4%</u>        | <u>6.2%</u>        | <u>1</u> |
| Calculated concentration (C <sub>s</sub> )                  |      | <u>1.963</u>        | <u>10.93</u>       | <u>1</u> |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$



## ANALYSIS OF METHOD 18 FIELD SAMPLES

METHANE

Date: 12-9-92 Analyst: D.S Plant: MAC ASPHALT  
 Location: PERRY FL. Sample Type: GAS  
 Type of Calibration Standard: CYLINDER Target Compound: METHANE  
 Number of Standards: 3 Date Prepared: \_\_\_\_\_ Prepared By: \_\_\_\_\_

GC Used: SRI Column Used: 5% SP1200 / 1.75% PENTONE 3T  
 Carrier Gas Used: N<sub>2</sub> Carrier Gas Flow Rate: 40 cc/min  
 Column Temperatures, Initial: 75C Program Rate: \_\_\_\_\_ Final: 75C  
 Sample Loop Volume: 1cc Loop Temperature: 75C Inject. Port Temp.: 75C  
 Detector Temp.: \_\_\_\_\_ Auxiliary Gases: \_\_\_\_\_

| Calibration Data                             | Standard 1       | Standard 2                    | Standard 3        |
|----------------------------------------------|------------------|-------------------------------|-------------------|
| First analysis/second analysis               |                  |                               |                   |
| Standard concentration (C <sub>std</sub> )   | <u>11</u>        | <u>310</u>                    | <u>495</u>        |
| Flow rate through loop (ml/min)              | <u>600/600</u>   | <u>600/600</u>                | <u>600/600</u>    |
| Liquid injection volume (tubes)              | <u>NA1</u>       | <u>NA1</u>                    | <u>NA1</u>        |
| Injection time (24-hr clock)                 | <u>1</u>         | <u>1</u>                      | <u>1</u>          |
| Chart speed (cm/min)                         | <u>NA1</u>       | <u>NA1</u>                    | <u>NA1</u>        |
| Detector attenuation                         | <u>321/32</u>    | <u>321/32</u>                 | <u>321/32</u>     |
| Peak retention time (min)                    | <u>3.83/4.00</u> | <u>4.16/4.16</u>              | <u>4.16/4.16</u>  |
| Peak retention time range (min)              | <u>3.83</u>      | <u>4.16</u>                   | <u>4.16</u>       |
| Peak area                                    | <u>170417.64</u> | <u>489551.47</u>              | <u>7053175.90</u> |
| Peak area x attenuation factor               | <u>1</u>         | <u>1</u>                      | <u>1</u>          |
| Average peak area value (Y)                  | <u>17.35</u>     | <u>480.5</u>                  | <u>733.72</u>     |
| Percent deviation from average               | <u>&lt;5%</u>    | <u>&lt;5%</u>                 | <u>&lt;5%</u>     |
| Calculated concentration (C <sub>std</sub> ) | <u>7.53</u>      | <u>319.071</u>                | <u>489.4</u>      |
| % deviation from actual (%D <sub>act</sub> ) | <u>20%</u>       | <u>1.9%</u>                   | <u>.8%</u>        |
| Linear regression equation: slope (m):       | <u>1.487</u>     | y-intercept (b): <u>6.151</u> |                   |

| Sample Analysis Data                                        | Sample 1         | Sample 2         | Sample 3           |
|-------------------------------------------------------------|------------------|------------------|--------------------|
| First analysis/second analysis                              |                  |                  |                    |
| Sample identification                                       | <u>11</u>        | <u>310</u>       | <u>495</u>         |
| Interface dilution factor                                   |                  |                  |                    |
| Flow rate through loop (ml/min)                             | <u>600/600</u>   | <u>600/600</u>   | <u>600/600</u>     |
| Liquid injection volume (tubes)                             | <u>NA1</u>       | <u>NA1</u>       | <u>NA1</u>         |
| Injection time (24-hr clock)                                | <u>1</u>         | <u>1</u>         | <u>1</u>           |
| Chart speed (cm/min)                                        | <u>NA1</u>       | <u>NA1</u>       | <u>NA1</u>         |
| Detector attenuation                                        | <u>321/32</u>    | <u>321/32</u>    | <u>321/32</u>      |
| Peak retention time (min)                                   | <u>3.83/4.00</u> | <u>4.16/4.16</u> | <u>4.16/4.16</u>   |
| Peak retention time range (min)                             | <u>4.16</u>      | <u>4.16</u>      | <u>4.16</u>        |
| Peak area                                                   | <u>156715.76</u> | <u>425894.25</u> | <u>62891709.53</u> |
| Peak area x atten. factor (A <sub>1</sub> /A <sub>2</sub> ) | <u>1</u>         | <u>1</u>         | <u>1</u>           |
| Average peak area value (Y)                                 | <u>15.72</u>     | <u>425.76</u>    | <u>6281.21</u>     |
| % deviation from average (%D <sub>avg</sub> )               | <u>10.4%</u>     | <u>12.9%</u>     | <u>7.7%</u>        |
| Calculated concentration (C <sub>s</sub> )                  | <u>6.43</u>      | <u>282.25</u>    | <u>454.68</u>      |

$$C_{std} \text{ or } C_s = \frac{(Y - b)}{m} \quad \%D_{avg} = \left| \frac{A_1 - Y}{Y} \right| \times 100\% \quad \%D_{act} = \frac{C_{std} - C_{act}}{Y} \times 100\%$$

## **VIII. EQUIPMENT CALIBRATION DATA**

### **B. CEMS Calibration Data**

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

177

SO<sub>2</sub> MONITORSPlant NAPA - Mac AsphaltLocation Perry, Fla.Date 12-7-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| Gas Type              | Actual Concentration | Analyzer Response |
|-----------------------|----------------------|-------------------|
| SO <sub>2</sub> -Zero | 0.0                  | 0.9               |
| SO <sub>2</sub> -High | 78                   | 77.7              |
| SO <sub>2</sub> -Mid  | 55                   | 54.5              |

System Bias Response: Analyzer Response-Initial Bias =  $\pm 5\%$  Span  
 Final Bias - Initial Bias =  $\pm 3\%$  Span

Run # 1 Time: 11:45-11:47 + 12:59-14:03

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 0.9                   | 1.1                 |       |
| SO <sub>2</sub> | 77.7                  | 77.9                |       |

Run # 2 Time: 14:52-16:07

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 1.1                   | 1.9                 |       |
| SO <sub>2</sub> | 77.9                  | 79.1                |       |

\* 12-8-92 Run # 3 Time: 8:30-8:40 + 9:30-10:24

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 1.0                   | 30.0                |       |
| SO <sub>2</sub> | 78.1                  | 49.0                |       |

12-8-92 Run # 4 Time: 11:24-12:37

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 0.7                   | 1.1                 |       |
| SO <sub>2</sub> | 73.4                  | 74.5                |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

178

SO<sub>2</sub> MONITORSPlant NAPA- Mac AsphaltLocation Perry, Fla.Date 12-8-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| Gas Type              | Actual Concentration | Analyzer Response |
|-----------------------|----------------------|-------------------|
| SO <sub>2</sub> -Zero |                      |                   |
| SO <sub>2</sub> -High |                      |                   |
| SO <sub>2</sub> -Mid  |                      |                   |

System Bias Response: Analyzer Response-Initial Bias =  $\pm 5\%$  Span  
 Final Bias - Initial Bias =  $\pm 3\%$  Span

Run # 5 Time: 13:43 - 13:52 + 15:45 - 17:11

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 1.0                   | -0.6                |       |
| SO <sub>2</sub> | 76.2                  | 72.4                |       |

12-9-92 Run # 6 Time: 9:46 - 12:16

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 0.9                   | 0.3                 |       |
| SO <sub>2</sub> | 77.4                  | 76.8                |       |

Run # Time:

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            |                       |                     |       |
| SO <sub>2</sub> |                       |                     |       |

Run # Time:

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            |                       |                     |       |
| SO <sub>2</sub> |                       |                     |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

## CARBON MONOXIDE

179

Plant WAPA-Mac AsphaltLocation Perry, Fla.Date 12-7-92Operator TMCO Range 0-1000 ppmInitial Calibration: (Accuracy:  $\pm 5\%$  Span)

| Gas Type | Actual Concentration | Anayzer Response |
|----------|----------------------|------------------|
| CO-Zero  | 0                    | 1.0              |
| CO-High  | 904                  | 909              |
| CO-Mid   | 536                  | 530              |
| CO-Low   | 290                  | 283              |

Zero & Span Drift: (Accuracy  $\pm 5\%$  Span)End Run # 1 Time: 11:45-11:47 + 12:59-14:03

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 1.0              | -3.1           |       |
| CO-290   | 283              | 291            |       |

End Run # 2 Time: 14:52-16:07

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 0.3              | -2.1           |       |
| CO-904   | 906              | 904            |       |

12-8-92 End Run # 3 Time: 8:30-8:40 + 9:30-10:24

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 1.0              | -1.9           |       |
| CO-904   | 906              | 900            |       |

12-8-92 End Run # 4 Time: 11:24-12:37

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 2.0              | -2.3           |       |
| CO-904   | 904              | 894            |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

## CARBON MONOXIDE

180

Plant NAPA - Mac AsphaltLocation Perry, Fla.Date 12-8-92Operator TMCO Range 0-1000 ppmInitial Calibration: (Accuracy:  $\pm 5\%$  Span)

| Gas Type | Actual Concentration | Anayzer Response |
|----------|----------------------|------------------|
| CO-Zero  | 0                    |                  |
| CO-High  |                      |                  |
| CO-Mid   |                      |                  |
| CO-Low   |                      |                  |

Zero & Span Drift: (Accuracy  $\pm 5\%$  Span)End Run # 5 Time: 13:43-13:52 + 15:45-17:11

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 1.2              | -4.2           |       |
| CO-904   | 911              | 924            |       |

12-9-92 End Run # 6 Time: 9:46-12:16

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 0.8              | -7.0           |       |
| CO-904   | 903              | 924            |       |

12-9-92 End Run # 7 Time: 12:48-13:53

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 1.1              | -5.0           |       |
| CO-904   | 908              | 921            |       |

12-9-92 End Run # 8 Time: 14:24-15:34

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | -0.9             | -11.9          |       |
| CO-904   | 907              | 919            |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

## CARBON MONOXIDE

181

Plant NAPA-Mac AsphaltLocation Perry, Fla.Date 12-9-92Operator TMCO Range 0-1000 ppmInitial Calibration: (Accuracy:  $\pm 5\%$  Span)

| Gas Type | Actual Concentration | Anayzer Response |
|----------|----------------------|------------------|
| CO-Zero  | 0                    |                  |
| CO-High  |                      |                  |
| CO-Mid   |                      |                  |
| CO-Low   |                      |                  |

Zero & Span Drift: (Accuracy  $\pm 5\%$  Span)End Run # 9 Time: 16:11-17:00

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  | 2.0              | -12.7          |       |
| CO-      | 920              | 930            |       |

End Run # Time:

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  |                  |                |       |
| CO-      |                  |                |       |

End Run # Time:

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  |                  |                |       |
| CO-      |                  |                |       |

End Run # Time:

| Gas Type | Initial Response | Final Response | Drift |
|----------|------------------|----------------|-------|
| CO-Zero  |                  |                |       |
| CO-      |                  |                |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

182

## TOTAL HYDROCARBONS

PLANT NAPA - MacAsphalt LOCATION Perry, Fla.  
 DATE 12-7-92 OPERATOR TM  
 HC RANGE 0-1000 ppm Methane RESPONSE TIME \_\_\_\_\_

INITIAL CALIBRATION: (Accuracy  $\pm 5\%$  of calibration gas value)

| Gas Type  | Actual Concentration | Analyzer | Gas Type | Actual Concentration | Analyzer |
|-----------|----------------------|----------|----------|----------------------|----------|
| HC - Zero | 0                    | 0.4      | HC - Mid | 495                  | 500      |
| HC - High | 999                  | 995      | HC - Low | 310                  | 309      |

ZERO & SPAN DRIFT: (Accuracy  $\pm 3\%$  of span)

12-8-92

| Run #     | 1                | Time: 11:45 + 11:47 + 12:59 - 14:02 |
|-----------|------------------|-------------------------------------|
| Gas Type  | Initial Response | Final Response                      |
| HC - Zero | 0.4              | -2.3                                |
| HC - 495  | 500              | 496                                 |

12-8-92

| Run #     | 4                | Time: 11:24 - 12:37 |
|-----------|------------------|---------------------|
| Gas Type  | Initial Response | Final Response      |
| HC - Zero | 0.9              | 1.9                 |
| HC - 495  | 500              | 499                 |

12-8-92

| Run #     | 2                | Time: 14:52 - 16:07 |
|-----------|------------------|---------------------|
| Gas Type  | Initial Response | Final Response      |
| HC - Zero | 0.2              | -1.0                |
| HC - 495  | 499              | 497                 |

12-8-92

| Run #     | 5                | Time: 13:43 - 13:52 + 15:45 - 17:4 |
|-----------|------------------|------------------------------------|
| Gas Type  | Initial Response | Final Response                     |
| HC - Zero | 1.1              | -3.2                               |
| HC - 495  | 495              | 479.9                              |

12-8-92

| Run #     | 3                | Time: 8:30 - 8:40 + 9:30 - 10:24 |
|-----------|------------------|----------------------------------|
| Gas Type  | Initial Response | Final Response                   |
| HC - Zero | 0.1              | 3.0                              |
| HC - 495  | 496              | 503                              |

12-9-92

| Run #     | 6                | Time: 9:46 - 12:16 |
|-----------|------------------|--------------------|
| Gas Type  | Initial Response | Final Response     |
| HC - Zero | 0.3              | -4.0               |
| HC -      | 499              | 496                |



## INSTRUMENTAL ANALYSIS CALIBRATION DATA

183

## TOTAL HYDROCARBONS

PLANT NAPA - Mac Asphalt LOCATION Perry, Fla.  
 DATE 12-9-92 OPERATOR TM  
 H C RANGE 0-1000 ppm Methane RESPONSE TIME \_\_\_\_\_

INITIAL CALIBRATION: (Accuracy  $\pm 5\%$  of calibration gas value)

| Gas Type  | Actual Concentration | Analyzer | Gas Type | Actual Concentration | Analyzer |
|-----------|----------------------|----------|----------|----------------------|----------|
| HC - Zero | 0                    |          | HC - Mid |                      |          |
| HC - High |                      |          | HC - Low |                      |          |

ZERO & SPAN DRIFT: (Accuracy  $\pm 3\%$  of span)

| Run # 7   | Time: 12:48-13:53 |                |
|-----------|-------------------|----------------|
| Gas Type  | Initial Response  | Final Response |
| HC - Zero | 0.5               | 2.7            |
| HC - 495  | 498               | 492            |

| Run #    | Time:            |                |
|----------|------------------|----------------|
| Gas Type | Initial Response | Final Response |
| HC- Zero |                  |                |
| HC -     |                  |                |

| Run # 8   | Time: 14:24-15:34 |                |
|-----------|-------------------|----------------|
| Gas Type  | Initial Response  | Final Response |
| HC - Zero | -0.3              | -1.7           |
| HC - 495  | 490               | 487            |

| Run #    | Time:            |                |
|----------|------------------|----------------|
| Gas Type | Initial Response | Final Response |
| HC- Zero |                  |                |
| HC -     |                  |                |

| Run # 9   | Time: 16:11-17:00 |                |
|-----------|-------------------|----------------|
| Gas Type  | Initial Response  | Final Response |
| HC - Zero | 1.0               | -0.2           |
| HC - 495  | 502               | 492            |

| Run #    | Time:            |                |
|----------|------------------|----------------|
| Gas Type | Initial Response | Final Response |
| HC- Zero |                  |                |
| HC -     |                  |                |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

184

NO<sub>x</sub> MONITORPlant NAPA - MacAsphaltLocation Perry, Fla.Date 12-7-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| Gas Type              | Actual Concentration | Analyzer Response |
|-----------------------|----------------------|-------------------|
| NO <sub>x</sub> -Zero | 0.0                  | 0.9               |
| NO <sub>x</sub> -High | 200                  | 202               |
| NO <sub>x</sub> -Mid  | 143                  | 144               |

System Bias Response: Analyzer Response-Initial Bias =  $\pm 5\%$  Span  
 Final Bias - Initial Bias =  $\pm 3\%$  Span

Run # 1 Time: 11:45-11:47 + 12:59-14:03

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 0.9                   | 12.1                |       |
| NO <sub>x</sub> | 144                   | 172                 |       |

Run # 2 Time: 14:52-16:07

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 0.4                   | 14.0                |       |
| NO <sub>x</sub> | 143.4                 | 177.1               |       |

12-8-92 Run # 3 Time: 8:30-8:40 + 9:30-10:24

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 1.0                   | 5.4                 |       |
| NO <sub>x</sub> | 143.1                 | 151                 |       |

12-8-92 Run # 4 Time: 11:24-12:37

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | 0.9                   | 6.2                 |       |
| NO <sub>x</sub> | 144.1                 | 153.2               |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

185

NO<sub>x</sub> MONITORPlant NAPA-MacAsphaltLocation Perry, Fla.Date 12-8-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| Gas Type              | Actual Concentration | Analyzer Response |
|-----------------------|----------------------|-------------------|
| NO <sub>x</sub> -Zero |                      |                   |
| NO <sub>x</sub> -High |                      |                   |
| NO <sub>x</sub> -Mid  |                      |                   |

System Bias Response: Analyzer Response-Initial Bias =  $\pm 5\%$  Span  
 Final Bias - Initial Bias =  $\pm 3\%$  Span

Run # 5 Time: 13:43 - 13:52 + 15:45 - 17:11

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | <u>0.7</u>            | <u>6.7</u>          |       |
| NO <sub>x</sub> | <u>143.5</u>          | <u>149.9</u>        |       |

12-9-92 Run # 6 Time: 9:46 - 12:14

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | <u>1.1</u>            | <u>12.0</u>         |       |
| NO <sub>x</sub> | <u>143.3</u>          | <u>159.2</u>        |       |

12-9-92 Run # 7 Time: 12:48 - 13:53

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | <u>0.7</u>            | <u>9.1</u>          |       |
| NO <sub>x</sub> | <u>144.0</u>          | <u>151.0</u>        |       |

12-9-92 Run # 8 Time: 14:24 - 15:34

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | <u>1.2</u>            | <u>4.5</u>          |       |
| NO <sub>x</sub> | <u>142.9</u>          | <u>149.6</u>        |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

186

NO<sub>x</sub> MONITORPlant NADA-Mac AsphaltLocation Perry, Fla.Date 12-9-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| Gas Type              | Actual Concentration | Analyzer Response |
|-----------------------|----------------------|-------------------|
| NO <sub>x</sub> -Zero |                      |                   |
| NO <sub>x</sub> -High |                      |                   |
| NO <sub>x</sub> -Mid  |                      |                   |

System Bias Response: Analyzer Response-Initial Bias =  $\pm 5\%$  Span  
Final Bias - Initial Bias =  $\pm 3\%$  Span

Run # 9 Time: 16:11-17:00

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            | <u>0.3</u>            | <u>5.1</u>          |       |
| NO <sub>x</sub> | <u>143.1</u>          | <u>148.3</u>        |       |

Run # Time:

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            |                       |                     |       |
| NO <sub>x</sub> |                       |                     |       |

Run # Time:

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            |                       |                     |       |
| NO <sub>x</sub> |                       |                     |       |

Run # Time:

| Gas Type        | Initial Bias Response | Final Bias Response | Drift |
|-----------------|-----------------------|---------------------|-------|
| Zero            |                       |                     |       |
| NO <sub>x</sub> |                       |                     |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

DILUENT O<sub>2</sub> AND CO<sub>2</sub> MONITORS

187

Plant NAPA MacAsphaltLocation Perry, Fla.Date 12-7-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| O <sub>2</sub>       |                      |                   | CO <sub>2</sub>       |                      |                   |
|----------------------|----------------------|-------------------|-----------------------|----------------------|-------------------|
| Gas Type             | Actual Concentration | Analyzer Response | Gas Type              | Actual Concentration | Analyzer Response |
| O <sub>2</sub> -Zero | 0.0                  | 0.0               | CO <sub>2</sub> -Zero | 0.0                  | 0.1               |
| O <sub>2</sub> -High | 20.9                 | 21.1              | CO <sub>2</sub> -High | 17.1                 | 17.2              |
| O <sub>2</sub> -Mid  | 10.0                 | 10.0              | CO <sub>2</sub> -Mid  | 10.0                 | 10.0              |

System Bias Response:

Analyzer Response-Initial Bias =  $\pm 5\%$  SpanFinal Bias - Initial Bias =  $\pm 3\%$  Span

Run # 1

Time: 11:45 - 11:47 + 12:59 - 14:03

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.0                   | 0.0  | 0.1                 | 0.1  |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.0                  | 10.0 | 10.1                | 10.1 |       |

Run # 2

Time: 14:52 - 16:07

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.1                   | 0.1  | 0.3                 | 0.1  |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.1                  | 10.1 | 10.4                | 10.6 |       |

12-8-92

Run # 3

Time: 8:30 - 8:40 + 9:30 - 10:24

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.0                   | 0.0  | 0.3                 | -0.3 |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.0                  | 10.0 | 10.1                | 9.8  |       |

12-8-92

Run # 4

Time: 11:24 - 12:37

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.6                   | 0.1  | 0.2                 | 0.2  |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.1                  | 10.0 | 10.1                | 10.2 |       |

# INSTRUMENTAL ANALYSIS CALIBRATION DATA

## DILUENT O<sub>2</sub> AND CO<sub>2</sub> MONITORS

188

Plant NAPA- Mac Asphalt

Location Perry, Fla.

Date 12-8-92

Operator TM

Initial Calibration (Accuracy:  $\pm 2\%$  Span)

| O <sub>2</sub>       |                      |                   | CO <sub>2</sub>       |                      |                   |
|----------------------|----------------------|-------------------|-----------------------|----------------------|-------------------|
| Gas Type             | Actual Concentration | Analyzer Response | Gas Type              | Actual Concentration | Analyzer Response |
| O <sub>2</sub> -Zero |                      |                   | CO <sub>2</sub> -Zero |                      |                   |
| O <sub>2</sub> -High |                      |                   | CO <sub>2</sub> -High |                      |                   |
| O <sub>2</sub> -Mid  |                      |                   | CO <sub>2</sub> -Mid  |                      |                   |

System Bias Response: Analyzer Response-Initial Bias =  $\pm 5\%$  Span  
Final Bias - Initial Bias =  $\pm 3\%$  Span

Run # 5 Time: 13:43-13:52 + 15:45-17:11

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.1                   | 0.0  | 0.3                 | 0.1  |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.1                  | 10.0 | 10.2                | 10.0 |       |

12-9-92 Run # 6 Time: 9:46-12:16

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.1                   | 0.1  | 0.3                 | 0.2  |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.1                  | 10.1 | 10.2                | 10.1 |       |

12-9-92 Run # 7 Time: 12:48-13:53

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.0                   | 0.0  | 0.3                 | -0.1 |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.1                  | 10.0 | 10.3                | 9.8  |       |

12-9-92 Run # 8 Time: 14:24-15:34

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.1                   | 0.1  | 0.2                 | -0.1 |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.0                  | 10.1 | 10.2                | 9.9  |       |

## INSTRUMENTAL ANALYSIS CALIBRATION DATA

DILUENT O<sub>2</sub> AND CO<sub>2</sub> MONITORS

189

Plant NAPA - Mac AsphaltLocation Perry, Fla.Date 12-9-92Operator TMInitial Calibration (Accuracy:  $\pm 2\%$  Span)

| O <sub>2</sub>       |                      |                   | CO <sub>2</sub>       |                      |                   |
|----------------------|----------------------|-------------------|-----------------------|----------------------|-------------------|
| Gas Type             | Actual Concentration | Analyzer Response | Gas Type              | Actual Concentration | Analyzer Response |
| O <sub>2</sub> -Zero |                      |                   | CO <sub>2</sub> -Zero |                      |                   |
| O <sub>2</sub> -High |                      |                   | CO <sub>2</sub> -High |                      |                   |
| O <sub>2</sub> -Mid  |                      |                   | CO <sub>2</sub> -Mid  |                      |                   |

System Bias Response:

Analyzer Response-Initial Bias =  $\pm 5\%$  SpanFinal Bias - Initial Bias =  $\pm 3\%$  SpanRun # 9Time: 16:11-17:00

| Gas Type                        | Initial Bias Response |      | Final Bias Response |      | Drift |
|---------------------------------|-----------------------|------|---------------------|------|-------|
| Zero                            | 0.0                   | 0.0  | -0.2                | 0.2  |       |
| CO <sub>2</sub> /O <sub>2</sub> | 10.0                  | 10.1 | 9.9                 | 10.2 |       |

Run #

Time:

| Gas Type                        | Initial Bias Response |  | Final Bias Response |  | Drift |
|---------------------------------|-----------------------|--|---------------------|--|-------|
| Zero                            |                       |  |                     |  |       |
| CO <sub>2</sub> /O <sub>2</sub> |                       |  |                     |  |       |

Run #

Time:

| Gas Type                        | Initial Bias Response |  | Final Bias Response |  | Drift |
|---------------------------------|-----------------------|--|---------------------|--|-------|
| Zero                            |                       |  |                     |  |       |
| CO <sub>2</sub> /O <sub>2</sub> |                       |  |                     |  |       |

Run #

Time:

| Gas Type                        | Initial Bias Response |  | Final Bias Response |  | Drift |
|---------------------------------|-----------------------|--|---------------------|--|-------|
| Zero                            |                       |  |                     |  |       |
| CO <sub>2</sub> /O <sub>2</sub> |                       |  |                     |  |       |

## **VIII. EQUIPMENT CALIBRATION DATA**

### **C. Particulate Calibration Data**



## TYPE S PITOT TUBE INSPECTION DATA FORM

Pitot tube assembly level? ☒ yes ☐ noPitot tube openings damaged? ☐ yes (explain below) ☒ no $\alpha_1 = 1.3^\circ (<10^\circ)$ ,  $\alpha_2 = 0.8^\circ (<10^\circ)$ ,  $\beta_1 = 0.5^\circ (<5^\circ)$ , $\beta_2 = 1.8^\circ (<5^\circ)$  $\gamma = 2.9^\circ$ ,  $\theta = 1.7^\circ$ ,  $A = .97$  cm (in.) $z = A \sin \gamma = .05$  cm (in.);  $<0.32$  cm ( $<1/8$  in.), $w = A \sin \theta = .03$  cm (in.);  $<.08$  cm ( $<1/32$  in.) $P_A = .48$  cm (in.)  $P_b = .49$  cm (in.) $D_t = .38$  cm (in.)Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_Calibration required? ☐ yes ☒ no



Nozzle Diameter Calibration

Date \_\_\_\_\_

Signature \_\_\_\_\_

Nozzle No.   Average Diameter

|   |       |
|---|-------|
| 1 | _____ |
| 2 | _____ |
| 3 | _____ |
| 4 | _____ |
| 5 | _____ |
| 6 | _____ |

Nozzle No.   Average Diameter

|    |       |
|----|-------|
| 7  | _____ |
| 8  | _____ |
| 9  | _____ |
| 10 | _____ |
| 11 | _____ |
| 12 | _____ |

Pitot Tube Calibration (S Type)Pitot Tube Identification No. 44Date 6-9-91Calibrated by: S Buck"A" SIDE CALIBRATION

| Run No.              | $\Delta p$ std<br>cm H <sub>2</sub> O<br>(in. H <sub>2</sub> O) | $\Delta p$ (s)<br>cm H <sub>2</sub> O<br>(in. H <sub>2</sub> O) | $C_p$ (s) | DEVIATION<br>$C_p(s) - \bar{C}_p(A)$ |
|----------------------|-----------------------------------------------------------------|-----------------------------------------------------------------|-----------|--------------------------------------|
| 1                    | 2.2                                                             | 3.3                                                             | .816      | .004                                 |
| 2                    | 1.8                                                             | 2.7                                                             | .816      | .004                                 |
| 3                    | 1.1                                                             | 1.6                                                             | .829      | .009                                 |
| $\bar{C}_p$ (SIDE A) |                                                                 |                                                                 | .820      |                                      |

"B" SIDE CALIBRATION

| Run No.              | $\Delta p$ std<br>cm H <sub>2</sub> O<br>(in. H <sub>2</sub> O) | $\Delta p$ (s)<br>cm H <sub>2</sub> O<br>(in. H <sub>2</sub> O) | $C_p$ (s) | DEVIATION<br>$C_p(s) - \bar{C}_p(B)$ |
|----------------------|-----------------------------------------------------------------|-----------------------------------------------------------------|-----------|--------------------------------------|
| 1                    | 2.2                                                             | 3.3                                                             | .816      | .004                                 |
| 2                    | 1.8                                                             | 2.7                                                             | .816      | .004                                 |
| 3                    | 1.1                                                             | 1.6                                                             | .829      | .009                                 |
| $\bar{C}_p$ (SIDE B) |                                                                 |                                                                 | .820      |                                      |

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} + \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| + \text{MUST BE } \leq 0.01$$

$$C_p(s) = C_p(\text{std}) \sqrt{\frac{\Delta p \text{ std}}{\Delta p s}}$$

## STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 5-5-90 Thermocouple number 44  
 Ambient temperature 20 °C Barometric pressure 29.88 in. Hg  
 Calibrator Stuma Reference: mercury-in-glass ✓  
 other \_\_\_\_\_

| Reference point number | Source <sup>a</sup> (specify) | Reference thermometer temperature, °C | Thermocouple potentiometer temperature, °C | Temperature difference, <sup>b</sup> % |
|------------------------|-------------------------------|---------------------------------------|--------------------------------------------|----------------------------------------|
| A                      | Ice Bath                      | 32                                    | 32                                         | 0                                      |
| B                      | Boiling water                 | 212                                   | 218                                        | 0                                      |
| C                      | Boiling oil                   | 381                                   | 381                                        | 0                                      |
| D                      | ambient                       |                                       |                                            |                                        |

<sup>a</sup>Type of calibration system used.

<sup>b</sup>
$$\left[ \frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$


RAMCON

## Lear Siegler Stack Sampler

Heating Probe Calibration

Probe No. 441 Probe Length 4'  
Date of Calibration 5-7-89 Signature Sam Turner  
Name of Company to be tested \_\_\_\_\_

Note: 3 ft. probe - 5 min. warmup  
6 ft. probe - 15 min. warmup  
10 ft. probe - 30 min. warmup  
Calibration flow rate = .75 CFM



# POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number \_\_\_\_\_ Date 1/2/93 Meter box number 90-800 Plant \_\_\_\_\_  
 Barometric pressure,  $P_b = 30.36$  in. Hg Dry gas meter number 26940 Pretest  $Y$  \_\_\_\_\_

| Orifice<br>manometer<br>setting,<br>( $\Delta H$ ),<br>in. $H_2O$ | Gas volume                                |                                          | Temperature                                    |                              |                              |                              | Vacuum<br>setting,<br>in. Hg | $Y_i$ | $Y_i$ | $V_w P_b (t_d + 460)$<br>$V_d (P_b + \frac{\Delta H}{13.6})(t_w + 460)$ |                                      |
|-------------------------------------------------------------------|-------------------------------------------|------------------------------------------|------------------------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|-------|-------|-------------------------------------------------------------------------|--------------------------------------|
|                                                                   | Wet test<br>meter<br>( $V_w$ ),<br>$ft^3$ | Dry gas<br>meter<br>( $V_d$ ),<br>$ft^3$ | Wet test<br>meter<br>( $t_w$ ),<br>$^{\circ}F$ | Dry gas meter                |                              | Time<br>( $\theta$ ),<br>min |                              |       |       |                                                                         |                                      |
|                                                                   |                                           |                                          |                                                | Inlet                        |                              |                              |                              |       |       |                                                                         | Average<br>( $t_d$ ),<br>$^{\circ}F$ |
|                                                                   |                                           |                                          |                                                | ( $t_{di}$ ),<br>$^{\circ}F$ | ( $t_{do}$ ),<br>$^{\circ}F$ |                              |                              |       |       |                                                                         |                                      |
| 1.0                                                               | 10                                        | <del>342.145</del><br>352.883            | 640                                            | <del>104</del><br>118        | <del>85</del><br>88          | 98.75                        | 6"                           | .99   | 1.89  |                                                                         |                                      |
| 2.0                                                               | 10                                        | <del>330.616</del><br>341.298            | 640                                            | <del>105</del><br>120        | <del>79</del><br>85          | 99.25                        | 5"                           | .99   | 1.94  |                                                                         |                                      |
| 3.0                                                               | 10                                        | <del>317.841</del><br>328.402            | 640                                            | <del>96</del><br>117         | <del>69</del><br>75          | 89.25                        | 7"                           | .985  | 1.94  |                                                                         |                                      |
|                                                                   |                                           |                                          |                                                |                              |                              |                              |                              | $Y =$ |       |                                                                         |                                      |

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$  where

$V_w$  = Gas volume passing through the wet test meter,  $ft^3$ .

$V_d$  = Gas volume passing through the dry gas meter,  $ft^3$ .

$t_w$  = Temperature of the gas in the wet test meter,  $^{\circ}F$ .

$t_{di}$  = Temperature of the inlet gas of the dry gas meter,  $^{\circ}F$ .

$t_{do}$  = Temperature of the outlet gas of the dry gas meter,  $^{\circ}F$ .

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{di}$  and  $t_{do}$ ,  $^{\circ}F$ .

$\Delta H$  = Pressure differential across orifice, in.  $H_2O$ .

$Y_i$  = Ratio of accuracy of wet test meter to dry gas meter for each run.

$Y$  = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest  $Y \pm 0.05Y$ .

$P_b$  = Barometric pressure, in. Hg.

$\theta$  = Time of calibration run, min.

Quality Assurance Handbook M4-2.4A

# POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number 10.17 Date 11/28 Meter box number Anderson Plant 1009  
 Barometric pressure,  $P_b = 30.18$  in. Hg Dry gas meter number Pretest Y

| Orifice<br>manometer<br>setting,<br>( $\Delta H$ ),<br>in. $H_2O$ | Gas volume                                         |                                                   | Temperature                           |                               |                                |                             | Time<br>( $\theta$ ),<br>min | Vacuum<br>setting,<br>in. Hg | $Y_i$ | $V_w P_b (t_d + 460)$<br>$V_d (P_b + \frac{\Delta H}{13.6})(t_w + 460)$ |
|-------------------------------------------------------------------|----------------------------------------------------|---------------------------------------------------|---------------------------------------|-------------------------------|--------------------------------|-----------------------------|------------------------------|------------------------------|-------|-------------------------------------------------------------------------|
|                                                                   | Wet test<br>meter<br>( $V_w$ ),<br>ft <sup>3</sup> | Dry gas<br>meter<br>( $V_d$ ),<br>ft <sup>3</sup> | Wet test<br>meter<br>( $t_w$ ),<br>°F | Dry gas meter                 |                                | Average<br>( $t_d$ ),<br>°F |                              |                              |       |                                                                         |
|                                                                   |                                                    |                                                   |                                       | Inlet<br>( $t_{d_i}$ ),<br>°F | Outlet<br>( $t_{d_o}$ ),<br>°F |                             |                              |                              |       |                                                                         |
| 10.17 3 D                                                         | 10                                                 | 40.565<br>551.782                                 | 63°                                   | 92°<br>110                    | 85°<br>85                      | 9.5                         | 5                            | .979                         | 1.920 |                                                                         |
| 5.324 .50                                                         | 10                                                 | 551.663<br>551.580                                | 63                                    | 85°<br>94                     | 84°<br>82                      | 8.7                         | 2                            | .981                         | 1.803 |                                                                         |
| 1.5                                                               | 10                                                 | 551.783<br>465.035                                | 63                                    | 93°<br>100                    | 82°<br>86                      | 90.3                        | 3                            | .971                         | 1.833 |                                                                         |
|                                                                   |                                                    |                                                   |                                       |                               |                                |                             |                              | $Y =$                        | 1.852 |                                                                         |

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$  where

$V_w$  = Gas volume passing through the wet test meter, ft<sup>3</sup>.

$V_d$  = Gas volume passing through the dry gas meter, ft<sup>3</sup>.

$t_w$  = Temperature of the gas in the wet test meter, °F.

$t_{d_i}$  = Temperature of the inlet gas of the dry gas meter, °F.

$t_{d_o}$  = Temperature of the outlet gas of the dry gas meter, °F.

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{d_i}$  and  $t_{d_o}$ , °F.

$\Delta H$  = Pressure differential across orifice, in.  $H_2O$ .

$Y_i$  = Ratio of accuracy of wet test meter to dry gas meter for each run.

$Y$  = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest  $Y \pm 0.05Y$ .

$P_b$  = Barometric pressure, in. Hg.

$\theta$  = Time of calibration run, min.

Quality Assurance Handbook M4-2.4A

# POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number \_\_\_\_\_ Date 12-11-92 Meter box number C-185 Plant \_\_\_\_\_  
 Barometric pressure,  $P_b =$  30.10 in. Hg Dry gas meter number 638809 Pretest  $Y$  \_\_\_\_\_

| Orifice<br>manometer<br>setting,<br>( $\Delta H$ ),<br>in. $H_2O$ | Gas volume                                |                                          | Temperature                                    |                                        |                                         |                                      | Time<br>( $\theta$ ),<br>min | Vacuum<br>setting,<br>in. Hg | $Y_i$       | $Y_i$ 543                      |                                                        |
|-------------------------------------------------------------------|-------------------------------------------|------------------------------------------|------------------------------------------------|----------------------------------------|-----------------------------------------|--------------------------------------|------------------------------|------------------------------|-------------|--------------------------------|--------------------------------------------------------|
|                                                                   | Wet test<br>meter<br>( $V_w$ ),<br>$ft^3$ | Dry gas<br>meter<br>( $V_d$ ),<br>$ft^3$ | Wet test<br>meter<br>( $t_w$ ),<br>$^{\circ}F$ | Dry gas meter                          |                                         |                                      |                              |                              |             | $V_w P_b (t_d + 460)$<br>541.5 | $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$<br>526 |
|                                                                   |                                           |                                          |                                                | Inlet<br>( $t_{d_i}$ ),<br>$^{\circ}F$ | Outlet<br>( $t_{d_o}$ ),<br>$^{\circ}F$ | Average<br>( $t_d$ ),<br>$^{\circ}F$ |                              |                              |             |                                |                                                        |
| 1.50                                                              | 10.25                                     | 862.314<br>461.419                       | 66                                             | 90<br>93                               | 70<br>71                                | 81                                   | 11.98                        | 1                            | 1.006       | 1.546                          |                                                        |
| 1                                                                 | 10                                        | 868.162<br>461.387                       | 66                                             | 93<br>96                               | 72<br>72                                | 83                                   | 16.9                         | 3                            | 1.007       | 1.532                          |                                                        |
| 3                                                                 | 10                                        | 852.030<br>461.022                       | 66                                             | 90<br>98                               | 68<br>70                                | 81.5                                 | 9.65                         | 6                            | 1.023       | 1.503                          |                                                        |
|                                                                   |                                           |                                          |                                                |                                        |                                         |                                      |                              |                              | $Y = 1.012$ | 1.527                          |                                                        |

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$  where

$V_w$  = Gas volume passing through the wet test meter,  $ft^3$ .

$V_d$  = Gas volume passing through the dry gas meter,  $ft^3$ .

$t_w$  = Temperature of the gas in the wet test meter,  $^{\circ}F$ .

$t_{di}$  = Temperature of the inlet gas of the dry gas meter,  $^{\circ}F$ .

$t_{do}$  = Temperature of the outlet gas of the dry gas meter,  $^{\circ}F$ .

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{di}$  and  $t_{do}$ ,  $^{\circ}F$ .

$\Delta H$  = Pressure differential across orifice, in.  $H_2O$ .

$Y_i$  = Ratio of accuracy of wet test meter to dry gas meter for each run.

$Y$  = Average ratio of accuracy of wet test meter to dry gas meter for all three runs;  
 tolerance = pretest  $Y \pm 0.05Y$ .

$P_b$  = Barometric pressure, in. Hg.

$\theta$  = Time of calibration run, min.

Quality Assurance Handbook M4-2.4A



## POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number 11-2352 Date 11-23-52 Meter box number C-185 Plant Pretest Y  
 Barometric pressure,  $P_b = 29.90$  in. Hg Dry gas meter number 658805

| Orifice<br>manometer<br>Setting,<br>( $\Delta H$ ),<br>in. $H_2O$ | Gas volume                                |                                          | Temperature                                    |                                        |                                         |                                      |                                      | Time<br>( $\Theta$ ),<br>min | Vacuum<br>setting,<br>in. Hg | $Y_i$ | $Y_i$ 539<br>$V_w P_b (t_d + 460)$<br>$V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$ |
|-------------------------------------------------------------------|-------------------------------------------|------------------------------------------|------------------------------------------------|----------------------------------------|-----------------------------------------|--------------------------------------|--------------------------------------|------------------------------|------------------------------|-------|---------------------------------------------------------------------------------------|
|                                                                   | Wet test<br>meter<br>( $V_w$ ),<br>$ft^3$ | Dry gas<br>meter<br>( $V_d$ ),<br>$ft^3$ | Wet test<br>meter<br>( $t_w$ ),<br>$^{\circ}F$ | Dry gas meter                          |                                         |                                      | Average<br>( $t_d$ ),<br>$^{\circ}F$ |                              |                              |       |                                                                                       |
|                                                                   |                                           |                                          |                                                | Inlet<br>( $t_{d_i}$ ),<br>$^{\circ}F$ | Outlet<br>( $t_{d_o}$ ),<br>$^{\circ}F$ | Average<br>( $t_d$ ),<br>$^{\circ}F$ |                                      |                              |                              |       |                                                                                       |
|                                                                   |                                           |                                          |                                                |                                        |                                         |                                      |                                      |                              |                              |       |                                                                                       |
| 5.15                                                              | 10.5                                      | 514.442<br>514.601                       | 65                                             | 92                                     | 70                                      | 81                                   | 12.0                                 | 2                            | 997                          | 1.555 |                                                                                       |
| 10.363                                                            | 10                                        | 514.532<br>514.595                       | 65                                             | 88                                     | 70                                      | 79                                   | 16.75                                | 4                            | 988                          | 1.515 |                                                                                       |
| 10.27                                                             | 3.0                                       | 514.528<br>514.591                       | 65                                             | 88                                     | 70                                      | 81                                   | 9.7                                  | 7                            | 996                          | 1.524 |                                                                                       |
|                                                                   |                                           |                                          |                                                |                                        |                                         |                                      |                                      |                              | $Y = 994$                    | 1.531 |                                                                                       |

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$  where

$V_w$  = Gas volume passing through the wet test meter,  $ft^3$ .

$V_d$  = Gas volume passing through the dry gas meter,  $ft^3$ .

$t_w$  = Temperature of the gas in the wet test meter,  $^{\circ}F$ .

$t_{d_i}$  = Temperature of the inlet gas of the dry gas meter,  $^{\circ}F$ .

$t_{d_o}$  = Temperature of the outlet gas of the dry gas meter,  $^{\circ}F$ .

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{d_i}$  and  $t_{d_o}$ ,  $^{\circ}F$ .

$\Delta H$  = Pressure differential across orifice, in.  $H_2O$ .

$Y_i$  = Ratio of accuracy of wet test meter to dry gas meter for each run.

$Y$  = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest  $Y \pm 0.05Y$ .

$P_b$  = Barometric pressure, in. Hg.

$\theta$  = Time of calibration run, min.

## **IX. FIELD DATA**

### **A. CEMS**



| Line | Frequency (MHz) | Power (dBm) | Modulation | Bandwidth (MHz) | Symbol Rate (baud) | Guard Band (MHz) | Interference (dBm) | SNR (dB) | BER  | Notes            |
|------|-----------------|-------------|------------|-----------------|--------------------|------------------|--------------------|----------|------|------------------|
| 1    | 100.0           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 2    | 100.1           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 3    | 100.2           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 4    | 100.3           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 5    | 100.4           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 6    | 100.5           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 7    | 100.6           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 8    | 100.7           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 9    | 100.8           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 10   | 100.9           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 11   | 101.0           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 12   | 101.1           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 13   | 101.2           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 14   | 101.3           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 15   | 101.4           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 16   | 101.5           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 17   | 101.6           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 18   | 101.7           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 19   | 101.8           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 20   | 101.9           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 21   | 102.0           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 22   | 102.1           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 23   | 102.2           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 24   | 102.3           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 25   | 102.4           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 26   | 102.5           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 27   | 102.6           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 28   | 102.7           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 29   | 102.8           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 30   | 102.9           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 31   | 103.0           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 32   | 103.1           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 33   | 103.2           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 34   | 103.3           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 35   | 103.4           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 36   | 103.5           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 | Normal operation |
| 37   | 103.6           | 10.0        | QPSK       | 1.0             | 1000               | 0.1              | -100               | 20       | 1e-6 |                  |





| Line | Altitude | Time  | Pressure | Temperature | Humidity | Wind | Clouds | Visibility | Remarks |
|------|----------|-------|----------|-------------|----------|------|--------|------------|---------|
| 1    | 1000     | 10:00 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 2    | 1000     | 10:05 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 3    | 1000     | 10:10 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 4    | 1000     | 10:15 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 5    | 1000     | 10:20 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 6    | 1000     | 10:25 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 7    | 1000     | 10:30 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 8    | 1000     | 10:35 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 9    | 1000     | 10:40 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 10   | 1000     | 10:45 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 11   | 1000     | 10:50 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 12   | 1000     | 10:55 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 13   | 1000     | 11:00 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 14   | 1000     | 11:05 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 15   | 1000     | 11:10 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 16   | 1000     | 11:15 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 17   | 1000     | 11:20 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 18   | 1000     | 11:25 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 19   | 1000     | 11:30 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 20   | 1000     | 11:35 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 21   | 1000     | 11:40 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 22   | 1000     | 11:45 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 23   | 1000     | 11:50 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 24   | 1000     | 11:55 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |
| 25   | 1000     | 12:00 | 1013.5   | 13.1        | 70       | 10   | 0      | 10         | Clear   |

[illegible]





| Wavenumber (cm <sup>-1</sup> ) | Assignment | Frequency (cm <sup>-1</sup> ) | Intensity | Wavenumber (cm <sup>-1</sup> ) | Assignment | Frequency (cm <sup>-1</sup> ) | Intensity |
|--------------------------------|------------|-------------------------------|-----------|--------------------------------|------------|-------------------------------|-----------|
| 34.73                          | OH         | 34.73                         | 3         | 29.79                          | CH         | 29.79                         | 3         |
| 31.5                           | CH         | 31.5                          | 3         | 29.11                          | CH         | 29.11                         | 3         |
| 14.46                          | CH         | 14.46                         | 3         | 29.0                           | CH         | 29.0                          | 3         |
| 13.65                          | CH         | 13.65                         | 3         | 28.9                           | CH         | 28.9                          | 3         |
| 13.5                           | CH         | 13.5                          | 3         | 28.8                           | CH         | 28.8                          | 3         |
| 13.43                          | CH         | 13.43                         | 3         | 28.7                           | CH         | 28.7                          | 3         |
| 13.39                          | CH         | 13.39                         | 3         | 28.6                           | CH         | 28.6                          | 3         |
| 13.3                           | CH         | 13.3                          | 3         | 28.5                           | CH         | 28.5                          | 3         |
| 13.2                           | CH         | 13.2                          | 3         | 28.4                           | CH         | 28.4                          | 3         |
| 13.1                           | CH         | 13.1                          | 3         | 28.3                           | CH         | 28.3                          | 3         |
| 13.0                           | CH         | 13.0                          | 3         | 28.2                           | CH         | 28.2                          | 3         |
| 12.9                           | CH         | 12.9                          | 3         | 28.1                           | CH         | 28.1                          | 3         |
| 12.8                           | CH         | 12.8                          | 3         | 28.0                           | CH         | 28.0                          | 3         |
| 12.7                           | CH         | 12.7                          | 3         | 27.9                           | CH         | 27.9                          | 3         |
| 12.6                           | CH         | 12.6                          | 3         | 27.8                           | CH         | 27.8                          | 3         |
| 12.5                           | CH         | 12.5                          | 3         | 27.7                           | CH         | 27.7                          | 3         |
| 12.4                           | CH         | 12.4                          | 3         | 27.6                           | CH         | 27.6                          | 3         |
| 12.3                           | CH         | 12.3                          | 3         | 27.5                           | CH         | 27.5                          | 3         |
| 12.2                           | CH         | 12.2                          | 3         | 27.4                           | CH         | 27.4                          | 3         |
| 12.1                           | CH         | 12.1                          | 3         | 27.3                           | CH         | 27.3                          | 3         |
| 12.0                           | CH         | 12.0                          | 3         | 27.2                           | CH         | 27.2                          | 3         |
| 11.9                           | CH         | 11.9                          | 3         | 27.1                           | CH         | 27.1                          | 3         |
| 11.8                           | CH         | 11.8                          | 3         | 27.0                           | CH         | 27.0                          | 3         |
| 11.7                           | CH         | 11.7                          | 3         | 26.9                           | CH         | 26.9                          | 3         |
| 11.6                           | CH         | 11.6                          | 3         | 26.8                           | CH         | 26.8                          | 3         |
| 11.5                           | CH         | 11.5                          | 3         | 26.7                           | CH         | 26.7                          | 3         |
| 11.4                           | CH         | 11.4                          | 3         | 26.6                           | CH         | 26.6                          | 3         |
| 11.3                           | CH         | 11.3                          | 3         | 26.5                           | CH         | 26.5                          | 3         |
| 11.2                           | CH         | 11.2                          | 3         | 26.4                           | CH         | 26.4                          | 3         |
| 11.1                           | CH         | 11.1                          | 3         | 26.3                           | CH         | 26.3                          | 3         |
| 11.0                           | CH         | 11.0                          | 3         | 26.2                           | CH         | 26.2                          | 3         |
| 10.9                           | CH         | 10.9                          | 3         | 26.1                           | CH         | 26.1                          | 3         |
| 10.8                           | CH         | 10.8                          | 3         | 26.0                           | CH         | 26.0                          | 3         |
| 10.7                           | CH         | 10.7                          | 3         | 25.9                           | CH         | 25.9                          | 3         |
| 10.6                           | CH         | 10.6                          | 3         | 25.8                           | CH         | 25.8                          | 3         |
| 10.5                           | CH         | 10.5                          | 3         | 25.7                           | CH         | 25.7                          | 3         |
| 10.4                           | CH         | 10.4                          | 3         | 25.6                           | CH         | 25.6                          | 3         |
| 10.3                           | CH         | 10.3                          | 3         | 25.5                           | CH         | 25.5                          | 3         |
| 10.2                           | CH         | 10.2                          | 3         | 25.4                           | CH         | 25.4                          | 3         |
| 10.1                           | CH         | 10.1                          | 3         | 25.3                           | CH         | 25.3                          | 3         |
| 10.0                           | CH         | 10.0                          | 3         | 25.2                           | CH         | 25.2                          | 3         |
| 9.9                            | CH         | 9.9                           | 3         | 25.1                           | CH         | 25.1                          | 3         |
| 9.8                            | CH         | 9.8                           | 3         | 25.0                           | CH         | 25.0                          | 3         |
| 9.7                            | CH         | 9.7                           | 3         | 24.9                           | CH         | 24.9                          | 3         |
| 9.6                            | CH         | 9.6                           | 3         | 24.8                           | CH         | 24.8                          | 3         |
| 9.5                            | CH         | 9.5                           | 3         | 24.7                           | CH         | 24.7                          | 3         |
| 9.4                            | CH         | 9.4                           | 3         | 24.6                           | CH         | 24.6                          | 3         |
| 9.3                            | CH         | 9.3                           | 3         | 24.5                           | CH         | 24.5                          | 3         |
| 9.2                            | CH         | 9.2                           | 3         | 24.4                           | CH         | 24.4                          | 3         |
| 9.1                            | CH         | 9.1                           | 3         | 24.3                           | CH         | 24.3                          | 3         |
| 9.0                            | CH         | 9.0                           | 3         | 24.2                           | CH         | 24.2                          | 3         |
| 8.9                            | CH         | 8.9                           | 3         | 24.1                           | CH         | 24.1                          | 3         |
| 8.8                            | CH         | 8.8                           | 3         | 24.0                           | CH         | 24.0                          | 3         |
| 8.7                            |            |                               |           |                                |            |                               |           |

[illegible]

[illegible]



| STATION | DATE     | TIME  | COORD  | DEPTH | WAVE | PERIOD | AMPLITUDE | PHASE | WAVELENGTH | VELOCITY | ACCELERATION | STATION | DATE | TIME     | COORD | DEPTH  | WAVE  | PERIOD | AMPLITUDE | PHASE | WAVELENGTH | VELOCITY | ACCELERATION |    |    |     |
|---------|----------|-------|--------|-------|------|--------|-----------|-------|------------|----------|--------------|---------|------|----------|-------|--------|-------|--------|-----------|-------|------------|----------|--------------|----|----|-----|
| 1       | 12/01/92 | 12:34 | 1704.2 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1704.2 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 2       | 12/01/92 | 12:34 | 1691.2 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1691.2 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 3       | 12/01/92 | 12:34 | 1684.5 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1684.5 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 4       | 12/01/92 | 12:34 | 1677.8 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1677.8 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 5       | 12/01/92 | 12:34 | 1671.1 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1671.1 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 6       | 12/01/92 | 12:34 | 1664.4 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1664.4 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 7       | 12/01/92 | 12:34 | 1657.7 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1657.7 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 8       | 12/01/92 | 12:34 | 1651.0 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1651.0 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 9       | 12/01/92 | 12:34 | 1644.3 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1644.3 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 10      | 12/01/92 | 12:34 | 1637.6 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1637.6 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 11      | 12/01/92 | 12:34 | 1630.9 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1630.9 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 12      | 12/01/92 | 12:34 | 1624.2 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1624.2 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 13      | 12/01/92 | 12:34 | 1617.5 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1617.5 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 14      | 12/01/92 | 12:34 | 1610.8 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1610.8 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 15      | 12/01/92 | 12:34 | 1604.1 | 46.34 | 120  | 30     | 40        | 50    | 60         | 70       | 80           | 90      | 100  | 12/01/92 | 12:34 | 1604.1 | 46.34 | 120    | 30        | 40    | 50         | 60       | 70           | 80 | 90 | 100 |
| 16      |          |       |        |       |      |        |           |       |            |          |              |         |      |          |       |        |       |        |           |       |            |          |              |    |    |     |

[illegible]



| Time       | Frequency | Power | Modulation | Bandwidth | SNR   | BER  | QoS |
|------------|-----------|-------|------------|-----------|-------|------|-----|
| 10:00:00   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:01   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:02   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:03   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:04   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:05   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:06   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:07   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:08   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:09   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:10   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:11   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:12   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:13   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:14   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:15   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:16   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:17   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:18   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:19   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:20   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:21   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:22   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:23   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:24   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:25   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:26   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:27   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:28   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:29   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:30   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:31   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:32   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:33   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:34   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:35   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:36   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:37   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:38   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:39   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:40   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:41   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:42   | 100.000   | 10.00 | QPSK       | 100       | 10.00 | 0.00 | 100 |
| 10:00:43</ |           |       |            |           |       |      |     |







|   |                 |     |    |    |      |     |     |    |      |     |     |
|---|-----------------|-----|----|----|------|-----|-----|----|------|-----|-----|
| 4 | 1516.4          | FRM | CO | 5  | 11.4 | %   | Q2  | 6  | 87.8 | PPM | NOX |
| 1 | 59.9            | PPM | HC | 2  | 9.5  | PPM | S02 | 3  | 7.4  | %   | CO2 |
| 4 | 1516.4          | FRM | CO | 3  | 11.5 | %   | Q2  | 4  | 86.1 | PPM | NOX |
| 1 | 58.9            | PPM | HC | 4  | 8.5  | PPM | S02 | 5  | 7.3  | %   | CO2 |
| 5 | DEC 92 14 36 38 |     |    | 5  | 11.7 | %   | Q2  | 6  | 84.5 | PPM | NOX |
| 1 | 58.9            | PPM | HC | 6  | 5.9  | PPM | S02 | 7  | 7.2  | %   | CO2 |
| 4 | 1516.4          | FRM | CO | 7  | 11.3 | %   | Q2  | 8  | 81.8 | PPM | NOX |
| 1 | 51.8            | PPM | HC | 8  | 6.8  | PPM | S02 | 9  | 7.1  | %   | CO2 |
| 5 | DEC 92 14 34 38 |     |    | 9  | 11.5 | %   | Q2  | 10 | 79.9 | PPM | NOX |
| 1 | 52.14           | PPM | HC | 10 | 6.9  | PPM | S02 | 11 | 78.1 | PPM | NOX |
| 4 | 1516.4          | FRM | CO | 11 | 11.3 | %   | Q2  | 12 | 76.5 | PPM | NOX |
| 1 | 52.15           | PPM | HC | 12 | 8.2  | PPM | S02 | 13 | 74.8 | %   | CO2 |
| 5 | DEC 92 14 33 38 |     |    | 13 | 11.3 | %   | Q2  | 14 | 73.1 | PPM | NOX |
| 4 | 1502.5          | PPM | CO | 14 | 8.2  | PPM | S02 | 15 | 71.8 | %   | CO2 |
| 1 | 52.7            | PPM | HC | 15 | 11.3 | %   | Q2  | 16 | 69.9 | %   | CO2 |
| 5 | DEC 92 14 32 38 |     |    | 16 | 6.9  | PPM | S02 | 17 | 68.1 | PPM | NOX |
| 4 | 1592.1          | PPM | CO | 17 | 6.9  | PPM | S02 | 18 | 66.5 | PPM | NOX |
| 1 | 55.13           | PPM | HC | 18 | 6.9  | PPM | S02 | 19 | 64.9 | PPM | NOX |
| 5 | DEC 92 14 31 38 |     |    | 19 | 12.4 | %   | Q2  | 20 | 63.9 | PPM | NOX |
| 1 | 56.5            | PPM | HC | 20 | 8.2  | PPM | S02 | 21 | 62.1 | %   | CO2 |
| 4 | 157.5           | PPM | CO | 21 | 12.4 | %   | Q2  | 22 | 60.5 | PPM | NOX |
| 1 | 57.5            | PPM | HC | 22 | 8.2  | PPM | S02 | 23 | 58.9 | PPM | NOX |
| 5 | DEC 92 14 30 38 |     |    | 23 | 12.4 | %   | Q2  | 24 | 57.8 | PPM | NOX |
| 4 | 1582.1          | PPM | CO | 24 | 8.2  | PPM | S02 | 25 | 56.1 | PPM | NOX |
| 1 | 58.13           | PPM | HC | 25 | 12.4 | %   | Q2  | 26 | 54.5 | PPM | NOX |
| 5 | DEC 92 14 29 38 |     |    | 26 | 8.2  | PPM | S02 | 27 | 52.9 | PPM | NOX |
| 4 | 1581.9          | PPM | CO | 27 | 12.4 | %   | Q2  | 28 | 51.7 | PPM | NOX |
| 1 | 58.8            | PPM | HC | 28 | 8.2  | PPM | S02 | 29 | 50.4 | PPM | NOX |
| 5 | DEC 92 14 28 38 |     |    | 29 | 12.2 | %   | Q2  | 30 | 49.7 | PPM | NOX |
| 4 | 1515.5          | PPM | CO | 30 | 8.9  | PPM | S02 | 31 | 48.1 | PPM | NOX |
| 1 | 53.5            | PPM | HC | 31 | 12.2 | %   | Q2  | 32 | 46.7 | PPM | NOX |
| 5 | DEC 92 14 27 38 |     |    | 32 | 8.9  | PPM | S02 | 33 | 45.1 | PPM | NOX |
| 4 | 1516.4          | PPM | CO | 33 | 11.4 | %   | Q2  | 34 | 43.9 | PPM | NOX |
| 1 | 59.9            | PPM | HC | 34 | 9.5  | PPM | S02 | 35 | 42.9 | PPM | NOX |
| 5 | DEC 92 14 26 38 |     |    | 35 | 11.5 | %   | Q2  | 36 | 41.8 | PPM | NOX |
| 4 | 1516.4          | PPM | CO | 36 | 8.5  | PPM | S02 | 37 | 40.5 | PPM | NOX |
| 1 | 58.9            | PPM | HC | 37 | 11.7 | %   | Q2  | 38 | 39.9 | PPM | NOX |
| 5 | DEC 92 14 25 38 |     |    | 38 | 8.5  | PPM | S02 | 39 | 38.1 | PPM | NOX |
| 4 | 1516.4          | PPM | CO | 39 | 11.3 | %   | Q2  | 40 | 36.5 | PPM | NOX |
| 1 | 51.8            | PPM | HC | 40 | 6.8  | PPM | S02 | 41 | 34.9 | PPM | NOX |
| 5 | DEC 92 14 24 38 |     |    | 41 | 11.5 | %   | Q2  | 42 | 33.9 | PPM | NOX |
| 4 | 1514.5          | PPM | CO | 42 | 8.2  | PPM | S02 | 43 | 32.1 | PPM | NOX |
| 1 | 52.15           | PPM | HC | 43 | 11.3 | %   | Q2  | 44 | 30.9 | PPM | NOX |
| 5 | DEC 92 14 23 38 |     |    | 44 | 8    |     |     |    |      |     |     |

|     |        |          |     |          |          |     |          |          |     |     |   |
|-----|--------|----------|-----|----------|----------|-----|----------|----------|-----|-----|---|
| 4   | 1917.2 | PPM      | 00  | 5 = 11.5 | %        | 02  | 6 = 83.0 | PPM      | NOX | 1   |   |
| 1   | 59.7   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.9  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 51 33 |     |          |          |     |          |          |     |     |   |
| 4   | 1912.5 | PPM      | 00  | 5 = 11.5 | %        | 02  | 6 = 84.5 | PPM      | NOX | 1   |   |
| 1   | 57.4   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 100 | DEC/92 | 14 53 38 | 80  | 70       | 60       | 50  | 40       | 30       | 20  | 10  |   |
| 0   | 4      | 1512.4   | PPM | 00       | 5 = 11.4 | %   | 02       | 6 = 79.2 | PPM | NOX | 1 |
| 1   | 58.8   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 45 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1515.0 | PPM      | 00  | 5 = 11.4 | %        | 02  | 6 = 80.9 | PPM      | NOX | 1   |   |
| 1   | 54.4   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 43 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1927.0 | PPM      | 00  | 5 = 11.4 | %        | 02  | 6 = 80.3 | PPM      | NOX | 1   |   |
| 1   | 55.7   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 47 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1922.5 | PPM      | 00  | 5 = 11.4 | %        | 02  | 6 = 83.1 | PPM      | NOX | 1   |   |
| 1   | 57.6   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 48 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1921.5 | PPM      | 00  | 5 = 11.4 | %        | 02  | 6 = 82.7 | PPM      | NOX | 1   |   |
| 1   | 56.7   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 48 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1923.3 | PPM      | 00  | 5 = 11.5 | %        | 02  | 6 = 81.8 | PPM      | NOX | 1   |   |
| 1   | 71.0   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 44 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1922.5 | PPM      | 00  | 5 = 11.5 | %        | 02  | 6 = 80.6 | PPM      | NOX | 1   |   |
| 1   | 53.6   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 43 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1925.5 | PPM      | 00  | 5 = 11.5 | %        | 02  | 6 = 80.9 | PPM      | NOX | 1   |   |
| 1   | 75.9   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 42 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1922.5 | PPM      | 00  | 5 = 11.5 | %        | 02  | 6 = 79.1 | PPM      | NOX | 1   |   |
| 1   | 38.6   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.3  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 41 38 |     |          |          |     |          |          |     |     |   |
| 4   | 1924.8 | PPM      | 00  | 5 = 11.4 | %        | 02  | 6 = 81.5 | PPM      | NOX | 1   |   |
| 1   | 71.9   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.4  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 43 38 |     |          |          |     |          |          |     |     |   |
| 0   | 4      | 1921.0   | PPM | 00       | 5 = 11.4 | %   | 02       | 6 = 80.3 | PPM | NOX | 1 |
| 1   | 55.1   | PPM      | HO  | 2 = 0.0  | PPM      | 302 | 3 = 7.5  | %        | 002 | 1   |   |
| 9   | DEC/92 | 14 40 38 |     |          |          |     |          |          |     |     |   |

[illegible]



| Time | Lat  | Long | Alt   | Speed | Heading | Roll | Pitch | Yaw | Roll Rate | Pitch Rate | Yaw Rate | Roll Acc | Pitch Acc | Yaw Acc |
|------|------|------|-------|-------|---------|------|-------|-----|-----------|------------|----------|----------|-----------|---------|
| 1    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 2    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 3    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 4    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 5    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 6    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 7    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 8    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 9    | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 10   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 11   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 12   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 13   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 14   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 15   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 16   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 17   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 18   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 19   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 20   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 21   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 22   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 23   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 24   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 25   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 26   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 27   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     | 0.0  | 0.0   | 0.0 | 0.0       | 0.0        | 0.0      | 0.0      | 0.0       | 0.0     |
| 28   | 32.1 | 15.3 | 37.33 | 0.0   | 0.0     |      |       |     |           |            |          |          |           |         |




|     |        |          |    |   |       |   |     |     |   |      |   |     |     |    |
|-----|--------|----------|----|---|-------|---|-----|-----|---|------|---|-----|-----|----|
| 1   | 5614   | PPM      | HO | 3 | 15.9  | % | PPM | SO2 | 3 | 8.12 | % | PPM | NOX | 10 |
| 2   | DEC 92 | 15 38    | CO | 5 | 10.2  | % | PPM | CO2 | 6 | 33.1 | % | PPM | NOX | 10 |
| 3   | 1884   | PPM      | HO | 3 | 8.5   | % | PPM | SO2 | 3 | 8.1  | % | PPM | NOX | 10 |
| 4   | DEC 92 | 16 18 38 | CO | 5 | 15.2  | % | PPM | CO2 | 6 | 32.7 | % | PPM | NOX | 10 |
| 5   | 1897   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 8.1  | % | PPM | NOX | 10 |
| 6   | DEC 92 | 16 17 38 | CO | 5 | 13.2  | % | PPM | CO2 | 6 | 32.5 | % | PPM | NOX | 10 |
| 7   | 1895   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 8.1  | % | PPM | NOX | 10 |
| 8   | DEC 92 | 16 16 38 | CO | 5 | 13.3  | % | PPM | CO2 | 6 | 32.3 | % | PPM | NOX | 10 |
| 9   | 1897   | PPM      | HO | 3 | 8.5   | % | PPM | SO2 | 3 | 8.0  | % | PPM | NOX | 10 |
| 10  | DEC 92 | 16 15 38 | CO | 5 | 10.5  | % | PPM | CO2 | 6 | 31.8 | % | PPM | NOX | 10 |
| 11  | 1887   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.5  | % | PPM | NOX | 10 |
| 12  | DEC 92 | 16 14 38 | CO | 5 | 15.7  | % | PPM | CO2 | 6 | 32.8 | % | PPM | NOX | 10 |
| 13  | 1895   | PPM      | HO | 3 | 8.8   | % | PPM | SO2 | 3 | 7.7  | % | PPM | NOX | 10 |
| 14  | DEC 92 | 16 13 38 | CO | 5 | 11.68 | % | PPM | CO2 | 6 | 30.7 | % | PPM | NOX | 10 |
| 15  | 1891   | PPM      | HO | 3 | 11.4  | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 16  | DEC 92 | 16 12 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.4 | % | PPM | NOX | 10 |
| 17  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 18  | DEC 92 | 16 11 38 | CO | 5 | 11.3  | % | PPM | CO2 | 6 | 30.2 | % | PPM | NOX | 10 |
| 19  | 1894   | PPM      | HO | 3 | 8.8   | % | PPM | SO2 | 3 | 7.2  | % | PPM | NOX | 10 |
| 20  | DEC 92 | 16 10 38 | CO | 5 | 11.3  | % | PPM | CO2 | 6 | 30.1 | % | PPM | NOX | 10 |
| 21  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 22  | DEC 92 | 16 9 38  | CO | 5 | 11.3  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 23  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 24  | DEC 92 | 16 8 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 25  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 26  | DEC 92 | 16 7 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 27  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 28  | DEC 92 | 16 6 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 29  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 30  | DEC 92 | 16 5 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 31  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 32  | DEC 92 | 16 4 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 33  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 34  | DEC 92 | 16 3 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 35  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 36  | DEC 92 | 16 2 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 37  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 38  | DEC 92 | 16 1 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 39  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 40  | DEC 92 | 16 0 38  | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 41  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 42  | DEC 92 | 15 59 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 43  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 44  | DEC 92 | 15 58 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 45  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 46  | DEC 92 | 15 57 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 47  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 48  | DEC 92 | 15 56 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 49  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 50  | DEC 92 | 15 55 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 51  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 52  | DEC 92 | 15 54 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 53  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 54  | DEC 92 | 15 53 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 55  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 56  | DEC 92 | 15 52 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 57  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 58  | DEC 92 | 15 51 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 59  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 60  | DEC 92 | 15 50 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 61  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 62  | DEC 92 | 15 49 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 63  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 64  | DEC 92 | 15 48 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 65  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 66  | DEC 92 | 15 47 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 67  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 68  | DEC 92 | 15 46 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 69  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 70  | DEC 92 | 15 45 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 71  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 72  | DEC 92 | 15 44 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 73  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 74  | DEC 92 | 15 43 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 75  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 76  | DEC 92 | 15 42 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 77  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 78  | DEC 92 | 15 41 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 79  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 80  | DEC 92 | 15 40 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 81  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 82  | DEC 92 | 15 39 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 83  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 84  | DEC 92 | 15 38 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 85  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 86  | DEC 92 | 15 37 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 87  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 88  | DEC 92 | 15 36 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 89  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 90  | DEC 92 | 15 35 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 91  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 92  | DEC 92 | 15 34 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 93  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 94  | DEC 92 | 15 33 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 95  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 96  | DEC 92 | 15 32 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 97  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 98  | DEC 92 | 15 31 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 99  | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 100 | DEC 92 | 15 30 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 101 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 102 | DEC 92 | 15 29 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 103 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 104 | DEC 92 | 15 28 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 105 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 106 | DEC 92 | 15 27 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 107 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 108 | DEC 92 | 15 26 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 109 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 110 | DEC 92 | 15 25 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 111 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 | 3 | 7.1  | % | PPM | NOX | 10 |
| 112 | DEC 92 | 15 24 38 | CO | 5 | 11.4  | % | PPM | CO2 | 6 | 30.0 | % | PPM | NOX | 10 |
| 113 | 1892   | PPM      | HO | 3 | 8.0   | % | PPM | SO2 |   |      |   |     |     |    |




|     |                 |    |   |      |     |     |     |     |     |
|-----|-----------------|----|---|------|-----|-----|-----|-----|-----|
| 4   | DEC 92 15 33 38 | CO | 5 | 15.5 | %   | Q2  | 30  | 90  | NO  |
| 100 | 79.7 90         | HC | 3 | 5.80 | PPM | 502 | 40  | 50  | 100 |
| 0   | DEC 92 15 32 38 | CO | 5 | 10.5 | %   | Q2  | 60  | 70  | 100 |
| 4   | DEC 92 15 32 38 | CO | 3 | 0.0  | PPM | 502 | 70  | 80  | 100 |
| 1   | DEC 92 15 31 38 | HC | 3 | 8.1  | PPM | 502 | 80  | 90  | 100 |
| 5   | DEC 92 15 31 38 | CO | 3 | 8.1  | PPM | 502 | 90  | 100 | 100 |
| 4   | DEC 92 15 31 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 30 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 30 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 29 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 28 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 28 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 27 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 27 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 26 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 26 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 25 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 25 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 24 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 23 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 23 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 22 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 21 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 21 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 20 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 19 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 18 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 17 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 16 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 15 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 14 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 13 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 12 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 11 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 10 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 09 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 08 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 07 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 06 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 05 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 04 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 03 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 4   | DEC 92 15 02 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 1   | DEC 92 15 01 38 | HC | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |
| 5   | DEC 92 15 00 38 | CO | 3 | 8.1  | PPM | 502 | 100 | 100 | 100 |

[illegible]









|   |        |    |    |    |     |    |          |     |     |          |     |    |    |     |
|---|--------|----|----|----|-----|----|----------|-----|-----|----------|-----|----|----|-----|
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 12.2 | %   | 02  | 5 = 69.8 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 7.0  | PPM | 302 | 3 = 7.6  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 3 = 11.7 | %   | 02  | 6 = 74.5 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 7.1  | PPM | 302 | 3 = 7.3  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.5 | %   | 02  | 6 = 74.5 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 3 = 7.2  | PPM | 302 | 3 = 7.4  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 3 = 11.3 | %   | 02  | 6 = 77.5 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 3 = 7.2  | PPM | 302 | 3 = 7.6  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.3 | %   | 02  | 6 = 77.3 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.8  | PPM | 302 | 3 = 30.6 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 3 = 11.4 | %   | 02  | 6 = 70.2 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 7.1  | PPM | 302 | 3 = 7.5  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.2 | %   | 02  | 6 = 84.9 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.7  | PPM | 302 | 3 = 7.7  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.3 | %   | 02  | 6 = 85.4 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.4  | PPM | 302 | 3 = 7.5  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.3 | %   | 02  | 6 = 84.9 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.3  | PPM | 302 | 3 = 7.6  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.3 | %   | 02  | 6 = 84.2 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.5  | PPM | 302 | 3 = 7.6  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.3 | %   | 02  | 6 = 82.5 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 7.3  | PPM | 302 | 3 = 7.5  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.3 | %   | 02  | 6 = 82.3 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.7  | PPM | 302 | 3 = 7.4  | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 5 = 11.4 | %   | 02  | 6 = 81.0 | PPM | NO | 90 | 100 |
| 1 | DEC/92 | 15 | 56 | 26 | PPM | NO | 2 = 6.2  | PPM | 302 | 3 = 7.3  | PPM | NO | 90 | 100 |

[illegible]

[illegible]





| Time                | Frequency | Power | Modulation | Bandwidth | SNR  | BER | QoS | Notes |
|---------------------|-----------|-------|------------|-----------|------|-----|-----|-------|
| 14:49:54            | 1702.4    | 11.5  | PPM        | 302       | 80.7 | 1%  | NO  |       |
| 1 = 61.4            | PPM       | 4.7   | PPM        | 302       | 71.2 | 1%  | DO3 |       |
| 7/DEC/92 14:48:13   | 1282.9    | 12.5  | PPM        | 302       | 75.1 | 1%  | NO  |       |
| 1 = 89.5            | PPM       | 4.7   | PPM        | 302       | 61.1 | 1%  | DO2 |       |
| 7/DEC/92 15:21:13   |           |       |            |           |      |     |     |       |
| RESTART             |           |       |            |           |      |     |     |       |
| INTERUPT            |           |       |            |           |      |     |     |       |
| 4 = 1702.4          | PPM       | 12.5  | PPM        | 302       | 61.8 | 1%  | NO  |       |
| 1 = 155.8           | PPM       | 7.3   | PPM        | 302       | 71.1 | 1%  | DO2 |       |
| 7/DEC/92 15:08:33   |           |       |            |           |      |     |     |       |
| 4 = 1719.1          | PPM       | 12.1  | PPM        | 302       | 76.2 | 1%  | NO  |       |
| 1 = 88.4            | PPM       | 7.5   | PPM        | 302       | 71.1 | 1%  | DO2 |       |
| 7/DEC/92 15:09:33   |           |       |            |           |      |     |     |       |
| 4 = 1715.3          | PPM       | 12.3  | PPM        | 302       | 77.1 | 1%  | NO  |       |
| 1 = 86.7            | PPM       | 7.5   | PPM        | 302       | 71.2 | 1%  | DO2 |       |
| 7/DEC/92 15:09:33   |           |       |            |           |      |     |     |       |
| 4 = 1720.8          | PPM       | 12.5  | PPM        | 302       | 77.7 | 1%  | NO  |       |
| 1 = 81.9            | PPM       | 7.9   | PPM        | 302       | 71.2 | 1%  | DO2 |       |
| 7/DEC/92 15:07:33   |           |       |            |           |      |     |     |       |
| 4 = 1744.8          | PPM       | 12.5  | PPM        | 302       | 77.1 | 1%  | NO  |       |
| 1 = 97.4            | PPM       | 8.8   | PPM        | 302       | 71.2 | 1%  | DO2 |       |
| 7/DEC/92 15:05:33   |           |       |            |           |      |     |     |       |
| 4 = 1720.8          | PPM       | 12.3  | PPM        | 302       | 78.2 | 1%  | NO  |       |
| 1 = 84.5            | PPM       | 10.0  | PPM        | 302       | 71.3 | 1%  | DO2 |       |
| 7/DEC/92 15:03:33   |           |       |            |           |      |     |     |       |
| 4 = 1725.5          | PPM       | 12.0  | PPM        | 302       | 78.2 | 1%  | NO  |       |
| 1 = 96.0            | PPM       | 8.3   | PPM        | 302       | 71.3 | 1%  | DO2 |       |
| 109/DEC/92 15:01:33 |           |       |            |           |      |     |     |       |
| 4 = 1743.12         | PPM       | 11.48 | PPM        | 302       | 78.5 | 1%  | NO  |       |
| 1 = 82.8            | PPM       | 5.2   | PPM        | 302       | 71.5 | 1%  | DO2 |       |
| 7/DEC/92 15:03:33   |           |       |            |           |      |     |     |       |
| 4 = 1702.4          | PPM       | 11.7  | PPM        | 302       | 81.1 | 1%  | NO  |       |
| 1 = 88.6            | PPM       | 4.9   | PPM        | 302       | 71.5 | 1%  | DO2 |       |
| 7/DEC/92 15:03:33   |           |       |            |           |      |     |     |       |
| 4 = 1759.0          | PPM       | 11.5  | PPM        | 302       | 81.0 | 1%  | NO  |       |
| 1 = 82.4            | PPM       | 4.5   | PPM        | 302       | 71.5 | 1%  | DO2 |       |
| 7/DEC/92 15:01:33   |           |       |            |           |      |     |     |       |
| 4 = 1744.4          | PPM       | 11.6  | PPM        | 302       | 79.3 | 1%  | NO  |       |
| 1 = 81.4            | PPM       | 4.6   | PPM        | 302       | 71.1 | 1%  | DO2 |       |



[illegible]




|     |            |       |    |    |       |     |     |    |       |     |     |    |
|-----|------------|-------|----|----|-------|-----|-----|----|-------|-----|-----|----|
| 4   | 1471.4     | PTM   | HC | 5  | 11.4  | %   | 02  | 6  | 115.1 | PPM | NO  |    |
| 1   | 1471.8     | PPM   | HC | 2  | 5.5   | PPM | 302 | 3  | 8.2   | %   | 002 |    |
| 4   | 1486.1     | PTM   | HC | 5  | 11.5  | %   | 03  | 6  | 114.5 | PPM | NO  |    |
| 1   | 1486.1     | PPM   | HC | 2  | 9.4   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1492.13    | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 114.9 | PPM | NO  |    |
| 1   | 1492.13    | PPM   | HC | 2  | 9.5   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1492.13    | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 114.4 | PPM | NO  |    |
| 1   | 1492.13    | PPM   | HC | 2  | 5.2   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1492.13    | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 113.6 | PPM | NO  |    |
| 1   | 1492.13    | PPM   | HC | 2  | 5.5   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 100 | DEC/92 503 | 21.37 | 80 | 70 | 60    |     | 50  | 40 | 30    |     | 20  | 10 |
| 4   | 1431.85    | PTM   | HC | 5  | 11.45 | %   | 502 | 6  | 102.2 | PPM | NO  |    |
| 1   | 1431.8     | PPM   | HC | 2  | 5.2   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1414.7     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 111.5 | PPM | NO  |    |
| 1   | 1414.7     | PPM   | HC | 2  | 5.1   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | DEC/92 13  | 19.37 |    |    |       |     |     |    |       |     |     |    |
| 1   | 1442.6     | PTM   | HC | 5  | 11.5  | %   | 03  | 6  | 111.2 | PPM | NO  |    |
| 1   | 1442.6     | PPM   | HC | 2  | 5.2   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1464.7     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 111.8 | PPM | NO  |    |
| 1   | 1464.7     | PPM   | HC | 2  | 5.1   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1471.7     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 112.2 | PPM | NO  |    |
| 1   | 1471.7     | PPM   | HC | 2  | 5.5   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1484.4     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 109.9 | PPM | NO  |    |
| 1   | 1484.4     | PPM   | HC | 2  | 5.7   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | 1491.4     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 109.9 | PPM | NO  |    |
| 1   | 1491.4     | PPM   | HC | 2  | 5.8   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | DEC/92 13  | 11.37 |    |    |       |     |     |    |       |     |     |    |
| 1   | 1413.1     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 105.7 | PPM | NO  |    |
| 1   | 1413.1     | PPM   | HC | 2  | 5.7   | PPM | 302 | 3  | 8.1   | %   | 002 |    |
| 4   | DEC/92 13  | 13.37 |    |    |       |     |     |    |       |     |     |    |
| 1   | 1413.1     | PTM   | HC | 5  | 11.5  | %   | 02  | 6  | 103.5 | PPM | NO  |    |
| 1   | 1413.1     | PPM   | HC | 2  | 11.5  | %   | 02  | 3  | 103.5 | PPM | NO  |    |





START RN 1-7=CONCRETABLE RM 5 REN 41 X  
KELLY MACASHEALTY SHAWDOCK ET  
UNRECORDED











| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84   | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 |
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84   | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84   | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84   | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84   | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84</ |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |     |

**WOLYTEK**

100 90 80 70 60 50 40 30 20 10 0

0 10 20 30 40 50 60 70 80 90 100

FAH-RUN-10

END

10 21 16

5 = 12.5

02

5 = 36.0

02

10 21 16

5 = 12.5

02

5 = 36.0

02

10 21 16

5 = 12.5

02

5 = 36.0

02

10 21 16

5 = 12.5

02

5 = 36.0

02



100 90 80 70 60 50 40 30 20 10 0

END

|        |     |     |   |      |     |     |   |      |     |     |
|--------|-----|-----|---|------|-----|-----|---|------|-----|-----|
| 1337.5 | PPM | 100 | 5 | 14.2 | %   | 02  | 6 | 39.7 | PPM | 100 |
| 1337.5 | PPM | 100 | 2 | 7.9  | PPM | 802 | 3 | 6.5  | %   | 002 |
| 1337.5 | PPM | 100 | 5 | 14.1 | %   | 02  | 6 | 39.3 | PPM | 100 |
| 1337.5 | PPM | 100 | 2 | 7.9  | PPM | 802 | 3 | 6.6  | %   | 002 |

[illegible]












The figure displays a large grid of handwritten data points, likely representing a chromatogram or mass spectrum. The grid is organized into columns and rows, with numerical values and chemical symbols (e.g., C, H, N, O) visible. The data is dense and covers most of the page area.



250






[illegible]









## **IX. FIELD DATA**

### **B. Gas Chromatography**

## FIELD ANALYSIS DATA SHEETS

256

Plant MACASPHALT Date 12-7-92Location PERRY FL

## 1. General Information:

|                                 |                  |                                |                  |
|---------------------------------|------------------|--------------------------------|------------------|
| Source temp. (°C)               | _____            | Columnar temperature:          |                  |
| Probe temp. (°C)                | _____            | Initial (°C)/time (min)        | <u>75 C</u>      |
| Ambient temp. (°C)              | _____            | Program rate (°C/min)          | <u>-</u>         |
| Atmospheric press. (in. Hg)     | _____            | Final (°C)/time (min)          | <u>75 C</u>      |
| Source press. (in. Hg)          | _____            | Carrier gas flow rate (ml/min) | <u>40 ml/min</u> |
| Absolute source press. (mm)     | _____            | Detector temperature (°C)      | _____            |
| Sampling rate (liter/min)       | <u>600 L/min</u> | Injection time (24-hr basis)   | _____            |
| Sample loop volume (ml)         | <u>1 ml</u>      | Chart speed (mm/min)           | <u>NA</u>        |
| Sample loop temp. (°C)          | <u>75 C</u>      | Dilution ratio                 | <u>NA</u>        |
| Dilution gas flow rate (ml/min) | <u>-</u>         | Dilution gas used (symbol)     | <u>NA</u>        |

2. Field Analysis Data: 1st CONDENSABLERun # 1 Time \_\_\_\_\_

| Components                         | Area                | Attenuation | A x A Factor | Concentration (ppm)  |
|------------------------------------|---------------------|-------------|--------------|----------------------|
| INT 1 <u>METHANE</u>               | <u>23.23</u>        | <u>32</u>   | <u>-</u>     | <u>14.212</u>        |
| 2 <u>METHANE, ETHANOL, BENZENE</u> | <u>21.95, 12.95</u> | <u>32</u>   | <u>-</u>     | <u>15.159, 2.062</u> |
| 3 <u>METHANE</u>                   | <u>23.43</u>        | <u>32</u>   | <u>-</u>     | <u>14.374</u>        |
| 4 <u>METHANE</u>                   | <u>24.21</u>        | <u>32</u>   | <u>-</u>     | <u>17.018</u>        |
| 5 <u>METHANE</u>                   | <u>22.24</u>        | <u>32</u>   | <u>-</u>     | <u>15.397</u>        |

Run # 1 Time \_\_\_\_\_

| Components       | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|------------------|--------------|-------------|--------------|---------------------|
| 6 <u>METHANE</u> | <u>15.76</u> | <u>32</u>   | <u>-</u>     | <u>10.046</u>       |
| 7 <u>METHANE</u> | <u>14.83</u> | <u>32</u>   | <u>-</u>     | <u>9.301</u>        |
| 8 <u>METHANE</u> | <u>16.50</u> | <u>32</u>   | <u>-</u>     | <u>10.562</u>       |
| 9 <u>METHANE</u> | <u>9.45</u>  | <u>32</u>   | <u>-</u>     | <u>4.874</u>        |

Run # \_\_\_\_\_ Time \_\_\_\_\_

| Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|------------|-------|-------------|--------------|---------------------|
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |

## FIELD ANALYSIS DATA SHEETS

257

Plant MACASPART Date 12-7-92  
 Location PERRY FL

## 1. General Information:

|                                 |                  |                                |                  |
|---------------------------------|------------------|--------------------------------|------------------|
| Source temp. (°C)               | _____            | Columnar temperature:          | _____            |
| Probe temp. (°C)                | _____            | Initial (°C)/time (min)        | <u>75 C</u>      |
| Ambient temp. (°C)              | _____            | Program rate (°C/min)          | <u>-</u>         |
| Atmospheric press. (in. Hg)     | _____            | Final (°C)/time (min)          | <u>75 C</u>      |
| Source press. (in. Hg)          | _____            | Carrier gas flow rate (ml/min) | <u>400ml/min</u> |
| Absolute source press. (mm)     | _____            | Detector temperature (°C)      | _____            |
| Sampling rate (liter/min)       | <u>600 1/min</u> | Injection time (24-hr basis)   | _____            |
| Sample loop volume (ml)         | <u>1ml</u>       | Chart speed (mm/min)           | <u>NA</u>        |
| Sample loop temp. (°C)          | <u>75 C</u>      | Dilution ratio                 | <u>NA</u>        |
| Dilution gas flow rate (ml/min) | <u>-</u>         | Dilution gas used (symbol)     | <u>NA</u>        |

2. Field Analysis Data: 2 mol CONDENSABLE

Run # 2 Time \_\_\_\_\_

| Components    | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|---------------|-------|-------------|--------------|---------------------|
| INT 1 METHANE | 34.88 | 32          | -            | 25.796              |
| 2 METHANE     | 6.28  | 32          | -            | 2.268               |
| 3 METHANE     | 32.61 | 32          | -            | 23.928              |
| 4 METHANE     | 37.12 | 32          | -            | 27.628              |
| 5 METHANE     | 36.79 | 32          | -            | 22.431              |

Run # 2 Time \_\_\_\_\_

| Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|------------|-------|-------------|--------------|---------------------|
| 6 METHANE  | 22.19 | 32          | -            | 21.115              |
| 7 METHANE  | 19.87 | 32          | -            | 13.448              |
| 8 METHANE  | 25.42 | 32          | -            | 18.013              |
| 9 METHANE  | 41.55 | 32          | -            | 31.283              |

Run # \_\_\_\_\_ Time \_\_\_\_\_

| Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|------------|-------|-------------|--------------|---------------------|
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |

## FIELD ANALYSIS DATA SHEETS

Plant

MACASphalt

Date

12-8-92 258

Location

PERRY FL

## 1. General Information:

|                                 |                  |                                |                  |
|---------------------------------|------------------|--------------------------------|------------------|
| Source temp. (°C)               | _____            | Columnar temperature:          |                  |
| Probe temp. (°C)                | _____            | Initial (°C)/time (min)        | <u>75C</u>       |
| Ambient temp. (°C)              | _____            | Program rate (°C/min)          | <u>-</u>         |
| Atmospheric press. (in. Hg)     | _____            | Final (°C)/time (min)          | <u>75C</u>       |
| Source press. (in. Hg)          | _____            | Carrier gas flow rate (ml/min) | <u>40 ml/min</u> |
| Absolute source press. (mm)     | _____            | Detector temperature (°C)      | _____            |
| Sampling rate (liter/min)       | <u>600 L/min</u> | Injection time (24-hr basis)   | _____            |
| Sample loop volume (ml)         | <u>1 ml</u>      | Chart speed (mm/min)           | <u>NA</u>        |
| Sample loop temp. (°C)          | <u>75C</u>       | Dilution ratio                 | <u>NA</u>        |
| Dilution gas flow rate (ml/min) | <u>-</u>         | Dilution gas used (symbol)     | <u>NA</u>        |

2. Field Analysis Data: 3<sup>rd</sup> CONDENSABLERun # 3

Time \_\_\_\_\_

| Components           | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|----------------------|--------------|-------------|--------------|---------------------|
| <u>INT 1 METHANE</u> | <u>56.95</u> | <u>32</u>   | <u>-</u>     | <u>43.689</u>       |
| <u>2 METHANE</u>     | <u>45.29</u> | <u>32</u>   | <u>-</u>     | <u>35.915</u>       |
| <u>3 METHANE</u>     | <u>45.29</u> | <u>32</u>   | <u>-</u>     | <u>35.902</u>       |
| <u>4 METHANE</u>     | <u>44.91</u> | <u>32</u>   | <u>-</u>     | <u>35.642</u>       |
| <u>5 METHANE</u>     | <u>40.99</u> | <u>32</u>   | <u>-</u>     | <u>33.048</u>       |

Run # 3

Time \_\_\_\_\_

| Components       | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|------------------|--------------|-------------|--------------|---------------------|
| <u>6 METHANE</u> | <u>45.61</u> | <u>32</u>   | <u>-</u>     | <u>36.128</u>       |
| <u>7 METHANE</u> | <u>44.94</u> | <u>32</u>   | <u>-</u>     | <u>35.695</u>       |
| <u>8 METHANE</u> | <u>19.43</u> | <u>32</u>   | <u>-</u>     | <u>18.674</u>       |
| <u>9 METHANE</u> | <u>8.47</u>  | <u>32</u>   | <u>-</u>     | <u>11.367</u>       |

Run # \_\_\_\_\_

Time \_\_\_\_\_

| Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|------------|-------|-------------|--------------|---------------------|
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |
| _____      | _____ | _____       | _____        | _____               |

# FIELD ANALYSIS DATA SHEETS

Plant MACASPORT

Date 12-8-92

259

Location PERRY FL

## 1. General Information:

|                                 |                  |                                |                  |
|---------------------------------|------------------|--------------------------------|------------------|
| Source temp. (°C)               | _____            | Columnar temperature:          | _____            |
| Probe temp. (°C)                | _____            | Initial (°C)/time (min)        | <u>75C</u>       |
| Ambient temp. (°C)              | _____            | Program rate (°C/min)          | <u>-</u>         |
| Atmospheric press. (in. Hg)     | _____            | Final (°C)/time (min)          | <u>75C</u>       |
| Source press. (in. Hg)          | _____            | Carrier gas flow rate (ml/min) | <u>40 ml/min</u> |
| Absolute source press. (mm)     | _____            | Detector temperature (°C)      | _____            |
| Sampling rate (liter/min)       | <u>600 L/min</u> | Injection time (24-hr basis)   | _____            |
| Sample loop volume (ml)         | <u>1 ml</u>      | Chart speed (mm/min)           | <u>NA</u>        |
| Sample loop temp. (°C)          | <u>75C</u>       | Dilution ratio                 | <u>NA</u>        |
| Dilution gas flow rate (ml/min) | <u>-</u>         | Dilution gas used (symbol)     | <u>NA</u>        |

## 2. Field Analysis Data: 1st PAH

Run # 1 Time \_\_\_\_\_

|       | Components     | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|-------|----------------|--------------|-------------|--------------|---------------------|
| INT 1 | <u>METHANE</u> | <u>44.95</u> | <u>32</u>   | <u>-</u>     | <u>35.688</u>       |
| 2     | <u>METHANE</u> | <u>35.80</u> | <u>32</u>   | <u>-</u>     | <u>29.588</u>       |
| 3     | <u>METHANE</u> | <u>42.28</u> | <u>32</u>   | <u>-</u>     | <u>33.908</u>       |
| 4     | <u>METHANE</u> | <u>40.87</u> | <u>32</u>   | <u>-</u>     | <u>32.968</u>       |
| 5     | <u>METHANE</u> | <u>40.70</u> | <u>32</u>   | <u>-</u>     | <u>32.855</u>       |

Run # 1 Time \_\_\_\_\_

|   | Components     | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|---|----------------|--------------|-------------|--------------|---------------------|
| 6 | <u>METHANE</u> | <u>41.52</u> | <u>32</u>   | <u>-</u>     | <u>33.401</u>       |
| 7 | <u>METHANE</u> | <u>36.44</u> | <u>32</u>   | <u>-</u>     | <u>30.148</u>       |
| 8 | <u>METHANE</u> | <u>36.98</u> | <u>32</u>   | <u>-</u>     | <u>30.375</u>       |
| 9 | <u>METHANE</u> | <u>40.22</u> | <u>32</u>   | <u>-</u>     | <u>32.535</u>       |

Run # \_\_\_\_\_ Time \_\_\_\_\_

|       | Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|-------|------------|-------|-------------|--------------|---------------------|
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |



# FIELD ANALYSIS DATA SHEETS

Plant MACASPORT Date 12-8-92 260  
 Location PERRY FL

## 1. General Information:

|                                 |                  |                                |                  |
|---------------------------------|------------------|--------------------------------|------------------|
| Source temp. (°C)               | _____            | Columnar temperature:          |                  |
| Probe temp. (°C)                | _____            | Initial (°C)/time (min)        | <u>75 C</u>      |
| Ambient temp. (°C)              | _____            | Program rate (°C/min)          | <u>—</u>         |
| Atmospheric press. (in. Hg)     | _____            | Final (°C)/time (min)          | <u>75 C</u>      |
| Source press. (in. Hg)          | _____            | Carrier gas flow rate (ml/min) | <u>40 ml/min</u> |
| Absolute source press. (mm)     | _____            | Detector temperature (°C)      | _____            |
| Sampling rate (liter/min)       | <u>600 L/min</u> | Injection time (24-hr basis)   | _____            |
| Sample loop volume (ml)         | <u>1 ml</u>      | Chart speed (mm/min)           | <u>NA</u>        |
| Sample loop temp. (°C)          | <u>75 C</u>      | Dilution ratio                 | <u>NA</u>        |
| Dilution gas flow rate (ml/min) | <u>—</u>         | Dilution gas used (symbol)     | <u>NA</u>        |

## 2. Field Analysis Data: 2nd PAH

Run # 2 Time \_\_\_\_\_

|              | Components             | Area               | Attenuation | A x A Factor | Concentration (ppm)   |
|--------------|------------------------|--------------------|-------------|--------------|-----------------------|
| <u>INT 1</u> | <u>METHANE/BENZENE</u> | <u>42.43/18.58</u> | <u>32</u>   | <u>—</u>     | <u>34.008 / 2.742</u> |
| <u>2</u>     | <u>METHANE</u>         | <u>50.30</u>       | <u>32</u>   | <u>—</u>     | <u>36.618</u>         |
| <u>3</u>     | <u>METHANE</u>         | <u>39.00</u>       | <u>32</u>   | <u>—</u>     | <u>28.657</u>         |
| <u>4</u>     | <u>METHANE</u>         | <u>36.25</u>       | <u>32</u>   | <u>—</u>     | <u>26.720</u>         |
| <u>5</u>     | <u>METHANE</u>         | <u>36.01</u>       | <u>32</u>   | <u>—</u>     | <u>26.551</u>         |

Run # 2 Time \_\_\_\_\_

|          | Components     | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|----------|----------------|--------------|-------------|--------------|---------------------|
| <u>6</u> | <u>METHANE</u> | <u>32.31</u> | <u>32</u>   | <u>—</u>     | <u>27.467</u>       |
| <u>7</u> | <u>METHANE</u> | <u>34.11</u> | <u>32</u>   | <u>—</u>     | <u>25.212</u>       |
| <u>8</u> | <u>METHANE</u> | <u>41.28</u> | <u>32</u>   | <u>—</u>     | <u>30.264</u>       |
| <u>9</u> | <u>METHANE</u> | <u>0.00</u>  | <u>32</u>   | <u>—</u>     | <u>0.002</u>        |

Run # \_\_\_\_\_ Time \_\_\_\_\_

|       | Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|-------|------------|-------|-------------|--------------|---------------------|
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |
| _____ | _____      | _____ | _____       | _____        | _____               |

## FIELD ANALYSIS DATA SHEETS

Plant

MACASPHALT

Date

12-9-92

261

Location

PERRY F.L.

## 1. General Information:

Source temp. (°C)

Probe temp. (°C)

Ambient temp. (°C)

Atmospheric press. (in. Hg)

Source press. (in. Hg)

Absolute source press. (mm)

Sampling rate (liter/min)

Sample loop volume (ml)

Sample loop temp. (°C)

Dilution gas flow rate (ml/min)

Columnar temperature:

Initial (°C)/time (min)

Program rate (°C/min)

Final (°C)/time (min)

Carrier gas flow rate (ml/min)

Detector temperature (°C)

Injection time (24-hr basis)

Chart speed (mm/min)

Dilution ratio

Dilution gas used (symbol)

75C—75C40 ml/min75C—NANANA

## 2. Field Analysis Data:

3<sup>rd</sup> PAHRun # 3Time                     

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

INT1

METHANE57.4632—34.513

2

METHANE64.5932—39.309

3

METHANE61.0132—36.901

4

METHANE58.8432—35.441

5

METHANE47.8432—28.042Run # 3Time                     

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

6

METHANE50.5532—29.865

7

METHANE52.1032—30.908

8

METHANE68.9332—42.228

9

METHANE66.5832—40.648

10

METHANE18.1832—8.092Run #           Time                     

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

11

12

## FIELD ANALYSIS DATA SHEETS

Plant

MACASPORT

Date

12-9-92

262

Location

PERRY FL

## 1. General Information:

Source temp. (°C)

Probe temp. (°C)

Ambient temp. (°C)

Atmospheric press. (in. Hg)

Source press. (in. Hg)

Absolute source press. (mm)

Sampling rate (liter/min)

Sample loop volume (ml)

Sample loop temp. (°C)

Dilution gas flow rate (ml/min)

Columnar temperature:

Initial (°C)/time (min)

Program rate (°C/min)

Final (°C)/time (min)

Carrier gas flow rate (ml/min)

Detector temperature (°C)

Injection time (24-hr basis)

Chart speed (mm/min)

Dilution ratio

Dilution gas used (symbol)

75C-75C50 ml/min--NANANA2. Field Analysis Data: 1<sup>st</sup> FORMALDEHYDERun # 1Time                     

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

1 METHANE55.6232-33.2762 METHANE47.2432-27.4523 METHANE51.8932-30.7674 METHANE46.0332-26.8255 METHANE46.8532-27.376Run # 1Time                     

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

6 METHANE50.5332-29.852Run #             Time                     

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

# FIELD ANALYSIS DATA SHEETS

Plant MACASphalt Date 12-9-92 263  
 Location PERRY FL

## 1. General Information:

|                                 |                   |                                |                  |
|---------------------------------|-------------------|--------------------------------|------------------|
| Source temp. (°C)               | _____             | Columnar temperature:          | _____            |
| Probe temp. (°C)                | _____             | Initial (°C)/time (min)        | <u>75C</u>       |
| Ambient temp. (°C)              | _____             | Program rate (°C/min)          | <u>-</u>         |
| Atmospheric press. (in. Hg)     | _____             | Final (°C)/time (min)          | <u>75C</u>       |
| Source press. (in. Hg)          | _____             | Carrier gas flow rate (ml/min) | <u>40 ml/min</u> |
| Absolute source press. (mm)     | _____             | Detector temperature (°C)      | _____            |
| Sampling rate (liter/min)       | <u>600 ml/min</u> | Injection time (24-hr basis)   | _____            |
| Sample loop volume (ml)         | <u>1 ml</u>       | Chart speed (mm/min)           | <u>NA</u>        |
| Sample loop temp. (°C)          | <u>75C</u>        | Dilution ratio                 | <u>NA</u>        |
| Dilution gas flow rate (ml/min) | <u>-</u>          | Dilution gas used (symbol)     | <u>NA</u>        |

## 2. Field Analysis Data: 2nd FORMALDEHYDE

Run # 2 Time \_\_\_\_\_

|       | Components | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|-------|------------|--------------|-------------|--------------|---------------------|
| INT 1 | METHANE    | <u>24.94</u> | <u>32</u>   | <u>-</u>     | <u>12.439</u>       |
| 2     | METHANE    | <u>40.21</u> | <u>32</u>   | <u>-</u>     | <u>22.91</u>        |
| 3     | METHANE    | <u>32.79</u> | <u>32</u>   | <u>-</u>     | <u>21.282</u>       |
| 4     | METHANE    | <u>47.74</u> | <u>32</u>   | <u>-</u>     | <u>22.975</u>       |
| 5     | METHANE    | <u>54.43</u> | <u>32</u>   | <u>-</u>     | <u>32.475</u>       |

Run # 2 Time \_\_\_\_\_

|   | Components | Area         | Attenuation | A x A Factor | Concentration (ppm) |
|---|------------|--------------|-------------|--------------|---------------------|
| 6 | METHANE    | <u>54.77</u> | <u>32</u>   | <u>-</u>     | <u>32.704</u>       |
|   | _____      | _____        | _____       | _____        | _____               |
|   | _____      | _____        | _____       | _____        | _____               |
|   | _____      | _____        | _____       | _____        | _____               |
|   | _____      | _____        | _____       | _____        | _____               |

Run # \_\_\_\_\_ Time \_\_\_\_\_

|  | Components | Area  | Attenuation | A x A Factor | Concentration (ppm) |
|--|------------|-------|-------------|--------------|---------------------|
|  | _____      | _____ | _____       | _____        | _____               |
|  | _____      | _____ | _____       | _____        | _____               |
|  | _____      | _____ | _____       | _____        | _____               |
|  | _____      | _____ | _____       | _____        | _____               |
|  | _____      | _____ | _____       | _____        | _____               |

## FIELD ANALYSIS DATA SHEETS

Plant

MACASphalt

Date

12-9-92

264

Location

PERRY FL

## 1. General Information:

Source temp. (°C)

Probe temp. (°C)

Ambient temp. (°C)

Atmospheric press. (in. Hg)

Source press. (in. Hg)

Absolute source press. (mm)

Sampling rate (liter/min)

Sample loop volume (ml)

Sample loop temp. (°C)

Dilution gas flow rate (ml/min)

Columnar temperature:

Initial (°C)/time (min)

Program rate (°C/min)

Final (°C)/time (min)

Carrier gas flow rate (ml/min)

Detector temperature (°C)

Injection time (24-hr basis)

Chart speed (mm/min)

Dilution ratio

Dilution gas used (symbol)

75 C-75 C40 ml/min--NANANA

## 2. Field Analysis Data:

3<sup>rd</sup> FORMALDEHYDERun # 3

Time

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

INT 1 METHANE61.3332-37.1162 METHANE78.3332-48.5513 METHANE65.2532-39.7534 METHANE96.3632-60.8145 METHANE88.7832-55.580Run # 3

Time

Components

Area

Attenuation

A x A Factor

Concentration (ppm)

6 METHANE104.0132-65.825

Run #

Time

Components

Area


Attenuation

A x A Factor

Concentration (ppm)

## **IX. FIELD DATA**

### **C. PAH**

Plant MPC AsPhalLocation Cross City, FLAOperator J. ClarkDate 12-8-52Run No. 1Sample Box No. 1Meter Box No. AdeSeuMeter H @ 1852C Factor 980Pitot Tube Coefficient Cp .84Ambient Temperature 60Barometric Pressure 30.08Assumed Moisture, % 28Probe Length, m(ft) 4.71

Nozzle Identification No. \_\_\_\_\_

Avg. Calibrated Nozzle Dia., (in.), 250Probe Heater Setting 4Leak Rate, m<sup>3</sup>/min. (cfm) 0.21 at 24"Probe Liner Material PYREX

Static Pressure, mm Hg (in. Hg) \_\_\_\_\_

Filter No. \_\_\_\_\_

Schematic of Stack Cross Section

PAH

| TRAV. PT<br>NO.     | SAMPLING<br>TIME<br>(@) min. | VACUUM<br>in. Hg | STACK<br>TEMP<br>(T <sub>s</sub> )<br>°F | VELOCITY<br>HEAD<br>(P <sub>s</sub> )<br>in. H <sub>2</sub> O | PRESSURE<br>DIFF. ORF.<br>MTR<br>in. H <sub>2</sub> O | GAS<br>SAMPLE<br>VOLUME<br>ft <sup>3</sup> | GAS SAMPLE TEMP.<br>AT DRY GAS METER<br>°F |        | FILTER<br>HOLDER<br>TEMP<br>°F | GAS TEMP LVG<br>CONDENSER OR<br>LAST IMPINGER<br>°F |
|---------------------|------------------------------|------------------|------------------------------------------|---------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------|--------------------------------------------|--------|--------------------------------|-----------------------------------------------------|
|                     |                              |                  |                                          |                                                               |                                                       |                                            | Inlet                                      | Outlet |                                |                                                     |
| A 1                 | <del>11:24</del><br>11:26    | 15               | 267                                      | 1.7                                                           | 3.2                                                   | <del>410.73</del><br>410.76                | 78                                         | 70     | 270                            | 58                                                  |
| 2                   | 11:28                        | 23               | 269                                      | 2.0                                                           | 3.8                                                   | 412.7                                      | 87                                         | 70     | 268                            | 53                                                  |
| 3                   | 11:30                        | 19               | 269                                      | 1.9                                                           | 3.7                                                   | 412.8                                      | 92                                         | 70     | 265                            | 54                                                  |
| 4                   | 11:32                        | 16               | 269                                      | 1.4                                                           | 2.7                                                   | 414.6                                      | 99                                         | 71     | 248                            | 55                                                  |
| 5                   | 11:34                        | 12               | 268                                      | 1.1                                                           | 2.1                                                   | 416.2                                      | 103                                        | 72     | 241                            | 55                                                  |
| <del>B 1</del><br>6 | <del>11:35</del><br>11:37    | 15               | 268                                      | 1.5                                                           | 2.9                                                   | 418.0                                      | 105                                        | 73     | 231                            | 58                                                  |
| 2                   | <del>11:40</del><br>11:42    | 15               | 267                                      | 1.5                                                           | 2.9                                                   | 419.7                                      | 89                                         | 74     | 264                            | 62                                                  |
| 3                   | 11:49                        | 14               | 268                                      | 1.3                                                           | 2.5                                                   | 421.5                                      | 99                                         | 74     | 271                            | 59                                                  |
| 4                   | 11:51                        | 12               | 260                                      | 1.0                                                           | 1.9                                                   | 423.0                                      | 104                                        | 75     | 268                            | 57                                                  |
| 5                   | 11:53                        | 12               | 267                                      | 1.0                                                           | 1.9                                                   | 424.5                                      | 107                                        | 76     | 267                            | 56                                                  |
|                     |                              |                  |                                          |                                                               |                                                       |                                            |                                            |        |                                |                                                     |
|                     |                              |                  |                                          |                                                               |                                                       |                                            |                                            |        |                                |                                                     |
|                     |                              |                  |                                          |                                                               |                                                       |                                            |                                            |        |                                |                                                     |
|                     |                              |                  |                                          |                                                               |                                                       |                                            |                                            |        |                                |                                                     |

RAMCON emissions test log sheet, cont. DATE: 12-8-52 LOCATION: PARADISE TEST NO. 1

PAH

Cove 077, Fla

| TRAVERSE POINT | SAMPLING TIME<br>(min)    | VACUUM<br>(in. Hg.) | STACK TEMP<br>(°F) | VELOCITY<br>HEAD | ORIFICE DIFF.<br>PRESSURE | GAS<br>VOLUME<br>V <sub>m</sub> (ft. <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |    | SAMPLE<br>BOX TEMP.<br>(°F) | IMPINGER<br>TEMP<br>(°F) |
|----------------|---------------------------|---------------------|--------------------|------------------|---------------------------|-----------------------------------------------------|-----------------------|----|-----------------------------|--------------------------|
|                |                           |                     |                    |                  |                           |                                                     |                       |    |                             |                          |
| 01             | <del>11:54</del><br>11:54 | 13                  | 268                | 1.3              | 2.5                       | 426.1                                               | 106                   | 77 | 272                         | 59                       |
| 2              | 11:58                     | 13                  | 267                | 1.3              | 2.5                       | 427.5                                               | 109                   | 78 | 262                         | 57                       |
| 3              | 12:00                     | 12                  | 257                | 1.1              | 2.1                       | 424.5                                               | 114                   | 79 | 253                         | 56                       |
| 4              | 12:02                     | 11                  | 252                | .95              | 1.8                       | 431.0                                               | 114                   | 80 | 251                         | 57                       |
| 5              | 12:04                     | 12                  | 252                | 1.1              | 2.1                       | 432.5                                               | 115                   | 81 | 249                         | 58                       |
| 01             | <del>12:05</del><br>12:05 | 13                  | 268                | 1.3              | 2.5                       | 434.2                                               | 111                   | 83 | 251                         | 59                       |
| 2              | 12:05                     | 14                  | 253                | 1.4              | 2.7                       | 435.5                                               | 118                   | 84 | 242                         | 56                       |
| 3              | 12:11                     | 14                  | 239                | 1.3              | 2.5                       | 437.7                                               | 121                   | 85 | 242                         | 59                       |
| 4              | 12:13                     | 12                  | 247                | 1.0              | 1.9                       | 439.3                                               | 122                   | 84 | 236                         | 56                       |
| 5              | 12:15                     | 12                  | 245                | .93              | 1.8                       | 440.7                                               | 121                   | 87 | 234                         | 55                       |
| 01             | <del>12:16</del><br>12:18 | 15                  | 258                | 1.5              | 2.9                       | 442.4                                               | 119                   | 89 | 234                         | 57                       |
| 2              | 12:20                     | 15                  | 254                | 1.5              | 2.9                       | 444.3                                               | 123                   | 89 | 236                         | 55                       |
| 3              | 12:22                     | 15                  | 234                | 1.5              | 2.9                       | 446.2                                               | 127                   | 90 | 238                         | 55                       |
| 4              | 12:24                     | 12                  | 238                | 1.0              | 1.9                       | 447.7                                               | 120                   | 91 | 233                         | 56                       |
| 5              | 12:24                     | 12                  | 248                | 1.0              | 1.9                       | 449.2                                               | 125                   | 92 | 239                         | 57                       |
| 01             | <del>12:27</del><br>12:29 | 20                  | 269                | 2.1              | 4.0                       | 451.5                                               | 123                   | 93 | 246                         | 69                       |
| 2              | 12:31                     | 20                  | 269                | 2.1              | 4.0                       | 453.5                                               | 127                   | 94 | 248                         | 57                       |
| 3              | 12:33                     | 21                  | 258                | 2.0              | 3.9                       | 455.6                                               | 129                   | 94 | 245                         | 56                       |
| 4              | 12:35                     | 18                  | 261                | 1.8              | 3.5                       | 457.7                                               | 131                   | 95 | 241                         | 55                       |
| 5              | 12:37                     | 18                  | 259                | 1.8              | 3.5                       | 459.75                                              | 133                   | 96 | 240                         | 55                       |

266



Plant MACASPT 5Location CROSS CITY, FLAOperator T. J. ROSEDate 12-8-92Run No. 2Sample Box No. 1Meter Box No. ANDERSONMeter H @ 1852C Factor 580Pitot Tube Coefficient Cp .84Ambient Temperature 60Barometric Pressure 30.08Assumed Moisture, % 28Probe Length, m(ft) 4.17Nozzle Identification No. Avg. Calibrated Nozzle Dia., (in.) .250Probe Heater Setting 4Leak Rate, m<sup>3</sup>/min. (cfm) .015 AT 20"Probe Liner Material PYREXStatic Pressure, mm Hg (in. Hg) Filter No. 

| WIND VOLUME<br>m <sup>3</sup> | RELATIVE<br>HUMIDITY<br>% |
|-------------------------------|---------------------------|
| 832                           | 49.1                      |
| 200                           | 48.3                      |
| 132                           | 9.1                       |

## Schematic of Stack Cross Section

PAH

| TRAV. PT<br>NO. | SAMPLING<br>TIME<br>( $\theta$ ) min. | VACUUM<br>in. Hg | STACK<br>TEMP<br>(T <sub>s</sub> )<br>°F | VELOCITY<br>HEAD<br>( $P_o$ )<br>in. H <sub>2</sub> O | PRESSURE<br>DIFF. ORF.<br>MTR<br>in. H <sub>2</sub> O | GAS<br>SAMPLE<br>VOLUME<br>ft <sup>3</sup> | GAS SAMPLE TEMP.<br>AT DRY GAS METER<br>°F |        | FILTER<br>HOLDER<br>TEMP<br>°F | GAS TEMP LVG<br>CONDENSER OR<br>LAST IMPINGER<br>°F |
|-----------------|---------------------------------------|------------------|------------------------------------------|-------------------------------------------------------|-------------------------------------------------------|--------------------------------------------|--------------------------------------------|--------|--------------------------------|-----------------------------------------------------|
|                 |                                       |                  |                                          |                                                       |                                                       |                                            | Inlet                                      | Outlet |                                |                                                     |
| A-1             | <del>13:43</del><br>13:46             | 13               | 261                                      | 1.6                                                   | 3.3                                                   | <del>460.65</del><br>463.5                 | 79                                         | 75     | 232                            | 66                                                  |
| 2               | 13:49                                 | 17               | 271                                      | 2.0                                                   | 4.1                                                   | 466.8                                      | 99                                         | 75     | 233                            | 57                                                  |
| 3               | <del>13:52</del><br>13:55             | 11               | 269                                      | 1.3                                                   | 2.7                                                   | 469.4                                      | 106                                        | 76     | 245                            | 57                                                  |
| 4               | <del>15:45</del><br>15:48             | 12               | 251                                      | 1.3                                                   | 2.7                                                   | 472.2                                      | 77                                         | 73     | 224                            | 67                                                  |
| 5               | 15:51                                 | 10               | 258                                      | 1.0                                                   | 2.1                                                   | 474.6                                      | 87                                         | 72     | 227                            | 62                                                  |
| B-1             | <del>15:53</del><br>15:55             | 12               | 261                                      | 1.5                                                   | 3.0                                                   | 477.5                                      | 97                                         | 73     | 235                            | 62                                                  |
| 2               | 15:58                                 | 12               | 264                                      | 1.5                                                   | 3.0                                                   | 480.3                                      | 106                                        | 75     | 230                            | 59                                                  |
| 3               | 16:01                                 | 10               | 264                                      | 1.1                                                   | 2.3                                                   | 482.7                                      | 110                                        | 76     | 226                            | 60                                                  |
| 4               | 16:04                                 | 9                | 265                                      | .95                                                   | 1.9                                                   | 485.1                                      | 111                                        | 78     | 238                            | 62                                                  |
| 5               | 16:07                                 | 10               | 265                                      | 1.0                                                   | 2.1                                                   | 487.3                                      | 113                                        | 79     | 232                            | 62                                                  |
|                 |                                       |                  |                                          |                                                       |                                                       |                                            |                                            |        |                                |                                                     |
|                 |                                       |                  |                                          |                                                       |                                                       |                                            |                                            |        |                                |                                                     |
|                 |                                       |                  |                                          |                                                       |                                                       |                                            |                                            |        |                                |                                                     |
|                 |                                       |                  |                                          |                                                       |                                                       |                                            |                                            |        |                                |                                                     |

267

MACASPT 5

**RAMCON** emissions test log sheet, cont. DATE 12-8-97 LOCATION MACASDAKT TEST NO. 2

CROSS CITY, FLA

PAH

| TRAVERSE POINT | SAMPLING TIME<br>(min) | VACUUM<br>(in. Hg) | STACK TEMP<br>(°F) | VELOCITY<br>HEAD<br>(ft. H <sub>2</sub> O) | ORIFICE DIFF. PRESSURE<br>(in. H <sub>2</sub> O) | GAS VOLUME<br>V <sub>m</sub> (ft. <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |     | SAMPLE BOX TEMP. (°F) | IMPINGER TEMP (°F) |
|----------------|------------------------|--------------------|--------------------|--------------------------------------------|--------------------------------------------------|--------------------------------------------------|-----------------------|-----|-----------------------|--------------------|
|                |                        |                    |                    |                                            |                                                  |                                                  |                       |     |                       |                    |
| C1             | 16:08                  | 10                 | 264                | 1.1                                        | 2.3                                              | 489.7                                            | 109                   | 82  | 258                   | 63                 |
| 2              | 16:14                  | 12                 | 269                | 1.4                                        | 2.8                                              | 492.4                                            | 117                   | 84  | 273                   | 63                 |
| 3              | 16:17                  | 11                 | 268                | 1.3                                        | 2.5                                              | 495.1                                            | 121                   | 86  | 261                   | 60                 |
| 4              | 16:20                  | 9                  | 267                | .95                                        | 1.9                                              | 497.3                                            | 122                   | 87  | 261                   | 60                 |
| 5              | 16:23                  | 9                  | 266                | .95                                        | 1.9                                              | 499.6                                            | 121                   | 89  | 260                   | 61                 |
| D1             | 16:24                  | 11                 | 266                | 1.3                                        | 2.5                                              | 502.3                                            | 117                   | 91  | 248                   | 61                 |
| 2              | 16:30                  | 11                 | 269                | 1.3                                        | 2.5                                              | 504.9                                            | 123                   | 92  | 258                   | 59                 |
| 3              | 16:33                  | 9                  | 264                | .92                                        | 1.9                                              | 507.2                                            | 124                   | 93  | 259                   | 59                 |
| 4              | 16:36                  | 9                  | 264                | .90                                        | 1.8                                              | 509.4                                            | 123                   | 94  | 258                   | 60                 |
| 5              | 16:39                  | 9                  | 264                | .85                                        | 1.7                                              | 511.5                                            | 123                   | 94  | 253                   | 60                 |
| E1             | 16:40                  | 11                 | 267                | 1.3                                        | 2.5                                              | 514.1                                            | 115                   | 95  | 248                   | 61                 |
| 2              | 16:46                  | 13                 | 267                | 1.5                                        | 3.1                                              | 517.0                                            | 124                   | 95  | 248                   | 59                 |
| 3              | 16:49                  | 11                 | 264                | 1.3                                        | 2.5                                              | 519.4                                            | 128                   | 96  | 240                   | 60                 |
| 4              | 16:52                  | 10                 | 261                | 1.0                                        | 2.1                                              | 522.0                                            | 126                   | 96  | 242                   | 60                 |
| 5              | 16:55                  | 10                 | 260                | 1.0                                        | 2.1                                              | 524.4                                            | 126                   | 97  | 242                   | 60                 |
| F1             | 16:56                  | 18                 | 266                | 2.2                                        | 4.5                                              | 527.9                                            | 128                   | 97  | 261                   | 58                 |
| 2              | 17:02                  | 18                 | 266                | 2.3                                        | 4.7                                              | 531.5                                            | 134                   | 98  | 256                   | 57                 |
| 3              | 17:05                  | 17                 | 262                | 2.1                                        | 4.3                                              | 534.9                                            | 136                   | 99  | 258                   | 56                 |
| 4              | 17:08                  | 15                 | 263                | 1.8                                        | 3.7                                              | 538.1                                            | 138                   | 100 | 263                   | 57                 |
| 5              | 17:11                  | 14                 | 262                | 1.7                                        | 3.5                                              | 541.264                                          | 138                   | 101 | 257                   | 57                 |

268

Plant MACASSET

Location CROSS CITY, FLA

Operator J. O. BOK

Date 12-9-52

Run No. 3

Sample Box No. ANDERSON 1

Meter Box No. 1857 ANDERSON

Meter H  $\emptyset$  1.852

C Factor 580

Pitot Tube Coefficient Cp .84

Ambient Temperature 50

Barometric Pressure 30.12

Assumed Moisture, % 27

Probe Length, m(ft) 4.17

Nozzle Identification No.

Avg. Calibrated Nozzle Dia., (in.) .250

Probe Heater Setting 4

Leak Rate, m<sup>3</sup>/min. (cfm) .018 @ 7.24"

Probe Liner Material Pyrex

Static Pressure, mm Hg (in. Hg)

Filter No.

| AMBIENT TEMPERATURE | BAROMETRIC PRESSURE | ASSUMED MOISTURE, % | PROBE LENGTH, M (FT) | NOZZLE IDENTIFICATION NO. | AVG. CALIBRATED NOZZLE DIA., (IN.) | PROBE HEATER SETTING | LEAK RATE, M <sup>3</sup> /MIN. (CFM) | PROBE LINER MATERIAL | STATIC PRESSURE, MM HG (IN. HG) | FILTER NO. |
|---------------------|---------------------|---------------------|----------------------|---------------------------|------------------------------------|----------------------|---------------------------------------|----------------------|---------------------------------|------------|
| 50                  | 30.12               | 27                  | 4.17                 |                           | .250                               | 4                    | .018 @ 7.24"                          | Pyrex                |                                 |            |

| INITIAL | FINAL | DIFFERENCE |
|---------|-------|------------|
| 7.19    | 43.11 |            |
| 22.0    | 42.88 |            |
| 2.0     | 8.3   |            |

Schematic of Stack Cross Section

PAH

| TRAV. PT NO. | SAMPLING TIME (H) min. | VACUUM in. Hg | STACK TEMP (Ts) | VELOCITY HEAD (Ps) | PRESSURE DIFF. ORF. MTR | GAS SAMPLE VOLUME ft <sup>3</sup> | GAS SAMPLE TEMP. AT DRY GAS METER °F |        | FILTER HOLDER TEMP °F | GAS TEMP LVG CONDENSER OR LAST IMPINGER °F |
|--------------|------------------------|---------------|-----------------|--------------------|-------------------------|-----------------------------------|--------------------------------------|--------|-----------------------|--------------------------------------------|
|              |                        |               |                 |                    |                         |                                   | Inlet                                | Outlet |                       |                                            |
| A 1          | 9:40                   | 17            | 250             | 1.6                | 3.0                     | 552.583                           | 94                                   | 73     | 268                   | 67                                         |
| 2            | 10:00                  | 20            | 251             | 2.0                | 3.8                     | 557.8                             | 102                                  | 81     | 254                   | 50                                         |
| 3            | 10:25                  | 14            | 245             | 1.8                | 1.8                     | 560.1                             | 96                                   | 90     | 255                   | 57                                         |
| 4            | 10:31                  | 16            | 251             | 1.2                | 2.3                     | 562.4                             | 104                                  | 88     | 257                   | 55                                         |
| 5            | 10:34                  | 23            | 258             | 1.8                | 3.4                     | 565.5                             | 117                                  | 88     | 259                   | 57                                         |
| 6 1          | 10:55                  | 18            | 266             | 1.4                | 2.6                     | 568.45                            | 98                                   | 82     | 265                   | 56                                         |
| 2            | 11:01                  | 17            | 273             | 1.4                | 2.6                     | 571.0                             | 111                                  | 83     | 269                   | 53                                         |
| 3            | 11:04                  | 12            | 272             | 1.2                | 2.3                     | 573.5                             | 122                                  | 86     | 268                   | 54                                         |
| 4            | 11:07                  | 10            | 271             | 1.0                | 1.7                     | 575.6                             | 125                                  | 89     | 271                   | 57                                         |
| 5            | 11:10                  | 12            | 271             | .85                | 1.6                     | 577.6                             | 127                                  | 91     | 289                   | 57                                         |
|              |                        |               |                 |                    |                         |                                   |                                      |        |                       |                                            |
|              |                        |               |                 |                    |                         |                                   |                                      |        |                       |                                            |
|              |                        |               |                 |                    |                         |                                   |                                      |        |                       |                                            |
|              |                        |               |                 |                    |                         |                                   |                                      |        |                       |                                            |

RAMCON emissions test log sheet, cont. DATE 12-9-92 LOCATION MACOS ~~ACT~~ TEST NO. 5


CROSS CITY, FLA

| TRAVERSE POINT | SAMPLING TIME (min) | VACUUM (in. Hg) | STACK TEMP | VELOCITY HEAD | ORFICE DIFF. PRESSURE | GAS VOLUME Vm (ft. <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |     | SAMPLE BOX TEMP. (°F) | IMPIRGER TEMP (°F) |
|----------------|---------------------|-----------------|------------|---------------|-----------------------|-----------------------------------|-----------------------|-----|-----------------------|--------------------|
|                |                     |                 |            |               |                       |                                   |                       |     |                       |                    |
| 0-1            | 11:14               | 15              | 276        | 1.1           | 2.1                   | 580.0                             | 128                   | 96  | 267                   | 59                 |
| 2              | 11:17               | 15              | 275        | 1.2           | 2.3                   | 582.4                             | 135                   | 98  | 269                   | 58                 |
| 3              | 11:20               | 13              | 273        | 1.0           | 1.9                   | 584.8                             | 137                   | 100 | 258                   | 60                 |
| 4              | 11:23               | 10              | 269        | .85           | 1.6                   | 587.0                             | 137                   | 102 | 254                   | 59                 |
| 5              | 11:26               | 13              | 268        | .95           | 1.8                   | 589.1                             | 136                   | 103 | 249                   | 58                 |
| D 1            | 11:28               | 17              | 273        | 1.3           | 2.5                   | 591.5                             | 132                   | 107 | 255                   | 43                 |
| 2              | 11:34               | 18              | 274        | 1.3           | 2.5                   | 594.0                             | 137                   | 106 | 257                   | 42                 |
| 3              | 11:37               | 14              | 272        | 1.1           | 2.1                   | 596.7                             | 137                   | 107 | 258                   | 46                 |
| 4              | 11:40               | 15              | 273        | .95           | 1.8                   | 598.8                             | 140                   | 107 | 258                   | 55                 |
| 5              | 11:43               | 13              | 275        | .77           | 1.5                   | 599.8                             | 139                   | 106 | 260                   | 58                 |
| E 1            | 11:44               | 21              | 278        | 1.5           | 2.8                   | 603.7                             | 136                   | 107 | 269                   | 62                 |
| 2              | 11:50               | 21              | 281        | 1.5           | 2.8                   | 606.5                             | 139                   | 107 | 272                   | 58                 |
| 3              | 11:53               | 19              | 280        | 1.3           | 2.5                   | 609.1                             | 141                   | 107 | 272                   | 58                 |
| 4              | 11:54               | 14              | 276        | .95           | 1.8                   | 611.4                             | 141                   | 108 | 269                   | 61                 |
| 5              | 11:59               | 13              | 273        | .90           | 1.7                   | 613.5                             | 139                   | 108 | 267                   | 63                 |
| F 1            | 12:00               | 22              | 283        | 2.2           | 4.2                   | 616.7                             | 138                   | 109 | 271                   | 62                 |
| 2              | 12:01               | 22              | 281        | 2.5           | 4.7                   | 619.6                             | 135                   | 109 | 268                   | 62                 |
| 3              | 12:10               | 22              | 268        | 2.3           | 4.3                   | 622.5                             | 136                   | 109 | 265                   | 62                 |
| 4              | 12:13               | 22              | 267        | 2.0           | 3.8                   | 625.5                             | 136                   | 109 | 265                   | 65                 |
| 5              | 12:14               | 22              | 264        | 1.4           | 3.0                   | 628.3                             | 137                   | 108 | 258                   | 67                 |

270

## **IX. FIELD DATA**

### **D. Particulate**

Plant MACASFLTLocation Phos City, FLAOperator JCRDate 12-7-92Run No. 1Sample Box No. 2-185Meter Box No. 1-185Meter H @ 15.31C Factor .987Pitot Tube Coefficient Cp .84

Schematic of Stack Cross Section

CONDENSATES

| TRAV. PT NO. | SAMPLING TIME (Ø) min. | VACUUM in. Hg | STACK TEMP (Ts) °F | VELOCITY HEAD (Ps) in H <sub>2</sub> O | PRESSURE DIFF. ORF. MTR in H <sub>2</sub> O | GAS SAMPLE VOLUME ft <sup>3</sup> | GAS SAMPLE TEMP. °F |        | FILTER HOLDER TEMP °F | GAS TEMP LVG CONDENSER OR LAST IMPINGER °F |
|--------------|------------------------|---------------|--------------------|----------------------------------------|---------------------------------------------|-----------------------------------|---------------------|--------|-----------------------|--------------------------------------------|
|              |                        |               |                    |                                        |                                             |                                   | Inlet               | Outlet |                       |                                            |
| 1            | 11:45                  | 12            | 275                | 1.5                                    | 2.2                                         | 768.570                           | 96                  | 88     | 272                   | 68                                         |
| 2            | 11:47                  | 8             | 250                | 1.0                                    | 1.4                                         | 771.6                             | 92                  | 84     | 225                   | 68                                         |
| 3            | 13:03                  | 8             | 253                | 1.2                                    | 1.7                                         | 773.2                             | 96                  | 86     | 234                   | 66                                         |
| 4            | 13:05                  | 8             | 259                | 1.2                                    | 1.7                                         | 774.8                             | 100                 | 86     | 239                   | 63                                         |
| 5            | 13:07                  | 8             | 264                | 1.1                                    | 1.4                                         | 776.3                             | 102                 | 84     | 254                   | 62                                         |
| 1            | 13:08                  | 7             | 269                | 0.95                                   | 1.4                                         | 777.8                             | 102                 | 88     | 261                   | 66                                         |
| 2            | 13:12                  | 9             | 279                | 1.3                                    | 1.9                                         | 779.3                             | 106                 | 88     | 265                   | 64                                         |
| 3            | 13:14                  | 9             | 282                | 1.1                                    | 1.4                                         | 780.9                             | 108                 | 88     | 262                   | 63                                         |
| 4            | 13:16                  | 8             | 284                | 0.93                                   | 1.3                                         | 782.3                             | 110                 | 90     | 262                   | 63                                         |
| 5            | 13:18                  | 8             | 285                | 0.90                                   | 1.3                                         | 783.7                             | 110                 | 90     | 261                   | 64                                         |
|              |                        |               |                    |                                        |                                             |                                   |                     |        |                       |                                            |
|              |                        |               |                    |                                        |                                             |                                   |                     |        |                       |                                            |
|              |                        |               |                    |                                        |                                             |                                   |                     |        |                       |                                            |
|              |                        |               |                    |                                        |                                             |                                   |                     |        |                       |                                            |

**RAMCON** emissions test log sheet, cont. DATE 12-7-92 LOCATION MAGNETHACT TEST NO. /

| TRAVERSE POINT | SAMPLING TIME (min) | VACUUM (in. Hg) | STACK TEMP (°F) | VELOCITY HEAD (ft/min) | ORIFICE DIFF. PRESSURE (in. H <sub>2</sub> O) | GAS VOLUME V <sub>m</sub> (ft. <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |     | SAMPLE BOX TEMP. (°F) | IMPIRGER TEMP (°F) |
|----------------|---------------------|-----------------|-----------------|------------------------|-----------------------------------------------|-----------------------------------------------|-----------------------|-----|-----------------------|--------------------|
|                |                     |                 |                 |                        |                                               |                                               |                       | out |                       |                    |
| 1              | 13:17               | 8               | 287             | 1.0                    | 1.5                                           | 785.1                                         | 110                   | 92  | 238                   | 65                 |
| 2              | 13:23               | 8               | 288             | .93                    | 1.3                                           | 786.5                                         | 112                   | 92  | 235                   | 63                 |
| 3              | 13:25               | 5               | 285             | .60                    | .87                                           | 787.7                                         | 112                   | 92  | 231                   | 63                 |
| 4              | 13:27               | 5               | 352             | .60                    | .87                                           | 788.8                                         | 112                   | 92  | 240                   | 64                 |
| 5              | 13:29               | 4               | 352             | .40                    | .58                                           | 789.7                                         | 114                   | 94  | 252                   | 65                 |
| 1              | 13:31               | 8               | 345             | 1.0                    | 1.5                                           | 791.2                                         | 114                   | 94  | 258                   | 67                 |
| 2              | 13:35               | 8               | 356             | .95                    | 1.4                                           | 792.6                                         | 114                   | 94  | 267                   | 64                 |
| 3              | 13:37               | 7               | 355             | .85                    | 1.2                                           | 794.0                                         | 114                   | 94  | 255                   | 65                 |
| 4              | 13:39               | 5               | 352             | .60                    | .87                                           | 795.2                                         | 116                   | 96  | 253                   | 65                 |
| 5              | 13:41               | 5               | 346             | .71                    | 1.0                                           | 796.3                                         | 116                   | 96  | 247                   | 67                 |
| 6              | 13:42               | 7               | 340             | 1.3                    | 1.9                                           | 797.7                                         | 116                   | 96  | 247                   | 63                 |
| 2              | 13:46               | 12              | 338             | 1.5                    | 2.2                                           | 799.4                                         | 116                   | 96  | 247                   | 62                 |
| 3              | 13:48               | 10              | 337             | 1.2                    | 1.7                                           | 801.0                                         | 116                   | 96  | 246                   | 61                 |
| 4              | 13:50               | 8               | 353             | .95                    | 1.4                                           | 802.5                                         | 116                   | 96  | 246                   | 61                 |
| 5              | 13:52               | 7               | 349             | .80                    | 1.2                                           | 803.9                                         | 116                   | 96  | 239                   | 63                 |
| 1              | 13:53               | 17              | 323             | 1.8                    | 2.6                                           | 806.0                                         | 116                   | 96  | 237                   | 61                 |
| 2              | 13:57               | 14              | 305             | 1.5                    | 2.2                                           | 807.7                                         | 116                   | 96  | 233                   | 59                 |
| 3              | 13:59               | 14              | 291             | 1.5                    | 2.2                                           | 809.5                                         | 116                   | 96  | 231                   | 59                 |
| 4              | 14:01               | 14              | 296             | 1.6                    | 2.3                                           | 811.3                                         | 116                   | 96  | 230                   | 59                 |
| 5              | 14:03               | 15              | 352             | 1.6                    | 2.3                                           | 813.219                                       | 116                   | 96  | 238                   | 59                 |

Plant MACASDUALTOperator T. CrookDate 12-7-92

Run No. 2

Sample Box No. 1

**Meter Box No.**

Meter H @ 2587

|          |      |
|----------|------|
| C Factor | .580 |
|----------|------|

Pitot Tube Coeff

Ambient Temperature

### Barometric Pressure

Assumed Moisture, 8-

Probe Length, m(ft)

## Nozzle Identification

**Avg. Calibrated Nozzle**

## Probe Heater Settings

Leak Rate:  $\text{m}^3/\text{min}$ . (c)

Probe Liner Material: (K...

Static Pressure. mm

Filter No. T5/

Filter No. TS6

### Schematic of Stack Cross Section

Counters

[illegible]

Form #REC-05

MACASFLT



**RAMCON** emissions test log sheet, cont. DATE 12-7-92 LOCATION MAC ASPLANT TEST NO. 2  
CRESS CITY, FLA

| TRAVERSE POINT | SAMPLING TIME (min) | VACUUM (in. Hg) | STACK TEMP (°F) | VELOCITY HEAD (in. H <sub>2</sub> O) | ORIFICE DIFF. PRESSURE (in. H <sub>2</sub> O) | GAS VOLUME V <sub>m</sub> (ft. <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |     | SAMPLE BOX TEMP. (°F) | IMPINGER TEMP (°F) |
|----------------|---------------------|-----------------|-----------------|--------------------------------------|-----------------------------------------------|-----------------------------------------------|-----------------------|-----|-----------------------|--------------------|
|                |                     |                 |                 |                                      |                                               |                                               | in                    | out |                       |                    |
| 1              | 15:20               | 6               | 267             | 1.2                                  | 1.7                                           | 325.9                                         | 117                   | 94  | 254                   | 65                 |
| 2              | 15:24               | 7               | 274             | 1.4                                  | 2.0                                           | 327.6                                         | 123                   | 97  | 251                   | 63                 |
| 3              | 15:26               | 6               | 274             | 1.1                                  | 1.6                                           | 328.9                                         | 125                   | 98  | 247                   | 63                 |
| 4              | 15:28               | 5               | 273             | .93                                  | 1.3                                           | 330.2                                         | 126                   | 99  | 248                   | 64                 |
| 5              | 15:30               | 5               | 271             | .90                                  | 1.3                                           | 331.5                                         | 126                   | 100 | 249                   | 65                 |
| 1              | 15:31               | 9               | 263             | 1.1                                  | 1.6                                           | 332.7                                         | 125                   | 102 | 245                   | 66                 |
| 2              | 15:35               | 7               | 272             | 1.5                                  | 2.1                                           | 334.2                                         | 128                   | 102 | 245                   | 65                 |
| 3              | 15:37               | 6               | 271             | 1.1                                  | 1.6                                           | 335.6                                         | 129                   | 102 | 244                   | 66                 |
| 4              | 15:39               | 6               | 267             | .92                                  | 1.3                                           | 337.0                                         | 130                   | 103 | 241                   | 66                 |
| 5              | 15:41               | 5               | 266             | .88                                  | 1.2                                           | 338.2                                         | 130                   | 104 | 247                   | 67                 |
| 1              | 15:42               | 7               | 267             | 1.5                                  | 2.1                                           | 339.8                                         | 128                   | 105 | 253                   | 67                 |
| 2              | 15:46               | 7               | 270             | 1.5                                  | 2.1                                           | 341.5                                         | 131                   | 105 | 251                   | 63                 |
| 3              | 15:48               | 7               | 269             | 1.4                                  | 2.0                                           | 343.1                                         | 134                   | 106 | 248                   | 62                 |
| 4              | 15:50               | 6               | 267             | 1.0                                  | 1.4                                           | 344.5                                         | 134                   | 107 | 245                   | 63                 |
| 5              | 15:51               | 5               | 247             | .80                                  | 1.1                                           | 345.8                                         | 116                   | 107 | 258                   | 67                 |
| 1              | 15:57               | 9               | 262             | 2.0                                  | 2.9                                           | 347.7                                         | 124                   | 108 | 243                   | 67                 |
| 2              | 16:01               | 10              | 267             | 2.2                                  | 3.2                                           | 349.6                                         | 134                   | 108 | 264                   | 65                 |
| 3              | 16:03               | 10              | 268             | 2.2                                  | 3.2                                           | 351.6                                         | 136                   | 108 | 261                   | 64                 |
| 4              | 16:05               | 9               | 269             | 1.8                                  | 2.6                                           | 353.6                                         | 138                   | 109 | 261                   | 65                 |
| 5              | 16:07               | 9               | 269             | 1.8                                  | 2.6                                           | 355.2                                         | 138                   | 109 | 262                   | 66                 |

**RAMCON ENVIRONMENTAL CORPORATION**

Plant MACADAMIA -

Location Pres. City, Fla

Operator T. Miller

Date 10-8-92

Run No.  Sample Box No. /

sample box No. 1  
Meter Box No. AN-2012

meter box no. 2582  
Meter H @

C Factor = 980

Pitot Tube Coefficient Cp. 84

## Condensables

## Schematic of Stack Cross Section

[illegible]

Form #REC-05

MACASF LT


275

**RAMCON** emissions test log sheet, cont. DATE 12-8-92 LOCATION MACASANT TEST NO. 3  
PROSODY

| TRAVERSE POINT | SAMPLING TIME (min) | VACUUM (in. Hg) | STACK TEMP (°F) | VELOCITY HEAD (in. H <sub>2</sub> O) | ORIFICE DIFF. PRESSURE (in. H <sub>2</sub> O) | GAS VOLUME V <sub>m</sub> (ft. <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |     | SAMPLE BOX TEMP. (°F) | IMPINGER TEMP (°F) |
|----------------|---------------------|-----------------|-----------------|--------------------------------------|-----------------------------------------------|-----------------------------------------------|-----------------------|-----|-----------------------|--------------------|
|                |                     |                 |                 |                                      |                                               |                                               | in                    | out |                       |                    |
| 01             | 9:41                | 6               | 250             | 1.3                                  | 1.9                                           | 373.4                                         | 83                    | 66  | 225                   | 50                 |
| 2              | 9:45                | 8               | 253             | 1.7                                  | 2.5                                           | 375.1                                         | 89                    | 66  | 226                   | 50                 |
| 3              | 9:47                | 7               | 257             | 1.3                                  | 1.9                                           | 376.6                                         | 94                    | 67  | 228                   | 50                 |
| 4              | 9:49                | 6               | 255             | 1.1                                  | 1.6                                           | 378.0                                         | 94                    | 66  | 230                   | 50                 |
| 5              | 9:51                | 6               | 254             | 1.0                                  | 1.5                                           | 379.4                                         | 97                    | 66  | 232                   | 50                 |
| 01             | 9:52                | 7               | 250             | 1.5                                  | 2.2                                           | 381.0                                         | 94                    | 66  | 235                   | 50                 |
| 2              | 9:56                | 7               | 257             | 1.5                                  | 2.2                                           | 382.5                                         | 102                   | 68  | 240                   | 49                 |
| 3              | 9:58                | 7               | 256             | 1.3                                  | 1.9                                           | 384.1                                         | 107                   | 70  | 240                   | 51                 |
| 4              | 10:00               | 6               | 254             | .95                                  | 1.4                                           | 385.4                                         | 109                   | 71  | 238                   | 53                 |
| 5              | 10:02               | 6               | 253             | .95                                  | 1.4                                           | 386.7                                         | 109                   | 70  | 245                   | 53                 |
| 01             | 10:03               | 8               | 257             | 1.5                                  | 2.2                                           | 388.4                                         | 104                   | 79  | 246                   | 55                 |
| 2              | 10:07               | 8               | 261             | 1.6                                  | 2.4                                           | 390.0                                         | 112                   | 81  | 257                   | 56                 |
| 3              | 10:09               | 8               | 261             | 1.5                                  | 2.2                                           | 391.7                                         | 115                   | 82  | 254                   | 56                 |
| 4              | 10:11               | 6               | 259             | 1.1                                  | 1.6                                           | 393.1                                         | 116                   | 83  | 248                   | 55                 |
| 5              | 10:13               | 6               | 256             | 1.1                                  | 1.6                                           | 394.5                                         | 114                   | 85  | 246                   | 55                 |
| 01             | 10:14               | 12              | 265             | 2.3                                  | 3.4                                           | 396.5                                         | 112                   | 86  | 266                   | 54                 |
| 2              | 10:18               | 12              | 264             | 2.3                                  | 3.4                                           | 398.4                                         | 117                   | 87  | 272                   | 58                 |
| 3              | 10:20               | 12              | 268             | 2.3                                  | 3.4                                           | 400.6                                         | 120                   | 87  | 267                   | 59                 |
| 4              | 10:24               | 11              | 265             | 2.0                                  | 2.9                                           | 402.4                                         | 122                   | 88  | 264                   | 276                |
| 5              | 10:24               | 11              | 263             | 2.0                                  | 2.9                                           | 404.7                                         | 122                   | 90  | 248                   | 60                 |

## **IX. FIELD DATA**

### **E. Formaldehyde**

Plant MACASFT4Location CROSS CITY, FLAOperator DRDate 12-9-92Run No. 1Sample Box No. 1Meter Box No. ALBANYMeter H @ 1.532C Factor 1.532Pitot Tube Coefficient Cp .84Ambient Temperature 60Barometric Pressure 30.12Assumed Moisture, % 2.2Probe Length, m(ft) 4.71Nozzle Identification No. 2014Avg. Calibrated Nozzle Dia., (in.) 0.005Probe Heater Setting 10"Leak Rate, m<sup>3</sup>/min. (cfm) 0.005Probe Liner Material PYREXStatic Pressure, mm Hg (in. Hg) 0.005Filter No. 0.005

Schematic of Stack Cross Section

FORM MLD-4002

| TRAV. PT<br>NO. | SAMPLING<br>TIME<br>( $\phi$ ) min. | VACUUM<br>in. Hg | STACK<br>TEMP<br>( $T_s$ ) | VELOCITY<br>HEAD<br>( $P_g$ )<br>in. H <sub>2</sub> O | PRESSURE<br>DIFF. ORF.<br>MTR | GAS<br>SAMPLE<br>VOLUME<br>ft <sup>3</sup> | GAS SAMPLE TEMP.<br>AT DRY GAS METER |        | FILTER<br>HOLDER<br>TEMP<br>°F | GAS TEMP LVG<br>CONDENSER OR<br>LAST IMPINGER<br>°F |
|-----------------|-------------------------------------|------------------|----------------------------|-------------------------------------------------------|-------------------------------|--------------------------------------------|--------------------------------------|--------|--------------------------------|-----------------------------------------------------|
|                 |                                     |                  |                            |                                                       |                               |                                            | Inlet                                | Outlet |                                |                                                     |
| A-1             | <del>12:18</del><br>12:50           | 7                | 260                        | 1.8                                                   | 3.9                           | <del>632.7</del><br>632.7                  | 93                                   | 87     | NA                             | 66                                                  |
| 2               | 12:52                               | 8                | 269                        | 2.0                                                   | 4.4                           | 632.9                                      | 101                                  | 87     | NA                             | 63                                                  |
| 3               | 12:54                               | 7                | 268                        | 1.7                                                   | 3.7                           | 635.0                                      | 106                                  | 86     | NA                             | 59                                                  |
| 4               | 12:56                               | 6                | 268                        | 1.3                                                   | 2.8                           | 638.9                                      | 109                                  | 86     | NA                             | 60                                                  |
| 5               | 12:58                               | 5                | 266                        | 1.1                                                   | 2.4                           | 638.5                                      | 112                                  | 86     | NA                             | 57                                                  |
| B-1             | <del>12:57</del><br>13:01           | 6                | 264                        | 1.6                                                   | 3.5                           | 640.5                                      | 111                                  | 87     | NA                             | 61                                                  |
| 2               | 13:03                               | 4                | 265                        | 1.5                                                   | 3.3                           | 642.5                                      | 115                                  | 87     | NA                             | 58                                                  |
| 3               | 13:05                               | 5                | 268                        | 1.0                                                   | 2.2                           | 644.2                                      | 118                                  | 88     | NA                             | 58                                                  |
| 4               | 13:07                               | 4                | 266                        | .90                                                   | 2.0                           | 645.6                                      | 117                                  | 89     | NA                             | 57                                                  |
| 5               | 13:09                               | 4                | 267                        | .90                                                   | 1.9                           | 647.1                                      | 118                                  | 90     | NA                             | 58                                                  |
|                 |                                     |                  |                            |                                                       |                               |                                            |                                      |        |                                |                                                     |
|                 |                                     |                  |                            |                                                       |                               |                                            |                                      |        |                                |                                                     |
|                 |                                     |                  |                            |                                                       |                               |                                            |                                      |        |                                |                                                     |
|                 |                                     |                  |                            |                                                       |                               |                                            |                                      |        |                                |                                                     |

RAMCON emissions test log sheet, cont. DATE 12-9-92 LOCATION Massachusetts TEST NO. 1Mass City, Pa

| TRAVERSE POINT | SAMPLING TIME (min) | VACUUM (in. Hg) | STACK TEMP (°F) | VELOCITY HEAD (ft/min) | ORIFICE DIFF. PRESSURE (in. H <sub>2</sub> O) | GAS VOLUME Vm (ft <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |          | SAMPLE BOX TEMP. (°F) | IMPINGER TEMP. (°F) |
|----------------|---------------------|-----------------|-----------------|------------------------|-----------------------------------------------|----------------------------------|-----------------------|----------|-----------------------|---------------------|
|                |                     |                 |                 |                        |                                               |                                  | Gas                   | Impinger |                       |                     |
| 01             | 13:10               | 5               | 258             | 1.2                    | 2.0                                           | 684.9                            | 117                   | 92       | NA                    | 60                  |
| 2              | 13:14               | 6               | 270             | 1.4                    | 3.1                                           | 650.8                            | 120                   | 92       | NA                    | 58                  |
| 3              | 13:16               | 5               | 270             | 1.2                    | 2.4                                           | 652.5                            | 122                   | 92       | NA                    | 57                  |
| 4              | 13:18               | 4               | 269             | .92                    | 2.0                                           | 654.2                            | 122                   | 93       | NA                    | 57                  |
| 5              | 13:20               | 4               | 264             | .80                    | 1.8                                           | 655.5                            | 122                   | 93       | NA                    | 57                  |
| D1             | 13:21               | 6               | 268             | 1.4                    | 3.1                                           | 657.5                            | 115                   | 94       | NA                    | 63                  |
| 2              | 13:25               | 6               | 268             | 1.5                    | 3.3                                           | 659.5                            | 124                   | 94       | NA                    | 58                  |
| 3              | 13:27               | 6               | 268             | 1.7                    | 2.6                                           | 661.2                            | 124                   | 95       | NA                    | 58                  |
| 4              | 13:29               | 5               | 268             | 1.0                    | 2.2                                           | 662.9                            | 126                   | 96       | NA                    | 59                  |
| 5              | 13:31               | 4               | 266             | .85                    | 1.8                                           | 664.3                            | 125                   | 96       | NA                    | 60                  |
| E1             | 13:32               | 6               | 269             | 1.4                    | 3.1                                           | 666.4                            | 115                   | 96       | NA                    | 63                  |
| 2              | 13:34               | 7               | 270             | 1.6                    | 3.5                                           | 668.4                            | 127                   | 97       | NA                    | 53                  |
| 3              | 13:38               | 6               | 265             | 1.3                    | 2.9                                           | 670.2                            | 129                   | 98       | NA                    | 58                  |
| 4              | 13:40               | 5               | 263             | 1.1                    | 2.4                                           | 671.9                            | 129                   | 98       | NA                    | 58                  |
| 5              | 13:42               | 4               | 261             | 1.0                    | 2.2                                           | 673.6                            | 127                   | 98       | NA                    | 59                  |
| F1             | 13:43               | 11              | 269             | 2.3                    | 5.1                                           | 676.0                            | 126                   | 99       | NA                    | 60                  |
| 2              | 13:47               | 11              | 273             | 2.3                    | 5.1                                           | 678.5                            | 130                   | 99       | NA                    | 60                  |
| 3              | 13:49               | 9               | 272             | 2.0                    | 4.4                                           | 680.8                            | 133                   | 99       | NA                    | 60                  |
| 4              | 13:51               | 8               | 268             | 1.7                    | 3.7                                           | 682.9                            | 134                   | 99       | NA                    | 61                  |
| 5              | 13:53               | 8               | 264             | 1.7                    | 3.7                                           | 685.041                          | 133                   | 100      | NA                    | 62                  |

Piant MacAspwa

Location C-Ross, City, FLA

Operator T. Clark

Date 12-5-92Run No. 2

**Sample Box No.**

Meter Box No. ANDERSEN

Meter H @ 1852

C Factor 5.80

Pitot Tube Coefficient  $C_p$  .84

FORMICIDE HND

## Schematic of Stack Cross Section

[illegible]

RAMCON emissions test log sheet, cont. DATE 12-9-92 LOCATION MAAPASHAULT TEST NO. 2  
 FORMAN, DENISE CROSS CITY, FLA

| TRAVERSE POINT | SAMPLING TIME (min) | VACUUM (in. Hg) | STACK TEMP | VELOCITY HEAD | ORFICE DIFF. PRESSURE | GAS VOLUME Vm (ft <sup>3</sup> ) | GAS SAMPLE TEMP. (°F) |    | SAMPLE BOX TEMP. (°F) | IMPIGNER TEMP (°F) |
|----------------|---------------------|-----------------|------------|---------------|-----------------------|----------------------------------|-----------------------|----|-----------------------|--------------------|
|                |                     |                 |            |               |                       |                                  |                       |    |                       |                    |
| 01             | 14:51               | 3               | 275        | 1.1           | 2.6                   | 706.4                            | 112                   | 89 | NA                    | 63                 |
| 2              | 14:55               | 3               | 277        | 1.2           | 2.9                   | 708.5                            | 116                   | 89 | NA                    | 63                 |
| 3              | 14:57               | 3               | 278        | .90           | 2.2                   | 710.1                            | 119                   | 89 | NA                    | 64                 |
| 4              | 14:59               | 3               | 277        | .80           | 1.9                   | 711.6                            | 118                   | 90 | NA                    | 64                 |
| 5              | 15:01               | 3               | 277        | .97           | 2.3                   | 713.3                            | 119                   | 91 | NA                    | 66                 |
| D1             | 15:02               | 4               | 278        | 1.5           | 3.6                   | 715.4                            | 113                   | 91 | NA                    | 68                 |
| 2              | 15:06               | 4               | 280        | 1.4           | 3.4                   | 717.4                            | 120                   | 92 | NA                    | 60                 |
| 3              | 15:08               | 3               | 280        | 1.1           | 2.6                   | 719.2                            | 122                   | 92 | NA                    | 63                 |
| 4              | 15:10               | 3               | 278        | 1.0           | 2.4                   | 721.8                            | 122                   | 93 | NA                    | 63                 |
| 5              | 15:12               | 3               | 275        | .87           | 2.1                   | 722.4                            | 122                   | 94 | NA                    | 63                 |
| E1             | 15:13               | 4               | 277        | 1.4           | 3.4                   | 724.5                            | 116                   | 95 | NA                    | 67                 |
| 2              | 15:17               | 4               | 279        | 1.5           | 3.6                   | 726.6                            | 123                   | 95 | NA                    | 63                 |
| 3              | 15:19               | 4               | 276        | 1.2           | 2.9                   | 728.5                            | 124                   | 96 | NA                    | 61                 |
| 4              | 15:21               | 3               | 272        | .93           | 2.4                   | 730.3                            | 123                   | 96 | NA                    | 62                 |
| 5              | 15:23               | 3               | 271        | .85           | 2.0                   | 731.7                            | 122                   | 97 | NA                    | 62                 |
| 1              | 15:24               | 6               | 277        | 2.2           | 5.3                   | 734.1                            | 121                   | 97 | NA                    | 64                 |
| 2              | 15:28               | 5               | 279        | 2.0           | 4.8                   | 736.6                            | 125                   | 97 | NA                    | 58                 |
| 3              | 15:30               | 5               | 279        | 2.0           | 4.8                   | 738.9                            | 124                   | 98 | NA                    | 59                 |
| 4              | 15:32               | 4               | 276        | 1.5           | 3.6                   | 741.0                            | 126                   | 98 | NA                    | 60                 |
| 5              | 15:34               | 4               | 276        | 1.4           | 3.4                   | 743.024                          | 126                   | 98 | NA                    | 61                 |

280



Plant MAC ASPHALT

Location Chessey, FLA

Operator T. C. CookDate 12-9-92Run No. 3

**Sample Box No.**

Meter Box No. ANDERSEN

Meter H @ 258.7

C Factor .580Pitot Tube Coefficient  $C_p$  .84

### Ambient Temperature

## Barometric Pressure

Assumed Moisture, %

Probe Length, m (ft)

Nozzle Identification No. 0003713

**Avg. Calibrated Nozzle Dia., (in.)** 0.061

Probe Heater Setting 4/Leak Rate, m<sup>3</sup>/min. (cfm) 0.17 @ 10"Probe Liner Material PVREX

Static Pressure, mm Hg (in. Hg)

Filter No.

## Schematic of Stack Cross Section

## Formaldehyde

[illegible]

RAMCON emissions test log sheet, cont. DATE 12-5-92 LOCATION MAGNET TEST NO. 3  
CRASH OUT, FLA

[illegible]

# OPERATING INFORMATION FOR STACK TESTED HOT MIX

DATE: 7/7/77

TEL NO. 3017314831

COMPANY NAME: APAC / Mc. Asph. P. Co.

COMPANY REP: \_\_\_\_\_

LOCATION OF HMA FACILITY: Davey Const. F. 10000

MODEL: Aster DH B-1

AC Type: \_\_\_\_\_ Mix Type: \_\_\_\_\_

Record Ambient Temperature At: \_\_\_\_\_

Startup \_\_\_\_\_ Mid-day \_\_\_\_\_ Shutdown \_\_\_\_\_

Record Relative Humidity (%) at: \_\_\_\_\_

Startup \_\_\_\_\_ Mid-day \_\_\_\_\_ Shutdown \_\_\_\_\_

TYPE OF CONTROL EQUIPMENT: \_\_\_\_\_

TYPE OF FUEL USED DURING TESTING: \_\_\_\_\_ FUEL UNIT: \_\_\_\_\_

Name & Phone of Individual(s) recording operating information: \_\_\_\_\_

| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 |
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|

## MATERIALS PROCESSED (standard test procedures)

| Time           | Fuel Used (standard) | Aggregate | RAP  | AC   | Mix Exhaust Temperature | Mix Temperature | Stack Temp | Baghouse Temp | Baghouse % closed | Baghouse Settling % | Baghouse Moisture Data | THC (ppm) | Other |
|----------------|----------------------|-----------|------|------|-------------------------|-----------------|------------|---------------|-------------------|---------------------|------------------------|-----------|-------|
| 24 hour        | 41.2 Diesel          |           |      |      |                         |                 |            |               |                   |                     |                        |           |       |
| 11:05          |                      | 112.4     | 66.0 | 12.0 | 300                     | 302             | 390        | 310           | 47                | 0.20                | 4                      |           |       |
| 11:15          |                      | 116.0     | 71.1 | 12.4 | 202                     | 308             | 394        | 317           | 47                | 0.16                | 4                      |           |       |
| Speed Up 11:30 | 11:30 2100           | 132       | 68   | 12   | 205                     | 292             | 391        | 316           | 47                | .18                 | 4                      |           |       |
| 11:45          |                      | 122       | 65   | 12   | 207                     | 285             | 396        | 319           | 51                | .18                 | 4                      |           |       |
| Shutdown 11:47 | 11:47 12:55          | 100       | 62   | 10.8 | 172                     | 307             | 369        | 270           | 46                | .16                 | 4                      |           |       |
| 12:00          |                      | 107       | 60   | 11.3 | 188                     | 305             | 413        | 317           | 48                | .16                 | 4                      |           |       |
| 12:15          |                      | 115       | 70   | 12   | 200                     | 310             | 406        | 323           | 48                | .18                 | 4                      |           |       |
| 12:30          |                      | 129       | 74   | 13   | 210                     | 295             | 408        | 329           | 52                | .19                 | 4                      |           |       |
| 12:45          |                      | 130       | 74   | 13   | 220                     | 295             | 411        |               | 55                | .19                 | 3.5                    |           |       |
| 2:00           |                      | 124       | 80   | 13.5 | 202                     | 305             | 424        | 339           | 57                | .16                 | 3.5                    |           |       |
| 2:15           |                      | 128       | 79   | 13.8 | 230                     | 312             | 422        | 339           | 57                | .18                 | 3.5                    |           |       |
| 2:30           |                      |           |      |      |                         |                 |            |               |                   |                     |                        |           | 283   |

Baghouse  
Settling  
Outlet

Baghouse  
Moisture Data  
As Dep.



# OPERATING INFORMATION FOR STACK TESTED HOT MIX ASPHALT FACILITY

DATE: 8/10/80

COMPANY NAME: GPCAC / Mc. Nelly's

COMPANY REP:

LOCATION OF HMA FACILITY: One County, FL

OEM:

PHONE:

AC Type:

Mix Type:

MODEL:

The loader operator was observed removing aggregate from the stockpiles at (circle): bottom side

TYPE OF CONTROL EQUIPMENT:

TYPE OF FUEL USED DURING TESTING:

FUEL UNIT:

## WEATHER INFORMATION

Record Ambient Temperature At:

Startup Mid-day Shutdown

Record Relative Humidity (%) at:

Startup Mid-day Shutdown

Name & Phone of individual(s) recording operating information:

| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 |
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|

## MATERIALS PROCESSED (rounded less production)

Boyle to generate PRINT-OUTS >> ☐ Not available Boyle

| Time  | Prod Used (combustion) | Aggregate | RAP  | AC  | Mix Temperature | Mix Moisture | Stack Temp | Boiler Temp | Boiler Solids % | Boiler Solids in H <sub>2</sub> O | Boiler Solids in H <sub>2</sub> O (combustion) | THC (gpm) | Other |
|-------|------------------------|-----------|------|-----|-----------------|--------------|------------|-------------|-----------------|-----------------------------------|------------------------------------------------|-----------|-------|
| 8:30  | 101                    | 59        | 10.1 | 175 | 300             | 285          | 371        | 295         | 38              | 14                                | 4                                              |           |       |
| 8:45  | 103                    | 60        | 11   | 177 | 285             | 350          | 385        | 350         | 38              | 16                                | 4                                              |           |       |
| 9:00  | 109                    | 64        | 11.4 | 182 | 298             | 357          | 359        | 289         | 42              | 14                                | 4                                              |           |       |
| 9:15  | 112                    | 66        | 11.9 | 194 | 291             | 353          | 386        | 286         | 45              | 15                                | 4                                              |           |       |
| 9:30  | 110                    | 64        | 11.7 | 191 | 310             | 361          | 290        | 290         | 45              | 14                                | 4                                              |           |       |
| 9:45  | 106                    | 59        | 11.0 | 185 | 307             | 369          | 300        | 300         | 38              | 14                                | 4                                              |           |       |
| 10:00 | 107                    | 60        | 11.2 | 181 | 310             | 361          | 301        | 301         | 44              | 14                                | 4                                              |           |       |
| 10:15 | 106                    | 59        | 11.0 | 185 | 307             | 369          | 300        | 300         | 38              | 14                                | 4                                              |           |       |
| 10:30 | 107                    | 60        | 11.2 | 181 | 310             | 361          | 301        | 301         | 44              | 14                                | 4                                              |           |       |
| 10:45 | 106                    | 59        | 11.0 | 185 | 307             | 369          | 300        | 300         | 38              | 14                                | 4                                              |           |       |
| 11:00 | 107                    | 60        | 11.2 | 181 | 310             | 361          | 301        | 301         | 44              | 14                                | 4                                              |           |       |
| 11:15 | 106                    | 59        | 11.0 | 185 | 307             | 369          | 300        | 300         | 38              | 14                                | 4                                              |           |       |
| 11:30 | 107                    | 60        | 11.2 | 181 | 310             | 361          | 301        | 301         | 44              | 14                                | 4                                              |           | 285   |

[illegible]

1

|                                                                                                             |  |            |           |
|-------------------------------------------------------------------------------------------------------------|--|------------|-----------|
| COMPANY NAME: NPAC / MacDonnell Division                                                                    |  |            |           |
| COMPANY REP:                                                                                                |  | PHONE:     |           |
| LOCATION OF HMA FACILITY: Davis County, IL                                                                  |  | AC Type:   | Mix Type: |
| OEM:                                                                                                        |  | MODEL:     |           |
| The loader operation was observed removing aggregate from the stockpiles at (circle):      bottom      side |  |            |           |
| TYPE OF CONTROL EQUIPMENT:                                                                                  |  |            |           |
| TYPE OF FUEL USED DURING TESTING:                                                                           |  | FUEL UNIT: |           |

Name &amp; Phone of Individual(s) recording operating information:

|   |   |   |   |   |   |   |   |   |    |    |    |    |    |
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 |
|---|---|---|---|---|---|---|---|---|----|----|----|----|----|

| MATERIALS PROCESSED<br>(combined into preheated) |                           |           |      |      |                    |                    |                      |                         |                   | Bay house<br>← Resumes to generate<br>T-let C-let |                           | PRINT-OUTS >> <input type="checkbox"/> Not available |       | Page of |  |
|--------------------------------------------------|---------------------------|-----------|------|------|--------------------|--------------------|----------------------|-------------------------|-------------------|---------------------------------------------------|---------------------------|------------------------------------------------------|-------|---------|--|
| Time                                             | Fuel Used<br>(uncombined) | Aggregate | RAP  | AC   | Mix<br>Temperature | Mix<br>Temperature | Steel<br>Temperature | Concrete<br>Temperature | Burner<br>Sooting | Burner<br>Composition                             | Burner<br>Monitoring Data | THC (ppm)                                            | Other |         |  |
| 20 min                                           |                           | unf       | unf  | unf  | 172                | 178                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 9:15                                             | Plant                     | started   | 58   | 10.7 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 9:30                                             | Burner                    | 4:38      | 4:38 | 10.7 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 9:45                                             | Burner                    | 4:48      | 4:48 | 11.0 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 10:00                                            | Burner                    | 4:58      | 4:58 | 11.6 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 10:15                                            |                           | 105       | 59   | 10.9 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 10:30                                            |                           | 102       | 60   | 10.8 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 10:45                                            |                           | 98        | 57   | 10.6 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 11:00                                            |                           | 102       | 63   | 11.1 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 11:15                                            |                           | 101       | 66   | 11.4 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 11:30                                            |                           | 113       | 65   | 11.7 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 11:45                                            |                           | 115       | 69   | 12.0 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |
| 12:00                                            |                           | 107       | 67   | 11.7 | 312                | 312                | 367                  | 382                     | 49.7              | 0.14                                              | 4                         |                                                      |       |         |  |

| PAINT-OUTS | Not available |
|------------|---------------|
| 1          | Not available |

ter Ende: 1. Generat

**MATERIALS PROCESSED**  
(compulsated 'one produced/used')

| Time  | Fuel Used<br>(recombined) | Average | RAP | AC   | Exhaust-<br>Temperature | Exhaust-<br>Temp °F | Stack<br>Pressure<br>in. wg | % closed | Blower<br>Speed<br>RPM | Blower<br>Current<br>Amps | THC (ppm) | Other |
|-------|---------------------------|---------|-----|------|-------------------------|---------------------|-----------------------------|----------|------------------------|---------------------------|-----------|-------|
| 12:15 |                           | 103     | 67  | 11.6 | 183                     | 307                 | 370                         | 301      | 49                     | 0.12                      | 4         |       |
| 12:30 |                           | 111     | 70  | 11.9 | 186.8                   | 308                 | 371                         | 302      | 50                     | 0.14                      | 4         |       |
| 12:45 |                           | 107     | 63  | 11.2 | 184.9                   | 339                 | 370                         | 303      | 49                     | 0.14                      | 4         |       |
| 1:00  |                           | 109     | 64  | 11.4 | 185                     | 313                 | 356                         | 296      | 49                     | 0.14                      | 4.5       |       |
| 1:15  |                           | 114     | 70  | 12.2 | 193                     | 312                 | 367                         | 301      | 53                     | 0.14                      | 4.5       |       |
| 1:30  |                           | 116     | 69  | 12   | 197                     | 290                 | 365                         | 302      | 50                     | .14                       | 4.5       |       |
| 1:45  |                           | 119     | 68  | 12.3 | 201                     | 299                 | 368                         | 303      | 51                     | 0.14                      | 4.5       |       |
| 2:00  |                           | 118     | 70  | 12   | 202                     | 307                 | 370                         | 308      | 51                     | .14                       | 4.5       |       |
| 2:15  |                           |         |     |      |                         |                     |                             |          |                        |                           |           |       |
| 2:30  |                           | 121     | 70  | 12.8 | 210                     | 301                 | 376                         | 312      | 55                     | 0.14                      | 4         |       |
| 2:45  |                           | 125     | 75  | 13   | 213                     | 304                 | 380                         | 314      | 54                     | .14                       | 4         |       |
| 3:00  |                           | 126     | 76  | 13   | 215                     | 304                 | 380                         | 311      | 55                     | .14                       | 4         |       |
| 3:15  |                           | 126     | 75  | 13.3 | 217                     | 302                 | 380                         | 313      | 54                     | .14                       | 4         |       |
| 3:30  |                           | 125     | 79  | 13   | 214                     | 294                 | 378                         | 314      | 55                     | .14                       | 4         |       |
| 3:45  |                           | 126     | 79  | 13.4 | 210                     | 301                 | 379                         | 314      | 55                     | .14                       | 4         |       |
| 4:00  |                           | 127     | 76  | 13   | 214                     | 302                 | 379                         | 311      | 55                     | .14                       | 4         |       |
| 4:15  |                           | 130     | 77  | 13   | 226                     | 296                 | 380                         | 361      | 55                     | .18                       | 4         |       |
| 4:30  |                           | 133     | 79  | 14   | 225                     | 297                 | 378                         | 354      | 55                     | calculated 250<br>1.9     | 4         |       |
| 4:45  |                           | 137     | 12  | 14   | 223                     | 301                 | 379                         | 370      | 60.9                   | 1.4                       | 4         |       |
| 5:00  |                           | 134     | 81  | 14.1 | 224                     | 275                 | 377                         | 329      | 1                      | 0.14                      | 4         |       |



**Name:** Mr. Sumner Buck  
**Title:** President

**Qualifications:** Mr. Buck is a graduate of the University of Mississippi with graduate studies at Memphis State University and State Technical Institute of Memphis. He is a graduate of the EPA 450 "Source Sampling for Particulate Pollutant's" course and the 474 "Continuous Emissions Monitoring" courses outlined by EPA at Research Triangle Park, N.C. He has been directly involved in conducting and supervising air emission testing for over 15 years. He has personally conducted over 400 air emission tests. He currently sponsors and directs visual emission certification schools for US EPA Method 9.

**Project Duties:** Mr. Buck is responsible for the overall supervision of each testing project. This includes the correspondence to the State Regulatory Agency and the plant personnel regarding scheduling, testing requirements, etc. He will assist in supervision of the project preparation for each team involved and the overall organization between the testing crew(s) and facility.

**Name:** Mr. Joe Sewell  
**Title:** Vice President

**Qualifications:** Mr. Sewell is currently serving as the Vice President of RAMCON Environmental Corporation. Mr. Sewell is a graduate of Christian Brothers University in Memphis, Tennessee where he obtained a Bachelor of Science degree in Chemical Engineering. He has conducted and supervised air emissions testing projects ranging a broad spectrum of facility process categories. His accomplishments include the development of the instrumental branch of emissions testing utilizing continuous emission monitors and gas chromatography. Mr. Sewell performs a major role in the upgrading of testing capabilities and professional quality that RAMCON Environmental Corporation offers.

**Project Duties:** Mr. Sewell provides staff engineering and project administration to ensure the integrity of the requested services. He serves as the primary contact person for RAMCON Environmental Corporation handling all correspondence between the facility personnel involved in the project and respective state agency representative(s). He provides project leadership to RAMCON Environmental Corporation field supervisors and managers involved in the testing project.

**Name:** Mr. Ray Jenkins

**Title:** Source Sampling Director

**Qualifications:** Mr. Jenkins is serving as the Source Sampling Director for RAMCON Environmental Corporation. He was promoted to this leadership position after gaining a significant amount of experience in conducting and providing field supervision of a variety of air testing projects. Mr. Jenkins has personally conducted and/or supervised all of the prevalent EPA approved procedures with expertise in the instrumental analyzer procedures. He graduated from Memphis State University obtaining a Bachelor of Science degree in Biology. He is also currently certified to conduct US EPA Reference Method 9 for the visual determination of emission opacity.

**Project Duties:** Mr. Jenkins provides project leadership to the Team Leaders and Field Technicians. He ensures the test crew(s) involved in the test project will be properly informed to his respective duties and responsibilities during the testing process. Mr. Jenkins also serves as the Quality Assurance/Quality Control Coordinator and provides guidance in QA/QC to each Team Leader with regard to sample integrity.

**Name:** Mr. Tommy South  
**Title:** Laboratory Technician

**Qualifications:** Mr. South is currently serving as Laboratory Technician. He is proficient in conducting many analysis procedures such as front and back-half particulate analysis, titrations, extractions, etc.

**Project Duties:** Mr. South conducts the laboratory analysis on the particulate samples. He is also responsible for accepting the remaining field samples from the Field Sample Bank Manager and performing inspection as to integrity. He documents the transfer on the chain of custody forms and distributed the subcontracted samples to the respective laboratories.

**Name:** Mr. Tommy Crook  
**Title:** Team Leader

**Qualifications:** Mr. Crook has been employed by RAMCON Environmental Corporation for three years. He has completed Team Leader training in isokinetic and proportional test methods. He currently is certified in conducting US EPA Reference Method 9 for opacity. He has been involved in conducting tests on process stacks, incinerators, boilers, etc. He has served as a Field Technician for over two years.

**Project Duties:** Mr. Crook is responsible for conducting isokinetic sampling procedures at the facility(s). He is responsible for preparation, calibration and cleaning of the necessary equipment for this testing. His duties on-site include assembling the sample train, leak checking the system, operation of the train and recording the test data on the field data forms.

... developed by ...  
 ... and ...  
 ...  
 ...

...  
 ...  
 ...  
 ...

...  
 ...  
 ...

...  
 ...  
 ...  
 ...

**Name:** Mr. Mickey Phillips  
**Title:** Team Leader

**Qualifications:** Mr. Phillips has been employed by RAMCON Environmental Corporation for one year. He is proficient in isokinetic and proportional test methods. He currently is certified in conducting Method 9 for opacity. He has conducted over 100 stack tests on process stacks, incinerators, boilers, etc. and is qualified as a Team Leader.

**Project Duties:** Mr. Phillips is responsible for conducting isokinetic sampling procedures at the facility(s). He is responsible for preparation, calibration and cleaning of the necessary equipment for this testing. His duties on-site include assembling the sample train, leak checking the system, operation of the train and recording the test data on the field data forms.

**Name:** Mr. Michael Winkler  
**Title:** Team Leader

**Qualifications:** Mr. Winkler is a Team Leader and has completed training in isokinetic and proportional test methods. He received an Associate degree in Mechanical Engineering from State Technical Institute at Memphis, Tennessee.

**Project Duties:** Mr. Winkler is responsible for conducting isokinetic sampling procedures at the facility(s). He is also responsible for preparation, calibration and cleaning of the necessary equipment for this testing. His duties on-site include assembling the sample train, leak checking the system, operation of the train and recording the test data on the field data forms.