

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section	11.1
Reference	
Report Sect.	4
Reference	57

MMT Environmental Services, Inc.
4610 North Churchill Street
St. Paul, MN 55126-5892
Phone (612) 483-9595 Fax (612) 483-2699

DRAFT COPY

RESULTS OF A
SOURCE EMISSION COMPLIANCE TEST
ON A HOT-MIX ASPHALT PLANT
PROCESS SCRUBBER
OPERATED BY
L.C. KRUSE & SONS, INC.
WINDOM, MINNESOTA
June 9, 1993

Submitted to:

L.C. Kruse & Sons, Inc.
P.O. Box 899
Lakefield, MN 56150
Attn: Mr. Darrin L. Kruse

Prepared by:

Ted Gibbons
Ted Gibbons
Sampling Team Leader

Approved by:

Alan L. Trowbridge
Alan L. Trowbridge
Director of Technical Services

MMT Report Number: 9993
MMT Project Number: 9374
Report Issued: June 18, 1993

TABLE OF CONTENTS

1	INTRODUCTION	1
2	TEST RESULTS	1
3	PROCESS DATA	3
4	TEST PROCEDURES	4
	4.1 SAMPLING POINTS	4
	4.2 EFFLUENT VOLUMETRIC FLOW RATE.....	4
	4.3 EFFLUENT COMPOSITION AND MOLECULAR WEIGHT	4
	4.4 EFFLUENT MOISTURE CONTENT.....	4
	4.5 EFFLUENT PARTICULATE CONCENTRATION.....	6
	4.6 SOURCE PLUME OPACITY	8
5	QUALITY ASSURANCE.....	9
	5.1 SAMPLING QUALITY ASSURANCE	9
	5.2 ANALYTICAL QUALITY CONTROL.....	9

APPENDIX A: CALCULATIONS

APPENDIX B: FIELD DATA FORMS

APPENDIX C: LABORATORY REPORTS

APPENDIX D: CALIBRATION DATA

APPENDIX E: PROCESS DATA

APPENDIX F: TEST PLAN & PROTOCOL

**RESULTS OF A
SOURCE EMISSION COMPLIANCE TEST
ON A HOT-MIX ASPHALT PLANT PROCESS SCRUBBER
OPERATED BY
L.C. KRUSE & SONS, INC.
WINDOM, MINNESOTA
June 9, 1993**

MMT Report Number 9993
MMT Project Number 9374
Report Issued June 18, 1993

1 INTRODUCTION

MMT Environmental Services, Inc. (MMT) was contracted by L.C. Kruse & Sons Inc. to perform a source emission compliance test on a single source at their hot-mix asphalt plant operating in Windom, Minnesota. The plant is a Portec, Inc., Pioneer Division, model DM with serial number 113-36-DM-106. Emissions generated by the plant's aggregate/asphalt drum mix operation are controlled by a Barber-Greene model CC99X102 venturi scrubber. The scrubber exhaust was tested for particulate and visible emissions on June 9, 1993. This report presents the results of the test program along with all substantiating documentation.

The MMT sampling team consisted of Messrs. Ted Gibbons and Bill Anderson. Mr. Daniel D. Schultz represented L.C. Kruse & Sons, Inc. throughout the test period. The Minnesota Pollution Control Agency was invited to witness the test proceedings but declined to do so.

2 TEST RESULTS

The results of the particulate emission test are presented in Table 2.1. The data indicates an average effluent particulate concentration of 0.136 grains per dry standard cubic foot and an average source particulate emission rate of 30.54 pounds per hour.

The visible emission test was performed concurrent with the third particulate test run. The observed plume opacity ranged from five (5) to twenty (20) percent with an overall average of 9.5 percent.

The average process weight rate (aggregate + asphalt) during the test period was 285 tons per hour.

Minnesota Air Emission Permit number 323-B-89-OT-1 states that the asphalt concrete plant shall not exhaust any gases (1) which contain particulate matter in excess of 0.04 grains per dry standard cubic foot or (2) which exhibit 20 percent or greater opacity. The test data indicates that the source emissions did not comply with either of these standards during the test period.

Table 2.1
Summary of Particulate Emission Test Results
L.C. Kruse & Sons, Inc. Asphalt Plant, Windom, Minnesota
Aggregate/Asphalt Drum Mix Operation Scrubber Exhaust
June 9, 1993

Parameter	Run #1	Run #2	Run #3	Average
Time of Test, hr				
Start	1159	1330	1500	---
Finish	1311	1442	1612	---
Effluent Temperature, °F	182	184	180	182
Effluent Moisture Content, % v/v	37.4	37.0	37.9	37.4
Effluent Composition, % v/v dry:				
Carbon Dioxide Content	6.5	7.5	7.0	7.0
Oxygen Content	11.4	10.0	10.5	10.6
Effluent Volumetric Flow Rate:				
Actual Conditions, acfm	53,377	53,352	53,724	53,484
Standard Conditions, scfm	41,149	41,048	41,663	41,287
Dry Standard Conditions, dscfm	25,768	25,856	25,868	25,831
Sampling Isokinetic Variation, %	103.0	101.8	102.8	102.5
Effluent Particulate Concentration:				
Front Catch Only;				
Actual Conditions, gr/acf	0.0633	0.0570	0.0589	0.0597
Standard Conditions, gr/scf	0.0821	0.0741	0.0760	0.0774
Dry Standard Conditions, gr/dscf	0.1310	0.1176	0.1224	0.1237
Back Catch Only;				
Actual Conditions, gr/acf	0.0058	0.0054	0.0069	0.0060
Standard Conditions, gr/scf	0.0075	0.0070	0.0089	0.0078
Dry Standard Conditions, gr/dscf	0.0120	0.0111	0.0143	0.0125
Total Catch;				
Actual Conditions, gr/acf	0.0691	0.0624	0.0658	0.0658
Standard Conditions, gr/scf	0.0896	0.0811	0.0849	0.0852
Dry Standard Conditions, gr/dscf	0.1431	0.1287	0.1367	0.1362
Source Particulate Emission Rate:				
Classical Method, lb/hr	31.62	28.55	30.33	30.17
Ratio of Areas Method, lb/hr	32.56	29.03	31.16	30.92
Average of the Two Methods, lb/hr	32.09	28.79	30.75	30.54

Standard Conditions: 68°F, 29.92 in. Hg

3 PROCESS DATA

During the test period the burner on the plant's aggregate/asphalt drum mix operation was fired with waste oil. A sample of the fuel was collected but not analyzed (per Darrin Kruse 6/16/93).

Production data is presented in Appendix E and summarized in Table 3.1.

Table 3.1
Summary of Process Data
L.C. Kruse & Sons, Inc. Asphalt Plant, Windom, Minnesota
Aggregate/Asphalt Drum Mix Operation Scrubber Exhaust
June 9, 1993

Parameter	Run #1	Run #2	Run #3	Average
Time of Test, hr				
Start	1159	1330	1500	---
Finish	1311	1442	1612	---
Process Weight Rate;				
Aggregate Usage, ton/hr	267.5	267.8	266.0	267.1
Asphalt Usage, ton/hr	17.6	17.6	17.4	17.5
Total Process Weight Rate, ton/hr	285.1	285.4	283.4	284.6
Aggregate Moisture Content, %	6.0	5.6	5.6	5.7
Burner Setting, %	95	95	95	95
Product Mix Temperature, °F	270	268	268	269
Scrubber Operating Parameters;				
Pressure Drop, in WC	15	15	15	15
Water Flow Rate, gpm	350	350	350	350

4 TEST PROCEDURES

In order to determine the pollutant emission rate from stationary sources, the Environmental Protection Agency (EPA) has established a series of reference methods which specify the manner in which tests must be performed. These reference methods are found in the Code of Federal Regulations (40 CFR 60) under Title 40 "Protection of the Environment"; Chapter I "Environmental Protection Agency"; Subchapter C "Air Programs"; Part 60 "Standards of Performance for New Stationary Sources"; Appendix A "Reference Methods". Unless otherwise noted, the tests presented in this report were performed according to the EPA Reference Methods as revised on July 1, 1993. A brief description of the test procedures used follows.

4.1 SAMPLING POINTS

The number of sampling points and their location within the source stack/duct was determined per EPA Method 1 which is entitled "Sample and velocity traverses for stationary sources". In this method the number of sampling points is based on the length of straight, undisturbed flow both before and after the sampling port location. Site specific data is presented in Figure 4.1.

4.2 EFFLUENT VOLUMETRIC FLOW RATE

The effluent volumetric flow rate was determined per EPA Method 2 which is entitled "Determination of stack gas velocity and volumetric flow rate (Type S pitot tube)". Gas velocity pressure (head) and temperature data were obtained during each EPA Method 5 particulate test run by traversing each of the sampling points defined by EPA Method 1. This data along with gas density (EPA Method 3) and moisture content (EPA Method 4) data was used to calculate the gas velocity at each sampling point. The source volumetric flow rate was calculated by multiplying the average gas velocity by the stack/duct cross-sectional area at the point of measurement.



4.3 EFFLUENT COMPOSITION AND MOLECULAR WEIGHT

The density of the effluent was determined per EPA Method 3 which is entitled "Gas analysis for the determination of dry molecular weight". One grab sample was collected during each EPA Method 5 particulate test run. The gas samples were analyzed for carbon dioxide and oxygen concentrations with a standard Orsat analyzer using commercially prepared solutions. For calculations of gas density the balance of the gas was assumed to be nitrogen and carbon monoxide.

4.4 EFFLUENT MOISTURE CONTENT

The effluent moisture content was determined per EPA Method 4 which is entitled "Determination of moisture content in stack gases". Data for making the gas moisture content determinations was collected simultaneously with each EPA Method 5 particulate test run. The gas moisture content was calculated from the mass and/or volume of liquid collected in the Method 5 sampling train cold box impingers and the volume of gas sampled.

Figure 4.1 Site Description Form
L.C. Kruse & Sons, Inc. Asphalt Plant, Windom, Minnesota
Aggregate/Asphalt Drum Mix Operation Scrubber Exhaust
June 9, 1993

SAMPLING LOCATION DATA																										
Stack Cross-Sectional Dimension; Depth (traverse dimension), inches... 47.0 Width, inches..... 41.0 Equivalent diameter, inches..... 43.8 Length of straight, undisturbed flow; Before ports, inches..... 96.0 After ports, inches 36.0 Before ports, stack diameters..... 2.19 After ports, stack diameters 0.82	Number of sampling points; Required by EPA Method 1 25 Actually used 28 Number of ports 4 Number of points per port 7 Particulate test sampling time; Minutes per point: 2.5 Minutes per test run: 70.0																									
SAMPLING POINT LOCATION WITHIN STACK CROSS-SECTION																										
<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; width: 15%;">Point Number</th> <th style="text-align: left; width: 35%;">Percent of Traverse</th> <th style="text-align: left; width: 50%;">Inches from Wall</th> </tr> </thead> <tbody> <tr><td>1</td><td>7.14</td><td>3.4</td></tr> <tr><td>2</td><td>21.43</td><td>10.1</td></tr> <tr><td>3</td><td>35.71</td><td>16.8</td></tr> <tr><td>4</td><td>50.00</td><td>23.5</td></tr> <tr><td>5</td><td>64.29</td><td>30.2</td></tr> <tr><td>6</td><td>78.57</td><td>36.9</td></tr> <tr><td>7</td><td>92.86</td><td>43.6</td></tr> </tbody> </table>	Point Number	Percent of Traverse	Inches from Wall	1	7.14	3.4	2	21.43	10.1	3	35.71	16.8	4	50.00	23.5	5	64.29	30.2	6	78.57	36.9	7	92.86	43.6		
Point Number	Percent of Traverse	Inches from Wall																								
1	7.14	3.4																								
2	21.43	10.1																								
3	35.71	16.8																								
4	50.00	23.5																								
5	64.29	30.2																								
6	78.57	36.9																								
7	92.86	43.6																								
SAMPLING SITE SCHEMATIC																										
																										

4.5 EFFLUENT PARTICULATE CONCENTRATION

The effluent particulate concentration was determined per EPA Method 5 which is entitled "Determination of particulate emissions from stationary sources". For each test run, particulate matter was isokinetically withdrawn from the gas stream at each of the EPA Method 1 defined sampling points and collected on a glass fiber filter which was maintained at constant temperature ($248 \pm 25^\circ\text{F}$). Water vapor, organic vapors and other matter in vapor form which passed through the filter was collected in an ice-cooled impinger trap whose exit temperature was maintained at less than 68°F .

The EPA Method 5 sampling train (Figure 4.2) consists of a heated sampling probe with attached nozzle, thermocouple and S-type pitot tube. The probe attaches to the front sample case (hot box) which houses a glass cyclone (optional) and an all-glass in-line filter holder in a temperature controlled environment. The front sample case is connected to the back sample case (cold box) which houses a series of glass impingers and a desiccant column in an ice bath. The back sample case is connected to the control unit which contains the sample vacuum pump, pressure and temperature indicators and all operating controls.

A representative particulate sample was acquired by sampling for equal periods of time at the center of a number of equal area regions within the stack/duct. At each sampling point the gas velocity head and temperature were measured and the sampling rate rapidly adjusted to isokinetic conditions with the aid of a nomograph or programmable computing device. Sample gas drawn into the nozzle flowed through the probe to the glass fiber filter where the particulate matter was collected. The gases then passed through the ice-cooled condenser (impingers and desiccant column) which quantitatively sorbed all moisture from the gas stream. The gas then passed through the vacuum pump, the dry test meter and the calibrated orifice.

Leak checks to detect any dilution air being pulled into the sampling line were performed at the beginning and end of each test run and also when and if any sample line connections were broken.

After completion of each test run, the sampling train was removed to the clean-up area for sample recovery. The filter was removed from the filter holder and placed in Container #1. Particulate matter collected in the nozzle, probe and all connecting glassware in front of the filter was quantitatively transferred to Container #2 by means of a distilled water wash followed by an acetone wash. A stiff brush was used in the probe cleaning step to help dislodge deposits. The water collected in each of the impingers (desiccant column excluded) was measured and transferred to Container #3. The impingers and all connecting pieces between the filter paper and the desiccant column were then rinsed with distilled water and these rinsings were added to Container #3.

Figure 4.2 Sampling Train Description
 L.C. Kruse & Sons, Inc. Asphalt Plant, Windom, Minnesota
 Aggregate/Asphalt Drum Mix Operation Scrubber Exhaust
 June 9, 1993

PARTICULATE SAMPLING TRAIN IDENTIFICATION

Sampling Train Manufacturer: MMT Environmental Services, Inc.

Sampling Train Model: Universal Stak Sampler

Hot Box Set-up and Operating Temperature;

Cyclone used: No

Filter Media: Glass Fiber Filter, Whatman GF/C, 11.0 cm diameter

Filtration Temperature: 248 ± 25 degrees Fahrenheit

Cold Box Set-up; Impinger Type and Initial Contents

Impinger #1: Modified Greenburg-Smith design, 100 ml deionized, distilled water

Impinger #2: Standard Greenburg-Smith design, 100 ml deionized, distilled water

Impinger #3: Modified Greenburg-Smith design, empty


Impinger #4: Modified Greenburg-Smith design, ≈ 250 grams silica gel, indicating type

Probe Nozzle Used: MMT #L10, 0.243 inch diameter, stainless steel

Sampling Probe Used: MMT #72, 72 inch effective length with stainless steel liner

Pitot Tube Used: MMT #60, S-type, 0.835 coefficient

PARTICULATE SAMPLING TRAIN SCHEMATIC



The impingers and all connecting pieces between the filter paper and the desiccant column were then rinsed with acetone and these rinsings were placed in Container #4. The desiccant column was then weighed and its contents transferred to a waste desiccant container.

Sample analysis was performed at MMT's laboratory. The filter was dried in a 105°C oven for three hours and then desiccated to constant weight. The contents of Container #2 were transferred to a tared beaker, evaporated to near dryness and then desiccated to a constant weight. The contents of Container #3 were analyzed for condensable organic compounds using the chloroform/ethyl ether extraction procedure described in Minnesota Rule 7005.0500. The collected extract was transferred to a tared beaker, evaporated to near dryness and then desiccated to a constant weight. The contents of Container #4 were also transferred to a tared beaker, evaporated to near dryness and then desiccated to a constant weight.

The mass of particulate matter collected and the volume of gas sampled was used to calculate the effluent particulate concentration. The source particulate mass emission rate was calculated by multiplying the effluent particulate concentration by the source volumetric flow rate. Separate calculations were performed for total catch, front catch only (Containers 1 & 2) and back catch only (Containers 3 & 4).

4.6 SOURCE PLUME OPACITY

The source visible emissions were determined by the visual observations of a certified visible emissions evaluator per EPA Method 9 which is entitled "Visual determination of the opacity of emissions from stationary sources".

In this procedure, the observer positions himself at a distance sufficient to provide a clear view of the emissions with the sun oriented in the 140 degree sector to his back. Consistent with this requirement, the observer's line of site was, as much as possible, perpendicular to the plume's direction.

Opacity observations were made at the point of greatest opacity in that portion of the plume where condensed water vapor was not present. Observations were made at 15-second intervals and recorded to the nearest 5 percent opacity.

5 QUALITY ASSURANCE

The project manager is responsible for implementation of the quality assurance program as applied to any specific project.

5.1 SAMPLING QUALITY ASSURANCE

Generally, implementation of quality assurance procedures for source measurement is designed so the work is done:

- ♦ by competent, trained individuals experienced on the specific methodologies being used
- ♦ using properly calibrated equipment
- ♦ using approved procedures for sample handling and documentation

Measuring devices, pitot tubes, dry gas meters, thermocouples and portable gas analyzers are uniquely identified and calibrated with documented procedures and acceptance criteria before and after each field effort. Records of all calibration data are maintained in the files.

Prior to the test program, MMT provides the following:

- ♦ filter numbers and tare weights of all filters available for the test
- ♦ results of an acetone residue analysis on the acetone to be used during the test
- ♦ calibrations of all pitot tubes, dry gas meters, orifice meters, thermocouples and probes

Specific details of MMT's QA program for stationary air pollution sources may be found in "Quality Assurance Handbook for Air Pollution Measurement Systems", Volume III (EPA-600/4-7-027b).

5.2 ANALYTICAL QUALITY CONTROL

MMT maintains a vigorous quality control program for all samples analyzed. This program is based on the general guidelines given in "Handbook for Analytical Quality Control in Water and Wastewater Laboratories" (EPA-600/4-79-019); March 1979. This program suggests guidelines in the areas of:

- ♦ Laboratory services
- ♦ Instrument selection
- ♦ Glassware
- ♦ Reagents
- ♦ Solvents
- ♦ Gases
- ♦ Analytical performance
- ♦ Laboratory safety

Standards and curves are determined for each analysis using the appropriate standard. Least square linear regression calculations are used in determining "best fit" to the data. Correlation coefficients are also calculated.

APPENDIX A: CALCULATIONS

DEFINITION OF UNIT ABBREVIATIONS

ACFM ACTUAL CUBIC FEET PER MINUTE
DEG F DEGREES FAHRENHEIT
DCF DRY CUBIC FEET
DSCF DRY STANDARD CUBIC FEET
DSCFM DRY STANDARD CUBIC FEET PER MINUTE
FPS FEET PER SECOND
G GRAMS
GR/ACF GRAINS PER ACTUAL CUBIC FOOT
GR/DSCF GRAINS PER DRY STANDARD CUBIC FOOT
GR/SCF GRAINS PER STANDARD CUBIC FOOT
IN INCHES
IN HG INCHES OF MERCURY
IN WC INCHES OF WATER
LB/HR POUNDS PER HOUR
LB/LB-MOLE .. POUND PER POUND-MOLE
MIN MINUTES
ML MILLILITERS
SCF STANDARD CUBIC FEET
SCFM STANDARD CUBIC FEET PER MINUTE
SF SQUARE FEET
% V/V DRY ... PERCENT BY VOLUME, DRY BASIS

DEFINITION OF STANDARD CONDITIONS

STANDARD TEMPERATURE 68 DEGREES FAHRENHEIT
STANDARD PRESSURE 29.92 INCHES OF MERCURY

DEFINITION OF VARIABLES

An CROSS-SECTIONAL AREA OF NOZZLE, SF
 As CROSS-SECTIONAL AREA OF STACK, SF
 Ewp ... EFFLUENT MOISTURE CONTENT, PERCENT BY VOLUME
 Bws ... EFFLUENT MOISTURE CONTENT, PROPORTION BY VOLUME
 Ca* ... EFFLUENT PARTICULATE CONCENTRATION AT ACTUAL
 CONDITIONS, GR/ACF; *=f,b,t; Caf: FRONT CATCH ONLY;
 Cab: BACK CATCH ONLY; Cat: TOTAL CATCH
 CD EFFLUENT CARBON DIOXIDE CONCENTRATION, % V/V DRY
 CM EFFLUENT CARBON MONOXIDE CONCENTRATION, % V/V DRY
 Cp PITOT TUBE COEFFICIENT, DIMENSIONLESS
 Cs* ... EFFLUENT PARTICULATE CONCENTRATION AT DRY STANDARD
 CONDITIONS, GR/DSCF; *=f,b,t; Csf: FRONT CATCH ONLY;
 Csb: BACK CATCH ONLY; Cst: TOTAL CATCH
 Cw* ... EFFLUENT PARTICULATE CONCENTRATION AT STANDARD
 CONDITIONS, GR/SCF; *=f,b,t; Cwf: FRONT CATCH ONLY;
 Cwb: BACK CATCH ONLY; Cwt: TOTAL CATCH
 Dn NOZZLE DIAMETER, IN
 I ISOKINETIC VARIATION, %
 Md EFFLUENT MOLECULAR WEIGHT, LB/LB-MOLE, DRY BASIS
 Ms EFFLUENT MOLECULAR WEIGHT, LB/LB-MOLE, WET BASIS
 NI EFFLUENT NITROGEN CONCENTRATION, % V/V DRY
 OX EFFLUENT OXYGEN CONCENTRATION, % V/V DRY
 Pb BAROMETRIC PRESSURE, IN HG
 Pg STACK STATIC PRESSURE, IN WC
 Po AVERAGE PRESSURE DROP ACROSS THE METERING
 ORIFICE, IN WC
 Ps STACK ABSOLUTE PRESSURE, IN HG
 Pv AVERAGE SQUARE-ROOT VELOCITY PRESSURE, IN WC
 Qa EFFLUENT FLOW RATE AT ACTUAL CONDITIONS, ACFM
 Qs EFFLUENT FLOW RATE AT STANDARD CONDITIONS, SCFM
 Qsd ... EFFLUENT FLOW RATE AT STANDARD CONDITIONS,
 DRY BASIS, DSCFM
 Rc* ... SOURCE PARTICULATE EMISSION RATE, CLASSICAL
 METHOD, LB/HR; *=f,b,t; Rcf: FRONT CATCH ONLY;
 Rcb: BACK CATCH ONLY; Rct: TOTAL CATCH
 Rr* ... SOURCE PARTICULATE EMISSION RATE, RATIO OF
 AREAS METHOD, LB/HR; *=f,b,t; Rrf: FRONT CATCH ONLY;
 Rrb: BACK CATCH ONLY; Rrt: TOTAL CATCH
 Sl STACK DIAMETER OR LENGTH, IN
 Sw STACK WIDTH, IN
 Ti TOTAL SAMPLING TIME, MIN
 Tm AVERAGE DRY GAS METER TEMPERATURE, DEG F
 Ts AVERAGE EFFLUENT TEMPERATURE, DEG F
 Vl VOLUME OF LIQUID COLLECTED, ML
 Vm VOLUME OF GAS SAMPLED AT METER CONDITIONS, DCF
 Vms ... VOLUME OF GAS SAMPLED AT STANDARD CONDITIONS, DSCF
 Vs AVERAGE EFFLUENT VELOCITY, FPS
 Vw VOLUME OF WATER VAPOR COLLECTED AT STANDARD
 CONDITIONS, SCF
 Wb MASS OF PARTICULATE MATTER COLLECTED IN THE
 BACK (WET) CATCH, G
 Wf MASS OF PARTICULATE MATTER COLLECTED IN THE
 FRONT (DRY) CATCH, G
 Wt TOTAL MASS OF PARTICULATE MATTER COLLECTED, G
 Y DRY GAS METER COEFFICIENT, DIMENSIONLESS

EQUATIONS USED TO CALCULATE PARTICULATE EMISSIONS

$$A_n = 0.005454154 * D_n * D_n$$

$$A_s = 0.005454154 * S_1 * S_1 \quad (\text{FOR ROUND STACKS})$$

$$A_s = S_1 * S_w / 144.0 \quad (\text{FOR RECTANGULAR STACKS})$$

$$P_s = P_b + P_g/13.6$$

$$NI = 100.0 - CD - OX - CM$$

$$W_t = W_f + W_b$$

$$V_{ms} = (528/29.92) * V_m * Y * (P_b + P_o/13.6) / (T_m + 460.0)$$

$$V_w = 0.04707 * V_l$$

$$B_{ws} = V_w / (V_w + V_{ms})$$

$$B_{wp} = 100.0 * B_{ws}$$

$$M_d = 0.440 * CD + 0.320 * OX + 0.280 * (NI + CM)$$

$$M_s = M_d * (1.0 - B_{ws}) + 18.0 * B_{ws}$$

$$V_s = 85.49 * C_p * P_v * \text{SQRT}((T_s + 460.0)/(M_s * P_s))$$

$$Q_a = 60.0 * V_s * A_s$$

$$Q_s = Q_a * (528/29.92) * P_s / (T_s + 460.0)$$

$$Q_{sd} = Q_s * (1.0 - B_{ws})$$

$$I = 0.09450 * (T_s + 460.0) * V_{ms} / (P_s * V_s * A_n * T_i * (1.0 - B_{ws}))$$

$$C_{sf} = 15.42 * W_f / V_{ws}$$

$$C_{sb} = 15.42 * W_b / V_{ws}$$

$$C_{st} = 15.42 * W_t / V_{ws}$$

$$C_{wf} = C_{sf} / (1.0 - B_{ws})$$

$$C_{wb} = C_{sb} / (1.0 - B_{ws})$$

$$C_{wt} = C_{st} / (1.0 - B_{ws})$$

$$C_{af} = C_{wf} * (29.92/528.0) * (T_s + 460.0) / P_s$$

$$C_{ab} = C_{wb} * (29.92/528.0) * (T_s + 460.0) / P_s$$

$$C_{at} = C_{wt} * (29.92/528.0) * (T_s + 460.0) / P_s$$

$$R_{cf} = 0.008578 * C_{sf} * Q_{sd}$$

$$R_{cb} = 0.008578 * C_{sb} * Q_{sd}$$

$$R_{ct} = 0.008578 * C_{st} * Q_{sd}$$

$$R_{rf} = 0.008578 * C_{sf} * (V_{ms}/T_i) * (A_s/A_n)$$

$$R_{rb} = 0.008578 * C_{sb} * (V_{ms}/T_i) * (A_s/A_n)$$

$$R_{rt} = 0.008578 * C_{st} * (V_{ms}/T_i) * (A_s/A_n)$$

VOLUMETRIC FLOW RATE CALCULATION

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
TEST DATE: 6-9-93 SOURCE: SCRUBBER OUTLET

Preliminary Flowrate Determination

DUCT DIMENSIONS;
 LENGTH, INCHES 47.00 LN
 WIDTH, INCHES 41.00 WD
 CROSS-SECTIONAL AREA, SQ FT 13.382 AR

EFFLUENT TEMPERATURE, DEG F 165 TS

MOISTURE CONTENT DETERMINATION:
 EFFLUENT WET BULB TEMPERATURE, DEG F 158 TW
 EFFLUENT DEW POINT TEMPERATURE, DEG F 158 TD
 EFFLUENT RELATIVE HUMIDITY, % 84.9 RH
 EFFLUENT MOISTURE CONTENT, % V/V 32.5 MC

DUCT PRESSURES;
 BAROMETRIC PRESSURE, IN HG 28.12 PB
 STATIC PRESSURE, IN WC -0.90 PS
 ABSOLUTE PRESSURE, IN WC 28.05 PA

EFFLUENT COMPOSITION;
 CARBON DIOXIDE CONTENT, % V/V DRY 7.0 CD
 OXYGEN CONTENT, % V/V DRY 10.5 OX

EFFLUENT MOLECULAR WEIGHT;
 DRY BASIS, LB/LB-MOLE 29.54 MD
 WET BASIS, LB/LB-MOLE 25.78 MS

PITOT TUBE COEFFICIENT 0.835 CP

EFFLUENT VELOCITY PRESSURES, IN WC;

POINT	PORT A	PORT B	PORT C	PORT D
1	0.460	0.550	0.580	0.610
2	0.850	0.790	0.990	0.880
3	0.870	1.150	1.300	1.150
4	1.000	1.300	1.300	0.950
5	1.100	1.200	1.200	0.950
6	1.100	1.200	1.100	1.050
7	1.100	1.150	1.050	1.050

AVE. SQUARE-ROOT VELOCITY PRESSURE, IN WC .. 0.99 PV

EFFLUENT AVERAGE VELOCITY, FT/SEC 65.828 VS

EFFLUENT VOLUMETRIC FLOW RATE;
 ACTUAL, ACFM 52855 FA
 STANDARD, SCFM 41874 FW
 DRY STANDARD, DSCFM 28248 FD

EQUATIONS USED TO CALCULATE THE VOLUMETRIC FLOW RATE

$$AR = LN * WD / 144.0$$

$$PA = PB + PS/13.6$$

$$MD = 0.44*CD + 0.32*OX + 0.28*(100-CD-OX)$$

$$MS = MD*(1-MC/100) + 0.18*MC$$

$$VS = 85.48 * CP * PV * \text{SQRT}((460+TS)/(MS*PA))$$

$$FA = 60 * VS * AR$$

$$FW = 17.65 * FA * PA / (TS+460)$$

$$FD = FW * (1-MC/100)$$

STANDARD CONDITIONS: 68 DEG F, 29.92 IN-HG

TRAVERSE POINT DATA SUMMARY AND VELOCITY PROFILE

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
 TEST NUMBER: 1 SOURCE: SCRUBBER OUTLET
 RUN NUMBER: 1 TIME: 6/ 9/93 1159-1311

		TRAVERSE POINT DATA					VELOCITY PROFILE	
SAMPLING LOCATION PORT	POINT	VELOCITY PRESSURE	ORIFICE PRESSURE	TEMPERATURE, DEG.F			SOOT VELOCITY	GAS VELOCITY
		IN WC	IN WC	STACK GAS	METER INLET	METER OUTLET	PRESSURE	FT/SEC
A	1	0.460	0.780	169	81	83	0.678	45.67
A	2	0.780	1.320	174	82	82	0.883	59.71
A	3	1.050	1.770	179	83	81	1.025	69.54
A	4	0.960	1.620	184	84	81	0.980	66.76
A	5	0.850	1.240	185	84	81	0.922	62.87
A	6	1.050	1.530	188	86	82	1.025	70.03
A	7	1.200	1.750	187	85	83	1.095	74.81
B	1	1.350	1.970	179	85	83	1.162	78.86
B	2	1.050	1.530	180	85	83	1.025	69.60
B	3	0.950	1.390	184	85	83	0.975	66.41
B	4	0.970	1.420	181	85	83	0.985	66.95
B	5	0.810	1.180	186	85	83	0.900	61.42
B	6	0.700	1.020	185	85	83	0.837	57.05
B	7	0.750	1.090	188	85	83	0.866	59.19
C	1	0.610	0.890	182	86	84	0.781	53.13
C	2	1.000	1.460	184	87	84	1.000	68.13
C	3	1.250	1.830	181	87	85	1.118	76.00
C	4	1.300	1.900	183	86	85	1.140	77.62
C	5	1.150	1.680	185	86	85	1.072	73.12
C	6	1.100	1.610	187	86	85	1.049	71.63
C	7	1.000	1.460	182	86	85	1.000	68.03
D	1	0.590	0.860	184	85	84	0.768	52.33
D	2	0.840	1.230	171	86	85	0.917	61.81
D	3	1.200	1.750	165	85	85	1.095	73.53
D	4	1.150	1.680	186	85	85	1.072	73.18
D	5	1.050	1.530	188	85	85	1.025	70.03
D	6	1.000	1.460	187	85	85	1.000	68.29
D	7	0.930	1.360	187	84	85	0.964	65.86
AVERAGE		0.968	1.440	182	85	84	0.977	66.48

PARTICULATE EMISSION TEST CALCULATIONS

PROJECT NUMBER: 9374	COMPANY: L.C. KRUISE
TEST NUMBER: 1	SOURCE: SCRUBBER OUTLET
RUN NUMBER: 1	TIME: 6/ 9/93 1159-1311

TEST DATA			
GAS METER COEFFICIENT	0.9816 Y	VOLUME OF LIQUID COLLECTED, ML	566.8 V1
PITOT TUBE COEFFICIENT	0.835 Cp	GAS COMPOSITION, % V/V DRY;	
NOZZLE DIMENSIONS;		CARBON DIOXIDE	6.50 CD
DIAMETER, IN	0.243 Dn	OXYGEN	11.40 OX
AREA, SF	0.000322 An	CARBON MONOXIDE	0.00 CM
		NITROGEN (BY DIFFERENCE)	82.10 NI
STACK DIMENSIONS;		AVE. TRAVERSE POINT DATA;	
DIAMETER/LENGTH, IN	47.00 S1	STACK TEMP., DEG F	182 Ts
WIDTH, IN	41.00 Sw	METER TEMP., DEG F	84 Tm
AREA, SF	13.382 As	ORIFICE PRESSURE, IN WC	1.440 Po
BAROMETRIC PRESSURE, IN HG	28.12 Pb	SQRT VELOCITY P., IN WC	0.977 Pv
STACK PRESSURES;		MASS OF PARTICULATE MATTER	
STATIC, IN WC	-0.91 Pg	COLLECTED, G;	
ABSOLUTE, IN HG	28.05 Ps	FRONT CATCH (91.6%)	0.3798 Wf
		BACK CATCH (8.4%)	0.0349 Wb
SAMPLING TIME, MIN	70.00 Ti	TOTAL CATCH	0.4147 Wt
VOLUME OF GAS SAMPLED AT METER, DCF	49.756 Vm		

CALCULATED RESULTS			
VOLUME OF GAS SAMPLED AT METER, DSCF	44.696 Vms	GAS MOLECULAR WEIGHT;	
		DRY BASIS, LB/LB-MOLE	29.50 Md
		WET BASIS, LB/LB-MOLE	25.20 Ms
EQUIVALENT VOLUME OF WATER VAPOR COLLECTED, SCF	26.679 Vw	AVERAGE GAS VELOCITY, FPS	66.48 Vs
GAS MOISTURE CONTENT;		GAS VOLUMETRIC FLOW RATE;	
VOLUME FRACTION	0.3738 Bws	ACTUAL, ACFM	53377 Qa
PERCENT BY VOLUME	37.38 Bwp	STANDARD, SCFM	41149 Qs
		DRY STANDARD, DSCFM	25768 Qsd
		ISOKINETIC VARIATION, %	103.02 I

PARTICULATE EMISSION PARAMETER	FRONT CATCH	BACK CATCH	TOTAL CATCH
PARTICULATE CONCENTRATION			
ACTUAL, GR/ACF	0.0633 Caf	0.0058 Cab	0.0691 Cat
STANDARD, GR/SCF	0.0821 Cwf	0.0075 Cwb	0.0896 Cwt
DRY STANDARD, GR/DSCF	0.1310 Csf	0.0120 Csb	0.1431 Cst
PARTICULATE EMISSION RATE, LB/HR			
CLASSICAL METHOD	28.96 Rcf	2.66 Rcb	31.62 Rct
RATIO OF AREAS METHOD	29.82 Rrf	2.74 Rrb	32.56 Rrt

STANDARD CONDITIONS: 68 DEG F, 29.92 IN HG	* NON-APPLICABLE DATA
--	-----------------------

TRAVERSE POINT DATA SUMMARY AND VELOCITY PROFILE

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
 TEST NUMBER: 1 SOURCE: SCRUBBER OUTLET
 RUN NUMBER: 2 TIME: 6/ 9/93 1330-1442

		TRAVERSE POINT DATA					VELOCITY PROFILE	
SAMPLING LOCATION	PORT POINT	VELOCITY PRESSURE IN WC	ORIFICE PRESSURE IN WC	TEMPERATURE, DEG.F STACK GAS	METER INLET	METER OUTLET	SQRT VELOCITY PRESSURE	GAS VELOCITY FT/SEC
A	1	0.520	0.760	180	85	85	0.721	48.84
A	2	0.810	1.190	184	85	85	0.900	61.15
A	3	0.940	1.380	183	85	85	0.970	65.82
A	4	0.980	1.440	184	85	85	0.990	67.26
A	5	1.050	1.540	185	85	85	1.025	69.67
A	6	1.050	1.540	182	85	85	1.025	69.51
A	7	1.200	1.760	181	85	85	1.095	74.25
B	1	0.540	0.790	182	85	85	0.735	49.85
B	2	0.690	1.010	183	85	86	0.831	56.39
B	3	0.940	1.380	181	86	86	0.970	65.72
B	4	1.200	1.760	187	85	85	1.095	74.60
B	5	1.350	1.980	185	85	85	1.162	79.00
B	6	1.300	1.910	186	86	86	1.140	77.59
B	7	1.250	1.840	186	87	86	1.118	76.08
C	1	0.600	0.880	185	87	86	0.775	52.67
C	2	0.810	1.190	184	86	86	0.900	61.15
C	3	1.000	1.470	186	86	86	1.000	68.05
C	4	1.050	1.540	185	86	86	1.025	69.67
C	5	1.200	1.760	185	86	86	1.095	74.49
C	6	1.200	1.760	186	86	86	1.095	74.54
C	7	1.100	1.620	184	86	86	1.049	71.26
D	1	0.490	0.720	186	86	86	0.700	47.63
D	2	0.740	1.080	187	86	86	0.860	58.58
D	3	0.960	1.410	185	86	86	0.980	66.62
D	4	1.050	1.540	186	86	86	1.025	69.73
D	5	1.100	1.620	188	86	86	1.049	71.48
D	6	1.100	1.620	181	86	86	1.049	71.09
D	7	1.000	1.470	184	86	86	1.000	67.94
AVERAGE		0.972	1.427	184	86	86	0.978	66.45

PARTICULATE EMISSION TEST CALCULATIONS

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
 TEST NUMBER: 1 SOURCE: SCRUBBER OUTLET
 RUN NUMBER: 2 TIME: 6/ 9/93 1330-1442

TEST DATA

GAS METER COEFFICIENT	0.9816 Y	VOLUME OF LIQUID COLLECTED, ML	553.0 V1
PITOT TUBE COEFFICIENT	0.835 Cp	GAS COMPOSITION, % V/V DRY;	
NOZZLE DIMENSIONS;		CARBON DIOXIDE	7.50 CD
DIAMETER, IN	0.243 Dn	OXYGEN	10.00 OX
AREA, SF	0.000322 An	CARBON MONOXIDE	0.00 CM
		NITROGEN (BY DIFFERENCE)	82.50 NI
STACK DIMENSIONS;		AVE. TRAVERSE POINT DATA;	
DIAMETER/LENGTH, IN	47.00 S1	STACK TEMP., DEG F	184 Ts
WIDTH, IN	41.00 Sw	METER TEMP., DEG F	86 Tm
AREA, SF	13.382 As	ORIFICE PRESSURE, IN WC	1.427 Po
BAROMETRIC PRESSURE, IN HG	28.16 Pb	SQRT VELOCITY P., IN WC	0.978 Pv
STACK PRESSURES;		MASS OF PARTICULATE MATTER COLLECTED, G;	
STATIC, IN WC	-0.94 Pg	FRONT CATCH (91.4%)	0.3379 Wf
ABSOLUTE, IN HG	28.09 Ps	BACK CATCH (8.6%)	0.0319 Wb
SAMPLING TIME, MIN	70.00 Ti	TOTAL CATCH	0.3698 Wt
VOLUME OF GAS SAMPLED AT METER, DCF	49.375 Vm		

CALCULATED RESULTS

VOLUME OF GAS SAMPLED AT METER, DSCF	44.304 Vms	GAS MOLECULAR WEIGHT;	
		DRY BASIS, LB/LB-MOLE	29.60 Md
		WET BASIS, LB/LB-MOLE	25.31 Ms
EQUIVALENT VOLUME OF WATER VAPOR COLLECTED, SCF	26.030 Vw	AVERAGE GAS VELOCITY, FPS	66.45 Vs
GAS MOISTURE CONTENT;		GAS VOLUMETRIC FLOW RATE;	
VOLUME FRACTION	0.3701 Bws	ACTUAL, ACFM	53352 Qa
PERCENT BY VOLUME	37.01 Bwp	STANDARD, SCFM	41048 Qs
		DRY STANDARD, DSCFM	25856 Qsd
		ISOKINETIC VARIATION, %	101.77 I

PARTICULATE EMISSION PARAMETER	FRONT CATCH	BACK CATCH	TOTAL CATCH
PARTICULATE CONCENTRATION			
ACTUAL, GR/ACF	0.0570 Caf	0.0054 Cab	0.0624 Cat
STANDARD, GR/SCF	0.0741 Cwf	0.0070 Cwb	0.0811 Cwt
DRY STANDARD, GR/DSCF	0.1176 Csf	0.0111 Csb	0.1287 Cst
PARTICULATE EMISSION RATE, LB/HR			
CLASSICAL METHOD	26.08 Rcf	2.46 Rcb	28.55 Rct
RATIO OF AREAS METHOD	26.53 Rrf	2.50 Rrb	29.03 Rrt

STANDARD CONDITIONS: 68 DEG F, 29.92 IN HG * NON-APPLICABLE DATA

TRAVERSE POINT DATA SUMMARY AND VELOCITY PROFILE

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
 TEST NUMBER: 1 SOURCE: SCRUBBER OUTLET
 RUN NUMBER: 3 TIME: 6/ 9/93 1500-1612

		TRAVERSE POINT DATA					VELOCITY PROFILE	
SAMPLING LOCATION	PORT POINT	VELOCITY PRESSURE IN WC	ORIFICE PRESSURE IN WC	TEMPERATURE, DEG.F STACK GAS	METER INLET	METER OUTLET	SQRT VELOCITY PRESSURE	GAS VELOCITY FT/SEC
A	1	0.550	0.810	187	87	87	0.742	50.63
A	2	0.760	1.120	183	87	87	0.872	59.33
A	3	0.920	1.350	180	87	87	0.959	65.12
A	4	0.970	1.430	178	87	86	0.985	66.77
A	5	0.980	1.440	181	87	86	0.990	67.27
A	6	1.200	1.760	177	87	86	1.095	74.20
A	7	1.200	1.760	176	86	86	1.095	74.14
B	1	0.480	0.710	178	86	85	0.693	46.97
B	2	0.840	1.230	177	86	85	0.917	62.08
B	3	1.100	1.620	179	86	85	1.049	71.15
B	4	1.200	1.760	180	86	85	1.095	74.38
B	5	1.300	1.910	181	86	85	1.140	77.47
B	6	1.200	1.760	183	86	85	1.095	74.55
B	7	1.150	1.690	185	86	85	1.072	73.09
C	1	0.650	0.960	184	85	85	0.806	54.91
C	2	0.860	1.260	186	85	85	0.927	63.26
C	3	1.100	1.620	186	85	85	1.049	71.54
C	4	1.300	1.910	185	86	85	1.140	77.72
C	5	1.250	1.840	188	86	85	1.118	76.38
C	6	1.100	1.620	193	85	85	1.049	71.93
C	7	1.050	1.540	189	85	85	1.025	70.06
D	1	0.610	0.900	182	85	85	0.781	53.11
D	2	0.820	1.210	177	85	85	0.906	61.34
D	3	1.050	1.540	174	85	84	1.025	69.25
D	4	1.000	1.470	171	85	84	1.000	67.42
D	5	1.000	1.470	170	85	84	1.000	67.36
D	6	0.990	1.460	162	85	84	0.995	66.60
D	7	0.960	1.410	160	85	84	0.980	65.48
AVERAGE		0.985	1.449	180	86	85	0.986	66.91

PARTICULATE EMISSION TEST CALCULATIONS

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
 TEST NUMBER: 1 SOURCE: SCRUBBER OUTLET
 RUN NUMBER: 3 TIME: 6/ 9/93 1500-1612

TEST DATA

GAS METER COEFFICIENT	0.9816 Y	VOLUME OF LIQUID COLLECTED, ML	580.9 V1
PITOT TUBE COEFFICIENT	0.835 Cp	GAS COMPOSITION, % V/V DRY;	
NOZZLE DIMENSIONS;		CARBON DIOXIDE	7.00 CD
DIAMETER, IN	0.243 Dn	OXYGEN	10.50 OX
AREA, SF	0.000322 An	CARBON MONOXIDE	0.00 CM
		NITROGEN (BY DIFFERENCE)	82.50 NI
STACK DIMENSIONS;		AVE. TRAVERSE POINT DATA;	
DIAMETER/LENGTH, IN	47.00 S1	STACK TEMP., DEG F	180 Ts
WIDTH, IN	41.00 Sw	METER TEMP., DEG F	85 Tm
AREA, SF	13.382 As	ORIFICE PRESSURE, IN WC	1.449 Po
BAROMETRIC PRESSURE, IN HG	28.18 Pb	SQRT VELOCITY P., IN WC	0.986 Pv
STACK PRESSURES;		MASS OF PARTICULATE MATTER COLLECTED, G;	
STATIC, IN WC	-0.92 Pg	FRONT CATCH (89.5%)	0.3554 Wf
ABSOLUTE, IN HG	28.11 Ps	BACK CATCH (10.5%)	0.0415 Wb
SAMPLING TIME, MIN	70.00 Ti	TOTAL CATCH	0.3969 Wt
VOLUME OF GAS SAMPLED AT METER, DCF	49.851 Vm		

CALCULATED RESULTS

VOLUME OF GAS SAMPLED AT METER, DSCF	44.780 Vms	GAS MOLECULAR WEIGHT;	
		DRY BASIS, LB/LB-MOLE	29.54 Md
		WET BASIS, LB/LB-MOLE	25.16 Ms
EQUIVALENT VOLUME OF WATER VAPOR COLLECTED, SCF	27.343 Vw	AVERAGE GAS VELOCITY, FPS	66.91 Vs
GAS MOISTURE CONTENT;		GAS VOLUMETRIC FLOW RATE;	
VOLUME FRACTION	0.3791 Bws	ACTUAL, ACFM	53724 Qa
PERCENT BY VOLUME	37.91 Bwp	STANDARD, SCFM	41663 Qs
		DRY STANDARD, DSCFM	25868 Qsd
		ISOKINETIC VARIATION, %	102.81 I

PARTICULATE EMISSION PARAMETER	FRONT CATCH	BACK CATCH	TOTAL CATCH
PARTICULATE CONCENTRATION			
ACTUAL, GR/ACF	0.0589 Caf	0.0069 Cab	0.0658 Cat
STANDARD, GR/SCF	0.0760 Cwf	0.0089 Cwb	0.0849 Cwt
DRY STANDARD, GR/DSCF	0.1224 Csf	0.0143 Csb	0.1367 Cst
PARTICULATE EMISSION RATE, LB/HR			
CLASSICAL METHOD	27.16 Rcf	3.17 Rcb	30.33 Rct
RATIO OF AREAS METHOD	27.90 Rrf	3.26 Rrb	31.16 Rrt

STANDARD CONDITIONS: 68 DEG F, 29.92 IN HG

* NON-APPLICABLE DATA

TABLE ANALYSIS OF VISIBLE EMISSION TEST DATA

PROJECT NUMBER: 9374
DATE TESTED: 6-9-93
TIME OF TEST: 1500

COMPANY: L.C. KRUISE
SOURCE: SCRUBBER OUTLET
OBSERVER: MR. BILL ANDERSON
RE-CERTIFICATION DATE: 10-1-93

Test-Run # 1-3

PLUME OPACITY OBSERVATIONS														
MIN-UTE	**00	15	30	**45	MIN-UTE	**00	15	30	**45	MIN-UTE	**00	15	30	**45
0	10	5	15	10	20	15	10	5	5	40	5	5	10	5
1	5	5	10	5	21	5	10	10	15	41	10	10	15	10
2	10	15	15	10	22	5	10	15	5	42	10	10	10	5
3	10	5	5	5	23	10	5	5	15	43	10	15	15	10
4	15	10	10	10	24	10	10	10	15	44	10	5	5	15
5	5	5	5	5	25	20	15	15	10	45	5	5	10	10
6	15	10	10	5	26	10	15	10	10	46	15	15	20	10
7	10	10	10	5	27	5	10	10	10	47	10	10	10	5
8	5	5	10	5	28	10	10	15	15	48	5	10	10	10
9	5	10	5	10	29	5	10	5	15	49	15	15	10	5
10	10	10	10	15	30	10	15	15	15	50	10	15	10	15
11	10	5	15	5	31	10	5	10	10	51	15	10	10	10
12	5	20	5	10	32	10	5	10	5	52	5	10	10	10
13	5	5	10	15	33	5	5	10	5	53	5	5	5	10
14	10	10	10	5	34	5	5	10	5	54	5	10	15	15
15	10	5	5	15	35	10	10	10	10	55	15	10	10	15
16	5	5	10	10	36	10	15	15	10	56	10	10	10	5
17	15	10	5	10	37	10	10	15	10	57	10	15	15	5
18	10	5	10	5	38	20	15	15	10	58	5	10	10	5
19	5	15	10	5	39	10	10	5	5	59	10	5	5	10

SUMMARY OF TEST DATA					
PLUME OPACITY %	PERCENT OF TIME AT OPACITY	PERCENT OF TIME OPACITY EXCEEDED	OPACITY RANGE, %	TIME OPACITY IN RANGE % OF TIME	MIN/HR
0	0.00	100.00	0 - 20	100.00	60.00
5	32.08	67.92	25 - 40	0.00	0.00
10	46.67	21.25	45 - 60	0.00	0.00
15	19.58	1.67	> 60	0.00	0.00
20	1.67	0.00			
25	0.00	0.00			
30	0.00	0.00			
35	0.00	0.00			
40	0.00	0.00			
45	0.00	0.00			
50	0.00	0.00			
55	0.00	0.00			
60	0.00	0.00			
65	0.00	0.00			
70	0.00	0.00			
75	0.00	0.00			
80	0.00	0.00			
85	0.00	0.00			
90	0.00	0.00			
95	0.00	0.00			
100	0.00	0.00			

MAXIMUM OBSERVED OPACITY, %: 20
MINIMUM OBSERVED OPACITY, %: 5
ARITHMETIC MEAN OPACITY, %: 9.5

SIX-MINUTE AVERAGE OPACITY, %
MAXIMUM: 11.7 (25:00-30:45)
2nd LARGEST: 11.3 (46:00-51:45)
3rd LARGEST: 10.6 (36:15-42:00)
4th LARGEST: 9.8 (54:00-59:45)
5th LARGEST: 9.4 (19:00-24:45)


APPENDIX B: FIELD DATA FORMS

SOURCE EMISSION TEST
SITE DESCRIPTION DATA SHEET

TRAVERSE POINT LOCATION		
Traverse Point Number	Port Length:	
	Inches From Wall	Inches From Port
1	3.36	
2	10.07	
3	16.78	
4	23.49	
5	30.20	
6	36.91	
7	43.62	
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		

PRELIMINARY TRAVERSE DATA	
Effluent Temperature, °F:	_____
Ave. Velocity Pressure, IN WC:	_____

MMT Job Number: 9374 Date: June 1993
 Company: L.C. Kruse + Sons
 Address: Windom, MIN
 Source: Aggregate Dryer - Wet Scrubber
 Source Cross-sectional Dimensions
 Round Duct; diameter: NA
 Rectangular Duct;
 Length: 41" 47"
 Width: 47" 41"
 Equivalent diameter: 43.80" = 3.65 ft
 $De = 2LW / (L+W)$
 Distance to Nearest Flow Disturbance;
 Before Ports: 8' 8" = 2.19 diameters
 After Ports: 8' 3" = 0.82 diameters
 Number of Sampling Points;
 Required by EPA Method 1: 24-25
 Actually Used: 28
 Number of ports: 4
 Points per port: 7
 Sampling Time;
 Minutes per Point: 2.5
 Minutes per Test Run: 70



Field Data Sheet

VELOCITY TRAVERSE: Time: <u>1131</u> Pitot Tube No: <u>60</u> Coefficient: <u>A = 0.835</u>										
Traverse Point Number	Inches From Wall	Inches From Port	PORT A		PORT B		PORT C		PORT D	
			ΔP in. H ₂ O	Temp. °F	ΔP in. H ₂ O	Temp. °F	ΔP in. H ₂ O	Temp. °F	ΔP in. H ₂ O	Temp. °F
1	3.36		.46	.55	.58	.61				
2	10.07		.95	.79	.99	.88				
3	16.78		.87	1.15	1.3	1.15				
4	23.49		1.0 1.0	1.3	1.3	.95				
5	30.20		1.1	1.2	1.2	.95				
6	36.91		1.1	1.2	1.1	1.05				
7	43.62		1.1	1.15	1.05	1.05				
			Port A	B	C	D				
$\bar{x} V_p \text{ in } C = .999 \sim 1.0''$ $\text{min } V_p = .46$ $\text{Max } V_p = 1.3$ $\text{Ideal Nozzle Dia.} = .239$ $\text{Actual Nozzle} = .243 \quad \text{" \& Dia.}$ $\text{Nozzle ID: } L/10$										

SOURCE EMISSION TEST
FIELD DATA SHEET

TEST: 1 RUN: /
Page 1 of 2

TEST IDENTIFICATION		EQUIPMENT IDENTIFICATION		NOMOGRAPH PARAMETERS
MMT Job Number: 9374		Control Unit No.: 5		$\Delta H@ 183$
Date: Wed 6/9/83		Gas Meter Coefficient: 983		TM 90
Company: L.C. Kruse & Sons		Sample Box No.: 5		MC 32-36
Source: Aggregate Dryer		Probe No.: 72 Length: 72 inches		PS/PM ≤ 1.0
Source Dimensions:		Pitot No.: 60 Coefficient: $A = 0.84$		C = .983
Test Team: Bill - Ted		Nozzle No.: 610 Diameter: .243 .835		TS 165
Test Procedure: EPA Methods 1-5		Filter No.: 8708		R
Ambient Temp., °F: 74		Barometric Pressure, in.Hg: 28.12		Static Pressure, in.WC: -.91

CLOCK TIME hours	TRAVERSE POINT NUMBER	SAMPLE TIME min.	SAMPLE VOLUME cu.ft.	VELOCITY HEAD in.WC	ORIFICE ΔH , in.WC		PUMP VAC. inHG	TEMPERATURE, DEG F					
					REQ.	ACT.		STACK GAS	GAS METER IN OUT	OVEN	PROBE	LAST IMP.	
1159	1	0	474.756	.46	.78	.78	7	169	81	83	241	247	78
	2		476.1	.78	1.32	1.32	10	174	82	82	240	249	68
1204	3	5	477.8	1.05	1.77	1.77	12	179	83	81	237	252	66
	4		479.8	.96	1.62	1.62	11	184	84	81	244	253	60
1209	5	10	481.7	.85	1.24	1.24	11	185	84	81	244	252	59
	6		483.4	1.05	1.53	1.53	12	188	86	82	251	251	58
1214	7	15	485.2	1.2	1.75	1.75	12	187	85	83	252	250	59
1216.5	End	17.5	487.2										
1217	1	20	X	1.35	1.97	1.97	14	179	85	83	257	248	60
	2	20	489.3	1.05	1.57	1.57	13	180	85	83	253	248	60
1222	3		491.1	.95	1.39	1.39	13	184	85	83	251	251	59
	4	25	492.9	.97	1.42	1.42	13	181	85	83	252	250	60
1227	5		494.6	.81	1.18	1.18	12	186	85	83	249	250	61
	6	30	496.1	.70	1.02	1.02	11	185	85	87	248	248	61
1232	7		497.8	.75	1.09	1.09	10	188	85	83	247	249	60
1234.5	End	35	499.3										
1235	1	40	X	.61	.89	.89	11	182	86	84	249	249	60
	2		500.7	1.0	1.46	1.46	14	184	87	84	248	252	60
1240	3	40	502.5	1.25	1.83	1.83	16	181	87	85	249	252	61
	4		504.5	1.3	1.90	1.90	16	183	86	85	251	258	61
1245	5	45	506.6	1.15	1.68	1.68	15	185	86	85	250	255	61
	6		508.5	1.1	1.61	1.61	15	187	86	85	252	254	60
1250	7	50	510.4	1.0	1.46	1.46	14	182	86	85	251	251	60
1252.5	End	55	512.2										
		Continue											

e 1204 Dry 185
Wet 163

MOISTURE DETERMINATION					
IMPINGER	1	2	3	4	5
Final					Not
Initial	100	100	0	876.3	Applied
Difference					
Total Moisture Collected:					

Impinger Catch Description:

SYSTEM LEAK CHECKS		
Time	Rate (cfm)	Vac. (in.Hg)
1151	.011	26"
1315	.014	27"

DETERMINATION OF GAS COMPOSITION BY ORSAT ANALYSIS								
Sample Id:	Replicate 1		Replicate 2		Replicate 3		Average	
	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Compound	Percent Volume
1-1								
Initial Reading								
Carbon Dioxide							CO2	
Oxygen							O2	
Carbon Monoxide							CO	

Total Sampling Time, min.: 25
Volume of Gas Sampled, DCF: _____

TEST:	RUN: 1
Page	of

[illegible]

SYSTEM LEAK CHECKS		
Time	Rate (cfm)	Vac. (in.Hg)

[illegible]

Total Sampling Time, min.: _____
Volume²⁶ of Gas Sampled, DCF: _____

SOURCE EMISSION TEST
FIELD DATA SHEET

TEST: 1 RUN: 2
Page 1 of 2

TEST IDENTIFICATION	EQUIPMENT IDENTIFICATION	NOMOGRAPH PARAMETERS
MMT Job Number: <u>9374</u>	Control Unit No.: <u>5</u>	$\Delta H @ 1.83$
Date: <u>Wed 6-7-93</u>	Gas Meter Coefficient: <u>.983</u>	TM <u>55</u>
Company: <u>L.C. Krue + Sons</u>	Sample Box No.: <u>5</u>	MC <u>36</u>
Source: <u>Rubber Outlet</u>	Probe No.: <u>72</u> Length: <u>72" 73"</u>	PS/PM <u>1.0</u>
Source Dimensions: <u>42 x 41"</u>	Pitot No.: <u>60</u> Coefficient: <u>A-1.84</u>	C <u>.983</u>
Test Team: <u>Bill + Ted</u>	Nozzle No.: <u>610</u> Diameter: <u>1.243 1.835</u>	TS <u>183</u>
Test Procedure: <u>EPA 1-5</u>	Filter No.: <u>8709</u>	R
Ambient Temp., °F: <u>77</u> Barometric Pressure, in.Hg: <u>29.16</u> Static Pressure, in.WC: <u>-.94</u>		

CLOCK TIME hours	TRAVERSE POINT NUMBER	SAMPLE TIME min.	SAMPLE VOLUME cu.ft.	VELOCITY HEAD in.WC	ORIFICE ΔH , in.WC		PUMP VAC. in.Hg	TEMPERATURE, DEG. F					LAST IMP.
					REQ.	ACT.		STACK GAS	GAS METER IN	GAS METER OUT	OVEN	PROBE	
1330	1	0	525.521	.52	.76	.76	7	180	85	85	249	234	78
	2		526.8	.81	1.19	1.19	13	184	85	85	251	242	66
1335	3	5	528.4	.94	1.38	1.38	14	183	85	85	250	247	62
	4		530.2	.98	1.44	1.44	15	184	85	85	249	249	60
1340	5	10	531.9	1.05	1.54	1.54	15	185	85	85	250	251	60
1345	6		533.8	1.05	1.54	1.54	15	182	85	85	248	250	58
1345	7	15	535.7	1.2	1.76	1.76	16	181	85	85	247	249	57
1345	End	17.5	537.7										
1348	1	17.5	539.0	.54	.79	.79	8	182	85	85	249	251	58
	2	20	539.0	.69	1.01	1.01	9	183	85	86	251	252	58
1353	3		540.4	.74	1.38	1.38	14	181	86	86	250	251	59
	4	25	542.2	1.2	1.76	1.76	16	187	85	85	254	250	60
1358	5		544.2	1.35	1.98	1.98	17	185	85	85	256	250	60
	6	30	546.3	1.30	1.91	1.91	17	186	86	86	257	248	60
1403	7		548.3	1.25	1.84	1.84	17	186	87	86	258	247	60
1405.5	End	35	550.4										
1406	1	35	551.8	.60	.88	.88	7	185	87	86	251	249	59
	2		551.8	.81	1.19	1.19	11	184	86	86	250	251	56
1411	3	40	553.4	1.0	1.47	1.47	14	186	86	86	256	252	55
	4		555.2	1.05	1.54	1.54	15	185	86	86	254	251	56
1416	5	45	557.1	1.2	1.76	1.76	16	185	86	86	248	250	58
	6		559.0	1.2	1.76	1.76	16	186	86	86	248	250	60
1421	7	50	560.9	1.1	1.62	1.62	15	184	86	86	247	251	62
1423.5	End	52.5	562.9										
Continued													

MOISTURE DETERMINATION					
IMPINGER	1	2	3	4	5
Final					
Initial	100	100	0	576.4	X
Difference					
Total Moisture Collected:					

Impinger Catch Description:

SYSTEM LEAK CHECKS		
Time	Rate (cfm)	Vac. (in.Hg)
1326	.009	26"
1445	.012	27"

DETERMINATION OF GAS COMPOSITION BY ORSAT ANALYSIS								
Sample Id:	Replicate 1		Replicate 2		Replicate 3		Average	
	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Compound	Percent Volume
1-2								
Initial Reading								
Carbon Dioxide							CO2	
Oxygen							O2	
Carbon Monoxide							CO	

Total Sampling Time, min.: 27

Volume of Gas Sampled, DCF:

TEST: 1	RUN: 2
Page 2 of 2	

[illegible]

SYSTEM LEAK CHECKS		
Time	Rate (cfm)	Vac. (in.Hg)
See page 1 of 2		

DETERMINATION OF GAS COMPOSITION BY ORSAT ANALYSIS								
Sample Id:	Replicate 1		Replicate 2		Replicate 3		Average	
	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Compound	Percent Volume
(-7)								
Initial Reading		X		X		X		X
Carbon Dioxide							CO ₂	
Oxygen							O ₂	
Carbon Monoxide							CO	

Total Sampling Time, min.: _____
Volume²⁸ of Gas Sampled, DCF: _____

SOURCE EMISSION TEST
FIELD DATA SHEET

TEST: RUN: **3**
Page **1** of **2**

TEST IDENTIFICATION	EQUIPMENT IDENTIFICATION	NOMOGRAPH PARAMETERS
MMT Job Number: 9374	Control Unit No.: 5	$\Delta H@$ 1.93
Date: Wed 6.9.93	Gas Meter Coefficient: .983	TM 87
Company: L.C. Kruse + Sons	Sample Box No.: 5	MC 367
Source: Scrubber Outlet	Probe No.: 2972 Length: 24" 72"	PS/PM = 1/0
Source Dimensions: 47" x 46" width	Pitot No.: 600 Coefficient: A = .844	C .983
Test Team: Bill + Ted	Nozzle No.: 410 Diameter: .243 .435	TS 185
Test Procedure: EPA 1-5	Filter No.: 8710	R
Ambient Temp., °F: 77 Barometric Pressure, in.Hg: 28.18 Static Pressure, in.WC: -.92		

CLOCK TIME hours	TRAVERSE POINT NUMBER	SAMPLE TIME min.	SAMPLE VOLUME cu. ft.	VELOCITY HEAD in. WC	ORIFICE		PUMP VAC. in HG	TEMPERATURE, DEG F					
					ΔH , in. WC REQ. ACT.	STACK GAS		GAS METER		OVEN	PROBE	LAST IMP.	
								IN	OUT				
1500	1	0	575.990	.55	.81	.81	8	187	87	87	241	238	77
	2		577.3	.76	1.12	1.12	9	183	87	87	244	241	69
1505	3	5	578.9	.92	1.35	1.35	11	180	87	87	251	244	65
	4		580.6	.97	1.43	1.43	14	178	87	86	255	246	63
1510	5	10	582.4	.98	1.44	1.44	14	181	87	86	256	247	61
	6		584.2	1.2	1.76	1.76	15	177	87	86	255	250	60
1516	7	15	586.2	1.2	1.76	1.76	15	176	86	86	254	252	60
1517.5	End	17.5	588.2										
1518	1	17.5	X	.48	.71	.71	8	178	86	85	253	251	61
	2	20	589.4	.84	1.23	1.23	11	177	86	85	251	250	61
1523	3		591.1	1.1	1.62	1.62	15	179	86	85	252	254	62
	4	25	593.0	1.2	1.76	1.76	15	180	86	85	250	255	63
1528	5		594.9	1.3	1.91	1.91	16	181	86	85	249	254	63
	6	30	597.0	1.2	1.76	1.76	15	183	86	85	250	252	64
1533	7		578.9	1.15	1.69	1.69	15	185	86	85	251	251	64
1535.5	End	35	600.9										
1536	1	35	X	.65	.96	.96	7	184	85	85	252	253	65
	2		602.4	.86	1.26	1.26	12	186	85	85	251	253	63
1541	3	40	604.1	1.1	1.62	1.62	14	186	85	85	250	251	62
	4		605.9	1.3	1.91	1.91	16	185	86	85	250	250	62
1546	5	45	608.0	1.25	1.84	1.84	15	188	86	85	248	248	62
	6		610.0	1.1	1.62	1.62	14	193	85	85	244	248	62
1551	7	50	611.9	1.05	1.54	1.54	13	189	85	85	254	249	63
1553.5	End	52.5	613.9										
			Continued										

MOISTURE DETERMINATION					
IMPINGER	1	2	3	4	5
Final					
Initial	100	100	0	888.8	X
Difference					
Total Moisture Collected:					

Impinger Catch Description:

SYSTEM LEAK CHECKS		
Time	Rate (cfm)	Vac. (in. Hg)
1457	.011	24"
1415	.008	18"

DETERMINATION OF GAS COMPOSITION BY ORSAT ANALYSIS								
Sample Id:	Replicate 1		Replicate 2		Replicate 3		Average	
	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Compound	Percent Volume
17								
Initial Reading								
Carbon Dioxide							CO2	
Oxygen							O2	
Carbon Monoxide							CO	

Total Sampling Time, min.: **29**
Volume of Gas Sampled, DCF:

SOURCE EMISSION TEST
FIELD DATA SHEET

TEST: 1 RUN: 3
Page of 2 of 2

TEST IDENTIFICATION		EQUIPMENT IDENTIFICATION		NOMOGRAPH PARAMETERS
MMT Job Number: <u>9374</u>		Control Unit No.: <u>5</u>		$\Delta H @ 1.83$
Date: <u>Wed 6-9-93</u>		Gas Meter Coefficient: <u>.983</u>		TM <u>86</u>
Company: <u>L.C. Krueh + Sons</u>		Sample Box No.: <u>5</u>		MC = <u>36</u>
Source: <u>Scrubber Outlet</u>		Probe No.: <u>8472</u> Length: <u>24" 72"</u>		PS/PM = <u>1.0</u>
Source Dimensions: <u>47" dia x 41" wide</u>		Pitot No.: <u>600</u> Coefficient: <u>A = .891</u>		C <u>.983</u>
Test Team: <u>Bill + Ted</u>		Nozzle No.: <u>110</u> Diameter: <u>.243 1835</u>		TS <u>183</u>
Test Procedure: <u>EPA 1-5</u>		Filter No.: <u>8710</u>		R
Ambient Temp., °F: <u>75</u>		Barometric Pressure, in.Hg: <u>28.18</u>		Static Pressure, in.WC: <u>-.92</u>

CLOCK TIME hours	TRAVERSE POINT NUMBER	SAMPLE TIME min.	SAMPLE VOLUME cu.ft.	VELOCITY HEAD in.WC	ORIFICE ΔH , in.WC		PUMP VAC. in.Hg	TEMPERATURE, DEG F					LAST IMP.
					REQ.	ACT.		STACK GAS	GAS METER IN	GAS METER OUT	OVEN	PROBE	
1554	1	52.5	X	.61	.90	.90	9	182	85	85	247	249	64
	2	75	615.2	.82	1.21	1.21	12	177	85	85	251	257	63
1559	3		616.8	1.05	1.54	1.54	14	174	85	84	254	249	64
	4	60	618.7	1.0	1.47	1.47	14	171	85	84	255	254	65
1604	5		620.5	1.0	1.47	1.47	14	170	85	84	254	250	65
	6	65	622.3	.99	1.46	1.46	14	162	85	84	251	248	66
1609	7		624.1	.96	1.41	1.41	14	160	85	84	250	250	66
1611.5	End	70	625.841										

DCF = 49.851

Time = 70 minutes

MOISTURE DETERMINATION					
IMPINGER	1	2	3	4	5
Final					
Initial	100	100	0	888.8	X
Difference					

Total Moisture Collected:

Impinger Catch Description:

SYSTEM LEAK CHECKS		
Time	Rate (cfm)	Vac. (in.Hg)

See page 2 of 2

DETERMINATION OF GAS COMPOSITION BY ORSAT ANALYSIS								
Sample Id:	Replicate 1		Replicate 2		Replicate 3		Average	
	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Compound	Percent Volume
1-3								
Initial Reading								
Carbon Dioxide							CO2	
Oxygen							O2	
Carbon Monoxide							CO	

Total Sampling Time, min.: 30

Volume of Gas Sampled, DCF:

Project # 9374

Test-Run # 1-3

Visible Emission Observation Form

SOURCE NAME L.E. Kruse + Sons			OBSERVATION DATE 6-9-93				START TIME 1500		STOP TIME 1600				
ADDRESS Aggregate Dryer - Wet Scrubber			SEC MIN	0	15	30	45	SEC MIN	0	15	30	45	
CITY _____ STATE _____ ZIP _____			1	10	5	15	10	31	10	15	15	15	
			2	5	5	10	5	32	10	5	10	10	
			3	10	15	15	10	33	10	5	10	5	
			4	10	5	5	5	34	5	5	10	5	
PHONE _____ SOURCE ID NUMBER _____			5	15	10	10	10	35	5	5	10	5	
PROCESS EQUIPMENT Drum Mixer			OPERATING MODE		6	5	5	5	5	36	10	10	10
CONTROL EQUIPMENT Scrubber			OPERATING MODE		7	15	10	10	5	37	10	15	15
DESCRIBE EMISSION POINT START Stack STOP ✓			8	10	10	10	5	38	10	10	15	10	
HEIGHT ABOVE GROUND LEVEL START 30' STOP ✓			HEIGHT RELATIVE TO OBSERVER START 30' STOP ✓		9	5	5	10	5	39	20	15	15
DISTANCE FROM OBSERVER START 90' STOP ✓			DIRECTION FROM OBSERVER START STOP		10	5	10	5	10	40	10	10	5
DESCRIBE EMISSIONS START Plume STOP ✓			11	10	10	10	15	41	5	5	10	5	
EMISSION COLOR START White STOP ✓			PLUME TYPE: CONTINUOUS ☒ FUGITIVE ☐ INTERMITTENT ☐		12	10	5	15	5	42	10	10	15
WATER DROPLETS PRESENT: NO ☐ YES ☒			IF WATER DROPLET PLUME: ATTACHED ☒ DETACHED ☐		13	5	20	5	10	43	10	10	10
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START After water droplets STOP			14	5	5	10	15	44	10	15	15	10	
DESCRIBE BACKGROUND START Sky STOP ✓			15	10	10	10	5	45	10	5	5	15	
BACKGROUND COLOR START White STOP ✓			SKY CONDITIONS START Partly Cloudy STOP		16	10	5	5	15	46	5	5	10
WIND SPEED START 25-35 STOP ✓			WIND DIRECTION START E/SE STOP ✓		17	5	5	10	10	47	15	15	20
AMBIENT TEMP. START 69° STOP ✓			WET BULB TEMP. _____ RH, percent _____		18	15	10	5	10	48	10	10	10
Source Layout Sketch Draw North Arrow Emission Point Observers Position Sun Wind Plume and Stack 140° Sun Location Line			19	10	5	10	5	49	5	10	10	10	
			20	5	15	10	5	50	15	15	10	5	
			21	15	10	5	5	51	10	15	10	15	
			22	5	10	10	15	52	15	10	10	10	
			23	5	10	15	5	53	5	10	10	10	
			24	10	5	5	15	54	5	5	5	10	
			25	10	10	10	15	55	5	10	15	15	
			26	20	15	15	10	56	15	10	10	15	
			27	10	15	10	10	57	10	10	10	5	
			28	5	10	10	10	58	10	15	15	5	
			29	10	10	15	15	59	5	10	10	5	
			30	5	10	5	15	60	10	5	5	10	
AVERAGE OPACITY FOR HIGHEST PERIOD			NUMBER OF READINGS ABOVE % WERE										
RANGE OF OPACITY READINGS			MINIMUM			MAXIMUM							
OBSERVER'S NAME (PRINT)			Bill Anderson										
OBSERVER'S SIGNATURE			DATE			6-9-93							
ORGANIZATION			MMT Environmental Services										
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE			CERTIFIED BY			DATE			4.1.93				
TITLE			VERIFIED BY			DATE			4.1.93				
			ETA										

ORSAT ANALYSIS

Job Number: 9374

Company: L.C. Kruse + Sons

SAMPLE DESCRIPTION

Scriber Outlet

SAMPLE ANALYSIS

Parameter Measured	Replicate 1		Replicate 2		Replicate 3	
	Buret Reading	Percent Volume	Buret Reading	Percent Volume	Buret Reading	Percent Volume

Average

Sample Id: 1-1	Initial Reading	0.0	0.0	0.0	0.0	0.0
Collected By: Bill	Carbon Dioxide	6.5	6.5	6.5	6.5	6.5
Date Collected: 6.9.93	Oxygen	17.9	11.4	17.9	11.4	11.4
Analyzed By: Ted	Carbon Monoxide	Not Analyzed				
Date Analyzed: 6.9.93						

1.462

Sample Id: 1-2	Initial Reading	0.0	0.0	0.0	0.0	0.0
Collected By: Bill	Carbon Dioxide	7.5	7.5	7.5	7.5	7.5
Date Collected: 6.9.93	Oxygen	17.5	10.0	17.5	10.0	10.0
Analyzed By: Ted	Carbon Monoxide					
Date Analyzed: 6.9.93						

1.45

Sample Id: 1-3	Initial Reading	0.0	0.0	0.0	0.0	0.0
Collected By: Ted	Carbon Dioxide	7.0	7.0	7.0	7.0	7.0
Date Collected: 6.9.93	Oxygen	11.5	10.5	11.5	10.5	10.5
Analyzed By: Ted	Carbon Monoxide					
Date Analyzed: 6.9.93						

1.486

For 1.434 - 1.586 range for C_3H_8 propane fuel, $[F.O. = (20.9 - 1.02) \div 1.02]$

APPENDIX C: LABORATORY REPORTS

SUMMARY OF PARTICULATE EMISSION TEST LABORATORY DATA

PROJECT NUMBER: 9374 COMPANY: L.C. KRUISE
TEST NUMBER: 1 SOURCE: SCRUBBER OUTLET

RUN NUMBER	MASS OF PARTICULATE MATTER COLLECTED, GRAMS							TOTAL PARTICULATE MASS COLLECTED
	FRONT CATCH				BACK CATCH			
	FRONT WASH	CYCLONE CATCH	FILTER CATCH	FRONT TOTAL	IMPINGER CATCH **	IMPINGER WASH	BACK TOTAL	
1	0.0859	0.0000	0.2939	0.3798	0.0169	0.0180	0.0349	0.4147
2	0.0655	0.0000	0.2724	0.3379	0.0147	0.0172	0.0319	0.3698
3	0.0637	0.0000	0.2917	0.3554	0.0163	0.0252	0.0415	0.3969

* NOT APPLICABLE

** CHLOROFORM/ETHYL ETHER EXTRACTION

LABORATORY REPORT: EPA Method 5

Project Number: 9374 Company: L.C. Krige

Frontwashes 300 ml Acetone				
Test-Run	1-1	1-2	1-3	Date
Dish #	374	371	380	---
1	2.8255	2.4264	2.2540	6.10.93
2	2.8253	2.4265	2.2544	6.11.93
3	2.8255	2.4263	2.2542	6.11.93
Tare Blank Net	2.7341 .0003 .0859	2.3605 .0003 .0655	2.1900 .0003 .0637	6.24.92 ----- -----

Backwashes 300 ml Acetone				
Test-Run	1-1	1-2	1-3	Date
Dish #	375	378	381	---
1	2.7340	2.3722	2.3291	6.10.93
2	2.7343	2.3723	2.3289	6.11.93
3	2.7341	2.3722	2.3292	6.11.93
Tare Blank Net	2.7157 .0003 .0180	2.2547 .0003 .0172	2.3034 .0003 .0252	6.24.92 ----- -----

Extractions 150 ml Chloroform - 150 ml Ether				
Test-Run	1-1	1-2	1-3	Date
Dish #	376	379	382	---
1	2.3156	2.2499	2.2856	6.10.93
2	2.3155	2.2498	2.2855	6.11.93
3	2.3157	2.2497	2.2853	6.11.93
Tare Blank Net	2.2985 .0001 .0169	2.2349 .0001 .0147	2.2689 .0001 .0163	6.24.92 ----- -----

Solvent Blanks				
Solvents	300 ml Acetone	150 ml Chloroform	150 ml Ether	Date
Dish #	371	372	373	---
1	2.7559	2.7180	2.7230	6.15.93
2	2.7557	2.7184	2.7229	6.11.93
3	2.7559	2.7183	2.7230	6.11.93
Tare	2.7554	2.7179	2.7229	6.24.92
Net	.0003	.0001	.0000	-----

Glass Filters				
Test-Run	1-1	1-2	1-3	Date
Filter #	8708	8709	8710	---
1	.7998	.7843	.7949	6.10.93
2	.7995	.7846	.7948	6.11.93
3	.7945	.7845	.7947	6.11.93
Tare	.5056	.5119	.5030	2.15.93
Net	.2939	.2724	.2917	-----

COMMENTS

Lowest Final Weight
 - Tare
 - Blank (if applicable)
 = Sample Net Gain (grams)

Signature: Ted Williams Date: 6.14.93

9374

Laboratory Report: Moisture Content of Aggregate Samples

L.C. Kruse

Project Number

Company

Test 1-1

Trial #	1	2	3	Date
Dish #	383	384	385	
Tare	22.390	22.274	2.3437	10.30.92
Tare + Wet	45.5258	45.345	45.5067	6.10.93
Wet	43.2868	43.0421	43.1630	
Dry	40.5305	40.6892	40.5839	
Dry + Tare	42.7695	42.9166	42.9276	6.10.93
% Moisture	6.37	5.58	5.98	

Test 1-2

Trial #	1	2	3	Date
Dish #	386	387	388	
Tare	2.3449	2.3722	2.3114	10.30.92
Tare + Wet	45.1699	45.2499	45.6197	6.10.93
Wet	42.825	42.8777	43.3083	
	40.3011	40.5469	40.8954	
Dry				
Dry + Tare	42.6460	42.9151	43.2068	6.10.93
% Moisture	5.89	5.14	5.57	

Test 1-3

Trial #	1	2	3	Date
Dish #	389	390	391	
Tare	2.2550	2.2599	2.2370	10.30.92
Tare + Wet	43.5770	45.4367	45.1255	6.10.93
Wet	73.3220	43.1768	42.8885	
	40.8077	40.6644	40.7316	
Dry				
Dry + Tare	43.0627	42.9243	42.9686	6.10.93
% Moisture	5.80	5.82	5.03	

Signature _____

W. L. Lelands

DATE

6.10.93

Comments

$$\frac{\text{Dry}}{\text{Wet}} * 100 = \% \text{ Solids}$$
$$100 - \% \text{ Solids} = \% \text{ Moisture}$$

Summary

	Mean	Deviation	% Error
Test 1-1	5.98	.40	6.61
1-2	5.03	.23	4.11
1-3	5.55	.45	8.12

PROJECT # 9374 COMPANY L.C. Kruse & Sons
 TEST DATE(s) June 1993 SOURCE Aggregate Dryer - Wet Scrubber
69.93

EPA METHOD 4 LABORATORY REPORT

FILTER #

#8708

TEST-RUN #	IMPINGER #	INITIAL	FINAL	GAIN	DESCRIPTION
1-1	1	100	399	299	cloudy
	2	100	269	169	
	3	0	61	61	
	4	876.5	914.3	37.8	
	5	X	X	X	
TOTAL MOISTURE GAIN, ML =				566.8	

#8709

TEST-RUN #	IMPINGER #	INITIAL	FINAL	GAIN	DESCRIPTION
1-2	1	100	388	288	cloudy
	2	100	339	239	
	3	0	3	3	
	4	876.4	899.4	23.0	
	5	X	X	X	
TOTAL MOISTURE GAIN, ML =				553.0	

#8710

TEST-RUN #	IMPINGER #	INITIAL	FINAL	GAIN	DESCRIPTION
1-3	1	100	320	220	cloudy
	2	100	423	323	
	3	0	11	11	
	4	888.8	915.7	26.9	
	5	Not Applied	X	X	
TOTAL MOISTURE GAIN, ML =				580.9	

APPENDIX D: CALIBRATION DATA

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Chick Anderson

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

Thomas J. [Signature]
President

[Signature]
Vice President

David B. Savage, Jr.
Program Manager

238342
Certificate Number

Memorapoli
Location

April 1, 1993
Date of Issue

CALIBRATION
DRY TEST METER/ORIFICE METER

Page: SSQA-1-25

Monday
Date: 6.7.93

Barometric Pressure, in. Hg. (Pb): 28.37

EQUIPMENT IDENTIFICATION			
Control Unit 5	Dry Test Meter	Wet Test Meter	Calibration Type
Mfg: mmt	Mfg: Rockwell	Mfg: GCA Corporation	General: X
Model: Universal	Model:	Model: Precision	Post-test: X
SN: 92-9093	SN: EEI-C89	SN: 11 RH 12	

EQUIPMENT CALIBRATION											
Orifice Pressure Drop in. WC H	Pump Vac. in. Hg	Wet Test Meter			Dry Test Meter						Elapsed Time, min. Q
		Volume, CF		Temp. OF Tw	Volume, CF		Temperature, OF				
		Initial V _{wi}	Final V _{wf}		Initial V _{di}	Final V _{df}	Inlet		Outlet		
							Initial T _{ii}	Final T _{if}	Initial T _{oi}	Final T _{of}	
0.5	0	zero	2.451	73	441.658	444.145	70	72	70	71	6
1.0	0	2.451	7.565	73	444.145	449.369	72	77	72	73	9
2.0	0	7.565	15.577	73	449.369	458.113	87	94	73	76	7
3.0	0	8.772	15.577	73	467.132	474.131	93	98	76	77	7
2.0		0.000	8.772	73	458.113	467.132	87	94	74	76	11

COMPUTER PRINTOUT

Pre-Test L.C. Kruse

H	Vw	Tw	Vd	Td	Q	C	HQ
0.5	2.451	73	2.487	70.8	6.8	0.9881	1.7921
1.0	5.114	73	5.224	73.5	9.0	0.9773	1.8428
2.0	8.772	73	9.019	82.8	11.0	0.9853	1.8394
3.0	6.805	73	6.999	86.0	7.0	0.9883	1.8455

AVERAGE CORRECTION FACTOR: C = 0.9828
AVERAGE ORIFICE CONSTANT: HQ = 1.8299

EQUATIONS:

$$\begin{aligned}
 V_w &= V_{wf} - V_{wi} \\
 V_d &= V_{df} - V_{di} \\
 T_d &= (T_{ii} + T_{if} + T_{oi} + T_{of}) / 4 \\
 C &= V_w * P_b * (T_d + 460) / (V_d * (P_b + H/13.6) * (T_w + 460)) \\
 H_Q &= 0.0317 * H * ((T_w + 460) * Q / V_w)^2 / (P_b * (T_d + 460))
 \end{aligned}$$

Calibration Performed by:

(Print)

Ted Gibbons

CALIBRATION
DRY TEST METER/ORIFICE METER

Page: SQA-1-26

Date: Thursday 6.10.93

Barometric Pressure, in. Hg. (Pb): 29.00

EQUIPMENT IDENTIFICATION			
Control Unit 5	Dry Test Meter	Wet Test Meter	Calibration Type
Mfg: umt	Mfg: Rockwell	Mfg: GCA Corporation	General: X
Model: Universal	Model:	Model: Precision	Post-test: X
SN: 92-9093	SN: EEI-C89	SN: 11 AH 12	

EQUIPMENT CALIBRATION											
Orifice Pressure Drop in. WC H	Pump Vac. in. Hg	Wet Test Meter			Dry Test Meter						Elapsed Time, min. Q
		Volume, CF		Temp. OF Tw	Volume, CF		Temperature, OF				
		Initial V _{wi}	Final V _{wf}		Initial V _{di}	Final V _{df}	Inlet		Outlet		
							Initial T _{ii}	Final T _{if}	Initial T _{oi}	Final T _{of}	
0.5	0	zero	2.882	74	627.472	630.380	69	71	69	69	7
1.0	0	2.882	12.012	74	630.380	635.700	72	84	69	72	16
2.0	0	12.012	22.375	74	639.700	650.386	84	96	72	75	13
3.0	0	22.375	33.038	74	650.386	661.426	95	103	75	78	11

COMPUTER PRINTOUT

Post Test Calibration

H	V _w	T _w	V _d	T _d	Q	C	H _a
0.5	2.882	74	2.908	69.5	7.0	0.9815	1.7364
1.0	9.130	74	9.320	74.3	16.0	0.9776	1.7918
2.0	10.363	74	10.686	81.8	13.0	0.9789	1.8109
3.0	10.663	74	11.040	87.8	11.0	0.9832	1.8168

AVERAGE CORRECTION FACTOR: C = 0.9803
AVERAGE ORIFICE CONSTANT: H_a = 1.7890

EQUATIONS:

$$V_w = V_{wf} - V_{wi}$$

$$V_d = V_{df} - V_{di}$$

$$T_d = (T_{ii} + T_{if} + T_{oi} + T_{of}) / 4$$

$$C = V_w * P_b * (T_d + 460) / (V_d * (P_b + H/13.6) * (T_w + 460))$$

$$H_a = 0.0317 * H * ((T_w + 460) * Q / V_w)^2 / (P_b * (T_d + 460))$$

Pre & Post Test X C = .9816

Calibration Performed by

(Print) *Jim Gibbons*

CALIBRATION S-TYPE PITOT TUBE

Probe length = 72"

Probe sheath ID: 70"

Date: 4.5.93

S-Type Pitot Tube ID No.: 60" Wide Body

Ambient Temperature, °F: 66

Standard Pitot Tube ID No.: 18"

Barometric Pressure, in. Hg.: 29.18

Standard Pitot Tube Coefficient: 0.995

PITOT TUBE EXAMINATION * Not Attached during calibration		
Alignment Check	Pitot Tube Dimensions	Pitot Assembly Intercomponent Spacings
$\alpha_1 < 10^\circ$ $\alpha_2 < 10^\circ$ $\beta_1 < 5^\circ$ $\beta_2 < 5^\circ$ $Q < 1/8$ in. $R < 1/32$ in.	External tubing diameter (D_t): 3/8" Base to Side A opening plane (P_A): Base to Side B opening plane (P_B):	Pitot to nozzle (X): Pitot to probe sheath (Y): Pitot to thermocouple, along probe (W): Pitot to thermocouple, perpendicular to probe (Z):

DESIRED CALIBRATION POINT		SIDE A CALIBRATION		SIDE B CALIBRATION	
Velocity ft/sec	P_{std} in. WC	P_{std} in. WC	P_s in. WC	P_{std} in. WC	P_s in. WC
20	0.09	.12	.164	.12	.17
40	0.37	.36	.51	.34	.46
60	0.82	.83	1.18	.79	1.09
80	1.45	1.51	2.24	1.41	2.02
100	2.30				

COMPUTER PRINTOUT

SIDE A CALIBRATION				SIDE B CALIBRATION			
Pstd	Ps	Cp	Cp-Cp(A)	Pstd	Ps	Cp	Cp-Cp(B)
0.120	0.164	0.851	0.016	0.120	0.170	0.836	-0.006
0.360	0.510	0.836	0.001	0.340	0.460	0.855	0.013
0.830	1.180	0.834	-0.000	0.790	1.090	0.847	0.005
1.510	2.240	0.817	-0.018	1.410	2.020	0.831	-0.011
Cp(A) = 0.835				Cp(B) = 0.842			

$$\text{side } A(\sigma) = .012$$

$$B(\sigma) = .009$$

Calibration Performed by:

(Print) Bill + Ted

(Signature) Bill Ted

CALIBRATION
NOZZLE DIAMETER

L = Long

Nozzle Number	Nominal Diameter, in.	Measured Diameter, in.			Nozzle* Diameter, in.
		D1	D2	D3	
L-1		.169	.172	.174	0.172
L-2		.249	.244	.248	0.247
L-3		.362	.360	.361	0.361
L-4		.493	.488	.493	0.491
L-5		.125	.124	.123	0.124
L-6		.302	.300	.305	0.302
L-7		.181	.177	.181	0.180
L-8		.489	.492	.494	0.492
L-9		.743	.747	.745	0.745
L-10	Nozzle Employed	.246	.241	.242	0.243
L-11		.251	.253	.248	0.251
L-12		.240	.241	.241	0.241
L-13		.243	.241	.239	0.241
L-14		.199	.199	.199	0.199
L-15		.369	.369	.374	0.371
L-81		.567	.562	.562	0.564

* Nozzle diameter = (D1 + D2 + D3)/3

Calibration Performed by:

(Print) *Ted Gibbons*

(Signature) *Ted Gibbons*

Date: *3-29-93*

CALIBRATION
THERMOCOUPLE/TEMPERATURE METER

EQUIPMENT IDENTIFICATION	
THERMOCOUPLE	TEMPERATURE METER
MMT ID No.: 36" Std Inflex +15" flexible	MMT ID No.: -
Mfg: Omega	Mfg: Newport Laboratories
Type: Chromel - Alumel	Model: 268-KF1
Length: 51 inches overall	SN: 747-4363
Length of connecting (extension) wire: 20 ft	

Stack Thermocouple

EQUIPMENT CALIBRATION		
Reference temperature by mercury-in-glass thermometer, °F T_a	Temperature indicated by thermocouple and temperature meter, °F T_i	Deviation, °F $T_i - T_a$
39	41	2
68	69	1
176	175	-1
276	276	0
374	375	1

Calibration Performed by:

(Print) Bill + Ted

(Signature) Bill - Ted

Date: 4.6.93

CALIBRATION
THERMOCOUPLE/TEMPERATURE METER

EQUIPMENT IDENTIFICATION	
THERMOCOUPLE	TEMPERATURE METER
MNT ID No.: 50" mini std Fluke	MNT ID No.: Testing #1 Fluke
Mfg: FLUKE	Mfg: John Fluke MFG. Co
Type: Chromel - Alumel	Model: Fluke 51 K/J
Length: 50 inches	SN: 5210078
Length of connecting (extension) wire: 0 ft	

Probe thermocouple

EQUIPMENT CALIBRATION		
Reference temperature by mercury-in-glass thermometer, °F T_a	Temperature indicated by thermocouple and temperature meter, °F T_i	Deviation, °F $T_i - T_a$
40	41	1
74	75	1
128	129	1
175	177	2
274	275	1
385	386	1

Calibration Performed by:

(Print) Bill + Ted

(Signature) Bill + Ted

Date: 4.6.93

CALIBRATION
THERMOCOUPLE/TEMPERATURE METER

Last impinger		EQUIPMENT IDENTIFICATION	
THERMOCOUPLE		TEMPERATURE METER	
MMT ID No.: <i>Andersen Thermocouple</i>		MMT ID No.: -	
Mfg: <i>Andersen</i>		Mfg: <i>Newport Laboratories</i>	
Type: <i>Chromel-Alumel</i>		Model: <i>268-KF1</i>	
Length: <i>14"</i>		SN: <i>747-4363</i>	
Length of connecting (extension) wire: <i>20 Ft.</i>			

EQUIPMENT CALIBRATION		
Reference temperature by mercury-in-glass thermometer, °F T_a	Temperature indicated by thermocouple and temperature meter, °F T_i	Deviation, °F $T_i - T_a$
40	41	1
66	68	2
104	103	-1
130	128	-2

Calibration Performed by:

(Print) *Bill & Ted*(Signature) *Bill & Ted*Date: *4.6.93*

CALIBRATION
THERMOCOUPLE/TEMPERATURE METER

EQUIPMENT IDENTIFICATION	
THERMOCOUPLE	TEMPERATURE METER
MMT ID No.: #5 Console Meter Inlet	MMT ID No.: -
Mfg: Omega	Mfg: Newport Laboratories
Type: Chromel - Alumel	Model: 268-KFI
Length: 4.5"	SN: 747-4363
Length of connecting (extension) wire: 20 ft.	

EQUIPMENT CALIBRATION		
Reference temperature by mercury-in-glass thermometer, °F T_a	Temperature indicated by thermocouple and temperature meter, °F T_i	Deviation, °F $T_i - T_a$
39	40	1
66	66	0
103	102	-1
129	130	1

Calibration Performed by:

(Print) Bill - Ted

(Signature) Bill - Ted

Date: 4.6.93

CALIBRATION
THERMOCOUPLE/TEMPERATURE METER

EQUIPMENT IDENTIFICATION	
THERMOCOUPLE	TEMPERATURE METER
MMT ID No.: #5 Console Meter Outlet	MMT ID No.: -
Mfg: Omega	Mfg: Newport Laboratories
Type: Chromel-Alumel	Model: 268-KF1
Length: 4.5 inches	SN: 747-4363
Length of connecting (extension) wire: 20 ft.	

EQUIPMENT CALIBRATION		
Reference temperature by mercury-in-glass thermometer, °F T_a	Temperature indicated by thermocouple and temperature meter, °F T_i	Deviation, of $T_i - T_a$
40	41	1
65	66	1
103	101	-2
128	129	1

Calibration Performed by:

(Print) Bill - Ted

(Signature) Bill - Ted

Date: 4-6-93

June 18, 1993

MMT Report #9993

APPENDIX E: PROCESS DATA

1991

Air Pollution Control Equipment:
Type: Venturi Scrubber
Manufacturer: Barber Greene
Model: CC 99X102 Serial Number: 114320
Effective Date: 5-92

Process Operating Data:

[illegible]

GENERAL DATA FORM:

NET Job Number:

Date:

Wed 6.9.93

Propane Gas as Combustion Fuel.

Company :

L.C. Kruse & Sons

Source:

Scrubber Outlet

* if applicable

[illegible]

helped slave ~~think~~
Ericke

Operator Name Print: Daniel D. Schultz

Signature

Carl Schrey

FORM: S-GN-2

APPENDIX F: TEST PLAN & PROTOCOL

Minnesota Pollution Control Agency_____
Division of Air Quality
Stack Testing Protocol

The following is a summary of the testing requirements for the facility owned by L.C. Kruse and Sons:

I. Test Methods

- A. EPA Method 1 for the location of sampling ports and points. Location of the sampling ports must be approved before the test.

Check for cyclonic flow must be done whenever there is a cyclonic type of device directly upstream of the sampling location. Correction of cyclonic flow by straightening vanes must also be verified by checking the cyclonic flow before the test.

If the location does not meet the minimum requirements in Method 1, the testing firm must conduct the flow pattern evaluation and testing according to the alternative procedures in part 2.5 of EPA Method 1 (Three-dimensional directional probe).

- B. EPA Method 2 for velocity and volumetric flow rate. Three determinations: one measurement concurrently with each test run for pollutant.
- C. EPA Method 3 for gas analysis. Three determinations: one measurement on an integrated sample taken concurrently with each test run for pollutant.
- D. EPA Method 4 for the determination of moisture in the flue gases. Three determinations: one measurement concurrently with each test for pollutant.
- E. EPA Method 5 as amended in Exhibit C and Minn. Rules 7005.0500 for the determination of particulate matter emissions. Three one-hour determinations are required. The sampling time for each run must be at least 60 minutes and the sampling rate must be at least 0.9 dscm/hr (0.53 dscf/min). Report the results as dry catch only; and wet and dry catch separately.
- F. EPA Method 9 for the determination of visible emissions as amended in Minn. Rules part 7005.1860. Three hours of opacity readings are required for initial compliance.

One Hour per Yolanda Hernandez

AQD File No.: 323B

NOTE: The protocol, testplan, and information required in Exhibit C shall be submitted as part of the performance test report. Please note the new Asphalt Plant Operating Conditions During Stack Testing Sheet.

I. GENERAL INFORMATION

Permittee: L C Kruse and Sons, Inc.
Contact person: Darrin Kruse
Telephone number: 507/662-5205
Mailing address: Box 899, Lakefield, Minnesota

AQD File No. 323B

MPCA permitting engineer: GGS

Applicable regulations for
each source tested (be specific):

Reason for testing: Permit requirement

Is this test for initial
compliance demonstration: No

Drawings showing location
of sampling ports included: Shall be submitted to Tom Kosevich,
Compliance Determination Unit

Location of the plant at the time of the test: To be provided at pre-test meeting

Date when test plan was discussed and
agreed upon with the Permittee, or
Pre-test meeting needed: Pre-test meeting is scheduled for 21 May, 1993

II. NOTIFICATION REQUIREMENTS:

The Permittee must contact the Agency at least two weeks before the scheduled test to have a pre-test meeting and obtain all necessary approvals.

It is very important to allow at least two weeks before the test to review the testing requirements in order to avoid last minute cancellations due to inadequate testing conditions.

Among the potential problems that may need to be solved before the test are:

1. Unsuitable location of sampling ports. The stack may need to be extended and/or straightening vanes be installed.
2. Permittee must schedule the test at a time when the plant can be operated at 100% of rated capacity, and at maximum recycle rate if applicable.
3. Permittee must be ready to burn specified fuel. *waste oil*
4. Permittee may have to install pressure drop taps and gauges, as well as water flow rate measuring devices.
5. Permittee may have to install sampling taps on the fuel feeding line to the burner.

III. TEST PLAN

The following is the test plan developed for

A. Emission point(s) to be tested: (specify plant maker and model)

B. Parameters to be tested at each emission point:

C. Fuel sampling and analysis. (Fuel oils and used oil)

This is part of the compliance demonstration requirements. Please note that the test report will not be accepted without complete submittal of fuel analysis results of samples taken at the time of the test.

1. Sampling. One tap sample per particulate test run must be taken. The sample must be taken as close as possible to the burner, (somewhere in feeding line) to be representative of the fuel burned at the time of the test. The sample may be taken in a pint-size clean container, and according to the procedures in ASTM Method D 270-2546. Mix the three samples taken into a composite.

2. Analysis. The composite shall be analyzed in accordance with Exhibit D (dated 8 April, 1993).

D. Moisture content in the virgin and recycle aggregate.

1. Take two samples of each: the virgin and recycle aggregate per test run of particulates. Sample must be taken as close as possible to the feeding conveyor and during the corresponding run. Mix samples of virgin aggregate with the samples of recycle material in the same proportion as they enter the dryer, this will give one composite recycle/virgin sample per test run.

2. Perform one analysis of moisture content in each composite recycle/virgin aggregate sample as per ASTM or other recognized methodologies. A total of three analysis shall be performed, one per test run for particulates.

D. Moisture content in the virgin aggregate

1. Take two samples the virgin aggregate per test run of particulates. Sample must be taken as close as possible to the feeding conveyor and during the corresponding run. Mix the two samples of virgin aggregate, this will give one composite sample per test run.

2. Perform one analysis of moisture content in each composite sample as per ASTM or other recognized methodologies. A total of three analysis shall be performed, one per test run for particulates.

E. Operating Conditions during the Test

1. Operation must be at 100% of design capacity at the existing aggregate moisture content - no deliberate reduction of feed rate or fan speed during testing, except for nominal damper adjustment for proper combustion. - The test report must include copies of the manufacturer's specifications that define the design capacity of the plant as a function of the moisture content of the aggregate.

2. Must burn 100% of the highest emitting fuel to be listed in and allowed by the permit: Used oil (waste oil, crank oil), No. 6 fuel oil, No. 5 fuel oil, No. 4 fuel oil, No. 3 fuel oil (sometimes described as clarified or industrial fuel oil), No. 2 fuel oil, No. 1 fuel oil, LPG and natural gas.

3. The permit is to authorize recycling, then testing must be conducted while recycling and at the maximum ratio of recycle to virgin aggregate to be allowed by the permit:

4. Normal operation of the plant will be recycling of scrubber water, the test must be done under the same conditions:

5. Normal operation of the plant will be with recycling of collected ashes from the baghouse into the dryer, the test must be conducted under the same conditions.

F. Operating Data to Be Recorded during the Test

Operating data must be recorded during the test in its entirety i.e., particulates and visible emission observations. Operating data must be recorded every fifteen minutes. Please use the attached data sheet or equivalent.

Note: No test report will be accepted without a complete data sheet included.

1. During testing the following measurements must be made:

a) Pressure drop across the baghouse or venturi scrubber throat.

b) Scrubber water flow rate. If the measurement is done indirectly from a pump pressure gauge, the test report must include calculations, nomograms or calibration data used to compute gallons per minute of water.

c) Virgin and recycle aggregate input (ton per hour) as well as asphalt input (ton per hour). Provide the manufacturer's rating of the asphalt plant at different moisture contents in the aggregate.

d) Moisture content of the aggregate, and if applicable, the recycling material.

2. Please provide the following data:

a) Average fuel consumption rate (calculated or measured)

b) Quality of the scrubber water: recycling percent

c) Cleaning cycles of the baghouse

d) Operating data sheet enclosed

G. Testing schedules and testing firm:

Schedule: 6/9/93

Firm: MMT

H. Permitting engineer to witness the test: No