

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/


The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.3
Background Chapter	4
Reference:	11
Title:	<i>Exhaust Gas Characterization Studies Conducted on the Plant 10B for General Shale Corporation in Johnson City, TN, Guardian Systems, Inc., Leeds, AL, February 1984.</i>

*Background Report
Reference 11 (Section 4)*

GUARDIAN SYSTEMS INC.

**2809 Central Avenue
Birmingham, Alabama 35209
205/879-1850**



Test Report

EXHAUST GAS CHARACTERIZATION STUDY

CONDUCTED ON PLANT 10B

FOR

GENERAL SHALE PRODUCTS CORPORATION

IN

JOHNSON CITY, TENNESSEE

ON

FEBRUARY 7-9, 1984


Approved by: 

Tom Lotz
Director
Field Services Division

TABLE OF CONTENTS

Chapter		
I	Introduction	1
II	Test Results	
	Summary of Test Results	2
	Tables	
	1 Summarized Single Point Results ON	4
	2 Summarized Single Point Results OFF	5
	3 Impactor Results	6
	4 Summarized Multipoint Tests and Velocity Information.....	7
	Computer Input Parameters..	8
	Complete Test Results..	11
III	Sampling and Analytical Procedure	17
	Figures	
	1 Stack Breeching And Sample Point Location Diagram (32)	20
	2 Stack Breeching And Sample Point Location Diagram (16)	21
	3 Particulate Sampling Train Method 17	22
	4 Particulate Sampling Train Method 5	23
	5 Anderson Preseparator	24
	6 Mark III Hi-Temp Sampler	25
IV	Field Data	
	Nomenclature	26
	Equations.....	29
	Particulate Analysis	31
	Data Sheets	50
	Velocity Data Sheets	60
V	Plant Operational Data	
	Process Information (2-08-84)	62
	Process Information (2-09-84)	64
VI	Calibrations	
	Set #1	66
	Set #2	77

Introduction



I. INTRODUCTION

On February 7-9, 1984, Guardian Systems, Inc. performed a series of particulate emissions and particle size tests on General Shale Products Brick Plant Kiln No. 10B located in Johnson City, Tennessee. This unit has been modified from a dryer stack and an exhaust to only one stack. The purpose of this research project was to determine the results of recent modifications to the system and further characterize the particulate emissions during the two different modes of the kiln cycle which are "flashing" (referred to as OFF) and normal operation (referred to as ON).


Individual bricks are formed and stacked onto kiln cars. The cars are inserted on a regular basis into a long, continuous-fired tunnel kiln. As one car is discharged another is inserted. This provides a constant moving mass inside the kiln. Cars are pushed through the long kiln at a slow, methodical pace. By means of a coal firing process, heat is increased in each chamber until the total firing is complete. During this process the brick are subjected to "flashing" or the process of imparting color to the brick. To accomplish the "flashing" of the brick, the fan damper is partially closed and more coal is added to the kiln to produce a reducing atmosphere. The damper is then opened and the kiln returns to its normal mode. During the testing the OFF mode was approximately 1 minute and 30 seconds and the ON mode was approximately 3 minutes. To determine the emissions during each mode of the cycle two sampling trains were utilized.

Mr. Dave McNees, Corporate Representative, and Mr. Dick Green Plant Superintendent represented General Shale Products Corporation and Mr. Tom Lotz and Mr. Ashley Riley represented Guardian Systems, Inc.

Thee following personnel were present during the actual field sampling and performed the duties indicated:

Mr. Dave McNees	Provided production data
Mr. Dick Green	Stable operation of plant
Mr. Tom Lotz	Field sampling
Mr. Ashley Riley	Field sampling

Test Results



II. SUMMARY OF TEST RESULTS

Tables 1,2, & 3 are summaries of the mass test results for plant #10B during each mode. Table 4 is a breakdown of the particle size. The allowable emission rate was determined using the following equation:

$$E = 3.59 P^{0.62}$$

Where: E = Allowable emission rate, lbs/hour
P = process weight, tons/hour

The allowable emission rate, based on a process weight of 10.415 tons per hour, is 15.35 pounds per hour (See **Plant Operational Data**). The average actual emission rate is shown below. Since the ON test was for 40 minutes and the OFF test was for 20 minutes each hour these rates have been combined to produce a weighted average for a one hour test.

Test type	ON ¹	OFF ¹	Total Emissions ²
Test 1 & 3 Emissions, Single point, lbs/hr	9.16	7.98	8.77
Test 2 Emissions, Single point, lbs/hr	15.14	10.92	13.75
Test 5 & 6 Emissions, Multi-point, lbs/hr	14.32	7.50	12.07

¹ These values represent true emissions even though the sample time was less than one hour.

² These values represent time weighted emissions which can be compared directly with the allowable emission rate.

II. SUMMARY OF TEST RESULTS CONTINUED

As the results indicate the single point mass emissions were reduced from the last test series approximately 58 %, from 21.32 pounds per hour to 8.92 pounds per hour with the coal crusher off (Tables 1 & 2). The coal crusher seems to add an additional 60 % in emissions, which if left in the system would cause problems with your compliance status.

When we initially decided to sample a single point, I indicated that this type of sampling would provide relative numbers to be used in evaluating operational changes to the system. The modifications to this process seems to have been very effective in reducing flow and concentration of particulate emissions. Once the changes had been made, the next step was to determine the total emissions (multi-point) and compare to the allowable emission rate. Tests 5 & 6 were taken at 16 different points to obtain an overall sample. The results of these tests showed a total emission rate of 12.96 pounds per hour which is approximately 84 % of the allowable emission rate.

Two single point particle size distribution tests were conducted to obtain relative mass and particle size relationships. These results are presented in Table 4 and the results of the total mass presented in Tables 1 & 2 tests 4. As the total emissions indicated, one impactor test is not sufficient to characterize the total emissions, but should supply relative mass and particle size relationships. These tests indicate that approximately 80% of your particles are smaller than approximately 10.5 microns. This would only give, at best, a 20 % reduction of particulate emissions with the installation of some type of cyclonic collection device.

GUARDIAN ** SYSTEMS ** INCORPORATED
 2610 19TH STREET, SOUTH
 BIRMINGHAM, AL 35209
 205-879-1850
 SUMMARIZED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
 JOB NUMBER 43071

RUN NUMBER	1	2	3	4
DATE OF TEST	02/08/84	02/08/84	02/08/84	02/08/84
TIME OF TEST	1008-1050	1129-1214	1535-1617	1650-1726
LOCATION OF TEST	ON	ON	ON	IMP ON
STACK GAS TEMPERATURE DEGREES F	139	141	140	140
MOISTURE CONTENT, % V/V	5.20	5.20	5.19	5.19
OXYGEN CONTENT, % V/V	17.00	17.00	19.00	19.00
CARBON DIOXIDE CONTENT, % V/V	3.00	3.00	1.00	1.00
STACK GAS VELOCITY FEET PER SECOND	46.99	48.04	55.57	53.86
VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE	23,400	23,924	27,674	26,823
VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE	19,162	19,525	22,627	21,932
CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT	0.046	0.090	0.055	0.035
CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT	0.038	0.074	0.045	0.029
PARTICULATE MASS RATE (W/HR.)	7.63	15.14	10.68	6.59
% ISOINETIC	102.08	102.93	101.03	106.86

Table 1

GUARDIAN ** BY SYSTEMS ** INCORPORATED
2610 19TH. STREET, SOUTH
BIRMINGHAM, AL. 35209
205-879-1850

SUMMARIZED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43070

RUN NUMBER	1	2	3	4
DATE OF TEST	02/08/84	02/08/84	02/08/84	02/08/84
TIME OF TEST	1008-1050	1129-1214	1535-1620	1650-1750
LOCATION OF TEST	OFF	OFF	OFF	IMPOFF
STACK GAS TEMPERATURE DEGREES F	140	149	138	139
MOISTURE CONTENT, % V/V	5.68	5.69	5.69	5.68
OXYGEN CONTENT, % V/V	17.00	17.00	19.00	19.00
CARBON DIOXIDE CONTENT, % V/V	3.00	3.00	1.00	1.00
STACK GAS VELOCITY FEET PER SECOND	43.68	33.95	46.09	47.48
VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE	21.752	16.905	22.953	23.647
VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE	17.699	13.531	18.749	19.287
CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT	0.047	0.094	0.055	0.028
CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT	0.038	0.075	0.045	0.023
PARTICULATE MASS RATE (M/HR.)	7.14	10.92	8.82	4.67
% ISOKINETIC	102.66	98.49	98.26	96.13

Table 2

TABLE 3
IMPACTOR RESULTS

Test #	4	4
Location	Port A	Port B
	Point 5	Point 6
Type	ON	OFF
Date	2-08-84	2-08-84
Oxygen, %	19.0	19.0
Carbon Dioxide, %	1.0	1.0
Moisture, %	5.19	5.68
Flow thru impactor,cfm	0.513	0.465
Barometric Pressure,in. of mercury	29.36	29.36
Static Pressure, in. of water	-0.52	-0.12
Temperature of Impactor, °F	140	139
Pre impactor D ₅₀ (microns)	13.67	14.36
Cum.% of mass smaller than D ₅₀	100.00	100.00
Stage 1 D ₅₀ (microns)	11.02	11.58
Cum % of mass small than D ₅₀	88.98	90.14
Stage 2 D ₅₀ (microns)	10.21	10.73
Cum % of mass small than D ₅₀	78.46	81.95
Stage 3 D ₅₀ (microns)	6.63	6.97
Cum % of mass small than D ₅₀	55.31	58.13
Stage 4 D ₅₀ (microns)	4.27	4.49
Cum % of mass small than D ₅₀	37.51	41.49
Stage 5 D ₅₀ (microns)	2.47	2.61
Cum % of mass small than D ₅₀	23.36	25.62
Stage 6 D ₅₀ (microns)	1.20	1.27
Cum % of mass small than D ₅₀	11.93	14.08
Stage 7 D ₅₀ (microns)	0.75	0.79
Cum % of mass small than D ₅₀	3.34	9.48
Stage 8 D ₅₀ (microns)	0.37	0.40
Cum % of mass small than D ₅₀	0.00	8.71

GUARDIAN ** SYSTEMS ** INCORPORATED
2610 19TH STREET, SOUTH
BIRMINGHAM, AL 35209
205-879-1850

SUMMARIZED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43072

RUN NUMBER	5	6	7	8
DATE OF TEST	02/09/84	02/09/84	02/09/84	02/07/84
TIME OF TEST	0922-0947	1010-1102	0835-0845	1630-1645
LOCATION OF TEST	ON	OFF	VEL ON	VEL ON
STACK GAS TEMPERATURE DEGREES F	141	145	140	136
MOISTURE CONTENT, % V/V	7.07	7.13	7.07	5.20
OXYGEN CONTENT, % V/V	19.00	19.00	19.00	18.00
CARBON DIOXIDE CONTENT, % V/V	1.00	1.00	1.00	2.00
STACK GAS VELOCITY FEET PER SECOND	59.75	41.61	60.44	59.26
VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE	29,756	20,723	30,097	29,512
VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE	23,750	16,421	24,063	24,299
CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT	0.070	0.053		
CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT	0.056	0.042		
PARTICULATE MASS RATE (H/HR.)	14.32	7.50		
% ISOINETIC	105.50	107.32		

Table 4

GUARDIAN ** SYSTEMS ** INCORPORATED
2610 19TH. STREET, SOUTH
BIRMINGHAM, AL 35209
205-879-1850

COMPUTER INPUT PARAMETERS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43071

	1	2	3	4
RUN NUMBER	1	2	3	4
DATE	02/08/84	02/08/84	02/08/84	02/08/84
LOCATION	ON	ON	ON	IMP. ON
TIME	1008-1050	1129-1214	1535-1617	1650-1726
BAROMETRIC PRESSURE (IN. HG)	29.36	29.36	29.36	29.36
STATIC PRESSURE (IN. H2O)	- 0.540	- 0.540	- 0.520	- 0.520
RUN TIME (MINUTES)	27	30	30	18
METER VOLUME (CORRECTED)	20.330	23.992	27.302	9.238
STACK TEMPERATURE (°F)	139	141	140	140
METER TEMPERATURE (°F)	69	87	88	92
METER PRESSURE (IN. H2O)	1.54	1.64	2.20	0.62
SUR VELOCITY PRESSURE	0.774	0.790	0.911	0.883
MASS OF PARTICULATE (MG.)	60.3	134.0	92.8	19.8
ML. OF WATER COLLECTED	23.3	26.6	30.2	10.1
% OXYGEN	17.0	17.0	19.0	19.0
% CARBON DIOXIDE	3.0	3.0	1.0	1.0
% CARBON MONOXIDE	0.0	0.0	0.0	0.0
STACK AREA (SQ. FT.)	8.30	8.30	8.30	8.30
PITOT CORRECTION FACTOR	0.84	0.84	0.84	0.84
NOZZLE DIAMETER (IN.)	0.240	0.240	0.240	0.177

GUARDIAN ** SYSTEMS ** INCORPORATED
 2610 19TH. STREET, SOUTH
 BIRMINGHAM, AL 35209
 205-879-1850

COMPUTER INPUT PARAMETERS FOR GENERAL SHALE PRODUCTS CO
 JOB NUMBER 43070

PARAMETER	1	2	3	4
RUN NUMBER	1	2	3	4
DATE	02/08/84	02/08/84	02/08/84	02/08/84
LOCATION	OFF	OFF	OFF	IMPOFF
TIME	1008-1050	1129-1214	1535-1620	1650-1750
BAROMETRIC PRESSURE (IN. HG)	29.36	29.36	29.36	29.36
STATIC PRESSURE (IN. H2O)	- 0.370	- 0.370	- 0.140	- 0.120
RUN TIME (MINUTES)	14	15	15	20
METER VOLUME (CORRECTED)	10.841	8.836	12.172	9.065
STACK TEMPERATURE (°F)	140	149	138	139
METER TEMPERATURE (°F)	67	85	85	92
METER PRESSURE (IN. H2O)	1.54	0.92	1.76	0.56
SQR VELOCITY PRESSURE	0.678	0.523	0.710	0.735
MASS OF PARTICULATE (MG.)	32.7	51.4	41.4	15.6
ML. OF WATER COLLECTED	13.7	10.8	14.9	10.9
% OXYGEN	17.0	17.0	19.0	19.0
% CARBON DIOXIDE	3.0	3.0	1.0	1.0
% CARBON MONOXIDE	0.0	0.0	0.0	0.0
STACK AREA (SQ. FT.)	8.30	8.30	8.30	8.30
PITOT CORRECTION FACTOR	0.89	0.89	0.89	0.89
NOZZLE DIAMETER (IN.)	0.253	0.253	0.253	0.187

GUARDIAN ** SYSTEMS ** INCORPORATED
 2610 19TH. STREET, SOUTH
 BIRMINGHAM, AL 35209
 205-879-1850

COMPUTER INPUT PARAMETERS FOR GENERAL SHALE PRODUCTS CO
 JOB NUMBER 43072

PARAMETER	5	6	7	8
RUN NUMBER	5	6	7	8
DATE	02/09/84	02/09/84	02/09/84	02/07/84
LOCATION	ON	OFF	VEL ON	VEL ON
TIME	0922-0947	1010-1102	0835-0845	1630-1645
BAROMETRIC PRESSURE (IN. HG)	29.26	29.26	29.26	29.38
STATIC PRESSURE (IN. H2O)	- 0.130	- 0.130	- 0.120	- 0.640
RUN TIME (MINUTES)	16	16	16	27
METER VOLUME (CORRECTED)	10.887	7.902	10.887	20.330
STACK TEMPERATURE (°F)	141	145	140	136
METER TEMPERATURE (°F)	70	86	70	69
METER PRESSURE (IN. H2O)	1.34	0.66	1.34	1.54
SQR VELOCITY PRESSURE	0.974	0.676	0.986	0.922
MASS OF PARTICULATE (MG.)	48.6	25.9	0.0	0.0
ML. OF WATER COLLECTED	17.2	12.2	17.2	23.3
% OXYGEN	19.0	19.0	19.0	18.0
% CARBON DIOXIDE	1.0	1.0	1.0	2.0
% CARBON MONOXIDE	0.0	0.0	0.0	0.0
STACK AREA (SQ. FT.)	8.30	8.30	8.30	8.30
PITOT CORRECTION FACTOR	0.84	0.84	0.84	0.89
NOZZLE DIAMETER (IN.)	0.201	0.201		

GUARDIAN ** SYSTEMS ** INCORPORATED
2610 19TH. STREET, SOUTH
BIRMINGHAM, AL 35209
205-879-1850

COMPUTED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43071

RUN NUMBER	1	2	3	4
DATE OF TEST	02/08/84	02/08/84	02/08/84	02/08/84
LOCATION OF TEST	ON	ON	ON	IMP ON
1. STACK PRESSURE INCHES HG MILLIMETERS HG	29.32 744.74	29.32 744.74	29.32 744.77	29.32 744.77
2. METER PRESSURE INCHES HG MILLIMETERS HG	29.47 748.62	29.48 748.81	29.52 749.85	29.41 746.90
3. METER VOLUME DRY STANDARD CUBIC FEET DRY STANDARD CUBIC METERS	19.989 0.565	22.819 0.646	25.955 0.735	8.684 0.246
4. WATER VOLUME STANDARD CUBIC FEET STANDARD CUBIC METERS	1.097 0.031	1.252 0.035	1.422 0.040	0.475 0.013
5. MOISTURE CONTENT (%)	5.20	5.20	5.19	5.19
6. MOLECULAR WEIGHT DRY	29.16	29.16	28.92	28.92
7. MOLECULAR WEIGHT WET	28.58	28.58	28.35	28.35
8. STACK VELOCITY FEET PER SECOND METERS PER SECOND	46.99 14.32	48.04 14.64	55.57 16.94	53.86 16.42
9. VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE ACTUAL CUBIC METERS PER SECOND	23.400 11.04	23.924 11.29	27.674 13.06	26.823 12.66
10. VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE DRY STANDARD CUBIC METER PER SECOND	19.162 9.04	19.525 9.21	22.627 10.68	21.932 10.35

GUARDIAN ** SYSTEMS ** INCORPORATED
2610 19TH. STREET, SOUTH
BIRMINGHAM, AL 35209
205-879-1850

COMPUTED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43071

RUN NUMBER	1	2	3	4
DATE OF TEST	02/08/84	02/08/84	02/08/84	02/08/84
LOCATION OF TEST	ON	ON	ON	IMP ON
11. CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT GRAMS PER DRY STANDARD CUBIC METER	0.0465 0.1063	0.0904 0.2069	0.0531 0.1260	0.0351 0.0803
15. PARTICULATE MASS RATE (M/HR.)	7.63	15.14	10.68	6.59
16. VOLUME AT NOZZLE ACTUAL CUBIC FEET ACTUAL CUBIC METERS	24.411 0.691	27.960 0.792	31.747 0.899	10.622 0.301
17. CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT GRAMS PER ACTUAL CUBIC METER	0.0380 0.0870	0.0738 0.1689	0.0450 0.1030	0.0287 0.0656
18. % ISOKINETIC	102.08	102.93	101.03	106.86

GUARDIAN ** SYSTEMS ** INCORPORATED
2610 19TH STREET, SOUTH
BIRMINGHAM, AL 35209
205-879-1850

COMPUTED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43070

RUN NUMBER	1	2	3	4
DATE OF TEST	02/08/84	02/08/84	02/08/84	02/08/84
LOCATION OF TEST	OFF	OFF	OFF	IMPDF
1. STACK PRESSURE INCHES HG MILLIMETERS HG	29.33 745.05	29.33 745.05	29.35 745.48	29.35 745.52
2. METER PRESSURE INCHES HG MILLIMETERS HG	29.47 748.62	29.43 747.46	29.49 749.03	29.40 746.79
3. METER VOLUME DRY STANDARD CUBIC FEET DRY STANDARD CUBIC METERS	10.699 0.303	8.420 0.238	11.623 0.329	8.521 0.241
4. WATER VOLUME STANDARD CUBIC FEET STANDARD CUBIC METERS	0.645 0.018	0.508 0.014	0.701 0.020	0.513 0.015
5. MOISTURE CONTENT (%)	5.68	5.69	5.69	5.68
6. MOLECULAR WEIGHT DRY	29.16	29.16	29.92	28.92
7. MOLECULAR WEIGHT WET	28.53	28.52	28.30	28.30
8. STACK VELOCITY FEET PER SECOND METERS PER SECOND	43.68 13.31	33.95 10.35	46.09 14.05	47.48 14.47
9. VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE ACTUAL CUBIC METERS PER SECOND	21.752 10.27	16.905 7.98	22.953 10.83	23.647 11.16
10. VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE DRY STANDARD CUBIC METER PER SECOND	17.699 8.35	13.551 6.40	18.749 8.85	19.287 9.10

GUARDIAN ** SYSTEMS ** INCORPORATED
 2610 19TH. STREET, SOUTH
 BIRMINGHAM, AL 35209
 205-879-1850

COMPUTED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
 JOB NUMBER 43070

RUN NUMBER	1	2	3	4
DATE OF TEST	02/08/84	02/08/84	02/08/84	02/08/84
LOCATION OF TEST	OFF	OFF	OFF	IMPOFF
11. CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT GRAMS PER DRY STANDARD CUBIC METER	0.0471 0.1077	0.0940 0.2151	0.0549 0.1255	0.0282 0.0646
15. PARTICULATE MASS RATE (H/HR.)	7.14	10.92	8.82	4.67
16. VOLUME AT NOZZLE ACTUAL CUBIC FEET ACTUAL CUBIC METERS	13.150 0.372	10.504 0.297	14.230 0.403	10.448 0.296
17. CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT GRAMS PER ACTUAL CUBIC METER	0.0383 0.0876	0.0754 0.1724	0.0448 0.1025	0.0230 0.0527
18. % ISOKINETIC	102.66	98.49	98.26	96.13

GUARDIAN SYSTEMS INCORPORATED
2610 19TH STREET, SOUTH
BIRMINGHAM, AL 35209
205-879-1850

COMPUTED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
JOB NUMBER 43072


	5	6	7	8
RUN NUMBER	5	6	7	8
DATE OF TEST	02/09/84	02/09/84	02/09/84	02/07/84
LOCATION OF TEST	ON	OFF	VEL ON	VEL ON
1. STACK PRESSURE INCHES HG MILLIMETERS HG	29.25 742.96	29.25 742.96	29.25 742.96	29.33 745.06
2. METER PRESSURE INCHES HG MILLIMETERS HG	29.36 745.71	29.31 744.44	29.36 745.71	29.49 749.13
3. METER VOLUME DRY STANDARD CUBIC FEET DRY STANDARD CUBIC METERS	10.642 0.301	7.485 0.212	10.642 0.301	20.002 0.566
4. WATER VOLUME STANDARD CUBIC FEET STANDARD CUBIC METERS	0.810 0.023	0.574 0.016	0.810 0.023	1.097 0.031
5. MOISTURE CONTENT (%)	7.07	7.13	7.07	5.20
6. MOLECULAR WEIGHT DRY	28.92	28.92	28.92	29.04
7. MOLECULAR WEIGHT WET	28.15	28.14	28.15	28.47
8. STACK VELOCITY FEET PER SECOND METERS PER SECOND	59.75 18.21	41.61 12.68	60.44 18.42	59.26 18.06
9. VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE ACTUAL CUBIC METERS PER SECOND	29.756 14.04	20.723 9.78	30.097 14.20	29.512 13.93
10. VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE DRY STANDARD CUBIC METERS PER SECOND	23.750 11.21	16.421 7.75	24.063 11.36	24.299 11.47

GUARDIAN ** SYSTEMS ** INCORPORATED
 2610 19TH STREET, SOUTH
 BIRMINGHAM, AL 35209
 205-879-1850

COMPUTED AIR TEST RESULTS FOR GENERAL SHALE PRODUCTS CO
 JOB NUMBER 43072

RUN NUMBER	5	6	7	8
DATE OF TEST	02/09/84	02/09/84	02/09/84	02/07/84
LOCATION OF TEST	ON	OFF	VEL ON	VEL ON
11. CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT GRAMS PER DRY STANDARD CUBIC METER	0.0703 0.1609	0.0533 0.1219		
15. PARTICULATE MASS RATE (#/HR.)	14.32	7.50		
16. VOLUME AT NOZZLE ACTUAL CUBIC FEET ACTUAL CUBIC METERS	13.335 0.378	9.447 0.268		
17. CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT GRAMS PER ACTUAL CUBIC METER	0.0561 0.1284	0.0422 0.0965		
18. % ISOKINETIC	105.50	107.32		

Sampling & Analytical Procedures



III. SAMPLING AND ANALYTICAL PROCEDURES

General

All sampling and analytical procedures for determination of the particulate emissions from this source were conducted in accordance with the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 1-5 and 17 as amended, except where noted below. All impactor data reduction was based on EPA-600/7-78-042, March 1978, "A Computer - Based Cascade Impactor Data Reduction Systems".

The dimensions of the stack (see **Figures 1 & 2**) indicated that 16 points (8 per diameter) would be required for the velocity traverses and 32 points should be used for the Method 5 test. A complete velocity traverse (32 points) was taken prior to the Method 5 test and it was determined from that traverse that 16 points should provide accurate information. The Method 17 tests were taken at a single point to compare the results with the previous test. The OFF train sampled side B, Point 6 for tests 1,2,3 & the impactor test #4, while the ON train sampled side A, Point 5 for the same test sequence.

A TI-55 was used to calculate the sampling rates for the mass and particle sizing determinations. The sampling equipment used in these tests was manufactured by Research Appliance Corporation and was properly calibrated before these tests (See **Calibrations**). The impactor was a Mark III High Temperature Sampler with Pre separator (**Figures 5 & 6**) made of stainless steel with Inconel O-rings and glass fiber collection media with a backup filter. Gas analysis for CO₂ and O₂ were determined during each test by a Fyrite Gas Analyser.

Sampling Techniques Method 17

The particulate determinations were made by utilizing the sample train in Figure 3. Initial and final leak checks of the sampling system and pitot lines were performed as outlined in Method 17 and were recorded on the data sheets. The nozzle was calibrated before and after each test using a micrometer and was also recorded on the data sheets.

The gases were drawn through a stainless steel nozzle attached to a Gelman 47mm Filter Holder. The gases then pass through a glass fiber filter (Gelman, Class A) of 0.3 micron retention to remove particulate matter. The filter was maintained at the stack temperature.

The gases then pass through a condenser placed in an ice bath to maintain a maximum exit temperature of 68° F. This temperature was also recorded on the data sheets. The gases then pass through a pre-weighed drying column filled with indicating silica gel to remove any remaining moisture. The clean and cool gases then entered the meter box where the gas flow and temperature were measured. Particulate catches were placed in sealed petri dishes. Each acetone wash from the nozzle and filter holder was combined and placed in a sealed container. For the group of tests an acetone blank of approximately 200 milliliters was placed in a sealed container. These containers were transported to the laboratory for analysis.

Sampling Techniques Method 5

The particulate determinations were made by utilizing the sample train in Figure 4 . Initial and final leak checks of the sampling system and pitot lines were performed as outlined in Method 5 and were recorded on the data sheets. The nozzle was calibrated before and after each test using a micrometer and was also recorded on the data sheets.

The gases were drawn through a stainless steel nozzle attached to a heated glass lined probe. The probe heater was maintained at the proper setting to obtain an exit temperature of 248 ± 25 °F. (See **Calibrations**) The gases then passed through a glass fiber filter (Gelman) of 0.3 micron retention to remove particulate matter. The filter was maintained at a temperature of 248 ± 25 °F. The sample box temperatures were recorded at each point on the data sheets. The gases then pass through a condenser placed in an ice bath to maintain a maximum exit temperature of 68 °F. This temperature was also recorded on the data sheets.

The gases then pass through a pre-weighed drying column filled with indicating silica gel to remove any remaining moisture. The clean and cool gases then entered the meter box where the gas flow and temperature were measured. At the end of each test, the particulate catch was placed in sealed petri dish. Each acetone wash from the nozzle, probe and filter holder was combined and placed in a sealed container. For the group of tests an acetone blank of approximately 200 milliliters was placed in a sealed container. These containers were kept in a locked box and then transported to the Birmingham laboratory for analysis.

Sampling Techniques Particle size

The gases were drawn through a stainless steel nozzle attached to a preseparator and an Anderson impactor. By maintaining a constant flow through the filtering system the particules were aerodynamically separated and deposited on pre-weighed collection substrates. The filtering system was maintained at the stack temperature which was recorded at each point on the data sheets. The gases then pass through a condenser placed in an ice bath to maintain a maximum exit temperature of 68 °F. This temperature was also recorded on the data sheets.

The gases then pass through a pre-weighed drying column filled with indicating silica gel to remove any remaining moisture. The clean and cool gases then entered the meter box where the gas flow and temperature were measured. At the end of each test, the particulate catch was placed in sealed petri dish and then transported to the Birmingham laboratory for analysis.


Analysis Particulates

The Filters (Gelman, Class A, without organic binder, minimum 99.9% retention for particules of 0.3 microns as determined by DOP tests) were prepared for the field test by desiccating at 68 ± 10 °F at ambient pressure for twenty four (24) hours and weighed at intervals of at least six (6) hours to a constant weight (less than 0.5 milligrams change from previous reading). Impactor substrates were weighed to a constant weight of 0.05 milligrams change from the previous reading. Upon return to the laboratory, the filters were again subjected to the same procedures as outlined above. The weights were recorded in a bound laboratory book and transferred to the sheets laboratory sheets in this report. During each weighing the filter was not exposed to laboratory atmosphere for more than two (2) minutes and a relative humidity of less than fifty percent (50%).

The acetone washes and the acetone blank for the group of tests were evaporated to dryness in tared glass beakers. They were then desiccated for twenty-four (24) hour and weighed to a constant weight, utilizing the weight procedure previously mention for the filters.

STACK BREECHING AND SAMPLE POINT LOCATION DIAGRAM

32 Points



POINT # Distance From Wall (inches)

16	38.0
15	37.1
14	35.7
13	34.1
12	32.4
11	30.4
10	27.9
9	24.4
8	14.6
7	11.1
6	8.6
5	6.6
4	4.9
3	3.3
2	1.9
1	1.0





Figure 1

STACK BREECHING AND SAMPLE POINT LOCATION DIAGRAM 16 Points



POINT #	Distance From Wall (inches)
8	37.7
7	34.9
6	31.4
5	26.4
4	12.6
3	7.6
2	4.1
1	1.3




Figure 2

METHOD 17

PARTICULATE SAMPLING TRAIN




Figure 3

PARTICULATE SAMPLING TRAIN METHOD 5





Figure 4



ANDERSEN Samplers INC

4215-C WENDELL DRIVE
ATLANTA, GEORGIA 30336

404-691-1910

TOLL FREE: 800-241-6898

IMPACTOR PRESEPARATOR
FOR
ANDERSEN PARTICLE SIZING STACK SAMPLER

Goes through 3" sampling port

The Andersen Preimpactor is used upstream from the particle sizing sampler when measuring particle size distributions in stacks with high grain loadings or with large particle size fractions ($> 10\mu\text{m}$). This stainless steel (temperature limitation: 1500°F), high capacity, instrument removes large particles in situ and attaches directly to the Andersen particle sizing stack sampler, permitting insertion through standard 3" sampling ports. It can also be adapted to other particle sizing instruments. Eliminates inherent bounce-off and reentrainment problems associated with aerodynamic fractionating of large particles ($> 10\mu\text{m}$). In addition, this new circular orifice design permits more efficient impaction and less reentrainment than is possible with cyclonic designs.

Mark III Hi-Temp Sampler





Figure 6

Field Data



NOMENCLATURE

ACF - Actual Cubic Feet

ACFM - Actual Cubic Feet per minute

ACM - Actual Cubic Meters

ACMS - Actual Cubic Meters per second

An - Cross sectional area of nozzle, (ft²)

As - Area of Stack, (ft²)

Bws - Water vapor in the gas stream, proportion by volume
(dimensionless)

Ca - Acetone blank residue concentration, mg/g

c_a - Particulate Concentration, ACF

CFM - Cubic feet per minute

Cp - Pitot tube coefficient, (dimensionless)

c_s - Particulate Concentration, grains/DSCF

Cso₂ - Concentration of sulfur dioxide (dry basis) corrected
to standard conditions, lb/DSCF

C₁₂ - Particulate concentration (c_s adjusted to 12% excess air),
grains/DSCF

C₅₀ - Particulate concentration (c_s adjusted to 50% excess air),
grains/DSCF

DSCF - Dry Standard Cubic Feet

DSCFM - Dry Standard Cubic Feet per minute

DSCM - Dry Standard Cubic Meters

DSCMS - Dry Standard Cubic Meters per second

EA - Excess Air, %

I - Isokinetic Sampling, %

Km - Orifice Correction Factor, (dimensionless)

Kp - Pitot tube constant, 85.49 $\left[\frac{(\text{lb/lb-mole})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right]^{1/2}$

NOMENCLATURE - continued

- La - Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to 0.02 CFM or 4 percent of the average sampling rate, whichever is less.
- Li - Individual leakage rate observed during the leak check conducted prior to the "ith" component change (i = 1,2,3,...n), CFM.
- Lp - Leakage rate observed during the post test leak check, ft³/min. (cfm).
- Ma - Mass of residue of acetone after evaporation, mg.
- Md - Molecular weight of stack gas; dry basis, lb/lb-mole.
- Mn - Total amount of particulate matter collected, mg.
- Ms - Molecular weight of stack gas; wet basis, lb/lb-mole.
- Mw - Molecular weight of water, 18.0 g/g-mole (18.01 lb/lb-mole)
- ΔP - Velocity head of stack gas, in. H₂O
- Pa - Density of acetone, mg/ml
- Pbar - Barometric pressure at the sampling site, in. Hg
- Pg - Stack static pressure, in. H₂O
- Pm - Meter pressure, in. Hg
- PMR - Particulate Mass Rate, lbs per hour
- Ps - Absolute stack pressure, in. Hg
- Pstd - Standard absolute pressure, 29.92 in. Hg
- Pw - Density of water, 0.9982 g/ml (0.002201 lb/ml)
- Qa - Volumetric flow rate, ACFM
- Qs - Volumetric flow rate, DSCFM
- R - Ideal gas constant, 0.06236 mm Hg - m³/°K-g-mole (21.85 in. Hg-ft³/°R-lb-mole)
- SCF - Standard Cubic Foot
- ta - Ambient Temperature, °F
- tm - Average Temperature of meter, °F
- t_s - Average Temperature of stack, °F

NOMENCLATURE - continued

t_{std} - Standard Temperature, 68°F

NOTE: Capital "T" denotes degrees Rankin

V_a - Volume of acetone blank, ml

V_{aw} - Volume of acetone used in wash, ml

V_{lc} - Total volume of liquid collected in condenser and silica gel, ml

V_m - Volume of gas sample, as measured by the dry gas meter, ACF

V_{mc} - Volume of gas sample, corrected for leak, ACF

$V_{m(std)}$ - Volume of gas sample measured by the dry gas meter, corrected to standard conditions, DSCF

V_n - Volume collected at stack conditions through nozzle, ACF

V_s - Average stack gas velocity, ft/sec.

$V_{w(std)}$ - Volume of water in the gas sample, corrected to standard conditions, SCF

W_a - Weight of residue in acetone wash, mg

Y - Dry gas meter calibration factor, (dimensionless)

ΔH - Average pressure differential across the calibrated orifice, in. H_2O

ΔH_a - Value of ΔH measured for a specific orifice when operated under the following conditions: 0.75 cfm of dry air (M.W. = 29) at 68°F , 29.92 in. Hg.

$\sqrt{\Delta P}$ - Average of the square roots of the velocity pressure, in. H_2O

θ - Total sampling time, min.

θ_1 - Sampling time interval from the beginning of a run until the first component change, min.

θ_i - Sampling time interval between two successive component changes, beginning with the interval between the first and second changes, min.

θ_p - Sampling time interval from the final (n^{th}) component change until the end of the sampling run, min.

$\% \text{CO}_2$, $\% \text{O}_2$, $\% \text{N}_2$, $\% \text{CO}$ - Number percent (%) by volume (dry basis) of each compound in the stack gas.

EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_{m(\text{std})} = V_m Y \left(\frac{T_{\text{std}}}{T_m} \right) \left[\frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{P_{\text{std}}} \right]$$

$$4. \quad V_w(\text{std}) = 0.04707 V_{lc}$$

$$5. \quad B_{ws} = \frac{V_w(\text{std})}{V_{m(\text{std})} + V_w(\text{std})}$$

$$6. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$7. \quad M_s = M_d (1 - B_{ws}) + 18(B_{ws})$$

$$8. \quad v_s = K_p C_p (\sqrt{\Delta p}) \text{ avg.} \sqrt{\frac{T_s}{M_s P_s}}$$

$$9. \quad Q_a = (v_s) (A_s) (60)$$

$$10. \quad Q_s = Q_a (1 - B_{ws}) \left(\frac{528}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$

$$11. \quad c_s = [0.0154 (Mn/Vm_{\text{std}})]$$

$$12. \quad EA = \left[\frac{\%O_2 - 0.5 \%CO}{0.264 \%N_2 (\%O_2 - 0.5 \%CO)} \right] 100$$

$$13. \quad c_{50} = \frac{c_s}{1 - \left[\frac{(1.5)(\%O_2) - 0.133(\%N_2) - 0.75 (\%CO)}{21} \right]}$$

$$14. \quad c_{12} = c_s \frac{12}{\% CO_2}$$

EQUATIONS - continued

$$15. \quad \text{PMR} = (c_s)(Q_s) \left(\frac{60}{7000} \right)$$

$$16. \quad V_n = \frac{T_s}{P_s} \left[(0.002669)(V_{1c}) + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6} \right) \right]$$

$$17. \quad C_a = (0.0154)(M_n) / V_n$$

$$18. \quad I = \frac{100 V_n}{60 \theta v_s A_n}$$

$$19. \quad V_{mc} = V_m - (L_p - L_a) \theta$$

$$20. \quad W_a = C_a V_{aw} p_a$$

BLANK ANALYTICAL DATA

Plant General Shale
 Sample location 10 B
 Relative humidity 20%
 Type of blank Acc Top
 Liquid level at mark and container sealed ✓
 Density of blank (ρ_a) 1.7847 g/ml
 Blank volume (V_a) 300 ml
 Date and time of wt. 2/13/84 500 Gross wt. 112104.3 mg
 Date and time of wt. 2/13/84 500 Gross wt. 112104.3 mg
 Average gross wt. 112104.3 mg
 Tare wt. 112104.2 mg
 Weight of blank (m_a) 0.1 mg

$$Ca = \frac{m_a}{V_a \rho_a} = \frac{(0.1)}{(300)(1.7847)} = 0.0004 \text{ mg/g}$$

Note: In no case shall a blank residue greater than (0.01 mg/g) or 0.001% of the weight of blank used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]
 Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: General Stage Sample date: 2/8/84
 Sample location: 10B Run no.: 1 ON
 Sample recovery person: LOTZ/Riley Recovery date: 2/8/84
 Filter(s) no.: 5-16

MOISTURE

Impingers

See #4 Silica gel

Final volume (wt) _____ ml (gm) Final wt. _____ g _____ g

Initial volume (wt) _____ ml (gm) Initial wt. _____ g _____ g

Net volume (wt) _____ ml (gm) Net wt. _____ g _____ g

Total moisture _____ g

Color of silica gel _____

Description of impinger water _____

RECOVERED SAMPLE

Filter container no. #1 ON sealed ✓

Description of particulate on filter BLACK

Acetone rinse container no. #1 ON Liquid level marked ✓

Acetone blank container no. _____ Liquid level marked _____

Samples stored and locked _____

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody LOTZ

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant General Store Run No. 10N
 Sample location 10B
 Relative humidity 20%
 Density of acetone (pa) .7847 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse	✓	✓
filter(s)	✓	✓

Acetone rinse container no. 35 10N

Acetone rinse volume (Vaw) 35 ml

Acetone blank residue concentration (Ca) 0.0004 mg/g

Wa = Ca Vaw pa = (0.0004) (35) (.7847) = - mg

Date and time of wt 2/12/84 01:00 Gross wt 115487.0 mg

Date and time of wt 2/14/84 08:00 Gross wt 115487.0 mg

Average gross wt 115487.0 mg

Tare wt 115471.4 mg

Less acetone blank wt (Wa) 0 mg

Weight of particulate in acetone rinse 15.6 mg

Filter(s) container no. 10N

Date and time of wt 08:00 2/12/84 Gross wt 155.4 mg

Date and time of wt 08:00 2/14/84 Gross wt 155.4 mg

Average gross wt 155.4 mg

Tare wt 110.7 mg

Weight of particulate on filter(s) 44.7 mg

Weight of particulate in acetone rinse 15.6 mg

Total weight of particulate 60.3 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: General Store Sample date: 2-8-84
 Sample location: 10 B Run no.: 2 ON
 Sample recovery person: Lotz/Ruz Recovery date: 2-8-84
 Filter(s) no.: J-18

MOISTURE

Sec #4

Impingers

Silica gel

Final volume (wt) _____ ml (gm) Final wt. _____ g _____ g

Initial volume (wt) _____ ml (gm) Initial wt. _____ g _____ g

Net volume (wt) _____ ml (gm) Net wt. _____ g _____ g

Total moisture _____ g

Color of silica gel _____

Description of impinger water _____

RECOVERED SAMPLE

Filter container no. Ru #2 ON sealed ✓

Description of particulate on filter BLK

Acetone rinse container no. R #2 ON Liquid level marked ✓

Acetone blank container no. _____ Liquid level marked _____

Samples stored and locked _____

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody Lotz

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant Coral Shale Run No. 200
 Sample location 10 B
 Relative humidity 20%
 Density of acetone (pa) .7847 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse	✓	✓
filter(s)	✓	✓

Acetone rinse container no. 200
 Acetone rinse volume (Vaw) 25 ml
 Acetone blank residue concentration (Ca) 0.004 mg/g
 $W_a = Ca \cdot Vaw \cdot pa = (0.004) (25) (.7847) = -0-$ mg
 Date and time of wt 2/12/84 800 Gross wt 113.57.5 mg
 Date and time of wt 2/14/84 800 Gross wt 113.57.5 mg
 Average gross wt 113.57.5 mg
 Tare wt 113.22.5 mg
 Less acetone blank wt (Wa) -0- mg
 Weight of particulate in acetone rinse 31.0 mg

Filter(s) container no. 200
 Date and time of wt 2/12/84 800 Gross wt 215.5 mg
 Date and time of wt 2/14/84 800 Gross wt 215.5 mg
 Average gross wt 215.5 mg
 Tare wt 112.5 mg
 Weight of particulate on filter(s) 103.0 mg
 Weight of particulate in acetone rinse 31.0 mg
 Total weight of particulate 134.0 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst Lot

Signature of reviewer Lot

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Camel Shale Sample date: 2-8-84
 Sample location: 103 Run no.: 3 on
 Sample recovery person: W. J. P. L. Recovery date: 2-8-84
 Filter(s) no.: J-21

MOISTURE

see #7

Impingers Silica gel
 Final volume (wt) _____ ml (gm) Final wt. _____ g _____ g
 Initial volume (wt) _____ ml (gm) Initial wt. _____ g _____ g
 Net volume (wt) _____ ml (gm) Net wt. _____ g _____ g
 Total moisture _____ g
 Color of silica gel _____
 Description of impinger water _____

RECOVERED SAMPLE

Filter container no. Rn #3 on sealed ✓
 Description of particulate on filter BLACK

Acetone rinse container no. Rn #3 on Liquid level marked ✓
 Acetone blank container no. _____ Liquid level marked _____
 Samples stored and locked _____
 Remarks: _____

Date of laboratory custody _____
 Laboratory personnel taking custody W. J. P. L.
 Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant General Shale Run No. 300
 Sample location 10 B
 Relative humidity 20%
 Density of acetone (pa) .7547 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse filter(s)	<u>✓</u>	<u>✓</u>

Acetone rinse container no. 300
 Acetone rinse volume (Vaw) 25 ml
 Acetone blank residue concentration (Ca) .0004 mg/g
 $W_a = Ca \cdot Vaw \cdot pa = (.0004) (25) (.7547) = \underline{-0-}$ mg
 Date and time of wt 2/13/84 0800 Gross wt 111236.6 mg
 Date and time of wt 2/14/84 0800 Gross wt 111236.6 mg
 Average gross wt 111236.6 mg
 Tare wt 111224.1 mg
 Less acetone blank wt (Wa) -0- mg
 Weight of particulate in acetone rinse 15.5 mg

Filter(s) container no. 300
 Date and time of wt 2/12/84 0800 Gross wt 188.1 mg
 Date and time of wt 2/14/84 0800 Gross wt 188.1 mg
 Average gross wt 188.1 mg
 Tare wt 110.8 mg
 Weight of particulate on filter(s) 77.3 mg
 Weight of particulate in acetone rinse 15.5 mg
 Total weight of particulate 92.8 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Genl Shale Sample date: 2-8-84
Sample location: 103 Run no.: 4 ON 108
Sample recovery person: C. J. R. L. Recovery date: 2-8-84
Filter(s) no.: AB-1

MOISTURE

Impingers Silica gel #6
Final volume (wt) 73 ml (gm) Final wt. 1001.9 g
Initial volume (wt) 0 ml (gm) Initial wt. 984.7 g
Net volume (wt) 73 ml (gm) Net wt. 17.2 g
Total moisture 90.2 g
Color of silica gel MIXED
Description of impinger water CLEAR

RECOVERED SAMPLE

Filter container no. 4-ON-108 sealed ✓
Description of particulate on filter BLACK

Acetone rinse container no. NA Liquid level marked —
Acetone blank container no. — Liquid level marked —
Samples stored and locked —
Remarks: —

Date of laboratory custody —
Laboratory personnel taking custody LOT
Remarks: —

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Copied Share Sample date: 2-8-84
 Sample location: 103 Run no.: 1 OFF
 Sample recovery person: L. J. R. R. Recovery date: 2-8-84
 Filter(s) no.: 5-17

MOISTURE

Impingers Silica gel
 Final volume (wt) _____ ml (gm) Final wt. _____ g _____ g
 Initial volume (wt) _____ ml (gm) Initial wt. _____ g _____ g
 Net volume (wt) _____ ml (gm) Net wt. _____ g _____ g
 Total moisture _____ g
 Color of silica gel _____
 Description of impinger water _____

RECOVERED SAMPLE

Filter container no. 1-OFF sealed ✓
 Description of particulate on filter Black

Acetone rinse container no. 1-OFF Liquid level marked ✓
 Acetone blank container no. _____ Liquid level marked _____
 Samples stored and locked ✓

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant Genl Shale Run No. 10FF
 Sample location 10 B
 Relative humidity 20%
 Density of acetone (pa) .7547 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse filter(s)	<u>✓</u>	<u>✓</u>

Acetone rinse container no. 1-0FF
 Acetone rinse volume (Vaw) 30 ml
 Acetone blank residue concentration (Ca) 0.0004 mg/g
 $Wa = Ca Vaw pa = (.0004)(30)(.7547) = \underline{-0-}$ mg
 Date and time of wt 2/12/84 800 Gross wt 111245.3 mg
 Date and time of wt 2/14/84 800 Gross wt 111245.3 mg
 Average gross wt 111245.3 mg
 Tare wt 111236.6 mg
 Less acetone blank wt (Wa) - mg
 Weight of particulate in acetone rinse 8.7 mg

Filter(s) container no. 1-0FF
 Date and time of wt 2/12/84 800 Gross wt 134.8 mg
 Date and time of wt 2/14/84 800 Gross wt 134.8 mg
 Average gross wt 134.8 mg
 Tare wt 110.8 mg
 Weight of particulate on filter(s) 24.0 mg
 Weight of particulate in acetone rinse 8.7 mg
 Total weight of particulate 32.7 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst Lt

Signature of reviewer Lt

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Cecil Sharp Sample date: 2-8-84
 Sample location: 10B Run no.: 2 OFF
 Sample recovery person: W. R. R. R. Recovery date: 2-8-84
 Filter(s) no.: J-19

MOISTURE

Impingers	Silica gel
Final volume (wt) _____ ml(gm)	Final wt. _____ g _____ g
Initial volume (wt) _____ ml(gm)	Initial wt. _____ g _____ g
Net volume (wt) _____ ml(gm)	Net wt. _____ g _____ g
Total moisture _____ g	
Color of silica gel _____	
Description of impinger water _____	

RECOVERED SAMPLE

Filter container no. 2-OFF sealed ✓
 Description of particulate on filter Black

Acetone rinse container no. <u>2-OFF</u>	Liquid level marked <u>✓</u>
Acetone blank container no. _____	Liquid level marked _____
Samples stored and locked <u>✓</u>	

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant General Stone Run No. 20FF
 Sample location 10.3
 Relative humidity 20%
 Density of acetone (pa) 0.7847 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse filter(s)	<u>✓</u>	<u>✓</u>

Acetone rinse container no. 2-0FF

Acetone rinse volume (Vaw) 25 ml

Acetone blank residue concentration (Ca) 0.0004 mg/g

$W_a = C_a V_{aw} \rho_a = (0.0004)(25)(0.7847) =$ 0 mg

Date and time of wt 2/13/84 8:00 Gross wt 110.54.2 mg

Date and time of wt 2/14/84 5:00 Gross wt 110.54.2 mg

Average gross wt 110.54.2 mg

Tare wt 110.35.8 mg

Less acetone blank wt (W_a) -0- mg

Weight of particulate in acetone rinse 18.3 mg

Filter(s) container no. 2-0FF

Date and time of wt 2/12/84 5:00 Gross wt 146.0 mg

Date and time of wt 2/14/84 8:00 Gross wt 146.0 mg

Average gross wt 146.0 mg

Tare wt 112.5 mg

Weight of particulate on filter(s) 33.1 mg

Weight of particulate in acetone rinse 18.3 mg

Total weight of particulate 51.4 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Gul Stamp Sample date: 2-8-84
 Sample location: 103 Run no.: 3072
 Sample recovery person: Letz/Riley Recovery date: 2-8-84
 Filter(s) no.: 5-20

MOISTURE

Impingers Silica gel
 Final volume (wt) _____ ml(gm) Final wt. _____ g _____ g
 Initial volume (wt) _____ ml(gm) Initial wt. _____ g _____ g
 Net volume (wt) _____ ml(gm) Net wt. _____ g _____ g
 Total moisture _____ g
 Color of silica gel _____
 Description of impinger water _____

RECOVERED SAMPLE

Filter container no. 3-07F sealed ✓
 Description of particulate on filter BLACK.

Acetone rinse container no. 3-07F Liquid level marked _____
 Acetone blank container no. _____ Liquid level marked _____

Samples stored and locked _____

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant Oron Shale Run No. 3-FF
 Sample location 102
 Relative humidity 20%
 Density of acetone (pa) 0.7847 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse filter(s)	☒	☒

Acetone rinse container no. 3-FF

Acetone rinse volume (Vaw) _____ ml

Acetone blank residue concentration (Ca) 0.0004 mg/g

Wa = Ca Vaw pa = (0.0004) (25) (0.7847) = 0 mg

Date and time of wt 2/12/54 500 Gross wt 115.4828 mg

Date and time of wt 2/14/54 500 Gross wt 115.4969 mg

Average gross wt 115.4969 mg

Tare wt 115.48470 mg

Less acetone blank wt (Wa) -0- mg

Weight of particulate in acetone rinse 9.9 mg

Filter(s) container no. R-#3-FF

Date and time of wt 2/12/54 500 Gross wt 142.6 mg

Date and time of wt 4/14/54 500 Gross wt 142.6 mg

Average gross wt 142.6 mg

Tare wt 111.1 mg

Weight of particulate on filter(s) 31.5 mg

Weight of particulate in acetone rinse 9.9 mg

Total weight of particulate 41.4 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Gul Shab Sample date: 2-8-84
 Sample location: 16 D Run no.: 4-07F
 Sample recovery person: Lot 1/16/84 Recovery date: 2-8-84
 Filter(s) no.: 21

MOISTURE

Impingers DSM Silica gel
 Final volume (wt) 45 ml (gm) Final wt. 988.2 g
 Initial volume (wt) 0 ml (gm) Initial wt. 982.9 g
 Net volume (wt) 45 ml (gm) Net wt. 5.3 g
 Total moisture 50.3 g - for all 4 hrs.
 Color of silica gel white
 Description of impinger water clean

RECOVERED SAMPLE

Filter container no. _____ sealed _____
 Description of particulate on filter _____

Acetone rinse container no. _____	Liquid level marked _____
Acetone blank container no. _____	Liquid level marked _____

Samples stored and locked _____

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: General State Sample date: 2-9-84
Sample location: 10B Run no.: 50N
Sample recovery person: W. H. H. H. Recovery date: 2-9-84
Filter(s) no.: 6-3

MOISTURE

Impingers Silica gel # 5
Final volume (wt) 15 ml (gm) Final wt. 98.4 g
Initial volume (wt) 0 ml (gm) Initial wt. 98.2 g
Net volume (wt) 15 ml (gm) Net wt. 2.2 g
Total moisture 17.1 g
Color of silica gel mixed
Description of impinger water clean

RECOVERED SAMPLE

Filter container no. 2.50N sealed ☒
Description of particulate on filter BULK

Acetone rinse container no. 50N Liquid level marked ☒
Acetone blank container no. _____ Liquid level marked _____
Samples stored and locked ☒

Remarks: _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant General Shale. Run No. 50N
 Sample location 10B
 Relative humidity 20%
 Density of acetone (pa) .7847 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse filter(s)	<u>✓</u>	<u>✓</u>

Acetone rinse container no. 50N

Acetone rinse volume (Vaw) 100 ml

Acetone blank residue concentration (Ca) 0.0001 mg/g

Wa = Ca Vaw pa = (0.0001)(100)(.7847) = -0- mg

Date and time of wt 2/13/84 500 Gross wt 110.135.8 mg

Date and time of wt 2/14/84 800 Gross wt 110.135.8 mg

Average gross wt 110.135.8 mg

Tare wt 110.110.4 mg

Less acetone blank wt (Wa) -0- mg

Weight of particulate in acetone rinse 25.5 mg

Filter(s) container no. Ru 50N

Date and time of wt 2/13/84 500 Gross wt 260.4 mg

Date and time of wt 2/14/84 800 Gross wt 260.4 mg

Average gross wt 260.4 mg

Tare wt 237.3 mg

Weight of particulate on filter(s) 23.1 mg

Weight of particulate in acetone rinse 25.5 mg

Total weight of particulate 48.6 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: Coal Spoke Sample date: 2-9-84
 Sample location: 102 Run no.: 6 OFF
 Sample recovery person: L. J. / J. S. Recovery date: 2-9-84
 Filter(s) no.: 8

MOISTURE

Impingers Silica gel #5
 Final volume (wt) 10 ml (gm) Final wt. 992.6 g
 Initial volume (wt) 0 ml (gm) Initial wt. 990.4 g
 Net volume (wt) 10 ml (gm) Net wt. 2.2 g
 Total moisture 12.2 g
 Color of silica gel white
 Description of impinger water clear

RECOVERED SAMPLE

Filter container no. 6-OFF sealed ✓
 Description of particulate on filter BLACK

Acetone rinse container no. 6-OFF Liquid level marked ✓
 Acetone blank container no. _____ Liquid level marked _____
 Samples stored and locked ✓

Remarks: _____

Date of laboratory custody MA

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant Carl Shale Run No. 60FF
 Sample location 103
 Relative humidity 20%
 Density of acetone (pa) 7847 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse	✓	✓
filter(s)	✓	✓

Acetone rinse container no. 6-0FF
 Acetone rinse volume (Vaw) 105 ml
 Acetone blank residue concentration (Ca) 0.0004 mg/g
 $W_a = Ca \cdot Vaw \cdot pa = (.0004) (105) (7847) =$ — mg
 Date and time of wt 2/12/54 500 Gross wt 113164.9 mg
 Date and time of wt 4/14/54 500 Gross wt 113164.2 mg
 Average gross wt 112164.9 mg
 Tare wt 113153.5 mg
 Less acetone blank wt (Wa) -0- mg
 Weight of particulate in acetone rinse 11.4 mg

Filter(s) container no. 6-0FF
 Date and time of wt 2/12/54 500 Gross wt 257.3 mg
 Date and time of wt 2/11/54 500 Gross wt 257.3 mg
 Average gross wt 257.3 mg
 Tare wt 236.8 mg
 Weight of particulate on filter(s) 14.5 mg
 Weight of particulate in acetone rinse 11.4 mg
 Total weight of particulate 25.9 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

FIELD DATA SHEET

A5

PLANT

Genl Shub

RUN #

1

LOCATION

108

DATE

2-8-84

BARO. PRES.

29.36

TIME

1018-1050

GUARDIAN SYSTEMS INC.

2810 18th Street South
Birmingham, Alabama 35208
205/979-1850Cool
Sys
OFF

TIME		METER	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE "H2O	VELOCITY PRESSURE "H2O	VACUUM PRESSURE "Hg	STATIC PRESSURE "H2O	
MIN	DUR	VOL FT 3		IN	OUT	AVG						- .54	
Port A5		937.254	1	2	3		4	-				PROBE TIP SIZE BEFORE AFTER	
			140	53	54	54	34	-				.240	.240
3	3	939.6	140	53	54	54	34	-	1.53	.61	4.0	.240	.240
6	3	941.6	138	60	60	60	33	-	1.55	.61	4.5	.240	.240
9	3	944.2	137	65	60	63	34	-	1.56	.61	4.5		
12	3	946.4	138	72	60	66	34	-	1.57	.61	4.5	WATER	
15	3	948.7	138	78	62	70	35	-	1.51	.55	4.5	ml.	23.3
18	3	951.0	139	82	64	73	35	-	1.52	.55	5.0	gram	
21	3	953.3	140	85	66	76	34	-	1.53	.55	5.0	Total	23.3
24	3	955.7	141	90	69	80	34	-	1.53	.55	5.5	OPERATOR	
27	3	958.065	142	91	72	82	34	-	1.53	.55	6.0	Riley	2.917
30	3											Sample Box No. NA	
												Meter Box No. 700	
												Meter ΔH@ 1.54	
27	✓	20.811	139			65			1.54	.774	6.0	Pitot, CP .54	
		.5067								(.570)		Temp. Device 25	
		20.320										Probe No.	
												Probe Liner 1	
												Probe Htr. Set NA	
												Ambient Temp. 30°F	
												% O ₂ 17.0	
												% CO ₂ 3.0	
												NOTES	
												Orifice @ 7.5	
												Pitot 8.3-8.2	
												Meter	
												937.248	
												937.254	
												.006 @ 25.17	

FIELD DATA SHEET

GUARDIAN SYSTEMS INC.

2810 18th Street South
Birmingham, Alabama 35209
205/879-1850PLANT Gen StateRUN # 2LOCATION 10BDATE 2-8-84BARO. PRES. 29.34TIME 11:29-12:14out Cond system ext.

TIME	METER	STACK	METER TEMP. OF			IMP	BOX	METER	VELOCITY	VACUUM	STATIC PRESSURE "H ₂ O
			MIN	DUR	VOL FT ³						
Port A5		961.621	1	2	3	4					
3	3	964.0	143	80	77	79	33	-	1.66	.64 ²³	5.0
6	3	966.4	144	77	77	77	33	-	1.60	.62 ²⁴	5.0
9	3	968.8	144	82	77	80	33	-	1.61	.62 ²⁴	6.0
12	3	971.2	149	87	77	82	34	-	1.60	.62 ²³	7.5
15	3	973.6	149	93	78	86	34	-	1.62	.62 ²³	8.5
18	3	976.1	137	95	80	88	34	-	1.65	.62 ²⁴	9.5
21	3	978.6	136	99	81	90	34	-	1.66	.62 ²⁴	10.5
24	3	981.0	136	102	83	93	35	-	1.61	.62 ²³	12.0
27	3	983.5	137	106	85	96	36	-	1.68	.62 ²³	13.5
30	3	986.180	139	108	87	98	38	-	1.68	.62 ²¹	16.0
30		24.559	141			87			1.64	.790	16
		.9767								(.482)	
		23.992									
		986.165									
		986.160									
		.008 @ 16									

- .54

PROBE TIP SIZE

BEFORE AFTER

240	240
240	240
240	240

WATER

mi. 26.6

#6 gram

Total

OPERATOR

R. J.
2.907
Sample Box No. 4/AMeter Box No. 700Meter ΔH₀ 1.54Pitot, CP 84Temp. Device RIProbe No. N/AProbe Liner N/AProbe Htr. Set N/AAmbient Temp. 35% O₂ 17.90% CO₂ 30.90

NOTES

Orifice

Pitot

Meter

GUARDIAN SYSTEMS INC.

COAL system off

[illegible]

Re ✓
STMA ✓

system off
ON

Gran State

4

A-B

2-8-84

29.36

16⁵⁰ 17²⁶

2610 18th Street South
Birmingham, Alabama 35209
205/878-1850

G-1

FIELD DATA SHEET

OFF

PLANT GS.S.C RUN # 1
 LOCATION 108 DATE 2-8-84
 BARO. PRES. 29.36 TIME 1008-1050

GUARDIAN SYSTEMS INC.

2810 18th Street South
 Birmingham, Alabama 35209
 205/878-1850

	TIME		METER VOL. FT ³	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	VACUUM PRESSURE "Hg	STATIC PRESSURE "H ₂ O	
	MIN	DUR			IN	OUT	AVG						BEFORE	AFTER
<u>Prof 36</u>			<u>457.835</u>										<u>- .37</u>	
				(1)	(1)	(2)							PROBE TIP SIZE	
													BEFORE AFTER	
<u>100845</u>	<u>130</u>	<u>130</u>	<u>458.922</u>	<u>134</u>	<u>50</u>	<u>50</u>	<u>50</u>	<u>33</u>	<u>-</u>	<u>1.51</u>	<u>.46</u> ^(.95)	<u>7.8</u>	<u>.253</u>	<u>.253</u>
<u>101245</u>	<u>3</u>		<u>460.003</u>	<u>136</u>	<u>61</u>	<u>58</u>	<u>60</u>	<u>34</u>	<u>-</u>	<u>1.52</u>	<u>.46</u> ^(.95)	<u>7.8</u>	<u>.253</u>	<u>.253</u>
<u>10175</u>	<u>4.5</u>		<u>461.1</u>	<u>137</u>	<u>64</u>	<u>59</u>	<u>62</u>	<u>35</u>	<u>-</u>	<u>1.53</u>	<u>.46</u> ^(.95)	<u>8.1</u>	<u>.253</u>	<u>.253</u>
<u>102145</u>	<u>6</u>		<u>462.2</u>	<u>137</u>	<u>67</u>	<u>60</u>	<u>64</u>	<u>34</u>	<u>-</u>	<u>1.53</u>	<u>.46</u> ^(.95)	<u>8.2</u>		
<u>102615</u>	<u>7.5</u>		<u>463.3</u>	<u>138</u>	<u>70</u>	<u>62</u>	<u>66</u>	<u>34</u>	<u>-</u>	<u>1.54</u>	<u>.46</u> ^(.95)	<u>8.6</u>		
<u>103045</u>	<u>9</u>		<u>464.42</u>	<u>140</u>	<u>74</u>	<u>64</u>	<u>69</u>	<u>35</u>	<u>-</u>	<u>1.54</u>	<u>.46</u> ^(.95)	<u>8.9</u>		
<u>103415</u>	<u>10.5</u>		<u>465.6</u>	<u>143</u>	<u>77</u>	<u>66</u>	<u>72</u>	<u>36</u>	<u>-</u>	<u>1.54</u>	<u>.46</u> ^(.95)	<u>9.1</u>		
<u>103730</u>	<u>12</u>		<u>466.70</u>	<u>144</u>	<u>79</u>	<u>68</u>	<u>74</u>	<u>35</u>	<u>-</u>	<u>1.54</u>	<u>.46</u> ^(.94)	<u>9.2</u>		
<u>104100</u>	<u>13.5</u>		<u>467.816</u>	<u>145</u>	<u>83</u>	<u>70</u>	<u>76</u>	<u>36</u>	<u>-</u>	<u>1.55</u>	<u>.46</u> ^(.94)	<u>9.5</u>		
<u>104430</u>	<u>15</u>		<u>468.435</u>	<u>146</u>	<u>86</u>	<u>72</u>	<u>79</u>	<u>36</u>	<u>-</u>	<u>1.56</u>	<u>.46</u> ^(.94)	<u>9.7</u>		
<u>Prof 36</u>													WATER	
													ml. <u>13.7</u>	
													#5 <u>gram</u>	
													Total <u> </u>	
													OPERATOR	
													<u>1076</u>	
													<u>3.78850</u>	
													Sample Box No. <u>NA</u>	
													Meter Box No. <u>400</u>	
													Meter ΔH@ <u>1.74</u>	
													Pilot, CP <u>.89</u>	
													Temp. Device <u>RT</u>	
													Probe No. <u>51-2</u>	
													Probe Liner <u> </u>	
													Probe Htr. Set <u> </u>	
													Ambient Temp. <u>30</u>	
													% O ₂ <u>12.0</u>	
													% CO ₂ <u>5.0</u>	
													NOTES	
													Orifice <u>@ 7.5</u>	
													Pilot <u>8.2 7.2</u>	
													Meter <u>@ 25</u>	
													<u>457.815</u>	
													<u>457.527</u>	
													<u>.008 @ 25</u>	
													<u>8.29585</u>	
													<u>39" O.D. with.</u>	

GUARDIAN SYSTEMS INC.

208/878-1850

005/878
OFF

35208
Cool system ON

G-1

2610 18th Street South
Birmingham, Alabama 35209
205/878-1850

RUN # 3
DATE 2-8-54
TIME 1535-1620

OFF Card system

56

GUARDIAN SYSTEMS INC.

2610 18th Street South
Birmingham, Alabama 35208
205/879-1850

RUN # 4 IMP

DATE 2-8-84

TIME 1650-1700

G-1

FIELD DATA SHEET

PLANT GS J.C. RUN # 5
 LOCATION 103 DATE 2-9-84
 BARO. PRES. 29.26 TIME 922-947

GUARDIAN SYSTEMS INC.
 2810 18th Street South
 Birmingham, Alabama 35209
 205/878-1850

ON

	TIME		METER VOL FT 3	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE "H2O	VELOCITY PRESSURE "H2O	VACUUM PRESSURE "Hg	STATIC PRESSURE "H2O	
	MIN	DUR			IN	OUT	AVG						BEFORE	AFTER
<u>Point A</u>			<u>499.660</u>	<u>(1)</u>	<u>(2)</u>	<u>(3)</u>		<u>(4)</u>	<u>(5)</u>					
<u>6</u>	<u>1</u>	<u>1</u>	<u>500.3</u>	<u>136</u>	<u>62</u>	<u>62</u>	<u>62</u>	<u>33</u>	<u>235</u>	<u>1.13</u>	<u>.82</u> ^{.57}	<u>6.6</u>	<u>201</u>	<u>201</u>
<u>14</u>		<u>2</u>	<u>500.8</u>	<u>136</u>	<u>64</u>	<u>64</u>	<u>64</u>	<u>34</u>	<u>270</u>	<u>1.13</u>	<u>.82</u>	<u>6.6</u>	<u>201</u>	<u>201</u>
<u>12</u>		<u>3</u>	<u>501.4</u>	<u>139</u>	<u>65</u>	<u>64</u>	<u>64</u>	<u>35</u>	<u>265</u>	<u>.84</u>	<u>.64</u>	<u>6.6</u>	<u>201</u>	<u>201</u>
<u>10</u>		<u>4</u>	<u>502.0</u>	<u>140</u>	<u>66</u>	<u>64</u>	<u>65</u>	<u>35</u>	<u>260</u>	<u>.86</u>	<u>.70</u>	<u>6.0</u>		
<u>8</u>		<u>5</u>	<u>502.6</u>	<u>139</u>	<u>68</u>	<u>64</u>	<u>66</u>	<u>34</u>	<u>240</u>	<u>1.04</u>	<u>.78</u>	<u>6.3</u>	WATER	
<u>6</u>		<u>6</u>	<u>503.2</u>	<u>140</u>	<u>68</u>	<u>64</u>	<u>66</u>	<u>34</u>	<u>245</u>	<u>1.52</u>	<u>1.1</u>	<u>7.5</u>	ml. <u>15</u>	
<u>4</u>		<u>7</u>	<u>503.9</u>	<u>141</u>	<u>70</u>	<u>66</u>	<u>69</u>	<u>36</u>	<u>252</u>	<u>1.40</u>	<u>1.0</u> ^{.42}	<u>7.2</u>	#5 gram <u>2.2</u>	
<u>2</u>		<u>8</u>	<u>504.568</u>	<u>141</u>	<u>73</u>	<u>66</u>	<u>70</u>	<u>36</u>	<u>250</u>	<u>1.12</u>	<u>.80</u>	<u>6.9</u>	Total <u>17.2</u>	
<u>Point B</u>													OPERATOR <u>JS</u>	
<u>6</u>	<u>1</u>	<u>9</u>	<u>505.2</u>	<u>140</u>	<u>75</u>	<u>67</u>	<u>71</u>	<u>35</u>	<u>248</u>	<u>1.40</u>	<u>.98</u> ^{.86}	<u>7.7</u>	<u>155</u>	
<u>14</u>		<u>10</u>	<u>506.0</u>	<u>142</u>	<u>75</u>	<u>68</u>	<u>71</u>	<u>35</u>	<u>249</u>	<u>1.56</u>	<u>1.1</u>	<u>8.0</u>	Sample Box No. <u>1</u>	
<u>12</u>		<u>11</u>	<u>506.700</u>	<u>143</u>	<u>77</u>	<u>68</u>	<u>74</u>	<u>36</u>	<u>255</u>	<u>1.7</u>	<u>1.2</u>	<u>8.4</u>	Meter Box No. <u>400</u>	
<u>10</u>		<u>12</u>	<u>507.5</u>	<u>144</u>	<u>80</u>	<u>68</u>	<u>74</u>	<u>36</u>	<u>270</u>	<u>1.7</u>	<u>1.2</u> ^{.60}	<u>8.6</u>	Meter ΔH@ <u>1.74</u>	
<u>8</u>		<u>13</u>	<u>508.2</u>	<u>143</u>	<u>80</u>	<u>70</u>	<u>75</u>	<u>35</u>	<u>271</u>	<u>1.63</u>	<u>1.15</u>	<u>8.4</u>	Pitot, CP <u>.84</u>	
<u>6</u>		<u>14</u>	<u>508.950</u>	<u>145</u>	<u>82</u>	<u>70</u>	<u>76</u>	<u>36</u>	<u>273</u>	<u>1.56</u>	<u>1.1</u>	<u>8.4</u>	Temp. Device <u>2.11</u>	
<u>4</u>		<u>15</u>	<u>509.6</u>	<u>146</u>	<u>84</u>	<u>70</u>	<u>77</u>	<u>36</u>	<u>263</u>	<u>1.5</u>	<u>1.05</u> ^{.59}	<u>8.4</u>	Probe No. <u>5-N</u>	
<u>2</u>		<u>16</u>	<u>510.325</u>	<u>146</u>	<u>84</u>	<u>70</u>	<u>77</u>	<u>36</u>	<u>254</u>	<u>1.22</u>	<u>.86</u>	<u>7.8</u>	Probe Liner <u>GLASS</u>	
<u>6</u>		<u>16</u>	<u>10.665</u> ✓	<u>141</u> ✓			<u>70</u> ✓			<u>1.34</u> ✓	<u>.974</u> ✓	<u>8.6</u> ✓	Probe Htr. Set <u>20</u>	
			<u>1.0208</u>										Ambient Temp. <u>24</u>	
			<u>10.887</u> ✓										% O ₂ <u>19.0</u>	
													% CO ₂ <u>1.0</u>	
													NOTES	
													Orifice <u>✓</u>	
													Pitot <u>RVSW</u>	
													Meter	
													<u>499.660</u>	
													<u>499.650</u>	
													<u>101025</u>	

FIELD DATA SHEET

PLANT

Gaul Shro Sub C. 73 006

RUN #

LOCATION

108 (OFF)

DATE

2-9-84

BARO. PRES.

29.26

TIME

1010 - 1102

GUARDIAN SYSTEMS INC.

2810 18th Street South
Birmingham, Alabama 35208
805/879-1850

OFF

	TIME		METER VOL FT 3	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE H2O	VELOCITY PRESSURE H2O	VACUUM PRESSURE Hg	STATIC PRESSURE "H2O	
	MIN	DUR			IN	OUT	AVG						BEFORE	AFTER
Port B			510.605	(1)	(2)	(3)		(4)	(5)					
16	1	1	511.1	149	78	76	77	34	227	.75	.53	7.5	201	201
14		2	511.6	134	78	76	77	35	256	.82	.58	7.8	201	201
12		3	512.25	135	80	78	79	35	270	.86	.60	8.2	201	201
10		4	512.7	138	82	78	80	35	264	.86	.60	8.5		
8		5	513.2	140	85	81	83	35	265	.68	.47	8.0		
6		6	513.760	141	87	80	84	35	270	.63	.44	8.0		
4	11	7	514.2	142	87	81	84	35	271	.60	.42	8.1		
2	220	8	514.640	143	88	82	86	35	272	.43	.30	7.5		
Port A														
16	1	9	515.1	145	88	84	86	34	265	.58	.40	8.5		
14		10	515.6	147	90	86	88	35	263	.58	.40	8.6		
12		11	516.045	148	91	86	88	34	263	.61	.42	8.5		
10	7	12	516.5	150	94	87	90	36	263	.57	.40	8.6		
8	170	13	517.1	150	93	87	90	36	259	.70	.45	9.0		
6		14	517.570	150	94	88	91	35	252	.72	.50	9.1		
4	1400	15	518.1	151	97	89	93	35	253	.65	.45	9.0		
2	1700	16	518.536	154	95	90	93	35	270	.50	.38	8.7		
16	16	16	7.931	145						.66	.676			
			1.9963								(.971)			
			7.902											
			518.546											
			518.544											
			0.2010											

WATER

ml. 10

#5 gram 2.2

Total 12.2

OPERATOR

Sample Box No. 1

Meter Box No. 400

Meter ΔH@ 1.74

Pitot, CP .84

Temp. Device RTI

Probe No. 5-N

Probe Liner GUS

Probe Htr. Set 70

Ambient Temp. 30

% O2 15.0

% CO2 1.0

NOTES

Orifice

Pitot

Meter

R✓
STATIC

510.605


510.600

0.005

2810 18th Street South
Birmingham, Alabama 35209
205/878-1850

~~ON~~
PRI

#8



16³⁰
16²⁵

3-on 1% OFF

P. 14

.45

60

2810 18th Street South
Birmingham, Alabama 35209
205/878-1850

DATE 2-28-84

LOCATION STACK 10B

STACK I.D. 39

BAROMETRIC PRESSURE, in. Hg 29.26

STACK PRESSURE, in. H₂O - .12

PERCENT O₂ 19

PERCENT CO₂ 1

PITOT CORRECTION FACTOR .84


OPERATORS 6072/Rly

SCHEMATIC OF TRAVERSE POINT LAYOUT

61

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s) , in. H ₂ O	STACK TEMPERATURE (T _s), °F
A 1	.70	140
2	.75	142
3	.99	142
4	1.05	142
5	1.10	142
6	1.15	142
7	1.15	142
8	1.00	142
9	.78	142
10	.73	142
11	.75	142
12	.75	142
13	.85	141
14	.89	141
15	.92	141
16	.92	141
AVERAGE	.986✓	140✓

Plant Operation Data



PROCESS INFORMATION

PLANT: JOHNSON CITY 105

DATE: FEBRUARY 8, 1984

Brick Rate:

Car Schedule = 56 Minutes = 1.07 Cars/Hour
 Car Count = 3,883 S/S Brick/Car
 Hourly Rate = 4,160 S/S Brick/Hour
 Brick Weight = 4.8 Lbs.
 Brick Rate = 19,968 Lbs./Hour

Fuel Rate:

Total = 28.7 Therms/M Brick
 Coal = 10.22 Tons/Day
852 Lbs./Hour = 100 % of Btu's
 Natural Gas = - 0 - MCF/Day
 Cu. Ft./Hour = - 0 - % of Btu's

Total Process Weight:

19,968 Lbs. Brick/Hour
 + 852 Lbs. Coal/Hour
20,820 Total Lbs./Hour
10.41 Tons/Hour

Coal Analysis:

14,029 Btu/Lb. _____
 _____ Sulfur _____
3.5 % Ash _____

Allowable Emissions:

$$3.59 \times 0.62$$

$$3.59 (10.41)^{0.62} = 15.34 \text{ LBS. / HR.}$$

GREEN BRICK AT 8:00 A.M.

STANDARD _____

SPECIAL _____

SOLID _____

PAVER _____

OTHER _____

44 con

	1	2	3
PUSHER PRESSURE			
TURBO PRESSURE			
GAS PRESSURE			
PREDRYER SUPPLY TEMP.			
DRYER EXHAUST DRAFT			
DRYER EXHAUST TEMP.			
COLD AIR SUPPLY TEMP.			
KILN EXHAUST DRAFT			
UNDER CAR TEMP.	340°		
COAL SCREENING			
COAL DRYER TEMP.			
FLASHING SYSTEM			
TURBO BLOWER (amps)			
DRYER SUPPLY (amps)			
DRYER EXHAUST (amps)			
COLD AIR SUPPLY (amps)			
KILN EXHAUST (amps)			
IMP MILL (amps)			
IMP MILL BLOWER (amps)			

	1	2	3
<u>PREDRYER</u>			
WET BULB			
DRY BULB			
HUMIDITY			
DEW POINT			
BRICK BODY			
FANS			
<u>DRYER</u>			
WET BULB			
DRY BULB			
HUMIDITY			
DEW POINT			
BRICK BODY			
FANS			
<u>DRYER RECIRCULATING FANS</u>			
NO. 1			
NO. 2			
NO. 3			
NO. 4			

48	47
----	----

	ENERGY METERS			
	GAS	COAL	FLASHING	ELECTRIC
END		11401		
BEGIN		10288		
TOTAL		1113		

% Ash
3.5%

CONTROL VALVE PRESSURE

NO. 1	11%
NO. 2	10%
NO. 3	20%
NO. 4	05 96%

GAS:	BTU	THERMS	COST	THERM % OF TOTAL	COST PER M	THERMS PER M
_____ c.f. @ 1,040 = _____	100,000	_____ @ _____/therm = \$ _____				
COAL:						
<u>20,446</u> lb. @ <u>14029</u> = <u>286878</u>	100,000	= <u>2868</u> @ <u>186</u> /therm = \$ <u>53345</u>	<u>100%</u>	<u>5.34</u>	<u>28.7</u>	
FLASHING:						
_____ lb. @ _____ = _____	100,000	_____ @ _____/therm = \$ _____				

GAS: \$ _____ per MCF, _____ ¢ per therm
TOTAL THERMS 2868
TOTAL THERMS PER M BRICK 2868
KWHR PER M BRICK _____
KWHR COST PER M BRICK _____

COAL: \$ _____ per ton, _____ ¢ per therm
BTU PER POUND OF BRICK 820
AVERAGE COST PER THERM .186
TOTAL COST -533.45
COST PER M BRICK 5.34

PROCESS INFORMATION

PLANT: JOHNSON CITY 108

DATE: FEBRUARY 9, 1984

Brick Rate:

Car Schedule = 56 Minutes = 1.07 Cars/Hour
 Car Count = 3,883 S/S Brick/Car
 Hourly Rate = 4,160 S/S Brick/Hour
 Brick Weight = 4.8 Lbs.
 Brick Rate = 19,968 Lbs./Hour

Fuel Rate:

Total = 29.3 Therms/M Brick
 Coal = 10.44 Tons/Day
870 Lbs./Hour = 100 % of Btu's
 Natural Gas = - 0 - MCF/Day
- 0 - Cu. Ft./Hour = - 0 - % of Btu's

Total Process Weight:

19,968 Lbs. Brick/Hour
 + 870 Lbs. Coal/Hour
20,838 Total Lbs./Hour
10.42 Tons/Hour

Coal Analysis:

14,029 Btu/Lb. _____
 _____ Sulfur _____
3.5% Ash _____

Allowable Emissions:

$$3.59 \text{ P } 0.62$$

$$3.59 (10.42) 0.62 = 15.35 \text{ LBS./HR.}$$

SUPERVISOR Saylor/DeSilvey
KILN SCHEDULE 56min.
PRODUCTION 99,840
TYPE BRICK _____
TOTAL KILN HOURS _____
KEY CHEK AVERAGE _____

DATE 2-10-84
GREEN BRICK WEIGHT _____
BURNED BRICK WEIGHT _____
CARS BURNED 26
TOTAL BRICK BURNED 99,840
TOTAL BRICK WEIGHT _____

GREEN BRICK AT 8:00 A.M.
STANDARD ☒ 19
SPECIAL _____ 29
SOLID _____ 39
PAVER _____ 49
OTHER _____ 59
610
55

	1	2	3
PUSHER PRESSURE	<u>250</u>		
TURBO PRESSURE	<u>25</u>		
GAS PRESSURE	<u>—</u>		
PREDRYER SUPPLY TEMP.	<u>165</u>		
DRYER EXHAUST DRAFT	<u>25</u>		
DRYER EXHAUST TEMP.	<u>125</u>		
COLD AIR SUPPLY TEMP.	<u>—</u>		
KILN EXHAUST DRAFT	<u>50</u>		
UNDER CAR TEMP.	<u>330°</u>		
COAL SCREENING	<u>OK</u>		
COAL DRYER TEMP.	<u>300</u>		
FLASHING SYSTEM	<u>OK</u>		
TURBO BLOWER (amps)	<u>33</u>		
DRYER SUPPLY (amps)	<u>19</u>		
DRYER EXHAUST (amps)	<u>—</u>		
COLD AIR SUPPLY (amps)	<u>9</u>		
KILN EXHAUST (amps)	<u>—</u>		
IMP MILL (amps)	<u>20</u>		
IMP MILL BLOWER (amps)	<u>40</u>		

	1	2	3
PREDRYER			
WET BULB			
DRY BULB			
HUMIDITY			
DEW POINT			
BRICK BODY			
FANS			
DRYER			
WET BULB			
DRY BULB			
HUMIDITY			
DEW POINT			
BRICK BODY			
FANS			
DRYER RECIRCULATING FANS			
NO. 1	<u>175</u>		
NO. 2	<u>190</u>		
NO. 3	<u>300</u>		
NO. 4	<u>300</u>		


	GAS	COAL	FLASHING	ELECTRIC
END		<u>1238</u>		
BEGIN		<u>1101</u>		
TOTAL		<u>1137</u>		

% Ash
3.5%

	CONTROL VALVE PRESSURE
NO. 1	<u>14%</u>
NO. 2	<u>11%</u>
NO. 3	<u>17%</u>
NO. 4	<u>90%</u>

	GAS	BTU	THERMS	COST	THERM % OF TOTAL	COST PER M	THERMS PER M
GAS:							
	c.f. @ 1,040			@ /therm = \$			
COAL:							
	<u>20887</u> lb. @ <u>14029</u>	<u>293023</u>	<u>2930</u> @ <u>.186</u>	/therm = \$ <u>544.98</u>	<u>100%</u>	<u>5.16</u>	<u>29.3</u>
		<u>100,000</u>					
FLASHING:							
	lb. @		@ /therm = \$				
		<u>100,000</u>					
GAS:	\$	per MCF,	\$	per therm			
TOTAL THERMS		<u>2930</u>					
TOTAL THERMS PER M BRICK		<u>29.3</u>					
KWHR PER M BRICK							
KWHR COST PER M BRICK							
COAL:	\$	per ton,	\$	per therm			
BTU PER POUND OF BRICK		<u>837</u>					
AVERAGE COST PER THERM		<u>.186</u>					
TOTAL COST		<u>544.98</u>					
COST PER M BRICK		<u>5.16</u>					

Calibrations



VL CALIBRATIONS

General

For each test the meter volume was adjusted using the average meter pressure during the test. For example, with an average meter pressure of 1.54 for box # 400 a 1.50 "H₂O was used to compare to the original calibration point, and a meter calibration factor of 1.0208 was multiplied by the sample volume to obtain the correct volume.

The equipment used during these tests was as follows:

Test Condition: OFF

Meter Box: #400

Stack Temperature: OMEGA II

Condenser: #1

Test Condition: ON

Meter Box: #700

Stack Temperature: OMEGA I

Condenser: #2

The average temperature of the stack was 141^o F. Both the OMEGA II and OMEGA I were recalibrated at 140^o F and agreed exactly with an ASTM mercury-in-glass reference thermometer. The intercomponent spacings and the face opening alignment of each Pitot Tube assembly was rechecked and no changes were noticed; therefore, it was assumed that the coefficient of the assembly had not changed.

Set #1

Gauge	Average Test Condition Temperature	Gauge Reading	Reference Reading	Difference
Impinger 2/3/84 (Pre) #1		60	Room Temp 60	—
Meter In 400 (Pre) 2/3/84		60	Room Temp 60	—
Meter Out 2/3/84 (Pre) 400		60	Room Temp 60	—
Filter Heated Area 2/3/84 (Pre) #1		240	248 ± 25°F 240	—
Stack 2/10/84 (Post) 141 Orig. #1	141	140	Stack Temp ° F 140	—

Post Test

Run 1

Run 2

Run 3

Train Leak Rate

_____ CFM _____ CFM _____ CFM

Pitot Leak Check

Pre Test (Answer Yes or No)

Orsat Leak Check

Metering System Leak Check

Barometer Calibrated

Sample Bag Leak Check (if used)

Signature

[Signature]

Title

Point

Date

2/10/84

Type A Glass Fiber Filters

FEATURES

- High tensile strength. ■ Excellent handling characteristics. ■ Good wetting properties. ■ Minimum of 99.9% retention for particles of .3 μ m as determined by DOP tests. ■ Binder free.

This is the original glass fiber filter pioneered by Gelman Instrument Company over 15 years ago. It continues to be widely used for high volume sampling. Since zinc is one of the raw materials incorporated in the glass fibers, Type A Filters have a variable zinc content. Another component of the filter, sulfuric acid, is used as a dispersion medium, making the sheets unsuitable for measurement of sulfates.

Type A Glass Fiber Filters are less likely to develop static charge or tear than other glass fiber media types. They are used extensively in applications where zinc and iron content is not important, or where sulfate content is not being determined.

Size	37 mm	47 mm	102 mm	8"x10"
Product No.	61715	61694	61696	61701
Filters/Pkg.	500	100	100	100

TYPE A GLASS FIBER FILTER SPECIFICATION REPORT

The following physical/chemical properties represent typical, average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/8" x 10" sheet).

ELEMENTS:

Antimony	.30	Manganese	.200
Arsenic	.30	Mercury	.100
Beryllium	.1	Molybdenum	.10
Bismuth	.10	Nickel	.10
Cadmium	.5	Selenium	.5000
Chromium	.10	Tin	.10
Cobalt	.10	Titanium	.170
Copper	.2	Vanadium	.10
Iron	.2300	Zinc	.5000
Lead	.20		to 25,000

OTHER PHYSICALS:

BSO	.522	Flow Resistance (Max.)	
*pH	.8.5	@ 320 cm/min.	.80 mm
DOP @320/cm/min		Flow Rate (air)	
(ASTM Method 2986)	.99.9%	lpm/cm ² @ 70 cm Hg	.50
Tensile Strength		Max. Use Temp.	.400°C
(Fed. Spec. UUP31B)	.750 gr	Static Properties	Low
Weight,		Ability to	
8"x10" sheet	.4.0±.3 gr.	Fold	Excellent

WATER EXTRACTABLE IONS:

Sulfate	.100	Chloride	.1500
Nitrate	.50	Fluoride	.15
Ammonia	.20		

*pH—Gelman Procedure:

- 500 ml distilled water.
- Add 15 drops saturated KCl solution.
- Shred one 8"x10" sheet and soak in prepared water for one hour.
- Run pH at ambient temperature.

Type A/E Glass Fiber Filters

FEATURES

- Low trace metals. ■ Medium Handling characteristics. ■ Available in all sizes. ■ Minimum of 99.9% retention for particles of .3 μ m as determined by DOP tests. ■ Binder free.

Type A/E Glass Fiber Filters are composed of low acid soluble glass fiber. They contain low levels of both zinc and iron. The filters do react with atmospheric sulfur dioxide; and therefore, when high levels of sulfur are expected; corrections for this reaction should be accounted for.

Type A/E Glass Fiber Filters are binder free and ideal for gravimetric analysis of air pollutants. This pure, organic free filter is the basis for procedures widely used in determining municipal and industrial air polluting substances.

Size	25 mm	37 mm	47 mm	102 mm	8"x10"
Product No.	61630	61652	61631	61633	61638
Filters/Pkg.	500	500	100	100	100

TYPE A/E GLASS FIBER FILTER SPECIFICATION REPORT

The following physical/chemical properties represent typical, average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/8" x 10" sheet).

ELEMENTS:

Antimony	.20	Manganese	.2
Arsenic	.20	Mercury	.80
Beryllium	.1	Molybdenum	.10
Bismuth	.10	Nickel	.10
Cadmium	.2	Selenium	.200
Chromium	.10	Tin	.10
Cobalt	.10	Titanium	.10
Copper	.2	Vanadium	.10
Iron	100-1800	Zinc	.90
Lead	.10		

OTHER PHYSICALS:

BSO	.522	Flow Resistance (Max.)	
*pH	.9.0	@ 320 cm/min.	.80 mm
DOP @320/cm/min		Flow Rate (air)	
ASTM Methods 2986)	.99.9%	lpm/cm ² @ 70 cm Hg	.60
Tensile Strength		Max. Use Temp.	.400°C
(Fed. Spec. UUP31B)	.600 gr.	Static Properties	Medium
Weight		Ability to	
8"x10" sheet	.4.0±.3 gr.	Fold	Good

WATER EXTRACTABLE IONS:

Sulfate	.600	Chloride	.1500
Nitrate	.115	Fluoride	.87
Ammonia	.13		

*pH—Gelman Procedure:

- 500 ml distilled water.
- Add 15 drops saturated KCl solution.
- Shred one 8"x10" sheet and soak in prepared water for one hour.
- Run pH at ambient temperature.

METER CALIBRATION FORM

Date 9/12/83

Box No. 400

P_{bar} = 30.00 in. Hg

Calibrated by For Lot

Orifice Manometer Set- ting ΔH (in. H ₂ O)	Δ wtm (in. H ₂ O)	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Avg. Temp. Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Inlet	Outlet
2.5 @ 21" H ₂ O	-1.3	0.002	14.371	404.517	418.752	26.4	26.2	105 123	90 98
2.0 @ 21" H ₂ O	-1.05	14.371	26.558	418.752	431.022	26.2	26.0	100 124	98 103
1.5 @ 21" H ₂ O	-0.80	26.558	37.175	431.022	441.607	26.0	26.0	120 123	102 105
1.0 @ 21" H ₂ O	-0.60	37.175	46.224	441.607	450.680	26.0	26.0	121 125	105 107
0.5 @ 21" H ₂ O	-0.38	46.224	52.432	450.680	457.094	26.0	26.0	123 102	107 107

Pump must be operated for at least 15 minutes at each ΔH setting (.5, 1, 1.5, 2 and 3).

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

P_{wtm} = P_{bar} - $\frac{\Delta wtm}{13.6}$

P_{dgm} = P_{bar} + $\frac{\Delta H}{13.6}$

Δwtm = pressure on wet test meter in inches of H₂O

Y = meter calibration factor

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$Y = \frac{(\text{wet final} - \text{wet initial})(T_{dgm})(P_{wtm})}{(\text{dry final} - \text{dry initial})(28.316)(T_{wtm})(P_{dgm})}$$

or (1)

$$\bar{Y} = \frac{\sum Y}{5}$$

Meter Tolerance = 1.00 ± 0.01

If the meter calibration factor is not within the allowable tolerance, the calibration factory Y may be used to mathematically correct the gas meter dial readings to the proper values instead of physically adjusting the dry gas meter dials to correspond to the wet test meter readings.

$$\begin{aligned} &1.0075 \\ &1.0167 \\ &1.0208 \\ &1.0242 \\ &0.9963 \\ \hline &1.0131 = 1.01 \end{aligned}$$

ORIFICE CALIBRATION FORM

Date 9/12/83Meter Box No. 400P_{bar} 30.00Calibrated By Lon LA

ΔH	V ₁	V ₂	θ	t ₁	t ₂	V ₂ - V ₁	Q _m	K _m
in. H ₂ O	CF	CF	Sec.	°F	°F	CF		
2.5	444.512	448.753	930	114	94	14.226	.9115	.7247
2.0	444.753	431.022	900	122	100.5	12.229	.8133	.7182
1.5	431.022	441.667	900	121.5	103.5	10.585	.7090	.7206
1.0	441.667	432.030	930	123.0	103.0	9.073	.5906	.7332
0.5	432.030	437.051	950	102.5	107.0	6.414	.4203	.7367
Average K _m								.7267

V₁ = Dry gas meter reading at the start of each testV₂ = Dry gas meter reading at the end of each testt₁ = Dry gas meter inlet temperaturet₂ = Dry gas meter outlet temperatureCalculations

$$1. Q_m = \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{\frac{t_1 + t_2 + 460}{2}} \right] (60)(Y)$$

$$2. K_m = \frac{Q_m}{\sqrt{\frac{P_m M_m}{T_m \Delta H}}} \quad \begin{array}{l} M_m = 29 \\ T_m = t_2 + 460 \\ P_m = P_{bar} + \frac{\Delta H}{13.6} \end{array}$$

Y = meter calibration factor

3. Calculate the average K_m as follows:

$$\bar{K}_m = \frac{\sum K_m}{5}$$

4. Calculate ΔH_a as follows:

$$\Delta H_a = \frac{Q @^2 P @ M @}{T @} \left[\frac{1}{\bar{K}_m^2} \right] = \frac{0.921}{\bar{K}_m^2}$$

Q @ = 0.75 cfm

T @ = 528°R

P @ = 29.92 in.Hg

M @ = 29

5. Orifice Tolerance = 1.84 ± .25

DEVICE READING (DEGREES F)

5 0 5

10

20

30

40

50

60

70


ACTUAL TEMPERATURE (DEGREES F)

TEMPERATURE CALIBRATION FOR TEMPERATURE #1
DATE 9/18/75 INITIALS STB

TEMPERATURE CALIBRATION FOR Omni II 199
DATE 9/2/85 INITIALS AS

DEVICE READING (DEGREES F)

ACTUAL TEMPERATURE (DEGREES F)



DEVICE READING (DEGREES F)

-5

0

+5

100

200

300

400

500

600

700

800

900


ACTUAL TEMPERATURE (DEGREES F)

TEMPERATURE CALIBRATION FOR CHINA 11/19/85
DATE 11/19/85 INITIALS AS

DEVICE READING (DEGREES F)

ACTUAL TEMPERATURE (DEGREES F)

TEMPERATURE CALIBRATION FOR 44502
DATE 5/17/85 INITIALS SSC



PITOT CALIBRATION FORM

Date 9/12/83 Probe # 5'-N

Calibrated By Tom Lutz

Nozzle Size None Used

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	0.60	0.84	0.845	+0.003
2	0.60	0.85	0.840	-0.002
3	0.60	0.85	0.840	-0.002
		$\bar{C}_p(A)$	0.842	

SIDE B

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	0.59	0.835	0.841	+0.001
2	0.59	0.835	0.841	+0.001
3	0.59	0.84	0.838	-0.002
		$\bar{C}_p(B)$	0.840	

CALCULATIONS

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}}$$

(or 0.99)

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3} \leftarrow \text{Must be } \leq 0.01$$

$$|\bar{C}_p(A) - \bar{C}_p(B)| \leftarrow \text{Must be } \leq 0.01$$

PITOT CALIBRATION FORM

Date 2/2/84 Probe # 5'-M172

Calibrated By LOTZ

Nozzle Size None

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	.53	0.655	0.891	
2	.53	0.615	0.891	
3	.53	0.655	0.891	
		$\bar{C}_p(A)$	0.891	

SIDE B

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	.53	0.655	.891	+ .002
2	.52	0.65	.885	- .004
3	.53	0.655	.891	+ .002
		$\bar{C}_p(B)$	.889	

CALCULATIONS

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}}$$

(or 0.99)

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3} \leftarrow \text{Must be } \leq 0.01$$

$$|\bar{C}_p(A) - \bar{C}_p(B)| \leftarrow \text{Must be } \leq 0.01$$

Set #2

Gauge	Average Test Condition Temperature	Gauge Reading	Reference Reading	Difference
Impinger (Pre) #2 2/3/84		60	Room Temp 60	✓
Meter In (Pre) #700 2/3/84		60	Room Temp 60	—
Meter Out (Pre) #700 2/3/84		60	Room Temp 60	—
Filter Heated Area (Pre) NA		242	248 ± 25°F 242	—
Stack (Post) 2/10/84 omega I	141	140	Stack Temp °F 140	—

Post Test

Run 1

Run 2

Run 3

Train Leak Rate

_____ CFM _____ CFM _____ CFM

Pitot Leak Check

Pre Test (Answer Yes or No)

Orsat Leak Check

Metering System Leak Check

Barometer Calibrated

Sample Bag Leak Check (if used)

Signature

[Signature]

Title

Dinit

Date

2/10/84

METER CALIBRATION FORM

Date 9/23/83

Box No. 700

P_{bar} = 30.39 in. Hg

Calibrated by Low Lef

Orifice Manometer Set- ting ΔH (in. H ₂ O)	Δ wtm (in. H ₂ O)	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Avg. Temp. Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Inlet	Outlet
2.5	-1.3	34.173	50.850	233.457	251.397	19.6	19.6	107 115	58 91
2.0	-1.1	50.850	65.042	251.397	266.521	19.5	19.5	111 113	20 92
1.5	-0.84	78.163	89.022	289.410	291.878	19.5	19.5	107 110	90 80
1.0	-0.61	89.022	99.416	291.878	302.132	19.5	19.5	107 107	80 85
0.5	-0.37	99.214	105.903	302.132	309.538	19.5	19.5	102 101	88 87

Pump must be operated for at least 15 minutes at each ΔH setting (.5, 1, 1.5, 2 and 3)

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

P_{wtm} = P_{bar} - $\frac{\Delta wtm}{13.6}$

P_{dgm} = P_{bar} + $\frac{\Delta H}{13.6}$

Δwtm = pressure on wet test meter in inches of H₂O

Y = meter calibration factor

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$Y = \frac{(\text{wet final} - \text{wet initial})(T_{dgm})(P_{wtm})}{(\text{dry final} - \text{dry initial})(28.316)(T_{wtm})(P_{dgm})}$$

or (1)

$$\bar{Y} = \frac{\Sigma Y}{5}$$

Meter Tolerance = 1.00 ± 0.01

If the meter calibration factor is not within the allowable tolerance, the calibration factory Y may be used to mathematically correct the gas meter dial readings to the proper values instead of physically adjusting the dry gas meter dials to correspond to the wet test meter readings.

.9669
.9702
.9769
.9831
.9869
.9768 = .98

ORIFICE CALIBRATION FORM

Date 9/23/82Meter Box No. 700P_{bar} 30.39Calibrated By Jan Lf

Δ H	V ₁	V ₂	θ	t ₁	t ₂	V ₂ - V ₁	Q _m	K _m	
in. H ₂ O	CF	CF	Sec.	°F	°F	CF			
2.5	233.657	251.357	1080	111	89.5	17.740	.9346	.7509	1.63
2.0	251.757	266.521	1025	112	91	15.124	.8429	.7556	1.61
1.5	250.410	251.578	900	108.5	90	11.468	.7345	.7606	1.59
1.0	251.578	302.552	1020	107.0	89.5	10.704	.6093	.7726	1.58
0.5	302.182	308.538	940	101.5	87.5	6.956	.4327	.7765	1.50
Average K _m								.7633	

V₁ = Dry gas meter reading at the start of each testV₂ = Dry gas meter reading at the end of each testt₁ = Dry gas meter inlet temperaturet₂ = Dry gas meter outlet temperatureCalculations

$$1. Q_m = \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{\frac{t_1 + t_2 + 460}{2}} \right] (60)(Y)$$

$$2. K_m = \frac{Q_m}{\sqrt{\frac{P_m M_m}{T_m \Delta H}}}$$

$$\begin{aligned} M_m &= 29 \\ T_m &= t_2 + 460 \\ P_m &= P_{bar} + \frac{\Delta H}{13.6} \end{aligned}$$

Y = meter calibration factor

3. Calculate the average K_m as follows:

$$\bar{K}_m = \frac{\sum K_m}{5}$$

4. Calculate Δ H_a as follows:

$$\Delta H_a = \frac{Q @^2 P @ M @}{T @} \left[\frac{1}{\bar{K}_m^2} \right] = \frac{0.921}{\bar{K}_m^2}$$


$$\begin{aligned} Q @ &= 0.75 \text{ cfm} \\ T @ &= 528^{\circ} \text{R} \\ P @ &= 29.92 \text{ in.Hg} \\ M @ &= 29 \end{aligned}$$

5. Orifice Tolerance = 1.84 ± .25

DEVICE READING (DEGREES F)

TEMPERATURE CALIBRATION FOR Probe # 2
DATE 7/12/83 INITIALS STB

ACTUAL TEMPERATURE (DEGREES F)



DEVICE READING (DEGREES F)

TEMPERATURE CALIBRATION FOR 7001484-1
DATE 7/12/01 INITIALS ECZ

ACTUAL TEMPERATURE (DEGREES F)

30 40 50 60 70 80 90 100 110

DEVICE READING (DEGREES F)

TEMPERATURE CALIBRATION FOR CHICO
DATE 7/1/75 INITIALS SS

ACTUAL TEMPERATURE (DEGREES F)

100 300 500 700 900 1100 1300 1500 1700 1900

PITOT CALIBRATION FORM

Date 2/2/84 Probe # 5-M171

Calibrated By 6072

Nozzle Size _____

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	0.53	0.74	0.838	
2	0.53	0.74	0.838	
3	0.53	0.74	0.838	
		$\bar{C}_p(A)$	0.838	

SIDE B

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	0.53	.74	.838	
2	0.53	.74	.838	
3	0.53	.74	.838	
		$\bar{C}_p(B)$	.838	

CALCULATIONS

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}}$$

(or 0.99)

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3} \leftarrow \text{Must be } \leq 0.01$$

$$|\bar{C}_p(A) - \bar{C}_p(B)| \leftarrow \text{Must be } \leq 0.01$$