

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.3
Background Chapter	4
Reference:	19
Title:	<i>Stationary Source Sampling Report: Lee Brick And Tile Company, Sanford, NC, Compliance Testing, Tunnel Kiln, Entropy Environmentalists, Inc., Research Triangle Park, NC, February 1978.</i>

BRICKS AND RELATED
CLAY PRODUCTS
AP-42 Section 8.3
Reference Number

14

CH 4 Ref 19

RECEIVED

MAR 13 1978

AIR QUALITY DIVISION
CENTRAL OFFICE

ENTROPY
ENVIRONMENTALISTS, INC.

SPECIALISTS IN
SOURCE
SAMPLING

STATIONARY SOURCE SAMPLING REPORT

LEE BRICK AND TILE COMPANY
SANFORD, NORTH CAROLINA
COMPLIANCE TESTING
TUNNEL KILN

FEBRUARY 1978

PERFORMED FOR
PULLMAN-SWINDELL, INC.

This Report was prepared

by: V. Cope

Date: 4/3/78

and found to be

Satisfactory

Unsatisfactory


Failed

P.O. Box 12291, Research Triangle Park, North Carolina 27709
Phone 919-781-3550

REPORT CERTIFICATION

The sampling and analysis performed for this report was carried out under my direction and supervision.


Date February 17, 1978 Signature



Roy N. Doster

I have reviewed all testing details and results in this test report and hereby certify that the test report is authentic and accurate.

Date February 17, 1978 Signature



D. James Grove, P.E.

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
INTRODUCTION	1
SUMMARY OF RESULTS	2
PROCESS DESCRIPTION AND OPERATION	7
SAMPLING AND ANALYTICAL PROCEDURES	10
APPENDICES	12
A - Particulate Results and Calculations	
B - Particle Sizing Results and Calculations	
C - Field, Analytical, and Process Data	
D - Test Participants	
E - Sampling and Analytical Procedures	
F - Calibration Data	

INTRODUCTION

Stationary source sampling was performed at Lee Brick and Tile Company, Sanford, North Carolina to determine the particulate emissions from a coal-fired tunnel kiln. Three sets of simultaneous particulate tests were made on each of the two kiln stacks on February 9, 1978. In addition, a particulate sizing test was performed on each stack.

Observing the testing were Paul Sieffert and Scott Frame of Pullman-Swindell, Inc., and Sammy Amerson of the North Carolina Department of Natural Resources and Community Development.

The measurements made for stack gas flow rate and particulate emissions were made according to North Carolina Department of Natural Resources and Community Development recommendations.

The following sections of this report treat the summary of results, a brief description of the process and its operation, and the sampling and analytical procedures used.

SUMMARY OF RESULTS

Presented in Table 1 below are the emission rates as determined by the six particulate emission tests performed on the tunnel kiln outlets. The values shown are reasonably consistent and reflect the non-changing nature of the process.

Table 1
Particulate Emissions

<u>Test Set No.</u>	-----Pounds Per Hour-----		
	<u>South</u>	<u>North</u>	<u>Total</u>
1	24.0	2.01	26.0
2	22.5	1.89	24.4
3*	19.4	1.71	21.1
Avg.	22.0	1.87	23.8

*During the third set of tests, the kiln doors were not opened.

According to North Carolina Regulation 2D.0515, the maximum allowable emission rate is 17.7 pounds per hour. This is based on a process weight rate of 8.90 tons per hour and includes an estimate of the coal being combusted.

Table 2 and 3 on the following pages give the individual test summaries for the tests performed at stack #1 (south) and stack #2 (north), respectively. Table 4 presents the results from the two particle sizing tests performed. In

TABLE 2

SUMMARY OF RESULTS, PARTICULATE EMISSIONS

KILN STACK #1, SOUTH

RUN NUMBER	1	2	3
DATE	2/ 9/78	2/ 9/78	2/ 9/78
STACK TEMPERATURE, DEG. F	306.	303.	308.
PERCENT EXCESS AIR	565.	565.	565.
PERCENT ISOKINETIC	96.8	96.1	99.5
STACK FLOW RATE SCFM* DRY	20905.	21714.	21012.
STACK FLOW RATE ACFM, WET	31560.	32827.	31912.
VOLUME OF GAS SAMPLED SCF* DRY	60.89	70.21	63.42
PARTICULATES, EPA METHOD 5:			
CATCH - MGRAMS	528.7	550.0	443.2
CONCENTRATION - GR/DSCF*	0.1337	0.1206	0.1076
EMISSION RATE - LBS/HR	23.96	22.45	19.38

* 68 DEG F, 29.92 IN. HG

TABLE 3

SUMMARY OF RESULTS, PARTICULATE EMISSIONS

KILN STACK #2, NORTH

RUN NUMBER	4	5	6
DATE	2/ 9/78	2/ 9/78	2/ 9/78
STACK TEMPERATURE, DEG. F	336.	336.	335.
PERCENT EXCESS AIR	565.	565.	565.
PERCENT ISOKINETIC	98.7	97.6	95.4
STACK FLOW RATE SCFM* DRY	1522.	1422.	1461.
STACK FLOW RATE ACFM,WET	2376.	2226.	2281.
VOLUME OF GAS SAMPLED SCF* DRY	19.05	17.83	17.90
PARTICULATES, EPA METHOD 5:			
CATCH - MGRAMS	190.6	179.9	158.9
CONCENTRATION - GR/DSCF*	0.1541	0.1554	0.1367
EMISSION RATE - LBS/HR	2.01	1.89	1.71

* 68 DEG F, 29.92 IN. HG

Table 4

Particle Size Summary

----Stack #1 (South)-----

----Stack #2 (North)-----

<u>Aerodynamic Diameter (microns)</u>	<u>Cumulative % Less Than Stated Size</u>
---	---

<u>Aerodynamic Diameter (microns)</u>	<u>Cumulative % Less Than Stated Size</u>
---	---

10.7	93.0
------	------

15.7	97.6
------	------

6.72	80.6
------	------

9.79	96.1
------	------

4.48	63.2
------	------

6.55	88.6
------	------

3.11	43.5
------	------

4.55	80.6
------	------

1.96	29.2
------	------

2.85	71.6
------	------

1.01	10.1
------	------

1.48	56.7
------	------

0.61	2.5
------	-----

0.91	48.2
------	------

0.41	1.7
------	-----

0.63	36.3
------	------

Median Size: approx. 3.3 microns

Median Size: approx. 1.3 microns

addition to the Andersen tests, the first set of simultaneous tests used cyclones ahead of the filter. No large particles were caught, although some small particles did adhere to the cyclone's surface due to static electricity.

PROCESS DESCRIPTION

Lee Brick and Tile Company in Sanford, North Carolina manufactures bricks, which involves the screening and blending of the raw materials, and the drying and firing of the final, shaped, product.

The firing of the bricks takes place in a tunnel kiln, with the bricks traveling on cars on rails through the kiln. After a set time, a car leaves the kiln at the same time a car is entering the kiln at the other end. At this time, doors at the end of the kiln are opened, allowing ambient air to enter uncontrolled.

Firing takes place in six steps: evaporation of free water, dehydration, oxidation, vitrification, flashing, and cooling. The actual fire zone is located near the middle of the kiln, with the 2000°F temperature provided by the combustion of coal. As shown in Figure 1, ambient air is used to cool the bricks and conversely preheat the air for the firing zone. Also some of the preheated air is ducted to the brick dryer for drying the bricks. The kiln is exhausted by two fans at opposite ends of the kiln.

Potential emissions from the kiln consists mainly of particulate matter in the form of dust generated by the handling of the bricks, and of combustion products from the coal. No emission control equipment is presently in use.




FIGURE 1. PROCESS SCHEMATIC AND SAMPLING LOCATIONS

During the testing performed at the outlet of the two kiln exhaust fans, the kiln was firing a carload of 8064 type #320 bricks every 100 minutes. With an average brick weight of 3.43 pounds, this converts to a process rate of 8.3 tons of bricks per hour. When the estimated coal usage rate of 0.60 tons per hour is added, the total process weight rate is 8.90 tons per hour.

It is suspected that the opening of the kiln doors increases the emissions; therefore, the last of the three sets of tests performed was made without a door opening occurring. As shown in Table 1 in the Summary of Results, the particulate tests did show a decrease in the emissions.


SAMPLING AND ANALYTICAL PROCEDURES

All sampling and analytical procedures used were those recommended by the U. S. Environmental Protection Agency and the North Carolina Department of Natural Resources and Community Development. Complete details of the equipment and procedures used are described in Appendix E, which is extracted from the Federal Register, August 18, 1977. Also included in Appendix E is a writeup of the Andersen particle sizing equipment and how to use it.


Method 1 was used to determine the number and location of the sampling points. The two kiln exhaust stacks are identical, with each stack cross section divided into 44 equal areas. Two ports labeled A and B, as shown in Figure 2, access the traverse axes, with each axis having 22 points. Every point was sampled for one and a half minutes, giving a total testing time of 66 minutes for each run on a stack.

Velocity measurements were in accordance with Method 2. Molecular weights for the stack gases were determined by Method 3 procedures. Particulate emissions were found using Method 5 analytical and sampling procedures. The particle sizing tests were made using Andersen Mark III Stack Samplers.

All sampling equipment used was manufactured by Nutech Corporation, Entropy Environmentalists, Inc., or Andersen 2000, Inc.



A



FROM FAN
AND KILN

FIGURE 2. STACK DIMENSIONS AND SAMPLING POINT LOCATIONS,
KILN EXHAUST STACKS (1 AND 2)

APPENDICES

RESULTS PREPARED BY
**ENTROPY ENVIRONMENTALISTS, INC. **

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: LEE BRICK & TILE COMPANY, SANFORD, N.C.

TEST TEAM LEADER: WILLIS NESBIT

TEST 1 KILN STACK #1, SOUTH

TEST 2 KILN STACK #1, SOUTH

TEST . 3 KILN STACK #1, SOUTH

RUN NUMBER		1	2	3
-----		-	-	-
TEST DATE		2/ 9/78	2/ 9/78	2/ 9/78

TB	TIME-START	1022	1215	1411
TF	TIME-FINISH	1137	1325	1623
TT	NET TIME OF TEST, MIN.	66.0	66.0	66.0
FNP	NET SAMPLING POINTS	44.	44.	44.
DN	SAMPLING NOZZLE DIA., IN.	0.243	0.257	0.244
CP	PITOT TUBE COEFFICIENT	0.84	0.84	0.84
PM	AVERAGE ORIFICE PRESSURE DROP, IN. H2O	2.85	3.88	2.88
VM	VOLUME OF DRY GAS SAMPLED CU. FT. AT METER CONDITIONS	61.509	71.815	65.390
TM	AVERAGE GAS METER TEMP DEGREES F	69.	77.	80.
VMSTD	VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS*, SCF	60.889	70.211	63.417
VW	TOTAL H2O COLLECTED IN IMPINGERS & SILICA GEL, ML.	32.0	45.0	38.0
VWV	VOLUME OF WATER VAPOR AT STANDARD CONDITIONS*, SCF	1.51	2.12	1.79
PMV	PERCENT MOISTURE BY VOL.	2.4	2.9	2.3
MD	MOLE FRACTION DRY GAS	0.976	0.971	0.972
PCO2	PERCENT CO2 BY VOL., DRY	2.3	2.3	2.3
PO2	PERCENT O2 BY VOL., DRY	17.9	17.9	17.9
PCO	PERCENT CO BY VOL., DRY	0.0	0.0	0.0
PN2	PERCENT N2 BY VOL., DRY	79.8	79.8	79.8

MWD	MOLECULAR WT-DRY STACK GAS	29.08	29.08	29.08
MW	MOLECULAR WT-STACK GAS	28.82	28.76	28.78
PB	BAROMETRIC PRESSURE, IN. HG.	29.46	29.46	29.46
PSI	STATIC PRES OF STACK GAS IN. H2O	0.0	0.0	0.0
PS	STACK PRES, ABS., IN. HG.	29.46	29.46	29.46
TS	AVERAGE STACK TEMP. DEG. F	306.	303.	308.
DPS	AVERAGE VELOCITY HEAD OF STACK GAS, IN. H2O	1.190	1.290	1.212
VS	AVE STACK GAS VELOCITY, FPS	74.4	77.4	75.2
AS	STACK AREA, SQUARE INCHES	1018.	1018.	1018.
QS	STACK FLOW RATE, DRY, SCFM*	20905.	21714.	21012.
QA	ACTUAL STACK FLOW RATE, ACFM	31560.	32827.	31912.
PERI	PERCENT ISOKINETIC	96.8	96.1	99.5
FMF	PARTICULATE, MG, EPA 5	528.7	550.0	443.2
CAN	PARTICULATE, GR/DSCF* EPA 5	0.1337	0.1206	0.1076
CAW	PARTICULATE, LBS/HR EPA 5	23.96	22.45	19.38
PEA	PERCENT EXCESS AIR	565.	565.	565.

* 68 DEG F, 29.92 IN. HG

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: LEE BRICK & TILE COMPANY, SANFORD, N.C.

TEST TEAM LEADER: ROY N. DOSTER

TEST 4 KILN STACK #2, NORTH

TEST 5 KILN STACK #2, NORTH

TEST - 6 KILN STACK #2, NORTH

RUN NUMBER		4	5	6
-----		-	-	-
TEST DATE		2/ 9/78	2/ 9/78	2/ 9/78

TB	TIME-START	1025	1218	1411
TF	TIME-FINISH	1135	1327	1623
TT	NET TIME OF TEST, MIN.	66.0	66.0	66.0
FNP	NET SAMPLING POINTS	44.	44.	44.
DN	SAMPLING NOZZLE DIA., IN.	0.499	0.502	0.502
CP	PITOT TUBE COEFFICIENT	0.84	0.84	0.84
PM	AVERAGE ORIFICE PRESSURE	0.27	0.23	0.25
	DROP, IN. H2O			
VM	VOLUME OF DRY GAS SAMPLED CU. FT. AT METER CONDITIONS	18.745	17.853	18.128
TM	AVERAGE GAS METER TEMP DEGREES F	52.	61.	67.
VMSTD	VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS*, SCF	19.050	17.828	17.897
VW	TOTAL H2O COLLECTED IN IMPINGERS & SILICA GEL, ML.	8.0	8.5	8.0
VWV	VOLUME OF WATER VAPOR AT STANDARD CONDITIONS*, SCF	0.378	0.401	0.378
PMV	PERCENT MOISTURE BY VOL.	1.9	2.2	2.1
MD	MOLE FRACTION DRY GAS	0.981	0.978	0.979
PCO2	PERCENT CO2 BY VOL., DRY	2.3	2.3	2.3
PO2	PERCENT O2 BY VOL., DRY	17.9	17.9	17.9
PCO	PERCENT CO BY VOL., DRY	0.0	0.0	0.0
PN2	PERCENT N2 BY VOL., DRY	79.8	79.8	79.8

MWD	MOLECULAR WT-DRY STACK GAS	29.08	29.08	29.08
MW	MOLECULAR WT-STACK GAS	28.87	28.84	28.85
PB	BAROMETRIC PRESSURE, IN. HG.	29.46	29.46	29.46
PSI	STATIC PRES OF STACK GAS IN. H2O	0.0	0.0	0.0
PS	STACK PRES, ABS., IN. HG.	29.46	29.46	29.46
TS	AVERAGE STACK TEMP. DEG. F	336.	336.	335.
DPS	AVERAGE VELOCITY HEAD OF STACK GAS, IN. H2O	0.006	0.006	0.006
VS	AVE STACK GAS VELOCITY, FPS	5.60	5.25	5.38
AS	STACK AREA, SQUARE INCHES	1018.	1018.	1018.
QS	STACK FLOW RATE, DRY, SCFM*	1522.	1422.	1461.
QA	ACTUAL STACK FLOW RATE, ACFM	2376.	2226.	2281.
PERI	PERCENT ISOKINETIC	98.7	97.6	95.4
FMF	PARTICULATE, MG, EPA 5	190.6	179.9	158.9
CAN	PARTICULATE, GR/DSCF* EPA 5	0.1541	0.1554	0.1367
CAW	PARTICULATE, LBS/HR EPA 5	2.01	1.89	1.71
PEA	PERCENT EXCESS AIR	565.	565.	565.

* 68 DEG F, 29.92 IN. HG

EXAMPLE PARTICULATE CALCULATIONS TEST NO. 4

KILN STACK #2, NORTH

VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS

$$VMSTD = (17.65 * VM * (PB + PM / 13.6)) / (TM + 460)$$

$$VMSTD = \frac{17.65 * 18.745 * (29.46 + 0.270 / 13.6)}{512.0} = 19.050 \text{ DSCF}$$

VOLUME OF WATER VAPOR AT STANDARD CONDITIONS

$$VWV = .0472 * VW$$

$$VWV = .0472 * 8.0 = 0.378 \text{ SCF}$$

PERCENT MOISTURE IN STACK GAS

$$PMV = (100 * VWV) / (VMSTD + VWV)$$

$$PMV = \frac{100 * 0.38}{19.050 + 0.38} = 1.9 \text{ PERCENT}$$

MOLE FRACTION OF DRY STACK GAS

$$MD = (100. - PMV) / 100.$$

$$MD = \frac{100. - 1.9}{100.} = 0.981$$

AVERAGE MOLECULAR WEIGHT OF DRY STACK GAS

$$MWD = (PCO_2 * .44) + (PO_2 * .32) + (PN_2 + PCO) * .28$$

$$MWD = (2.3 * 0.44) + (17.9 * 0.32) + ((79.8 + 0.0) * 0.28) = 29.08 \text{ LB/LB MOLE}$$

MOLECULAR WEIGHT OF STACK GAS

$$MW = MWD * MD + 18 * (1 - MD)$$

$$MW = 29.08 * 0.981 + 18 * (1 - 0.981) = 28.87 \text{ LB/LB MOLE}$$

STACK GAS VELOCITY AT STACK CONDITIONS

$$VS = 85.48 * CP * \sqrt{(DPS * (TS + 460)) / (PS * MW)}$$

$$VS = 85.48 * .84 * \sqrt{(0.006 * 796.) / (29.46 * 28.87)} = 5.6 \text{ FPS}$$

STACK GAS VOLUMETRIC FLOW AT STACK CONDITIONS

$$QA = VS * AS * 60 / 144$$

$$QA = 5.6 * 1018. * 60 / 144 = 2376. \text{ ACFM}$$

STACK GAS VOLUMETRIC FLOW AT STANDARD CONDITIONS

$$QS = (17.65 * QA * PS * MD) / (TS + 460)$$

$$QS = \frac{17.65 * 2376. * 29.46 * 0.981}{796.0} = 1522. \text{ SCFM}$$

PERCENT ISOKINETIC

$$PERI = (17.3 * (TS + 460) * VMSTD) / (VS * TT * PS * MD * DN * DN)$$

$$PERI = \frac{17.3 * 796.0 * 19.05}{5.6 * 66.0 * 29.46 * 0.981 * 0.499 * 0.499} = 98.7 \text{ PERCENT}$$

PARTICULATE LOADING -- EPA METHOD 5
(AT STANDARD CONDITIONS)

$$CAN = 0.0154 * FMF / VMSTD$$

$$CAN = 0.0154 * (190.6 / 19.05) = 0.1541 \text{ GR/DSCF}$$

PARTICULATE LBS/HR--EPA METHOD 5

$$CAW = 0.00857 * CAN * QS$$


$$CAW = 0.00857 * 0.154 * 1522. = 2.01 \text{ LBS/HR}$$

PERCENT EXCESS AIR

$$PEA = \frac{(PO_2 - 0.5 * PCO)}{0.264 * PN_2 - PO_2 + 0.5 * PCO} * 100$$

$$PEA = \frac{17.9 - (0.5 * 0.0)}{(0.264 * 79.8) - (17.9 + 0.5 * 0.0)} * 100 = 565.2 \text{ PERCENT}$$

APPENDIX B



CALCULATIONS - ANDERSEN SAMPLING HEAD

PLANT NAME Low Brick #1

SAMPLING LOCATION Stack #1 (South)

TEST DATE 2-9-77

STACK TEMPERATURE 300 °F

METER TEMPERATURE 72 °F

BAROMETRIC PRESS. 29.46 in. Hg

METER VOLUME 6.60 ACF

STACK STATIC PRESS. 0 in. H₂O

WATER COLLECTED 2.5 mls

AVERAGE ΔH 1.20 in. H₂O

$$\text{METER VOLUME @ STP} = \frac{17.65 \times 6.60 \times (29.46 + \frac{1.20}{13.6})}{(460 + 72)} = \underline{5.470} \text{ SCF}$$

$$\text{WATER VOLUME(VAPOR) @ STP: } 0.0472 \times 2.5 = \underline{0.118} \text{ SCF}$$

$$\text{TOTAL SAMPLE VOLUME @ STP: } \underline{5.47} + \underline{0.118} = \underline{5.588} \text{ SCF}$$

$$\text{TOTAL SAMPLE VOLUME(ACF): } \frac{5.588 \times (460 + 300)}{17.65 (29.46 + \frac{1.20}{13.6})} = \underline{1.257} \text{ ACF}$$

$$\text{SAMPLING RATE: } \underline{9.627} \text{ ACF / 12 min.} = \underline{0.802} \text{ ACFM}$$

$$\text{VISCOSITY CORRECTION FACTOR @ } \underline{\quad} \text{ °F} = \underline{\quad}$$

$$\text{SPECIFIC GRAVITY CORRECTION FACTOR @ } \underline{\quad} \text{ g/cm}^3 = \underline{\quad}$$

$$\text{COMBINED CORRECTION FACTOR } \underline{\quad}$$

STAGE	AERODYNAMIC DIAMETER, μ	PHYSICAL DIAMETER, μ	CATCH mgs	%	CUMULATIVE %
1	12.7	-	2.5	7.0	7.0
2	6.72	-	4.1	12.4	19.4
3	4.73	-	6.2	17.4	36.8
4	3.11	-	7.0	19.7	56.5
5	1.96	-	5.1	14.3	70.8
6	1.01	-	6.3	19.1	89.9
7	0.61	-	2.7	7.6	97.5
8	0.41	-	0.3	0.8	98.3
BACKUP FILTER	-	-	2.0	1.7	100.0
TOTAL CATCH			35.0	-	-

A-2
CALCULATIONS - ANDERSEN SAMPLING HEAD

PLANT NAME Lee Brick & Tile SAMPLING LOCATION 151/2 Sec = 2 (North)
 TEST DATE 2-4-78 STACK TEMPERATURE 331 °F
 METER TEMPERATURE 70 °F BAROMETRIC PRESS. -9.70 in. Hg
 METER VOLUME 4.011 ACF STACK STATIC PRESS. 0 in. H₂O
 WATER COLLECTED 2 mls AVERAGE ΔH 5.17 in. H₂O

$$\text{METER VOLUME @ STP} = \frac{17.65 \times 4.011 \times (29.4\% + \frac{0.19}{13.6})}{(460 + 70)} = 3.777 \text{ SCF}$$

$$\text{WATER VOLUME(VAPOR) @ STP: } 0.0472 \times 2 = 0.0944 \text{ SCF}$$

$$\text{TOTAL SAMPLE VOLUME @ STP: } 3.777 + 0.094 = 4.031 \text{ SCF}$$

$$\text{TOTAL SAMPLE VOLUME(ACF): } \frac{4.031 \times (460 + 331)}{17.65 (29.4\% + \frac{0}{13.6})} = 6.132 \text{ ACF}$$

$$\text{SAMPLING RATE: } 0.132 \text{ ACF / } 16 \text{ min.} = 0.0083 \text{ ACFM}$$

$$\text{VISCOSITY CORRECTION FACTOR @ } \text{°F} =$$

$$\text{SPECIFIC GRAVITY CORRECTION FACTOR @ } \text{g/cm}^3 =$$


$$\text{COMBINED CORRECTION FACTOR}$$

STAGE	AERODYNAMIC DIAMETER, μ	PHYSICAL DIAMETER, μ	CATCH mgs	%	CUMULATIVE %
0	15.7	-	0.5	2.5	100
1	9.79	-	0.3	1.5	97.6
2	6.55	-	1.5	7.5	96.1
3	4.55	-	1.6	10	86.6
4	2.85	-	1.8	9.0	80.6
5	1.48	-	3.0	14.9	71.0
6	0.91	-	1.7	8.5	50.7
7	0.63	-	2.4	11.1	48.2
BACKUP FILTER	-	-	7.3	36.3	36.3
TOTAL CATCH			20.1	-	-

APPENDIX C

PRELIMINARY FIELD DATA

Stack Geometry



Plant Name LEE BRICK & TILE

Plant Location SANFORD

Sampling Location KILN STACKS 1 & 2

Date(s) 2-9-78

A. Dist. from inside of far wall to outside of near wall: 38 3/4 inches


B. Wall thickness: 2 3/4 inches

Inside diameter of stack (A-B): 36 inches

Stack Area: 1018 square inches

Sketch of stack cross section showing sampling ports.

Comments: #1 Stack is South Stack
#2 is North Stack



Sketch of stack dimensions and location of sampling ports.

Point	% of Diameter	Distance from inside wall	Distance from outside of port
1	1.1	3/8"	3 1/8
2	3.5	1 1/4"	4
3	6.0	2 1/8"	4 7/8
4	8.7	3 1/8"	5 7/8
5	11.6	4 1/8"	6 7/8
6	14.6	5 1/4"	8
7	18.0	6 1/2"	9 1/4
8	21.8	7 7/8"	10 5/8
9	26.2	9 1/2"	12 1/4
10	31.5	11 3/8"	14 1/8
11	39.3	14 1/8"	16 7/8
12	60.7	21 7/8"	24 5/8

2 3/4"



SPECIALISTS IN
SOURCE
SAMPLING

2 3/4"

Point	% of Diameter	Distance from inside wall	Distance from outside of port
13	68.5	24 $\frac{5}{8}$ "	27 $\frac{3}{8}$
14	73.8	26 $\frac{1}{2}$ "	29 $\frac{1}{4}$
15	78.2	28 $\frac{1}{8}$ "	30 $\frac{7}{8}$
16	82.0	29 $\frac{1}{2}$ "	32 $\frac{1}{4}$
17	85.4	30 $\frac{3}{4}$ "	33 $\frac{1}{2}$
18	88.4	31 $\frac{7}{8}$ "	34 $\frac{5}{8}$
19	91.3	32 $\frac{7}{8}$ "	35 $\frac{5}{8}$
20	94.0	33 $\frac{7}{8}$ "	36 $\frac{5}{8}$
21	96.5	34 $\frac{3}{4}$ "	37 $\frac{1}{2}$
22	98.9	35 $\frac{5}{8}$	38 $\frac{3}{8}$
			

ORSAT FIELD DATA

Plant Name Lee Brick

Date 2-9-78

Sampling Location Stack #1 (South Stack)

Operator RD

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
1415 & 1620	1800	2.3	20.2	20.2	17.9	0	79.8

PROCESS DESCRIPTION


FUEL TYPE				BOILER TYPE			
Wood	bark chips	shavings	sawdust	Feeding Location	overfeed	underfeed	
Oil	#1	#3	#5	Mechanism	manual	screw	chain
	#2	#4	#6		steam	vibrator	air
					flipper	gravity	ram
Coal	coke	bituminous		Grating type	solid	stationary	
	anthracite				traveling	vibrating	
	pulverized?			Control Equipment?	<u>None</u>		
Nat. Gas	Other			Combustion Air Configuration	overfire jets		

PROCESS OPERATION

RATE TYPE	Rated	Normal	Actual
Feed Rate (lbs/hr, gals/hr, cu. ft./hr)			1600
Steam Rate (lbs/hr)		100-1500	
KW produced (power boilers only)			
MBTU/hr produced			
H.P. produced			

PARTICULATE FIELD DATA

Company Lee Brinkley
 Plant Location Sanford, NC
 Run No. 1
 Sampling Location Stack 1 (Sand)
 Date 2/9/78
 Operator WV
 Sample Box No. 6
 Meter Box No. N-3
 Meter Δ Hg 1.74
 C Factor 92



Start: 10:22
 Finish: 11:37
 Filter # 2809
 Tare Weight: .3932

REMARKS:

PRE LEAK: 0.00 @ 15"
 POST LEAK: 0.00 @ 7"

Ambient Temp., °F 35
 Bar. Press., in. Hg 29.46
 Assumed Moisture, % 57
 Heater Box Setting, °F 41
 Probe Heater Setting 16
 Probe Tip Dia., in. .243 (304)
 Actual Probe Length, Ft. 4.1
 Static Pressure, in. H₂O 0
 Average Δ p 0.75
 Average Δ H 1.85

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (dp) in. H ₂ O	Orifice Manometer (dp) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A 1	0	976.090	0.95	2.25	2.25	62	4	220	50	310
2	1 1/2	977.690	1.00	2.40	2.40	62	4	220	50	310
3	3	978.470	1.15	2.75	2.75	62	5	220	50	310
4	4 1/2	979.970	1.20	2.90	2.90	62	5	220	50	310
5	6	981.200	1.20	2.90	2.90	62	5	220	50	310
6	7 1/2	982.580	1.25	3.00	3.00	63	6	220	50	310
7	9	983.980	1.25	3.00	3.00	63	6	220	50	310
8	10 1/2	985.510	1.25	3.00	3.00	64	6	220	50	310
9	12	987.300	1.20	2.90	2.90	65	6	220	50	310
10	13 1/2	988.520	1.20	2.90	2.90	66	6	220	50	310
11	15	989.680	1.15	2.75	2.75	67	6	220	50	310
12	1 1/2	991.085	1.10	2.60	2.60	67	6	220	50	310
13	3	992.450	1.15	2.75	2.75	68	6	220	50	310
14	4 1/2	993.830	1.50	3.50	3.50	68	7	220	50	310
15	6	995.275	1.50	3.50	3.50	69	7	220	50	240
16	7 1/2	996.845	1.30	3.10	3.10	69	6 1/2	220	50	250
17	9	998.350	1.30	3.10	3.10	70	6 1/2	220	50	270
18	10 1/2	999.850	1.30	3.10	3.10	70	6 1/2	220	50	280
19	12	1001.380	1.20	3.10	3.10	70	7	220	50	295

Company Lee Brick

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Ap) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
20	13½	1002.795	1.30	3.10	3.10	70	7	220	50	350
21	15	1004.250	1.30	3.10	3.10	70	7	220	50	300
22	1½	1005.745	1.20	2.90	2.90	71	6	220	50	305
A 1	3	1007.150	1.20	2.90	2.90	71	6	220	50	365
2	4½	1008.685	0.95	2.25	2.25	67	5	220	50	310
3	6	1009.875	0.95	2.25	2.25	68	5	220	50	310
4	7½	1011.140	1.10	2.60	2.60	70	5	220	52	310
5	9	1012.460	1.20	2.90	2.90	70	6	220	52	310
6	10½	1013.920	1.20	2.90	2.90	70	6	220	53	310
7	12	1015.255	1.15	2.75	2.75	70	6	220	53	310
8	13½	1016.675	1.10	2.60	2.60	70	6	220	54	315
9	15	1018.150	1.10	2.60	2.60	70	6	220	55	318
10	1½	1019.410	1.05	2.55	2.55	70	6	220	56	320
11	3	1020.745	1.05	2.55	2.55	70	6	220	56	320
12	4½	1022.080	1.10	2.60	2.60	70	6	220	57	320
13	6	1023.450	1.15	2.75	2.75	71	6	220	57	320
14	7½	1024.820	1.15	2.75	2.75	71	6	220	57	320
15	9	1026.185	1.20	2.90	2.90	72	6	220	58	320
16	10½	1027.600	1.25	3.00	3.00	72	6	220	58	325
17	12	1029.095	1.30	3.10	3.10	73	7	220	58	325
18	13½	1030.520	1.25	3.00	3.00	73	7	220	58	325
19	15	1032.050	1.25	3.00	3.00	73	7	220	58	320
20	1½	1033.535	1.20	2.90	2.90	74	7	220	57	320
21	3	1034.935	1.25	3.00	3.00	74	7	220	57	320
22	4½	1036.350	1.15	2.75	2.75	74	7	220	57	305
		1037.599								
Diff.		61.509								
Ave.			1.19	2.85	69					306
			(1.09)							

PARTICULATE FIELD DATA

Company Lee Bricks Ambient Temp., °F 40
 Plant Location Sanford, NC Bar. Press., in. Hg 29.46
 Run No. 2 Assumed Moisture, % 5.90
 Sampling Location Stack 1 (South) Heater Box Setting, °F 41
 Date 2-19-78 Probe Heater Setting 41
 Operator WNN Probe Tip Dia., in. 2.57 (306)
 Sample Box No. 6 Actual Probe Length, Ft. 4'-2
 Meter Box No. N-3 Static Pressure, in. H₂O 0
 Water Mite 1.74 Average ΔP 0.64
 C Factor 92 Average ΔH 1.85

REMARKS:
 Pre H₂O test, 0.15 @ 15"
 Post " " 0.01 @ 8"

Start: 12:15
 Finish: 13:25
 Filter # 2806
 Tare Weight: .3915

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (ΔP) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A 1	0	1038.340	1.00	3.50	3.10	66	4	220	50	310
2	1 1/2	1039.095	1.00	3.50	3.00	66	4	220	50	310
3	3	1041.395	1.20	3.60	3.60	66	5	220	50	310
4	4 1/2	1042.950	1.10	3.30	3.30	68	5	220	50	310
5	6	1044.450	1.25	3.75	3.75	68	5	220	50	310
6	7 1/2	1045.995	1.25	3.75	3.75	67	5 1/2	220	50	310
7	9	1047.580	1.25	3.75	3.75	70	6	220	50	310
8	10 1/2	49.200	1.50	4.50	4.50	71	7	220	50	310
9	12	51.010	1.50	4.50	4.50	72	7	220	50	310
10	13 1/2	52.650	1.50	4.50	4.50	73	7	220	50	235
11	15	54.385	1.20	3.60	3.60	74	6	220	50	250
12	1 1/2	55.975	1.20	3.60	3.60	75	6	220	50	275
13	3	57.550	1.25	3.75	3.75	76	6	220	50	285
14	4 1/2	59.150	1.25	3.75	3.75	77	6	220	50	295
15	6	60.765	1.25	3.75	3.75	78	6	220	50	300
16	7 1/2	62.350	1.25	3.75	3.75	78	6	220	50	305
17	9	63.950	1.25	3.75	3.75	78	6	220	50	310
18	10 1/2	65.560	1.30	3.85	3.85	78	6	220	50	310
19	12	67.885	1.30	3.85	3.85	78	6	220	50	310

Company *Lee Brick*

Run # *2*

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) In. H ₂ O	Orifice Manometer (ΔH) In. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
20	13½	69.685	1.30	3.85	3.85	78	8	220	58	310
21	15	71.095	1.25	3.75	3.75	78	8	220	58	310
22	1½	72.590	1.30	3.85	3.85	78	8	220	58	310
23	3-0	74.335	1.15	3.50	3.50	77	8	220	58	310
2	4½	75.870	1.40	4.15	4.15	77	8	220	59	310
3	6	77.240	1.45	4.35	4.35	78	8	220	60	315
4	7½	78.795	1.35	4.12	4.10	78	7	220	61	315
5	9	80.500	1.35	4.10	4.10	79	7	220	61	315
6	10½	82.055	1.40	4.15	4.15	79	7	220	62	320
7	12	83.770	1.40	4.15	4.15	79	7	220	63	320
8	13½	85.355	1.40	4.15	4.15	79	7	220	64	325
9	15	87.035	1.40	4.15	4.15	80	7	220	65	320
10	1½	88.740	1.35	4.10	4.10	81	7	220	65	325
11	3	90.415	1.30	3.85	3.85	81	7	220	65	300
12	4½	92.075	1.25	3.75	3.75	81	7	220	65	320
13	6	93.715	1.30	3.85	3.85	81	7	220	65	320
14	7½	95.335	1.30	3.85	3.85	81	7	220	65	320
15	9	97.001	1.30	3.85	3.85	81	7	220	65	300
16	10½	98.595	1.30	3.85	3.85	81	7	220	65	320
17	12	100.015	1.30	3.85	3.85	81	7	220	65	300
18	13½	101.755	1.35	4.10	4.10	82	7	220	65	300
19	15	103.520	1.35	4.10	4.10	82	7	220	65	300
20	1½	105.195	1.35	4.10	4.10	82	7	220	65	300
21	3	106.875	1.30	3.85	3.85	82	7	220	65	320
22	4½	108.150	1.30	3.85	3.85	82	7	220	65	320
	6	110.155								
DIFF.		71.815								
Ave.			1.29 (1.14)	3.88		77				303

CO₂ "170"
 "05"
 "170"
 "120"
 "05"
 "120"
 "05"
 "120"
 "05"
 "120"

PARTICULATE FIELD DATA

Company/Location Lee Brack
Sanford, NC
 Sampling Location: Stack 1 (South)
 Date 2/7/78 Test Participants DM, RP, W, J, CG
 Bar. Press., in. Hg 29.46 Meter Box # N-3
 Static Press., in. H₂O 0 AH@ 1.74
 Ambient Temp, °F 40° C Factor .92
 Est. Moisture, % 59% Temp. Device Palmer

Run # 3
 Start: 14:11
 Finish: 16:23
 Filter # 2850 Tare Wt. .4008

Sample Box # 6 @ Heat Setting 14,
 Probe # 4-3 @ Heat Setting 7/1
 Nozzle # 305 with Dia., inches .244
 Pitot Leak Tests: Before 0 After 0
 Sampling Train Leak Test (from nozzle)
 Before @ 15 in. Hg = 0.01 cfm
 After @ 15 in. Hg = 0.01 cfm
 Avg. Ap 0.74 at Δh of 1.84

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (AP) in. H ₂ O	Orifice Manometer (AH) in. H ₂ O	Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
A	0	110.529	1.15	2.90	78	15	220	55	300
2	1 1/2	111.560	1.15	2.90	78	15	220	55	300
3	3	112.650	1.15	2.90	78	15	220	55	300
4	4 1/2	113.735	1.25	3.20	78	15	220	55	300
5	6	114.700	1.25	3.20	78	15	220	55	305
6	7 1/2	115.900	1.30	3.28	79	15	220	55	305
7	9	116.981	1.35	3.45	77	10	220	59	300
8	10 1/2	121.570	1.35	3.45	77	10	220	59	300
9	12	123.085	1.35	3.45	78	10	220	60	300
10	13 1/2	124.603	1.30	3.28	80	10	220	60	300
11	15	126.17	1.25	3.20	80	10	220	60	300
12	1 1/2	127.70	1.25	3.20	80	10	220	60	300
13	3	128.17	1.20	3.05	80	10	220	60	300
14	4 1/2	130.65	1.25	3.20	81	10	220	60	300
15	6	132.15	1.20	3.05	82	10	220	60	300
16	7 1/2	133.62	1.25	3.20	82	11	220	60	305
17	9	135.12	1.25	3.20	82	11	220	60	305
18	10 1/2	136.58	1.30	3.28	82	12	220	60	305
19	12	138.09	1.30	3.28	82	12	220	60	310
20	13 1/2	139.60	1.30	3.28	82	12	220	60	310
21	15	141.12	1.30	3.28	82	12	220	60	310

various problems from 116.98 to 120.03

PARTICULATE FIELD DATA

Company/Location Lee Brist
Seymour, N.C.
 Sampling Location: Stack #2 (Nozzle)
 Date 2-9-77 Test Participants RD-M-WN-26
 Bar. Press., in. Hg 29.46 Meter Box # N7
 Static Press., in. H₂O 0 ΔH@ 1.84
 Ambient Temp, °F 35 C Factor 1.0
 Est. Moisture, % 5 Temp. Device Palmer

Run # 4
 Start: 10:25
 Finish: 11:35
 Filter # 2807 Tare Wt. .3950
 Sample Box # 13 @ Heat Setting Hi
 Probe # 4 @ Heat Setting Hi
 Nozzle # 219 with Dia., inches .499
 Pitot Leak Tests: Before 0.0 After 0.0
 Sampling Train Leak Test (from nozzle)
 Before @ ≥ 15 in. Hg = 0.15 cfm
 After @ 4 in. Hg = 0.1 cfm
 Avg. Δp 0.42 at ΔH of 1.84

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (all) in. H ₂ O	Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
A1	0	102.420	.005	.20	42	1	210	50	330
1	1 1/2	102.89	.005	.20	44	1	220	50	330
2	3	103.17	.005	.20	44	1	225	50	330
4	4 1/2	103.63	.007	.30	44	1	225	50	330
5	6	104.10	.005	.20	44	1	230	50	330
6	7 1/2	104.49	.005	.20	44	1	230	50	335
7	9	104.87	.006	.25	44	1	230	50	335
8	10 1/2	105.30	.005	.20	45	1	230	50	335
9	12	105.70	.007	.30	45	1	220	50	335
10	13 1/2	106.11	.006	.25	45	1	220	50	335
11	15	106.55	.006	.25	45	1	220	50	335
12	1 1/2	106.96	.005	.20	45	1	220	50	335
13	3	107.34	.005	.20	45	1	220	50	335
14	4 1/2	107.72	.005	.20	45	1	220	50	335
15	6	108.12	.005	.20	45	1	220	50	330
16	7 1/2	108.41	.005	.20	45	1	220	50	330
17	9	108.91	.005	.20	45	1	220	50	330
18	10 1/2	109.15	.005	.20	45	1	220	50	330
19	12	109.58	.008	.35	45	1	220	50	330
20	13 1/2	110.05	.01	.44	48	1	220	50	330
21	15	110.43	.01	.44	48	1	220	50	330

Company Lee Brick

Run # 4

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Ap) In. H ₂ O	Orifice Manometer (ΔH) In. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
22	1 1/2	111.14	.01	44	44	48	1	225	50	330
21	3-0	111.68	.005	20	20	55	1	225	50	330
2	1 1/2	112.11	.01	44	44	55	1	225	50	330
3	3	112.69	.01	44	44	55	1	225	50	335
4	4 1/2	113.12	.01	44	44	55	1	225	50	335
5	6	113.69	.015	65	65	58	1	225	50	335
6	7 1/2	114.35	.01	44	44	58	1	225	50	335
7	9	114.89	.01	44	44	58	1	225	50	340
8	10 1/2	115.44	.005	20	20	58	1	225	50	345
9	12	115.85	.005	20	20	60	1	225	50	345
10	13 1/2	116.22	.005	20	20	60	1	225	50	345
11	15	116.80	.005	20	20	60	1	235	50	345
12	16 1/2	116.97	.005	20	20	60	1	235	50	345
13	18 1/2	117.35	.005	20	20	60	1	235	50	345
14	4 1/2	117.73	.005	20	20	60	1	245	50	345
15	6	118.09	.005	20	20	60	1	250	50	345
16	7 1/2	118.47	.005	20	20	60	1	250	50	345
17	9	118.85	.005	20	20	60	1	250	50	345
18	10 1/2	119.23	.005	20	20	60	1	250	50	345
19	12	119.61	.005	20	20	62	1	245	50	340
20	13 1/2	119.97	.005	20	20	62	1	245	50	340
21	15	120.30	.005	20	20	62	1	245	50	340
22	1 1/2	120.73	.000	44	44	62	1	245	50	340
	66 min	121.165								

PARTICULATE FIELD DATA

Company/Location Lee Buck
Sanford, NC
 Sampling Location: Stack #2
 Date 2-9-78 Test Participants DDDM J6 MW
 Bar. Press., in. Hg 29.46 Meter Box # N7
 Static Press., in. H₂O 0 Alt 1.84
 Ambient Temp, °F 40° C Factor 1.0
 Est. Moisture, % 5 Temp. Device Palmer

Run # 5
 Start: 12:18
 Finish: 13:27
 Filter # 2808 Tare Wt. 3941
 Sample Box # 12 @ Heat Setting Hi
 Probe # 4 @ Heat Setting Hi
 Nozzle # 314 with Dia., inches .502
 Pitot Leak Tests: Before 0.0 After 0.0
 Sampling Train Leak Test (from nozzle)
 Before @ ≥ 15 in. Hg = 0.005 cfm
 After @ 3 in. Hg = 0.005 cfm

Avg. Δp 0.042 at Alt of 1.84

Pyrite Section 1 and 1

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (ap) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
1	0	121.450	.005	.20	.20	52	1	225	50	340
2	1 1/2	121.88	.005	.20	.20	52	1	225	50	340
3	3	123.21	.005	.20	.20	52	1	225	50	340
4	4 1/2	122.60	.005	.20	.20	52	1	225	50	340
5	6	122.97	.005	.20	.20	52	1	225	50	340
6	7 1/2	123.28	.005	.20	.20	58	1	225	50	340
7	9	123.79	.01	.44	.44	58	1	225	50	340
8	10 1/2	124.15	.01	.44	.44	58	1	225	50	340
9	12	124.72	.01	.44	.44	58	1	225	50	340
10	13 1/2	125.18	.008	.35	.35	58	1	225	50	340
11	15	125.87	.008	.35	.35	58	1	235	50	340
12	1 1/2	126.27	.005	.20	.20	60	1	235	50	335
13	3	126.64	.005	.20	.20	60	1	235	50	335
14	4 1/2	127.05	.005	.20	.20	60	1	245	50	335
15	6	127.34	.01	.44	.44	60	1	245	50	335
16	7 1/2	127.89	.01	.44	.44	60	1	250	50	335
17	9	128.30	.005	.20	.20	60	1	250	50	335
18	10 1/2	128.91	.005	.20	.20	60	1	250	50	335
19	12	129.30	.005	.20	.20	60	1	250	50	340
20	13 1/2	129.67	.005	.20	.20	60	1	250	50	340
21	15	130.05	.005	.20	.20	60	1	250	50	340

Company/Location Sanford, NC
 Sampling Location: Start #2
 Date 2-9-78 Test Participants RDDM
 Bar. Press., in. Hg 29.46 Meter Box # N2
 Static Press., in. H₂O 0 Alt. 1.84
 Ambient Temp, °F 40 C Factor 1.0
 Est. Moisture, % 5 Temp. Device Relay

Run # 6
 Start: 1411
 Finish: 16:23
 Filter # 2857 Tare Wt. 3908

Sample Box # 12 @ Heat Setting 250
 Probe # 4 @ Heat Setting 74
 Nozzle # 315 with Dia., inches .502
 Pitot Leak Tests: Before 0.0 After 0.0
 Sampling Train Leak Test (from nozzle)
 Before @ ≥ 15 in. Hg = 0.01 cfm
 After @ 4 in. Hg = 0.005 cfm
 Avg. Ap. 0.042 at Alt of 1.84

PARTICULATE FIELD DATA

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (in. H ₂ O)	Orifice Manometer (in. H ₂ O)		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Injinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A 1	0	139.600	.005	.20	.20	64	1	225	55	335
2	1 1/2	140.00	.005	.20	.20	64	1	225	55	335
3	3	140.42	.005	.20	.20	64	1	225	55	335
4	4 1/2	140.93	.005	.20	.20	64	1	230	55	335
5	6	141.10	.01	.44	.44	64	1	230	55	335
6	7 1/2	141.58	.01	.44	.44	64	1	230	55	340
7	9	142.17	.009	.35	.35	64	1	230	55	340
8	10 1/2	142.57	.008	.35	.35	64	1	230	55	340
9	12 1/2	143.01	.01	.44	.44	62	1	230	55	340
10	13 1/2	143.48	.01	.44	.44	62	1	230	55	340
11	15	144.01	.008	.35	.35	64	1	235	55	340
12	1 1/2	144.51	.005	.20	.20	64	1	235	55	340
13	3	144.92	.005	.20	.20	64	1	235	55	340
14	4 1/2	145.28	.005	.20	.20	64	1	240	55	340
15	6	145.67	.008	.35	.35	64	1	240	55	340
16	7 1/2	146.14	.01	.44	.44	64	1	240	55	340
17	9	146.70	.01	.44	.44	68	1	240	55	340
18	10 1/2	147.26	.008	.35	.35	68	1	240	55	340
19	12	147.78	.005	.20	.20	68	1	245	55	340
20	13 1/2	148.20	.005	.20	.20	68	1	245	55	340
21	15	148.57	.005	.20	.20	68	1	245	55	340

CUSTODY SHEET FOR REAGENT BOX # 0208

Date of Makeup 18 Jan 77 Individual Water Tare Volume 200 mls
 Initials ESS Individual Silica Gel Tare Weight 225.0 gms
 Locked? /

Plant Name Yee Brick
 Sampling Location Sanford, NC

Box/Test Number	Date Used	Initials	Locked?	Date Cleanup	S. Gel Spent?	Initials	Locked?
6 / 1	2/9/78	UN	✓	2/9/78	55%	UN	✓
6 / 2	2/9/78	UN	✓	2/9/78	80%	UN	✓
6 / 3	2/9/78	UN	✓	2/9/78	99%	UN	✓

Date Initials Locked?
 Transferred to Lab 10 Feb ESS /
 Received in Lab 10 Feb ESS /

Zero & Span Balance
 Initials ESS

Sampling Method: EPA - 5

Remarks:

Heavy loading

Filter #	Tare Weight (mgms)	Used on Test
<u>2809</u>	<u>393.2</u>	<u>1</u>
<u>2806</u>	<u>391.5</u>	<u>2</u>
<u>2850</u>	<u>400.8</u>	<u>3</u>

ENTROPY
 ENVIRONMENTALISTS, INC.

SPECIALISTS IN
 SOURCE
 SAMPLING

PARTICULATE SAMPLING CLEANUP SHEET

Plant Name Lee Buck Sanford, N.C.
 Sampling Location _____
 Reagent Box # 0208 Date Analyzed 10 Feb 78

Date of Test
 Test Number

9 Feb 9 Feb
1 2
3

Moisture Collected:

Impinger water volume	<u>212</u>	<u>218</u>	<u>210</u>
Tared volume	<u>200</u>	<u>200</u>	<u>200</u>
Captured water	<u>12</u> mls	<u>18</u> mls	<u>10</u> mls
Silica Gel weight	<u>245.0</u>	<u>251.0</u>	<u>253.0</u>
Tared weight	<u>225.0</u>	<u>225.0</u>	<u>225.0</u>
Adsorbed water	<u>20.0</u> gms	<u>26.0</u> gms	<u>28.0</u> gms
TOTAL MOISTURE CATCH	<u>32.0</u> mls	<u>45.0</u> mls	<u>38.0</u> mls

Front Half Analysis: (Nozzle, probe, cyclone, filter front half)

Filter & Particulate	<u>923.5</u>	<u>942.6</u>	<u>845.0</u>
Filter Tare weight	<u>393.2</u>	<u>391.5</u>	<u>400.8</u>
Filter Particulate	<u>530.3</u>	<u>551.1</u>	<u>444.2</u>
Rinsings or Dry Wt.	<u>-</u>	<u>-</u>	<u>-</u>
Particulate catch	<u>530.3</u> mgms	<u>551.1</u> mgms	<u>444.2</u> mgms
Acetone blank	<u>-1.6</u>	<u>-1.1</u>	<u>-1.0</u>
TOTAL FRONT CATCH	<u>528.7</u> mgms	<u>550.0</u> mgms	<u>443.2</u> mgms

Back Half Analysis: (Impingers, filter back half)

Extractables weight	_____	_____	_____
Boil Down weight	_____	_____	_____
Impingers' Catch	_____ mgms	_____ mgms	_____ mgms
Water blank	_____	_____	_____
TOTAL BACK CATCH	_____ mgms	_____ mgms	_____ mgms
TOTAL TRAIN CATCH	_____ mgms	_____ mgms	_____ mgms

Blank Calculations:	Acetone	Water
Blank Residue	<u>0.6</u> mg	_____
Blank Volume	<u>100</u> ml	_____
Concentration	<u>0.06</u> mg/mls	_____ mg/mls
Volume Used	<u>257</u> mls	_____ mls
# <u>1</u> Blank Weight	<u>1.6</u> mgms	_____ mgms
Volume Used	<u>181</u> mls	_____ mls
# <u>2</u> Blank Weight	<u>1.1</u> mgms	_____ mgms
Volume Used	<u>175</u> mls	_____ mls
# <u>3</u> Blank Weight	<u>1.0</u> mgms	_____ mgms

Analysis Method: (Zero & Span Balance SES Initials)
EPA Method 5

Description of Sample:
gray powder or dust

Remarks:
Heavy loading

CUSTODY SHEET FOR REAGENT BOX # 0207

Date of Makeup 7 Feb 78 Individual Water Tare Volume 200 mls
 Initials SSS Individual Silica Gel Tare Weight 225.0 gms
 Locked? ☒

Plant Name

Sen. Brick

Sampling Location

Sanford, VT

Box/Test Number	Date Used	Initials	Locked?	Date Cleanup	S. Gel Spent?	Initials	Locked?
<u>4</u>	<u>2-9-78</u>	<u>WW</u>	<u>—</u>	<u>2-9-78</u>	<u>25%</u>	<u>RD</u>	☒
<u>5</u>	<u>2-9-78</u>	<u>WW</u>	<u>✓</u>	<u>2-9-78</u>	<u>35%</u>	<u>RD</u>	☒
<u>6</u>	<u>2-9-78</u>	<u>WW</u>	<u>—</u>	<u>2-9-78</u>	<u>25%</u>	<u>RD</u>	☒

Date Initials Locked?
 Transferred to Lab 2-10-78 RD ☒
 Received in Lab 2-10-78 SSS ☒

Zero & Span Balance
 Initials SSS

Sampling Method: EPA # 5

Remarks:

medium loading

Filter #	Tare Weight (mgms)	Used on Test
<u>2827</u>	<u>395.0</u>	<u>4</u>
<u>2828</u>	<u>394.1</u>	<u>5</u>
<u>2857</u>	<u>390.8</u>	<u>6</u>

PARTICULATE SAMPLING CLEANUP SHEET

Plant Name Lee Buck, Sanford, N.C.
 Sampling Location _____
 Reagent Box # 0207 Date Analyzed 10 Feb 78

Date of Test 7 Feb 7 Feb 9 Feb
 Test Number 4 5 6

Blank Calculations: Acetone _____ Water _____
 Blank Residue 0.6 mg
 Blank Volume 100 ml
 Concentration 0.06 ng/mls _____ mg/mls
 Volume Used 244 mls _____ mls
 # 4 Blank Weight 1.5 mgms _____ mgms
 Volume Used 194 mls _____ mls
 # 5 Blank Weight 1.2 mgms _____ mgms
 Volume Used 178 mls _____ mls
 # 6 Blank Weight 1.1 mgms _____ mgms

Moisture Collected:
 Impinger water volume 205 _____ 206 _____ 203 _____
 Tared volume 200 _____ 200 _____ 200 _____
 Captured water 5 mls _____ 6 mls _____ 3 mls _____
 Silica Gel weight 228.0 _____ 227.5 _____ 230.0 _____
 Tared weight 225.0 _____ 225.0 _____ 225.0 _____
 Adsorbed water 3.0 gms _____ 2.5 gms _____ 5.0 gms _____
 TOTAL MOISTURE CATCH 8.0 mls _____ 8.5 mls _____ 8.0 mls _____

Front Half Analysis: (Nozzle, probe, cyclone, filter front half)
 Filter & Particulate 587.1 _____ 575.2 _____ 550.8 _____
 Filter Tare weight 395.0 _____ 394.1 _____ 390.8 _____
 Filter Particulate 192.1 _____ 181.1 _____ 160.0 _____
 Rinsings or Dry Wt. _____
 Particulate catch 192.1 mgms _____ 181.1 mgms _____ 160.0 mgms
 Acetone blank 1.5 _____ 1.2 _____ 1.1 _____
 TOTAL FRONT CATCH 190.6 mgms _____ 179.9 mgms _____ 158.9 mgms

Back Half Analysis: (Impingers, filter back half)
 Extractables weight _____
 Boil Down weight _____
 Impingers' Catch _____ mgms _____ mgms _____ mgms
 Water blank _____
 TOTAL BACK CATCH _____
 TOTAL TPAH CATCH _____

Analysis Method: (Zero & Span Balance SES Initials)
EPA - method 5

Description of Sample: gray dust

Remarks: medium looking

PARTICULATE FIELD DATA

	Company/Location	Date
10.	LEE BACK	7-9-68

SANFORD NC

Sampling Location: STACK #1

Date 2-9-78 Test Participants WV DJC RD DM

Bar. Press., in. Hg 29.46 Meter Box # 11-3

Static Press., in. H₂O ΔH_0 1.74

Ambient Temp, °F 40° C Factor .92

Est. Moisture, % 570 Temp. Device Palmer

Run # 1-A

Start: 16:40

Finish: 16.52.

Filter #	Tare Wt.
1	0.0000
2	0.0000
3	0.0000
4	0.0000
5	0.0000
6	0.0000
7	0.0000
8	0.0000
9	0.0000
10	0.0000
11	0.0000
12	0.0000
13	0.0000
14	0.0000
15	0.0000
16	0.0000
17	0.0000
18	0.0000
19	0.0000
20	0.0000
21	0.0000
22	0.0000
23	0.0000
24	0.0000
25	0.0000
26	0.0000
27	0.0000
28	0.0000
29	0.0000
30	0.0000
31	0.0000
32	0.0000
33	0.0000
34	0.0000
35	0.0000
36	0.0000
37	0.0000
38	0.0000
39	0.0000
40	0.0000
41	0.0000
42	0.0000
43	0.0000
44	0.0000
45	0.0000
46	0.0000
47	0.0000
48	0.0000
49	0.0000
50	0.0000
51	0.0000
52	0.0000
53	0.0000
54	0.0000
55	0.0000
56	0.0000
57	0.0000
58	0.0000
59	0.0000
60	0.0000
61	0.0000
62	0.0000
63	0.0000
64	0.0000
65	0.0000
66	0.0000
67	0.0000
68	0.0000
69	0.0000
70	0.0000
71	0.0000
72	0.0000
73	0.0000
74	0.0000
75	0.0000
76	0.0000
77	0.0000
78	0.0000
79	0.0000
80	0.0000
81	0.0000
82	0.0000
83	0.0000
84	0.0000
85	0.0000
86	0.0000
87	0.0000
88	0.0000
89	0.0000
90	0.0000
91	0.0000
92	0.0000
93	0.0000
94	0.0000
95	0.0000
96	0.0000
97	0.0000
98	0.0000
99	0.0000
100	0.0000

Sample Box # 6 @ Heat Setting He

Probe # A1 @ Heat Setting 26

Nozzle # 303 with Dia., inches, (73

Pitot	Leak	Tests:	Before	After

Sampling Train Leak Test (from nozzle)

Before @ ≥ 15 in. Hg = 0.00 cfm

After @ 5 in. Hg = 0.00 cfm

Avg. Ap **2.75** at ΔH of 1.84

[illegible]

Company/Location	Lee Black

Lee Back

Amherst NC

Sampling Location: Stack #2

Date 2-1-78
Test Participants 80 BM

Bar. Press., in. Hg 29.46 Meter Box # 112

Static Press., in. H₂O 0 Atm 1.84

Ambient Temp, °F 40 C Factor 1.0

Est. Moisture, % 5 Temp. Device Palmer

run # 2A

Start: 1840

Finish: 16:56

Filter #	Tare wt.
1	0.0000
2	0.0000
3	0.0000
4	0.0000
5	0.0000
6	0.0000
7	0.0000
8	0.0000
9	0.0000
10	0.0000
11	0.0000
12	0.0000
13	0.0000
14	0.0000
15	0.0000
16	0.0000
17	0.0000
18	0.0000
19	0.0000
20	0.0000
21	0.0000
22	0.0000
23	0.0000
24	0.0000
25	0.0000
26	0.0000
27	0.0000
28	0.0000
29	0.0000
30	0.0000
31	0.0000
32	0.0000
33	0.0000
34	0.0000
35	0.0000
36	0.0000
37	0.0000
38	0.0000
39	0.0000
40	0.0000
41	0.0000
42	0.0000
43	0.0000
44	0.0000
45	0.0000
46	0.0000
47	0.0000
48	0.0000
49	0.0000
50	0.0000
51	0.0000
52	0.0000
53	0.0000
54	0.0000
55	0.0000
56	0.0000
57	0.0000
58	0.0000
59	0.0000
60	0.0000
61	0.0000
62	0.0000
63	0.0000
64	0.0000
65	0.0000
66	0.0000
67	0.0000
68	0.0000
69	0.0000
70	0.0000
71	0.0000
72	0.0000
73	0.0000
74	0.0000
75	0.0000
76	0.0000
77	0.0000
78	0.0000
79	0.0000
80	0.0000
81	0.0000
82	0.0000
83	0.0000
84	0.0000
85	0.0000
86	0.0000
87	0.0000
88	0.0000
89	0.0000
90	0.0000
91	0.0000
92	0.0000
93	0.0000
94	0.0000
95	0.0000
96	0.0000
97	0.0000
98	0.0000
99	0.0000
100	0.0000

Sample Box # 12 @ Heat Setting 76

Probe # 4 @ Heat Setting 26

Nozzle # 214 with Dia., inches 0.489

Pitot Leak Tests:	Before	After
	0	0

Sampling Train Leak Test (from nozzle)

Before @ ≥ 15 in. Hg = 0.05cfm

After @ l in. lly = 8.0 cfm

Avg. Ap. ~~2.48~~ at ΔH of 1.84

[illegible]

APPENDIX D

TEST PARTICIPANTS

ROY N. DOSTER

D. JAMES GROVE, P.E.

WILLIS NESBIT

DAN MILHOLLAND

PROJECT DIRECTOR, TEAM LEADER

SENIOR ENGINEER

TEAM LEADER

ENGINEERING TECHNICIAN

APPENDIX E

F-factor Method

For each sample run, an integrated gas sample is obtained using a stainless steel probe, moisture knockout jar, diaphragm pump, and Tedlar bag. The gas sample is collected at a minimum of 12 Method 5 traverse points and later analyzed with an orsat apparatus to determine %CO₂, %O₂, and %CO. An excess air correction factor is calculated based on the oxygen content in the effluent stream.

The F-factor is defined as the ratio of the theoretical quantity of dry effluent gas generated by combustion to the heat content of the fuel. Using this ratio and the excess air correction factor, the ratio of the actual volumetric flow rate to the heat input rate may be calculated. Measurement of the excess air and the flow rate thus allows determination of the heat input rate. In a similar manner, the F-factor, excess air, and pollutant concentration are used to calculate emission rates directly in terms of lbs/10⁶ Btu.

Using stoichiometric relations, F-factors may be calculated from the ultimate analysis and heating value of the fuel. However, the values for F are constant for any given fuel category within ±3%. Average values for F (dscf/10⁴ Btu), for some common fuels are : bituminous coal, 98.2; oil, 92.2; gas, 87.4; wood, 92.5; and bark, 97.0.

The use of the F-factor Method eliminates the inconsistencies which arise in determining heat input rates from fuel burning rates or steam production rates. The accuracy of the F-factor Method, however, is dependent on the accuracy of the excess air and volumetric flow rate measurements.