

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.3
Background Chapter	4
Reference:	21
Title:	<i>Stationary Source Sampling Report: Chatham Brick And Tile Company, Sanford, NC, Kiln No. 2 Particulate Emissions Compliance Testing, Entropy Environmentalists, Inc., Research Triangle Park, NC, July 1979.</i>

CH4 ref 21

NTROPY NVIRONMENTALISTS, INC

SPECIALISTS IN AIR POLLUTION MEASUREMENT & MANAGEMENT

STATIONARY SOURCE SAMPLING REPORT

CHATHAM BRICK INDUSTRIES, INC.

SANFORD, NORTH CAROLINA

PARTICULATE EMISSIONS COMPLIANCE TEST

JUNE 1970


P.O. Box 12291, Research Triangle Park, North Carolina 27709
Phone 919 761 3550

REPORT CERTIFICATION

The sampling and analysis performed for this report was carried out under my direction and supervision.

Date July 27, 1979

Signature


Frank J. Phoenix

I have reviewed all testing details and results in this test report and hereby certify that the test report is authentic and accurate.

Date July 27, 1979

Signature



D. James Grove, P. E.

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
INTRODUCTION	1
SUMMARY OF RESULTS	2
PROCESS DESCRIPTION AND OPERATION	5
SAMPLING AND ANALYTICAL PROCEDURES	7
APPENDICES	11
A - Particulate Results & Example Calculations	
A-1 Waste Heat Stack, Tests 1-3	
A-2 Dryer Stack, Tests 4-6	
B - Field & Analytical Data	
B-1 Waste Heat Stack, Tests 1-3	
B-2 Dryer Stack, Tests 4-6	
C - Test Participants	
D - Sampling & Analytical Procedures	
E - Calibration Data	

INTRODUCTION

Stationary source sampling was performed on July 18-19, 1979 at Chatham Brick and Tile Company, Sanford, North Carolina to determine the particulate emissions from kiln #2 which is exhausted by two stacks - the waste heat stack and the dryer stack. Three sets of tests at each site were performed simultaneously.

Immediately following is the "Summary of Results" section, presenting a summary for all the tests. Detailed results of the six particulate tests appear in Appendix A.

A description of the process, including an air flow schematic, is given in the "Process Description and Operation" section.

The last section, "Sampling and Analytical Procedures," briefly describes the sampling strategy used. For a detailed description of the equipment and procedures, see Appendix D. Calibration data is given in Appendix E.

SUMMARY OF RESULTS

Presented in Table 1 below are the emission rates as determined by the six particulate emission tests performed on the waste heat and dryer exhaust stacks.

TABLE 1
PARTICULATE EMISSIONS
pounds per hour

<u>Simultaneous Tests</u>	<u>Waste Heat Stack</u>	<u>Dryer Exhaust</u>	<u>Total</u>
1 & 4	1.35	0.81	2.16
2 & 5	1.12	0.38	1.50
3 & 6	1.80	0.49	2.29
Average	1.42	0.56	1.98

According to North Carolina Regulation 2D.0515, the maximum allowable emission rate is 13.2 pounds per hour. This is based on a process rate of 5.75 tons per hour and includes an estimate of the sawdust being burned. Determination of the process rate is given in the "Process Description and Operation" section.

Tables 2 and 3 on the following pages give the individual test summaries for the tests performed at the waste heat stack and the dryer exhaust.

TABLE 2

PARTICULATE TESTS SUMMARY OF RESULTS

Waste Heat Stack

RUN NUMBER	1	2	3
DATE	7/18/79	7/18/79	7/19/79
STACK TEMPERATURE, DEG. F	341.	344.	323.
STACK FLOW RATE SCFM* DRY	12037.	11888.	12328.
STACK FLOW RATE ACFM, WET	19677.	19577.	19522.
VOLUME OF GAS SAMPLED SCF* DRY	50.91	49.83	52.34
PERCENT ISOKINETIC	102.3	101.3	102.6
PARTICULATES, EPA METHOD 5: -----			
MILLIGRAMS - CATCH	43.2	35.4	57.8
GRAINS PER DSCF*	.0131	.0110	.0170
POUNDS PER HOUR	1.35	1.12	1.80

* 68 DEG F, 29.92 IN. HG

TABLE 3

PARTICULATE TESTS SUMMARY OF RESULTS

Dryer Outlet Stack

RUN NUMBER	4	5	6
DATE	7/18/79	7/18/79	7/19/79
STACK TEMPERATURE, DEG. F	124.	124.	116.
STACK FLOW RATE SCFM* DRY	16272.	14877.	15246.
STACK FLOW RATE ACFM, WET	18917.	17596.	17527.
VOLUME OF GAS SAMPLED SCF* DRY	50.79	49.21	49.00
PERCENT ISOKINETIC	93.8	99.4	96.5
PARTICULATES, EPA METHOD 5: -----			
MILLIGRAMS - CATCH	19.1	9.6	12.0
GRAINS PER DSCF*	.0058	.0030	.0038
POUNDS PER HOUR	.81	.38	.49

* 68 DEG F, 29.92 IN. HG

PROCESS DESCRIPTION AND OPERATION

Chatham Brick and Tile Company in Sanford, North Carolina manufactures bricks, which involves the screening and blending of the raw materials and the drying and firing of the final, shaped product. The bricks travel through a tunnel consisting of three zones - brick dryer, firing zone, and cooling zone. The bricks are placed on cars which travel on rails through the kiln. When the car enters and leaves the tunnel, ambient air is allowed to enter uncontrolled. The dryer exhaust stack is located at the beginning of the tunnel.

The car enters the brick dryer where excess water is evaporated off. Hot air used to dry the brick is supplied by the firing zone of the tunnel. The firing zone is located near the middle of the kiln. Natural gas and sawdust are used to heat the firing zone. As shown in Figure 1, ambient air is used to cool the bricks. The beginning of the firing zone is exhausted by a fan.

Potential emissions from the kiln consist mainly of particulate matter in the form of dust generated by the handling of the bricks, and of combustion products from the sawdust. No pollution control equipment is presently in use.




FIGURE 1. PROCESS AIR SCHEMATIC & SAMPLING LOCATIONS

During the testing performed at the two stacks, 2263 bricks per hour were being fired in the kiln. With an average brick weight of 4.6 pounds, this converts to a process rate of 5.2 tons of brick per hour. When the estimated sawdust usage rate of 0.55 tons per hour is added, the total process rate is 5.75 tons per hour.

SAMPLING AND ANALYTICAL PROCEDURES

All sampling and analytical procedures used were those recommended by the United States Environmental Protection Agency and the North Carolina Department of Natural Resources and Community Development. Complete details of the equipment and procedures used are described in Appendix D, which is extracted from the Federal Register, August 18, 1977.

Method 1 was used to determine the number and location of the sampling points. A stack extension was added to both stacks. The waste heat stack cross section was divided into 40 equal areas with eight points on each of five traverse axes, as shown in Figure 2. The centroid of each area was sampled for two minutes, resulting in 80 minute tests. The dryer exhaust stack was divided into 36 equal areas, with nine points on each of four traverse axes, as shown in Figure 3. The points were sampled for two minutes each, for a total testing time of 72 minutes for each run.

Velocity measurements were in accordance with Method 2. Molecular weights for the stack gases were determined by Method 3 procedures. Particulate emissions were found using Method 5 analytical and sampling procedures.

All sampling equipment used was manufactured by Nutech Corporation or Entropy Environmentalists, Inc.





FIGURE 2. WASTE HEAT STACK DIMENSIONS AND SAMPLING POINT LOCATION





FIGURE 3. DRYER EXHAUST STACK DIMENSION AND SAMPLE POINT LOCATION

APPENDICES

APPENDIX A

APPENDIX A-1

PARTICULATE TESTS RESULTS
WITH EXAMPLE CALCULATIONS

EXAMPLE PARTICULATE CALCULATIONS TEST NO. 1

Waste Heat Stack

VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS

$$VMSTD = 17.64 * VM * Y * (PB+PM/13.6) / (TM+460)$$

$$VMSTD = \frac{17.64 * 53.956 * 1.006 * (29.77 + 1.520/13.6)}{562.0} = 50.910 \text{ DSCF}$$

VOLUME OF WATER VAPOR AT STANDARD CONDITIONS

$$VWV = .04707 * VW$$

$$VWV = .04707 * 77.0 = 3.624 \text{ SCF}$$

PERCENT MOISTURE IN STACK GAS

$$PMV = (100 * VWV) / (VMSTD + VWV)$$

$$PMV = \frac{100. * 3.62}{50.910 + 3.62} = 6.6 \text{ PERCENT}$$

MOLE FRACTION OF DRY STACK GAS

$$MD = (100. - PMV) / 100.$$

$$MD = \frac{100. - 6.6}{100.} = .934$$

AVERAGE MOLECULAR WEIGHT OF DRY STACK GAS

$$MWD = (PCO2 * .44) + (PO2 * .32) + (PN2 + PCO) * .28$$

$$MWD = (1.8 * 0.44) + (18.7 * 0.32) + ((79.5 + 0.0) * 0.28) = 29.04 \text{ LB/LB MOLE}$$

MOLECULAR WEIGHT OF STACK GAS

$$MW = MWD * MD + 18 * (1 - MD)$$

$$MW = 29.04 * .934 + 18 * (1 - .934) = 28.30 \text{ LB/LB MOLE}$$

STACK GAS VELOCITY AT STACK CONDITIONS

$$VS = 85.49 * CP * \text{SQRT}[(DPS * (TS+460))/(PS * MW)]$$

$$VS = 85.49 * .84 * \text{SQRT}[(.528 * 801.)/(29.76 * 28.30)] = 50.9 \text{ FPS}$$

STACK GAS VOLUMETRIC FLOW AT STACK CONDITIONS

$$QA = VS * AS * 60 / 144$$

$$QA = 50.9 * 928. * 60 / 144 = 19677. \text{ ACFM}$$

STACK GAS VOLUMETRIC FLOW AT STANDARD CONDITIONS

$$QS = (17.64 * QA * PS * MD) / (TS+460)$$

$$QS = \frac{17.64 * 19677. * 29.76 * .934}{801.0} = 12037. \text{ SCFM}$$

PERCENT ISOKINETIC

$$PERI = (17.3 * (TS+460) * VMSTD)/(VS * TT * PS * MD * DN * DN)$$

$$PERI = \frac{17.3 * 801. * 50.910}{50.9 * 80.0 * 29.76 * .934 * .247 * .247} = 102.3 \text{ PERCENT}$$

PARTICULATE LOADING -- EPA METHOD 5
(AT STANDARD CONDITIONS)

$$CAN = 0.01543 * FMF/VMSTD$$

$$CAN = 0.01543 * (43.2/50.91) = .0131 \text{ GR/DSCF}$$

PARTICULATE LBS/HR--EPA METHOD 5

$$CAW = 0.00857 * CAN * QS$$

$$CAW = 0.00857 * .0131 * 12037. = 1.35 \text{ LBS/HR}$$

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: Chatham Brick & Tile Company, Sanford, N. C.

TEST TEAM LEADER: Frank J. Phoenix

TEST 1 Waste Heat Stack

TEST 2 Waste Heat Stack

TEST 3 Waste Heat Stack

RUN NUMBER		1	2	3
-----		-	-	-
TEST DATE		7/18/79	7/18/79	7/19/79

TB	TIME-START	920	1115	1028
TF	TIME-FINISH	1048	1312	1240
TT	NET TIME OF TEST, MIN.	80.0	80.0	80.0
FNP	NET SAMPLING POINTS	40.	40.	40.
DN	SAMPLING NOZZLE DIA., IN.	.247	.247	.247
CP	PITOT TUBE COEFFICIENT	.84	.84	.84
Y	DRY GAS METER CAL. FACTOR	1.006	1.006	1.006
PM	AVERAGE ORIFICE PRESSURE DROP, IN. H2O	1.52	1.51	1.54
VM	VOLUME OF DRY GAS SAMPLED CU. FT. AT METER CONDITIONS	53.956	53.466	54.259
TM	AVERAGE GAS METER TEMP. DEGREES F	102.	109.	94.
VMSTD	VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS*, SCF	50.910	49.826	52.338
VW	TOTAL H2O COLLECTED IN IMPINGERS & SILICA GEL, ML.	77.0	79.5	77.5
VWV	VOLUME OF WATER VAPOR AT STANDARD CONDITIONS*, SCF	3.62	3.74	3.65
PMV	PERCENT MOISTURE BY VOL.	6.6	7.0	6.5
MD	MOLE FRACTION DRY GAS	.934	.930	.935
PCO2	PERCENT CO2 BY VOL., DRY	1.8	1.8	1.8
PO2	PERCENT O2 BY VOL., DRY	18.7	18.7	18.7

PCO	PERCENT CO BY VOL., DRY	0.0	0.0	0.0
PN2	PERCENT N2 BY VOL., DRY	79.5	79.5	79.5
MWD	MOLECULAR WT-DRY STACK GAS	29.04	29.04	29.04
MW	MOLECULAR WT-STACK GAS	28.30	28.27	28.32
PB	BAROMETRIC PRESSURE, IN. HG.	29.77	29.77	30.00
PSI	STATIC PRES OF STACK GAS IN. H2O	-.2	-.2	-.2
PS	STACK PRES, ABS., IN. HG.	29.76	29.76	29.99
TS	AVERAGE STACK TEMP. DEG. F	341.	344.	323.
DPS	AVERAGE VELOCITY HEAD OF STACK GAS, IN. H2O	.528	.520	.536
VS	AVE STACK GAS VELOCITY, FPS	50.9	50.6	50.5
AS	STACK AREA, SQUARE INCHES	928.	928.	928.
QS	STACK FLOW RATE, DRY SCFM*	12037.	11888.	12328.
QA	ACTUAL STACK FLOW RATE, ACFM	19677.	19577.	19522.
PERI	PERCENT ISOKINETIC	102.3	101.3	102.6

PARTICULATES, EPA METHOD 5:

FMF	MILLIGRAMS - CATCH	43.2	35.4	57.8
CAN	GRAINS PER DSCF*	.0131	.0110	.0170
CAW	POUNDS PER HOUR	1.35	1.12	1.80

* 68 DEG F, 29.92 IN. HG

APPENDIX A-2

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: Chatham Brick & Tile Company, Sanford, N. C.

TEST TEAM LEADER: Chris M. Wrenn

TEST 4 Dryer Outlet Stack

TEST 5 Dryer Outlet Stack

TEST 6 Dryer Outlet Stack

RUN NUMBER		4	5	6
-----		-	-	-
TEST DATE		7/18/79	7/18/79	7/19/79

TB	TIME-START	920	1119	1134
TF	TIME-FINISH	1043	1257	1254
TT	NET TIME OF TEST, MIN.	72.0	72.0	72.0
FNP	NET SAMPLING POINTS	36.	36.	36.
DN	SAMPLING NOZZLE DIA., IN.	.252	.252	.252
CP	PITOT TUBE COEFFICIENT	.84	.84	.84
Y	DRY GAS METER CAL. FACTOR	1.000	1.000	1.000
PM	AVERAGE ORIFICE PRESSURE DROP, IN. H2O	1.79	2.31	1.74
VM	VOLUME OF DRY GAS SAMPLED CU. FT. AT METER CONDITIONS	53.444	52.086	50.800
TM	AVERAGE GAS METER TEMP. DEGREES F	95.	99.	91.
VMSTD	VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS*, SCF	50.792	49.210	48.998
VW	TOTAL H2O COLLECTED IN IMPINGERS & SILICA GEL, ML.	49.5	67.0	59.0
VWV	VOLUME OF WATER VAPOR AT STANDARD CONDITIONS*, SCF	2.33	3.15	2.78
PMV	PERCENT MOISTURE BY VOL.	4.4	6.0	5.4
MD	MOLE FRACTION DRY GAS	.956	.940	.946
PCO2	PERCENT CO2 BY VOL., DRY	1.8	1.8	1.8
PO2	PERCENT O2 BY VOL., DRY	18.7	18.7	18.7

PCO	PERCENT CO BY VOL., DRY	0.0	0.0	0.0
PN2	PERCENT N2 BY VOL., DRY	79.5	79.5	79.5
MWD	MOLECULAR WT-DRY STACK GAS	29.04	29.04	29.04
MW	MOLECULAR WT-STACK GAS	28.55	28.37	28.44
PB	BAROMETRIC PRESSURE, IN. HG.	29.77	29.77	30.00
PSI	STATIC PRES OF STACK GAS IN. H2O	.2	.2	.2
PS	STACK PRES, ABS., IN. HG.	29.78	29.78	30.01
TS	AVERAGE STACK TEMP. DEG. F	124.	124.	116.
DPS	AVERAGE VELOCITY HEAD OF STACK GAS, IN. H2O	.499	.429	.436
VS	AVE STACK GAS VELOCITY, FPS	42.0	39.1	38.9
AS	STACK AREA, SQUARE INCHES	1080.	1080.	1080.
QS	STACK FLOW RATE, DRY SCFM*	16272.	14877.	15246.
QA	ACTUAL STACK FLOW RATE, ACFM	18917.	17596.	17527.
PERI	PERCENT ISOKINETIC	93.8	99.4	96.5
	PARTICULATES, EPA METHOD 5: -----			
FMF	MILLIGRAMS - CATCH	19.1	9.6	12.0
CAN	GRAINS PER DSCF*	.0058	.0030	.0038
CAW	POUNDS PER HOUR	.81	.38	.49

* 68 DEG F, 29.92 IN. HG

APPENDIX B

APPENDIX B-1

Plant Name CHATHAM BRICK & TILE CO.

Sampling Location WASTE HEAT STACK

Run and/or Sample No. _____ Leak Test? ☒ Date 7-19 Operator CW

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
11:00 → 12:30	15:00	1.8	20.5	-	18.7	-	—
							—
							—
Avg.		1.8	Avg.		18.7		79.5

Run and/or Sample No. _____ Leak Test? _____ Date _____ Operator _____

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
							—
							—
							—
Avg.			Avg.				

Run and/or Sample No. _____ Leak Test? _____ Date _____ Operator _____

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
							—
							—
							—
Avg.			Avg.				

PRELIMINARY FIELD DATA

Stack Geometry

Plant Name CHATHAM BRICK & TILE

Plant Location SANFORD, N.C.

Sampling Location WASTE HEAT STACK

Date(s) 7/17 - 19/79

A. Dist. from inside of far wall to outside of near wall: 32" inches

B. Wall thickness: neg. inches


Inside diameter of stack (A-B): - inches

Stack Area: 928 square inches

Comments: 5 PORTS / 8 points per port

Sketch of stack cross section showing sampling ports.

STACK EXTENSION



Sketch of stack dimensions and location of sampling ports.

Point	% of Diameter	Distance from inside wall	Distance from outside of port
1	1/16	2	
2	3/16	6	
3	5/16	10	
4	7/16	14	
5	9/16	18	
6	11/16	22	SAME
7	13/16	26	
8	15/16	30	

ENTROPY ENVIRONMENTALISTS, INC.

SPECIALISTS IN
SOURCE
AMPLING

PARTICULATE FIELD DATA

Company/Location CHATHAM BRICK

AND TILE CO.

Run # 1

Sampling Location: WASTE HEAT STACK

Date 7-18-79 Test Participants FSP, JAI

Bar. Press., in. Hg 29.77 Meter Box # N-4

Static Press., in. H₂O - .15 ΔH@ 1.87

Ambient Temp, °F 90 C Factor 1.09

Est. Moisture, % 6 Temp. Device T/c

Sample Box # 1 @ Heat Setting 5

Probe # 4 @ Heat Setting 5

Nozzle # 505 with Dia., inches 2.47

Pitot Leak Tests: Before ☒ After ☒

Sampling Train Leak Test (from nozzle)

Before @ ≥ 15 in. Hg = .003 cfm

After @ 6 in. Hg = .000 cfm

Avg. Δp .65 at ΔH of 1.84

Start: 9:20

Finish: 10:48

ΔW/ΔP = K = 2.83

Filter # 3947 Tare Wt. .4712

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A 1	0	988.350	.18	.51	.51	95	1	260	68	310
2	2	989.27	.31	.878	.878	96	1	-	-	321
3	4	990.3	.39	1.10	1.10	97	3	-	-	331
4	6	991.4	.44	1.25	1.25	97	3	255	60	341
5	8	992.7	.43	1.22	1.22	98	3	-	-	345
6	10	993.9	.44	1.25	1.25	99	3	-	-	346
7	12	995.1	.38	1.08	1.08	99	3	250	60	344
8	14	996.3	.35	.96	.96	100	3	-	-	341
B 1	1-0	997.49	.22	.63	.63	98	2	-	-	312
2	2	998.3	.40	1.13	1.13	99	3	255	60	329
3	4	999.5	.48	1.36	1.36	100	3	-	-	340
4	6	000.8	.55	1.56	1.56	100	3	-	-	349
5	8	002.2	.56	1.59	1.59	100	3	260	69	352
6	10	003.6	.60	1.70	1.70	101	3	-	-	354
7	12	005.0	.56	1.59	1.59	101	3	-	-	351
8	14	006.3	.52	1.47	1.47	101	3	260	68	347
C 1	1-0	007.72	.36	1.02	1.02	100	3	-	-	331
2	2	008.	.35	1.55	1.55	101	3	260	68	340
3	4	010.18	.60	1.70	1.70	102	3	260	68	345
4	6	011.61	.75	2.12	2.12	102	4	260	68	348
5	8	013.155	.75	2.12	2.12	102	4	260	68	351

~~copy~~

Run

PARTICULATE FIELD DATA

Company/Location CHATHAM BRICK

AND TILE CO.

Run # 2

Sampling Location: WASTE HEAT STACK

Date 7-18-79 Test Participants FJP, JTN

Bar. Press., in. Hg 29.77 Meter Box # N-4

Static Press., in. H₂O 1.15 ΔH@ 1.87

Ambient Temp, °F 95 C Factor 1.09

Est. Moisture, % 6 Temp. Device T/C 0004

Sample Box # 4 @ Heat Setting 5

Probe # 4' @ Heat Setting 5

Nozzle # 505 with Dia., inches .247

Pitot Leak Tests: Before ☒ After ☐

Sampling Train Leak Test (from nozzle)

Before @ ≥ 15 in. Hg = .00 cfm

After @ 10 in. Hg = .00 cfm

Avg. Ap .65 at ΔH of 1.84

Start: 11:15

Finish: 13:12

K = 2.833

Filter # 3945 Tare Wt. .4625

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A1	0	043.427	.28	.79	.79	105	3	300	85	335
2	2	044.4	.35	1.01	1.01	105	3	280	80	336
3	4	045.6	.55	1.56	1.56	105	10	270	65	343
4	6	046.8	.55	1.56	1.56	106	10	260	60	343
5	8	048.1	.70	1.98	1.98	106	10	260	60	344
6	10	052.3	.76	2.16	2.16	108	5	250	60	345
7	12	053.9	.65	1.84	1.84	108	5	251	61	347
8	14	055.5	.50	1.42	1.42	108	4	252	62	329
B1	1-0	056.84	.40	1.13	1.13	108	3	260	62	341
2	2	057.9	.50	1.42	1.42	109	3	260	65	346
3	4	059.3	.57	1.62	1.62	108	4	260	65	352
4	6	060.7	.68	1.93	1.93	109	4	260	65	356
5	8	062.4	.76	2.15	2.15	110	5	260	66	358
6	10	063.8	.84	2.38	2.38	110	5	255	66	356
7	12	065.6	.75	2.11	2.11	110	5	255	62	350
8	14	067.3	.56	1.59	1.59	111	4	250	65	342
C1	1-0	068.75	.34	.96	.96	110	3	250	65	331
2	2	69.8	.50	1.42	1.42	110	3	250	65	340
3	4	71.1	.55	1.56	1.56	110	3	250	65	348
4	6	72.5	.68	1.93	1.93	110	3	250	65	355
5	8	74.0	.76	2.15	2.15	110	4	250	65	356

051.9
049.2
-2.71

PARTICULATE FIELD DATA

Company/Location CHATHAM BR. K

AND TILE CO. #2 KILN

Sampling Location: WASTE HEAT STACK

Date 7-19-79 Test Participants FSP, JTN

Bar. Press., in. Hg 30.00 Meter Box # N-4

Static Press., in. H₂O 1.15 ΔH @ 1.87

Ambient Temp, °F 85 C Factor 1.07

Est. Moisture, % 6 Temp. Device T/C 0004

Sample Box # 1 @ Heat Setting 5

Probe # 4 @ Heat Setting 5

Nozzle # 505 with Dia., inches .247

Pitot Leak Tests: Before ☒ After ☒

Sampling Train Leak Test (from nozzle)

Before @ ≥ 15 in. Hg = 0.00 cfm

After @ 4.5 in. Hg = 0.00 cfm

Avg. Δp .65 at ΔH of 1.84

Run # 3

Start: 10:28

Finish: 12:40

Filter # 3944

Tare Wt. 46.8

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A 1	0	100.803	0.18	0.51	0.51	84	1.0	250	65	295
2	2	100.91	0.28	0.78	0.78	84	2.0	250	65	305
3	4	101.95	0.40	1.12	1.12	85	3.0	250	65	317
4	6	103.04	0.35	0.98	0.98	85	2.0	250	65	325
5	8	104.21	0.45	1.28	1.28	86	2.0	250	65	331
6	10	105.34	0.45	1.28	1.28	90	2.0	250	65	329
7	12	106.58	0.43	1.21	1.21	90	2.5	250	65	328
8	14	107.77	0.40	1.12	1.12	90	2.5	250	65	324
B 1	1-0	108.905	0.24	0.68	0.68	91	2.0	250	65	301
2	2	109.83	0.40	1.12	1.12	91	2.0	250	65	314
3	4	110.95	0.50	1.40	1.40	91	2.5	250	65	325
4	6	112.24	0.55	1.55	1.55	91	2.5	250	65	331
5	8	113.59	0.60	1.70	1.70	92	3.0	250	65	333
6	10	115.01	0.65	1.81	1.81	93	3.0	250	65	329
7	12	116.47	0.55	1.55	1.55	94	3.0	250	65	327
8	14	117.84	0.55	1.55	1.55	94	3.0	250	65	326
C 1	1-0	119.213	0.40	1.12	1.12	94	2.0	250	65	312
2	2	120.34	0.50	1.40	1.40	94	2.5	250	65	318
3	4	121.64	0.60	1.70	1.70	95	3.0	250	65	324
4	6	123.04	0.65	1.81	1.81	95	3.0	250	65	330
5	8	124.51	0.75	2.10	2.10	95	4.0	250	65	333

STOPPED BECAUSE OF TROUBLE, B-SIDE
BOX NOT HEATING B-SIDE

PARTICULATE SAMPLING CLEANUP SHEET

Plant Name CHATHAM BRICK
 Sampling Location A-Side Waste Heat Stack
 Reagent Box # 0210 Date Analyzed 7/25/79

Date of Test 7/18 7/18
 Test Number 1 2 3

Moisture Collected:

Impinger water volume	<u>262</u>	<u>264</u>	<u>264</u>
Tared volume	<u>200</u>	<u>200</u>	<u>200</u>
Captured water	<u>62</u> mls	<u>64</u> mls	<u>64</u> mls
Silica Gel weight	<u>240.0</u>	<u>240.5</u>	<u>238.5</u>
Tared weight	<u>225.0</u>	<u>225.0</u>	<u>225.0</u>
Adsorbed water	<u>15.0</u> gms	<u>15.5</u> gms	<u>13.5</u> gms
TOTAL MOISTURE CATCH	<u>77.0</u> mls	<u>79.5</u> mls	<u>77.5</u> mls

Front Half Analysis: (Nozzle, probe, cyclone, filter front half)

Filter & Particulate	<u>515.1</u>	<u>498.7</u>	<u>520.5</u>
Filter Tare weight	<u>471.2</u>	<u>462.5</u>	<u>461.8</u>
Filter Particulate	<u>-</u>	<u>-</u>	<u>-</u>
Rinsings or Dry Wt.	<u>-</u>	<u>-</u>	<u>-</u>
Particulate catch	<u>43.9</u> mgms	<u>36.2</u> mgms	<u>58.7</u> mgms
Acetone blank	<u>0.7</u>	<u>0.8</u>	<u>0.9</u>
TOTAL FRONT CATCH	<u>43.2</u> mgms	<u>35.4</u> mgms	<u>57.8</u> mgms

Back Half Analysis: (Impingers, filter back half)

Extractables weight	<u>-</u>	<u>-</u>	<u>-</u>
Boil Down weight	<u>-</u>	<u>-</u>	<u>-</u>
Impingers' Catch	<u>-</u> mgms	<u>-</u> mgms	<u>-</u> mgms
Water blank	<u>-</u>	<u>-</u>	<u>-</u>
TOTAL BACK CATCH	<u>-</u> mgms	<u>-</u> mgms	<u>-</u> mgms
TOTAL TRAIN CATCH	<u>-</u> mgms	<u>-</u> mgms	<u>-</u> mgms

Blank Calculations:

Blank Residue	<u>1.4</u>	Water	<u>-</u>
Blank Volume	<u>200</u>		
Concentration	<u>.007</u> mg/mls		
Volume Used	<u>100</u> mls		
# <u>1</u> Blank Weight	<u>0.7</u> mgms		
Volume Used	<u>110</u> mls		
# <u>2</u> Blank Weight	<u>0.8</u> mgms		
Volume Used	<u>125</u> mls		
# <u>3</u> Blank Weight	<u>0.9</u> mgms		

Analysis Method: (Zero & Span Balance mg Initials)
EPA-5

Description of Sample:
light catch, black particulate

Remarks:
-
-
-

CUSTODY SHEET FOR REAGENT BOX # 0210

Date of Makeup 6/22/79 Individual Water Tare Volume 200 mls
 Initials msj Individual Silica Gel Tare Weight 225 gms
 Locked? ✓

Plant Name CHATHAM BRICKSampling Location A-SIDE Waste Heat Stack

Box/Test Number	Date Used	Initials	Locked?	Date Cleanup	S. Gel Spent?	Initials	Locked?
<u>1</u>	<u>7-18</u>	<u>JNS</u>	<u>✓</u>	<u>7-18</u>	<u>1/2</u>	<u>FJP</u>	<u>✓</u>
<u>2</u>	<u>"</u>	<u>"</u>	<u>✓</u>	<u>"</u>	<u>1/2</u>	<u>FJP</u>	<u>✓</u>
<u>3</u>	<u>"</u>	<u>"</u>	<u>✓</u>	<u>"</u>	<u>1/2</u>	<u>FJP</u>	<u>✓</u>

Date Initials Locked?
 Transferred to Lab 7-20 FJP ✓
 Received in Lab 7-20 msj ✓

Zero & Span Balance

Initials msjSampling Method: Method 5

Filter #	Tare Weight (mgms)	Used on Test
----------	--------------------	--------------

<u>3947</u>	<u>.4712</u>	<u>1</u>
<u>3944</u>	<u>.4618</u>	<u>3</u>
<u>3945</u>	<u>.4625</u>	<u>2</u>

ENTROPY
 ENVIRONMENTALISTS, INC.

SPECIALISTS IN
 SOURCE
 SAMPLING

APPENDIX B-2

PRELIMINARY FIELD DATA

Stack Geometry

Plant Name CHATHAM BRICK & TILE CO

Plant Location SANFORD, N.C.

Sampling Location DRIER OUTLET STACK

Date(s) 7/17 - 19/79

A. Dist. from inside of far wall to outside of near wall: 40 inches

B. Wall thickness: neg. inches


Inside diameter of stack (A-B): — inches

Stack Area: 1080 square inches

Comments:

4 ports / 9 points per port

Sketch of stack cross section showing sampling ports.



Sketch of stack dimensions and location of sampling ports.

Point	% of Diameter	Distance from inside wall	Distance from outside of port
1	1/18	2 1/4	Δ
2	3/18	6 1/2	
3	5/18	11	
4	7/18	15	
5	9/18	20	
6	11/18	24 1/2	
7	13/18	28 3/4	SAME
8	15/18	32 1/4	
9	17/18	37 3/4	

ENTROPY
ENVIRONMENTALISTS, INC.

SPECIALISTS IN
SOURCE
SAMPLING

PARTICULATE FIELD DATA

Company/Location Chatham, Brick
Samuel, N.C.

Run # 4
Start: 09:20
Finish: 10:43

Sampling Location: Dry 2 Outlet Shed
Date 7/18 Test Participants CE, CC

Bar. Press., in. Hg 29.77 Meter Box # N-3

Static Press., in. H₂O .201 ΔH₀ 1.85

Ambient Temp, °F 81 C Factor 1.00

Filter # 3814 Tare Wt. 4615

Est. Moisture, % 7.0 Temp. Device 71C-1

Sample Box # Red @ Heat Setting H
Probe # S-1 @ Heat Setting 5
Nozzle # 506 with Dia., inches .252
Pitot Leak Tests: Before ☒ After ☐
Sampling Train Leak Test (from nozzle)
Before @ ≥ 15 in. Hg = 0.000 cfm
After @ 7 in. Hg = 0.000 cfm
Avg. Δp .47 at ΔH of 1.84

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A-1	0	269.894	.23	.91	.91	87	5	250	75	109
2	2	271.28	.42	1.65	1.65	88	5	250	75	124
3	4	272.72	.45	1.78	1.78	89	5	250	73	125
4	6	274.18	.48	1.90	1.90	90	5	250	70	125
5	8	275.70	.52	2.0	2.0	90	5	250	70	125
6	10	277.29	.68	2.68	2.68	91	6	250	70	125
7	12	279.05	.65	2.55	2.55	91	7	250	70	126
8	14	280.83	.62	2.45	2.45	93	7	250	70	126
9	16	282.59	.62	2.45	2.45	94	7	250	70	126
0-1	18/10	284.39	.29	1.06	1.06	95	4	245	70	123
2	20	285.69	.42	1.65	1.65	95	5	245	73	126
3	22	286.96	.50	1.98	1.98	95	6	244	75	127
4	24	288.47	.50	1.78	1.98	95	6	240	75	126
5	26	290.02	.51	2.0	2.0	95	6	240	75	126
6	28	291.60	.55	2.15	2.15	95	6	240	75	123
7	30	293.24	.57	2.21	2.21	95	6	240	75	123
8	32	294.90	.60	2.35	2.35	95	6	240	75	123
9	34	296.60	.65	2.53	2.53	95	7	240	75	123
0-1	18/10	298.43	.37	1.30	1.30	95	5	238	73	117
2	20	299.24	.38	1.42	1.42	95	5	235	73	121
3	22	300.99	.35	1.40	1.40	95	5	235	73	123

PARTICULATE FIELD DATA

Company Location Chatham Brick
Smyrna, N.C.

Run # 5

Sampling Location: Days Outlet Steel

Date 7/18 Test Participants CW, CG

Bar. Press., in. Hg 22.77 Meter Box # W-3

Static Press., in. H₂O 2.17 ΔH @ 1.85

Ambient Temp, °F 92 C Factor 1.05

Est. Moisture, % 7 Temp. Device I/C-1

Sample Box # Pool @ Heat Setting 5

Probe # 5-1 @ Heat Setting 5

Nozzle # 506 with Dia., inches .252

Pitot Leak Tests: Before ☒ After ☒

Sampling Train Leak Test (from nozzle)

Before @ ≥ 15 in. Hg = 0.005 cfm

After @ 6 in. Hg = 0.001 cfm

Avg. Δp .46 at ΔH of 1.84

Start: 11:19

Finish: 12:57

Filter # 3848 Tare Wt. 1.915

.4719

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (ΔH) in. H ₂ O		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A-1	0	323.698	.24	.96	.96	96	3	235	75	110
2	2	324.87	.38	1.52	1.52	97	4	235	75	120
3	4	325.601	.43	1.72	1.72	97	4	235	75	125
4	6	327.37	.57	2.20	2.20	97	5	235	73	126
5	8	328.98	.57	2.20	2.20	98	5	235	70	126
6	10	330.66	.60	2.40	2.40	98	5	235	70	125
7	12	332.37	.57	2.20	2.20	99	6	235	70	125
8	14	334.07	.57	2.20	2.20	99	6	235	70	124
9	16	335.70	.45	1.80	1.80	99	5	240	70	110
B-1	18/0	337.23	.31	1.25	1.25	99	5	240	70	115
2	2	338.48	.39	1.55	1.55	99	5	240	70	129
3	4	339.83	.46	1.85	1.85	99	5	240	70	127
4	6	341.30	.46	1.85	1.85	99	5	240	70	127
5	8	342.80	.49	1.98	1.98	99	5	240	70	127
6	10	344.36	.55	2.20	2.20	100	5	240	70	127
7	12	346.00	.53	2.11	2.11	100	5	241	70	127
8	14	347.67	.58	2.30	2.30	100	5	243	70	124
9	16	349.36	.60	2.40	2.40	100	5	243	70	124
C-1	18/0	351.16	.32	1.21	1.21	100	4	245	70	109
2	2	352.30	.39	1.55	1.55	100	5	243	70	121
3	4	353.63	.35	1.40	1.40	100	5	240	70	125

PARTICULATE FIELD DATA

Company/Location Chatham Brick
Spartan, NC

Run # 6

Sample Box # Red @ Heat Setting 5
Probe # 5-1 @ Heat Setting 5

Sampling Location: Days Outlet Steel
Date 7/18 Test Participants CW, LG

Nozzle # 506 with Dia., inches 2.52
Pitot Leak Tests: Before ☒ After ☒

Bar. Press., in. Hg. 29.7 Meter Box # 1153

Sampling Train Leak Test (from nozzle)

Static Press., in. H₂O 2.27 ΔH @ 1.85

Before @ ≥ 15 in. Hg = 0.005 cfm 0.002

Ambient Temp, °F 80 C Factor 1.05

After @ 4 in. Hg = 0.003 cfm

Est. Moisture, % 7 Temp. Device TK-1

Avg. Δp .47 at ΔH of 1.84

Point	Clock Time	Dry Gas Meter, Cu. Ft.	Pitot Manometer (Δp) in. H ₂ O	Orifice Manometer (ΔH)		Average Meter Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp. °F	Impinger Temp. °F	Stack Temp. °F
				Desired	Actual					
A-1	0	377.540	.25	.98	.98	86	2	215	70	112
2	2	378.66	.40	1.56	1.56	86	2	217	70	116
3	4	380.04	.52	2.0	2.0	87	2	220	70	117
4	6	381.66	.55	2.15	2.15	89	3	220	68	117
5	8	383.31	.57	2.20	2.20	89	4	220	66	116
6	10	385.00	.62	2.40	2.40	90	4	220	65	116
7	12	386.71	.52	2.0	2.0	90	4	222	64	116
8	14	388.32	.52	2.0	2.0	90	4	222	64	116
9	16	389.92	.42	1.65	1.65	90	4	222	64	116
B-1	18/0	391.47	.32	1.27	1.27	90	3	220	65	107
2	2	392.62	.40	1.58	1.58	90	3	220	67	115
3	4	393.98	.43	1.69	1.69	90	4	220	66	119
4	6	395.41	.45	1.78	1.78	90	4	220	65	119
5	8	396.88	.57	2.20	2.20	90	4	220	65	119
6	10	398.53	.63	2.45	2.45	90	4	220	65	119
7	12	400.26	.68	2.65	2.65	90	4	220	65	118
8	14	402.04	.68	2.65	2.65	91	4	220	66	118
9	16	403.84	.50	1.95	1.95	91	4	220	66	118
C-10	18/0	405.42	.30	1.18	1.18	92	3	220	66	104
2	2	406.64	.32	1.27	1.27	92	3	220	66	112
3	4	407.90	.36	1.42	1.42	92	3	220	66	115

PARTICULATE SAMPLING CLEANUP SHEET

Plant Name CHATHAM BRICK
 Sampling Location B-Side Dyer Outlet Stack
 Reagent Box # 0203 Date Analyzed 7/25/79

Date of Test 7/19
 Test Number 4

Moisture Collected:
 Impinger water volume 234
 Tared volume 200
 Captured water 34 mls
 Silica Gel weight 240.5
 Tared weight 225.0
 Adsorbed water 15.5 gms
 TOTAL MOISTURE CATCH 49.5 mls

Front Half Analysis: (Nozzle, probe, cyclone, filter front half)
 Filter & Particulate 482.0
 Filter Tare weight 461.5
 Filter Particulate -
 Rinsings or Dry Wt. -
 Particulate catch 20.5 mgms
 Acetone blank 1.4
 TOTAL FRONT CATCH 19.1 mgms

Back Half Analysis: (Impingers, filter back half)
 Extractables weight -
 Boil Down weight -
 Impingers' Catch - mgms
 Water blank - mgms
 TOTAL BACK CATCH - mgms
 TOTAL TRAIN CATCH - mgms

Blank Calculations:
 Acetone 1.4
 Water 200
 Concentration .007 mg/mls
 Volume Used 200 mls
 # 4 Blank Weight 1.4 mgms
 Volume Used 175 mls
 # 5 Blank Weight 1.2 mgms
 Volume Used 100 mls
 # 6 Blank Weight 0.7 mgms

Analysis Method: (Zero & Span Balance mg Initials)
EPA-5

Description of Sample:
light catch, white particulate
 Remarks:

CUSTODY SHEET FOR REAGENT BOX # 0203Date of Makeup 6/22/79 Individual Water Tare Volume 200 mlsInitials meq Individual Silica Gel Tare Weight 225 gmsLocked? ✓Plant Name Chatham BrickSampling Location B-Side Dryer Outlet Stack

Box/Test Number	Date Used	Initials	Locked?	Date Cleanup	S. Gel Spent?	Initials	Locked?
<u>0203/4</u>	<u>7/18/79</u>	<u>C.G.</u>	<u>✓</u>	<u>7/20</u>	<u>20%</u>	<u>CW</u>	<u>✓</u>
<u>25</u>	<u>7/18</u>	<u>C.G.</u>	<u>✓</u>	<u>7/20</u>	<u>20%</u>	<u>CW</u>	<u>✓</u>
<u>6</u>	<u>7/19</u>	<u>CW</u>	<u>✓</u>	<u>7/20</u>	<u>70%</u>	<u>CW</u>	<u>✓</u>

Transferred to Lab 7/20 CW ✓
Received in Lab 7/20 meq ✓

Sampling Method: EPA-5Remarks:
34

Zero & Span Balance

Initials meq

Filter #	Tare Weight (mgs)	Used on Test
----------	-------------------	--------------

<u>3814</u>	<u>.4615</u>	<u>4</u>
-------------	--------------	----------

<u>3848</u>	<u>.4715</u>	<u>5</u>
-------------	--------------	----------

<u>3946</u>	<u>.4679</u>	<u>6</u>
-------------	--------------	----------

ENTROPY
ENVIRONMENTALISTS, INC.

SPECIALISTS IN
SOURCE
SAMPLING

APPENDIX C

TEST PARTICIPANTS

FRANK J. PHOENIX

PROJECT DIRECTOR

CHRIS M. WRENN

SAMPLING TEAM LEADER

W. CHRIS GOODALL

ENGINEERING TECHNICIAN

JOHN T. NASH

ENGINEERING TECHNICIAN

DONALD J. DEITZ

ENGINEERING TECHNICIAN

APPENDIX D

APPENDIX E

CALIBRATIONS

GENERAL

All measuring equipment Entropy uses is initially calibrated before use. Equipment which can change calibration is both checked upon return from each field use and is also periodically recalibrated in full. When an instrument is found out of calibration, it is so noted in the report and appropriate adjustments are made to the final results. The equipment is then repaired and recalibrated or retired as needed. Specific equipment is handled as follows:

PITOT TUBE

All pitot tubes used by Entropy, whether separate or attached to a sampling probe, are constructed in-house or by Nutech Corporation. Prior to their initial usage, they are calibrated using EPA geometry standards. In general, if a type "S" pitot tube is assembled correctly, and positioned properly in relation to the probe nozzle, it will have an average C_p of 0.84. As long as it is not damaged, it should not change its calibration. The recalibration schedule for pitot tubes is related to the physical condition and usage of the pitot tube, not a fixed time schedule. Each pitot tube is inspected upon return to the laboratory from each field use.

DRY GAS METER AND ORIFICE METER

All Entropy meter boxes are calibrated upon purchase and at least once every six months against a secondary test meter (one calibrated against a wet test meter) according to their usage history. Basic procedures are outlined in the EPA Publication No. APTD-0576. The only differences are in the choice of flow rates used and the volumes metered at each flow rate. After each field use, quick checks are performed to insure all changes of less than 5%. These checks compare the orifice against the dry gas meter. If greater than 5% changes occur, recalibration and repair are instituted.

NOZZLES

Each nozzle is calibrated upon purchase, and thereafter whenever it becomes apparent that the nozzle has become damaged. Each nozzle is inspected upon return to laboratory from each field use. The diameter is measured on four different axes, with the high and low readings differing by no more than 0.004 inches as a tolerance.

TEMPERATURE MEASURING INSTRUMENTS

After each field use, the thermocouples or thermometers are calibrated against an ASTM precision mercury-in-glass thermometer across a wide range of temperatures. If the initial

reading is not within $\pm 1.5\%$ of the absolute temperature reading of the standard thermometer, the instrument is adjusted until it is in the acceptable range.

MAGNEHELIC GAUGES

After each field use, each magnehelic gauge is calibrated against an inclined manometer at three different settings (low, medium, high) over the range of the individual gauges. If the readings differ more than $\pm 5\%$ from the manometer readings, the magnehelics are recalibrated.

BAROMETER

After each field use, each barometer is checked against a mercury barometer.

Date 7-6-79 Box N-3 P_B 29.82 Initials MC

ORIFICE SETTING	TEST METER VOLUME	ROOM TEMP °F	TIME MINUTES	ΔH	BOX METER VOLUME	BOX METER TEMP	γ
0.3	2	72°	6.48	1.74	2.0150	84°	1.014
0.5	3	74°	7.43	1.73	3.014	76°	.996
0.7	3	74°	6.4	1.80	3.017	78°	1.000
1.0	3	72°	5.48	1.86	3.020	84°	.997
1.5	5	74°	7.41	1.86	5.02	78°	.999
2.0	5	74°	6.43	1.85	5.04	83°	.997
4.0	5	74°	4.68	1.95	5.074	84°	.992
6.0	5	72°	3.87	1.98	5.028	84°	1.002

$$\Delta H = \frac{(0.0317) \Delta H}{P_B (T_{Box} + 460)} \left(\frac{(T_{Room} + 460)^2}{V_{Test Meter}} \right)$$

ΔH 21.85 $\gamma = 1.000$

$$V_{Test} (P_B) (T_{Box} + 460)$$

$$\gamma = \frac{V_{Box} (P_B + \frac{\Delta H}{13.6}) (T_{Room} + 460)}{V_{Box} (P_B + 460)}$$

Date 7-3-79 Box N-4 P_B 29.54 Initials MH

ORIFICE SETTING	TEST METER VOLUME	ROOM TEMP °F	TIME MINUTES	ΔH	BOX METER VOLUME	BOX METER TEMP	γ
0.3	2	73°	6.60	1.85	2.008	78°	1.005
0.5	3	74°	7.70	1.87	3.030	80°	1.000
0.7	3	73°	6.35	1.79	2.962	74°	1.013
1.0	3	74°	5.40	1.86	3.029	82°	1.003
1.5	5	74°	7.53	1.92	5.043	82°	1.003
2.0	5	73°	6.52	1.93	5.067	76°	0.987
4.0	5	74°	4.55	1.87	5.002	83°	1.006
6.0	5	74°	3.73	1.88	4.984	84°	1.007

$$\Delta H\theta = \frac{(0.0317) \Delta H}{P_B (T_{Box} + 460)} \left(\frac{(T_{Room} + 460)^0}{V_{Test Meter}} \right)^2 \quad \Delta H\theta = 1.87$$

$$\gamma = 1.003$$

$$\gamma = \frac{V_{Test} (P_B) (T_{Box} + 460)}{V_{Box} (P_B + \frac{\Delta H}{13.6}) (T_{Room} + 460)}$$

NOZZLE CALIBRATION DATA

NOZZLE # 505

-----DIAMETER, in.-----

<u>DATE</u>	<u>INITIALS</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>AVERAGE</u>
7-15-77	WN	.250	.247	.250	.248	.249
12-13-78	JLE	.252	.252	.252	.250	.252
3-26-79	NH	.251	.250	.254	.252	.252
6/29/79	C.G.	.246	.249	.247	.247	.247

NOZZLE CALIBRATION DATA

NOZZLE # 506

-----DIAMETER, in.-----						
<u>DATE</u>	<u>INITIALS</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>AVERAGE</u>
7-15-77	WN	.254	.254	.254	.254	.254
12-13-78	JLE	.253	.252	.255	.255	.254
3-26-79	MH	.253	.250	.253	.252	.252