

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.


AP42 Section:	11.3
Reference:	37
Title:	<i>Source Emissions Testing, Marseilles Brick, Marseilles, Illinois, Fugro Midwest, Inc., St. Ann, MO, July 1, 1994.</i>



FUGRO MIDWEST, INC.

**SOURCE EMISSIONS TESTING
MARSEILLES BRICK
MARSEILLES, ILLINOIS**

MARSEILLES BRICK VENTURE, LTD.




FUGRO MIDWEST, INC.



**SOURCE EMISSIONS TESTING
MARSEILLES BRICK
MARSEILLES, ILLINOIS**

MARSEILLES BRICK VENTURE, LTD.



FUGRO MIDWEST, INC.



July 1, 1994
Report 0894-8885

9921 St. Charles Rock Road
St. Ann (St. Louis), Missouri 63074
Tel: (314) 428-8880
Fax: (314) 428-8719

Mr. Charles Laird
Marseilles Brick Venture, Ltd.
P.O. Box 306
1401 Broadway
Marseilles, Illinois 61341

**Source Emissions Testing
Marseilles Brick
Marseilles, Illinois**

Dear Mr. Laird:

Fugro Midwest, Inc. (Fugro) is pleased to provide you with this report on the results of the air emissions tests conducted at the Marseilles Brick facility located in Marseilles, Illinois. Testing was conducted on May 10, 1994 at the outlet of the number one dryer, and on May 11, 1994 at the outlet of the number two dryer and kiln.

This report describes the testing methodologies and summarizes the results of the emissions testing.

Fugro appreciates this opportunity to provide service to Marseilles Brick, and we look forward to working with you on future projects. Please call us if you have any questions concerning this report.

Sincerely,

FUGRO MIDWEST, INC.

Anna C. Nabb
Air Quality Scientist

Christopher N. Dawdy
Vice President
Manager, Air Quality Group

ACN:CND:ab

CONTENTS

	<u>Page</u>
1.0 INTRODUCTION	1
2.0 SUMMARY OF TEST RESULTS	2
3.0 PURPOSE OF TESTING	2
4.0 ACTIVITIES DURING THE TESTING	2
5.0 TEST METHODS AND PROCEDURES	2
5.1 Field Procedures and Equipment (EPA Method 5 and 6)	4
5.1.1 Sampling Equipment and Procedures	4
5.1.2 Sample Recovery	6
5.1.3 Analytical Procedures	7
5.2 Oxygen (O ₂) and Carbon Dioxide (CO ₂) Sampling	7
5.3 Oxides of Nitrogen Sampling - EPA Method 7E	8
5.4 Sampling Equipment and Procedures for Carbon Monoxide (CO) Sampling ..	10
5.5 Sampling Equipment and Procedures for Total Hydrocarbon (THC) Determination (EPA Method 25A)	10
6.0 EMISSION RESULTS	12



TABLES

Table

Emissions Summary	2-1
Particulate Matter Emission Summary — Kiln Stack	6-1
Sulfur Trioxide Emission Summary — Kiln Stack	6-2
Sulfur Dioxide Emission Summary — Kiln Stack	6-3
Particulate Matter Emission Summary — Dryer Stack #1	6-4
Sulfur Trioxide Emission Summary — Dryer Stack #1	6-5
Sulfur Dioxide Emission Summary — Dryer Stack #1	6-6
Particulate Matter Emission Summary — Dryer Stack #2	6-7
Sulfur Trioxide Emission Summary — Dryer Stack #2	6-8
Sulfur Dioxide Emission Summary — Dryer Stack #2	6-9

FIGURES

Figure

Particulate SO ₂ /SO ₃ Sampling Train	5-1
Nitrogen Oxide (NO _x) Sampling System	5-2
Carbon Monoxide (CO) Sampling System	5-3
Total Hydrocarbon (THC) Sampling Train 1	5-4

APPENDICES

APPENDIX A: PROCESS OPERATIONS DATA
APPENDIX B: RESUMES OF TEST CREW
APPENDIX C: LABORATORY ANALYSIS
APPENDIX D: FIELD DATA SHEETS
APPENDIX E: CALIBRATION DATA
APPENDIX F: STRIP CHART RECORDINGS
APPENDIX G: EXAMPLE CALCULATIONS

1.0 INTRODUCTION

Fugro Midwest, Inc. (Fugro) was contracted by Marseilles Brick Venture, Ltd. to conduct source emissions testing at their facility located in Marseilles, Illinois. Marseilles Brick has two independent Dryer tunnels approximately 200 ft. in length that hold 14 kiln cars each. Waste heat from the cooling section of the kiln is supplied to each dryer by a fan through a duct/plenum system. The heat to each dryer is boosted to 325°F by two natural gas burners, 442M BTU/hr. and 432M BTU/hr. respectively, located in the air supply duct. Moist warm air is exhausted to the atmosphere by a fan at the entrance end of each dryer tunnel. Dryer #1 and Dryer #2 are independent of each other except for the common waste heat supply from the kiln.

The tunnel kiln used by Marseilles Brick to fire its brick is a 498 ft. metal jacketed natural gas fired kiln designed by Ceric. The kiln holds a total of 36 kiln cars with 20 in the pre-heat and furnace section and 16 in the cooling section. The pre-heat section is divided into 6 zones with a total of 32 gas fired side burners. The furnace section is divided into 7 zones with 19 natural gas fired top burners in each zone for a total of 133 top fired burners. The cooling section has a rapid cool zone (2 car lengths long) where the brick is cooled from 1930°F to approximately 1300°F by injecting ambient air directly on the brick. The balance of the cooling section is used to cool the brick to approximately 100°F before exiting the kiln.

Waste heat is removed from the cooling section close to the exit to supply heated air to the dryers. The kiln exhaust fan is located near the entrance end of the pre-heat and exhausts the products of combustion to the atmosphere through a 40 ft high brick chimney.

Source emissions testing was conducted to determine mass emission rates of particulate, sulfur trioxide, sulfur dioxide, carbon monoxide, nitrogen oxide, and volatile organics. Three 1-hour test runs were conducted on each of the two dryer units and the kiln while firing bricks with an 80% shale/20% fireclay composition.

The emissions testing was conducted following the procedures outlined in 40 CFR Part 60, Appendix A, using USEPA Methods 1, 2, 3, 4, 5, and 6 to determine sampling point locations, volumetric flow rates, molecular weight, moisture concentrations, total particulate matter, and sulfur dioxide/sulfur trioxide, respectively. Additionally, USEPA Method 7E was used to determine nitrogen oxide (NO_x) emissions, USEPA Method 10 was used to determine carbon monoxide emissions, and USEPA Method 25A was used to determine total volatile organic emissions.

This report presents the results of the emissions testing conducted at the Marseilles Brick facility. Copies of the field data sheets, laboratory analysis, equipment calibration records, calibration gas certifications, and example calculations are included in the appendices of this report.

2.0 SUMMARY OF TEST RESULTS

Fugro conducted source emissions testing at the Marseilles Brick facility located in Marseilles, Illinois, on May 10 and May 11, 1994 to quantify emission rates from three processes. An air emissions summary is presented in Table 2-1. The emissions were determined by averaging the results of three 1-hour test runs conducted on the exhaust of each unit. The testing was conducted during the use of 80% shale/20% clay mixture. Appendix A contains related process operations data.

3.0 PURPOSE OF TESTING

Fugro conducted air emissions testing at the facility located in Marseilles, Illinois for the purpose of determining mass emission rates of particulate matter, sulfur trioxide, sulfur dioxide, carbon monoxide, nitrogen oxide and volatile organics. These emissions rates will be used to evaluate the potential emissions associated with the brick manufacturing operation. The testing was conducted as required by 35 Ill. Adm. Code 201.282(a) in association with Permit #89010009.

4.0 ACTIVITIES DURING THE TESTING

Messrs. Robert Folle, Todd Staley, and Dan Cusac of Fugro conducted the emissions testing. Mr. Charles Laird of Marseilles Brick scheduled the testing and coordinated the testing effort. Resumes of the test crew are presented in Appendix B.

5.0 TEST METHODS AND PROCEDURES

Fugro utilized USEPA Test Methods 1, 2, 3, 4, 5, and 6 as outlined in 40 CFR Part 60, Appendix A, to determine traverse point locations, stack gas velocity, volumetric flow rates, molecular weight, moisture, total particulate matter emissions and sulfur emissions, respectively. Additionally, Methods 7E, 10, and 25A when used to determine nitrogen oxide, carbon monoxide, and total hydrocarbon emissions.

Table 2-1
Emissions Summary
Marseilles Brick Venture Ltd.
Marseilles, Illinois

Source	Run	Parameter						
			Particulate	SO ₂	SO _x	NO _x	CO	THC
Dryer #1	1	gr/dscf	0.0074	0	0.0005	-	-	-
		lb/hr.	0.9765	0	0.0632	1.29	0.53	0.39
		ppm	-	ND	0.35	11.9	8.0	3.7
	2	gr/dscf	0.0023	0	0.0001	-	-	-
		lb/hr.	0.3741	0	0.0216	0.47	1.52	0.78
		ppm	-	ND	0.10	3.5	18.7	6.1
	3	gr/dscf	0.0041	0	0.0004	-	-	-
		lb/hr	0.6398	0	0.0625	0.26	1.86	0.88
		ppm	-	ND	0.30	2.0	24.0	7.3
	Avg.	gr/dscf	0.0046	0	0.0003	-	-	-
lb/hr.		0.6635	0	0.0491	0.67	1.30	0.68	
ppm		-	ND	0.25	5.8	16.9	5.7	
Dryer #2	1	gr/dscf	0.0057	0	0	-	-	-
		lb/hr.	0.7770	0	0	0.17	1.04	0.33
		ppm	-	ND	ND	1.5	14.9	3
	2	gr/dscf	0.0008	0	0	-	-	-
		lb/hr.	0.1199	0	0	0.29	1.50	0.32
		ppm	-	ND	ND	2.2	19.0	2.6
	3	gr/dscf	0.0008	0	0.0004	-	-	-
		lb/hr.	0.1206	0	0.0529	0.35	1.43	0.55
		ppm	-	ND	0.27	3.0	20.0	4.9
	Avg.	gr/dscf	0.0024	0	0.0001	-	-	-
lb/hr.		0.3391	0	0.0176	0.27	1.32	0.40	
ppm		-	ND	0.09	2.2	18.0	3.5	
Kiln	1	gr/dscf	0.0376	0.3800	0.0249	-	-	-
		lb/hr.	4.2421	42.9170	2.3903	2.36	6.98	0.80
		ppm	-	338.1	18.6	25.9	125.8	9.2
	2	gr/dscf	0.0381	0.3496	0.0197	-	-	-
		lb/hr.	4.6234	42.3965	2.8082	2.67	7.23	0.81
		ppm	-	314.5	14.95	27.6	122.8	8.8
	3	gr/dscf	0.0347	0.3458	0.0163	-	-	-
		lb/hr.	3.8788	38.5965	1.8228	2.50	6.81	0.67
		ppm	-	310.8	12.4	28.0	125.5	7.8
	Avg.	gr/dscf	0.0368	0.3585	0.0203	-	-	-
lb/hr.		4.2481	41.3033	2.3404	2.51	7.01	0.76	
ppm		-	321.1	15.3	27.2	124.7	8.6	


5.1 Field Procedures and Equipment (EPA Method 5 and 6)

5.1.1 Sampling Equipment and Procedures

The sampling equipment consists of the following:

1. Pitot Assembly
 - a. Nozzle — Glass with a sharp, tapered leading edge.
 - b. Probe — Stainless steel sheath with a 5/8-in. OD glass liner wrapped with nichrome wire; rheostat controlled and capable of maintaining a temperature of 248 degrees F $\pm$ 25 degrees F.
 - c. Pitot — Type "S" constructed and attached to probe according to specifications outlined in the "code of Federal Regulations, Chapter I, Title 40 Part 60, Appendix A, Method 2."
 - d. Fyrite probe — Stainless steel 1/4-in. tubing attached to pitot tube in an interference-free arrangement.
 - e. Thermocouple — Type "K" attached to the pitot tube such that the tip has no contact with the metal and does not interfere with the pitot tube face openings.
2. Filter Holder — Borosilicate glass with a glass fritted filter support and silicone rubber sealing gasket.
3. Filter Heating Assembly — Controlled heating element in aluminum module attached to end of probe; capable of maintaining 248 degrees F $\pm$ 25 degrees F.
4. Impingers — Four glass impingers connected in series with glass ball joint fittings and placed in an ice bath. The first, third, and fourth impingers were of the modified Greenburg-Smith design. The second impinger was of the Greenburg-Smith design with a standard tip. Final gas exit temperature was measured to within $\pm$ 5 degrees F with a thermometer immersed in the gas stream.
5. Control Box — Module containing the vacuum gauge, leak-free pump, thermometer capable of measuring temperature to within $\pm$ 5 degrees F, dry gas meter with a minimum of 2% accuracy, valves and related equipment as required to maintain an isokinetic sampling rate and to determine sample volume.
6. Nomograph — To determine isokinetic sampling rate.

A schematic of the particulate sampling train is shown in Figure 5-1.



SOURCE: ENVIRONMENT REPORTER

FIGURE 5-1

Particulate Matter and Sulfur Dioxide Sampling Train

Prior to leaving the laboratory, glass fiber filters were numbered for identification purposes, heated for 2 hours at 250 degrees F, desiccated for 2 hours, and preweighed to the nearest 0.1 mg.

Upon arrival at the sampling site, the control box was leak-checked from the pump to the orifice at 5 to 7 in. of water.

The sampling train was prepared in the following manner: 100 ml of 80% isopropanol in the first impinger, 100 ml of 3% hydrogen peroxide water was added to each of the next two impingers. The fourth impinger was left empty and the fifth impinger contained 250 grams of silica gel.

After assembling the train with the pitot tube, as shown on the schematic, the system was leak-checked by plugging the inlet to the probe nozzle and pulling a 15-in. mercury vacuum. A leakage rate not to exceed 0.02 cfm is considered acceptable. The pitot tube system was also leak-checked at 2 to 3 in. of water, and any leaks found were corrected.

The probe nozzle size and moisture content was derived from a preliminary velocity and temperature traverse measurement. Sampling points within the duct were selected in accordance with EPA Method 1 (40 CFR 60, Appendix A). The sampling probe was attached and the heater was adjusted to provide a gas temperature of approximately 248 degrees F, +/- 25 degrees F.

The filter heating system was turned on, and ice was placed around the impingers. After a suitable warmup period, the nozzle was placed at the first traverse point with the flow adjusted to isokinetic conditions. Using calculated sampling points and sampling times, the probe was repositioned to the next traverse point, and isokinetic sampling was re-established. This was accomplished for each point along the traverse until the run was completed. Readings were taken at each traverse point and at the calculated time interval. At the conclusion of each run, the pump was turned off and the final readings were recorded. A final leak check of the sampling system was performed, as previously described at the highest vacuum encountered during the test run. A leak check of the pitot system was also repeated.

5.1.2 Sample Recovery

The volume of liquid in the first four impingers was measured and recorded on the field data sheet. The probe nozzle, and all sample-exposed surfaces were washed with reagent-grade acetone and put into a clean sample bottle marked "prefilter." A brush was used to loosen any adhering particulate matter, and subsequent washings were put into the "prefilter" container. The filter was carefully removed from the fritted teflon support and placed in its original container. Any filter material that adhered to the filter support surfaces was carefully removed and added to the filter

container. The silica gel was removed from the fifth impinger and transferred to its original container. A sample of the acetone used in washing the probe was saved as a blank for laboratory analysis. The liquid from the first four impingers was collected and labeled for shipment to the laboratory.

5.1.3 Analytical Procedures

The filter and any loose particulate matter was transferred from the filter container to a clean, tared glass weighing dish. The filter was placed in a desiccator for 24 hours and weighed to a constant weight. The original weight of the filter was deducted, and the weight gain recorded to the nearest 0.1 mg.

The "prefilter" wash and blank acetone solutions were transferred to individual clean, tared beakers, then evaporated to dryness and desiccated to a constant weight. The weight gain of the "prefilter" was adjusted for the blank and recorded to the nearest 0.1 mg. The silica gel was weighed, and the weight gain was recorded to the nearest 0.1 gram.

The impinger catch was shipped to IT Analytical of Cincinnati, Ohio, for sulfur titrations. The analytical data sheets for particulate and SO_2/SO_3 analyses are presented in Appendix C.

5.2 Oxygen (O_2) and Carbon Dioxide (CO_2) Sampling

As required by EPA Method 3 (40 CFR 60, Appendix A), oxygen and carbon dioxide samples were collected by an integrated bag system for Orsat analysis. The Orsat sampling system consists of a stainless steel probe, flexible sample line from the probe to a condenser, a small vacuum pump with a critical orifice, and a tedlar bag. The collected sample was then analyzed using an Orsat gas analyzer. Oxygen and carbon dioxide concentrations were determined in percent of stack gas and stack gas molecular weight was then calculated.

The Orsat sampling procedure consists of the following leak check and sampling techniques. Prior to sampling, the base was leak-checked to 2 to 4 in. of water. The inlet to the condenser was plugged, and a vacuum of 10 in. of Hg was created. The outlet of the pump was then plugged and the pump was turned off. The vacuum was observed for 30 seconds to determine any leakage. The vacuum must hold steady for at least 30 seconds for the leak test to be acceptable. The sample line was then purged with stack gas and the bag was connected. Sampling was conducted at an appropriate constant rate at the same traverse points and for the same length of time as the other testing parameters were tested. At the conclusion of the run, the pump was turned off and the bag sealed.

After leak-checking, the Orsat gas analyzer, an average value for each gas was determined. The gas was analyzed until two values were obtained that fell within the specified variance of the gas tested. Data were recorded on the field data sheets, and the bag was evacuated for the next sample run.

Appendix D contains copies of all field data and sample custody sheets. Equipment calibration records are presented as Appendix E.


5.3 Oxides of Nitrogen Sampling - EPA Method 7E

Nitrogen oxide (NO_x) was measured following the procedures set forth in Method 7E of 40 CFR 60, Appendix A. The NO_x analysis was performed with a TECO, Model 10AR, chemiluminescent NO_x analyzer manufactured by Thermo Environmental Instruments, Inc. The TECO 10AR blends the gas sample with O_3 in a reaction chamber. The resulting chemiluminescence is monitored through an optical filter by a high-sensitivity photomultiplier positioned at one end of the chamber. The filter/photomultiplier combination responds to light in a narrow-wave length band unique to the reaction of NO and O_3 . The output from the photomultiplier is linearly proportional to the NO concentration. To measure NO_x concentrations, the NO_x in the sample gas is converted to NO through a converter. The chemiluminescent response in the reaction chamber to the converter effluent is linearly proportional to the NO_x concentration entering the converter.

The electrical responses from the TECO 10AR were recorded on an Omega 5500 data logger. This data was digitized into 60-minute averages. The gas sample in the stack was drawn from the stack port with a Thomas Industries Model 107 diaphragm pump. The sample gas flow from the stack flowed through Teflon tubing to a glass condenser (ice bath) where the water vapor was removed. From the condenser, the gas flow was reduced by a valve before entering the pump. The gas sample was then pumped through the analyzer at a constant flow rate and pressure (Figure 5-2).

The nitrogen oxide analyzer was calibrated using a three-point calibration consisting of a zero gas, and two additional test concentrations of nitrogen oxide (NO) consisting of 86.7 parts per million (ppm) and 356 ppm of NO. The NO_x analyzer was calibrated before and after the NO_x tests. The certifications for the calibration gases used during the test are presented in Appendix E.

An initial analyzer calibration error test was performed for zero and upscale span calibrations on the analyzer to determine the difference between the gas concentrations exhibited by the gas analyzer and the known concentrations of the calibration gas, when the calibration gas is introduced directly to the analyzer's input (+/- 2% of span for each concentration is acceptable).



SOURCE: ENVIRONMENT REPORTER

FIGURE 5-2

Nitrogen Oxide (NO_x) Sampling System

A sampling system bias test was performed on the analyzer system. Zero and calibration gases were introduced to the outlet of the sampling probe, and the difference between the bias readings and the initial analyzer calibration error readings (known gas concentrations introduced directly into the analyzer's input) were recorded (bias). Bias system limits for each concentration is $\pm 5\%$ of span. Sampling was performed simultaneously. Sampling was started at the first measurement point, as determined by Method 1, after twice the system response time (time it takes for calibration gas to travel up to the probe and back down to the analyzers input) had elapsed. System response time was 2 minutes and 36 seconds. Zero and calibration drift (span) tests were performed immediately preceding and following the test run before any adjustments to the measurement system ($\pm 3\%$ of span). All test runs were found to be within the system specifications and all zero and upscale calibrations were within the sampling system bias specifications.


5.4 Sampling Equipment and Procedures for Carbon Monoxide (CO) Sampling **Carbon Monoxide (CO) Sampling — EPA Method 10.**

CO concentrations in the stack gas were monitored with a Horiba 331 CO Analyzer. This instrument utilizes gas filter correlation for CO measurement.

The gas sample was continuously drawn from the stack with a Thomas Industries Model 107 diaphragm pump. The gas flowed from the stack through Teflon tubing to a glass condenser where the majority of the water vapor was removed. From the condenser, the gas flow rate was reduced by a valve before entering the pump. The gas was then pumped through the analyzer at a constant flow rate and pressure (Figure 5-3). The CO analyzer was calibrated with known concentrations of certified N_2 for zero span and certified concentrations of CO for upscale span calibrations. The analyzer was calibrated before and after each test run. Protocol-1 calibration gas certificates are presented in Appendix E. Photocopies of the actual CO concentration readings recorded on a data logger/chart recorder are presented in Appendix F.

5.5 Sampling Equipment and Procedures for Total Hydrocarbon (THC) Determination (EPA Method 25A)

Total hydrocarbon concentrations (as propane) in the stack gas were continuously extracted and analyzed with a J.U.M. Model VE-7 heated total hydrocarbon analyzer. The analyzer utilizes a hydrogen flame ionization detector (FID) in a heated oven (190°C) to prevent the loss of high molecular weight hydrocarbons.



SOURCE: ENVIRONMENT REPORTER

FIGURE 5-3
Carbon Monoxide (CO) Sampling Train
EPA Method 10




Stack gas was continuously extracted from the source through heated teflon sample lines (250°F) connected to suitable stainless steel sampling probes. The stack gas was introduced directly into the heated total hydrocarbon analyzer at a constant flow rate and pressure. The total hydrocarbon analyzer was calibrated before and after each of the tests with known concentrations of USEPA Protocol-1 propane calibration gases for upscale span calibrations and drift checks and zero gas for zero calibrations.

The total hydrocarbon analyzer's responses (as propane) were continuously recorded on an Omega Model 5500 data logger. Figure 5-4 illustrates a schematic diagram of the total hydrocarbon sampling train. Calibration gas certifications for the USEPA Protocol-1 calibration gases are presented in Appendix E. Copies of the data logger records are presented in Appendix F.

6.0 EMISSION RESULTS

The emissions results of the testing are presented in Tables 6-1 through 6-9. Example calculations for test run number 1, conducted on the #1 dryer outlet on May 10, 1994, are presented in Appendix F.



SOURCE: ENVIRONMENT REPORTER

FIGURE 5-4

Total Hydrocarbon Sampling Train



TABLE 6-1. PARTICULATE MATTER EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, ILL.
 STACK: KILN STACK

PARTICULATE MATTER SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 11, 1994			
Starting Time (hours)	1515	1700	1840	
Ending Time (hours)	1615	1800	1943	
Net Time of Run (minutes)	60	60	60	
Number of Points	21	21	21	
Barometric Pressure (in. Hg)	29.85	29.85	29.85	
Static Pressure (in. H ₂ O)	-0.11	-0.11	-0.11	
Stack Pressure (in. Hg)	29.84	29.84	29.84	29.84
Average Delta H (in. H ₂ O)	2.4143	2.5619	2.1667	2.38
Average Delta P (in. H ₂ O)	0.2129	0.2400	0.2038	0.22
Meter Pressure (in. Hg)	30.03	30.04	30.01	30.03
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Length (in.)	41	41	41	
Stack Width (in.)	41	41	41	
Stack Cross Sectional Area (ft ²)	11.673611	11.673611	11.673611	11.67361111
Nozzle Diameter (inches)	0.370	0.370	0.370	
Nozzle Area (ft ²)	0.00074667	0.0007467	0.000746674	0.000746674
Meter Temperature (F)	88.952	95.238	94.381	92.857
Stack Temperature (F)	481.571	480.143	473.524	478.413
Ending DGM Volume (ACF)	923.715	986.317	1036.52	
Beginning DGM Volume (ACF)	872.15	935.121	991.447	
Volume of Dry Gas Sample (acft)	51.5650	51.1960	45.0730	49.2780
Dry, Std. Gas Sample Volume (dscf)	49.8247	48.926	43.099	47.2832
Condensate Collected (mL)	74.50	73.60	63.60	70.57
Moisture Concentration (%)	6.58	6.61	6.49	6.56
Carbon Dioxide Concentration (%)	1.800	1.800	1.800	1.800
Oxygen Concentration (%)	17.800	17.800	17.800	17.800
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	80.400	80.400	80.400	80.400
Molecular Weight, Dry (lb/lb-mole)	29.0000	29.0000	29.0000	29.0000
Molecular Weight, Wet (lb/lb-mole)	28.2767	28.2726	28.2856	28.2783
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.458527	0.486638	0.446180	0.463782
Avg. Velocity, Stack Gas (ft/sec)	34.7823	36.8894	33.6955	35.1224
Actual Flow Rate (acfm)	24362.113	25837.945	23600.892	24600.317
Dry, Std. Vol. Flow Rate (dscfm)	12729.777	13516.055	12449.049	12898.294
% Isokinetic	102.05	94.38	90.26	95.56
Total Filter Catch (mg)	20.90	25.10	15.80	20.60
Total Wash Catch (mg)	104.60	101.40	85.70	97.23
Total Catch (mg)	125.50	126.50	101.50	117.83
Particulate Conc. (grams/dscf)	0.0024	0.0025	0.0023	0.0024
Particulate Conc. (grains/dscf)	0.0376	0.0381	0.0347	0.0368
Particulate Concentration (lb/dscf)	5.55E-06	5.70E-06	5.19E-06	5.48E-06
Particulate Emission Rate (lb/hr)	4.2421	4.6234	3.8788	4.2481

TABLE 6-2. SULFUR TRIOXIDE EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, ILL.
 STACK: KILN STACK

SULFUR TRIOXIDE SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 11, 1994			
Starting Time (hours)	1515	1700	1840	
Ending Time (hours)	1615	1800	1943	
Net Time of Run (minutes)	60	60	60	
Number of Points	21	21	21	
Barometric Pressure (in. Hg)	29.85	29.85	29.85	
Static Pressure (in. H ₂ O)	-0.11	-0.11	-0.11	
Stack Pressure (in. Hg)	29.84	29.84	29.84	29.84
Average Delta H (in. H ₂ O)	2.4143	2.5619	2.1667	2.38
Average Delta P (in. H ₂ O)	0.2129	0.2400	0.2038	0.22
Meter Pressure (in. Hg)	30.03	30.04	30.01	30.03
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Length (in.)	41	41	41	
Stack Width (in.)	41	41	41	
Stack Cross Sectional Area (ft ²)	11.673611	11.673611	11.673611	11.67361111
Nozzle Diameter (inches)	0.370	0.370	0.370	
Nozzle Area (ft ²)	0.00074667	0.0007467	0.000746674	0.000746674
Meter Temperature (F)	88.952	95.238	94.381	92.857
Stack Temperature (F)	482.048	480.143	473.524	478.571
Ending DGM Volume (ACF)	923.715	986.317	1036.52	
Beginning DGM Volume (ACF)	872.15	935.121	991.447	
Volume of Dry Gas Sample (acf)	51.5650	51.1960	45.0730	49.2780
Dry, Std. Gas Sample Volume (dscf)	49.8247	48.926	43.099	47.2832
Condensate Collected (mL)	74.50	73.60	63.60	70.57
Moisture Concentration (%)	6.58	6.61	6.49	6.56
Carbon Dioxide Concentration (%)	1.800	1.800	1.800	1.800
Oxygen Concentration (%)	17.800	17.800	17.800	17.800
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	80.400	80.400	80.400	80.400
Molecular Weight, Dry (lb/lb-mole)	29.0000	29.0000	29.0000	29.0000
Molecular Weight, Wet (lb/lb-mole)	28.2767	28.2726	28.2856	28.2783
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.458527	0.486638	0.446180	0.463782
Avg. Velocity, Stack Gas (ft/seo)	34.7911	36.8894	33.6955	35.1253
Actual Flow Rate (acfm)	24368.272	25837.945	23600.892	24602.370
Dry, Std. Vol. Flow Rate (dscfm)	12726.359	13516.055	12449.049	12897.221
% Isokinetic	102.07	94.38	90.26	95.57
Total Catch (mg)	83.10	65.40	47.70	65.4000
SO ₃ Conc. (grams/dscf)	0.0016	0.0013	0.0011	0.0013
SO ₃ Conc. (grains/dscf)	0.0249	0.0197	0.0163	0.0203
SO ₃ Concentration (lb/dscf)	3.68E-06	2.95E-06	2.44E-06	3.02E-06
SO ₃ Emission Rate (lb/hr)	2.8082	2.3903	1.8228	2.3404

TABLE 6-3. SULFUR DIOXIDE EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, ILL.
 STACK: KLN STACK

SULFUR DIOXIDE SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 11, 1994			
Starting Time (hour)	1515	1700	1840	
Ending Time (hour)	1615	1800	1943	
Net Time of Run (minutes)	60	60	60	
Number of Points	21	21	21	
Barometric Pressure (in. Hg)	29.85	29.85	29.85	
Static Pressure (in. H ₂ O)	-0.11	-0.11	-0.11	
Stack Pressure (in. Hg)	29.84	29.84	29.84	29.84
Average Delta H (in. H ₂ O)	2.4143	2.5619	2.1667	2.38
Average Delta P (in. H ₂ O)	0.2129	0.2400	0.2038	0.22
Meter Pressure (in. Hg)	30.03	30.04	30.01	30.03
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Length (in.)	41	41	41	
Stack Width (in.)	41	41	41	
Stack Cross Sectional Area (ft ²)	11.673611	11.673611	11.673611	11.67361111
Nozzle Diameter (inches)	0.370	0.370	0.370	
Nozzle Area (ft ²)	0.00074667	0.0007467	0.000746674	0.000746674
Meter Temperature (F)	88.952	95.238	94.381	92.857
Stack Temperature (F)	482.048	480.143	473.524	478.571
Ending DGM Volume (ACF)	923.715	986.317	1036.52	
Beginning DGM Volume (ACF)	872.15	935.121	991.447	
Volume of Dry Gas Sample (acf)	51.5650	51.1960	45.0730	49.2780
Dry, Std. Gas Sample Volume (dscf)	49.8247	48.926	43.099	47.2832
Condensate Collected (mL)	74.50	73.60	63.60	70.57
Moisture Concentration (%)	6.58	6.61	6.49	6.56
Carbon Dioxide Concentration (%)	1.800	1.800	1.800	1.800
Oxygen Concentration (%)	17.800	17.800	17.800	17.800
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	80.400	80.400	80.400	80.400
Molecular Weight, Dry (lb/lb-mole)	29.0000	29.0000	29.0000	29.0000
Molecular Weight, Wet (lb/lb-mole)	28.2767	28.2726	28.2856	28.2783
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.458527	0.486638	0.446180	0.463782
Avg. Velocity, Stack Gas (ft/sec)	34.7911	36.8894	33.6955	35.1253
Actual Flow Rate (acfm)	24368.272	25837.945	23600.892	24602.370
Dry, Std. Vol. Flow Rate (dscfm)	12726.559	13516.055	12449.049	12897.221
% Isokinetic	102.07	94.38	90.26	95.57
Total Catch (mg)	1270.00	1160.00	1010.00	1146.6667
SO ₂ Conc. (grams/dscf)	0.0246	0.0227	0.0224	0.0232
SO ₂ Conc. (grains/dscf)	0.3800	0.3496	0.3458	0.3585
SO ₂ Concentration (lb/dscf)	5.62E-05	5.23E-05	5.17E-05	5.34E-05
SO ₂ Emission Rate (lb/hr)	42.9170	42.3965	38.5965	41.3033

TABLE 6-4. PARTICULATE MATTER EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, IL.
 STACK: DRYER STACK #1

PARTICULATE MATTER SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 10, 1994			
Starting Time (hours)	1253	1448	1630	
Ending Time (hours)	1353	1548	1730	
Net Time of Run (minutes)	60	60	60	
Number of Points	24	24	24	
Barometric Pressure (in. Hg)	30.26	30.26	30.26	
Static Pressure (in. H ₂ O)	-0.21	-0.21	-0.21	
Stack Pressure (in. Hg)	30.24	30.24	30.24	30.24
Average Delta H (in. H ₂ O)	1.7917	2.3938	2.2138	2.13
Average Delta P (in. H ₂ O)	0.2204	0.3075	0.2817	0.27
Meter Pressure (in. Hg)	30.39	30.44	30.42	30.42
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Diameter (in.)	45	45	45	
Stack Cross Sectional Area (ft ²)	11.0447	11.0447	11.0447	11.0447
Nozzle Diameter (inches)	0.300	0.300	0.300	
Nozzle Area (ft ²)	0.00049087	0.0004909	0.000490874	0.000490874
Meter Temperature (F)	84.667	86.625	86.858	82.750
Stack Temperature (F)	92.333	94.292	94.125	93.583
Ending DGM Volume (ACF)	580.614	639.95	701.52	
Beginning DGM Volume (ACF)	540.3	591.384	653.16	
Volume of Dry Gas Sample (acf)	40.3140	48.5660	48.3600	45.7467
Dry, Std. Gas Sample Volume (dscf)	39.7361	46.910	46.662	44.4361
Condensate Collected (mL)	90.40	84.30	85.20	86.63
Moisture Concentration (%)	9.67	7.80	7.91	8.46
Carbon Dioxide Concentration (%)	0.300	0.300	0.300	0.300
Oxygen Concentration (%)	20.400	20.400	20.400	20.400
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	79.300	79.300	79.300	79.300
Molecular Weight, Dry (lb/lb-mole)	28.8640	28.8640	28.8640	28.8640
Molecular Weight, Wet (lb/lb-mole)	27.8132	28.0167	28.0042	27.9447
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.451493	0.546681	0.520479	0.506218
Avg. Velocity, Stack Gas (ft/sec)	26.2723	31.7516	30.2320	29.4186
Actual Flow Rate (acfm)	17410.091	21041.132	20034.131	19495.118
Dry, Std. Vol. Flow Rate (dscfm)	15196.275	18680.309	17769.427	17215.337
% Isokinetic	98.11	94.22	98.53	96.96
Total Filter Catch (mg)	0.00	0.20	0.10	0.10
Total Wash Catch (mg)	19.30	6.90	12.60	12.93
Total Catch (mg)	19.30	7.10	12.70	13.03
Particulate Conc. (grams/dscf)	0.0005	0.0001	0.0003	0.0003
Particulate Conc. (grains/dscf)	0.0074	0.0023	0.0041	0.0048
Particulate Concentration (lb/dscf)	1.07E-06	3.34E-07	6.00E-07	6.68E-07
Particulate Emission Rate (lb/hr)	0.9765	0.3741	0.6398	0.6635

TABLE 6-1

TABLE 6-5. SULFUR TRIOXIDE EMISSION SUMMARY

PLANT: MARSELLES BRICK
 CITY, STATE: MARSELLES, ILL.
 STACK: DRYER STACK #1

SULFUR TRIOXIDE EMISSIONS SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 10, 1994			
Starting Time (hours)	1253	1448	1630	
Ending Time (hours)	1353	1548	1730	
Net Time of Run (minutes)	60	60	60	
Number of Points	24	24	24	
Barometric Pressure (in. Hg)	30.26	30.26	30.26	
Static Pressure (in. H ₂ O)	-0.21	-0.21	-0.21	
Stack Pressure (in. Hg)	30.24	30.24	30.24	30.24
Average Delta H (in. H ₂ O)	1.7917	2.3938	2.2138	2.13
Average Delta P (in. H ₂ O)	0.2204	0.3075	0.2817	0.27
Meter Pressure (in. Hg)	30.39	30.44	30.42	30.42
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Diameter (in.)	45	45	45	
Stack Cross Sectional Area (ft ²)	11.0447	11.0447	11.0447	11.04466167
Nozzle Diameter (inches)	0.300	0.300	0.300	
Nozzle Area (ft ²)	0.00049087	0.0004909	0.000490874	0.000490874
Meter Temperature (F)	84.667	86.625	86.958	82.750
Stack Temperature (F)	92.333	94.292	94.125	93.583
Ending DGM Volume (ACF)	580.614	639.95	701.52	
Beginning DGM Volume (ACF)	540.3	591.384	653.16	
Volume of Dry Gas Sample (acf)	40.3140	48.5660	48.3600	45.7467
Dry, Std. Gas Sample Volume (dscf)	39.7361	46.910	46.662	44.4361
Condensate Collected (mL)	90.40	84.30	85.20	86.63
Moisture Concentration (%)	9.67	7.80	7.91	8.46
Carbon Dioxide Concentration (%)	0.300	0.300	0.300	0.300
Oxygen Concentration (%)	20.400	20.400	20.400	20.400
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	79.300	79.300	79.300	79.300
Molecular Weight, Dry (lb/lb-mole)	28.8640	28.8640	28.8640	28.8640
Molecular Weight, Wet (lb/lb-mole)	27.8132	28.0167	28.0042	27.9447
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.451493	0.546681	0.520479	0.506218
Avg. Velocity, Stack Gas (ft/sec)	26.2723	31.7516	30.2320	29.4186
Actual Flow Rate (acfm)	17410.091	21041.132	20034.131	19485.118
Dry, Std. Vol. Flow Rate (dscfm)	15196.275	18680.309	17769.427	17215.337
% Isokinetic	98.11	94.22	98.53	96.96
Total Catch (mg)	1.25	0.41	1.24	0.97
SO ₃ Conc. (grams/dscf)	0.0000	0.0000	0.0000	0.0000
SO ₃ Conc. (grains/dscf)	0.0005	0.0001	0.0004	0.0003
SO ₃ Concentration (lb/dscf)	6.94E-08	1.93E-08	5.86E-08	4.91E-08
SO ₃ Emission Rate (lb/hr)	0.0632	0.0216	0.0625	0.0491

TABLE 6-6. SULFUR DIOXIDE EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, ILL.
 STACK: DRYER STACK #1

SULFUR DIOXIDE EMISSIONS SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 10, 1994			
Starting Time (hours)	1253	1448	1630	
Ending Time (hours)	1353	1548	1730	
Net Time of Run (minutes)	60	60	60	
Number of Points	24	24	24	
Barometric Pressure (in. Hg)	30.26	30.26	30.26	
Static Pressure (in. H ₂ O)	-0.21	-0.21	-0.21	
Stack Pressure (in. Hg)	30.24	30.24	30.24	30.24
Average Delta H (in. H ₂ O)	1.7917	2.3938	2.2138	2.13
Average Delta P (in. H ₂ O)	0.2204	0.3075	0.2817	0.27
Meter Pressure (in. Hg)	30.39	30.44	30.42	30.42
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Diameter (in.)	45	45	45	
Stack Cross Sectional Area (ft ²)	11.0447	11.0447	11.0447	11.04466167
Nozzle Diameter (inches)	0.300	0.300	0.300	
Nozzle Area (ft ²)	0.00049087	0.0004909	0.000490874	0.000490874
Meter Temperature (F)	84.667	96.625	96.958	92.750
Stack Temperature (F)	92.333	94.292	94.125	93.583
Ending DGM Volume (ACF)	580.614	639.95	701.52	
Beginning DGM Volume (ACF)	540.3	591.384	653.16	
Volume of Dry Gas Sample (acf)	40.3140	48.5660	48.3600	45.7467
Dry, Std. Gas Sample Volume (dscf)	39.7361	46.910	46.662	44.4361
Condensate Collected (mL)	90.40	84.30	85.20	86.63
Moisture Concentration (%)	9.67	7.80	7.91	8.46
Carbon Dioxide Concentration (%)	0.300	0.300	0.300	0.300
Oxygen Concentration (%)	20.400	20.400	20.400	20.400
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	79.300	79.300	79.300	79.300
Molecular Weight, Dry (lb/lb-mole)	28.8640	28.8640	28.8640	28.8640
Molecular Weight, Wet (lb/lb-mole)	27.8132	28.0167	28.0042	27.9447
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.451493	0.546681	0.520479	0.506218
Avg. Velocity, Stack Gas (ft/sec)	26.2723	31.7516	30.2320	29.4186
Actual Flow Rate (acfm)	17410.091	21041.132	20034.131	19495.118
Dry, Std. Vol. Flow Rate (dscfm)	15196.275	18680.309	17769.427	17215.337
% Isokinetic	98.11	94.22	96.53	96.96
Total Catch (mg)	ND	ND	ND	ND
SO ₂ Conc. (grams/dscf)	0.0000	0.0000	0.0000	0.0000
SO ₂ Conc. (grains/dscf)	0.0000	0.0000	0.0000	0.0000
SO ₂ Concentration (lb/dscf)	0.00E+00	0.00E+00	0.00E+00	0.00E+00
SO ₂ Emission Rate (lb/hr)	0.0000	0.0000	0.0000	0.0000

ND = Not detected above the detection limit, 0.6 mg.

TABLE 6-7. PARTICULATE MATTER EMISSION SUMMARY

PLANT: MARSELLES BRICK
 CITY, STATE: MARSELLES, IL.
 STACK: DRYER STACK #2

PARTICULATE MATTER SUMMARY

Run Number	1	2	3	AVERAGE
Date of Run	MAY 11, 1994			
Starting Time (hours)	750	930	1106	
Ending Time (hours)	850	1030	1206	
Net Time of Run (minutes)	60	60	60	
Number of Points	24	24	24	
Barometric Pressure (in. Hg)	30.09	30.09	30.09	
Static Pressure (in. H ₂ O)	-0.21	-0.21	-0.21	
Stack Pressure (in. Hg)	30.07	30.07	30.07	30.07
Average Delta H (in. H ₂ O)	1.7142	2.1388	1.8067	1.89
Average Delta P (in. H ₂ O)	0.2354	0.2858	0.2417	0.25
Meter Pressure (in. Hg)	30.22	30.25	30.22	30.23
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Diameter (in.)	45	45	45	
Stack Cross Sectional Area (ft ²)	11.044662	11.044662	11.044662	11.04466167
Nozzle Diameter (inches)	0.300	0.300	0.300	
Nozzle Area (ft ²)	0.00049087	0.0004909	0.000490874	0.000490874
Meter Temperature (F)	70.708	83.083	86.500	80.097
Stack Temperature (F)	94.375	94.750	98.208	95.778
Ending DGM Volume (ACF)	750	809.014	862.16	
Beginning DGM Volume (ACF)	708.421	762.5	819.654	
Volume of Dry Gas Sample (acf)	41.5790	46.5140	42.5060	43.5330
Dry, Std. Gas Sample Volume (dscf)	41.8178	45.762	41.524	43.0347
Condensate Collected (mL)	82.80	71.40	69.50	74.57
Moisture Concentration (%)	8.53	6.84	7.30	7.56
Carbon Dioxide Concentration (%)	0.300	0.300	0.300	0.300
Oxygen Concentration (%)	20.400	20.400	20.400	20.400
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	79.300	79.300	79.300	79.300
Molecular Weight, Dry (lb/lb-mole)	28.8640	28.8640	28.8640	28.8640
Molecular Weight, Wet (lb/lb-mole)	27.9378	28.1207	28.0706	28.0430
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.474180	0.524860	0.482470	0.493837
Avg. Velocity, Stack Gas (ft/sec)	27.6595	30.5263	28.1733	28.7864
Actual Flow Rate (acfm)	18329.380	20229.150	18669.877	19076.136
Dry, Std. Vol. Flow Rate (dscfm)	16051.471	18029.040	16454.378	16844.963
% Isokinetic	97.75	95.24	94.69	95.89
Total Filter Catch (mg)	0.50	0.30	2.10	0.97
Total Wash Catch (mg)	14.80	2.00	0.20	5.67
Total Catch (mg)	15.30	2.30	2.30	6.63
Particulate Conc. (grams/dscf)	0.0004	0.0000	0.0001	0.0002
Particulate Conc. (grains/dscf)	0.0057	0.0008	0.0008	0.0024
Particulate Concentration (lb/dscf)	8.07E-07	1.11E-07	1.22E-07	3.47E-07
Particulate Emission Rate (lb/hr)	0.7770	0.1199	0.1206	0.3391

TABLE 6-8. SULFUR TRIOXIDE EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, ILL.
 STACK: DRYER STACK #2

SULFUR TRIOXIDE SUMMARY

	1	2	3	AVERAGE
Run Number	MAY 11, 1994			
Date of Run				
Starting Time (hours)	750	930	1106	
Ending Time (hours)	850	1030	1206	
Net Time of Run (minutes)	60	60	60	
Number of Points	24	24	24	
Barometric Pressure (in. Hg)	30.09	30.09	30.09	
Static Pressure (in. H ₂ O)	-0.21	-0.21	-0.21	
Stack Pressure (in. Hg)	30.07	30.07	30.07	30.07
Average Delta H (in. H ₂ O)	1.7142	2.1388	1.8067	1.89
Average Delta P (in. H ₂ O)	0.2354	0.2858	0.2417	0.25
Meter Pressure (in. Hg)	30.22	30.25	30.22	30.23
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (SIL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Diameter (in.)	45	45	45	
Stack Cross Sectional Area (ft ²)	11.044662	11.044662	11.044662	11.04466167
Nozzle Diameter (inches)	0.300	0.300	0.300	
Nozzle Area (ft ²)	0.00049087	0.0004909	0.000490874	0.000490874
Meter Temperature (F)	70.708	83.083	86.500	80.097
Stack Temperature (F)	94.375	94.750	98.208	95.776
Ending DGM Volume (ACF)	750	809.014	862.16	
Beginning DGM Volume (ACF)	708.421	762.5	819.654	
Volume of Dry Gas Sample (acf)	41.5790	46.5140	42.5060	43.5330
Dry, Std. Gas Sample Volume (dscf)	41.8178	45.762	41.524	43.0347
Condensate Collected (mL)	82.80	71.40	69.50	74.57
Moisture Concentration (%)	8.53	6.84	7.30	7.56
Carbon Dioxide Concentration (%)	0.300	0.300	0.300	0.300
Oxygen Concentration (%)	20.400	20.400	20.400	20.400
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	79.300	79.300	79.300	79.300
Molecular Weight, Dry (lb/lb-mole)	28.8640	28.8640	28.8640	28.8640
Molecular Weight, Wet (lb/lb-mole)	27.9378	28.1207	28.0706	28.0430
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.474180	0.524860	0.482470	0.493837
Avg. Velocity, Stack Gas (ft/sec)	27.6595	30.5263	28.1733	28.7864
Actual Flow Rate (acfm)	18329.380	20229.150	18669.877	19076.136
Dry, Std. Vol. Flow Rate (dscfm)	16051.471	18029.040	16454.378	16844.963
% Isokinetic	97.75	95.24	94.69	95.89
Total Catch (mg)	ND	ND	1.01	EFF
SO ₃ Conc. (grams/dscf)	0.0000	0.0000	0.0000	0.0000
SO ₃ Conc. (grains/dscf)	0.0000	0.0000	0.0004	0.0001
SO ₃ Concentration (lb/dscf)	0.00E+00	0.00E+00	5.36E-08	1.79E-08
SO ₃ Emission Rate (lb/hr)	0.0000	0.0000	0.0529	0.0176

ND = Not detected above detection limit.

TABLE 6-9. SULFUR DIOXIDE EMISSION SUMMARY

PLANT: MARSEILLES BRICK
 CITY, STATE: MARSEILLES, IL
 STACK: DRYER STACK #2

SULFUR DIOXIDE SUMMARY

	1	2	3	AVERAGE
Run Number				
Date of Run	MAY 11, 1994			
Starting Time (hours)	750	930	1106	
Ending Time (hours)	850	1030	1206	
Net Time of Run (minutes)	60	60	60	
Number of Points	24	24	24	
Barometric Pressure (in. Hg)	30.09	30.09	30.09	
Static Pressure (in. H ₂ O)	-0.21	-0.21	-0.21	
Stack Pressure (in. Hg)	30.07	30.07	30.07	30.07
Average Delta H (in. H ₂ O)	1.7142	2.1388	1.8067	1.89
Average Delta P (in. H ₂ O)	0.2354	0.2858	0.2417	0.25
Meter Pressure (in. Hg)	30.22	30.25	30.22	30.23
Pitot Tube Coefficient	0.84	0.84	0.84	0.84
Meter Box Number (STL#)	2	2	2	
Y-Factor	1.001	1.001	1.001	
Stack Diameter (in.)	45	45	45	
Stack Cross Sectional Area (ft ²)	11.044662	11.044662	11.044662	11.04466167
Nozzle Diameter (inches)	0.300	0.300	0.300	
Nozzle Area (ft ²)	0.00049087	0.0004909	0.000490874	0.000490874
Meter Temperature (F)	70.708	83.083	86.500	80.097
Stack Temperature (F)	94.375	94.750	98.208	95.778
Ending DGM Volume (ACF)	750	809.014	862.16	
Beginning DGM Volume (ACF)	708.421	762.5	819.654	
Volume of Dry Gas Sample (acf)	41.5790	46.5140	42.5060	43.5330
Dry, Std. Gas Sample Volume (dscf)	41.8178	45.762	41.524	43.0347
Condensate Collected (mL)	82.80	71.40	69.50	74.57
Moisture Concentration (%)	8.53	6.84	7.30	7.56
Carbon Dioxide Concentration (%)	0.300	0.300	0.300	0.300
Oxygen Concentration (%)	20.400	20.400	20.400	20.400
Carbon Monoxide Concentration (%)	0.000	0.000	0.000	0.000
Nitrogen Conc. Dry (gas balance)	79.300	79.300	79.300	79.300
Molecular Weight, Dry (lb/lb-mole)	28.8640	28.8640	28.8640	28.8640
Molecular Weight, Wet (lb/lb-mole)	27.9378	28.1207	28.0706	28.0430
SQRT Delta P Avg., Pitot (in. H ₂ O)	0.474180	0.524860	0.482470	0.493837
Avg. Velocity, Stack Gas (ft/sec)	27.6595	30.5263	28.1733	28.7864
Actual Flow Rate (acfm)	18329.380	20229.150	18669.877	19076.136
Dry, Std. Vol. Flow Rate (dscfm)	16051.471	18029.040	16454.378	16844.963
% Isokinetic	97.75	95.24	94.69	95.89
Total Catch (mg)	ND	ND	ND	ND
SO ₂ Conc. (grams/dscf)	0.0000	0.0000	0.0000	0.0000
SO ₂ Conc. (grains/dscf)	0.0000	0.0000	0.0000	0.0000
SO ₂ Concentration (lb/dscf)	0.00E+00	0.00E+00	0.00E+00	0.00E+00
SO ₂ Emission Rate (lb/hr)	0.0000	0.0000	0.0000	0.0000

ND = Not detected above detection limit.

APPENDIX A
Process Operations Data

MARSEILLES BRICK

VENTURE LIMITED PARTNERSHIP

*****FAX COVER SHEET*****

DATE: 5/25/94
TO: Robt Felle
Eugene McClelland
FROM: Jack Laird

TOTAL # OF PAGES, INCLUDING COVER: 3MESSAGE: Dear Bob

Following is a Brief description of
our Drying & Firing process. The
test were set up for a 80% shale 20%
Fireclay mix. If you have any questions
about this information please give me a
call.

Regards
Jack

Description of Drying & Firing Procedure

Marseilles Brick has two independent Dryer tunnels approximately 200 ft. in length that hold 14 kiln cars each. Waste heat from the cooling section of the kiln is supplied to each dryer by a fan through a duct/plenum system. The heat to each dryer is boosted to 325°F by two natural gas burners, 442M BTU/hr and 432M BTU/hr respectively, located in the air supply duct. Moist warm air is exhausted to the atmosphere by a fan at the entrance end of each dryer tunnel. Dryer #1 and Dryer #2 are independent of each other except for the common waste heat supply from the kiln.

The tunnel kiln used by Marseilles Brick to fire its brick is a 498 ft. metal jacketed natural gas fired kiln designed by Ceric. The kiln holds a total of 36 kiln cars with 20 in the pre-heat and furnace section and 16 in the cooling section. The pre-heat section is divided into 6 zones with a total of 32 gas fired side burners. The furnace section is divided into 7 zones with 19 natural gas fired top burners in each zone for a total of 133 top fired burners. The cooling section has a rapid cool zone (2 car lengths long) where the brick are cooled from 1930°F to approximately 1300°F by injecting ambient air directly on the brick. The balance of the cooling section is used to cool the brick to approximately 100°F before exiting the kiln.

Waste heat is removed from the cooling section close to the exit to supply heated air to the dryers. The kiln exhaust fan is located near the entrance end of the pre-heat and exhausts the products of combustion to the atmosphere through a 40' high brick chimney.

MATERIAL BEING TESTED

80% Shale, 20% Fireclay

Size: Modular

Weight: Wet - 4.6 lbs., Dry - 4.1 lbs., Fired - 3.8 lbs.

Units per car: 10,080

Production rate 12 cars per day

Date: May 10, Time 12:00 p.m.

Position of cars in kiln

16 cars 80% Shale, 20% Fireclay in pre-heat & furnace section

20 cars 10% Shale, 90% Fireclay 4 in furnace & 16 in cooling

Position of cars in Dryers

Dryer #1

14 cars 80% Shale, 20% Fireclay

Dryer #2

14 cars 80% Shale, 20% Fireclay

Date: May 11, Time 7:00 a.m.

Position of cars in kiln

23 cars 80% Shale, 20% Fireclay in pre-heat, furnace & cooling
13 cars 10% Shale, 90% Fireclay in cooling section

Position of cars in Dryers

Dryer #1

14 cars 80% Shale, 20% Fireclay

Dryer #2

14 cars 80% Shale, 20% Fireclay

Date: May 11, Time 12:00 p.m.

Position of cars in kiln

25 cars 80% Shale, 20% Fireclay in pre-heat, furnace & cooling
11 cars 10% Shale, 90% Fireclay in cooling section

Position of cars in Dryers

Dryer #1

14 cars 80% Shale, 20% Fireclay

Dryer #2

14 cars 80% Shale, 20% Fireclay

Total fuel consumption during Test #1 (Dryer #1 exhaust)

May 10 - 14,200 cubic feet per hour

Total fuel consumption during Test #2 (Dryer #2 exhaust)

May 11 - 13,100 cubic feet per hour

Total fuel consumption during Test #3 (kiln exhaust)

May 11 - 13,100 cubic feet per hour

APPENDIX B

Resumes

RESUME



Robert F. Folle
Air Quality Scientist

EDUCATION:

MBA, Business Management, Golden Gate University, San Francisco, California, 1979

BA, Business Administration, St. Leo College, St. Leo, Florida, 1977

QUALIFICATIONS:

Certified EPA Method 9 visual opacity observer, 40 CFR, Part 52, Appendix F, Air Pollution Control Board, St. Louis, MO, April 1993; Certified AHERA Asbestos Inspector #7ME0409920031R; Certified AHERA Asbestos Mgr. Planner #7ME040992003MPR; Certification of Completion, 40 Hr. Course in Hazardous Materials/Waste Site Investigation, 1989; Certification of Completion, Supervisors Course in Hazardous Materials/Waste Site Operations, 1990; Certification of Completion, Air Dispersion Modeling, 1990; Certification of Completion, Air Dispersion Modeling Laboratory, 1990.

EXPERIENCE:

Over 4 years experience in the performance and management of a diversified range of air quality projects. Performed as field team leader, project manager or group leader on over 200 source emissions projects involving the collection and analysis of air quality data for engineering design, permitting and compliance.

Project manager for numerous air dispersion modeling projects involving the use of the USEPA industrial source complex (ISC) short-term (ISCST) and long-term (ISCLT), complex-1 and screen models.

Extensive experience as field team leader and project manager for continuous emission monitoring system (CEMS) performance specification certification testing including CEMS relative accuracy (RA) certifications.

Participated and managed numerous projects involving asbestos sampling and asbestos air monitoring for facility and transactional environmental audits.

PROFESSIONAL AFFILIATIONS:

Member of the Air and Waste Management Association
Source Evaluation Society

RESUME



J. Todd Staley

Senior Environmental Technician

EDUCATION:

Community College of the Air Force
1983 - 1992 - Management and Construction Technology

QUALIFICATIONS:

Certified EPA Method 9 visual opacity observer
OSHA Hazardous Waste Operations and Emergency Response
RCRA Compliance & Hazardous Waste Management

EXPERIENCE:

Over nine years experience as an environmental technician. Responsible for ensuring compliance and providing technical assistance on waste disposal, UST remediation and air quality projects. Currently assigned to the Air Quality Group engaged in all technical aspects of Source Emissions testing. Participated in several source tests including projects at petroleum refineries, hazardous waste incinerators, chemical production facilities, explosive manufacturers and chemical transfer facilities.

Mr. Staley has served as an Air Quality Technician on several source emission testing projects and Continuous Emission Monitoring System (CEM) specification certifications.

He has provided technical support on several USEPA Method 5 projects including collection and analysis of Air Quality data for a major explosives plant in Missouri.

At a chemical production facility in West Virginia, he assisted in a USEPA Boiler and Industrial Furnace (BIF) project, providing Continuous Emission Monitoring (CEM) specification certifications on two CO and O₂ systems. Certifications included span drift and CEMS relative accuracy tests. (RA)

Mr. Staley is presently providing on-going monitoring services for two benzene transfer facilities in Illinois and Missouri. He is responsible for leak detection monitoring of all components at both facilities on a routine basis.

PROFESSIONAL AFFILIATIONS:

Air and Waste Management Association
Source Evaluation Society

RESUME



Daniel M. Cusac
Air Quality Technician

EDUCATION: Illinois Central College, 1989-1993, Metals Technology

QUALIFICATIONS: Certified EPA Method 9-Visual Plume Observer
OSHA Hazardous Waste Operations and Emergency Response

EXPERIENCE: Assigned to the Air Quality Division serving as a technician on several Source Emissions Testing projects. Provided technical support for Air Quality projects at petroleum refineries, waste incinerators, chemical production facilities and chemical transfer facilities.

While assigned to the Air Quality Group, Mr. Cusac has provided technical support on several source emission testing projects and Continuous Emission Monitoring (CEM) system certifications.

He has served as an Air Quality Technician on a wide variety of tests utilizing USEPA Methods 1, 2, 3, 4, 5, 9, and 12 for the collection and analysis of total particulate matter, visible opacity and lead.

Mr. Cusac has also performed multi-metals emission testing utilizing USEPA (Draft) Method 0012 at major industrial facilities. He has been involved in the collection and recovery of samples utilizing the procedures outlined in the draft method.

He has participated in conducting Continuous Emission Monitoring (CEM) system performance specification and relative accuracy testing following the guidelines published in the Boilers and Industrial Furnace (BIF) regulation.

**PROFESSIONAL
AFFILIATIONS:**

Air and Waste Management Association
Source Evaluation Society

APPENDIX C
Laboratory Analysis

CERTIFICATE OF ANALYSIS

Fugro McClelland
9921 St. Charles Rock Road
St. Ann, MO 63074

Date: June 2, 1994

Attn: Todd Staley

Project Number 415

This is the Certificate of Analysis for the following samples:

Client Project ID:	Fugro McClelland
Date Received:	May 17, 1994
Work Order:	4448
Number of Samples:	20
Sample Type:	Liquid

I. Introduction


Twenty samples arrived at ITAS Cincinnati on May 17, 1994. The samples were collected on May 10, 1994 and May 11, 1994 and are labeled in Table I.

II. Analytical Results/Methodology

The analytical results for this report are presented by analytical test. The data will include sample identification information, the analytical results, and the appropriate detection limits.

The analysis requested was Sulfur Dioxide and Trioxide including Sulfuric Acid Mist by EPA Method 8.

Reviewed and Approved by:


Kenneth Mueller, C.H.M.M.
Project Manager

American Council of Independent Laboratories
International Association of Environmental Testing Laboratories
American Association for Laboratory Accreditation

Client: Fugro McClelland
Work Order: 4448
05444807

INTERNATIONAL TECHNOLOGY CORPORATION

I. Introduction (cont.)

Client Sample ID	Lab Sample ID
DRIER 1 RUN 1A	AD5859
DRIER 1 RUN 2A	AD5860
DRIER 1 RUN 3A	AD5861
DRIER 1 RUN 1B	AD5862
DRIER 1 RUN 2B	AD5863
DRIER 1 RUN 3B	AD5864
DRIER 2 RUN 1A	AD5865
DRIER 2 RUN 2A	AD5866
DRIER 2 RUN 3A	AD5867
DRIER 2 RUN 1B	AD5868
DRIER 2 RUN 2B	AD5869
DRIER 2 RUN 3B	AD5870
KILN EXHAUST RUN 1A	AD5871
KILN EXHAUST RUN 2A	AD5872
KILN EXHAUST RUN 3A	AD5873
KILN EXHAUST RUN 1B	AD5874
KILN EXHAUST RUN 2B	AD5875
KILN EXHAUST RUN 3B	AD5876
BLANK 80% IPA	AD5877
BLANK 3% H2O2	AD5878

Client: Fugro McClelland
Work Order: 4448
05444801

INTERNATIONAL TECHNOLOGY CORPORATION

III. Quality Control

Immediately following the analytical data for the samples can be found the QA/QC information that pertains to these samples. The purpose of this information is to demonstrate that the data enclosed is scientifically valid and defensible. This QA/QC data is used to assess the laboratory's performance during the analysis of the samples it accompanies. All quantitations were performed within the calibrated range of the analytical instrument.

Client: Fugro McClelland
Work Order: 4448
05444802

INTERNATIONAL TECHNOLOGY CORPORATION

Analytical Results, mg

Client Sample ID	Lab Sample ID	Sulfur Trioxide including Sulfuric Acid			Detection Limit
		1ST	2ND	Average	
DRIER 1 RUN 1A	AD5859	1.13	1.37	1.25	0.4
DRIER 1 RUN 2A	AD5860	ND	0.41	ND	0.3
DRIER 1 RUN 3A	AD5861	1.15	1.34	1.24	0.3
DRIER 2 RUN 1A	AD5865	ND	ND	ND	0.5
DRIER 2 RUN 2A	AD5866	ND	ND	ND	0.5
DRIER 2 RUN 3A	AD5867	1.01	1.01	1.01	0.4
KILN EXHAUST RUN 1A	AD5871	84.6	81.5	83.1	0.4
KILN EXHAUST RUN 2A	AD5872	65.9	64.9	65.4	0.4
KILN EXHAUST RUN 3A	AD5873	47.8	47.6	47.7	0.5
BLANK 80% IPA	AD5877	ND	ND	ND	1.0

Client Sample ID	Lab Sample ID	Sulfur Dioxide			Detection Limit
		1ST	2ND	Average	
DRIER 1 RUN 1B	AD5862	ND	ND	ND	0.5
DRIER 1 RUN 2B	AD5863	ND	ND	ND	0.6
DRIER 1 RUN 3B	AD5864	ND	ND	ND	0.6
DRIER 2 RUN 1B	AD5868	ND	ND	ND	0.6
DRIER 2 RUN 2B	AD5869	ND	ND	ND	0.6
DRIER 2 RUN 3B	AD5870	ND	ND	ND	0.6
KILN EXHAUST RUN 1B	AD5874	1270	1270	1270	4
KILN EXHAUST RUN 2B	AD5875	1160	1160	1160	3
KILN EXHAUST RUN 3B	AD5876	1010	1010	1010	3
BLANK 3% H2O2	AD5878	ND	ND	ND	3

ND = Not detected above the reported detection limit

Client: Fugro McClelland
Work Order: 4448
05444803

INTERNATIONAL TECHNOLOGY CORPORATION

Quality Assurance Data

Quality Control
Standard Reference Solutions

Analyte -----	Theoretical Value -----	Percent Recovery -----
Sulfur Dioxide	114.4 mg/DSCM	
	111.23	97.2
	113.52	99.2

CHAIN OF CUSTODY RECORD



9921 St Charles Rock Rd.
St Ann, MO 63074
Phone: 314-428-8880
Fax: 314-428-8719

PROJECT NO.
0894-8885

PROJECT NAME
Marseilles Brick

LOCATION
Marseilles, IL

SAMPLE IDENTIFICATION	DATE	TIME	ANALYSES REQUESTED						SAMPLE TYPE (Water, Soil, etc.)	CONTAINERS/ PRESERVATIVES								COMMENTS
			REQUESTED							PRESERVATIVES								
			A	B	C	D	E	F		G	H	I	J	K	L			
Drill 1 RUN 1 A	5-10-94	1400	X						Aqueous	X							A = 80% IPA Reagent + DI Rinse	
RUN 2 A	5-10-94	1600	X														B = 3% H ₂ O ₂ Reagent + DI Rinse	
RUN 3 A	5-10-94	1730	X															
Drill 1 RUN 1 B	5-10-94	1400		X														
RUN 2 B	5-10-94	1600		X														
RUN 3 B	5-10-94	1730		X														
Drill 2 RUN 1 A	5-11-94	0900	X															
RUN 2 A	5-11-94	1030	X															
RUN 3 A	5-11-94	1200	X															
Drill 2 RUN 1 B	5-11-94	0900		X													Sample Acrid @ 180°C,	
RUN 2 B	5-11-94	1030		X													NO CX Arals present	
RUN 3 B	5-11-94	1200		X														
Kiln Exhaust RUN 1 A	5-11-94	1630	X															
RUN 2 A	5-11-94	1800	X															
RUN 3 A	5-11-94	1930	X															
(Cont)																		

SAMPLES SUBMITTED TO:
(LABORATORY)

Relinquished By
(signature)

Date

Time

Received By
(signature)

Analyses
Requested

Containers/
Preservatives

A 503
B 502
C
D
E
F
G Seal Poly
H
I
J
K
L

9921 St Charles Rock Rd.
St Ann, MO 63074
Phone: 314-428-8880
Fax: 314-428-8719

[illegible]

PARTICULATE LABORATORY ANALYSIS

Project Name: Marseilles Brick Date Sampled: 5-14-94
 Project Number: 0894-8885 Date Analyzed: 5-17-94
 Source: Kiln Exhaust Analyzed By: CND

Run No. <u>1</u> Beaker No. <u>94-24</u> Beaker Vol <u>300</u> ml Final Wt <u>51.9076</u> g Tare Wt <u>51.8030</u> g Wt Gain <u>104.6</u> mg Blk Corr <u>0</u> mg Net Wt <u>104.6</u> mg	Run No. <u>2</u> Beaker No. <u>94-27</u> Beaker Vol <u>300</u> ml Final Wt <u>51.7349</u> g Tare Wt <u>51.6335</u> g Wt Gain <u>101.4</u> mg Blk Corr <u>0</u> mg Net Wt <u>101.4</u> mg	Run No. <u>3</u> Beaker No. <u>94-28</u> Beaker Vol <u>300</u> ml Final Wt <u>51.8320</u> g Tare Wt <u>51.7463</u> g Wt Gain <u>85.7</u> mg Blk Corr <u>0</u> mg Net Wt <u>85.7</u> mg	Run No. <u>94-22</u> Beaker No. <u>31ank</u> Beaker Vol <u>300</u> ml Final Wt <u>51.5721</u> g Tare Wt <u>51.5721</u> g Wt Gain <u>0</u> mg Blk Corr <u>0</u> mg Net Wt <u>0</u> mg
Filter No. <u>940017</u> Final Wt <u>0.3578</u> g Tare Wt <u>0.3369</u> g Wt Gain <u>20.9</u> mg Blk Gain <u>0</u> mg Net Wt <u>20.9</u> mg	Filter No. <u>940018</u> Final Wt <u>0.3617</u> g Tare Wt <u>0.3366</u> g Wt Gain <u>25.1</u> mg Blk Gain <u>0</u> mg Net Wt <u>25.1</u> mg	Filter No. <u>940019</u> Final Wt <u>0.3558</u> g Tare Wt <u>0.3400</u> g Wt Gain <u>15.8</u> mg Blk Gain <u>0</u> mg Net Wt <u>15.8</u> mg	Filter No. <u>0</u> Final Wt <u>0</u> g Tare Wt <u>0</u> g Wt Gain <u>0</u> mg Blk Gain <u>0</u> mg Net Wt <u>0</u> mg
TOTAL PARTICULATE WTS Filter <u>20.9</u> mg Wash <u>104.6</u> mg Total <u>125.5</u> mg	TOTAL PARTICULATE WTS Filter <u>25.1</u> mg Wash <u>101.4</u> mg Total <u>126.5</u> mg	TOTAL PARTICULATE WTS Filter <u>15.8</u> mg Wash <u>85.7</u> mg Total <u>101.5</u> mg	TOTAL PARTICULATE WTS Filter <u>0</u> mg Wash <u>0</u> mg Total <u>0</u> mg

PARTICULATE LABORATORY ANALYSIS

Project Name: Marseilles Brick

Date Sampled: 5-10-94

Project Number: 0894-8885

Date Analyzed: 5-17-94

Source: Dryer #1

Analyzed By: CND

Run No. <u>1</u> Beaker No. <u>94-23</u> Beaker Vol <u>300</u> ml Final Wt <u>51.9817</u> g Tare Wt <u>51.9624</u> g Wt Gain <u>19.3</u> mg Blk Corr <u>0</u> mg Net Wt <u>19.3</u> mg	Run No. <u>2</u> Beaker No. <u>94-24</u> Beaker Vol <u>300</u> ml Final Wt <u>52.6761</u> g Tare Wt <u>52.6692</u> g Wt Gain <u>6.9</u> mg Blk Corr <u>0</u> mg Net Wt <u>6.9</u> mg	Run No. <u>3</u> Beaker No. <u>94-25</u> Beaker Vol <u>300</u> ml Final Wt <u>52.3703</u> g Tare Wt <u>52.3577</u> g Wt Gain <u>12.6</u> mg Blk Corr <u>0</u> mg Net Wt <u>12.6</u> mg	Run No. <u>4</u> Beaker No. <u>94-26</u> Beaker Vol <u>300</u> ml Final Wt <u>52.3703</u> g Tare Wt <u>52.3577</u> g Wt Gain <u>12.6</u> mg Blk Corr <u>0</u> mg Net Wt <u>12.6</u> mg
Filter No. <u>940013</u> Final Wt <u>0.3352</u> g Tare Wt <u>0.3353</u> g Wt Gain <u>0</u> mg Blk Gain <u>0</u> mg Net Wt <u>0</u> mg	Filter No. <u>940012</u> Final Wt <u>0.3382</u> g Tare Wt <u>0.3380</u> g Wt Gain <u>0.2</u> mg Blk Gain <u>0</u> mg Net Wt <u>0.2</u> mg	Filter No. <u>940018</u> <i>ALN</i> Final Wt <u>0.3385</u> g Tare Wt <u>0.3384</u> g Wt Gain <u>0.1</u> mg Blk Gain <u>0</u> mg Net Wt <u>0.1</u> mg	Filter No. <u>940019</u> Final Wt <u>0.3385</u> g Tare Wt <u>0.3384</u> g Wt Gain <u>0.1</u> mg Blk Gain <u>0</u> mg Net Wt <u>0.1</u> mg
TOTAL PARTICULATE WTS Filter <u>0</u> mg Wash <u>19.3</u> mg Total <u>19.3</u> mg	TOTAL PARTICULATE WTS Filter <u>0.2</u> mg Wash <u>6.9</u> mg Total <u>7.1</u> mg	TOTAL PARTICULATE WTS Filter <u>0.1</u> mg Wash <u>12.6</u> mg Total <u>12.7</u> mg	TOTAL PARTICULATE WTS Filter <u>0.1</u> mg Wash <u>12.6</u> mg Total <u>12.7</u> mg

PARTICULATE LABORATORY ANALYSIS

Project Name: Marseilles Brick

Date Sampled: 5-10-94

Project Number: 0894-8885

Date Analyzed: 5-17-94

Source: Dryer # 2

Analyzed By: CDD

Run No. <u>1</u> Beaker No. <u>94-19</u> Beaker Vol <u>300</u> ml Final Wt <u>52.3604</u> g Tare Wt <u>52.3456</u> g Wt Gain <u>14.8</u> mg Blk Corr <u>0</u> mg Net Wt <u>14.8</u> mg	Run No. <u>2</u> Beaker No. <u>94-20</u> Beaker Vol <u>300</u> ml Final Wt <u>51.8732</u> g Tare Wt <u>51.8103</u> g Wt Gain <u>2.0</u> mg Blk Corr <u>0</u> mg Net Wt <u>2.0</u> mg	Run No. <u>3</u> Beaker No. <u>94-21</u> Beaker Vol <u>30</u> ml Final Wt <u>52.0157</u> g Tare Wt <u>52.0136</u> g Wt Gain <u>2.1</u> mg Blk Corr <u>0</u> mg Net Wt <u>2.1</u> mg	Run No. _____ Beaker No. _____ Beaker Vol _____ ml Final Wt _____ g Tare Wt _____ g Wt Gain _____ mg Blk Corr _____ mg Net Wt _____ mg
Filter No. <u>940014</u> Final Wt <u>0.3371</u> g Tare Wt <u>0.3366</u> g Wt Gain <u>0.5</u> mg Blk Gain <u>0</u> mg Net Wt <u>0.5</u> mg	Filter No. <u>940015</u> Final Wt <u>0.3381</u> g Tare Wt <u>0.3378</u> g Wt Gain <u>0.3</u> mg Blk Gain <u>0</u> mg Net Wt <u>0.3</u> mg	Filter No. <u>940016</u> Final Wt <u>0.3368</u> g Tare Wt <u>0.3366</u> g Wt Gain <u>0.2</u> mg Blk Gain <u>0</u> mg Net Wt <u>0.2</u> mg	Filter No. _____ Final Wt _____ g Tare Wt _____ g Wt Gain _____ mg Blk Gain _____ mg Net Wt _____ mg
TOTAL PARTICULATE WTS Filter <u>0.5</u> mg Wash <u>14.8</u> mg Total <u>15.3</u> mg	TOTAL PARTICULATE WTS Filter <u>0.3</u> mg Wash <u>2.0</u> mg Total <u>2.3</u> mg	TOTAL PARTICULATE WTS Filter <u>2.1</u> mg Wash <u>0.2</u> mg Total <u>2.3</u> mg	TOTAL PARTICULATE WTS Filter _____ mg Wash _____ mg Total _____ mg

APPENDIX D
Field Data Sheets



Company Marselles Brick

Project _____

Test Location N

Date 5-10-94

Traverse Point Determination — Circular Stacks

Stack Inside Diameter 45 feet

Is diameter greater than 12 inches? Yes / No

Distance Upstream from Disturbance _____ ft / _____ diameters


Distance Downstream from Disturbance _____ ft 5 diameters

Are the ports greater than two diameters downstream and one-half diameter upstream from disturbances? Yes / No

Number of Traverse Points Required (as shown in 40CFR60, Appendix 1, Method 1) 24 points

Number of Traverse Points per Diameter 12

Minimum Number of Traverse Points



Port Extension Length

4.75 inches

Point No.	% of ID From Wall	Distance To Inside Wall	Distance To Outside Port Edge
1	<u>2.1</u>	<u>.945</u>	<u>5.69</u>
2	<u>6.7</u>	<u>3.01</u>	<u>7.76</u>
3	<u>11.8</u>	<u>5.31</u>	<u>10.06</u>
4	<u>17.7</u>	<u>7.96</u>	<u>12.71</u>
5	<u>25.0</u>	<u>11.25</u>	<u>16.0</u>
6	<u>35.6</u>	<u>16.0</u>	<u>20.75</u>
7	<u>49.4</u>	<u>22.98</u>	<u>28.73</u>
8	<u>75.0</u>	<u>33.75</u>	<u>38.5</u>
9	<u>82.3</u>	<u>37.035</u>	<u>41.78</u>
10	<u>88.2</u>	<u>39.69</u>	<u>44.44</u>
11	<u>93.3</u>	<u>41.98</u>	<u>46.73</u>
12	<u>97.9</u>	<u>44.05</u>	<u>48.75</u>

PLANT Marsailles Brick
 CITY, STATE Marsailles IL
 STACK N

PROJECT _____
 TEST SERIES NO. _____
 DATE 5-10-94

VELOCITY TRAVERSE DATA

Run No. _____
 Page _____ of _____

	Glock Time Cyclone	Port # and Point	Stack Temp. °F	ΔP in. H ₂ O	$\sqrt{\Delta P}$
1	0	A 1	92	.49	
2	0	2	93	.40	
3	10 ⁺	3	93	.41	
4	0	4	93	.29	
5	0	5	94	.25	
6	0	6	93	.21	
7	0	B 1	93	.32	
8	0	2	93	.27	
9	0	3	93	.26	
10	0	4	93	.11	
11	0	5	93	.14	
12	0	6	94	.17	
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
AVERAGES			93	.276	0.5253

PITOT TUBE

Number _____
 Coefficient (C_p) .84
 Calibration Date _____

PRESSURES

Barometric 30.26 in. Hg
 Static -.21 in. H₂O
 Stack (P_s) _____ in. Hg

CALCULATIONS

Stack Area (A) 49.75 ft²
 Water Vapor Conc. _____ %

Dry Gas Fraction (DGF)

$$DGF = 1 - (\%H_2O/100) = \underline{\hspace{2cm}}$$

Carbon Dioxide Conc. 0.3 %

Oxygen Concentration 20.4 %

Molecular Weight, Wet (M_s) 28.2797

$$RMS \ p = (\sqrt{\Delta P})^2 \quad \sqrt{\Delta P} = \underline{\hspace{2cm}}$$

Stack Temp. _____ °F + 460 = (T_s) _____ °K

Stack Gas Velocity (V_s)

$$V_s = (\sqrt{(T_s/(P_s \cdot H_s))} / \sqrt{\Delta P}) C_p \cdot 85.43$$

$$V_s = \underline{\hspace{2cm}} \text{ feet/second}$$

Actual Volumetric Flowrate (Q_s)

$$Q_s = 3600 V_s A$$

$$Q_s = \underline{\hspace{2cm}} \text{ acf/hour}$$

$$Q_s/60 = \underline{\hspace{2cm}} \text{ acf/min.}$$

Dry, Standard Volumetric Flowrate (Q_d)

$$Q_d = 17.64 Q_s DGF P_s / T_s$$

$$Q_d = \underline{\hspace{2cm}} \text{ dscf/hour}$$

$$Q_d/60 = \underline{\hspace{2cm}} \text{ dscf/min.}$$

Signature _____


FUGRO

9403

Client: <i>Marselles Brick</i>	Hot Box No.: <i>572 Z</i>	Barometric Pressure: <i>30.09</i>
Location: <i>Marselles 1/L</i>	Cold Box No.: <i>572 Z</i>	Stack Diameter, in: <i>4/5</i>
Source ID: <i>Drier No. 2</i>	Console No.: <i>572 Z</i>	Nozzle Diameter, in: <i>3.0</i>
Project No.: <i>0884-8885</i>	Pilot No.: <i>940014</i>	Filter No.: <i>63</i>
Date: <i>5-11-94</i>	Pilot Coefficient: <i>.84</i>	Ambient Temp.: <i>63</i>
Run Number: <i>1</i>	DGMC Factor: <i>1.001</i>	Static Pressure: <i>-.21</i>
Operator: <i>JTS</i>	Meter a Hg: <i>1.928</i>	K Factor: <i>7.35</i>

Port and Traverse Pointing	Sample Time	Dry Gas Meter Reading	Velocity Head (ft)		Off-gas Pressure Differential (in Hg)		Stack Gas Temperature (°F)		Sample Train Temperature (°F)		Vacuum (in Hg)
			7.2 P	7.2 P	Calcs	Actual	Probe	Filter Box	Impinger	Dry Gas Meter	
1	0	208.421	.411	.6403	3.0135	3.0	92	250	50	63	4
2	2.5	710.825	.39	.6245	2.8665	2.7	95	250	50	64	4
3	5.0	713.040	.31	.5568	2.2785	2.3	95	250	50	64	4
4	7.5	714.900	.22	.4690	1.6170	1.6	94	250	50	64	4
5	10.0	716.640	.19	.4359	1.3965	1.4	95	250	50	64	4
6	12.5	718.240	.13	.3605	0.9555	.95	92	250	50	66	2
7	15.0	719.620	.10	.3162	0.7350	.73	92	250	50	66	2
8	17.5	720.751	.14	.3742	1.0290	1.0	95	250	50	67	2
9	20.0	722.035	.14	.3742	1.0290	1.0	95	249	52	67	2
10	22.5	723.150	.09	.3000	0.6615	.60	95	249	52	68	2
11	25.0	724.700	.18	.4243	1.3230	1.3	95	250	53	69	2
12	27.5	726.260	.28	.4472	1.4700	1.5	95	250	53	70	2
13 B	30.0	727.966	.42	.6481	3.0870	3.1	92	250	53	71	2
14	32.5	730.200	.38	.6164	2.7930	2.8	95	250	53	68	2
15	35.0	732.600	.26	.5099	1.9110	1.9	95	250	53	69	2
16	37.5	734.195	.24	.4899	1.7641	1.8	95	250	53	69	2
Total/Avg											

COMMENTS:

Start 0750

Stop

Flue Gas Analysis

Total	O ₂			CO ₂			H ₂		
	1	2	3	1	2	3	1	2	3
1	20.4	13	0						
2	20.4	3	0						
3	20.4	3	0						
Avg									

Weight Gained

Final Weights	Initial Weights	Weight Gained
130	100	30
125	100	25
100	100	0
277.8	250	27.8
Total Condensate		

Pretest Leak Check @ 20 in Hg for 0.000 CFM

Posttest Leak Check @ 10 in Hg for 0.000 CFM

FUGRO McClelland

Client: *Morseilles Brick*Location: *Morseilles 1C*Source I.D.: *Dier 2*

Project No.:

Date: *5-11-94*Run Number: *Z*Operator: *JTS*Hot Box No.: *57CZ*Cold Box No.: *57CZ*Console No.: *57CZ*

Plot No.:

Plot Coefficient: *.84*DDMC Factor: *1.001*Meter Δ Hg: *1.928*Barometric Pressure: *30.09*Stack Diameter, in: *45*Nozzle Diameter, in: *.30*Filter No.: *940015*Ambient Temp.: *67*Static Pressure: *-.21*K Factor: *7.52*

Operator: JTS		Meter & Model: 1.92B		K Factor: 7.52.								
Port and Traverse Point No.	Sample Time	Dry Gas Mole Reading	Velocity Head (ft/s)		Orifice Pressure Differential (in Hg)		Stack Gas Temperature (°F)	Sample Train Temperature (°F)		Dry Gas Mole	Vacuum (in Hg)	
			AP	VAP	Calc	Actual		Probe	Filter Box			Impinger
1 A	0	762.500	.45	.6708	3.384	3.4	95	250	250	50	77	4
2	2.5	264.751	.41	.6403	3.0832	3.1	95	250	250	50	78	2
3	5.0	767.250	.35	.5916	2.6220	2.6	94	249	250	50	79	2
4	7.5	769.375	.27	.5196	2.0304	2.0	95	249	250	50	80	2
5	10.0	771.240	.18	.4243	1.3536	1.3	95	250	250	51	80	2
6	12.5	772.910	.13	.3605	.9776	.8	95	249	250	52	81	2
7	15.0	774.300	.10	.3162	.7520	.75	94	250	250	52	81	2
8	17.5	775.525	.124	.4899	1.8018	1.8	94	251	250	52	81	2
9	20.0	777.400	.29	.5385	2.1808	2.2	94	250	250	52	82	2
10	22.5	779.290	.26	.5099	1.9552	1.9	95	250	250	52	82	2
11	25.0	781.351	.18	.4243	1.3536	1.3	95	249	250	53	83	2
12	27.5	782.540	.35	.5416	2.632	2.6	95	250	250	54	83	2
13 B	30.0	784.660	.50	.7071	3.8000	3.8	94	250	250	51	83	2
14	32.5	787.285	.50	.7071	3.8000	3.8	94	250	251	50	84	2
15	35.0	789.990	.42	.6481	3.1920	3.2	95	250	251	50	84	2
16	37.5	792.340	.31	.5668	2.3560	2.3	95	250	250	51	85	2
Total Avg												

COMMENTS:

Start *0930*Stop *1033** Change K factor - *7.60*Pretest Leak Check @ *10* Hg for *0.000* CFMPosttest Leak Check @ *10* Hg for *0.000* CFM

Fluo Gas Analysis

Tidal	O ₂			CO			N ₂		
	1	2	3	1	2	3	1	2	3
1	20.4	30	0	0	0	0	0	0	0
2	20.4	30	0	0	0	0	0	0	0
3	20.4	30	0	0	0	0	0	0	0
Avg									

	Final Weights	Initial Weights	Weight Gained
First Impinger	132	100	32
Second Impinger	124	100	24
Third Impinger	0	100	0
Etica Oil	265.4	250	15.4
Total Condensate			

[illegible]



Client: <i>Morseilles Bank</i>	Hot Box No.: <i>5722</i>	Barometric Pressure: <i>30.09</i>
Location: <i>Morseilles LC</i>	Cold Box No.: <i>5722</i>	Stack Diameter, in: <i>45"</i>
Source ID.: <i>Diner 2</i>	Console No.: <i>5722</i>	Nozzle Diameter, in: <i>3.0</i>
Project No.:	Pilot No.:	Filter No.: <i>940016</i>
Date: <i>5.11.94</i>	Pilot Coefficient: <i>.84</i>	Ambient Temp.: <i>68</i>
Run Number: <i>3</i>	DGMC Factor: <i>1.001</i>	Static Pressure: <i>-.21</i>
Operator: <i>JTS</i>	Meter A No.: <i>1.928</i>	K Factor: <i>7.52</i>

[illegible]

	Final Weights	Initial Weights	Weight Gained	Flue Gas Analysis						COMMENTS:	
				Total	O ₂	CO ₂	CO	H ₂			
First Impinger	130	100	30	1	20.1	3	0			Start 1100	
Second Impinger	122	100	22	2	20.1	3	0			Stop 1212	
Third Impinger	100	100	0	3	20.1	3	0				
Slime Out	267.5	250	17.5	AVG							
Total Condensate											
				Pretest Leak Check ●		10		Hg for		0.000 CFM	
				Posttest Leak Check ●		20		Hg for		0.900 CFM	



Company Marseilles Brick

Project _____

Test Location Drier #2

Date 5-11-94

Traverse Point Determination — Circular Stacks

Stack Inside Diameter 45" feet

Is diameter greater than 12 inches? Yes / No

Distance Upstream from Disturbance _____ ft 1 diameters


Distance Downstream from Disturbance _____ ft 5 diameters

Are the ports greater than two diameters downstream and one-half diameter upstream from disturbances? Yes / No

Number of Traverse Points Required (as shown in 40CFR60, Appendix A, Method 1) 24 points

Number of Traverse Points per Diameter 12


Minimum Number of Traverse Points



Port Extension Length

5 inches

Point No.	% of ID From Wall	Distance To Inside Wall	Distance To Outside Port Edge
1	<u>2.1</u>	<u>0.945</u>	<u>5.94</u>
2	<u>6.7</u>	<u>3.015</u>	<u>8.01</u>
3	<u>11.8</u>	<u>5.31</u>	<u>10.31</u>
4	<u>17.7</u>	<u>7.96</u>	<u>12.96</u>
5	<u>25.0</u>	<u>11.25</u>	<u>16.25</u>
6	<u>35.0</u>	<u>16.02</u>	<u>21.02</u>
7	<u>47.4</u>	<u>29.48</u>	<u>33.98</u>
8	<u>75.0</u>	<u>33.75</u>	<u>38.75</u>
9	<u>82.3</u>	<u>37.035</u>	<u>42.03</u>
10	<u>88.2</u>	<u>39.69</u>	<u>44.69</u>
11	<u>93.3</u>	<u>41.98</u>	<u>46.98</u>
12	<u>97.9</u>	<u>44.05</u>	<u>49.05</u>



Page of

96.93

Client: <i>Marsailles Back</i>	Hot Box No.: <i>STK2</i>	Barometric Pressure: <i>29.85</i>
Location: <i>Marsailles IL</i>	Cold Box No.: <i>STK2</i>	Stack Diameter, in: <i>41</i>
Source ID: <i>K.Ln Exhaust</i>	Console No.: <i>STK2</i>	Nozzle Diameter, in: <i>37</i>
Project No.: <i></i>	Pilot No.: <i></i>	Filter No.: <i>940017</i>
Date: <i>5-11-94</i>	Pilot Coefficient: <i>84</i>	Ambient Temp.: <i>89</i>
Run Number: <i>1</i>	DOHC Factor: <i>1.001</i>	Static Pressure: <i>-11</i>
Operator: <i>JTS</i>	Meter & H ₂ O: <i>1.928</i>	K Factor: <i>11.28</i>

Port and Traverse Point No.	Sample Time	Dr. (Gas) Meter Reading	Velocity Head (H ₂ O)		Orifice Pressure Differential (H ₂ O)		Stack Gas Temperature (°F)		Sample Train Temperatures (°F)			Vacuum (in. Hg)
			Up	Down	Calcd	Actual	Probo	Filter Box	Last Impinger	PPV Gas Meter		
1	0	872.150	.17	.4123	1.9176	1.9	468	250	49	82	2	
2	2.8	874.010	.20	.4472	2.256	2.2	480	250	50	82	2	
3	5.6	876.125	.20	.4472	2.256	2.2	483	250	50	82	2	
4	8.4	878.130	.20	.4472	2.256	2.2	487	250	50	83	2	
5	11.2	880.520	.18	.4243	2.0304	2.0	488	249	51	86	2	
6	14.0	882.950	.15	.3873	1.6920	1.7	491	250	51	87	2	
7	16.8	884.820	.14	.3741	1.5792	1.6	490	250	51	87	2	
8 B	19.6	886.570	.14	.3741	1.5792	1.6	485	250	52	89	2	
9	22.4	888.300	.18	.4243	2.0304	2.0	455	250	52	89	2	
10	25.2	890.410	.16	.4000	1.8048	1.8	462	250	52	89	2	
11	28.0	892.440	.17	.4123	1.9176	1.9	466	250	53	89	2	
12	30.8	894.515	.26	.5099	2.9328	2.9	467	250	52	90	2	
13	33.6	896.890	.27	.5196	3.0456	3.0	476	250	54	90	2	
14 *	36.4	899.600	.27	.5196	3.0888	3.1	480	250	54	91	2	
15 C	39.2	901.420	.27	.5196		3.1	486	250	56	92	2	
16	42.0	905.900	.25	.5000	2.860	2.9	486	250	57	92	2	
Total Avg												

K Factor: 11.28

COMMENTS:

Sheet 1513

Stack 1623

* Change K-Factor 11.44

Prelim Last Check 10. "Hg for 0.0000CFM

Posttest Last Check 0

Flue Gas Analysis

	O ₂	CO ₂	CO	H ₂
Total				
1	17.8	1.8	0	
2	17.8	1.8	0	
3	17.8	1.8	0	
Avg				

Weight Gained


Initial Weights

Final Weights

	Weight Gained	Initial Weights	Final Weights
First Impinger	20	100	120
Second Impinger	15	100	115
Third Impinger	0	100	100
Since Od	39.5	250	289.5
Total Condensate			

2021

[illegible]



92.87

Client: *Marcellus Brick*
 Location: *Merseilles IL*
 Source ID: *Kila Exhaust*
 Project No.:
 Date: *5-11-94*
 Run Number: *2*
 Operator: *JTS*

Hot Box No.: *STL 2*
 Cold Box No.: *STL 2*
 Console No.: *STL 2*
 Plot No.:
 Plot Coefficient: *.84*
 DDMC Factor: *1.001*
 Meter a Hot: *1.928*
 Barometric Pressure: *29.85*
 Stack Diameter, in: *41*
 Nozzle Diameter, in: *3.7*
 Filter No.: *940018*
 Ambient Temp.: *69*
 Static Pressure: *-.11*
 K Factor: *10.70*

Portland Cement Port No.	Sample Time	Dry Gas Meter Reading	Velocity Head (ft)		Orifice Pressure Differential (in H ₂ O)		Stack Gas Temperature (°F)	Sample Train Temperatures (°F)			Vacuum (in Hg)	
			Velocity		Orifice Pressure			Probo	Filter Box	Last Impinger Gas		
			AP	VAP	Calc.	Actual						
1	0	935.121	.28	.5291	2.9960	3.0	486	250	280	50	90	2
2	2.8	937.990	.28	.5291	2.9960	3.0	487	250	250	80	91	2
3	5.6	940.120	.28	.5291	2.9960	3.0	488	250	250	52	91	2
4	8.4	943.210	.30	.5477	3.2400	3.2	491	250	250	51	92	2
5	11.2	946.100	.25	.5000	2.6750	2.7	495	250	250	52	92	2
6	14.0	948.230	.27	.5196	2.8890	2.9	496	250	250	52	93	2
7	16.8	950.920	.27	.5196	2.8890	2.9	498	250	250	53	94	2
8	19.6	953.100	.24	.4899	2.528	2.6	493	250	250	54	94	2
9	22.4	955.890	.28	.5291	2.9960	3.0	440	250	250	54	94	2
10	25.2	958.190	.26	.5099	2.7820	2.8	463	247	249	55	95	2
11	28.0	961.200	.28	.5291	2.9960	3.0	468	248	250	56	97	2
12	30.8	963.420	.31	.5568	3.317	3.3	471	250	250	57	97	2
13	33.6	965.900	.32	.5657	3.421	3.4	472	250	250	60	98	2
14	36.4	968.857	.15	.3873	1.605	1.6	445	250	250	60	96	2
15	39.2	971.009	.17	.4123	1.819	1.8	477	250	251	60	96	2
16	42.0	972.620	.20	.4472	2.1400	2.1	481	250	251	60	97	2
Total Avg												

COMMENTS:									
Start - 1700									
Stop - 1804									
Pretest Leak Check @ 10 "Hg for 0.00 CFM									
Posttest Leak Check @									

Flue Gas Analysis									
		Total	O ₂	CO ₂	CO	N ₂			
First Impinger		1	17.8	1.8					
Second Impinger		2	17.8	1.8					
Third Impinger		3	17.8	1.8					
Seals Od									
AVG									

Final Weights	Initial Weights	Weight Gained
129	100	29
117	100	14
0	100	0
280.6	250	30.6
Total Condensate		

FUGRO  **McClelland**

Client: *Marseilles Beach*
 Location: *Marseilles, IL*
 Source ID: *K. In Excess*
 Project No.:
 Date: *5-11-94*
 Run Number: *3*
 Operator: *JTS*

Hot Box No:	STL 2	Barometric Pressure:	29.85
Cold Box No:	STL 2	Stack Diameter, in:	41'
Console No:	STL 2	Nozzle Diameter, in:	.37
Pilot No:		Filter No:	940019
Pilot Coefficient:	.84	Ambient Temp:	69
DMC Factor:	1.001	Static Pressure:	-.11
Meter a H ₂ O:	1.928	K Factor:	0.65

Portland Cement Favorable Point No.	Sample Time	Dry Gas Water Reading	Velocity (ft/min)	Orifice Pressure (H ₂ O)		Stack Gas Temperature (F)		Filter Box	Last Impeller Gage	Vacuum (H ₂ O)
				Calc	Actual	Static	Dynamic			
1 A	0	991.447	.15	1.3873	1.5975	1.6	477	250	50	92
2	2.0	993.260	.15	1.3873	1.5975	1.6	482	249	50	93
3	5.0	995.101	.15	1.3873	1.5975	1.6	480	250	51	94
4	8.4	996.875	.16	1.4000	1.7040	1.7	488	251	53	95
5	11.2	999.010	.15	1.3873	1.5975	1.6	490	250	54	93
6	14.0	1000.610	.14	1.3742	1.491	1.5	493	250	55	93
7	16.8	1002.411	.15	1.3873	1.5975	1.6	477	251	56	94
8 B	19.6	1004.150	.14	1.3742	1.491	1.5	440	252	57	94
9	22.4	1005.990	.14	1.3742	1.491	1.5	456	250	57	95
10	25.2	1007.921	.20	1.4472	2.13	2.1	459	250	59	93
11	28.0	1009.851	.15	1.3873	1.5975	1.6	461	250	60	93
12	30.8	1011.401	.16	1.4000	1.7040	1.7	463	250	60	94
13	33.6	1013.500	.20	1.4472	2.13	2.1	464	250	62	94
14	36.4	1015.862	.25	1.5000	2.6625	2.7	465	250	63	95
15 C	39.2	1018.320	.30	1.5477	3.1450	3.2	471	250	60	95
16	42.0	1021.150	.30	1.5477	3.1450	3.2	473	250	60	95
Total Avg										

COMMENTS:

START - 1840
 STOP 1943

Flue Gas Analysis

Total	O ₂	CO ₂	CO	N ₂
1	17.8	1.8	0	
2	17.8	1.8	0	
3	17.8	1.8	0	
Avg				

Weight Gained

Final Weights	Initial Weights	Weight Gained
First Impinger	12.1	2.1
Second Impinger	11.8	1.8
Third Impinger	10.0	0
Sum of	33.9	24.6
Total Condensate		

Pretest Leak Check 10 "Hg for 6000 CFM

[illegible]



Company _____ Project _____

Test Location Kila Exposed Date 5.11.94

Traverse Point Determination Circular Stacks

Stack Inside Diameter 41" feet

Is diameter greater than 12 inches? Yes / No

Distance Upstream from Disturbance .7 ft 2 diameters


Distance Downstream from Disturbance 20 ft 5 diameters

Are the ports greater than two diameters downstream and one-half diameter upstream from disturbances? Yes / No

Number of Traverse Points Required (as shown in 40CFR60, Appendix A, Method 1) _____ points

Number of Traverse Points per Diameter _____

Minimum Number of Traverse Points



Port Extension Length

20 inches

Point No.	% of ID From Wall	Distance To Inside Wall	Distance To Outside Port Edge
1	_____	_____	_____
2	_____	_____	_____
3	_____	_____	_____
4	_____	_____	_____
5	_____	_____	_____
6	_____	_____	_____
7	_____	_____	_____
8	_____	_____	_____
9	_____	_____	_____
10	_____	_____	_____
11	_____	_____	_____
12	_____	_____	_____

5.8

PLANT Marselles Brick

PROJECT _____

CITY, STATE Marselles IL

TEST SERIES NO. _____

STACK Kiln Exhaust

DATE _____

VELOCITY TRAVERSE DATA

Run No. _____

Page _____ of _____

	Clock Time <i>Cyclone</i>	Port # and Point	Stack Temp. °F	Δp in. H ₂ O	$\sqrt{\Delta p}$
1	0		472	.22	
2	0		474	.25	
3	0		475	.25	
4	0		477	.24	
5	0		479	.25	
6	0		480	.23	
7	0		480	.24	
8	0		470	.15	
9	0		472	.15	
10	0		477	.16	
11	0		479	.15	
12	0		481	.13	
13	0		481	.10	
14	0		482	.10	
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
AVERAGES			.177	.18	0.4243

PITOT TUBE

Number _____

Coefficient (C_p) .87

Calibration Date _____

PRESSURES

Barometric 29.85 in. HgStatic -.11 in. H₂OStack (P_s) 41" in. Hg

CALCULATIONS

Stack Area (A) _____ ft²Water Vapor Conc. 5 %

Dry Gas Fraction (DGF)

DGF = $1 - (\%H_2O/100) =$ _____Carbon Dioxide Conc. 1.8 %Oxygen Concentration 17.8 %Molecular Weight, Wet (M_w) 28.4500RMS $p = (\sqrt{\Delta p})^2 = \sqrt{\Delta p} =$ _____Stack Temp. _____ °F + 460 = (T_s) _____ °RStack Gas Velocity (V_s) $V_s = (\sqrt{T_s/(P_s \times C_p)})(\sqrt{\Delta p}) C_p$ 85.49 $V_s =$ _____ feet/secondActual Volumetric Flowrate (Q_s) $Q_s = 3600 V_s A$ $Q_s =$ _____ acf/hour $Q_s/60 =$ _____ acf/min.Dry, Standard Volumetric Flowrate (Q_d) $Q_d = 17.64 Q_s \text{ DGF } P_s / T_s$ $Q_d =$ _____ dscf/hour $Q_d/60 =$ _____ dscf/min.

Signature _____



43.09

Client: *Marseilles Brack*
 Location: *Marseilles LC*
 Source ID: *N*
 Project No.:
 Date: *5-10-94*
 Run Number: *1*
 Operator: *JTS*

Hot Box No.: *57L2*
 Cold Box No.: *57L2*
 Console No.: *57L2*
 Plot No.:
 Pilot Contolent: *84*
 DDMC Factor: *1.001*
 Meter # Hg: *1.928*
 Biomatic Pressure: *30.26*
 Stack Diameter, in: *49.75*
 Nozzle Diameter, in: *.30*
 Filter No.: *940011*
 Ambient Temp.: *74*
 Static Pressure: *-.21*
 K Factor: *8.15*

Port and Sample Container	Sample Time	Dry Gas Weight Reading	Velocity Head (ft H ₂ O)	Officer's Reading (ft H ₂ O)	Stack Gas Temperature (°F)	Sample Train Temperatures (°F)				Vacuum (in Hg)
						Probe	Filter Box	Impact	DP Gage	
1 A	0	540.300	.42	.6481	90	250	250	54	72	3
2	2.5	542.130	.35	.5916	91	250	250	55	73	2
3	5.0	545.500	.27	.5196	91	250	250	56	76	2
4	7.5	547.000	.17	.4123	91	250	250	56	76	2
5	10.0	548.52	.10	.3162	91	250	250	56	76	2
6	12.5	549.610	.07	.2646	91	250	250	56	77	2
7	15.0	550.620	.07	.2646	91	250	250	57	78	2
8	17.5	551.691	.08	.2828	91	250	250	57	79	2
9	20.0	553.100	.32	.2651	93	250	250	58	79	2
10	22.5	554.500	.21	.4582	93	250	250	59	80	2
11	25.0	555.880	.16	.4000	93	250	250	59	81	2
12	27.5	557.300	.16	.4000	93	249	250	59	81	2
13 B	30.0	558.800	.11	.3317	93	250	250	59	84	2
14	32.5	560.020	.45	.6708	93	250	250	60	84	2
15	35.0	562.750	.47	.6856	93	251	250	60	86	2
16	37.5	564.990	.41		93	249	249	61	88	4
Total/Avg				3.378	93	250	251	62	89	4

COMMENTS:

Start 1253

Stop 1400

Change to 8.24

Flue Gas Analysis

THW	O ₂	CO ₂	CO	N ₂
1	20.4	.03		
2	20.4	.03		
3	20.4	.03		
Avg				

	Final Weights	Initial Weights	Weight Gained
First Impinger	130	100	30
Second Impinger	130	100	30
Third Impinger	105	100	5
Blank Oil	275.4	250	25.4
Total Condensate			

Pretest Leak Check 10 "Hg for 0.000 CFM

Posttest Leak Check 10 "Hg for 0.000 CFM

[illegible]

FUGRO McClelland

93.48

Client: *Maxwell Bruck*Location: *Marshall IL*Source ID: *Dier 1*

Project No.:

Date: *5-10-94*Run Number: *2*Operator: *JTS*Hot Box No.: *STL 2*Cold Box No.: *STL 2*Console No.: *STL 2*

Plot No.:

Plot Coefficient: *.84*DOMC Factor: *1.88001*Meter a Hg: *1.928*Baromide Pressure: *30.26*Stack Diameter, in: *45*Nozzle Diameter, in: *.30*Filter No.: *940012*Ambient Temp.: *75*Static Pressure: *-.21*K Factor: *7.69*

Point No.	Sample Time	Dry Gas Meter Reading	Velocity Head (ftH ₂ O)		Orifice Pressure Differential (ftH ₂ O)		Stack Gas Temperature (°F)		Sample Train Temperature (°F)		Vacuum (inHg)	
			Calc.	Actual	Calc.	Actual	Flue Box	Probe	Flue Box	Impinger	Flue Box	Probe
1A	0	591.384	.45		3.4605	3.5	94	250	250	58	90	2
2	2.5	593.300	.50		3.845	3.8	95	250	250	58	93	4
3	5.0	595.920	.48		3.691	3.7	95	250	250	54	94	4
4	7.5	598.700	.44		3.384	3.4	95	250	251	58	95	4
5	10.0	601.200	.34		2.614	2.6	95	250	250	60	95	4
6	12.5	603.400	.21		1.615	1.615	95	250	250	60	95	4
7	15.0	605.151	.22		1.692	1.7	94	251	250	61	95	4
8	17.5	606.510	.30		2.307	2.3	94	250	250	62	96	2
9	20.0	608.800	.27		2.076	2.0	94	250	250	63	97	2
10	22.5	610.800	.20		1.472	1.5	95	250	249	63	98	2
11*	25.0	612.270	.25		1.9425	1.9	94	250	250	63	98	2
12	27.5	613.950	.25		1.9425	1.9	94	250	250	60	98	2
13B	30.0	615.828	.31		2.4087	2.4	94	250	250	60	98	2
14	32.5	617.510	.35		2.719	2.7	94	251	250	61	97	2
15	35.0	620.201	.26		2.020	2.0	94	251	250	61	97	2
16	37.5	622.100	.22		1.709	1.7	94	250	249	62	97	2
Total/Avg												

COMMENTS:

Start *1448*Stop *1553** Change K Factor *7.77*Pretest Leak Check H₂ for*H₂ for

0-0000CFM

Posttest Leak Check *H₂ for

0-0000CFM

Flue Gas Analysis

	O ₂	CO ₂	CO	N ₂
Total				
1	20.4	0.3	0	
2	20.4	0.3	0	
3	20.4	0.3	0	
Avg				

	Final Weights	Initial Weights	Weight Gained
First Impinger	130	100	30
Second Impinger	127	100	27
Third Impinger	5	100	5
Effluent	272.3	250	22.3
Total Condensate			

Point No.	Sample Weight (g)	Gas Motor Reading	Velocity (ft/sec)		Grain Diameter (mm)	Grain Temperature (°C)	Grain Temperature (°F)	Grain Temperature (°C)	Grain Temperature (°F)	Grain Temperature (°C)	Grain Temperature (°F)	Grain Temperature (°C)	Grain Temperature (°F)
			P	V									
17	40.0	623.900	.19	.4359	1.4763	1.5	94	250	62	98	2		
18	42.5	625.800	.11	.3317	.8547	.85	95	250	63	98	2		
19	45.0	627.150	.27	.5196	2.098	2.1	94	250	63	98	2		
20	47.5	628.870	.39	.6245	3.2329	3.2	94	250	64	98	2		
21	50.0	631.851	.27	.5196	2.098	2.1	94	250	64	98	2		
22	52.5	633.400	.27	.5196	2.098	2.1	94	250	60	98	2		
23	55.0	635.310	.41	.7000	4.0619	4.1	94	250	61	99	2		
24	57.5	637.800	.31	.5831	2.8185	2.8	94	250	61	99	2		
25	60.0	639.850											
												</	

FUGRO McClelland

96

Client: *Marselles East*Location: *Marselles 16*Source I.D.: *Ducc #1*Project No.: *C*Date: *8-10-94*Run Number: *3*Operator: *JTS*Hot Box No.: *572 Z*Cold Box No.: *572 Z*Console No.: *572 Z*Plot No.: *C*Plot Coefficient: *.84*DDMO Factor: *1.0001*Meter #HQ: *1.828*Barometric Pressure: *30.26*Stack Diameter, in: *45*Nozzle Diameter, in: *.30*Filter No.: *940013*Ambient Temp.: *75*Static Pressure: *-.21*K Factor: *7.79*

Port and Traverse Point No.		Sample Time	Dry Gas Meter Reading	Velocity Head (ft/s)		Office Pressure Differential (in Hg)		Stack Gas Temperature (°F)		Sample Train Temperature (°F)			Vacuum (in Hg)
				AP	VP	Calc.	Actual	Temp. (°F)	Probe	Filter Box	Impinger	Dry Gas Meter	
A	1	0	653.160	.45	1.6708	3.505	3.5	94	250	251	50	92	4
	2	2.5	655.529	.41	1.6403	3.193	3.2	94	250	250	51	92	4
	3	5.0	658.010	.31	1.5568	2.4144	2.4	94	251	249	50	93	4
	4	7.5	660.105	.22	1.4690	1.7138	1.7	94	251	250	51	95	2
	5	10.0	662.050	.15	1.3873	1.685	1.7	94	251	251	52	95	2
	6	12.5	663.957	.14	1.3742	1.0906	1.1	94	250	251	52	95	2
	7	15.0	665.420	.17	1.423	1.324	1.3	94	250	250	53	95	2
	8	17.5	666.950	.23	1.496	1.791	1.8	95	250	250	53	96	2
	9	20.0	668.686	.22	1.490	1.7138	1.7	95	250	250	54	96	2
	10	22.5	670.400	.34	1.5831	2.1448	2.6	95	250	251	54	97	2
	11	25.0	672.500	.31	1.5568	2.444	2.4	94	250	250	55	98	2
	12	27.5	674.590	.22	1.4690	2.1791	1.8	94	250	250	55	98	2
B	13	30.0	676.700	.43	1.6557	3.3497	3.3	94	250	250	55	98	2
	14	32.5	679.010	.39	1.6245	3.038	3.0	94	250	251	57	100	2
	15	35.0	681.460	.37	1.6083	2.882	2.9	94	250	250	58	100	2
	16	37.5	682.951	.22	1.4890	1.7138	1.7	94	250	250	59	100	2
Total/Avg													

Meter & Hg#	1.928	K Factor	7.79
-------------	-------	----------	------

COMMENTS:

Start *1630*Stop *1633*

Flue Gas Analysis

	O ₂	CO ₂	CO	H ₂
Total				
1	20.4	.03	0	
2	20.4	.03	0	
3	20.4	.03	0	
AVG				

	Final Weights	Initial Weights	Weight Gained
First Impinger	132	100	32
Second Impinger	130	100	30
Third Impinger	105	100	5
Silica Gel	268.2	250	18.2
Total Condensate			

Pretest Leak Check ☒ *0* *0.000* CFMPosttest Leak Check ☒ *0* *0.000* CFM


Portland Traverse Point No.	Sample Time	Dr. Gas Meter Reading	Volatility (HFO)		Gravimetric Distillation (GHD)		Stack Gas Temperature (°C)	Sampling Temperature (°F)		Vacuum (in Hg)	
			P	VAP	Gals	Actual		Probe	Filler Box		
17	40.0	685.520	.14	.3742	1.0906	1.1	94	250	59	100	2
18	42.8	687.060	.12	.3464	.9348	.93	94	250	59	100	2
19	45.0	688.451	.15	.3873	1.1685	1.2	94	250	59	100	2
20	47.5	689.990	.24	.4879	1.8696	1.7	94	249	60	97	2
21	50.0	691.600	.31	.5568	2.414	2.4	94	250	61	97	2
22	52.5	693.650	.36	.6000	2.8094	2.8	94	250	62	97	2
23	55.0	695.757	.41	.6403	3.1939	3.2	94	250	63	97	2
24	57.5	698.010	.45	.6708	3.5056	3.5	94	250	64	97	2
25	60.0	701.520									

APPENDIX E
Equipment Calibration Records






TYPE S PITOT TUBE CALIBRATION

PITOT TUBE 5-1ss
DATE 4-11-94



Are a_1 and $a_2 < 10^\circ$? ☒ Yes ☐ No
Are B_1 and $B_2 < 5^\circ$? ☒ Yes ☐ No
Is $Z < 1/8$ inch? ☒ Yes ☐ No
Is $W < 1/32$ inch? ☒ Yes ☐ No



External tube diameter (D_c) .3705

Is D_c between $3/16$ and $3/8$ in.? ☒ Yes ☐ No

Base-to-opening plane distances:

P_A .401
 P_B .401

Does $P_A = P_B$? ☒ Yes ☐ No

Is $1.05 D_c \leq P \leq 1.50 D_c$?

.377 < .401 < .568 ☒ Yes ☐ No

When pitot tube is part of an assembly:

Is the thermocouple 2 inches behind the pitot tube opening? ☒ Yes ☐ No

Does the pitot tube extend 3 inches beyond the compression fitting on the nozzle? ☒ Yes ☐ No

Is the distance between the nozzle and the pitot tube more than $3/4$ inch when a $1/2$ inch nozzle is in place? ☒ Yes ☐ No

If any answer is no, the pitot tube must be calibrated in a wind tunnel against a standard type pitot tube.

If all answers are yes, the pitot tube may be assigned a baseline coefficient of 0.84.

Assigned Baseline Coefficient 0.84

Signature Daniel M. Khan

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 1-6-94 Thermocouple number 5-1

Ambient temperature 23.0 °C Barometric pressure 29.74 in. Hg

Calibrator D.M.C Reference: mercury-in-glass Fisher Scientific #15-041A
other _____

Reference point number	Source ^a (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, ^b %
100°C	Water	100°C	97.78	0.006
0°C	Ice Water	0.000°C	0.000°C	0.000
—	Oil	219.44°C	219.44°C	0.000

^aType of calibration system used.

^b
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$



Dry Gas Meter and Orifice Calibration

Dry Gas Meter or Console Number 5722 Date 5-4-94
Barometric Pressure (not corrected to sea level pressure), $P_b = 30.09$ in. Hg

ΔH	Dry Gas Meter				Wet Test Meter						Time		γ	$\Delta H @$			
	Volume, cu.ft.		Temp.	Press	Volume, cu.ft.		Temp.	Δ	$^{\circ}F$	$^{\circ}R$	' & "	min.					
	Final	Init.	Δ	V_d	$^{\circ}F$	$^{\circ}R$	T_d								P_{in}	Final	Init.
.5	490.00	480.00	10.00	78	538	30.127	48.237	38.107	10.13		68	528		25.4	1.031	1.716	
1.0	500.00	490.00	10.00	83	543	30.164	58.141	48.237	9.904		68	528		18.3	1.016	1.847	
1.5	510.00	500.00	10.00	84	544	30.200	67.900	58.141	9.759		68	528		15.2	1.001	1.965	
2.0	520.03	510.01	10.003	89	549	30.237	77.578	67.900	9.618		68	528		13.1	0.995	1.985	
2.5	530.06	520.03	10.003	91	551	30.274	87.016	77.578	9.478		68	528		11.6	0.985	1.988	
3.0	540.08	530.06	10.002	95	555	30.311	96.394	87.016	9.378		68	528		10.7	0.978	2.067	
Average											1.001		1.928				

Signature Daniel M. Lewis

$$P_m = (\Delta H + 13.6) + P_b$$

$$^{\circ}P = (^{\circ}O \times 9 \div 5) + 32$$

$$^{\circ}R = ^{\circ}F + 460$$

$$\gamma = \frac{V_w P_b T_d}{V_d P_m T_w}$$

$$\Delta H @ = \left(\frac{T_w \theta^2}{V_w} \right) \frac{0.0317 \Delta H}{P_b T_d}$$

γ is the ratio of accuracy of the wet test meter to the dry gas meter and its tolerance limits are ± 0.02 from 1.00.

$\Delta H @$ is the orifice differential pressure which gives an air flow rate of 0.75 cfm at 70°F and 29.92 inches of mercury. It had tolerance limits of ± 0.20 in. H₂O from 1.84.



213-585-2154
FAX# 213-585-0582

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

5700 SOUTH ALAMEDA STREET • LOS ANGELES, CALIFORNIA 90058

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER ENV. & INDUST. DIST.

P.O NUMBER 031694-2

REFERENCE STANDARD

COMPONENT	NIST SRM NO.	CYLINDER NO.	CONCENTRATION
PROPANE	GMIS vs 2645a	SA 5908	497 ppm

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT	PROPANE	GMIS	ANALYZER MAKE-MODEL-S/N	HP 5890 SERIES 11	S/N 3310A48533
ANALYTICAL PRINCIPLE	GC/ FLAME IONIZATION			LAST CALIBRATION DATE	03/11/94
FIRST ANALYSIS DATE	04/08/94			SECOND ANALYSIS DATE	
Z 0	R 519884	C 526732	CONC. 497 ppm	Z	R C CONC.
R 521351	Z 0	C 526817	CONC. 496 ppm	R	Z C CONC.
Z 0	C 527344	R 520672	CONC. 497 ppm	Z	C R CONC.
U/M uv		MEAN TEST ASSAY	497 ppm	U/M uv	MEAN TEST ASSAY

THIS CYLINDER NO. SA 5143
HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4
OF TRACEABILITY PROTOCOL NO. 1
PROCEDURE G1
CERTIFIED ACCURACY ± 1 % NIST TRACEABLE
CYLINDER PRESSURE 2000 PSIG
CERTIFICATION DATE 04/08/94
EXPIRATION DATE 04/08/97 TERM 36 MONTHS

CERTIFIED CONCENTRATION
PROPANE 497 ppm
ZERO AIR BALANCE

ANALYZED BY

W. E. Bohm
W. E. BOHM

CERTIFIED BY

T. J. Triplett
T. J. TRIPLETT



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(313) 589-2950 FAX: (313) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
FURGO MCCLELLAND
CHRIS DAWDY
9921 ST CHARLES ROCK RD
ST ANN MO 63074

Assay Laboratory
Scott Specialty Gases, Inc.
1290 Combermere
Troy, MI 48083

Purchase Order H145-2
Scott Project # 547552

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol 1 Procedure #G1, Section Number 3.0.4

Cylinder Number ALM030957
Cylinder Pressure 1900 psig

Certification Date 2-18-93
Previous Certification Dates None

Expiration Date 8-18-94

ANALYZED CYLINDER

Components
Propane

Certified Concentration
30.68 ppm

Analytical Uncertainty*
±1% NIST Directly Traceable

Balance Gas: Nitrogen

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type SRM 2643A
Expiration Date 10-14-95

Cylinder Number
SX-20305

Concentration
99.12 ppm Propane in N₂

INSTRUMENTATION

Instrument/Model/Serial #
Prop: Beckman/400/1002059

Last Date Calibrated
1-25-93

Analytical Principle
Flame Ionization Detector

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Second Triad Analysis

Calibration Curve

Propane

Date: 2-18-93 Response Units: mv
Z1=0.00 R1=99.10 T1=30.70
R2=99.10 Z2=0.00 T2=30.70
Z3=0.00 T3=30.70 R3=99.10
Avg. Conc. of Cust. Cyl. 30.68 ppm

Concentration=A+Bx+Cx²+Dx³+Ex⁴
r=0.99999 SRM 2643A
Constants: A=-0.03442105
B=1.000549 C=0
D=0 E=0

Concentration=A+Bx+Cx²+Dx³+Ex⁴

Concentration=A+Bx+Cx²+Dx³+Ex⁴

Special Notes

Analyst Tim S. Jerson



213-585-2154
FAX# 213-585-0582

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

5700 SOUTH ALAMEDA STREET • LOS ANGELES, CALIFORNIA 90058

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER ENV. & INDUST. DIST.

P.O NUMBER 092393-2

REFERENCE STANDARD

COMPONENT
NITRIC OXIDE GHIS

NIST SRM NO.
vs. 1687b

CYLINDER NO.
CC56971

CONCENTRATION
485 ppm

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT		NITRIC OXIDE		GHIS		ANALYZER MAKE-MODEL-S/N		Beckman 951A		S/N 0101354			
ANALYTICAL PRINCIPLE				Chemiluminescence				LAST CALIBRATION DATE				08/27/93	
FIRST ANALYSIS DATE				10/04/93				SECOND ANALYSIS DATE				10/11/93	
Z 0		R 485		C 356		CONC. 356 ppm		Z 0		R 487		C 354	CONC. 353 ppm
R 485		Z 0		C 356		CONC. 356 ppm		R 487		Z 0		C 356	CONC. 355 ppm
Z 0		C 356		R 485		CONC. 356 ppm		Z 0		C 358		R 488	CONC. 356 ppm
U/M mV				MEAN TEST ASSAY		356 ppm		U/M mV				MEAN TEST ASSAY	355 ppm

THIS CYLINDER NO. SA 8379
HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4
OF TRACEABILITY PROTOCOL NO. 1
PROCEDURE G1
CERTIFIED ACCURACY ± 1 % NIST TRACEABLE
CYLINDER PRESSURE 2000 PSIG
CERTIFICATION DATE 10/11/93
EXPIRATION DATE 10/11/95 TERM 24 MONTHS

CERTIFIED CONCENTRATION

NITRIC OXIDE 356 ppm
NITROGEN BALANCE
NOx 362 ppm

ANALYZED BY

W. E. P. [Signature]
MARIA E. ROCKON

CERTIFIED BY

[Signature]
DOUG GRANT



213-585-2154
FAX# 213-585-0582

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

5700 SOUTH ALEMEDA STREET • LOS ANGELES, CALIFORNIA 90058

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER ENV. & INDUST. DIST.

P.O NUMBER 031993-4

REFERENCE STANDARD

COMPONENT
NITRIC OXIDE

GMIS

NIST SRM NO.
vs 1684b

CYLINDER NO.
SA 1395

CONCENTRATION
85.2 ppm

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT	NITRIC OXIDE	GMIS	ANALYZER MAKE-MODEL-S/N	Beckman 951A	S/N 0101354		
ANALYTICAL PRINCIPLE		Chemiluminescence		LAST CALIBRATION DATE	03/03/93		
FIRST ANALYSIS DATE		01/21/93		SECOND ANALYSIS DATE	03/24/93		
Z 0	R 967	C 822	CONC. 86.7 ppm	Z 0	R 862	C 870	CONC. 86.0 ppm
R 967	Z 0	C 822	CONC. 86.7 ppm	R 860	Z 0	C 869	CONC. 86.1 ppm
Z 0	C 822	R 967	CONC. 86.7 ppm	Z 0	C 869	R 860	CONC. 86.1 ppm
U/M mV		MEAN TEST ASSAY	86.7 ppm	U/M mV		MEAN TEST ASSAY	86.1 ppm

CHRONOLOGY: First Analysis vs GMIS SA 3057, 102 ppm NO/N2

THIS CYLINDER NO. SGAL 1074
HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.2
OF TRACEABILITY PROTOCOL NO. 1
PROCEDURE G1
CERTIFIED ACCURACY ± 1 % NIST TRACEABLE
CYLINDER PRESSURE 2000 PSIG
CERTIFICATION DATE 03/24/93
EXPIRATION DATE 09/24/94

CERTIFIED CONCENTRATION
NITRIC OXIDE 86.4 ppm
NITROGEN BALANCE
NOx 88.7 ppm

ANALYZED BY

MARK E. ROEGNER

CERTIFIED BY

KWAM T. YOUNG



213-585-2154
FAX# 213-585-0582

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

5700 SOUTH ALAMEDA STREET • LOS ANGELES, CALIFORNIA 90058

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER ENV. & INDUST. DIST.

P.O NUMBER 102293-1

REFERENCE STANDARD

COMPONENT
CARBON DIOXIDE GMS

NIST SRM NO.
vs 1675b

CYLINDER NO.
438008

CONCENTRATION
14.04 %

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT CARBON DIOXIDE GMS			ANALYZER MAKE-MODEL-S/N Siemens Ultramat 5E S/N A12-730		
ANALYTICAL PRINCIPLE NDIR			LAST CALIBRATION DATE 09/03/93		
FIRST ANALYSIS DATE 11/10/93			SECOND ANALYSIS DATE		
Z 0.00	R 14.00	C 10.06	CONC. 10.09 %	Z	R C CONC.
R 14.02	Z 0.00	C 10.06	CONC. 10.07 %	R	Z C CONC.
Z 0.00	C 10.06	R 14.04	CONC. 10.06 %	Z	C R CONC.
U/M %		MEAN TEST ASSAY	10.07 %	U/M %	MEAN TEST ASSAY

THIS CYLINDER NO. SA 3236
HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4
OF TRACEABILITY PROTOCOL NO. 1
PROCEDURE G1
CERTIFIED ACCURACY ± 1 % NIST TRACEABLE
CYLINDER PRESSURE 2000 PSIG
CERTIFICATION DATE 11/10/93
EXPIRATION DATE 11/10/96 TERM 36 MONTHS

CERTIFIED CONCENTRATION
CARBON DIOXIDE 10.07 %
NITROGEN BALANCE

ANALYZED BY

Marta Rochon
MARTA ROCHON

CERTIFIED BY

David Leon
DAVID LEON



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(313) 589-2950 FAX: (313) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

FUGRO MCCLELLAND
MR. TODD SATLEY
9921 ST CHARLES ROCK RD
ST ANN MO 63074

Assay Laboratory

Scott Specialty Gases, Inc.
1290 Combermere
Troy, MI 48083

Purchase Order H145
Scott Project # 549824

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol 1 Procedure # G1, Section Number 3.0.4

Cylinder Number ALM022583
Cylinder Pressure 1900 psig

Certification Date 4-19-93
Previous Certification Dates None

General Exp. Date 4-19-96
Acid Rain Exp. Date 10-19-94

ANALYZED CYLINDER

Components

Carbon Monoxide

Certified Concentration

60.08 ppm

Analytical Uncertainty*

±1% NIST Directly Traceable

Balance Gas: NITROGEN

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type Expiration Date
CRM 1679 12-20-94

Cylinder Number
AAL1355

Concentration
96.67 ppm CO in N₂

INSTRUMENTATION

Instrument/Model/Serial #
CO: Horiba/OPE 144E/560172153

Last Date Calibrated
4-6-93

Analytical Principle
Non-Dispersive Infrared

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Carbon Monoxide

Date: 4-12-93 Response Units: mv
Z1=0.00 R1=170.0 T1=106.4
R2=170.0 Z2=0.00 T2=106.4
Z3=0.00 T3=106.4 R3=170.0
Avg. Conc. of Cust. Cyl. 60.13 ppm

Second Triad Analysis

Date: 4-19-93 Response Units: mv
Z1=0.00 R1=170.0 T1=106.2
R2=170.0 Z2=0.00 T2=106.2
Z3=0.00 T3=106.2 R3=170.0
Avg. Conc. of Cust. Cyl. 60.02 ppm

Calibration Curve

Concentration=A+Bx+Cx²+Dx³+Ex⁴
r=0.99999 CRM 1679
Constants: A=-0.02233189
B=0.5597086 C=0.000053352
D=0 E=0

Concentration=A+Bx+Cx²+Dx³+Ex⁴

Concentration=A+Bx+Cx²+Dx³+Ex⁴

Special Notes

If this product is used for Acid Rain Rule Compliance, the Acid Rain Expiration Date noted above applies per 40 CFR Part 75, Appendix H. Otherwise, the General Expiration Date applies.

Analyst Frank P. Doran



213-585-2154
FAX# 213-585-0582

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

5700 SOUTH ALEMEDA STREET • LOS ANGELES, CALIFORNIA 90058

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS8U

CUSTOMER ENV. & INDUST. DIST.

P.O NUMBER 022293-3

REFERENCE STANDARD

COMPONENT
OXYGEN

GMIS

NIST SRM NO.
vs 2629a

CYLINDER NO.
632487

CONCENTRATION
21.00 %

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT	OXYGEN	GMIS	ANALYZER MAKE-MODEL-S/N	Siemens Oxymat 5E	S/N A12-839
ANALYTICAL PRINCIPLE		Paramagnetic	LAST CALIBRATION DATE 12/08/92		
FIRST ANALYSIS DATE		03/01/93	SECOND ANALYSIS DATE		
Z 0.00	R 21.00	C 20.05	CONC. 20.05 %	Z	R C CONC.
R 21.00	Z 0.00	C 20.00	CONC. 20.00 %	R	Z C CONC.
Z 0.00	C 20.05	R 21.00	CONC. 20.05 %	Z	C R CONC.
U/M %		MEAN TEST ASSAY	20.03 %	U/M %	MEAN TEST ASSAY

THIS CYLINDER NO. SA 6957

HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4
OF TRACEABILITY PROTOCOL NO. 1

PROCEDURE G1

CERTIFIED ACCURACY ± 1 % NIST TRACEABLE

CYLINDER PRESSURE 2000 PSIG

CERTIFICATION DATE 03/01/93

EXPIRATION DATE 09/01/94

CERTIFIED CONCENTRATION

OXYGEN 20.03 %

NITROGEN BALANCE

ANALYZED BY

MARIA E. ROCHON

CERTIFIED BY

KWAN T. YOUNG



213-585-2154
FAX# 213-585-0582

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

5700 SOUTH ALEMEDA STREET • LOS ANGELES, CALIFORNIA 90058

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER ENV. & INDUST. DIST.

P.O NUMBER 031993-4

REFERENCE STANDARD

COMPONENT		NIST SRM NO.	CYLINDER NO.	CONCENTRATION
OXYGEN	GMIS	vs 2629a	632487	21.00 %

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT	OXYGEN	GMIS	ANALYZER MAKE-MODEL-S/N	Siemens Oxymat 5E S/N A12-839
ANALYTICAL PRINCIPLE		Paramagnetic		LAST CALIBRATION DATE 03/08/93
FIRST ANALYSIS DATE		03/29/93		SECOND ANALYSIS DATE
Z 0.00	R 21.00	C 11.95	CONC. 11.95 %	Z R C CONC.
R 21.00	Z 0.00	C 11.95	CONC. 11.95 %	R Z C CONC.
Z 0.00	C 11.95	R 21.00	CONC. 11.95 %	Z C R CONC.
U/M %		MEAN TEST ASSAY	11.95 %	U/M % MEAN TEST ASSAY

THIS CYLINDER NO. SA 6956

HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4

OF TRACEABILITY PROTOCOL NO. 1

PROCEDURE G1

CERTIFIED ACCURACY ± 1 % NIST TRACEABLE

CYLINDER PRESSURE 2000 PSIG

CERTIFICATION DATE 03/29/93

EXPIRATION DATE 09/29/94

CERTIFIED CONCENTRATION

OXYGEN 11.95 %

NITROGEN BALANCE

ANALYZED BY

KELLY GALLAGHER

CERTIFIED BY

KWAN YOUNG

METHOD 5: PROBE NOZZLE FIELD CALIBRATION DATA



Nozzle Identification Number: 3-10

Client: MASTER

Project No.:

Source:

Date: 4-18-94

Analyst:

Micrometer:

Scale:

Tolerance:

CALIBRATION DATA

Trial Number	Run	Run	Run	Run
1	.370			
2	.370			
3	.370			
4	.370			
5	.371			
6	.370			
7				
8				
9				
10				
AVERAGE	.370			

Comments:

METHOD 5: PROBE NOZZLE FIELD CALIBRATION DATA



Nozzle Identification Number: 3-4

Client: Master

Project No.: _____

Source: _____

Date: _____

Analyst: _____

Micrometer: _____

Scale: _____

Tolerance: _____

CALIBRATION DATA

Trial Number	Run	Run	Run	Run
1	0.291			
2	0.300			
3	0.277			
4	0.302			
5	0.277			
6				
7				
8				
9				
10				
AVERAGE	0.300			

Comments: _____

APPENDIX F

Data Logger Strip Chart Recordings

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE 5-10-94

SOURCE NORTH STACK (DRYER)

RUN # 1

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	THC OTHER (ppm dry)
1 START 1253	6	17		.4	20.625		5
2	7	17.5		.4	20.75		5.5
3	8	16.5		.4	20.5		3.5
4	9.5	6		.5	20.25		3
5	11	5		.6	20.125		3.5
6	11.5	5		.6	20		3.2
7	11.5	5		.6	20.125		3
8	12	5		.6	20.125		3.5
9	12.5	5		.6	20.125		3.5
10	12.5	5.5		.6	20.3		3.5
11	12.5	5.5		.6	20.375		3.6
12	13	5.5		.5	20.5		3.9
13	13	5.5		.5	20.625		3.4
14	13.5	5		.56	20.5		3.5
15	14	6.5		.56	20.625		3.8
16	14	7.5		.56	20.5		3.5
17	14	7.5		.56	20.625		4
18	14	9.5		.58	20.625		4
19	14	10		.58	20.725		4
20 1353	14	10		.5	20.7		4
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	11.875	8.0		0.540	20.436		3.745

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE 5-10-94

SOURCE NORTH STACK (DRYER)

RUN # 2

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	THC OTHER (ppm dry)
1 1448	4	15		.4	20.5		5.9
2	4	15		.4	20.5		6
3	4	15		.4	20.58		6
4	4	15		.4	20.58		6
5	4	15.5		.4	20.55		6
6	4	15		.4	20.55		6
7	4	17.5		.4	20.53		6
8	4	20		.4	20.53		6.3
9	4	20		.4	20.53		6.5
10	3.5	20		.4	20.55		6.5
11	3.5	20		.4	20.63		6.3
12	3.1	20		.4	20.63		6
13	3.1	20		.4	20.63		6
14	3.1	20		.4	20.63		6
15	3	20		.4	20.63		6
16	3	20		.4	20.63		6
17	3	20		.4	20.63		6
18	3	20.5		.4	20.63		6
19	3	22.5		.4	20.63		6.4
20 1548	3	22.5		.4	20.63		6.5
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	3.55	18.625		0.4	19.653		6.120

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSELLES BRICK

DATE 5-10-94

SOURCE NORTH STACK (DRYER)

RUN # 3

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	THC OTHER (ppm dry)
1 1630	2.5	22.5		.4	20.38		7
2	2.8	23		.4	20.5		7.5
3	2.8	24		.4	20.5		7.5
4	2.5	24		.4	20.5		7
5	2	24		.4	20.5		7
6	2	24		.4	20.5		7.5
7	2	22.5		.4	20.55		7.5
8	2	24		.4	20.5		7
9	2	24.5		.4	20.5		7
10	2	24.5		.4	20.63		7
11	2	24		.4	20.5		7
12	2	24		.4	20.55		7
13	2	23.5		.4	20.5		7.2
14	0	24.5		.4	20.5		7.5
15	2	24.5		.4	20.5		7.5
16	2	24.5		.4	20.58		7.5
17	2	24.5		.4	20.5		7.5
18 1724	2	25.0		.4	20.5		7.5
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	2.03	23.97		.4	20.51		7.26

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE

5-11-94

SOURCE DRYER STACK 2

RUN #

1

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	TEMP (ppm dry)
10750	1.5	15		.5	20.63		3
2	1.5	15		.5	20.63		3
3	1.5	15		.5	20.7		3
4	1.5	15		.5	20.75		3
5	1.5	14		.5	20.75		3
6	1.5	14		.5	20.73		3
7	1.5	14		.5	20.7		3
8	1.5	14		.5	20.75		3
9	1.5	12.5		.5	20.75		3
10	1.2	15		.5	20.63		3
11	1.3	15		.5	20.75		3
12	1.2	15		.5	20.88		3
13	1.2	15		.5	20.75		3
14	1.3	15		.5	20.7		3
15	1.5	15		.5	20.75		3
16	1.8	15		.5	20.75		3
17	1.5	15		.5	20.65		3
18	1.5	16		.5	20.75		3
19	1.5	17.5		.5	20.75		3
200850	1.5	15		.5	20.75		3
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	1.5	15		.5	20.73		3

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE

5-11-94

SOURCE DRYER STACK 2

RUN #

2

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	THC OTHER (ppm dry)
1 0930	2	17.5		.4	20.75		.5
2	2	17.5		.4	20.75		.5
3	2	17.5		.4	20.75		.5
4	2	17.5		.4	20.75		.5
5	2	17.5		.4	20.75		.5
6	2	19		.4	20.75		.5
7	2	17.5		.4	20.75		.5
8	2	17.5		.4	20.75		.5
9	2	19		.4	20.75		.5
10	2	20		.4	20.75		2.5
11	2	20		.4	20.75		4.5
12	2.5	20		.5	20.75		4.5
13	2.5	20		.5	20.75		4
14	2.5	20		.5	20.75		4.5
15	2.5	20		.5	20.75		4.5
16	2.5	20		.5	20.75		4
17	2.5	20		.5	20.75		4.5
18	2.5	20		.5	20.75		4.5
19	2.5	20		.5	20.75		4.5
20 1030	2.5	20		.5	20.75		4.5
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	2.225	19.04		.45	20.75		2.55

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE 5-11-94

SOURCE DRYER STACK 2

RUN # 3

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	HC OTHER (ppm dry)
1 1106	3	20		.4	20.75		4.5
2	3	20		.4	20.75		4.5
3	3	20		.4	20.75		4.5
4	3	20		.4	20.75		4.5
5	3	20		.4	20.75		4.5
6	3	20		.4	20.75		4.5
7	3	20		.4	20.75		5
8	3	20		.4	20.75		5
9	3	20		.4	20.75		5
10	3	20		.4	20.75		5
11	3	20		.4	20.75		5
12	3	20		.4	20.75		5
13	3	20		.4	20.875		5
14	3	20		.4	20.75		5
15	3	20		.4	20.875		5
16	3	20		.4	20.875		5
17	3	20		.4	20.875		5
18	3	20		.4	20.875		5
19	3	20		.4	20.875		5
20 1206	3	20		.4	20.875		5
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	3	20		.4	20.79		4.5

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE 5-11-94

SOURCE KILN

RUN # 1

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	OTHER (ppm dry)
1 1515	24.5	127.5		2	18		10
2	26	127.5		2	17.875		9.9
3	24	127.5		2	18		10
4	25	132.5		2	18.125		9.5
5	24	130		2	18		9
6	23.5	127.5		2	18		9
7	24	125		1.96	18.125		8.5
8	24	122.5		2	18		8
9	24	122.5		2	18		8
10	21	115		1.6	18.75		8
11	28	112.5		2.2	17.5		8
12	28	117.5		2.4	17.125		8.5
13	30	120		2.3	17.25		9
14	27	122.5		2.3	17.25		9.5
15	26	125		2.2	17.5		9.5
16	27	130		2.1	17.75		10
17	29	132.5		2.1	17.75		10
18	26.5	132.5		2.2	17.625		10
19	29	132.5		2.1	17.75		10
20 1615	25	132.5		2.1	17.875		10
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	25.88	125.75		2.08	17.81		9.25

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE 5-11-94

SOURCE KILN

RUN # 2

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	THC OTHER (ppm dry)
1 1700	27	125		2.1	17.75		9
2	26	127.5		2	17.75		9
3	28	127.5		2.1	17.875		9
4	25	130		2.1	17.875		9
5	28	127.5		2.2	17.75		9
6	26	127.5		2	18		8.5
7	27	125		2	18		8.5
8	26	122.5		2.1	18		8.5
9	23	120		1.8	17.875		8.5
10	29	115		2.2	18.5		8.5
11	30	115		2.6	17.5		9
12	29	120		2.4	16.875		9
13	30	120		2.4	17.25		9
14	29	120		2.3	17.5		9
15	30	122.5		2.2	17.5		9
16	29	122.5		2.2	17.5		9
17	28	122.5		2.1	17.625		9
18	28	122.5		2.1	17.875		9
19	28	120		2	17.875		8.5
20 1800	26	122.5		2	17.875		8
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	27.6	122.75		2.15	17.77		8.8

NOTES:

CONTINUOUS EMISSIONS MONITORING DATA SHEET

PLANT MARSEILLES BRICK

DATE

5-11-94

SOURCE KILN

RUN #

3

TIME	NOX (ppm dry)	CO (ppm dry)	SO2 (ppm dry)	CO2 (ppm dry)	O2 (ppm dry)	VOC (ppm dry)	T/KC OTHER (ppm dry)
1 1840	26	135		2.2	17.75		8
2	27	132.5		2.2	17.875		8
3	26.5	130		2.1	17.875		8
4	28	127.5		2.1	17.75		8
5	26	127.5		2.1	17.875		8
6	26	127.5		2	17.875		8
7	26	130		2.2	17.75		8
8	29	120		1.7	18.75		8
9	30	120		2.6	17		8
10	30	120		2.6	17.25		8
11	29	122.5		2.4	17.5		8
12	29	125		2.4	17.5		8
13	28	125		2.2	17.75		8
14	30	125		2.3	17.5		7.5
15	29.5	125		2.2	17.75		7.5
16	30	125		2.2	18		7.5
17	27	122.5		2.2	18		7.5
18	28	125		2.1	17.75		7.5
19	27	122.5		2.1	18		7.5
20 1940	27.5	122.5		2.1	18		7.5
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
AVERAGE	27.88	125.85		2.2	17.88		7.8

NOTES:

87PM
TWC

18PM
NOX

18PM
NOX

1.8% CO₂

0.125 PM
00 PM

1455 PM

17.8%
O₂

zero

STACK
1930

20.9%
O₂

503ppm
TWC BIAS

358ppm
NOX BIAS

59PM
CO₂ CAL.

10.0% CO₂ CAL.

11.9%
O₂ CAL.

87.3PM
NOT BIAS

30.4PM
TWC BIAS MARSEILLES BRICK
KILN 5-11-89

06 0.704V
 05 0.055V
 04 0.255V
 02 0.959V
 01 2.34V
 200mm/h
 May. 11 15:10

← START
 RUN #1 KILN
 1515 5-11-99

87ppm
 THC
 18ppm
 NOX
 1.8% CO2
 12.5ppm
 CO

1455 PM

17.7%
 O2

— STACK
 1930

20.9%
 O2

503ppm
 THC BIAS

358ppm
 NOX BIAS

59ppm
 CO CAL.

10.0% CO2
 CAL.
 11.9%
 O2 CAL.

87.3ppm
 NOT BIAS


30.4ppm
 THC BIAS
 MARSEILLER BRICK
 KILN 5-11-99

RUN #1
KILM 5-11-94
1673

06 0.718V
05 0.049V
04 0.265V
02 1.017V
01 2.59V
200mm/h
May.11 16:10

06 0.704V
05 0.055V
04 0.255V
02 0.959V
01 2.34V
200mm/h
May.11 15:10

← START
RUN #1 KILM
1515 5-11-94



140

06 0.726V
05 0.048V
04 0.263V
02 0.854V
01 2.40V
200mm/h
May. 11 17:10

CO2 = 1.8% TAC = 8 ppm
CO = 124 ppm ABT = 30 ppm
O2 = 17.8%

← START RUN
#2 KILN
1700 - 1800

BAG #1 KILN
O2 = 17.8% CO2 = 1.8%
CO2 = 1.8%

57MM
CO CAL

9.8%
O2 CAL
CO2 CAL

30.8 ppm
TAC BIAS

88.2 ppm NOX
BIAS

← END
RUN #1
KILN 5-11-74
1673

06 0.718V
05 0.049V
04 0.265V
02 1.017V
01 2.59V
200mm/h
May 11 12:10

20 cm

40 cm

THE 7.5 PM
NOX = 25 ppm
CO = 125
CO2 = 1.8%

17.8% O2

← START RUN #3 1840
BAG #2 KILN
O2 = 17.7 CO = 132 CO2 = 1.3%

20.9% O2

60 ppm CO CAL.

10.1% CO2 CAL.

11.9% O2 CAL.

89.6 ppm NOX BIAS

30.2 ppm THE BIAS

— END RUN #2 KILN 1804

00
04
02
01
2000 h
May. 11 18:10

05
09
0.006V

10

11

12

20 cm

25107

10856

200mm/h
May.11 20:10

BAG #3
OZ=17.5%
CR=1.870
CO=128ppm

60.0ppm
CO CAL.

303ppm
CO CAL.

20.9%
O2

10.0% O2
CAL.

18.2%
O2 CAL.

20.2%
O2 CAL.

12.0% O2
CAL.

29.8
ppm
TWO CAL.

31.2ppm
TWO BIAS

86.6
ppm
NOT CAL

86.9ppm
NOT BIAS

END RUN #3
1943 KILN
5-11-94

06 0.690V
05 0.061V
04 0.243V
02 0.775V
01 2.78V
200mm/h
May.11 19:10

May.10 18:10

30.7 PPM CO CAL

86.4 PPM NOX CAL

↑ 30.7 PPM CO CAL.

①
↑ 60 PPM CO CAL.
0-500 PPM SCALE

①
↑ 11.9% O₂ CAL.

①
↑ 20.2% O₂ CAL.

①
↑ 18.0% O₂ CAL.

① ZERO CO, O₂, NOX, THC

①
↑ 10.1% CO₂ CAL.

①
20.9% O₂ CAL.

STACK
DRYER #1

5-10-94 MARSEILLES BRICK
1006

03 0.001V
02 0.000V
01 0.248V
200 m/h
May.10 08:10

2 MIN 30 SECONDS

500 PPM TMA
CAL

359 PPM
NOX BARS

92.02
PPM
THE B CAL

361 PPM NOX
CAL

86.4 PPM
NOX CAL

307 PPM CO CAL

60 PPM CO CAL
0-500 PPM SCALE

20.2% O2 CAL

11.9% O2 CAL

18.0%
CO2 CAL

Zero CO, O2, NOX, TMA

10.1% CO2
CAL

20.9% O2 CAL

STACK
Dryer #1

5-10-94 MARSEILLES BRICK

1006

06 0.842V
05 0.805V
04 0.801V
02 0.815V
01 0.806V
200 m/h
May. 10 18:10

03 0.001V
02 0.000V
01 0.248V

START RUN #1
NORTH STACK (DRYER)
1253

06 0.623V
05 0.611V
04 0.645V
02 0.624V
01 0.65V
200 mV/h
May. 10 11:50

NOX = 1 PPM
CO2 = 0.39%
CO = 22 PPM
O2 HC = 6 PPM

O2 20.4% 20.42%

NOX = 0-100 PPM O2 = 0-25%
THC = 0-100 PPM CO2 = 0-20%
CO = 0-500 PPM

STACK 1155

Zero CO2, NOX, THC

50 PPM
THC BIAS

84 PPM
THC BIAS

86 PPM
NOX BIAS

SYSTEM RESPONSE TIME
2 MIN. 30 SECONDS

50 PPM
THC
CALI

RUN 1 complete
1400

06 0.602V
05 0.015V
04 0.012V
02 2.783V
01 1.112V
200mm
May. 10 12:10

NOX = 11 ppm
CO = 4 ppm
CO2 0.5%

O2 = 20.0%
THC = 3 ppm

←
START RUN #1
North Stack (Dryer)
1253

06 0.822V
05 0.018V
04 0.037V
02 0.637V
01 0.85V
200mm/h
May. 10 15:00

CO₂ = 0.3% THC = 5.3ppm 20.4% O₂
CO = 12ppm NO_x = 3.5ppm
← START RUN #2
1448

BAG #1, Run = 1

CO = 4ppm O₂ = 20.2%
CO₂ = 0.3%

Zero

60ppm CO
CO CAL.

10.2% CO₂ CAL.
11.9% O₂ CAL.

31ppm THC
BIAS

20.0% O₂ CAL.

86.0ppm NO_x BIAS

20.9% O₂

05 0.822V
04 0.016V
02 0.200V
01 1.29V
200mm/h
May. 10 14:10

RUN 1 complete
1400

CO₂
0.8%

OTHC= 111

20.4%

280cm

zeros

START RUN #3
1630

30.64ppm
THE

83.0ppm
NOX 6.45

06 0.831V
05 0.007V
04 0.020V
02 0.044V
01 0.016V

200mm
May. 10 1960

60ppm
O₂ CAL.

10.2%
CO₂ CAL.

20.02
O₂ CAL.

20.8% O₂
CAL

BAY # 2, RUN # 2
CO = 18ppm CO₂ = 0.3%

O₂ = 20.2%

RUN # 2 complete at
1553

06 0.822V
05 0.011V
04 0.031V
02 0.631V
01 0.556V

200mm

06 0.821V
 05 0.009V
 04 0.005V
 02 0.743V
 01 -0.104V

200 mph
 May. 10 7:10

← END RUN #3 1730
 5-10-94

NOX
 3ppm
 CO2
 0.3%
 CO = 21ppm
 THC = 7ppm

zeros

← START RUN #3
 1630

31.4ppm
 THC

31.3ppm

THC BIAS

BAG #3

CO = 21ppm

CO2 = 0.3%

O2 = 20.4%

11.9%
 O2 CAL.
 10.0%
 COO CAL

20.9%
 O2

82.7ppm
 NOX CAL

84.6ppm
 NOX BIAS

20.9%
 O2
 CAL

O2
 20.4%

SYSTEM RESPONSE TIME 2335

18.0% CO2 CAL.
92.03 ppm THE CAL.

10.0% 10.0%
CO2 CAL.

367 ppm
NOX CAL.

51.6 ppm THE CAL.

12.0%
O2 CAL.

26.2%
O2 CAL.

86.5 ppm
NOX CAL.

30.5 ppm THE CAL.

20.9%
O2 CAL.

06 0.789V
05 0.005V
04 0.000V
02 0.035V
01 0.000V

200 mV/div
May. 11 05:10

4 zero

5-11-94

DRYER STACK #2

MARSHALLS
BRIDGE

START Run #1
0750

06 0.829V
05 0.030V
04 0.028V
02 0.360V
01 0.020V
200mm
May.11 07:10

STACK #2
0650
DRYER #2 5-11-74

zero

zero
02

29.30ppm
THC GAS

20.9%
O2

88.2ppm
NOX GAS

SYSTEM response time 2335

82.03ppm
THC CAL.
18.0% CO2 CAL.

29.6 ppm
THC B:AS

12.0%
02 OK

88 ppm
NOx B:AS

Run #1
complete
0850

06 0.824V
05 0.002V
04 0.005V
02 0.301V
01 0.005V
200mm
May.11 08:10

START Run #1
0750

04 0.038V
02 0.443V
01 0.233V
200mm/h
May.11 10:10-

THC = 4PPM
NOX = 2PPM
CO = 18PPM
CO2 = 0.3%
O2 = 20.5%

← START RUN #2
DRYER #2 0930

Zero

20.9% O2

06 0.001V
05 0.005V
04 0.008V
02 0.002V
01 0.001V
200mm/h
May.11 09:10-

BAG #1 Dryer #2 CO = 14PPM
CO2 = .3%
O2 = 20.4%

59PPM
59CO OK

10.1% O2 OK

12.0% O2 OK

29.6 PPM
THC B:AS

85PPM
NOX B:AS

06 0.829V
05 0.011V
04 0.003V
02 0.428V
01 0.26V

200mm
May. 11 11:20-

THC = 4ppm
NOx = 2.5ppm

CO2 = 0.3%
CO = 20ppm

O2 = 20.4%

← START RUN #3
1106 5-11-99
Dryer STACK #2

⑤ zero

⑥ 20.9% O2

BAG #2 Run #2
Dryer #2 5-11-99
O2 = 20.4% CO2 = 0.3% CO = 17ppm

① ↑
59ppm
CO CAL.

② ↑
29.3ppm
THC BAS

③ ↑
10.0% CO2

④ ↑
12% O2 CAL.


⑦ 87.1ppm
NOx BAS

← END RUN #2
1030 5-11-99

06 0.819V
05 0.003V
04 0.003V
02 0.428V
01 0.26V

200mm
May. 11 10:00-

NA 05 04 02 01
0.010V
0.039V
0.508V
0.000V
200mm
May. 11 12:00



BAG #3 Run 3
Dryer #2 5-11-94
CO₂ = 0.3%
CO = 18 PPM
O₂ = 20.4%

61 PPM
CO CAL

10.0% CO₂
CAL

11.9% O₂
CAL

20.9%
O₂

28.8
PPM

H₂C BIAS

← END RUN #3
1206 5-11-94
Dryer #2

84 PPM
NOX BIAS

APPENDIX G
Example Calculations

DRYER STACK #1
EMISSION RATE CALCULATION
OXIDES OF NITROGEN (NOx)

En - OXIDES OF NITROGEN (NOx) Emission Rate: lb/hr
Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
Standard Conditions; DSCF/min.
Mw - Molecular Weight of OXIDES OF NITROGEN (NOx) 46.0 g/gmole
Cn - Concentration of OXIDES OF NITROGEN (NOx); Dry basis
K1 - Conversion Factor: Part Per Million
K2 - Conversion Factor; 385.3 g/gmole-lb/ft3
k3 - Conversion Factor, 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

TEST DATA
DRYER STACK #1

RUN 1:	Cn =	11.8750	Qsd =	15196.28
RUN 2:	Cn =	3.5150	Qsd =	18680.31
RUN 3:	Cn =	2.0300	Qsd =	17769.43
AVERAGE:		=	5.81	

OXIDES OF NITROGEN (NOx) Emission
CALCULATIONS:
DRYER STACK #1

RUN 1:	11.875 *	46 *	15196.28 *	60
(385.3 E6)				
			=	1.292650 LB/HR
RUN 2:	3.515 *	46 *	18680.31 *	60
(385.3 E6)				
			=	0.470348 LB/HR
RUN 3:	2.03 *	46 *	17769.43 *	60
(385.3 E6)				
			=	0.258392 LB/HR
AVERAGE:			=	0.673796 LB/HR

DRYER STACK #2
EMISSION RATE CALCULATION
OXIDES OF NITROGEN (NOx)

En - OXIDES OF NITROGEN (NOx) Emission Rate; lb/hr
Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
Standard Conditions; DSCF/min.
Mw - Molecular Weight of OXIDES OF NITROGEN (NOx) 46.0 g/gmole
Cn - Concentration of OXIDES OF NITROGEN (NOx); Dry Basis
K1 - Conversion Factor; Part Per Million
K2 - Conversion Factor; 385.3 g/gmole-lb/ft³
K3 - Conversion Factor; 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * K2}$$

TEST DATA
DRYER STACK #2

RUN 1:	Cn =	1.4500	Qsd =	16051.47
RUN 2:	Cn =	2.2250	Qsd =	18029.04
RUN 3:	Cn =	3.0000	Qsd =	16454.38
AVERAGE:	=	2.23		

OXIDES OF NITROGEN (NOx) Emission
CALCULATIONS:
DRYER STACK #2

RUN 1:	1.45 *	46 *	16051.47 *	60
(385.3 E6)				
			=	0.166721 LB/HR
RUN 2:	2.225 *	46 *	18029.04 *	60
(385.3 E6)				
			=	0.287350 LB/HR
RUN 3:	3 *	46 *	16454.38 *	60
(385.3 E6)				
			=	0.353600 LB/HR
AVERAGE:			=	0.269224 LB/HR

**KILN STACK
EMISSION RATE CALCULATION
OXIDES OF NITROGEN (NOx)**

En - OXIDES OF NITROGEN (NOx) Emission Rate: lb/hr
 Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
 Standard Conditions; DSCF/min.
 Mw - Molecular Weight of OXIDES OF NITROGEN (NOx) 46.0 g/gmole
 Cn - Concentration of OXIDES OF NITROGEN (NOx); Dry Basis
 K1 - Conversion Factor: Part Per Million
 K2 - Conversion Factor; 385.3 g/gmole-lb/ft³
 k3 - Conversion Factor; 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

**TEST DATA
KILN STACK**

RUN 1:	Cn =	25.8800	Qsd =	12729.78
RUN 2:	Cn =	27.6000	Qsd =	13516.06
RUN 3:	Cn =	27.9800	Qsd =	12449.05
AVERAGE:		=	27.15	

**OXIDES OF NITROGEN (NOx) Emission
CALCULATIONS:
KILN STACK**

RUN 1:	25.88 *	46 *	12729.78 *	60
(385.3 E6)				
			=	2.359908 LB/HR
RUN 2:	27.6 *	46 *	13516.06 *	60
(385.3 E6)				
			=	2.672201 LB/HR
RUN 3:	27.98 *	46 *	12449.05 *	60
(385.3 E6)				
			=	2.495134 LB/HR
AVERAGE:			=	2.509081 LB/HR

DRYER STACK #1
EMISSION RATE CALCULATION
CARBON MONOXIDE (CO)

En - Carbon monoxide Emission Rate; lb/hr
Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
Standard Conditions; DSCF/min.
Mw - Molecular Weight of Carbon Monoxide; 28.0 g/gmole
Cn - Concentration of Carbon Monoxide; Dry Basis
K1 - Conversion Factor, Part Per Million
K2 - Conversion Factor, 385.3 g/gmole-lb/ft3
k3 - Conversion Factor: 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

TEST DATA
DRYER STACK #1

RUN 1:	Cn =	8.00	Qsd =	15196.28
RUN 2:	Cn =	18.675	Qsd =	18680.31
RUN 3:	Cn =	23.97	Qsd =	17769.43
AVERAGE: =		16.88		17215.34

Carbon Monoxide (CO) Emissions
CALCULATIONS:
DRYER STACK #1

RUN 1:	8 *	28 *	15196.28 *	60
(385.3 E6)				
			=	0.530075 LB/HR
			=	
RUN 2:	18.675 *	28 *	18680.31 *	60
(385.3 E6)				
			=	1.521090 LB/HR
			=	
RUN 3:	23.97 *	28 *	17769.43 *	60
(385.3 E6)				
			=	1.857170 LB/HR
			=	
AVERAGE: =				1.302778 LB/HR

DRYER STACK #2
EMISSION RATE CALCULATION
CARBON MONOXIDE (CO)

En - Carbon monoxide Emission Rate; lb/hr
 Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
 Standard Conditions: DSCF/min.
 Mw - Molecular Weight of Carbon Monoxide; 28.0 g/gmole
 Cn - Concentration of Carbon Monoxide; Dry Basis
 K1 - Conversion Factor, Part Per Million
 K2 - Conversion Factor; 385.3 g/gmole-lb/ft3
 k3 - Conversion Factor; 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

TEST DATA
DRYER STACK #2

RUN 1:	Cn =	14.85	Qsd =	16051.47
RUN 2:	Cn =	19.03	Qsd =	18029.04
RUN 3:	Cn =	20.00	Qsd =	16454.38
AVERAGE: =		17.96		16844.96

Carbon Monoxide (CO) Emissions
CALCULATIONS:
DRYER STACK #2

RUN 1:	14.85 *	28 *	16051.47 *	60
(385.3 E6)				
			=	1.039325 LB/HR
			=	
RUN 2:	19.03 *	28 *	18029.04 *	60
(385.3 E6)				
			=	1.495965 LB/HR
			=	
RUN 3:	20 *	28 *	16454.38 *	60
(385.3 E6)				
			=	1.434900 LB/HR
			=	
AVERAGE: =				1.323397 LB/HR

**KILN STACK
EMISSION RATE CALCULATION
CARBON MONOXIDE (CO)**

En - Carbon monoxide Emission Rate; lb/hr
 Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
 Standard Conditions: DSCF/min.
 Mw - Molecular Weight of Carbon Monoxide: 28.0 g/gmole
 Cn - Concentration of Carbon Monoxide; Dry Basis
 K1 - Conversion Factor, Part Per Million
 K2 - Conversion Factor, 385.3 g/gmole- lb/ft³
 k3 - Conversion Factor; 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

**TEST DATA
KILN STACK**

RUN 1:	Cn =	125.75	Qsd =	12729.78
RUN 2:	Cn =	122.75	Qsd =	13516.06
RUN 3:	Cn =	125.50	Qsd =	12449.05
AVERAGE: =		124.67		12898.30

**Carbon Monoxide (CO) Emissions
CALCULATIONS:
KILN STACK**

RUN 1:	125.75 *	28 *	12729.78 *	60
(385.3 E6)				
				= 6.979738 LB/HR
RUN 2:	122.75 *	28 *	13516.06 *	60
(385.3 E6)				
				= 7.234056 LB/HR
RUN 3:	125.5 *	28 *	12449.05 *	60
(385.3 E6)				
				= 6.812244 LB/HR
AVERAGE: =				7.008679 LB/HR

DRYER STACK #1
EMISSION RATE CALCULATION
TOTAL HYDROCARBONS (THC)

En - TOTAL HYDROCARBONS (THC) Emission Rate; lb/hr
 Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
 Standard Conditions: DSCF/min.
 Mw - Molecular Weight of TOTAL HYDROCARBONS (THC); 44.0 g/gmole
 Cn - Concentration of TOTAL HYDROCARBONS (THC); Dry Basis
 K1 - Conversion Factor, Part Per Million
 K2 - Conversion Factor; 385.3 g/gmole-lb/ft³
 k3 - Conversion Factor; 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

TEST DATA
DRYER STACK #1

RUN 1:	Cn =	3.745	Qsd =	15196.28
RUN 2:	Cn =	6.12	Qsd =	18680.31
RUN 3:	Cn =	7.26	Qsd =	17769.43
AVERAGE:	=	5.708333		

TOTAL HYDROCARBONS (THC) Emission
CALCULATIONS:
DRYER STACK #1

RUN 1:	3.745 *	44 *	15196.28 *	60
	(385.3 E6)			
		=	0.389936 LB/HR	
RUN 2:	6.12 *	44 *	18680.31 *	60
	(385.3 E6)			
		=	0.783322 LB/HR	
RUN 3:	7.26 *	44 *	17769.43 *	60
	(385.3 E6)			
		=	0.883924 LB/HR	
	AVERAGE:	=	0.685727 LB/HR	

DRYER STACK #2
EMISSION RATE CALCULATION
TOTAL HYDROCARBONS (THC)

En - TOTAL HYDROCARBONS (THC) Emission Rate; lb/hr
 Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
 Standard Conditions: DSCF/min.
 Mw - Molecular Weight of TOTAL HYDROCARBONS (THC); 44.0 g/gmole
 Cn - Concentration of TOTAL HYDROCARBONS (THC); Dry Basis
 K1 - Conversion Factor, Part Per Million
 K2 - Conversion Factor: 385.3 g/gmole-lb/ft³
 K3 - Conversion Factor: 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * K2}$$

TEST DATA
DRYER STACK #2

RUN 1:	Cn =	3.00	Qsd =	16051.47
RUN 2:	Cn =	2.55	Qsd =	18029.04
RUN 3:	Cn =	4.85	Qsd =	16454.38
AVERAGE:	=	3.466666		

TOTAL HYDROCARBONS (THC) Emission
CALCULATIONS:
DRYER STACK #2

RUN 1:	3 *	44 *	16051.47 *	60
	(385.3 E6)			
			=	0.329944 LB/HR
RUN 2:	2.55 *	44 *	18029.04 *	60
	(385.3 E6)			
			=	0.315005 LB/HR
RUN 3:	4.85 *	44 *	16454.38 *	60
	(385.3 E6)			
			=	0.546799 LB/HR
	AVERAGE:	=		0.397249 LB/HR

**KILN STACK
EMISSION RATE CALCULATION
TOTAL HYDROCARBONS (THC)**

En - TOTAL HYDROCARBONS (THC) Emission Rate: lb/hr
 Qsd - Volumetric Flow Rate of Stack Gas, Corrected to Dry,
 Standard Conditions: DSCF/min.
 Mw - Molecular Weight of TOTAL HYDROCARBONS (THC): 44.0 g/gmole
 Cn - Concentration of TOTAL HYDROCARBONS (THC): Dry Basis
 K1 - Conversion Factor: Part Per Million
 K2 - Conversion Factor: 385.3 g/gmole-lb/ft³
 k3 - Conversion Factor: 60 Minutes Per Hour

$$En = \frac{Cn * Mw * Qsd * K3}{K1 * k2}$$

**TEST DATA
KILN STACK**

RUN 1:	Cn =	9.22	Qsd =	12729.78
RUN 2:	Cn =	8.8	Qsd =	13516.06
RUN 3:	Cn =	7.83	Qsd =	12449.05
AVERAGE:	=	8.615		

**TOTAL HYDROCARBONS (THC) Emission
CALCULATIONS:
KILN STACK**

RUN 1:	9.215 *	44 •	12729.78 *	60
	(385.3 E6)			
			=	0.803750 LB/HR
RUN 2:	8.8 *	44 •	13516.06 •	60
	(385.3 E6)			
			=	0.814962 LB/HR
RUN 3:	7.83 *	44 •	12449.05 •	60
	(385.3 E6)			
			=	0.667886 LB/HR
	AVERAGE:	=		0.762199 LB/HR

MOISTURE CONTENT DETERMINATION
EPA Method 4 Calculations
TEST RUN #1

Parameter	Definition	Unit
Pm	- Absolute Meter Pressure	in. Hg.
Po	- Average Meter Orifice Differential Pressure	in. H ₂ O
Pstd	- Absolute Standard Barometric Pressure (29.92)	in. Hg.
Pb	- Absolute Barometric Pressure	in. Hg.
k	- Standard Volume H ₂ O Vapor/Unit Weight Liquid Constant = 0.04715 cu. ft./g	ft./g
Tm(F)	- Average Meter Temperature Degrees F:	degrees (F)
Tm	- Average Meter Temperature Degrees R:	degrees (R)
Tstd	- Absolute Standard Temperature (528 R)	degrees (R)
Y	- Dry Gas Meter Correction Factor	dimensionless
Vicg	- Total condensate Collected	grams/ml H ₂ O
Vm	- Metered Dry Sample Gas Volume	dcf
Vmstd	- Volume of Water Vapor Collected at Standard Conditions (528 R, 1 atmosphere)	scf
Bws	- Moisture Content (mole fraction)	mole fraction
Bwd	- Moisture Content (% Volume)	% volume

TEST DATA
RUN # 1

Pb	29.85	Y	1.001
Vm	51.565	Tm(F)	88.952381
Vicg	74.50	Tm	548.95238
Tstd	528.00	Po	2.414
Pstd	29.92	k	0.04715

MOISTURE DETERMINATION CALCULATIONS:

1. Meter Pressure:

$$P_m = (P_o/13.6) + P_b$$

$$P_m = 2.414285714 \text{ divided by } 13.6 + 29.85 = 30.0275 \text{ in. Hg.}$$

2. Standard Meter Volume:

$$V_{mstd} = \frac{17.64 \cdot V_m \cdot Y \cdot P_m}{T_m}$$

$$V_{mstd} =$$

$$\frac{17.64 \cdot 51.565 \cdot 1.001 \cdot 30.0275}{548.952381} = 49.8049 \text{ dscf}$$

3. Meter Temperature:

$$T_m = T_m(F) + 460$$

$$T_m = 88.95238095 + 460 = 548.952381 \text{ Deg. (F)}$$

4. Standard Water Volume:

$$V_{wstd} = k \cdot V_{cg}$$

$$V_{wstd} = 0.04715 \cdot 74.5 = 3.512675 \text{ scf}$$

5a. Moisture Content:

$$B_{ws} = \frac{V_{wstd}}{V_{wstd} + V_{mstd}}$$

$$B_{ws} = \frac{3.512675}{3.512675 + 49.8049} = 0.0659 \text{ mole frac.}$$

5b. Bwd = Bws*100

$$B_{wd} = 0.065882064 \cdot 100 = 6.5882 \% \text{ H}_2\text{O}$$

5c. Dry Gas Fraction:

$$F_{dg} = 1 - B_{ws}$$

$$F_{dg} = 1 - 0.0659 = 0.9341 \text{ FDG}$$

VELOCITY AND VOLUMETRIC FLOWRATE DETERMINATION
EPA METHOD 2 CALCULATIONS
TEST RUN #1

Parameter	Definition	Units
Cp	- Pitot Tube Coefficient	dimensionless
Vs	- Gas Stream Velocity	ft./second
Qsd	- Volumetric Flow Rate at Standard Condition, Dry Basis	dscfm
Qact	- Actual Volumetric Flow Rate, Wet Basis	acfm
Bws	- Moisture Content	mole fraction
Dp	- Average Square Root of Velocity Head	in. H2O
Pb	- Absolute Barometric Pressure	in. Hg.
Kp	- Constant = $89.49 \text{ (ft)}^3 \text{ (lb/lb-mol)} \text{ (in.Hg}^{-0.5}) \text{ (s)} \text{ (R)}$	in.H2O
Ts	- Absolute Stack Gas Temperature (R)	Degrees (R)
Me	- Sample Gas Molecular Weight, Wet Basis	lb/lb-mole
Sp	- Static Pressure of Gas Stream	in. H2O
Abs	- Absolute Standard Temperature	528 degrees R
Sd	- Stack Diameter	in.
Csa	- Stack Cross-sectional Area	ft ²
Ps	- Absolute Stack Gas Pressure	in. Hg.
Sm	- Conversion Factor	60 sec/min
Pl	- Constant Ratio	3.1415927 dimensionless
Dn	- Nozzle Diameter	in.
An	- Nozzle Area	ft ²
Tstd	- Absolute Standard Temperature (528) (R)	degrees R

TEST DATA
TEST RUN #1

Ms	28.2767	Cp	0.84
Bws	0.0659	Pb	29.85
Sp	-0.11	Ts	941.57
Sd	41.00	Dp	0.4585
Tstd	528.00	Dn	0.3700

VELOCITY AND VOLUMETRIC FLOWRATE CALCULATIONS:

1. Stack Pressure:

$$P_s = P_b + (Sp/13.6)$$

$$P_s = 29.85 + \frac{-0.11}{13.6} = 29.8419 \text{ in. Hg.}$$

2. Velocity of Stack Gas:

$$\frac{V_s = 85.49 \cdot C_p \cdot D_p \cdot \left[\frac{\text{SQRT}[(T_s)/(P_s \cdot M_s)]}{V_s = 85.49 \cdot 0.38516278 \cdot 1.056328127} \right]}{30.6850} = \frac{29.0488}{34.7823 \text{ ft./sec.}}$$

3. Stack Cross-sectional Area:

$$\frac{C_{sa} = (\pi)(S_d)^2 / (4)(144)}{C_{sa} = 3.141592654 \cdot 1681 \text{ divided by } 576} = 9.16843273 \text{ ft}^2$$

4a. Volumetric Flowrate, Wet Basis:

$$\begin{aligned} Q_{act} &= (V_s \cdot C_{sa}) \cdot 60 \\ Q_{act} &= 34.7823 \cdot 550.1060 = 19133.9584 \text{ acfm} \end{aligned}$$

4b. Volumetric Flowrate at Standard Conditions, Dry Basis:

$$\begin{aligned} Q_{sd} &= \frac{(Q_{act})(1 - B_{ws})(T_{std})(P_s)}{(T_s)(29.92)} \\ Q_{sd} &= \frac{19133.9584 \cdot 0.934117936 \cdot 15756.52941}{28171.81714} \end{aligned}$$

$$Q_{sd} = 9996.5983 \text{ dscfm}$$

MOLECULAR WEIGHT DETERMINATION
EPA METHOD 3 CALCULATIONS
TEST RUN # 1

Parameter	Definition	Units
Md	- Sample Gas Molecular Weight, Dry Basis	lb/lb-mole
Ms	- Sample Gas Molecular Weight, Wet Basis	lb/lb-mole
Bws	- Moisture Content	mole fraction
%O2	- Oxygen (O2) Concentration, Dry Basis	% volume
%CO2	- Carbon Dioxide (CO2) Concentration, Dry Basis	% volume
%CO	- Carbon Monoxide (CO) Concentration, Dry Basis	% volume
%N2	- Nitrogen (N2) Concentration, Dry Basis (gas balance)	% volume
0.32	- Molecular Weight of Oxygen (O2) divided by 100	lb/lb-mole
0.44	- Molecular Weight of Carbon Dioxide (CO2) / by 100	lb/lb-mole
0.28	- Molecular Weight of Carbon Monoxide (CO) / by 100	lb/lb-mole
0.28	- Molecular Weight of Nitrogen (N2) divided by 100	lb/lb-mole
18.00	- Molecular Weight of Water	lb/lb-mole

TEST DATA
TEST RUN #1

Bws	0.0659	%N2	80.4
%O2	17.8		
%CO2	1.8		
%CO	0		

1. MOLECULAR WEIGHT, DRY:

$$M_d = 0.44\%CO_2 + 0.32\%O_2 + 0.28\%N_2 + \%CO$$

$$0.792 + 5.696 + 22.512 + 0$$

$$M_d = 29.0000 \text{ lb/lb-mole}$$

2. MOLECULAR WEIGHT, WET:

$$M_s = M_d(1 - B_{ws}) + 18.00 \cdot B_{ws}$$

$$29 * 0.934117936 + 1.185877146$$

$$M_s = 28.2753 \text{ lb/lb-mole}$$

PARTICULATE MATTER EMISSION DETERMINATION
EPA METHOD 5 CALCULATIONS
TEST RUN # 1

Parameter	Definition	Units
Fdg	- (1-Bws)	fraction
I	- Percent of Isokinetic Sampling	%
Ts	- Absolute Average Stack Gas Temperature	degrees R
Vmstd	- Volume of Stack Gas Sampled, Corrected to Dry, Standard Conditions	dscl
Vs	- Stack Gas Velocity	ft./second
T	- Sample Time Interval	minutes
An	- Cross-Sectional Area of Sampling Nozzle	ft.2
Ps	- Absolute Stack Gas Pressure	in. Hg
Dn	- Sampling Nozzle Diameter	inches
Pi	- Constant (3.141592654)	dimensionless
K2	- Conversion Factor (144)	in.2/ft.2
K3	- Conversion Factor (0.002669)	in. Hg-ft.3/ml-R
K4	- Conversion Factor (17.64)	deg.R/in. Hg
1.67	- Conversion Factor	%-sec/min

TEST DATA
TEST RUN #1

Bws	0.0659		
Vs	34.7823	Ts	941.57
Vicg	74.5000	Ps	29.8419
K3	0.0027	T	60
K4	0.0945	Dn	0.3700
Fdg	0.9341	Vmstd	49.8049

1. Nozzle Area:

$$An = (Dn/24)^2 \cdot Pi$$

$$\frac{An}{An} = \frac{0.000237674 \cdot 3.1415927}{=} = 0.00074667 \text{ ft.2}$$

2. I = ISOKINETICS (%):

$$\frac{0.0945 \cdot Ts \cdot Vmstd}{Ps \cdot Vs \cdot An \cdot T \cdot Fdg} \quad An \cdot T \cdot Fdg = 0.041848676$$

$$\frac{0.0945 \cdot 941.5714286 \cdot 49.804948}{29.84191 \cdot 34.78231415 \cdot 0.0418489} = 102.02 \% I$$

PARTICULATE MATTER EMISSION DETERMINATION
EPA METHOD 5 CALCULATIONS
TEST RUN # 1

Parameter	Definition	Units
Pc	- Total Particulate Catch	mg
Pg	- Total Particulate Catch (mg/1000)	grams
Vmstd	- Volume of Stack Gas Sampled, Corrected to Dry, Standard Conditions	dscf
Cs	- Concentration of Particulate in Stack Gas, Corrected to Dry, Standard Conditions (grams/dscf)	gm/dscf
Cg	- Concentration of Particulate Matter (grains)	gr/dscf
Pcs	- Concentration of Particulate (lb/hour)	lb/hour
K3	- Conversion Factor (15.43)	gr/gm
Qsd	- Stack Gas Volumetric Flow Rate, Corrected to Dry, Standard Conditions	dscf/min
K2	- Conversion Factor (0.002205)	lb/gm
K1	- Conversion Factor (0.001)	gm/mg
K4	- Conversion Factor (60)	min/hour
Pe	- Particulate Matter Emission Rate	lb/hour

TEST DATA
TEST RUN #1

Pc	125.5	K4	60.00
Pg	0.1255	Qsd	9996.5983
Vmstd	49.8049	K1	0.001000
K2	0.002205	K3	15.43

PARTICULATE MATTER EMISSIONS CALCULATIONS:

1a. Total Particulate Catch :

$$Cs = Pg/Vmstd$$

$$0.1255 \quad / \quad 49.80494752$$

$$Cs = 0.0025 \text{ grams/dscf}$$

1b. $Cg = K3 * Cs$

$$15.43 \quad * \quad 0.00251983$$

$$Cg = 0.0389 \text{ grains/dscf}$$

1c. $Pcs = K2 * Cs$

$$0.002205 \quad * \quad 0.00251983$$

$$Pcs = 0.00000556 \text{ lb/dscf}$$

1d. $Pe = K4 \quad * \quad Pcs \quad * \quad Qsd$

$$60 \quad * \quad 5.5562E-06 \quad * \quad 9996.598308$$

$$Pe = 3.3326 \text{ lbs/hour} \quad \text{Total Particulate Emissions.}$$