

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section	<u>11.6</u>
Reference	<u>21</u>
Report Sect.	<u>4</u>
Reference	<u>14</u>

GAS PROCESS SURVEY

ROANOKE NO. 5

KILN SYSTEM

1979

Source category:

Plant name :

Test date :

Process :

Portland Cement
Lone Star Cement, Inc.
7/22 - 10/12/79
dry (1,3,4) & wet (5)

Date: 01/15/93

Location: Roanoke, VA

Ref. No.: 14

Basis for process rate : feed/production

Ratio: 1.50 dry

1.59 wet

Source	Type of control	Pollutant	Run No.	Emission rate, lb/hr	Process rate, ton/hr	Emission factor		Total PM emission rate, lb/hr	Total catch, mg	Filt/probe catch, mg	Impinger catch, mg
						kg/Mg	lb/ton				
Rotary kiln No. 1	Cooling tower + multiclone + ESP	BASED ON FEED RATE									
		filt. PM	45	8.14	21.0	0.194	0.388	12.9	0.1764	0.1113	0.0651
		filt. PM	46	9.85	21.9	0.225	0.450	14.5	0.1860	0.1263	0.0597
		filt. PM	47	11.08	20.7	0.268	0.535	16.4	0.2056	0.1389	0.0667
		filt. PM	48	14.51	20.7	0.350	0.701	18.4	0.2118	0.1670	0.0448
		filt. PM	49	45.52	21.0	1.08	2.17	48.0	0.4343	0.4119	0.0224
		filt. PM	50	56.43	21.0	1.34	2.69	60.2	0.5880	0.5512	0.0368
		average				0.577	1.155	Rating: B			
		cond. inor. PM	45	4.76	21.0	0.113	0.227	12.9	0.1764	0.1113	0.0651
		cond. inor. PM	46	4.65	21.9	0.106	0.213	14.5	0.1860	0.1263	0.0597
		cond. inor. PM	47	5.32	20.7	0.129	0.257	16.4	0.2056	0.1389	0.0667
		cond. inor. PM	48	3.89	20.7	0.0940	0.188	18.4	0.2118	0.1670	0.0448
		cond. inor. PM	49	2.48	21.0	0.0589	0.118	48.0	0.4343	0.4119	0.0224
		cond. inor. PM	50	3.77	21.0	0.0897	0.179	60.2	0.5880	0.5512	0.0368
		average				0.0985	0.197	Rating: B			
Rotary kiln No. 3	Cooling tower + multiclone + ESP	BASED ON FEED RATE									
		filt. PM	51	18.48	22.1	0.418	0.836	21.4	0.2114	0.1826	0.0288
		filt. PM	52	23.30	22.1	0.527	1.05	28.0	0.2975	0.2476	0.0499
		filt. PM	53	20.19	21.9	0.461	0.922	25.7	0.2837	0.2229	0.0608
		filt. PM	54	18.50	21.9	0.422	0.845	23.0	0.2477	0.1992	0.0485
		filt. PM	55	17.43	20.7	0.421	0.842	22.5	0.2498	0.1935	0.0563
		filt. PM	56	15.24	20.7	0.368	0.736	20.8	0.2440	0.1788	0.0652
		average				0.436	0.873	Rating: B			
		cond. inor. PM	51	2.92	22.1	0.0660	0.132	21.4	0.2114	0.1826	0.0288
		cond. inor. PM	52	4.70	22.1	0.106	0.213	28.0	0.2975	0.2476	0.0499
		cond. inor. PM	53	5.51	21.9	0.126	0.251	25.7	0.2837	0.2229	0.0608
		cond. inor. PM	54	4.50	21.9	0.103	0.206	23.0	0.2477	0.1992	0.0485
		cond. inor. PM	55	5.07	20.7	0.122	0.245	22.5	0.2498	0.1935	0.0563
		cond. inor. PM	56	5.56	20.7	0.134	0.269	20.8	0.2440	0.1788	0.0652
		average				0.110	0.219	Rating: B			
Rotary kiln No. 4	Cooling tower + multiclone + ESP	BASED ON FEED RATE									
		filt. PM	39	22.46	26.0	0.432	0.864	26.9	0.2569	0.2145	0.0424
		filt. PM	40	27.00	26.0	0.519	1.04	30.5	0.2965	0.2625	0.0340
		filt. PM	41	28.91	25.6	0.565	1.13	29.0	0.2456	0.2448	0.0008
		filt. PM	42	24.52	25.6	0.479	0.958	29.6	0.3167	0.2623	0.0544
		filt. PM	43	24.53	32.1	0.382	0.764	26.5	0.2397	0.2219	0.0178
		filt. PM	44	22.20	32.1	0.346	0.692	31.0	0.3794	0.2717	0.1077
		average				0.454	0.908	Rating: B			
		cond. inor. PM	39	4.44	26.0	0.0854	0.171	26.9	0.2569	0.2145	0.0424
		cond. inor. PM	40	3.50	26.0	0.0673	0.135	30.5	0.2965	0.2625	0.0340
		cond. inor. PM	41	0.09	25.6	0.00184	0.00369	29.0	0.2456	0.2448	0.0008
		cond. inor. PM	42	5.08	25.6	0.0993	0.199	29.6	0.3167	0.2623	0.0544
		cond. inor. PM	43	1.97	32.1	0.0307	0.0613	26.5	0.2397	0.2219	0.0178
		cond. inor. PM	44	8.80	32.1	0.137	0.274	31.0	0.3794	0.2717	0.1077
		average				0.0703	0.141	Rating: B			
Rotary kiln No. 5	ESP	BASED ON FEED RATE									
		filt. PM	7	21.38	102.0	0.105	0.210	45.3	0.3025	0.1428	0.1597
		filt. PM	8	4.27	102.0	0.0209	0.0418	17.1	0.2345	0.0585	0.1760
		average				0.0629	0.126	Rating: B			
		cond. inor. PM	7	23.92	102.0	0.117	0.234	45.3	0.3025	0.1428	0.1597
		cond. inor. PM	8	12.83	102.0	0.0629	0.126	17.1	0.2345	0.0585	0.1760
average				0.0901	0.180	Rating: B					

GAS PROCESS SURVEY

ROANOKE NO. 5

KILN SYSTEM

1979

**LONE STAR CEMENT INC.**

P. O. Box 27, Cloverdale, Virginia 24077

Originating Office: Roanoke Plant

Date: October 15, 1979

PERSONAL & BUSINESS CONFIDENTIAL

TO: W. J. Cavanaugh

FROM: W. W. Hurst

SUBJECT: Process Gas Survey on Roanoke No. 5 Kiln System

CC: W. L. Greer
C. W. Moore

Gas volumes, particulate emissions and compositions were tested at various process locations in the No. 5 Kiln System on September 16 & 17. Survey included hourly collection of data over periods of 6 & 8 hours covering two consecutive days. Testing was conducted in accordance with EPA Methods for stationary sources.

Objectives were:

1. Measure gas parameters at 5 different locations simultaneously.
2. Determine electrostatic precipitator efficiency based on both the "wet" and "dry" catch.
3. Determine the sulfur content of gases in the "Recoup Duct".

Results showed:

1. Average gas conditions at various locations


Location	ACFM	% H ₂ O	% CO ₂	% O ₂	Temp. °F
Stack	275,000	10.8	11.1	14.5	291
Pptr. Input	269,000	11.9	14.1	13.0	312
Preheater	174,000	13.0	24.2	7.8	338
By-Pass	181,000	4.0	5.6	17.4	660
Recoup	85,000	0.86	0.17	20.9	392

2. Precipitator efficiency on a "wet catch basis" was 98.8%; whereas, the efficiency on a "dry catch basis" was 99.3%.

October 15, 1979

3. Sulfur content of gases flowing in the recoup gas duct contained essentially no sulfur at less than 1 ppm.

Respectfully submitted


W. W. Hurst, P.E.

WWH/lbc

Supplement

Objective 4 was to rerun Objective 1. This was done on October 15.

Results Showed:

Location	ACFM	%H ₂ O	% CO ₂	% O ₂	Temp. °F
Stack	186,000	11.4	10.9	14.7	310
Pptr. Input	259,000	12.0	13.6	12.3	284
Preheater	196,000	15.2	23.9	8.4	350
By-Pass	199,000	4.9	6.2	16.7	658
Recoup	81,000	0.7	0.1	20.85	384

TABLE OF CONTENTS

	<u>Page</u>
List of Figures	ii
List of Data Tables	iii
I. Introduction	2
II. Test Equipment and Procedures	3
III. Discussion of Results	4
IV. Conclusion	8
V. Recommendations	9
Appendix	
1. Gas Parameter Raw Data, Sept. 16 & 17	
2. Gas Parameter Raw Data, Oct. 15	
3. Precipitator Efficiency Raw Data	
4. Sulfur Concentration Raw Data	

LIST OF FIGURES

<u>Figures</u>	<u>Page</u>
1. Stack Emission Test Location	10
2. Stack Sampling Traverse	11
3. Precipitator Input Test Traverse	12
4. Preheater Gas Duct	13
5. By-Pass Gas Duct	14
6. Cooler Recoup Gas Duct	15
7. Gas Parameter Test Locations	16

LIST OF DATA TABLES

<u>Table</u>		<u>Page</u>
I.	No. 5 Kiln Stack Gas Emissions	17
II.	No. 5 Kiln Precipitator Input Gases	19
III.	No. 5 Kiln Preheater Exit Gases	21
IV.	No. 5 Kiln By-Pass Gases	23
V.	No. 5 Kiln Clinker Cooler Recoup Gases	25
VI.	No. 5 Kiln System - Gas Flow Rate, Daily Averages	27
VII.	Particulate and Precipitator Efficiency	28
VIII.	No. 5 Kiln System	29
	A. Exhaust Gas Characteristics	
	B. Exhaust Gas Flow	
	C. Gas Sampling and Testing Parameters	
	D. Gas Analysis and Meteorological Conditions	
IX.	Sulfuric Acid and Sulfur Trioxide Emissions	31
X.	No. 5 Kiln System, Process Rate, Consumption & Production	33

I. INTRODUCTION

During the course of stack particulate emission testing at Roanoke, Mr. Cavanaugh requested that we divert from planned program and conduct some special tests. These special tests were conceived to produce process data that would assist Bill in his continued effort to optimize the new No. 5 Kiln System.

We were requested to conduct tests in three categories: 1. Gas volumes and associated parameters that existed in 5 locations throughout the kiln system at the present level and conditions of operation. 2. Perform efficient tests at a time when the Kopper Representative was available for optimizing the precipitator operation. 3. Determine sulfur concentration of the recoup duct gases for design consideration during a proposed modification of the duct.

The purpose of this report is to present test data and evaluate the accuracy of the results. It is not our purpose to evaluate the results as they might effect the kiln system level of uniformity of operation.

The gas volumes and associated parameters determined at the 5 testing locations were observed simultaneously on an hourly basis over a period of two days covering 14 cycles of data. Precipitator efficiency data consisted of 6 runs, in sets of 2 runs conducted simultaneously at the precipitator input and output. Each set of runs on the precipitator was conducted on different days. Sulfur determinations were made on measured volumes of gas drawn from the recoup duct over four test periods of approximately 4 hours each.

The report is divided into four major sections: 1. Test equipment and procedures are described, 2. Test results are discussed including possible process implication in the future, 3. Conclusions are stated, 4. Recommendations are offered.

Supplement

Preliminary review of test results in Category 1, mentioned above, indicated gas measurements at the various locations might not reflect the equipment operation sought. Accordingly, equipment adjustments were made to the pelletizing system by the equipment manufacturer's representative and tests were repeated.

II. TEST EQUIPMENT AND TESTING PROCEDURE

"S" type pitot tubes meeting EPA specifications for certification were used to measure velocity of duct gases along with conventional inclined manometers. All measurements were made in accordance with EPA Methods 1 & 2, Standards of Performance for New Stationary Sources.

Moisture levels of the various gas streams were determined by drawing a gas sample at about $\frac{1}{4}$ CFM continuously at the various testing stations over a period of 4-5 hrs. centered near the middle of the overall test period each day. Moisture in the gases was condensed in impingers mounted in an ice bath. All techniques were in accordance with good practice as outlined by EPA Method 4.

Integrated samples of gas at the various locations were sampled for gas composition analysis near the beginning and ending of each daily test. These gas samples were analyzed with the conventional "Orsat Equipment" for gas composition. Results were averaged to represent a daily average. Composition analysis of the various gas streams was performed as prescribed in EPA Method 3.

Temperature levels of the gases were measured with thermocouples working into digital indicators which were sensitive to $\pm 1\%$ of readings. Indicators were calibrated with a potentiometer accurate to $\pm \frac{1}{2}\%$. All temperature data met or exceeded EPA standards for this type of work.

IV. CONCLUSIONS

1. Simultaneous testing at various points in a kiln system has no substitute insofar as reflecting the true process inter-related conditions at any given period in time.

2. Conditions of gas volume, temperature, composition and moisture at the various testing locations were consistent with one another and with respect to a mass and energy balance.

3. Precipitator efficiency was significantly lowered due to the influence of the "ammonium compound" syndrome which according to EPA and/or VACB constitutes a particulate.

4. Precipitator efficiency was short of stated 99.8% level stipulated in the performance guarantee.

5. Corrosion cannot logically deteriorate the recoup duct as a result of airborne sulfuric acid and/or sulfur compounds.

Supplement

1. Rerun results developed while simultaneously measuring gas parameters at 5 test locations seemed compatible with previous work in this testing category.

2. Though equipment adjustment might have altered and/or improved the No. 5 Kiln System operation, it did not materially change gas volumes, temperatures, moisture or composition.

TABLE I

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN STACK GAS EMISSION

1979

AREA OF STACK = 78.5 SQ. FT.

PITOT TUBE COEF. = 0.83

Sept. 16
 Moisture = 11.3%
 Gas Mol. Wt. = 28.94
 Baro. Press. = 29.01" Hg.
 Duct Static Press. = -0.71" H₂O
 Duct Press. ABS. = 28.96" Hg.
 CO₂ = 10.9%
 O₂ = 14.7%
 N₂ = 74.4%

Sept. 17
 Moisture = 10.3%
 Gas Mol. Wt. = 29.11
 Baro. Press. = 29.04" Hg.
 Duct Static Press. = -0.52" H₂O
 Duct Press. ABS. = 29.00" Hg.
 CO₂ = 11.3%
 O₂ = 14.4%
 N₂ = 74.3%

Time Day	Trav. $\sqrt{\Delta p}$ " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM _s x 10 ⁵	Time Day	Trav. p. " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM _s x 10 ⁵
8:45	0.88	750	59.1	2.78	8:00	0.95	770	64.4	3.03
9:45	0.86	757	58.0	2.73	9:00	0.88	762	59.3	2.79
10:45	0.87	744	58.2	2.74	10:00	0.86	759	57.9	2.72
11:45	0.86	739	57.3	2.70	11:00	0.89	759	59.9	2.82
12:45	0.86	737	57.2	2.70	12:00	0.86	752	57.6	2.71
13:45	0.87	742	58.1	2.74	13:00	0.87	750	58.2	2.74
					14:00	0.86	752	57.6	2.71
					15:00	0.83	743	55.2	2.60
Ave/Day	0.87	745	58.0	2.73	Ave/Day	0.88	756	68.7	2.77

TABLE I - CONT.

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN STACK GAS EMISSION

1979

AREA OF STACK = 78.5 SQ. FT.

PITOT TUBE COEF. = 0.83

10/15/79

Moisture = 11.4%
Gas Mol. Wt. = 28.93
Baro. Press. = 28.89" Hg
Duct. Static Press. = -0.44" H₂O
Duct. Press. Abs. = 28.86
CO₂ = 10.9%
O₂ = 14.7%
N₂ = 74.4%

<u>Time</u> <u>Day</u>	<u>Traverse</u> <u>$\sqrt{\Delta P}$ ("H₂O)</u>	<u>Duct</u> <u>Temp (°R)</u>	<u>Gas</u> <u>Vel. (ft/sec)</u>	<u>ACFM</u> <u>(X10⁵)</u>
7:40	0.58	769	39.50	1.86
8:40	0.59	771	40.22	1.89
9:35	0.58	772	39.57	1.86
10:35	0.58	766	39.42	1.86
11:35	0.57	769	38.82	1.83
12:35	0.59	763	40.02	1.88
12:35	0.57	769	38.82	1.83
14:35	0.58	778	39.73	1.87
Ave/Day	0.58	770	39.51	1.86

TABLE II

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN PRECIPITATOR INPUT GASES

1979

AREA OF DUCT = 55.0 SQ. FT.

PITOT TUBE COEF. = 0.83

Sept. 16

Moisture = 11.9%
Gas Mol. Wt. = 29.19
Baro. Press. = 29.01" Hg.
Duct Static Press. = -6.1" H₂O
Duct Press. ABS. = 28.56" Hg.
CO₂ = 13.6%
O₂ = 13.1%
N₂ = 73.3%

Sept. 17

Moisture = 11.9%
Gas Mol. Wt. = 29.30
Baro. Press. = 29.04" Hg.
Duct Static Press. = -5.7" H₂O
Duct Press. ABS. = 28.62" Hg.
CO₂ = 14.5%
O₂ = 12.8%
N₂ = 72.7%

Time Day	Trav. $\Delta p.$ " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM ₅ x 10 ⁵	Time Day	Trav. $\Delta p.$ " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM ₅ x 10 ⁵
8:45	1.11	759	75.1	2.48	8:00	1.33	769	90.4	2.98
9:45	1.14	771	77.8	2.57	9:00	1.24	786	85.2	2.81
10:45	1.10	757	74.4	2.45	10:00	1.22	788	83.9	2.77
11:45	1.13	761	76.6	2.53	11:00	1.20	787	82.5	2.72
12:45	1.22	744	81.8	2.70	12:00	1.25	790	86.1	2.84
13:45	1.15	760	77.9	2.57	13:00	1.23	802	86.7	2.86
					14:00	1.24	785	85.1	2.81
					15:00	1.23	766	83.4	2.75
Ave/Day	1.14	759	77.3	2.55	Ave/Day	1.24	784	85.4	2.82

TABLE II CONT.

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN PRECIPITATOR INPUT GASES

1979

AREA OF DUCT = 55.0 SQ. FT.

PITOT TUBE COEF. = 0.83

10/15/79

Moisture = 12.0%
 Gas Mol. Wt. = 29.15
 Baro. Press. = 28.89" Hg
 Duct Static Press = -7.53" H₂O
 Duct Press. Abs = 28.34" Hg
 CO₂ = 13.6%
 O₂ = 12.3%
 N₂ = 74.1%

<u>Time</u> <u>Day</u>	<u>Traverse</u> <u>$\sqrt{\Delta P}$ ("H₂O)</u>	<u>Duct</u> <u>Temp (°R)</u>	<u>Gas</u> <u>Vel. (ft/sec)</u>	<u>ACFM</u> <u>(X10⁵)</u>
8:15	1.154	763	78.69	2.60
9:00	1.194	769	81.74	2.70
9:43	1.163	749	78.58	2.59
10:34	1.194	739	80.13	2.64
11:34	1.183	737	79.28	2.62
12:38	1.160	726	77.16	2.55
13:34	1.124	736	75.28	2.48
14:37	1.151	736	77.09	2.54
Ave/Day	1.165	744	78.49	2.59

TABLE III

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN PREHEATER EXIT GASES

1979

AREA OF DUCT = 33.06 SQ. FT.

PITOT TUBE COEF. = 0.83

Sept. 16

Moisture = 14.1%
Gas Mol. Wt. = 30.19
Baro. Press. = 29.01" Hg.
Duct Static Press. = -7.6" H₂O
Duct Press. ABS. = 28.45" Hg.
CO₂ = 24.3%
O₂ = 7.7%
N₂ = 68.0%

Sept. 17

Moisture = 11.9%
Gas Mol. Wt. = 30.49
Baro. Press. = 29.04" Hg.
Duct Static Press. = -5.8" H₂O
Duct Press. ABS. = 28.61" Hg.
CO₂ = 24.1%
O₂ = 7.9%
N₂ = 68.0%

Time Day	Trav. $\sqrt{\Delta p}$ " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM x 10 ⁵	Time Day	Trav. p. " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM x 10 ⁵
8:45	1.35	789	91.8	1.82	8:00	1.17	825	80.7	1.60
9:45	1.34	790	91.2	1.81	9:00	1.33	819	91.4	1.81
10:45	1.21	790	82.3	1.63	10:00	1.32	817	90.6	1.80
11:45	1.13	780	76.4	1.52	11:00	1.34	816	91.9	1.82
12:45	1.32	794	90.0	1.79	12:00	1.43	788	96.4	1.91
13:45	1.27	799	86.9	1.72	13:00	1.30	793	87.9	1.74
					14:00	1.29	798	87.5	1.74
					15:00	1.27	783	85.4	1.69
Ave/Day	1.27	790	88.4	1.72	Ave/Day	1.31	805	89.0	1.76

TABLE III - CONT.

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN PREHEATER EXIT GASES

1979

AREA OF DUCT = 33.06 SQ. FT.

PITOT TUBE COEF. = 0.83

10/15/79

Moisture = 15.2%
 Gas Mol. Wt. = 33.01
 Baro. Press. = 28.89" Hg
 Duct Static Press. = -7.57" H₂O
 Duct Press. Abs = 28.33" Hg
 CO₂ = 23.9%
 O₂ = 8.4%
 N₂ = 67.7%

<u>Time</u> <u>Day</u>	<u>Traverse</u> <u>DP ("H₂O)</u>	<u>Duct</u> <u>Temp (°R)</u>	<u>Gas</u> <u>Vel. (ft/sec)</u>	<u>ACFM</u> <u>(X10⁵)</u>
7:50	1.434	830	100.52	1.99
8:30	1.262	817	87.77	1.74
9:31	1.464	823	102.19	2.03
10:29	1.400	801	96.41	1.91
11:27	1.481	806	102.31	2.03
12:30	1.451	790	99.23	1.97
13:27	1.483	801	102.13	2.03
14:29	1.455	815	101.07	2.00
Ave/Day	1.429	810	98.95	1.96

TABLE IV

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN BYPASS GASES

1979

AREA OF DUCT = 40.11 SQ. FT.

PITOT TUBE COEF. = 0.83

Sept. 16

Moisture = 4.5%
Gas Mol. Wt. = 29.29
Baro. Press. = 29.01" Hg.
Duct Static Press. = -4.67" H₂O
Duct Press. ABS. = 28.67" Hg.
CO₂ = 6.0%
O₂ = 17.1%
N₂ = 76.9%

Sept. 17

Moisture = 3.5%
Gas Mol. Wt. = 29.19
Baro. Press. = 29.04" Hg.
Duct Static Press. = -4.66" H₂O
Duct Press. ABS. = 28.70" Hg.
CO₂ = 5.2%
O₂ = 17.7%
N₂ = 77.1%

Time Day	Trav. p. " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM x 10 ⁵	Time Day	Trav. p. " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM x 10 ⁵
8:45	0.86	1110	69.9	1.69	8:00	0.94	1125	76.9	1.85
9:45	0.96	1110	77.9	1.87	9:00	0.95	1102	77.3	1.86
10:45	0.93	1100	75.8	1.82	10:00	0.95	1118	78.0	1.88
11:45	0.88	1150	73.4	1.77	11:00	0.93	1128	76.7	1.85
12:45	0.87	1110	70.6	1.70	12:00	0.91	1134	75.3	1.81
13:45	0.93	1105	75.9	1.83	13:00	0.91	1128	74.6	1.79
					14:00	0.91	1141	75.6	1.82
					15:00	0.94	1115	76.8	1.85
Ave/Day	0.91	1116	73.9	1.78	Ave/Day	0.93	1124	76.5	1.84

TABLE IV - CONT.

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN BYPASS GASES

1979

AREA OF DUCT = 40.11 SQ. FT.

PITOT TUBE COEF. = 0.83

10/15/79

Moisture = 4.9%
Gas Mol. Wt. = 29.09
Baro. Press. = 28.89" Hg
Duct Static Press. = -4.98" H₂O
Duct Press. Abs = 28.52" Hg
CO₂ = 6.2%
O₂ = 16.7%
N₂ = 77.1%

<u>Time</u> <u>Day</u>	<u>Traverse</u> <u>$\sqrt{\Delta P}$ ("H₂O)</u>	<u>Duct</u> <u>Temp (°R)</u>	<u>Gas</u> <u>Vel. (ft/sec)</u>	<u>ACFM</u> <u>(X10⁵)</u>
7:30	1.018	1103	83.27	2.00
8:30	1.005	1116	82.69	1.99
9:30	1.005	1107	82.36	1.98
10:30	1.011	1100	82.59	1.99
11:30	0.995	1142	82.81	1.99
12:30	0.999	1088	81.16	1.95
13:30	1.001	1144	83.39	2.01
14:30	1.001	1145	83.43	2.01
Ave/Day	1.004	1118	82.71	1.99

TABLE V

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN CLINKER COOLER RECOUP GASES

1979

AREA OF DUCT = 25.22 SQ. FT.

PITOT TUBE COEF. = 0.83

Sept. 16
 Moisture = 0.72%
 Gas Mol. Wt. = 28.80
 Baro. Press. = 29.01" Hg.
 Duct Static Press. = 0.18" H₂O
 Duct Press. ABS. = 29.02" Hg.
 CO₂ = 0.25%
 O₂ = 20.95%
 N₂ = 78.8%

Sept. 17
 Moisture = 1.0%
 Gas Mol. Wt. = 28.74
 Baro. Press. = 29.04" Hg.
 Duct Static Press. = 0.16" H₂O
 Duct Press. ABS. = 29.05" Hg.
 CO₂ = 0.1%
 O₂ = 20.9%
 N₂ = 79.0%

Time Day	Trav. $\sqrt{\Delta P}$. " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM x 10 ⁵	Time Day	Trav. p. " H ₂ O	Duct Temp °R	Gas Vel. Ft/Sec	ACFM x 10 ⁵
8:45	0.79	834	56.0	0.85	8:00	0.78	823	54.9	0.83
9:45	0.77	870	55.7	0.84	9:00	0.77	767	52.4	0.79
10:45	0.76	877	55.2	0.84	10:00	0.78	827	55.1	0.83
11:45	0.74	976	56.7	0.86	11:00	0.78	814	54.6	0.83
12:45	0.79	826	55.7	0.84	12:00	0.78	862	56.2	0.85
13:45	0.79	860	56.9	0.86	13:00	0.80	805	55.7	0.84
					14:00	0.76	887	55.6	0.84
					15:00	0.78	848	55.8	0.84
Ave/Day	0.77	874	56.0	0.85	Ave/Day	0.78	829	55.0	0.84

TABLE V - CONT.

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN CLINKER COOLER RECOUP GASES

1979

AREA OF DUCT = 25.22 SQ. FT.

PITOT TUBE COEF. = 0.83

10/15/79

Moisture = 0.76%
Gas Mol. Wt. = 28.73
Baro. Press. = 28.89" Hg
Duct Static Press. = 0.41" H₂O
Duct Press. Abs = 28.92" Hg
CO₂ = 0.1%
O₂ = 20.85%
N₂ = 79.05%

<u>Time</u> <u>Day</u>	<u>Traverse</u> <u>$\overline{U\Delta P}$ ("H₂O)</u>	<u>Duct</u> <u>Temp (°R)</u>	<u>Gas</u> <u>Vel. (ft/sec)</u>	<u>ACFM</u> <u>(X10⁵)</u>
8:00	0.78	833	55.41	0.84
8:30	0.74	866	54.33	0.82
9:30	0.75	840	53.50	0.81
10:25	0.75	818	52.80	0.80
11:25	0.73	868	52.94	0.80
12:25	0.77	803	53.71	0.81
13:25	0.74	855	53.26	0.81
14:25	0.74	872	53.79	0.81
Ave/Day	0.75	844	53.72	0.81

TABLE VI

ROANOKE PROCESS GAS SURVEY

NO. 5 KILN SYSTEM - GAS FLOW RATE, DAILY AVERAGES

1979

Testing Date - Sept. 16
6 Hr. Average

Location	Temp. °F.	ACFM	% Moisture	% CO ₂
Stack Gases	285	273,000	11.3	10.9
Precipitator Input Gases	299	255,000	11.9	13.6
Pre-Heater Exit Gases	330	172,000	14.1	24.3
Kiln By-Pass Gases	656	179,000	4.5 * (Est.)	6.0
Clinker Cooler Recoup Gases	414	85,000	0.7	0.3

Testing Date - Sept. 17
8 Hr. Average

Location	Temp. °F.	ACFM	% Moisture	% CO ₂
Stack Gases	296	287,000	10.3	11.3
Precipitator Input Gases	324	282,000	11.9	14.5
Pre-Heater Exit Gases	345	176,000	11.9	24.1
Kiln By-Pass Gases	664	184,000	3.6 * (Est.)	5.2
Clinker Cooler Recoup Gases	369	83,000	1.0	0.1

* Value based on CO₂ balance and moisture level indicated for recoup and preheater gases.

Testing Date - Oct. 15
8 Hr. Average

Location	Temp. °F.	ACFM	% Moisture	% CO ₂
Stack	310	186,000	11.4	10.9
Precipitator Input Gases	284	259,000	12.0	13.6
Pre-Heater Exit Gases	350	196,000	15.2	23.9
Kiln By-Pass Gases	658	199,000	4.9 * (Est.)	6.2
Clinker Cooler Recoup Gases	384	81,000	0.7	0.1

TABLE VII

ROANOKE EMISSION SURVEY

PARTICULATE AND PRECIPITATOR EFFICIENCY

1979

<u>Runs</u>	<u>Date</u>	<u>Location</u>	<u>Particulate Emissions</u>		<u>% Efficiency</u>	
			<u>Wet*</u>	<u>Dry*</u>	<u>Wet</u>	<u>Dry</u>
9	8/4	Pptr. Input	4910	4830	98.7	99.2
10		Stack	65.0	37.6		
11	8/5	Pptr. Input	6630	6340	98.6	99.2
12		Stack	89.7	53.5		
13	8/6	Pptr. Input	7670	7530	99.0	99.5
14		Stack	76.9	38.5		
Average			77.2	43.2	98.8	99.3

* Emission "Wet" weight includes impinger catch
Emission "Dry" weight excludes impinger catch

TABLE VIII

ROANOKE EMISSION SURVEY

NO. 5 KILN SYSTEM - 1979

A. EXHAUST GAS CHARACTERISTICS

Run No.	Pitot Tube Factor	Temp. °R	% H ₂ O In Gas	Gas Density	Stack Gas Press. "Hg.	Static Gas Press. "H ₂ O
9	0.83	846	13.2	28.84	28.38	-6.0
10	"	789	12.1	28.75	28.87	+0.72
11	"	847	9.8	29.12	28.41	-6.0
12	"	777	12.2	28.82	28.91	+0.74
13	"	849	11.9	29.05	28.38	-6.0
14	"	799	12.7	28.76	28.87	+0.65

B. EXHAUST GAS FLOW

Run No.	Temp. °F	Duct Area Sq. Ft.	$\sqrt{\Delta P}$ "H ₂ O	Velocity Ft./Sec	Volume ACFM	CFH St. Cond. Dry x 10 ⁶
9	386	55.0	1.29	93.05	307,000	9.49
10	329	78.5	0.88	61.40	289,000	9.71
11	387	55.0	1.28	91.89	303,000	9.74
12	317	78.5	0.89	60.98	287,000	9.96
13	389	55.0	1.28	92.16	304,000	9.51
14	339	78.5	0.91	62.67	295,000	10.10

C. GAS SAMPLING AND TESTING PARAMETERS

Run No.	% Iso-Kinetic	Nozzle Size Sq. Ft.	Test Duration Min.	Meter Temp. °R	Meter Volume .Ft.	Meter Volume Std. Cond. Cu.Ft.	Meter Press. "Hg.	Meter Press. "ΔH" "H ₂ O
9	101.3	0.000085	140	541	36.67	34.62	28.84	0.23
10	96.7	0.000289	144	541	87.30	82.62	28.91	1.22
11	98.1	0.000085	140	541	36.43	34.44	28.88	0.23
12	94.3	0.000287	144	541	88.00	82.62	28.95	1.26
13	100.5	0.000085	140	543	36.27	34.09	28.83	0.19
14	87.7	0.000287	144	543	83.92	79.16	28.92	1.31

TABLE VIII - CONT'D

ROANOKE EMISSION SURVEY

NO. 5 KILN SYSTEM - 1979

D. GAS ANALYSIS AND METEOROLOGICAL CONDITIONS

Run No.	Date	Gas Analysis			Rel. Humidity %	Ambient Temp. °F	Baro. Press. "Hg
		%CO ₂	%O ₂	%N ₂			
9	8/4	12.2	13.6	74.2	76	68	28.82
10	8/4	10.2	15.0	74.8	76	68	28.82
11	8/5	11.0	14.2	74.6	81	70	28.86
12	8/5	10.8	15.0	74.2	81	70	28.86
13	8/6	12.5	13.5	74.0	60	77	28.82
14	8/6	10.8	15.0	74.2	60	77	28.82

TABLE IX

HOUSTON EMISSION STUDY

SULFURIC ACID & SULFUR TRIOXIDE EMISSION - EPA METHOD 8

1979

- (A) Normality of Std. H_2SO_4 - 0.010
 (B) Mls. Std. H_2SO_4 used - 20.00
 (C) Mls. Barium Perchlorate Soln. Req'd. - 20.30
 (D) Normality of Ba (ClO_4) $3H_2O$ Soln. - 0.0095

$$(D) = (A) (B) / (C)$$

Sample No.	Location of Test	(E) Tot. Vol. Alcohol / SO_2 Mls.	(F) Aliquot titrated Mls.	(G) Quantity Factor (E)/(F)	(H) Vol. Gas Sampled @ Std. Cond. Dry - Cu.Ft.	(I) Vol. Ba(ClO_2) Soln. titrant Mls.
27	Recoup	223	50	4.46	60.90	0.1
28	Gas	215	50	4.30	77.84	0.1
29	Duct	216	50	4.32	58.64	0.1
30	-	219	50	4.38	86.1	0.15


Sample No.	(J) Blank Corr. -Mls.	(K) Net Titrant Mls. (I-J)	(L) Run Const. (1.08×10^{-4}) (D)=(L) $\times 10^{-6}$	(M) Conc. H_2SO_4 Lbs/Std. C.F. Dry (L) (K) (G) (H) $\times 10^{-6}$	(N) Conc. as Sulfur Lbs/Std. C.F. Dry (.327) (M) $\times 10^{-6}$	H_2SO_4 Lbs/Hr. Std. Cond. Dry (M) (CFH)
27	0.1	0	1.03	-	-	-
28	0.1	0	1.03	-	-	-
29	0.1	0	1.03	-	-	-
30	0.1	0	1.03	-	-	-

EQUIPMENT ARRANGEMENT

GAS PARAMETER TEST LOCATIONS

NEW PLANT

FIGURE 7



KEY

- A - Stack
- B - Precipitator Input
- C - Preheater
- D - By-Pass
- E - Recoup

TABLE IX

HOUSTON EMISSION STUDY

SULFUR DIOXIDE EMISSION - EPA METHOD 8


1979

- (A) Normality of Std. H_2SO_4 - 0.010
 (B) Mls. Std. H_2SO_4 used - 20.00
 (C) Mls. Barium Perchlorate Soln. Req'd. - 20.30
 (D) Normality of $Ba(ClO_4)_2 \cdot 3H_2O$ Soln. - 0.0095

$$(D) = (A) (B) / (C)$$


Sample No.	Location of Test	(E) Tot. Vol. Peroxide/ SO_2 Mls.	(F) Aliquot titrated Mls.	(G) Quantity Factor (E)/(F)	(H) Vol. Gas Sampled @ Std. Cond. Dry - Cu.Ft.	(I) Vol. $Ba(ClO_2)$ Soln. titrant Mls.
27	Recoup	700	5.0	140	60.90	0.3
28	Gas	670	5.0	134	77.84	0.2
29	Duct	650	5.0	130	58.64	0.2
30		670	5.0	134	86.1	0.15
Sample No.	(J) Blank Corr. -Mls.	(K) Net Titrant Mls. (I-J)	(L) Run Constant (7.05×10^{-5}) (D) $\times 10^{-7}$	(M) Conc. SO_2 Lbs/Std. C.F. Dry $(L)(K)(G)$ (H) $\times 10^{-7}$	(N) Conc. as Sulfur Lbs/Std. C.F. Dry $(0.5)(M)$ $\times 10^{-7}$	SO_2 Lbs/Hr. Std. Cond. Dry (M) (CFH)
27	0.1	0.2	6.7	3.08	1.54	0.77
28	0.1	0.1	6.7	1.54	0.77	0.46
29	0.1	0.1	6.7	1.54	0.77	0.40
30	0.1	0.05	6.7	0.77	0.39	0.24

FIGURE 1
KILN STACK EMISSION SAMPLING



- 11 -
ROADSIDE DUST SURVEY
KILN STACK
VELOCITY & PARTICULATE
SAMPLING TRAVERSE


FIGURE 2



PLAN VIEW

CROSS SECTIONAL AREA = 78.5 SQ. FT.


NO. 5 PRECIPITATOR INPUT DUCT
VELOCITY AND PARTICULATE SAMPLING TRAVERSE



CROSS SECTIONAL AREA = 55.0 SQ. FT.

ROANOKE EMISSIONS SURVEY
NO. 5 PREHEATER GAS DUCT
VELOCITY SAMPLING TRAVERSE

FIGURE 4




CROSS SECTIONAL AREA = 33.06

ROANOKE EMISSIONS SURVEY

NO. 5 BY-PASS GAS DUCT

VELOCITY SAMPLING TRAVERSE


FIGURE 5



CROSS SECTIONAL AREA = 40.11 SQ. FT.

- 15 -
ROANOKE EMISSIONS SURVEY
NO. 5 CLINKER COOLER RECOUP GAS DUCT
VELOCITY SAMPLING TRAVERSE

FIGURE 6



CROSS SECTIONAL AREA = 25.22 SQ. FT.

TABLE X

ROANOKE EMISSION SURVEY

OPERATOR 1st

HARTINSTEALLDATE: 9-16-79

2nd

Burant

NO. 5 KILN SYSTEM

3rd

RandyPROCESS RATE, CONSUMPTION & PRODUCTION
1979

TIME	0700	0900	1100	1300	1500	1700	1900	2100	2300	0100	0300	0500
KILN SPEED	115	115	115	115	115	115	115	115	115	115	115	115
FEED RATE	110	110	110	110	110	110	110	110	110	110	110	110
WATER RATE	57.8	58.0	58.0	59.7	59.4	59.1	58.9	58.7	59.1	58.7	59.0	59.
COAL RATE	9.8	9.0	9.8	9.9	10.1	9.9	9.9	9.9	9.9	9.9	10.0	10.4
KILN OXYGEN	0.48	0.20	0.39	0.18	0	.24	1.75	1.33	0.87	0.80	0.50	0.87
I.D. FAN SPEED	671	671	671	671	669	669	669	669	669	669	669	669
PREHEAT FAN DAMPER	47	47	47	47	46	46	46	46	46	46	46	46
BYPASS FAN DAMPER	57	57	57	57	57	57	57	57	57	57	57	57
RECIP. EXIT TEMP.	308	318	306	303	309	308	306	299	298	302	334	327
KILN EXIT TEMP.	1943	1965	1954	1938	1938	1953	1950	1942	1938	1936	1950	1968
SECONDARY AIR TEMP.	2069	2081	2056	2242	2176	2231	2225	2189	2192	2164	2122	2122
COOLER EXHAUST TEMP.	370	470	530	392	400	472	400	329	342	372	326	291
RECUP FAN SPEED	489	491	491	491	492	492	492	492	496	494	495	495
RECUP FAN DAMPER	40	40	40	40	40	40	40	40	40	40	40	40
INCLINE COOLER SPEED	6.8	6.8	8.0	6.7	5.6	6.4	5.5	5.8	5.9	4.5	4.5	7.1
#1 UNDERGRATE PRESS.	15.8	15.9	16.3	15.9	15.9	15.9	15.9	16.1	15.8	15.0	14.9	16.0
HORIZONTAL COOLER SPEED	9.1	9.2	8.8	8.9	9.2	9.1	9.2	9.1	9.2	9.1	9.3	9.3
#4 UNDERGRATE PRESS.	5.7	5.6	6.6	6.1	5.7	5.1	5.6	5.9	6.2	6.5	6.2	6.1
#1 FAN DAMPER	46	46	46	46	46	46	46	46	46	46	46	46
#2 FAN DAMPER	48	48	48	48	48	48	48	48	48	48	48	48
#3 FAN DAMPER	48	48	48	48	48	48	48	48	48	48	48	48
STACK OPACITY	14	14	14	14	13	13	16	14	13	13	14	14

ROANOKE EMISSION SURVEY

OPERATOR 1st

DATE: 9-17-79

NO. 5 KILN SYSTEM

2nd

3rd

PROCESS RATE, CONSUMPTION & REDUCTION

1979

TIME	0700	0900	1100	1300	1500	1700	1900	2100	2300	0100	0300	0500
KILN SPEED	115	115	115	115	115	115						
FEED RATE	110	110	110	110	110	110						
WATER RATE	59.3	59.4	57.4	59.4	58.9	57.4	D					
COAL RATE	10.0	9.8	9.5	9.5	9.5	9.5		D				
KILN OXYGEN	.20	.10	1.58	1.19	.83	.96	D					
IND. FAN SPEED	677	676	677	677	677	674		D				
PREHEAT FAN DAMPER	45	45	45	45	46	46	W					
BYPASS FAN DAMPER	58	58	58	58	56	56		W				
CIP. EXIT TEMP.	319	320	327	321	321	314	N					
KILN EXIT TEMP.	1957	1944	1926	1924	1912	1910		N				
SECONDARY AIR TEMP.	2241	2242	2241	2242	2242	2142						
COOLER EXHAUST TEMP.	390	369	421	473	526	530						
RECOUP FAN SPEED	496	481	478	478	478	480						
RECOUP FAN DAMPER	40	40	40	40	40	40						
INCLINE COOLER SPEED	7.1	7.3	8.1	4.7	4.1	6.0						
#1 UNDERGRATE PRESS.	16.1	15.9	16.0	15.3	15.0	15.7						
HORIZONTAL COOLER SPEED	8.8	8.9	8.9	9.0	9.0	8.9						
#4 UNDERGRATE PRESS.	4.3	4.6	5.3	5.2	6.6	6.0						
#1 FAN DAMPER	48	48	48	48	48	48						
#2 FAN DAMPER	48	48	48	48	48	50						
#3 FAN DAMPER	48	48	48	48	48	50						
STACK OPACITY	14	14	14	13	14	13						

TABLE X - CONT.

ROANOKE EMISSION SURVEY OPERATOR 1st RandyDATE: 10-15-79

NO. 5 KILN SYSTEM

2nd

PROCESS RATE, CONSUMPTION & PRODUCTION

3rd

1979

TIME	0700	0900	1100	1300	1500	1700	1900	2100	2300	0100	0300	0500
KILN SPEED	115	115	115	115								
FEED RATE	110	110	110	110								
WATER RATE	54.4	55.2	54.9	55.9								
COAL RATE	10.3	10.1	10.0	10.0								
KILN OXYGEN	-	-	-	-								
IP. FAN SPEED	689	690	689	689								
PREHEAT FAN DAMPER	48	48	48	48								
BYPASS FAN DAMPER	58	56	56	56								
IP. EXIT TEMP.	317	323	315	311								
KILN EXIT TEMP.	1907	1879	1887	1893								
SECONDARY AIR TEMP.	2150	2065	2167	2197								
COOLER EXHAUST TEMP.	320	497	480	360								
ECOUF FAN SPEED	487	487	486	486								
ECOUF FAN DAMPER	40	40	40	40								
ENGINE COOLER SPEED	5.9	5.2	5.4	4.5								
UNDERGRATE PRESS.	15.9	15.6	15.4	15.6								
HORIZONTAL COOLER SPEED	7.5	7.4	7.4	7.5								
UNDERGRATE PRESS.	5.1	5.8	5.2	4.3								
IN DAMPER	46	46	46	46								
OUT DAMPER	48	47	47	47								
PAN DAMPER	48	47	47	47								

OPACITY 13 12 12 12

III. DISCUSSION OF RESULTS

(A) Gas Parameters At Different Locations

Results showed range of variation of parameters during testing at various stages in process remained rather constant. For details note raw data in Appendix I, as well as, summary data included in Tables I-V.

Table V showed stack gases to have a volume of around 280,000 ACFM with 10-11% moisture derived from both combustion and pelletizing processes. CO₂ at around 11% with oxygen at 14.5% was consistent with cement processes that theoretically exit gases from the kiln at 35-37% CO₂. (No excess air and assuming all CO₂ liberation from raw mix occurs in the kiln.) The stack gas temperature was around 300°F.

Precipitator input gas volume was somewhat less than stack gases at slightly higher moisture (1%), slightly richer in CO₂ and at a little higher temperature (200-250°F). Accordingly, all precipitator input gas characteristics were exactly what might be anticipated and were at the proper magnitude to indicate a slight infiltration of outside air between the two testing locations - probably around the induction fan.

Preheater gases of considerable volume @ 175,000 ACFM showed a rather high CO₂ level indicating limited adulteration by outside air. Preheater temperatures were quite low @ 330-345°F. When one considered exit gases from the kiln were 1900°-2000°F, the obvious conclusion was that excellent heat transfer from kiln exit gases to kiln feed pellets existed since this was the only way to lower kiln exit gas temperatures drastically and still maintain a high level of CO₂. Also, note the moisture was around 13% which was consistent with the CO₂ level and the combustion process. Off hand, one might conclude that 13% moisture @ 24% CO₂ was not consistent with 12% moisture @ 14% CO₂ as shown for gas composition later in process at the precipitator input. However, all comes into balance when one considers the air dilution of gases from 24% CO₂ to 14% CO₂ (water dilution from 13% to around 7.5%) was associated with the moisture addition from pellets. Pellet water raised the gas moisture level to around 12%, as shown, for precipitator input gases.

Bypass gas at 650°F and 6% CO₂ was about what one would expect if $\frac{1}{2}$ of the bypass volume consisted of kiln gases @ 24% CO₂ and 1950°F were mixed with 314 ambient and recoup air. This being the case, about 45,000 ACFM kiln exit gases were bypassed rather than preheated the raw mix.

Recoup gases showed a relatively low temperature since they were produced by heat transfer from hot clinker at the low potential section of the clinker cooler. Since "recoup" gases consisted only of heated ambient air, one would expect the CO₂ and moisture level of recoup gases to be very low, essentially zero, which was the case.

(B) Precipitator Efficiency

Runs 9-14 reported 3 sets of runs made on the stack and precipitator input simultaneously. The stack and precipitator "output" were considered to be one and the same insofar as the end result was concerned. Note, results were reported at both ends of the precipitator (input & stack) on a "Lbs/Hr" basis making the recorded weight rates independent of volume rate. This precluded any

error that might seem to occur due to infiltrated air. That is to say, infiltrated air would decrease the concentration of particulates but yield a larger volume so that the product of concentration times volume remains the same.

Simultaneous collection of data before and after a unit under test eliminated any error due to variance that might occur if the unit input and output were measured singularly at different periods in time.

Note, the precipitator efficiency (Table VII) has been reported by two methods - "Wet Efficiency" and "Dry Efficiency". The output component of "Wet Efficiency" consisted of particulates that were collected on a filter plus material that passed the filter - probably for the most part as a vapor - and was absorbed in the water of the impingers. The impinger water, following testing, was evaporated leaving the absorbed material as solid crystals. The output component of "Dry Efficiency" consisted of particulate solids that one would normally consider as dust which was collected on the filter.

Also, consider that the "wet emission" was roughly twice the magnitude of the "dry emissions" which made a significant difference in the calculated precipitator efficiency as shown in the Table VII under results on a wet and dry basis.

The No. 5 Roanoke kiln system associated possibly with the nature of Roanoke raw materials gives rise to an "ammonium compound" phenomenon that has not been noted at other Lone Star plants. This is not to say that the phenomenon is non-existent at other Lone Star plants, but we have not detected same. Of concern was the order of magnitude of this phenomenon which was notably greater at Roanoke No. 5 kiln system.

The No. 5 kiln system produced the usual dust which was granular in nature and remained as a well established particulate at kiln temperatures (except the Burning Zone). These are the type of particulates which do not easily undergo a change of state (solid, liquid or vapor) and that the precipitator was designed to remove since they possess electrostatic characteristics and can be attracted to electrodes for concentration and removal from the gases.

Also, the kiln system produces an "ammonium compound" that has been associated with sulfur, sodium and potassium with possible trace elements. The nature of the ammonium compounds, which may or may not be a solid at kiln system exit temperatures, but rather a vapor, does not seem to be effectively removed by electrostatic precipitation. There was some evidence that the ammonium compound existed largely as a vapor at stack temperatures of 300°F and remains as a vapor to below 250°F (filter oven temperature). This was the reason why most of the ammonium compound ended up in the impinger with little to no evidence of salting out in the pores of the filter. If only a portion of the ammonium compound that was collected in the impinger condensed in the pores of the filter there should be a notable pressure drop across the filter, as well as, some indication of the ammonium compound white crystals on the filter.

The ammonium compound ($\text{NH}_4 \text{SO}_3 \cdot \text{NAO} \cdot \text{K}_2\text{O}$, etc.) has been cited in the literature as a kiln product from other cement clinker kilns in this country and abroad so that it was not unique to the Roanoke No. 5 Kiln System.

The practical significance of the existing "ammonium compound" was that it loads the stack gases with particulate emissions, though ironically, as it leaves the processing equipment (pptr. & stack), it was mainly a vapor. Unfortunately, the definition of particulate emissions included the recovered solids from impingers in the Commonwealth of Virginia so that the vaporous ammonium might just as well be conventional particulates, such as, clinker or raw mix dust, with respect to the regulations.

Recalling again, data in Table VII, showed that the difference between "wet" & "dry" particulates was the "ammonium compound" which was about half of the total. That is to say, inclusion of the "ammonium compound" almost doubles the particulate emission burden so that the conventional dust designed for removal by the electrostatic precipitator can be only about half the allowable limit if the total load remained in compliance.

It should clearly be pointed out for future consideration - like the proposed Georgetown Plant - that at locations where:

(a) the process equipment configuration and/or raw materials significantly produce the "ammonium compound" phenomenon and,

(b) local emission regulations include the impinger catch, particulate abatement processing should be considered as a double function.

(1) Electrostatic precipitation or bag house filtering to remove conventional particulates.

(2) Spray System, etc. for the absorption and removal of "ammonium compounds" from the process gases.

At Roanoke Bill Cavanaugh has conveniently solved the "ammonium compound" problem of excessive particulate emissions (conventional and ammonium compounds) by minimizing the volume of stack gas. This has been accomplished by using stack gases for drying the raw mix. However, when the total kiln gases were emitted from the kiln stack - though the precipitator was operated at peak conditions - the wet particulate emissions consistently exceeded the allowable limit. (See Virginia, 1979, Emission Survey Report, Table I, No Gas Bypassed)

Though splitting the stack gas load was conceived in the interest of fuel economy, its side benefit of reducing stack emissions from the kiln stack has developed as a major plus for the Gas Bypass System.

People being what they are, it is conceivable that the time might come when the Regulatory Group might view the Kiln Bypass System, not only as an economic move to recover energy, but speculate that it was conceived primarily as a means to circumvent the intent of the regulations by restricting particulate emissions. If this happens, undoubtedly we would be obliged to test the raw mill stack which potentially could open a new can of worms. At this time we have no idea as to the particulate nature of the raw mill stack but suffice it to say, raw mill emission allowables are less than kiln stack emission allowables. (See Virginia Regulations)

(C) Sulfur Determinations

Sulfur analysis tabulated in Table IX indicate concentrations in recoup gases at less than 1 ppm. Though the lower limit of defection was probably beyond the actual sulfur content of the gas, the fundamental objective was accomplished. Similar testing of clinker cooling gases has shown essentially no sulfur content though hot clinker invariably freezes some sulfur on cooling that might conceivably be liberated to the cooling gases.

Supplement

It would seem the rerun on gas parameters measured simultaneously was performed with tabulated results added to Tables 1-5 on October 15. These results were summarized in Table VI so that they could be readily compared with work done in September without having to turn a page.

In a word, the work done on October 15 was just about a carbon copy of work done on September 16, as well as, in close agreement with work on September 17.

There are two noticable differences in the rerun data vs. initial work.

1. The ACFM up the stack on September 16 & 17 included all the kiln process gas; whereas, the ACFM up the stack on October 15 included only a portion of the kiln process gas. The difference between 186,000 ACFM shown on October 15 and approximately 300,000 ACFM shown in September represents bypass gas that was used to dry raw mix for a one raw mill operation.

2. Note the stack temperature recorded for October 15 was 310°F; whereas, the precipitator input temperature was 284°F. Of course this cannot be the case - especially over an 8 hour period with approximately 200 individual temperature entries making up the average at each location. The indicated temperature at each location showed the normal and usual variation. Accordingly, we were led to believe the discrepancy was due to one or both of the thermocouple indicators being out of calibration - a fact which was confirmed later.

V. RECOMMENDATIONS

1. For best system testing results, simultaneous testing of the various component parts should be undertaken whenever practical.

2. New particulate abatement systems should include adequate facilities for removal of conventional particulates as well as pseudomorphic "ammonium compounds" if their presence can be anticipated.

Supplement

If equipment modification or adjustments are calculated to influence gas flow in the kiln system, it is recommended testing should be done just before the adjustment and repeated immediately thereafter in order to yield the best data on system gas behavior.

Volume Measurements
and SOX and NOX |
Monitoring

Roanoke Plant
11/29,30 - 12/1
1977

**LONE STAR INDUSTRIES, INC.**

P. O. Box 2148, Houston, Texas 77001

Originating Office: Central Research Laboratory

Date: December 7, 1977

PERSONAL & BUSINESS CONFIDENTIAL

TO: Mr. W. J. Cavanaugh
Roanoke Plant

FROM: D. V. Vu

SUBJECT: Volume Measurements and SOX and NOX Monitoring

CC: Messrs: G. F. Messinger
C. D. Fehnel
C. W. Moore
W. W. Hurst
J. D. Davenport

Dear Mr. Cavanaugh:

At your request, two tests were made at the plant on three days: November 29, 30 and December 1st, 1977.

The first test was to measure the Volume Flow rate and Temperature of the kiln exit gas at two locations: Cooling tower inlet for kiln #1, and cooling tower outlet for kiln #4. The test was conducted in accordance with EPA - Method 2 given in Federal Register, Vol. 42, No. 160, dated August 18, 1977. The results showed:

<u>Date</u> <u>(1977)</u>	<u>Location</u>	<u>Volume</u> <u>(ACFM)</u>	<u>Temperature</u> <u>(F°)</u>
11-29	Cooling Tower Inlet (Kiln #1)	80,000	1074
11-29	Cooling Tower Outlet (Kiln #4)	93,600	773

The second test was to monitor continuously and simultaneously the SOX and NOX levels by Envirometrics Analyzer, Model NS-300, at three different locations of kiln #5. The results showed:

December 7, 1977

<u>Date (1977)</u>	<u>Location</u>	<u>Temperature (°F)</u>	<u>SOX, ppm (Dry Basis)</u>	<u>NOX, ppm (Dry basis)</u>
11-30	Precipitator Outlet	~ 400	80-100	450-500
12-1	Preheater Inlet (Under Grate)	~ 700	< 10	900-1000
12-1	Kiln Exit (Over Grate)	~ 1800	< 10	> 1000

Also, enclosed please find all the data and calculations of the results.

Respectfully submitted,



D. V. Vu
Environmental Control Engineer

DVV/po

Encl.

Discussion:

The objective of the first test was originally planned to measure the volume flow rate of exit gas of kiln #1 and #4 at the Cooling Tower Inlet of each kiln, (See Fig. 1 for plant equipment arrangement). There are 4 ports at Cooling Tower Inlet Duct of Kiln #1, but only one port at Cooling Tower Inlet Duct of Kiln #4, and this only port was insufficient to measure the volume flow rate of Kiln #4's exit gas, according to EPA - Method 2. Therefore, the volume measurement for Kiln #4 was instead made at its Cooling Tower Outlet Duct which has enough ports (4), and the volume was greater than the one measured at Kiln #1 Exit (even though the kilns are about the same size), due to the added cooling water.

Three different locations of Kiln #5 (see Fig. 4): Precipitator Outlet, Preheater Inlet (under grate) and Kiln Exit (over grate) were chosen to measure the SOX and NOX concentrations. Each location has only one port which, however, is sufficient for the sample probe to collect gas sample for Envirometrics Analyzer. The sample probe consists of a stainless steel filter which was connected to a 5/8" (O.D.) stainless steel rod by a galvanized coupling. At the kiln exit location (over grate), due to a high temperature ($\sim 1800^{\circ}\text{F}$), this coupling had melted and dropped the filter in the feed bed, after nearly 10 minutes of sampling and monitoring by the Analyzer. This accident, however, was expected and discussed before the sample probe was put in the kiln exit port, but it was worth this to know how long the gas sample could be collected and analyzed so that the SOX and NOX levels would be recorded at this location. It was noted that the NOX concentration at this location was much higher than the analyzer's maximum range which is 1000 ppm.

The SOX level at the precipitator outlet of kiln #5 was about 100 ppm which should be nearly the same as the SOX concentration in the stack. This result will be confirmed again by conducting EPA - Method 8 at the stack in a future date.

Gas Flow Rate Calculations:

1. Kiln #1 Exit Gas (Before Cooling Tower)

(a) Velocity

The formula for calculating gas velocity, given by EPA - Method 2, is:

$$V = 85.49 \times C_p \times (\sqrt{\Delta P})_{\text{avg.}} \times \sqrt{\frac{T_s (\text{avg.})}{P_s \times M_s}}$$

where:

$$\begin{aligned} *C_p &= \text{Avg. Pitot Tube Coefficient} \\ &= 0.79, \text{ from Table 1} \end{aligned}$$

$$\begin{aligned} *(\sqrt{\Delta P})_{\text{avg.}} &= \text{Square Root of Velocity head, avg.} \\ &= 0.63, \text{ from Table 1} \end{aligned}$$

$$\begin{aligned} *T_s (\text{avg.}) &= \text{Average Duct Temperature (°R)} \\ &= 1534 \text{ °R, from Table 1} \end{aligned}$$

$$\begin{aligned} *P_s &= \text{Absolute Duct gas Pressure, mm Hg} \\ &= P_{\text{bar}} + P_{\text{static}} \\ &= 28.96 - \frac{(0.40)}{(13.6)} \\ &= 28.93 \text{ mm Hg} \end{aligned}$$

$$\begin{aligned} *M_s &= \text{Molecular Weight of Duct Gas, Wet Basis,} \\ &\quad \text{Lb/Lb. mole} \\ &= M_d (1 - \% \text{ H}_2\text{O}) + 18(\% \text{ H}_2\text{O}) \end{aligned}$$

$$\begin{aligned} *M_d &= \text{Molecular weight of Duct Gas, Dry Basis,} \\ &\quad \text{Lb/Lb. mole} \\ &= 44 (\% \text{ CO}_2) + 32(\% \text{ O}_2) + 28(\% \text{ N}_2) \end{aligned}$$

The moisture of Kiln Exit Gas was approximately 6% and Orsat Analysis of one gas sample gave: $\text{CO}_2 = 22.5\%$,

$O_2 = 8\%$ and $N_2 = 69.5\%$. Therefore,

$$\begin{aligned} M_d &= 44(0.225) + 32(0.08) + 28(0.695) \\ &= 31.92 \text{ Lb/Lb-mole} \end{aligned}$$

$$\begin{aligned} \text{and } M_s &= M_d(1 - \% H_2O) + 18(\% H_2O) \\ &= 31.92(1 - 0.06) + 18(0.06) \\ &= 31.08 \text{ Lb/Lb-mole} \end{aligned}$$

Hence:

$$\begin{aligned} V &= 85.49 \times 0.79 \times 0.63 \times \sqrt{\frac{1534}{(28.93)(31.08)}} \\ &= \underline{55.57} \text{ ft/sec} \end{aligned}$$

(b) Gas Flow Rate

$$\begin{aligned} &= V \times 60 \times \text{Cross Sectional Area} \\ &= 55.57 \times 60 \times 24 \\ &= \underline{80,000} \text{ ACFM} \end{aligned}$$

2. Kiln #4 Exit Gas (After Cooling Tower)

(a) Velocity

$$V = 85.49 \times C_p \times (\sqrt{\Delta P})_{\text{avg.}} \times \sqrt{\frac{T_{s(\text{avg.})}}{(P_s)(M_s)}}$$

Here,

$$* C_p = 0.79, \text{ from Table 2}$$

$$* (\sqrt{\Delta P})_{\text{avg.}} = 0.80, \text{ from Table 2}$$

$$* T_{s(\text{avg.})} = 773^\circ\text{F or } 1233^\circ\text{R, from Table 2}$$

$$\begin{aligned} * P_s &= 28.96 - \frac{1.20}{13.6}, \text{ from Table 2} \\ &= 28.87 \text{ mm Hg} \end{aligned}$$

* With Moisture = 12% and $\text{CO}_2 = 16.5\%$,

$\text{O}_2 = 10.5\%$ and $\text{N}_2 = 73.0\%$

$$M_d = 44(0.165) + 32(0.105) + 28(0.730)$$

$$= 31.06 \text{ Lb/Lb-mole}$$

$$M_s = 31.06(1 - 0.12) + 18(0.12)$$

$$= 29.49 \text{ Lb/Lb-mole}$$

Hence,

$$V = 85.49 \times 0.79 \times 0.80 \times \sqrt{\frac{1233}{(28.87)(29.49)}}$$
$$= \underline{65.02} \text{ ft/sec}$$

(b) Gas Flow Rate

$$= V \times 60 \times \text{Cross Sectional Area}$$

$$= 65.02 \times 60 \times 24$$

$$= \underline{93,600} \text{ ACFM}$$

List of Tables

Table 1: Velocity Traverse Data for Kiln #1 Exit Gas

Table 2: Velocity Traverse Data for Kiln #4 Exit Gas

Table 1
Velocity Traverse Data

<u>Plant</u>	:	Rcanoke
<u>Location</u>	:	Kiln #1 @ Cooling Tower Inlet
<u>Date</u>	:	11-29-1977
<u>Duct Dimensions, ft.</u>	:	4 x 6
<u>Barometric Pressure, mm Hg</u>	:	28.96
<u>Cross Sectional Area, ft²</u>	:	24
<u>Pitot Tube</u>		
Avg. Coefficient, C _p	:	0.79
Last Date Calibrated	:	April 1977

<u>Traverse Point No.</u>	<u>Velocity Head ΔP, in. H₂O</u>	<u>Temperature °F</u>	<u>Static Press. in. H₂O</u>	<u>√ΔP</u>
1	0.31	985	---	0.56
2	0.38	1080	---	0.62
3	0.53	1083	-0.40	0.73
4	0.49	1089	---	0.70
5	0.44	1088	---	0.66
6	0.38	1085	---	0.62
7	0.28	995	---	0.53
8	0.32	1086	---	0.56
9	0.39	1094	-0.40	0.62
10	0.46	1096	---	0.68
11	0.45	1094	---	0.67
12	0.41	1089	---	0.64
13	0.32	998	---	0.56
14	0.37	1089	---	0.61
15	0.42	1098	-0.45	0.65
16	0.44	1099	---	0.66
17	0.49	1097	---	0.70
18	0.44	1088	---	0.66
19	0.24	995	---	0.49
20	0.28	1082	---	0.53
21	0.38	1083	-0.36	0.62
22	0.49	1098	---	0.70
23	0.45	1093	---	0.67
24	0.47	1090	---	0.68

Table 2

Velocity Traverse Data

<u>Plant</u>	:	Roanoke
<u>Location</u>	:	Kiln #4 @ Cooling Tower Outlet
<u>Date</u>	:	11-29-1977
<u>Duct Dimensions, ft.</u>	:	4 x 6
<u>Barometric Pressure, mm Hg</u>	:	28.96
<u>Cross Sectional Area, ft²</u>	:	24
<u>Pitot Tube</u>		
Avg. Coefficient, C _p	:	0.79
Last Date Calibrated	:	April 1977

<u>Traverse Point No.</u>	<u>Velocity Head ΔP, in. H₂O</u>	<u>Temperature °F</u>	<u>Static Press. in. H₂O</u>	<u>$\sqrt{\Delta P}$</u>
1	0.41	760	---	0.64
2	0.62	765	---	0.79
3	0.74	769	-1.20	0.86
4	0.66	775	---	0.81
5	0.73	779	---	0.85
6	0.67	772	---	0.82
7	0.51	761	---	0.71
8	0.53	778	---	0.73
9	0.77	782	-1.20	0.88
10	0.78	781	---	0.88
11	0.70	780	---	0.84
12	0.60	772	---	0.77
13	0.42	759	---	0.65
14	0.47	768	---	0.68
15	0.78	779	-1.20	0.88
16	0.76	788	---	0.87
17	0.72	787	---	0.85
18	0.60	781	---	0.77
19	0.47	755	---	0.68
20	0.56	761	---	0.75
21	0.78	768	-1.20	0.88
22	0.79	779	---	0.89
23	0.75	776	---	0.87
24	0.65	768	---	0.81

List of Figures

Figure 1: Test Locations for Glas Flow Rate Measurements

Figure 2: Traverse Points for Cooling Tower Inlet Duct

Figure 3: Traverse Points for Cooling Tower Outlet Duct

Figure 4: Test Locations for SOX and NOX Monitoring

Figure 5: Chart Recorded SOX and NOX Levels @ Precipitator
Outlet (Kiln #5)

Figure 6: Chart Recorded SOX and NOX Levels @ Preheater
Inlet (Kiln #5)

Figure 7: Chart Recorded SOX and NOX Levels @ Kiln #5 Exit
(Over Grate)




Figure 2

ROANOKE PLANT


COOLING TOWER INLET DUCT

SAMPLING TRAVERSE POINTS

$$S = \frac{2AW}{L+W}$$

$$= \frac{(2)(84-12)(60-12)}{(84-12) + (60-12)} =$$

$$57.6" = 4'8"$$



Plan View


Cross Sectional Area - 24 ft²

Figure 3

ROANOKE PLANT

COOLING TOWER OUTLET DUCT

SAMPLING TRAVERSE POINTS




Plan View

Cross Sectional Area = 24 ft²

Fig. 4

TEST
LOCATIONS
@ KILN #5



KILN #5

Figure 5

SO_x & NO_x Levels @ Precip. Outlet (Kiln #5)




Figure 6

SO_x & NO_x Levels @ Under Grate (Kiln #5)





Figure 7

SO_x & NO_x Levels @ Over Grate (Kiln #5)





LONE STAR INDUSTRIES, INC.

P. O. Box 2148, Houston, Texas 77001

Originating Office: Central Research Laboratory

Date: December 22, 1977

TO: Mr. George Messinger

FROM: C. W. Moore

SUBJECT: Volume Measurements and SOX and NOX Monitoring
Mr. Vu's Report of December 7 on Roanoke

CC: Mr. C. D. Fehnel
Mr. W. W. Hurst
Mr. D. V. Vu

Earlier this month, I forwarded Duc Van Vu's report on volume measurements and SOX and NOX measurements dated December 7, 1977. Under the circumstances of time and expediency the work appears to have accomplished its objectives, and the report is a good report for our internal use, which was the only intent of the process oriented work.

The lack of suitable test ports seriously affects the conclusions that may be drawn from the data, and they must be interpreted with close attention to the test conditions and locations. Stewart Fritts has given me comments on the report, which I attach. I would suggest appending them to the report when it is transmitted to Bill Cavanaugh.

Clyde

CWM/po

1 Encl.



LONE STAR INDUSTRIES, INC.

One Greenwich Plaza, Greenwich, Connecticut 06830

December 8, 1977

Interoffice Memo

TO: Clyde Moore

FROM: Stewart S. Fritts

SUBJECT: Roanoke Report - Volume Measurements - Duc V. Vu

I have had the opportunity to review Duc's excellent report covering recent testing at the Roanoke, Va. Plant. The report has been well presented and covers the essential facts as requested by Bill Cavanaugh.

However, it should be emphasized the data as developed is predicated on less than favorable testing conditions and any conclusions based on the data should be accepted with reservation.

As an example the test locations for Kilns 1 and 4 are not favorable for securing the best flow patterns and hence subject to questionable interpretation regarding velocities and volumes even though the velocity patterns appear to be in line - and certainly better than the flow patterns indicated by the recent Nazareth testing.

Duc notes the testing program was initiated with the objective of measuring flow rates of the exit gases from both Kilns # 1 and # 4; but because testing ports were not available (in accordance with good testing practice) it was agreed to test the Inlet to Cooling Tower # 1 and the Outlet from Cooling Tower # 4 and to assume the operating conditions were comparable for all kilns.

This basic assumption is not correct because each kiln - in any plant and more especially at Roanoke - does not operate comparably at any one time and most certainly they do not operate uniformly all of the time. Therefore we can never assume operating conditions for Kiln # 1 will obtain at the same time as Kiln # 4 ; and any conclusions based on this assumption would be subject to critical examination.

At Roanoke the No. 4 Kiln system has a potential capacity of 20 T/H while the No. 1 Kiln system rarely exceeds 18 T/H. While the kilns are all of the same size the Cooler and Kiln Exhaust Fan for the No. 4 System is some 15 to 20 percent greater than the Cooler and Kiln Exhaust Fan for the No. 1 Kiln system. Again I must emphasize the two systems are not comparable.

It is of course disturbing to note - in the interest of expediency - we accepted testing conditions that were not in compliance with the best testing practice; and I refer specifically to the fact that there were insufficient testing ports - at the proper location - for good sound tests.

As you and I well know any testing program does not develop without a respectable expenditure of time and money; and it serves little purpose to make a study of operating conditions without first of all securing the fundamental factors that will contribute to the development of the best known facts upon which our conclusions must be based.

I refer especially to the testing conditions that existed at Roanoke where the test ports were not adequate not were they at the proper location; and the Roanoke situation is not singular since we noted a similar condition at the Nazareth Plant.

At Nazareth we accepted inadequate test ports and staging and now find our test results are very questionable even after some five months of concentrated efforts to reach responsible conclusions. The Nazareth situation is even more disturbing because we are confronted with the spectre of possible non-compliance with regulations promulgated by State environmental authorities and having to accept data based on less than favorable testing conditions.

In the final analysis I do not believe we can afford - economically - not to do the best job we know how and to present our data in the most favorable light but to do this job we must insist on having the proper number of test ports and at the best - but at the same time a reasonably practical - location.

With your transmittal of Duc's report to Bill Cavanaugh I would suggest you specially call to Bill's attention the fact that adequate test ports were not available and that the test data for Kilns #1 and # 4 should be accepted with considerable reservation even though Duc and his group performed their task with the highest efficiency and dispatch under the limited circumstances.

A handwritten signature in cursive script, appearing to read "R. C. Cavanaugh".

1-12-78

Bill.

I Believe I had sent
you a copy of Duc Vu's "Volume
Measurement and SOx and NOx
Monitoring Report" (12-7-77)

As I recall, we had
discussed it over the phone
and you stated that the
information had been requested
strictly as an "in-house" basis.

Just in a way of caution
on the use of the data I'm
enclosing a copy of a commentary
letter on the report written
by Stew Fritts.

Best Regards
George Messinger

PARTICULATE EMISSION

TESTING AT ROANOKE

1979



LONE STAR CEMENT INC.

P. O. Box 27, Cloverdale, Virginia 24077

Originating Office: Central Research Laboratory

Date: November 1, 1979

PERSONAL & BUSINESS CONFIDENTIAL

TO: W. J. Cavanaugh
FROM: W. W. Hurst
SUBJECT: Particulate Emission Testing at Roanoke Plant
CC: G. F. Messinger
C. D. Fehnel
C. W. Moore

Stack particulate emissions were tested on days between July 22 and October 12. Survey included 45 complete runs associated with Kiln System Nos. 1-5. Testing was conducted in accordance with EPA Methods 1-5 for Stationary Sources as given in Fed. Register, Vol. 35, No. 247; dated December 23, 1971, and amended August 18, 1977, and modified so as to meet the requirements of the Commonwealth of Virginia State Air Pollution Control Board.

Objectives were:

- (1) Determine normal level of stack particulate emissions.
- (2) Observe stack gas opacity during course of stack particulate testing on Stacks 1 - 5. Observations to be made by Virginia Air Control Board and Lone Star plant personnel.
- (3) Obtain Lear Siegler continuous monitor average readings from strip chart during particulate source testing of stack by E.P.A. Method 5.

Results showed average conditions for each Kiln System as follows:

Location Kiln Stack	Temp. °F	Volume ACFM	Emission Lbs/Hr	Opacity	
				Lear Sieg.	OBS
1	401	65,700	28.4	34	
2			Postponed		
3	420	60,700	23.6	25	15.7
4	413	70,900	28.9	31	19.9
5 *	332	288,600	38.4	14	
5 **	326	192,000	20.3	14	
5 ***	296	86,650	12.2	11	

TABLE 5

- * No Gas Bypass
- ** Gas Bypass to one Raw Mill
- *** Gas Bypass to two Raw Mills

Respectfully submitted,


W. W. Hurst, P. E.

WWH/tab

I. Introduction

Since our last testing period during the summer of 1978, a Sonic Spray System was added to each of the cooling towers and Kilns No. 1-4, as well as a major modification to the No. 5 Kiln System. All process alterations cited above were implemented so as to lower the particulate stack emission burden and improve to emission rate. Upon completion of these process modifications, the plan, which was conceived with the participation of the V.A.C.B., was to retest all stacks so as to realistically evaluate the process upgrading.

Upon the request of Mr. Cavanaugh, Roanoke Plant Manager, personnel of the Lone Star Central Research Laboratory conducted particulate emission test on the stacks during the period of August 4 - October 12, 1979. The V.A.C.B. was advised of our plans prior to each test so that they might be available for testing and/or opacity observations. The V.A.C.B. personnel performed opacity observations during some of our test but not all.

The purpose of this report is to present test data and evaluate the results. In the case of stack emissions, results are viewed in light of present source standards for the Commonwealth of Virginia and the Environmental Protection Agency.

The test program consisted of complete runs utilizing Isokinetic Sampling Techniques for particulate loads at the stacks. In general, the aim was to conduct three good sets of simultaneous tests at each of the locations. Some tests were lost due to operational malfunction--usually as a result of equipment breakage during testing.

Kiln No. 3 which averaged 23.6 lbs/hr. emissions was in compliance since the allowable was 34.8 lbs/hr. All testing results of this operation were consistently in the range of the average.

Kiln No. 4 averaged 28.9 lbs/hr. emissions with an allowable of 40.2 lbs/hr. The No. 4 kiln was somewhat larger than Kilns 1-3 and thus the increased allowable. Kiln 4, as in the case of Kiln 3, showed consistent results varying little from the average.

The allowable for No. 5 Kiln Stack was 41.9 lbs/hr., whereas, emissions varied between 38.4 and 12.2 lbs/hr. depending on the amount of stack gas bypassed to the Raw Mill for heating purposes.

TABLE I
ROANOKE STACK EMISSION
PARTICULATE EMISSION

1979

<u>Exhaust Gas</u>					<u>Particulate Emission Rates</u>			
<u>Run No.</u>	<u>Date 1979</u>	<u>Temp. °F</u>	<u>Volume ACFM</u>	<u>% H₂O</u>	<u>Mgs/M³ Std. Cond.</u>	<u>Grains/ SCF Dry</u>	<u>Lbs./SCF Dry (10⁻⁶)</u>	<u>Lbs/ Hr.</u>
<u>I-Kiln Stack #1 :</u>								
45	9-29	404	60,600	17.1	117	0.051	7.3	12.9
46	9-29	408	62,200	18.8	131	0.057	8.2	14.5
47	9-30	386	53,700	16.5	164	0.071	10.2	16.4
48	9-30	399	65,800	17.3	153	0.067	9.5	18.4
49	10-1	406	73,900	16.6	357	0.156	22.2	48.0
50	10-1	403	77,900	17.9	430	0.187	26.8	60.2
Ave.		<u>401</u>	<u>65,700</u>	<u>17.4</u>	<u>225</u>	<u>0.098</u>	<u>14.0</u>	<u>28.4</u>
<u>II-Kiln Stack #2 :</u>								
POSTPONED								
<u>III-Kiln Stack #3 :</u>								
51	10-4	417	61,600	17.3	195	0.085	12.2	21.4
52	10-4	422	60,100	16.6	260	0.113	16.2	28.0
53	10-11	432	59,800	15.8	241	0.105	15.0	25.7
54	10-11	415	61,200	16.4	209	0.091	13.0	23.0
55	10-12	416	59,600	16.3	210	0.091	13.0	22.5
56	10-12	415	61,600	16.6	189	0.082	11.8	20.8
Ave.		<u>420</u>	<u>60,700</u>	<u>16.5</u>	<u>217</u>	<u>0.095</u>	<u>13.5</u>	<u>23.6</u>
<u>IV-Kiln Stack #4 :</u>								
39	9-19	423	74,000	13.0	206	0.090	12.8	26.9
40	9-19	421	73,000	12.5	244	0.106	15.2	30.5
41	9-20	428	71,000	12.8	216	0.094	13.5	29.0
42	9-20	412	69,000	13.3	23	0.101	1.4	29.6
43	9-27	401	68,200	14.7	205	0.089	12.7	26.5
44	9-27	395	70,100	15.8	235	0.102	14.6	31.0
Ave.		<u>413</u>	<u>70,900</u>	<u>13.7</u>	<u>188</u>	<u>0.082</u>	<u>11.7</u>	<u>28.9</u>

TABLE I (CONT'D)

ROANOKE STACK EMISSION - 1979PARTICULATE EMISSION

<u>Run No.</u>	<u>Date 1979</u>	<u>Temp. °F</u>	<u>Volume ACFM</u>	<u>% H₂O</u>	<u>Mgs/M³ Std. Cond.</u>	<u>Grains/SCF Dry</u>	<u>Lbs./SCF Dry (10⁻⁶)</u>	<u>Lbs/Hr.</u>
<u>V-Kiln Stack #5 (No Gas Bypass) :</u>								
7	7-26	348	288,000	13.5	77	0.034	4.8	45.3
8	7-26	347	284,000	13.1	29	0.013	1.8	17.1
10	8-4	329	289,000	12.1	62	0.027	3.9	37.7
12	8-5	317	287,000	12.2	86	0.038	5.4	53.4
14	8-6	319	295,000	12.7	61	0.027	3.8	38.5
Ave.		<u>332</u>	<u>288,600</u>	<u>12.7</u>	<u>63</u>	<u>0.028</u>	<u>3.9</u>	<u>38.4</u>
<u>VI-Kiln Stack #5 (Gas Bypass to One Raw Mill) :</u>								
1	7-22	374	198,000	11.0	39	0.017	2.4	15.5
2	7-22	344	204,000	11.6	45	0.020	2.8	19.3
*3	7-24	337	199,000	11.2	41	0.018	2.6	17.5
4	7-24	336	200,000	12.7	32	0.014	2.0	13.6
5	7-25	346	145,000	13.0	90	0.039	5.6	27.0
*6	7-25	346	147,000	7.6	28	0.012	1.7	9.0
15	8-18	335	188,000	11.9	31	0.014	2.0	12.5
16	8-18	338	195,000	13.1	30	0.013	1.9	12.3
23	9-2	304	188,000	14.0	104	0.046	6.5	42.0
24	9-2	300	193,000	12.5	72	0.032	4.5	30.6
25	9-3	307	196,000	13.5	69	0.030	4.3	29.0
*26	9-3	301	179,000	4.8	22	0.010	1.4	9.5
31	9-4	302	201,000	15.1	58	0.025	3.6	24.7
32	9-4	301	204,000	12.0	47	0.021	2.9	21.3
Ave.		<u>326</u>	<u>192,000</u>	<u>12.8</u>	<u>51</u>	<u>0.022</u>	<u>3.2</u>	<u>20.3</u>

* Data from Runs No. 3, 6, & 26 were not included for average due to breakdown of testing equipment.

VII-Kiln Stack #5 (Gas Bypass to Two Raw Mills) :

17	8-22	310	74,900	10.3	36	0.016	2.3	6.0
18	8-22	303	76,400	6.5	53	0.023	3.3	9.5
19	8-23	303	108,500	9.2	36	0.016	2.3	9.0
20	8-23	291	110,000	10.9	69	0.030	4.3	17.2
21	8-30	287	75,900	12.2	55	0.024	3.4	9.3
22	8-30	280	74,200	11.3	132	0.057	8.2	22.3
Ave.		<u>296</u>	<u>86,650</u>	<u>10.1</u>	<u>64</u>	<u>0.028</u>	<u>4.0</u>	<u>12.2</u>

TABLE 2

ROANOKE EMISSION SURVEY

SPECIAL DATA FOR

VIRGINIA STATE AIR POLLUTION CONTROL BOARD

Run No.	Date	Time of Day	Volume @ Stack (ACFM)	Fuel Coal (T/Hr.)	Kiln Feed (T/Hr.)	Particulate Emission (Lb./Hr.)	Stack Opacity (%)		
							Observer	Plant	L. S. Recorder Average
Stack #1:									
45	9-29	9:38-12:10	60,600	3.3	21.0	12.9			30
46	9-29	9:42-12:14	62,200	3.3	21.9	14.5			30
47	9-30	8:11-10:36	53,700	3.4	20.7	16.4			31
48	9-30	8:15-10:40	65,800	3.4	20.7	18.4			31
49	10-1	10:00-12:25	73,900	3.4	21.0	48.0			42
50	10-1	10:04-12:29	77,900	3.4	21.0	60.2			42
Stack #2:									
POSTPONED									
Stack #3:									
51	10-4	10:28-12:51	61,600	2.7	22.1	21.4	12.2		17
52	10-4	10:32-12:55	60,100	2.7	22.1	28.0	12.2		17
53	10-11	10:04-12:26	59,800	2.8	21.9	25.7	20.3		24
54	10-11	10:00-12:30	61,200	2.8	21.9	23.0	20.3		24
55	10-12	10:04-12:24	58,600	2.8	20.7	22.5	14.6		33
56	10-12	10:00-12:28	61,600	2.8	20.7	20.8	14.6		33
Stack #4:									
39	9-19	10:20-12:58	74,000	3.0	26.0	26.9	18.5		30
40	9-19	10:24-12:54	73,000	3.0	26.0	30.5	18.5		30
41	9-20	10:02-12:35	71,000	2.9	25.6	29.0	21.3		34
42	9-20	9:58-12:31	69,000	2.9	25.6	29.6	21.3		34
43	9-27	10:00-12:29	68,200	3.0	32.1	26.5			28
44	9-27	10:04-12:33	70,100	3.0	32.1	31.0			28

SPECIAL DATA FOR VIRGINIA STATE AIR POLLUTION CONTROL BOARD

ROANOKE EMISSION SURVEY - 1979

Run No.	Date	Time of Day	Volume @ Stack (ACFM)	Fuel Coal (T/Hr.)	Kiln Feed (T/Hr.)	Particulate Emission (Lb./Hr.)	Stack Opacity (%)		
							Observer	Plant	L.S. Recorder Average
Stack #5 (No Gas Bypass):									
7	7-26	8:42-11:47	288,000	9.5	102	45.3			11
8	7-26	8:45-11:50	284,000	9.5	102	17.1			11
10	8-4	9:10-12:17	289,000	9.3	100	37.7			14
12	8-5	7:56-10:44	287,000	9.5	102	53.4			16
14	8-6	9:40-12:30	295,000	9.3	105	38.5			17
				9.4	102.2				
Stack #5 (Gas Bypass to one Raw Mill):									
1	7-22	9:39-13:04	198,000	8.5	95	15.5			13
2	7-22	9:42-13:07	204,000	8.5	95	19.3			13
3	7-24	10:05-13:47	199,000	9.3	105	17.5			13
4	7-24	10:08-13:50	200,000	9.3	105	13.6			13
5	7-25	10:44-13:44	145,000	9.4	105	27.0			12
6	7-25	10:47-13:47	147,000	9.4	105	9.0			12
15	8-18	7:55-10:53	188,000	9.9	105	12.5			13
16	8-18	7:58-10:56	195,000	9.9	105	12.3			13
23	9-2	7:57-10:46	188,000	9.8	110	42.0			18
24	9-2	8:00-10:49	193,000	9.8	110	30.6			18
25	9-3	8:23-11:11	196,000	9.5	110	29.0			15
26	9-3	8:26-11:14	179,000	9.5	110	9.5			15
31	9-4	10:04-12:52	201,000	9.4	110	24.7			15
32	9-4	10:07-12:55	204,000	9.4	110	21.3			15

Data from Run No. 3, 6, & 26 were not included for Average due to breakdown of testing equipment.

Stack #5 (Gas Bypass to two Raw Mills):									
17	8-22	8:24-11:28	74,900	9.5	105	6.0			13
18	8-22	8:27-11:31	76,400	9.5	105	9.5			13
19	8-23	10:03-12:57	108,500	9.7	105	9.0			12
20	8-23	10:06-13:00	110,000	9.7	105	17.2			12
21	8-30	10:07-13:04	75,900	8.7	110	9.3		2.4	9
22	8-30	10:10-13:07	74,200	8.7	110	22.3		2.4	9

T-3

PROCESS RATE, CONSUMPTION AND PRODUCTION

1979

Run No.	Date	Kiln No.	Fuel Rate T/H	% Water In Coal	Feed Rate T/H	% Water In Raw Mix	Clinker Production Rate T/H	Cooling Water Gal/Min
45-46	9-29	1	3.3	6.9	21.9	0.42	14.6	22
47-48	9-30	1	3.4	5.6	20.7	0.39	13.8	25
49-50	10-1	1	3.4	8.8	21.0	0.56	14.0	26
Average (Kiln #1)			<u>3.4</u>	<u>7.1</u>	<u>21.2</u>	<u>0.46</u>	<u>14.1</u>	<u>24</u>
2			POSTPONED					
2								
2								
Average (Kiln #2)								
51-52	10-4	3	2.7	7.3	22.1	0.53	14.7	26
53-54	10-11	3	2.8	7.2	21.9	0.52	14.6	25
55-56	10-12	3	2.8	7.4	20.7	0.48	13.8	24
Average (Kiln #3)			<u>2.8</u>	<u>7.3</u>	<u>21.6</u>	<u>0.51</u>	<u>14.4</u>	<u>25</u>
39-40	9-19	4	3.0	5.4	26.0	0.45	17.3	24
41-42	9-20	4	2.9	6.3	25.6	0.38	18.4	25
43-44	9-27	4	3.0	6.6	32.1	0.38	21.4	29
Average (Kiln #4)			<u>3.0</u>	<u>6.1</u>	<u>27.9</u>	<u>0.40</u>	<u>19.0</u>	<u>26</u>
1-2	7-22	5	8.5	4.9	95	0.30	59	37
3-4	7-24	5	9.3	5.0	105	0.28	66	48
5-6	7-25	5	9.4	7.3	105	0.32	66	49
15-16	8-18	5	9.9	5.2	105	0.34	66	49
23-24	9-2	5	9.8	6.8	110	0.38	69	50
25-26	9-3	5	9.5	5.1	110	0.42	69	50
31-32	9-4	5	9.4	6.6	110	0.38	69	51
7-8	7-26	5	9.5	5.0	102	0.29	64	44
10	8-4	5	9.3	5.2	100	0.36	63	61
12	8-5	5	9.5	4.8	102	0.32	64	46
14	8-6	5	9.3	8.3	105	0.38	66	47
17-18	8-22	5	9.5	3.7	105	0.36	66	45
19-20	8-23	5	9.7	7.2	105	0.38	66	44
21-22	8-30	5	8.7	4.4	110	0.52	69	51
Average (Kiln #5)			<u>9.4</u>	<u>5.7</u>	<u>105</u>	<u>0.36</u>	<u>66</u>	<u>48</u>

TABLE 4

T-4

ROANOKE EMISSION STUDY
EXHAUST GAS CHARACTERISTICS

1979

Run No.	Kiln No.	Location	Date	Temperature (°R)	% Water	Gas Density (Lb/Lb-Mole)	Static Pressure ("H ₂ O)
45	1	Stack	9-29	864	17.1	28.30	+0.16
46	1	"	9-29	868	18.8	28.09	+0.16
47	1	"	9-30	846	16.5	28.38	+0.11
48	1	"	9-30	859	17.3	28.20	+0.19
49	1	"	10-1	866	16.6	28.77	+0.22
50	1	"	10-1	863	17.9	28.60	+0.37
	2	Stack					
	2	"					
	2	"					
	2	"	POSTPONED				
	2	"					
	2	"					
51	3	Stack	10-4	877	17.3	28.34	+0.12
52	3	"	10-4	882	16.6	28.43	+0.09
53	3	"	10-11	892	15.8	28.36	+0.10
54	3	"	10-11	875	16.4	28.29	+0.06
55	3	"	10-12	876	16.3	28.77	+0.09
56	3	"	10-12	875	16.6	28.73	+0.11
39	4	Stack	9-19	883	13.0	29.35	+0.27
40	4	"	9-19	881	12.5	29.42	+0.32
41	4	"	9-20	888	12.8	29.47	+0.30
42	4	"	9-20	872	13.3	29.40	+0.27
43	4	"	9-27	861	14.7	29.20	+0.34
44	4	"	9-27	855	15.8	29.05	+0.31
* 7	5	Stack	7-26	808	13.5	28.73	+0.62
8	5	"	7-26	807	13.1	28.77	+0.56
10	5	"	8-4	789	12.1	28.75	+0.72
12	5	"	8-5	777	12.2	28.82	+0.74
14	5	"	8-6	779	12.7	28.76	+0.65

*No Exhaust Gas was Bypass to Raw Mill for Runs 7, 8, 10, 12 & 14.

TABLE 4 - (CONT'D)

T-4 Cont'd

EXHAUST GAS CHARACTERISTICSROANOKE EMISSION STUDY - 1979

Run No.	Kiln No.	Location	Date	Temperature (°R)	% Water	Gas Density (Lb/Lb-Mole)	Static Pressure ("H ₂ O)
**1	5	Stack	7-22	834	11.0	28.63	+0.51
2	5	"	7-22	804	11.6	28.63	+0.52
3	5	"	7-24	797	11.2	28.85	+0.52
4	5	"	7-24	796	12.7	28.66	+0.59
5	5	"	7-25	806	13.0	28.56	+0.55
6	5	"	7-25	806	7.6	29.21	+0.62
15	5	"	8-18	795	11.9	28.90	+0.50
16	5	"	8-18	798	13.1	28.75	+0.51
23	5	"	9-2	764	14.0	28.61	+0.53
24	5	"	9-2	760	12.5	28.79	+0.49
25	5	"	9-3	767	13.5	28.73	+0.47
26	5	"	9-3	761	4.8	29.80	+0.61
31	5	"	9-4	762	15.1	28.42	+0.43
32	5	"	9-4	761	12.0	28.80	+0.49

**Exhaust gas was bypass to one raw mill for Runs 1-6, 15-16, 23-26 & 31-32.

***17	5	Stack	8-22	770	10.3	28.84	+0.36
18	5	"	8-22	763	6.5	29.30	+0.36
19	5	"	8-23	763	9.2	28.50	+0.38
20	5	"	8-23	751	10.9	28.31	+0.36
21	5	"	8-30	747	12.2	28.70	+0.29
22	5	"	8-30	740	11.3	28.81	+0.27

***Exhaust gas was bypass to two raw mills for runs 17-22.

TABLE 5

T-5

ROANOKE EMISSION SURVEY

EXHAUST GAS FLOW RATE

1979

Run No.	Date	Kiln No.	Location	ΔP ("H ₂ O)	Velocity (Ft/Sec)	Volume (ACFM)	Volume @ Std. Cond. CFH x 10 ⁶ (Dry)
45	9-29	1	Stack	0.39	28.23	60,600	1.77
46	9-29	1	"	0.39	28.99	62,200	1.78
47	9-30	1	"	0.35	25.03	53,700	1.61
48	9-30	1	"	0.42	30.63	65,800	1.93
49	10-1	1	"	0.47	34.42	73,900	2.16
50	10-1	1	"	0.50	36.28	77,900	2.25
		2	Stack				
		2	"				
		2	"				
		2	"	POSTPONED			
		2	"				
		2	"				
51	10-4	3	Stack	0.39	28.70	61,600	1.76
52	10-4	3	"	0.38	28.00	60,100	1.73
53	10-11	3	"	0.37	27.85	59,800	1.71
54	10-11	3	"	0.39	28.50	61,200	1.77
55	10-12	3	"	0.38	27.75	59,600	1.72
56	10-12	3	"	0.39	28.70	61,600	1.77
39	9-19	4	Stack	0.45	32.48	74,000	2.10
40	9-19	4	"	0.44	32.19	73,000	2.01
41	9-20	4	"	0.44	33.05	71,000	2.15
42	9-20	4	"	0.45	32.29	69,000	2.12
43	9-27	4	"	0.44	31.73	68,200	2.07
44	9-27	4	"	0.46	32.63	70,100	2.12
7	7-26	5	Stack	0.87	61.05	288,000	9.41
8	7-26	5	"	0.86	60.27	284,000	9.34
10	8-4	5	"	0.88	61.40	289,000	9.71
12	8-5	5	"	0.89	60.98	287,000	9.96
14	8-6	5	"	0.91	62.67	295,000	10.10

No exhaust gas was bypass to Raw Mill for Runs 7, 8, 10, 12, & 14.

9.70

161700 DSCCM

TABLE 5 - CONT'D

T-5 Cont'd

EXHAUST GAS FLOW RATEROANOKE EMISSION SURVEY - 1979

Run No.	Date	Kiln No.	Location	P ("H ₂ O)	Velocity (Ft/Sec)	Volume (ACFM)	Volume @ Std. Cond. CFH x 10 ⁶ (Dry)
** 1	7-22	5	Stack	0.59	42.02	198,000	6.48
2	7-22	5	"	0.62	43.38	204,000	6.89
3	7-24	5	"	0.61	42.27	199,000	6.82
4	7-24	5	"	0.61	42.38	200,000	6.85
5	7-25	5	"	0.44	30.86	145,000	4.81
6	7-25	5	"	0.45	31.20	147,000	5.16
15	8-18	5	"	0.61	39.84	188,000	6.37
16	8-18	5	"	0.64	41.50	195,000	6.53
23	9-2	5	"	0.58	39.88	188,000	6.47
24	9-2	5	"	0.60	40.94	193,000	6.79
25	9-3	5	"	0.61	41.70	196,000	6.76
26	9-3	5	"	0.57	38.05	179,000	6.86
31	9-4	5	"	0.62	32.48	201,000	6.83
32	9-4	5	"	0.64	32.19	204,000	7.22

* Exhaust gas was bypass to one Raw Mill for Runs 1-6, 15-16, 23-26, & 31-32.

6.49

108150 DSCF

***17	8-22	5	Stack	0.25	15.91	74,900	2.67
18	8-22	5	"	0.26	16.22	76,400	2.87
19	8-23	5	"	0.34	23.04	108,500	3.95
20	8-23	5	"	0.34	23.35	110,000	3.99
21	8-30	5	"	0.24	16.12	75,900	2.73
22	8-30	5	"	0.24	15.75	74,200	2.72

***Exhaust gas was bypass to two Raw Mills to Runs 17-22.

3.155

52580

TABLE 6

T-6

ROANOKE EMISSION SURVEY

GAS SAMPLING AND TESTING PARAMETERS

1979

* Test Period (= 128 min. for Stacks 1, 2, 3 and 4
 (= 144 min. for Stack 5

Run No.	Kiln No.	Test Nozzle Size (Sq.Ft.)	Meter Temp. (°R)	H ("H ₂ O)	Meter Vol. (Cu.Ft.)	Meter Vol. @ STD. Cond. (Cu. Ft.)	% ISO-Kinetic
45	1	0.000314	538	0.31	35.64	33.73	102.1
46	1	"	528	0.32	35.32	34.06	103.1
47	1	"	539	0.25	31.78	29.96	99.8
48	1	"	521	0.37	39.49	38.52	107.4
49	1	"	540	0.46	43.43	40.77	101.4
50	1	"	524	0.52	46.84	45.32	108.3
	2	0.000314					
	2	"					
	2	"	POSTPONED				
	2	"					
	2	"					
	2	"					
51	3	0.000314	540	0.30	35.18	33.02	100.7
52	3	"	526	0.26	34.95	33.68	104.8
53	3	"	534	0.25	34.43	32.62	102.5
54	3	"	532	0.30	35.39	33.66	102.2
55	3	"	535	0.25	34.60	32.60	102.0
56	3	"	538	0.31	35.73	33.48	101.6
39	4	0.000314	546	0.38	39.35	36.78	93.9
40	4	"	538	0.34	40.10	38.04	97.1
41	4	"	544	0.44	42.34	39.99	99.8
42	4	"	529	0.38	42.22	41.00	103.6
43	4	"	542	0.40	40.40	38.19	98.9
44	4	"	528	0.38	42.16	40.91	103.6
*7	5	0.000289	534	0.82	68.43	65.29	79.0
8	5	"	533	0.82	73.71	70.46	85.8
10	5	"	541	1.22	87.30	82.62	96.7
12	5	"	541	1.26	88.00	82.62	94.3
14	5	"	543	1.31	83.92	79.16	87.8

*No exhaust gas was bypass to raw mill for runs 7, 8, 10, 12 & 14.

TABLE 6 (CONT'D)

T-6 Cont'd

ROANOKE EMISSION SURVEYGAS SAMPLING AND TESTING PARAMETERS - 1979

Run No.	Kiln No.	Test Nozzle Size (Sq.Ft.)	Meter Temp. (°R)	H ("H ₂ O)	Meter Vol. (Cu.Ft.)	Meter Vol. @ STD. Cond. (Cu. Ft.)	% ISO-Kinetic
**1	5	0.000289	537	0.75	65.24	62.26	109.1
2	5	"	537	0.78	71.62	68.35	112.7
3	5	"	535	0.71	65.25	62.57	104.2
4	5	"	534	0.68	66.69	64.07	108.0
5	5	"	538	0.46	51.09	48.55	114.7
6	5	"	537	0.48	56.08	53.39	117.2
15	5	"	533	0.59	57.55	55.21	98.5
16	5	"	533	0.66	61.50	59.01	102.7
23	5	0.000309	531	0.81	64.35	61.92	101.7
24	5	"	532	0.75	67.33	64.65	101.2
25	5	"	537	0.86	66.20	62.86	98.8
26	5	"	537	0.68	63.61	60.50	93.4
31	5	"	542	0.89	67.14	63.19	98.4
32	5	"	543	0.81	69.74	65.51	96.4

**Exhaust gas was bypass to one raw mill for runs 1-6, 15-16, 23-26 & 31-32.

***17	5	0.000289	539	0.12	23.93	22.66	96.6
18	5	"	538	0.11	25.02	23.73	93.9
19	5	0.000739	536	1.33	82.08	78.37	91.5
20	5	"	537	1.47	91.96	87.67	94.0
21	5	"	544	0.77	61.50	57.69	97.6
22	5	"	545	0.73	64.97	60.83	95.9

***Exhaust gas was bypass to two raw mills for runs 17-22.

TABLE 7

T-7

ROANOKE EMISSION SURVEYORSAT ANALYSIS

1979

Run No.	Date	Kiln No.	Location	CO ₂	O ₂	N ₂
45-46	9-29	1	Stack	12.0	12.6	75.4
47-48	9-30	1	"	12.0	12.8	75.2
49-50	10-1	1	"	15.4	11.2	73.4
		2	Stack	POSTPONED		
		2	"			
		2	"			
51-52	10-4	3	Stack	12.4	13.0	74.6
53-54	10-11	3	"	11.0	13.6	75.4
55-56	10-12	3	"	15.4	10.0	74.6
39-40	9-19	4	Stack	16.4	10.6	73.0
41-42	9-20	4	"	17.2	10.0	72.8
43-44	9-27	4	"	17.2	9.4	73.4
7-8	7-26	5	Stack	11.4	14.4	74.2
10	8-4	5	"	10.2	15.0	74.8
12	8-5	5	"	10.8	15.0	74.2
14	8-6	5	"	10.8	15.0	74.2
1-2	7-22	5	Stack	8.2	15.8	76.0
3-4	7-24	5	"	10.0	15.4	74.6
5-6	7-25	5	"	9.6	15.0	75.4
15-16	8-18	5	"	11.2	14.4	74.4
23-24	9-2	5	"	11.2	13.6	75.2
25-26	9-3	5	"	11.4	14.4	74.2
31-32	9-4	5	"	10.6	14.5	74.9
17-18	8-22	5	Stack	9.2	15.4	75.4
19-20	8-23	5	"	5.4	17.6	77.0
21-22	8-30	5	"	9.8	15.6	74.6

TABLE 8
ROANOKE STACK EMISSIONS

CHEMICAL ANALYSIS

1979

	SiO ₂	Al ₂ O ₃	Fe ₂ O ₃	CaO	MgO	SO ₃	K ₂ O	Na ₂ O	Loss
Kiln Feed Composite No. 1-4	14.24	2.80	2.28	43.03	2.10	0.99	0.58	0.19	34.53
Clinker Composite No. 1-4	22.08	4.62	3.82	64.03	3.00	1.70	0.81	0.23	0.29
Waste Dust Composite No. 1-4	13.86	5.18	2.24	44.20	1.59	5.64	3.20	0.30	24.22
Kiln Feed Composite No. 5	14.44	3.24	1.50	42.85	2.15	<u>0.82</u> 0.4	0.62	0.19	34.91
linker Composite No. 5	22.75	5.30	2.48	64.64	3.30	0.49	0.74	0.25	0.37
Waste Dust Composite No. 5	18.24	5.48	2.32	51.80	2.73	4.58	3.35	0.45	11.74

TABLE 9

T-9

ROANOKE EMISSION SURVEY
METEOROLOGICAL CONDITIONS

1979

Run No.	Date	Kiln No.	Location	Ambient Temp. (°F.)	Baro. Pressure (In. Hg.)	Relative Humidity (%)
45-46	9-29	1	Stack	73	28.73	77
47-48	9-30	1	"	66	28.67	84
49-50	10-1	1	"	70	28.59	78
		2	Stack			
		2	"	POSTPONED		
		2	"			
51-52	10-4	3	Stack	56	28.60	82
53-54	10-11	3	"	45	28.55	85
55-56	10-12	3	"	55	28.44	70
39-40	9-19	4	Stack	72	28.79	69
41-42	9-20	4	"	63	28.98	70
43-44	9-27	4	"	67	28.90	72
7-8	7-26	5	Stack	73	28.71	90
10	8-4	5	"	68	28.82	86
12	8-5	5	"	70	28.86	83
14	8-6	5	"	77	28.82	60
1-2	7-22	5	Stack	70	28.85	71
3-4	7-24	5	"	71	28.92	95
5-6	7-25	5	"	71	28.84	90
15-16	8-18	5	"	67	28.83	72
23-24	9-2	5	"	71	28.79	90
25-26	9-3	5	"	73	28.73	87
31-32	9-4	5	"	71	28.74	90
17-18	8-22	5	Stack	68	28.81	85
19-20	8-23	5	"	69	28.80	100
21-22	8-30	5	"	71	28.76	90

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
I. Introduction	I-1
II. Regulations	II (1-2)
III. Operating Equipment and Process Parameters	III (1-2)
IV. Test Equipment and Procedures	IV (1-4)
V. Discussion of Results	V (1-2)
 <u>Figures</u>	
A. <u>Old Plant</u>	
F. Stack Emission Test Location	F-1
F. Stack Sampling Traverse	F-2
B. <u>New Plant</u>	
F. Stack Emission Test Location	F-4
F. Stack Sampling Traverse	F-5
 <u>Tables</u>	
T. Particulate Emission Rate	T-1
T. Special Data for Virginia APCM	T-2
T. Process Rate, Consumption and Production	T-3
T. Exhaust Gas Characteristics	T-4
T. Exhaust Gas Flow Rate	T-5
T. Gas Sampling & Testing Parameters	T-6
T. Orsat Analysis	T-7
T. Chemical Analysis	T-8
T. Meteorological Conditions	T-9

TABLE OF CONTENTS CONT'D

Section

Appendix

A.	Nomenclature and Isokinetics Sample Calculation	A (1-4)
A.	Material Balance	A (5-21)
A.	Material Balance Schematics	A (22-25)
A.	Pittsburg Testing Laboratory Coal Analysis	A-26
A.	E.P.A. Method 5 Particulate Sampling Train	A (27-28)
A.	Raw Data Sheets	

III. Operating Equipment and Process Parameters

A. Old Plant

Four medium size, dry process clinker kilns are operated--each with its own flue gas transporting ducts, gas conditioning equipment, and dust abatement equipment--with the cleaned and cooled flue gas fed to an individual stack for waste gas dissemination. In all, there are 4 kilns each with its individual stack. Each stack is supplied gas by the same configuration as described herein.

Flue gases leave the kilns at 1100° - 1200° F. and are initially conditioned with water at the kiln exit area so that gases enter the cooling tower at approximately 900° F. In the cooling tower, additional water spraying is done to raise the moisture level of the gases to around 15% and lower the temperature to 650° F. range.

Gases leaving the cooling-conditioning tower are fed to a group of 4 - 4 1/2' Buell Multiclones operated in parallel to achieve capacity requirements. Each multiclone unit (4-4 1/2' cyclones) is designed to handle 67,000 CFM @ 700° F. to give approximately 80% separating efficiency for medium size particles at 50 microns. No grain loading of the gases was specified in the performance guarantee. After a portion of the coarser dust is removed by the multiclones, the gases are fed to electrostatic precipitators.

Though Koppers electrostatic precipitators installed at Roanoke have been in operation since startup dating back to 1951, they were extensively reconditioned and modernized in 1967. Precipitators on Kiln Systems 1, 2, 3 were the same size but the precipitator associated with No. 4 Kiln System was somewhat larger. All units were designed to handle 65,000 CFM @ 600° F. at a 2" negative water pressure. Each precipitator consists of

a north and south section with a total collecting surface of 20,088 sq. ft. for Units 1-3 and 22,320 sq. ft. for Unit No. 4. Correspondingly, the discharge electrode has an effective length of 13,392 ft. for Units 1-3 and 14,880 ft. for No. 4.

The precipitator design throughput velocity was 2.4 ft/sec. for Units 1-3 and 2.17 ft/sec. for Unit 4. This provides for a resident period of 7.5 sec. for the smaller precipitators and 8.3 sec. for No. 4 Unit. System design allowed for moisture in the gas by volume at 15% minimum. The guaranteed collection efficiency was 99.6% for Units 1-3 and 99.8% for Unit 4. The designed input grain loading for Unit 1-3 was 5.0 grains/cu. ft. and 9.0 grains/cu. ft. for Unit 4. Expected output grain loading for all units was 0.02 grains/cu. ft.

Stack discharge location was 105'-3" above foundation. (Foundation 1433"-11½" above sea level.) Test ports were located 56'-3" above foundation where the stack diameter was 81". Each stack had two - 4" test ports placed at 90° apart and in the same elevation plane. At the 56'-3" elevation, ports were 6.3 flue diameters from the stack input ducts in the upwind direction and 6.13 flue diameters from discharge on the downwind side of ports. See Sketch, Fig. 1, for details. Accordingly, the upwind direction becomes the most critical with respect to duct disturbance. Using E.P.A. chart-flue diameters vs. test points on traverse - we estimate stack traverse should have 16 test points with locations as shown in Sketch Fig. 2.

B. New Plant

The new kiln is a high efficiency, Allis-Chalmers rotary unit operated in conjunction with a preheater-pelletizer utilizing the Lepol system. The kiln is rated at 110 T/H raw mix feed and is currently operated at this rate or about 100% of rated capacity. Gases with airborne particulates leave the preheater and enter the precipitator at about 385° F. and approximately 12% water by volume. As a result of efficient heat recuperation and "bleeding air" for system stability, the precipitator input gases have been degraded from combustion composition at 1-2% oxygen and dry to about 15% oxygen and wet.

The kiln system electrostatic precipitator is a double chamber, four field unit of Koppers manufacture. The unit is designed to handle 286,000 ACFM @ 250° F. and 10% water vapor by volume AT-8" VWC. The input dust concentration is rated at 5 grains/cu. ft. (actual) or 12,214 Lbs/Hr. Residual dust should be 0.009 grains/ACF or 21.84 Lbs/Hr. to give a guaranteed efficiency of 99.82+. Pressure drop across the unit is 1/2" water with a throughput gas velocity of 3 ft/sec. for a resident time of 12 seconds.

IV. Test Equipment and Testing Procedures

The Sampling Train used for source testing was basically a Model AP-5000 "Stac-O-Lator" manufactured by Scientific Glass and Instruments, Inc. of Houston and has been E.P.A. approved. The impinger type and charge was in accordance with E.P.A. recommendation except we use somewhat more silica gel than E.P.A. suggests so as to be sure of absorbing all water vapor.

We also use 5 impingers instead of the required 4. The 5th impinger is a modified Smith-Greenfield placed in the train ahead of the usual first impinger and connected in a "reverse" configuration. The reverse arrangement acts as a trap to collect water from the first impinger in the event of an unexpected back pressure in the system. Such a system in no way detracts from the intended function of the impinger train and prevents the fouling (wetting) of the filter and loss of moisture in the event of a sudden momentary back pressure in the system. The glass fiber filters were 4" Gelman, Type A, with a retentions factor of 99.7% @ 0.3 micron particle size.

We used the E.P.A. sampling procedure as prescribed in the "Commonwealth of Virginia - Procedures for Emission Testing" dated April 21, 1977. Each test was 2-3 hours long generally sampling at 0.5 CFM dry gas. Each of the stack tests gathered well over 30 cu. ft. The train was leak checked at the start and end of each run at about 17" Hg. rather than 15" Hg. as required by E.P.A. Our control valves are at equilibrium with pump at 17" Hg. rather than 15" Hg.

Teflon heated probe liners were used for stack testing. Probes, filter assemblies, and nozzle were thoroughly washed with acetone following each test with nozzle removed. Reassembled clean probes were leak checked @ 25" Hg. vacuum with no noticeable leaks tolerated.

We operate out of a 30' mobile laboratory so that all sample recovery, such as weighing, evaporating, and washing is done within the air-conditioned mobile laboratory and not at testing area.

Laboratory analysis are performed strictly in accordance with E.P.A. Our analytical balance for weighing filters and beakers is a Mettler H-6. Our impinger weighing balance is a Mettler P-1200. We use 4 large desiccators for storing and keeping filters and beakers at constant weight. We generally run blanks on each acetone and distilled water lot but seldom find enough residue for significant modification of results. For the record, our current acetone residue per 500 ml. is 0.5 mg. and our distilled water residue is 1.9 mg. per 500 ml.

We use two Thermo Electric digital thermocouple indicators, Model ELPA with a 1° accuracy. The indicators are electrically connected through switching to a Thermo Electric "Minimite" which is used to calibrate the temperature range of interest per test. The "Minimite" has an accuracy of $\pm 1/4\%$. Calibration of thermocouple indicators occurs at the beginning of each plant run and more often if it seems necessary or a significant change occurs in the range of testing interest.

Five dry test Rockwell meters are calibrated at the start of each plant test. Part of the mobile laboratory equipment is a Precision Wet Test Meter, Serial No. AA-9 which is used to standardize the dry test meters. The wet test meter is calibrated annually by equipment traceable to the Bureau of Standards.

The orifice used for " ΔH " readings is calibrated at random periods whenever the " ΔH " vs. CFM relationship show significant variation. The " ΔH " orifice plate has a 3/16" orifice working in a 3/4" pipe duct. $\Delta H @ = 1.79$ at .75 CFM, 68° F. and 29.92" Hg.

Near the beginning and toward the end of each two hour (approx.) run, we collect a gas sample (GRAB) for determining the gas composition. The two analyses are averaged but seldom show much variation. The analysis is performed with the Orsat equipment. Considerable effort is devoted toward keeping the Orsat equipment in top operating condition.

Pitot tubes were calibrated in Houston during March, 1979, before starting our annual plant tour. Each tube was calibrated in our 12" wind tunnel at the approximate velocity anticipated in the field where the Pitot tube was to be used. Our wind tunnel was capable of producing air attaining 100 ft/sec. velocity and could be throttled by a system of screen grinds that not only induce resistance to diminish the flow of air but also acted as straightening vanes to minimize eddy currents produced by the fan. Pitot tubes were only used during the course of a single testing assignment per specifications.

During calibration, Pitot tubes ("S" type) values were compared to values produced by a standard pitot tube which had been certified with a correction factor of .99. Both standard and "S" type tubes were moved across the wind tunnel duct diameter on a 12 point traverse while readings were taken on a duplex manometer for direct comparison of the " ΔP " values - standard vs. "S" type Pitot tubes. Both "forward" and "reverse" tube orientation readings were taken with each "S" type Pitot tube. Reverse tube modifications were made, if necessary, to assure " ΔP " values in both directions agreed within 1%. We make our own Pitot tubes and design tube openings configuration more oval than round. Our Pitot tubes meet require-


ments as outlined in E.P.A. Method 2, Standards of Performance for New Stationary Sources.

Figure 1

F-1

OLD PLANT


Roanoke Plant Stacks Emission Test Location



Cross Sectional Area @ Test Ports = 35.78 Sq.Ft.

FIG. 2
 ROANOKE DUST SURVEY
 STACK
 VELOCITY & PARTICULATE SAMPLING
 OLD PLANT


F-2



PLAN VIEW
 CROSS SECTIONAL AREA - 35.78 Sq. Ft.

FIGURE 4
KILN STACK EMISSION SAMPLING


F-4



VELOCITY & PARTICULATE

SAMPLING TRAVERSE

FIGURE 5

PLAN VIEWCROSS SECTIONAL AREA = 78.5 SQ. FT.

SAMPLE CALCULATION FOR STACK RUN INOMENCLATURE

A_n	-	Cross-sectional area of sample nozzle, sq. ft.
A	-	Cross-sectional area of stack, ft. ³
B_{wo}	-	Proportion by volume of water vapor in the gas stream, dimensionless
C_p	-	Pitot tube coefficient, dimensionless
$C_{p \text{ std.}}$	-	Pitot tube coef. of standard type tube 0.99
$C_{p \text{ test}}$	-	Pitot tube coefficient of type "S" pitot tube
$c's$	-	Concentration of particulate matter in stack gas, gr./s.c.f. dry basis
c_s	-	Concentration of particulate matter in stack gas, lb/s.c.f.
D_s	-	Inside diameter of stack at sample port, Ft.
E	-	Particulate emission rate
ΔH	-	Average pressure drop across the orifice meter, inches H ₂ O
I	-	Percent of Iso Kinetic sampling. Test acceptable between 90% - I - 110%
K_p	-	$85.48 \frac{\text{ft. lbs.}}{\text{sec. lb-mole } ^\circ R}$
M_d	-	Dry molecular weight of stack gas
M_{H_2O}	-	Molecular weight of water, 18 lb/lb-mole
M_s	-	Molecular weight of stack gas (wet basis) lbs/lb-mole $M_d (1-B_{wo}) + 18 B_{wo}$
M_n	-	Total amount of particulate matter collected, mg.
P_{bar}	-	Barometric pressure at the orifice meter, inches Hg.
$P_{std.}$	-	Absolute pressure at standard conditions, 29.92 inches Hg.
P_s	-	Absolute stack gas pressure, inches Hg.

$\Delta P_{std.}$	-	Velocity head measured by standard type pitot tube
ΔP_{test}	-	Velocity head measured by type "S" pitot tube
$\sqrt{\Delta P}_{ave.}$	-	Ave. velocity head of stack gas, inches H_2O
Q_s	-	Volumetric flow rate, dry basis, standard conditions, ft. ³ /hr.
R	-	Ideal gas constant
$^{\circ}R$	-	Degrees of temperature, Rankin (F+460)
ρ_{H_2O}	-	Density of water, 1 gm./ml.
$(T_s)_{ave}$	-	Average absolute stack gas temperature, $^{\circ}R$
$T_{std.}$	-	Absolute temperature at standard conditions, 550 $^{\circ}R$
T_m	-	Average dry gas meter temperature, $^{\circ}R$
θ	-	Total sampling time, min.
$V_m std.$	-	Volume of gas sample through the dry gas meter (standard conditions), cu. ft.
$V_s (ave)$	-	Stack gas velocity, feet per second (f.p.s.)
V_m	-	Volume of gas sample through the dry gas meter (meter conditions) cu. ft.
V_{ic}	-	Total volume of liquid collected in impingers and silica gel
17.71	-	$^{\circ}R$ per inch. Hg @ std. cond. of 550 & 29.92
24.1	-	Liters water per gram-mole
28.3	-	Liters dry air per cu. ft.
1.667	-	100/60 min/sec
13.6	-	Specific gravity of mercury
2.205×10^{-6}	-	mg/lb.
0.0154	-	Grains per mg.
32	-	Molecular weight of oxygen

1. - Velocity of Stack Gas

$$\begin{aligned}
 V_s \text{ (ave)} &= K_p \times C_p \times \sqrt{\Delta P_{\text{ave.}}} \times \sqrt{\frac{T_s \text{ ave.}}{P_s \times M_s}} \\
 &= (85.49) (0.83) (0.59) \times \sqrt{\frac{834}{(28.89) (28.63)}} \\
 &= \underline{42.02} \text{ ft/sec.}
 \end{aligned}$$

2. - Volume of Gas (Actual) from Stack:

$$\begin{aligned}
 \text{Volume} &= (V_s \text{ ave}) (A) (60) \\
 &= (42.02) (78.5) (60) \\
 &= 198,000 \text{ ACFM}
 \end{aligned}$$

3. - Volume Dry Gas @Standard Conditions:

$$\begin{aligned}
 Q_s &= 3600 (1-B_{wo}) (V_s \text{ ave.}) (A) \left(\frac{T_{\text{std}}}{T_s \text{ ave.}} \right) \left(\frac{P_s}{P_{\text{std}}} \right) \\
 &= 3600 (1-0.110) (42.02) (78.5) \left(\frac{530}{834} \right) \left(\frac{28.89}{29.92} \right) \\
 &= 6.48 \times 10^6 \text{ SCFH}
 \end{aligned}$$

4. - Sample Gas Volume @Standard Conditions:

$$\begin{aligned}
 V_m \text{ std.} &= 17.71 \times V_m \left(\frac{P_{\text{bar}} + \Delta H/13.6}{T_m} \right) \\
 &= 17.71 \times 65.24 \times \left(\frac{28.85 + 0.75/13.6}{537} \right) \\
 &= 62.26 \text{ Cu. Ft.}
 \end{aligned}$$

5. - Percent of Isokinetic - EPA Method:

$$\begin{aligned}
 I &= \frac{(1.667 \times T_s) \left[(0.00267) (V_{ic}) + \left(\frac{V_m}{T_m} (P_{\text{bar}} + \Delta H/13.6) \right) \right]}{(9) (V_s) (P_s) (A_n)} \\
 &= \frac{(1.667) (834) [(0.00267) (169) + (3.516)]}{(144) (42.02) (28.89) (0.000289)} \\
 &= \underline{109.1}
 \end{aligned}$$

% Isokinetic for all runs were calculated using the same method as above, and are presented in Table 8.

6. - Dust Concentration Calculations:

The particulate weight collected for Run No. 1 was 182.7 mg; therefore:

(a) Concentration in Grain/SCF is

$$= \frac{67.8}{V_{m \text{ std}}} \times 0.0154$$

$$= \frac{67.8}{62.26} \times 0.0154$$

$$= \underline{0.0168} \text{ Grain/SCF}$$

(b) Concentration in Lb/SCF is:

$$= \frac{0.0168}{7000} = 2.4 \times 10^{-6} \text{ Lb/SCF}$$

(c) Concentration in Lb/Hr. is:

$$= 2.4 \times 10^{-6} \times Q_s$$

$$= (2.4 \times 10^{-6}) \times (6.48 \times 10^6)$$

$$= \underline{15.5} \text{ Lb/Hr.}$$

(d) Concentration in mg/m³ :

$$= 0.0168 \frac{\text{grain/SCF}}{\sqrt{}} \times 22.83 \text{ (conversion factor)}$$

$$= \frac{103}{39} \text{ mg/m}^3 \text{ @ Std. Cond.}$$

MATERIAL BALANCE CALCULATIONS

(Sample Calculation for Stack No. 5)

I - Fuel Consumption Calculation - Molal BasisA. Coal Analysis

See Appendix for the copy of letter enclosed from Pittsburgh Testing Laboratory showing ultimate analysis of average sample gathered during testing, on the dry basis. Accordingly, ultimate coal analysis corrected for moisture of 7.13% is:

<u>% Component</u>	<u>Dry Basis</u>	<u>Coal Mill Feed "as used"*</u>
Carbon	74.56	69.24
Hydrogen	4.94	4.59
Nitrogen	0.03	0.03
Oxygen	7.14	6.63
Sulfur	1.78	1.65
Water	-	7.13
Ash	11.55	10.73

* "As used" refers to coal as fed to coal mill.

Coal "as fired" would be coal condition after the coal mill via the burner pipe to the kiln and burning process.

B. Distribution of Combustible and ProductsFuel, Oxygen & Air per 100 Lbs. Coal

Line	Constituent	Coal	Mol. Wt.	Moles Fuel	O ₂ Multiplier	O ₂ Moles Theo.	Moles/100 Lbs. Coal As Used			
							CO ₂	SO ₂	O ₂	N ₂ H ₂ O
1	C to CO ₂	69.24	12	5.77	1	5.77	5.77	-	-	-
2	H ₂ to H ₂ O	4.59	2	2.30	0.5	1.15	-	-	-	2.30
3	S to SO ₂	1.65	32	0.05	1	0.05	-	0.05	-	-
4	O ₂ (Deduct)	6.63	32	0.21	---	0.21	-	-	-	-
5	N ₂	0.03	28	0.00	---	0	-	-	-	0.00
6	Water	7.13	18	0.40	---	0	-	-	-	0.40
7	Ash	10.73	--	--	---	0	-	-	-	-
8	Total	100	--	--	---	7.18	5.77	0.05	-	0.00 2.70

9 Therefore, O₂ required, Line 8 - 7.18

10 Recall, Mole Ratio of N₂ to O₂ in Air is 3.76

11 Then, N₂ with Air - $7.18 \times 79/21 = 27.01$ - - - - - 27.01

12 Dry Air supplied (Line 9+11) - 7.18 + 27.01 = 34.19

13 H₂O in Air - $*0.0195 \times 34.19 = 0.67$ - - - - - 0.67

14 Wet Air supplied (Line 12+13) - 34.86

15 Flue Gas Constituents (Line 1 to 14) Total - - - - - 5.77 0.05 27.01 3.37

Total Moles Dry Flue Gas / 100 Lbs. Coal As Used - 32.83

Total Moles Wet Flue Gas / 100 Lbs. Coal As Used - 36.20

*Molal Humidity For Ambient Air @ 68°F & 82 % Relative Humidity

Theoretical Combustion Gas Quantities (No Excess Air)

1. - The average fuel coal used by kiln #1 during testing was 9.4 T/Hr., or:

$$\frac{(9.4)(2000)}{(60)} = 313 \text{ Lb/min.}$$

Accordingly, 100 lbs. coal supplies fuel for:

$$\frac{100}{313} = 0.319 \text{ min. of kiln operation}$$

2. - Therefore, referring to I-B:

(a) Theoretical dry air supplied for total combustion:

$$\frac{(32.20)(387)}{(0.319)} = 39045 \text{ SCFM}$$

(Standard Conditions: 70° F and 29.92 in. Hg.)

Wet Air Supplied:

$$\frac{(32.83)(387)}{(0.319)} = 39806.38 \text{ SCFM}$$

$$\begin{aligned} \text{H}_2\text{O in air} &= 39806 - 39045 \\ &= 761 \text{ SCFM} \end{aligned}$$

(b) Flue Gas Components:

$$\text{CO}_2 = \frac{(5.77)(44)}{(0.319)} = 795.49 \text{ Lb/min.}$$

$$\text{H}_2\text{O} = \frac{(3.37)(18)}{(0.319)} = 183.02 \text{ Lb/min.}$$

$$\text{N}_2 = \frac{(27.01)(28)}{(0.319)} = 2231.81 \text{ Lb/min.}$$

$$\text{SO}_2 = \frac{(0.05)(64)}{(0.319)} = 10.34 \text{ Lb/min.}$$

3. - Breakdown of Water Source:

(a) Combustion Water:

$$\frac{(2.30)(18)}{(0.319)} = 129.44 \text{ Lb/min.}$$

(b) Water in coal as used:

$$\frac{(0.323)(18)}{(0.319)} = 18.17 \text{ Lb/min.}$$

(3) Water in supplied air:

$$\frac{(0.628)(18)}{(0.319)} = 35.41 \text{ Lb/min.}$$

TOTAL 183 Lb/min., for combustion process

III - Other Sources for CO₂ and H₂O :

(a) Liberation of CO₂ from kiln feed:

Average raw mix feed rate during test was 102.3 T/hr. or 3410 Lb/min. dry solids;

Kiln feed chemical analysis (Table 10) was used to determine the available CO₂ liberated from CaCO₃ and MgCO₃ :

$$\begin{aligned} (\% \text{ CaO}) \times \frac{100}{56} &= (\% \text{ CaCO}_3) \\ &= (42.85) \times \frac{100}{56} = 76.52 \% \text{ CaCO}_3 \end{aligned}$$

$$\begin{aligned} (\% \text{ MgO}) \times \frac{84}{40} &= (\% \text{ MgCO}_3) \\ &= (2.15) \times \frac{84}{40} = 4.52 \% \text{ MgCO}_3 \end{aligned}$$

$$\text{From CaCO}_3, \text{ CO}_2 = \frac{(76.52)(44)}{(100)} = 33.67 \text{ Lb/100 Lb. kiln feed}$$

$$\text{From MgCO}_3, \text{ CO}_2 = \frac{(4.52)(44)}{(84)} = 2.37 \text{ Lb/100 Lb. kiln feed}$$

Total CO₂ = 36.03 Lb/100 Lb. kiln feed

or,

$$\begin{aligned} \text{CO}_2 \text{ liberated from kiln feed} &= \frac{(36.03)(3410)}{(100)} \\ &= 1228 \text{ Lb/min.} \end{aligned}$$

(b) H₂O from kiln feed and cooling process:

Average moisture in kiln feed is 0.34 %, therefore water from kiln feed:

$$785 \times \frac{(0.34)}{(100-0.34)} = 11.63 \text{ Lb/min.}$$

During normal operation conditions, Roanoke Plant used approximately 22.5 Gal/min. of water to cool kiln exit gases. Water from cooling process:

$$(49.5)(8.33) = 412 \text{ Lb/min.}$$

IV - Theoretical Kiln Exit Gas (No Excess Air)1. - Total Exit Gas Quantities (per min. of kiln operation)

<u>Source</u>	<u>CO₂ (Lb)</u>	<u>H₂O (Lb)</u>	<u>N₂ (Lb)</u>
(a) Combustion Process	795.49	183.02	2231.81
(b) Kiln Feed Liberation	1228.72	11.63	-
(c) Cooling Process	-	412.34	-
TOTAL	2024.21	606.99	2231.81

2. - Exit Gas Analysis - Wet Basis

$$\text{CO}_2 \text{ (moles)} = \frac{2024.21}{44} = 46.00$$

$$\text{H}_2\text{O (moles)} = \frac{606.99}{18} = 33.72$$

$$\text{N}_2 \text{ (moles)} = \frac{2231.81}{28} = 79.70$$

$$\text{TOTAL} \quad 159.43 \quad \text{Moles/min.}$$

Hence:

$$\text{CO}_2 = \frac{46.00}{159.43} = 28.86\%$$

$$\text{H}_2\text{O} = \frac{33.72}{159.42} = 21.15\%$$

$$\text{N}_2 = \frac{79.70}{159.43} = 49.99\%$$

3. - Exit Gas Analysis - Dry Basis

$$\text{CO}_2 = \frac{28.86}{(100-21.15)} = 36.60\%$$

$$\text{N}_2 = \frac{49.99}{(100-21.15)} = 63.40\%$$

4. - Theoretical Exit Gas Volume:

At standard conditions (70°F and 29.92 "Hg)		
Volume = (159.43)(387)	=	61701 SCFM (wet)
or = (61701)(100-21.15)	=	48650 SCFM (dry)

V - Actual Stack Gas at Sampling Ports (Calculated):

1. - Exhaust gas included not only theoretical combustion flue gas but also excess air for actual combustion and infiltrated air at location such as kiln exit, precipitator, etc. From here forward, the term "Excess Air" will be used to indicate "Excess and Infiltrated Air".
2. - Average Orsat Analysis taken from exhaust gas is showing along with theoretical gas analysis:

Orsat Analysis (Dry)

CO₂ - 10.8
O₂ - 14.85
N₂ - 74.35

Theoretical Analysis (Dry)

CO₂ - 36.60
O₂ - 0
N₂ - 63.40

3. - Excess Air Calculation:

(a) CO₂ Balance (using above analysis)

$$(\text{Vol. Comb. Gas}) (\% \text{ CO}_2) + (\text{Vol. Excess Air}) (\% \text{ CO}_2) = (\text{Vol. Actual Gas}) (\% \text{ CO}_2)$$

Let X = Vol. Combustion Gas (Relative)
(100-X) = Vol. Excess Air (Relative)
100 = Vol. Actual Gas (Relative)

then,

$$\begin{aligned} (X) (36.60) &= (100-X) (0) = (100) (10.8) \\ 36.60 X &= 1080 \\ X &= 29.51\% (\text{Comb. Gas}) \\ (100-X) &= 70.49\% (\text{Excess Air}) \end{aligned}$$

From IV-4 above, the theoretical dry exit gas was 48650 SCFM, therefore actual kiln exit gas (dry) would be:

$$\frac{48650}{0.2951} = 164850 \quad \text{SCFM (dry)}$$

$$\begin{aligned} \text{and Excess Air: } 164850 &- 48650.70 \\ &= 116199 \quad \text{SCFM (dry)} \end{aligned}$$

(b) Oxygen Balance (using above analysis)

$$\begin{aligned} (\text{Vol. Comb. Gas}) (\% \text{ O}_2) &+ (\text{Vol. Excess Air}) (\% \text{ O}_2) \\ &= (\text{Vol. Actual Gas}) (\% \text{ O}_2) \end{aligned}$$

Using the same symbol X as above,

$$\begin{aligned} (X) (0) &= (100-X) (21) &= (100) (14.85) \\ &X &= \frac{2100 - 1485}{21} \\ &(100-X) &= 29.29\% \text{ (Comb. Gas)} \\ &&= 70.71\% \text{ (Excess Air)} \end{aligned}$$

Hence,

$$\begin{aligned} \text{Actual kiln exit gas volume} &= \frac{48650}{0.2929} \\ &= 166124 \text{ SCFM (dry)} \\ \text{Excess Air} &= (166124) - 48650 \\ &= 117473 \text{ SCFM (dry)} \end{aligned}$$

(c) Reconciliation of Balance:

The CO₂ and O₂ balance should give the same quantity of excess air for a given location. They did not agree exactly due to experimental error, but the average of the balances may represent the true condition;

$$\text{(Average) Excess Air} = \frac{116199 + 117473}{2}$$

$$= 116836 \text{ SCFM (dry)}$$

4. - Excess Air Components:

Lb/min. of kiln operation:

$$O_2 = \frac{(116836) (.21) (32)}{(387)} = 2028 \text{ Lb/min.}$$

$$N_2 = \frac{(116836) (.79) (28)}{(387)} = 6678 \text{ Lb/min.}$$

$$H_2O = \frac{(116836) (0.0195) (18)}{(387)} = 105 \text{ Lb/min}$$

$$\text{or } (116836) (0.0195) = 2278 \text{ SCFM}$$

(Recall was the average molal humidity of air @ testing period)

5. - Actual Stack Exit Gas Volume:

$$(a) \text{ Theoretical kiln exit gas (IV-4)} = 61701 \text{ SCFM (wet)}$$

$$(b) \text{ Excess Air (V-3 and V-4)} = 116836 + 2278$$

$$= 119115.05 \text{ SCFM (wet)}$$

$$(c) \text{ Actual Stack Exit Gas} = 61701 + 119115$$

$$\text{@ Standard conditions} = 180816 \text{ SCFM (wet)}$$

(70°F and 29.92 "Hg)

$$(d) \text{ Actual Stack Exit Gas} = \frac{(180816.10) (792) (29.92)}{(530) (28.87)}$$

@ Stack conditions

(332°F and 28.87 "Hg)

$$= 280027 \text{ ACFM (wet)}$$

VI - Actual Stack Gas (Measured)1. - Gas Volume:

Average volume of stack gas measured was 288600. ACFM (wet) @ average stack conditions of 332 °F (or 792 °R) and 28.87 "Hg. Therefore, at standard conditions (70 °F and 29.92 "Hg.), stack gas volume is:

$$\frac{(288600)(530)(28.87)}{(792)(29.92)} = 186351 \text{ SCFM (wet)}$$

2. - Gas Components:

- (a) On the average, 12.7% of stack gas was water vapor based on condensate collected during test. This was 12.7 % by volume since we compared moisture content of stack gas while water was in vapor state. Therefore, stack gas contained:

$$(186351)(0.127) = 23666 \text{ SCFM}$$

or,

$$\frac{(23666)(18)}{(387)} = 1100 \text{ Lb/min.}$$

- (b) Orsat analysis shows 10.8% CO₂, 14.85% O₂, and 74.35% N₂ on the dry basis. With 12.7% H₂O, the analysis can be reported on the wet basis as follows:

$$\begin{array}{lcl} \text{CO}_2 & : & (10.8)(1-0.127) = 9.43 \\ \text{O}_2 & : & (14.85)(1-0.127) = 12.96 \\ \text{N}_2 & : & (74.35)(1-0.127) = 64.91 \\ \text{H}_2\text{O} & : & = 12.70 \end{array}$$

TOTAL 100

- (c) From VI-1 above, the total volume of stack gas was measured as 186351 SCFM (wet). The rate of each gaseous component emitted from the stack can be calculated as follows:

$$\text{CO}_2 = \frac{(186351)(0.0943)(44)}{(387)} = 1997 \text{ Lb/min.}$$

$$\text{O}_2 = \frac{(186351)(0.1296)(32)}{(387)} = 1997 \text{ Lb/min.}$$

$$\text{N}_2 = \frac{(186351)(0.6491)(28)}{(387)} = 8751 \text{ Lb/min.}$$

$$\text{H}_2\text{O} = 1100 \text{ Lb/min. (from VI - 2(a))}$$

VII - Gas Balance:(1) CO₂ :

CO₂ Input = 2024 Lb/min. (from IV - 1)
CO₂ Output = 1997 Lb/min. (from VI - 2 - c)

Measuring Efficiency (°/I) = 98.69 %

(2) O₂ :

O₂ Input = 2028 Lb/min. (from V-4)
O₂ Output = 1997 Lb/min. (from VI-2-c)

Measuring Efficiency (°/I) = 98.46 %

(3) N₂ :

N₂ Input = 8909 Lb/min. (from IV-1 and V-4)
N₂ Output = 8751 Lb/min. (from VI-2-c)

Measuring Efficiency (°/I) = 98.22 %

(4) Water:

H₂O Input = 712 Lb/min. (from IV-1 and V-4)
H₂O Output = 1100 Lb/min. (from VI-2-c)

Measuring Efficiency (°/I) = 154.39 %

(5) Total Gas Volume:

Calculated Gas Volume = 280027 ACFM (from V-5)
Measured Gas Volume = 288600 ACFM (from VI-1)
Measuring Efficiency = 103 %

MATERIAL BALANCE CALCULATIONS FOR KILN OPERATED WITH COAL AS FUEL
 EMISSION TESTING AT ROANOKE PLANT, July - Oct./1979
 RUNS 45, 46, 47, 48, 49, and 50 (Stack No. 1)

DATA INPUT

CARBON WEIGHT% IN COAL= 69.24
 HYDROGEN WEIGHT% IN COAL= 4.59
 NITROGEN WEIGHT% IN COAL= 0.03
 OXYGEN WEIGHT% IN COAL= 6.63
 SULFUR WEIGHT% IN COAL= 1.65
 WATER WEIGHT% IN COAL= 7.13
 CAO WEIGHT% IN RAW MIX = 43.03
 MGO WEIGHT% IN RAW MIX = 2.10
 H2O RATE FOR COOLING PROCESS, GAL/MIN = 24.0
 H2O% IN KILN FEED = 0.46
 CO2 VOL.%, ORSAT ANALYSIS = 13.13
 OXY VOL.%, ORSAT ANALYSIS = 12.20
 N2 VOL.%, ORSAT ANALYSIS = 74.67
 AVE. RAW FEED, TON/HR = 21.2
 AVE. CLINKER PRODUCED, TON/HR = 14.1
 AVE. FUEL COAL RATE, TON/HR = 3.4
 MOLAL HUMIDITY OF AMBIENT AIR = 1.95000000E-02
 AVE. VOL. OF STACK GAS (WET), ACFM = 65700
 AVE. VOL. % OF H2O IN STACK GAS = 17.4
 AVE. TEMP. OF STACK GAS, DEG. R = 861
 AVE. PRES. OF STACK GAS, IN. HG. = 28.68

RESULTS

BASIS 100 LB FUEL COAL (AS USED)

THEORETICAL AIR REQUIRED :

DRY AIR = 14122.66 SCFM
 WET AIR = 14398.05 SCFM

EXCESS AIR CALCULATED :

BASED ON CO2 BALANCE, DRY = 20439.36 SCFM
 BASED ON OXY BALANCE, DRY = 22089.03 SCFM
 AVERAGE, DRY = 21264.19 SCFM
 AVERAGE, WET = 21678.84 SCFM

CARBON DIOXIDE BALANCE :

CO2 LIBERATED FROM RAW MIX = 255.24 LB/MIN
TOTAL INPUT = 542.97 LB/MIN

CO2 MEASURED FROM STACK = 478.02 LB/MIN
TOTAL OUTPUT = 478.02 LB/MIN

MEASURING EFFICIENCY (O/I) = 88.04 %

A-15

OXYGEN BALANCE :

O2 IN EXCESS AIR = 369.24 LB/MIN
TOTAL INPUT = 369.24 LB/MIN

O2 MEASURED FROM STACK = 323.02 LB/MIN
TOTAL OUTPUT = 323.02 LB/MIN

MEAS. EFFICIENCY (O/I) = 87.48 %

NITROGEN BALANCE :

N2 IN COMBUSTION AIR = 807.25 LB/MIN
N2 IN EXCESS AIR = 1215.4 LB/MIN
TOTAL INPUT = 2022.66 LB/MIN

N2 MEASURED FROM STACK = 1729.93 LB/MIN
TOTAL OUTPUT = 1729.93 LB/MIN

MEAS. EFFICIENCY (O/I) = 85.53 %

WATER BALANCE :

H2O FROM COMBUSTION PROCESS = 46.82 LB/MIN
H2O IN COMBUSTION AIR = 12.81 LB/MIN
H2O IN EXCESS AIR = 19.29 LB/MIN
H2O FROM COOLING PROCESS = 199.92 LB/MIN
H2O IN FUEL COAL = 8.08 LB/MIN
H2O IN KILN FEED = 3.27 LB/MIN
TOTAL INPUT = 290.18 LB/MIN

H2O MEASURED FROM STACK = 313.74 LB/MIN
TOTAL OUTPUT = 313.74 LB/MIN

MEASURING EFFICIENCY (O/I) = 108.12 %

TOTAL THEO. VOLUME OF STACK GAS (WET) = 43436.12 SCFM
TOTAL MEAS. VOLUME OF STACK GAS (WET) = 38766.42 SCFM
TOTAL GAS MEAS. EFFICIENCY = 89.25 %

MATERIAL BALANCE CALCULATIONS FOR KILN OPERATED WITH COAL AS FUEL

EMISSION TESTING AT ROANOKE PLANT, July - Oct./1979

RUNS 51, 52, 53, 54, 55, and 56 (Stack No. 3)

DATA INPUT

CARBON WEIGHT% IN COAL= 69.24
 HYDROGEN WEIGHT% IN COAL= 4.59
 NITROGEN WEIGHT% IN COAL= 0.03
 OXYGEN WEIGHT% IN COAL= 6.63
 SULFUR WEIGHT% IN COAL= 1.65
 WATER WEIGHT% IN COAL= 7.3
 CAO WEIGHT% IN RAW MIX = 43.03
 MGO WEIGHT% IN RAW MIX = 2.10
 H2O RATE FOR COOLING PROCESS, GAL/MIN = 25
 H2O% IN KILN FEED = 0.51
 CO2 VOL.%, ORSAT ANALYSIS = 12.93
 OXY VOL.%, ORSAT ANALYSIS = 12.20
 N2 VOL.%, ORSAT ANALYSIS = 74.87
 AVE. RAW FEED, TON/HR = 21.6
 AVE. CLINKER PRODUCED, TON/HR = 14.4
 AVE. FUEL COAL RATE, TON/HR = 2.8
 MOLAL HUMIDITY OF AMBIENT AIR = 195000000E-02
 AVE. VOL. OF STACK GAS (WET), ACFM = 60700
 AVE. VOL. % OF H2O IN STACK GAS = 16.5
 AVE. TEMP. OF STACK GAS, DEG. R = 880
 AVE. PRES. OF STACK GAS, IN. HG. = 28.54

RESULTS

BASIS 100 LB FUEL COAL (AS USED)

THEORETICAL AIR REQUIRED :

DRY AIR = 11630.43 SCFM
 WET AIR = 11857.22 SCFM

EXCESS AIR CALCULATED :

BASED ON CO2 BALANCE, DRY = 20248.78 SCFM
 BASED ON OXY BALANCE, DRY = 18798.93 SCFM
 AVERAGE, DRY = 19523.85 SCFM
 AVERAGE, WET = 19904.57 SCFM

CARBON DIOXIDE BALANCE :

CO₂ LIBERATED FROM RAW MIX = 260.06 LB/MIN
 TOTAL INPUT = 497.01 LB/MIN

CO₂ MEASURED FROM STACK = 428.06 LB/MIN
 TOTAL OUTPUT = 428.06 LB/MIN

MEASURING EFFICIENCY (O/I) = 86.13 %

OXYGEN BALANCE :

O₂ IN EXCESS AIR = 339.02 LB/MIN
 TOTAL INPUT = 339.02 LB/MIN

O₂ MEASURED FROM STACK = 293.74 LB/MIN
 TOTAL OUTPUT = 293.74 LB/MIN

MEAS. EFFICIENCY (O/I) = 86.64 %

NITROGEN BALANCE :

N₂ IN COMBUSTION AIR = 664.80 LB/MIN
 N₂ IN EXCESS AIR = 1115.94 LB/MIN
 TOTAL INPUT = 1780.73 LB/MIN

N₂ MEASURED FROM STACK = 1577.30 LB/MIN
 TOTAL OUTPUT = 1577.30 LB/MIN

MEAS. EFFICIENCY (O/I) = 88.58 %

WATER BALANCE :

H₂O FROM COMBUSTION PROCESS = 38.56 LB/MIN
 H₂O IN COMBUSTION AIR = 10.55 LB/MIN
 H₂O IN EXCESS AIR = 17.71 LB/MIN
 H₂O FROM COOLING PROCESS = 208.25 LB/MIN
 H₂O IN FUEL COAL = 6.81 LB/MIN
 H₂O IN KILN FEED = 3.69 LB/MIN
 TOTAL INPUT = 285.57 LB/MIN

H₂O MEASURED FROM STACK = 267.62 LB/MIN
 TOTAL OUTPUT = 267.62 LB/MIN

MEASURING EFFICIENCY (O/I) = 93.72 %

TOTAL THEO. VOLUME OF STACK GAS (WET) = 39223.41 SCFM
 TOTAL MEAS. VOLUME OF STACK GAS (WET) = 34871.79 SCFM
 TOTAL GAS MEAS. EFFICIENCY = 88.91 %

MATERIAL BALANCE CALCULATIONS FOR KILN OPERATED WITH COAL AS FUEL

EMISSION TESTING AT ROANOKE PLANT, July - October/1979

RUNS 39, 40, 41, 42, 43, and 44 (Stack No. 4)

DATA INPUT

CARBON WEIGHT% IN COAL= 69.24
 HYDROGEN WEIGHT% IN COAL= 4.59
 NITROGEN WEIGHT% IN COAL= 0.03
 OXYGEN WEIGHT% IN COAL= 6.63
 SULFUR WEIGHT% IN COAL= 1.65
 WATER WEIGHT% IN COAL= 6.1
 CAO WEIGHT% IN RAW MIX = 43.03
 MGO WEIGHT% IN RAW MIX = 2.10
 H2O RATE FOR COOLING PROCESS, GAL/MIN = 26
 H2O% IN KILN FEED = 0.40
 CO2 VOL.%, ORSAT ANALYSIS = 16.93
 OXY VOL.%, ORSAT ANALYSIS = 10
 N2 VOL.%, ORSAT ANALYSIS = 73.07
 AVE. RAW FEED, TON/HR = 27.9
 AVE. CLINKER PRODUCED, TON/HR = 19.0
 AVE. FUEL COAL RATE, TON/HR = 3.0
 MOLAL HUMIDITY OF AMBIENT AIR = 1.95000000E-02
 AVE. VOL. OF STACK GAS (WET), ACFM = 70900
 AVE. VOL. % OF H2O IN STACK GAS = 13.7
 AVE. TEMP. OF STACK GAS, DEG. R = 873
 AVE. PRES. OF STACK GAS, IN. HG. = 28.91

RESULTS

BASIS 100 LB FUEL COAL (AS USED)

THEORETICAL AIR REQUIRED :

DRY AIR = 12461.17 SCFM
 WET AIR = 12704.16 SCFM

EXCESS AIR CALCULATED :

BASED ON CO2 BALANCE, DRY = 15608.47 SCFM
 BASED ON OXY BALANCE, DRY = 13665.64 SCFM
 AVERAGE, DRY = 14637.05 SCFM
 AVERAGE, WET = 14922.48 SCFM

CARBON DIOXIDE BALANCE :

CO2 LIBERATED FROM RAW MIX = 335.91 LB/MIN
TOTAL INPUT = 589.79 LB/MIN

A-19

CO2 MEASURED FROM STACK = 690.88 LB/MIN
TOTAL OUTPUT = 690.88 LB/MIN

MEASURING EFFICIENCY (O/I) = 117.14 %

OXYGEN BALANCE :

O2 IN EXCESS AIR = 254.16 LB/MIN
TOTAL INPUT = 254.16 LB/MIN

O2 MEASURED FROM STACK = 296.79 LB/MIN
TOTAL OUTPUT = 296.79 LB/MIN

MEAS. EFFICIENCY (O/I) = 116.77 %

NITROGEN BALANCE :

N2 IN COMBUSTION AIR = 712.28 LB/MIN
N2 IN EXCESS AIR = 836.62 LB/MIN
TOTAL INPUT = 1548.90 LB/MIN

N2 MEASURED FROM STACK = 1897.54 LB/MIN
TOTAL OUTPUT = 1897.54 LB/MIN

MEAS. EFFICIENCY (O/I) = 122.51 %

WATER BALANCE :

H2O FROM COMBUSTION PROCESS = 41.31 LB/MIN
H2O IN COMBUSTION AIR = 11.30 LB/MIN
H2O IN EXCESS AIR = 13.28 LB/MIN
H2O FROM COOLING PROCESS = 216.58 LB/MIN
H2O IN FUEL COAL = 6.10 LB/MIN
H2O IN KILN FEED = 3.73 LB/MIN
TOTAL INPUT = 292.30 LB/MIN

H2O MEASURED FROM STACK = 265.02 LB/MIN
TOTAL OUTPUT = 265.02 LB/MIN

MEASURING EFFICIENCY (O/I) = 90.67 %

TOTAL THEO. VOLUME OF STACK GAS (WET) = 35953.76 SCFM
TOTAL MEAS. VOLUME OF STACK GAS (WET) = 41590.52 SCFM
TOTAL GAS MEAS. EFFICIENCY = 115.68 %

MATERIAL BALANCE CALCULATIONS FOR KILN OPERATED WITH COAL AS FUEL

EMISSION TESTING AT ROANOKI PLANT, July - October/1979

RUNS 7, 8, 10, 12, and 14 (Stack No. 5)

DATA INPUT

CARBON WEIGHT% IN COAL= 69.24
 HYDROGEN WEIGHT% IN COAL= 4.59
 NITROGEN WEIGHT% IN COAL= 0.03
 OXYGEN WEIGHT% IN COAL= 6.63
 SULFUR WEIGHT% IN COAL= 1.65
 WATER WEIGHT% IN COAL= 5.8
 CAO WEIGHT% IN RAW MIX = 42.85
 MGO WEIGHT% IN RAW MIX = 2.15
 H2O RATE FOR COOLING PROCESS, GAL/MIN = 49.5
 H2O% IN KILN FEED = 0.34
 CO2 VOL.%, ORSAT ANALYSIS = 10.8
 OXY VOL.%, ORSAT ANALYSIS = 14.85
 N2 VOL.%, ORSAT ANALYSIS = 74.35
 AVE. RAW FEED, TON/HR = 102.3
 AVE. CLINKER PRODUCED, TON/HR = 64.3
 AVE. FUEL COAL RATE, TON/HR = 9.4
 MOLAL HUMIDITY OF AMBIENT AIR = 1.95000000E-02
 AVE. VOL. OF STACK GAS (WET), ACFM = 288600
 AVE. VOL. % OF H2O IN STACK GAS = 12.7
 AVE. TEMP. OF STACK GAS, DEG. R = 792
 AVE. PRES. OF STACK GAS, IN. HG. = 28.87

RESULTS

BASIS 100 LB FUEL COAL (AS USED)

THEORETICAL AIR REQUIRED :

DRY AIR = 39045.00 SCFM
 WET AIR = 39806.38 SCFM

EXCESS AIR CALCULATED :

BASED ON CO2 BALANCE, DRY = 116199.82 SCFM
 BASED ON OXY BALANCE, DRY = 117473.65 SCFM
 AVERAGE, DRY = 116836.74 SCFM
 AVERAGE, WET = 119115.05 SCFM

CARBON DIOXIDE BALANCE :

CO2 LIBERATED FROM RAW MIX = 1228.72 LB/MIN
TOTAL INPUT = 2024.21 LB/MIN

A-21

CO2 MEASURED FROM STACK = 1997.62 LB/MIN
TOTAL OUTPUT = 1997.62 LB/MIN

MEASURING EFFICIENCY (O/I) = 98.69 %

OXYGEN BALANCE :

O2 IN EXCESS AIR = 2028.79 LB/MIN
TOTAL INPUT = 2028.79 LB/MIN

O2 MEASURED FROM STACK = 1997.62 LB/MIN
TOTAL OUTPUT = 1997.62 LB/MIN

MEAS. EFFICIENCY (O/I) = 98.46 %

NITROGEN BALANCE :

N2 IN COMBUSTION AIR = 2231.81 LB/MIN
N2 IN EXCESS AIR = 6678.11 LB/MIN
TOTAL INPUT = 8909.92 LB/MIN

N2 MEASURED FROM STACK = 8751.34 LB/MIN
TOTAL OUTPUT = 8751.34 LB/MIN

MEAS. EFFICIENCY (O/I) = 98.22 %

WATER BALANCE :

H2O FROM COMBUSTION PROCESS = 129.44 LB/MIN
H2O IN COMBUSTION AIR = 35.41 LB/MIN
H2O IN EXCESS AIR = 105.97 LB/MIN
H2O FROM COOLING PROCESS = 412.34 LB/MIN
H2O IN FUEL COAL = 18.17 LB/MIN
H2O IN KILN FEED = 11.63 LB/MIN
TOTAL INPUT = 712.96 LB/MIN

H2O MEASURED FROM STACK = 1100.77 LB/MIN
TOTAL OUTPUT = 1100.77 LB/MIN

MEASURING EFFICIENCY (O/I) = 154.39 %

TOTAL THEO. VOLUME OF STACK GAS (WET) = 180816.10 SCFH
TOTAL MEAS. VOLUME OF STACK GAS (WET) = 186351.21 SCFH
TOTAL GAS MEAS. EFFICIENCY = 103.06 %

STACK EMISSIONS
SUMMARY SCHEMATIC
UNITS: LB/MIN.
KILN NO. 1

INPUT

199.9 Water in pelletizing process
46.8 Water from combustion process
8.1 Water in coal fuel
3.3 Water in raw mix feed
12.8 Water in combustion air
19.3 Water in excess air

1215.4 Nitrogen in excess air
807.3 Nitrogen in combustion air

237.0 CO₂ from carbon in coal
255.2 CO₂ from raw mix decomposition


369.3 O₂ in excess & infiltrated air

3174.4 TOTAL

OUTPUT

CO ₂	O ₂	N ₂	H ₂ O	TOTAL
478.0	323.0	1729.9	313.7	2844.6

STACK
GAS



$$\text{MEASURING EFFICIENCY} = \frac{2844.6}{3174.4} = 89.6$$

JOAN DUSKIN
STACK EMISSIONS
SUMMARY SCHEMATIC
UNITS: LB/MIN.
KILN NO. 3

INPUT

208.3 Water in pelletizing process
38.6 Water from combustion process
6.8 Water in coal fuel
3.7 Water in raw mix feed
10.6 Water in combustion air
17.7 Water in excess air

1115.9 Nitrogen in excess air
664.8 Nitrogen in combustion air

237.0 CO₂ from carbon in coal
260.1 CO₂ from raw mix decomposition


339.0 O₂ in excess & infiltrated air

2902.5 TOTAL


OUTPUT

428.1	CO ₂
293.7	O ₂
1577.3	N ₂
267.6	H ₂ O
<u>2566.7</u>	TOTAL

STACK
GAS



$$\text{MEASURING EFFICIENCY} = \frac{2567}{2903} = 88.4$$



OUTPUT		
→	690.9	CO ₂
→	296.8	O ₂
→	1897.5	N ₂
→	265.0	H ₂ O
	3150.2	TOTAL

$$\text{MEASURING EFFICIENCY} = \frac{3150.2}{2685.2} = 117.3$$

COAL DUST
STACK EMISSIONS
SUMMARY SCHEMATIC
UNITS: LB/MIN.
KILN NO. 5

INPUT

412.3 Water in pelletizing process
129.4 Water from combustion process
18.2 Water in coal fuel
11.6 Water in raw mix feed
35.4 Water in combustion air
105.9 Water in excess air

6678.1 Nitrogen in excess air
2231.8 Nitrogen in combustion air


795.5 CO₂ from carbon in coal
1228.7 CO₂ from raw mix decomposition

2028.8 O₂ in excess & infiltrated air


13675.7 TOTAL

OUTPUT	CO ₂	O ₂	N ₂	H ₂ O	TOTAL
1997.6	1997.6	8751.3	1100.8		
					13847.3

STACK
GAS



$$\text{MEASURING EFFICIENCY} = \frac{13847.3}{13675.7} = 101.25$$



PITTSBURGH TESTING LABORATORY

ESTABLISHED 1881

850 POPLAR STREET, PITTSBURGH, PA. 15220

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

A-26

FORM 407 REV. 1-66

PLEASE REPLY TO:
P. O. BOX 1646
PITTSBURGH, PA. 15230

CLIENT'S No. P.O. #V-15921

AREA CODE 412 TELEPHONE 922-4000

LABORATORY No. 800852

ORDER No. PG-12577

REPORT

Oct. 12, 1979

Sample Description:

C O A L

Submitted by:


Lone Star Cement Inc.

Reported to:

Lone Star Cement Inc.
Roanoke Plant
P. O. Box 27
Cloverdale, VA. 24077

	<u>As Received</u>	<u>Dry Basis</u>
Moisture	1.36%	--
B.T.U. Per Pound	13,140	13,321
Carbon	--	74.56%
Hydrogen	--	4.94%
Oxygen	--	7.14%
Nitrogen	--	0.03%
Sulfur	--	1.78%
Ash	--	11.55%


PITTSBURGH TESTING LABORATORY


William S. Carlson
Manager, Chemical Department

2-Client
Attn: W. W. Hurst

ear

EPA METHOD 5 Particulate Sampling Train



EPA METHOD 5 SAMPLING TRAIN

1. Sampling Nozzle
2. Sampling probe sheath
3. Heated sample probe liner
4. Cyclone assembly (proposed regulations do not require this cyclone)
5. Out of stack filter assembly
6. Heated filter compartment maintained about 250°F (proposed = $\leq 248^{\circ}\text{F} \pm 25^{\circ}\text{F}$)
7. Impinger case
8. First impinger filled with H₂O (100 ml)
9. Greenburg-Smith (or modified Greenburg-Smith) impinger filled with H₂O (100 ml)
10. Third impinger - Dry
11. Fourth impinger - filled with H₂O absorption media (200 - 300 gm)
12. Impinger exit gas thermometer
13. Check valve to prevent back pressure
14. Umbilical cord - vacuum line
15. Pressure gauge
16. Coarse adjustment valve
17. Leak free pump
18. By-pass valve
19. Dry gas meter with inlet and outlet dry gas meter thermometer
20. Orifice meter with manometer
21. "S" type pitot tube with manometer
22. Stack temperature sensor

PARTICULATE FIELD DATA

68°F W.B

Run No. 1

Location KILN STE. NO. 5

Date 7/22/79

Operator R. C. CHU

Amb. Temp. °F 70°F

Bar. Press. "Hg. 28.85

Assumed Moist 10%

Test Periods 24 @ 6 min each

Probe Tip Dia., In. 1/4"

Probe Length 8'

Inp. Nos. 1-4

Sample Box No. 1

Heater Box Setting 250°F

FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST

Point	Clock Time	Dry Gas Meter C.F.	Pitot. In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	Desired	Actual	Inlet	Outlet						
NW-1	9:39/45	260.92	0.21	0.46	0.59	0.56	74	74	0.0	247	80	156	384	
2	51	263.34	0.21	0.46	0.59	0.59	75	76	0.0	251	87	175	421	
3	57	265.83	0.36	0.60	0.77	0.71	75	77	0.0	240	91	189	412	
4	10:03	271.43	0.41	0.64	0.82	0.79	77	79	1.0	206	90	288	403	
5	09	274.33	0.41	0.64	0.82	0.80	76	80	1.5	272	90	338	398	
6	15	277.30	0.45	0.67	0.86	0.85	75	79	1.5	260	81	365	385	+0.51
NW-1	10:29/31	279.83	0.25	0.50	0.64	0.61	73	75	0.0	272	78	216	375	
2	41	282.47	0.27	0.52	0.67	0.67	72	75	0.5	268	77	187	375	
3	47	285.34	0.43	0.66	0.84	0.79	75	76	2.0	232	81	212	360	
4	53	288.33	0.47	0.69	0.88	0.86	74	78	2.5	255	83	275	375	
5	59	291.76	0.49	0.70	0.90	0.88	72	78	2.5	246	80	323	370	
6	10:05	294.41	0.45	0.67	0.86	0.89	72	77	2.5	269	75	348	355	
SE-1	11:34/40	296.87	0.25	0.50	0.64	0.58	73	74	2.0	280	82	228	398	
2	44	299.46	0.25	0.50	0.64	0.64	73	74	2.0	256	79	193	330	
3	52	302.29	0.42	0.65	0.83	0.77	76	78	2.5	256	88	202	401	
4	58	305.36	0.45	0.67	0.86	0.87	73	76	3.0	224	80	231	331	
5	12:04	308.32	0.47	0.69	0.88	0.89	73	77	3.0	285	79	284	329	
6	10	311.36	0.52	0.72	0.92	0.89	72	77	3.5	257	75	315	329	
SW-1	12:28/34	313.90	0.14	0.37	0.61	0.61	77	79	2.5	273	79	220	348	
2	06	316.43	0.14	0.37	0.61	0.61	78	80	2.5	246	79	177	270	
3	46	319.10	0.30	0.55	0.70	0.68	78	80	3.0	246	85	150	385	
4	52	321.94	0.38	0.62	0.79	0.77	79	81	3.0	213	82	233	317	
5	58	324.86	0.43	0.66	0.84	0.81	79	83	3.5	243	82	288	336	
6	1:04	327.80	0.42	0.65	0.83	0.83	82	86	3.5	269	88	311	326	
TOTAL			10.16	15.21	17.94								8163	
AVERAGE			0.59	0.77	0.75		75.2	76.1					3135	

Dry Meter Calibration Factor

76.5 Volume

Ft. 3 X

0.9756

65.24 Ft. 3

CORRECTED SAMPLE VOLUME = 76.5

RUN NO. 1

PARTICULATE & WATER CATCH

IMPINGER NO. 1 Final Weight 673.39 Initial Weight 538.30 Increase 135.09 WATER WEIGHT GAIN

IMPINGER 1 135.09

IMPINGER NO. 2 Final Weight 576.71 Initial Weight 564.47 Increase 12.04

IMPINGER 2 12.04

IMPINGER NO. 3 Final Weight 458.71 Initial Weight 456.40 Increase 2.31

IMPINGER 3 2.31

IMPINGER NO. 4 Final Weight 758.15 Initial Weight 738.54 Increase 19.61

IMPINGER 4 19.61

FILTER NO. 3 Final Weight 7960 Initial Weight 7745 Part. Catch 215

TOTAL 169.05

SOLID WEIGHT GAIN

BEAKER NO. 14 Final Weight 143.1327 Initial Weight 143.0178 Increase 0.1149

ORSAT
40 CO₂ 8.2
32 O₂ 15.8
CO 0
28 N₂ 76.0

BEAKER NO. Final Weight Initial Weight Increase

FCHV 0.0215
BEAKER 18 0.0463
BEAKER 23 0.0678
BEAKER 5 0.1149

BEAKER NO. Final Weight Initial Weight Increase

TOTAL 0.1827

BEAKER NO. 18 Final Weight 143.7030 Initial Weight 143.6567 Increase 0.0463

Moisture Content: Sample Vol. 65.24 ft.³ x $\frac{460 + 70}{460 + \text{Meter}}$ X 28.3 L/ft.³ = 1823.9 L Dry Gas
536.5 Temp.

Water Weight 169.05 gm. x 24.1 L = 226.3 L H₂O Vapor
18 gm. mol.

Total = 2050.3 L

H₂O Vol. 226.3 L x 100 = 11.0 %
Total 2050.3

PARTICULATE FIELD DATA

68° WB

Run No. 2 Location CLD STKNOS Date 7/22/79 Operator Bill C.W.

Amb. Temp. °F 70° F Bar. Press. "Hg. 29.85 Assumed Moist 100% Test Periods 24 @ 6 min

Probe Tip Dia., In. 1/4" Probe Length 8' Inp. Nos. 5-8 Sample Box No. 7

Heater Box Setting 240° F FILL IN ALL BLANKS READ & RECORD AT THE START OF EACH TEST POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot, H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	√AP	In.	Desired	Actual	Inlet	Outlet					
SE-1	9:44/47	617.45	0.26	0.51	0.65	0.65	0.62	74	75	29.5	78	161	361	
2	50	619.57	0.25	0.50	0.64	0.64	0.53	73	75	3.5	76	195	365	
3	10:00	622.32	0.42	0.65	0.83	0.83	0.71	75	77	4.5	80	239	386	
4	06	625.04	0.52	0.72	0.92	0.92	0.82	75	79	5.5	82	262	389	
5	12	631.08	0.49	0.70	0.90	0.90	0.93	73	78	6.0	77	314	388	
6	17	634.28	0.52	0.72	0.92	0.92	0.91	74	81	7.0	85	365	384	
SW-1	10:32/38	636.70	0.22	0.47	0.60	0.60	0.56	72	75	3.5	80	230	358	
2	44	639.21	0.24	0.49	0.63	0.63	0.60	71	74	4.0	79	191	347	+0.52
3	50	641.98	0.38	0.62	0.79	0.79	0.74	72	77	5.0	81	177	356	
4	56	644.90	0.45	0.67	0.86	0.86	0.82	71	77	6.0	79	242	359	
5	11:02	648.08	0.49	0.70	0.90	0.90	0.97	72	79	7.0	80	314	362	
6	08	651.15	0.53	0.73	0.93	0.93	0.90	71	79	7.0	80	338	348	
NA-1	11:37/43	653.77	0.29	0.54	0.69	0.69	0.66	72	73	4.5	79	201	326	
2	49	656.35	0.26	0.51	0.65	0.65	0.64	72	75	5.0	79	207	328	
3	55	659.06	0.36	0.60	0.77	0.77	0.70	72	76	5.5	80	176	328	
4	12:01	661.96	0.42	0.65	0.83	0.83	0.81	71	76	5.5	76	193	331	
5	07	664.17	0.47	0.69	0.88	0.88	0.87	71	78	6.5	76	270	329	
6	13	668.11	0.52	0.72	0.92	0.92	0.94	70	79	7.5	81	312	327	
NE-1	12:31/37	670.62	0.22	0.47	0.60	0.60	0.60	81	83	4.5	75	195	294	
2	43	673.13	0.27	0.48	0.59	0.59	0.60	77	79	5.0	78	188	292	
3	49	675.95	0.41	0.64	0.82	0.82	0.76	81	85	6.0	88	175	316	
4	55	674.04	0.50	0.71	0.91	0.91	0.92	80	86	7.0	86	180	331	
5	1:01	682.37	0.64	0.73	0.94	0.94	1.06	85	91	8.5	83	288	337	
6	07	685.52	0.50	0.73	0.94	0.94	0.95	77	84	8.0	78	309	327	
TOTAL		6807		14.13	14.11	14.11	13.81	1712	1812				3443	
AVERAGE				0.62	0.560	0.560	0.78	70.3	70.8					

Corrected Sample Volume = 76.5 Meter Volume 68.07 Ft. 3 x 1.0521 = 71.62 Ft. 3

Dry Meter Calibration Factor

RUN NO. 2

PARTICULATE & WATER CATCH

IMPINGER NO. 5 Final Weight 696.35 Initial Weight 542.40 Increase 153.95 WATER WEIGHT GAIN

IMPINGER 1 153.95

IMPINGER NO. 6 Final Weight 559.71 Initial Weight 544.41 Increase 15.30

IMPINGER 2 15.30

IMPINGER NO. 7 Final Weight 466.71 Initial Weight 464.40 Increase 2.31

IMPINGER 3 2.31

IMPINGER 4 24.18

TOTAL 195.74

IMPINGER NO. 8 Final Weight 775.04 Initial Weight 750.86 Increase 24.18

ORSAT

CO₂ 8.2

O₂ 15.8

FILTER NO. 4 Final Weight 8145 Initial Weight 7781 Part. Catch 0.364

CO 0

N₂ 76.0

SOLID WEIGHT GAIN

BEAKER NO. 16 Final Weight 142.3236 Initial Weight 142.2322 Increase 0.0914

FCLV 0.0364

BEAKER 23.0504

BEAKER 0.0868

BEAKER NO. Final Weight Initial Weight Increase

BEAKER 3

BEAKER 16.0914

BEAKER NO. Final Weight Initial Weight Increase

TOTAL 0.1782

BEAKER NO. 23 Final Weight 146.0268 Initial Weight 145.9764 Increase 0.0504

Moisture Content: Sample Vol. 71.62 ft.³ x 460 ⁵³⁰ 70 X 28.3 L/ft.³ = 2002.3 L Dry Gas
460 Meter
536.5 Temp.

Water Weight 195.74 gm. x 24.1 L = 262.1 L H₂O Vapor
18 gm. mol.
mol.

Total = 2264.3 L

H₂O Vol. 262.1 L x 100 = 11.6 %
Total 2264.3

CECIL PARTICULATE FIELD DATA 70003

Run No. 3
Location W.S. Pile Stack
Date 7/24/79
Operator CECIL

Amb. Temp. °F 71.0
Bar. Press. "Hg. 28.92
Assumed Moist 100%
Test Periods 2400-0600

Probe Tip Dia., In. 1/4"
Probe Length 8'
Imp. Nos. 9-12
Sample Box No. 1

Heater Box Setting
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In.	1/2"	In.	1/2"	Inlet	Outlet						
S-1	10:05	328.42	AP	52	60	55	68	69	0	299	80	216	330	
S-2	10:11	330.82	.27	52	60	55	68	71	0	267	83	225	343	
S-3	10:17	333.51	.37	64	70	69	68	71	0	228	78	238	343	
S-4	10:26	338.93	.45	67	77	—	68	71	1.0	217	85	259	334	
S-5	10:32	341.70	.50	71	81	73	68	73	1.0	270	79	301	334	
S-6	10:40	344.63	.56	75	86	82	68	74	1.5	245	81	324	334	
S-7	10:48	347.57	.57	73	85	83	69	75	1.5	245	81	324	334	
E-1	11:08	349.95	.23	48	55	54	73	75	1.0	140	88	157	343	
2	21	352.58	.36	60	69	66	71	74	1.0	200	86	145	336	4.52
3	27	355.21	.26	60	69	66	72	76	1.0	222	84	214	345	
4	33	357.85	.36	60	69	66	74	75	1.0	288	88	303	346	
5	39	360.62	.48	69	80	74	70	75	1.0	262	81	340	347	
6	45	363.53	.48	69	80	81	75	80	1.0	236	88	347	345	
N-1	12:13	365.61	.18	42	49	44	69	70	1.0	340	82	150	313	
N-2	29	368.39	.31	56	64	74	71	73	2.0	229	82	153	391	
N-3	35	370.03	.36	60	69	67	70	73	1.5	260	85	227	329	
N-4	41	373.77	.41	64	74	77	69	73	1.5	234	85	282	330	
N-5	47	376.43	.41	64	74	77	70	75	2.0	250	91	297	324	
N-6	53	379.50	.43	66	75	78	70	75	2.5	291	82	313	320	
W-1	13:17	381.74	.18	42	49	44	84	86	1.0	262	95	130	308	
2	28	384.28	.29	53	62	62	83	86	1.5	250	94	120	334	
3	34	387.00	.36	60	69	67	83	86	1.5	260	93	182	378	
4	35	389.50	.43	66	75	75	81	85	1.5	240	93	250	328	
5	41	392.51	.43	66	75	87	85	89	1.5	280	98	261	329	
6	49	395.30	.49	70	81	75	86	91	2.0	245	99	266	324	
TOTAL														
AVERAGE														

Post Check Leaks - Beckman Clean Connect. 535 Meter Volume 66.78 Ft. 3 x 0.6756
CORRECTED SAMPLE VOLUME = 66.78 Dry Meter Calibration Factor 797
65.25

RUN NO. 3

PARTICULATE & WATER CATCH

Final Weight 90.80
Initial Weight 543.63
Increase

Final Weight 576.70
Initial Weight 569.46
Increase

Final Weight 454.45
Initial Weight 452.79
Increase

Final Weight 751.84
Initial Weight 734.99
Increase

Final Weight 7959
Initial Weight 7768
Part. Catch

Final Weight 145.1889
Initial Weight 145.1289
Increase

Final Weight 145.1889
Initial Weight 145.1289
Increase

Final Weight
Initial Weight
Increase

Final Weight
Initial Weight
Increase

IMPINGER NO. 9

IMPINGER NO. 10

IMPINGER NO. 11

IMPINGER NO. 12

FILTER NO. 5

BEAKER NO. 22

BEAKER NO.

BEAKER NO.

BEAKER NO. 5
PROBE WASH

Water Weight 172.4
18 gm.
x 24.1 L
mol.

mol.
= 230.8
L H₂O Vapor

460 + Meter
535 Temp.

Moisture Content: Sample Vol. 5.2 ft.³ x 28.3 L/ft.³ = 182.9 L Dry Gas

Final Weight 148.6878
Initial Weight 148.6339
Increase

460 + Meter
535 Temp.

Total = 9060 L

H₂O Vol. 231 L x 100 = 11.2%
Total 2000

TOTAL 1330

BEAKER 4

BEAKER 3 0.660

BEAKER 2 0.730

BEAKER 1 0.539

DELTA 0.0191

98.85

N₂ 74.6

CO

O₂ 15.4

CO₂ 10.0

ORSAT

TOTAL

172.4

IMPINGER 4 16.85

IMPINGER 3 1.66

IMPINGER 2 6.74

IMPINGER 1 147.17

Bos PARTICULATE FIELD DATA 70°F = 20°C

Run No. 4
Location Nb. S. E. L. D. ST. C. K.
Date 7-24-79
Operator LEWIS

Amb. Temp. °F 71.0 F
Bar. Press. "Hg. 28.92
Assumed Moist 109%
Test Periods 24 to 26

Probe Tip Dia., In. 1/4"
Probe Length 6"
Imp. Nos. 13-16
Sample Box No. 2

Heater Box Setting
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.		Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack In. H ₂ O Press.
		AP	VP	Desired	Actual	Inlet	Outlet	Inlet	Outlet						
N-1	18:05	686.05	.17	.41	.47	.37	66	70	69	3.0	220	80	130	255	
N-2	20	650.27	.23	.48	.55	.49	66	69	69	3.0	230	81	140	359	
N-3	38	692.44	.27	.52	.60	.45	66	69	69	3.0	287	79	157	339	
N-4	45	694.69	.32	.52	.65	.49	66	70	70	3.0	293	82	217	368	
N-5	51	696.94	.42	.65	.75	.49	66	70	70	3.0	175	80	342	335	
N-6	57	699.55	.40	.63	.73	.49	67	72	72	4.0	250	80	380	327	
W-1	11:12	701.87	.22	.52	.60	.52	69	71	71	4.0	269	8x	18x	29x	
7	24	704.51	.23	.48	.55	.66	71	74	74	5.0	250	97	159	34x	
3	30	707.10	.30	.55	.63	.64	69	73	73	5.0	220	90	220	373	
4	36	709.72	.30	.55	.63	.67	67	71	71	6.0	212	82	201	3x1	
5	42	712.52	.38	.62	.71	.75	70	74	74	6.0	205	88	325	345	
6	48	715.49	.40	.63	.73	.85	70	75	75	6.0	231	88	342	337	4
S-1	12:22	717.80	.20	.45	.51	.51	67	69	69	4.0	375	81	95	342	
2	32	720.47	.36	.60	.69	.68	69	71	71	6.0	397	89	149	35x	
3	38	723.38	.43	.66	.75	.81	67	71	71	6.0	342	82	227	325	
4	44	726.01	.48	.69	.80	.71	69	74	74	6.5	307	82	290	322	
5	50	729.12	.54	.73	.86	.87	69	73	73	6.5	263	85	318	32x	
6	56	732.76	.52	.72	.83	.96	69	76	76	7.0	230	80	319	326	
E-1	13:14	734.55	.57	.72	.80	.49	80	83	83	7.0	335	94	159	314	
2	26	737.42	.49	.70	.81	.79	80	86	86	7.0	290	100	182	352	
3	32	740.45	.53	.73	.84	.88	81	86	86	7.0	223	97	200	335	
4	38	743.40	.50	.71	.81	.83	82	86	86	7.0	242	93	274	331	
5	44	746.42	.61	.78	.96	.89	84	88	88	7.0	250	110	321	332	
6	50	749.44	.61	.78	.90	.89	85	89	89	7.0	280	98	329	354	
TOTAL															
AVERAGE															

Post Check O.K.

CORRECTED SAMPLE VOLUME = 537 Meter Volume
Ft. 3 x 1.052 Dry Meter Calibration Factor
66.69 Ft. 3

PARTICULATE & WATER CATCH

RUN NO. 4

WATER WEIGHT GAIN

Final Weight 722.17
Initial Weight 544.11
Increase

IMPINGER NO. 13

Final Weight 568.89
Initial Weight 562.58
Increase

IMPINGER NO. 14

Final Weight 463.43
Initial Weight 462.91
Increase

IMPINGER NO. 15

Final Weight 787.84
Initial Weight 770.58
Increase

IMPINGER NO. 16

Final Weight 2288
Initial Weight 1760
Part. Catch

FILTER NO. 6

SOLID WEIGHT GAIN

Final Weight 117.7094
Initial Weight 117.5752
Increase 1342

BEAKER NO. 21

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 145.9239
Initial Weight 145.8750
Increase 0489

BEAKER NO. 28
PROBE WASH

Moisture Content: Sample Vol. 6.39 ft.³ x 460 + 70 = 2935 Temp.
x 28.3 L/ft.³ = 1861 L Dry Gas

Water Weight 202.15 gm. x 24.1 L = 270.6 L H₂O Vapor
18 gm. mol.

Total = 2132
H₂O Vol. 271 L x 100 = 12.7%
Total 2132

ORSAT

CO₂ 10.0
O₂ 15.4

CO
N₂ 74.6
28.66

BEAKER 4 00.88
BEAKER 3 04.89
BEAKER 2 05.97
BEAKER 1 1342

TOTAL 1919

PARTICULATE FIELD DATA

Run No. 5
 Location Mo. S. & L. Stock
 Date 7/25/75
 Operator CO. J. H. H.
 Amb. Temp. °F 71° F
 Bar. Press. "Hg. 28.84
 Assumed Moist 1.2%
 Test Periods 24 @ 6 min
 Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos. 12-20
 Sample Box No. 1
 Heater Box Setting 250
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock	Dry Gas Meter C.F.	Pitot In. H ₂ O	Orifice ΔH		Dry Gas Temp.		Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
				Desired	Actual	Inlet	Outlet						
W-1	18:44	399.13	AP .32	33	33	72	74	0	286	77	158	328	
2	56	407.98	.16	47	38	71	75	1.0	237	87	148	374	
3	11:01	405.30	.20	47	51	70	74	1.0	259	90	222	326	
4	8	407.50	.21	48	46	73	77	1.5	289	88	293	325	
5	14	409.80	.21	48	51	75	79	1.5	258	89	310	328	
6	20	412.12	.23	50	52	74	79	1.5	240	88	321	315	
U-1	11:25	414.04	.12	36	35	78	81	1.5	252	95	181	306	
2	41	416.13	.18	44	42	78	82	1.5	251	97	245	378	
3	47	418.31	.21	48	46	78	78	2.0	314	92	225	330	
4	53	420.56	.23	48	49	80	84	2.0	301	98	235	333	
5	59	422.90	.24	49	51	77	77	2.0	253	87	305	331	
6	12:05	425.13	.24	49	48	71	75	2.0	222	84	321	327	0.55
E-1	12:28	427.07	.12	35	36	78	81	2.0	320	97	200	338	
2	34	429.21	.20	45	44	74	76	2.0	329	91	215	346	
3	40	431.45	.22	47	48	74	77	2.0	304	92	237	347	
4	46	433.74	.23	48	50	78	81	2.0	302	98	269	350	
5	52	436.04	.23	48	50	75	78	2.0	243	92	316	348	
6	58	438.36	.24	49	51	71	75	2.0	209	83	333	347	
S-1	13:03	440.25	.10	32	32	72	76	2.0	273	80	173	344	
2	20	442.35	.18	42	42	84	88	2.0	255	95	217	392	
3	26	444.57	.18	42	45	78	82	2.0	207	91	170	382	
4	32	446.63	.20	45	47	85	88	2.0	247	98	287	385	
5	38	448.07	.27	52	55	77	81	2.0	254	90	375	370	
6	44	451.50	.30	55	59	77	81	2.0	207	90	369	356	
TOTAL													
AVERAGE													

Meter Volume 538
 Dry Meter Calibration Factor 0.977
 CORRECTED SAMPLE VOLUME 519

RUN NO. 5
PARTICULATE & WATER CATCH

Final Weight 729.81
Initial Weight 555.66
Increase

IMPINGER NO. 17

Final Weight 518.13
Initial Weight 550.43
Increase

IMPINGER NO. 18

Final Weight 462.15
Initial Weight 460.98
Increase

IMPINGER NO. 19

Final Weight 822.34
Initial Weight 806.59
Increase

IMPINGER NO. 20

Final Weight 842.1
Initial Weight 780.7
Part. Catch

FILTER NO. 7

Final Weight 135.5230
Initial Weight 135.4855
Increase

BEAKER NO. 1

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 154.2094
Initial Weight 134.1471
Increase .0623

BEAKER NO. 40
PROBE WASH

530
460 + Meter
538 Temp.

212.6
24.1 L
mol.

Water Weight 158.13
18 gm.
mol.

530
460 + Meter
538 Temp.

Total = 1637

H₂O Vol. 212.6
Total = 13.0
x 100 = 13.0

ORSAT TOTAL 158.77

IMPINGER 4 15.75

IMPINGER 3 1.17

IMPINGER 2 -32.3

IMPINGER 1 174.15

CO₂ 9.6

CO -

N₂ 75.4

BEAKER 4 0.0614
BEAKER 4 0.0623

BEAKER 4 0.0375

BEAKER 4

TOTAL 1612

BBB

6905 223

6

Amb. Temp. °F 71°F

Location Ho. S. Kiln Shop

Bar. Press. 116. ~~217~~ 28.84

Date 7/25/15

Assumed Moist

Operator 60520575

Test Periods

706. 14x

1

1.04

SCORE OF EACH TEST
POINT

Heater Box Setting 250

FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp.		Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In.	H ₂ O	Desired	Actual	Inlet	Outlet						
5-1	11:47	750.48	AP	VP										
2	53	752.31	.14	.37	39	.32	71	73	0	240	85	100	341	
3	59	754.60	.21	.46	.48	.50	72	76	0	272	92	153	349	
4	11:05	756.94	.23	.48	.50	.52	75	79	0	286	93	234	352	
5	11	758.28	.24	.49	.51	.52	69	74	0	216	80	315	325	
6	17	761.69	.26	.51	.53	.56	74	82	0	262	93	330	334	
7-1	23	764.18	.27	.52	.54	.59	72	78	0	228	89	325	330	
2	11:38	766.13	.13	.36	.37	.36	75	78	0	286	93	186	313	
3	44	768.22	.15	.39	.40	.42	72	81	0	219	96	216	318	
4	50	770.43	.25	.50	.52	.47	71	75	0	195	91	267	333	
5	56	772.83	.27	.52	.54	.35	70	75	0	212	88	290	330	
6	12:02	775.33	.27	.52	.54	.60	71	76	0	246	87	307	328	0.62
7-1	08	777.63	.27	.52	.54	.51	69	78	0	231	93	326	338	
2	12:25	779.72	.13	.36	.37	.42	76	78	0	320	92	162	320	
3	37	781.82	.18	.42	.44	.42	72	76	0	201	87	202	332	
4	43	783.97	.22	.47	.49	.44	72	75	0	260	86	209	342	
5	49	786.37	.22	.47	.49	.35	78	81	0	245	92	243	345	
6	55	788.60	.23	.48	.50	.48	78	81	0	202	90	286	349	
7-1	13:01	790.90	.23	.48	.50	.51	71	76	0	193	75	310	356	
2	13:14	792.80	.10	.32	.33	.35	83	85	0	278	89	182	346	
3	23	794.71	.15	.39	.40	.35	82	85	0	237	92	160	384	
4	29	796.75	.16	.40	.42	.40	85	89	0	227	97	180	392	
5	35	798.47	.20	.45	.47	.47	83	85	0	262	90	307	384	
6	41	801.28	.23	.48	.50	.51	76	79	0	227	86	318	364	
7	48	803.79	.26	.51	.53	.60	82	84	0	256	92	337	369	
TOTAL				.45									375	
AVERAGE							.49	75					306	

Post Jack Quast Shows for -

53

Meter Volume

CORRECTED SAMPLE VOLUME =

三

3

Dry Meter Calibration Factor

3
F
2
8
D

RUN NO. 6

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 609.56
Initial Weight 538.07
Increase

IMPINGER NO. 21

Final Weight 549.31
Initial Weight 541.91
Increase

IMPINGER NO. 22

Final Weight 457.86
Initial Weight 456.91
Increase

IMPINGER NO. 23

Final Weight 817.3x
Initial Weight 800.40
Increase

IMPINGER NO. 24

Final Weight 794.6
Initial Weight 786.3
Part. Catch

FILTER NO. 8

Final Weight 157.3848
Initial Weight 157.3460
Increase

BEAKER NO. 35

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 147.0458
Initial Weight 147.0117
Increase

BEAKER NO. 32
PROBE WASH

460 + Meter
537 Temp.

129.5 = 24.1 L H₂O Vapor
mol.

Water Weight 96.72
18 gm.
mol.

Sample Vol. 56.08 ft.³ x 28.3 L/ft.³ = 1566 L Dry Gas

Total = 1696

H₂O Vol. 129.5 L
Total = 1696
x 100 = 7.6%

TOTAL 0812

BEAKER 4

BEAKER 35 0388

BEAKER 32 0424

BEAKER 31 0341
BEAKER 30 0683

N₂ 75.4
29.21

CO -

O₂ 15.0

CO₂ 9.6

ORSAT

TOTAL 96.72

IMPINGER 4 16.94

IMPINGER 3 0.89

IMPINGER 2 7.4

IMPINGER 1 71.49

BRUCE PARTICULATE FIELD DATA 71.8°F WB

Run No. 7
Location Field No 5 Stock
Date 7/26/79
Operator W.C. 18

Amb. Temp. °F 73.0 F
Bar. Press. "Hg. 28.71
Assumed Moist 12.9%
Test Periods 24 @ 6 min
144 min

Probe Tip Dia., In. 1/4"
Probe Length 8'
Inp. Nos. 25 - 28
Sample Box No. 1

Heater Box Setting 250
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In. H ₂ O	ΔP	Desired In. H ₂ O	Actual	Inlet	Outlet						
S-1	48	454.71	.48	.69	.66	.64	74	74	0	200	73	160	344	
2	54	457.57	.77	.88	.83	.78	68	71	0	213	74	122	355	
3	9:00	460.58	.95	.97	.93	.86	71	73	0	275	75	230	362	
4	6	463.75	.98	.99	.94	.96	72	75	1.5	207	78	340	355	
5	12	467.05	.95	.97	.93	1.04	71	74	2.0	236	78	355	356	
6	18	470.25	.98	.99	.94	1.04	72	75	2.0	247	78	353	348	
E-1	24	472.81	.48	.69	.66	.63	70	72	0.5	253	75	144	337	
2	30	475.64	.75	.87	.82	.77	72	74	1.0	314	82	222	350	
3	36	478.70	.87	.93	.89	.90	71	74	1.5	304	80	309	351	
4	42	481.85	.90	.95	.90	.95	70	74	2.0	237	78	328	352	
5	48	484.81	.95	.97	.93	.84	72	77	2.0	182	79	347	350	
6	54	488.08	.95	.97	.93	1.04	72	77	2.5	205	80	346	350	462
D-1	10:00	490.43	.53	.57	.55	.53	69	71	1.0	310	73	147	314	
2	10:06	493.09	.63	.79	.75	.68	70	73	1.5	249	78	178	343	
3	10:12	495.93	.68	.82	.78	.77	72	75	2.0	214	78	227	346	
4	10:18	498.82	.73	.85	.81	.80	73	77	2.0	272	81	279	348	
5	10:24	501.78	.82	.91	.86	.84	71	76	2.0	235	75	325	345	
6	10:30	504.83	.82	.91	.86	.89	74	78	2.0	209	84	338	346	
U-1	11:00	507.29	.41	.64	.61	.58	69	71	1.5	320	72	143	335	
2	11:06	510.07	.68	.82	.78	.74	71	73	1.5	259	75	143	346	
3	11:12	513.07	.76	.87	.83	.86	72	75	2.5	285	79	237	347	
4	11:18	516.25	.83	.91	.87	.97	74	78	4.0	256	82	200	347	
5	11:24	519.25	.92	.96	.91	.96	73	77	4.5	213	83	330	347	
6	11:30	522.28	.92	.96	.91	.96	75	79	4.5	249	86	336	337	
TOTAL							72	75					348	
AVERAGE							82	75					308	

Meter Volume 15 Dry Meter Calibration Factor 68.13

RUN NO. 7

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 736.40
Initial Weight 554.94
Increase

IMPINGER NO. 25

Final Weight 599.53
Initial Weight 544.78
Increase

IMPINGER NO. 26

Final Weight 459.74
Initial Weight 457.43
Increase

IMPINGER NO. 27

Final Weight 787.65
Initial Weight 761.88
Increase

IMPINGER NO. 28

Final Weight 8053
Initial Weight 7310
Part. Catch

FILTER NO. 29

Final Weight 144.6148
Initial Weight 144.4551
Increase

BEAKER NO. 30

Final Weight
Initial Weight
Increase

BEAKER NO. 31

Final Weight
Initial Weight
Increase

BEAKER NO. 32

Final Weight 142.9775
Initial Weight 142.9094
Increase

BEAKER NO. 33
PROBE WASH

Moisture Content: Sample Vol. 68.43 L x 28.3 L/ft.³ = 1922 Dry Gas

Water Weight 27.45 gm. x 24.1 L = 200.29 L H₂O Vapor

H₂O Vol. 200.29 L x 100 = 13.5% Total

Total = 2222

460 + Meter
534 Temp.

TOTAL 3025

BEAKER 3 1597

BEAKER 2 1428
BEAKER 1 0685
BEAKER 4 0743

N₂ 74.2

CO -

O₂ 14.4

CO₂ 11.4

ORSAT

TOTAL 224.29

IMPINGER 4 25.77

IMPINGER 3 2.31

IMPINGER 2 14.75

IMPINGER 1 18.46

50B PARTICULATE FIELD DATA 71°F WB

Run No. 8
 Location K-6-165 Stock
 Date 2/26/75
 Operator CEJED B

Amb. Temp. °F 73.0
 Bar. Press. "Hg. 28.71
 Assumed Moist
 Test Periods 144 mi Tot.

Probe Tip Dia., In. 1/4"
 Probe Length 29-32
 Imp. Nos. 2
 Sample Box No. 7-95

Heater Box Setting 250
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST POINT

Point	Clock	Dry Gas Meter C.F.	Pitot, In. H ₂ O	Orifice In. H ₂ O	ΔH	Dry Gas Temp. °F	Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O	
	8:45	804.97	AP	VAP	Desired	Actual	Inlet	Outlet					
U-1	51	807.44	.40	.63	.60	.59	74	75	0	272	81	180	376
2	57	810.18	.68	.82	.78	.72	73	74	0	236	80	141	359
3	9:03	812.12	.82	.91	.86	.81	72	74	0	218	77	165	356
4	9	816.45	.77	.88	.83	1.06	72	76	1.0	272	78	317	355
5	15	819.62	.88	.94	.89	.84	71	76	1.0	240	75	342	355
6	21	822.81	.88	.94	.89	.84	70	76	1.0	225	75	350	354
S-1	27	825.06	.50	.71	.67	.62	71	73	1.0	195	76	161	346
2	47	827.84	.75	.87	.82	.74	69	72	0	252	75	187	350
3	53	830.97	.87	.93	.89	.84	70	75	1.0	292	77	280	349
4	59	834.19	.93	.96	.92	.89	69	75	1.0	218	74	317	348
5	10:05	837.19	.93	.96	.92	.86	69	76	1.0	220	74	335	347
6	11	840.19	.90	.95	.90	.86	73	74	1.0	208	82	345	348
E-1	10:35	842.75	.48	.69	.66	.63	70	73	0	276	75	158	337
2	37	845.57	.70	.84	.80	.76	70	74	1.0	233	80	224	342
3	43	848.69	.85	.92	.88	.83	71	75	1.5	214	83	311	343
4	49	851.89	.90	.95	.90	.88	70	76	1.5	240	77	324	342
5	55	855.01	.92	.96	.91	.89	70	77	1.5	278	78	338	344
6	11:01	858.07	.87	.93	.89	.84	70	77	1.5	248	78	342	344
N-1	11:26	860.56	.40	.63	.60	.59	71	73	1.5	255	72	211	335
7	26	863.17	.56	.75	.71	.65	75	78	1.5	201	80	175	342
3	32	865.94	.65	.81	.76	.74	71	75	1.5	253	75	274	340
4	38	868.98	.73	.85	.81	.89	76	76	1.5	281	75	302	338
5	44	871.25	.81	.90	.86	.84	71	77	1.5	244	77	322	337
6	50	875.03	.90	.95	.90	1.03	70	75	1.5	225	75	320	334
TOTAL							71	75					347
AVERAGE							71	75					347

Meter Volume 6 t. 3
 Dry Meter Calibration Factor 1.02
 73.71

RUN NO. 8

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 745.65
Initial Weight 573.17
Increase

IMPINGER NO. 25

Final Weight 564.71
Initial Weight 541.08
Increase

IMPINGER NO. 30

Final Weight 479.00
Initial Weight 475.74
Increase

IMPINGER NO. 31

Final Weight 837.33
Initial Weight 803.97
Increase

IMPINGER NO. 32

Final Weight 7594
Initial Weight 7290
Part. Catch

FILTER NO. 28

SOLID WEIGHT GAIN
0.0304
7290

Final Weight 140.5254
Initial Weight 140.3494
Increase 0.1760

BEAKER NO. 7

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 140.4866
Initial Weight 144.3615
Increase

BEAKER NO. 29
PROBE WASH

460 + Meter
533 Temp.

Water Weight 232.73 gm.
18 gm.
mol. = 311.59
x 24.1 L
H₂O Vapor

mol.

Moisture Content: Sample Vol. 73.71 ft.³ x 460 + 70
x 28.3 L/ft.³ = 2074 L Dry Gas

Total = 2385 L

H₂O Vol. 311.59 L
Total = 2385
x 100 = 13.06

ORSAT

TOTAL 232.73

IMPINGER 4 33.36

IMPINGER 3 3.26

IMPINGER 2 23.63

IMPINGER 1 172.48

TOTAL 2345

BEAKER 4

BEAKER 3 1760

BEAKER 2 0585

BEAKER 1 0281

0.0304

78.71

N₂

74.2

CO

—

O₂

14.4

CO₂

11.4

PARTICULATE FIELD DATA

Run No. 15
 Location STACK #5
 Date 8/18/79
 Operator CHU/BRUCE

Amb. Temp. °F 61.68
 Bar. Press. "Hg. 28.83"
 Assumed Moist 12%
 Test Periods 144 MIN.

Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos.
 Sample Box No.

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	In. H ₂ O	Desired	Actual	Inlet	Outlet					
S-1	7:55/60	805.32	0.21	0.46	0.33	0.28	68	68	0.0	260	70	121	321	
2	07	807.00	0.32	0.57	0.51	0.50	68	69	0.5	260	74	139	332	
3	13	811.67	0.42	0.63	0.63	0.59	68	69	2.0	252	71	175	338	
4	19	814.31	0.42	0.65	0.67	0.70	66	69	3.0	244	68	221	337	
5	25	816.94	0.43	0.66	0.68	0.70	67	71	3.0	284	72	305	337	
6	31	819.57	0.44	0.66	0.70	0.70	67	71	3.0	243	69	325	334	
W-1	8:40/46	821.33	0.19	0.44	0.30	0.31	67	69	0.0	224	69	178	307	
2	52	823.43	0.30	0.55	0.48	0.44	68	71	1.0	273	70	178	325	+0.50
3	58	825.87	0.36	0.60	0.57	0.60	68	72	3.0	247	73	178	345	
4	9:04	828.33	0.38	0.62	0.60	0.61	67	70	3.0	248	70	256	332	
5	10	830.79	0.39	0.62	0.61	0.61	68	72	3.5	261	73	311	333	
6	16	833.39	0.44	0.66	0.70	0.68	68	72	4.0	242	75	341	333	
N-1	9:24/30	835.30	0.23	0.48	0.36	0.37	74	77	1.0	218	70	165	323	
2	36	837.62	0.37	0.61	0.58	0.54	74	78	3.0	259	73	162	328	
3	42	840.10	0.40	0.63	0.63	0.62	75	79	4.0	230	75	169	345	
4	48	842.78	0.47	0.69	0.74	0.72	74	78	4.0	260	73	258	343	
5	54	845.53	0.48	0.69	0.75	0.76	72	82	5.0	247	76	245	341	
6	10:00	848.35	0.50	0.71	0.79	0.80	75	79	5.5	277	72	335	336	
E-1	10:17/23	850.17	0.21	0.46	0.33	0.33	77	78	1.0	218	72	198	328	
2	29	852.48	0.36	0.60	0.57	0.64	76	77	4.0	273	75	196	334	
3	35	854.95	0.41	0.64	0.64	0.61	78	80	5.0	248	81	203	344	
4	41	857.57	0.46	0.68	0.72	0.69	78	82	5.0	264	82	283	346	
5	47	860.28	0.47	0.69	0.74	0.74	78	81	6.0	241	80	325	350	
6	53	863.07	0.48	0.69	0.75	0.78	76	82	6.0	282	79	330	343	
TOTAL							1720	1773						
AVERAGE		57.75			0.612	0.600	0.593	71.7	73.88				335	

533.8

72.8

Dry Meter Calibration Factor

198.8

RUN NO. 15

PARTICULATE & WATER CATCH

Final Weight 680.29
Initial Weight 540.42
Increase

IMPINGER NO. 21

Final Weight 552.11
Initial Weight 549.41
Increase

IMPINGER NO. 62

Final Weight 443.03
Initial Weight 441.86
Increase

IMPINGER NO. 23

Final Weight 332.65
Initial Weight 816.90
Increase

IMPINGER NO. 64

Final Weight 7990
Initial Weight 7770
Part. Catch

FILTER NO. 9

Final Weight 141.753
Initial Weight 141.0291
Increase

BEAKER NO. 38
Imp.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 121.6172
Initial Weight 121.5501
Increase

BEAKER NO. 9
PROBE WASH

530
460 + Meter
533 Temp.

Moisture Content: Sample Vol. 57.55 ft.³ x 460 + 70
X 28.3 L/ft.³ = 1625.7 L Dry Gas

Water Weight 164.49 gm. x 24.1 L = 220.2 L H₂O Vapor
18 gm. mol.

Total = 1844.9 L
H₂O Vol. 220.2 L x 100 = 11.9 %
Total 1844.9 L

PARTICULATE FIELD DATA

Run No. 16
 Location STMC
 Date 8/18/79
 Operator CHU/BGB

Amb. Temp. °F 61.88
 Bar. Press. "Hg. 28.83"
 Assumed Moist 12%
 Test Periods 1944/1/14

Probe Tip Dia. In 1/8"
 Probe Length 8'
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg. Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	Desired	Actual	Inlet	Outlet						
N-1	7:58/8:04	123.64	0.27	0.52	0.43	0.39	68	69	0.0	243	69	169	335	
2	10	126.22	0.42	0.65	0.67	0.67	67	69	1.0	248	70	182	340	
3	16	128.98	0.50	0.71	0.79	0.77	65	68	1.5	237	69	206	340	
4	22	131.88	0.51	0.71	0.81	0.85	65	70	2.0	246	69	207	335	
5	28	134.81	0.53	0.73	0.84	0.86	66	72	2.0	260	65	308	340	
6	34	137.72	0.53	0.71	0.84	0.85	65	73	2.0	249	70	329	339	
E-1	8:03/09	139.81	0.25	0.50	0.40	0.44	65	69	0.0	252	65	218	322	
2	55	142.41	0.42	0.65	0.67	0.68	65	74	1.5	254	70	215	333	
3	9:01	145.17	0.46	0.68	0.73	0.77	65	71	2.0	245	68	213	336	
4	07	147.87	0.45	0.67	0.71	0.73	66	73	2.0	245	72	285	337	10.51
5	13	150.64	0.48	0.69	0.75	0.77	66	73	2.5	250	71	311	334	
6	19	153.41	0.50	0.71	0.79	0.77	69	76	2.5	240	77	329	343	
5-1	9:27/33	155.52	0.24	0.49	0.38	0.45	73	77	1.0	261	75	231	329	
2	39	157.87	0.35	0.59	0.55	0.55	73	77	2.0	253	72	184	339	
3	45	160.31	0.38	0.62	0.60	0.60	74	79	2.0	255	74	206	346	
4	51	162.98	0.42	0.65	0.66	0.72	73	79	2.5	236	73	289	343	
5	57	165.74	0.48	0.69	0.75	0.77	72	78	3.0	250	77	312	337	
6	10:03	168.48	0.48	0.69	0.75	0.75	71	78	3.0	281	72	326	333	
N-1	10:20/26	170.41	0.20	0.45	0.31	0.37	98	80	1.5	290	79	142	324	
2	32	172.65	0.32	0.57	0.50	0.51	76	79	2.0	241	74	127	338	
3	38	175.00	0.35	0.59	0.55	0.55	77	81	2.5	244	75	175	344	
4	44	177.50	0.40	0.63	0.63	0.63	76	80	2.5	256	75	277	344	
5	50	180.07	0.42	0.65	0.66	0.66	74	79	3.0	268	72	315	342	
6	56	182.83	0.48	0.69	0.75	0.77	74	80	3.0	237	73	335	346	
TOTAL														
AVERAGE		6.115	0.635	0.647	0.662	0.662	70.2	75.04					337.5	

5330R

72.6 Meter Volume

Dry Meter Calibration Factor

297.5R

CO TEL

PL

1.6

7

F

RUN NO. 15

PARTICULATE & WATER CATCH

Final Weight 734.59
Initial Weight 623.63
Increase 110.96
WATER WEIGHT GAIN

IMPINGER 1 210.96

Final Weight 514.23
Initial Weight 550.51
Increase 36.28
IMPINGER 2

IMPINGER 3 1.12

Final Weight 445.08
Initial Weight 444.66
Increase 0.42
IMPINGER 4

IMPINGER 4 18.66

TOTAL 194.96
ORSAT

Final Weight 807.18
Initial Weight 788.52
Increase 18.66
IMPINGER

CO₂ 11.2

Final Weight 763.1
Initial Weight 730.0
Part. Catch 33.1
IMPINGER

O₂ 14.4

SOLID WEIGHT GAIN 33.1

Final Weight 140.5890
Initial Weight 140.5757
Increase 0.0133
BEAKER

BEAKER 6 0.175

BEAKER 3 0.113

Final Weight
Initial Weight
Increase
BEAKER

BEAKER 4

Final Weight
Initial Weight
Increase
BEAKER

Net TOTAL 0.619

Final Weight 144.6153
Initial Weight 144.5978
Increase 0.0175
BEAKER

Moisture Content: Sample Vol. 61.50 ft.³ x 460 + 70 = 28.3 L/ft.³ = 1730.7 L Dry Gas
460 + Meter
530 Temp.

Water Weight 194.46 gm. x 24.1 L = 260.42 H₂O Vapor
18 gm.
mol.

H₂O Vol. 260.4 L x 100 = 13.1%
Total 199.0 L

PARTICULATE FIELD DATA

Run No. 17
 Location STACK
 Date 8/24/79
 Operator CHU/BLUCE

Amb. Temp. °F 65.08
 Bar. Press. "Hg. 29.81"
 Assumed Moist 12%
 Test Periods 198 MIN

Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In. H ₂ O	√ΔP	In. H ₂ O	Desired	Inlet	Outlet						
ND-1	8:24/30	871.43	0.19	0.44	0.33	0.34	69	69	0.0	271	64	225	314	
2	86	872.93	0.14	0.37	0.25	0.25	71	71	0.0	250	67	219	316	
3	42	874.10	0.09	0.30	0.16	0.15	71	71	0.0	265	78	186	315	
4	48	875.15	0.07	0.26	0.12	0.12	74	75	0.0	237	80	212	316	
5	55	876.36	0.07	0.26	0.12	0.12	75	81	0.0	260	82	268	314	
6	9:00	877.37	0.09	0.30	0.16	0.16	79	81	0.0	260	82	303	345	
7	9:11/12	878.06	0.03	0.17	0.05	0.05	84	84	0.0	289	80	169	297	+0.36
8	23	879.00	0.05	0.22	0.09	0.10	86	87	0.0	255	79	151	324	
9	29	879.99	0.06	0.25	0.11	0.11	87	83	0.0	267	88	175	318	
10	35	881.10	0.07	0.26	0.12	0.14	84	86	0.0	245	82	228	329	
11	41	882.28	0.08	0.28	0.14	0.15	85	87	0.0	269	85	291	329	
12	47	883.46	0.11	0.33	0.20	0.15	92	83	0.0	262	81	310	321	
13	54	884.35	0.05	0.22	0.09	0.09	83	82	0.0	309	76	127	307	
14	10:02/08	885.02	0.03	0.17	0.05	0.05	84	85	0.0	268	80	130	299	
15	20	885.68	0.03	0.17	0.05	0.05	71	76	0.0	243	80	128	295	
16	26	886.32	0.03	0.17	0.05	0.05	75	76	0.0	244	80	166	302	
17	32	887.23	0.05	0.22	0.09	0.09	73	75	0.0	233	76	245	308	
18	38	888.27	0.06	0.25	0.11	0.12	77	76	0.0	250	77	283	311	
19	10:52/58	888.90	0.03	0.17	0.05	0.05	80	82	0.0	221	82	129	261	
20	11:04	889.71	0.04	0.20	0.07	0.07	80	81	0.0	238	81	195	308	
21	10	890.74	0.06	0.25	0.11	0.12	75	76	0.0	244	81	151	309	
22	16	891.68	0.05	0.22	0.09	0.10	82	82	0.0	260	81	209	319	
23	22	892.61	0.05	0.22	0.09	0.10	76	79	0.0	250	75	263	305	
24	28	893.67	0.07	0.26	0.12	0.12	83	85	0.0	243	82	291	315	
TOTAL	144						1870	1914					7947	
AVERAGE	6			0.248	0.118	0.118	77.9	79.8					310.3	

10:40 power off PRT
 10:50 power on PRT
 539°R 78.8
 Meter Volume 0.10
 Dry Meter Calibration Factor 770.3°R
 23.95 ft.

RUN NO. 17
PARTICULATE & WATER CATCH

Final Weight 61.87
Initial Weight 56.89
Increase 4.98
51.41
464.12

Final Weight 510.59
Initial Weight 464.53
Increase 46
47
464.06

Final Weight 791.87
Initial Weight 782.14
Increase 9.73
7864

Final Weight 141.0835
Initial Weight 141.0051
Increase 0.0788
0.0788

Final Weight 148.4473
Initial Weight 143.14
Increase 5.30
539 Temp.

Final Weight 148.4473
Initial Weight 143.14
Increase 5.30
539 Temp.

Final Weight 148.4473
Initial Weight 143.14
Increase 5.30
539 Temp.

Final Weight 148.4473
Initial Weight 143.14
Increase 5.30
539 Temp.

Final Weight 148.4473
Initial Weight 143.14
Increase 5.30
539 Temp.

IMPINGER NO. 65

IMPINGER NO. 66

IMPINGER NO. 67

IMPINGER NO. 68

FILTER NO. 10

BEAKER NO. 5

BEAKER NO. 6

BEAKER NO. 7

BEAKER NO. 8
PROBE WASH

Water Weight 56.87 gm.
18 gm.
mol.

mol. = 24.1 L
26.1 L H₂O Vapor

IMPINGER 1 45.82

IMPINGER 2 0.82

IMPINGER 3 0.47

IMPINGER 4 9.73

TOTAL 56.82

CO₂ 9.2

O₂ 15.4

CO -

N₂ 75.4

BEAKER 1 0.074

BEAKER 2 0.155

BEAKER 3 0.233

BEAKER 4 0.788

TOTAL 1.021

Moisture Content: Sample Vol. 23.93 ft.³ x 28.3 L/ft.³ = 665.9 L Dry Gas

Moisture Content: Sample Vol. 23.93 ft.³ x 28.3 L/ft.³ = 665.9 L Dry Gas

Total = 742.01 L

H₂O Vol. 76.1 L
Total 742.01 L
% = 10.3

PARTICULATE FIELD DATA

Run No. 18
 Location STK
 Date 8/22/79
 Operator CFA/BAB

Amb. Temp. °F 65-68
 Bar. Press. "Hg. 28.81"
 Assumed Moist 12%
 Test Periods 144 M/A

Probe Tip Dia., In. 1/4"
 Probe Length 81
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP In. H ₂ O	√AP	Desired In. H ₂ O	Actual	Inlet	Outlet						
1-1	8:27/33	191.68	0.20	0.45	0.31	0.28	76	78	0.0	261	25	181	290	
2	34	193.07	0.09	0.30	0.14	0.19	70	72	0.0	270	26	192	203	
3	45	193.87	0.06	0.25	0.09	0.06	76	77	0.0	253	26	180	319	
4	51	194.88	0.07	0.26	0.11	0.10	80	82	0.0	289	82	202	314	
5	57	195.90	0.07	0.26	0.11	0.15	75	76	0.0	240	86	205	311	
6	9:03	197.14	0.09	0.30	0.14	0.15	77	79	0.0	258	86	269	319	
1-1	9:14/20	198.03	0.05	0.22	0.08	0.08	81	82	0.0	258	80	230	293	
2	26	199.11	0.07	0.26	0.11	0.11	84	85	0.0	238	78	172	310	
3	32	200.30	0.08	0.28	0.13	0.14	81	83	0.0	268	80	174	317	+0.36
4	38	201.43	0.08	0.28	0.13	0.12	85	85	0.0	245	80	245	326	
5	44	202.68	0.09	0.30	0.14	0.15	77	84	0.0	278	87	269	315	
6	50	203.78	0.09	0.30	0.14	0.12	76	78	0.0	242	80	202	311	
1-1	10:01/11	204.70	0.05	0.22	0.08	0.08	79	79	0.0	242	82	170	240	
2	17	205.38	0.04	0.20	0.06	0.06	75	75	0.0	271	80	158	250	
3	23	206.17	0.03	0.17	0.05	0.06	75	75	0.0	242	78	150	298	
4	29	207.12	0.06	0.25	0.09	0.09	71	72	0.0	258	70	196	302	
5	35	208.22	0.07	0.26	0.11	0.12	75	76	0.0	232	75	232	310	
6	41	209.31	0.07	0.26	0.11	0.11	71	74	0.0	270	75	269	306	
1-1	10:54/14	209.96	0.03	0.17	0.05	0.04	82	82	0.0	278	75	171	293	
2	07	210.83	0.04	0.20	0.08	0.07	76	79	0.0	200	80	144	301	
3	13	211.96	0.06	0.25	0.09	0.12	72	74	0.0	215	77	146	306	
4	19	212.82	0.05	0.22	0.08	0.07	78	75	0.0	247	85	202	304	
5	25	213.78	0.05	0.22	0.08	0.09	79	79	0.0	230	82	249	309	
6	31	214.84	0.07	0.26	0.11	0.11	81	84	0.0	253	83	284	311	
TOTAL	144			6.14	2.62	2.60	1848	1883					7261	
AVERAGE	6			0.256	0.109	0.108	77	78.5					302.5	

10:40 Power off PPR
 10:50 Power off PPR

5377°C 77.7 Meter Volume 284.98
 CORRECTED SAMPLE VOLUME 284.98
 Dry Meter Calibration Factor 762.50°C

RUN NO. 18
PARTICULATE & WATER CATCH

Final Weight 561.30
Initial Weight 533.48
Increase 27.82

Final Weight 515.47
Initial Weight 476.71
Increase 38.76

Final Weight 515.09
Initial Weight 477.15
Increase 37.94

Final Weight 477.15
Initial Weight 472.05
Increase 5.10

Final Weight 812.95
Initial Weight 805.10
Increase 7.85

Final Weight 75.14
Initial Weight 78.26
Part. Catch -2.12

Final Weight 142.0810
Initial Weight 142.0331
Increase 0.0479

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

Final Weight 135.4480
Initial Weight 135.4212
Increase 0.0268

IMPINGER NO. 69

IMPINGER NO. 70

IMPINGER NO. 91

IMPINGER NO. 72

FILTER NO. 11

BEAKER NO. 15

BEAKER NO. 13

BEAKER NO. 14

BEAKER NO. 3

PROBE WASH

Water Weight 36.15 gm. x 24.1 L = 870.4 L H₂O Vapor

mol. 18 gm.

IMPINGER 1 27.82

IMPINGER 2 38

IMPINGER 3 10

IMPINGER 4 7.85

TOTAL 35.67

ORSAT

CO₂ 9.2

O₂ 25.4

CO 7.54

N₂ 7.54

BEAKER 3 0.268

BEAKER 2 0.352

BEAKER 1 0.475

Wet TOTAL 0.835

Final Weight 135.4480

Initial Weight 135.4212

Increase 0.0268

Moisture Content: Sample Vol. 25.02 ft.³ x 28.3 L/ft.³ = 697.5 L Dry Gas

460 + Meter 538 Temp.

Water Weight 36.15 gm. x 24.1 L = 870.4 L H₂O Vapor

mol. 18 gm.

Total 745.9 L

H₂O Vol. 48.4 L x 100 = 6.5%

PARTICULATE FIELD DATA

Run No. 19
 Location STARK
 Date 8/23/79
 Operator CHU/BRUCE

Amb. Temp. °F 69.28
 Bar. Press. "Hg. 28.80"
 Assumed Moist 12%
 Test Periods 144 MIN

Probe Tip Dia., In. 3/8"
 Probe Length 8'
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In.	ΔP	In. H ₂ O	Actual	Inlet	Outlet						
1-1	0:03:08	897.85	0.22	0.47	2.56	2.00	77	77	4.5	245	75	180	314	
2	0:05:08	902.11	0.22	0.47	2.56	2.00	76	76	7.0	285	74	157	313	
3	0:07:08	906.40	0.10	0.45	2.33	2.02	74	76	8.0	281	75	174	312	
4	0:09:08	910.51	0.13	0.36	1.51	1.86	76	79	7.0	284	78	234	309	
5	0:11:08	914.60	0.12	0.35	1.40	1.84	75	77	7.0	287	82	271	303	
6	0:13:08	918.43	0.14	0.37	1.63	1.61	80	90	6.0	285	90	295	303	
1-1	0:15:08	920.65	0.08	0.22	0.58	0.54	70	72	0.0	235	82	166	284	
2	0:17:08	922.89	0.08	0.28	0.93	0.83	68	69	2.0	274	75	136	291	10.38
3	0:19:08	926.35	0.08	0.28	0.93	0.83	69	76	2.5	234	82	120	297	
4	0:21:08	929.38	0.09	0.30	1.05	1.01	69	72	3.0	234	75	124	292	
5	0:23:08	932.75	0.12	0.35	1.40	1.25	69	72	4.0	253	74	172	285	
6	0:25:08	936.45	0.12	0.35	1.40	1.51	71	77	5.0	242	76	286	296	
1-1	0:27:08	939.14	0.07	0.26	0.81	0.80	70	72	0.0	257	76	263	296	
2	0:29:08	942.79	0.13	0.36	1.51	1.47	76	80	0.0	245	81	175	307	
3	0:31:08	946.57	0.14	0.37	1.63	1.57	80	83	0.0	242	87	181	307	
4	0:33:08	950.46	0.14	0.37	1.63	1.66	77	83	0.0	243	82	210	309	
5	0:35:08	954.24	0.14	0.37	1.63	1.57	79	85	0.0	209	86	232	314	
6	0:37:08	957.38	0.10	0.32	1.12	1.08	74	81	0.0	264	77	226	305	
1-1	0:39:08	959.67	0.05	0.22	0.58	0.50	71	72	2.0	251	70	171	257	
2	0:41:08	962.84	0.10	0.32	1.16	1.18	75	78	4.0	209	78	143	302	
3	0:43:08	966.35	0.12	0.35	1.40	1.36	76	77	5.0	242	75	184	312	
4	0:45:08	969.63	0.10	0.32	1.16	1.18	79	82	5.0	215	89	199	318	
5	0:47:08	973.15	0.13	0.36	1.51	1.36	74	80	5.5	238	82	278	312	
6	0:49:08	976.57	0.10	0.32	1.16	1.29	75	82	5.5	247	90	303	312	
TOTAL							1778	1872					7260	
AVERAGE							74.08	78.00					302.5	

536°K 76°C Meter Volume 36
 Dry Meter Calibration Factor 763°K

CO TESTED APPLICATION

8/23/79

0:00

0:00

0:00

0:00

PARTICULATE & WATER CATCH

RUN NO. 19

WATER WEIGHT GAIN

Final Weight 648.20
Initial Weight 540.49
Increase

IMPIINGER NO. 73

Final Weight 563.55
Initial Weight 540.67
Increase

IMPIINGER NO. 74

Final Weight 456.59
Initial Weight 451.33
Increase

IMPIINGER NO. 75

Final Weight 799.87
Initial Weight 768.68
Increase

IMPIINGER NO. 76

Final Weight 841.3
Initial Weight 781.5
Part. Catch

FILTER NO. 72

SOLID WEIGHT GAIN

Final Weight 137.6867
Initial Weight 137.5827
Increase 0.1040

BEAKER NO. 11

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 142.6074
Initial Weight 142.5865
Increase

BEAKER NO. 17
PROBE WASH

Moisture Content: Sample Vol. 82.08 ft.³ x 460 + 10 = 460 + Meter 536 Temp. 530

Water 174.18 gm.
Weight 174.18 gm. x 24.1 L = 233.2 L H₂O Vapor
mol.

H₂O Vol. 233.2 L
Total 2530.1 L
% 9.2 = 2530.1 L x 100 = 9.2 %

N₂ 77.0

CO -

O₂ 17.6

CO₂ 5.4

ORSAT

TOTAL 114.15

IMPIINGER 4 31.19

IMPIINGER 3 5.26

IMPIINGER 2 22.88

IMPIINGER 1 107.71

BEAKER 2 0.807

BEAKER 1 7.0229

BEAKER 3 0.598

BEAKER 14 1.640

TOTAL 184.7

PARTICULATE FIELD DATA

Run No. 20
 Location STACK
 Date 9/23/79
 Operator CHG/BOS

Amb. Temp. °F 69.08
 Bar. Press. "Hg. 28.80
 Assumed Moist 12%
 Test Periods 144

Probe Tip Dia., In. 3/8"
 Probe Length 8'
 Imp. Nos. 1
 Sample Box No. 144

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot.		Orifice ΔH		Dry Gas Temp.		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In. H ₂ O	√AP	Desired In. H ₂ O	Actual	Inlet	Outlet						
15-1	10:00/04	220.33	0.22	0.47	2.60	2.32	79	79	6.5	247	82	159	295	
2	10:02	225.83	0.35	0.59	4.13	2.90	85	85	9.0	200	82	163	317	
3	10:04	231.29	0.19	0.44	2.24	2.86	79	86	9.0	215	87	205	308	
4	10:06	236.74	0.14	0.37	1.65	2.85	80	89	9.5	243	87	210	309	
5	10:08	241.84	0.15	0.39	1.77	2.49	75	80	9.5	225	89	202	310	
6	10:10	244.79	0.15	0.39	1.77	0.83	72	77	2.0	233	86	277	307	
15-1	10:10/16	247.24	0.05	0.22	0.59	0.58	70	72	0.5	261	70	181	213	
2	10:12	249.38	0.06	0.24	0.71	0.72	73	74	2.0	269	80	220	284	+0.36
3	10:14	253.75	0.13	0.36	1.53	1.36	69	73	7.5	234	77	184	307	
4	10:16	257.73	0.12	0.35	1.42	1.52	72	80	4.0	283	80	284	286	
5	10:18	261.81	0.14	0.37	1.65	1.60	69	76	5.5	257	79	263	294	
6	10:20	265.91	0.14	0.38	1.65	1.61	71	78	4.5	222	71	280	286	
15-1	10:20/22	268.80	0.07	0.24	0.83	0.80	72	79	2.5	248	80	286	294	
2	10:24	272.62	0.12	0.35	1.42	1.40	73	79	3.5	250	85	180	296	
3	10:26	276.60	0.12	0.35	1.42	1.42	75	83	4.5	235	86	186	301	
4	10:28	280.67	0.13	0.36	1.53	1.59	70	78	5.0	264	81	258	301	
5	10:30	284.25	0.11	0.33	1.30	1.23	76	83	4.0	223	85	286	307	
6	10:32	287.89	0.11	0.33	1.30	1.27	68	78	4.5	267	80	295	302	
15-1	10:32/34	290.36	0.05	0.22	0.59	0.58	74	77	2.0	272	71	157	209	
2	10:34	293.38	0.08	0.28	0.94	0.87	78	82	3.0	278	85	168	266	
3	10:36	296.44	0.07	0.26	0.83	0.90	72	77	3.0	268	77	170	303	
4	10:38	299.73	0.09	0.30	1.06	1.04	74	85	3.5	232	88	212	319	
5	10:40	303.23	0.10	0.32	1.18	1.17	76	83	4.0	272	82	268	310	
6	10:42	306.95	0.10	0.32	1.18	1.26	83	86	4.0	276	85	294	314	
TOTAL													6992	
AVERAGE													291.3	

CO. TESTED. PLE. L.M. 537R 76.9 Meter Volume 94 t. 3 100.5 Dry Meter Calibration Factor 91.0

RUN NO. 20

PARTICULATE & WATER CATCH

Final Weight 588.18
Initial Weight 501.65
Increase 86.53
WATER WEIGHT GAIN

IMPINGER 1 26.63
IMPINGER 2 164.34
IMPINGER 3 5.33
IMPINGER 4 39.07
TOTAL 235.37
ORSAT

IMPINGER NO. 27

IMPINGER NO. 28

Final Weight 731.26
Initial Weight 566.92
Increase 164.34

IMPINGER NO. 29

Final Weight 461.80
Initial Weight 456.47
Increase 5.33

IMPINGER NO. 80

Final Weight 843.93
Initial Weight 804.86
Increase 39.07

FILTER NO. 13

Final Weight 984.5
Initial Weight 865.0
Part. Catch 119.5
SOLID WEIGHT GAIN

CO 77.0
N₂

BEAKER NO. 4

Final Weight 143.0340
Initial Weight 142.9120
Increase 0.1220

BEAKER 12 0523
BEAKER 2 11718
BEAKER 3
BEAKER 4 12220
TOTAL 2938

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO. 12
PROBE WASH

Final Weight 138.5669
Initial Weight 5142
Increase 0523

Moisture Content: Sample Vol. 91.96 ft. 3 x 460 + 70 = 460 + Meter
X 28.3 L/ft. 3 = 2668.5 L Dry Gas

Water Weight 25.37 gm.
x 24.1 L = 315.1 L H₂O Vapor
mol.

H₂O Vol. 315.1 L x 100 = 10.9%
Total 2883.6 L

PARTICULATE FIELD DATA

Run No. 21
 Location STACK
 Date 8/30/79
 Operator CHU / BRUCE

Amb. Temp. °F 71.08
 Bar. Press. "Hg. 28.26"
 Assumed Moist 10%
 Test Periods 144 min

Probe Tip Dia., in. 3/8"
 Probe length 8'
 Inp. Nos. _____
 Sample Box No. _____

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT _____

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In. H ₂ O	√ΔP	In. H ₂ O	Actual	Inlet	Outlet						
1-1	10:07/13	977.55	0.05	0.22	0.61	0.52	75	72	3.0	263	82	122	290	
2	19	982.87	0.11	0.33	1.34	1.09	77	80	8.0	245	95	163	289	
3	25	986.13	0.14	0.37	1.70	1.17	77	81	10.0	247	95	165	296	
4	31	989.26	0.13	0.36	1.58	1.15	78	81	10.0	263	100	203	307	
5	37	992.61	0.14	0.37	1.70	1.16	79	85	10.0	243	105	269	301	
6	43	995.94	0.13	0.36	1.58	1.22	79	86	10.0	240	95	190	296	
DE-1	10:45/11:00	999.38	0.05	0.25	0.61	1.30	79	83	10.0	244	95	197	296	
2	07	1002.78	0.08	0.28	0.97	1.27	80	83	11.0	250	98	165	297	
3	13	1006.25	0.08	0.28	0.97	1.32	80	85	11.0	270	98	166	296	1029
4	19	1009.63	0.03	0.17	0.37	1.26	81	87	11.5	243	100	281	286	
5	25	1011.49	0.03	0.17	0.37	0.38	81	86	2.5	240	100	261	287	
6	31	1013.34	0.03	0.17	0.37	0.36	83	87	2.5	243	102	272	284	
S-1	11:15/11:45	1015.13	0.03	0.17	0.37	0.36	82	86	2.5	248	87	136	284	
2	57	1017.21	0.04	0.20	0.49	0.48	84	85	3.5	242	150	170	284	
3	12:03	1019.39	0.04	0.20	0.49	0.50	84	88	4.0	272	95	107	294	
4	09	1021.64	0.05	0.22	0.61	0.58	85	84	5.0	276	95	205	281	
5	15	1023.83	0.04	0.20	0.49	0.53	85	88	4.5	247	96	230	287	
6	21	1026.17	0.05	0.22	0.61	0.60	89	92	5.0	224	98	265	276	
12-1	12:28/30	1027.98	0.03	0.17	0.37	0.36	85	91	3.0	191	96	183	277	
2	00	1030.12	0.04	0.20	0.49	0.50	85	89	4.0	267	99	171	282	
3	06	1032.26	0.04	0.20	0.49	0.50	90	92	4.5	193	97	150	295	
4	52	1034.57	0.05	0.22	0.61	0.59	89	92	5.0	259	97	181	291	
5	58	1036.90	0.05	0.22	0.61	0.60	90	93	5.5	237	95	207	278	
6	1:04	1039.26	0.05	0.22	0.61	0.61	89	93	5.5	238	94	268	273	
TOTAL	144						1983	2019						
AVERAGE	6						82.6	86.2						

5440K

84.4 Meter Volume

Dry Meter Calibration Factor

7470K

COMPUTER SAMPLE NUMBER

71

1

0

6

PARTICULATE & WATER CATCH

IMPINGER
NO. 18

IMPINGER
NO. 82

IMPINGER
NO. 83

IMPINGER NO. 84

71
-FILTER NO.

9. BREAKER

LEAKER
0.

0.
EAKER

39
EAKER
O.
ROBE WASHI

$$\frac{\text{Weight} 15.19 \text{ gm.} \times 24.1 \text{ L}}{18 \frac{\text{gm.}}{\text{mol.}}} = 204.5 \text{ H}_2\text{O Vapor}$$

77.03 = Total

Moisture Content: Sample Vol. 61.5 ft.^3 x $\frac{460 + 70}{460 + \text{Water}}$ x $28.3 \text{ L/ft.}^3 = 165.7 \text{ L Dry Gas}$

PARTICULATE FIELD DATA

Run No. 22
 Location STACK
 Date 8/30/79
 Operator CHA/BOS

Amb. Temp. °F 69.48
 Bar. Press. "Hg. 28.76"
 Assumed Moist 10%
 Test Periods 144 min

Probe Tip Dia., In. 3/8"
 Probe Length 8'
 Imp. Nos. 81
 Sample Box No. 8304

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice		Dry Gas Temp.		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In.	ΔP	In. H ₂ O	ΔH	Inlet	Outlet						
8-1	10:10.16	307.41	0.07	0.26	0.86	0.90	80	81	1.5	287	83	171	271	
2	22	313.96	0.09	0.30	1.11	1.16	80	81	2.0	248	93	146	288	
3	28	317.71	0.16	0.32	1.23	1.35	77	81	2.5	186	87	145	299	
4	34	321.60	0.11	0.33	1.60	1.45	77	81	3.0	278	89	181	303	
5	40	325.14	0.10	0.32	1.23	1.20	77	81	2.5	271	87	246	293	
6	46	328.96	0.12	0.35	1.48	1.40	76	81	3.0	247	86	273	293	
W-1	10:46/10:48	331.47	0.05	0.22	0.61	0.60	81	81	0.5	310	90	197	247	
2	10	334.62	0.08	0.28	0.98	0.95	82	81	2.0	275	95	182	282	
3	16	337.40	0.06	0.24	0.73	0.74	77	81	2.0	275	95	189	284	
4	22	339.70	0.04	0.20	0.49	0.51	78	81	1.0	242	92	204	280	
5	28	341.98	0.04	0.20	0.49	0.50	84	87	0.5	236	95	248	288	
6	34	344.26	0.04	0.20	0.49	0.50	84	89	0.5	282	102	266	285	
N-1	11:48/11:52	346.23	0.03	0.17	0.37	0.37	83	87	0.0	291	86	199	247	
2	12:00	348.72	0.04	0.22	0.61	0.59	83	87	1.5	261	88	168	264	
3	06	351.27	0.05	0.22	0.62	0.61	85	89	1.5	232	92	150	287	
4	12	353.80	0.05	0.22	0.62	0.61	85	90	1.5	266	95	185	284	
5	18	356.33	0.05	0.22	0.62	0.61	84	88	1.5	238	95	240	287	
6	24	358.72	0.04	0.20	0.49	0.55	86	92	1.5	248	98	216	289	
E-1	12:31/12:37	360.70	0.03	0.17	0.37	0.38	87	90	0.5	226	96	219	287	
2	43	362.70	0.03	0.17	0.37	0.38	89	91	0.5	265	98	191	286	
3	49	364.71	0.04	0.20	0.49	0.47	90	92	1.5	286	103	180	229	
4	55	367.40	0.05	0.22	0.62	0.59	88	91	2.0	258	97	221	278	
5	1:01	369.75	0.04	0.20	0.49	0.53	89	92	2.0	235	99	246	283	
6	07	372.01	0.04	0.20	0.49	0.49	91	92	2.0	210	98	273	282	
TOTAL	144						1443	1087						
AVERAGE	6						8304	86.96						

895°C

85°F
Meter Volume

Dry Meter Calibration Factor

740°C

CO-TESTED BY PLT LUN

60

1.3

0.0075

64.9

RUN NO. 22

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 65.50
Initial Weight 537.84
Increase

IMPINGER NO. 85

Final Weight 580.16
Initial Weight 567.84
Increase

IMPINGER NO. 86

Final Weight 462.58
Initial Weight 461.07
Increase

IMPINGER NO. 87

Final Weight 934.80
Initial Weight 815.71
Increase

IMPINGER NO. 88

Final Weight 904.2
Initial Weight 863.4
Part. Catch

FILTER NO. 15

SOLID WEIGHT GAIN

0.0408

Final Weight 147.7844
Initial Weight 147.6282
Increase 0.1562

BEAKER NO. 8

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 157.3318
Initial Weight 157.1461
Increase 0.1857

BEAKER NO. 40
PROBE WASH

Moisture Content: Sample Vol. 64.97 ft.³ x 460 + 70 = 29977 L H₂O Vapor
460 + Meter
545 Temp.

Water 170.58
Weight 40.58 gm. x 24.1 L
18 gm.
mol.

Total = 2016.47
H₂O Vol. 228.39 L x 100 = 11.3 %
Total 2016.4

PARTICULATE FIELD DATA

Run No. Run 23
 Location STACK
 Date 9/2/79
 Operator CHU/BRUCE

Amb. Temp. °F 89 WB
 Bar. Press. "Hg. 28.79"
 Assumed Moist 11%
 Test Periods 149 min

Probe Tip Dia., In 1/4"
 Probe Length 8'
 Imp. Nos. 149 min
 Sample Box No. 149 min

Heater Box Setting 200°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	In. H ₂ O	Actual	Inlet	Outlet						
10-1	7:57/8:00	41.81	0.22	0.45	0.47	0.45	60	61	0.0	255	65	169	280	
2	09	44.28	0.32	0.55	0.70	0.67	61	62	0.5	280	64	170	286	
3	15	46.97	0.35	0.59	0.82	0.80	61	63	3.0	246	65	231	291	
4	21	49.86	0.39	0.62	0.91	0.92	61	64	3.5	272	68	262	292	
5	27	53.09	0.43	0.66	1.08	1.15	63	67	5.0	275	67	280	289	
6	33	55.98	0.48	0.65	0.98	0.92	63	69	4.5	276	69	287	290	
5-1	8:40/46	58.12	0.22	0.47	0.52	0.50	65	68	2.2	237	70	191	300	
2	52	60.80	0.35	0.59	0.82	0.79	67	71	3.5	258	72	150	304	10.53
3	58	63.66	0.37	0.61	0.87	0.90	69	74	4.0	258	76	151	305	
4	9:04	66.70	0.42	0.65	0.98	1.02	69	75	5.0	275	77	247	306	
5	10	69.73	0.43	0.66	1.01	1.01	71	77	5.5	238	80	277	309	
6	16	72.55	0.39	0.69	0.87	0.87	72	78	5.0	264	81	301	306	
5-1	9:22/28	74.75	0.24	0.49	0.56	0.53	72	76	3.0	235	75	223	307	
2	34	77.44	0.35	0.59	0.82	0.80	72	75	4.5	295	77	175	306	
3	40	80.29	0.39	0.62	0.91	0.89	73	76	5.5	289	80	190	310	
4	46	83.33	0.41	0.64	0.96	1.02	71	77	6.0	233	82	254	312	
5	52	86.09	0.43	0.66	1.01	0.84	72	77	6.0	249	80	291	307	
6	58	89.07	0.35	0.59	0.82	0.98	72	77	5.5	276	78	305	305	
5-1	10:10/16	91.14	0.19	0.44	0.45	0.47	74	75	3.0	269	74	176	306	
2	22	93.51	0.28	0.53	0.66	0.62	74	75	3.0	234	78	144	312	
3	28	96.15	0.32	0.57	0.75	0.77	76	77	4.0	280	82	152	314	
4	34	98.85	0.36	0.60	0.84	0.80	75	77	4.5	234	80	216	315	
5	40	101.77	0.39	0.62	0.91	0.94	74	78	5.0	240	81	278	313	
6	46	104.36	0.31	0.56	0.73	0.74	74	77	4.5	280	87	303	307	
TOTAL	144						1641	1746					7204	
AVERAGE	6						69.2	72.8					304.3	

(531°K)

71.0 Meter Volume

Dry Meter Calibration Factor

(764°K)

COLLECTED SAMPLE VOLUME

44.57

ft.³

0.0066

64.3

1.0

RUN NO. 23

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 733.87
Initial Weight 522.04
Increase

IMPIINGER NO. 89

Final Weight 584.52
Initial Weight 563.96
Increase

IMPIINGER NO. 90

Final Weight 452.50
Initial Weight 448.34
Increase

IMPIINGER NO. 91

Final Weight 810.01
Initial Weight 781.34
Increase

IMPIINGER NO. 92

Final Weight 1.0048
Initial Weight .8714
Part. Catch

FILTER NO.

SOLID WEIGHT GAIN

Final Weight 144.6951
Initial Weight 144.5961
Increase

BEAKER NO. 22

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 141.0695
Initial Weight 141.0204
Increase

BEAKER NO. 38
PROBE WASH

Moisture Content: Sample Vol. 64.34 ft.³ x 460.70 = 29500 L H₂O Vapor
460.70 Meter
530
530 Temp.

Water Weight 220.32 gm. x 24.1 L = 29500 L H₂O Vapor
18 gm.
mol.

Total = 112.7 L
H₂O Vol. 29500 L x 100 = 14.0 %
Total 292.7

IMPIINGER 1 166.83

IMPIINGER 2 20.60

IMPIINGER 3 4.22

IMPIINGER 4 28.67

TOTAL 220.32

ORSAT

CO₂ 11.2

O₂ 13.6

CO

N₂ 75.2

133.4

BEAKER 38 0495

BEAKER 2 1829

BEAKER 3

BEAKER 22 0989

TOTAL 2818

0495

0495

133.4

PARTICULATE FIELD DATA

Run No. PLU 24
 Location STICK
 Date 9/2/79
 Operator CHU/BOB

Amb. Temp. °F 69 WBS
 Bar. Press. "Hg. 28.79"
 Assumed Moist 11%
 Test Periods 144 min

Probe Tip Dia., In 1/4"
 Probe Length 8'
 Imp. Nos. 144 min
 Sample Box No. 042411

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT TIME
 START OF EACH TEST POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In.	√AP	In. H ₂ O	Desired	Actual	Inlet	Outlet					
E-1	8:00/06	372.57	0.28	0.53	0.57	0.61	61	62	0.5	230	63	134	288	
2	12	372.86	0.38	0.62	0.78	0.74	61	63	1.0	258	63	149	298	
3	2/8	380.77	0.40	0.63	0.82	0.81	62	65	1.5	285	64	199	303	
4	24	383.87	0.44	0.66	0.90	0.92	61	66	2.5	283	65	197	300	
5	30	387.05	0.45	0.67	0.92	0.97	62	70	2.5	256	68	263	303	
6	36	390.03	0.44	0.66	0.90	0.85	64	72	2.5	239	68	200	304	
A-1	8:43/49	392.20	0.22	0.47	0.45	0.45	66	72	0.5	207	70	226	263	
2	55	394.85	0.34	0.58	0.69	0.67	68	73	2.0	282	71	181	291	
3	9:01	397.65	0.36	0.62	0.73	0.75	70	76	2.0	283	73	175	304	+0.99
4	07	400.47	0.37	0.61	0.75	0.76	70	76	2.0	271	73	231	301	
5	13	403.42	0.39	0.62	0.80	0.83	73	80	3.0	269	78	279	304	
6	19	406.43	0.41	0.64	0.84	0.87	73	80	3.0	290	76	290	308	
A-1	9:27/31	408.50	0.20	0.45	0.41	0.41	72	75	1.5	271	72	243	278	
2	37	411.04	0.32	0.57	0.65	0.62	74	78	2.0	272	76	188	300	
3	43	413.73	0.33	0.57	0.67	0.69	73	77	2.5	267	76	192	304	
4	49	416.48	0.35	0.59	0.71	0.72	74	79	2.5	271	79	243	310	
5	55	419.36	0.39	0.62	0.80	0.79	74	79	3.0	249	78	277	307	
6	10:01	422.32	0.40	0.63	0.82	0.84	73	78	3.0	266	75	300	308	
S-1	10:13/19	424.63	0.24	0.49	0.49	0.51	73	75	1.5	249	73	199	275	
2	25	427.43	0.38	0.62	0.78	0.75	77	79	2.5	244	79	147	305	
3	31	430.38	0.39	0.62	0.82	0.83	75	78	2.5	276	76	147	311	
4	37	433.41	0.40	0.65	0.86	0.85	77	81	3.0	260	80	216	316	
5	43	436.30	0.46	0.68	0.94	0.80	78	82	3.5	247	82	222	316	
6	49	439.52	0.46	0.68	0.94	0.99	73	78	6.5	270	74	301	311	
TOTAL	144				14.46	18.02	16.01	1684	1794				7207	
AVERAGE	6				0.603	0.751	0.753	70.2	74.8				300.3	

CONNECTED SAMPLE VOLUME

Meter Volume

Dry Meter Calibration Factor

67.32

RUN NO. 24

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

IMPINGER 1 145.92

IMPINGER 2 17.91

IMPINGER 3 10.64

IMPINGER 4 28.37

TOTAL 202.84

ORSAT

CO₂ 11.2

O₂ 13.6

CO -

N₂ 75.7

SOLID WEIGHT GAIN

1115

Final Weight 9796
Initial Weight 8681
Part. Catch 1115

FILTER NO. 17

Final Weight 830.37
Initial Weight 802.00
Increase 28.37

IMPINGER NO. 96

Final Weight 474.64
Initial Weight 464.00
Increase 10.64

IMPINGER NO. 95

Final Weight 562.33
Initial Weight 544.42
Increase 17.91

IMPINGER NO. 94

Final Weight 691.38
Initial Weight 645.46
Increase 145.92

IMPINGER NO. 93

Final Weight
Initial Weight
Increase

BEAKER

BEAKER

Final Weight
Initial Weight
Increase

BEAKER

Final Weight 140.6973
Initial Weight 140.5887
Increase 0.1086

Final Weight 9796
Initial Weight 8681
Part. Catch 1115

Final Weight 830.37
Initial Weight 802.00
Increase 28.37

Final Weight 474.64
Initial Weight 464.00
Increase 10.64

Final Weight 562.33
Initial Weight 544.42
Increase 17.91

Final Weight 691.38
Initial Weight 645.46
Increase 145.92

BEAKER NO. 24
PROBE WASH

Final Weight 148.4490
Initial Weight 148.4280
Increase 0.0210

Moisture Content: Sample Vol. 67.33 ft.³ x 460 + 70 = 31250.66
x 28.3 L/ft.³ = 898.3 L Dry Gas

Water Weight 202.84 gm. x 24.1 L = 4888.284
mol. 18 gm. = 271.6 L H₂O Vapor

H₂O Vol. 271.6 L
Total 2469.9 L
x 100 = 12.5%

PARTICULATE FIELD DATA

Run No. 25
 Location STACK
 Date 9/3/79
 Operator C.H. BRUCE

Amb. Temp. °F 70.68
 Bar. Press. "Hg. 28.73
 Assumed Moist 12%
 Test Periods 141 min

Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos.
 Sample Box No.

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O	Orifice ΔH		Dry Gas Temp. °F	Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
				Desired	Actual							
M-1	8:23/29	104.89	0.23	0.48	0.49	72	3.0	266	75	163	297	
2	8:25	109.55	0.34	0.58	0.72	72	4.5	292	80	173	318	
3	41	112.27	0.35	0.59	0.81	73	5.5	268	81	184	317	
4	47	115.20	0.40	0.63	0.92	79	7.0	294	85	226	326	
5	53	118.14	0.41	0.64	0.94	72	7.0	297	76	285	315	
6	59	121.27	0.47	0.69	1.08	74	8.0	256	79	304	304	
M-1	9:07/11	123.53	0.25	0.50	0.57	74	3.0	285	85	185	314	
2	14	126.39	0.39	0.62	0.89	72	6.0	267	75	166	312	70.47
3	23	129.30	0.41	0.64	0.94	79	6.5	260	88	168	315	
4	29	132.36	0.46	0.69	1.08	75	8.5	230	85	232	315	
5	35	135.42	0.47	0.69	1.08	78	8.5	264	86	285	309	
6	41	138.70	0.47	0.69	1.08	81	8.5	267	89	306	307	
M-1	9:49/55	141.10	0.28	0.53	0.63	81	4.5	250	84	171	312	
2	10:01	143.81	0.32	0.60	0.81	73	5.0	270	85	143	310	
3	07	146.76	0.42	0.65	0.96	71	7.0	292	85	132	309	
4	13	149.62	0.42	0.65	0.96	74	7.0	292	85	143	310	
5	19	152.65	0.47	0.69	1.08	74	7.0	292	85	143	310	
6	25	155.82	0.47	0.69	1.08	74	7.0	292	85	143	310	
M-1	10:35/01	157.64	0.15	0.39	0.34	73	3.0	231	86	164	282	
2	47	160.00	0.28	0.53	0.61	72	4.0	282	75	141	302	
3	53	162.68	0.33	0.57	0.76	71	6.0	238	82	142	308	
4	59	165.37	0.37	0.61	0.85	74	7.0	280	76	233	307	
5	11:05	168.28	0.41	0.64	0.88	74	7.0	280	76	233	307	
6	11	171.72	0.43	0.64	0.93	74	7.0	280	76	233	307	
TOTAL	144					74	9.0	268	74	294	294	
AVERAGE	6					74	7.0	268	74	294	294	

CORRECTED SAMPLE VOLUME

Meter Volume

Dry Meter Calibration Factor

(537)K

76.70K

(761)K

RUN NO. 25

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 710.20
Initial Weight 544.87
Increase

IMPINGER NO. 97

IMPINGER NO. 98

Final Weight 572.89
Initial Weight 554.44
Increase

IMPINGER NO. 99

Final Weight 465.41
Initial Weight 462.18
Increase

IMPINGER NO. 100

Final Weight 851.35
Initial Weight 826.67
Increase

FILTER NO. #18

Final Weight 0.9771
Initial Weight 0.8724
Part. Catch

SOLID WEIGHT GAIN

0.1047

Final Weight 143.0075
Initial Weight 142.8987
Increase

BEAKER NO. 4

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 142.6050
Initial Weight 142.5871
Increase

BEAKER NO. 17
PROBE WASH

Moisture Content: Sample Vol. 66.2 ft.³ x 460 + 70 = 287.4 L H₂O Vapor
460 + Meter
437 Temp.

Water Weight 18 gm. x 24.1 L = 287.4 L H₂O Vapor
mol.

H₂O Vol. 287.4 L x 100 = 13.5 %
Total 736.1

Total = 2736.5 L

TOTAL 0.2314

BEAKER 1 0.1088

BEAKER 2 0.1226

BEAKER 3 0.1647

BEAKER 4 0.0179

N₂ 74.2

CO -

O₂ 14.4

CO₂ 11.4

ORSAT

TOTAL 214.69

IMPINGER 4 22.68

IMPINGER 3 3.23

IMPINGER 2 18.45

IMPINGER 1 165.33

PARTICULATE FIELD DATA

Run No. 26
 Location STDC
 Date 9/3/79
 Operator Chaf Bill

Amb. Temp. °F 73.08
 Bar. Press. "Hg. 28.73
 Assumed Moist 12%
 Test Periods 144 min

Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos. 144 min
 Sample Box No. 144 min

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack In. H ₂ O
			AP	VAP	Desired	Actual	Inlet	Outlet						
S-1	8:26/32	442.29	0.19	0.44	0.46	0.47	73	74	0.5	244	76	247	289	
2	38	444.78	0.30	0.55	0.60	0.59	77	76	0.5	239	82	164	307	
3	44	447.51	0.36	0.60	0.70	0.71	73	74	1.5	245	81	141	313	
4	50	450.41	0.41	0.64	0.82	0.81	75	76	2.0	241	79	197	319	
5	56	453.50	0.45	0.67	0.90	0.92	78	80	2.5	246	83	280	324	
6	9:02	456.75	0.48	0.69	0.96	1.01	73	80	3.0	249	79	243	312	
E-1	9:08/14	458.58	0.15	0.39	0.30	0.32	74	78	0.0	300	82	239	273	
2	20	460.95	0.21	0.50	0.50	0.49	73	79	0.5	250	83	195	293	+0.61
3	26	463.58	0.38	0.59	0.64	0.66	75	79	1.0	267	82	186	308	
4	32	466.32	0.35	0.59	0.70	0.72	73	80	1.5	238	80	220	314	
5	38	469.03	0.35	0.59	0.70	0.70	75	79	1.0	278	80	209	304	
6	44	472.103	0.42	0.64	0.84	0.86	82	89	2.0	277	81	271	307	
N-1	9:52/58	473.77	0.14	0.32	0.28	0.27	74	76	6.0	278	79	211	293	
2	10:04	478.07	0.25	0.50	0.50	0.53	74	76	0.5	280	76	164	286	
3	10	478.60	0.30	0.57	0.60	0.61	73	76	0.5	291	76	132	302	
4	16	481.30	0.36	0.60	0.72	0.70	74	78	1.0	291	76	144	305	
5	22	480.17	0.36	0.60	0.72	0.79	72	78	2.0	289	74	222	303	
6	28	487.02	0.38	0.62	0.76	0.78	75	81	2.0	290	78	261	308	
7	10:35/09	489.13	0.21	0.46	0.42	0.43	73	76	0.5	297	77	190	293	
8	50	491.62	0.30	0.55	0.60	0.59	74	77	1.0	239	77	149	302	
9	56	494.51	0.37	0.61	0.74	0.80	77	80	2.0	246	81	152	308	
10	11:02	497.47	0.41	0.64	0.82	0.84	76	78	2.5	247	82	201	306	
11	08	500.32	0.41	0.64	0.82	0.79	76	82	2.5	221	76	248	308	
12	14	503.33	0.41	0.64	0.82	0.87	74	80	2.5	271	70	276	305	
TOTAL	144						74	80						
AVERAGE							74.6	78.6						

afano broken

537°K 76.0

Meter Volume

ft. 1

Dry Meter Calibration Factor

761°K

62.81

301.5

301.5

RUN NO. 22
PARTICULATE & WATER CATCH

Broken glassware

WATER WEIGHT GAIN

Final Weight 579.31
Initial Weight 555.67
Increase

IMPINGER NO. 1

IMPINGER 2 4.81

Final Weight 537.72
Initial Weight 532.91
Increase

IMPINGER NO. 2

IMPINGER 3 1.35

Final Weight 452.77
Initial Weight 451.42
Increase

IMPINGER NO. 3

IMPINGER 4 17.12

Final Weight 796.48
Initial Weight 779.36
Increase

IMPINGER NO. 4

IMPINGER 5 14.4

Final Weight 0.8700
Initial Weight 0.8629
Part. Catch

FILTER NO. # 19

IMPINGER 6 74.2

SOLID WEIGHT GAIN

Final Weight 142.0274
Initial Weight 142.0259
Increase

BEAKER NO. 15

BEAKER 1 0.0309

Final Weight
Initial Weight
Increase

BEAKER NO.

BEAKER 2 5.0015

Final Weight
Initial Weight
Increase

BEAKER NO.

BEAKER 3 39.5 mg

Final Weight 137.5989
Initial Weight 137.5680
Increase 0.0309

BEAKER NO. 11
PROBE WASH

Moisture Content: Sample Vol. 63.61 ft. 3 x 460 + 70 460 + Meter 37 Temp. X 28.3 L/ft. 3 = 17767 L Dry Gas

Water Weight 66.9 gm. x 24.1 L = 89.6 L H₂O Vapor mol.

H₂O Vol. 89.6 L x 100 = 41.8 % Total 186.3

PARTICULATE FIELD DATA

Run No. 31
 Location STAC
 Date 9/4/79
 Operator CHU / BRUCE

Amb. Temp. °F 71.08
 Bar. Press. "Hg. 28.74"
 Assumed Moist 13%
 Test Periods 144 min

Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos. 144 min
 Sample Box No. ONE

Heater Box Setting 200°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O	Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
				Desired	Actual	Inlet	Outlet						
1	10:04/10	173.48	0.20	0.45	0.48	67	69	0.5	222	226	185	277	
2	16	177.98	0.30	0.55	0.68	66	70	2.0	251	73	189	293	
3	22	180.66	0.34	0.58	0.77	67	69	2.5	243	75	185	286	
4	28	183.41	0.37	0.61	0.84	69	72	3.0	263	72	210	296	
5	34	186.23	0.40	0.63	0.91	70	76	3.5	259	76	277	293	
6	40	189.23	0.43	0.66	0.98	71	77	4.0	269	80	292	286	
C-1	10:47/53	191.67	0.30	0.57	0.68	74	82	2.5	221	82	206	298	+0.43
2	59	194.41	0.37	0.61	0.84	79	83	2.5	245	87	185	302	
3	11:05	197.34	0.41	0.64	0.93	81	83	4.0	265	87	173	301	
4	11	200.55	0.52	0.72	1.18	85	90	5.0	290	88	223	310	
5	17	204.44	0.75	0.87	1.70	87	96	5.2	251	87	290	304	
6	23	208.36	0.75	0.87	1.66	87	89	8.5	229	88	240	297	
C-1	11:29/35	210.66	0.26	0.57	0.59	85	89	7.0	236	87	223	289	
2	41	213.35	0.34	0.68	0.84	85	87	3.5	249	84	174	304	
3	47	216.16	0.40	0.63	0.91	89	92	4.0	263	86	199	312	
4	53	219.09	0.42	0.65	0.94	86	90	4.0	230	97	245	304	
5	59	222.08	0.45	0.67	1.02	88	93	4.1	240	95	288	304	
6	12:05	225.01	0.42	0.65	0.95	88	96	4.1	240	95	245	304	
N-1	12:16/22	227.14	0.40	0.65	0.95	87	96	5.0	269	98	249	310	
2	28	229.65	0.30	0.55	0.48	83	84	3.0	243	88	181	296	
3	34	232.32	0.35	0.59	0.68	87	89	3.0	240	94	160	311	
4	40	235.09	0.39	0.62	0.79	89	89	3.5	269	92	151	310	
5	46	238.13	0.40	0.63	0.88	87	89	4.0	240	94	223	321	
6	52	240.85	0.42	0.65	0.91	87	84	5.0	272	90	286	309	
TOTAL	149			11.93	21.52	1915	2003	6.5	222	90	306	308	
AVERAGE	C			0.622	0.897	79.8	83.5					302.1	

COLLECTED SAMPLE VOLUME

Meter Volume

Dry Meter Calibration Factor

54296

81.6

1737

0.0006

62

76206

RUN NO. 31

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 704.43
Initial Weight 554.51
Increase

IMPIINGER NO. 21

Final Weight 575.03
Initial Weight 549.61
Increase

IMPIINGER NO. 22

Final Weight 468.14
Initial Weight 463.22
Increase

IMPIINGER NO. 23

Final Weight 841.89
Initial Weight 809.33
Increase

IMPIINGER NO. 24

Final Weight 0.9479
Initial Weight 0.8634
Part. Catch

FILTER NO. 20

SOLID WEIGHT GAIN

0.0845

Final Weight 138.5780
Initial Weight 138.5091
Increase

BEAKER NO. 12

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 141.0298
Initial Weight 141.0105
Increase

BEAKER NO. 5
PROBE WASH

Moisture Content: Sample Vol. 67.14 ft. 3 x 460 + 70 = 460 + Meter
X 28.3 L/ft. 3 = 1858.0 L Dry Gas

Water Weight 2463 gm. x 24.1 L = 329.8 L H₂O Vapor
18 gm. mol.

Total = 2187.8
H₂O Vol. 329.8 L
Total = 2187.8
% = 15.1

PARTICULATE FIELD DATA

Run No. 32
 Location STK
 Date 9/4/79
 Operator Chapman

Amb. Temp. °F 71.03
 Bar. Press. "Hg. 28.74"
 Assumed Moist 13%
 Test Periods 1st 1 hr

Probe Tip Dia., In. 1/4"
 Probe Length 8'
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 270°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	√AP	In. H ₂ O	Actual	Inlet	Outlet						
E-6	10:07/13	527.72	0.51	0.71	1.01	1.01	67	74	3.5	301	80	202	300	
5	14	510.97	0.52	0.72	1.03	1.01	67	72	3.5	238	69	206	302	
4	25	514.11	0.50	0.71	0.99	0.85	72	75	3.5	205	75	279	300	
3	31	517.03	0.44	0.64	0.81	0.52	71	75	3.0	237	67	281	299	
2	37	519.68	0.35	0.59	0.69	0.67	69	76	2.5	272	69	271	296	
1	43	522.09	0.27	0.52	0.53	0.56	71	77	2.5	239	72	274	271	
N-6	10:09/56	525.38	0.47	0.69	0.93	1.04	79	85	6.0	244	86	206	309	
5	11:02	528.36	0.47	0.69	0.93	0.85	85	90	3.5	228	89	316	316	+0.49
4	08	531.30	0.43	0.68	0.85	0.53	89	92	3.5	262	92	259	302	
3	14	534.55	0.49	0.70	0.97	1.01	78	86	4.0	240	80	284	299	
2	20	537.62	0.47	0.69	0.93	0.90	84	90	3.5	233	85	243	300	
1	26	540.33	0.36	0.60	0.71	0.70	81	87	3.0	276	85	202	278	
W-6	11:33/38	543.33	0.45	0.67	0.89	0.86	81	91	3.5	270	91	233	301	
5	04	546.39	0.42	0.65	0.83	0.90	86	90	3.5	202	95	294	304	
4	50	549.07	0.37	0.61	0.73	0.69	82	88	3.0	266	95	294	298	
3	56	551.68	0.33	0.57	0.65	0.65	88	92	2.5	260	102	289	304	
2	12:02	554.11	0.28	0.53	0.55	0.57	89	94	2.5	202	93	266	306	
1	08	556.06	0.20	0.45	0.39	0.36	86	89	2.0	249	85	209	284	
W-6	12:19/25	559.21	0.50	0.71	0.99	0.95	85	86	3.5	209	90	261	306	
5	31	562.44	0.50	0.71	0.99	1.00	87	90	4.0	201	90	243	312	
4	37	565.67	0.50	0.71	0.99	1.00	82	86	4.0	247	89	245	320	
3	43	568.62	0.43	0.66	0.85	0.83	88	93	3.5	279	93	236	309	
2	49	571.39	0.36	0.60	0.71	0.70	81	86	3.0	245	88	236	309	
1	55	573.82	0.27	0.52	0.53	0.57	89	93	2.5	239	92	184	288	
TOTAL	144						1531	1948					7231	
AVERAGE	6						0.638	0.812					301.3	

Collected Sample Volume 543.8 Meter Volume 83.3 Ft. 3.4
 Dry Meter Calibration Factor 761.0

32
RUN NO. PARTICULATE & WATER CATCH

Final Weight 71.24
Initial Weight 550.80
Increase

IMPINGER NO. 25

Final Weight 579.54
Initial Weight 556.66
Increase

IMPINGER NO. 26

Final Weight 462.74
Initial Weight 461.39
Increase

IMPINGER NO. 27

Final Weight 820.03
Initial Weight 794.41
Increase

IMPINGER NO. 28

Final Weight 0.8618
Initial Weight 0.8183
Part. Catch 0.0435

FILTER NO. 21

Final Weight 121.6440
Initial Weight 121.5838
Increase

BEAKER NO. 9

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 135.4489
Initial Weight 135.4046
Increase 0.0443

BEAKER NO. 3
PROBE WASH

Moisture Content: Sample Vol. 69.74 ft. 3 x 28.3 L/ft. 3 = 1926.4 L Dry Gas
460 + Meter 530
543 Temp.

Water Weight 1953 gm. x 24.1 L = 261.5 L H₂O Vapor
18 gm. mol.

H₂O Vol. 261.5 L
Total = 2487.9 L
Total = 12.0% x 100 = 12.0%
2787.9

SOLID WEIGHT GAIN

IMPINGER 1 164.46
IMPINGER 2 2.88
IMPINGER 3 2.35
IMPINGER 4 25.62
TOTAL 195.31
ORSAT
CO₂ 10.6
O₂ 14.1
CO -
N₂ 74.9

BEAKER 3 0.0443
BEAKER 2 0.0435
BEAKER 3 0.0878
BEAKER 3 0.0602
TOTAL 0.1480
148 mg

$K_{m} = 0.6716$

PARTICULATE FIELD DATA

Run No. 39
Location OLD PLANT SITE 4
Date 9/19/79
Operator CHU/BREWE

Amb. Temp. °F 65.08
Bar. Press. "Hg. 28.79"
Assumed Moist 14%
Test Periods 128 min.

Probe Tip Dia., In. 1/4"
Probe Length 6'
Imp. Nos. 81
Sample Box No. 88.2

Heater Box Setting 250°F
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. $\frac{1}{2}$ "	$\sqrt{AP}$	Desired In. $\frac{1}{2}$ "	Actual ΔH $\frac{1}{2}$ "	Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
							Inlet	Outlet						
A-1	10:20/28	283.74	0.22	0.47	0.41	0.42	81	82	1.0	238	101	165	406	
2	36	289.15	0.26	0.51	0.49	0.47	81	84	2.0	240	103	222	430	
3	44	292.05	0.28	0.53	0.52	0.54	82	85	2.0	241	96	174	426	
4	52	294.97	0.29	0.54	0.54	0.52	82	86	2.0	242	96	228	428	
5	11:00	297.38	0.19	0.44	0.34	0.35	82	88	1.5	242	99	346	435	
6	08	299.67	0.17	0.41	0.32	0.32	83	88	0.5	225	100	411	417	
7	16	302.05	0.19	0.44	0.35	0.35	83	89	0.5	221	103	417	417	70.27
8	24	303.99	0.11	0.33	0.20	0.23	84	89	0.0	250	109	442	417	
B-1	11:54/12:00	305.85	0.13	0.36	0.24	0.21	85	89	2.0	195	84	156	414	
2	10	307.86	0.11	0.33	0.20	0.25	85	89	0.0	192	86	134	419	
3	18	310.09	0.18	0.42	0.33	0.30	85	88	1.0	267	95	158	424	
4	26	312.61	0.22	0.47	0.41	0.39	86	89	1.5	269	94	281	428	
5	34	315.28	0.23	0.48	0.43	0.43	86	91	2.0	240	97	396	422	
6	42	318.04	0.23	0.48	0.43	0.46	86	91	2.5	239	92	418	430	
7	50	320.66	0.23	0.48	0.43	0.42	87	92	2.5	243	94	425	428	
8	58	323.27	0.23	0.48	0.43	0.42	87	94	2.5	248	96	440	431	
TOTAL														
AVERAGE														

COLECTED SAMPLES
Meter Volume 86.4
Dry Meter Calibration Factor 8830/6

RUN NO. 37

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

IMPINGER 1 99.82

IMPINGER 2 6.98

IMPINGER 3 0.19

IMPINGER 4 13.70

TOTAL 120.69

ORSAT

CO₂ 16.4

O₂ 10.6

CO -

N₂ 73.0

SOLID WEIGHT GAIN

Final Weight 142.2763
Initial Weight 142.2339 = 0.0424 Increase

Final Weight
Initial Weight
Increase

Final Weight
Initial Weight
Increase

Final Weight 140.4108
Initial Weight 140.3473 = 0.0635 Increase

Moisture Content: Sample Vol. 29.34 ft.³ x $\frac{460 + 70}{460 + \text{Meter}}$ x 28.3 L/ft.³ = 1081.4 L Dry Gas

546 Temp.

Water Weight 120.69 gm. x 24.1 L = 161.6 L H₂O Vapor

H₂O Vol. 161.6 L x 100 = 13.0% Total 1242.6

IMPINGER NO. 53

IMPINGER NO. 54

IMPINGER NO. 52

IMPINGER NO. 51

FILTER NO. 22

BEAKER NO. 46

BEAKER NO.

BEAKER NO.

BEAKER NO. 7
PROBE WASH

$k_{m} = 0.6714$

PARTICULATE FIELD DATA

Run No. 40
Location OLD PLANT STACK 4
Date 9/19/79
Operator CHU/BOS

Amb. Temp. °F 72.03
Bar. Press. "Hg. 28.79
Assumed Moist 14.0%
Test Periods 128 hrs

Probe Tip Dia., In. 1/4"
Probe Length 6'
Imp. Nos.
Sample Box No.

Heater Box Setting 250°F
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack In. H ₂ O Press.
			In. H ₂ O	$\sqrt{\Delta P}$	In. H ₂ O Desired	Actual	Inlet	Outlet						
B-1	10:24/32	724.78	0.11	0.33	0.21	0.23	70	71	0.00	244	111	177	498	
2	48	729.22	0.17	0.41	0.32	0.31	70	72	0.50	300	75	204	412	
3	48	731.77	0.20	0.45	0.39	0.38	74	76	1.0	270	75	213	422	
4	56	734.13	0.19	0.44	0.31	0.30	71	76	1.0	270	74	215	421	
5	11:04	736.59	0.21	0.46	0.34	0.33	74	78	1.5	281	75	203	418	
6	12	739.31	0.25	0.50	0.41	0.40	82	87	2.0	306	85	223	423	40.32
7	20	742.13	0.25	0.50	0.41	0.42	82	86	2.0	269	82	225	424	
8	28	744.69	0.23	0.48	0.38	0.36	83	85	2.5	261	83	221	412	
A-1	11:50/58	747.20	0.21	0.46	0.34	0.34	79	81	2.0	282	89	267	412	
2	12:06	749.89	0.25	0.50	0.41	0.39	79	80	2.5	246	94	174	418	
3	14	752.79	0.27	0.52	0.44	0.44	79	82	2.5	284	89	227	432	
4	22	755.52	0.25	0.50	0.41	0.40	80	84	2.5	252	87	365	434	
5	30	758.02	0.17	0.41	0.32	0.33	76	80	2.5	249	90	404	417	
6	38	760.48	0.17	0.41	0.32	0.33	74	78	2.5	308	90	418	422	
7	46	762.59	0.15	0.39	0.25	0.24	74	78	2.5	252	85	412	406	
8	54	764.65	0.13	0.36	0.21	0.23	81	85	2.5	226	103	410	418	
TOTAL														
AVERAGE														

CORRECTED SAMPLE VOLUME

Meter Volume

Dry Meter Calibration Factor

48.10

RUN NO. 40

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

IMPINGER 1 99.10

IMPINGER 2 7.04

IMPINGER 3 0.21

IMPINGER 4 12.4

TOTAL 118.75

ORSAT

CO₂ 16.4

O₂ 10.6

CO -

N₂ 73

SOLID WEIGHT GAIN

BEAKER 15 0.0840

BEAKER 27 0.1785

BEAKER 3 0.065

BEAKER 25 0.0340

TOTAL 0.2965

Final Weight 66.49
Initial Weight 56.59
Increase

IMPINGER NO. 57

Final Weight 57.78
Initial Weight 56.474
Increase

IMPINGER NO. 58

Final Weight 46.821
Initial Weight 46.800
Increase

IMPINGER NO. 59

Final Weight 85.73
Initial Weight 84.033
Increase

IMPINGER NO. 60

Final Weight 0.8853
Initial Weight 0.7068
Part. Catch
= 0.1785

FILTER NO. 29

Final Weight 146.0141
Initial Weight 145.9801
Increase
= 0.0340

BEAKER NO. 23

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 128.7178
Initial Weight 128.6338
Increase
= 0.0840

BEAKER NO. 75
PROBE WASH

Moisture Content: Sample Vol. 40.10 ft.³ x 460 + 70 = 18800
x 28.3 L/ft.³ = 1118.0 L Dry Gas
530
460 + Meter
536 Temp.

Water Weight 118.75 gm. x 24.1 L = 157.0 L H₂O Vapor
18 gm.
mol.

H₂O Vol. 157.0 L x 100 = 12.5%
Total 127.0 L

PARTICULATE FIELD DATA

Heater Box Setting

FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

[illegible]

12.2.10.11.12.13.14.15.16.17.18.19.20.21.22.23.24.25.26.27.28.29.30.31.32.33.34.35.36.37.38.39.40.41.42.43.44.45.46.47.48.49.50.51.52.53.54.55.56.57.58.59.60.61.62.63.64.65.66.67.68.69.70.71.72.73.74.75.76.77.78.79.80.81.82.83.84.85.86.87.88.89.90.91.92.93.94.95.96.97.98.99.100.101.102.103.104.105.106.107.108.109.110.111.112.113.114.115.116.117.118.119.120.121.122.123.124.125.126.127.128.129.130.131.132.133.134.135.136.137.138.139.140.141.142.143.144.145.146.147.148.149.150.151.152.153.154.155.156.157.158.159.160.161.162.163.164.165.166.167.168.169.170.171.172.173.174.175.176.177.178.179.180.181.182.183.184.185.186.187.188.189.190.191.192.193.194.195.196.197.198.199.200.201.202.203.204.205.206.207.208.209.210.211.212.213.214.215.216.217.218.219.220.221.222.223.224.225.226.227.228.229.230.231.232.233.234.235.236.237.238.239.240.241.242.243.244.245.246.247.248.249.250.251.252.253.254.255.256.257.258.259.260.261.262.263.264.265.266.267.268.269.270.271.272.273.274.275.276.277.278.279.280.281.282.283.284.285.286.287.288.289.290.291.292.293.294.295.296.297.298.299.300.301.302.303.304.305.306.307.308.309.310.311.312.313.314.315.316.317.318.319.320.321.322.323.324.325.326.327.328.329.330.331.332.333.334.335.336.337.338.339.340.341.342.343.344.345.346.347.348.349.350.351.352.353.354.355.356.357.358.359.360.361.362.363.364.365.366.367.368.369.370.371.372.373.374.375.376.377.378.379.380.381.382.383.384.385.386.387.388.389.390.391.392.393.394.395.396.397.398.399.400.401.402.403.404.405.406.407.408.409.410.411.412.413.414.415.416.417.418.419.420.421.422.423.424.425.426.427.428.429.430.431.432.433.434.435.436.437.438.439.440.441.442.443.444.445.446.447.448.449.450.451.452.453.454.455.456.457.458.459.460.461.462.463.464.465.466.467.468.469.470.471.472.473.474.475.476.477.478.479.480.481.482.483.484.485.486.487.488.489.490.491.492.493.494.495.496.497.498.499.500.501.502.503.504.505.506.507.508.509.510.511.512.513.514.515.516.517.518.519.520.521.522.523.524.525.526.527.528.529.530.531.532.533.534.535.536.537.538.539.540.541.542.543.544.545.546.547.548.549.550.551.552.553.554.555.556.557.558.559.560.561.562.563.564.565.566.567.568.569.570.571.572.573.574.575.576.577.578.579.580.581.582.583.584.585.586.587.588.589.590.591.592.593.594.595.596.597.598.599.600.601.602.603.604.605.606.607.608.609.610.611.612.613.614.615.616.617.618.619.620.621.622.623.624.625.626.627.628.629.630.631.632.633.634.635.636.637.638.639.640.641.642.643.644.645.646.647.648.649.650.651.652.653.654.655.656.657.658.659.660.661.662.663.664.665.666.667.668.669.670.671.672.673.674.675.676.677.678.679.680.681.682.683.684.685.686.687.688.689.690.691.692.693.694.695.696.697.698.699.700.701.702.703.704.705.706.707.708.709.710.711.712.713.714.715.716.717.718.719.720.721.722.723.724.725.726.727.728.729.730.731.732.733.734.735.736.737.738.739.740.741.742.743.744.745.746.747.748.749.750.751.752.753.754.755.756.757.758.759.760.761.762.763.764.765.766.767.768.769.770.771.772.773.774.775.776.777.778.779.780.781.782.783.784.785.786.787.788.789.790.791.792.793.794.795.796.797.798.799.800.801.802.803.804.805.806.807.808.809.810.811.812.813.814.815.816.817.818.819.820.821.822.823.824.825.826.827.828.829.830.831.832.833.834.835.836.837.838.839.840.841.842.843.844.845.846.847.848.849.850.851.852.853.854.855.856.857.858.859.860.861.862.863.864.865.866.867.868.869.870.871.872.873.874.875.876.877.878.879.880.881.882.883.884.885.886.887.888.889.890.891.892.893.894.895.896.897.898.899.900.901.902.903.904.905.906.907.908.909.910.911.912.913.914.915.916.917.918.919.920.921.922.923.924.925.926.927.928.929.930.931.932.933.934.935.936.937.938.939.940.941.942.943.944.945.946.947.948.949.950.951.952.953.954.955.956.957.958.959.960.961.962.963.964.965.966.967.968.969.970.971.972.973.974.975.976.977.978.979.980.981.982.983.984.985.986.987.988.989.990.991.992.993.994.995.996.997.998.999.1000.1001.1002.1003.1004.1005.1006.1007.1008.1009.1010.1011.1012.1013.1014.1015.1016.1017.1018.1019.1020.1021.1022.1023.1024.1025.1026.1027.1028.1029.1030.1031.1032.1033.1034.1035.1036.1037.1038.1039.1040.1041.1042.1043

COBALT TELECOMP LUM



Dry Meter Calibration Factor

88010

RUN NO. 41

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 753.35
Initial Weight 574.97
Increase

IMPIINGER NO. 61

IMPIINGER NO. 62

Final Weight 494.10
Initial Weight 566.84
Increase

IMPIINGER NO. 63

IMPIINGER NO. 64

Final Weight 785.02
Initial Weight 769.18
Increase

FILTER NO. 30

Final Weight 0.8863
Initial Weight 0.7097
Part. Catch = 0.1766

SOLID WEIGHT GAIN

Final Weight 143.6222
Initial Weight 143.6214
Increase = 0.0008

BEAKER NO. 19

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO. 30
PROBE WASH

Final Weight 142.5810
Initial Weight 142.9128
Increase = 0.0682

Moisture Content: Sample Vol. 42.34 ft. 3 x 460 + Meter 460 + Temp. 74
X 28.3 L/ft. 3 = 1167.4 L Dry Gas

Water Weight 127.44 gm. x 24.1 L = 170.6 L H₂O Vapor
18 gm. mol.

H₂O Vol. 170.6 L x 100 = 12.8 %
Total = 1338.01

PARTICULATE FIELD DATA

Run No. 42 Amb. Temp. °F 63.0 Probe Tip Dia., In. 1/4" Heater Box Setting 870°F
 Location Stack #4 Bar. Press. "Hg. 28.88" Probe Length 6' FILL IN ALL BLANKS
 Date 9/20/79 Assumed Moist 13% Imp. Nos. 128 READ & RECORD AT THE
 Operator Chg/BBE Test Periods 128 Aug Sample Box No. 128 START OF EACH TEST POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	√AP	Desired	Actual	Inlet	Outlet						
B-1	9:58/10:00	76.520	0.23	0.48	0.42	0.90	67	67	0.0	245	63	139	219	
2	14	770.91	0.28	0.53	0.52	0.50	66	67	0.0	255	61	267	425	
3	22	774.20	0.29	0.54	0.53	0.56	65	69	0.5	267	62	363	424	
4	30	777.32	0.29	0.54	0.53	0.52	64	70	0.5	263	63	387	425	
5	38	779.79	0.19	0.44	0.35	0.33	65	72	0.0	263	66	413	421	
6	46	782.20	0.16	0.40	0.29	0.31	67	74	0.0	266	69	430	417	
7	54	784.32	0.12	0.36	0.24	0.24	68	73	0.0	267	70	418	408	+0.27
8	11:02	780.52	0.13	0.36	0.24	0.26	68	79	0.0	269	73	416	403	
A-1	11:27/35	785.48	0.15	0.36	0.24	0.21	66	68	0.5	319	63	416	395	
2	43	790.85	0.15	0.39	0.28	0.30	69	68	2.0	263	62	158	402	
3	51	793.49	0.20	0.44	0.37	0.38	67	70	2.0	265	65	299	410	
4	59	796.13	0.20	0.45	0.37	0.38	66	70	2.0	253	64	360	409	
5	12:07	798.94	0.22	0.47	0.41	0.43	66	71	2.5	256	64	397	416	
6	15	801.59	0.22	0.47	0.41	0.38	66	72	2.5	280	63	408	407	
7	23	804.44	0.23	0.48	0.42	0.44	68	74	2.5	278	66	410	406	
8	31	807.18	0.23	0.48	0.42	0.40	68	79	3.0	244	67	410	404	
TOTAL														
AVERAGE														

529.6 68.7

Meter Volume

Dry Meter Calibration Factor

872.0

COPIES OF THIS REPORT WILL BE FURNISHED TO THE FOLLOWING:

RUN NO. 42

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 723.69
Initial Weight 575.15
Increase

IMPINGER NO. 65

Final Weight 535.85
Initial Weight 570.79
Increase

IMPINGER NO. 66

Final Weight 449.17
Initial Weight 444.93
Increase

IMPINGER NO. 67

Final Weight 789.21
Initial Weight 767.82
Increase

IMPINGER NO. 68

Final Weight 0.9051
Initial Weight 0.7090
Part. Catch

FILTER NO. 34

SOLID WEIGHT GAIN

Final Weight 139.2826
Initial Weight 139.2252
Increase = 0.0574

BEAKER NO. 37

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

BEAKER NO. 35
PROBE WASH

Final Weight 155.9094
Initial Weight 155.3432
Increase = 0.0662

Moisture Content: Sample Vol. 42.22 ft.³ x 28.3 L/ft.³ = 1197.1 L Dry Gas

Water Weight 13.72 gm. x 24.1 L = 183.7 L H₂O Vapor

Total = 1380.8 L

H₂O Vol. 183.7 L x 100 = 13.3 %
Total 1380.8 L

ORSAT

TOTAL 137.23

IMPINGER 4 21.39

IMPINGER 3 4.24

IMPINGER 2 38.94

IMPINGER 1 150.54

N₂ 72.8

CO

O₂ 10

CO₂ 17.2

$K_a = 0.63$

PARTICULATE FIELD DATA

Run No. 43
Location Stack # 4
Date 9/27/79
Operator CHG/BWICE

Amb. Temp. °F 61.68
Bar. Press. "Hg. 28.90
Assumed Moist 14%
Test Periods 125 MIN

Probe Tip Dia., In. 1/4"
Probe Length 6'
Imp. Nos. 820
Sample Box No. 820

Heater Box Setting 280°F
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O	Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
				Desired	Actual	Inlet	Outlet						
B-1	08:48	367.72	0.23	0.48	0.48	75	76	0.0	268	78	260	397	
2	16	373.61	0.28	0.53	0.56	77	78	0.0	274	80	184	403	
3	24	376.70	0.28	0.53	0.58	77	78	0.0	274	84	279	407	
4	32	379.61	0.26	0.51	0.53	78	79	0.0	270	83	344	408	
5	40	382.02	0.19	0.44	0.52	78	80	0.0	237	82	397	405	
6	48	384.24	0.15	0.39	0.30	79	81	0.0	269	81	405	402	
7	56	386.25	0.12	0.31	0.24	80	82	0.0	262	83	401	394	10.34
8	11:04	387.99	0.09	0.30	0.18	81	83	0.0	251	87	404	392	
A-1	11:25/33	390.02	0.18	0.35	0.29	81	87	0.0	277	89	76	374	
2	41	392.43	0.17	0.34	0.35	82	84	0.0	287	84	78	403	
3	49	395.05	0.20	0.41	0.41	83	84	0.0	284	82	175	405	
4	57	397.73	0.20	0.46	0.44	84	86	0.0	286	82	220	412	
5	12:05	400.44	0.23	0.48	0.47	84	86	0.0	284	84	264	406	
6	13	403.32	0.25	0.50	0.51	84	87	0.0	290	82	388	401	
7	21	405.99	0.20	0.45	0.41	84	87	0.0	261	84	400	401	
8	29	408.36	0.19	0.44	0.34	86	88	0.0	255	87	404	402	
TOTAL				7.08	6.36	6.41	1298	1327				6413	
AVERAGE				0.443	0.398	0.401	81.1	82.97				100.8	

COPIED BY SAMPLE

Meter Volume

Dry Meter Calibration Factor

82°F

861.76

RUN NO. 43

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

IMPINGER 1 127.51

IMPINGER 2 16.80

IMPINGER 3 1.64

IMPINGER 4 22.19

TOTAL 144.31

ORSAT

CO₂ 17.2

O₂ 9.4

CO

N₂ 73.4

SOLID WEIGHT GAIN

BEAKER 27 0.0403

BEAKER 28 0.1816

BEAKER 29 0.2219

BEAKER 30 0.2397

TOTAL 0.2397

BEAKER 31 0.0178

BEAKER 32 0.0178

BEAKER 33 0.0178

BEAKER 34 0.0178

BEAKER 35 0.0178

BEAKER 36 0.0178

BEAKER 37 0.0178

IMPINGER NO. 69

IMPINGER NO. 70

IMPINGER NO. 71

IMPINGER NO. 72

FILTER NO. 32

BEAKER NO. 29

BEAKER NO. 30

BEAKER NO. 31

BEAKER NO. 32
PROBE WASH

Final Weight 664.35
Initial Weight 536.84
Increase

Final Weight 578.28
Initial Weight 561.48
Increase

Final Weight 477.31
Initial Weight 475.67
Increase

Final Weight 840.42
Initial Weight 817.93
Increase

Final Weight 0.5878
Initial Weight 0.7217
Part. Catch = 0.1816

Final Weight 144.3816
Initial Weight 144.7638
Increase = 0.0178

Final Weight
Initial Weight
Increase

Final Weight
Initial Weight
Increase

Final Weight 146.412
Initial Weight 146.3769
Increase = 0.0403

460 + Meter
592 Temp.

Moisture Content: Sample Vol. 40.40 ft.³ x 460 + 70 = 188.0 L DRY GAS

Water Weight 144.31 gm. x 24.1 L = 193.2 L H₂O Vapor

Total = 1311.2
H₂O Vol. 193.2 L x 100 = 14.7 %
Total 1311.2

$t_{m} = 0.714$

PARTICULATE FIELD DATA

Run No. 144
Location STARK #4
Date 9/27/79
Operator CHU/BLU

Amb. Temp. °F 67.83
Bar. Press. "Hg. 28.90
Assumed Moist 4%
Test Periods 125 MIN

Probe Tip Dia., In. 1/4"
Probe Length 6'
Imp. Nos.
Sample Box No.

Heater Box Setting 270°F
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O	Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
				AP	VP	Desired	Actual						
#-1	10:04/12	867.72	0.18	0.42	0.32	0.35	64	65	0.5	253	67	140	295
2	20	813.73	0.19	0.44	0.34	0.38	65	67	0.5	247	67	194	392
3	28	815.29	0.20	0.45	0.36	0.35	64	68	0.5	249	72	198	385
4	36	817.97	0.22	0.47	0.40	0.39	63	67	0.5	272	66	318	398
5	44	820.76	0.22	0.47	0.40	0.42	65	71	1.0	245	70	377	394
6	52	823.48	0.23	0.48	0.41	0.40	66	73	1.5	247	67	392	400
7	11:00	826.26	0.23	0.48	0.41	0.42	67	74	2.0	249	74	396	398
8	08	828.82	0.20	0.45	0.36	0.35	68	75	2.0	245	74	393	473
B-1	11:29/37	831.56	0.22	0.47	0.40	0.40	68	70	2.0	247	71	150	396
2	45	834.50	0.28	0.53	0.50	0.47	61	70	2.5	249	72	194	405
3	53	837.74	0.31	0.56	0.56	0.57	69	73	3.0	230	75	231	407
4	12:01	840.88	0.29	0.54	0.52	0.53	65	70	3.0	251	68	332	399
5	09	843.33	0.19	0.44	0.34	0.32	67	73	3.0	251	70	379	397
6	17	845.59	0.15	0.39	0.27	0.28	65	66	2.5	287	66	185	384
7	25	847.62	0.13	0.36	0.23	0.22	66	71	2.0	243	71	285	388
8	33	849.64	0.12	0.35	0.22	0.22	61	72	2.0	271	70	187	380
TOTAL													
AVERAGE													

COLLECTED SAMPLE VOLUME

Meter Volume

Dry Meter Calibration Factor

528°K

682°K

855°K

42.16

PARTICULATE & WATER CATCH

RUN NO. 177

Final Weight 702.49
Initial Weight 570.69
Increase

IMPINGER NO. 13

Final Weight 558.69
Initial Weight 515.51
Increase

IMPINGER NO. 14

Final Weight 462.31
Initial Weight 461.58
Increase

IMPINGER NO. 15

Final Weight 810.17
Initial Weight 787.94
Increase

IMPINGER NO. 16

Final Weight 0.880
Initial Weight 0.7065
Part. Catch = 0.1815

FILTER NO. 33

SOLID WEIGHT GAIN

0.0902

0.1815

0.2717

0.1077

0.3794 TOTAL

BEAKER 33 0.0547

BEAKER 3 0.2182

BEAKER 2 0.1777

BEAKER 33 0.0547

N₂ 73.4

CO₂ 9.4

CO₂ 17.2

ORSAT

TOTAL 167.94

IMPINGER 4 22.23

IMPINGER 3 0.73

IMPINGER 2 13.18

IMPINGER 1 131.8

BEAKER NO. 32
PROBE WASH

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO. 33

Final Weight 146.1934
Initial Weight 146.0857
Increase = 0.1077

Final Weight 147.1062
Initial Weight 147.0160
Increase = 0.0902

Moisture Content: Sample Vol. 42.16 ft.³ x 460 + 70 = 520
528 Temp. 528
X 28.3 L/ft.³ = 1472 L Dry Gas

Water Weight 147.94 gm.
x 24.1 L = 354.9 L H₂O Vapor
mol.

H₂O Vol. 224.9 L
Total 1472.1 L
x 100 = 15.8 %

Total = 1472.5 L

PARTICULATE FIELD DATA

Run No. 45
 Location Stark #1
 Date 9/29/79
 Operator CHU/BRUCE

Amb. Temp. °F 73.2
 Bar. Press. "Hg. 29.75
 Assumed Moist 14%
 Test Periods 120 min

Probe Tip Dia., In. 1/4"
 Probe Length 6"
 Imp. Nos. 6
 Sample Box No. 120 min

Heater Box Setting 200°F
 FILE IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O	Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
				Desired	Actual	Inlet	Outlet						
A-1	9:38/44	356.66	0.18	0.36	0.28	75	25	0.0	247	76	130	396	
2	9:44	361.17	0.16	0.40	0.35	76	26	0.0	228	76	205	405	
3	10:02	363.43	0.16	0.40	0.32	76	27	0.0	252	76	217	415	
4	10	365.67	0.15	0.39	0.31	77	29	0.0	238	75	262	407	
5	18	368.27	0.21	0.46	0.42	77	30	0.0	252	76	296	410	
6	26	370.98	0.18	0.42	0.37	76	31	0.0	286	71	405	407	
7	34	373.23	0.20	0.45	0.41	77	31	0.0	242	71	412	407	
8	42	375.22	0.10	0.32	0.21	77	32	0.0	294	77	406	397	+0.16
R-8	11:06/14	377.09	0.10	0.32	0.21	77	32	0.0	287	82	310	380	
7	25	379.21	0.14	0.37	0.29	77	32	0.0	282	82	279	404	
6	30	381.38	0.14	0.35	0.29	77	32	0.0	205	76	401	403	
5	38	383.60	0.15	0.39	0.31	78	31	0.0	253	79	413	410	
4	46	385.27	0.16	0.40	0.34	78	32	0.0	240	84	409	411	
3	54	388.27	0.16	0.40	0.34	78	33	0.0	274	80	379	411	
2	1:02	390.47	0.15	0.39	0.30	79	33	0.0	280	89	313	407	
1	10	392.42	0.11	0.33	0.24	79	33	0.0	257	89	219	401	
TOTAL		6.17	4.96	5.01	1233	1076						6966	
AVERAGE		0.386	0.310	0.313	77.1	79.8						404	

COMPUTER SAMPLE VOLUME

5380K 78.41F
 Meter Volume

Dry Meter Calibration Factor

3640K

3544

PARTICULATE & WATER CATCH

RUN NO. 45

Final Weight 677.18
Initial Weight 539.18
Increase

WATER WEIGHT GAIN

IMPINGER 1 138.00

IMPINGER 2 3.21

IMPINGER 3 0.44

IMPINGER 4 11.03

TOTAL 152.68

ORSAT

CO₂ 12.0

O₂ 13.6

CO —

N₂ 75.4

FACT #34

BEAKER 3 10.854

BEAKER 2 0.259

BEAKER 3 0.113

BEAKER 4 10.0654

TOTAL 176.4

BEAKER 5 10.0654

BEAKER 6 10.0654

BEAKER 7 10.0654

BEAKER 8 10.0654

BEAKER 9 10.0654

BEAKER 10 10.0654

BEAKER 11 10.0654

BEAKER 12 10.0654

BEAKER 13 10.0654

BEAKER 14 10.0654

BEAKER 15 10.0654

BEAKER 16 10.0654

BEAKER 17 10.0654

BEAKER 18 10.0654

BEAKER 19 10.0654

BEAKER 20 10.0654

BEAKER 21 10.0654

BEAKER 22 10.0654

BEAKER 23 10.0654

BEAKER 24 10.0654

BEAKER 25 10.0654

BEAKER 26 10.0654

BEAKER 27 10.0654

BEAKER 28 10.0654

BEAKER 29 10.0654

BEAKER 30 10.0654

BEAKER 31 10.0654

BEAKER 32 10.0654

BEAKER 33 10.0654

BEAKER 34 10.0654

BEAKER 35 10.0654

BEAKER 36 10.0654

BEAKER 37 10.0654

BEAKER 38 10.0654

BEAKER 39 10.0654

BEAKER 40 10.0654

BEAKER 41 10.0654

BEAKER 42 10.0654

BEAKER 43 10.0654

BEAKER 44 10.0654

BEAKER 45 10.0654

BEAKER 46 10.0654

BEAKER 47 10.0654

BEAKER 48 10.0654

BEAKER 49 10.0654

BEAKER 50 10.0654

BEAKER 51 10.0654

BEAKER 52 10.0654

BEAKER 53 10.0654

BEAKER 54 10.0654

BEAKER 55 10.0654

BEAKER 56 10.0654

BEAKER 57 10.0654

BEAKER 58 10.0654

BEAKER 59 10.0654

BEAKER 60 10.0654

BEAKER 61 10.0654

BEAKER 62 10.0654

BEAKER 63 10.0654

BEAKER 64 10.0654

BEAKER 65 10.0654

BEAKER 66 10.0654

BEAKER 67 10.0654

BEAKER 68 10.0654

BEAKER 69 10.0654

BEAKER 70 10.0654

BEAKER 71 10.0654

BEAKER 72 10.0654

BEAKER 73 10.0654

BEAKER 74 10.0654

BEAKER 75 10.0654

BEAKER 76 10.0654

BEAKER 77 10.0654

BEAKER 78 10.0654

BEAKER 79 10.0654

BEAKER 80 10.0654

BEAKER 81 10.0654

BEAKER 82 10.0654

BEAKER 83 10.0654

BEAKER 84 10.0654

BEAKER 85 10.0654

BEAKER 86 10.0654

BEAKER 87 10.0654

BEAKER 88 10.0654

BEAKER 89 10.0654

BEAKER 90 10.0654

BEAKER 91 10.0654

BEAKER 92 10.0654

BEAKER 93 10.0654

BEAKER 94 10.0654

BEAKER 95 10.0654

BEAKER 96 10.0654

BEAKER 97 10.0654

BEAKER 98 10.0654

BEAKER 99 10.0654

BEAKER 100 10.0654

BEAKER 101 10.0654

BEAKER 102 10.0654

BEAKER 103 10.0654

BEAKER 104 10.0654

BEAKER 105 10.0654

BEAKER 106 10.0654

BEAKER 107 10.0654

BEAKER 108 10.0654

BEAKER 109 10.0654

BEAKER 110 10.0654

BEAKER 111 10.0654

BEAKER 112 10.0654

BEAKER 113 10.0654

BEAKER 114 10.0654

BEAKER 115 10.0654

BEAKER 116 10.0654

BEAKER 117 10.0654

BEAKER 118 10.0654

BEAKER 119 10.0654

BEAKER 120 10.0654

BEAKER 121 10.0654

BEAKER 122 10.0654

BEAKER 123 10.0654

BEAKER 124 10.0654

BEAKER 125 10.0654

BEAKER 126 10.0654

BEAKER 127 10.0654

BEAKER 128 10.0654

BEAKER 129 10.0654

BEAKER 130 10.0654

BEAKER 131 10.0654

BEAKER 132 10.0654

BEAKER 133 10.0654

BEAKER 134 10.0654

BEAKER 135 10.0654

BEAKER 136 10.0654

BEAKER 137 10.0654

BEAKER 138 10.0654

BEAKER 139 10.0654

BEAKER 140 10.0654

BEAKER 141 10.0654

BEAKER 142 10.0654

BEAKER 143 10.0654

BEAKER 144 10.0654

BEAKER 145 10.0654

BEAKER 146 10.0654

BEAKER 147 10.0654

BEAKER 148 10.0654

BEAKER 149 10.0654

BEAKER 150 10.0654

BEAKER 151 10.0654

BEAKER 152 10.0654

BEAKER 153 10.0654

BEAKER 154 10.0654

BEAKER 155 10.0654

BEAKER 156 10.0654

BEAKER 157 10.0654

BEAKER 158 10.0654

BEAKER 159 10.0654

BEAKER 160 10.0654

BEAKER 161 10.0654

BEAKER 162 10.0654

BEAKER 163 10.0654

BEAKER 164 10.0654

BEAKER 165 10.0654

BEAKER 166 10.0654

BEAKER 167 10.0654

BEAKER 168 10.0654

BEAKER 169 10.0654

BEAKER 170 10.0654

BEAKER 171 10.0654

BEAKER 172 10.0654

BEAKER 173 10.0654

BEAKER 174 10.0654

BEAKER 175 10.0654

BEAKER 176 10.0654

BEAKER 177 10.0654

BEAKER 178 10.0654

BEAKER 179 10.0654

BEAKER 180 10.0654

BEAKER 181 10.0654

BEAKER 182 10.0654

BEAKER 183 10.0654

BEAKER 184 10.0654

BEAKER 185 10.0654

BEAKER 186 10.0654

BEAKER 187 10.0654

BEAKER 188 10.0654

BEAKER 189 10.0654

BEAKER 190 10.0654

BEAKER 191 10.0654

BEAKER 192 10.0654

BEAKER 193 10.0654

BEAKER 194 10.0654

BEAKER 195 10.0654

BEAKER 196 10.0654

BEAKER 197 10.0654

BEAKER 198 10.0654

BEAKER 199 10.0654

BEAKER 200 10.0654

BEAKER 201 10.0654

BEAKER 202 10.0654

BEAKER 203 10.0654

BEAKER 204 10.0654

BEAKER 205 10.0654

BEAKER 206 10.0654

BEAKER 207 10.0654

BEAKER 208 10.0654

BEAKER 209 10.0654

BEAKER 210 10.0654

BEAKER 211 10.0654

BEAKER 212 10.0654

BEAKER 213 10.0654

BEAKER 214 10.0654

BEAKER 215 10.0654

BEAKER 216 10.0654

BEAKER 217 10.0654

BEAKER 218 10.0654

BEAKER 219 10.0654

BEAKER 220 10.0654

BEAKER 221 10.0654

BEAKER 222 10.0654

BEAKER 223 10.0654

BEAKER 224 10.0654

BEAKER 225 10.0654

BEAKER 226 10.0654

BEAKER 227 10.0654

BEAKER 228 10.0654

BEAKER 229 10.0654

BEAKER 230 10.0654

BEAKER 231 10.0654

BEAKER 232 10.0654

BEAKER 233 10.0654

BEAKER 234 10.0654

BEAKER 235 10.0654

BEAKER 236 10.0654

BEAKER 237 10.0654

BEAKER 238 10.0654

BEAKER 239 10.0654

BEAKER 240 10.0654

BEAKER 241 10.0654

BEAKER 242 10.0654

BEAKER 243 10.0654

BEAKER 244 10.0654

BEAKER 245 10.0654

BEAKER 246 10.0654

BEAKER 247 10.0654

BEAKER 248 10.0654

BEAKER 249 10.0654

BEAKER 250 1

PARTICULATE FIELD DATA

Run No. 06
 Location Stack #1
 Date 9/29/79
 Operator Chad Bill

Amb. Temp. °F 68.08
 Bar. Press. "Hg. 28.73
 Assumed Moist 14%
 Test Periods 128 hr

Probe Tip Dia., In. 1/4"
 Probe Length 6'
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VAP	Desired	Actual	Inlet	Outlet						
B-1	9:42/50	474.10	0.12	0.35	0.25	0.20	57	77	0.0	274	75	123	397	
2	58	478.20	0.13	0.36	0.27	0.32	61	67	0.0	281	80	127	405	
3	10:06	479.18	0.15	0.39	0.31	0.06	65	69	0.0	197	82	150	409	
4	14	480.16	0.17	0.41	0.35	0.06	61	68	0.0	205	85	262	411	
5	22	482.44	0.18	0.42	0.37	0.49	63	70	0.5	299	86	260	412	
6	30	486.68	0.13	0.36	0.27	0.87	61	77	0.0	278	77	233	392	410
7	38	488.18	0.16	0.40	0.33	0.22	68	78	0.0	221	88	326	415	40.16
8	46	490.10	0.11	0.33	0.23	0.14	64	73	0.0	281	86	404	412	
A-1	11:04/18	492.32	0.11	0.33	0.23	0.30	64	68	0.0	287	77	190	399	
2	26	493.97	0.13	0.36	0.27	0.17	65	68	0.0	200	80	129	409	
3	34	495.97	0.15	0.39	0.31	0.25	65	70	0.0	209	82	145	410	
4	42	498.15	0.18	0.42	0.37	0.42	65	73	0.0	226	85	290	412	
5	50	501.20	0.20	0.45	0.41	0.42	70	79	0.0	234	87	361	413	
6	58	503.80	0.20	0.45	0.41	0.42	67	77	0.2	273	96	392	407	
7	12:06	506.42	0.22	0.47	0.45	0.42	65	75	0.0	258	94	400	405	
8	14	508.93	0.17	0.41	0.35	0.39	68	78	0.0	298	86	394	400	
TOTAL														
AVERAGE														

CO. TESTED BY PL. JUM
 Meter Volume 67.90
 Dry Meter Calibration Factor 86806
5280 R
352

RUN NO. 42

PARTICULATE & WATER CATCH

Final Weight 650.66

Initial Weight 547.31

Increase

IMPINGER NO. 81

IMPINGER NO. 82

Final Weight 588.80

Initial Weight 546.37

Increase

IMPINGER NO. 83

Final Weight 492.57

Initial Weight 478.85

Increase

IMPINGER NO. 84

Final Weight 803.32

Initial Weight 789.30

Increase

FILTER NO. 35

Final Weight 787.8

Initial Weight 704.0

Part. Catch

SOLID WEIGHT GAIN

0.838

Final Weight 144.5079

Initial Weight 144.4482

Increase

BEAKER NO. 2

Final Weight

Initial Weight

Increase

BEAKER NO.

Final Weight

Initial Weight

Increase

BEAKER NO.

BEAKER NO. 22

PROBE WASH

Final Weight 145.1725

Initial Weight 145.1380

Increase

Moisture Content: Sample Vol. 35.32 ft.³ x 460 + 70 = 16425.53

460 + Meter

Temp.

Water Weight 13.5 gm. x 24.1 L = 327.3 L H₂O Vapor

mol.

mol.

H₂O Vol 232.3 L x 100 = 15.8 %

Total = 1035.6 L

TOTAL 1860

BEAKER 0.00591

BEAKER 0.1263

BEAKER 0.495

BEAKER 22 0.838

BEAKER 2

Leche = 0.838

N₂ 75.4

CO -

O₂ 12.6

CO₂ 12.0

ORSAT

TOTAL 173.50

IMPINGER 4 14.02

IMPINGER 3 13.70

IMPINGER 2 02.93

IMPINGER 1 103.34

PARTICULATE FIELD DATA

Run No. 47
 Location Slick Hill
 Date 4/30/79
 Operator W. H. H. H. H. H.

Amb. Temp. °F 63.68
 Bar. Press. "Hg. 28.67
 Assumed Moist 14%
 Test Periods 128.4 min

Probe Tip Dia., In. 1/4"
 Probe Length 6'
 Imp. Nos. 81
 Sample Box No. 81

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In. H ₂ O	ΔP	Desired In. H ₂ O	Actual	Inlet	Outlet						
B-8	8:41.19	344.14	0.05	0.22	0.10	0.09	74	74	0.0	239	70	294	244	
7	8:47	347.34	0.10	0.32	0.21	0.25	75	76	0.0	258	72	337	385	
6	8:55	349.05	0.10	0.32	0.21	0.18	76	77	0.0	259	78	400	401	
5	8:59	351.14	0.13	0.36	0.27	0.27	76	78	0.0	255	73	407	396	
4	9:01	351.60	0.15	0.39	0.31	0.32	77	80	0.0	253	73	407	402	
3	9:07	357.71	0.15	0.39	0.31	0.30	77	81	0.0	233	72	381	393	10.11
2	9:15	359.59	0.10	0.32	0.29	0.29	78	83	0.0	232	71	309	387	
A-8	9:32.40	361.24	0.08	0.28	0.17	0.17	79	83	0.0	206	71	256	354	
7	9:48	363.28	0.13	0.36	0.27	0.26	79	81	0.0	267	80	250	382	
6	9:56	365.52	0.15	0.39	0.31	0.31	79	81	0.0	289	80	364	385	
5	10:04	367.78	0.15	0.39	0.31	0.32	79	82	0.0	268	76	396	378	
4	10:12	370.03	0.15	0.39	0.31	0.31	79	83	0.0	252	80	404	385	
3	10:20	372.17	0.14	0.37	0.29	0.28	81	84	0.0	253	73	380	397	
2	10:28	374.18	0.12	0.35	0.25	0.25	81	85	0.0	243	74	322	394	
1	10:36	376.03	0.10	0.32	0.21	0.21	81	85	0.0	251	73	212	379	
TOTAL														
AVERAGE														

453712 79.5°F

Meter Volume 89

Dry Meter Calibration Factor

896.8

CO FTB MPL D LUN

ft.

896.8

378

RUN NO. 47

PARTICULATE & WATER CATCH

Final Weight 667.30
Initial Weight 560.17
Increase

IMPINGER NO. 85

Final Weight 564.27
Initial Weight 554.92
Increase

IMPINGER NO. 86

Final Weight 458.03
Initial Weight 456.57
Increase

IMPINGER NO. 87

Final Weight 784.50
Initial Weight 771.22
Increase

IMPINGER NO. 88

Final Weight 795.5
Initial Weight 704.0
Part. Catch

FILTER NO. 36

SOLID WEIGHT GAIN

Final Weight 134.1458
Initial Weight 124.0791
Increase

BEAKER NO. 10

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 143.0691
Initial Weight 143.0217
Increase

BEAKER NO. 117
PROBE WASH

Moisture Content: Sample Vol. 31.78 ft.³ x 460 + 70 = 14600 + 70 = 14670
x 28.3 L/ft.³ = 884.4 L Dry Gas
460 + Meter
539 Temp.

Water Weight 130.7 gm.
18 gm.
mol.
x 24.1 L = 172.0 L H₂O Vapor
mol.

H₂O Vol. 175.0 L
Total 167.4
x 100 = 16.5%

PARTICULATE FIELD DATA

Run No. 48
 Location Stack #1
 Date 9/30/79
 Operator CHU/130E

Amb. Temp. °F 66.8
 Bar. Press. "Hg. 28.87"
 Assumed Moist 14%
 Test Periods 128 min

Probe Tip Dia., In. 1/8"
 Probe Length 6'
 Imp. Nos.
 Sample Box No.

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. $\frac{1}{2}$ "		Orifice ΔH		Dry Gas Temp. °F		Vac. In. $\frac{1}{2}$ "	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. $\frac{1}{2}$ "
			ΔP	$\sqrt{\Delta P}$	Desired	Actual	Inlet	Outlet						
A-1	8:15/23	512.12	0.12	0.35	0.25	0.29	55	56	0.0	247	50	49	359	
2	3/	516.29	0.15	0.39	0.31	0.30	59	61	0.0	240	50	46	347	
3	39	518.75	0.16	0.40	0.33	0.30	59	62	0.0	247	58	47	407	
4	47	521.15	0.17	0.41	0.35	0.35	57	61	0.0	261	58	47	408	
5	55	523.88	0.22	0.47	0.45	0.46	58	62	0.5	272	61	360	407	
6	9:03	526.58	0.22	0.47	0.45	0.45	57	61	0.5	243	64	388	403	10-19
7	11	529.28	0.22	0.47	0.45	0.45	58	61	1.0	238	62	393	399	
8	19	531.78	0.19	0.44	0.39	0.39	59	62	1.0	238	62	393	395	
R-1	9:36/44	533.91	0.18	0.39	0.31	0.28	60	61	0.0	280	51	166	389	
2	52	536.64	0.19	0.44	0.45	0.46	62	64	0.5	257	66	139	799	
3	10:00	539.35	0.19	0.44	0.45	0.45	63	65	0.5	271	67	149	401	
4	08	541.97	0.20	0.45	0.41	0.41	61	63	0.5	257	63	272	403	
5	16	544.33	0.18	0.42	0.37	0.34	58	71	0.5	229	74	361	401	
6	24	546.72	0.17	0.41	0.35	0.35	61	63	0.5	226	63	385	398	
7	32	548.95	0.15	0.39	0.31	0.31	61	62	0.5	207	59	392	394	
8	40	551.06	0.14	0.37	0.29	0.28	66	61	0.5	289	69	391	390	
TOTAL														
AVERAGE														

CO TTD PPL LUM
 Meter Volume 94 c. 3
 Dry Meter Calibration Factor 859.0
61.4
38.09

RUN NO. 48

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 686.93
Initial Weight 558.16
Increase

IMPINGER NO. 89

Final Weight 534.48
Initial Weight 533.26
Increase

IMPINGER NO. 90

Final Weight 460.35
Initial Weight 460.65
Increase

IMPINGER NO. 91

Final Weight 822.49
Initial Weight 800.52
Increase

IMPINGER NO. 92

Final Weight 805.5
Initial Weight 693.5
Part. Catch

FILTER NO. 37

SOLID WEIGHT GAIN

Final Weight 144.260
Initial Weight 144.2152
Increase 0.0448

BEAKER NO. 20

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 145.3164
Initial Weight 145.2609
Increase 0.0555

BEAKER NO. 36

Final Weight
Initial Weight
Increase

BEAKER NO.

IMPINGER 1 128.77

IMPINGER 2 27.22

IMPINGER 3 57.0

IMPINGER 4 21.97

ORSAT

CO₂ 12.0
O₂ 12.8

CO
N₂ 75.2

Final 111.5
BEAKER 36 0.0555
Total DM 167.08

BEAKER 20 0.0448

BEAKER 4
TOTAL 211.8

Moisture Content: Sample Vol. 39.49 ft.³ x 460 + 70
460 + Meter
X 28.3 L/ft.³ = 1136.9 L Dry Gas

130

460 + Meter
Temp.

Water Weight 171.6 gm. x 24.1 L = 237.9 L H₂O Vapor
18 gm. mol.

H₂O Vol. 237.9 L
Total
x 100 = 17.3 %

PARTICULATE FIELD DATA

Run No. 49
 Location 51mk #1
 Date 10/1/79
 Operator CHG/BRUCE

Amb. Temp. °F 65.103
 Bar. Press. "Hg. 28.59"
 Assumed Moist 14%
 Test Periods 1284/11

Probe Tip Dia., In. 1/4"
 Probe length 6'
 Imp. Nos. 81
 Sample Box No. 821

Heater Box Setting 250 °F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	√AP	Desired	Actual	Inlet	Outlet						
A-8	10:00/28	426.83	0.21	0.46	0.43	0.39	76	77	0.0	285	80	277	402	
7	16	432.51	0.26	0.51	0.54	0.62	76	77	0.0	296	82	298	406	
6	24	435.46	0.28	0.53	0.58	0.54	76	78	0.0	231	81	384	407	
5	32	438.36	0.26	0.51	0.54	0.52	76	79	0.0	272	82	389	411	
4	40	441.46	0.23	0.48	0.48	0.49	76	80	0.0	282	84	394	410	
3	48	443.80	0.21	0.46	0.43	0.43	76	81	0.0	238	79	382	403	
2	56	446.20	0.17	0.41	0.31	0.36	77	82	0.0	252	82	321	405	10.22
1	11:04	448.45	0.15	0.39	0.31	0.31	77	82	0.0	271	80	319	396	
R-8	11:21/29	450.72	0.15	0.39	0.31	0.32	78	81	0.0	283	82	334	393	
7	37	453.35	0.21	0.46	0.43	0.43	79	82	0.0	258	85	366	402	
6	45	455.96	0.21	0.46	0.43	0.42	79	82	2.5	268	161	391	405	
5	53	458.68	0.22	0.47	0.45	0.46	79	83	3.0	242	93	399	410	
4	12:01	461.62	0.27	0.52	0.56	0.53	81	86	9.0	285	91	399	413	
3	09	464.76	0.29	0.54	0.60	0.61	81	87	4.5	263	87	402	414	
2	17	467.65	0.24	0.49	0.50	0.52	81	88	3.5	253	88	384	409	
1	25	470.41	0.23	0.48	0.48	0.47	81	88	4.5	281	85	380	407	
TOTAL														
AVERAGE														

(58.0 °F) 80 °F

Meter Volume

Dry Meter Calibration Factor

(166.0)

CO TESTED MPLI LUM

58.0 °F

0.0

4 13

ft.

RUN NO. 49

PARTICULATE & WATER CATCH

Final Weight 1695.64
Initial Weight 549.65
Increase

NO. 93
IMPINGER

Final Weight 556.71
Initial Weight 542.85
Increase

NO. 94
IMPINGER

Final Weight 465.82
Initial Weight 465.14
Increase

NO. 95
IMPINGER

Final Weight 828.97
Initial Weight 810.01
Increase

NO. 96
IMPINGER

Final Weight 103.00
Initial Weight 7.088
Part. Catch

FILTER NO. 38

SOLID WEIGHT GAIN

Final Weight 145.9028
Initial Weight 145.8804
Increase

NO. 28
BEAKER

Final Weight
Initial Weight
Increase

NO. BEAKER

Final Weight
Initial Weight
Increase

NO. BEAKER

Final Weight 117.6683
Initial Weight 117.5776
Increase

NO. BEAKER
PROBE WASH

Moisture Content: Sample Vol. 43.43 ft.³ x 460 + 70 = 520
X 28.3 L/ft.³ = 1206.3 L Dry Gas

Water Weight 179.51 gm.
x 24.1 L = 240.3 L H₂O Vapor
mol.

H₂O Vol. 240.3 L
Total = 1446.6 L
x 100 = 16.6 %

IMPINGER 1 146.01

IMPINGER 2 13.86

IMPINGER 3 0.68

IMPINGER 4 18.96

TOTAL 179.51

ORSAT

CO₂ 15.4

O₂ 11.2

CO -

N₂ 73.4

BEAKER 1 521.2

BEAKER 2 090.7

BEAKER 3 411.9

BEAKER 4 022.4

TOTAL 4343

PARTICULATE FIELD DATA

Run No. 50
 Location Stack #1
 Date 10/1/79
 Operator CHW/BGB

Amb. Temp. °F 57.0
 Bar. Press. "Hg. 28.53
 Assumed Moist 14%
 Test Periods 128 Min

Probe Tip Dia., In. 1/4"
 Probe Length 6'
 Imp. Nos. 1
 Sample Box No. 1

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	In. H ₂ O	Actual	Inlet	Outlet						
1	10:04/12	554.70	0.22	0.48	0.48	0.47	58	61	0.0	303	70	82	400	
2	20	557.79	0.24	0.54	0.60	0.59	60	61	0.0	290	82	107	403	
3	28	561.00	0.31	0.56	0.64	0.64	62	65	0.0	286	84	198	408	
4	36	564.20	0.30	0.57	0.62	0.63	64	64	0.0	298	81	323	407	
5	44	567.22	0.25	0.52	0.52	0.56	59	63	0.0	295	80	386	408	
6	52	570.07	0.23	0.48	0.48	0.50	57	61	0.0	286	77	398	404	to 37
7	11:00	572.070	0.31	0.46	0.43	0.43	59	64	0.0	288	82	395	396	
8	08	575.11	0.18	0.42	0.37	0.36	61	65	0.0	294	85	389	389	
A-1	11:25/32	577.81	0.18	0.42	0.37	0.45	62	65	0.0	263	76	149	400	
2	41	580.20	0.20	0.45	0.42	0.44	64	68	0.0	269	71	131	405	
3	49	582.18	0.22	0.47	0.45	0.44	62	64	0.0	264	72	178	407	
4	57	585.81	0.25	0.50	0.52	0.53	64	65	0.5	299	81	298	409	
5	12:05	589.08	0.32	0.57	0.66	0.66	67	71	2.0	263	78	376	408	
6	13	592.24	0.30	0.55	0.62	0.62	64	68	2.0	253	76	335	406	
7	21	595.30	0.28	0.53	0.58	0.58	70	67	2.0	239	84	292	395	
8	29	598.12	0.23	0.48	0.48	0.49	61	64	2.0	261	71	399	397	
TOTAL														
AVERAGE														

(5240R) 63.8

Meter Volume

Dry Meter Calibration Factor

(1630R)

CO. L. TEL. MPL. JUN.

18

ft.

14

90.84

RUN NO. 50

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 718.11
Initial Weight 554.78
Increase

IMPINGER NO. 97

Final Weight 561.33
Initial Weight 532.60
Increase

IMPINGER NO. 98

Final Weight 448.89
Initial Weight 445.74
Increase

IMPINGER NO. 99

Final Weight 813.22
Initial Weight 785.92
Increase

IMPINGER NO. 100

Final Weight 1064.3
Initial Weight 703.8
Part. Catch

FILTER NO. 39

SOLID WEIGHT GAIN

Final Weight 143.6926
Initial Weight 143.6558
Increase

BEAKER NO. 18

0.0308

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 146.7151
Initial Weight 146.5244
Increase

BEAKER NO. 34
PROBE WASH

Moisture Content: Sample Vol. 46.84 ft.³ x 28.3 L/ft.³ = 1340.8 L Dry Gas

Water 218.17 gm. x 24.1 L = 2921 L H₂O Vapor
18 gm. mol.

H₂O Vol. 2921 L x 100 = 17.9%
Total 1632.9 L

BEAKER 1 2441.8605
BEAKER 2 34.1907
BEAKER 3 5512
BEAKER 4 0368
TOTAL 5880

ORSAT
CO₂ 15.4
O₂ 11.2
CO -
N₂ 73.4

IMPINGER 1 163.33
IMPINGER 2 23.69
IMPINGER 3 3.15
IMPINGER 4 28.00
TOTAL 218.17

PARTICULATE FIELD DATA

Run No. 51
 Location Stack #3
 Date 10/4/79
 Operator CHU/BRUCE

Amb. Temp. °F 53
 Bar. Press. "Hg. 28.62
 Assumed Moist 92%
 Test Periods 12:11:00

Probe Tip Dia., In. 1/4"
 Probe Length 6'
 Imp. Nos. 81
 Sample Box No. 128111

Heater Box Setting 20°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	Desired	Actual	Inlet	Outlet						
B-8	10:36/46	412.69	0.12	0.35	0.24	0.30	74	75	0.0	221	78	85	413	
7	44	419.52	0.13	0.36	0.26	0.30	75	76	0.0	272	81	87	419	
6	52	417.02	0.20	0.48	0.30	0.38	76	79	0.0	271	82	88	430	
5	11:00	419.57	0.21	0.46	0.41	0.40	76	78	0.0	240	81	88	431	
4	8	421.97	0.18	0.42	0.35	0.35	77	79	0.0	292	81	79	424	
3	16	424.20	0.15	0.39	0.30	0.30	78	81	0.0	283	80	341	417	12.12
2	24	426.15	0.13	0.36	0.26	0.26	79	81	0.0	246	80	320	413	
1	32	428.20	0.11	0.33	0.22	0.22	79	82	0.0	266	80	300	403	
A-8	11:47/55	430.32	0.13	0.36	0.26	0.27	82	83	0.0	270	82	104	409	
12	12:03	432.41	0.14	0.37	0.28	0.27	82	83	0.0	244	88	112	417	
11	11	434.73	0.20	0.45	0.39	0.39	82	83	0.0	270	89	104	421	
10	19	437.44	0.20	0.45	0.39	0.38	82	87	0.0	200	89	100	425	
9	27	439.77	0.17	0.42	0.37	0.33	83	87	0.0	241	90	89	421	
8	35	441.38	0.15	0.39	0.30	0.30	84	84	0.0	236	88	97	416	
7	43	444.05	0.13	0.36	0.26	0.26	84	86	0.0	209	88	92	411	
6	51	445.80	0.09	0.30	0.18	0.19	86	87	0.0	147	88	98	401	
TOTAL														
AVERAGE														

Leaks 100% 79.5
 Meter Volume 34
 Dry Meter Calibration Factor 877.2
 CON. TTD. PL. LUM. 31
 Ft. 31

RUN NO. 51

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

IMPINGER 1 132.48

IMPINGER 2 7.34

IMPINGER 3 8.74

IMPINGER 4 4.35

TOTAL 152.89

ORSAT

CO₂ 13.4

O₂ 13.0

CO -

N₂ 74.6

1194

BEAKER 5 .0632

BEAKER 2 1826

BEAKER 3

BEAKER 4 .0288

TOTAL 2114

Final Weight 696.73
Initial Weight 564.25
Increase

Final Weight 553.97
Initial Weight 546.63
Increase

Final Weight 443.84
Initial Weight 455.12
Increase

Final Weight 788.43
Initial Weight 784.08
Increase

Final Weight 8263
Initial Weight 7069
Part. Catch

Final Weight 112.9275
Initial Weight 142.8987
Increase

Final Weight
Initial Weight
Increase

Final Weight
Initial Weight
Increase

Final Weight 141.6737
Initial Weight 141.0105
Increase

Moisture Content: Sample Vol. 35.18 ft.³ x 460 = 16160 + Meter
x 28.3 L/ft.³ = 997.2 L Dry Gas

790 Temp.

Water Weight 52.89 gm. x 24.1 L = 1264.7 L H₂O Vapor

H₂O Vol. 204.7 L x 100 = 17.3%
Total 1181.9 L

IMPINGER NO. 1

IMPINGER NO. 2

IMPINGER NO. 3

IMPINGER NO. 4

FILTER NO. 40

BEAKER NO. 4

BEAKER NO.

BEAKER NO.

BEAKER NO. 5
PROBE WASH

0.674

Heater Box Setting
FILL IN ALL BLANKS
READ & RECORD AT THE
START OF EACH TEST
POINT

1827

RUN NO. 52

PARTICULATE & WATER CATCH

Final Weight 685.57
Initial Weight 526.70
Increase

IMPIINGER NO. 5

Final Weight 564.05
Initial Weight 557.04
Increase

IMPIINGER NO. 6

Final Weight 480.17
Initial Weight 479.30
Increase

IMPIINGER NO. 7

Final Weight 836.12
Initial Weight 825.68
Increase

IMPIINGER NO. 8

Final Weight 858.6
Initial Weight 709.1
Part. Catch

FILTER NO. 241

SOLID WEIGHT GAIN

Final Weight 135.4545
Initial Weight 135.4046
Increase

BEAKER NO. 3

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 142.1240
Initial Weight 142.0259
Increase

BEAKER NO. 15
PROBE WASH

Moisture Content: Sample Vol. 34.95 ft.³ x 460 + 70 460 + Meter 576 Temp.
X 28.3 L/ft.³ = 996.6 L Dry Gas

Water Weight 147.69 gm. x 24.1 L = 197.7 L H₂O Vapor
18 gm. mol.

Total = 1194.31
H₂O Vol. 197.7 L x 100 = 16.6 %
Total 1194.3

IMPIINGER 1 129.37
IMPIINGER 2 7.01
IMPIINGER 3 0.87
IMPIINGER 4 10.44
TOTAL 147.69
ORSAT

BEAKER 15 1495
BEAKER 2 2476
BEAKER 3 0499
TOTAL 2975
Wet Beaker 4

PARTICULATE FIELD DATA

Run No. 53
 Location Stick #3
 Date 10/11/79
 Operator John B. Bate

Amb. Temp. °F 43.5
 Bar. Press. "Hg. 28.55"
 Assumed Moist 14%
 Test Periods 128 min

Probe Tip Dia., In. 1/4"
 Probe Length 6'
 Imp. Nos.
 Sample Box No.

Heater Box Setting 370°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	Desired	Actual	Inlet	Outlet						
1	10:04/12	890.12	0.13	0.36	0.23	0.23	72	75	0.0	223	71	293	486	
2	20	892.26	0.14	0.37	0.25	0.25	73	76	0.0	248	72	291	436	
3	28	896.55	0.16	0.40	0.28	0.28	72	76	0.0	244	73	291	436	
4	36	896.84	0.17	0.41	0.30	0.31	72	77	0.0	243	73	373	438	
5	44	897.32	0.18	0.42	0.32	0.31	73	78	0.0	241	74	415	440	
6	52	901.55	0.16	0.40	0.28	0.27	73	79	0.0	247	77	424	441	10.10
7	11:00	903.54	0.13	0.36	0.23	0.21	72	78	0.0	253	79	423	423	
8	01	905.49	0.10	0.32	0.18	0.20	70	77	0.0	243	80	430	424	
A	11:22/30	907.45	0.12	0.35	0.21	0.21	73	75	0.0	234	67	185	425	
9	38	909.55	0.14	0.37	0.21	0.24	72	75	0.0	229	65	202	420	
10	46	911.83	0.16	0.40	0.28	0.28	71	75	0.0	232	60	272	427	
11	54	914.17	0.17	0.41	0.30	0.30	72	76	0.0	229	63	352	428	
12	12:02	916.39	0.16	0.40	0.28	0.27	71	77	0.0	223	63	401	423	
13	10	918.51	0.14	0.39	0.25	0.24	71	76	0.0	227	68	395	419	
14	18	920.56	0.12	0.35	0.21	0.23	71	75	0.0	226	60	476	421	
15	26	922.29	0.09	0.30	0.16	0.16	70	75	0.0	242	63	421	429	
TOTAL														
AVERAGE														

Broken glassware

5240R

74.1

Meter Volume

Dry Meter Calibration Factor

428920K

CO TESTED APPL. LUM.

2

3

3

3

3

RUN NO. 53

PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

Final Weight 691.43
Initial Weight 577.99
Increase

NO. 9
IMPINGER

Final Weight 558.55
Initial Weight 550.48
Increase

NO. 10
IMPINGER

Final Weight 463.97
Initial Weight 462.50
Increase

NO. 11
IMPINGER

Final Weight 832.55
Initial Weight 819.86
Increase

NO. 12
IMPINGER

Final Weight 838.6
Initial Weight 699.9
Part. Catch

NO. 13
FILTER

SOLID WEIGHT GAIN

Final Weight 154.2071
Initial Weight 137.1463
Increase

NO. 14
BEAKER

0.6608

Final Weight
Initial Weight
Increase

NO. 15
BEAKER

Final Weight
Initial Weight
Increase

NO. 16
BEAKER

Final Weight 142.3124
Initial Weight 142.2082
Increase

NO. 17
PROBE WASH

Moisture Content: Sample Vol. 24.43 ft.³ x 28.3 L/ft.³ = 697.1 L Dry Gas

460 + Meter
24 Temp.

Water Weight 175.67 gm. x 24.1 L = 181.6 L H₂O Vapor

H₂O Vol. 181.6 L x 100 = 15.8%
Total = 1148.7 L

PARTICULATE FIELD DATA

Run No. 54
 Location Stark #5
 Date 10/11/79
 Operator Chas. B. B.

Amb. Temp. °F 43° W3
 Bar. Press. "Hg. 45.08
 Assumed Moist 14%
 Test Periods 1286-1414

Probe Tip Dia., In. 1/4"
 Probe Length 6'
 Inp. Nos.
 Sample Box No.

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot In. H ₂ O		Orifice ΔH In. H ₂ O		Dry Gas Temp. °F		Vac. In. Hg	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			AP	VP	Desired	Actual	Inlet	Outlet						
A-8	10:00/08	450.56	0.13	0.36	0.26	0.23	61	67	0.0	277	257	240	436	
7	16	452.86	0.15	0.39	0.30	0.33	66	67	0.0	241	71	362	416	
6	22	455.19	0.17	0.41	0.34	0.33	66	68	0.0	249	73	388	417	
5	32	457.54	0.17	0.41	0.34	0.34	67	69	0.0	260	76	425	419	
4	40	459.95	0.18	0.42	0.36	0.35	68	69	0.0	260	73	403	422	
3	48	462.41	0.18	0.42	0.36	0.37	69	71	0.0	257	82	357	422	
2	56	464.48	0.13	0.36	0.26	0.26	70	72	0.0	246	88	249	399	10.06
1	11:04	466.47	0.12	0.35	0.24	0.24	71	72	0.0	249	84	191	402	
B-8	11:26/34	468.52	0.13	0.36	0.26	0.26	71	73	0.0	279	72	322	404	
7	42	470.71	0.15	0.39	0.30	0.29	73	74	0.0	241	75	389	413	
6	50	473.00	0.15	0.39	0.30	0.32	74	75	0.0	258	73	404	416	
5	58	475.41	0.18	0.42	0.36	0.35	74	74	0.0	273	72	409	418	
4	12:06	477.88	0.18	0.42	0.36	0.37	75	76	0.0	279	72	410	420	
3	14	480.04	0.14	0.37	0.28	0.28	75	77	0.0	245	70	353	418	
2	22	482.21	0.14	0.37	0.28	0.28	76	77	0.0	272	69	239	415	
1	30	484.15	0.11	0.33	0.22	0.23	76	77	0.0	231	67	185	405	
TOTAL														
AVERAGE														

CO. TED. MPL. LIME
 Meter Volume 71.9
 Dry Meter Calibration Factor 8750%
 31

RUN NO. 54

PARTICULATE & WATER CATCH

Final Weight 671.07
Initial Weight 560.07
WATER WEIGHT GAIN

IMPIINGER NO. 13

Final Weight 562.59
Initial Weight 516.65
Increase

IMPIINGER NO. 14

Final Weight 465.89
Initial Weight 461.85
Increase

IMPIINGER NO. 15

Final Weight 848.64
Initial Weight 833.01
Increase

IMPIINGER NO. 16

Final Weight 867.6
Initial Weight 708.8
Part. Catch

FILTER NO. 2943

SOLID WEIGHT GAIN

Final Weight 144.6390
Initial Weight 144.5905
Increase 0.485

BEAKER NO. 26

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 148.6712
Initial Weight 148.6308
Increase

BEAKER NO. 25
PROBE WASH

Moisture Content: Sample Vol. 35.39 ft.³ x 460 + 70
460 + Meter
X 28.3 L/ft.³ = 997.7 L Dry Gas

Water Weight 148.61 gm. x 24.1 L
18 gm. mol.
= 196.3 L H₂O Vapor

Total = 1194.1 L
H₂O Vol. 196.3 L x 100 = 16.4 %
Total 1194.1

PARTICULATE FIELD DATA

Run No. SS
 Location STACK #3
 Date 10/12/79
 Operator CHU/BAUCE

Amb. Temp. °F 50.6
 Bar. Press. "Hg. 28.49
 Assumed Moist 14%
 Test Periods 128 min

Probe Tip Dia., In. 1/4"
 Probe length 6'
 Imp. Nos.
 Sample Box No.

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			ΔP	√ΔP	In. H ₂ O	Desired	Inlet	Outlet						
A-1	10:04/12	923.25	0.12	0.35	0.21	0.22	74	75	0.0	210	82	185	415	
2	20	927.44	0.15	0.39	0.26	0.26	73	75	0.0	218	77	188	419	
3	28	929.79	0.17	0.41	0.32	0.32	73	77	0.0	215	78	263	424	
4	36	932.27	0.18	0.42	0.32	0.33	72	77	0.0	219	77	230	424	
5	44	934.53	0.16	0.40	0.28	0.28	71	77	0.0	232	77	365	425	
6	52	936.68	0.15	0.39	0.26	0.25	71	77	0.0	244	77	325	419	10.09
7	11:00	938.67	0.12	0.35	0.21	0.21	72	77	0.0	235	80	410	412	
8	08	940.51	0.11	0.33	0.19	0.18	72	77	0.0	246	92	413	412	
B-1	11:20/28	942.42	0.12	0.35	0.21	0.20	74	77	0.0	248	78	189	369	
2	36	944.59	0.14	0.37	0.25	0.25	75	77	0.0	172	77	275	435	
3	44	946.84	0.16	0.40	0.28	0.27	74	77	0.0	170	77	326	421	
4	52	948.23	0.17	0.41	0.30	0.31	73	78	0.0	157	74	362	410	
5	12:00	951.64	0.18	0.42	0.32	0.31	72	77	0.0	149	73	410	414	
6	8	953.84	0.15	0.39	0.26	0.26	73	78	0.0	132	74	413	413	
7	16	955.80	0.16	0.35	0.21	0.21	72	77	0.0	127	73	406	406	
Q	24	957.65	0.10	0.32	0.18	0.18	72	77	0.0	138	76	409	402	
TOTAL														
AVERAGE														

CO. TESTED PPL. LUM. 5350K 74.8°F
 Meter Volume 44 t. 3. 1 57
 Dry Meter Calibration Factor 876-R 34.6

RUN NO. 55

PARTICULATE & WATER CATCH

Final Weight 664.12 Initial Weight 547.81 Increase

IMPINGER NO. 17

Final Weight 549.71 Initial Weight 537.05 Increase

IMPINGER NO. 18

Final Weight 445.59 Initial Weight 445.09 Increase

IMPINGER NO. 19

Final Weight 826.15 Initial Weight 812.94 Increase

IMPINGER NO. 20

Final Weight 859.3 Initial Weight 703.0 Part. Catch

FILTER NO. 44

SOLID WEIGHT GAIN

Final Weight 141.0790 Initial Weight 141.0227 Increase 0.0563

BEAKER NO. 38

Final Weight Initial Weight Increase

BEAKER NO.

Final Weight Initial Weight Increase

BEAKER NO.

Final Weight 150.5275 Initial Weight 150.4903 Increase

BEAKER NO. 39 PROBE WASH

Moisture Content: Sample Vol. 34.60 ft.³ x 460 + 70 = 15840 + 70 = 15910

460 + Meter 535 Temp.

Water Weight 110.68 gm. x 24.1 L = 188.4 L H₂O Vapor

H₂O Vol. 188.4 L x 100 = 16.3% Total = 1158.4 L

IMPINGER 1 116.31

IMPINGER 2 10.66

IMPINGER 3 0.50

IMPINGER 4 13.21

TOTAL 140.68

ORSAT

CO₂ 15.4

O₂ 10.0

CO -

N₂ 74.6

Water 1563

BEAKER 1 0372

BEAKER 3 1935

BEAKER 380523

TOTAL 2498

PARTICULATE FIELD DATA

Run No. 56
 Location Stack #3
 Date 10/12/79
 Operator CHL/BAB

Amb. Temp. °F 50 WB
 Bar. Press. "Hg. 28.49"
 Assumed Moist 14.7%
 Test Periods 128 min

Probe Tip Dia., in 1/4"
 Probe Length 6'
 Imp. Nos.
 Sample Box No.

Heater Box Setting 250°F
 FILL IN ALL BLANKS
 READ & RECORD AT THE
 START OF EACH TEST
 POINT

Point	Clock Time	Dry Gas Meter C.F.	Pitot		Orifice ΔH		Dry Gas Temp. °F		Vac. In. Hg Gage	Box Temp. °F	Imp. Temp. °F	Probe Temp. °F	Stack Temp. °F	Stack Press. In. H ₂ O
			In. H ₂ O	ΔP	Desired In. H ₂ O	Actual	Inlet	Outlet						
B-8	10:00/68	485.02	0.12	0.25	0.24	0.27	73	74	0.0	257	73	405	403	
7	16	487.40	0.16	0.90	0.32	0.32	73	73	0.0	257	72	405	413	
6	20	491.71	0.18	0.42	0.36	0.35	73	74	0.0	237	81	412	419	
5	32	494.14	0.17	0.41	0.34	0.34	74	75	0.0	238	77	410	421	
4	40	496.58	0.18	0.42	0.36	0.26	74	75	0.0	202	81	409	423	
3	48	498.82	0.16	0.40	0.32	0.31	75	77	0.0	260	78	367	420	+0.11
2	56	500.91	0.13	0.36	0.26	0.27	76	78	0.0	228	83	262	418	
1	11:04	502.83	0.12	0.35	0.24	0.22	76	78	0.0	234	83	177	414	
A-8	11:24/32	504.96	0.14	0.37	0.28	0.28	78	79	0.0	244	82	353	406	
7	46	507.04	0.13	0.36	0.26	0.26	78	80	0.0	202	90	392	420	
6	48	509.32	0.16	0.40	0.32	0.32	78	80	0.0	267	87	405	411	
5	56	511.74	0.17	0.41	0.34	0.35	80	80	0.0	264	86	407	417	
4	12:04	514.17	0.18	0.42	0.36	0.37	80	82	0.0	250	90	404	419	
3	12	516.52	0.18	0.42	0.36	0.33	81	82	0.0	208	86	380	417	
2	20	518.75	0.15	0.39	0.30	0.30	81	82	0.0	239	87	298	415	
1	28	520.92	0.14	0.37	0.28	0.29	81	83	0.0	250	85	289	420	
TOTAL														
AVERAGE														

CO. 1120
 5380K 77.6
 Meter Volume
 Dry Meter Calibration Factor 8750K

RUN NO. 56
PARTICULATE & WATER CATCH

WATER WEIGHT GAIN

IMPINGER 1 118.44

IMPINGER 2 11.56

IMPINGER 3 0.77

IMPINGER 4 17.37

TOTAL

148.14

ORSAT

CO₂ 15.4

O₂ 10.0

CO -

N₂ 74.6

total 144.2

BEAKER 1

BEAKER 2 0.346

BEAKER 3 1.788

BEAKER 4 0.652

total wet total 244.0

Final Weight 688.29
Initial Weight 697.85
Increase

IMPINGER NO. 21

Final Weight 551.83
Initial Weight 540.27
Increase

IMPINGER NO. 22

Final Weight 465.25
Initial Weight 464.48
Increase

IMPINGER NO. 23

Final Weight 896.11
Initial Weight 828.74
Increase

IMPINGER NO. 24

Final Weight 254.8
Initial Weight 700.6
Part. Catch

FILTER NO. 45

Final Weight 139.2764
Initial Weight 139.2112
Increase

BEAKER NO. 37

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight
Initial Weight
Increase

BEAKER NO.

Final Weight 151.3757
Initial Weight 151.3411
Increase

BEAKER NO. 35
PROBE WASH

Moisture Content: Sample Vol. 35.73 ft.³ x 460 + 70 460 + Meter 1-38 Temp.
X 28.3 L/ft.³ = 996.1 L Dry Gas

Water Weight 48.1 gm. x 24.1 L = 1178.3 L H₂O Vapor
18 gm. mol.

H₂O Vol. 98.3 L x 100 = 16.6 %
Total 1174.4 L

II. Regulations

Source standards for stack particulate emissions applicable to the Roanoke Old Plant section (Kilns 1-4) are regulated by the Virginia State Air Pollution Control Board Regulation Part IV "Emission Standards for Particulate Emissions from Manufacturing Operations," Rule EX-4, Part 4.40 - Manufacturing Operations, Section (b) (8) Portland Cement Plants.

This rule limits particulate emissions to rates contained in Table 4.40A based on "Process Weight Rate."

Interpolation of the Table data for Process Weights up to 30 tons/hr is expressed by the formula:

$$E = 4.10 (P) 0.67$$

and for Process Weights in excess of 30 tons/hr by the formula:

$$E = 5.50 (P) 0.11 - 40$$

where E represents the allowable emission rate in lb./hr. and P the process weight in tons/hr.

"Process Weight" by definition is: "Total weight of all materials introduced into any source process unit which may cause any emission of pollutants. Process weight includes solid fuels charged, but does not include liquid and gaseous fuels charged or combustion air for all fuels."

Thus, for these test purposes, the "Process Weight" is the sum of the coal fuel rate and the kiln feed rate for each kiln. The following tabulation summarizes the average process weights, as listed in Table 3, and the compatible allowable emission rates for each kiln.

Stack No.	Coal T/H	Kiln Feed T/H	Process Weight T/H	Allowable Emission lb./Hr
1	3.4	21.2	24.6	35.1
2	2.8	21.6	24.4	34.8
3	3.0	27.9	30.9	40.2
4				

----- POSTPONED -----

In the case of the new No. 5 kiln, the State of Virginia requires compliance with the E.P.A. Standards of Performance for New Stationary Sources (40 CFR Part 60), Subpart F - Portland Cement Plants 40 CFR 60.60 thru 40 CFR 60.64. This regulation limits particulate emissions from any kiln to 0.3 lb. per ton of kiln feed (dry basis) and from any clinker cooler 0.1 lb. per ton of kiln feed (dry basis). Since the clinker cooler gases are emitted through the same stack, the allowable mass particulate emissions equate to 0.4 lbs. per ton of kiln feed (dry basis).

Therefore, at a kiln feed rate of 105 ton/hr. with a moisture content of 0.36%, the allowable emission rate for the No. 5 kiln is:

$$(105) (1-0.0036) (0.4) = 41.8 \text{ lbs/hr}$$

As designated in "Procedures for Emission Testing" dated April 21, 1977, Virginia State Regulations require extensive data concerning process parameters, testing equipment details and sampling procedures. To comply, details of process parameters, operating equipment specifications, and test equipment and procedures are presented in the following report sections.

V. Discussion of Results

Results of stack particulate emission test tabulated in Table I seem consistent and represent the conditions at hand during the course of testing. Since there were several runs on each stack during different days, all the results for each stack were consistently close to the average for the various stacks.

Since our last work at Roanoke, we have adapted as a testing standard the operation of two testing systems simultaneously at the same location. Accordingly, we were afforded a standard for measuring the quality of our results since, theoretically, the results of simultaneous test should be identical. Please note runs made on the same date were the simultaneous runs. Though results for simultaneous runs are never the same, they were, in our opinion, reasonably close for the most part.

In the interest of adding creditability to the test performed and lessen the probability of a built-in bias influencing the results determined by E.P.A. Method 5, please refer to Table 2 for direct comparison of Method 5 results with Lear Siegler opacity meter results which are tabulated in the last two columns. Though the correlation between results was not completely proportional, there was excellent agreement when it was considered L/S results were eyeball integrated to arrive at the averages tabulated.

Kiln No. 1, which averaged $\overline{28.4}$ lbs/hr. particulate emissions, was in compliance since the allowable was $\overline{35.1}$ lbs/hr. (see section of Regulations). One of the three days tested, emissions were abnormally high which brought the average up considerably. Accordingly, the average probably was biased to the high side.

