

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section 11.6
 Reference 27
 Report Sect. 4
 Reference 20

Source category:

Plant name :

Test date :

Process :

Portland Cement

Lehigh Portland Cement Company

2/17 - 2/18/83

dry

Date: 01/11/93

Location: Mason City, IO

Ref. No.: 20

Basis for process rate : feed

Basis for process rate : feed									
Source	Type of control	Pollutant	Run No.	Emission rate, lb/hr	Process rate, ton/hr	Emission factor		Volumetric flow rate, DSCFM	Concen %
						kg/Mg	lb/ton		
clinker cooler	fabric filter	BASED ON FEED RATE							
		filt. PM	1	2.71	136.4	0.00993	0.01987		
		filt. PM	2	1.03	139.2	0.00370	0.00740		
		filt. PM	3	0.98	138.1	0.00355	0.00710		
		AVERAG				0.0057	0.0115	RATING: B	
		CO2	1	124	136.4	0.454	0.909	60,400	0.03
		CO2	2	123	139.2	0.441	0.882	59,800	0.03
		CO2	3	124	138.1	0.449	0.897	60,400	0.03
		AVERAG				0.448	0.896	RATING: B	
		Notes:							
1. Data on kiln not useable due to lack of clarity and combined APCD's in process.									

Notes:

1. Data on kiln not useable due to lack of clarity and combined APCD's in parallel.

Interpoll Inc.
4500 Ball Road N.E.
Blaine, Minnesota 55014

Telephone (612) 786-6020
Telex 297095

**RESULTS OF THE FEBRUARY 17
AND 18, 1983 NSPS PARTICULATE EMISSION
COMPLIANCE TEST ON THE NO. 8 KILN
AT THE LEHIGH PORTLAND CEMENT PLANT
IN MASON CITY, IOWA**

Submitted to:

LEHIGH PORTLAND CEMENT COMPANY
P. O. Box 1068
Mason City, Iowa 50401

Attention: Mr. James Powell

Approved by:



Perry Lonnes, Ph.D.
President

Report Number 3-1466
March 22, 1983

TABLE OF CONTENTS

	ABBREVIATIONS	iii
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	4
3	RESULTS	8
	3.1 Results of Orsat and Moisture Analysis	9
	3.2 Results of Particulate Loading Determinations	16

APPENDICES:

- A - Results of Preliminary Measurements
- B - Location of Test Ports and Traverse Points
- C - Field Data Sheets
- D - Laboratory Data Sheets
- E - Iowa DEQ Air Pollution Control Equipment
Operating Data Sheets
- F - Iowa DEQ Cement Plant Operating Data Sheets
- G - Procedures
- H - Calculation Equations
- I - Sampling Train Calibration Data

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FT/SEC	feet per second
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g	gram
HP	horsepower
HRS	hours
IN.	inches
IN. HG.	inches of mercury
IN. WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
MW	megawatt
mg/DSCM	milligrams per dry standard cubic meter
microns (μm)	micrometer
MIN.	minutes
ohm-cm	ohm-centimeter
PPH	pounds per hour
PPM	parts per million
PSI	pounds per square inch
SQ. FT.	square feet
v/v	percent by volume
w/w	percent by weight

Standard conditions are defined as 68°F (20°C) and 29.92 in. of mercury pressure.

INTRODUCTION

On February 17 and 18, 1983, Interpoll Inc. personnel conducted an NSPS particulate emission test on the No. 8 Cement Kiln at the Lehigh Portland Cement Company Plant in Mason City, Iowa. On-site testing was performed by a four-man team under the direction of J. Stock. Coordination between testing activities and plant operation was provided by Bill Volk of Lehigh. The test was witnessed by Bill Youngquist and Gregg Cunningham of the Iowa Department of Environmental Quality (DEQ).

The No. 8 Cement Kiln is a continuous rotary kiln with a rated capacity of 130 TONS/HR. Particulates entrained in the process are collected by a baghouse and a Wheelabrator-Frye electrostatic precipitator operated in parallel. Feed to the No. 8 Kiln during the emission test remained essentially constant throughout the emission test. The approximate feed composition (by weight) was 78.6% limestone, 16.0% silica clay, 0.3% iron, 5.1% sand and 0.1% water. 87.4% of the feed passed a 200 mesh sieve. The feed rate ranged from 132 to 138 TONS/HR for the emission compliance test. The kiln was coal fired during the test.

Evaluations were conducted in accordance with EPA Methods 1-5, CFR title 40, Part 60, Appendix A (Revised July 1, 1982). The selection of the appropriate nozzle diameter required for isokinetic sampling was made based on the results of a previous test on the same unit. An Interpoll sampling train which meets or exceeds specifications in the above-cited reference was used to extract representative particulate samples by means of a heated glass-lined probe on the No. 8 Cooler Stack and the No. 7 and 11 Baghouse Outlets and a teflon-lined probe on the Main Stack (due to the large stack diameter).

An integrated flue gas sample was extracted simultaneously with each particulate sample using a specially designed gas sampling system. Integrated flue gas samples were collected in 44-liter Tedlar

bags. After sampling was complete, the bags were sealed and returned to the laboratory for Orsat analysis. The integrity of the sample bags was insured by reading the oxygen content of the bag in the field immediately after sampling and again in the laboratory immediately prior to Orsat analysis using a Teledyne 320P oxygen analyzer.

Testing on the No. 8 Kiln Clinker Cooler was conducted from four test ports oriented at 90 degrees on the stack. These ports are located approximately five diameters downstream of the breeching inlet of the eight-foot radial steel stack. The test ports are approximately 10.5 feet upstream of the stack outlet. A 32-point traverse was used to extract samples. Each traverse point was sampled 2.5 minutes to give a total sampling time of 80 minutes per run.


Exhaust gas streams from the No. 1, 2, 3 and 4 Baghouses on the No. 8 Kiln are combined in a common plenum and vented to the atmosphere by means of a 28-foot long, four-foot diameter radial steel stack. Two test ports located approximately 12 feet from a 45 degree elbow were used to extract particulate samples. The test ports are approximately 16 feet below the top of the stack. A 44-point traverse was used to collect particulate samples. Each traverse point was sampled two minutes to give a total sampling time of 88 minutes per run.

The stacks on the No. 7 and 11 Baghouses are identical and rest directly on top of the I.D. fans. Two ports oriented at approximately 120 degrees were used to collect representative particulate samples. The test ports are approximately six diameters downstream of the I.D. fan outlet and four diameters upstream of the stack outlet. A 24-point traverse was utilized on both sources to extract particulate samples. Each traverse point was sampled 2.5 minutes to give a total sampling time of 60 minutes per run.

Testing on the No. 8 Kiln Main Stack was conducted from two test ports oriented at 90 degrees on the stack and located more than two diameters upstream of the stack outlet and more than eight diameters

downstream of the last directional change in the stack (see Appendix B). A 12-point traverse was used to extract particulate samples. Each traverse point was sampled five minutes to give a total sampling time of 60 minutes per run.

The important results of the tests are summarized in Section 2. Detailed results are presented in Section 3. Results of preliminary measurements, field data and all other supporting information are presented in the appendices.



Summary of the Results
 of the Gas Test and
 the Gas Test

1000 ft
 Stack

Time of test (hrs)

Volumetric flow

ACTUAL (ACFM)

STANDARD (SCFM)

Gas feed rate (lb/hr)

Approximate Feed Composition

(% by weight)

Hydrogen

Water

Sand

Iron

Gas temperature (deg-F)

Moisture content (% v/v)

Gas composition (% v/v, dry)

Calorific value (Btu/lb)

Standard (Btu/lb)

Summary of the Results of the
Main Stack and the Main
Mason City Stack.

Main
Stack

Time of test (HRS)

Volumetric flow

ACTUAL (ACFM)
STANDARD (DSCFM)

Kiln feed rate (TONS/HR)

Approximate Feed Composition
(% by weight):

Limestone
Silica Clay
Water
Sand
Iron

Gas temperature (DEG-F)

Moisture content (% v/v)

Gas composition (% v/v, dry)
carbon dioxide
oxygen
nitrogen

Oxygen analyzer (% v/v, dry)

Isokinetic variation (%)

Particulate mass flow (LB/HR)

Particulate concentration

ACTUAL (GR/ACF)
STANDARD (GR/DSCF)

1000/1100

135000

135000

135000

135000

78.6

16.0

0.1

5.1

0.3

257

18.00

27.00

6.00

67.00

6.19

102.1

30.3

5.00

315

8.00

3.00

1.00

1.00

1.00

1.00

1.00

1.00

295

8.44

2.74

18.26

74.00

17.10

100.0

100.0

100.0

Summary of the Results of the
Main Stack and the No. 11
Magazine

No. 11
Stack

Time of test (HRS)

Volumetric flow

ACTUAL (ACFM)

STANDARD (DSCFM)

Kiln feed rate (TONS/HR)

Approximate feed Composition

(% by weight):

1. Moisture

2. Silicon

3. Water

4. Carbon

5. Iron

Gas temperature (DEG-F)

Moisture content (% v/v)

Gas composition (% v/v, dry)

carbon dioxide

oxygen

nitrogen

hydrogen and water

gas

fact

The results of all field and laboratory evaluations are presented in this section. Gas composition (Orsat and moisture) results are presented first, followed by the computer printout of particulate emission data. Preliminary measurements including traverse point description are given in Appendices A and B.

The results have been calculated on a DEC PDP-11 Computer using standard Fortran programs. EPA-published equations have been used as the basis of the calculation techniques in these programs. It should be noted in interpreting these results that the particulate emission rates have been calculated by both the "concentration x flow" and the "ratio of areas" methods and the average reported. The average is the best estimate of the true value, since the bias introduced by anisokinetic sampling is approximately equal but of opposite sign in the two calculation techniques and thus cancels in the average.

3.1 Results of Orsat and Moisture Analysis

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 1
No. 8 Kiln Cooler Stack

Results of Orsat & Moisture Analysis -- Methods 3 & 4 (% v/v)

	Run 1	Run 2	Run 3
Date of run	02/17/83	02/17/83	02/17/83
Dry basis (orsat)			
carbon dioxide	.03	.03	.03
oxygen	20.90	20.90	20.90
carbon monoxide	.00	.00	.00
nitrogen	79.07	79.07	79.07
Wet basis (orsat)			
carbon dioxide	.03	.03	.03
oxygen	20.34	20.39	20.36
carbon monoxide	.00	.00	.00
nitrogen	76.93	77.14	77.03
Moisture content	2.70	2.44	2.58
Dry molecular weight	28.84	28.84	28.84
Wet molecular weight	28.55	28.58	28.56
Specific gravity (relative to air)	.9861	.9871	.9866
Teledyne oxygen analyzer (velocity & time weighted avgs.)	20.90	20.90	20.90

FD .00 .00 .00

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 1
No. 1-4 Baghouse Outlet

Results of Orsat & Moisture Analysis -- Methods 3 & 4 (% v/v)

	Run 1	Run 2	Run 3
Date of run	02/17/83	02/17/83	02/17/83
Dry basis (orsat)			
carbon dioxide	3.40	4.00	4.00
oxygen	17.60	17.60	17.40
carbon monoxide	.00	.00	.00
nitrogen	79.00	78.40	78.60
Wet basis (orsat)			
carbon dioxide	3.09	3.61	3.65
oxygen	15.97	15.91	15.88
carbon monoxide	.00	.00	.00
nitrogen	71.67	70.85	71.75
Moisture content	9.28	9.63	8.72
Dry molecular weight	29.25	29.34	29.34
Wet molecular weight	28.20	28.25	28.35
Specific gravity (relative to air)	.9742	.9759	.9792
Teledyne oxygen analyzer (velocity & time weighted avs.)	17.09	17.19	17.15

FD .97 .82 .88

Test No. 2
 No. 8 Main Stack

Results of Orsat & Moisture Analysis -- Methods 3 & 4 (% v/v)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Dry basis (orsat)			
carbon dioxide	27.00	27.40	27.60
oxygen	6.00	6.60	5.90
carbon monoxide	.00	.00	.00
nitrogen	67.00	66.00	66.50
Wet basis (orsat)			
carbon dioxide	22.14	22.23	22.44
oxygen	4.92	5.35	4.80
carbon monoxide	.00	.00	.00
nitrogen	54.94	53.54	54.06
Moisture content	18.00	18.88	18.71
Dry molecular weight	32.56	32.65	32.65
Wet molecular weight	29.94	29.88	29.91
Specific gravity (relative to air)	1.0342	1.0322	1.0332
Teledyne oxygen analyzer (velocity & time weighted avg.)			
	6.19	6.15	6.19

FO	.55	.52	.54
----	-----	-----	-----

Test No. 2
 No. 7 Bashouse Outlet

Results of Orsat & Moisture Analysis -- Methods 3 & 4 (% v/v)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Dry basis (orsat)			
carbon dioxide	3.60	2.80	2.74
oxygen	17.60	18.40	18.26
carbon monoxide	.00	.00	.00
nitrogen	78.80	78.80	79.00
Wet basis (orsat)			
carbon dioxide	3.31	2.55	2.51
oxygen	16.18	16.74	16.72
carbon monoxide	.00	.00	.00
nitrogen	72.43	71.67	72.34
Moisture content	8.08	9.05	8.44
Dry molecular weight	29.28	29.18	29.17
Wet molecular weight	28.37	28.17	28.23
Specific gravity (relative to air)	.9799	.9731	.9750
Teledyne oxygen analyzer (velocity & time weighted avg.)	17.41	18.25	17.70

FD .92 .89 .96

Test No. 3
No. 8 Main Stack

Results of Orsat & Moisture Analysis -- Methods 3 & 4 (% v/v)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Dry basis (orsat)			
carbon dioxide	27.40	27.00	27.60
oxygen	6.60	7.00	6.40
carbon monoxide	.00	.00	.00
nitrogen	66.00	66.00	66.00
Wet basis (orsat)			
carbon dioxide	22.36	22.19	22.66
oxygen	5.39	5.75	5.26
carbon monoxide	.00	.00	.00
nitrogen	53.87	54.24	54.20
Moisture content	18.39	17.82	17.89
Dry molecular weight	32.65	32.60	32.67
Wet molecular weight	29.95	30.00	30.05
Specific gravity (relative to air)	1.0347	1.0362	1.0379
Teledyne oxygen analyzer (velocity & time weighted avg.)	6.15	6.23	6.17
FD	.52	.51	.53

Interpoll Report No. 3-1466
 Lehigh Portland Cement Company
 Mason City, Iowa

Test No. 3
 No. 11 Baghouse Outlet

Results of Orsat & Moisture Analysis -- Methods 3 & 4 (% v/v)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Dry basis (orsat)			
carbon dioxide	3.19	3.55	3.01
oxygen	17.80	17.89	18.12
carbon monoxide	.00	.00	.00
nitrogen	79.01	78.56	78.87
Wet basis (orsat)			
carbon dioxide	2.91	3.25	2.75
oxygen	16.21	16.36	16.57
carbon monoxide	.00	.00	.00
nitrogen	71.95	71.84	72.11
Moisture content	8.93	8.56	8.57
Dry molecular weight	29.22	29.28	29.21
Wet molecular weight	28.22	28.32	28.25
Specific gravity (relative to air)	.9748	.9782	.9757
Teledyne oxygen analyzer (velocity & time weighted avg.)			
	17.53	17.36	17.43

FO .97 .85 .92

3.2 Results of Particulate Loading Determinations

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 1
No. 8 Kiln Cooler Stack

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/17/83	02/17/83	02/17/83
Time run start/end (HRS)	1000/1123	1220/1350	1425/1550
Pitot tube coefficient	.853	.853	.853
Water in sample			
condensate (ml)	18.0	14.0	13.0
silica gel (grams)	11.0	13.0	14.0
Total particulate material collected (grams) *	.0167	.0066	.0063
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions...(CF)	49.30	51.03	51.46
standard conditions...(SCF)	49.20	50.81	51.60
Total sampling time (MIN)	80.0	80.0	80.0
Nozzle diameter (IN)	.310	.310	.310
Average stack gas temperature during determination (DEG-F)	193	214	214
Volumetric flow			
actual.....(CFM)	79960	81488	82386
standard.....(DSCFM)	60398	59801	60440
Isokinetic variation (%)	97.6	101.8	102.3
Particle concentration			
actual.....(GR/ACF)	.0040	.0015	.0014
dry standard.....(GR/DSCF)	.0052	.0020	.0019
Particle mass flow (LB/HR)	2.71	1.03	.98

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 1
No. 1-4 Baghouse Outlet

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/17/83	02/17/83	02/17/83
Time run start/end (HRS)	1000/1132	1225/1356	1425/1557
Pitot tube coefficient	.857	.857	.857
Water in sample			
condensate (ml)	115.0	118.0	112.0
silica gel (grams)	47.0	44.0	31.5
Total particulate material collected (grams) *	.1582	.1389	.1536
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions...(CF)	74.18	73.18	72.95
standard conditions...(SCF)	74.58	71.61	70.74
Total sampling time (MIN)	88.0	88.0	88.0
Nozzle diameter (IN)	.254	.254	.254
Average stack gas temperature during determination (DEG-F)	320	335	343
Volumetric flow			
actual.....(CFM)	53031	52229	52013
standard.....(DSCFM)	31342	30179	30035
Isokinetic variation (%)	96.8	96.5	95.8
Particle concentration			
actual.....(GR/ACF)	.0194	.0174	.0194
dry standard.....(GR/DSCF)	.0327	.0299	.0335
Particle mass flow (LB/HR)	8.79	7.74	8.63

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 2
No. 8 Main Stack

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Time run start/end (HRS)	1000/1101	1138/1239	1336/1437
Pitot tube coefficient	.856	.856	.856
Water in sample			
condensate (ml)	175.0	182.0	186.0
silica gel (grams)	16.0	21.1	18.9
Total particulate material collected (grams) *	.1538	.1524	.1634
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions...(CF)	41.86	42.12	43.39
standard conditions...(SCF)	40.96	41.09	41.92
Total sampling time (MIN)	60.0	60.0	60.0
Nozzle diameter (IN)	.246	.246	.246
Average stack gas temperature during determination (DEG-F)	257	256	257
Volumetric flow			
actual.....(CFM)	135110	135648	137246
standard.....(DSCFM)	76997	76584	77505
Isokinetic variation (%)	102.1	102.9	103.8
Particle concentration			
actual.....(GR/ACF)	.0332	.0324	.0341
dry standard.....(GR/DSCF)	.0579	.0572	.0601
Particle mass flow (LB/HR)	38.24	37.57	39.96

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 2
No. 7 Baghouse Outlet

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Time run start/end (HRS)	1000/1101	1138/1238	1336/1438
Pitot tube coefficient	.848	.848	.848
Water in sample			
condensate (ml)	61.0	40.0	66.0
silica gel (grams)	9.0	20.0	20.0
Total particulate material collected (grams) *	.0102	.0192	.0211
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions...(CF)	38.15	29.45	46.10
standard conditions...(SCF)	37.47	28.41	43.96
Total sampling time (MIN)	60.0	60.0	60.0
Nozzle diameter (IN)	.188	.188	.254
Average stack gas temperature during determination (DEG-F)	317	308	295
Volumetric flow			
actual.....(CFM)	19582	14685	12253
standard.....(DSCFM)	11687	8774	7503
Isokinetic variation (%)	100.2	101.2	100.3
Particle concentration			
actual.....(GR/ACF)	.0025	.0063	.0046
dry standard.....(GR/DSCF)	.0042	.0104	.0074
Particle mass flow (LB/HR)	.42	.78	.48

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 3
No. 8 Main Stack

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Time run start/end (HRS)	1527/1628	1644/1746	1800/1902
Pitot tube coefficient	.856	.856	.856
Water in sample			
condensate (ml)	177.0	173.0	180.0
silica gel (grams)	21.6	18.7	14.1
Total particulate material collected (grams) *	.1440	.1702	.1573
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions...(CF)	42.85	42.31	42.27
standard conditions...(SCF)	41.50	41.62	41.95
Total sampling time (MIN)	60.0	60.0	60.0
Nozzle diameter (IN)	.246	.246	.246
Average stack gas temperature during determination (DEG-F)	260	260	251
Volumetric flow			
actual.....(CFM)	136094	136441	135109
standard.....(DSCFM)	76800	77531	77755
Isokinetic variation (%)	103.7	103.0	103.5
Particle concentration			
actual.....(GR/ACF)	.0303	.0360	.0334
dry standard.....(GR/DSCF)	.0535	.0631	.0579
Particle mass flow (LB/HR)	35.24	41.93	38.56

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 3
No. 11 Beshouse Outlet

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Time run start/end (HRS)	1527/1631	1644/1746	1800/1803
Pitot tube coefficient	.848	.848	.848
Water in sample			
condensate (ml)	86.0	96.0	76.0
silica gel (grams)	25.0	17.0	20.0
Total particulate material collected (grams) *	.2226	.1924	.2064
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions... (CF)	55.74	59.27	49.97
standard conditions... (SCF)	53.30	56.86	48.20
Total sampling time (MIN)	60.0	60.0	60.0
Nozzle diameter (IN)	.254	.254	.254
Average stack gas temperature during determination (DEG-F)	289	272	279
Volumetric flow			
actual..... (CFM)	14691	15201	13065
standard..... (DSCFM)	9011	9585	8156
Isokinetic variation (%)	101.2	101.5	101.1
Particle concentration			
actual..... (GR/ACF)	.0397	.0331	.0414
dry standard..... (GR/DSCF)	.0644	.0522	.0661
Particle mass flow (LB/HR)	4.98	4.29	4.62

* Dry Catch Only

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 3
No. 11 Bashouse Outlet

Results of Particulate Loading Determinations -- Method 5(BE)

	Run 1	Run 2	Run 3
Date of run	02/18/83	02/18/83	02/18/83
Time run start/end (HRS)	1527/1631	1644/1746	1800/1803
Pitot tube coefficient	.848	.848	.848
Water in sample			
condensate (ml)	86.0	96.0	76.0
silica gel (grams)	25.0	17.0	20.0
Total particulate material collected (grams) *	.2226	.1924	.2064
Meter correction coefficient	1.0014	1.0014	1.0014
Volume through gas meter			
at meter conditions...(CF)	55.74	59.27	49.97
standard conditions...(SCF)	53.30	56.86	48.20
Total sampling time (MIN)	60.0	60.0	60.0
Nozzle diameter (IN)	.254	.254	.254
Average stack gas temperature during determination (DEG-F)	289	272	279
Volumetric flow			
actual.....(CFM)	14691	15201	13065
standard.....(DSCFM)	9011	9585	8156
Isokinetic variation (%)	101.2	101.5	101.1
Particle concentration			
actual.....(GR/ACF)	.0397	.0331	.0414
dry standard.....(GR/DSCF)	.0644	.0522	.0660
Particle mass flow (LB/HR)	4.98	4.29	4.62

APPENDIX A

RESULTS OF PRELIMINARY MEASUREMENTS

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 1
No. 8 Kiln Cooler Stack

Results of Flow Determination -- Method 2

Time and date	0900 hrs, 02/17/83
Barometric pressure (uncompensated, in. Hg)	28.80
Pitot tube coefficient	.853
Number of sampling ports	4
Total number of points sampled	32
Duct or stack diameter (IN)	96.0
Cross sectional area (SQ FT)	50.26
Direction of flow	vertical, up
Static pressure (IN WC)	-.300
Average gas temperature (DEG-F)	150
Absolute gas pressure (IN HG)	28.78
Average moisture content (% v/v)	2.57
Actual gas density (LB/ACF)	.062
Average linear velocity (FT/SEC)	24.9
(standard deviation, FT/SEC)	2.0
Volumetric flow	
actual (ACFM)	75213
dry standard (DSCFM)	60981
Mass flow of gas - wet (LB/HR)	278630

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 1
No. 8 Kiln Cooler Stack

Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FPS/SEC)
------------	----------------------------	------------------------------

A/ 1	150	24.3
A/ 2	150	25.9
A/ 3	150	25.1
A/ 4	150	25.1
A/ 5	150	25.9
A/ 6	150	27.4
A/ 7	150	23.5
A/ 8	150	22.7

B/ 1	150	25.1
B/ 2	150	26.7
B/ 3	150	27.4
B/ 4	150	27.4
B/ 5	150	30.8
B/ 6	150	28.1
B/ 7	150	25.1
B/ 8	150	24.3

C/ 1	150	21.8
C/ 2	150	23.5
C/ 3	150	25.1
C/ 4	150	25.1
C/ 5	150	26.7
C/ 6	150	25.9
C/ 7	150	25.1
C/ 8	150	24.3

D/ 1	150	22.7
D/ 2	150	22.7
D/ 3	150	21.8
D/ 4	150	23.5
D/ 5	150	23.5
D/ 6	150	23.5
D/ 7	150	24.3
D/ 8	150	23.5

Test No. 2
No. 8 Main Stack

Results of Flow Determination -- Method 2

Time and date	1000 May 18/67
Barometric pressure (inches Hg)	29.92
Pitot tube coefficient	0.955
Number of sampling points	2
Total number of points sampled	2
Duct or stack diameter (IN)	36
Cross sectional area (SQ FT)	3.14
Direction of flow	vertical, up
Static pressure (IN WC)	-1.10
Average gas temperature (DEG-F)	257
Absolute gas pressure (IN HG)	28.25
Average moisture content (% v/v)	18.53
Actual gas density (LB/ACF)	.054
Average linear velocity (FT/SEC)	59.2
(standard deviation, FT/SEC)	1.9
Volumetric flow	
actual (ACFM)	135169
dry standard (DSCFM)	76535
Mass flow of gas - wet (LB/HR)	437934

Test No. 2
No. 8 Main Stack

Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FT/SEC)

A/ 1	256	56.3
A/ 2	256	56.3
A/ 3	256	40.6
A/ 4	257	59.5
A/ 5	259	60.3
A/ 6	260	58.5
B/ 1	256	58.3
B/ 2	256	58.3
B/ 3	257	58.3
B/ 4	256	61.7
B/ 5	258	62.5
B/ 6	258	60.3

Test No. 3
No. 8 Main Stack

Results of Flow Determination -- Method 2

Time and date	1527 hrs. 02/19/83
Barometric pressure (uncompensated, in. Hg)	28.26
Pitot tube coefficient	.855
Number of sampling ports	2
Total number of points sampled	12
Duct or stack diameter (IN)	83.5
Cross sectional area (SQ FT)	38.03
Direction of flow	vertical, up
Static pressure (IN WC)	-.110
Average gas temperature (DEG-F)	260
Absolute gas pressure (IN HG)	28.25
Average moisture content (% v/v)	18.03
Actual gas density (LB/ACF)	.054
Average linear velocity (FT/SEC)	59.6
(standard deviation, FT/SEC)	3.6
Volumetric flow	
actual (ACFM)	135989
dry standard (DSCFM)	77075
Mass flow of gas - wet (LB/HR)	439655

Test No. 3
No. 8 Main Stack

Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FT/SEC)
------------	----------------------------	-----------------------------

A/ 1	259	53.5
A/ 2	260	58.4
A/ 3	262	60.4
A/ 4	262	61.9
A/ 5	261	62.2
A/ 6	262	62.2
B/ 1	259	56.4
B/ 2	261	58.4
B/ 3	261	60.3
B/ 4	261	60.3
B/ 5	262	61.9
B/ 6	259	59.8

Test No. 1
No. 1-4 Baghouse Outlet

Results of Flow Determination -- Method 2

Time and date	1000 hrs, 02/17/83
Barometric pressure (uncompensated, in. Hg)	28.83
Pitot tube coefficient	.857
Number of sampling ports	2
Total number of points sampled	44
Duct or stack diameter (IN)	48.0
Cross sectional area (SQ FT)	12.57
Direction of flow	vertical, up
Static pressure (IN WC)	.030
Average gas temperature (DEG-F)	320
Absolute gas pressure (IN HG)	28.83
Average moisture content (% v/v)	9.21
Actual gas density (LB/ACF)	.048
Average linear velocity (FT/SEC)	70.3
(standard deviation, FT/SEC)	9.9
Volumetric flow	
actual (ACFM)	52970
dry standard (DSCFM)	31330
Mass flow of gas - wet (LB/HR)	152033

Interpoll Report No. 3-1466
 Lehigh Portland Cement Company
 Mason City, Iowa

Test No. 1
 No. 1-4 Boshouse Outlet

Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FT/SEC)

A/ 1	280	74.5
A/ 2	294	73.9
A/ 3	321	78.5
A/ 4	319	78.4
A/ 5	324	70.0
A/ 6	324	70.0
A/ 7	338	67.6
A/ 8	325	46.4
A/ 9	321	78.5
A/10	311	78.0
A/11	307	81.0
A/12	302	77.6
A/13	313	71.3
A/14	311	63.7
A/15	344	63.0
A/16	340	66.9
A/17	340	76.1
A/18	340	79.5
A/19	330	82.2
A/20	333	88.5
A/21	340	82.7
A/22	341	51.3
B/ 1	300	70.7
B/ 2	330	75.6
B/ 3	337	82.6
B/ 4	346	86.2
B/ 5	346	72.8
B/ 6	341	68.9
B/ 7	345	69.0
B/ 8	345	69.0
B/ 9	295	77.2
B/10	287	76.8
B/11	310	81.2
B/12	310	71.2
B/13	315	65.8
B/14	315	57.6
B/15	310	57.4
B/16	311	59.6

Test No. 1
No. 1-4 Baghouse Outlet

Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FT/SEC)

B/17	50.0	39.5
B/18	50.0	39.5
B/19	50.0	39.5
B/20	50.0	39.5
B/21	50.0	55.5
B/22	50.0	39.5

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Test No. 2
No. 7 Baghouse Outlet

Results of Flow Determination -- Method 2

Time and date	1000 hrs, 02/18/83
Barometric pressure (uncompensated, in. Hg)	28.61
Pitot tube coefficient	0.848
Number of sampling ports	2
Total number of points sampled	24
Duct or stack diameter (IN)	25.8
Cross sectional area (SQ FT)	3.62
Direction of flow	vertical, down
Static pressure (IN WC)	3.300
Average gas temperature (DEG-F)	317
Absolute gas pressure (IN HG)	28.63
Average moisture content (% v/v)	8.52
Actual gas density (LB/ACF)	0.048
Average linear velocity (FT/SEC)	90.4
(standard deviation, FT/SEC)	11.1
Volumetric flow	
actual (ACFM)	19624
dry standard (DSCFM)	11456
Mass flow of gas - wet (LB/HR)	56115

Test No. 2
No. 7 Baghouse Outlet

Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FT/SEC)

A/ 1	310	88.1
A/ 2	318	88.6
A/ 3	318	92.7
A/ 4	318	91.1
A/ 5	318	98.0
A/ 6	319	100.6
A/ 7	318	76.3
A/ 8	318	100.6
A/ 9	322	100.8
A/10	322	100.8
A/11	322	105.8
A/12	325	106.0
B/ 1	310	67.9
B/ 2	313	77.7
B/ 3	315	88.4
B/ 4	318	92.7
B/ 5	318	92.7
B/ 6	318	65.2
B/ 7	318	84.1
B/ 8	318	88.5
B/ 9	318	88.5
B/10	318	92.7
B/11	318	92.7
B/12	318	94.1

Test No. 3
No. 11 Baghouse Outlet

Results of Flow Determination -- Method 2

Time and date	1527 hrs, 02/18/83
Barometric pressure (uncompensated, in. Hg)	28.61
Pitot tube coefficient	.848
Number of sampling ports	2
Total number of points sampled	24
Duct or stack diameter (IN)	25.8
Cross sectional area (SQ FT)	3.62
Direction of flow	vertical, up
Static pressure (IN WC)	.300
Average gas temperature (DEG-F)	289
Absolute gas pressure (IN HG)	28.63
Average moisture content (% v/v)	8.69
Actual gas density (LB/ACF)	.049
Average linear velocity (FT/SEC)	67.8
(standard deviation, FT/SEC)	5.3
Volumetric flow	
actual (ACFM)	14714
dry standard (DSCFM)	9049
Mass flow of gas - wet (LB/HR)	43652

Test No. 3
No. 11 Bashouse Outlet


Appendix A -- Point Velocity and Temperature Data

Port/Point	Gas Temperature (DEG-F)	Linear Velocity (FT/SEC)

A/ 1	290	66.2
A/ 2	289	66.2
A/ 3	290	66.2
A/ 4	290	66.2
A/ 5	289	66.2
A/ 6	288	66.4
A/ 7	286	67.9
A/ 8	284	69.5
A/ 9	283	71.2
A/10	290	69.8
A/11	291	69.9
A/12	290	62.4
B/ 1	288	57.5
B/ 2	288	57.5
B/ 3	289	63.2
B/ 4	293	66.4
B/ 5	294	73.4
B/ 6	292	79.7
B/ 7	290	73.2
B/ 8	290	73.2
B/ 9	292	68.1
B/10	291	68.1
B/11	290	66.2
B/12	300	60.9


APPENDIX B

LOCATION OF TEST PORTS AND TRAVERSE POINTS



NOT TO SCALE

TWO TEST
PORTS @ 90°




FLOW GEOMETRY NO 2 3 & 4 BAGHOUSE
TEST SITE

JOB: LEHIGH PORTLAND CEMENT
INTERPOLL REPORT NO. 3-1466
APPENDIX B

LOCATION OF TRAVERSE POINTS

TEST NO. 1

LOCATION - NO.8 KILN COOLER STACK




DIAMETER (IN.)	96.0
NUMBER OF PORTS	4
NUMBER OF POINTS TRAVERSED	32

JOB: LEHIGH PORTLAND CEMENT
INTERPOLL REPORT NO. 3-1466
APPENDIX B

LOCATION OF TRAVERSE POINTS

TEST NO. 1


LOCATION - NO.1,2,3&4 BAGHOUSE OUTLET



DIAMETER (IN.)	48.0
NUMBER OF PORTS	2
NUMBER OF POINTS TRAVERSED	44

LEHIGH CEMENT COMPANY

NO. 7 & 11 BAGHOUSE OUTLETS (STACKS)



NOT TO SCALE


D.V.H. 8/82

INTERPOLL REPORT NO. 3-1466
LEHIGH PORTLAND CEMENT COMPANY
APPENDIX B

LOCATION OF TRAVERSE POINTS

TEST NO. 2

LOCATION - NO. 7 BAGHOUSE OUTLET




DIAMETER (IN.)	25.8
NUMBER OF PORTS	2
NUMBER OF POINTS TRAVERSED	24

INTERPOLL REPORT NO. 3-1466
LEHIGH PORTLAND CEMENT COMPANY
APPENDIX B

LOCATION OF TRAVERSE POINTS

TEST NO. 3


LOCATION - NO. 11 BAGHOUSE OUTLET



DIAMETER (IN.)	25.8
NUMBER OF PORTS	2
NUMBER OF POINTS TRAVERSED	24

LEHIGH PORTLAND CEMENT CO.

NOT TO SCALE




LP 9/80

JOB: LEHIGH PORTLAND CEMENT CO.
INTERPOLL REPORT NO. 3-1466
APPENDIX B

LOCATION OF TRAVERSE POINTS

TEST NO. 2 & 3

LOCATION - NO. 8 KILN - STACK



DIAMETER (IN.)	83.5
NUMBER OF PORTS	2
NUMBER OF POINTS TRAVERSED	12

APPENDIX C

FIELD DATE SHEETS


KILN COOLER STACK

TEST NO. 1

Preliminary Data — Method 2

— Interpoll Inc. —

Job Lehigh Cement
 Source No 8 Kiln Cooler Stack Date 2-17-83
 Test No. 1 Run No. 1
 Stack dimensions: 96 in.
 Dry bulb °F Wet bulb °F
 Rel. hum. % B_{wo} 3 %
 Barometric pressure (P_b) 28.80 in. Hg
 Static pressure (P_g) -.30 in. WC in. Hg
 Operators J Stock + S Olson
 Pitot No. 6 C_p .853 Port Length 4"



Traverse Point No.	Distance from Stack wall	Distance from End of Port	(0.900) Velocity Head (in. WC)	Temperature (°F)
A-1 / 0-1	1.54	5 1/2	.15 / .13	
2 2	4.70	8 3/4	.17 / .13	
3 3	8.16	12 1/8	.16 / .12	
4 4	12	16	.16 / .14	
5 5	16.22	20 1/4	.17 / .14	
6 6	21.12	25 1/8	.19 / .14	
7 7	27.17	31 1/8	.14 / .15	
8 8	36	40	.13 / .14	
B-1			.16 / .13	
2			.18	
3			.19	
4			.19	
5			.24	
6			.20	
7			.16	
8			.15	
C-1			.12	
2			.14	
3			.16	
4			.16	
5			.18	
6			.17	
7			.16	
8			.15	
25				avg. / 50

Sample Log Sheet

Job Lehigh Cement
 Unit and Sampling Location No. 8 Kiln Cooler Stack
 Date 2-17-83 Test 1 Run 1

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 5.2 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
Filter # 3413			
Pu			
Wet Catcher			
Total (M _n)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	104	100	4
2	102	100	2
3	12	0	2
Drierite	1247	1236	11
Total (M _{wo})			19 9

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 2 Bag No. 1
 Bag Material Tedlon Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
1000			
	400		
	↓		
1123	✓		

Operator J. Hark 320-P Reading 20.9 % v/v

Job Ecchigh / No 8 K.in
 Source No 8 K.in Cooler Stack
 Date 2-17-85 Test 1 Run 1

Operators JS & SO Pitot No. 6 C_p 853
 Sampling Train No. 8 ΔH_g 1.35 Bar. Press. 28.80 in.Hg. B_{wo} 6 %
 Gas meter coeff. 99.78 Amb. Temp. 25.0 F Nozzle No. 9-3 Nozzle Dia. .370 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf) (in. Hg)	Stack Temp (°F)	Probe Temp (°F)	Oven Temp (°F)	Oxygen (4% v/v)	Gas meter temp IN (°F)	QUT (°F)
	(1000)	(857.07)									
A-8	2.5	858.64	.16	1.10	1.57	150	260	260	20.9	50	40
7	5	860.24	.16	1.10	1.57	150				54	40
6	7.5	861.85	.18	1.38	1.63	180				54	40
5	10	863.41	.17	1.30	1.56	190				56	40
4	12.5	864.96	.17	1.30	1.56	198				56	40
3	15	866.51	.17	1.30	1.56	198		261		56	40
2	17.5	867.08	.17	1.30	1.56	197				56	40
1	20	869.53	.15	1.05	1.46	195				58	42
B-8	22.5	871.15	.19	1.33	1.67	196				58	42
7	25	872.89	.21	1.47	1.73	199				58	42
6	27.5	874.54	.19	1.33	1.67	198				60	44
5	30	876.33	.22	1.54	1.77	197				60	44
4	32.5	878.08	.22	1.54	1.77	197				60	44
3	35	879.79	.21	1.47	1.73	198				60	44
2	37.5	880.50	.20	1.40	1.69	197				60	44
1	40	883.01	.16	1.12	1.51	197				60	44
C-8	42.5	884.53	.16	1.12	1.51	197				60	46
7	45	886.10	.18	1.26	1.60	198				60	46
6	47.5	887.75	.19	1.33	1.64	198				60	46
5	50	889.27	.16	1.12	1.51	197				60	46
4	52.5	890.77	.16	1.12	1.51	197				60	46
3	55	892.21	.14	.98	1.41	197				60	46
2	57.5	893.54	.14	.98	1.41	197				60	46
1	60	895.00	.14	.98	1.41	198				60	46

Operators JS-50

Pitot No

6

Sampling Train No.

 ΔH_c

Bar. Press

in H₂O

%

Gas meter coeff.

Temp

Nozzle No. _____

Wetting, Dyeing, Nozzle Die

2.

[illegible]

49.83

Interpol Inc.

Job Lehigh No 8 Kih
Unit and Sampling Location No 8 Kih Cooler Stage
Date 2-17-83 Test 1 Run 2

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
Filter # 3421			
PW			
Wet Catch			
Total (Mn)			9

Impinger Number	Weights		
	Final	Tare	Difference
1	104	100	4
2	106	100	6
3	4	0	4
Driver	1332	1319	13
Total (M _{wo})			27

FG Train No. B-1 Box No. 2 Bag No. 2
Bag Material Tedlon Bag Volume 44
Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
1220			
	400		
	↓		
1355			

Operator CH 320-P Reading 20.9 % v/v

Traverse Point No.	Sampling Time (min)	S
	(1220)	90
O-8	2.5	90
7	5	90
6	7.5	91
5	10	91
4	12.5	91
3	15	91
2	17.5	91
1	20	91
C-8	22.5	91
7	25	92
6	27.5	92
5	30	92
4	32.5	92
3	35	92
2	37.5	92
1	40	93
B-8	42.5	93
7	45	93
6	47.5	93
5	50	93
4	52.5	94
3	55	94
2	57.5	94
1	60	94

C-7

stopped

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velo He (in.)
A-8	62.5	946.90	
7	65	948.48	
6	67.5	950.04	
5	70	951.62	
4	72.5	953.20	
3	75	954.78	
2	77.5	956.26	
1	80	957.73	
	(1350)		
	8:00	958.5103	

C-8

Sample Log Sheet

Job Lchigh / No. 8 Kiln
 Unit and Sampling Location No. 8 Kiln Cooler Stack
 Date 2-17-83 Test 1 Run 3

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 6 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
Filter # 3457			
pu			
Wat Catch			
Total (Mn)			

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	106	100	6
2	105	100	5
3	2	0	2
Orientis	1328	1312	16
Total (Mwo)			

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 2 Bag No. 3
 Bag Material Tedlon Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
1425			
	400		
1550			

Operator gto 320-P Reading 20.9 % v/v

NO. 1-4 BAGHOUSE OUTLET

TEST NO. 1

C-12

17	17	40.99	44"		
18	18	42.43	45 1/2"		
19	19	43.82	46 7/8"		
20	20	45.12	48 1/8"		
21	21	46.32	49 3/4"		
22	22	47.97	50"		
25					avg.

C-13

Sample Log Sheet

Job LENIGH No 8 KILN
 Unit and Sampling Location NO 1-4 BH STACK
 Date 2-17-83 Test 1 Run 1

Sample Train: Leak check pretest: ⁰ < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: ⁰ cfm at 10 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER # 3312</u>			
<u>PW</u>			
Total (Mn)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>165</u>	<u>100</u>	<u>65</u>
<u>2</u>	<u>150</u>	<u>100</u>	<u>50</u>
<u>3</u>	<u>0</u>	<u>0</u>	
<u>Desiccant</u>	<u>1322</u>	<u>1275</u>	<u>47</u>
Total (Mwo)			162 9

Integrated Flue Gas Sampling Data

FG Train No. 4 Box No. 3 Bag No. 1
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
<u>1002</u>			
	<u>400</u>		
<u>1130</u>			

Operator P. LUNNES 320-P Reading _____ % v/v

Job Lehigh No 8 KILNOperators PL & CMPitot No. 10Cp 357Source No 1-4 BH StackSampling Train No. 7 ΔH 6.29Bar. Press. 28.82in.Hg. B_{wo} 10.5 %Date 2-17-83 Test 1 Run 1Gasmeter coeff. 1.0014 Amb. Temp. 30 °FNozzle No. 7-2Nozzle Dia. .254 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf)	Vac. (in.Hg)	Stack Temp (°F)	Probe Temp (°F)	Oven Temp (°F)	Oxygen % (v/v)	Gasmeter temp IN (°F)	Gasmeter temp QUT (°F)
	(1000)	(313.60)										
A-22	2	313.79	.50	1.14	1.17	4	341	250	258	16.8	35	35
21	4	315.68	1.3	2.86	1.89	8	340			16.8	35	35
20	6	317.70	1.5	3.3	2.04		333			16.7	34	34
19	8	319.61	1.3	2.76	1.81	53	330			16.8	34	32
18	10	321.51	1.2	2.56	1.52	7.8	340	258	260	16.8	34	32
17	12	323.16	1.1	2.35	1.24	7.4	340			16.8	34	32
16	14	324.71	.85	1.81	1.53	6.0	340			16.8	33	32
15	16	326.16	.75	1.60	1.44	5.0	344			17.2	33	32
14	18	327.66	.80	1.70	1.51	5.3	311	252	259	17.1	33	32
13	20	329.34	1.0	2.13	1.69	6.7	313			17.2	32	31
12	22	331.19	1.2	2.56	1.87	7.9	302			17.1	32	31
11	24	333.12	1.3	2.76	1.83		307			17.3	32	31
10	26	334.99	1.2	2.56	1.85		311	255	260	17.2	30	30
9	28	336.83	1.2	2.56	1.54		321			17.1	34	33
8	30	337.94	.42	.89	1.09	3.5	325			16.8	37	35
7	32	339.49	.87	1.85	1.55		338			17.2	41	38
6	34	341.11	.95	2.02	1.64	6.0	334	252	263	17.2	46	43
5	36	342.74	.95	2.02	1.11	6.2	324			16.8	50	47
4	38	344.63	1.2	2.56	1.90	8.2	319			16.7	55	50
3	40	346.53	1.2	2.60	1.65		321			16.7	60	51
2	42	348.41	1.1	2.51	1.85	8.0	294	249	260	16.8	62	51
1	44	350.04	.85	1.94	1.64	6.2	286			16.9	61	52
B-22	46	351.29	.80	1.14	1.23	4.0	300			17.1	59	52
21	48	353.61	.60	1.37	1.24		326			17.2	60	52

SUN CAME OUT

Job Lehigh No 8 KILN Pitot No. C_p
Source No 1-4 BH Stack Bar. Press. in. Hg. B_{wo} %
Date 2-17-83 Test L Run L Gasmeter coeff. °F
Sampling Train No. ΔH_a
Operators Nozzle No. Dia. in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf)	Vac. (in.Hg)	Stack Temp (°F)	Probe Temp (°F)	Oven Temp (°F)	Oxygen % v/v	Gasmeter temp	
											IN (°F)	OUT (°F)
B-20	50	354.05	.70	1.60	1.95 4.06		320			17.1	62	52
19	52	355.70	.90	2.05	1.65 5.71	6.5	311	251	259	17.1	62	52
18	54	357.36	.90	2.05	7.36	6.5	311			17.2	63	52
17	56	358.84	.70	1.60	1.46 8.82	5.3	308			17.3	63	53
16	58	360.30	.70	1.60	0.28		311			17.5	63	53
15	60	361.70	.65	1.48	1.40 1.68	4.8	310	249	253	17.8	64	53
14	62	363.08	.65	1.48	3.08		315			17.5	64	53
13	64	364.66	.85	1.87	1.60 4.68	6.0	315			17.5	64	54
12	66	366.40	1.0	2.28	1.74 2.42		310			17.3	66	54
11	68	368.43	1.3	2.86	2.03 8.45	9.0	310	253	260	17.2	66	54
10	70	370.46	1.2	2.74	1.98 0.43		287			17.2	67	55
9	72	372.39	1.2	2.74	2.41	9.0	295			17.2	67	55
8	74	374.07	.90	2.16	1.65 4.06		345			17.2	68	56
7	76	375.71	.90	2.16	5.71	7.0	345	251	259	17.2	68	56
6	78	377.36	.90	2.16	7.36		341			17.2	68	56
5	80	379.12	1.0	2.2	1.74 9.10	6.6	346			17.2	68	56
4	82	381.15	1.4	3.19	2.04 1.16		346			17.2	70	57
3	84	383.13	1.3	2.96	1.59 3.15	9.1	337			16.8	71	58
2	86	384.99	1.1	2.53	1.84 4.54	8.2	330			17.2	72	59
1	88	386.78	1.0	2.3	1.79 6.78		300			17.2	71	59
(1132)												
G=88		V _m =74.18		$\overline{\Delta H} =$								

Interpol Inc.

Sample Log Sheet

Job Lehigh No 8 KILN
 Unit and Sampling Location No 1-4 BH Stack
 Date 2-17-83 Test 1 Run 2

Sample Train: Leak check pretest: ⁶ <0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 11 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER # 3328</u>			
<u>PW</u>			
Total (M _n)			g

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>186</u>	<u>100</u>	<u>86</u>
<u>2</u>	<u>132</u>	<u>100</u>	<u>32</u>
<u>3</u>	<u>6</u>	<u>6</u>	
<u>Desiccant</u>	<u>1395</u>	<u>1351</u>	<u>44</u>
Total (M _{wo})			g

Integrated Flue Gas Sampling Data

FG Train No. 4 Box No. 3 Bag No. 2
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check _____ cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
<u>1228</u>			
	<u>400</u>		
	↓		
<u>1355</u>			

Operator P. LONNES 320-P Reading _____ % v/v

Job Lehigh No 8 KILN Operators PL & CM Pitot No. 10 Cp 857
 Source No 1-4 BH Stack Sampling Train No. 7 ΔH_g 6.79 Bar. Press. 28.82 in.Hg. B_{wo} %
 Date 2-17-83 Test 1 Run 2 Gasmeter coeff. 1.0014 Amb. Temp. °F Nozzle No. 7-2 Nozzle Dia. .254 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf)	Vac. (in.Hg)	Stack Temp (°F)	Probe Temp (°F)	Oven Temp (°F)	Oxygen 4 (% v/v)	Gasmeter Temp IN (°F)	Gasmeter Temp OUT (°F)
	(1225)	(387.0)										
8-22	2	388.19	.45	1.03	6.17	3.7	338	250	255	17.2	55	55
21	4	389.75	.82	1.87	6.6	5.2	319			17.2	51	51
20	6	391.28	.75	1.73	6.53	5.0	318			17.3	58	56
19	8	392.88	.82	1.90	6.6	5.4	317			17.3	59	56
18	10	394.47	.80	1.84	6.58	5.7	319	250	251	17.5	60	51
17	12	395.79	.55	1.32	6.27	4.2	340			17.5	62	56
16	14	397.14	.60	1.38	6.13	4.0	326			17.4	62	51
15	16	398.56	.65	1.5	6.43	4.7	317			17.3	64	56
14	18	399.98	.65	1.5	6.56		317			17.2	65	51
13	20	401.60	.85	1.96	6.63		320	255	259	17.3	66	56
12	22	403.32	.95	2.19	6.62		319			17.3	67	56
11	24	405.09	1.0	2.35	6.72	7.0	328			17.2	67	56
10	26	406.88	1.0	2.35	6.86		338			17.1	67	57
9	28	408.64	1.0	2.35	6.86		355	251	262	17.2	67	58
8	30	410.46	1.0	2.35	8.62		347			17.3	67	58
7	32	412.17	1.0	2.35	6.36		333			17.4	67	58
6	34	414.05	1.2	2.76	2.14	6.8	346			17.1	68	59
5	36	416.09	1.4	3.22	1.90	9.5	353	252	263	16.8	68	59
4	38	417.98	1.2	2.76	2.05	8.0	350			17.1	68	59
3	40	419.82	1.1	2.53	1.90		342			17.1	68	59
2	42	421.50	.90	2.07	1.83	6.3	320			17.3	67	60
1	44	423.92	.65	1.50	1.67		310	255	260	17.5	67	60
A-22	46	424.85	1.2	2.76	1.43	8.0	300			17.3	64	60
21	48	426.98	1.4	3.22	1.96		310			17.2	65	60

Job Lahigh No 8 KILN

Source No 1-4 BH Stock

Date 2-17-83 Test 1 Run 2

Operators

Sampling Train No.

Gasmeter coeff.

Pitot No.

Bar. Press

Nozzle No.

١٥

В

Nozzle Dia

%

2

%

2

[illegible]

Sample Log Sheet

Job Lehigh No 8 KILN
 Unit and Sampling Location No 1-4 BH Stack
 Date 2-17-83 Test 1 Run 3

Sample Train: Leak check pretest: ⁰<0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: ⁰ cfm at 12 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		Difference
	Final	Tare	
<u>FILTER # 3349</u>			
<u>PW</u>			
Total (M _n)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		Difference
	Final	Tare	
<u>1</u>	<u>181</u>	<u>100</u>	<u>81</u>
<u>2</u>	<u>126</u>	<u>100</u>	<u>26</u>
<u>3</u>	<u>5</u>	<u>0</u>	<u>5</u>
<u>Desiccant</u>	<u>1267</u>	<u>1235.5</u>	<u>31.5</u>
Total (M _{wo})			143.5 9

Integrated Flue Gas Sampling Data

FG Train No. 4 Box No. 3 Bag No. 3
 Bag Material Pedlar Bag Volume 44 L
 Pretest leak check _____ cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
	<u>400</u>		

Operator P. LONNES 320-P Reading 17.2 % v/v

Job Lehigh No 8 KILN Operators P.L. & C.M. Pitot No. 10 Cp .857
 Source No 1-4 BN Stack Sampling Train No. 7 ΔH_g 1.79 in.Hg. B_{wo} 16.5 %
 Date 2-17-83 Test 1 Run 3 Gasmeter coeff. 1.0014 Amb. Temp. 0 F Nozzle Dia. .254 in.
 Bar. Press. 28.82 Nozzle No. 7-2

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf)	Vac. (in.Hg)	Stack Temp (°F)	Probe Temp (°F)	Oven Temp (°F)	Oxygen 4 (% v/v)	Gasmeter temp IN 5 (°F)	Gasmeter temp OUT 6 (°F)
(1425)	(460 40)											
0-22	2	462.37	1.3	2.99	1.57		356	243	260	17.2	63	62
21	4	464.19	1.1	2.53	1.80	7.1	364			17.2	64	62
20	6	466.07	1.2	2.76	1.99		351			16.8	66	63
19	8	468.02	1.3	3.00	2.05	8.0	348			16.8	66	63
18	10	470.07	1.4	3.23	2.10		346	251	259	16.8	67	63
17	12	472.12	1.4	3.23	2.15		358			16.7	68	63
16	14	474.04	1.2	2.76	4.04		356			16.8	68	63
15	16	475.95	1.2	2.76	5.93		358			17.0	68	63
14	18	477.43	1.5	1.73	1.50	5.2	354	249	254	16.8	69	63
13	20	479.03	.85	1.96	1.58		363			17.3	70	63
12	22	480.68	.90	2.07	1.67		326			17.3	70	64
11	24	482.41	1.0	2.3	1.75	6.7	330			17.5	70	64
10	26	484.34	1.2	2.76	1.93		324	247	248	17.5	71	65
9	28	486.32	1.3	3.00	4.33	8.6	321			17.3	72	64
8	30	488.15	1.1	2.53	1.8	7.3	336			17.4	72	65
7	32	489.88	1.0	2.3	1.75		346			17.3	72	65
6	34	491.05	.45	1.04	1.17		341			17.2	72	65
5	36	492.54	.75	1.73	1.49		356	251	250	17.4	72	65
4	38	494.06	.75	1.73	2.54	5.3	345			17.3	72	65
3	40	495.55	.75	1.73	4.03		345			17.2	72	65
2	42	497.17	.90	2.07	5.52		310			17.2	72	65
1	44	498.83	.85	1.96	7.19	5.2	310			17.3	72	65
A-22	46	500.20	.60	1.38	8.83		330			17.6	70	65
21	48	501.32	.41	.94	1.36	3.6	356			17.3	70	65

MAIN STACK

TEST NOS. 2 & 3

Preliminary Data — Method 2

— Interpoll Inc. —

Job Lehigh - No. 8 Kiln

Source No. 8 Mainstack Date 2-18-83

Test No. 2 Run No. 1

Stack dimensions: 142 83 1/2 in.

Dry bulb 346 °F Wet bulb 142 °F


Rel. hum. _____ % B_{w0} _____ %

Barometric pressure (P_b) _____ in. Hg

Static pressure (P_g) -0.09 in. WC _____ in. Hg

Operators J. Stock + S. Olson

Pitot No. 20 C_p .856 Port Length 3"



Traverse Point No.	Distance from Stack wall	Distance from End of Port	() Velocity Head (in. WC)	Temperature (°F)
A - 1	3.67	6 5/8		
2	12.19	15 1/4		
3	24.72	27 3/4		
4	58.78	61 3/4		
5	71.31	74 3/8		
6	79.83	82 7/8		
B - 1				
2				
3				
4				
5				
6				
25				avg.

Sample Log Sheet

Job Lchigh / No. 8 Kiln
 Unit and Sampling Location No. 8 Kiln Mainstack
 Date 2-18-87 Test 2 Run 1

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 6 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		Difference
	Final	Tare	
Filter# <u>3442</u>			
PW			
Wet Catch			
Total (Mn)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		Difference
	Final	Tare	
1	<u>288</u>	<u>100</u>	<u>172</u>
2	<u>100</u>	<u>100</u>	<u>0</u>
3	<u>3</u>	<u>0</u>	<u>3</u>
Drierite	<u>1750</u>	<u>1334</u>	<u>16</u>
Total (Mwo)			191 9

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 2 Bag No. 1
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.

Operator J Stock 320-P Reading 6.3 % v/v

C_p 856
in.Hg. B_{wo} 20 %
Nozzle Dia. 246 in.

[illegible]

40.77

Interpoll Inc.

106.36
2.20

Sample Log Sheet

Job Lehigh / No. 8 Kiln
 Unit and Sampling Location No 8 Mainstack
 Date 2-18-83 Test 2 Run 2

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 6 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
Filter# 3440			
PW			
Wet Catch			
Total (Mn)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	238	100	138
2	140	100	40
3	4	0	4
Orients	1371.1	1350	21.1
Total (Mwo)			203.1 9

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 2 Bag No. 2
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
1138			
	400		
1239			

Operator g/hove 320-P Reading 6.2 % v/v

Job Lehigh / No 8 Kiln

Source No 8 Mainstack

Date 2-18-83 Test 2 Run 2

Operators $\sqrt{s+50}$

Sampling Train No. 8

Gasmeter coeff. 997? Amb. Temp. —°F

Orifice	ΔV	Vac.	Stack	Probe
---------	------------	------	-------	-------

Pitot No. 20

Bar. Press. 28-26

Nozzle No. 4-2

958.856

in. Hg. $\frac{18}{100}$ %

Nozzle Dia. .247 in.

[illegible]

Interpoll Inc.

S-0037R

Sample Log Sheet

Job Lehigh / No. 8 Kiln
 Unit and Sampling Location No 8 Mainstack
 Date 2-18-83 Test 2 Run 3

Sample Train: Leak check pretest: ≤ 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 5.6 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
Filter# 3443			
PW			
Wet Catch			
Total (Mn)			g

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	242	100	142
2	140	100	40
3	4	0	4
Drierite		1340	1358.9
Total (Mwo)			g

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 2 Bag No. 3
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
1336	400 ↓		
1430			

Operator g/hw 320-P Reading 6.2 % v/v

Sample Log Sheet

Job Lehigh / No. 2 Kiln
 Unit and Sampling Location No. 2 Mainstack
 Date 2-18-83 Test 3 Run 1

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 7 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
Filter # 3444			
PW			
Blue Catch			
Total (Mw)			0

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	221	100	121
2	115	100	50
3	6	0	6
Oriento	1405.3	1384	21.3
Total (Mwo)			198.3 g

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 6 Bag No. 1
 Bag Material Tedlon Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
1527	400 ↓		
1628			

Operator [Signature] 320-P Reading 6.1 % v/v

Job Lehigh / No. 8 Kil-

Source No. 8 Mainstack

Date 2-18-83 Test 3 Run 1

Operators js + so

Sampling Train No. 9

Gasmeter coeff. .9978

Pitot No.

100

Wesley's New

20 956

100

Marile Dia . 17-04

[illegible]

Interpoll Inc.

S-0037R

Sample Log Sheet

Job Lehigh / No. 8 Kiln
 Unit and Sampling Location No. 8 Mainstack
 Date 2-18-83 Test 3 Run 2

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 5 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>Filt. # 3445</u>			
<u>PW</u>			
<u>Wet Catch</u>			
Total (Mn)			

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>226</u>	<u>100</u>	<u>126</u>
<u>2</u>	<u>143</u>	<u>100</u>	<u>43</u>
<u>3</u>	<u>4</u>	<u>0</u>	<u>4</u>
<u>Drierite</u>	<u>1377.6</u>	<u>1358.9</u>	<u>18.7</u>
Total (M _{wo})			
			<u>191.70</u> g

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 6 Bag No. 2
 Bag Material Tedlon Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
<u>1644</u>			
	<u>400</u>		
<u>1746</u>			

Operator J. Stock 320-P Reading 6.2 % v/v

OM

[illegible]

Sample Log Sheet

Job Lehigh / No. 8 kiln
 Unit and Sampling Location No. 8 Mainstack
 Date 2-18-83 Test 3 Run 3

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac) ☒
 posttest: 0 cfm at 6 in. Hg. (vac)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
F. filter #			
PW			
Wet catch			
Total (Mn)			

Impinger ☒

Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	234	100	134
2	142	100	42
3	4	0	4
Orierite	1419.4	1405.3	14.1
Total (Mwo)			
			194.1 g

Integrated Flue Gas Sampling Data

FG Train No. B-1 Box No. 6 Bag No. 3
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 1

Time	cc/min.	Time	cc/min.
	440		

Operator gsh 320-P Reading _____ % v/v

NO. 7 BAGHOUSE OUTLET

TEST NO. 2

Interpoll Inc.

Pitot No. 23 C_p .848 Port Length

25

Sample Log Sheet

Job Lehigh No 3 KILN
 Unit and Sampling Location No 7 BH Stack
 Date 2-18-78 Test 2 Run 1

Sample Train: Leak check pretest: <0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 6 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER # 33.68</u>			
<u>PW</u>			
Total (M _w)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>143</u>	<u>100</u>	<u>43</u>
<u>2</u>	<u>118</u>	<u>100</u>	<u>18</u>
<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>
<u>Desiccant</u>	<u>1319</u>	<u>1310</u>	<u>9</u>
Total (M _{wo})			70 9

Integrated Flue Gas Sampling Data

FG Train No. B-4 Box No. 1 Bag No. 1
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 6 cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
	<u>400</u>		

Operator P. LONNES 320-P Reading _____ % v/v

Job Lehigh No 8 KILN
 Source No 7 Baghouse Stack
 Date 2-18-83 Test 2 Run 1

Operators P. LONNES C. MAMSON Pitot No. 23 C_p .848
 Sampling Train No. 7 Bar Press. 28.61 in.Hg. B_{wo} 8 %
 Gas meter coeff. 1.0014 Amb Temp. 7-1 Nozzle Dia. .188 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf)	Vac. (in.Hg)	Stack Temp (°E)	Probe Temp (°F)	Oxygen 4 (% v/v)	Gas meter temp IN (°F)	OUT (°F)
	(1000)	(533.80)									
A-12	2.5	535.63	2.2	1.76	1.83 5.13	5.8	325	270	17.2	48	45
11	5	537.46	2.2	1.76	7.46		322		17.2	50	45
10	7.5	539.26	2.2	1.76	9.26	6.6	323		17.2	52	46
9	10	541.01	2.0	1.6	1.75 1.01	5.7	323		17.2	54	46
8	12.5	542.76	2.0	1.6	2.76		318	260	17.2	56	41
7	15	544.16	1.15	.86	1.33 4.09	3.5	318		18.2	56	47
6	17.5	545.86	2.0	1.5	1.75 5.84	5.0	319		17.3	60	47
5	20	547.57	1.9	1.39	1.71 7.55		319		17.3	60	48
4	22.5	549.19	1.75	1.26	1.64 9.19		318	263	17.3	62	48
3	25	550.80	1.70	1.22	1.60 8.81	4.3	315		17.3	62	48
2	27.5	552.32	1.45	1.06	1.51 2.32	4.2	316		17.3	63	49
1	30	553.75	1.25	.93	1.41 3.73		310		17.3	64	50
B-12	2.5	555.37	1.75	1.30	1.66 5.39		318		17.3	63	51
11	5	557.02	1.70	1.26	1.63 7.02	4.8			17.3	65	52
10	7.5	558.67	1.70	1.28	1.65 8.68				17.3	65	52
9	10	560.27	1.55	1.16	1.59 8.25				17.3	65	52
8	12.5	561.84	1.55	1.16	1.62 9.83				17.3	67	53
7	15	563.33	1.46	1.05	1.60 9.31				17.3	67	54
6	17.5	564.47	.84	.62	1.61 9.85				19.8	67	54
5	20	566.12	1.70	1.26					17.5	68	54
4	22.5	567.75	1.70	1.26	1.60 9.85				17.3	68	54
3	25	569.35	1.55	1.16	1.59 9.35	4.4			17.3	69	55
2	27.5	570.74	1.20	.90	1.59 8.74				17.2	68	56
1	30	571.95	.92	.69	1.62 1.96		310		17.8	68	56

$\theta = 60$ (1101) $V_m = 38.15$

Interpoll Inc.

S-0037R

Sample Log Sheet

Job LEHIGH No 8 KILN
 Unit and Sampling Location No 7 BN STACK
 Date 2-18-83 Test 2 Run 2

Sample Train: Leak check pretest: <0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: _____ cfm at _____ in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER #3369</u>			
<u>PW</u>			
<u>Total (Mw)</u>			<u>9</u>

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>132</u>	<u>100</u>	<u>32</u>
<u>2</u>	<u>108</u>	<u>100</u>	<u>8</u>
<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>
<u>Desiccant</u>	<u>1206</u>	<u>1186</u>	<u>20</u>
<u>Total (Mwo)</u>			<u>60</u> <u>g</u>

Integrated Flue Gas Sampling Data

FG Train No. B-4 Box No. 1 Bag No. _____
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check _____ cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
	<u>46</u>		

Operator P. LONNES 320-P Reading _____ % v/v

Sample Log Sheet

Job Lehigh NOB KILN
 Unit and Sampling Location NO 7 Baghouse Stack
 Date 2-18-83 Test 2 Run 3

Sample Train: Leak check pretest: <0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 7 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER # 3370</u>			
<u>PW</u>			
Total (Mn)			

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>150</u>	<u>100</u>	<u>50</u>
<u>2</u>	<u>116</u>	<u>100</u>	<u>16</u>
<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>
<u>Desiccant</u>	<u>1333</u>	<u>1313</u>	<u>20</u>
Total (M _{wo})			

Integrated Flue Gas Sampling Data

FG Train No. B-4 Box No. 1 Bag No.
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
	<u>400</u>		

Operator P. LONNES 320-P Reading % v/v

Job Lehigh No 8 KILN Operators PL & CM Pilot No. 23 Cp 848
 Source No 4 BN STACK Sampling Train No. 7 AH 6 Barometer 28.61 in. Hg. B 8 %
 Date 2-18-83 Test 2 Run 3 Gasmeter coeff. 1.0014 Amb. Temp. 72 Nozzle No. 7-2 Nozzle Dia. .254 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf) (in. Hg)	Vac. (in. Hg)	Stack Temp (°F)	Preb Temp (°F)	Oven Temp (°F)	Oxygen (% v/v)	Gasmeter temp IN (°F)	Gasmeter temp QUT (°F)
	(1336)	(612.40)										
A-12	2.5	613.91	.40	1.07	3.89	3.5	310	257	261	17.8	65	63
11	5	615.56	.50	1.34	5.58	4.0	295			17.5	72	63
10	7.5	617.34	.55	1.47	7.34	4.1	300			17.7	74	63
9	10	619.20	.60	1.60	9.21	4.7	280			18.3	76	64
8	12.5	621.34	.82	2.20	1.35	6.2	307	249	251	17.7	77	64
7	15	623.59	.88	2.40	3.39	7.8	293			17.4	79	65
6	17.5	625.66	.77	2.1	2.09		295			17.3	79	65
5	20	627.74	.75	2.06	2.04	6.0	298			17.3	79	65
4	22.5	629.80	.75	2.06	2.06		295	250	250	17.4	79	66
3	25	631.70	.65	1.79	1.92	5.3	295			17.5	80	67
2	27.5	633.65	.65	1.79	3.64		292			17.6	80	67
1	30	635.78	.80	2.2	2.14	6.4	290			17.7	80	67
A-12	32.5	637.83	.72	1.98	2.03		293	244	259	17.5	78	67
11	35	639.94	.80	2.2	2.14	6.2	295			17.6	80	67
10	37.5	642.21	.90	2.5	2.26		295			17.6	80	67
9	40	644.35	.80	2.2	2.14	6.3	296			17.6	81	68
8	42.5	646.50	.80	2.2	4.35	6.3	296			17.6	80	68
7	45	648.02	.40	1.07	6.49		296			18	80	68
6	47.5	649.93	.65	1.79	1.51		298	244	260	17.8	80	68
5	50	651.35	.35	.96	8.00		293			18.1	80	69
4	52.5	652.76	.35	.96	1.92	3.3	293			18.6	80	69
3	55	654.87	.80	2.2	2.14	6.0	293			17.7	80	69
2	57.5	656.91	.72	1.98	4.86		292			18.3	80	69
1	60	658.50	.45	1.24	2.03	5.8	293			17.7	80	70

(1438) $V_m = 46.10$


Interpoll Inc.

Preliminary Data — Method 2

— Interpoll Inc. —

Job LEHIGH NO. 8 KILNSource NO 11 BAGHOUSE STACK Date 2-18-83Test No. 2 Run No. _____Stack dimensions: 25 3/4" in.

Dry bulb _____ °F Wet bulb _____ °F

Rel. hum. _____ % B_{wp} _____ %Barometric pressure (P_b) _____ in. HgStatic pressure (P_s) _____ in. WC _____ in. HgOperators P. LONNES C. MANSONPitot No. _____ C_p _____ Port Length 6 1/4"

Traverse Point No.	Distance from Stack wall	Distance from End of Port	Velocity Head (in. WC)	Temperature (°F)
1	.54	6 3/4"		
2	1.73	8 "		
3	3.04	9 1/4"		
4	4.56	10 3/4"		
5	6.44	12 3/4"		
6	9.17	15 3/8"		
7	16.58	22 3/4"		
8	19.31	25 1/2"		
9	21.19	27 3/8"		
10	22.71	29 "		
11	24.02	30 1/4"		
12	25.21	31 1/2"		
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				avg.

Sample Log Sheet

Job Lehigh No 8 KILN
Unit and Sampling Location No 11 BH Stack
Date 2-18-83 Test 3 Run 1

Sample Train: Leak check pretest : < 0.02 cfm at 15 in. Hg. (vac.) ☒
posttest: _____ cfm at _____ in. Hg. (vac.)

Particulate Sample Type and Number	Weights	
	Final	Tare
FILTER # 3365		
PW		
Total (Mg)		

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
1	160	100	60
2	126	100	26
3	0	0	0
Desiccant	1313	1288	
Total (M _{wo})			9

Integrated Flue Gas Sampling Data

FG Train No. B-4 Box No. 1 Bag No. _____
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 4

[illegible]

Operator P. LONNES 320-P Reading _____ % v/v

Job Lehigh No 8 KILN Operators P.L. & CM Pitot No. 23 C_p .848
 Source No 11 BH STACK Sampling Train No. 7 A_H 1.79 Bar. Press. 28.61 in.Hg. B 8 %
 Date 2-18-83 Test 3 Run 1 Gasmeter coeff. 1.0014 Amb. Temp. 71 Nozzle Dia. .254 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf) (in. WC)	Vac. (in. Hg)	Stack Temp (°F)	Oven Temp (°F)	Oxygen (4% v/v)	Gasmeter temp IN (°F)	Gasmeter temp OUT (°F)
	(1527)	(658.70)									
B-12	2.5	660.75	.75	2.04	2.06		300	261	17.5	68	65
11	5	663.60	.90	2.48	2.32	7.1	290		17.3	73	65
10	7.5	665.32	.95	2.61	2.33	7.8	291		17.4	75	66
9	10	667.66	.95	2.61	2.35	8.1	292		17.8	76	66
8	12.5	670.16	1.1	3.08	2.51	9.3	294	260	17.5	76	66
7	15	672.68	1.1	3.08	2.70	9.5	290		17.4	77	66
6	17.5	675.40	1.3	3.64	2.73	11.7	292		17.6	77	66
5	20	677.93	1.1	3.08	2.51	9.9	294		17.6	77	66
4	22.5	680.20	.90	2.48	2.30		293	260	17.5	77	66
3	25	682.39	.82	2.30	2.17		289		17.6	77	66
2	27.5	684.35	.68	1.88	1.98	6.0	288		18.5	78	67
1	30	686.33	.68	1.88	1.83		285		17.6	78	67
A-12	32.5	688.48	.80	2.34	2.14	6.8	287		17.6	78	67
11	35	690.87	1.0	2.8	2.39	8.3	291		17.3	78	67
10	37.5	693.27	1.0	2.8	2.25		290		17.3	78	67
9	40	695.72	1.05	2.94	2.46		287		17.3	78	67
8	42.5	698.13	1.0	2.8	2.39	8.3	284		17.3	79	68
7	45	700.45	.95	2.61	2.1		281		17.3	79	68
6	47.5	703.08	1.2	3.36	2.43		278		17.4	80	68
5	50	705.40	.95	2.61	2.39	7.8	279		17.5	80	68
4	52.5	707.68	.90	2.48	2.16		279		17.4	80	68
3	55	709.93	.90	2.48	2.16		279		17.3	79	68
2	57.5	712.18	.90	2.48	2.17		279		17.3	79	68
1	60	714.44	.90	2.48	2.17		279		17.4	78	68

$\theta = 60$ (1631) $V_m = 55.74$

Interpoll Inc.

S-0037R

Sample Log Sheet

Job Lehigh No 8 KILN
 Unit and Sampling Location No 11 BA STACK
 Date 2-18-83 Test 3 Run 2

Sample Train: Leak check pretest : < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 13 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER # 3366</u>			
<u>PW</u>			
Total (Mn)			

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>172</u>	<u>100</u>	<u>72</u>
<u>2</u>	<u>124</u>	<u>100</u>	<u>24</u>
<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>
<u>Desiccant</u>	<u>1356</u>	<u>1339</u>	<u>17</u>
Total (M _{wo})			

Integrated Flue Gas Sampling Data

FG Train No. B-4 Box No. 1 Bag No. _____
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.
	<u>400</u>		

Operator P. LONNIES 320-P Reading 17.2 % v/v

Job Lehigh No 8 KILN

Operators P.L. & CM

Blot No. 23

Sampling Train No. 7

Gasmeter coeff. 1.0014

Run 2

Test 3

Source No 11 BH Stack Bar Press. 28.61 in. Hg. B_{wo} 848 %
Date 2-18-83 Nozzle Dia. 2.54 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcf)	Vac. (in. Hg.)	Stack Temp (°F)	Over Temp (°F)	Oxygen (v/v)	Gasmeter Temp IN (°F)	Gasmeter Temp OUT (°F)
B-12	2.5	716.68	.75	2.1	207	5.5	292	260	17.8	73	66
11	5	718.84	.81	2.27	245		293		17.8	75	67
10	7.5	721.37	1.1	3.08	258		290		17.3	76	67
9	10	724.07	1.2	3.36	269	9.5	293		17.2	77	67
8	12.5	726.63	1.1	3.08	256	9.0	290		17.3	77	67
7	15	729.08	1.0	2.9	244		292		17.2	76	66
6	17.5	731.47	.95	2.7	237	7.8	293		17.2	76	66
5	20	733.90	1.0	2.9	290				17.3	76	66
4	22.5	736.32	1.0	2.9	634	8.5			17.3	76	66
3	25	738.78	1.0	2.9	820				17.2	76	66
2	27.5	741.22	1.0	2.9	122				17.2	76	66
1	30	743.52	.90	2.54	230	7.2			17.2	76	66
A-12	32.5	746.21	1.2	3.4	641				17.2	76	66
11	35	748.9	1.2	3.4	89				17.2	76	66
10	37.5	751.55	1.2	3.4	189				17.2	76	66
9	40	753.36	0.82	1.46	174				17.2	76	66
8	42.5	756.27	1.5	4.3	243	13			17.2	76	66
7	45	759.16	1.4	3.92	255	13			17.2	76	66
6	47.5	761.68	1.1	3.08	253				17.2	76	66
5	50	764.27	1.1	3.08	434				17.2	76	66
4	52.5	766.74	1.1	3.08	633				17.2	76	66
3	55	769.17	1.0	2.8	240				17.2	76	66
2	57.5	771.61	1.0	2.8	918				17.2	76	66
1	60	773.87	.90	2.54	159				17.2	76	66

(1746) $V_m = 59.27$

Interpoll Inc.

Sample Log Sheet

Job Lchigh No8 KILN
 Unit and Sampling Location No 11 BH STACK
 Date 2-18-83 Test 3 Run 3

Sample Train: Leak check pretest: < 0.02 cfm at 15 in. Hg. (vac.) ☒
 posttest: 0 cfm at 13 in. Hg. (vac.)

Particulate Sample Type and Number	Weights		
	Final	Tare	Difference
<u>FILTER # 3367</u>			
<u>PW</u>			
Total (M ₉₀)			9

Impinger ☒ Condenser ☐

Impinger Number	Weights		
	Final	Tare	Difference
<u>1</u>	<u>160</u>	<u>100</u>	<u>60</u>
<u>2</u>	<u>116</u>	<u>100</u>	<u>16</u>
<u>3</u>	<u>0</u>	<u>0</u>	<u>0</u>
<u>residual</u>	<u>1226</u>	<u>1206</u>	<u>20</u>
Total (M ₉₀)			9

Integrated Flue Gas Sampling Data

FG Train No. B-4 Box No. 1 Bag No. _____
 Bag Material Tedlar Bag Volume 44 L
 Pretest leak check 0 cc/min at 15 in. Hg. 320-P No. 4

Time	cc/min.	Time	cc/min.

Operator D. LONNES 320-P Reading _____ % v/v

Job Lehigh No 8 KILN

Source No 1 BA STACK

Date 2-28-83 Test 3 Run 3

Operators PL 2 CM

Sampling Train No. 7

Gasmeter coeff. 1.0014 Amb. Temp. 72

Pilot No. 23

Bar. Press. 30.61

Nozzle Dia. .254 in.

Cp .848

Traverse Point No.	Sampling Time (min)	Sample Volume (ft ³)	Velocity Head (in. WC)	Orifice Meter (in. WC)	ΔV (mcft)	Vac. (in. Hg)	Stack Temp (°F)	Temp. (°F)	Oxygen (v/v)	Gasmeter Temp IN (°F)	Gasmeter Temp OUT (°F)
	(1800)	(774.10)									
B-12	2.5	775.82	.50	1.4	1.69		290	250	17.8	65	64
11	5	778.65	1.4	3.92	2.83	11.3	288		17.7	68	64
10	7.5	781.28	1.2	3.36	2.54		280		17.2	69	63
9	10	783.81	1.1	3.08	2.53		280		17.2	70	63
8	12.5	786.23	1.0	2.8	2.41		280	263	17.2	71	63
7	15	788.63	1.0	2.8	2.20		281		17.2	71	63
6	17.5	791.04	1.0	2.8	2.02	8.0	282		17.2	72	63
5	20	793.32	.90	2.5	2.28		281		18.3	72	63
4	22.5	796.13	1.4	3.92	2.83		280	260	17.7	72	63
3	25	798.80	1.2	3.36	2.64	10	278		17.2	72	63
2	27.5	801.05	.90	2.5	2.29		280		17.1	72	63
1	30	803.32	.90	2.5	2.33		280		17.0	72	63
A-12	32.5	805.05	.50	1.4	1.69	4.2	280	263	17.2	70	63
11	35	806.35	.30	.84	1.31		280		18.0	72	63
10	37.5	808.33	.70	1.96	2.00	5.0	280		15.7	72	63
9	40	810.33	.70	1.96	2.33		280		17.8	72	62
8	42.5	812.36	.70	1.96	2.33	5.3	280		17.8	72	62
7	45	814.39	.75	2.11	2.07		280		17.8	72	62
6	47.5	816.32	.65	1.8	1.93		280		17.8	72	62
5	50	817.96	.45	1.26	1.61	3.8	280		18.0	72	62
4	52.5	819.03	.20	.56	1.07		280		17.7	72	62
3	55	820.72	.50	1.4	1.08		280		17.7	72	62
2	57.5	822.39	.50	1.4	1.39		280		17.3	72	62
1	60	824.07	.50	1.4	1.08	4.0	280		17.3	72	62

0-60 (1703) V_m = 49.97

— Interpoll Inc —

APPENDIX D

LABORATORY DATA SHEETS

SAMPLE DEPOSITION SHEET

1. No 8 Kiln Cooler
2. No 1, 2, 3 & 4 BH outlet
3. No 8 Mainstack
4. No 7 BH outlet
5. No 11 BH outlet

Job Lehigh Cement / No 8 Kiln

Site _____

Team Leader Jeff Stock

Priority ASAP

Date Submitted 2-21-83

Test No(s). 6 Number of Runs Completed 18

No. of Samples	Type of Sample	Analysis Required	Date Analyzed	Other Information or Special Instructions
18	Probe Wash	☒ As per EPA 5 ☐ _____		use no water
18	Filter: ☒ 4" glass fiber ☐ Stainless steel ☐ ERC	☒ As per EPA 5 ☐ _____		use no water
18	Wet Catch	☒ Organic ☒ Inorganic ☐ SO ₂ Other: _____		
18	Orsat.			
0	SO ₂			
0	NO _x			
0	Fuel Sample			

Source Information

- 1) Type of source: ☐ Boiler ☐ Asphalt Plant ☐ Incinerator ☒ Other Cement Kiln
- 2) Fuel: ☒ Coal ☐ Wood ☐ Gas ☐ Oil ☐ Other _____
- 3) Is sample combustible? ☒ No ☒ Yes
- 4) Does sample need special desiccating? ☒ No ☐ Yes If yes, explain _____
- 5) Is particle size analysis required ☒ No ☐ Yes If yes, how many run(s)? _____
run preference _____

SUMMARY OF ORSAT DATA

Laboratory Chemicals 1000
Batch No. 255
Date Received 2-21-83

Form #L-200 R

SUMMARY OF ORSAT DATA

Technician:

Date Received 2-21-83

[illegible]

EPA METHOD-3

SUMMARY OF ORSAT DATA

Job: Lehigh Cement

Sampling Location: No 8 Main Stack

Sampling Date: 2-18-83

Analysis Date:

Technician:

Laboratory Client No 1000

Batch No 255

Date Received 2-21-83

RESULTS

TESTING
AND
DATE

RUN
NO.

INTEGRATED (BAG)
Box 2

GRAB (BULB)

ANALYZER

 $\frac{1}{2} - \text{CO}_2$ % O₂

CO

% CO₂

Figure 1



3854

0-10-83

1

27.0

6.0

一、

1

27 ✓

6.6

3864

2
-19-83

2

22.1

59

SUMMARY OF ORSAT DATA

Technicians

Date received 2-21-83

4

EPA METHOD 3
LABORATORY REPORT
SUMMARY OF ORSAT DATA

Job: Lehigh Cement
Sampling Location: 116.7 Bayhouse Stack
Sampling Date: 2-18-83
Analysis Date:
Technician:

Laboratory Client No. 1000
Batch No. 255
Date Received 2-21-83

[illegible]

SUMMARY OF ORSAT DATA

Laboratory Chem No 1000
Batch No 255
Date Received 2-21-83

[illegible]

(EPA Method 5) Probe Wash
Gravimetric Analysis Lab

Data Sheet
FR 42(160)

Laboratory Client No. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-21-83

Technician Red

3829 **interpoll**
Job High Kiln #8 Date 2-17-83
City/State Mason City, IA J/N J/N
Source #8 Kiln Cooler Stack
Test Site PW Tech JS
Sample type PW Test/Run 1/1
Remarks: _____ of _____

Special Handling Required _____

Sample No. 3829

Evaporating Dish No. 301

Volume of acetone 95 cc

E. Dish Tare Wt. 84.2300 g

E. Dish + Sample Wt. 84.2494 g

Comments _____

3833 **interpoll**
Job Le High Kiln #8 Date 2-17-83
City/State Mason City, IA J/N J/N
Source #8 Kiln Cooler Stack
Test Site _____ Tech JS
Sample type PW Test/Run 1/2
Remarks: _____ of _____

Special Handling Required _____

Sample No. 3833

Evaporating Dish No. 301

Volume of acetone 115 cc

E. Dish Tare Wt. 84.2986 g

E. Dish + Sample Wt. 84.3046 g

Comments _____

3837 **interpoll**
Job Le High, #8 Kiln Date 2-17-83
City/State Mason City, IA J/N J/N
Source #8 Kiln Cooler Stack
Test Site _____ Tech JS
Sample type PW Test/Run 1/3
Remarks: _____ of _____

Special Handling Required _____

Sample No. 3837

Evaporating Dish No. 305

Volume of acetone 95 cc

E. Dish Tare Wt. 84.0597 g

E. Dish + Sample Wt. 84.0649 g

Comments _____

RESULTS:

1 .0194

2 .0060

3 .0052

D-8

1-0185/V

(EPA Method 5) Probe Wash
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Laboratory client No. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-21-83
Technician RCW

3841 **interpoll**
Job Lehigh No 8 KILN Date 2-17-83
City/State J/N
Source No 1-4 BH
Test Site STACK
Sample type PW Tech PL
Remarks: Test/Run 1/1
1 of 1

Special Handling Required _____

Sample No. 3841

Evaporating Dish No. FN

Volume of acetone 125 cc

E. Dish Tare Wt. 82.47 g

E. Dish + Sample Wt. 94.4994 g

Comments _____

3845 **interpoll**
Job Lehigh No 8 KILN Date 2-17-83
City/State J/N
Source No 1-4 SH
Test Site STACK
Sample type PW Tech PL
Remarks: Test/Run 1/2
1 of 1

Special Handling Required _____

Sample No. 3845

Evaporating Dish No. FN

Volume of acetone 125 cc

E. Dish Tare Wt. 84.3174 g

E. Dish + Sample Wt. 84.4214 g

Comments _____

3849 **interpoll**
Job Lehigh No 8 KILN Date 2-17-83
City/State J/N
Source No 1-4 BH
Test Site STACK
Sample type PW Tech PL
Remarks: Test/Run 1/3
1 of 1

Special Handling Required _____

Sample No. 3849

Evaporating Dish No. 307

Volume of acetone 125 cc

E. Dish Tare Wt. 82.6345 g

E. Dish + Sample Wt. 82.7423 g

Comments _____

RESULTS:

1/0.1149

2/0.1040

3/0.1078

(EPA Method 5) Filter
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Date of Analysis 2-21-83
Technician RCV

Laboratory Client No. 1000
Batch No. 255
Date Received 2-21-83

1

interpoll

Job Lehigh #8 Kila Date 2-17-83
City/State _____ J/N _____
Source No 1-4 BH
Test Site Stack
Sample type _____ Tech P.L.
Remarks: _____ Test/Run 1/1
_____ 1 of 1

Special Handling Required _____

Sample No. 3842
Filter No. 3312
Filter Type 4" G
Filter Tare Wt. 0.68479
Filter + Sample Wt. 0.72824
Comments Very Lt. Creme color

2

interpoll

Job Lehigh #8 Kila Date 2-17-83
City/State _____ J/N _____
Source No 1-4 BH
Test Site Stack
Sample type _____ Tech P.L.
Remarks: _____ Test/Run 1/2
_____ 1 of 1

Special Handling Required _____

Sample No. 3846
Filter No. 3328
Filter Type 4" G
Filter Tare Wt. 0.68210
Filter + Sample Wt. 0.69697
Comments Very Lt. Creme color

3

interpoll

Job Lehigh #8 Kila Date 2-17-83
City/State _____ J/N _____
Source No 1-4 BH
Test Site Stack
Sample type _____ Tech P.L.
Remarks: _____ Test/Run 1/3
_____ 1 of 1

Special Handling Required _____

Sample No. 3850
Filter No. 3349
Filter Type 4" G
Filter Tare Wt. 0.72494
Filter + Sample Wt. 0.77071
Comments Very Lt. Creme color

RESULTS:

1 .0435

D-11

2 .0349

3 .0458

water, the mean, inorganic

.1592

1389

1536

(EPA Method 5) Filter
Gravimetric Analysis Lab

Data Sheet
FR 42(160)

Laboratory Client No. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-21-83

Technician RCV

interpoll

Job La high Date 2-18-83
City/State Mason City Ia J/N
Source # 8 Main Stack
Test Site
Sample type
Remarks:

Special Handling Required

Sample No. 3854

Filter No. 3442

Filter Type 4" 6

Filter Tare Wt. 0.69710

Filter + Sample Wt. 0.73673

Job La high Date 2-18-83
City/State Mason City Ia J/N
Source # 8 Main Stack
Test Site
Sample type Tech J.S.
Remarks: Test/Run 2/2
of

Filter

Filter + Sample Wt. 0.7131

Comments Tau color

interpoll

Job La high Date 2-18-83
City/State Mason City Ia J/N
Source # 8 Main Stack
Test Site
Sample type Tech J.S.
Remarks: Test/Run 2/3
of

Special Handling Required

Sample No. 3862

Filter No. 3443

Filter Type 4" 6

Filter Tare Wt. 0.68652

Filter + Sample Wt. 0.74626

Comments Tau color

RESULTS:

1/.0590

2/.0594

3/.0597

with persulfate, Inorganic

.1538

D-13

.1524

.1634

L-0186/0

(EPA Method 5) Probe Wash
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Laboratory client No. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-22-83
Technician ACV

1

3877

interpoll

Job Lehigh Date 2-18-83
City/State Mason City, IA J/N
Source #8 Main Stack
Test Site
Sample type PW Tech JS
Remarks: Test/Run 3/1
of

Special Handling Required

Sample No. 3877
Evaporating Dish No. 206
Volume of acetone 95 c
E. Dish Tare Wt. 76.7460 g
E. Dish + Sample Wt. 76.8230 g
Comments

2

3881

interpoll

Job Lehigh Date 2-18-83
City/State Mason City, IA J/N
Source #8 Main Stack
Test Site
Sample type PW Tech JS
Remarks: Test/Run 3/2
of

Special Handling Required

Sample No. 3881
Evaporating Dish No. 507
Volume of acetone 105 c
E. Dish Tare Wt. 74.5800 g
E. Dish + Sample Wt. 74.6830 g
Comments Wt reduced OK

3

3885

interpoll

Job Lehigh Date 2-18-83
City/State Mason City, IA J/N
Source #8 Main Stack
Test Site
Sample type PW Tech JS
Remarks: Test/Run 3/3
of

Special Handling Required

Sample No. 3885
Evaporating Dish No. 508
Volume of acetone 95 c
E. Dish Tare Wt. 74.1076 g
E. Dish + Sample Wt. 74.1960 g
Comments

RESULTS:

1/.0770

2/.1030

3/.0884

D-14

L-0185/Y

(EPA Method 5) Filter
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Laboratory Client No. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-21-83
Technician RCV

1

interpoll

Job Lehigh Date 2-18-83
City/State _____ J/N _____
Source No 8 Kiln
Test Site Mainstack
Sample type _____ Tech J.S.
Remarks: _____ Test/Run 3/1
_____ of _____

Special Handling Required _____
Sample No. 3878
Filter No. 3444
Filter Type 2" G
Filter Tare Wt. 0.65296
Filter + Sample Wt. 0.7293
Comments Tan color

2

interpoll

Job Lehigh Date 2-18-83
City/State _____ J/N _____
Source No 8 Kiln
Test Site Mainstack
Sample type _____ Tech J.S.
Remarks: _____ Test/Run 3/2
_____ of _____

Special Handling Required _____
Sample No. 3880
Filter No. 3445
Filter Type 2" G
Filter Tare Wt. 0.65296
Filter + Sample Wt. 0.7293
Comments Tan color

3

interpoll

Job Lehigh Date 2-18-83
City/State _____ J/N _____
Source No 8 Kiln
Test Site Mainstack
Sample type _____ Tech J.S.
Remarks: _____ Test/Run 3/3
_____ of _____

Special Handling Required _____
Sample No. 3886
Filter No. 3409
Filter Type 4" G
Filter Tare Wt. 0.68696
Filter + Sample Wt. 0.75583
Comments Tan color

RESULTS:

1/.0670

D-15 2/.0672

3/.0689

Interpoll organic & inorganic

1440

1702

1573

L-0186/P

(EPA Method 5) Probe Wash
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Laboratory client no. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-22-83

Technician Rou

3865

interpoll

Job Lehigh No 8 KILN Date 2-18-83

City/State J/N

Source No 7 BH

Test Site STACK

Sample type PW

Remarks:

Tech PL

Test/Run 1/1

1 of 1

Special Handling Required

Sample No. 3865

Evaporating Dish No. 604

Volume of acetone 115 g

E. Dish Tare Wt. 77.8315 g

E. Dish + Sample Wt. 77.8346 g

Comments

3869

interpoll

Job Lehigh No 8 KILN Date 2-18-83

City/State J/N

Source No 7 BH

Test Site STACK

Sample type PW

Remarks:

Tech PL

Test/Run 2/2

1 of 1

Special Handling Required

Sample No. 3869

Evaporating Dish No. 604

Volume of acetone 115 g

E. Dish Tare Wt. 77.8315 g

E. Dish + Sample Wt. 77.8346 g

Comments

3873

interpoll

Job Lehigh No 8 KILN Date 2-18-83

City/State J/N

Source No 7 BH #

Test Site STACK

Sample type PW

Remarks:

Tech PL

Test/Run 2/3

1 of 1

Special Handling Required

Sample No. 3873

Evaporating Dish No. 604

Volume of acetone 115 g

E. Dish Tare Wt. 74.8745 g

E. Dish + Sample Wt. 74.8902 g

Comments

RESULTS:

1/.0145

2/.0131

3/.0157

(EPA Method 5) Filter
Gravimetric Analysis Lab

Data Sheet
FR 42(160)

Laboratory Client No. 100
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-21-83
Technician RCV

interpoll

Job Lehigh No 8 Kila Date 2-18-83
City/State J/N
Source No 7 Baghouse
Test Site Stack
Sample type Tech P.L.
Remarks: Test/Run 3/1
1 of 1

Special Handling Required

Sample No. 3866
Filter No. 3368
Filter Type 4" G
Filter Tare Wt. 0.73791
Filter + Sample Wt. 0.74279
Comments Very Lt Tan

interpoll

Job Lehigh No 8 Kila Date 2-18-83
City/State J/N
Source No 7 Baghouse
Test Site Stack
Sample type Tech P.L.
Remarks: Test/Run 3/2
1 of 1

Special Handling Required

Sample No. 3870
Filter No. 3369
Filter Type 4" G
Filter Tare Wt. 0.74253
Filter + Sample Wt. 0.74860
Comments Very Lt Tan

interpoll

Job Lehigh No 8 Kila Date 2-18-83
City/State J/N
Source No 7 Baghouse
Test Site Stack
Sample type Tech P.L.
Remarks: Test/Run 3/3
1 of 1

Special Handling Required

Sample No. 3874
Filter No. 3370
Filter Type 4" G
Filter Tare Wt. 0.75049
Filter + Sample Wt. 0.75592
Comments Very Lt Tan

RESULTS:

1 .0043

D-17

2 .0061

3 .0054

Dry Catch Only
Catch plus organic & inorganic

.0102

.0192

.0211

L-0186/P

(EPA Method 5) Probe Wash
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Laboratory client No. 1000
Batch No. 255
Date Received 2-21-83

Date of Analysis 2-22-83

Technician Red

3889 **interpoll**
Job Lehigh No 8 KILN Date 2-18-83
City/State PA J/N
Source No 11 BH
Test Site STACK
Sample type Tech PL
Remarks: Test/Run
 of

Special Handling Required
Sample No. 3889
Evaporating Dish No. 203
Volume of acetone 85 c
E. Dish Tare Wt. 24.9815 g
E. Dish + Sample Wt. 25.1405 g
Comments

3897 **interpoll**
Job Lehigh No 8 KILN Date 2-18-83
City/State PA J/N
Source No 11 BH
Test Site STACK
Sample type PW Tech PL
Remarks: Test/Run 3/2
 of 1

Special Handling Required
Sample No. 3897
Evaporating Dish No. 603
Volume of acetone 105 c
E. Dish Tare Wt. 74.2261 g
E. Dish + Sample Wt. 74.1600 g
Comments

3897 **interpoll**
Job Lehigh No 8 Kiln Date 2-18-83
City/State PA J/N
Source No 11 BH
Test Site STACK
Sample type PW Tech PL
Remarks: Test/Run 3/3
 of 1

Special Handling Required
Sample No. 3897
Evaporating Dish No. 603
Volume of acetone 105 c
E. Dish Tare Wt. 74.9321 g
E. Dish + Sample Wt. 74.8987 g
Comments

RESULTS:

1/0.1690

2/0.1339

3/.1666

(EPA Method 5) Filter
Gravimetric Analysis Lab
Data Sheet
FR 42(160)

Date of Analysis 2-21-83
Technician RAV

Laboratory Client No. 1000
Batch No. 255
Date Received 2-21-83

1

interpoll

Job La high No 8 Kila Date 2-18-83
City/State _____ J/N _____
Source No 11 B.H.
Test Site Stack
Sample type _____ Tech P.L.
Remarks: _____ Test/Run 3/1
_____ of _____

Special Handling Required _____

Sample No. 3890
Filter No. 3365
Filter Type 4" G
Filter Tare Wt. 0.74556
Filter + Sample Wt. 0.79919
Comments white color

2

interpoll

Job La high No 8 Kila Date 2-18-83
City/State _____ J/N _____
Source No 11 B.H.
Test Site Stack
Sample type _____ Tech P.L.
Remarks: _____ Test/Run 3/2
_____ of _____

Special Handling Required _____

Sample No. 3894
Filter No. 3366
Filter Type 4" G
Filter Tare Wt. 0.74273
Filter + Sample Wt. 0.80125
Comments white color

3

interpoll

Job La high No 8 Kila Date 2-18-83
City/State _____ J/N _____
Source No 11 B.H.
Test Site Stack
Sample type _____ Tech P.L.
Remarks: _____ Test/Run 3/3
_____ of _____

Special Handling Required _____

Sample No. 3898
Filter No. 3367
Filter Type 4" G
Filter Tare Wt. 0.74909
Filter + Sample Wt. 0.78888
Comments white color

RESULTS:

1/.0536

D-19

2/.0585

3/.0398

Draw Sample Only
Don't catch plus organic & Inorganic

.2226

.1924

.2064

.0186

APPENDIX E

**IOWA DEQ AIR POLLUTION
CONTROL EQUIPMENT OPERATING DATA SHEETS**

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO Location HOSON CITY, IA
 Source Type COOLER BAGHOUSE Rated Production 130 TPH (FEED)
 Date 17 FEB 83 Time 1000-1123 Actual Production 136.4
 Air Flow Data _____ Run No. 1

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____ Design Δp _____ in. H_2O @ Gas Temp. _____ $^{\circ}F$.
 Observed Δp _____ in. H_2O . Design cfm/tube @ Observed Δp _____ @ _____ $^{\circ}F$.
 Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (volts)	Secondary Current (amps)

Scrubber:

Type _____ Δp (across scrubber) _____ in. H_2O .
 Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
 Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ gpm.
 Scrubbing Water Change Interval _____
 Settling Tank Cleaning Interval _____

Baghouse:

PULSE-JET
 Pressure-Positive _____ ~~Negative~~ X No Compartments 4
 Type Cleaning COMP. AIR PULSE Clean Cycle N/A min.
 Avg. Baghouse Δp -1.35 in. H_2O . Δp Range -4/+4 in. H_2O .
 Fan: Rated H.P. 500 Operating Volts 500 Operating Amps 175

Cyclone:

Type _____ Δp _____ in. H_2O . Diameter _____
 Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: K. W. VolkSignature: [Signature]Title/Position: RAW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY

- AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAZON CITY, IA
 Source Type BAGHOUSE 1-2-3-4 Rated Production 130 TPA (FEED)
 Date 17 FEB 83 Time 1000-1123 Actual Production 136.4
 Air Flow Data _____ Run No. 1

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp _____ in. H_2O @ Gas Temp. _____ F.
 Observed Δp _____ in. H_2O . Design cfm/tube @ Observed Δp _____ @ _____ F.
 Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min.)
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H_2O .
 Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
 Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
 Scrubbing Water Change Interval _____
 Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X _____. No Compartments 11.
 Type Cleaning REVERSE AIR _____. Clean Cycle 1/4 min.
 Avg. Baghouse Δp -7.94 in. H_2O . Δp Range +8/-12 in. H_2O .
 Fan: Rated H.P. 75. Operating Volts 575. Operating Amps 54.3.

Cyclone:

Type _____ Δp _____ in. H_2O . Diameter _____.
 Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: K. W. VockSignature: [Signature]Title/Position: KIW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA

(1) ETHANOL CEMENT Location 16000 CHY, 2A
 Type COOLING Rated Production 130 TPH (REED)
 Date FEB 63 Time 1220-1355 Actual Production 139.2

v. 16000 CHY, 2A
 CAL. 16000 CHY, 2A

d. Ap. 16000 CHY, 2A

ed H.P. 16000 CHY, 2A

g. 16000 CHY, 2A

ed H.P. 16000 CHY, 2A

Circulation Rate 16000 CHY, 2A gal/min. % Make-up 16000 CHY, 2A

ng Water Change Interval 16000 CHY, 2A

g Tank Cleaning Interval 16000 CHY, 2A

e: 16000 CHY, 2A

e-Positive PULSE-JET 4 No Compartments 4

eaning COMP. AIR PULSE Clean Cycle N/A min.

ghouse Ap -1.41 in. H₂O. Ap Range -4/14 in. H₂O.

ated H.P. 500 Operating Volts 500 Operating Amps 183

ed H.P. 16000 CHY, 2A Operating Volts 16000 CHY, 2A Operating Amps 16000 CHY, 2A

Person Responsible for Data: K.W. YORK
 Signature: [Signature]
 Title/Position: KIM ENGINEER

s of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEWIS CHEM CO. Location HASOL CITY, IA
Source Type 1-2-3-4 Rated Production 130 TPA (FEED)
Date 17 Feb 1975 Actual Production 139.2
Air Flow Data _____ Run No. 2

Wet Scrubber:

No. of Tubes _____ Design Δp _____ in. H_2O @ Gas Temp. _____ $^{\circ}F$.
Design cfm/tube @ Observed Δp _____ @ _____ $^{\circ}F$.
Operating Volts _____ Operating Amps _____

Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min)
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Type _____ Δp (across scrubber) _____ in. H_2O .
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X _____ No Compartments 11 _____
Type Cleaning REVERSE AIR _____ Clean Cycle 1/4 min.
Avg. Baghouse Δp -7.93 in H_2O . Δp Range +8/-12 in. H_2O .
Fan: Rated H.P. 75 _____ Operating Volts 575 _____ Operating Amps 53.3 _____

Cyclone:

Type _____ Δp _____ in. H_2O . Diameter _____
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: K.W. VolkSignature: KW VolkTitle/Position: KW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO Location WASON CITY, IA
 Source Type COOKER BAGHOUSE Rated Production 130 TPH (FEED)
 Date 12 FEB 83 Time 1425-1556 Actual Production 138.1
 Air Flow Data _____ Run No. 3

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp _____ in. H_2O @ Gas Temp. _____ $^{\circ}F$.
 Observed Δp _____ in. H_2O . Design cfm/tube @ Observed Δp _____ @ _____ $^{\circ}F$.
 Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (amps)	Spark Rate per min.
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H_2O .
 Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
 Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
 Scrubbing Water Change Interval _____.
 Settling Tank Cleaning Interval _____.

Baghouse:

Pressure-Positive PULSE-JET ~~Negative~~ X. No Compartments 4.
 Type Cleaning COMP. AIR PULSE. Clean Cycle N/A min.
 Avg. Baghouse Δp -1.53 in. H_2O . Δp Range -4/+4 in. H_2O .
 Fan: Rated H.P. 500. Operating Volts 500. Operating Amps 195.

Cyclone:

Type _____. Δp _____ in. H_2O . Diameter _____.
 Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: K.W. VolkSignature: [Signature]Title/Position: RAW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAZEL CITY, IA
 Source Type BAGHOUSE 1-2-3-4 Rated Production 130 TPA (FEED)
 Date 17 FEB 83 Time 1425-1556 Actual Production 138.1
 Air Flow Data _____ Run No. 3

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____ Design Ap. _____ in. H₂O @ Gas Temp. _____ F.
 Observed Ap. _____ in H₂O. Design cfm/tube @ Observed Ap. _____ @ _____ °F.
 Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Electrostatic Precipitator:

Field	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (volts)	Secondary Current (amps)	Stack Gas Temp. (F)
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
 Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
 Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ gpm
 Scrubbing Water Change Interval _____
 Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X No Compartments 11
 Type Cleaning REVERSE AIR Clean Cycle 1/4 min.
 Avg. Baghouse Δp -8.23 in H₂O. Δp Range +8/-12 in. H₂O.
 Fan: Rated H.P. 75 Operating Volts 575 Operating Amps 53.4

Cyclone:

Type _____ Δp _____ in. H₂O. Diameter _____
 Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: K.W. VockSignature: KWTitle/Position: KW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HASON CITY, IA.
Source Type #8 PRECIPITATOR Rated Production 130 TPH (FEED)
Date 18 Feb 83 Time 1000-1103 Actual Production 134.1
Air Flow Data _____ Run No. 1

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp . _____ in. H_2O @ Gas Temp. _____ $^{\circ}F$.
Observed Δp _____ in H_2O . Design cfm/tube @ Observed Δp _____ @ _____ $^{\circ}F$.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min.)
<u>1</u>	<u>480</u>	<u>172</u>	<u>60</u>	<u>1075</u>	<u>0</u>
<u>2</u>	<u>437</u>	<u>200</u>	<u>56</u>	<u>1200</u>	<u>0</u>
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H_2O .
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative _____. No Compartments _____.
Type Cleaning _____. Clean Cycle _____ min.
Avg. Baghouse Δp _____ in H_2O . Δp Range _____ in. H_2O .
Fan: Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Cyclone:

Type _____ Δp _____ in. H_2O . Diameter _____.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: K.uy. Volk

Signature: [Signature]

Title/Position: Plant Engineer

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAZEL CITY, IA
Source Type BAGHOUSE #7 Rated Production 130 TPA (FEED)
Date 1/18/83 Time 1000-1103 Actual Production 134.1
Air Flow Data _____ Run No. 1

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp _____ in. H₂O @ Gas Temp. _____ F.
Observed Δp _____ in. H₂O. Design cfm/tube @ Observed Δp _____ cfm.
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Spark Rate (per min.)
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X _____ No Compartments 11 _____
Type Cleaning REVERSE AIR _____ Clean Cycle 1/4 min.
Avg. Baghouse Δp -10.8 in. H₂O. Δp Range +8/-12 in. H₂O.
Fan: Rated H.P. 75 Operating Volts 575 Operating Amps 53.5

Cyclone:

Type _____ Δp _____ in. H₂O. Diameter _____
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: K.W. Vock

Signature: KW

Title/Position: KW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HASON CITY, IA.
Source Type #8 PRECIPITATOR Rated Production 130 TPH (FEED)
Date 10/10/83 Time 1138-1239 Actual Production 132.9
Air Flow Data _____ Run No. 2

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp . _____ in. H_2O @ Gas Temp. _____ F.
Observed Δp _____ in H_2O . Design cfm/tube @ Observed Δp _____ @ _____ °F.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min.)
1	475	175	60	1080	0
2	440	200	56	1200	0

Scrubber:

Type _____. Δp (across scrubber) _____ in. H_2O .
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative _____. No Compartments _____.
Type Cleaning _____. Clean Cycle _____ min.
Avg. Baghouse Δp _____ in H_2O . Δp Range _____ in. H_2O .
Fan: Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Cyclone:

Type _____. Δp _____ in. H_2O . Diameter _____.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

K. W. Volk

KIM ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAISON CITY, IA
Source Type BAUGHUSE #7 Rated Production 130 TPH (FEED)
Date 10/03/83 Time 1138-1239 Actual Production 132.9
Air Flow Data _____ Run No. 2

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____ Design Ap. _____ in. H₂O @ Gas Temp. _____ F.
Observed Ap _____ in H₂O. Design cfm/tube @ Observed Ap _____ cfm/tube @ _____ F.
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Electrostatic Precipitator:

Field	Primary Voltage (volts)	Primary Current (amps)

Scrubber:

Type _____ Ap (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X No Compartments 11
Type Cleaning REVERSE AIR Clean Cycle 1/4 min.
Avg. Baghouse Ap -9.2 in H₂O. Ap Range +8/-12 in. H₂O.
Fan: Rated H.P. 75 Operating Volts 575 Operating Amps 53

Cyclone:

Type _____ Ap _____ in. H₂O. Diameter _____
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: K.W. YorkSignature: [Signature]Title/Position: KIW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

WICH CEMENT CO. Location HASON CITY, IA.
pe #8 PRECIPITATOR Rated Production 130 TPH (FEED)
OB 83 Time 1336-1437 Actual Production 132.9
Data _____ Run No. 3

al Collector:

meter _____ in. No. of Tubes _____. Design Δp . _____ in. H₂O @ Gas Temp. _____ F.
 Δp . _____ in. H₂O. Design cfm/tube @ Observed Δp _____ @ _____ F.
1 H.P. _____ Operating Volts _____. Operating Amps _____.

Static Precipitator:

	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min.)
1	475	173	59	1077	0
2	440	200	56	1201	0

_____ Δp (across scrubber) _____ in. H₂O.
ed H.P. _____ Operating Volts _____. Operating Amps _____.
Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
ng Water Change Interval _____
g Tank Cleaning Interval _____

_____ e-Positive _____ Negative _____ No Compartments _____
eaning _____ Clean Cycle _____ min.
ghouse Δp _____ in. H₂O. Δp Range _____ in. H₂O.
ated H.P. _____ Operating Volts _____. Operating Amps _____.

_____ Δp _____ in. H₂O. Diameter _____
ed H.P. _____ Operating Volts _____. Operating Amps _____.

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

King Vack

King

King Engineer

es of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAZOU CITY, IA
Source Type BAGHOUSE #7 Rated Production 130 TPA (FEED)
Date 10/05/83 Time 1336-1437 Actual Production 132.9
Air Flow Data _____ Run No. 3

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp _____ in. H₂O @ Gas Temp. _____ F.
Observed Δp _____ in H₂O. Design cfm/tube @ Observed Δp _____ @ _____ F.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (amps)	Spark Rate (per min)

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X. No Compartments 11.
Type Cleaning REVERSE AIR. Clean Cycle 1/4 min.
Avg. Baghouse Δp -10.8 in H₂O. Δp Range +8/-12 in. H₂O.
Fan: Rated H.P. 75. Operating Volts 575. Operating Amps 50.3.

Cyclone:

Type _____. Δp _____ in. H₂O. Diameter _____.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

K.W. Vack

[Signature]

KW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HASON CITY, IA.
Source Type #8 PRECIPITATOR Rated Production 130 TPH (FEED)
Date 18 Feb 83 Time 1527-1631 Actual Production 132.2
Air Flow Data _____ Run No. 4

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp _____ in. H₂O @ Gas Temp. _____ F.
Observed Δp _____ in H₂O. Design cfm/tube @ Observed Δp _____ @ _____ F.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (kV)	Secondary Current (amps)	Efficiency (%)
<u>1</u>	<u>472</u>	<u>176</u>	<u>58</u>	<u>100</u>	<u>91</u>
<u>2</u>	<u>433</u>	<u>196</u>	<u>56</u>	<u>1200</u>	
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative _____. No Compartments _____.
Type Cleaning _____. Clean Cycle _____ min.
Avg. Baghouse Δp _____ in H₂O. Δp Range _____ in. H₂O.
Fan: Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Cyclone:

Type _____. Δp _____ in. H₂O. Diameter _____.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

K.W. Vock

Rue

K.W. Vock

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAZOU CITY, IA
Source Type BAGHOUSE #11 Rated Production 130 TPH (FEED)
Date 12/05/83 Time 1527-1631 Actual Production 132.2
Air Flow Data _____ Run No. 4

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp . _____ in. H₂O @ Gas Temp. _____ F.
Observed Δp _____ in. H₂O. Design cfm/tube @ Observed Δp _____ @ _____ °F.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min.)
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X. No Compartments 11.
Type Cleaning REVERSE AIR. Clean Cycle 1/4 min.
Avg. Baghouse Δp -8.1 in. H₂O. Δp Range +8/-12 in. H₂O.
Fan: Rated H.P. 75. Operating Volts 575. Operating Amps 50.5.

Cyclone:

Type _____. Δp _____ in. H₂O. Diameter _____.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HASON CITY, IA.
Source Type #8 PRECIPITATOR Rated Production 130 TPH (FEED)
Date 18 Feb 63 Time 1644-1746 Actual Production 133.4
Air Flow Data _____ Run No. 5

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____ Design Δp _____ in. H₂O Gas Temp. _____ F.
Observed Δp _____ in. H₂O Design cfm/tube @ Observed Δp _____ cfm
Fan Rated H.P. _____ Operating Volts _____

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (volts)	Secondary Current (amps)	Spark (per sec.)
<u>1</u>	<u>414</u>	<u>170</u>	<u>1100</u>	<u>1.2</u>	<u>0</u>
<u>2</u>	<u>427</u>	<u>198</u>	<u>1100</u>	<u>1.2</u>	<u>0</u>

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ ppm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative _____ No Compartments _____
Type Cleaning _____ Clean Cycle _____ min.
Avg. Baghouse Δp _____ in. H₂O. Δp Range _____ in. H₂O.
Fan: Rated H.P. _____ Operating Volts _____ Operating Amps _____

Cyclone:

Type _____ Δp _____ in. H₂O. Diameter _____
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: K. W. Volk
Signature: [Signature]
Title/Position: Plant Engineer

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HAZON CITY, IA
Source Type BAGHOUSE #11 Rated Production 130 TPH (FEED)
Date 18 Feb 63 Time 1644-1746 Actual Production 133.4
Air Flow Data _____ Run No. 5

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp . _____ in. H₂O @ Gas Temp. _____ F.
Observed Δp _____ in. H₂O. Design cfm/tube @ Observed Δp _____ @ _____ F.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.

Electrostatic Precipitator:

Field	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (ma)	Spark Rate (per min.)
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H₂O.
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____.
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X _____ No Compartments 11 _____
Type Cleaning REVERSE AIR _____ Clean Cycle 1/4 min.
Avg. Baghouse Δp -7.4 in. H₂O. Δp Range +8/-12 in. H₂O.
Fan: Rated H.P. 75 _____ Operating Volts 575 _____ Operating Amps 52.5

Cyclone:

Type _____ Δp _____ in. H₂O. Diameter _____
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____

Person Responsible for Data: K.W. Volk

Signature: KW

Title/Position: KW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CEMENT CO. Location HASON CITY, IA.
Source Type 4B PRECIPITATOR Rated Production 130 TPH (FEED)
Date 10 Feb 53 Time 1800-1902 Actual Production 132.1
Air Flow Data _____ Run No. 6

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp . _____ in. H_2O @ Gas Temp. _____ F.
Observed Δp _____ in H_2O . Design cfm/tube @ Observed Δp _____ @ _____
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (KV)	Secondary Current (amps)	Spark Rate (per hour)
<u>1</u>	<u>475</u>	<u>176</u>	<u>56</u>	<u>1235</u>	<u>0</u>
<u>2</u>	<u>425</u>	<u>200</u>	<u>54</u>	<u>1235</u>	<u>0</u>
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Scrubber:

Type _____ Δp (across scrubber) _____ in. H_2O .
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____
Liquid Circulation Rate _____ gal/min. % Make-up _____. Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative _____. No Compartments _____
Type Cleaning _____. Clean Cycle _____ min.
Avg. Baghouse Δp _____ in H_2O . Δp Range _____ in. H_2O .
Fan: Rated H.P. _____. Operating Volts _____. Operating Amps _____

Cyclone:

Type _____. Δp _____ in. H_2O . Diameter _____
Fan Rated H.P. _____. Operating Volts _____. Operating Amps _____

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

K. J. Vock

K. J. Vock

K. J. Vock

*Averages of operating data taken during actual test run unless requested otherwise.

IOWA DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR POLLUTION CONTROL EQUIPMENT OPERATING DATA*

Plant LEHIGH CHEMICAL CO. Location HASSEN CITY, IA
Source Type BAGHOUSE #11 Rated Production 130 TPA (FEED)
Date 10/05/63 Time 1800-1902 Actual Production 132.1
Air Flow Data _____ Run No. 6

Mechanical Collector:

Tube Diameter _____ in. No. of Tubes _____. Design Δp _____ in. H₂O Gas Temp. _____ F.
Observed Δp _____ in. H₂O Design cfm/tube @ Observed Δp _____ cfm
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Electrostatic Precipitator:

Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (volts)	Secondary Current (amps)

Scrubber:

Type _____ Δp (across scrubber) _____
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____
Liquid Circulation Rate _____ gal/min. % Make-up _____ Blowdown _____ gpm.
Scrubbing Water Change Interval _____
Settling Tank Cleaning Interval _____

Baghouse:

Pressure-Positive _____ Negative X No Compartments 11
Type Cleaning REVERSE AIR Clean Cycle 1/4 min.
Avg. Baghouse Δp -8.0 in. H₂O Δp Range +8/-12 in. H₂O
Fan: Rated H.P. 75 Operating Volts 575 Operating Amps 52.0

Cyclone:

Type _____ Δp _____ in. H₂O Diameter _____
Fan Rated H.P. _____ Operating Volts _____ Operating Amps _____

Person Responsible for Data: _____

Signature: _____

Title/Position: _____

K.W. Vock

KW

KW ENGINEER

*Averages of operating data taken during actual test run unless requested otherwise.

APPENDIX F

**IOWA DEQ CEMENT PLANT
OPERATING DATA SHEETS**

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LENIGH PORTLAND CEMENT CO.

Run No. 1

Kiln No. 8

Date 17 Feb 83

Type of Kiln: Wet ☒ Dry ☐

Kiln Diameter 130 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.

Approximate Kiln Speed at Above Rating 150 rev./hr.

Historical Average Kiln Feed Rate 97 tons/hr.

Historical Maximum Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Estimated Kiln Feed Rate 97 tons/hr.

Approximate Feed Composition During Test
Run by Weight

Limestone 7
Silica 7
Alumina 7
Water (wet) 7
(Other) SAND 5.1 IRON 0.3 7

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 136.4 tons/hr.

Kiln Speed 123 RPH

Fuel Coal ☒ Oil Gas ☐

Insufflation in Progress: Yes No ☒

Person Responsible for Data R. W. Volk

Signature RWV

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LEHIGH PORTLAND CEMENT CO.
Kiln No. 8

Run No. 2
Date 17 Feb 83

Type of Kiln: _____ Wet X Dry _____
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 TO DATE) 97 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.
Insufflation Capability: Yes _____ No X

Anticipated Fuel Usage: Coal X % of time.
Oil _____ % of time.
Gas _____ % of time.

Approximate Feed Composition During Test
Run by Weight

Limestone 78.6 %
Silica Clay 16.0 %
Alumina 4.4 %
Water (wet) 0.1 %
(Other) SAND 5.1 %
IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 139.2 tons/hr.
Kiln Speed 129 RPH
Fuel _____ Coal X Oil _____ Gas _____
Insufflation in Progress: Yes _____ No X

Person Responsible for Data K.W. Volk

Signature [Signature]

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LENIGH PORTLAND CEMENT CO.
Kiln No. 8

Run No. 3
Date 17 Feb 83

Type of Kiln: Wet ☒ Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 TO DATE) 135 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.
Insufflation Capability: Yes No ☒

Anticipated Fuel Usage: Coal ☒ % of time
Oil % of time
Gas % of time

Approximate Feed Composition During Test
Run by Weight

Limestone 76.6 %
Silica Clay 16.0 %
Alumina N/A %
Water (wet) 0.1 %
(Other) SAND 5.1 %
IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 138.1 tons/hr.
Kiln Speed 131 RPH
Fuel Coal ☒ Oil Gas
Insufflation in Progress: Yes No ☒

Person Responsible for Data R.W. Volk

Signature RW Volk

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LENHART PORTLAND CEMENT CO.
Kiln No. 8

Run No. 1
Date 18 Feb 83

Type of Kiln: Wet ☒ Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 - 1982) 97 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.

Insufflation Capability: Yes ☐

Anticipated Fuel Usage:

Coal ☒

Oil ☐

Gas ☐

Approximate Feed Composition During Test
Run by Weight

Limestone 75.6

Silica Clay 16.0

Alumina N/A

Water (wet) 0.1

(Other) SAND 5.1

IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 134.1 tons/hr.

Kiln Speed 132 RPH

Fuel Coal ☒ Oil ☐ Gas ☐

Insufflation in Progress: Yes ☐ No ☒

Person Responsible for Data K. W. Volk

Signature K. W. Volk

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LEHIGH PORTLAND CEMENT CO.
Kiln No. 8

Run No. 2
Date 18 Feb 83

Type of Kiln: Wet X Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 TO DATE) 97 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.

Insufflation Capability: Yes X

Anticipated Fuel Usage: Coal X % of time
Oil % of time
Gas % of time

Approximate Feed Composition During Test
Run by Weight

Limestone	<u>78.6</u>	<u> </u>
Silica Clay	<u>16.0</u>	<u> </u>
Alumina	<u>N/A</u>	<u> </u>
Water (wet)	<u>0.1</u>	<u> </u>
(Other)	<u>SAND 5.1</u>	<u> </u>
	<u>IRON 0.3</u>	<u> </u>

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 132.9 tons/hr.
Kiln Speed 132 RPH
Fuel Coal X Oil Gas
Insufflation in Progress: Yes No X

Person Responsible for Data K. W. Volk

Signature KW

Title/Position Kiln ENGINEER

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LEHIGH PORTLAND CEMENT CO.
Kiln No. 8

Run No. 3
Date 18 Feb 83

Type of Kiln: Wet X Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 1.5 rev./hr.
Historical Average Kiln Feed Rate 127 tons/hr.
Historical Maximum Kiln Feed Rate 130 tons/hr.
Insufflation Capability: Yes

Anticipated Fuel Usage: Coal X
Oil
Gas

Approximate Feed Composition During Test
Run by Weight

Limestone 70.0
Silica Clay 16.0
Alumina N/A
Water (wet) 0.1
(Other) SAND 5.1
IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 132.9 tons/hr.
Kiln Speed 1.32 RPH
Fuel Coal X Oil Gas
Insufflation in Progress: Yes No X

Person Responsible for Data R. W. Volk

Signature R. W. Volk

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LENING PORTLAND CEMENT CO.
Kiln No. 8

Run No. 4
Date 18 Feb 83

Type of Kiln: Wet ☒ Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 TO DATE) 97 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.
Insufflation Capability: Yes No ☒

Anticipated Fuel Usage: Coal ☒ % of time.
Oil % of time.
Gas % of time.

Approximate Feed Composition During Test
Run by Weight

Limestone 78.6 %
Silica Clay 16.0 %
Alumina U/A %
Water (wet) 0.1 %
(Other) SAND 5.1 %
IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 132.2 tons/hr.
Kiln Speed 138 RPH
Fuel Coal ☒ Oil Gas
Insufflation in Progress: Yes No ☒

Person Responsible for Data K. W. Volk

Signature K. W. Volk

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LENIGH PORTLAND CEMENT CO.
Kiln No. 8

Run No. 5
Date 18 Feb 83

Type of Kiln: Wet X Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 TO DATE) 97 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.
Insufflation Capability: Yes No X

Anticipated Fuel Usage: Coal X % of time.
Oil % of time.
Gas % of time.

Approximate Feed Composition During Test
Run by Weight

Limestone 78.6 %
Silica Clay 16.0 %
Alumina N/A %
Water (wet) 0.1 %
(Other) SAND 5.1 %
IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 133.4 tons/hr.
Kiln Speed 138 RPH
Fuel Coal X Oil Gas
Insufflation in Progress: Yes No X

Person Responsible for Data R.W. Volk

Signature RW

Title/Position Kiln Engineer

PARTICULATE EMISSIONS TEST REPORT
CEMENT PLANT OPERATING DATA

Owner LENIGH PORTLAND CEMENT CO.
Kiln No. 8

Run No. 6
Date 18 Feb 83

Type of Kiln: Wet ☒ Dry
Kiln Diameter 13.0 ft.

Maximum Continuous Kiln Feed Rate (Manufacturer's Rating) 130 tons/hr.
Approximate Kiln Speed at Above Rating 150 rev./hr.
Historical Average Kiln Feed Rate (1979 TO DATE) 97 tons/hr.
Historical Maximum Kiln Feed Rate 135 tons/hr.
Insufflation Capability: Yes ☒ No ☒

Anticipated Fuel Usage: Coal ☒ % of time.
Oil ☐ % of time.
Gas ☐ % of time.

Approximate Feed Composition During Test
Run by Weight

Limestone 78.6 %
Silica Clay 16.0 %
Alumina N/A %
Water (wet) 0.1 %
(Other) SAND 5.1 %
IRON 0.3

Feed Size: 87.4 % passing 200 mesh sieve.

KILN OPERATION DURING RUN (AVERAGED)

Kiln Feed Rate 132.1 tons/hr.
Kiln Speed 126 RPH
Fuel Coal ☒ Oil ☐ Gas ☐
Insufflation in Progress: Yes ☐ No ☒

Person Responsible for Data R. W. Volk

Signature [Signature]

Title/Position Kiln Operator

APPENDIX G

PROCEDURES

Particulate Loadings and Emission Rates

The particulate emission rates were determined per EPA Methods 1-5, CFR title 40, Part 60, Appendix A (Revised July 1, 1982). In this procedure, a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass-lined sampling probe equipped with a Type S pitot and a thermometer. The probe is attached to a sampling module which houses the all-glass in-line filter holder in a temperature controlled oven. In addition, the sampling module houses the impinger case and a Drierite drying column. The sampling module is connected by means of an umbilical cord to the control module which houses the dry test gasmeter, the calibrated orifice, a leafless pump, two manometers, and all controls required for operating the sampling train.


Particulate samples were collected as follows: The sample gas was drawn in through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter. The particulates were removed at this point and collected on the filter. The gases then passed through an ice-cooled impinger train and a desiccant-packed drying column which quantitatively absorb all moisture from the sample gas stream after which the sample gas passes through the pump and the dry test gasmeter which integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gasmeter provides instantaneous flow rate data.

A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each site such that an isokinetic sampling condition prevails. Nomographs are used to aid in the rapid determination of the sampling rate.

After sampling is complete, the filter is removed and placed in a clean container. The nozzle and inlet side of the filter holder are quantitatively washed with acetone and the washings are stored in a second container. A brush is often used in the cleaning step to help dislodge deposits. The samples are returned to the laboratory where they are logged in and analyzed. The volume of the acetone rinse ("probe wash") is noted and then the rinse is quantitatively transferred to a tared 120 cc porcelain evaporating dish and the acetone evaporated off at 97-105 °F. This temperature is used to prevent condensation of atmospheric moisture due to the cooling effect induced by the evaporation of acetone. The acetone-free sample is then transferred to an oven and dried at 105 °C for 30 minutes, cooled in a desiccator over Drierite, and then weighed to the nearest .01 mg. The filter sample is quantitatively transferred to a 6-inch watch glass and dried in an oven at 105 °C for two hours. The filter and watch glass are then cooled in a desiccator and the filter weighed to the nearest .01 mg. All weighings are performed in a balance room where the relative humidity is hydrostatted to less than 50% relative humidity. Microscopic examination of the samples is performed if any unusual characteristics are observed. The weight of the acetone rinse is corrected for the acetone blank. The Drierite column is weighed on-site and the water collected by Drierite is added to the condensate so that the total amount of absorbed water may be ascertained.

Integrated flue gas samples for Orsat analysis were collected simultaneously from the stack and from the breeching at the inlet to the wet scrubber. The samples were collected in 44-liter Tedlar or teflon gas sampling bags at a constant flow rate throughout each particulate run. The bags were then returned to the laboratory and analyzed by Orsat analysis. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen). In addition to the above, the oxygen content of the flue gas was measured at each traverse during the particulate determinations using a Teledyne Model 320P-4 Portable Oxygen Analyzer to sample the effluent from the Method 5 train.

G-2



G-3

APPENDIX H

CALCULATION EQUATIONS

$$m_g = \frac{4.995 Q_{s,d} G}{1 - B_{ws}}$$

$$RH^* = 100 [vp_{twb} - 0.0003641 P_s (T_{db} - T_{wb})] / vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

CALCULATION EQUATIONS

METHOD 2

$$\bar{V}_s = 85.48 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60(1 - B_{ws}) \bar{V}_s A \left[\frac{528}{T_{s(avg)}} \right] \left[\frac{P_s}{29.92} \right]$$

$$Q_a = 60 \bar{V}_s A$$

$$m_g = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 [vp_{twb} - 0.000364 P_s (T_{db} - T_{wb})] / vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb}) / P_s$$

$$\rho = \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

CALCULATION EQUATIONS

METHOD 3

$$\%EA = \frac{100(\%O_2 - 0.5\% CO_2)}{0.264\% N_2 - \%O_2 - 0.5\% CO_2}$$

$$M_d = 0.54(\%CO_2) + 0.5$$

$$M_g = M_d$$

$$B_{ws} = \frac{w(std)}{V_{w(std)} + V_{m(std)}}$$

METHOD 5

$$V_{m(std)} = 17.65 V_m \gamma \left[\frac{P_{bar} + \overline{\Delta H}/13.6}{T_{m(avg)}} \right]$$

$$V_{w(std)} = 0.0472 V_{ls}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$= 0.0944 \left[\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (1 - B_{ws})} \right]$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_a = \frac{272.3 M_p P_s}{T_{s(avg)} [V_{w(std)} + V_{m(std)}]}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_{s,d}$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{\theta A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

SYMBOLS

A	=	Cross sectional area of stack, SQ. FT.
A_n	=	Cross sectional area of nozzle, SQ. FT.
B_{ws}	=	Water vapor in gas stream, proportion by volume
C_p	=	Pitot tube coefficient, dimensionless
C_a	=	Concentration of particulate matter in stack, GR/ADF
C_s	=	Concentration of particulate matter, corrected to standard conditions, basis
EA	=	Excess air, percent by volume
F	=	Dry test meter correction factor, dimensionless
G_d	=	Specific gravity (relative to air), dimensionless
I	=	Isokinetic variation, percent by volume
M_d	=	Molecular weight of stack gas, dry basis, g/g - mole.
m_g	=	Mass flow of wet flue gas, LB/HR
m_p	=	Particulate mass flow, LB/HR
M_s	=	Molecular weight of stack gas, wet basis, g/g, mole.
M_p	=	Total amount of particulate matter collected, g
P_{bar}	=	Atmospheric pressure, IN. HG (uncompensated)
P_g	=	Stack static gas pressure, IN. W.C.
P_{std}	=	Standard absolute pressure, 29.92 IN. HG

- Q_a = Actual volumetric stack gas flow rate, ACFM
 $Q_{s,d}$ = Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
 RH = Relative humidity, %
 T_{db} = Dry bulb temperature of stack gas, °F
 T_{wb} = Wet bulb temperature of stack gas, °F
 $T_{m(avg)}$ = Absolute average dry gas meter temperature, °F
 $T_{s(avg)}$ = Absolute average stack gas temperature, °F
 T_{std} = Standard absolute temperature, °F
 θ = Total sampling time, min
 V_{lc} = Total volume of liquid collected in the sample, ml
 V_m = Volume of gas sample as measured by dry gas meter, ft³
 $V_{m(std)}$ = Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
 $V_{w(std)}$ = Volume of water vapor in the gas sample corrected to standard conditions, SCF
 $\bar{V}_s$ = Average actual stack gas velocity, FT/SEC
 vp_{tdb} = Vapor pressure at T_{db} , IN. HG
 vp_{twb} = Vapor pressure at T_{wb} , IN. HG
 $\bar{\Delta H}$ = Average pressure differential across the orifice meter, IN. W.C.
 ΔP = Velocity pressure of stack gas, IN. W.C.
 γ = Dry test meter correction coefficient, dimensionless
 ρ = Actual gas density, LB/ACF

APPENDIX I

SAMPLING TRAIN CALIBRATION DATA

Report No. 3-1466
 Portland Cement Company
 Mason City, Iowa

Meter Box Calibration Data Sheet

Date of Cal: February 15, 1983
 Technician: J. Stock
 Bar. Press.: 29.11

Box No. 8
 Test Meter Ser. No. 64710
 Test Meter No. AL-20

Delta H Actual (in. WC)	Gas Volume Wet Test Meter	Cal. Index (%)	Diff. Wet Test Meter (in. WC)	Gas Volume Dry Test Meter Vde (cf)	Orifice Constant (in. WC)
0.50	4.0	99.90	0.01	825.83	1.744
0.90	5.0	99.90	0.02	819.67	1.695
1.40	16.0	99.90	0.04	767.12	1.742
2.00	14.0	99.90	0.06	752.35	1.787
3.00	14.0	99.91	0.09	832.00	1.809
5.00	10.0	99.91	0.13	807.43	1.799
					0.99774
					1.763

Rockwell Report No. 3-1466
 Lehigh Portland Cement Company
 Mason City, Iowa

Meter Box Calibration and Usage Summary

Date of Report: February 18, 1983

Control Case No. 8 (Rockwell Dry Test Meter Serial No. 64710)

Date of Last Calibration: February 15, 1983
 Calibration Technician: J. Stock
 Wet Test Meter No.: American Meter AL-20

Date of Use	Job No.	Initial Meter Reading	Final Meter Readings	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
February 17, 1983	3-1466	857.07	9.46	152.39	152.39
February 18, 1983	3-1466	10.16	138.09	127.93	280.32
February 18, 1983	3-1466	138.40	266.27	127.87	408.19

*Total volume through meter since last calibration

Intersoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Meter Box Calibration Data Sheet

Date of Cal: December 27, 1982
Technician: D. Stock
Bar. Press.: 29.12

Meter Box No. 7
Dry Test Meter Ser. No. 676477
Wet Test Meter No. AL-20

Delta M	Gas	Cal.	Diff.	Gas Volume	Gas Temperature	Time	Meter	Orifice
Actual	Volume	Index	Wet	Dry Test Meter	of Meters	(min)	Coef.	Constant
(in. WC)	Wet Test Meter	(%)	Meter	Vde	Vdf			
				(cf)				(in. WC)
0.50	5.0	99.90	0.01	134.24	139.33	68	12.56	1.00729 1.763
0.92	9.0	99.90	0.02	171.33	180.43	68	16.68	1.00442 1.778
1.40	11.0	99.90	0.04	120.96	132.15	64	16.77	1.00715 1.807
2.00	16.0	99.90	0.06	100.48	116.76	64	20.61	0.99823 1.856
3.00	10.0	99.91	0.09	182.61	192.77	66	10.09	0.99831 1.849
5.00	10.0	99.91	0.12	193.78	203.97	64	18.03	0.99270 1.805
							average:	1.00135 1.810

Interpoll Report No. 3-1466
 Lehigh Portland Cement Company
 Mason City, Iowa

Meter Box Calibration and Usage Status

Date of Report: February 18, 1983

Control Case No. 7 (Rockwell Dry Test Meter Serial No. 676477)

Date of Last Calibration: December 27, 1982
 Calibration Technician: D. Stock
 Wet Test Meter No.: American Meter AL-20

Date of Use	Job No.	Initial Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
January 26, 1983	3-1446	204.42	107.29	107.29
February 17, 1983	3-1466	312.60	220.75	328.04
February 18, 1983	3-1466	533.80	124.70	452.74
February 18, 1983	3-1466	658.70	165.37	618.11

*Total volume through meter since last calibration

Pitot Tube Calibration
 Data Sheet

Date of Cal: December 18, 1982 Pitot Tube Number 6
 Technician: J. Stock

Direction A

U* (fps)	H std* (in. wc)	Actual H std (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.09	0.12	0.8660
40	0.37	0.37	0.52	0.8435
60	0.82	0.79	1.11	0.8436
80	1.46	1.45	2.00	0.8515
100	2.29	2.30	3.21	0.8465

Average Coefficient: 0.8502

Direction B

U* (fps)	H std* (in. wc)	Actual H std (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.10	0.13	0.8771
40	0.37	0.36	0.50	0.8485
60	0.82	0.83	1.12	0.8609
80	1.46	1.47	2.03	0.8510
100	2.29	2.31	3.23	0.8457

Average Coefficient: 0.8566

Overall Average Coefficient: 0.8534

Pitot Tube Calibration
 Data Sheet

Date of Cal: December 18, 1982 Pitot Tube Number 20
 Technician: J. Stock

Direction A

U* (fps)	H std* (in. wc)	Actual H (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.09	0.12	0.8660
40	0.37	0.38	0.53	0.8467
60	0.82	0.82	1.12	0.8557
80	1.46	1.45	2.00	0.8515
100	2.29	2.30	3.19	0.8421

Average Coefficient: 0.8515

Direction B

U* (fps)	H std* (in. wc)	Actual H (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.09	0.12	0.8660
40	0.37	0.38	0.53	0.8467
60	0.82	0.82	1.12	0.8557
80	1.46	1.45	2.00	0.8515
100	2.29	2.35	3.05	0.8778

Average Coefficient: 0.8595

Overall Average Coefficient: 0.8555

Pitot Tube Calibration
 Data Sheet

Date of Cal: December 18, 1982 Pitot Tube Number 10
 Technician: J. Stock

Direction A

U* (fps)	H std* (in. wc)	Actual H std (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.08	0.11	0.8528
40	0.37	0.40	0.53	0.8687
60	0.82	0.80	1.10	0.8528
80	1.46	1.50	2.00	0.8660
100	2.29	2.30	3.11	0.8600

Average Coefficient: 0.8601

Direction B

U* (fps)	H std* (in. wc)	Actual H std (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.08	0.11	0.8528
40	0.37	0.39	0.54	0.8498
60	0.82	0.80	1.10	0.8528
80	1.46	1.45	1.95	0.8623
100	2.29	2.20	3.05	0.8493

Average Coefficient: 0.8534

Overall Average Coefficient: 0.8567

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Pitot Tube Calibration
Data Sheet

Date of Cal: January 18, 1983 Pitot Tube No. 21
Technician: J. Stock

Direction A

U* (fps)	H std* (in. wc)	Actual H std (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.08	0.11	0.8466
40	0.37	0.39	0.54	0.8498
60	0.82	0.80	1.11	0.8490
80	1.46	1.45	2.02	0.8472
100	2.29	2.25	3.12	0.8492

Average Coefficient: 0.8485

Direction B

U* (fps)	H std* (in. wc)	Actual H std (in. wc)	H s-type (in. wc)	Coeff
20	0.09	0.08	0.11	0.8466
40	0.37	0.39	0.54	0.8498
60	0.82	0.80	1.11	0.8490
80	1.46	1.45	2.02	0.8472
100	2.29	2.25	3.12	0.8492

Average Coefficient: 0.8484

Overall Average Coefficient: 0.8484

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

Nozzle Calibration
Data Sheet

Date: 10/10/66
Technician: J. J. [unclear]

to nearest 0.001

Readings

1	0.246
2	0.246
3	0.247
4	0.245
5	0.246

Average:

0.246

Nozzle Calibration
Data Sheet

Date of Cal: February 17, 1983
Technician: Stock

Nozzle No. 1015

Nozzle checked by 30 degree increments and rounded to nearest .001 inch. Observed readings and average:

Position

1	0.310
2	0.310
3	0.311
4	0.309
5	0.310

Average:

0.310

Interpoll Report No. 3-1466
Lehigh Portland Cement Company
Mason City, Iowa

1	
2	0.184
3	0.190
4	0.192
5	0.186

Average: 0.188

Nozzle Calibration
Data Sheet

Date of Cal: February 18, 1983
Technician: C. Manson

Nozzle Number 7.2

Nozzle rotated by 36 degree increments and diameter measured
nearest 0.001 inch. Observed readings and average:

Position	Diameter (inches)
1	0.254
2	0.254
3	0.255
4	0.253
5	0.254
Average:	0.254