

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

51
AP-42 Section 11.6
Reference AP 42-60
Report Sect. 4
Reference 49



ASH GROVE CEMENT WEST, INC.

330 CEMENT PLANT ROAD
P.O. BOX 5
DURKEE, OREGON 97905
(503) 877-2411

May 13, 1987

Mr. Frank Noonan
Monitoring and Data Analysis Division
U.S. Environmental Protection Agency
Mail Drop 14
Research Triangle Park, NC 27711

Dear Mr. Noonan:

Mr. Robert Crolius, Director of Public Affairs for the Portland Cement Association has requested that member plants send data to you on the NOX emission as measured in the stacks from their Portland Cement kilns.

I am sending you a report on a test performed September 15, 1985 by Mr. David R. Rossman, P.E., Horizon Engineering on our kiln.

In addition I am sending you copies of our daily plant reports for the month of April 1987. Plant report #6 shows the hourly NOX. At the bottom of the page the maximum, minimum and mean of the values are noted for the 24 hour calendar day. To calculate the ppm NOX, the % NOXST reading is multiplied times 2500, i.e. a 50% reading would equal 1250 ppm.

In addition to the coal burned we are using 3.5 to 4 gallons per minute of used motor oil in our four stage preheater kiln. This oil is not included on the plant reports.

Attached is a reprint from the July 1980 Pit & Quarry magazine that describes this plant.

I will be happy to supply further information if you need it.


Very truly yours,

ASH GROVE CEMENT WEST, INC.

Richard E. Cooke
Plant Manager

REC:mm

Enclosures



505 N.E. Thompson Mill Road

Corbett, Oregon 97019

503/695-2151

NOX EMISSION TEST REPORT

ASHGROVE CEMENT WEST, INC.
DURKEE, OREGON CEMENT PLANT


September 15, 1985

Prepared For

Ashgrove Cement West, Inc.
111 S.E. Madison Street
Portland, Oregon 97214

by

David R. Rossman, P.E.



ASHGROVE CEMENT WEST, DURKEE, OREGON

Introduction and Summary of Results

Ashgrove Cement West, Inc. is planning on constructing a plant in the Seattle, Washington area and needed information to predict the amount of NOx that will be emitted from that plant. Since the plant to be constructed is similar to a plant already in operation near Durkee, Oregon, it was decided to obtain data from that plant. Although that plant has a continuous NOx monitor, it samples the kiln exhaust very near the kiln. Since the exhaust gases are used to preheat the kiln raw material and there is a considerable amount of ductwork and therefore residence time associated with this preheating, it was considered possible that the concentration measured at the exit of the kiln is not representative of the exhaust discharge to the atmosphere. It was decided to take samples near the stack discharge to more accurately determine the impact on the atmosphere.

The results of the testing are in the table below. The five results are with the plant running at steady state on type II cement, using EPA Method 7 sampling and analytical methods.

Time, 24 hr-	10:27	11:02	11:32	12:33	13:01
Concentration, NOx lb/scfd-	6 4.8	7 5.3	8 4.0	2 6.9	3 7.5
	*10-5	*10-5	*10-5	*10-5	*10-5
NOx ppm-	410	445	340	572	634

Concentration, NOx lb/scfd-	Average Values
NOx ppm-	5.7*10-5 480

Production, tph clinker-	60.8
tph feed-	100.1

Stack Flow, scfm-	89,700
(based on 11/84 stack test @ 105 tph feed)	

lb NOx/hr-	307.
lb NOx/ton product-	5.06

ASH GROVE CEMENT WEST, DURKEE, OREGON

Sampling and Analytical Methods

Sampling and analytical methods conformed to EPA Method 7. This method uses evacuated two liter flasks loaded with an absorbing solution for collecting the sample, and after several pretreatment steps the samples are analyzed with a spectrophotometer. Complete laboratory analysis of the collected samples was done by Antech, but spectrophotometer readings were confirmed on another machine at Aqua Tech. Although the results from both labs were close, the readings from Aqua Tech were used for calculation purposes because the standard curve generated on their machine was straighter and all sample absorption data was within the standard curve range.

Sampling was done through the south port normally used for particulate testing. Samples were drawn from a single point about 2 feet into the stack and about a foot upstream (down) from the sampling port. The sampling probe was a piece of 1/4 in o.d. stainless steel tubing feeding into a heated manifold before the flask. Heating was controlled to eliminate condensation in the glass valve at the top of the flask as the system was being purged.

Details of the sampling and lab procedures are in the complete copy of the EPA method included in the appendix.

Plant Description and Operation

The plant tested is a coal fired, refractory lined rotary kiln, and was running a type II cement on the test date. Exhaust from the kiln is used to preheat incoming raw material and is then cleaned in an electrostatic precipitator system. Fans on the outlet of the precipitator discharge into an insulated stack several hundred feet tall. Sampling ports are about 50 feet below the stack discharge.

Plant operation is continuously monitored with a computer system, and printouts of most of the data is included in the appendix. One of the two kiln exhaust NOx monitors was disconnected during part of the testing to allow checking some bag samples taken from the test location. Data from the other monitor was only available on an hourly basis.


ASHGROVE CEMENT WEST, DURKEE, OREGON

Discussion

The figure on the next page shows the sampling data and the data from the continuous monitors at the kiln outlet. The difference in concentration between the two locations is substantial.

The results of one of the test flasks was not included in the average calculations. When compared with the other data points, it appeared out of line, and examinations of the sampling data, lab procedure, and plant operation did not give any clues on why. One statistical technique to test dubious data points is called Chauvenet's Criterion. This test, referenced and detailed in the appendix, permitted that data point to be excluded from the averages.

O. S. U. BOOK STORES, INC.
10 x 10 to the 1/2 inch No. 20



ASHGROVE CEMENT WEST, DURKEE, OREGON

APPENDICES

- field data and calculations
- laboratory results
- statistical analysis
- EPA Method 7
- plant operation records

DETERMINATION OF NITROGEN OXIDE EMISSIONS - EPA METHOD 7

SOURCE ASH GROVE CEMENT
 DATE SEPT 15, 1985
 OPERATOR ROSSMAN
 OPERATING CONDITIONS OF SOURCE
TYPE 2 CEMENT

AQUA TECH LAB

		BLANKS							
Flask number		5	6	7	8	1	2	3	4
V _f	Volume of flask and valve, ml.	2080	2050	2060	2070	2050	2100	2090	2050
	Date of initial readings <u>9/15/85</u> , time,	10:27	11:02	11:32	12:00	12:33	13:01	10:15	10:15
T _{if}	Initial temperature of flask, °F	62	62	62	63	64	70	70	70
T _{ir}	Initial absolute temperature of flask, °R	522	522	522	523	524	530	530	530
P _{bi}	Initial barometric pressure, in. Hg. <i>(taken at the sampling elevation)</i>	27.12	27.12	27.12	27.09	27.09	27.09	27.12	27.12
P _{mi}	Initial manometer readings, in. Hg.	-26.45	-26.45	-26.60	-26.30	-26.25	-26.25	Not Evaluated	0.0
P _i	Initial absolute pressure of flask, P _i = P _{bi} + P _{mi} , in. Hg	.67	.67	.52	.79	.84	.84	27.12	27.12
	Date of final readings <u>9/16/85</u> , time,	0600	0605	0610	0615	0620	0625	0630	0635
P _{bf}	Final barometric pressure, in. Hg.	28.81							
P _{mf}	Final manometer reading, in. Hg.	-10.30	-2.25	-2.60	-2.10	-2.45	-3.60	-1.85	-1.75
P _f	Final absolute pressure of flask P _f = P _{bf} + P _{mf} , in. Hg.	18.51	26.56	26.21	26.71	26.36	25.21	26.96	27.00
T _{ff}	Final temperature of flask, °F	60	60	60	60	60	60	60	60
T _{fr}	Final absolute temperature of flask, °R	520	520	520	520	520	520	520	520
V _a	Volume of absorbing solution, ml	25	25	25	25	25	25	25	25
V _{sc}	$17.64 (V_f - V_a) \left(\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right)$, ml	1243.8	1778.7	1773.6	1798.5	1753.5	1716.5	—	—
M	Mass of NO ₂ in gas sample, μg AQUATECH	971.4	1509.0	1147.5	471.6	1911.4	2074.8	—	—
C	$6.243 \times 10^{-5} \left(\frac{M}{V} \right)$, $(\text{lb/scf} \times 10^6)^{sc} \times 8.406 = \text{PPM}$	4.876 $\times 10^{-5}$	5.296 $\times 10^{-5}$	4.039 $\times 10^{-5}$	1.237 $\times 10^{-5}$	6.805 $\times 10^{-5}$	7.546 $\times 10^{-5}$	—	—
	Average C NO ₂ ,	lb/scf	$5.71 \times 10^{-5}^*$						
		PPM	480*						

* excluding #8

ASHGROVE CEMENT

AQUA-TECH SPECTROPHOTOMETER

$$K_c = 100 \cdot \frac{A_1 + 2A_2 + 3A_3 + 4A_4}{A_1^2 + A_2^2 + A_3^2 + A_4^2}$$

Std. Curve Data:	<u>ug</u>	<u>Absorbance</u>	<u>A_x</u>
	100	.100	1
	200	.254	2
	300	.400	3
	400	.500	4

$$K_c = 100 \left[\frac{.100 + 2(.254) + 3(.400) + 4(.500)}{(.100)^2 + (.254)^2 + (.400)^2 + (.500)^2} \right]$$

$$= 785.939$$

3.808
.4845

$m = 2K_c AF$ where $m = \text{mass of NO}_x (\text{as NO}_2) - \mu\text{g}$

$K_c = \text{as above}$

$A = \text{Absorbance}$

$F = \text{dilution factor}$
Mass

<u>Sample #</u>	<u>Dilution</u>	<u>Absorb</u>	<u>Mass</u>
25902	4X	.304	1911.4
25903	4X	.330	2074.8
25906	2X	.309	971.4
25907	2X	.480	1509.0
25908	2X	.365	1147.5
25909	2X	.150	471.6

ASHGROVE CEMENT

AQUA TECH LAB RESULTS (CONT.)

<u>Sample #</u>	<u>Conc.</u> <u>lb/scf</u>	<u>Conc.</u> <u>ppm</u>
25902	6.805×10^5	572.0
3	7.546 "	634.3
6	4.876 "	409.9
7	5.296 "	445.2
8	4.039 "	339.5
9	1.637 "	137.6

Production Basis

$$\frac{\text{lb NO}_x}{\text{ton clinker}} = \frac{\text{lb NO}_x}{\text{scfd}} \times \frac{\text{scfd}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{hr}}{\text{tons clinker}}$$

$$= 5.056 \text{ lb NO}_x / \text{ton clinker}$$

$$5.03 \times 10^{-5} \times X \times \frac{60 \times}{60.8} = 5.056$$

NO_x - lb/scfd \rightarrow ppm conversion

$$\frac{\text{lb NO}_2}{\text{ft}^3 \text{ air}} \times \frac{386 \text{ ft}^3}{\text{lb-mole}} \times \frac{\text{lb-mole}}{46 \text{ lb-NO}_2}$$

$$\frac{\text{lb NO}_2}{\text{ft}^3 \text{ air}} \times 8.406 \frac{\text{ft}^3}{\text{lb NO}_2} = \text{dimensionless}$$

$$\begin{aligned} \therefore 6.013 \times 10^{-5} \text{ lb/scfd} \\ = 60.13 \times 10^{-6} \text{ lb/scfd} \end{aligned}$$

$$\begin{aligned} \times 8.406 &= 505.5 \times 10^{-6} \\ &= 505.5 \text{ ppm} \end{aligned}$$

Ashgrove Cement - Data Check

"Experimental Methods for Engineers", p 53, J.P. Holman, 1961
 Chauvenet's Criterion: "A reading may be rejected if the probability of obtaining the particular deviation from the mean is less than $1/2^n$ "

<u>Date</u>	<u>Value-ppm</u>	<u>Deviation</u>
5	409.9	-13.18
6	445.2	22.12
7	339.5	-83.58
8	137.6	-285.48
1	572.0	+148.92
2	<u>634.3</u>	+211.22

$$x_m = 423.08$$

Standard Deviation

$$\sigma = \left[\frac{1}{n} \sum_{i=1}^n (x_i - x_m)^2 \right]^{1/2}$$

where $n = 6$

and $x_i - x_m$ are from the table above

$$\sigma = 161.2$$

From table 3-4 For $n=6$, the ratio of maximum acceptable deviation to standard deviation is 1.73 ^($\frac{d_{max}}{\sigma}$)

$$\frac{d_{max}}{\sigma} = 1.73$$

$$\begin{aligned} \therefore d_{max} &= 1.73(\sigma) \\ &= 278.9 \end{aligned}$$

\therefore data point no. 8 can be rejected

Ashgrove Cement - Data Check (cont.)

According to the method, a new mean value and standard deviation may be computed with the dubious data point eliminated from the calculation.

<u>Data</u>	<u>Value</u>	<u>Deviation</u>
5	409.9	-70.3
6	445.2	-35.0
7	339.5	-140.7
1	572.0	+91.8
2	<u>634.3</u>	154.1

$$\bar{x}_m = 480.18$$

$$\text{Std. Dev.} = \sigma = 107.8$$

3.3.5 Sulfuric Acid Standard, 0.0100 N. Purchase or standardize to =0.0002 N against 0.0100 N NaOH which has previously been standardized against potassium acid phthalate (primary standard grade).

4. Procedure.

4.1 Sampling.

4.1.1 Preparation of collection train. Measure 15 ml of 80 percent isopropanol into the midget bubbler and 15 ml of 3 percent hydrogen peroxide into each of the first two midget impingers. Leave the final midget impinger dry. Assemble the train as shown in Figure 6-1. Adjust probe heater to a temperature sufficient to prevent water condensation. Place crushed ice and water around the impingers.

4.1.2 Leak-check procedure. A leak check prior to the sampling run is optional; however, a leak check after the sampling run is mandatory. The leak-check procedure is as follows:

Temporarily attach a suitable (e.g., 0-40 cc/min) rotameter to the outlet of the dry gas meter and place a vacuum gauge at or near the probe inlet. Plug the probe inlet, pull a vacuum of at least 250 mm Hg (10 in. Hg), and note the flow rate as indicated by the rotameter. A leakage rate not in excess of 2 percent of the average sampling rate is acceptable.

NOTE: Carefully release the probe inlet plug before turning off the pump.

It is suggested (not mandatory) that the pump be leak-checked separately, either prior to or after the sampling run. If done prior to the sampling run, the pump leak-check shall precede the leak check of the sampling train described immediately above; if done after the sampling run, the pump leak-check shall follow the train leak-check. To leak check the pump, proceed as follows: Disconnect the drying tube from the probe-impinger assembly. Place a vacuum gauge at the inlet to either the drying tube or the pump, pull a vacuum of 250 mm (10 in.) Hg, plug or pinch off the outlet of the flow meter and then turn off the pump. The vacuum should remain stable for at least 30 seconds.

Other leak-check procedures may be used, subject to the approval of the Administrator, U.S. Environmental Protection Agency.

4.1.3 Sample collection. Record the initial dry gas meter reading and barometric pressure. To begin sampling, position the tip of the probe at the sampling point, connect the probe to the bubbler, and start the pump. Adjust the sample flow to a constant rate of approximately 1.0 liter/min as indicated by the rotameter. Maintain this constant rate (=10 percent) during the entire sampling run. Take readings (dry gas meter, temperatures at dry gas meter and at impinger outlet and rate meter) at least every 5 minutes. Add more ice during the run to keep the temperature of the gases leaving the last impinger at 20° C (68° F) or less. At the conclusion of each run, turn off the pump, remove probe from the stack, and record the final readings. Conduct a leak check as in Section 4.1.2. (This leak check is mandatory.)

If a leak is found, void the test run, or use procedures acceptable to the Administrator to adjust the sample volume for the leakage. Drain the ice bath, and purge the remaining part of the train by drawing clean ambient air through the system for 15 minutes at the sampling rate.

Clean ambient air can be provided by passing air through a charcoal filter or through an extra midget impinger with 15 ml of 3 percent H₂O₂. The tester may opt to simply use ambient air, without purification.

4.2 Sample Recovery. Disconnect the impingers after purging. Discard the contents of the midget bubbler. Pour the contents of the midget impingers into a leak-free polyethylene bottle for shipment. Rinse the three midget impingers and the connecting tubes with deionized, distilled water, and add the washings to the same storage

container. Mark the fluid level. Seal and identify the sample container.

4.3 Sample Analysis. Note level of liquid in container, and confirm whether any sample was lost during shipment; note this on analytical data sheet. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results.

Transfer the contents of the storage container to a 100-ml volumetric flask and dilute to exactly 100 ml with deionized, distilled water. Pipette a 20-ml aliquot of this solution into a 250-ml Erlenmeyer flask, add 80 ml of 100 percent isopropanol and two to four drops of thion indicator, and titrate to a pink endpoint using 0.0100 N barium perchlorate. Repeat and average the titration volumes. Run a blank with each series of samples. Replicate titrations must agree within 1 percent or 0.2 ml, whichever is larger.

(NOTE.—Protect the 0.0100 N barium perchlorate solution from evaporation at all times.)

5. Calibration

5.1 Metering System.

5.1.1 Initial Calibration. Before its initial use in the field, first leak check the metering system (drying tube, needle valve, pump, rotameter, and dry gas meter) as follows: place a vacuum gauge at the inlet to the drying tube and pull a vacuum of 250 mm (10 in.) Hg; plug or pinch off the outlet of the flow meter, and then turn off the pump. The vacuum shall remain stable for at least 30 seconds. Carefully release the vacuum gauge before releasing the flow meter end.

Next, calibrate the metering system (at the sampling flow rate specified by the method) as follows: connect an appropriately sized wet test meter (e.g., 1 liter per revolution) to the inlet of the drying tube. Make three independent calibration runs, using at least five revolutions of the dry gas meter per run. Calculate the calibration factor, Y (wet test meter calibration volume divided by the dry gas meter volume, both volumes adjusted to the same reference temperature and pressure), for each run, and average the results. If any Y value deviates by more than 2 percent from the average, the metering system is unacceptable for use. Otherwise, use the average as the calibration factor for subsequent test runs.

5.1.2 Post-Test Calibration Check. After each field test series, conduct a calibration check as in Section 5.1.1 above, except for the following variations: (a) the leak check is not to be conducted, (b) three, or more revolutions of the dry gas meter may be used, and (c) only two independent runs need be made. If the calibration factor does not deviate by more than 5 percent from the initial calibration factor (determined in Section 5.1.1), then the dry gas meter volumes obtained during the test series are acceptable. If the calibration factor deviates by more than 5 percent, recalibrate the metering system as in Section 5.1.1, and for the calculations, use the calibration factor (initial or recalibration) that yields the lower gas volume for each test run.

5.2 Thermometers. Calibrate against mercury-in-glass thermometers.

5.3 Rotameter. The rotameter need not be calibrated but should be cleaned and maintained according to the manufacturer's instruction.

5.4 Barometer. Calibrate against a mercury barometer.

5.5 Barium Perchlorate Solution. Standardize the barium perchlorate solution against 25 ml of standard sulfuric acid to which 100 ml of 100 percent isopropanol has been added.

6. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

6.1 Nomenclature.

- C_{SO_2} = Concentration of sulfur dioxide, dry basis corrected to standard conditions, mg/dscfm (lb/dscf).
- N = Normality of barium perchlorate titrant, milliequivalents/ml.
- P_{bar} = Barometric pressure at the exit orifice of the dry gas meter, mm Hg (in. Hg).
- P_{std} = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).
- T_m = Average dry gas meter absolute temperature, °K (°R).
- T_{std} = Standard absolute temperature, 293° K (528° R).
- V_s = Volume of sample aliquot titrated, ml.
- V_m = Dry gas volume as measured by the dry gas meter, dcm (dcl).
- $V_{m(Std)}$ = Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf).

V_{soln} = Total volume of solution in which the sulfur dioxide sample is contained, 100 ml.

V_t = Volume of barium perchlorate titrant used for the sample, ml (average of replicate titrations).

V_{blnk} = Volume of barium perchlorate titrant used for the blank, ml.

Y = Dry gas meter calibration factor.

32.03 = Equivalent weight of sulfur dioxide.

6.2 Dry sample gas volume, corrected to standard conditions.

$$V_{m(Std)} = V_m Y \left(\frac{T_{std}}{T_m} \right) \left(\frac{P_{bar}}{P_{std}} \right) = K_1 Y \frac{V_m P_{bar}}{T_m}$$

where:

K_1 = 0.3558 °K/mm. Hg for metric units.

= 17.64 °R/in. Hg for English units.

6.3 Sulfur dioxide concentration.

$$C_{SO_2} = K_2 \frac{(V_t - V_{blnk}) N \left(\frac{V_{soln}}{V_m} \right)}{V_{m(Std)}} \quad \text{Equation 6-2}$$

where:

K_2 = 32.03 mg/meq. for metric units.

= 7.061 X 10⁻⁴ lb/meq. for English units.

7. Bibliography

1. Atmospheric Emissions from Sulfuric Acid Manufacturing Processes. U.S. DHEW, PHS, Division of Air Pollution. Public Health Service Publication No. 999-AP-13. Cincinnati, Ohio, 1965.
2. Corbett, P. F. The Determination of SO₂ and SO₃ in Flue Gases. Journal of the Institute of Fuel, 4: 237-243, 1961.
3. Matty, R. E. and E. K. Diehl. Measuring Fine-Gas SO₂ and SO₃. Power, 101: 64-67, November 1957.
4. Patton, W. F. and J. A. Brink, Jr. New Equipment and Techniques for Sampling Chemical Process Gases. J. Air Pollution Control Association, 13: 162, 1963.
5. Rom, J. J. Maintenance, Calibration, and Operation of Isokinetic Source-Sampling Equipment. Office of Air Programs, Environmental Protection Agency, Research Triangle Park, N.C. APTD-0576, March 1972.
6. Hamill, H. P. and D. E. Camann. Collaborative Study of Method for the Determination of Sulfur Dioxide Emissions from Stationary Sources (Fossil-Fuel Fired Steam Generators). Environmental Protection Agency, Research Triangle Park, N.C. EPA-650/4-74-024, December 1974.
7. Annual Book of ASTM Standards, Part 21: Water, Atmospheric Analysis. American Society for Testing and Materials, Philadelphia, Pa. 1974, pp. 40-42.
8. Knoll, J. E. and M. R. Middett. The Application of EPA Method 6 to High Sulfur Dioxide Concentrations. Environmental Protection Agency, Research Triangle Park, N.C. EPA-600/4-76-005, July 1976.

METHOD 7—DETERMINATION OF NITROGEN OXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and Applicability

1.1 Principle. A grab sample is collected in an evacuated flask containing a dilute sulfuric acid-hydrogen peroxide absorbing solution, and the nitrogen oxides, except nitrous oxide, are measured colorimetrically using the phenoldisulfonic acid (PDS) procedure.

1.2 Applicability. This method is applicable to the measurement of nitrogen oxides emitted from stationary sources. The range of the method has been determined to be 2 to 400 milligrams NO_x (as NO₂) per dry standard cubic meter, without having to dilute the sample.

2. Apparatus

2.1 Sampling (see Figure 7-1). Other grab sampling systems or equipment, capable of measuring sample volume to within ±2.0 percent and collecting a sufficient sample volume to allow analytical reproducibility to within ±5 percent, will be considered acceptable alternatives, subject to approval of the Administrator, U.S. Environmental Protection Agency. The following equipment is used in sampling:

2.1.1 Probe. Borosilicate glass tubing, sufficiently heated to prevent water condensation and equipped with an in-stack or out-stack filter to remove particulate matter (a plug of glass wool is satisfactory for this purpose). Stainless steel or Teflon tubing may also be used for the probe. Heating is not necessary if the probe remains dry during the purging period.

1. Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.




Figure 7-1. Sampling train, flask valve, and flask.

2.1.2 Collection Flask. Two-liter borosilicate, round bottom flask, with short neck and 24:40 standard taper opening, protected against implosion or breakage.

2.1.3 Flask Valve. T-bore stopcock connected to a 24:40 standard taper joint.

2.1.4 Temperature Gauge. Dial-type thermometer, or other temperature gauge, capable of measuring 1° C (2° F) intervals from -5 to 30° C (25 to 125° F).

2.1.5 Vacuum Line. Tubing capable of withstanding a vacuum of 75 mm Hg (3 in. Hg) absolute pressure, with "T" connection and T-bore stopcock.

2.1.6 Vacuum Gauge. U-tube manometer, 1 meter (36 in.), with 1-mm (0.1-in.) divisions, or other gauge capable of measuring pressure to within ± 2.5 mm Hg (0.10 in. Hg).

2.1.7 Pump. Capable of evacuating the collection flask to a pressure equal to or less than 75 mm Hg (3 in. Hg) absolute.

2.1.8 Squeeze Bulb. One-way.

2.1.9 Volumetric Pipette. 25 ml.

2.1.10 Stopcock and Ground Joint Grease. A high-vacuum, high-temperature chlorofluorocarbon grease is required. Hakocarbon 24-55 has been found to be effective.

2.1.11 Barometer. Mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg). In many cases, the barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the weather station and sampling point shall be applied at a rate of minus 2.5 mm Hg (0.1 in. Hg) per 30 m (100 ft) elevation increase, or vice versa for elevation decrease.

2.2 Sample Recovery. The following equipment is required for sample recovery:

2.2.1 Graduated Cylinder. 50 ml with 1-ml divisions.

2.2.2 Storage Containers. Leak-free polyethylene bottles.

2.2.3 Wash Bottle. Polyethylene or glass.

2.2.4 Glass Stirring Rod.

2.2.5 Test Paper for Indicating pH. To cover the pH range of 7 to 14.

2.3 Analysis. For the analysis, the following equipment is needed:

2.3.1 Volumetric Pipettes. Two 1 ml, two 2 ml, one 4 ml, two 10 ml, and one 25 ml for each sample and standard.

2.3.2 Porcelain Evaporating Dishes. 175- to 250-ml capacity with lip for pouring, one for each sample and each standard. The Coors No. 45006 (shallow-form, 195 ml) has been found to be satisfactory. Alternatively, polymethyl pentene beakers (Nalgae No. 1203, 150 ml), or glass beakers (150 ml) may be used. When glass beakers are used, etching of the beakers may cause solid matter to be present in the analytical step; the solids should be removed by filtration (see Section 4.3).

2.3.3 Steam Bath. Low-temperature ovens or thermostatically controlled hot plates kept below 70° C (160° F) are acceptable alternatives.

2.3.4 Dropping Pipette or Dropper. Three required.

2.3.5 Polyethylene Policeman. One for each sample and each standard.

2.3.6 Graduated Cylinder. 100 ml with 1-ml divisions.

2.3.7 Volumetric Flasks. 50 ml (one for each sample and each standard), 100 ml (one for each sample and each standard, and one for the working standard KNO₃ solution), and 1000 ml (one).

2.3.8 Spectrophotometer. To measure absorbance at 410 nm.

2.3.9 Graduated Pipette. 10 ml with 0.1-ml divisions.

2.3.10 Test Paper for Indicating pH. To cover the pH range of 7 to 14.

2.3.11 Analytical Balance. To measure to within 0.1 mg.

3. Reagents

Unless otherwise indicated, it is intended that all reagents conform to the specifications established by the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available; otherwise, use the best available grade.

3.1 Sampling. To prepare the absorbing solution, cautiously add 2.5 ml concentrated H₂SO₄ to 1 liter of deionized, distilled water. Mix well and add 6 ml of 3 percent hydrogen peroxide, freshly prepared from 30 percent hydrogen peroxide solution. The absorbing solution should be used within 1 week of its preparation. Do not expose to extreme heat or direct sunlight.

3.2 Sample Recovery. Two reagents are required for sample recovery:

3.2.1 Sodium Hydroxide (5N). Dissolve 40 g NaOH in deionized, distilled water and dilute to 1 liter.

3.2.2 Water. Deionized, distilled to conform to ASTM specification D1193-74, Type 3. At the option of the

analyst, the KMnO₄ test for oxidizable organic matter may be omitted when high concentrations of organic matter are not expected to be present.

3.3 Analysis. For the analysis, the following reagents are required:

3.3.1 Fuming Sulfuric Acid. 15 to 18 percent by weight free sulfur trioxide. HANDLE WITH CAUTION.

3.3.2 Phenol. White solid.

3.3.3 Sulfuric Acid. Concentrated, 95 percent minimum assay. HANDLE WITH CAUTION.

3.3.4 Potassium Nitrate. Dried at 105 to 110° C (220 to 230° F) for a minimum of 2 hours just prior to preparation of standard solution.

3.3.5 Standard KNO₃ Solution. Dissolve exactly 2.195 g of dried potassium nitrate (KNO₃) in deionized, distilled water and dilute to 1 liter with deionized, distilled water in a 1,000-ml volumetric flask.

3.3.6 Working Standard KNO₃ Solution. Dilute 10 ml of the standard solution to 100 ml with deionized distilled water. One milliliter of the working standard solution is equivalent to 100 µg nitrogen dioxide (NO₂).

3.3.7 Water. Deionized, distilled as in Section 3.2.2.

3.3.8 Phenoldisulfonic Acid Solution. Dissolve 25 g of pure white phenol in 150 ml concentrated sulfuric acid on a steam bath. Cool, add 75 ml fuming sulfuric acid, and heat at 100° C (212° F) for 2 hours. Store in a dark, stoppered bottle.

4. Procedures

4.1 Sampling.

4.1.1 Pipette 25 ml of absorbing solution into a sample flask, retaining a sufficient quantity for use in preparing the calibration standards. Insert the flask valve stopper into the flask with the valve in the "purge" position. Assemble the sampling train as shown in Figure 7-1 and place the probe at the sampling point. Make sure that all fittings are tight and leak-free, and that all ground glass joints have been properly greased with a high-vacuum, high-temperature chlorofluorocarbon-based stopcock grease. Turn the flask valve and the pump valve to their "evacuate" positions. Evacuate the flask to 75 mm Hg (3 in. Hg) absolute pressure, or less. Evacuation to a pressure approaching the vapor pressure of water at the existing temperature is desirable. Turn the pump valve to its "vent" position and turn off the pump. Check for leakage by observing the manometer for any pressure fluctuation. (Any variation

greater than 10 mm Hg (0.4 in. Hg) over a period of 1 minute is not acceptable, and the flask is not to be used until the leakage problem is corrected. Pressure in the flask is not to exceed 75 mm Hg (3 in. Hg) absolute at the time sampling is commenced. Record the volume of the flask and valve (V_1), the flask temperature (T_1), and the barometric pressure. Turn the flask valve counterclockwise to its "purge" position and do the same with the pump valve. Purge the probe and the vacuum tube using the squeeze bulb. If condensation occurs in the probe and the flask valve area, heat the probe and purge until the condensation disappears. Next, turn the pump valve to its "vent" position. Turn the flask valve clockwise to its "evacuate" position and record the difference in the mercury levels in the manometer. The absolute internal pressure in the flask (P_1) is equal to the barometric pressure less the manometer reading. Immediately turn the flask valve to the "sample" position and permit the gas to enter the flask until pressures in the flask and sample line (i.e., duct, stark) are equal. This will usually require about 15 seconds; a longer period indicates a "plug" in the probe, which must be corrected before sampling is continued. After collecting the sample, turn the flask valve to its "purge" position and disconnect the flask from the sampling train. Shake the flask for at least 5 minutes.

4.1.2 If the gas being sampled contains insufficient oxygen for the conversion of NO to NO₂ (e.g., an applicable subpart of the standard may require taking a sample of a calibration gas mixture of NO in N₂), then oxygen shall be introduced into the flask to permit this conversion. Oxygen may be introduced into the flask by one of three methods: (1) Before evacuating the sampling flask, flush with pure cylinder oxygen, then evacuate flask to 75 mm Hg (3 in. Hg) absolute pressure or less; or (2) inject oxygen into the flask after sampling; or (3) terminate sampling with a minimum of 50 mm Hg (2 in. Hg) vacuum remaining in the flask, record this final pressure, and then vent the flask to the atmosphere until the flask pressure is almost equal to atmospheric pressure.

4.2 Sample Recovery. Let the flask set for a minimum of 16 hours and then shake the contents for 2 minutes. Connect the flask to a mercury filled U-tube manometer. Open the valve from the flask to the manometer and record the flask temperature (T_2), the barometric pressure, and the difference between the mercury levels in the manometer. The absolute internal pressure in the flask (P_2) is the barometric pressure less the manometer reading. Transfer the contents of the flask to a leak-free polyethylene bottle. Rinse the flask twice with 5-ml portions of deionized, distilled water and add the rinse water to the bottle. Adjust the pH to between 9 and 12 by adding sodium hydroxide (1 N), dropwise (about 25 to 35 drops). Check the pH by dipping a stirring rod into the solution and then touching the rod to the pH test paper. Remove as little material as possible during this step. Mark the height of the liquid level so that the container can be checked for leakage after transport. Label the container to clearly identify its contents. Seal the container for shipping.

4.3 Analysis. Note the level of the liquid in container and confirm whether or not any sample was lost during shipment; note this on the analytical data sheet. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Immediately prior to analysis, transfer the contents of the shipping container to a 50-ml volumetric flask, and rinse the container twice with 5-ml portions of deionized, distilled water. Add the rinse water to the flask and dilute to the mark with deionized, distilled water; mix thoroughly. Pipette a 25-ml aliquot into the porcelain evaporating dish. Return any unused portion of the sample to the polyethylene storage bottle. Evaporate the 25-ml aliquot to dryness on a steam bath and allow to cool. Add 2 ml phenoldisulfonic acid solution to the dried residue and triturate thoroughly with a polyethylene policeman. Make sure the solution contacts all the residue. Add 1 ml deionized, distilled water and four drops of concentrated sulfuric acid. Heat the solution on a steam bath for 3 minutes with occasional stirring. Allow the solution to cool, add 20 ml deionized, distilled water, mix well by stirring, and add concentrated ammonium hydroxide, dropwise, with constant stirring, until the pH is 10 (as determined by pH paper). If the sample contains solids, these must be removed by filtration (centrifugation is an acceptable alternative, subject to the approval of the Administrator), as follows: filter through Whatman No. 41 filter paper into a 100-ml volumetric flask; rinse the evaporating dish with three 5-ml portions of deionized, distilled water; filter these three rinses. Wash the filter with at least three 15-ml portions of deionized, distilled water. Add the filter washings to the contents of the volumetric flask and dilute to the mark with deionized, distilled water. If

solids are absent, the solution can be transferred directly to the 100-ml volumetric flask and diluted to the mark with deionized, distilled water. Mix the contents of the flask thoroughly, and measure the absorbance at the optimum wavelength used for the standards (Section 5.2.1), using the blank solution as a zero reference. Dilute the sample and the blank with equal volumes of deionized, distilled water if the absorbance exceeds A_1 , the absorbance of the 400- μ g NO₂ standard (see Section 5.2.2).

5. Calibration

5.1 Flask Volume. The volume of the collection flask-flask valve combination must be known prior to sampling. Assemble the flask and flask valve and fill with water, to the stopcock. Measure the volume of water to ± 10 ml. Record this volume on the flask.

5.2 Spectrophotometer Calibration.
5.2.1 Optimum Wavelength Determination. Calibrate the wavelength scale of the spectrophotometer every 6 months. The calibration may be accomplished by using an energy source with an intense line emission such as a mercury lamp, or by using a series of glass filters spanning the measuring range of the spectrophotometer. Calibration materials are available commercially and from the National Bureau of Standards. Specific details on the use of such materials should be supplied by the vendor, generally. Information about calibration techniques can be obtained from general reference books on analytical chemistry. The wavelength scale of the spectrophotometer must read correctly within ± 5 nm at all calibration points; otherwise, the spectrophotometer shall be repaired and recalibrated. Once the wavelength scale of the spectrophotometer is in proper calibration, use 415 nm as the optimum wavelength for the measurement of the absorbance of the standards and samples.

Alternatively, a scanning procedure may be employed to determine the proper measuring wavelength. If the instrument is a double-beam spectrophotometer, scan the spectrum between 400 and 415 nm using a 200- μ g NO₂ standard solution in the sample cell and a blank solution in the reference cell. If a peak does not occur, the spectrophotometer is probably malfunctioning and should be repaired. When a peak is obtained within the 400 to 415 nm range, the wavelength at which this peak occurs shall be the optimum wavelength for the measurement of absorbance of both the standards and the samples. For a single-beam spectrophotometer, follow the scanning procedure described above, except that the blank and standard solutions shall be scanned separately. The optimum wavelength shall be the wavelength at which the maximum difference in absorbance between the standards and the blank occurs.

5.2.2 Determination of Spectrophotometer Calibration Factor K_c .

Determination of Spectrophotometer Calibration Factor K_c . Add 0.0 ml, 2 ml, 4 ml, 6 ml, and 8 ml of the KNO₃ working standard solution (1 ml = 100 μ g NO₂) to a series of five 50-ml volumetric flasks. To each flask, add 25 ml of absorbing solution, 10 ml deionized, distilled water, and sodium hydroxide (1 N) dropwise until the pH is between 9 and 12 (about 25 to 35 drops each). Dilute to the mark with deionized, distilled water. Mix thoroughly and

pipette a 25-ml aliquot of each solution into a separate porcelain evaporating dish.

Beginning with the evaporation step, follow the analysis procedure of Section 4.3, until the solution has been transferred to the 100-ml volumetric flask and diluted to the mark. Measure the absorbance of each solution at the optimum wavelength, as determined in Section 5.2.1. This calibration procedure must be repeated on each day that samples are analyzed. Calculate the spectrophotometer calibration factor as follows:

$$K_c = 100 \frac{A_1 + 2A_2 + 3A_3 + 4A_4}{A_1^2 + A_2^2 + A_3^2 + A_4^2} \quad \text{Equation 7-1}$$

where:

- K_c = Calibration factor
- A_1 = Absorbance of the 100- μ g NO₂ standard
- A_2 = Absorbance of the 200- μ g NO₂ standard
- A_3 = Absorbance of the 300- μ g NO₂ standard
- A_4 = Absorbance of the 400- μ g NO₂ standard
- 5.3 Barometer. Calibrate against a mercury barometer.
- 5.4 Temperature Gauge. Calibrate dial thermometers against mercury-in-glass thermometers.
- 5.5 Vacuum Gauge. Calibrate mechanical gauges, if used, against a mercury manometer such as that specified in 2.1.6.
- 5.6 Analytical Balance. Calibrate against standard weights.

6. Calculations

Carry out the calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculations.

6.1 Nomenclature.

- A = Absorbance of sample.
- C = Concentration of NO₂ as NO₂, dry basis, corrected to standard conditions, mg/dscm (lb/dscf).
- F = Dilution factor (i.e., 25%, 25/100, etc., required only if sample dilution was needed to reduce the absorbance into the range of calibration).
- K_c = Spectrophotometer calibration factor.
- m = μ g of NO₂ as NO₂ in gas sample, μ g.
- P_1 = Final absolute pressure of flask, mm Hg (in. Hg).
- P_2 = Initial absolute pressure of flask, mm Hg (in. Hg).
- P_{std} = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).
- T_1 = Final absolute temperature of flask, °K (°R).
- T_2 = Initial absolute temperature of flask, °K (°R).
- T_{std} = Standard absolute temperature, 293° K (528° R).
- V_s = Sample volume at standard conditions (dry basis), ml.
- V_1 = Volume of flask and valve, ml.
- V_2 = Volume of absorbing solution, 25 ml.
- 2 = 50/25, the aliquot factor. (If other than a 25-ml aliquot was used for analysis, the corresponding factor must be substituted).

6.2 Sample volume, dry basis, corrected to standard conditions.

$$V_s = \frac{T_{std}}{P_{std}} (V_1 - V_2) \left[\frac{P_1}{T_1} - \frac{P_2}{T_2} \right] \\ = K_1 (V_1 - 25 \text{ ml}) \left[\frac{P_1}{T_1} - \frac{P_2}{T_2} \right] \quad \text{Equation 7-2}$$

where:

$$K_1 = 0.3558 \frac{^\circ\text{K}}{\text{mm Hg}} \text{ for metric units}$$

$$= 17.64 \frac{^\circ\text{R}}{\text{in. Hg}} \text{ for English units}$$

6.3 Total μ g NO₂ per sample.

$$m = 2 K_c A F \quad \text{Equation 7-3}$$

NOTE.—If other than a 25-ml aliquot is used for analysis, the factor 2 must be replaced by a corresponding factor.

6.4 Sample concentration, dry basis, corrected to standard conditions.

$$C = K_1 \frac{m}{V_{sc}}$$

Equation 7-4

where:

$$K_1 = 10^3 \frac{\text{mg/m}^3}{\mu\text{g/ml}} \text{ for metric units}$$

$$= 6.243 \times 10^{-3} \frac{\text{lb/scf}}{\mu\text{g/ml}} \text{ for English units}$$

7. Bibliography

1. Standard Methods of Chemical Analysis. 6th ed. New York, D. Van Nostrand Co., Inc. 1962. Vol. 1, p. 329-330.
2. Standard Method of Test for Oxides of Nitrogen in Gaseous Combustion Products (Phenoldisulfonic Acid Procedure). In: 1968 Book of ASTM Standards, Part 26. Philadelphia, Pa. 1968. ASTM Designation D-1508-60, p. 725-729.
3. Jacob, M. B. The Chemical Analysis of Air Pollutants. New York, Interscience Publishers, Inc. 1960. Vol. 10, p. 351-356.
4. Beatty, R. L., L. B. Berger, and H. H. Schrenk. Determination of Oxides of Nitrogen by the Phenoldisulfonic Acid Method. Bureau of Mines, U.S. Dept. of Interior. R. I. 3657, February 1943.
5. Hamill, H. F. and D. E. Cammann. Collaborative Study of Method for the Determination of Nitrogen Oxide Emissions from Stationary Sources (Fossil Fuel-

Fired Steam Generators). Southwest Research Institute report for Environmental Protection Agency. Research Triangle Park, N.C. October 5, 1973.

6. Hamill, H. F. and R. E. Thomas. Collaborative Study of Method for the Determination of Nitrogen Oxide Emissions from Stationary Sources (Nitric Acid Plants). Southwest Research Institute report for Environmental Protection Agency. Research Triangle Park, N.C. May 8, 1974.

METHOD 8—DETERMINATION OF SULFURIC ACID MIST AND SULFUR DIOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and Applicability

1.1 Principle. A gas sample is extracted isokinetically from the stack. The sulfuric acid mist (including sulfur trioxide) and the sulfur dioxide are separated, and both fractions are measured separately by the barium-thorin titration method.

1.2 Applicability. This method is applicable for the determination of sulfuric acid mist (including sulfur trioxide, and in the absence of other particulate matter) and sulfur dioxide emissions from stationary sources. Collaborative tests have shown that the minimum detectable limits of the method are 0.05 milligrams/cubic meter (0.08×10^{-2} pounds/cubic foot) for sulfur trioxide and 1.2 mg/m³ (0.74×10^{-2} lb/ft³) for sulfur dioxide. No upper limits have been established. Based on theoretical calculations for 200 milliliters of 3 percent hydrogen peroxide solution, the upper concentration limit for sulfur dioxide in a 1.0 m³ (35.3 ft³) gas sample is about 12,500 mg/m³ (7.7×10^{-1} lb/ft³). The upper limit can be extended by increasing the quantity of peroxide solution in the impingers.

Possible interfering agents of this method are fluorides, free ammonia, and dimethyl aniline. If any of these interfering agents are present (this can be determined by knowledge of the process), alternative methods, subject

Filterable particulate matter may be determined along with SO₂ and SO₃ subject to the approval of the Administrator) by inserting a heated glass fiber filter between the probe and isopropanol impinger (see Section 2.1 of Method 6). If this option is chosen, particulate analysis is gravimetric only; H₂SO₄ acid mist is not determined separately.

2. Apparatus

2.1 Sampling. A schematic of the sampling train used in this method is shown in Figure 8-1. It is similar to the Method 5 train except that the filter position is different and the filter holder does not have to be heated. Commercial models of this train are available. For those who desire to build their own, however, complete construction details are described in APTD-0581. Changes from the APTD-0581 document and allowable modifications to Figure 8-1 are discussed in the following subsections.

The operating and maintenance procedures for the sampling train are described in APTD-0576. Since correct usage is important in obtaining valid results, all users should read the APTD-0576 document and adopt the operating and maintenance procedures outlined in it, unless otherwise specified herein. Further details and guidelines on operation and maintenance are given in Method 5 and should be read and followed whenever they are applicable.

2.1.1 Probe Nozzle. Same as Method 5, Section 2.1.1.

2.1.2 Probe Liner. Borosilicate or quartz glass, with a heating system to prevent visible condensation during sampling. Do not use metal probe liners.

2.1.3 Pitot Tube. Same as Method 5, Section 2.1.3.

OREGON

DURKEE PLANT

PLANT REPORT # 5.1 15 SEP 1985 ENVIRONMENT CONTROL FLS-SDRS2 07.18.10 16 SEP 1985

HOUR	OA	OA	OA	OA	OA	OA	OA	NO	OA	OA	NO	OA	OA	PR	HOUR
	WHTR1	WHTR2	WHTR3	14X1	WHTR4	WHTR5	15X1	X15	1X202	1X200	1X5-2	1X2-2	1XCO2	OD	
	DEG	MPH	DEG	%	DEG	MPH	%	%	%	%	%	%	%	T/H	
7	361.	3.2	50.8	13.0			2.9	47.4	2.3	--		2.2	-0.01	60.7	7
8	363.	4.1	53.1	17.4			3.0	40.9	2.6	--		2.5	-0.01	60.9	8
9	364.	4.2	51.4	16.2			2.9	48.8	2.4	--		2.3	-0.01	60.8	9
10	361.	4.3	56.7	12.6			2.7	-0.5	2.4	--	41.0	2.3	-0.01	61.0	10
11	366.	7.4	59.0	12.5			2.5	-0.3	2.3	--	52.2	2.3	-0.02	60.4	11
12	359.	9.5	65.2	15.2			2.4	54.6	2.0	--		2.0	-0.02	60.9	12
13	361.	1.7	64.1	13.9			3.6	50.2	3.0	--		2.0	-0.02	61.0	13
14	364.	4.1	63.4	17.6			3.3	35.3	2.7	--		2.6	-0.02	60.9	14
15	366.	7.3	64.8	15.7			2.8	38.7	2.3	--		2.3	-0.01	61.2	15
16	361.	5.3	67.4	14.4			2.8	41.6	2.0	--	45.7	2.1	0.01	60.7	16
17	366.	5.7	64.0	16.4			3.0	50.2	2.3	--	54.0	2.2	-0.01	61.0	17
18	364.	4.8	63.6	13.2			2.5	52.5	2.2	--	55.5	2.2	-0.01	60.9	18
19	363.	2.1	64.2	13.7			2.7	53.0	2.2	--	57.2	2.2	-0.00	60.9	19
20	367.	6.4	57.2	16.8			3.5	45.0	2.8	--	49.2	2.7	-0.03	61.0	20
21	364.	1.2	57.1	13.3			3.0	42.2	2.3	--	45.3	2.1	-0.01	60.7	21
22	359.	1.9	55.6	13.3			3.1	49.3	2.2	--	53.6	2.2	-0.01	61.0	22
23	365.	2.9	54.7	17.7			2.1	49.3	1.7	--	54.2	1.8	-0.01	60.8	23
24	362.	2.4	52.9	15.4			3.3	41.0	2.4	--	42.7	2.4	-0.02	60.7	24
1	365.	2.8	51.6	16.9			2.7	53.6	1.9	--	57.4	1.9	0.00	60.7	1
2	364.	1.9	52.4	53.7			2.7	52.0	2.1	--	55.6	2.2	0.00	61.0	2
3	363.	3.7	50.7	12.9			3.0	46.5	2.4	--	48.0	2.3	-0.01	60.7	3
4	360.	6.5	48.5	15.9			3.7	52.5	2.5	--	54.2	2.4	-0.01	60.7	4
5	360.	1.9	46.6	13.2			3.4	45.2	2.7	--	47.5	2.6	-0.02	61.0	5
6	359.	7.0	45.0	13.0			2.7	56.4	2.0	--	58.4	2.1	-0.02	60.9	6
7	363.	3.7	46.1	25.1			3.7	44.8	2.3	--	46.3	2.1	-0.00	61.4	7
MAX	371.	14.7	70.0	61.2			4.8	73.1	3.2	--	61.8	3.0	0.16	61.5	MAX
MIN	353.	0.1	43.4	6.4			2.0	-2.7	1.5	--	34.9	1.6	-0.04	60.1	MIN
M/A	363.	4.4	56.4	16.3			3.0	42.3	2.3	--	--	2.3	-0.01	1460.	M/A


W1/ Z02 KILN OUTL
W1/ NOX KILN OUTL
W1/ Z02 EX PREHEAT
W1/ Z00 EX PREHEAT
W1/NOX-2 KILN OUTL
W1/ Z02 EX PREHEAT
W1/ZCO-2 EX PREHEAT
KILN PRODUCTION

OREGON

DURKEE PLANT

GRAPHIC LOG

LS-SDR52 13.41.50 15 SEP 1985



O R E G O N

#IRKEE PLANT

PLANT REPORT # 1.0 ON DEMAND KILN PRODUCTION REPORT FLS-SDRS2 13.43.30 15 SEP 1985

W1/ KILN FEED C3S	W1/ FEED LOSS-D-16
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HO	PR	KM	KC	BF	KF	KF	C3	KF	LT	KL	FC	CL	CL	KC	KM	
HOUR	10F1	OD	2F1	AL	-LS	MS	S	-LOI	WT	O	AO	-LS	-MS	DNTRL	2F1*	HOUR
	T/H	T/H	T/H	KC/KG			%	%	GR/L	DEG.C	%					

7	99.8	60.7	10.66	954.	--	--	--	--	1220.	223.	--	--	--			7
8	100.2	60.9	10.58	943.	110.8	0.914	2.476	60.3	1155.	216.	--	--	--			8
9	100.0	60.8	10.65	951.	--	--	--	--	1180.	229.	--	--	--			9
10	100.4	61.0	10.70	952.	--	--	--	--	1260.	240.	--	--	--			10
11	99.4	60.4	10.63	956.	--	--	--	--	1185.	237.	--	--	--			11
12	100.1	60.9	10.57	943.	--	--	--	--	1320.	224.	--	--	--			12
13	100.3	61.0	10.25	913.	--	--	--	--	1365.	229.	--	--	--			13
14	--	--	--	--	--	--	--	--	--	--	--	--	--			14
15	--	--	--	--	--	--	--	--	--	--	--	--	--			15
16	--	--	--	--	--	--	--	--	--	--	--	--	--			16
17	--	--	--	--	--	--	--	--	--	--	--	--	--			17
18	--	--	--	--	--	--	--	--	--	--	--	--	--			18
19	--	--	--	--	--	--	--	--	--	--	--	--	--			19
20	--	--	--	--	--	--	--	--	--	--	--	--	--			20
21	--	--	--	--	--	--	--	--	--	--	--	--	--			21
22	--	--	--	--	--	--	--	--	--	--	--	--	--			22
23	--	--	--	--	--	--	--	--	--	--	--	--	--			23
24	--	--	--	--	--	--	--	--	--	--	--	--	--			24
1	--	--	--	--	--	--	--	--	--	--	--	--	--			1
2	--	--	--	--	--	--	--	--	--	--	--	--	--			2
3	--	--	--	--	--	--	--	--	--	--	--	--	--			3
4	--	--	--	--	--	--	--	--	--	--	--	--	--			4
5	--	--	--	--	--	--	--	--	--	--	--	--	--			5
6	--	--	--	--	--	--	--	--	--	--	--	--	--			6
7	--	--	--	--	--	--	--	--	--	--	--	--	--	--	6.72	7

MAX	101.2	61.5	10.74	968.	110.8	0.922	2.696	61.0	34.5	1365.	257.	0.19	0.936	2.557		MAX
MIN	98.9	60.2	10.10	900.	107.0	0.953	2.410	45.8	34.3	1155.	198.	0.19	0.901	2.548		MIN
N/A	672.4	408.8	70.91	942.	110.8	0.913	2.476	60.3	0.0	1244.	226.	0.00	0.000	0.000	3601	4586

PLANT REPORT # 1.0 ON DEMAND KILN PRODUCTION REPORT FLS-SDRS2 13.44.00 15 SEP 1985

O R E G O N

DURKEE PLANT

PLANT REPORT # 3.0 ON DEMAND

K I L N / P R E H E A T E R

FLS-SDR52 13.46.20 15 SEP 1985

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ ZD2 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	W1/ ZD2 EX PREHEAT
W1/ KILN TORQUE	W1/ ZD2 EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	DA 15V1	DA 15A1	DA 15P1	DA 15X1	A5 4T1	A5 4P1	A5 3T1	A5 3P1	A5 2T1	A5 1T1	A6 1T1	A5 0T1	A5 0P1	DA 1X202	DA 1X200	DA 2V1	HOUR
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	%	RPM	
7	2.0	100.0	98	2.9	809	170	686	281	625	387	396	388	548	2.3	--	841	7
8	2.0	100.0	102	3.0	808	171	681	282	625	388	396	388	559	2.6	--	841	8
9	2.0	100.0	105	2.9	813	171	681	283	629	391	399	390	551	2.4	--	838	9
10	2.0	100.0	101	2.7	814	168	677	284	625	391	395	389	549	2.4	--	843	10
11	2.0	100.0	103	2.5	807	172	685	286	624	388	395	387	552	2.3	--	842	11
12	2.0	100.0	101	2.4	806	173	687	287	630	392	400	392	555	2.0	--	840	12
13	2.0	100.0	103	3.6	807	170	684	289	625	387	394	387	552	3.0	--	842	13
14	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	14
15	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	15
16	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	16
17	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	17
18	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	18
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
20	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	20
21	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	21
22	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	22
23	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	23
24	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	24
1	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1
2	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3
4	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4
5	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	5
6	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	6
7	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	7
MAX	2.0	100.0	113	3.9	817	182	690	300	633	393	401	392	574	3.0	--	849	MAX
MIN	2.0	100.0	93	2.0	802	159	674	274	618	384	391	384	540	1.8	--	834	MIN
M/A	2.0	100.0	103	2.9	809	171	683	286	626	387	396	388	557	2.4	--	841	M/A

PLANT REPORT # 3.0 ON DEMAND

K I L N / P R E H E A T E R

FLS-SDR52 13.46.50 15 SEP 1985

O R E G O N

PURKEE PLANT

PLANT REPORT # 2.0 ON DEMAND HILL REPORT

FLS-SDRS2 13.48.30 15 SEP 1985

CM8/ CEMENT TEMP.	CM8/ MILL SOUND
1ST COMPARTMENT	CEMENT MILL CLUTCH
CM8/ MILL FEED	M1/ COAL TO KILN
RAW MILL CLUTCH	KM5/ MILL INLET T
RM7/ MILL SOUND	KM5/ MILL OUTLET T
RM7/ MILL OUTLET T	KM5/ MILL SOUND
RM7/ MILL INLET T	COAL TO RISER PIPE
RM7/ MILL FEED	COAL TO KILN

CM8/ CEMENT TEMP.	CM8/ MILL SOUND	CEMENT MILL CLUTCH	M1/ COAL TO KILN	KM5/ MILL INLET T	KM5/ MILL OUTLET T	KM5/ MILL SOUND	COAL TO RISER PIPE	COAL TO KILN								
RM 7F1	RM 7T1	KM 7T3	RM 7X1	RM 7	CM 8F1	CM 8T1	CM 8T2	CM 8X1	CM 8	KM 2F1	KM 5T1	KM 5T2	KM 5X1	KM 13F1	KM 2F1*	HOUR
T/H	DEG. C	DEG. C	Z		T/H	DEG. C	DEG. C	Z		T/H	DEG. C	DEG. C	Z			
7	123.1	358.	72.1	44.6	--	--	--	--		10.66	298.	41.7	60.2			7
8	136.4	359.	79.9	42.1	--	--	--	--		10.58	286.	40.5	60.6			8
9	136.2	361.	72.1	41.5	--	--	--	--		10.65	287.	40.4	61.3			9
10	136.3	361.	71.7	44.1	--	--	--	--		10.70	283.	42.7	61.7			10
11	135.5	361.	71.1	44.4	--	--	--	--		10.63	294.	42.7	61.7			11
12	136.1	359.	76.8	49.5	--	--	--	--		10.57	285.	41.2	62.1			12
13	136.4	359.	75.5	49.5	--	--	--	--		10.25	278.	42.0	59.0			13
14	--	--	--	--	--	--	--	--		--	--	--	--			14
15	--	--	--	--	--	--	--	--		--	--	--	--			15
16	--	--	--	--	--	--	--	--		--	--	--	--			16
17	--	--	--	--	--	--	--	--		--	--	--	--			17
18	--	--	--	--	--	--	--	--		--	--	--	--			18
19	--	--	--	--	--	--	--	--		--	--	--	--			19
20	--	--	--	--	--	--	--	--		--	--	--	--			20
21	--	--	--	--	--	--	--	--		--	--	--	--			21
22	--	--	--	--	--	--	--	--		--	--	--	--			22
23	--	--	--	--	--	--	--	--		--	--	--	--			23
24	--	--	--	--	--	--	--	--		--	--	--	--			24
1	--	--	--	--	--	--	--	--		--	--	--	--			1
2	--	--	--	--	--	--	--	--		--	--	--	--			2
3	--	--	--	--	--	--	--	--		--	--	--	--			3
4	--	--	--	--	--	--	--	--		--	--	--	--			4
5	--	--	--	--	--	--	--	--		--	--	--	--			5
6	--	--	--	--	--	--	--	--		--	--	--	--			6
7	--	--	--	--	6.81	--	--	--		--	--	--	--	6.81	6.81	7
MAX	158.3	368.	95.5	55.6	--	--	--	--		10.74	298.	43.6	63.7			MAX
MIN	51.6	351.	67.7	29.6	--	--	--	--		10.10	277.	39.2	57.9			MIN
M/A	892.0	360.	74.4	45.7	3224	--	--	--		2616	71.78	287.	41.7	61.0	4586	M/A

PLANT REPORT # 2.0 ON DEMAND HILL REPORT

FLS-SDRS2 13.49.10 15 SEP 1985

PLANT REPORT # 4.0 ON DEMAND GAS CONDITIONING FLS-SDR52 13.49.20 15 SEP 1985

..... 2. STAGE STAT.PRES
 PREC. OASB INLET T
 W1/ OUT COOL TOWER PREC. OASB INLET T
 W1/ INL COOL TOWER HOOD TEMP
 J1/ COOLING WATER STACK OPACITY

 J1/ PRESSURE DAMP
 J1/ ID FAN SPEED

HOOR	OA 2V1	OA 2P1	OA 3F1	OA 3Y1	OA 3T3	AS 2P1	OA SAT1	OA SBT1	OA 15HT	OA 14X1	HOOR
	RPM	MMHG	L/M	DEG C	DEG.C	MMHG	DEG.C	DEG.C	DEG.C	%	
7	841	32.77	103.	373.	136.	356.	119.	130.	632	13.0	7
8	841	32.77	109.	374.	135.	356.	125.	132.	636	17.4	8
9	838	32.77	92.	373.	135.	361.	119.	128.	637	16.2	9
10	843	32.77	101.	374.	135.	358.	119.	127.	662	12.6	10
11	842	32.77	95.	373.	133.	345.	115.	129.	668	12.5	11
12	840	32.77	107.	374.	135.	360.	119.	128.	671	15.2	12
13	842	32.77	107.	374.	135.	362.	120.	126.	684	13.9	13
14	--	--	--	--	--	--	--	--	--	--	14
15	--	--	--	--	--	--	--	--	--	--	15
16	--	--	--	--	--	--	--	--	--	--	16
17	--	--	--	--	--	--	--	--	--	--	17
18	--	--	--	--	--	--	--	--	--	--	18
19	--	--	--	--	--	--	--	--	--	--	19
20	--	--	--	--	--	--	--	--	--	--	20
21	--	--	--	--	--	--	--	--	--	--	21
22	--	--	--	--	--	--	--	--	--	--	22
23	--	--	--	--	--	--	--	--	--	--	23
24	--	--	--	--	--	--	--	--	--	--	24
1	--	--	--	--	--	--	--	--	--	--	1
2	--	--	--	--	--	--	--	--	--	--	2
3	--	--	--	--	--	--	--	--	--	--	3
4	--	--	--	--	--	--	--	--	--	--	4
5	--	--	--	--	--	--	--	--	--	--	5
6	--	--	--	--	--	--	--	--	--	--	6
7	--	--	--	--	--	--	--	--	--	--	7
MAX	849	32.77	110.	377.	138.	373.	126.	135.	706	60.6	MAX
MIN	834	32.77	87.	369.	132.	339.	113.	122.	614	6.6	MIN
M/A	843	37.61	875.	373.	135.	358.	119.	127.	680	16.0	M/A

OREGON

DURKEE PLANT

PLANT REPORT # 5.0 ON DEMAND ENVIRONMENT CONTROL FLS-SDRS2 13.50.00 15 SEP 1985

																W1/ 202 KILN OUTL
																W1/ NOX KILN OUTL
																W1/ 202 EX PREHEAT
																W1/ 200 EX PREHEAT
																W1/NOX-2 KILN OUTL
																W1/ 202 EX PREHEAT
																W1/200-2 EX PREHEA
																KILN PRODUCTION
HOUR	QA WHTR1	QA WHTR2	QA WHTR3	QA 14X1	QA WHTR4	QA WHTR5	QA 15X1	NO X15	QA 1X202	QA 1X200	NO X15-2	QA 1X2-2	QA 1X002	PR OD	HOUR	
	DEG	NPH	DEG	%	DEG	NPH	%	%	%	%	%	%	%	T/H		
7	361.	3.2	50.8	13.0			2.9	47.4	2.3	--	49.1	2.2	-0.01	60.7	7	
8	363.	4.1	53.1	17.4			3.0	40.9	2.6	--	42.7	2.5	-0.01	60.9	8	
9	364.	4.2	51.4	16.2			2.9	48.8	2.4	--	51.6	2.3	-0.01	60.8	9	
10	361.	4.3	56.7	12.6			2.7	-0.5	2.4	--	41.0	2.3	-0.01	61.0	10	
11	366.	7.4	59.0	12.5			2.5	-0.3	2.3	--	52.2	2.3	-0.02	60.4	11	
12	359.	9.5	65.2	15.2			2.4	54.6	2.0	--	57.8	2.0	-0.02	60.9	12	
13	361.	1.7	64.1	13.9			3.6	50.2	3.0	--	54.3	2.8	-0.02	61.0	13	
14	--	--	--	--			--	--	--	--	--	--	--	--	14	
15	--	--	--	--			--	--	--	--	--	--	--	--	15	
16	--	--	--	--			--	--	--	--	--	--	--	--	16	
17	--	--	--	--			--	--	--	--	--	--	--	--	17	
18	--	--	--	--			--	--	--	--	--	--	--	--	18	
19	--	--	--	--			--	--	--	--	--	--	--	--	19	
20	--	--	--	--			--	--	--	--	--	--	--	--	20	
21	--	--	--	--			--	--	--	--	--	--	--	--	21	
22	--	--	--	--			--	--	--	--	--	--	--	--	22	
23	--	--	--	--			--	--	--	--	--	--	--	--	23	
24	--	--	--	--			--	--	--	--	--	--	--	--	24	
1	--	--	--	--			--	--	--	--	--	--	--	--	1	
2	--	--	--	--			--	--	--	--	--	--	--	--	2	
3	--	--	--	--			--	--	--	--	--	--	--	--	3	
4	--	--	--	--			--	--	--	--	--	--	--	--	4	
5	--	--	--	--			--	--	--	--	--	--	--	--	5	
6	--	--	--	--			--	--	--	--	--	--	--	--	6	
7	--	--	--	--			--	--	--	--	--	--	--	--	7	
MAX	370.	14.7	67.3	60.6			3.9	73.1	3.0	--	60.9	3.0	0.06	61.5	MAX	
MIN	353.	0.5	47.0	6.6			2.0	-2.7	1.8	--	37.5	1.8	-0.04	60.2	MIN	
M/A	363.	6.0	57.1	16.0			2.9	28.5	2.5	--	--	2.4	-0.01	414.9	N/A	

PLANT REPORT # 5.0 ON DEMAND ENVIRONMENT CONTROL FLS-SDRS2 13.50.30 15 SEP 1985

OREGON

DIRKEE PLANT

PLANT REPORT # 6.0 ON DEMAND KILN CONTROL

FLS-SDR52 13.50.50 15 SEP 1985

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTM FOR CONTRL	W1/ ASOT1 CHANGE
W1/ ESTIMATED LTM	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	W1/ Z02 EX PREHEAT
KILN CON. MEASUR.	W1/ Z00 EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM 2F1*	KC ONTRL	KA LARM	LT WT	ES TLTW	LT WGTSP	NO XST	NO XLT	NO XALT	AS OT1	AS OALT	OA 15X1	OA 1X202	OA 1X200	KM 2F1	OA 2V1	HOUR
				GR/L	GR/L	GR/L	%	%		DEG.C	%	%	%		T/H	RPM	
7				1220.	1320	1308	47.8	47.9	0.276	388	0.06	2.9	2.3	--	10.66	841	7
8				1155.	1270	1170	42.1	43.7	-0.154	388	-0.07	3.0	2.6	--	10.58	841	8
9				1180.	1329	1277	50.6	51.4	0.269	390	-0.06	2.9	2.4	--	10.65	838	9
10				1260.	1247	1256	42.1	43.9	-0.255	389	0.03	2.7	2.4	--	10.70	843	10
11				1185.	1325	1284	51.8	54.5	0.276	387	0.00	2.5	2.3	--	10.63	842	11
12				1320.	1345	1338	57.3	57.4	0.098	392	0.11	2.4	2.0	--	10.57	840	12
13				1365.	1304	1315	51.6	52.0	-0.656	387	0.13	3.6	3.0	--	10.25	842	13
14				--	--	--	--	--	--	--	--	--	--	--	--	--	14
15				--	--	--	--	--	--	--	--	--	--	--	--	--	15
16				--	--	--	--	--	--	--	--	--	--	--	--	--	16
17				--	--	--	--	--	--	--	--	--	--	--	--	--	17
18				--	--	--	--	--	--	--	--	--	--	--	--	--	18
19				--	--	--	--	--	--	--	--	--	--	--	--	--	19
20				--	--	--	--	--	--	--	--	--	--	--	--	--	20
21				--	--	--	--	--	--	--	--	--	--	--	--	--	21
22				--	--	--	--	--	--	--	--	--	--	--	--	--	22
23				--	--	--	--	--	--	--	--	--	--	--	--	--	23
24				--	--	--	--	--	--	--	--	--	--	--	--	--	24
1				--	--	--	--	--	--	--	--	--	--	--	--	--	1
2				--	--	--	--	--	--	--	--	--	--	--	--	--	2
3				--	--	--	--	--	--	--	--	--	--	--	--	--	3
4				--	--	--	--	--	--	--	--	--	--	--	--	--	4
5				--	--	--	--	--	--	--	--	--	--	--	--	--	5
6				--	--	--	--	--	--	--	--	--	--	--	--	--	6
7	6.84	--	6.84	--	--	--	--	--	--	--	--	--	--	--	--	--	7
MAX				1365.	1352	1342	58.0	58.2	1.000	392	0.27	3.9	3.0	--	10.74	849	MAX
MIN				1155.	1141	1154	35.5	35.0	-1.000	384	-0.26	2.0	1.8	--	10.10	834	MIN
M/A	4586	3681		1244.	--	1270	--	--	-0.001	388	0.00	2.9	2.5	--	72.12	841	M/A

PLANT REPORT # 6.0 ON DEMAND KILN CONTROL

FLS-SDR52 13.51.20 15 SEP 1985

OREGON

JURKEE PLANT

PLANT REPORT # 7.0 ON DEMAND PRODUCTION REPORT

FLS-SDR52 13.51.50 15 SEP 1985

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU' PER SH. T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO 10F1	PR OD	PR ODR	KM 2F1	KC AL	NK CAL	C- MOIST	C- ASH	C- HEAT	ST ONS	LB COAL	BTU	LT WT	KM 2F1*	HOUR
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z		T/H			GR/L		
7	99.8	60.7	1456	10.66	954.	893	--	--	9148	65.9	357	3.26	1220.		7
8	100.2	60.9	1463	10.58	943.	882	--	--	9148	66.1	353	3.23	1155.		8
9	100.0	60.8	1460	10.65	951.	890	--	--	9148	66.0	356	3.27	1180.		9
10	100.4	61.0	1465	10.70	952.	891	--	--	9148	66.2	356	3.25	1260.		10
11	99.4	60.4	1450	10.63	956.	895	--	--	9148	65.6	358	3.26	1185.		11
12	100.1	60.9	1461	10.57	943.	883	--	--	9148	66.1	353	3.23	1320.		12
13	100.3	61.0	1463	10.25	913.	854	--	--	9148	66.2	341	3.12	1365.		13
14	--	--	--	--	--	--	--	--	--	--	--	--	--		14
15	--	--	--	--	--	--	--	--	--	--	--	--	--		15
16	--	--	--	--	--	--	--	--	--	--	--	--	--		16
17	--	--	--	--	--	--	--	--	--	--	--	--	--		17
18	--	--	--	--	--	--	--	--	--	--	--	--	--		18
19	--	--	--	--	--	--	--	--	--	--	--	--	--		19
20	--	--	--	--	--	--	--	--	--	--	--	--	--		20
21	--	--	--	--	--	--	--	--	--	--	--	--	--		21
22	--	--	--	--	--	--	--	--	--	--	--	--	--		22
23	--	--	--	--	--	--	--	--	--	--	--	--	--		23
24	--	--	--	--	--	--	--	--	--	--	--	--	--		24
1	--	--	--	--	--	--	--	--	--	--	--	--	--		1
2	--	--	--	--	--	--	--	--	--	--	--	--	--		2
3	--	--	--	--	--	--	--	--	--	--	--	--	--		3
4	--	--	--	--	--	--	--	--	--	--	--	--	--		4
5	--	--	--	--	--	--	--	--	--	--	--	--	--		5
6	--	--	--	--	--	--	--	--	--	--	--	--	--		6
7	--	--	--	--	--	--	--	--	--	--	--	--	--	6.86	7
MAX	101.2	61.5	1477	10.74	968.	906	19.6	9.03	9307	66.8	362	3.31	1365.		MAX
MIN	98.9	60.2	1444	10.10	900.	838	18.0	7.64	9101	65.3	337	3.06	1155.		MIN
M/A	605.7	416.9	1461	72.29	942.	801	0.0	0.00	--	452.6	352	3.22	1244.	4586	M/A

PLANT REPORT # 7.0 ON DEMAND

PRODUCTION REPORT

FLS-SDR52 13.52.20 15 SEP 1985


OREGON

JURKEE PLANT

GRAPHIC LOG

1LS-SDRS2 13.54.10 15 SEP 1985

F.S. = 2500 PPM





OREGON

DURKEE PLANT

GRAPHIC LOG

11.5-SDR52 13.55.40 15 SEP 1985



O R E G O N

1 APR 1987

FLS-SDR52

7.34.53

DURKEE PLANT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-D-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI		KLO	CL-LS		KCONTRL	
	PROD		KCAL			KF-LS		C3S		LTWT	FCAO		CL-MS	
	T/H	T/H	T/H	KC/KG		Z	Z	GR/L	DES.C	Z	H	H		
7.25	98.6	60.0	8.93	888	112.8	0.920	2.700	57.3	34.7	1420	222	0.24	0.930	2.890
8.25	99.3	60.3	8.70	783	109.9	0.880	2.800	46.5	34.7	1450	202	0.24	0.930	2.890
9.25	99.1	60.3	8.34	751	109.9	0.880	2.800	46.5	34.7	1445	239	0.24	0.930	2.890
10.25	100.2	60.9	8.38	747	109.9	0.880	2.800	46.5	34.7	1320	252	0.24	0.930	2.890
11.25	99.5	60.5	8.46	758	109.9	0.880	2.800	46.5	34.7	1170	226	0.24	0.930	2.890
12.25	98.7	60.0	8.58	776	109.9	0.880	2.800	46.5	34.7	1175	209	0.24	0.930	2.890
13.25	99.9	60.7	8.80	786	109.9	0.880	2.800	46.5	34.7	1315	206	0.24	0.930	2.890
14.25	100.1	60.8	8.68	775	111.6	0.890	2.830	50.6	34.6	1335	191	0.12	0.910	2.910
15.25	99.8	60.7	8.44	755	111.6	0.890	2.830	50.6	34.6	1380	196	0.12	0.910	2.910
16.25	98.8	60.0	8.20	741	109.0	0.850	2.980	39.4	34.6	1320	206	0.12	0.910	2.910
17.25	100.6	61.2	8.48	752	109.0	0.850	2.980	39.4	34.6	1270	227	0.12	0.910	2.910
18.25	100.3	61.0	8.66	770	109.0	0.850	2.980	39.4	34.6	1130	211	0.12	0.910	2.910
19.25	99.3	60.4	8.90	799	109.0	0.850	2.980	39.4	34.6	1185	189	0.12	0.910	2.910
20.25	99.3	60.3	8.95	805	109.0	0.850	2.980	39.4	34.6	1190	166	0.12	0.910	2.910
21.25	99.6	60.5	8.66	776	109.0	0.850	2.980	39.4	34.6	1260	202	0.12	0.910	2.910
22.25	98.9	60.1	9.01	813	109.0	0.850	2.980	39.4	34.6	1240	258	0.12	0.910	2.910
23.25	99.6	60.6	9.35	838	109.0	0.850	2.980	39.4	34.6	1135	213	0.12	0.910	2.910
0.25	99.6	60.5	8.95	802	109.0	0.850	2.980	39.4	34.6	1250	219	0.12	0.910	2.910
1.25	99.9	60.7	8.67	775	109.0	0.850	2.980	39.4	34.6	1330	224	0.12	0.910	2.910
2.25	99.2	60.3	8.77	790	109.0	0.850	2.980	39.4	34.6	1285	229	0.12	0.910	2.910
3.25	99.5	60.4	8.91	800	109.0	0.850	2.980	39.4	34.6	1225	226	0.12	0.910	2.910
4.25	99.8	60.7	9.06	811	121.8	0.990	2.780	74.7	34.6	1230	254	0.12	0.910	2.910
5.25	99.7	60.6	9.28	831	121.8	0.990	2.780	74.7	34.6	1230	251	0.12	0.910	2.910
6.25	100.2	60.9	9.37	835	121.8	0.990	2.780	74.7	34.6	1270	256	0.12	0.910	2.910
7.25	99.7	60.6	9.16	820	121.8	0.990	2.780	74.7	34.6	1370	243	0.12	0.910	2.910

0.00 - 7.35	
MAX	101.1 61.5 9.50 858. 121.8 0.990 2.980 74.8 34.7 1370. 267. 0.12 0.910 2.910
MIN	97.8 59.5 8.52 762. 109.0 0.850 2.780 39.4 34.7 1135. 196. 0.12 0.910 2.910
MEAN	99.7 60.6 9.00 807. 114.4 0.989 2.895 54.4 34.7 1262. 237. 0.12 0.910 2.910 7.59 7.59
ACCM	756.4 459.9 68.34 807. 114.5 0.910 2.894 54.6 34.7 1260. 237. 0.12 0.910 2.910 93.04 114.5
0.00 - 0.00	
MAX	101.4 61.6 9.41 849. 112.8 0.920 2.980 46250. 34.8 1450. 308. 0.24 0.930 2.910
MIN	93.4 56.8 6.29 562. 109.0 0.850 2.780 39.4 34.7 1130. 137. 0.12 0.910 2.890
MEAN	99.8 60.7 8.70 778. 110.6 0.883 2.831 55.9 34.7 1278. 221. 0.19 0.921 2.897 22.46 24.02
ACCM	2395.5 1456.4 208.70 778. 110.5 0.881 2.841 47.4 34.7 1285. 221. 0.19 0.921 2.899 85.54 107.0

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

O R E G O N

1 APR 1987

FLS-SDR52

7.35.28

DURKEE PLANT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
W1/ GAS TEMP A53
W1/ PRESSURE A54
W1/ TEMP CYCL A54
W1/ ZO2 KILN OUTL
W1/ PRES EXIT KILN
W1/ KILN TORQUE
W1/ KILN ROT SPEED

W1/ GAS TEMP A52
W1/ GAS TEMP A51
W1/ GAS TEMP A61
W1/ T EXIT PREHEAT
W1/ PRESS EX PREH
W1/ ZO EX PREHEAT
J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.8	22.3	102	2.54	802	164	767	284	610	376	372	383	541	-0.01	817	
8.25	1.8	26.0	107	3.64	802	184	773	295	610	379	372	384	551	0.00	835	
9.25	1.8	25.2	124	5.28	799	205	776	319	618	389	383	394	607	0.00	847	
10.25	1.8	18.7	116	4.84	799	209	775	322	618	382	375	388	596	0.00	843	
11.25	1.8	23.4	112	4.43	799	203	768	317	614	379	372	385	577	0.00	854	
12.25	1.8	24.7	108	4.04	797	195	777	308	613	379	370	385	572	0.01	849	
13.25	1.8	24.8	109	4.02	799	209	780	310	614	386	376	391	587	0.00	842	
14.25	1.8	25.2	109	3.97	801	194	777	312	616	385	376	389	581	0.02	838	
15.25	1.8	23.7	106	4.48	798	195	776	314	614	386	377	389	584	0.00	839	
16.25	1.8	21.4	114	4.37	799	198	773	317	610	376	371	385	579	0.01	841	
17.25	1.8	20.7	116	4.74	797	206	772	321	617	384	375	389	589	0.00	841	
18.25	1.8	24.0	124	3.79	798	199	776	328	624	384	374	389	598	0.00	842	
19.25	1.8	27.6	122	3.31	801	204	778	319	623	387	377	392	588	0.00	838	
20.25	1.8	33.4	119	2.70	804	200	780	312	625	388	378	392	581	0.00	827	
21.25	1.8	36.1	124	3.54	801	218	779	314	620	385	375	391	585	0.02	832	
22.25	1.8	33.9	120	2.95	803	194	784	322	627	392	383	395	588	0.00	834	
23.25	1.8	34.9	114	2.11	805	204	787	309	621	382	377	391	563	0.00	834	
0.25	1.8	35.9	123	2.90	802	203	784	317	623	390	381	398	590	0.00	853	
1.25	1.8	35.8	128	3.86	802	199	781	340	626	393	387	398	616	0.00	863	
2.25	1.8	34.8	129	3.21	802	208	784	322	629	390	385	399	599	-0.01	847	
3.25	1.8	35.6	130	3.37	804	206	782	335	625	392	384	397	615	-0.03	847	
4.25	1.8	36.1	130	2.93	803	221	779	334	627	394	383	398	613	0.00	846	
5.25	1.8	38.1	130	2.80	805	212	783	329	624	392	384	398	603	-0.01	843	
6.25	1.8	38.9	130	2.39	806	213	784	336	630	393	387	398	602	-0.01	842	
7.25	1.8	38.8	144	3.59	805	230	783	352	622	394	385	398	638	-0.01	865	

0.00 - 7.36

MAX	1.9	41.0	152.	4.57	810.	246.	794.	364.	640.	401.	393.	405.	649.	0.02	871.
MIN	1.9	34.4	116.	1.96	800.	173.	774.	311.	617.	384.	379.	398.	581.	-0.04	833.
MEAN	1.9	36.9	131.	3.24	805.	212.	784.	332.	628.	393.	385.	398.	606.	-0.01	850.
ACCM	1.9	36.9	131.		805.	212.	784.	332.	628.	393.	385.	398.	606.	-0.01	850.

0.00 - 0.00

MAX	1.9	37.7	154.	5.78	809.	251.	791.	345.	635.	397.	392.	400.	617.	0.04	859.
MIN	1.9	18.6	85.	1.20	793.	120.	756.	264.	597.	372.	364.	379.	517.	-0.04	804.
MEAN	1.9	26.1	113.	3.68	801.	195.	775.	309.	616.	384.	377.	390.	577.	0.00	833.
ACCM	1.9	26.1	113.		801.	195.	775.	309.	616.	384.	377.	390.	577.	0.00	833.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTROL		LTWT		LTWGTSP		NOXLT		A50T1		OA15X1		OA1X2CO OA2V1		
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	T/H	RPM	
7.25				1420	1359	1291	48.2	46.6	0.376	383	-0.36	2.54	-0.01	8.93	817
8.25				1450	1383	1407	47.1	46.8	-0.075	384	-0.76	3.64	0.00	8.70	835
9.25				1445	1234	1340	30.0	30.4	-0.588	394	0.21	5.28	0.00	8.34	847
10.25				1320	1156	1253	19.6	18.4	-0.385	388	-0.35	4.84	0.00	8.38	843
11.25				1170	1176	1175	19.4	19.6	-0.116	385	0.13	4.43	0.00	8.46	854
12.25				1175	1261	1253	29.0	28.9	0.524	385	-0.10	4.84	0.01	8.58	849
13.25				1315	1264	1268	27.2	26.8	-0.071	391	0.02	4.02	0.00	8.80	842
14.25				1335	1388	1347	39.6	40.3	0.527	389	-0.06	3.97	0.02	8.68	838
15.25				1390	1367	1367	37.3	37.1	0.030	389	-0.12	4.48	0.00	8.44	839
16.25				1320	1316	1316	32.6	31.3	-0.153	385	-0.61	4.37	0.01	8.20	841
17.25				1270	1175	1181	17.3	16.8	-0.575	389	0.63	4.74	0.00	8.48	841
18.25				1130	1206	1198	21.6	21.7	0.135	389	-0.13	3.79	0.00	8.66	842
19.25				1185	1241	1237	25.4	25.1	0.148	392	-0.05	3.31	0.00	8.90	838
20.25				1190	1261	1302	26.4	27.0	0.012	392	-0.12	2.70	0.00	8.95	827
21.25				1260	1288	1286	29.8	29.7	0.001	391	-0.14	3.54	0.02	8.66	832
22.25				1240	1226	1227	24.1	24.2	0.059	395	0.52	2.95	0.00	9.01	834
23.25				1135	1314	1297	31.4	32.5	0.293	391	-0.29	2.11	0.00	9.35	834
0.25				1250	1454	1359	45.3	45.6	0.413	398	0.11	2.90	0.00	8.95	853
1.25				1330	1357	1314	40.3	41.4	-0.109	398	0.14	3.86	0.00	8.67	863
2.25				1285	1289	1289	36.6	35.6	-0.130	399	-0.24	3.21	-0.01	8.77	847
3.25				1225	1263	1239	34.1	34.2	-0.065	397	-0.08	3.37	-0.03	8.91	947
4.25				1230	1268	1272	34.5	34.9	0.001	398	0.02	2.93	0.00	9.06	846
5.25				1230	1259	1255	34.5	34.9	0.076	398	-0.06	2.80	-0.01	9.20	843
6.25				1270	1306	1289	43.2	43.2	0.451	398	0.03	2.39	-0.01	9.37	842
7.25				1370	1316	1323	44.4	44.9	-0.329	398	0.31	3.59	-0.01	9.16	865

0.00 - 7.37

MAX				1370.	1462.	1442.	51.3	51.6	0.600	405.	0.55	4.57	0.02	9.50	871.
MIN				1135.	1255.	1237.	32.7	33.1	-0.596	390.	-0.70	1.96	-0.04	8.52	833.
MEAN	7.64	7.64		1263.	1315.	1297.	38.8	39.0	0.037	398.	0.00	3.24	-0.01	9.01	850.
ACCM	114.6	93.09		1260.		1297.			0.037	398.	0.00		-0.01	68.73	850.

0.00 - 8.00

MAX				1450.	1523.	1468.	55.9	56.5	1.014	400.	1.03	5.78	0.04	9.41	859.
MIN				1130.	1141.	1164.	17.2	16.2	-0.754	379.	-1.02	1.20	-0.04	6.29	804.
MEAN	24.02	22.46		1278.	1283.	1281.	31.8	31.8	0.001	390.	0.00	3.68	0.00	8.70	833.
ACCM	107.0	85.54		1285.		1281.			0.001	390.	0.00		0.00	208.70	833.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		BTU		LTWT	
	PROD		KM2F1		NKCAL		C-ASH				LB. COAL		KM2F1*			
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%	T	T	T/H		GR/L	H		
7.25	98.6	60.0	1440	8.93	898	849	21.8	3.41	9302	65.1	0	28.24	1420			
8.25	99.3	60.3	1449	8.70	783	822	21.8	3.41	9302	65.5	0	27.25	1450			
9.25	99.1	60.3	1447	8.34	751	789	21.8	3.41	9302	65.4	0	26.24	1445			
10.25	100.2	60.9	1452	8.38	747	785	21.8	3.41	9302	66.1	0	25.92	1320			
11.25	99.5	60.5	1453	8.46	758	797	21.8	3.41	9302	65.7	0	26.38	1170			
12.25	98.7	60.0	1441	8.58	776	815	21.8	3.41	9302	65.2	0	26.92	1175			
13.25	99.9	60.7	1459	8.80	786	826	21.8	3.41	9302	65.9	0	27.28	1315			
14.25	100.1	60.8	1460	8.68	775	806	21.5	2.94	9395	66.0	0	27.22	1335			
15.25	99.8	60.7	1457	8.44	755	785	21.5	2.94	9395	65.9	0	26.62	1380			
16.25	98.8	60.0	1441	8.20	741	771	21.5	2.94	9395	65.2	0	25.93	1320			
17.25	100.6	61.2	1469	8.48	752	783	21.5	2.94	9395	66.4	0	26.44	1270			
18.25	100.3	61.0	1464	8.66	770	802	21.5	2.94	9395	66.2	0	26.97	1130			
19.25	99.3	60.4	1450	8.98	799	832	21.5	2.94	9395	65.6	0	28.30	1185			
20.25	99.3	60.3	1449	8.95	805	838	21.5	2.94	9395	65.5	0	28.39	1190			
21.25	99.6	60.5	1454	8.66	776	807	21.5	2.94	9395	65.7	0	27.29	1260			
22.25	98.9	60.1	1444	9.01	813	846	21.5	2.94	9395	65.3	0	28.50	1240			
23.25	99.6	60.6	1454	9.35	838	871	21.5	2.94	9395	65.7	0	29.36	1135			
0.25	99.6	60.5	1453	8.95	802	834	21.5	2.94	9395	65.7	0	28.04	1250			
1.25	99.9	60.7	1458	8.67	775	806	21.5	2.94	9395	65.9	0	27.17	1330			
2.25	99.2	60.3	1447	8.77	790	821	21.5	2.94	9395	65.4	0	27.77	1285			
3.25	99.5	60.4	1451	8.91	800	832	21.5	2.94	9395	65.6	0	28.05	1225			
4.25	99.8	60.7	1457	9.06	811	843	21.5	2.94	9395	65.9	0	28.41	1230			
5.25	99.7	60.6	1455	9.28	831	864	21.5	2.94	9395	65.8	0	29.29	1230			
6.25	100.2	60.9	1462	9.37	835	869	21.5	2.94	9395	66.1	0	29.41	1270			
7.25	99.7	60.6	1455	9.16	820	853	21.5	2.94	9395	65.8	0	28.90	1370			

0.00 - 7.38

MAX	101.1	61.5	1475.	9.50	858.	893.	21.5	2.94	9395.	66.7	0.	30.15	1370.
MIN	97.8	59.5	1429.	8.52	762.	792.	21.5	2.94	9392.	64.6	0.	26.76	1135.
MEAN	99.7	60.6	1454.	9.01	807.	840.	21.5	2.94	9394.	65.8	0.	28.36	1263. 7.65
ACCM	761.8	463.2		68.84	807.	840.	21.5	2.94			0.	28.36	1260. 114.6

0.00 - 0.00

MAX	101.4	61.6	1479.	9.41	849.	887.	21.8	3.41	9395.	66.9	0.	29.85	1450.
MIN	93.4	56.8	1362.	6.29	562.	590.	21.5	2.94	9380.	61.6	0.	19.55	1130.
MEAN	99.8	60.7	1456.	8.70	778.	814.	21.7	3.21	9342.	65.9	0.	27.19	1278. 24.02
ACCM	2395.5	1456.4		208.70	778.	814.	21.7	3.21			0.	27.19	1285. 107.0

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-O-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO1OF1	KM2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL										
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KM2F1*										
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H							
7.25	99.8	60.7	9.19	822	121.8	0.990	2.780	74.7	34.6	1270	252	0.12	0.910	2.910				
8.25	99.9	60.7	9.38	838	121.8	0.990	2.780	74.7	34.6	1350	252	0.12	0.910	2.910				
9.25	100.0	60.8	9.42	841	118.5	0.950	2.890	66.1	34.6	1290	264	0.12	0.910	2.910				
10.25	99.5	60.5	9.54	855	118.5	0.950	2.890	66.1	34.6	1250	258	0.12	0.910	2.910				
11.25	99.7	60.6	9.28	831	118.5	0.950	2.890	66.1	34.6	1250	286	0.12	0.910	2.910				
12.25	99.8	60.7	9.40	841	118.5	0.950	2.890	66.1	34.6	1320	278	0.12	0.910	2.910				
13.25	99.8	60.1	9.30	839	109.5	0.860	2.900	43.2	34.5	1350	295	0.24	0.890	3.060				
14.25	99.8	60.7	9.32	834	109.5	0.860	2.900	43.2	34.5	1350	277	0.24	0.890	3.060				
15.25	100.0	60.8	9.12	814	109.5	0.860	2.900	43.2	34.5	1330	218	0.24	0.890	3.060				
16.25	99.1	60.2	8.89	801	120.7	0.970	2.860	71.5	34.5	1390	217	0.24	0.890	3.060				
17.25	99.3	60.4	9.03	812	120.7	0.970	2.860	71.5	34.5	1330	279	0.24	0.890	3.060				
18.25	99.9	60.7	9.25	826	120.7	0.970	2.860	71.5	34.5	1190	228	0.24	0.890	3.060				
19.25	99.7	60.6	9.64	863	120.7	0.970	2.860	71.5	34.5	1210	254	0.24	0.890	3.060				
20.25	99.8	60.6	9.31	833	120.7	0.970	2.860	71.5	34.5	1270	257	0.24	0.890	3.060				
21.25	99.7	60.6	8.96	803	120.7	0.970	2.860	71.5	34.5	1280	261	0.24	0.890	3.060				
22.25	98.8	60.1	9.11	823	120.7	0.970	2.860	71.5	34.5	1270	262	0.24	0.890	3.060				
23.25	99.8	60.6	9.33	835	120.7	0.970	2.860	71.5	34.5	1145	234	0.24	0.890	3.060				
0.25	99.4	60.4	9.62	864	121.2	0.980	2.850	73.2	34.5	1175	224	0.24	0.890	3.060				
1.25	99.5	60.4	9.70	871	121.2	0.980	2.850	73.2	34.5	1175	226	0.24	0.890	3.060				
2.25	99.9	60.7	9.93	888	121.2	0.980	2.850	73.2	34.5	1275	235	0.24	0.890	3.060				
3.25	100.2	60.9	9.50	846	121.2	0.980	2.850	73.2	34.5	1320	255	0.24	0.890	3.060				
4.25	99.2	60.3	9.54	858	121.2	0.980	2.850	73.2	34.5	1405	236	0.24	0.890	3.060				
5.25	100.1	60.9	9.29	828	121.2	0.980	2.850	73.2	34.5	1420	235	0.24	0.890	3.060				
6.25	99.6	60.6	9.13	818	121.2	0.980	2.850	73.2	34.5	1405	198	0.24	0.890	3.060				
7.25	100.0	60.8	8.82	788	121.2	0.980	2.850	73.2	34.5	1405	224	0.24	0.890	3.060				

0.00 - 7.27																
MAX	101.1	61.4	10.05	900.	121.2	0.980	2.850	73.2	34.5	1420.	264.	0.24	0.890	3.060		
MIN	98.0	59.6	8.83	788.	121.2	0.980	2.850	73.2	34.5	1175.	194.	0.24	0.890	3.060		
MEAN	99.8	60.7	9.46	847.	121.2	0.980	2.850	73.2	34.5	1321.	232.	0.24	0.890	3.060	7.18	7.46
ACCM	743.9	452.3	70.55	847.	121.2	0.980	2.850	73.2	34.5	1344.	232.	0.24	0.890	3.060	116.4	138.1
0.00 - 0.00																
MAX	101.6	61.8	9.70	872.	121.8	0.990	2.980	74.8	34.7	1390.	325.	0.24	0.910	3.060		
MIN	97.8	59.5	8.52	762.	109.0	0.850	2.780	39.4	34.5	1135.	185.	0.12	0.890	2.910		
MEAN	99.7	60.6	9.19	823.	117.2	0.937	2.877	62.4	34.6	1280.	251.	0.17	0.901	2.979	24.02	24.02
ACCM	2393.7	1455.4	220.47	823.	117.6	0.940	2.876	63.3	34.6	1280.	251.	0.18	0.901	2.979	109.3	130.8

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ ZD2 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCO EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO		0A2V1	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM			
7.25	1.8	40.9	140	3.53	804	223	782	350	622	388	380	393	623	-0.02	854			
8.25	1.8	38.5	147	3.65	804	230	787	359	631	395	388	400	639	-0.01	865			
9.25	1.8	38.6	149	3.26	805	236	785	361	626	395	389	400	637	0.00	867			
10.25	1.8	39.7	148	2.58	807	229	788	348	631	395	388	402	614	0.00	856			
11.25	1.8	37.4	146	3.04	804	221	781	353	631	394	383	399	621	0.02	863			
12.25	1.8	35.9	145	2.95	806	236	785	353	626	395	385	400	625	0.02	860			
13.25	1.8	36.6	135	1.85	805	229	789	352	633	399	388	404	622	0.02	867			
14.25	1.8	33.5	133	2.42	896	208	785	344	629	394	385	400	601	0.01	854			
15.25	1.8	34.4	125	3.57	805	211	786	342	627	392	384	400	613	0.03	857			
16.25	1.8	35.5	131	3.84	804	218	784	346	628	390	384	398	620	0.00	858			
17.25	1.8	31.6	139	3.90	801	237	786	352	624	394	384	398	621	0.01	857			
18.25	1.8	32.9	136	3.90	802	214	788	344	628	392	384	398	618	0.01	856			
19.25	1.8	33.8	137	2.36	806	233	789	353	625	395	384	400	618	0.03	859			
20.25	1.8	36.3	115	3.22	804	205	785	330	629	398	388	402	614	0.01	858			
21.25	1.8	34.0	117	3.62	802	199	782	335	623	387	382	395	606	0.00	877			
22.25	1.8	29.9	133	3.43	800	213	785	338	619	391	382	397	612	0.01	849			
23.25	1.8	30.6	127	3.00	803	206	781	333	630	392	383	398	609	0.00	849			
0.25	1.8	30.8	119	3.35	805	209	785	329	631	393	385	400	613	0.00	849			
1.25	1.8	33.9	121	2.63	807	202	787	323	629	394	387	402	614	0.00	846			
2.25	1.8	33.9	113	2.48	808	213	790	324	631	394	388	402	610	0.00	841			
3.25	1.8	33.1	114	3.49	806	191	788	324	633	394	384	399	608	0.00	838			
4.25	1.8	30.6	101	4.19	806	178	787	314	630	394	388	401	599	0.00	839			
5.25	1.8	33.3	107	4.12	804	205	778	315	628	391	384	398	594	0.00	839			
6.25	1.8	27.3	101	4.36	805	203	782	315	625	393	385	398	598	-0.01	837			
7.25	1.8	27.1	105	5.38	801	192	777	326	620	394	386	400	618	-0.01	852			

0.00 - 7.28															
MAX	1.9	35.3	137.	10.50	812.	233.	797.	344.	639.	402.	394.	405.	631.	0.04	861.
MIN	1.9	27.0	86.	2.89	800.	168.	770.	301.	613.	387.	379.	391.	574.	-0.04	824.
MEAN	1.9	31.6	110.	3.88	806.	196.	784.	320.	628.	395.	387.	400.	606.	-0.00	843.
ACCM	1.9	31.6	110.		806.	196.	784.	320.	628.	395.	387.	400.	606.	-0.00	843.
0.00 - 0.00															
MAX	1.9	42.7	161.	8.00	810.	252.	795.	370.	641.	404.	394.	406.	653.	0.06	886.
MIN	1.9	29.0	108.	0.48	797.	126.	772.	309.	616.	384.	376.	390.	574.	-0.04	833.
MEAN	1.9	35.5	134.	3.24	804.	217.	785.	342.	629.	394.	385.	399.	615.	0.00	857.
ACCM	1.9	35.5	134.		804.	217.	785.	342.	629.	394.	385.	399.	615.	0.00	857.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ AS0T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ ZCO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		AS0ALT		KM2F1		
	KCONTRL		LTWT		LTWGTSP		NOXL		AS0T1		OA15X1		OA1X2CO	OA2V1	
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM	
7.25				1270	1354	1324	51.1	51.6	0.445	393	-0.24	3.53	-0.02	9.19	854
8.25				1350	1266	1286	34.0	34.2	-0.104	400	-0.06	3.65	-0.01	9.38	865
9.25				1290	1265	1271	32.0	32.8	0.029	400	-0.07	3.26	0.00	9.42	867
10.25				1250	1279	1292	36.0	35.7	0.172	402	0.04	2.50	0.00	9.54	856
11.25				1250	1312	1306	41.6	42.7	-0.010	399	0.01	3.04	0.02	9.28	863
12.25				1320	1312	1299	41.4	42.6	0.027	400	0.11	2.95	0.02	9.40	860
13.25				1350	1296	1302	30.8	38.3	-0.495	404	0.55	1.85	0.02	9.30	867
14.25				1350	1331	1298	43.5	44.0	0.341	400	-0.09	2.42	0.01	9.32	854
15.25				1330	1327	1328	43.5	43.3	-0.156	400	0.10	3.57	0.03	9.12	857
16.25				1390	1323	1354	40.9	40.7	-0.199	398	0.07	3.84	0.00	8.89	858
17.25				1330	1192	1220	30.1	29.8	-0.212	398	0.03	3.90	0.01	9.03	857
18.25				1180	1185	1184	29.7	29.4	-0.034	398	0.09	3.90	0.01	9.25	856
19.25				1210	1249	1245	34.5	33.4	0.047	400	0.05	2.36	0.03	9.64	859
20.25				1270	1350	1320	41.8	40.9	0.178	402	0.33	3.22	0.01	9.31	858
21.25				1280	1366	1330	42.4	43.6	0.208	395	-0.47	3.62	0.00	8.96	877
22.25				1270	1210	1229	31.0	31.1	0.039	397	-0.31	3.43	0.01	9.11	849
23.25				1145	1227	1193	33.9	33.6	0.082	398	0.01	3.00	0.00	9.33	849
0.25				1175	1248	1240	36.3	36.1	0.192	400	-0.15	3.35	0.00	9.62	849
1.25				1175	1391	1368	47.3	48.3	0.468	402	0.16	2.63	0.00	9.70	846
2.25				1275	1403	1389	50.9	49.3	0.461	402	0.05	2.48	0.00	9.93	841
3.25				1320	1503	1483	58.1	57.9	0.080	399	0.04	3.49	0.00	9.50	838
4.25				1405	1343	1288	51.4	49.2	-0.342	401	-0.07	4.19	0.00	9.54	839
5.25				1420	1449	1372	55.6	58.3	0.145	398	-0.28	4.12	0.00	9.29	839
6.25				1405	1400	1400	53.7	54.2	0.093	398	-0.09	4.36	-0.01	9.13	837
7.25				1405	1274	1285	42.4	40.5	-0.747	400	0.15	5.38	-0.01	8.82	852

0.00 - 7.30

MAX				1420.	1515.	1494.	59.3	60.1	0.584	405.	0.35	10.50	0.04	10.05	861.
MIN				1175.	1224.	1219.	34.5	34.8	-0.001	391.	-0.36	2.09	-0.04	8.83	824.
MEAN	7.50	7.23		1322.	1384.	1337.	50.0	50.1	0.058	400.	-0.00	3.89	-0.00	9.46	843.
ACCM	138.2	116.4		1344.		1337.			0.058	400.	-0.00		-0.00	70.94	843.

0.00 - 8.00

MAX				1390.	1462.	1442.	51.3	51.6	0.600	406.	0.01	8.00	0.06	9.70	886.
MIN				1135.	1178.	1174.	27.6	27.9	-0.987	390.	-0.98	0.48	-0.04	8.52	833.
MEAN	24.02	24.02		1280.	1289.	1283.	37.6	37.6	-0.006	399.	0.00	3.24	0.00	9.19	857.
ACCM	130.8	109.3		1280.		1283.			-0.006	399.	0.00		0.00	220.47	857.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU		LTWT	
	PROD		T	KCAL		C-ASH				T/H	LB.COAL		GR/L	H
	T/H	T/H		T/H	KC/KG	KC/KG	%	%						
7.25	99.8	60.7	1457	9.19	822	855	21.5	2.94	9395	65.9	0	28.97	1270	
8.25	99.9	60.7	1458	9.38	838	872	21.5	2.94	9395	66.1	0	29.55	1350	
9.25	100.0	60.8	1459	9.42	841	875	21.5	2.94	9395	66.0	0	29.54	1290	
10.25	99.5	60.5	1453	9.54	855	890	21.5	2.94	9392	65.7	0	30.22	1250	
11.25	99.7	60.6	1455	9.28	831	864	21.5	2.94	9395	65.8	0	29.19	1250	
12.25	99.8	60.7	1456	9.40	841	876	21.5	2.94	9392	65.8	0	29.60	1320	
13.25	99.0	60.1	1444	9.30	839	862	20.0	3.51	9522	65.3	0	29.91	1350	
14.25	99.8	60.7	1456	9.32	834	856	20.0	3.51	9519	65.8	0	29.92	1350	
15.25	100.0	60.8	1459	9.12	814	836	20.0	3.51	9522	66.0	0	28.94	1330	
16.25	99.1	60.2	1446	8.89	801	822	20.0	3.51	9522	65.4	0	28.54	1390	
17.25	99.3	60.4	1449	9.03	812	833	20.0	3.51	9522	65.5	0	28.82	1330	
18.25	99.9	60.7	1459	9.25	826	848	20.0	3.51	9519	65.9	0	29.45	1180	
19.25	99.7	60.6	1455	9.64	863	886	20.0	3.51	9519	65.8	0	30.61	1210	
20.25	99.8	60.6	1456	9.31	833	855	20.0	3.51	9519	65.8	0	29.64	1270	
21.25	99.7	60.6	1455	8.96	803	824	20.0	3.51	9519	65.8	0	28.67	1280	
22.25	98.8	60.1	1443	9.11	823	845	20.0	3.51	9522	65.2	0	29.32	1270	
23.25	99.8	60.6	1456	9.33	835	857	20.0	3.51	9522	65.8	0	29.87	1145	
0.25	99.4	60.4	1451	9.62	864	887	20.0	3.51	9522	65.6	0	30.78	1175	
1.25	99.5	60.4	1451	9.70	871	894	20.0	3.51	9522	65.6	0	31.01	1175	
2.25	99.9	60.7	1458	9.93	888	911	20.0	3.51	9522	65.9	0	31.63	1275	
3.25	100.2	60.9	1463	9.50	846	868	20.0	3.51	9522	66.1	0	30.28	1320	
4.25	99.2	60.3	1448	9.54	858	881	20.0	3.51	9522	65.5	0	30.53	1405	
5.25	100.1	60.9	1461	9.29	828	850	20.0	3.51	9522	66.1	0	29.50	1420	
6.25	99.6	60.6	1454	9.13	818	840	20.0	3.51	9522	65.7	0	29.22	1405	
7.25	100.0	60.8	1459	8.82	788	809	20.0	3.51	9519	66.0	0	28.17	1405	

0.00 - 7.30													
MAX	101.1	61.4	1475.	10.05	900.	924.	20.0	3.51	9522.	66.7	0.	32.07	1420.
MIN	98.0	59.6	1431.	8.83	788.	809.	20.0	3.51	9519.	64.7	0.	28.86	1175.
MEAN	99.8	60.7	1456.	9.46	847.	869.	20.0	3.51	9522.	65.8	0.	30.16	1322. 7.51
ACCM	749.3	455.6		71.04	847.	869.	20.0	3.51			0.	30.16	1344. 138.2
0.00 - 0.00													
MAX	101.6	61.8	1483.	9.70	872.	902.	21.5	3.51	9522.	67.1	0.	31.06	1390.
MIN	97.8	59.5	1429.	8.52	762.	792.	20.0	2.94	9330.	64.6	0.	26.76	1135.
MEAN	99.7	60.6	1455.	9.19	823.	851.	20.8	3.20	9451.	65.8	0.	29.09	1280. 24.02
ACCM	2393.7	1455.4		220.47	823.	851.	20.8	3.20			0.	29.08	1280. 130.8

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-D-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI	KLO	CL-LS		KCONTRL		
	PROD			KCAL		KF-LS	C3S			LTWT	FCAO	CL-MS	KN2F1*	
	T/H	T/H	T/H	KC/KG		%	%	GR/L	DEG.C	%	H	H		
7.25	100.0	60.8	9.00	803	121.2	0.980	2.850	73.2	34.5	1405	224	0.24	0.890	3.060
8.25	99.3	60.4	9.02	811	117.1	0.940	2.850	63.3	34.5	1340	212	0.24	0.890	3.060
9.25	99.1	60.2	9.25	834	117.1	0.940	2.850	63.3	34.5	1290	222	0.24	0.890	3.060
10.25	99.6	60.5	9.45	847	117.1	0.940	2.850	63.3	34.5	1160	219	0.24	0.890	3.060
11.25	99.0	60.1	9.38	847	117.1	0.940	2.850	63.3	34.5	1275	233	0.24	0.890	3.060
12.25	100.3	60.9	9.19	819	117.1	0.940	2.850	63.3	34.5	1325	234	0.24	0.890	3.060
13.25	100.8	61.2	9.22	817	118.0	0.940	2.890	63.6	35.2	1360	254	0.18	0.960	2.990
14.25	99.4	60.4	10.05	982	118.0	0.940	2.890	63.6	35.2	1250	241	0.18	0.960	2.990
15.25	100.1	60.8	9.46	844	118.0	0.940	2.890	63.6	35.2	1220	238	0.18	0.960	2.990
16.25	100.3	61.0	9.31	829	118.0	0.940	2.890	63.6	35.2	1280	255	0.18	0.960	2.990
17.25	100.2	60.9	9.05	806	115.9	0.920	2.920	58.8	35.2	1365	246	0.18	0.960	2.990
18.25	100.0	60.8	9.13	815	115.9	0.920	2.920	58.8	35.2	1460	232	0.18	0.960	2.990
19.25	99.4	60.4	9.12	819	115.9	0.920	2.920	58.8	35.2	1470	214	0.18	0.960	2.990
20.25	99.1	60.3	8.68	782	115.9	0.920	2.920	58.8	35.2	1450	185	0.18	0.960	2.990
21.25	100.2	60.9	8.43	751	115.9	0.920	2.920	58.8	35.2	1325	197	0.18	0.960	2.990
22.25	100.7	61.2	8.57	759	115.9	0.920	2.920	58.8	35.2	1175	238	0.18	0.960	2.990
23.25	100.0	60.8	8.85	791	115.9	0.920	2.920	58.8	35.2	1030	207	0.18	0.960	2.990
0.25	99.4	60.4	9.09	817	115.9	0.920	2.920	58.8	35.2	1065	188	0.18	0.960	2.990
1.25	99.9	60.7	9.38	839	118.5	0.920	2.920	66.0	35.2	1110	193	0.18	0.960	2.990
2.25	99.3	60.3	9.57	860	118.5	0.950	2.880	66.0	35.2	1155	222	0.18	0.960	2.990
3.25	100.0	60.8	9.42	841	118.5	0.950	2.880	66.0	35.2	1235	229	0.18	0.960	2.990
4.25	99.5	60.5	9.38	842	118.5	0.950	2.880	66.0	35.2	1365	241	0.18	0.960	2.990
5.25	100.8	61.3	9.02	799	118.5	0.950	2.880	66.0	35.2	1500	212	0.18	0.960	2.990
6.25	99.5	60.5	9.03	811	118.5	0.950	2.880	66.0	35.2	1500	219	0.18	0.960	2.990
7.25	98.7	60.0	9.01	814	118.5	0.950	2.880	66.0	35.2	1500	185	0.18	0.960	2.990

0.00 - 7.27														
MAX	101.5	61.7	9.75	875.	118.5	0.950	2.920	66.0	35.2	1500.	259.	0.18	0.960	2.990
MIN	98.4	59.8	8.90	791.	115.9	0.920	2.880	58.8	35.2	1065.	177.	0.18	0.960	2.990
MEAN	100.0	60.8	9.28	829.	118.0	0.945	2.888	64.7	35.2	1296.	218.	0.18	0.960	2.990
ACCH	745.4	453.2	69.17	829.	118.1	0.946	2.886	65.0	35.2	1331.	218.	0.18	0.960	2.990
0.00 - 0.00														
MAX	101.3	61.6	10.14	914.	121.2	0.980	2.920	73.2	35.2	1470.	274.	0.24	0.960	3.060
MIN	98.0	59.6	8.28	738.	115.9	0.920	2.850	58.8	34.5	1030.	167.	0.18	0.890	2.990
MEAN	99.9	60.7	9.25	828.	118.2	0.947	2.879	65.1	34.9	1308.	229.	0.21	0.924	3.027
ACCH	2396.4	1457.0	222.00	828.	118.0	0.945	2.880	64.8	34.9	1305.	229.	0.21	0.925	3.025

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ Z02 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCO EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO		
	0A15A1		0A15X1		A54P1		A53P1		A51T1		A50T1		0A2V1				
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM		
7.25	1.8	30.9	102	4.60	802	179	775	313	621	392	383	397	604	0.00	843		
8.25	1.8	31.8	109	4.69	800	194	782	328	616	393	384	398	624	0.00	852		
9.25	1.8	31.5	121	4.04	801	201	779	336	620	393	384	398	632	0.00	859		
10.25	1.8	30.9	121	3.97	804	211	784	341	632	394	384	398	631	0.00	857		
11.25	1.8	37.9	120	3.29	803	208	779	333	622	393	385	398	620	0.00	857		
12.25	1.8	37.5	122	3.79	802	209	784	337	621	392	380	398	630	0.02	864		
13.25	1.8	36.2	127	4.01	801	221	778	346	626	392	384	398	651	0.01	873		
14.25	1.8	36.0	126	4.33	801	224	784	347	627	394	388	482	651	0.01	879		
15.25	1.8	35.3	124	2.75	805	212	793	348	637	399	389	400	642	0.02	872		
16.25	1.8	33.1	124	2.96	806	225	786	348	627	395	387	482	630	0.03	874		
17.25	1.8	27.2	130	3.62	804	216	785	347	628	398	386	401	631	0.01	874		
18.25	1.8	24.7	129	4.30	804	211	778	340	630	394	389	400	630	0.01	869		
19.25	1.8	25.6	127	3.82	805	209	784	339	629	394	385	401	615	0.02	866		
20.25	1.8	32.8	108	4.20	801	186	777	329	631	398	389	483	614	0.01	862		
21.25	1.8	31.2	122	4.92	798	209	784	329	622	395	385	401	617	0.00	867		
22.25	1.8	25.1	124	4.69	797	204	781	344	620	393	384	399	632	0.01	868		
23.25	1.8	27.2	128	3.90	799	218	780	340	622	392	384	399	634	0.00	864		
0.25	1.8	30.6	117	4.02	801	210	780	332	626	396	387	482	641	0.00	869		
1.25	1.8	35.3	114	3.41	803	203	785	325	624	395	387	399	636	0.00	866		
2.25	1.8	36.0	105	3.54	805	195	785	326	632	398	388	482	631	0.00	867		
3.25	1.8	34.6	96	3.45	804	176	787	301	626	399	390	485	609	0.00	857		
4.25	1.8	28.3	82	10.33	805	173	778	298	621	399	391	484	593	0.01	853		
5.25	1.8	25.1	78	6.54	805	154	778	295	629	398	391	483	685	0.01	854		
6.25	1.8	22.4	80	5.24	803	185	775	286	619	397	390	482	607	0.00	854		
7.25	1.8	19.5	86	5.08	803	166	770	303	626	393	385	398	595	0.00	855		

0.00 - 7.28

MAX	1.9	37.0	135.	10.46	809.	230.	793.	352.	639.	404.	397.	411.	648.	0.03	872.		
MIN	1.9	19.0	73.	2.23	797.	119.	764.	281.	612.	387.	381.	396.	587.	-0.03	834.		
MEAN	1.9	29.5	98.	5.00	804.	184.	780.	308.	626.	397.	389.	403.	615.	0.00	859.		
ACCM	1.9	29.5	98.		804.	184.	780.	308.	626.	397.	389.	403.	615.	0.00	859.		

0.00 - 0.00

MAX	1.9	38.6	142.	10.50	812.	241.	797.	365.	642.	407.	394.	407.	665.	0.09	885.		
MIN	1.9	24.2	86.	1.34	796.	128.	768.	301.	613.	387.	379.	391.	574.	-0.04	824.		
MEAN	1.9	31.6	119.	3.92	803.	206.	783.	334.	627.	395.	386.	400.	623.	0.01	859.		
ACCM	1.9	31.6	119.		803.	206.	783.	334.	627.	395.	386.	400.	623.	0.01	859.		

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KMZF1*			ESTLTW			NOXST		NOXALT		A50ALT		KMZF1		
	KCONTRL			LTWT	LTWGTSP		NOXL	NOXLT	A50T1	DA15X1	DA1X2CO	DA2V1			
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	T/H	RPH	
7.25				1405	1378	1388	48.7	51.8	-0.239	397	-0.10	4.68	0.00	9.00	843
8.25				1340	1258	1312	37.4	38.3	-0.187	398	-0.26	4.69	0.00	9.02	852
9.25				1290	1155	1167	27.4	27.0	-0.283	398	-0.03	4.84	0.00	9.25	859
10.25				1160	1233	1226	34.8	33.9	0.210	398	-0.09	3.97	0.00	9.45	857
11.25				1275	1306	1303	40.6	40.7	0.323	398	0.08	3.29	0.00	9.38	857
12.25				1325	1351	1344	45.6	46.2	0.113	398	-0.07	3.79	0.02	9.19	864
13.25				1360	1294	1304	39.6	39.4	-0.271	398	0.02	4.01	0.01	9.22	873
14.25				1250	1220	1222	32.0	31.1	-0.173	402	0.00	4.33	0.01	10.05	879
15.25				1220	1301	1271	41.6	39.6	0.471	400	-0.28	2.75	0.02	9.46	872
16.25				1280	1383	1314	49.0	49.1	0.343	402	0.07	2.96	0.03	9.31	874
17.25				1365	1342	1344	47.0	47.4	-0.325	401	-0.17	3.62	0.01	9.05	874
18.25				1460	1321	1284	42.5	42.6	-0.294	400	-0.06	4.30	0.01	9.13	869
19.25				1470	1340	1342	43.7	42.4	-0.037	401	-0.03	3.82	0.02	9.12	866
20.25				1450	1279	1374	32.1	34.5	-0.518	403	0.22	4.20	0.01	8.68	862
21.25				1325	1187	1315	19.8	20.9	-0.570	401	-0.14	4.92	0.00	8.43	867
22.25				1175	1132	1146	13.1	12.5	-0.124	399	-0.13	4.69	0.01	8.57	868
23.25				1030	1124	1204	15.9	16.1	0.098	399	0.05	3.90	0.00	8.85	864
0.25				1065	1162	1131	21.3	20.9	0.193	402	0.29	4.02	0.00	9.09	869
1.25				1110	1172	1152	22.7	22.6	0.024	399	0.27	3.41	0.00	9.38	866
2.25				1155	1319	1259	32.3	33.1	0.216	402	0.38	3.54	0.00	9.57	867
3.25				1235	1607	1279	52.4	52.8	0.610	405	0.25	3.45	0.00	9.42	857
4.25				1365	1573	1496	51.1	50.4	-0.075	404	0.01	10.33	0.01	9.38	853
5.25				1500	1585	1553	51.1	51.3	-0.125	403	0.06	6.54	0.01	9.02	854
6.25				1500	1395	1227	43.6	38.5	0.014	402	0.15	5.24	0.00	9.03	854
7.25				1500	1375	1378	37.3	37.1	-0.173	398	0.15	5.08	0.00	9.01	855

0.00 - 7.30

MAX				1500.	1661.	1574.	56.4	56.5	0.899	411.	0.45	10.46	0.03	9.75	872.
MIN				1065.	1138.	1115.	18.2	18.7	-0.752	396.	-0.72	2.23	-0.03	8.98	834.
MEAN	7.50	3.48		1297.	1406.	1281.	38.9	38.9	0.091	403.	-0.01	5.00	0.00	9.27	859.
ACCM	161.9	134.1		1331.		1281.			0.091	403.	-0.01		0.00	69.56	859.

0.00 - 0.00

MAX				1470.	1515.	1494.	59.3	60.1	0.614	407.	0.47	10.50	0.09	10.14	885.
MIN				1030.	1114.	1031.	12.8	12.0	-0.801	391.	-0.48	1.34	-0.04	8.28	824.
MEAN	24.02	21.68		1308.	1302.	1299.	40.0	40.0	-0.020	400.	0.00	3.92	0.01	9.25	859.
ACCM	154.5	130.7		1305.		1299.			-0.020	400.	0.00		0.01	222.00	859.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU		LTWT
	PROD		T	KN2F1		C-ASH				T/H	LB. COAL		KN2F1*
	T/H	T/H		KC/KG	KC/KG	Z	Z	GR/L	H				
7.25	100.0	60.8	1468	9.00	803	824	20.0	3.51	9519	66.0	0	28.54	1465
8.25	99.3	60.4	1458	9.02	811	832	20.0	3.51	9519	65.6	0	28.85	1340
9.25	99.1	60.2	1446	9.25	834	856	20.0	3.51	9519	65.4	0	29.59	1290
10.25	99.6	60.5	1453	9.45	847	870	20.0	3.51	9519	65.7	0	30.06	1160
11.25	99.0	60.1	1444	9.38	847	869	20.0	3.51	9519	65.3	0	30.07	1275
12.25	100.3	60.9	1463	9.19	819	840	20.0	3.51	9522	66.2	0	29.14	1325
13.25	100.8	61.2	1470	9.22	817	826	19.3	3.03	9667	66.5	0	29.48	1360
14.25	99.4	60.4	1451	10.05	902	912	19.3	3.03	9667	65.6	0	32.74	1250
15.25	100.1	60.8	1461	9.46	844	854	19.3	3.03	9667	66.0	0	30.59	1220
16.25	100.3	61.0	1464	9.31	829	838	19.3	3.03	9664	66.2	0	30.84	1280
17.25	100.2	60.9	1462	9.05	806	815	19.3	3.03	9667	66.1	0	29.81	1365
18.25	100.0	60.8	1459	9.13	815	824	19.3	3.03	9664	66.0	0	29.56	1460
19.25	99.4	60.4	1451	9.12	819	829	19.3	3.03	9664	65.6	0	29.50	1470
20.25	99.1	60.3	1447	8.68	782	790	19.3	3.03	9664	65.4	0	28.30	1450
21.25	100.2	60.9	1462	8.43	751	759	19.3	3.03	9664	66.1	0	27.21	1325
22.25	100.7	61.2	1470	8.57	759	768	19.3	3.03	9664	66.5	0	27.59	1175
23.25	100.0	60.8	1459	8.85	791	800	19.3	3.03	9664	66.0	0	28.68	1030
0.25	99.4	60.4	1451	9.09	817	826	19.3	3.03	9667	65.6	0	29.43	1065
1.25	99.9	60.7	1458	9.38	839	848	19.3	3.03	9667	65.9	0	30.23	1110
2.25	99.3	60.3	1449	9.57	860	870	19.3	3.03	9667	65.5	0	30.98	1155
3.25	100.0	60.8	1459	9.42	841	851	19.3	3.03	9667	66.0	0	30.45	1235
4.25	99.5	60.5	1452	9.38	842	851	19.3	3.03	9667	65.6	0	30.42	1365
5.25	100.8	61.3	1471	9.02	799	808	19.3	3.03	9667	66.5	0	28.96	1500
6.25	99.5	60.5	1452	9.03	811	820	19.3	3.03	9667	65.6	0	29.33	1500
7.25	98.7	60.0	1441	9.01	814	823	19.3	3.03	9667	65.1	0	29.46	1500

0.00 - 7.30

MAX	101.5	61.7	1481.	9.75	875.	885.	19.3	3.03	9667.	67.0	0.	31.65	1500.
MIN	98.4	59.8	1436.	8.90	791.	800.	19.3	3.03	9664.	64.9	0.	28.61	1065.
MEAN	100.0	60.8	1459.	9.27	829.	838.	19.3	3.03	9666.	66.0	0.	29.97	1298. 7.51
ACCM	750.8	456.5		69.66	829.	838.	19.3	3.03			0.	29.96	1331. 161.9

0.00 - 0.00

MAX	101.3	61.6	1479.	10.14	914.	924.	20.0	3.51	9667.	66.9	0.	33.03	1470.
MIN	98.0	59.6	1431.	8.28	738.	746.	19.3	3.03	9519.	64.7	0.	26.66	1030.
MEAN	99.9	60.7	1457.	9.25	828.	844.	19.7	3.28	9589.	65.9	0.	29.68	1308. 24.02
ACCM	2396.4	1457.0		222.00	828.	843.	19.7	3.28			0.	29.68	1305. 154.5

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S

W1/ KILN FEED MS

W1/ KILN FEED LSF

W1/ BURNING FACTOR

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUCTION

W1/ KILN FEED

W1/ FEED LOSS-0-1G

U1/ LITER WEIGHT

U1/ CLINKER TEMP

U1/ FREE LIME

U1/ CLINKER LSF

U1/ CLINKER MS

KILN CONTROL

COAL TO KILN

HOUR	HO1OF1	KM2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL	KM2F1*					
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS							
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.25	99.8	60.6	8.99	804	118.5	0.950	2.880	66.0	35.2	1500	200	0.18	0.960	2.990
8.25	100.5	61.1	9.01	800	118.5	0.950	2.880	66.0	35.2	1350	194	0.18	0.960	2.990
9.25	100.1	60.9	8.70	776	113.0	0.900	2.870	54.5	35.2	1455	243	0.18	0.960	2.990
10.25	100.6	61.1	8.68	770	113.0	0.900	2.870	54.5	35.2	1290	201	0.18	0.960	2.990
11.25	99.8	60.7	8.68	776	113.0	0.900	2.870	54.5	35.2	1230	202	0.18	0.960	2.990
12.25	99.7	60.6	8.89	796	115.1	0.910	2.950	56.5	35.2	1225	185	0.30	0.930	3.050
13.25	99.4	60.4	9.16	823	115.1	0.910	2.950	56.5	35.2	1185	184	0.30	0.930	3.050
14.25	91.0	55.3	9.20	902	115.1	0.910	2.950	56.5	35.2	1185	171	0.30	0.930	3.050
15.25	90.0	54.7	9.20	913	115.1	0.910	2.950	56.5	35.2	1185	187	0.30	0.930	3.050
16.25	90.9	55.3	9.26	909	118.8	0.950	2.910	66.0	35.2	1185	207	0.30	0.930	3.050
17.25	99.5	60.5	9.14	820	118.8	0.950	2.910	66.0	35.2	1250	195	0.30	0.930	3.050
18.25	100.0	60.8	8.77	783	118.8	0.950	2.910	66.0	35.2	1330	238	0.30	0.930	3.050
19.25	99.8	60.7	8.94	799	118.8	0.950	2.910	66.0	35.2	1300	235	0.30	0.930	3.050
20.25	99.7	60.6	9.24	828	118.8	0.950	2.910	66.0	35.2	1300	205	0.30	0.930	3.050
21.25	99.5	60.5	9.35	839	118.8	0.950	2.910	66.0	35.2	1250	204	0.30	0.930	3.050
22.25	100.1	60.8	9.04	807	118.8	0.950	2.910	66.0	35.2	1340	201	0.30	0.930	3.050
23.25	99.4	60.4	9.10	817	118.8	0.950	2.910	66.0	35.2	1420	191	0.30	0.930	3.050
0.25	100.2	60.9	9.30	829	115.9	0.910	3.030	57.3	35.2	1305	222	0.30	0.930	3.050
1.25	99.1	60.2	9.15	825	115.9	0.910	3.030	57.3	35.2	1265	235	0.30	0.930	3.050
2.25	98.7	60.0	9.34	845	115.9	0.910	3.030	57.3	35.2	1305	220	0.30	0.930	3.050
3.25	98.7	60.0	9.26	837	115.9	0.910	3.030	57.3	35.2	1250	241	0.30	0.930	3.050
4.25	99.9	60.7	9.09	813	115.9	0.910	3.030	57.3	35.2	1320	240	0.30	0.930	3.050
5.25	98.9	60.1	9.30	840	115.9	0.910	3.030	57.3	35.2	1320	249	0.30	0.930	3.050
6.25	98.7	60.0	9.08	821	115.9	0.910	3.030	57.3	35.2	1290	227	0.30	0.930	3.050
7.25	98.8	60.1	8.76	792	116.0	0.930	2.890	60.8	35.2	1275	240	0.30	0.930	3.050

0.00 - 7.26

MAX	101.1	61.5	9.46	855.	116.0	0.930	3.030	60.9	35.2	1420.	259.	0.30	0.930	3.050
MIN	97.9	59.5	8.67	773.	115.9	0.910	2.890	57.3	35.2	1250.	197.	0.30	0.930	3.050
MEAN	99.6	60.6	9.18	823.	115.9	0.910	3.028	57.4	35.2	1296.	232.	0.30	0.930	3.050
ACCM	742.1	451.2	68.37	823.	115.9	0.910	3.030	57.3	35.2	1289.	232.	0.30	0.930	3.050
													7.00	7.45
													149.4	185.2

0.00 - 0.00

MAX	101.5	61.7	9.75	10465.	118.8	0.950	3.030	66.0	35.2	1600.	259.	0.30	0.960	3.050
MIN	-4.8	-2.9	1.21	-6746.	113.0	0.900	2.870	54.6	35.2	1065.	89.	0.18	0.930	2.990
MEAN	98.6	59.9	9.08	821.	117.2	0.936	2.902	62.7	35.2	1290.	209.	0.24	0.944	3.020
ACCM	2330.5	1416.0	214.49	823.	117.1	0.934	2.908	62.3	35.2	1299.	209.	0.25	0.944	3.023
													142.4	177.9

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ ZD2 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCO EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0	
	0A15A1		0A15X1		A54P1		A53P1		A51T1		A50T1				0A2V1	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.25	1.8	20.4	89	5.78	800	166	774	294	620	395	387	400	609	0.00	852	
8.25	1.8	22.2	87	5.01	802	167	772	298	620	395	387	401	596	0.00	857	
9.25	1.8	19.9	84	4.80	801	176	773	305	620	393	384	398	596	0.01	853	
10.25	1.8	20.1	100	6.30	800	185	771	314	614	388	380	393	599	0.02	853	
11.25	1.8	17.9	99	3.53	800	188	770	318	613	387	377	393	601	0.00	851	
12.25	1.8	18.3	107	3.82	800	192	774	328	618	390	379	395	612	-0.01	865	
13.25	1.8	22.6	107	2.66	800	213	776	318	622	389	380	396	603	-0.01	866	
14.25	1.8	20.9	92	4.37	799	188	783	299	633	407	402	413	581	0.03	866	
15.25	1.8	29.1	87	3.33	804	184	784	302	629	404	396	409	572	0.00	870	
16.25	1.8	37.3	87	3.76	804	180	788	305	638	407	400	414	578	0.00	867	
17.25	1.8	34.7	86	3.39	806	166	785	313	627	397	390	404	592	0.00	870	
18.25	1.8	28.6	95	3.82	800	184	779	306	622	390	379	396	595	-0.04	859	
19.25	1.8	26.0	100	3.63	801	186	777	308	619	390	379	395	610	-0.07	864	
20.25	1.8	29.1	97	3.31	802	175	775	306	620	389	380	394	609	-0.08	859	
21.25	1.8	30.4	100	2.64	804	190	782	310	623	392	382	397	609	-0.12	860	
22.25	1.8	32.9	94	3.19	802	195	780	310	622	391	381	396	617	-0.17	861	
23.25	1.8	33.2	101	3.02	803	194	775	313	621	389	380	394	613	-0.16	865	
0.25	1.8	34.1	108	3.14	803	198	781	314	627	391	380	397	620	-0.15	864	
1.25	1.8	36.1	106	3.08	802	194	781	314	623	393	381	389	619	-0.17	863	
2.25	1.8	33.9	113	2.62	802	200	781	325	623	391	381	396	620	-0.18	862	
3.25	1.8	35.1	115	2.36	802	216	787	322	623	390	381	395	620	-0.18	861	
4.25	1.8	35.7	111	2.44	802	187	787	325	627	394	383	398	631	-0.18	869	
5.25	1.8	33.6	126	2.48	803	215	782	330	625	393	384	398	625	-0.18	864	
6.25	1.8	33.6	99	3.54	803	192	780	290	627	396	388	402	598	-0.18	863	
7.25	1.9	33.7	98	4.00	801	174	778	297	624	394	388	399	600	-0.01	854	

0.00 - 7.28																
MAX	1.9	36.6	144.	10.43	815.	231.	791.	350.	635.	401.	392.	406.	647.	-0.01	874.	
MIN	1.9	32.9	87.	1.74	798.	149.	770.	282.	616.	384.	377.	389.	576.	-0.21	842.	
MEAN	1.9	34.7	114.	3.08	803.	196.	783.	321.	625.	393.	383.	398.	621.	-0.18	864.	
ACCM	1.9	34.7	114.		803.	196.	783.	321.	625.	393.	383.	398.	621.	-0.18	864.	

0.00 - 8.00																
MAX	1.9	38.4	137.	10.54	816.	230.	797.	377.	662.	431.	429.	418.	648.	0.39	878.	
MIN	0.8	0.1	-10.	-0.88	760.	22.	741.	3.	602.	383.	375.	380.	52.	-0.20	469.	
MEAN	1.9	27.6	97.	4.27	803.	184.	779.	309.	624.	395.	386.	400.	603.	-0.03	860.	
ACCM	1.9	27.6	97.		803.	184.	779.	309.	624.	395.	386.	400.	603.	-0.03	860.	

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTM FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTM	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ ZCO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1	
	KCONTRL		LTWT		LTWGTSP		NOXLT		A50T1		OA15X1		OA1X2CO	
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	T/H	RPM
7.25			1500	1396	1399	38.9	38.6	-0.304	400	0.00	5.78	0.00	8.99	852
8.25			1350	1329	1330	36.7	32.9	-0.165	401	0.20	5.81	0.00	9.81	857
9.25			1455	1336	1400	31.7	30.9	0.116	398	-0.08	4.80	0.01	8.78	853
10.25			1290	1361	1401	31.1	31.2	-0.012	393	-0.15	6.30	0.02	8.68	853
11.25			1230	1366	1328	30.8	31.5	0.224	393	-0.02	3.53	0.00	8.68	851
12.25			1225	1149	1282	23.9	23.6	-0.229	395	-0.02	3.82	-0.01	8.89	865
13.25			1185	1145	1163	22.9	21.8	-0.185	396	-0.11	2.66	-0.01	9.16	866
14.25			1185	894	5122	8.3	8.6	-0.869	413	2.31	4.37	0.03	9.20	866
15.25			1185	1091	1252	19.7	19.0	0.173	409	1.22	3.33	0.00	9.20	870
16.25			1185	1254	1222	29.3	27.5	-0.079	414	0.85	3.76	0.00	9.26	867
17.25			1250	1613	1351	43.4	44.8	0.480	404	-1.41	3.39	0.00	9.14	870
18.25			1330	1731	1356	49.6	50.4	0.019	396	-0.09	3.82	-0.04	8.77	859
19.25			1300	1291	1269	37.9	36.6	-0.342	395	0.03	3.63	-0.07	8.94	864
20.25			1300	1236	1256	28.2	27.4	-0.552	394	-0.12	3.31	-0.08	9.24	859
21.25			1250	1271	1282	39.5	40.0	0.350	397	0.23	2.64	-0.12	9.35	860
22.25			1340	1285	1312	43.4	44.1	0.048	396	-0.08	3.19	-0.17	9.04	861
23.25			1420	1267	1286	34.6	34.3	-0.178	394	-0.11	3.82	-0.16	9.10	865
0.25			1305	1248	1280	34.3	31.5	-0.044	397	-0.01	3.14	-0.15	9.30	864
1.25			1265	1284	1306	36.1	36.8	0.188	389	0.10	3.08	-0.17	9.15	863
2.25			1305	1260	1286	33.5	33.3	-0.091	396	0.15	2.62	-0.18	9.34	862
3.25			1250	1288	1305	37.4	37.4	0.120	395	0.00	2.36	-0.18	9.26	861
4.25			1320	1286	1307	36.2	37.1	-0.102	398	0.09	2.44	-0.18	9.09	869
5.25			1320	1283	1296	36.6	36.7	-0.005	398	0.06	2.48	-0.18	9.30	864
6.25			1290	1312	1312	39.6	40.9	-0.004	402	0.26	3.54	-0.18	9.08	863
7.25			1275	1231	1271	28.8	29.0	-0.558	399	-0.09	4.00	-0.01	8.76	854

0.00 - 7.29

MAX			1420.	1322.	1318.	43.3	42.4	0.246	406.	0.58	10.43	-0.01	9.46	874.
MIN			1250.	1227.	1268.	28.2	27.9	-0.634	389.	-0.41	1.74	-0.21	8.67	842.
MEAN	7.50	7.00	1295.	1281.	1300.	36.4	36.4	-0.006	398.	0.02	3.08	-0.18	9.18	864.
ACCM	185.3	149.4	1289.		1300.			-0.006	398.	0.02		-0.18	68.74	864.

0.00 - 8.00

MAX			1600.	1771.	6100.	56.4	56.5	0.899	418.	2.32	10.54	0.39	9.75	878.
MIN			1065.	861.	1012.	8.3	6.9	-0.888	380.	-1.58	-0.08	-0.20	1.21	469.
MEAN	23.64	11.89	1290.	1337.	1330.	34.4	34.4	0.023	400.	-0.01	4.27	-0.03	9.08	860.
ACCM	177.9	142.4	1299.		1330.			0.023	400.	-0.01		-0.03	214.49	860.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL

% MOISTURE IN COAL

NET HEAT CONSUMP.

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUC. RATE

KILN PRODUCTION

W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER

LB COAL / SH. T

MBTU' PER SH. T

U1/ LITER WEIGHT

COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT	STONS	BTU	LTWT	KM2F1*	
	PROD		T	T/H	KC/KG	KC/KG	%	%	T/H	LB. COAL	GR/L		H
	T/H	T/H											
7.25	99.8	60.6	1456	8.99	804	813	19.3	3.03	9667	65.8	0	29.17	1580
8.25	100.5	61.1	1467	9.01	800	809	19.3	3.03	9667	66.3	0	28.86	1350
9.25	100.1	60.9	1461	8.70	776	784	19.3	3.03	9667	66.1	0	28.86	1455
10.25	100.6	61.1	1468	8.68	770	779	19.3	3.03	9667	66.4	0	27.83	1290
11.25	99.8	60.7	1457	8.68	776	785	19.3	3.03	9667	65.9	0	28.22	1230
12.25	99.7	60.6	1456	8.89	796	814	19.5	3.00	9553	65.8	0	28.33	1225
13.25	99.4	60.4	1451	9.16	823	842	19.5	3.00	9553	65.6	0	29.55	1185
14.25	91.0	55.3	1329	9.20	902	923	19.5	3.00	9553	60.1	0	32.37	1185
15.25	90.0	54.7	1314	9.20	913	934	19.5	3.00	9553	59.4	0	32.48	1185
16.25	90.9	55.3	1327	9.26	909	930	19.5	3.00	9553	60.0	0	32.50	1185
17.25	99.5	60.5	1453	9.14	820	839	19.5	3.00	9553	65.7	0	29.30	1250
18.25	100.0	60.8	1459	8.77	783	801	19.5	3.00	9550	66.0	0	27.95	1330
19.25	99.8	60.7	1457	8.94	799	818	19.5	3.00	9553	65.9	0	28.48	1300
20.25	99.7	60.6	1455	9.24	828	847	19.5	3.00	9553	65.8	0	29.36	1300
21.25	99.5	60.5	1453	9.35	839	858	19.5	3.00	9553	65.7	0	30.10	1250
22.25	100.1	60.8	1460	9.04	807	826	19.5	3.00	9553	66.0	0	28.76	1340
23.25	99.4	60.4	1451	9.10	817	836	19.5	3.00	9550	65.6	0	29.17	1420
0.25	100.2	60.9	1463	9.30	829	848	19.5	3.00	9550	66.1	0	29.67	1305
1.25	99.1	60.2	1446	9.15	825	844	19.5	3.00	9553	65.4	0	29.48	1265
2.25	98.7	60.0	1441	9.34	845	864	19.5	3.00	9553	65.1	0	30.21	1305
3.25	98.7	60.0	1441	9.26	837	857	19.5	3.00	9553	65.2	0	29.72	1250
4.25	99.9	60.7	1457	9.09	813	832	19.5	3.00	9553	65.9	0	29.09	1320
5.25	98.9	60.1	1443	9.30	840	859	19.5	3.00	9553	65.3	0	29.92	1320
6.25	98.7	60.0	1440	9.08	821	840	19.5	3.00	9553	65.1	0	29.28	1290
7.25	98.8	60.1	1442	8.76	792	810	19.5	3.00	9553	65.2	0	28.22	1275

0.00 - 7.30

MAX	101.1	61.5	1475.	9.46	855.	875.	19.5	3.00	9553.	66.7	0.	30.55	1420.
MIN	97.9	59.5	1429.	8.67	773.	791.	19.5	3.00	9550.	64.6	0.	27.61	1250.
MEAN	99.6	60.6	1454.	9.18	823.	842.	19.5	3.00	9552.	65.7	0.	29.40	1295. 7.51
ACCM	747.5	454.4		68.84	823.	842.	19.5	3.00		0.	29.39		1289. 185.3

0.00 - 0.00

MAX	101.5	61.7	1481.	9.75	18465.	18891.	19.5	3.00	9667.	67.0	7.	659.77	1600.
MIN	-4.8	-2.9	-82.	1.21	-6746.	-6902.	19.3	3.03	9550.	-3.7	-3.	-241.05	1065.
MEAN	98.6	59.9	1416.	9.08	821.	835.	19.4	3.42	9608.	64.1	0.	29.51	1290. 23.64
ACCM	2330.5	1416.0		214.49	823.	835.	19.4	3.42		0.	29.51		1299. 177.9

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-IC
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1	KN2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL						
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KN2F1*						
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.25	99.4	60.4	8.76	787	115.9	0.910	3.030	57.3	35.2	1290	226	0.30	0.930	3.050
8.25	100.6	61.1	9.10	808	116.0	0.930	2.890	60.8	35.2	1180	254	0.30	0.930	3.050
9.25	99.7	60.6	9.35	837	116.0	0.930	2.890	60.8	35.2	1125	212	0.30	0.930	3.050
10.25	99.0	60.2	9.45	852	116.0	0.930	2.890	60.8	35.2	1190	188	0.30	0.930	3.050
11.25	99.0	60.2	9.29	838	116.0	0.930	2.890	60.8	35.2	1300	220	0.30	0.930	3.050
12.25	100.3	61.0	9.24	822	114.5	0.910	2.950	54.9	34.9	1275	245	0.24	0.920	3.070
13.25	99.7	60.6	9.41	843	114.5	0.910	2.950	54.9	34.9	1250	276	0.24	0.920	3.070
14.25	99.6	60.5	9.45	847	114.5	0.910	2.950	54.9	34.9	1275	273	0.24	0.920	3.070
15.25	100.3	61.0	9.29	827	114.5	0.910	2.950	54.9	34.9	1315	246	0.24	0.920	3.070
16.25	99.0	60.2	9.08	819	114.5	0.910	2.950	54.9	34.9	1380	260	0.24	0.920	3.070
17.25	99.9	60.7	8.83	789	118.8	0.950	2.930	66.2	34.9	1375	251	0.24	0.920	3.070
18.25	99.5	60.5	9.05	812	118.8	0.950	2.930	66.2	34.9	1280	268	0.24	0.920	3.070
19.25	99.3	60.3	9.29	835	118.8	0.950	2.930	66.2	34.9	1110	258	0.24	0.920	3.070
20.25	99.7	60.6	9.54	854	118.8	0.950	2.930	66.2	34.9	1090	229	0.24	0.920	3.070
21.25	100.3	61.0	9.90	882	118.8	0.950	2.930	66.2	34.9	1150	195	0.24	0.920	3.070
22.25	100.1	60.8	9.54	850	118.8	0.950	2.930	66.2	34.9	1250	225	0.24	0.920	3.070
23.25	99.4	60.4	8.53	766	118.8	0.950	2.930	66.2	34.9	1380	239	0.24	0.920	3.070
0.25	100.9	61.3	9.07	803	118.8	0.950	2.930	66.2	34.9	1405	204	0.24	0.920	3.070
1.25	100.0	60.8	8.86	791	119.7	0.960	2.910	68.9	34.9	1360	204	0.24	0.920	3.070
2.25	100.1	60.9	8.97	800	119.7	0.960	2.910	68.9	34.9	1360	230	0.24	0.920	3.070
3.25	99.7	60.6	9.04	810	119.7	0.960	2.910	68.9	34.9	1385	241	0.24	0.920	3.070
4.25	100.2	60.9	8.97	799	119.7	0.960	2.910	68.9	34.9	1270	236	0.24	0.920	3.070
5.25	100.7	61.2	8.81	781	119.7	0.960	2.910	68.9	34.9	1380	243	0.24	0.920	3.070
6.25	99.9	60.7	8.83	789	119.7	0.960	2.910	68.9	34.9	1385	230	0.24	0.920	3.070
7.25	99.6	60.5	9.09	815	116.1	0.940	2.800	62.9	34.9	1310	235	0.24	0.920	3.070

0.00 - 7.26

MAX	101.5	61.7	9.20	832.	119.7	0.960	2.930	68.9	34.9	1405.	253.	0.24	0.920	3.070
MIN	98.2	59.6	8.64	767.	116.1	0.940	2.800	63.0	34.9	1270.	186.	0.24	0.920	3.070
MEAN	99.6	60.6	8.94	801.	119.3	0.957	2.906	68.1	34.9	1325.	228.	0.24	0.920	3.070
ACCM	742.2	451.3	66.56	801.	119.1	0.956	2.897	67.7	34.9	1324.	228.	0.24	0.920	3.070

0.00 - 0.00

MAX	108.6	66.0	10.22	923.	118.8	0.950	3.030	66.2	35.2	1420.	288.	0.30	0.930	3.070
MIN	97.6	59.3	3.90	340.	114.5	0.910	2.890	54.9	34.9	1090.	179.	0.24	0.920	3.050
MEAN	99.7	60.6	9.26	830.	116.5	0.926	2.958	60.2	35.1	1262.	239.	0.27	0.925	3.061
ACCM	2392.5	1454.6	222.27	830.	116.6	0.927	2.957	60.4	35.1	1254.	239.	0.27	0.925	3.061

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	34.3	103	10.31	801	178	773	298	621	394	385	400	604	-0.18	856	
8.25	1.8	29.1	98	3.80	800	193	772	294	618	388	380	395	604	-0.03	855	
9.25	1.8	30.9	90	3.03	804	180	780	288	622	391	383	395	592	0.00	859	
10.25	1.8	32.4	76	3.17	805	145	772	280	612	393	384	398	585	-0.01	859	
11.25	1.8	35.4	81	3.72	804	169	778	276	620	394	385	398	581	-0.01	861	
12.25	1.8	42.4	80	4.05	803	169	781	293	627	395	388	400	596	0.00	861	
13.25	1.8	39.9	81	4.00	804	164	785	296	626	394	385	400	584	-0.01	853	
14.25	1.8	38.2	82	2.89	805	178	785	300	628	394	385	400	588	0.00	854	
15.25	1.8	39.6	88	3.07	807	161	783	302	629	395	385	401	590	0.00	851	
16.25	1.8	38.7	101	2.94	803	190	780	318	620	393	383	398	610	0.01	864	
17.25	1.8	36.6	126	3.52	802	208	779	334	621	388	381	396	616	-0.01	866	
18.25	1.8	32.5	88	3.87	803	177	780	300	623	394	384	397	601	0.00	864	
19.25	1.8	32.9	87	3.55	804	167	782	295	626	393	384	397	595	0.00	855	
20.25	1.8	35.1	87	2.27	806	182	788	298	630	392	382	398	598	0.00	855	
21.25	1.8	36.4	107	0.90	809	186	789	317	623	391	380	395	600	0.01	855	
22.25	1.8	39.4	103	2.24	813	190	791	314	627	396	389	403	608	0.00	860	
23.25	1.8	36.2	115	3.00	806	214	785	329	628	393	384	398	614	0.00	863	
0.25	1.8	30.4	120	3.56	803	219	784	324	618	388	378	393	618	0.01	860	
1.25	1.8	35.9	119	3.59	804	203	783	328	622	392	381	396	616	0.00	863	
2.25	1.8	35.1	110	2.96	804	196	786	317	630	390	382	397	610	0.00	861	
3.25	1.8	34.3	118	3.11	802	203	788	328	625	390	381	397	613	0.00	860	
4.25	1.8	35.1	130	3.22	803	214	785	332	623	391	385	398	610	0.00	860	
5.25	1.8	33.7	113	3.71	805	190	784	306	630	400	394	404	609	0.00	863	
6.25	1.8	34.0	114	3.87	802	196	778	314	621	390	384	397	612	0.00	856	
7.25	1.8	34.0	115	3.15	803	201	778	313	625	391	384	397	612	-0.01	856	

0.00 - 7.28

MAX	1.9	37.6	156.	4.38	807.	244.	795.	354.	636.	404.	396.	407.	634.	0.03	870.
MIN	1.9	29.9	87.	2.01	799.	162.	772.	295.	610.	383.	377.	388.	585.	-0.04	842.
MEAN	1.9	34.5	119.	3.36	804.	202.	783.	323.	624.	391.	383.	397.	613.	-0.00	861.
ACCH	1.9	34.5	119.		804.	202.	783.	323.	624.	391.	383.	397.	613.	-0.00	861.

0.00 - 0.00

MAX	1.9	42.7	146.	10.52	825.	240.	798.	350.	639.	404.	394.	408.	647.	0.08	874.
MIN	1.9	28.4	70.	0.25	797.	132.	768.	266.	610.	382.	362.	387.	568.	-0.21	842.
MEAN	1.9	35.6	101.	3.29	804.	185.	782.	308.	624.	393.	384.	398.	605.	-0.06	860.
ACCH	1.9	35.6	101.		804.	185.	782.	308.	624.	393.	384.	398.	605.	-0.06	860.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTM FOR CONTRL
 W1/ ESTIMATED LTM
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KN2F1*		KALARM		ESTLTM		NOXST		NOXALT		A50ALT		KN2F1		
	KCONTRL		LTWT		LTWGTSP		NOXLT		A50T1		OA15X1		OA1X2CO		
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	Z	T/H	RPM
7.25				1290	1288	1302	35.4	37.4	-0.276	400	0.09	10.31	-0.18	8.76	856
8.25				1180	1172	1174	21.2	28.4	-0.283	395	-0.31	3.80	-0.03	9.18	855
9.25				1125	1226	1228	26.9	28.1	0.313	395	0.17	3.83	0.00	9.35	859
10.25				1190	1286	1261	35.9	36.5	0.269	398	-0.64	3.17	-0.01	9.45	859
11.25				1300	1288	1291	38.6	36.8	0.167	398	0.14	3.72	-0.01	9.29	861
12.25				1275	1273	1273	35.8	35.3	-0.437	400	0.37	4.05	0.00	9.24	861
13.25				1250	1294	1283	39.3	39.0	0.148	400	-0.27	4.00	-0.01	9.41	853
14.25				1275	1310	1298	42.0	41.6	0.335	400	0.83	2.89	0.00	9.45	854
15.25				1315	1359	1319	50.5	49.9	0.174	401	-0.48	3.07	0.00	9.29	851
16.25				1380	1352	1359	45.8	45.4	-0.310	398	0.13	2.94	0.01	9.08	864
17.25				1375	1301	1314	39.8	38.6	-0.228	396	-0.21	3.52	-0.01	8.83	866
18.25				1280	1133	1153	21.1	19.1	-0.905	397	-0.88	3.87	0.00	9.05	864
19.25				1110	1136	1135	22.4	21.5	0.053	397	-0.01	3.55	0.00	9.29	855
20.25				1090	1193	1235	27.9	28.2	0.152	398	-0.06	2.27	0.00	9.54	855
21.25				1150	1191	1177	29.8	29.8	0.041	395	0.23	0.90	0.01	9.90	855
22.25				1250	1191	1192	29.8	29.8	0.000	403	0.33	2.24	0.00	9.54	860
23.25				1380	1623	1386	73.0	74.9	0.275	398	-0.22	3.80	0.00	8.53	863
0.25				1405	1364	1292	55.0	53.0	-0.467	393	-0.83	3.56	0.01	9.07	860
1.25				1360	1323	1300	46.7	46.9	-0.195	396	-0.12	3.59	0.00	8.86	863
2.25				1360	1297	1279	43.8	43.2	-0.088	397	0.01	2.96	0.00	8.97	861
3.25				1305	1300	1300	43.1	43.6	0.033	397	0.00	3.11	0.00	9.04	860
4.25				1270	1301	1298	44.7	45.1	-0.018	398	0.24	3.22	0.00	8.97	860
5.25				1300	1303	1302	44.8	45.4	-0.024	404	0.27	3.71	0.00	8.81	863
6.25				1385	1265	1268	41.8	41.0	-0.588	397	0.38	3.87	0.00	8.83	856
7.25				1310	1261	1263	40.7	40.1	0.027	397	0.05	3.15	-0.01	9.09	856

0.00 - 7.29

MAX				1405.	1435.	1433.	56.1	55.3	0.358	407.	0.99	4.38	0.03	9.28	870.
MIN				1270.	1253.	1256.	38.5	39.0	-1.038	388.	-1.16	2.81	-0.04	8.64	842.
MEAN	7.50	6.74		1325.	1309.	1296.	45.6	45.5	-0.112	397.	0.01	3.36	-0.00	8.94	861.
ACCM	209.0	167.2		1324.		1296.			-0.112	397.	0.01		-0.00	66.95	861.

0.00 - 0.00

MAX				1420.	1723.	1710.	78.5	85.4	2.932	408.	1.25	10.52	0.08	10.22	874.
MIN				1090.	1123.	1123.	19.0	19.0	-1.023	387.	-0.95	0.25	-0.21	3.98	842.
MEAN	24.02	18.30		1262.	1280.	1279.	36.8	36.8	0.043	398.	-0.00	3.29	-0.06	9.26	860.
ACCM	201.6	160.5		1254.		1279.			0.043	398.	-0.00		-0.06	222.27	860.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL

Z MOISTURE IN COAL

NET HEAT CONSUMP.

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUC. RATE

KILN PRODUCTION

W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER

LB COAL / SH.T

MBTU' PER SH.T

U1/ LITER WEIGHT

COAL TO KILN

HO10F1	PRDR	KCAL	C-MOIST	C-HEAT	STONS	BTU	LTWT						
PROD	KN2F1	NCAL	C-ASH	LB. COAL	KN2F1*	GR/L	H						
T/H	T/H	T	T/H	KC/KG	KC/KG	%	%	T/H	GR/L	H			
7.25	99.4	60.4	1450	8.76	787	806	19.5	3.80	9553	65.6	0	28.36	1290
8.25	100.6	61.1	1468	9.10	888	826	19.5	3.80	9553	66.4	0	28.92	1180
9.25	99.7	60.6	1454	9.35	837	857	19.5	3.80	9553	65.8	0	29.92	1125
10.25	99.0	60.2	1445	9.45	852	871	19.5	3.80	9553	65.3	0	30.33	1190
11.25	99.0	60.2	1445	9.29	838	858	19.5	3.80	9553	65.3	0	29.99	1300
12.25	100.3	61.0	1464	9.24	822	845	20.0	3.60	9509	66.2	0	29.28	1275
13.25	99.7	60.6	1456	9.41	843	866	20.0	3.60	9512	65.8	0	30.06	1250
14.25	99.6	60.5	1453	9.45	847	871	20.0	3.60	9512	65.7	0	30.20	1275
15.25	100.3	61.0	1464	9.29	827	849	20.0	3.60	9512	66.2	0	29.49	1315
16.25	99.0	60.2	1445	9.08	819	841	20.0	3.60	9512	65.3	0	29.17	1380
17.25	99.9	60.7	1458	8.83	789	811	20.0	3.60	9512	65.9	0	28.16	1375
18.25	99.5	60.5	1453	9.05	812	834	20.0	3.60	9512	65.7	0	28.89	1280
19.25	99.3	60.3	1449	9.29	835	858	20.0	3.60	9512	65.5	0	29.72	1110
20.25	99.7	60.6	1455	9.54	854	877	20.0	3.60	9512	65.8	0	30.49	1090
21.25	100.3	61.0	1464	9.90	882	906	20.0	3.60	9509	66.2	0	31.40	1150
22.25	100.1	60.8	1461	9.54	850	874	20.0	3.60	9512	66.1	0	30.35	1250
23.25	99.4	60.4	1451	8.53	766	787	20.0	3.60	9512	65.6	0	27.02	1380
0.25	100.9	61.3	1472	9.07	803	825	20.0	3.60	9512	66.6	0	28.52	1405
1.25	100.0	60.8	1460	8.86	791	813	20.0	3.60	9509	66.0	0	28.19	1360
2.25	100.1	60.9	1461	8.97	800	822	20.0	3.60	9509	66.1	0	28.59	1360
3.25	99.7	60.6	1455	9.04	810	832	20.0	3.60	9512	65.8	0	28.74	1305
4.25	100.2	60.9	1463	8.97	799	821	20.0	3.60	9512	66.1	0	28.43	1270
5.25	100.7	61.2	1470	8.81	781	802	20.0	3.60	9512	66.5	0	27.93	1300
6.25	99.9	60.7	1458	8.83	789	811	20.0	3.60	9512	65.9	0	28.15	1305
7.25	99.6	60.5	1453	9.09	815	837	20.0	3.60	9512	65.7	0	29.02	1310

0.00 - 7.30

MAX	101.5	61.7	1482.	9.20	832.	855.	20.0	3.60	9512.	67.0	0.	29.60	1405.
MIN	98.2	59.6	1430.	8.64	767.	788.	20.0	3.60	9509.	64.7	0.	27.29	1270.
MEAN	99.6	60.6	1454.	8.94	801.	823.	20.0	3.60	9511.	65.8	0.	28.50	1325. 7.51
ACCH	747.6	454.5		67.06	801.	823.	20.0	3.60			0.	28.50	1324. 209.0

0.00 - 0.00

MAX	108.6	66.0	1585.	10.22	923.	948.	20.0	3.80	9576.	71.7	0.	32.84	1420.
MIN	97.6	59.3	1424.	3.90	340.	350.	19.5	3.60	9509.	64.4	0.	12.11	1090.
MEAN	99.7	60.6	1455.	9.26	830.	851.	19.8	3.70	9532.	65.8	0.	29.58	1262. 24.02
ACCH	2392.5	1454.6		222.27	830.	851.	19.8	3.70			0.	29.59	1254. 201.6

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-O-IG
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HD10F1		KM2F1		BF		KF-MS		KF-LOI		KLO	CL-LS		KCONTRL			
	PROD		KCAL	T/H	KC/KG	T/H	T/H	T/H	T/H	T/H		T/H	T/H	T/H	T/H	T/H	T/H
	T/H	T/H															
7.26	99.2	60.3	9.01	811	116.1	0.940	2.800	62.9	34.9	1310	237	0.24	0.920	3.070			
8.26	99.0	60.3	9.21	826	116.1	0.940	2.800	62.9	34.9	1305	248	0.24	0.920	3.070			
9.26	99.3	60.4	9.14	821	116.1	0.940	2.800	62.9	34.9	1305	234	0.24	0.920	3.070			
10.26	99.5	60.5	8.83	792	116.1	0.940	2.800	62.9	34.9	1320	253	0.24	0.920	3.070			
11.26	99.9	60.7	8.91	796	116.1	0.940	2.800	62.9	34.9	1360	248	0.24	0.920	3.070			
12.26	99.8	60.7	9.05	810	115.0	0.920	2.940	57.7	34.9	1310	236	0.24	0.940	3.070			
13.26	100.2	60.9	8.98	800	115.0	0.920	2.940	57.7	34.9	1300	253	0.24	0.940	3.070			
14.26	99.0	60.1	8.78	792	115.0	0.920	2.940	57.7	34.9	1355	245	0.24	0.940	3.070			
15.26	100.2	60.9	8.75	779	121.0	0.980	2.870	73.1	34.9	1350	247	0.24	0.940	3.070			
16.26	95.4	58.0	8.78	822	121.0	0.980	2.870	73.1	34.9	1230	229	0.24	0.940	3.070			
17.26	99.4	60.4	8.86	796	121.0	0.980	2.870	73.1	34.9	1340	238	0.24	0.940	3.070			
18.26	99.6	60.5	8.96	804	121.0	0.980	2.870	73.1	34.9	1230	279	0.24	0.940	3.070			
19.26	96.9	58.9	8.97	827	121.0	0.980	2.870	73.1	34.9	1210	270	0.24	0.940	3.070			
20.26	97.7	59.4	8.97	820	121.0	0.980	2.870	73.1	34.9	1190	262	0.24	0.940	3.070			
21.26	97.3	59.1	8.95	822	121.0	0.980	2.870	73.1	34.9	1280	244	0.24	0.940	3.070			
22.26	99.7	60.6	8.94	801	121.0	0.980	2.870	73.1	34.9	1330	232	0.24	0.940	3.070			
23.26	99.3	60.4	8.88	799	121.0	0.980	2.870	73.1	34.9	1335	233	0.24	0.940	3.070			
0.25	99.2	60.3	8.51	766	112.2	0.910	2.720	55.4	34.9	1335	243	0.24	0.940	3.070			
1.25	100.0	60.8	8.84	789	112.2	0.910	2.720	55.4	34.9	1300	255	0.24	0.940	3.070			
2.25	100.1	60.8	8.96	800	112.2	0.910	2.720	55.4	34.9	1165	234	0.24	0.940	3.070			
3.25	98.7	60.0	9.23	835	112.2	0.910	2.720	55.4	34.9	1220	235	0.24	0.940	3.070			
4.25	100.5	61.1	9.45	840	112.2	0.910	2.720	55.4	34.9	1235	225	0.24	0.940	3.070			
5.25	100.1	60.8	9.11	813	112.2	0.910	2.720	55.4	34.9	1300	217	0.24	0.940	3.070			
6.25	99.6	60.6	8.84	793	112.2	0.910	2.720	55.4	34.9	1330	221	0.24	0.940	3.070			
7.25	100.1	60.8	8.99	802	112.2	0.910	2.720	55.4	34.9	1305	227	0.24	0.940	3.070			

0.00 - 7.26

MAX	101.2	61.6	9.50	860	112.2	0.910	2.720	55.4	35.0	1335	270	0.24	0.940	3.070		
MIN	97.8	59.4	8.40	755	112.2	0.910	2.720	55.4	35.0	1165	193	0.24	0.940	3.070		
MEAN	99.6	60.6	9.02	809	112.2	0.910	2.720	55.4	35.0	1271	234	0.24	0.940	3.070	7.44	7.44
ACCH	740.7	450.3	67.86	809	112.2	0.910	2.720	55.4	35.0	1266	234	0.24	0.940	3.070	179.1	231.7

0.00 - 0.00

MAX	103.8	63.1	9.35	870	121.0	0.980	2.940	73.2	35.0	1405	301	0.24	0.940	3.070		
MIN	92.3	56.1	8.61	766	112.2	0.910	2.720	55.4	34.9	1190	186	0.24	0.920	3.070		
MEAN	99.1	60.3	8.95	806	118.7	0.957	2.880	67.5	35.0	1307	242	0.24	0.930	3.070	11.28	23.83
ACCH	2281.0	1386.9	205.86	806	118.3	0.954	2.875	66.7	35.0	1387	242	0.24	0.931	3.070	171.7	224.3

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ Z02 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCD EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.26	1.9	33.6	115	3.84	804	199	780	313	624	391	384	397	610	-0.01	856	
8.26	1.8	34.5	117	3.35	804	194	781	314	626	391	385	398	610	-0.01	855	
9.26	1.8	37.6	112	2.91	806	200	777	316	618	389	383	397	610	0.00	861	
10.26	1.8	37.8	129	3.25	803	211	776	326	615	385	388	367	610	0.00	863	
11.26	1.8	35.9	154	3.66	804	236	786	361	635	396	388	369	656	0.00	863	
12.26	1.8	36.9	135	3.51	803	219	782	356	624	394	385	373	623	0.00	866	
13.26	1.8	37.5	143	2.98	803	230	782	343	628	388	381	395	620	0.00	864	
14.26	1.8	37.9	138	3.26	802	221	784	368	622	393	381	397	637	0.02	879	
15.26	1.8	34.9	110	4.40	802	220	784	324	631	394	384	397	634	0.01	878	
16.26	1.8	35.1	160	3.02	804	259	792	378	638	400	391	405	642	0.00	883	
17.26	1.8	41.0	117	3.76	803	211	786	344	628	397	388	399	640	0.02	879	
18.26	1.8	34.5	145	2.98	804	225	784	364	634	395	383	401	643	0.01	878	
19.26	1.8	39.1	156	2.50	802	245	785	368	634	399	389	404	647	0.00	881	
20.26	1.8	37.6	135	2.90	805	222	785	348	630	398	390	402	639	0.00	880	
21.26	1.8	37.0	138	3.10	806	217	787	356	638	404	394	407	650	-0.02	878	
22.26	1.8	38.2	118	4.20	804	289	786	331	637	406	398	412	641	0.00	879	
23.26	1.8	38.7	109	3.73	804	200	782	310	631	400	394	407	618	0.00	871	
0.25	1.8	37.1	110	4.54	802	173	783	311	624	398	390	403	606	-0.02	869	
1.25	1.8	33.4	92	3.87	804	174	777	284	619	394	389	400	577	0.00	844	
2.25	1.9	33.5	89	3.16	804	158	769	277	618	383	380	391	545	0.01	833	
3.25	1.8	33.1	87	3.68	804	185	777	281	620	394	387	396	580	0.00	843	
4.25	1.8	34.1	78	3.87	808	178	783	286	624	398	392	402	581	-0.01	833	
5.25	1.8	37.5	83	3.08	806	178	779	288	623	398	389	403	585	-0.02	840	
6.25	1.8	36.1	80	4.24	805	159	782	284	624	398	392	401	585	-0.02	839	
7.25	1.8	34.4	87	4.19	805	175	774	286	614	391	384	397	582	0.00	839	

0.00 - 7.27

MAX	1.9	38.7	119.	5.02	810.	219.	789.	322.	633.	403.	394.	407.	622.	0.03	872.
MIN	1.9	32.3	71.	2.37	793.	104.	768.	264.	608.	383.	376.	390.	536.	-0.05	827.
MEAN	1.9	35.2	87.	3.82	805.	169.	778.	286.	620.	394.	387.	399.	577.	-0.01	842.
ACCM	1.9	35.2	87.		805.	169.	778.	286.	620.	394.	387.	399.	577.	-0.01	842.

0.00 - 0.00

MAX	1.9	42.8	174.	4.63	809.	272.	795.	386.	646.	414.	407.	418.	671.	0.05	891.
MIN	1.9	29.9	87.	1.31	799.	162.	771.	294.	610.	383.	375.	359.	579.	-0.04	842.
MEAN	1.9	36.3	129.	3.31	804.	216.	784.	340.	628.	395.	386.	397.	627.	0.00	869.
ACCM	1.9	36.3	129.		804.	216.	784.	340.	628.	395.	386.	397.	627.	0.00	869.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME

W1/ NOX REG STIME

W1/ LTW FOR CONTRL

W1/ ESTIMATED LTW

U1/ LITER WEIGHT

KILN CON. MEASUR.

KILN CONTROL

COAL TO KILN

W1/ NOX CHANGE LT

W1/ T EXIT PREHEAT

W1/ A50T1 CHANGE

W1/ Z02 KILN OUTL

W1/ ZCO EX PREHEAT

W1/ COAL TO KILN

J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		LTWT	LTWTGSP	NOXLT	A50T1	OA15X1	OA1X2CO	OA2V1						
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM	
7.26				1310	1254	1257	39.6	39.1	-0.192	397	0.16	3.84	-0.01	9.01	856
8.26				1305	1273	1274	40.0	40.2	0.031	398	0.10	3.35	-0.01	9.21	855
9.26				1305	1286	1287	42.2	42.5	0.111	397	-0.13	2.91	0.00	9.14	861
10.26				1320	1313	1329	44.5	45.0	0.054	367	-3.28	3.25	0.00	8.93	863
11.26				1360	1264	1276	35.6	37.1	-0.131	369	0.75	3.66	0.00	8.91	863
12.26				1310	1280	1327	40.3	39.4	0.117	373	0.18	3.51	0.00	9.05	866
13.26				1300	1359	1345	47.7	47.9	0.212	395	0.20	2.98	0.00	8.98	864
14.26				1355	1370	1358	51.5	51.8	0.011	397	0.03	3.26	0.02	8.78	879
15.26				1350	1296	1311	37.3	36.7	-0.548	397	0.12	4.40	0.01	8.75	878
16.26				1230	1384	1352	52.9	54.8	0.936	405	0.29	3.02	0.00	8.70	883
17.26				1340	1281	1297	32.4	33.5	-1.071	399	-0.47	3.76	0.02	8.86	879
18.26				1230	1299	1291	40.9	38.6	0.428	401	-0.63	2.98	0.01	8.96	878
19.26				1210	1269	1297	34.8	33.6	-0.155	404	0.25	2.50	0.00	8.97	881
20.26				1190	1332	1314	44.6	44.0	0.297	402	0.01	2.90	0.00	8.97	880
21.26				1280	1335	1320	44.0	44.5	0.185	407	0.30	3.10	-0.02	8.95	878
22.26				1330	1317	1318	41.0	41.6	-0.116	412	-0.30	4.20	0.00	8.94	879
23.26				1335	1311	1312	40.1	40.1	-0.046	407	-0.32	3.73	0.00	8.88	871
0.25				1335	1307	1308	38.3	39.4	-0.218	403	0.16	4.54	-0.02	8.51	869
1.25				1300	1254	1257	30.1	30.1	-0.240	400	-0.14	3.87	0.00	8.84	844
2.25				1165	1280	1272	34.1	35.0	0.076	391	-0.08	3.16	0.01	8.96	833
3.25				1220	1264	1263	34.6	34.5	-0.188	396	0.44	3.68	0.00	9.23	843
4.25				1235	1298	1287	41.3	40.9	0.308	402	0.26	3.07	-0.01	9.45	833
5.25				1300	1332	1306	44.7	46.3	0.009	403	-0.10	3.08	-0.02	9.11	840
6.25				1330	1324	1325	43.9	44.0	-0.076	401	-0.20	4.24	-0.02	8.84	839
7.25				1305	1253	1264	35.2	35.1	-0.163	397	0.15	4.19	0.00	8.99	839

0.00 - 7.28

MAX				1335.	1342.	1333.	48.0	47.8	0.427	407.	0.49	5.02	0.03	9.50	872.
MIN				1165.	1251.	1233.	29.9	30.1	-0.483	390.	-0.67	2.37	-0.05	8.40	827.
MEAN	7.48	7.48		1271.	1293.	1290.	38.7	38.7	-0.027	399.	-0.02	3.82	-0.01	9.02	842.
ACCH	231.7	179.1		1266.		1290.			-0.027	399.	-0.02		-0.01	67.45	842.

0.00 - 0.00

MAX				1405.	1435.	1433.	56.1	55.3	1.188	418.	3.76	4.63	0.05	9.35	891.
MIN				1190.	1251.	1254.	29.8	29.4	-1.098	359.	-3.78	1.31	-0.04	8.61	842.
MEAN	23.03	11.28		1307.	1311.	1300.	43.1	43.1	-0.033	397.	0.01	3.31	0.00	8.95	869.
ACCH	224.3	171.7		1307.		1308.			-0.033	397.	0.01		0.00	205.86	869.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL COAL HEAT VALUE
 Z MOISTURE IN COAL
 NET HEAT CONSUMP. SHORT TONS CLINKER
 HEAT CONSUMPTION LB COAL / SH. T
 W1/ COAL TO KILN MBTU' PER SH. T
 KILN PRODUC. RATE
 KILN PRODUCTION U1/ LITER WEIGHT
 W1/ KILN FEED COAL TO KILN

HOUR	HD10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		BTU		LTWT	
	PROD		KM2F1		NKCAL		C-ASH				LB.COAL		KM2F1#			
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z			T/H		GR/L	H		
7.26	99.2	60.3	1448	9.01	811	833	20.0	3.60	9512	65.5	0	28.88	1310			
8.26	99.0	60.3	1449	9.21	826	849	20.0	3.60	9512	65.5	0	29.51	1305			
9.26	99.3	60.4	1450	9.14	821	844	20.0	3.60	9512	65.5	0	29.22	1305			
10.26	99.5	60.5	1453	8.83	792	814	20.0	3.60	9512	65.7	0	28.33	1320			
11.26	99.9	60.7	1457	8.91	796	818	20.0	3.60	9512	65.9	0	28.35	1360			
12.26	99.8	60.7	1457	9.05	810	824	19.8	3.01	9605	65.9	0	29.15	1310			
13.26	100.2	60.9	1463	8.98	800	814	19.8	3.01	9605	66.1	0	28.72	1300			
14.26	99.0	60.1	1444	8.78	792	806	19.8	3.01	9605	65.3	0	28.51	1355			
15.26	100.2	60.9	1463	8.75	779	793	19.8	3.01	9605	66.1	0	28.04	1350			
16.26	95.4	58.0	1392	8.78	822	836	19.8	3.01	9605	63.0	0	29.65	1230			
17.26	99.4	60.4	1450	8.86	796	810	19.8	3.01	9605	65.6	0	28.54	1340			
18.26	99.6	60.5	1453	8.96	804	818	19.8	3.01	9605	65.7	0	28.88	1230			
19.26	96.9	58.9	1414	8.97	827	841	19.8	3.01	9605	63.9	0	29.63	1210			
20.26	97.7	59.4	1426	8.97	820	834	19.8	3.01	9605	64.5	0	29.35	1190			
21.26	97.3	59.1	1419	8.95	822	836	19.8	3.01	9605	64.2	0	29.58	1280			
22.26	99.7	60.6	1454	8.94	801	815	19.8	3.01	9605	65.8	0	28.79	1330			
23.26	99.3	60.4	1449	8.88	799	813	19.8	3.01	9605	65.5	0	28.61	1335			
0.25	99.2	60.3	1448	8.51	766	780	19.8	3.01	9605	65.4	0	27.61	1335			
1.25	100.0	60.8	1460	8.84	789	803	19.8	3.01	9605	66.0	0	28.37	1300			
2.25	100.1	60.8	1461	8.96	800	814	19.8	3.01	9605	66.0	0	28.75	1165			
3.25	98.7	60.0	1440	9.23	835	850	19.8	3.01	9605	65.1	0	29.94	1220			
4.25	100.5	61.1	1467	9.45	840	854	19.8	3.01	9605	66.3	0	30.15	1235			
5.25	100.1	60.8	1460	9.11	813	827	19.8	3.01	9605	66.0	0	29.20	1300			
6.25	99.6	60.6	1454	8.84	793	806	19.8	3.01	9605	65.7	0	28.38	1330			
7.25	100.1	60.8	1461	8.99	802	816	19.8	3.01	9605	66.0	0	28.90	1305			

0.00 - 7.29

MAX	101.2	61.6	1477.	9.50	860.	875.	19.8	3.01	9605.	66.8	0.	30.88	1335.			
MIN	97.8	59.4	1426.	8.40	755.	760.	19.8	3.01	9602.	64.5	0.	27.12	1165.			
MEAN	99.6	60.6	1453.	9.02	809.	823.	19.8	3.01	9606.	65.7	0.	29.06	1272.	7.49		
ACCM	746.1	453.6		67.55	809.	823.	19.8	3.01			0.	29.06	1266.	231.7		

0.00 - 0.00

MAX	103.8	63.1	1515.	9.35	870.	885.	20.0	3.60	9605.	68.5	0.	31.25	1405.			
MIN	92.3	56.1	1346.	8.61	766.	779.	19.8	3.01	9509.	60.9	0.	27.29	1190.			
MEAN	99.1	60.3	1446.	8.95	806.	824.	19.9	3.29	9558.	65.4	0.	28.83	1307.	23.03		
ACCM	2281.0	1386.9		205.96	806.	825.	19.9	3.29			0.	28.82	1307.	224.3		

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1	KM2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL						
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KM2F1*						
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.25	100.2	60.9	8.89	792	112.2	0.910	2.720	55.4	34.9	1330	230	0.24	0.940	3.070
8.25	99.2	60.3	9.28	835	113.5	0.920	2.770	57.5	34.9	1240	234	0.24	0.940	3.070
9.25	99.9	60.7	8.96	801	113.5	0.920	2.770	57.5	34.9	1250	215	0.24	0.940	3.070
10.25	99.6	60.6	9.27	831	113.5	0.920	2.770	57.5	34.9	1315	252	0.24	0.940	3.070
11.25	101.7	61.8	8.85	776	113.5	0.920	2.770	57.5	34.9	1270	252	0.24	0.940	3.070
12.25	106.3	64.6	8.62	724	113.5	0.920	2.770	57.5	34.9	1360	254	0.24	0.940	3.070
13.25	107.8	65.5	8.94	740	113.5	0.910	2.860	55.7	34.6	1340	300	0.24	0.940	3.010
14.25	107.4	65.3	9.27	771	113.5	0.910	2.860	55.7	34.6	1115	243	0.24	0.940	3.010
15.25	107.4	65.3	9.00	748	113.5	0.910	2.860	55.7	34.6	1125	221	0.24	0.940	3.010
16.25	107.4	65.3	8.96	745	108.7	0.890	2.570	52.1	34.6	1330	214	0.24	0.940	3.010
17.25	107.9	65.6	8.79	728	108.7	0.890	2.570	52.1	34.6	1365	222	0.24	0.940	3.010
18.25	109.4	66.5	8.70	710	108.7	0.890	2.570	52.1	34.6	1365	261	0.24	0.940	3.010
19.25	109.2	66.4	9.04	739	108.7	0.890	2.570	52.1	34.6	1175	234	0.24	0.940	3.010
20.25	109.3	66.4	9.27	757	108.7	0.890	2.570	52.1	34.6	1115	206	0.24	0.940	3.010
21.25	109.2	66.4	9.48	775	108.7	0.890	2.570	52.1	34.6	1160	228	0.24	0.940	3.010
22.25	109.4	66.5	9.07	740	108.7	0.890	2.570	52.1	34.6	1280	238	0.24	0.940	3.010
23.25	109.6	66.6	8.87	723	108.7	0.890	2.570	52.1	34.6	1325	251	0.24	0.940	3.010
0.25	110.5	67.1	9.12	737	108.7	0.890	2.570	52.1	34.6	1255	294	0.24	0.940	3.010
1.25	109.9	66.8	9.50	772	108.7	0.890	2.570	52.1	34.6	1080	240	0.24	0.940	3.010
2.25	108.9	66.2	9.50	778	108.7	0.890	2.570	52.1	34.6	1100	212	0.24	0.940	3.010
3.25	105.4	64.1	9.68	820	115.4	0.960	2.450	69.9	34.6	1195	261	0.24	0.940	3.010
4.25	110.4	67.1	9.66	781	115.4	0.960	2.450	69.9	34.6	1180	244	0.24	0.940	3.010
5.25	109.5	66.6	9.44	769	115.4	0.960	2.450	69.9	34.6	1340	286	0.24	0.940	3.010
6.25	108.8	66.2	9.39	770	115.4	0.960	2.450	69.9	34.6	1275	309	0.24	0.940	3.010
7.25	110.4	67.1	9.43	762	115.4	0.960	2.450	69.9	34.6	1320	301	0.24	0.940	3.010

0.00 - 7.25																
MAX	111.3	67.7	9.97	832.	115.4	0.960	2.570	70.0	34.7	1340.	316.	0.24	0.940	3.010		
MIN	103.2	62.7	8.80	718.	108.7	0.890	2.450	52.1	34.7	1080.	203.	0.24	0.940	3.010		
MEAN	109.0	66.3	9.52	780.	112.5	0.930	2.501	62.4	34.7	1213.	264.	0.24	0.940	3.010	3.17	7.43
ACCH	810.2	492.6	70.72	780.	112.5	0.930	2.501	62.3	34.7	1204.	264.	0.24	0.940	3.010	196.1	255.4
0.00 - 0.00																
MAX	111.1	67.6	9.56	860.	113.5	0.920	2.860	57.6	35.0	1365.	311.	0.24	0.940	3.070		
MIN	97.8	59.4	8.40	696.	108.7	0.890	2.570	52.1	34.7	1115.	193.	0.24	0.940	3.010		
MEAN	104.3	63.4	9.03	775.	111.4	0.905	2.697	54.8	34.8	1262.	238.	0.24	0.940	3.041	21.48	24.02
ACCH	2502.7	1521.6	216.64	773.	111.3	0.905	2.692	54.7	34.8	1261.	238.	0.24	0.940	3.040	192.9	248.1

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	0A15A1		0A15X1		A54P1		A53P1		A51T1		A50T1				0A2V1	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	35.5	75	4.39	804	142	774	270	616	392	385	398	552	-0.02	839	
8.25	1.9	34.6	83	3.82	805	169	778	276	623	393	382	395	558	0.00	834	
9.25	1.8	37.5	85	4.46	806	187	781	297	618	388	382	391	588	-0.01	853	
10.25	1.8	38.9	91	3.63	807	161	779	298	621	390	383	393	578	0.00	846	
11.25	1.9	40.0	99	4.18	807	189	782	313	616	383	376	388	591	0.00	853	
12.25	1.9	39.3	113	3.87	804	209	772	333	613	375	367	380	620	0.00	865	
13.25	1.9	30.4	111	3.67	802	215	770	333	607	379	370	382	622	0.00	868	
14.25	1.9	30.2	109	1.82	804	202	770	328	601	367	361	374	614	0.01	872	
15.25	1.9	35.4	111	2.01	804	207	778	338	614	382	371	384	633	0.00	880	
16.25	1.9	36.7	129	3.20	807	234	783	361	620	389	378	391	665	0.01	882	
17.25	1.9	36.5	111	4.51	806	184	787	350	624	386	377	392	644	0.00	883	
18.25	1.9	31.1	123	5.20	806	220	790	355	623	389	377	390	669	0.00	882	
19.25	1.9	30.8	130	4.60	809	227	792	363	625	387	378	391	661	0.00	884	
20.25	1.9	33.1	120	4.17	808	225	789	355	630	385	376	391	652	0.00	874	
21.25	1.9	35.0	125	2.62	812	210	791	351	623	387	374	391	638	0.01	868	
22.25	1.9	36.7	134	3.99	813	219	790	354	628	391	384	396	649	0.03	891	
23.25	1.9	37.0	129	3.90	809	211	787	348	624	382	372	386	629	0.00	878	
0.25	1.9	30.6	141	2.68	804	219	780	347	609	376	366	380	636	0.00	881	
1.25	1.9	30.7	135	2.41	807	222	784	345	612	375	367	382	628	0.00	883	
2.25	1.9	33.9	136	2.38	811	208	788	340	619	379	370	384	620	0.00	883	
3.25	1.9	35.6	136	3.07	808	221	788	352	621	385	376	389	631	0.00	882	
4.25	1.9	37.6	136	2.38	811	217	793	360	627	385	376	389	651	0.00	892	
5.25	1.9	38.9	155	2.61	810	243	787	368	626	384	376	389	651	0.00	899	
6.25	1.9	38.3	146	3.39	809	242	782	357	618	387	377	393	649	-0.01	899	
7.25	1.9	34.9	158	1.58	813	248	785	360	626	393	382	396	656	0.02	900	

0.00 - 7.27

MAX	2.0	41.3	167.	5.49	816.	266.	799.	397.	634.	394.	385.	398.	707.	0.05	907.
MIN	2.0	29.6	97.	1.21	802.	174.	772.	315.	604.	371.	362.	378.	615.	-0.03	874.
MEAN	2.0	35.5	140.	2.86	810.	228.	785.	354.	620.	383.	374.	388.	643.	-0.00	890.
ACCN	2.0	35.5	140.		810.	228.	785.	354.	620.	383.	374.	388.	643.	-0.00	890.

0.00 - 0.00

MAX	2.0	40.8	146.	5.60	817.	251.	798.	373.	637.	403.	394.	407.	680.	0.05	891.
MIN	1.9	29.7	71.	0.49	793.	184.	761.	264.	595.	367.	360.	373.	536.	-0.05	827.
MEAN	1.9	35.4	104.	3.72	807.	192.	781.	319.	620.	387.	379.	392.	610.	-0.00	861.
ACCN	1.9	35.4	104.		807.	192.	781.	319.	620.	387.	379.	392.	610.	-0.00	861.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ 202 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ %CO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KN2F1*			KALARM			ESTLTW			NOXST			NOXALT			A50ALT			KN2F1					
	KCONTRL			LTWT			LTWGTSP			NOXLT			A50T1			OA15X1			OA1X2CO			OA2V1		
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM									
7.25				1330	1264	1277	35.0	35.6	-0.483	398	-0.12	4.39				-0.02	8.89	839						
8.25				1240	1288	1275	42.2	39.8	0.183	395	0.06	3.82				0.00	9.28	834						
9.25				1250	1255	1254	37.0	36.7	-0.359	391	0.12	4.46				-0.01	8.96	853						
10.25				1315	1236	1305	32.2	30.5	-0.156	393	0.11	3.63				0.00	9.27	846						
11.25				1270	1268	1292	37.4	36.9	-0.019	388	-0.12	4.18				0.00	8.85	853						
12.25				1360	1292	1358	37.7	38.5	0.353	380	-0.50	3.87				0.00	8.62	865						
13.25				1340	1112	1271	15.3	13.0	-0.654	382	0.07	3.67				0.00	8.94	868						
14.25				1115	1126	1170	13.9	13.8	-0.030	374	-0.33	1.82				0.01	9.27	872						
15.25				1125	1122	1192	13.3	13.3	-0.023	384	0.02	2.01				0.00	9.00	880						
16.25				1330	1330	1324	36.4	41.5	1.216	391	0.10	3.20				0.01	8.96	882						
17.25				1365	1302	1333	29.8	30.5	-0.359	392	0.27	4.51				0.00	8.79	883						
18.25				1365	1242	1283	17.0	17.1	-0.566	390	0.15	5.20				0.00	8.70	882						
19.25				1175	1213	1184	14.9	14.6	0.001	391	0.08	4.60				0.00	9.04	884						
20.25				1115	1218	1117	19.4	18.9	0.111	391	-0.17	4.17				0.00	9.27	874						
21.25				1160	1275	1247	27.8	27.8	0.402	391	-0.06	2.62				0.01	9.48	868						
22.25				1280	1340	1283	36.2	36.7	0.109	396	0.51	3.99				0.03	9.07	881						
23.25				1325	1330	1329	34.8	34.7	0.039	386	-0.39	3.90				0.00	8.87	878						
0.25				1255	1215	1225	18.0	18.2	-0.516	380	-0.09	2.68				0.00	9.12	881						
1.25				1080	1214	1194	18.3	18.0	0.001	382	-0.44	2.41				0.00	9.50	883						
2.25				1100	1218	1101	25.3	24.9	0.204	384	0.06	2.38				0.00	9.51	883						
3.25				1195	1249	1241	28.1	28.2	-0.309	389	0.35	3.07				0.00	9.68	882						
4.25				1180	1374	1303	37.5	39.8	0.535	389	0.15	2.38				0.00	9.66	892						
5.25				1340	1331	1290	36.4	35.8	0.018	389	-0.03	2.61				0.00	9.44	899						
6.25				1275	1296	1293	35.8	35.9	0.090	393	-0.10	3.39				-0.01	9.39	899						
7.25				1320	1228	1240	28.0	28.0	-0.444	396	0.68	1.58				0.02	9.43	900						

0.00 - 7.28			0.00 - 0.00														
MAX			1340.	1380.	1331.	39.8	40.3	0.586	398.	0.05	5.49				0.05	9.97	907.
MIN			1080.	1201.	1102.	17.1	16.0	-0.614	378.	-0.75	1.21				-0.03	8.80	874.
MEAN	7.48	3.17	1213.	1276.	1246.	29.3	29.3	0.012	388.	0.05	2.86				-0.00	9.52	890.
ACCM	255.5	196.1	1204.		1246.			0.012	388.	0.05					-0.00	71.13	890.
MAX			1365.	1348.	1358.	48.0	47.8	1.602	407.	1.08	5.60				0.05	9.56	891.
MIN			1115.	1111.	1117.	12.9	12.8	-0.988	373.	-0.88	0.49				-0.05	8.40	827.
MEAN	24.02	21.48	1262.	1261.	1270.	31.1	31.1	-0.019	392.	-0.03	3.72				-0.00	9.03	861.
ACCM	248.1	192.9	1261.		1270.			-0.019	392.	-0.03					-0.00	216.64	861.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH.T
W1/ COAL TO KILN	MBTU' PER SH.T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT	STONS		BTU	LTWT
	PROD		KM2F1		NKKAL		C-ASH			LB.COAL			KM2F1*
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%		T/H		GR/L	H
7.25	100.2	60.9	1462	8.89	792	806	19.8	3.01	9605	66.1	0	28.42	1330
8.25	99.2	60.3	1448	9.28	835	849	19.8	3.01	9605	65.5	0	29.83	1240
9.25	99.9	60.7	1458	8.96	801	815	19.8	3.01	9605	65.9	0	28.71	1250
10.25	99.6	60.6	1454	9.27	831	845	19.8	3.01	9605	65.7	0	30.02	1315
11.25	101.7	61.8	1485	8.85	776	790	19.8	3.01	9605	67.1	0	27.99	1270
12.25	106.3	64.6	1552	8.62	724	736	19.8	3.01	9605	70.2	0	26.23	1360
13.25	107.8	65.5	1574	8.94	740	755	20.0	2.97	9584	71.2	0	26.55	1340
14.25	107.4	65.3	1567	9.27	771	786	20.0	2.97	9584	70.9	0	27.71	1115
15.25	107.4	65.3	1568	9.00	748	763	20.0	2.97	9581	70.9	0	26.71	1125
16.25	107.4	65.3	1567	8.96	745	760	20.0	2.97	9584	70.8	0	26.76	1330
17.25	107.9	65.6	1574	8.79	728	742	20.0	2.97	9584	71.2	0	26.34	1365
18.25	109.4	66.5	1596	8.70	710	724	20.0	2.97	9584	72.2	0	25.50	1365
19.25	109.2	66.4	1593	9.04	739	754	20.0	2.97	9584	72.0	0	26.58	1175
20.25	109.3	66.4	1595	9.27	757	772	20.0	2.97	9584	72.1	0	27.11	1115
21.25	109.2	66.4	1593	9.48	775	790	20.0	2.97	9584	72.0	0	27.74	1160
22.25	109.4	66.5	1596	9.07	740	755	20.0	2.97	9584	72.2	0	26.58	1280
23.25	109.6	66.6	1599	8.87	723	737	20.0	2.97	9584	72.3	0	25.92	1325
0.25	110.5	67.1	1612	9.12	737	752	20.0	2.97	9584	72.9	0	26.49	1255
1.25	109.9	66.8	1604	9.50	772	787	20.0	2.97	9584	72.5	0	27.61	1080
2.25	108.9	66.2	1589	9.50	778	794	20.0	2.97	9584	71.9	0	27.94	1100
3.25	105.4	64.1	1539	9.68	820	836	20.0	2.97	9584	69.6	0	29.48	1195
4.25	110.4	67.1	1611	9.66	781	796	20.0	2.97	9584	72.8	0	28.24	1180
5.25	109.5	66.6	1599	9.44	769	784	20.0	2.97	9584	72.3	0	27.57	1340
6.25	108.8	66.2	1588	9.39	770	785	20.0	2.97	9584	71.8	0	27.52	1275
7.25	110.4	67.1	1611	9.43	762	778	20.0	2.97	9584	72.8	0	27.33	1320

0.00 - 7.29

MAX	111.3	67.7	1625.	9.97	832.	848.	20.0	2.97	9584.	73.5	0.	29.81	1340.
MIN	103.2	62.7	1505.	8.80	718.	733.	20.0	2.97	9584.	68.1	0.	25.71	1080.
MEAN	109.0	66.3	1591.	9.52	780.	795.	20.0	2.97	9584.	72.0	0.	27.95	1213. 7.49
ACCM	816.2	496.2		71.23	780.	795.	20.0	2.97			0.	27.95	1204. 255.5

0.00 - 0.00

MAX	111.1	67.6	1622.	9.56	860.	875.	20.0	3.01	9610.	73.4	0.	30.88	1365.
MIN	97.8	59.4	1426.	8.40	696.	709.	19.8	2.97	9581.	64.5	0.	24.93	1115.
MEAN	104.3	63.4	1522.	9.03	775.	789.	19.9	2.99	9599.	68.8	0.	27.80	1262. 24.02
ACCM	2502.7	1521.6		216.64	773.	789.	19.9	2.99			0.	27.81	1261. 248.1

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-O-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI		KLD	CL-LS		KCONTRL	
	PROD		T/H	KC/KG		KF-LS	C3S	LTWT	FCAD		CL-MS	KM2F1*	H	H
	T/H	T/H	T/H	KC/KG		Z	Z	GR/L	DEG.C	Z		H	H	
7.25	109.4	66.5	9.42	769	115.4	0.960	2.450	69.9	34.6	1275	293	0.24	0.940	3.010
8.25	110.5	67.2	9.36	756	108.5	0.900	2.380	55.0	34.6	1270	305	0.24	0.940	3.010
9.25	109.5	66.6	8.53	695	108.5	0.900	2.380	55.0	34.6	1540	303	0.24	0.940	3.010
10.25	110.3	67.0	8.57	693	108.5	0.900	2.380	55.0	34.6	1540	302	0.24	0.940	3.010
11.25	109.9	66.8	8.45	686	108.5	0.900	2.380	55.0	34.6	1350	244	0.24	0.940	3.010
12.25	109.6	66.6	8.41	685	108.5	0.900	2.380	55.0	34.6	1290	246	0.24	0.940	3.010
13.25	110.2	67.0	9.20	745	109.6	0.890	2.640	54.0	34.4	1290	239	0.24	0.910	2.680
14.25	105.1	63.9	9.33	793	109.6	0.890	2.640	54.0	34.4	1125	190	0.24	0.910	2.680
15.25	104.7	63.6	9.35	797	109.6	0.890	2.640	54.0	34.4	1185	229	0.24	0.910	2.680
16.25	109.8	66.7	9.35	761	106.2	0.860	2.530	46.9	34.4	1325	250	0.24	0.910	2.680
17.25	110.2	67.0	9.47	767	106.2	0.860	2.530	46.9	34.4	1455	246	0.24	0.910	2.680
18.25	109.2	66.4	9.43	771	106.2	0.860	2.530	46.9	34.4	1375	233	0.24	0.910	2.680
19.25	109.9	66.8	9.49	771	106.2	0.860	2.530	46.9	34.4	1330	233	0.24	0.910	2.680
20.25	109.6	66.6	9.23	752	106.2	0.860	2.530	46.9	34.4	1260	222	0.24	0.910	2.680
21.25	110.7	67.3	9.58	772	106.2	0.860	2.530	46.9	34.4	1240	216	0.24	0.910	2.680
22.25	104.2	63.3	9.66	828	106.2	0.860	2.530	46.9	34.4	1175	208	0.24	0.910	2.680
23.25	110.5	67.2	9.63	777	106.2	0.860	2.530	46.9	34.4	1305	241	0.24	0.910	2.680
0.25	109.6	66.6	9.67	788	106.6	0.880	2.480	49.0	34.4	1335	258	0.24	0.910	2.680
1.25	110.1	66.9	9.70	787	106.6	0.880	2.480	49.0	34.4	1270	242	0.24	0.910	2.680
2.25	110.9	67.4	9.77	787	106.6	0.880	2.480	49.0	34.4	1275	246	0.24	0.910	2.680
3.25	110.3	67.0	9.69	785	106.6	0.880	2.480	49.0	34.4	1180	234	0.24	0.910	2.680
4.25	110.3	67.1	9.73	787	106.6	0.880	2.480	49.0	34.4	1230	271	0.24	0.910	2.680
5.25	109.7	66.7	9.81	798	106.6	0.880	2.480	49.0	34.4	1240	250	0.24	0.910	2.680
6.25	109.6	66.6	9.58	780	106.6	0.880	2.480	49.0	34.4	1310	249	0.24	0.910	2.680
7.25	110.3	67.0	9.45	765	106.6	0.880	2.480	49.0	34.4	1350	248	0.24	0.910	2.680
0.00 - 7.25														
MAX	111.4	67.7	10.03	814.	106.6	0.880	2.480	49.0	34.5	1350.	283.	0.24	0.910	2.680
MIN	108.5	66.0	9.38	761.	106.6	0.880	2.480	49.0	34.5	1180.	209.	0.24	0.910	2.680
MEAN	110.0	66.9	9.71	788.	106.6	0.880	2.480	49.0	34.5	1265.	249.	0.24	0.910	2.680 6.02 7.43
ACCH	817.7	497.1	72.13	788.	106.6	0.880	2.480	49.0	34.5	1263.	249.	0.24	0.910	2.680 204.7 279.1
0.00 - 0.00														
MAX	111.8	67.9	9.97	863.	115.4	0.960	2.640	70.0	34.7	1540.	323.	0.24	0.940	3.010
MIN	100.2	60.9	8.33	673.	106.2	0.860	2.380	46.9	34.5	1080.	183.	0.24	0.910	2.680
MEAN	109.0	66.3	9.30	762.	109.1	0.895	2.497	54.6	34.6	1283.	252.	0.24	0.927	2.860 5.90 24.02
ACCH	2616.6	1590.9	223.14	762.	108.9	0.894	2.491	54.1	34.6	1290.	252.	0.24	0.926	2.859 198.8 271.8

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ ZD2 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN
W1/ KILN TORQUE	W1/ ZCD EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	DA15V1		DA15P1		A54T1		A53T1		A52T1		A61T1		A50P1		DA1X2CD	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.25	1.9	37.0	136	3.83	807	242	783	357	621	384	375	389	652	-0.01	981	
8.25	1.9	31.1	143	3.30	809	221	777	346	611	376	368	383	626	-0.01	882	
9.25	1.9	29.3	137	3.56	807	217	780	347	617	379	368	383	634	-0.01	879	
10.25	1.9	23.1	142	3.48	807	240	781	351	615	379	369	383	651	-0.01	878	
11.25	1.9	21.8	133	3.83	805	222	776	347	615	382	373	386	636	0.00	879	
12.25	1.9	18.7	133	4.15	805	216	781	350	615	384	373	388	639	0.00	876	
13.25	1.9	18.2	134	3.75	806	222	781	345	616	378	372	384	631	-0.01	882	
14.25	1.8	23.0	127	3.66	807	213	780	336	620	387	379	390	613	0.00	880	
15.25	1.8	27.1	135	3.39	806	238	785	340	626	391	379	394	617	0.00	878	
16.25	1.9	24.5	128	2.96	808	212	781	344	608	377	368	384	631	0.00	883	
17.25	1.9	19.6	134	2.88	805	219	778	339	611	376	367	381	626	0.00	874	
18.25	1.9	19.0	137	3.96	811	221	786	354	620	381	373	387	653	0.01	880	
19.25	1.9	18.7	134	3.50	810	224	787	349	617	383	376	388	645	0.01	881	
20.25	1.9	20.3	122	4.19	809	215	780	337	615	380	373	387	631	0.00	882	
21.25	1.9	22.2	121	3.75	809	223	787	352	618	381	373	387	648	0.00	873	
22.25	1.9	25.7	134	3.55	810	219	792	351	629	393	383	396	631	0.00	872	
23.25	2.0	26.9	139	3.39	811	223	789	350	623	384	377	393	645	0.00	872	
0.25	2.0	25.9	149	2.49	809	230	784	355	614	379	372	395	643	0.00	872	
1.25	1.9	23.3	148	2.94	809	237	784	384	619	383	372	386	669	-0.01	879	
2.25	2.0	23.9	144	2.67	808	240	785	358	617	382	370	388	662	0.00	876	
3.25	1.9	28.3	146	2.93	808	239	786	370	616	384	375	388	672	0.00	881	
4.25	1.9	26.0	150	2.88	808	251	783	375	617	385	374	390	675	-0.01	881	
5.25	1.9	23.6	148	3.52	807	237	783	365	619	386	378	391	676	-0.01	881	
6.25	1.9	23.3	147	3.66	810	244	786	370	627	388	379	393	679	0.00	882	
7.25	1.9	19.3	146	4.00	806	228	782	359	622	387	377	393	664	-0.01	869	

0.00 - 7.27

MAX	2.0	29.3	162.	4.32	814.	260.	793.	400.	631.	394.	386.	396.	693.	0.02	892.
MIN	2.0	19.3	112.	1.94	805.	202.	772.	345.	607.	376.	366.	382.	638.	-0.05	864.
MEAN	2.0	24.5	146.	3.19	808.	235.	784.	368.	620.	385.	375.	390.	671.	-0.01	880.
ACCM	2.0	24.5	146.		808.	235.	784.	368.	620.	385.	375.	390.	671.	-0.01	880.

0.00 - 0.00

MAX	2.0	41.3	178.	5.49	816.	274.	799.	397.	638.	399.	390.	402.	707.	0.07	911.
MIN	1.9	17.8	97.	0.89	801.	174.	770.	315.	603.	371.	362.	378.	607.	-0.04	866.
MEAN	2.0	27.2	136.	3.27	809.	224.	784.	350.	618.	383.	374.	388.	637.	-0.00	883.
ACCM	2.0	27.2	136.		809.	224.	784.	350.	618.	383.	374.	388.	637.	-0.00	883.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CNTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ 202 KILN OUTL
U1/ LITER WEIGHT	W1/ ZCO EX PREHEAT
KILN CON. MEASUR.	W1/ COAL TO KILN
KILN CONTROL	J1/ ID FAN SPEED
COAL TO KILN	

HOUR	KN2F1*		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KN2F1							
	KCONTRL	LTWT	LTWGTSP	NOXLT	A50T1	OA15X1	OA1X2CO	OA2V1	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	T/H
7.25			1275	1283	1282	34.8	34.4	-0.057	389	-0.33	3.83	-0.01	9.42	981						
8.25			1270	1383	1288	34.9	43.2	0.923	383	-0.83	3.30	-0.01	9.36	882						
9.25			1540	1440	1304	38.9	41.6	0.828	383	-0.12	3.56	-0.01	8.53	879						
10.25			1540	1383	1241	32.2	32.7	-0.847	383	0.47	3.48	-0.01	8.57	878						
11.25			1350	1231	1325	27.4	28.1	-0.219	386	0.09	3.83	0.00	8.45	879						
12.25			1290	1273	1289	26.2	26.9	-0.837	388	0.16	4.15	0.00	8.41	876						
13.25			1290	1124	1284	15.5	16.6	-0.559	384	0.41	3.75	-0.01	9.20	882						
14.25			1125	1241	1230	21.8	21.3	0.244	390	0.66	3.66	0.00	9.33	880						
15.25			1185	1373	1312	35.6	35.7	0.356	394	0.13	3.39	0.00	9.35	878						
16.25			1325	1406	1376	39.9	42.2	-0.896	384	-0.16	2.96	0.00	9.35	883						
17.25			1455	1375	1301	38.2	38.6	0.881	381	0.88	2.88	0.00	9.47	874						
18.25			1375	1332	1347	33.9	33.4	-0.152	387	0.12	3.96	0.01	9.43	880						
19.25			1330	1274	1286	27.8	27.1	-0.113	388	0.18	3.50	0.01	9.49	881						
20.25			1260	1267	1265	26.6	27.3	-0.139	387	0.09	4.19	0.00	9.23	882						
21.25			1240	1212	1219	20.9	19.9	-0.066	387	-0.18	3.75	0.00	9.58	873						
22.25			1175	1275	1251	30.1	29.5	0.687	396	0.14	3.55	0.00	9.66	872						
23.25			1305	1352	1343	39.8	39.3	0.237	393	-0.41	3.39	0.00	9.63	872						
0.25			1335	1301	1303	34.4	33.7	-0.131	395	-0.46	2.49	0.00	9.67	872						
1.25			1270	1277	1276	30.5	30.7	-0.082	386	0.12	2.94	-0.01	9.70	879						
2.25			1275	1235	1250	23.7	24.1	-0.346	388	-0.84	2.67	0.00	9.77	876						
3.25			1180	1270	1294	27.1	28.8	0.181	388	0.88	2.93	0.00	9.69	891						
4.25			1230	1266	1265	28.5	28.9	0.812	390	0.85	2.88	-0.01	9.73	881						
5.25			1240	1294	1290	33.7	33.6	0.261	391	0.83	3.52	-0.01	9.81	881						
6.25			1310	1305	1386	35.0	34.6	-0.864	393	0.29	3.66	0.00	9.58	882						
7.25			1350	1272	1276	29.6	30.2	-0.187	393	-0.16	4.00	-0.01	9.45	869						

0.00 - 7.28															
MAX			1350.	1317.	1315.	37.3	36.8	0.329	396.	0.58	4.32	0.02	10.03	892.	
MIN			1180.	1218.	1223.	22.1	21.7	-0.384	382.	-0.56	1.94	-0.05	9.38	864.	
MEAN	7.48	6.86	1266.	1278.	1279.	30.5	30.5	-0.025	390.	0.03	3.20	-0.01	9.71	880.	
ACCM	279.2	204.7	1263.		1279.			-0.025	390.	0.03		-0.01	72.54	880.	
0.00 - 8.00															
MAX			1540.	1467.	1535.	47.6	46.3	1.212	402.	1.54	5.49	0.07	9.97	911.	
MIN			1080.	1087.	1102.	15.5	14.1	-0.671	378.	-1.25	0.89	-0.04	8.33	866.	
MEAN	24.02	5.90	1283.	1286.	1275.	30.1	30.1	0.012	388.	0.01	3.27	-0.00	9.30	883.	
ACCM	271.8	198.8	1290.		1275.			0.012	388.	0.01		-0.00	223.14	883.	

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	H010F1		PRODR		KCAL		C-MOIST		C-HEAT	STONS	BTU		LTWT
	PROD		KM2F1		MKCAL		C-ASH			LB. COAL			KM2F1*
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z		T/H	GR/L	H	
7.25	109.4	66.5	1597	9.42	769	784	20.0	2.97	9584	72.2	0	27.56	1275
8.25	110.5	67.2	1613	9.36	756	771	20.0	2.97	9584	72.9	0	27.16	1270
9.25	109.5	66.6	1598	8.53	695	789	20.0	2.97	9584	72.3	0	24.89	1540
10.25	110.3	67.0	1610	8.57	693	787	20.0	2.97	9584	72.8	0	24.91	1540
11.25	109.9	66.8	1604	8.45	686	780	20.0	2.97	9584	72.5	0	24.76	1350
12.25	109.6	66.6	1600	8.41	685	699	20.0	2.97	9581	72.3	0	24.65	1290
13.25	110.2	67.0	1608	9.20	745	757	19.5	3.21	9620	72.7	0	26.83	1290
14.25	105.1	63.9	1534	9.33	793	805	19.5	3.21	9617	69.4	0	28.58	1125
15.25	104.7	63.6	1528	9.35	797	810	19.5	3.21	9620	69.1	0	28.65	1185
16.25	109.8	66.7	1602	9.35	761	773	19.5	3.21	9620	72.4	0	27.33	1325
17.25	110.2	67.0	1608	9.47	767	780	19.5	3.21	9620	72.7	0	27.61	1455
18.25	109.2	66.4	1594	9.43	771	783	19.5	3.21	9620	72.1	0	27.73	1375
19.25	109.9	66.8	1604	9.49	771	783	19.5	3.21	9620	72.5	0	27.82	1330
20.25	109.6	66.6	1600	9.23	752	764	19.5	3.21	9620	72.3	0	26.85	1260
21.25	110.7	67.3	1616	9.58	772	784	19.5	3.21	9620	73.1	0	27.87	1240
22.25	104.2	63.3	1521	9.66	828	841	19.5	3.21	9620	68.8	0	29.96	1175
23.25	110.5	67.2	1613	9.63	777	790	19.5	3.21	9620	72.9	0	28.88	1385
0.25	109.6	66.6	1599	9.67	788	800	19.5	3.21	9620	72.3	0	28.24	1335
1.25	110.1	66.9	1607	9.70	787	799	19.5	3.21	9620	72.7	0	28.28	1270
2.25	110.9	67.4	1618	9.77	787	799	19.5	3.21	9620	73.1	0	28.36	1275
3.25	110.3	67.0	1609	9.69	785	797	19.5	3.21	9620	72.8	0	28.33	1180
4.25	110.3	67.1	1610	9.73	787	800	19.5	3.21	9620	72.8	0	28.15	1230
5.25	109.7	66.7	1601	9.81	798	811	19.5	3.21	9620	72.4	0	28.67	1240
6.25	109.6	66.6	1599	9.58	780	793	19.5	3.21	9620	72.3	0	28.11	1310
7.25	110.3	67.0	1609	9.45	765	778	19.5	3.21	9620	72.8	0	27.56	1350
0.00 - 7.29													
MAX	111.4	67.7	1626.	10.03	814.	827.	19.5	3.21	9621.	73.5	0.	29.29	1350.
MIN	108.5	66.0	1584.	9.38	761.	773.	19.5	3.21	9618.	71.6	0.	27.37	1180.
MEAN	110.0	66.9	1606.	9.71	788.	800.	19.5	3.21	9622.	72.6	0.	28.35	1266. 7.49
ACCH	823.6	580.8		72.64	788.	800.	19.5	3.21			0.	28.35	1263. 279.2
0.00 - 0.00													
MAX	111.8	67.9	1631.	9.97	863.	876.	20.0	3.21	9621.	73.8	0.	31.04	1540.
MIN	100.2	60.9	1462.	8.33	673.	687.	19.5	2.97	9554.	66.1	0.	24.14	1080.
MEAN	109.0	66.3	1591.	9.30	762.	776.	19.8	3.08	9602.	72.0	0.	27.37	1283. 24.02
ACCH	2616.6	1590.9		223.14	762.	776.	19.8	3.08			0.	27.37	1290. 271.8

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-O-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KM2F1		BF		KF-MS		KF-LOI		KLO	CL-LS		KCONTRL	
	PROD		KCAL		KF-LS		C3S		LTWT		FCAO	CL-MS		KM2F1*	
	T/H	T/H	T/H	KC/KG			%	%	GR/L	DEG.C	%	H	H		
7.25	110.5	67.2	9.51	768	106.6	0.880	2.480	49.0	34.4	1310	246	0.24	0.910	2.680	
8.25	109.9	66.8	9.39	762	106.6	0.880	2.480	49.0	34.4	1260	224	0.24	0.910	2.680	
9.25	109.1	66.3	9.56	782	105.7	0.880	2.380	49.0	34.4	1370	235	0.24	0.910	2.680	
10.25	109.6	66.6	9.42	767	105.7	0.880	2.380	49.0	34.4	1205	216	0.24	0.910	2.680	
11.25	105.1	63.9	9.55	811	105.7	0.880	2.380	49.0	34.4	1190	237	0.24	0.910	2.680	
12.25	104.1	63.3	9.52	816	105.7	0.880	2.380	49.0	34.4	1135	265	0.24	0.910	2.680	
13.25	110.1	66.9	9.49	769	105.7	0.880	2.380	49.0	34.4	1350	265	0.24	0.910	2.680	
14.25	110.3	67.1	9.31	753	107.3	0.890	2.400	52.5	34.3	1260	245	0.12	0.900	2.540	
15.25	103.8	63.1	9.52	819	107.3	0.890	2.400	52.5	34.3	1260	220	0.12	0.900	2.540	
16.25	103.9	63.2	9.30	798	107.3	0.890	2.400	52.5	34.3	1190	240	0.12	0.900	2.540	
17.25	106.1	64.5	9.00	757	108.9	0.900	2.450	55.9	34.3	1310	242	0.12	0.900	2.540	
18.25	106.6	64.8	8.71	730	108.9	0.900	2.450	55.9	34.3	1410	241	0.12	0.900	2.540	
19.25	104.5	63.5	8.94	763	108.9	0.900	2.450	55.9	34.3	1325	214	0.12	0.900	2.540	
20.25	104.3	63.4	8.83	756	108.9	0.900	2.450	55.9	34.3	1160	217	0.12	0.900	2.540	
21.25	102.9	62.6	9.09	788	108.9	0.900	2.450	55.9	34.3	1225	223	0.12	0.900	2.540	
22.25	103.5	62.9	8.87	765	108.9	0.900	2.450	55.9	34.3	1210	241	0.12	0.900	2.540	
23.25	104.9	63.8	9.01	766	108.9	0.900	2.450	55.9	34.3	1290	231	0.12	0.900	2.540	
0.25	104.3	63.4	9.18	786	108.6	0.900	2.450	54.8	34.3	1085	205	0.12	0.900	2.540	
1.25	95.6	58.1	8.84	825	108.6	0.900	2.450	54.8	34.3	1025	352	0.12	0.900	2.540	
2.25	--	--	--	--	108.6	0.900	2.450	54.8	34.3	1025	--	0.12	0.900	2.540	
3.25	--	--	--	--	108.6	0.900	2.450	54.8	34.3	1025	--	0.12	0.900	2.540	
4.25	--	--	--	--	108.6	0.900	2.450	54.8	34.3	1025	--	0.12	0.900	2.540	
5.25	--	--	--	--	108.6	0.900	2.450	54.8	34.3	1025	--	0.12	0.900	2.540	
6.25	37.5	22.8	4.53	1078	108.6	0.900	2.450	54.8	34.3	1025	79	0.12	0.900	2.540	
7.25	37.9	23.0	5.07	1196	108.6	0.900	2.450	54.8	34.3	1025	93	0.12	0.900	2.540	

0.00 - 7.25

MAX	105.9	64.4	9.36	6128.	108.6	0.900	2.450	54.8	34.3	1085.	510.	0.12	0.900	2.540	
MIN	-4.6	2.8	1.08	715.	108.6	0.900	2.450	54.8	34.3	1025.	11.	0.12	0.900	2.540	
MEAN	70.3	42.7	7.01	1049.	108.6	0.900	2.450	54.8	34.3	1033.	164.	0.12	0.900	2.540	0.98 3.04
ACCH	219.1	130.1	21.35	891.	108.6	0.900	2.450	54.8	34.3	1025.	164.	0.12	0.900	2.540	221.2 298.5

0.00 - 0.00

MAX	111.7	67.8	10.03	847.	108.9	0.900	2.480	55.9	34.5	1410.	283.	0.24	0.910	2.680	
MIN	100.1	61.0	8.64	715.	105.7	0.880	2.380	49.0	34.3	1085.	187.	0.12	0.900	2.540	
MEAN	107.6	65.4	9.37	778.	107.3	0.888	2.443	51.5	34.4	1264.	239.	0.19	0.906	2.620	21.77 24.01
ACCH	2583.6	1570.8	224.89	778.	107.3	0.888	2.443	51.7	34.4	1261.	239.	0.19	0.905	2.616	220.3 295.5

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ ZQ2 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCO EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	2.0	20.3	150	4.21	809	246	783	372	619	387	381	392	679	-0.01	884	
8.25	1.9	19.3	130	3.84	806	212	782	352	612	382	374	386	643	0.00	856	
9.25	1.9	18.3	144	3.37	807	231	783	361	620	381	373	388	654	-0.02	867	
10.25	1.9	26.7	144	3.62	806	238	782	362	616	384	373	388	664	-0.01	867	
11.25	1.8	24.8	144	2.44	806	232	783	345	622	384	376	389	622	0.00	838	
12.25	1.9	23.8	136	3.36	806	224	784	346	621	386	377	391	644	-0.02	854	
13.25	1.9	20.4	138	2.77	807	206	780	346	605	373	364	377	642	-0.01	867	
14.25	1.9	20.1	148	3.23	805	227	773	357	607	373	365	378	644	-0.01	883	
15.25	1.9	21.3	142	2.32	808	224	783	347	617	383	375	388	640	-0.02	873	
16.25	1.9	22.3	137	3.01	805	218	780	350	622	384	378	392	650	-0.02	887	
17.25	1.9	21.4	137	3.12	806	216	780	350	619	383	374	387	644	-0.02	876	
18.25	1.9	18.0	144	4.10	804	226	776	354	610	379	369	385	652	-0.02	881	
19.25	1.9	18.8	147	3.04	803	224	773	363	614	379	373	386	658	-0.02	882	
20.25	1.9	20.3	138	3.57	802	222	769	357	607	381	378	386	657	-0.04	881	
21.25	1.9	22.3	150	2.82	802	231	776	360	616	384	377	389	649	-0.03	890	
22.25	1.9	21.8	133	3.94	807	209	783	348	614	384	379	388	632	-0.03	885	
23.25	1.9	21.3	141	3.26	808	218	786	346	615	384	375	389	638	-0.02	878	
0.25	1.9	27.2	142	3.33	807	218	782	351	619	385	378	392	632	-0.01	880	
1.25	1.7	13.7	128	2.72	807	211	779	331	614	383	376	388	614	-0.03	882	
2.25	--	--	--	--	--	--	--	--	--	--	--	367	--	--	--	
3.25	--	--	--	--	--	--	--	--	--	--	--	348	--	--	--	
4.25	--	--	--	--	--	--	--	--	--	--	--	336	--	--	--	
5.25	--	--	--	--	--	--	--	--	--	--	--	325	--	--	--	
6.25	0.4	32.4	16	10.32	712	49	689	67	580	406	409	398	149	-0.01	495	
7.25	0.6	28.0	21	10.27	776	59	734	88	603	411	409	408	180	-0.03	533	

0.00 - 7.27

MAX	2.0	46.0	152.	10.43	818.	242.	795.	353.	631.	431.	429.	417.	640.	1.06	893.
MIN	0.0	0.1	-11.	0.65	588.	8.	602.	3.	532.	335.	347.	320.	41.	-0.20	445.
MEAN	1.3	28.8	75.	6.27	771.	133.	743.	205.	602.	393.	390.	365.	387.	-0.01	696.
ACCH	1.3	28.8	75.		771.	133.	743.	205.	602.	393.	390.	365.	387.	-0.01	696.

0.00 - 0.00

MAX	2.0	29.6	162.	4.39	814.	260.	794.	400.	631.	394.	386.	396.	693.	0.02	892.
MIN	1.9	16.6	112.	1.83	797.	183.	763.	324.	598.	367.	359.	375.	688.	-0.06	831.
MEAN	2.0	22.4	143.	3.20	807.	228.	781.	358.	617.	383.	374.	388.	654.	-0.02	876.
ACCH	2.0	22.4	143.		807.	228.	781.	358.	617.	383.	374.	388.	654.	-0.02	876.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME

W1/ NOX REG STIME

W1/ LTW FOR CONTRL

W1/ ESTIMATED LTW

U1/ LITER WEIGHT

KILN CON. MEASUR.

KILN CONTROL

COAL TO KILN

W1/ NOX CHANGE LT

W1/ T EXIT PREHEAT

W1/ A50T1 CHANGE

W1/ Z02 KILN OUTL

W1/ ZCO EX PREHEAT

W1/ COAL TO KILN

J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1	
	KCONTRL	LTWT	LTWT	LTWTGSP	NOXL	A50T1	OA15X1	OA1X2CO	OA2V1					
H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	T/H	RPM	
7.25			1310	1289	1290	32.7	32.7	-0.121	392	-0.02	4.21	-0.01	9.51	884
8.25			1260	1335	1321	33.6	35.7	0.529	386	-0.16	3.84	0.00	9.39	856
9.25			1370	1174	1259	22.0	21.2	-0.324	388	0.05	3.37	-0.02	9.56	867
10.25			1205	1174	1181	18.9	19.8	-0.047	388	0.04	3.62	-0.01	9.42	867
11.25			1190	1171	1174	21.1	18.2	0.195	389	-0.71	2.44	0.00	9.55	838
12.25			1135	1392	1351	37.5	38.1	0.443	391	0.44	3.36	-0.02	9.52	854
13.25			1350	1263	1277	26.9	26.5	-0.707	377	0.09	2.77	-0.01	9.49	867
14.25			1260	1276	1273	25.7	27.6	0.053	378	-0.83	3.23	-0.01	9.31	883
15.25			1260	1226	1237	24.5	23.1	0.141	388	0.08	2.32	-0.02	9.52	873
16.25			1190	1298	1281	30.5	29.6	0.164	392	0.03	3.01	-0.02	9.30	887
17.25			1310	1368	1359	35.4	36.0	0.296	387	0.00	3.12	-0.02	9.00	876
18.25			1410	1302	1352	27.9	28.8	-0.265	395	-0.40	4.10	-0.02	8.71	881
19.25			1325	1163	1249	17.7	16.5	-0.205	386	0.08	3.04	-0.02	8.94	882
20.25			1160	1227	1246	20.9	21.6	0.139	386	-0.20	3.57	-0.04	8.83	881
21.25			1225	1189	1241	20.8	18.2	0.001	389	0.27	2.82	-0.03	9.09	880
22.25			1210	1333	1292	28.6	29.3	0.122	388	0.03	3.94	-0.03	8.87	885
23.25			1290	1131	1149	15.1	14.0	-0.125	389	-0.07	3.26	-0.02	9.01	878
0.25			1085	1105	1103	11.5	13.4	-0.393	392	-0.10	3.33	-0.01	9.18	880
1.25			1025	1062	1059	8.3	11.5	-0.370	388	-0.24	2.72	-0.03	8.84	882
2.25			1025	820	991	-2.9	-3.2	-0.343	367	-1.93	--	--	--	--
3.25			1025	739	969	-8.1	-8.1	-0.119	348	-0.46	--	--	--	--
4.25			1025	722	965	-9.2	-9.2	-0.023	336	-0.47	--	--	--	--
5.25			1025	727	966	-8.9	-8.9	0.015	325	-0.41	--	--	--	--
6.25			1025	744	4880	-7.8	-7.9	0.037	398	3.51	10.32	-0.01	4.53	495
7.25			1025	765	1100	-6.5	-6.5	0.044	408	0.26	10.27	-0.03	5.07	533

0.00 - 7.28

MAX			1085.	1224.	5073.	21.0	21.3	0.385	417.	10.22	10.43	1.06	9.36	893.
MIN			1025.	722.	853.	-9.2	-9.3	-0.711	320.	-2.47	0.65	-0.20	1.08	445.
MEAN	3.09	0.98	1033.	838.	1172.	-2.4	-2.3	-0.107	365.	0.06	6.30	-0.01	6.98	694.
ACCH	298.6	221.2	1025.		1172.			-0.107	365.	0.06		-0.01	21.57	694.

0.00 - 0.00

MAX			1410.	1398.	1372.	30.3	30.7	0.783	396.	0.92	4.39	0.02	10.03	892.
MIN			1085.	1095.	1117.	13.0	11.4	-0.891	375.	-1.02	1.83	-0.06	8.64	831.
MEAN	24.01	21.77	1264.	1256.	1266.	26.7	26.7	-0.027	388.	-0.01	3.20	-0.02	9.37	876.
ACCH	295.5	220.3	1261.		1266.			-0.027	388.	-0.01		-0.02	224.89	876.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU/ PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT	STONS	BTU	LTWT	
	PROD		KM2F1		MKCAL		C-ASH			LB. COAL		KN2F1*	
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%		T/H		GR/L	H
7.25	110.5	67.2	1613	9.51	768	780	19.5	3.21	9620	72.9	0	27.71	1310
8.25	109.9	66.8	1604	9.39	762	775	19.5	3.21	9620	72.5	0	27.35	1260
9.25	109.1	66.3	1593	9.56	782	795	19.5	3.21	9617	72.0	0	28.02	1370
10.25	109.6	66.6	1600	9.42	767	779	19.5	3.21	9617	72.4	0	27.69	1205
11.25	105.1	63.9	1535	9.55	811	824	19.5	3.21	9620	69.4	0	29.34	1190
12.25	104.1	63.3	1519	9.52	816	830	19.5	3.21	9617	68.7	0	29.20	1135
13.25	110.1	66.9	1607	9.49	769	781	19.5	3.21	9620	72.7	0	27.62	1350
14.25	110.3	67.1	1610	9.31	753	773	20.0	3.54	9519	72.8	0	26.75	1260
15.25	103.8	63.1	1515	9.52	819	841	20.0	3.54	9519	68.5	0	29.05	1260
16.25	103.9	63.2	1517	9.30	798	820	20.0	3.54	9519	68.6	0	28.53	1190
17.25	106.1	64.5	1549	9.00	757	778	20.0	3.54	9519	70.0	0	26.96	1310
18.25	106.6	64.8	1555	8.71	730	749	20.0	3.54	9519	70.3	0	25.97	1410
19.25	104.5	63.5	1525	8.94	763	784	20.0	3.54	9519	69.0	0	27.24	1325
20.25	104.3	63.4	1523	8.83	756	776	20.0	3.54	9519	68.8	0	26.91	1160
21.25	102.9	62.6	1502	9.09	788	809	20.0	3.54	9519	67.9	0	28.07	1225
22.25	103.5	62.9	1510	8.87	765	786	20.0	3.54	9519	68.3	0	27.27	1210
23.25	104.9	63.8	1532	9.01	766	787	20.0	3.54	9519	69.2	0	27.30	1290
0.25	104.3	63.4	1522	9.18	786	807	20.0	3.54	9519	68.8	0	28.02	1095
1.25	95.6	58.1	1395	8.84	825	847	20.0	3.54	9519	63.1	0	28.41	1025
2.25	--	--	-72	--	--	--	20.0	3.54	9519	-3.2	--	--	1025
3.25	--	--	-72	--	--	--	20.0	3.54	9515	-3.2	--	--	1025
4.25	--	--	-65	--	--	--	20.0	3.54	9519	-2.9	--	--	1025
5.25	--	--	-71	--	--	--	20.0	3.54	9515	-3.2	--	--	1025
6.25	37.5	22.8	547	4.53	1078	1108	20.0	3.54	9519	24.7	0	38.44	1025
7.25	37.9	23.0	553	5.07	1196	1228	20.0	3.54	9515	25.0	0	42.58	1025

0.00 - 7.29

MAX	105.9	64.4	1546.	9.36	6128.	6292.	20.0	3.54	9519.	69.9	2.	218.17	1095.
MIN	-4.6	2.8	-81.	1.88	715.	734.	20.0	3.54	9516.	-3.6	0.	0.36	1025.
MEAN	69.7	42.4	393.	6.98	1051.	1080.	20.0	3.54	9518.	17.8	0.	37.41	1033. 3.10
ACCM	221.2	131.3		21.62	894.	1080.	20.0	3.54			0.	37.41	1025. 298.6

0.00 - 0.00

MAX	111.7	67.8	1628.	10.03	847.	860.	20.0	3.54	9621.	73.6	0.	30.46	1410.
MIN	100.1	61.0	1463.	8.64	715.	734.	19.5	3.21	9516.	66.2	0.	25.46	1095.
MEAN	107.6	65.4	1571.	9.37	778.	794.	19.7	3.35	9574.	71.0	0.	27.85	1264. 24.01
ACCM	2583.6	1570.8		224.89	778.	794.	19.7	3.35			0.	27.84	1261. 295.5

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1	KN2F1	BF	KF-LS	KF-MS	KF-LOI	KLD	FCAO	CL-LS	KCONTRL	KH2F1*			
	PROD	KCAL										CL-MS	KH2F1*	
	T/H	T/H	T/H	KC/KC	Z	Z	GR/L	DEG.C	Z	H	H			
7.25	35.5	21.5	4.73	1191	108.6	0.900	2.450	54.8	34.3	1025	19	0.12	0.900	2.540
8.25	32.9	20.0	5.34	1449	110.0	0.920	2.390	59.3	34.3	1025	52	0.12	0.900	2.540
9.25	41.6	25.3	4.50	967	110.0	0.920	2.390	59.3	34.3	1025	34	0.12	0.900	2.540
10.25	44.3	26.9	4.77	960	110.0	0.920	2.390	59.3	34.3	1025	39	0.12	0.900	2.540
11.25	48.7	29.6	5.92	1084	110.0	0.920	2.390	59.3	34.3	1025	80	0.12	0.900	2.540
12.25	56.4	34.3	6.83	1081	110.0	0.920	2.390	59.3	34.3	1560	86	0.12	0.900	2.540
13.25	71.7	43.6	7.32	912	110.0	0.920	2.390	59.3	34.3	1590	111	0.12	0.900	2.540
14.25	77.2	46.9	8.38	969	106.4	0.890	2.370	51.6	34.4	1570	125	0.47	0.910	2.490
15.25	79.3	48.2	8.35	940	106.4	0.890	2.370	51.6	34.4	1490	126	0.47	0.910	2.490
16.25	82.4	50.1	8.35	905	110.2	0.910	2.410	59.1	34.4	1530	142	0.47	0.910	2.490
17.25	83.1	50.5	8.48	911	110.2	0.910	2.410	59.1	34.4	1530	159	0.47	0.910	2.490
18.25	86.2	52.4	8.46	877	110.2	0.910	2.410	59.1	34.4	1470	158	0.47	0.910	2.490
19.25	88.9	54.0	8.49	853	110.2	0.910	2.410	59.1	34.4	1470	168	0.47	0.910	2.490
20.25	90.9	55.3	8.63	848	110.2	0.910	2.410	59.1	34.4	1430	164	0.47	0.910	2.490
21.25	93.7	57.0	8.80	839	110.2	0.910	2.410	59.1	34.4	1320	169	0.47	0.910	2.490
22.25	94.1	57.2	8.75	830	110.2	0.910	2.410	59.1	34.4	1320	48	0.47	0.910	2.490
23.25	93.1	56.6	8.83	847	110.8	0.920	2.370	61.4	34.4	1385	18	0.47	0.910	2.490
0.25	95.9	58.3	9.08	846	110.8	0.920	2.370	61.4	34.4	1385	181	0.47	0.910	2.490
1.25	97.7	59.4	9.14	835	110.8	0.920	2.370	61.4	34.4	1345	192	0.47	0.910	2.490
2.25	99.2	60.3	9.18	826	110.8	0.920	2.370	61.4	34.4	1335	208	0.47	0.910	2.490
3.25	99.4	60.4	9.23	829	110.8	0.920	2.370	61.4	34.4	1320	210	0.47	0.910	2.490
4.25	98.7	60.0	9.17	829	110.8	0.920	2.370	61.4	34.4	1320	216	0.47	0.910	2.490
5.25	100.5	61.1	9.06	804	110.8	0.920	2.370	61.4	34.4	1310	203	0.47	0.910	2.490
6.25	100.3	61.0	9.05	805	110.8	0.920	2.370	61.4	34.4	1310	221	0.47	0.910	2.490
7.25	100.0	60.8	9.08	811	110.8	0.920	2.370	61.4	34.4	1260	199	0.47	0.910	2.490

0.00 - 7.25															
MAX	101.5	61.7	9.30	859.	110.8	0.920	2.370	61.5	34.4	1385.	231.	0.47	0.910	2.490	
MIN	94.5	57.5	8.92	789.	110.8	0.920	2.370	61.5	34.4	1260.	94.	0.47	0.910	2.490	
MEAN	99.0	60.2	9.12	823.	110.8	0.920	2.370	61.5	34.4	1327.	206.	0.47	0.910	2.490	0.68 7.43
ACCM	735.5	447.2	67.74	823.	110.8	0.920	2.370	61.5	34.4	1321.	206.	0.47	0.910	2.490	221.9 322.1
0.00 - 0.00															
MAX	105.9	64.4	9.36	12012.	110.8	0.920	2.450	61.5	34.4	1590.	510.	0.47	0.910	2.540	
MIN	-5.1	-3.0	1.08	-366888	106.4	0.890	2.370	51.6	34.3	1025.	7.	0.12	0.900	2.490	
MEAN	72.4	44.0	7.42	924.	109.4	0.909	2.413	57.4	34.4	1259.	113.	0.27	0.904	2.519	0.98 19.47
ACCM	1416.3	857.2	144.32	914.	109.4	0.908	2.412	57.4	34.4	1269.	113.	0.28	0.905	2.517	221.2 314.8

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ ZD2 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCD EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	0.4	30.9	13	10.33	747	48	712	71	600	417	417	412	145	-0.03	491	
8.25	0.7	5.7	20	10.33	749	56	718	79	607	423	423	423	146	0.01	506	
9.25	0.8	11.0	20	8.26	784	62	737	87	609	416	415	418	184	-0.02	534	
10.25	0.9	8.0	17	7.88	789	61	745	90	617	418	417	420	184	-0.02	532	
11.25	1.0	10.9	19	7.87	795	68	754	106	609	398	397	401	213	-0.01	571	
12.25	1.1	14.3	57	8.50	793	114	757	173	626	412	412	418	380	0.00	649	
13.25	1.4	13.9	52	7.93	795	123	749	187	603	389	386	398	337	-0.01	681	
14.25	1.5	12.7	57	7.45	798	136	769	231	611	394	390	400	428	-0.02	752	
15.25	1.6	15.6	92	7.86	799	171	767	259	617	403	393	407	448	-0.01	756	
16.25	1.6	16.2	62	7.56	799	156	767	240	610	391	383	397	440	-0.01	758	
17.25	1.7	14.4	89	8.30	798	164	763	261	616	392	385	397	471	-0.02	772	
18.25	1.7	16.2	63	7.62	798	140	766	253	606	387	380	394	468	-0.01	773	
19.25	1.8	15.5	79	7.35	799	161	766	253	603	378	373	387	467	0.00	784	
20.25	1.8	14.7	74	7.61	799	162	759	264	605	379	369	385	486	0.00	781	
21.25	1.9	19.6	92	7.13	799	182	763	279	605	382	376	388	514	0.00	802	
22.25	1.9	19.4	99	7.57	798	170	770	301	616	389	380	394	552	-0.01	816	
23.25	1.9	18.7	87	7.12	799	180	767	288	617	388	381	394	554	-0.02	815	
0.25	1.9	18.4	106	5.98	799	201	769	319	618	391	382	395	587	-0.01	835	
1.25	1.9	20.0	107	6.05	799	200	762	317	615	389	383	395	593	-0.02	840	
2.25	1.9	20.9	107	5.48	800	188	763	326	612	385	379	390	599	-0.01	841	
3.25	1.9	21.8	102	5.64	799	200	762	321	606	387	377	390	597	0.00	841	
4.25	1.9	21.4	117	5.60	800	206	764	326	606	384	375	389	602	-0.01	837	
5.25	1.9	23.4	113	5.17	800	197	765	329	611	383	376	388	599	-0.02	842	
6.25	1.9	22.9	108	10.39	799	201	771	325	608	385	377	391	599	-0.03	843	
7.25	1.9	24.6	115	10.34	800	205	766	328	610	383	377	387	589	0.00	840	

0.00 - 7.27		0.00 - 0.00													
MAX	2.0	25.0	125.	10.45	805.	224.	778.	345.	623.	396.	387.	401.	613.	0.01	854.
MIN	2.0	17.7	84.	4.57	795.	161.	753.	302.	599.	380.	367.	385.	573.	-0.05	827.
MEAN	2.0	21.6	108.	6.78	800.	194.	766.	324.	611.	386.	379.	392.	595.	-0.02	841.
ACCH	2.0	21.6	108.		800.	194.	766.	324.	611.	386.	379.	392.	595.	-0.02	841.
MAX	2.0	46.0	152.	10.43	818.	242.	795.	353.	644.	456.	452.	444.	640.	1.06	893.
MIN	0.0	0.1	-11.	0.65	588.	-0.	602.	-15.	532.	335.	347.	320.	2.	-0.20	411.
MEAN	1.5	16.8	62.	7.76	791.	130.	757.	211.	611.	396.	392.	391.	391.	-0.01	707.
ACCH	1.5	16.8	62.		791.	130.	757.	211.	611.	396.	392.	391.	391.	-0.01	707.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	W1/ ZCO EX PREHEAT
KILN CON. MEASUR.	W1/ COAL TO KILN
KILN CONTROL	J1/ ID FAN SPEED
COAL TO KILN	

HOUR	KM2F1#			ESTLTW			NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL	KALARM	LTWT	GR/L	GR/L	GR/L	NOXL1	NOXL2	A50T1	DA15X1	DA1X2CO	DA2V1	T/H	RPM	
	H	H	H				Z	Z	Z	DEG.C	Z	Z			
7.25				1025	756	1098	-7.1	-7.1	0.042	412	2.12	10.33	-0.03	4.73	491
8.25				1025	788	983	-5.1	-5.1	0.049	423	2.03	10.33	0.01	5.34	506
9.25				1025	1361	1182	22.0	29.8	1.933	418	0.38	8.26	-0.02	4.50	534
10.25				1025	1479	1197	38.5	37.0	1.333	420	0.00	7.88	-0.02	4.77	532
11.25				1025	1340	1317	33.4	28.5	-0.640	401	0.41	7.87	-0.01	5.92	571
12.25				1560	1512	1280	36.5	34.9	-0.332	418	-0.23	8.50	0.00	6.83	649
13.25				1590	1466	1506	35.6	33.3	-0.103	398	0.19	7.93	-0.01	7.32	681
14.25				1570	1351	1476	28.1	26.7	0.060	400	0.03	7.45	-0.02	8.38	752
15.25				1490	1381	1483	27.1	27.6	0.087	407	-0.57	7.86	-0.01	8.35	756
16.25				1530	1415	1488	28.4	27.8	0.002	397	-0.35	7.56	-0.01	8.35	758
17.25				1530	1347	1465	25.4	24.3	-0.199	397	0.07	8.30	-0.02	8.48	772
18.25				1470	1392	1489	24.6	24.9	-0.021	394	-0.74	7.62	-0.01	8.46	773
19.25				1470	1361	1474	23.5	23.1	-0.008	387	-0.76	7.35	0.00	8.49	784
20.25				1430	1445	1469	19.5	19.1	-0.150	385	-0.49	7.61	0.00	8.63	781
21.25				1320	1394	1440	18.1	19.0	0.048	388	0.23	7.13	0.00	8.80	802
22.25				1320	1431	1458	23.2	22.9	0.044	394	0.18	7.57	-0.01	8.75	816
23.25				1385	1340	1346	18.5	17.7	-0.214	394	-0.16	7.12	-0.02	8.83	815
0.25				1385	1318	1327	15.6	16.1	-0.177	395	0.16	5.98	-0.01	9.08	835
1.25				1345	1350	1350	18.6	18.5	0.118	395	-0.02	6.05	-0.02	9.14	840
2.25				1335	1379	1378	20.4	20.5	0.071	390	-0.02	5.48	-0.01	9.18	841
3.25				1320	1407	1370	21.9	22.4	0.140	390	-0.03	5.64	0.00	9.23	841
4.25				1320	1385	1338	21.4	22.2	0.111	389	0.18	5.60	-0.01	9.17	837
5.25				1310	1350	1338	22.0	21.2	0.000	388	-0.16	5.17	-0.02	9.06	842
6.25				1310	1330	1314	20.2	20.2	-0.033	391	0.13	10.39	-0.03	9.05	843
7.25				1260	1320	1315	19.0	19.0	-0.041	387	-0.39	10.34	0.00	9.08	840

0.00 - 7.28															
MAX				1385.	1407.	1385.	22.8	22.4	0.222	401.	0.28	10.45	0.01	9.30	854.
MIN				1260.	1302.	1311.	14.2	15.0	-0.194	385.	-0.48	4.57	-0.05	8.92	827.
MEAN	7.48	0.68		1327.	1350.	1338.	19.8	19.8	0.002	392.	-0.03	6.79	-0.02	9.12	841.
ACCM	322.2	221.9		1321.		1338.			0.002	392.	-0.03		-0.02	68.13	841.
0.00 - 8.00															
MAX				1590.	1670.	5073.	47.4	48.1	2.050	444.	10.22	10.43	1.06	9.36	893.
MIN				1025.	722.	853.	-9.2	-9.3	-1.016	320.	-2.85	0.65	-0.20	1.08	411.
MEAN	19.47	0.98		1259.	1184.	1336.	15.3	15.3	0.003	391.	0.01	7.76	-0.01	7.42	787.
ACCM	314.8	221.2		1269.		1336.			0.003	391.	0.01		-0.01	144.32	787.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL

Z MOISTURE IN COAL

NET HEAT CONSUMP.

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUC. RATE

KILN PRODUCTION

W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER

LB COAL / SH. T

MBTU/ PER SH. T

UI/ LITER WEIGHT

COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU		LTWT
	PROD		KN2F1	MKCAL		C-ASH				LB. COAL			KN2F1*
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z	T/H			GR/L	H
7.25	35.5	21.5	518	4.73	1191	1223	20.0	3.54	9515	23.4	0	42.56	1025
8.25	32.9	20.0	480	5.34	1449	1488	20.0	3.54	9519	21.7	0	51.33	1025
9.25	41.6	25.3	607	4.50	967	993	20.0	3.54	9519	27.4	0	34.40	1025
10.25	44.3	26.9	647	4.77	960	986	20.0	3.54	9519	29.3	0	34.22	1025
11.25	48.7	29.6	711	5.92	1084	1113	20.0	3.54	9519	32.1	0	38.34	1025
12.25	56.4	34.3	823	6.83	1081	1110	20.0	3.54	9519	37.2	0	38.28	1560
13.25	71.7	43.6	1047	7.32	912	936	20.0	3.54	9519	47.3	0	32.36	1590
14.25	77.2	46.9	1127	8.38	969	1000	19.0	5.06	9473	50.9	0	34.28	1570
15.25	79.3	48.2	1157	8.35	940	970	19.0	5.06	9473	52.3	0	33.39	1490
16.25	82.4	50.1	1203	8.35	985	933	19.0	5.06	9473	54.4	0	32.00	1530
17.25	83.1	50.5	1213	8.48	911	940	19.0	5.06	9473	54.8	0	32.11	1530
18.25	86.2	52.4	1258	8.46	877	985	19.0	5.06	9473	56.9	0	31.04	1470
19.25	88.9	54.0	1297	8.49	853	880	19.0	5.06	9473	58.6	0	30.31	1470
20.25	90.9	55.3	1327	8.63	848	874	19.0	5.06	9473	60.0	0	30.02	1430
21.25	93.7	57.0	1368	8.80	839	865	19.0	5.06	9473	61.8	0	29.65	1320
22.25	94.1	57.2	1373	8.75	830	857	19.0	5.06	9470	62.1	0	29.59	1320
23.25	93.1	56.6	1358	8.83	847	874	19.0	5.06	9473	61.4	0	30.01	1385
0.25	95.9	58.3	1400	9.08	846	872	19.0	5.06	9473	63.3	0	29.92	1385
1.25	97.7	59.4	1426	9.14	835	861	19.0	5.06	9473	64.5	0	29.63	1345
2.25	99.2	60.3	1448	9.18	826	852	19.0	5.06	9473	65.5	0	29.22	1335
3.25	99.4	60.4	1450	9.23	829	855	19.0	5.06	9473	65.6	0	29.45	1320
4.25	98.7	60.0	1441	9.17	829	856	19.0	5.06	9473	65.2	0	29.42	1320
5.25	100.5	61.1	1467	9.06	804	830	19.0	5.06	9473	66.3	0	28.33	1310
6.25	100.3	61.0	1464	9.05	805	831	19.0	5.06	9473	66.2	0	28.51	1310
7.25	100.0	60.8	1459	9.08	811	836	19.0	5.06	9473	66.0	0	28.79	1260

0.00 - 7.29

MAX	101.5	61.7	1481.	9.30	859.	886.	19.0	5.06	9473.	67.0	0.	30.44	1385.
MIN	94.5	57.5	1380.	8.92	789.	814.	19.0	5.06	9470.	62.4	0.	27.96	1260.
MEAN	99.0	60.2	1444.	9.12	823.	849.	19.0	5.06	9473.	65.3	0.	29.15	1327. 7.49
ACCH	740.9	450.5		68.23	823.	849.	19.0	5.06			0.	29.15	1321. 322.2

0.00 - 0.00

MAX	105.9	64.4	1546.	9.36	12012.	12333.	20.0	5.06	9519.	69.9	4.	427.64	1590.
MIN	-5.1	-3.0	-81.	1.08	-366888-	-376836	19.0	3.54	9345.	-3.6	-137.	-13062.	1025.
MEAN	72.4	44.0	849.	7.42	924.	951.	19.6	4.18	9499.	38.4	0.	32.82	1259. 19.47
ACCH	1416.3	857.2		144.32	914.	952.	19.6	4.18			0.	32.82	1269. 314.8

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	W1/ LITER WEIGHT
W1/ KILN FEED LSF	W1/ CLINKER TEMP
W1/ BURNING FACTOR	W1/ FREE LIME
HEAT CONSUMPTION	W1/ CLINKER LSF
W1/ COAL TO KILN	W1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

	HO1OF1	KN2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL			
HOUR	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KN2F1*			
	T/H	T/H	T/H	KC/KG	Z	Z	GR/L	DEG.C	Z	H	H

7.25	100.6	61.1	9.87	805	110.8	0.920	2.370	61.4	34.4	1310	213	0.47	0.910	2.490
8.25	99.7	60.6	9.15	819	110.8	0.920	2.370	61.4	34.4	1250	178	0.47	0.910	2.490
9.25	100.2	60.9	9.20	819	119.8	1.000	2.450	81.6	34.4	1250	190	0.47	0.910	2.490
10.25	99.2	60.3	8.89	801	119.8	1.000	2.450	81.6	34.4	1280	201	0.47	0.910	2.490
11.25	100.1	60.9	8.35	745	119.8	1.000	2.450	81.6	34.4	1310	223	0.47	0.910	2.490
12.25	97.9	59.5	9.20	839	119.8	1.000	2.450	81.6	34.4	1235	204	0.47	0.910	2.490
13.25	98.6	59.9	9.07	821	108.5	0.900	2.400	55.4	34.5	1235	158	0.12	0.910	2.490
14.25	99.6	60.5	8.90	798	108.5	0.900	2.400	55.4	34.5	1235	163	0.12	0.920	2.510
15.25	99.0	60.2	8.82	796	108.5	0.900	2.400	55.4	34.5	1340	239	0.12	0.920	2.510
16.25	100.4	61.0	8.94	795	108.5	0.900	2.400	55.4	34.5	1270	231	0.12	0.920	2.510
17.25	100.3	60.9	8.83	787	108.5	0.890	2.440	54.3	34.5	1260	232	0.12	0.920	2.510
18.25	99.1	60.2	9.51	857	108.5	0.890	2.440	54.3	34.5	1280	318	0.12	0.920	2.510
19.25	99.8	60.6	9.33	834	108.5	0.890	2.440	54.3	34.5	1150	234	0.12	0.920	2.510
20.25	100.1	60.9	8.73	779	108.5	0.890	2.440	54.3	34.5	1290	227	0.12	0.920	2.510
21.25	100.3	61.0	8.89	791	108.5	0.890	2.440	54.3	34.5	1380	208	0.12	0.920	2.510
22.25	99.6	60.5	8.78	787	108.5	0.890	2.440	54.3	34.5	1385	223	0.12	0.920	2.510
23.25	99.4	60.4	8.87	797	108.5	0.890	2.440	54.3	34.5	1330	243	0.12	0.920	2.510
0.25	99.3	60.3	9.03	812	108.5	0.890	2.440	54.3	34.5	1285	255	0.12	0.920	2.510
1.25	99.6	60.5	8.86	794	108.5	0.890	2.440	54.3	34.5	1270	246	0.12	0.920	2.510
2.25	99.1	60.2	8.94	806	108.5	0.890	2.440	54.3	34.5	1305	231	0.12	0.920	2.510
3.25	100.7	61.2	8.98	796	111.5	0.930	2.410	62.4	34.5	1250	248	0.12	0.920	2.510
4.25	99.9	60.7	9.06	809	111.5	0.930	2.410	62.4	34.5	1270	214	0.12	0.920	2.510
5.25	100.0	60.8	8.94	798	111.5	0.930	2.410	62.4	34.5	1340	211	0.12	0.920	2.510
6.25	100.1	60.8	8.74	780	111.5	0.930	2.410	62.4	34.5	1310	219	0.12	0.920	2.510
7.25	98.9	60.1	8.78	792	111.5	0.930	2.410	62.4	34.5	1345	224	0.12	0.920	2.510

0.00 - 7.25

MAX	101.6	61.8	9.17	831.	111.5	0.930	2.440	62.5	34.6	1345.	267.	0.12	0.920	2.510		
MIN	96.9	58.8	8.52	761.	108.5	0.890	2.410	54.3	34.6	1250.	177.	0.12	0.920	2.510		
MEAN	99.6	60.6	8.91	799.	110.2	0.912	2.424	58.8	34.6	1293.	229.	0.12	0.920	2.510	6.80	7.43
ACCH	740.3	450.1	66.20	799.	110.2	0.913	2.423	59.0	34.6	1290.	229.	0.12	0.920	2.510	229.9	345.9

0.00 - 0.00

MAX	102.1	62.1	9.99	902.	119.8	1.000	2.450	81.6	34.6	1385.	332.	0.47	0.920	2.510		
MIN	94.2	57.3	8.28	736.	108.5	0.890	2.370	54.3	34.4	1150.	94.	0.12	0.910	2.490		
MEAN	99.4	60.5	9.02	810.	111.4	0.923	2.410	62.2	34.5	1297.	214.	0.32	0.914	2.498	1.95	24.02
ACCH	2386.5	1451.0	216.41	810.	111.6	0.924	2.414	62.5	34.5	1296.	214.	0.31	0.915	2.499	223.2	338.5

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ X02 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ X00 EX PREHEAT
 J1/ ID FAN SPEED

	0A15V1	0A15P1	A54T1	A53T1	A52T1	A61T1	A50P1	0A1X2C0						
HOURL	0A15A1	0A15X1	A54P1	A53P1	A51T1	A50T1		0A2V1						
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM

7.25	1.9	23.8	99	10.34	798	196	769	321	608	385	377	390	597	-0.01	842
8.25	1.9	28.9	119	10.38	803	204	770	333	611	382	377	389	605	-0.02	840
9.25	1.9	31.5	124	10.36	801	207	764	332	609	382	375	388	595	-0.01	845
10.25	1.9	31.6	114	1.20	802	205	765	330	612	383	374	388	586	-0.01	854
11.25	1.9	31.5	123	3.19	797	213	767	347	608	383	375	388	614	-0.03	866
12.25	1.9	30.8	118	1.94	799	205	768	336	610	384	378	388	598	-0.01	847
13.25	1.9	33.5	131	1.93	801	223	772	353	619	391	381	393	630	-0.02	868
14.25	1.9	34.8	124	2.61	805	230	786	354	627	390	383	397	622	0.00	862
15.25	1.9	34.7	115	3.12	801	202	779	345	620	390	382	396	609	-0.01	862
16.25	1.9	33.7	113	2.89	804	203	776	339	620	389	381	394	611	0.00	862
17.25	1.9	36.2	116	3.57	803	210	782	337	622	394	384	398	608	0.00	860
18.25	1.9	39.2	127	2.56	803	222	781	343	623	391	383	397	624	0.00	870
19.25	1.9	36.8	135	2.38	805	214	783	355	635	400	387	402	641	-0.01	877
20.25	1.9	36.9	119	3.12	803	204	781	344	628	392	384	397	612	0.00	858
21.25	1.9	35.8	117	3.15	803	203	778	348	626	391	383	396	610	-0.01	861
22.25	1.9	34.9	126	3.25	800	212	776	333	624	392	383	396	621	-0.02	862
23.25	1.9	34.0	124	3.16	801	204	776	341	622	390	381	394	627	-0.03	860
0.25	1.9	33.3	125	3.03	801	200	781	346	616	389	381	396	627	-0.03	858
1.25	1.9	34.5	126	3.07	802	202	781	343	620	389	381	394	638	-0.02	861
2.25	1.9	36.4	126	3.42	801	194	777	343	624	391	380	396	632	-0.04	862
3.25	1.9	34.8	133	2.69	803	204	777	337	615	386	378	391	620	-0.04	859
4.25	1.9	34.8	124	2.13	804	209	779	335	618	389	382	393	619	-0.02	866
5.25	1.9	36.0	136	3.37	802	207	775	338	619	390	382	397	626	-0.02	866
6.25	1.9	35.7	125	2.78	803	208	784	344	621	391	384	396	620	-0.02	861
7.25	1.9	33.7	126	3.59	801	209	779	323	620	388	382	394	626	-0.02	860

0.00 - 7.27

MAX	2.0	37.4	142.	4.16	808.	231.	787.	356.	631.	395.	391.	400.	643.	0.00	873.
MIN	2.0	33.1	117.	2.14	798.	180.	771.	269.	610.	382.	376.	389.	608.	-0.06	851.
MEAN	2.0	35.1	129.	3.15	803.	208.	779.	338.	620.	390.	382.	395.	626.	-0.03	863.
ACCN	2.0	35.1	129.		803.	208.	779.	338.	620.	390.	382.	395.	626.	-0.03	863.

0.00 - 0.00

MAX	2.0	45.8	148.	10.51	810.	243.	792.	376.	637.	402.	392.	412.	665.	0.32	886.
MIN	2.0	17.7	84.	0.27	790.	124.	753.	300.	596.	374.	367.	380.	573.	-0.07	827.
MEAN	2.0	30.3	118.	4.59	801.	206.	773.	336.	616.	388.	380.	393.	607.	-0.02	853.
ACCN	2.0	30.3	118.		801.	206.	773.	336.	616.	388.	380.	393.	607.	-0.02	853.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6 KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ ZCO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL	LTWT	LTWT	LTWT	LTWT	LTWT	NOXLT	NOXLT	A50T1	A50T1	OA15X1	OA15X1	OA1X2CO	OA2V1	
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM
7.25				1310	1324	1313	19.5	19.5	-0.037	398	-0.15	10.34	-0.01	9.07	942
8.25				1250	1309	1326	17.6	17.6	-0.049	389	-0.36	10.38	-0.02	9.15	840
9.25				1250	1297	1333	16.1	16.1	-0.049	388	-0.01	10.36	-0.01	9.20	845
10.25				1280	1390	1343	29.7	29.7	0.331	388	-0.58	1.20	-0.01	8.89	854
11.25				1310	1386	1344	25.7	29.2	-0.291	388	0.20	3.19	-0.03	8.35	866
12.25				1235	1219	1262	12.6	12.3	-0.351	388	0.04	1.94	-0.01	9.20	847
13.25				1235	1380	1348	24.1	27.7	1.019	393	0.12	1.93	-0.02	9.07	868
14.25				1235	1456	1388	35.1	35.0	0.099	397	0.37	2.61	0.00	8.90	862
15.25				1340	1322	1323	28.6	27.7	-0.180	396	-0.01	3.12	-0.01	8.82	862
16.25				1270	1296	1287	26.0	24.8	-0.216	394	0.13	2.89	0.00	8.94	862
17.25				1260	1305	1287	28.9	30.1	0.219	398	-0.34	3.57	0.00	8.83	860
18.25				1280	1236	1253	10.8	10.7	-0.417	397	-0.02	2.56	0.00	9.51	870
19.25				1150	1215	1243	15.6	15.2	0.049	402	0.03	2.38	-0.01	9.33	877
20.25				1290	1386	1338	44.6	46.2	0.850	397	-0.09	3.12	0.00	8.73	858
21.25				1380	1332	1340	36.9	36.4	-0.225	396	-0.16	3.15	-0.01	8.89	861
22.25				1385	1344	1305	37.9	38.3	0.000	396	-0.12	3.25	-0.02	8.78	862
23.25				1330	1305	1307	32.1	32.4	-0.192	394	-0.09	3.16	-0.03	8.87	860
0.25				1285	1275	1275	28.8	28.5	-0.149	396	0.09	3.03	-0.03	9.03	858
1.25				1270	1272	1276	28.2	28.5	-0.037	394	0.29	3.07	-0.02	8.86	861
2.25				1305	1268	1269	26.9	27.3	-0.068	396	0.01	3.42	-0.04	8.94	862
3.25				1250	1262	1262	26.6	26.5	0.005	391	0.01	2.69	-0.04	8.98	859
4.25				1270	1284	1283	30.2	29.7	0.073	393	0.20	2.13	-0.02	9.06	866
5.25				1340	1277	1279	28.6	27.9	-0.123	397	0.11	3.37	-0.02	8.94	866
6.25				1310	1302	1302	30.4	30.7	0.065	396	0.28	2.78	-0.02	8.74	861
7.25				1345	1267	1277	25.3	24.8	-0.151	394	-0.08	3.59	-0.02	8.78	860

0.00 - 7.28

MAX				1345.	1306.	1306.	32.7	32.4	0.203	400.	0.67	4.16	0.00	9.17	873.
MIN				1250.	1250.	1250.	24.5	24.5	-0.318	389.	-0.32	2.14	-0.06	8.52	851.
MEAN	7.48	6.85		1293.	1278.	1279.	28.4	28.4	-0.024	395.	0.01	3.15	-0.03	8.91	863.
ACCH	345.9	229.9		1290.		1279.			-0.024	395.	0.01		-0.03	66.57	863.

0.00 - 0.00

MAX				1385.	1464.	1394.	45.1	46.6	1.205	412.	0.88	10.51	0.32	9.99	886.
MIN				1150.	1178.	1153.	8.5	8.4	-0.900	380.	-0.75	0.27	-0.07	8.28	827.
MEAN	24.02	1.95		1297.	1331.	1323.	24.4	24.4	0.017	393.	-0.00	4.59	-0.02	9.02	853.
ACCH	338.5	223.2		1296.		1323.			0.017	393.	-0.00		-0.02	216.41	853.

PLANT REPORT 6 KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU' PER SH. T
W1/ COAL TO KILN	U1/ LITER WEIGHT
KILN PRODUC. RATE	COAL TO KILN
KILN PRODUCTION	
W1/ KILN FEED	

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT	STONS	BTU		LTWT	
	PROD		KN2F1	NKCAL		C-ASH		LB. COAL		KN2F1#			
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%		T/H	GR/L	H	
7.25	100.6	61.1	1468	9.07	805	830	19.0	5.06	9473	66.4	0	28.59	1310
8.25	99.7	60.6	1455	9.15	819	845	19.0	5.06	9473	65.8	0	28.99	1250
9.25	100.2	60.9	1463	9.20	819	845	19.0	5.06	9473	66.1	0	28.96	1250
10.25	99.2	60.3	1447	8.89	881	826	19.0	5.06	9473	65.4	0	28.34	1280
11.25	100.1	60.9	1461	8.35	745	768	19.0	5.06	9473	66.1	0	26.65	1310
12.25	97.9	59.5	1430	9.20	839	865	19.0	5.06	9473	64.6	0	29.56	1235
13.25	98.6	59.9	1439	9.07	821	848	19.0	5.06	9470	65.0	0	28.92	1235
14.25	99.6	60.5	1453	8.90	798	825	20.0	4.10	9453	65.7	0	28.36	1235
15.25	99.0	60.2	1444	8.82	796	822	20.0	4.10	9453	65.3	0	28.06	1340
16.25	100.4	61.0	1465	8.94	795	822	20.0	4.10	9453	66.2	0	28.89	1270
17.25	100.3	60.9	1463	8.83	787	813	20.0	4.10	9453	66.2	0	27.66	1260
18.25	99.1	60.2	1446	9.51	857	886	20.0	4.10	9453	65.4	0	30.31	1280
19.25	99.8	60.6	1456	9.33	834	863	20.0	4.10	9453	65.8	0	29.51	1150
20.25	100.1	60.9	1461	8.73	779	805	20.0	4.10	9453	66.1	0	27.58	1290
21.25	100.3	61.0	1464	8.89	791	818	20.0	4.10	9453	66.2	0	28.87	1380
22.25	99.6	60.5	1454	8.78	787	814	20.0	4.10	9453	65.7	0	27.96	1385
23.25	99.4	60.4	1451	8.87	797	824	20.0	4.10	9453	65.6	0	28.19	1330
0.25	99.3	60.3	1449	9.03	812	840	20.0	4.10	9453	65.5	0	28.45	1285
1.25	99.6	60.5	1454	8.86	794	821	20.0	4.10	9450	65.7	0	28.06	1270
2.25	99.1	60.2	1446	8.94	806	833	20.0	4.10	9453	65.4	0	28.46	1385
3.25	100.7	61.2	1470	8.98	796	823	20.0	4.10	9453	66.5	0	28.11	1250
4.25	99.9	60.7	1458	9.06	809	837	20.0	4.10	9453	65.9	0	28.78	1270
5.25	100.0	60.8	1460	8.94	798	825	20.0	4.10	9453	66.0	0	28.34	1340
6.25	100.1	60.8	1461	8.74	780	806	20.0	4.10	9453	66.0	0	27.43	1310
7.25	98.9	60.1	1444	8.78	792	819	20.0	4.10	9453	65.3	0	27.97	1345

0.00 - 7.29

MAX	101.6	61.8	1482.	9.17	831.	859.	20.0	4.11	9454.	67.1	0.	29.39	1345.
MIN	96.9	58.8	1411.	8.52	761.	787.	20.0	4.11	9451.	63.8	0.	26.92	1250.
MEAN	99.6	60.6	1454.	8.91	799.	826.	20.0	4.11	9454.	65.8	0.	28.24	1293. 7.49
ACCM	745.7	453.4		66.67	799.	826.	20.0	4.11			0.	28.24	1290. 345.9

0.00 - 8.00

MAX	102.1	62.1	1498.	9.99	982.	931.	20.0	5.06	9579.	67.4	0.	31.98	1385.
MIN	94.2	57.3	1375.	8.28	736.	760.	19.0	4.11	9451.	62.2	0.	26.89	1150.
MEAN	99.4	60.5	1451.	9.02	810.	837.	19.4	4.64	9463.	65.6	0.	28.68	1297. 24.02
ACCM	2386.5	1451.0		216.41	810.	837.	19.4	4.64			0.	28.67	1296. 338.5

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HO10F1	KM2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL	HO10F1*						
PROD	KCAL	BF	KF-LS	C3S	LTWT	FCAO	CL-MS	KM2F1*						
T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H				
7.25	98.9	60.1	8.66	781	111.5	0.930	2.410	62.4	34.5	1310	212	0.12	0.920	2.510
8.25	98.5	59.9	9.00	816	103.6	0.840	2.490	40.3	34.5	1285	255	0.12	0.920	2.510
9.25	100.5	61.1	8.78	780	103.6	0.840	2.490	40.3	34.5	1290	233	0.12	0.920	2.510
10.25	99.9	60.7	8.59	767	103.6	0.840	2.490	40.3	34.5	1345	244	0.12	0.920	2.510
11.25	100.0	60.8	8.42	751	103.6	0.840	2.490	40.3	34.5	1330	228	0.12	0.920	2.510
12.25	99.2	60.3	8.63	776	103.6	0.840	2.490	40.3	34.5	1330	215	0.12	0.920	2.510
13.25	99.5	60.5	8.77	787	103.6	0.840	2.490	40.3	34.5	1195	197	0.12	0.920	2.510
14.25	99.7	60.6	8.95	802	108.7	0.900	2.440	56.2	34.3	1215	173	0.24	0.910	2.530
15.25	98.7	60.0	8.88	803	108.7	0.900	2.440	56.2	34.3	1240	209	0.24	0.910	2.530
16.25	99.4	60.4	8.57	770	109.0	0.910	2.370	56.5	34.3	1310	195	0.24	0.910	2.530
17.25	99.4	60.4	8.70	781	109.0	0.910	2.370	56.5	34.3	1310	211	0.24	0.910	2.530
18.25	99.0	60.2	8.79	793	109.0	0.910	2.370	56.5	34.3	1245	234	0.24	0.910	2.530
19.25	100.3	61.0	8.77	780	109.0	0.910	2.370	56.5	34.3	1230	227	0.24	0.910	2.530
20.25	100.0	60.8	8.91	795	109.0	0.910	2.370	56.5	34.3	1205	187	0.24	0.910	2.530
21.25	98.9	60.1	8.87	801	109.0	0.910	2.370	56.5	34.3	1175	200	0.24	0.910	2.530
22.25	100.2	60.9	8.73	777	109.0	0.910	2.370	56.5	34.3	1250	248	0.24	0.910	2.530
23.25	99.5	60.5	9.16	822	109.0	0.910	2.370	56.5	34.3	1200	197	0.24	0.910	2.530
0.25	99.3	60.4	9.25	831	106.2	0.870	2.450	48.1	34.3	1210	202	0.24	0.910	2.530
1.25	99.3	60.4	9.47	851	106.2	0.870	2.450	48.1	34.3	1180	230	0.24	0.910	2.530
2.25	99.9	60.7	9.26	827	106.2	0.870	2.450	48.1	34.3	1255	216	0.24	0.910	2.530
3.25	99.5	60.4	8.99	807	106.2	0.870	2.450	48.1	34.3	1320	248	0.24	0.910	2.530
4.25	100.0	60.8	9.14	817	106.2	0.870	2.450	48.1	34.3	1300	247	0.24	0.910	2.530
5.25	100.3	60.9	9.24	823	106.2	0.870	2.450	48.1	34.3	1210	193	0.24	0.910	2.530
6.25	98.3	59.8	9.00	817	106.2	0.870	2.450	48.1	34.3	1310	213	0.24	0.910	2.530
7.25	99.8	60.7	8.86	793	106.2	0.870	2.450	48.1	34.3	1350	259	0.24	0.910	2.530

0.00 - 7.25														
MAX	101.3	61.6	9.58	867.	106.2	0.870	2.450	48.2	34.3	1350.	267.	0.24	0.910	2.530
MIN	97.9	59.5	8.76	779.	106.2	0.870	2.450	48.2	34.3	1180.	189.	0.24	0.910	2.530
MEAN	99.7	60.6	9.18	822.	106.2	0.870	2.450	48.2	34.3	1256.	228.	0.24	0.910	2.530
ACCM	741.1	450.6	68.21	822.	106.2	0.870	2.450	48.2	34.3	1247.	228.	0.24	0.910	2.530

0.00 - 0.00														
MAX	101.6	61.8	9.36	845.	111.5	0.930	2.490	62.5	34.6	1345.	269.	0.24	0.920	2.530
MIN	96.9	58.8	8.29	742.	103.6	0.840	2.370	40.4	34.3	1175.	162.	0.12	0.910	2.510
MEAN	99.7	60.6	8.83	791.	108.2	0.894	2.422	53.7	34.4	1273.	220.	0.17	0.916	2.520
ACCM	2393.0	1454.9	211.90	791.	108.2	0.895	2.421	53.7	34.4	1276.	220.	0.18	0.915	2.519

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ Z02 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCO EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	36.0	120	3.74	802	206	774	341	619	389	381	395	617	-0.02	864	
8.25	1.9	31.6	131	3.38	800	200	778	345	622	391	383	396	624	-0.03	859	
9.25	1.9	31.6	125	3.47	801	197	779	344	619	389	382	395	619	-0.02	862	
10.25	1.9	28.6	126	3.86	801	198	779	329	619	389	380	394	620	-0.03	861	
11.25	1.9	25.8	126	4.17	799	215	778	332	619	388	382	395	620	-0.01	864	
12.25	1.9	24.5	126	4.11	800	209	778	325	615	389	382	395	616	-0.01	864	
13.25	1.9	25.6	119	3.39	800	190	769	300	609	383	376	389	601	-0.01	863	
14.25	1.9	29.5	129	3.34	801	213	775	328	617	389	380	395	616	-0.01	873	
15.25	1.9	30.3	130	2.72	802	207	783	323	621	391	384	397	612	-0.02	874	
16.25	1.9	33.3	126	3.06	804	217	780	336	622	393	385	397	610	-0.02	874	
17.25	1.9	33.0	125	3.70	800	203	774	326	620	390	379	395	607	0.00	867	
18.25	1.9	34.0	123	3.12	801	208	778	321	612	390	380	394	610	-0.02	866	
19.25	1.9	30.0	127	2.79	802	210	779	313	624	391	383	396	612	-0.01	865	
20.25	1.9	31.5	132	2.78	803	207	778	331	621	391	380	394	604	-0.02	860	
21.25	1.9	32.8	127	3.23	802	207	779	329	615	393	383	395	605	-0.01	862	
22.25	1.9	33.8	123	3.45	802	202	770	316	613	389	379	394	602	0.00	868	
23.25	1.9	31.7	127	3.12	803	208	780	338	617	386	381	393	606	0.00	959	
0.25	1.9	39.0	129	2.30	805	203	779	337	613	389	382	395	608	0.00	862	
1.25	1.9	35.3	135	2.29	805	215	777	329	619	391	382	394	611	0.00	857	
2.25	1.9	36.8	141	3.18	804	220	777	331	622	389	380	393	616	-0.01	860	
3.25	1.9	37.5	140	2.97	804	229	778	349	620	387	381	393	613	0.00	862	
4.25	1.9	31.3	129	2.97	801	210	775	343	609	385	381	393	612	0.00	863	
5.25	1.9	31.8	135	2.62	805	215	783	333	626	390	384	396	608	0.00	861	
6.25	1.9	33.7	125	3.32	804	214	781	331	621	390	384	396	605	-0.01	860	
7.25	1.9	32.0	114	3.60	804	204	778	293	616	385	382	393	606	-0.01	864	

0.00 - 7.27

MAX	2.0	39.4	155.	4.06	811.	242.	788.	354.	630.	394.	389.	400.	625.	0.03	870.
MIN	2.0	30.4	110.	1.84	801.	179.	769.	285.	609.	383.	374.	387.	596.	-0.03	852.
MEAN	2.0	34.4	130.	2.88	805.	210.	779.	334.	619.	390.	383.	395.	609.	-0.00	862.
ACCM	2.0	34.4	130.		805.	210.	779.	334.	619.	390.	383.	395.	609.	-0.00	862.

0.00 - 0.00

MAX	2.0	37.4	142.	4.44	808.	231.	788.	356.	631.	396.	391.	402.	643.	0.01	881.
MIN	2.0	23.8	114.	2.14	796.	180.	767.	262.	606.	381.	374.	386.	587.	-0.06	849.
MEAN	2.0	32.0	127.	3.30	802.	206.	778.	329.	619.	390.	382.	395.	617.	-0.02	865.
ACCM	2.0	32.0	127.		802.	206.	778.	329.	619.	390.	382.	395.	617.	-0.02	865.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME W1/ NOX CHANGE LT
 W1/ NOX REG STIME W1/ T EXIT PREHEAT
 W1/ LTW FOR CONTRL W1/ A50T1 CHANGE
 W1/ ESTIMATED LTW W1/ Z02 KILN OUTL
 U1/ LITER WEIGHT
 KILN CON. MEASUR. W1/ ZCO EX PREHEAT
 KILN CONTROL W1/ COAL TO KILN
 COAL TO KILN J1/ ID FAN SPEED

HOUR	KN2F1#		KALARN		ESTLTW		NOXST		NOXALT		A50ALT		KN2F1		
	KCONTRL		LTWT		LTWTSP		NOXL		A50T1		OA15X1		OA1X2CO	OA2V1	
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM
7.25				1310	1274	1276	26.2	26.1	-0.305	395	-0.08	3.74	-0.02	8.66	864
8.25				1285	1278	1280	25.8	25.6	0.088	396	0.04	3.38	-0.03	9.00	859
9.25				1290	1292	1291	26.6	27.1	-0.041	395	-0.27	3.47	-0.02	8.78	862
10.25				1345	1284	1306	24.6	24.7	-0.007	394	0.15	3.86	-0.03	8.59	861
11.25				1330	1269	1290	20.2	20.7	-0.153	395	-0.18	4.17	-0.01	8.42	864
12.25				1330	1218	1256	14.0	13.3	-0.177	395	0.01	4.11	-0.01	8.63	864
13.25				1195	1228	1212	15.9	16.2	0.078	389	-0.45	3.39	-0.01	8.77	863
14.25				1215	1228	1227	16.7	16.8	0.113	395	-0.01	3.34	-0.01	8.95	873
15.25				1240	1311	1304	24.6	25.3	0.193	397	-0.03	2.72	-0.02	8.88	874
16.25				1310	1290	1291	24.3	23.3	-0.112	397	-0.07	3.86	-0.02	8.57	874
17.25				1310	1244	1249	18.3	18.2	-0.142	395	-0.31	3.70	0.00	8.70	867
18.25				1245	1261	1260	19.3	19.5	0.071	394	-0.07	3.12	-0.02	8.79	866
19.25				1230	1282	1280	21.5	22.0	0.038	396	0.06	2.79	-0.01	8.77	865
20.25				1205	1237	1235	18.2	17.7	-0.140	394	-0.20	2.78	-0.02	8.91	860
21.25				1175	1275	1266	22.1	22.5	0.131	395	0.06	3.23	-0.01	8.87	862
22.25				1250	1211	1219	16.8	16.6	-0.468	394	0.08	3.45	0.00	8.73	868
23.25				1200	1229	1221	19.0	18.6	0.116	393	0.12	3.12	0.00	9.16	859
0.25				1210	1229	1224	19.0	19.3	-0.169	395	0.01	2.30	0.00	9.25	862
1.25				1180	1291	1262	26.0	26.3	0.498	394	0.09	2.29	0.00	9.47	857
2.25				1255	1376	1292	34.8	34.9	0.167	393	-0.08	3.18	-0.01	9.26	860
3.25				1320	1313	1278	34.6	34.3	0.031	393	-0.15	2.97	0.00	8.99	862
4.25				1300	1231	1228	23.5	22.6	-0.153	393	0.03	2.97	0.00	9.14	863
5.25				1210	1280	1269	29.3	29.7	0.290	396	-0.03	2.62	0.00	9.24	861
6.25				1310	1303	1304	31.7	32.5	-0.077	396	-0.03	3.32	-0.01	9.00	860
7.25				1350	1255	1260	24.0	24.9	-0.372	393	0.03	3.60	-0.01	8.86	864

0.00 - 7.28

MAX				1350.	1376.	1343.	35.0	34.9	0.552	400.	0.38	4.06	0.03	9.58	870.
MIN				1180.	1213.	1208.	17.6	17.7	-0.689	387.	-0.64	1.84	-0.03	8.76	852.
MEAN	7.48	7.48		1257.	1287.	1271.	28.2	28.3	0.033	395.	-0.01	2.88	-0.00	9.18	862.
ACCH	369.6	253.6		1247.		1271.			0.033	395.	-0.01		-0.00	68.59	862.

0.00 - 0.00

MAX				1345.	1324.	1317.	32.7	32.4	0.397	402.	0.67	4.44	0.01	9.36	881.
MIN				1175.	1195.	1202.	13.7	13.3	-0.483	386.	-0.65	2.14	-0.06	8.29	849.
MEAN	24.02	23.31		1273.	1266.	1269.	23.2	23.2	-0.015	395.	0.00	3.30	-0.02	8.83	865.
ACCH	362.2	246.2		1276.		1269.			-0.015	395.	0.00		-0.02	211.98	865.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU		LTWT
	PROD			KM2F1	MKCAL		C-ASH		LB. COAL		KN2F1*		
	T/H	T/H	T		T/H	KC/KG	KC/KG	Z	Z	T/H		GR/L	H
7.25	98.9	60.1	1444	8.66	781	888	20.0	4.10	9453	65.3	0	27.55	1310
8.25	98.5	59.9	1438	9.00	816	843	20.0	4.10	9453	65.0	0	28.80	1285
9.25	100.5	61.1	1467	8.78	780	886	20.0	4.10	9453	66.3	0	27.69	1290
10.25	99.9	60.7	1458	8.59	767	793	20.0	4.10	9453	65.9	0	27.00	1345
11.25	100.0	60.8	1460	8.42	751	777	20.0	4.10	9453	66.0	0	26.38	1330
12.25	99.2	60.3	1448	8.63	776	802	20.0	4.10	9453	65.5	0	27.39	1330
13.25	99.5	60.5	1452	8.77	787	813	20.0	4.10	9450	65.6	0	27.77	1195
14.25	99.7	60.6	1454	8.95	802	827	20.0	3.85	9483	65.8	0	28.38	1215
15.25	98.7	60.0	1441	8.88	803	828	20.0	3.85	9483	65.2	0	28.48	1240
16.25	99.4	60.4	1451	8.57	770	793	20.0	3.85	9483	65.6	0	27.35	1310
17.25	99.4	60.4	1451	8.70	781	805	20.0	3.85	9483	65.6	0	27.63	1310
18.25	99.0	60.2	1445	8.79	793	817	20.0	3.85	9483	65.3	0	28.15	1245
19.25	100.3	61.0	1465	8.77	780	804	20.0	3.85	9483	66.2	0	27.70	1230
20.25	100.0	60.8	1460	8.91	795	820	20.0	3.85	9483	66.0	0	28.14	1205
21.25	98.9	60.1	1443	8.87	801	825	20.0	3.85	9483	65.2	0	28.37	1175
22.25	100.2	60.9	1462	8.73	777	801	20.0	3.85	9483	66.1	0	27.77	1250
23.25	99.5	60.5	1453	9.16	822	847	20.0	3.85	9480	65.7	0	29.10	1200
0.25	99.3	60.4	1450	9.25	831	857	20.0	3.85	9480	65.5	0	29.66	1210
1.25	99.3	60.4	1450	9.47	851	877	20.0	3.85	9480	65.5	0	30.18	1180
2.25	99.9	60.7	1458	9.26	827	853	20.0	3.85	9480	65.9	0	29.22	1255
3.25	99.5	60.4	1451	8.99	807	832	20.0	3.85	9480	65.6	0	28.69	1320
4.25	100.0	60.8	1459	9.14	817	842	20.0	3.85	9483	66.0	0	29.00	1300
5.25	100.3	60.9	1463	9.24	823	848	20.0	3.85	9483	66.2	0	29.10	1210
6.25	98.3	59.8	1435	9.00	817	842	20.0	3.85	9483	64.9	0	29.08	1310
7.25	99.8	60.7	1457	8.86	793	817	20.0	3.85	9483	65.9	0	28.03	1350

0.00 - 7.29													
MAX	101.3	61.6	1478.	9.58	867.	894.	20.0	3.85	9484.	66.8	0.	30.75	1350.
MIN	97.9	59.5	1429.	8.76	779.	883.	20.0	3.85	9481.	64.6	0.	27.64	1180.
MEAN	99.7	60.6	1455.	9.18	822.	847.	20.0	3.85	9481.	65.8	0.	29.15	1257. 7.49
ACCH	746.5	453.9		68.69	822.	847.	20.0	3.85			0.	29.15	1247. 369.6
0.00 - 0.00													
MAX	101.6	61.0	1482.	9.36	845.	871.	20.0	4.11	9484.	67.1	0.	29.98	1345.
MIN	96.9	58.8	1411.	8.29	742.	767.	20.0	3.85	9451.	63.8	0.	26.24	1175.
MEAN	99.7	60.6	1455.	8.83	791.	817.	20.0	4.00	9466.	65.8	0.	28.01	1273. 24.02
ACCH	2393.0	1454.9		211.90	791.	817.	20.0	4.00			0.	28.01	1276. 362.2

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI	KLO	CL-LS		KCONTRL		
	PROD	KCAL	KF-LS	C3S		LTWT	FCAO			CL-MS	KM2F1*			
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.26	99.9	60.7	8.90	795	106.2	0.870	2.450	48.1	34.3	1310	230	0.24	0.910	2.530
8.26	99.4	60.4	9.22	828	106.2	0.870	2.450	48.1	34.3	1350	222	0.24	0.910	2.530
9.26	99.8	60.6	9.12	816	111.4	0.930	2.370	63.0	34.3	1295	210	0.24	0.910	2.530
10.26	100.3	60.9	8.91	793	111.4	0.930	2.370	63.0	34.3	1235	231	0.24	0.910	2.530
11.26	99.2	60.3	9.06	816	111.4	0.930	2.370	63.0	34.3	1335	252	0.24	0.910	2.530
12.26	100.1	60.8	9.05	808	105.0	0.860	2.450	45.8	34.1	1255	235	0.24	0.900	2.600
13.26	100.3	61.0	8.86	789	105.0	0.860	2.450	45.8	34.1	1245	242	0.24	0.900	2.600
14.26	100.2	60.9	8.74	779	105.0	0.860	2.450	45.8	34.1	1295	253	0.24	0.900	2.600
15.26	98.7	60.0	9.05	818	105.0	0.860	2.450	45.8	34.1	1230	252	0.24	0.900	2.600
16.26	100.0	60.8	9.07	810	105.0	0.860	2.450	45.8	34.1	1280	241	0.24	0.900	2.600
17.26	99.6	60.5	8.74	784	107.4	0.870	2.540	48.9	34.1	1260	249	0.24	0.900	2.600
18.26	99.5	60.5	8.69	779	107.4	0.870	2.540	48.9	34.1	1310	271	0.24	0.900	2.600
19.26	101.0	61.4	8.82	780	107.4	0.870	2.540	48.9	34.1	1240	244	0.24	0.900	2.600
20.26	98.7	60.0	8.79	795	107.4	0.870	2.540	48.9	34.1	1215	224	0.24	0.900	2.600
21.26	99.4	60.4	8.92	801	107.4	0.870	2.540	48.9	34.1	1255	245	0.24	0.900	2.600
22.26	100.2	60.9	8.73	778	107.4	0.870	2.540	48.9	34.1	1220	230	0.24	0.900	2.600
23.26	99.4	60.4	8.49	763	107.4	0.870	2.540	48.9	34.1	1330	251	0.24	0.900	2.600
0.25	100.1	60.9	8.47	755	107.4	0.870	2.540	48.9	34.1	1280	270	0.24	0.900	2.600
1.25	99.3	60.4	8.57	770	107.4	0.870	2.540	48.9	34.1	1260	239	0.24	0.900	2.600
2.25	100.1	60.9	8.57	764	107.4	0.870	2.540	48.9	34.1	1250	222	0.24	0.900	2.600
3.25	99.3	60.4	8.56	769	107.4	0.870	2.540	48.9	34.1	1270	208	0.24	0.900	2.600
4.25	98.2	59.7	8.54	776	107.4	0.870	2.540	48.9	34.1	1250	194	0.24	0.900	2.600
5.25	99.0	60.2	8.49	766	107.4	0.870	2.540	48.9	34.1	1280	187	0.24	0.900	2.600
6.25	99.2	60.3	8.51	766	107.4	0.870	2.540	48.9	34.1	1300	199	0.24	0.900	2.600
7.25	99.8	60.7	8.69	777	107.4	0.870	2.540	48.9	34.1	1250	185	0.24	0.900	2.600

0.00 - 7.25																
MAX	101.3	61.6	8.88	824	107.4	0.870	2.540	48.9	34.1	1330	274	0.24	0.900	2.600		
MIN	92.8	56.4	8.27	738	107.4	0.870	2.540	48.9	34.1	1250	173	0.24	0.900	2.600		
MEAN	99.4	60.4	8.54	768	107.4	0.870	2.540	48.9	34.1	1270	211	0.24	0.900	2.600	7.43	7.43
ACCM	738.7	449.1	63.49	768	107.4	0.870	2.540	48.9	34.1	1270	211	0.24	0.900	2.600	277.3	393.3
0.00 - 0.00																
MAX	101.4	61.7	9.58	867	111.4	0.930	2.540	63.1	34.3	1350	280	0.24	0.910	2.600		
MIN	97.9	59.5	8.34	744	105.0	0.860	2.370	45.8	34.1	1190	199	0.24	0.900	2.530		
MEAN	99.8	60.7	8.98	804	107.2	0.877	2.466	50.2	34.2	1261	239	0.24	0.905	2.565	24.02	24.02
ACCM	2394.4	1455.8	215.55	804	107.3	0.878	2.467	50.5	34.2	1257	239	0.24	0.905	2.565	269.9	386.0

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3 KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ X02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ XCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.26	1.9	32.9	121	3.52	804	193	775	291	611	388	379	393	611	-0.01	860	
8.26	1.9	30.9	125	3.16	806	207	778	321	620	389	384	396	607	0.01	864	
9.26	1.9	33.9	126	2.99	805	194	783	338	617	393	386	396	606	-0.01	861	
10.26	1.9	34.5	125	2.69	807	211	784	333	622	389	383	395	615	0.00	863	
11.26	1.9	32.6	124	2.80	804	201	783	333	614	389	383	395	601	-0.01	862	
12.26	1.9	34.7	131	2.55	806	210	786	333	620	391	381	396	607	0.00	858	
13.26	1.9	34.8	127	2.79	805	211	787	328	619	390	384	395	600	0.00	859	
14.26	1.9	32.7	116	3.06	804	200	777	339	614	388	383	395	595	0.01	864	
15.26	1.9	32.9	126	2.94	805	208	779	338	619	387	382	394	596	0.00	859	
16.26	1.9	33.8	120	2.72	806	195	779	333	617	389	382	397	582	0.00	852	
17.26	1.9	34.9	123	5.36	805	199	779	333	621	388	383	393	584	0.00	857	
18.26	1.9	33.0	120	2.95	803	192	779	335	614	386	383	394	590	0.01	859	
19.26	1.9	31.6	125	2.61	804	212	779	334	622	390	382	395	601	0.00	855	
20.26	1.9	33.2	117	2.88	805	191	780	328	619	392	385	397	600	0.00	856	
21.26	1.9	32.7	120	2.94	805	210	781	300	618	394	388	398	588	0.01	852	
22.26	1.9	33.5	128	3.01	803	200	777	326	618	390	384	397	590	0.00	842	
23.26	1.9	31.2	138	3.29	801	222	774	328	611	388	381	394	592	0.00	840	
0.25	1.9	26.4	130	3.27	801	204	776	320	615	386	382	395	586	0.00	842	
1.25	1.9	23.0	136	3.19	801	220	773	322	617	390	384	397	585	0.00	837	
2.25	1.9	21.0	124	3.62	801	208	771	314	615	391	385	397	573	0.00	836	
3.25	1.9	19.9	103	3.66	801	184	778	304	616	394	382	401	575	0.00	835	
4.25	1.9	19.1	119	3.59	801	200	776	306	619	393	387	398	586	-0.01	839	
5.25	1.9	18.3	106	3.59	802	179	771	305	610	392	387	397	567	0.00	835	
6.25	1.9	16.9	121	3.83	801	204	775	308	616	388	384	397	587	-0.01	840	
7.25	1.9	19.3	122	3.18	801	210	768	317	622	394	385	397	583	0.00	840	

0.00 - 7.27															
MAX	2.0	27.9	147.	4.21	805.	234.	782.	340.	628.	399.	394.	404.	601.	0.02	850.
MIN	2.0	16.8	97.	2.66	798.	166.	765.	294.	607.	385.	380.	389.	567.	-0.04	827.
MEAN	2.0	20.5	120.	3.52	801.	199.	774.	314.	617.	392.	386.	397.	583.	-0.01	838.
ACCH	2.0	20.5	120.		801.	199.	774.	314.	617.	392.	386.	397.	583.	-0.01	838.
0.00 - 0.00															
MAX	2.0	39.4	155.	10.48	811.	242.	792.	354.	630.	397.	392.	403.	625.	0.03	870.
MIN	2.0	27.8	107.	1.84	799.	176.	769.	277.	609.	383.	374.	387.	566.	-0.04	835.
MEAN	2.0	33.4	126.	2.96	805.	205.	780.	330.	619.	390.	383.	395.	601.	0.00	858.
ACCH	2.0	33.4	126.		805.	205.	780.	330.	619.	390.	383.	395.	601.	0.00	858.

PLANT REPORT 3 KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME

W1/ NOX REG STIME

W1/ LTW FOR CONTRL

W1/ ESTIMATED LTW

U1/ LITER WEIGHT

KILN CON. MEASUR.

KILN CONTROL

COAL TO KILN

W1/ NOX CHANGE LT

W1/ T EXIT PREHEAT

W1/ A50T1 CHANGE

W1/ Z02 KILN OUTL

W1/ Z00 EX PREHEAT

W1/ COAL TO KILN

J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		LTWT	LTWGTSP		NOXLT	A50T1	OA15X1	OA1X2C0	OA2V1					
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM	
7.26				1310	1288	1290	30.3	30.5	-0.121	393	-0.32	3.52	-0.01	8.90	860
8.26				1350	1226	1232	21.5	21.1	-0.007	396	0.25	3.16	0.01	9.22	864
9.26				1205	1263	1277	26.1	26.3	0.193	396	0.44	2.99	-0.01	9.12	861
10.26				1235	1289	1292	29.5	29.6	-0.028	395	-0.23	2.69	0.00	8.91	863
11.26				1335	1250	1270	24.7	25.0	-0.040	395	0.13	2.80	-0.01	9.06	862
12.26				1255	1266	1288	27.0	26.7	0.056	396	-0.22	2.55	0.00	9.05	858
13.26				1245	1298	1315	29.6	29.9	0.092	395	0.10	2.79	0.00	8.86	859
14.26				1295	1255	1258	24.5	25.0	-0.219	395	0.04	3.06	0.01	8.74	864
15.26				1230	1220	1246	21.3	21.2	-0.117	394	-0.02	2.94	0.00	9.05	859
16.26				1200	1262	1274	26.0	25.8	0.193	397	0.15	2.72	0.00	9.07	852
17.26				1260	1301	1298	30.0	30.3	0.039	393	0.00	5.36	0.00	8.74	857
18.26				1310	1282	1281	29.0	28.2	-0.260	394	-0.16	2.95	0.01	8.69	859
19.26				1240	1264	1262	26.4	26.1	0.000	395	0.10	2.61	0.00	8.82	855
20.26				1215	1254	1263	26.0	26.0	-0.032	397	-0.12	2.88	0.00	8.79	856
21.26				1255	1232	1235	25.0	24.0	-0.143	398	0.20	2.94	0.01	8.92	852
22.26				1220	1342	1325	34.1	34.0	0.217	397	0.01	3.01	0.00	8.73	842
23.26				1330	1313	1285	31.8	31.4	-0.188	394	0.13	3.29	0.00	8.49	840
0.25				1280	1290	1288	29.6	29.0	-0.097	395	0.06	3.27	0.00	8.47	842
1.25				1260	1258	1258	27.3	26.6	-0.085	397	-0.03	3.19	0.00	8.57	837
2.25				1250	1272	1268	29.1	28.6	-0.002	397	-0.15	3.62	0.00	8.57	836
3.25				1270	1282	1278	29.5	29.8	-0.067	401	0.12	3.66	0.00	8.56	835
4.25				1250	1270	1262	31.4	30.2	-0.007	398	-0.16	3.59	-0.01	8.54	839
5.25				1280	1304	1294	32.8	32.6	0.059	397	-0.13	3.59	0.00	8.49	835
6.25				1300	1195	1216	25.5	24.8	-0.249	397	-0.12	3.83	-0.01	8.51	840
7.25				1250	1250	1250	26.4	26.6	0.127	397	-0.04	3.18	0.00	8.69	840

0.00 - 7.28

MAX				1330.	1311.	1304.	33.4	33.2	0.206	404.	0.41	4.21	0.02	8.88	850.
MIN				1250.	1188.	1210.	23.7	24.2	-0.359	389.	-0.27	2.66	-0.04	8.27	827.
MEAN	7.48	7.48		1269.	1269.	1269.	29.0	29.0	-0.023	397.	0.01	3.52	-0.01	8.55	838.
ACCM	393.4	277.3		1270.		1269.			-0.023	397.	0.01		-0.01	63.86	838.

0.00 - 0.00

MAX				1350.	1376.	1343.	35.4	35.6	0.552	403.	0.48	10.48	0.03	9.58	870.
MIN				1180.	1213.	1208.	17.6	17.7	-0.609	387.	-0.64	1.84	-0.04	8.34	835.
MEAN	24.02	24.02		1261.	1278.	1273.	27.6	27.6	0.014	395.	0.00	2.96	0.00	8.98	858.
ACCM	386.0	269.9		1257.		1273.			0.014	395.	0.00		0.00	215.55	858.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL

Z MOISTURE IN COAL

NET HEAT CONSUMP.

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUC. RATE

KILN PRODUCTION

W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER

LB COAL / SH. T

MBTU' PER SH. T

U1/ LITER WEIGHT

COAL TO KILN

HOUR	HD10F1		PRODR	KCAL		C-MOIST		C-HEAT	STONS	BTU	LTWT		
	PROD			KM2F1	NKCAL	Z	Z		LB. COAL		KM2F1*		
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z	T/H		GR/L	H	
7.26	99.9	60.7	1458	8.90	795	820	20.0	3.85	9483	65.9	0	28.16	1318
8.26	99.4	60.4	1451	9.22	828	853	20.0	3.85	9483	65.6	0	29.43	1350
9.26	99.8	60.6	1456	9.12	816	841	20.0	3.85	9483	65.8	0	28.86	1285
10.26	100.3	60.9	1463	8.91	793	818	20.0	3.85	9483	66.2	0	28.14	1235
11.26	99.2	60.3	1447	9.06	816	841	20.0	3.85	9483	65.4	0	28.92	1335
12.26	100.1	60.8	1460	9.05	808	833	20.0	3.69	9483	66.0	0	28.75	1255
13.26	100.3	61.0	1464	8.86	789	812	20.0	3.69	9501	66.2	0	28.10	1245
14.26	100.2	60.9	1462	8.74	779	801	20.0	3.69	9501	66.1	0	27.70	1295
15.26	98.7	60.8	1441	9.05	818	842	20.0	3.69	9501	65.2	0	28.96	1230
16.26	100.0	60.8	1459	9.07	810	833	20.0	3.69	9501	66.0	0	29.00	1200
17.26	99.6	60.5	1454	8.74	784	806	20.0	3.69	9501	65.7	0	27.82	1260
18.26	99.5	60.5	1452	8.69	779	801	20.0	3.69	9501	65.7	0	27.71	1310
19.26	101.0	61.4	1474	8.82	780	802	20.0	3.69	9501	66.6	0	27.75	1240
20.26	98.7	60.8	1440	8.79	795	818	20.0	3.69	9501	65.1	0	28.26	1215
21.26	99.4	60.4	1450	8.92	801	824	20.0	3.69	9498	65.6	0	28.35	1255
22.26	100.2	60.9	1462	8.73	778	801	20.0	3.69	9501	66.1	0	27.59	1220
23.26	99.4	60.4	1451	8.49	763	785	20.0	3.69	9498	65.6	0	27.84	1330
0.25	100.1	60.9	1462	8.47	755	776	20.0	3.69	9501	66.1	0	26.87	1280
1.25	99.3	60.4	1450	8.57	770	792	20.0	3.69	9498	65.5	0	27.28	1260
2.25	100.1	60.9	1462	8.57	764	786	20.0	3.69	9501	66.1	0	27.16	1250
3.25	99.3	60.4	1450	8.56	769	791	20.0	3.69	9501	65.6	0	27.36	1270
4.25	98.2	59.7	1434	8.54	776	798	20.0	3.69	9501	64.8	0	27.61	1250
5.25	99.0	60.2	1445	8.49	766	788	20.0	3.69	9501	65.3	0	27.29	1280
6.25	99.2	60.3	1448	8.51	766	787	20.0	3.69	9501	65.5	0	27.23	1300
7.25	99.8	60.7	1457	8.69	777	800	20.0	3.69	9501	65.9	0	27.63	1250

0.00 - 7.29													
MAX	101.3	61.6	1478.	8.88	824.	848.	20.0	3.69	9502.	66.8	0.	29.38	1330.
MIN	92.8	56.4	1355.	8.27	738.	759.	20.0	3.69	9499.	61.3	0.	26.23	1250.
MEAN	99.4	60.4	1451.	8.55	768.	790.	20.0	3.69	9501.	65.6	0.	27.29	1269. 7.49
ACCH	744.0	452.4		63.96	768.	790.	20.0	3.69		0.	27.29	1270.	393.4

0.00 - 0.00													
MAX	101.4	61.7	1480.	9.58	867.	894.	20.0	3.85	9502.	66.9	0.	30.75	1350.
MIN	97.9	59.5	1429.	8.34	744.	766.	20.0	3.69	9481.	64.6	0.	26.44	1180.
MEAN	99.8	60.7	1456.	8.98	804.	828.	20.0	3.77	9491.	65.8	0.	28.55	1261. 24.02
ACCH	2394.4	1455.8		215.55	804.	828.	20.0	3.77		0.	28.55	1257.	386.0

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S

W1/ KILN FEED MS

W1/ KILN FEED LSF

W1/ BURNING FACTOR

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUCTION

W1/ KILN FEED

W1/ FEED LOSS-0-1G

U1/ LITER WEIGHT

U1/ CLINKER TEMP

U1/ FREE LIME

U1/ CLINKER LSF

U1/ CLINKER MS

KILN CONTROL

COAL TO KILN

HOUR	HD10F1		KM2F1		BF		KF-MS		KF-LOT		KLO		CL-LS		KCONTRL	
	PROD		KCAL		KF-LS		C3S		LTWT		FCAO		CL-MS		KM2F1*	
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H					
7.25	100.1	60.8	8.68	775	107.4	0.870	2.540	48.9	34.1	1300	182	0.24	0.900	2.600		
8.25	100.7	61.2	9.52	844	107.4	0.870	2.540	48.9	34.1	1265	197	0.24	0.900	2.600		
9.25	99.3	60.4	8.41	756	107.4	0.870	2.540	48.9	34.1	1265	195	0.24	0.900	2.600		
10.25	98.5	59.9	9.08	823	106.4	0.870	2.450	48.7	34.1	1260	166	0.24	0.900	2.600		
11.25	99.9	60.7	8.97	802	106.4	0.870	2.450	48.7	34.1	1140	169	0.24	0.900	2.600		
12.25	99.2	60.3	9.04	814	106.4	0.870	2.450	48.7	34.1	1235	240	0.24	0.900	2.600		
13.25	99.0	60.2	8.89	802	108.7	0.900	2.440	55.8	34.4	1100	195	0.24	0.920	2.560		
14.25	99.6	60.5	8.94	881	108.7	0.900	2.440	55.8	34.4	1220	210	0.24	0.920	2.560		
15.25	100.8	61.2	8.94	792	108.7	0.900	2.440	55.8	34.4	1255	219	0.24	0.920	2.560		
16.25	101.5	61.7	8.98	790	109.1	0.900	2.420	56.2	34.4	1280	240	0.24	0.920	2.560		
17.25	101.0	61.4	9.04	799	109.1	0.900	2.420	56.2	34.4	1250	237	0.24	0.920	2.560		
18.25	101.0	61.4	8.95	791	109.1	0.900	2.420	56.2	34.4	1270	281	0.24	0.920	2.560		
19.25	103.1	62.7	8.99	778	109.1	0.900	2.420	56.2	34.4	1185	238	0.24	0.920	2.560		
20.25	103.4	62.8	9.24	798	109.1	0.900	2.420	56.2	34.4	1385	243	0.24	0.920	2.560		
21.25	102.7	62.4	9.26	805	109.1	0.900	2.420	56.2	34.4	1290	257	0.24	0.920	2.560		
22.25	103.1	62.7	8.96	776	109.1	0.900	2.420	56.2	34.4	1280	269	0.24	0.920	2.560		
23.25	102.2	62.1	9.23	807	108.0	0.890	2.440	52.9	34.4	1290	269	0.24	0.920	2.560		
0.25	104.0	63.2	9.29	798	108.0	0.890	2.440	52.9	34.4	1245	251	0.24	0.920	2.560		
1.25	102.7	62.4	9.29	807	108.0	0.890	2.440	52.9	34.4	1275	267	0.24	0.920	2.560		
2.25	102.5	62.3	9.27	807	108.0	0.890	2.440	52.9	34.4	1250	249	0.24	0.920	2.560		
3.25	102.2	62.1	9.21	804	108.0	0.890	2.440	52.9	34.4	1275	239	0.24	0.920	2.560		
4.25	102.5	62.3	9.07	790	108.0	0.890	2.440	52.9	34.4	1360	228	0.24	0.920	2.560		
5.25	102.6	62.4	9.05	787	108.0	0.890	2.440	52.9	34.4	1330	258	0.24	0.920	2.560		
6.25	103.0	62.6	9.31	807	108.0	0.890	2.440	52.9	34.4	1330	285	0.24	0.920	2.560		
7.25	103.6	63.0	9.37	807	108.0	0.890	2.440	52.9	34.4	1320	223	0.24	0.920	2.560		

0.00 - 7.25	
MAX	104.4 63.5 9.52 829. 108.0 0.890 2.440 53.0 34.4 1360. 275. 0.24 0.920 2.560
MIN	101.2 61.5 8.81 764. 108.0 0.890 2.440 53.0 34.4 1245. 192. 0.24 0.920 2.560
MEAN	102.9 62.5 9.21 800. 108.0 0.890 2.440 53.0 34.4 1298. 241. 0.24 0.920 2.560 4.03 7.43
ACCH	764.4 464.8 68.46 800. 108.0 0.890 2.440 53.0 34.4 1299. 241. 0.24 0.920 2.560 291.5 417.0
0.00 - 0.00	
MAX	104.7 63.7 9.88 889. 109.1 0.900 2.540 56.2 34.4 1330. 310. 0.24 0.920 2.600
MIN	92.8 56.4 8.27 738. 106.4 0.870 2.420 48.7 34.1 1100. 138. 0.24 0.900 2.560
MEAN	100.5 61.1 8.85 787. 107.9 0.884 2.477 52.1 34.2 1251. 222. 0.24 0.909 2.583 17.82 24.02
ACCH	2411.9 1466.4 212.50 787. 107.9 0.883 2.472 52.1 34.2 1255. 222. 0.24 0.909 2.582 287.6 409.7

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ ID2 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCD EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CD	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	18.5	111	3.57	801	189	774	310	618	392	387	397	581	-0.01	839	
8.25	1.9	21.3	102	3.76	802	193	770	295	625	399	390	403	580	0.00	841	
9.25	1.9	21.0	127	3.35	802	214	771	320	613	387	383	394	586	-0.01	844	
10.25	1.9	23.6	121	2.38	803	217	772	332	612	386	384	394	601	0.00	845	
11.25	1.9	28.1	120	1.23	804	211	773	338	619	396	387	398	614	0.00	857	
12.25	1.9	29.0	117	2.15	806	208	783	329	628	398	392	404	604	0.00	860	
13.25	1.9	29.9	121	1.84	804	214	781	330	630	398	389	402	602	0.00	872	
14.25	1.9	33.0	110	2.27	804	203	779	335	619	396	390	402	606	0.00	871	
15.25	1.9	31.2	113	2.31	807	201	787	333	633	398	390	404	606	0.03	871	
16.25	1.9	31.8	113	2.70	810	211	785	320	628	394	385	399	591	0.02	870	
17.25	1.9	31.8	103	2.05	811	193	788	315	623	394	385	398	580	0.01	870	
18.25	1.9	33.7	106	3.40	808	195	786	315	626	389	381	397	574	0.03	872	
19.25	1.9	31.4	108	2.73	811	185	787	316	633	394	388	401	578	0.01	862	
20.25	1.9	33.8	108	3.01	812	194	789	319	627	384	378	393	582	0.01	846	
21.25	1.9	34.1	123	2.99	810	205	791	327	630	392	384	398	600	0.01	850	
22.25	1.9	33.6	111	3.23	811	190	790	323	622	393	383	398	598	0.03	849	
23.25	1.9	31.2	115	2.35	811	198	788	323	619	387	380	394	578	0.02	847	
0.25	1.9	30.3	124	2.25	808	203	783	326	621	392	383	397	610	0.02	853	
1.25	1.9	32.7	114	1.95	807	194	786	322	626	392	384	397	605	0.02	864	
2.25	1.9	29.7	111	2.01	809	194	785	316	626	394	383	398	613	0.00	869	
3.25	1.9	31.0	115	2.83	809	198	787	324	623	394	386	398	597	0.01	868	
4.25	1.9	30.5	117	3.14	806	202	782	329	623	394	386	400	611	0.00	863	
5.25	1.9	28.9	112	2.84	807	207	784	311	618	389	380	395	591	0.00	859	
6.25	1.9	27.8	124	2.15	809	201	780	321	620	389	381	393	596	-0.01	858	
7.25	1.9	29.4	119	1.57	811	204	786	314	619	392	383	396	602	0.00	854	

0.00 - 7.27

MAX	2.0	35.5	135.	3.45	814.	225.	794.	344.	637.	402.	392.	405.	634.	0.04	873.
MIN	2.0	26.7	104.	0.91	806.	172.	775.	300.	610.	383.	376.	390.	573.	-0.02	845.
MEAN	2.0	30.2	117.	2.34	809.	198.	785.	323.	623.	392.	383.	397.	603.	0.01	862.
ACCN	2.0	30.2	117.		809.	198.	785.	323.	623.	392.	383.	397.	603.	0.01	862.

0.00 - 0.00

MAX	2.0	38.0	147.	10.34	816.	242.	797.	358.	638.	404.	397.	410.	643.	0.06	879.
MIN	2.0	16.8	78.	0.51	794.	143.	764.	278.	607.	381.	373.	387.	517.	-0.04	827.
MEAN	2.0	26.9	116.	3.01	805.	200.	780.	322.	622.	393.	386.	399.	592.	0.00	852.
ACCN	2.0	26.9	116.		805.	200.	780.	322.	622.	393.	386.	399.	592.	0.00	852.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ Z00 EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		LTWT	LTWGTSP		NOXL	A50T1	OA15X1	OA1X2C0	OA2V1					
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM	
7.25				1300	1193	1213	25.5	24.6	-0.035	397	-0.01	3.57	-0.01	8.68	839
8.25				1265	1247	1271	25.7	26.0	-0.206	403	0.13	3.76	0.00	9.52	841
9.25				1265	1262	1262	27.3	28.6	0.051	394	-0.16	3.35	-0.01	8.41	844
10.25				1260	1193	1214	14.0	14.1	-0.391	394	0.20	2.38	0.00	9.08	845
11.25				1140	1185	1247	12.4	12.4	-0.103	398	0.15	1.23	0.00	8.97	857
12.25				1235	1244	1275	18.4	19.3	-0.016	404	0.46	2.15	0.00	9.04	860
13.25				1100	1242	1264	23.9	25.5	0.436	402	-0.06	1.84	0.00	8.89	872
14.25				1220	1272	1251	30.6	31.8	0.120	402	0.24	2.27	0.00	8.94	871
15.25				1255	1263	1250	30.3	30.5	-0.060	404	0.49	2.31	0.03	8.94	871
16.25				1200	1254	1247	28.7	28.5	-0.067	399	-0.37	2.70	0.02	8.98	870
17.25				1250	1264	1258	31.8	32.3	0.227	398	-0.03	2.05	0.01	9.04	870
18.25				1270	1230	1263	25.8	24.9	-0.279	397	-0.10	3.40	0.03	8.95	872
19.25				1185	1246	1218	30.0	30.2	0.276	401	0.40	2.73	0.01	8.99	862
20.25				1305	1250	1262	30.0	29.4	-0.135	393	-0.90	3.01	0.01	9.24	846
21.25				1290	1275	1270	31.6	31.4	0.144	398	0.56	2.99	0.01	9.26	850
22.25				1200	1258	1259	30.2	29.9	-0.195	398	0.03	3.23	0.03	8.96	849
23.25				1290	1248	1253	29.2	28.8	-0.081	394	0.10	2.35	0.02	9.23	847
0.25				1245	1270	1266	31.1	30.5	0.060	397	0.15	2.25	0.02	9.29	853
1.25				1275	1269	1269	30.2	30.5	-0.103	397	0.03	1.95	0.02	9.29	864
2.25				1250	1245	1249	29.1	28.5	-0.017	398	0.00	2.01	0.00	9.27	869
3.25				1275	1343	1335	36.6	36.6	0.147	398	-0.26	2.03	0.01	9.21	868
4.25				1360	1310	1276	32.3	33.9	-0.258	400	0.36	3.14	0.00	9.07	863
5.25				1330	1234	1245	28.0	27.7	-0.343	395	-0.05	2.84	0.00	9.05	859
6.25				1330	1167	1207	22.1	22.1	-0.171	393	0.12	2.15	-0.01	9.31	858
7.25				1320	1285	1274	31.6	32.5	0.446	396	0.01	1.57	0.00	9.37	854

0.00 - 7.28

MAX				1360	1361	1354	38.1	38.1	0.449	405	0.60	3.45	0.04	9.52	873
MIN				1245	1157	1204	21.5	21.4	-0.347	390	-0.63	0.91	-0.02	8.81	845
MEAN	7.48	4.07		1298	1269	1267	30.6	30.5	-0.003	397	0.00	2.34	0.01	9.21	862
ACCM	417.1	291.6		1299		1267			-0.003	397	0.00		0.01	68.86	862

0.00 - 0.00

MAX				1330	1311	1304	34.5	33.8	0.596	410	0.96	10.34	0.06	9.88	879
MIN				1100	1182	1102	11.7	11.6	-0.520	387	-1.10	0.51	-0.04	8.27	827
MEAN	24.02	17.02		1251	1254	1258	27.4	27.4	-0.001	399	0.00	3.01	0.00	8.85	852
ACCM	409.7	287.6		1255		1258			-0.001	399	0.00		0.00	212.50	852

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS	BTU	LTWT
	PROD		KM2F1		NKCAL		C-ASH				LB. COAL		KM2F1*
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%			T/H		GR/L
7.25	100.1	60.8	1460	8.68	775	797	20.0	3.69	9501	66.0	0	27.58	1300
8.25	100.7	61.2	1469	9.52	844	868	20.0	3.69	9498	66.4	0	30.84	1265
9.25	99.3	60.4	1449	8.41	756	778	20.0	3.69	9498	65.5	0	26.77	1265
10.25	98.5	59.9	1437	9.08	823	846	20.0	3.69	9501	65.0	0	29.15	1260
11.25	99.9	60.7	1458	8.97	802	825	20.0	3.69	9498	65.9	0	28.47	1140
12.25	99.2	60.3	1448	9.04	814	837	20.0	3.69	9498	65.4	0	28.85	1235
13.25	99.0	60.2	1445	8.89	802	827	20.0	3.84	9484	65.3	0	28.40	1100
14.25	99.6	60.5	1454	8.94	801	826	20.0	3.84	9484	65.7	0	28.28	1220
15.25	100.8	61.2	1470	8.94	792	817	20.0	3.84	9484	66.5	0	28.00	1255
16.25	101.5	61.7	1481	8.98	790	814	20.0	3.84	9484	67.0	0	28.01	1280
17.25	101.0	61.4	1474	9.04	799	823	20.0	3.84	9484	66.7	0	28.33	1250
18.25	101.0	61.4	1475	8.95	791	815	20.0	3.84	9484	66.7	0	28.22	1270
19.25	103.1	62.7	1505	8.99	778	802	20.0	3.84	9484	68.1	0	27.59	1185
20.25	103.4	62.8	1508	9.24	798	822	20.0	3.84	9484	68.2	0	28.40	1305
21.25	102.7	62.4	1499	9.26	805	829	20.0	3.84	9484	67.8	0	28.59	1290
22.25	103.1	62.7	1505	8.96	776	800	20.0	3.84	9484	68.0	0	27.58	1280
23.25	102.2	62.1	1491	9.23	807	831	20.0	3.84	9484	67.4	0	28.64	1290
0.25	104.0	63.2	1517	9.29	798	822	20.0	3.84	9484	68.6	0	28.33	1245
1.25	102.7	62.4	1499	9.29	807	832	20.0	3.84	9484	67.8	0	28.64	1275
2.25	102.5	62.3	1496	9.27	807	832	20.0	3.84	9484	67.6	0	28.68	1250
3.25	102.2	62.1	1491	9.21	804	829	20.0	3.84	9484	67.4	0	28.65	1275
4.25	102.5	62.3	1496	9.07	790	814	20.0	3.84	9484	67.6	0	28.13	1360
5.25	102.6	62.4	1498	9.05	787	811	20.0	3.84	9484	67.7	0	28.09	1330
6.25	103.0	62.6	1504	9.31	807	832	20.0	3.84	9484	68.0	0	28.59	1330
7.25	103.6	63.0	1513	9.37	807	832	20.0	3.84	9484	68.4	0	28.70	1320

0.00 - 7.29													
MAX	104.4	63.5	1525.	9.52	829.	854.	20.0	3.84	9485.	69.0	0.	29.41	1360.
MIN	101.2	61.5	1477.	8.81	764.	787.	20.0	3.84	9482.	66.8	0.	27.10	1245.
MEAN	102.9	62.5	1501.	9.21	800.	824.	20.0	3.84	9485.	67.9	0.	28.38	1298. 7.49
ACCH	770.0	468.2		68.96	800.	824.	20.0	3.84			0.	28.38	1299. 417.1
0.00 - 8.00													
MAX	104.7	63.7	1529.	9.08	889.	914.	20.0	3.84	9502.	69.1	0.	31.58	1330.
MIN	92.8	56.4	1355.	8.27	738.	759.	20.0	3.69	9482.	61.3	0.	26.23	1100.
MEAN	100.5	61.1	1466.	8.85	787.	810.	20.0	3.76	9492.	66.3	0.	27.94	1251. 24.02
ACCH	2411.9	1466.4		212.50	787.	810.	20.0	3.76			0.	27.94	1255. 489.7

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KN2F1		BF	KF-MS		KF-LOI		KLD	CL-LS		CL-MS	KN2F1*
	PROD			KCAL		KF-LS	C3S	LTWT	FCAO					
	T/H	T/H	T/H	KC/KG		Z	Z	GR/L	DEG.C	Z		H		
7.25	102.6	62.3	9.46	823	108.0	0.890	2.440	52.9	34.4	1330	217	0.24	0.920	2.560
8.25	103.0	62.6	9.10	788	107.7	0.880	2.500	51.3	34.4	1370	252	0.24	0.920	2.560
9.25	102.6	62.3	8.90	774	107.7	0.880	2.500	51.3	34.4	1430	243	0.24	0.920	2.560
10.25	103.1	62.6	8.59	744	107.7	0.880	2.500	51.3	34.4	1430	256	0.24	0.920	2.560
11.25	102.5	62.3	8.36	729	107.7	0.880	2.500	51.3	34.4	1395	254	0.24	0.920	2.560
12.25	104.1	63.3	8.15	699	107.7	0.880	2.500	51.3	34.4	1370	245	0.24	0.920	2.560
13.25	104.1	63.3	8.65	741	107.5	0.890	2.430	53.2	34.4	1280	227	0.24	0.910	2.520
14.25	104.8	63.7	8.55	729	107.5	0.890	2.430	53.2	34.4	1210	239	0.24	0.910	2.520
15.25	105.4	64.1	8.65	732	107.5	0.890	2.430	53.2	34.4	1215	234	0.24	0.910	2.520
16.25	105.6	64.2	8.39	710	105.8	0.850	2.610	43.8	34.4	1270	216	0.24	0.910	2.520
17.25	105.1	63.9	8.64	734	105.8	0.850	2.610	43.8	34.4	1285	243	0.24	0.910	2.520
18.25	104.4	63.5	8.94	764	105.8	0.850	2.610	43.8	34.4	1175	227	0.24	0.910	2.520
19.25	104.9	63.8	8.77	747	105.8	0.850	2.610	43.8	34.4	1250	231	0.24	0.910	2.520
20.25	105.7	64.2	8.42	711	105.8	0.850	2.610	43.8	34.4	1345	262	0.24	0.910	2.520
21.25	104.6	63.5	8.51	727	105.8	0.850	2.610	43.8	34.4	1300	264	0.24	0.910	2.520
22.25	104.6	63.6	8.78	750	105.8	0.850	2.610	43.8	34.4	1180	244	0.24	0.910	2.520
23.25	99.7	60.6	9.09	814	105.8	0.850	2.610	43.8	34.4	1125	233	0.24	0.910	2.520
0.25	104.3	63.4	8.96	767	105.8	0.850	2.610	43.8	34.4	1205	276	0.24	0.910	2.520
1.25	103.7	63.0	8.93	769	105.8	0.850	2.610	43.8	34.4	1310	270	0.24	0.910	2.520
2.25	105.0	63.8	8.93	760	105.8	0.850	2.610	43.8	34.4	1325	295	0.24	0.910	2.520
3.25	104.6	63.6	8.79	751	105.8	0.850	2.610	43.8	34.4	1315	284	0.24	0.910	2.520
4.25	104.7	63.6	8.88	757	110.9	0.920	2.420	60.8	34.4	1290	256	0.24	0.910	2.520
5.25	105.0	63.8	9.02	767	110.9	0.920	2.420	60.8	34.4	1230	266	0.24	0.910	2.520
6.25	104.1	63.3	8.98	770	110.9	0.920	2.420	60.8	34.4	1245	269	0.24	0.910	2.520
7.25	104.7	63.6	8.99	766	110.9	0.920	2.420	60.8	34.4	1390	261	0.24	0.910	2.520

0.00 - 7.25														
MAX	106.4	64.7	9.10	809	110.9	0.920	2.610	60.9	34.4	1390	310	0.24	0.910	2.520
MIN	98.6	60.1	8.66	735	105.8	0.850	2.420	43.9	34.4	1125	203	0.24	0.910	2.520
MEAN	104.5	63.6	8.93	763	107.9	0.879	2.531	50.9	34.4	1271	268	0.24	0.910	2.520
ACCH	776.8	472.3	66.33	763	108.0	0.880	2.529	51.2	34.4	1274	268	0.24	0.910	2.520

0.00 - 0.00														
MAX	106.4	64.8	9.52	831	108.0	0.890	2.610	53.2	34.4	1430	275	0.24	0.920	2.560
MIN	98.2	59.8	8.11	696	105.8	0.850	2.430	43.9	34.4	1125	192	0.24	0.910	2.520
MEAN	103.6	63.0	8.83	762	107.1	0.874	2.510	49.5	34.4	1294	242	0.24	0.915	2.542
ACCH	2496.4	1511.7	212.01	762	107.0	0.873	2.515	49.3	34.4	1299	242	0.24	0.915	2.540

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ XCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.25	1.9	27.5	116	2.28	810	198	788	324	626	393	382	396	602	0.00	856	
8.25	1.9	30.0	114	3.01	811	193	789	317	630	394	385	398	589	-0.03	854	
9.25	1.9	29.0	111	2.74	812	199	793	318	628	394	384	398	583	-0.01	856	
10.25	1.9	30.1	111	2.75	810	203	791	329	620	392	382	397	587	0.00	851	
11.25	1.9	29.3	106	2.97	811	182	785	310	617	386	379	393	570	-0.01	857	
12.25	1.9	28.7	106	4.09	808	205	787	333	623	388	382	393	616	-0.01	864	
13.25	1.9	27.8	112	3.07	807	196	786	321	619	385	375	392	603	0.00	861	
14.25	1.9	31.7	120	3.06	807	214	781	337	615	383	376	393	599	0.00	868	
15.25	1.9	30.6	116	2.84	810	212	784	335	620	386	379	394	609	0.00	867	
16.25	1.9	31.7	108	3.68	809	202	789	334	619	389	379	393	595	-0.01	868	
17.25	1.9	32.1	111	3.40	809	196	784	329	615	387	377	393	597	0.00	870	
18.25	1.9	32.1	114	2.57	812	207	789	334	623	390	383	397	602	0.00	865	
19.25	1.9	34.4	123	2.43	811	207	793	335	620	392	383	395	595	0.00	866	
20.25	1.9	33.9	110	3.22	809	207	784	330	622	386	381	393	599	0.00	866	
21.25	1.9	32.1	114	3.44	807	198	783	336	622	388	380	395	598	-0.01	864	
22.25	1.9	33.0	125	3.28	810	211	788	342	620	389	381	394	613	-0.02	862	
23.25	1.8	34.9	123	2.86	809	203	792	334	634	398	390	403	600	-0.01	867	
0.25	1.8	35.8	105	3.10	813	198	788	327	626	395	388	403	604	-0.01	869	
1.25	1.9	34.7	113	3.15	812	200	794	329	630	396	386	402	603	-0.02	867	
2.25	1.9	33.2	121	3.64	813	198	788	335	627	401	392	407	624	-0.02	869	
3.25	1.9	31.7	106	4.00	810	198	787	329	631	396	386	402	604	-0.02	869	
4.25	1.9	31.0	106	10.43	811	188	791	337	637	400	391	407	610	-0.01	870	
5.25	1.9	32.0	108	10.41	811	190	788	319	626	395	386	403	598	-0.02	866	
6.25	1.9	29.2	110	3.44	812	190	786	325	633	399	390	403	613	-0.02	870	
7.25	1.9	27.3	116	3.76	811	201	791	334	631	403	393	407	632	-0.01	868	

0.00 - 7.27

MAX	2.0	38.6	133.	10.48	816.	229.	797.	360.	642.	406.	397.	410.	641.	0.02	879.
MIN	1.9	26.9	97.	2.54	808.	173.	783.	306.	617.	387.	381.	396.	573.	-0.05	857.
MEAN	2.0	32.0	113.	5.10	812.	199.	790.	331.	630.	398.	389.	404.	611.	-0.02	870.
ACCH	2.0	32.0	113.		812.	199.	790.	331.	630.	398.	389.	404.	611.	-0.02	870.

0.00 - 0.00

MAX	2.0	40.1	136.	5.53	817.	236.	799.	360.	642.	407.	397.	412.	634.	0.04	877.
MIN	1.9	26.7	90.	0.91	805.	169.	775.	288.	610.	381.	374.	387.	564.	-0.04	845.
MEAN	2.0	31.1	114.	2.85	810.	200.	786.	327.	623.	391.	382.	396.	599.	-0.00	862.
ACCH	2.0	31.1	114.		810.	200.	786.	327.	623.	391.	382.	396.	599.	-0.00	862.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	W1/ ZCO EX PREHEAT
KILN CON. MEASUR.	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1#	KALARM	ESTLTW		NOXST		NOXALT		A50ALT		KM2F1			
	H	H	LTWT	LTWGTSP	NOXL	A50T1	OA15X1	OA1X2CO	OA2V1	T/H	RPM			
			GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%		
7.25			1330	1214	1228	25.8	26.1	0.229	396	0.13	2.28	0.00	9.46	856
8.25			1370	1356	1323	49.9	47.4	0.796	398	0.22	3.01	-0.03	9.10	854
9.25			1430	1300	1284	37.8	35.7	-0.428	398	-0.03	2.74	-0.01	8.90	856
10.25			1430	1345	1321	45.3	45.2	0.154	397	0.00	2.75	0.00	8.59	851
11.25			1395	1340	1318	40.4	39.6	-0.164	393	-0.47	2.97	-0.01	8.36	857
12.25			1370	1267	1297	26.7	26.6	-0.368	393	-0.42	4.09	-0.01	8.15	864
13.25			1280	1247	1255	21.4	20.4	-0.072	392	-0.60	3.07	0.00	8.65	861
14.25			1210	1245	1235	22.9	22.1	0.043	393	-0.44	3.06	0.00	8.55	868
15.25			1215	1285	1277	29.7	28.4	0.264	394	-0.67	2.84	0.00	8.65	867
16.25			1270	1284	1281	27.3	28.2	-0.191	393	0.40	3.68	-0.01	8.39	868
17.25			1285	1223	1235	18.5	18.2	-0.193	393	0.10	3.40	0.00	8.64	870
18.25			1175	1239	1229	23.4	23.4	0.209	397	-0.27	2.57	0.00	8.94	865
19.25			1250	1308	1285	31.7	32.1	0.265	395	0.00	2.43	0.00	8.77	866
20.25			1345	1388	1311	30.5	30.6	-0.091	393	-0.05	3.22	0.00	8.42	866
21.25			1300	1211	1220	20.4	20.3	-0.297	395	0.34	3.44	-0.01	8.51	864
22.25			1180	1171	1172	19.1	18.3	-0.064	394	0.04	3.28	-0.02	8.78	862
23.25			1125	1198	1223	21.7	21.8	0.123	403	1.00	2.86	-0.01	9.09	867
0.25			1205	1451	1347	39.6	41.9	0.640	403	-0.12	3.10	-0.01	8.96	869
1.25			1310	1389	1311	41.5	41.4	0.234	402	-0.09	3.15	-0.02	8.93	867
2.25			1325	1326	1325	36.9	36.7	-0.338	407	0.27	3.64	-0.02	8.93	869
3.25			1315	1324	1323	38.3	37.1	0.081	402	-0.75	4.00	-0.02	8.79	869
4.25			1290	1267	1271	30.2	30.2	-0.157	407	-0.03	10.43	-0.01	8.88	870
5.25			1230	1242	1266	27.4	27.3	-0.091	403	0.24	10.41	-0.02	9.02	866
6.25			1245	1349	1336	36.5	40.0	0.564	403	0.72	3.44	-0.02	8.98	870
7.25			1390	1343	1295	37.5	37.7	0.047	407	-0.03	3.76	-0.01	8.99	868

0.00 - 7.28														
MAX		1390.	1452.	1408.	42.9	42.6	0.830	410.	1.07	10.48	0.02	9.10	879.	
MIN		1125.	1233.	1248.	26.3	26.2	-0.352	396.	-0.84	2.54	-0.05	8.66	857.	
MEAN	7.48	1272.	1328.	1309.	35.4	35.5	0.041	404.	-0.01	5.10	-0.02	8.93	870.	
ACCM	449.8	1274.		1309.			0.041	404.	-0.01		-0.02	66.72	870.	
0.00 - 0.00														
MAX		1430.	1368.	1354.	50.2	49.9	0.828	412.	1.02	5.53	0.04	9.52	877.	
MIN		1125.	1157.	1170.	18.0	18.0	-0.594	387.	-0.78	0.91	-0.04	8.11	845.	
MEAN	24.02	1294.	1272.	1267.	29.4	29.4	-0.002	396.	0.02	2.85	-0.00	8.83	862.	
ACCM	433.4	1299.		1267.			-0.002	396.	0.02		-0.00	212.01	862.	

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

2 ASH IN COAL	COAL HEAT VALUE
2 MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	MBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT	STONS	BTU		LTWT
	PROD		KM2F1		NKCAL		C-ASH			LB. COAL		KN2F1*	
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z		T/H		GR/L	H
7.25	102.6	62.3	1497	9.46	823	848	20.0	3.84	9484	67.7	0	29.19	1330
8.25	103.0	62.6	1503	9.10	788	813	20.0	3.84	9484	68.0	0	28.00	1370
9.25	102.6	62.3	1497	8.90	774	798	20.0	3.84	9484	67.7	0	27.50	1430
10.25	103.1	62.6	1504	8.59	744	767	20.0	3.84	9484	68.0	0	26.38	1430
11.25	102.5	62.3	1496	8.36	729	751	20.0	3.84	9484	67.6	0	25.82	1395
12.25	104.1	63.3	1519	8.15	699	720	20.0	3.84	9484	68.7	0	24.86	1370
13.25	104.1	63.3	1520	8.65	741	749	18.7	3.57	9679	68.7	0	26.74	1280
14.25	104.8	63.7	1529	8.55	729	736	18.7	3.57	9682	69.1	0	26.37	1210
15.25	105.4	64.1	1538	8.65	732	739	18.7	3.57	9682	69.5	0	26.52	1215
16.25	105.6	64.2	1541	8.39	710	716	18.7	3.57	9682	69.7	0	25.78	1270
17.25	105.1	63.9	1534	8.64	734	740	18.7	3.57	9682	69.4	0	26.53	1285
18.25	104.4	63.5	1524	8.94	764	771	18.7	3.57	9682	68.9	0	27.58	1175
19.25	104.9	63.8	1531	8.77	747	754	18.7	3.57	9682	69.2	0	27.13	1250
20.25	105.7	64.2	1543	8.42	711	718	18.7	3.57	9682	69.7	0	25.87	1345
21.25	104.6	63.5	1526	8.51	727	733	18.7	3.57	9682	69.0	0	26.26	1300
22.25	104.6	63.6	1526	8.78	750	757	18.7	3.57	9682	69.0	0	27.18	1180
23.25	99.7	60.6	1455	9.09	814	822	18.7	3.57	9682	65.8	0	29.55	1125
0.25	104.3	63.4	1521	8.96	767	774	18.7	3.57	9682	68.8	0	27.82	1285
1.25	103.7	63.0	1514	8.93	769	776	18.7	3.57	9682	68.4	0	27.74	1310
2.25	105.0	63.8	1532	8.93	768	767	18.7	3.57	9682	69.3	0	27.50	1325
3.25	104.6	63.6	1527	8.79	751	758	18.7	3.57	9682	69.0	0	27.14	1315
4.25	104.7	63.6	1527	8.88	757	764	18.7	3.57	9682	69.1	0	27.47	1290
5.25	105.0	63.8	1532	9.02	767	774	18.7	3.57	9682	69.3	0	27.78	1230
6.25	104.1	63.3	1519	8.98	770	778	18.7	3.57	9682	68.7	0	27.97	1245
7.25	104.7	63.6	1528	8.99	766	774	18.7	3.57	9679	69.1	0	27.76	1390

0.00 - 7.29

MAX	106.4	64.7	1552	9.10	809	816	18.7	3.57	9682	70.2	0	29.29	1390
MIN	98.6	60.1	1442	8.66	735	742	18.7	3.57	9679	65.2	0	26.61	1125
MEAN	104.5	63.6	1526	8.93	763	770	18.7	3.57	9682	69.0	0	27.62	1272. 7.49
ACCM	782.5	475.8		66.82	763	770	18.7	3.57			0	27.62	1274. 440.8

0.00 - 8.00

MAX	106.4	64.8	1555	9.52	831	854	20.0	3.84	9682	70.4	0	30.09	1430
MIN	98.2	59.8	1435	8.11	696	707	18.7	3.57	9482	64.9	0	24.70	1125
MEAN	103.6	63.0	1512	8.83	762	778	19.4	3.71	9581	68.4	0	27.29	1294. 24.02
ACCM	2486.4	1511.7		212.01	762	777	19.4	3.71			0	27.30	1299. 433.4

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
W1/ KILN FEED MS
W1/ KILN FEED LSF
W1/ BURNING FACTOR
HEAT CONSUMPTION
W1/ COAL TO KILN
KILN PRODUCTION
W1/ KILN FEED

W1/ FEED LOSS-O-IG
U1/ LITER WEIGHT
U1/ CLINKER TEMP
U1/ FREE LIME
U1/ CLINKER LSF
U1/ CLINKER MS
KILN CONTROL
COAL TO KILN

HOUR	HO1OF1		KM2F1		BF	KF-MS		KF-LOI		KLD	CL-LS		KCONTRL	
	PROD		T/H	KC/KG		KF-LS	C3S	LTWT	FCAO		CL-MS	KM2F1*	H	H

7.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
8.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
9.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
10.25	104.6	63.6	8.65	738	0.0	0.000	0.000	0.0	0.0	0	235	0.00	0.000	0.000
11.25	104.8	63.7	8.80	749	105.2	0.860	2.480	45.1	0.0	1350	239	0.00	0.000	0.000
12.25	104.4	63.5	8.79	752	105.2	0.860	2.480	45.1	0.0	1450	231	0.00	0.000	0.000
13.25	105.1	63.9	8.37	711	105.5	0.870	2.530	47.3	34.0	1450	221	0.12	0.900	0.000
14.25	104.1	63.3	8.25	707	105.5	0.870	2.530	47.3	34.0	1500	230	0.12	0.900	2.570
15.25	105.3	64.0	8.15	691	102.6	0.840	2.460	38.6	34.0	1500	217	0.12	0.900	2.570
16.25	104.4	63.5	8.60	735	102.6	0.840	2.460	38.6	34.0	1450	215	0.12	0.900	2.570
17.25	103.2	62.7	8.70	752	102.6	0.840	2.460	38.6	34.0	1240	187	0.12	0.900	2.570
18.25	105.3	64.0	8.79	745	102.6	0.840	2.460	38.6	34.0	1160	286	0.12	0.900	2.570
19.25	95.6	58.1	8.77	819	102.6	0.840	2.460	38.6	34.0	1130	311	0.12	0.900	2.570
20.25	104.9	63.8	8.88	756	102.6	0.840	2.460	38.6	34.0	1060	198	0.12	0.900	2.570
21.25	104.8	63.7	8.92	760	102.6	0.840	2.460	38.6	34.0	1060	256	0.12	0.900	2.570
22.25	104.3	63.4	8.90	762	102.6	0.840	2.460	38.6	34.0	1220	248	0.12	0.900	2.570
23.25	105.3	64.0	8.86	751	102.6	0.840	2.460	38.6	34.0	1200	219	0.12	0.900	2.570
0.25	105.0	63.8	9.05	770	104.4	0.850	2.510	42.8	34.0	1215	230	0.12	0.900	2.570
1.25	104.3	63.4	9.30	795	104.4	0.850	2.510	42.8	34.0	1190	208	0.12	0.900	2.570
2.25	104.5	63.5	9.50	812	104.4	0.850	2.510	42.8	34.0	1220	242	0.12	0.900	2.570
3.25	105.4	64.1	9.21	780	104.4	0.850	2.510	42.8	34.0	1290	237	0.12	0.900	2.570
4.25	104.9	63.8	9.04	769	104.4	0.850	2.510	42.8	34.0	1390	233	0.12	0.900	2.570
5.25	104.7	63.6	9.31	794	104.4	0.850	2.510	42.8	34.0	1355	217	0.12	0.900	2.570
6.25	105.3	64.0	9.15	776	104.4	0.850	2.510	42.8	34.0	1340	215	0.12	0.900	2.570
7.25	105.0	63.8	9.17	780	104.4	0.850	2.510	42.8	34.0	1325	227	0.12	0.900	2.570

0.00 - 7.27

MAX	106.3	64.7	9.58	825	104.4	0.850	2.510	42.8	34.1	1390	250	0.12	0.900	2.570		
MIN	103.0	62.7	8.88	753	104.4	0.850	2.510	42.8	34.1	1190	173	0.12	0.900	2.570		
MEAN	104.9	63.8	9.22	786	104.4	0.850	2.510	42.8	34.1	1289	226	0.12	0.900	2.570	7.46	7.46
ACCM	782.0	475.5	68.77	786	104.4	0.850	2.510	42.8	34.1	1291	226	0.12	0.900	2.570	8.30	21.30

0.00 - 0.00

MAX	106.1	64.5	9.23	843	105.5	0.870	2.530	47.4	34.1	1500	323	0.12	0.900	2.570		
MIN	42.2	29.3	3.58	683	0.0	0.000	0.000	0.0	0.0	0	103	0.00	0.000	0.000		
MEAN	104.2	63.3	8.68	745	100.4	0.823	2.400	40.2	26.2	1216	229	0.09	0.693	1.976	0.83	13.83
ACCM	1440.6	875.9	120.84	744	103.7	0.849	2.478	41.6	26.8	1214	229	0.09	0.707	2.019	0.83	13.83

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3 KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
8.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
9.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
10.25	1.9	24.1	112	10.44	810	281	787	334	631	399	389	403	615	0.00	873	
11.25	1.9	24.0	113	2.97	810	199	788	327	631	397	391	403	610	-0.01	872	
12.25	1.9	21.5	105	10.49	808	195	788	313	631	399	392	406	605	0.00	870	
13.25	1.9	21.2	105	10.49	806	195	786	314	624	396	388	403	604	0.00	864	
14.25	1.9	19.8	120	10.50	808	285	786	329	623	396	387	401	609	0.00	863	
15.25	1.9	18.7	110	4.17	803	281	778	315	624	394	386	400	591	-0.01	865	
16.25	1.9	16.6	106	4.89	804	281	782	320	614	388	379	396	592	0.00	855	
17.25	1.9	20.1	115	4.43	805	214	779	324	622	393	383	398	592	0.00	856	
18.25	1.9	22.0	128	3.81	803	221	772	338	607	385	376	393	605	-0.01	857	
19.25	1.9	18.9	82	3.96	808	162	783	291	628	413	404	416	556	-0.01	845	
20.25	1.9	24.6	88	3.76	809	157	778	301	619	395	385	403	577	0.01	846	
21.25	1.9	24.2	96	4.20	807	182	778	306	618	398	388	403	583	0.01	845	
22.25	1.9	23.8	93	3.47	805	174	775	302	621	395	386	401	580	0.00	844	
23.25	1.9	23.0	89	3.32	808	184	779	300	618	392	385	399	574	-0.01	846	
0.25	1.9	23.7	94	3.59	806	184	774	302	622	396	389	402	584	0.00	843	
1.25	1.9	24.5	102	2.76	807	184	776	306	616	393	384	400	588	0.00	843	
2.25	1.9	24.1	88	2.35	808	177	776	302	618	392	383	398	568	-0.01	842	
3.25	1.9	22.5	94	3.20	809	192	780	303	616	395	389	403	593	-0.02	846	
4.25	1.9	21.5	101	4.13	809	173	781	313	622	396	389	402	594	-0.02	849	
5.25	1.9	20.9	97	3.92	809	190	783	294	625	396	389	402	584	-0.02	844	
6.25	1.9	21.4	92	4.19	809	200	784	310	625	394	389	402	586	-0.03	843	
7.25	1.9	22.1	93	3.63	807	176	785	298	628	394	387	402	592	-0.02	843	

0.00 - 7.28

MAX	2.0	25.0	108.	5.44	813.	216.	789.	320.	629.	404.	394.	406.	603.	0.01	863.
MIN	2.0	19.9	82.	1.89	803.	149.	770.	284.	611.	388.	380.	397.	565.	-0.05	835.
MEAN	2.0	22.5	95.	3.58	809.	183.	780.	301.	620.	395.	388.	402.	587.	-0.01	845.
ACCM	2.0	22.5	95.		809.	183.	780.	301.	620.	395.	388.	402.	587.	-0.01	845.

0.00 - 0.00

MAX	2.0	33.8	137.	10.64	815.	238.	798.	351.	638.	414.	407.	417.	626.	0.03	879.
MIN	1.9	10.2	76.	1.08	784.	152.	760.	277.	599.	380.	375.	373.	471.	-0.04	825.
MEAN	2.0	21.9	105.	5.43	807.	195.	782.	315.	622.	395.	387.	402.	591.	-0.00	856.
ACCM	2.0	21.9	105.		807.	195.	782.	315.	622.	395.	387.	402.	591.	-0.00	856.

PLANT REPORT 3 KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ Z00 EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

	KN2F1#	KALARM	ESTLTW	NOXST	NOXALT	A50ALT		KN2F1						
HOUR	KCONTRL	LTWT	LTWTGSP	NOXL	A50T1	OA15X1		OA1X2CO	OA2V1					
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM

7.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
8.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
9.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
10.25				0	0	0	0.0	0.0	0.000	403	0.00	10.44	0.00	8.65	873
11.25				1350	1235	602	49.3	27.7	2.032	403	-0.06	2.97	-0.01	8.80	872
12.25				1450	1466	704	54.8	54.9	0.442	406	0.38	10.49	0.00	8.79	870
13.25				1450	1511	718	59.9	60.1	0.152	403	-0.33	10.49	0.00	8.37	864
14.25				1500	1524	718	61.7	61.7	0.038	401	0.10	10.50	0.00	8.25	863
15.25				1500	1324	1339	36.3	38.1	-0.119	400	0.13	4.17	-0.01	8.15	865
16.25				1450	1210	738	24.5	27.1	-0.519	396	0.10	4.89	0.00	8.60	855
17.25				1240	1107	825	15.7	15.2	-0.138	398	-0.03	4.43	0.00	8.70	856
18.25				1160	1188	1179	19.6	19.6	0.144	393	-0.38	3.01	-0.01	8.79	857
19.25				1130	1056	930	10.0	6.6	-0.576	416	2.34	3.96	-0.01	8.77	845
20.25				1060	1328	1266	30.0	32.5	0.497	403	-1.05	3.76	0.01	8.88	846
21.25				1060	1189	1159	20.6	20.5	-0.175	403	0.15	4.20	0.01	8.92	845
22.25				1220	1195	1198	20.6	19.2	-0.117	401	-0.34	3.47	0.00	8.90	844
23.25				1200	1240	1235	21.9	22.3	0.105	399	-0.11	3.32	-0.01	8.86	846
0.25				1215	1202	1203	19.0	19.1	-0.116	402	0.09	3.59	0.00	9.05	843
1.25				1190	1252	1250	22.4	22.2	0.120	400	0.02	2.76	0.00	9.30	843
2.25				1220	1405	1400	32.4	31.7	0.380	398	-0.18	2.35	-0.01	9.50	842
3.25				1290	1579	1304	41.7	42.4	0.305	403	0.07	3.20	-0.02	9.21	846
4.25				1390	1281	1256	28.7	28.4	-0.607	402	-0.08	4.13	-0.02	9.04	849
5.25				1355	1296	1277	29.2	28.8	0.079	402	0.00	3.92	-0.02	9.31	844
6.25				1340	1323	1325	30.5	31.0	0.079	402	-0.06	4.19	-0.03	9.15	843
7.25				1325	1265	1271	23.5	24.6	-0.242	402	-0.38	3.63	-0.02	9.17	843

0.00 - 7.30

MAX				1390.	1580.	1568.	42.4	42.5	0.405	406.	0.32	5.44	0.01	9.58	863.
MIN				1190.	1202.	1203.	19.1	19.1	-0.618	397.	-0.44	1.89	-0.05	8.88	835.
MEAN	7.50	7.50		1289.	1335.	1299.	29.1	29.1	0.021	402.	-0.01	3.58	-0.02	9.22	845.
ACCH	21.34	8.34		1291.		1299.			0.021	402.	-0.01		-0.02	69.17	845.

0.00 - 0.00

MAX				1500.	1525.	1469.	61.7	61.8	3.283	417.	58.78	10.64	0.03	9.23	879.
MIN				0.	0.	0.	0.0	0.0	-1.593	373.	-1.22	1.08	-0.04	3.58	825.
MEAN	13.83	0.83		1216.	1229.	993.	28.9	28.9	0.053	402.	0.34	5.43	-0.00	8.68	856.
ACCH	13.83	0.83		1214.		993.			0.053	402.	0.34		-0.00	120.04	856.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL COAL HEAT VALUE
 Z MOISTURE IN COAL
 NET HEAT CONSUMP SHORT TONS CLINKER
 HEAT CONSUMPTION LB COAL / SH.T
 W1/ COAL TO KILN MBTU' PER SH.T
 KILN PRODUC. RATE
 KILN PRODUCTION U1/ LITER WEIGHT
 W1/ KILN FEED COAL TO KILN

HOUR	HD10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		BTU		LTWT	
	PROD		KM2F1		NKCAL		C-ASH				LB.COAL		KM2F1*			
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z	T	T	T/H	CR/L	H			
7.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0			
8.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0			
9.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0			
10.25	104.6	63.6	1527	8.65	738	578	0.0	0.00	12486	69.0	0	34.43	0			
11.25	104.8	63.7	1529	8.80	749	587	0.0	0.00	12486	69.2	0	35.13	1350			
12.25	104.4	63.5	1524	8.79	752	588	0.0	0.00	12486	68.9	0	35.11	1450			
13.25	105.1	63.9	1533	8.37	711	556	0.0	0.00	12486	69.3	0	33.18	1450			
14.25	104.1	63.3	1519	8.25	707	722	19.3	3.82	9573	68.7	0	25.33	1500			
15.25	105.3	64.0	1537	8.15	691	705	19.3	3.82	9576	69.5	0	24.79	1500			
16.25	104.4	63.5	1524	8.60	735	751	19.3	3.82	9576	68.9	0	26.32	1450			
17.25	103.2	62.7	1506	8.70	752	768	19.3	3.82	9576	68.1	0	27.31	1240			
18.25	105.3	64.0	1537	8.79	745	760	19.3	3.82	9576	69.5	0	26.68	1160			
19.25	95.6	58.1	1395	8.77	819	836	19.3	3.82	9576	63.1	0	29.35	1130			
20.25	104.9	63.8	1531	8.88	756	771	19.3	3.82	9576	69.2	0	27.86	1060			
21.25	104.8	63.7	1529	8.92	760	776	19.3	3.82	9576	69.1	0	27.19	1060			
22.25	104.3	63.4	1522	8.90	762	777	19.3	3.82	9576	68.8	0	27.26	1220			
23.25	105.3	64.0	1537	8.86	751	767	19.3	3.82	9576	69.5	0	26.92	1200			
0.25	105.0	63.8	1532	9.05	770	785	19.3	3.82	9576	69.3	0	27.62	1215			
1.25	104.3	63.4	1523	9.30	795	812	19.3	3.82	9576	68.8	0	28.45	1190			
2.25	104.5	63.5	1525	9.50	812	828	19.3	3.82	9576	69.0	0	29.23	1220			
3.25	105.4	64.1	1539	9.21	780	796	19.3	3.82	9576	69.6	0	28.10	1290			
4.25	104.9	63.8	1531	9.04	769	785	19.3	3.82	9576	69.2	0	27.60	1390			
5.25	104.7	63.6	1528	9.31	794	810	19.3	3.82	9576	69.1	0	28.48	1355			
6.25	105.3	64.0	1537	9.15	776	792	19.3	3.82	9576	69.5	0	27.75	1340			
7.25	105.0	63.8	1532	9.17	780	796	19.3	3.82	9576	69.3	0	28.03	1325			

0.00 - 7.30	
MAX	106.3 64.7 1552. 9.58 825. 842. 19.3 3.82 9577. 70.2 0. 29.56 1390.
MIN	103.0 62.7 1504. 8.88 753. 769. 19.3 3.82 9574. 68.0 0. 26.98 1190.
MEAN	104.9 63.8 1530. 9.22 786. 802. 19.3 3.82 9576. 69.2 0. 28.14 1289. 7.52
ACCH	787.7 478.9 69.27 786. 802. 19.3 3.82 0. 28.13 1291. 21.35
0.00 - 0.00	
MAX	106.1 64.5 1548. 9.23 843.***** 19.3 3.82 12490. 70.0 0. 36.96 1500.
MIN	42.2 29.3 703. 3.58 683. 552. 0.0 0.00 9574. 31.8 0. 0.00 0.
MEAN	104.2 63.3 1520. 8.68 745.***** 14.8 2.94 10254. 68.7 0. 28.54 1216. 13.83
ACCH	1440.6 875.9 120.04 744. 710. 14.8 2.94 0. 28.56 1214. 13.83

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HD10F1		KM2F1		BF		KF-MS		KF-LOI		KLO		CL-LS		KCONTRL	
	PROD		KCAL		KF-LS		C3S		LTWT		FCAO		CL-MS		KM2F1*	
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H					
7.25	104.7	63.7	9.12	777	104.4	0.850	2.510	42.8	34.0	1340	226	0.12	0.900	2.570		
8.25	105.4	64.1	9.27	785	106.6	0.880	2.420	42.8	34.0	1325	224	0.12	0.900	2.570		
9.25	105.1	63.9	9.05	768	106.6	0.880	2.420	42.8	34.0	1310	216	0.12	0.900	2.570		
10.25	--	--	--	--	106.6	0.880	2.420	42.8	34.0	1310	--	0.12	0.900	2.570		
11.25	--	--	--	--	106.6	0.880	2.420	42.8	34.0	1310	--	0.12	0.900	2.570		
12.25	--	--	--	--	106.6	0.880	2.420	42.8	34.0	1310	--	0.12	0.900	2.570		
13.25	56.3	34.2	5.20	824	106.6	0.880	2.420	42.8	34.0	1310	79	0.12	0.900	2.570		
14.25	61.3	37.3	6.35	924	105.7	0.860	2.580	46.6	33.9	1310	153	0.47	0.890	2.560		
15.25	71.9	43.7	7.15	888	105.7	0.860	2.580	46.6	33.9	1310	96	0.47	0.890	2.560		
16.25	86.6	52.6	8.49	876	104.5	0.840	2.570	40.9	33.9	1230	125	0.47	0.890	2.560		
17.25	104.5	63.5	9.39	802	104.5	0.840	2.570	40.9	33.9	1340	176	0.47	0.890	2.560		
18.25	105.0	63.8	9.23	785	104.5	0.840	2.570	40.9	33.9	1370	224	0.47	0.890	2.560		
19.25	104.6	63.6	9.18	784	104.5	0.840	2.570	40.9	33.9	1380	253	0.47	0.890	2.560		
20.25	99.7	60.6	9.08	813	104.5	0.840	2.570	40.9	33.9	1400	255	0.47	0.890	2.560		
21.25	99.3	60.3	8.77	788	104.5	0.840	2.570	40.9	33.9	1410	220	0.47	0.890	2.560		
22.25	99.1	60.2	8.88	800	104.5	0.840	2.570	40.9	33.9	1410	183	0.47	0.890	2.560		
23.25	99.8	60.7	8.99	804	104.5	0.840	2.570	40.9	33.9	1380	194	0.47	0.890	2.560		
0.25	100.2	60.9	8.99	801	119.5	0.970	2.770	71.0	33.9	1315	229	0.47	0.890	2.560		
1.25	100.8	61.3	8.89	787	119.5	0.970	2.770	71.0	33.9	1280	191	0.47	0.890	2.560		
2.25	100.3	61.0	8.83	786	119.5	0.970	2.770	71.0	33.9	1385	235	0.47	0.890	2.560		
3.25	99.9	60.7	8.84	790	119.5	0.970	2.770	71.0	33.9	1285	248	0.47	0.890	2.560		
4.25	99.2	60.3	8.90	801	119.5	0.970	2.770	71.0	33.9	1285	315	0.47	0.890	2.560		
5.25	100.8	61.3	8.77	777	119.5	0.970	2.770	71.0	33.9	1220	257	0.47	0.890	2.560		
6.25	99.6	60.6	8.87	795	119.5	0.970	2.770	71.0	33.9	1290	264	0.47	0.890	2.560		
7.25	99.8	60.7	8.89	795	119.5	0.970	2.770	71.0	33.9	1175	255	0.47	0.890	2.560		

0.00 - 7.27																
MAX	101.3	61.6	9.08	822	119.5	0.970	2.770	71.0	33.9	1385	332	0.47	0.890	2.560		
MIN	98.1	59.5	8.67	773	119.5	0.970	2.770	71.0	33.9	1175	185	0.47	0.890	2.560		
MEAN	99.8	60.7	8.86	793	119.5	0.970	2.770	71.0	33.9	1290	245	0.47	0.890	2.560	7.46	7.46
ACCM	744.2	452.5	66.04	793	119.5	0.970	2.770	71.0	33.9	1291	245	0.47	0.890	2.560	32.33	42.06
0.00 - 0.00																
MAX	106.3	64.7	9.58	37530	119.5	0.970	2.770	71.0	34.1	1410	263	0.47	0.900	2.570		
MIN	-4.3	-2.6	1.07	-8598	104.4	0.840	2.420	40.9	33.9	1190	22	0.12	0.890	2.560		
MEAN	96.8	58.9	8.69	812	105.5	0.858	2.513	43.2	34.0	1321	199	0.27	0.896	2.566	24.01	20.72
ACCM	2086.6	1219.2	180.07	802	105.7	0.860	2.518	43.7	34.0	1317	199	0.28	0.895	2.565	24.85	34.58

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	21.6	93	4.43	809	182	782	296	626	397	389	402	588	-0.01	844	
8.25	1.9	20.6	101	3.80	809	181	776	298	625	394	388	400	584	-0.01	846	
9.25	1.9	20.5	92	3.34	808	177	779	295	617	396	389	402	590	-0.03	847	
10.25	--	--	--	--	--	--	--	--	--	--	--	373	--	--	--	
11.25	--	--	--	--	--	--	--	--	--	--	--	341	--	--	--	
12.25	--	--	--	--	--	--	--	--	--	--	--	356	--	--	--	
13.25	1.2	22.7	20	10.45	745	74	717	99	589	403	401	405	183	0.05	553	
14.25	1.2	4.7	17	1.42	795	77	755	130	614	403	398	408	257	0.03	633	
15.25	1.3	13.2	52	0.73	799	131	774	201	626	414	410	420	374	0.00	729	
16.25	1.5	20.9	64	2.12	802	157	773	240	621	410	403	416	440	0.02	772	
17.25	1.9	23.6	87	3.33	809	194	779	305	626	404	396	412	574	0.00	852	
18.25	1.9	24.3	93	2.95	811	198	781	305	617	394	384	398	578	0.00	846	
19.25	1.9	24.8	93	2.83	811	188	774	306	616	391	381	396	567	-0.01	850	
20.25	1.9	21.9	76	3.22	807	186	783	282	623	395	388	403	558	-0.03	849	
21.25	1.9	22.0	87	3.74	807	180	785	286	623	392	384	397	576	-0.03	849	
22.25	1.9	26.3	96	3.62	806	174	786	302	623	394	384	400	591	-0.04	849	
23.25	1.9	29.2	114	3.51	808	209	785	308	623	394	383	398	597	-0.03	851	
0.25	1.9	30.7	91	2.15	811	191	787	298	633	400	389	403	579	-0.03	854	
1.25	1.9	34.4	68	3.48	810	177	785	287	631	401	389	405	576	-0.02	857	
2.25	1.9	32.7	72	4.26	809	173	786	280	630	403	389	406	580	-0.10	855	
3.25	1.9	33.1	71	4.08	810	172	788	276	634	400	390	405	573	-0.04	848	
4.25	1.9	32.7	71	3.96	810	159	788	279	635	402	389	404	569	-0.04	850	
5.25	1.9	32.0	71	4.45	809	193	790	290	635	404	393	408	579	-0.04	852	
6.25	1.9	30.1	75	4.05	808	164	792	286	637	402	390	406	581	-0.16	849	
7.25	1.9	30.8	76	3.93	810	174	793	297	636	403	393	408	585	-0.13	847	

0.00 - 7.28															
MAX	2.0	42.2	129.	4.93	816.	227.	805.	327.	645.	408.	396.	411.	607.	-0.00	864.
MIN	2.0	29.1	58.	1.71	806.	135.	782.	261.	616.	393.	380.	397.	551.	-0.20	830.
MEAN	2.0	32.5	75.	3.91	810.	173.	790.	287.	634.	402.	390.	406.	580.	-0.06	851.
ACCH	2.0	32.5	75.		810.	173.	790.	287.	634.	402.	390.	406.	580.	-0.06	851.
0.00 - 0.00															
MAX	2.0	31.5	127.	10.60	814.	222.	795.	324.	647.	403.	475.	445.	603.	1.28	863.
MIN	0.0	0.1	-11.	0.36	629.	-4.	653.	-11.	564.	369.	369.	336.	-2.	-0.19	407.
MEAN	1.9	21.9	84.	3.35	804.	170.	775.	276.	619.	397.	390.	398.	534.	-0.01	815.
ACCH	1.9	21.9	84.		804.	170.	775.	276.	619.	397.	390.	398.	534.	-0.01	815.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME W1/ NOX CHANGE LT
 W1/ NOX REG STIME W1/ T EXIT PREHEAT
 W1/ LTM FOR CONTRL W1/ A50T1 CHANGE
 W1/ ESTIMATED LTM W1/ Z02 KILN OUTL
 U1/ LITER WEIGHT
 KILN CON. MEASUR. W1/ ZCO EX PREHEAT
 KILN CONTROL W1/ COAL TO KILN
 COAL TO KILN J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM	ESTLTM		NOXST		NOXALT		A50ALT		KM2F1		OA2V1	
	KCONTRL		LTWT	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H		RPM
7.25				1340	1290	1295	26.5	27.4	-0.190	402	-0.17	4.43	-0.01	9.12	844
8.25				1325	1320	1321	29.1	30.7	0.554	400	0.18	3.80	-0.01	9.27	846
9.25				1310	1315	1315	29.0	29.5	-0.050	402	-0.10	3.34	-0.03	9.05	847
10.25				1310	1266	1189	23.7	23.7	-0.175	373	-1.69	--	--	--	--
11.25				1310	1235	1173	20.1	20.0	-0.112	341	-0.98	--	--	--	--
12.25				1310	1213	1162	17.5	17.5	-0.081	356	0.18	--	--	--	--
13.25				1310	1197	2694	15.6	15.6	-0.060	405	2.91	10.45	0.05	5.20	553
14.25				1310	1184	1198	16.4	14.0	-0.589	408	-0.54	1.42	0.03	6.35	633
15.25				1310	1161	1194	11.6	11.3	-0.041	420	-0.19	0.73	0.00	7.15	729
16.25				1230	1384	1348	37.7	39.2	0.782	416	0.13	2.12	0.02	8.49	772
17.25				1340	1315	1321	31.2	28.2	-0.823	412	-0.08	3.33	0.00	9.39	852
18.25				1370	1333	1339	31.3	31.2	0.180	398	-0.03	2.95	0.00	9.23	846
19.25				1380	1365	1353	36.5	36.2	0.149	396	-0.07	2.83	-0.01	9.18	850
20.25				1480	1376	1394	39.8	37.9	0.189	403	1.10	3.22	-0.03	9.08	849
21.25				1410	1432	1429	49.2	48.1	0.002	397	-0.12	3.74	-0.03	8.77	849
22.25				1410	1363	1365	36.5	35.9	-0.376	400	0.02	3.62	-0.04	8.88	849
23.25				1380	1338	1339	32.4	31.2	-0.084	398	-0.07	3.51	-0.03	8.99	851
0.25				1315	1337	1371	33.6	31.9	0.031	403	0.33	2.15	-0.03	8.99	854
1.25				1280	1410	1421	44.7	45.6	0.162	405	-0.06	3.48	-0.02	8.89	857
2.25				1385	1348	1349	34.9	34.7	-0.124	406	0.09	4.26	-0.10	8.83	855
3.25				1285	1318	1348	32.4	30.4	-0.364	405	-0.19	4.08	-0.04	8.84	848
4.25				1285	1348	1342	35.1	37.0	0.361	404	0.03	3.96	-0.04	8.90	850
5.25				1220	1303	1299	33.4	33.6	-0.191	408	0.19	4.45	-0.04	8.77	852
6.25				1290	1265	1273	27.9	28.4	-0.255	406	0.06	4.05	-0.16	8.87	849
7.25				1175	1266	1252	31.2	31.4	-0.005	408	-0.04	3.93	-0.13	8.89	847

0.00 - 7.30															
MAX			1385.	1417.	1425.	45.8	46.8	0.662	411.	0.88	4.93	-0.00	9.08	864.	
MIN			1175.	1260.	1179.	27.6	27.6	-0.518	397.	-0.89	1.71	-0.20	8.67	830.	
MEAN	7.50	7.50	1289.	1331.	1335.	34.8	34.8	-0.001	406.	0.04	3.91	-0.06	8.86	851.	
ACCH	42.10	32.37	1291.		1335.			-0.001	406.	0.04		-0.06	66.44	851.	
0.00 - 0.00															
MAX			1410.	1580.	6231.	52.0	52.9	1.126	445.	8.70	10.60	1.28	9.58	863.	
MIN			1190.	1147.	1155.	9.2	9.7	-0.854	336.	-6.81	0.36	-0.19	1.87	407.	
MEAN	20.72	24.01	1321.	1313.	1348.	28.8	28.8	0.014	398.	-0.01	3.35	-0.01	8.69	815.	
ACCH	34.58	24.85	1317.		1348.			0.014	398.	-0.01		-0.01	180.87	815.	

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU / PER SH. T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU		LTWT
	PROD	KN2F1		NKCAL	C-ASH	LB. COAL	KN2F1*						
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z		T/H	GR/L	H	
7.25	104.7	63.7	1528	9.12	777	794	19.3	3.82	9576	69.1	0	28.82	1340
8.25	105.4	64.1	1539	9.27	785	801	19.3	3.82	9573	69.6	0	28.17	1325
9.25	105.1	63.9	1534	9.05	768	784	19.3	3.82	9576	69.4	0	27.61	1310
10.25	--	--	-78	--	--	--	19.3	3.82	9576	-3.2	--	--	1310
11.25	--	--	-73	--	--	--	19.3	3.82	9576	-3.3	--	--	1310
12.25	--	--	-65	--	--	--	19.3	3.82	9573	-2.9	--	--	1310
13.25	56.3	34.2	822	5.20	824	841	19.3	3.82	9576	37.2	0	29.58	1310
14.25	61.3	37.3	895	6.35	924	945	20.0	3.22	9552	40.5	0	33.14	1310
15.25	71.9	43.7	1049	7.15	888	908	20.0	3.22	9555	47.4	0	31.91	1310
16.25	86.6	52.6	1264	8.49	876	896	20.0	3.22	9555	57.1	0	31.32	1230
17.25	104.5	63.5	1525	9.39	802	821	20.0	3.22	9555	69.0	0	28.80	1340
18.25	105.0	63.8	1532	9.23	785	803	20.0	3.22	9555	69.3	0	28.82	1370
19.25	104.6	63.6	1527	9.18	784	801	20.0	3.22	9555	69.0	0	28.80	1388
20.25	99.7	60.6	1455	9.08	813	832	20.0	3.22	9555	65.8	0	29.19	1400
21.25	99.3	60.3	1449	8.77	788	807	20.0	3.22	9555	65.5	0	28.12	1410
22.25	99.1	60.2	1446	8.88	800	818	20.0	3.22	9555	65.4	0	28.45	1410
23.25	99.8	60.7	1457	8.99	804	823	20.0	3.22	9552	65.9	0	28.87	1380
0.25	100.2	60.9	1463	8.99	801	819	20.0	3.22	9555	66.1	0	28.56	1315
1.25	100.8	61.3	1472	8.89	787	805	20.0	3.22	9555	66.5	0	28.10	1280
2.25	100.3	61.0	1464	8.83	786	804	20.0	3.22	9555	66.2	0	28.23	1385
3.25	99.9	60.7	1458	8.84	790	808	20.0	3.22	9555	65.9	0	28.34	1285
4.25	99.2	60.3	1448	8.90	801	819	20.0	3.22	9555	65.4	0	28.55	1285
5.25	100.8	61.3	1472	8.77	777	795	20.0	3.22	9555	66.5	0	27.81	1220
6.25	99.6	60.6	1454	8.87	795	813	20.0	3.22	9555	65.7	0	28.36	1290
7.25	99.8	60.7	1457	8.89	795	813	20.0	3.22	9555	65.9	0	28.48	1175

0.00 - 7.30

MAX	101.3	61.6	1478.	9.88	822.	841.	20.0	3.22	9556.	66.9	0.	29.37	1385.
MIN	98.1	59.5	1429.	8.67	773.	791.	20.0	3.22	9556.	64.6	0.	27.64	1175.
MEAN	99.8	60.7	1456.	8.86	793.	811.	20.0	3.22	9555.	65.9	0.	28.33	1289. 7.51
ACCM	749.7	455.8		66.53	793.	811.	20.0	3.22			0.	28.33	1291. 42.11

0.00 - 0.00

MAX	106.3	64.7	1552.	9.58	37530.	38315.	20.0	3.82	9645.	70.2	14.	1344.3	1410.
MIN	-4.3	-2.6	-81.	1.07	-8598.	-8778.	19.3	3.22	9553.	-3.7	-3.	-307.88	1190.
MEAN	96.8	58.9	1211.	8.69	812.	830.	19.6	3.56	9569.	54.8	0.	29.84	1321. 20.72
ACCM	2006.6	1219.2		190.07	802.	829.	19.6	3.56			0.	29.84	1317. 34.58

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S

W1/ KILN FEED MS

W1/ KILN FEED LSF

W1/ BURNING FACTOR

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUCTION

W1/ KILN FEED

W1/ FEED LOSS-O-IG

U1/ LITER WEIGHT

U1/ CLINKER TEMP

U1/ FREE LIME

U1/ CLINKER LSF

U1/ CLINKER MS

KILN CONTROL

COAL TO KILN

HOUR	HO10F1	KM2F1	BF	KF-MS		KF-LS	C3S	KF-LOI	LTWT	KLO	FCAD	CL-LS	CL-MS	KCONTRL	KM2F1*					
	PROD	KCAL	BF	KF-LS	C3S	LTWT	FCAD	CL-MS	KM2F1*	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG. C	%	H	H
7.25	98.8	60.8	8.83	798	119.5	0.970	2.770	71.0	33.9	1290	256	0.47	0.890	2.560						
8.25	99.1	60.3	9.00	810	119.5	0.970	2.770	71.0	33.9	1220	251	0.47	0.890	2.560						
9.25	99.1	60.2	9.03	814	119.5	0.970	2.770	71.0	33.9	1270	243	0.47	0.890	2.560						
10.25	99.5	60.5	9.01	808	118.0	0.950	2.840	66.8	33.9	1260	257	0.47	0.890	2.560						
11.25	99.7	60.6	9.04	810	118.0	0.950	2.840	66.8	33.9	1260	270	0.47	0.890	2.560						
12.25	100.7	61.2	8.94	792	118.0	0.950	2.840	66.8	33.9	1220	275	0.47	0.890	2.560						
13.25	100.1	60.9	9.00	803	118.0	0.950	2.840	66.8	33.9	1290	267	0.47	0.890	2.560						
14.25	100.6	61.1	9.16	813	118.0	0.950	2.840	66.8	33.9	1290	259	0.47	0.890	2.560						
15.25	99.0	60.2	9.17	826	118.0	0.950	2.840	66.8	33.9	1140	238	0.47	0.890	2.560						
16.25	98.8	60.1	9.18	829	119.5	0.950	2.950	67.6	33.9	1140	247	0.47	0.890	2.560						
17.25	99.7	60.6	9.19	822	119.5	0.950	2.950	67.6	33.9	1250	226	0.47	0.890	2.560						
18.25	100.0	60.8	9.21	823	119.5	0.950	2.950	67.6	33.9	1250	258	0.47	0.890	2.560						
19.25	99.9	60.7	9.13	815	119.5	0.950	2.950	67.6	33.9	1250	251	0.47	0.890	2.560						
20.25	99.4	60.4	9.05	813	119.5	0.950	2.950	67.6	33.9	1300	262	0.47	0.890	2.560						
21.25	98.0	59.6	8.93	814	119.5	0.950	2.950	67.6	33.9	1250	258	0.47	0.890	2.560						
22.25	100.1	60.8	8.88	792	119.5	0.950	2.950	67.6	33.9	1250	253	0.47	0.890	2.560						
23.25	99.7	60.6	8.94	800	119.5	0.950	2.950	67.6	33.9	1170	257	0.47	0.890	2.560						
0.25	99.5	60.5	8.96	804	112.6	0.900	2.830	53.3	33.9	1170	230	0.47	0.890	2.560						
1.25	98.6	60.8	8.95	810	112.6	0.900	2.830	53.3	33.9	1265	248	0.47	0.890	2.560						
2.25	100.8	61.2	8.92	790	112.6	0.900	2.830	53.3	33.9	1265	250	0.47	0.890	2.560						
3.25	99.3	60.4	8.91	801	112.6	0.900	2.830	53.3	33.9	1280	242	0.47	0.890	2.560						
4.25	99.9	60.7	8.89	795	112.6	0.900	2.830	53.3	33.9	1280	235	0.47	0.890	2.560						
5.25	99.7	60.6	8.82	790	112.6	0.900	2.830	53.3	33.9	1335	234	0.47	0.890	2.560						
6.25	100.1	60.8	8.45	754	112.6	0.900	2.830	53.3	33.9	1405	238	0.47	0.890	2.560						
7.25	--	--	--	--	112.6	0.900	2.830	53.3	33.9	1405	--	0.47	0.890	2.560						

0.00 - 7.27

MAX	101.4	61.6	9.03	844.	112.6	0.900	2.830	53.4	33.9	1405.	261.	0.47	0.890	2.560						
MIN	33.9	57.4	2.41	217.	112.6	0.900	2.830	53.4	33.9	1170.	197.	0.47	0.890	2.560						
MEAN	99.5	60.5	8.76	786.	112.6	0.900	2.830	53.4	33.9	1297.	240.	0.47	0.890	2.560	7.46	6.83				
ACCM	682.6	413.3	59.84	786.	112.6	0.900	2.830	53.4	33.9	1301.	249.	0.47	0.890	2.560	56.39	65.47				

0.00 - 0.00

MAX	101.4	61.6	9.32	875.	119.5	0.970	2.950	71.0	33.9	1385.	332.	0.47	0.890	2.560						
MIN	94.2	57.3	8.67	773.	112.6	0.900	2.770	53.4	33.9	1140.	185.	0.47	0.890	2.560						
MEAN	99.6	60.6	8.99	806.	119.0	0.957	2.850	68.6	33.9	1254.	252.	0.47	0.890	2.560	24.01	24.02				
ACCM	2391.1	1453.8	215.74	806.	118.8	0.955	2.850	68.1	33.9	1251.	252.	0.47	0.890	2.560	48.91	58.64				

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ Z02 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCO EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO		0A2V1
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM		
7.25	1.9	30.4	75	4.30	810	163	792	292	634	405	393	408	588	-0.17	845		
8.25	1.9	30.7	74	3.90	810	158	792	282	640	404	392	408	582	-0.04	846		
9.25	1.9	31.6	69	3.64	812	185	791	280	636	403	391	406	584	-0.03	849		
10.25	1.9	33.7	72	3.84	812	152	792	286	640	400	389	405	580	-0.03	848		
11.25	1.9	32.2	78	4.02	809	157	794	292	639	404	392	405	587	-0.03	850		
12.25	1.9	35.3	72	3.91	812	172	790	296	637	401	393	408	579	-0.02	859		
13.25	1.9	35.2	78	3.75	812	177	794	305	638	407	393	408	599	-0.02	860		
14.25	1.9	32.3	78	4.10	811	182	795	310	641	404	392	407	597	-0.03	851		
15.25	1.9	34.3	82	3.14	808	172	786	303	629	398	385	402	601	-0.02	856		
16.25	1.9	31.1	72	3.13	809	187	792	305	644	411	398	413	605	0.00	869		
17.25	1.9	34.9	96	3.04	806	189	788	327	634	403	392	406	615	-0.02	872		
18.25	1.9	33.7	85	2.89	808	175	788	305	640	404	391	408	596	-0.02	871		
19.25	1.9	34.3	126	10.50	807	216	788	342	626	395	384	402	619	-0.02	871		
20.25	1.9	33.1	128	1.84	806	213	789	349	633	398	385	402	635	-0.04	870		
21.25	1.9	33.3	120	2.57	805	215	786	331	630	395	384	400	631	-0.04	873		
22.25	1.9	32.0	108	3.28	803	197	782	324	630	398	386	403	630	-0.05	873		
23.25	1.9	29.2	124	3.22	801	217	786	331	630	401	389	404	635	-0.05	870		
0.25	1.9	31.1	99	3.38	805	186	783	304	633	402	392	407	619	-0.04	871		
1.25	2.0	31.1	101	3.06	805	191	782	305	636	403	394	405	624	-0.04	872		
2.25	1.9	30.4	102	3.06	803	198	781	304	633	404	394	407	614	-0.04	871		
3.25	2.0	30.2	96	3.16	803	175	780	307	629	400	393	406	617	-0.05	873		
4.25	2.0	30.6	95	3.61	804	187	785	307	636	403	394	408	608	-0.07	873		
5.25	1.9	28.6	98	3.96	804	182	782	304	627	404	396	408	622	-0.06	872		
6.25	2.0	23.9	103	4.68	802	171	778	297	626	397	387	401	609	-0.05	854		
7.25	--	--	--	--	--	--	--	--	--	--	--	364	--	--	--		

0.00 - 7.28

MAX	2.0	32.1	123.	4.86	809.	219.	790.	328.	640.	409.	400.	412.	634.	-0.03	880.
MIN	0.5	19.5	79.	2.67	789.	148.	761.	244.	606.	385.	378.	360.	492.	-0.19	769.
MEAN	2.0	29.7	100.	3.63	804.	189.	783.	305.	629.	402.	393.	404.	615.	-0.06	869.
ACCM	2.0	29.7	100.		804.	189.	783.	305.	629.	402.	393.	404.	615.	-0.06	869.

0.00 - 0.00

MAX	2.0	42.2	153.	10.62	816.	249.	805.	369.	648.	414.	402.	416.	648.	0.00	883.
MIN	1.9	28.8	58.	0.88	800.	135.	775.	261.	616.	392.	378.	397.	551.	-0.20	830.
MEAN	2.0	33.0	85.	3.68	810.	182.	790.	303.	635.	402.	390.	406.	597.	-0.04	859.
ACCM	2.0	33.0	85.		810.	182.	790.	303.	635.	402.	390.	406.	597.	-0.04	859.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL	LTWT	LTWT	LTWT	LTWTGSP	NOXL	NOXL	A50T1	DA15X1	DA1X2CO	DA2V1	Z	T/H	RPM	
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	Z	Z	
7.25				1290	1291	1290	32.2	32.3	0.205	408	0.09	4.30	-0.17	8.83	845
8.25				1220	1270	1250	32.8	33.8	0.182	408	-0.05	3.90	-0.04	9.00	846
9.25				1270	1270	1270	34.8	35.0	-0.071	406	0.15	3.64	-0.03	9.03	849
10.25				1260	1263	1263	37.3	36.4	-0.038	405	0.00	3.84	-0.03	9.01	848
11.25				1260	1252	1254	34.1	33.9	0.082	405	-0.01	4.02	-0.03	9.04	850
12.25				1220	1224	1236	30.2	28.9	0.043	408	0.03	3.91	-0.02	8.94	859
13.25				1290	1219	1262	30.1	30.0	-0.163	408	0.00	3.75	-0.02	9.00	860
14.25				1290	1191	1252	27.1	25.8	-0.124	407	-0.20	4.10	-0.03	9.16	851
15.25				1140	1199	1255	26.6	27.1	-0.105	402	-0.17	3.14	-0.02	9.17	856
16.25				1140	1200	1211	35.6	29.9	0.421	413	0.88	3.13	0.00	9.18	869
17.25				1250	1282	1256	35.0	35.8	0.055	406	0.32	3.04	-0.02	9.19	872
18.25				1250	1268	1244	34.3	34.8	0.066	408	0.66	2.89	-0.02	9.21	871
19.25				1250	1235	1242	32.1	32.4	-0.116	402	-0.74	10.50	-0.02	9.13	871
20.25				1300	1501	1466	50.3	50.7	0.667	402	0.49	1.94	-0.04	9.05	870
21.25				1250	1448	1414	45.5	47.2	-0.437	400	0.13	2.57	-0.04	8.93	873
22.25				1250	1288	1243	35.5	36.2	-0.230	403	0.04	3.28	-0.05	8.88	873
23.25				1170	1344	1251	40.8	40.0	0.431	404	0.00	3.22	-0.05	8.94	870
0.25				1170	1325	1299	37.7	38.7	-0.106	407	0.30	3.30	-0.04	8.96	871
1.25				1265	1282	1278	38.1	37.3	-0.017	405	-0.27	3.06	-0.04	8.95	872
2.25				1265	1279	1276	37.8	37.0	-0.050	407	0.26	3.06	-0.04	8.92	871
3.25				1280	1297	1293	40.2	39.1	0.127	406	0.03	3.16	-0.05	8.91	873
4.25				1280	1346	1330	43.5	43.9	0.061	400	0.20	3.61	-0.07	8.89	873
5.25				1335	1356	1351	45.7	45.5	0.026	408	0.20	3.96	-0.06	8.82	872
6.25				1405	1354	1349	45.3	45.3	-0.151	401	-0.35	4.68	-0.05	8.45	854
7.25				1405	1337	1204	42.6	42.6	-0.042	364	-1.57	--	--	--	--

0.00 - 7.30

MAX				1405.	1383.	1376.	48.7	48.3	0.288	412.	0.35	4.86	-0.03	9.03	880.
MIN				1170.	1274.	1202.	36.3	36.5	-0.234	359.	-2.04	2.67	-0.19	2.41	769.
MEAN	6.83	7.50		1298.	1325.	1316.	41.5	41.5	0.014	404.	-0.16	3.63	-0.06	8.76	869.
ACCM	65.47	56.43		1301.		1316.			0.014	404.	-0.16		-0.06	59.84	869.

0.00 - 0.00

MAX				1385.	1571.	1524.	55.3	55.6	0.864	416.	1.01	10.62	0.00	9.32	883.
MIN				1140.	1101.	1143.	23.1	23.0	-0.610	397.	-1.22	0.88	-0.20	8.67	830.
MEAN	24.02	24.01		1254.	1294.	1286.	34.8	34.8	0.011	406.	0.01	3.68	-0.04	8.99	859.
ACCM	58.64	48.91		1251.		1286.			0.011	406.	0.01		-0.04	215.74	859.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU' PER SH. T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOURL	HO10F1	PRODR	KCAL	C-MOIST	C-HEAT	STONS	RTU	LTWT					
	PROD	KM2F1	NKCAL	C-ASH		LB. COAL		KM2F1*					
	T/H	T	KC/KG	%	%	T/H		GR/L	H				
7.25	98.8	60.0	1442	8.83	798	816	20.0	3.22	9555	65.2	0	28.61	1290
8.25	99.1	60.3	1447	9.00	810	829	20.0	3.22	9555	65.4	0	28.81	1220
9.25	99.1	60.2	1446	9.03	814	832	20.0	3.22	9555	65.4	0	28.99	1270
10.25	99.5	60.5	1452	9.01	808	827	20.0	3.22	9555	65.7	0	28.76	1260
11.25	99.7	60.6	1455	9.04	810	828	20.0	3.22	9555	65.8	0	29.18	1260
12.25	100.7	61.2	1470	8.94	792	811	20.0	3.22	9555	66.4	0	28.36	1220
13.25	100.1	60.9	1461	9.00	803	821	20.0	3.22	9555	66.1	0	28.95	1290
14.25	100.6	61.1	1468	9.16	813	832	20.0	3.22	9552	66.4	0	29.09	1290
15.25	99.0	60.2	1445	9.17	826	845	20.0	3.22	9555	65.4	0	29.42	1140
16.25	98.8	60.1	1442	9.18	829	848	20.0	3.22	9552	65.2	0	29.60	1140
17.25	99.7	60.6	1455	9.19	822	841	20.0	3.22	9552	65.8	0	29.32	1250
18.25	100.0	60.8	1459	9.21	823	842	20.0	3.22	9552	66.0	0	29.49	1250
19.25	99.9	60.7	1459	9.13	815	834	20.0	3.22	9555	65.9	0	29.05	1250
20.25	99.4	60.4	1451	9.05	813	832	20.0	3.22	9552	65.6	0	29.81	1300
21.25	98.0	59.6	1430	8.93	814	833	20.0	3.22	9552	64.7	0	28.96	1250
22.25	100.1	60.8	1461	8.88	792	811	20.0	3.22	9552	66.0	0	28.29	1250
23.25	99.7	60.6	1455	8.94	800	819	20.0	3.22	9552	65.8	0	28.54	1170
0.25	99.5	60.5	1453	8.96	804	822	20.0	3.22	9552	65.7	0	28.78	1170
1.25	98.6	60.0	1440	8.95	810	829	20.0	3.22	9552	65.1	0	29.03	1265
2.25	100.8	61.2	1471	8.92	790	808	20.0	3.22	9555	66.5	0	28.21	1265
3.25	99.3	60.4	1449	8.91	801	819	20.0	3.22	9552	65.5	0	28.55	1280
4.25	99.9	60.7	1458	8.89	795	813	20.0	3.22	9555	65.9	0	28.54	1280
5.25	99.7	60.6	1455	8.82	790	808	20.0	3.22	9555	65.8	0	28.31	1335
6.25	100.1	60.8	1460	8.45	754	771	20.0	3.22	9555	66.0	0	26.95	1405
7.25	--	--	-63	--	--	--	20.0	3.22	9555	-2.8	--	--	1405

0.00 - 7.30													
MAX	101.4	61.6	1479.	9.03	844.	864.	20.0	3.22	9556.	66.9	0.	30.17	1405.
MIN	33.9	57.4	-79.	2.41	217.	222.	20.0	3.22	9550.	-3.6	0.	7.77	1170.
MEAN	99.5	60.5	1321.	8.76	786.	804.	20.0	3.22	9553.	59.7	0.	28.10	1298. 6.83
ACCM	682.6	413.3		59.84	786.	804.	20.0	3.22			0.	28.10	1301. 65.47
0.00 - 0.00													
MAX	101.4	61.6	1479.	9.32	875.	896.	20.0	3.22	9556.	66.9	0.	31.28	1385.
MIN	94.2	57.3	1374.	8.67	773.	791.	20.0	3.22	9553.	62.2	0.	27.64	1140.
MEAN	99.6	60.6	1454.	8.99	806.	825.	20.0	3.22	9557.	65.8	0.	28.80	1254. 24.82
ACCM	2391.1	1453.8		215.74	806.	824.	20.0	3.22			0.	28.81	1251. 58.64

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-D-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1	KM2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTR						
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KM2F1#	H	H				
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.25	--	--	--	--	112.6	0.900	2.830	53.3	33.9	1405	--	0.47	0.890	2.560
8.25	--	--	--	--	112.6	0.900	2.830	53.3	33.9	1405	--	0.47	0.890	2.560
9.25	--	--	--	--	112.6	0.900	2.830	53.3	33.9	1405	--	0.47	0.890	2.560
10.25	--	--	--	--	112.6	0.900	2.830	53.3	33.9	1405	--	0.47	0.890	2.560
11.25	--	-3.1	0.00	9	112.6	0.900	2.830	53.3	33.9	1405	22	0.47	0.890	2.560
12.25	61.5	37.4	6.53	948	112.6	0.900	2.830	53.3	33.9	1405	75	0.47	0.890	2.560
13.25	71.5	43.4	7.20	899	117.8	0.940	2.940	65.0	35.0	1405	108	0.24	0.970	3.020
14.25	80.9	49.2	7.82	863	117.8	0.940	2.940	65.0	35.0	1405	107	0.24	0.970	3.020
15.25	98.8	60.1	8.18	739	117.8	0.940	2.940	65.0	35.0	1510	130	0.24	0.970	3.020
16.25	98.9	60.1	8.79	794	117.8	0.940	2.940	65.0	35.0	1525	174	0.24	0.970	3.020
17.25	99.6	60.5	8.51	763	111.5	0.880	2.930	47.1	35.0	1160	165	0.24	0.970	3.020
18.25	99.9	60.7	8.48	758	111.5	0.880	2.930	47.1	35.0	1350	176	0.24	0.970	3.020
19.25	98.8	60.0	8.22	743	111.5	0.880	2.930	47.1	35.0	1445	167	0.24	0.970	3.020
20.25	100.1	60.9	8.25	735	111.5	0.880	2.930	47.1	35.0	1340	183	0.24	0.970	3.020
21.25	99.4	60.4	8.30	745	111.5	0.880	2.930	47.1	35.0	1275	176	0.24	0.970	3.020
22.25	99.4	60.4	8.32	747	111.5	0.880	2.930	47.1	35.0	1260	179	0.24	0.970	3.020
23.25	100.5	61.1	8.35	742	111.5	0.880	2.930	47.1	35.0	1295	187	0.24	0.970	3.020
0.25	100.1	60.8	8.45	754	111.5	0.880	2.930	47.1	35.0	1335	190	0.24	0.970	3.020
1.25	100.0	60.8	8.46	755	119.8	0.970	2.780	70.4	35.0	1295	193	0.24	0.970	3.020
2.25	--	--	--	--	119.8	0.970	2.780	70.4	35.0	1295	--	0.24	0.970	3.020
3.25	71.0	43.1	7.24	910	119.8	0.970	2.780	70.4	35.0	1295	164	0.24	0.970	3.020
4.25	96.7	58.8	8.47	782	119.8	0.970	2.780	70.4	35.0	1140	180	0.24	0.970	3.020
5.25	100.4	61.0	8.48	754	119.8	0.970	2.780	70.4	35.0	1245	165	0.24	0.970	3.020
6.25	99.8	60.6	8.66	775	119.8	0.970	2.780	70.4	35.0	1265	190	0.24	0.970	3.020
7.25	99.4	60.4	8.60	773	119.4	0.970	2.760	69.7	35.0	1290	174	0.24	0.970	3.020

0.00 - 7.27														
MAX	101.7	61.9	8.74	24139.	119.8	0.970	2.930	70.4	35.0	1335.	218.	0.24	0.970	3.020
MIN	-4.4	-2.8	1.12	-39964.	111.5	0.880	2.760	47.1	35.0	1140.	111.	0.24	0.970	3.020
MEAN	93.7	57.4	8.23	778.	119.3	0.965	2.788	68.9	35.0	1273.	180.	0.24	0.970	3.020 7.46 6.81
ACCM	649.5	390.4	56.01	779.	119.8	0.970	2.780	70.4	35.0	1270.	180.	0.24	0.970	3.020 80.22 84.72
0.00 - 0.00														
MAX	101.4	61.6	9.03	29898.	117.8	0.940	2.940	65.1	35.0	1525.	261.	0.47	0.970	3.020
MIN	-4.5	-3.4	2.04	-23878.	111.5	0.880	2.830	47.1	33.9	1160.	20.	0.24	0.890	2.560
MEAN	93.3	56.7	8.24	801.	113.1	0.900	2.878	53.3	34.4	1350.	183.	0.36	0.928	2.775 24.01 19.50
ACCM	1820.4	1105.0	160.61	789.	113.1	0.900	2.882	53.2	34.5	1340.	183.	0.36	0.930	2.790 72.85 77.99

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ Z02 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCO EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0		0A2V1
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM		
7.25	--	--	--	--	--	--	--	--	--	--	--	383	--	--	--	--	
8.25	--	--	--	--	--	--	--	--	--	--	--	370	--	--	--	--	
9.25	--	--	--	--	--	--	--	--	--	--	--	366	--	--	--	--	
10.25	--	--	--	--	--	--	--	--	--	--	--	359	--	--	--	--	
11.25	0.4	0.4	-9	10.34	591	7	624	-5	560	344	360	339	-15	-0.18	421		
12.25	1.2	6.6	64	1.37	798	121	754	181	619	415	410	412	292	-0.05	679		
13.25	1.4	9.8	48	2.41	794	111	763	179	618	404	401	410	318	-0.05	703		
14.25	1.6	15.4	56	1.58	799	121	770	188	630	404	401	411	357	-0.03	731		
15.25	1.9	16.4	130	2.78	798	210	768	308	611	375	370	382	555	-0.05	851		
16.25	1.9	13.8	116	2.14	799	207	781	308	613	379	373	384	570	-0.04	852		
17.25	1.9	16.9	126	3.02	799	208	778	315	614	390	371	385	578	-0.04	854		
18.25	1.9	15.6	132	3.13	799	190	784	326	617	381	374	387	578	-0.05	852		
19.25	1.9	16.4	132	3.52	799	209	780	331	620	381	373	387	587	-0.07	853		
20.25	1.9	14.4	137	3.45	799	203	783	330	614	382	375	387	587	-0.07	854		
21.25	1.9	15.3	123	3.56	799	190	779	324	620	382	373	386	583	-0.06	852		
22.25	1.9	16.2	137	1.95	797	221	774	330	615	378	370	383	587	-0.05	855		
23.25	1.9	15.6	140	2.33	801	218	778	328	612	377	369	383	583	-0.05	851		
0.25	1.9	16.6	134	2.18	802	223	778	330	615	379	368	385	587	-0.05	851		
1.25	1.9	18.7	132	2.33	800	219	777	335	616	379	372	385	598	-0.06	851		
2.25	--	--	--	--	--	--	--	--	--	--	--	408	--	--	--		
3.25	1.5	12.3	74	0.99	799	132	774	206	620	394	390	398	351	0.08	688		
4.25	1.9	18.2	127	2.41	801	196	767	297	608	375	367	378	531	0.05	802		
5.25	1.9	20.7	99	2.55	806	183	779	285	620	386	384	394	543	0.02	820		
6.25	1.9	21.8	92	2.57	806	165	777	283	612	384	380	389	545	0.02	819		
7.25	1.9	24.4	93	2.33	805	184	771	282	606	378	372	383	543	0.02	820		

0.00 - 7.28	
MAX	2.0 25.0 150. 10.42 808. 242. 789. 345. 636. 424. 420. 422. 606. 0.45 860.
MIN	-0.4 0.1 -11. -0.13 700. -13. 683. -12. 578. 351. 355. 358. -1. -0.19 551.
MEAN	1.9 18.8 103. 2.37 801. 177. 773. 281. 614. 383. 378. 389. 520. 0.01 802.
ACCM	1.9 18.8 103. 801. 177. 773. 281. 614. 383. 378. 389. 520.
0.00 - 0.00	
MAX	2.0 39.6 153. 10.44 809. 245. 790. 345. 640. 470. 464. 439. 634. 1.15 890.
MIN	0.2 0.1 -11. -0.09 574. -3. 683. -6. 548. 346. 368. 329. -19. -0.19 418.
MEAN	1.9 20.5 103. 3.17 797. 182. 774. 287. 619. 393. 386. 391. 536. -0.06 822.
ACCM	1.9 20.5 103. 797. 182. 774. 287. 619. 393. 386. 391. 536.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTM FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTM	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	W1/ ZCD EX PREHEAT
KILN CON. MEASUR.	W1/ COAL TO KILN
KILN CONTROL	J1/ ID FAN SPEED
COAL TO KILN	

HOUR	KM2F1#		KALARM		ESTLTM		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		LTWT		LTWTGSP		NOXL		A50T1		DA15X1		DA1X2C0	DA2V1	
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM
7.25				1405	1341	1352	43.9	43.0	-0.113	383	-1.58	--	--	--	--
8.25				1405	1318	1195	40.9	40.9	-0.056	370	0.17	--	--	--	--
9.25				1405	1302	1187	39.4	39.4	-0.049	366	-0.28	--	--	--	--
10.25				1405	1285	1179	37.9	37.9	-0.049	359	-0.20	--	--	--	--
11.25				1405	1269	1171	36.4	36.4	-0.049	339	-0.75	10.34	-0.18	0.00	421
12.25				1405	1088	1077	15.6	12.8	-0.263	412	-1.45	1.37	-0.05	6.53	679
13.25				1405	1254	1280	33.7	35.1	0.043	410	-0.37	2.41	-0.05	7.20	703
14.25				1405	1375	1380	45.8	46.0	0.316	411	-0.27	1.58	-0.03	7.82	731
15.25				1510	1758	1430	63.1	69.0	0.468	382	-1.80	2.78	-0.05	8.18	851
16.25				1525	1188	1380	28.7	24.5	0.034	384	0.18	2.14	-0.04	8.79	852
17.25				1160	1402	1371	40.7	44.1	0.329	385	0.21	3.02	-0.04	8.51	854
18.25				1350	1497	1467	49.5	50.1	0.239	387	-0.12	3.13	-0.05	8.48	852
19.25				1445	1428	1431	45.1	45.6	-0.320	387	0.09	3.52	-0.07	8.22	853
20.25				1340	1323	1327	37.3	38.8	-0.038	387	0.23	3.45	-0.07	8.25	854
21.25				1275	1297	1292	37.8	37.0	-0.247	386	-0.26	3.56	-0.06	8.30	852
22.25				1260	1388	1297	38.4	37.9	-0.032	383	-0.40	1.95	-0.05	8.32	855
23.25				1295	1338	1328	43.2	39.8	0.203	383	0.06	2.33	-0.05	8.35	851
0.25				1335	1522	1338	55.4	54.5	0.174	385	-0.20	2.18	-0.05	8.45	851
1.25				1295	1312	1320	41.5	41.0	-0.633	385	-0.10	2.33	-0.06	8.46	851
2.25				1295	1335	1250	45.3	45.1	0.535	408	3.36	--	--	--	--
3.25				1295	1100	1161	0.7	2.8	-1.194	398	1.63	0.99	0.08	7.24	688
4.25				1140	1037	1159	7.7	-8.5	0.479	378	-0.20	2.41	0.05	8.47	802
5.25				1245	1366	1347	48.3	50.7	0.024	394	-0.60	2.55	0.02	8.48	820
6.25				1265	1290	1304	43.1	42.3	0.188	389	-0.15	2.57	0.02	8.66	819
7.25				1290	1304	1300	43.8	44.6	-0.002	383	-0.01	2.33	0.02	8.60	820

0.00 - 7.30															
MAX			1335.	1605.	4252.	56.0	56.2	3.840	422.	4.25	10.42	0.45	8.74	860.	
MIN			1140.	956.	1113.	-22.7	-23.3	-2.195	358.	-4.92	-0.13	-0.19	1.12	551.	
MEAN	6.85	7.50	1273.	1290.	1383.	33.9	34.0	-0.018	389.	0.00	2.37	0.01	8.24	802.	
ACCH	84.76	80.26	1270.		1383.			-0.018	389.	0.00		0.01	56.39	802.	
0.00 - 8.00															
MAX			1525.	1801.	5244.	71.7	71.9	1.146	439.	11.54	10.44	1.15	9.03	880.	
MIN			1160.	928.	1022.	8.5	5.6	-2.708	329.	-4.70	-0.09	-0.19	2.04	418.	
MEAN	19.50	24.01	1350.	1322.	1337.	40.0	40.0	0.013	391.	-0.03	3.17	-0.06	8.24	822.	
ACCH	77.99	72.85	1340.		1337.			0.013	391.	-0.03		-0.06	160.61	822.	

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU' PER SH. T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HD10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		BTU		LTWT	
	PROD	T	PROD	T	KM2F1	NKCAL	C-ASH	%	%	T/H	LB.COAL	T/H	GR/L	H	KM2F1*	
7.25	--	--	-68	--	--	--	20.0	3.22	9555	-3.1	--	--			1485	
8.25	--	--	-63	--	--	--	20.0	3.22	9555	-2.8	--	--			1485	
9.25	--	--	-66	--	--	--	20.0	3.22	9552	-2.9	--	--			1485	
10.25	--	--	-63	--	--	--	20.0	3.22	9552	-2.8	--	--			1485	
11.25	--	-3.1	-75	0.00	9	9	20.0	3.22	9555	-3.4	0	-0.00			1485	
12.25	61.5	37.4	897	6.53	948	969	20.0	3.22	9555	40.6	0	33.87			1485	
13.25	71.5	43.4	1043	7.20	899	920	20.0	3.22	9552	47.2	0	32.21			1485	
14.25	80.9	49.2	1181	7.82	863	883	20.0	3.22	9555	53.4	0	30.79			1485	
15.25	98.8	60.1	1442	8.18	739	756	20.4	3.22	9555	65.2	0	26.39			1510	
16.25	98.9	60.1	1443	8.79	794	812	20.0	3.22	9555	65.2	0	28.58			1525	
17.25	99.6	60.5	1453	8.51	763	781	20.0	3.22	9555	65.7	0	27.20			1160	
18.25	99.9	60.7	1457	8.48	758	775	20.0	3.22	9555	65.9	0	26.97			1350	
19.25	98.8	60.0	1441	8.22	743	760	20.0	3.22	9552	65.2	0	26.53			1445	
20.25	100.1	60.9	1461	8.25	735	752	20.0	3.22	9552	66.1	0	26.39			1340	
21.25	99.4	60.4	1450	8.30	745	763	20.0	3.22	9552	65.6	0	26.52			1275	
22.25	99.4	60.4	1451	8.32	747	764	20.0	3.22	9552	65.6	0	26.73			1260	
23.25	100.5	61.1	1467	8.35	742	759	20.0	3.22	9552	66.3	0	26.62			1295	
0.25	100.1	60.8	1461	8.45	754	771	20.0	3.22	9555	66.0	0	26.97			1335	
1.25	100.0	60.8	1459	8.46	755	773	20.0	3.22	9552	66.0	0	27.03			1295	
2.25	--	--	-65	--	--	--	20.0	3.22	9555	-2.9	--	--			1295	
3.25	71.0	43.1	1036	7.24	910	931	20.0	3.22	9555	46.8	0	32.42			1295	
4.25	96.7	58.8	1412	8.47	782	800	20.0	3.22	9552	63.8	0	27.94			1140	
5.25	100.4	61.0	1465	8.48	754	771	20.0	3.22	9552	66.2	0	26.98			1245	
6.25	99.8	60.6	1456	8.66	775	793	20.0	3.22	9552	65.8	0	27.79			1265	
7.25	99.4	60.4	1450	8.60	773	791	20.0	3.22	9555	65.6	0	27.71			1290	

0.00 - 7.30

MAX	101.7	61.9	1485.	8.74	24139.	24698.	20.0	3.22	9556.	67.2	9.	862.43			1335.
MIN	-4.4	-2.8	-79.	1.12	-39964.	-40877.	20.0	3.22	9553.	-3.6	-15.	-1427.8			1140.
MEAN	93.7	57.4	1271.	8.24	778.	796.	20.0	3.22	9554.	57.5	0.	27.77		6.86	1273.
ACCH	654.7	393.7		56.47	779.	796.	20.0	3.22			0.	27.77		84.77	1270.

0.00 - 0.00

MAX	101.4	61.6	1479.	9.03	29888.	30581.	20.0	3.22	9556.	66.9	11.	1068.2			1525.
MIN	-4.5	-3.4	-82.	2.04	-23878.	-24432.	20.0	3.22	9550.	-3.7	-9.	-853.13			1160.
MEAN	93.3	56.7	1094.	8.24	801.	820.	20.0	3.22	9556.	49.5	0.	28.63		19.50	1350.
ACCH	1820.4	1105.0		160.61	789.	820.	20.0	3.22			0.	28.63		77.99	1340.

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-0-IG
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HO10F1	KN2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL	KN2F1*					
	PROD	KCAL								KF-LS	C3S	LTWT	FCAO	CL-MS
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.26	99.1	60.2	8.62	777	119.8	0.970	2.760	70.4	35.0	1290	181	0.24	0.970	3.020
8.26	--	--	--	--	119.4	0.970	2.760	69.7	35.0	1320	--	0.24	0.970	3.020
9.26	-1.2	--	--	--	119.4	0.970	2.760	69.7	35.0	1320	--	0.24	0.970	3.020
10.26	--	--	--	--	119.4	0.970	2.760	69.7	35.0	1320	--	0.24	0.970	3.020
11.26	72.0	43.7	5.89	730	119.4	0.970	2.760	69.7	35.0	1320	102	0.24	0.970	3.020
12.26	76.5	46.5	6.62	772	112.5	0.890	2.760	50.1	34.7	1320	204	0.47	0.910	3.100
13.26	81.8	49.7	7.14	779	112.5	0.890	2.760	50.1	34.7	1320	145	0.47	0.910	3.100
14.26	86.5	52.6	8.06	831	112.5	0.890	2.760	50.1	34.7	1320	186	0.47	0.910	3.100
15.26	84.9	51.6	8.29	872	112.5	0.890	2.760	50.1	34.7	1320	145	0.47	0.910	3.100
16.26	87.3	53.0	8.45	865	116.8	0.920	2.980	60.0	34.7	1080	144	0.47	0.910	3.100
17.26	92.1	56.0	8.73	847	116.8	0.920	2.980	60.0	34.7	1220	168	0.47	0.910	3.100
18.26	95.8	58.2	8.79	819	116.8	0.920	2.980	60.0	34.7	1340	193	0.47	0.910	3.100
19.26	99.7	60.6	8.75	784	116.8	0.920	2.980	60.0	34.7	1330	243	0.47	0.910	3.100
20.26	99.0	60.2	8.98	810	116.8	0.920	2.980	60.0	34.7	1330	242	0.47	0.910	3.100
21.26	100.2	60.9	8.92	795	116.8	0.920	2.980	60.0	34.7	1250	233	0.47	0.910	3.100
22.26	99.3	60.4	8.76	788	116.8	0.920	2.980	60.0	34.7	1360	252	0.47	0.910	3.100
23.26	98.9	60.1	8.78	793	116.8	0.920	2.980	60.0	34.7	1305	259	0.47	0.910	3.100
0.25	100.5	61.1	8.84	785	120.2	0.970	2.810	71.2	34.7	1200	241	0.47	0.910	3.100
1.25	99.7	60.6	8.96	802	120.2	0.970	2.810	71.2	34.7	1185	212	0.47	0.910	3.100
2.25	99.5	60.5	8.97	805	120.2	0.970	2.810	71.2	34.7	1275	219	0.47	0.910	3.100
3.25	99.8	60.7	8.90	796	120.2	0.970	2.810	71.2	34.7	1345	216	0.47	0.910	3.100
4.25	--	--	--	--	120.2	0.970	2.810	71.2	34.7	1345	--	0.47	0.910	3.100
5.25	-0.5	--	--	--	120.2	0.970	2.810	71.2	34.7	1375	--	0.47	0.910	3.100
6.25	--	--	--	--	120.2	0.970	2.810	71.2	34.7	1375	--	0.47	0.910	3.100
7.25	48.8	29.7	4.01	734	120.2	0.970	2.810	71.2	34.7	1375	93	0.47	0.910	3.100

0.00 - 7.27	
MAX	101.1 61.5 9.28 10082. 120.2 0.970 2.810 71.2 34.7 1375. 253. 0.47 0.910 3.100
MIN	-4.5 -2.9 0.01-30171. 120.2 0.970 2.810 71.2 34.7 1185. 43. 0.47 0.910 3.100
MEAN	92.5 56.9 8.54 810. 120.2 0.970 2.810 71.2 34.7 1304. 203. 0.47 0.910 3.100 7.46 5.61
ACCH	529.6 319.2 47.88 815. 120.2 0.970 2.810 71.2 34.7 1304. 203. 0.47 0.910 3.100 104.0 104.0
0.00 - 0.00	
MAX	101.7 61.9 9.01 24139. 120.2 0.970 2.980 71.2 35.0 1360. 381. 0.47 0.970 3.100
MIN	-4.0 -2.8 1.12-39964. 111.5 0.880 2.760 47.1 34.7 1080. 28. 0.24 0.910 3.020
MEAN	90.6 55.5 8.20 803. 117.5 0.940 2.844 63.4 34.9 1291. 185. 0.36 0.940 3.061 24.02 20.75
ACCH	1908.5 1151.4 170.03 802. 117.5 0.940 2.841 63.5 34.9 1291. 185. 0.36 0.937 3.063 96.58 98.50

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ Z02 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCD EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0	
	0A15A1		0A15X1		A54P1		A53P1		A51T1		A50T1				0A2V1	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.26	1.9	23.8	69	2.60	804	170	772	282	607	377	373	385	549	0.00	819	
8.26	--	--	--	--	--	--	--	--	--	--	--	433	--	--	--	
9.26	--	--	--	--	--	--	--	--	--	--	--	427	--	--	--	
10.26	--	--	--	--	--	--	--	--	--	--	--	418	--	--	--	
11.26	1.4	27.9	46	3.43	782	182	753	144	618	407	409	416	254	0.01	625	
12.26	1.5	7.7	62	3.59	794	130	779	285	642	422	423	431	362	0.00	697	
13.26	1.6	17.5	63	3.42	797	133	776	222	637	415	412	423	407	0.00	746	
14.26	1.7	25.5	107	3.75	796	188	775	388	632	484	396	410	556	0.00	842	
15.26	1.7	25.6	133	3.20	800	226	784	322	643	408	399	413	574	-0.01	851	
16.26	1.7	29.3	116	2.11	803	281	790	321	639	489	483	415	573	-0.01	845	
17.26	1.8	33.6	140	2.46	804	228	784	335	637	399	394	486	605	-0.01	865	
18.26	1.9	35.1	135	2.85	887	238	786	334	627	394	386	399	618	-0.01	868	
19.26	1.9	33.6	123	3.34	805	197	789	348	628	387	379	394	607	-0.02	865	
20.26	1.9	35.2	124	3.84	885	285	788	341	629	387	378	394	611	-0.01	862	
21.26	1.9	34.8	138	1.80	886	219	783	345	628	388	377	391	618	-0.01	867	
22.26	1.9	32.4	132	2.26	885	213	785	358	622	390	381	394	629	-0.03	864	
23.26	1.9	29.9	142	2.79	885	223	788	346	629	389	383	395	636	-0.03	863	
0.25	1.9	29.6	128	2.88	884	197	786	349	626	389	384	396	630	-0.02	866	
1.25	1.9	29.6	138	2.48	886	227	786	348	632	391	385	395	644	-0.04	872	
2.25	1.9	31.8	141	2.93	885	213	787	358	625	392	384	397	639	-0.05	874	
3.25	1.9	32.3	109	3.04	887	195	789	315	639	399	392	408	615	-0.04	872	
4.25	--	--	--	--	--	--	--	--	--	--	--	398	--	--	--	
5.25	0.0	0.1	--	--	--	--	--	--	--	--	--	414	--	--	--	
6.25	--	--	--	--	--	--	--	--	--	--	--	379	--	--	--	
7.25	0.6	28.8	17	2.42	773	55	729	84	605	486	415	418	147	0.32	583	

0.00 - 7.28

MAX	2.0	42.8	157.	10.39	811.	252.	797.	370.	667.	470.	470.	455.	650.	1.14	879.
MIN	0.3	0.1	-11.	-0.86	711.	4.	706.	-2.	586.	370.	372.	378.	46.	-0.20	444.
MEAN	1.9	30.1	115.	3.03	801.	194.	781.	395.	628.	396.	391.	403.	572.	-0.05	832.
ACCH	1.9	30.1	115.		881.	194.	781.	385.	628.	396.	391.	483.	572.	-0.05	832.

0.00 - 8.00

MAX	2.0	36.4	162.	10.45	810.	257.	797.	367.	662.	467.	463.	447.	645.	1.39	880.
MIN	-0.5	0.1	-11.	-0.13	651.	-13.	657.	-12.	578.	351.	355.	358.	-1.	-0.19	380.
MEAN	1.8	24.2	118.	2.82	801.	187.	779.	295.	625.	396.	389.	402.	536.	-0.00	816.
ACCH	1.8	24.2	118.		881.	187.	779.	295.	625.	396.	389.	402.	536.	-0.00	816.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
W1/ NOX REG STIME
W1/ LTW FOR CONTRL
W1/ ESTIMATED LTW
U1/ LITER WEIGHT
KILN CON. MEASUR.
KILN CONTROL
COAL TO KILN

W1/ NOX CHANGE LT
W1/ T EXIT PREHEAT
W1/ A50T1 CHANGE
W1/ X02 KILN OUTL
W1/ XCO EX PREHEAT
W1/ COAL TO KILN
J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		KCONTRL	LTWT	GR/L	LTWTGSP	NOXLT	NOXLT	A50T1	A50T1	OA15X1	OA15X1	OA1X2CO	OA2V1	
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM
7.26				1290	1308	1320	46.0	46.4	0.228	385	-0.53	2.60	0.00	8.62	819
8.26				1320	1253	1162	22.3	27.9	-0.881	433	5.47	--	--	--	--
9.26				1320	1194	1086	6.9	6.5	-0.563	427	0.64	--	--	--	--
10.26				1320	1169	1053	-2.4	-2.6	-0.257	418	-0.11	--	--	--	--
11.26				1320	1250	5052	23.3	26.6	1.988	416	-1.60	3.43	0.01	5.89	625
12.26				1320	1240	1161	23.3	23.1	0.386	431	0.79	3.59	0.00	6.62	697
13.26				1320	1263	1247	37.4	31.1	0.441	423	0.13	3.42	0.00	7.14	746
14.26				1320	1272	1278	32.0	34.4	0.116	410	-1.49	3.75	0.00	8.06	842
15.26				1320	1232	1235	19.9	20.3	-0.013	413	0.02	3.20	-0.01	8.29	851
16.26				1080	1199	1252	31.4	31.5	0.360	415	0.15	2.11	-0.01	8.45	845
17.26				1220	1319	1308	48.3	49.0	0.372	406	0.31	2.46	-0.01	8.73	865
18.26				1340	1335	1326	49.8	51.2	0.023	399	-0.55	2.85	-0.01	8.79	868
19.26				1330	1323	1324	49.7	49.3	0.216	394	-0.53	3.34	-0.02	8.75	865
20.26				1330	1263	1269	41.6	41.2	-0.120	394	0.01	3.04	-0.01	8.98	862
21.26				1250	1326	1319	49.8	50.4	0.324	391	-0.09	1.80	-0.01	8.92	867
22.26				1360	1377	1316	54.2	57.4	0.061	394	-0.08	2.26	-0.03	8.76	864
23.26				1305	1300	1301	46.3	46.9	-0.193	395	0.10	2.79	-0.03	8.78	863
0.25				1200	1253	1244	40.9	40.4	-0.178	396	0.01	2.88	-0.02	8.84	866
1.25				1185	1292	1233	43.7	44.4	0.234	395	-0.16	2.48	-0.04	8.96	872
2.25				1275	1363	1276	52.5	52.0	0.347	397	0.19	2.93	-0.05	8.97	874
3.25				1345	1393	1327	59.1	59.0	0.167	400	0.35	3.04	-0.04	8.90	872
4.25				1345	1408	1177	60.7	61.0	0.078	398	-0.02	--	--	--	--
5.25				1375	1143	1044	33.2	27.0	-1.053	414	5.64	--	--	--	--
6.25				1375	1060	1002	17.5	17.4	-0.351	379	-1.35	--	--	--	--
7.25				1375	1003	974	10.0	10.3	-0.499	418	3.50	2.42	0.32	4.01	503

0.00 - 7.30

MAX				1375.	1423.	6087.	62.9	61.5	0.483	455.	6.23	10.39	1.14	9.28	879.
MIN				1185.	1002.	974.	8.4	10.1	-1.454	378.	-4.48	-0.06	-0.20	0.01	444.
MEAN	5.65	7.50		1304.	1256.	1506.	40.9	40.9	-0.133	403.	0.17	3.03	-0.05	8.51	831.
ACCM	104.1	104.0		1304.		1506.			-0.133	403.	0.17		-0.05	48.05	831.

0.00 - 8.00

MAX				1360.	1605.	5231.	60.1	60.1	3.840	447.	5.73	10.45	1.39	9.01	880.
MIN				1080.	956.	1045.	-22.7	-23.3	-2.195	358.	-4.92	-0.13	-0.19	1.12	380.
MEAN	20.75	24.02		1291.	1275.	1343.	33.4	33.5	-0.007	402.	0.02	2.82	-0.00	8.20	816.
ACCM	98.50	96.58		1291.		1343.			-0.007	402.	0.02		-0.00	170.03	816.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH.T
W1/ COAL TO KILN	MBTU' PER SH.T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU	LTWT	
	PROD		KN2F1	NKCAL		C-ASH				LB.COAL		KN2F1*	
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%		T/H		GR/L H	
7.26	99.1	60.2	1446	8.62	777	795	20.0	3.22	9552	65.4	0	27.73	1290
8.26	--	--	-26	--	--	--	20.0	3.22	9552	-1.1	--	--	1320
9.26	-1.2	--	-17	--	--	--	20.0	3.22	9552	-0.8	--	--	1320
10.26	--	--	-73	--	--	--	20.0	3.22	9552	-3.3	--	--	1320
11.26	72.0	43.7	1050	5.89	730	747	20.0	3.22	9552	47.5	0	26.30	1320
12.26	76.5	46.5	1116	6.62	772	791	20.0	3.34	9538	50.5	0	27.63	1320
13.26	81.8	49.7	1194	7.14	779	797	20.0	3.34	9541	54.0	0	27.89	1320
14.26	86.5	52.6	1263	8.06	831	852	20.0	3.34	9538	57.1	0	29.55	1320
15.26	84.9	51.6	1239	8.29	872	893	20.0	3.34	9538	56.0	0	31.07	1320
16.26	87.3	53.0	1274	8.45	865	886	20.0	3.34	9538	57.6	0	30.77	1080
17.26	92.1	56.0	1344	8.73	847	867	20.0	3.34	9541	60.7	0	30.29	1220
18.26	95.8	58.2	1399	8.79	819	839	20.0	3.34	9541	63.2	0	29.14	1340
19.26	99.7	60.6	1454	8.75	784	803	20.0	3.34	9541	65.8	0	27.93	1330
20.26	99.0	60.2	1445	8.98	810	830	20.0	3.34	9541	65.3	0	28.92	1330
21.26	100.2	60.9	1462	8.92	795	814	20.0	3.34	9541	66.1	0	28.34	1250
22.26	99.3	60.4	1449	8.76	788	807	20.0	3.34	9541	65.5	0	28.10	1360
23.26	98.9	60.1	1443	8.78	793	812	20.0	3.34	9538	65.2	0	28.21	1305
0.25	100.5	61.1	1467	8.84	785	805	20.0	3.34	9541	66.3	0	27.93	1200
1.25	99.7	60.6	1456	8.96	802	822	20.0	3.34	9538	65.8	0	28.57	1195
2.25	99.5	60.5	1452	8.97	805	825	20.0	3.34	9541	65.7	0	28.53	1275
3.25	99.8	60.7	1457	8.90	796	816	20.0	3.34	9538	65.9	0	28.45	1345
4.25	--	--	-67	--	--	--	20.0	3.34	9538	-3.0	--	--	1345
5.25	-0.5	--	-7	--	--	--	20.0	3.34	9538	-0.3	--	--	1375
6.25	--	--	-67	--	--	--	20.0	3.34	9538	-3.0	--	--	1375
7.25	48.8	29.7	712	4.01	734	752	20.0	3.34	9538	32.2	0	25.93	1375

0.00 - 7.30	
MAX	101.1 61.5 1475. 9.28 10082. 10331. 20.0 3.34 9542. 66.7 4. 359.71 1375.
MIN	-4.5 -2.9 -83. 0.01-30171. -30914. 20.0 3.34 9539. -3.7 -11. -1076.4 1185.
MEAN	92.0 56.7 1024. 8.50 809. 829. 20.0 3.34 9539. 46.3 0. 28.73 1304. 5.66
ACCM	532.3 320.8 48.10 814. 829. 20.0 3.34 0. 28.73 1304. 104.1
0.00 - 0.00	
MAX	101.7 61.9 1485. 9.01 24139. 24698. 20.0 3.34 9556. 67.2 9. 862.43 1360.
MIN	-4.8 -2.0 -80. 1.12-39964. -40877. 20.0 3.22 9539. -3.6 -15. -1427.8 1080.
MEAN	90.6 55.5 1155. 8.20 803. 822. 20.0 3.28 9545. 52.2 0. 28.65 1291. 20.75
ACCM	1908.5 1151.4 170.83 802. 823. 20.0 3.28 0. 28.65 1291. 98.50

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-16
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LINE
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI	KLO	CL-LS		KCONTRL		
	PROD					KF-LS	C3S	LTWT	FCAO	CL-MS	KM2F1#			
	T/H	T/H	T/H	KC/KG		%	%	GR/L	DEG.C	%	H	H		
7.25	--	--	--	--	120.2	0.970	2.810	71.2	34.7	1375	--	0.47	0.910	3.100
8.25	66.9	40.7	7.34	979	118.6	0.970	2.750	68.8	34.7	1080	108	0.47	0.910	3.100
9.25	93.1	56.6	8.80	844	118.6	0.970	2.750	68.8	34.7	1180	148	0.47	0.910	3.100
10.25	97.2	59.1	9.09	835	118.6	0.970	2.750	68.8	34.7	1180	130	0.47	0.910	3.100
11.25	99.0	60.1	9.04	815	118.6	0.970	2.750	68.8	34.7	1195	158	0.47	0.910	3.100
12.25	99.6	60.6	9.02	808	118.6	0.970	2.750	68.8	34.7	1210	184	0.47	0.910	3.100
13.25	100.0	60.8	8.74	780	117.4	0.940	2.940	63.6	35.2	1330	202	0.53	0.940	3.100
14.25	99.9	60.7	8.18	731	117.4	0.940	2.940	63.6	35.2	1410	205	0.53	0.940	3.100
15.25	99.6	60.5	8.60	771	117.4	0.940	2.940	63.6	35.2	1395	262	0.53	0.940	3.100
16.25	99.2	60.3	8.58	772	117.4	0.940	2.940	63.6	35.2	1395	219	0.53	0.940	3.100
17.25	100.2	60.9	8.48	755	118.5	0.950	2.850	66.4	35.2	1400	224	0.53	0.940	3.100
18.25	99.5	60.5	8.43	756	118.5	0.950	2.850	66.4	35.2	1355	223	0.53	0.940	3.100
19.25	98.8	60.0	8.28	749	118.5	0.950	2.850	66.4	35.2	1400	232	0.53	0.940	3.100
20.25	99.2	60.3	8.24	742	118.5	0.950	2.850	66.4	35.2	1385	235	0.53	0.940	3.100
21.25	99.9	60.7	8.29	741	118.5	0.950	2.850	66.4	35.2	1380	219	0.53	0.940	3.100
22.25	100.2	60.9	8.24	735	118.5	0.950	2.850	66.4	35.2	1375	235	0.53	0.940	3.100
23.25	100.4	61.0	8.31	738	118.5	0.950	2.850	66.4	35.2	1300	253	0.53	0.940	3.100
0.25	99.3	60.4	8.18	735	118.5	0.950	2.850	66.4	35.2	1320	259	0.53	0.940	3.100
1.25	99.2	60.3	8.20	738	118.5	0.950	2.850	66.4	35.2	1275	252	0.53	0.940	3.100
2.25	99.3	60.3	8.43	758	117.6	0.950	2.850	64.4	35.2	1305	238	0.53	0.940	3.100
3.25	99.2	60.3	8.28	745	117.6	0.950	2.850	64.4	35.2	1300	236	0.53	0.940	3.100
4.25	99.9	60.7	8.26	738	117.6	0.950	2.850	64.4	35.2	1330	242	0.53	0.940	3.100
5.25	99.5	60.5	8.21	737	117.6	0.950	2.850	64.4	35.2	1340	245	0.53	0.940	3.100
6.25	99.9	60.7	7.87	703	117.6	0.950	2.850	64.4	35.2	1310	248	0.53	0.940	3.100
7.25	100.9	61.3	8.26	731	117.6	0.950	2.850	64.4	35.2	1400	250	0.53	0.940	3.100

0.00 - 7.27

MAX	101.1	61.5	8.57	776.	118.5	0.950	2.850	66.4	35.2	1400.	267.	0.53	0.940	3.100	
MIN	98.0	59.6	7.82	698.	117.6	0.950	2.850	64.4	35.2	1275.	220.	0.53	0.940	3.100	
MEAN	99.6	60.5	8.21	737.	117.8	0.950	2.850	64.8	35.2	1315.	243.	0.53	0.940	3.100	7.46
ACCM	742.5	451.5	61.23	737.	117.7	0.950	2.850	64.7	35.2	1311.	243.	0.53	0.940	3.100	127.8

0.00 - 0.00

MAX	101.3	61.5	9.28	10082.	120.2	0.970	2.940	71.2	35.2	1440.	275.	0.53	0.940	3.100	
MIN	-4.5	-2.9	0.01	-30171.	117.4	0.940	2.750	63.6	34.7	1080.	43.	0.47	0.910	3.100	
MEAN	95.0	57.9	8.42	791.	118.9	0.959	2.830	68.1	35.0	1315.	200.	0.50	0.924	3.181	22.16
ACCM	2115.4	1283.4	186.43	789.	118.9	0.958	2.835	68.0	35.0	1316.	200.	0.50	0.925	3.180	120.4

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN.....	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A59P1		0A1X2CO	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.25	--	--	--	--	--	--	--	--	--	--	--	429	--	--	--	
8.25	1.3	21.4	63	0.23	798	122	767	171	629	418	411	415	305	-0.03	645	
9.25	1.9	18.9	109	3.02	805	191	784	301	632	401	392	405	561	-0.03	831	
10.25	1.9	25.1	115	2.99	804	210	790	348	638	404	394	405	636	-0.03	869	
11.25	1.9	29.6	131	2.65	805	225	792	352	637	400	392	406	628	-0.03	862	
12.25	1.9	32.7	129	2.51	807	218	794	348	629	395	391	402	633	-0.03	866	
13.25	1.9	33.6	131	2.65	809	217	791	349	633	394	391	402	635	-0.01	864	
14.25	1.9	35.2	131	4.07	806	227	785	351	632	394	388	399	631	-0.04	867	
15.25	1.9	34.4	127	3.17	809	221	789	349	639	395	392	402	630	-0.04	863	
16.25	1.9	36.2	138	3.28	808	228	796	360	633	398	389	403	630	-0.03	866	
17.25	1.9	35.1	118	3.40	810	211	797	343	640	399	392	404	630	-0.03	864	
18.25	1.9	34.7	134	3.63	808	228	796	356	636	397	392	404	639	-0.07	866	
19.25	1.9	36.1	122	3.06	808	209	793	346	631	397	386	399	616	-0.12	869	
20.25	1.9	33.3	117	3.40	810	214	792	339	637	396	387	401	618	-0.05	871	
21.25	1.9	32.3	119	3.64	810	214	791	348	631	395	398	401	619	-0.04	863	
22.25	1.9	31.3	115	3.81	806	213	789	347	629	393	384	398	618	-0.18	867	
23.25	1.9	30.1	131	3.65	807	217	788	337	628	393	380	398	608	-0.17	869	
0.25	1.9	30.9	129	3.02	806	210	788	339	623	389	379	394	612	-0.17	862	
1.25	1.9	30.3	120	2.88	807	190	790	322	618	383	375	389	582	-0.18	866	
2.25	1.9	31.5	129	3.42	807	202	790	358	631	394	384	398	628	-0.18	861	
3.25	1.9	33.7	117	3.40	805	200	785	328	632	392	383	397	608	-0.18	859	
4.25	1.9	32.8	138	3.15	807	230	793	335	631	392	382	397	613	-0.18	860	
5.25	1.9	30.9	133	3.25	806	208	791	330	626	394	389	401	614	-0.18	853	
6.25	1.9	29.5	134	3.10	806	216	783	325	611	383	376	388	588	-0.19	840	
7.25	1.9	26.5	131	3.43	805	216	784	321	623	389	383	395	606	-0.18	845	

0.00 - 7.28	
MAX	2.0 34.2 153. 4.07 811. 253. 797. 366. 639. 399. 391. 402. 646. -0.15 870.
MIN	2.0 26.2 100. 2.57 802. 173. 777. 386. 611. 379. 373. 388. 566. -0.20 831.
MEAN	2.0 31.1 128. 3.34 807. 213. 789. 336. 627. 390. 382. 396. 608. -0.18 857.
ACCH	2.0 31.1 128. 807. 213. 789. 336. 627. 390. 382. 396. 608. -0.18 857.
0.00 - 0.00	
MAX	2.0 42.8 157. 10.41 813. 252. 802. 375. 667. 470. 470. 455. 650. 1.14 879.
MIN	0.3 0.1 -11. -0.86 711. 4. 706. -2. 586. 378. 372. 378. 46. -0.20 444.
MEAN	1.9 30.9 117. 3.07 805. 202. 787. 322. 632. 397. 391. 403. 587. -0.06 840.
ACCH	1.9 30.9 117. 805. 202. 787. 322. 632. 397. 391. 403. 587. -0.06 840.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	W1/ ZCO EX PREHEAT
KILN CON. MEASUR.	W1/ COAL TO KILN
KILN CONTROL	J1/ ID FAN SPEED
COAL TO KILN	

HOUR	KM2F1#			KALARM			ESTLTW			NOXST		NOXALT		A50ALT		KM2F1	
	KCONTRL	LWT		LTWGTSP	NOXLT	A50T1	OA15X1	OA1X2CO	OA2V1								
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM		
7.25				1375	1059	2306	10.7	17.2	-0.171	429	1.67	--	--	--	--		
8.25				1080	1374	1268	62.2	63.4	1.208	415	1.09	0.23	-0.03	7.34	645		
9.25				1180	1239	508	45.6	43.8	-1.431	405	-0.87	3.02	-0.03	8.00	831		
10.25				1180	1083	448	23.3	21.0	-0.381	405	0.30	2.99	-0.03	9.09	869		
11.25				1195	1155	508	31.3	31.5	0.161	406	-0.02	2.65	-0.03	9.04	862		
12.25				1210	1265	567	48.6	49.2	0.849	402	-0.12	2.51	-0.03	9.02	866		
13.25				1330	1364	628	65.3	65.7	0.565	402	-0.08	2.65	-0.01	8.74	864		
14.25				1410	1384	1393	65.6	66.4	-0.169	399	-0.17	4.87	-0.04	8.18	867		
15.25				1395	1270	601	51.8	48.6	0.093	402	-0.04	3.17	-0.04	8.60	863		
16.25				1395	1377	657	63.5	65.3	0.271	403	0.07	3.28	-0.03	8.58	866		
17.25				1400	1360	1369	60.2	60.6	-0.131	404	0.22	3.40	-0.03	8.48	864		
18.25				1355	1406	1397	66.4	66.5	0.116	404	0.06	3.63	-0.07	8.43	866		
19.25				1400	1458	1449	73.5	72.9	0.485	399	-0.14	3.06	-0.12	8.28	869		
20.25				1385	1417	1388	69.3	70.5	-0.127	401	0.14	3.40	-0.05	8.24	871		
21.25				1380	1426	1417	73.2	73.2	0.153	401	-0.04	3.64	-0.04	8.29	863		
22.25				1375	1342	1345	59.9	61.0	-0.400	398	-0.16	3.81	-0.18	8.24	867		
23.25				1300	1345	1321	56.2	55.7	-0.114	398	-0.10	3.65	-0.17	8.31	869		
0.25				1320	1323	1325	54.7	55.5	-0.059	394	0.07	3.02	-0.17	8.18	862		
1.25				1275	1313	1303	58.3	57.1	0.145	389	-0.48	2.88	-0.18	8.28	866		
2.25				1305	1285	1282	51.4	51.7	-0.119	398	0.10	3.42	-0.18	8.43	861		
3.25				1300	1327	1324	60.6	60.9	0.274	397	-0.04	3.40	-0.10	8.28	859		
4.25				1330	1313	1313	57.7	57.8	-0.103	397	0.12	3.15	-0.18	8.26	860		
5.25				1340	1319	1320	58.1	58.9	0.007	401	0.29	3.25	-0.18	8.21	853		
6.25				1310	1338	1335	63.7	64.6	-0.036	398	-0.32	3.10	-0.19	7.87	840		
7.25				1400	1244	1268	45.9	45.9	-0.593	395	0.53	3.43	-0.18	8.26	845		

0.00 - 7.30																	
MAX		1400.	1351.	1378.	66.4	66.6	0.415	402.	1.07	4.07		-0.15	8.57	870.			
MIN		1275.	1237.	1264.	45.7	44.8	-0.623	388.	-0.80	2.57		-0.20	7.82	831.			
MEAN	7.50	1315.	1314.	1314.	57.3	57.4	-0.031	396.	-0.01	3.34		-0.18	8.21	857.			
ACCM	127.8	1311.		1314.			-0.031	396.	-0.01			-0.18	61.59	857.			
0.00 - 0.00																	
MAX		1440.	1466.	6119.	74.6	73.8	2.363	455.	6.23	10.41		1.14	9.28	879.			
MIN		1080.	1002.	436.	8.4	10.1	-1.454	378.	-4.48	-0.06		-0.20	0.81	444.			
MEAN	22.16	1315.	1305.	1254.	51.7	51.7	0.018	403.	0.00	3.07		-0.06	8.42	840.			
ACCM	120.4	1316.		1254.			0.018	493.	0.00			-0.06	196.43	840.			

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU' PER SH. T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS	BTU	LTWT
	PROD		KM2F1		NKCAL		C-ASH				LB. COAL		KM2F1*
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z			T/H		GR/L
7.25	--	--	-67	--	--	--	20.0	3.34	9538	-3.0	--	--	1375
8.25	66.9	40.7	977	7.34	979	1003	20.0	3.34	9538	44.2	0	34.86	1080
9.25	93.1	56.6	1359	8.80	844	865	20.0	3.34	9538	61.4	0	30.21	1180
10.25	97.2	59.1	1419	9.09	835	856	20.0	3.34	9538	64.1	0	29.76	1180
11.25	99.0	60.1	1444	9.04	815	835	20.0	3.34	9538	65.3	0	29.06	1195
12.25	99.6	60.6	1454	9.02	808	828	20.0	3.34	9538	65.7	0	28.75	1210
13.25	100.0	60.8	1460	8.74	780	807	20.0	4.07	9455	66.0	0	27.72	1330
14.25	99.9	60.7	1458	8.18	731	756	20.0	4.07	9455	65.9	0	25.97	1410
15.25	99.6	60.5	1453	8.60	771	797	20.0	4.07	9455	65.7	0	27.42	1395
16.25	99.2	60.3	1448	8.58	772	798	20.0	4.07	9455	65.5	0	27.20	1395
17.25	100.2	60.9	1462	8.48	755	781	20.0	4.07	9455	66.1	0	26.73	1400
18.25	99.5	60.5	1452	8.43	756	782	20.0	4.07	9455	65.7	0	26.61	1355
19.25	98.8	60.0	1442	8.28	749	774	20.0	4.07	9458	65.2	0	26.36	1400
20.25	99.2	60.3	1447	8.24	742	767	20.0	4.07	9455	65.4	0	26.24	1385
21.25	99.9	60.7	1457	8.29	741	766	20.0	4.07	9455	65.9	0	26.32	1380
22.25	100.2	60.9	1462	8.24	735	759	20.0	4.07	9458	66.1	0	26.84	1375
23.25	100.4	61.0	1465	8.31	738	763	20.0	4.07	9458	66.3	0	26.32	1380
0.25	99.3	60.4	1450	8.18	735	759	20.0	4.07	9455	65.5	0	26.81	1320
1.25	99.2	60.3	1448	8.20	738	763	20.0	4.07	9455	65.5	0	26.21	1275
2.25	99.3	60.3	1449	8.43	758	784	20.0	4.07	9458	65.5	0	26.91	1305
3.25	99.2	60.3	1448	8.28	745	770	20.0	4.07	9455	65.5	0	26.29	1300
4.25	99.9	60.7	1459	8.26	738	762	20.0	4.07	9458	65.9	0	26.88	1330
5.25	99.5	60.5	1452	8.21	737	761	20.0	4.07	9458	65.6	0	26.05	1348
6.25	99.9	60.7	1458	7.87	703	727	20.0	4.07	9458	65.9	0	24.99	1310
7.25	100.9	61.3	1473	8.26	731	755	20.0	4.07	9458	66.6	0	25.92	1400

0.00 - 7.30	
MAX	101.1 61.5 1475. 8.57 776. 882. 20.0 4.07 9458. 66.7 0. 27.44 1400.
MIN	98.0 59.6 1431. 7.82 698. 722. 20.0 4.07 9455. 64.7 0. 24.70 1275.
MEAN	99.6 60.5 1453. 8.21 737. 761. 20.0 4.07 9457. 65.7 0. 26.06 1316. 7.51
ACCM	747.9 454.7 61.68 737. 761. 20.0 4.07 0. 26.06 1311. 127.8
0.00 - 0.00	
MAX	101.3 61.5 1477. 9.28 10082. 10331. 20.0 4.07 9542. 66.8 4. 359.71 1440.
MIN	-4.5 -2.9 -83. 0.01-30171. -30914. 20.0 3.34 9455. -3.7 -11. -1076.4 1080.
MEAN	95.0 57.9 1283. 8.42 791. 814. 20.0 3.68 9500. 58.0 0. 28.09 1315. 22.16
ACCM	2115.4 1283.4 186.43 789. 814. 20.0 3.68 0. 28.08 1316. 120.4

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HD10F1	KN2F1	BF	KF-MS		KF-LOI	KLO	CL-LS		KN2F1*				
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS							
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
8.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
9.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
10.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000
11.25	99.9	60.7	8.46	756	0.0	0.000	0.000	0.0	0.0	0	231	0.00	0.000	0.000
12.25	99.5	60.5	8.47	760	0.0	0.000	0.000	0.0	0.0	1385	239	0.00	0.000	0.000
13.25	99.3	60.4	8.28	744	0.0	0.000	0.000	0.0	0.0	1380	265	0.00	0.000	0.000
14.25	94.5	57.4	8.24	779	115.8	0.920	2.940	58.3	35.0	1435	340	0.96	0.000	2.980
15.25	97.5	59.2	8.24	755	115.8	0.920	2.940	58.3	35.0	1345	275	0.96	0.000	2.980
16.25	99.7	60.6	8.15	730	112.8	0.890	2.940	50.8	35.0	1440	272	0.96	0.000	2.980
17.25	99.6	60.5	8.23	737	112.8	0.890	2.940	50.8	35.0	1380	230	0.96	0.000	2.980
18.25	99.4	60.4	8.26	742	112.8	0.890	2.940	50.8	35.0	1220	173	0.96	0.000	2.980
19.25	99.7	60.6	8.40	752	112.8	0.890	2.940	50.8	35.0	1140	177	0.96	0.000	2.980
20.25	100.5	61.1	8.53	757	112.8	0.890	2.940	50.8	35.0	1080	183	0.96	0.000	2.980
21.25	99.0	60.1	8.46	763	112.8	0.890	2.940	50.8	35.0	1140	215	0.96	0.000	2.980
22.25	100.5	61.1	8.56	761	112.8	0.890	2.940	50.8	35.0	1140	223	0.96	0.000	2.980
23.25	100.0	60.8	8.57	765	112.8	0.890	2.940	50.8	35.0	1265	237	0.96	0.000	2.980
0.25	99.7	60.6	8.62	771	112.1	0.890	2.850	50.8	35.0	1195	270	0.96	0.000	2.980
1.25	100.4	61.0	8.80	782	112.1	0.890	2.850	50.8	35.0	1175	245	0.96	0.000	2.980
2.25	100.0	60.8	8.81	787	112.1	0.890	2.850	50.8	35.0	1250	246	0.96	0.000	2.980
3.25	100.0	60.8	8.68	774	112.1	0.890	2.850	50.8	35.0	1305	238	0.96	0.000	2.980
4.25	99.6	60.6	8.49	761	112.1	0.890	2.850	50.8	35.0	1305	257	0.96	0.000	2.980
5.25	100.4	61.0	8.41	748	112.1	0.890	2.850	50.8	35.0	1305	264	0.96	0.000	2.980
6.25	100.4	61.0	8.43	750	112.1	0.890	2.850	50.8	35.0	1295	266	0.96	0.000	2.980
7.25	100.3	61.0	8.29	738	112.1	0.890	2.850	50.8	35.0	1360	236	0.96	0.000	2.980

0.00 - 7.27

MAX	101.3	61.6	8.95	810.	112.1	0.890	2.850	50.9	35.1	1360.	298.	0.96	0.000	2.980		
MIN	96.1	58.5	8.16	726.	112.1	0.890	2.850	50.9	35.1	1175.	228.	0.96	0.000	2.980		
MEAN	99.8	60.7	8.59	768.	112.1	0.890	2.850	50.9	35.1	1264.	250.	0.96	0.000	2.980	0.59	7.46
ACCM	744.4	452.6	64.03	768.	112.1	0.890	2.850	50.9	35.1	1261.	250.	0.96	0.000	2.980	1.30	20.36

0.00 - 0.00

MAX	101.6	61.7	8.66	809.	115.8	0.920	2.940	58.4	35.1	1440.	354.	0.96	0.000	2.980		
MIN	41.1	28.5	3.44	720.	0.0	0.000	0.000	0.0	0.0	0.	105.	0.00	0.000	0.000		
MEAN	99.2	60.3	8.38	755.	88.2	0.697	2.287	40.5	27.3	1226.	233.	0.75	0.000	2.316	0.71	12.89
ACCM	1279.4	777.9	108.14	755.	95.9	0.758	2.481	44.2	29.7	1269.	233.	0.81	0.000	2.522	0.71	12.89

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53

W1/ GAS TEMP A53

W1/ PRESSURE A54

W1/ TEMP CYCL A54

W1/ Z02 KILN OUTL

W1/ PRES EXIT KILN

W1/ KILN TORQUE

W1/ KILN ROT SPEED

W1/ GAS TEMP A52

W1/ GAS TEMP A51

W1/ GAS TEMP A61

W1/ T EXIT PREHEAT

W1/ PRESS EX PREH

W1/ ZCO EX PREHEAT

J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A58P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
8.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
9.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
10.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0	0.00	0	
11.25	1.9	32.9	96	2.85	809	207	785	328	623	399	389	401	605	-0.01	856	
12.25	1.9	33.5	117	1.79	807	220	791	331	623	385	377	389	597	-0.02	853	
13.25	1.9	32.8	127	2.95	805	213	787	350	623	386	379	391	616	0.00	865	
14.25	1.8	36.1	125	3.23	807	216	792	343	632	392	383	397	598	0.00	855	
15.25	1.8	28.7	120	3.53	806	221	792	347	631	391	384	397	614	0.00	857	
16.25	1.9	21.0	121	2.86	804	200	783	342	622	391	379	394	615	0.00	866	
17.25	1.9	18.6	117	3.42	803	204	787	343	620	394	383	397	613	0.00	860	
18.25	1.9	21.6	120	3.67	803	218	790	345	627	393	382	397	616	0.00	867	
19.25	1.9	24.1	116	3.16	804	197	789	339	631	396	385	400	612	0.01	865	
20.25	1.9	28.6	97	3.70	805	187	786	321	631	400	382	405	607	0.00	864	
21.25	1.9	31.1	113	2.91	806	193	794	340	629	394	384	399	615	0.00	862	
22.25	1.9	32.7	105	3.29	807	206	793	332	632	393	385	398	607	-0.01	862	
23.25	1.9	34.7	120	2.92	807	205	790	334	628	389	381	395	601	-0.01	866	
0.25	1.9	31.8	133	3.30	806	219	791	342	628	394	387	403	613	-0.02	859	
1.25	1.9	31.6	114	2.64	807	204	789	331	632	399	388	403	616	-0.01	863	
2.25	1.9	32.8	97	3.11	812	199	789	315	635	400	394	405	609	-0.03	862	
3.25	1.9	32.5	101	3.55	809	199	788	314	637	401	390	404	605	-0.02	860	
4.25	1.9	32.2	118	2.97	807	197	783	333	631	393	386	398	616	-0.03	864	
5.25	1.9	32.3	126	3.04	807	209	787	339	634	398	391	404	619	-0.03	860	
6.25	1.9	28.8	122	3.21	807	204	789	318	635	395	388	403	585	-0.03	859	
7.25	1.9	26.7	128	3.72	806	210	791	316	625	399	390	402	615	-0.04	861	

0.00 - 7.28

MAX	2.0	35.9	150.	4.12	814.	249.	799.	364.	646.	404.	401.	400.	630.	0.00	870.
MIN	2.0	26.5	86.	2.17	803.	149.	779.	294.	619.	389.	379.	395.	572.	-0.08	851.
MEAN	2.0	31.5	117.	3.19	808.	204.	790.	331.	632.	397.	389.	402.	609.	-0.03	862.
ACCH	2.0	31.5	117.		808.	204.	790.	331.	632.	397.	389.	402.	609.	-0.03	862.

0.00 - 0.00

MAX	2.0	43.2	142.	4.03	811.	246.	799.	363.	641.	402.	396.	407.	632.	0.03	873.
MIN	1.8	13.5	79.	1.26	783.	161.	760.	253.	611.	380.	371.	369.	460.	-0.13	833.
MEAN	2.0	29.2	116.	3.07	806.	209.	789.	335.	628.	392.	383.	397.	608.	-0.01	863.
ACCH	2.0	29.2	116.		806.	209.	789.	335.	628.	392.	383.	397.	608.	-0.01	863.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME W1/ NOX CHANGE LT
 W1/ NOX REG STIME W1/ T EXIT PREHEAT
 W1/ LTW FOR CONTRL W1/ AS0T1 CHANGE
 W1/ ESTIMATED LTW W1/ X02 KILN OUTL
 U1/ LITER WEIGHT
 KILN CON. MEASUR. W1/ XCD EX PREHEAT
 KILN CONTROL W1/ COAL TO KILN
 COAL TO KILN J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		AS0ALT		KM2F1		
	KCONTRL	LTWT	LTWT	LTWT	LTWT	LTWT	NOXL	NOXL	AS0T1	AS0T1	OA15X1	OA1X2CO	OA2V1		
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	T/H	RPM	
7.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
8.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
9.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
10.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0
11.25				0	0	0	0.0	0.0	0.000	401	58.34	2.85	-0.01	8.46	856
12.25				1385	1783	1645	58.7	59.2	0.406	389	-0.24	1.79	-0.02	8.47	853
13.25				1380	1751	1668	63.9	65.1	0.157	391	0.09	2.95	0.00	8.28	865
14.25				1435	1367	1525	48.9	45.1	0.050	397	-0.27	3.23	0.00	8.24	855
15.25				1345	1384	1533	56.2	55.9	0.181	397	0.10	3.53	0.00	8.24	857
16.25				1440	1428	1488	52.5	54.7	-0.273	394	0.16	2.86	0.00	8.15	866
17.25				1380	1381	1381	38.1	38.0	-0.493	397	0.06	3.42	0.00	8.23	860
18.25				1220	1338	1308	27.1	27.1	-0.287	397	-0.07	3.67	0.00	8.26	867
19.25				1140	1300	1266	21.1	21.7	-0.242	400	0.14	3.16	0.01	8.40	865
20.25				1080	1278	1280	28.8	28.2	0.044	405	0.25	3.70	0.00	8.53	864
21.25				1140	1276	1242	36.1	36.8	0.318	399	-0.22	2.91	0.00	8.46	862
22.25				1140	1290	1256	40.8	39.9	0.122	398	-0.14	3.29	-0.01	8.56	862
23.25				1265	1287	1255	41.1	39.2	-0.036	395	-0.46	2.92	-0.01	8.57	866
0.25				1195	1199	1197	34.4	33.2	-0.280	403	0.10	3.30	-0.02	8.62	859
1.25				1175	1247	1222	39.4	38.5	0.165	403	0.00	2.64	-0.01	8.80	863
2.25				1250	1338	1337	48.1	47.4	0.108	405	0.02	3.11	-0.03	8.91	862
3.25				1305	1385	1374	52.6	54.8	-0.026	404	0.15	3.55	-0.02	8.68	860
4.25				1305	1441	1325	62.4	60.9	0.382	398	-0.09	2.97	-0.03	8.49	864
5.25				1305	1388	1377	55.5	55.1	-0.086	404	-0.02	3.04	-0.03	8.41	860
6.25				1295	1336	1334	54.3	53.7	0.056	403	-0.25	3.21	-0.03	8.43	859
7.25				1360	1311	1313	50.6	50.3	-0.118	402	0.30	3.72	-0.04	8.29	861

0.00 - 7.30															
MAX				1360.	1446.	1444.	62.4	61.1	0.537	400.	0.02	4.12	0.00	8.95	870.
MIN				1175.	1197.	1196.	33.5	33.0	-0.386	395.	-0.59	2.17	-0.08	8.16	848.
MEAN	7.50	0.64		1265.	1338.	1315.	49.5	49.5	0.059	402.	0.02	3.20	-0.03	8.58	862.
ACCM	20.40	1.35		1261.		1315.			0.059	402.	0.02		-0.03	64.39	862.
0.00 - 0.00															
MAX				1440.	1766.	1720.	65.4	67.0	3.862	407.	58.35	4.03	0.03	8.66	873.
MIN				0.	0.	0.	0.0	0.0	-1.403	369.	-1.03	1.26	-0.13	3.44	833.
MEAN	12.89	0.71		1226.	1376.	1372.	41.9	42.0	0.097	397.	0.43	3.07	-0.01	8.38	863.
ACCM	12.89	0.71		1269.		1372.			0.097	397.	0.43		-0.01	108.14	863.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH. T
HEAT CONSUMPTION	MBTU' PER SH. T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR	KCAL		C-MOIST		C-HEAT	STONS	BTU		LTWT	
	PROD		T	KM2F1		C-ASH		%	%	LB. COAL	%	KM2F1*	
	T/H	T/H		KC/KG	KC/KG	Z	Z						T/H
7.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
8.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
9.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
10.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
11.25	99.9	60.7	1458	8.46	756	591	0.0	0.00	12486	65.9	0	35.43	0
12.25	99.5	60.5	1452	8.47	760	595	0.0	0.00	12486	65.6	0	35.58	1305
13.25	99.3	60.4	1449	8.28	744	583	0.0	0.00	12486	65.5	0	34.93	1380
14.25	94.5	57.4	1378	8.24	779	794	20.0	2.93	9588	62.3	0	28.16	1435
15.25	97.5	59.2	1422	8.24	755	770	20.0	2.93	9588	64.3	0	27.00	1345
16.25	99.7	60.6	1455	8.15	730	744	20.0	2.93	9588	65.8	0	26.12	1440
17.25	99.6	60.5	1453	8.23	737	752	20.0	2.93	9588	65.7	0	26.27	1390
18.25	99.4	60.4	1451	8.26	742	756	20.0	2.93	9588	65.6	0	26.61	1220
19.25	99.7	60.6	1455	8.40	752	767	20.0	2.93	9588	65.8	0	26.95	1140
20.25	100.5	61.1	1467	8.53	757	772	20.0	2.93	9588	66.3	0	27.20	1080
21.25	99.0	60.1	1444	8.46	763	778	20.0	2.93	9588	65.3	0	27.41	1140
22.25	100.5	61.1	1466	8.56	761	775	20.0	2.93	9588	66.3	0	27.33	1140
23.25	100.0	60.8	1460	8.57	765	780	20.0	2.93	9588	66.0	0	27.50	1265
0.25	99.7	60.6	1456	8.62	771	786	20.0	2.93	9588	65.8	0	27.76	1195
1.25	100.4	61.0	1466	8.80	782	797	20.0	2.93	9588	66.3	0	28.04	1175
2.25	100.0	60.8	1459	8.81	787	802	20.0	2.93	9588	66.0	0	28.39	1250
3.25	100.0	60.8	1460	8.68	774	789	20.0	2.93	9588	66.0	0	27.90	1305
4.25	99.6	60.6	1454	8.49	761	776	20.0	2.93	9588	65.7	0	27.31	1305
5.25	100.4	61.0	1466	8.41	748	762	20.0	2.93	9588	66.3	0	26.85	1305
6.25	100.4	61.0	1465	8.43	750	764	20.0	2.93	9588	66.2	0	26.85	1295
7.25	100.3	61.0	1464	8.29	738	753	20.0	2.93	9588	66.2	0	26.67	1360

0.00 - 7.30													
MAX	101.3	61.6	1479.	8.95	810.	826.	20.0	2.93	9589.	66.9	0.	29.05	1360.
MIN	96.1	58.5	1404.	8.16	726.	740.	20.0	2.93	9586.	63.5	0.	26.04	1175.
MEAN	99.8	60.7	1456.	8.58	768.	783.	20.0	2.93	9589.	65.9	0.	27.55	1265. 7.51
ACCM	749.7	455.8		64.47	768.	783.	20.0	2.93			0.	27.55	1261. 20.42
0.00 - 0.00													
MAX	101.6	61.7	1482.	8.66	809.*****		20.0	2.93	12490.	67.0	0.	37.71	1440.
MIN	41.1	28.5	684.	3.44	720.	572.	0.0	0.00	9586.	31.0	0.	0.00	0.
MEAN	99.2	60.3	1447.	8.38	755.*****		15.5	2.27	10239.	65.5	0.	28.93	1226. 12.89
ACCM	1279.4	777.9		108.14	755.	721.	15.5	2.27			0.	28.91	1269. 12.89

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-D-IG
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HO10F1	KM2F1	BF	KF-LS	KF-MS	KF-LOI	KLO	FCAO	CL-LS	CL-MS	KCONTRL			
	PROD	KCAL									CL-MS	KM2F1*		
	T/H	T/H	KC/KG	Z	Z	GR/L	DEG.C	Z	H	H				
7.25	100.0	60.8	8.23	735	112.1	0.890	2.850	50.8	35.0	1295	239	0.96	0.000	2.980
8.25	100.2	60.9	8.45	753	121.8	0.990	2.770	75.7	35.0	1340	217	0.96	0.000	2.980
9.25	100.1	60.8	8.56	763	121.8	0.990	2.770	75.7	35.0	1170	225	0.96	0.000	2.980
10.25	99.4	60.4	8.68	779	121.8	0.990	2.770	75.7	35.0	1170	214	0.96	0.000	2.980
11.25	99.9	60.7	8.52	762	121.8	0.990	2.770	75.7	35.0	1170	221	0.96	0.000	2.980
12.25	99.9	60.7	8.39	749	121.8	0.990	2.770	75.7	35.0	1325	241	0.96	0.000	2.980
13.25	99.5	60.5	8.46	760	110.4	0.870	2.950	45.5	34.7	1285	259	0.24	0.930	3.020
14.25	99.6	60.5	8.42	755	110.4	0.870	2.950	45.5	34.7	1190	265	0.24	0.930	3.020
15.25	99.9	60.7	7.97	713	110.4	0.870	2.950	45.5	34.7	1355	250	0.24	0.930	3.020
16.25	98.7	60.0	8.24	745	110.4	0.870	2.950	45.5	34.7	1310	253	0.24	0.930	3.020
17.25	99.6	60.5	8.30	744	115.3	0.920	2.880	58.9	34.7	1385	266	0.24	0.930	3.020
18.25	98.7	60.0	8.16	738	115.3	0.920	2.880	58.9	34.7	1430	298	0.24	0.930	3.020
19.25	100.5	61.1	7.88	700	115.3	0.920	2.880	58.9	34.7	1510	286	0.24	0.930	3.020
20.25	99.4	60.4	7.24	650	115.3	0.920	2.880	58.9	34.7	1510	254	0.24	0.930	3.020
21.25	100.1	60.9	8.11	724	115.3	0.920	2.880	58.9	34.7	1475	232	0.24	0.930	3.020
22.25	100.5	61.1	8.12	721	115.3	0.920	2.880	58.9	34.7	1175	183	0.24	0.930	3.020
23.25	100.1	60.8	8.10	723	115.3	0.920	2.880	58.9	34.7	1215	176	0.24	0.930	3.020
0.25	99.4	60.4	8.03	721	126.0	1.020	2.870	83.6	34.7	1175	221	0.24	0.930	3.020
1.25	99.5	60.5	8.10	726	126.0	1.020	2.870	83.6	34.7	1125	241	0.24	0.930	3.020
2.25	99.9	60.7	8.23	735	126.0	1.020	2.870	83.6	34.7	1065	202	0.24	0.930	3.020
3.25	99.8	60.6	8.41	753	126.0	1.020	2.870	83.6	34.7	1160	200	0.24	0.930	3.020
4.25	98.8	60.0	8.76	792	126.0	1.020	2.870	83.6	34.7	1195	241	0.24	0.930	3.020
5.25	100.0	60.8	8.53	762	126.0	1.020	2.870	83.6	34.7	1280	250	0.24	0.930	3.020
6.25	99.1	60.2	8.14	733	126.0	1.020	2.870	83.6	34.7	1460	248	0.24	0.930	3.020
7.25	101.4	61.6	8.82	777	126.0	1.020	2.870	83.6	34.7	1450	250	0.24	0.930	3.020

0.00 - 7.27

MAX	102.0	62.0	9.02	813.	126.0	1.020	2.870	83.6	34.7	1460.	280.	0.24	0.930	3.020		
MIN	97.9	59.5	7.81	697.	126.0	1.020	2.870	83.6	34.7	1065.	144.	0.24	0.930	3.020		
MEAN	99.8	60.7	8.35	747.	126.0	1.020	2.870	83.6	34.7	1227.	227.	0.24	0.930	3.020	5.04	7.46
ACCM	744.7	452.8	62.28	747.	126.0	1.020	2.870	83.6	34.7	1253.	227.	0.24	0.930	3.020	16.30	44.42

0.00 - 0.00

MAX	105.4	64.1	8.98	810.	126.0	1.020	2.950	83.6	35.1	1510.	320.	0.96	0.930	3.020		
MIN	96.1	58.5	7.15	611.	110.4	0.870	2.770	45.5	34.7	1170.	172.	0.24	0.000	2.980		
MEAN	99.8	60.7	8.34	746.	115.1	0.920	2.856	58.4	34.9	1295.	245.	0.64	0.413	2.999	10.56	24.02
ACCM	2395.9	1456.7	200.13	746.	115.8	0.927	2.852	60.1	34.9	1280.	245.	0.63	0.426	2.998	11.26	36.94

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ ZD2 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN
W1/ KILN TORQUE	W1/ ZCD EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	27.7	109	3.58	805	208	785	308	628	394	391	401	583	-0.03	859	
8.25	1.9	25.0	117	2.93	805	209	789	341	623	388	382	396	611	-0.02	856	
9.25	1.9	24.7	114	2.39	807	233	788	352	628	393	384	397	618	-0.01	869	
10.25	1.9	27.2	117	2.24	806	206	785	342	625	391	381	395	610	-0.02	873	
11.25	1.9	29.3	117	2.31	805	202	790	335	631	391	391	396	600	-0.02	877	
12.25	1.9	30.2	116	3.01	805	211	789	344	632	395	386	399	613	-0.01	879	
13.25	1.9	33.7	123	2.90	805	222	790	344	635	396	385	398	618	-0.01	869	
14.25	1.9	30.6	123	2.76	809	228	793	357	635	397	387	401	625	0.00	874	
15.25	1.9	30.2	110	3.94	804	199	785	313	629	394	384	399	600	-0.02	857	
16.25	1.9	31.1	111	3.69	802	198	783	335	626	393	383	398	617	-0.01	869	
17.25	1.9	33.3	111	3.00	804	200	782	337	625	391	379	395	619	0.00	872	
18.25	1.9	28.4	119	2.74	802	205	785	333	619	388	379	396	591	-0.02	878	
19.25	1.9	22.5	116	4.59	800	216	785	357	622	393	381	397	631	-0.01	884	
20.25	1.9	17.8	110	4.49	796	192	776	328	618	382	374	389	585	-0.02	847	
21.25	1.9	16.6	132	3.09	800	206	777	336	611	382	372	386	593	-0.04	844	
22.25	1.9	21.5	120	3.00	800	214	782	331	621	384	374	390	607	-0.02	852	
23.25	1.9	24.0	128	2.41	803	221	781	339	617	385	375	392	618	-0.04	855	
0.25	1.9	24.1	134	2.92	801	217	778	345	624	387	379	394	615	-0.03	856	
1.25	1.9	23.9	121	3.10	801	195	780	340	619	388	379	394	627	-0.04	857	
2.25	1.9	24.9	125	2.82	802	206	784	335	618	388	379	392	626	-0.07	856	
3.25	1.9	28.4	140	2.32	804	228	782	341	622	387	378	391	614	-0.06	855	
4.25	1.9	30.6	145	1.21	806	241	785	346	624	389	380	393	616	-0.03	853	
5.25	1.9	31.6	148	1.40	808	229	784	359	624	392	383	397	631	-0.02	863	
6.25	1.9	29.3	135	2.91	802	226	785	359	624	392	380	396	631	-0.05	868	
7.25	1.9	29.6	123	3.43	802	206	784	359	624	392	384	398	637	-0.18	868	

0.00 - 7.28															
MAX	2.0	32.1	164.	4.19	814.	264.	797.	376.	634.	395.	390.	401.	645.	0.01	875.
MIN	2.0	23.4	104.	0.29	798.	162.	774.	322.	613.	382.	372.	378.	599.	-0.20	847.
MEAN	2.0	27.8	132.	2.34	804.	216.	784.	342.	622.	389.	380.	395.	621.	-0.06	860.
ACCM	2.0	27.8	132.		804.	216.	784.	342.	622.	389.	380.	395.	621.	-0.06	860.
0.00 - 0.00															
MAX	2.0	35.9	151.	5.96	814.	259.	799.	377.	646.	404.	401.	408.	653.	0.01	889.
MIN	1.9	14.4	86.	1.61	795.	149.	765.	210.	602.	373.	364.	382.	563.	-0.18	825.
MEAN	2.0	28.1	119.	3.15	805.	209.	787.	335.	627.	393.	383.	398.	612.	-0.03	865.
ACCM	2.0	28.1	119.		805.	209.	787.	335.	627.	393.	383.	398.	612.	-0.03	865.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ ZCO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		LTWT		LTWGTSP		NOXLT		A50T1		OA15X1		OA1X2CO OA2V1		
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM	
7.25				1295	1323	1322	50.9	52.0	-0.186	401	0.16	3.58	-0.03	8.23	859
8.25				1340	1241	1243	37.1	41.0	-0.466	396	-0.16	2.93	-0.02	8.45	856
9.25				1170	1133	1204	26.6	26.6	-0.263	397	0.24	2.39	-0.01	8.56	869
10.25				1170	1169	1169	31.4	31.1	-0.150	395	-0.18	2.24	-0.02	8.68	873
11.25				1170	1311	1305	47.9	48.7	0.555	396	-0.10	2.31	-0.02	8.52	877
12.25				1325	1256	1290	43.3	41.9	-0.582	399	0.21	3.01	-0.01	8.38	879
13.25				1285	1220	1223	37.6	36.8	-0.412	398	0.32	2.90	-0.01	8.46	869
14.25				1190	1310	1320	47.5	48.3	0.347	401	0.15	2.76	0.00	8.42	874
15.25				1355	1274	1280	41.6	42.5	-0.395	399	0.01	3.94	-0.02	7.97	857
16.25				1310	1252	1257	38.0	38.2	-0.158	398	0.04	3.69	-0.01	8.24	869
17.25				1305	1308	1319	44.1	44.3	0.323	395	0.01	3.00	0.00	8.30	872
18.25				1430	1373	1429	49.4	49.4	0.339	396	-0.07	2.74	-0.02	8.16	878
19.25				1510	1443	1385	50.4	52.2	-0.182	397	0.56	4.59	-0.01	7.88	884
20.25				1510	1312	1329	40.8	39.7	0.014	389	-1.38	4.49	-0.02	7.24	847
21.25				1475	1206	1310	25.9	21.6	-0.227	386	-0.09	3.09	-0.04	8.11	844
22.25				1175	1307	1384	33.6	33.6	0.124	390	0.30	3.00	-0.02	8.12	852
23.25				1215	1295	1363	34.8	34.6	0.064	392	0.09	2.41	-0.04	8.10	855
0.25				1175	1170	1319	29.2	29.1	-0.135	394	0.16	2.92	-0.03	8.03	856
1.25				1125	993	1260	19.5	18.3	-0.432	394	-0.27	3.10	-0.04	8.10	857
2.25				1065	1180	1155	27.3	28.0	0.406	392	0.01	2.82	-0.07	8.23	856
3.25				1160	1225	1220	30.9	31.2	0.074	391	0.06	2.32	-0.06	8.41	855
4.25				1195	1230	1244	31.5	31.5	0.003	393	-0.10	1.21	-0.03	8.76	853
5.25				1280	1230	1246	31.5	31.5	0.000	397	0.20	1.40	-0.02	8.53	863
6.25				1460	1404	1284	54.9	42.6	0.045	396	0.23	2.91	-0.05	8.14	868
7.25				1450	1421	1344	47.6	49.7	-0.546	398	0.07	3.43	-0.18	8.82	868

0.00 - 7.30															
MAX				1460.	1774.	1627.	66.5	66.2	1.984	401.	0.45	4.19	0.01	9.02	875.
MIN				1065.	993.	1139.	18.8	18.3	-0.679	378.	-0.60	0.29	-0.20	7.81	847.
MEAN	7.50	5.04		1228.	1242.	1278.	32.8	32.8	0.098	395.	0.02	2.34	-0.06	8.35	860.
ACCH	44.46	16.30		1253.		1278.			0.098	395.	0.02		-0.06	62.66	860.
0.00 - 0.00															
MAX				1510.	1484.	1510.	62.4	61.1	0.802	400.	0.82	5.96	0.01	8.98	889.
MIN				1170.	1046.	1136.	19.5	17.8	-1.061	382.	-1.47	1.61	-0.18	7.15	825.
MEAN	24.02	10.56		1295.	1294.	1304.	42.9	42.9	-0.008	398.	-0.01	3.15	-0.03	8.34	865.
ACCH	36.94	11.26		1280.		1304.			-0.008	398.	-0.01		-0.03	200.13	865.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	SHORT TONS CLINKER
NET HEAT CONSUMP.	LB COAL / SH.T
HEAT CONSUMPTION	MBTU' PER SH.T
W1/ COAL TO KILN	
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HD10F1		PRODR	KCAL		C-MOIST		C-HEAT		STONS	BTU		LTWT
	PROD		KN2F1	NKCAL		C-ASH				LB. COAL			KN2F1*
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z		T/H			GR/L
7.25	100.0	60.8	1459	8.23	735	749	20.0	2.93	9588	66.0	0	26.30	1295
8.25	100.2	60.9	1462	8.45	753	768	20.0	2.93	9585	66.1	0	27.86	1340
9.25	100.1	60.8	1460	8.56	763	778	20.0	2.93	9585	66.0	0	27.25	1170
10.25	99.4	60.4	1451	8.68	779	795	20.0	2.93	9585	65.6	0	27.91	1170
11.25	99.9	60.7	1457	8.52	762	776	20.0	2.93	9585	65.9	0	27.44	1170
12.25	99.9	60.7	1458	8.38	749	763	20.0	2.93	9585	65.9	0	26.75	1325
13.25	99.5	60.5	1452	8.46	760	775	20.5	3.81	9588	65.6	0	27.05	1285
14.25	99.6	60.5	1453	8.42	755	783	20.5	3.81	9423	65.7	0	26.76	1190
15.25	99.9	60.7	1458	7.97	713	739	20.5	3.81	9423	65.9	0	25.18	1355
16.25	98.7	60.0	1441	8.24	745	773	20.5	3.81	9423	65.1	0	26.28	1310
17.25	99.6	60.5	1454	8.30	744	772	20.5	3.81	9423	65.7	0	26.07	1305
18.25	98.7	60.0	1441	8.16	738	766	20.5	3.81	9423	65.1	0	25.74	1430
19.25	100.5	61.1	1467	7.88	700	726	20.5	3.81	9423	66.3	0	24.66	1510
20.25	99.4	60.4	1451	7.24	650	674	20.5	3.81	9423	65.6	0	23.02	1510
21.25	100.1	60.9	1461	8.11	724	751	20.5	3.81	9423	66.1	0	25.44	1475
22.25	100.5	61.1	1466	8.12	721	749	20.5	3.81	9423	66.3	0	25.52	1175
23.25	100.1	60.8	1461	8.10	723	750	20.5	3.81	9423	66.0	0	25.59	1215
0.25	99.4	60.4	1450	8.03	721	748	20.5	3.81	9423	65.6	0	25.46	1175
1.25	99.5	60.5	1452	8.10	726	753	20.5	3.81	9423	65.6	0	25.68	1125
2.25	99.9	60.7	1458	8.23	735	763	20.5	3.81	9420	65.9	0	25.79	1865
3.25	99.8	60.6	1456	8.41	753	781	20.5	3.81	9423	65.8	0	26.53	1160
4.25	98.8	60.0	1441	8.76	792	821	20.5	3.81	9423	65.2	0	27.75	1195
5.25	100.0	60.8	1459	8.53	762	790	20.5	3.81	9423	66.0	0	26.81	1280
6.25	99.1	60.2	1446	8.14	733	761	20.5	3.81	9423	65.4	0	25.94	1460
7.25	101.4	61.6	1479	8.82	777	806	20.5	3.81	9420	66.9	0	27.28	1450

0.00 - 7.30	
MAX	102.0 62.0 1488. 9.02 813. 843. 20.5 3.81 9424. 67.3 0. 28.66 1460.
MIN	97.9 59.5 1428. 7.81 697. 723. 20.5 3.81 9421. 64.6 0. 24.58 1065.
MEAN	99.9 60.7 1457. 8.35 747. 775. 20.5 3.81 9423. 65.9 0. 26.34 1229. 7.52
ACCH	750.1 456.1 62.75 747. 775. 20.5 3.81 0. 26.34 1253. 44.48
0.00 - 0.00	
MAX	105.4 64.1 1537. 8.98 810. 826. 20.5 3.81 9589. 69.5 0. 29.05 1510.
MIN	96.1 58.5 1404. 7.15 611. 634. 20.0 2.93 9421. 63.5 0. 21.53 1170.
MEAN	99.8 60.7 1457. 8.34 746. 766. 20.2 3.32 9512. 65.9 0. 26.56 1295. 24.02
ACCH	2395.9 1456.7 200.13 746. 767. 20.2 3.32 0. 26.55 1280. 36.94

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-0-IG
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HD10F1	KM2F1	BF	KF-MS		KF-LOI	KLO	CL-LS		KCONTRL	KM2F1*			
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	H H						
	T/H	T/H	T/H	KC/KG	Z	Z	GR/L	DEG.C	Z	H	H			
7.25	100.5	61.1	8.14	723	126.0	1.020	2.870	83.6	34.7	1460	220	0.24	0.930	3.020
8.25	101.7	61.8	9.05	795	119.3	0.950	2.880	67.5	34.7	1260	271	0.24	0.930	3.020
9.25	101.1	61.4	9.24	816	119.3	0.950	2.880	67.5	34.7	1255	251	0.24	0.930	3.020
10.25	47.0	28.5	4.08	775	119.3	0.950	2.880	67.5	34.7	1255	227	0.24	0.930	3.020
11.25	45.2	27.4	2.16	427	119.3	0.950	2.880	67.5	34.7	1255	169	0.24	0.930	3.020
12.25	--	--	--	--	119.3	0.950	2.880	67.5	34.7	1255	--	0.24	0.930	3.020
13.25	--	-2.7	0.01	-28	119.3	0.950	2.880	67.5	34.7	1255	48	0.24	0.930	3.020
14.25	--	--	--	--	118.7	0.960	2.900	67.7	35.2	1255	--	0.59	0.940	3.040
15.25	--	-2.8	0.03	-60	118.7	0.960	2.900	67.7	35.2	1255	48	0.59	0.940	3.040
16.25	--	-2.9	0.04	-81	118.7	0.960	2.900	67.7	35.2	1255	71	0.59	0.940	3.040
17.25	--	-2.8	0.03	-66	118.7	0.960	2.900	67.7	35.2	1255	27	0.59	0.940	3.040
18.25	--	-2.8	0.06	-122	118.7	0.960	2.900	67.7	35.2	1255	41	0.59	0.940	3.040
19.25	--	-2.8	0.01	-25	118.7	0.960	2.900	67.7	35.2	1255	30	0.59	0.940	3.040
20.25	--	-2.7	0.07	-139	118.7	0.960	2.900	67.7	35.2	1255	47	0.59	0.940	3.040
21.25	--	-2.8	0.05	-113	118.7	0.960	2.900	67.7	35.2	1255	35	0.59	0.940	3.040
22.25	--	-3.0	0.04	-77	118.7	0.960	2.900	67.7	35.2	1255	41	0.59	0.940	3.040
23.25	--	-2.6	0.02	-60	118.7	0.960	2.900	67.7	35.2	1255	27	0.59	0.940	3.040
0.25	--	-2.9	0.06	-114	118.7	0.960	2.900	67.7	35.2	1255	27	0.59	0.940	3.040
1.25	--	-2.8	0.03	-58	118.7	0.960	2.900	67.7	35.2	1255	18	0.59	0.940	3.040
2.25	--	-2.8	0.05	-96	118.7	0.960	2.900	67.7	35.2	1255	26	0.59	0.940	3.040
3.25	--	-3.1	0.05	-97	118.7	0.960	2.900	67.7	35.2	1255	23	0.59	0.940	3.040
4.25	--	-2.7	0.06	-123	118.7	0.960	2.900	67.7	35.2	1255	13	0.59	0.940	3.040
5.25	--	-3.1	0.05	-91	118.7	0.960	2.900	67.7	35.2	1255	13	0.59	0.940	3.040
6.25	--	-2.5	0.02	-43	118.7	0.960	2.900	67.7	35.2	1255	13	0.59	0.940	3.040
7.25	--	--	--	--	118.7	0.960	2.900	67.7	35.2	1255	--	0.59	0.940	3.040

0.00 - 7.37

MAX	-2.2	0.11	63.	118.7	0.960	2.900	67.7	35.2	1255.	47.	0.59	0.940	3.040	
MIN	-3.5	-0.03	-213.	118.7	0.960	2.900	67.7	35.2	1255.	1.	0.59	0.940	3.040	
MEAN	-2.9	0.04	-84.	118.7	0.960	2.900	67.7	35.2	1255.	18.	0.59	0.940	3.040	7.02 7.34
ACCM	0.0	-21.2	0.33	-84.	118.7	0.960	2.900	67.7	35.2	1255.	18.	0.59	0.940	3.040 31.97 66.42

0.00 - 0.00

MAX	103.1	62.7	9.27	15478.	126.0	1.020	2.900	83.6	35.2	1460.	284.	0.59	0.940	3.040
MIN	-4.6	-3.4	-0.03	-473235	118.7	0.950	2.870	67.6	34.7	1065.	15.	0.24	0.930	3.020
MEAN	92.2	27.6	4.01	306.	121.3	0.978	2.884	73.0	35.0	1254.	141.	0.39	0.934	3.028 13.65 22.11
ACCM	1057.9	610.3	88.53	788.	121.3	0.978	2.886	73.0	35.0	1263.	141.	0.40	0.935	3.029 24.93 59.10

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCD EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	OA15V1		OA15P1		A54T1		A53T1		A52T1		A61T1		A50P1		OA1X2CD	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.25	1.9	29.7	112	3.02	804	161	780	341	621	390	379	395	624	-0.15	867	
8.25	1.9	30.4	121	3.76	806	195	783	331	622	390	379	393	636	-0.03	883	
9.25	1.9	31.5	147	3.57	804	230	784	363	634	399	387	405	656	-0.05	874	
10.25	1.0	23.0	11	5.07	784	62	757	93	621	411	407	411	190	-0.17	551	
11.25	0.8	9.5	5	10.49	753	51	727	73	608	407	413	414	135	-0.14	595	
12.25	--	--	--	--	--	--	--	--	--	--	--	397	--	--	--	
13.25	--	--	-9	10.53	668	-6	679	-17	582	374	384	362	-21	-0.16	187	
14.25	--	--	--	--	--	--	--	--	--	--	--	339	--	--	--	
15.25	--	--	-9	10.55	611	-3	635	-17	549	341	355	322	-21	-0.18	187	
16.25	--	--	-9	10.57	585	-3	616	-22	533	329	341	311	-22	-0.17	184	
17.25	--	--	-10	10.52	560	-4	599	-13	520	320	334	302	-25	-0.18	182	
18.25	--	--	-9	10.61	537	-1	585	-19	506	306	321	291	-19	-0.17	183	
19.25	--	--	-10	10.56	516	-4	565	-19	486	278	317	285	-15	-0.17	183	
20.25	--	--	-9	10.55	494	-4	549	-18	476	267	310	277	-17	-0.17	184	
21.25	--	--	-10	10.49	475	-3	534	-18	465	259	302	268	-18	-0.18	184	
22.25	--	--	-9	10.45	457	-4	519	-16	451	252	293	261	-24	-0.18	186	
23.25	--	--	-10	10.48	441	-3	504	-14	437	242	287	250	-41	-0.17	183	
0.25	--	--	-10	10.44	423	-3	490	-18	424	230	277	242	-37	-0.18	183	
1.25	--	--	-9	10.49	410	-2	477	-13	414	226	272	233	-42	-0.18	183	
2.25	--	--	-10	10.47	397	-3	465	-19	408	220	262	226	-36	-0.18	182	
3.25	--	--	-10	10.40	386	-1	450	-14	400	216	254	219	-37	-0.17	183	
4.25	--	--	-10	10.40	371	-6	438	-15	387	210	246	211	-39	-0.18	183	
5.25	--	--	-9	10.42	361	-2	426	-11	376	202	234	198	-39	-0.18	187	
6.25	--	--	-10	10.42	351	-2	419	-14	372	197	227	191	-43	-0.18	183	
7.25	--	--	--	--	--	--	--	--	--	--	--	182	--	--	--	

0.00 - 7.38

MAX			-9.	10.58	432.	2.	501.	-1.	436.	237.	285.	249.	-29.	-0.16	191.
MIN			-12.	10.29	340.	-8.	403.	-28.	356.	188.	216.	179.	-51.	-0.20	176.
MEAN			-10.	10.44	383.	-3.	450.	-15.	394.	213.	251.	214.	-39.	-0.18	184.
ACCH	0.0	0.0	-10.		383.	-3.	450.	-15.	394.	213.	251.	214.	-39.	-0.18	184.

0.00 - 0.00

MAX	2.0	32.1	164.	10.69	814.	264.	797.	376.	673.	481.	472.	467.	684.	0.01	891.
MIN	0.4	9.5	-12.	0.29	429.	-11.	492.	-31.	426.	234.	281.	245.	-51.	-0.21	176.
MEAN	1.8	27.0	54.	6.81	673.	97.	684.	149.	564.	347.	355.	351.	276.	-0.12	510.
ACCH	1.8	27.0	54.		673.	97.	684.	149.	564.	347.	355.	351.	276.	-0.12	510.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ ZCO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KMZF1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KMZF1		
	KCONTRL		LTWT		LTWGTSP		NOXLT		A50T1		OA15X1		OA1X2CO	OA2V1	
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	Z	T/H	RPM
7.25				1460	1633	1350	58.0	57.2	-0.121	395	-0.21	3.02	-0.15	8.14	867
8.25				1260	1362	1325	44.4	43.9	-0.090	393	-0.18	3.76	-0.03	9.05	883
9.25				1255	1217	1305	32.4	31.0	-0.594	405	0.27	3.57	-0.05	9.24	874
10.25				1255	1572	1305	78.2	69.1	0.638	411	3.04	5.07	-0.17	4.00	551
11.25				1255	1109	1305	21.2	19.5	-1.540	414	3.06	10.49	-0.14	2.16	505
12.25				1255	865	1305	-6.1	-6.6	-0.732	397	-1.02	--	--	--	--
13.25				1255	770	1305	-16.6	-16.8	-0.289	362	-0.99	10.53	-0.16	0.01	187
14.25				1255	736	1305	-20.4	-20.5	-0.100	339	-0.84	--	--	--	--
15.25				1255	729	1305	-21.1	-21.2	-0.009	322	-0.66	10.55	-0.18	0.03	187
16.25				1255	735	1305	-20.6	-20.6	0.024	311	-0.06	10.57	-0.17	0.04	184
17.25				1255	745	1305	-19.6	-19.5	0.036	302	-0.21	10.52	-0.18	0.03	182
18.25				1255	756	1305	-18.3	-18.3	0.043	291	-0.47	10.61	-0.17	0.06	183
19.25				1255	770	1305	-16.8	-16.8	0.050	285	-0.38	10.56	-0.17	0.01	183
20.25				1255	784	1305	-15.3	-15.3	0.050	277	-0.24	10.55	-0.17	0.07	184
21.25				1255	798	1305	-13.8	-13.8	0.050	268	-0.26	10.49	-0.18	0.05	184
22.25				1255	812	1305	-12.3	-12.3	0.050	261	-0.12	10.45	-0.18	0.04	186
23.25				1255	826	1305	-10.8	-10.8	0.050	250	-0.09	10.48	-0.17	0.02	183
0.25				1255	840	1305	-9.3	-9.3	0.050	242	-0.60	10.44	-0.18	0.06	183
1.25				1255	854	1305	-7.8	-7.8	0.050	233	-0.46	10.49	-0.18	0.03	183
2.25				1255	868	1305	-6.3	-6.3	0.050	226	-0.26	10.47	-0.18	0.05	182
3.25				1255	883	1305	-4.7	-4.7	0.050	219	-0.23	10.40	-0.17	0.05	183
4.25				1255	897	1305	-3.2	-3.2	0.050	211	-0.16	10.40	-0.18	0.06	183
5.25				1255	911	1305	-1.7	-1.7	0.050	198	-0.44	10.42	-0.18	0.05	187
6.25				1255	925	1305	-0.2	-0.2	0.050	191	-0.23	10.42	-0.18	0.02	183
7.25				1255	929	1305	0.1	0.2	0.004	182	-0.22	--	--	--	--

0.00 - 7.40															
MAX			1255.	930.	1306.	0.2	0.2	0.050	249.	-0.02	10.58	-0.16	0.11	191.	
MIN			1255.	836.	1306.	-9.8	-9.8	0.000	178.	-0.72	10.29	-0.20	-0.03	176.	
MEAN	7.34	7.02	1255.	889.	1306.	-4.2	-4.2	0.046	214.	-0.29	10.44	-0.18	0.04	184.	
ACCM	66.42	31.97	1255.		1306.			0.046	214.	-0.29		-0.18	0.33	184.	
0.00 - 0.00															
MAX			1460.	1774.	1627.	79.4	77.5	2.041	467.	5.43	10.69	0.01	9.27	891.	
MIN			1065.	729.	1139.	-21.2	-21.3	-2.319	245.	-6.11	0.29	-0.21	-0.03	176.	
MEAN	22.11	13.65	1254.	1023.	1298.	9.8	9.8	-0.058	351.	-0.20	6.81	-0.12	4.01	510.	
ACCM	59.10	24.93	1263.		1298.			-0.058	351.	-0.20		-0.12	88.53	510.	

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL COAL HEAT VALUE
 Z MOISTURE IN COAL
 NET HEAT CONSUMP. SHORT TONS CLINKER
 HEAT CONSUMPTION LB COAL / SH. T
 W1/ COAL TO KILN MBTU' PER SH. T
 KILN PRODUC. RATE
 KILN PRODUCTION W1/ LITER WEIGHT
 W1/ KILN FEED COAL TO KILN

HOUR	H010F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		RTU		LTWT	
	PRDD		KN2F1		NKKAL		C-ASH				LB. COAL		KN2F1*			
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z			T/H		GR/L	H		
7.25	100.5	61.1	1467	8.14	723	750	20.5	3.81	9420	66.3	0	25.41	1460			
8.25	101.7	61.8	1484	9.05	795	824	20.5	3.81	9420	67.1	0	27.92	1260			
9.25	101.1	61.4	1475	9.24	816	847	20.5	3.81	9420	66.7	0	28.78	1255			
10.25	47.0	28.5	685	4.08	775	804	20.5	3.81	9420	31.0	0	27.43	1255			
11.25	45.2	27.4	659	2.16	427	443	20.5	3.81	9420	29.8	0	14.63	1255			
12.25	--	--	-69	--	--	--	20.5	3.81	9423	-3.1	--	--	1255			
13.25	--	-2.7	-67	0.01	-28	-29	20.5	3.81	9423	-3.0	0	-0.86	1255			
14.25	--	--	-67	--	--	--	21.2	4.35	9268	-3.0	--	--	1255			
15.25	--	-2.8	-69	0.03	-60	-64	21.2	4.35	9271	-3.1	0	-1.87	1255			
16.25	--	-2.9	-71	0.04	-81	-86	21.2	4.35	9271	-3.2	0	-3.21	1255			
17.25	--	-2.8	-67	0.03	-66	-70	21.2	4.35	9271	-3.0	0	-2.59	1255			
18.25	--	-2.8	-68	0.06	-122	-129	21.2	4.35	9271	-3.1	0	-3.96	1255			
19.25	--	-2.8	-67	0.01	-25	-26	21.2	4.35	9271	-3.0	0	-0.21	1255			
20.25	--	-2.7	-65	0.07	-139	-147	21.2	4.35	9271	-2.9	0	-3.39	1255			
21.25	--	-2.8	-67	0.05	-113	-119	21.2	4.35	9271	-3.0	0	-3.19	1255			
22.25	--	-3.0	-72	0.04	-77	-81	21.2	4.35	9268	-3.2	0	-3.30	1255			
23.25	--	-2.6	-63	0.02	-60	-63	21.2	4.35	9271	-2.8	0	-1.97	1255			
0.25	--	-2.9	-70	0.06	-114	-120	21.2	4.35	9271	-3.2	0	-4.20	1255			
1.25	--	-2.8	-67	0.03	-58	-61	21.2	4.35	9271	-3.0	0	-0.95	1255			
2.25	--	-2.8	-67	0.05	-96	-101	21.2	4.35	9271	-3.0	0	-3.58	1255			
3.25	--	-3.1	-74	0.05	-97	-102	21.2	4.35	9271	-3.3	0	-3.08	1255			
4.25	--	-2.7	-66	0.06	-123	-130	21.2	4.35	9271	-3.0	0	-3.66	1255			
5.25	--	-3.1	-75	0.05	-91	-96	21.2	4.35	9271	-3.3	0	-3.66	1255			
6.25	--	-2.5	-60	0.02	-43	-46	21.2	4.35	9271	-2.7	0	-2.52	1255			
7.25	--	--	-76	--	--	--	21.2	4.35	9271	-3.4	--	--	1255			

0.00 - 7.40														
MAX		-2.2	-53.	0.11	63.	66.	21.2	4.36	9271.	-2.4	0.	2.17	1255.	
MIN		-3.5	-85.	-0.03	-213.	-225.	21.2	4.36	9271.	-3.8	-0.	-7.40	1255.	
MEAN		-2.9	-69.	0.04	-84.	-89.	21.2	4.36	9272.	-3.1	-0.	-2.92	1255.	7.34
ACCM	0.0	-21.2		0.33	-84.	-89.	21.2	4.36			-0.	-2.92	1255.	66.42

0.00 - 0.00														
MAX	103.1	62.7	1585.	9.27	15478.	16058.	21.2	4.36	9424.	68.1	6.	545.38	1460.	
MIN	-4.6	-3.4	-81.	-0.03	-473235	-490970	20.5	3.81	9268.	-3.7	-177.	-16675.	1065.	
MEAN	92.2	27.6	608.	4.01	306.	317.	20.8	4.05	9358.	27.5	0.	10.78	1254.	22.11
ACCM	1057.9	610.3		88.53	788.	320.	20.8	4.05			0.	10.68	1263.	59.10

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-0-1G
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1	KM2F1	BF	KF-MS	KF-LOI	KLO	CL-LS	KCONTRL						
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KM2F1*						
	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H				
7.25	--	-2.7	0.05	-101	118.7	0.960	2.900	67.7	35.2	1255	7	0.59	0.940	3.040
8.25	--	--	--	--	118.7	0.960	2.900	67.7	35.2	1255	--	0.59	0.940	3.040
9.25	--	-2.9	0.06	-116	118.7	0.960	2.900	67.7	35.2	1255	12	0.59	0.940	3.040
10.25	--	-3.1	0.08	-155	118.7	0.960	2.900	67.7	35.2	1	16	0.59	0.940	3.040
11.25	--	-3.0	0.39	-713	118.7	0.960	2.900	67.7	35.2	0	16	0.59	0.940	3.040
12.25	--	-3.0	0.23	-411	118.7	0.960	2.900	67.7	35.2	0	19	0.59	0.940	3.040
13.25	--	-2.7	4.89	-9780	117.1	0.930	2.960	61.2	35.1	0	23	0.24	0.920	3.020
14.25	--	-2.9	0.02	-40	117.1	0.930	2.960	61.2	35.1	0	23	0.24	0.920	3.020
15.25	--	-3.0	0.13	-245	117.1	0.930	2.960	61.2	35.1	0	32	0.24	0.920	3.020
16.25	--	-2.7	2.93	-5893	117.1	0.930	2.960	61.2	35.1	1260	27	0.24	0.920	3.020
17.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	0	--	0.24	0.920	3.020
18.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	0	--	0.24	0.920	3.020
19.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	0	--	0.24	0.920	3.020
20.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
21.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
22.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
23.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
0.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
1.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
2.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
3.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
4.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
5.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
6.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020
7.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020

0.00 - 7.26														
MAX	-4.6				117.1	0.930	2.960	61.3	35.1	1234.		0.24	0.920	3.020
MIN	-5.4				117.1	0.930	2.960	61.3	35.1	1234.		0.24	0.920	3.020
MEAN	-4.9				117.1	0.930	2.960	61.3	35.1	1234.		0.24	0.920	3.020
ACCM	-0.2	0.0	0.00	0.	117.1	0.930	2.960	61.3	35.1	1234.	0.	0.24	0.920	3.020
0.00 - 0.00														
MAX	-2.2	8.07	88.		118.7	0.960	2.960	67.7	35.2	1324.	47.	0.59	0.940	3.040
MIN	-3.7	-0.04	-18001.		117.1	0.930	2.900	61.3	35.1	0.	1.	0.24	0.920	3.020
MEAN	-2.9	0.86	-1606.		118.0	0.946	2.927	64.8	35.2	772.	19.	0.43	0.931	3.032
ACCM	0.0	-44.1	13.04	-1686.	118.0	0.946	2.928	64.8	35.2	728.	19.	0.43	0.931	3.031

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	OA15V1		OA15P1		A54T1		A53T1		A52T1		A61T1		A50P1		DA1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	--	--	-10	10.42	345	-3	489	-15	368	191	221	184	-42	-0.18	182	
8.25	--	--	--	--	--	--	--	--	--	--	--	173	--	--	--	
9.25	--	--	-10	10.47	322	-1	386	-11	346	202	189	165	-36	-0.18	185	
10.25	--	--	-10	10.50	312	-4	374	-14	333	179	197	151	-41	-0.18	183	
11.25	--	--	-9	10.54	303	-2	362	-12	328	171	196	148	-41	-0.18	183	
12.25	--	--	-9	10.53	292	0	348	-10	321	166	198	143	-44	-0.17	183	
13.25	--	--	-10	10.48	284	-1	340	-12	306	179	177	138	-44	-0.18	182	
14.25	--	--	-10	10.56	271	0	330	-7	301	180	177	140	-37	-0.18	182	
15.25	--	--	-9	10.52	199	0	273	-11	258	191	200	179	-39	-0.18	181	
16.25	--	--	-9	10.59	164	1	205	-5	215	174	181	174	-41	-0.17	182	
17.25	--	--	--	--	--	--	--	--	--	--	--	169	--	--	--	
18.25	--	--	--	--	--	--	--	--	--	--	--	162	--	--	--	
19.25	--	--	--	--	--	--	--	--	--	--	--	154	--	--	--	
20.25	--	--	--	--	--	--	--	--	--	--	--	145	--	--	--	
21.25	--	--	--	--	--	--	--	--	--	--	--	139	--	--	--	
22.25	--	--	--	--	--	--	--	--	--	--	--	134	--	--	--	
23.25	--	--	--	--	--	--	--	--	--	--	--	130	--	--	--	
0.25	--	--	--	--	--	--	--	--	--	--	--	125	--	--	--	
1.25	--	--	--	--	--	--	--	--	--	--	--	121	--	--	--	
2.25	--	--	--	--	--	--	--	--	--	--	--	122	--	--	--	
3.25	--	--	--	--	--	--	--	--	--	--	--	113	--	--	--	
4.25	--	--	--	--	--	--	--	--	--	--	--	122	--	--	--	
5.25	--	--	--	--	--	--	--	--	--	--	--	126	--	--	--	
6.25	--	--	--	--	--	--	--	--	--	--	--	136	--	--	--	
7.25	--	--	--	--	--	--	--	--	--	--	--	145	--	--	--	

0.00 - 7.29

MAX													149.		
MIN													112.		
MEAN													126.		
ACCM	0.0	0.0	0.		0.	0.	0.	0.	0.	0.	0.	0.	126.	0.	0.00 0.

0.00 - 0.00

MAX			-9.	10.66	1745.	6.	1305.	3.	2042.	991.	970.	867.	-27.	-0.16	192.
MIN			-12.	10.29	-3.	-8.	-89.	-28.	9.	-97.	-244.	-238.	-51.	-0.21	173.
MEAN			-10.	10.48	327.	-2.	388.	-13.	350.	198.	220.	173.	-40.	-0.18	183.
ACCM	0.0	0.0	-10.		327.	-2.	388.	-13.	350.	198.	220.	173.	-40.	-0.18	183.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ 202 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ 2CO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL	LTWT	LTWT	LTWT	LTWTGSP	NOXL	A50T1	OA15X1	OA1X2CO	OA2V1	Z	T/H	RPM		
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	Z	Z	
7.25				1255	929	1305	0.2	0.2	0.023	184	-0.21	10.42	-0.18	0.05	182
8.25				1255	929	1305	0.1	0.2	0.000	173	-0.29	--	--	--	--
9.25				1255	929	1305	0.1	0.2	0.000	165	-0.36	10.47	-0.18	0.06	185
10.25				1	929	915	0.1	0.2	0.000	151	-6.60	10.50	-0.18	0.08	183
11.25				0	929	915	0.1	0.2	0.000	148	-0.24	10.54	-0.18	0.39	183
12.25				0	929	915	0.1	0.2	0.000	143	-0.06	10.53	-0.17	0.23	193
13.25				0	929	915	0.1	0.2	0.000	138	-0.12	10.48	-0.18	4.89	182
14.25				0	929	915	0.1	0.2	0.000	140	-0.10	10.56	-0.18	0.02	182
15.25				0	929	915	0.1	0.2	0.000	179	-0.03	10.52	-0.18	0.13	181
16.25				1260	929	915	0.1	0.2	0.000	174	-0.32	10.59	-0.17	2.93	182
17.25				0	929	915	0.1	0.2	0.000	169	-0.22	--	--	--	--
18.25				0	929	915	0.1	0.2	0.000	162	-0.13	--	--	--	--
19.25				0	929	915	0.1	0.2	0.000	154	-0.13	--	--	--	--
20.25				1234	929	915	0.1	0.2	0.000	145	-0.33	--	--	--	--
21.25				1234	929	915	0.1	0.2	0.000	139	-0.29	--	--	--	--
22.25				1234	929	915	0.1	0.2	0.000	134	-0.11	--	--	--	--
23.25				1234	929	915	0.1	0.2	0.000	130	-0.13	--	--	--	--
0.25				1234	929	915	0.1	0.2	0.000	125	-0.01	--	--	--	--
1.25				1234	929	915	0.1	0.2	0.000	121	-0.14	--	--	--	--
2.25				1234	929	915	0.1	0.2	0.000	122	0.21	--	--	--	--
3.25				1234	929	915	0.1	0.2	0.000	113	-0.40	--	--	--	--
4.25				1234	929	915	0.1	0.2	0.000	122	0.29	--	--	--	--
5.25				1234	929	915	0.1	0.2	0.000	126	0.30	--	--	--	--
6.25				1234	929	915	0.1	0.2	0.000	136	0.52	--	--	--	--
7.25				1234	929	915	0.1	0.2	0.000	145	0.36	--	--	--	--

0.00 - 7.30															
MAX				1234.	930.	916.	0.2	0.2	0.000	150.	0.56				
MIN				1234.	930.	916.	0.2	0.2	0.000	112.	-0.61				
MEAN	0.00	0.00		1234.	930.	916.	0.2	0.2	0.000	126.	0.08				
ACCH	74.18	33.90		1234.		916.			0.000	126.	0.08	0.00	0.00	0.	
0.00 - 8.00															
MAX				1324.	930.	1306.	0.2	0.2	0.050	867.	7.25	10.66	-0.16	8.07	192.
MIN				0.	836.	916.	-9.8	-9.8	0.000	-238.	-8.36	10.29	-0.21	-0.04	173.
MEAN	15.19	8.95		772.	917.	1076.	-1.2	-1.2	0.015	173.	-0.17	10.48	-0.18	0.86	183.
ACCH	74.18	33.90		728.		1076.			0.015	173.	-0.17		-0.18	13.04	183.

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL	COAL HEAT VALUE
% MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH.T
W1/ COAL TO KILN	MBTU' PER SH.T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		RTU		LTWT	
	T/H	T/H	T	T/H	KC/KG	KC/KG	%	%			T/H	LB. COAL	GR/L	H		
7.25	--	-2.7	-66	0.05	-101	-107	21.2	4.35	9271	-3.0	0	-3.90	1255			
8.25	--	--	-69	--	--	--	21.2	4.35	9271	-3.1	--	--	1255			
9.25	--	-2.9	-70	0.06	-116	-123	21.2	4.35	9271	-3.2	0	-4.25	1255			
10.25	--	-3.1	-75	0.08	-155	-163	21.2	4.35	9271	-3.3	0	-4.77	1			
11.25	--	-3.0	-72	0.39	-713	-752	21.2	4.35	9271	-3.2	0	-26.33	0			
12.25	--	-3.0	-73	0.23	-411	-433	21.2	4.35	9268	-3.3	0	-14.91	0			
13.25	--	-2.7	-65	4.89	-9780	-10310	21.2	4.35	9271	-2.9	-3	-327.48	0			
14.25	--	-2.9	-70	0.02	-40	-42	21.2	4.35	9271	-3.1	0	-1.72	0			
15.25	--	-3.0	-74	0.13	-245	-258	21.2	4.35	9271	-3.3	0	-7.76	0			
16.25	--	-2.7	-64	2.93	-5893	-6213	21.2	4.35	9271	-2.9	-2	-195.91	1260			
17.25	--	--	-68	--	--	--	21.2	4.35	9271	-3.0	--	--	0			
18.25	--	--	-62	--	--	--	21.2	4.35	9271	-2.8	--	--	0			
19.25	--	--	-70	--	--	--	21.2	4.35	9271	-3.1	--	--	0			
20.25	--	--	-64	--	--	--	21.2	4.35	9271	-2.9	--	--	1234			
21.25	--	--	-67	--	--	--	21.2	4.35	9271	-3.0	--	--	1234			
22.25	--	--	-70	--	--	--	21.2	4.35	9268	-3.1	--	--	1234			
23.25	--	--	-62	--	--	--	21.2	4.35	9268	-2.8	--	--	1234			
0.25	--	--	-62	--	--	--	21.2	4.35	9271	-2.8	--	--	1234			
1.25	--	--	-71	--	--	--	21.2	4.35	9271	-3.2	--	--	1234			
2.25	--	--	-69	--	--	--	21.2	4.35	9271	-3.1	--	--	1234			
3.25	--	--	-73	--	--	--	21.2	4.35	9271	-3.3	--	--	1234			
4.25	--	--	-67	--	--	--	21.2	4.35	9268	-3.0	--	--	1234			
5.25	--	--	-72	--	--	--	21.2	4.35	9271	-3.2	--	--	1234			
6.25	--	--	-73	--	--	--	21.2	4.35	9268	-3.3	--	--	1234			
7.25	--	--	-79	--	--	--	21.2	4.35	9268	-3.5	--	--	1234			

0.00 - 7.31													
MAX	-4.6		-58.				21.2	4.36	9271.	-2.6			1234.
MIN	-5.4		-87.				21.2	4.36	9268.	-3.9			1234.
MEAN	-4.9		-71.				21.2	4.36	9271.	-3.2			1234. 0.08
ACCH	-0.2	0.0		0.00	0.	0.	21.2	4.36			0.	0.00	1234. 74.18
0.00 - 8.00													
MAX		-2.2	-53.	8.07	88.	93.	21.2	4.36	9271.	-2.4	0.	3.04	1324.
MIN		-3.7	-88.	-0.04	-18001.	-19977.	21.2	4.36	9268.	-4.0	-7.	-624.19	0.
MEAN		-2.9	-70.	0.86	-1606.	-1693.	21.2	4.36	9271.	-3.1	-1.	-55.68	772. 15.19
ACCH	0.0	-44.1		13.04	-1606.	-1693.	21.2	4.36			-1.	-55.67	728. 74.18

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-0-1G
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LDI	KLO	CL-LS		KCONTRL				
	PROD			KCAL		KF-LS	C3S			LTWT	FCAO	CL-MS	KN2F1#			
	T/H	T/H	T/H	KC/KG		%	%	GR/L	DEG.C	%	H	H				
7.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
8.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
9.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
10.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
11.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
12.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
13.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
14.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
15.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
16.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
17.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
18.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
19.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
20.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
21.25	--	--	--	--	117.1	0.930	2.960	61.2	35.1	1234	--	0.24	0.920	3.020		
22.25	34.0	20.6	5.43	1426	117.1	0.930	2.960	61.2	35.1	1234	50	0.24	0.920	3.020		
23.25	34.7	21.1	6.76	1740	117.1	0.930	2.960	61.2	35.1	1234	39	0.24	0.920	3.020		
0.25	41.3	25.1	6.75	1460	114.3	0.890	3.060	52.8	35.1	1234	54	0.24	0.920	3.020		
1.25	44.9	27.3	7.03	1400	114.3	0.890	3.060	52.8	35.1	1234	46	0.24	0.920	3.020		
2.25	46.2	28.1	7.34	1419	114.3	0.890	3.060	52.8	35.1	1305	63	0.24	0.920	3.020		
3.25	54.3	33.0	7.69	1264	114.3	0.890	3.060	52.8	35.1	1395	69	0.24	0.920	3.020		
4.25	66.3	40.3	7.71	1037	114.3	0.890	3.060	52.8	35.1	1495	116	0.24	0.920	3.020		
5.25	71.7	43.6	7.84	977	114.3	0.890	3.060	52.8	35.1	1405	141	0.24	0.920	3.020		
6.25	44.3	--	--	--	114.3	0.890	3.060	52.8	35.1	1405	--	0.24	0.920	3.020		
7.25	57.5	34.9	8.17	1269	119.1	0.950	2.900	66.4	35.1	1405	120	0.24	0.920	3.020		
0.00 - 8.48																
MAX	72.8	44.3	9.46	63660	119.1	0.950	3.060	66.4	35.1	1495	161	0.24	0.920	3.020		
MIN	-4.7	-3.3	0.14	-23666	114.3	0.890	2.900	52.8	35.1	1234	32	0.24	0.920	3.020		
MEAN	54.0	33.1	7.65	1202	115.1	0.899	3.035	54.9	35.1	1380	91	0.24	0.920	3.020	0.00	8.31
ACCM	461.8	275.3	63.57	1254	114.9	0.897	3.040	54.5	35.1	1387	91	0.24	0.920	3.020	33.90	85.16
0.00 - 0.00																
MAX	40.0	24.4	6.85	113946	117.1	0.930	3.060	61.3	35.1	1234	58	0.24	0.920	3.020		
MIN	-5.4	-3.5	0.03	-225330	114.3	0.890	2.960	52.8	35.1	1234	26	0.24	0.920	3.020		
MEAN	29.7	13.7	5.50	-543	117.0	0.929	2.962	61.2	35.1	1234	42	0.24	0.920	3.021	0.00	2.80
ACCM	66.8	38.2	15.38	2187	117.0	0.928	2.964	60.9	35.1	1234	42	0.24	0.920	3.020	33.90	76.95

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCO EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	--	--	--	--	--	--	--	--	--	--	--	142	--	--	--	
8.25	--	--	--	--	--	--	--	--	--	--	--	153	--	--	--	
9.25	--	--	--	--	--	--	--	--	--	--	--	164	--	--	--	
10.25	--	--	--	--	--	--	--	--	--	--	--	180	--	--	--	
11.25	--	--	--	--	--	--	--	--	--	--	--	193	--	--	--	
12.25	--	--	--	--	--	--	--	--	--	--	--	204	--	--	--	
13.25	--	--	--	--	--	--	--	--	--	--	--	217	--	--	--	
14.25	--	--	--	--	--	--	--	--	--	--	--	226	--	--	--	
15.25	--	--	--	--	--	--	--	--	--	--	--	236	--	--	--	
16.25	--	--	--	--	--	--	--	--	--	--	--	248	--	--	--	
17.25	--	--	--	--	--	--	--	--	--	--	--	262	--	--	--	
18.25	--	--	--	--	--	--	--	--	--	--	--	271	--	--	--	
19.25	--	--	--	--	--	--	--	--	--	--	--	286	--	--	--	
20.25	--	--	--	--	--	--	--	--	--	--	--	292	--	--	--	
21.25	--	--	--	--	--	--	--	--	--	--	--	333	--	--	--	
22.25	0.7	17.0	3	10.49	677	40	609	54	481	324	330	343	41	-0.18	500	
23.25	0.7	13.0	42	1.54	774	89	727	125	586	403	400	392	169	-0.19	589	
0.25	0.8	15.3	44	1.05	781	96	725	136	591	398	400	399	180	-0.18	591	
1.25	0.9	19.2	46	1.42	785	102	743	144	599	402	404	402	193	-0.18	608	
2.25	0.9	20.1	52	0.83	789	107	737	148	593	392	391	390	205	-0.18	618	
3.25	1.1	19.8	54	1.47	789	118	745	164	593	385	384	385	233	-0.18	641	
4.25	1.3	18.6	63	1.73	790	116	738	191	586	375	375	379	266	-0.18	656	
5.25	1.4	17.3	71	2.43	792	130	753	224	611	397	394	394	352	-0.06	752	
6.25	1.2	4.5	--	--	--	--	--	--	--	--	--	383	--	--	--	
7.25	1.2	13.1	76	2.16	794	146	774	201	638	423	423	420	290	-0.01	703	

0.00 - 8.49	
MAX	1.5 30.9 104. 10.42 825. 176. 785. 261. 679. 488. 492. 456. 393. 1.14 757.
MIN	9.0 0.1 -11. -0.12 697. 9. 677. 9. 540. 347. 343. 360. 18. -0.20 553.
MEAN	1.2 18.3 62. 2.06 789. 120. 747. 178. 601. 393. 393. 395. 255. -0.12 659.
ACCH	1.2 18.3 62. 789. 120. 747. 178. 601. 393. 393. 395. 255. -0.12 659.
0.00 - 0.00	
MAX	0.9 19.2 57. 10.60 781. 115. 735. 142. 603. 415. 417. 406. 179. 0.16 595.
MIN	-0.2 0.1 -12. -0.11 567. -7. 511. -15. 421. 315. 320. 112. -51. -0.20 364.
MEAN	0.7 15.2 19. 6.57 716. 52. 657. 71. 533. 373. 376. 211. 75. -0.16 518.
ACCH	0.7 15.2 19. 716. 52. 657. 71. 533. 373. 376. 211. 75. -0.16 518.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KN2F1#			KALARN			ESTLTW			NOXST		NOXALT		A50ALT		KN2F1	
	KCONTRL			LTWT			LTWGTSP			NOXLT		A50T1		OA15X1		OA1X2CO	
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C		%		%		%	T/H
7.25				1234	929	915	0.1	0.2	0.000	142	0.33	--	--	--	--	--	--
8.25				1234	929	915	0.1	0.2	0.000	153	0.57	--	--	--	--	--	--
9.25				1234	929	915	0.1	0.2	0.000	164	0.54	--	--	--	--	--	--
10.25				1234	929	915	0.1	0.2	0.000	180	0.63	--	--	--	--	--	--
11.25				1234	929	915	0.1	0.2	0.000	193	0.60	--	--	--	--	--	--
12.25				1234	929	915	0.1	0.2	0.000	204	0.37	--	--	--	--	--	--
13.25				1234	929	915	0.1	0.2	0.000	217	0.36	--	--	--	--	--	--
14.25				1234	929	915	0.1	0.2	0.000	226	0.38	--	--	--	--	--	--
15.25				1234	929	915	0.1	0.2	0.000	236	0.66	--	--	--	--	--	--
16.25				1234	929	915	0.1	0.2	0.000	248	0.64	--	--	--	--	--	--
17.25				1234	929	915	0.1	0.2	0.000	262	0.61	--	--	--	--	--	--
18.25				1234	929	915	0.1	0.2	0.000	271	0.39	--	--	--	--	--	--
19.25				1234	929	915	0.1	0.2	0.000	286	0.30	--	--	--	--	--	--
20.25				1234	929	915	0.1	0.2	0.000	292	0.24	--	--	--	--	--	--
21.25				1234	929	915	0.1	0.2	0.000	333	3.62	--	--	--	--	--	--
22.25				1234	929	5330	0.1	0.2	0.000	343	-2.95	10.49	-0.18	5.43	500		
23.25				1234	1085	1071	16.5	16.9	0.751	392	4.18	1.54	-0.19	6.76	589		
0.25				1234	1165	1121	25.3	25.5	0.254	399	0.56	1.85	-0.18	6.75	591		
1.25				1234	1195	1157	28.7	28.7	0.084	402	0.98	1.42	-0.18	7.03	608		
2.25				1305	1200	1166	29.1	29.2	0.003	398	-0.21	0.83	-0.18	7.34	618		
3.25				1395	1199	1166	29.1	29.2	0.000	385	0.40	1.47	-0.18	7.69	641		
4.25				1495	1199	1159	29.1	29.2	0.000	379	0.87	1.73	-0.18	7.71	656		
5.25				1405	1199	1151	29.1	29.2	0.000	394	3.60	2.43	-0.06	7.84	752		
6.25				1405	1297	1092	40.6	39.6	0.398	383	-5.23	--	--	--	--		
7.25				1405	1190	1120	28.7	28.2	0.683	420	0.31	2.16	-0.01	8.17	703		

0.00 - 8.50

MAX				1495.	1522.	5310.	58.3	63.8	2.113	456.	5.08	10.42	1.14	9.46	757.		
MIN				1234.	1012.	998.	7.8	9.1	-1.872	360.	-8.15	-0.12	-0.20	0.14	553.		
MEAN	0.35	0.00		1380.	1230.	1249.	32.4	32.5	0.110	395.	0.02	2.06	-0.11	7.66	659.		
ACCM	85.21	33.90		1387.		1249.			0.110	395.	0.02		-0.11	63.97	659.		

0.00 - 0.00

MAX				1234.	1145.	7062.	23.0	23.3	0.811	406.	4.35	10.60	0.16	6.85	595.		
MIN				1234.	930.	916.	0.2	0.2	0.000	112.	-7.15	-0.11	-0.20	0.03	364.		
MEAN	2.80	0.00		1234.	937.	999.	1.0	1.0	0.027	211.	0.38	6.57	-0.16	5.50	518.		
ACCM	76.95	33.90		1234.		999.			0.027	211.	0.38		-0.16	15.38	518.		

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL	COAL HEAT VALUE
Z MOISTURE IN COAL	
NET HEAT CONSUMP.	SHORT TONS CLINKER
HEAT CONSUMPTION	LB COAL / SH. T
W1/ COAL TO KILN	NBTU' PER SH. T
KILN PRODUC. RATE	
KILN PRODUCTION	U1/ LITER WEIGHT
W1/ KILN FEED	COAL TO KILN

HOUR	HD10F1		PRODR		KCAL		C-MOIST		C-HEAT	STONS	BTU	LTWT	
	PROD	KN2F1	KN2F1	NKCAL	C-ASH				LB. COAL		KN2F1#		
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z		T/H		GR/L	H
7.25	--	--	-66	--	--	--	21.2	4.35	9271	-3.0	--	--	1234
8.25	--	--	-70	--	--	--	21.2	4.35	9268	-3.1	--	--	1234
9.25	--	--	-71	--	--	--	21.2	4.35	9271	-3.2	--	--	1234
10.25	--	--	-72	--	--	--	21.2	4.35	9271	-3.2	--	--	1234
11.25	--	--	-69	--	--	--	21.2	4.35	9271	-3.1	--	--	1234
12.25	--	--	-69	--	--	--	21.2	4.35	9271	-3.1	--	--	1234
13.25	--	--	-71	--	--	--	21.2	4.35	9271	-3.2	--	--	1234
14.25	--	--	-70	--	--	--	21.2	4.35	9271	-3.1	--	--	1234
15.25	--	--	-71	--	--	--	21.2	4.35	9271	-3.2	--	--	1234
16.25	--	--	-72	--	--	--	21.2	4.35	9271	-3.2	--	--	1234
17.25	--	--	-71	--	--	--	21.2	4.35	9271	-3.2	--	--	1234
18.25	--	--	-68	--	--	--	21.2	4.35	9271	-3.0	--	--	1234
19.25	--	--	-70	--	--	--	21.2	4.35	9271	-3.1	--	--	1234
20.25	--	--	-66	--	--	--	21.2	4.35	9271	-3.0	--	--	1234
21.25	--	--	-67	--	--	--	21.2	4.35	9268	-3.0	--	--	1234
22.25	34.0	20.6	496	5.43	1426	1584	21.2	4.35	9271	22.4	0	49.66	1234
23.25	34.7	21.1	506	6.76	1740	1835	21.2	4.35	9271	22.9	0	60.59	1234
0.25	41.3	25.1	602	6.75	1460	1539	21.2	4.35	9271	27.2	0	50.55	1234
1.25	44.9	27.3	655	7.03	1400	1475	21.2	4.35	9271	29.6	0	48.66	1234
2.25	46.2	28.1	674	7.34	1419	1496	21.2	4.35	9271	30.5	0	49.43	1305
3.25	54.3	33.0	792	7.69	1264	1332	21.2	4.35	9271	35.8	0	44.07	1395
4.25	66.3	40.3	968	7.71	1037	1094	21.2	4.35	9271	43.8	0	36.83	1495
5.25	71.7	43.6	1046	7.84	977	1030	21.2	4.35	9271	47.3	0	33.75	1405
6.25	44.3	--	646	--	--	--	21.2	4.35	9271	29.2	--	--	1405
7.25	57.5	34.9	839	8.17	1269	1337	21.2	4.35	9271	37.9	0	44.07	1405

0.00 - 8.51	
MAX	72.8 44.3 1062. 9.46 63660. 67112. 21.2 4.36 9271. 48.0 24. 2207.5 1495.
MIN	-4.7 -3.3 -80. 0.14-23666. -24949. 21.2 4.36 9268. -3.6 -9. -820.64 1234.
MEAN	54.1 33.2 766. 7.66 1202. 1267. 21.2 4.36 9272. 34.6 0. 41.65 1380. 8.36
ACCM	465.7 277.6 64.07 1254. 1267. 21.2 4.36 0. 41.65 1387. 85.22
0.00 - 0.00	
MAX	40.0 24.4 585. 6.85 113946 120164 21.2 4.36 9271. 26.5 43. 3949.9 1234.
MIN	-5.4 -3.5 -87. 0.03-225330-237627 21.2 4.36 9268. -3.9 -84. -7813.5 1234.
MEAN	29.7 13.7 -23. 5.50 -543. -573. 21.2 4.36 9270. -1.0 -0. -18.76 1234. 2.80
ACCM	66.8 38.2 15.38 2187. -572. 21.2 4.36 1. -18.76 1234. 76.95

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-0-1G
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI	KLO	CL-LS		KCONTRL		
	PROD		T/H	KCAL		KF-LS	C3S			LTWT	FCAO	CL-MS	KN2F1*	
	T/H	T/H	T/H	KC/KG		Z	Z	GR/L	DEG.C	Z	H	H		
7.26	51.9	31.5	7.96	1368	114.3	0.890	3.060	52.8	35.1	1405	152	0.24	0.920	3.020
8.26	61.3	37.3	8.79	1279	119.1	0.950	2.900	66.4	35.1	1405	93	0.24	0.920	3.020
9.26	77.1	46.9	8.82	928	119.1	0.950	2.900	66.4	35.1	1380	116	0.24	0.920	3.020
10.26	81.1	49.3	8.30	914	119.1	0.950	2.900	66.4	35.1	1390	145	0.24	0.920	3.020
11.26	81.7	49.7	8.68	949	119.1	0.950	2.900	66.4	35.1	1160	178	0.24	0.920	3.020
12.26	81.1	49.3	8.80	968	116.3	0.920	3.020	58.9	34.9	1195	216	0.59	0.930	3.080
13.26	80.8	49.1	8.79	972	116.3	0.920	3.020	58.9	34.9	1195	208	0.59	0.930	3.080
14.26	81.4	49.5	8.78	962	116.3	0.920	3.020	58.9	34.9	1195	206	0.59	0.930	3.080
15.26	86.3	52.4	8.77	908	116.3	0.920	3.020	58.9	34.9	1320	233	0.59	0.930	3.080
16.26	81.3	49.4	8.53	936	116.3	0.920	3.020	58.9	34.9	1360	258	0.59	0.930	3.080
17.26	82.4	50.1	8.18	886	118.8	0.950	2.930	65.7	34.9	1315	252	0.59	0.930	3.080
18.26	82.5	50.1	8.15	882	118.8	0.950	2.930	65.7	34.9	1340	235	0.59	0.930	3.080
19.26	81.8	49.7	7.81	852	118.8	0.950	2.930	65.7	34.9	1380	215	0.59	0.930	3.080
20.26	87.0	52.9	8.24	845	118.8	0.950	2.930	65.7	34.9	1390	235	0.59	0.930	3.080
21.26	86.8	52.7	8.17	840	118.8	0.950	2.930	65.7	34.9	1295	232	0.59	0.930	3.080
22.26	87.1	52.9	8.14	835	118.8	0.950	2.930	65.7	34.9	1320	226	0.59	0.930	3.080
23.26	91.8	55.8	8.12	790	118.8	0.950	2.930	65.7	34.9	1365	229	0.59	0.930	3.080
0.25	96.0	58.4	8.34	776	118.8	0.950	2.930	65.7	34.9	1315	249	0.59	0.930	3.080
1.25	95.7	58.2	8.61	802	119.3	0.960	2.900	67.5	34.9	1365	246	0.59	0.930	3.080
2.25	96.3	58.5	8.61	798	119.3	0.960	2.900	67.5	34.9	1330	229	0.59	0.930	3.080
3.25	99.2	60.3	8.64	778	119.3	0.960	2.900	67.5	34.9	1330	243	0.59	0.930	3.080
4.25	99.7	60.6	8.59	769	119.3	0.960	2.900	67.5	34.9	1345	269	0.59	0.930	3.080
5.25	99.9	60.7	8.64	772	119.3	0.960	2.900	67.5	34.9	1265	272	0.59	0.930	3.080
6.25	100.0	60.8	9.11	814	119.3	0.960	2.900	67.5	34.9	1295	248	0.59	0.930	3.080
7.25	99.6	60.5	8.99	806	119.3	0.960	2.900	67.5	34.9	1290	267	0.59	0.930	3.080

0.00 - 7.27														
MAX	101.4	61.7	9.23	931.	119.3	0.960	2.930	67.5	35.0	1365.	297.	0.59	0.930	3.080
MIN	85.1	51.8	8.24	755.	118.8	0.950	2.900	65.7	35.0	1265.	222.	0.59	0.930	3.080
MEAN	97.9	59.5	8.73	797.	119.2	0.959	2.904	67.3	35.0	1322.	253.	0.59	0.930	3.080
ACCM	729.5	443.5	65.05	797.	119.3	0.960	2.900	67.5	35.0	1321.	253.	0.59	0.930	3.080
0.00 - 0.00														
MAX	95.0	57.7	9.46	63660.	119.1	0.950	3.060	66.4	35.1	1495.	266.	0.59	0.930	3.080
MIN	-4.7	-3.3	0.14	-23666.	114.3	0.890	2.980	52.8	35.0	1160.	32.	0.24	0.920	3.020
MEAN	72.5	44.3	8.13	1013.	117.0	0.926	2.981	60.6	35.1	1333.	171.	0.42	0.925	3.049
ACCM	1706.1	1031.3	189.10	996.	117.0	0.926	2.982	60.6	35.0	1333.	171.	0.43	0.925	3.053

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCD EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2C0	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.26	1.1	9.6	89	2.47	794	151	763	226	618	412	412	409	350	0.00	745	
8.26	1.2	23.9	80	3.13	794	134	772	226	633	412	410	412	342	-0.02	717	
9.26	1.6	25.1	123	3.80	798	202	782	292	633	413	406	412	472	-0.01	800	
10.26	1.6	24.3	96	3.76	796	154	778	267	624	404	399	404	457	-0.02	773	
11.26	1.6	26.8	125	3.81	796	204	777	287	625	398	394	398	465	-0.02	776	
12.26	1.6	25.8	111	3.40	799	180	779	288	624	401	394	398	467	-0.01	774	
13.26	1.6	28.9	97	3.53	800	191	779	273	627	407	401	404	466	0.00	773	
14.26	1.6	29.3	114	3.34	802	196	786	303	633	403	397	404	502	-0.01	803	
15.26	1.7	35.1	129	2.68	802	212	780	311	617	393	385	395	508	0.00	799	
16.26	1.6	31.0	131	3.17	801	207	781	317	629	400	392	400	517	-0.01	803	
17.26	1.6	30.7	143	1.79	805	208	781	334	631	402	394	403	531	-0.01	805	
18.26	1.6	31.6	112	3.03	806	199	785	300	639	406	398	406	512	0.00	800	
19.26	1.6	29.3	128	3.10	802	220	775	309	618	395	386	395	515	-0.01	801	
20.26	1.7	26.4	98	3.28	799	170	775	298	613	384	376	385	509	-0.01	809	
21.26	1.7	24.4	136	1.91	802	224	775	316	621	394	387	393	519	-0.01	798	
22.26	1.7	26.7	97	2.29	806	170	778	274	624	395	390	396	489	-0.15	801	
23.26	1.8	29.7	98	2.05	806	178	778	280	617	389	384	391	502	-0.05	814	
0.25	1.9	28.3	94	2.99	805	173	776	305	626	393	383	392	514	-0.07	821	
1.25	1.9	28.6	104	3.02	806	197	774	305	624	394	388	394	552	-0.18	834	
2.25	1.9	30.1	87	3.27	806	177	779	305	620	395	390	396	547	-0.18	831	
3.25	1.9	32.1	104	2.90	806	188	777	315	621	390	385	391	566	-0.11	839	
4.25	1.9	32.2	102	2.93	806	198	775	307	615	388	384	389	569	-0.17	842	
5.25	1.9	33.7	91	3.12	807	202	774	301	622	394	392	398	561	-0.17	843	
6.25	1.9	33.3	86	2.62	808	177	777	290	624	392	386	391	563	-0.17	837	
7.25	1.9	36.1	83	2.89	808	194	777	292	616	394	388	395	558	-0.18	844	

0.00 - 7.29															
MAX	2.0	40.8	126.	3.72	812.	231.	791.	339.	646.	418.	412.	414.	586.	-0.02	850.
MIN	1.8	27.5	71.	1.92	802.	124.	765.	272.	609.	393.	377.	385.	498.	-0.21	817.
MEAN	2.0	32.3	97.	2.89	807.	189.	776.	305.	621.	393.	387.	393.	556.	-0.16	836.
ACCH	2.0	32.3	97.		807.	189.	776.	305.	621.	393.	387.	393.	556.	-0.16	836.

0.00 - 0.00															
MAX	2.0	35.8	153.	10.57	825.	246.	795.	338.	679.	488.	492.	456.	546.	1.14	825.
MIN	-0.5	0.1	-11.	-0.12	697.	9.	677.	3.	540.	347.	343.	360.	-8.	-0.20	445.
MEAN	1.5	24.6	94.	2.69	797.	165.	768.	252.	617.	397.	393.	397.	407.	-0.06	745.
ACCH	1.5	24.6	94.		797.	165.	768.	252.	617.	397.	393.	397.	407.	-0.06	745.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME	W1/ NOX CHANGE LT
W1/ NOX REG STIME	W1/ T EXIT PREHEAT
W1/ LTW FOR CONTRL	W1/ A50T1 CHANGE
W1/ ESTIMATED LTW	W1/ Z02 KILN OUTL
U1/ LITER WEIGHT	
KILN CON. MEASUR.	W1/ ZCO EX PREHEAT
KILN CONTROL	W1/ COAL TO KILN
COAL TO KILN	J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL		LTWT	LTWGTSP		NOXL	A50T1		OA15X1		OA1X2CO	OA2V1			
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM	
7.26				1405	1024	4162	17.9	10.3	-1.644	409	1.73	2.47	0.00	7.96	745
8.26				1405	1413	1297	50.7	52.0	-0.222	412	0.20	3.13	-0.02	8.79	717
9.26				1380	1313	1375	43.8	44.5	-0.222	412	0.86	3.80	-0.01	8.02	800
10.26				1380	1144	3468	28.4	23.9	-0.598	404	0.16	3.76	-0.02	8.30	773
11.26				1160	1158	1164	27.8	28.8	-0.319	398	-0.11	3.81	-0.02	8.68	776
12.26				1195	1201	1199	34.2	33.7	0.228	398	0.00	3.40	-0.01	8.90	774
13.26				1195	1232	1229	38.0	37.6	0.125	404	0.46	3.53	0.00	8.79	773
14.26				1195	1262	1368	41.9	41.5	0.293	404	-0.05	3.34	-0.01	8.78	803
15.26				1320	1224	1551	35.3	36.6	-0.231	395	-1.43	2.68	0.00	8.77	799
16.26				1360	1280	1458	43.3	43.7	0.554	400	-0.02	3.17	-0.01	8.53	803
17.26				1315	1260	1260	40.0	40.3	-0.020	403	0.27	1.79	-0.01	8.18	805
18.26				1340	1341	1723	55.4	50.9	0.792	406	0.29	3.03	0.00	8.15	800
19.26				1380	1375	1378	55.4	55.5	-0.122	395	-0.42	3.10	-0.01	7.81	801
20.26				1390	1283	1282	44.3	42.5	-0.248	385	-0.15	3.28	-0.01	8.24	809
21.26				1295	1317	1315	45.1	46.1	0.220	393	0.78	1.91	-0.01	8.17	798
22.26				1320	1346	1342	49.3	49.8	0.320	396	0.16	2.29	-0.15	8.14	801
23.26				1365	1411	1410	58.7	59.5	0.158	391	-0.96	2.05	-0.05	8.12	814
0.25				1315	1313	1804	47.8	47.5	-0.212	392	0.12	2.99	-0.07	8.34	821
1.25				1365	1314	1796	42.7	42.4	-0.210	394	0.41	3.02	-0.18	8.61	834
2.25				1330	1325	1810	44.8	45.5	0.035	396	0.43	3.27	-0.18	8.61	831
3.25				1330	1321	1364	45.3	44.4	-0.093	391	0.29	2.90	-0.11	8.64	839
4.25				1345	1387	1317	39.4	40.3	-0.196	389	0.07	2.93	-0.17	8.59	842
5.25				1265	1306	1788	43.1	40.3	0.691	398	-1.40	3.12	-0.17	8.64	843
6.25				1295	1292	1293	38.5	37.7	0.076	391	-0.04	2.62	-0.17	9.11	837
7.25				1290	1282	1396	34.2	34.4	-0.143	395	0.05	2.89	-0.18	8.99	844

0.00 - 7.30														
MAX			1365.	1332.	1826.	49.8	48.3	0.076	414.	3.18	3.72	-0.02	9.23	850.
MIN			1265.	1258.	1278.	27.9	26.9	-0.015	385.	-1.72	1.92	-0.21	8.24	817.
MEAN	7.52	0.20	1322.	1307.	1491.	41.4	41.3	-0.087	393.	0.02	2.89	-0.16	8.73	836.
ACCM	107.4	34.10	1321.		1491.			-0.087	393.	0.02		-0.16	65.60	836.
0.00 - 0.00														
MAX			1495.	1522.	5310.	60.0	63.8	2.113	456.	5.08	10.57	1.14	9.46	825.
MIN			1160.	1012.	998.	7.8	9.1	-1.872	360.	-8.15	-0.12	-0.20	0.14	445.
MEAN	23.28	0.00	1333.	1259.	1350.	38.5	38.6	0.049	397.	-0.02	2.69	-0.06	8.13	745.
ACCM	99.95	33.90	1333.		1350.			0.049	397.	-0.02		-0.06	189.10	745.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

% ASH IN COAL

% MOISTURE IN COAL

NET HEAT CONSUMP.

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUC. RATE

KILN PRODUCTION

W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER

LB COAL / SH. T

MBTU' PER SH. T

U1/ LITER WEIGHT

COAL TO KILN

HOUR	H010F1		PRODR	KCAL		C-MOIST		C-HEAT	STONS	BTU		LTWT	
	T/H	T/H	T	KM2F1	NKCAL	%	%		T/H	LB. COAL		KN2F1*	
7.26	51.9	31.5	758	7.96	1368	1442	21.2	4.35	9271	34.2	0	48.03	1405
8.26	61.3	37.3	895	8.79	1279	1348	21.2	4.35	9271	40.5	0	44.03	1405
9.26	77.1	46.9	1126	8.02	928	979	21.2	4.35	9268	50.9	0	32.19	1380
10.26	81.1	49.3	1184	8.30	914	963	21.2	4.35	9271	53.5	0	31.92	1380
11.26	81.7	49.7	1193	8.68	949	1000	21.2	4.35	9268	53.9	0	32.86	1160
12.26	81.1	49.3	1184	8.80	968	1036	21.5	5.22	9134	53.5	0	33.81	1195
13.26	80.8	49.1	1179	8.79	972	1040	21.5	5.22	9131	53.3	0	33.29	1195
14.26	81.4	49.5	1189	8.78	962	1030	21.5	5.22	9134	53.7	0	32.93	1195
15.26	86.3	52.4	1259	8.77	908	972	21.5	5.22	9134	56.9	0	31.20	1320
16.26	81.3	49.4	1187	8.53	936	1002	21.5	5.22	9134	53.6	0	31.85	1360
17.26	82.4	50.1	1203	8.18	886	948	21.5	5.22	9134	54.4	0	30.30	1315
18.26	82.5	50.1	1203	8.15	882	944	21.5	5.22	9134	54.4	0	30.25	1340
19.26	81.8	49.7	1194	7.81	852	912	21.5	5.22	9134	54.0	0	29.26	1380
20.26	87.0	52.9	1270	8.24	845	905	21.5	5.22	9134	57.4	0	28.98	1390
21.26	86.8	52.7	1266	8.17	840	899	21.5	5.22	9134	57.3	0	28.86	1295
22.26	87.1	52.9	1271	8.14	835	893	21.5	5.22	9134	57.5	0	28.55	1320
23.26	91.8	55.8	1339	8.12	790	846	21.5	5.22	9134	60.5	0	27.83	1365
0.25	96.0	58.4	1401	8.34	776	830	21.5	5.22	9134	63.4	0	26.56	1315
1.25	95.7	58.2	1397	8.61	802	859	21.5	5.22	9134	63.2	0	27.36	1365
2.25	96.3	58.5	1405	8.61	798	854	21.5	5.22	9134	63.5	0	27.10	1330
3.25	99.2	60.3	1447	8.64	778	832	21.5	5.22	9134	65.4	0	26.58	1330
4.25	99.7	60.6	1455	8.59	769	823	21.5	5.22	9134	65.8	0	26.21	1345
5.25	99.9	60.7	1458	8.64	772	826	21.5	5.22	9134	65.9	0	26.42	1265
6.25	100.0	60.8	1459	9.11	814	871	21.5	5.22	9134	66.0	0	27.84	1295
7.25	99.6	60.5	1453	8.99	806	862	21.5	5.22	9134	65.7	0	27.62	1290

0.00 - 7.31

MAX	101.4	61.7	1480	9.23	931	996	21.5	5.22	9134	66.9	0	31.81	1365
MIN	85.1	51.8	1242	8.24	755	808	21.5	5.22	9131	56.2	0	25.80	1265
MEAN	97.9	59.5	1429	8.73	797	853	21.5	5.22	9135	64.6	0	27.23	1322 7.53
ACCM	736.8	448.0		65.70	797	853	21.5	5.22			0	27.23	1321 107.4

0.00 - 0.00

MAX	95.0	57.7	1384	9.46	63660	67112	21.5	5.22	9271	62.6	24	2207.5	1495
MIN	-4.7	-3.3	-80	0.14	-23666	-24949	21.2	4.36	9131	-3.6	-9	-820.64	1160
MEAN	72.5	44.3	1036	8.13	1013	1075	21.3	4.79	9201	46.9	0	34.86	1333 23.28
ACCM	1706.1	1031.3		189.10	996	1076	21.3	4.79			0	34.83	1333 99.95

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-O-IG
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 W1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOUR	HO10F1		KM2F1		BF	KF-MS		KF-LOI		KLD	CL-LS		KCONTRL	
	PROD	T/H	T/H	KC/KG		KF-LS	C3S	LTWT	FCAO		CL-MS	KN2F1*	H	H

7.25	98.7	60.0	9.13	826	119.3	0.960	2.900	67.5	34.9	1295	259	0.59	0.930	3.080
8.25	100.0	60.8	9.05	809	117.6	0.950	2.790	65.6	34.9	1290	301	0.59	0.930	3.080
9.25	99.4	60.4	9.35	839	117.6	0.950	2.790	65.6	34.9	1070	312	0.59	0.930	3.080
10.25	99.5	60.5	9.35	838	117.6	0.950	2.790	65.6	34.9	1080	239	0.59	0.930	3.080
11.25	100.3	61.0	9.26	824	117.6	0.950	2.790	65.6	34.9	1080	259	0.59	0.930	3.080
12.25	99.0	60.2	9.10	820	117.6	0.950	2.790	65.6	34.9	1260	253	0.59	0.930	3.080
13.25	99.6	60.6	9.22	826	117.6	0.950	2.790	65.6	34.9	1200	270	0.59	0.930	3.080
14.25	100.6	61.1	9.22	818	115.2	0.910	2.970	56.5	34.8	1160	239	0.36	0.940	3.060
15.25	100.2	60.9	9.55	851	115.2	0.910	2.970	56.5	34.8	1185	254	0.36	0.940	3.060
16.25	96.6	58.7	9.23	853	116.4	0.920	2.910	59.6	34.8	1155	279	0.36	0.940	3.060
17.25	96.2	58.5	9.20	854	116.4	0.920	2.910	59.6	34.8	1180	280	0.36	0.940	3.060
18.25	97.4	59.2	9.26	848	116.4	0.920	2.910	59.6	34.8	1375	271	0.36	0.940	3.060
19.25	99.8	60.7	9.24	827	116.4	0.920	2.910	59.6	34.8	1390	249	0.36	0.940	3.060
20.25	99.5	60.5	9.42	845	116.4	0.920	2.910	59.6	34.8	1300	226	0.36	0.940	3.060
21.25	95.7	58.2	9.55	890	116.4	0.920	2.910	59.6	34.8	1210	228	0.36	0.940	3.060
22.25	97.1	59.0	9.47	870	116.4	0.920	2.910	59.6	34.8	1305	218	0.36	0.940	3.060
23.25	97.2	59.1	9.38	862	116.4	0.920	2.910	59.6	34.8	1365	219	0.36	0.940	3.060
0.25	97.8	59.4	9.26	845	117.5	0.940	2.870	63.5	34.8	1380	188	0.36	0.940	3.060
1.25	97.6	59.3	9.36	857	117.5	0.940	2.870	63.5	34.8	1225	250	0.36	0.940	3.060
2.25	98.5	59.9	9.36	849	117.5	0.940	2.870	63.5	34.8	1225	247	0.36	0.940	3.060
3.25	98.3	59.8	9.24	839	117.5	0.940	2.870	63.5	34.8	1295	247	0.36	0.940	3.060
4.25	97.5	59.3	8.98	822	117.5	0.940	2.870	63.5	34.8	1335	260	0.36	0.940	3.060
5.25	99.7	60.6	9.15	820	117.5	0.940	2.870	63.5	34.8	1320	261	0.36	0.940	3.060
6.25	100.1	60.8	9.02	804	117.5	0.940	2.870	63.5	34.8	1270	247	0.36	0.940	3.060
7.25	100.1	60.9	9.06	808	117.5	0.940	2.870	63.5	34.8	1270	269	0.36	0.940	3.060

0.00 - 7.26

MAX	101.2	61.5	9.50	881.	117.5	0.940	2.870	63.5	34.8	1380.	280.	0.36	0.940	3.060		
MIN	95.3	58.0	8.92	795.	117.5	0.940	2.870	63.5	34.8	1225.	177.	0.36	0.940	3.060		
MEAN	98.5	59.9	9.19	834.	117.5	0.940	2.870	63.5	34.8	1295.	247.	0.36	0.940	3.060	0.00	7.45
ACCM	734.0	446.3	68.49	833.	117.5	0.940	2.870	63.5	34.8	1293.	247.	0.36	0.940	3.060	39.48	131.0

0.00 - 8.00

MAX	102.0	62.0	9.62	931.	119.3	0.960	2.970	67.5	35.0	1390.	340.	0.59	0.940	3.080		
MIN	85.1	51.8	8.24	755.	115.2	0.910	2.790	56.6	34.8	1070.	182.	0.36	0.930	3.060		
MEAN	98.4	59.8	9.10	827.	117.5	0.939	2.884	63.2	34.9	1262.	256.	0.49	0.934	3.072	5.56	24.02
ACCM	2361.6	1435.9	218.50	826.	117.4	0.939	2.883	63.2	34.9	1264.	256.	0.48	0.935	3.071	39.48	123.7

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ ID2 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCO EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	%	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	37.7	84	2.84	810	187	775	303	620	392	387	394	556	-0.18	838	
8.25	1.9	31.7	96	3.94	886	178	770	305	615	390	383	388	570	-0.15	844	
9.25	1.9	30.4	105	3.58	805	194	773	311	618	384	379	386	588	-0.18	851	
10.25	1.9	29.1	98	3.53	805	195	777	316	624	388	382	388	585	0.03	855	
11.25	1.9	28.1	110	3.06	804	219	779	331	622	389	382	387	601	0.02	856	
12.25	1.9	27.7	121	4.15	802	233	781	352	624	397	387	393	639	0.00	882	
13.25	1.9	27.5	132	3.74	804	235	772	354	617	380	373	380	623	-0.01	865	
14.25	1.9	24.0	136	2.90	803	252	770	379	617	380	373	381	649	0.00	883	
15.25	1.9	26.2	142	3.36	803	275	778	390	618	386	380	387	659	0.01	885	
16.25	1.9	26.6	151	3.80	803	248	780	375	632	397	390	397	638	0.00	883	
17.25	1.9	25.2	142	3.18	803	231	778	358	619	386	379	388	598	0.00	886	
18.25	1.9	21.3	155	3.78	801	254	781	378	627	391	381	389	648	-0.01	883	
19.25	1.9	18.2	133	2.99	805	237	779	339	614	377	370	380	594	-0.01	881	
20.25	1.9	18.4	122	3.54	803	223	777	365	620	387	378	386	626	0.00	877	
21.25	1.9	20.6	156	3.25	804	252	781	373	626	395	387	394	615	0.00	880	
22.25	1.9	23.5	149	2.86	805	249	783	360	630	393	384	393	607	0.00	884	
23.25	1.9	24.1	142	3.12	805	231	777	338	628	393	383	392	607	-0.01	881	
0.25	1.9	26.2	148	3.08	804	232	783	350	626	391	380	389	594	-0.02	877	
1.25	1.9	27.0	157	3.50	805	247	778	354	627	388	379	386	604	-0.01	876	
2.25	1.9	28.2	148	3.00	806	237	782	350	631	387	382	390	616	0.00	878	
3.25	1.9	30.0	147	3.01	805	244	779	328	619	384	379	384	581	-0.01	878	
4.25	1.9	28.3	131	3.18	807	224	782	330	626	388	381	389	588	-0.01	872	
5.25	1.9	27.8	136	3.28	805	232	783	361	630	394	386	393	631	-0.02	876	
6.25	2.0	29.5	147	3.45	804	236	780	338	623	390	385	389	605	-0.03	873	
7.25	1.9	27.7	131	3.90	804	225	779	337	625	392	388	391	607	-0.04	872	

0.00 - 7.28

MAX	2.0	30.7	166.	6.32	811.	273.	791.	385.	637.	398.	393.	397.	643.	0.01	885.
MIN	2.0	25.0	112.	1.83	797.	190.	773.	290.	614.	381.	374.	382.	572.	-0.09	858.
MEAN	2.0	28.3	142.	3.20	805.	231.	783.	350.	625.	390.	383.	390.	608.	-0.02	875.
ACCH	2.0	28.3	142.		805.	231.	783.	350.	625.	390.	383.	390.	608.	-0.02	875.

0.00 - 0.00

MAX	2.0	40.8	174.	4.78	812.	289.	791.	402.	646.	418.	412.	414.	670.	0.04	895.
MIN	1.8	17.1	71.	1.92	799.	181.	764.	272.	576.	374.	363.	377.	498.	-0.21	817.
MEAN	2.0	27.6	119.	3.29	805.	216.	778.	338.	622.	391.	383.	390.	597.	-0.07	862.
ACCH	2.0	27.6	119.		805.	216.	778.	338.	622.	391.	383.	390.	597.	-0.07	862.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ X02 KILN OUTL
 W1/ XCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1*		KALARM	ESTLTW	NOXST	NOXALT	A50ALT	A50T1	GA15X1	GA1X2CO	KM2F1				
	KCONTRL	LTWT	LTWT	LTWTGSP	NOXL	DEG.C	GA15X1		GA2V1						
	H	H	H	GR/L	GR/L	GR/L	%	%	%	%	T/H	RPM			
7.25				1295	1286	1289	36.9	36.0	-0.073	394	0.11	2.84	-0.18	9.13	838
8.25				1290	1246	1262	20.7	19.8	-0.689	388	0.13	3.94	-0.15	9.05	844
9.25				1070	1112	1626	15.2	14.5	-0.151	386	-0.05	3.58	-0.18	9.35	851
10.25				1080	1199	1188	27.9	29.6	0.230	388	-0.16	3.53	0.03	9.35	855
11.25				1080	1167	1162	25.5	24.9	-0.047	397	-0.04	3.06	0.02	9.26	856
12.25				1260	1179	1179	24.5	24.3	-0.159	393	0.41	4.15	0.00	9.10	882
13.25				1200	1184	1182	23.9	25.2	0.108	388	-0.19	3.74	-0.01	9.22	865
14.25				1160	1177	1174	24.7	24.3	0.219	381	0.11	2.90	0.00	9.22	883
15.25				1185	1111	1113	17.1	16.8	-0.293	387	0.17	3.36	0.01	9.55	885
16.25				1155	1179	1174	23.9	24.0	0.199	397	0.67	3.80	0.00	9.23	883
17.25				1180	1318	1316	39.2	39.6	0.411	388	0.16	3.18	0.00	9.20	886
18.25				1375	1323	1333	36.8	36.6	-0.187	389	0.35	3.78	-0.01	9.26	883
19.25				1390	1330	1302	34.3	34.4	-0.149	380	-0.92	2.99	-0.01	9.24	881
20.25				1300	1227	1231	26.1	25.9	-0.059	386	-0.58	3.54	0.00	9.42	877
21.25				1210	1320	1308	33.7	33.0	0.439	394	-0.13	3.25	0.00	9.55	880
22.25				1305	1404	1389	43.5	43.3	0.303	393	-0.42	2.86	0.00	9.47	884
23.25				1365	1468	1455	49.5	49.7	0.008	392	0.00	3.12	-0.01	9.38	881
0.25				1380	1363	1363	40.5	41.5	-0.356	389	-0.06	3.08	-0.02	9.26	877
1.25				1225	1336	1330	38.5	38.5	-0.066	386	-0.03	3.50	-0.01	9.36	876
2.25				1225	1366	1356	42.0	41.8	0.560	390	0.21	3.00	0.00	9.36	878
3.25				1295	1372	1377	49.1	48.3	-0.035	384	-0.11	3.01	-0.01	9.24	878
4.25				1335	1417	1418	56.5	55.9	0.588	389	0.12	3.18	-0.01	8.98	872
5.25				1320	1319	1319	41.5	39.8	-0.734	393	0.23	3.28	-0.02	9.15	876
6.25				1270	1344	1323	52.4	52.3	0.210	389	-0.58	3.45	-0.03	9.02	873
7.25				1270	1381	1280	43.6	44.8	-0.337	391	0.61	3.90	-0.04	9.06	872

0.00 - 7.29															
MAX				1380.	1447.	1442.	57.8	58.6	0.766	397.	0.97	6.32	0.01	9.50	885.
MIN				1225.	1258.	1256.	28.9	29.6	-0.842	382.	-0.71	1.83	-0.09	8.92	858.
MEAN	7.49	0.00		1295.	1362.	1363.	45.7	45.7	-0.008	390.	-0.01	3.20	-0.02	9.19	875.
ACCM	131.1	39.48		1293.		1363.			-0.000	390.	-0.01		-0.02	68.88	875.
0.00 - 0.00															
MAX				1390.	1487.	1826.	52.7	51.6	0.976	414.	3.18	4.78	0.04	9.62	895.
MIN				1070.	1110.	1071.	14.1	14.2	-0.853	377.	-1.72	1.92	-0.21	8.24	817.
MEAN	24.02	5.56		1262.	1269.	1342.	33.3	33.2	-0.010	390.	0.00	3.29	-0.07	9.10	862.
ACCM	123.7	39.48		1264.		1342.			-0.010	390.	0.00		-0.07	218.50	862.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL COAL HEAT VALUE
 Z MOISTURE IN COAL SHORT TONS CLINKER
 NET HEAT CONSUMP. LB COAL / SH. T
 HEAT CONSUMPTION MBTU' PER SH. T
 W1/ COAL TO KILN
 KILN PRODUC. RATE
 KILN PRODUCTION U1/ LITER WEIGHT
 W1/ KILN FEED COAL TO KILN

HOUR	HD10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS	RTU	LTWT
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z	T/H	T/H	LB. COAL	GR/L	H
7.25	98.7	60.0	1441	9.13	826	883	21.5	5.22	9134	65.1	0	28.20	1295
8.25	100.0	60.8	1459	9.05	809	866	21.5	5.22	9131	66.0	0	27.59	1290
9.25	99.4	60.4	1451	9.35	839	898	21.5	5.22	9131	65.6	0	28.74	1070
10.25	99.5	60.5	1453	9.35	838	897	21.5	5.22	9134	65.7	0	28.60	1080
11.25	100.3	61.0	1464	9.26	824	882	21.5	5.22	9134	66.2	0	28.16	1080
12.25	99.0	60.2	1446	9.10	820	877	21.5	5.22	9134	65.4	0	27.88	1260
13.25	99.6	60.6	1454	9.22	826	884	21.5	5.22	9134	65.7	0	28.08	1200
14.25	100.6	61.1	1468	9.22	818	875	20.5	6.27	9142	66.4	0	27.94	1160
15.25	100.2	60.9	1463	9.55	851	909	20.5	6.27	9142	66.1	0	29.22	1185
16.25	96.6	58.7	1410	9.23	853	912	20.5	6.27	9142	63.7	0	29.25	1155
17.25	96.2	58.5	1404	9.20	854	913	20.5	6.27	9142	63.5	0	29.23	1180
18.25	97.4	59.2	1422	9.26	848	907	20.5	6.27	9142	64.3	0	28.95	1375
19.25	99.8	60.7	1457	9.24	827	884	20.5	6.27	9142	65.9	0	28.26	1390
20.25	99.5	60.5	1452	9.42	845	904	20.5	6.27	9142	65.6	0	28.94	1300
21.25	95.7	58.2	1397	9.55	890	952	20.5	6.27	9142	63.2	0	30.43	1210
22.25	97.1	59.0	1418	9.47	870	930	20.5	6.27	9142	64.1	0	29.76	1305
23.25	97.2	59.1	1418	9.38	862	922	20.5	6.27	9142	64.1	0	29.50	1365
0.25	97.0	59.4	1427	9.26	845	903	20.5	6.27	9142	64.5	0	28.95	1380
1.25	97.6	59.3	1424	9.36	857	916	20.5	6.27	9139	64.4	0	29.36	1225
2.25	98.5	59.9	1438	9.36	849	907	20.5	6.27	9142	65.0	0	29.18	1225
3.25	98.3	59.8	1435	9.24	839	897	20.5	6.27	9142	64.9	0	28.73	1295
4.25	97.5	59.3	1423	8.98	822	878	20.5	6.27	9142	64.3	0	28.07	1335
5.25	99.7	60.6	1455	9.15	820	876	20.5	6.27	9142	65.8	0	28.61	1320
6.25	100.1	60.8	1461	9.02	804	860	20.5	6.27	9142	66.0	0	27.64	1270
7.25	100.1	60.9	1461	9.06	808	863	20.5	6.27	9142	66.1	0	27.58	1270

0.00 - 7.30													
MAX	101.2	61.5	1477.	9.50	881.	942.	20.5	6.27	9143.	66.8	0.	30.12	1380.
MIN	95.3	58.0	1392.	8.92	795.	850.	20.5	6.27	9140.	62.9	0.	27.20	1225.
MEAN	98.6	59.9	1438.	9.19	834.	891.	20.5	6.27	9143.	65.0	0.	28.50	1295. 7.51
ACCM	739.4	449.6		68.98	833.	891.	20.5	6.27			0.	28.50	1293. 131.1
0.00 - 0.00													
MAX	102.0	62.0	1489.	9.62	931.	996.	21.5	6.27	9143.	67.4	0.	31.81	1390.
MIN	85.1	51.8	1242.	8.24	755.	808.	20.5	5.22	9014.	56.2	0.	25.80	1070.
MEAN	98.4	59.8	1436.	9.10	827.	884.	21.1	5.68	9137.	64.9	0.	28.26	1262. 24.02
ACCM	2361.6	1435.9		218.50	826.	884.	21.1	5.68			0.	28.25	1264. 123.7

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED MS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-O-IG
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER MS
 KILN CONTROL
 COAL TO KILN

HOURL	HD10F1 PROD	KM2F1 T/H	KCAL T/H	BF KC/KG	KF-LS T/H	KF-MS T/H	C3S Z	KF-LOI Z	LTWT GR/L	KLO DEG.C	FCAO Z	CL-LS Z	CL-MS Z	KCONTRL H	KM2F1* H
7.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
8.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
9.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
10.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
11.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
12.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
13.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
14.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
15.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
16.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
17.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
18.25	0.0	0.0	0.00	0	0.0	0.000	0.000	0.0	0.0	0	0	0.00	0.000	0.000	
19.25	99.9	60.7	8.71	778	0.0	0.000	0.000	0.0	0.0	1355	276	0.00	0.000	0.000	
20.25	100.2	60.9	8.80	784	0.0	0.000	0.000	0.0	0.0	1325	288	0.00	0.000	0.000	
21.25	99.9	60.7	8.90	795	0.0	0.000	0.000	0.0	0.0	1285	288	0.00	0.000	0.000	
22.25	100.0	60.8	8.88	793	0.0	0.000	0.000	0.0	0.0	1290	278	0.00	0.000	0.000	
23.25	99.4	60.4	8.90	799	0.0	0.000	0.000	0.0	0.0	1265	291	0.00	0.000	0.000	
0.25	98.9	60.1	8.95	888	0.0	0.000	0.000	0.0	0.0	1285	304	0.00	0.000	0.000	
1.25	100.3	61.0	8.94	795	115.5	0.910	2.910	57.5	0.0	1265	276	0.00	0.000	0.000	
2.25	99.1	60.2	8.87	799	115.5	0.910	2.910	57.5	0.0	1310	271	0.00	0.000	0.000	
3.25	99.8	60.7	8.67	775	115.5	0.910	2.910	57.5	0.0	1310	291	0.00	0.000	0.000	
4.25	99.5	60.5	8.91	799	115.5	0.910	2.910	57.5	0.0	1295	265	0.00	0.000	0.000	
5.25	99.4	60.4	8.72	783	115.5	0.910	2.910	57.5	0.0	1300	274	0.00	0.000	0.000	
6.25	98.7	60.0	8.56	774	115.5	0.910	2.910	57.5	0.0	1300	298	0.00	0.000	0.000	
7.25	99.8	60.6	8.82	789	115.5	0.910	2.910	57.5	0.0	1285	305	0.00	0.000	0.000	

0.00 - 7.26

MAX	101.2	61.5	9.05	816.	115.5	0.910	2.910	57.6	0.0	1310.	316.	0.00	0.000	0.000	
MIN	97.1	59.0	8.38	749.	0.0	0.000	0.000	0.0	0.0	1265.	224.	0.00	0.000	0.000	
MEAN	99.7	60.6	8.81	789.	95.8	0.756	2.415	47.9	0.0	1294.	284.	0.00	0.000	0.000	5.30 7.45
ACCM	743.1	451.8	65.60	789.	99.0	0.780	2.494	49.3	0.0	1295.	284.	0.00	0.000	0.000	5.35 12.78

0.00 - 8.00

MAX	100.9	61.4	8.97	807.	0.0	0.000	0.000	0.0	0.0	1355.	312.	0.00	0.000	0.000	
MIN	40.9	28.6	3.63	770.	0.0	0.000	0.000	0.0	0.0	0.	116.	0.00	0.000	0.000	
MEAN	99.6	60.5	8.81	790.	0.0	0.000	0.000	0.0	0.0	1177.	285.	0.00	0.000	0.000	0.05 5.33
ACCM	530.8	322.8	46.96	790.	0.0	0.000	0.000	0.0	0.0	1987.	285.	0.00	0.000	0.000	0.05 5.33

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53	W1/ GAS TEMP A52
W1/ GAS TEMP A53	W1/ GAS TEMP A51
W1/ PRESSURE A54	W1/ GAS TEMP A61
W1/ TEMP CYCL A54	W1/ T EXIT PREHEAT
W1/ Z02 KILN OUTL	W1/ PRESS EX PREH
W1/ PRES EXIT KILN	
W1/ KILN TORQUE	W1/ ZCD EX PREHEAT
W1/ KILN ROT SPEED	J1/ ID FAN SPEED

HOUR	0A15V1	0A15P1	A54T1	A53T1	A52T1	A61T1	A50P1	0A1X2C0							
	0A15A1	0A15X1	A54P1	A53P1	A51T1	A50T1			0A2V1						
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
8.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
9.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
10.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
11.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
12.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
13.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
14.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
15.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
16.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
17.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
18.25	0.0	0.0	0	0.00	0	0	0	0	0	0	0	0	0.00	0	
19.25	1.9	32.8	138	4.29	809	208	798	359	631	389	380	388	619	-0.01	861
20.25	1.9	31.7	150	4.41	808	238	788	366	632	393	384	393	622	-0.02	864
21.25	1.9	30.7	125	3.67	811	211	791	351	639	394	384	394	614	-0.07	862
22.25	1.9	32.4	139	3.33	809	230	788	351	632	394	385	392	616	-0.02	865
23.25	1.9	32.3	135	2.89	802	212	779	357	624	387	379	388	611	-0.15	862
0.25	1.9	31.8	142	3.09	805	234	784	354	625	392	382	389	630	-0.17	871
1.25	1.9	32.8	158	2.36	806	251	785	366	627	390	382	388	633	-0.18	871
2.25	1.9	32.7	136	2.19	806	233	783	361	624	392	382	391	627	-0.05	871
3.25	1.9	32.1	146	2.91	805	234	783	359	631	391	384	389	628	-0.16	874
4.25	1.9	32.1	135	2.74	803	225	778	352	627	384	378	387	610	-0.09	879
5.25	1.9	32.3	133	3.45	805	236	784	371	625	392	385	391	638	-0.18	883
6.25	1.9	31.4	136	3.27	804	236	778	347	616	384	376	385	609	-0.18	874
7.25	1.9	28.4	126	1.91	805	213	780	327	610	376	369	376	573	-0.07	858

0.00 - 7.28															
MAX	2.0	34.1	168.	4.23	811.	273.	796.	389.	637.	398.	392.	396.	659.	-0.01	891.
MIN	2.0	28.1	113.	1.90	798.	184.	771.	303.	605.	371.	366.	374.	554.	-0.21	851.
MEAN	2.0	32.0	141.	2.84	805.	233.	783.	359.	625.	389.	381.	389.	623.	-0.16	875.
ACCM	2.0	32.0	141.		805.	233.	783.	359.	625.	389.	381.	389.	623.	-0.16	875.
0.00 - 0.00															
MAX	2.0	33.9	167.	5.05	813.	266.	799.	381.	641.	399.	391.	398.	640.	0.00	878.
MIN	1.9	13.3	117.	1.32	784.	194.	767.	334.	613.	380.	371.	359.	477.	-0.20	833.
MEAN	1.9	32.1	141.	3.85	808.	232.	788.	358.	631.	392.	383.	392.	619.	-0.05	866.
ACCM	1.9	32.1	141.		808.	232.	788.	358.	631.	392.	383.	392.	619.	-0.05	866.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCO EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1#		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1	
	KCONTRL	LTWT	LTWGTSP	NOXL	A50T1	OA15X1	OA1X2CD	OA2V1						
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	T/H	RPM

7.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
8.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
9.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
10.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
11.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
12.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
13.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
14.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
15.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
16.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
17.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
18.25				0	0	0	0.0	0.0	0.000	0	0.00	0.00	0.00	0.00	0	
19.25					1355	1561	724	52.0	66.0	3.715	388	0.13	4.29	-0.01	8.71	861
20.25					1325	1294	777	42.1	41.9	-0.500	393	0.07	4.41	-0.02	8.80	864
21.25					1285	1294	948	43.6	43.2	0.018	394	-0.02	3.67	-0.07	8.90	862
22.25					1290	1289	1289	42.4	42.6	-0.110	392	-0.06	3.33	-0.02	8.88	865
23.25					1265	1297	1297	46.3	46.4	0.305	388	-0.53	2.09	-0.15	8.90	862
0.25					1285	1279	1279	42.1	40.7	-0.184	389	0.16	3.09	-0.17	8.95	871
1.25					1265	1297	1172	47.3	46.4	0.145	388	0.13	2.36	-0.18	8.94	871
2.25					1310	1313	1312	51.3	51.1	0.133	391	-0.07	2.19	-0.05	8.87	871
3.25					1310	1316	1329	50.8	52.5	-0.073	389	0.16	2.91	-0.16	8.67	874
4.25					1295	1300	1299	48.4	48.3	0.107	387	0.27	2.74	-0.09	8.91	879
5.25					1300	1298	1298	48.1	47.7	-0.140	391	0.04	3.45	-0.18	8.72	883
6.25					1300	1285	1286	43.2	42.7	-0.071	385	-0.32	3.27	-0.18	8.56	874
7.25					1285	1274	1267	41.3	41.2	-0.030	376	-0.53	1.91	-0.07	8.82	858

0.00 - 7.29

MAX				1310.	1323.	1338.	54.1	54.3	0.215	396.	0.09	4.23	-0.01	9.05	891.
MIN				1265.	1274.	1150.	40.2	40.6	-0.437	374.	-0.66	1.90	-0.21	8.38	851.
MEAN	7.50	5.34		1294.	1297.	1264.	46.7	46.7	-0.014	389.	-0.05	2.84	-0.16	8.81	875.
ACCH	12.82	5.40		1295.		1264.			-0.014	389.	-0.05		-0.16	65.98	875.

0.00 - 0.00

MAX				1355.	1564.	1299.	63.9	66.4	3.856	398.	49.46	5.05	0.00	8.97	878.
MIN				0.	0.	0.	0.0	0.0	-0.509	359.	-0.67	1.32	-0.20	3.63	833.
MEAN	5.33	0.05		1177.	1265.	922.	42.9	42.9	0.279	392.	0.68	3.85	-0.05	8.81	866.
ACCH	5.33	0.05		1087.		922.			0.279	392.	0.68		-0.05	46.96	866.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL

Z MOISTURE IN COAL

NET HEAT CONSUMP.

HEAT CONSUMPTION

W1/ COAL TO KILN

KILN PRODUC. RATE

KILN PRODUCTION

W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER

LB COAL / SH. T

KBTU/ PER SH. T

W1/ LITER WEIGHT

COAL TO KILN

HOUR	H010F1		PRODR	KCAL		C-MOIST		C-HEAT	STONS	BTU		LTWT	
	PROD		KN2F1	MKCAL		C-ASH			LB. COAL			KN2F1*	
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z	T/H			GR/L	H
7.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
8.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
9.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
10.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
11.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
12.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
13.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
14.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
15.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
16.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
17.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
18.25	0.0	0.0	0	0.00	0	0	0.0	0.00	0	0.0	0	0.00	0
19.25	99.9	60.7	1459	8.71	778	689	0.0	0.00	12490	65.9	0	36.59	1355
20.25	100.2	60.9	1462	8.80	784	614	0.0	0.00	12490	66.1	0	36.84	1325
21.25	99.9	60.7	1458	8.90	795	622	0.0	0.00	12490	65.9	0	37.03	1285
22.25	100.0	60.8	1459	8.88	793	621	0.0	0.00	12490	66.0	0	37.04	1290
23.25	99.4	60.4	1450	8.90	799	625	0.0	0.00	12490	65.6	0	37.33	1265
0.25	98.9	60.1	1444	8.95	808	632	0.0	0.00	12490	65.3	0	37.60	1285
1.25	100.3	61.0	1464	8.94	795	622	0.0	0.00	12490	66.2	0	37.38	1265
2.25	99.1	60.2	1446	8.87	799	625	0.0	0.00	12490	65.4	0	37.76	1310
3.25	99.8	60.7	1457	8.67	775	607	0.0	0.00	12490	65.9	0	36.26	1310
4.25	99.5	60.5	1453	8.91	799	626	0.0	0.00	12490	65.7	0	37.38	1295
5.25	99.4	60.4	1451	8.72	783	613	0.0	0.00	12490	65.6	0	36.47	1300
6.25	98.7	60.0	1440	8.56	774	606	0.0	0.00	12490	65.1	0	36.14	1300
7.25	99.8	60.6	1456	8.82	789	618	0.0	0.00	12490	65.8	0	36.85	1285

0.00 - 7.31

MAX	101.2	61.5	1476.	9.05	816.	638.	0.0	0.00	12490.	66.8	0.	38.11	1310.
MIN	97.1	59.8	1417.	8.38	749.	586.	0.0	0.00	12487.	64.1	0.	34.98	1265.
MEAN	99.7	60.6	1456.	8.81	789.	617.	0.0	0.00	12490.	65.8	0.	36.84	1294. 7.53
ACCH	750.3	456.2		66.24	789.	617.	0.0	0.00			0.	36.84	1295. 12.85

0.00 - 0.00

MAX	100.9	61.4	1473.	8.97	807.*****		0.0	0.00	12490.	66.6	0.	37.72	1355.
MIN	40.9	28.6	686.	3.63	770.	683.	0.0	0.00	12487.	31.0	0.	0.00	0.
MEAN	99.6	60.5	1453.	8.81	790.*****		0.0	0.00	12490.	65.7	0.	36.91	1177. 5.33
ACCH	530.8	322.8		46.96	790.	619.	0.0	0.00			0.	36.90	1087. 5.33

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S
 W1/ KILN FEED NS
 W1/ KILN FEED LSF
 W1/ BURNING FACTOR
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUCTION
 W1/ KILN FEED

W1/ FEED LOSS-0-1G
 U1/ LITER WEIGHT
 U1/ CLINKER TEMP
 U1/ FREE LIME
 U1/ CLINKER LSF
 U1/ CLINKER NS
 KILN CONTROL
 COAL TO KILN

HOUR	HO10F1	KN2F1	BF	KF-NS	KF-LOT	KLO	CL-LS	KCONTRL						
	PROD	KCAL	KF-LS	C3S	LTWT	FCAO	CL-MS	KN2F1*						
	T/H	T/H	T/H	KC/KG	%	%	GR/L	DEG.C	%	H	H			
7.25	99.5	60.5	8.68	779	115.5	0.910	2.910	57.5	0.0	1300	312	0.00	0.000	0.000
8.25	99.5	60.5	8.93	801	115.5	0.910	2.910	57.5	0.0	1285	292	0.00	0.000	0.000
9.25	99.6	60.6	9.10	815	119.1	0.960	2.820	68.7	0.0	1290	309	0.00	0.000	0.000
10.25	99.2	60.3	9.07	816	119.1	0.960	2.820	68.7	0.0	1240	261	0.00	0.000	0.000
11.25	99.9	60.7	8.79	786	119.1	0.960	2.820	68.7	0.0	1345	289	0.00	0.000	0.000
12.25	99.6	60.5	8.93	801	119.1	0.960	2.820	68.7	0.0	1355	284	0.00	0.000	0.000
13.25	99.5	60.5	9.02	809	114.1	0.900	2.890	53.3	34.8	1200	301	0.36	0.950	3.000
14.25	99.4	60.4	9.06	814	114.1	0.900	2.890	53.3	34.8	1120	308	0.36	0.950	3.000
15.25	96.3	58.5	9.06	840	120.7	0.970	2.880	71.5	34.8	1240	263	0.36	0.950	3.000
16.25	95.6	58.1	8.91	832	120.7	0.970	2.880	71.5	34.8	1270	271	0.36	0.950	3.000
17.25	96.6	58.7	8.94	826	120.7	0.970	2.880	71.5	34.8	1310	289	0.36	0.950	3.000
18.25	95.8	58.2	9.13	851	120.7	0.970	2.880	71.5	34.8	1300	294	0.36	0.950	3.000
19.25	95.7	58.2	9.28	866	120.7	0.970	2.880	71.5	34.8	1300	292	0.36	0.950	3.000
20.25	95.9	58.3	9.33	868	120.7	0.970	2.880	71.5	34.8	1250	277	0.36	0.950	3.000
21.25	98.9	60.1	9.32	841	120.7	0.970	2.880	71.5	34.8	1350	277	0.36	0.950	3.000
22.25	96.3	58.6	9.32	863	120.7	0.970	2.880	71.5	34.8	1240	262	0.36	0.950	3.000
23.25	95.4	58.0	9.26	867	120.7	0.970	2.880	71.5	34.8	1295	253	0.36	0.950	3.000
0.25	96.3	58.5	9.30	862	119.5	0.960	2.860	67.9	34.8	1355	276	0.36	0.950	3.000
1.25	95.4	58.0	8.97	839	119.5	0.960	2.860	67.9	34.8	1385	265	0.36	0.950	3.000
2.25	99.0	60.2	9.05	816	119.5	0.960	2.860	67.9	34.8	1405	256	0.36	0.950	3.000
3.25	97.5	59.3	9.49	868	119.5	0.960	2.860	67.9	34.8	1225	264	0.36	0.950	3.000
4.25	97.5	59.2	9.35	857	119.5	0.960	2.860	67.9	34.8	1215	243	0.36	0.950	3.000
5.25	97.0	58.9	8.99	828	119.5	0.960	2.860	67.9	34.8	1345	260	0.36	0.950	3.000
6.25	97.3	59.1	9.02	827	119.5	0.960	2.860	67.9	34.8	1350	272	0.36	0.950	3.000
7.25	97.0	59.0	9.55	879	119.5	0.960	2.860	67.9	34.8	1190	270	0.36	0.950	3.000

0.00 - 7.27														
MAX	101.0	61.4	9.74	895.	119.5	0.960	2.860	67.9	34.9	1405.	293.	0.36	0.950	3.000
MIN	94.8	57.6	8.71	781.	119.5	0.960	2.860	67.9	34.9	1190.	206.	0.36	0.950	3.000
MEAN	97.4	59.2	9.16	840.	119.5	0.960	2.860	67.9	34.9	1321.	265.	0.36	0.950	3.000 7.18 7.46
ACCM	726.6	441.7	68.32	840.	119.5	0.960	2.860	67.9	34.9	1321.	265.	0.36	0.950	3.000 14.19 36.83
0.00 - 0.00														
MAX	101.3	61.6	9.42	883.	120.7	0.970	2.910	71.6	34.9	1355.	320.	0.36	0.950	3.000
MIN	94.6	57.5	8.38	749.	0.0	0.000	0.000	0.0	0.0	1120.	207.	0.00	0.000	0.000
MEAN	98.6	59.9	8.99	815.	111.8	0.892	2.729	61.1	16.1	1280.	283.	0.17	0.438	1.382 6.96 24.02
ACCM	2365.3	1438.1	215.77	815.	113.0	0.901	2.759	61.6	17.4	1280.	283.	0.18	0.475	1.500 7.02 29.36

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3 KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ ZD2 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCO EX PREHEAT
 J1/ ID FAN SPEED

HOUR	0A15V1		0A15P1		A54T1		A53T1		A52T1		A61T1		A50P1		0A1X2CO	
	RPM	Z	MMWG	Z	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	Z	RPM	
7.25	1.9	28.6	132	2.39	802	226	779	356	616	377	373	380	599	-0.18	859	
8.25	1.9	30.2	134	3.60	807	240	785	360	629	393	384	388	634	-0.17	877	
9.25	1.9	30.4	133	3.69	808	229	791	356	635	396	390	397	638	-0.17	878	
10.25	1.9	33.4	130	3.14	807	215	783	354	631	393	387	393	620	-0.16	877	
11.25	1.9	32.2	132	3.25	806	229	790	356	629	393	387	393	645	-0.16	876	
12.25	1.9	31.1	130	3.62	805	221	786	348	636	393	388	397	638	-0.12	876	
13.25	1.9	31.8	133	3.37	805	231	787	355	637	395	388	396	631	-0.17	879	
14.25	1.9	29.3	135	3.28	806	235	789	356	636	396	387	396	628	-0.09	876	
15.25	1.9	31.8	130	3.38	805	209	782	358	628	393	386	392	627	-0.15	877	
16.25	1.9	33.2	133	3.14	805	212	782	354	629	390	384	391	612	-0.15	861	
17.25	1.9	31.6	134	3.39	804	217	779	339	623	392	383	390	578	-0.17	863	
18.25	1.9	29.9	128	3.84	804	214	784	358	626	393	385	391	611	-0.18	862	
19.25	1.9	31.2	147	3.45	804	231	783	353	629	392	384	394	619	-0.17	863	
20.25	1.9	30.5	122	3.13	808	208	789	354	630	394	389	394	683	-0.17	866	
21.25	1.9	31.1	136	3.85	805	229	782	355	628	392	383	391	635	-0.18	870	
22.25	1.9	30.4	130	3.21	809	228	787	359	634	396	389	396	620	-0.18	865	
23.25	1.9	33.4	121	2.92	810	194	788	370	637	396	386	396	618	-0.19	869	
0.25	1.9	32.6	125	2.84	810	232	790	361	636	394	386	394	618	-0.17	869	
1.25	1.9	30.9	121	3.26	809	212	790	356	630	398	390	395	615	-0.17	866	
2.25	1.9	30.2	120	4.87	805	223	784	320	628	392	385	391	621	-0.17	866	
3.25	1.9	28.8	132	2.37	809	232	787	355	636	396	389	394	632	-0.17	870	
4.25	1.9	33.2	132	2.19	809	229	783	361	633	394	387	393	636	-0.17	872	
5.25	1.9	32.7	125	3.24	810	239	786	366	628	394	386	392	648	-0.19	873	
6.25	1.9	30.9	129	3.82	807	228	786	315	634	393	386	394	615	-0.17	857	
7.25	1.9	29.4	118	3.43	808	220	788	274	633	391	385	392	615	-0.18	860	

0.00 - 7.28

MAX	2.0	33.6	140.	4.64	813.	270.	794.	398.	642.	403.	394.	400.	658.	-0.07	887.
MIN	2.0	28.3	110.	1.57	804.	188.	775.	263.	621.	386.	380.	387.	597.	-0.21	854.
MEAN	2.0	31.0	128.	3.21	809.	225.	786.	352.	633.	394.	387.	394.	628.	-0.18	869.
ACCM	2.0	31.0	128.		809.	225.	786.	352.	633.	394.	387.	394.	628.	-0.18	869.

0.00 - 0.00

MAX	2.0	34.1	168.	4.49	813.	273.	798.	389.	645.	402.	394.	400.	659.	-0.01	891.
MIN	2.0	27.8	105.	1.47	798.	170.	757.	287.	685.	370.	365.	373.	554.	-0.21	850.
MEAN	2.0	31.6	134.	3.15	806.	228.	785.	354.	629.	392.	384.	392.	621.	-0.15	872.
ACCM	2.0	31.6	134.		806.	228.	785.	354.	629.	392.	384.	392.	621.	-0.15	872.

PLANT REPORT 3 KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ X02 KILN OUTL
 W1/ XCD EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1#			KALARM			ESTLTW			NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL			LTWT	LTWGTSP	NOXLT	A50T1	OA15X1	OA1X2CO	OA2V1								
	H	H	H	GR/L	GR/L	GR/L	%	%	%	DEG.C	%	%	%	T/H	RPM			
7.25				1300	1281	1282	42.1	41.4	-0.099	388	-0.19	2.39	-0.18	8.68	859			
8.25				1285	1262	1262	36.3	38.1	-0.219	388	1.03	3.60	-0.17	8.93	877			
9.25				1290	1273	1272	32.3	31.2	-0.298	397	0.27	3.69	-0.17	9.10	878			
10.25				1240	1285	1276	43.7	43.7	0.480	393	-0.04	3.14	-0.16	9.07	877			
11.25				1345	1309	1518	48.9	50.2	0.383	393	-0.16	3.25	-0.16	8.79	876			
12.25				1355	1264	1307	33.5	31.9	-0.322	397	-0.07	3.62	-0.12	8.93	876			
13.25				1200	1209	1643	28.2	27.5	-0.203	396	0.00	3.37	-0.17	9.02	879			
14.25				1120	1240	1729	33.9	36.2	0.279	396	0.81	3.28	-0.09	9.06	876			
15.25				1240	1240	1240	36.5	35.7	-0.199	392	0.64	3.38	-0.15	9.06	877			
16.25				1270	1326	1303	43.3	44.1	0.219	391	0.13	3.14	-0.15	8.91	861			
17.25				1310	1268	1272	38.3	38.2	-0.249	390	0.16	3.39	-0.17	8.94	863			
18.25				1300	1252	1257	37.6	37.4	-0.047	391	0.83	3.84	-0.18	9.13	862			
19.25				1300	1247	1248	36.8	36.4	0.181	394	-0.03	3.45	-0.17	9.28	863			
20.25				1250	1306	1303	43.1	42.0	0.153	394	0.86	3.13	-0.17	9.33	866			
21.25				1350	1188	1198	33.5	31.5	-0.623	391	-0.12	3.85	-0.18	9.32	870			
22.25				1240	1330	1310	43.4	43.4	0.489	396	0.86	3.21	-0.18	9.32	865			
23.25				1295	1343	1338	48.0	47.9	0.293	396	-0.28	2.92	-0.19	9.26	869			
0.25				1355	1379	1375	52.7	53.3	0.280	394	0.86	2.84	-0.17	9.30	869			
1.25				1385	1372	1373	51.5	51.6	-0.184	395	0.00	3.26	-0.17	8.97	866			
2.25				1405	1255	1268	34.5	34.4	-0.547	391	-0.25	4.07	-0.17	9.05	866			
3.25				1225	1275	1783	38.9	38.2	0.255	394	0.63	2.37	-0.17	9.49	870			
4.25				1215	1361	1287	50.4	49.1	0.450	393	-0.18	2.19	-0.17	9.35	872			
5.25				1345	1359	1352	48.5	48.9	-0.381	392	0.05	3.24	-0.19	8.99	873			
6.25				1350	1286	1220	33.7	31.4	-0.475	394	-0.33	3.82	-0.17	9.02	857			
7.25				1190	1193	1192	31.9	33.1	-0.018	392	-0.04	3.43	-0.18	9.55	860			

0.00 - 7.29															
MAX				1405.	1412.	1864.	54.3	55.0	0.567	400.	0.63	4.64	-0.07	9.74	887.
MIN				1190.	1184.	1185.	31.8	31.1	-0.800	387.	-0.48	1.57	-0.21	8.71	854.
MEAN	7.50	7.22		1320.	1308.	1372.	42.9	43.0	-0.067	394.	-0.01	3.22	-0.18	9.16	869.
ACCH	36.88	14.23		1321.		1372.			-0.067	394.	-0.01		-0.18	68.73	869.
0.00 - 0.00															
MAX				1355.	1360.	1806.	54.1	54.3	0.520	400.	1.03	4.49	-0.01	9.42	891.
MIN				1120.	1173.	1150.	28.0	27.5	-0.805	373.	-0.94	1.47	-0.21	8.38	850.
MEAN	24.02	6.96		1280.	1281.	1328.	41.2	41.2	0.002	392.	0.01	3.15	-0.15	8.99	872.
ACCH	29.36	7.02		1280.		1328.			0.002	392.	0.01		-0.15	215.77	872.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL COAL HEAT VALUE
 Z MOISTURE IN COAL
 NET HEAT CONSUMP. SHORT TONS CLINKER
 HEAT CONSUMPTION LB COAL / SH. T
 W1/ COAL TO KILN MBTU' PER SH. T
 KILN PRODUC. RATE
 KILN PRODUCTION U1/ LITER WEIGHT
 W1/ KILN FEED COAL TO KILN

HOUR	HD10F1	PRODR	KCAL	C-MOIST	C-HEAT	STONS	BTU	LTWT				
	PROD	KM2F1	NKCAL	C-ASH		LB. COAL		KM2F1*				
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z	T/H	GR/L	H	
7.25	99.5	60.5	1453	8.68	779	689	0.0	0.00	12498	65.7	0 36.62	1300
8.25	99.5	60.5	1453	8.93	801	627	0.0	0.00	12490	65.7	0 37.63	1285
9.25	99.6	60.6	1454	9.10	815	638	0.0	0.00	12490	65.7	0 38.05	1290
10.25	99.2	60.3	1447	9.07	816	639	0.0	0.00	12490	65.4	0 38.13	1240
11.25	99.9	60.7	1457	8.79	786	615	0.0	0.00	12490	65.9	0 36.74	1345
12.25	99.6	60.5	1453	8.93	801	627	0.0	0.00	12490	65.7	0 37.39	1355
13.25	99.5	60.5	1453	9.02	809	848	19.9	5.34	9325	65.7	0 28.06	1200
14.25	99.4	60.4	1451	9.06	814	853	19.9	5.34	9325	65.6	0 28.39	1120
15.25	96.3	58.5	1406	9.06	840	880	19.9	5.34	9325	63.6	0 29.32	1240
16.25	95.6	58.1	1395	8.91	832	872	19.9	5.34	9325	63.1	0 29.07	1270
17.25	96.6	58.7	1410	8.94	826	866	19.9	5.34	9325	63.7	0 28.75	1310
18.25	95.8	58.2	1398	9.13	851	892	19.9	5.34	9325	63.2	0 29.63	1300
19.25	95.7	58.2	1397	9.28	866	907	19.9	5.34	9325	63.2	0 30.16	1300
20.25	95.9	58.3	1400	9.33	868	910	19.9	5.34	9325	63.3	0 30.40	1250
21.25	98.9	60.1	1443	9.32	841	882	19.9	5.34	9325	65.2	0 29.39	1350
22.25	96.3	58.6	1406	9.32	863	905	19.9	5.34	9325	63.6	0 30.20	1240
23.25	95.4	58.0	1392	9.26	867	908	19.9	5.34	9325	62.9	0 30.21	1295
0.25	96.3	58.5	1406	9.30	862	903	19.9	5.34	9322	63.5	0 30.28	1355
1.25	95.4	58.0	1393	8.97	839	880	19.9	5.34	9325	63.0	0 29.34	1385
2.25	99.0	60.2	1445	9.05	816	855	19.9	5.34	9325	65.3	0 28.36	1405
3.25	97.5	59.3	1423	9.49	868	910	19.9	5.34	9325	64.4	0 30.50	1225
4.25	97.5	59.2	1422	9.35	857	898	19.9	5.34	9325	64.3	0 29.71	1215
5.25	97.0	58.9	1415	8.99	820	868	19.9	5.34	9325	64.0	0 28.72	1345
6.25	97.3	59.1	1420	9.02	827	867	19.9	5.34	9325	64.2	0 28.81	1350
7.25	97.0	59.0	1416	9.55	879	921	19.9	5.34	9325	64.0	0 30.54	1190

0.00 - 7.30												
MAX	101.0	61.4	1473.	9.74	895.	938.	19.9	5.34	9326.	66.6	0. 31.23	1405.
MIN	94.8	57.6	1383.	8.71	781.	818.	19.9	5.34	9323.	62.6	0. 27.24	1190.
MEAN	97.4	59.2	1422.	9.16	840.	881.	19.9	5.34	9326.	64.3	0. 29.31	1320. 7.51
ACCM	731.9	444.9		68.83	840.	881.	19.9	5.34			0. 29.31	1321. 36.89
0.00 - 0.00												
MAX	101.3	61.6	1478.	9.42	883.	925.	19.9	5.34	12490.	66.9	0. 38.94	1355.
MIN	94.6	57.5	1381.	8.38	749.	586.	0.0	0.00	9323.	62.5	0. 27.28	1120.
MEAN	98.6	59.9	1438.	8.99	815.	741.	9.2	2.46	11030.	65.0	0. 33.51	1280. 24.02
ACCM	2365.3	1438.1		215.77	815.	722.	9.2	2.46			0. 33.63	1280. 29.36

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

W1/ KILN FEED C3S	W1/ FEED LOSS-O-IG
W1/ KILN FEED MS	U1/ LITER WEIGHT
W1/ KILN FEED LSF	U1/ CLINKER TEMP
W1/ BURNING FACTOR	U1/ FREE LIME
HEAT CONSUMPTION	U1/ CLINKER LSF
W1/ COAL TO KILN	U1/ CLINKER MS
KILN PRODUCTION	KILN CONTROL
W1/ KILN FEED	COAL TO KILN

HOUR	HD10F1		KM2F1		BF	KF-MS		KF-LOI		KLO	CL-LS		KCONTRL	
	PROD		KCAL	KF-LS		C3S	LTWT	FCAO	CL-MS		KM2F1*			
	T/H	T/H										T/H	KC/KG	Z
7.25	96.7	58.8	9.12	842	119.5	0.960	2.860	67.9	34.8	1350	283	0.36	0.950	3.000
8.25	97.4	59.2	9.70	889	119.5	0.960	2.860	67.9	34.8	1230	247	0.36	0.950	3.000
9.25	99.8	60.7	9.62	861	117.9	0.940	2.900	63.8	34.8	1290	242	0.36	0.950	3.000
10.25	99.3	60.4	9.81	882	117.9	0.940	2.900	63.8	34.8	1275	258	0.36	0.950	3.000
11.25	99.9	60.7	9.63	860	117.9	0.940	2.900	63.8	34.8	1280	251	0.36	0.950	3.000
12.25	--	--	--	--	117.9	0.940	2.900	63.8	34.8	1350	--	0.36	0.950	3.000
13.25	93.3	56.7	9.74	932	117.9	0.940	2.900	63.8	34.8	1350	193	0.36	0.950	3.000
14.25	93.4	56.7	9.76	934	117.3	0.940	2.880	62.4	35.1	1135	227	0.24	0.960	3.020
15.25	97.7	59.4	9.84	899	117.3	0.940	2.880	62.4	35.1	1290	230	0.24	0.960	3.020
16.25	100.1	60.8	9.79	873	117.3	0.940	2.880	62.4	35.1	1330	254	0.24	0.960	3.020
17.25	100.5	61.1	9.65	857	122.1	0.980	2.910	73.4	35.1	1375	285	0.24	0.960	3.020
18.25	100.4	61.0	9.71	864	122.1	0.980	2.910	73.4	35.1	1330	272	0.24	0.960	3.020
19.25	100.7	61.2	10.00	886	122.1	0.980	2.910	73.4	35.1	1280	285	0.24	0.960	3.020
20.25	99.9	60.7	9.98	892	122.1	0.980	2.910	73.4	35.1	1150	246	0.24	0.960	3.020
21.25	99.3	60.3	9.97	897	122.1	0.980	2.910	73.4	35.1	1245	261	0.24	0.960	3.020
22.25	99.3	60.4	10.01	900	122.1	0.980	2.910	73.4	35.1	1265	271	0.24	0.960	3.020
23.25	99.1	60.2	10.02	903	124.4	1.010	2.840	79.5	35.1	1275	270	0.24	0.960	3.020
0.25	99.2	60.3	9.94	895	124.4	1.010	2.840	79.5	35.1	1315	261	0.24	0.960	3.020
1.25	99.2	60.3	9.74	877	124.4	1.010	2.840	79.5	35.1	1285	270	0.24	0.960	3.020
2.25	99.1	60.2	10.06	907	124.4	1.010	2.840	79.5	35.1	1285	280	0.24	0.960	3.020
3.25	99.9	60.7	9.95	889	124.4	1.010	2.840	79.5	35.1	1215	263	0.24	0.960	3.020
4.25	99.5	60.4	10.10	907	124.4	1.010	2.840	79.5	35.1	1280	279	0.24	0.960	3.020
5.25	98.7	60.0	9.99	904	124.4	1.010	2.840	79.5	35.1	1255	263	0.24	0.960	3.020
6.25	99.4	60.4	9.72	873	124.4	1.010	2.840	79.5	35.1	1340	274	0.24	0.960	3.020
7.25	91.0	55.3	10.38	1019	124.4	1.010	2.840	79.5	35.1	1240	270	0.24	0.960	3.020

0.00 - 7.27														
MAX	100.9	61.3	10.44	1023.	124.4	1.010	2.840	79.5	35.2	1340.	299.	0.24	0.960	3.020
MIN	90.4	55.0	9.57	855.	124.4	1.010	2.840	79.5	35.2	1215.	233.	0.24	0.960	3.020
MEAN	99.0	60.2	9.96	899.	124.4	1.010	2.840	79.5	35.2	1282.	271.	0.24	0.960	3.020 6.87 7.46
ACCH	738.1	448.7	74.29	899.	124.4	1.010	2.840	79.5	35.2	1286.	271.	0.24	0.960	3.020 26.11 60.52
0.00 - 8.00														
MAX	101.7	61.8	10.13	9104.	124.4	1.010	2.910	79.5	35.2	1405.	306.	0.36	0.960	3.020
MIN	-4.7	-2.9	1.43	769987	117.3	0.940	2.840	62.4	34.9	1135.	140.	0.24	0.950	3.000
MEAN	97.5	59.2	9.52	827.	119.7	0.960	2.883	68.3	35.0	1291.	258.	0.31	0.955	3.010 12.20 23.64
ACCH	2303.2	1399.2	224.98	873.	119.9	0.961	2.885	68.5	35.0	1297.	258.	0.30	0.955	3.009 19.22 53.04

PLANT REPORT 1

KILN PRODUCTION REPORT

PLANT REPORT

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

W1/ PRESSURE A53
 W1/ GAS TEMP A53
 W1/ PRESSURE A54
 W1/ TEMP CYCL A54
 W1/ Z02 KILN OUTL
 W1/ PRES EXIT KILN
 W1/ KILN TORQUE
 W1/ KILN ROT SPEED

W1/ GAS TEMP A52
 W1/ GAS TEMP A51
 W1/ GAS TEMP A61
 W1/ T EXIT PREHEAT
 W1/ PRESS EX PREH
 W1/ ZCD EX PREHEAT
 J1/ ID FAN SPEED

HOUR	DA15V1		DA15P1		A54T1		A53T1		A52T1		A61T1		A50P1		DA1X2CD	
	RPM	%	MMWG	%	DEG.C	MMWG	DEG.C	MMWG	DEG.C	DEG.C	DEG.C	DEG.C	MMWG	%	RPM	
7.25	1.9	29.3	123	3.85	806	214	789	358	628	393	388	393	621	-0.18	856	
8.25	1.9	31.1	113	3.46	813	191	790	343	638	394	386	393	614	-0.16	860	
9.25	1.9	33.8	125	3.61	812	229	787	358	636	395	388	394	644	-0.18	879	
10.25	1.9	33.5	122	3.05	813	207	794	356	635	395	386	393	634	-0.18	875	
11.25	1.9	34.2	129	3.52	812	238	789	358	636	394	386	392	646	-0.18	884	
12.25	--	--	--	--	--	--	--	--	--	--	--	372	--	--	--	
13.25	1.9	28.8	119	3.31	807	214	785	265	635	396	391	396	566	-0.01	845	
14.25	1.9	29.2	127	3.80	810	210	793	336	640	396	391	398	612	-0.04	868	
15.25	1.9	31.6	122	2.62	811	225	783	355	636	394	387	395	623	-0.04	870	
16.25	1.9	33.8	119	2.20	810	223	788	364	631	387	384	387	642	-0.07	875	
17.25	1.9	33.3	143	2.79	809	244	787	351	626	387	380	384	628	-0.18	878	
18.25	1.9	31.6	118	5.22	884	207	783	380	629	386	382	387	645	-0.18	877	
19.25	1.9	28.1	135	2.74	807	217	784	352	626	386	383	387	640	-0.18	880	
20.25	1.9	31.8	124	2.59	810	208	790	380	631	386	379	386	638	-0.16	878	
21.25	1.9	34.2	125	2.83	810	220	789	326	637	392	384	388	646	-0.17	879	
22.25	1.9	32.9	150	2.58	811	242	789	353	631	385	381	387	640	-0.18	879	
23.25	1.9	33.3	129	3.36	813	220	792	349	629	391	386	390	640	-0.18	883	
0.25	1.9	34.4	147	3.66	813	233	787	344	630	391	385	389	644	-0.17	867	
1.25	1.9	33.3	121	4.34	812	222	791	380	629	393	385	390	632	-0.18	877	
2.25	1.9	31.1	145	3.42	814	252	789	343	631	389	384	390	634	-0.18	873	
3.25	1.9	34.8	142	3.36	811	215	787	359	629	387	385	389	637	-0.17	873	
4.25	1.9	34.0	146	3.86	815	235	793	350	630	389	385	390	638	-0.18	873	
5.25	1.9	35.1	133	3.59	815	222	789	354	635	391	384	390	636	-0.17	874	
6.25	1.9	36.6	154	2.96	814	241	791	361	627	391	387	390	646	-0.18	874	
7.25	1.9	31.3	111	4.86	811	286	793	337	644	396	394	398	607	-0.16	864	

0.00 - 7.28

MAX	2.0	39.1	164.	5.30	819.	268.	800.	374.	647.	403.	398.	399.	654.	-0.12	887.
MIN	1.9	30.6	100.	2.44	807.	182.	780.	252.	623.	385.	379.	385.	585.	-0.21	861.
MEAN	2.0	33.9	133.	3.44	813.	224.	790.	346.	633.	391.	386.	391.	631.	-0.18	875.
ACCM	2.0	33.9	133.		813.	224.	790.	346.	633.	391.	386.	391.	631.	-0.18	875.

0.00 - 8.00

MAX	2.0	36.3	160.	10.50	817.	270.	799.	398.	665.	438.	436.	427.	659.	1.38	890.
MIN	0.4	0.1	-10.	0.04	771.	0.	745.	-20.	593.	365.	363.	367.	-40.	-0.21	476.
MEAN	2.0	31.6	126.	3.08	810.	222.	787.	344.	631.	392.	386.	392.	622.	-0.16	868.
ACCM	2.0	31.6	126.		810.	222.	787.	344.	631.	392.	386.	392.	622.	-0.16	868.

PLANT REPORT 3

KILN / PREHEATER

PLANT REPORT

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

W1/ NOX REG LTIME
 W1/ NOX REG STIME
 W1/ LTW FOR CONTRL
 W1/ ESTIMATED LTW
 U1/ LITER WEIGHT
 KILN CON. MEASUR.
 KILN CONTROL
 COAL TO KILN

W1/ NOX CHANGE LT
 W1/ T EXIT PREHEAT
 W1/ A50T1 CHANGE
 W1/ Z02 KILN OUTL
 W1/ ZCD EX PREHEAT
 W1/ COAL TO KILN
 J1/ ID FAN SPEED

HOUR	KM2F1%		KALARM		ESTLTW		NOXST		NOXALT		A50ALT		KM2F1		
	KCONTRL	LTWT	LTWGTSP	NOXLT	A50T1	OA15X1	OA1X2CO	OA2V1							
	H	H	H	GR/L	GR/L	GR/L	Z	Z	Z	DEG.C	Z	Z	T/H	RPM	
7.25				1350	1227	1238	34.7	33.6	-0.004	393	0.11	3.85	-0.18	9.12	856
8.25				1230	1245	1244	35.8	37.0	0.143	393	0.13	3.46	-0.16	9.70	860
9.25				1290	1275	1275	40.6	40.2	-0.274	394	0.20	3.61	-0.18	9.62	879
10.25				1275	1294	1293	41.9	42.2	0.247	393	0.18	3.05	-0.18	9.81	875
11.25				1280	1335	1332	45.0	46.6	-0.001	392	0.15	3.52	-0.18	9.63	884
12.25				1350	1289	1295	42.3	42.2	-0.097	372	-3.24	--	--	--	--
13.25				1350	1311	1311	33.9	44.7	0.594	396	2.56	3.31	-0.01	9.74	845
14.25				1135	1334	1333	44.2	47.3	0.772	398	0.73	3.00	-0.04	9.76	868
15.25				1290	1317	1316	45.3	46.1	0.066	395	0.13	2.62	-0.04	9.84	870
16.25				1330	1360	1356	51.2	50.9	0.168	387	0.10	2.20	-0.07	9.79	875
17.25				1375	1373	1373	52.6	52.5	0.054	384	0.10	2.79	-0.18	9.65	878
18.25				1330	1322	1323	45.5	48.0	-0.162	387	0.09	5.22	-0.18	9.71	877
19.25				1280	1264	1267	37.9	37.0	0.173	387	-0.05	2.74	-0.18	10.00	880
20.25				1150	1268	1268	40.9	41.7	0.043	386	0.01	2.59	-0.16	9.98	878
21.25				1245	1273	1245	42.4	42.3	0.042	388	-0.10	2.83	-0.17	9.97	879
22.25				1265	1308	1265	46.2	46.3	0.175	387	-0.05	2.58	-0.18	10.01	879
23.25				1275	1331	1330	48.8	48.9	-0.101	390	0.30	3.36	-0.18	10.02	883
0.25				1315	1303	1306	46.7	46.2	-0.126	389	-0.18	3.66	-0.17	9.94	867
1.25				1285	1282	1282	43.7	44.3	-0.280	390	0.07	4.34	-0.18	9.74	877
2.25				1285	1271	1275	44.9	44.2	0.022	390	0.45	3.42	-0.18	10.06	873
3.25				1215	1250	1243	44.7	42.9	-0.381	389	-0.15	3.36	-0.17	9.95	873
4.25				1280	1295	1292	47.6	47.9	-0.010	390	0.22	3.06	-0.18	10.10	873
5.25				1255	1317	1302	50.8	51.4	0.146	390	0.00	3.59	-0.17	9.99	874
6.25				1340	1301	1315	48.6	48.6	-0.151	390	-0.13	2.96	-0.18	9.72	874
7.25				1240	1195	1191	35.9	35.7	-0.932	398	0.39	4.86	-0.16	10.38	864

0.00 - 7.29														
MAX			1340.	1341.	1340.	52.3	51.6	0.390	400.	0.98	5.30	-0.12	10.45	887.
MIN			1215.	1173.	1168.	34.2	32.5	-1.022	385.	-0.50	2.44	-0.21	9.57	861.
MEAN	7.50	6.87	1282.	1296.	1293.	47.2	47.3	-0.030	391.	0.01	3.44	-0.18	9.97	875.
ACCM	60.56	26.11	1286.		1293.			-0.030	391.	0.01		-0.18	74.74	875.
0.00 - 8.00														
MAX			1405.	1412.	1864.	57.4	55.0	1.370	427.	7.27	10.50	1.38	10.13	890.
MIN			1135.	1121.	1122.	21.8	22.8	-1.463	367.	-6.15	0.04	-0.21	1.43	476.
MEAN	23.64	12.20	1291.	1299.	1315.	43.2	43.2	0.000	392.	-0.00	3.08	-0.16	9.52	868.
ACCM	53.04	19.22	1297.		1315.			0.000	392.	-0.00		-0.16	224.98	868.

PLANT REPORT 6

KILN CONTROL

PLANT REPORT

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT

Z ASH IN COAL
 Z MOISTURE IN COAL
 NET HEAT CONSUMP.
 HEAT CONSUMPTION
 W1/ COAL TO KILN
 KILN PRODUC. RATE
 KILN PRODUCTION
 W1/ KILN FEED

COAL HEAT VALUE

SHORT TONS CLINKER
 LB COAL / SH. T
 MBTU/ PER SH.T

U1/ LITER WEIGHT
 COAL TO KILN

HOUR	HO10F1		PRODR		KCAL		C-MOIST		C-HEAT		STONS		BTU		LTWT	
	PROD		KM2F1		MKCAL		C-ASH				LB. COAL		KM2F1*			
	T/H	T/H	T	T/H	KC/KG	KC/KG	Z	Z			T/H		GR/L	H		
7.25	96.7	58.8	1411	9.12	842	883	19.9	5.34	9325	63.8	0	29.52	1350			
8.25	97.4	59.2	1422	9.70	889	932	19.9	5.34	9325	64.3	0	31.15	1230			
9.25	99.8	60.7	1457	9.62	861	902	19.9	5.34	9325	65.9	0	30.00	1290			
10.25	99.3	60.4	1449	9.81	882	924	19.9	5.34	9325	65.5	0	30.84	1275			
11.25	99.9	60.7	1459	9.63	860	901	19.9	5.34	9325	65.9	0	29.84	1280			
12.25	--	--	-62	--	--	--	19.9	5.34	9322	-2.8	--	--	1350			
13.25	93.3	56.7	1361	9.74	932	978	19.9	5.34	9325	61.5	0	32.54	1350			
14.25	93.4	56.7	1363	9.76	934	979	20.5	4.64	9324	61.6	0	32.51	1135			
15.25	97.7	59.4	1426	9.84	899	943	20.5	4.64	9324	64.5	0	31.62	1290			
16.25	100.1	60.8	1461	9.79	873	915	20.5	4.64	9324	66.1	0	30.56	1330			
17.25	100.5	61.1	1467	9.65	857	898	20.5	4.64	9327	66.3	0	29.89	1375			
18.25	100.4	61.0	1465	9.71	864	905	20.5	4.64	9324	66.2	0	30.10	1330			
19.25	100.7	61.2	1470	10.00	886	929	20.5	4.64	9324	66.5	0	30.93	1280			
20.25	99.9	60.7	1459	9.98	892	934	20.5	4.64	9324	65.9	0	31.03	1150			
21.25	99.3	60.3	1449	9.97	897	939	20.5	4.64	9327	65.5	0	31.16	1245			
22.25	99.3	60.4	1449	10.01	900	943	20.5	4.64	9327	65.5	0	31.42	1265			
23.25	99.1	60.2	1446	10.02	903	946	20.5	4.64	9327	65.4	0	31.38	1275			
0.25	99.2	60.3	1447	9.94	895	938	20.5	4.64	9327	65.4	0	31.18	1315			
1.25	99.2	60.3	1447	9.74	877	919	20.5	4.64	9327	65.4	0	30.57	1285			
2.25	99.1	60.2	1446	10.06	907	950	20.5	4.64	9327	65.4	0	31.44	1285			
3.25	99.9	60.7	1458	9.95	889	932	20.5	4.64	9327	65.9	0	30.96	1215			
4.25	99.5	60.4	1451	10.10	907	950	20.5	4.64	9327	65.6	0	31.57	1280			
5.25	98.7	60.0	1440	9.99	904	947	20.5	4.64	9327	65.1	0	31.68	1255			
6.25	99.4	60.4	1451	9.72	873	914	20.5	4.64	9327	65.6	0	30.46	1340			
7.25	91.0	55.3	1328	10.38	1019	1067	20.5	4.64	9327	60.0	0	35.40	1240			

0.00 - 7.30

MAX	100.9	61.3	1472.	10.45	1029.	1079.	20.5	4.65	9328.	66.6	0.	35.92	1340.
MIN	90.2	54.9	1316.	9.57	855.	896.	20.5	4.65	9328.	59.5	0.	29.84	1215.
MEAN	98.9	60.1	1444.	9.97	900.	943.	20.5	4.65	9328.	65.3	0.	31.41	1282. 7.51
ACCH	743.0	451.7		74.86	900.	943.	20.5	4.65			0.	31.41	1286. 60.57


0.00 - 0.00

MAX	101.7	61.8	1484.	10.13	9104.	9545.	20.5	5.34	9405.	67.1	3.	317.45	1405.
MIN	-4.7	-2.9	-77.	1.43	-769987	-807245	19.9	4.65	9323.	-3.5	-288.	-26849.	1135.
MEAN	97.5	59.2	1400.	9.52	827.	867.	20.2	5.05	9324.	63.3	0.	28.84	1291. 23.64
ACCH	2303.2	1399.2		224.98	873.	867.	20.2	5.05			0.	28.83	1297. 53.84

PLANT REPORT 7

PRODUCTION REPORT

PLANT REPORT



PIT & QUARRY


July 1980

concrete reports issue

Oregon Portland Cement's new preheater-equipped plant in eastern Oregon is a dry process installation rated at 500,000 tpy.

Eastern Oregon plant boosts Pacific Northwest's cement supply


Oregon Portland Cement's new dry process plant rated at 1,500 tpd



BY SID LEVINE

The first cement plant constructed in the Northwest since 1967 went into operation last fall. Oregon Portland Cement Co.'s new 1,500-tpd plant, located in Durkee in eastern Oregon (110 miles northwest of Boise, Idaho), also is the first dry-process cement plant equipped with a preheater kiln in the Pacific Northwest.


The 500,000-tpy plant will replace the company's 200,000-tpy wet plant at Lime, Oreg., located 13 miles southeast of Durkee. In addition to serving the markets currently supplied by Lime, the Durkee plant will permit expansion of the southeast Washington




1. Belt conveyor delivering limestone and shale from secondary crusher in quarry.
2. Storage silos for limestone and shale (each, 40 ft. diam. x 110 ft. high).
3. Iron ore storage silo
4. Raw grind department
5. Homogenizing and storage silos for raw meal (each, 40 ft. diam. x 180 ft. high).
6. Four-stage preheater tower
7. Electrostatic precipitators


8. Kiln
9. Clinker cooler
10. Inclined bucket elevator to clinker storage silos.
11. Clinker, coal, and gypsum storage silos (six-each is 40 ft. in diam. x 145 ft. high).
12. Finish mill
13. Bulk cement storage silos (bulk cement loadout facility to trucks and railcar is located behind silos).
14. Coal car unloading facility

15. Belt conveyor from coal storage stockpile
16. Coal mill building and burner floor
17. Maintenance and parts storage building
18. General office, control room, and laboratory building
19. Water cooling and reclaiming pond






To stabilize the quarry's 600 ft. high face, the company is establishing 13 working benches.




Northwest shovel loads stone into Euclid trucks for haul to primary crusher.



Primary crusher is a 36 in. x 48 in. Lippman jaw unit.

and northern Idaho markets and will supplement Oregon Portland Cement's Lake Oswego and Inkomp plants. Lake Oswego supplies western Oregon and southwestern Washington and Inkomp supplies eastern Idaho, northern Utah, and western Wyoming.


The 14-ft., 3/4-in. x 216-ft., 6-in. rotary kiln is an F.L. Smidth unit equipped with Unax satellite coolers and a single-string four-stage preheater. Heat consumption is just under 3 million Btu per short ton of clinker when the kiln operates at its 1,500-tpd design capacity. Coal for firing the kiln is prepared in a 7-ft. 2-in. x 21-ft. FLS Tirax air-swept coal mill for drying and grinding.



Secondary crusher, a Pennsylvania Crusher unit with a 700 hp drive, breaks material into minus 1-in. size.


Shale from company pit is reduced to 7 in. minus size via a 30 in. x 42 in. Lippmann jaw crusher.

Enclosed belt conveyor carries crushed material 2,000 ft. to 4,000 ton capacity silo in the plant.




Oregon Portland Cement's new plant is located near the company's existing chemical-grade limestone quarry at Lime. This quarry was mined for 20 years to supply rock to the Lime cement plant and to beet sugar plants. The mining procedure left the quarry with a 600-ft. face on a 40-degree slope from the horizontal.

To stabilize the quarry's high face, the company is establishing 13 working benches. Bench faces are maintained as close to vertical as practical, forming a 75-degree angle from the horizontal plane. Bench widths are maintained at 35 ft. from toe line to crest line, with vertical intervals at 45 ft. This bench pattern is designed to give an overall







Raw meal is analyzed by a Siemens X-ray analyzer operating with a Digital PDP-11 computer.





A 13 ft. x 22 ft. 9 in. F.L. Smidth Unidan Mill with an 11 ft. 2 in. x 11 ft. overhung drying chamber grinds raw meal to 90% passing 200 mesh size.



Rotary kiln is a 14 ft. 3/4 in. x 216 ft. 6 in. F.L. Smidth unit equipped with satellite coolers and a single-string 4-stage preheater.



An 18 in. x 300 ft. inclined deep-bucket elevator raises clinker to top of clinker storage silos.



Process equipment and operating conditions are monitored in the central control room by a Honeywell TDC 2000 control system.


Coal is dried and ground in an FLS Tirax air-swept coal mill.

backslope of 44 degrees which is considered adequate to stabilize the face.

A Gardner-Denver 6D-25C drill is used to provide 7¼-in. x 48-ft. blastholes, and ANFO prills are used for blasting. The quarry is shot every two weeks, providing about 60,000 tons per blast. Broken material is dozed over the benching to the quarry floor. A 180-D Northwest shovel loads the stone into Euclid trucks for haul to a 36-in. x 48-in. Lippman (primary) jaw crusher.

Crusher product is screened to give a 2½-in. x 4½-in. limestone which is stockpiled for shipment to two sugar beet factories in the area. The remaining stone is stockpiled for trucking to the plant's secondary crusher. The crusher, a Pennsylvania Crusher unit with a 700-hp drive, breaks the stock to a minus 1-in. size. The crushed material is transported 2,000 feet via an enclosed conveyor belt to a 4,000-ton capacity silo in the plant.

Shale is obtained from a pit adjacent to the secondary crusher. The shale is ripped from the pit by a Caterpillar D-9 tractor and fed to a 30-in. x 42-in. Lippman jaw crusher with a Cat 988 front end loader. The crusher reduces the material to 7-in. minus size




Finish mill is a 13 ft. x 47 ft. 3 in. FLS Unidan two-compartment mill driven by a 4,000 hp motor.



and the shale is then crushed in the secondary crusher. The enclosed belt conveyor moves the shale to a 1,500-ton capacity interstice section in the raw material silo facility in the plant.

Sections also are available in the silo facility for clay and hi-mag stone which are excavated from the area adjacent to the crushers.

Raw materials are proportioned to the raw mill via Merrick digital weigh feeders. The raw mill is an F.L. Smidth Tirax Unidan mill, 13-ft. x 22-ft., 9-in. with an 11-ft., 2-in. x 11-ft. over-hung drying chamber. It is arranged for central drive via an FLS Symetro reducer and 2,100-hp Westinghouse motor. The raw meal is ground to at least 90% passing



Left: Sonic cooling tower and FLS electrostatic precipitator handle kiln exhaust gases. Center: Finished cement is pumped to



four storage silos via a Fuller pump. Right: Cement loadout bins are located over rail and truck scales.

200 mesh. Separation takes place in a 20-ft. diameter Sturtevant rotary air separator.

The raw meal is sampled hourly and analyzed with a Siemens MRS 301, nine-channel X-ray analyzer tied in with a Digital PDP-11 computer. X-ray results are converted into new feeder settings by the computer. Process data is entered into the computer each hour. All chemical and process data are stored, and daily, weekly, and monthly reports are made.

Raw mill product is elevated to the top of two homogenizing silos by a Claudius Peters airlift. Each blending silo is located on top of one of the two storage silos. A fluidizing-type conveyor brings the material across the two blending silos and an automatically controlled diverter valve distributes the raw mix between the two blending silos.

The kiln feed discharged from the bottom of the storage silos also is raised by fluidized air conveyor to the Schenck flow meter kiln feeder, located on top of the preheater tower. Overflow from the kiln feeder is returned to the blending silos together with the raw mill feed. Homogenization takes place by a gravity flow effect (the F.L. Smidth "Funnel Flow" system) in the silos.

Clinker is conveyed to one of five clinker silos by an arrangement consisting of a drag conveyor, Rexnord 18-in. x 300-ft. inclined deep bucket elevator, and drag conveyors. Clinker and gypsum are withdrawn from the storage silos and carried to the finish mill by belt conveyors.

The finish mill is a 13-ft. x 47-ft., 3-in. FLS Unidan mill with two compartments. The mill, rated at 80 tph at 3,500 Blaine, is driven by a 4,000-hp Westinghouse motor through an F.L. Smidth Symetro gear reducer.

Finished cement is pumped to one of four finished cement silos by a Fuller 8-in. pump. The cement silos have a specially designed fluidized-air conveyor system that feeds the cement, via screw conveyor and elevator, to loading bins situated over rail and truck scales. All cement from the Durkee plant is shipped in bulk.

Kiln preheater exhaust gases are split for drying the raw materials in the raw mill. Gases not cooled in the raw mill are conditioned in a Sonic cooler tower. The combined gases then go to an F.L. Smidth electrostatic precipitator. Dust is collected from other points via I.C.A. fabric pulse-jet-type dust collectors.

The status of each major piece of process equipment and operating conditions are monitored in the central control room by two identical Honeywell TDC 2000 control systems operating in parallel. Each station is independent of the other and is composed of a color CRT television-type display.

By using a combination of analog and digital methods, the CRT units provide a variety of displays including overview, group, and single loop displays. The TDC 2000 links controllers and displays through a coaxial cable. This system is based on a microprocessor ("computer on a chip") which performs all arithmetic, logic, and decision-making operations without the aid of a conventional computer software program.

Each operating station has a keyboard with dedicated-function pushbuttons. After one operator station is configured, a cassette recording of the configuration can be taken and the other station configured identically. The inside of the kiln and the raw mill and finish mills are monitored with color TV cameras. Electric motors are interlocked with an Allen-Bradley programmable controller. The controller is programmed for group start and stop as well as for interlocking. Programmable controllers are installed for the raw mill, kiln, and finish mill departments.

Key personnel at the Durkee plant are: Richard E. Cooke, plant manager; Arthur L. Heward, business manager; Jack E. Yeates, plant superintendent; David J. Beedle, plant engineer; Richard A. Cartwright, quarry maintenance superintendent; Arthur G. Obendorf, chief chemist; Francis L. Garhart, quality control chemist; Douglas Y. Hale, safety and environmental director; Percy L. Raney, general foreman. ●