

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.7
Reference:	23
Title:	<p>Emission Test Report--Plant A, Roller Kiln, May 1994, Document No. 4602-01-02,</p> <p>Confidential Business Information Files,</p> <p>Contract No 68-D2-0159, Assignment No. 2-01, U. S. Environmental Protection Agency, Research Triangle Park, NC, June 8, 1995.</p>

MONOPOROSA ROLLER KILN

MAY 23, 1994

AP-42 Section 8.7
Reference 23
Report Sect. 4
Reference 21

EMISSIONS TEST REPORT
MONOPOROSA ROLLER KILN

MAY 23, 1994

Prepared For:

Prepared By:

JUNE 22, 1994

TABLE OF CONTENTS

- I. SUMMARY
- II. SOURCE DESCRIPTION
- III. METHODS AND PROCEDURES
 - APPENDIX A - Test Data and Calculations
 - APPENDIX B - Visible Emission Test Report
 - APPENDIX C - Process Weight Statement
 - APPENDIX D - Calibration Data
 - APPENDIX E - Chain of Custody

I. SUMMARY

On May 23, 1994 [REDACTED] conducted fluoride and particulate emissions tests for annual compliance certification at [REDACTED]

The source tested was the Monoporosa Roller Kiln operating under [REDACTED]

The tests were conducted by [REDACTED] and [REDACTED] of [REDACTED] with the assistance and cooperation of employees of [REDACTED]

A summary of the fluoride and particulate test results is shown in Table 1. The average fluoride emission rate was 0.198 lb/hr, less than the maximum allowable emission rate of 3.0 lb/hr. The average particulate emission rate was 0.0048 gr/dscf, less than the maximum allowable emission rate of 0.03 gr/dscf. No visible emissions were observed during the one hour test, conducted on April 14, 1994 (previously submitted). During the test, the kiln was processing green tile at the normal production rate of 2.5 tons per hour.

All emission rates were determined according to the procedures prescribed by the [REDACTED] and the tested source was found to be in compliance with applicable emission standards.

I hereby certify that these results are true and correct and
were obtained by the procedures and methods described herein.

Respectfully Submitted;

[REDACTED]
Environmental Specialist II

[REDACTED]
Test Team Chief

TABLE 1
TEST SUMMATION

PLANT:
SOURCE: MONOPOROSA KILN
PARAMETER: PART. & FLUORIDE
DATE: 5-23-94


RUN NO.	SAMPLE VOL. (DSCF)	FLOWRATE (ACFM)	WATER CONTENT (DSCFM)	STACK TEMP. (%)	ISO KINETIC (deg F)	PARTICULATE EMISSIONS (gr/dscf)(1b/hr)	FLUORIDE EMISSIONS (1b/hr)
1	30.422	9341	4726	7.48	512	95.4	0.0047
2	32.318	9253	4728	6.68	510	96.1	0.0048
3	31.104	9320	4742	6.42	517	97.2	0.0048
Average	-----	9305	4732	6.86	513	96.2	0.19
						* ALLOWABLE 0.0300	0.198
							3.000

* Allowable emissions per Permit No.

II. SOURCE DESCRIPTION

... is a ceramic tile manufacturing plant operating a Sacmi brand monoporosa roller kiln. The kiln is direct fired using natural gas. The kiln has two stacks, one located at the tile discharge end of the kiln and one at the tile feed end of the kiln. During the test, all emissions were routed through the stack located at the tile feed end of the kiln. The damper on the stack at the tile discharge end of the kiln was observed to be closed during emission testing.

The tested stack was 24.8 inches in diameter with two ports 90 degrees apart. The sampling port locations were 4.6 stack diameters upstream and approximately 4.8 stack diameters downstream from disturbances in the exhaust flow. A diagram of the stack is shown in Figure 1.



24.8 inch Diameter Stack

Sampling Point	Distance From Stack Wall (Inches)
1	0.6 *
2	2.0
3	3.6
4	5.6
5	8.5
6	16.3
7	19.2
8	21.2
9	22.8
10	24.2 *

* Note: Points
1 & 10 Relocated
to 1.0" From
Stack Wall.

FIGURE 1

MONOPOROSA ROLLER KILN
SAMPLING POINT LOCATION

III. METHODS AND PROCEDURES

The modified Method 13B sampling train was assembled as shown in Figure 2 for each fluoride/particulate test. A five foot probe with a heated stainless steel liner was used for all test runs. Stack temperature measurements were conducted at each point during sampling.

The first and second impingers were each charged with 100 ml of distilled, deionized water; the third was dry; and the fourth was filled with known weight of indicator-grade silica gel. Crushed ice was placed around the impingers during sampling to maintain the temperature of the gas leaving the last impinger below 68°F.


A heated glass microfiber filter in a glass filter holder was placed between the probe and the first impinger.

Leak tests were performed on the sampling train before and after each sampling run by blocking the nozzle inlet. No leakages were observed at vacuum levels at or exceeding those experienced during sampling.

Each sampling run consisted of 20 points, 10 points through each of two ports. Each point was sampled for three minutes, giving a total test time of 60 minutes per run.

At the end of each run, the volume of water collected in the first three impingers was measured and the silica gel in the fourth impinger was weighed to the nearest 0.5 gram to determine the volume of water collected. The impinger contents and a deionized distilled water rinse of the impingers and connecting glassware up to the filter were collected in a sample storage container for subsequent laboratory analysis. The filter bell, probe and nozzle were rinsed with acetone and collected in a separate sample bottle for subsequent particulate analysis according to EPA Method 5 procedures.

Upon completion of the gravimetric analysis of the particulate sample, the particulate residue in beakers, the filters, as well as the impinger, samples collected plus a blank sample of distilled water, acetone residue blank and an unused filter were analyzed for total fluorides by , Inc. The analyses were performed using a specific ion electrode procedures as described in EPA Method 13B.



PARTICULATE / FLUORIDE SAMPLING TRAIN
MODIFIED EPA METHOD 13B

Figure 2

APPENDIX A
TEST DATA AND CALCULATIONS

SUMMARY OF TEST DATA

Plant:

Source: MONOPOROSA KILN

Emission:PART.&FLUORIDE

	RUN 1	RUN 2	RUN 3
Test Date:	5-23-94	5-23-94	5-23-94
Test Interval:	0920-1021	1100-1202	1213-1314
Test Time, min.:	60	60	60
Stack Area, sq. ft.:	3.353	3.353	3.353
Nozzle Diameter, in.:	0.263	0.27	0.263
Barometric Pressure, in. Hg.:	30.10	30.10	30.10
Absolute Stack Pressure, in. Hg.:	30.14	30.13	30.13
Volume Liquid Collected, ml.:	52.2	49.1	45.3
Stack Moisture (measured value), %	7.5	6.7	6.4
Stack Moisture (saturated value), %	5362.2	5291.3	5621.8
Stack Gas Temperature, deg F:	512	510	517
Sample Volume, DSCF:	30.4222	32.3180	31.1041
Gas Velocity, FPS:	46.430	45.994	46.328
Gas Flowrate, ACFM:	9341	9253	9320
Gas Flowrate, DSCFM:	4726	4728	4742
Particulate Collected, mg:	0.009	0.010	0.010
Acid Mist Concentration, lb/DSCF:	4.72E-03	4.82E-03	4.81E-03
Emission Rate, lb/hr:	0.19	0.20	0.20
Percent Isokinetic, %:	95.4	96.1	97.2

CALCULATIONS

PLANT:

SOURCE: MONOPOROSA KILN

PARAMETER: PART. & FLUORIDE

DATE: 5-23-94

RUN NO.	1	2	3
Cp=	0.84	0.84	0.84
Y=	1.012	1.012	1.012
Dn=	0.263 inches	0.27 inches	0.263 inches
An=	3.773E-04 sq. ft.	3.976E-04 sq. ft.	3.773E-04 sq. ft.
Pb =	30.10 in Hg	30.10 in Hg	30.10 in Hg
Ps =	30.14 in Hg	30.13 in Hg	30.13 in Hg
As =	3.353 sq. ft.	3.353 sq. ft.	3.353 sq. ft.
Time=	60 min	60 min	60 min
Vm =	30.800 DCF	32.943 DCF	32.002 DCF
Vm(COR)=	30.800 DCF	32.943 DCF	32.002 DCF
dH=	0.93 in. H2O	1.06 in. H2O	0.93 in. H2O
Tm=	545 deg R	549 deg R	554 deg R
Ts=	972 deg R	970 deg R	977 deg R
Vlc=	52.2 ml.	49.1 ml.	45.3 ml.
SQRTdPavg=	0.6044	0.6000	0.6025
Mn=	0.0093 mg	0.0101 mg	0.0097 mg
F=	11.50 mg	10.50 mg	7.62 mg
Vms=	30.4222 DSCF	32.3180 DSCF	31.1041 DSCF
Vw=	2.4586 SCF	2.3126 SCF	2.1336 SCF
Bws=	0.0748	0.0668	0.0642
Bws(sat)=	53.62	52.91	56.22
Md=	29 assumed	29 assumed	29 assumed
Ms=	28.1775	28.2654	28.2939
Vs=	46.4296 FPS	45.9945 FPS	46.3280 FPS
Qs=	4726 DSCFM	4728 DSCFM	4742 DSCFM
Qa=	9341 ACFM	9253 ACFM	9320 ACFM
I=	95.4 %	96.1 %	97.2 %
Cs=	0.0047 gr/dscf	0.0048 gr/dscf	0.0048 gr/dscf
E=	0.191 lb/hr	0.195 lb/hr	0.196 lb/hr
Ef=	0.2363 lb/hr	0.2031 lb/hr	0.1536 lb/hr

$$Vms=17.64*Vm*Y*(Pb+dH/13.6)$$

$$Vw=.0471*Vlc$$

$$Bws=Vw/(Vw+Vms)$$

$$Md=0.44(\%CO_2)+0.32(\%O_2)+0.28(\%CO+\%N_2)$$

$$Ms=Md(1-Bws)+18*Bws$$

$$Vs=85.49*Cp*SQRTdPavg*SQRT(Ts/Ps*Ms)$$

$$Qs=1058*(1-Bws)*Vs*As*(Ps/Ts)$$

$$Qa=60*As*Vs$$

$$I=100*Vm(std)*As/(Time*Qs*An)$$

$$Cs=15.43*Mn/Vms$$

$$E=Cs*Qs/116.67$$

$$Ef=2.205E-6*60*F*Qs/Vms$$

PLANT 1

2

SOURCE

Monsoporosa Kit


NOZZLE I.D. NO. 9A	
DIA 1	264
DIA 2	263
DIA 3	263
AVERAGE	263

FINAL VOLUME 773,500
 INITIAL VOLUME 742,700
 NET VOLUME 20,800

RUN NO OHIO
 DATE 5/23/94
 OPERATOR [REDACTED]
 METER BOX NO [REDACTED]
 FILTER NO 113

HOMOGRAPH VALUES
 $\Delta H@ 1.929$ C FACTOR 1.00
 T_m AVG OP
 ΔH_2O 90 T₁ 540
 REFERENCE 2.55

BAROMETRIC PRESSURE 30.010
 STATIC PRESSURE 70.55
 AMBIENT TEMPERATURE 5
 PROBE LENGTH 5
 PROBE LINER 9/16 in.
 PORT LENGTH 3 in
 PORT DIAMETER 3 in
 METER SYSTEM LEAK-CHECK 0.00005
 ORSAT LEAK-CHECK ✓
 SAMPLE BAG LEAK-CHECK ✓



TRAVERSE POINT NUMBER	SAMPLING TIME		STACK TEMP (11.1 °F)	VELOCITY HEAD		ORIFICE METER (10H)	GAS SAMPLE VOLUME (10m ³ H ₂)	DRY GAS METER TEMP (11m 1 °F)	PROBE TEMP °F	SAMPLE BOX TEMP °F	TEMP OF GAS LEAVING LAST IMPINGER °F	PUMP VACUUM GAUGE in. Hg
	CLOCK	SAMPLE		10 PSI	100 PSI							
	0920						742.700					
1-1	3	513	33	.89	744.200	75	231	233	62	6		
2	6	515	33	.89	745.70	76	233	234	50	6		
3	9	517	33	.89	747.12	78	242	230	43	6		
4	12	510	34	.87	740.67	78	245	240	41	5.5		
5	15	511	35	.89	750.17	81	247	260	41	5		
6	18	511	35	.89	751.67	84	249	253	42	5		
7	21	517	42	1.07	753.32	85	249	240	42	6		
8	24	517	42	1.07	755.00	84	250	252	42	6		
9	27	513	46	1.17	756.71	86	251	268	42	6		
10	30	516	47	1.20	758.43	87	251	263	41	6.5		
2-1	33	507	30	.77	759.85	87	252	249	42	4		
2	36	505	30	.77	761.30	87	250	260	42	4		
3	39	510	33	1.84	762.92	87	237	251	40	4		
4	42	510	33	.89	764.25	87	243	255	39	4		
5	45	510	33	.84	765.80	86	260	263	39	4.5		
6	48	512	35	.89	767.30	86	245	269	39	4.0		
7	51	510	35	.89	768.79	85	245	244	39	4		
8	54	519	31	.94	770.46	84	250	237	39	5		
9	57	511	37	.94	771.96	84	249	246	39	5		
10	1021	60	37	.94	773.500	84	251	252	40	5		
TOTAL												
AVERAGE												

STATIC PITOT LEAK-CHECK @ 15 sec ✓
 IMPACT PITOT LEAK-CHECK @ 15 sec ✓
 TRAIN LEAK RATE @ 60 sec 0.00 ft@ in

VOLUME OF LIQUID WATER COLLECTED	IMPINGER WEIGHT (g) OR VOLUME (ml)			
	1	2	3	4
FINAL	140	106	0	271.2
INITIAL	100	100	0	271.0
LIQUID COLL	40	6	0	6.2
TOTAL VOLUME	1	52.2		

GAS MEASUREMENTS				
TIME	CO ₂	O ₂	CO	H ₂
1				
2				
3				
4				

SIGNATURE

PLANT

SOURCE

Monoyorosa Kih


NOZZLE I.D. NO. 5A	
DIA 1	270
DIA 2	269
DIA 3	270
AVERAGE	270

FINAL VOLUME 807.003
 INITIAL VOLUME 274.050
 NET VOLUME 32.943

RUN NO. Two
 DATE 5/23/94
 OPERATOR [REDACTED]
 METER BOX NO. [REDACTED]
 FILTER NO. 114

NOMOGRAPH VALUES
 DH@ [REDACTED] C FACTOR [REDACTED]
 Tm [REDACTED] AVG OP [REDACTED]
 RH₂O [REDACTED] T₁ [REDACTED]
 REFERENCE 2:93

BAROMETRIC PRESSURE 30.16
 STATIC PRESSURE 40.40
 AMBIENT TEMPERATURE 88
 PROBE LENGTH 3
 PROBE LINER glass
 PILOT LENGTH 3
 PORT DIAMETER 3
 METER SYSTEM LEAK-CHECK 0.00@15
 ORSAT LEAK-CHECK ✓
 SAMPLE BAG LEAK-CHECK ✓



TRAVERSE POINT NUMBER	SAMPLING TIME	STACK TEMP 13.1 °F	VELOCITY HEAD		ORIFICE METER 10HI	GAS SAMPLE VOLUME 1Vml 11	DRY GAS METER TEMP 11m 1 °F	PROBE TEMP °F	SAMPLE BOX TEMP °F	TEMP OF GAS LEAVING LAST IMPINGER °F	PUMP VACUUM GAUGE in. Hg
			CLOCK	SAMPLE							
1	1100	3	509	.33	.97	775.60	87	237	246	67	5
2		6	509	.33	.97	771.17	87	238	254	65	5
3		9	509	.33	.97	788.77	86	246	261	65	5
4		12	513	.33	.97	780.33	87	229	259	63	5
5		15	513	.33	1.03	782.00	86	229	262	63	5.5
6		18	517	.35	1.03	783.70	87	232	256	60	5.0
7		21	507	.40	1.18	785.30	88	239	246	61	6.0
8		24	506	.40	1.08	87.02	88	245	250	61	5.5
9		27	507	.37	1.09	788.68	89	252	252	61	5.5
10		30	504	.37	1.09	790.02	89	254	253	61	5.5
21		33	506	.30	-0.9	791.87	89	253	256	60	4
2		36	510	.35	1.03	793.51	90	251	253	62	5.0
3		39	509	.35	1.03	795.16	90	250	253	62	5.0
4		42	515	.35	1.03	796.76	91	238	253	60	5.0
5		45	516	.37	1.09	798.40	91	239	253	61	6.0
6		48	515	.37	1.09	800.61	91	232	252	60	6.0
7		51	514	.37	1.09	801.80	91	235	246	63	5.5
8		54	510	.35	1.03	803.45	92	241	251	63	5.5
9		57	510	.35	1.03	805.10	92	240	249	64	5.5
10	1202	60	509	.50	1.48	807.003	92	241	247	63	8
TOTAL											
AVERAGE											

STATIC PITOT LEAK-CHECK @ 15 SEC ✓

IMPACT PITOT LEAK-CHECK @ 15 SEC ✓

TRAIN LEAK RATE @ 60 SEC 0.0 ft@10 in

VOLUME OF LIQUID WATER COLLECTED	IMPINGER WEIGHT (g) OR VOLUME (ml)			
	1	2	3	4
FINAL	136	109	0	278.7
INITIAL	100	100	0	269.6
LIQUID COLL.	36	4	0	9.1
TOTAL VOLUME	1	49.1		

GAS MEASUREMENTS				
TIME	CO ₂	O ₂	CO	N ₂
1				
2				
3				
4				

SIGNATURE


PLANT

SOURCE Monoparam kilo

NOZZLE I.D. NO. 911	
DIA 1	
DIA 2	
DIA 3	
AVERAGE	.263

RUN NO Three
 DATE 4/5/72 3:54
 OPERATORS ██████████
 METER BOX NO ██████████
 FILTER NO 113

BAROMETRIC PRESSURE 30.10
 STATIC PRESSURE 40.40
 AMBIENT TEMPERATURE 89
 PROBE LENGTH 57
 PROBE LINER glass
 PORT LENGTH
 PORT DIAMETER 3"
 METER SYSTEM LEAK-CHECK 0.000 P/S
 ORSAT LEAK-CHECK ✓
 SAMPLE BAG LEAK-CHECK ✓



FINAL VOLUME 839.002
 INITIAL VOLUME 807.000
 NET VOLUME 32.002

NOMOGRAPH VALUES
 $\Delta H@$ C FACTOR
 T_m AVG. AP
 ΔH_{H_2O} T₁
 REFERENCE

PORT LOCATION

TRAVERSE POINT NUMBER	SAMPLING TIME	STACK TEMP (F, °F)	VELOCITY HEAD	ORIFICE METER (10H)	GAS SAMPLE VOLUME (mls) (l)	DRY GAS METER TEMP (11m, 1°F)	PROBE TEMP (°F)	SAMPLE BOX TEMP (°F)	TEMP OF GAS LEAVING LAST IMPINGER (°F)	PUMP VACUUM GAUGE in. Hg
CLOCK	SAMPLE		10PSI 100PSI							
11	1213	3	501 -33	.84	809.11	93	229	232	67	4.5
2		6	516 -33	.84	810.64	93	238	234	65	4.5
3		9	519 -35	.89	812.20	92	260	231	64	5.0
4		12	518 -35	.89	813.80	92	251	232	63	5.0
5		15	518 -35	.89	815.23	92	250	240	60	5.0
6		18	517 -35	.89	816.80	93	268	251	58	5.0
7		21	519 -37	.94	818.40	93	267	254	56	5.0
8		24	520 -37	.94	820.00	94	267	251	55	5
9		27	519 -37	.94	821.50	94	271	256	54	5
10		30	520 -40	1.02	823.02	94	268	246	59	6
2-1		33	510 -30	.77	824.60	95	255	253	56	4.5
2		36	506 -39	.77	826.10	95	256	257	54	4.5
3		39	529 -35	.89	827.70	94	257	251	54	5
4		42	516 -35	.89	829.20	95	251	252	54	5
5		45	529 -35	.89	830.70	95	260	247	55	5
6		48	522 -40	1.02	832.40	96	261	249	57	5.5
7		51	519 -37	.94	834.00	96	260	250	56	5.0
8		54	516 -43	1.02	835.69	95	262	247	58	6
9		57	513 -43	1.10	837.33	96	264	251	60	6
10	1314	60	519 -43	1.10	839.002	95	261	240	61	6
TOTAL										
AVERAGE										

STATIC PILOT LEAK-CHECK @ 15 SEC IMPACT PILOT LEAK-CHECK @ 15 SEC

TRAIN LEAK RATE @ 60 SEC 0.0 ml @ 10 hr

VOLUME OF LIQUID WATER COLLECTED	IMPIINGER WEIGHT (g) OR VOLUME (ml)			
	1	2	3	4
FINAL	132	104	0	270.8
INITIAL	100	100	0	264.5
LIQUID COLL.	32	4	0	9.3
TOTAL VOLUME	1	45.3		

TIME	GAS MEASUREMENTS			
	CO ₂	O ₂	CO	N ₂
1				
2				
3				
4				

SIGNATURE

6-Jun-1994
Page 1

Report For:

Sample Identification:

Impinger solution/Filter 113
Run 1, Monoporous kiln

attn: [REDACTED]

Date Received: 27-May-1994

Laboratory Number:

CERTIFICATE OF ANALYSIS

Method	Parameter	Result	Units
40CFR Part 60 App.A Method 13B EPA	Total Fluoride in Solution & Filter	11.5	mg
	Volume of Solution	395	mL

RECEIVED
JUN 9 1994

1110
M

S

88502

6-Jun-1994
Page 1

Report For:

Sample Identification:

Impinger solution/Filter 114
Run 2. Monoporous kiln

attn: [REDACTED]

Date Received: 27-May-1994

Laboratory Number:

CERTIFICATE OF ANALYSIS

Method	Parameter	Result	Units
40CFR Part 60 App.A Method 13B	Total Fluoride in Solution & Filter	10.5	mg
EPA	Volume of Solution	445	mL

6-Jun-1994
Page 1

Report For:

Sample Identification:

Impinger solution/Filter 115
Run 3, Monoporous kiln

attn: [REDACTED]

Date Received: 27-May-1994

Laboratory Number:

CERTIFICATE OF ANALYSIS

Method	Parameter	Result	Units
40CFR Part 60 App.A Method 13B EPA	Total Fluoride in Solution & Filter	7.62	mg
	Volume of Solution	387	mL

6-Jun-1994
Page 1

Report For:

Sample Identification:

Impinger solution/Filter 116
Run 4, Blank

attn: [REDACTED]

Date Received: 27-May-1994

Laboratory Number:

CERTIFICATE OF ANALYSIS

Method	Parameter	Result	Units
40CFR Part 60 App.A Method 13B EPA	Total Fluoride in Solution & Filter	0.004	mg
	Volume of Solution	100	mL

APPENDIX B
VISIBLE EMISSION TEST REPORT

VISIBLE EMISSION OBSERVATION FORM

ENVIRONMENTAL ENGINEERING CONSULTANTS, INC.

APPENDIX C
PROCESS WEIGHT STATEMENT

PROCESS RATE STATEMENT

COMPANY:

SOURCE: Monoporosa Kiln

DATE: May 23, 1994

	TIME	PROCESS RATE
RUN NO. 1	<u>0920-1021</u>	<u>4928 lbs/hr</u>
RUN NO. 2	<u>1100-1202</u>	<u>4980 lbs/hr</u>
RUN NO. 3	<u>1213-1314</u>	<u>5000 lbs/hr</u>

SIGNATURE

Monoporosa Manager
TITLE

5-23-94

DATE

APPENDIX D
CALIBRATION DATA

SUMMARY OF EQUIPMENT CALIBRATION

Equipment	Calib. Date	Place	Method	Results
Nozzle #9A	05/23/94	On-Site	3 measurements w/ vernier caliper	Dn=0.274
Nozzle #9B	05/23/94	"		Dn=0.263
Pitot Tube P-1	03/25/94	[REDACTED]	EPA Method	Cp=0.84
Pitot Tube P-5	03/24/95	"		Cp=0/84
Meter Console	01/17/94	[REDACTED]	Wet Test Meter	Y=1.012 H@=1.929
Post-Test Check	05/31/94	[REDACTED]	Wet Test Meter	Y=0.999
Thermocouples (Console [REDACTED])	03/18/94	[REDACTED]	Comparison to ASTM Thermometer	Correct to <u>±1%</u>

TYPE S PITOT TUBE INSPECTION DATA FORM

Pitot tube assembly level? yes no

Pitot tube openings damaged? yes (explain below) no

P_A ,529 cm (in.) P_B ,519 cm (in.)

$D_t = ,375$ cm (in.) $A = P_A + P_B = ,1048$ cm (in.)

$\alpha_1 = 10^\circ$ ($<10^\circ$), $\alpha_2 = 0^\circ$ ($<10^\circ$), $\beta_1 = 0.5^\circ$ ($<5^\circ$),

$\beta_2 = 4.05^\circ$ ($<5^\circ$)

$\gamma = 2^\circ$, $\theta = 1^\circ$


$z = A \sin \gamma = 0.0365$ cm (in.); <0.32 cm ($<1/8$ in.)

$w = A \sin \theta = 0.0183$ cm (in.); $<.08$ cm ($<1/32$ in.)

Comments: Meets Specifications






$C_p = 0.84$

Calibration required? yes no



NOTE:
 $1.05 D_t < P < 1.50 D_t$
 $P_A = P_B$

$0.48 \text{ CM} < D_t < 0.95 \text{ CM}$
 $(3/16 \text{ IN.}) < D_t < 3/8 \text{ IN.}$



Pitot tube I.D. Number: P-1

Inspection Date: 3/25/94

Inspected By: [Redacted]

TYPE S PITOT TUBE INSPECTION DATA FORM

Pitot tube assembly level? yes no

Pitot tube openings damaged? yes (explain below) no

P_A 1430 cm (in.) P_B 1396 cm (in.)

$D_t = 376$ cm (in.) $A = P_A + P_B = 1826$ cm (in.)

$\alpha_1 = 0^\circ$ ($< 10^\circ$), $\alpha_2 = 2^\circ$ ($< 10^\circ$), $\beta_1 = 1^\circ$ ($< 5^\circ$),
 $\beta_2 = 3^\circ$ ($< 5^\circ$)



$\gamma = 0^\circ$, $\epsilon = 2^\circ$

$z = A \sin \gamma = 0$ cm (in.); < 0.32 cm ($< 1/8$ in.)

$w = A \sin \epsilon = 0.029$ cm (in.); $< .08$ cm ($< 1/32$ in.)

Comments: Meets Spec. $C_p = 0.84$




Calibration required? yes no



Pitot tube I.D. Number: P-5

Inspection Date: 3/25/94

Inspected By: [Redacted]



DGM Calibration

Technician: [REDACTED] DATE: 1/17/94

Control Box No.: [REDACTED] SDGM:

Barometer (*Hg): 29.990 Ys: 0.9980

[^] Hd ([*] H ₂ O)	Net SDGM Volume [dHd] [Vs]	Net DGM Volume [Vd]	SDGM Temp (^o F) [ts]	DGM In (^o F) [td]	DGM Out (^o F) [td]	Avg. Setting (*Hg) [td]	Time (min)	Vacuum ("Hg)	Y	dHa ("H ₂ O)
0.50	5.706	5.634	67.0	67	67.0	15		3	1.010	1.9247
1.00	8.115	8.000	68.0	68	69.0	15		3	1.012	1.9068
1.50	10.591	10.424	68.0	72	74.0	16		3	1.022	1.8962
2.00	12.896	12.829	68.0	73	75.0	17		3	1.012	1.9215
2.50	12.596	12.555	68.0	74	76.0	15		3	1.010	1.9564
3.00	13.765	13.714	68.0	74	76.0	15		3	1.009	1.9658

dHd RANGE	CRITERIA	1.012 1.929
0.069 <0.15 [*] H ₂ O	Thermocouple Check EEC-2: 75 F = 535 R ASTM: 68 F = 528 R DIFFERENCE % : 0.09 	

Calibration Performed By [REDACTED]

$$Y = [Vs * Ys * Pbar * (td + 460)] / [Vd * (Pbar + (dHd / 13.6)) * (ts + 460)]$$

$$dHa = [Pb(0.0317 * dH / (td + 460)) * ((tw + 460) * Time / Vw)]^2$$

SDGM = Standard Dry Gas Meter

Recheck of Orifice and DGM Calibration

Technician: [REDACTED] Date: 5/31/94

Control Box No.: [REDACTED] SDGM: 30593

Barometer ("Hg): 30.010 Ys: 0.9990

Monoporous Kiln

[^] Hd ("H ₂ O) [dHd]	Net SDGM Volume [Vs]	Net DGM Volume [Vd]	SDGM Temp [ts]	DGM In (F) [ts]	DGM Out (F) [ts]	DGM Avg. (F) [td]	Time (min)	Vacuum Setting ["Hg] [td]
1.50	9.801	9.804	85.0	85	84	84.5	15	15
1.50	9.796	9.766	80.0	83	82	82.5	15	15
1.50	9.770	9.771	80.0	84	82	83.0	15	15

Y(1)=	0.994		Thermocouple Check	
Y(2)=	1.003		EEC-2 83.33 F = 543. R	
Y(3)=	1.001		ASTM: 81 F = 541 R	
Y(avg)=	0.999		DIFFERENCE: 0.43%	

Prior Y = 1.012 Calibration Performed By [REDACTED]
Diff. = 1.3%

Y=[Vs*Ys*Pbar*(td+460)]/[Vd*(Pbar+(dHd/13.6))*(ts+460)]
SDGM= Standard Dry Gas Meter

PYROMETER/THERMOMETER CALIBRATION

IDENTIFICATION	DATE	REFERENCE TEMP. °F(ASTM-Hg)	INDICATION TEMP. °F	REFERENCE MEDIUM	CORRECTION
# 1	3/18/94	538°	539°	Ambient	0.19%
		502°	499°	Ice Water	0.60%
		674°	674°	Boiling Water	0%
		840°	842°	Hot Oil	0.24%
# 2	3/18/94	538°	537°	Ambient	0.19%
		502°	500°	Ice Water	0.40%
		674°	673°	Boiling Water	0.15%
		840°	842°	Hot Oil	0.24%
# 3	3/18/94	538°	539°	Ambient	0.19%
		502°	502°	Ice Water	0%
		674°	674°	Boiling Water	0%
		840°	843°	Hot Oil	0.35%
Fluke	3/18/94	538°	539°	Ambient	0.19%
		502°	499.2	Ice Water	0.56%
		674°	675°	Boiling Water	0.15%
		850°	849°	Hot Oil	0.12%
DGM Dial	3/18/94	538°	536°	Ambient	0.37%

APPENDIX E
CHAIN OF CUSTODY

work 6.7
Received

Chain of Custody

Sample Identification

Comments:	Transferred From:			Transferred To:			Comments:
	Signature:	Date	Time	Signature:	Date	Time	
Run 1 Bekar # 413 Filter # 113 EPA Meth 13B [REDACTED]	[REDACTED]	5/23/94	0930	[REDACTED]	5/23/94	0930	Report Result to: [REDACTED]
[REDACTED]	[REDACTED]	5/27/94	1100	[REDACTED]	5/27/94	1100	
Run 2 Bekar # 4168 Filter # 114 EPA Meth 13B [REDACTED]	[REDACTED]	5/23/94	1100	[REDACTED]	5/23/94	1100	Please be very careful this time!
[REDACTED]	[REDACTED]	5/27/94	1100	[REDACTED]	5/27/94	1100	
Run 3 Bekar # 413 Filter # 115 EPA Meth 13B [REDACTED]	[REDACTED]	5/23/94	1230	[REDACTED]	5/23/94	1230	Method
[REDACTED]	[REDACTED]	5/27/94	1100	[REDACTED]	5/27/94	1100	B
Run 4 (Blank) Bekar # 157 Filter # 116 EPA Meth 13B [REDACTED]	[REDACTED]	5/23/94	1245	[REDACTED]	5/23/94	1245	
[REDACTED]	[REDACTED]	5/27/94	1100	[REDACTED]	5/27/94	1100	

Consulting

LETTER OF TRANSMITTAL

TO Mr. [REDACTED] - Air Section

DATE	June 29, 1994	JOB NO.	[REDACTED]
RE	[REDACTED]		
	[REDACTED]		

GENTLEMEN:

WE ARE SENDING YOU Attached Permit Applications Report Review Fees
 Shop Drawings Prints Plans Samples Specifications

COPIES	NO.	DESCRIPTION
1		Annual compliance test conducted on the Monoporosa Kiln located at the above-referenced facility on May 23, 1994.

THESE ARE TRANSMITTED as checked below:

For approval For Your use As requested

REMARKS

If you have any questions, please call me at [REDACTED]

COPY TO [REDACTED]

SIGNED [REDACTED]

Environmental Tech. II