

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.7
Reference:	30
Title:	Stationary Source Sampling Report Reference No. 6445, Lead And Particulate Emissions Testing, Spray Booth 2A Stack, Entropy Environmentalists, Inc., Research Triangle Park, NC, September 20, 1989.

AP-42 Section 11.7
Reference 30
Report Sect. 4
Reference 28

N.C. Dept. NRCD

NOV 1 1989

Winston-Salem
Regional Office

ENTROPY

ENVIRONMENTALISTS INC.

POST OFFICE BOX 12291
RESEARCH TRIANGLE PARK
NORTH CAROLINA 27709-2291
919-781-3550

STATIONARY SOURCE SAMPLING REPORT

REFERENCE NO. 6445

MANNINGTON CERAMIC TILE, INC.

LEXINGTON, NORTH CAROLINA

LEAD AND PARTICULATE EMISSIONS TESTING

SPRAY BOOTH 2A STACK

RECEIVED
NOV 27 1989

AIR QUALITY TECH SERVICES

SEPTEMBER 20, 1989

DIVISION OF ENVIRONMENTAL MANAGEMENT

Air Quality Section

June 20, 1991

MEMORANDUM

To: Myron Whitley

From: Shannon M. Vogel *MMV*

Subject: Mannington Ceramic Tile
Mid-State Tile Company
Lexington, Davidson County, North Carolina
Particulate and Lead Emissions Testing of Spray Booth No. 2A
Performed on August 20, 1989 by
Entropy Environmentalists Inc.

A report of the subject testing has been reviewed and is found to be acceptable. The results appear reliable and demonstrate that compliance with the applicable particulate emission standard was achieved during the test period.

The emission standard that applies to the subject facility is 15A NCAC 2D .0515, PARTICULATES FROM MISCELLANEOUS INDUSTRIAL PROCESSES, which limits particulate emissions according to process rates.

No maximum process rate is stated in permit No. 5408R for spray booth 2A. The production rate during testing was 4425 pounds per hour, for which the allowable particulate emission rate is 3.98 pounds per hour. The average particulate emission rate demonstrated by the test results was 3.86 pounds per hour.

Compliance for particulate is demonstrated.

cc: Central File via Earl McCune
Mike Aldridge

NORTH CAROLINA DIVISION OF ENVIRONMENTAL MANAGEMENT

Air Quality Action Request

Computer _____

Name	Location	Reg/Co./Prem. No.
Mannington Ceramic Tile	Lexington, Davidson Company	4-29-00097
Contact		Telephone
Mike Tkach, Plant Manager		
Type Action:	CI ☐ EE ☒ SR ☐ PC ☐ VE ☐ PI ☐ Other	Source Test
Air Program Status	03	Class B Chg
Action Requested By:	Address/Phone	Rec'd Date
Last Insp. Date	Action Date 9-20-89	Next Insp. Date
Permit # 5408R	Issued	Expires 4-1-93
		Stip. #
		Met Y/N
Recommendations:	Signature	Date
Await Test Results		
Re-visit as previously scheduled	Stephen M. Moser	12-89
Dist: Yellow (Central File) - Blue (Region) - White (Opt.) Specify		

On 9-20-89 Entropy Environmentalists Inc. performed a stack test on one of the glaze spray booths at Mannington Ceramic Tile. The company identifies the booth as No. 2-A and the booth was chosen for testing because the glaze mixture contains lead. The test is part of a testing program which will also contain high volume sampling as a measure to determine the facility's emissions and hopefully will reduce or eliminate the rash of complaints the company has recently experienced.

In addition to Mike Tkach, the following people were contacted:

- (1) Bill Piske, P.E. - Charles T. Main, Inc.
- (2) Neill Hardin - Entropy, and
- (3) Lee Marchmen - Entropy

RECEIVED
NOV 27 1989

AIR QUALITY TECH SERVICES

During the test, a 30 minute visible emissions evaluation was performed on the stack which indicates compliance. The booth is a 20% source. The company has seven booths. Five are 20% sources and 2 are 40% sources. All appeared to comply. The booths and their respective opacity limits have been identified.

The testing I observed seemed acceptable. Source test data was obtained. The company has supplied process rates during the test. According to their figures, 4026 lbs/hr of tile and 399 lbs/hr. of glaze were processed in the booth, for a total of 4425 lbs per hour.

At the time of the testing, Mr. Bill Piske with Charles T. Main, Inc. (Mannington's consultant) asked how often, and for how long, the high volume sampling should be done. At the time I did not know. The next day I discussed this question with my supervisor and it was decided that modeling would be preferable to monitoring, but if the company chose to do the monitoring anyway, the more frequent schedule, and the larger the better. I informed Mike Tkach of this by phone the next day.

9-21-89

unglazed wt. 189.5 g/pc
glazed wt. 208.3 g/pc
glaze wt. 18.8 g/pc

RECEIVED
N.C. Dept. NRCD

SEP 22 1989

Winston-Salem
Regional Office

7am-9:00 am 2 hr
9:15 am-11:20 am 2 hr 5 min
11:50 am-2:00 pm 2 hr 10 min

from 7am-2pm, 60,293 pcs. of tile were spray

$60,293 \times 189.5 \text{ g/pc} = 25,166 \text{ lbs of unglazed tile}$

$60,293 \times 18.8 \text{ g/pc} = 2,496 \text{ lbs of glaze}$

$\frac{25,166 \text{ lbs}}{6.25 \text{ hrs}} = 4,026 \text{ lbs/hr unglazed tile}$

$\frac{2,496 \text{ lbs}}{6.25 \text{ hrs}} = 399 \text{ lbs/hr glaze}$

Process rate 9-20-89

Spray booth 2A

308 glaze

**SOURCE TEST
OBSERVERS CHECKLIST**

N. C. Division of Environmental Management / Air Quality Section

Source Name: <u>Manning Ceramic Tile</u> Address: <u>P.O. Box 1777</u> <u>Lexington 27293</u> Plant Location: <u>20 Victor St 27092</u> Source Contact: <u>Mike Tkach</u> Phone: <u>249-3931</u>	Testing Firm: <u>Entropy Environmentalists</u> Address: <u>P.O. Box 12291</u> <u>RTP, NC 27709</u> Phone: <u>(919) 781-3550</u> Test Engineer: <u>Noel Harden</u> Assistant: <u>Lee Matthews</u>
--	--

Other Personnel Involved <u>William E. Piske, P.E.</u>	Affiliation <u>Chas. T. Main, Inc.</u>
--	--

Process Description: <u>Spray Booth</u> <u># 2-A - Lead Colare</u> Process Rate During Test: <u>4425 lbs. per hr</u> Maximum Process Rate: <u>4425 lbs per hr</u> Burner Sizes (Incin.) Pri: <u> </u> Sec: <u> </u>	Soot Blowing Parameters: <u>N-A</u> A = <u> </u> Hr B = <u> </u> Hr R = <u> </u> Hr S = <u> </u> Hr A = Hours of soot blowing during sample(s) B = Hours not soot blowing during sample(s) containing soot blowing R = Average hours of operation per 24 hours S = Average hours of soot blowing per 24 hours
--	---

TEST PARAMETERS Duct Size: <u>20 inch</u> Distance Before Ports: <u>3 ft</u> Distance After Ports: <u>3 ft</u> Number of Test Points: <u>12 x 2</u> Number of Runs: <u>3</u> Sampling Time Per Run (min.): <u>60</u>	Pollutant Sampled: <u>Particulate</u> E. P. A. Method No.: <u>5</u> If method differs from E. P. A. method, explain: For Method 5 sampling train record ΔH_a <u>1.714</u> <u>Y 9803</u>
---	---

	Run #1	Run #2	Run #3
Leakage Rate (ft³/min.) (0.02 ft³/min. or less)	<u>0.001 P³/Hr</u>	<u>0.001 P³/Hr</u>	<u>0.000 P³/Hr</u>
Time Started 24 hr. Clock	<u>0827</u>	<u>1002</u>	<u>1258</u>
Time Ended	<u>0945</u>	<u>1104</u>	<u>1155</u>
Test Date(s)	<u>9/20/89</u>	<u>9/20/89</u>	<u>9/20/89</u>

See Graph on Reverse Side For Number of Test Points. Use Reverse Side for Comments.	Request 2 Copies of Report <u>Shannon M. J. Jones</u> OBSERVERS SIGNATURE
---	---

VISIBLE EMISSION OBSERVATION FORM

No. /

COMPANY NAME Manning Ceram Tile
 STREET ADDRESS 20 Victor St
 CITY Lexington STATE NC ZIP
 PHONE (KEY CONTACT) SOURCE ID NO.

PROCESS EQUIPMENT Spray Booth OPERATING MODE Lead Glass
 CONTROL EQUIPMENT OPERATING MODE

DESCRIBE EMISSION POINT Spray Booth Stack on Roof of Plant
 HEIGHT ABOVE GROUND 30 HEIGHT RELATIVE TO OBSERVER Start 0 End 0
 DISTANCE FROM OBSERVER Start End DIRECTION FROM OBSERVER Start End

DESCRIBE EMISSIONS
 Start Glaze Dust End
 EMISSION COLOR White IF WATER DROPLET PLUME Attached ☐ Detached ☐
 POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start Stack Exit End

DESCRIBE PLUME BACKGROUND
 Start Trees End
 BACKGROUND COLOR Green SKY CONDITION Cloudy
 WIND SPEED Start 5-10 End WIND DIRECTION
 AMBIENT TEMP Start 72°F End WET-BULB TEMP RH, percent 90% + Est

SOURCE LAYOUT SKETCH Draw North Arrow

Stack with Plume
 Sun
 Wind
 Emission Point
 Observer's Position
 Sun Location Line
 NO SUN
 140°

ADDITIONAL INFORMATION 15 second interval estimated

OBSERVATION DATE					START TIME		END TIME			
9-20-89					1100		1130			
SEC MIN	0	15	30	45	SEC MIN	0	15	30	45	
1	5	10	10	5	31					
2	10	10	5	5	32					
3	5	10	10	5	33					
4	5	10	5	5	34					
5	10	5	5	10	35					
6	10	5	5	5	36					
7	5	5	5	5	37					
8	5	10	10	10	38					
9	5	5	5	5	39					
10	5	10	5	5	40					
11	5	5	5	10	41					
12	5	10	10	5	42					
13	5	5	5	10	43					
14	5	5	5	5	44					
15	5	10	5	10	45					
16	5	10	5	10	46					
17	5	10	0	0	47					
18	0	0	5	5	48					
19	5	10	5	5	49					
20	5	5	5	5	50					
21	5	5	5	0	51					
22	10	5	5	5	52					
23	5	5	5	5	53					
24	5	5	5	5	54					
25	5	5	5	5	55					
26	5	5	5	5	56					
27	5	5	5	5	57					
28	0	5	0	0	58					
29	0	5	5	5	59					
30	0	0	0	5	60					

OBSERVER'S NAME (PRINT) Stephen M. Moore
 OBSERVER'S SIGNATURE Stephen M. Moore DATE 9-20-89
 ORGANIZATION NC Division of Env. Mgmt
 CERTIFIED BY DATE

CONTINUED ON VEO FORM NUMBER



State of North Carolina
Department of Natural Resources and Community Development
Winston-Salem Regional Office

James G. Martin, Governor

William W. Cobey, Jr., Secretary

DIVISION OF ENVIRONMENTAL MANAGEMENT

November 21, 1989

CERTIFIED MAIL NUMBER P-614 922 490
RETURN RECEIPT REQUESTED

Mr. Micheal Tkach, Plant Manager
Mannington Ceramic Tile
P.O. Box 1777
Lexington, N.C. 27293-1777

Dear Mr. Tkach:

Subject: Comments on Emissions Assessment Program
Mannington Ceramic Tile
Lexington, North Carolina
Davidson County

Reference is made to your program to assess the emissions from your facility and their impact on your neighbors. The following comments are offered:

1. The test report for the particulate and lead emissions stack test conducted September 20, 1989, on the spray booth 2A stack has been received at this office. A copy of the test report will be forwarded to our stack test unit in Raleigh for review. You will be notified of the results of that review when it is completed.
2. This office considers ambient dispersion modeling to be the most reliable method to predict the maximum pollutant impact from a facility. Due to the complaints received regarding your facility and our concern over the potential high level of emissions it is required that Mannington Ceramic Tile submit ambient dispersion modeling for total suspended particulate (TSP), particulate matter (PM₁₀) and lead. The modeling should address all significant sources of emission at Mannington Ceramic Tile as well as sources of significant emissions at neighboring facilities. Prior to modeling submittal, a modeling plan must be

Mr. Micheal Tkach
November 21, 198

Page 2

submitted to this Division for approval. You should contact Mr. Kevin Eldridge, Air Quality Section Meteorologist, (919) 733-3340, to discuss modeling requirements and details of the modeling plan.

3. It is my understanding that Mannington Ceramic Tile has set up several particulate samplers. While the data from these samplers may be useful, the value of the data is limited unless the sampling program complies with Section 1.6 of "Procedures for Standard Operation and Quality Assurance" (QA Plan) (copy enclosed). If the QA plan is not followed, the data cannot be used to document compliance or noncompliance. If Mannington wishes to use the data for compliance purposes you should make sure that your sampling program meets the requirements of the QA plan.
4. There is no air permit for Mannington Ceramic Tile. Permit No. 5408R, which is the last permit issued that covers your equipment, was issued to Mid-State Tile Company. Mannington Ceramic Tile should request that Permit No. 5408R be reissued in its name, describing any changes or modifications that have occurred since its last issuance. A check for \$25.00 should accompany the request.

Please submit the required information as soon as possible. If you have any questions, please call Steve Moser or me.

Sincerely,



Myron G. Whitley
Regional Engineer
Air Quality Section

MGW/ahl

cc: Lee Daniel
Kevin Eldridge
~~Mike Aldridge~~
Jim Critopoulos - EPA

TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTION	
1.1 Outline of Test Program	1-1
1.2 Test Participants	1-1
SUMMARY OF RESULTS	
2.1 Presentation	2-1
2.2 Cyclonic Flow Check	2-1
2.3 Average Emission Rates	2-1
PROCESS DESCRIPTION AND OPERATION	
3.1 General	3-1
3.2 Source Air Flow	3-1
3.3 Operation During Testing	3-1
SAMPLING AND ANALYTICAL PROCEDURES	
4.1 General	4-1
4.2 Sampling Points	4-1
4.3 Cyclonic Flow Check	4-1
4.4 Volumetric Air Flow Rates	4-1
4.4.1 Flue Gas Velocity	4-1
4.4.2 Flue Gas Composition	4-1
4.4.3 Flue Gas Moisture Content	4-1
4.5 Emissions Determinations	4-1
4.6 Equipment Calibration	4-1
APPENDICES	
A. Test Results and Example Calculations	1
B. Field and Analytical Data	7
C. Calibration Data	20
D. Process Data	34
E. Sampling and Analytical Procedures	37

INTRODUCTION

1.1 Outline of Test Program. Stationary source sampling was performed for Mannington Ceramic Tile, Inc. at their facility in Lexington, North Carolina on September 20, 1989. Three sets of combined EPA Methods 5 and 12 runs were performed at the spray booth 2A stack to determine the lead and particulate emissions.

1.2 Test Participants. Table 1-1 lists the personnel present during the test program.

TABLE 1-1
TEST PARTICIPANTS

Mannington Ceramic Tile, Inc.

Michael Tkach
Test Coordinator

North Carolina Dept. of Environment,
Health, and Natural Resources

Steve Moser
Test Observer

Entropy Environmentalists Inc.

Neill M. Harden
Project Manager

R. Lee Marchman
Engineering Technician

SUMMARY OF RESULTS

2.1 Presentation. Table 2-1 summarizes the results of lead and particulate emissions testing performed on September 20, 1989, at the spray booth 2A stack. Detailed test results are presented in Appendix A; field and analytical data are given in Appendix B.

2.2 Cyclonic Flow Check. Prior to testing, a cyclonic flow check was performed at the spray booth 2A stack to determine if any cyclonic flow existed at the sampling location. An average yaw angle of less than 2° was measured, indicating an acceptable location with respect to EPA Method 1 requirements.

2.3 Average Emission Rates. The average lead and particulate emission rates for the test program were 0.599 and 3.86 pounds per hour, respectively.

TABLE 2-1

LEAD AND PARTICULATE TESTS SUMMARY

Spray Booth 2A Stack

	M5&12-1	M5&12-2	M5&12-3
	-----	-----	-----
Run Date	8/20/89	9/20/89	9/20/89
Run Start Time	827	1002	1155
Run Finish Time	945	1104	1258
<u>Test Train Parameters:</u>			
Volume Of Dry Gas Sample, SCF *	44.230	44.410	49.730
Percent Isokinetic	100.9	100.0	101.9
<u>Flue Gas Parameters:</u>			
Temperature, °F	78	77	74
Air Flow Rate, Dry SCFM *	4,225	4,555	4,705
Air Flow Rate, Wet ACFM	4,502	4,881	5,019
<u>Lead:</u>			
Concentration, ppmvd	4.63	3.92	3.87
Emission Rate, lb/hr	0.632	0.577	0.588
<u>Filterable Particulate:</u>			
Concentration, grains/DSCF *	0.111	0.0950	0.0951
Emission Rate, lb/hr	4.03	3.71	3.84

* 68° F -- 29.92 Inches of Mercury (Hg).

PROCESS DESCRIPTION AND OPERATION

3.1 General. Mannington Ceramic Tile, Inc. sprays glaze on ceramic tile at their facility in Lexington, North Carolina.

3.2 Source Air Flow. Figure 3-1 is an air flow schematic which shows the passage of flue gases exhausted from spray booth 2A.

3.3 Operation During Testing. The production rate during testing was 4,026 lb/hr of tile and 399 lb/hr of glaze. Process data supplied by Mannington is presented in Appendix D.




FIGURE 3-1. SPRAY BOOTH 2A AIR FLOW SCHEMATIC.

SAMPLING AND ANALYTICAL PROCEDURES

4.1 General. All sampling and analytical procedures were those recommended by the United States Environmental Protection Agency and the North Carolina Department of Environment, Health, and Natural Resources. This section provides brief descriptions of the sampling and analytical procedures. Detailed descriptions of the procedures are provided in Appendix E.

4.2 Sampling Points. The number and location of the sampling points were determined according to EPA Method 1. The stack cross section was divided into 24 equal areas with 12 sampling points on each of two traverse axes, as shown in Figure 4-1.

4.3 Cyclonic Flow Check. A Type S pitot tube assembly, Magnehelic gauges, and a universal protractor (angle finder) were used to determine the nonvertical flow angles at each of the 24 points. At each point, the pitot tube was positioned at a right angle to vertical. The angles were determined by rotating the pitot tube until a null reading was obtained on the Magnehelic gauges. When the null reading was obtained, the angle of the pitot tube was recorded.

4.4 Volumetric Air Flow Rates

4.4.1 Flue Gas Velocity. EPA Method 2 was used to take the velocity measurements during the traverses of the stack cross section.

4.4.2 Flue Gas Composition. The flue gas composition and molecular weight were assumed to be that of ambient air.

4.4.3 Flue Gas Moisture. Moisture content was determined by analyzing the sampling train impinger reagents according to the procedures outlined in EPA Method 5.

4.5 Emissions Determinations. A combined EPA Methods 5 and 12 sampling train was used to determine the lead and particulate emissions. The sampling train was modified by using 100 ml of 0.1 N nitric acid in the first and second impingers. The particulate analysis was performed according to EPA Method 5. The lead analysis was performed according to EPA Method 12. Each of the 24 points was sampled for 2.5 minutes, resulting in net run times of 60 minutes.

4.6 Equipment Calibration. Pertinent calibration data are provided in Appendix C.

TRAVERSE POINTS

2 AXES
12 POINTS/AXIS
24 TOTAL POINTS



SECTION K-K

FIGURE 4-1. SPRAY BOOTH 2A STACK TEST LOCATION.

TEST RESULTS AND EXAMPLE CALCULATIONS

FIELD DATA AND RESULTS TABULATION

PLANT: Mannington Ceramic Tile, Inc., Lexington, North Carolina

2

RUN #	DATE	SAMPLING LOCATION	OPERATOR		
M5&12-1	8/20/89	Spray Booth 2A Stack	Neill M. Harden		
M5&12-2	9/20/89	Spray Booth 2A Stack	Neill M. Harden		
M5&12-3	9/20/89	Spray Booth 2A Stack	Neill M. Harden		
			M5&12-1	M5&12-2	M5&12-3
	Run Start Time		827	1002	1155
	Run Finish Time		945	1104	1258
	Net Traversing Points		24	24	24
Theta	Net Run Time, Minutes		60.00	60.00	60.00
Dia	Nozzle Diameter, Inches		0.263	0.255	0.263
Cp	Pitot Tube Coefficient		0.840	0.840	0.840
Y	Dry Gas Meter Calibration Factor		0.9863	0.9863	0.9863
Pbar	Barometric Pressure, Inches Hg		29.20	29.20	29.20
Delta-H	Avg. Pressure Differential of Orifice Meter, Inches H ₂ O		1.85	1.88	2.30
Vm	Volume Of Metered Gas Sample, Dry ACF		48.008	49.940	55.572
tm	Dry Gas Meter Temperature, Degrees F		94	114	111
Vmstd	Volume Of Metered Gas Sample, Dry SCF*		44.230	44.410	49.730
Vlc	Total Volume of Liquid Collected in Impingers & Silica Gel, ml		19.5	26.0	30.5
Vwstd	Volume of Water Vapor, SCF*		0.918	1.224	1.436
%H ₂ O	Moisture Content, Percent by Volume		2.0	2.7	2.8
Mfd	Dry Mole Fraction		0.980	0.973	0.972
Md	Gas Molecular Weight, lb/lb-Mole, Dry		28.84	28.84	28.84
Ms	Gas Molecular Weight, lb/lb-Mole, Wet		28.62	28.55	28.54
Pg	Flue Gas Static Pressure, Inches H ₂ O		-0.20	-0.15	-0.21
Ps	Absolute Flue Gas Pressure, Inches Hg		29.19	29.19	29.18
ts	Flue Gas Temperature, Degrees F		78	77	74
Delta-p	Average Velocity Head, Inches H ₂ O		0.3561	0.4182	0.4446
vs	Flue Gas Velocity, Feet/Second		34.39	37.28	38.34
A	Stack/Duct Area, Square Inches		314.2	314.2	314.2
Qsd	Volumetric Air Flow Rate, Dry SCFM*		4,225	4,555	4,705
Qaw	Volumetric Air Flow Rate, Wet ACFM		4,502	4,881	5,019
%I	Isokinetic Sampling Rate, Percent		100.9	100.0	101.9

* 68° F -- 29.92 Inches of Mercury (Hg)

(Continued next page)

FIELD DATA AND RESULTS TABULATION

(Continued)

3

PLANT: Mannington Ceramic Tile, Inc., Lexington, North Carolina

		M5&12-1	M5&12-2	M5&12-3
		-----	-----	-----
	<u>Lead</u>			
fw	Formula Weight, lb/lb-Mole	207.19	207.19	207.19
mg	Catch Weight, Milligrams	50	42.5	47
ppmvd	Concentration, ppmvd	4.63	3.92	3.87
lb/hr	Emission Rate, lb/hr	0.632	0.577	0.588
	<u>Filterable Particulate</u>			
mg	Catch Weight, Milligrams	318.6	273.5	306.6
gr/DSCF	Concentration, grains/DSCF *	0.111	0.0950	0.0951
lb/hr	Emission Rate, lb/hr	4.03	3.71	3.84

* 68° F -- 29.92 Inches of Mercury (Hg)

Spray Booth 2A Stack

VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS

$$Vmstd = 17.64 * Y * Vm * \frac{Pbar + (\Delta H/13.6)}{(460 + tm)}$$

$$Vmstd = 17.64 * 0.9863 * 48.008 * \frac{29.20 + (1.850/13.6)}{(460 + 94)} = 44.230 \text{ DSCF}$$

VOLUME OF WATER VAPOR AT STANDARD CONDITIONS

$$Vwstd = 0.04707 * Vlc$$

$$Vwstd = 0.04707 * 19.5 = .918 \text{ SCF}$$

PERCENT MOISTURE, BY VOLUME, AS MEASURED IN FLUE GAS

$$\%H_2O = 100 * Vwstd / (Vwstd + Vmstd)$$

$$\%H_2O = \frac{0.918}{0.918 + 44.230} * 100 = 2.0 \%$$

ABSOLUTE FLUE GAS PRESSURE

$$Ps = Pbar + (Pg / 13.6)$$

$$Ps = 29.20 + (-0.20/13.6) = 29.19 \text{ inches Hg}$$

DRY MOLE FRACTION OF FLUE GAS

$$Mfd = 1 - \%H_2O / 100$$

$$Mfd = 1 - 2.0/100 = 0.980$$

DRY MOLECULAR WEIGHT OF FLUE GAS

$$Md = (\%CO_2/100 * 44) + (\%O_2/100 * 32) + ((100 - \%CO_2 - \%O_2)/100 * 28)$$

$$Md = (0.0/100 * 44) + (20.9/100 * 32) + ((100 - 0.0 - 20.9)/100 * 28)$$

$$Md = 28.84 \text{ lb/lb-Mole}$$

WET MOLECULAR WEIGHT OF FLUE GAS

$$Ms = (Md * Mfd) + (0.18 * \%H_2O)$$

$$Ms = (28.84 * 0.980) + (0.18 * 2.0) = 28.62 \text{ lb/lb-Mole}$$

AVERAGE FLUE GAS VELOCITY [Note: (Delta p)avg is square of average square root]

$$v_s = 85.49 * C_p * \text{SQUARE ROOT} \left[\frac{(\Delta P)_{\text{avg}} * (460 + t_s)}{P_s * M_s} \right]$$

$$v_s = 85.49 * 0.840 * \text{SQUARE ROOT} \left[\frac{0.3561 * (460 + 78)}{29.19 * 28.62} \right] = 34.39 \text{ ft/sec}$$

DRY VOLUMETRIC FLUE GAS FLOW RATE AT STANDARD CONDITIONS

$$Q_{sd} = \frac{60}{144} * M_{fd} * v_s * A * \frac{T_{std}}{460 + t_s} * \frac{P_s}{P_{std}}$$

$$Q_{sd} = \frac{60}{144} * 0.980 * 34.39 * 314.2 * \frac{528}{460 + 78} * \frac{29.19}{29.92}$$

$$Q_{sd} = 4,225 \text{ SCFM}$$

WET VOLUMETRIC FLUE GAS FLOW RATE AT STANDARD CONDITIONS

$$Q_{aw} = 60 / 144 * v_s * A$$

$$Q_{aw} = 60 / 144 * 34.39 * 314.2 = 4,502 \text{ ACFM}$$

PERCENT ISOKINETIC OF SAMPLING RATE

$$\%I = \frac{P_{std}}{T_{std}} * \frac{100}{60} * \frac{(t_s + 460) * V_{mstd}}{P_s * v_s * M_{fd} * \Theta * (\pi * (\text{NozzleDia}/2)^2 / 144)}$$

$$\%I = \frac{29.92}{528} * \frac{100}{60} * \frac{(78 + 460) * 44.230}{29.19 * 34.39 * 0.980 * 60.00 * (\pi * (0.263/2)^2 / 144)}$$

$$\%I = 100.9 \%$$

CONCENTRATION, PARTS PER MILLION BY VOLUME DRY, LEAD

$$\text{ppmvd} = \frac{385.3 * 10^6 * (\text{mg}/10^3)}{453.592 * \text{Mol. Wt.} * V_{mstd}}$$

$$\text{ppmvd} = \frac{385.3 * 10^6 * (50.0/10^3)}{453.592 * 207.19 * 44.230} = 4.63 \text{ ppmvd}$$

EMISSION RATE, POUNDS PER HOUR, LEAD

$$\text{lb/hr} = \frac{60}{453.592} * \frac{(\text{mg} / 10^3)}{V_{mstd}} * Q_{sd}$$

$$\text{lb/hr} = \frac{60}{453.592} * \frac{(50.0/10^3)}{44.230} * 4,225 = 0.632 \text{ lb/hr}$$

CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT, FILTERABLE PARTICULATE

$$\text{gr/DSCF} = \frac{7,000}{453.592} * \frac{(\text{mg} / 10^3)}{\text{Vmstd}}$$

$$\text{gr/DSCF} = \frac{7,000}{453.592} * \frac{(318.6/10^3)}{44.230} = 0.111 \text{ gr/DSCF}$$

FIELD AND ANALYTICAL DATA

Preliminary Field Data

8

SAMPLING

PLANT NAME MANNINGTON TILE
 LOCATION SPRAY BOOTH ZA STACK
 SAMPLING LOCATION LEXINGTON, NC

NO. OF PORTS 2
 PORT INSIDE DIAMETER 3"

DUCT DEPTH
 FROM INSIDE FAR WALL TO OUTSIDE OF PORT 20
 NIPPLE LENGTH 0
 DEPTH OF DUCT 20
 WIDTH (RECTANGULAR DUCT) _____

EQUIVALENT DIAMETER:
 $D_e = \frac{2 \times \text{DEPTH} \times \text{WIDTH}}{\text{DEPTH} + \text{WIDTH}} = \frac{2(20)(10)}{20 + 10} = 13.3$

DISTANCE FROM UPSTREAM DOWNSTREAM
 PORTS TO NEAREST FLOW DISTURBANCE 60" 60"
 DIAMETERS 3 3

STACK AREA = $\pi(100)$ = 314 IN²

LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS


	4	6	8	10	12	14	16	18	20	22	24
1	6.7	4.4	3.2	2.8	2.1	1.8	1.8	1.4	1.3	1.1	1.1
2	25.0	14.8	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3	75.0	29.6	19.4	14.8	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4	93.3	70.4	32.3	22.8	17.7	14.6	12.5	10.9	9.7	8.7	7.9
6		85.4	67.7	34.2	25.0	20.1	18.9	14.8	12.9	11.8	10.5
8		95.8	80.8	65.8	35.6	28.9	22.0	18.8	16.5	14.6	13.2
7		89.5	77.4	64.4	38.6	28.3	23.6	20.4	18.0	16.1	
8			96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9				91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10				97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11					93.3	85.4	78.0	70.4	61.2	39.3	32.3
12					97.9	90.1	83.1	76.4	69.4	60.7	39.8
13						94.3	87.5	81.2	75.0	68.5	60.2
14						98.2	91.5	85.4	79.6	73.8	67.7
16							95.1	89.1	83.5	78.2	72.8
16							98.4	92.5	87.1	82.0	77.0
17								95.6	90.3	85.4	80.6
18								98.6	93.3	88.4	83.9
19									96.1	91.3	86.8
20									98.7	94.0	89.5
21										96.5	92.1
22										98.9	94.5
23											96.8
24											98.9

LOCATION OF TRAVERSE POINTS IN RECTANGULAR STACKS

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	28.2
5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6					91.7	78.8	68.8	61.1	55.0	50.0	45.8
7						92.9	81.3	72.2	65.0	59.1	54.2
8							93.8	83.3	75.0	68.2	62.5
9								94.4	85.0	77.3	70.8
10									95.0	86.4	79.2
11										95.5	87.5
12											95.8

DRAW HORIZONTAL LINE THROUGH DIAMETER

If more than 8 and 2 diameters and if duct dia. is less than 24", use 8 or 9 points.



POINT	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL	DISTANCE FROM OUTSIDE OF PORT
1	2.1	$\frac{1}{2}$ "	SAME
2	6.7	$1\frac{3}{8}$	
3	11.8	$2\frac{3}{8}$	
4	17.7	$3\frac{1}{2}$	
5	25.0	5	
6	35.6	$7\frac{1}{8}$	
7	64.4	$12\frac{7}{8}$	
8	75.0	15	
9	82.3	$16\frac{1}{2}$	
10	85.2	$17\frac{3}{8}$	
11	93.3	$18\frac{5}{8}$	
12	92.9	$19\frac{1}{2}$	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			

YAW ANGLE DATA
FOR CASES OF NON-STREAMLINED FLOW

9

Plant name MANNINGTON TILE

Date 9-20-89

Plant location LEXINGTON, NC

Initials MM

Measurement site SPRAY BOOTH ZA STACK

Pitot type S

POINT	PORT A	PORT B	PORT C	PORT D	PORT E	PORT F	PORT G
1	-5	0					
2	-4	0					
3	0	0					
4	-4	+4					
5	-4	+4					
6	-4	-4					
7	0	-3					
8	0	0					
9	0	0					
10	0	0					
11	-4	0					
12	0	-3					

Average of absolute values of all angles = 1.79

ISOKINETIC TYPE FIELD DATA SHEET

10

COMPANY NAME MANNINGTON TILE RUN NUMBER M5812-1
 ADDRESS LEXINGTON, NC TIME START 0827
 SAMPLING LOCATION SPRAY BOOTH 2A STACK TIME FINISH 0945
 DATE 9-20-89 TEAM LEADER LM TECHNICIANS LM
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE IN. H₂O -0.20
 TRAIN LEAK CHECK VACUUM IN. HG 15 3(F)
 TRAIN LEAK RATE, CU.FT/MIN 0.010 0.001

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS				LEAK CHECK READINGS	
☒	PITOTS, PRETEST	REAGENT BOX	<u>203</u>	NOZZLE	<u>705</u>	DIAMETER	<u>0.263</u>
☒	PITOTS, POSTTEST	METER BOX	<u>29</u>	T/C READOUT	<u>F69</u>		
☐	M3 SAMPLING SYS/TED BAG	UMBILICAL	<u>U6</u>	T/C PROBE	<u>6-4</u>		
☒	THERMOCOUPLE @ <u>68</u> PRE	SAMPLE BOX	<u>21</u>	ORSAT PUMP	<u>---</u>		
☒	THERMOCOUPLE @ <u>75</u> POST	PROBE	<u>3-9</u>	PITOT	<u>---</u>	TEDLAR BAG	<u>---</u>
FILTER # <u>E8446</u> TARE <u>0.5041</u>		DELTA Hg	<u>1.714</u>			FYRITE	
		METER TEMP	<u>80</u>	<u>95</u>			
		EST. %H ₂ O	<u>2</u>				
		C FACTOR	<u>0.99</u>	<u>1.01</u>			
		STACK TEMP	<u>78</u>				
		REF DELTA P	<u>0.37</u>	<u>0.365</u>			
		K-FACTOR				<u>Cpl. 84</u>	

LINE	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READINGS CUBIC FEET	PITOT READING IN. H ₂ O	ORIFICE SETTING IN. H ₂ O		GAS METER TEMP. °F	VACUUM IN. HG GAUGE	GAS TEMPERATURES		STACK TEMP. °F	LK CHK
					IDEAL	ACTUAL			FILTER BOX °F	IMPINGER EXIT °F		
1	A1	0	127.420	0.34	1.70	1.70	71	1	255	60	75	
2	2	2½	129.41	0.42	2.10	2.10	74	1	260	60	76	
3	3	5	131.52	0.57	2.80	2.80	79	1	250	60	77	
4	4	7½	134.33	0.62	3.05	3.05	84	1	235	60	77	
5	5	10	136.39	0.63	3.10	3.10	86	1	235	60	77	
6	6	12½	139.41	0.52	2.60	2.60	88	1	240	60	77	
7	7	15	141.52	0.28	1.40	1.40	91	1	240	60	78	
8	8	17½	143.43	0.23	1.15	1.15	92	1	245	60	78	
9	9	20	144.99	0.18	0.89	0.89	92	1	245	60	78	
10	10	22½	146.52	0.17	0.83	0.83	93	1	245	56	78	
11	11	25	147.45	0.16	0.77	0.77	95	1	245	56	78	
12	12	27½	149.25	0.16	0.77	0.77	96	1	250	56	78	
13	B1	30/0	150.573	0.26	1.27	1.27	97	1	245	55	78	
14	2	2½	152.02	0.40	1.98	1.98	96	1	245	55	78	
15	3	5	154.69	0.38	1.91	1.91	97	1	245	55	78	
16	4	7½	156.21	0.40	1.98	1.98	97	1	240	58	79	
17	5	10	158.16	0.42	2.14	2.14	98	1	245	58	79	
18	6	12½	160.36	0.43	2.20	2.20	100	1	235	60	79	
19	7	15	162.63	0.44	2.27	2.27	102	1	235	60	79	
20	8	17½	164.88	0.43	2.20	2.20	103	1	235	60	79	
21	9	20	167.14	0.38	1.91	1.91	104	1	235	60	79	
22	10	22½	169.38	0.37	1.90	1.90	104	1	240	62	79	
23	11	25	171.38	0.32	1.63	1.63	106	1	240	62	79	
24	12	27½	173.52	0.34	1.78	1.78	107	1	240	62	78	
25		60/OFF	175.428									

STOP
0900
STACK
041.F1010
9/89
pl

60 48.008 0.3561 1.85 94 78
 minutes Vm (V/P)² /H cm ca

ENTROPY

ISOKINETIC TYPE FIELD DATA SHEET

11

COMPANY NAME MANNINGTON TILE RUN NUMBER M5812-2
 ADDRESS LEXINGTON, NC TIME START 1002
 SAMPLING LOCATION SPRAY BOOTH ZA STACK TIME FINISH 1104
 DATE 9-20-89 TEAM LEADER MYT TECHNICIANS LM
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE IN. H₂O -0.15
 TRAIN LEAK CHECK VACUUM IN. HG 15 5F
 TRAIN LEAK RATE, CU.FT/MIN 0.003 0.001

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS		LEAK CHECK READINGS	
☒ PITOTS, PRETEST		REAGENT BOX <u>203</u>	NOZZLE <u>706</u>	DIAMETER <u>0.255</u>	
☒ PITOTS, POSTTEST		METER BOX <u>N9</u>	T/C READOUT <u>E69</u>		
☐ M3 SAMPLING SYS/TED BAG		UMBILICAL <u>U6</u>	T/C PROBE <u>5-14</u>		
☒ THERMOCOUPLE @ <u>75</u> PRE		SAMPLE BOX	ORSAT PUMP		
☒ THERMOCOUPLE @ <u>15</u> POST		PROBE <u>3-6</u>	PITOT	TEDLAR BAG	

FILTER #	TARE	DELTA H _g	METER TEMP	EST. %H ₂ O	C FACTOR	STACK TEMP	REF DELTA P	K-FACTOR	FYRITE	C _p
<u>E8447</u>	<u>0.5023</u>	<u>1.714</u>	<u>105</u>	<u>2</u>	<u>1.02</u>	<u>80</u>	<u>0.42</u>			<u>0.84</u>

L I N E	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READINGS CUBIC FEET	PITOT READING IN. H ₂ O	ORIFICE SETTING IN. H ₂ O		GAS METER TEMP. °F	VACUUM IN. HG GAUGE	GAS TEMPERATURES		STACK TEMP. °F	LK CHK #
					IDEAL	ACTUAL			FILTER BOX °F	IMPINGER EXIT °F		
1	A1	0	175.588	0.42	1.84	1.84	103	1	230	60	75	
2	2	2½	177.44	0.59	2.60	2.60	105	1	235	60	75	
3	3	5	180.20	0.63	2.75	2.75	107	1	250	60	74	
4	4	7½	182.82	0.69	3.00	3.00	109	1	255	60	76	
5	5	10	185.69	0.67	2.90	2.90	112	1	255	58	76	
6	6	12½	188.04	0.58	2.58	2.58	109	1	250	58	79	
7	7	15	190.64	0.36	1.60	1.60	114	1	250	58	80	
8	8	17½	192.25	0.33	1.48	1.48	114	1	250	58	80	
9	9	20	194.29	0.30	1.30	1.30	115	1	245	55	80	
10	10	22½	195.95	0.29	1.27	1.27	115	1	245	55	79	
11	11	25	197.76	0.28	1.22	1.22	115	1	245	55	80	
12	12	27½	199.35	0.28	1.22	1.22	115	1	245	55	79	
13	B1	30/0	201.056	0.37	1.63	1.63	115	1	245	52	76	
14	2	2½	202.98	0.37	1.63	1.63	116	1	245	52	76	
15	3	5	205.05	0.39	1.75	1.75	116	1	245	52	76	
16	4	7½	207.11	0.41	1.81	1.81	117	1	245	52	76	
17	5	10	209.12	0.44	1.94	1.94	118	1	240	50	77	
18	6	12½	211.06	0.48	2.10	2.10	118	1	240	50	77	
19	7	15	213.50	0.43	1.90	1.90	118	1	245	53	76	
20	8	17½	215.50	0.45	1.99	1.99	119	1	245	53	77	
21	9	20	217.82	0.39	1.75	1.75	119	1	245	53	77	
22	10	22½	219.35	0.35	1.56	1.56	119	1	245	53	78	
23	11	25	221.74	0.35	1.56	1.56	119	1	245	53	77	
24	12	27½	223.55	0.37	1.64	1.64	119	1	245	53	78	
25		60/0FF	225.528									

F1010
9/89
pl160
minutes49.940
V_m0.4182
(V/ΔP)²1.98
ΔP

cm

77
cs

ENTROPY

ISOKINETIC TYPE FIELD DATA SHEET

12

COMPANY NAME MANWINGTON TILE RUN NUMBER MS12-3
 ADDRESS LEXINGTON, NC TIME START 1155
 SAMPLING LOCATION SPRAY BOOTH 2-A STACK TIME FINISH 1258
 DATE 9-20-89 TEAM LEADER MM TECHNICIANS LM
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE IN. H₂O -0.21
 TRAIN LEAK CHECK VACUUM IN. HG 15 35(F)
 TRAIN LEAK RATE, CU.FT/MIN 0.004 0.001

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS		LEAK CHECK READINGS	
☒	PITOTS, PRETEST	REAGENT BOX	<u>203</u> NOZZLE	<u>705</u> DIAMETER	<u>0.263</u>
☒	PITOTS, POSTTEST	METER BOX	<u>N 9</u>	T/C READOUT	<u>F 69</u>
☐	M3 SAMPLING SYS/TED BAG	UMBILICAL	<u>U 6</u>	T/C PROBE	<u>6-4</u>
☒	THERMOCOUPLE @ <u>78</u> PRE	SAMPLE BOX	<u>21</u>	ORSAT PUMP	<u>—</u>
☒	THERMOCOUPLE @ <u>78</u> POST	PROBE	<u>3-9</u>	PITOT	<u>—</u>
				TEDLAR BAG	<u>—</u>

FILTER #	TARE	DELTA H _g	METER TEMP	EST. %H ₂ O	C FACTOR	STACK TEMP	REF DELTA P	K-FACTOR	FYRITE
<u>E8448</u>	<u>0.5056</u>	<u>1.714</u>	<u>105</u>	<u>2</u>	<u>1.02</u>	<u>80</u>	<u>0.365</u>	<u>—</u>	<u>—</u>

L I N E	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READINGS CUBIC FEET	PITOT READING IN. H ₂ O	ORIFICE SETTING IN. H ₂ O		GAS METER TEMP. °F	VACUUM IN. HG GAUGE	GAS TEMPERATURES		STACK TEMP. °F	LX CHK #
					IDEAL	ACTUAL			FILTER BOX °F	IMPINGER EXIT °F		
1	A1	0	225.642	0.58	2.90	2.90	97	2	235	60	76	
2	2	2½	228.25	0.59	2.94	2.94	98	2	235	60	77	
3	3	5	230.84	0.68	3.40	3.40	101	3	235	60	75	
4	4	7½	233.60	0.71	3.65	3.65	103	3	235	60	74	
5	5	10	236.00	0.68	3.40	3.40	104	3	235	56	74	
6	6	12½	239.01	0.60	3.10	3.10	107	3	240	56	74	
7	7	15	241.72	0.45	2.37	2.37	108	3	240	56	74	
8	8	17½	244.21	0.40	2.10	2.10	109	2	240	56	74	
9	9	20	246.51	0.35	1.81	1.81	110	3	240	56	73	
10	10	22½	248.63	0.37	1.89	1.89	111	3	240	56	74	
11	11	25	250.71	0.37	1.89	1.89	112	2	240	56	74	
12	12	27½	252.80	0.37	1.89	1.89	112	2	240	53	74	
13	B1	30/0	255.13	0.38	1.91	1.91	112	2	240	54	74	
14	2	2½	257.25	0.29	1.45	1.99	112	2	240	55	74	
15	3	5	259.31	0.42	2.11	2.11	113	2	240	54	75	
16	4	7½	261.91	0.42	2.11	2.11	113	2	242	55	74	
17	5	10	263.93	0.46	2.30	2.30	115	2	240	55	74	
18	6	12½	266.90	0.49	2.51	2.51	116	2	240	55	74	
19	7	15	268.57	0.48	2.00	2.00	117	2	240	56	74	
20	8	17½	270.92	0.38	1.95	1.95	117	2	240	55	74	
21	9	20	272.00	0.37	1.89	1.59	118	2	240	55	75	
22	10	22½	273.25	0.34	1.77	1.75	118	2	245	57	75	
23	11	25	277.32	0.34	1.75	1.75	119	2	245	57	75	
24	12	27½	279.41	0.30	1.51	1.51	119	2	245	57	75	
25		64OFF	281.264	0.30	1.51	1.51	118	2	245	57	75	

F1010
9/89.
pl60
minutes55.572
V_m0.4446
(V_AP)²2.30
ΔH
cm74
t_s

ENTROPY

MOISTURE SAMPLING LABORATORY RESULTS

Plant Name: MANNINGTON CERAMIC TILE

EEI Ref# 6445

Sampling Location: Spray Booth 2A Stack

Date Received: 9/21 Date Analyzed: 9/21 Reagent Box(es): 0203

Run Number	M5A12-1	M5A12-2	M5A12-3
Run Date	9/20	9/20	9/20

ANALYSIS OF MOISTURE CATCH

Reagent 1 (0.1N HNO3)			
Final Weight, g.	587.0	570.5	593.5
Tared Weight, g.	579.5	555.0	575.5
	=====	=====	=====
Water Catch, g.	7.5	15.5	18.0
Reagent 2 ()			
Final Weight, g.			
Tared Weight, g.			
	=====	=====	=====
Water Catch, g.	0.0	0.0	0.0
Reagent 3 ()			
Final Weight, g.			
Tared Weight, g.			
	=====	=====	=====
Water Catch, g.	0.0	0.0	0.0
CONDENSED WATER, g.	7.5	15.5	18.0
Silica Gel:			
Final Weight, g.	212.0	210.5	212.5
Tared Weight, g.	200.0	200.0	200.0
	=====	=====	=====
ADSORBED WATER, g.	12.0	10.5	12.5
TOTAL WATER COLLECTED, g.	19.5	26.0	30.5

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name: MANNINGTON CERAMIC TILE

EEI Ref# 6445

Sampling Location: Spray Booth 2A Stack

Date Received: 9/21 Date Analyzed: 9/26 Reagent Box(es): 0203

Run Number	M5&12-1	M5&12-2	M5&12-3
Run Date	9/20	9/20	9/20
Sample ID/Container #	F / 1177 =====	F / 1178 =====	F / 1179 =====
	78.0182	83.1582	82.2594
	✓ 78.0178	✓ 83.1579	✓ 82.2593
	78.0189	83.1591	82.2606
Tare Weight.. g.	77.3497	82.4613	81.6161
	=====	=====	=====
SAMPLE WT., g.	0.6681	0.6966	0.6432
Sample ID/Container #	R / 2255 =====	R / 2256 =====	R / 2257 =====
	103.4262	✓ 101.3087	✓ 104.2574
	✓ 103.4259	101.3089	104.2578
	103.4311	101.3102	104.2630
Tare Wt., g.	103.2710	101.2291	104.0880
	=====	=====	=====
SAMPLE WT., g.	0.1549	0.0796	0.1694
Sum of Particulate, mg.	823.0	776.2	812.6
Total Filter Tare, mg.	504.1	502.3	505.6
Blank Residue, mg. (150 ml)	0.3 (175 ml)	0.4 (200 ml)	0.4
	=====	=====	=====
TOTAL PARTICULATE CATCH, mg.	318.6	273.5	306.6

Blank Beaker # 2003
 Final wt., mg. 99546.3
 Tare wt., mg. 99545.9
 Residue, mg. 0.4
 Volume, ml. 200

---Legend---
 ✓ = Final Weight
 L = Loose Particulate
 F = Filter D = Dish
 R = Rinse P = Pan

Notes and Comments

Concentration, mg/ml 0.002

ENTROPY

Oxford Laboratories, Inc.

Analytical and Consulting Chemists

DATE RECEIVED 9-29-88
DATE REPORTED 10-20-89
89W81441316 South Fifth Street
Wilmington, N.C. 28401
(919) 763-9793

PAGE 1 OF 1

ENTROPY ENVIRONMENTALIST INC
P.O. BOX 12291
RESEARCH TRIANGLE PK , N.C. 27709-2291

P.O. # 6445A-1


ATTENTION: BRUCE HAWKS

SAMPLE DESCRIPTION: M5/12 0.1N NaOH

1. M5/12-1
2. M5/12-2
3. M5/12-3
4. METHOD CODE

RESULTS

	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
Lead, as Pb, total mg	50.0	42.5	47.0	SW846-7000


ROGER C. OXFORD , CHEMIST

method code SW846-7000

P.O # 6445A-1

Entropy

10-3-89
89W 8146

#1

#2

#3

Pb $10.0 \times 50 \times 100 \div 1000$
50.0 mg

$8.5 \times 50 \times 100 \div 1000$
42.5 mg

$9.4 \times 50 \times 100 \div 1000$
47.0

Samples prepared by digesting in
 HNO_3 . Final volume = 100 ml

CUSTODY SHEET FOR REAGENT BOX # 0203

Date of Makeup 14 Sept 1989 Initials BxH Locked? ☒
 Individual Tare of Reagent: 200 mls. of 0.1N HNO₃
 Individual Tare of Reagent: _____ mls. of _____
 Individual Silica Gel Tare Weight 200 gms.

PLANT NAME MANNINGTON TIE (LEXINGTON, NC)
 SAMPLING LOCATION MS/12 SPRAY BOOTH 2-A STACK

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
MS/12-1	9/20/89	LM	✓	9/20/89	5%	LM	✓
MS/12-2	"	LM	✓	"	5%	LM	✓
MS/12-3	"	LM	✓	"	50%	LM	✓

Received in Lab Date 9/21 Initials PR Locked? ☒

Sampling Method: MS/12

Zero & Span Balance

Initials PR

Filter # Tare Weight (grams) Used on Test

Remarks:

E8446 0.5041 MS/12-1
E8447 0.5023 MS/12-2
E8448 0.5056 MS/12-3

ENVIRONMENTALISTS INC.

POST OFFICE BOX 12291
RESEARCH TRIANGLE PARK
NORTH CAROLINA 27709-2291
919-781-3550

Page 1

JOB NAME: Mannington Tile

LABORATORY: OLL

OF RESULTS: 10-12-81

SAMPLE MATRIX: M542 0.1 N NaOH

TYPE OF ANALYSIS REQUESTED: Ph

SUBMITTED BY: Richard J. Blau

L-0005a

ENTROPY

ENVIRONMENTALISTS INC.

POST OFFICE BOX 12291
RESEARCH TRIANGLE PARK
NORTH CAROLINA 27709-2291
919-781-3550

INTERLABORATORY SAMPLE TRANSFER CHAIN-OF-CUSTODY FORM

Please return this form along with the analytical results.

The samples referenced on EEI Purchase Order Number: 6445 A-1 were
shipped via Pony Express on 9-28 by RAT
to OLI

Samples received at Oxford Lab on 9-29-89
by M. Conlton

Note any broken seals, leakage, spillage, and/or damage to the samples.

APPENDIX C

CALIBRATION DATA

QUALITY ASSURANCE PROCEDURES

General. Each item of field test equipment purchased or constructed by Entropy is assigned a unique, permanent identification number. New items for which calibration is required are calibrated before initial field use. Equipment with the possibility of the calibration status changing with use or with time is inspected in the field before testing begins, and again upon return from each field use. When an item of equipment is found to be out of calibration, it is adjusted and recalibrated or retired from service. All equipment is periodically recalibrated in full, regardless of the outcome of these regular inspections.

Calibrations are conducted in a manner and at a frequency which meet or exceed U. S. EPA specifications. Entropy Environmentalists Inc. (EEI) follows the calibration procedures outlined in EPA Reference Methods, and those recommended within the Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III (EPA-600/4-77-027b, August, 1977). When the Reference Methods are inapplicable, EEI uses methods such as those prescribed by the American Society for Testing and Materials (ASTM).

Data obtained during calibrations are recorded on standardized forms, which are checked for completeness and accuracy by the Quality Assurance Manager or the Quality Assurance Director. Data reduction and subsequent calculations are performed using EEI's in-house computer facilities. Calculations are generally performed at least twice as a check for accuracy. Copies of calibration data are included in the test or project reports.

Inspection and Maintenance. An effective preventive maintenance program is necessary to ensure data quality. Each item of equipment returning from the field is inspected before it is returned to storage. During the course of these inspections, items are cleaned, repaired, reconditioned, and recalibrated when necessary.

Each item of equipment used for this test program was inspected again before being packed and transported to the job site. The majority of the equipment needs a visual inspection only. In the case of the meter consoles, a 10-minute quick calibration check is conducted. EEI performs these quality assurance activities prior to departure to detect equipment problems which may originate during periods of storage. This minimizes on-site delays due to equipment failure.

Occasional equipment failure in the field is unavoidable despite the most rigorous inspection and maintenance procedures. For this reason, EEI makes every effort to transport sufficient backup equipment to the job site to have complete redundancy of all critical sampling train components.

Calibration. Equipment that require calibration include the nozzle, pitot tube, pressure gauges, thermometers, flow meters, dry gas meters, and barometers. The following sections elaborate on the calibration procedures followed by EEI for these items of equipment. Calibration data for the specific items of equipment used for this test program follow the text.

Nozzles. Each probe nozzle is uniquely and permanently identified at the time of purchase, calibrated before initial field use, and visually inspected on-site prior to testing. Each time a nozzle is calibrated, the inside diameter of the nozzle is measured to the nearest 0.001 in. using a micrometer. Five measurements are made using different diameters each time. If the difference between the high and the low numbers does not exceed 0.004 inch, the average of the five measurements is used. If the difference exceeds this amount, or when the nozzle becomes nicked, dented, or corroded, the nozzle is reshaped, sharpened, and recalibrated.

Pitot Tubes. All Type S pitot tubes used by EEI, whether separate or attached to a sampling probe, are constructed in-house or by Nutech Corporation. Each pitot is calibrated when new in accordance with the geometry standards contained in EPA Reference Method 2. A Type S pitot tube, constructed and positioned according to these standards, will have a coefficient of 0.84 ± 0.02 . This coefficient should not change as long as the pitot tube is not damaged.

Each pitot tube is inspected visually before it is transported to the field and again on-site prior to testing. If either of these visual inspections indicate damage or raise doubt that the pitot remains in accordance with the EPA geometry standards, the pitot tube is not used until it has been refurbished and recalibrated.

Differential Pressure Gauges. Some meter consoles used by EEI are equipped with 10-in. W.C. inclined-vertical manometers. Fluid manometers

do not require calibration other than leak checks. Manometers are leak checked in the field prior to each test series, and again upon return from the field.

Most of EEI's meter consoles are equipped with Magnehelic® differential pressure gauges. Each set of gauges is calibrated initially over its full range, 0-10 inches W.C. After each field use, the calibration of the gauge set is checked against an inclined manometer at the average delta p encountered during the test. If the agreement is within $\pm 5\%$, the calibration is acceptable.

Thermometers

Impinger Thermometer. On-site, prior to the start of testing, the thermometer used to monitor the temperature of the gas leaving the last impinger is compared with a mercury-in-glass thermometer which meets ASTM E-1 specifications. If necessary, the impinger thermometer is adjusted until it agrees within $\pm 2^{\circ}\text{F}$ of the reference thermometer. (If the thermometer is not adjustable, it is labeled with a correction factor.)

Dry Gas Meter Thermometer. Prior to each field use, the thermometer used to measure the temperature of the metered gas sample is checked against an ASTM mercury-in-glass thermometer. The dry gas meter thermometer is acceptable if the values agree within $\pm 5.4^{\circ}\text{F}$. Thermometers not meeting this requirement are adjusted or labeled with a correction factor.

Flue Gas Temperature Sensor. All thermocouples employed by EEI for the measurement of flue gas temperatures are calibrated upon receipt. Each receives an initial, 3-point calibration (ice bath, boiling water, and hot oil) using an ASTM mercury-in-glass thermometer as a reference. The thermocouple is acceptable if the agreement is within $\pm 1.5\%$ (absolute) at each of the three calibration points.

On-site, prior to the start of testing, the reading from the stack gas thermocouple-potentiometer combination is compared with a mercury-in-glass reference thermometer. If the two agree within $\pm 1.5\%$ (absolute), the thermocouple and potentiometer are considered to be in proper working order for the test series.

After each field use, the thermocouple-potentiometer system is again compared with an ASTM mercury-in-glass reference. If the absolute temperatures agree within $\pm 1.5\%$, the temperature data are considered valid.

Dry Gas Meter and Orifice

General. The dry gas meter and orifice are typically installed in a common console and are calibrated simultaneously. As a transfer standard, EEI uses a dry gas meter that is calibrated annually against a spirometer. During the annual transfer standard calibration, three calibration runs are performed at each of seven flow rates ranging from approximately 0.2 to 1.25 cfm.

EEI uses three calibration procedures: 1) full calibration, 2) 10-minute quick calibration, and 3) posttest calibration.

Full Calibration. The full calibration is a complete calibration procedure used to obtain the calibration factor of the dry gas meter and orifice before their first use and, at a minimum, every six months thereafter. Two calibrations are performed at each of three different orifice settings (flow rates): 0.5, 2.1, and 4.8 in. H_2O , and at zero vacuum.

EPA Reference Method 5 calls for another full calibration anytime a posttest meter calibration indicates that the average meter coefficient (Y_d) has changed by more than 5%. Standard practice at EEI is to recalibrate the meter anytime Y_d is found to be outside the range $0.97 \leq Y_d \leq 1.03$, or deviates more than the 5%.

An orifice calibration factor (ΔH) is calculated for each of the six flow settings during the full calibration. If the range of values does not vary by more than 0.15 in. H_2O , the arithmetic average of the six values obtained during the calibration is used. Standard practice at EEI is to recalibrate if the average ΔH is found to be outside the range 1.6 to 2.0 in. H_2O .

Ten-Minute Quick Calibration. The 10-minute quick calibration is conducted prior to reporting to the test site and again prior to each day of testing. The meter console is not used if Y_d is not within $\pm 3\%$ of that of the full test.

Posttest Calibration. The posttest calibration is designed to check whether the calibration factors have changed. Posttest calibrations are performed after each field test series. Each posttest calibration is performed at an average orifice setting (based on the test data) and at the maximum vacuum reached during the testing. Three calibrations are performed at these settings.

If the post test Y_d deviates by less than 5 % from that of the full test calibration, the test data are acceptable. If Y_d deviates by more than 5 %, the meter is recalibrated prior to reuse, and the Y_d (initial or posttest) that yields the lowest sample volume is used for all calculations.

If the posttest delta-H₀ deviates by more than 10 % from that of the full test, the orifice is recalibrated prior to reuse. No adjustments are made for calculation purposes.

Barometer. Each field barometer is adjusted before each test series to agree within ± 0.1 inches of a reference aneroid barometer. The reference barometer is checked weekly against the station pressure value (corrected for elevation difference) reported by the National Weather Service station at the Raleigh-Durham International Airport, approximately 2.5 miles from EEI's location.

Calibration by: WLS

Dry Gas Meter Identification: 6838323

Dry Gas Meter Identification: 6838323

Date: 3-30-89 Barometric Pressure (P_b): 29.56 in. Hg

*Date: 3-31-89 *Barometric Pressure (P_b): 29.34 in. Hg



Approx. Flow Rate (Q) cfm	Spirometer		Dry Gas Meter		Pressure (Δp) in. H ₂ O	Time (t) min.	Flow Rate (Q) cfm	Meter Coeff. (V_{ds})	Avg. Meter Coeff. ($\bar{V}_{ds}$)
	Gas Volume (V_s) ft ³	Temp. (t_s) °F	Gas Volume (V_{ds}) ft ³	Temp. (t_{ds}) °F					
	2.859	77	2.757	77	5	10	.2776		1.0357
	2.823	77	2.726	77	5		.2741		1.0343
	2.796	79	2.710	77	5		.2705		1.0266
	4.144	79	4.127	77	.8		.4009		0.9984
	4.189	79	4.133	77	.8		.4053		1.0078
	4.262	79	4.136	77	.8		.4123		1.0246
	5.027	79	4.92	77	1.0		.4863		1.0154
	4.945	79	4.884	77	1.0		.4784		1.0062
	5.055	79	4.909	77	1.0		.4870		1.0234
	8.069	79	7.955	77	2.2		.7806		1.0051
	8.076	79	7.917	77	2.2		.7815		1.011
	8.051	79	7.938	77	2.2		.7789		1.005
	10.700	79	10.436	76	3.4		1.0274		1.011
	10.665	79	10.525	76	3.4		1.0241		0.9991
	10.565	79	10.452	76	3.4		1.0145		0.9967

* * *

(V_s) (t_s + 160) (P_b)

(P_b) (V_s)
0 = (17.611)

SAMPLING EQUIPMENT CALIBRATION CHECKLIST

28

JOB NAME/NUMBER MANNINGTON TILE TEAM LEADER NH

SAMPLING LOCATION SPRAY BOOTH ZA STACK

BAROMETER CHECK

DATE	ENTROPY IN-HOUSE REFERENCE BAROMETER	FIELD BAROMETER
9-19-89	29.69	29.7

THERMOMETERS AND THERMOCOUPLE CHECK

DATE <u>9-19</u>	REFERENCE THERMOMETER AMBIENT TEMPERATURE	<u>77 °F</u>																								
<table style="width: 100%;"> <tr> <th style="width: 40%;"></th> <th style="width: 30%; text-align: center;"><u>AMBIENT TEMPERATURE °F</u></th> <th style="width: 30%; text-align: center;"><u>MUST BE WITHIN ACCEPTANCE RANGE °F</u></th> </tr> <tr> <td colspan="3"><u>THERMOMETERS</u></td> </tr> <tr> <td>Impinger Exit</td> <td style="text-align: center;"><u>75</u></td> <td style="text-align: center;"><u>+2 °F</u></td> </tr> <tr> <td>Filter Compartment</td> <td style="text-align: center;"><u>75</u></td> <td style="text-align: center;"><u>+5.4 °F</u></td> </tr> <tr> <td>Dry Gas Meter</td> <td style="text-align: center;"><u>76</u></td> <td style="text-align: center;"><u>+5.4 °F</u></td> </tr> <tr> <td>Other</td> <td style="text-align: center;">_____</td> <td></td> </tr> <tr> <td colspan="3"><u>THERMOCOUPLE</u></td> </tr> <tr> <td></td> <td style="text-align: center;"><u>77</u></td> <td style="text-align: center;"><u>+8 °F</u></td> </tr> </table>				<u>AMBIENT TEMPERATURE °F</u>	<u>MUST BE WITHIN ACCEPTANCE RANGE °F</u>	<u>THERMOMETERS</u>			Impinger Exit	<u>75</u>	<u>+2 °F</u>	Filter Compartment	<u>75</u>	<u>+5.4 °F</u>	Dry Gas Meter	<u>76</u>	<u>+5.4 °F</u>	Other	_____		<u>THERMOCOUPLE</u>				<u>77</u>	<u>+8 °F</u>
	<u>AMBIENT TEMPERATURE °F</u>	<u>MUST BE WITHIN ACCEPTANCE RANGE °F</u>																								
<u>THERMOMETERS</u>																										
Impinger Exit	<u>75</u>	<u>+2 °F</u>																								
Filter Compartment	<u>75</u>	<u>+5.4 °F</u>																								
Dry Gas Meter	<u>76</u>	<u>+5.4 °F</u>																								
Other	_____																									
<u>THERMOCOUPLE</u>																										
	<u>77</u>	<u>+8 °F</u>																								
NOTE: Adjust thermometer until acceptable. If thermometer can't be adjusted, use a backup. If no back up, then record the ambient temperature indicated by the unadjusted thermometer.																										

PITOT AND NOZZLE CHECK

<u>PITOTS</u>	<u>I.D. #</u>	<u>VISUAL INSPECTION CHECK</u>
	<u>3-9</u>	<u>✓</u>
	<u>3-6</u>	<u>✓</u>
	_____	_____
	_____	_____
<u>NOZZLES</u>	<u>705</u>	<u>✓</u>
	<u>706</u>	<u>✓</u>
	_____	_____
	_____	_____

Meter Box Number: N9Calibration by: MBCStandard Meter Number: 6838323 Standard Meter Gamma: 1.0063Date: 7-19-89 Barometric Pressure (P_b): 29.57 in. Hg*Date: _____ *Barometric Pressure (P_b): _____ in. Hg

METERBOX CALIBRATION

Standard Meter			Meter Box Metering System				
Gas Volume (V_{ds}) ft ³	Temp. (t_{ds}) °F	Time (θ) min.	Orifice Setting (ΔH) in. H ₂ O	Gas Volume (V_d) ft ³	Temp. (t_d) °F	Coeff. (Y_d)	ΔH_{θ} in. H ₂ O
4.042	76	10	0.5	4.197	84	.9824	1.709
4.061			0.5	4.199	84	.9884	1.687
8.180			2.1	8.462	85	.9840	1.550
8.180			2.1	8.480	86	.9837	1.546
12.535			4.8	12.899	88	.9880	1.694
12.505	↓	↓	4.8	12.853	89	.9910	1.699
Average						.9863	1.714

$$Y_d = \frac{Y_{ds} * V_{ds} * (t_d + 460) * P_b}{V_d * (t_{ds} + 460) * (P_b + \Delta H/13.6)}$$

$$\Delta H_{\theta} = \frac{0.0317 * \Delta H}{P_b * (t_d + 460)} * \left[\frac{(t_{ds} + 460) * \theta}{Y_{ds} * V_{ds}} \right]^2$$

ON-SITE DRY GAS METER AUDIT

Date 9-19-89Meter Box Identification Number N9

Time _____

Pretest Gamma (Y) 0.9863 ΔH_a 1.714Auditor MABarometric Pressure (P_{bar}) 29.2 in.Hg

Dry Gas Meter Readings, ft^3	Meter Temperatures, $^{\circ}F$	Upper and Lower Limits for Audit Gamma
Initial <u>119.500</u>	Initial <u>84</u>	$0.97 * Y = \underline{0.9567}$
Final <u>127.317</u>	Final <u>93</u>	$1.03 * Y = \underline{1.0159}$

Dry Gas Volume Metered, ft^3	Average Meter Temperature, $^{\circ}F$	Run Time, min.	Calculated Audit Gamma
$V_m = \underline{7.817}$	$T_m = \underline{89}$	10	$Y_c = \underline{0.9903}$

$$Y_c = \frac{10}{V_m} * \sqrt{\frac{0.0319 (T_m + 460)}{P_{bar}}}$$

$$Y_c = \frac{10}{\underline{7.817}} * \sqrt{\frac{0.0319 (\underline{89} + 460)}{\underline{29.2}}} = \underline{0.9903}$$

Audit Gamma Within Acceptable Limits? Yes ☒ No ☐

Meter Box Number N9Calibration by: MBCMeter Box Vacuum: 3 (in. Hg)Job No. 6445Standard Meter Number: 6838323 Standard Meter Game: 1.0063Date: 9-29-89Barometric Pressure (P_b): 29.8 (in. Hg)**POST TEST CALIBRATION**

Standard Meter			Meter Box Metering System				
Gas Volume (V_{ds}) ft ³	Temp. (t_{ds}) °F	Time (θ) min.	Orifice Setting (ΔH) in. H ₂ O	Gas Volume (V_d) ft ³	Temp. (t_d) °F	Coeff. (Y_d)	ΔH_{θ} in. H ₂ O
7.916	74	10	2.0	8.565	98	.9671	1.722
8.010	74	10	2.0	8.685	100	.9685	1.676
7.919	74	10	2.0	8.563	100	.9699	1.719
Average						.9685	1.706

$$Y_d = \frac{Y_{ds} * V_{ds} * (t_d + 460) * P_b}{V_d * (t_{ds} + 460) * (P_b + \Delta H/13.6)}$$

$$\Delta H_{\theta} = \frac{0.0317 * \Delta H}{P_b * (t_d + 460)} * \left[\frac{(t_{ds} + 460) * \theta}{Y_{ds} * V_{ds}} \right]^2$$

ΔP (Magnehelic®)	ΔP (Manometer)	% Difference
.16	.16	0
.44	.448	1.8
.71	.71	0

PROCESS DATA



9-19-89

308 Glaze - Mill Formula

	Wt %
Feldspar	6.8 %
Silica	6.6
Clay	10.1
Limestone	2.3
Ultrav	20.0
Zinc Oxide	4.0
Fluorspar	1.0
Calcined Alumina	4.6
Lead Monosilicate	28.3
FZ-16 Frit	13.9
Titania	2.5
	100.1 %

Does not include :

CMC	.03 %	
VGUM T	.05 %	
Unknown Composition	14M200 Coral Stain	.12 % (Zr Si Fe stain)
	14H705 Yellow	.17 % (Zr Si Ps stain)
	41166 Gray	.08 % (Co Ni Fe Zr Si stain)

TOTAL P.03
09.21.89 10:39 AM P03mannington
CERAMIC TILE MFG. CO.

308

9-19-89

Glaze Composition % by wgt - oxides

K₂O .3 %Na₂O 1.8

CaO 2.7

ZnO 6.1

PbO 24.1

Al₂O₃ 9.9B₂O₃ 4.2SiO₂ 32.4ZrO₂ 13.4TiO₂ 2.5

F .5 %

CO₂ 1.0 %H₂O 1.4 %

100.3 %

APPENDIX E

SAMPLING AND ANALYTICAL PROCEDURES