

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.14
Reference:	10
Title:	<i>Diagnostic Test, Dry Gas Cleaning Exhauster Stack, Miles, Inc., International Technology Corporation, Monroeville, PA, February 1994.</i>



**INTERNATIONAL
TECHNOLOGY
CORPORATION**

**Project No. 313674
February 1994**

Final Report

**Diagnostic Test
Dry Gas Cleaning Exhauster Stack
Miles Inc.**

Prepared for:

**Miles Inc.
Industrial Chemicals Division
Baltimore, Maryland**

Prepared by:

**IT Corporation
Monroeville, Pennsylvania**

RESPONSIVE TO THE NEEDS OF ENVIRONMENTAL MANAGEMENT

**Diagnostic Test
Dry Gas Cleaning Exhauster Stack
Miles Inc.**

Table of Contents

List of Tables/List of Figures	ii
1.0 Introduction	1
2.0 Summary of Results	1
2.1 Particulate	1
2.2 Total Fluoride	2
2.3 Specific Metals	2
2.4 Nitrogen Oxides	3
2.5 Stack Gas Conditions	4
3.0 Process Description	4
4.0 Sampling Locations and Methods	4
4.1 Sampling Location	5
4.2 Sampling Methods	5
4.2.1 Velocity and Gas Temperature	5
4.2.2 Molecular Weight	5
4.2.3 Moisture	7
4.2.4 Particulate	7
4.2.5 Fluoride	7
4.2.6 Trace Metals	7
4.2.7 Nitrogen Oxides	7
5.0 Quality Assurance	8
Appendix A - Sampling Methods	
Appendix B - Example Calculations	
Appendix C - Field Data	
Appendix D - Laboratory Data	
Appendix E - Calibration Data	

List of Tables

Table	Title
2-1	Particulate Emissions
2-2	Fluoride Emissions
2-3	Trace Metal Emissions
2-4	Nitrogen Oxide (NO _x) Emissions
2-5	Summary of Stack Conditions

List of Figures

Figure	Title
4-1	Sample Locations

1.0 Introduction

On January 11, 12, and 15, 1994, IT Corporation (IT) conducted diagnostic emission tests on the baghouse dry filter system (Building No. 8) at Miles Inc. (Miles), Baltimore, Maryland facility. The baghouse dry filter system provides emission controls for eight continuous and three rotary smelters used in the manufacture of frit. Sampling was conducted to determine concentration and mass emission rates of barium (Ba), cobalt (Co), chromium (Cr), copper (Cu), manganese (Mn), nickel (Ni), lead (Pb), zinc (Zn), total fluoride, total nitrogen oxide (NO_x), and total particulate matter.

IT utilized "U.S. Environmental Protection Agency (EPA) Draft Reference Method 29 Methodology for the Determination of Trace Metals Emissions in Exhaust Gases from Combustion Sources" for multimetals sampling. Particulate testing was conducted by utilizing EPA Reference Method 5 (EPA RM5) and total fluoride samples were obtained by utilizing EPA RM13B. Nitrogen oxide testing was conducted by utilizing EPA RM7A.

In conjunction with the emission tests, measurements were also made for total stack gas flow rate, temperature, moisture, oxygen, and carbon dioxide content by EPA Reference Methods 1-4.

All sampling methods (Appendix A) were instituted based on an IT testing protocol submitted to the state of Maryland.

2.0 Summary of Results

This section summarizes the results of the test program in tabular form. The appendices contain the backup data for the tables as follows:

- Appendix B - Example Calculations
- Appendix C - Field Data Sheets
- Appendix D - Laboratory Data
- Appendix E - Calibration Data

2.1 Particulate

Table 2-1 represents particulate emission concentrations in grains per dry standard cubic foot (gr/dscf) and emission rates in pounds per hour (lb/hr). The product of the particulate concentration and the stack gas flow rate yields the mass emission rate in lb/hr.

The particulate emissions in Table 2-1 represent that material collected on the filter and in the probe, both of which were heated to 250 degrees Fahrenheit (°F). The particulate emission test conducted on the first day of sampling yielded an average filterable concentration of 5.35×10^{-4} gr/dscf, which corresponds to an average emission rate of 9.47×10^{-2} lb/hr.

Table 2-1
Particulate Emissions

Run No.	Concentration (gr/dscf) ^a	Emission Rate (lb/hr)
1	5.60×10^{-4}	9.55×10^{-2}
2	5.11×10^{-4}	9.38×10^{-2}
Average	5.35×10^{-4}	9.47×10^{-2}

^aGrains per dry standard cubic foot (gr/dscf); standard conditions are 68 °F, 29.92 in Hg and zero percent moisture.

2.2 Total Fluoride

Table 2-2 represents total fluoride emission concentrations in gr/dscf and emission rates in lb/hr. An average concentration of 2.25×10^{-2} gr/dscf was found during sampling. This concentration corresponds to an average emission rate of 4.05 lb/hr.

Table 2-2
Fluoride Emissions

Run No.	Concentration (gr/dscf) ^a	Emission Rate (lb/hr)
1	2.42×10^{-2}	4.34
2	2.08×10^{-2}	3.76
Average	2.25×10^{-2}	4.05

^aGrains per dry standard cubic foot (gr/dscf); standard conditions are 68 °F, 29.92 in Hg and zero percent moisture.

2.3 Specific Metals

Table 2-3 represents emission concentrations and emission rates for specific metals recovered over each of two runs as well as the average stack gas concentration and mass emission rate.

Table 2-3
Trace Metal Emissions

Metal	Run #1		Run #2		Average	
	Conc. ^a ($\mu\text{g}/\text{m}^3$)	Emission Rate (lbs/hr)	Conc. ^a ($\mu\text{g}/\text{m}^3$)	Emission Rate (lbs/hr)	Conc. ^a ($\mu\text{g}/\text{m}^3$)	Emission Rate (lbs/hr)
Ba	2.02	1.5×10^{-4}	1.36	1.09×10^{-4}	1.69	1.30×10^{-4}
Co	0.36	2.68×10^{-5}	<0.31	$<2.51 \times 10^{-5}$	<0.337	$<2.60 \times 10^{-5}$
Cr	0.97	7.20×10^{-5}	0.71	5.70×10^{-5}	0.84	6.45×10^{-5}
Cu	1.64	1.22×10^{-4}	0.65	5.20×10^{-5}	1.14	8.71×10^{-5}
Mn	1.08	8.04×10^{-5}	0.65	5.20×10^{-5}	0.86	6.62×10^{-5}
Ni	1.51	1.12×10^{-4}	<1.04	$<8.38 \times 10^{-5}$	<1.27	$<9.80 \times 10^{-5}$
Pb	0.63	4.69×10^{-5}	0.52	4.19×10^{-5}	0.58	4.44×10^{-5}
Zn	12.81	9.55×10^{-4}	<5.22	$<4.19 \times 10^{-4}$	<9.01	$<6.87 \times 10^{-4}$

^aConcentration ($\mu\text{g}/\text{m}^3$)

2.4 Nitrogen Oxides

Table 2-4 represents total NO_x emission concentration in parts per million (ppm) by volume and the corresponding emission rate in lb/hr. An average concentration of 583 ppm was found during sampling. This corresponds to an average emission rate 80.8 lb/hr.

Table 2-4
 NO_x Emissions

Run No.	Concentration (ppm)	Emission Rate (lb/hr)
1	536	80.0
2	548	81.9
3	587	75.7
4	661	85.5
Average	583	80.8

2.5 Stack Gas Conditions

Table 2-5 represents a summary of gas conditions during each of the sample runs. The stack gas flow rate averaged 19,778 dry standard cubic feet per minute (dscfm) (26,650 actual cubic feet per minute [acfm]) during the testing events. The stack gas temperature averaged 238 degrees Fahrenheit (°F). Moisture content averaged 3.81 percent while the carbon dioxide (CO₂) and oxygen (O₂) content averaged 1.7 percent and 19.4 percent, respectively.

Table 2-5
Summary of Stack Conditions

Run No.	Flow Rate		Temperature (°F)	Moisture (%)	O ₂ ^c (%)	CO ₂ ^c (%)
	(acfm) ^a	(dscfm) ^b				
Day 1	27,426	19,904	251	4.90	19.4	2.0
Day 2	28,776	21,440	238	3.87	19.4	1.4
Day 3	23,749	17,989	226	2.66	19.4	1.7
Average	26,650	19,778	238	3.81	19.4	1.7

^a Actual cubic feet per minute.

^b Dry standard cubic feet per minute; standard conditions are 68°F and 29.92 in Hg and 0% moisture.

^c ORSAT analysis of integrated bag sample.

Example calculations used to determine the results presented in Tables 2-1 through 2-5 are found in Appendix B.

3.0 Process Description

The dry filter system processes air from eight continuous smelters. It consists of five primary filter compartments and three secondary filter compartments. Each compartment houses approximately 160 bags coated with soda ash. The air passes through the filters to two fans and finally exhausts through a 100 foot high stack.

4.0 Sampling Locations and Methods

This section contains a brief description of the sampling locations and methods.

4.1 Sampling Location

Particulate testing was conducted at the sample location on the final exit stack serving emissions from the baghouse dry filter system. (As shown in Figure 4-1)

The two sample ports used for testing were located 6.2 stack diameters downstream from the air entry point and 1.5 stack diameters upstream from the bottom of the silencer. A total of 24 sampling points (12 per port) were used to traverse the cross-sectional area of the 48 inch inside-diameter round stack. Each point of the multimetals sampling train was sampled for 6.5 minutes, which yielded a total of 156 minutes per test run. Fluoride testing was conducted at 60 minutes per test run, which equates to 2.5 minutes per sampling point. All sampling was conducted isokinetically by regulating the sampling rate relative to the stack gas velocity as measured by a pitot tube attached to the sample probe.

4.2 Sampling Methods

The test methods are described briefly below. Detailed descriptions of the sampling and analytical procedures used are contained in Appendix A.


4.2.1 Velocity and Gas Temperature

All gas velocities were measured with a Type-S pitot tube and a 0- to 10-inch inclined manometer. In all cases, velocities were measured at the field sample location at each sampling point across the stack to determine an average value according to procedures described in EPA RM2.¹

4.2.2 Molecular Weight

Stack gas composition and molecular weight were determined by EPA RM3.¹ Integrated bag samples were collected simultaneously with the particulate tests. Analyses for CO₂ and O₂ were made with an Orsat gas analyzer.

¹40 CFR 60, Appendix A, July 1991.



STACK I.D.=48"

TRAVERSE POINT NO.	DISTANCE FROM NEAR WALL, IN.
1	1
2	3.22
3	5.66
4	8.50
5	12
6	17.09
7	30.91
8	36
9	39.5
10	42.34
11	44.8
12	47




FIGURE 4-1
SAMPLE LOCATION

PREPARED FOR

MILES INC.
BALTIMORE, MARYLAND

IT INTERNATIONAL
TECHNOLOGY
CORPORATION

4.2.3 Moisture

The stack gas moisture content was determined by EPA RM4.¹ Testing was conducted simultaneously with the particulate testing. The data generated from the following test methods include: Field Data, Appendix C; Laboratory Data, Appendix D; and Calibration Data, Appendix E.

4.2.4 Particulate

Particulate grain loading at the outlet stack serving Building No. 8 was measured by EPA RM5.¹ A sampling train consisting of a heated borosilicate glass-lined probe, a heated 3-inch-diameter glass fiber filter (Whatman Reeve Angel 934 AH), and a series of Greenburg-Smith and modified impingers was used in each test. The nozzle, probe, and filter holder portions of the sampling train were acetone-rinsed at the end of each test. The acetone rinse and the particulate caught on the filter media were dried at room temperature, desiccated to a constant weight, and weighed on an analytical balance. Total filterable particulate matter was determined by adding these two values.

The contents of the impingers were measured volumetrically in the field for moisture determination and transferred to a polyethylene container. The impingers and connecting glassware were then rinsed with distilled water and both sample fractions were placed in a polyethylene container.

4.2.5 Fluoride

Fluoride was sampled by EPA RM13B¹ single point samples were collected in an impinger train containing distilled water absorbing solution. Three tests were run, each test lasting 60 minutes. Samples were analyzed by the specific ion electrode method.

4.2.6 Trace Metals

Trace metals, consisting of those illustrated in Table 2-3, were sampled by methods described in the previously discussed EPA Reference Methods Manual for compliance with BIF regulations.

4.2.7 Nitrogen Oxides

NO_x emissions were sampled using EPA RM7A. Single point samples were collected in an evacuated flask containing sulfuric acid and hydrogen peroxide. Four flasks were filled per

hour (15 minutes each). Eight flasks were filled on January 12, 1994 and 8 more were filled on January 15, 1994. A total of 16 grab samples were taken at 15 minute intervals. The arithmetic average of the first four flasks is reported in Table 2-4 as Run No. 1.

5.0 Quality Assurance

Routine standard reference method quality control procedures were followed throughout this test series. These included, but were not limited to, the following:

- Calibration of field sampling equipment. Appendix E contains calibration data for equipment used during this testing event. Calibration guidelines are described in more detail in Appendix E.
- Train configuration (field) and calculation checks (office).
- On-site quality assurance checks, such as leak checks of the sampling train, pitot tube, and Orsat line.
- Use of designated analytical equipment and sampling reagent (field and laboratory).
- Laboratory analysis quality assurance procedures. (Appendix D contains quality assurance results for filter and reagent blank analyses.)

Sampling equipment, reagents, and analytical procedures for this test series met all necessary guidelines set forth for accurate test results. Calibration showed that all particulate sampling equipment was within the limits described for EPA RM5 with the exception of isokinetics. Isokinetic requirements are 100 ± 10 percent of target flow rate. Isokinetics for the particulate sampling were 85.2 and 71.5 for the first and second runs, respectively. This condition allows for an overestimation of the concentration and corresponding emission rate by allowing larger particles not originally in the gas volume sampled to enter the probe.² The quality of analytical procedures and reagents met federal regulations described in EPA RM5.

²William C. Hind, 1982, *Properties, Behavior, and Measurement of Airborne Particles*.

**APPENDIX A
SAMPLING METHODS**

DETERMINATION OF PARTICULATE AND METAL EMISSIONS

Sampling for filterable particulate matter and total metals (particulate and gaseous) emissions was conducted in accordance with the Methodology for the Determination of Trace Metal Emissions in Exhaust Gases From Stationary Source Combustion Processes* and that in Subsection 3.1 of the Methods Manual for Compliance with BIF Regulations.** The particulate determination in this method is consistent with EPA Method 5.***

Sampling Apparatus

The sampling train used in these tests is assembled by ITAQS personnel and meets all design specifications established by the U.S. EPA. The sampling apparatus consists of:

Nozzle - Borosilicate glass with an accurately measured round opening.

Probe - Borosilicate glass with a heating system capable of maintaining a minimum gas temperature of 250° F at the exit end during sampling.

Pitot Tube - A Type-S pitot tube that meets all geometric standards is used to measure gas velocity during each sampling run.

Temperature Gauge - Type-K thermocouple attached to the pitot tube in an interference-free arrangement to monitor stack gas temperature with a digital readout to within 1.5 percent Rankine.

Filter Holder - Pyrex glass with a heating system capable of maintaining a filter temperature of 250° ± 25° F. A Teflon filter support is used.

Filter - 87-mm (3-in.)-diameter, Pallflex Type 2500 QAT-UP ultra-pure filter.

• EPA Draft Protocol, July 1988.

** EPA/530-SW-91-010, December 1990.

*** 40 CFR 60, Appendix A, July 1990.

Draft Gauge - An inclined manometer made by Dwyer with a readability of 0.01 in.H₂O in the 0- to 10-in.H₂O range is used.

Impingers - Five Greenburg-Smith design impingers connected in series with glass ball joints. The first, third, and fifth impingers are modified by removing the tip and extending the tube to within 1.3 cm (0.5 in.) of the bottom of the flask. For gas streams with high moisture contents, an optional empty impinger may be used before the first impinger as a condensate collector. An optional empty impinger may also be used as a condensate collector between the second and third impingers to avoid carryover into the permanganate solution.

Metering System - Vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 2.8°C (5°F), calibrated dry gas meter, and related equipment to maintain an isokinetic sampling rate and to determine sample to volume. The dry gas meter is made by Rockwell, and the fiber vane pump is made by Gast.

Barometer - Aneroid tube type to measure atmospheric pressures to ±2.5 mmHg (±0.1 in.Hg).

Sampling Procedure

Pallflex filters are desiccated for at least 24 hours and weighed to the nearest 0.1 mg on an analytical balance. One hundred mL of 5 percent nitric acid/10 percent hydrogen peroxide solution are placed in each of the first two impingers; if mercury is to be determined, the third and fourth impingers contain 100 mL of acidic potassium permanganate solution--otherwise the third and fourth impingers are not used; and the last impinger contains 200 to 400 g of silica gel.

The train is set up with the probe as shown in Figure PMM-1. If used, the empty condensate collector is placed before the first impinger or after the second impinger. The sampling train is leak-checked at the sampling site prior to each test run by plugging the inlet to the nozzle and pulling a 15-in.Hg vacuum, and at the conclusion of the test by plugging the inlet to the nozzle and pulling a vacuum equal to the highest vacuum reached during the test run.

The pitot tube and lines are leak-checked at the test site prior to and at the conclusion of each test run. This check is made by blowing into the impact opening of the pitot tube until 3 or more inches of water is recorded on the manometer and then capping the impact opening and holding it for 15 seconds to ensure that it is leak




Figure PMM-1. Particulate/metals sampling train.

free. The static-pressure side of the pitot tube is leak-checked by the same procedure, except suction is used to obtain the 3-in.H₂O manometer reading.

Crushed ice is placed around the impingers to keep the temperature of the gas leaving the last impinger at 68°F or less. During sampling, stack gas and sampling train data are recorded at each sampling point. Sampling rates are determined with the aid of a programmable calculator, and all sampling data are recorded on the Emission Testing Field Data Sheet.

Recovery Procedures

Upon completion of each sample run, the sampling train is allowed to cool and is then disassembled into sections. The probe and impinger sections are sealed and carefully transported to the cleanup area.

The amount of moisture collected is determined volumetrically using a graduated cylinder or by weighing each impinger before and after the sample run. After being weighed, the silica gel is discarded. Figure PMM-2 is a schematic of the sample recovery performed on the different sample fractions. The samples are recovered as follows:

Container No. 1 - The filter is placed into a petri dish, sealed, and labeled.

Container No. 2 - The filter holder, probe, and nozzle are rinsed with acetone to recover particulate. A nylon brush is used to remove particulate. The rinse is recovered in a glass jar.

Container No. 3 - The nozzle, probe, and filter holder front halves are rinsed with 0.1 N HNO₃ into a leak-free polyethylene container.

The contents of the first two impingers (and condensate collector if used) and a 0.1 N HNO₃ rinse of the filter holder backhalf and connecting glassware are placed in the same leak-free polyethylene container. The container is sealed and labeled, and the liquid level is marked.

Container No. 4 - The contents of the third and fourth impingers and an acidified potassium permanganate rinse are placed in an amber glass container. A final rinse with Type II water is added to the same container. The container is sealed and labeled, and the liquid level is marked. To prevent pressure buildup in the container, one of the following two procedures is used: 1) a small hole is drilled in the container lid (~1/16 in. dia.), or 2) the lid is left approximately




Figure PMM-2. Multimetals train recovery procedures.

one-quarter turn from closed and is taped in position. In either case, the containers should be packed to maintain them in an upright position.

Container No. 5 - If a brown residue remains in the third and fourth impingers following the water rinse, 15 mL of 8 N HCl is measured in a graduated cylinder. Then 200 mL of Type II water is put in the empty polyethylene container. One impinger is rinsed with the HCl until the residue is removed, then the rinse is poured into the other impinger using a funnel. When the residue is removed, the HCl rinse is added to the water in Container 5. Both impingers are again rinsed with Type II water into Container 5.

Blanks of each reagent are taken in the field for preparation and analysis in a manner identical to that for the samples. The blanks consist of one or more of the following, depending upon the specific project requirements:

- 1) Field blank - A sampling train is set up, leak-checked, recovered, and analyzed as a sample.
- 2) Reagent blank - A sample of each reagent used is taken and analyzed either separately or by combining them in the same proportion as that used for samples.
- 3) Blank spike - A set of blank reagents is taken and combined in the same proportion as was used for the samples. Prior to analysis, the blank set is spiked with a known amount of each metal.

A diagram illustrating sample preparation and analysis procedures for each of the sample train components is shown in Figure PMM-3.

Sample Preparation and Analysis, Particulate

Container No. 1 - The filter and any loose particulate matter from this sample are placed into a tared weighing dish, desiccated for 24 hours to a constant weight, and weighed to the nearest 0.1 mg.

Container No. 2 - The acetone washings are transferred to a tared beaker and evaporated to dryness at ambient temperature and pressure, desiccated for 24 hours to a constant weight, and weighed to the nearest 0.1 mg.

Sample Preparation and Analysis, Metals

Container Nos. 1 and 2 - The filter with its filter catch and the acetone residue are divided into portions containing approximately 0.5 g each and placed into the analyst's choice of either individual microwave pressure-relief vessels or




Figure PMM-3. Sample preparation and analysis scheme.

Parr® Bombs. Six mL of concentrated nitric acid and 4 mL of concentrated hydrofluoric acid are added to each vessel. For microwave heating, the sample vessels are microwaved for approximately 12 to 15 minutes (in intervals of 1 to 2 minutes) at 600 Watts. For conventional heating, the Parr Bombs are heated at 140°C (285°F) for 6 hours. The samples are then cooled to room temperature and combined with the acid-digested probe rinse.

Container No. 3 - If necessary, the pH of this sample is lowered to 2 with concentrated nitric acid. After pH adjustment, the sample is rinsed into a beaker with water, and the beaker is covered with a ribbed watchglass. The sample volume is reduced to approximately 20 mL by heating on a hot plate at a temperature just below boiling. The sample is then digested as follows:

- a) 30 mL of 50 percent nitric acid is added to the sample, and the solution is heated for 30 minutes on a hot plate at a temperature just below boiling.
- b) 10 mL of 3 percent hydrogen peroxide is added, and the solution is heated for an additional 10 minutes.
- c) 50 mL of hot water is added, and the solution is heated for an additional 20 minutes.

After digestion, the remaining sample is combined with the contents of Container 1. This combined solution of the acid-digested filter, probe, and probe rinse and the impinger contents is filtered by using Whatman 541 filter paper.

The filtered solution is then divided into three fractions. The first fraction is analyzed by inductively coupled argon plasma emission spectroscopy (ICAP) in accordance with EPA Method 200.7 (40 CFR 136, Appendix C) which is the same as Method 6010 from SW 846.* The second fraction is analyzed by graphite furnace atomic absorption spectroscopy (AAS). The third fraction is then digested and analyzed for mercury by cold vapor atomic absorption (CVAA) spectroscopy.

The following list shows the methods normally used for each metal. The listed detection limits are shown in micrograms per sample; actual detection limits will vary depending on blank levels, any dilutions made to account for high levels of metals, or interferences. The detection limit for mercury includes the permanganate fraction.

* Test Methods for Evaluating Solid Waste: Physical/Chemical Methods, SW 846, Third Edition, September 1988.

Normal procedure				Optional alternate procedure		
Metal	Method	No.*	Nominal detection limit, μg	Method	No.*	Nominal detection limit, μg
Antimony	ICAP	6010	30	AA	7041	2
Arsenic	AA	7060	0.3	-	-	-
Barium	ICAP	6010	0.5	-	-	-
Beryllium	ICAP	6010	0.7	-	-	-
Cadmium	ICAP	6010	1	-	-	-
Chromium	ICAP	6010	3	-	-	-
Copper	-	-	-	ICAP	6010	3
Lead	AA	7421	0.4	ICAP	6010	60
Nickel	-	-	-	ICAP	6010	10
Manganese	-	-	-	ICAP	6010	1
Mercury	AA	7470	0.2	-	-	-
Selenium	-	-	-	AA	7740	0.5
Silver	AA	7761	0.1	-	-	-
Thallium	ICAP	6010	120	AA	7841	0.7
Zinc	-	-	-	ICAP	6010	4

Container No. 4 - A known aliquot of the sample is taken and diluted to approximately 120 mL with mercury-free water. Approximately 15 mL of 50 percent potassium permanganate solution, 5 mL of 50 percent nitric acid, 5 mL of concentrated sulfuric acid, and 9 mL of 5 percent potassium sulfate are added to the sample. The sample is then heated for 2 hours at 95°C in a convection oven or water bath. After cooling, 5 mL of hydroxylamine hydrochloride solution is added and mixed with the sample. Then 7 mL of stannous chloride is added and the sample is analyzed for mercury by CVAA spectroscopy.

Container No. 5 - Analysis of this sample for mercury depends on project requirements; it may be retained for potential analysis, it may be combined with the same fraction from other runs for one analysis, the sample from one run may be analyzed to confirm the absence of mercury, or each sample may be analyzed for mercury. If analyzed, the procedures are the same as for Container 4.

Normal analytical quality assurance measures include daily full instrument calibration (ICAP is a zero and standard; AAS is a zero and minimum three standards), analysis of a method blank, analysis of a laboratory control sample (LCS, a method blank spiked with a known quantity of each metal), analysis of one sample by ICAP in duplicate, performance of all AAS analyses in duplicate, and performance of a post-digestion spike for each metal analyzed by AAS. For specific projects, a matrix spike may be designated for mercury in the permanganate fraction.

* Test Methods for Evaluating Solid Waste: Physical/Chemical Methods, SW 846, Third Edition, September 1988.

SAMPLING AND ANALYTICAL PROCEDURES

DETERMINATION OF TOTAL FLUORIDE EMISSIONS BY EPA METHOD 13b

The sampling procedures followed during this test program are those described in EPA Method 13b.*

Sampling Apparatus

The sampling train used at the exit stack during these tests meets design specifications established by the Federal EPA. Assembled by ITAQS personnel, it consists of the following:

Nozzle - Stainless steel (316) with sharp, tapered, leading edge and accurately measured round opening.

Probe - Borosilicate glass with a heating system capable of maintaining a gas temperature of $248 \pm 25^\circ\text{F}$ at the exit end during sampling.

Pitot Tube - A Type-S pitot tube that meets all geometric standards; attached to the probe to monitor stack gas velocity.

Filter Holder - Pyrex glass. If the filter is placed between the probe and the first impinger, the filter support must be a 20-mesh stainless steel or Teflon screen. A glass frit cannot be used.

Filter - Whatman No. 541 paper filter, 3-in. diameter.

Draft Gauge - A dual-inclined manometer made by Dwyer with a readability of 0.01 in.H₂O in the 0- to 1-in. range and 0.1 in.H₂O in the 1- to 10-in. range.

Impingers - Four impingers connected in series with glass ball joints. The first, third, and fourth impingers are of the Greenburg-Smith design, modified by replacing the tip with a 1/2-in.-i.d. glass tube extending to 1/2-in. from the bottom of the flask. The second is a standard Greenberg-Smith type.

Metering System - Vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 5°F , dry gas meter with 2 percent accuracy, and related equipment to maintain an isokinetic sampling rate and to determine

* 40 CFR 60, Appendix A, July 1991.

sample volume. The dry gas meter is made by Rockwell and the fiber vane pump is made by Gast.

Barometer - Aneroid type to measure atmospheric pressure to ± 0.1 in.Hg.


Sampling Procedure

After the sampling site and the minimum number of traverse points are selected, the stack pressure, temperature, composition (percent CO₂ and percent O₂ by volume), moisture, and range of velocity head are measured according to procedures described in EPA Methods 1 through 4.*

Approximately 200 grams of silica gel is weighed and placed in a sealed impinger prior to each test. One hundred milliliters (mL) of distilled water is placed in each of the first two impingers; the third impinger is initially empty; and the fourth impinger contains silica gel. The train is set up with the probe as shown in Figure M13-1. As an option, the filter may be placed between the probe and the first impinger and heated to $248^{\circ} \pm 25^{\circ}\text{F}$. The sampling train is leak-checked at the sampling site prior to each test run by plugging the inlet to the nozzle and pulling a 15-in.Hg vacuum; and at the conclusion of the test, by plugging the inlet to the nozzle and pulling a vacuum equal to the highest vacuum reached during the test run. The leak check is acceptable if the leakage rate is less than 0.02 ft³/min or 4 percent of the average sampling rate, whichever is lower.

The pitot tube and lines are leak-checked at the test site prior to and at the conclusion of each test run. The check is made by blowing into the impact opening of the pitot tube until 3 or more inches of water is recorded on the manometer and then capping the impact opening and holding it for 15 seconds to assure it is leak-free. The static pressure side of the pitot tube is leak-checked by the same procedure, except suction is used to obtain the 3-in.H₂O manometer reading. Crushed ice is placed around the impingers to keep the temperature of the gases leaving the last impinger at 68°F or less.

* 40 CFR 60, Appendix A, July 1991.



During sampling, stack gas and sampling train data are recorded at each sampling point and whenever significant changes occur in stack flow conditions. Isokinetic sampling rates are set throughout the sampling period with the aid of a calculator. All sampling data are recorded on the Particulate Field Data Sheet.

Sample Recovery Procedure

The sampling train is moved carefully from the test site to the cleanup area. The volume of water from the first three impingers is measured, and sample fractions are recovered as follows:

Container No. 1 - Distilled H₂O in the impinger section of the sampling train is placed in a polyethylene container. The impingers, connecting glassware, probe, and nozzle are rinsed with distilled H₂O, and this rinse is added to the container for shipment to the laboratory. A nylon brush is used to remove particulate from the probe and nozzle fractions and the stem of the first impinger if needed. The filter is also added to this container.

The silica gel from the fourth impinger is weighed, and this value is recorded on the Sample Recovery and Integrity Sheet along with other pertinent data. An unused filter and a minimum of 200 mL each of distilled water are taken as blanks.

Analytical Procedures

The analytical procedures followed during this program are those described in EPA Method 13b.* Analysis is conducted by specific ion electrode.

The sample is initially filtered. The filtered solids are then combusted in the presence of CaO to prevent loss of fluorine. The ash is then fused with crushed NaOH and quantitatively mixed with the filtrate. The filtrate solution is acidified and distilled. The distillate is diluted, buffered, and analyzed by specific ion electrode. The ion electrode is calibrated with five standards between 0.1 and 10.0 mg/liter. If no fluoride is detected, the reported detection limit is 0.1 mg/liter.

* 40 CFR 60, Appendix A, July 1991.

DETERMINATION OF NITROGEN OXIDE EMISSIONS

This test program follows the sampling procedures described in EPA Method 7A.*

Sampling Apparatus

The nitrogen oxide (NO_x) sampling train used in these tests meets design specifications established by the Federal EPA. Assembled by ITAQS personnel, it consists of the following:

Probe - Borosilicate glass tubing with a heating system capable of maintaining a gas temperature of approximately 250°F at the exit end to prevent water condensation. A glass-wool plug is placed in the end of the probe to remove particulate matter, as shown in Figure 7A-1.

Collection Flask - Two-liter borosilicate, round-bottom flask, with short neck and 24/40 standard taper opening, protected against implosion or breakage.

Flask Valve - Two-way stopcock connected to a 24/10 standard taper joint.

Manifold - Two- and three-way Teflon stopcock and connected 24/10 standard taper joints.

Temperature Gauge - Dial-type thermometer capable of measuring 2°F intervals from 25° to 125°F.

Vacuum Line - Tubing capable of withstanding a vacuum of 3 in.Hg absolute pressure, with "T" connection and T-bore stopcock.

Vacuum Gauge - U-tube manometer, 36 in.Hg with 0.1-in. divisions.

Pump - Capable of evacuating the collection flask to a pressure equal to or less than 3 in.Hg absolute.

Barometer - Aneroid type to measure atmospheric pressures to ±0.1 in.Hg.

* 40 CFR 60, Appendix A, July 1990.




Figure 7A-1. Method 7 sampling train.

Sampling Procedure

Following the selection of the sampling site and minimum number of traverse points, the stack pressure, temperature, moisture, and range of velocity head are measured according to procedures described in EPA Methods 1 through 4.*

One sampling point, representing the average flow rate, is chosen. The sampling flask is charged with 25 mL of absorbing solution (made by mixing 1 liter of distilled water, 2.8 mL of concentrated H_2SO_4 , and 6 mL of 3 percent H_2O_2). A portion of the reagent is retained for use in preparing the calibration standards.

With the sample valve closed, the flask valve open, and the pump/manometer valve open to pump, the flask is evacuated to less than 3 in.Hg absolute pressure. Flask vacuum is determined by moving the pump/manometer valve to manometer. Leakage is checked by observing the manometer for pressure fluctuation. Any variation greater than 0.4 in.Hg over a 1-minute period is corrected before sampling.

With the flask closed, the sample valve open, and the pump/manometer valve turned to pump, the sampling apparatus is purged for 5 minutes. The probe heater setting is adjusted to prevent any visible condensation. With the sample valve closed and the pump/manometer valve open to manometer, an initial flask vacuum is determined by opening the flask valve. The sample valve is then slowly opened, allowing stack gas to enter the flask. The vacuum is allowed to drop to 3 in.Hg (approximately 15 seconds), and then the sample flask valves are closed. The flask is shaken for 5 minutes to ensure contact between the sample and absorbing solution.

Sample Recovery Procedure

The collection flasks are transported to the laboratory for sample recovery. The flasks are set aside for a minimum of 16 hours. At the end of the period, the flasks are shaken for 2 minutes and the final flask pressure and temperatures are measured. All pertinent data are recorded on the recovery data sheets.

* 40 CFR 60, Appendix A, July 1990.

The contents of the flask are measured volumetrically and transferred to a polyethylene container. The flask is then rinsed with two separate 5-mL portions of deionized, distilled water, and the solution is added to the same container.

Analytical Procedure

The volume of absorbing solution is recorded and diluted to 50 mL with deionized, distilled water. A 5-mL aliquot of this solution is pipetted to a volumetric flask and diluted to 50 mL with deionized water. The samples from the second dilution are analyzed by ion chromatography. A calibration curve of $\mu\text{g NO}_x$ versus peak area response is prepared using standards of known concentration.

APPENDIX B
EXAMPLE CALCULATIONS

IT AIR QUALITY SERVICES VELOCITY DETERMINATION

validated 11/1/90

PLANT : Miles
SAMPLE LOCATION : Dry Gas Exhaust Stack
RUN NUMBER : M-V-1

DATE :	1/15/94	BAROMETRIC PRES., in. Hg :	30.26
TIME(24-HR) :	703	STATIC PRES., in. H2O :	-0.11
OPERATOR(S) :	JN,SF		
PERCENT MOISTURE :	2.7	PITOT TUBE, Cp :	0.84
STACK AREA, SQ. IN. :	1809.56	PERCENT CO2 :	1.7
NO. OF TRAVERSE PTS. :	24	PERCENT O2 :	19.4

TRAVERSE PT. NO.	VELOCITY HEAD, in. H2O	STACK TEMP., deg. F
1	0.21	223
2	0.24	225
3	0.25	227
4	0.24	224
5	0.25	224
6	0.26	227
7	0.24	227
8	0.24	227
9	0.23	228
10	0.23	228
11	0.22	227
12	0.23	228
13	0.22	225
14	0.24	225
15	0.24	225
16	0.25	225
17	0.24	225
18	0.26	224
19	0.27	224
20	0.25	224
21	0.26	224
22	0.25	224
23	0.23	226
24	0.24	226
	0.24	226

D. C. M.
1-24-94

**IT AIR QUALITY SERVICES
VELOCITY DETERMINATION**

validated 11/1/90

PLANT : Miles
SAMPLE LOCATION : Dry Gas Exhaust Stack
RUN NUMBER : M-V-2

DATE : 1/15/94
TIME(24-HR) : 835
OPERATOR(S) : JN,SF
PERCENT MOISTURE : 2.7
STACK AREA, SQ. IN. : 1809.56
NO. OF TRAVERSE PTS. : 24

BAROMETRIC PRES., in. Hg : 30.26
STATIC PRES., in. H2O : -0.12
PITOT TUBE, Cp : 0.84
PERCENT CO2 : 1.7
PERCENT O2 : 19.4

TRAVERSE PT. NO.	VELOCITY HEAD, in. H2O	STACK TEMP., deg. F
1	0.23	224
2	0.24	225
3	0.25	225
4	0.25	225
5	0.25	225
6	0.24	225
7	0.22	225
8	0.23	225
9	0.23	225
10	0.24	227
11	0.27	227
12	0.26	227
13	0.26	225
14	0.26	226
15	0.23	226
16	0.23	226
17	0.24	226
18	0.25	226
19	0.25	226
20	0.26	224
21	0.25	224
22	0.27	224
23	0.27	226
24	0.26	226
	0.25	225

0.668
1-24-94

**IT AIR QUALITY SERVICES
VELOCITY DETERMINATION**

validated 11/1/90

PLANT : Miles
SAMPLE LOCATION : Dry Gas Exhaust Stack
RUN NUMBER : M-V-3

DATE :	1/15/94	BAROMETRIC PRES., in. Hg :	30.28
TIME(24-HR) :	920	STATIC PRES., in. H2O :	-0.11
OPERATOR(S) :	JN,SF	PITOT TUBE, Cp :	0.84
PERCENT MOISTURE :	2.7	PERCENT CO2 :	1.7
STACK AREA, SQ. IN. :	1809.56	PERCENT O2 :	19.4
NO. OF TRAVERSE PTS. :	24		

TRAVERSE PT. NO.	VELOCITY HEAD, in. H2O	STACK TEMP., deg. F
1	0.24	224
2	0.24	226
3	0.23	225
4	0.25	228
5	0.25	228
6	0.26	228
7	0.26	228
8	0.24	228
9	0.25	228
10	0.28	228
11	0.28	228
12	0.26	228
13	0.24	228
14	0.24	228
15	0.24	228
16	0.25	228
17	0.24	228
18	0.22	228
19	0.22	228
20	0.22	228
21	0.24	228
22	0.24	228
23	0.24	228
24	0.22	228
	0.24	228

01627
1-24-94

**IT AIR QUALITY SERVICES
VELOCITY DETERMINATION**

validated 11/1/90

PLANT :	Miles				
SAMPLE LOCATION :	Dry Gas Exhaust Stack				
	Run No:	M-V-1	M-V-2	M-V-3	AVERAGE
STACK PRESSURE, in Hg :		30.25	30.25	30.27	30.26
STACK TEMP., deg. F :		226	225	228	226
MOLECULAR WEIGHT, DRY :		29.05	29.05	29.05	29.05
MOLECULAR WEIGHT, STACK :		28.75	28.75	28.75	28.75
AVG. SQRT. VELOCITY HEAD :		0.49	0.50	0.49	0.49
VELOCITY, fps :		31.30	31.70	31.49	31.50
ACTUAL CUBIC FEET/ MINUTE :		23599	23901	23747	23749
DRY STANDARD CUBIC FEET/ MINUTE :		17889	18120	17958	17989
AVERAGE FLOW RATE RUN#1 TO RUN#2:		18005 dscfm			Calc by BLB 1/24/94
AVERAGE FLOW RATE RUN#2 TO RUN#3:		18039 dscfm			

07 Calc
1-24-94

IT AIR QUALITY SERVICES EMISSION TEST REPORT

validated 7/3/91

FIELD DATA

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet
Test time (start-stop): 1110-1344

Date: 1/11/94
Run number: Miles-PMM-1

Sample type: Part/Metals
Bar. press. (in. Hg): 30.75
Static press. (in. H2O): -0.250
Filter number(s): 9370107
Stack inside dia. (in.): 48.00
Pitot tube coeff.: 0.84
Total H2O collected (ml): 171.9
% O2 by volume (dry): 19.4

Volume correction (cu. ft.): 0.000
Meter calibration factor: 0.946
Data interval (min.): 6.5
Nozzle dia. (in.): 0.370
Meter box number: FT-5
Number of traverse points: 24
% CO2 by volume (dry): 2.0
% CO by volume (dry): 0.0

Sample time (min)	Gas meter reading (cu. ft.)	Velocity head ΔP (in. H2O)	Orifice drop actual ΔH (in. H2O)	Stack Temp. (°F)	Dry gas meter temp. (°F)	
					inlet	outlet
0.0	935.702					
6.5		0.240	1.65	248	40	40
13.0		0.250	1.73	248	44	40
19.5		0.260	1.81	249	49	40
26.0		0.260	1.85	250	54	44
32.5		0.260	1.83	250	58	44
39.0		0.260	1.86	250	66	54
45.5		0.290	2.08	252	70	56
52.0		0.280	2.01	253	72	56
58.5		0.270	1.95	254	74	60
65.0		0.260	1.87	255	74	60
71.5		0.250	1.80	256	74	60
78.0		0.210	1.51	257	74	60
84.5		0.280	1.98	259	66	56
91.0		0.310	2.20	260	70	56
97.5		0.350	2.48	261	70	56
104.0		0.390	2.75	265	70	56
110.5		0.400	2.84	264	74	58
117.0		0.400	2.85	262	74	60
123.5		0.430	3.11	253	76	62
130.0		0.440	3.23	242	76	64
136.5		0.410	3.05	235	76	64
143.0		0.410	3.08	229	77	65
149.5		0.410	3.08	230	77	65
156.0	1094.632	0.380	2.84	234	78	66
156.0	158.930	0.321	2.31	251	68	58

**IT AIR QUALITY SERVICES
EMISSION TEST REPORT**

validated 7/3/91

FIELD DATA

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet
Test time (start-stop): 1429-1712

Date: 1/11/94
Run number: Miles-PMM-2

Sample type: Part/Metals
Bar. press. (in. Hg): 30.68
Static press. (in. H2O): -0.250
Filter number(s): 9370108
Stack inside dia. (in.): 48.00
Pitot tube coeff.: 0.84
Total H2O collected (ml): 144.7
% O2 by volume (dry): 19.4

Volume correction (cu. ft.): 0.000
Meter calibration factor: 0.946
Data interval (min.): 6.5
Nozzle dia. (in.): 0.370
Meter box number: FT-5
Number of traverse points: 24
% CO2 by volume (dry): 1.4
% CO by volume (dry): 0.0

Sample time (min)	Gas meter reading (cu. ft.)	Velocity head ΔP (in. H2O)	Orifice drop actual ΔH (in. H2O)	Stack Temp. (°F)	Dry gas meter temp. (°F)	
					inlet	outlet
0.0	94.788					
6.5		0.400	2.86	243	56	54
13.0		0.410	2.94	243	58	54
19.5		0.390	2.81	242	60	55
26.0		0.390	2.83	241	66	58
32.5		0.390	2.83	241	67	58
39.0		0.370	2.70	241	70	60
45.5		0.360	2.63	241	70	60
52.0		0.370	2.70	241	70	60
58.5		0.320	2.34	242	71	60
65.0		0.330	2.42	241	71	61
71.5		0.320	2.34	241	71	61
78.0		0.300	2.20	240	71	61
84.5		0.330	2.38	238	60	52
91.0		0.320	2.31	240	62	54
97.5		0.330	2.39	239	64	54
104.0		0.340	2.46	238	66	54
110.5		0.360	2.62	238	66	54
117.0		0.360	2.63	237	66	56
123.5		0.350	2.57	235	68	56
130.0		0.360	2.66	232	69	57
136.5		0.360	2.66	230	69	57
143.0		0.360	2.66	230	69	57
149.5		0.350	2.58	230	68	56
156.0	266.087	0.350	2.58	231	68	56
156.0	171.299	0.355	2.59	238	67	57

0.224
1-24.00

**IT AIR QUALITY SERVICES
EMISSION TEST REPORT**

validated 7/3/91

TEST RESULTS
 Plant: Miles
 Sampling location: Dry Gas Exhaust Outlet

Test date(s): 1/11/94 1/11/94

		<u>Run Numbers</u>		<u>AVERAGE</u>
		<u>Miles-PMM-1</u>	<u>Miles-PMM-2</u>	
Ø	Net time of test (min)	----- 156.0	156.0	
NP	Net sampling points	----- 24	24	
Y	Meter calibration factor	----- 0.946	0.946	
Dn	Sampling nozzle diameter (in)	----- 0.370	0.370	
Cp	Pitot tube coefficient	----- 0.84	0.84	
ΔH	Average orifice pressure drop (in. H ₂ O)	----- 2.31	2.59	2.45
Vm	Volume of dry gas sampled at meter conditions (cu. ft.)	----- 158.930	171.299	165.115
Tm	Average gas meter temperature (°F)	----- 62.0	61.7	61.9
Vmstd	Volume of dry gas sampled at standard conditions (scf)	----- 157.164	169.218	163.191
Vlc	Total H ₂ O collected in impingers and silica gel (ml)	----- 171.9	144.7	158.3
Vwstd	Volume of water vapor at standard conditions (scf)	----- 8.091	6.811	7.451
Bws	Percent moisture by volume, as measured	----- 4.90	3.87	4.39
	Percent moisture by volume, at saturation	----- 100.00	100.00	
	Percent moisture by volume, used in calculations	----- 4.90	3.87	4.39
Fmd	Mole fraction of dry gas	----- 0.951	0.961	0.956
%CO₂	Percent CO ₂ by volume (dry)	----- 2.0	1.4	1.7
%O₂	Percent O ₂ by volume (dry)	----- 19.4	19.4	19.4
%CO	Percent CO by volume (dry)	----- 0.0	0.0	0.0
%N₂	Percent N ₂ by volume (dry)	----- 78.6	79.2	78.9
Md	Molecular weight - dry stack gas	----- 29.10	29.00	29.05
Ms	Molecular weight - stack gas	----- 28.55	28.57	28.56
Pbar	Barometric pressure (in. Hg)	----- 30.75	30.68	30.72
Psi	Static pressure of stack gas (in. H ₂ O)	----- -0.250	-0.250	
Ps	Stack pressure - absolute (in. Hg)	----- 30.73	30.66	30.70
Ts	Average stack gas temperature (°F)	----- 250.7	238.1	244.4

 Calc by
 BCG
 1/24/94

 0.024
 1-24-94

**IT AIR QUALITY SERVICES
EMISSION TEST REPORT**

validated 7/3/91

TEST RESULTS

Plant: **Miles**
Sampling location: **Dry Gas Exhaust Outlet**

Test date(s): 1/11/94 1/11/94

		<u>Run Numbers</u>		<u>AVERAGE</u>
		<u>Miles-PMM-1</u>	<u>Miles-PMM-2</u>	
Vh	Average square root of velocity head (in. H ₂ O)	0.5628	0.5954	0.5791
Vs	Average stack gas velocity (feet/sec.)	36.37	38.16	37.27
As	Stack area (sq. in.)	1809.6	1809.6	1809.6
Qs	Actual stack flow rate (acfm)	27426	28776	28,101
Qstd	Stack flow rate - dry (scfm)	19904	21440	20,672
ISO	Percent isokinetic	85.2	85.2	85.2
Mass of pollutant = If below detection limits, replace 0 with 1. 5.7 0 5.7 5.6 0 5.6				
Mn	Filterable Particulate	mass	mg	
Cs	Filterable Particulate	concentration	gr/dscf	5.351×10^{-4}
Pmr	Filterable Particulate	emission rate	lb/h	9.466×10^{-2}
Mass of pollutant = If below detection limits, replace 0 with 1. 9.0 0 9.0 6.5 0 6.5				
Mn	Barium	mass	µg	
Cs	Barium	concentration	µg/m³	1.690
Pmr	Barium	emission rate	lb/h	1.299×10^{-4}
Mass of pollutant = If below detection limits, replace 0 with 1. 4.3 0 4.3 3.4 0 3.4				
Mn	Chromium	mass	µg	
Cs	Chromium	concentration	µg/m³	0.838
Pmr	Chromium	emission rate	lb/h	6.450×10^{-5}

Calc by
BLL
4/4/94

MY
2/4/94

IT AIR QUALITY SERVICES EMISSION TEST REPORT

validated 7/3/91

TEST RESULTS

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet

Test date(s): 1/11/94 1/11/94

				Run Numbers		AVERAGE
				Miles-PMM-1	Miles-PMM-2	
Mn	Cobalt	Mass of pollutant	=	1.6	1.5	
		If below detection limits, replace 0 with 1.		0	1	
		mass	µg	1.6	<1.5	
Cs	Cobalt	concentration	µg/m3	0.360	<0.313	<0.337
Pmr	Cobalt	emission rate	lb/h	2.680E-05	<2.514E-05	<2.597x10 ⁻⁵
Mn	Copper	Mass of pollutant	=	7.3	3.1	
		If below detection limits, replace 0 with 1.		0	0	
		mass	µg	7.3	3.1	
Cs	Copper	concentration	µg/m3	1.640	0.647	1.144
Pmr	Copper	emission rate	lb/h	1.223E-04	5.195E-05	9.713x10 ⁻⁵
Mn	Lead	Mass of pollutant	=	2.8	2.5	
		If below detection limits, replace 0 with 1.		0	0	
		mass	µg	2.8	2.5	
Cs	Lead	concentration	µg/m3	0.629	0.522	0.576
Pmr	Lead	emission rate	lb/h	4.690E-05	4.189E-05	4.440x10 ⁻⁵
Mn	Manganese	Mass of pollutant	=	4.8	3.1	
		If below detection limits, replace 0 with 1.		0	0	
		mass	µg	4.8	3.1	
Cs	Manganese	concentration	µg/m3	1.079	0.647	0.863
Pmr	Manganese	emission rate	lb/h	8.040E-05	5.195E-05	6.618x10 ⁻⁵
Mn	Nickel	Mass of pollutant	=	6.7	5.0	
		If below detection limits, replace 0 with 1.		0	1	
		mass	µg	6.7	<5.0	
Cs	Nickel	concentration	µg/m3	1.505	<1.043	<1.274
Pmr	Nickel	emission rate	lb/h	1.122E-04	<8.378E-05	<9.799x10 ⁻⁵

Calc by
BCE
2/4/94

2/11/94

**IT AIR QUALITY SERVICES
EMISSION TEST REPORT**

validated 7/3/91

TEST RESULTS

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet

Test date(s): 1/11/94 1/11/94

				<u>Run Numbers</u>		<u>AVERAGE</u>
				<u>Miles-PMM-1</u>	<u>Miles-PMM-2</u>	
		Mass of pollutant	=	57.0	25.0	
		If below detection limits, replace 0 with 1.		0	1	
Mn	Zinc	mass	µg	57.0	<25.0	
Ca	Zinc	concentration	µg/m3	12.808	<5.217	< 9.013
Pmr	Zinc	emission rate	lb/h	9.548E-04	<4.189E-04	< 6.869 x 10 ⁻⁴

Calc by
BLL
2/4/94

2/4/94

IT AIR QUALITY SERVICES EMISSION TEST REPORT

validated 7/3/91

FIELD DATA

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet
Test time (start-stop): 1128-1328

Date: 1/11/94
Run number: Miles-F-1

Sample type: Fluoride
Bar. press. (in. Hg): 30.75
Static press. (in. H2O): -0.250
Filter number(s): NA
Stack inside dia. (in.): 48.00
Pitot tube coeff.: 0.84
Total H2O collected (ml): 42.6
% O2 by volume (dry): 19.4

Volume correction (cu. ft.): 0.000
Meter calibration factor: 1.004
Data interval (min.): 2.5
Nozzle dia. (in.): 0.323
Meter box number: FT-4
Number of traverse points: 24
% CO2 by volume (dry): 2.0
% CO by volume (dry): 0.0

Sample time (min)	Gas meter reading (cu. ft.)	Velocity head ΔP (in. H2O)	Orifice drop actual ΔH (in. H2O)	Stack Temp. (°F)	Dry gas meter temp. (°F)	
					inlet	outlet
0.0	884.118					
2.5		0.240	1.02	247	40	40
5.0		0.250	1.06	249	42	40
7.5		0.260	1.10	250	42	40
10.0		0.280	1.19	248	43	40
12.5		0.280	1.19	248	44	40
15.0		0.290	1.23	250	45	41
17.5		0.290	1.23	250	46	42
20.0		0.300	1.29	250	48	44
22.5		0.310	1.33	250	50	44
25.0		0.310	1.33	252	52	44
27.5		0.300	1.29	252	52	44
30.0		0.290	1.24	252	56	44
32.5		0.370	1.57	262	50	48
35.0		0.390	1.65	264	50	48
37.5		0.380	1.61	263	51	48
40.0		0.380	1.61	263	51	48
42.5		0.400	1.70	262	52	48
45.0		0.430	1.83	262	52	48
47.5		0.460	1.97	258	54	48
50.0		0.460	1.97	258	54	48
52.5		0.470	2.04	248	54	48
55.0		0.440	1.92	244	54	48
57.5		0.440	1.93	240	54	48
60.0	921.924	0.420	1.87	236	60	50
60.0	37.806	0.352	1.51	252	50	45

D Call
1-24-94

**IT AIR QUALITY SERVICES
EMISSION TEST REPORT**

validated 7/3/91

FIELD DATA

Plant: **Miles**
 Sampling location: **Dry Gas Exhaust Outlet**
 Test time (start-stop): **1510-1626**

Date: **1/11/94**
 Run number: **Miles-F-2**

Sample type: **Fluoride**
 Bar. press. (in. Hg): **30.68**
 Static press. (in. H2O): **-0.250**
 Filter number(s): **NA**
 Stack inside dia. (in.): **48.00**
 Pitot tube coeff.: **0.84**
 Total H2O collected (ml): **40.6**
 % O2 by volume (dry): **19.4**

Volume correction (cu. ft.): **0.000**
 Meter calibration factor: **1.004**
 Data interval (min.): **2.5**
 Nozzle dia. (in.): **0.323**
 Meter box number: **FT-4**
 Number of traverse points: **24**
 % CO2 by volume (dry): **1.4**
 % CO by volume (dry): **0.0**

Sample time (min)	Gas meter reading (cu. ft.)	Velocity head ΔP (in. H2O)	Orifice drop actual ΔH (in. H2O)	Stack Temp. (°F)	Dry gas meter temp. (°F)	
					inlet	outlet
0.0	922.132					
2.5		0.330	1.44	242	50	46
5.0		0.350	1.52	241	50	46
7.5		0.370	1.61	241	52	46
10.0		0.370	1.61	242	52	46
12.5		0.360	1.57	242	52	46
15.0		0.360	1.57	241	52	46
17.5		0.360	1.57	241	52	46
20.0		0.350	1.52	241	52	46
22.5		0.350	1.52	241	52	46
25.0		0.360	1.57	240	52	44
27.5		0.360	1.57	240	52	44
30.0		0.350	1.53	240	52	44
32.5		0.320	1.40	240	50	46
35.0		0.310	1.35	240	50	46
37.5		0.320	1.40	239	50	46
40.0		0.320	1.40	239	50	46
42.5		0.310	1.35	240	50	46
45.0		0.340	1.49	239	50	46
47.5		0.350	1.53	239	52	46
50.0		0.350	1.53	239	52	46
52.5		0.380	1.66	239	52	46
55.0		0.370	1.62	238	52	46
57.5		0.370	1.62	238	52	48
60.0	960.237	0.380	1.67	237	52	47
60.0	38.105	0.350	1.53	240	51	46

01-24-94

**IT AIR QUALITY SERVICES
EMISSION TEST REPORT**

validated 7/3/91

TEST RESULTS

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet

Test date(s): 1/11/94 1/11/94 1/1/04

		<u>Run Numbers</u>		0	AVERAGE
		Miles-F-1	Miles-F-2		
Ø	Net time of test (min)	60.0	60.0		
NP	Net sampling points	24	24		
Y	Meter calibration factor	1.004	1.004		
Dn	Sampling nozzle diameter (in)	0.323	0.323		
Cp	Pitot tube coefficient	0.84	0.84		
ΔH	Average orifice pressure drop (in. H ₂ O)	1.51	1.53		1.52
Vm	Volume of dry gas sampled at meter conditions (cu. ft.)	37.806	38.105		37.956
Tm	Average gas meter temperature (°F)	47.4	48.6		48.0
Vmstd	Volume of dry gas sampled at standard conditions (scf)	40.737	40.874		40.806
Vlc	Total H ₂ O collected in impingers and silica gel (ml)	42.6	40.6		41.6
Vwstd	Volume of water vapor at standard conditions (scf)	2.005	1.911		1.958
Bws	Percent moisture by volume, as measured	4.69	4.47		4.58
	Percent moisture by volume, at saturation	100.00	100.00		
	Percent moisture by volume, used in calculations	4.69	4.47		4.58
Fmd	Mole fraction of dry gas	0.953	0.955		0.954
%CO ₂	Percent CO ₂ by volume (dry)	2.0	1.4		1.7
%O ₂	Percent O ₂ by volume (dry)	19.4	19.4		19.4
%CO	Percent CO by volume (dry)	0.0	0.0		
%N ₂	Percent N ₂ by volume (dry)	78.6	79.2		78.9
Md	Molecular weight - dry stack gas	29.10	29.00		29.05
Ms	Molecular weight - stack gas	28.58	28.51		28.55
Pbar	Barometric pressure (in. Hg)	30.75	30.68		30.72
Psl	Static pressure of stack gas (in. H ₂ O)	-0.250	-0.250		
Ps	Stack pressure - absolute (in. Hg)	30.73	30.66		30.70
Ts	Average stack gas temperature (°F)	252.4	240.0		246.2

Calc by

BCL
1/24/94D. Cahill
1/24/94

IT AIR QUALITY SERVICES
EMISSION TEST REPORT

validated 7/3/91

TEST RESULTS

Plant: Miles
Sampling location: Dry Gas Exhaust Outlet

Test date(s): 1/11/94 1/11/94

			Run Numbers		AVERAGE
			Miles-F-1	Miles-F-2	
Vh	Average square root of velocity head (in. H ₂ O)	-----	0.5897	0.5910	0.5904
Ve	Average stack gas velocity (feet/sec.)	-----	38.14	37.98	38.06
As	Stack area (sq. in.)	-----	1809.6	1809.6	
Qs	Actual stack flow rate (acfm)	-----	28759	28634	28,697
Qstd	Stack flow rate - dry (scfm)	-----	20866	21146	21,006
ISO	Percent isokinetic	-----	71.9	71.1	71.5

		Mass of pollutant	=	64.0	55.0	
		If below detection limits, replace 0 with 1.		0	0	
Mn	Fluoride	mass	mg	64.0	55.0	
Cs	Fluoride	concentration	gr/dscf	2.424E-02	2.076E-02	2.25×10^{-2}
Pmr	Fluoride	emission rate	lb/h	4.336E+00	3.763E+00	4.050×10^0

Calc by
BLC
2/4/94M
2.4.94

NOx Emissions Calculations

PLANT : Miles
LOCATION : Dry Gas Exhaust Outlet
DATE : 1/1/94

Barometric Pressure(in. Hg): Final 29.60 Initial 30.34

Run No.	Test Time (24-hr)	Final		Initial		Temp. ° F	Sample Volume ml	PNOx µg	CPPM ppm	Qstd dscfm	NOx Emissions	
		Pressure in. Hg.	Temp. ° F	Pressure in. Hg.	Temp. ° F						lb/dscf	lb/h
M-NOx-1A	0914	3.3	35	26.70	35	1578.8	1700	563	20839	6.72E-05	84.1	
M-NOx-1B	0929	2.5	37	27.00	34	1718.9	1700	517	20839	6.17E-05	77.2	
M-NOx-1C	0944	2.8	34	27.00	34	1720.9	1740	528	20839	6.31E-05	78.9	
M-NOx-1D	0959	2.3	34	26.80	34	1756.8	1800	535	20839	6.40E-05	80.0	
Average								536			6.40E-05	80.0
M-NOx-2A	1014	2.7	33	26.90	33	1718.6	1750	532	20839	6.36E-05	79.5	
M-NOx-2B	1029	2.5	34	26.90	34	1712.4	1780	543	20839	6.49E-05	81.1	
M-NOx-2C	1044	2.3	34	26.70	34	1610.4	1680	545	20839	6.51E-05	81.4	
M-NOx-2D	1059	2.8	34	26.80	34	1633.1	1790	573	20839	6.84E-05	85.6	
Average								548			6.55E-05	81.9

Overall Average

542

6.48E-05

81.0

Calculated by BUC
2/4/94

NOx Emissions Calculations

PLANT : Miles
LOCATION : Dry Gas Exhaust Outlet
DATE : 1/15/94

Barometric Pressure(in. Hg): Final 30.10 Initial 30.26

Run No.	Test Time (24-hr)	Final		Initial		Temp. °F	Pressure in. Hg	Sample Volume ml	PNOx µg	CPPM ppm	Qstd decfm	NOx Emissions	
		Flask Volume ml	Pressure in. Hg	Temp. °F	Pressure in. Hg							lb/decf	lb/h
M-NOx-3A	0730	2020.5	0.2	67	27.50	15	1793.3	1900	554	18005	18005	6.61E-05	71.5
M-NOx-3B	0745	2084.6	0.4	66	27.20	15	1800.4	2110	612	18005	18005	7.32E-05	79.0
M-NOx-3C	0800	2012.8	0.5	67	27.10	14	1739.7	2050	616	18005	18005	7.36E-05	79.5
M-NOx-3D	0815	2027.4	0.8	67	27.10	16	1730.0	1870	565	18005	18005	6.75E-05	72.9
Average									587			7.01E-05	75.7
M-NOx-4A	0830	2014.9	2.2	68	27.00	17	1615.6	2030	657	18039	18039	7.84E-05	84.9
M-NOx-4B	0845	2073.3	1.0	68	26.90	17	1737.5	2190	659	18039	18039	7.87E-05	85.2
M-NOx-4C	0900	2095.9	1.4	67	26.90	16	1732.3	2170	655	18039	18039	7.82E-05	84.6
M-NOx-4D	0915	2049.9	1.0	67	26.90	16	1720.9	2220	674	18039	18039	8.05E-05	87.2
Average									661			7.90E-05	85.6

Overall Average

624

7.46×10^{-5}

80.6

C-1, 6, 8, 10
2/4/94

7-1
4-1-1

NO_x CALCULATIONS

$$\text{Equation 1: } V_s = 17.647 \times (V_f - 25) \times \left[\left(\frac{P_b - P}{T + 460} \right)_f - \left(\frac{P_b - P}{T + 460} \right)_i \right]$$

Where:

V_s = Sample volume, ml

V_f = Flask volume, ml

P_b = Barometric pressure, in.Hg

P = Flask pressure, in.Hg

T = Flask temperature, °F

Note: Subscripts f and i indicate final and initial, respectively.

$$\text{Equation 2: } C_{NO_x} = \frac{522.5 \times P_{NO_x}}{V_s}$$

Where:

C_{NO_x} = NO_x concentration, ppm

P_{NO_x} = micrograms NO_x, µg

$$\text{Equation 3: } C'_{NO_x} = \frac{6.243 \times 10^{-5} \times P_{NO_x}}{V_s}$$

Where:

C'_{NO_x} = NO_x concentration, lb/dscf

$$\text{Equation 4: } E_{NO_x} = C'_{NO_x} \times Q_{s_{std}} \times 60$$

Where:

E_{NO_x} = NO_x emission rate, lb/h

$Q_{s_{std}}$ = Volumetric flow rate, dscfm

APPENDIX C
FIELD DATA



FIELD ACTIVITY DAILY LOG

DAILY LOG	DATE	1	10	94
	NO.			
	SHEET	1	OF	1

PROJECT NAME <i>Miles</i>		PROJECT NO. <i>313674-6</i>	
FIELD ACTIVITY SUBJECT: <i>Set-up Day</i>			
DESCRIPTION OF DAILY ACTIVITIES AND EVENTS: <i>DC & JN Arrive @ 0840</i> <i>Met Alice Webber.</i> <i>Had health & safety briefing</i> <i>She mentioned that scaffolding may not be safe</i> <i>ck'd scaffold - No ladder, no side rails at any level,</i> <i>No kick plates / Alice webber said she would have</i> <i>fixed</i> <i>Began Set-up & calibrations</i> <i>1300 trains set & boxes cal'd</i> <i>1330 talked to Maintenance / they said they could</i> <i>have scaffolding fixed in morning</i> <i>Could not locate Alice Webber / will call later</i> <i>DC & JN off site @ 1400</i>			
VISITORS ON SITE:		CHANGES FROM PLANS AND SPECIFICATIONS, AND OTHER SPECIAL ORDERS AND IMPORTANT DECISIONS. <i>Scaffolding unsafe</i>	
WEATHER CONDITIONS: <i>cold & clear</i>		IMPORTANT TELEPHONE CALLS:	
IT PERSONNEL ON SITE: <i>DC JN</i>			
SIGNATURE <i>Doug Giff</i>		DATE: <i>1-10-94</i>	



INTERNATIONAL
TECHNOLOGY
CORPORATION

FIELD ACTIVITY DAILY LOG

DAILY LOG	DATE	1	11	94
	NO.			
	SHEET	1	OF	1

PROJECT NAME *Miles*

PROJECT NO. *313674-6*

FIELD ACTIVITY SUBJECT: *DAY 1 Testing*

DESCRIPTION OF DAILY ACTIVITIES AND EVENTS:

DC & JN Arrive on site @ 0810

Scaffolding finished & Acceptable

Workers taking off port caps (ok @ 0830)

Began platform set-up

Testing

Test	RUN #	Start	Stop
PART/MM	Miles-M-1	1110	1344
FLOURIDE	Miles-F-1	1128	1328
PART/MM	Miles-M-2	1429	1712
FLOURIDE	Miles-F-2	1510	1626

Tests complete @ 1712

DC & JN off site @ 1745

VISITORS ON SITE:

CHANGES FROM PLANS AND SPECIFICATIONS, AND
OTHER SPECIAL ORDERS AND IMPORTANT DECISIONS.

Scaffolding repaired

WEATHER CONDITIONS:

COLD, clear

IMPORTANT TELEPHONE CALLS:

IT PERSONNEL ON SITE: *DC JN*

SIGNATURE *Doug Caldwell*

DATE: *11/11/94*



FIELD ACTIVITY DAILY LOG

PROJECT NAME <i>Miles</i>		PROJECT NO. <i>313674-6</i>
FIELD ACTIVITY SUBJECT: <i>DAY 2 Testing</i>		
DESCRIPTION OF DAILY ACTIVITIES AND EVENTS: <i>DC & JN Arrive @ 0745</i> <i>Met Alice Webber</i> <i>she informed me that NOx without N₂ compounds test</i> <i>was supposed to be run on 1/11/94</i> <i>It is not possible to switch back at this time</i> <i>I called Scott Furlong (pitts. office), He is going to ck</i> <i>when the plant will return to non N₂ compounds and</i> <i>Coordinate with J.P. concerning scheduling.</i> <i>I called J.P. to inform.</i> <i>Going ahead with Nox testing with N₂ Compounds</i> <i>Testing</i> <i>M-NOx-1A 914-959</i> <i>M-NOx-2A 1014-1059</i> <i>Began tear down</i> <i>talked to Alice Weber</i> <i>she will contact Scott Furlong when she finds out</i> <i>when they can run other Nox tests</i> <i>JN off site 1300</i> <i>DC off site 1330</i>		
VISITORS ON SITE:		CHANGES FROM PLANS AND SPECIFICATIONS, AND OTHER SPECIAL ORDERS AND IMPORTANT DECISIONS.
WEATHER CONDITIONS: <i>Cool, Raining</i>		IMPORTANT TELEPHONE CALLS: <i>Scott Furlong</i> <i>John Prohaska</i>
IT PERSONNEL ON SITE <i>DC, JN</i>		
SIGNATURE <i>Doug Galt</i>		DATE: <i>1-12-94</i>



By _____ Date _____ Subject _____ Sheet No. _____ of _____

Chkd. By _____ Date _____ Proj. No. _____

1-X 3 3-4 4 4-9 5 8 6

Scott Furlong (call when job is done)

Miles LAB plant 0830 or later

Alice Webber or John Jozefouscy



SAFETY TOPICS PRESENTED

Chemical Hazards: residents above

Emergency Procedures EMERGENCY PROCEDURES

Hospital / Clinic St. Vincent's Hospital Home Phone 841

Hospital Address 3005 E. 9th Ave. Denver, CO 80202

Special Equipment

Other _____

NAME: PHILIP DOB: 19/01/1978 SIGNATURE: [Signature]

Meeting conducted by _____

Supervisor _____ Manager _____



TAILGATE SAFETY MEETING

Division/Subsidiary ITAG Facility Cinci
Date 1-11-94 Time 0900 Job Number 318674-6
Customer Miles Address: 301 East
Specific Location Oxy Gas Exhauster
Type of Work source test
Chemicals Used Acid, Acids

SAFETY TOPICS PRESENTED

Protective Clothing/Equipment Hard Hat, safety glasses, shoes
gloves handling reagent
Chemical Hazards reagents above
Physical Hazards scaffold ok
slips, trips, falls
Emergency Procedures call operator
Hospital / Clinic Galva Co Phone (911)
Hospital Address 300 Western
Special Equipment
Other

ATTENDEES

NAME PRINTED

TERRY
DODD

[Signature]
[Signature]

Meeting conducted by:

Doug C. Hill

NAME PRINTED

Supervisor

[Signature]

SIGNATURE

Manager



TAILGATE SAFETY MEETING

Division/Subsidiary ITAO Facility Cinci

Date 1-12-94 Time 0930 Job Number 913674-6

Customer Miles Address: _____

Specific Location Dry Gas Exhauster

Type of Work Source testing

Chemicals Used Acetone 5% HNO₃ / 10% H₂O₂ / 1N HNO₃

SAFETY TOPICS PRESENTED

Protective Clothing/Equipment Hard hat, safety glasses, shoes

Poly gloves when handling reagent

Chemical Hazards Acetone above

Physical Hazards Slips, trips, falls

Emergency Procedures Call plant operator

Hospital/Clinic St. Vincent Phone 911

Hospital Address 3000 ...

Special Equipment _____

Other _____

ATTENDEES

NAME PRINTED

Paul ...

SIGNATURE

[Signature]

Meeting conducted by Doug ...

NAME PRINTED

SIGNATURE

Supervisor _____ Manager _____



TAILGATE SAFETY MEETING

Division/Subsidiary ITT Facility _____
Date 1-15-94 Time 0600 Job Number 313674
Customer ITT Address _____
Specific Location Built dry gas exhaust
Type of Work Source test
Chemicals Used Acids

SAFETY TOPICS PRESENTED

Protective Clothing/Equipment Level 2

Chemical Hazards Acids, ammonia, sulfuric acid

Physical Hazards Extreme cold, heights

Emergency Procedures Call plant for help

Hospital/Clinic Baldwin

Hospital Address 300 ...

Special Equipment _____


Other _____

NAME PRINTED

Meeting conducted by [Signature]

NAME PRINTED

Supervisor _____ Manager _____



* FROM POINT OF ANY TYPE OF
DISTURBANCE (BEND, EXPANSION, CONTRACTION, ETC.)

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Fraction of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter				
	4	6	8	10	12
1	0.067	0.044	0.032	0.026	0.021
2	0.250	0.146	0.105	0.082	0.067
3	0.750	0.296	0.194	0.146	0.118
4	0.933	0.704	0.323	0.226	0.177
5		0.854	0.677	0.342	0.250
6		0.956	0.806	0.658	0.356
7			0.895	0.774	0.644
8			0.968	0.854	0.750
9				0.918	0.823
10				0.974	0.882
11					0.933
12					0.979

FIELD AUDIT REPORT: DRY GAS METER
BY CRITICAL ORIFICE

DATE: 1-10-94 CLIENT: Miles Lab
 BAROMETRIC PRESSURE (P_{bar}): 30.88 in.Hg METER BOX NO. ET-4
 ORIFICE NO. 3 PRETEST Y: 1.004 $\Delta H@$ 1.98 in.H₂O
 ORIFICE K FACTOR: 5.483×10^{-4} AUDITOR: J. Neese

Orifice manometer reading ΔH , in. H ₂ O	Dry gas meter reading V_i/V_f , ft ³	Temperatures					Duration of run ϕ min.
		Ambient		Dry gas meter			
		T_{ai}/T_{af} , °F	Average T_a , °F	Inlet T_{ii}/T_{if} , °F	Outlet T_{oi}/T_{of} , °F	Average T_m , °F	
2.90	868.3	30	30	46	46	46	17.28.38
	883.6	30		46	46		

Dry gas meter V_m , ft ³	V_{mstd} , ft ³	V_{mact} , ft ³	Audit, Y	Y deviation, %	Audit $\Delta H@$, in.H ₂ O	$\Delta H@$ Deviation, in.H ₂ O
15.3	16.59	16.08	1.04 0.969	3.5%	2.06	.08

$$V_{mstd} = \frac{17.647(V_m)(P_{bar} + \Delta H/13.6)}{(T_m + 460)} = 16.59 \text{ ft}^3$$

$$V_{mact} = \frac{1203(\phi)(K)(P_{bar})}{(T_a + 460)^{1/2}} = 16.075 \text{ ft}^3$$

$$\text{Audit } Y = \frac{V_{mact}}{V_{mstd}} = 0.969 \quad Y \text{ deviation} = \frac{\text{Audit } Y - \text{Pretest } Y}{\text{Pretest } Y} \times 100 = 3.5\%$$

$$\text{Audit } \Delta H@ = (0.0317)(\Delta H)(P_{bar})(T_m + 460) \left[\frac{\phi}{Y(V_m)(P_{bar} + \Delta H/13.6)} \right]^2 = 2.06 \text{ in.H}_2\text{O}$$

Audit Y must be in the range, pretest $Y \pm 0.05 Y$.
 Audit $\Delta H@$ must be in the range pretest $\Delta H@ \pm 0.15$ inches H₂O.



INTERNATIONAL
TECHNOLOGY
CORPORATION

DIGITAL INDICATOR AUDIT DATA SHEET

Indicator No. ET-4
Client Miles Lab.
Date 1-10-94

Project No. 313674-6
Operator J. Neese

Test Point No.	Equivalent Temperature F	Digital Indicator Temperature F	% Difference
1	0	1	.22
2	100	99	.18
3	200	199	.15
4	400	398	.23

Percent Difference Must Be Less Than or Equal To 0.5%

Percent Difference:

$$\frac{-(\text{Equivalent Temperature} - \text{Digital Indicator Temperature})(100)}{(\text{Equivalent Temperature} + 460)}$$

FIELD AUDIT REPORT: DRY GAS METER
BY CRITICAL ORIFICE

DATE: 1-10-94 CLIENT: Miles
BAROMETRIC PRESSURE (P_{bar}): 30.88 in.Hg METER BOX NO. ET-5
ORIFICE NO. 3 PRETEST Y: 946 $\Delta H@$ 1.34 in.H₂O
ORIFICE K FACTOR: 5.483×10^{-4} AUDITOR: J.N.

Orifice manometer reading ΔH , in. H ₂ O	Dry gas meter reading V_i/V_f , ft ³	Temperatures					Duration of run ϕ min.
		Ambient		Dry gas meter			
		T_{ai}/T_{af} , °F	Average T_a , °F	Inlet T_{ii}/T_{if} , °F	Outlet T_{oi}/T_{of} , °F	Average T_m , °F	
1.95	918.7	30	30	44	42	44	12/12.93
	934.3	30		48	42		

Dry gas meter V_m , ft ³	V_{mstd} , ft ³	V_{mact} , ft ³	Audit, Y	Y deviation, %	Audit $\Delta H@$, in.H ₂ O	$\Delta H@$ Devia- tion, in.H ₂ O
<u>15.6</u>	<u>16.944</u>	<u>15.845</u>	<u>.935</u>	<u>1.16</u>	<u>1.36</u>	<u>0.02</u>

$$V_{mstd} = \frac{17.647(V_m)(P_{bar} + \overset{31.02}{\Delta H/13.6})}{(T_m + \overset{504}{460})} = 16.944 \text{ ft}^3$$

$$V_{mact} = \frac{1203(\emptyset)(K)(P_{bar})}{(T_a + 460)^{\frac{1}{2}}} = 15.845 \text{ ft}^3$$

$$\text{Audit } Y = \frac{V_{mact}}{V_{mstd}} = .935 \quad Y \text{ deviation} = \frac{\text{Audit } Y - \text{Pretest } Y}{\text{Pretest } Y} \times 100 = 1.16$$

$$\text{Audit } \Delta H@ = (0.0317)(\overset{1.44}{\Delta H})(P_{bar})(T_m + \overset{504}{460}) \left[\frac{\emptyset^{\overset{17.22}{1.722}}}{Y(V_m)(P_{bar} + \overset{31.02}{\Delta H/13.6})} \right]^2 = 1.36 \text{ in.H}_2\text{O}$$

Audit Y must be in the range, pretest $Y \pm 0.05 Y$.
Audit $\Delta H@$ must be in the range pretest $\Delta H@ \pm 0.15$ inches H₂O.



INTERNATIONAL
TECHNOLOGY
CORPORATION

DIGITAL INDICATOR AUDIT DATA SHEET

Indicator No. ET-5
Client Miles Lab
Date 1-10-94

Project No. 313674-6
Operator J. NERSE

Test Point No.	Equivalent Temperature F	Digital Indicator Temperature F	% Difference
1	0	0	0
2	100	98	.36
3	200	200	0
4	400	398	.23

Percent Difference Must Be Less Than or Equal To 0.5%

Percent Difference:

$$\frac{-(\text{Equivalent Temperature} - \text{Digital Indicator Temperature})(100)}{(\text{Equivalent Temperature} + 460)}$$



142

TEST NO MULES - M-1

SAMPLING TIME (24-hr CLOCK) 1110-1350

~~SAMPLING LOCATION~~ Dry Gas Expander Stack

SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS)

ANALYTICAL METHOD ORSA

AMBIENT TEMPERATURE

OPERATOR JN

ORSAT LEAK CHECKED ☒

RUN GAS	1		2		3		AVERAGE NET VOLUME	MULTIPLIER	MOLECULAR WEIGHT OF STACK GAS (DRY BASIS) M _g , lb 'lb-mole
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET			
CO ₂	2.0	2.0	2.0	2.0			2.0	44/100	
O ₂ (NET IS ACTUAL O ₂ READING MINUS ACTUAL CO ₂ READING)	21.4	19.4	21.4	19.4			19.4	32/100	
CO (NET IS ACTUAL CO READING MINUS ACTUAL O ₂ READING)							✓ 28.6 11/14/44	28/100	
N ₂ (NET IS 100 MINUS ACTUAL CO READING)								28/100	
TOTAL									

GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant and City Miles Baltimore Md Date 1-11-93
Sampling Location DRY GAS EXHAUSTER Clock Time 0845
Run No. Pre test Operator DC & JN
Barometric Pressure, in. Hg 30.75 Static Pressure, in. H₂O 7.25
Moisture, % 25 Molecular wt., Dry 29.12 Pitot Tube, Cp .84
Stack Dimension, in. Diameter or Side 1 48 ~~Side 2~~

FIELD DATA

[illegible]

CALCULATIONS

$$M_s = M_d \times \left(1 - \frac{H_2O}{100}\right) + 18 \left(\frac{H_2O}{100}\right)$$

$$m_s = (29.12) \times (1 - \frac{5}{100}) + 18 (\frac{5}{100})$$

$M_s = 28.56$

$$T_s = 245 \quad ^\circ F = 705 \quad ^\circ R = (^{\circ}F + 460)$$

$$P_s = P_b + \frac{S.P.}{13.6} = (\quad) + \frac{\quad}{13.6}$$

$P_s = 30.73$ in. Hg

$$\sqrt{\Delta P} = .474$$

$$V_s = 85.49 \times C_D \times \sqrt{\Delta P} \times \sqrt{\frac{T_s}{P_s \times M_s}} \times \sqrt{\frac{R}{M_s}}$$

$$V_s = 85.49 \times (\quad) \times (\quad) \times \sqrt{\frac{1}{x}}$$

$$V_s = 27.3 \text{ ft/s}$$

$$A_s = 12.57 \text{ in}^2$$

$$Q_s = V_s \times A_s \times \frac{60 \text{ s}}{\text{min}}$$

$$Q_s = \quad \times \quad \times 60$$

$Q_s = 20,589$ acfm

$$Q_{s, \text{std}} = Q_s \times 17.647 \times \frac{P_s}{T_s} \times \left(1 - \frac{H_2O}{100}\right)$$

$$Q_{std} = 17.647 \times \frac{100}{100} \times (1 - \frac{100}{100})$$

Q_s std dscfm

CALCULATIONS FOR SELECTING A NOZZLE AND SETTING ISOKINETIC SAMPLING RATES

I. NOZZLE SELECTION

$$D_n = \left(\frac{T_s M_s}{\Delta P P_s} \right)^{0.25} \left(\frac{0.02678 P_b}{(1-B_{wo}) T_m C_p} \right)^{0.5}$$

T_s , °R	M_s	ΔP	P_s , in.Hg	P_b , in.Hg	B_{wo} , decimal	$(1-B_{wo})$, decimal	T_m , °R	C_p	D_n , inches
705	28.56	.23	30.73	30.75	.05 +	.95	530	.84	.322
					→				

Note: Approximate $\Delta H = \left(\frac{D_n \text{ selected}}{D_n \text{ calculated}} \right)^4 \times \Delta H_a$

II. K FACTOR FOR ISOKINETIC EQUATION

$$K = D_n^4 C_p^2 (1-B_{wo})^2 (850.5 \Delta H_a) \frac{M_d}{M_s} \frac{P_s}{P_m}$$

D_n , in.	C_p	B_{wo} , decimal	$(1-B_{wo})$, decimal	ΔH_a	M_d	M_s	P_s , in.Hg	P_m , in.Hg	K
.323	.84	.05 +	.95						6.01 F#4
		→							
.370	.84	.05 +	.95						9.76 FTS

III. ISOKINETIC ΔH CALCULATION

$$\Delta H = K \frac{\Delta P T_m}{T_s} \text{ for } T = \text{°R}$$

If desired, a calculator can be programmed to calculate ΔH during a test by storing the K value calculated above.

1. Program: GTO 000, LRN, 2nd Lbl, A, CLR, RCL, 1, x, (, R/S, +, 4, 6, 0,), ÷, (, R/S, +, 4, 6, 0,), x, R/S, =, R/S, LRN.
2. Store K in Register 01.
3. Press A, enter t_m , °F, press R/S, enter t_s , °F, press R/S, enter ΔP , press R/S, ΔH is displayed.
4. For next point, repeat step 3.

Note: To verify program let $K = 10$, $t_m = 70^\circ\text{F}$, $t_s = 250^\circ\text{F}$, $\Delta P = 1.0$, $\rightarrow \Delta H = 7.46$



COMMENTS: 142

TEST NO. M-195 - M-2

1

Exhauster Stack

CONTINUOUS)

13

RUN GAS	1		2		3		AVERAGE NET VOLUME	MULTIPLIER	MOLECULAR WEIGHT OF STACK GAS (DRY BASIS) M _D , lb/lb-mole
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET			
CO ₂	1.4	1.4	1.4	1.4			1.4	44/100	
O ₂ (NET IS ACTUAL O ₂ READING MINUS ACTUAL CO ₂ READING)	20.8	19.4	20.8	19.4			19.4	32/100	
CO (NET IS ACTUAL CO READING MINUS ACTUAL O ₂ READING)							✓ 11/14/44	28/100	
N ₂ (NET IS 100 MINUS ACTUAL CO READING)								28/100	
TOTAL									

PARTICULATE/METALS TRAIN SAMPLE RECOVERY AND INTEGRITY SHEET

Plant Miles
 Sample location Dry Gas Exhauster
 Run number Miles - PMM - 1
 Filter number(s) 9370107

Sample date 1-11-94
 Recovery date 1-11-94
 Recovered by DC

MOISTURE

Impingers	Condensate	1st	2nd	3rd	4th	5th
Contents	<u>Empty</u>	<u>5% HNO₃/10% H₂O₂</u>	<u>Empty</u>	<u>KMnO₄</u>	<u>Silica gel</u>	<u>Silica gel</u>
Final wt/vol	<u>X</u> g	<u>661.9</u> g	<u>647.4</u> g	<u>508.5</u> g	<u>703.4</u> g	<u>X</u> g
Initial wt/vol	<u>X</u> g	<u>591.6</u> g	<u>592.1</u> g	<u>495.6</u> g	<u>670.0</u> g	<u>X</u> g
Net Gain	<u>X</u> g	<u>70.3</u> g	<u>55.3</u> g	<u>12.9</u> g	<u>33.4</u> g	<u>X</u> g
Description of impinger water <u>clean</u>						

Total moisture 171.9 g ✓ 1/14/94
BLC

RECOVERED SAMPLE

Filter container number(s) 01945B Sealed ✓
 Description of particulate on filter Very light

	Sample solution/rinse container numbers	Sealed/liquid level marked
Acetone probe rinse	<u>01945A</u>	<u>✓</u>
5% HNO ₃ /10% H ₂ O ₂ solution and 0.1N HNO ₃ rinse	<u>01946A</u>	<u>✓</u>
KMnO ₄ solution and rinse	<u>NOT USED</u>	<u> </u>
8N HCl rinse	<u>NOT USED</u>	<u> </u>

Samples stored and locked ✓
 Remarks Blanks, Acetone 01425A, 1N HNO₃ 01423A,
5% HNO₃ 10% H₂O₂ 01424A, Pallflex filter 01423B



Emission Testing Field Data

Plant and City		Date		Sampling Location		Sample Type		Run Number	
Miles		Baltimore, Md		1/11/84 Dry Gas Exhaust Out		PART/mw		Miles PM10	
Operator(s)		Bar. Press. (in. Hg)	Static Press. (in. H ₂ O)	Amb. Temp. (°F)	Filter Number(s)	Probe Length and Type		Nozzle	
Mc & JV		20.64	-12.5	29	Q320108	6FT CLASS		320	
								G-101	

Moisture (%)	Meter Box No.	Meter ΔH @	Meter Cal. Factor (Y)	K Factor	Probe Heat (°F)	Box Heat (°F)	Therm. No.	Pilot No.	Imp. Therm. No.	Gas Bag Pump No.	Gas Bag Sys. Leak Check	Train Leak Check (Initial)	CFM	In. Hg	Train Leak Check (Final)	CFM	Initial	Pilot Leak Check
~3	FT-5	1.34	946	9.76	250	250	690	559	149	102	✓	14	0.002	5	0.000	✓	✓	✓

Traverse Point No.	Sampling Time (min.)	Clock Time (24-hr)	Gas Meter Reading (V _m), ft ³	Velocity Head* (ΔP), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O*		Stack (T _s)	Dry Gas Meter		Temperature (°F)		Resin	Imp. Inger	Pump Vac. (in. Hg)	Gas Bag Sample Data
					Desired	Actual		Inlet (T _m)	Outlet (T _m)	Probe	Sample Box				
1	6.5	1442	102.1	.40	2.96	2.86	243	56	54	246	249	N/A	51	3	2000
2	13	1442	109.6	.41	2.94	2.94	243	58	54	253	253		55	4	
3	19.5	1445	117.1	.37	2.91	2.81	242	60	53	253	255		57	4	
4	26	1455	124.3	.39	2.93	2.83	241	65	58	251	252		60	4	
5	32.5	1504	132.3	.37	2.83	2.83	241	67	58	253	254		62	4	
6	39	1504	139.4	.37	2.70	2.70	241	70	60	247	250		63	4	
7	45.5	1521	146.7	.39	2.63	2.63	241	70	60	245	249		64	4	
8	52	1521	154.3	.32	2.70	2.70	242	71	60	250	253		67	4	
9	58.5	1534	160.6	.32	2.74	2.74	242	71	60	253	254		62	4	
10	65	1534	167.5	.32	2.42	2.42	241	71	61	253	258		60	4	
11	71.5	1547	174.4	.33	2.34	2.34	240	71	61	251	254		60	3	STOP
12	78	1547	180.9	.33	2.38	2.38	238	60	53	255	257		50	3	START
A1	84.5	1607	187.8	.32	2.31	2.31	240	62	54	248	250		48	3	2000
2	91	1607	194.6	.32	2.39	2.39	239	64	54	253	251		49	3	
3	97.5	1620	201.4	.34	2.46	2.46	238	66	54	251	255		50	3	
4	104	1620	208.4	.36	2.42	2.42	238	66	54	253	251		50	3	
5	110.5	1633	215.4	.36	2.63	2.63	237	65	56	254	252		50	3	
6	117	1633	222.7	.35	2.57	2.57	235	68	56	251	250		50	4	
7	123.5	1646	229.8	.36	2.66	2.66	232	69	57	253	255		51	4	
8	130	1646	237.9	.36	2.66	2.66	230	69	57	255	253		51	4	
9	136.5	1659	244.3	.36	2.66	2.66	230	69	57	255	254		51	4	
10	143	1659	251.7	.35	2.69	2.69	230	68	56	255	254		52	4	
11	149.5	1712	258.9	.35	2.58	2.58	239	68	56	254	252		52	4	
12	156	1712	266.0	.35	2.58	2.58	239	68	56	254	252		52	4	

*Record pressure differentials to 2 significant figures, e.g., 0.015, 0.88, 1.2, etc.

Comments:

**PARTICULATE/METALS TRAIN
SAMPLE RECOVERY AND INTEGRITY SHEET**

Plant Miles
Sample location Dry Gas Exhauster
Run number Miles-PMM-2
Filter number(s) 9370108

Sample date 1-11-94
Recovery date 1-11-94
Recovered by DC

MOISTURE

Impingers	Condensate	1st	2nd	3rd	4th	5th
Contents	Empty	5% HNO_3 /10% H_2O_2	Empty	KMnO_4	Silica gel	Silica gel
Final wt/vol	X	g 655.6	g 670.5	g 486.4	g 738.0	g X
Initial wt/vol	X	g 620.2	g 619.1	g 471.6	g 705.0	g X
Net Gain	X	g 45.5	g 51.4	g 14.8	g 33	g X
Description of impinger water <u>clean</u>						

Total moisture 144.7 g ✓ BLG
11/14/94

RECOVERED SAMPLE

Filter container number(s) 01947B Sealed ✓
Description of particulate on filter Very light

	Sample solution/rinse container numbers	Sealed/liquid level marked
Acetone probe rinse	<u>01947A</u>	<u>✓</u>
5% HNO_3 /10% H_2O_2 solution and 0.1N HNO_3 rinse	<u>01948A</u>	<u>✓</u>
KMnO_4 solution and rinse	<u>Not Used</u>	
8N HCl rinse	<u>Not Used</u>	

Samples stored and locked ✓
Remarks _____



Emission Testing Field Data

Plant and City		Date	Sampling Location	Sample Type	Run Number
MILES		1/11/84	DRY GAS EXHAUST OUT	FLUORIDE	MILES-F-1

Operator(s)	Bar. Press. (in. Hg)	Static Press. (in. H ₂ O)	Amb. Temp. (°F)	Filter Number(s)	Probe Length and Type	Nozzle	
	30.75	2.5	26	PAPER N.T.	6 FT GLASS	Dia. (in.)	Number
DC & JA						3.23	5-107

Moisture (%)	Meter Box No.	Meter Δ H @	Meter Cal. Factor (Y)	K Factor	Probe Heat (°F)	Box Heat (°F)	Therm. No.	Pilot No.	Imp. Therm. No.	Gas Bag Pump No.	Gas Bag Sys. Leak Check	Train Leak Check (Initial)	Train Leak Check (Final)	CFM	CFM	Pilot Leak Check initial	Pilot Leak Check final
25	FT4	1.98	1.004	6.01	250	250	250	250	250	N/A	—	13	0.003	3	0.002	✓	✓

Traverse Point No.	Sampling Time (min.)	Clock Time (24-hr)	Gas Meter Reading (V _m), ft ³	Velocity Head* (ΔP), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O*		Stack (T _s)	Temperature (°F)				Sample Box	Resin	Imp-inger	Pump Vac. (in. Hg)	Gas Bag Sample Data
					Desired	Actual		Inlet (T _m)	Dry Gas Meter		Probe					
									Outlet (T _m)							
B 12	0	11:28	884.118	1.24	1.02	1.02	247	42	42	247	N/A	N/A	43	1	N/A	
11	2.5	11:33	885.4	1.25	1.06	1.06	249	42	40	251			45	1		
10	7.5		886.7	1.26	1.10	1.10	250	42	40	253			46	1		
9	10		889.4	1.28	1.19	1.19	248	43	40	251			46	1		
8	12.5	11:43	890.8	1.28	1.19	1.19	248	44	40	252			44	1		
7	15		892.3	1.29	1.23	1.23	250	45	41	253			44	1		
6	17.5		893.7	1.29	1.23	1.23	250	46	42	253			45	1		
5	20	11:48	895.2	1.30	1.29	1.29	250	48	44	254			44	1		
4	22.5		896.7	1.31	1.33	1.33	250	50	44	250			46	1		
3	25		898.2	1.31	1.33	1.33	252	52	44	253			47	1		
2	27.5	11:58	899.6	1.30	1.29	1.29	252	52	44	252			48	1		
1	30		901.062	1.29	1.24	1.24	252	56	44	254			49	1		
A 12	32.5		902.7	1.37	1.57	1.57	262	50	48	255			44	2		
11	35	13:03	904.4	1.39	1.65	1.65	264	50	48	253			43	2		
10	37.5		906.0	1.38	1.61	1.61	263	51	48	255			42	2		
9	40		907.6	1.38	1.61	1.61	263	51	48	255			43	2		
8	42.5	13:13	909.3	1.40	1.70	1.70	262	52	48	253			43	2		
7	45		911.1	1.43	1.83	1.83	262	52	48	255			45	2		
6	47.5		913.0	1.46	1.97	1.97	258	54	48	256			46	2		
5	50	13:18	914.8	1.46	1.97	1.97	258	54	48	259			47	2		
4	52.5		916.6	1.47	2.04	2.04	248	54	48	255			48	2		
3	55		918.9	1.44	1.92	1.92	246	54	48	257			48	2		
2	57.5	13:28	920.1	1.44	1.98	1.98	246	54	48	253			49	2		
1	60		921.24	1.42	1.87	1.87	236	60	50	250			50	2		

*Record pressure differentials to 2 significant figures, e.g., 0.015, 0.88, 1.2, etc. Comments: @ port change, wait for flame train / START @ 12:58

FLOURIDE

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant Miles Sample date 1-11-94
 Sample location Dry Gas Exhauster Recovery date 1-11-94
 Run number Miles - F - 1 Recovered by DC
 Filter number(s) PAPER N.T.

MOISTURE

Impingers	Silica gel
Final volume (wt) <u>231</u> ml(g)	Final wt <u>211.6</u> g
Initial volume (wt) <u>200</u> ml(g)	Initial wt <u>200</u> g
Net volume (wt) <u>31</u> ml(g)	Net wt <u>11.6</u> g
Description of impinger water <u>clean</u>	<u>20</u> % spent

Total moisture 42.6 g 1/11/94

RECOVERED SAMPLE

Filter container number(s) Paper N.T. Sealed IN POLY CONTAINER
 Description of particulate on filter NONE visible

Probe rinse container no. <u>01950A</u>	Liquid level marked <u>✓</u>
<u>DE H2O</u> blank container no. <u>01952A</u>	Liquid level marked <u>✓</u>
Impinger contents container no. <u>01950A</u>	Liquid level marked <u>✓</u>
<u>Filter</u> blank container no. <u>01952B</u>	Liquid level marked <u>N/A</u>

Samples stored and locked ✓
 Remarks _____

LABORATORY CUSTODY

Received by _____ Date _____
 Remarks _____



Emission Testing Field Data

Plant and City		Date	Sampling Location	Sample Type	Run Number
Miles	Baltimore MD	1/11/94	DRY GAS EXHAUST	WJT FLOURRIE	M. 105-F-2

Operator(s)	Bar. Press. (in. Hg)	Static Press. (in. H ₂ O)	Amb. Temp. (°F)	Filter Number(s)	Probe Length and Type	
					Dia. (in.)	Number
DL & JN	30.68	2.25	29	PAPER NT.	6 FT GLASS	5-107

Moisture (%)	Meter Box No.	Meter Δ H @	Meter Cal. Factor (Y)	K Factor	Probe Heat (°F)	Box Heat (°F)	Therm. No.	Pilot No.	Imp. Therm. No.	Gas Bag Pump No.	Gas Bag Sys. Leak Check	Train Leak Check (Initial)	Train Leak Check (Final)	CFM	in. Hg	Pilot Leak Check initial	Pilot Leak Check final
25	FT4	1.98	1.004	6.01	250	-	21	H-1	21	-	-	13	0.006	3	0.003	✓	✓

Traverse Point No.	Sampling Time (min.)	Clock Time (24-hr)	Gas Meter Reading (V _m), ft ³	Velocity Head* (ΔP), in. H ₂ O	Onifice Pressure Differential (ΔH), in. H ₂ O*		Stack (T _s)	Dry Gas Meter		Temperature (°F)	Sample Box	Resin	Imp-inger	Pump Vac. (in. Hg)	Gas Bag Sample Data
					Desired	Actual		Inlet (T _m)	Outlet (T _m)	Probe					
A1	0	15:10	922.2	1.32	1.44	1.44	242	50	46	251	N/A	N/A	40	1	N/A
2	5	1515	925.3	1.35	1.52	1.52	241	50	46	254			39	1	
3	7.5		926.9	1.37	1.61	1.61	241	52	46	251			41	1	
4	10	1520	928.6	1.37	1.61	1.61	242	52	46	250			41	1	
5	12.5		930.2	1.36	1.57	1.57	242	52	46	252			42	1	
6	15	1525	931.8	1.36	1.57	1.57	241	52	46	250			43	1	
7	17.5		933.4	1.36	1.57	1.57	241	52	46	253			43	1	
8	20	1530	935.0	1.35	1.52	1.52	241	52	46	255			44	1	
9	22.5		936.6	1.35	1.52	1.52	241	52	46	253			44	1	
10	25	1535	938.2	1.36	1.57	1.57	240	52	44	250			45	1	
11	27.5		939.8	1.36	1.57	1.57	240	52	44	252			45	1	
12	30	1540	941.422	1.35	1.53	1.53	240	52	44	255			45	1	
B1	32.5		943.0	1.32	1.40	1.40	240	50	46	251			45	1	
2	35	1601	944.5	1.31	1.35	1.35	240	50	46	254			42	1	
3	37.5		946.0	1.32	1.40	1.40	239	50	46	252			43	1	
4	40	1606	947.6	1.32	1.40	1.40	239	50	46	254			43	1	
5	42.5		949.1	1.31	1.35	1.35	240	50	46	251			44	1	
6	45	1611	950.6	1.34	1.49	1.49	239	50	46	255			44	1	
7	47.5		952.0	1.35	1.53	1.53	239	52	46	256			44	1	
8	50	1616	953.6	1.33	1.53	1.53	239	52	46	252			45	1	
9	52.5		955.1	1.38	1.66	1.66	239	52	46	252			45	1	
10	55	1621	956.8	1.37	1.62	1.62	238	52	46	250			46	1	
11	57.5		958.5	1.37	1.62	1.62	238	52	47	251			47	1	
12	60	1626	960.237	1.38	1.67	1.67	237	52	48	253			46	1	

*Record pressure differentials to 2 significant figures, e.g., 0.015, 0.88, 1.2, etc. Comments:

FLOURIDE

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant Miles Sample date 1-11-94
 Sample location Dry GAS Exhauster Recovery date 1-11-94
 Run number Miles-F-2 Recovered by DC
 Filter number(s) PAPER N.T

MOISTURE

Impingers		Silica gel
Final volume (wt) <u>230</u> ml(g)		Final wt <u>210.6</u> g
Initial volume (wt) <u>200</u> ml(g)		Initial wt <u>200</u> g
Net volume (wt) <u>30</u> ml(g)		Net wt <u>10.6</u> g
Description of impinger water <u>clean</u>		<u>20</u> % spent

Total moisture 40.6 g ✓ BUG
11/14/94

RECOVERED SAMPLE

Filter container number(s) Paper N.T. Sealed In Poly Container
 Description of particulate on filter None Visible

Probe rinse container no. <u>01951A</u>	Liquid level marked <u>✓</u>
<u>DE H₂O</u> blank container no. <u>01952A</u>	Liquid level marked <u>✓</u>
Impinger contents container no. <u>01951A</u>	Liquid level marked <u>✓</u>
<u>Filter</u> blank container no. <u>01952B</u>	Liquid level marked <u>N/A</u>

Samples stored and locked ✓
 Remarks _____

LABORATORY CUSTODY

Received by _____ Date _____
 Remarks _____

Baltimore

SAMPLE LOCATION: DRY GAS EXHAUSTER

1953-54

25-11

DATE: 1-12-2014

INITIAL BAROMETRIC PRESSURE:

FINAL BAROMETRIC PRESSURE: 87.02

[illegible]

Reagent blank IO# 00468A

10



INTERNATIONAL
TECHNOLOGY
CORPORATION

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD *

Reference Document No. 42402/
Page 1 of

White: To accompany samples Yellow: Field copy *See back of form for special instructions.

Project Name/No. 1 Miles/313674-6 Samples Shipment Date 7 1-13-94 Bill to: ITACS - Cincinnati
Sample Team Members 2 DC, JN Lab Destination 8 Cincinnati Lab Contact 9 Ken Mueller
Profit Center No. 3 3572 Project Manager 4 B. Carls Project Contact/Phone 12 Blacks Report to: 10 B. Carls
Purchase Order No. 6 To be determined Carrier/Waybill No. 13 Cincinnati - ITACS

Required Report Date 11

ONE CONTAINER PER LINE

Sample Number	Sample 15 Description/Type	Date/Time Collected	Sample 16 Container Type	Sample 17 Volume	Sample 18 Pre-servative	Requested Testing Program	Condition on Receipt	Disposal 22 Record No.
01945A	Miles - PMM - 1	1-11-94	500ml Amber			PART/MM Per BIF		
01946A	Front Rinse	1-11-94	1000ml Amber			" (Ba, Co, Cu, Pb, Zn)		
01945B	Back half Rinse 3 SOLUTION 9370107	1-11-94	Petri			" Pb + Zn		
01947A	Palladium filter	1-11-94	250ml Amber			"	BUG, 1/14/94	
01948A	Miles - PMM - 2	1-11-94	500ml Amber			"		
01947B	Front Rinse	1-11-94	1000ml Amber			" Notified Ken Mueller (ITACS - Cincinnati)		
01423A	Back half Rinse 3 SOLUTION 9370108	1-11-94	Petri			" of Metals and proper methods		
01424A	Palladium filter	1-11-94	250ml Amber			"		
	INVENTS BLANK	1-11-94	250ml Amber			"		
	5% HNO ₃ 10% H ₂ O ₂ BLANK	1-11-94	250ml Amber			"		

Special Instructions: 23

Possible Hazard Identification: 24

Non-hazard ☐ Flammable ☒ Skin Irritant ☒ Poison B ☐ Unknown ☐

Sample Disposal: 25

Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

Turnaround Time Required: 26

Normal ☒ Rush ☐

QC Level: 27

Project Specific (specify):

1. Relinquished by 28

(Signature/Affiliation)

Date: 1-13-94

Time: 1740

1. Received by 28

(Signature/Affiliation)

Date: 1-13-94

Time: 1740

2. Relinquished by

(Signature/Affiliation)

Date:

Time:

2. Received by

(Signature/Affiliation)

Date:

Time:

3. Relinquished by

(Signature/Affiliation)

Date:

Time:

3. Received by

(Signature/Affiliation)

Date:

Time:

Comments: 29



Reference Document No. 30 4248-7
Page 2 of 2

Samples Shipment Date: 1-13-14

*See back of form for special instructions

ONE CONTAINER PER LINE

[illegible]

M-NOX-2A, 2B, 2C, 2D



Emission Testing Field Data

Operator(s)	Bar. Press. (in. Hg)	Static Press. (in. H ₂ O)	Amb. Temp. (°F)	Filter Number(s)	Probe Length and Type	Nozzle	
						Dia. (in.)	Number
JN	30.26	- 0.11	10	—	3' Glass	—	—

Moisture (%)	Meter Box No.	Meter ΔH @	Meter Cal. Factor (Y)	K Factor	Probe Heat ($^{\circ}F$)	Box Heat ($^{\circ}F$)	Therm. No.	Pilot No.	Imp. Therm. No.	Gas Bag Pump No.	Gas Bag Sys. Leak Check	Train Leak Check (Initial)		Train Leak Check (final)		Pilot Leak Check	
												In. Hg	CFM	In. Hg	CFM	Initial	final
---	FT-10	197	978	---	250	---	---	---	197	---	---	15	CFM	2	CFM	---	---

[illegible]

*Record pressure differentials to 2 significant figures, e.g., 0.015, 0.88, 1.2, etc. Comments:

(continue on reverse, if necessary)

2. 4. 74

GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant and City Miles Lab Baltimore Date 1-15-94
Sampling Location Stack Clock Time 0920
Run No. M-V-3 Operator JN, SF
Barometric Pressure, in. Hg 30.28 Static Pressure, in. H₂O -0.11
Moisture, % _____ Molecular wt., Dry _____ Pitot Tube, Cp 84
Stack Dimension, in. Diameter or Side 1 48 Side 2 →

FIELD DATA

TRAVERSE POINT NUMBER	VELOCITY HEAD (ΔP_s), 1n. H ₂ O	STACK TEMP., °F
B-1	.24	224
2	.24	226
3	.23	225
4	.25	228
5	.25	
6	.26	
7	.26	
8	.24	
9	.25	
10	.23	
11	.23	
12	.26	
		✓
A-1	.24	
2	.24	
3	.24	
4	.25	
5	.24	
6	.20	
7	.22	
8	.22	
9	.24	
10	.24	
11	.24	
12	.22	

CALCULATIONS

$$M_s = M_d \times (1 - \frac{H_2O}{100}) + 18 (\frac{H_2O}{100})$$

$$K_s = (\quad) \times (1 - \frac{\quad}{100}) + 18 (\frac{\quad}{100})$$

3

$$T_1 = \quad ^\circ F = \quad ^\circ R = (^{\circ}F + 460)$$

$$P_s = P_b + \frac{S.P.}{13.6} = (\quad) + \frac{\quad}{13.6}$$

1n.Hg

$\sqrt{\Delta P}$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta P} \times \sqrt{\frac{T_{s, \text{OR}}}{P_s \times H_s}}$$

$$v_s = 85.49 \times (\quad) \times (\quad) \times \sqrt{\frac{\quad}{x}}$$

$$V_s = \quad \text{ft/s}$$

A. 8. 11. 7

$$Q_s = v_s \times A_s \times \frac{60 \text{ s}}{\text{min}}$$

Q. **A** **x 60**

Q_s = **scfm**

$$Q_{s, std} = Q_s \times 17.647 \times \frac{P_s}{T_s} \times \left(1 - \frac{H_2O^s}{100}\right)$$

$$Q_{std} = 17.647 \times \left(1 - \frac{100}{100} \right)$$

Q. 1. **discm**



DRY MOLECULAR WEIGHT DETERMINATION

PLANT _____
DATE _____ TEST NO _____
SAMPLING TIME (24-hr CLOCK) _____
SAMPLING LOCATION _____
SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) _____
ANALYTICAL METHOD _____
AMBIENT TEMPERATURE _____
OPERATOR _____
ORSAT LEAK CHECKED _____

COMMENTS:

RUN GAS	1		2		3		AVERAGE NET VOLUME	MULTIPLIER	MOLECULAR WEIGHT OF STACK GAS (DRY BASIS) M _D , lb/lb-mole
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET			
CO ₂							2	44/100	.88
O ₂ (NET IS ACTUAL O ₂ READING MINUS ACTUAL CO ₂ READING)							20	32/100	6.4
CO (NET IS ACTUAL CO READING MINUS ACTUAL O ₂ READING)								28/100	
N ₂ (NET IS 100 MINUS ACTUAL CO READING)							78	28/100	21.84
TOTAL								29.12	



INTERNATIONAL
TECHNOLOGY
CORPORATION

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD *

Reference Document No. 4261/5
Page 1 of 1

White: To accompany samples Yellow: Field copy *See back of form for special instructions.

Project Name/No. 1 Miles/313674-06 Samples Shipment Date 7 1/19/94
Sample Team Members 2 J. Neese, S. Eurling Lab Destination 8 ITAS-Cinti
Profit Center No. 3 3572 Lab Contact 9 K. Mueller
Project Manager 4 Scott Eurling Project Contact/Phone 12 BGals 44249 Report to: 10 BGals
Purchase Order No. 6 U/K Carrier/Waybill No. 13 IT-CINTI

Bill to: 5 ITAS

Required Report Date 11 2/4/94

ONE CONTAINER PER LINE

Sample 14 Number	Sample 15 Description/Type	Date/Time Collected	16 Container Type	17 Sample Volume	18 Pre-19 preservative	20 Requested Testing Program	Condition on Receipt 21	Disposal 22 Record No.
M-N0x-3A	Air/N0x Flask	1/15/94	Flask	22L	None	EPA Method 7A		
M-N0x-3B								
M-N0x-3C								
M-N0x-3D								
M-N0x-4A								
M-N0x-4B								
M-N0x-4C								
M-N0x-4D								

FOR LAB
USE ONLY

FOR LAB
USE ONLY

Blank w/other
NOx shipment

Special Instructions: 23

Possible Hazard Identification: 24

Non-hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Sample Disposal: 25

Return to Client ☐

Disposal by Lab ☒ Archive

(mos.)

Turnaround Time Required: 26

Normal ☒ Rush ☐

QC Level: 27

I ☒ II ☐ III ☐

Project Specific (specify):

1. Relinquished by 28 Jerry Neese

(Signature/Affiliation)

Date: 1/19/94
Time: 1515

1. Received by 28

(Signature/Affiliation)

Date: 1/19/94
Time: 1515

2. Relinquished by 31 Brian Z. Eurling

(Signature/Affiliation)

Date: 1/19/94
Time: 1527

2. Received by 31

(Signature/Affiliation)

Date: 1/19/94
Time: 1527

3. Relinquished by

(Signature/Affiliation)

Date: 1/19/94
Time: 1527

3. Received by

(Signature/Affiliation)

Date: 1/19/94
Time: 1527

Comments: 29



Emission Testing Field Data

Plant and City		Date	Sampling Location	Sample Type	Run Number
MILES BALTIMORE MD		11/11/94	DRY GAS Exhaust out	PART/NUM	MILES FMM-1

Operator(s)	Bar. Press. (in. Hg)	Static Press. (in. H ₂ O)	Amb. Temp. (°F)	Filter Number(s)	Probe Length and Type	Nozzle	
						Dia. (in.)	Number
DC & JN	30.75	22.5	26	9370107	6 FT GLASS	3.70	G-101

Moisture (%)	Meter Box No.	Meter Δ H @	Meter Cal. Factor (Y)	K Factor	Probe Heat (°F)	Box Heat (°F)	Therm. No.	Pilot No.	Imp. Therm. No.	Gas Bag Pump No.	Gas Bag Sys. Leak Check	Train Leak Check		Pilot Leak Check
												in. Hg	CFM	
~5	FT-5	1.34	946	9.76	250	250	690	559	49	102	✓	15	0.005	4 0.001

Traverse Point No.	Sampling Time (min.)	Clock Time (24-hr)	Gas Meter Reading (V _m), ft ³	Velocity Head* (ΔP), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O*		Stack (T _s)	Dry Gas Meter		Temperature (°F)				Pump Vac. (in. Hg)	Gas Bag Sample Data
					Desired	Actual		Inlet (T _m)	Outlet (T _m)	Probe	Sample Box	Resin Inger			
A 1	0	11:10	935.702	.24	1.65	1.65	248	40	40	253	247	N/A	2	200cc	
2	6.5		941.1	.25	1.73	1.73	248	44	40	249	248		2	"	
3	13	11:23	946.7	.26	1.81	1.81	249	49	40	248	250		2	"	
4	19.5		952.4	.26	1.85	1.85	250	54	44	249	253		2	"	
5	26	11:36	958.3	.26	1.83	1.83	250	58	44	250	251		2	"	
6	32.5		964.2	.26	1.86	1.86	250	66	54	253	253		2	"	
7	39	11:49	970.2	.26	2.08	2.08	252	70	56	251	252		2	"	
8	45.5		976.5	.27	2.01	2.01	253	72	56	254	251		2	"	
9	52	12:02	982.7	.27	1.93	1.93	254	74	60	254	253		2	"	
10	58.5		988.8	.26	1.87	1.87	255	74	60	252	255		2	"	
11	65	12:15	994.9	.25	1.80	1.80	256	74	60	254	260		2	"	
12	71.5		1000.5	.25	1.51	1.51	257	74	60	248	254		2	"	
A 1	78	12:28	1005.982	.28	1.98	1.98	259	66	60	251	251		2	START	
2	84.5		1012.2	.31	2.20	2.20	260	70	56	253	255		2	200cc	
3	91	12:49	1018.4	.33	2.48	2.48	261	70	56	250	255		2	"	
4	97.5		1025.7	.39	2.73	2.73	265	70	56	248	255		2	"	
5	104	13:02	1033.1	.40	2.84	2.84	264	74	58	250	253		2	"	
6	110.5		1040.5	.40	2.85	2.85	262	74	60	255	253		2	"	
7	117	13:15	1048.0	.43	3.11	3.11	253	76	62	252	250		2	"	
8	123.5		1056.0	.44	3.23	3.23	242	76	64	255	251		2	"	
9	130	13:28	1063.9	.41	3.05	3.05	235	76	64	253	254		2	"	
10	136.5		1071.0	.41	3.08	3.08	229	77	65	258	255		2	"	
11	143	13:41	1079.2	.41	2.84	2.84	230	77	65	253	251		2	"	
12	149.5		1087.2	.41	2.84	2.84	234	78	66	251	254		2	END	

*Record pressure differentials to 2 significant figures, e.g., 0.015, 0.88, 1.2, etc. Comments:



MODIFIED METHOD 5 SEMIVOLATILE
SAMPLE RECOVERY AND INTEGRITY SHEET

Plant Miles Lab
Sample location Stack
Run number M-H2O-1
Filter type _____
XAD-2 trap No. _____

Sample date 1-15-94
Recovery date 1-15-94
Recovered by CFM

Impingers Contents	Condensate Empty	MOISTURE			
		1st H ₂ O	2nd	3rd Empty	4th Silica gel
Final weight/volume	g	617.5 g	588.0 g	498.4 g	714.0 g
Initial weight/volume	g	594.3 g	605.0 g	497.6 g	712.0 g
Net Gain	g	23.2 g	-17.0 g	0.8 g	2.0 g
Description of impinger contents _____					

Total moisture 9 g

RECOVERED SAMPLE

✓BL-6
1/18/94

Filter container number(s) _____ Sealed _____
Description of particulate on filter _____

XAD-2 container number(s) _____ Sealed _____ Foil-wrapped _____

	Sample solution/rinse container numbers	Sealed/liquid level marked
Acetone/MeCl ₂ probe rinse	_____	_____
Toluene rinse	_____	_____
_____	_____	_____
_____	_____	_____

Samples stored and locked _____
Remarks _____

LABORATORY CUSTODY

Received by _____ Date _____
Remarks _____

GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant and City Miles Lab - Baltimore Date 1-15-94
 Sampling Location Stack Clock Time 0835
 Run No. M-V-2 Operator JN
 Barometric Pressure, in. Hg 30.26 Static Pressure, in. H₂O -0.12
 Moisture, % _____ Molecular wt., Dry _____ Pitot Tube, Cp .84
 Stack Dimension, in. Diameter or Side 1 48" Side 2 →

FIELD DATA

TRAVERSE POINT NUMBER	VELOCITY HEAD (ΔP_s), in. H ₂ O	STACK TEMP., °F
B-1	.23	224
2	.24	225
3	.25	
4	.25	
5	.25	
6	.24	
7	.22	
8	.23	
9	.23	
10	.24	227
11	.27	227
12	.26	227
A-1	.26	225
2	.26	226
3	.23	
4	.23	
5	.24	
6	.25	
7	.25	
8	.26	224
9	.25	224
10	.27	224
11	.27	226
12	.26	226

CALCULATIONS

$$M_s = M_d \times \left(1 - \frac{H_2O}{100}\right) + 18 \left(\frac{H_2O}{100}\right)$$

$$M_s = () \times \left(1 - \frac{H_2O}{100}\right) + 18 \left(\frac{H_2O}{100}\right)$$

$$M_s =$$

$$T_s = \quad \quad \quad ^\circ F = \quad \quad \quad ^\circ R = (^\circ F + 460)$$

$$P_s = P_b + \frac{S.P.}{13.6} = () + \frac{ }{13.6}$$

$$P_s = \quad \quad \quad \text{in. Hg}$$

$$\sqrt{\Delta P} =$$

$$V_s = 85.49 \times C_p \times \sqrt{\Delta P} \times \sqrt{\frac{T_s \times R}{P_s \times M_s}}$$

$$V_s = 85.49 \times () \times () \times \sqrt{ \quad \quad \quad }$$

$$V_s = \quad \quad \quad \text{ft/s}$$

$$A_s = \quad \quad \quad \text{ft}^2$$

$$Q_s = V_s \times A_s \times \frac{60 \text{ s}}{\text{min}}$$

$$Q_s = \quad \quad \quad \times \quad \quad \quad \times 60$$

$$Q_s = \quad \quad \quad \text{acfm}$$

$$Q_{s, \text{std}} = Q_s \times 17.647 \times \frac{P_s}{T_s} \times \left(1 - \frac{H_2O}{100}\right)$$

$$Q_{s, \text{std}} = \quad \quad \quad \times 17.647 \times \quad \quad \quad \times \left(1 - \frac{H_2O}{100}\right)$$

$$Q_{s, \text{std}} = \quad \quad \quad \text{dscfm}$$

APPENDIX D
LABORATORY DATA

Method 5 Train Blank Data
Acetone Rinses and FilterPlant: MILESDensity of Acetone: 0.7899 g/ml (pa)

Sample Type	Sample Identifiable	Liquid level at mark and/or container sealed
Acetone	YES	YES
Filter	YES	YES

Acetone Blank Container No: 01425ALab #: 3223-AC6020Acetone Volume: 112 ml. (Va)Date & Time of Wt. 1-19-94 10:30AMBeaker Gross Wt.: 98796.1 mgDate & Time of Wt. 1-19-94 4:55PMBeaker Gross Wt.: 98796.5 mgAverage Gross Wt.: 98796.3 mgBeaker Tare Wt.: 98796.4 mg $Ca, (mg/g) = ma / (Va \times pa)$ Beaker Net Wt.: -0.1 mg (ma)Acetone Blank Value: 0 mg/g (Ca)Blank Value Used for Calculations: 0.0000 mg/gFilter #: 9370028Lab #: 3223-AC6021Date & Time of Wt. 1-19-94 4:25PMFilter Gross Wt.: 311.5 mgDate & Time of Wt. 1-20-94 8:00AMFilter Gross Wt.: 311.9 mgAverage Gross Wt.: 311.7 mgFilter Tare Wt.: 310.2 mgDifference: 1.5 mgSignature of Analyst: M. W. WeneDate: 1-21-94Signature of Reviewer: John MuellerDate: 1/24/94

Method 5 Train Analytical Particulate Data
Acetone Rinses and Filter(s)Plant: MILESRun No.: MILES-PMM-1Sample Location: DRY GAS EXHAUSTERDensity of Acetone: 0.7899 g/ml

Sample Type	Sample Identifiable	Liquid level at mark and/or container sealed
Acetone	YES	YES
Filter	YES	YES

Acetone Blank Residue Conc. 0.0000 mg/gLab #: 3223-AC6014Acetone Volume: 160 ml.Date & Time of Wt. 1-19-94 4:55PMDate & Time of Wt. 1-20-94 8:15AMBeaker Gross Wt.: 107581.9 mgBeaker Gross Wt.: 107582.0 mgAverage Gross Wt.: 107582.0 mgBeaker Tare Wt.: 107577.8 mgLess acetone blank wt.: 0.0 mgAcetone Rinse Particulate Wt.: 4.2 mgFilter # 9370107Lab #: 3223-AC6015Date & Time of Wt. 1-19-94 10:00AMDate & Time of Wt. 1-20-94 8:00AMFilter Gross Wt.: 309.6 mgFilter Gross Wt.: 309.4 mgAverage Gross Wt.: 309.5 mgFilter Tare Wt.: 308.0 mgWeight of Particulate on
Filter: 1.5 mgWeight of Particulate in
Acetone Rinse: 4.2 mgTotal Weight of Particulate : 5.7 mgSignature of Analyst: McWaneDate: 1-21-94Signature of Reviewer: Ken MuellerDate: 1/24/94

Method 5 Train Analytical Particulate Data
Acetone Rinses and Filter(s)Plant: MILESRun No.: MILES-PMM-2Sample Location: DRY GAS EXHAUSTERDensity of Acetone: 0.7899 g/ml

Sample Type	Sample Identifiable	Liquid level at mark and/or container sealed
Acetone	YES	YES
Filter	YES	YES

Acetone Blank Residue Conc. 0.0000 mg/gLab #: 3223-AC6017Acetone Volume: 168 ml.Date & Time of Wt. 1-19-94 4:55PMDate & Time of Wt. 1-20-94 8:15AMBeaker Gross Wt.: 112749.4 mgBeaker Gross Wt.: 112749.7 mgAverage Gross Wt.: 112749.6 mgBeaker Tare Wt.: 112746.7 mgLess acetone blank wt.: 0.0 mgAcetone Rinse Particulate Wt.: 2.9 mgFilter # 9370108Lab #: 3223-AC6018Date & Time of Wt. 1-19-94 10:00AMDate & Time of Wt. 1-20-94 8:00AMFilter Gross Wt.: 310.8 mgFilter Gross Wt.: 310.5 mgAverage Gross Wt.: 310.7 mgFilter Tare Wt.: 308.0 mgWeight of Particulate on
Filter: 2.7 mgWeight of Particulate In
Acetone Rinse: 2.9 mgTotal Weight of Particulate : 5.6 mgSignature of Analyst: M. W. WeneDate: 1-21-94Signature of Reviewer: Ken MuellerDate: 1/27/94

Acidores				10:30 AM Miles 1/19/94	4:55 PM Miles 1/19/94	Miles 1/20/94 8:15 AM	
Run#	Cont#	Yell#	(mils) Volume	(g) Solute	(g) Gross wt	(g) Gross wt	(g) Gross wt
Miles - Pmm-1	01945A	AC6014	160	107.5778	107.5808	107.5819	107.5820
Miles - Pmm-2	01947A	AC6017	168	112.7467		112.7494	112.7497
Blank	01425A	AC6020	112	98.7964	98.7961	98.7915	

Filters				Miles 1/19/94 10:00 AM	Miles 1/19/94 4:25 PM	Miles 1/20/94 8:00 AM	
Run#	Cont#	Yell#	filter#	(g) Solute	(g) Gross wt	(g) Gross wt	(g) Gross wt
Miles - Pmm-1	01945B	AC6015	9370107	3080	3096	3107	3109
Miles - Pmm-2	01947B	AC6018	9370108	3080	3108	3095	3105
Blank	01423B	AC6021	9370028	3102	3142	3115	3119

Continued on Page

Continued on Page

Read and Understood By

Miles

Signed

1-21-94

Date

Kern

Signed

1/24/94

Date

CERTIFICATE OF ANALYSIS

IT Corporation

Date: February 03, 1994

Attn: Mr. Brian Garls

Project Number 516

This is the Certificate of Analysis for the following samples:

Client Project ID: Miles Laboratories
Date Received: January 13, 1994
Work Order: 3223
Number of Samples: 15
Sample Type: Air

I. Introduction

Fifteen samples arrived at ITAS Cincinnati on January 23, 1994. The samples were collected on January 11, 1994 and were labeled as follows:

Client Sample ID	Lab Sample ID	Client Sample ID	Lab Sample ID
MILES-PMM-1 COMPOSITE	AC6024	6KB H-NO _x -1A	AC6031
MILES-PMM-2 COMPOSITE	AC6025	ZZ M-NO _x -1B	AC6032
MILES-BLANK COMPOSITE	AC6026	TG M-NO _x -1C	AC6033
10950A MILES-F-1	AC6027	ZA M-NO _x -1D	AC6034
10950A MILES-F-2	AC6028	XC M-NO _y -2A	AC6035
10952A BLANK FLUORIDE	AC6029	MN M-NO _x -2B	AC6036
10952A FILTER FLUORIDE	AC6030	9KB M-NO _x -2C	AC6037
		5HD M-NO _x -2D	AC6038

II. Analytical Results/Methodology

The analytical results for this report are presented by analytical test. The data will include sample identification information, the analytical results, and the appropriate detection limits.

The analyses requested and the methods used are listed on the following page.

Reviewed and Approved by:



Kenneth Mueller, C.H.M.M.
Project Manager

American Council of Independent Laboratories
International Association of Environmental Testing Laboratories
American Association for Laboratory Accreditation

Client: Miles Laboratories
Work Order: 3223
01322306

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

II. Analytical Results/Methodology (cont.)

- * NOX; EPA Method 7A
- Fluoride; EPA Method 13B
- * Barium, Cobalt, Copper, Chromium, Manganese, Nickel and Zinc by Inductively Coupled Plasma Spectroscopy; EPA Method 6010
- Lead by Graphite Furnace Atomic Absorption; EPA Method 7421

III. Quality Control

Immediately following the analytical data for the samples can be found the QA/QC information that pertains to these samples. The purpose of this information is to demonstrate that the data enclosed is scientifically valid and defensible. This QA/QC data is used to assess the laboratory's performance during the analysis of the samples it accompanies. All quantitations were performed within the calibrated range of the analytical instrument.

IV. Comments

Due to an interferent in the sample matrix, the lead analysis was done by the method of standard additions.

Client: Miles Laboratories
Work Order: 3223
01322304

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

Analytical Results, ug

Client Sample ID	Lab Sample ID	NOX
6KB M-NO _x -1A	AC6031	Run 1 1680
		Run 2 1710
		Average 1700
22 M-NO _x -1B	AC6032	Run 1 1720
		Run 2 1680
		Average 1700
TG M-NO _x -1C	AC6033	Run 1 1740
		Run 2 1750
		Average 1740
ZA M-NO _x -1D	AC6034	Run 1 1780
		Run 2 1810
		Average 1800
XC M-NO _x -2A	AC6035	Run 1 1770
		Run 2 1730
		Average 1750
MN M-NO _x -2B	AC6036	Run 1 1730
		Run 2 1830
		Average 1780
9KB M-NO _x -2C	AC6037	Run 1 1690
		Run 2 1660
		Average 1680
5HD M-NO _x -2D	AC6038	Run 1 1800
bc6		Run 2 1780
2/4/94		Average 1790
00468A NOX BLANK	AC6039	Run 1 ND
		Run 2 ND
		Average ND
Audit 3080		Run 1 131
T.V. 125		Run 2 119
		Average 125 100% Recovery
Detection Limit		62
ND = Not detected above the reported detection limit		

Client: Miles Laboratories
Work Order: 3223
01322303

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

Analytical Results, mg

Client Sample ID	Lab Sample ID	Fluoride
10950A MILES-F-1	AC6027	64
10950A MILES-F-2	AC6028	55
01952A BLANK FLUORIDE	AC6029	0.19
01952B FILTER BLANK	AC6030	0.12
Detection Limit		0.1

Client: Miles Laboratories
Work Order: 3223
01322302

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

Analytical Results, ug

Client Sample ID	MILES-PMM-1 COMPOSITE	MILES-PMM-1 COMPOSITE	MILES-PMM-2 COMPOSITE		Detection Limit
Lab Sample ID	AC6024	AC6024 Duplicate	AC6025		
Analyte					
Barium	9.2	8.8	9.0	6.5	0.25
Cobalt	1.6	ND	1.6	ND	1.5
Copper	7.4	7.2	7.3	3.1	1.0
Chromium	4.4	4.2	4.3	3.4	1.0
Lead	2.8	---	2.8	2.5	1.5
Manganese	4.9	4.6	4.8	3.1	0.3
Nickel	6	7.3	6.7	ND	5.0
Zinc	56	57	57	ND	25

calc by
OLG
2/4/94

Client Sample ID	MILES-BLANK COMPOSITE	Method Blank	Method Blank		Detection Limit
Lab Sample ID	AC6026	PBM1 1/25/94	PBM2 1/25/94		
Analyte					
Barium	3.6	0.25	1.6		0.25
Cobalt	ND	ND	ND		1.5
Copper	ND	ND	ND		1.0
Chromium	2.2	ND	ND		1.0
Lead	ND	ND	ND		1.5
Manganese	1.4	ND	0.35		0.3
Nickel	ND	ND	ND		5.0
Zinc	29	ND	44		25

ND = Not detected above the reported detection limit

MS
2-4-94

Client: Miles Laboratories
Work Order: 3223
01322305

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

Quality Assurance Data

Quality Control
Standard Reference Solutions

Analyte -----	Theoretical Value -----	Percent Recovery -----
NOX	125	105, 95
Fluoride	1.6	95, 94
Barium	1.25	107, 108
Cobalt	1.25	107, 107
Copper	1.25	105, 107
Chromium	1.25	106, 105
Lead	0.05	98, 108
Manganese	1.25	105, 106
Nickel	1.25	105, 106
Zinc	1.25	106, 107

CERTIFICATE OF ANALYSIS

IT Corporation

Date: January 27, 1994

Attn: Mr. Brian Garls

Project Number 516

This is the Certificate of Analysis for the following samples:

Client Project ID: Miles Laboratories
Date Received: January 19, 1994
Work Order: 3255
Number of Samples: 8
Sample Type: Air

I. Introduction

Eight samples arrived at ITAS Cincinnati on January 19, 1994. The samples were collected on January 15, 1994 and were labeled as follows:

Client Sample ID	Lab Sample ID
M-NOX-3A	AC6216
M-NOX-3B	AC6217
M-NOX-3C	AC6218
M-NOX-3D	AC6219
M-NOX-4A	AC6220
M-NOX-4B	AC6221
M-NOX-4C	AC6222
M-NOX-4D	AC6223

II. Analytical Results/Methodology

The analytical results for this report are presented by analytical test. The data will include sample identification information, the analytical results, and the appropriate detection limits.

The analysis requested was NOX by EPA Method 7A.

Reviewed and Approved by:


Kenneth Mueller, C.H.M.M.
Project Manager

American Council of Independent Laboratories
International Association of Environmental Testing Laboratories
American Association for Laboratory Accreditation

Client: Miles Laboratories
Work Order: 3255
01325501

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

III. Quality Control

Immediately following the analytical data for the samples can be found the QA/QC information that pertains to these samples. The purpose of this information is to demonstrate that the data enclosed is scientifically valid and defensible. This QA/QC data is used to assess the laboratory's performance during the analysis of the samples it accompanies. All quantitations were performed within the calibrated range of the analytical instrument.

IV. Comments

Method 7A states that samples should not be held more than four days between sampling and recovery. The samples were collected on 1/15/94 and received in the laboratory 1/19/94 and recovered on 1/20/94.

Client: Miles Laboratories
Work Order: 3255
01325502

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

Analytical Results, Total ug

Client Sample ID	Lab Sample ID	NOX
M-NOX-3A	AC6216	Run 1 1890
		Run 2 1900
		Average 1900
M-NOX-3B	AC6217	Run 1 2110
		Run 2 2100
		Average 2110
M-NOX-3C	AC6218	Run 1 2060
		Run 2 2050
		Average 2050
M-NOX-3D	AC6219	Run 1 1870
		Run 2 1860
		Average 1870
M-NOX-4A	AC6220	Run 1 2020
		Run 2 2040
		Average 2030
M-NOX-4B	AC6221	Run 1 2190
		Run 2 2180
		Average 2190
M-NOX-4C	AC6222	Run 1 2200
		Run 2 2140
		Average 2170
M-NOX-4D	AC6223	Run 1 2240
		Run 2 2210
		Average 2220
Detection Limit		120

Client: Miles Laboratories
Work Order: 3255
01325503

IT ANALYTICAL SERVICES
CINCINNATI, OH
(513) 782-4700

Quality Assurance Data

Quality Control
Standard Reference Solutions

Analyte -----	Theoretical Value -----	Analytical Value -----	Percent Recovery -----
Audit # 3080			
NOX	125 mg/DSCM	129.0 mg/DSCM	103
		129.8 mg/DSCM	104
	Average	129.4 mg/DSCM	104



COC NO.

0003296*

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD *

Reference Document No. 426179
Page 1 of 1

Project Name/No. 1 Miles / 313674-06

Samples Shipment Date ⁷ 1/19/54

Sample Team Members 2 JNancy, S. Furlong

Lab Destination ⁸ JTAG - JTAG

Profit Center No. 3 3572

Lab Contact ⁹ K. Müller

Project Manager: Scott Farley

Project Contact/Phone 12 B Canal, X7849

Purchase Order No. 6 U/K

Carrier/Waybill No. 13

Required Report Date ¹¹ 2/4/94

2/4/94

ONE CONTAINER PER LINE

Sample Number	Sample Description/Type	Date/Time Collected	Container Type	Sample Volume	Pre- servative	Requested Testing Program	Condition on Receipt	Disposal 22 Record No.
M-N01-3A	Air/NO _x FlueK	1/15/94	FlueK	2 L	None	EPA Method 7A	Sample Nucleon FOR LAB USE ONLY	
M-N01-3B								
M-N01-3C						Blank w/other NO _x shipment	1/19/94 FOR LAB USE ONLY	
M-N01-3D								
M-N01-4A							FOR LAB USE ONLY	
M-N01-4B								
M-N01-4C								
M-N01-4D								

Special Instructions. 23

Possible Hazard Identification: 24

Non-hazard	Flammable	Sk
------------	-----------	----

Turnaround Time Required: 26

~~Normal~~ ~~X~~ Rush

1 Delivered by 28

Denny Hoese

Date: 1/19/94
Time: 1:51

1

1. Received by 28
(Signature/Affiliation)

B. Zimmermann

Date: _____
Time: _____

5151
55/6111

0-0-0-0-0-0

10

Date: 1/14/54

19

3 Received by

10/1/10

Date:

119190

3. Relinquished by

Date: _____

1

3. Received b

Date: _____

Comments: 29



INTERNATIONAL
TECHNOLOGY
CORPORATION

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Reference Document No. 4261A
Page 1 of 1

Project Name/No. 1 Miles/313674-06

Samples Shipment Date 7/19/94

Bill to: ITAS

Sample Team Members 2 J. Neece, S. Furlong

Lab Destination 8 ITAS-Cinti

Profit Center No. 3 3572

Lab Contact 9 K. Mueller

Project Manager 4 Scott Furlong

Project Contact/Phone 12 B. Gools

Report to: 10 B. Gools

Purchase Order No. 6 U/K

Carrier/Waybill No. 13

IT-CINTI

Required Report Date 11/2/94

ONE CONTAINER PER LINE

Sample Number	Sample 15 Description/Type	Date/Time Collected	Container Type	Sample Volume	Pre- servative	Requested Testing Program	Condition on Receipt	Disposal 22 Record No.
M-N0x-3A	Air/N0x Flusk	1/15/94	Flusk	22L	None	EPA Method 7A	Sample Analysis FOR LAB USE ONLY	
M-N0x-3B								
M-N0x-3C								
M-N0x-3D						Blank w/other 100x shipment	1/19/94	
M-N0x-4A								
M-N0x-4B								
M-N0x-4C								
M-N0x-4D								

Special Instructions: 23

Possible Hazard Identification: 24

Non-hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Sample Disposal: 25

Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

Turnaround Time Required: 26

QC Level: 27

Project Specific (specify):

1. Relinquished by 28 (Signature/Affiliation)

Date: 1/19/94
Time: 1515

1. Received by 28 (Signature/Affiliation)

Date: 1/17/94
Time: 1515

2. Relinquished by (Signature/Affiliation)

Date: 1/19/94
Time: 1527

2. Received by (Signature/Affiliation)

Date: 1/19/94
Time: 1527

3. Relinquished by (Signature/Affiliation)

Date: 1/19/94
Time: 1527

3. Received by (Signature/Affiliation)

Date: 1/19/94
Time: 1527

Comments: 29

APPENDIX E
CALIBRATION DATA

APPENDIX E
CALIBRATION PROCEDURES AND RESULTS

CALIBRATION PROCEDURES AND RESULTS

All of the equipment used is calibrated in accordance with the procedures outlined in the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III.^{*} The following pages describe these procedures and include the data sheets.

^{*}EPA 600/4-77-027b.

Nozzle Diameter

Each nozzle used in these tests is calibrated by making three separate measurements and calculating the average. If a deviation of more than 0.004 inch is found between any two measurements, the nozzle is either discarded or reamed out and remeasured. A micrometer is used for measuring. These calibration data are shown in the following Nozzle Calibration data sheet(s).



INTERNATIONAL
TECHNOLOGY
CORPORATION

NOZZLE CALIBRATION

Client Miles

Project No. 313674-06

Date 1-11-94

Calibrated By QC

Nozzle I.D.	D1 in.	D2 in.	D3 in.	&D in.	D avg.
S-107	.323	.324	.323	.001	.323
G-101	.370	.370	.370	.000	.370

Where:

D 1, 2, 3 = nozzle diameter measured on a different diameter, in.
Tolerance = measure within 0.001 in.


&D = maximum difference in any two measurements, in.
Tolerance = 0.004 in.

D avg. = average of D1, D2, and D3




Pitot Tube Calibration

Each pitot tube used in sampling is constructed by ITAQS and meets all requirements of EPA Method 2, Section 4.1.* Therefore, a baseline coefficient of 0.84 is assigned to each pitot tube. The following pages show the alignment requirements of Method 2 and the Pitot Tube Inspection Data Sheet(s) for each pitot tube used during the test program.

*40 CFR 60, Appendix A, July 1989.



Types of face-opening misalignment that can result from field use or improper construction of Type S pitot tubes. These will not affect C_p as long as a_1 and a_2 are $< 10^\circ$, B_1 and B_2 are $< 5^\circ$, z is < 0.32 (1/8 in.), and w is < 0.08 cm (1/32 in.).



Properly constructed Type S pitot tubes shown in: (a) end view, face opening planes perpendicular to transverse axis; (b) top view, face opening planes parallel to longitudinal axis; (c) side view, both legs of equal length and centerlines coincident when viewed from both sides. Baseline coefficient values of 0.84 may be assigned to pitot tubes constructed this way.

PITOT TUBE INSPECTION DATA SHEET

Pilot Tube No. 559 Date 12/29/93 Inspector H B

α_1 degrees	α_2 degrees	β_1 degrees	β_2 degrees
0	0	0	0
<10°	<10°	<5°	<5°

D_t inches	P inches	1.05 D_t inches	1.50 D_t inches
.371	1.56	.390	.557
$0.185 \leq P_1 < 0.380$	-	-	-

γ degrees	ϕ degrees	$P_{\sin(\gamma)}$ inches	$P_{\sin(\phi)}$ inches
1	1	.027	.027
-	-	<0.125	<0.03125

P_1 inches	P_2 inches	$ P_1 - P_2 $ inches	Meet specifications
.428	.421	.007	✓
$1.05 D_t < P_1 < 1.50 D_t$	$1.05 D_t < P_2 < 1.50 D_t$	≤ 0.010	

Lower line in each table is limits for meeting specifications.

Checked by Jm Date 1/19/94

PITOT TUBE INSPECTION DATA SHEET

Pitot Tube No. H1 Date 12-28-93 Inspector C. Miller

α_1 degrees	α_2 degrees	β_1 degrees	β_2 degrees
0	0	0	0
<10°	<10°	<5°	<5°

D_1 inches	P inches	1.05 D_1 inches	1.50 D_1 inches
.372	1.05	.391	.558
$0.185 \leq P_1 < 0.380$	-	-	-

γ degrees	φ degrees	$P_{\sin(\gamma)}$ inches	$P_{\sin(\varphi)}$ inches
1	0	.018	0
-	-	<0.125	<0.03125

P_1 inches	P_2 inches	$ P_1 - P_2 $ inches	Meet specifications
.509	.502	.007	✓
$1.05 D_1 < P_1 < 1.50 D_1$	$1.05 D_1 < P_2 < 1.50 D_1$	≤ 0.010	

Lower line in each table is limits for meeting specifications.

Checked by HB Date 1/3/94

Dry Gas Meter and Orifice Meter

The following page shows the Calibration Setup used for the initial and post-test calibration. A wet-test meter with a 2-cubic-feet-per-minute capacity and ± 1 percent accuracy is used. The pump is run for approximately 15 minutes at an orifice manometer setting of 0.5 in.H₂O to heat up the pump and wet the interior surface of the wet-test meter. The information in the following example Calibration Data Sheet is gathered for the initial calibration; the ratio of accuracy of the wet-test meter to the dry-test meter and the $\Delta H@$ are then calculated.


Post-Test Meter Calibration Check

A post-test meter calibration check is made on each meter box used during the test to check its accuracy against the last calibration check. This post-test calibration must be within ± 5 percent of the initial calibration. The initial calibration is performed as described in APTD-0576. The post-test calibration is performed by the same method. Three calibration runs are made by using the average orifice setting obtained during each test run and setting the vacuum at the maximum value obtained during each test run. The post-test calibration check indicated that all three runs for each meter box were within the ± 5 percent range allowed by EPA Method 5.*

The Particulate Sampling Meter Box Initial Calibration and Post-Test Calibration data sheets are included in the following pages.

* 40 CFR 60, Appendix A, July 1990.

Title: E-2
Date: 3/23/92



Calibration setup.

DATE _____

METER BOX NO. _____

BAROMETRIC PRESSURE, P_b = _____ in. Hg.

DRY GAS METER NO. _____

ORIFICE MANOMETER SETTING ΔH in. H ₂ O	GAS VOLUME WET TEST METER V_w , ft ³	GAS VOLUME DRY GAS METER V_d , ft ³	WET TEST METER T_w , °F	DRY GAS METER			TIME ϕ , min.	Y	$\Delta H@$
				INLET t_{di} , °F	OUTLET t_{dn} , °F	AVERAGE t_d , °F			
0.5	5								
1.0	5								
1.5	10								
2.0	10								
3.0	10								
4.0	10								

AVERAGE _____

ΔH	$\frac{\Delta H}{13.6}$	Y	$\Delta H@$
		$\frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \phi}{V_w} \right]^2$
0.5	0.0368		
1.0	0.0737		
1.5	0.110		
2.0	0.147		
3.0	0.221		
4.0	0.294		

Y = Ratio of accuracy of wet test meter to dry test meter. Tolerance = ± 0.01
 $\Delta H@$ = Orifice of pressure differential that gives 0.75 cfm of air at 70° F and 29.92 inches of mercury, in H_g. Tolerance = ± 0.15 .

Calibration data sheet.



METER BOX INITIAL CALIBRATION

validated 11/8/90

Date: 12/29/83
Barometric Pressure, (Pbar): 29.44
Meter Box No.: FT-4
Calibrator: Neese

Run No.	Orifice manometer setting* ΔH	In. H ₂ O	Temperatures																	
			Wet test meter volume		Dry gas meter volume		Wet test meter		Dry gas meter		Average Td °F	Vacuum setting** in. Hg	Duration of run, $\emptyset$ min. sec							
			Vw ft ³		Vd ft ³		Tw °F		Tdi °F					Tdo °F						
1		0.50		5.000		811.710		67		76		72		74.0		10		13		5
						816.760		67		76		72								
2		1.00		10.000		801.417		67		75		72		73.8		10		18		35
						811.500		67		76		72								
3		1.50		10.000		817.147		67		76		72		74.0		10		15		17
						827.208		67		76		72								
4		2.00		14.500		827.829		67		76		72		74.8		10		19		31
						842.417		67		77		74								
5		3.00		10.000		842.822		67		77		74		75.8		10		11		1
						852.848		67		78		74								
6		4.00		10.000		853.332		67		78		74		76.0		10		9		28
						863.349		67		78		74								

$$Y = \frac{(V_w)(P_{bar})(T_d + 460)}{(V_d)(P_{bar} + \Delta H)(13.6)(T_w + 460)}$$

$$\Delta H @ = \frac{(0.0317)(\Delta H)}{(P_{bar})(T_d + 460)} \times \frac{(T_w + 460)}{V_w} (\emptyset) \frac{1}{2}$$

Pretest average 1.004 1.98

Difference* = 0.003 0.12

* Y must not deviate by more than $\pm 0.02 Y$.
 $\Delta H @$ must not deviate by more than $\pm 0.15 \Delta H @$

Data checked by: HB
Date: 1/11/94



METER BOX POST-TEST CALIBRATION

validated 10/24/00

Date: 1/26/94
Barometric Pressure, (Pbar): 29.76
Miles
Garls
Project Manager:
Meter Box No.: FT-4
Initial Y: 1.004
Project No.: 313674
Calibrator: Neese
 $\Delta H@$: 1.98

Run No.	Orifice manometer setting* ΔH in. H ₂ O	Wet test		Dry gas meter		Temperatures		Vacuum setting** in. Hg	Duration of run, $\emptyset$ min. sec
		meter volume Vw ft ³	meter volume Vd ft ³	Wet test meter Tw °F	Dry gas meter Tdl °F	Inlet Tdl °F	Average Td °F		
1	1.70	10.000	995.487 1005.553	68 68	84 85	74 75	78.5	4	14 32
2	1.70	10.000	5.553 15.672	68 68	85 86	75 76	80.5	4	14 34
3	1.70	10.500	15.672 26.329	68 68	86 88	76 77	81.8	4	15 16

Run No.	Y	$\Delta H@$
1	1.011	1.98
2	1.007	1.98
3	1.007	1.97

Post-test average*** 1.008 1.98

Difference from Pretest ****= 0.004 0.00

- * To be the average ΔH used during the test series.
- ** To be the highest vacuum used during the test series.
- *** Post-test Y must be within ± 0.05 Initial Y.
 $\Delta Y = (\text{Posttest } Y - \text{Initial } Y) / \text{Initial } Y$
- Post-test $\Delta H@$ must be within ± 0.15 in.H₂O of the Initial $\Delta H@$.
- $\Delta H@$ difference = Posttest $\Delta H@$ - Initial $\Delta H@$

$$Y = \frac{(V_w)(P_{\text{bar}})(T_d + 460)}{(V_d)(P_{\text{bar}} + \Delta H/13.6)(T_w + 460)}$$

$$\Delta H@ = \frac{(0.0317)(\Delta H) \times (P_{\text{bar}})(T_d + 460)}{V_w} \quad \frac{(T_w + 460)}{V_w} \quad \frac{(\emptyset)}{V_w} \quad \frac{2}{V_w}$$

Data checked by: 217
Date: 1-26-94



METER BOX INITIAL CALIBRATION

Validated 11/8/90

Date: 9/28/93
Barometric Pressure, (Pbar): 29.44
Meter Box No.: FT-5
Calibrator: Neese

Run No.	Orifice manometer setting* ΔH	In. H2O	Wet test		Dry gas meter volume Vd ft3	Wet test meter		Temperatures				Vacuum setting** In. Hg	Duration of run, Ø	
			Vw ft3	meter volume		Tw °F	Inlet Tdl °F	Dry gas meter		Average Td °F	min.		sec	
								Outlet Tdo °F						
1	0.50				564.105	64	80	64						
			5.000		64	76	64		71.0	10	11	0		
2	1.00				569.942	64	76	64						
			10.000		64	80	64		71.0	10	15	32		
3	1.50				552.548	64	84	66						
			10.000		64	82	65		74.3	10	12	41		
4	2.00				581.358	63	80	64						
			11.000		63	86	66		74.0	10	12	6		
5	3.00				593.631	63	86	66						
			10.000		63	89	67		77.0	10	9	2		
6	4.00				541.152	64	82	64						
			10.000		64	84	66		74.0	10	7	49		

$$Y = \frac{(Vw)(Pbar)(Td+460)}{(Vd)(Pbar+\Delta H/13.6)(Tw+460)}$$

$$\Delta H @ = \frac{(0.0317)(\Delta H) \times}{(Pbar)(Td+460)} \left[\frac{(Tw+460)(\emptyset)}{Vw} \right]^2$$

Run No.	Y	ΔH@
1	0.939	1.35
2	0.939	1.34
3	0.946	1.34
4	0.948	1.33
5	0.956	1.34
6	0.949	1.35

Pretest average	0.946	1.34
-----------------	-------	------

Difference* = 0.010 0.02

* Y must not deviate by more than ±0.02Y.
ΔH@ must not deviate by more than 10.15 ΔH@1

Data checked by: YJDate: 9/30/93



METER BOX POST-TEST CALIBRATION

valid 10/24/90

Date: 1/26/94
Barometric Pressure, (Pbar): 29.76
Miles: Garis
Project Manager:
Meter Box No.: FT-5
Initial Y: 0.946
Project No.: 313674
Callibrator: Neese
 $\Delta H@$: 1.34

Run No.	Orifice manometer setting* ΔH in. H2O	Wet test		Dry gas		Temperatures				Vacuum		Duration	
		meter volume Vw ft3	meter volume Vd ft3	meter volume Vd ft3	meter volume Vd ft3	Wet test meter Tw °F	Inlet Tdi °F	Outlet Tdo °F	Average Td °F	setting** in. Hg	in. Hg	of run, Ø min. sec	Ø min. sec
1	2.80	10.000	278.640	289.047	289.047	69	74	68	73.8	3	3	9	20
2	2.80	10.000	289.047	299.581	289.047	69	83	70	78.3	3	3	9	24
3	2.80	12.000	299.581	312.292	299.581	69	88	72	81.5	3	3	11	19

Run No.	Y	$\Delta H@$
1	0.963	1.36
2	0.959	1.37
3	0.960	1.37
Post-test average***	0.961	1.37

Difference
from Pretest ***= 0.015 0.03

$$y = \frac{(Vw)(Pbar)(Td+460)}{(Vd)(Pbar+\Delta H/13.6)(Tw+460)}$$

$$\Delta H@ = \frac{(0.0317)(\Delta H) \times}{(Pbar)(Td+460)} \left| \frac{(Tw+460)}{Vw} \right| \frac{2}{2}$$

- * To be the average ΔH used during the test series.
- ** To be the highest vacuum used during the test series.
- *** Post-test Y must be within ± 0.05 Initial Y.
 $\Delta Y = (Posttest Y - Initial Y) / Initial Y$
Post-test $\Delta H@$ must be within ± 0.15 in. H2O of the Initial $\Delta H@$.
 $\Delta H@ \text{ difference} = Posttest \Delta H@ - Initial \Delta H@$

Data checked by: C. M.
Date: 1-26-94

Stack Thermocouples

Each thermocouple is calibrated by comparing it with an ASTM-3F thermometer at approximately 32°F, ambient temperature, 100°F, and 500°F. The thermocouple read within 1.5 percent of the reference thermometer throughout the entire range when expressed in degrees Rankine. If the stack gas is saturated with moisture, the thermocouple is calibrated at 10° intervals between 70° and 180°F using a water bath. The thermocouple agreed within $\pm 2^\circ\text{F}$ of the reference thermometer over the entire range. The thermocouples may be checked at ambient temperature at the test site to verify the calibration. Calibration data are included in the following Thermocouple Calibration Data Sheet(s).



INTERNATIONAL
TECHNOLOGY
CORPORATION

THERMOCOUPLE CALIBRATION DATA SHEET

Date: 12/27/93 Thermocouple No: 690
Calibrator: H. Bowles Reference: ASTM-3F
Range: _____

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference %**
1	2	70	69	.19
2	1	32	34	-.41
3	3	185	187	-.31
4	4	455	456	-.11

- Source: 1) Ice bath
2) Ambient
3) Water bath
4) Oil bath

** Percent difference.

$$\frac{\text{Reference temp. } ^\circ\text{R} - \text{thermocouple temp. } ^\circ\text{R}}{(\text{Reference temp. } ^\circ\text{R})} \times 100\%$$

$$\text{where } ^\circ\text{R} = ^\circ\text{F} + 460$$

Each percent difference must be less than or equal to 1.5%.

Checked by Jm Date 1/19/94

DIGITAL INDICATOR CALIBRATION DATA SHEET

 DATE: 12-29-93 INDICATOR: FT-4

 OPERATOR: J. Nerse

Test Point Number	Equivalent Temperature, °F T_e	Digital Indicator Temperature, °F T_{di}	Difference,* %
1	0	0	0
2	100	98	.36
3	200	201	.15
4	300	298	.26
5	400	398	.23
6	500	497	.31
7	1000	997	.21
8	1300	1295	.28
9	1600	1593	.34
10	1900	1890	.42

*PERCENT DIFFERENCE MUST BE LESS THAN OR EQUAL TO 0.5%

$$\% \text{ DIFFERENCE} = \frac{(T_e, ^\circ\text{F} - T_{di}, ^\circ\text{F})}{(T_e, ^\circ\text{F} + 460)} \times 100$$

 Checked By HB Date 1/3/94

DIGITAL INDICATOR CALIBRATION DATA SHEET

DATE: 9-27-93 INDICATOR: FT-5

OPERATOR: J. Neese

Test Point Number	Equivalent Temperature, °F T_e	Digital Indicator Temperature, °F T_{di}	Difference,* %
1	0	1	.22
2	100	100	0
3	200	201	.15
4	300	300	0
5	400	399	.12
6	500	501	.10
7	1000	1002	.14
8	1300	1301	.06
9	1600	1602	.10
10	1900	1901	.04

*PERCENT DIFFERENCE MUST BE LESS THAN OR EQUAL TO 0.5%

$$\% \text{ DIFFERENCE} = \frac{(T_e, ^\circ\text{F} - T_{di}, ^\circ\text{F})}{(T_e, ^\circ\text{F} + 460)} \times 100$$

Checked By 3/1 Date 9/29/93

Dry Gas Thermocouples and Impinger Thermocouples

The dry gas thermocouples are calibrated by comparing them with an ASTM-3F thermometer at approximately 32°F, ambient temperature, and a higher temperature between approximately 100° and 200°F. The thermocouples agreed within 5°F of the reference thermometer. The impinger thermocouples are checked in a similar manner at approximately 32°F and ambient temperature, and they agreed within 2°F. The thermocouples may be checked at ambient temperature prior to the test series to verify calibration. Calibration data are included in the following Dry Gas Thermometer and Impinger Thermocouple Calibration Data Sheet(s).

DRY GAS THERMOCOUPLE CALIBRATION DATA SHEET

Date: 12-29-93 Thermocouple No: FT-4

Calibrator: J. Neese Reference: ASTM-3F

Inlet

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	70	70	0
2	2	32	35	3
3	3	166	166	0

Outlet

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	70	69	1
2	2	32	34	2
3	3	166	162	4

- Source: 1) Ambient
2) Ice bath
3) Water bath

** Difference must be less than 5°F at both points.

Checked by HJB Date 1/3/94

DRY GAS THERMOCOUPLE CALIBRATION DATA SHEET

Date: 9-27-93 Thermocouple No: FT-5

Calibrator: J. Neese Reference: ASTM

Inlet

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	68	66	2
2	2	36	35	1
3	3	144	142	2

Outlet

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	68	67	1
2	2	36	35	0
3	3	144	142	2

- * Source: 1) Ambient
2) Ice bath
3) Water bath

** Difference must be less than 5°F at both points.

Checked by J. Neese Date 9-27-93

IMPINGER THERMOCOUPLE CALIBRATION DATA SHEET

Date: 1-7-93 Thermocouple No: I-21

Calibrator: GThress Reference: ASTM

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	68°	68°	0
2	2	33	34	+1

- Source: 1) Ambient
2) Ice bath

** Difference must be less than 2°F at both points.

Checked by Jm Date 1/19/94

IMPINGER THERMOCOUPLE CALIBRATION DATA SHEET

Date: 12-17-92 Thermocouple No: I-99
Calibrator: P7 Reference: ASTM 3F

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	69	69	0.0
2	2	35	35	0

- Source: 1) Ambient
2) Ice bath

** Difference must be less than 2°F at both points.

Checked by JM Date 12/29/92

IMPINGER THERMOCOUPLE CALIBRATION DATA SHEET

Date: 1-24-94 Thermocouple No: I-99
 Calibrator: J. Neese Reference: ASTM

Reference point no.	Source*	Reference thermometer temperature °F	Thermocouple temperature °F	Difference °F**
1	1	70	71	1
2	2	34	35	1

- Source: 1) Ambient
2) Ice bath

** Difference must be less than 2°F at both points.

Checked by R. Well Date 1/24/94

Trip Balance

The trip balance is calibrated by comparing it with Class-S standard weights, and it agreed within 0.5 g. Calibration data are shown in the following Trip Balance Calibration Data Sheet(s).

TRIP BALANCE CALIBRATION DATA SHEET

*

Balance No.	Date	Calibrator	Mass determined for					
			5 g	Error	50 g	Error	100 g	Error
198	1/6/93	J. Neese	5	0	50	0	100	0
422	1/6/93	J. Neese	5	0	50	0	100	0
199	1/6/93	J. Neese	4.8	.2	49.7	.3	99.9	.1
Mettler	1/6/93	J. Neese	5	0	50	0	100	0
421	1/6/93	J. Neese	5	0	49.8	.2	99.8	.2
418	1/6/93	J. Neese	4.7	.3	49.9	1	100	0
419	1/6/93	J. Neese	5	0	49.9	1	100	0

Error must not exceed 0.5 grams at each point.

Checked by Doug Gill Date 1-6-93

Barometer

The field barometer is calibrated to within 0.1 in.Hg of an NBS-traceable mercury-in-glass barometer before the test series. It is checked against the reference barometer after each test series to determine if it reads within 0.2 in.Hg. The barometer read within the allowable limits each time. Calibration data are included in the following Barometer Calibration Log(s).

BAROMETER CALIBRATION LOG

PRETEST

BAROMETER NO.	401	420	431	415	420	431	401
Client	Svelep	Jefferson	Cichen	E. Detroit	Jefferson	ST. LOUIS	Miles
Project No.	332336	332			332353 332352		313674-6
BAROMETER READING	29.50	29.36	29.25	29.62	29.40	29.25	29.39
REFERENCE BAROMETER READING	29.52	29.34	29.28	29.62	29.40	29.22	29.40
DIFFERENCE*	.02	.02	.03	.00	.00	.03	.01
DATE	12-13-93	12-14-93	12-14-93	12-16-93	1-3-94	1-4-94	1-7-94
CALIBRATOR	JT	JT	Qm	Qm	JT	P7	JT

POST-TEST


BAROMETER READING	29.36	29.40		29.72	29.40	29.61	29.55
REFERENCE BAROMETER READING	29.40	29.40		29.79	29.38	29.69	29.57
DIFFERENCE**	0.04	.00		.07	.02	0.08	0.02
DATE	12/21/93	1-3-94		12/30/93	1-12-94	1/24/94	2/4/94
CALIBRATOR	BLG	JT		JT	JT	BLG	BLG

*Barometer is adjusted so that difference does not exceed 0.05 in. Hg.

**Barometer is not adjusted. If difference exceed 0.10 in. Hg, inform project manager immediately.

Orsat Analyzer

The Orsat analyzer is calibrated before the test series by determining the percentages of carbon dioxide and oxygen in a calibration gas containing known percentages of each. The analyzer read within 0.5 percent of the known values. Calibration data are shown in the following Orsat Calibration Data Sheets.



Orsat No.: 142 Gas: CO₂
4.5 5.0 5.5

Calibrator	Date	PN	Value determined
GThress	7-19-93	332310	5.0
J. Neese	8/28/93	332319-01	5.0
GThress	9-11-93	Fernco	5.0
P. Fitzgerald	12-3-93	JAN 14	4.9
D. Cahill	1-3-94	332-352	4.9
D. Cahill	1-7-94	miles	4.9