

Note: This material is related to a section in AP42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.

These are the source test reports for AP 42 section 11.17 Lime Manufacturing. They are referenced in the database as a group, Lime Manufacturing source tests.

*to determine
lime-kiln emissions
from existing kilns.*

**EMISSION TEST REPORT
LIME KILN VENTURI SCRUBBER STACK
W. S. FREY COMPANY
CLEAR BROOK, VA 22624**

Prepared for:

**W. S. FREY COMPANY
Clear Brook, Virginia 22624**

Prepared By:

**Roy F. Weston, Inc.
Weston Way
West Chester, Pennsylvania 19380**

W.O. No.: 6845-01-02


JULY 1992



**EMISSION TEST REPORT
LIME KILN VENTURI SCRUBBER STACK
W. S. FREY COMPANY
CLEAR BROOK, VA 22624**


Prepared for:

**W. S. FREY COMPANY
Clear Brook, Virginia 22624**


**Richard Ruch
Project Director**


**Uttam Trivedi, P.E.
Project Manager**

(215) 344-3674


**Kam Lo (Larry) Si
Project Engineer**

Prepared By:

**Roy F. Weston, Inc.
Weston Way
West Chester, Pennsylvania 19380**

W.O. No.: 6845-01-02

JULY 1992



TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1	SUMMARY	1-1
2	INTRODUCTION	2-1
3	RESULTS AND DISCUSSIONS	3-1
4	PROCESS DESCRIPTION	4-1
5	DESCRIPTION OF TEST LOCATION	5-1
6	DESCRIPTION OF SAMPLING TRAINS AND GENERAL SAMPLING TEST PROCEDURES	6-1

APPENDICES

A	RAW TEST DATA
B	LABORATORY REPORT
C	SAMPLE CALCULATIONS
D	EQUIPMENT CALIBRATION RECORDS
E	PROCESS OPERATIONS DATA
F	CALIBRATION GAS CERTIFICATES
G	CHAIN OF CUSTODY
H	LIST OF WESTON PROJECT PARTICIPANTS

LIST OF FIGURES

<u>FIGURE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
4-1	LIME KILN PROCESS AND CONTROL EQUIPMENT FLOW DIAGRAM	4-2
5-1	LIME KILN VENTURI SCRUBBER PORT LOCATION AND TRAVERSE POINTS DISTANCES	5-2
6-1	CONTINUOUS EMISSIONS MONITORING SYSTEM	6-3
6-2	EPA METHOD 5 PARTICULATE SAMPLING TRAIN	6-7

LIST OF TABLES

<u>TABLE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
1-1	SUMMARY OF EMISSIONS - LIME KILN VENTURI SCRUBBER STACK	1-2
3-1	PARTICULATE, NO _x , SO ₂ , AND CO TEST DATA AND TEST RESULTS - LIME KILN VENTURI SCRUBBER STACK	3-2
6-1	TEST PARAMETERS AND ASSOCIATED SAMPLING PROCEDURES	6-2



SECTION 1 SUMMARY

Roy F. Weston, Inc., (WESTON®) was retained by W.S. Frey Company (FREY) to conduct a source emission testing program on the stack of the venturi scrubber serving the lime kiln process at the Clear Brook, Virginia facility.

The objective of the testing was to measure particulate matter (TSP), sulfur dioxide (SO_2), oxides of nitrogen (NO_x) and carbon monoxide (CO) emission concentrations and mass rates exiting the lime kiln's venturi scrubber. All testing procedures conformed with United States Environmental Protection Agency (EPA) Reference Methods (40 CFR 60, Appendix A). Mr. David A. Taylor of the Commonwealth of Virginia's Department of Air Pollution Control (DAPC) was present during the testing program.

A summary of the test results is presented in Table 1-1.

TABLE 1-1

**SUMMARY OF EMISSIONS
LIME KILN VENTURI SCRUBBER STACK
W.S. FREY COMPANY - CLEAR BROOK, VIRGINIA**

TEST DATA			
Run No.	One	Two	Three
Date	5-19-92	5-19-92	5-19-92
Time	0845-1024	1154-1329	1455-1624
STACK DATA			
Temperature, °F	148	148	148
Oxygen, % by volume, dry	4.8	5.0	5.8
CO ₂ , % by volume, dry	20.9	20.7	18.9
Moisture, %	24.1	23.6	24.0
Velocity, ft/sec	92.0	92.0	91.7
Volume Flow Rate			
- Actual, ACFM	34,500	34,500	34,400
- Standard, DSCFM	23,000	23,200	23,000
NITROGEN OXIDE			
Concentration, ppmv (dry)	494.6	479.8	598.0
Mass Rate, lb/hr	81.5	79.7	98.5
Emission Factor, lb/ton of lime	9.1	8.5	10.7
SULFUR DIOXIDE			
Concentration, ppmv (dry)	726.7	891.1	768.3
Mass Rate, lb/hr	166.5	206.0	176.1
Emission Factor, lb/ton of lime	18.5	21.9	19.1
CARBON MONOXIDE			
Concentration, ppmv (dry)	85.3	180.5	50.9
Mass Rate, lb/hr	8.6	18.3	5.1
Emission Factor, lb/ton of lime	1.0	1.9	0.6
PARTICULATE			
Concentration, gr/dscf	0.0485	0.0425	0.0705
Mass Rate, lb/hr	9.57	8.46	13.89
Emission Factor, lb/ton of lime	1.1	0.9	1.5



SECTION 2

INTRODUCTION

WESTON was retained by FREY to conduct a source emission testing program on the stack of the venturi scrubber serving the lime kiln process (reference No. 22 and SCC No. 30501604) at the Clear Brook, Virginia facility.

The objective of the testing was to measure particulate matter (TSP), sulfur dioxide (SO_2), oxides of nitrogen (NO_x) and carbon monoxide (CO) emission concentrations and mass rates exiting the lime kiln's venturi scrubber. All testing procedures conformed with United States Environmental Protection Agency (EPA) Reference Methods (40 CFR 60, Appendix A).

All tests were performed on 19 May 1992 by WESTON Air Quality Testing Services personnel. Mr. Mark A. Georgiana of FREY coordinated the testing with facility operations and served as WESTON's technical contact throughout the effort. Mr. David A. Taylor of the Commonwealth of Virginia's DAPC was present during the entire testing program.

Section 3 of this report presents the detailed results of the testing effort. Section 4 describes the lime kiln process. Section 5 describes the test location. Section 6 describes sampling trains and general sampling test procedures. Raw test data, laboratory reports, sample calculations, equipment calibration records, process operations data, calibration gas certificates, chain of custody, and a list of WESTON project participants are provided in Appendices A through H, respectively.



SECTION 3

RESULTS AND DISCUSSIONS

A summary of the test results is presented in Table 1-1, page 1-2 of this report. Detailed test data and results are presented in Table 3-1 of this section.

All test data and test results shown herein are believed to be representative of process emissions encountered during the testing periods. Mr. David A. Taylor of the Commonwealth of Virginia's DAPC was present to observe the testing and process operations.

No process, sampling or analytical problems were noted during the entire testing program.

**Table 3-1. Detailed Summary Of
Emissions - TSP, NO_x, SO₂, CO.
W.S. Frey Co. Lime kiln Venturi
Scrubber Stack.**

TEST DATA:

	1	2	3
Test run number		SCRUBBER STACK	
Test location			
Test date	05-19-92	05-19-92	05-19-92
Test time period	0854-1024	1154-1329	1455-1624

SAMPLING DATA:

Sampling duration, min.	60.0	60.0	60.0
Nozzle diameter, in.	0.175	0.175	0.175
Cross sectional nozzle area, sq.ft.	0.000167	0.000167	0.000167
Barometric pressure, in. Hg	30.35	30.38	30.41
Avg. orifice press. diff., in H ₂ O	1.09	1.18	1.19
Avg. dry gas meter temp., deg F	73	79	91
Avg. abs. dry gas meter temp., deg. R	533	539	551
Total liquid collected by train, ml	238.0	244.0	247.0
Std. vol. of H ₂ O vapor coll., cu.ft.	11.204	11.486	11.627
Dry gas meter calibration factor	0.9915	0.9915	0.9915
Sample vol. at meter cond., dcf	35.428	37.647	38.038
Sample vol. at std. cond., dscf (1)	35.375	37.232	36.805
Percent of isokinetic sampling	95.8	100.1	99.9

GAS STREAM COMPOSITION DATA:

CO ₂ , % by volume, dry basis	20.9	20.7	18.9
O ₂ , % by volume, dry basis	4.8	5.0	5.8
N ₂ , % by volume, dry basis	74.2	74.3	75.3
Molecular wt. of dry gas, lb/lb mole	31.54	31.51	31.25
H ₂ O vapor in gas stream, prop. by vol.	0.241	0.236	0.240
Mole fraction of dry gas	0.759	0.764	0.760
Molecular wt. of wet gas, lb/lb mole	28.29	28.32	28.07

GAS STREAM VELOCITY AND VOLUMETRIC FLOW DATA:

Static pressure, in. H ₂ O	-0.90	-0.91	-0.97
Static pressure, in. Hg	-0.066	-0.067	-0.071
Absolute pressure, in. Hg	30.28	30.31	30.34
Avg. temperature, deg. F	148	148	148
Avg. absolute temperature, deg.R	608	608	608
Pitot tube coefficient	0.84	0.84	0.84
Total number of traverse points	24	24	24
Avg. gas stream velocity, ft./sec.	92.0	92.0	91.7
Stack/duct cross sectional area, sq.ft.	6.25	6.25	6.25
Avg. gas stream volumetric flow, wacf/min.	34500	34500	34400
Avg. gas stream volumetric flow, dscf/min.	23000	23200	23000

PARTICULATE LABORATORY REPORT:

Frt half acetone catch, g	0.0293	0.0218	0.0335
Filter catch, g	0.0818	0.0808	0.1346
Total filterable catch weight, g	0.1111	0.1026	0.1681

PARTICULATE EMISSIONS:

Concentration, gr/dscf	0.0485	0.0425	0.0705
Particulate mass rate, lb/hr	9.57	8.46	13.89

(1) Standard conditions = 68 deg. F. (20 deg. C.) and 29.92 in Hg (760 mm Hg)

TABLE 3-1
(continued)

TEST DATA:

	1	2	3
Test Run No.			
Test Date	5/19/92	5/19/92	5/19/92
Test Time Period	0845-1024	1154-1329	1455-1624

NO_x EMISSIONS:

Concentration, ppmv (dry)	494.6	479.8	598.0
Mass Rate, lb/hr	81.5	79.7	98.7

SO₂ EMISSIONS:

Concentration, ppmv (dry)	726.7	891.1	768.3
Mass Rate, lb/hr	166.5	206.0	176.1

CO EMISSIONS:

Concentration, ppmv (dry)	85.3	180.5	50.9
Mass Rate, lb/hr	8.6	18.3	5.1

SECTION 4

PROCESS DESCRIPTION

The W.S. Frey Company, Inc. owns and operates a limestone quarry in Clear Brook, Frederick County, Virginia. In recent years, approximately 800,000 tons per year of limestone, i.e., calcium carbonate, have been quarried at the facility. While most of the total quantity of limestone quarried is processed into aggregate stone and other limestone products, such as agricultural lime, an average quantity in 1990 and 1991 of 54,000 tons per year of lime, i.e., calcium oxide, was produced by processing limestone through a coal-fired horizontal rotary kiln. The kiln is a refractory-lined steel cylinder approximately 165 feet long. Limestone travels through the kiln countercurrent to the flow of hot gases produced from coal combustion, and the heat results in decomposition of the limestone to lime and carbon dioxide. The kiln is equipped with a venturi scrubber to reduce particulate matter and sulfur dioxide emissions prior to discharge to the atmosphere through a 30-foot stack. Figure 4-1 presents the process and control equipment flow diagram.

Due to an increase in market demand for lime and the age of its existing kiln, FREY proposes to replace the existing Allis Chalmers rotary kiln with a newer, higher capacity F.L. Smidth rotary kiln. The existing kiln has an average rated capacity of approximately 216 tons of lime per day. The proposed kiln will have a maximum rated capacity of 500 tons of lime per day.

In order to determine the specific air quality permitting requirements associated with the facility modification, FREY conducted a stack test of the existing kiln to characterize baseline emissions of SO_2 , NO_x , and CO. The air pollutants and other exhaust gas parameters were measured using EPA Test Methods given in Appendix A, 40CFR60. The SO_2 , NO_x , and CO tests were conducted in the venturi scrubber stack using instrumental analyzers. Details of the test methods are discussed in the following sections.




Figure 4-1
W.S. Frey Co.
Lime Kiln Process and Control Equipment Flow Diagram


WSFREY01-d18

SECTION 5

DESCRIPTION OF TEST LOCATION

Four, 3-inch ID test ports were installed horizontally on the 30" by 30" square vertical duct. The ports were placed ~ 24 feet downstream (9.6 duct diameters) from the scrubber ID fan and 5 feet (2 duct diameters) upstream from the stack discharge point. Twenty-four traverse points (6 per port) were selected based on requirements of EPA Reference Method One. These traverse points were utilized to determine a representative velocity profile and volumetric flowrate of the discharge gases. Figure 5-1 illustrates test port placement and traverse point locations.

**W.S. FREY COMPANY
CLEARBROOK, VIRGINIA**



TRAVERSE POINT NUMBER	DISTANCE FROM INSIDE NEAR WALL (INCHES)
1	2 1/2
2	7 1/2
3	12 1/2
4	17 1/2
5	22 1/2
6	27 1/2

**FIGURE 5-1
LIME KILN VENTURI SCRUBBER
PORT LOCATIONS AND TRAVERSE POINT DISTANCES**

SECTION 6

DESCRIPTION OF SAMPLING TRAINS AND GENERAL SAMPLING TEST PROCEDURES

Test procedures conformed with the United States Environmental Protection Agency (EPA) Reference Methods (40CFR60, Appendix A). Table 6-1 summarized the emissions test parameters and test methods.

6.1 CONTINUOUS MONITORING SYSTEM

A Continuous Emissions Monitoring (CEM) system was employed to measure sulfur dioxide, carbon monoxide and nitrogen oxides. A flow diagram of the CEM system is presented in Figure 6-1.

A heated (~250°F) stainless steel probe was used to collect a sample at the centroid of the stack. At the back end of the probe, a pneumatic valve that permits the introduction of calibration gas was used. The sample was drawn through a heated Teflon® sample line to the sample conditioner. The sample conditioner consists of a two-pass refrigeration cooler with a Teflon® headed pump. Sample system pressure was monitored immediately before the sample pump. The dried sample was directed to the analyzers. The output from the CEM system were maintained with a data logger and recorded on a Molytek Model 2702 strip chart recorder. Simultaneously, a computer was hooked up to the data logger for data collection. The data logger averages one second values to form one-minute averages. These one-minute averages are used to compute an average one-hour concentration. These data were all stored in the computer.

TABLE 6-1

**TEST PARAMETERS AND
ASSOCIATED SAMPLING PROCEDURES**

LIME KILN VENTURI SCRUBBER

PARAMETER	SAMPLING AND ANALYTICAL PROCEDURES ¹
Gas Velocity and Volumetric Flow Rate	EPA 1, 2
Gas Composition (CO ₂ and O ₂ Concentrations)	EPA 3
Moisture Content	EPA 4
Particulate	EPA 5
Carbon Monoxide	EPA 10
Sulfur Dioxide	EPA 6C
Oxides of Nitrogen	EPA 7E

¹ EPA = U.S. Environmental Protection Agency 40CFR60, Appendix A - Reference Methods.

Each analyzer was set up and calibrated internally by introduction of calibration gas standards directly to the analyzer from a calibration manifold. The calibration gas was supplied in excess; the excess gas was released to the atmosphere to maintain calibration at ambient pressure. After internal calibration, a system bias check was conducted for each analyzer. The zero gas and one upscale calibration gas was sequentially introduced into the sample system at the valve at the end of the probe. Calibration gas injection rate was monitored to maintain the sample system pressure at the same level observed during actual stack sampling. The internal and bias check instrument responses agreed to within 3% full scale. All calibration gases were NBS standards with a guaranteed accuracy of $\pm 2\%$ or EPA Protocol One gases.

6.1.1 Carbon Monoxide

Carbon monoxide (CO) concentrations were determined using EPA Method 10 procedures. The carbon monoxide analyzer was a Thermo-Environmental Model 48, gas phase correlation filter nondispersive infrared analyzer which is not affected by carbon dioxide in the sample gas. Therefore, no CO₂ scrubber was necessary.

6.1.2 Sulfur Dioxide

Sulfur dioxide (SO₂) concentrations were determined using EPA Method 6C procedures. A Western Research Model 721AT analyzer was used to measure the SO₂ concentrations. The analyzer measures the SO₂ concentration continuously using a non-dispersive ultraviolet light detection procedure.

6.1.3 Oxides of Nitrogen

Oxides of nitrogen (NO_x) concentrations were determined using EPA Method 7E procedures. A Thermo-Environmental Model 10A chemiluminescent reaction analyzer was used to continuously measure NO_x concentrations. The analyzer's built in response time is approximately 1.5 seconds.

6.1.4 Particulate

Preliminary test data were obtained on the sampling locations for nozzle sizing and sampling rate determinations for isokinetic sampling procedures. Stack geometric measurements were recorded, and traverse point distances calculated. A preliminary velocity traverse was performed utilizing a calibrated "S" type pitot tube and a Dwyer inclined manometer to determine velocity profiles. Flue gas temperatures were observed with a calibrated direct readout pyrometer equipped with a chromel-alumel thermocouple. Water vapor was determined from wet bulb/dry bulb measurements utilizing a psychrometric chart.

A check for the presence or absence of cyclonic flow was conducted at the test location prior to formal testing. All cyclonic flow checks proved to be negative ($\alpha < 20^\circ$) thus verifying the suitability of the test site for obtaining representative samples.

Calibration of probe nozzles, pitot tubes, metering systems, probe heaters and temperature gauges was performed as specified in the Environmental Protection Agency Test Method procedures (see Appendix D).

6.1.4.1 Description Of Particulate Sampling Train

The sampling train utilized to perform the particulate sampling was EPA Reference Method 5 train (see Figure 6-2).

A calibrated stainless steel nozzle was attached to a heated ($\sim 250^{\circ}\text{F}$) borosilicate probe of appropriate length. The probe was connected to a heated ($\sim 250^{\circ}\text{F}$) borosilicate filter holder containing a 9-cm 2,500-QAT-UP quartz fiber filter (preweighed to a constant 0.1 mg weight). The first and second impingers each contained 100 ml of distilled water, the third impinger was dry, and the fourth impinger contained 300 grams of dry preweighed silica gel. The second impinger was a standard Greenburg-Smith type; the first, third, and fourth were of a modified design. All impingers were maintained in a crushed ice bath. A Nutech control console with a leakless vacuum pump, a calibrated dry gas meter, a calibrated orifice, and inclined manometers was connected to the final impinger via an umbilical cord to complete the train.

Flue gas velocity was measured with a calibrated "S" type pitot tube (provided with extensions) fastened alongside the sampling probe. Flue gas temperature was monitored with a calibrated direct readout pyrometer equipped with a chromel-alumel thermocouple positioned near the sampling nozzle. Filter box and impinger exit gas temperatures were monitored with a calibrated direct readout pyrometer equipped with chromel-alumel thermocouples positioned in the heated filter chamber and in the sample gas stream after the last impinger. Stack gas stream composition (carbon dioxide and oxygen content) was determined utilizing an Orsat apparatus to analyze multi-point integrated samples of the flue gas obtained for each test period.

6.1.4.2 Particulate Sample Recovery

At the conclusion of each test, the sampling train was dismantled, openings sealed, and the components transported to the field laboratory. Sample integrity was assured by maintaining chain-of-custody records.

A consistent procedure was employed for sample recovery as follows:

- The quartz fiber filter was removed from its holder with tweezers and placed in its original container (petri dish), along with any loose particulate and filter fragments (Sample 1).
- The probe and nozzle were separated and the particulate rinsed with acetone into a borosilicate container fitted with a Teflon-lined closure while brushing a minimum of three times. Particulate adhering to the brush was rinsed with acetone into the same container. The front-half of the filter holder and connecting glassware were also rinsed with acetone while brushing a minimum of three times. The rinses were combined (Sample 2).
- The total liquid contents of impingers one, two and three were measured volumetrically to the nearest milliliter (ml) and the liquid discarded.
- The silica gel was removed from the last impinger and immediately weighed to the nearest 0.1 gram (g).
- Samples of acetone and a quartz fiber filter were retained for blank analysis.

Each sample bottle was labeled to clearly identify it's contents. The height of the fluid was marked on each bottle. The samples were then placed in a locked shipping crate prior to transport to the WESTON Analytics laboratory.

6.1.4.3 Particulate Analysis

The particulate analysis proceeded as follows:

- The filters (Sample 1) and any loose fragments were desiccated for 24 hours and weighed to the nearest 0.1 milligram (mg) to a constant (± 0.5 mg) weight.
- The front-half acetone wash samples (Sample 2) and an acetone blank were evaporated at ambient temperature and pressure in tared beakers, then desiccated to constant 0.1 mg weight.

The total weight of material measured in the front-half acetone-rinse fraction plus the weight of material collected on the glass fiber filter represents the particulate catch for each train. Blank corrections were made where appropriate for all sample weights.



APPENDIX A
RAW TEST DATA

W.S. FREY COMPANY
Clear Brook, VA
Lime Kiln Stack
Run One

DATE	TIME	SO2 (ppmv)	CO (ppmv)	NOx (ppmv)
19 May 1992	08:58	520.83	2.59	661.29
19 May 1992	08:59	541.55	2.96	641.66
19 May 1992	09:00	576.45	3.10	638.18
19 May 1992	09:01	587.32	4.29	584.83
19 May 1992	09:02	633.35	6.20	589.69
19 May 1992	09:03	682.45	6.62	572.09
19 May 1992	09:04	696.76	9.32	502.56
19 May 1992	09:05	684.81	21.83	425.43
19 May 1992	09:06	633.45	31.68	349.37
19 May 1992	09:07	543.91	45.00	239.98
19 May 1992	09:08	202.22	45.68	286.14
19 May 1992	09:09	14.43	22.21	305.94
19 May 1992	09:10	3.89	23.36	228.42
19 May 1992	09:11	8.26	28.34	317.32
19 May 1992	09:12	622.34	14.35	564.57
19 May 1992	09:13	768.18	7.83	569.10
19 May 1992	09:14	885.74	32.33	356.22
19 May 1992	09:15	1232.13	36.68	503.32
19 May 1992	09:16	1076.02	14.21	560.26
19 May 1992	09:17	912.66	8.50	562.32
19 May 1992	09:18	830.43	30.31	401.39
19 May 1992	09:19	848.42	217.92	296.84
19 May 1992	09:20	946.59	88.60	234.77
19 May 1992	09:21	594.85	751.14	96.31
19 May 1992	09:22	83.67	353.04	251.67
19 May 1992	09:23	11.96	251.35	312.48
19 May 1992	09:24	5.99	47.37	277.98
19 May 1992	09:25	396.39	31.18	573.13
19 May 1992	09:26	668.58	11.88	617.84
19 May 1992	09:27	682.17	7.77	616.06
19 May 1992	09:28	915.90	36.84	318.65
19 May 1992	09:29	1443.58	588.03	129.50
19 May 1992	09:30	1092.98	943.17	563.37
19 May 1992	09:31	766.04	84.72	585.68
19 May 1992	09:32	630.30	13.08	637.19
19 May 1992	09:33	538.33	8.11	630.95
19 May 1992	09:34	524.35	5.87	646.37
19 May 1992	09:35	510.47	14.45	496.65
19 May 1992	09:36	681.93	31.84	557.00
19 May 1992	09:37	904.64	10.03	641.44
19 May 1992	09:38	768.44	5.58	675.53
19 May 1992	09:39	610.14	4.28	677.03
19 May 1992	09:40	528.02	4.10	678.13
19 May 1992	09:41	501.45	4.10	670.77
19 May 1992	09:42	507.91	3.26	677.77
19 May 1992	09:43	457.69	4.10	696.81
19 May 1992	09:44	523.57	3.24	696.23
19 May 1992	09:45	517.35	3.28	680.05
19 May 1992	09:46	619.85	4.10	665.55
19 May 1992	09:47	694.28	6.28	602.42
19 May 1992	09:48	958.19	16.84	511.23
19 May 1992	09:49	1048.05	26.90	466.51
19 May 1992	09:50	1147.11	43.86	353.58
19 May 1992	09:51	1313.98	59.79	335.83
19 May 1992	09:52	1178.31	47.01	435.53
19 May 1992	09:53	1053.86	32.91	492.53
19 May 1992	09:54	1031.13	31.16	492.18
19 May 1992	09:55	1048.89	32.78	505.15
19 May 1992	09:56	1054.46	36.15	464.42
19 May 1992	09:57	1097.00	38.83	476.90
19 May 1992	09:58	1090.70	39.15	437.16
19 May 1992	09:59	1110.32	199.10	240.26
19 May 1992	10:00	1281.52	595.82	287.20
19 May 1992	10:01	1272.00	94.50	340.72
AVG		723.7	81.7	482.9
Bias Corrected		726.7	85.3	494.6

W.S. FREY COMPANY
Clear Brook, VA
Lime Kiln Stack
Run Two

DATE	TIME	SO2 (ppmv)	CO (ppmv)	NOx (ppmv)
19 May 1992	11:58	785.47	40.75	669.76
19 May 1992	11:59	623.56	12.39	685.28
19 May 1992	12:00	759.74	19.26	503.49
19 May 1992	12:01	1117.74	35.43	633.68
19 May 1992	12:02	848.61	25.24	408.02
19 May 1992	12:03	1126.16	351.79	195.47
19 May 1992	12:04	1299.62	821.98	182.07
19 May 1992	12:05	1281.97	1036.01	178.58
19 May 1992	12:06	1317.35	1036.09	170.96
19 May 1992	12:07	1358.06	1036.17	180.67
19 May 1992	12:08	1335.03	847.13	317.76
19 May 1992	12:09	1302.99	174.08	311.94
19 May 1992	12:10	1338.89	661.41	138.67
19 May 1992	12:11	1333.69	670.42	123.70
19 May 1992	12:12	1302.35	1035.24	126.27
19 May 1992	12:13	1330.43	677.98	141.29
19 May 1992	12:14	1305.97	1036.11	163.84
19 May 1992	12:15	1344.28	756.41	487.27
19 May 1992	12:16	1323.26	56.75	438.08
19 May 1992	12:17	1330.76	46.49	544.23
19 May 1992	12:18	951.09	20.12	662.74
19 May 1992	12:19	701.49	11.76	699.24
19 May 1992	12:20	568.13	8.90	692.79
19 May 1992	12:21	611.12	10.32	604.53
19 May 1992	12:22	760.57	12.78	676.84
19 May 1992	12:23	741.56	8.48	700.26
19 May 1992	12:24	629.68	8.25	698.64
19 May 1992	12:25	603.83	7.95	653.52
19 May 1992	12:26	590.99	11.03	635.41
19 May 1992	12:27	573.16	8.38	642.75
19 May 1992	12:28	568.70	7.35	629.60
19 May 1992	12:29	572.24	6.98	618.29
19 May 1992	12:30	580.75	6.25	592.54
19 May 1992	12:31	580.52	6.61	571.17
19 May 1992	12:32	572.45	7.50	560.98
19 May 1992	12:33	524.33	22.30	365.18
19 May 1992	12:34	286.79	37.95	426.78
19 May 1992	12:35	80.47	12.44	493.15
19 May 1992	12:36	18.87	26.84	281.24
19 May 1992	12:37	503.33	56.45	220.28
19 May 1992	12:38	1261.96	101.66	259.92
19 May 1992	12:39	1151.70	60.43	474.15
19 May 1992	12:40	982.23	43.74	321.04
19 May 1992	12:41	1114.54	41.18	580.23
19 May 1992	12:42	975.77	43.23	275.86
19 May 1992	12:43	1231.50	73.47	277.94
19 May 1992	12:44	1174.86	40.08	587.57
19 May 1992	12:45	903.27	15.67	545.29
19 May 1992	12:46	820.70	33.81	532.64
19 May 1992	12:47	951.46	19.38	631.93
19 May 1992	12:48	782.37	13.47	536.74
19 May 1992	12:49	1198.94	54.12	372.35
19 May 1992	12:50	1050.68	35.81	524.10
19 May 1992	12:51	1003.64	31.64	602.83
19 May 1992	12:52	772.21	11.70	667.57
19 May 1992	12:53	672.65	6.07	701.61
19 May 1992	12:54	657.77	4.66	694.93
19 May 1992	12:55	615.52	4.05	690.46
19 May 1992	12:56	636.62	4.45	668.61
19 May 1992	12:57	697.14	5.25	648.70
19 May 1992	12:58	734.65	5.25	627.78
19 May 1992	12:59	723.12	4.85	620.17
19 May 1992	13:00	699.17	4.05	643.27
19 May 1992	13:01	676.21	20.75	423.54
AVG		879.3	177.4	483.4
Bias Corrected		891.1	180.5	479.8

W.S. FREY COMPANY
Clear Brook, VA
Lime Kiln Stack
Run Three

DATE	TIME	SO2 (ppmv)	CO (ppmv)	NOx (ppmv)
19 May 1992	15:15	1487.21	254.75	626.76
19 May 1992	15:16	762.70	53.89	599.22
19 May 1992	15:17	423.90	31.01	592.13
19 May 1992	15:18	336.15	21.39	528.84
19 May 1992	15:19	238.28	17.71	445.69
19 May 1992	15:20	179.85	15.57	433.08
19 May 1992	15:21	166.75	12.88	561.33
19 May 1992	15:22	279.42	10.70	616.20
19 May 1992	15:23	473.71	9.27	636.90
19 May 1992	15:24	535.83	8.25	676.87
19 May 1992	15:25	889.01	10.38	664.73
19 May 1992	15:26	1206.85	19.76	598.71
19 May 1992	15:27	1306.58	31.19	575.76
19 May 1992	15:28	1235.75	31.27	519.50
19 May 1992	15:29	1293.37	46.40	476.74
19 May 1992	15:30	1231.36	43.05	425.90
19 May 1992	15:31	1436.55	630.38	91.17
19 May 1992	15:32	1381.13	755.05	274.66
19 May 1992	15:33	959.57	389.22	642.66
19 May 1992	15:34	582.44	26.65	651.85
19 May 1992	15:35	484.17	12.31	646.07
19 May 1992	15:36	484.75	8.17	641.05
19 May 1992	15:37	467.21	6.72	644.59
19 May 1992	15:38	461.88	5.41	645.46
19 May 1992	15:39	453.44	4.86	638.54
19 May 1992	15:40	443.41	4.05	633.97
19 May 1992	15:41	466.95	4.05	621.86
19 May 1992	15:42	455.65	4.05	633.88
19 May 1992	15:43	638.52	9.34	516.91
19 May 1992	15:44	1342.54	39.52	556.91
19 May 1992	15:45	625.39	10.01	637.68
19 May 1992	15:46	566.79	4.86	629.30
19 May 1992	15:47	824.36	9.59	539.07
19 May 1992	15:48	852.32	12.85	619.51
19 May 1992	15:49	613.54	4.84	654.05
19 May 1992	15:50	621.30	4.05	646.33
19 May 1992	15:51	928.15	12.40	517.10
19 May 1992	15:52	1005.67	18.61	593.64
19 May 1992	15:53	794.77	7.47	602.83
19 May 1992	15:54	1238.37	32.24	349.64
19 May 1992	15:55	1656.60	83.62	348.55
19 May 1992	15:56	866.46	32.14	685.05
19 May 1992	15:57	704.49	9.77	678.46
19 May 1992	15:58	611.42	5.73	669.27
19 May 1992	15:59	584.88	4.05	658.45
19 May 1992	16:00	536.08	3.23	652.28
19 May 1992	16:01	593.64	3.37	642.06
19 May 1992	16:02	694.10	4.05	635.83
19 May 1992	16:03	683.01	4.05	653.83
19 May 1992	16:04	692.89	4.05	648.14
19 May 1992	16:05	688.28	4.05	626.61
19 May 1992	16:06	706.82	4.05	626.65
19 May 1992	16:07	652.08	3.39	596.65
19 May 1992	16:08	679.14	4.04	625.69
19 May 1992	16:09	705.55	4.22	623.68
19 May 1992	16:10	722.56	5.84	617.35
19 May 1992	16:11	763.29	7.53	618.33
19 May 1992	16:12	742.91	8.06	637.49
19 May 1992	16:13	780.00	10.50	576.73
19 May 1992	16:14	889.84	14.82	621.60
19 May 1992	16:15	762.86	10.18	642.14
19 May 1992	16:16	767.15	9.94	634.52
19 May 1992	16:17	781.07	10.13	666.93
AVG		753.0	45.8	587.2
Bias Corrected		768.3	50.9	598.0

W.S.FREY-CLEARBROOK, VA

Test Data

Run number	1	2	3
Location		SCRUBBER STACK	
Date	05-19-92	05-19-92	05-19-92
Time period	0854-1024	1154-1329	1455-1624
Operator	MILLS	WILLIAMS	MILLS

Inputs For Calcs.

Sq. rt. delta P	1.520619	1.52291	1.51041
Delta H	1.087917	1.18458	1.19375
Stack temp. (deg.F)	147.75	147.79	148.17
Meter temp. (deg.F)	73.02	78.81	91.27
Sample volume (act.)	35.428	37.647	38.038
Barometric press. (in.Hg)	30.35	30.38	30.41
Volume H2O imp. (ml)	224.0	228.0	234.0
Weight chnge sil. gel (g)	14.0	16.0	13.0
% CO2	20.9	20.7	18.9
% O2	4.8	5.0	5.8
% CO			
% N	74.2	74.3	75.3
Area of stack (sq.ft.)	6.250	6.250	6.250
Sample time (min.)	60	60	60
Static pressure (in.H2O)	-0.90	-0.91	-0.97
Nozzle dia. (in.)	0.175	0.175	0.175
Meter box cal.	0.9915	0.9915	0.9915
Cp of pitot tube	0.84	0.84	0.84

Particulate Laboratory Report Data

Frt half acetone rinse, g	0.0293	0.0218	0.0335
Filter, g	0.0818	0.0808	0.1346
Total filterable catch weight, g	0.1111	0.1026	0.1681

W.S.FREY-CLEARBROOK, VA
SUMMARY OF PARTICULATE TEST DATA AND TEST RESULTS
TABLE 1

TEST DATA:

	1	2	3
Test run number		SCRUBBER STACK	
Test location			
Test date	05-19-92	05-19-92	05-19-92
Test time period	0854-1024	1154-1329	1455-1624

SAMPLING DATA:

Sampling duration, min.	60.0	60.0	60.0
Nozzle diameter, in.	0.175	0.175	0.175
Cross sectional nozzle area, sq.ft.	0.000167	0.000167	0.000167
Barometric pressure, in. Hg	30.35	30.38	30.41
Avg. orifice press. diff., in H ₂ O	1.09	1.18	1.19
Avg. dry gas meter temp., deg F	73	79	91
Avg. abs. dry gas meter temp., deg. R	533	539	551
Total liquid collected by train, ml	238.0	244.0	247.0
Std. vol. of H ₂ O vapor coll., cu.ft.	11.204	11.486	11.627
Dry gas meter calibration factor	0.9915	0.9915	0.9915
Sample vol. at meter cond., dcf	35.428	37.647	38.038
Sample vol. at std. cond., dscf (1)	35.375	37.232	36.805
Percent of isokinetic sampling	95.8	100.1	99.9

GAS STREAM COMPOSITION DATA:

CO ₂ , % by volume, dry basis	20.9	20.7	18.9
O ₂ , % by volume, dry basis	4.8	5.0	5.8
CO, % by volume, dry basis	0.0	0.0	0.0
N ₂ , % by volume, dry basis	74.2	74.3	75.3
Molecular wt. of dry gas, lb/lb mole	31.54	31.51	31.25
H ₂ O vapor in gas stream, prop. by vol.	0.241	0.236	0.240
Mole fraction of dry gas	0.759	0.764	0.760
Molecular wt. of wet gas, lb/lb mole	28.29	28.32	28.07

GAS STREAM VELOCITY AND VOLUMETRIC FLOW DATA:

Static pressure, in. H ₂ O	-0.90	-0.91	-0.97
Static pressure, in. Hg	-0.066	-0.067	-0.071
Absolute pressure, in. Hg	30.28	30.31	30.34
Avg. temperature, deg. F	148	148	148
Avg. absolute temperature, deg.R	608	608	608
Pitot tube coefficient	0.84	0.84	0.84
Total number of traverse points	24	24	24
Avg. gas stream velocity, ft./sec.	92.0	92.0	91.7
Stack/duct cross sectional area, sq.ft.	6.25	6.25	6.25
Avg. gas stream volumetric flow, wacf/min.	34500	34500	34400
Avg. gas stream volumetric flow, dscf/min.	23000	23200	23000

PARTICULATE LABORATORY REPORT:

Frit half acetone catch, g	0.0293	0.0218	0.0335
Filter catch, g	0.0818	0.0808	0.1346
Total filterable catch weight, g	0.1111	0.1026	0.1681



PARTICULATE EMISSIONS:

Concentration, gr/dscf	0.0485	0.0425	0.0705
Particulate mass rate, lb/hr	9.57	8.46	13.89

(1) Standard conditions = 68 deg. F. (20 deg. C.) and 29.92 in Hg (760 mm Hg)

TRAVERSE POINT LOCATION FOR CIRCULAR AND RECTANGULAR DUCTS

PLANT WS Frey
 DATE 5/18/92
 SAMPLING LOCATION Schwaben Outlet
 INSIDE OF FAR WALL TO
 OUTSIDE OF PORT (DISTANCE A) 33"
 INSIDE OF NEAR WALL TO
 OUTSIDE OF PORT (DISTANCE B) 3"
 STACK I.D. (DISTANCE A - DISTANCE B) 30"
 NEAREST UPSTREAM DISTURBANCE (C) 24'
 NEAREST DOWNSTREAM DISTURBANCE (D) 5'
 CALCULATOR J. K. Mills



LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

	4	6	8	10	12	14	16	18	20	22	24
1	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3	75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4	93.3	70.4	32.3	22.8	17.7	14.6	12.5	10.8	9.7	8.7	7.9
5		85.4	67.7	34.2	25.0	20.1	16.9	14.8	12.9	11.8	10.5
6		95.6	80.6	63.8	35.6	26.9	22.0	18.8	16.5	14.8	13.2
7			89.5	77.4	64.4	38.6	28.3	23.8	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	28.6	25.0	21.8
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5
11						93.3	85.4	78.0	70.4	61.2	38.3
12							97.9	90.1	83.1	76.4	68.4
13								94.3	87.5	81.2	75.0
14									98.2	91.5	85.4
15										95.1	89.1
16											98.4
17											
18											
19											
20											
21											
22											
23											
24											

LOCATION OF TRAVERSE POINTS IN RECTANGULAR STACKS

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3		83.3	62.5	50.0	41.7	36.7	31.3	27.8	25.0	22.7	20.8
4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
7						92.9	81.3	72.2	65.0	59.1	54.2
8							93.8	83.3	75.0	68.2	62.5
9								94.4	85.0	77.3	70.8
10									95.0	86.4	79.2
11										95.5	87.5
12											95.8

ONE DATE 5/19/82

COMMENTS:

PARTICULATE SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant W.S. Frey Sample Date 5/19/92
 Sample Location Schaden Stack Run Number ONE
 Sample Recovery Person millis Recovery Date 5/19/92
 Filter Number(s) 274

MOISTURE

<u>220</u> <u>204</u> <u>424</u> <u>Impingers</u> Final volume (wt) _____ ml Initial volume (wt) <u>200</u> ml Net volume (wt) <u>224</u> ml Total moisture <u>224 + 14</u> Color of silica gel <u>1/2 Blue 1/2 orange</u> Description of impinger water <u>clear colorless</u>	<u>Silica Gel</u> Final wt <u>314</u> g Initial wt <u>300</u> g Net wt <u>14</u> g
---	--

RECOVERED SAMPLE

Blank Filter container number <u>Frey - Blank - Filter #252</u>	Sealed ☒
Filter container number <u>Frey - R1 - Part - Filter #274</u>	Sealed ☒
Filter container number _____	Sealed _____
Filter container number _____	Sealed _____
Filter container number _____	Sealed _____
Description of particulate on filter <u>Very Fine Light Grey</u>	
Front-half acetone rinse container number <u>Frey - R1 - Part - FHA</u>	Liquid level marked? ☒
Back-half water rinse container number <u>N/A</u>	Liquid level marked? _____
Back-half acetone rinse container number <u>N/A</u>	Liquid level marked? _____
Water blank container number <u>N/A</u>	Liquid level marked? _____
Acetone blank container number <u>Frey - Blank - Acetone</u>	Liquid level marked? ☒
Samples stored and locked _____	
Remarks: _____	

Date of laboratory custody 5/20/92

Laboratory personnel taking custody _____

Remarks: _____

CLIENT U.S. Frey
PLANT Clear Creek
LOCATION Kenai

EPA METHOD 5 FIELD DATA FORM

OPERATOR

RUN NO.

K FACTOR

Wills/Williams
2nd
-SHEET 2 OF 2
DATE 5/19/92

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	24-HOUR CLOCK TIME	VELOCITY HEAD (delta P) (in. H ₂ O)	ORIFICE METER PRESSURE DIFFERENTIAL (delta H) (in. H ₂ O)	GAS METER READING (cubic ft.)	DRY GAS METER TEMPERATURE		SOURCE TEMP. (deg F)	PUMP VACUUM (in. Hg gauge)	IMPINGER EXIT TEMP. (deg F)	FILTER BOX TEMP. (deg F)
						INLET (deg F)	OUTLET (deg F)				
C 1	0	1241			285.267						
2	2.5		2.40	1.22	286.9	77	75	147	7.0	62	250
3	5		2.65	1.35	288.5	80	75	146	7.5	57	252
4	7.5		2.60	1.33	290.2	83	76	147	7.5	55	253
5	10		2.55	1.30	291.8	84	76	146	7.5	55	253
6	12.5		2.50	1.27	293.5	86	77	146	7.5	55	253
7	15	1256	2.10	1.07	294.922	87	77	146	7.0	57	253
				Leak check - 1016 CFM @ 12 IN VAC							
D 1	0				295.000						
2	2.5	1314	1.9	0.97	296.4	82	80	146	6.5	67	252
3	5		1.9	0.97	297.8	85	79	146	7.0	62	252
4	7.5		2.55	1.30	299.6	86	80	146	8.0	60	254
5	10		2.45	1.25	301.2	90	81	147	8.0	58	254
6	12.5		2.50	1.27	302.7	92	81	147	8.0	58	255
7	15	1329	1.95	0.99	304.115	93	82	147	7.5	60	254
TOTAL θ			AVG. ΔP 1.522914	AVG. ΔH 1.194583	TOTAL V _m 36.1159	AVG. T _m 78.812	AVG. T _s 147.992	MAX. VAC. 8.0	MAX. TEMP. 60	MIN. 55	MAX. 255

COMMENTS: Both 253

COMMENTS: ~~20-75.8~~
~~644-20.5~~
~~Sub 0. 63~~

PARTICULATE SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant W.S. Frey Sample Date 5/19/92
 Sample Location SCHUBB-STACK Run Number TWO
 Sample Recovery Person mills Recovery Date 5/19/92
 Filter Number(s) 214

MOISTURE

Impingers

Final volume (wt) 428 ml
 Initial volume (wt) 200 ml
 Net volume (wt) 228 ml
 Total moisture 228 + 16

Silica Gel

Final wt 316 g
 Initial wt 300 g
 Net wt 16 g

Color of silica gel 1/2 Blue 1/2 orange

Description of impinger water Clear colorless

RECOVERED SAMPLE

Blank Filter container number Frey-Blank-Filter #252 Sealed ☒
 Filter container number Frey-R2-PART-FILTER #214 Sealed ☒
 Filter container number _____ Sealed _____
 Filter container number _____ Sealed _____
 Filter container number _____ Sealed _____
 Description of particulate on filter Very Fine Light Grey-TAN
 Front-half acetone rinse container number Frey-R2-PART-FHA Liquid level marked? ☒
 Back-half water rinse container number N/A Liquid level marked? _____
 Back-half acetone rinse container number N/A Liquid level marked? _____
 Water blank container number N/A Liquid level marked? _____
 Acetone blank container number Frey-Blank-Acetone Liquid level marked? ☒
 Samples stored and locked _____

Remarks: _____

Date of laboratory custody 5/20/92

Laboratory personnel taking custody _____

Remarks: _____

WELDON
LABORATORY
EPA METHOD 5 FIELD DATA FORM

CLIENT WS Frey
PLANT Cleary Creek
LOCATION Monte Vista
Sierra

OPERATOR Walt Williams
RUN NO. Three
K FACTOR _____

SHEET 2 OF 2
DATE 5/19/90

EPA METHOD 5 FIELD DATA FORM

[illegible]

COMMENTS:

PARTICULATE SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant W.S. Frey Sample Date 5/19/92
 Sample Location Schwab's Stalk Run Number Three
 Sample Recovery Person Mills Recovery Date 5/19/92
 Filter Number(s) 251

MOISTURE

<u>Impingers</u>	<u>310</u>		<u>Silica Gel</u>	
	<u>224</u>			
Final volume (wt)	<u>234</u> ml		Final wt	<u>313</u> g
Initial volume (wt)	<u>200</u> ml		Initial wt	<u>300</u> g
Net volume (wt)	<u>234</u> ml		Net wt	<u>13</u> g
Total moisture	<u>234 + 13</u>			
Color of silica gel	<u>1/2 Blue 1/2 orange</u>			
Description of impinger water	<u>Clear colorless</u>			

RECOVERED SAMPLE

Blank Filter container number	<u>Frey - Blank - Filter #252</u>	Sealed	<u>✓</u>
Filter container number	<u>Frey - R3 - PART - Filter #251</u>	Sealed	<u>✓</u>
Filter container number		Sealed	
Filter container number		Sealed	
Filter container number		Sealed	
Description of particulate on filter	<u>Very Fine TAN-LIGHT Grey - with 9 black layers underneath</u>		
Front-half acetone rinse container number	<u>Frey - R3 - PART - FHA</u>	Liquid level marked?	<u>✓</u>
Back-half water rinse container number	<u>N/A</u>	Liquid level marked?	
Back-half acetone rinse container number	<u>N/A</u>	Liquid level marked?	
Water blank container number	<u>N/A</u>	Liquid level marked?	
Acetone blank container number	<u>Frey - Blank - Acetone</u>	Liquid level marked?	<u>✓</u>
Samples stored and locked			
Remarks:			

Date of laboratory custody 5/20/92

Laboratory personnel taking custody _____

Remarks: _____

GAS ANALYSIS DATA FORM

Plant: WS. Frey

Date: 5/19/92

Sample Location: Sn B/B

Operator: mills

Sample Type: SINGLE POINT or MULTIPOINT: GRAB or INTEGRATED

Analytical Method: ORsat

Orsat Leak Check: Good

Run Number	Sample Location/Train ID	% CO ₂ Reading 1	%O ₂		%N ₂ 100 - Reading 2
			Reading 2	Net (1)	
ONE		21.0	26.0	5.0	
ONE		21.0	25.7	4.7	
ONE		20.8	25.6	4.8	
		(20.933)		(4.833)	
TWO		20.5	25.5	5.0	
TWO		20.8	25.7	4.9	
TWO		20.7	25.8	5.1	
		(20.667)		(5.000)	
THREE		18.8	24.6	5.8	
THREE		18.8	24.6	5.8	
THREE		19.0	24.9	5.9	
		(18.867)		(5.833)	
AVERAGES					

$$\%N_2 = 100 - (\%CO_2 + \%O_2 + \%CO)$$

$$MWd = 0.440(\%CO_2) + 0.320(\%O_2) + 0.280(\%N_2 + \%CO)$$

(1) Net %O₂ = Reading 1 - Reading 2

Integrated Bag Limits

CO₂ > 4% - 0.3% by vol

<=4% - 0.2% by vol

O2 $\geq$ 15% - 0.2% by vol

< 15% - 0.3% by vol



APPENDIX B
LABORATORY REPORT



ROY F. WESTON, INC.
Lionville Laboratory

CLIENT: W.S. FREY
RFW #: 9205L356
W.O. #: 6845-01-02

SAMPLE(S) RECEIVED: 05-20-92

INORGANIC NARRATIVE

The following is a summary of the quality control results and a description of any problems encountered during the analysis of this batch of samples:

1. The analytical methods applied by the laboratory in the analysis of air samples contained in this batch were derived from the Federal Register, 40 CFR, Part 60, Revised July 1, 1988, The Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air, EPA - 600/4-84-041, May 1987 and NIOSH Manual of Analytical Methods, 2nd & 3rd Editions.



Jack R. Tuschall, Ph.D.
Laboratory Manager
Lionville Analytical Laboratory

06.08.92
Date

ROY F. WESTON, INC.
GLOSSARY OF TERMS - INORGANIC REPORTS

DATA QUALIFIERS

- U - Indicates that the parameter was not detected at or above the reported limit. The associated numerical value is the sample detection limit.
- * - Indicates that the original sample result is greater than 4x the spike amount added. The USEPA-CLP has determined that spike results on samples where this occurs may be unreliable and therefore, the control limits are not applicable.

ABBREVIATIONS

- MB - Method or preparation blank.
- MS - Matrix Spike.
- MSD - Matrix Spike Duplicate.
- REP - Sample Replicate.
- LC - Indicates a method LCS or Blank Spike.
- NC - Not calculable, result below the detection limit.

A suffix of -R or -S following these codes indicates a replicate or spike analysis respectively.

ANALYTICAL METAL METHODS

As : EPA 206.2	SE	:	EPA 270.2
Pb : EPA 239.2	ICP Scan	:	EPA 200.7
Hg : EPA 245.1	All Others	:	EPA 200.7
Tl : EPA 279.2	EP Leachates	(except Hg)	200.7

The analytical methods applied by the laboratory for the determination of drinking water are found in 5.2.1.

NOTES

The laboratory prepares a matrix spike at one-per 20 frequency for TCLP samples. The Federal Register recommends that all matrix spikes be prepared at greater than 50% of the indigenous analyte concentration.

Holding times for soil samples have not been promulgated by the USEPA.

For solid samples, all results are reported on a dry weight basis.

The range for mercury solid laboratory control standards is 66.9% to 133.8%.

ROY F. WESTON INC.

INORGANIC DATA SUMMARY REPORT 06/03/92

CLIENT: W.S. FREY
WORK ORDER: 6845-01-02-0000

WESTON BATCH #: 9205L356

SAMPLE	SITE ID	ANALYTE	RESULT	UNITS	REPORTING LIMIT
-001	FREY-R1-PART-FHA	Particulate	29.5	MG	0.10
-002	FREY-R1-PRT-FLT 274	Particulate	82.1	MG	0.10
-003	FREY-R2-PART-FHA	Particulate	22.0	MG	0.10
-004	FREY-R2-PRT-FLT 214	Particulate	81.1	MG	0.10
-005	FREY-R3-PART-FHA	Particulate	33.8	MG	0.10
-006	FREY-R3-PRT-FLT 251	Particulate	135	MG	0.10
-007	FREY-BLANK-ACETONE	Particulate	0.20	MG	0.10
-008	FREY-BLANK-FLT 252	Particulate	0.30	MG	0.10

Roy F. Weston, Inc. - Lionville Laboratory
INORGANIC ANALYTICAL DATA PACKAGE FOR
W.S. FREY

DATE RECEIVED: 05/20/92

RFW LOT # :9205L356

CLIENT ID /ANALYSIS	RFW #	MTX	PREP #	COLLECTION	EXTR/PREP	ANALYSIS
FREY-R1-PART-FHA						
PARTICULATE-RESIDUE	001	AI	92LPT019	05/19/92	05/20/92	06/01/92
FREY-R1-PRT-FLT 274						
PARTICULATE-FILTER	002	AI	92LPT019	05/19/92	05/20/92	06/01/92
FREY-R2-PART-FHA						
PARTICULATE-RESIDUE	003	AI	92LPT019	05/19/92	05/20/92	06/01/92
FREY-R2-PRT-FLT 214						
PARTICULATE-FILTER	004	AI	92LPT019	05/19/92	05/20/92	06/01/92
FREY-R3-PART-FHA						
PARTICULATE-RESIDUE	005	AI	92LPT019	05/19/92	05/20/92	06/01/92
FREY-R3-PRT-FLT 251						
PARTICULATE-FILTER	006	AI	92LPT019	05/19/92	05/20/92	06/01/92
FREY-BLANK-ACETONE						
PARTICULATE-RESIDUE	007	AI	92LPT019	05/18/92	05/20/92	06/01/92
FREY-BLANK-FLT 252						
PARTICULATE-FILTER	008	AI	92LPT019	05/18/92	05/20/92	06/01/92



APPENDIX C

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS FOR PARTICULATE TEST (EPA METHOD 5)

Client: W.S. FREY
Test Number: Run 1
Test Location: SCRUBBER STACK

Plant: CLEARBROOK, VA
Test Date: 05-19-92
Test Period: 0854-1024

1. Volume of dry gas sampled at standard conditions (68 deg F, 29.92 in. Hg), dscf.

$$Vm(std) = \frac{17.64 \times Y \times Vm \times \left(Pb + \frac{\text{delt H}}{13.6} \right)}{(Tm + 460)}$$

$$Vm(std) = \frac{17.64 \times 0.9915 \times 35.428 \times \left(30.35 + \frac{1.088}{13.6} \right)}{73.02 + 460} = 35.375$$

Where:

- $Vm(std)$ = Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscf.
- Vm = Volume of gas sample measured by the dry gas meter at meter conditions, dcf.
- Pb = Barometric Pressure, in Hg.
- delt H = Average pressure drop across the orifice meter, in H_2O .
- Tm = Average dry gas meter temperature, deg F.
- Y = Dry gas meter calibration factor.
- 17.64 = Factor that includes ratio of standard temperature (528 deg R) to standard pressure (29.92 in. Hg), deg R/in. Hg.
- 13.6 = Specific gravity of mercury.

2. Volume of water vapor in the gas sample corrected to standard conditions, scf.

$$V_w(\text{std}) = (0.04707 \times V_{wc}) + (0.04715 \times W_{wsg})$$

$$V_w(\text{std}) = (0.04707 \times 224.0) + (0.04715 \times 14.0) = 11.204$$

Where:

$V_w(\text{std})$ = Volume of water vapor in the gas sample corrected to standard conditions, scf.

V_{wc} = Volume of liquid condensed in impingers, ml.

W_{wsg} = Weight of water vapor collected in silica gel, g.

0.04707 = Factor which includes the density of water (0.002201 lb/ml), the molecular weight of water (18.0 lb/lb-mole), the ideal gas constant 21.85 (in. Hg) (ft³/lb-mole)(deg R); absolute temperature at standard conditions (528 deg R), absolute pressure at standard conditions (29.92 in. Hg), ft³/ml.

0.04715 = Factor which includes the molecular weight of water (18.0 lb/lb-mole), the ideal gas constant 21.85 (in. Hg) (ft³/lb-mole)(deg R); absolute temperature at standard conditions (528 deg R), absolute pressure at standard conditions (29.92 in. Hg), and 453.6 g/lb, ft³/g.

3. Moisture content

$$B_{ws} = \frac{V_w(\text{std})}{V_w(\text{std}) + V_m(\text{std})}$$

$$B_{ws} = \frac{11.204}{11.204 + 35.375} = 0.241$$

Where:

B_{ws} = Proportion of water vapor, by volume, in the gas stream, dimensionless.

4. Mole fraction of dry gas.

$$M_d = 1 - B_{ws}$$

$$M_d = 1 - 0.241 = 0.759$$

Where:

$$M_d = \text{Mole fraction of dry gas, dimensionless.}$$

5. Dry molecular weight of gas stream, lb/lb-mole.

$$MW_d = (0.440 \times \% \text{CO}_2) + (0.320 \times \% \text{O}_2) + (0.280 \times (\% \text{N}_2 + \% \text{CO}))$$

$$MW_d = (0.440 \times 20.90) + (0.320 \times 4.80) + (0.280 \times (74.30 + 0.00))$$

$$= 31.54$$

Where:

$$MW_d = \text{Dry molecular weight, lb/lb-mole.}$$

$$\% \text{CO}_2 = \text{Percent carbon dioxide by volume, dry basis.}$$

$$\% \text{O}_2 = \text{Percent oxygen by volume, dry basis.}$$

$$\% \text{N}_2 = \text{Percent nitrogen by volume, dry basis.}$$

$$\% \text{CO} = \text{Percent carbon monoxide by volume, dry basis.}$$

$$0.440 = \text{Molecular weight of carbon dioxide, divided by 100.}$$

$$0.320 = \text{Molecular weight of oxygen, divided by 100.}$$

$$0.280 = \text{Molecular weight of nitrogen or carbon monoxide, divided by 100.}$$

6. Actual molecular weight of gas stream (wet basis), lb/lb-mole.

$$MWs = (MWd \times Md) + (18 \times (1 - Md))$$

$$MWs = (31.54 \times 0.759) + 18(1 - 0.759) = 28.28$$

Where:

$$MWs = \text{Molecular weight of wet gas, lb/lb-mole.}$$

$$18 = \text{Molecular weight of water, lb/lb-mole.}$$

7. Average velocity of gas stream at actual conditions, ft/sec.

$$Vs = 85.49 \times Cp \times ((\Delta p)^{1/2})_{avg} \times \left(\frac{Ts (avg)}{Ps \times MWs} \right)^{1/2}$$

$$Vs = 85.49 \times 0.84 \times 1.520619 \times \left(\frac{608}{30.28 \times 28.28} \right)^{1/2} = 91.99$$

Where:

$$Vs = \text{Average gas stream velocity, ft/sec.}$$

$$85.49 = \text{Pitot tube constant, ft/sec} \times \frac{(\text{lb/lb-mole})(\text{in. Hg})^{1/2}}{(\text{deg R})(\text{in H}_2\text{O})}$$

$$Cp = \text{Pitot tube coefficient, dimensionless.}$$

$$Ts = \text{Absolute gas stream temperature, deg R} = Ts, \text{ deg F} + 460.$$

$$Ps = \text{Absolute gas stack pressure, in. Hg.} = Pb + \frac{P(\text{static})}{13.6}$$

$$\Delta p = \text{Velocity head of stack, in. H}_2\text{O.}$$

8. Average gas stream volumetric flowrate at actual conditions, wacf/hr.

$$Qs(act) = 3,600 \times Vs \times As$$

$$Qs(act) = 3,600 \times 91.99 \times 6.25 = 2069731$$

Where:

$$Qs(act) = \text{Volumetric flowrate of wet stack gas at actual conditions, wacf/hr.}$$

$$As = \text{Cross-sectional area of stack, ft}^2.$$

9. Average gas stream dry volumetric flowrate at standard conditions, dscf/hr.

$$Qs(std) = 17.64 \times Md \times \frac{Ps}{Ts} \times Qs(act)$$

$$Qs(std) = 17.64 \times 0.759 \times \frac{30.28}{608} \times 2069731$$

$$= 1381677$$

Where:

$$Qs(std) = \text{Volumetric flowrate of dry stack gas at standard conditions, dscf/hr.}$$

10. Isokinetic variation calculated from intermediate values, percent.

$$I = \frac{17.327 \times Ts \times Vm(std)}{Vs \times O \times Ps \times Md \times (Dn)^2}$$

$$I = \frac{17.327 \times 608 \times 35.375}{91.99 \times 60 \times 30.28 \times 0.759 \times (0.175)^2} = 95.82$$

Where:

$$I = \text{Percent of isokinetic sampling.}$$

$$O = \text{Total sampling time, minutes.}$$

$$Dn = \text{Diameter of nozzle, inches.}$$

$$17.327 = \text{Factor which includes standard temperature (528 deg R), standard pressure (29.92 in. Hg), the formula for calculating area of circle } D^2/4, \text{ conversion of square feet to square inches (144), conversion of seconds to minutes (60), and conversion to percent (100),}$$

$$\frac{(\text{in. Hg})(\text{in}^2)(\text{min})}{(\text{deg R})(\text{ft}^2)(\text{sec})}$$

11. Particulate Concentration, gr/dscf.

$$\begin{aligned} C1 &= 15.432 \times \frac{Mt}{Vm(std)} \\ C1 &= 15.432 \times \frac{0.11110}{35.375} \\ &= 0.0485 \end{aligned}$$

Where:

C1 = Particulate concentration, lb/dscf.

Mt = Total weight of particulate caught by train
minus the particulate caught by the blank train, gms.

15.432 = Conversion factor from gms to gr.

12. Particulate mass emission rate, lbs/hr.

$$\begin{aligned} PMRt &= 0.008571 \times C1 \times Qs(std) \\ PMRt &= 0.008571 \times 0.04847 \times 23028 \\ &= 9.57 \end{aligned}$$

Where:

PMRt = Particulate mass emission rate, lbs/hr.

0.008571 = Conversion factor relating grains to pounds (7,000)
and minutes to hours.

**SAMPLE CALCULATIONS FOR
BIAS CORRECTION AND MASS EMISSION RATE OF
CARBON MONOXIDE**

Client: W.S. FREY COMPANY
Test Run No.: RUN 1
Test Location: LIME KILN SCRUBBER STACK

Plant: CLEAR BROOK, VA
Test Date: 05-19-92
Test Period: 0845-1024

1. Bias corrected value of carbon monoxide.

$$C(\text{corr}) = \frac{\text{AVG} - \text{ZERO}}{\text{BIAS} - \text{ZERO}} \times \text{SPAN GAS}$$

$$C(\text{corr}) = \frac{81.70 - 4.70}{506.00 - 4.70} \times 504.0$$

$$C(\text{corr}) = 85.266$$

Where:

AVG = Average CO concentration for the test run as reported by the analyzer.

ZERO = The average of pre and post test zero bias check of the complete system with "zero" air.

BIAS = The average of pre and post test bias check of the complete system with the calibration span gas.

SPAN GAS = The calibration gas closest to the gas stream concentration, which was used for a BIAS check.

C(corr) = Bias corrected value of carbon monoxide.

2. Carbon monoxide mass emission rate, lbs/hr.

$$\text{PMR}(\text{CO}) = \frac{C(\text{corr}) \times Q_s(\text{std}) \times 28.01 \times 60 \text{ min/hr}}{385.35 \times 10^6}$$

$$\text{PMR}(\text{CO}) = \frac{85 \times 23000.00 \times 28.01 \times 60 \text{ min/hr}}{385.35 \times 10^6}$$

$$\text{PMR}(\text{CO}) = 8.55$$

Where:

PMR(CO) = Carbon monoxide mass emission rate, lbs/hr.

Qs(std) = Avg. volumetric gas stream flow rate at std. conditions, dscf/min.

28.01 = Molecular weight of CO.

385.35x10⁶ = Conversion factor from ppm to lbs.



APPENDIX D
EQUIPMENT CALIBRATION RECORDS

CEM CALIBRATION DATA SHEET

RUN NO. ONE SITE: WS FRYE LIME KILN STACK DATE: 5/19/92 OPERATOR: L. Si

START TIME: 0856 INTERNAL SYSTEM BIAS

STOP TIME: 1000 CALIBRATION PRE-TEST POST-TEST

TIME 0815 0845 1015
 ANAL. % ANAL. % ANAL. %
 KNOWN RESP. DIFF. RESP. DIFF. RESP. DIFF. DRIFT RESP.

CO ppm range	ZERO	0.0	-4.7		-4.7		-4.7			
	LOW	251	265							
	MID	504	509		507		505			
	HIGH	803	793							

CO2 % range 20	ZERO	0.0								
	LOW									
	MID									
	HIGH									

O2 % range 25	ZERO	0.0								
	LOW									
	MID									
	HIGH									

NOx ppm range	ZERO	0.0	0		0		0.1			
	LOW	84.43	84.6							
	MID	1258	1256		1256		1200			
	HIGH	2062	2048							

THC ppm range	ZERO	0.0								
	LOW									
	MID									
	HIGH									

SO2 ppm range	ZERO	0.0	1.4		1.2		3.5			
	LOW	202	201							
	MID	391	395		388		393			
	HIGH	777	778							

range	ZERO	0.0								
	LOW									
	MID									
	HIGH									

CEM CALIBRATION DATA SHEET

RUN NO. TWO SITE: WS FREE time KNW STAY DATE: 5/19/92 OPERATOR: SI
 START TIME: 1156 INTERNAL SYSTEM BIAS
 STOP TIME: _____ CALIBRATION PRE-TEST POST-TEST
 TIME 1050 1120 1310

		ANAL.	%	KNOWN	RESP.	DIFF.	ANAL.	%	PRE-TEST	RESP.	DIFF.	ANAL.	%	POST-TEST	RESP.	DIFF.	%	AVG
CO	ZERO	0.0	-4.7				-4.7					-4.8						
ppm	LOW	251	266															
range	MID	504	504				500					508						
	HIGH	803	796															

CO2	ZERO	0.0																
%	LOW																	
range	MID																	
20	HIGH																	

O2	ZERO	0.0																
%	LOW																	
range	MID																	
25	HIGH																	

NOx	ZERO	0.0	0.3				0.4					2.0						
ppm	LOW	84.43	84															
range	MID	1258	1252				1268					1263						
	HIGH	2062	2068															

THC	ZERO	0.0																
ppm	LOW																	
range	MID																	
	HIGH																	

SO2	ZERO	0.0	0.5				1.5					3.5						
ppm	LOW	202	201															
range	MID	391	393				393					389						
	HIGH	777	778				769					765						

	ZERO	0.0																
	LOW																	
	MID																	
range	HIGH																	

CEM CALIBRATION DATA SHEET

RUN NO. THREE SITE: WS FREY LIME KILN STACK DATE: 5/19/92 OPERATOR: SI

START TIME: _____ INTERNAL _____ SYSTEM BIAS _____
STOP TIME: _____ CALIBRATION _____ PRE-TEST _____ POST-TEST _____

TIME 1350 1500 1630
ANAL. % ANAL. % ANAL. %
KNOWN RESP. DIFF. RESP. DIFF. RESP. DIFF. DRIFT RESP.

CO ppm range	ZERO	0.0	-5.0		-5.0		-5.1			
	LOW	251	264							
	MID	504	504		497		499			
	HIGH	803	792							

CO2 % range 20	ZERO	0.0								
	LOW									
	MID									
	HIGH									

O2 % range 25	ZERO	0.0								
	LOW									
	MID									
	HIGH									

NOx ppm range	ZERO	0.0	1.2		4.3		6.0			
	LOW	84.43	87							
	MID	1258	1260		1235		1220			
	HIGH	2062	2060							

THC ppm range	ZERO	0.0								
	LOW									
	MID									
	HIGH									

SO2 ppm range	ZERO	0.0	0.3		0.3		6.5			
	LOW	202	198							
	MID	391	392							
	HIGH	777	775		765		758			

range	ZERO	0.0								
	LOW									
	MID									
	HIGH									



POSTTEST DRY GAS METER CALIBRATION DATA FORM

Calibrator PM

Date 5/21/92 Meter box number 8 Plant WS Frey Pretest Y .9946

Barometric pressure, $P_b =$ 29.74 in. Hg Dry gas meter number 6842672

Setting	Gas Volume		Temperature			Vacuum Setting, in. Hg.	Time (e), min.	Y ₁	Y ₁ = $\frac{V_w P_b (t_d + 460)}{V_d \left(P_b + \frac{\Delta H}{13.6} \right) (t_w + 460)}$
	Wet test meter	Dry gas meter	Wet test meter	Dry gas meter					
				Inlet (t _d) °F	Outlet (t _d) °F				
Orifice Manometer	(V _w) ft ³	(V _d) ft ³	(t _w) °F						
1.18	10	361.559	71.5	83.8688	82	12	15.7	1.061	
		351.511							
1.18	10	371.680	71	85.8889	83.5	12	15.7	1.008	
		361.559							
1.18	10	381.862	71	87.8990	84.5	12	15.8	1.004	
		371.680							
									Y = 1.007

If there is only one thermometer on the dry gas meter, record the temperature under t_d.

V_w = Gas volume passing through the wet test meter, ft³.

V_d = Gas volume passing through the dry gas meter, ft³.

t_w = Temperature of the gas in the wet test meter, °F.

t_{d1} = Temperature of the inlet gas of the dry gas meter, °F.

t_{d0} = Temperature of the outlet gas of the dry gas meter, °F.

t_d = Average temperature of the gas in the dry gas meter, $\frac{t_{d1} + t_{d0}}{2}$.

ΔH = Pressure differential across orifice, in. H₂O.

Y_1 = Ratio of accuracy of wet test meter to dry gas meter for each run.

Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest Y ± 0.05Y.

P_b = Barometric pressure, in. Hg.

e = Time of calibration run, min.

Long calibration required? Yes No

$$\Delta H @ t_d = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) e}{V_d} \right]^2$$



STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

DATE 5/21/92
AMBIENT TEMPERATURE 70
CALIBRATION PM

POTENTIOMETER NUMBER 2010 #8
BAROMETRIC PRESSURE 29.74
REFERENCE: THERMOCOUPLE SIMULATOR
(ACCURACY $\pm 1^{\circ}\text{F}$)

REFERENCE TEMPERATURE		TEMPERATURE READING FROM THERMOCOUPLE CHANNEL INPUT NUMBER					AVERAGE TEMPERATURE READING $^{\circ}$	TEMPERATURE DIFFERENCE $^{\circ}$ (%)
$^{\circ}\text{C}$	$^{\circ}\text{F}$	1	2	3	4	5		
0	32	33	33	33	33	33	33	1° - 1.20%
100	212	213	213	213	213	213	213	1° - 1.14%
-500	932	931	931	931	931	931	931	1° - 1.07%
1000	1832	1825	1825	1825	1825	1825	1825	7° - 1.30%

COMMENTS

⊙ AVERAGE TEMPERATURE READING = MEAN OF THE TEMPERATURE READINGS FOR THE THERMOCOUPLE CHANNELS

⊙ THE CHANNEL READINGS MUST AGREE WITHIN $\pm 5^{\circ}\text{F}$ OR 3°C

ACCEPTABLE TEMPERATURE DIFFERENCE $\leq 1.5 =$

$$\left(\frac{(\text{REF TEMP } ^{\circ}\text{F} + 460) - (\text{TEST TEMP } ^{\circ}\text{F} + 460)}{(\text{REF TEMP } ^{\circ}\text{F} + 460)} \right) \times 100$$

POTCAL-67

NOZZLE CALIBRATION DATA FORM

Date 5/18/92

Calibrated by Jack Mills

[illegible]

Where:

¹ $D_{1,2,3}$ = Three different nozzle diameters, inches; each diameter must be measured to nearest 0.001 in.

² ΔD = Maximum difference between any two diameters, inches. ΔD must be ≤ 0.004 in.

³ D_{noz} = Nozzle diameter = average of D_1 , D_2 , and D_3 .

PITOT TUBE IDENTIFICATION NUMBER: P - 4

TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ASSEMBLY LEVEL? ✓ (YES) _____ (NO)

PITOT TUBE OPENINGS DAMAGED? _____ (YES-EXPLAIN BELOW) ✓ (NO)

$\alpha_1 =$ 4 $^{\circ}$ ($<10^{\circ}$)

$\alpha_2 =$ 2 $^{\circ}$ ($<10^{\circ}$)

$\beta_1 =$ 3 $^{\circ}$ ($<5^{\circ}$)

$\beta_2 =$ 4 $^{\circ}$ ($<5^{\circ}$)

$\gamma =$ 4 $^{\circ}$

$\theta =$ 1 $^{\circ}$

$A =$.94 cm (in.)

$z = A \sin \gamma =$.066 cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta =$.016 cm (in.); <0.32 cm ($<1/8$ in.),

$P_a =$.47 in cm (in.)

$P_b =$.47 in cm (in.)

$D_t =$.38 in cm (in.)

COMMENTS _____

CALIBRATION REQUIRED? _____ (YES) ✓ (NO)

INSPECTOR Alfred R. Barber DATE 4-22-92



APPENDIX E
PROCESS OPERATIONS DATA

TABLE E-1**LIME KILN PROCESS DATA¹
W.S. FREY COMPANY - CLEAR BROOK, VIRGINIA**

Run No.	One	Two	Three
Date	5-19-92	5-19-92	5-19-92
Time	0854-1024	1154-1329	1455-1624
Coal Feed Rate, tons/hr	4.3	4.4	4.2
Lime Discharge Rate, tons/hr	9.0	9.4	9.2
Limestone Feed Rate, tons/hr	18.0	18.9	18.4
Kiln Feed End Temperature, °F	1315.1	1299.9	1332.3
Kiln Firing End Temperature, °F	2369.4	2426.2	2347.3
Kiln Speed, revolutions/hr	38.0	39.5	38.5

¹ Provided by W.S. Frey Company. These are average values for the stated time period.



APPENDIX F
CALIBRATION GAS CERTIFICATES



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL RECERTIFICATION ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order :
5918

Shipped to:
ROY F WESTON
1280 KING RD
WEST CHESTER PA 19380
ATTN: LARRY SI
KEYSTONE BLDG
Project No 38505

Certified per E.P.A. Protocol # 1 Procedure #G1 Section # 3.0.4
Certified accuracy +/- 1 % NIST Traceable

Cylinder number	AAL 9336	Cylinder pressure	Date of assay:	6/9/92
		500 psig.		
Component		Certified concentration	Expiration date:	12/9/93
CARBON MONOXIDE		803 ppm		
NITROGEN		Balance		

Standard		Analyzer	
Type	CRM 1681b	Make	: HORIBA
Concentration	968 ppm	Model	: CFA-310A
Cylinder #	CLM000330	Serial number	: 474091
		Analytical principle	: NDIR
		Date of calibration	: 5/7/92

Raw data units:	VOLTS	:	:	Concentration	:
		:	:	of Customer	:
		:	:	Cylinder	:
First analysis	9/18/90	:	:		:
		:	:		:
Z1=0.0000	R1=0.0000000	T1=0.00000000:	:	803	ppm
R2=0.0000000	Z2=0.0000	T2=0.00000000:	:	803	ppm
Z3=0.0000	T3=0.0000000	R3=0.00000000:	:	803	ppm
		:	:		:
		:	:		:
Second analysis:	6/9/92	:	:		:
		:	:		:
Z1=0.0000	R1=0.86850	T1=0.72760	:	805	ppm
R2=0.87230	Z2=0.0000	T2=0.73040	:	804	ppm
Z3=0.0000	T3=0.72980	R3=0.87370	:	802	ppm

Analys

Approved by

Mark S. Sirinides/Ted Heeme



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL RECERTIFICATION ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order :
5918

Shipped to:
ROY F WESTON
1280 KING RD
WEST CHESTER PA 19380
ATTN: LARRY SI
KEYSTONE BLDG
Project No 38505

Certified per E.P.A. Protocol # 1 Procedure #G1 Section # 3.0.4
Certified accuracy +/- 1 X NIST Traceable

Cylinder number	AAL 14003	Cylinder pressure	Date of assay:	6/9/92
		600 psig.		
Component		Certified concentration	Expiration date:	12/9/93
CARBON MONOXIDE		504 ppm		
NITROGEN		Balance		

Standard		Analyzer	
Type	CRM 1681b	Make	: HORIBA
Concentration	968 ppm	Model	: CFA-310A
Cylinder #	CLM030330	Serial number	: 474091
		Analytical principle	: NDIR
		Date of calibration	: 5/7/92

Raw data units:	VOLTS	:	:	Concentration	:
		:	:	of Customer	:
		:	:	Cylinder	:
First analysis	9/18/90	:	:		:
		:	:		:
Z1=0.0000 R1=0.00000000T1=0.00000000:		:	:	505	ppm
R2=0.00000000Z2=0.0000 T2=0.00000000:		:	:	505	ppm
Z3=0.0000 T3=0.00000000R3=0.00000000:		:	:	505	ppm
		:	:		:
Second analysis:	6/9/92	:	:		:
		:	:		:
Z1=0.0000 R1=0.86510 T1=0.46230	:	:	:	506	ppm
R2=0.87080 Z2=0.0000 T2=0.46200	:	:	:	502	ppm
Z3=0.0000 T3=0.46180 R3=0.86770	:	:	:	503	ppm

Analyst

Christine Rush

Approved by

Mark S. Sirinides
Mark S. Sirinides/Tec Neeme



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL RECERTIFICATION ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order :
5918

Shipped to:
ROY F WESTON
1280 KING RD
WEST CHESTER PA 19380
ATTN: LARRY SI
KEYSTONE BLDG
Project No 38505

Certified per E.P.A. Protocol # 1 Procedure #G1 Section # 3.0.4
Certified accuracy +/- 1 % NIST Traceable

Cylinder number	AAL 934	Cylinder pressure	Date of assay:	6/8/92
		700 psig.		
Component		Certified concentration	Expiration date:	12/8/93
CARBON MONOXIDE		251 ppm		
NITROGEN		Balance		

Standard
Type CRM 2636
Concentration 243.4 ppm
Cylinder # ALM013375

Analyzer
Make : HORIBA
Model : CFA-310A
Serial number : 474091
Analytical principle : NDIR
Date of calibration : 5/6/92

Raw data units:	VOLTS	:	:	Concentration	:
		:	:	of Customer	:
		:	:	Cylinder	:
First analysis	9/19/90	:	:		:
		:	:		:
Z1=0.0000	R1=0.0000000	T1=0.00000000:	:	252	ppm
R2=0.0000000	Z2=0.0000	T2=0.00000000:	:	252	ppm
Z3=0.0000	T3=0.0000000	R3=0.00000000:	:	252	ppm
		:	:		:
		:	:		:
Second analysis:	6/8/92	:	:		:
		:	:		:
Z1=0.0000	R1=0.61240	T1=0.63320	:	252	ppm
R2=0.61600	Z2=0.0000	T2=0.63110	:	249	ppm
Z3=0.0000	T3=0.63300	R3=0.61530	:	250	ppm

Analyst

Christine Rush

Approved by

Mark S. Sirinides
Mark S. Sirinides/Ted Heeme



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL RECERTIFICATION ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order :
5918

Shipped to:
ROY F WESTON
1280 KING RD
WEST CHESTER PA 19380
ATTN: LARRY SI
KEYSTONE BLDG
Project No 38505

Certified per E.P.A. Protocol # 1 Procedure #G1 Section # 3.0.4
Certified accuracy +/- 1 % NIST Traceable

Cylinder number	ALM001953	Cylinder pressure	Date of assay:	6/4/92
		200 psig.		
Component		Certified concentration	Expiration date:	12/4/92
SULFUR DIOXIDE		777 ppm		
AIR		Balance		

Standard		Analyzer	
Type	CRM 1662	Make	: HORIBA
Concentration	1006 ppm	Model	: CMA-321A
Cylinder #	ALM007670	Serial number	: 564-371-02
		Analytical principle	: NDIR
		Date of calibration	: 5/13/92

Raw data units:	VOLTS	:	:	Concentration	:
		:	:	of Customer	:
		:	:	Cylinder	:
First analysis	9/21/90	:	:		:
		:	:		:
Z1=0.0000	R1=0.0000000	T1=0.00000000:	:	773	ppm
R2=0.0000000	Z2=0.0000	T2=0.00000000:	:	773	ppm
Z3=0.0000	T3=0.0000000	R3=0.00000000:	:	773	ppm
		:	:		:
		:	:		:
Second analysis:	6/4/92	:	:		:
		:	:		:
Z1=0.0000	R1=1.0037	T1=0.76740	:	778	ppm
R2=1.0005	Z2=0.0000	T2=0.77110	:	784	ppm
Z3=0.0000	T3=0.77270	R3=1.0049	:	782	ppm

Analyst:

Christine Rush

Approved by

Mark S. Sirinides
Mark S. Sirinides/Ted Heeme



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL RECERTIFICATION ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order :
5918

Shipped to:
ROY F WESTON
1280 KING RD
WEST CHESTER PA 19380
ATTN: LARRY SI
KEYSTONE BLDG
Project No 38505

Certified per E.P.A. Protocol # 1 Procedure #G1
Certified accuracy +/- 1 % NIST Traceable

Section # 3.0.4

Cylinder number	AL21470	Cylinder pressure	Date of assay:	6/4/92
Component		1300 psig.		
SULFUR DIOXIDE		Certified concentration	Expiration date:	12/4/92
AIR		391 ppm		
		Balance		

Standard		Analyzer	
Type	CRM 1661	Make	: HORIBA
Concentration	454 ppm	Model	: CMA-321A
Cylinder #	ALM005781	Serial number	: 564-371-02
		Analytical principle	: NDIR
		Date of calibration	: 5/13/92

Raw data units:	VOLTS	:	: Concentration	:
		:	: of Customer	:
First analysis	10/29/91	:	: Cylinder	:
		:	:	:
Z1=0.0000 R1=0.00000000T1=0.00000000:		:	: 393	ppm
R2=0.00000000Z2=0.0000 T2=0.00000000:		:	: 393	ppm
Z3=0.0000 T3=0.00000000R3=0.00000000:		:	: 393	ppm
		:	:	:
Second analysis:	6/4/92	:	:	:
		:	:	:
Z1=0.0000 R1=0.41400 T1=0.35130		:	: 388	ppm
R2=0.41580 Z2=0.0000 T2=0.35500		:	: 390	ppm
Z3=0.0000 T3=0.35660 R3=0.41700		:	: 391	ppm

Analyst

Christine Paul

Approved by

Mark S. Sirinides
Mark S. Sirinides/Ted Neeme



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL RECERTIFICATION ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order :
5918

Shipped to:
ROY F WESTON
1280 KING RD
WEST CHESTER PA 19380
ATTN: LARRY SI
KEYSTONE BLDG
Project No 38505

Certified per E.P.A. Protocol # 1 Procedure #G1
Certified accuracy +/- 1 % NIST Traceable

Section # 3.0.4

Cylinder number	AL5352	Cylinder pressure	Date of assay:	6/4/92
		1500 psig.		
Component		Certified concentration	Expiration date:	12/4/92
SULFUR DIOXIDE		202 ppm		
AIR		Balance		

Standard		Analyzer	
Type	CRM 1661	Make	: HORIBA
Concentration	454 ppm	Model	: CMA-321A
Cylinder #	ALM005781	Serial number	: 564-371-02
		Analytical principle	: NDIR
		Date of calibration	: 5/13/92

Raw data units:	VOLTS	:	: Concentration	:
		:	: of Customer	:
First analysis	10/29/91	:	: Cylinder	:
		:	:	:
Z1=0.0000 R1=0.00000000T1=0.00000000:		:	: 201	ppm
R2=0.00000000Z2=0.0000 T2=0.00000000:		:	: 201	ppm
Z3=0.0000 T3=0.00000000R3=0.00000000:		:	: 201	ppm
		:	:	:
Second analysis:	6/4/92	:	:	:
		:	:	:
Z1=0.0000 R1=0.047500 T1=0.038800 :		:	: 202	ppm
R2=0.047500 Z2=0.0000 T2=0.038800 :		:	: 202	ppm
Z3=0.0000 T3=0.038800 R3=0.047500 :		:	: 202	ppm

Analyst

Brian Reffen

Approved by

Mark S. Sirinides/Ted Heeme

F-6



Scott Specialty Gases, Inc.

PLUMSTEADVILLE, PA 18949

PHONE: 215-766-8881

FAX: 215-766-0320

ROY F WESTON

ATTN: PETER VIRAG

Date Shipped 2-26-91

Our Project No: 26099

Your P.O. No: 25-13048

Page 3 of 3

CERTIFICATE OF ANALYSIS -- EPA PROTOCOL GASES*

(Concentrations are in mole % or ppm)

Cylinder Number 2L - 1042 CP = 2000 psig Analysis Dates: First 2-15-91 Last 2-26-91
Certified Accuracy ± 1 % NBS Traceable

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND
NITRIC OXIDE	2052 ppm	8-26-92	CHEMILUMINESCENCE	2631	2056 ppm 2065 ppm
NOX	2062 ppm				2029 ppm 2049 ppm
OXYGEN FREE NITROGEN BALANCE					2056 ppm 2053 ppm

Cylinder Number _____ Certified Accuracy _____ % NBS Traceable Analysis Dates: First _____ Last _____

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No: 1 Procedure G1

Analyst Ed Leane Approved By Mark S. Sirinides
The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBLEND® ■ CALIBRATION & SPECIALTY GAS MIXTURES
PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA / HOUSTON, TEXAS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO



Scott Specialty Gases, Inc.

PLUMSTEADVILLE, PA 18949

PHONE: 215-768-8861

FAX: 215-768-0320

ROY F WESTON

Date Shipped 2-26-91

Our Project No: 26099

Your P.O. No: 25-13048

Page 2 of 3

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES*

(Concentrations are in mole % or ppm)

Cylinder Number BAL - 843 Certified Accuracy ± 1 % NBS Traceable Analysis Dates: First 2-15-91 Last 2-26-91
CP = 2000 psig

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND
NITRIC OXIDE	1258 ppm	8-26-92	CHEMILUMINESCENCE	2631	1251 ppm 1254 ppm
NOX	1258 ppm				1281 ppm 1250 ppm
OXYGEN FREE NITROGEN BALANCE					1253 ppm 1255 ppm

100

Cylinder Number _____ Certified Accuracy _____ % NBS Traceable Analysis Dates: First _____ Last _____

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No: 1 Procedure G1

Analyst Ed Leone Approved By Mark S. Sirinides

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBLEND® ■ CALIBRATION & SPECIALTY GAS MIXTURES
PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA / HOUSTON, TEXAS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO

PLUMSTEADVILLE, PA 18949 PHONE: (215) 766-8861 TWX: 510-665-9344

ROY F WESTON

Date Shipped: 8-25-89
Our Project No.: 12641
Your P.O. No.: 54026-B-0017
Page 2 of 2

RECERTIFICATION ANALYSIS - EPA PROTOCOL GASES*
(Concentrations are in mole % or ppm)

Cylinder Number AAL 17391 cylinder pressure = 1300 psig
Certified Accuracy ± 1 % NBS Traceable Analysis Dates: Last 8-15-89 New 8-23-89

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS LAST	REPLICATE CONCENTRATIONS NEW
NITRIC OXIDE	84.8 ppm	2-23-91	Chemiluminescence	1685	85.10 ppm	84.86 ppm
NOx	85.4 ppm				85.00 ppm	84.73 ppm
					84.83 ppm	84.44 ppm
NITROGEN	BAL					

Cylinder Number _____ Certified Accuracy _____ % NBS Traceable Analysis Dates: Last _____ New _____

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS LAST	REPLICATE CONCENTRATIONS NEW

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No.: 1 Procedure G1
Analyst JENNIFER MEASE Approved By Mark Sirinides
The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBLEND® ■ CALIBRATION & SPECIALTY GAS MIXTURES
PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA / HOUSTON TEXAS



APPENDIX G
CHAIN OF CUSTODY

Custody Transfer Record/Lab Work Request

RFW 21-21-001/A-7/91



APPENDIX H

WESTON PROJECT PARTICIPANTS



PROJECT PARTICIPANTS

The following WESTON employees participated in this project:

Richard Ruch
Project Director

ECONENVIRONOMICS Division

Uttam Trivedi, P.E.
Project Manager

ECONENVIRONOMICS Division

Kam Lo (Larry) Si
Associate Project Engineer

ECONENVIRONOMICS Division

Jack Mills
Project Scientist

ECONENVIRONOMICS Division

Andre Williams
Technician

ECONENVIRONOMICS Division

Jack Tuschall, Ph.D.
Laboratory Manager

WESTON Analytics

