

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.18
Reference:	9
Title:	<i>Particulate Emission Tests On Batt Curing Oven For U. S. Gypsum, Birmingham, Alabama On October 31-November 1, 1977, Guardian Systems, Inc., Birmingham, AL, Undated.</i>

PM data for
curing op only. No
process description
but process rate as
it batt cured is
included B.

Particulate Emission Tests

On

Batt Curing Oven

For

U.S. Gypsum

Birmingham, Alabama

October 31, - November 1, 1977

Summit

28017

TABLE OF CONTENTS

Chapter		Page
I.	Introduction	1
II.	Sampling and Analytical Procedures	2
III.	Summary of Test Results	7
IV.	Operational Data	9
V.	Test Results	16
	Nomenclature	17
	Calculations	19
	Clinker Cooler Run Sheets	21
VI.	Calibrations	30
	Filter Information	31
	Probe Heater Calibration	32
	Meter Calibration	33
	Orifice Calibration	34
	Box Thermometer Calibration	37
	Impinger Calibration	38
	Stack Temperature Calibration	39
	Pitot Calibration	40
Table:		
1	Summary of Test Results	8
Figures		
1	Stack Breeching and Sample Point Location	5
2	Particulate Sampling Train	6

I. INTRODUCTION

On October 31, 1977 a pretest discussion of sampling procedures was conducted with Mr. Jim Carroll of Jefferson County Department of Health, Air Pollution Control Program. These procedures were those outlined in the new revision to Reference Method 1-8, Standards of Performance for New Stationary Sources 40CFR60.

On October 31, 1977 the first test (Test #1) was completed on the batt curing oven stack. This test was disallowed by the Jefferson County Health Department due to a post test pitot leak check failure and subsequently is not included in this report.

On November 1, 1977 four (4) tests were conducted on the curing oven. The first test of this series (Test #2) was discontinued at midpoint due to a malfunction on the production line. It is not included in this report. The final three (3) tests (Tests #3, 4, 5) comprise this report.

The control device for the curing oven is a Veltran Electrostatic Precipitator exhausting through a two foot diameter stack.

Operational data for the curing oven was collected by U.S. Gypsum personnel. Mr. Lee Crawford of U.S. Gypsum was responsible for coordinating production line operation with the testing schedule. Mr. Jim Carroll of the Jefferson County Department of Health, Air Pollution Control Program observed the tests. Mr. David Daws and Mr. Paul Eddins of Guardian Systems performed the tests.

II. SAMPLING AND ANALYTICAL PROCEDURES

General

Preliminary measurements were made of the stack to determine the number of sampling points according to Method 1. The batt curing oven was sampled at 8 points on two (2) diameters for a total of 16 points. The Stack and Sample Point Locations for the stack can be found in Figure 1.

Stack temperature, stack pressure, the range of velocity heads, moisture content, and the stack gas dry molecular weight were determined to correctly set the nomographs for isokinetic sampling. The meter box was leaked checked from the pump to the orifice meter as outlined in Method 5. The equipment used in this test was manufactured by Research Appliance Corporation and was properly calibrated before and after the tests. (See calibrations.)

Sampling Techniques

The particulate determinations were made by utilizing the sampling train in Figure 2. Initial and final leak checks of the sampling systems and of the pitot lines were performed as outlined in Method 5 and these were recorded on the individual data sheets.

The gases were drawn through a stainless steel nozzle attached to a heated stainless steel lined probe. The probe heater was maintained at the proper setting to obtain an exit temperature of $248 \pm 25^{\circ}\text{F}$. (See calibrations). The gases then passed through a glass cyclone for removing particulate matter approximately 10 microns and greater in size, then through a glass fiber filter (Gelman, Class A) of 0.3 microns retention to remove

any remaining particulate matter. The cyclone and filter were maintained at temperature of $248 \pm 25^{\circ}\text{F}$. The sample box temperature were recorded at each point on the data sheet.

The gases then passed through four (4) Greenburg-Smith impingers. The first and second impingers contained 150 milliliters of distilled water each, while the third was empty and the fourth contained approximately 220 grams of indicating silica gel. These impingers were placed in an ice bath during the tests to maintain a maximum exit temperature from the last impinger of 68°F . This temperature is also recorded on the data sheets. The clean and cool gases then entered the meter box where the gas flow and temperature were measured. (See data sheets.)

Gas analysis for CO_2 and NO_2 were determined for each run by using Fyrite gas analyzers. Particulate catches were placed in sealed petri dishes. The acetone washes of the nozzle, probe and cyclone were combined and placed in sealed containers. These containers were transported to the laboratory for analysis.

Analysis



The filters (Gelman, Class A, without organic binder, minimum 99.9% retention for particles of 0.3 micrometer as determined by DOP tests) prepared for the field test were first desiccated at $68 \pm 10^{\circ}\text{F}$ at ambient pressure for 24 hours and weighed at intervals of at least 6 hours to a constant weight (less than 0.5 milligrams change from previous reading.) Upon return to the laboratory the filters were again subjected to the same procedures as outlined above. The weights are recorded in a Bound Laboratory Book and were transferred to the laboratory report sheets in this report. During each weighing the filter

was not exposed to laboratory atmosphere for more than 2 minutes and the relative humidity of the laboratory was less than 50%.

The acetone washings for each run and the blank were to dryness in tared glass beakers at ambient pressure and temperature. They were then desiccated for 24 hours and weighed to constant weight.


The moisture content was determined for each run by measuring the amount of water collected in the impingers and the increase in weight of the silica gel. These weights were combined to give the total amount of water collected.

BATT CURING OVEN



POINT *	DISTANCE FROM WALL (IN.)
1.	1.0
2.	2.5
3.	4.7
4.	7.8
5.	16.2
6.	19.3
7	21.5
8.	23.0

FIGURE 1



Particulate Sampling Train

Figure 2

III. SUMMARY OF TEST RESULTS

11/1/77

The production rates (tons/hr) for the curing oven were based on production run times and weights supplied by U.S. Gypsum. The emission rates were computed according to the equation found in Section 6.4.1 of The Jefferson County Health Department, Air Pollution Control Rules and Regulations as follows:

$$E = 3.59 P^{0.62}$$

$$P \leq 30 \text{ tons/hr}$$

Run Number	Allowable Emission (lb/hr)	Emissions
3	5.52 P 2.0	0.93
4	4.46 1.4	1.71
5	6.78 2.8	1.34

TABLE I
Summary of Test Results

Run Number	1	2	3
Date	11-1-77	11-1-77	11-1-77
Time	11:00-12:20	1:31-2:41	5:00-6:15
Temperature, °F	175	185	189
Moisture, %	4.95	4.87	5.07
Stack Velocity, f/s	59.57	60.60	60.03
Volumetric Flow, ACFM	11,228	11,423	11,315
Volumetric Flow, DSCFM	8,942	8,943	8,779
Concentration, Grains/ACF	0.0097	0.0175	0.0139
Concentration, Grains/DSCF	0.0122	0.0223	0.0179
Particulate Mass Rate, lb/hr	0.93	1.71	1.34
Process Weight, T/hr	2.00	1.42	2.79
Allowables, lb/hr	5.52	4.46	6.78

8800 DSCFM
0.029 DSCFM
1.52 ppb

N23
1.33 lb

Avg

$$\frac{.029 \text{ gr}}{\text{DSCF}} \times \frac{8800 \text{ DSCF}}{\text{min}} \times \frac{1.0 \text{ hr}}{60 \text{ min}} \times \frac{1 \text{ lb}}{7000} = 1.52 \text{ ppb}$$

IV. OPERATIONAL DATA

1.6
12?

INDUSTRIAL FELT PRODUCTS

DAILY REPORT

B'HAM WOOL PLANT

10/11/77

LEADER: *W*

SHIFT: 7-3 DATE: 10-11-77

	1	2	3	4	5
CUSTOMER					
CODE & ITEMS	FELT	54			
FELT SIZE	4 X 24 X 48	2 X 16 X 48			
DENSITY & TYPE	4# 4"	2.5# 2"			
BLANKET THICKNESS	4"	4" 1/2"			
PKGS. ORDERED & PCS. PER PKG	→ 4 PCS	8 PCS			
TYPE OF PACKAGE	cut	1525-1			
WEIGHT TOLERANCE					
FEEDER SETTING	7%	7%			
CUT OFF TIMER SETTING					
CHANGE TIME- START	9:00	1:30			
ROD. TIME-START	9:00	1:30			
PROD. TIME-STOP	12:45	3:00			
DST TIME (REASON ON BACK)	10 min	25 min			
NET PRODUCT TIME	3 hr.	1 hr. 5 min			
LINEAL FT. READING	1445	782			
ACTUAL LIN. FT.					
D. GROSS PCS.	956	960			
PKGS. & PCS. PER PKG.	224 - 110 = 5	120 - 8 PCS			
D. SALABLE PCS.	825	940			
PCS. REJECTS	60	20			
REJECTS	620	270			
WIDTH OF TRIM	4"	4"			
PRODUCTION LABOR	10	10			
REMARKS:					

134-1

•

SCALE

35-44281

142

June 25 /

1000 1015

Take Do. & the Birds

10-11-17

1-42-130

2-4 months

shot drag

کے پاس سے گزرتا ہے

Лен. ст. 2.

235. 300

PRODUCTION REPORT -

NO.

SIGNED

DATE

SHIFT

LINE NO.	#1	#1	#1									
REF. DES.	1.1	1.1	1.1									
ORDER NO.	1.8477	2.2867	2.2867									
QTY	1.2532	1.451575	5.35									
PACKAGE	1.1	1.1	1.1									
DE	4.124148	2.116448	2.116448									
TYPE	1" = 0.1	2" 5.1	2" 5.1									
TRAC NO.	UNITS	WEIGHT	UNITS	WEIGHT	UNITS	WEIGHT	UNITS	WEIGHT	UNITS	WEIGHT	UNITS	WEIGHT
1	10	510	20	460	30	530						
2	10	530	20	450	30	520						
3	10	480	20	480	30	540						
4	10	550	20	530	30	530						
5	10	530	30	520	30	510						
6	10	550	20	520	30	500						
7	10	540	5	110								
8	10	510										
9	10	560										
10	10	510										
11	10	450										
12	10	490										
13	10	570										
14	10	530										
15	10	630										
16	10	590										
17	10	540										
18	10	570										
19	10	600										
20	10	570										
21	10	530										
22	10	510										
23	5	110										
24												
25												
26												
27												
28												
TOTAL	11980	125	3070	120	3130							

INDUSTRIAL FELT PRODUCTS

DAILY REPORT

B'HAM WOOL PLANT

FOREMAN:

LEADER:

SHIFT: 3-4

DATE:

11-1-77

	1	2	3	4	5
CUSTOMER	#3				
CODE & ITEMS	S.A.	S.A.			
FELT SIZE	24x16x1/8	15x24x1/8			
DENSITY & TYPE	2.5 2"	2.5 1 1/2"			
BLANKET THICKNESS	4 SPLIT	3" Split			
PKGS. ORDERED & PCS. PER PKG	8	8			
TYPE OF PACKAGE	Bags	Bags			
WEIGHT TOLERANCE					
FEEDER SETTING	7 70	7 70			
CUT OFF TIMER SETTING					
CHANGE TIME- START	3:00	9:00			
PROD. TIME-START	4:25	9:00			
PROD. TIME-STOP	8:00	11:00			
LOST TIME (REASON ON BACK)	25 min	15 min			
NET PRODUCT TIME	3.05	1.75			
LINEAL FT. READING	2560	1400			
ACTUAL LIN. FT.					
NO. GROSS PCS.	3494	1992			
PKGS. & PCS. PER PKG.	673 @ 20	259 @ 8			
NO. SALABLE PCS.	3254	1912			
PCS. REJECTS	111	80			
% REJECTS					
WIDTH OF TRIM	4	4			
PRODUCTION LABOR	1.8	1.0			

REMARKS:

DATE	DESCRIPTION	AMOUNT	TOTAL
------	-------------	--------	-------

8-610-615	Sliter Saw Plug		
85-615-630	no ginkles		
8-730-735	Sliter Saw Plug		
ITEM #2-			

25	1045-1100	Change over	
----	-----------	-------------	--

No.

2017

DAFE

SHIFT

GPO - 19 FEB. 1970 (PRINTED IN U.S.A.) 15

V. TEST RESULTS

NOMENCLATURE

$\overline{\Delta h}$ - Avg. pressure diff. of orifice (in. H₂O)

$\overline{\sqrt{\Delta p}}$ - Avg. of square roots of the velocity pressure (in. H₂O)

P_b - Barometric pressure (uncorrected, in. Hg)

P_m - Meter pressure

P_s/P_m - $\frac{\text{Stack pressure (in. Hg)}}{\text{Meter pressure (in. Hg)}}$

P_s - Stack pressure (in. Hg)

$\overline{t_m}$ - Avg. temp. of meter (°F)

$\overline{t_s}$ - Avg. temp. of stack (°F)

t_a - Ambient temperature

Note: Capital T denotes degrees Rankin

V_n - Volume collected at stack cond through nozzle

V_m - Actual volume metered (ADCF) (Metered Gas Volume x MCF)

V_{mstd} - Vol. metered (SDCF)

V_{lo} - Tot. vol. of liquid collected in impinger & silica gel (ml)

V_{wstd} - Vol. of water vapor in gas sample (SCF)

B_{wo} - Proportion by volume of water vapor in the gas stream (dimensionless)

M_d - Molecular wt. of dry gas stream

M_w - Molecular wt. of wet gas stream

EA - Excess air

$\overline{v_s}$ - Avg. stack gas velocity (fps)

Q_a - Volumetric flow rate (ACFM)

Q_s - Volumetric flow rate (wet basis, SCFM)

Q_{std} - Volumetric flow rate ("SDCFM)

X_p - Total amount of particulate collected (mg)

C_s - Particulate concentration (grains/SDCF)

C_a - Particulate concentration (grains/ACF)

C_{50} - Concentration (C_s) adjusted to 50% EA

PMR - Particulate mass rate (#/Hr.)

C_{12} - Concentration (C_s) adjusted to 12% CO_2

% CO_2 , % N_2 , % O_2 , %CO - Number % by volume, dry basis from orsat analysis

ΔP_s - Differential pressure of the stack (in. H_2O)

A_n - Area of nozzle (ft^2) (6 significant digits)

A_s - Area of stack (ft^2)

%I - Isokinetic (dimensionless)

K_p - Dimensional coefficient $(85.48 \frac{ft.}{Sec.} \frac{lb.}{lb. - mole OR})$

K_m - Orifice correction factor (dimensionless)

ΔH_Q - Value of h measured for a specific orifice when operated under the following conditions: 0.75 cfm of dry air ($M=29$) at $70^\circ F$, 29.92 in. Hg.

mcf - Meter correction factor

t - Total sampling time (minutes)

Standard conditions are $70^\circ F$, 29.92 in. Hg

CFM - Cubic feet per minute

SCFM - Standard cubic feet per minute

SDCFM - Standard dry cubic feet per minute

SCF - Standard cubic feet

C_{SO_2} - Concentration of sulfur dioxide at standard conditions, dry basis, lb/CF

EQUATIONS

$$1. P_s = P_b + (\Delta P_s / 13.6) = () + (/ 13.6) =$$

$$2. P_m = P_b + (\Delta H / 13.6) = () + (/ 13.6) =$$

$$3. \bar{V}_s = K_p C_p (\sqrt{\Delta P}) \sqrt{(T_s) / (M_w) (P_s)} =$$

$$= (85.48) () () \sqrt{() / () ()} =$$

$$4. V_{mstd} = 17.71 (V_m) (P_m) / (T_m) = 17.71 () () / () =$$

$$=$$

$$5. V_{wstd} = 0.0474 (V_{lc}) = (0.0474) () =$$

$$6. B_{wo} = V_{wstd} / (V_{wstd} + V_{mstd}) = () / (+) =$$

$$=$$

$$7. M_d = .44(\%CO_2) + .32(\%O_2) + .28(\%N_2 + \%CO) =$$

$$= .44() + .32() + .28(+) =$$

$$8. M_w = M_d (1 - B_{wo}) + 18(B_{wo}) = () (1 -) + (18) () =$$

$$9. \%EA = \frac{[(\%O_2) - (0.5)(\%CO)]}{[(.264)(\%N_2) - (\%O_2) + (.5)(\%CO)]} (100)$$

$$= \frac{[() - (.5)()]}{[(.264)() - () + (.5)()]} (100)$$

$$=$$

$$10. C_{12} = (C_s) (12) / (\%CO_2) = () (12) / () =$$

$$11. C_{50} = \frac{C_s}{1 - \frac{[(1.5)(\%O_2) - (.133)(\%N_2) - (.75)(\%CO)]}{21}} =$$

$$= \frac{()}{1 - \frac{[(1.5)() - (.133)() - (.75)()]}{21}} =$$

$$=$$

EQUATIONS CONTD

$$12. Q_a = (v_s)(A_s)(60) = (\quad)(\quad)(60) =$$

$$13. Q_s = (Q_a)(530)(P_s)/(T_s)(29.92) = (\quad)(530)(\quad)/(\quad)(29.92)$$

$$=$$

$$14. Q_{std} = (Q_s)(1-B_{wo}) = (\quad)(1 - \quad) =$$

$$15. C_s = (.0154)(M_n)/(V_{mstd}) = (.0154)(\quad)/(\quad) =$$

$$=$$

$$16. V_n = (T_s)/(P_s) \left[(.00267)(V_{lc}) + (V_m)(P_m)/(T_m) \right] =$$

$$= (\quad)/(\quad) \left[(.00267)(\quad) + (\quad)(\quad)/(\quad) \right]$$

$$=$$

$$17. PMR = C_s(Q_{std})(60)/(7000) = (\quad)(\quad)(60)/(7000) =$$

$$=$$

$$18. C_a = (.0154)(M_n)/(V_n) = (.0154)(\quad)/(\quad) =$$

$$19. \%I = \frac{(V_n)(1.667)}{(\rho)(v_s)(A_n)} = \frac{(\quad)(1.667)}{(\quad)(\quad)(\quad)} =$$

SUPPLEMENTARY LABORATORY DATA

As requested by Mr. Jim Carroll of the Jefferson County Department of Health, Air Pollution Control, the impinger water for Runs 3, 4, and 5 were analyzed for solids content. Runs 3 and 4 were combined before it was decided to analyze the impinger catch.

Run Number	Weight Increase mg.	ml. water	ppm
3 & 4	201.0	800.0	251.3
5	74.1	350.0	211.7

.....

3. 11-1-77 Run Number
30.03 Date
-52 Barometric Pressure
64.00 Static Pressure (in. H₂O)
61.613 Run Time (min)
175.00 Volume of Meter (CF)
85.00 Stack Temp (°F)
2.96 Meter Temp (°F)
.953 Diff. Orifice Press (in. H₂O)
47.90 Sq. root Vel. Press.
66.50 Mg. of Particulate
20.50 Ml. of water condensed
.50 % O₂
3.1416 % CO₂
.847 Stack Area (Ft²)
PCF
.000341 Nozzle Area (Ft²)

.....

1. Stack Pressure
30.04 Inches Hg.
763.02 Millimeters Hg.
2. Meter Pressure
30.30 Inches Hg.
769.62 Millimeters Hg.
3. Stack Velocity
59.57 Feet Per Second
18.16 Meters per Second
4. Meter Volume
60.554 SCF
1.715 SCM
5. Water Volume
3.152 SCF
.089 SCM
6. Moisture Content
7. Molecular Wt. Dry
8. Molecular Wt. Dry
12. Volumetric Flow
13.233 ACFM
13.231 ACFM
14. Volumetric Flow
0.942 DCFM
0.942 DCFM
15. Percent Humidity
0.122 Gr/SCF
0.122 Gr/SCF
16. Volume at Std. Conditions
76.025 CF
76.025 CF
17. Particulate Mass Rate
lb/hr
18. Concentration
0.0027 Gr/ACF
0.0027 Gr/ACF
19. % Total Moisture
97.60

.....

.....

3. Run Number
11-1-77 Date
30.08 Barometric Pressure
-0.52 Static Pressure (in. H₂O)
64.00 Run Time (min)
61.618 Volume of Meter (CF)
175.00 Stack Temp (°F)
86.00 Meter Temp (°F)
2.96 Diff. Orifice Press (in. H₂O)
.953 Sq. root Vel. Press.
47.90 Mg. of Particulate
66.50 Ml. of water condensed
20.50 % O₂
.50 % CO₂
3.1416 Stack Area (Ft²)
.847 PCF
.000341 Nozzle Area (Ft²)

1. Stack Pressure
30.04 Inches Hg.
763.02 Millimeters Hg.
2. Meter Pressure
30.30 Inches Hg.
769.62 Millimeters Hg.
3. Stack Velocity
59.57 Feet Per Second
18.16 Meters per Second
4. Meter Volume
60.554 SCF
1.715 SCM
5. Water Volume
3.152 SCI
.089 SCM
6. Moisture Content
.0495
7. Molecular Wt. Dry
28.90
8. Molecular Wt. Dry
28.90
12. Volumetric Flow
11,228. ACFM
5.2991 ACMS
14. Volumetric Flow
8,942. DSCFM
4.2202 DSCMS
15. Concentration
.0122 Gr/SDCF
.0279 Gm/SDCM
16. Volume at Nozzle
76.025 CF
2.153 CM
17.
.93
18. Concentration
.0097 Gr/ACF
.0222 Gm/ACM
19. % Isokinetic
97.40
.....

Guardian Systems, Inc.
2809 Central Avenue
Birmingham, Alabama 35209

Run Number 3
Date 11/1/77
Location U.S. Gypsum
Amount liquid lost during transport none
Acetone blank volume, ml 200
Acetone wash volume, ml 420
Acetone blank concentration, mg/mg 6.39×10^{-7}
Acetone wash blank, mg .1

Filter Collections (mg)

Filter # T-7
Gross 276.7
Tare 260.5
Net 16.2

Probe and Cyclone Wash (mg)

Dish # 3
Gross 78852.6
Tare 78820.9
Acetone Blank 0.0
Net 31.7

Total Particulate Capture 47.9 mg.

Water

Final 350
Initial 300
Net 50

Silica Gel

Final 236.5
Initial 220
Net 16.5

Total Water 66.5

.....
 4. Run Number
 11-1-77 Date
 30.03 Barometric Pressure
 .79 Static Pressure (in. H₂O)
 64.00 Run Time (min)
 61.656 Volume of Meter (CF)
 185.00 Stack Temp (°F)
 89.00 Meter Temp (°F)
 3.02 Diff. Orifice Press (in. H₂O)
 .961 Sq. root Vel. Press.
 87.10 Mg. of Particulate
 65.00 ML. of water condensed
 20.50 % O₂
 .50 % CO₂
 3.1416 Stack Area (Ft²)
 .847 PCF
 .000341 Nozzle Area (Ft²)

 1. Stack Pressure
 29.97 Inches Hg.
 761.24 Millimeters Hg.
 2. Meter Pressure
 30.25 Inches Hg.
 763.35 Millimeters Hg.
 3. Stack Velocity
 60.60 Feet Per Second
 18.47 Meters per Second
 4. Meter Volume
 60.170 SCF
 1.704 SCM
 5. Water Volume
 3.081 SCF
 .087 SCM
 6. Moisture Content
 0.487
 7. Molecular Wt. Dry
 28.96
 8. Molecular Wt. Dry
 28.96
 Volumetric Flow
 1.423 AFPM
 1.423 AFPM
 14. Volumetric Flow
 0.943 AFPM
 0.943 AFPM
 15. Concentration
 .0225 Gr/SCF
 .0225 Gr/SCM
 Volume at Nozzle
 76.047 CF
 2.176 CM
 17. Particulate Mass Rate
 Concentration 1 lb/hr
 18. Concentration
 .011 Gr/AFM
 .011 Gr/AFM
 19. Concentration
 .000341

-24-

PLANT U.S. Gypsum
 LOCATION BIRMINGHAM, AL
 BARO. PRES. 30.08

RUN # 3
 DATE 11/1/77
 TIME 11:00 - 12:20

Guardian SYSTEMS
 INCORPORATED
 2809 CENTRAL AVENUE
 BIRMINGHAM, ALABAMA 35209
 PHONE (205) 879-1850

POINT NO.	TIME		METER		STACK TEMP °F			METER TEMP °F			IMP TEMP °F	BOX TEMP °F	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	Vacuum Pressure "Hg	STATIC PRESSURE "H ₂ O	
	MIN	HOUR	VOL	FT. 3	IN	OUT	AVG	IN	OUT	AVG						BEFORE	AFTER
1	4	4	451.902														
2	8		456.1		82	76	79	52	230	2.5	.77	3				.250	.250
3	12		459.1		84	76	81	54	230	2.8	.87	4					
4	16		463.3		88	76	82	54	230	3.1	.96	4					
5	20		467.3		90	76	83	58	230	3.3	1.05	5					
6	24		471.4		92	80	86	58	230	3.3	1.05	5					
7	28		475.5		94	80	87	60	250	3.3	1.05	5					
8	32		479.6		94	82	88	62	250	2.9	.90	5					
9	36		483.3		94	82	88	64	250	2.9	.90	5					
10	40		486.3		86	80	83	64	230	1.6	.48	2					
11	44		489.3		88	82	85	64	240	1.8	.55	3					
12	48		492.4		90	80	85	64	240	1.85	.56	3					
13	52		495.3		92	80	85	62	240	2.25	.69	3					
14	56		500.4		96	82	89	62	260	3.8	1.2	6					
15	60		505.2		98	84	91	64	260	4.45	1.4	8					
16	64		509.8		100	86	93	62	260	4.2	1.3	7					
17			514.142		100	88	93	62	260	3.55	1.1	6					
18			62.240							2.98	.75						
19																	
20																	
21																	
22																	
23																	
24																	
25																	
26																	
27																	
28																	
29																	
30																	

PROBE TIP SIZE
 BEFORE AFTER
 .250 .250
 WATER
 ml. 50
 gram 16.5
 Total 66.5
 FILTER NO.
 T-7
 NOTES
 SAMPLE BOX NO. 400
 METER BOX NO. 400
 METER ΔH@
 PITOT, CP
 TEMP. DEVICE
 FINAL
 leak check @ 15" Hg
 514.186
 514.184
 .002 CFM
 Pitot 1k cl
 impact @ 4" ✓
 static @ 6" ✓
 Orifice check ✓
 O₂ = 20.5 %
 CO₂ = 0.5 %
 INITIAL
 leak check @ 15" Hg
 451.902
 451.897
 .005 CFM
 Pitot 1k cl
 impact @ 7" ✓
 static @ 4.5" ✓
 Nozzle # 7
 .250 .250
 .250 .250
 .249 .250

.....

4.

11-1-77

Run Number

30.03

Date

- . 79

Barometric Pressure

64.00

Static Pressure (in. H₂O)

61.656

Run Time (min)

185.00

Volume of Meter (CF)

89.00

Stack Temp (°F)

3.02

Diff. Orifice Press (in. H₂O)

.961

Sq. root Vel. Press.

87.10

Mg. of Particulate

65.00

ML. of water condensed

20.50

% O₂

.50

% CO₂

3.1416

Stack Area (Ft²)

.847

PCF

.000341

Nozzle Area (Ft²)

.....

1. Stack Pressure

29.97

Inches Hg.

761.24

Millimeters Hg.

2. Meter Pressure

30.25

Inches Hg.

768.35

Millimeters Hg.

3. Stack Velocity

60.60

Feet Per Second

18.47

Meters per Second

4. Meter Volume

60.170

SCF

1.704

SCM

5. Water Volume

3.081

SCF

.087

SCM

6. Moisture Content

.0487

7. Molecular Wt. Dry

28.90

8. Molecular Wt. Dry

28.57

12. Volumetric Flow

11,423.

ACFM

5.3911

ACMS

14. Volumetric Flow

0,943.

DSCM

4.2206

DSCMS

15. Concentration

.0223

Gr/SDCF

.0510

Gm/SDCM

16. Volume at Nozzle

76.849

CF

2.176

CM

17.

Concentration 1.71

18.

.0175

Gr/ACF

.0400

Gm/ACM

19. % Incombustible

96.87

.....

Guardian Systems, Inc.
2809 Central Avenue
Birmingham, Alabama 35209

Run Number 4

Date 11/1/77

Location U.S. Gypsum

Amount liquid lost during transport none

Acetone blank volume, ml 200

Acetone wash volume, ml 1470

Acetone blank concentration, mg/mg 6.39×10^{-7}

Acetone wash blank, mg .1

Filter Collections (mg)

Filter # T-9

Gross 274.8

Tare 260.5

Net 14.3

Probe and Cyclone Wash (mg)

Dish # 4

Gross 77747.3

Tare 77673.8

Acetone Blank 0.7

Net 72.8

Total Particulate Capture 87.1 mg.

Water

Final 350

Initial 300

Net 50

Silica Gel

Final 235

Initial 220

Net 15

Total Water 65.0

LOCATION B'ham

DATE _____

11/1/22

Guardian

SYSTEMS

INCORPORATED

2808 CENTRAL AVENUE

BIRMINGHAM, ALABAMA 35209

PHONE (206) 879-1850

BARO. PRES. 30.03

TIME

1131-2141

POINT NO.	TIME		METER		STACK TEMP °F	METER TEMP. °F			IMP TEMP °F	BOX TEMP °F	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	Vacuum Pressure "Hg	STATIC PRESSURE "H ₂ O		
	MIN	OUR	VOL	FT. 3		IN	OUT	AVG						BEFORE	AFTER	
1/B			514.274													
1	4	4	514.7	170°	80	80	80°	62°	240°	1.6	.49	1	.250	.250		
2	8	1	517.4	170°	88	80	84°	64°	240°	1.6	.49	2	WATER			
3	12		520.6	170°	90	80	85°	64°	240°	1.9	.60	2	mi. 50			
4	16		524.0	180°	94	82	88°	68°	240°	2.2	.68	2	gram 15.0			
5	20		528.7	190°	98	82	90°	64°	250°	4.1	1.3	5	Total 65			
6	24		531.7	195°	100	84	92°	64°	260°	4.1	1.3	5	FILTER NO.			
7	28		535.9	190°	100	84	92°	64°	250°	4.1	1.3	5	T-9			
8	32	1	540.3	190°	100	84	92°	64°	250°	4.1	1.3	6	NOTES			
9/A													SAMPLE BOX NO. 400			
10	36	4	545.3	175°	90	84	87°	60°	230°	2.5	.75	2	METER BOX NO. 400			
11	40	1	548.7	180°	94	84	89°	58°	250°	2.7	.85	3	METER ΔH@ 1.81			
12	44		552.3	185°	96	84	90°	60°	260°	3.0	.94	4	PITOT, CP			
13	48		556.4	190°	100	84	92°	60°	250°	3.5	1.1	5	TEMP. DEVICE 7.4 min.			
14	52		562.2	195°	100	84	92°	60°	240°	3.5	1.1	5	Leak check @ 15" Hg			
15	56		565.3	195°	100	84	92°	62°	230°	3.5	1.1	5	514.270			
16	60		568.6	195°	102	84	93°	62°	250°	3.1	.96	5	514.267			
17	64	1	573.2	195°	102	84	93°	62°	250°	2.9	.88	5	.003 CFM			
18			576.553										pito lk. ck			
19			62.274	185			89			3.025	.961		impact @ 6.0			
20													static @ 5.5			
21													orifice			
22													O ₂ = 20.5%			
23													CO ₂ = 0.5%			
24													leak check @ 14g			
25													576.591			
26													576.590			
27													6" 14g. 1 min			
28													pito lk ck			
29													impact @ 5.0			
30													static @ 4.8			
31													nozzle			
32													.250 .250			
33													.250 .250			
34													.250 .250			

.....

5.	Run Number
11-1-77	Date
30.00	Barometric Pressure
-0.62	Static Pressure (in. H ₂ O)
64.00	Run Time (min)
61.526	Volume of Meter (CF)
199.00	Stack Temp (°F)
86.00	Meter Temp (°F)
2.96	Diff. Orifice Press (in. H ₂ O)
.948	Sq. root Vel. Press.
69.90	Mg. of Particulate
68.00	Ml. of water condensed
20.00	% O ₂
.50	% CO ₂
3.1416	Stack Area (Ft ²)
.847	PCF
.000341	Nozzle Area (Ft ²)
1.	Stack Pressure
29.95	Inches Hg.
760.73	Millimeters Hg.
2.	Meter Pressure
30.22	Inches Hg.
767.59	Millimeters Hg.
3.	Stack Velocity
60.03	Feet Per Second
18.30	Meters per Second
4.	Meter Volume
60.304	SCF
1.708	SCM
5.	Water Volume
3.223	SCF
.091	SCM
6.	Moisture Content
.0507	
7.	Molecular Wt. Dry
28.88	
8.	Molecular Wt. Dry
28.33	
12.	Volumetric Flow
11,315.	ACFM
5.3401	ACMS
14.	Volumetric Flow
0.779.	DSCFM
4.1432	DSCMS
15.	Concentration
.0179	Gr/SDCF
.0410	Gm/SDCM
16.	Volume at Nozzle
77.709	CF
2.200	CM
17.	
1.36	
18.	Concentration
.0139	Gr/ACF
.0318	Gm/ACM
19.	% Isokinetic
98.89	
.....	

```

.....
5.
11-1-77 Run Number
30.00 Date
-0.2 Barometric Pressure
64.00 Static Pressure (in. H2O)
61.526 Run Time (min)
139.00 Volume of Meter (CF)
86.00 Stack Temp (°F)
2.26 Meter Temp (°F)
.948 Diff. Orifice Press (in. H2O)
69.20 Sq. root Vel. Press.
68.00 Mg. of Particulate
20.00 Ml. of water condensed
.50 % O2
3.1416 % CO2
.847 Stack Area (Ft2)
.0003 PCF
.....
1. Stack Pressure
29.55 Inches Hg.
760.73 Millimeters Hg.
2. Meter Pressure
30.22 Inches Hg.
767.55 Millimeters Hg.
3. Stack Velocity
60.03 Feet Per Second
18.30 Meters per Second
4. Meter Volume
60.304 SCF
1.705 SCF
5. Water Volume
3.225 SCF
.091 SCF
6. Moisture Content
.0507
7. Molecular Wt. Dry
28.86
8. Molecular Wt. Dry
28.86
12. Volumetric Flow
11.515 ACFM
5.3411 ACFM
14. Volumetric Flow
0.775 SCFH
4.3632 SCFH
15. Concentration
.0175 Gr/SCF
0.410 Gr/ACFM
16.
77.70 Gr
2.200 Gr
17. Particulate Mass Rate
1.36 lb/hr
Concentration
.0175 Gr/SCF
.0175 Gr/ACF
18.
.0175 Gr/SCF
.0175 Gr/ACF
.....

```

Guardian Systems, Inc.
2809 Central Avenue
Birmingham, Alabama 35209

Run Number 5

Date 11/1/77

Location U.S. Gypsum

Amount liquid lost during transport none

Acetone blank volume, ml 200

Acetone wash volume, ml 1280

Acetone blank concentration, mg/mg 6.39×10^{-7}

Acetone wash blank, mg .1

Filter Collections (mg)

Filter # T-6

Gross 274.4

Tare 260.2

Net 14.2

Probe and Cyclone Wash (mg)

Dish # 5

Gross 77503.5

Tare 77447.2

Acetone Blank 0.6

Net 55.7

Total Particulate Capture 69.9 mg.

Water

Final 380

Initial 300

Net 80

Silica Gel

Final 238

Initial 220

Net 18

Total Water 68.0

RUN # 5

LOCATION BIRMINGHAM, AL

DATE 11/1/77

BARO. PRES. 30.00

TIME 5:00

Guardian

SYSTEMS
INCORPORATED

**2809 CENTRAL AVENUE
BIRMINGHAM, ALABAMA 35209
PHONE (205) 879-1850**

POINT NO.	TIME		METER		STACK TEMP °F	METER TEMP. °F			IMP TEMP °F	BOX TEMP °F	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	Vacuum Pressure "Hg	STATIC PRESSURE "H ₂ O	
	MIN	OUR	VOL	FT. 3		IN	OUT	AVG						-	+
Font A			576.681											PROBE TIP SIZE	
	4	4	580.3	170	82	72	77	64	230	2.6	.80	4		BEFORE	AFTER
2	8		584.0	180	86	76	81	56	230	2.6	.80	4	WATER		
3	12		587.6	180	90	78	84	56	240	2.9	.90	5	ml. 50		
4	16		591.8	190	92	80	90	56	250	3.2	1.0	5	gram 18		
5	20		595.9	195	94	80	87	55	250	3.3	1.05	5	Total 68		
6	24		600.0	1.95	96	80	88	60	250	3.15	.97	5	FILTER NO.		
7	28		603.8	1.95	96	82	89	64	250	2.8	.88	4	T-6		
8	32		607.5	1.95	98	82	90	64	260	2.5	.77	4	NOTES		
Font B													SAMPLE BOX NO.		
1	36	4	609.0	170	90	80	85	62	260	1.6	.47	2	METER BOX NO. 400		
2	40		613.7	185	90	80	85	64	260	1.85	.56	3	METER ΔH@ 1.81		
3	44		617.2	190	92	80	86	66	250	2.4	.72	4	PITOT, CP		
4	48		620.8	190	94	80	87	64	250	2.4	.72	4	TEMP. DEVICE Blue M.P.		
5	52		625.3	195	96	80	88	64	250	4.2	1.33	7	Leak check @ 15" H ₂ O		
6	56		629.8	195	98	80	89	62	240	4.25	1.3	7	576.681		
7	60		634.6	200	98	82	90	62	240	4.25	1.3	7	576.677		
8	64		638.825	200	98	82	90	62	250	3.5	1.1		.004 cfm		
			62.147	189			86			2.96	.7476		pitot 1k, ck		
													impact @ 20"		
													static @ 4.5"		
													O ₂ = 20.0 %		
													CO ₂ = 0.5 %		
													Leak check @ 15" H ₂ O		
													638.887		
													638.886		
													.001 cfm		
													pitot 1k ck		
													impact @ 3"		
													static @ 7"		
													Nozzle #7		
													.250 .250		
													.250 .249		
													.250 .250		

-29-

nozzle #7
.250 .250
.250 .249
.250 .250

VI. CALIBRATIONS

General

All meter boxes were recalibrated upon return to the laboratory from this test. Using the average meter pressure, each box was calibrated at the closest point (for an average meter pressure of 0.62 a 0.5 "H₂O was used as the calibration point). These three (3) calibrations produced a single point average ΔH which was compared to the original calibration. All were within the 5% allowed at the highest vacuum seen. These calibration sheets are located behind the original calibration sheets.

Batt Oven

The equipment used at the Batt Oven Stack was as follows:

Probe: 5 ft SP

Box: 400

Stack Temperature: Pyrometer

Sample Box: 2

The average temperature of the stack was 183°F. The pyrometer was recalibrated at 185°F and agreed within 1.5% of the initial calibration value.

Class Fiber Filters

FEATURES

- High tensile strength. ■ Excellent handling characteristics. ■ Good wetting properties. ■ Minimum of 99.9% retention for particles of $.3 \mu\text{m}$ as determined by DOP tests. ■ Binder free.

This is the original glass fiber filter pioneered by Gelman Instrument Company over 15 years ago. It continues to be widely used for high volume sampling. Since zinc is one of the raw materials incorporated in the glass fibers, Type A Filters have a variable zinc content. Another component of the filter, sulfuric acid, is used as a dispersion medium, making the sheets unsuitable for measurement of sulfates.

Type A Glass Fiber Filters are less likely to develop static charge or tear than other glass fiber media types. They are used extensively in applications where zinc and iron content is not important, or where sulfate content is not being determined.

Size	37 mm	47 mm	102 mm	8"x10"
Product No.	61715	61694	61696	61701
Filters/Pkg.	500	100	100	100

TYPE A GLASS FIBER FILTER SPECIFICATION REPORT

The following physical/chemical properties represent typical, average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/8" x 10" sheet).

ELEMENTS:

Antimony	30	Manganese	200
Arsenic	30	Mercury	100
Beryllium	1	Molybdenum	10
Bismuth	10	Nickel	10
Cadmium	5	Selenium	5000
Chromium	10	Tin	10
Cobalt	10	Titanium	170
Copper	2	Vanadium	10
Iron	2300	Zinc	5000
Lead	20		to 25,000

OTHER PHYSICALS:

BSO	522	Flow Resistance (Max.)	
*pH	8.5	@ 320 cm/min.	.80 mm
DOP @320/cm/min		Flow Rate (air)	
(ASTM Method 2985)	99.9%	lpm/cm ² @ 70 cm Hg	.50
Tensile Strength		Max. Use Temp.	400°C
(Fed. Spec. UUP31B)	750 gr	Static Properties	Low
Weight,		Ability to	
8"x10" sheet	4.0±.3 gr.	Fold	Excellent

WATER EXTRACTABLE IONS:

Sulfate	100	Chloride	1500
Nitrate	50	Fluoride	15
Ammonia	20		

*pH—Gelman Procedure:

- 500 ml distilled water.
- Add 15 drops saturated KCl solution.
- Shred one 8"x10" sheet and soak in prepared water for one hour.
- Run pH at ambient temperature.

Class Fiber Filters

FEATURES

- Low trace metals. ■ Medium Handling characteristics. ■ Available in all sizes. ■ Minimum of 99.9% retention for particles of $.3 \mu\text{m}$ as determined by DOP tests. ■ Binder free.

Type A/E Glass Fiber Filters are composed of low acid soluble glass fiber. They contain low levels of both zinc and iron. The filters do react with atmospheric sulfur dioxide; and therefore, when high levels of sulfur are expected, corrections for this reaction should be accounted for.

Type A/E Glass Fiber Filters are binder free and ideal for gravimetric analysis of air pollutants. This pure, organic free filter is the basis for procedures widely used in determining municipal and industrial air polluting substances.

Size	25 mm	37 mm	47 mm	102 mm	8"x10"
Product No.	61630	61652	61631	61633	61638
Filters/Pkg.	500	500	100	100	100

TYPE A/E GLASS FIBER FILTER SPECIFICATION REPORT

The following physical/chemical properties represent typical, average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/8" x 10" sheet).

ELEMENTS:

Antimony	20	Manganese	2
Arsenic	20	Mercury	.80
Beryllium	1	Molybdenum	10
Bismuth	10	Nickel	10
Cadmium	2	Selenium	200
Chromium	10	Tin	10
Cobalt	10	Titanium	10
Copper	2	Vanadium	10
Iron	100-1800	Zinc	90
Lead	10		

OTHER PHYSICALS:






BSO	522	Flow Resistance (Max.)	
*pH	9.0	@ 320 cm/min.	.60 mm
DOP @320/cm/min		Flow Rate (air)	
ASTM Methods 2986)	99.9%	lpm/cm ² @ 70 cm Hg	.60
Tensile Strength		Max. Use Temp.	400°C
(Fed. Spec. UUP31B)	600 gr.	Static Properties	Medium
Weight		Ability to	
8"x10" sheet	4.0±.3 gr.	Fold	Good

WATER EXTRACTABLE IONS:

Sulfate	600	Chloride	1500
Nitrate	115	Fluoride	.87
Ammonia	13		

*pH—Gelman Procedure:

- 500 ml distilled water.
- Add 15 drops saturated KCl solution.
- Shred one 8"x10" sheet and soak in prepared water for one hour.
- Run pH at ambient temperature.



NOTE: Flow rate held constant at 0.75; 50% change in flow rate has little effect on probe temperature.

Figure 16
Probe Temperatures

Date 9/28/77

Box No. 400

Barometric Pressure $P_b = 30.02$ in. Hg

Orifice Manometer Setting ΔH In. H ₂ O	Δw_{tm} in. H ₂ O	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Temperature Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Initial	Final
.5	-.19	244.402	250.446	594.100	600.413	76	78	99	95
1.0	-.31	220.726	229.058	569.500	578.158	76	76	91	94
2.0	-.49	250.819	262.513	600.800	612.908	76	76	100	92
3.0	-.66	229.768	244.057	578.700	593.734	76	78	94	99
4.0									

Pump must be operated for 15 minutes at each ΔH setting.

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

$$P_{wtm} = P_b - \frac{\Delta w_{tm}}{13.6}$$

$$P_{dgm} = P_b + \frac{\Delta h}{13.6}$$

Δw_{tm} = negative pressure on wet test meter in inches of H₂O

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$\text{Meter Correction Factor} = \frac{(\text{wet final} - \text{wet initial}) (T_{dgm}) (P_{wtm})}{(\text{dry final} - \text{dry initial}) (28.316) (T_{wtm}) (P_{dgm})} \text{ or } (1)$$

$$\text{Average MCF} = \frac{\sum \text{MCF}}{5}$$

Tolerances

$$\text{Average MCF} = 1.00 \pm .01$$

.99
.99
.99
.99

.99

METER CALIBRATION FORM

Date 11/8/77

Box No. 400

Barometric Pressure $P_b = \underline{30.00}$ in. Hg

8" Hg

Orifice Manometer Setting ΔH In. H ₂ O	Δw_{tm} in. H ₂ O	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Temperature Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Initial	Final
<u>18</u> 7.0	<u>-1.87</u>	<u>845.452</u>	<u>859.829</u>	<u>649.700</u>	<u>664.470</u>	<u>72</u>	<u>72</u>	<u>81</u>	<u>90</u>
<u>120</u> 7.0	<u>-1.85</u>	<u>860.822</u>	<u>875.064</u>	<u>665.500</u>	<u>680.403</u>	<u>72</u>	<u>74</u>	<u>90</u>	<u>100</u>
<u>20</u> 7.0	<u>-1.84</u>	<u>876.007</u>	<u>890.157</u>	<u>681.400</u>	<u>696.407</u>	<u>74</u>	<u>74</u>	<u>101</u>	<u>109</u>
3.0									
.0									

Pump must be operated for 15 minutes at each ΔH setting.

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

$P_{wtm} = P_b - \frac{\Delta w_{tm}}{13.6}$

$P_{dgm} = P_b + \frac{\Delta h}{13.6}$

Δw_{tm} = negative pressure on wet test meter in inches of H₂O

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

Meter Correction Factor = $\frac{(\text{wet final} - \text{wet initial}) (T_{dgm}) (P_{wtm})}{(\text{dry final} - \text{dry initial}) (28.316) (T_{wtm}) (P_{dgm})}$
(for each ΔH) or (1)

Average MCF = $\frac{\sum MCF}{5}$

Tolerances

Average MCF = 1.00 ± .01

ORIFICE CALIBRATION FORM

Date 9/28/77

Meter Box No. 400

ΔH	V_1	V_2	θ	t_1	t_2	$V_2 - V_1$	Q_m	K_m
in. H ₂ O	CF	CF	Sec.	OF	OF	CF		
0.5	594.100	600.413	900	97	90	6.313	.4120	.7336
1.0	569.500	578.158	900	98	87	8.658	.5651	.7138
2.0	600.800	612.908	900	100	90	12.108	.7951	.7092
3.0	578.900	593.734	900	104	89	14.834	.9652	.7044
4.0								
Average K_m								

V_1 = Dry gas meter reading at the start of each test

V_2 = Dry gas meter reading at the end of each test

t_1 = Dry gas meter inlet temperature

t_2 = Dry gas meter outlet temperature

Calculations

$$1. \quad Q_m = \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{\frac{t_1 + t_2 + 460}{2}} \right] (60) (MCF)$$

$$2. \quad K_m = \frac{Q_m}{\sqrt{\frac{P_m M_m}{T_m \Delta H}}} \quad \text{(for each } \Delta H \text{)}$$

MCF: meter correction factor

3. Calculate the average K_m as follows:

$$\bar{K}_m = \frac{\sum K_m}{5}$$

4. Calculate ΔH as follows:

$$\Delta H@ = \frac{Q@^2 P@ M@}{T@} \frac{1}{\bar{K}_m^2}$$

$Q@ = 0.75 \text{ cfm}$
 $T@ = 5300 \text{ A}$
 $P@ = 29.92 \text{ in. Hg}$
 $M@ = 29$

Tolerances $\Delta H@ = 1.84 \pm .25$

APC - 062

1.80

ORIFICE CALIBRATION FORM

Date

11/8/77

Meter Box No.

4008" Hg

ΔH	V_1	V_2	θ	t_1	t_2	$V_2 - V_1$	Q_m	K_m
in. H ₂ O	CF	CF	Sec.	OF	OF	CF		
0.25 3.0	649.700	664.470	900	96	96	14.770 14.770	.9816	.7154
1.00 3.0	665.500	680.403	1	110	86	14.903	.9882	.7138
2.00 3.0	681.400	696.407	1	116	84	15.007	.9923	.7122
3.0								
4.0								
Average K_m								

 V_1 = Dry gas meter reading at the start of each test V_2 = Dry gas meter reading at the end of each test t_1 = Dry gas meter inlet temperature t_2 = Dry gas meter outlet temperature

Calculations

$$1. \quad Q_m = \text{(for each } \Delta H) \quad \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{\frac{t_1 + t_2 + 460}{2}} \right] (60) \text{ (MCF)}$$

MCF: meter correction factor

$$2. \quad K_m = \text{(for each } \Delta H) \quad Q_m \sqrt{\frac{P_m M_m}{T_m \Delta H}}$$

$$\begin{aligned} P_m &= P_{atm} + \frac{\Delta H}{13.6} \\ M_m &= 29 \\ T_m &= t_2 + 460 \end{aligned}$$

3. Calculate the average K_m as follows:

$$\bar{K}_m = \frac{\sum K_m}{5}$$

4. Calculate ΔH as follows:

$$\Delta H = \frac{Q_0^2 P_0 M_0}{T_0} \frac{1}{\bar{K}_m^2}$$

$$\begin{aligned} Q_0 &= 0.75 \text{ cfm} \\ T_0 &= 530^\circ \text{ A} \\ P_0 &= 29.92 \text{ in. Hg} \\ M_0 &= 29 \end{aligned}$$

(1.80
1.81
1.82)

Tolerance
~~1.77~~


$\pm 5\%$ 1.86 1.77 $\rightarrow$ 1.95

Tolerances $\Delta H = 1.84 \pm .25$

Calibration

Box thermometer #2 vs. Mercury Std.

~~X~~ - #2 temps.



9 8 7 6 5 4 3 2 1 0 -1 -2 -3 -4 -5 -6 -7 -8 -9

°F - Mercury std

Calibration

1 3/4" impinger vs. 70°F Hg std.
therm.

~~X~~ - 13 1/4" temp.

Calibration

1" impinger^(unmarked) vs. 70°F Hg. std.
therm.

~~X~~ - 1" temp.

45° 44° 43° 42° 41° 40° 39° 38° 37° 36° 35°

65 66 67 68 69 70 71 72 73 74 75

°F - Hg std

°F - Hg std.


65 66 67 68 69 70 71 72 73 74 75

Calibrations -

LdN, Pyrometer,
vs.

ASTM. stand. bulb

- Standard
- ooo - LdN
- x - Pyrometer
- o-o - Galvanometer



PITOT CALIBRATION FORM

PITOT NO. 5'5P

DATE 9-20-77

STD READ	A	B	Cp A	Cp B
.52	.70	.70	.853	.853
.46	.63	.63	.846	.846
.35	.48	.49	.845	.837
.21	.29	.29	.842	.842
AVERAGE Cp's			<u>.847</u>	<u>.845</u>

Measure the velocity pressure (ΔP) at the same point within a cross section of a straight run of duct work (8 diameters downstream and 2 diameters upstream from any point of disturbance) with a standard pitot tube and the S-type pitot tube for the desired range of gas velocities. The S-type pitot should be calibrated twice, reversing the direction of the legs during the second calibration. Make at least three determinations for each direction. Determine Cp for the minimum and maximum flow rates of the sampling train. Determine the pitot tube coefficient for each direction as:

Cp (std) = Coefficient
of standard pitot tube
(if unknown, use .99)

$$Cp(s) = Cp(std) \sqrt{\frac{\Delta P (Standard)}{\Delta P(s)}}$$

Use only those pitot tubes in which the average coefficient, Cp, equals 0.85 ± 0.02 in both directions, since the nomograph used with the sampling train is designed for this number. When other methods are employed where Cp is measured as an independent variable, this requirement will be waived.

This calibration must be done quarterly or at any time that a pitot tube is damaged. A record should be maintained showing dates and calibrations, and a copy included with each test report.

Emission Test Report
Review Checklist

Reviewer: Wallace
Review Date: 8/5/92

A. Background Information

1. Facility name: U. S. Gypsum
Location: Birmingham, AL
2. Source category: Mineral Wool
3. Test date: 11/1/77
4. Test sponsor: Facility
5. Testing contractor: Guardian Systems Inc.
6. Purpose of test: Compliance

7. Pollutants measured

☒ PM PM-10 CO SO₂ NO_x VOC Pb CO₂

Others (list): _____


8. Process overview: On an attached page provide a block diagram of the unit operations and associated air pollution control systems at the facility. Identify process tested with letters from the beginning of the alphabet (A, B, C, etc.) and APC systems with letters from end of alphabet (V, W, X, etc.). Also identify test locations with Arabic numerals (1, 2, 3, ...). Using the ID symbols from that sketch complete the table below that identifies processes or unit operations tested.

No process description or flow diagram in report last effort on back of this page

Test ID	Process	Process ID	Emissions tested		APCD (controlled emissions only)
			Uncontrolled	Controlled	
1	Bath Curium Oven	A		X	ESP

B. Process Information

1. Provide a brief narrative description of the process. With as much detail as possible, (e.g., if a furnace or conveyor system is used, identify the type of unit) describe the equipment used for those operations tested. (Note: If process description provided in test report is adequate, attach copy or reproduce here.)



*No process diagram or process description in report
process data were provided. Process rate assumed
to be based on tons of batt produced*

DRAFT/WP
d3006-4/971130
03/30/92 3

2. For each process tested list feedstock materials and products. Indicate if activity factors are for feed (F) rate or product (P) rate.

Process ID	Feedstock materials	Products	Basis for activity factor	F/P
A	Batt mineral Wool	Cured mineral wool	Batts produced	F

Basis for data: 1, 9-15
(Indicate page/table Nos. in test report)

3. For each process or operation tested and each test run note process capacity and operating rate during test.

Process ID	Capacity	Units	Test run	Process rate	Units
A	NA	NA	1	2.00	T/hr
			2	1.42	↓
			3	2.79	
			4		
			4		
			1		
			2		
			3		
			4		
			4		
			1		
			2		
			3		
			4		
			4		
			1		
			2		
			3		
			4		
			4		

Basis for data: 8

C. Air Pollution Control Systems Tested

1. For each air pollution control system pollution control system identified in A.8, note the following

ID	Type of APCD	Manufacturer	Model No.
W	ESP	Veltran	NA

Note: Be as specific as possible in identifying APCD. For example, indicate "pulse jet fabric filter" rather than simply "fabric filter."

2. For each system identified above, provide a narrative description. For fugitive systems describe capture techniques as well as the removal techniques (use a separate page if necessary)

No description available

DRAFT/WP
d3006-4/971130
03/30/92 5

3. Using the attached parameter list for guidance complete the table below. (Use additional pages as needed.)

APCD ID	Parameter	Units	Readings			
			Run 1	Run 2	Run 3	Run 4
Type of APCD:						
Type of APCD:						
Type of APCD:						

NA

D. Sampling and Analysis Methods

1. Complete the following table

Test location	Pollutant	S & A method	Reference/ conditional method	Deviations noted
A	PM	Methods 1-5	Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N
			Y/N	Y/N

DRAFT/WP
d3006-4/971130
03/30/92 7

2. If a method used was not a reference or conditional method, provide a narrative discussion including any data manipulation needed to make results correspond to reference or conditional method results.

NA

3. Describe any deviations identified above.

Used Fyrite for CO₂ and O₂ results. Does not affect PM levels

E. Emission Data Documentation

1. Tabulate the following stack gas data from the test report. (Use additional pages as needed.)

Test ID	Parameter	Units	Values reported			
			Run 1	Run 2	Run 3	Run 4
	Stack temperature	°F	175	185	189	
	Moisture	%	4.95	4.87	5.07	
	Oxygen	%	20.5	20.5	20.4	
	Volumetric flow, actual	acfm	11,228	11,423	11,315	
	Volumetric flow, standard	scfm	8942	8943	8779	
	Percent isokinetic	%	97	97	97	
	Pollutant concentration:					
	PM	gr/dscf	0.0122	0.0223	0.0179	
	Stack temperature					
	Moisture					
	Oxygen					
	Volumetric flow, actual					
	Volumetric flow, standard					
	Percent isokinetic					
	Pollutant concentration:					
	Stack temperature					
	Moisture					
	Oxygen					
	Volumetric flow, actual					
	Volumetric flow, standard					
	Percent isokinetic					
	Pollutant concentration:					

DRAFT/WP
d3006-4/971130
03/30/92 .9

2. Tabulate pollutant mass flux rates

Test ID	Pollutant	Units	Mass flux rates			
			Run 1	Run 2	Run 3	Run 4
1	PM	lb/hr	0.93	1.21	1.34	

DRAFT/WP
d3006-4/971130
03/30/92 10

3. Present example emission factor calculations below.

DRAFT/WP
d3006-4/971130
03/30/92 11

4. Tabulate emission factors

Process	Pollutant	Units	Average emission factor	
			Uncontrolled	Controlled
A	PM	lb/Ton batt		0.72

b3006-4/971130

ATTACHMENT A
APCD PARAMETERS

Type of APCD	Parameters
Fabric filter	Cleaning mechanism Bag type Cleaning frequency Air to cloth ratio (A/C) Pressure drop Inlet temperature
ESP	Type (wet or dry) Number of fields Rapping cycle (if dry) Specific Collection Area (SCA) Particulate resistivity (if known) Spark rate Current and power levels
Venturi (or other high energy) scrubber	Pressure drop Liquid/gas (L/G) ratio Mist eliminator type
Packed-bed scrubber	Packing depth L/G ratio Caustic use (Y/N) pH Mist eliminator type
Carbon absorber	Bed depth Superficial gas velocity Bed temperature Desorption mechanism (media) Flue-gas moisture Cycle length Time-on-line after breakthrough