

Commonwealth of Pennsylvania
Environmental Resources
October 18, 1990

Subject: Stack Test Review

To: Data File
Rich Hill Quarry
Commercial Stone Company, Inc.
Connellsville, Fayette County

From: Rick Begley *RB*
Air Pollution Control Engineer
Division of Technical Services and Monitoring
Bureau of Air Quality Control

Through: Chief, Source Testing and Monitoring Section *bb*

Commercial Stone Company, Inc. operates a sand plant at the above location utilizing four Buell "Size Classifiers", each rated at 40 tons per hour. The plant processed an average of 148 tons of sand per hour during the testing period.

Effluent from the classifiers is collected and directed to a Tri Fab Inc. fabric collector, model 405-12, consisting of a single compartment containing 405 felted polyester bags for an air to cloth ratio of 7.3:1. The collector is rated at 48,400 ACFM with a pressure drop of 3.5 to 4.0 inches W.G.. A reverse jet pulse, actuated by a timer is used to periodically clean the bags. The effluent is drawn through the collector by a 200 HP L.D. Fan and directed to a 4 feet x 3 feet rectangular stack discharging to the atmosphere at a point 15 feet above grade.

On August 22, 1990, three particulate tests were performed on the exhaust stack of the fabric collector by personnel from Comprehensive Safety Compliance Inc. to demonstrate compliance with NEPS. The tests were conducted in accordance with a preapproved protocol and found to be acceptable to the Department with the following exception:

The posttest meter calibration factor (Y) was used for the gas meter volumetric calculations instead of the pretest gas meter calibration factor. Although the effect of using the posttest Y in this case is negligible, future test reports may be rejected if the correct procedures are not followed.

The following test results were extracted from the test report:

Run	RES-1	RES-2	RES-3
Volumetric Flow Rate (DSCF/min)	44,600	39,700	39,100
Rated capacity (T/hr)	160	160	160
Tested Rate (T/hr)	150	145	148
Actual Concentration (pp/DSCF)	0.011	0.011	0.009
Actual Emission Rate (lbs/hr)	4.2	3.9	3.1
Allowable Concentration (pp/DSCF)*	0.0218	0.0218	0.0218

*Per 40 CFR, Part 60, Subpart 000, Section 6.0672(1)

cc: Dick Murray - Greensburg District Office
File 26-310-016 through Doug Leisher, Abatement and Compliance Section
Reading File, Source Testing

RBBarjr

PARTICULATE EMISSION TESTING
SAND PLANT BAGHOUSE
RICH HILL QUARRY
COMMERCIAL STONE
CONNELLSVILLE, PA

Report to:

Mr. Ted Dinardo
Commercial Stone Inc.
2200 Springfield Pike
Connellsville, PA 15425

Report by:

Mr. Richard L. Campbell
Division Manager

Comprehensive Safety Compliance, Inc.
295 William Pitt Way
Pittsburgh, PA 15238

Report Disclaimer

"This report (Particulate Emission Testing) and the associated attachments and appendices has been produced and developed for and at the request of Commercial Stone Company. It conveys the findings of CSC as of the date noted herein. This report (etc.) is intended for the exclusive use of the Commercial Stone Company (including its employees, officers, and Board of Directors) and may not be used, referenced, or cited for any reason whatsoever by any other individual, company, or party whether or not related to or associated with the Commercial Stone Company now or at any time in the future. Any such reliance, use, reference, or citation without the expressed authorization of CSC is expressly prohibited. Any other company, individual, or party relying upon, using, referencing, or citing this report does so at their own risk and detriment. No guarantee or warranty of whatever nature, whether expressed or implied by or in this report (etc.) which may flow to the Commercial Stone Company is granted or conveyed to, or may be assumed to have been granted to or conveyed to anyone else."

TABLE OF CONTENTS

1.0	Introduction
2.0	Summary of Results
3.0	Process and Test Program Description

APPENDIX

A.	Formulas and Calculations
B.	Sampling Methodology & Equipment Calibration
C.	Field Data Sheets
D.	Process Data
E.	Laboratory Data
F.	W. E. Certification

1.0 INTRODUCTION

On August 22, 1990, particulate emission testing and opacity observations were performed on the Sand Plant Baghouse at Commercial Stone Company's Rich Hill plant in Connellsville, PA.

The test program was authorized by Ms. Leah Trielle of Commercial Stone Company. Testing was performed by Mr. Richard Campbell, Mr. Darren Midberry and visible emission readings by Mr. Kevin Kennedy of Comprehensive Safety Compliance, Inc. (CSC). Testing was observed by Mr. Dick Murray of the Pennsylvania Department of Environmental Resources Air Pollution Control Bureau.

2.0 SUMMARY OF RESULTS

Table No. 1 below is a summary of Particulate Emission Data and Opacity Data from tests on the Sand Plant Baghouse.

Table No. 2 is a summary of flue gas parameters.

TABLE NO. 1
Particulate Emissions and Opacity Data

Test Date 1990	Test No.	Test Location	Particulate Emission Data			Opacity Data ^c		
			Conc. ^a Gr/dscf	Emission Rate ^b lb/hr	Allowable lb/hr	Min. %	Max. %	Highest 6 min. Avg. %
8/22	RHS-1	Baghouse Outlet	0.011	4.2	21.9	0	5	1
8/22	RHS-2	Baghouse Outlet	0.011	3.9	21.6	0	0	0
8/22	RHS-3	Baghouse Outlet	0.009	3.1	21.8	0	0	0

- (a) Grains per dry standard cubic foot
- (b) Pounds per hour
- (c) Opacity data from EPA Method 9 observations

TABLE NO. 2
Summary of Flue Gas Parameters

Test Date 1990	Test No.	Test Location	Percent Moisture	Stack Temp. °F	Percent		Flow Rates	
					CO ₂ ^a	O ₂ ^b	ACFM ^c	DSCFM ^d
8/22	RHS-1	Baghouse Outlet	1.6	72	0	21.0	48,000	44,600
8/22	RHS-2	Baghouse Outlet	1.6	81	0	21.0	43,400	39,700
8/22	RHS-3	Baghouse Outlet	1.8	103	0	21.0	44,700	39,100

- a. percent carbon dioxide by volume
b. percent oxygen by volume
c. actual cubic feet per minute
d. dry standard cubic feet per minute

3.0 PROCESS AND TEST PROGRAM DESCRIPTION

Process Description

Commercial Stone operates a sand plant which uses a Buell size classifier (Model GI75) manufactured by Envirotech Corporation. The Buell Gravitational-Inertial Classifier utilizes classifying principles combining, gravitational, inertial centrifugal, and aerodynamic forces. Air or gas entrained feed material enters the classifier primary air inlet at the top of the unit. The primary air inlet velocity is between 3500 and 6000 feet per minute, depending on the classification required. The curtain of feed material drops in front of the air outlet provided with widely spaced vanes to almost reverse the gas flow introduced through the primary air inlet. Prior to passing through the vanes, the relatively high velocity of the entering gas stream sets up, by friction, a counter clockwise eddy current in the chamber. The eddy current is reinforced by gas entering through the secondary air inlet located just above the coarse discharge outlet. Each particle entering the classifier has a gravitational force (F_g) proportional to its mass which, in turn, is proportional to the cube of its diameter. As the particle is introduced in the classifier at the velocity of the primary gas stream, it is also subjected to an inertial force (F_i) also proportional to its mass.

Since the gas stream flows in a downward direction, the inertial and gravitational forces (F_i and F_g) complement each other. The gas stream changes direction as it passed through the vanes, thus exerting a drag force (F_d) proportional to the diameter of the particle, and almost opposite in direction to the gravitational and inertial forces. As the particle is influenced by the drag force (F_d) and changes direction, it is subjected to a small centrifugal force (F_c) proportional to its mass, directly opposing drag force (F_d). Under

set conditions, the resultant force (R) acting on a particular particle diameter (K) referred to as the cut point, will be of a magnitude and direction to give the particle a 50-50 chance of being swept by the gas stream through the vanes or to impinge on the vanes and to be thrown back into the feed curtain. The resultant force (R) on larger particles than (K) is in a direction at small variance with the gravitational-inertial forces and the particles will either impinge on the vanes and be knocked out, or if large enough, they will not even come in contact with the vanes but fall directly into the coarse discharge. Smaller particles will have a resultant force (R) almost perpendicular to the gravitational-inertial forces which will permit them to be swept through the vanes by the gas stream. The eddy current flowing in a downward parallel direction to the plane formed by the vanes, provides a moving wall containing the curtain of feed material in the classifying zone without detrimental frictional drag effects of a solid wall. The particles not swept through the vanes fall on an inclined baffle plate located at the bottom of the gas outlet directly underneath the primary gas inlet. The coarse product is scrubbed by the secondary air as it slides off into the coarse discharge outlet. Any fines adhering to coarser particles are picked up by the secondary air flow to join the stray fine particles entrained by the eddy current and are returned to the classifier inlet point, where they are reintroduced in the classifying zone. The buell gravitational-inertial classifier separates at any desired cut point between 200 to 50 mesh (74 to 297) microns). The cut point is controlled by the air velocity through the vanes, determining the magnitude of the drag force (F_d), and the primary air inlet velocity determining inertial force, (F_i). Regulating the inlet velocity by increasing the flow through the secondary air inlet while keeping the total air volume, i.e., vane velocity constant, is usually all that

is required to meet varying cut point requirements. There are four units which each have a capacity of 50-70 tons per hour. A process schematic is shown in Figure No. 1. Process data is provided in Table No. 3.

Emission Control Equipment

The emissions from the four classifiers are collected by a common baghouse. The baghouse is a Tri Fab Inc. reverse pulse collector. The unit is a Model 405-12 which contains 108 ten foot length bags. The bag material is BHA Style NX01 NOMEX. Control System process data during testing is provided in Appendix D.

Test Program Description

Testing was conducted on the Particulate Emissions from the Sand Plant Baghouse Exit Stack.

The sampling location is shown in Figure No. 2. Sample duration was 87.5 minutes for Test No. 1 and 75 minutes for Tests 2 and 3.

BUELL GRAVITATIONAL-INERTIAL CLASSIFIER





Figure No. 1

Process Schematic

TABEL NO. 3
Process Production
Rich Hill Sand Plant

DATE 1990	TEST NO	PRODUCTION RATE TONS/HR
8/22	RHS-1	150
8/22	RHS-2	145
8/22	RHS-3	148

Additional process data is provided in Appendix D.



Rectangular Duct 48" x 36"

5 sample ports

5 points per port

25 total sample points

FIGURE NO. 2
Commercial Stone Rich Hill Sandplant
Sampling Location

Method 5 Sampling Procedures

After selecting the sampling site and the minimum number of traverse points, the stack pressure, temperature, moisture and range of velocity head were measured according to the procedures described in the Federal Register*.

Approximately 200 grams of silica gel was weighed in a sealed impinger prior to each test. Glass fiber filters** (4 inch diameter) desiccated for at least 24 hours, dried at 105°C for 2 hours and weighed to the nearest 0.1mg. on an analytical balance. One hundred ml of distilled water was placed in each of the first two impingers; the third impinger was initially empty; and the impinger containing the silica gel was placed next in series. The sampling train was leak-checked at the sampling site prior to each test run by plugging the inlet to the nozzle and pulling 15-inch Hg vacuum, at the conclusion of the test by plugging the inlet to the nozzle and pulling a vacuum equal to the highest vacuum reached during the test run. A more detailed description of the sampling and analytical procedures is provided in Appendix B.

*Federal Register, CFR 40, Part 60, July 1, 1989.

A. FORMULAS AND CALCULATIONS

NOMENCLATURE AND DIMENSIONS

A_s	=	cross-sectional area of stack, ft ²
A_n	=	area of sampling nozzle, ft ²
B_{ws}	=	proportional by volume of water vapor in the gas stream, dimensionless
C_p	=	pitot tube coefficient, dimensionless = .84
C_s	=	concentration of particulate matter in stack gas, gr/scf, dry basis
%CO	=	percent of carbon monoxide by volume, dry basis
%CO ²	=	percent of carbon dioxide by volume, dry basis
H	=	average pressure drop across the orifice meter, inches of H ₂ O
I	=	percent of isokinetic sampling
M_d	=	dry molecular weight, lb/lb-mole
M_n	=	total amount of particulate matter collected, mg.
M_s	=	molecular weight of stack gas (wet basis), lb/lb-mole
%N ₂	=	percent of nitrogen by volume, dry basis
%O ₂	=	percent of oxygen by volume, dry basis
p	=	velocity head of stack gas, inches of H ₂ O
P_{bar}	=	barometric pressure, inches of Hg
P_s	=	absolute stack gas pressure, inches of Hg
pmr	=	particulate matter emission rate, lbs/hr
Q_s	=	volumetric flow rate, wet basis, standard conditions
$Q_{s\text{ std}}$	=	volumetric flow rate, dry basis, standard
T_m	=	average temperature of dry gas meter, °R
T_s	=	average temperature of stack gas, °R

V_{lc} = total volume of liquid collected in impingers and silica gel, ml.

V_m = volume of sample through the dry gas meter at meter conditions, ft^3

V_{mstd} = volume of gas sample through the dry gas meter at standard conditions, ft^3

V_s = stack gas velocity at stack conditions, fps

V_{wstd} = volume of water in the gas sample at standard conditions, ft^3

t = total sampling time, minutes

Note: Standard conditions = $70^{\circ}F$ and 29.92 inches of Hg.

Example Calculations for Particulate Emissions

Test No. RHS-1

1. Volume of dry gas sampled corrected to standard conditions. Note: V_m must be corrected for leakage if any leakage rates exceed L_a .)

$$V_{mstd} = 17.65 \times V_m \times Y \left[\frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right] =$$

$$V_{mstd} = 17.65 \times 67.994 \times (.995) \left[\frac{28.4 + \frac{1.6}{13.6}}{548} \right] = 62.140$$

2. Volume of water vapor at standard conditions, ft^3 .

$$V_{wstd} = 0.04707 V_{1c} =$$

$$V_{wstd} = 0.04707 \times 21.3 = 1.00$$

3. Moisture content in stack gas.

$$B_{ws} = \frac{V_{wstd}}{V_{mstd} \times V_{wstd}} = B_{ws} = \frac{1.00}{62.140 + 1.00} = .016$$

4. Dry molecular weight of stack gas.

$$M_d = 0.440 (\% CO_2) + 0.320 (\% O_2) + 0.280 (\% N_2 + \% CO) =$$

$$M_d = 0.440 (0.0) + 0.32 (21) + 0.280 (79) = 28.84$$

5. Molecular weight of stack gas

$$M_s = M_d (1 - B_{ws}) + 18 B_{ws} =$$

$$M_s = 28.84 (1 - .016) + 18(.016) = 28.67$$

6. Stack velocity at stack conditions, fps

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg.} \times \frac{T_s}{P_s M_s}} =$$

RHS-1

$$V_s = 85.49 \times .84 \times (1.15) \times \sqrt{\frac{532}{28.45 \times 28.67}} = 66.69$$

7. Stack gas volumetric flow rate at stack conditions, cfh

$$Q_s = 3600 \times V_s \times A_s$$

$$Q_s = 60 \times 66.69 \times 12.0 = 48,017 \text{ ACFM}$$

8. Dry stack gas volumetric flow rate at standard conditions, cfh.

$$Q_{s, \text{std}} = 17.65 Q_s \frac{P_s}{T_s} (1 - B_{ws}) = \text{SCFM} \times 60 = \text{SCFH}$$

$$Q_{\text{std}} = 17.65 \times 48,017 \times \frac{28.45}{532} \times (1 - .016) = 44,597 \times 60 = 2,675,820$$

9. Concentration in g/scf

$$C'_s = 0.001 \text{ g/mg} \frac{M_n}{V_{m, \text{std}}} = 0.001 \times \frac{44.7}{62.140} = 0.00072$$

$$0.00072 \times 15.43 = 0.011 \text{ gr/dscf}$$

10. Particulate mass emission rate, lbs/hr.

$$\text{pmr} = \frac{C_s \times Q_{s, \text{std}}}{454} = \frac{0.00072 \times 2,675,820}{454} = 4.2 \text{ lb/hr}$$

11. Isokinetic variation

$$I = 100 \frac{T_s}{T_n} \left[\frac{0.002669}{60} \frac{V_1}{V_s} + \frac{\frac{V_m}{T_n}}{P_s A_n} \frac{P_{\text{bar}}}{A_n} + \frac{A_n}{13.6} \right]$$

$$I = 100 (532) \left[\frac{0.002669(21.3)}{60 \times 87.5 \times 66.69 \times 28.45 \times .000189} + \frac{67.994}{548 (.995) (28.4 + 13.6)} + \frac{1.6}{13.6} \right] = 101.1$$

Example Calculations for Particulate Emissions

Test No. RHS-2

1. Volume of dry gas sampled corrected to standard conditions. Note: V_m must be corrected for leakage if any leakage rates exceed L_a .)

$$V_{mstd} = 17.65 \times V_m \times Y \left[\frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right] =$$

$$V_{mstd} = 17.65 \times 55.394 \times (.995) \left[\frac{28.4 + \frac{1.3}{13.6}}{554} \right] = 50.038$$

2. Volume of water vapor at standard conditions, ft^3 .

$$V_{wstd} = 0.04707 V_{1c} =$$

$$V_{wstd} = 0.04707 \times 16.4 = 0.77$$

3. Moisture content in stack gas.

$$B_{ws} = \frac{V_{wcstd}}{V_{mstd} + V_{wcstd}} = B_{wsstd} = \frac{0.77}{50.038 + 0.77} = .015$$

4. Dry molecular weight of stack gas.

$$M_d = 0.440 (\% CO_2) + 0.320 (\% O_2) + 0.280 (\% N_2 + \% CO) =$$

$$M_d = 0.440 (0.0) + 0.32 (21.0) + 0.280 (79.0) = 28.84$$

5. Molecular weight of stack gas

$$M_s = M_d (1 - B_{ws}) + 18 B_{ws} =$$

$$M_s = 28.84 (1 - .015) + 18(.015) = 28.68$$

6. Stack velocity at stack conditions, fps

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg.}} \times \sqrt{\frac{T_s}{P_s M_s}} =$$

RHS-2

$$V_s = 85.49 \times .84 \times (1.03) \times \sqrt{\frac{541}{28.45 \times 28.68}} = 60.23$$

7. Stack gas volumetric flow rate at stack conditions, cfm

$$Q_s = 3600 \times V_s \times A_s$$

$$Q_s = 60 \times 60.23 \times 12.0 = 43,366 \text{ ACFM}$$

8. Dry stack gas volumetric flow rate at standard conditions, cfm.

$$Q_{s\text{std}} = 17.65 Q_s \frac{P_s}{T_s} (1 - B_{ws}) = \text{SCFM} \times 60 = \text{SCFH}$$

$$Q_{s\text{std}} = 17.65 \times 43,366 \frac{28.45}{541} \times (1 - .015) = 39,647 \times 60 = 2,378,820$$

9. Concentration in g/scf

$$C'_s = 0.001 \text{ g/mg} \frac{M_n}{V_{m\text{std}}} = 0.001 \times \frac{37.6}{50.038} = 0.00075$$

$$0.00075 \times 15.43 = 0.011 \text{ gr/dscf}$$

10. Particulate mass emission rate, lbs/hr.

$$\text{pmr} = \frac{C_s \times Q_{s\text{std}}}{454} = \frac{0.00075 \times 2,378,820}{454} = 3.9 \text{ lb/hr}$$

11. Isokinetic variation

$$I = \frac{100 T_s \left[\frac{V_1}{60} + \frac{\frac{V_m}{T_m} \gamma \frac{P_{\text{bar}}}{P_s} + \frac{\Delta H}{13.6}}{V_s \frac{P_s}{P_n} A_n} \right]}{0.002669}$$

$$I = \frac{100 (541) \left[\frac{0.002669(16.4)}{60 \times 75 \times 60.23 \times 28.45 \times .000189} + \frac{55.394}{554} \left(\frac{.9951}{.000189} \right) \left(\frac{28.4}{.000189} + \frac{1.3}{.000189} \right) \right]}{0.002669(16.4)} = 106.9$$

Example Calculations for Particulate Emissions

Test No. RHS-3

1. Volume of dry gas sampled corrected to standard conditions. Note: V_m must be corrected for leakage if any leakage rates exceed 1_a .)

$$V_{mstd} = 17.65 \times V_m \times Y \left[\frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right] =$$

$$V_{mstd} = 17.65 \times 55.203 \times (.995) \left[\frac{28.4 + \frac{1.2}{13.6}}{551} \right] = 50.123$$

2. Volume of water vapor at standard conditions, ft^3 .

$$V_{wstd} = 0.04707 V_{1c} =$$

$$V_{wstd} = 0.04707 \times 19.2 = 0.904$$

3. Moisture content in stack gas.

$$B_{ws} = \frac{V_{wcstd}}{V_{mstd} + V_{wcstd}} = B_{ws} = \frac{0.904}{50.123 + 0.904} = 0.018$$

4. Dry molecular weight of stack gas.

$$M_d = 0.440 (\% CO_2) + 0.320 (\% O_2) + 0.280 (\% N_2 + \% CO) =$$

$$M_d = 0.440 (0.0) + 0.320 (21) + 0.280 (79) = 28.84$$

5. Molecular weight of stack gas

$$M_s = M_d (1 - B_{ws}) + 18 B_{ws} =$$

$$M_s = 28.84 (1 - .018) + 18(.018) = 28.64$$

6. Stack velocity at stack conditions, fps

$$V_s = 85.49 \times C_p \times \sqrt{\Delta p_{avg}} \times \sqrt{\frac{T_s}{P_s M_s}} =$$

RHS-3

$$V_s = 85.49 \times .84 \times (1.04) \times \sqrt{\frac{563}{28.45 \times 28.64}} = 62.08$$

7. Stack gas volumetric flow rate at stack conditions, cfh

$$Q_s = 3600 \times V_s \times A_s$$

$$Q_s = 60 \times 62.08 \times 12 = 44,698 \text{ ACFM}$$

8. Dry stack gas volumetric flow rate at standard conditions, cfh.

$$Q_{sstd} = 17.65 Q_s \frac{P_s}{T_s} (1 - B_{ws}) = \text{SCFM} \times 60 = \text{SCFH}$$

$$Q_{std} = 17.65 \times 44,698 \times \frac{28.45}{563} \times (1 - .018) = 39,149 \times 60 = 2,348,940$$

9. Concentration in g/scf

$$C'_s = 0.001 \text{ g/mg} \frac{M_n}{V_{nstd}} = 0.001 \times \frac{30.2}{50.123} = 0.00060$$

$$0.00060 \times 15.43 = 0.009 \text{ gr/dscf}$$

10. Particulate mass emission rate, lbs/hr.

$$\text{pmr} = \frac{C_s \times Q_{sstd}}{454} = \frac{0.00060 \times 2,348,940}{454} = 3.1 \text{ lb/hr}$$

11. Isokinetic variation

$$I = 100 \frac{T_s}{T_n} \left[\frac{V_1}{V_s} \frac{P_s}{P_n} \frac{A_n}{A_s} + \frac{\Delta H}{13.6} \right]$$

$$I = 100 \frac{563}{551} \left[\frac{0.002669(19.2)}{60 \times 75 \times 62.08 \times 28.45 \times .000189} + \frac{1.2}{13.6} \right] = 109.3$$

Formula,

$A = 0.76E^{0.42}$, where:

A = Allowable emissions in pounds per hour

E = Emission index = F x W pounds per hour

E = Process factor in pounds per unit, and

W = Production or charging rate in units per hour

F = 20 lbs/ton

W = Tons/hr

Test No. 1

$$A = 0.76 (20 \times 150)^{0.42} = 21.9 \text{ lbs/hr}$$

Test No. 2

$$A = 0.76 (20 \times 145)^{0.42} = 21.6 \text{ lbs/hr}$$

Test No. 3

$$A = 0.76 (20 \times 148)^{0.42} = 21.8 \text{ lbs/hr}$$

B. SAMPLING METHODOLOGY & EQUIPMENT CALIBRATION

B. SAMPLING METHODOLOGY & EQUIPMENT CALIBRATION

SAMPLE AND VELOCITY TRAVERSES FOR STATIONARY SOURCES EPA METHOD 1

The following method was used in this test program. Sampling procedures follow those described in EPA Method 1 of the Federal Register*.

SELECTION OF THE MEASUREMENT SITE

The velocity measurement were taken at (**) stack (or duct) diameters downstream and (**) diameters upstream from any flow disturbances.

CHOOSING THE NUMBER OF TRAVERSE POINTS (non-Cyclonic flow)

Particulate Traverse Sampling

At least twelve (12) traverse points were sampled for circular (or rectangular) stack diameters greater than .61 meters. At least eight (8) traverse points were sampled for circular stacks and nine (9) points for rectangular stacks for equivalent diameters for .30 to .61 meters. For other stack diameters, Figure 1-1 was referred to.

Non-Particulate Traverse Sampling

The above procedure was used except that Figure 1-2 is substituted for Figure 1-1.

CROSS SECTIONAL TRAVERSE POINT LOCATIONS

The traverse points were located on two (2) perpendicular diameters. For particulate traverse samples, on of the above diameters was positioned in the plane containing the greatest concentration variation.

Circular Stacks

EPA Method 1, Figure 1-3 and Table 1-2 was referred to.

Rectangular Stacks

Using Figure 1-4 and Table 1-1 a rectangular grid, sectioned into as many equal areas as there are traverse points, was constructed. A sample was taken at the center of each elemental area in the grid.

No traverse points were located within 2.5 centimeters of the stack wall for stack diameters greater than .61 meters. For stack diameters equal to or less than .61 meters, no traverse points were located within 1.3 centimeters. For both of the above cases, where the sample nozzle inside diameter was greater than the adjusted distances, the larger distance was used.

*Federal Register, CFR 40, Part 60, July 1, 1989

** Check sampling location schematic included.




Figure 1-2. Minimum number of traverse points for particulate traverses.




Figure 1-2. Minimum number of traverse points for velocity (nonparticulate) traverses.

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter--											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.8	43.7	49.4	52.8	55.6	57.9	60.1	62.3	64.5	66.7	68.9	71.1
2	45.6	55.0	64.6	69.6	73.2	75.7	77.9	80.1	82.3	84.5	86.7	88.9
3		65.0	74.6	79.6	83.2	85.7	87.9	90.1	92.3	94.5	96.7	98.9
4			84.3	90.6	94.3	96.7	98.9	100.0	100.0	100.0	100.0	100.0
5				95.6	97.7	99.2	100.0	100.0	100.0	100.0	100.0	100.0
6					98.6	99.6	100.0	100.0	100.0	100.0	100.0	100.0
7						99.6	100.0	100.0	100.0	100.0	100.0	100.0
8							99.6	100.0	100.0	100.0	100.0	100.0
9								99.6	100.0	100.0	100.0	100.0
10									99.6	100.0	100.0	100.0
11										99.6	100.0	100.0
12											99.6	100.0
13												99.6
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												




Figure 1-3. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points indicated.




Figure 1-4. Example showing rectangular stack cross section divided into 12 equal areas, with a traverse point at centroid of each area.

Verification of the Absence of Cyclonic Flow through Stacks

For any stack where there existed a possibility of cyclonic flow, a test for the presence of cyclonic flow was performed using a manometer and Type S pitot tube.

The manometer was leveled and zeroed before the pitot tube was connected to the probe and positioned at each traverse point. The pitot tube was rotated (if necessary) until a null reading was obtained. All rotation angles were assigned absolute values. When no rotation was necessary, a value of 0 degrees was assigned. The values were summed, and the resultant angle called alpha (α). Twenty (20) degrees was the limit of acceptability of the measurement locations for the average value of alpha with a Standard Deviation of ten (10) degrees or less.

A minimum of 24 traverse points for circular ducts and 42 points for rectangular ducts were used in the determination of gas flow angles. When the absence of cyclonic gas flow was verified, these same points were used to obtain velocity measurements.

EPA METHOD 2

DETERMINE OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE
EPA METHOD 2

The average velocity in a stack (or duct) was determined from the gas' density and average velocity head with a Type S pitot tube and stack gas flow was quantified.

SAMPLING APPARATUS

The apparatus consisted of the following equipment:

Pitot Tube - Type S pitot tube that meet all geometry standards was used to monitor stack gas velocity.

Draft Gauge - An inclined manometer made by Dwyer with readability of 0.01 inches H_2O in the 0-1 inch range was used.

Temperature Gauge - Included a thermocouple and digital readout capable of measuring temperatures to within 1.5% of the minimum stack temperatures.

Barometer - A barometer capable of measuring atmospheric pressure to within 2.5 mm Hg.

Gas Density Determination Equipment - Fyrite analyzer.

SAMPLING PROCEDURE

The apparatus was set up as illustrated in Figure 1.

The pretest leak-check was conducted for both the impact and static openings of the Pitot tube.


After adjusting the manometer level and zero, the velocity head and temperature were measured for each traverse point and recorded on the data sheet.

In addition, the static pressure in the stack was measured and the atmospheric pressure recorded.

The stack gas dry molecular weight was determined using EPA Method 3.

The moisture content was obtained using either EPA Method 4 or EPA Method 5.

The cross sectional area of the stack (or duct) at the sampling location was measured and recorded.



EPA Method 2
 Flow Measurement System

EPA METHOD 3

GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR & DRY

GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR AND DRY
MOLECULAR WEIGHT

EPA METHOD 3

The following method was used in this test program. Sampling procedures followed those described in EPA Method 3 of the Federal Register*.

SAMPLING APPARATUS

The gas analysis sampling train used in these tests at the exit stack meet the design specifications established by the Federal EPA and was assembled by Comprehensive Safety Compliance, Inc. (CSC) personnel.

The apparatus consisted of the following:

INTEGRATE SAMPLING: APPARATUS

PROBE - A stainless steel probe equipped with an in-stack or out-stack glass wool filter to remove particulate matter.

PUMP - A leak-free, diaphragm-type pump to transport sample gas to the flexible bag.

CONDENSER - A water-cooled condenser to remove excess moisture.

VALVE - A needle valve to adjust the sample flow rate.

SURGE TANK - A surge tank installed between the pump and rate meter to eliminate the pulsation effect of the diaphragm pump on the rate meter.

RATE METER - A rotameter capable of measuring flow rates to within $\pm 2\%$ of a flow range of 500 to 1000 cubic centimeters per minute.

ORSAT ANALYZER - This combustible gas analyzer was used to determine dry molecular weight (DMW) for O_2 , CO_2 and CO.

*Federal Register, CFR 40, Part 60, July 1, 1989

INTEGRATED SAMPLING

The sample train was set up as shown in Figure No. 1.

For single point sampling the sample point location was at the center of the cross-section or at least 1 meter away from the stack wall. The analyzer leak test was performed, and the flexible bag as well as the sample train was also leak tested.

For multi-point sampling at least eight traverse points were sampled in circular stacks with diameters less than .61 meters (9 points for rectangular stacks of .61 meter equivalent diameter). At least twelve points were sampled for all other cases.

Traverse point location was performed; with respect to EPA Method 1. All points were traversed and sampled for an equal length of time.

After positioning the probe and purging the sample line, the sample bag was connected to the train.

The sample was taken at a constant rate. The run was simultaneous with the lasted the total duration of the pollutant emission rate determination.


One flue gas sample was taken for each pollutant emission rate determination. Within eight hours the samples were analyzed for % CO_2 and O_2 . The % N_2 and CO were determined and the dry molecular weight was calculated.

SAMPLE ANALYSIS


After a sample was drawn into a combustible gas analyzer, it was immediately analyzed for percent CO_2 and O_2 . The percentage of the gas that is N_2 and CO was determined by subtracting the sum of the percents CO_2 and O_2 from 100 percent.

During sample analysis for a given gas, consecutive passes through the analyzer absorbing solutions were made until two consecutive readings were obtained. All values were averaged and recorded to the nearest 0.1%.

The analyzer was leak-tested before and after the analyses was performed.



Grab-sampling train.



EPA Method 3
Gas Composition Sampling Train

CO₂ ANALYSIS

The results of three analyses differ by no more than:

- a) .3% volume when the CO₂ was greater than 4% of the total gas volume.
- b) .2% volume when CO₂ was less than or equal to 4% of the total gas volume.

O₂ ANALYSIS

The analytical procedure was repeated until the results of three analyses differ by no more than:

- a) .3% volume when O₂ was less than or equal to 15% of total gas volume.
- b) .2% by volume when O₂ was greater than or equal to 15% of total gas volume.

CO AND N₂ ANALYSIS

For percent CO and N₂, the analytical procedure was repeated until three analyses differ by no more than .3%.

DETERMINATION OF THE DRY MOLECULAR WEIGHT

The DMW of each sample was determined using the following formula:

$$DMW = 0.440 (\% CO_2) + .322 (\% O_2) + .280 (\% N_2 + \% CO)$$

EMISSION RATE CORRECTION FACTOR OR EXCESS AIR DETERMINATION

An EPA approved combustible gas analyzer was used to determine the excess air content in the stack emissions.

For single point and grab samples, the values obtained for % O₂, CO and N₂ were substituted in the following equation to determine the % excess air:

$$\% EA = \frac{\% O_2 - .5\% CO}{.264\% N_2 - (\% O_2 - .5\% CO)} \times 100\%$$

The fuel factor, F, calculated as follows:

$$F = \frac{20.9 - \% O_2}{\% CO_2}$$

*20.9 = The percent of O₂ by volume in ambient air.

SAMPLING PROCEDURE

After selecting the sampling site and the minimum number of traverse points, the stack pressure and temperature was measured according to the procedures described in the Federal Register*.


Approximately 200 grams of silica gel were weighed in a sealed impinger prior to each test. One-hundred ml of distilled water was placed in each of the first two impingers; the third impinger was initially empty; and the impinger containing the silica gel was placed next in series. The train was set up with the probe as shown in Figure A-1. The sampling train was leak-checked at the sampling site prior to each test run by plugging the inlet to the nozzle and pulling a 15 inch Hg vacuum, and at the conclusion of the test by plugging the inlet to the nozzle and pulling a vacuum equal to the highest vacuum reached during the test run.

Crushed ice was placed around the impingers to keep the temperature of the gases leaving the last impinger at 68 F or less.

During sampling, stack gas and sampling train data were recorded at each sampling point and when significant changes in stack flow conditions occur. All sampling data were recorded on the Field Data Sheet.

*Federal Register, CFR 40, Part 60, July 1, 1989

IMPINGER TRAIN OPTIONAL, MAY BE REPLACED
BY AN EQUIVALENT CONDENSER



Moisture sampling train-reference method.

SAMPLE RECOVERY PROCEDURE

The sampling train was moved carefully from the test site to the cleanup area. Sample fractions were recovered as follows:

1. The volume of water from the first three impingers was measured and recorded on the Recovery Data Sheet.
2. The silica gel from the fourth impinger was weighed and the gain recorded on the Sample Recovery Data Sheet with other pertinent data.

EPA METHOD 5
DETERMINATION OF PARTICULATE EMISSIONS

DETERMINATION OF PARTICULATE EMISSIONS EPA METHOD 5

The following method was used in this test program. Sampling procedures followed those described in Method 5 of the Federal Register*.

SAMPLING APPARATUS

The particulate sampling train used in these tests at the exit stack met design specifications established by the Federal EPA and was assembled by Comprehensive Safety Compliance, Inc. (CSC) personnel. It consisted of:

Nozzle - Stainless steel (316) with sharp, tapered leading edge and accurately measured round opening.

Probe - Glass lined with a heating system capable of maintaining a minimum gas temperature of 250 F at the exit end during sampling.

Filter Holder - Pyrex glass with heating system capable of maintaining a filter temperature of approximately 250 F.

Draft Gauge - An inclined manometer made by Dwyer with readability of 0.01 inches H₂O in the 0-1 inch range was used.

Impingers - Four impingers connected in series with glass ball joints. The first, third and fourth impingers were of the Greensburg-Smith design, modified by replacing the tip with a 1/2 inch I.D. glass tube extending to 1/2 inch from the bottom of the flask.

Metering System - Vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 5°, calibrated dry gas meter, and related equipment, to maintain an isokinetic sampling rate and to determine sample volume. The dry gas meter is made by Rockwell and the fiber vane pump is made by Gast.

Barometer - Aneroid type to measure atmospheric pressures to ± 0.1 inch Hg.

*Federal Register, CFR 40, Part 60, July 1, 1989

SAMPLING PROCEDURE

After selecting the sampling site and the minimum number of traverse points, the sack pressure, temperature, moisture and range of velocity head were measured according to the procedures described in the Federal Register*.

Approximately 200 grams of silica gel was weighed in a sealed impinger prior to each test. Glass fiber filters** (4 inch diameter) were desiccated for at least 24 hours, dried at 105 C for 2 hours and weighed to the nearest 0.1 mg on an analytical balance. One hundred ml of distilled water was placed in each of the first two impingers; the third impinger was initially empty; and the impinger containing the silica gel was placed next in series. The train was set up with the probe as shown in Figure A-1. The sampling train was leak-checked at the sampling site prior to each test run by plugging the inlet to the nozzle and pulling 15 inch Hg vacuum, and at the conclusion of the test by plugging the inlet to the nozzle and pulling a vacuum equal to the highest vacuum reached during the test run.

The pitot tube and line were leak-checked at the test site prior to an following the initial velocity traverse. The check was made by blowing into the impact opening of the pitot tube* until 3 or more inches of water were recorded on the manometer and then capping the impact opening and holding it for 15 seconds to assure it was leak free. The static pressure side of the pitot tube was leak checked using the same procedure, except suction was used to obtain the 3 inch H₂O manometer reading. Crushed ice was placed around the impingers to keep the temperature of the gases leaving the last impinger at 68 F or less.

During sampling, stack gas and sampling train data were recorded at each sampling point and when significant changes in stack flow conditions occurred. Isokinetic sampling rates were set throughout the sampling period with the aid of a nomograph or calculator. All sampling were recorded on the Particulate Field Data Sheet.

* Federal Register, CFR 40, Part 60, July 1, 1989

**934 AH type

SAMPLE RECOVERY PROCEDURE

The sampling train was moved carefully from the test site to the cleanup area. Samples of the acetone and distilled water used in the sample recovery were taken for use as blanks. The volume of water from the first three impingers was measured. Sample fractions were recovered as follows:

Container No. 1 - The filter was removed from its holder and placed in a petri dish and sealed.

Container No. 2 - Loose particulate and H₂O washings from all sample-exposure surface prior to the filter were placed in a sample container, sealed and labelled. Particulate was removed from the probe with the aid of a brush and H₂O rinsing. The liquid level was marked after the container was sealed.

Container No. 3 - Loose particulate and acetone washings from all sample-exposure surface prior to the filter were placed in a sample container, sealed and labeled. Particulate was removed from the probe with the aid of a brush and acetone rinsing. The liquid level was marked after the container was sealed.

Container No. 4 - A minimum of 200 ml of acetone was taken for the blank analysis. The blank was obtained and treated in a similar manner as the acetone washing.

Container No. 5 - Distilled water in the impinger section of the sampling train was measured and placed in a sample container. The impingers and connecting glassware were rinsed with distilled H₂O and this rinse was added to the container for shipment to the laboratory.

Container No. 6 - The impinger section of the sampling train of the connecting glassware was rinsed with acetone and this rinse was put in a container for shipment to the laboratory.

Container No. 7 - A minimum of 200 ml of distilled water was taken for the blank analysis. The blank was obtained and treated in a similar manner as the water rinse.

The silica gel from the fourth impinger was weighed and the gain recorded on the Sample Recovery Data Sheet with other pertinent data.

ANALYTICAL PROCEDURES

The following procedures were used and follow the methods described in the DER Source Testing Manual*.

Container No. 1 - The filter and any loosed particulate matter from this sample container were placed into a tared glass weighing dish, baked at 105 C for 2 hours, desiccated for 24 hours to a constant weight and weighed to the nearest 0.1 mg.

Container No. 2 - The H₂O washings were transferred to a tared beaker and evaporated to dryness at 105 C temperature and pressure, desiccated for 24 hours to a constant weight, and weighed to the nearest 0.1 mg.

Container No. 3 - the acetone washings were transferred to a tared beaker and evaporated to dryness at ambient temperature and pressure, desiccated for 24 hours to a constant weight, and weighed to the nearest 0.1 mg.

Container No. 4 - The acetone blank was transferred to a tared breaker and evaporated to dryness at ambient temperature and pressure. The blank was then desiccated for 24 hours to a constant weight and weighed to the nearest 0.1 mg.

Container No. 5 - The contents of this container were filtered through 0.8-.22 micron tared filters to remove insoluble particulate. The filters and filtrates in tared breakers were evaporated to dryness at 105 C, then desiccated to a constant weight and weighed on an analytical balance to the nearest 0.1 mg.

Container No. 6 - The acetone was transferred to a tared beaker and evaporated to dryness at ambient temperature and pressure. The sample was then desiccated for 24 hours to a constant weight and weighed to the nearest 0.1 mg.

Container No. 7 - The distilled water blank was transferred to a tared beaker and evaporated to dryness at 105 C. The blank was desiccated to a constant weight and weighed on analytical balance to the nearest 0.1 mg.

The term "constant weight" means a difference of no more than 0.5 mg or 1% of total weight less tare weight, whichever is greater between two consecutive readings, with no less than 6 hours of desiccation between weighings.

EPA Method 9
Visual Determination of the
Opacity of Emissions from Stationary Sources

Determination of Opacity of Emissions from
Stationary Sources

EPA Method 9

The following method was used in this test program. Observation procedures follow those described in EPA Method 9 of the Federal Register *.

Observation Procedures

The opacity of emissions from stationary sources was determined visually by a qualified observer. The qualified observer stood at a distance sufficient to provide a clear view of the emissions with the sun oriented in the 140 sector to his back. Consistent with maintaining the above requirement, the observer made his observations from a position such that his line of vision was approximately perpendicular to the plume direction, and approximately perpendicular to the longer axis of the outlet. The observer recorded the name of the plant, emissions location, type facility, observer's name and affiliation, a sketch of the observer's position relative to the source, and the date on a field data sheet (Figure 1). The time, estimated distance to the emission location, approximate wind direction, estimated wind speed, description of the sky condition (presence and color of clouds), and plume background were recorded on a field data sheet at the time opacity readings were taken.

Opacity observations were made at the point of greatest opacity in the portion of the plume where condensed water vapor was not present. The observer did not look continuously at the plume, but momentarily at 15-seconds intervals.

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME			
ADDRESS			SEC MIN	0	15	30	45	SEC MIN	0	15	30	45
			1					31				
			2					32				
CITY	STATE	ZIP	3					33				
PHONE	SOURCE ID NUMBER		4					34				
PROCESS EQUIPMENT		OPERATING MODE	5					35				
CONTROL EQUIPMENT		OPERATING MODE	6					36				
			7					37				
DESCRIBE EMISSION POINT			8					38				
START		STOP	9					39				
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER	10					40				
START		STOP	11					41				
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER	12					42				
START		STOP	13					43				
DESCRIBE EMISSIONS			14					44				
START		STOP	15					45				
EMISSION COLOR		PLUME TYPE: CONTINUOUS ☐	16					46				
START		STOP	17					47				
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME	18					48				
NO ☐ YES ☐		ATTACHED ☐ DETACHED ☐	19					49				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			20					50				
START		STOP	21					51				
DESCRIBE BACKGROUND			22					52				
START		STOP	23					53				
BACKGROUND COLOR		SKY CONDITIONS	24					54				
START		STOP	25					55				
WIND SPEED		WIND DIRECTION	26					56				
START		STOP	27					57				
AMBIENT TEMP.		WET BULB TEMP.	28					58				
START		STOP	29					59				
			30					60				
Source Layout Sketch			AVERAGE OPACITY FOR HIGHEST PERIOD									
Draw North Arrow			NUMBER OF READINGS ABOVE % WERE									
			RANGE OF OPACITY READINGS									
			MINIMUM MAXIMUM									
			OBSERVER'S NAME (PRINT)									
COMMENTS			OBSERVER'S SIGNATURE						DATE			
			ORGANIZATION									
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS			CERTIFIED BY						DATE			
SIGNATURE			VERIFIED BY						DATE			
TITLE												

If condensed water vapor was present within the plume as it emerged from the emission outlet, opacity observations were made beyond the point in the plume at which condensed water vapor was no longer visible. The observer recorded the approximate distance from the emission outlet to the point in the plume at which the observations were made.

If water vapor in the plume condensed and became visible at a distinct distance from the emission outlet, the opacity of emissions were evaluated at the emission outlet prior to the condensation of water vapor and the formation of the steam plume.

Opacity observations were recorded to the nearest 5 percent at 15-second intervals on an observational record sheet (Figure 1). A minimum of 24 observations were recorded. Each momentary observation recorded was deemed to represent the average opacity of emissions for a 15-second period.

Opacity was determined as an average of 24 consecutive observations recorded at 15-second intervals. The observations recorded on the record sheet were divided into sets of 24 consecutive observations. A set was composed of any 24 consecutive observations. For each set of 24 observations, the average was calculated by summing the opacity of the 24 observations and dividing this sum by 24.

To receive certification as a qualified observer, a candidate was tested and demonstrated the ability to assign opacity readings in 5 percent increments to 25 different black plumes and 25 different white plumes, with an error not to exceed 15 percent opacity on any one reading and an average error not exceed 7.5 percent opacity in each category.

The certification is valid for a period of 6 months, at which time the qualification procedure must be repeated by any observer in order to retain certification. The certification test consists of showing the candidate a complete run of 50 plumes-25 black plumes and 25 white plumes-generated by a smoke generator. Plumes within each set of 25 black and 25 white runs were presented in random order. The candidate assigned an opacity value to each plume and recorded his observation on a suitable form. At the completion of each run of 50 readings, the score of the candidate was determined. If a candidate failed to qualify, the complete run of 50 readings was repeated in any retest. The smoke test was administered as part of a smoke school and was preceded by training of familiarization runs of the smoke generator during which candidates were shown black and white plumes of known opacity.

METER BOX CALIBRATION DATA AND CALCULATION FORM

Date 8/2/90

Meter box number 443

Barometric pressure, $P_b =$ 28.9 in. Hg Calibrated by John Kennedy

Orifice manometer setting (ΔH), in. H_2O	Gas volume		Temperatures				Time (θ), min	Y_i	$\Delta H @$ in. H_2O
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Inlet (t_{d_i}), °F	Outlet (t_{d_o}), °F	Avg ^a (t_d), °F			
0.5	5	920.400 926.150	72°F	108 120	79 83	97	12.10	.996	
1.0	5	926.260 931.560	73°F	122 103	88 91	101	8.14	.990	
1.5	10	935.000 945.227	73°F	133 105	92 79	102	13.00	1.017	
2.0	10	945.992 956.195	73°F	111 115	80 89	97	8.30	.994	
3.0	10	956.939 967.278	73°F	111 140	85 90	106	10.00	.998	
4.0	10	968.026 978.609	73°F	112 140	86 90	107	8.39	.993	
							Avg	.998	

ΔH , in. H_2O	ΔH 13.6	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H @_i = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	$\frac{5 (28.9) (533)}{926.15 (28.97) (533)} = .996$	
1.0	0.0737	$\frac{5 (28.97) (533)}{931.56 (28.97) (533)} = .990$	
1.5	0.110	$\frac{10 (28.97) (533)}{945.227 (28.97) (533)} = 1.017$	
2.0	0.147	$\frac{10 (28.97) (533)}{956.195 (28.97) (533)} = .994$	
3.0	0.221	$\frac{10 (28.97) (533)}{967.278 (28.97) (533)} = .998$	
4.0	0.294	$\frac{10 (28.97) (533)}{978.609 (28.97) (533)} = .993$	

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d .

POSTTEST DRY GAS METER CALIBRATION DATA FORM

Date 9-10-90

Meter box number 443

Plant

Pretest Y .995

Test numbers

Barometric pressure, P_b - 29.40 in. Hg

Orifice manometer setting, (ΔH), in. H ₂ O	Gas volume		Temperature		Time (ϕ), min	Vacuum setting, in. Hg	Y_1	$V_d P_b (t_d + 460)$ $V_d P_b + \frac{\Delta H}{13.6}$ 10 (29.4) 568
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Dry gas meter Inlet Outlet Average (t_d), (t_d), (t_d), °F °F °F				
2"	10	10.667	72	113.4 89.9 108	12.52	2"	.996	10.667(29.4 + 460) 10 (29.4) 568
2"	10	10.704	72	114.3 89.9 109	12.54	2"	.994	10.704(29.4 + 460) 10 (29.4) 568
2"	10	10.757	72	124.3 90.4 112	12.56	2"	.994	10.757(29.4 + 460) 10 (29.4) 568
							$Y = .995$	

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d .

V_w = Gas volume passing through the wet test meter, ft³.

V_d = Gas volume passing through the dry gas meter, ft³.

t_w = Temperature of the gas in the wet test meter, °F.

t_{d1} = Temperature of the inlet gas of the dry gas meter, °F.

t_{d0} = Temperature of the outlet gas of the dry gas meter, °F.

t_d = Average temperature of the gas in the dry gas meter, obtained by the average of t_{d1} and t_{d0} .

ΔH = Pressure differential across orifice, in H₂O.

Y_1 = Ratio of accuracy of wet test meter to dry gas meter for each run.

Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs.

P_b = Barometric pressure, in. Hg.




ϕ = Time of calibration run, min.

PITOT TUBE INSPECTION DATA SHEET

Pitot Tube Identification Number: #6

Date: 2/22/90

1. What is the external diameter of the tubing in inches?
3/8"
2. Are the face opening planes perpendicular to the transverse axis as in Figure A (end view)? yes
3. Are the face opening planes parallel to the longitudinal axis as in Figure B (top view)? yes
4. Are both legs of equal length and center lines coincident, when viewed from both sides as in Figure (C)? yes
5. Does the tube meet all the geometric specifications to be assigned a .84 coefficient? yes



CALIBRATED BY: Kevin Kennedy

NOZZLE CALIBRATION DATA FORM

Parte

calibrated by

Nozzle identification number	D_1 (in.)	D_2 (in.)	D_3 (in.)	ΔD (in.)	D_{avg}
# 7	.186	.186	.186	0.0	.186

where:

D_{1,2,3} = Three different nozzles diameters, in.; each diameter measure within 0.001 in.

AD = Maximum difference between any two diameters, in.,
AD < 0.004 in.

$$D_{avg} = \text{Average of } D_1, D_2, \text{ and } D_3.$$

C. FIELD DATA SHEETS

Visible Emission Observation Form

SOURCE NAME		OBSERVATION DATE				START TIME				STOP TIME			
ADDRESS		SEC				SEC							
		MIN	0	15	30	45	MIN	0	15	30	45		
Commercial Stone		1	0	0	5	5	31	0	0	0	0		
Richhill		2	0	0	0	0	32	0	0	0	0		
CITY	STATE PA ZIP	3	0	0	0	0	33	0	0	0	0		
PHONE	SOURCE ID NUMBER	4	0	0	0	0	34	0	0	0	0		
PROCESS EQUIPMENT	OPERATING MODE	5	0	0	0	0	35	0	0	0	0		
CONTROL EQUIPMENT	OPERATING MODE	6	5	0	0	0	36	0	0	0	0		
DESCRIBE EMISSION POINT		7	0	0	0	0	37	0	0	0	0		
START	STOP	8	0	0	0	0	38	0	0	0	0		
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER	9	0	0	0	0	39	0	0	0	0		
START 20' STOP 20'	START 15' STOP 15'	10	0	0	0	0	40	0	0	0	0		
DISTANCE FROM OBSERVER	DIRECTION FROM OBSERVER	11	5	5	5	5	41	0	0	0	0		
START 30' STOP 30'	START SW STOP	12	0	0	0	0	42	0	0	0	0		
DESCRIBE EMISSIONS		13	0	0	0	0	43	0	0	0	0		
START	STOP	14	0	0	0	0	44	0	0	0	0		
EMISSION COLOR	PLUME TYPE: CONTINUOUS ☐	15	0	0	0	0	45	0	0	0	0		
START STOP	FUGITIVE ☐ INTERMITTENT ☐	16	0	0	0	0	46	0	0	0	0		
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME	17	0	0	0	0	47	0	0	0	0		
NO ☒ YES ☐	ATTACHED ☐ DETACHED ☐	18	0	0	0	0	48	0	0	0	0		
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED		19	0	0	0	0	49	0	0	0	0		
START	STOP	20	0	0	0	0	50	0	0	0	0		
DESCRIBE BACKGROUND		21	0	0	0	0	51	0	0	0	0		
START Cloudy SKY STOP	STOP	22	0	0	0	0	52	0	0	0	0		
BACKGROUND COLOR	SKY CONDITIONS	23	0	0	0	0	53	0	0	0	0		
START GRAY STOP	START Cloud STOP	24	0	0	0	0	54	0	0	0	0		
WIND SPEED	WIND DIRECTION	25	0	0	0	0	55	0	0	0	0		
START 0 - 5 mph STOP	START NE STOP	26	0	0	0	0	56	0	0	0	0		
AMBIENT TEMP	WET BULB TEMP	27	0	0	0	0	57	0	0	0	0		
START 65°F STOP	REL percent	28	0	0	0	0	58	0	0	0	0		
Source Layout Sketch		29	0	0	0	0	59	0	0	0	0		
Draw North Arrow		30	0	0	0	0	60	0	0	0	0		
		AVERAGE OPACITY FOR HIGHEST PERIOD				NUMBER OF READINGS ABOVE % WERE							
		RANGE OF OPACITY READINGS				MINIMUM MAXIMUM							
COMMENTS		OBSERVER'S NAME (PRINT)				OBSERVER'S SIGNATURE							
TEST-1		Kevin Kennedy				DATE 8/28/90							
		ORGANIZATION				DATE							
		CSC Inc.				DATE							
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS		CERTIFIED BY				DATE							
SIGNATURE		DATE				DATE							
TITLE		VERIFIED BY				DATE							

Visible Emission Observation Form

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME					
ADDRESS			SEC	MIN	0	15	30	45	SEC	MIN	0	15	30	45
Commercial Stone			9	12	00				9	25				
Rich Hill														
CITY	STATE	ZIP	1	0	0	0	0	0	31					
PHONE	SOURCE ID NUMBER		2	0	0	0	0	0	32					
PROCESS EQUIPMENT	OPERATING MODE		3	0	0	0	0	0	33					
CONTROL EQUIPMENT	OPERATING MODE		4	0	0	0	0	0	34					
DESCRIBE EMISSION POINT			5	0	0	0	0	0	35					
START	STOP		6	0	0	0	0	0	36					
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER		7	0	0	0	0	0	37					
START 20' STOP 20'	START 15' STOP 15'		8	0	0	0	0	0	38					
DISTANCE FROM OBSERVER	DIRECTION FROM OBSERVER		9	0	0	0	0	0	39					
START 30' STOP	START S W STOP		10	0	0	0	0	0	40					
DESCRIBE EMISSIONS			11	0	0	0	0	0	41					
START None STOP	STOP		12	0	0	0	0	0	42					
EMISSION COLOR	PLUME TYPE: CONTINUOUS ☐		13	0	0	0	0	0	43					
START STOP	FUGITIVE ☐ INTERMITTENT ☐		14	0	0	0	0	0	44					
WATER DROPLETS PRESENT: NO ☐ YES ☐	IF WATER DROPLET PLUME: ATTACHED ☐ DETACHED ☐		15	0	0	0	0	0	45					
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			16	0	0	0	0	0	46					
START STOP	STOP		17	0	0	0	0	0	47					
DESCRIBE BACKGROUND			18						48					
START Clear Sky STOP	STOP		19						49					
BACKGROUND COLOR	SKY CONDITIONS		20						50					
START GRAY STOP	START Clear STOP		21						51					
WIND SPEED	WIND DIRECTION		22						52					
START 0-5 mph STOP	START NW STOP		23						53					
AMBIENT TEMP	WET BULB TEMP RH, percent		24						54					
START 65°F STOP			25						55					
Source Layout Sketch			26						56					
Draw North Arrow			27						57					
			28						58					
			29						59					
			30						60					
AVERAGE OPACITY FOR HIGHEST PERIOD			NUMBER OF READINGS ABOVE % WERE											
RANGE OF OPACITY READINGS			MINIMUM				MAXIMUM							
OBSERVER'S NAME (PRINT)			Kevin Kennedy											
OBSERVER'S SIGNATURE			Kevin Kennedy				DATE 8/22/90							
ORGANIZATION			CSC Inc.											
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS			CERTIFIED BY				DATE							
SIGNATURE			ETA				March 1990							
TITLE			VERIFIED BY				DATE							

Visible Emission Observation Form

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME			
ADDRESS			MIN				MIN		MIN			
CITY			0 15 30 45				0 15 30 45		0 15 30 45			
STATE			0 15 30 45				0 15 30 45		0 15 30 45			
ZIP			0 15 30 45				0 15 30 45		0 15 30 45			
PHONE			0 15 30 45				0 15 30 45		0 15 30 45			
SOURCE ID NUMBER			0 15 30 45				0 15 30 45		0 15 30 45			
PROCESS EQUIPMENT			0 15 30 45				0 15 30 45		0 15 30 45			
OPERATING MODE			0 15 30 45				0 15 30 45		0 15 30 45			
CONTROL EQUIPMENT			0 15 30 45				0 15 30 45		0 15 30 45			
OPERATING MODE			0 15 30 45				0 15 30 45		0 15 30 45			
DESCRIBE EMISSION POINT			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
HEIGHT ABOVE GROUND LEVEL			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
DISTANCE FROM OBSERVER			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
DIRECTION FROM OBSERVER			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
DESCRIBE EMISSIONS			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
EMISSION COLOR			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
PLUME TYPE: CONTINUOUS ☐			0 15 30 45				0 15 30 45		0 15 30 45			
FUGITIVE ☐ INTERMITTENT ☐			0 15 30 45				0 15 30 45		0 15 30 45			
WATER DROPLETS PRESENT			0 15 30 45				0 15 30 45		0 15 30 45			
NO ☐ YES ☐			0 15 30 45				0 15 30 45		0 15 30 45			
IF WATER DROPLET PLUME			0 15 30 45				0 15 30 45		0 15 30 45			
ATTACHED ☐ DETACHED ☐			0 15 30 45				0 15 30 45		0 15 30 45			
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
DESCRIBE BACKGROUND			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
BACKGROUND COLOR			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
SKY CONDITIONS			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
WIND SPEED			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
WIND DIRECTION			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
AMBIENT TEMP			0 15 30 45				0 15 30 45		0 15 30 45			
START			0 15 30 45				0 15 30 45		0 15 30 45			
STOP			0 15 30 45				0 15 30 45		0 15 30 45			
WET BULB TEMP.			0 15 30 45				0 15 30 45		0 15 30 45			
RH, percent			0 15 30 45				0 15 30 45		0 15 30 45			
1	0	0	0	0	0	31	0	0	0	0		
2	0	0	0	0	0	32	0	0	0	0		
3	0	0	0	0	0	33	0	0	0	0		
4	0	0	0	0	0	34	0	0	0	0		
5	0	0	0	0	0	35	0	0	0	0		
6	0	0	0	0	0	36	0	0	0	0		
7	0	0	0	0	0	37	0	0	0	0		
8	0	0	0	0	0	38	0	0	0	0		
9	0	0	0	0	0	39	0	0	0	0		
10	0	0	0	0	0	40	0	0	0	0		
11	0	0	0	0	0	41	0	0	0	0		
12	0	0	0	0	0	42	0	0	0	0		
13	0	0	0	0	0	43	0	0	0	0		
14	0	0	0	0	0	44	0	0	0	0		
15	0	0	0	0	0	45	0	0	0	0		
16	0	0	0	0	0	46	0	0	0	0		
17	0	0	0	0	0	47	0	0	0	0		
18	0	0	0	0	0	48	0	0	0	0		
19	0	0	0	0	0	49	0	0	0	0		
20	0	0	0	0	0	50	0	0	0	0		
21	0	0	0	0	0	51	0	0	0	0		
22	0	0	0	0	0	52	0	0	0	0		
23	0	0	0	0	0	53	0	0	0	0		
24	0	0	0	0	0	54	0	0	0	0		
25	0	0	0	0	0	55	0	0	0	0		
26	0	0	0	0	0	56	0	0	0	0		
27	0	0	0	0	0	57	0	0	0	0		
28	0	0	0	0	0	58	0	0	0	0		
29	0	0	0	0	0	59	0	0	0	0		
30	0	0	0	0	0	60	0	0	0	0		
AVERAGE OPACITY FOR HIGHEST PERIOD			0 15 30 45				0 15 30 45					
NUMBER OF READINGS ABOVE % WERE			0 15 30 45				0 15 30 45					
RANGE OF OPACITY READINGS			0 15 30 45				0 15 30 45					
MINIMUM			0 15 30 45				0 15 30 45					
MAXIMUM			0 15 30 45				0 15 30 45					
OBSERVER'S NAME (PRINT)			Kevin Kennedy				DATE 8/22/90					
OBSERVER'S SIGNATURE			[Signature]				DATE 8/22/90					
ORGANIZATION			CSC Inc.				DATE 8/22/90					
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS			CERTIFIED BY ETA				DATE MARCH 1990					
SIGNATURE			[Signature]				DATE					
TITLE			DATE				DATE					

Visible Emission Observation Form

SOURCE NAME		OBSERVATION DATE				START TIME		STOP TIME					
ADDRESS		MIN	SEC	0	15	30	45	MIN	SEC	0	15	30	45
Commercial Store		8	22	19				12	00				
Rich Hill													
CITY	STATE	ZIP											
PHONE	SOURCE ID NUMBER												
PROCESS EQUIPMENT	OPERATING MODE												
CONTROL EQUIPMENT	OPERATING MODE												
DESCRIBE EMISSION POINT													
START													
STOP													
HEIGHT ABOVE GROUND LEVEL													
HEIGHT RELATIVE TO OBSERVER													
START													
STOP													
DISTANCE FROM OBSERVER													
DIRECTION FROM OBSERVER													
START													
STOP													
DESCRIBE EMISSIONS													
START													
STOP													
EMISSION COLOR													
PLUME TYPE: CONTINUOUS ☐													
FUGITIVE ☐ INTERMITTENT ☐													
WATER DROPLETS PRESENT: ☐													
IF WATER DROPLET PLUME: ☐													
ATTACHED ☐ DETACHED ☐													
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED													
START													
STOP													
DESCRIBE BACKGROUND													
START													
STOP													
BACKGROUND COLOR													
SKY CONDITIONS													
START													
STOP													
WIND SPEED													
WIND DIRECTION													
START													
STOP													
AMBIENT TEMP.													
WET BULB TEMP.													
RH, percent													
START													
STOP													
Source Layout Sketch			Draw North Arrow										
Sun $\odot$ Wind $\rightarrow$ Plume and Stack Emission Point Observer's Position Sun Location Line													
AVERAGE OPACITY FOR HIGHEST PERIOD			NUMBER OF READINGS ABOVE % WERE										
RANGE OF OPACITY READINGS			MINIMUM MAXIMUM										
OBSERVER'S NAME (PRINT)			OBSERVER'S SIGNATURE										
OBSERVER'S SIGNATURE			DATE										
ORGANIZATION			OBSERVER'S SIGNATURE										
OBSERVER'S SIGNATURE			DATE										
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS			CERTIFIED BY										
SIGNATURE			VERIFIED BY										
TITLE			DATE										

Visible Emission Observation Form

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME			
ADDRESS			SEC				SEC					
			MIN	0	15	30	45	MIN	0	15	30	45
CITY			1	0	0	0	0	31	0	0	0	0
STATE			2	0	0	0	0	32	0	0	0	0
ZIP			3	0	0	0	0	33	0	0	0	0
PHONE			4	0	0	0	0	34	0	0	0	0
SOURCE ID NUMBER			5	0	0	0	0	35	0	0	0	0
PROCESS EQUIPMENT			6	0	0	0	0	36	0	0	0	0
OPERATING MODE			7	0	0	0	0	37	0	0	0	0
CONTROL EQUIPMENT			8	0	0	0	0	38	0	0	0	0
OPERATING MODE			9	0	0	0	0	39	0	0	0	0
DESCRIBE EMISSION POINT			10	0	0	0	0	40	0	0	0	0
START			11	0	0	0	0	41	0	0	0	0
STOP			12	0	0	0	0	42	0	0	0	0
HEIGHT ABOVE GROUND LEVEL			13	0	0	0	0	43	0	0	0	0
START			14	0	0	0	0	44	0	0	0	0
STOP			15	0	0	0	0	45	0	0	0	0
HEIGHT RELATIVE TO OBSERVER			16	0	0	0	0	46	0	0	0	0
START			17	0	0	0	0	47	0	0	0	0
STOP			18	0	0	0	0	48	0	0	0	0
DISTANCE FROM OBSERVER			19	0	0	0	0	49	0	0	0	0
START			20	0	0	0	0	50	0	0	0	0
STOP			21	0	0	0	0	51	0	0	0	0
DIRECTION FROM OBSERVER			22	0	0	0	0	52	0	0	0	0
START			23	0	0	0	0	53	0	0	0	0
STOP			24	0	0	0	0	54	0	0	0	0
DESCRIBE EMISSIONS			25	0	0	0	0	55	0	0	0	0
START			26	0	0	0	0	56	0	0	0	0
STOP			27	0	0	0	0	57	0	0	0	0
EMISSION COLOR			28	0	0	0	0	58	0	0	0	0
START			29	0	0	0	0	59	0	0	0	0
STOP			30	0	0	0	0	60	0	0	0	0
PLUME TYPE: CONTINUOUS ☒			AVERAGE OPACITY FOR HIGHEST PERIOD									
FUGITIVE ☐ INTERMITTENT ☐												
WATER DROPLETS PRESENT: NO ☒ YES ☐			NUMBER OF READINGS ABOVE % WERE									
IF WATER DROPLET PLUME ATTACHED ☐ DETACHED ☐												
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			RANGE OF OPACITY READINGS MINIMUM MAXIMUM									
START												
STOP			OBSERVER'S NAME (PRINT)									
DESCRIBE BACKGROUND												
START			OBSERVER'S SIGNATURE									
STOP												
BACKGROUND COLOR			DATE									
SKY CONDITIONS												
START			ORGANIZATION									
STOP												
WIND SPEED			CERTIFIED BY									
WIND DIRECTION												
START			DATE									
STOP												
AMBIENT TEMP.			VERIFIED BY									
WET BULB TEMP.												
RH. percent			DATE									
START												
STOP			DATE									
Source Layout Sketch												
Draw North Arrow												
			COMMENTS: TEST-3 OBSERVER'S SIGNATURE: [Signature] ORGANIZATION: ESC INC. CERTIFIED BY: [Signature] VERIFIED BY: [Signature]									
X Emission Point Sun - Wind - Plume and Stack Observers Position Sun Location Line												

Visible Emission Observation Form

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME			
Commercial Stone			8/22/90				2:25		3:35			
ADDRESS			Rich Hill									
CITY			STATE		ZIP							
PHONE			SOURCE ID NUMBER									
PROCESS EQUIPMENT			OPERATING MODE									
CONTROL EQUIPMENT			OPERATING MODE									
DESCRIBE EMISSION POINT												
START			STOP									
HEIGHT ABOVE GROUND LEVEL			HEIGHT RELATIVE TO OBSERVER									
START			STOP									
DISTANCE FROM OBSERVER			DIRECTION FROM OBSERVER									
START			STOP									
DESCRIBE EMISSIONS												
START			STOP									
EMISSION COLOR			PLUME TYPE: CONTINUOUS ☐ FUGITIVE ☐ INTERMITTENT ☐									
START			STOP									
WATER DROPLETS PRESENT			IF WATER DROPLET PLUME: ATTACHED ☐ DETACHED ☐									
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED												
START			STOP									
DESCRIBE BACKGROUND												
START			STOP									
BACKGROUND COLOR			SKY CONDITIONS									
START			STOP									
WIND SPEED			WIND DIRECTION									
START			STOP									
AMBIENT TEMP			WET BULB TEMP. RH percent									
START			STOP									
Source Layout Sketch			Draw North Arrow									
AVERAGE OPACITY FOR HIGHEST PERIOD			NUMBER OF READINGS ABOVE % WERE									
RANGE OF OPACITY READINGS			MINIMUM MAXIMUM									
OBSERVER'S NAME (PRINT)			Kevin Kennedy									
OBSERVER'S SIGNATURE			DATE 8/22/90									
ORGANIZATION			CS, INC.									
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS			CERTIFIED BY									
SIGNATURE			DATE March 1990									
TITLE			DATE									

PLANT Koch Mill (Cm. S. 100)
 LOCATION SANDS Pile Stack
 OPERATOR Rock Campbell
 DATE 8/22/90
 RUN NO. RHS-1
 SAMPLE BOX NO. H 443
 METER BOX NO.
 METER A/D KC-121
 CFACOR
 HITOT TIME COEFFICIENT, 0.84

BAROMETRIC PRESSURE 28.4
 ASSUMED MOISTURE, % 2%
 PROBE LENGTH, (in) 47
 NOZZLE IDENTIFICATION NO. 186
 AVERAGE CALIBRATED NOZZLE DIAMETER, (in) 2.50
 PROBE HEATER SETTING 6.0 at 87.14
 LEAK RATE, (in) 6.125
 PROBE LINE MATERIAL 100051
 STATIC PRESSURE, (in) 4.70
 FILTER NO. 100051

SCHEMATIC OF STACK CROSS SECTION
 Location
 Section dimension:

TRAVERSE POINT NUMBER	TIME	SAMPLING TIME (in. min.)	VACUUM (in. Hg)	STACK TEMPERATURE (°F)	VELOCITY HEAD (in. Hg)	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (in. Hg)	GAS SAMPLE VOLUME (in.)	GAS SAMPLE TEMPERATURE - AT ORIFICE METER		TEMPERATURE OF GAS LEAVING OR CONDENSER OR LAST IMPINGER
								INLET (°F)	OUTLET (°F)	
A-1	0125	3.5	3.5	68	1.2	1.45	66.7	64	64	250
2		7.0	3.5	73	1.1	1.30	66.7	63	63	250
3		10.5	3.5	74	.95	1.10	66.7	64	64	258
4		14.0	3.0	71	.80	0.98	66.7	64	64	259
5		17.5	2.0	72	.75	0.90	66.7	64	64	251
B-1	0147	21.0	3.5	72	1.7	2.10	66.7	64	64	256
2		24.5	3.0	72	1.4	1.70	66.7	64	64	258
3		28.0	3.0	72	1.3	1.60	66.7	64	64	256
4		31.5	3.5	73	1.7	2.10	66.7	64	64	258
5		35.0	4.0	74	1.8	2.20	66.7	64	64	256
C-1	0157	38.5	4.5	72	1.9	2.20	66.7	64	64	250
2		42.0	5.0	72	1.9	2.30	66.7	64	64	257
3		45.5	5.0	71	1.9	2.20	66.7	64	64	259
4		49.0	4.0	71	1.5	1.80	66.7	64	64	261
5		52.5	4.0	71	1.5	1.80	66.7	64	64	260
D-1	0203	56.0	4.0	71	1.4	1.70	66.7	64	64	264
2		59.5	4.0	71	1.5	1.80	66.7	64	64	265
3		63.0	3.5	71	1.2	1.40	66.7	64	64	266
TOTAL										
AVERAGE		37.5		72	1.15	1.6	67.94			

6-053

INTRINSIC WATER
 Final 21.9 ml
 Initial 200 ml
 Cond. 10 ml

DESICCANT
 Final 21.9 gms
 Initial 20.1 gms
 Cond. 16.3 gms

ORSAT ANALYSIS
 Time
 Wt %
 Vol %

[illegible][illegible][illegible][illegible]

PLAN: 7-11 SA Std
 LOCAL: 7-11 SA Std
 OPERATOR: R. Campbell
 DATE: 8/22/40
 RUN NO.: 215-2
 SAMPLE BOX NO.: 4143
 METER BOX NO.: 4143
 METER ANG: 4143
 C FACTOR: 2.84
 FLOW TUBE COEFFICIENT, C₂: 2.84

AMBIENT TEMPERATURE: 73°
 BAROMETRIC PRESSURE: 29.6
 ASSUMED HUMIDITY, %: 73
 PROBE LENGTH, (in): 57
 NOZZLE IDENTIFICATION NO.: 191
 AVERAGE CALIBRATED NOZZLE DIAMETER, (in): 0.0148
 PROBE HEATER SETTING: 610.53
 LEAK RATE, (l/min): 4.70
 PROBE LINE MATERIAL: 1000 52
 STATIC PRESSURE, (in. Hg): 1000 52
 FILTER NO.: 1000 52

SCHEMATIC OF STACK CROSS SECTION
 Location: Stack
 Stack diam.: 1000 52

TRAVERSE POINT NUMBER	TIME (hr, min)	SAMPLING TIME (hr, min)	VACUUM (in. Hg)	STACK TEMPERATURE (°F)	VELOCITY HEAD (in. Hg)	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (in. Hg)	GAS SAMPLE VOLUME (ft ³)	GAS SAMPLE TEMPERATURE "AT ORIF" GAS METER		FILTER HOLDER TEMPERATURE, (°F)	TEMPERATURE OF GAS LEAVING CONDENSER OR LAST IMPING, (°F)
								INLET (°F)	OUTLET (°F)		
1-1	12:00	0	2.0	76	1.1	1.1	684.770	106	77	246	58
2		6	2.0	77	1.0	1.0	686.670	109	78	249	58
3		9	3.0	77	1.0	1.2	688.760	111	79	253	58
4		12	3.0	76	1.0	1.2	690.875	113	81	256	59
5		15	3.0	76	1.0	1.2	693.006	114	82	256	57
6-1	12:20	18	3.5	74	1.1	1.3	695.210	109	79	259	57
2		21	4.0	78	1.1	1.3	697.990	107	81	263	56
3		24	3.0	75	1.0	1.0	699.390	106	80	264	57
4		27	2.0	75	1.0	1.0	700.810	108	81	267	57
5		30	4.0	75	1.0	1.2	702.943	111	81	269	58
6-1	12:41	33	4.0	77	1.4	1.7	705.400	94	80	260	59
2		36	4.0	80	1.5	1.8	708.000	106	79	258	59
3		39	4.0	83	1.4	1.7	710.401	109	79	257	59
4		42	4.0	83	1.1	1.3	712.499	109	80	260	59
5		45	4.0	81	1.3	1.6	714.810	112	80	261	60
6-1	1:00	48	4.0	82	1.2	1.4	717.220	96	80	257	51
2		51	4.0	85	1.4	1.3	719.410	106	80	254	50
3		54	4.0	88	1.4	1.3	721.640	108	80	254	51
TOTAL								Avg.	Avg.		
AVERAGE				81	1.03	1.3	55.374		94		

IMPINGER WATER: Final 20.4 ml
 DESICCANT: Final 20.4 gm
 TIME: 00:00
 CONDENSATE: Final 20.4 ml
 DRY GAS: Final 20.4 ml
 TOTAL: Final 20.4 ml
 COND.: Final 20.4 ml

ORIFICE ANALYSIS
 C-055
 TIME: 00:00
 COND.: Final 20.4 ml
 DRY GAS: Final 20.4 ml
 TOTAL: Final 20.4 ml
 COND.: Final 20.4 ml

1900		1901		1902		1903		1904		1905		1906		1907		1908		1909		1910		1911		1912		1913		1914		1915		1916		1917		1918		1919		1920		1921		1922		1923		1924		1925		1926		1927		1928		1929		1930		1931		1932		1933		1934		1935		1936		1937		1938		1939		1940		1941		1942		1943		1944		1945		1946		1947		1948		1949		1950		1951		1952		1953		1954		1955		1956		1957		1958		1959		1960		1961		1962		1963		1964		1965		1966		1967		1968		1969		1970		1971		1972		1973		1974		1975		1976		1977		1978		1979		1980		1981		1982		1983		1984		1985		1986		1987		1988		1989		1990		1991		1992		1993		1994		1995		1996		1997		1998		1999		2000		2001		2002		2003		2004		2005		2006		2007		2008		2009		2010		2011		2012		2013		2014		2015		2016		2017		2018		2019		2020		2021		2022		2023		2024		2025		2026		2027		2028		2029		2030		2031		2032		2033		2034		2035		2036		2037		2038		2039		2040		2041		2042		2043		2044		2045		2046		2047		2048		2049		2050		2051		2052		2053		2054		2055		2056		2057		2058		2059		2060		2061		2062		2063		2064		2065		2066		2067		2068		2069		2070		2071		2072		2073		2074		2075		2076		2077		2078		2079		2080		2081		2082		2083		2084		2085		2086		2087		2088		2089		2090		2091		2092		2093		2094		2095		2096		2097		2098		2099		2100	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100																																																																																																																																																																																																																																																																																																														

DATE	DESCRIPTION	AMOUNT	BALANCE
1900			
1901			
1902			
1903			
1904			
1905			
1906			
1907			
1908			
1909			
1910			
1911			
1912			
1913			
1914			
1915			
1916			
1917			
1918			
1919			
1920			
1921			
1922			
1923			
1924			
1925			
1926			
1927			
1928			
1929			
1930			
1931			
1932			
1933			
1934			
1935			
1936			
1937			
1938			
1939			
1940			
1941			
1942			
1943			
1944			
1945			
1946			
1947			
1948			
1949			
1950			
1951			
1952			
1953			
1954			
1955			
1956			
1957			
1958			
1959			
1960			
1961			
1962			
1963			
1964			
1965			
1966			
1967			
1968			
1969			
1970			
1971			
1972			
1973			
1974			
1975			
1976			
1977			
1978			
1979			
1980			
1981			
1982			
1983			
1984			
1985			
1986			
1987			
1988			
1989			
1990			
1991			
1992			
1993			
1994			
1995			
1996			
1997			
1998			
1999			
2000			

250691	1900	250691	1900
250692	1900	250692	1900
250693	1900	250693	1900
250694	1900	250694	1900
250695	1900	250695	1900
250696	1900	250696	1900
250697	1900	250697	1900
250698	1900	250698	1900
250699	1900	250699	1900
250700	1900	250700	1900

TRAVERSE POINT NUMBER	TIME	SAMPLING TIME (Hr. min.)	VACUUM (In. Hg)	STACK TEMPERATURE (°F)	VELOCITY HEAD (FPS) (In. H ₂ O)	PRESSURE DIFFERENTIAL ACROSS ORIFICE WATER (In. H ₂ O)	GAS SAMPLE VOLUME (cu ft)	GAS SAMPLE TEMPERATURE - AT ORY GAS W/CA		FILTER HOLDING TEMPERATURE, (°F)	TEMPERATURE OF GAS LEAVING CONCENTRATOR OR LAST IMPINGER, (°F)
								INLET (°F)	OUTLET (°F)		
B-4	r	57	4.0	89	1.3	1.55	724.080	111	80	250	51
S		60	4.0	83	1.3	1.55	726.546	112	80	251	51
A-1	009 ✓	63	4.0	88	1.0	1.2	722.840	98	80	250	52
Z		66	4.0	80	1.0	1.2	730.930	102	80	252	52
?		69	4.0	91	.80	0.98	722.910	107	80	254	53
4		72	4.0	95	1.0	1.2	735.615	109	80	253	53
5	034	75	4.0	97	1.0	1.2	739.715	111	80	254	53
TOTAL								Avg.			
AVERAGE								Avg.			

PLANT Cam. 21
 LOCATION 25th Ave. W. 10th
 OPERATOR R. Campbell
 DATE 6/22/60
 RUN NO. 015-3
 SAMPLE BOX NO. 4443
 METER BOX NO. 4443
 METER AMP KG 121
 CAPACITOR KG 121
 PITOT TUBE COEFFICIENT 0.94

BAROMETRIC PRESSURE 29.9
 ASSUMED MOISTURE %
 PROBE LENGTH, IN #7
 NOZZLE IDENTIFICATION NO.
 AVERAGE CALIBRATED NOZZLE DIAMETER, IN 0.016
 PROBE HEATER SETTING
 LEAK RATE, (l/min) 0.01 at 10 in
 PROBE LINDER MATERIAL Glass
 STATIC PRESSURE, (in. Hg) 4.70
 FILTER NO. 100053

SCHEDULE OF STACK CROSS SECTION
 LOCATION
 STACK DIAMETER

TRAVERSE POINT NUMBER	TIME	SAMPLING TIME (W. MIN.)	VACUUM (in. Hg)	STACK TEMPERATURE (°F)	VELOCITY HEAD (in. Hg)	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (in. Hg)	GAS SAMPLE VOLUME (cu ft)	GAS SAMPLE TEMPERATURE - AT ORIFICE METER		TEMPERATURE OF GAS LEAVING CONDENSER OR LAST IMPIINGER
								INLET (°F)	OUTLET (°F)	
A-1	2:05	3	3.0	104	1.0	1.2	73.87	91	74	255
2		6	3.0	104	1.1	1.3	74.85	91	74	255
3		9	3.0	110	.95	1.65	73.950	88	74	256
4		12	3.0	95	.90	1.1	74.535	100	75	255
5		15	3.0	100	.80	.96	74.733	102	74	256
B-1	2:22	18	3.0	101	1.1	1.3	74.710	76	93	259
2		21	3.0	103	1.1	1.3	75.160	103	77	258
3		24	3.0	99	1.0	1.2	75.280	104	78	261
4		27	3.0	115	1.1	1.3	75.125	108	90	264
5		30	3.0	116	1.2	1.45	75.639	109	79	265
C-1	2:47	33	3.0	118	1.2	1.45	76.430	99	80	266
2		36	3.5	130	1.3	1.55	76.470	109	81	261
3		39	3.5	122	1.2	1.45	75.760	111	81	264
4		42	3.5	131	1.2	1.45	76.670	109	81	263
5		45	3.0	102	1.1	1.3	76.262	110	82	259
D-1	3:02	48	3.0	112	.80	0.96	77.295	98	82	253
2		51	3.0	108	1.0	1.2	77.399	106	81	251
3		54	3.0	102	.80	0.96	77.120	106	82	254
TOTAL								AVG.	AVG.	
AVERAGE				103	1.04	1.2	55.203		91	

IMPINGER WATER
 Final 208 ml
 Initial 200 ml
 Cond. 8 ml
 C-075
 DESICCANT
 Final 23.9 gm
 Initial 226.7 gm
 OREGAT ANALYSES

6.0	0.0	0.0
24.0	24.0	24.0

TRAVERSE POINT NUMBER	TIME	SAMPLING TIME HRS. MIN.	VACUUM IN. Hg	STACK TEMPERATURE °F	VELOCITY HEAD FPS. ft./min	PRESSURE DIFFERENTIAL ACROSS ORIFICE WATER IN. H ₂ O	GAS SAMPLE VOLUME cu ft	GAS SAMPLE TEMPERATURE - AT DRY GAS METER		FILTER HOLDER TEMPERATURE °F	TEMPERATURE OF GAS LEAVING CONDENSER OR LAST BUBBLER °F
								INLET °F	OUTLET °F		
0-9		57	3.0	96	0.10	0.84	177.9	104	91	252	60
5		60	3.0	93	1.0	1.2	180.15	111	92	252	61
2-1	3:17	63	3.0	94	1.1	1.3	182.02	101	92	257	60
2		66	3.0	90	1.1	1.3	186.815	100	92	260	59
7		69	3.0	82	1.0	1.2	188.610	109	82	261	59
4		70	3.0	80	1.0	1.2	191.95	110	82	260	61
5	3:30	75	3.0	79	1.0	1.2	193.03	111	82	259	62
TOTAL								Avg.	Avg.		
AVERAGE								Avg.	Avg.		

00	
01	
02	
03	
04	
05	
06	
07	
08	
09	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	

D. PROCESS DATA

8/22/90

Rich Hill Sand Plant

Time: 9:25-11:10 12-1:34 2:05-3:32

Going In 150 T/Hr 145 T/Hr 142 T/Hr

Coming Out 120 116 119

Officer 30 29 29

Rich H.

1A Sand Fine Dust out of Sand Plant @ Rich Hill

3/8 100 100

1/4 99 99

3/4 74 72

1/2 52 117 100

3/4 41 53 99

5/8 29 21 97

3/4 19 10 87

200 9 4 58

24

**FABRIC FILTER DATA SHEET -- PARAMETERS
OF DESIGN AND OPERATION AFFECTING PERFORMANCE**

Facility Rock Hill Sulfur Plant Boiler No. _____
 Monitor Name Boyle, Robert Test No. 1-3
 Design Efficiency _____ Test Date 1/22/80

Recording Interval		Pressure Drop Across Baghouse (in. H ₂ O)	Pressure Drop Across Compartment (in. H ₂ O)				
Sampling Time (minutes)	Clock Time (24 hr. clock)		1	2	3	4	5
9:26:00 am		1.3 ⁰					
9:34:00 am		1.3 ⁰					
9:55:00 am		1.3 ⁰					
10:15:00 am		1.3 ⁰					
10:25:00 am		1.3 ⁰					
10:40:00 am		1.3 ⁰					
10:45:00 am		1.3 ⁰					
10:50:00 am		1.3 ⁰					
11:00:00 am		1.3 ⁰					
11:05:00 am		1.3 ⁰					
11:10:00 am		1.3 ⁰					
11:15:00 am		1.3 ⁰					
11:20:00 am		1.3 ⁰					
11:25:00 am		1.3 ⁰					
11:30:00 am		1.3 ⁰					
11:35:00 am		1.3 ⁰					
11:40:00 am		1.3 ⁰					
11:45:00 am		1.3 ⁰					
11:50:00 am		1.3 ⁰					
11:55:00 am		1.3 ⁰					
12:00:00 pm		1.3 ⁰					
12:05:00 pm		1.3 ⁰					
12:10:00 pm		1.3 ⁰					
12:15:00 pm		1.3 ⁰					
12:20:00 pm		1.3 ⁰					
12:25:00 pm		1.3 ⁰					
12:30:00 pm		1.3 ⁰					
12:35:00 pm		1.3 ⁰					
12:40:00 pm		1.3 ⁰					
12:45:00 pm		1.3 ⁰					
12:50:00 pm		1.3 ⁰					
12:55:00 pm		1.3 ⁰					
1:00:00 pm		1.3 ⁰					
1:05:00 pm		1.3 ⁰					
1:10:00 pm		1.3 ⁰					
1:15:00 pm		1.3 ⁰					
1:20:00 pm		1.3 ⁰					
1:25:00 pm		1.3 ⁰					
1:30:00 pm		1.3 ⁰					
1:35:00 pm		1.3 ⁰					
1:40:00 pm		1.3 ⁰					
1:45:00 pm		1.3 ⁰					
1:50:00 pm		1.3 ⁰					
1:55:00 pm		1.3 ⁰					
2:00:00 pm		1.3 ⁰					
2:05:00 pm		1.3 ⁰					
2:10:00 pm		1.3 ⁰					
2:15:00 pm		1.3 ⁰					
2:20:00 pm		1.3 ⁰					
2:25:00 pm		1.3 ⁰					
2:30:00 pm		1.3 ⁰					
2:35:00 pm		1.3 ⁰					
2:40:00 pm		1.3 ⁰					
2:45:00 pm		1.3 ⁰					
2:50:00 pm		1.3 ⁰					
2:55:00 pm		1.3 ⁰					
3:00:00 pm		1.3 ⁰					
3:05:00 pm		1.3 ⁰					
3:10:00 pm		1.3 ⁰					
3:15:00 pm		1.3 ⁰					
3:20:00 pm		1.3 ⁰					
3:25:00 pm		1.3 ⁰					
3:30:00 pm		1.3 ⁰					
3:35:00 pm		1.3 ⁰					
3:40:00 pm		1.3 ⁰					
3:45:00 pm		1.3 ⁰					
3:50:00 pm		1.3 ⁰					
3:55:00 pm		1.3 ⁰					
4:00:00 pm		1.3 ⁰					
4:05:00 pm		1.3 ⁰					
4:10:00 pm		1.3 ⁰					
4:15:00 pm		1.3 ⁰					
4:20:00 pm		1.3 ⁰					
4:25:00 pm		1.3 ⁰					
4:30:00 pm		1.3 ⁰					
4:35:00 pm		1.3 ⁰					
4:40:00 pm		1.3 ⁰					
4:45:00 pm		1.3 ⁰					
4:50:00 pm		1.3 ⁰					
4:55:00 pm		1.3 ⁰					
5:00:00 pm		1.3 ⁰					
5:05:00 pm		1.3 ⁰					
5:10:00 pm		1.3 ⁰					
5:15:00 pm		1.3 ⁰					
5:20:00 pm		1.3 ⁰					
5:25:00 pm		1.3 ⁰					
5:30:00 pm		1.3 ⁰					
5:35:00 pm		1.3 ⁰					
5:40:00 pm		1.3 ⁰					
5:45:00 pm		1.3 ⁰					
5:50:00 pm		1.3 ⁰					
5:55:00 pm		1.3 ⁰					
6:00:00 pm		1.3 ⁰					
6:05:00 pm		1.3 ⁰					
6:10:00 pm		1.3 ⁰					
6:15:00 pm		1.3 ⁰					
6:20:00 pm		1.3 ⁰					
6:25:00 pm		1.3 ⁰					
6:30:00 pm		1.3 ⁰					
6:35:00 pm		1.3 ⁰					
6:40:00 pm		1.3 ⁰					
6:45:00 pm		1.3 ⁰					
6:50:00 pm		1.3 ⁰					
6:55:00 pm		1.3 ⁰					
7:00:00 pm		1.3 ⁰					
7:05:00 pm		1.3 ⁰					
7:10:00 pm		1.3 ⁰					
7:15:00 pm		1.3 ⁰					
7:20:00 pm		1.3 ⁰					
7:25:00 pm		1.3 ⁰					
7:30:00 pm		1.3 ⁰					
7:35:00 pm		1.3 ⁰					
7:40:00 pm		1.3 ⁰					
7:45:00 pm		1.3 ⁰					
7:50:00 pm		1.3 ⁰					
7:55:00 pm		1.3 ⁰					
8:00:00 pm		1.3 ⁰					
8:05:00 pm		1.3 ⁰					
8:10:00 pm		1.3 ⁰					
8:15:00 pm		1.3 ⁰					
8:20:00 pm		1.3 ⁰					
8:25:00 pm		1.3 ⁰					
8:30:00 pm		1.3 ⁰					
8:35:00 pm		1.3 ⁰					
8:40:00 pm		1.3 ⁰					
8:45:00 pm		1.3 ⁰					
8:50:00 pm		1.3 ⁰					
8:55:00 pm		1.3 ⁰					
9:00:00 pm		1.3 ⁰					
9:05:00 pm		1.3 ⁰					
9:10:00 pm		1.3 ⁰					
9:15:00 pm		1.3 ⁰					
9:20:00 pm		1.3 ⁰					
9:25:00 pm		1.3 ⁰					
9:30:00 pm		1.3 ⁰					
9:35:00 pm		1.3 ⁰					
9:40:00 pm		1.3 ⁰					
9:45:00 pm		1.3 ⁰					
9:50:00 pm		1.3 ⁰					
9:55:00 pm		1.3 ⁰					
10:00:00 pm		1.3 ⁰					
10:05:00 pm		1.3 ⁰					
10:10:00 pm		1.3 ⁰					
10:15:00 pm		1.3 ⁰					
10:20:00 pm		1.3 ⁰					
10:25:00 pm		1.3 ⁰					
10:30:00 pm		1.3 ⁰					
10:35:00 pm		1.3 ⁰					
10:40:00 pm		1.3 ⁰					
10:45:00 pm		1.3 ⁰					
10:50:00 pm		1.3 ⁰					
10:55:00 pm		1.3 ⁰					
11:00:00 pm		1.3 ⁰					
11:05:00 pm		1.3 ⁰					
11:10:00 pm		1.3 ⁰					
11:15:00 pm		1.3 ⁰					
11:20:00 pm		1.3 ⁰					
11:25:00 pm		1.3 ⁰					
11:30:00 pm		1.3 ⁰					
11:35:00 pm		1.3 ⁰					
11:40:00 pm		1.3 ⁰					
11:45:00 pm		1.3 ⁰					
11:50:00 pm		1.3 ⁰					
11:55:00 pm		1.3 ⁰					
12:00:00 am		1.3 ⁰					
12:05:00 am		1.3 ⁰					
12:10:00 am		1.3 ⁰					
12:15:00 am		1.3 ⁰					
12:20:00 am		1.3 ⁰					
12:25:00 am		1.3 ⁰					
12:30:00 am		1.3 ⁰					
12:35:00 am		1.3 ⁰					
12:40:00 am		1.3 ⁰					
12:45:00 am		1.3 ⁰					
12:50:00 am		1.3 ⁰					
12:55:00 am		1.3 ⁰					
1:00:00 am		1.3 ⁰					
1:05:00 am		1.3 ⁰					
1:10:00 am		1.3 ⁰					
1:15:00 am		1.3 ⁰					
1:20:00 am		1.3 ⁰					
1:25:00 am		1.3 ⁰					
1:30:00 am		1.3 ⁰					
1:35:00 am		1.3 ⁰					
1:40:00 am		1.3 ⁰					
1:45:00 am		1.3 ⁰					
1:50:00 am		1.3 ⁰					
1:55:00 am		1.3 ⁰					
2:00:00 am		1.3 ⁰					
2:05:00 am		1.3 ⁰					
2:10:00 am		1.3 ⁰					
2:15:00 am		1.3 ⁰					
2:20:00 am		1.3 ⁰					
2:25:00 am		1.3 ⁰					
2:30:00 am		1.3 ⁰					
2:35:00 am		1.3 ⁰					
2:40:00 am		1.3 ⁰					
2:45:00 am		1.3 ⁰					
2:50:00 am		1.3 ⁰					
2:55:00 am		1.3 ⁰					
3:00:00 am		1.3 ⁰					
3:05:00 am		1.3 ⁰					
3:10:00 am		1.3 ⁰					
3:15:00 am		1.3 ⁰					
3:20:00 am		1.3 ⁰					
3:25:00 am		1.3 ⁰					
3:30:00 am		1.3 ⁰					
3:35:00 am		1.3 ⁰					
3:40:00 am		1.3 ⁰					
3:45:00 am		1.3 ⁰					
3:50:00 am		1.3 ⁰					
3:55:00 am		1.3 ⁰					
4:00:00 am		1.3 ⁰					

E. LABORATORY DATA

ANALYTICAL DATA

	RHS-1	RHS-2	RHS-3
Test No.			
Test Date	8/22/90	8/22/90	8/22/90
Filter No.	100051	100052	100053
Filter Tare, mg	636.6	634.7	630.8
Filter Final, mg	646.4	642.7	638.9
Filter Net, mg	9.8	7.6	8.1
Probe Acetone, mg	23.8	18.5	15.5
Probe Water mg	7.2	2.0	0.3
Impinger Sol. mg	7.3	1.9	21.8
Impinger Insol., mg	1.5	4.7	5.7
Impinger Acetone, mg	2.4	4.8	0.6
Acetone Blank (mg)*	0.2		
Water Blank (mg)*	0.4		
Total particulate, mg	44.7	37.6	30.2

*Data not corrected for blank values.

Analyst

Ruth Karamody

Reviewer

Richard S. Campbell

F. V. E. CERTIFICATION

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Technical Systems, Inc.

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

Thomas Thorpe

President

W. Lee

Vice President

David L. Lantz

Program Manager

235654

Certificate Number

Charlotte

Location

March 31, 1990

Date of Issue