

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Let's protect ourselves



State of New Jersey
DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF ENVIRONMENTAL QUALITY
CN 027, TRENTON, N.J. 08625

JORGE H. BERKOWITZ, Ph.D.
DIRECTOR

June 30, 1988

(609) 292-5383

MEMORANDUM

TO: Don Patterson

FROM: Edward Choromanski 

SUBJECT: New Jersey Pulverizing Company
Bagville, New Jersey
APC ID No. 78003
NJ Stack No. 001

Emission tests were conducted at the above referenced facility on the Drier Stack No. 1. The purpose of the tests was to determine the particulate emission rate and collection efficiency of the cyclone/scrubber system.

Doug Bruckman reviewed the final test report. His review indicates that the particulate collection efficiency of the control device did not meet the 99% collection efficiency stated on Permit No. P-77187, for all test runs. Although, Mr. Bruckman stated that the particulate emission rates were within the permit standards, further review indicates that the particulate emission standards exceeded the standards stated on Permit No. P-77187, during all test runs. The following chart represents the corrected outlet emissions.

RUN NO.	ACTUAL EMISSION RATE (LB/HR)	ALLOWABLE EMISSION RATE (LB/HR)
1	7.99	0.31
2	5.59	0.31
3	7.14	0.31

The amount of sand dried during the tests were within permit standards as verified by Central Regional Office personnel.

Let's protect our earth



State of New Jersey
DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF ENVIRONMENTAL QUALITY
CN 027, TRENTON, N.J. 08625

JORGE H. BERKOWITZ, Ph.D.
DIRECTOR

(609) 292-5383

June 21, 1988

MEMORANDUM

TO: Ed Choromanski

FROM: Douglas J. Bruckman *DB*

SUBJECT: New Jersey Pulverizing Company
Bayville, NJ
ID #78003 NJ Stack #001
Permit No. 77187

Stack tests were conducted at New Jersey Pulverizing in Bayville, NJ on November 19, 1987 by Weston Consultants of West Chester, Pa. The tests were conducted to determine outlet particulate emissions and also to determine compliance with the permit conditions - 99%-removal efficiency of control device.

The test results are as follows:

PARTICULATE

Run No.	Inlet Emission Rate * lbs/hr	Outlet Emission Rate lbs/hr	Allowable Emission Rate lbs/hr	Control Efficiency **	Required Control Efficiency
1	58.99	7.99	9.18	86.46%	99%
2	59.73	5.59	9.18	90.64%	99%
3	65.79	7.14	9.18	89.15%	99%

* The inlet E.R. is the sum of the cyclone catch rate plus the measured mass rate.

** Control Efficiency = $\frac{\text{E.R. scrubber inlet} - \text{E.R. outlet}}{\text{E.R. scrubber inlet}}$

Technical Services using the raw data supplied produced substantially the same results. The test results indicate that the particulate emissions were in compliance with the values on Permit No 77187. However the required control efficiency of 99% was not obtained during the test - 90.64% was the highest control efficiency demonstrated. Production data was taken during runs # 1 & 2. Note that production was operated at permitted conditions.

After reviewing the stack test report it was found necessary to require NJ Pulverizing to install an additional control device to achieve a minimum collection efficiency of 99%, as stated in the permit conditions.

Based on the reported emission test results, the following action is recommended.

1. Proper enforcement action is recommended since the source's particulate emission rate exceed Permit No. P-77187 standards during each test run.
2. Proper enforcement action is recommended since the particulate control efficiency was not within the requirements specified by Permit No. P-77187.

c Milt Polakovic
Louis Mikolajczyk
Harold Christiff
Joe DePierro
Doug Bruckman



SOURCE EMISSIONS COMPLIANCE
TEST REPORT
SAND DRYER SYSTEM
New Jersey Pulverizing Company
Bayville, New Jersey

W.O.# 2373-01-02

JANUARY 1988

Jeffrey D. Olcott FOR RR
Roy Rakiewicz
Project Scientist

James C. Serne FOR
Barry L. Jackson
Project Manager
Air Quality Testing Services

Prepared by:
ROY F. WESTON, INC.
Weston Way
West Chester, PA 19380
(215) 692-3030

TABLE OF CONTENTS

	<u>PAGE</u>
SUMMARY	1
INTRODUCTION	3
DESCRIPTION OF PROCESS	4
DESCRIPTION OF TEST LOCATIONS	5
DESCRIPTION OF SAMPLING TRAINS	8
TEST PROCEDURES	13
ANALYTICAL PROCEDURES	16
TEST RESULTS AND DISCUSSION	18
APPENDICES	
Appendix A - Raw Test Data	
Appendix B - Laboratory Reports	
Appendix C - Sample Calculations	
Appendix D - Equipment Calibration Records	
Appendix E - WESTON Project Participants	

LIST OF TABLES AND FIGURES

<u>TABLE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
1	Summary of Particulate Compliance Test Results	2
2	Summary of Particulate Test Results Sand Dryer Scrubber Inlet	19
3	Summary of Particulate Test Results 1 Sand Dry Scrubber Outlet	20

<u>FIGURE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
1	Test Port and Point Location for Scrubber Inlet Location	6
2	Test Port and Point Location for Scrubber Outlet Location	7
3	Particulate Sampling Train - Scrubber Outlet; USEPA Mthod 5	10
4	Particulate Sampling Train - Scrubber Inlet; New Jersey Air Test Method 1	11

SUMMARY

New Jersey Pulverizing Company (NJPCO) contracted Roy F. Weston, Inc. (Weston) to conduct a source compliance testing and analysis program on the Sand Dryer Wet Scrubber located at its Bayville, New Jersey Plant.

The Primary objective of the survey was to determine particulate mass rates and concentrations entering and exiting the scrubber in order to establish the collection efficiency of the control device for comparison with applicable New Jersey Department of Environmental Protection (NJDEP) air pollution regulations. A series of three simultaneous wet scrubber inlet and outlet (stack) particulate tests was conducted. Material collected by the cyclone separator located between the dryer exhaust and scrubber was captured, retained and weighed to establish mass rates exiting the sand dryer.

Particulate emission compliance test results are summarized in Table 1. Detailed test data and test results are provided in Tables 2 and 3 in the test results and discussion section of the report.

All testing procedures conformed to the U.S. Environmental Protection Agency (EPA) and NJDEP protocols.

NEW JERSEY PULVERIZING COMPANY
BAYVILLE, NEW JERSEY

TABLE 1

SUMMARY OF TEST RESULTS FOR
SAND DRYER SCRUBBER

LOCATION	RUN	TEST DATE	TEST PERIOD	MEASURED GR/DSCF1	LBS/HR2	NJDEP3 ALLOWABLE REMOVAL EFFICIENCY PERCENT	SCRUBBER PARTICULATE REMOVAL EFFICIENCY PERCENT
INLET	1	11-19-87	1137-1420	0.102	59.0	—	—
	2	11-19-87	1729-1842	0.071	59.7	—	—
	3	11-19-87	2115-2244	0.076	65.8	—	—
	SERIES AVG.			0.083	61.4		
OUTLET	1	11-19-87	1135-1415	0.038	7.99	99.00	86.5 %
	2	11-19-87	1729-1842	0.026	5.59	99.00	90.6 %
	3	11-19-87	2115-2244	0.033	7.14	99.00	89.2 %
	SERIES AVG.			0.032	7.04	--	88.8 %

1 standard conditions = 70 deg. F. (21.1 deg. C.) and 29.92 inches Hg (760mm Hg) gr/dscf = grains per dry standard cubic foot at standard conditions

2 The inlet lbs/hr mass rate was obtained by adding the cyclone catch rate (lbs/hr) and measured mass rate (lbs/hr) between the cyclone and scrubber to obtain a total dryer exit mass rate (lbs/hr)

3 Scrubber particulate removal efficiency must be ≥ 99.0 % to demonstrate compliance with DEP regulations

INTRODUCTION

NJPCO contracted WESTON to conduct a source compliance testing and analysis program on the Sand Dryer Wet Scrubber located at its Bayville, New Jersey Plant.

The primary objective of the program was to determine the particulate emissions compliance status of the source relevant to NJDEP regulations.

Simultaneous particulate tests utilizing NJDEP Air Test Method 1¹ were performed on the scrubber inlet and outlet locations during the day of 19 November 1987 by WESTON Air Quality Testing Services personnel.

The compliance test results are summarized in Table 1 in the Summary section. Detailed test data and test results summaries are presented in Tables 2 and 3 of this report in the Test Results and Discussion Section.

Descriptions of the sand dryer process, test locations, test equipment, test procedures, sample recovery techniques and analytical methods used during the survey are also included herein. Raw test data, laboratory reports, sample calculations, equipment calibration records and a list of WESTON project participants are provided in Appendices A through F respectively.

¹ N.J.A.C. 7:27B-1, Air Test Method 1, "Sampling and Analytical Procedures for Determining Emissions of Particles from Manufacturing Processes and from Combustion of Fuels".

DESCRIPTION OF PROCESS

The source is a rotary sand and gravel dryer that is fired directly by natural gas (primary fuel) or No. 2 fuel oil. The unit is designed to produce 31.25 tons per hour (62,500 lbs/hr) of sand and gravel on a continuous basis. The dried material is then packaged and prepared for shipment.

Particulate emissions from the dryer are controlled by a cyclone and wet scrubber in series.

DESCRIPTION OF TEST LOCATIONS

Sand Dryer Scrubber Inlet

Two 4" ID test ports were placed 90° apart on a horizontal section of circular 32" diameter duct work leading to the scrubber.

Tests ports were located on the 32" ID duct 8 diameters from the nearest upstream disturbance and at least 2 stack diameters from the nearest downstream disturbance. Criteria for traverse point location as dictated by New Jersey Air Test Method 1 required a minimum of 12 traverse points, six per port axis for this duct configuration. Figure 1 illustrates the test port and sampling point locations.

Sand Dryer Scrubber Outlet

Two test ports, 90° apart, were located on the 35 1/2" ID exhaust stack at a site which was 8 diameters from the nearest upstream flow disturbance (scrubber) and greater than 2 diameters from the downstream stack discharge disturbance. Criteria for traverse point location as dictated by New Jersey Air Test Method 1 required a minimum of twelve traverse points, six per port axis, for this stack configuration. Figure 2 illustrates the test port and sampling port locations.






FIGURE 1
TEST PORT AND POINT
LOCATION FOR SCRUBBER
INLET LOCATION



Point No.	Distance from Stack wall (in)
1	1 5/8
2	5 1/8
3	10 1/2
4	25
5	30 3/8
6	33 7/8

FIGURE 2: Test Port and Point
Location for Scrubber
Outlet location

Note: Stack height dimensions
are approximate.

DESCRIPTION OF SAMPLING TRAIN

Particulate

The sampling train utilized to perform the particulate sampling at the outlet location was a New Jersey Air Test Method 1 train (See Figure 3). The inlet train used was an EPA Method 5 train modified to include an in-stack thimble and a section of Teflon tubing between the filter holder and first impinger. (See Figure 4).

At the outlet location a calibrated stainless steel nozzle was attached to a heated ($\leq 225^{\circ}\text{F}$) 4 ft. borosilicate probe. The probe was connected to a heated ($\leq 225^{\circ}\text{F}$) borosilicate filter holder containing a 9-cm Reeve Angel 934 AH glass fiber filter (preweighed to a constant 0.1 mg weight). At the inlet location a section of flexible Teflon tubing was inserted between the filter holder and first impinger and an in-stack glass fiber thimble was added between the nozzle and probe to collect the bulk of heavy particulate.

Flue gas velocity was measured by using a calibrated "S" type pitot tube (provided with extensions) fastened alongside the sampling probe. Flue gas temperature was monitored with a calibrated direct readout pyrometer equipped with a chromel alumel thermocouple positioned near the sampling nozzle. Probe exit and filter exit gas temperatures were monitored at the outlet location with a calibrated direct readout pyrometer equipped with chromel-alumel thermocouple positioned in the sample gas stream after the probe but before the filter and after the filter, respectively.

Stack gas stream composition (carbon dioxide, oxygen, and carbon monoxide content) was determined utilizing a bag sampler and an Orsat apparatus to analyze integrated samples of the flue gases for each test. The integrated samples of the flue gases were collected at a constant rate of 0.8 liter per minute at each sample point. Triplicate Orsat analyses were performed on each sample.




FIGURE 3 PARTICULATE SAMPLING TRAIN

N.J. Air Test Method 1

Outlet Location




FIGURE 4: PARTICULATE SAMPLING TRAIN
INLET LOCATION EPA #5

TEST PROCEDURES

Preliminary Tests

Preliminary test data were obtained at the scrubber inlet and stack test locations. Stack geometry measurements were recorded, and traverse point distances calculated. A preliminary velocity traverse was performed at each location to determine velocity profiles using a calibrated S-type pitot tube and a Dwyer inclined manometer. Flue gas temperatures were observed with a calibrated direct readout pyrometer equipped with a chromel-alumel thermocouple. Water vapor content was measured utilizing EPA Method 4 procedures at the scrubber inlet. The scrubber outlet percent water vapor was determined by the saturation temperature of the gas stream using a psychometric chart. A check for the presence or absence of cyclonic flow was conducted at both locations prior to formal testing. The cyclonic flow check at both test sites proved to be negative ($\alpha < 20^\circ$), verifying the suitability of the test sites for obtaining representative samples.

Calibration of probe nozzles, pitot tubes, metering systems, and temperature gauges was performed according to EPA Method 5² and NJDEP procedures. (See Appendix D for calibration records.)

²"Standards of Performance for New Stationary Sources, "Code of Federal Regulations", Title 40, Part 60, Appendix A, as amended.

Formal Tests

A series of three simultaneous particulate test runs was conducted on the Sand Dryer scrubber inlet and stack locations.

Test period length for each particulate test run at both locations was 60 minutes. A total of 12 traverse points were sampled for five minutes each at the inlet location. Twelve traverse points were sampled for five minutes each at the stack location also.

During particulate sampling, gas stream velocities were measured by inserting a calibrated "S" type pitot tube into the gas stream adjacent to the sampling nozzle. The velocity pressure differential was observed immediately after positioning the nozzle at each point, and the sampling rate adjusted to maintain isokineticity. Stack gas temperature was monitored at each point with a pyrometer and thermocouple. Temperature readings of the probe exit, filter exit, final impinger and dry test meter gas stream were also recorded. Leak checks were performed on each apparatus according to NJ Air Test Method One instructions, prior to and following each run.

A constant rate integrated sampling technique was employed to collect flue gas samples at each particulate traverse point for the molecular weight determination using an Orsat analyzer. The sampling train was operated for 5 minutes with the Tedlar bag disconnected to purge extraneous gases during each test.

During each test period, particulate captured by the cyclone separator was transferred to tared containers and weighed. The weights were converted to a lbs/hr collection rate, and added to the measured lbs/hr emission rate measured at the scrubber inlet. The resulting dryer exit emission rate was used to calculate the system collection efficiency (see Appendix C - sample calculations).

ANALYTICAL PROCEDURES

Particulate Sample Recovery

At the conclusion of each test run, the sampling train was dismantled, the openings sealed and the components transported to the field laboratory. A complete chain-of-custody record for the samples was maintained from this point forward.

A consistent procedure was employed for sample recovery:

1. The preweighed glass fiber filter was removed from its holder with tweezers and placed in its original container (pertri dish) along with any loose particulates and filter fragments. The inlet pre-weighed glass fiber thimble was removed from the thimble holder with tweezers and placed on its original container (500 ml amber glass jar).
2. The particulate adhering to the internal surfaces of the nozzle, probe, inlet thimble holder and front-half of the filter holder was rinsed with acetone into a borosilicate container while brushing a minimum of three times until no visible particulate remained. Particulate adhering to the brush was rinsed with acetone into the same container. The container was sealed with a Teflon-lined closure (sample type 2).
3. The total volume of liquid in impingers 1 and 2 was measured to the nearest milliliter, the value recorded and the impinger contents were discarded.

4. The silica gel was removed from the last impinger and immediately weighed to the nearest tenth gram. The weight gain was recorded.
5. An acetone blank sample was placed into a borosilicate/Teflon container for gravimetric analysis.

Each container was labeled to clearly identify its contents. The height of the fluid level was marked on the container of each sample to determine if leakage had occurred during transport. All samples were placed in a locked shipping crate, then transported to the WESTON laboratories for analysis.

Particulate Analysis

Gravimetric analysis of the particulate samples was performed as follows:

1. The filters (sample type 1) and any loose fragments were heated to 220-230°F for 2 to 3 hours, cooled in a dessicator to room temperature and weighed to a constant weight (± 0.5 mg) to the nearest 0.1 mg.
2. The front-half acetone wash samples (sample type 2) and an acetone blank were transferred to tared 250 ml beakers, and evaporated to dryness at ambient temperature and pressure. The samples were then heated to 220-230°F for 24 hours, and weighed to a constant 0.1 mg weight. Final front-half wash residue weights were determined by correcting for the acetone blank factor.

The weight of the material collected on the glass fiber filter (and thimble of the inlet train) plus the residue weight of the acetone wash sample yields the total front half weight which was used to calculate the particulate emission results.

TEST RESULTS AND DISCUSSION

A summary of compliance test results is presented in Table 1, page 2 of this report. Detailed test data and test results summaries are included in Tables 2 and 3 of this section.

All test data and test results shown herein are believed to be representative of process emissions encountered during the survey periods. Representatives of NJDEP were present during all sampling periods to witness the tests.

Run 1 at the scrubber inlet was stopped at 1201 due to a power loss but was restarted at 1234 and run to completion. Run 1 of the scrubber outlet was also halted due to the loss of power. It was stopped at 1157 and resumed at 1230 for completion.

The sample volume on run 1 of the scrubber inlet was less than 30 dscf as required by NJATM 1. Approval for a sample volume of less than 30 dscf was given by the NJDEP observers on site due to the expected high particulate loading at this test location. Although the loading was not as high as expected, sufficient particulate was collected to calculate a grain loading and mass emission rate for this run. The nozzle size was adjusted upward on runs 2 and 3.

During all test periods, the measured particulate removal efficiency of the collection system was below the state minimum allowable removal efficiency of 99.0 percent. The average removal efficiency for the three test runs was 88.8 %; the range was 86.5% to 90.6%

NEW JERSEY PULVERIZING
BAYVILLE, NEW JERSEY
TABLE 2
SUMMARY OF PARTICULATE RESULTS

TEST DATA:	1	2	3
Test run number		SCRUBBER INLET	
Test location	11-19-87	11-19-87	11-19-87
Test date	1137-1420	1729-1842	2115-2244
Test time period			
SAMPLING DATA:			
Sampling duration, min.	60.0	60.0	60.0
Nozzle diameter, in.	0.120	0.175	0.175
Cross sectional nozzle area, sq.ft.	0.000079	0.000167	0.000167
Barometric pressure, in. Hg	30.31	30.31	30.31
Avg. orifice press. diff., in H2O	0.30	1.74	1.65
Avg. dry gas meter temp., deg F	59	55	55
Avg. abs. dry gas meter temp., deg. R	519	515	515
Total liquid collected by train, ml	33.0	72.5	74.5
Std. vol. of H2O vapor coll., cu.ft.	1.6	3.4	3.5
Dry gas meter calibration factor	1.002	1.002	1.002
Sample vol. at meter cond., dcf	18.591	43.235	43.951
Sample vol. at std. cond., dscf (1)	19.270	45.338	46.052
Percent of isokinetic sampling	104.2	97.4	104.2
GAS STREAM COMPOSITION DATA:			
CO2, % by volume, dry basis	0.0	0.0	0.0
O2, % by volume, dry basis	18.4	18.4	18.4
CO, % by volume, dry basis	0.0	0.0	0.0
N2, % by volume, dry basis	81.6	81.6	81.6
Molecular wt. of dry gas, lb/lb mole	28.74	28.74	28.74
H2O vapor in gas stream, prop. by vol.	0.075	0.070	0.071
Mole fraction of dry gas	0.925	0.930	0.929
Molecular wt. of wet gas, lb/lb mole	27.9	28.0	28.0
GAS STREAM VELOCITY AND VOLUMETRIC FLOW DATA:			
Static pressure, in. H2O	-5.40	-6.00	-5.85
Static pressure, in. Hg	-0.397	-0.441	-0.430
Absolute pressure, in. Hg	29.91	29.87	29.88
Avg. temperature, deg. F	105	103	103
Avg. absolute temperature, deg.R	565	563	563
Pitot tube coefficient	0.84	0.84	0.84
Total number of traverse points	12	12	12
Avg. gas stream velocity, ft./sec.	75.4	88.6	84.1
Stack/duct cross sectional area, sq.ft.	5.59	5.59	5.59
Avg. gas stream volumetric flow, wacf/min.	25300	29700	28200
Avg. gas stream volumetric flow, dscf/min.	21900	25900	24600
LABORATORY REPORT:			
Particulate	0.11190	0.18220	0.21270
Front half acetone rinse, g	0.00000	0.00000	0.00000
Filter, g	0.01510	0.02760	0.01530
Thimble, g	0.12700	0.20980	0.22800
Total catch, g			
CYCLONE CATCH:			
Time, hours	2.72	1.22	1.48
Total sand, lbs	108.5	53.5	73.5
Cyclone catch rate, lbs/hr	39.89	43.85	49.66
PARTICULATE EMISSIONS:			
Concentration, gr/dscf	0.1017	0.0714	0.0764
Mass rate, lbs/hr	19.10	15.88	16.13
Scrubber inlet loading, lbs/hr (2)	58.99	59.73	65.79

(1) Standard conditions = 70 deg. F. (21.1 deg. C.) and
29.92 inches Hg (760 mm Hg)

(2) Scrubber inlet loading = cyclone catch rate + measured mass rate/both in lbs/hr

NEW JERSEY PULVERIZING
BAYVILLE, NEW JERSEY
TABLE 3
SUMMARY OF PARTICULATE RESULTS

TEST DATA:

	1	2	3
Test run number			
Test location			
Test date	11-19-87	11-19-87	11-19-87
Test time period	1135-1415	1729-1842	2115-2244

SAMPLING DATA:

Sampling duration, min.	60.0	60.0	60.0
Nozzle diameter, in.	0.185	0.185	0.185
Cross sectional nozzle area, sq.ft.	0.000187	0.000187	0.000187
Barometric pressure, in. Hg	30.31	30.31	30.31
Avg. orifice press. diff., in H2O	1.37	1.38	1.44
Avg. dry gas meter temp., deg F	67	56	57
Avg. abs. dry gas meter temp., deg. R	527	516	517
Total liquid collected by train, ml	61.0	61.0	67.3
Std. vol. of H2O vapor coll., cu.ft.	2.9	2.9	3.2
Dry gas meter calibration factor	0.997	0.997	0.997
Sample vol. at meter cond., dcf	37.720	38.418	39.818
Sample vol. at std. cond., dscf (1)	38.447	39.959	41.345
Percent of isokinetic sampling	96.4	97.8	99.7

GAS STREAM COMPOSITION DATA:

CO2, % by volume, dry basis	0.0	0.0	0.0
O2, % by volume, dry basis	18.5	18.4	18.5
CO, % by volume, dry basis	0.0	0.0	0.0
N2, % by volume, dry basis	81.5	81.6	81.5
Molecular wt. of dry gas, lb/lb mole	28.74	28.74	28.74
H2O vapor in gas stream, prop. by vol.	0.070	0.067	0.072
Mole fraction of dry gas	0.930	0.933	0.928
Molecular wt. of wet gas, lb/lb mole	28.0	28.0	28.0

GAS STREAM VELOCITY AND VOLUMETRIC FLOW DATA:

Static pressure, in. H2O	-0.48	-0.79	-0.60
Static pressure, in. Hg	-0.036	-0.058	-0.044
Absolute pressure, in. Hg	30.27	30.25	30.27
Avg. temperature, deg. F	100	96	95
Avg. absolute temperature, deg.R	560	556	555
Pitot tube coefficient	0.84	0.84	0.84
Total number of traverse points	12	12	12
Avg. gas stream velocity, ft./sec.	66.6	67.6	68.8
Stack/duct cross sectional area, sq.ft.	6.87	6.87	6.87
Avg. gas stream volumetric flow, wscf/min.	27400	27900	28400
Avg. gas stream volumetric flow, dscf/min.	24500	25100	25400

LABORATORY REPORT:

Particulate			
Front half acetone rinse, g	0.08040	0.05818	0.07269
Filter, g	0.01450	0.00920	0.01500
Total catch, g	0.09490	0.06738	0.08769

PARTICULATE EMISSIONS:

Concentration, gr/dscf	0.0381	0.0260	0.0327
Mass rate, lbs/hr	7.99	5.59	7.14
Scrubber inlet loading, lbs/hr	58.99	59.73	65.79

COLLECTION EFFICIENCY:

Percent efficient	86.46	90.64	89.15
-------------------	-------	-------	-------

(1) Standard conditions = 70 deg. F. (21.1 deg. C.) and
29.92 inches Hg (760 mm Hg)

$$C.E. = \frac{E.R. \text{ inlet} - E.R. \text{ outlet}}{E.R. \text{ inlet}}$$

CLIENT: NJ Pulverizing
FACILITY: BAYVILLE NJ
TEST LOCATION: SCRUBBER INLET
TEST RUN NO.: 1 2 3
TEST DATE: 11/19/87

ROY F. WESTON, INC.

EMISSION TEST DATA/REPORT
QA/QC CHECK LIST

Raw Test Data	Initial Data Averages <u>RR</u>	Data Check 1 <u>MG</u>	Data Check 2 (if req'd) <u>MG</u>	Data Completeness Check <u>✓</u>
Laboratory Data	Initial Lab Calculator <u>MT</u>	Check 1 <u>MG</u>	Check 2 (if req'd) <u>NS</u>	Data Completeness Check <u>✓</u>
Test Result Calculations	Initial Calculator <u>RR</u>	Check 1 <u>MG</u>	Check 2 (if req'd) <u>NS</u>	Reasonable-ness Check <u>✓</u>
Test Data Tables	Author <u>RR</u>	Check 1 <u>MG</u>	Check 2 (if req'd) <u>MG</u>	Completeness Reasonable-ness Check <u>✓</u>
Report Body	Author <u>W/S/RR</u>	Check 1 <u>RR</u>	Check 2 (if req'd) <u>RR/BS=00</u>	Table of Contents, Figure, page number Check <u>✓</u>
Appendices Completeness	Originator <u>RR</u>	Check 1 <u>000</u>	Check 2 (if req'd)	

Compilation Check: ✓ Page alignment and completeness
Draft Report (if required)
Final Report 1/22/88

Date provided to Client:
1/22/88

Final Report Review: PD _____
PM _____
SM/DM _____

TRAVERSE POINT LOCATION FOR CIRCULAR DUCTS

PLANT New Jersey Pulverizing
DATE 11/18/87
SAMPLING LOCATION SCRUBBER INLET
INSIDE OF FAR WALL TO
OUTSIDE OF PORT. (DISTANCE A) 36"
INSIDE OF NEAR WALL TO
OUTSIDE OF PORT. (DISTANCE B) 4"
STACK I.D.. (DISTANCE A - DISTANCE B) 32"
NEAREST UPSTREAM DISTURBANCE ≥ 2"
NEAREST DOWNSTREAM DISTURBANCE ± 8"
CALCULATOR BAKIEWICZ

SCHEMATIC OF SAMPLING LOCATION


[illegible]

GAS VELOCITY AND VOLUME DATA FORM

Plant N. J. Pulverizing Location INLET
Date 1/18/87 Run no. 1 24-hr. clock time 1500
Operators _____ Stack diameter or dimensions, in. 32"
Barometric pressure, in. Hg 30.04 Cross sectional area, ft.² 5.585
Pitot tube identification no. _____ Cp 184

[illegible]

^a Must be <10 degrees to be acceptable.



Test point schematic lower lamp

average point number	Sampling time, min.	24-hr. clock time	Velocity head (ΔP), in. H2O	Orifice meter pressure differential (ΔH), in. H2O	Gas meter reading, ft.3	Dry gas meter temperature (Tm) Inlet OF. Outlet OF.	Source temperature (Ts), OF	Pump vacuum, in. Hg. gauge	Impinger exit gas temp., OF.	Filter box temp., OF.
1	0	1137	1.90	1.33	450.030	61	106	3	56	200
2	5		1.90	1.33	451.0	61	107	3	51	180
3	10		2.3	1.42	453.2	62	103	3	49	225
4	15	1182	2.4	1.44	455.1	61	107	3	40	225
5	20	1201	2.0	1.30	457.3	62	101	3	49	215
6	25		1.5	1.27	459.5	60	97	3	49	225
7	30	1347	1.0	1.18	460.355	57	101	2	58	225
8	5		1.5	2.73	462.00	57	109	2	49	225
9	10		1.7	1.31	463.7	58	105	2.9	53	220
10	15		1.4	1.26	466.0	57	115	2.5	42	210
11	20	1181	1.2	1.22	467.3	57	101	2.0	48	210
12	25		1.1	1.20	468.4	57	97	2.0	40	215
13	30	1420	1.1	1.20	469.344	56				
Stopped test due to power loss @ outlet										
Total 0	1137-1420		Avg. ΔP 1.276466	Avg. ΔH 0.29858	Total Vm 18.591	Avg. Tm 59.3	Avg. Ts 104.8	Max. vac. 3	Max. temp. 56	Min. 80 Max. 225

Comments: Stopped test due to power loss @ outlet
Restart @ 1234

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant N.J. Pulverize Sample date 11/19/97
 Sample location inlet Run number 1
 Sample recovery person RR/DM Recovery date 11/19
 Filter(s) number 9377, 9347, 179

MOISTURE

Impingers	118 102	Silica gel
Final volume (wt) <u>220</u> ml (g)		Final wt <u>263.0</u> g
Initial volume (wt) <u>200</u> ml (g)		Initial wt <u>250.0</u> g
Net volume (wt) <u>20</u> ml (g)		Net wt <u>19.0</u> g
Total moisture <u>33</u> g		
Color of silica gel <u>50% Pink 50% Blue</u>		
Description of impinger water <u>clean</u>		

RECOVERED SAMPLE

Blank filter container number INL-THB-001A, B Sealed _____
 Filter container number _____ Sealed _____
 Description of particulate on filter LIGHT

Acetone rinse container number INL-FHA-001 Liquid level marked? _____

Acetone blank container number _____ Liquid level marked? _____

Samples stored and locked _____

Remarks _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks _____

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant NJ Pulverizing Sample date 11/17/87
 Sample location INLET Run number 2
 Sample recovery person RAKIEWICZ Recovery date 11/19/87
 Filter(s) number 9379, TS

MOISTURE

Impingers

Final volume (wt) 258.5 ml (g)
 Initial volume (wt) 200 ml (g)
 Net volume (wt) 58.5 ml (g)
 Total moisture 72 g

Silica gel

Final wt 264 g
 Initial wt 250 g
 Net wt 14 g

Color of silica gel 90% blue, 10% pink
 Description of impinger water _____

RECOVERED SAMPLE

Blank filter container number INA-002 Sealed _____
 Filter container number INL-THB-002A, B Sealed ✓
 Description of particulate on filter _____

Acetone rinse container number INL-FHA-002 Liquid level marked? ✓

Acetone blank container number _____ Liquid level marked? _____

Samples stored and locked _____


Remarks _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks _____

Plant NS Pulverizers
 City Bayville PA
 Location INLET
 Operator RWH/EWICE
 Run No. 3 Date 11/19/87
 Ambient temp., °F _____
 Baro. press. (P_b), in. Hg. 30.31
 Sample box no. _____
 Meter box no. NUTECH 6
 Meter box ΔH 1.784
 Meter box cal. (V) 1.002
 Probe length, ft. 4
 Probe liner material inox/teflon
 Probe heater setting _____




Pitot tube identification no. P-7
 Pitot tube cal. factor (C_p) 0.8
 Nozzle identification no. N-12
 Avg. nozzle diameter (D_n), in. 0.175
 Pyrometer identification no. NUTECH 6
 Thermocouple identification no. _____
 Assumed moisture, % 6
 Assumed temperature, °F. 103
 Static pressure (P_{static}), in. H₂O 5.85
 C factor _____ Reference ΔP _____
 Initial leak rate 0.16 cfm @ 15 in. Hg
 Final leak rate 0.18 cfm @ 7 in. Hg
 Filter no. 9360 T-4
 Comments: Pitot tube 1.c. good

Test point schematic

Traverse point number	Sampling time, min.	24-hr. clock time	Velocity head (ΔP), in. H ₂ O	Orifice meter pressure differential (ΔH), in. H ₂ O	Gas meter reading, ft. ³	Dry gas meter temperature (T _m) Inlet OF. Outlet OF.	Source temperature (T _s), OF	Pump vacuum, in. Hg. gauge	Impinger exit gas temp., OF.	Filter box temp., OF.
1	6	2115	2.1	1.62	512.929	51	103	5.5	47	170
2	5		2.3	1.86	517.0	52	112	6.2	47	180
3	15		2.6	2.12	521.4	53	95	7.0	45	220
4	20		2.6	2.12	525.3	59	98	7.0	43	221
5	25		2.2	1.78	527.8	54	94	6.8	45	220
6	30	2145	1.3	1.05	533.2	55	93	4.8	45	200
1	5	2206	1.6	1.31	535.201	54	105	5.1	48	200
2	10	*	2.7	1.80	539.510	54	106	6.5	42	202
3	15		2.4	1.96	542.0	55	106	6.5	45	201
4	20	*	2.0	1.64	546.4	54	106	6.0	42	200
5	25		1.7	1.39	551.5	54	104	5.0	49	210
6	30	2244	1.7	1.39	554.3	54	111	5.5	46	200
					557.189	54				
					21677 + 22.272					
Total θ			Avg. √ΔP 1.427	Avg. ΔH 1.645	Total V _m 43.951	Avg. T _m 55.375	Avg. T _s 103.75	Max. vac 7.0	Max. temp. 48	Min. 170 Max. 221

Comments: Backed @ 2115 mid point 1.c. 0.18 @ 8" * stopped to realign probe ** stopped to check filter

Plant N.J. Pulverizing
 City Bayville NJ
 Location INLET
 Operator RAKIEWICZ
 Run No. 7 of 14 Date 1/19/87
 Ambient temp., °F 30.31
 Baro. press. (P_b), in. Hg. 30.31
 Sample box no. 1
 Meter box no. NUTECH 6
 Meter box ΔH_e 1.784
 Meter box cal. (Y) 1.002
 Probe length, ft. 4
 Probe liner material borosilicate
 Probe heater setting 30



Pitot tube identification no. P-7
 Pitot tube cal. factor (C_p) 0.94
 Nozzle identification no. N-12
 Avg. nozzle diameter (D_n), in. 1.75
 Pyrometer identification no. #6
 Thermocouple identification no. 1
 Assumed moisture, % 8.5
 Assumed temperature, °F 110
 Static pressure (P_{static}), in. H₂O -6.0
 C factor Reference Δp
 Initial leak rate 0.12 cfm @ 15 in. Hg
 Final leak rate 0.12 cfm @ 7 in. Hg
 Filter no. 9379 - T5

Comments:

Pitot tube leak check good

Test point schematic

N = .77

Traverse point number	Sampling time, min.	24-hr. clock time	Velocity head (ΔP), in. H ₂ O	Orifice meter pressure differential (ΔH), in. H ₂ O	Gas meter reading, ft. ³	Dry gas meter temperature (T _m)		Source temperature (T _s), °F	Pump vacuum, in. Hg. gauge	Impinger exit gas temp., °F	Filter box temp., °F
						Inlet °F	Outlet °F				
0		1729			419.966						
1	5		2.4	1.05	473.5	52	52	100	6.0	45	200
2	10		2.4	1.05	477.4	52	52	106	6.0	39	200
3	15		2.8	2.1	481.6	55	57	104	6.0	42	190
4	20		2.8	2.1	485.4	53	57	105	7.0	43	194
5	25		2.6	2.0	489.4	55	58	106	7.0	44	190
6	30	1759	2.0	1.54	492.473	53	57	102	6.0	46	192
		1812			492.539						
1	5		1.9	1.46	496.0	53	54	97	5.5	47	210
2	10		2.0	1.62	500.6	53	57	100	6.0	42	205
3	15		2.4	1.85	503.7	54	58	102	7.0	44	215
4	20		2.4	1.85	507.2	55	59	104	7.0	44	210
5	25		1.9	1.46	509.6	55	59	101	6.0	46	200
6	30	1842	1.6	1.23	513.267	54	58	104	5.2	51	200
Total 0			Avg. √ΔP / 11.503411	Avg. ΔH / 1.7425	Total V _m / 43.235	Avg. T _m / 55.1		Avg. T _s / 102.0	Max. vac / 7	Max. temp. / 51	Min. 190 Max. 215

Comments:

Backed @ 1729
out @ 1842

Mid point leak ok 0.0150 (P)

6" Hg

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant N.J. Pulveriser Sample date 11/19
 Sample location INLET Run number 3
 Sample recovery person RR DM Recovery date 11/19/87
 Filter(s) number 9360, T-9

MOISTURE

Impingers

Final volume (wt) 200 ml (g)
 Initial volume (wt) 200 ml (g)
 Net volume (wt) 60 ml (g)
 Total moisture 745 g

Silica gel

Final wt 2645 g
 Initial wt 250 g
 Net wt 14.5 g

Color of silica gel 50% BLUE / PINK
 Description of impinger water SLIGHTLY FOGGY

RECOVERED SAMPLE

Blank filter container number _____ Sealed _____
 Filter container number INL-F-003 Sealed ✓
 Description of particulate on filter _____

Acetone rinse container number INL-FHA-003 Liquid level marked? _____

Acetone blank container number _____ Liquid level marked? _____

Samples stored and locked _____

Remarks Thomble - INL - THB - 003

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks _____

GAS ANALYSIS DATA FORM

Plant NEW JERSEY POLYMERIZING Sample location IN LET
 Date 1/14/87 Run no. 1, 2, 3 Operator BARKER
 Sample type: single-point or multipoint; grab or integrated
 Analytical method GRSAT Comments LEAK CHECK C.O.
AMBIENT O₂ 20.0%

Sample point	24-hour clock time	% CO ₂	% O ₂		% CO	
		Reading 1	Reading 2	Net ^a	Reading 3	Net ^b
	1230	0.0	18.4	18.4	18.4	0.0
	1235	0.0	18.4	18.4	18.4	0.0
	1240	0.0	18.4	18.4	18.4	0.0
	1735	0.0	18.4	18.4	18.4	0.0
	1740	0.0	18.4	18.4	18.4	0.0
	1745	0.0	18.4	18.4	18.4	0.0
	2345	0.0	18.4	18.4	18.4	0.0
	2350	0.0	18.4	18.4	18.4	0.0
	2355	0.0	18.4	18.4	18.4	0.0
Averages			----		----	

$$\% N_2 = 100 - (\% CO_2 + \% O_2 + \% CO) =$$

$$MW_d = 0.440 (\% CO_2) + 0.320 (\% O_2) + 0.280 (\% N_2 + \% CO) =$$

$$^a \text{ Net } \% O_2 = \text{Reading 2} - \text{Reading 1}$$

$$^b \text{ Net } \% CO = \text{Reading 3} - \text{Reading 2}$$

CLIENT: NU PULVERIZING
FACILITY: BAYVILLE NJ
TEST LOCATION: SCRUBBER OUTLET
TEST RUN NO.: 1, 2, + 3
TEST DATE: 11-19-87

SEE PAGE ONE

ROY F. WESTON, INC.

EMISSION TEST DATA/REPORT
QA/QC CHECK LIST

	Initial Data Averages	Data Check 1	Data Check 2 (if req'd)	Data Completeness Check
Raw Test Data	<u>DA</u>	<u>MG</u>	<u>BS</u>	<u> </u>
Laboratory Data	Initial Lab Calculator <u>MT</u>	Check 1 <u>RL</u>	Check 2 (if req'd) <u>BS</u>	Data Completeness Check <u> </u>
Test Result Calculations	Initial Calculator <u>RL</u>	Check 1 <u>MG</u>	Check 2 (if req'd) <u>BS</u>	Reasonable- ness Check <u> </u>
Test Data Tables	Author <u>DA</u>	Check 1 <u>MG</u>	Check 2 (if req'd) <u>BS</u>	Completeness Reasonable- ness Check <u> </u>
Report Body	Author <u>DA</u>	Check 1 <u>MG</u>	Check 2 (if req'd) <u>RR/B</u>	Table of Contents, Figure, page number Check <u>500</u>
Appendices Completeness	Originator <u> </u>	Check 1 <u> </u>	Check 2 (if req'd) <u> </u>	<u> </u>

Compilation Check: Page alignment and completeness
Draft Report
(if required)
Final Report

Date provided to
Client:

Final Report Review: PD
PM
SM/DM

GAS VELOCITY AND VOLUME DATA FORM


Plant N.J. Pulverizing Location OUTLET 1
Date 11/10/87 Run no. 1 24-hr. clock time _____
Operators _____ Stack diameter or dimensions, in. 36
Barometric pressure, in. Hg 30.04 Cross sectional area, ft.² 7.069
Pitot tube identification no. _____ Cp 1.84

Traverse Point Number	Velocity head (Δp), in. H_2O	Stack Temperature (T_s), $^{\circ}F.$	Static pressure (P_{static}), in. H_2O	Cyclonic flow determination	
				Δp at 0° reference	Angle (α) which yields a null Δp
1	1.32	70	- .42		
2	1.50	70		- .02	45°
3	1.50	70	- .85		
4	1.40	70		- .04	8°
5	1.35	68	- .65		
6	1.10	68		- .02	50
1	1.40	95		- .02	5°
2	1.40	102	- .84		
3	1.42	102		+ .15	45°
4	1.38	107	- .61		
5	1.10	109		+ .14	8°
6	1.00	103	- .22		
Avg. $\Delta p = 1.30$ Temp 103 Bar = - .60					
Set @ $103^{\circ} = 7\%$					
$TM = 65^{\circ}$					
	TM	K			
	65	1.09	3/16" Nozzle .185 N2		
	60	1.08			
	55	1.07			
	70	1.10			
	75	1.11			
Avg. $\sqrt{\Delta p}$		Avg. T_s	Avg. P_{static}		Avg. α^a

^a Must be <10 degrees to be acceptable.

TRAVERSE POINT LOCATION FOR CIRCULAR DUCTS

PLANT New Jersey Pulverizing
DATE 11/12/87
SAMPLING LOCATION Scrubber Outlet
INSIDE OF FAR WALL TO
OUTSIDE OF PORT. (DISTANCE A) 40
INSIDE OF NEAR WALL TO
OUTSIDE OF PORT. (DISTANCE B) 4 1/2
STACK I.D.. (DISTANCE A - DISTANCE B) 35 1/2
NEAREST UPSTREAM DISTURBANCE 22
NEAREST DOWNSTREAM DISTURBANCE 28
CALCULATOR RAKIEWICZ




SCHEMATIC OF SAMPLING LOCATION

[illegible]

NEW JERSEY TEST METHOD 1

Plant N.J. Pulverizing
 City Bayville NJ
 Location Scrubber Outlet
 Operator ALSTON/BARKER
 Run No. 1 of 70 Date 11/19/87
 Ambient temp., 70
 Baro. press. (Pb), in. Hg. 30.3
 Sample box no. N/A
 Meter box no. 7
 Meter box ΔH 1.908
 Meter box cal. (Y) .9969
 Probe length, ft. 4
 Probe liner material borosilicate
 Probe heater setting 65°F



Pitot tube identification no. P-8
 Pitot tube cal. factor (Cp) .87
 Nozzle identification no. N-5
 Avg. nozzle diameter (Dn), in. .185
 Pyrometer identification no. #7
 Thermocouple identification no.
 Assumed moisture, % 7
 Assumed temperature, °F. 103
 Static pressure (Pstatic), in. H2O 25.267
 K factor 1.04 Reference ΔP N/A in. Hg
 Initial leak rate .013 cfm @ 16 in. Hg
 Final leak rate 0.006 cfm @ 11 in. Hg
 Filter no. 9376
 Comments: pilot tube L.C. - good
lung system L.C. - good

Test point schematic

H=

Traverse point number	Sampling time, min.	24-hr. clock time	Velocity head (ΔP), in. H2O	Orifice meter pressure differential (ΔH), in. H	Gas meter reading, ft. ³	Dry gas meter temperature (Tm)		Source temperature (Ts), °F	Pump vacuum, in. Hg. gauge	Impinger exit gas temp., °F. (Probe Ex. Temp. (4))	Filter box temp., °F. (4)	Filter Exit temp., °F. (3)
1	6	1135	1.35	1.4	384.475	Inlet OF.	Outlet OF.	(1)				
2	5		1.40	1.466	387.8	64	65	93	9	51	160	116
3	10		1.40	1.466	391.0	64	66	95	9	47	160	125
4	15		1.40	1.466	393.6	64	66	97	10	49	197	140
5	20		1.30	1.365	396.8	65	66	100	10	51	203	158
6	25		1.35	1.309	399.9	66	67	97	10	53	197	153
7	30	1239	1.10	1.146	402.950	70	73	97	8	52	204	144
8	0	1345	1.30	1.365	403.155							
9	5		1.30	1.365	406.5	66	67	103	9	49	167	160
10	10		1.30	1.365	409.4	67	69	103	9	46	180	116
11	15		1.45	1.518	412.6	67	69	101	9	47	182	110
12	20		1.45	1.518	416.3	66	68	104	10	48	187	123
13	25		1.40	1.466	419.4	66	68	101	11	50	181	113
14	30	1415	0.96	1.005	422.500	66	68	94	9	52	210	119
15			13.68702	16.403/12	19.345 18.8			114/12				
Total	60	1135-1415	Avg. $\sqrt{\Delta P}$ 1.140586	Avg. ΔH 1.3669	Total Vm 37.72	Avg. Tm 66.8	Avg. Ts 99.5	Max. temp. 53	Max. vac. 11	Min. 125	Max. 195	158

Comments: 11:57 - lost power

12:30 - resumed test

midpoint L.C. - 0.015 cfm @ 15" Hg

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant NT PULVERIZING Sample date 11/19/87
 Sample location SCRUBBER OUTLET Run number ONE
 Sample recovery person ALSTON/BARKER Recovery date 11/19/87
 Filter(s) number 9376

MOISTURE

Impingers

Final volume (wt) 246 ml (g)
 Initial volume (wt) 200 ml (g)
 Net volume (wt) 46 ml (g)
 Total moisture 61 g

Silica gel

Final wt 265 g
 Initial wt 250 g
 Net wt 15 g

Color of silica gel 1/3 pink, 2/3 blue
 Description of impinger water clear

RECOVERED SAMPLE

Blank filter container number BLK-F-001 Sealed _____
 Filter container number OUT-F-001 Sealed yes
 Description of particulate on filter brown

Acetone rinse container number OUT-FHA-001 (2 of 2) Liquid level marked? _____

Acetone blank container number BLK-FHA-001 Liquid level marked? _____

Samples stored and locked _____

Remarks _____

Date of laboratory custody _____


Laboratory personnel taking custody _____

Remarks _____

PARTICULATE 1 D DATA FORM
NEW SERVEY TEST METHOD 1

Sheet of

Plant N. S. POLVERIZING
 City CAYVILLE, NY
 Location SERVISER OUTLET
 Operator ALSTON/DARKER
 Run No. Two of Date 11/19/97
 Ambient temp., 57
 Baro. press. (P_b), in. Hg. 30.31
 Sample box no. N/A
 Meter box no. 7
 Meter box ΔH 1.809
 Meter box cal. (Y) 0.9969
 Probe length, ft. 4
 Probe liner material BAROSILICATE
 Probe heater setting 65 °F



AN= 0.0001866
 TOT LIO=61.
 VMSID= 2.8724
 VMSID= 39.8017
 X180=
 N2= 81.40000
 MWID= 28.74400
 BWS= 0.06751
 MD= 0.93268
 MWIS= 28.02030
 STAT,46=-0.03808
 PS= 30.2519
 VADT= 67.6045
 AS= 7.0685
 WADPH= 1725

97.8729

evation

Comments:

pitot tube EC-D.K
long system EC-D.K

Traverse point number	Sampling time, min.	24-hr. clock time	Velocity head (ΔP), in. H ₂ O	Orimet pressure differential (ΔH), in. H ₂ O	ft. 3	gas meter temperature (T _m)		Source temperature (T _s), OF (5)	Pump vacuum, in. Hg. gauge	Impinger exit gas temp., OF (4)	Filter box temp., OF. (1)	FILT OF. EXIT TEND (3)
						Inlet OF.	Outlet OF.					
1	0	1723	1.30	1.323	423.110	54	55	94	9.5	41	208	134
2	5		1.30	1.323	425.6	55	55	97	9	38	208	133
3	10		1.40	1.425	431.9	55	56	98	10	37	197	135
4	15		1.35	1.374	434.9	55	57	97	10	37	190	124
5	20		1.30	1.323	438.9	56	57	98	10	38	185	118
6	25		1.30	1.323	441.545	55	58	97	10	38	210	153
	30	1753										
1	0	1809	1.45		441.745	55	57	91	10	43	203	175
2	5		1.50	1.527	445.0	56	57	92	12	39	207	160
3	10		1.45	1.476	448.3	56	58	97	13	39	210	143
4	15		1.50	1.527	451.7	56	58	97	12	41	209	146
5	20		1.35	1.374	455.2	56	58	96	11	40	211	149
6	25		1.05	1.069	458.8	56	58	97	9	40	210	173
	30	1840			461.728	56	58					
Total 6	180		Avg. $\sqrt{\Delta P}$	Avg. ΔH	Total V _m	Avg. T _m	Avg. T _s	Max. vac.	Max. temp.	Min. 90	Max. 205	153
			1.162518	1.3783	39.418	56.2	95.9	12	43	218		

Comments: midpoint L.C. (initial) - 0.006 cfm @ 15" Hg
 (final) - 0.006 cfm @ 15" Hg

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant NS PULVERIZING Sample date 11/19/87
 Sample location SCRUBBER OUTLET Run number TWO
 Sample recovery person ALSTON/BARKER Recovery date 11/19/87
 Filter(s) number 9348

MOISTURE

Impingers

Final volume (wt) 246 ml (g)
 Initial volume (wt) 200 ml (g)
 Net volume (wt) 46 ml (g)
 Total moisture 61 g

Silica gel

Final wt 265 g
 Initial wt 250 g
 Net wt 15 g

Color of silica gel 1/3 pink, 2/3 blue
 Description of impinger water clear

RECOVERED SAMPLE

Blank filter container number BLK-F-001 Sealed _____
 Filter container number OUT-F-002 Sealed yes
 Description of particulate on filter brown

Acetone rinse container number OUT-FHA-002 Liquid level marked? _____

Acetone blank container number BLK-FHA-001 Liquid level marked? _____

Samples stored and locked _____

Remarks _____

Date of laboratory custody _____


Laboratory personnel taking custody _____

Remarks _____

PARTICULATE TEST METHOD 2

Sheet of

Plant N.S. PULVERIZING
 City BAYVILLE, NJ
 Location SCARBOROUGH OUTLET
 Operator ALSTON/BARKER
 Run No. THREE of 56 Date 11/19/87
 Ambient temp., 56
 Baro. press. (Pb), in. Hg. 30.31
 Sample box no. N/A
 Meter box no. 7
 Meter box ΔH 1.808
 Meter box cal. (Y) 0.9969
 Probe length, ft. 4
 Probe liner material BOARDS/LICATE
 Probe heater setting 75°F



Pitot tube identification no. P-8
 Pitot tube cal. factor (Cp) 0.84
 Nozzle identification no. N-5
 Avg. nozzle diameter (Dn), in. 0.198
 Pyrometer identification no. #7
 Thermocouple identification no. 7
 Assumed moisture, % 7
 Assumed temperature, OF. 100
 Static pressure (Pstatic), in. H2O -0.60
 Δ factor 1.02 Reference Δp N/A
 Initial leak rate 0.01 cfm @ 15 in. Hg
 Final leak rate 0.012 cfm @ 12 in. Hg
 Filter no. 9345

Comments:

pitot tube L.C. - good
lung system L.C. - good

Test point schematic

Traverse point number	Sampling time, min.	24-hr. clock time	Velocity head (ΔP), in. H2O	Orifice meter pressure differential (ΔH), in. H2O	Gas meter reading, ft. ³	Dry gas meter temperature (Tm) OF.		Source temperature (Ts), OF (S)	Pump vacuum, in. Hg. gauge	Impinger exit gas temp., OF. (4)	Filter box temp., OF. (1)	FILTER EXIT TEMP (3)
1	0	2110	1.460	1.643	462.339	55	56	97	12	39	225	172
2	5		1.50	1.541	465.60	55	56	104	12	38	219	172
3	10		1.50	1.544	469.2	55	57	91	12	42	221	199
4	15		1.40	1.438	472.7	56	57	92	12	41	221	198
5	20		1.30	1.335	475.8	56	58	90	11	41	224	205
6	25	2140	1.20	1.232	479.1	56	58	92	10	41	234	198
	30	2200			482.344	56	58					
1	0		1.55	1.592	482.550	56	57	87	10	43	211	132
2	5		1.40	1.438	485.7	57	59	95	11	41	198	112
3	10		1.45	1.499	489.0	57	59	100	12	41	203	179
4	15		1.50	1.541	492.5	57	59	101	12	41	217	195
5	20		1.30	1.335	496.0	57	60	103	13	43	205	147
6	25	2230	1.15	1.191	499.1	58	60	92	10	43	206	171
	30				502.359	58	60					
Total 60						Avg. Tm		Avg. Ts	Max. vac.	Max. temp.	Min. 112	95
						57.2		95.3	12	43	225	168
												170

Comments: midpoint L.C. (initial) - 0.007 afm @ 15" Hg
 (final) - 0.011 afm @ 15" Hg

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant NJ PULVERIZING Sample date 11/19/87
 Sample location SCRUBBER OUTLET Run number THREE
 Sample recovery person ALSTON/BARKER Recovery date 11/19/87
 Filter(s) number 9349

MOISTURE

Impingers

Final volume (wt) 252 ml (g)
 Initial volume (wt) 200 ml (g)
 Net volume (wt) 52 ml (g)

Silica gel

Final wt 245.3 g
 Initial wt 250 g
 Net wt 15.3 g

Total moisture 67.3 g

Color of silica gel 1/3 pink, 2/3 blue

Description of impinger water clear

RECOVERED SAMPLE

Blank filter container number BIK-F-001 Sealed _____

Filter container number OUT-F-003 Sealed _____

Description of particulate on filter brown

Acetone rinse container number OUT-FHA-003 Liquid level marked? _____

Acetone blank container number BIK-FHA-001 Liquid level marked? _____

Samples stored and locked _____

Remarks _____

Date of laboratory custody _____

Laboratory personnel taking custody _____

Remarks _____

GAS ANALYSIS DATA FORM

Plant NEW JERSEY FERTILIZING Sample location OUTLET
 Date 11/19/87 Run no. 1, 2, 3 Operator BARKER
 Sample type: single-point or multipoint; grab or integrated
 Analytical method ORSAT Comments LEAK CHECK 0.0
AMBIENT 20.0%

Sample point	24-hour clock time	% CO ₂	% O ₂		% CO	
		Reading 1	Reading 2	Net ^a	Reading 3	Net ^b
	1245	0.0	18.6	18.6	18.6	0.0
	1250	0.0	18.6	18.6	18.6	0.0
	1255	0.0	18.4	18.4	18.4	0.0
			18.4	18.4		
	1750	0.0	18.4	18.4	18.4	0.0
	1755	0.0	18.4	18.4	18.4	0.0
	1800	0.0	18.4	18.4	18.4	0.0
			18.4	18.4		
	2335	0.0	18.4	18.4	18.4	0.0
	2340	0.0	18.6	18.6	18.6	0.0
	2342	0.6	18.4	18.4	18.4	0.0
				18.4		
Averages			----		----	

$$\% N_2 = 100 - (\% CO_2 + \% O_2 + \% CO) =$$

$$MW_d = 0.440 (\% CO_2) + 0.320 (\% O_2) + 0.280 (\% N_2 + \% CO) =$$

$$^a \text{ Net } \% O_2 = \text{Reading 2} - \text{Reading 1}$$

$$^b \text{ Net } \% CO = \text{Reading 3} - \text{Reading 2}$$



APPENDIX B
LABORATORY REPORTS

Inter-Office Memorandum



TO: Jeff O'Neill
Josie King

FROM: Mike Taylor *mt*

DATE: 30 November 1987

PROJECT: **NJ PULVERIZING**

W.O. NO.: 2373-01-02-0025

SUBJECT: Analytical Results for Method 5 Source Samples
RFW Batch 8711-833

ACTION:

Attached are the results for the source emission samples submitted to WESTON Analytics on November 20, 1987. The samples were analyzed for particulates according to EPA Method 5.

Custody transfer record and raw data sheets are included for your information. Should you have any questions regarding this report, please do not hesitate to call.

/sma
Attachments



CLIENT: NJ PULVERIZING
DATE OF REPORT: 28 November 1987

TABLE OF RESULTS
EPA METHOD 5: PARTICULATE

<u>RFW NUMBER</u>	<u>CLIENT ID</u>	<u>DATE COLLECTED</u>	<u>DATE ANALYZED</u>	<u>*NET WEIGHT IN GRAMS</u>
8711-833-001	OUT-F-001	11-19-87	11-22-87	0.0148
8711-833-009	OUT-FHA-001		THRU 11-30-87	0.0812
8711-833-002	OUT-F-002	11-19-87	11-22-87	0.0095
8711-833-010	OUT-FHA-002		THRU 11-30-87	0.0588
8711-833-003	OUT-F-003	11-19-87	11-22-87	0.0153
8711-833-011	OUT-FHA-003		THRU 11-30-87	0.0730
8711-833-004	INL-F-001A	11-19-87	11-22-87	-0.0014
8711-833-005	INL-F-001B		THRU	-0.0005
8711-833-012	INL-FHA-001		11-30-87	0.1119
8711-833-016	INL-THB-001			SEE RAW DATA
8711-833-006	INL-F-002	11-19-87	11-22-87	-0.0010
8711-833-013	INL-FHA-002		THRU	0.1822
8711-833-017	INL-THB-002		11-30-87	SEE RAW DATA
8711-833-007	INL-F-003	11-19-87	11-22-87	0.0004
8711-833-014	INL-FHA-003		THRU	0.2127
8711-833-018	INL-THB-003		11-30-87	SEE RAW DATA
8711-833-008	BLNK-F-001	11-19-87	11-22-87	0.0003
8711-833-015	BLNK-FHA-001		THRU	0.0002
8711-833-019	BLNK-THB-001		11-30-87	SEE RAW DATA

* Note that acetone rinses have not been corrected for the blank.



Custody Transfer Record/Lab Work Request

Received By [Signature]
Date 11/20/87
Assigned to _____

Client N.J. Pulverizing
Client Contact B. SANTO
Phone _____

RFW Contact BABELEWIS
Date Due 12/18/87
Project Number 2373-01-02-0025

MILK

SAMPLE IDENTIFICATION

Sample No.	Client ID No.	Description	Matrix	Date Collected	Container/Preservative	EPA method	Analyses Requested
001	✓	OUT-F-001		11/19/87	Petri dish	✓	particulate
002	✓	OUT-F-002				✓	
003	✓	OUT-F-003				✓	
004	✓	INL-F-001A				✓	
005	✓	INL-F-001B				✓	
006	✓	INL-F-002				✓	
007	✓	INL-F-003				✓	
008	✓	BLANK-F-001				✓	
009	✓	OUT-FHA-001 (2 jars)				✓	
010	✓	OUT-FHA-002			Amber glass	✓	
011	✓	OUT-FHA-003				✓	
012	✓	INL-FHA-001				✓	
013	✓	INL-FHA-002				✓	
014	✓	INL-FHA-003				✓	
015	✓	BLANK-FHA-001				✓	
016	✓	INL-THB-001	*			✓	
017	✓	INL-THB-002	*			✓	
018	✓	INL-THB-003	*			✓	
019	✓	BLANK-THB-001				✓	

Special Instructions: * use caution when handling thimbles particulate is on outside. INL-THB-002 became wet during testing

Matrix:
S- Soil DS- Drum Solids
W- Water DL- Drum Liquids
O- Oil X- Other

Items/Reason	Relinquished By	Received By	Date	Time	Relinquished By	Received By	Date	Time
Analysis	[Signature]	[Signature]	11/20/87					

Plant N.J. Pulverizing
 Test Date 1-19-87
 Sampling Location _____
 Test Period _____
 Stack # Out - F-001 Run # _____ Process # _____

871-833

Beaker #	Volume ml	Tare (1) grams	Tare (2) grams	Final (1) grams	Final (2) grams	g wt. grams	Bk. Cor. grams	Net wt. grams
N-17	640	106.3743	106.3743	106.4556	106.4552	0.0812		0.0812
9376	-	14159	0.4160	0.4155	0.4308	0.0148		0.0148
FILTER 1 #								
FILTER 2 #								
FH TOTAL								
BHW								
BHA								
TOTAL								
Comments								

Plant N. T. 12-2-19 Run # 2 Process# _____
 Test Date 11-14-52 Stack # Out 1-002
 Sampling Location _____
 Test Period _____

Beaker #	Volume ml	Tare (1) grams	Tare (2) grams	Final (1) grams	Final (2) grams	Awt grams	Blk. Cor. grams	Net wt. grams
B-24	500	103.4857	103.4255	103.4842	103.4845	103.4845		0.058
9348	-	0.4112	0.4114	0.4208	0.4208	0.4208		0.009
FHA								
FILTER ₁ #								
FILTER ₂								
FH TOTAL								
BHW								
BHA								
TOTAL								
Comments								

Plant N.S. Plantations Run # 3 Process# _____
 Test Date 1-19-64 Stack # QATF-003
 Sampling Location _____
 Test Period _____

[illegible]

Comments	4771	84771	84771	0.4116	0.4116	0.005
9380						
160	104.8007	104.8005	104.8016	104.8020	104.8016	104.8018
-ACETONE BLK N-20						
WATER BLK						
CODE:						
FHA=Front half acetone wash						
acetone wash						
FH TOTAL=Front half catch weight						
BHW=Back half water (Impinger contents + water wash)						
BHA=Back half						
TOTAL=Total train catch weight						

Date 11-22 11:26

PARTICULATE SAMPLE ANALYSES

Analyst J. P. [unclear] Date 11-22 11:26

Plant N.J. Pulverizing
Test Date 11-19-87

Beaker #	Volume ml	Tare (1) grams	Tare (2) grams	Final (1) grams	Final (2) grams	Awt grams	Blk. Cor. grams	Net wt. grams
N-20	500	105.4753	105.4779	105.4751	105.5868	105.5870		0.1119
9347	-	0.4112	0.4114	0.4113	0.4099	0.4095		-0.0014
9377	-	0.4143	0.4142	0.4145	0.4138	0.41375		-0.0005
T-19	-			2.2745	2.2745	2.2745		
FH TOTAL								
BWA Thimbale								
FHA								
TOTAL								
Comments								

Plant N.J. Pulverizing
Test Date 11-19-87
Run # 132
Stack # FAL - F-001A
Process #

Beaker #	Volume ml	Tare (1) grams	Tare (2) grams	Final (1) grams	Final (2) grams	Awt grams	Blk. Cor. grams	Net wt. grams
N-21	440	107.4729	107.4726	107.4727	107.6551	107.6546		0.1822
9377	-	0.4176	0.4176	0.4176	0.4167	0.4165		-0.0010
FH TOTAL				2.4541	2.4537	2.4539		
BWA Thimbale								
BHA								
TOTAL								
Comments								

Plant N.J. Pulverizing
Test Date 11-19-87
Run # 3
Stack # FAL - F-002
Process #

Beaker #	Volume ml	Tare (1) grams	Tare (2) grams	Final (1) grams	Final (2) grams	Awt grams	Blk. Cor. grams	Net wt. grams
N-8	470	101.5059	101.5092	101.5005	101.7216	101.7219		0.2212
9368	-	0.4074	0.4074	0.4074	0.4079	0.4076		0.0004
FH TOTAL				2.1139	2.1138	2.1138		
BWA Thimbale								
BHA								
TOTAL				2.1932	2.1930	2.1931		
Comments								

Plant N.J. Pulverizing
Test Date 11-19-87
Run # 5
Stack # FAL - F-003
Process #

Beaker #	Volume ml	Tare (1) grams	Tare (2) grams	Final (1) grams	Final (2) grams	Awt grams	Blk. Cor. grams	Net wt. grams
N-9	470	101.5059	101.5092	101.5005	101.7216	101.7219		0.2212
9368	-	0.4074	0.4074	0.4074	0.4079	0.4076		0.0004
FH TOTAL				2.1139	2.1138	2.1138		
BWA Thimbale								
BHA								
TOTAL				2.1932	2.1930	2.1931		
Comments								

ACETONE BLK
WATER BLK
CODE:

FHA=Front half acetone wash BHA=Back half water (Impinger contents + water wash)
acetone wash FH TOTAL=Front half catch weight TOTAL=Total train catch weight



APPENDIX C SAMPLE CALCULATIONS



New Jersey Pulverizing,
11/19/87
1134-1415
SCRUBBER OUTLET

SAMPLE CALCULATIONS

Test Run No: 1

1. Volume of dry gas sampled at standard conditions, (70°F, 29.92 in. Hg), dscf.

$$V_{m(std)} = \frac{17.71 \times Y \times V_m \times (P_b + \frac{\Delta H}{13.6})}{T_m + 460}$$

$$V_{m(std)} = \frac{17.71 \times .9969 \times 37.72 \times (30.31 + \frac{1.36682}{13.6})}{(66.75 + 460)} = 38.447$$

Where:

- $V_{m(std)}$ = Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscf.
- V_m = Volume of gas sample measured by the dry gas meter at meter conditions, dcf.
- P_b = Barometric pressure, in. Hg.
- H = Average pressure drop across the orifice meter, in. H₂O.
- T_m = Average dry gas meter temperature, °F.
- 17.71 = Factor that includes ratio of standard temperature (530°R) to standard pressure (29.92 in. Hg), °R/in. Hg.
- Y = Dry gas meter calibration factor.

2. Volume of water vapor in the gas sample corrected to standard conditions, scf.

$$V_{w(std)} = (\quad \times V_{wc}) + (\quad \times W_{wsg})$$

$$V_{w(std)} = (0.04733 \times 46) + (0.0474 \times 15) = 2.9$$

Where:

- $V_{w(std)}$ = Volume of water vapor in the gas sample corrected to standard conditions, scf.
- V_{wc} = Volume of liquid condensed in impingers, mL.



- W_{wsg} = Weight of water vapor collected in silica gel, g.
- 0.04733 = Factor which includes the density of water (0.002201 lb/mL), the molecular weight of water (18.0 lb/lb-mole), the ideal gas constant (21.85 [in. Hg] [ft³]/[lb-mole][°R]; absolute temperature at standard conditions (530°R), absolute pressure at standard conditions (29.92 in. Hg), ft³/mL.
- 0.0474 = Factor which includes the molecular weight of water (18.0 lb/lb-mole), the ideal gas constant (21.85 [in. Hg][ft³]/[lb-mole][°R]), absolute temperature at standard conditions (530°R), absolute pressure at standard conditions (29.92 in. Hg), and 453.6 g/lb, ft³/g.

3. Moisture content.

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$
$$B_{ws} = \frac{2.9}{2.9 + 38.447} = 0.070$$

Where:

- B_{ws} = Proportion of water vapor, by volume, in the gas stream, dimensionless.

4. Mole fraction of dry gas.

$$M_d = 1 - B_{ws}$$
$$M_d = 1 - .07 = .930$$

Where:

- M_d = Mole fraction of dry gas, dimensionless.

5. Dry molecular weight of gas stream, lb/lb-mole.

$$MW_d = 0.440 (\%CO_2) + 0.320 (\%O_2) + 0.280 (\%N_2 + \%CO)$$
$$MW_d = (0.440 \times 0) + (0.320 \times 18.5) + [0.280 (81.5 + 0.0)]$$
$$= 28.74$$

Where:

MW_d	=	Dry molecular weight, lb/lb-mole.
$\%CO_2$	=	Percent carbon dioxide by volume, dry basis.
$\%O_2$	=	Percent oxygen by volume, dry basis.
$\%N_2$	=	Percent nitrogen by volume, dry basis.
$\%CO$	=	Percent carbon monoxide by volume, dry basis.
0.440	=	Molecular weight of carbon dioxide, divided by 100.
0.320	=	Molecular weight of oxygen, divided by 100.
0.280	=	Molecular weight of nitrogen or carbon monoxide, divided by 100.

6. Actual molecular weight of gas stream (wet basis), lb/lb-mole.

$$MW_s = (MW_d \times M_d) + (18 [1 - M_d])$$

$$MW_s = (28.74 \times .93) + (18 [1 - .93])$$

Where: $\quad = 28.74$

MW_s	=	Molecular weight of wet gas, lb/lb-mole.
18	=	Molecular weight of water, lb/lb-mole.

7. Average velocity of gas stream at actual conditions, ft/sec.

$$v_s = 85.49 \times C_p \times (\sqrt{\Delta p})_{avg} \times \left[\frac{T_s (avg)}{P_s \times MW_s} \right]^{\frac{1}{2}}$$

$$v_s = 85.49 \times .84 \times 1.146 \times \left[\frac{559.5}{30.31 \times 28} \right]^{\frac{1}{2}}$$

Where: $\quad = 66.6$

v_s = Average gas stream velocity, ft/sec.

85.49 = Pitot tube constant, ft/sec $\times$

$$\left[\frac{(lb/lb-mole)(in. Hg)}{(^{\circ}R)(in. H_2O)} \right]^{\frac{1}{2}}$$

- C_p = Pitot tube coefficient, dimensionless.
 Δp = Velocity head of stack gas, in H_2O .
 T_s = Absolute gas stream temperature, $^{\circ}R$.
 P_s = Absolute stack gas pressure, in. Hg.

8. Average gas stream dry volumetric flow rate, dscf/min.

$$Q_{s(std)} = \frac{1062.8 \times \sqrt{v_s} \times A_s \times M_d \times P_s}{T_s}$$

$$Q_{s(std)} = \frac{1062.8 \times 66.6 \times 6.87 \times .93 \times 30.31}{(99.5 + 460)}$$

$$= 24500$$

Where:

$Q_{s(std)}$ = Volumetric flow rate of dry stack gas, corrected to standard conditions, dscf/min.

A_s = Cross-sectional area of stack, $ft.^2$.

1062.8 = Factor which includes standard temperature ($530^{\circ}R$) standard pressure (29.92 in. Hg), and 60 sec/min, $\frac{(^{\circ}R)(sec)}{(in. Hg)(min)}$.

9. Isokinetic variation calculated from intermediate values, percent.

$$I = \frac{17.251 \times T_s \times V_{m(std)}}{\sqrt{v_s} \times \theta \times P_s \times M_d \times (D_n)^2}$$

$$I = \frac{17.251 \times 559.5 \times 38.447}{66.6 \times 60 \times 30.31 \times .93 \times (.185)^2}$$

$$= 96.4$$



Where:

- I = Percent of isokinetic sampling.
- θ = Total sampling time, minutes.
- D_n = Diameter of nozzle, inches.
- 17.251 = Factor which includes standard temperature (530°R)
standard pressure (29.92 in. Hg), the formula for
calculating area of circle $\frac{\pi D^2}{4}$, conversion of
square feet to square inches (144), conversion of
seconds to minutes (60), and conversion to percent
(100), $\frac{(\text{in. Hg}) (\text{in}^2) (\text{min})}{(\text{°R}) (\text{ft}^2) (\text{sec})}$.

10. Particulate concentration, gr/dscf.

$$C_1 = \frac{0.015432 \times M_t}{V_{m(\text{std})}}$$
$$C_1 = 0.015432 \times \frac{74.9}{33.447} = .0381$$

Where:

- C_1 = Particulate concentration, gr/dscf.
- M_t = Total weight of particulate caught by train, mg.
- 0.015432 = Conversion factor of gr/mg.

11. Particulate mass emission rate, lb/hr.

$$\text{PMR}_t = 0.0085714 \times C_1 \times Q_{s(\text{std})}$$
$$= 0.0085714 \times .0381 \times 24500 = 8.0$$

Where:

- PMR_t = Particulate mass emission rate, lb/hr.
- 0.0085714 = Conversion factor relating minutes to hours (60),
and grains to pounds (7,000), (lb) (min)/(gr) (hr).

12. Particulate Removal Efficiency

$$\%E = \frac{PMR_i - PMR_o}{PMR_i} \times 100$$

$$\%E = \frac{58.99 - 7.99}{58.99} \times 100$$

$$= 86.46$$

%E = Percent Efficiency

PMR_i = Pollutant Mass Rate at Scrubber inlet, lbs/hr

PMR_o = Pollutant Mass Rate at Scrubber Outlet, lbs/hr

Sand Captured by Cyclone

IN	TIME	HOURS	lbs of Sand	lbs/hr
T	1137-1420	2.72	108.5	39.89
	1729-1842	1.22	53.5	43.85
2	2115-2244	1.48	73.5	49.66

Sand was weighed and recorded
by WESTON



APPENDIX D
EQUIPMENT CALIBRATION RECORDS

METER BOX CALIBRATION DATA AND CALCULATION FORM

New Orleans

Date 11 September 1981

Meter Box Number NOTCE 40 # 9

Barometric pressure, $P_b =$ 30.16 in. Hg

Calibrated by James Wood

Office manometer reading (ΔH), in. H ₂ O	Gas volume		Temperatures				Time (θ), min	Y_i	ΔH_e in. H ₂ O
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Dry gas meter					
				Inlet (t_{di}), °F	Outlet (t_{do}), °F	Avg ^a (t_d), °F			
0.5	5	012.966 017.960	71	75 75 76	74 74 75	74.5	12.44	1.007	1.705
0	5	018.702 023.708	71	76 76 76	75 75 75	75.5	8.85	1.005	1.734
1.5	10	024.200 034.212	71	76 76 76	75 75 76	75.7	14.8	1.004	1.818
0	10	034.959 044.987	71	76 77 77	75 76 77	76.3	12.95	1.002	1.853
0	10	045.784 055.845	71	77 78 78	76 77 79	77.5	10.8	.9988	1.929
4.0	10								
Avg								Y 1.003	ΔH_e 1.808

$\frac{\Delta H}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H_{e_i} = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]$
0.5	0.0368 534.8-30.16-5 531-30.20-4.994	1.007 1.007 531-12.4 1.705
1.5	0.0735 535.5-30.16-5 531-30.23-5.005	1.005 1.005 531-8.85 1.734
2.0	0.110 535.7-30.16-10 531-30.27-10.012	1.004 1.004 531-14.8 1.818
2.0	0.147 536.3-30.16-10 531-30.31-10.028	1.002 1.002 531-12.95 1.853
3.0	0.221 537.5-30.16-10 531-30.38-10.061	.9988 .9988 531-10.8 1.929
4.0	0.294	

If there is only one thermometer on the dry gas meter, record the temperature under t_d .

Test numbers Date 9 Oct 1984 Meter box number 21 Plant SCM-CORP
 Barometric pressure, $P_b = 30.36$ in. Hg Dry gas meter number Pretest $Y = 1.003$

Specific anometer setting, (ϵ_H), in. H ₂ O	Gas volume		Temperature				Time (t), min	Vacuum setting, in. Hg.	Y_i	$Y_i = \frac{V_w P_b (\epsilon_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (\epsilon_w + \frac{\Delta H}{13.6})}$	$Y = .9977$
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (ϵ_w), of	Dry gas meter		Average (ϵ_d), of					
				Inlet (ϵ_{d1}), of	Outlet (ϵ_{d2}), of						
1.5"	10	323.803 338.845	73 74	74 76	74.8	14.98	4.0"	.9966			
1.5"	10	338.845 348.992	75 75	76 78	76	14.98	4.0"	.9983			
1.5"	10	348.992 359.118	76 77	78 79	77.5	14.45	4.0"	.9983			

If there is only one thermometer on the dry gas meter, record the temperature under ϵ_d .

V_w = Gas volume passing through the wet test meter, ft³.

V_d = Gas volume passing through the dry gas meter, ft³.

ϵ_w = Temperature of the gas in the wet test meter, °F.

ϵ_d = Temperature of the inlet gas of the dry gas meter, °F.

ϵ_{d2} = Temperature of the outlet gas of the dry gas meter, °F.

ϵ_d = Average temperature of the gas in the dry gas meter, °F.

ΔH = Pressure differential across orifice, in H₂O.

Y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.

Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs;

P_b = Barometric pressure, in. Hg.

Δ = Time of calibration run, min.

$$Y_i = \frac{\frac{\Delta H}{13.6}}{\frac{V_w P_b (\epsilon_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (\epsilon_w + \frac{\Delta H}{13.6})}}$$

$$\Delta H = \frac{P_b (\epsilon_d + 460)}{0.0317 \Delta H} \left[\frac{(\epsilon_w + \frac{\Delta H}{13.6})}{V_w} \right]$$

NOTE W

Test numbers _____ Date 22 OCT - 1957 Meter box number # 6 Plant _____

Barometric pressure, $P_b = \underline{30.35}$ in. Hg Dry gas meter number _____ Protest Y 1.006

Orifice nometer setting. (mm). N ₂ O	Gas volume		Wet test meter (t _w). OF	Temperature			Time (t). min	Vacuum setting. in. Hg.	Y ₁	Y ₁ = $\frac{V_w P_b (\epsilon_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (\epsilon_w + 460)}$
	Wet test meter (V _w). ft ³	Dry gas meter (V _d). ft ³		Dry gas meter		Average (t _d). OF				
				Inlet (t _{d1}). OF	Outlet (t _{d2}). OF					
1.0"	10	215.223	68	71	72.8	17.8	4.0"	1.001		
1.0"	10	225.285	68	72	73	17.83	4.0"	1.004		
1.0"	10	235.342	68	73	74	17.88	4.0"	1.003		
				74	75				Y = 1.002	

if there is only one thermometer on the dry gas meter, record the temperature under t_d .

- | | | |
|------------|--|---|
| V_w | - Gas volume passing through the wet test meter, ft ³ . | $V_w P_b (t_d + 460)$ |
| V_d | - Gas volume passing through the dry gas meter, ft ³ . | $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$ |
| t_w | - Temperature of the gas in the wet test meter, °F. | |
| t_d | - Temperature of the inlet gas of the dry gas meter, °F. | |
| t_{do} | - Temperature of the outlet gas of the dry gas meter, °F. | |
| t_d | - Average temperature of the gas in the dry gas meter. | $\frac{t_{d1} + t_{d0}}{2}$ |
| ΔH | - Pressure differential across orifice, in H ₂ O. | $\frac{0.0317 \Delta H}{P_b (t_d + 460)}$ |
| Y_i | - Ratio of accuracy of wet test meter to dry gas meter for each run. | $\Delta H \theta_i$ |
| Y | - Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest $Y \pm 0.05Y$ | |
| P_b | - Barometric pressure, in. Hg. | |

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 2/16/87 Thermocouple number WUTech #6
 Ambient temperature 73 °F Barometric pressure 30.14 in. Hg
 Calibrator: JMB Reference: mercury-in-glass yes
 other

Reference point number	Source ^a (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Temperature difference, %
32°F	ice BATH	32°F	32°F	0.0 %
73°F	Ambient	73°F	72°F	-0.19 %
379°F	Hot oil	379°F	381°F	+0.24 %

^aType of calibration system used.

$$^b \left[\frac{(\text{ref temp, } ^\circ\text{F} + 459.67) - (\text{test thermom temp, } ^\circ\text{F} + 459.67)}{\text{ref temp, } ^\circ\text{F} + 459.67} \right] 100 \leq 1.5\%$$

New Calibration METER BOX CALIBRATION DATA AND CALCULATION FORM

te 14 August 1987

Meter Box Number NOTE: 60
6

Barometric pressure, P_b = 30.24 [±] in. Hg

Calibrated by James Wood

Office manometer reading (ΔH), in. H ₂ O	Gas volume		Temperatures				Time (θ), min	Y_i	ΔH_{θ} in. l
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Dry gas meter					
				Inlet (t_{di}), °F	Outlet (t_{do}), °F	Avg ^a (t_d) °F			
0.5	5	588.700 593.703	72.5	77 75	78 79	78.3	12.4	1.009	1.64
1.0	5	594.448 599.460	72.5	78 78	78 79	78.1	8.81	1.007	1.73
1.5	10	599.957 610.026	72.5	78 79	79 81	80.0	14.78	1.003	1.79
2.0	10	610.523 620.649	72.5	80 80	81 85	82.2	13.23	1.001	1.919
2.5	10	621.407 631.597	72.5	80 80	81 85	82.2	10.88	.9923	1.772
3.0	10								
Avg							Y	1.002	ΔH_{θ} 1.784

$\frac{\Delta H}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H_{\theta_i} = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]$
0.0368	588.3 - 30.24 - 5 593.5 - 30.25 - 5.003 1.009	.01585 .000001 532.5 - 12.4 588.3 - 30.24 5.5 ✓
0.0735	588.7 - 30.24 - 5 592.5 - 30.31 - 5.012 1.007	.0317 .0000019 532.5 - 8.81 588.7 - 30.24 5.5 ✓
0.110	540 - 30.24 - 10 593.5 - 30.35 - 10.069 1.003	.04755 .0000017 532.5 - 14.78 540 - 30.24 5.10 ✓
0.147	542.2 - 30.24 - 10 592.5 - 30.39 - 10.121 1.001	.0634 .0000029 532.5 - 13.23 542.2 - 30.24 5.10 ✓
0.221	542.2 - 30.24 - 10 592.5 - 30.46 - 10.187 .9923	.0951 .0000054 532.5 - 10.88 542.2 - 30.24 5.10 ✓
0.294		

If there is only one thermometer on the dry gas meter, record the temperature under t_d .

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 2/16/87 Thermocouple number NOTECH #7
 Ambient temperature 73 °F Barometric pressure 30.14 in. Hg
 Calibrator: JMB Reference: mercury-in-glass yes
 other

Reference point number	Source ^a (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Temperature difference, %
32°F	ICE BATH	32°F	32°F	0.0 %
73°F	Ambient	73°F	72°F	- 0.19 %
379°F	Hot oil	379°F	379°F	0.0 %

^aType of calibration system used.

^b
$$\left[\frac{(\text{ref temp, } ^\circ\text{F} + 459.67) - (\text{test thermom temp, } ^\circ\text{F} + 459.67)}{\text{ref temp, } ^\circ\text{F} + 459.67} \right] 100 \leq 1.5\%$$

TYPE S PITOT TUBE INSPECTION DATA FORM

Pitot Tube P-8

Pitot tube assembly level? ☒ yes ☐ no

Pitot tube openings damaged? ☐ yes (explain below) ☒ no

$\alpha_1 = 1^\circ (<10^\circ)$, $\alpha_2 = 2^\circ (<10^\circ)$, $\beta_1 = 1^\circ (<5^\circ)$,
 $\beta_2 = 2^\circ (<5^\circ)$

$\gamma = 1^\circ$, $\theta = 1^\circ$, $A = .936$ cm (in.)

$z = A \sin \gamma = .016$ cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta = .016$ cm (in.); $<.08$ cm ($<1/32$ in.)

$P_A = .468$ cm (in.) $P_b = .468$ cm (in.)

$D_t = .374$ cm (in.)

Comments: Inspected 7/10/57 B. Strub

Calibration required? ☐ yes ☒ no

TYPE S PITOT TUBE INSPECTION DATA FORM

Pitot Tube P-7

Pitot tube assembly level? ☒ yes ☐ no

Pitot tube openings damaged? ☐ yes (explain below) ☒ no

$\alpha_1 = 1^\circ (<10^\circ)$, $\alpha_2 = 1^\circ (<10^\circ)$, $\beta_1 = 1^\circ (<5^\circ)$,
 $\beta_2 = 2^\circ (<5^\circ)$

$\gamma = 1^\circ$, $\theta = 1^\circ$, $A = 1.034$ cm (in.)

$z = A \sin \gamma = .014$ cm (in.); <0.32 cm ($<1/8$ in.),

$w = A \sin \theta = .014$ cm (in.); $<.08$ cm ($<1/32$ in.)

$P_A = .517$ cm (in.) $P_b = .517$ cm (in.)

$D_t = .375$ cm (in.)

Comments: INSPECTED 7/10/87 B Straub

Calibration required? ☐ yes ☒ no

Protest Y, 9962

24

Water box number

Date of birth 1957

Test numbers

Barometric pressure, P_b = ~~30.24~~ 31.1 in. Hg

Protest Y, 9962

Orifice diameter setting. (mm).	Gas volume		Temperature				Time (t), min	Vacuum setting, in. Hg.	Y_1	$Y_1 = \frac{V_w P_b (c_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (c_w + 4)}$
	Gas volume		Dry gas meter		Wet test meter (c _w) of	Average (c _d) of				
	Wet test meter (V _w) ft ³	Dry gas meter (V _d) ft ³	Inlet (c _{d1}) of	Outlet (c _{d2}) of						
1.74	10	570.856	72.57	77	78	78	14.03	6"	.9968	
		580.950		76	77	79				
1.74	10	580.950	72.5	79	77	83	14.08	6"	.9964	
		591.080		78	79	83				
1.70	10	591.080	72.5	79	83	83	14.13	6"	.9983	
		601.231		80	81	85				$Y = .9971$

Is only one thermometer on the dry gas meter, record the temperature under test.

V = Gas volume passing through the wet test meter, ft.³.

$$V_{\text{gas}} = \text{gas volume passing through the wet gas meter, ft}^3$$

V_d = Gas volume passing through the dry gas meter, of.
= Temperature of the gas in the wet test meter, of.

Temperature of the gas in the wet test meter, t_w , of.

Temperature of the inlet gas of the dry gas meter, °F.

- Temperature of the outlet gas of the dry gas meter.

t_d - Average temperature of the gas in the dry gas passage differential across orifice, in H₂O.

ΔH = Pressure differential across orifice, in H₂O.

y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.

$$Y = \text{Average ratio of accuracy of } Y$$

$$\text{tolerance} = \text{pretest } Y + 0.05$$

• = Barometric pressure, in. Hg.

P₀ = Barometric pressure, mm. Hg.
A₀ = Time of calibration run, min.

$\frac{\Delta H_i}{\text{in. H}_2\text{O}}$	$\frac{\Delta H}{13.6}$	$\dots$	$\frac{V_w P_b (c_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (c_w + 460)}$
$+ \frac{t_{d0}}{2}, \text{ } ^\circ\text{F.}$	$\Delta H \theta_i$	$\dots$	$\frac{(c_w + 460)}{V_w}$

INSTRUMENT: W 29

DATE: 24 Nov 1987 TIME: 09:11 AS: ER ON: AF

NOTES: Plant N.J. DULTERIZING

Test numbers: 30639 F Meter box number: # 7 Plant: N.J. DULTERIZING
 Barometric pressure, P_b = 30.639 F in. Hg Dry gas meter number: Protest Y .9969

Orifice diameter (in.)	Gas volume		Temperature		Time (t), min	Vacuum setting, in. Hg.	Y_i	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$
	Wet test meter (V_w), ft^3	Dry gas meter (V_d), ft^3	Wet test meter (t_w), OF.	Dry gas meter Inlet (t_{d1}), OF. Outlet (t_{d2}), OF. Average (t_d), OF.				
1.5"	10	511.180	73	74 76 77 75	14.72	10"	.9968	
1.5"	10	531.213	73	76 78 79 77	14.46	10"	.9983	
1.5"	10	531.539	73	77 79 80 79	14.50	10"	.9974	
							$Y = .9975$	

If there is only one thermometer on the dry gas meter, record the temperature under t_d .

V_w = Gas volume passing through the wet test meter, ft^3 .
 V_d = Gas volume passing through the dry gas meter, ft^3 .
 t_w = Temperature of the gas in the wet test meter, OF.
 t_{d1} = Temperature of the inlet gas of the dry gas meter, OF.
 t_{d2} = Temperature of the outlet gas of the dry gas meter, OF.
 t_d = Average temperature of the gas in the dry gas meter, OF.
 ΔH = Pressure differential across orifice, in H₂O.
 Y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.
 Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs;
 P_b = Barometric pressure, in. Hg.
 t = Time of calibration run, min.

$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$
 $\Delta H = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460)}{V_w} \right]$

ON-SITE
NOZZLE CALIBRATION DATA FORM

Date 11-16-87

Calibrated by RAKIEWICZ

Nozzle identification number	Nozzle diameter, inches ^a			ΔD , ^b	D_{avg} ^c
	D_1	D_2	D_3		
N-9	.120	.121	.120	.001	.120
N-12	.176	.175	.175	.001	.175
N-5	.184	.185	.185	.001	.185

Where:

^a $D_{1,2,3}$ = three different nozzle diameters, inches; each diameter must be measured to nearest 0.001 in.

^b ΔD = maximum difference between any two diameters, inches.
 ΔD must be ≤ 0.004 in.

^c D_{avg} = nozzle diameter = average of D_1 , D_2 and D_3 .



APPENDIX E
WESTON PROJECT PARTICIPANTS

PROJECT PARTICIPANTS

The following WESTON employees participated in this project:

Richard B. Ruch, JR
Project Director

econENVIRONomics Division

Barry L. Jackson
Project Manager

econENVIRONomics Division

Roy Rakiewicz
Asst. Project Scientist

econENVIRONomics Division

Ted Barker
Project Technician

econENVIRONomics Division

Denise Alston
Asst. Proj. Engineer

econENVIRONomics Division

Dan Miesse
Project Technician

econENVIRONomics Division

Micheal Taylor
Laboratory Supervisor

WESTON ANALYTICS