

August, 2001

**COMPLIANCE REPORT**

(ADDENDUM)

**COMPLIANCE TEST PROGRAM  
for  
PARTICULATE EMISSIONS  
from  
FLASH DRYER #3**

Submitted For:  
**OMYA, INC.**  
61 Main Street  
Proctor, Vermont 05765

Purchase Order Number: 95782

Submitted To:  
**AGENCY OF NATURAL RESOURCES  
DEPARTMENT OF ENVIRONMENTAL CONSERVATION  
AIR POLLUTION CONTROL DIVISION**  
103 South Main Street  
Waterbury, Vermont 05671-0402

Prepared by:  
**AIR QUALITY TECHNICAL SERVICES, INC.**  
18 Morse Drive  
Essex Junction, Vermont 05452

Project Number: 001266

January 24, 2001




## FOREWORD

Air Quality Technical Services, Inc., an environmental consulting company specializing in air resource management and air quality assessment, was contracted by OMYA, Inc. to conduct a source emission compliance program at the non-metallic mineral processing facility it owns and operates in Florence, Vermont.

This report presents additional program results, test and analytical data not previously presented.

To the best of my knowledge the data contained herein are correct and reliable.

  
John J. Jasko  
President

## 1.0 INTRODUCTION

This document summarizes program data generated from test run 1-2 conducted during the initial phase of compliance testing on August 10, 2000. All other information pertaining to testing methodologies is the same as presented in the formal Compliance Report dated October 27, 2000.

The major on-site representatives that participated in the field portion of the particulate emission compliance program, on August 10, and their respective affiliations were:

OMYA, Inc.

Neal Jordan - Environmental Engineer

Jim Prior - Engineer

State of Vermont Agency of Natural Resources, Air Pollution Control Division

Dave Manning - Environmental Technician

Air Quality Technical Services, Inc.

John Jasko - Project Director

Michael Spector - Environmental Technician

## 2.0 SUMMARY OF RESULTS

Particulate matter was measured as a non-filterable sample fraction collected by a filter media and preceding section of sample train. This fraction includes particulates greater than or equal to the particle cut point size of the filter media (0.3  $\mu$ ).

### 2.1 FLASH DRYER #3

#### 2.1.1 Particulate Matter

The concentrations of PM for test run 1-2, the sole valid test run conducted August 10, was 0.0069 gr/dscf. The corresponding emission rate of PM was 0.66 lbs/hr.

A summary of the PM test determinations for test run 1-2 for Flash Dryer #3 is presented in Table 2-1.

**TEST DATA SUMMARY****FLASH DRYER #3**

<b>PARTICULATE MATTER</b>	
<b>Test Run</b>	1-2
Date	08/10/2000
Clock Time (24 hour)	14:46-16:26
Test Duration (minutes)	96
Sample Volume (dscf)	68.845
<b>Test Measurements</b>	
Isokinetics (%)	92.3
Moisture Content (%)	18.8
Temperature (°F)	303.1
Gas Composition - CO <sub>2</sub> (%)	2.5
O <sub>2</sub> (%)	18.5
CO (%)	0
N <sub>2</sub> (%)	79.0
Gas Velocity (fps)	69.1
Gas Volumetric Flow (dscfm)	11198
(acfm)	20353
<b>Emission Determinations</b>	
<b>Particulate:</b>	
Concentration (gr/dscf)	0.0069
Emission Rate (lbs/hr)	0.66

Table 2-1

**APPENDIX A**

## FIELD DATA TEST RESULTS

CLIENT: OMYA, INC.  
FACILITY: FLORENCE, VT  
PROJECT: 001266  
UNIT: FLASH DRYER 3  
TEST DATE: August 10, 2000  
TEST RUN: 1-2

### TEST DATA SUMMARY

#### INPUT VALUES

Pitot Coefficient - Cp:	0.84	Average Delta P ("H2O):	0.969
Nozzle Diameter - Dn (in):	0.25	Average Delta H ("H2O):	2.079
Dry Gas Meter Cal. (Y):	1.008	Stack Temperature - Ts (°F):	303.1
Stack Area (ft <sup>2</sup> ):	4.909	Meter Temperature - Tm (°F):	120.4
Barometric Press. - Pb ("Hg):	29.34	Average Square Root of Delta P:	0.981
Static Press. - Pst ("Hg):	-0.51	Mass of Particulate Collected - Mp - (g.):	0.0307
Sample Duration (min.):	96		
Volume of Gas Metered - Vm (ft <sup>3</sup> ):	76.646		
Volume of Water Condensed - Vlc (g.):	338.2		
Oxygen - O2 (%):	18.5		
Carbon Dioxide - CO2 (%):	2.5		
Carbon Monoxide - CO (%):	0		
Nitrogen - N2 (%):	79		

#### OUTPUT VALUES

Dry Gas Volume (Standard) - Vmstd (dscf):	68.845
Volume of Water (Standard) - Vwstd (scf):	15.919
Stack Gas Water Proportion by Volume - Bwo:	0.188
Molecular Weight of Dry Stack Gas - MWd (lb/lb-mole):	29.14
Molecular Weight of Stack Gas - MWs (lb/lb-mole):	27.05
Pressure of Stack - Ps ("Hg.):	29.3
Velocity of Stack Gas - Vs (fps):	69.1
Dry Standard Volumetric Flow of Stack Gas - Qdscfm:	11198
Actual Volumetric Flow of Stack Gas - Qacfm:	20353
Test Isokinetic Sample Rate (%):	92.3
Particulate Concentration of Stack Gas - Cs (gr/dscf):	0.0069
Particulate Emission Rate - ER (lbs/hr):	0.66

000001

**APPENDIX B**

**000002**



OMYA, INC., FLORENCE, VT

PROJECT: 001266

FLASH DRYER #3

PARTICULATE CONCENTRATION AND EMISSION DATA

SAMPLE ID	TEST RUN	GROSS SAMPLE MASS (g)	NET SAMPLE MASS (g)	AIR VOLUME SAMPLED (dscf)	EMISSION CONCENTRATIONS			VOLUMETRIC AIR FLOW (dscfm)	EMISSION RATE (lbs/hr)
					(gr/dscf)	(mg/dscm)	(lbs/dscf)		
C819/C820	1-2	0.0324	0.0307	68.845	0.0069	15.75	9.83E-007	11198	0.66
C828	BLANK	0.0017							
VERAGES					0.0069	15.75	9.83E-007	11198	0.66

000003

**APPENDIX C**

# ISOKINETIC STACK CALCULATOR

(Revised 06/03/96)

## INPUT PARAMETERS

PITOT COEFFICIENT (Cp):	0.84
METER TEMPERATURE (°F):	115
STACK TEMPERATURE (°F):	305
AVERAGE DELTA P ("H2O):	1
MAXIMUM DELTA P ("H2O):	1.3
ESTIMATED MOISTURE (%):	24
METER BOX NUMBER:	1284-239
DELTA H @:	1.919

## NOZZLE DIAMETER (Dn) DATA

CALCULATED DIAMETER (in.):	0.2382
SELECTED SIZE (in.):	0.25

## CALCULATED PARAMETERS

K FACTOR =	2.1468
ISOKINETIC DELTA H ("H2O) =	2.15
MAX DELTA H ("H2O) =	2.79

## SAMPLING PARAMETERS

MIMIMUM SAMPLE VOLUME REQUIRED (dscf):	60
SAMPLE TIME REQUIRED (min):	86
SAMPLE RATE > 0.75 CFM	0.79
MAX SAMPLE RATE > 0.75 cfm:	0.9

PROJECT NUMBER:	001266
TEST RUN NUMBER:	1-2

000004

**METHOD 5**

CLIENT: OMYA, INC.  
 FACILITY: FLORENCE, VT  
 PROJECT: 001266  
 UNIT: FLASH DRYER 3  
 TEST DATE: August 10, 2000  
 TEST RUN: 1-2

Barometric Press. - Pb ("Hg): 29.34  
 Static Press. - Pst ("H2O): -0.51  
 Stack Press. - Ps ("Hg.): 29.30  
 Pilot Coefficient - Cp: 0.84  
 Nozzle Diameter - Dn (in): B-4  
 Meter Box Number: 1284-239  
 Dry Gas Meter Cal. (Y): 1.008  
 Stack area (ft<sup>2</sup>): 4.909  
 Filter Number(s): 42-002

Run Clock Time (24-Hr.): 14:46-16:26  
 Sample Duration (min.): 96  
 Number of Sample Points: 24

Impinger Volume (ml)	
Initial	Final
1>	100
2>	100
3>	0
Silica Gel (g)	
Initial	Final
200	222.2
Total Volume>	
	338.2

Gas Composition	
O2	18.5
CO2	2.5
CO	0
N2	79

Vacuum Leak Check	
Leak Rate (cf)	Vacuum ("Hg.)
Pre-test: 0.006	15
Post-test: 0.009	15

Pilot Leak Checks	
Pre-test:	OK
Post-test:	OK
	OK
	OK

SAMPLE POINT	CLOCK TIME (24 Hr)	GAS METER READING (cf)	DELTA P (In. H2O)	DESIRED DELTA H (In. H2O)	ACTUAL DELTA H (In. H2O)	STACK TEMPERATURES (°F)	TEMPERATURES (°F)		PERCENT ISO
							INLET	OUTLET	
E1	14:46	77.228	1.1	2.36	2.36	305	120	100	88.1
2	14:50	80.24	1.05	2.25	2.25	308	133	102	102.7
3	14:54	83.71	1.1	2.36	2.36	308	133	104	98.8
4	14:58	87.13	1.2	2.58	2.58	310	133	105	96.4
5	15:02	90.61	1.1	2.36	2.36	307	135	107	100.3
6	15:06	94.1	1.05	2.25	2.25	308	135	107	98.6
7	15:10	97.45	1.1	2.36	2.36	306	136	108	97.8
8	15:14	100.86	1.1	2.36	2.36	304	135	108	98.6
9	15:18	104.3	1.05	2.25	2.25	308	134	109	98.6
10	15:22	107.66	0.88	1.89	1.89	304	134	107	99.7
11	15:26	110.77	0.72	1.55	1.55	300	132	109	102.7
12	15:30	113.68	0.68	1.46	1.46	290	129	108	100.1
END	15:34	116.444							
B1	15:38	116.444	0.8	1.72	1.72	305	118	106	93.4
2	15:42	119.18	0.78	1.67	1.67	307	130	107	96.5
3	15:46	122	0.9	1.93	1.93	305	133	108	87.9
4	15:50	124.77	1	2.15	2.15	301	132	109	92.8
5	15:54	127.86	1.05	2.25	2.25	301	133	109	96.9
6	15:58	131.17	1.1	2.36	2.36	307	136	110	98.5
7	16:02	134.61	1.1	2.36	2.36	305	136	110	99.5
8	16:06	138.09	1.1	2.36	2.36	303	138	110	99
9	16:10	141.56	1.05	2.25	2.25	301	138	111	98.7
10	16:14	144.95	0.94	2.02	2.02	300	138	111	100.2
11	16:18	148.21	0.68	1.46	1.46	294	136	111	101.1
12	16:22	151.02	0.62	1.33	1.33	288	132	112	107.5
END	16:26	153.874							

000003

APPENDIX D





# SAMPLE WEIGHT LOG SHEET

Client: OMYA, Inc.  
 Facility: Florence, VT  
 Project: 001266 - FD#3

Sample Number	Identification	Date/Time			
	Tare Weight (g.)	Gross Weight (g.)			
C819	PF 42-002	08/15/00 - 08:00	08/16/00 - 07:30	08/16/00 - 15:30	08/21/00 - 06:30
	0.9241	0.9491	0.9482	0.9464	0.9468
C820	Beaker 1500	08/15/00 - 08:00	08/16/00 - 07:30	08/16/00 - 15:30	08/21/00 - 06:30
	69.1200	69.1311	69.1291	69.1297	69.1297

000008



**PARTICULATE LAB ANALYSIS  
SUMMARY SHEET**

Client: OMYA, Inc. Project Number: 001266 Test/Run: 1-2

**Sample Identification**

Number	Description
C819	PF 42-002
C820	Front half acetone wash - 225 ml A/P
C828	Acetone blank - 225 ml A/P

**Acetone Blank Background Data**

Manufacturer: Anachemia Lot/Batch: 990413 Density: 0.7857 g/ml  
 $C_a$  = Acetone blank residue concentration (mg/mg)  
 $m_a$  = Mass of acetone residue after evaporation (mg)  
 $V_a$  = Volume of acetone blank (ml)  
 $\rho_a$  = Density of acetone (mg/ml)

$$C_a = m_a / (V_a \rho_a) = ( 1.7 ) / ( 225 ) ( 0.0007857 ) = \underline{9.616 \text{ mg/mg}}$$

**Front Half Acetone Wash Data**

$W_a$  = Weight of acetone residue in wash (mg)  
 $V_{aw}$  = Volume of acetone wash (ml)

$$W_a = C_a V_a \rho_a = ( 9.616 ) ( 225 ) ( 0.0007857 ) = \underline{1.7 \text{ mg}}$$

**Acetone Wash Data**

Beaker Number: <u>150/O</u>	Gross Weight (g):	60.1297
	Tare Weight (g):	60.1200
	Blank Weight (g):	0.0017
	Net Weight (g):	0.0080

**Filter Data**

Filter Number: <u>42-002</u>	Gross Weight (g):	0.9468
	Tare Weight (g):	0.9241
	Net Weight (g):	0.0227

**Particulate Weight Summary**

Weight of particulate in front half wash (g):	0.0080
Weight of particulate on filter (g):	0.0227
Total weight of particulate catch (g):	0.0307

000009

**APPENDIX E**

**METER BOX CALIBRATION  
SEMI-ANNUAL**

DATE: 03-Jul-00  
CALIBRATED BY: Mike Spector

METER BOX NUMBER: 1084-239  
NEXT CAL DUE: 02-Jan-01

BAROMETRIC PRESSURE (In. Hg)	ORIFICE MANOMETER SETTING (In. H <sub>2</sub> O)	WET TEST METER VOLUME (cf)	DRY GAS METER VOLUME		WET TEST METER (°F)	TEMPERATURES DRY GAS METER			TIME (min)	Y <sub>i</sub>	DELTA H <sub>@</sub>
			INITIAL (cf)	FINAL (cf)		INLET (°F)	OUTLET (°F)	AVERAGE (°F)			
29.91	0.5	5	177.848	182.862	74.0	79	75	83.5	12.78	1.014	1.816
29.91	1.0	5	183.042	188.143	74.0	100	80	93.0	9.35	1.013	1.911
29.91	1.5	10	189.145	199.526	74.0	110	86	100.0	15.43	1.006	1.927
29.91	2.0	10	199.745	210.236	74.0	114	93	105.3	13.45	1.004	1.934
29.91	3.0	10	210.767	221.315	74.0	122	96	110.0	11.07	1.005	1.949
29.91	4.0	10	221.971	232.551	74.0	119	96	112.5	9.67	1.003	1.975
						127	98				
						128	101				
AVERAGE										1.008	1.919

TOLERANCES FROM AVERAGE FOR Y<sub>i</sub> and DELTA H<sub>@</sub> ARE <0.02 AND 0.20, RESPECTIVELY

Y <sub>i</sub>	Y <sub>i</sub> DIFF	DELTA H <sub>@</sub>	DELTA H <sub>@</sub> DIFF
1.014	0.006	1.816	-0.103
1.013	0.005	1.911	-0.008
1.006	-0.002	1.927	0.008
1.004	-0.004	1.934	0.015
1.005	-0.003	1.949	0.030
1.003	-0.005	1.975	0.056

000010

**METER BOX CALIBRATION  
(POST-TEST)**

PROJECT: 001266  
 DATE: 25-Oct-00  
 CALIBRATED BY: Roland Tremble

METER BOX NUMBER: 1084-239  
 PRETEST CAL Y: 1.008

BAROMETRIC PRESSURE (In. Hg)	ORIFICE MANOMETER SETTING (In. H <sub>2</sub> O)	MAXIMUM VACUUM (In. H <sub>2</sub> O)	WET TEST METER VOLUME (cf)	DRY GAS METER VOLUME		WET TEST METER (°F)	TEMPERATURES			TIME (min)	Yt
				INITIAL (cf)	FINAL (cf)		DRY GAS METER				
							INLET (°F)	OUTLET (°F)	AVERAGE (°F)		
30.06	2.10	13.0	10	557.782	568.079	59.5	100	69	87.3	13.16	1.018
30.06	2.10	13.0	10	568.079	578.581	59.5	107	73	93.3	13.17	1.009
30.06	2.10	13.0	10	578.581	589.238	59.5	105	74	98.8	13.18	1.004
							113	81			
							108	83			
							117	87			
										AVERAGE	1.010

ACCEPTABLE VARIATION IN CALIBRATION  
 (Must be less than 5% of Pretest Meter Calibration)

Difference from Pretest Calibration = 0.2 % >>>> ACCEPTABLE

000011