

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.20
Reference:	7
Title:	Summary Of Emission Measurements On No. 5 Kiln, Carolina Solite Corporation, Aquadale, North Carolina, Sholtes & Koogler Environmental Consultants, Inc., Gainesville, FL, April 1983.

AP-42 Section 11.20
Reference 7
Report Sect. 4
Reference 5

SUMMARY OF
EMISSION MEASUREMENTS

NO. 5 KILN

CAROLINA SOLITE CORPORATION
AQUADALE, NORTH CAROLINA

APRIL 5 AND 6, 1983

RECEIVED
MAY 2 1983
AIR QUALITY
SECTION


RECEIVED
MAY 4 1983
AIR QUALITY
PERMITS & OPERATIONS

SHOLTES & KOOGLER
ENVIRONMENTAL CONSULTANTS, INC.
1213 N.W. 6TH STREET
GAINESVILLE, FLORIDA 32601
(904) 377-5822

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 INTRODUCTION.....	1
2.0 PROCESS DESCRIPTION.....	2
3.0 SAMPLING LOCATIONS.....	3
4.0 SAMPLING AND ANALYTICAL PROCEDURES.....	6
5.0 SUMMARY OF RESULTS.....	8

To the best of my knowledge, all applicable field and analytical procedures comply with Florida Department of Environmental Regulation requirements and all test data and plant operating data are true and correct.



ROBERT S. SHOLTES, PH.D., P.E.

4-25-83

DATE

SEAL

1.0 INTRODUCTION

The Carolina Solite Corporation owns and operates a lightweight aggregate production facility near the town of Aquadale, North Carolina. This facility consists of eight rotary kilns which are used to produce lightweight aggregate from materials mined on site.

On April 5 and 6, 1983, Sholtes & Koogler, Environmental Consultants, Inc. (SKEC) of Gainesville, Florida conducted measurements on the No. 5 kiln inlet and outlet for particulate matter, chlorides, chromium and lead. The purpose of this testing was to satisfy provisos 10 and 11 of permit number 3225R4 issued on February 10, 1983, by the North Carolina Department of Natural Resources and Community Developments. These provisos are related to the combustion of liquid waste in kilns 5-8 to provide the heat necessary to produce the lightweight aggregate.

Prior to the test date, the North Carolina Department of Natural Resources and Community Development were notified of the test schedule. Mr. Yin-Pong Chang of this Department was at the plant site to witness the plant operations and the testing procedures.

2.0 PROCESS DESCRIPTION


The production of the lightweight aggregate consists of mining the raw material, which is a form of shale, crushing and sizing the material and heating the material in a rotary kiln.

At the point of fusion the carbon dioxide creates millions of tiny cells within the plastic mass expanding it and giving it the lightweight property. The material is removed from the kiln, cooled, crushed, sized and graded for shipment. The combustion gases passing through the kiln suspend small particles which result in particulate matter emissions from the process.

3.0 SAMPLING LOCATIONS

The sampling ports used for emission measurements on the discharge stack were located 60 feet above the base of the stack and 30 feet below the top of the stack. This is equivalent to 20 stack diameters from the point where the gases enter the stack and 9 stack diameters from the exit of the stack. It was determined that a total of 12 sampling points would be used for the sampling and velocity traverses; six sampling points on each of the two perpendicular traverses. The location of the sampling ports and a table of the sampling point locations are in Figure 1 of this report.

The sampling at the inlet of the air pollution control system was conducted in two separate ducts with four sampling ports located in the 21-inch face of each of these ducts. The ports were less than one diameter upstream and downstream from a flow disturbance. For testing, 48 sampling points were used; 24 sampling points in each of the two ducts. The location of these sampling ports and sampling points are shown in Figure 2 of this report.



SECTION A-A

<u>Point</u>	<u>Distance From Stack Wall</u>
1	1.6 inches
2	5.4 inches
3	10.7 inches
4	25.7 inches
5	31.1 inches
6	34.9 inches




FIGURE 1

NO. 5 KILN OUTLET

CAROLINA SOLITE CORPORATION
AQUADALE, NORTH CAROLINA




FIGURE 2

NO. 5 KILN INLET

CAROLINA SOLITE CORPORATION
AQUADALE, NORTH CAROLINA

4.0 SAMPLING AND ANALYTICAL PROCEDURES

The methods for sampling at both the inlet and the outlet were as published in 40 CFR 60, Appendix A, Code of Federal Regulations. The sampling and velocity traverses were determined in accordance with Method 1B and the determination of the stack gas flow rate was in accordance with Method 2. The stack gas temperature was measured with a Iron-constantan thermocouple and the barometric pressure was obtained from the Aquadale airport. The stack gas density for determining the gas flow rate, was determined by Method 3. The emission measurements were conducted in accordance with Method 5 with one slight variation. There was a flexible connection between the filter and the first Impinger. This modification has been agreed to prior by the DNR personnel prior to the test. Testing for all pollutants consisted of three sets of simultaneous tests at the inlet and the outlet of the control system. Particulate matter concentrations were determined from the weight of material collected on the filter and that removed from the probe by the acetone probe wash. Cadmium and lead concentrations were determined in the particulate matter sample using atomic absorption for the heavy metals analyses. The chlorides were collected in the Impingers of the sampling train in a solution of 0.1 normal sodium hydroxide. The Impinger solution was analyzed by the Argentometric Method.

It should be noted that run 3 on the Inlet was compromised due to darkness and overheating conditions. The suction line from the probe was melted down at least two times. Due to darkness and in the interest of safety, the run was terminated after completing approximately two thirds of the run.

5.0 SUMMARY OF RESULTS

Summarized results of the emission measurements conducted on April 5 and 6, 1983 are presented in Tables 1-4 of this report. These tables summarize the results of test runs 3-5. Test runs 1 and 2 were used to balance the operating parameters of the No. 5 kiln.

The particulate matter concentration at the inlet of the pollution control system averaged 3.6859 grains per standard cubic foot and at the outlet averaged 0.0631 grains per standard cubic foot; resulting in an overall control efficiency of 98.2 percent. The control efficiency for chromium was 91.9 percent, for lead-87.6 percent and for chloride-78.4 percent. These data are summarized in Tables 3 and 4 of this report. All control efficiencies were calculated from concentration data rather than from source data because of the uncertainty involved in measuring air flow rates at the inlet to the control system.

The mass emission rate of materials from the No. 5 kiln stack were 3.19 pounds per hour of particulate matter, 0.01 pounds per hour of chromium, 0.003 pounds per hour of lead and 3.56 pounds per hour of chloride.

Included in the Appendix of this report are all field and analytical data sheets, nomenclature sheets, a list of sample calculations, all necessary calibrations and a list of project participants.

TABLE 1

SUMMARY OF PARTICULATE MATTER EMISSIONS

NO. 5 KILN INLET

CAROLINA SOLITE CORPORATION
AQUADALE, NORTH CAROLINA

APRIL 5 AND 6, 1983

Run No.	Process Weight Rate (tons/hr)	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (°F)	Stack Gas Moisture (%)	Particulate Matter Emissions	
					Concentration (gr/SCF)	Mass Emission Rate (lbs/hr)
3		4174	709	8.7	2.8696	102.89
4		3641	791	10.7	4.0089	125.40
5		3702	792	11.2	4.1719	132.67
Average	10	3839	764	10.2	3.6859	120.32
		3,672			4.0904	129.035

TABLE 2

SUMMARY OF PARTICULATE MATTER EMISSIONS

NO. 5 KILN OUTLET

CAROLINA SOLITE CORPORATION
AQUADALE, NORTH CAROLINA

APRIL 5 AND 6, 1983

Run No.	Process Weight Rate (tons/hr)	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (°F)	Stack Gas Moisture (%)	Particulate Matter Emissions	
					Concentration (gr/SCF)	Mass Emission Rate (lbs/hr)
3		6207	110	7.2	0.0926	4.94
4		5509	117	7.7	0.0536	2.53
5		5685	98	*6.0	0.0431	2.11
Average	10	5800	108	7.0	0.0631	3.19

*Stack gas saturated.

TABLE 3

EMISSION MEASUREMENTS

NO. 5 KILN

CAROLINA SOLITE CORPORATION
AQUADALE, NORTH CAROLINA

	CHROMIUM				LEAD		MG/L	CHLORIDE		
	SCFD	SCFMD	(UG)	GR/SCF	LBS/HR	(UG)	GR/SCF	SAMPLE VOL (ML)	TOTAL (MG) -BLANK	LBS/HR
<u>OUTLET</u>										
Run 3	61.378	6207	1915	.000481	.026	268	.000067	395	184.1	.046281
Run 4	54.608	5509	586	.000166	.008	196	.000055	340	314.3	.088808
Run 5	53.702	5685	400	.000115	.006	95	.000027	325	288.1	.082779
<u>INLET</u>										
Run 3	19.383	4174	6612	.005264	.188	428	.000341	SAMPLE VOID		
Run 4	49.415	3641	6612	.002065	.064	1707	.000533	630	1233.6	.385196
Run 5	51.923	3702	5344	.001588	.050	1255	.000373	574	1377.0	.409204
BLANK								428	1.2	

TABLE 4
 PERCENT POLLUTANT REMOVAL
 CAROLINA SOLITE CORPORATION
 AQUADALE, NORTH CAROLINA
 NO. 5 KILN

	<u>CHROMIUM</u>	<u>LEAD</u>	<u>CHLORIDE</u>	<u>PARTICULATE MATTER</u>
Run 3	90.9	80.4	VOID	96.8
Run 4	92.0	89.7	76.9	98.7
Run 5	92.8	92.8	79.8	99.0
Average	91.9	87.6	78.4	98.2

APPENDIX

SOURCE SAMPLING NOMENCLATURE SHEET

- PB - Barometric pressure, inches Hg
- PS - Stack pressure, inches Hg
- As - Stack area, sq. ft.
- AS' - Effective area of positive stack gas flow, sq. ft.
- NPTS - Number of traverse points where the pitot velocity head was greater than zero
- TSTD - Standard temperature, °R
- TS - Stack temperature, °R
- TM - Meter temperature, °R
- H - Average square root of velocity head, $\sqrt{\text{inches H}_2\text{O}}$
- H - Average meter orifice pressure differential, inches H₂O
- AN - Sampling nozzle area, square feet
- CP - S-type pitot tube correction factor
- VM - Recorded meter volume sample, cubic feet (meter conditions)
- VC - Condensate and silica gel increase in impingers, milliliters
- Po - Pressure at the dry test meter orifice, $\left[\text{PB} + \frac{\Delta H}{13.6} \right]$ inches Hg
- STP - Standard conditions

-
- VWV - Conversion of condensate in milliliters to water vapor in cubic feet (STP)
 - VSTPD - Volume sampled, cubic feet (STP)
 - VT - Total water vapor volume and dry gas volume sampled, cubic feet (STP)
 - W - Moisture fraction of stack gas
 - FDA - Dry gas fraction
 - MD - Molecular weight of stack gas, lbs/lb-mole (dry conditions)
 - MS - Molecular weight of stack gas, lbs/lb-mole (stack conditions)
 - GS - Specific gravity of stack gas, referred to air
 - EA - Excess air, %
 - $\sqrt{H \times TS}$ - Average square root of velocity head times stack temperature
 - U - Stack gas velocity, feet per minute
 - QS - Stack gas flow rate, cubic feet per minute (stack conditions)
 - QD - Stack gas flow rate, cubic feet per minute (dry conditions)
 - QSTD - Stack gas flow rate, cubic feet per minute (STP)
 - PISO - Percent isokinetic volume sampled (method described in Federal Register)
 - ESTP - Particulate concentration at standard and dry conditions, grains/scf
 - E₁₂ - ESTP corrected to 12% CO₂, grains/scf
 - E₅₀ - ESTP corrected to 50% excess Air, grains/scf
 - EM - Mass Emission Rate, lbs/hr
 - - Stack Gas Saturated

EQUATIONS FOR CALCULATING PARTICULATE EMISSIONS

$$VWV = 0.0000893(TSTD)(VC)$$

$$VSTPD = (VM)(PB + \frac{\Delta H}{13.6})(\frac{TSTD}{TM})(\frac{1}{29.92})$$

$$VT = (VWV) + (VSTPD)$$

$$W = (VWV) \div (VT)$$

$$FDA = (1.0) - (W)$$

FMOIST = Assumed moisture fraction

$$MD = (0.44 \times \% CO_2) + (0.32 \times \% O_2) + (0.28 \times \% N_2) + (0.28 \times \% CO)$$

$$MS = (MD \times FDA) + (18 \times W)$$

$$GS = (MS) \div (28.99)$$

$$EA = \left[(100) \times (\% O_2 - \frac{\% CO}{2}) \right] \div \left[(0.266 \times \% N_2) - (\% O_2 - \frac{\% CO}{2}) \right]$$

$$\underline{U} = 4.006(CP)\sqrt{H} \sqrt{\left(\frac{TS}{TSTD} \right) \left(\frac{29.92}{PS} \right) \left(\frac{1}{GS} \right)}$$

$$QS = (\underline{U}) \times (AS)$$

$$QD = (QS) \times (FDA)$$

$$QSTPD = TSTD(QD)(PS) + [TS(29.92)]$$

$$PISO = \left[(0.00267 \times VC \times TS) + (P_o \times TS \times VM \div TM) \right] \div \left[(Time \times \underline{U} \times PS \times AN) \right]$$

$$ESTP = \frac{\left(\frac{15.43 \text{ grains}}{\text{gram}} \right) (y)}{VSTPD}$$

$$E_{12} = \frac{(ESTP) (12)}{(\% CO_2)}$$

$$E_{50} = \frac{(ESTP) (100 + EA)}{150}$$

$$EM = (ESTP) (QSTPD) \left(60 \frac{\text{min}}{\text{hr}} \right) \left(\frac{1 \text{ lb}}{7000 \text{ grains}} \right)$$

COMPUTER PRINT-OUTS

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-5-83
 Stack: NO. 5 KILN INLET Run 3 from 1757 -1940
 Weather conditions: OVERCAST ~~Barometric Pressure~~ Ps= 30.24 In.Hg
 As= 7 Sq.Ft. ~~Temperature~~ F ~~Relative Humidity~~
~~Barometric Pressure~~ ~~Temperature~~ An= 0.000508 Sq.Ft. CP= 0.84
 Vm= 19.403 cf Vc= 39 ml Total time: 62.2 Minutes

1. Volume Water Vapor	1.837	SCF	
2. Gas Volume Sampled - STPD	19.383	SCFD	
3. Total Volume	21.22	SCF	
4. Moisture in Stack Gas - Volume Fraction	0.087		
5. Dry Stack Gas - Volume Fraction	0.913		
6. Molecular Weight of Stack Gas - Dry Basis	29		
7. Molecular Weight of Stack Gas - Stack Conditions	28.05		
8. Specific Gravity of Stack Gas Relative to Air	0.97		
9. Excess Air - Percent			
10. Average Stack Velocity	1429.4	FPM	
11. Average Stack Gas Flow Rate	10006	ACFM	NOT to use
12. Actual Stack Gas Flow Rate Dry	9139	CFMD	
13. Stack Gas Flow Rate STPD	4174	SCFMD	
14. Percent Isokinetic	102.8	%	

Probe Wash	1507.70 Mg	1.1979 Gr/SCF	42.95 Lbs/Hr
Filter	2104.10 Mg	1.6717 Gr/SCF	59.94 Lbs/Hr
Totals	3611.80 Mg	2.8696 Gr/SCF	102.89 Lbs/Hr

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-5-83
 Stack: NO. 5 KILN OUTLET Run 3 from 1806-1940
 Weather conditions: CLOUDY Pb= 30.24 In.Hg Ps= 30.25 In.Hg
 As= 7.27 Sq.Ft. Ts= ~~410.2 Deg. F~~ Tm= ~~67.5 Deg. F~~
 H= 6.279 In.H2O Del H= ~~2.12 In.Hg~~ An= 0.001042 Sq.Ft. Cp= 0.84
 Vm= 60.36 cf Vc= 101.5 ml Total time: ~~72 Minutes~~

1. Volume Water Vapor	4.781	SCF
2. Gas Volume Sampled - STPD	61.378	SCFD
3. Total Volume	66.159	SCF
4. Moisture in Stack Gas - Volume Fraction	0.072	
5. Dry Stack Gas - Volume Fraction	0.928	
6. Molecular Weight of Stack Gas - Dry Basis	29	
7. Molecular Weight of Stack Gas - Stack Conditions	28.21	
8. Specific Gravity of Stack Gas Relative to Air	0.97	
9. Excess Air - Percent		
10. Average Stack Velocity	983	FFM
11. Average Stack Gas Flow Rate	7146	ACFM
12. Actual Stack Gas Flow Rate Dry	6630	CFMD
13. Stack Gas Flow Rate STPD	6207	SCFMD
14. Percent Isokinetic	95.8	%

Probe Wash	256.20 Mg	0.0643 Gr/SCF	3.43 Lbs/Hr
Filter	112.70 Mg	0.0283 Gr/SCF	1.51 Lbs/Hr
Totals	368.90 Mg	0.0926 Gr/SCF	4.94 Lbs/Hr

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-6-83
 Stack: NO. 5 KILN INLET Run 4 from 0912-1127
 Weather conditions: OVERCAST Pb= 30.08 In.Hg Ps= 30.08 In.Hg
 As= 7 Sq.Ft. ~~Ts= 72°F Dew. F~~ ~~Em= 2000 Btu/F~~
 H= 0.261 In.H2O Del ~~Hs= 0.96 In.H2O~~ An= 0.001056 Sq.Ft. Cp= 0.84
 Vm= 49.576 cf Vc= 125.5 ml Total time ~~96 Minutes~~

1. Volume Water Vapor	5.911	SCF
2. Gas Volume Sampled - STPD	49.415	SCFD
3. Total Volume	55.326	SCF
4. Moisture in Stack Gas - Volume Fraction	0.107	
5. Dry Stack Gas - Volume Fraction	0.893	
6. Molecular Weight of Stack Gas - Dry Basis	29	
7. Molecular Weight of Stack Gas - Stack Conditions	27.82	
8. Specific Gravity of Stack Gas Relative to Air	0.96	
9. Excess Air - Percent		
10. Average Stack Velocity	1372.6	FPM
11. Average Stack Gas Flow Rate	9608	ACFM
12. Actual Stack Gas Flow Rate Dry	8582	CFMD
13. Stack Gas Flow Rate STPD	3641	SCFMD
14. Percent Isokinetic	93.7	%

Probe Wash	9977.10 Mg	3.1093 Gr/SCF	97.26 Lbs/Hr
Filter	2886.70 Mg	0.8996 Gr/SCF	28.14 Lbs/Hr
Totals	PPPPPP Mg	4.0089 Gr/SCF	125.40 Lbs/Hr

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-6-83
 Stack: NO. 5 KILN OUTLET Run. 4 from 0905-1022
 Weather conditions: CLOUDY RAIN Pb= 30.08 In.Hg Ps= 30.09 In.Hg
 As= 7.27 Sq.Ft. T_{amb}= 114.2 F T_m= 551.1 F
 H= 0.251 In.H₂O Del H= 1.46 In.H₂O An= 0.001042 Sq.Ft. Cp= 0.84
 V_m= 54.108 cf V_e= 76.5 m³ Total time: 72 Minutes

1. Volume Water Vapor	4.545	SCF
2. Gas Volume Sampled - STPD	54.608	SCFD
3. Total Volume	59.153	SCF
4. Moisture in Stack Gas - Volume Fraction	0.077	
5. Dry Stack Gas - Volume Fraction	0.923	
6. Molecular Weight of Stack Gas - Dry Basis	29	
7. Molecular Weight of Stack Gas - Stack Conditions	28.15	
8. Specific Gravity of Stack Gas Relative to Air	0.97	
9. Excess Air - Percent		
10. Average Stack Velocity	891.7	FPM
11. Average Stack Gas Flow Rate	6482	ACFM
12. Actual Stack Gas Flow Rate Dry	5984	CFMD
13. Stack Gas Flow Rate STPD	5509	SCFMD
14. Percent Isokinetic	96	%

Probe Wash	106.00	Mg	0.0299	Gr/SCF	1.41	Lbs/Hr
Filter	83.90	Mg	0.0237	Gr/SCF	1.12	Lbs/Hr
Totals	189.90	Mg	0.0536	Gr/SCF	2.53	Lbs/Hr

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-6-83
 Stack: NO. 5 KILN INLET Run 5 from 1229-1432
 Weather conditions: OVERCAST Pb= ~~30.08 In. Hg~~ Ps= 30.08 In. Hg
 As= 7 Sq.Ft. Ts= ~~79.7-82.5~~ F Tm= ~~9.5-10.5~~
 H= 0.266 In. H2O Del ~~4.1-4.08~~ In. H2O An= 0.001056 Sq.Ft. Cp= 0.84
 Vm= 53.989 CF Vc= 139.2 ml Total time: ~~9.5 Minutes~~

1. Volume Water Vapor	6.556	SCF
2. Gas Volume Sampled - STPD	51.923	SCFD
3. Total Volume	58.48	SCF
4. Moisture in Stack Gas - Volume Fraction	0.112	
5. Dry Stack Gas - Volume Fraction	0.888	
6. Molecular Weight of Stack Gas - Dry Basis	29	
7. Molecular Weight of Stack Gas - Stack Conditions	27.77	
8. Specific Gravity of Stack Gas Relative to Air	0.96	
9. Excess Air - Percent		
10. Average Stack Velocity	1404.4	FPM
11. Average Stack Gas Flow Rate	9831	ACFM avg = 9711.6
12. Actual Stack Gas Flow Rate Dry	8729	CFMD
13. Stack Gas Flow Rate STPD	<u>3702</u>	<u>SCFMD</u>
14. Percent Isokinetic	96.8	%

Probe Wash	PPPPPP	Ms	4.0776	Gr/SCF	129.67	Lbs/Hr
Filter		318.00	Ms	0.0943	Gr/SCF	3.00
Totals	PPPPPP	Ms	4.1719	Gr/SCF	132.67	Lbs/Hr

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-6-83
 Stack: NO. 5 KILN OUTLET Run 5 from 1301-1434
 Weather conditions: CLOUDY RAIN Pb= 30.08 In.Hg Ps= 30.09 In.Hg
 As= 7.27 Sq.Ft. Ts= 82.0 F Tm= 82.0 F
 H= 0.251 In.H2O Del H= 1.44 In.H2O An= 0.001042 Sq.Ft. Cp= 0.84
 Vm= 54.752 cf Vc= 7.0 In.H2O Total time: 7.0 minutes

1. Volume Water Vapor	3.434*	SCF
2. Gas Volume Sampled - STPD	53.702	SCFD
3. Total Volume	57.136*	SCF
4. Moisture in Stack Gas - Volume Fraction	0.06*	
5. Dry Stack Gas - Volume Fraction	0.94*	
6. Molecular Weight of Stack Gas - Dry Basis	29	
7. Molecular Weight of Stack Gas - Stack Conditions	28.34*	
8. Specific Gravity of Stack Gas Relative to Air	0.98	
9. Excess Air - Percent		
10. Average Stack Velocity	874	FPM
11. Average Stack Gas Flow Rate	6354	ACFM per year
12. Actual Stack Gas Flow Rate Dry	5972	CFMD
13. Stack Gas Flow Rate STPD	5685	SCFMD
14. Percent Isokinetic	91.5*	%

Probe Wash	72.30 Ms	0.0207 Gr/SCF	1.01 Lbs/Hr
Filter	78.00 Ms	0.0224 Gr/SCF	1.09 Lbs/Hr
Totals	150.30 Ms	0.0431 Gr/SCF	2.11 Lbs/Hr

Enter restart point or RETURN to end: q7

q7) Run number: 3

q8) Time begin: 1757

q9) Time end: 1940

q10) Enter averages for: Stack Vel, Diff. Actual, Stack Temp, Meter Temp
.08 .306 708.6 74.6

0.08 0.306 708.6 74.6

q11) Enter: Total sampling time, Barometric pressure, Stack pressure
62.2 30.24 30.24

62.2 30.24 30.24

q12) Enter: Stack area, Nozzle dia., Final meter, Init. meter, Cond vol.(ml)
7 .3053 977.005 957.602 39

7 0.3053 977.005 957.602 39

Has the lab work been completed? (y/n) y

Enter Scrubber weights in milligrams

1507.7 2104.1

1507.7 2104.1 0 0 0

3053

Enter restart point or RETURN to end: q5

q5) Date sampled: 4-6-83

q6) Weather conditions:

OVERCAST

q7) Run number: 4

q8) Time begin: 0912

q9) Time end: 1127

q10) Enter averages for: Stack Vel, Diff. Actual, Stack Temp, Meter Temp

.068 .955 791.1 73.8

0.068 0.955 791.1 73.8

q11) Enter: Total sampling time, Barometric pressure, Stack pressure

96 30.08 30.08

96 30.08 30.08

q12) Enter: Stack area, Nozzle dia., Final meter, Init. meter, Cond vol.(ml)

7 .44 1026.776 977.2 125.5

7 0.44 1026.776 977.2 125.5

Has the lab work been completed? (y/n) y

Enter Scrubber weights in milligrams

9977.1 2886.7

9977.1 2886.7 0 0 0

3. }
 Chang
 Meme
 Hwang
 moggie
 moggie
 moggie

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft.)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
3			85.3	.04	.40	.40	784	69	233	42	3
4			86.6	.04	.40	.40	785	69	239	40	3
5			86.7	.07	.71	.71	801	69	243	40	4
6			87.7	.07	.71	.71	804	69	234	40	4
3-1			88.6	.05	.72	.72	781	70	237	42	4
2			89.6	.05	.72	.72	796	71	239	41	4
3			90.5	.05	.72	.72	781	71	233	42	4
4			91.5	.085	1.23	1.23	807	71	245	41	6
5			92.7	.085	1.23	1.23	814	71	253	40	6
6			93.9	.10	1.44	1.44	808	71	250	40	7
4-1			95.2	.10	1.44	1.44	781	72	242	40	7
2			96.5	.09	1.29	1.29	786	72	259	42	7
3			97.8	.12	1.73	1.73	809	72	259	42	9
4			99.2	.14	2.01	2.01	810	72	256	41	10
5			100.8	.16	2.3	2.3	816	73	261	42	12
6			2.5	.16	2.3	2.3	825	73	257	43	12
5-1			4.1	.07	1.0	1.0	762	74	260	57	5
2			4.9	.07	1.0	1.0	772	74	257	57	5
3			6.0	.055	.79	.79	767	74	239	45	4
4			7.0	.06	.86	.86	767	74	232	44	5
5			8.0	.085	1.23	1.23	785	74	241	43	6
6			9.3	.10	1.44	1.44	792	74	250	43	6
6-1			10.6	.025	.36	.36	775	74	244	47	3
2			11.3	.03	.43	.43	778	74	237	46	4

SK



#1

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina Solite
Sampling Location H5 Outlet
Type of Control None
Type of Samples Part
Date 4-6-83 Run No. 5
Time Start 1229 Time End 1432
Sample Time 2 min/pt 96 Total min
DB °F, WB °F, VP @ DP "Hg
Bar. Press. "Hg, Stack Press. "Hg
Moisture 11 %, FDA , Gas Density Factor
Temp. 62 °F, W/D Var, W/S 3.5
Weather Partly cloudy Thermocouple Readout 26.7
Sample Box No. 25-1 Meter Box No. 26-1
Meter ΔH@ 1.74 Pitot Corr. Factor 0.84
Nozzle Dia. 7/16 in., Probe Length 24 ft
Probe Heater Setting 5 Nomograph C 44468
Stack Dimensions in
Stack Area 7.0 ft²
Effective Stack Area 7.0 ft²
Stack Height ft

Mat'l Processing Rate
Final Gas Meter Reading 81.091 ft³
Initial Gas Meter Reading 27.102 ft³
Condensate Increase in Impingers 113 ml
Moisture in Silica Gel 26.2 gm
Silica Gel Container No. 5 Filter No.
Orsat: %CO₂
 %O₂
 %CO
 %N₂

Test Conducted By: R Paul
R Barton
Stack Test Observers:

Leak Check Meter Box Initial 0.006 cfm @ 15 In H₂
Final 0.003 cfm @ 13 In Hg
Pitot Tubes Impact 3 In H₂O for 15 sec. Stable Leak
Static 3 In H₂O for 15 sec. Stable Leak

Stack Dimensions	

Umbilical Cord 100' 200'

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head ("H ₂ O")	Meter Orifice Press. Diff. ("H ₂ O")		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1-1			27.1	.08	1.16	1.16	822	85	243	69	5
2			28.3	.08	1.16	1.16	816	85	241	52	5
3			29.5	.08	1.16	1.16	816	85	237	47	5
4			30.7	.095	1.37	1.37	826	85	232	46	6
5			32.1	.12	1.74	1.74	830	85	239	46	7
6			33.5	.14	2.03	2.03	834	85	247	47	8
2-1			35.0	.05	.72	.72	800	85	251	61	4
7			36.0	.05	.72	.72	804	85	253	57	4

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft.)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
3			370	.67	1.01	1.01	806	86	262	52	5
4			382	.67	1.01	1.01	813	86	267	52	5
5			392	.085	1.23	1.23	823	89	261	51	6
6			405	.11	1.59	1.59	833	88	262	51	7
3-1			418	.065	.94	.94	800	91	266	57	5
2			429	.065	.94	.94	806	92	265	55	5
3			440	.06	.87	.87	808	93	267	54	5
4			450	.065	.94	.94	818	93	268	52	5
5			461	.07	1.01	1.01	818	92	269	51	6
6			473	.11	1.59	1.59	836	94	264	51	8
4-1			486	.11	1.59	1.59	801	95	269	56	6
2			500	.10	1.45	1.45	805	95	267	51	6
3			513	.10	1.45	1.45	806	95	262	50	6
4			527	.10	2.3	2.3	831	96	271	51	10
5			542	.17	2.45	2.45	840	96	269	52	13
6			56	.10	2.3	2.3	844	96	262	52	13
5-1			577	.06	.87	.87	772	96	242	71	4
2			587	.065	.94	.94	772	96	240	59	5
3			598	.065	.94	.94	770	96	234	54	5
4			609	.07	1.01	1.01	776	96	231	52	5
5			620	.07	1.01	1.01	779	96	236	51	5
6			631	.12	1.74	1.74	802	96	241	50	9
6-1			645	.03	.43	.43	759	95	244	57	3
2			653	.03	.43	.43	755	95	239	54	3

SK

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina SoliteSampling Location #5 Kiln Scumbrer StackType of Control Scrubber + CycloneType of Samples Particulate + otherDate 4-5-87 Run No. 3Time Start 1806 Time End 1940Sample Time 6 min/pt 72 Total minDB °F, WB °F, VP @ DP "HgBar. Press. 30.24 "Hg, Stack Press. "HgMoisture %, FDA Gas Density FactorTemp. 60 °F, W/D W/SWeather Cloudy Thermocouple Readout 77 °FSample Box No. 2 Meter Box No. 2Meter ΔH₀ 1.55 Pitot Corr. Factor 0.84Nozzle Dia. 7/16 in., Probe Length 4 ftProbe Heater Setting Nomograph C-26-307Stack Dimensions 36 1/2 inStack Area 7.27 ft²Effective Stack Area 7.27 ft²Stack Height ft

Mat'l Processing Rate

Final Gas Meter Reading 407,360 ft³Initial Gas Meter Reading 347,000 ft³Condensate Increase in Impingers 90 mlMoisture in Silica Gel 11.5 gmSilica Gel Container No. 1 Filter No. 73Orsat: %CO₂%O₂

%CO

%N₂Test Conducted By: R. SholtesBen Edkins

Stack Test Observers:

Leak Check

Meter Box

Initial <.005 cfm @ 15 In H₂Final 0.000 cfm @ 15.3 In HgImpact 3 In H₂O for 15 sec. Stable LeakStatic 3 In H₂O for 15 sec. Stable Leak

Pitot Tubes

Stack Dimensions

Umbilical Cord 100' 200'2.12

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1		0	347.000	.06	1.58	1.58	99	68	280	47	5
2		6	51.5	.07	1.84	1.84	103	65	290	44	6
3		12	57.7	.13	3.4	3.4	107	63	272	47	13
4		18	62.5	.13	3.4	3.4	109	65	262	50	13
5		24	69.1	.13	3.4	3.4	112	67	246	52	13 1/2
6		30	75.8	.11	2.9	2.9	110	68	230	53	12

Enter restart point or RETURN to end: 97

97) Run number: 5

98) Time begin: 1229

99) Time end: 1432

910) Enter averages for: Stack Vel, Diff. Actual, Stack Temp, Meter Temp
.071 1.08

791.7 93.4

0.071 1.08 791.7 93.4

911) Enter: Total sampling time, Barometric pressure, Stack pressure
96 30.08 30.08

96 30.08 30.08

912) Enter: Stack area, Nozzle dia., Final meter, Init. meter, Cond vol.(ml)
7 .44 81.091 27.102 139.2

7 0.44 81.091 27.102 139.2

Has the lab work been completed? (Y/n) Y

Enter Scrubber weights in milligrams

13748.3 318

13748.3 318 0 0 0

SHOLTES AND KOOGLER ENVIRONMENTAL CONSULTANTS

Source Sampling Calculations

Plant: N. CAROLINA SOLITE AQUADALE, N.C. Date: 4-5-83
 Stack: NO. 5 KILN INLET Run 1 from 1031-1309
 Weather conditions: OVERCAST Pb= 30.24 In.Hg Ps= 30.23 In.Hg
 As= 7 Sq.Ft. Ts= 678.5 Deg. F Tm= 78.9 Deg. F
 H= 0.52 In.H2O Del H= 0.53 In.H2O An= 0.000352 Sq.Ft. Cp= 0.84
 Vm= 37.675 cf Vc= 53.2 ml Total time: 96 Minutes

1. Volume Water Vapor	2.506	SCF
2. Gas Volume Sampled - STPD	37.356	SCFD
3. Total Volume	39.862	SCF
4. Moisture in Stack Gas - Volume Fraction	0.063	
5. Dry Stack Gas - Volume Fraction	0.937	
6. Molecular Weight of Stack Gas - Dry Basis	29	
7. Molecular Weight of Stack Gas - Stack Conditions	28.31	
8. Specific Gravity of Stack Gas Relative to Air	0.98	
9. Excess Air - Percent		
10. Average Stack Velocity	2580.4	FPM
11. Average Stack Gas Flow Rate	18062	ACFM
12. Actual Stack Gas Flow Rate Dry	16927	CFMD
13. Stack Gas Flow Rate STPD	7932	SCFMD
14. Percent Isokinetic	97.6	%

Probe Wash	5862.80 Mg	2.4169 Gr/SCF	164.69 Lbs/Hr
Filter	1269.00 Mg	0.5231 Gr/SCF	35.65 Lbs/Hr
Totals	7131.80 Mg	2.9400 Gr/SCF	200.33 Lbs/Hr

Enter restart point or RETURN to end: 95

95) Date sampled: 4-6-83

96) Weather conditions: CLOUDY RAIN

97) Run number: 4

98) Time begin: 0905

99) Time end: 1022

910) Enter averages for: Stack Vel, Diff. Actual, Stack Temp, Meter Temp

.063 1.664 116.8 68.1

0.063 1.664 116.8 68.1

911) Enter: Total sampling time, Barometric pressure, Stack pressure

72 30.08 30.09

72 30.08 30.09

912) Enter: Stack area, Nozzle dia., Final meter, Init. meter, Cond vol.(ml)

7.27 .437 462.108 408 96.5

7.27 0.437 462.108 408 96.5

Has the lab work been completed? (y/n) y

Enter Scrubber weights in milligrams

106 83.9

106 83.9 0 0 0

Enter restart point or RETURN to end: 47

47) Run number: 5

48) Time begin: 1301

49) Time end: 1434

410) Enter averages for: Stack Vel, Diff. Actual, Stack Temp, Meter Temp
.063 1.664 97.8 83.4

0.063 1.664 97.8 83.4

411) Enter: Total sampling time, Barometric pressure, Stack pressure
72 30.08 30.09

72 30.08 30.09

412) Enter: Stack area, Nozzle dia., Final meter, Init. meter, Cond vol.(ml)
7.27 .437 521.422 466.67 97.5

7.27 0.437 521.422 466.67 97.5

Has the lab work been completed? (y/n) y

Enter Scrubber weights in milligrams

72.3 78

72.3 78 0 0 0

FIELD AND LAB DATA SHEETS

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina Solite
Sampling Location #5 Outlet
Type of Control None
Type of Samples Part
Date 4-5-83 Run No. 3
Time Start 1757 Time End 1940
Sample Time 2 min/pt 2
DB 62 °F, WB 62 °F, VP @ DP 62 °F
Bar. Press. 29.9 "Hg, Stack Press. 29.9 "Hg
Moisture 8 %, FDA 2-3, Gas Density Factor 2-3
Temp. 62 °F, W/D W/S
Weather Overcast Thermocouple Reading 62
Sample Box No. Ab-1 Meter Box No. Ab-1
Meter ΔH₀ 1.74 Pitot Corr. Factor 1.0
Nozzle Dia. 5/16 in., Probe Length 31.1 ft
Probe Heater Setting 4 Nomograph C_r 3.72
Stack Dimensions 7.0 in
Stack Area 7.0 ft²
Effective Stack Area 7.0 ft²
Stack Height 7 ft

Mat'l Processing Rate
Final Gas Meter Reading 977.005 ft³
Initial Gas Meter Reading 957.002 ft³
Condensate Increase in Impingers 34 ml
Moisture in Silica Gel 5.8 gm
Silica Gel Container No. 28 Filter No. 28
Orsat: %CO₂ %O₂ %CO %N₂

Test Conducted By: R Paul
R Barton
Stack Test Observers:

Leak Check
Meter Box Initial 8012 cfm @ 5 In H₂
Final 8012 cfm @ 5 In Hg

Pitot Tubes
Impact 3 In H₂O for 15 sec Stable Leak
Static 3 In H₂O for 15 sec Stable Leak

Stack Dimensions	

Umbilical Cord 100' 200'

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1-1			57.6	.07	.26	.26	748	74	257	67	2
2			58.1	.07	.26	.26	724	74	261	61	2
3			58.8	.08	.29	.29	718	74	252	57	3
4			59.4	.08	.29	.29	733	74	244	56	3
5			60.1	.11	.41	.41	741	74	241	55	3
6			60.8	.12	.45	.45	748	74	249	53	3
2-1			61.6	.04	.15	.15	696	74	253	60	2
7			62.1	.04	.15	.15	696	71	255	59	2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft.)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
3			62.5	.04	.15	.15	696	74	255	59	2
4			63.0	.06	.22	.22	705	74	268	58	3
5			63.5	.10	.37	.37	720	74	247	57	3
6			64.0	.10	.37	.37	729	74	230	56	3
3-1			64.8	.05	.19	.19	674	75	237	59	2
2			65.3	.05	.19	.19	669	75	241	59	2
3			65.8	.05	.19	.19	672	75	247	59	2
4			66.3	.07	.26	.26	693	75	257	60	3
5			66.9	.11	.41	.41	710	75	249	60	3
6			67.5	.11	.41	.41	721	75	252	60	3
4-1			68.3	.05	.19	.19	672	75	239	61	2
2			68.8	.06	.22	.22	661	75	243	60	3
3			69.4	.07	.26	.26	660	75	249	60	3
4			69.6	.09	.33	.33	674	75	253	59	3
5			70.6	.11	.41	.41	688	75	259	57	3
6			71.1	.12	.45	.45	695	75	261	55	3
5-1			72.0	.10	.37	.37	711	75	266	69	3
2			72.8	.10	.37	.37	717	75	256	67	3
3			73.5	.09	.33	.33	732	75	251	64	4
4			74.1	.11	.41	.41	750	75	249	64	4
5			74.9	.11	.41	.41	754	75	250	62	4
6			75.6	.11	.41	.41	750	75	254	61	4
6-1			76.3	.08	.30	.30	701	75	251	65	3
2											

SK

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina White
 Sampling Location #5 Inlet
 Type of Control none
 Type of Samples Part
 Date 4-6-83 Run No. 4
 Time Start 0912 Time End 1127
 Sample Time 2 min/pt 96 Total min
 DB °F, WB °F, VP @ DP "Hg
 Bar. Press. "Hg, Stack Press. "Hg
 Moisture 10 %, FDA °F, Gas Density Factor W/S
 Temp. 57 °F, W/D Calor, W/S
 Weather Overcast Thermocouple Readout 26.1
 Sample Box No. 26-1 Meter Box No. 26-1
 Meter ΔH@ 1.74 Pitot Corr. Factor 0.84
 Nozzle Dia. 1/4 in., Probe Length 14.41 ft
 Probe Heater Setting 6 Nomograph C_p 1007
 Stack Dimensions in
 Stack Area 7.0 ft²
 Effective Stack Area 7.0 ft²
 Stack Height 6 ft

Mat'l Processing Rate

Final Gas Meter Reading 1026.776 ft³Initial Gas Meter Reading 977.200 ft³ 49.576Condensate Increase in Impingers 117 mlMoisture in Silica Gel 8.5 gmSilica Gel Container No. 11 Filter No.
 Orsat: %CO₂
 %O₂
 %CO
 %N₂
Test Conducted By: R. PaulStack Test Observers: R. BartonLeak Check
Meter BoxInitial 9817 cfm @ 15 In H₂
Final 9817 cfm @ 15 In Hg

Pitot Tubes

Impact 3 In H₂O for 15 sec. Stable Leak
Static 3 In H₂O for 15 sec. Stable Leak

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1-1			77.2	.07	.71	.71	789	66	231	69	3
2			78.2	.07	.71	.71	787	66	233	52	3
3			79.1	.08	.81	.81	782	66	244	42	4
4			80.1	.10	1.0	1.0	790	66	251	41	4
5			81.2	.15	1.51	1.51	797	67	233/140	40	5
6			82.6	.15	1.51	1.51	803	67	245	40	5
2-1			83.9	.04	.40	.40	781	68	240	46	3
2			84.6	.04	.40	.40	766	69	237	43	3

SK

#1

3. }
 Chang
 Monte
 Henry
 mfg. Co.
 inc.
 1000
 1000

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft.)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
3			85.3	.04	.40	.40	784	69	233	42	3
4			86.6	.04	.40	.40	785	69	234	40	3
5			86.7	.07	.71	.71	801	69	243	40	4
6			87.7	.07	.71	.71	804	69	234	40	4
3-1			88.6	.05	.72	.72	781	70	231	42	4
2			89.6	.05	.72	.72	786	71	239	41	4
3			90.5	.05	.72	.72	781	71	233	42	4
4			91.5	.085	1.23	1.23	807	71	245	41	6
5			92.7	.085	1.23	1.23	814	71	253	40	6
6			93.9	.10	1.44	1.44	808	71	250	40	7
4-1			95.2	.10	1.44	1.44	781	72	242	40	7
2			96.5	.09	1.29	1.29	786	72	259	42	7
3			97.8	.12	1.73	1.73	809	72	257	42	9
4			99.2	.14	2.01	2.01	810	72	256	41	10
5			100.8	.16	2.3	2.3	816	73	260	42	12
6			2.5	.16	2.3	2.3	825	73	257	43	12
5-1			4.1	.07	1.0	1.0	762	74	260	51	5
2			4.9	.07	1.0	1.0	772	74	257	51	5
3			6.0	.055	.79	.79	767	74	239	45	4
4			7.0	.06	.86	.86	767	74	232	44	5
5			8.0	.085	1.23	1.23	785	74	241	43	6
6			9.3	.10	1.44	1.44	792	74	250	43	6
6-1			10.6	.025	.36	.36	775	74	244	47	3
2			11.3	.03	.43	.43	778		231	46	4

SK

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina Solite
Sampling Location #5 Outlet
Type of Control None
Type of Samples Part
Date 4-6-83 Run No. 5
Time Start 1229 Time End 1432
Sample Time 2 min/pt 96 Total min
DB °F, WB °F, VP @ DP "Hg
Bar. Press. "Hg, Stack Press. "Hg
Moisture 11 %, FDA , Gas Density Factor
Temp. 102 °F, W/D Var. W/S 3-5
Weather Partly Cloudy Thermocouple Readout 26.7
Sample Box No. 26-1 Meter Box No. 26-1
Meter ΔH@ 1.74 Pitot Corr. Factor 0.84
Nozzle Dia. 7/16 in., Probe Length Std ft
Probe Heater Setting 5 Nomograph C₄ 14468
Stack Dimensions in
Stack Area 7.0 ft²
Effective Stack Area 7.0 ft²
Stack Height ft

Mat'l Processing Rate
Final Gas Meter Reading 84.091 ft³
Initial Gas Meter Reading 27.102 ft³
Condensate Increase in Impingers 113 ml
Moisture in Silica Gel 26.2 gm
Silica Gel Container No. 5 Filter No.
Orsat: %CO₂
 %O₂
 %CO
 %N₂

Test Conducted By: R Paul
R Barton
Stack Test Observers:

Leak Check
Meter Box Initial 0.0016 cfm @ 15 In H₂
Final 0.003 cfm @ 13 In Hg
Pitot Tubes Impact 3 In H₂O for 15 sec. Stable Leak
Static 3 In H₂O for 15 sec. Stable Leak

Stack Dimensions	

Umbilical Cord 100' 200'

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1-1			27.1	.08	1.16	1.16	822	85	243	69	5
2			28.3	.08	1.16	1.16	816	85	241	52	5
3			29.5	.08	1.16	1.16	816	85	237	47	5
4			30.7	.095	1.37	1.37	826	85	232	46	6
5			32.1	.12	1.74	1.74	830	85	239	46	7
6			33.5	.14	2.03	2.03	834	85	247	47	8
2-1			35.0	.05	.72	.72	800	85	251	61	4
7			36.0	.05	.72	.72	804	85	253	57	4

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft.)	Stack Velocity Head (=H ₂ O)	Meter Orifice Press. Diff. (=H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train (=Hg)
					Calc.	Actual					
3			370	.07	101	101	806	86	262	52	5
4			382	.07	101	101	813	86	267	52	5
5			392	.085	123	123	823	87	261	51	10
6			405	.11	159	159	833	88	262	51	7
3-1			418	.065	94	94	800	91	266	57	5
2			429	.065	94	94	806	92	265	55	5
3			440	.06	87	87	808	93	267	54	5
4			450	.065	94	94	818	93	268	52	5
5			461	.07	101	101	818	94	269	51	6
6			473	.11	159	159	836	94	264	51	8
4-1			486	.11	159	159	801	95	269	56	6
2			500	.10	145	145	805	95	267	51	6
3			513	.10	145	145	806	95	262	50	6
4			527	.10	23	23	831	96	271	51	10
5			542	.17	245	245	840	96	269	52	13
6			56	.10	23	23	844	96	262	52	13
5-1			577	.06	87	87	772	96	242	71	4
2			587	.065	94	94	772	96	240	59	5
3			598	.065	94	94	770	96	234	54	5
4			609	.07	101	101	776	96	231	52	5
5			620	.07	101	101	779	96	236	51	5
6			631	.12	174	174	802	96	241	50	9
6-1			645	.03	43	43	759	95	244	57	3
2			653	.03	43	43	755	95	239	54	3

SK

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina SoliteSampling Location #5 Kiln Summer StackType of Control Scrubber + CycloneType of Samples Particulate + OtherDate 4-5-87 Run No. 3Time Start 1806 Time End 1940Sample Time 6 min/pt 72 Total minDB °F, WB °F, VP @ DP °F, "HgBar. Press. 30.24 "Hg, Stack Press. °F, "HgMoisture %, FDA °F, Gas Density Factor W/STemp. 60 °F, W/D °F, W/SWeather Cloudy Thermocouple Readout 77°FSample Box No. 2 Meter Box No. 2Meter ΔH₀ 1.55 Pitot Corr. Factor 0.84Nozzle Dia. 7/16 in., Probe Length 4 ftProbe Heater Setting Nomograph C-26-307Stack Dimensions 36 1/2 inStack Area 7.27 ft²Effective Stack Area 7.27 ft²Stack Height ft

Mat'l Processing Rate

Final Gas Meter Reading 407,360 ft³Initial Gas Meter Reading 347,000 ft³Condensate Increase in Impingers 90 mlMoisture in Silica Gel 11.5 gmSilica Gel Container No. 1 Filter No. 73Orsat: %CO₂%O₂

%CO

%N₂Test Conducted By: R. SholtesBen Edkins

Stack Test Observers:

Leak Check

Meter Box

Initial <.005 cfm @ 15 In H₂Final 0.000 cfm @ 13.5 In Hg

Pitot Tubes

Impact 3 In H₂O for 15 sec. Stable LeakStatic 3 In H₂O for 15 sec. Stable Leak

Stack Dimensions

Unbilical Cord 100' 200'2.12

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1		0	347,000	.06	1.58	1.58	99	68	280	47	5
2		6	51.5	.07	1.84	1.84	103	65	290	44	6
3		12	57.7	.13	3.4	3.4	107	63	272	47	13
4		18	62.5	.13	3.4	3.4	109	65	262	50	13
5		24	69.1	.13	3.4	3.4	112	67	246	52	13 1/2
6		30	75.8	.11	2.9	2.9	110	68	230	53	12

SK

SHOLTES & KOUGLER
ENVIRONMENTAL CONSULTANTS, INC.
GAINESVILLE, FLORIDA 32601
(904) 377-5822

SOURCE SAMPLING FIELD DATA SHEET

Plant Carolina Solite
 Sampling Location Silica Stack
 Type of Control Cyclones - Scrubber
 Type of Samples Particulate + others
 Date 4-6-83 Run No. 4
 Time Start 0905 Time End 1020
 Sample Time 6 min/pt 72 Total min
 DB 68 °F, WB 68 °F, VP @ DP 72 "Hg
 Bar. Press. 30.08 "Hg, Stack Press. 72 "Hg
 Moisture 68 %, FDA 68 %, Gas Density Factor 72
 Temp. 68 °F, W/D 68 W/S
 Weather Cloudy - Rain Thermocouple Readout 72
 Sample Box No. 42 Meter Box No. 75
 Meter ΔH0 1.55 Pitot Corr. Factor 72
 Nozzle Dia. 7/16 in., Probe Length 4 ft
 Probe Heater Setting 36 1/2 " Nomograph C₁₆ 307
 Stack Dimensions 36 1/2 in
 Stack Area 7.27 ft²
 Effective Stack Area 7.27 ft²
 Stack Height 72 ft

Mat'l Processing Rate
 Final Gas Meter Reading 462,108 ft³
 Initial Gas Meter Reading 408,000 ft³
 Condensate Increase in Impingers 90 ml
 Moisture in Silica Gel 6.5 gm
 Silica Gel Container No. 42 Filter No. 75
 Orsat: %CO₂ 72
 %O₂ 72
 %CO 72
 %N₂ 72

Test Conducted By: R. Sholtes
Ben Eldins

Stack Test Observers: _____

Leak Check
 Meter Box Initial 0.016 cfm @ 15 In H₂
 Final 0.000 cfm @ 7 In Hg
 Pitot Tubes Impact 3 In H₂O for 15 sec. Stable Leak
 Static 3 In H₂O for 15 sec. Stable Leak

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1		0	408.000	.06	1.58	1.58	121	61	255	60	4
2		6	12.4	.07	1.84	1.84	118	62	280	57	5
3		12	17.1	.07	1.84	1.84	117	63	253	53	5
4		18	—	.07	1.84	1.84	115	65	270	53	5
5		24	26.7	.06	1.58	1.58	114	66	233	54	5
6		30	30.8	.04	1.05	1.05	116	69	250	54	4
										* Thermocouple	Under Testing

290
200
90
76

1.6.6.1


4-6-85

* Thermocouple pickup undesirable

#5

SOURCE SAMPLING FIELD DATA SHEET

Plant Caroline Solite
Sampling Location 45 Kiln Stack
Type of Control Cyclones - Scrubber
Type of Samples Particulate & others
Date 4-6-83 Run No. 5
Time Start 1301 Time End 1434
Sample Time 6 min/pt 72 Total min
DB 72 °F, WB 6 °F, VP @ DP 72 °F
Bar. Press. 30.08 "Hg, Stack Press. 72 "Hg
Moisture 72 %, FDA 72 %, Gas Density Factor 72 W/S
Temp. 72 °F, W/D 72 W/S
Weather clearing Thermocouple Readout Bad
Sample Box No. 4 Meter Box No. 2
Meter ΔH 1.55 Pitot Corr. Factor 4 ft
Nozzle Dia. 7/16 in., Probe Length 4 ft
Probe Heater Setting 36 1/2 " in
Stack Dimensions 7.27 ft²
Stack Area 7.27 ft²
Effective Stack Area 7.27 ft²
Stack Height 7.27 ft



Stack Dimensions
Umbilical Cord 100' 200'

Mat'l Processing Rate
Final Gas Meter Reading 521.422 ft³
Initial Gas Meter Reading 466.670 ft³
Condensate Increase in Impingers 85 ml
Moisture in Silica Gel 12.5 gm
Silica Gel Container No. 18 Filter No. 74
Orsat: %CO₂ 74
 %O₂ 74
 %CO 74
 %N₂ 74

Test Conducted By: R. Sholtes
Ben Eddins
Stack Test Observers:

Leak Check
Meter Box Initial 0.018 cfm @ 15 In H₂
Final 0.00 cfm @ 7 In Hg
Impact 3 In H₂O for 15 sec. Stable Leak
Static 3 In H₂O for 15 sec. Stable Leak

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Meter Temp. (°F)	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual					
1		0	66.6	.06	1.58	1.58	100	280	78	60	5
2		6	71.2	.07	1.84	1.84	98	270	78	54	6
3		12	76.4	.08	2.10	2.10	102	235	79	60	7
4		18	81.0	.07	1.84	1.84	98	233	80	65	6 1/2
5		24	86.0	.05	1.31	1.31	101	225	82	65	5
6		30	89.9	.04	1.05	1.05	98	238	83	58	4

[illegible]

SHOLTES & KOOGLER, ENVIRONMENTAL CONSULTANTS

PARTICULATE LAB DATA SHEETOUTLETDate 4-5-83Project No. N. CAROLINA SOLITEPROBE WASH

	<u>Run 3</u>	<u>Run 4</u>	<u>Run 5</u>	<u>Blank</u>
Container No.	<u>SK-1</u>	<u>SK-24</u>	<u>SK-38</u>	<u>SK-18</u>
Total Volume (ml)	<u>240</u>	<u>250</u>	<u>240</u>	<u>100</u>
Aliquot Evaporated (ml)	<u>240</u>	<u>250</u>	<u>240</u>	<u>100</u>
Final Weight (g)	<u>93.0397</u>	<u>93.9530</u>	<u>99.2010</u>	<u>93.7194</u>
Tare Weight (g)	<u>-92.7835</u>	<u>-93.8470</u>	<u>-99.1287</u>	<u>-93.7188</u>
Gross Weight Gained (g)	<u>.2562</u>	<u>.1060</u>	<u>.0723</u>	<u>.0006</u>
Average Blank (g)	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>
Net Weight (g)	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>
Aliquot Factor	<u>x 1.0</u>	<u>x 1.0</u>	<u>x 1.0</u>	<u>x 1.0</u>
Total Net Weight (mg)	<u>256.2</u>	<u>106.0</u>	<u>72.3</u>	<u>0.6</u>
Container No.	<u>3F</u>	<u>1J</u>	<u>3J</u>	<u>-</u>
Filter No.	<u>73</u>	<u>75</u>	<u>74</u>	<u>-</u>
Final Weight (g)	<u>.5161</u>	<u>.4896</u>	<u>.4812</u>	<u>-</u>
Tare Weight (g)	<u>-.4034</u>	<u>-.4057</u>	<u>-.4032</u>	<u>-</u>
Gross Weight Gained (g)	<u>.1127</u>	<u>.0839</u>	<u>.0780</u>	<u>-</u>
Average Blank	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>
Total Net Weight (mg)	<u>112.7</u>	<u>83.9</u>	<u>78.0</u>	<u>-</u>

Balance Check

0 0.0 24 50g 50.0000 24
 10g 10.0000 24 100g 100.0000 24
 0.5g 0.5000 24

Analyzed by: JKL

SHOLTES & KOOGLER, ENVIRONMENTAL CONSULTANTS

PARTICULATE LAB DATA SHEET

INLET

Date 4-5-83 Project No. N. CAROLINA SOLITE
PROBE WASH

	<u>Run 3</u>	<u>Run 4</u>	<u>Run 5</u>	<u>Blank</u>
Container No.	<u>SK-47</u>	<u>SK-10</u>	<u>SK-43</u>	<u>SK-41</u>
Total Volume (ml)	<u>240</u>	<u>250</u>	<u>260</u>	<u>100</u>
Aliquot Evaporated (ml)	<u>240</u>	<u>250</u>	<u>260</u>	<u>100</u>
Final Weight (g)	<u>98.8088</u>	<u>99.0559</u>	<u>112.9468</u>	<u>93.8478</u>
Tare Weight (g)	<u>-97.3006</u>	<u>-89.0788</u>	<u>-99.1985</u>	<u>-93.8475</u>
Gross Weight Gained (g)	<u>1.5077</u>	<u>9.9771</u>	<u>13.7483</u>	<u>.0003</u>
Average Blank (g)	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>
Net Weight (g)	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>
Aliquot Factor	<u>x 1.0</u>	<u>x 1.0</u>	<u>x 1.0</u>	<u>x 1.0</u>
Total Net Weight (mg)	<u>1,507.7</u>	<u>9,977.1</u>	<u>13,748.3</u>	<u>0.3</u>
	<u>Run 3</u>	<u>Run 4</u>	<u>Run 5</u>	
Container No.	<u>3A</u>	<u>(1C + 2C)</u>	<u>3C</u>	
Filter No.	<u>122</u>	<u>123</u>	<u>124</u>	<u>125</u>
Final Weight (g)	<u>2.5159</u>	<u>3.0802</u>	<u>.6304</u>	<u>.7328</u>
Tare Weight (g)	<u>-.4118</u>	<u>-.4111</u>	<u>-.4128</u>	<u>-.4148</u>
Gross Weight Gained (g)	<u>2.1041</u>	<u>2.6691</u>	<u>.2176</u>	<u>.3180</u>
Average Blank	<u>-</u>	<u>+ .2176</u>	<u>-</u>	<u>-</u>
Total Net Weight (mg)	<u>2,104.1</u>	<u>2,886.7</u>	<u>-</u>	<u>* 318.0</u>

Balance Check

0 0.0 1g 50g 50.0000 1g
 10g 10.0000 1g 100g 100.0000 1g
 0.5g 0.5000 1g

Analyzed by: JK

* NOTE: EXCESS SAMPLE BUILDUP
 ON FILTER WAS PLACED IN WITH
 PROBE WASH.

SHOLTES & KOOGLER



April 21, 1983
File: 107-80-17

Sholtes & Koogler
Environmental Consultants
1213 N.W. 6th Street
Gainesville, Florida 32601

Attention: Mr. George Allen

RESULTS OF ANALYSIS

Samples received: 4/13/83


Lab ID No.	Sample Designation	Chloride (mg/l)
C4158	Blank (0.1N NaOH)	2.7
C4159	Impinger Run 3, Inlet	110 100
C4160	Impinger Run 3, Outlet	469
C4161	Impinger Run 4, Inlet	1960
C4162	Impinger Run 4, Outlet	928
C4163	Impinger Run 5, Inlet	2401
C4164	Impinger Run 5, Outlet	890

Katherine M. White
Katherine M. White for
Jennet K. Burf
Associate Chemist

/mgm

Breedlove Associates Inc.
Environmental Consultants

618 Northwest 13th Avenue/Gainesville, Florida 32601/(904) 377-5830



April 21, 1983
File: 107-80-17

Sholtes & Koogler
Environmental Consultants
1213 N.W. 6th Street
Gainesville, Florida 32601

Attention: Mr. George Allen

RESULTS OF ANALYSIS

Samples received: 4/13/83

Lab ID No.	Sample Designation	Total Chromium (ug)	Total Lead (ug)
C4165	Run 3, Inlet	6614	434
C4166	Run 3, Outlet	1917	274
C4167	Run 4, Inlet	6614	1713
C4168	Run 4, Outlet	588	202
C4169	Run 5, Inlet	5346	1261
C4170	Run 5, Outlet	402	101
C4171	Blank filter	2.2	6.0


Katherine M. White for
Jennet K. Buri
Associate Chemist

/mgm

Breedlove Associates Inc.
Environmental Consultants

618 Northwest 13th Avenue/Gainesville, Florida 32601/(904) 377-5830

SAMPLING RATE

CALCULATIONS

SGK NOMOGRAPH

ΔH = ORIFICE READING (INCHES H_2O)

D_n = NOZZLE DIA. (INCHES)

ΔH_0 = METER BOX CONSTANT

B_w = MOISTURE FRACTION

T_m = METER TEMP ($^{\circ}F$)

T_s = STACK TEMP ($^{\circ}F$)

M_s = WET MOLECULAR WEIGHT OF STACK GAS (FROM TABLE)

ΔP = PITOT READING (INCHES H_2O)

$$\left[\frac{T_m + 460}{M_s(T_s + 460)} (1 - B_w)^2 \Delta H_0 (D_n)^4 17741 \right] \Delta P = \Delta H$$

.2 - .7

MOISTURE FRACTION	M_s
0.0	29.0
0.05	28.5
0.10	27.9
0.15	27.4
0.20	26.8
0.25	26.2
0.30	25.7
0.35	25.2
0.40	24.6

$$\frac{540}{28.2 (1160)} 32712$$

$$\frac{540}{27.0 (595)} 135 \quad 179$$

$$\frac{540}{28.2 (1135)} 32007$$

$$\frac{534}{27.8 (580)} 16124$$

$$\frac{530}{28.1 (1160)} 32596$$

RUN 1

Bobs

me

RUN 2 Bob

RUN 3

$$\frac{T_m + 460}{M_s(T_s + 460)} = \frac{0.0165}{0.0336} \quad \frac{0.0168}{0.033} \quad \frac{0.0162}{0.033}$$

$$\times (1 - B_w)^2 = \frac{0.8649}{0.6889} \quad \frac{0.8649}{0.6889} \quad \frac{0.8649}{0.6889} \quad \frac{0.8649}{0.6889}$$

$$\times \Delta H_0 = \frac{1.74}{1.55} \quad \frac{1.74}{1.55} \quad \frac{1.74}{1.55} \quad \frac{1.74}{1.55}$$

$$\times (D_n)^4 = \frac{0.004162}{0.0083} \quad \frac{0.004162}{0.0083} \quad \frac{0.004162}{0.0083} \quad \frac{0.004162}{0.0083}$$

$$\times 17741 = \frac{17741}{17741} \quad \frac{17741}{17741} \quad \frac{17741}{17741} \quad \frac{17741}{17741}$$

$$\times \Delta P = \frac{1.833}{2.7338} \quad \frac{1.833}{2.7338} \quad \frac{1.833}{2.7338} \quad \frac{1.833}{2.7338}$$

$$5.283 \quad 3.9459$$

SAMPLING RATE CALCULATIONS

SEK NOMOGRAPH

ΔH = ORIFICE READING (INCHES H_2O)

D_N = NOZZLE DIA. (INCHES)

ΔH_Q = METER BOX CONSTANT

B_W = MOISTURE FRACTION

T_M = METER TEMP ($^{\circ}F$)

T_S = STACK TEMP ($^{\circ}F$)

M_S = WET MOLECULAR WEIGHT OF STACK GAS (FROM TABLE)

ΔP = PITOT READING (INCHES H_2O)

$$\left[\frac{T_M + 460}{M_S(T_S + 460)} (1 - B_W)^2 \Delta H_Q (D_N)^4 17741 \right] \Delta P = \Delta H$$

MOISTURE FRACTION	M_S
0.0	29.0
0.05	28.5
0.10	27.9
0.15	27.4
0.20	26.8
0.25	26.2
0.30	25.7
0.35	25.2
0.40	24.6

$$\frac{530}{27.9(1235)} 34456.5$$

$$\frac{553}{27.8(1260)} 35028$$

05-15
TS 775
109/120

Run 1

Run 2

Run 3

$\frac{T_M + 460}{M_S(T_S + 460)} =$	$\frac{0.1538}{0.03748}$	0.01578		
$\times (1 - B_W)^2 =$	0.81	0.7921		
$\times \Delta H_Q =$	1.74	1.74		
$\times (D_N)^4 =$	0.03748	0.03748		
$\times 17741 =$	17741	17741	17741	17741
$\times \Delta P =$	10.076	14.468		

SAMPLING RATE CALCULATIONS

SK NOMOGRAPH

ΔH = ORIFICE READING (INCHES H_2O)

D_N = NOZZLE DIA. (INCHES)

ΔH_0 = METER BOX CONSTANT

B_w = MOISTURE FRACTION

T_m = METER TEMP ($^{\circ}F$)

T_s = STACK TEMP ($^{\circ}F$)

M_s = WET MOLECULAR WEIGHT OF STACK GAS (FROM TABLE)

ΔP = PITOT READING (INCHES H_2O)

$$\left[\frac{T_m + 460}{M_s(T_s + 460)} (1 - B_w)^2 \Delta H_0 (D_n)^4 17741 \right] \Delta P = \Delta H$$

T_s 129

$3/8$

MOISTURE FRACTION	M_s
0.0	29.0
0.05	28.5
0.10	27.9
0.15	27.4
0.20	26.8
0.25	26.2
0.30	25.7
0.35	25.2
0.40	24.6

$$\frac{5730}{27.6 (589)} = 16256.4$$

$$1 - .35$$

RUN 1

RUN 2

RUN 3

$$\frac{T_m + 460}{M_s(T_s + 460)} = 0.0326$$

$$\times (1 - B_w)^2 = 0.7744$$

$$\times \Delta H_0 = 1.55$$

$$\times (D_n)^4 = \frac{3}{8} \cdot 0.09987 \cdot \frac{5}{16} \cdot 0.08100$$


$$\times 17741 = 17741 \cdot 5.622$$

$$\times \Delta P = 13.87$$

CALIBRATIONS AND PROJECT PARTICIPANTS

SHOLTES & KOOGLER
ENVIRONMENTAL CONSULTANTS, INC.

SOURCE SAMPLING EQUIPMENT




S.K.E.C. Meter Box

Equipment used in Source Sampling is either manufactured by or assembled by SKEC. The guidelines followed are A.P.T.D. 0581, Details of Isokinetic Source Sampling Equipment, and A.P.T.D. 0576, Maintenance, Calibration and Operation of Isokinetic Source Sampling Equipment.

Nozzle #1

NOZZLE CALIBRATION

Nozzle



Date 4-5-83

Measurement No.

Inside Diameter (inches)

1	<u>.439</u>
2	<u>.441</u>
3	<u>.440</u>


Average

.440

Area of Nozzle

 Ft²

Calibrated by: R Paul



Nozzle X-section

Nozzle #3

NOZZLE CALIBRATION

Nozzle 1/4

Date 4-5-83

<u>Measurement No.</u>	<u>Inside Diameter (inches)</u>
<u>1</u>	<u>0.254</u>
<u>2</u>	<u>0.253</u>
<u>3</u>	<u>0.255</u>


Average

0.254

Area of Nozzle

 Ft²

Calibrated by: RC Paul



Nozzle X-section

#4

NOZZLE CALIBRATION

Nozzle 5/16

Date 4-5-83

<u>Measurement No.</u>	<u>Inside Diameter (inches)</u>
1	<u>.307</u>
2	<u>.307</u>
3	<u>.307</u>


Average

.307

Area of Nozzle

 Ft²

Calibrated by: R Sholtz



Nozzle X-section

5

NOZZLE CALIBRATION

Nozzle 7/16

Date 4-5-83

Measurement No.	Inside Diameter (inches)
1	.438
2	.437
3	.437


Average

.437

Area of Nozzle

 Ft²

Calibrated by: JSP.



Nozzle X-section

METER ORIFICE CHECK

Meter Box No. 16-1

Δ Ha of Box 1.74

Date 4-5-87

Time for 10 ft³ = 13 min. 24 sec.

^{856.4}
10 $\div$ 13.4 total minutes = 0.7462 Δ Ha₂

$\frac{0.75}{\Delta \text{ Ha}_2}$ = 1005 x 100 = 100.5%

RC Paul
Signature

Procedure: Set flow rate of meter box at Δ Ha of meter box--measure the amount of time required to sample 10.00 ft³.

Note: If answer is within 5 percent meter is o.k. If not, recalibrate meter.

METER ORIFICE CHECK

Meter Box No. #2

Δ Ha of Box 1.55

Date 4-5-83

30.00

Time for 10 ft³ = 13 min. 22 sec.

10 $\div$ 13.37 total minutes = 0.748 Δ Ha₂

$\frac{0.75}{\Delta \text{ Ha}_2}$ = 1,0027 x 100 = 100.27


Signature

Procedure: Set flow rate of meter box at Δ Ha of meter box--measure the amount of time required to sample 10.00 ft³.

Note: If answer is within 5 percent meter is o.k. If not, recalibrate meter.

100 FT. UMBILICAL CORD

SHOLTES & KOOGLER
ENVIRONMENTAL CONSULTANTS, INC.
THERMOCOUPLE CALIBRATIONS

Read Out No. SK-1

Date 9-22-82

PROBE NO.	N.B.S. °F	Probe °F	N.B.S. °F	Probe °F	N.B.S. °F	Probe °F
SK 2-1						
SK 4-1	56	54	32	30	228	226
SK 6-1	39	40	230	234	178	175
SK 6-2	33	36	82	85	190	193
SK 7-1	61	59	37	36	222	218
SK 8-1	66	63	39	38	217	216
SK 10-1	66	63	39	40	195	192
SK 11-1	55	56	40	40	197	195
SK 5-1-T	65	62	41	40	215	215
SK 10-T	52	50	37	36	260	258
Heated Box No. 1	254	253	45	41	221	221
Heated Box No. 2	198	194	264	259	220	218
Last Impinger Probe No. 1	42	44	204	206	65	64
Last Impinger Probe No. 2	56	54	34	32	185	181

J.K. Helstern
Signature

200 Ft. Umbilical cord

SHOLTES & KOOGLER
ENVIRONMENTAL CONSULTANTS, INC.
THERMOCOUPLE CALIBRATIONS


Read Out No. SK-2

Date 9-21-82

Short wire
extension
in parenthesis

PROBE NO.	AMBIENT		ICE WATER		HEATED BOX	
	N.B.S. °F	Probe °F	N.B.S. °F	Probe °F	N.B.S. °F	Probe °F
SK 2-1						
SK 4-1	69	71	39	37	237	233
SK 6-1	67	66	38	37	228	231
SK 6-2	91	90	40	40	242	244
SK 7-1	(51) 79	78	(46) 47	45	216	215
SK 8-1	76	75	34	31	177	178
SK 10-1	80	78	40	38	198	199
SK 11-1	145	143	40	42	243	239
SK 5-1-T	69	70	208	207	39	40
SK 10-T	62	61	274	270	40	40

Heated Box No. 1	72	71	212	208	271	273
Heated Box No. 2	(77) 79	77	35	32	259	257
Last Impinger Probe No. 1	74	74	36	37	261	261
Last Impinger Probe No. 2	78	79	35	34	269	270


Signature

SK-5-T

PITOT TUBE CALIBRATION MEASUREMENTS

DATE CALIBRATED 5-28-82

Pitot tube assembly level? X yes _____ no

Pitot tube openings damaged? _____ yes (explain below) X no

$\alpha_1 = \underline{2.0}^\circ (<10^\circ)$, $\alpha_2 = \underline{0.5}^\circ (<10^\circ)$, $\beta_1 = \underline{0.5}^\circ (<5^\circ)$,
 $\beta_2 = \underline{1.5}^\circ (<5^\circ)$

$\gamma = \underline{3.0}^\circ$, $\theta = \underline{4.5}^\circ$, $A = \underline{0.863}$ in. = $(P_a + P_b)$

$z = A \sin \gamma = \underline{0.045}$ in. ; <0.32 $<1/8$ in.

$w = A \sin \theta = \underline{0.068}$ in. ; <0.08 $<1/32$ in.

$P_A \underline{0.423}$ in. $P_b \underline{0.440}$ in.

$D_t = \underline{0.375}$

Comments: _____

Calibration required? _____ yes X no

Calibrated by George F. Habel

SK-41

PITOT TUBE CALIBRATION MEASUREMENTS

DATE CALIBRATED 5-11-82

Pitot tube assembly level? X yes _____ no

Pitot tube openings damaged? _____ yes (explain below) X no

$\alpha_1 = \underline{4.5}^\circ (<10^\circ)$, $\alpha_2 = \underline{2.5}^\circ (<10^\circ)$, $\beta_1 = \underline{2.0}^\circ (<5^\circ)$,

$\beta_2 = \underline{0.5}^\circ (<5^\circ)$

$\gamma = \underline{1.0}^\circ$, $\theta = \underline{3.5}^\circ$, $A = \underline{1.284}$ in. = $(P_a + P_b)$

$z = A \sin \gamma = \underline{0.0224}$ in. ; <0.32 $<1/8$ in.

$w = A \sin \theta = \underline{0.0784}$ in. ; <0.08 $<1/32$ in.

$P_A \underline{.641}$ in. $P_b \underline{.643}$ in.

$D_t = \underline{.375}$

Comments: _____

Calibration required? _____ yes X no

Calibrated by George F. Gabel

CALIBRATION FORM

Date 3-30-83

Box No. SK-1

Barometric Pressure 30.09 inches Hg

ΔHT	ΔHD	Teledyne Mass Flow Meter		Gas Volume, Dry Gas Meter			Temp. Teledyne	Temp. of Dry Meter	Time Minutes
		Desired liters/min	Actual liters/min	Initial	Final	Actual ft.3			
0	0.93	15	15	53.0	55.766	2.766	68	87	5
0	1.68	20	20	58.0	61.638	3.638	68	88	5
0	2.45	25	25	63.0	67.523	4.523	68	89	5
0	3.65	30	30	69.0	74.378	5.378	68	90	5
0	4.9	35	35	77.0	83.233	6.233	68	91	5

--MEAN--

GAS METER THERMOMETER CALIBRATION

N.B.S. °F	METER BOX

DELTA-H : 1.781 1.806 1.683 1.738 1.711 1.744

Y : 0.989 1.003 1.008 1.017 1.022 1.008

SCFM : 0.533 0.710 0.888 1.065 1.243

OF : 4.112 5.531 6.686 8.168 9.472

Signature George T. Habel

CALIBRATION FORM

Date 3-30-83

Barometric Pressure 30.09 inches Hg

Box No. SK-2

ΔHT	ΔHD	Teledyne Mass Flow Meter		Gas Volume, Dry Gas Meter			Temp. Teledyne	Temp. of Dry Meter	Time Minutes
		Desired liters/min	Actual liters/min	Initial	Final	Actual ft.3			
0	0.81	15	15	54.5	57.278	2.778	68	90	5
0	1.48	20	20	50.0	53.682	3.682	68	90	5
0	2.22	25	25	39.0	43.575	4.575	68	88	5
0	3.22	30	30	32.0	37.429	5.429	68	87	5
0	4.35	35	35	24.0	36.244	6.244	68	86	5

--MEAN--

GAS METER THERMOMETER CALIBRATION

DELTA-H : 1.543 1.586 1.528 1.542 1.533 1.546

N.B.S.
of

METER
BOX

Y : 0.991 0.995 0.996 1.003 1.012 0.999

SCFM : 0.533 0.710 0.888 1.065 1.243

CF : 3.848 5.201 6.359 7.651 8.894

Signature

George F. Noble

36 36

107 106

115 116

82 82

71 71

PROJECT PARTICIPANTS

John B. Koogler, Ph.D, P.E.

Project Advisor

George F. Allen

Project Manager

Robert S. Sholtes, Ph.D, P.E.

Field Test Coordinator

Rodney C. Paul

Field Test Crew

Rick Barton

Field Test Crew

Memo:

To: Dick Pearce / Keith Overcash

From: Michael Y Aldridge

Subject: Emissions tests performed at
Carolina Solite Corp
Aquadale N.C.
on April 5 and 6, 1983
by Stoltes & Koogler Inc.
of Gainesville, Fla.

A report of the subject tests has been reviewed and found to be acceptable. The results appear reliable, and adequately represent the ~~discharge~~ emissions from the kiln, and the outlet emissions from the control equipment during the test period. There is some question, however, regarding the method used by Stoltes & Koogler to calculate control equipment efficiencies for the various test runs.

According to the text of the report: "All control efficiencies were calculated from concentration data rather than from source data because of the uncertainty involved in measuring air flow rates at the inlet to the control system." (Section 5.0, page 8 of the subject report).

Exception is taken with the above method of calculation for the following reasons:

1. Removal of the velocity data for the inlet to the control system ~~results in the~~ shows

1. the velocity data for the inlet to the control system ~~is~~ appears to be consistent from point to point and in spite of the fact that the inlet sampling location does not comply with (MIL-21) there is no real reason to doubt its reliability.

1. Concentration can be affected by air in-leakage such as around a fan shaft. Basing control efficiency on concentration, assumes that these leaks can be ignored.

2. In spite of the fact that the sampling location at the inlet to the control system does not comply with method 1, the inlet velocity data appears to be consistent from point to point. Assuming that these data are reliable appears ~~to be~~ (in the opinion of this reviewer) to be a better engineering assumption than ignoring the fan leakage.

Therefore, it is considered that basing control efficiency on mass emission rate is preferable to basing it ~~on~~ on concentration.

The pollutants tested ~~and~~ were particulate, chromium, lead and chloride. The attached table shows the test results for each of the above pollutants and control efficiencies calculated both ways.

~~Compliance with 15WCHC2D~~

~~Control of particulate emissions from the subject source comply~~
Particulate control equipment was demonstrated to be in compliance with 15WCHC2D .0511 during the test period.

Emission Measurements
 No. 5 Kiln
 Carolina Solite Corporation
 Aquadale, North Carolina
 April 5-6, 1983

	<u>Particulate</u>		<u>Chromium</u>		<u>Lead</u>		<u>Chloride</u>	
	Gr/DSCF	lb/hr	Gr/DSCF	lb/hr	Gr/DSCF	lb/hr	Gr/DSCF	lb/hr
<u>Inlet</u>								
Run 3	2.87	102.89	.00526	.188	.000341	.012	Void	Void
Run 4	4.01	125.40	.00207	.064	.000533	.017	.3852	12.02
Run 5	<u>4.17</u>	<u>132.67</u>	<u>.00159</u>	<u>.050</u>	<u>.000373</u>	<u>.012</u>	<u>.4920</u>	<u>12.98</u>
Average	3.68	120.32	.00297	.101	.000416	.014	.4386	12.50
<u>Outlet</u>								
Run 3	.093	4.94	.000481	.026	.000067	.004	.04628	2.46
Run 4	.054	2.53	.000166	.008	.000055	.003	.08881	4.19
Run 5	<u>.043</u>	<u>2.11</u>	<u>.000115</u>	<u>.006</u>	<u>.000027</u>	<u>.001</u>	<u>.08278</u>	<u>4.03</u>
Average	.063	3.19	.000254	.013	.000050	.003	.07262	3.56

Percent Pollutant Removal

	<u>Particulate</u>		<u>Chromium</u>		<u>Lead</u>		<u>Chloride</u>	
	Concentration	Mass Rate	Concentration	Mass Rate	Concentration	Mass Rate	Concentration	Mass Rate
Run 3	96.8	95.23	90.9	86.43	80.4	70.66	Void	Void
Run 4	98.7	97.98	92.0	87.87	89.7	84.34	76.9	65.07
Run 5	<u>99.0</u>	<u>98.42</u>	<u>92.8</u>	<u>88.89</u>	<u>92.8</u>	<u>88.77</u>	<u>79.8</u>	<u>68.98</u>
Average	98.2	<u>97.21</u>	91.9	<u>87.73</u>	87.6	<u>81.26</u>	78.4	<u>67.03</u>

DIVISION OF ENVIRONMENTAL MANAGEMENT
Air Quality Section

December 16, 1983

M E M O R A N D U M

TO: Dick Peace/Keith Overcash

FROM: Michael Y. Aldridge *MYA*

SUBJECT: Emissions Test Performed at
Carolina Solite Corporation
Aquadale, North Carolina
on April 5&6, 1983
by Sholtes & Koogler, Inc.
of Gainesville, Florida

A report of the subject tests has been reviewed and found to be acceptable. The results appear reliable and adequately represent the emissions from the kiln and the outlet emissions from the control equipment during the test period. There is some question, however, regarding the method used by Sholtes & Koogler to calculate control equipment efficiencies for the various test runs. According to the text of the report: "All control efficiencies were calculated from concentration data rather than from source data because of the uncertainty involved in measuring air flow rates at the inlet to the control system." (Section 5.0, page 8 of the subject report).

Exception is taken with the above method of calculation for the following reasons:

1. Concentration can be affected by air in-leakage such as around a fan shaft. Basing control efficiency on concentration, assumes that these leaks can be ignored.
2. In spite of the fact that the sampling location at the inlet to the control system does not comply with method 1, the inlet velocity data appears to be consistent from point to point. Assuming that this data is reliable appears (in the opinion of this reviewer) to be a better engineering assumption than ignoring the fan leakage.

Therefore, it is considered that basing control efficiency on mass emission rate is preferable to basing it on concentration.

Memo
page 2
December 16, 1983

The pollutants tested were particulate, chromium, lead and chloride. The attached table shows the test results for each of the above pollutants and control efficiencies calculated both ways.

Particulate control equipment was demonstrated to be in compliance with 15 NCAC 2D .0511 during the test period.

/la

Attachment

cc: Dennis Ramsey



SHOLTES & KOOGLER, ENVIRONMENTAL CONSULTANTS

1213 N.W. 8th Street

Gainesville, Florida 32601

(904) 377-5822

SKEC 105-84-02

February 2, 1984

Mr. B. Keith Overcash, P.E.
Air Quality Regional Engineer
North Carolina Department of Natural
Resources and Community Development
Post Office Box 950
Mooresville, North Carolina 28115-0950

Subject: Source Emission Tests
Carolina Solite Corporation
Stanley County, North Carolina

Dear Mr. Overcash:

Your letter of January 16, 1984 regarding the emission measurements that our firm conducted at the Carolina Solite Aquadale, North Carolina plant was forwarded to us by Solite for comment. In this letter you questioned our reason for calculating the efficiency of the air pollution control system on the basis of particulate matter concentrations rather than on the basis of particulate matter mass flows.

We agree with your contention that it is more appropriate to determine the efficiency of control equipment on mass flow rates but, in our opinion, conditions at the Carolina Solite plant precluded the accurate determination of the mass flow rate of particulate matter at the inlet to the air pollution control system. If reference will be made to Figure 2, Page 5 of our report dated April 5-6, 1983, describing the results of the emission measurements, it will be noted that the gas flow at the inlet to the air pollution control system is through two square ducts which exit the kiln, immediately make approximately 60 degree turns to the vertical, and enter the feed rock bin. The undisturbed distance of gas flow both above and below the sampling ports is less than one-half an equivalent duct diameter. The

physical conditions that exist at the Inlet sampling location result in extremely turbulent gas flow and, in our opinion, resulted in gas flow measurements that were much less than ideal.

The gas flow measurements made at the discharge end of the air pollution control system (in the stack as shown in Figure 1, Page 4, of our report) are made at a point approximately 20 diameters above a flow disturbance and approximately nine stack diameters below the top of the stack; an ideal location for making gas flow measurements.

The problem anticipated in making accurate gas flow measurements at the Inlet to the air pollution control system proved to be a reality. This is demonstrated by comparing the flow measurements made at the Inlet (Table 1, Page 9) and outlet (Table 2, Page 10) of the air pollution control system. The flow measured at the outlet of the system was 5800 standard cubic feet per minute while the flow measured at the Inlet was just 3839 standard cubic feet per minute. The difference in flow is attributed, in our opinion, to the inaccuracies involved in the flow measurement at the Inlet of the control system.

Supporting our opinion on this matter was an inspection of the control system for leaks conducted by Dr. Robert S. Sholtes of our staff who was present at the time the emission measurements were made. Dr. Sholtes is a Registered Professional Engineer and has had over 20 years experience in the field of air pollution control and air quality management. He found the components of the air pollution control system and the connecting ductwork to be sound and concluded that the difference in the measured flow rates was the result of errors associated with gas flow measurements at the Inlet to the system.

Taking into consideration the facts set forth in the above paragraphs, we decided that the efficiency of the air pollution control system would most reasonably be represented by calculations based on particulate matter concentrations. As stated previously, we recognize that this is not the ideal method of calculating control system efficiencies but in the case of the Carolina Solite Aquadale Plant, it is the most acceptable.

Mr. B. Keith Overcash, P.E.
North Carolina Dept. of Natural Resources
and Community Development

February 2, 1984

Page 3

I hope that the information provided herein will satisfy the concerns you have regarding this matter. If you have further questions or comments, please do not hesitate to contact me.

Very truly yours,

SHOLTES & KOOGLER,
ENVIRONMENTAL CONSULTANTS, INC.

John B. Koogler, Ph.D., P.E.

JBK:ldh

cc: Mr. Ed Martin
Mr. Tom Purvis
Mr. George Eure

JAMES A. SUMMERS, SECRETARY
DIVISION OF ENVIRONMENTAL MANAGEMENT

January 16, 1984

Mr. E. E. Martin, Vice-President
Solite Corporation
Post Office Box 27211
Richmond, Virginia 23261

Subject: Source Emissions Test
Carolina Solite Corporation
Stanly County, N. C.

Dear Mr. Martin:

On April 5 and 6, 1983, a source emissions test was performed on the coal/coke/No. 2 oil/liquid waste fired light weight aggregate expanding kiln No. 5 (35 MBTU/hr. maximum heat input) controlled by a packed bed preconditioner, a multicyclone, a precooler and a crossflow gravity spray wet scrubber at Carolina Solite Corporation, Aquadale, N. C.

A review of the report of the results of the aforementioned test has been completed by our Source Test Unit in Raleigh. The test methods have been found to be acceptable and the results appear reliable and adequately represent the emissions from the kiln before and after the aforementioned air pollution control devices. However, the method used by Sholtes & Koogler to calculate control equipment efficiencies is questionable. In Section 5.0, Page 8 of the subject report, "All control efficiencies were calculated from concentration data rather than the source data because of the uncertainty involved in measuring air flow rates at the inlet to the control system." This Office considers that basing control efficiency on mass emission rate is preferable to basing it on concentration. Compliance with 15 NCAC 2D .0511, "Particulates, SO₂ from Lightweight Aggregate Processes", has been demonstrated based on the mass emission rate calculation.

If you have any questions concerning the above matter, please feel free to call Mr. Yin-Pong Chang or me at (704) 663-1699.

Sincerely,



B. Keith Overcash, P. E.
Air Quality Regional Engineer


YPC:sju





P. O. BOX 27211 • RICHMOND • VIRGINIA 23261 • PHONE (804) 321-6761

April 29, 1983



Mr. Keith Overcash
919 North Main Street
Mooresville, North Carolina 28115

Dear Mr. Overcash:

Attached are three copies of the Sholtes & Koogler stack test results on emissions from the #5 kiln of Carolina Solite Corporation at Aquadale, North Carolina, conducted on April 5-6, 1983. These tests were conducted in order to satisfy the Provisos 10 and 11 of Permit No. 32 25 R 4 issued on February 10, 1983 by the North Carolina Department of Natural Resources and Community Development. These provisos are related to the combustion of liquid waste in kilns #5 - 8 to provide the heat necessary to produce lightweight aggregate.

In addition to the test results provided by Sholtes & Koogler, tests were conducted by our on-site laboratory to determine the Btu, chloride, water, ash and specific gravity of the fuels being burned during the course of the tests. These results are as follows:

Btu - 113,892 per gal.
Chloride - 1.9%
Water - none detected
Ash - 1.4%
Specific gravity - .871

If any additional information is required, please don't hesitate to contact me or George Eure, plant manager at Carolina Solite.

Sincerely,

SOLITE CORPORATION

A handwritten signature in cursive script, appearing to read "E. E. Martin".

E. E. Martin, Vice President

EEM:emd
Encl. (3)

cc: George Eure
Wm. T. Johnson

DISTRIBUTION

Yellow Copy - Mon. Mgt./Central Files
Blue Copy - Regional Office
(Optional) White Copy - Permits
Enforcement
Stack Test

NORTH CAROLINA DIVISION OF ENVIRONMENTAL MANAGEMENT
AIR QUALITY REPORT

REQUEST FOR ACTION TO BE TAKEN

The item listed below requires action to ascertain compliance under Article 21, Chapter 143 of the General Statutes of North Carolina, concerning rules and regulations governing the control of air pollution:

Name	Address	County
Carolina Solite Corp.	Aquadale	Stanly
Subject		

Observe Stack Test in Permit No. 3225R4

Investigation Requested By	Address	County
----------------------------	---------	--------

Remarks

Assigned To	Date
MRO	

Investigated By	Date	Returned
Yin-Pong Chang	4/5 and 4/6/83	4/11/83

Action Recommended

Investigation Report

CONTACT: Ed. E. Martin, Vice-President
George Eure, Plant Manager

The subject stack test was performed on the light weight aggregate expanded kiln No. 5 fired by coal and 225 gallons/hr. liquid waste solvents for sampling particulate chromium, lead (Stip. No. 10), and hydrogen chloride (Stip. No. 11) emissions as required in Permit No. 3225R4. Two sample trains were sampled simultaneously, one each at the inlet and outlet of the air pollution control system, in order to determine whether the particulate emissions control efficiency of the multicyclone, precooler, and wet scrubber was greater than 95% as required in EMC Regulation 15 NCAC 2D .0511. The stack test was conducted by Sholtes & Koogler from Gainesville, Florida in accordance with EPA Method No. 5. Three runs of particulate emission test were performed on 4/5/83 at the outlet, and only two-thirds of the third run was performed at the inlet of the air pollution control system due to a melting tube in the main sample train (or hot box) from filter to the impingers.

It was discovered at the end of the second run that too much excess air flow had been sampled during those two runs and would result in higher particulate emission rate than normal operating conditions. Two additional runs were performed both on the inlet and outlet of air pollution control system on 4/6/83. A 30 minutes visible emission evaluation of the kiln No. 5 revealed that the facility was in compliance with EMC Regulation 15 NCAC 2D .0521.

Correspondence To:

Signature: Yin-Pong Chang

SOURCE TEST
OBSERVERS CHECKLIST

N. C. Division of Environmental Management

Source Name: <u>Carolina Solite Corp.</u>	Testing Firm: <u>Sholtes & Koogler</u>
Address: <u>Aquadale, N.C.</u>	Address: <u>1213 NW 6th St.</u>
Plant Location: _____	<u>Gainesville, Florida 32601</u>
Source Contact: <u>George Eune, Plant Manager</u>	Phone: <u>(904) 377-5822</u>
Phone: <u>(704) 474-3165</u>	Test Engineer: <u>Robert S. Sholtes, Ph.D., P.E.</u>
	Assistant: <u>Rodney C. Paul</u>

Other Personnel Involved

Affiliation

Ed. E. Martin, Vice-President of Manufacturing

Process Description: coal/coke No. 2 oil/liquid waste fired light weight aggregate expanded kilns No. 5

Process Rate

During Test:

Maximum

Process Rate:

35 MBTU/hr. maximum heat input

Burner Sizes

(Incinerators)

Pri: _____

Sec: _____

Inlet	Outlet	TEST PARAMETERS
Duct Size: <u>2 - 21" x 24"</u>	<u>36 1/2"</u>	Pollutant Sampled: <u>Particulate, Chrome, Lead, Hydrogen Chloride</u>
Distance Before Ports: _____	<u>56'</u>	E. P. A. Method No.: <u># 5</u>
Distance After Ports: _____	<u>34'</u>	If method differs from E. P. A. method, explain:
Number of Test Points: <u>2 x 24</u>	<u>12</u>	<u>4/5/83 Run #1 Run #2</u>
Number of Runs: <u>3</u>	<u>3</u>	Inlet Outlet Inlet Outlet
Sampling Time Per Run (min.): <u>96</u>	<u>72</u>	<u>0.00/0.02 0.01/0.00 0.016/0.009 0.005/0.00</u>
		<u>10:31 A.M. 10:28 A.M. 14:40 P.M. 14:37 P.M.</u>
		<u>13:09 P.M. 12:05 P.M. 17:40 P.M. 16:00 P.M.</u>
		For Method 5 sampling train record ΔH_2 _____

Leakage Rate (ft³/min.)

0.02 ft³/min. or less

Time Started

24 hr.

Time Ended

Clock

Test Date(s)

Inlet	Run #1	Outlet	Inlet	Run #2	Outlet	Inlet	Run #3	Outlet
0.012/0.000	0.005/0.000	0.017/0.011	0.016/0.00	0.006/-	0.018/-			
17:57	18:06	9:12	9:05	12:29	13:0			
19:40	19:40	11:27	10:22	14:40	14:40			
4/5/83	4/5/83	4/6/83	4/6/83	4/6/83	4/6/83			

See Graph on Reverse Side

For Number of Test Points.

Use Reverse Side for Comments.

Request 2 Copies of Report

Yin-Pong Chung
OBSERVERS SIGNATURE

DEPARTMENT OF NATURAL AND ECONOMIC RESOURCES
DIVISION OF ENVIRONMENTAL MANAGEMENT

Plume Observation Record Form

Date 4/6/83

Source Carolina Solite Corp.

Observer Jim-Pony Chang

Address Aquadale, N.C.

Checked By Bk Onal

Type of installation coal/liquid waste fired

light weight aggregate Kiln No. 5

Fuel Coal/liq. w. Stack Ht. 90'

Observers Distance from Stack
110 Ft.

Wind Speed 0-5 mph Direct South

Sky Condition Sunny

Plume Color steam + tan

Plume Background sky

Start Time 13:25 P.M.

Ending Time 13:55 P.M.

Ending Weather

Wind Speed 0-5 mph Direct South

Sky Condition sunny

No. Units in Excess of
standard 0


5 min/hr. allow 20

No. Units of VIO. 0

Remarks: _____

Sec. Min.	0	15	30	45	Sec. Min.	0	15	30	45
0	15	15	10	10	30				
1	10	10	10	10	31				
2	10	5	5	10	32				
3	5	10	10	10	33				
4	10	10	10	10	34				
5	5	10	5	5	35				
6	10	10	10	5	36				
7	10	10	10	10	37				
8	10	10	10	10	38				
9	10	10	10	10	39				
10	10	10	10	10	40				
11	10	10	10	10	41				
12	10	10	10	10	42				
13	5	5	5	5	43				
14	10	10	10	10	44				
15	10	10	10	10	45				
16	5	5	5	5	46				
17	5	5	5	5	47				
18	-	-	-	-	48				
19	10	10	10	10	49				
20	10	10	10	10	50				
21	5	5	5	5	51				
22	10	10	15	10	52				
23	10	10	10	10	53				
24	5	5	5	5	54				
25	5	5	5	5	55				
26	5	5	5	5	56				
27	5	10	5	5	57				
28	5	5	10	5	58				
29	5	10	10	10	59				

Use circle to draw a diagram showing any pertinent buildings, trees, roads etc. in relationship to your point of observation of the source.



Emission Measurements

No. 5 Kiln
Carolina Solite Corp. 20
Aquadale, N.C. 23
April 5-6, 1983 13

Particulate		Chromium		Lead	
Gr/DSCF	Lb/hr	Gr/DSCF	Lb/hr	Gr/DSCF	Lb/hr
2.87	102.89	.00526	.188	.000341	.012
4.01	125.40	.00207	.064	.000533	.017
1.17	132.67	.00159	.050	.000373	.012
3.68	120.32	.00297	.101	.000416	.014
.093	4.94	.000481	.026	.000067	.004
.054	2.53	.000166	.008	.000055	.003
.043	2.11	.000115	.006	.000027	.001
.063	3.19	.000254	.013	.000050	.003

Chloride	
Gr/DSCF	Lb/hr
Void	Void
.3852	12.02
.4920	12.98
.4386	12.50

.04628	2.46
.08881	4.19
.08278	4.03
.07262	3.56

Percent Pollutant Removal

Particulate		Chromium		Lead	
Concen- tration	mass rate	concen- tration	mass rate	concen- tration	mass rate
96.8	95.23	90.9	86.43	80.4	70.66
98.7	97.98	92.0	87.87	89.7	84.34
99.0	98.42	92.8	88.89	92.8	88.77
98.2	97.21	91.9	87.73	87.6	81.26

Chloride	
Concen- tration	mass rate
Void	Void
76.9	65.07
79.8	68.98
78.4	67.03