

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020

FAX: (612) 786-7854

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

**RESULTS OF THE JANUARY 25, 1990
PARTICULATE AND SULFUR DIOXIDE ENGINEERING
EMISSION TEST ON THE LINE 7 GRATE KILN AT THE
USX MINNESOTA ORE OPERATION FACILITY**

Submitted to:

USS, A DIVISION OF USX CORPORATION
P.O. Box 417
Mt. Iron, Minnesota 55768

Attention: Nick Brascugli
Supervisor of Facility Engineering

Approved by:



Kathleen Eickstadt
Senior Data Analyst
Field Testing Division

Report Number 0-2935
March 7, 1990
KE/des



TABLE OF CONTENTS

	ABBREVIATIONS	111
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	3
3	RESULTS	6
	3.1 Results of Orsat and Moisture Analyses	7
	3.2 Results of the Particulate Loading Determinations	9
	3.3 Results of the Sulfur Dioxide Determinations	11

APPENDICES:

- A - Sampling Train Calibration Data
- B - Location of Test Ports
- C - Methods 2-6 Field Data Sheet
- D - Laboratory Data Sheets
- E - Results of Particulate Catch Sulfate Analyses
- F - Process Data
- G - Procedures
- H - Calculation Equations



ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (^o F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68 °F (20 °C) and 29.92 IN. of mercury pressure.

1 INTRODUCTION

On January 25, 1990, Interpoll Laboratories personnel conducted a particulate and sulfur dioxide emission engineering test on the Line 7 Grate Kiln at the USX Minnesota Ore Operation Facility in Mt. Iron, Minnesota. On-site testing was performed by D. Van Hoever and C. Mosser. Coordination between testing activities and plant operation was provided by Nick Brascugli of USX.

Particulate determinations were performed in accordance with EPA Methods 1 - 6, CFR Title 40, Part 60, Appendix A (revised July 1, 1988). Appropriate nozzle diameters for isokinetic sampling were selected from previous flow data. An Interpoll Labs sampling train which meets or exceeds specifications in the above-cited reference was used to extract particulate samples by means of a heated glass-lined probe. Sulfur dioxide samples were collected in the back half of the Method 5 sampling train in accordance with the large impinger version of Method 6 without the isopropanol. In addition, the probe wash and filter catches were combined and analyzed for sulfate by ion chromatography.

Integrated flue gas samples were extracted simultaneously with each particulate and sulfur dioxide sample using a specially designed gas sampling system. The integrated flue gas samples were collected in 44-liter Tedlar bags housed in a protective aluminum container. After sampling was complete, the bags were sealed and returned to the laboratory for Orsat analysis. Prior to sampling, the Tedlar bags are leak checked at 15 IN.HG. vacuum with an in-line rotameter. Bags with any detectable inleakage are discarded.

Testing on the waste gas stack was conducted from a set of four test ports oriented at 90°. The test ports are located 3.4 diameters downstream of the nearest flow disturbance and 2.3 diameters upstream of the stack

exit. A 24-point traverse was used to collect the particulate samples. Each traverse point was sampled 2.5 minutes for a total of 64 minutes per run.

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The important results of the particulate emission engineering test are summarized in Table 1. As will be noted, the particulate emission factor averaged 0.20 LB/10³BTU.

A summary of the sulfur dioxide results is presented in Table 2. The sulfur dioxide concentration averaged 7 ppm,w with a corresponding average emission rate of 27 LB/HR.

The results of the sulfate analysis conducted on the particulate catch were as follows:

<u>Run</u>	<u>Sulfur Content</u>
	<u>% by Weight</u>
1	64.0
2	42.6
3	46.6

TABLE 1. Summary of the Results of the January 25, 1990 Particulate Emission Engineering Test on the No. 7 Waste Gas Stack at the United States Steel Plant in Mt. Iron, Minnesota.

ITEM	Run 1	Run 2	Run 3
Date of test	01-25-90	01-25-90	01-25-90
Time runs were done (HRS)	1010/1113	1140/1245	1303/1408
Process Rate (LTPH)	624 557	634 566	642 573
Volumetric flow			
actual (ACFM)	446526	452674	452524
standard (DSCFM)	369986	376138	376339
Gas temperature (DEG-F)	103	103	103
Moisture content (%V/V)	7.19	6.92	6.88
Gas composition (%V/V, dry)			
carbon dioxide	3.60	3.70	4.00
oxygen	17.10	17.00	16.80
nitrogen	79.30	79.30	79.20
Isokinetic variation (%)	98.9	91.4	91.9
Particulate concentration			
actual (GR/ACF)	.0151	.0136	.0155
standard (GR/DSCF)	.0182	.0164	.0186
Part. emission rate (LB/HR)	57.66	52.97	60.06
Emission factor			
By Ratio (LB/MMBTU)	0.210	0.190	0.213
By F-Fact. (LB/MMBTU)			

NOTE: Dry catch only

Table 2. Summary of the Results of the January 25, 1990 Sulfur Dioxide Determinations on the No. 7 Waste Gas Stack at the United States Steel Plant in Mt. Iron, Minnesota.

Test/Run	Concentration (ppm.w)	Emission Rate (LB/HR)
1/1	6	22
1/2	7	28
1/3	8	30
Avg.	7	27

3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition (Orsat and moisture) are presented first followed by the computer printout of the particulate and sulfur dioxide results.

The results have been calculated on a personal computer using programs written in Extended BASIC specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The particulate emission rate has been calculated using the product of the concentration times flow method. -

3.1 Results of Orsat and Moisture Analyses

Test No. 1
 No. 7 Waste Gas Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

	Run 1	Run 2	Run 3
Date of run	01-25-90	01-25-90	01-25-90

Dry basis (orsat)

carbon dioxide.....	3.60	3.70	4.00
oxygen.....	17.10	17.00	16.80
carbon monoxide.....	0.00	0.00	0.00
nitrogen.....	79.30	79.30	79.20

Wet basis (orsat)

carbon dioxide.....	3.34	3.44	3.72
oxygen.....	15.87	15.82	15.64
carbon monoxide.....	0.00	0.00	0.00
nitrogen.....	73.60	73.81	73.75
water vapor.....	7.19	6.92	6.88

Dry molecular weight.....	29.26	29.27	29.31
Wet molecular weight.....	28.45	28.49	28.53
Specific gravity.....	0.983	0.984	0.986
Water mass flow.....(LB/HR)	80416	78469	78033

3.2 Results of Particulate Loading Determinations

Test No. 1
No. 7 Waste Gas Stack

Results of Particulate Loading Determinations-----Method 5

	Run 1 01-25-90	Run 2 01-25-90	Run 3 01-25-90
Date of run			
Time run start/end.....(HRS)	1010/1118	1140/1245	1303/1408
Static pressure.....(IN.WC)	-0.26	-0.26	-0.26
Cross sectional area (SQ.FT)	201.06	201.06	201.06
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	72.0	48.0	48.0
desiccant.....(GRAMS)	16.0	9.0	8.0
total.....(GRAMS)	88.0	56.0	56.0
Total particulate material..			
.....collected(grams)	0.0631	0.0378	0.0431
Gas meter coefficient.....	0.9942	0.9942	0.9942
Barometric pressure..(IN.HG)	28.50	28.50	28.50
Avg. orif.pres.drop..(IN.WC)	2.90	1.28	1.30
Avg. gas meter temp..(DEG-F)	85.9	85.8	88.4
Volume through gas meter....			
at meter conditions...(CF)	58.05	38.64	39.06
standard conditions.(DSCF)	53.55	35.50	35.72
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.300	.252	.252
Avg.stack gas temp ..(DEG-F)	103	103	103
Volumetric flow rate.....			
actual.....(ACFM)	446526	452674	452524
dry standard.....(DSCFM)	369986	376138	376339
Isokinetic variation.....(%)	98.9	91.4	91.9
Particulate concentration...			
actual.....(GR/ACF)	0.01506	0.01365	0.01548
dry standard.....(GR/DSCF)	0.01818	0.01643	0.01862
Particle mass rate...(LB/HR)	57.66	52.97	60.06

3.3 Results of Sulfur Dioxide Determinations

Test No. 1
 No. 7 Waste Gas Stack

Results of Sulfur Dioxide Determinations-----Method 6

	Run 1	Run 2	Run 3
Date of run	01-25-90	01-25-90	01-25-90
Time run start/end.....(HRS)	1010-1118	1140-1245	1303-1408
Barometric pressure...(IN.HG)	28.50	28.50	28.50
Meter temperature....(DEG-F)	85.90	85.80	88.40
Meter correction coefficient	0.9942	0.9942	0.9942
Volume through gas meter....			
at meter conditions...(CF)	58.050	38.640	39.060
standard conditions...(SCF)	53.548	35.502	35.720
Total sampling time....(MIN)	60.0	60.0	60.0
Moisture content.....(%V/V)	7.19	6.92	6.88
Oxygen content....(%V/V DRY)	17.10	17.00	16.80
Milliequivalents of SO4 in..			
gas sample.....	0.7648	0.6269	0.6770
<u>Sulfur dioxide concentration</u>			
(GR/DSCF).....	0.0071	0.0087	0.0094
(MG/DSCM).....	16	20	21
(PPM-DRY).....	6	8	8
(PPM-WET).....	6	7	8
SO2 Emission rate....(LB/HR)	22.39	28.14	30.22

APPENDIX A

SAMPLING TRAIN CALIBRATION DATA

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: March 7, 1990

Meter Box No. : 3 (Rockwell Dry Test Meter Serial No. 35303)

Date of Last Calibration: January 16, 1990
Calibration Technician: D. Van Hoever
Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
January 25, 1990	0-2935	713.10	857.36	144.26	144.26

* Total volume through meter since last calibration.

11/16/90

Bar. Press. 29.07 in. Hg

INTERPOLL LABORATORIES, INC.
METER CALIBRATION SHEET
EPA METHOD 5

Control Module No. 3

Serial No. DTM 35303

Wet Test Meter No. AL-20Technician [illegible]

Water was in tolerance ☒
 Meter was not in tolerance ☐: readjusted linkage
 Meter was not in tolerance ☐: changed dry test meters

Approved by J. Jones Date 1-17-90

* Based on AL-20 wet test meter calibration in August 1989 against Bell Prover (NBS Traceable) - Carl Poe Co.

S0102R 8/89

Interpoll Laboratories. Inc.

(612) 786-6020

Nozzle Calibration

Data Sheet

Date of Calibration: January 25, 1990

Nozzle Number 8-5

Technician: D. Van Hoever

Nozzle rotated by 60 degree increments and diameter measured to nearest 0.001 inch. Observed readings and average:

Position	Diameter (inches)
1	0.293
2	0.303
3	0.302
Average:	0.300

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: January 25, 1990
Technician: D. Van Hoever

Nozzle Number 8-4

Nozzle rotated by 60 degree increments and diameter measured to nearest 0.001 inch. Observed readings and average:

Position	Diameter (inches)
1	0.258
2	0.248
3	0.250
Average:	0.252

Interpoll Laboratories
(612)786-6020

S-Type Pitot Tube Inspection Sheet

Pitobe No. 6-21

Pitot tube dimensions:

1. External tubing diameter (D_t) .316 IN.
2. Base to Side A opening plane (P_A) .464 IN.
3. Base to Side B opening plane (P_B) .462 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0
6. $B_1 < 5^\circ$ 2
7. $B_2 < 5^\circ$ 1
8. $Z < .125"$ 2
9. $W < .0625"$ 2

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .762 IN.
11. Pitot to probe sheath 3.20 IN.
12. Pitot to thermocouple (parallel to probe) 3.00 IN.
13. Pitot to thermocouple (perpendicular to probe) .762 IN.

Date of Inspection:

12-8-89

Inspected by:

[Signature]

S-348(1)

Interpoll Laboratories, Inc.
(612) 786-6020

EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

* Control module
never used since
latest calibration

Module No. 3 Date 1/25/90
Job USX - Minntac Operator Diff

Instructions: Operate the control module at ΔH_e for 10 minutes without the umbilical. Note the following data:

Barometric pressure (P_b) 28.50 IN.HG. ΔH_e 1.90 IN.WC.

Time (MIN)	Volume (CF)	Gas Meter Temperature (°F)	
		Inlet	Outlet
0	(713.10)	64	60
2	714.57	69	63
4	716.02	70	63
6	717.49	74	67
8	718.95	77	70
10	(720.43)	82	76
$V_m = 7.33$ CF		Average Meter Temp (t_m) = 69.58	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\cancel{7.755} V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{\frac{1}{2}} = \frac{18.5818}{4.3106} = 1.03$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning the test".

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test:

Vendor AITKINS PDT5
 Model 39658-K Serial Number 881021528-197
 Range -112.0 to 1999 °F Thermocouple Type TYPE K
 Date of Calibration 12/11/89 Technician D. SMITH

Method of Calibration:

- ☐ Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- ☐ Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp ($^{\circ}\text{F}$) Nominal	Temperature of Standard or Simulated Temp ($^{\circ}\text{F}$)	Response of Unit Under Test ($^{\circ}\text{F}$)	Deviation	
			Δt ($^{\circ}\text{F}$)	(%)
0	0	0.1	.1	.022
100	100	97.4	2.6	.46
200	200	200	0	0
300	300	278	2	.36
400	400	395	5	.58
500	500	494	6	.63
600	600	596	4	.38
700	700	695	5	.43
800	800	800	0	0
900	900	901	1	.07
1000	1000	1004	4	.27
1100	1100	1107	7	.45
1200	1200	1211	11	.66
1300	1300	1310	10	.57
1400	1400	1413	13	.70
1500	1500	1509	9	.46
1600	1600	1608	8	.39
1700	1700	1702	2	.09
1800	1800	1798	2	.08
1900	1900	1889	11	.47
2000	2000	1982	18	.73
2100	2100	OFF	—	—
		Averages:	5.75	.37

OF = off scale response by unit under test ($^{\circ}\text{F}$)
 $\% \text{ dev} = 100 \Delta t / (460 + \Delta t)$



Unit in tolerance



Unit was not in tolerance; recalibrated - See new calibration sheet.

DIFFERENTIAL PROOF FIRE AND PROOF CALIBRATION CURVES

WET TEST METER

DIFFERENTIAL - INCHES H2O

PULSATION RANGE

PROOF

PROOF %

CORRECT VOLUME = INDEX READING x PROOF + 100


FLOW RATE - CUBIC FEET OF AIR PER HOUR

20 40 60 80 100 120

DAVID BANKS
AUGUST, 1989

Calibrated with a 10 Ft. American Bell Prover, Serial No. 3157. Traceable to the Bureau of Standards. Reference No. 106870, PI-TAPE.


AL-20 American Wet Test Meter
Serial No. P-717
Stainless Steel w/Removable Back
Calibrated w/Saturated Air
Water Temp. 74° F.
Air Temp. 74° F.
Inlet Pressure 2" H2O Constant
Calibration Rate: 60 CFH Per/Hr.
Capacity Rate: 120 CFH Per/Hr.
Restricted Outlet for Rate Deviation



APPENDIX B

LOCATION OF TEST PORTS

Step II
Agglomerator
Waste Gas



Elevation View

1. Emission Source Number - 8,21
2. " " Flow Sheet Number
3. Stack Diameter - 15.0'
4. " Design Gas Velocity - 51.3 FPS
5. " " Volume - 541,000 CFM
6. " " Temperature - 125 to 150°F
7. Pollutant - Taconite Dust
8. Stack Loading - 0.061 GR./Cubic Ft
9. Traverse Points - 38


Step II Agglomerator
Minnesota Ore Operations
Minnetac, Mt. Iron, Minnesota

APPENDIX C

METHODS 2-6 FIELD DATA SHEETS

INTERPOL LABORATORIES EPA METHOD 2 FIELD DATA SHEET

Job USA - MINUTAC
 Source No. 7 Waste Gas Stack
 Test 1 Run Date 1/25/90
 Stack dimen. 192" IN.
 Dry bulb °F Wet bulb °F
 Manometer: ☒ Reg. ☐ Exp. ☐ Elec.
 Barometric pressure 28.50 in Hg
 Static pressure -.26 in WC
 Operators D. Van Hoever & C. Mosser
 Pitot No. 121-6 Cp .84



Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: 5.5 in.	Time start:	hrs	
A 1	.021	4.03	9.53	.36	
2	.067	12.86	18.36	.41	
3	.118	22.66	28.16	.40	103
4	.177	33.98	39.48	.38	
5	.250	48	53.5	.35	
6	.356	68.35	73.85	.35	
B 1					
2					
3					
4					
5					
6					
C 1					
2					
3					
4					
5					
6					
D 1					
2					
3					
4					
5					
6					
Temp. meas. tool & S/N: <u>POT-5</u>				Time end:	hrs

R or nothing = reg. manometer; S = expanded; E = electronic S-392.1

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job U.S. X Date 1/25/90 Test 1 Run 1
 Source #7 Waste Recovery Stack No. of traverse points 24
 Method 5+6 Filter holder: S.S Filter type: glass fiber

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac) ~~☒~~
 Posttest: 0 cfm at 15 in. Hg. (vac) ~~☒~~

Particulate Catch Data:

No.s of filters used: 1802 Recovery solvent(s)
~~☒~~ acetone
☐ other(s) _____

No. of probe wash bottles: _____
 Sample recovered by: [Signature]

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	272	200	72
Impinger No. 3			
Condenser			
Desiccant	1360	1344	16
Total			88

Integrated Gas Sampling Data:

Bag Pump No. 38 Box No. 12 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 10¹⁶ (HRS) Time end: 11¹⁷ (HRS)
 Sampling rate: 400 cc/min Operator: [Signature]
 S/N of O₂ Analyzer used to monitor train outlet: 3

CF-023

Job USX
Source #7 waste Gas Stack
Date 1/25/90 1991 1 Run 1

[illegible]

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job USX Minntac Date 1/25/90 Test 1 Run 2
 Source #7 Waste Gas Stack No. of traverse points 24
 Method 5-6 Filter holder: S.S Filter type: glass fiber

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac) ☒
 Posttest: 0 cfm at 8 in. Hg. (vac) ☒

Particulate Catch Data:

No.s of filters used: 1838 Recovery solvent(s) ☒ acetone
☐ other(s) _____

No. of probe wash bottles: 1
 Sample recovered by: SW

Condensate Data:

Item	Weight(g)		
	Final	Tare	Difference
Impinger No. 1		200	
Impinger No. 2	248		48
Impinger No. 3			
Condenser			
Desiccant	1447	1439	8
Total			56

Integrated Gas Sampling Data:

Bag Pump No. B8 Box No. 12 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 1145 (HRS) Time end: 1245 (HRS)
 Sampling rate: 400 cc/min Operator: SW
 S/N of O₂ Analyzer used to monitor train outlet: 3

CF-023

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job U.S.X Operator DAH acm Pitot No. V21-6 Cp .84
 Source #7 Waste Recovery Stack Meter Box No. 3 XRF 1.87 IN MC IN MC INHg H2O 7 X
 Date 11/25/90 Computer conf. SPVZ Nozzle No. 8-2 Nozzle Dia. 2.52 IN.

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (inWC)	Droplet Water (inWC)	Des. Vol. (cf)	VAC. inHg	Temperatures (°F)						Oxygen (xv/v)				
							Stack	Probe	Duct	Inpg.	Cas/in	Cas/Out					
D 6	11.40	779.27															
5	2.5	780.80	.36	1.18	0.82	4	103	276	252	40	79	79					16.0
4	5	782.35	.37	1.19	2.37	4	103				81	79					16.3
3	7.5	784.00	.43	1.39	4.04	4.5	103				83	80					16.5
2	10	785.86	.51	1.65	5.87	5	103				84	80					16.8
1	12.5	787.61	.51	1.66	7.70	5	103				85	80					16.7
C 6	15	789.37	.43	1.41	9.38	4.5	103	273	258	37	85	80					16.6
5	17.5	790.99	.38	1.23	0.97	4	103				83	79					16.4
4	20	792.64	.44	1.43	2.66	4.5	103				83	80					16.6
3	22.5	794.35	.45	1.46	4.38	4.5	103				84	80					16.5
2	25	796.15	.48	1.54	6.14	5	103				86	82					16.6
1	27.5	797.89	.48	1.56	7.94	5	103				85	81					16.9
B 6	30	799.58	.42	1.37	9.60	4.3	103				82	79					16.7
5	32.5	801.09	.33	1.07	1.07	4	103	268	255	36	82	78					16.6
4	35	802.57	.35	1.03	2.59	4	103				84	80					16.9
3	37.5	804.10	.35	1.14	4.10	4	103				85	80					16.5
2	40	805.58	.34	1.10	5.60	4	103				86	81					16.3
1	42.5	807.12	.36	1.17	7.14	4	103				86	82					16.4
A 6	45	808.69	.38	1.24	8.73	4	103				86	82					16.5
5	47.5	810.20	.34	1.11	0.23	4	103				86	82					16.5
4	50	811.75	.36	1.17	1.78	4	103				86	82					16.6
3	52.5	813.27	.35	1.14	3.30	4	103	272	257	34	86	82					16.4
2	55	814.81	.35	1.14	4.83	4	103				86	83					16.5
1	57.5	816.40	.37	1.21	6.39	4	103				85	82					16.6
	60	817.91	.35	1.14	7.91		103				85	82					16.5
	12.45																
V ₀ = 38.64																	Av _{g.} = 85.8
θ = 60																	

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job USX - MINNTAL
 Source #7 Waste Gas Stack
 Method 5-6 Filter holder: 55

Date 1/25/90 Test 1 Run 3
 No. of traverse points 24
 Filter type: glass fiber

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac) ☒
 Posttest: 0 cfm at 8 in. Hg. (vac) ☒

Particulate Catch Data:

No.s of filters used: 1839 Recovery solvent(s) acetone
☒ acetone
☐ other(s) _____
 No. of probe wash bottles: 1
 Sample recovered by: DOH

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1		200	
Impinger No. 2	248		48
Impinger No. 3			
Condenser			
Desiccant	1368	1360	8
Total			56

Integrated Gas Sampling Data:

Bag Pump No. 38 Box No. 12 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 0 cc/min at 15 in. Hg.
 Time start: 13⁰⁸ (HRS) Time end: 14⁰⁶ (HRS)
 Sampling rate: 400 cc/min Operator: DOH
 S/N of O₂ Analyzer used to monitor train outlet: 3

CF-023

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job U.S. XSource #7 Waste Recovery StackDate 1/25/90 Run 3Operator W.A. 2C.17Meter Box No. 3Gas meter conf. 8902Pitot No. 121-6Bar. Press. 29.50 inHgNozzle No. 8-4CP 84

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (inH ₂ O)	Drifts Meter (inH ₂ O)	Des. Vol. (cf)	VAC. inHg	Temperatures (°F)					Oxygen (xv/v)	
							Stack	Probe	Down	Impg.	Gas/In		Gas/Out
A	13.0	818.30											
6	2.5	819.82	.34	1.11	9.80	4	102				85	85	17.0
5	5	821.32	.34	1.11	1.31	4	102	254	259	50	86	84	16.8
4	7.5	822.87	.36	1.18	2.86	4	102				86	83	16.7
3	10	824.34	.35	1.14	4.38	4	102				85	82	16.7
2	12.5	825.86	.33	1.08	5.86	4	102				87	84	16.6
1	15	827.37	.32	1.05	7.33	4	102				89	85	16.5
B	17.5	828.88	.35	1.15	8.86	4	103				89	85	16.5
5	20	830.43	.36	1.18	0.41	4	103				91	87	16.6
4	22.5	831.97	.34	1.12	1.93	4	103	253	266	44	91	87	16.5
3	25	833.47	.32	1.05	3.40	4	103				91	87	16.6
2	27.5	834.97	.35	1.15	4.93	4	103				90	86	16.4
1	30	836.61	.39	1.28	6.55	5	103				90	86	16.3
C	32.5	838.19	.36	1.18	8.11	4	103				91	87	16.7
5	35	839.84	.41	1.35	9.77	4	103				91	86	16.7
4	37.5	841.50	.44	1.45	1.49	4.5	103				92	88	16.4
3	40	843.34	.51	1.68	3.35	5	103	257	258	41	92	88	16.6
2	42.5	845.20	.53	1.75	5.24	5	103				92	88	16.5
1	45	847.04	.48	1.58	7.05	5	103				91	87	16.8
D	47.5	848.66	.36	1.18	8.61	4	103				91	88	16.9
5	50	850.22	.40	1.32	0.25	4	103				93	90	16.7
4	52.5	851.91	.42	1.39	1.94	4.3	103				93	90	16.3
3	55	853.71	.50	1.65	3.78	5	103	256	257	43	94	90	16.4
2	57.5	855.63	.52	1.72	5.67	5	103				93	89	16.6
1	60	857.36	.44	1.45	7.39	4.5	103				92	88	16.9
V ₀ = 39.26													
V ₀ = 60													

APPENDIX D

LABORATORY DATA SHEETS

Interpoll Laboratories
(612) 786-6020

Chain of Custody
Sample Deposition Sheet

Job U.S. X Source #7 Waste Recovery Stack
 Team Leader [Signature] Test Site Stack
 Date Submitted 1/25/90 Date of Test 1/25/90
 Test No. 1 No. of Runs Completed 3

No. of Samples	Type of Sample	Analysis Required	Comments
43	Probe Wash: ☒ Acetone ☐ D.I. Water	☒ As per EPA M-5 ☐ Other _____	1 Blank Sulfate Analysis
4	Filter: ☒ 4" G.F. ☐ S.S. Thimble ☐ 2.5" G.F. ☐ 47 mm G.F.	☒ As per EPA M-5 ☐ As per EPA M-17 ☐ Other _____	See proposal 1 or Perry
4	Impinger Catch: ☐ D.I. Water ☒ 3% H ₂ O ₂ ☐ 4M5 Hg Only ☐ 4M5 Metals ☐ 1.0 N NaOH ☐ Other _____	☐ MN Protocol ☐ WI Protocol ☒ EPA M-6 or 8 ☐ Acid Gases ☐ Formaldehyde ☐ Metals ☐ Other _____	
3	Integrated Gas sample	☒ As per EPA M-3 ☐ As per EPA M-10 ☐ Other _____	
	Oxides of Nitrogen (NO _x)	☐ As per EPA M-7A ☐ Other _____	Date _____ Time (HRS) _____
	☐ Fuel Sample ☐ Aggregate	☐ Attached fuel Form #S-0163RRR	
	Particle Size	☐ X-Ray Sedigraph ☐ Bahco Method ☐ Other _____	
	Audit Samples ☐ Sulfur Dioxide ☐ Oxides of Nit. ☐ Other _____	☐ As per EPA M-6 ☐ As per EPA M-7A ☐ Other _____	

Source Information

- 1) Type of Source: ☐ Boiler ☐ Asphalt Plant ☐ Incinerator ☐ Dryer
☒ Other _____
- 2) Fuel: ☒ Coal ☐ Wood ☐ Gas ☐ Oil ☐ RDF ☐ Other _____
- 3) Is sample combustible? ☒ No ☐ Yes
- 4) Does sample need special handling? ☒ No ☐ Yes If yes, explain _____

EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job USX Source #7 Waste Recovery
Team Leader DVT Test Site Stack
Date Submitted 1-26-90 Date of Test 1-25-90
Test No. 1 No. of Runs Completed 3
Date of Analysis 1-26-90 Technician RE

Test/ Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
1/1	8948-07 □ B □ F	1	0.00	3.60	20.70	3.60	17.10	1.055
		2	0.00	3.60	20.70	3.60	17.10	1.055
		Avg				3.60	17.10	
1/2	8948-11 □ B □ F	1	0.00	3.70	20.70	3.70	17.00	1.054
		2	0.00	3.70	20.70	3.70	17.00	1.054
		Avg				3.70	17.00	
1/3	8948-15 □ B □ F	1	0.00	4.00	20.80	4.00	16.80	1.025
		2	0.00	4.00	20.80	4.00	16.80	1.025
		Avg				4.00	16.80	
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						

- ☒ Ambient Air QA Check
☒ Orsat Analyzer System Leak Check
☐ F₀ Within EPA M-3 Guidelines
for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

F=Flask (250 cc all glass)
B=Tedlar Bag (5-layer)

EPA Method 3 Guidelines	
Fuel Type	F ₀ Range
Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.596
Butane	1.405-1.553
Wood/Wood Bark	1.000-1.100

Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job USX Source #7 Waste Recovery
 Team Leader DVH Test Site Stack
 Date Submitted 1-26-90 Date of Test 1-25-90
 Test No. 1 No. of Runs Completed 3
 Date of Analysis 1-26-90 Technician RE
 Transport Leakage ☒ None ☐ ml Solvent acetone

0	Test <u>1</u> Run <u>0</u>	Dish No. <u>100</u>	
	Field Blank	Dish Tare Wt. <u>45.9678</u>	g
	Log Number <u>8948-01</u>	Dish+Sample Wt. <u>45.9680</u>	g
	Vol. of Solvent <u>100</u> ml	Sample Wt. <u>0.0002</u>	g
	*Solvent Residue <u>2.0</u> ug/ml		
1	Test <u>1</u> Run <u>1</u>	Dish No. <u>101</u>	
	Vol. of Solvent <u>120</u> ml	Dish Tare Wt. <u>44.7949</u>	g
	Log Number <u>8948-04</u>	Dish+Sample Wt. <u>44.8210</u>	g
	Comments <u> </u>	Sample Wt. <u>0.0261</u>	g
2	Test <u>1</u> Run <u>2</u>	Dish No. <u>102</u>	
	Vol. of Solvent <u>90</u> ml	Dish Tare Wt. <u>44.3236</u>	g
	Log Number <u>8948-08</u>	Dish+Sample Wt. <u>44.3340</u>	g
	Comments <u> </u>	Sample Wt. <u>0.0104</u>	g
3	Test <u>1</u> Run <u>3</u>	Dish No. <u>105</u>	
	Vol. of Solvent <u>95</u> ml	Dish Tare Wt. <u>47.8621</u>	g
	Log Number <u>8948-12</u>	Dish+Sample Wt. <u>47.8772</u>	g
	Comments <u> </u>	Sample Wt. <u>0.0151</u>	g
4	Test <u> </u> Run <u> </u>	Dish No. <u> </u>	
	Vol. of Solvent <u> </u> ml	Dish Tare Wt. <u> </u>	g
	Log Number <u> </u>	Dish+Sample Wt. <u> </u>	g
	Comments <u> </u>	Sample Wt. <u> </u>	g
5	Test <u> </u> Run <u> </u>	Dish No. <u> </u>	
	Vol. of Solvent <u> </u> ml	Dish Tare Wt. <u> </u>	g
	Log Number <u> </u>	Dish+Sample Wt. <u> </u>	g
	Comments <u> </u>	Sample Wt. <u> </u>	g

*Solvent Residue 2.0 ug/ml = [(Sample Wt. g) (10⁶)] / Vol. of Sol. ml
 EPA-M5 Acetone Residue Blank Spec. { 7.8 ug/ml

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	<u>0.0259</u>	<u>0.0102</u> ^{D-3}	<u>0.0149</u>		
--	---------------	------------------------------	---------------	--	--

LSC-01YR

Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job USX Source #7 Waste Recovery
Team Leader DVH Test Site Stack
Date Submitted 1-26-90 Date of Test 1-25-90
Test No. 1 No. of Runs Completed 3
Date of Analysis 1-26-90 Technician RE

0	Test <u>1</u> Run <u>0</u> Field Blank Log Number <u>8948-02</u> Comments _____	Filter No. <u>1804</u> Filter Type <u>4" GF</u> Filter Tare Wt. <u>.9401</u> g Filter+Sample Wt. <u>.9402</u> g Sample Wt. <u>.0001</u> g
1	Test <u>1</u> Run <u>1</u> Log Number <u>8948-05</u> Comments _____	Filter No. <u>1802</u> Filter Type <u>4" GF</u> Filter Tare Wt. <u>.9452</u> g Filter+Sample Wt. <u>.9824</u> g Sample Wt. <u>0.0372</u> g
2	Test <u>1</u> Run <u>2</u> Log Number <u>8948-09</u> Comments _____	Filter No. <u>1838</u> Filter Type <u>4" GF</u> Filter Tare Wt. <u>.9565</u> g Filter+Sample Wt. <u>.9841</u> g Sample Wt. <u>0.0276</u> g
3	Test <u>1</u> Run <u>3</u> Log Number <u>8948-13</u> Comments _____	Filter No. <u>1839</u> Filter Type <u>4" GF</u> Filter Tare Wt. <u>.9584</u> g Filter+Sample Wt. <u>.9866</u> g Sample Wt. <u>0.0282</u> g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.0372	0.0276	0.0282		

Field Blk.	Run 1	Run 2	Run 3	Run 4	Run 5
	0.0631	0.0378	0.0431		

EPA Method 6 Sulfur Dioxide
Titration Data Sheet

Job USX Source #7 Waste Recovery
Team Leader OVH Test Site JTECK
Date Submitted 1-26-90 Date of Test 1-25-90
Test No. 1 No. of Runs Completed 3
Date of Analysis 1-29-90 Technician RL

Test/Run	Sample Log Number	pH of Original Sample *	Final Vol. (V _{vol})	Dilution Factor (DF)	Aliquot Titrated (V _a)	No. of An.	Start Vol. Buret (ml)	Final Vol. Buret (ml)	Volume of Tit. (V _t) (ml)
Field Blank 1/0	8948-03	☒ pH < 3.5	☒ 500 ml	☒ 1 DF	☒ 1 ml	1	3.85	4.00	.15
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2	4.00	4.15	.15
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			.15 v _t
1/1	8948-06	☒ pH < 3.5	☒ 500 ml	☒ 1 DF	☒ 1 ml	1	4.20	7.50	3.30
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2	7.50	10.60	3.31
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			3.20
1/2	8948-10	☒ pH < 3.5	☒ 500 ml	☒ 1 DF	☒ 1 ml	1	10.60	13.30	2.70
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2	13.30	15.90	2.60
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			2.65
1/3	8948-14	☒ pH < 3.5	☒ 500 ml	☒ 1 DF	☒ 1 ml	1	16.60	18.95	2.95
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2	19.00	21.75	2.75
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			2.85
		☐ pH < 3.5	☐ 500 ml	☐ 1 DF	☐ 1 ml	1			
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2			
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			
		☐ pH < 3.5	☐ 500 ml	☐ 1 DF	☐ 1 ml	1			
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2			
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			
		☐ pH < 3.5	☐ 500 ml	☐ 1 DF	☐ 1 ml	1			
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2			
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			
		☐ pH < 3.5	☐ 500 ml	☐ 1 DF	☐ 1 ml	1			
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2			
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			
		☐ pH < 3.5	☐ 500 ml	☐ 1 DF	☐ 1 ml	1			
		☐ pH _____	☐ 250 ml	☐ 10 DF	☐ 5 ml	2			
			☐ 100 ml	☐ 25 DF	☐ 10 ml				
			☐ _____ ml	☐ 50 DF	☐ 20 ml	Avg			

Normality of Titrant (N): 0.003 N

Vol. Titrant for Field blank (V_b): 0.15 ml
Vol. Titrant for Method Blank: 0.15 ml

☐ Ion Exchange
☐ EPA Audit(s)
Audit No. _____
Audit No. _____

* If pH > 3.5 Adjust with conc. perchloric acid to pH ~ 2.0

APPENDIX E

RESULTS OF PARTICULATE CATCH SULFATE ANALYSES

Interpoll Laboratories, Inc.
(612) 786-6020

Ion Chromatography Laboratory

DIONEX MODEL 40001 WITH ANION MICRO MEMBRANE SUPPRESSION

Analyst: T.D.J.

Date of Analysis: 2-19-90

Job: A.S. X.

Source: No-7 Waste Recovery Site Site: Stack

Chromatography Conditions

Column	Flow Rate	Eluent	Flow Rate	Suppressor Acid
AS3	ml/min	2.4 mM Na ₂ CO ₃ & 3.0 mM NaHCO ₃	10 ml/min	12.5 mM Sulfuric Acid
X AS4A	2.0 ml/min	1.8 mM Na ₂ CO ₃ & 1.7 mM NaHCO ₃	ml/min	
AS5	ml/min	100 mM NaOH	X	Isocratic
	ml/min			Gradient (List program below)

Gradient Program	Time (Min.)									
Eluent	0.0									
% A										
% B										

Results of Sulfate Determination

Sample Name	Interpoll Log Number	Tot. Sample Volume (ml)	Dilution	Solution Conc. (ug/ml)	Total ug Sulfate	meq of Sulfate
T ₁ R ₀	8948-16	100	1	0.507	50.7	0.00106
T ₁ R ₁	-17	100	1	404	4.04 x 10 ⁴	0.842
T ₁ R ₂	-18	100	1	161	1.61 x 10 ⁴	0.335
T ₁ R ₃	-19	100	1	201	2.01 x 10 ⁴	0.419

Field Blank

Total ug = (Sample Vol.) x (Dilution) x (Solution Conc.)
meq = Total ug / 48000

LSC-08RR

APPENDIX F

PROCESS DATA

**Minntac Agglomerator Operating Data Summary
Interpoll Testing - January 25, 1990**

Run	Time	Fuel Rates*		Solid rates**		Moisture	Scrubber
		Gas Std. MCF/hr	Coal lbs./hr	Feed rate Green Ball LTPH	Bentonite Pounds/hr	Green Ball %	GPM
1	0955-1100	107	11,638	624 557	7678	9.1	2900
2	1132-1238	106	11,975	634 566	7692	9.2	2900
3	1253-1359	108	12,100	642 573	7800	9.2	2900

* Rates are based on hourly log readings. All gas used was used in the Preheat burners. The kiln burners were firing 100% coal/coke blend.

** The green ball feed rates are close to the highest ever achieved on a Step 3 line.

APPENDIX G

PROCEDURES


Particulate Loadings and Emission Rates

The particulate emission rates were determined per EPA Methods 1-5, CFR title 40, Part 60, Appendix A (revised July 1, 1988). In this procedure, a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass-lined sampling probe equipped with a Type S pitot and a thermocouple. The probe is attached to a sampling module which houses the all-glass in line filter holder in a temperature controlled oven. In addition, the sampling module also houses the impinger case and a Drierite drying column. The sampling module is connected by means of an umbilical cord to the control module which houses the dry test gasmeter, the calibrated orifice, a leakless pump, two inclined manometers, and all controls required for operating the sampling train.

Particulate samples were collected as follows: The sample gas was drawn in through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter. The particulates were removed at this point and collected on the filter. The gases then passed through an ice-cooled impinger train and a desiccant-packed drying column which quantitatively absorb all moisture from the sample gas stream after which the sample gas passes through the pump and the dry test gasmeter which integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gasmeter provides instantaneous flow rate data.

A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each site such that an isokinetic sampling condition prevails. Nomographs are used to aid in the rapid determination of the sampling rate.



Particulate sampling train.

Sulfur Dioxide Emissions

The sulfur dioxide concentrations were determined per Method 6, CFR Title 40, Part 60, Appendix A (Revised July 1, 1987). In the procedure employed, the back half of the Method 5 sampling train was used to collect SO₂ samples during the particulate determinations. Each of the first two impingers was filled with 100 cc of freshly prepared 3% hydrogen peroxide. The samples were quantitatively recovered in the field and returned to the laboratory for sulfate analysis by a barium-thorin titration method.

APPENDIX H

CALCULATION EQUATIONS

CALCULATION EQUATIONS

METHOD 2

$$\bar{V}_s = 85.48 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60(1 - B_{ws}) \bar{V}_s A \left(\frac{528}{T_{s(avg)}}\right) \left(\frac{P_s}{29.92}\right)$$

$$Q_a = 60 \bar{V}_s A$$

$$\dot{m}_g = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} 0.0003641 P_s (T_{db} - T_{wb}))/vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb})/P_s$$

$$= \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

CALCULATION EQUATIONS

METHOD 3

$$\%EA = \frac{100(\%O_2 - .5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (1 - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

CALCULATION EQUATIONS

METHOD 5

$$V_{m(std)} = 17.65 V_m \gamma \left(\frac{P_{bar} + \overline{\Delta H}/13.6}{T_{m(avg)}} \right)$$

$$V_{w(std)} = 0.0472 V_{Is}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$I = 0.0944 \left(\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (1 - B_{ws})} \right)$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_a = \frac{272.3 M_p P_s}{T_{s(avg)} (V_{w(std)} + V_{m(std)})}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_{s,d}$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{0 A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

SYMBOLS

A	= Cross sectional area of stack, SQ. FT.
A _n	= Cross sectional area of nozzle, SQ. FT.
B _{ws}	= Water vapor in gas stream, proportion by volume
C _p	= Pitot tube coefficient, dimensionless
C _a	= Concentration of particulate matter in stack gas, wet basis, GR/ACF
C _s	= Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	= Excess air, percent by volume
Y	= Dry test meter correction factor, dimensionless
G _d	= Specific gravity (relative to air), dimensionless
I	= Isokinetic variation, percent by volume
M _d	= Molecular weight of stack gas, dry basis, g/g - mole.
$\dot{m}_g$	= Mass flow of wet flue gas, LB/HR
$\dot{m}_p$	= Particulate mass flow, LB/HR
M _s	= Molecular weight of stack gas, wet basis, g/g, mole.
M _p	= Total amount of particulate matter collected, g
P _{bar}	= Atmospheric pressure, IN. HG. (uncompensated)
P _g	= Stack static gas pressure, IN. WC.

P_s	= Absolute pressure of stack gas, IN.HG.
P_{std}	= Standard absolute pressure, 29.92 IN. HG.
A_a	= Actual volumetric stack gas flow rate, ACFM
$Q_{s,d}$	= Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
RH	= Relative humidity, %
T_{db}	= Dry bulb temperature of stack gas, °F
T_{wb}	= Wet bulb temperature of stack gas, °F
$T_m(avg)$	= Absolute average dry gas meter temperature, °R
$T_s(avg)$	= Absolute average stack temperature, °F
T_{std}	= Standard absolute temperature, 528 °F (68 °F)
θ	= Total sampling time, min.
V_{lc}	= Total volume of liquid collected in impingers and silica gel, ml
V_m	= Volume of gas sample as measured by dry gas meter, CF
$V_m(std)$	= Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
$V_w(std)$	= Volume of water vapor in the gas sample corrected to standard conditions, SCF
$\bar{V}_s$	= Average actual stack gas velocity, FT/SEC
v_{ptdb}	= Vapor pressure at T_{db} , IN. HG.

- $v_{p_{twb}}$ = Vapor pressure at T_{wb} , IN. HG
- $\overline{\Delta H}$ = Average pressure differential across the orifice meter, IN. WC.
- ΔP = Velocity pressure of stack gas, IN. WC.
- γ = Dry test meter correction coefficient, dimensionless
- ρ = Actual gas density, LB/ACF

CALCULATION EQUATIONS

METHOD 6

$$V_{std} = 17.64 \frac{V_m P_{by}}{T_m} \quad (\text{MIDGET IMPINGER VERSION})$$

$$V_{std} = \frac{17.64 V_m (P_b + \frac{\overline{\Delta H}}{13.6}) \gamma}{T_m} \quad (\text{LARGE IMPINGER VERSION})$$

$$MEQ = (V_t - V_{tb}) N \left(\frac{V_{soln}}{V_a} \right) DF$$

$$C_s = \frac{7.06 \times 10^{-5} MEQ}{V_{std}}$$

$$E = \frac{20.90 C_s F_d}{20.90 - \overline{B}'_{O_2}} = \frac{F C_s}{\overline{B}'_{CO_2}}$$

$$C_s \text{ (MG/DSCM)} = 1.60186 \times 10^7 C_s$$

$$C_s \text{ (GR/DSCF)} = 7000 C_s$$

$$C_s \text{ (ppm, dry)} = 6.02119 \times 10^6 C_s$$

$$C_s \text{ (ppm, wet)} = 6.02119 \times 10^6 C_s \left(1 - \frac{MC}{100} \right)$$

SYMBOLS

$\bar{B}'_{O_2}$	=	Average oxygen content in flue gas, % v/v, dry
$\bar{B}'_{CO_2}$	=	Average carbon dioxide content in flue gas, % v/v, dry
C_s	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, LB/DSCF
C_s (GR/DSCF)	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, GR/DSCF
C_s (MG/DSCM)	=	Concentration of sulfur dioxide in flue gas, dry basis, corrected to standard conditions, MG/DSCM
DF	=	Dilution Factor
E	=	Emission factor, LB of $SO_2/10^6$ BTU
F_d	=	Dry oxygen F-Factor for given fuel type, DSCF/ 10^6 BTU
F_c	=	Carbon dioxide F-Factor for given fuel type, DSCF/ 10^6 BTU
ΔH	=	Average pressure drop across calibrated orifice, IN. W.C.
γ	=	Dry test meter correction factor, dimensionless
MC	=	Moisture content of flue gas, % v/v
MEQ	=	Total milliequivalents of SO_2 in gas sample
N	=	Normality of barium perchlorate titrant
P_b	=	Barometric pressure at the dry gas meter, IN. HG.

C_s (ppm-dry) = Concentration of sulfur dioxide in flue gas, dry basis, (v/v), ppm

C_s (ppm-wet) = Concentration of sulfur dioxide in flue gas, wet basis, (v/v), ppm

T_m = Absolute average dry gas meter temperature, $^{\circ}R$

V_a = Volume of sample aliquot titrated, cc

V_m = Dry gas volume as measured by the dry gas meter, DCF

V_{std} = Dry gas volume as measured by the dry gas meter, corrected to standard conditions (at 68 $^{\circ}F$ and 1 atmosphere), DSCF

V_{soln} = Total volume of the solution in which the sulfur dioxide sample is contained, cc

V_t = Volume of barium perchlorate titrant used for the sample, cc (average of replicate titrations)

V_{tb} = Volume of barium perchlorate titrant used for the blank, cc

100

Source category:

Taconite ore processing

Date: 10/24/96

Plant name :

USS Minnesota

Location: Mountain Iron, MN

Test date :

January 25, 1990

Ref. No.: 26

Process :

Grate kiln

Basis for process rate : production

Source	Type of control	Pollutant	Run No.	Emission rate, lb/hr	Process rate, ton/hr	Emission factor		Volumetric flow rate, DSCFM	Concen %
						kg/Mg	lb/ton		
Waste gas (coke/coal fired) grate/kiln	Wet scrubber	filt. PM	1	57.66	468.00	0.062	0.12		
		filt. PM	2	52.97	475.50	0.056	0.11		
		filt. PM	3	60.06	481.50	0.062	0.12		
		AVERAGE				0.060	0.12	RATING:	
		SO2	1	22.39	468.00	0.024	0.048		
		SO2	2	28.14	475.50	0.030	0.059		
		SO2	3	30.22	481.50	0.031	0.063		
		AVERAGE				0.028	0.057	RATING:	
		CO2	1	91425	468.00	98	195	369,986	3.60
		CO2	2	95527	475.50	100	201	376,138	3.70
		CO2	3	103328	481.50	107	215	376,339	4.00
		AVERAGE				102	204	RATING:	

Notes: Furnace production rates estimated as 75% of feed rates, based on information provided by MPCA (Reference 53)

