

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section 11.23
Reference 37
Report Sect. 4
Reference 47

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (612) 786-6020
FAX: (612) 786-7854

RESULTS OF THE APRIL 28, 1993
STATE AIR EMISSION COMPLIANCE
TESTING ON THE NO. 4 AND 5
PELLETIZERS AT THE US STEEL PLANT IN
MOUNTAIN IRON, MINNESOTA

Submitted to:

U.S. STEEL-MINNTAC
P.O. Box 417
Mountain Iron, Minnesota 55768

Attention:

Nick Brascugli

Reviewed by:



Daniel J. Despen
Manager
Stationary Source Testing Department

Report Number 3-8678
June 10, 1993
KE/kce





TABLE OF CONTENTS

ABBREVIATIONS	iii
1 INTRODUCTION	1
2 SUMMARY AND DISCUSSION	3
3 RESULTS	8
3.1 Results of Orsat and Moisture Analyses	9
3.2 Results of Particulate Loading Determinations	12
3.3 Results of Opacity Observations	15

APPENDICES:


- A - Sampling Equipment Calibration Data
- B - Location of Test Ports
- C - Field Data Sheets
- D - Interpoll Laboratories Analytical Data
- E - MPCA Exhibit C
- F - Process Data
- G - Procedures
- H - Calculation Equations
- I - MPCA Test Plan



ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	diameter
FP	finished product for plant
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard cubic meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
LTPD	long tons per day
MW	megawatt
mg/Nm ³	milligrams per dry standard cubic meter
ug/Nm ³	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
ohm-cm	ohm-centimeter
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight
<	≤ (when following a number)

Standard conditions are defined as 68°F (20°C) and 29.92 IN. of mercury pressure.




1 INTRODUCTION

On April 28, 1993, Interpoll Laboratories personnel conducted particulate and visible emission compliance tests on the No. 4 and 5 Pelletizers (Emission Points Nos. 8.21 and 8.22) at the US Steel Minntac Plant in Mountain Iron, Minnesota. On-site testing was performed by D. Brennan, S. Bainville and J. Bergstrom. Coordination between testing activities and plant operation was provided by Ray Potts of US Steel. The tests were not witnessed by a member of the MPCA.

The Step II Pelletizers 4 and 5 consist of traveling grates followed by rotary kilns. The pellets are heated in the kiln where they are hardened. After leaving the kiln, the pellets are air-cooled and loaded into railcars for shipment. During the tests the No. 4 Pelletizer was co-fired with natural gas and fuel oil and the No. 5 Pelletizer was fired with natural gas. Particulate emissions from the No. 4 and 5 Pelletizers are controlled by individual multiple throat venturi type wet scrubbers.


Particulate determinations were performed in accordance with EPA Methods 1 - 5, CFR Title 40, Part 60, Appendix A (revised July 1, 1992). Previous data collected at the test sites was used to select of the appropriate nozzle diameter required for isokinetic sample withdrawal. An Interpoll Labs sampling train which meets or exceeds specifications in the above-cited reference was used to extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed as per Minnesota Rules Part 7005.0500.

Testing at each test location was conducted from four test ports oriented at 90 degrees on the respective stacks. The test ports in each case are located approximately 3 diameters downstream and approximately 4 diameters upstream of the nearest flow disturbance. A 24-point traverse was used to collect representative particulate samples. Each traverse



point was sampled 2.5 minutes to give a total sampling time of 60 minutes per run. Visible emissions determinations were performed by J. Bergstrom, an EPA-certified observer.

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.



2 SUMMARY AND DISCUSSION

The results of the particulate emission compliance tests are summarized in Tables 1 and 2. As will be noted, the particulate concentration averaged 0.0092 GR/DSCF for the No. 4 Pelletizer and 0.0097 GR/DSCF for the No. 5 Pelletizer (dry + organic wet catch). Opacity averaged 11.3% for the No. 4 Pelletizer and 11.4% for the No. 5 Pelletizer.

No difficulties were encountered in the field or in the laboratory evaluation of the samples. On the basis of these facts and a complete review of the data and results, it is our opinion that the concentrations and emission rates reported herein are accurate and closely reflect the actual values which existed at the time the test was performed.




Table 1a Summary of the Results of the April 28, 1993 Particulate Emission Compliance Test on the No. 4 Pelletizer (Source No. 8.21) at the US Steel Minntac Plant in Mountain Iron, Minnesota.

ITEM	Run 1	Run 2	Run 3
Date of test	04-27-93	04-27-93	04-27-93
Time runs were done (HRS)	1420/1525	1540/1645	1655/1758
Process rate (LTON/HR)	505	495	495
Volumetric flow actual (ACFM) standard (DSCFM)	564667 433690	626665 486968	612350 471755
Gas temperature (DEG-F)	120	118	120
Moisture content (%V/V)	10.06	9.35	9.71
Gas composition (%V/V, dry) carbon dioxide oxygen nitrogen	2.10 18.40 79.50	2.10 18.40 79.50	2.10 18.50 79.40
Isokinetic variation (%)	97.5	99.1	99.4
Particulate concentration actual (GR/ACF) standard (GR/DSCF)	.00650 .00847	.00916 .0118	.00568 .00738
Part. emission rate (LB/HR)	31.49	49.23	29.84

Note: Dry + Organic Wet Catch




Table 1b Summary of the Results of the April 28, 1993 Particulate Emission Compliance Test on the No. 4 Pelletizer (Source No. 8.21) at the US Steel Minntac Plant in Mountain Iron, Minnesota.

ITEM	Run 1	Run 2	Run 3
Date of test	04-27-93	04-27-93	04-27-93
Time runs were done (HRS)	1420/1525	1540/1645	1655/1758
Process rate (LTON/HR)	505	495	495
Volumetric flow actual (ACFM) standard (DSCFM)	564667 433690	626665 486968	612350 471755
Gas temperature (DEG-F)	120	118	120
Moisture content (%V/V)	10.06	9.35	9.71
Gas composition (%V/V.dry) carbon dioxide oxygen nitrogen	2.10 18.40 79.50	2.10 18.40 79.50	2.10 18.50 79.40
Isokinetic variation (%)	97.5	99.1	99.4
Particulate concentration actual (GR/ACF) standard (GR/DSCF)	.00644 .00839	.00897 .0115	.00549 .00712
Part. emission rate (LB/HR)	31.18	48.19	28.80

Note: Dry Catch Only




Table 2a Summary of the Results of the April 28, 1993 Particulate Emission Compliance Test on the No. 5 Pelletizer (Source No. 8.22) at the US Steel Minntac Plant in Mountain Iron, Minnesota.

ITEM	Run 1	Run 2	Run 3
Date of test	04-28-93	04-28-93	04-28-93
Time runs were done (HRS)	1820/1925	1935/2043	2045/2150
Process rate (LTON/HR)	488	462	476
Volumetric flow actual (ACFM)	571905	594540	580078
standard (DSCFM)	452410	463696	456712
Gas temperature (DEG-F)	114	117	115
Moisture content (%V/V)	8.29	9.10	8.49
Gas composition (%V/V.dry)			
carbon dioxide	2.10	2.20	2.00
oxygen	18.10	18.10	18.30
nitrogen	79.80	79.70	79.70
Isokinetic variation (%)	97.7	100.7	100.1
Particulate concentration actual (GR/ACF)	.00749	.00706	.00838
standard (GR/DSCF)	.00947	.00905	.0106
Part. emission rate (LB/HR)	36.72	35.97	41.67

Note: Dry + Organic Wet Catch





Table 2b Summary of the Results of the April 28, 1993 Particulate Emission Compliance Test on the No. 5 Pelletizer (Source No. 8.22) at the US Steel Minntac Plant in Mountain Iron, Minnesota.

ITEM	Run 1	Run 2	Run 3
Date of test	04-28-93	04-28-93	04-28-93
Time runs were done (HRS)	1820/1925	1935/2043	2045/2150
Process rate (LTON/HR)	488	462	476
Volumetric flow actual (ACFM) standard (DSCFM)	571905 452410	594540 463696	580078 456712
Gas temperature (DEG-F)	114	117	115
Moisture content (%V/V)	8.29	9.10	8.49
Gas composition (%V/V, dry) carbon dioxide oxygen nitrogen	2.10 18.10 79.80	2.20 18.10 79.70	2.00 18.30 79.70
Isokinetic variation (%)	97.7	100.7	100.1
Particulate concentration actual (GR/ACF) standard (GR/DSCF)	.00680 .00861	.00618 .00793	.00782 .00994
Part. emission rate (LB/HR)	33.37	31.52	38.91


Note: Dry Catch Only




3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition are presented first followed by the computer printouts of the particulate and opacity results. Preliminary measurements are given in the appendices.

The results have been calculated on a personal computer using programs written in Extended BASIC specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The particulate emission rates have been calculated using the product of the concentration times flow method.




3.1 Results of Orsat and Moisture Determinations



Test No. 4
 No. 4 Pelletizer Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)


Date of run	Run 1 04-27-93	Run 2 04-27-93	Run 3 04-27-93
Dry basis (orsat)			
carbon dioxide.....	2.10	2.10	2.10
oxygen.....	18.40	18.40	18.50
nitrogen.....	79.50	79.50	79.40
Wet basis (orsat)			
carbon dioxide.....	1.89	1.90	1.90
oxygen.....	16.55	16.68	16.70
nitrogen.....	71.51	72.07	71.69
water vapor.....	10.06	9.35	9.71
Dry molecular weight.....	29.07	29.07	29.08
Wet molecular weight.....	27.96	28.04	28.00
Specific gravity.....	0.966	0.968	0.967
Water mass flow.....(LB/HR)	136003	140902	142283
FO	1.190	1.190	1.143




Test No. 5
 No. 5 Pelletizer Stack

Results of Orsat & Moisture Analyses-----Methods 3 & 4(%v/v)

Date of run	Run 1 04-28-93	Run 2 04-28-93	Run 3 04-28-93
Dry basis (orsat)			
carbon dioxide.....	2.10	2.20	2.00
oxygen.....	18.10	18.10	18.30
nitrogen.....	79.80	79.70	79.70
Wet basis (orsat)			
carbon dioxide.....	1.93	2.00	1.83
oxygen.....	16.60	16.45	16.75
nitrogen.....	73.18	72.45	72.94
water vapor.....	8.29	9.10	8.49
Dry molecular weight.....	29.06	29.08	29.05
Wet molecular weight.....	28.14	28.07	28.11
Specific gravity.....	0.972	0.970	0.971
Water mass flow.....(LB/HR)	114761	130185	118808
FO	1.333	1.273	1.300




3.2 Results of Particulate Loading Determinations



Test No. 4
No. 4 Pelletizer Stack

Results of Particulate Loading Determinations-----Method 5


	Run 1	Run 2	Run 3
Date of run	04-27-93	04-27-93	04-27-93
Time run start/end.....(HRS)	1420/1525	1540/1645	1655/1758
Static pressure.....(IN.WC)	-0.80	-0.80	-0.80
Cross sectional area (SQ.FT)	153.94	153.94	153.94
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	111.0	74.0	70.0
desiccant.....(GRAMS)	19.0	7.0	12.0
total.....(GRAMS)	130.0	81.0	82.0
Total particulate material..			
.....collected(grams)	0.0301	0.0283	0.0172
Gas meter coefficient.....	0.9920	0.9970	0.9970
Barometric pressure..(IN.HG)	28.12	28.12	28.12
Avg. orif.pres.drop..(IN.WC)	3.12	1.36	1.28
Avg. gas meter temp..(DEF-F)	97.1	89.2	89.5
Volume through gas meter....			
at meter conditions...(CF)	61.57	40.97	39.82
standard conditions.(DSCF)	54.83	37.02	35.96
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.247	.190	.190
Avg.stack gas temp ..(DEG-F)	120	118	120
Volumetric flow rate.....			
actual.....(ACFM)	564667	626665	612350
dry standard.....(DSCFM)	433690	486968	471755
Isokinetic variation.....(%)	97.5	99.1	99.4
Particulate concentration...			
actual.....(GR/ACF)	0.00650	0.00916	0.00568
dry standard.....(GR/DSCF)	0.00847	0.01179	0.00738
Particle mass rate...(LB/HR)	31.490	49.229	29.845




Test No. 5
 No. 5 Pelletizer Stack

Results of Particulate Loading Determinations-----Method 5

	Run 1 04-28-93	Run 2 04-28-93	Run 3 04-28-93
Date of run			
Time run start/end.....(HRS)	1820/1925	1935/2043	2045/2150
Static pressure.....(IN.WC)	-0.88	-0.88	-0.88
Cross sectional area (SQ.FT)	153.94	153.94	153.94
Pitot tube coefficient.....	.840	.840	.840
Water in sample gas			
condenser.....(ML)	0.0	0.0	0.0
impingers.....(GRAMS)	55.0	68.0	60.0
desiccant.....(GRAMS)	10.0	8.0	9.0
total.....(GRAMS)	65.0	76.0	69.0
Total particulate material..			
.....collected(grams)	0.0208	0.0210	0.0242
Gas meter coefficient.....	0.9970	0.9970	0.9970
Barometric pressure..(IN.HG)	28.12	28.12	28.12
Avg. orif.pres.drop..(IN.WC)	1.22	1.26	1.19
Avg. gas meter temp..(DEF-F)	84.0	83.0	77.8
Volume through gas meter....			
at meter conditions...(CF)	37.16	39.18	38.03
standard conditions.(DSCF)	33.89	35.80	35.08
Total sampling time....(MIN)	60.00	60.00	60.00
Nozzle diameter.....(IN)	.190	.190	.190
Avg.stack gas temp ..(DEG-F)	114	117	115
Volumetric flow rate.....			
actual.....(ACFM)	571905	594540	580078
dry standard.....(DSCFM)	452410	463696	456712
Isokinetic variation.....(%)	97.7	100.7	100.1
Particulate concentration...			
actual.....(GR/ACF)	0.00749	0.00706	0.00838
dry standard.....(GR/DSCF)	0.00947	0.00905	0.01064
Particle mass rate...(LB/HR)	36.723	35.972	41.669



3.3 Results of Opacity Observations




Test No. 3
No. 4 Pelletizer

Results of Opacity Observations ----- EPA Method 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	0.00
5	0.0223	7.92
10	0.0458	58.33
15	0.0706	33.33
20	0.0969	0.42
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac11.31	Avg OD 0.0524	Time average

Observer: J. Bergstrom
Cert. Date: 04-01-93
Date of Observation: 04-28-93
Time of Observation: 1425-1525




Test No. 4
No. 5 Pelletizer

Results of Opacity Observations ----- EPA Method 9


PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0.0000	0.00
5	0.0223	0.00
10	0.0458	71.67
15	0.0706	28.33
20	0.0969	0.00
25	0.1249	0.00
30	0.1549	0.00
35	0.1871	0.00
40	0.2219	0.00
45	0.2596	0.00
50	0.3010	0.00
55	0.3468	0.00
60	0.3979	0.00
65	0.4559	0.00
70	0.5229	0.00
75	0.6021	0.00
80	0.6690	0.00
85	0.8239	0.00
90	1.0000	0.00
95	1.3010	0.00
99	2.0000	0.00
Avg Opac11.42	Avg OD 0.0528	Time average

Observer: J. Bergstrom
Cert. Date: 04-01-93
Date of Observation: 04-28-93
Time of Observation: 1820-1920



APPENDIX A

SAMPLING EQUIPMENT CALIBRATION DATA



P_s = Absolute pressure of stack gas, IN.HG.
 P_{std} = Standard absolute pressure, 29.92 IN. HG.
 A_a = Actual volumetric stack gas flow rate, ACFM
 $Q_{s,d}$ = Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
 RH = Relative humidity, %
 T_{db} = Dry bulb temperature of stack gas, °F
 T_{wb} = Wet bulb temperature of stack gas, °F
 $T_m(avg)$ = Absolute average dry gas meter temperature, °R
 $T_s(avg)$ = Absolute average stack temperature, °F
 T_{std} = Standard absolute temperature, 528 °F (68 °F)
 θ = Total sampling time, min.
 V_{lc} = Total volume of liquid collected in impingers and silica gel, ml
 V_m = Volume of gas sample as measured by dry gas meter, CF
 $V_m(std)$ = Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
 $V_w(std)$ = Volume of water vapor in the gas sample corrected to standard conditions, SCF
 $\bar{V}_s$ = Average actual stack gas velocity, FT/SEC
 $v_{p_{tdb}}$ = Vapor pressure at T_{db} , IN. HG.

v_{ptwb} = Vapor pressure at T_{wb} , IN. HG

$\overline{\Delta H}$ = Average pressure differential across the orifice meter, IN. WC.

ΔP = Velocity pressure of stack gas, IN. WC.

γ = Dry test meter correction coefficient, dimensionless

ρ = Actual gas density, LB/ACF

CALCULATION EQUATIONS

METHOD 3

$$\%EA = \frac{100(\%O_2 -) .5\% CO)}{0.264\% N_2 - \%O_2 + 0.5\% CO}$$

$$M_d = 0.44(\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$M_s = M_d (I - B_{ws}) + 0.18 B_{ws}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

CALCULATION EQUATIONS

METHOD 5

$$V_{m(std)} = 17.65 V_m \gamma \left(\frac{P_{bar} + \Delta H/13.6}{T_{m(avg)}} \right)$$

$$V_{w(std)} = 0.0472 V_{Is}$$

$$B_{ws} = \frac{V_{w(std)}}{V_{w(std)} + V_{m(std)}}$$

$$I = 0.0944 \left(\frac{T_{s(avg)} V_{m(std)}}{P_s V_s A_n \theta (1 - B_{ws})} \right)$$

$$C_s = \frac{15.43 M_p}{V_{m(std)}}$$

$$C_a = \frac{272.3 M_p P_s}{T_{s(avg)} (V_{w(std)} + V_{m(std)})}$$

$$(\dot{m}_p)_1 = 8.5714 \times 10^{-3} C_s Q_{s,d}$$

$$(\dot{m}_p)_2 = \frac{1.3228 \times 10^{-1} M_p A}{O A_n}$$

$$\dot{m}_p = \frac{(\dot{m}_p)_1 + (\dot{m}_p)_2}{2}$$

SYMBOLS

A	= Cross sectional area of stack, SQ. FT.
A _n	= Cross sectional area of nozzle, SQ. FT.
B _{ws}	= Water vapor in gas stream, proportion by volume
C _p	= Pitot tube coefficient, dimensionless
C _a	= Concentration of particulate matter in stack gas, wet basis, GR/ACF
C _s	= Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	= Excess air, percent by volume
γ	= Dry test meter correction factor, dimensionless
G _d	= Specific gravity (relative to air), dimensionless
I	= Isokinetic variation, percent by volume
M _d	= Molecular weight of stack gas, dry basis, g/g - mole.
$\dot{m}_g$	= Mass flow of wet flue gas, LB/HR
$\dot{m}_p$	= Particulate mass flow, LB/HR
M _s	= Molecular weight of stack gas, wet basis, g/g, mole.
M _p	= Total amount of particulate matter collected, g
P _{bar}	= Atmospheric pressure, IN. HG. (uncompensated)
P _g	= Stack static gas pressure, IN. WC.

P_s = Absolute pressure of stack gas, IN.HG.
 P_{std} = Standard absolute pressure, 29.92 IN. HG.
 A_a = Actual volumetric stack gas flow rate, ACFM
 $Q_{s,d}$ = Dry volumetric stack gas flow rate corrected to standard conditions, DSCFM
 RH = Relative humidity, %
 T_{db} = Dry bulb temperature of stack gas, °F
 T_{wb} = Wet bulb temperature of stack gas, °F
 $T_m(avg)$ = Absolute average dry gas meter temperature, °R
 $T_s(avg)$ = Absolute average stack temperature, °F
 T_{std} = Standard absolute temperature, 528 °F (68 °F)
 θ = Total sampling time, min.
 V_{lc} = Total volume of liquid collected in impingers and silica gel, ml
 V_m = Volume of gas sample as measured by dry gas meter, CF
 $V_m(std)$ = Volume of gas sample measured by the dry gas meter corrected to standard conditions, DSCF
 $V_w(std)$ = Volume of water vapor in the gas sample corrected to standard conditions, SCF
 $\bar{V}_s$ = Average actual stack gas velocity, FT/SEC
 $v_{p_{tdb}}$ = Vapor pressure at T_{db} , IN. HG.


v_{ptwb} = Vapor pressure at T_{wb} , IN. HG

$\overline{\Delta H}$ = Average pressure differential across the orifice meter, IN. WC.

ΔP = Velocity pressure of stack gas, IN. WC.

γ = Dry test meter correction coefficient, dimensionless

ρ = Actual gas density, LB/ACF



APPENDIX I

MPCA TEST PLAN

FILE COPY

RECEIVED

MAR 12 1993

Minnesota Pollution Control Agency
Division of Air Quality
Stack Testing Protocol

INTERPOLL LABORATORIES

Date: 3/9/93

Test Date: 3/30/93-4/1/93

The following is a summary of the testing requirements for the U.S. Steel facility in Mountain Iron, Minnesota.

I. Test Methods

- A. EPA Method 1 for the location of sampling ports and points. Location of the sampling ports must be approved before the test.

Check for cyclonic flow must be done whenever there is a cyclonic type of device directly upstream of the sampling location. Correction of cyclonic flow by straightening vanes must also be verified by checking the cyclonic flow before the test.

If the location does not meet the minimum requirements in Method 1, the testing firm must conduct the flow pattern evaluation and testing according to the alternative procedures in part 2.5 of EPA Method 1 (Three-dimensional directional probe).

- B. EPA Method 2 for velocity and volumetric flow rate. Three determinations: one measurement concurrently with each test run for pollutant.

- C. EPA Method 4 for the determination of moisture in the flue gases. Three determinations: one measurement concurrently with each test for pollutant.

- D. EPA Method 5 for the determination of total particulate matter (TSP). Three one hour determinations are required for each emission point and condensable compounds will be analyzed as per Minn. Rules 7005.0500. The results will be reported as (i) dry catch only and (ii) dry catch plus wet catch for all emission points. The sampling time for each run must be at least 60 minutes and the sampling rate must be at least 0.9 DSCM/Hr (0.53 DSCF/min).

- E. EPA Method 201 or 201A for the determination of particulate matter of less than 10 microns diameter (PM10) Three determinations of at least one hour are required for each emission point.

- F. EPA Method 202 for the determination of condensable particulate matter, to be performed in conjunction with Method 201 or 201A.

- G. EPA Method 9 for the determination of opacity, as amended in Minn. Rules part 7005.1860. One hour of opacity readings is required, to be performed concurrently with one test run for total particulate matter.

Note: The final version of the test plan and protocol shall be included in the test report.

Post-It™ brand fax transmittal memo 7671		# of pages *	
To	Kathy Eickstedt	From	H. Brancagli
Co.	Interpoll	Co.	USX
Dept.		Phone 1	
Fax 1	612-706-7854	Fax 2	

TEST PLAN FOR USS Minntac

I. GENERAL INFORMATION

A. Permittee: USS

B. AQD File No.: 26A

**C. Permittee contact person and telephone number: Nick Brascugli
218-749-7485**

Permittee's mailing address: P.O. Box 417, Mountain Iron, MN 55768

D. MPCA permitting engineer: Patrick O'Neill

E. Drawings showing location of sampling ports is included.

**F. Testing schedules and testing firm: March 30 - April 1, Interpoll Labs
Kathy Rickstedt**

II. PROCESS UNIT INFORMATION

A. STEP I&II Course Crusher Scrubbers, Emission Point No. 4.3

Pollutant: Total Suspended Particulate matter, PM-10 and Opacity

Steady State Process: Yes

**Applicable regulations: 40 CFR 52.21
Minn. Rules Part 7005.0480 Subp.1.B.
Special Condition 2.2 of Air Emission Permit
No. 26A-92-I/O-2**

**Test Methods: EPA Methods 1,2,4,5,9
201 and 202 or 201A and 202
As specified in 40 CFR Part 60 Appendix A**

Reason for testing: Initial compliance

B. STEP I&II Course Crusher Scrubbers, Emission Point No. 4.4

Pollutant: Total Suspended Particulate matter, PM-10 and Opacity

Steady State Process: Yes

**Applicable regulations: 40 CFR 52.21
Minn. Rules Part 7005.0480 Subp.1.B.
Special Condition 2.2 of Air Emission Permit
No. 26A-92-I/O-2**

**Test Methods: EPA Methods 1,2,4,5,9
201 and 202 or 201A and 202
As specified in 40 CFR Part 60 Appendix A**

Reason for testing: Initial compliance

C. STEP III Course Crusher Scrubbers, Emission Point No. 4.7

Pollutant: Total Suspended Particulate matter, PM-10 and Opacity

Steady State Process: Yes

Applicable regulations: 40 CFR 52.21
Minn. Rules Part 7005.0480 Subp.1.B.
Special Condition 2.2 of Air Emission Permit
No. 26A-92-I/O-2

Test Methods: EPA Methods 1,2,4,5,9
201 and 202 or 201A and 202
As specified in 40 CFR Part 60 Appendix A

Reason for testing: Initial compliance

D. STEP ~~III~~ ^{II} Palletizer 4 Scrubbers, Emission Point No. 8.21

Pollutant: Total Suspended Particulate matter, PM-10 and Opacity

Steady State Process: Yes

Applicable regulations: 40 CFR 52.21
Minn. Rules Part 7005.0480 Subp.1.B.
Special Condition 2.2 of Air Emission Permit
No. 26A-92-I/O-2

Test Methods: EPA Methods 1,2,3,4,5,9
201 and 202 or 201A and 202
As specified in 40 CFR Part 60 Appendix A

Reason for testing: Initial compliance

E. STEP ~~III~~ ^{II} Palletizer 5 Scrubbers, Emission Point No. 8.22

Pollutant: Total Suspended Particulate matter, PM-10 and Opacity

Steady State Process: Yes

Applicable regulations: 40 CFR 52.21
Minn. Rules Part 7005.0480 Subp.1.B.
Special Condition 2.2 of Air Emission Permit
No. 26A-92-I/O-2

Test Methods: EPA Methods 1,2,3,4,5,9
201 and 202 or 201A and 202
As specified in 40 CFR Part 60 Appendix A

Reason for testing: Initial compliance

III. EMISSION POINT INFORMATION.

- A. Emission Points No. 4.3, 4.4, and 4.7 capture and exhaust emission from the course crushers

B. Emission Points No. 8.21 and 8.22 control emissions from two pelletizers

IV. TEST PLAN

A. Operating conditions during tests

1. All pollution control equipment must be operated as is done during normal operations. This includes pressure drop across the scrubbers and water flow rate.
2. Pelletizers 4 and 5 shall be operated within 10% of their design capacity.

B. Operating Data to Be Recorded during the Test

Operating conditions of each process/source tested and its associated pollution control equipment must be documented in the test report. No test report will be accepted without complete documentation of process conditions during the test. Documentation of operating conditions includes:

1. Raw material input and product output

- a. Number of coarse crushers that are and are not used during the test
- b. The amount of material crushed or the long tons of pellets produced in each of the pelletizing lines that are supplied by these crushers for each test run.
- c. For Emission Points No.s 8.21 and 8.22 the type of fuel used and the amount of fuel used during each test run shall be recorded. The amount of pellets shall also be recorded during each run.

2. Pollution control equipment

Wet Scrubbers - Pressure drop and scrubber water flow rate.

3. Description and date of last maintenance work done before the test.

4. Record keeping of operational parameters as measured throughout the entire test. For continuous recorders, please provide properly labelled copies of strip charts. For records of discrete data, please provide data taken at 15 minute intervals.

5. Calculations

6. Certification of the data by a responsible party.

7. Brief explanation of how the parameters are measured. Indicate if it is a routine measurement, or a special procedure followed for purposes of the test only.

Enclosed is a copy of "Exhibit C", which describes the general requirements for performance testing. Please review it, to make sure that all the requirements are documented in your test report. Some of these general requirements have already been specifically addressed in this letter as they apply to your particular case.

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job US STEEL MIN TAC

Date 4-26-93

Operator E. T. [Signature]

Module No. 3

Instructions: Operate the control module at a flow rate equal to $\dot{V}_{He}$ for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.17 in. Hg. $\tau =$.9940 $\dot{V}_{He}$ 1.77 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	(615.00)		
2.5	617.50	58	52
5.0	619.54	59	52
7.5	621.23	60	53
10	623.11	61	53
	$V_m = 7.57$	Avg(t_m) = 56.0 °F	

Calculate Y_{cn} as follows:

$$Y_{cn} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{cn} = \frac{1.786}{() ()} \left[\frac{(56) + 460}{(28.17)} \right]^{0.5} = 1.278$$

$$Y_{cn} = \underline{1.0239}$$

If Y_{cn} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

INTERPOLL LABORATORIES
EPA Method 5 Gas Metering System
Quality Control Check Data Sheet

Job U.S. STEEL / MINITAC
 Operator SCOTT BAINVILLE

Date 4-27-93
 Module No. 6

Instructions: Operate the control module at a flow rate equal to $\dot{V}_m$ for 10 minutes before attaching the umbilical. Record the following data:

Bar press 28.17 in. Hg. $\tau =$ 9970 $\dot{V}_m$ 1.81 in. W.C.

Time (min)	Volume (CF)	Meter Temp. (°F)	
		Inlet	Outlet
	(70.60)		
2.5	752.55	50	48
5.0	754.52	53	49
7.5	756.42	54	50
10	758.37	56	50
	$V_m = 7.77$	Avg(t_m) = 51.25°F	

Calculate Y_{on} as follows:

$$Y_{on} = \frac{1.786}{\tau V_m} \left[\frac{(t_m + 460)}{P_b} \right]^{0.5}$$

$$Y_{on} = \frac{1.786}{(.9970)(7.77)} \left[\frac{(51.25) + 460}{(28.17)} \right]^{0.5}$$

$$Y_{on} = \underline{.9822}$$

If Y_{on} is not within the range of 0.97 to 1.03, "the volume metering system should be investigated before beginning."

CFR Title 40, Part 60, Appendix A, Method 5, Section 4.4.1

S-432

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: May 3, 1993

Meter Box No. : 3 (Rockwell Dry Test Meter Serial No. 35302)

Date of Last Calibration: April 19, 1993
Calibration Technician: D. Van Hoever
Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
April 26, 1993	3-8678	1615.60	1727.41	111.81	864.51

* Total volume through meter since last calibration.

Interpoll Laboratories, Inc.
(612) 786-6020

Meter Box Calibration and Usage Status

Date of Report: April 30, 1993

Meter Box No. : 6 (Rockwell Dry Test Meter Serial No. 712852)

Date of Last Calibration: March 1, 1993

Calibration Technician: D. Van Hoever

Wet Test Meter No.: American Meter AL-20

Date of Use	Report No.	Initial Meter Reading	Final Meter Reading	Volume/Job (cu. ft.)	Total Volume* (cu. ft.)
March 18, 1993	3-8381	275.90	373.85	97.95	97.95
April 8, 1993	3-8520	374.60	516.40	141.80	239.75
April 14, 1993	3-8569	516.85	749.60	232.75	472.50
April 27, 1993	3-8678	750.60	1177.67	427.07	899.57

* Total volume through meter since last calibration.

Technician D. Bezuw

Water was not in tolerance ☒; changed dry test meters

A-5

INTERPOLLABORATORIES, INC.
METER CALIBRATION SHEET
EPA METHOD 5

Control Module No. 6
Serial No. DYN 712852
Wat Test Meter No. AL-20
Technician D. Van Horven

Positive leak check performed by BAI
 Meter was in tolerance ☒
 Meter was not in tolerance ☐; readjusted linkage
 Meter was not in tolerance ☐; changed dry test meters

Approved by Ramona Day Date 3/1/93


* Based on AL-20 wet test meter calibration in Nov. 1991 against Bell Prover (NBS Traceable) - Carl Poe Co.

SG102RR 11/91

DIFFERENTIAL - INCHES H2O

PULSATON RANGE

.30
.20
.10
0



Calibrated with a 10 Ft. American Bell
Prover, Serial No. 3157. Traceable to
the Bureau of Standards. Reference No.
5249068, PI-TAPE.

AL-20 American Met Test Meter

Serial No. p. 717

Stainless Steel w/Removable Back

Calibrated w/Saturated Air

Water Temp. 74° F.

Air Temp. 74° F.

Inlet Pressure 2" H2O Constant


Calibration Rate: 60 CFH Per/Hr.

Capacity Rate: 120 CFH Per/Hr.

Restricted Outlet for Rate Deviation

PROOF

101
100
99



CORRECT VOLUME * INDEX READING * PROOF = 100

DAVID BANKS

FLOW RATE - CUBIC FEET OF AIR PER HOUR

November, 1991

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 4-27-93

Nozzle Number 7-3

Technician: Scott Bainville

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.190
2	.190
3	.188
Average:	.190

Interpoll Laboratories, Inc.
(612) 786-6020

Nozzle Calibration
Data Sheet

Date of Calibration: 4-27-93

Nozzle : PM10-2

Technician: Ed Trowbridge

The nozzle is rotated in 60 degree increments and the diameter at each point is measured to the nearest 0.001 inch. The observed readings and average are shown below.

Position	Diameter (inches)
1	.146
2	.146
3	.145
Average:	.146

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test:

Vendor Beckman IndustrialModel HD 110TRange 0-2000 °FDate of Calibration 2-8-93Serial Number 10913005 (PDT-19)Thermocouple Type KTechnician Mark Gaehler

Method of Calibration:

- ☐ Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- ☒ Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	004	-004	4	.87
100	100	92	8	1.43
200	200	195	5	.76
300	300	294	6	.79
400	400	391	9	1.05
500	500	491	9	.94
600	600	593	7	.66
700	700	694	6	.52
800	800	799	1	.08
900	900	901	1	.07
1000	1000	1006	6	.41
1100	1100	1110	10	.64
1200	1200	1216	16	.96
1300	1300	1316	16	.91
1400	1400	1421	21	1.13
1500	1500	1519	19	.97
1600	1600	1620	20	.97
1700	1700	1716	16	.74
1800	1800	1814	14	.62
1900	1900	1907	7	.30
2000				
2100				
Averages:			10.05	0.74

OF = off scale response by unit under test (°F)
 $\% \text{ dev} = 100 \Delta t / (460 + t)$



Unit in tolerance

Unit was not in tolerance; recalibrated - See new calibration sheet.

S-433

Interpoll Laboratories, Inc.

Temperature Measurement Device
Calibration Sheet

Unit under test:

Vendor BILKMAN #28
Model HD 110T Serial Number 920521132
Range 0 - 1900 °F Thermocouple Type K
Date of Calibration 3-5-93 Technician E. T. LOWBRIDGE

Method of Calibration:

- ☐ Comparison against ASTM mercury in glass thermometer using a thermostatted and insulated aluminum block designed to provide uniform temperature. The temperature is adjusted by adjusting the voltage on the block heater cartridge.
- ☒ Omega Model CL-300 Type K Thermocouple Simulator which provides 22 precise temperature equivalent millivolt signals. The CL-300 is cold junction compensated. Calibration accuracy is $\pm 0.1\%$ of span (2100°F) ± 1 degree (for negative temperatures add ± 2 degrees. The CL-300 simulates exactly the millivoltage of a Type K thermocouple at the indicated temperature.

Desired Temp (°F) Nominal	Temperature of Standard or Simulated Temp (°F)	Response of Unit Under Test (°F)	Deviation	
			Δt (°F)	(%)
0	0	1	+1	.22
100	100	98	-2	.36
200	200	201	+1	.15
300	300	299	-1	.13
400	400	396	-4	.46
500	500	496	-4	.42
600	600	598	-2	.19
700	700	699	-1	.08
800	800	804	+4	.32
900	900	906	+6	.44
1000	1000	1012	12	.82
1100	1100	1115	15	.96
1200	1200	1221	21	1.26
1300	1300	1322	22	1.25
1400	1400	1426	26	1.39
1500	1500	1524	24	1.22
1600	1600	1625	25	1.21
1700	1700	1721	21	.97
1800	1800	1819	19	.84
1900	1900	1912	12	.51
2000				
2100				
Averages:			11.15	.66

OF = off scale response by unit under test (°F)
% dev = $100 \Delta t / (460 + t)$

- ☒ Unit in tolerance
☐ Unit was not in tolerance; recalibrated - See new calibration sheet.

(612)786-6020

S-Type Pitot Tube Inspection Sheet

Pitot No. 23-6

Pitot tube dimensions:

1. External tubing diameter (D_t) .316 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .461 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 1
5. $\alpha_2 < 10^\circ$ 1
6. $B_1 < 5^\circ$ 1
7. $B_2 < 5^\circ$ 2
8. $Z < .125"$.02
9. $W < .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .750 IN.
11. Pitot to probe sheath 3.00 IN.
12. Pitot to thermocouple (parallel to probe) 3.00 IN.
13. Pitot to thermocouple (perpendicular to probe) .760 IN.

- ☒ Meets all EPA design criteria thus $C_p = 0.84$
- ☐ Does not meet EPA design criteria - thus calibrate in wind tunnel
 $C_p =$ _____

Date of Inspection:

4-7-93

Inspected by:

[Signature]

S-Type Pitot Tube Inspection SheetPitot No. 23-8Pitot tube dimensions:

1. External tubing diameter (D_t) .516 IN.
2. Base to Side A opening plane (P_A) .460 IN.
3. Base to Side B opening plane (P_B) .460 IN.

Alignment:

4. $\alpha_1 < 10^\circ$ 0
5. $\alpha_2 < 10^\circ$ 0
6. $B_1 < 5^\circ$ 2
7. $B_2 < 5^\circ$ 1
8. $Z < .125"$.02
9. $W < .0625"$.02

Distance from Pitot to Probe Components:

10. Pitot to 0.500 IN. nozzle .755 IN.
11. Pitot to probe sheath 3.00 IN.
12. Pitot to thermocouple (parallel to probe) 3.00 IN.
13. Pitot to thermocouple (perpendicular to probe) .750 IN.

☒ Meets all EPA design criteria thus $C_p = 0.84$ ☐ Does not meet EPA design criteria - thus calibrate in wind tunnel
 $C_p =$ _____

Date of Inspection:

Inspected by:

4-7-93

INTERPOLL LABORATORIES
(612)786-6020

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

ET'S

Date 2-19-93
Technician [Signature]
Mercury Column Barometer No. LAS #1
Aneroid Barometer No. 01002008

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} -P _{bm})
29.180	72°F	.115	29.065	29.06	.005

Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. No

Has problem been alleviated? Yes/No. How? _____

*Note

Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.

S-312

INTERPOLL LABORATORIES
(612)786-6020

Scott B.

Stack Sampling Department - QA
Aneroid Barometer Calibration Sheet

Date 2-19-93
Technician *E. Lawler*
Mercury Column Barometer No. 475#1
Aneroid Barometer No. _____

Actual Mercury Barometer Read	Ambient Temp.	Temperature Correction Factor	Adjusted Mercury Barometer Read	Initial Aneroid Barometer Read	Difference (P _{ba} -P _{bm})
29.180	72°F	.115	29.065	29.190	+ .125


Has this barometer shown any consistent problems with calibration? Yes/No. If yes, explain. NO

Has problem been alleviated? Yes/No. How? _____

*Note


Aneroid barometers will be calibrated periodically against a mercury column barometer. The aneroid barometer to be calibrated should be placed in close proximity to the mercury barometer and left to equilibrate for 20-30 minutes before calibrating. Aneroid barometer will be calibrated to the adjusted mercury barometer readings.


S-312




APPENDIX B

LOCATION OF TEST PORTS









USS
Minnesota Ore Operations
P. O. Box 417
Mt. Iron, MN 55768

To: Interpoll Laboratories, Inc.
4500 Ball Road NE
Circle Pines, MN 55014-1819

Attention: Kathy Eickstadt

Date: May 14, 1993

From: Raymond Potts

Subject: Interpoll Stack Tests
Minntac Agglomerator April 1993

Enclosed is data relating to Interpoll's stack tests on April 27 and 28 at the Minntac Agglomerator (Pelletizer). A summary of the data is enclosed along with copies of logs and process overviews upon which the summary is based. If you have any questions or require more data, feel free to call me at 218-749-7598.


Raymond Potts
Agglomerator Metallurgist

pc: Jane Kingston, USS

RECEIVED
MAY 17 1993
INTERPOLL LABORATORIES

Minntac Agglomerator Operating Data Summary Interpoll Testing - April 1993

Test #	Date	Run	line #	Time	Source					Fuel Rates				Solids Rates				Water Rates	
										Natural gas	Grate	Total	Wood	Fuel oil	Green Ball	Bent.	Flux	Grn Ball	
										Burner	Burners		Tons	Gals	Feed Rate	lbs/ton	Ratio**	% H2O	
1	27-Apr-93	1	3	0835-1100						89.2	33.7	122.9	2.2	0	294	15.1	0.077	***9.8	
1	27-Apr-93	2	3	1205-1335						95.9	33.2	129.1	2.2	0	289	15.1	0.077	***9.8	
1	27-Apr-93	3	3	1420-1545						93.4	32.6	126.0	2.2	0	293	15.0	0.077	***9.8	
2	27-Apr-93	1	3	1000-1136						91.6	33.2	124.8	2.2	0	292	15.6	0.077	***9.8	
2	27-Apr-93	2	3	1210-1345						95.9	33.2	129.1	2.2	0	289	15.1	0.077	***9.8	
2	27-Apr-93	3	3	1415-1549						93.4	32.6	126.0	2.2	0	293	15.0	0.077	***9.8	
4	28-Apr-93	1	4	1420-1525						0.0	87.1	87.1	0	*760	505	17.0	0.079	***9.8	
4	28-Apr-93	2	4	1540-1645						0.0	95.1	95.1	0	*760	495	16.8	0.079	***9.8	
4	28-Apr-93	3	4	1655-1758						0.0	100.4	100.4	0	*760	495	16.7	0.079	***9.8	
5	28-Apr-93	1	5	1820-1925						154.1	74.8	228.9	0	0	488	16.3	0.079	***9.8	
5	28-Apr-93	2	5	1935-2043						156.4	83.8	240.2	0	0	462	16.6	0.079	***9.8	
5	28-Apr-93	3	5	2045-2150						151.4	91.4	242.8	0	0	476	18.0	0.079	***9.8	

*Estimated - meter not working

**Ratio of dry long tons of flux to dry long tons concentrate

***Estimated - no samples taken

1230

[illegible]

USS HINHTAC GAO CONSUMPTION 28-APR-1973 13104146.42

HOUR	24 HOUR
MAIN TURBINES	716.5
FUEL CONSUMPTION	703.6
GAS SMCF	149.2
GAS TEMP	43.6
GAS PRESS	19.8
GAS MBTU/T	675.2
CUAL TONS	0.0
CUAL MBTU/T	0.0
OIL GALLONS	-21264.8
OIL MBTU/T	-7851.9
WOOD TONS	0.0
WOOD MBTU/T	0.0
TOTAL MBTU/T	-7301.6
PHB GAS SMCF	32.9
LINE 3	154.1
LINE 4	201.5
LINE 5	0.0
LINE 6	235.4
LINE 7	0.0
UTIL	0.0
CTAILS	0.0
TOTAL	740.1
TURBINE	724.3
PULSE	738.0

USS MINNTAC GAS CONSUMPTION 28-APR-1973 14104146.34

	HOUR	24 HOUR
MAIN TURBINES	675.8	1446.4

LINE	TOT PRD TONS	PRODUCT LYPH	GRN BALL TOT TONS	BALL DRN TOT TONS	BENT PER PRD TON1	BENT PER PRD TON2	BENT PER PRD TON3	BENT PER PRD TON4	BENT PER PRD TONS	BENT PER LBS/TON	BENTONIT TOT LBS
LINE 3	1759.47	220.62	2385.02	2293.76	17.20	12.49	10.25	11.62	11.67	17.10	29975.00
LINE 4	3062.29	383.95	3977.00	3964.50	14.32	11.87	13.70	12.00	11.67	15.05	50259.00
LINE 5	1241.63	155.69	1612.50	1612.40	15.15	10.67	1.43	8.00	17.85	6.89	16726.00
TOT/AVG	6063.38	209.81	7874.52	9912.66							96960.00

UNIT	GRATE OPR HRS	LN3-BRUM OPR HRS	LN4-DNUM OPR HRS	LN5-BRUM OPR HRS	FILT HRS 4-1704-5	FILT HRS 5-1705-5	FILT HRS 2-1702-5	FILT HRS 2-6Y02-7	TONS TO STK-PILE	OUTSIDE TEMP
UNIT 1		7.98	7.98	2.78	4.47	7.93	0.00	0.00	0.00	
UNIT 2		7.98	7.98	2.78	2.93	0.00	0.00	0.00	0.00	
UNIT 3	7.98	7.98	7.98	2.77	2.25	7.98	0.00			
UNIT 4	7.98	7.98	7.98	2.39	0.00	7.98	0.00			
UNIT 5	2.42	7.98	7.98	2.40	6.49	7.98	0.00			
TOT/AVG	18.39	31.94	39.92	13.11	16.14	31.88	0.00	0.00		

UNIT	RECLAIM HRS	TON FROM RECLAIM	G.B. CON REJ TONS	OPR HRS ALL FILT	BALL DRN TOT HRS	FILT IPH ALL FILT	TON FILT ALL FILT	TON FROM CUNC	TONS TO STK-PILE	OUTSIDE TEMP
UNIT 1		0.00	0.00	48.02	31.94	4451.93	35494.00	0.00	0.00	51.89
UNIT 2		0.00	0.00		53.04	0.00	0.00	0.00	0.00	
TOT/AVG		0.00	0.00			4451.93	35494.00	0.00	0.00	


LINE	GAS STD HCF	PH BURHR	TURBINE	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SHCF
LINE 3	1185.79	264.60	5411.68			0.0	0.0	0.0	0.0	0.0	0.0	677.2	33.4
LINE 4	1358.30	694.80				0.0	0.0	-22989.0	-8114.2	0.0	0.0	-8114.1	85.3
LINE 5	1156.66	172.00				0.0	0.0	0.0	0.0	0.1	1821.0	2263.3	0.0
TOT/AVG	3700.75	1131.40	5411.68			0.0	0.0	0.0	0.0	0.0	0.0	599.2	0.0

FUEL CONSUMPTION	HOUR	28-APR-1993	14:32	352.93
LINE 3	148.3	44.1	19.8	677.2
LINE 4	83.3	72.5	0.0	-8110.0
LINE 5	198.8	43.2	20.9	2265.8
LINE 6	0.0	67.2	0.0	0.0
LINE 7	236.5	46.3	18.4	599.2
UTIL	0.0	73.9	13.0	
CTAILS	0.0			
TOTAL	668.9		948.1	
TURBINE	450.3	32.6	98.6	
T PULSE	649.0			
TOTAL				195.1

FUEL CONSUMPTION	SHIFT	28-APR-1993	14:32	52.93
LINE 3	1185.8	43.7	19.8	677.2
LINE 4	1358.3	47.2	23.4	683.6
TOTAL				1361.8
TURBINE	450.3	32.6	98.6	
T PULSE	649.0			
TOTAL				1361.8

INTERPOL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job US STEEL / MINTAK
 Source NO. 4 PELLETTIERE STACK
 Test 4 Run 0 Date 4-27-93
 Stack dimen. 168 IN.
 Dry bulb 119 °F Wet bulb °F
 Manometer: ☒ Reg. ☐ Exp. ☐ Elec.
 Barometric pressure 28.17 in Hg
 Static pressure -0.81 in WC
 Operators SLB + JB
 Pitot No 23-8 Cp .840



Traverse Point No.	Fraction of Diameter	Distance from Stack Wall (in)	Distance from End of Port (in)	Velocity Pressure (in WC)	Temperature of gas (°F)
		Port length: <u>16</u> in.		Time start: hrs	
A	1	.021	3.53	21.53	
	2	.067	11.26	29.26	
	3	.118	19.82	37.82	
	4	.177	29.24	47.24	
	5	.250	42.00	60.00	
	6	.356	59.81	77.81	
B	1				
	2				
	3				
	4				
	5				
	6				
C	1				
	2				
	3				
	4				
	5				
	6				
D	1				
	2				
	3				
	4				
	5				
	6				
Temp. meas. device & S/N: <u>DIGITAL TC/PDT29</u>				Time end: hrs	

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job US STEEL / MINTAC Date 4/27/93 Test 4 Run 21
 Source NO. 4 Pulverizer STACK No. of traverse points 21
 Method FS Filter holder: BLACK Filter type: GLASS Fiber

Sample Train Leak Checks:

Pretest: (0.02 cfm at 15 in. Hg. (vac) ☒
 Posttest: 0.00 cfm at 15 in. Hg. (vac) ☒

Particulate Catch Data:

No.s of filters used: 5102 Recovery solvent(s) _____
☐ acetone _____
☐ other(s) _____
 No. of probe wash bottles: _____
 Sample recovered by: _____

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1	598	497	111
Impinger No. 2			
Impinger No. 3			
Condenser			
Desiccant	1316	1297	19
Total			130

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 26 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 00 cc/min at 15 in. Hg.
 Time start: 1420 (HRS) Time end: 1525 (HRS)
 Sampling rate: 400 cc/min Operator: SCB
 S/N of O₂ Analyzer used to monitor train outlet: 7

CF-023

S-0046RR

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job US Steel / Inconel Operators S-B J-J Pitot No. 23-8 Cp. 840
 Sample No. 4 Motor Box No. 6 SHF 6.81 IN MC Bar. Press. 28.72 inHg H₂O
 Date 01-22-83 Computer Effct. 9380 Nozzle No. 2-2 Nozzle Dia. 2.57 in.

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (inWC)	Drifts Meter (inWC)	Dye Vol. (cf)	VAC. inHg	Temperatures (°F)					Oxygen (xv/v)
							Stack	Probe	Oven	Inpg.	Gas In	Gas Out
B 6	2.5	915.66	1.10	3.36	5.64	5	120	257	240	46	80	78
5	5	918.37	1.15	3.55	8.38	5	119				84	80
7	7.5	921.19	1.20	3.73	1.19	5	119	275	248	46	85	80
3	10	923.90	1.15	3.57	3.93	5	120				86	81
2	12.5	926.45	1.10	3.42	6.62	5	120	251	252	46	88	82
1	15	929.30	1.10	3.43	9.33	5	120				84	83
C 6	17.5	931.48	0.68	2.13	1.46	4	120	250	253	46	90	83
5	20	933.76	0.60	1.88	3.47	4	120				81	84
4	22.5	935.55	0.63	1.98	5.53	4	120	252	256	47	92	84
3	25	937.35	0.57	1.86	7.53	4	120				92	85
2	27.5	939.56	0.60	1.89	9.54	4	120	251	250	46	92	85
1	30	941.66	0.80	2.52	1.57	4	120				92	85
D 6	32.5	944.29	1.05	3.30	1.52	5	120	252	256	44	93	86
5	35	947.00	1.00	3.15	7.14	5	120				94	87
4	37.5	949.88	1.10	3.47	9.85	6	120	256	258	45	95	87
3	40	952.62	1.10	3.47	2.58	6	120				95	87
2	42.5	955.12	0.95	3.00	5.12	6	120	255	258	45	95	88
1	45	957.60	0.95	3.00	7.67	6	120				95	88
A 6	47.5	960.51	1.20	3.78	0.52	6	120	255	257	45	95	88
5	50	963.39	1.20	3.78	3.37	6	120				96	89
4	52.5	966.28	1.25	3.95	6.29	6	120	255	258	46	97	89
3	55	969.20	1.20	3.79	9.15	6	120				97	90
2	57.5	971.94	1.15	3.64	1.95	6	120	256	258	47	98	90
1	60	974.57	1.00	3.17	4.57	5	120				98	90
	(1505)											
	0 = 60	V = 61.57		ΔH = 312							avg. = 971	

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job BUSSTEEL / MINUTAC Date 4-28-93 Test 4 Run 2
 Source NO. 4 POWERER STAKE No. of traverse points 27
 Method 1-5 Filter holder: GLASS Filter type: GLASS FIBER

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac) 1
 Posttest: 0.02 cfm at 15 in. Hg. (vac) 1

Particulate Catch Data:

No.s of filters used: 5101 Recovery solvent(s)
☒ acetone
☐ other(s)

No. of probe wash bottles: 1
 Sample recovered by: SLB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>274</u>	<u>5200</u>	<u>74</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1407</u>	<u>1400</u>	<u>7</u>
Total			<u>81</u>

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 26 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 00 cc/min at 15 in. Hg.
 Time start: 1540 (HRS) Time end: 1645 (HRS)
 Sampling rate: 400 cc/min Operator: SLB
 S/N of O₂ Analyzer used to monitor train outlet: 7

CF-023

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job US Steel / MINUTAS Operator SWB 40B Pitot No. 23-8 Cp 840
 Source NO. 4 POWERHOUSE STAIRS Meter Box No. 6 HP 4.82 IN MC Bar. Press. 23.2 IN Hg H₂O 10 X
 Date 6-28-93 1061 4 Computer Coeff. .9920 Nozzle No. 2-3 Nozzle Dia. 1.50 IN.

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Hood (ft/min)	Orifice Meter (ft/min)	Dep. Vol. (cf)	VAC. inHg	Temperature (°F)					Oxygen (xv/v)
							Stack	Probe	Duct	Inlet	Outlet	
A 4	2.5	976.73	1.30	1.44	6.71	4	120	251	258	87	88	18.0
5	5	978.57	1.30	1.65	8.60	4	121			92	87	18.0
9	7.5	980.52	1.55	1.71	0.52	4	121	252	258	93	88	18.0
3	10	982.86	1.60	1.77	2.48	3	121			94	89	18.0
2	12.5	984.53	1.60	1.77	4.43	3	121	252	258	94	87	17.0
1	15	986.38	1.55	1.72	6.36	3	121			95	90	18.2
D 4	17.5	988.00	1.15	1.28	8.02	3	121	256	260	97	91	18.3
5	20	989.62	1.10	1.22	9.66	3	121			95	90	18.1
4	22.5	991.36	1.15	1.28	1.32	3	120	255	258	95	90	18.1
3	25	992.90	1.05	1.17	2.92	3	120			94	91	17.9
2	27.5	994.58	1.05	1.17	4.51	3	120	252	256	94	90	17.7
1	30	995.95	1.00	1.04	5.95	3	108			92	87	17.7
C 6	32.5	997.54	1.05	1.21	7.55	3	108	252	256	92	87	17.7
5	35	999.02	0.95	1.07	9.07	3	107			91	87	17.7
4	37.5	1000.65	0.94	1.06	0.59	3	107	251	257	92	87	17.7
3	40	1002.17	1.00	1.13	2.15	3	109			93	88	17.9
2	42.5	1003.72	0.98	1.09	3.69	3	118	252	257	93	88	17.7
1	45	1005.15	0.83	0.92	5.10	2	119			93	88	17.7
B 6	47.5	1006.26	1.25	1.38	6.21	3	120	251	255	93	88	17.7
5	50	1008.73	1.50	1.66	8.72	3	120			93	88	17.9
4	52.5	1010.64	1.50	1.66	0.62	3	120	252	254	94	89	18.0
3	55	1012.46	1.35	1.50	2.42	3	120			95	89	17.9
2	57.5	1014.23	1.30	1.44	4.19	3	120	251	254	96	90	18.0
1	60	1015.92	1.20	1.33	5.89	3	121			96	90	18.0
	(1645)											
	0 = 60	V = 90.97		ΔH = 1.38						Avg. = 89.2		

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job US Steel / MINNTAC Date 4-28-93 Test 4 Run 3
 Source NO. 4 PULVERIZER STACK No. of traverse points 21
 Method 1-S Filter holder: GLASS Filter type: GLASS FIBER

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac)
 Posttest: 0.00 cfm at 15 in. Hg. (vac) 

Particulate Catch Data:

No.s of filters used: 5123 Recovery solvent(s)
☒ acetone
☐ other(s) _____
 No. of probe wash bottles: _____
 Sample recovered by: SLB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>568</u>	<u>498</u>	<u>70</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1362</u>	<u>1350</u>	<u>12</u>
Total			<u>82</u>

Integrated Gas Sampling Data:

Bag Pump No. 231 Box No. 24 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 00 cc/min at 15 in. Hg.
 Time start: 1655 (HRS) Time end: 1758 (HRS)
 Sampling rate: 400 cc/min Operator: SLB
 S/N of O₂ Analyzer used to monitor train outlet: 7

CF-023

S-0046RR

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job US Steel (Munich) Operator SAB + JB Pitot No. 23-8 CP 840
 Sample 100.9 Meter Box No. 6 Bar. Press. 28.12 in Hg H₂O 10 x
 Date 7-28-67 Gasometer const. 5550 IN MC 1.81 Nozzle Dia. 1.20 in.

Transfer Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (in MC)	Drifts Meter (in MC)	Dis. Vol. (cf)	VAC. in Hg	Temperature (°F)				Gas/Dut	Oxygen (xv/v)
							Stack	Probe	Duct	Inpg.	Gas/In	
B	6	1016.10	1.10	1.21	7.72	3	120	251	248	44	89	16.3
	5	1017.70	1.15	1.27	9.37	3	120				91	17.3
	4	1021.15	1.30	1.44	1.13	3	120	251	252	45	92	18.1
	3	1022.98	1.40	1.55	2.96	3	121				92	18.4
	2	1024.74	1.30	1.43	4.72	3	121	251	250	45	93	18.4
	1	1026.39	1.15	1.27	6.38	3	121				94	18.5
C	6	1027.88	0.93	1.03	7.87	3	121	252	256	46	94	18.5
	5	1029.46	1.00	1.11	9.42	3	121				93	18.2
	4	1030.90	1.00	1.10	0.97	3	121	252	256	46	93	18.2
	3	1032.52	0.97	1.07	2.49	3	121				94	18.3
	2	1033.98	0.93	1.03	3.99	3	121	251	256	45	93	18.1
	1	1035.46	0.84	0.93	5.41	3	120				93	17.9
D	6	1037.00	1.10	1.22	7.03	3	120	251	255	46	92	17.9
	5	1038.66	1.10	1.22	8.65	3	120				90	18.0
	4	1040.24	1.05	1.16	0.23	3	120	252	256	44	91	18.0
	3	1041.88	1.10	1.21	1.85	3	121				92	18.0
	2	1043.35	0.93	1.03	3.34	3	120	251	258	45	92	18.0
	1	1044.90	0.93	1.03	4.83	3	120				92	18.0
A	6	1046.55	1.20	1.32	6.52	3	120	252	257	45	92	18.1
	5	1048.32	1.35	1.49	8.31	3	120				91	18.2
	4	1050.20	1.60	1.76	0.26	4	120	252	257	45	90	18.2
	3	1052.19	1.60	1.76	2.21	4	120				91	18.2
	2	1054.10	1.55	1.71	4.13	4	120	252	256	46	91	18.1
	1	1055.92	1.35	1.49	5.92	4	120				91	18.1
	(1758)											
	0 = 60	40 = 39.82		ΔH = 1.28							Avg. = 87.5	

Interpoll Laboratories
(612)786-6020

Visible Emissions Form

TEST #3

SOURCE NAME <u>U.S. Steel - Minntac</u>			OBSERVATION DATE <u>4-28-93</u>				START TIME <u>1425</u>				STOP TIME <u>1525</u>			
ADDRESS <u>P.O. Box 417</u>			SEC MIN				SEC MIN				SEC MIN			
			0 15 30 45				0 15 30 45				0 15 30 45			
CITY <u>Mountain Iron</u>			STATE <u>MN</u>		ZIP <u>55768</u>		1 15 15 15 10 31 15 15 15 15				2 10 15 15 10 32 10 10 10 10			
PHONE			SOURCE ID NUMBER				3 10 10 15 15 33 10 10 10 15				4 20 15 15 15 34 10 10 10 10			
PROCESS EQUIPMENT <u>No. 4 Pelletizer</u>			OPERATING MODE <u>100%</u>				5 15 15 10 10 35 10 10 10 15				6 10 10 10 10 36 15 15 10 10			
CONTROL EQUIPMENT			OPERATING MODE				7 15 15 15 15 37 15 15 15 10				8 10 10 15 15 38 10 10 10 10			
DESCRIBE EMISSION POINT START <u>Round Metal Stack</u> STOP ☒							9 10 10 10 10 39 15 15 15 10				10 15 15 10 10 40 15 10 10 15			
HEIGHT ABOVE GROUND LEVEL START <u>30'</u> STOP ☒			HEIGHT RELATIVE TO OBSERVER START <u>10'</u> STOP ☒				11 10 10 10 15 41 10 10 15 15				12 10 10 10 15 42 15 10 10 15			
DISTANCE FROM OBSERVER START <u>100'</u> STOP ☒			DIRECTION FROM OBSERVER START <u>NW</u> STOP ☒				13 10 10 10 15 43 10 10 15 15				14 10 10 10 10 44 15 15 10 10			
DESCRIBE EMISSIONS START <u>Wh to Br Billowy</u> STOP ☒							15 10 10 15 15 45 10 10 10 10				16 15 15 10 10 46 15 15 10 10			
EMISSION COLOR START <u>Wh to Br</u> STOP ☒			PLUME TYPE: CONTINUOUS ☒ FUGITIVE ☐ INTERMITTENT ☐				17 15 10 10 10 47 15 15 10 10				18 10 10 15 15 48 15 15 10 10			
WATER DROPLETS PRESENT: NO ☒ YES ☐			IF WATER DROPLET PLUME: ATTACHED ☐ DETACHED ☐				19 10 10 10 10 49 10 10 10 10				20 10 10 10 10 50 10 10 10 15			
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <u>Exit point</u> STOP ☒							21 15 15 15 10 51 10 10 10 10				22 10 10 10 10 52 10 10 10 10			
DESCRIBE BACKGROUND START <u>Sky to some clouds</u> STOP ☒							23 15 15 15 10 53 5 5 5 5				24 10 10 15 10 54 10 5 10 5			
BACKGROUND COLOR START <u>Blue</u> STOP ☒			SKY CONDITIONS <u>Part. CL</u> START <u>CL to</u> STOP ☒				25 10 10 10 10 55 5 10 10 10				26 10 15 15 15 56 10 10 5 5			
WIND SPEED START <u>12-15 mph</u> STOP ☒			WIND DIRECTION START <u>NW</u> STOP ☒				27 15 15 15 15 57 5 5 10 5				28 15 15 10 10 58 5 5 10 10			
AMBIENT TEMP. START <u>65°</u> STOP <u>65°</u>			WET BULB TEMP.		RH. percent <u>47</u>		29 10 15 15 10 59 10 5 10 5				30 15 10 10 10 60 5 5 5 10			
Source Layout Sketch Draw North Arrow The sketch shows two stacks, No. 3 and No. 5, with an emission point between them. An observer's position is marked with a line of sight to the emission point. A sun location line is drawn at a 40-degree angle from the observer's position. Wind direction is indicated by an arrow pointing towards the stacks.			AVERAGE OPACITY FOR HIGHEST PERIOD <u>13.333</u>				NUMBER OF READINGS ABOVE 20% WERE <u>0</u>							
			RANGE OF OPACITY READINGS MINIMUM <u>5</u> MAXIMUM <u>20</u>											
			OBSERVER'S NAME (PRINT) <u>JEFF BERGSTROM</u>											
			OBSERVER'S SIGNATURE <u>Jeff Bergstrom</u>				DATE <u>4-28-93</u>							
COMMENTS			ORGANIZATION <u>Interpoll Lab</u>											
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS			CERTIFIED BY <u>E.T.A. Minneapolis MN</u>				DATE <u>4-1-93</u>							
SIGNATURE			VERIFIED BY				DATE							
TITLE			DATE											

INTERPOLL LABORATORIES - EPA METHOD 2 FIELD DATA SHEET

Job US Steel / M / NW TAC
Source No. 5 Pelletizer Stock
Test 5 Run 0 Date 4-28-93
Stack dimen. 168 IN.

Dry bulb _____ °F Wet bulb _____ °F

Manometer: ☒ Reg. ☐ Exp. ☐ Elec.

Barometric pressure 28.12 in Hg

Static pressure 0.88 in WC

Operators S. Bainville & J. VanHoever

Pitot No. V23-8 Cp 1.84

Cross-section View

Elevation
View

Drawing
of Test Site

[illegible]

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job US Steel / MINOTAC Date 4-28-93 Test 5 Run 1
 Source NO. 5 POWER PLANT STACK No. of traverse points 21
 Method 1-1 Filter holder: GLASS Filter type: GLASS FIBER

Sample Train Leak Checks:

Pretest: (0.02 cfm at 15 in. Hg. (vac) ✓
 Posttest: 0.01 cfm at 15 in. Hg. (vac) ✓

Particulate Catch Data:

No.s of filters used: 5119 Recovery solvent(s)
☒ acetone
☐ other(s) _____
 No. of probe wash bottles: 1
 Sample recovered by: SLB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>563</u>	<u>508</u>	<u>55</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1344</u>	<u>1334</u>	<u>10</u>
Total			<u>65</u>

Integrated Gas Sampling Data:

Bag Pump No. 233 Box No. 17 Bag No. 1
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 00 cc/min at 15 in. Hg.
 Time start: 1720 (HRS) Time end: 1725 (HRS)
 Sampling rate: 400 cc/min Operator: SLB
 S/N of O₂ Analyzer used to monitor train outlet: 7

CF-023

S-0046RR

INTERPOL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job US Steel / PONTIAC Operators SCB & JBS Pitot No. 23-8 Cp 840
 Source NO 5 Peccoffice Stack Meter Box No. 6 HP 181 IN HC 28.12 INHg 6
 Date 4-28-83 1981 5 Run 1 Gasometer coeff. 9970 Nozzle No. 2-3 Nozzle Dia 1/8 IN.

Traverse Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (inHC)	Driftless Water (inHC)	Dep. Vol. (cf)	VAC. inHg	Temperature (°F)					Oxygen (xv/v)	
							Stack	Probe	Oven	Imp.	Gas/in		Gas/Dup
	(1820)												
D 6	2.5	1057.70	0.98	1.18	7.28	3	103	249	251	44	80	80	17.7
5	5	1039.25	0.98	1.18	9.36	3	102				81	80	17.7
7	7.5	1060.96	0.98	1.18	0.94	3	102	248	253	44	82	80	17.7
3	10	1062.53	1.05	1.27	2.58	3	102				83	81	17.9
2	12.5	1064.27	1.10	1.30	4.25	3	115	248	254	44	86	81	17.9
1	15	1065.88	1.05	1.24	5.88	3	115				86	82	17.9
A 6	17.5	1067.60	1.20	1.42	7.62	3	115	248	254	43	85	82	17.9
5	20	1069.41	1.25	1.48	9.40	3	114				86	82	17.7
7	22.5	1071.24	1.35	1.60	1.24	3	116	248	255	43	87	83	17.7
3	25	1073.26	1.55	1.83	3.22	3	116	249	255	43	88	83	17.7
2	27.5	1075.00	1.30	1.54	5.04	3	116				88	83	17.5
1	30	1076.75	1.15	1.36	6.75	3	116	249	256	42	89	83	17.5
C 6	32.5	1078.10	0.75	0.89	8.13	2	116				88	83	17.7
5	35	1079.62	0.83	0.99	9.59	2	115	249	252	42	88	83	17.5
7	37.5	1080.90	0.70	0.83	0.93	2	115				88	83	17.5
3	40	1082.32	0.88	1.04	2.42	3	117	249		45	88	83	17.4
2	42.5	1083.87	0.80	0.95	3.85	2	117	252	258	45	88	82	17.5
1	45	1085.18	0.70	0.83	5.18	2	118				87	82	17.5
B 6	47.5	1086.78	1.05	1.24	6.81	3	118	251	256	46	87	82	17.5
5	50	1088.39	0.95	1.12	8.36	3	118				86	82	17.4
7	52.5	1089.95	0.98	1.15	9.93	3	118	253	257	47	87	82	17.3
3	55	1091.45	1.05	1.24	1.56	3	117				86	82	17.2
2	57.5	1093.20	1.10	1.30	3.23	3	117	254	253	44	86	82	17.0
1	60	1094.86	1.05	1.24	4.86	3	117				86	82	17.0
	(1925)												
	0 = 60	V _s = 37.16		ΔH = 1.22							avg. = 87		

INTERPOLL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job US Steel (mining) Date 11-28-93 Test 5 Run 2
 Source No. 5 Powerline STACIS No. of traverse points 24
 Method 1-5 Filter holder: GLASS Filter type: GLASS FIBER

Sample Train Leak Check:

Pretest: (0.02 cfm at 15 in. Hg. (vac) A
 Posttest: 0.00 cfm at 10 in. Hg. (vac) B

Particulate Catch Data:

No.s of filters used: 5/20 Recovery solvent(s) acetone
☒ acetone
☐ other(s) _____
 No. of probe wash bottles: 2
 Sample recovered by: SLB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	<u>268</u>	<u>200</u>	<u>68</u>
Impinger No. 3			
Condenser			
Desiccant	<u>1370</u>	<u>1362</u>	<u>8</u>
Total			<u>76</u>

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 17 Bag No. 2
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 00 cc/min at 15 in. Hg.
 Time start: 1935 (HRS) Time end: 2043 (HRS)
 Sampling rate: 400 cc/min Operator: SLB
 S/N of O₂ Analyzer used to monitor train outlet: 2

CF-023

INTERPOLL LABORATORIES EPA METHOD 5 FIELD DATA SHEET

Job USS Steel Minutac Date 4-28-83 Operator Sub JTB Pitot No. 23-8 Cp X40
 Source 24.5 Percutene Motor Box No. 6 HP 1.81 IN MC Bar. Press. 28.12 inHg H₂O
 Gasometer confit. 5 Revs 9470 Nozzle No. 7-3 Nozzle Dia .90 in.

Transfer Point No.	Sampling Time (min)	Sample Volume (cf)	Velocity Head (inWC)	Drifts Water (inWC)	Dis. Vol. (cf)	VAC. inHg	Temperature (°F)				Gas In	Gas Out	Oxygen (xv/v)
							Stack	Probe	Duct	Inlet			
B	6	(193.5)	1.00	1.14	6.81	2	117	253	247	43	80	79	17.7
	5	1096.87	.99	1.12	98.35	2	117				80	78	17.7
	4	1099.88	1.10	1.24	99.97	2.5	116	253	252	43	81	79	17.9
	3	1101.57	1.20	1.36	106.7	2.5	117				83	79	17.7
	2	1103.25	1.15	1.30	103.34	2.0	117	250	254	44	84	80	17.5
	1	1104.89	1.0	1.14	104.89	2	117				86	80	17.9
C	6	1106.35	.95	1.08	106.41	2	117	249	251	45	84	80	17.7
	5	1107.92	.99	1.13	107.96	2	116				86	80	17.5
	4	1109.46	.88	1.00	109.43	2	117	251	253	46	86	80	17.9
	3	1111.08	1.10	1.25	110.6	2.5	117				86	80	17.9
	2	1112.51	.92	1.04	112.55	2	118	252	250	46	87	80	18.1
	1	1113.92	.80	.91	113.95	2	119				87	80	17.9
D	6	1115.58	.98	1.12	115.50	2	116	250	254	44	85	80	17.9
	5	1117.05	1.0	1.14	117.05	2.5	117				87	81	17.9
	4	1118.62	1.05	1.20	118.66	2.5	117	253	257	45	87	81	17.9
	3	1120.29	1.10	1.25	120.29	3	117				88	81	17.9
	2	1121.99	1.15	1.31	121.97	3	118	253	258	46	88	81	17.2
	1	1123.55	.95	1.08	123.44	2.5	118				88	81	17.9
A	6	1125.20	1.15	1.31	125.17	3	116	251	255	47	87	81	18.0
	5	1126.84	1.10	1.25	126.80	3	117				87	81	17.9
	4	1128.73	1.50	1.71	128.71	3	117	252	257	47	88	81	17.9
	3	1130.61	1.55	1.77	130.66	3.5	117				88	81	18.0
	2	1132.54	1.50	1.71	132.54	3.5	117	253	258	47	88	81	18.0
	1	1134.43	1.40	1.60	134.42	3.5	117				88	81	18.0
	(2043)										Av. = 83		

S-0037R

INTERPOL LABORATORIES EPA METHOD 5/17 SAMPLE LOG SHEET

Job US Steel / MINNTA Date 4-28-93 Test 5 Run 3
 Source NO. 5 POWER PLANT STACK No. of traverse points 24
 Method 1-5 Filter holder: GLASS Filter type: GLASS FIBER

Sample Train Leak Checks:

Pretest: (0.02 cfm at 15 in. Hg. (vac) ☒
 Posttest: 0.00 cfm at 10 in. Hg. (vac) ☒

Particulate Catch Data:

No.s of filters used: 5/21 Recovery solvent(s) ☒ acetone
☐ other(s) _____
 No. of probe wash bottles: _____
 Sample recovered by: SLB

Condensate Data:

Item	Weight (g)		
	Final	Tare	Difference
Impinger No. 1			
Impinger No. 2	558	498	60
Impinger No. 3			
Condenser			
Desiccant	1515	1506	9
Total			69

Integrated Gas Sampling Data:

Bag Pump No. 23B Box No. 17 Bag No. 3
 Bag Material: 5-layer Aluminized Tedlar Size: 44 L
 Pretest leak check: 00 cc/min at 15 in. Hg.
 Time start: 2045 (HRS) Time end: 2150 (HRS)
 Sampling rate: 400 cc/min Operator: SLB
 S/N of O₂ Analyzer used to monitor train outlet: 7

CF-023

EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job US Steel / Minntac Source No. 4 Pulverizer
Team Leader SLB Test Site Stack
Date Submitted 4-29-93 Date of Test 4-27-93
Test No. 4 No. of Runs Completed 3
Date of Analysis 4-29-93 Technician B. Duple

Test/ Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F ₀
			Zero Pt.	After CO ₂	After O ₂			
4/1	86 78-32 □ B □ F	1	0.00	2.10	20.50	2.10	18.40	1.19
		2	0.00	2.10	20.50	2.10	18.40	1.19
		Avg				2.10	18.40	
4/2	-36 □ B □ F	1	0.00	2.10	20.50	2.10	18.40	1.19
		2	0.00	2.10	20.50	2.10	18.40	1.19
		Avg				2.10	18.40	
4/3	-40 □ B □ F	1	0.00	2.10	20.60	2.10	18.50	1.14
		2	0.00	2.10	20.60	2.10	18.50	1.14
		Avg				2.10	18.50	
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						
	□ B □ F	1						
		2						
		Avg						

- ☒ Ambient Air QA Check
☒ Orsat Analyzer System Leak Check
☐ F₀ Within EPA M-3 Guidelines
for fuel type.

Where $F_0 = \frac{20.9 - O_2}{CO_2}$

EPA Method 3 Guidelines
Fuel Type F₀ Range

Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
D-1 Wood/Wood Bark	1.000-1.130

F=Flask (250 cc all glass)
B=Tedlar Bag (5-layer)

EPA Method 3 Data Reporting Sheet
Orsat Analysis

Job U.S. Steel / Minnatac
Team Leader SLB
Date Submitted 4-29-93
Test No. 5
Date of Analysis 4-29-93

Source No. 5 Pelletizer
Test Site Stack
Date of Test 4-28-93
No. of Runs Completed 3
Technician B. Duh

Test/ Run	Sample Log Number and Type	No. of An.	Buret Readings (ml)			Conc. CO ₂ %v/v Dry	Conc. O ₂ %v/v Dry	F _o
			Zero Pt.	After CO ₂	After O ₂			
5/1	8678-44 ☒ B ☐ F	1	0.00	2.10	20.20	2.10	18.10	1.33
		2	0.00	2.10	20.20	2.10	18.10	1.33
		Avg				2.10	18.10	
5/2	-48 ☒ B ☐ F	1	0.00	2.20	20.30	2.20	18.10	1.27
		2	0.00	2.20	20.30	2.20	18.10	1.27
		Avg				2.20	18.10	
5/3	-52 ☒ B ☐ F	1	0.00	2.00	20.30	2.00	18.30	1.30
		2	0.00	2.00	20.30	2.00	18.30	1.30
		Avg				2.00	18.30	
	☐ B ☐ F	1						
		2						
		Avg						
	☐ B ☐ F	1						
		2						
		Avg						
	☐ B ☐ F	1						
		2						
		Avg						
	☐ B ☐ F	1						
		2						
		Avg						
	☐ B ☐ F	1						
		2						
		Avg						
	☐ B ☐ F	1						
		2						
		Avg						
	☐ B ☐ F	1						
		2						
		Avg						

- ☒ Ambient Air QA Check
☒ Orsat Analyzer System Leak Check
☐ F_o Within EPA M-3 Guidelines
for fuel type.

Where $F_o = \frac{20.9 - O_2}{CO_2}$

EPA Method 3 Guidelines
Fuel Type F_o Range

Coal:	
Anthracite/Lignite	1.016-1.130
Bituminous	1.083-1.250
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.836
Propane	1.434-1.586
Butane	1.405-1.553
D-2 Wood/Wood Bark	1.000-1.130

F=Flask (250 cc all glass)
B=Tedlar Bag (5-layer)

Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Impinger Catch/Minnesota Protocol

Job US Steel/Minnesota Source No. 4 Pelletizer
Team Leader SLB Test Site Stack
Date Submitted 4-28-93 Date of Test 4-27-93
Test No. 4 No. of Runs Completed 3
Date of Analysis 5-5-93 Technician B. Duke

0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>4</u> Run <u>1</u> Log Number <u>8678-31</u> Comments _____	Dish No. <u>106</u> Dish Tare Wt. <u>43.0171</u> g Dish+Sample Wt. <u>43.0178</u> g Sample Wt. <u>0.0007</u> g
2	Test <u>4</u> Run <u>2</u> Log Number <u>-35</u> Comments _____	Dish No. <u>110</u> Dish Tare Wt. <u>49.7365</u> g Dish+Sample Wt. <u>49.7375</u> g Sample Wt. <u>0.0010</u> g
3	Test <u>4</u> Run <u>3</u> Log Number <u>-34</u> Comments _____	Dish No. <u>605</u> Dish Tare Wt. <u>49.6846</u> g Dish+Sample Wt. <u>49.6856</u> g Sample Wt. <u>0.0010</u> g
4	Test _____ Run _____ Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


Blank Solvent Wt. 0.0004g

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0003	0.0006 D-3	0.0006		
--	--------	------------	--------	--	--

LSC-03.GF



Interpoll Laboratories
(612) 786-6020

EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job US Steel / Minntac Source No. 4 Pelletizer
Team Leader SLB Test Site Stack
Date Submitted 4-28-93 Date of Test 4-28-93
Test No. 4 No. of Runs Completed 3
Date of Analysis 4-30-93 Technician B. Dula
Transport Leakage ☒ None ☐ _____ ml Solvent Acetone

0	Test <u>Run 0</u> Field Blank Log Number _____ Vol. of Solvent _____ ml *Solvent Residue <u>2.0</u> ug/ml	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>4</u> Run <u>1</u> Vol. of Solvent <u>160</u> ml Log Number <u>8678-24</u> Comments _____	Dish No. <u>518</u> Dish Tare Wt. <u>48.1026</u> g Dish+Sample Wt. <u>48.1125</u> g Sample Wt. <u>0.0099</u> g
2	Test <u>4</u> Run <u>2</u> Vol. of Solvent <u>180</u> ml Log Number <u>-33</u> Comments _____	Dish No. <u>521</u> Dish Tare Wt. <u>50.5957</u> g Dish+Sample Wt. <u>50.6101</u> g Sample Wt. <u>0.0144</u> g
3	Test <u>4</u> Run <u>3</u> Vol. of Solvent <u>140</u> ml Log Number <u>-37</u> Comments _____	Dish No. <u>611</u> Dish Tare Wt. <u>50.0094</u> g Dish+Sample Wt. <u>50.0137</u> g Sample Wt. <u>0.0043</u> g
4	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


*Solvent Residue _____ ug/ml = [(Sample Wt. _____ g) (10⁶)] / Vol. of Sol. _____ ml
EPA-M5 Acetone Residue Blank Spec. { 7.8 ug/ml

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0096	0.0140 D-4	0.0040		
--	--------	------------	--------	--	--

LSC-01YR



EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job U.S. Steel / Minntac Source No. 4 Pelletizer
Team Leader SLB Test Site Stack
Date Submitted 4-28-93 Date of Test 4-28-93
Test No. 4 No. of Runs Completed 3
Date of Analysis 4-30-93 Technician B. Deane

0	Test <u>Run 0</u> Field Blank Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>4</u> Run <u>1</u> Log Number <u>8678-30</u> Comments _____	Filter No. <u>5102</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.8858</u> g Filter+Sample Wt. <u>.9060</u> g Sample Wt. <u>0.0202</u> g
2	Test <u>4</u> Run <u>2</u> Log Number <u>-34</u> Comments _____	Filter No. <u>5101</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.8761</u> g Filter+Sample Wt. <u>.8898</u> g Sample Wt. <u>0.0137</u> g
3	Test <u>4</u> Run <u>3</u> Log Number <u>-38</u> Comments _____	Filter No. <u>5123</u> Filter Type <u>4"GF</u> Filter Tare Wt. <u>.8781</u> g Filter+Sample Wt. <u>.8907</u> g Sample Wt. <u>0.0126</u> g
4	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Log Number _____ Comments _____	Filter No. _____ Filter Type _____ Filter Tare Wt. _____ g Filter+Sample Wt. _____ g Sample Wt. _____ g

Results:


Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0202	0.0137	0.0126		
--	--------	--------	--------	--	--

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0301	0.0283	0.0172		
--	--------	--------	--------	--	--

LSC-02PR



EPA Method 5 Data Reporting Sheet
Impinger Catch/Minnesota Protocol

Job US Steel / Minntac Source NO. 5 Pelletizer
Team Leader SLB Test Site Stack
Date Submitted 4-28-93 Date of Test 4-28-93
Test No. 5 No. of Runs Completed 3
Date of Analysis 5-6-93 Technician R. Quinn

0	Test <u>Run 0</u> Field Blank Log Number Comments	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>5</u> Run <u>1</u> Log Number <u>8678-43</u> Comments	Dish No. <u>21</u> Dish Tare Wt. <u>47.5276</u> g Dish+Sample Wt. <u>47.5299</u> g Sample Wt. <u>0.0023</u> g
2	Test <u>5</u> Run <u>2</u> Log Number <u>-47</u> Comments	Dish No. <u>61A</u> Dish Tare Wt. <u>51.4830</u> g Dish+Sample Wt. <u>51.4860</u> g Sample Wt. <u>0.0030</u> g
3	Test <u>5</u> Run <u>3</u> Log Number <u>-51</u> Comments	Dish No. <u>98</u> Dish Tare Wt. <u>47.2149</u> g Dish+Sample Wt. <u>47.2169</u> g Sample Wt. <u>0.0020</u> g
4	Test <u>Run</u> Log Number Comments	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test <u>Run</u> Log Number Comments	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


Blank Solvent Wt. 0.0004g

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0019	0.0026 D-6	0.0016		
--	--------	------------	--------	--	--

LSC-03.GR



EPA Method 5 Data Reporting Sheet
Probe/Cyclone Wash

Job US Steel / Minntrac Source No. 5 Pelletsizer
Team Leader SLB Test Site Stack
Date Submitted 4-28-93 Date of Test 4-28-93
Test No. 5 No. of Runs Completed 3
Date of Analysis 4-30-93 Technician B. Duke
Transport Leakage ☒ None ☐ _____ ml Solvent Acetone

0	Test <u>Run 0</u> Field Blank Log Number _____ Vol. of Solvent _____ ml *Solvent Residue <u>2.0</u> ug/ml	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
1	Test <u>5</u> Run <u>1</u> Vol. of Solvent <u>180</u> ml Log Number <u>8678-41</u> Comments _____	Dish No. <u>17</u> Dish Tare Wt. <u>48.3906</u> g Dish+Sample Wt. <u>48.3961</u> g Sample Wt. <u>0.0055</u> g
2	Test <u>5</u> Run <u>2</u> Vol. of Solvent <u>150</u> ml Log Number <u>-45</u> Comments _____	Dish No. <u>27</u> Dish Tare Wt. <u>52.4480</u> g Dish+Sample Wt. <u>52.4569</u> g Sample Wt. <u>0.0089</u> g
3	Test <u>5</u> Run <u>3</u> Vol. of Solvent <u>120</u> ml Log Number <u>-49</u> Comments _____	Dish No. <u>37</u> Dish Tare Wt. <u>49.4981</u> g Dish+Sample Wt. <u>49.5071</u> g Sample Wt. <u>0.0090</u> g
4	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g
5	Test _____ Run _____ Vol. of Solvent _____ ml Log Number _____ Comments _____	Dish No. _____ Dish Tare Wt. _____ g Dish+Sample Wt. _____ g Sample Wt. _____ g


*Solvent Residue _____ ug/ml = [(Sample Wt. _____ g) (10⁶)] / Vol. of Sol. _____ ml
EPA-M5 Acetone Residue Blank Spec. { 7.8 ug/ml

Results:

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0051	0.0086	0.0086		
--	--------	--------	--------	--	--

LSC-01YR



EPA Method 5 Data Reporting Sheet
Filter Gravimetrics

Job U.S. Steel / Minntac Source No. 5 Pelletizer
Team Leader S+B Test Site Stack
Date Submitted 4-28-93 Date of Test 4-28-93
Test No. 5 No. of Runs Completed 3
Date of Analysis 4-30-93 Technician A. Dulac

Test <u> </u> Run <u>0</u>	Filter No. <u> </u>
Field Blank	Filter Type <u> </u>
Log Number <u> </u>	Filter Tare Wt. <u> </u> g
Comments <u> </u>	Filter+Sample Wt. <u> </u> g
	Sample Wt. <u> </u> g
Test <u>5</u> Run <u>1</u>	Filter No. <u>5119</u>
Log Number <u>8678-42</u>	Filter Type <u>4" GF</u>
Comments <u> </u>	Filter Tare Wt. <u>.8778</u> g
	Filter+Sample Wt. <u>.8916</u> g
	Sample Wt. <u>0.0138</u> g
Test <u>5</u> Run <u>2</u>	Filter No. <u>5120</u>
Log Number <u>-46</u>	Filter Type <u>4" GF</u>
Comments <u> </u>	Filter Tare Wt. <u>.8854</u> g
	Filter+Sample Wt. <u>.8952</u> g
	Sample Wt. <u>0.0098</u> g
Test <u>5</u> Run <u>3</u>	Filter No. <u>5121</u>
Log Number <u>-50</u>	Filter Type <u>4" GF</u>
Comments <u> </u>	Filter Tare Wt. <u>.8825</u> g
	Filter+Sample Wt. <u>.8965</u> g
	Sample Wt. <u>0.0140</u> g
Test <u> </u> Run <u> </u>	Filter No. <u> </u>
Log Number <u> </u>	Filter Type <u> </u>
Comments <u> </u>	Filter Tare Wt. <u> </u> g
	Filter+Sample Wt. <u> </u> g
	Sample Wt. <u> </u> g
Test <u> </u> Run <u> </u>	Filter No. <u> </u>
Log Number <u> </u>	Filter Type <u> </u>
Comments <u> </u>	Filter Tare Wt. <u> </u> g
	Filter+Sample Wt. <u> </u> g
	Sample Wt. <u> </u> g

Results:


Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0138	0.0098	0.0140		
--	--------	--------	--------	--	--

Field Blk. Run 1 Run 2 Run 3 Run 4 Run 5

	0.0208	0.0210	0.0242		
--	--------	--------	--------	--	--

LSC-02PR



Interpoll Laboratories
(612) 786-6020


Chain of Custody
Sample Deposition Sheet

Job 46 Sp. 4 MINNIA Source No. 5 Selection
Team Leader SLB Test Site STATIC
Date Submitted 4-28-93 Date of Test 4-28-93
Test No. 5 No. of Runs Completed 3

No. of Samples	Type of Sample	Analysis Required	Comments
3	Probe Wash: ☒ Acetone ☐ D.I. Water	☒ As per EPA M-5 ☐ Other _____	
3	Filter: ☒ 4" G.F. ☐ S.S. Thimble ☐ 2.5" G.F. ☐ 47 mm G.F.	☒ As per EPA M-5 ☐ As per EPA M-17 ☐ Other _____	
3	Impinger Catch: ☒ D.I. Water ☐ 3% H ₂ O ₂ ☐ 4M5 Hg Only ☐ 4M5 Metals ☐ 1.0 N NaOH ☐ Other _____	☒ EPA Protocol ☐ WI Protocol ☐ EPA M-6 or 8 ☐ Acid Gases ☐ Formaldehyde ☐ Metals ☐ Other _____	
3	Integrated Gas sample	☐ As per EPA M-3 ☐ As per EPA M-10 ☐ Other _____	
	Oxides of Nitrogen (NO _x)	☐ As per EPA M-7A ☐ Other _____	Date _____ Time (HRS) _____
	☐ Fuel Sample ☐ Aggregate	☐ Attached fuel Form #S-0163RRR	
	Particle Size	☐ X-Ray Sedigraph ☐ Bahco Method ☐ Other _____	
	Audit Samples ☐ Sulfur Dioxide ☐ Oxides of Nit. ☐ Other _____	☐ As per EPA M-6 ☐ As per EPA M-7A ☐ Other _____	

Source Information

- Type of Source: ☐ Boiler ☐ Asphalt Plant ☐ Incinerator ☐ Dryer
☒ Other Powerplant
- Fuel: ☐ Coal ☐ Wood ☒ Gas ☐ Oil ☐ RDF ☐ Other _____
- Is sample combustible? ☒ No ☐ Yes
- Does sample need special handling? ☒ No ☐ Yes If yes, explain _____



REQUIRED DATA
for
PROCESS EMISSIONS

Company Name US Steel Group

C. Equipment & Operating Data

1. Process Equipment No./Ident. Source No 8.22
2. Process Equipment Description Agglomerator Line 5
Waste Gas Stack
3. Process equipment operating under normal operating conditions?
No Yes ✓ Process rate during the test 475 LPH.
(raw materials or finished product)

D. Instrument Data on Process Equipment

1. Include copy of production records or instrumentation which indicates rate of production or operation of the equipment, i.e. units per hour, lbs. per hour, pressure, air flow, etc.

E. Air Pollution Control Equipment

1. Type/model of control equipment Multi-throat Scrubber
Air Tech MTS 600K
2. Air pressure drop across the control equipment 6" W.G.
3. Air flow through the control equipment 580,000 ACFM
4. Was the control equipment operating normally? Yes
5. Date of last major maintenance/cleaning of control equipment Feb '83
Clean-out

F. Plant Manager's Certification

I certify that the information submitted herein is accurate and correct and that no information requested was withheld from the Division Manager.

By M. Brincough, Position Major-Tech Serv.

Imb1770

REQUIRED DATA
for
PROCESS EMISSIONS

Company Name US Steel Group

C. Equipment & Operating Data

1. Process Equipment No./Ident. Source No. 8.21
2. Process Equipment Description Agglomerator Line 4
Waste Gas Stack
3. Process equipment operating under normal operating conditions?
No Yes ✓ Process rate during the test 498 LTPH.
(raw materials or finished product)

D. Instrument Data on Process Equipment

1. Include copy of production records or instrumentation which indicates rate of production or operation of the equipment, i.e. units per hour, lbs. per hour, pressure, air flow, etc.

E. Air Pollution Control Equipment

1. Type/model of control equipment Multi-Throat Scrubber
Air Tech MTS 600K
2. Air pressure drop across the control equipment 6" W.G.
3. Air flow through the control equipment 600,000 ACFM
4. Was the control equipment operating normally? Yes
5. Date of last major maintenance/cleaning of control equipment Jan '83 Clean-out

F. Plant Manager's Certification

I certify that the information submitted herein is accurate and correct and that no information requested was withheld from the Division Manager.

By N. Bransburgh, Position Mgr - Tech Serv.

lmb1770

1741.2

-40.1

364.8

48.0

738.0

1000.0

1000.0

1000.0

1000.0

1000.0

1000.0

1000.0

1000.0

1000.0

TURBINE 3411.7 30.5 98.7

T PULSE 5471.0

USS MINNTAC GAS CONSUMPTION 20-APR-1993 15104146.23

MAIN TURBINES 633.9 2069.2

FUEL CONSUMPTION HOUR 20-APR-1993 15:33:51.42

	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	150.4	45.0	19.8	674.0	0.0	0.0	0.0	0.0	0.0	0.0	674.0	32.8
LINE 4	88.9	70.9	0.0	-8121.0	0.0	0.0	-22797.4	-8120.0	0.0	0.0	-8120.0	88.9
LINE 5	117.8	47.2	21.1	1158.1	0.0	0.0	0.0	0.0	7.8	920.7	1030.5	4.0
LINE 6	0.0	67.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	239.9	46.5	18.4	607.8	0.0	0.0	0.0	0.0	0.0	0.0	607.8	76.4
UTIL	0.0	70.6	13.0									
CTAILS	0.0											

TOTAL 596.9 35.3 99.4 842.5 0.0 0.0 -22797.4 -8120.0 7.8 920.7 -2023.7

TURBINE 573.6 35.3 99.4

T PULSE 593.0

USS MINNTAC GAS CONSUMPTION 20-APR-1993 16104146.29

MAIN TURBINES 559.1 2640.6

FUEL CONSUMPTION HOUR 20-APR-1993 16:33:45.64

	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	157.2	45.8	19.7	710.0	0.0	0.0	0.0	0.0	0.0	0.0	710.0	33.6
LINE 4	101.2	0.0	0.0	-8056.6	0.0	0.0	-22989.0	-8058.0	0.0	0.0	-8058.0	101.2
LINE 5	144.8	50.8	21.0	917.5	0.0	0.0	0.0	0.0	7.0	713.2	769.1	53.7
LINE 6	0.0	68.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	243.8	47.4	18.4	617.0	0.0	0.0	0.0	0.0	0.0	0.0	617.8	76.0
UTIL	0.0	69.2	13.0									
CTAILS	0.0											

TOTAL 647.0 35.7 99.2 828.0 0.0 0.0 -22989.0 -8058.0 7.8 713.2 -1833.2

TURBINE 600.7 35.7 99.2

T PULSE 610.0

USS MINNTAC GAS CONSUMPTION 20-APR-1993 17104146.34

MAIN TURBINES 559.1 2640.6

FUEL CONSUMPTION HOUR 20-APR-1993 17:33:45.64

17:30

[illegible]

TURBINE	600.0	34.3	99.3
T PULSE	606.0		

USS MINNTAC BAG CONSUMPTION 28-APR-1993 18104:46.17

[illegible]

TURBINE	330.3	32.5	99.3
T PULSE	637.0		

USS MIANTAC GAS CONSUMPTION 28--APR-1993 17104146.55

HOUR		24 HOUR		HOUR 28-APR-1993 (12:31) 13.09													
MAIN TURBINES		660.0		4534.6													
FUEL CONSUMPTION		HOUR															
	GAS SHCF	GAS TEMP	GAS PRESS	SAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SHCF					
LINE 3	164.6	45.3	19.7	755.0	0.0	0.0	0.0	0.0	0.0	0.0	755.0	33.7					
LINE 4	133.1	34.3	23.1	1470.0	0.0	0.0	-16830.6	-8074.7	0.0	0.0	-5804.7	98.1					
LINE 5	228.9	44.9	21.0	616.1	0.0	0.0	0.0	0.0	0.0	0.0	616.1	74.8					
LINE 6	0.0	68.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					
LINE 7	249.3	47.9	18.3	630.5	0.0	0.0	0.0	0.0	0.0	0.0	630.5	76.3					
UTIL	0.0	67.3	13.0														
CTAILS	0.0																
TOTAL	775.9			721.4	0.0	0.0	-16830.6	-8074.7	0.0	0.0	-1147.7	282.9					

030-1	95 0.4
-2	104 -.0
-3	109 -1
-4	98 77
-5	102 0.3
TOTAL	509 77
PERCENT	16.1 0.0
FLX RATIO	0.082
CALCIUM	3.65
DEB D	5.2 4.5
SPEED	224 -10
AMPS	46 0.1
DEB D	3.5 4.1
SPEED	86 -1
AMPS	13 .0

NAME	DATE	TIME	IN	OUT
KEWIT	2084	1668		
SAIR	1929	750		
NWB-1A	960	292		
NWB-1B	964	292		
RECUP	1196	283		
DDII	1055	354		
DDI	606	246		
E.Z.	2383	2496		
1Aout	616	111		
1Bout	587	192		
NGin	104	65		
ClrST	889	116		
RecST	2125	206		
PRE H	5015	-563		
OUTSIDE		60.3		

W.G.	101	4.2
1A	57	-4
1B	45	0.2
3A	96	8.4
3B	74	11
CLrST	-5	106
Rec1A	-0	-1
Rec1B	-1	-1
259-	71	82
ST-UP	1	100
BI-1A	1	76
BI-1B	1	85
BP-1A	-4	83
BP-1B	-5	13
STACK	CAP	POS
	0	55

KKHOOD	-10	-0.7
DDIIF	1.6	-0.2
DDIUb	-11	-0.6
DDIIF	-1.1	-0.0
PPREF	-0.3	-1.0
PPREb	-1.3	0.0
CLR-1	11.1	0.7
CLR-2	5.9	0.1
REC S	-1.2	-0.1
WNG	3.3	1.1
1A	1.1	0.1
1B	1.9	1.1
INI T	229	208
INI T	265	194
OUT T	106	63.3
DIF P	10	5.0

UNIT	---	+++
MBTU	63	223
MCF/H	0.0	47
VALVE	32	21
PRESS	55	41
TEMP	1.8	9.6
BURMP	0.0	61
WOODZ	48	0
PHD Z	MAIN GAS:	
MSCFH	673	
TEMP	31.7	
PRESS	98.0	
203-1	43	61
-2	57	62
-3	48	50
-4	50	49
SCPE PH		9.8

BOILER UNIT 20
DATE 9/15/79

UNIT 20

030-1 103 0.9
-2 106 0.0
-3 95 -1
-4 97 77
-5 95 0.4
TOTAL 493 77
BENT 17.7 0.0
FLX RATIO .090
CALCIUM 3.57

BED D 5.6 4.5
SPEED 243 -10
AMPS 44 0.1
BED D 3.1 5.0
SPEED 72 -1
AMPS 13 -1

KEHIT 2067 1506
SAIR 1919 692
WB-1A 952 263
WB-1B 958 271
RECUP 1163 253
DDI 1031 327
DDI 614 229
B.Z. 2294 2353
1Aout 621 107
1Bout 587 177
WGin 104 57
ClrST 816 112
RecST 2125 181
PRE H 5015 -563
OUTSIDE 61.2

W.G. 101 4.2
1A 56 -4
1B 36 0.2
3A 98 8.4
3B 74 11
ClrST -5 104
Rec1A -0 -1
Rec1B -1 -1
259- 71 82
ST-UP 1 100
BI-1A 2 76
BI-1B 1 85
BP-1A -4 84
BP-1B -5 -1
STACK CAP POS 0 55

KHOOD -1.0 -0.6
DDIfr 1.6 -0.2
DDIwb -1.0 -0.6
DDIff -1.2 -0.0
PREff -0.04 -0.09
PREwb -1.2 0.0
CLR-1 11.9 0.8
CLR-2 5.7 0.1
REC-S -1.2 -0.1
WG 3.1 1.3
1A 1.0 0.1
1B 1.8 1.1
IN1 T 235 195
IN2 T 272 184
OUT T 106 61.4

MBTU --- +++
MCF/H 64 210
VALVE 0.0 43
PRESS 32 21
TEMP 73 43
BURNP 2.8 7.2
WOOD% 0.0 61
PHB % 48 0
MAIN GAS:
MSCFH 653
TEMP 32.6
PRESS 98.9
203-1 43 60
-2 57 60
-3 48 50
-4 50 49

14:25:39

03/20/33

030-1	97	69	KEXIT	2067	1588	W.G.	101	23	KHOOD	-.12	-.03	MBTU	---	908
-2	105	68	SAIR	1909	777	1A	63	17	DDIFF	1.7	-0.1	MCF/H	66	188
-3	104	72	WB-1A	962	369	1B	41	16	DDIwb	-11	-5.6	VALVE	0.1	38
-4	99	0.9	WB-1B	960	315	3A	102	2.8	DDIFF	-1.2	-0.1	PRESS	32	21
-5	93	0.3	RECUP	1177	233	3B	74	40	PREFR	-.03	-.08	TEMP	79	44
TOTAL	497	211	DDII	1040	281	CL1ST	-5	105	PREFR	-1.3	-3.3	BURNP	3.6	5.5
BENT	16.9	30.6	DDI	610	231	Rec1A	-0	-1	CLR-1	11.9	1.9	WOOD%	0.0	61
FLX RAT	10.088		B.Z.	2373	2378	Rec1B	-1	-1	CLR-2	5.4	0.1	PHB %	48	0
CALCIUM	3.49		1Aout	623	252	259-	71	82	REC-S	-1.2	-0.1	MAIN GAS:		
BED D	5.2	4.0	1Bout	582	221	ST-UP	1	100	WG	3.5	1.3	MSCFH	630	
SPEED	234	57	WGin	105	69	BI-1A	1	0	1A	1.0	1.6	TEMP	32.8	
AMPS	45	46	CL1ST	845	107	BI-1B	1	1	1B	1.9	1.8	PRESS	98.1	
BED D	3.5	2.9	RECST	2125	167	BP-1A	-4	84	IN1 T	230	185	203-1	43	60
SPEED	86	77	PRE H	5016	-563	BP-1B	-5	-1	IN2 T	265	175	-2	57	61
AMPS	16	15	OUTSIDE	60.1		STACK CAP	POS		OUT T	106	73.4	-3	48	50
						-0	-1		DIF P	10.5	4.3	-4	50	49
									SCRB PH					9.8

0 000000 000000
000000 000000

000000

000000

030-1 94 70
-2 93 71
-3 100 78
-4 94 65
-5 100 0.3
TOTAL 490 280
BENT 17.1 22.4
FLX RATIO 0.081
CALCIUM 3.38

000000

BED D 5.5 4.5
SPEED 230 93
AMPS 44 44

000000

BED D 3.6 2.5
SPEED 90 37
AMPS 16 15

000000

KEXIT 2060 1847
SAIR 1922 1115
WB-1A 972 935
WB-1B 965 911
RECUP 1189 647
DDI 1051 567
DDI 616 455
B.Z. 2407 2386
1Aout 628 461
1Bout 589 487
WGin 105 88
ClrST 870 287
RecST 2125 640
PRE H 5015 -563
OUTSIDE 60.3

000000

W.G. 101 40
1A 60 27
1B 42 33
3A 102 18
3B 74 58
ClrST -5 105
Rec1A -0 -1
Rec1B -1 -1
259- 71 82
ST-UP 1 100
BI-1A 2 0
BI-1B 1 1
BP-1A -4 85
BP-1B -5 -1

STACK CAP POS
-0 -1

000000

KHOOD -.11 -.02
DDI 1.8 0.0
DDI 11 -9.0
DDI 1.2 -0.0
PREFF -.03 0.22
PREMB -1.5 -8.1
CLR-1 12.2 9.7
CLR-2 5.9 0.1
REC-S -1.2 -0.1

IN1 T 232 227
IN2 T 268 219
OUT T 106 93.4

000000

MBTU --- 835
MCF/H 63 70
VALVE 0.1 21
PRESS 32 21
TEMP 79 47
BURNP 3.3 -.7
WOODZ 0.0 61
PHB % 48 0
MAIN GAS:

000000

MSCFH 528
TEMP 36.7
PRESS 99.0

000000

203-1 43 59
-2 57 61
-3 48 50
-4 50 49

000000

04/28/93

15:31:23

030-1 100 73
-2 116 63
-3 104 71
-4 44 72
-5 104 73
TOTAL 516 351
BENT 17.4 15.9
FLX RATIO 0.080
CALCIUM 3.59
BED D 5.7 4.3
SPEED 230 125
AMPS 44 49
BED D 3.4 3.0
SPEED 83 61
AMPS 14 15

KEXIT 2083 1749
SAIR 1926 1390
WB-1A 957 947
WB-1B 953 888
RECUP 1190 445
DDI 1058 452
DDI 615 489
B.Z. 2428 2373
1Aout 625 489
1Bout 582 514
WGIN 105 94
CIRST 896 113
RecST 2125 230
PRE H 5015 -563
OUTSIDE 62.9

W.G. 101 96
1A 59 32
1B 35 66
3A 101 43
3B 74 58
CIRST -5 103
Rec1A -0 -1
Rec1B -1 -1
259- 71 82
ST-UP 1 101
BI-1A 2 0
BI-1B 1 1
BP-1A -4 87
BP-1B -5 -1
STACK CAP POS 0 -1

KHOOD -.06 -.02
DDIFr 1.8 -0.2
DDIub -11 -16
DDIIF -1.2 -0.1
PREFr -.02 0.07
PREUb -1.1 -13
CLR-1 12.4 19.7
CLR-2 5.8 0.1
REC-5 -1.1 -0.1
WG 3.2 1.7
1A 0.8 3.0
1B 1.9 2.4
IM1 T 233 229
IM2 T 268 228
OUT T 106 95.2
Dif P 10.5 10.5

MBTU --- 862
MCF/H 63 90
VALVE 0.2 16
PRESS 32 22
TEMP 79 51
BURMP 3.2 -.7
WOODZ 0.0 61
PHB Z 48 0
MAIN GAS:
MSCFH 569
TEMP 37.0
PRESS 99.5
203-1 43 60
-2 58 60
-3 48 50
-4 50 49
SCOR PH 9.6

WIRELESS TELETYPE
DATE 04/20/70

04 00000

04 00000

030-1 104 88
-2 102 90
-3 100 106
-4 93 88
-5 102 109
TOTAL 498 477
BENTIS.7 16.9
FLX RATIO.030
CALCIUM 3.51
BED D 5.4 4.6
SPEED 241 185
AMPS 47 51
BED D 3.3 2.6
SPEED 81 52
AMPS 13 14

KEXIT 2041 1876
SAIR 1906 1500
NB-1A 983 872
NB-1B 979 825
RECUP 1255 546
DDII 1098 498
DDI 618 491
B.Z. 2141 2364
1Aout 630 471
1Bout 603 518
NGin 104 97
ClrST 909 114
RecST 2125 364
PRE H 5015 -563
OUTSIDE 62.0

W.G. 101 101
1A 57 59
1B 45 66
3A 95 37
3B 74 58
ClrST -5 105
Rec1A -0 -1
Rec1B -1 -1
259- 71 82
ST-UP 1 101
BI-1A 1 0
BI-1B 1 1
BP-1A -4 87
BP-1B -5 -1

STACK CAP POS
0 -1

KHOOD -.11 -.01
DDIfr 1.8 0.3
DDIwb -7.9 -17
DDIff -1.2 -0.1
PREff -.02 0.10
PREwb -1.4 -17
CLR-1 11.5 17.7
CLR-2 6.1 0.1
REC-S -1.2 0.0
WG 3.0 1.6
1A 0.8 2.9
1B 1.9 2.8

IN1 T 235 205
IN2 T 273 212
OUT T 106 98.5

NBTU --- ++
MCF/H 64 41
VALVE 0.1 14
PRESS 32 21
TEMP 79 50
BURMP 4.7 -7
WOODX 0.0 61
PHB Z 48 0
MAIN GAS:
MSCFH 574
TEMP 33.4
PRESS 100
203-1 43 60
-2 59 60
-3 48 50
-4 50 49

— 10 —

செய்து கொடுத்திருக்கிறார்கள். அந்த நேரத்தில் எல்லா மனிதர்களும் தங்களுடைய உரிமைகளைப் பற்றித் தெரிந்துகொள்ள வேண்டும். அதற்காகவே இப்போது இந்தக் கருத்தியோக்கைச் செய்கிறோம்.

030-1 97 100
-2 103 96
-3 100 101
-4 93 96
-5 100 99

TOTAL	492.433
BENT	16.915.8
FLX RATIO	0.078
CALCULUM	3.59

BED D	5.0	4.5
SPEED	234	193
AMPS	44	48

RED	3.5	1.9
SPEED	96	45
AMPS	13	13

THE

WKEWIT	2085	1902
SSAIR	1927	1410
WB-1A	966	942
WB-1B	969	881
RECUF	1208	712
DDII	1078	610
DDI	619	512
B.Z.	2454	2361
1Bout	625	511
1Bout	594	528
WGIn	105	98
ClrST	870	114
RecST	2125	605
PRE H	5015	-563
OUTSIDE		61.5

THE NEW YORK PUBLIC LIBRARY

W.G.	101	101
1A	44	51
1B	31	66
3A	101	56
3B	74	58
CI-ST	-5	105
Rec1A	0	-1
Rec1B	-1	-1
259-	71	82
ST-UP	1	101
BI-1A	1	1
BI-1B	1	1
BP-1A	-4	89
BP-1B	-5	-1

STACK CAP POS -0 -1

2000年12月10日

ENH000	-0.6	0.06
DDIFF	1.0	0.2
DDIwb	-3.8	-16
DDIIF	-1.2	-0.1
PREFR	-0.1	-0.03
PREwb	-1.2	-14
CLR-1	11.8	23.8
CLR-2	5.9	0.1
REC-5	1.1	-0.1
NG	3.8	1.4
1A	0.8	3.1
1B	1.8	2.8

IM1	T	238	215
IM2	T	275	220
OUT	T	106	99.9
DIF	P	10.5	10.4

THE
FUTURE
OF
THE
FUTURE
OF
THE
FUTURE

MBTU	---	843
MC/F/H	49	251
VALVE	0.0	81
PRESS	32	21
TEMP	79	47
BURNP	4.4	14
WOOD%	0.0	61
PHB %	48	0
MAIN GAS:		

MSCFH	768
TEMP	31.6
PRESS	98.6

SCRB PH	203-1	2	3	4	SCRB PH
9.6	43	58	48	50	9.6
60	60	60	50	49	60

DIAGRAM NUMBER: 2020 V10 100
 DATE: 04/28/93

04/28/93 12:04:51

030-1 95 93	KEXIT 2069 1954	W.G. 101 60	KHOOD -.07 -.01	MBTU --- 641
-2 103 90	SAIR 1932 1694	1A 42 19	DDIFF 0.9 -0.3	MCF/H 46 49
-3 107 97	WB-1A 968 969	1B 35 56	DDIub -11 -13	VALVE 0.1 15
-4 92 100	WB-1B 972 958	3A 99 30	DDIIF -1.3 -0.1	PRESS 32 21
-5 102 99	RECUP 1214 1265	3B 74 58	PREFR -.03 0.04	TEMP 79 51
TOTAL 501 479	DDII 1085 984	CLrST -5 105	PREFB -1.3 -12	BURNP 4.6 -.7
BENT 16.3 16.2	DDI 619 546	Rec1A 0 -1	CLR-1 11.8 17.3	WOODZ 0.0 61
FLX RATIO 0.078	B.Z. 2397 2378	Rec1B -1 -1	CLR-2 5.8 0.1	PHB Z 48 0
CALCIUM 3.65	1Aout 625 517	259- 71 82	REC-S -1.2 -0.2	MAIN GAS:
	1Bout 598 586	ST-UP 1 101		MSCFH 571
BED D 4.8 4.5	NGin 105 99	BI-1A 2 0	WG 4.0 1.3	TEMP 35.7
SPEED 225 190	CLrST 892 696	BI-1B 1 1	1A 0.7 3.0	PRESS 99.9
AMPS 42 47	RecST 2125 1315	BP-1A -4 90	1B 1.9 2.6	DENSITY:
	PRE H 5015 -563	BP-1B -5 -1		203-1 43 60
BED D 3.5 2.8	OUTSIDE 63.7		IN1 T 239 263	-2 58 60
SPEED 86 100		STACK CAP POS	IN2 T 278 261	-3 48 50
AMPS 13 14		0 -1	OUT T 107 101	-4 50 49
				203-1 43 60

DIAGRAM NUMBER: 2225 VOLUME: 5
DATE: 01/28/79 TITLE: 11012-20

4 1 11 20

01 00 00

030-1 88 185

-2 181 92

-3 105 185

-4 92 93

-5 98 98

TOTAL 490 487

BENT 17.1 16.1

FLX RATIO 0.78

CALCIUM 3.48

BED D 4.9 4.5

SPEED 229 197

AMPS 44 50

BED D 3.3 2.6

SPEED 86 93

AMPS 15 13

KEXIT 2880 1922

SAIR 1932 1774

WB-1A 969 953

WB-1B 972 924

RECUP 1197 1194

DDI 1067 912

DDI 615 546

B.Z. 2442 2393

1Aout 629 524

1Bout 593 582

WGin 105 100

ClrST 865 249

RecST 2125 1160

PRE H 5015 -563

OUTSIDE 62.7

W.G. 101 69

1A 54 22

1B 36 66

3A 96 40

3B 74 58

ClrST -5 105

Rec1A 0 -1

Rec1B -1 -1

259- 71 82

ST-UP 1 101

BI-1A 1 0

BI-1B 1 1

BP-1A -4 88

BP-1B -5 -1

STACK CAP POS

0 -1

KHOOD -0.0 0.00

DDIFF 1.4 -0.1

DDIMB -9.1 -14

DDIIF -1.2 -0.1

PREFF -.03 -.01

PREMB -1.4 -11

CLR-1 12.2 20.4

CLR-2 6.0 0.1

REC-S -1.2 -0.2

WG 4.1 1.2

1A 0.8 3.0

1B 1.8 2.5

IM1 T 236 247

IM2 T 275 247

OUT T 107 102

DIF P 10 5 9 1

MBTU --- 719

MCF/H 78 66

VALVE 0.1 18

PRESS 32 21

TEMP 79 51

BURNP 4.0 -.7

WOODZ 0.0 61

PHB Z 48 0

MAIN GAS:

MSCFH 592

TEMP 33.8

PRESS 99.6

203-1 43 60

-2 58 61

-3 48 50

-4 50 49

SCPP PH 9 5

Figure 1 is a schematic representation of the experimental design. It shows a sequence of steps: 1. A subject is shown in a box labeled 'Subject'. 2. An arrow points to a box labeled 'Stimulus'. 3. An arrow points to a box labeled 'Response'. 4. An arrow points to a box labeled 'Feedback'. 5. An arrow points to a box labeled 'Next trial'. 6. An arrow points to a box labeled 'End of session'.

MBTU	---	600
MCF/H	85	151
VALVE	0.0	30
PRESS	32	21
TEMP	79	48
BURAP	2.9	1.9
WOOD%	0.0	61
PHB %	48	0
MAIN GAS:		
MSCFH		678
TEMP		30.3
PRESS		99.0
203-1 43 61		
-2 59 60		
-3 48 50		
-4 50 49		

DIAGRAM NUMBER: 2526 VOLUME: 9
DATE: 04/26/93 TIME: 10:00:00

18:01:01

04/28/93

030-1 96 106
-2 104 93
-3 98 108
-4 105 109
-5 96 103
TOTAL 501 518
BENT 16.4 16.2
FLX RATIO 0.077
CALCIUM 3.56
BED D 4.9 5.0
SPEED 245 205
AMPS 44 52
BED D 3.3 2.4
SPEED 87 93
AMPS 13 13

KEXIT 2089 1900
SAIR 1940 1810
WB-1A 937 959
WB-1B 937 923
RECUP 1190 1285
DDII 1067 966
DDI 609 547
B.Z. 2376 2368
1Aout 609 528
1Bout 583 581
WGin 105 101
CLrST 844 310
RecST 2125 1255
PRE H 5015 -563
OUTSIDE 60.7

W.G. 101 72
1A 53 22
1B 35 66
3A 100 40
3B 74 58
CLrST -5 105
Rec1A 0 -1
Rec1B -1 -1
259- 71 82
ST-UP 0 101
BI-1A 1 0
BI-1B 1 1
BP-1A -4 88
BP-1B -5 -1
STACK CAP POS
0 -1

KHOOD -.05 0.00
DDIfr 1.0 -0.2
DDIwb -4.0 -15
DDIIF -1.2 -0.2
PREfr -.03 -.02
PREwb -1.2 -12
CLR-1 12.1 20.8
CLR-2 5.2 0.1
REC-S -1.2 -0.2
WG 3.9 1.1
1A 1.0 3.0
1B 1.8 2.3
IN1 T 235 250
IN2 T 269 251
OUT T 107 103
Diff P 10.5 9.4

MBTU --- 589
MCF/H 85 159
VALVE 0.2 31
PRESS 32 21
TEMP 79 45
BURNP 3.8 2.4
WOODZ 0.0 61
PHB Z 48 0
MAIN GAS:
NSCFH 680
TEMP 28.5
PRESS 99.5
203-1 43 60
-2 59 59
-3 48 50
-4 50 49
SCRB PH 9.5

DIAGRAM NUMBER: 2026 VL-10000
 DATE: 04/26/90

0000000000

0000000000

0000000000

030-1 92 98
 -2 98 88
 -3 95 95
 -4 95 91
 -5 99 92
 TOTAL 481 462
 BENT 17.2 16.6
 FLX RATIO 0.072
 CALCIUM 3.62
 BED D 5.3 4.5
 SPEED 232 195
 AMPS 43 51
 BED D 3.6 2.7
 SPEED 88 97
 AMPS 14 13

KEWIT 2138 1916
 SAIR 1945 1823
 WB-1A 953 958
 WB-1B 958 916
 RECUP 1215 1306
 DDII 1074 993
 DDI 611 544
 B.Z. 2387 2374
 1Aout 617 526
 1Bout 588 575
 WGIN 106 101
 CLFST 840 233
 RECST 2125 1260
 PRE H 5015 -563
 OUTSIDE 56.3

W.G. 101 76
 1A 57 22
 1B 40 66
 3A 102 38
 3B 74 58
 CLFST -5 105
 REC1A 0 -1
 REC1B -1 -1
 259- 71 82
 ST-UP 1 101
 BI-1A 1 0
 BI-1B 1 1
 BP-1A -4 88
 BP-1B -5 -1
 STACK CAP POS 0 -1

XHOOD -.05 -.01
 DDIFR 1.7 0.3
 DDILUB -4.3 -16
 DDILF -1.3 -0.2
 PREFR -.04 -.04
 PREWB -1.3 -12
 CLR-1 12.2 19.8
 CLR-2 4.9 0.1
 REC-S -1.2 -0.2
 WG 3.9 1.1
 1A 0.9 3.0
 1B 1.8 2.1
 IN1 T 234 246
 IN2 T 268 248
 OUT T 108 103

MBTU 464 622
 MCF/H 109 163
 VALVE 27 32
 PRESS 24 21
 TEMP 50 43
 BURNP 7.2 2.7
 WOODZ 0.0 61
 PHB Z 48 0
 MAIN GAS:
 MSCFH 810
 TEMP 23.3
 PRESS 98.5
 203-1 43 61
 -2 58 61
 -3 48 50
 -4 50 49

04/28/93

21:14:25

DIAGRAM NUMBER: 2026 VLINE: 9
DATE: 04/20/93

030-1 97 103
-2 98 89
-3 99 92
-4 97 105
-5 99 100
TOTAL 438 484
BENT 18.4 18.1
FLX RATIO 0.875
CALCIUM 3.53
BED D 5.2 4.6
SPEED 237 195
AMPS 47 45
BED D 3.6 2.8
SPEED 87 109
AMPS 16 14

KEXIT 2126 1916
SAIR 1913 1848
WB-1A 963 947
WB-1B 956 906
RECUP 1182 1323
DDI 1048 1030
DDI 611 539
B.Z. 2396 2375
1Rout 617 522
1Rout 587 567
WGin 106 100
ClrST 873 250
RecST 2125 1281
PRE H 5015 -563
OUTSIDE 47.3

W.G. 101 82
1A 55 30
1B 43 66
3A 89 40
3B 74 58
ClrST -5 105
Rec1A -0 -1
Rec1B -1 -1
259- 71 82
ST-UP 1 101
BI-1A 1 0
BI-1B 1 1
BP-1A -4 84
BP-1B -5 -1
STACK CAP POS
-0 -1

KHOOD -.07 -.01
DDIfr 2.0 -0.3
DDIwb -4.6 -16
DDIlf -1.2 -0.1
PREfr -.05 -.13
PREwb -1.6 -13
CLR-1 11.9 22.0
CLR-2 5.7 0.1
REC-S -1.1 -0.2
WG 3.9 1.0
1A 1.1 2.9
1B 1.9 2.7
IN1 T 231 240
IN2 T 265 243
OUT T 108 102
DIF P 10.5 9.4

MBTU 606 625
MCF/H 217 151
VALVE 47 29
PRESS 24 21
TEMP 39 41
BURMP 18 1.8
WOODZ 0.0 61
PHB Z 48 0
MAIN GAS:
MSCFH 870
TEMP 21.8
PRESS 97.9
203-1 43 60
-2 59 59
-3 48 50
-4 50 49
SCRB PH 9.5

Grandview Aluminum 26.5 VERSION: 0
DATE: 11/27/13 TIME: 11:12:18

04/20/2013 21:13:15

030-1 95 100		KENVIT 2086 1936		W.G. 101 75		KHOOD -.10 -.01		MBTU 555 643	
-2 99 94		SAIR 1897 1870		1A 60 22		DDIFF 1.9 -0.2		MCF/H 140 160	
-3 103 94		WB-1A 969 962		1B 44 66		DDIwb -7.6 -15		VALVE 33 30	
-4 90 92		WB-1B 966 930		3A 96 40		DDIff -1.2 -0.0		PRESS 24 21	
-5 96 95		RECUP 1164 1353		3B 74 58		PREff -.03 -.09		TEMP 39 40	
TOTAL 480 471		DDI 1036 1013		ClrST -5 104		PREwb -1.5 -12		BURNP 11 2.0	
BENT 18.1 17.9		DDI 606 547		Rec1A -0 -1		CLR-1 11.8 22.8		WOOD% 0.0 61	
FLX RATIO 0.075		B.2. 2360 2386		Rec1B -1 -1		CLR-2 6.3 0.1		PHB % 48 0	
CALCIUM 3.59		1Aout 618 625		259- 71 82		REC-S -1.1 -0.2		MAIN GAS:	
BED D 5.3 4.3		1Bout 584 579		ST-UP 1 101		WG 4.2 1.1		MSCFH 871	
SPEED 237 197		WGin 105 101		BI-1A 1 0		1A 1.2 3.0		TEMP 21.4	
AMPS 46 48		ClrST 883 196		BI-1B 1 1		1B 1.9 2.7		PRESS 97.8	
BED D 3.5 2.7		RecST 2125 1315		BP-1A -4 82		IN1 T 231 243		203-1 43 60	
SPEED 87 99		PRE H 5015 -563		BP-1B -5 -1		IN2 T 267 245		-2 57 60	
AMPS 12 13		OUTSIDE 45.9		STACK CAP POS		OUT T 108 103		-3 48 50	
								-4 50 49	

TURBINE 5411.7 30.3 98.7

T PULSE 5471.0

USS MINNTAC GAS CONSUMPTION 28-APR-1993 15:04:16.23

HOUR 24 HOUR

MAIN TURBINES 633.9 2069.2

FUEL CONSUMPTION HOUR 28-APR-1993 15:13:15.42

	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	150.4	45.0	19.8	674.0	0.0	0.0	0.0	0.0	0.0	0.0	674.0	32.8
LINE 4	88.9	78.9	0.0	-8121.0	0.0	0.0	-22797.4	-8120.0	0.0	0.0	-8120.0	88.9
LINE 5	117.8	47.2	21.1	1158.1	0.0	0.0	0.0	0.0	7.8	920.7	1030.5	4.0
LINE 6	0.0	67.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	239.9	46.5	18.4	607.8	0.0	0.0	0.0	0.0	0.0	0.0	607.8	76.4
UTIL	0.0	70.6	13.0									
CTAILS	0.0											
TOTAL	596.9			842.5	0.0	0.0	-22797.4	-8120.0	7.8	920.7	-2023.7	202.2

TURBINE 573.6 35.3 99.4

T PULSE 593.0

USS MINNTAC GAS CONSUMPTION 28-APR-1993 16:04:16.29

HOUR 24 HOUR

MAIN TURBINES 559.1 2640.6

FUEL CONSUMPTION HOUR 28-APR-1993 16:13:14.64

	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	157.2	45.8	19.7	710.0	0.0	0.0	0.0	0.0	0.0	0.0	710.0	33.6
LINE 4	101.2	0.0	0.0	-8036.5	0.0	0.0	-22909.0	-8038.0	0.0	0.0	-8038.0	101.2
LINE 5	144.8	50.8	21.0	117.5	0.0	0.0	0.0	0.0	7.8	713.2	769.1	53.7
LINE 6	0.0	68.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	243.8	47.4	18.4	617.8	0.0	0.0	0.0	0.0	0.0	0.0	617.8	76.0
UTIL	0.0	49.2	13.0									
CTAILS	0.0											
TOTAL	647.0			828.8	0.0	0.0	-22989.0	-8058.0	7.8	713.2	-1833.2	264.5

TURBINE 600.7 35.7 99.2

T PULSE 610.0

USS MINNTAC GAS CONSUMPTION 28-APR-1993 17:04:16.34

HOUR 24 HOUR

TEST #5

17.30

LINE 4	99.6	0.0	0.0	-8047.9	0.0	0.0	-22989.0	-8074.3	0.0	0.0	0.0	-8075.1	99.6
LINE 5	149.0	49.8	21.1	811.8	0.0	0.0	0.0	0.0	0.0	0.0	676.6	748.6	62.9
LINE 6	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	241.0	48.4	18.4	610.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	610.3	76.6
UTIL	0.0	0.0	13.0										
CTAILS	0.0												
TOTAL	642.9	34.3	99.5	816.5	0.0	0.0	-22989.0	-8074.3	7.0	676.6	-1817.2	272.5	

TURBINE 600.0 34.3 99.5

T PULSE 606.0

USS MINNTAC GAS CONSUMPTION 28-APR-1993 19104146.17

HOUR 24 HOUR

MAIN TURBINES 398.6 3837.8

FUEL CONSUMPTION HOUR 28-APR-1993 1913151.27

	GAS SHCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SHCF
LINE 3	156.7	46.5	19.7	707.1	0.0	0.0	0.0	0.0	0.0	0.0	707.1	33.6
LINE 4	104.0	0.0	0.0	-8023.8	0.0	0.0	-22989.0	-8037.4	0.0	0.0	-8037.8	104.0
LINE 5	177.8	50.1	21.0	684.2	0.0	0.0	0.0	0.0	5.4	638.0	676.2	79.8
LINE 6	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	245.8	48.1	18.3	622.6	0.0	0.0	0.0	0.0	0.0	0.0	622.6	76.3
UTIL	0.0	68.0	13.0									
CTAILS	0.0											
TOTAL	684.3	32.3	99.3	792.6	0.0	0.0	-22989.0	-8037.4	5.4	638.0	-1770.9	293.7

TURBINE 630.3 32.3 99.3

T PULSE 637.0

USS MINNTAC GAS CONSUMPTION 28-APR-1993 19104146.35

HOUR 24 HOUR

MAIN TURBINES 668.0 4534.6

FUEL CONSUMPTION HOUR 28-APR-1993 1913143.09

	GAS SHCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SHCF
LINE 3	164.6	45.3	19.7	755.0	0.0	0.0	0.0	0.0	0.0	0.0	755.0	33.7
LINE 4	133.1	34.3	23.1	1470.0	0.0	0.0	-16038.6	-8074.7	0.0	0.0	-5804.7	98.1
LINE 5	228.9	44.9	21.0	616.1	0.0	0.0	0.0	0.0	0.0	0.0	616.1	74.8
LINE 6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	249.3	47.9	18.3	630.5	0.0	0.0	0.0	0.0	0.0	0.0	630.5	76.3
UTIL	0.0	67.3	13.0									
CTAILS	0.0											
TOTAL	775.9	32.3	99.3	721.4	0.0	0.0	-16038.6	-8074.7	0.0	0.0	-1147.7	282.9

TURBINE 668.0 32.3 99.3

T PULSE 637.0

HOUR 24 HOUR

MAIN TURBINES 789.7 5333.5

FUEL CONSUMPTION HOUR 28-APR-1993/20:31:42.72

	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	167.8	43.3	19.7	756.8	0.0	0.0	0.0	0.0	0.0	0.0	756.8	33.6
LINE 4	232.7	42.5	24.0	611.5	0.0	0.0	0.0	0.0	0.0	0.0	605.8	105.8
LINE 5	251.4	41.7	21.0	671.2	0.0	0.0	0.0	0.0	0.0	0.0	671.2	92.8
LINE 6	0.0	68.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	249.2	47.8	18.3	631.4	0.0	0.0	0.0	0.0	0.0	0.0	631.4	76.5
UTIL	0.0	65.9	13.0									
CTAILS	0.0											
TOTAL	901.1			657.0	0.0	0.0	0.0	0.0	0.0	0.0	655.3	308.7

TURBINE 822.5 22.1 98.1

T PULSE 832.0

USS MINNTAC GAS CONSUMPTION 20-APR-1993 21:04:46.08

HOUR 24 HOUR

MAIN TURBINES 813.9 6141.8

FUEL CONSUMPTION HOUR 28-APR-1993/21:31:53.50

	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	132.6	43.6	19.7	2373.5	0.0	0.0	0.0	0.0	0.0	0.0	2373.5	7.4
LINE 4	222.8	39.1	23.7	584.8	0.0	0.0	0.0	0.0	0.0	0.0	579.6	90.4
LINE 5	234.3	40.3	21.0	624.0	0.0	0.0	0.0	0.0	0.0	0.0	624.0	79.0
LINE 6	0.0	67.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	247.6	47.3	18.3	628.5	0.0	0.0	0.0	0.0	0.0	0.0	628.5	76.0
UTIL	0.0	64.9	12.9									
CTAILS	0.0											
TOTAL	837.3			694.1	0.0	0.0	0.0	0.0	0.0	0.0	692.1	252.8

TURBINE 790.2 22.4 90.5

T PULSE 799.0

USS MINNTAC GAS CONSUMPTION 28-APR-1993 22:04:46.17

HOUR 24 HOUR

MAIN TURBINES 805.9 6955.0

LINE	TOT PRD TONS	PRODUCT LIPH	GRN BALL TOT TONS	BALL DRUM TOT TONS	BENT PER PRD TON1	BENT PER PRD TON2	BENT PER PRD TON3	BENT PER PRD TON4	BENT PER PRD TONS	BENT PER LBS/TON	BENTONIT TOT LBS
LINE 3	1557.70	195.26	2022.99	2110.91	18.02	14.54	11.35	12.43	12.19	53.65	28000.00
LINE 4	3040.98	303.82	3975.30	3964.20	14.67	12.40	13.07	12.79	15.91	15.91	53079.00
LINE 5	2765.07	346.46	3591.00	10564.40	15.39	10.74	1.39	7.92	16.47	16.23	48308.00
TOT/AVG	7383.76	330.03	9509.29	16639.51							129387.00

UNIT	GRATE OPR HRS	LN3-DRUM UPR HRS	LN4-DRUM OPR HRS	LN5-DRUM UPR HRS	FILT HRS 4-1T04-5	FILT HRS 5-1T05-5	FILT HRS 2-1T02-5	FILT HRS 2-6T02-7	TONS YD S1K-PILE	OUTSIDE TEMP
UNIT 1		7.58	7.99	7.99	4.44	7.99	0.00	0.00		
UNIT 2		7.58	7.99	7.99	0.00	0.00	0.00	0.00		
UNIT 3	7.26	7.10	7.99	7.99	7.99	7.99	0.00			
UNIT 4	7.99	7.22	7.99	7.99	0.00	7.99	0.00			
UNIT 5	7.99	7.99	7.99	7.08	7.99	5.64	0.00			
TOT/AVG	23.24	29.56	39.94	39.83	20.42	29.51	0.00	0.00		

UNIT	RECLAIM HRS	TON FROM RECLAIM	G.B. CON REJ TONS	UPR HRS ALL FILT	BALL DRUM TOT HRS	FILT TPH ALL FILT	TON FILT ALL FILT	TONS YD S1K-PILE	OUTSIDE TEMP
UNIT 1		0.00	0.00		29.56	4147.76	33068.00	0.00	56.64
UNIT 2		0.00	0.00	30.02	79.77	0.00	0.00	0.00	
TOT/AVG		0.00	0.00			4147.76	33068.00	0.00	

LINE	GAS STD MCF	PH NURR GAS SHCF	TURBINE GAS SHCF
LINE 3	1242.18	219.90	5546.39
LINE 4	1195.93	781.90	
LINE 5	1526.77	522.30	
TOT/AVG	3964.88	1523.70	5546.39

LINE	TOT PRD TONS	PRDUCT LPH	URN BALL TOT TONS	BALL DRUM TOT TONS	BENT PER PRD TON1	BENT PER PRD TON2	BENT PER PRD TON3	BENT PER PRD TON4	BENT PER PRD TON5	BENT PER LBS/TON	BENTONIT TOT LBS
LINE 3	5076.83	212.32	6593.20	6702.55	18.28	14.56	11.26	12.63	12.53	29.65	93089.00
LINE 4	9115.11	381.24	11837.01	11796.81	14.87	12.44	15.06	12.84	16.05	16.05	159418.00
LINE 5	7068.68	295.64	9180.10	25581.10	16.23	12.21	1.49	8.24	18.62	13.96	127698.00
TOT/AVG	21280.62	312.44	27611.19	44080.46							380205.00

GRATE	LN3-DRUM OPR HRS	LN4-DRUM OPR HRS	LN5-DRUM UPR HRS	FILT HRS 4-1TU4-5	FILT HRS 5-1TU5-5	FILT HRS 2-1TU2-5	FILT HRS 2-6TU2-7
UNIT 1	23.55	23.96	18.75	16.89	23.90	0.00	0.00
UNIT 2	23.54	23.96	10.75	10.90	0.00	0.00	0.00
UNIT 3	23.15	23.96	18.74	14.23	23.96	0.00	0.00
UNIT 4	23.19	23.96	18.36	0.00	23.96	0.00	0.00
UNIT 5	18.39	23.96	18.26	22.45	21.61	0.00	0.00
TOT/AVG	65.58	93.43	92.87	64.48	93.43	0.00	0.00

RECLAIM HRS	TON FROM RECLAIM	G.B. CON REJ TONS	OPN HRS ALL FILT	BALL DRUM TOT HRS	FILT TPH ALL FILT	TUN FILT ALL FILT	TON FILT CONC	TONS TO STK-PILE	OUTSIDE TEMP
UNIT 1	0.00	0.00	157.91	93.43	4161.47	99502.00	0.00	0.00	50.34
UNIT 2	0.00	0.00	212.65	0.00	0.00	0.00	0.00	0.00	0.00
TOT/AVG	0.00	0.00			4161.47	99502.00	0.00	0.00	

LINE	GAS STD MCF	PH BURN GAS SMCF	TURBINE GAS SMCF
LINE 3	3361.24	748.60	15875.82
LINE 4	3682.94	2124.20	
LINE 5	3641.50	1259.00	
TOT/AVG	10885.69	4131.80	15875.82

FUEL CONSUMPTION HOUR 28-APR-1993 22:33:46.79


LINE	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	UTIL GALLONS	UTIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	159.5	40.8	19.7	913.7	0.0	0.0	0.0	0.0	0.0	0.0	913.7	11.4
LINE 4	213.6	38.4	23.9	560.9	0.0	0.0	0.0	0.0	0.0	0.0	560.9	93.9
LINE 5	222.7	39.6	21.1	599.6	0.0	0.0	0.0	0.0	0.0	0.0	599.6	75.3
LINE 6	0.0	64.9	-0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LINE 7	235.1	45.7	18.2	642.3	0.0	0.0	0.0	0.0	0.0	0.0	642.3	77.6
UTIL	0.0	63.2	12.9									
CTAILS	0.0											
TOTAL	850.9			642.7	0.0	0.0	0.0	0.0	0.0	0.0	642.7	258.3

TURBINE 800.2 21.5 98.6

T PULSE 800.0

FUEL CONSUMPTION SHIFT 28-APR-1993 22:33:46.79

LINE	GAS SMCF	GAS TEMP	GAS PRESS	GAS MBTU/T	COAL TONS	COAL MBTU/T	OIL GALLONS	OIL MBTU/T	WOOD TONS	WOOD MBTU/T	TOTAL MBTU/T	PHB GAS SMCF
LINE 3	1242.2	44.6	19.7	797.4	0.0	0.0	0.0	0.0	0.0	0.0	797.4	219.5
LINE 4	1195.9	41.3	23.8	1010.0	0.0	0.0	-108623.0	-8042.8	0.0	0.0	-4541.3	781.0



Particulate Loadings and Emission Rates

The particulate emission rates were determined per EPA Methods 1-5, CFR title 40, Part 60, Appendix A (revised July 1, 1987). In this procedure, a preliminary velocity profile of the gases in the flue is obtained by means of a temperature and velocity traverse. On the basis of these values, sampling nozzles of appropriate diameter are selected to allow isokinetic sampling, a necessary prerequisite for obtaining a representative sample.

The sampling train consists of a heated glass-lined sampling probe equipped with a Type S pitot and a thermocouple. The probe is attached to a sampling module which houses the all-glass in line filter holder in a temperature controlled oven. In addition, the sampling module also houses the impinger case and a Drierite drying column. The sampling module is connected by means of an umbilical cord to the control module which houses the dry test gasmeter, the calibrated orifice, a leakless pump, two inclined manometers, and all controls required for operating the sampling train.

Particulate samples were collected as follows: The sample gas was drawn in through the sampling probe isokinetically and passed through a 4-inch diameter Gelman Type A/E glass fiber filter. The particulates were removed at this point and collected on the filter. The gases then passed through an ice-cooled impinger train and a desiccant-packed drying column which quantitatively absorb all moisture from the sample gas stream after which the sample gas passes through the pump and the dry test gasmeter which integrates the sample gas flow throughout the course of the test. A calibrated orifice attached to the outlet of the gasmeter provides instantaneous flow rate data.

A representative particulate sample was acquired by sampling for equal periods of time at the centroid of a number of equal area regions in the duct. The sampling rate is adjusted at each site such that an isokinetic sampling condition prevails. Nomographs are used to aid in the rapid determination of the sampling rate.

After sampling is complete, the filter is removed and placed in a clean container. The nozzle and inlet side of the filter holder are quantitatively washed with acetone and the washings are stored in a second container. A brush is often used in the cleaning step to help dislodge deposits. The samples are returned to the laboratory where they are logged in and analyzed. The volume of the acetone rinse ("probe wash") is noted and then the rinse is quantitatively transferred to a tared 120 cc porcelain evaporating dish and the acetone evaporated off at 97-105 OF. This temperature is used to prevent condensation of atmospheric moisture due to the cooling effect induced by the evaporation of acetone. The acetone-free sample is then transferred to an oven and dried at 105 OC for 30 minutes, cooled in a desiccator over Drierite, and then weighed to the nearest .01 mg. The filter sample is quantitatively transferred to a 6-inch watch glass and dried in an oven at 105 OC for two hours. The filter and watch glass are then cooled in a desiccator and the filter weighed to the nearest .01 mg. All weighings are performed in a balance room where the relative humidity is hydrostatted to less than 50% relative humidity. Microscopic examination of the samples is performed if any unusual characteristics are observed. The weight of the acetone rinse is corrected for the acetone blank. The Drierite column is weighed on-site and the water collected by Drierite is added to the condensate so that the total amount of absorbed water may be ascertained.

Integrated flue gas samples for Orsat analysis were collected simultaneously from the stack and from the breeching at the inlet to the wet scrubber. The samples were collected in 15-liter gas sampling bags at a constant flow rate throughout each particulate run. The bags were then returned to the laboratory and analyzed by Orsat analysis. Standard commercially prepared solutions were used in the Orsat analyzer (sat. KOH for carbon dioxide and reduced methylene blue for oxygen).

Condensible Organic Compounds Analysis

(State of Minnesota - MPCA Exhibit C)

Method II-8672-MN

Equipment: Separatory funnel - 500 cc with Teflon stopcock
 Powder funnel - 75 mm ID with a 17 mm stem
 Evaporating dish(es) - 200 cc or 250 cc beaker

Reagents: Diethyl ether - reagent grade
 Chloroform - reagent grade
 Sodium sulfate - (ACS) granular anhydrous
 Toluene - (if 3% hydrogen peroxide is used to collect the
 samples)
 Glass wool (Pyrex microfiber)

PREPARATION

1. Place 1 kg of granular anhydrous sodium sulfate in a shallow tray and heat to 200 °C for at least four hours. Store in a tightly sealed glass container.
2. Place a plug of clean glass wool in the stem of the powder funnel. The plug must be of sufficient size so that it is held snugly in place by its own pressure. Add a one-inch layer of dry sodium sulfate.

SAMPLING

An all-glass impinger assembly is used in the back half of the EPA Method 5 sampling train when an organic wet catch is to be collected. The impinger assembly consists of a modified impinger, a Greenburg Smith impinger followed by another modified impinger. The third impinger should have a temperature measuring device at the outlet upstream of a final impinger or desiccant column to monitor the temperature of the outlet gas stream. Prior to the start of the test, each of the first two impingers should be charged with 100 g of Class I water. The Method 5 train should be operated as provided for in EPA Method 5. Ice should be added to the impinger bath to keep the temperature of the gas at the outlet at or less than 68 °F. After the post test leak check, the impinger train is removed and impinger contents poured into a tared all-glass sample bottle and closed with a Teflon-lined cap. The sample bottle is then weighed and the total condensate calculated by subtraction of the bottle tare weight and the weight of initial water added to the impingers (200 g). A label is affixed and the sample is returned to the laboratory for analysis. The sample should be stored at 4 °C if the analysis is not conducted within 48 hours.

I. Organics

Caution! Work in vented hood!!!

A. Organic Blank Determination

1. Pour 125 mL of ethyl ether and 125 mL of chloroform into a tared beaker.
2. Evaporate solvent in hood at 70 °F or less until no solvent remains.
3. Desiccate the sample in dish for two hours.
4. Weigh the sample to nearest 0.1 mg, record and report on Form LSC-036.

B. Organic Sample Determination

1. Test for peroxide in sample ether using KI strips. (If KI strip shows positive, contact your supervisor before proceeding.)
2. Transfer the sample solution quantitatively to a 500 mL separatory funnel. Use the first of three 25 mL chloroform aliquots to rinse the sample container.
3. Extract with three 25 mL portions of chloroform. (Shake and vent to release pressure about 4 to 5 times each.) Allow the phases to separate. (Bottom layer is chloroform.) Draw off the bottom layer, transferring the solvent with a funnel containing a plug of sodium sulfate into a tared beaker. (Do not draw off any of the aqueous layer.)

4. After the three chloroform extractions, use two 25 mL portions of chloroform to rinse the sodium sulfate, collecting the rinses in the same tared beaker as the extracts.
5. Next extract the sample three times with 25 mL aliquots of ethyl ether. (Shake and vent to release pressure about 4 to 5 times each.) Allow the phases to separate. (Top layer is ethyl ether.) Draw off the bottom layer (aqueous) into another separatory funnel taking less than 1 mL of the ethyl ether layer with. Decant the ethyl ether, passing it through sodium sulfate and collecting the ethyl ether in the same tared dish as the chloroform.
6. After the three ethyl ether extractions, take two 25 mL portions of ethyl ether and rinse the sodium sulfate collecting the rinses in the same tared beaker as the extracts.
7. Evaporate the solvents (chloroform and ethyl ether) in the tared beaker in the hood at 70 °F or less until no solvent remains. (Use no heat and have no sources of ignition in the hood when doing this procedure.) Do not evaporate so quickly as to allow evaporative cooling to lower the temperature of the container below the dew point of water, otherwise, water will be condensed out in the container.
8. Desiccate to constant weight (two hours). Record and report the final weight to the nearest 0.1 mg on Form LSC-036.

II. Inorganics

If inorganic residue information is required, the following procedure should be conducted:

A. Inorganic Blank Determination

1. Vent the remaining aqueous phase from the organic extraction in the hood to remove residual organic solvents (usually overnight).
2. Decant the impinger catch into a tared evaporating dish.
3. Evaporate all of the water in the sample in an oven at 100 °C. Take care not to boil to prevent bumping and loss of sample.
4. Cool the dried sample in the desiccator and desiccate until a constant weight is obtained.
5. Report the results to the nearest 0.1 mg on Form LSC-036.

B. Inorganic Sample Determination

Follow steps 1-5 in Section A above.


NOTES

1. For the organics determination, in the rare event that the impinger catch resulted from a Modified Method 6 determination (SO_2), whereby the solution contains dilute hydrogen peroxide ($\geq 3\%$), do not use ether as an extraction solvent. Substitute toluene for ethyl ether in Section I. (Ether in the presence of peroxide forms explosive hydroperoxide.)
2. In the organics determination, more than three extractions may be required to extract all of the organics. Additional extractions should be performed if the aqueous phase is still cloudy.
3. Special state requirements:
Michigan - Total sample evaporated in tared evaporating dish on steam bath.
Iowa - Organics and inorganics separately, as required.
Wisconsin - Use Method II-8672-W1.
Rest of states - Organics only.

REFERENCES

Proposed Standards of Performance for New Stationary Sources, Federal Register 36(159) Part II, August 1, 1979.

Minnesota Pollution Control Agency, Exhibit C.



Particulate sampling train.

CALCULATION EQUATIONS

METHOD 2

$$\bar{V}_s = 85.48 C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

$$Q_{s,d} = 60(1 - B_{ws}) \bar{V}_s A \left(\frac{528}{T_{s(avg)}}\right) \left(\frac{P_s}{29.92}\right)$$

$$Q_a = 60 \bar{V}_s A$$

$$\dot{m}_g = \frac{4.995 Q_{s,d} G_d}{1 - B_{ws}}$$

$$RH^* = 100 (vp_{twb} + 0.0003641 P_s (T_{db} - T_{wb}))/vp_{tdb}$$

$$B_{ws}^* = RH(vp_{tdb})/P_s$$

$$= \frac{4.585 \times 10^{-2} P_s M_s}{T_s (avg)}$$

*Alternate equations for calculating moisture content from wet bulb and dry bulb data.

SYMBOLS

A	= Cross sectional area of stack, SQ. FT.
A _n	= Cross sectional area of nozzle, SQ. FT.
B _{ws}	= Water vapor in gas stream, proportion by volume
C _p	= Pitot tube coefficient, dimensionless
C _a	= Concentration of particulate matter in stack gas, wet basis, GR/ACF
C _s	= Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, GR/DSCF
EA	= Excess air, percent by volume
γ	= Dry test meter correction factor, dimensionless
G _d	= Specific gravity (relative to air), dimensionless
I	= Isokinetic variation, percent by volume
M _d	= Molecular weight of stack gas, dry basis, g/g - mole.
$\dot{m}_g$	= Mass flow of wet flue gas, LB/HR
$\dot{m}_p$	= Particulate mass flow, LB/HR
M _s	= Molecular weight of stack gas, wet basis, g/g, mole.
M _p	= Total amount of particulate matter collected, g
P _{bar}	= Atmospheric pressure, IN. HG. (uncompensated)
P _g	= Stack static gas pressure, IN. WC.