

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section	<u>12.2</u>
Reference	<u>4</u>
Report Sect.	<u>112</u>
Reference	

MASS EMISSION TESTS
CONDUCTED ON THE
BAGHOUSE FOR THE #9 BATTERY
IN
BIRMINGHAM, ALABAMA
FOR
U.S. STEEL
ON
AUGUST 18-21, 1980

TABLE OF CONTENTS

		Page
I.	Introduction	1
II.	Sampling and Analytical Procedures	2
III.	Test Results	
	Summary of Test Results	10
	Nomenclature	12
	Equations	15
	Detailed Results	17
	Back Half Analysis	27
IV.	Field Data	28
V.	Calibrations	36
Tables		
1	Tabular Test Results	11
Figures		
1	Sample Point Location	8
2	Particulate Sampling Train	9

INTRODUCTION

On August 18-21, 1980, Guardian Systems, Inc., conducted a series of mass emission measurements on the Wheelabrator-Frye Baghouse for the #9 Coke Battery located at Fairfield, Alabama. Measurements were made only during coke pushes. Each point tested represents one push.

The following personnel represented the companies listed below:

Pat Hester
Paul Thomas
Jerry Anderson
Clyde D. Kepple
Jim Manning
Tom Lotz
Mark Wilson
Don Lackey

U.S. Steel Corporation
U.S. Steel Corporation
U.S. Steel Corporation
Wheelabrator-Frye, Inc.
Environmental Protection Agency
Guardian Systems, Inc.
Guardian Systems, Inc.
Guardian Systems, Inc.

SAMPLING AND ANALYTICAL PROCEDURES

General

Stack temperature, pressure, range of velocity heads, and moisture content were determined to correctly set the nomograph and proper nozzle size for isokinetic sampling. The meter box was leak checked from the pump through the orifice as outlined in Method 5. The equipment used in this test was manufactured by Research Appliance Corporation and was properly calibrated before these tests (See Calibrations).

The stack was sampled at 24 points. The sample point location can be found in Figure 1.

Sampling Techniques

The particulate determinations were made by utilizing the sampling train in Figure 2. Initial and final leak checks of the sampling systems and pitot lines were performed as outlined in Method 5 and these were recorded on the individual data sheets. The nozzles were calibrated before and after each test using a micrometer and were also recorded on the individual data sheets.

The particulate samples were taken by sampling each point for 3 minutes. The gases were drawn through a heated glass lined probe. The probe heater was maintained at the proper setting to obtain an exit temperature of $248 \pm 25^{\circ}\text{F}$. (See Calibrations) The gases then passed through a glass cyclone for removing particulate matter approximately 10 microns and greater in size, then through a glass fiber filter (Gelman, Class A) of 0.3 microns retention to remove any remaining particulate matter. The cyclone and filter were maintained at a temperature of $248 \pm 25^{\circ}\text{F}$. The sample box temperatures were recorded at each point on the data sheets.

The gases then passed through four (4) Greenburg-Smith impingers. The first and second impingers contained 150 milliliters of distilled water each, while the third was empty and the fourth contained approximately 220 grams of indicating silica gel. These impingers were placed in an ice bath during the test to maintain a maximum exit temperature from the last impinger of 68°F . This temperature is also recorded on the data sheets. The clean and cool gases then entered the meter box where the gas flow and temperature was measured. (See data sheets)

Gas analysis for CO₂ and O₂ were determined for each run by using Fyrite Gas Analyzers. These samples were taken approximately five times during the testing sequence and were averaged. This was approved by Mr. Jim Manning. Particulate catches were placed in sealed petri dishes. The acetone washes of the nozzle, probe and cyclone were combined and placed in sealed containers also. For each run an acetone blank of approximately 300 milliliters was placed in a sealed container. These containers were transported to the laboratory for analysis. In our laboratory, the back-half train, (everything between and including the back-half of the filter holder to the third impinger) was prepared for analysis by first measuring the volume of liquid in the first three impingers and then transferring the liquid to a sample container. All parts of the back-half were rinsed with distilled water and the rinsings were added to the same sample container. The back half was again rinsed with acetone and these rinsings were placed in another container.

Analysis - Front-Half

The filters (Gelman, Class A, without organic binder, minimum 99.9% retention for particles of 0.3 microns as determined by DOP tests) were prepared for the field test by desiccating at $68 \pm 10^{\circ}\text{F}$ at ambient pressure for 24 hours and weighing at intervals of at least six (6) hours to a constant weight (less than 0.5 milligrams change from previous reading). Upon return to the laboratory, the filters were again subjected to the same procedures as outlined above. The weights are recorded in a bound laboratory book and were transferred to the laboratory sheets in this report. During each weighing the filter was not exposed to laboratory atmosphere for more than two (2) minutes and the relative humidity of the laboratory was less than fifty percent (50%).

The acetone washings, along with the acetone blank for the group of tests, were evaporated to dryness in tared glass beakers. They were then desiccated for twenty four (24) hours and weighed to a constant weight.

The moisture content was determined for each run by measuring the increase in the amount of water collected in the impingers and the increase in weight of the silica gel. These weights were combined to give the total amount of water collected.

Analysis - Back-Half

The water and water rinsings were first filtered, then extracted with ether and Chloroform. The organic portion was evaporated and weighed. The aqueous portion was evaporated and a sulfate analysis was performed on the residue. The acetone rinsings were evaporated and weighed. These weights were combined to determine total back-half catch. A more thorough procedure follows.

2. In addition to the analytical procedure found in EPA Method 5, the condensible materials found in the back-half (everything between and including the back-half of the filter holder to the third impinger) will be included in the test results. The following procedures and calculations apply only to the back-half of the sampling train:

(a) Procedures for back-half particulate analysis.

(i) Identify and desiccate for 24 hours sufficient filters to filter all liquid collectors and washings.

(ii) Weigh and record the weights of the filters in addition to the identification number.

(iii) Before filtering, measure to the nearest milliliter the volume of liquid in each impinger and record.

(iv) Place the impinger solutions in a labeled container and wash any residue in the impinger into the container using distilled water and a policeman.

(v) Add the water washings from the back half of the filter holder and interconnecting glassware to the container in (iv).

(vi) Wash the impingers and the components in step (iii) with acetone and place in a labeled container.

(vii) Filter the solutions from steps (iv) and (vi) using preweighed and identified millipore filters. Use suction on all filtering.

(viii) Measure the filtrate from (vii) to the nearest milliliter and record the volume.

(ix) Air dry, then desiccate for 24 hours all filters used in the above steps. Weigh to the nearest .1 mg. and record the weight. As an alternative, the filters can be oven dried at 105 degrees C for 2 hours, cooled in a desiccator, and weighed to a constant weight.

(x) Identify and dry for 2 hours at 105 degrees C as many 350 milliliter evaporating dishes as are needed to evaporate the filtrates. Then desiccate until cool and weigh to the nearest .1 mg. Record each weight with its identification number.

(xi) Take the filtrate from step (viii) and extract organic particulate using three 25 milliliter portions of chloroform and three 25 milliliter portions of ethyl ether. Combine the ether and chloroform extracts, and transfer to a tared beaker.

(1) Organic Portion - evaporate at about 70 degrees F until no solvent remains. Desiccate for 24 hours and weigh to a constant weight. Report the results to the nearest .1 mg.

Place a measured quantity of unused ether into a preweighed evaporating dish. This is the ether blank.

Do the same to obtain a chloroform blank. Record both weights to the nearest .1 mg.

(II) Water Portion - follow steps (xii) and (xiii) below.

(xii) Evaporate, using an evaporating dish prepared in (x), the filtrates from (xi)(II) and an equal amount of distilled water separately to constant weight at 105 degrees C. Desiccate the residue until cool and weigh to the nearest .1 mg. and record the weights.

(xiii). Perform a sulfate analysis (turbidimetric) of the impinger residue from step (xii). Follow steps as given in Standard Methods For the Examination of Water and Wastewater, 14th Edition, published by the American Public Health Association, Washington, D. C. 20036, pages 496 - 498.

(xiv) Transfer the acetone washing from step (vi) into a preweighed evaporating dish after measuring and recording the volume of acetone.

(xv) Place a measured quantity of unused acetone into a preweighed evaporating dish. This is the acetone blank.

(xvi) Evaporate both the blank (xiv) and unknowns (xiii) at less than 60 degrees C in a vacuum.

(xvii) Desiccate to constant weight and reweigh. Then, record the weight to the nearest .1 mg.

(b) Addendum to procedures for back-half particulate analysis.

(i) After filtration, the filters are to be handled carefully to prevent loss of material.

(ii) Store used filters in separate petri dishes for transportation.

(iii) When filtering using the Millipore filters, it may be necessary to start with an $.8\mu$ filter, then a $.45\mu$ filter, and finally a $.22\mu$ filter.

Millipore	$.22\mu$	Catalog #GSWP-047-00
	$.45\mu$	Catalog #HAWP-047-00
	$.80\mu$	Catalog #AAWP-047-00

(iv)

(I) Solvent/water blank concentration

$$C_a = \frac{m_a}{V_a \rho_a}$$

m_a = Mass of residue of solvent after evaporation

V_a = Volume of solvent or water blank

ρ_a = Density of solvent/water

C_a = Solvent/water concentration

(II) Solvent/Water wash blank

$$W_a = C_a V_{aw} \rho_a$$


W_a = Weight of solvent/water residue in solvent/water wash

V_{aw} = Volume of solvent/water wash blank

(c) Calculation of back-half particulate catch.


Determine the total back-half particulate catch from the sum of the weights obtained from steps (xi)(I), (xii), and (xvii) less the acetone, ether and chloroform blanks, and the sulfate determined from (xiii).

SAMPLE POINT LOCATION



Point #	Distance from Wall (inches)
1.	2.0
2.	6.4
3.	11.3
4.	17.0
5.	24.0
6.	34.1
7.	61.9
8.	72.0
9.	79.0
10.	84.7
11.	89.6
12.	94.0

Figure 1



PARTICULATE SAMPLING TRAIN... METHOD 5

SUMMARY OF TEST RESULTS

The following table is a summary of the tests performed for U.S. Steel Corporation on August 18-21, 1980. Four complete tests were run during the testing period. The first test was performed using a condenser instead of the impingers. Guardian Systems, Inc., was then requested by U.S. Steel to use impingers on the back half of the train. Therefore, the next three tests were done using impingers.

Sampling was done at each of the 24 points for three minutes at each point. Each sampling point contains one coke push. A representative from U.S. Steel with a radio would tell Guardian Systems, Inc., when they were ready to push. The technicians from Guardian would turn on and set the meter box and then the representative from U.S. Steel would tell the coke battery to go ahead and push the coke. The meter box was turned off at the end of 3 minutes until the next push. Therefore, each test consists of 24 coke pushes.

TABLE 1

TABULAR TEST RESULTS

Test Number	1	2	3	4	Average (Runs 2-4)
Type	Condenser	Imp.	Imp.	Imp.	
Date	8-18-80	8-19-80	8-20-80	8-21-80	
Time	7:45-2:14	7:49-2:27	7:09-2:08	7:38-4:11	
Moisture, %	2.78	2.67	2.71	2.66	2.68
Gas Temperature, °F	129	132	132	133	132
Gas Velocity	62.63	61.31	59.15	57.73	59.40
Volumetric Flow, ACFM	188,877	184,919	178,405	174,118	
Volumetric Flow, DSCFM	166,313	161,877	155,291	151,315	156,161
Concentration, grains/ACF	0.004	0.008	0.007	0.008	
Concentration, grains/DSCF	0.005	0.010	0.008	0.009	0.008
Emissions, lbs/hr	6.62	13.33	9.94	11.85	11.71
Coke Pushed, tons/test	324.0	324.0	324.0	324.0	324.0
Emissions, lbs/ton of coke pushed		0.05	0.04	0.04	0.04
Allowable, lbs/ton of coke pushed					0.03
Isokinetic, %	91.33	90.20	94.54	93.62	

NOMENCLATURE

ACF - Actual Cubic Feet

ACFM - Actual Cubic Feet per minute

ACM - Actual Cubic Meters

ACMS - Actual Cubic Meters per second

An - Cross sectional area of nozzle, (ft²)

As - Area of Stack, (ft²)

Bws - Water vapor in the gas stream, proportion by volume
(dimensionless)

Ca - Acetone blank residue concentration, mg/g

c_a - Particulate Concentration, ACF

CFM - Cubic feet per minute

Cp - Pitot tube coefficient, (dimensionless)

c_s - Particulate Concentration, grains/DSCF

Cso₂ - Concentration of sulfur dioxide (dry basis) corrected
to standard conditions, lb/DSCF

C₁₂ - Particulate concentration (c_s adjusted to 12% excess air),
grains/DSCF

C₅₀ - Particulate concentration (c_s adjusted to 50% excess air),
grains/DSCF

DSCF - Dry Standard Cubic Feet

DSCFM - Dry Standard Cubic Feet per minute

DSCM - Dry Standard Cubic Meters

DSCMS - Dry Standard Cubic Meters per second

EA - Excess Air, %

I - Isokinetic Sampling, %

Km - Orifice Correction Factor, (dimensionless)

Kp - Pitot tube constant, 85.49 $\left[\frac{(\text{lb/lb-mole})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right]^{1/2}$

NOMENCLATURE - continued

- La - Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to 0.02 CFM or 4 percent of the average sampling rate, whichever is less.
- Li - Individual leakage rate observed during the leak check conducted prior to the "ith" component change (i = 1,2,3,...n), CFM.
- Lp - Leakage rate observed during the post test leak check, ft³/min. (cfm).
- Ma - Mass of residue of acetone after evaporation, mg.
- Md - Molecular weight of stack gas; dry basis, lb/lb-mole.
- Mn - Total amount of particulate matter collected, mg.
- Ms - Molecular weight of stack gas; wet basis, lb/lb-mole.
- Mw - Molecular weight of water, 18.0 g/g-mole (18.01 lb/lb-mole)
- ΔP - Velocity head of stack gas, in. H₂O
- Pa - Density of acetone, mg/ml
- Pbar - Barometric pressure at the sampling site, in. Hg
- Pg - Stack static pressure, in. H₂O
- Pm - Meter pressure, in. Hg
- PMR - Particulate Mass Rate, lbs per hour
- Ps - Absolute stack pressure, in. Hg
- Pstd - Standard absolute pressure, 29.92 in. Hg
- Pw - Density of water, 0.9982 g/ml (0.002201 lb/ml)
- Qa - Volumetric flow rate, ACFM
- Qs - Volumetric flow rate, DSCFM
- R - Ideal gas constant, 0.06236 mm Hg - m³/°K-g-mole (21.85 in. Hg-ft³/°R-lb-mole)
- SCF - Standard Cubic Foot
- ta - Ambient Temperature, °F
- tm - Average Temperature of meter, °F
- ts - Average Temperature of stack, °F

NOMENCLATURE - continued

t_{std} - Standard Temperature, 68°F

NOTE: Capital "T" denotes degrees Rankin

V_a - Volume of acetone blank, ml

V_{aw} - Volume of acetone used in wash, ml

V_{lc} - Total volume of liquid collected in condenser and silica gel, ml

V_m - Volume of gas sample, as measured by the dry gas meter, ACF

V_{mc} - Volume of gas sample, corrected for leak, ACF

$V_m(std)$ - Volume of gas sample measured by the dry gas meter, corrected to standard conditions, DSCF

V_n - Volume collected at stack conditions through nozzle, ACF

V_s - Average stack gas velocity, ft/sec.

$V_w(std)$ - Volume of water in the gas sample, corrected to standard conditions, SCF

W_a - Weight of residue in acetone wash, mg

Y - Dry gas meter calibration factor, (dimensionless)

ΔH - Average pressure differential across the calibrated orifice, in. H_2O

ΔH_a - Value of ΔH measured for a specific orifice when operated under the following conditions: 0.75 cfm of dry air (M.W. = 29) at 68°F, 29.92 in. Hg.

$\sqrt{\Delta P}$ - Average of the square roots of the velocity pressure, in. H_2O

θ - Total sampling time, min.

θ_1 - Sampling time interval from the beginning of a run until the first component change, min.

θ_i - Sampling time interval between two successive component changes, beginning with the interval between the first and second changes, min.

θ_p - Sampling time interval from the final (n^{th}) component change until the end of the sampling run, min.

$\%CO_2$, $\%O_2$, $\%N_2$, $\%CO$ - Number percent (%) by volume (dry basis) of each compound in the stack gas.

EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_{m(\text{std})} = V_m Y \left(\frac{T_{\text{std}}}{T_m} \right)$$

$$\left[\frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{P_{\text{std}}} \right]$$

$$4. \quad V_w(\text{std}) = 0.04707 V_{lc}$$

$$5. \quad B_{ws} = \frac{V_w(\text{std})}{V_{m(\text{std})} + V_w(\text{std})}$$

$$6. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$7. \quad M_s = M_d (1 - B_{ws}) + 18(B_{ws})$$

$$8. \quad v_s = K_p C_p (\sqrt{\Delta p}) \text{ avg.}$$

$$\sqrt{\frac{T_s}{M_s P_s}}$$

$$9. \quad Q_a = (v_s) (A_s) (60)$$

$$10. \quad Q_s = Q_a (1 - B_{ws}) \left(\frac{528}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$

$$11. \quad c_s = [0.0154 (Mn/V_{mstd})]$$

$$12. \quad EA = \left[\frac{\%O_2 - 0.5 \%CO}{0.264 \%N_2 (\%O_2 - 0.5 \%CO)} \right] 100$$

$$13. \quad c_{50} = \frac{c_s}{1 - \left[\frac{(1.5)(\%O_2) - 0.133(\%N_2) - 0.75 (\%CO)}{21} \right]}$$

$$14. \quad c_{12} = c_s \frac{12}{\%CO_2}$$

EQUATIONS - continued

$$15. \quad PMR = (c_s)(Q_s) \left(\frac{60}{7000} \right)$$

$$16. \quad V_n = \frac{T_s}{P_s} \left[(0.002669)(V_{1c}) + \frac{V_m}{T_m} \left(P_{bar} + \frac{\overline{\Delta H}}{13.6} \right) \right]$$

$$17. \quad C_a = (0.0154)(M_n) / V_n$$

$$18. \quad I = \frac{100 V_n}{60 \theta v_s A_n}$$

$$19. \quad V_{mc} = V_m - (L_p - L_a) \theta$$

$$20. \quad W_a = C_a V_{aw} p_a$$

.....

1.	Run Number
0-18-80	Date
	30.27 Barometric Pressure (in. Hg.)
	- .38 Static Pressure (in. H ₂ O)
	72.00 Time (minutes)
	73.038 Meter Volume (corrected)
	129.00 Stack Temperature (°F)
	116.00 Meter Temperature (°F)
	3.60 Meter Pressure (in. H ₂ O)
	1.042 Sq. Root Velocity Pressure
	20.60 Mg of Particulate
	41.50 Ml of water condensed
	19.25 % O ₂
	.00 % CO ₂
	50.2656 Stack Area (Ft ²)
	.95 Pitot Correction Factor
	.000314 Nozzle Area (Ft ²)

1.	Stack Pressure
	30.24 Inches Hg
	768.10 Millimeters Hg
2.	Meter Pressure
	30.53 Inches Hg
	775.46 Millimeters Hg
3.	Meter Volume
	63.300 Dry Standard Cubic Feet
	1.934 Dry Standard Cubic Meters
4.	Water Volume
	1.953 Standard Cubic Feet
	.055 Standard Cubic Meters
5.	Moisture Content
	.0278 (Convert to % X 100)
6.	Molecular Weight Dry
	28.77
7.	Molecular Weight Wet
	28.47
8.	Stack Velocity
	62.63 Feet per Second
	19.09 Meters per Second
9.	Volumetric Flow
	188,577. Actual Cubic Feet per Minute
	59.1405 Actual Cubic Meters per Second
10.	Volumetric Flow
	166,313. Dry Standard Cubic Feet per Minute
	73.4914 Dry Standard Cubic Meters per Second
11.	Concentration
	.0045 Grains per Dry Standard Cubic Foot
	.0105 Grams per Dry Standard Cubic Meter
15.	Particulate Mass Rate
	6.62 Pounds per Hour
16.	Volume at Nozzle
	77.566 Actual Cubic Feet
	2.196 Actual Cubic Meters
17.	Concentration
	.0041 Grains per Actual Cubic Foot
	.0094 Grams per Actual Cubic Meter
18.	% Isokinetic
	91.33

.....

TOTAL

2. 8-19-80 Run Number
 ✓ 30.24 Date
 -.75 Barometric Pressure (in. Hg.)
 72.00 Static Pressure (in. H₂O)
 69.847 Time (minutes)
 132.00 Meter Volume (corrected)
 112.00 Stack Temperature (°F)
 3.30 Meter Temperature (°F)
 1.017 Meter Pressure (in. H₂O)
 40.95 Sq. Root Velocity Pressure
 38.30 Mg of Particulate
 19.50 Ml of water condensed
 .00 % O₂
 .00 % CO₂
 50.2656 Stack Area (Ft²)
 .85 Pitot Correction Factor
 .000314 Nozzle Area (Ft²)

1. Stack Pressure
 30.18 Inches Hg
 766.57 Millimeters Hg
 2. Meter Pressure
 30.48 Inches Hg
 774.19 Millimeters Hg
 3. Meter Volume
 65.660 Dry Standard Cubic Feet
 1.859 Dry Standard Cubic Meters
 4. Water Volume
 1.803 Standard Cubic Feet
 .051 Standard Cubic Meters
 5. Moisture Content
 .0267 (Convert to % X 100)
 6. Molecular Weight Dry
 28.78
 7. Molecular Weight Wet
 28.49
 8. Stack Velocity
 61.31 Feet per Second
 18.69 Meters per Second
 9. Volumetric Flow
 184,919. Actual Cubic Feet per Minute
 87.2725 Actual Cubic Meters per Second
 10. Volumetric Flow
 161,877. Dry Standard Cubic Feet per Minute
 76.3979 Dry Standard Cubic Meters per Second
 11. Concentration
 .0096 Grains per Dry Standard Cubic Foot
 .0220 Grams per Dry Standard Cubic Meter
 15. Particulate Mass Rate
 13.33 Pounds per Hour
 16. Volume at Nozzle
 75.007 Actual Cubic Feet
 2.124 Actual Cubic Meters
 17. Concentration
 .0084 Grains per Actual Cubic Foot
 .0192 Grams per Actual Cubic Meter
 18. % Isokinetic
 90.20

FRONT HALF ONLY

.....
2. Run Number
8-19-80 Date
30.24 Barometric Pressure (in. Hg.)
- .75 Static Pressure (in. H₂O)
72.00 Time (minutes)
69.847 Meter Volume (corrected)
132.00 Stack Temperature (°F)
112.00 Meter Temperature (°F)
3.30 Meter Pressure (in. H₂O)
1.017 Sq. Root Velocity Pressure
14.10 Mg of Particulate
38.30 Ml of water condensed
19.50 % O₂
.00 % CO₂
50.2656 Stack Area (Ft²)
.85 Pitot Correction Factor
.000314 Nozzle Area (Ft²)
1. Stack Pressure
30.18 Inches Hg
766.57 Millimeters Hg
2. Meter Pressure
30.48 Inches Hg
774.19 Millimeters Hg
3. Meter Volume
65.660 Dry Standard Cubic Feet
1.859 Dry Standard Cubic Meters
4. Water Volume
1.803 Standard Cubic Feet
.051 Standard Cubic Meters
5. Moisture Content
.0267 (Convert to % X 100)
6. Molecular Weight Dry
28.78
7. Molecular Weight Wet
28.49
8. Stack Velocity
61.31 Feet per Second
18.69 Meters per Second
9. Volumetric Flow
184,919. Actual Cubic Feet per Minute
87.2725 Actual Cubic Meters per Second
10. Volumetric Flow
161,877. Dry Standard Cubic Feet per Minute
76.3979 Dry Standard Cubic Meters per Second
11. Concentration
.0033 Grains per Dry Standard Cubic Foot
.0076 Grams per Dry Standard Cubic Meter
15. Particulate Mass Rate
4.59 Pounds per Hour
16. Volume at Nozzle
75.007 Actual Cubic Feet
2.124 Actual Cubic Meters
17. Concentration
.0029 Grains per Actual Cubic Foot
.0066 Grams per Actual Cubic Meter
18. % Isokinetic
90.20
.....

Back Air Only

2. Run Number
8-19-80 Date
- 30.24 Barometric Pressure (in. Hg.)
-.75 Static Pressure (in. H₂O)
72.00 Time (minutes)
69.847 Meter Volume (corrected)
132.00 Stack Temperature (°F)
112.00 Meter Temperature (°F)
3.30 Meter Pressure (in. H₂O)
1.017 Sq. Root Velocity Pressure
26.85 Mg of Particulate
38.30 Ml of water condensed
19.50% O₂
.00% CO₂
50.2656 Stack Area (Ft²)
.85 Pitot Correction Factor
...:000314 Nozzle Area (Ft²)
1. Stack Pressure
30.18 Inches Hg
766.57 Millimeters Hg
2. Meter Pressure
30.48 Inches Hg
774.19 Millimeters Hg
3. Meter Volume
65.660 Dry Standard Cubic Feet
1.859 Dry Standard Cubic Meters
4. Water Volume
1.803 Standard Cubic Feet
.051 Standard Cubic Meters
5. Moisture Content
.0267 (Convert to % X 100)
6. Molecular Weight Dry
28.78
7. Molecular Weight Wet
28.49
8. Stack Velocity
61.31 Feet per Second
18.69 Meters per Second
9. Volumetric Flow
184,919. Actual Cubic Feet per Minute
87.2725 Actual Cubic Meters per Second
10. Volumetric Flow
161,877. Dry Standard Cubic Feet per Minute
76.3979 Dry Standard Cubic Meters per Second
11. Concentration
.0063 Grains per Dry Standard Cubic Foot
.0144 Grams per Dry Standard Cubic Meter
15. Particulate Mass Rate
8.74 Pounds per Hour
16. Volume at Nozzle
75.007 Actual Cubic Feet
2.124 Actual Cubic Meters
17. Concentration
.0055 Grains per Actual Cubic Foot
.0126 Grams per Actual Cubic Meter
18. % Isokinetic
90.20
-

.....
 3. *TOTAL* Run Number
 8-20-30 Date
 30.07 Barometric Pressure (in. Hg.)
 -.62 Static Pressure (in. H₂O)
 72.00 Time (minutes)
 70.619 Meter Volume (corrected)
 132.00 Stack Temperature (°F)
 112.00 Meter Temperature (°F)
 3.30 Meter Pressure (in. H₂O)
 .978 Sq. Root Velocity Pressure
 32.00 Mg of Particulate
 39.00 Ml of water condensed
 18.75 % O₂
 .00 % CO₂
 Stack Area (Ft²)
 50.2656 Pitot Correction Factor
 .85 Nozzle Area (Ft²)
 .000314

 1. Stack Pressure
 30.02 Inches Hg
 762.51 Millimeters Hg
 2. Meter Pressure
 30.31 Inches Hg
 769.88 Millimeters Hg
 3. Meter Volume
 66.016 Dry Standard Cubic Feet
 1.869 Dry Standard Cubic Meters
 4. Water Volume
 1.836 Standard Cubic Feet
 .052 Standard Cubic Meters
 5. Moisture Content
 .0271 (Convert to % X 100)
 6. Molecular Weight Dry
 23.75
 7. Molecular Weight Wet
 23.46
 8. Stack Velocity
 59.15 Feet per Second
 18.03 Meters per Second
 9. Volumetric Flow
 173,405. Actual Cubic Feet per Minute
 34.1982 Actual Cubic Meters per Second
 10. Volumetric Flow
 153,291. Dry Standard Cubic Feet per Minute
 73.2396 Dry Standard Cubic Meters per Second
 11. Concentration
 .0075 Grains per Dry Standard Cubic Foot
 .0172 Grams per Dry Standard Cubic Meter
 15. Particulate Mass Rate
 9.94 Pounds per Hour
 16. Volume at Nozzle
 75.842 Actual Cubic Feet
 2.148 Actual Cubic Meters
 17. Concentration
 .0065 Grains per Actual Cubic Foot
 .0149 Grams per Actual Cubic Meter
 18. % Isokinetic
 94.54

FRONT HALF JULY

3.	Run Number	0
3-20-80	Date	30.07.80
	Barometric Pressure (in. Hg.)	- .62
	Static Pressure (in. H ₂ O)	72.00
	Time (minutes)	70.619
	Meter Volume (corrected)	132.00
	Stack Temperature (°F)	112.00
	Meter Temperature (°F)	3.30
	Meter Pressure (in. H ₂ O)	.978
	Sq. Root Velocity Pressure	7.00
	Mg of Particulate	39.00
	Ml of water condensed	18.75
	% O ₂	.00
	% CO ₂	50.2656
	Stack Area (Ft ²)	.85
	Pitot Correction Factor	.000314
	Nozzle Area (Ft ²)	
1.	Stack Pressure	30.02
	Inches Hg	752.51
	Millimeters Hg	
2.	Meter Pressure	30.31
	Inches Hg	769.33
	Millimeters Hg	
3.	Meter Volume	58.016
	Dry Standard Cubic Feet	1.869
	Dry Standard Cubic Meters	
4.	Water Volume	1.836
	Standard Cubic Feet	.052
	Standard Cubic Meters	
5.	Moisture Content	.0271
	(Convert to % X 100)	
6.	Molecular Weight Dry	28.75
7.	Molecular Weight Wet	28.46
8.	Stack Velocity	59.15
	Feet per Second	18.03
	Meters per Second	
9.	Volumetric Flow	174,405
	Actual Cubic Feet per Minute	34.1992
	Actual Cubic Meters per Second	
10.	Volumetric Flow	155,291
	Dry Standard Cubic Feet per Minute	73.2835
	Dry Standard Cubic Meters per Second	
11.	Concentration	.0016
	Grains per Dry Standard Cubic Foot	.0037
	Grams per Dry Standard Cubic Meter	
15.	Particulate Mass Rate	2.17
	Pounds per Hour	
16.	Volume at Nozzle	75.342
	Actual Cubic Feet	2.148
	Actual Cubic Meters	
17.	Concentration	.0014
	Grains per Actual Cubic Foot	.0032
	Grams per Actual Cubic Meter	
19.	% Isokinetic	94.54
.....		

3. BACK HALF ONLY

8-20-80

Run Number

Date

30.07 Barometric Pressure (in. Hg.)

-.62 Static Pressure (in. H₂O)

72.00 Time (minutes)

70.619 Meter Volume (corrected)

132.00 Stack Temperature (°F)

112.00 Meter Temperature (°F)

3.30 Meter Pressure (in. H₂O)

.978 Sq. Root Velocity Pressure

25.00 Mg of Particulate

39.00 Ml of water condensed

13.75 % O₂

.00 % CO₂

50.2656 Stack Area (Ft²)

.85 Pitot Correction Factor

.000314 Nozzle Area (Ft²)

1. Stack Pressure

30.02

Inches Hg

762.51

Millimeters Hg

2. Meter Pressure

30.31

Inches Hg

769.88

Millimeters Hg

3. Meter Volume

66.016

Dry Standard Cubic Feet

1.869

Dry Standard Cubic Meters

4. Water Volume

1.836

Standard Cubic Feet

.052

Standard Cubic Meters

5. Moisture Content

.0271

(Convert to % X 100)

6. Molecular Weight Dry

28.75

7. Molecular Weight Wet

28.46

8. Stack Velocity

59.15

Feet per Second

18.03

Meters per Second

9. Volumetric Flow

173,405

Actual Cubic Feet per Minute

34.1932

Actual Cubic Meters per Second

10. Volumetric Flow

155,291

Dry Standard Cubic Feet per Minute

73.2893

Dry Standard Cubic Meters per Second

11. Concentration

.0058

Grains per Dry Standard Cubic Foot

.0133

Grams per Dry Standard Cubic Meter

15. Particulate Mass Rate

7.76

Pounds per Hour

16. Volume at Nozzle

75.342

Actual Cubic Feet

2.148

Actual Cubic Meters

17. Concentration

.0051

Grains per Actual Cubic Foot

.0117

Grams per Actual Cubic Meter

18. % Isokinetic

94.54

.....

.....
TOTAL.....

4. Run Number
S-21-80
30.06 Date
-.64 Barometric Pressure (in. Hg.)
72.00 Static Pressure (in. H₂O)
67.973 Time (minutes)
133.00 Meter Volume (corrected)
110.00 Stack Temperature (°F)
3.03 Meter Temperature (°F)
.954 Meter Pressure (in. H₂O)
37.80 Sq. Root Velocity Pressure
37.00 Mg of Particulate
19.375 Ml of water condensed
.00 % O₂
50.2656 % CO₂
.85 Stack Area (Ft²)
.000314 Pitot Correction Factor
Nozzle Area (Ft²)
.....

1. Stack Pressure
30.01 Inches Hg
762.26 Millimeters Hg
2. Meter Pressure
30.28 Inches Hg
769.11 Millimeters Hg
3. Meter Volume
63.702 Dry Standard Cubic Feet
1.804 Dry Standard Cubic Meters
4. Water Volume
1.742 Standard Cubic Feet
.049 Standard Cubic Meters
5. Moisture Content
.0266 (Convert to % X 100)
6. Molecular Weight Dry
28.78
7. Molecular Weight Wet
28.49
8. Stack Velocity
57.73 Feet per Second
17.60 Meters per Second
9. Volumetric Flow
174,118. Actual Cubic Feet per Minute
32.1750 Actual Cubic Meters per Second
10. Volumetric Flow
151,315. Dry Standard Cubic Feet per Minute
71.4131 Dry Standard Cubic Meters per Second
11. Concentration
.0091 Grains per Dry Standard Cubic Foot
.0208 Grams per Dry Standard Cubic Meter
15. Particulate Mass Rate
11.85 Pounds per Hour
16. Volume at Nozzle
73.303 Actual Cubic Feet
2.076 Actual Cubic Meters
17. Concentration
.0079 Grains per Actual Cubic Foot
.0181 Grams per Actual Cubic Meter
18. % Isokinetic
93.62
.....

..FRONT HALF ONLY

4.	Run Number
6-21-80	Date
30.06	Barometric Pressure (in. Hg.)
- .64	Static Pressure (in. H ₂ O)
72.00	Time (minutes)
67.973	Meter Volume (corrected)
133.00	Stack Temperature (°F)
110.00	Meter Temperature (°F)
3.03	Meter Pressure (in. H ₂ O)
.954	Sq. Root Velocity Pressure
3.00	Mg of Particulate
37.00	Ml of water condensed
19.375	% O ₂
.00	% CO ₂
50.2656	Stack Area (Ft ²)
.85	Pitot Correction Factor
.000314	Nozzle Area (Ft ²)
.....	
1.	Stack Pressure
30.01	Inches Hg
762.26	Millimeters Hg
2.	Meter Pressure
30.28	Inches Hg
769.11	Millimeters Hg
3.	Meter Volume
63.702	Dry Standard Cubic Feet
1.804	Dry Standard Cubic Meters
4.	Water Volume
1.742	Standard Cubic Feet
.049	Standard Cubic Meters
5.	Moisture Content
.0266	(Convert to % X 100)
6.	Molecular Weight Dry
28.78	
7.	Molecular Weight Wet
28.49	
8.	Stack Velocity
57.73	Feet per Second
17.60	Meters per Second
9.	Volumetric Flow
174,118.	Actual Cubic Feet per Minute
32.1750	Actual Cubic Meters per Second
10.	Volumetric Flow
151,315.	Dry Standard Cubic Feet per Minute
71.4131	Dry Standard Cubic Meters per Second
11.	Concentration
.0007	Grains per Dry Standard Cubic Foot
.0016	Grams per Dry Standard Cubic Meter
15.	Particulate Mass Rate
.94	Pounds per Hour
16.	Volume at Nozzle
73.303	Actual Cubic Feet
2.076	Actual Cubic Meters
17.	Concentration
.0006	Grains per Actual Cubic Foot
.0014	Grams per Actual Cubic Meter
18.	% Isokinetic
93.62	
.....	

Back Half Only

4.	Run Number
8-21-80	Date
30.06	Barometric Pressure (in. Hg.)
-64	Static Pressure (in. H ₂ O)
72.00	Time (minutes)
67.973	Meter Volume (corrected)
133.00	Stack Temperature (°F)
110.00	Meter Temperature (°F)
3.03	Meter Pressure (in. H ₂ O)
.954	Sq. Root Velocity Pressure
34.80	Mg of Particulate
37.00	ML of water condensed
19.375	% O ₂
.00	% CO ₂
50.2656	Stack Area (Ft ²)
.35	Pitot Correction Factor
.000314	Nozzle Area (Ft ²)
.....	
1.	Stack Pressure
30.01	Inches Hg
762.26	Millimeters Hg
2.	Meter Pressure
30.28	Inches Hg
769.11	Millimeters Hg
3.	Meter Volume
63.702	Dry Standard Cubic Feet
1.804	Dry Standard Cubic Meters
4.	Water Volume
1.742	Standard Cubic Feet
.049	Standard Cubic Meters
5.	Moisture Content
.0266	(Convert to % X 100)
6.	Molecular Weight Dry
28.78	
7.	Molecular Weight Wet
28.43	
8.	Stack Velocity
57.73	Feet per Second
17.60	Meters per Second
9.	Volumetric Flow
174,118	Actual Cubic Feet per Minute
32.1750	Actual Cubic Meters per Second
10.	Volumetric Flow
151,315	Dry Standard Cubic Feet per Minute
71.4131	Dry Standard Cubic Meters per Second
11.	Concentration
.0064	Grains per Dry Standard Cubic Foot
.0132	Grams per Dry Standard Cubic Meter
12.	Particulate Mass Rate
10.21	Pounds per Hour
13.	Volume at Nozzle
73.303	Actual Cubic Feet
2.076	Actual Cubic Meters
14.	Concentration
.0073	Grains per Actual Cubic Foot
.0157	Grams per Actual Cubic Meter
15.	% Isokinetic
93.62	
.....	

BACK HALF ANALYSIS

Run #	#2	#3	#4
Initial filtering of water collected with .22 micron filter, mg	1.2	0.9	2.9
Organic Portion, mg	2.3	0.7	1.5
Chloroform Blank, mg	-.1	-.1	-.1
Ether Blank, mg	-.2	-.2	-.2
Evaporation of Water Portion, mg	53.7	43.0	53.0
blank Water, mg	-.1	-.1	-.1
Sulfate Analysis, mg	-32.25	-31.50	-35.50
Acetone Rinse, mg	2.3	12.4	13.4
Acetone Blank, mg	-0.0	-.1	-.1
Total Back Half Catch, mg	26.85	25.50	34.50

GUARDIAN SYSTEMS INC.2009 Central Avenue
Birmingham, Alabama 35209
205/979-1850Run Number 1Date 8-18-80Location U.S. Steel BayhouseAmount liquid lost during transport NoneAcetone blank volume, ml 350Acetone wash volume, ml 120Acetone blank concentration, mg/mg 3.64×10^{-7} Acetone wash blank, mg 0.1Filter Collections (mg)Filter # L710Gross 256.7Tare 250.3Net 6.4Probe and Cyclone Wash (mg)Dish # 1Gross 99491.6Tare 99477.4Acetone Blank 0Net 14.2Total Particulate Capture 20.6 mg.WaterFinal 30Initial Net 30Silica GelFinal Initial Net 11.5Total Water 41.5Approved By LA

GUARDIAN SYSTEMS INC.2009 Central Avenue
Birmingham, Alabama 35209
205/879-1850

Run Number 2
Date 8/19/80
Location U.S. Bayhouse
Amount liquid lost during transport None
Acetone blank volume, ml 350
Acetone wash volume, ml 120
Acetone blank concentration, mg/mg 3.64×10^{-7}
Acetone wash blank, mg 0.1

Filter Collections (mg)

Filter # LX16
Gross 268.8
Tare 267.1
Net 1.7

Probe and Cyclone Wash (mg)

Dish # 2
Gross 98951.0
Tare 98938.6
Acetone Blank —
Net 12.4

Total Particulate Capture 14.1 mg.

Water

Final 25
Initial 0
Net 25

Silica Gel

Final
Initial
Net 13.3

Total Water 38.3

Approved By Loft

FIELD DATA SHEET

GUARDIAN SYSTEMS INC.

2009 Central Avenue
Birmingham, Alabama 35208
205/879-1850PLANT U.S. Steel
LOCATION BirminghamRUN # 3
DATE 8/20/80BARO PRES 30.07TIME 7:09 - 2:08 ΔH 18P

QINT NO.	TIME		METER VOL	METER FT 3	STACK TEMP °F	METER TEMP °F			IMP TEMP °F	BOX TEMP °F	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	Vacuum Pressure "Hg	STATIC PRESSURE "H ₂ O	
	MIN	HOUR				IN	OUT	AVG						BEFORE	AFTER
1	3	3	081.7	125	92	88	90	45	250	4.0	1.2	2		.240	.240
2	3	6	085.0	130	100	92	96	50	230	4.0	1.2	2		.240	.240
3	3	9	088.3	135	104	98	100	58	240	3.7	1.1	2		.240	.240
4	3	12	091.3	135	106	102	104	56	260	3.3	1.0	2			
5	3	15	094.5	135	110	106	108	58	270	3.3	1.0	2			
6	3	18	097.2	130	112	110	111	62	245	2.5	.78	1			
7	3	21	099.5	130	110	110	110	55	245	1.8	.55	1			
8	3	24	102.0	130	110	112	111	56	260	2.3	.72	1			
9	3	27	104.7	130	110	114	112	58	270	2.3	.72	1			
10	3	30	107.7	135	110	114	112	58	245	3.1	.95	2			
11	3	33	111.0	132	110	114	112	57	250	3.7	1.1	2			
12	3	36	114.3	135	116	116	116	59	250	3.7	1.1	2			
13	3	39	118.6	133	118	118	118	58	250	6.6	2.1	3			
14	3	42	123.0	125	120	120	120	60	235	6.8	2.2	3			
15	3	45	127.4	134	120	120	120	58	270	6.8	2.2	3			
16	3	48	131.5	136	120	116	118	58	265	5.7	1.8	3			
17	3	51	135.2	131	120	114	117	60	240	4.7	1.5	2			
18	3	54	138.3	133	120	114	117	60	270	3.1	.95	2			
19	3	57	140.5	136	120	114	118	60	230	1.5	.45	1			
20	3	60	142.4	135	120	112	116	59	250	1.2	.38	1			
21	3	63	144.4	130	110	112	111	60	240	1.3	.42	1			
22	3	66	146.4	132	112	110	112	60	255	1.3	.42	1			
23	3	69	148.3	130	114	114	114	60	250	1.2	.38	1			
24	3	72	150.1	131	114	114	114	60	230	1.5	.45	1			
25			152.0	132			112			3.3	.77				
26			154.0	132			112			3.3	.77				

WATER

mi 20from 19.0Total 39.0

OPERATOR

Don LockingSAMPLE BOX NO. 300METER BOX NO. 13METER ΔH .85PITOT, CP .85TEMP. DEVICE LVHPROBE LGTH. 4'PROBE LINER 62200PROBE HTR SET. 90%AMBIENT TEMP.

NOTES

Static - 10" OK

Ram - 9" OK

Leak check

098.278

099.267

0.0110

20" high for 1 min

CO₂ - 0%O₂ - 18.75%

Final Leak Check

150.514

150.510

0.00425 in

Ram - 9" OK

Static - 10" OK

72.060

132

11.54

3.306

.9775

GUARDIAN SYSTEMS INC.2009 Central Avenue
Birmingham, Alabama 35209
205/879-1050

Run Number 3
Date 8/20/80
Location U.S.S. Barge House
Amount liquid lost during transport Nine
Acetone blank volume, ml 350
Acetone wash volume, ml 150
Acetone blank concentration, mg/mg 3.64×10^{-7}
Acetone wash blank, mg 0.1

Filter Collections (mg)

Filter # LX15
Gross 269.4
Tare 268.3
Net 1.1

Probe and Cyclone Wash (mg)

Dish # 3
Gross 99355.4
Tare 99349.5
Acetone Blank -
Net 5.9

Total Particulate Capture 7.0 mg.

Water

Final 20
Initial 0
Net 20

Silica Gel

Final
Initial
Net 19.0

Total Water 39.0

Approved By LL

FIELD DATA SHEET

GUARDIAN SYSTEMS, INC.

2809 Central Avenue
Birmingham, Alabama 35209
205-979-1050

PLANT

U.S. Steel

RUN #

4

LOCATION

Basshouse

DATE

8/21/80

BARO PRES

30.06

TIME

7:38 - 4:11

ΔH

ΔP

POINT NO.	TIME		METER		STACK TEMP °F			METER TEMP °F			IMP TEMP °F	BOX TEMP °F	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	Vacuum Pressure "H ₂ O	STATIC PRESSURE "H ₂ O	
	MIN	SEC	VOL	FT. 3	IN	OUT	AVG	IN	OUT	AVG	F	F				BEFORE	AFTER
1	3		154.112		128	110	104	107	52	245	4.4	1.4	5			-240	.240
2	1		161.1		130	112	106	109	54	245	4.4	1.4	51			.240	.240
3			164.9		130	112	106	109	54	235	4.2	1.3	1			.240	.240
4			168.0		132	112	108	110	56	255	3.2	1.0	1				
5			170.9		130	110	106	108	58	260	2.9	.92	1				
6			173.6		135	108	106	107	60	265	2.4	.80	1				
7			175.8		130	110	108	109	59	250	1.7	.55	1				
8			178.3		135	108	106	107	60	270	1.8	.60	1				
9			181.0		138	108	106	107	59	250	2.6	.85	1				
10			183.9		140	110	106	108	54	265	3.2	1.0	1				
11			186.8		140	110	108	109	58	250	2.9	.95	1				
12	✓		189.9		138	110	108	109	54	250	3.4	1.1	1				
13			193.7		135	114	110	112	52	250	5.0	1.6	1				
14	3		193.7		135	114	110	112	52	250	5.0	1.6	1				
15			197.3		137	114	108	111	56	250	4.6	1.5	1				
16			201.0		135	114	110	112	58	245	5.0	1.6	1				
17			205.1		130	112	112	112	52	230	5.9	1.9	2				
18			208.9		134	112	108	110	60	240	5.0	1.6	2				
19			211.9		130	114	112	113	59	260	3.2	1.0	1				
20			213.8		130	114	112	113	60	260	1.1	.35	1				
21			215.7		132	114	114	114	60	245	1.1	.35	1				
22			217.8		132	112	112	112	58	235	1.4	.45	1				
23			219.8		130	106	106	106	60	250	1.2	.40	1				
24			221.7		128	110	110	110	60	250	1.2	.40	1				
25	✓		223.172		130	110	110	110		260	.91	.3	1				
26					318.1			112.4			72.71		1				
27			69.360		133			110			3.03	.154	✓				

WATER

ml 9.0

gram 17.0

Total 37.0

OPERATOR

Mark Wilson

SAMPLE BOX NO. 2

METER BOX NO. 320

METER ΔH 1.80

PITOT, CP .85

TEMP. DEVICE L4N

PROBE LGTH. 8'

PROBE LINER Glass

PROBE HTR SET. 802

AMBIENT TEMP. 95

NOTES

154.112

154.112

.00065 "H₂O
for 1 minRem 7" o.k.
Static 7" o.k.CO₂ - 0.0%O₂ - 19.375%

223.014

223.005

.00965 "H₂O
forRem 7" o.k.
Static 7" o.k.

GUARDIAN SYSTEMS INC.2808 Central Avenue
Birmingham, Alabama 35208
205/378-1050

Run Number 4
Date 8/21/80
Location U.S.S. Baghouse
Amount liquid lost during transport NONE
Acetone blank volume, ml 350
Acetone wash volume, ml 100
Acetone blank concentration, mg/mg 3.64×10^{-7}
Acetone wash blank, mg 0.1

Filter Collections (mg)

Filter # 4X14
Gross 269.6
Tare 268.9
Net 0.7

Probe and Cyclone Wash (mg)

Dish # 4
Gross 811364
Tare 81134.1
Acetone Blank -
Net 2.3

Total Particulate Capture 3.0 mg.

Water

Final 20
Initial 0
Net 20

Silica Gel

Final
Initial
Net 17.0

Total Water 37.0

Approved By 

V. CALIBRATIONS

General

The meter box was recalibrated upon return to the laboratory from this test. The box was recalibrated at 2.5 "H₂O, the highest limit of our wet test meter. This calibration produced a single point MCF and ΔH_0 which was compared to the original calibration. All were within the 5% allowed at the highest vacuum seen. This calibration sheet is located behind the original calibration sheets.

The equipment used on both ports was as follows:

Probe: 8' - 1

Box: 300

Stack Temperature: L&N 1

Sample Box: 2 & 3

The average temperature of the stack was 131.5 °F. The Pyro 1 was recalibrated at 135 °F and agreed within 1.5% of the initial calibration value.

Type A Glass Fiber Filters

FEATURES

- High tensile strength. • Excellent handling characteristics. • Good wetting properties. • Minimum of 99.9% retention for particles of $3 \mu\text{m}$ as determined by DOP tests. • Binder free.

This is the original glass fiber filter pioneered by Gelman Instrument Company over 15 years ago. It continues to be widely used for high volume sampling. Since zinc is one of the raw materials incorporated in the glass fibers, Type A filters have a variable zinc content. Another component of the filter, sulfuric acid, is used as a dispersion medium making the sheets unsuitable for measurement of sulfates.

Type A Glass Fiber Filters are less likely to develop static charge or tear than other glass fiber media types. They are used extensively in applications where zinc and iron content is not important, or where sulfate content is not being determined.

Size	37 mm	47 mm	102 mm	8"x10"
Product No.	G1715	G1694	G1696	G1701
Filters/Pkg.	500	100	100	100

TYPE A GLASS FIBER FILTER SPECIFICATION REPORT

The following physical and chemical properties represent typical average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/m² x 10" sheet).

ELEMENTS:

Antimony	30	Manganese	200
Arsenic	30	Mercury	100
Barythium	1	Molybdenum	10
Bismuth	10	Nickel	10
Cadmium	5	Selenium	5000
Chromium	10	Tin	10
Cobalt	10	Titanium	10
Copper	2	Vanadium	10
Iron	100-1000	Zinc	5000
Lead	10		to 25,000

OTHER PHYSICALS:

BSO	522	Flow Resistance (Max)	
pH	8.5	@ 320 cm/min.	80 mm
DOP @ 320 cm/min		Flow Rate (air)	
ASTM Method 2986	99.9%	Ipnu/cm ² @ 70 cm Hg	50
Tensile Strength		Max. Use Temp	400°C
(Fed. Spec. OUP-31B)	750 gr	Static Property	Low
Weight		Ability to	
8"x10" sheet	40±3 gr	Fold	Excellent

WATER EXTRACTABLE IONS

Sulfate	100	Chloride	1500
Nitrate	50	Fluoride	15
Ammonia	20		

1. Analysis made by EPA procedures.
2. Analysis made by EPA procedures.
3. Analysis made by EPA procedures.
4. Analysis made by EPA procedures.

Type A/E Glass Fiber Filters

FEATURES

- Low trace metals. • Medium Handling characteristics. • Available in all sizes. • Minimum of 99.9% retention for particles of $3 \mu\text{m}$ as determined by DOP tests. • Binder free.

Type A/E Glass Fiber Filters are composed of low acid soluble glass fiber. They contain low levels of both zinc and iron. The filters do react with atmospheric sulfur dioxide, and therefore, when high levels of sulfur are expected, correct for this reaction should be accounted for.

Type A/E Glass Fiber Filters are binder free and ideal for gravimetric analysis of air pollutants. This pure, organic free filter is the basis for procedures widely used in determining municipal and industrial air polluting substances.

Size	25 mm	37 mm	47 mm	102 mm	8"x10"
Product No.	G1630	G1652	G1631	G1633	G1635
Filters/Pkg.	500	500	100	100	100

TYPE A/E GLASS FIBER FILTER SPECIFICATION REPORT

The following physical and chemical properties represent typical average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/m² x 10" sheet).

ELEMENTS:

Antimony	20	Manganese	2
Arsenic	20	Mercury	50
Barythium	1	Molybdenum	10
Bismuth	10	Nickel	10
Cadmium	2	Selenium	200
Chromium	10	Tin	10
Cobalt	10	Titanium	10
Copper	2	Vanadium	10
Iron	100-1000	Zinc	50
Lead	10		

OTHER PHYSICALS:






BSO	522	Flow Resistance (Max)	
pH	9.0	@ 320 cm/min.	80 mm
DOP @ 320 cm/min		Flow Rate (air)	
ASTM Method 2986	99.9%	Ipnu/cm ² @ 70 cm Hg	50
Tensile Strength		Max. Use Temp	400°C
(Fed. Spec. OUP-31B)	600 gr	Static Properties	Medium
Weight		Ability to	
8"x10" sheet	40±3 gr	Fold	Good

WATER EXTRACTABLE IONS:

Sulfate	60	Chloride	1500
Nitrate	115	Fluoride	15
Ammonia	13		

pH: 8.5 to 9.0

1. Analysis made by EPA procedures.
2. Analysis made by EPA procedures.
3. Analysis made by EPA procedures.
4. Analysis made by EPA procedures.



NOTE: Flow rate held constant at 0.75; 50% change in flow rate has little effect on probe temperature.

Figure 16
Probe Temperatures

METER CALIBRATION FORM

Date 8-1-80

Box No. 300

P_{bar} = 30.08 in. Hg

Calibrated by Mark Wilson

Orifice Manometer Set- ting ΔH (in. H ₂ O)	Δ wtm (in. H ₂ O)	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Avg. Temp. Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Inlet	Outlet
.5	-.3	3109.37	3115.61	874.046	880.311	27.7	27.7	110 106	96 96
1.0	-.5	3115.61	3124.374	880.311	888.944	27.7	27.9	106 108	96 96
1.5	-.7	3124.374	3134.980	888.944	899.498	27.9	27.9	108 110	96 96
2.0	-.9	3134.980	3147.432	899.498	911.938	27.9	27.9	110 112	96 98
2.5	-1.1	3147.432	3161.082	911.938	925.391	27.9	27.9	112 112	98 98

Pump must be operated for at least 15 minutes at each ΔH setting (.5, 1, 1.5, 2 and 3)

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

P_{wtm} = P_{bar} - $\frac{\Delta wtm}{13.6}$

P_{dgm} = P_{bar} + $\frac{\Delta H}{13.6}$

Δwtm = pressure on wet test meter in inches of H₂O

Y = meter calibration factor

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$Y = \frac{(\text{wet final} - \text{wet initial})(T_{dgm})(P_{wtm})}{(\text{dry final} - \text{dry initial})(28.316)(T_{wtm})(P_{dgm})}$$

or (1)

$$\bar{Y} = \frac{\sum Y}{5}$$

Meter Tolerance = 1.00 ± 0.01

If the meter calibration factor is not within the allowable tolerance, the calibration factory Y may be used to mathematically correct the gas meter dial readings to the proper values instead of physically adjusting the dry gas meter dials to correspond to the wet test meter readings.

Post
METER CALIBRATION FORM

Date August 26, 1980

Box No. 300

P_{bar} = 30.10 in. Hg

Calibrated by Mark Wilson

Orifice Manometer Set- ting ΔH (in. H ₂ O)	Δ wtm (in. H ₂ O)	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Avg. Temp. Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Inlet	Outlet
* 2.5	-1.1	4063.656	4078.392	588.762	604.334	28.5	28.5	126 126	118 118
2.5	-1.1	4078.392	4092.578	604.334	619.126	28.5	28.1	126 126	118 118
* 2.5	-1.1	4092.578	4109.026	619.126	636.314	28.1	27.9	126 126	118 118

* + 60 sec

* * + 150 sec Pump must be operated for at least 15 minutes at each ΔH setting (.5, 1, 1.5, 2 and 3)

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

P_{wtm} = P_{bar} - $\frac{\Delta wtm}{13.6}$

P_{dgm} = P_{bar} + $\frac{\Delta H}{13.6}$

.4790

.9805

.9800

$2.9395 \div 3 = .9798 \approx .98 = Y$

Δwtm = pressure on wet test meter in inches of H₂O

Y = meter calibration factor

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$Y = \frac{(\text{wet final} - \text{wet initial})(T_{dgm})(P_{wtm})}{(\text{dry final} - \text{dry initial})(28.316)(T_{wtm})(P_{dgm})}$$

or (1)

$$\bar{Y} = \frac{\Sigma Y}{5}$$

Meter Tolerance = 1.00 ± 0.01

If the meter calibration factor is not within the allowable tolerance, the calibration factory Y may be used to mathematically correct the gas meter dial readings to the proper values instead of physically adjusting the dry gas meter dials to correspond to the wet test meter readings.

ORIFICE CALIBRATION FORM

Date 8-1-80Meter Box No. 300P_{bar} 30.08Calibrated By Mark Wilson

ΔH	V ₁	V ₂	θ	t ₁	t ₂	V ₂ - V ₁	Q _m	K _m
in. H ₂ O	CF	CF	Sec.	°F	°F	CF		
0.5	874.046	880.311	900	108	96	6.265	0.4140	0.7339
1.0	880.311	888.944	900	107	96	8.633	0.5751	0.7213
1.5	888.944	899.498	900	108	96	10.554	0.6945	0.7116
2.0	899.498	911.938	930	110	98	12.440	0.7891	0.7000
2.5	911.938	925.391	900	112	98	13.453	0.8940	0.7091
Average K _m								0.7152

V₁ = Dry gas meter reading at the start of each testV₂ = Dry gas meter reading at the end of each testt₁ = Dry gas meter inlet temperaturet₂ = Dry gas meter outlet temperature

$$\Delta H_a = 1.80$$

Calculations

$$1. Q_m = \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{t_1 + t_2 + 460} \right] \quad (60)(Y)$$

(for each ΔH)

$$2. K_m = \frac{Q_m}{\sqrt{\frac{P_m M_m}{T_m \Delta H}}} \quad \begin{matrix} M_m = 29 \\ T_m = t_2 + 460 \\ P_m = P_{bar} + \frac{\Delta H}{13.6} \end{matrix}$$

(for each ΔH)

Y = meter calibration factor

3. Calculate the average K_m as follows:

$$\bar{K}_m = \frac{\sum K_m}{5}$$

4. Calculate ΔH_a as follows:

$$\Delta H_a = \frac{Q^2 P_0 M_0}{T_0 \bar{K}_m^2} = 0.921$$

$$\begin{aligned} Q_0 &= 0.75 \text{ cfm} \\ T_0 &= 528^\circ R \\ P_0 &= 29.92 \text{ in.Hg} \\ M_0 &= 29 \end{aligned}$$

5. Orifice Tolerance = $1.84 \pm .25$

Post
ORIFICE CALIBRATION FORM

Date August 26, 1980
P_{bar} 30.10

Meter Box No. 300
Calibrated By Mark Wilson

Δ H	V ₁	V ₂	θ	t ₁	t ₂	V ₂ - V ₁	Q _m	K _m
in. H ₂ O	CF	CF	Sec.	°F	°F	CF		
2.5	588.92	604.334	960	126	118	15.372	.9341	.7282
2.5	604.334	619.126	900	126	118	14.792	.9602	.7486
2.5	619.126	636.314	1050	126	118	17.188	.9559	.7452
Average K _m								<u>.7407</u>

V₁ = Dry gas meter reading at the start of each test

V₂ = Dry gas meter reading at the end of each test

t₁ = Dry gas meter inlet temperature

t₂ = Dry gas meter outlet temperature

1.74

1.64

1.66

5.04 ÷ 3 = 1.68 = ΔH_a

Calculations

1. $Q_m =$ (for each ΔH) $\frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{t_1 + t_2 + 460} \right] (60)(Y)$

2. $K_m =$ (for each ΔH) $Q_m \sqrt{\frac{P_m M_m}{T_m \Delta H}}$

M_m = 29
T_m = t₂ + 460
P_m = P_{bar} + $\frac{\Delta H}{13.6}$

Y = meter calibration factor

3. Calculate the average K_m as follows:

$$K_m = \frac{\sum K_m}{5}$$

4. Calculate ΔH_a as follows:

$$\Delta H_a = \frac{Q @^2 P @ M @}{T @} \left[\frac{1}{K_m^2} \right] = \frac{0.921}{K_m^2}$$

Q@ = 0.75 cfm
T@ = 528°R
P@ = 29.92 in.Hg
M@ = 29

5. Orifice Tolerance = 1.84 ± .25

PITOT CALIBRATION FORM

Date 6-25-80

Probe # 8-1

Calibrated By Tim Thornton

Nozzle Size None

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	.55	.75	.848	-.002
2	.55	.75	.848	-.002
3	.55	.74	.853	+.003
		$\bar{C}_p(A)$	.850	.001

SIDE B

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	.55	.74	.853	+.003
2	.55	.75	.848	-.002
3	.55	.75	.848	-.002
		$\bar{C}_p(B)$	.850	.001

CALCULATIONS

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}}$$

(or 0.99)

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3}$$

3

← Must be ≤ 0.01

$$|\bar{C}_p(A) - \bar{C}_p(B)| \leftarrow \text{Must be } \leq 0.01$$

METHOD 5 SOURCE TEST FOR PARTICULATE

Company US STEEL Today's Date APRIL 2, 1981
 Location BIRMINGHAM, AL Date of Test AUG 19, 1980
 Test Performed on (stack, boiler, etc.) #9 COKE BATTERY BAGHOUSE Run No. 2 TOTAL

ENTER	PRESS	ALTERNATE PRESS
<u>1.017</u> AVG $\sqrt{F}$ Calculator prints entry.	A	A
<u>3.30</u> ΔH Calculator prints entry.	R/S	SER 008
<u>112.3</u> Tm-meter temperature °F Calculator prints entry and absolute temperature.	R/S	SER 012
<u>132.5</u> Ts-stack temperature °F Calculator prints entry and absolute temperature.	R/S	SER 022
<u>.85</u> Cp-pitot tube co-efficient Calculator prints entry.	R/S	SER 032
<u>72</u> G minutes in run Calculator prints entry.	R/S	SER 036
<u>.24</u> DIAM NOZZLE IN INCHES Calculator prints entry and nozzle area.	R/S	SER 040
<u>30.24</u> OR nozzle area in square feet Calculator prints entry.	SER 052	SER 052
<u>- .75</u> Pbar-barometric pressure in inches in mercury Calculator prints entry.	R/S	SER 056
<u>96</u> Ps-pressure of stack in inches of water. Calculator prints entry and absolute temperature.	R/S	SER 060
<u>1</u> OR absolute pressure of stack in inches of mercury Calculator prints entry.	SER 070	SER 070
<u>96</u> DIAM STACK IN INCHES Calculator prints entry and area in square feet	R/S	SER 074
<u>1</u> OR-area of stack in square feet Calculator prints entry.	SER 086	SER 086
<u>9500</u> MM BTU/HR (enter best estimates available or enter 1 and disregard calculated result.) Calculator prints entry.	R/S	SER 090
<u>9500</u> F. FACTOR DSCP/MM BTU (Federal Register 60.45, laboratory factor, or enter 9500 and disregard calculated results). Calculator prints entry.	R/S	SER 094

ENTER	PRESS	ENTER	PRESS
<u>38.3</u> Total milliliters of water (water plus silica gel) Calculator prints entry and volume of water vapor at standard conditions.	B	<u>0</u> % CO ₂ Calculator prints entry.	E
<u>.04095</u> Total grams particulate collected (Subtract blank weight) Calculator prints out entry.	C	<u>19.5</u> % O ₂ Calculator prints entry.	R/S
<u>73.603</u> Total volume gas metered (less allowed leaks and gas lost at filter changes) Calculator prints entry.	D	<u>0</u> % CO Calculator prints entry.	R/S
		<u>80.5</u> % H ₂ Calculator prints entry and molecular weight dry.	R/S

1.017
3.3
112.3
572.3
132.5
592.5
0.85
72
0.24
.0003141593
30.24
-0.75
30.18485294
50.26548246
1.
9500.
38.3
1.802781
0.04095

73.603

0.

19.5

0.

80.5

28.78

69.15 V/M DSCF

2.54 % WATER

28.51 M/S

61.32 V/S

11097065.56 ACFH

9719210.49 DSCFH

1113.01 % EXCESS AIR

.0005921488 GM/CUFT

17.47 PPM

12.69 LB/HR

12.6878729 LB/MMBTU

.0124017061 LB/MMBTU (F FAC)

3972.366478

41.8704115

94.87 % ISOKINETIC

.0091368565

0.05 #/ton of coke pushed

METHOD 5 SOURCE EST FOR PARTICULATE

Company US STEEL Today's Date APRIL 2, 1981
 Location BIRMINGHAM, AL Date of Test AVG 20, 1980
 Test Performed on (stack, boiler, etc.) COKE BATTERY #9 BAGHOUSE Run No. 3 TOTAL

ENTER		PRESS	ALTERNATE PRESS
<u>.978</u>	AVG $\sqrt{F}$ Calculator prints entry.	A	A
<u>3.31</u>	AH Calculator prints entry.	R/S	SER 008
<u>111.5</u>	Ta-meter temperature °F Calculator prints entry and absolute temperature.	R/S	SER 012
<u>132</u>	Ts-stack temperature °F Calculator prints entry and absolute temperature.	R/S	SER 022
<u>.85</u>	Cp-pitot tube co-efficient Calculator prints entry.	R/S	SER 032
<u>72</u>	Q minutes in run Calculator prints entry.	R/S	SER 036
<u>.24</u>	DIAM NOZZLE IN INCHES Calculator prints entry and nozzle area.	R/S	SER 040
<u>30.07</u>	OR nozzle area in square feet Calculator prints entry.	SER 052	SER 052
<u>30.07</u>	Pbar-barometric pressure in inches in mercury Calculator prints entry.	R/S	SER 056
<u>-.62</u>	Ps-pressure of stack in inches of water. Calculator prints entry and absolute temperature.	R/S	SER 060
<u>96</u>	OR absolute pressure of stack in inches of mercury Calculator prints entry.	SER 070	SER 070
<u>96</u>	DIAM STACK IN INCHES Calculator prints entry and area in square feet	R/S	SER 074
<u>1</u>	OR-area of stack in square feet Calculator prints entry.	SER 086	SER 086
<u>1</u>	MM BTU/HR (enter best estimates available or enter 1 and disregard calculated result.) Calculator prints entry.	R/S	SER 090
<u>9500</u>	F. FACTOR DSCF/MM BTU (Federal Register 60.45, Laboratory factor, or enter 9500 and disregard calculated results). Calculator prints entry.	R/S	SER 094

ENTER		PRESS	ENTER	PRESS
<u>39</u>	Total milliliters of water (water plus silica gel) Calculator prints entry and volume of water vapor at standard conditions.	B	<u>0</u>	Z CO ₂ Calculator prints entry.
<u>032</u>	Total grams particulate collected (Subtract blank weight) Calculator prints out entry.	C	<u>18.75</u>	Z O ₂ Calculator prints entry.
<u>74.942</u>	Total volume gas metered (less allowed leaks and gas lost at filter changes) Calculator prints entry.	D	<u>0</u>	Z CO Calculator prints entry.
			<u>91.25</u>	Z H ₂ Calculator prints entry and molecular weight dry.

0.978
 3.31
 111.5
 571.5
 1327
 592
 0.85
 72
 0.24
 .0003141593
 30.07
 -0.62
 30.02441176
 96
 50.26548246
 1
 9500

39
 1.83573
 0.032

74.942

0
 18.75
 0
 91.25
 31.55

70.12 V/M DSCF
 2.55 % WATER
 31.20 M/S
 56.49 V/S
 10222608.72 ACFH
 8912296.91 DSCFH
 351.12 % EXCESS AIR

.0004563604 GM/CUFT
 12.28 PPM
 8.97 LB/HR
 8.966533107 LB/MMBTU
 .0095578127 LB/MMBTU (F FAC)

4024.840589
 38.36597669
 104.91 % ISO KINETIC

0.00704164

0.03 #/ton coke pushed

METHOD 5 SOURCE TEST FOR PARTICULATE

Today's Date ARIL 2, 1981
 Date of Test AUG 21, 1980
 Company US STEEL
 Location BIRMINGHAM, AL
 Run No. 4 TOTAL
 Test Performed on (stack, boiler, etc.) COKE BATTERY #9 BAGHOUSE

ENTER	PRESS	ALTERNATE PRESS
<u>.954</u> AVG $\sqrt{F}$ Calculator prints entry.	A	A
<u>3.03</u> A H Calculator prints entry.	R/S	SER 008
<u>109.8</u> In-meter temperature °F Calculator prints entry and absolute temperature.	R/S	SER 012
<u>132.9</u> In-stack temperature °F Calculator prints entry and absolute temperature.	R/S	SER 022
<u>.85</u> Cp-pitot tube co-efficient Calculator prints entry.	R/S	SER 032
<u>72</u> 0 minutes in run Calculator prints entry.	R/S	SER 036
<u>.240</u> DIAM NOZZLE IN INCHES Calculator prints entry and nozzle area.	R/S	SER 040
<u>30.06</u> OR nozzle area in square feet Calculator prints entry.	SER 052	SER 052
<u>30.06</u> Pbar-barometric pressure in inches in mercury Calculator prints entry.	R/S	SER 056
<u>-.64</u> Pa-pressure of stack in inches of water. Calculator prints entry and absolute temperature.	R/S	SER 060
<u>96</u> OR absolute pressure of stack in inches of mercury Calculator prints entry.	SER 070	SER 070
<u>96</u> DIAM STACK IN INCHES Calculator prints entry and area in square feet.	R/S	SER 074
<u>1</u> OR-area of stack in square feet Calculator prints entry.	SER 086	SER 086
<u>1</u> MM BTU/HR (enter best estimates available or enter 1 and disregard calculated result.) Calculator prints entry.	R/S	SER 090
<u>9500</u> F. FACTOR DSCF/MM BTU (Federal Register 60.45, laboratory factor, or enter 9500 and disregard calculated results). Calculator prints entry.	R/S	SER 094

ENTER	PRESS	ENTER	PRESS
<u>37.0</u> Total milliliters of water (water plus silica gel) Calculator prints entry and volume of water vapor at standard conditions.	B	<u>0</u> % CO ₂ Calculator prints entry.	X
<u>0.370</u> Total grams particulate collected (Subtract blank weight) Calculator prints out entry.	C	<u>19.375</u> % O ₂ Calculator prints entry.	R/S
<u>72.134</u> Total volume gas metered less allowed leaks and gas lost at filter changes) Calculator prints entry.	D	<u>0</u> % CO Calculator prints entry.	R/S
		<u>80.625</u> % H ₂ Calculator prints entry and molecular weight dry.	R/S

0.954

3.03

109.8

569.8

132.9

592.9

0.85

72

0.24

0003141593

30.06

-0.64

30.01294118

96

50.26548246

1.

9500.

37.

1.74159

0.0378

72.134

0.

19.375

0.

80.625

28.775

67.63 V/M DSCF

2.51% WATER

28.50 M/S

57.71 V/S

10443231.39 ACFH

9091125.26 DSCFH

1014.40% EXCESS AIR

0005589587 GM/CUFT

16.49 PPM

11.20 LB/HR

11.20274112 LB/MMBTU

0117065361 LB/MMBTU (F FAC)

3885.956475

39.17901116

99.48% ISOKINETIC

0086247324

0.04 #/ton coke pushed

Post-test DGM Calibration

$$D_{\text{dgm}} = 30.18$$

$$P_{\text{dgm}} = 30.28$$

$$Y = \frac{14.736 \cdot 30.18 \cdot 582}{15.372 \cdot 30.28 \cdot 543} = 1.02$$

$$= \frac{14.186}{14.792} = 1.02$$

$$= \frac{16.448}{17.188} = 1.02$$

Avg 1.02

$$PMR_c = \frac{m}{Q_m} \cdot \frac{Q_s}{\theta} = \frac{0.032 \text{ g}}{0.2 \text{ hr}} \times \frac{\#}{454 \text{ g}} \times \frac{155,291 (60) \text{ ft}^3}{70.619 \text{ ft}^3} = 7.75 \frac{\#}{\text{hr}}$$

$$PMR_a = \frac{0.032 \text{ g}}{1.2 \text{ hr}} \times \frac{\#}{454 \text{ g}} \times \frac{50.2656}{0.000314} = 9.4 \frac{\#}{\text{hr}}$$

$$\% \text{ I} = \frac{PMR_a}{PMR_c} \times 100 = \frac{9.4}{7.75} \times 100 = 121 \%$$

~~30.28~~
~~14.736~~ ~~582 x 30.18~~
~~15.372~~ ~~(28.516 x 488.5 x 30.28)~~

$$P_{WTM} = 30.10 - \left(\frac{-1.1}{13.6} \right) = 30.18$$

$$P_{dgm} = 30.10 + \frac{2.5}{13.6} = 30.28$$

$$Y_1 = \frac{6.294 (30.10) 562}{6.265 (30.12) 487.7} \cdot \frac{1.16}{1.16} = 1.04$$

542

$$= \frac{8.763}{8.633} \cdot \frac{30.12 \cdot 562}{30.15 \cdot 542} = 1.05$$

$$= \frac{10.606}{10.554} \cdot \frac{30.13 \cdot 563}{30.19 \cdot 542} = 1.04$$

$$= \frac{12.452}{12.44} \cdot \frac{30.15 \cdot 564}{30.22 \cdot 542} = 1.04$$

$$= \frac{13.65}{13.453} \cdot \frac{30.16 \cdot 565}{30.26 \cdot 542} = 1.05$$

Avg = 1.04 ✓

Pre test
DGM calibration