

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

MASS EMISSION TESTS

CONDUCTED ON THE

COKE BATTERY POSITIVE PUSHING CONTROL SYSTEM

IN


BIRMINGHAM, ALABAMA

FOR

JIM WALTERS RESOURCES

ON

NOVEMBER 6-7, 1984


Approved by: 

Tom Lotz
Director
Field Services Division

TABLE OF CONTENTS

Chapter		Page
I	Introduction and Test Description	1
II	Summary of Test Results	2
	Tables	
	1 VE Summaries	3
	2 Summarized Particulate Results	4
	Computer Input Parameters..	5
	Complete Test Results..	6
III	Sampling and Analytical Procedure	8
	Figures	
	1 Stack Breeching Diagram	
	And Sample Point Location	11
	2 Particulate Sampling Train	12
IV	Field Data	
	Nomenclature	13
	Equations	16
	Data Sheets	18
	Particulate Analysis	21
	VE Sheets for Coke Battery.....	28
	VE Sheets for Stack	31
V	Plant Operational Data	37
VI	Calibrations	41

Introduction



L. INTRODUCTION AND TEST DESCRIPTION


On November 6-7, 1984, Guardian Systems, Inc. performed a series of particulate emissions tests on the Coke Battery Positive Pushing Control System of Jim Walters Resources located in Birmingham, Alabama. These tests were conducted in accordance to the rules and regulating expressed in the Code of Federal Regulations, Title 40, Section 60, Reference Methods 1-5 as amended.

The Push Control System consists of a movable hood assembly which travels with the car and a baghouse for particulate removal. The damper on the baghouse fan is closed when not in use and is open by radio control when the coke is pushed. The sampling time for particulate emissions started when the pusher machine ram began moving forward and stopped when the emissions captured were collected by the baghouse. Only one push was sampled per traverse point and the sampling time varied for each push. Visible Emissions were monitored at the pushing emission control device outlet (stack) and at the pushing operation around the battery by Jefferson County Health Department Personnel.

The following personnel were present during the actual field sampling and represented the companies indicated:

Mr. Dan Schrimsher	Jim Walters Resources
Mr. Ken Walton	Jim Walters Resources
Ms. Veda Hampton	Jefferson County Health Dept.
Mr. Keith Witherspoon	Jefferson County Health Dept.
Mr. George Duckworth	Jefferson County Health Dept.
Mr. Tom Lotz	Guardian Systems, Inc.
Mr. Greg Karstens	Guardian Systems, Inc

Test Results



II. SUMMARY OF TEST RESULTS

The following table gives the results of the tests conducted on the Coke Battery Positive Pushing Control System on November 6-7, 1984. The allowable emission rate 0.03 pounds per ton of coal charged. The figures are presented in two formats; one by calculation of coal and particulate in pounds per test and the second in pounds per hour.

<u>RUN #</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>Avg.</u>
Sample time per test, Minutes	22.14	25.44	27.06	24.88
Coal charged per test, Tons	336	336	336	336
Particulate Mass Rate lbs/test	3.65	4.23	1.80	3.23
Emissions lbs/ton of coal charged	0.01	0.01	0.01	0.01
*Particulate Mass Rate lbs/hr	9.89	9.97	4.00	7.95
*Coal charged Tons/hour	910.6	792.5	745.0	816.0
Emissions lbs/ton of coal charged	0.01	0.01	0.01	0.01

* The particulate mass rate and the coal charged are both presented in hourly rates even though the individual test times were less than an hour. This was accomplished by using a ratio of the time sampled to 60 minutes or one hour.

Visual Emissions Summaries
Around Push Control

<u>RUN #</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>Avg.</u>
Sample time per test, Seconds	1328	1526	1624	1493
Time greater than 20% opacity, seconds	57	24	21	34
% greater than, 20 % opacity	4.3	1.6	1.3	2.3
Highest opacity, %	30	30	30	30

Data was taken from the VE Sheets found in the **Field Data** Section.

Stack Opacity

<u>RUN #</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>Avg.</u>
Opacity, %	0	0	0	0

Table 1

GUARDIAN ** SYSTEMS ** INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Summarized Air Test Results for Jim Watters Resources
Job Number 48032

	1	2	3	4
DATE OF TEST	11/06/84	11/06/84	11/07/84	11/09/84
TIME OF TEST	0820-1348	1404-1054	1105-1622	Average
LOCATION OF TEST	STACK	STACK	STACK	Average
STACK GAS TEMPERATURE DEGREES F	81	85	90	85
MOISTURE CONTENT, % V/V	5.34	5.32	4.92	5.18
OXYGEN CONTENT, % V/V	20.50	20.00	19.50	20.00
CARBON DIOXIDE CONTENT, % V/V	0.00	0.50	1.00	0.20
STACK GAS VELOCITY FEET PER SECOND	71.49	70.49	70.66	71.10
VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE	181,159	178,652	179,075	180,208
VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE	168,915	165,561	165,283	167,234
CONCENTRATION GRAINS PER DRY STANDARD CUBIC FOOT	0.007	0.007	0.003	0.005
CONCENTRATION GRAINS PER ACTUAL CUBIC FOOT	0.006	0.007	0.003	0.005
PARTICULATE MASS RATE (W/HR.)	9.89	9.97	4.00	7.82
% ISOKINETIC	106.60	104.54	105.00	104.84

Table 2

GUARDIAN ** SYSTEMS ** INCORPORATED
P.O. BOX 380
LEEDS, AL 35094
205-699-6647

Computer Input Parameters for Jim Walters Resources
Job Number 48032

RUN NUMBER	1	2	3	4
DATE	11/06/84	11/06/84	11/07/84	11/09/84
LOCATION	STACK	STACK	STACK	Average
TIME	0820-1348	1404-1854	1105-1622	Average
BAROMETRIC PRESSURE (IN. HG)	30.22	30.25	30.28	30.25
STATIC PRESSURE (IN. H2O)	- 0.300	- 0.280	- 0.340	- 0.310
RUN TIME (MINUTES)	22.14	25.44	27.06	74.64
METER VOLUME (CORRECTED)	16.013	17.874	19.337	53.224
STACK TEMPERATURE (°F)	81.00	85.00	90.00	85.00
METER TEMPERATURE (°F)	54.00	60.00	68.00	61.00
METER PRESSURE (IN. H2O)	1.60	1.58	1.59	1.59
SQR VELOCITY PRESSURE	1.250	1.230	1.230	1.240
MASS OF PARTICULATE (MG.)	7.4	8.4	3.6	19.4
ML. OF WATER COLLECTED	20.0	22.0	21.6	63.6
% OXYGEN	20.5	20.0	19.5	20.0
% CARBON DIOXIDE	0.0	0.5	1.0	0.2
% CARBON MONOXIDE	0.0	0.0	0.0	0.0
STACK AREA (SQ. FT.)	42.24	42.24	42.24	42.24
PITOT CORRECTION FACTOR	0.84	0.84	0.84	0.84
NOZZLE DIAMETER (IN.)	0.180	0.180	0.180	0.180

GUARDIAN ** SYSTEMS ** INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Computed Air Test Results for Jim Walters Resources
Job Number 48032


RUN NUMBER				
	1	2	3	4
DATE OF TEST	11/06/84	11/06/84	11/07/84	11/09/84
LOCATION OF TEST	STACK	STACK	STACK	Average
1. STACK PRESSURE INCHES HG MILLIMETERS HG	30.20 767.03	30.23 767.83	30.25 768.48	30.23 767.77
2. METER PRESSURE INCHES HG MILLIMETERS HG	30.34 770.58	30.37 771.30	30.40 772.08	30.37 771.32
3. METER VOLUME DRY STANDARD CUBIC FEET DRY STANDARD CUBIC METERS	16.679 0.472	18.420 0.522	19.645 0.556	54.745 1.550
4. WATER VOLUME STANDARD CUBIC FEET STANDARD CUBIC METERS	0.941 0.027	1.036 0.029	1.017 0.029	2.994 0.085
5. MOISTURE CONTENT (%)	5.34	5.32	4.92	5.18
6. MOLECULAR WEIGHT DRY	28.82	28.88	28.94	28.83
7. MOLECULAR WEIGHT WET	28.24	28.30	28.40	28.27
8. STACK VELOCITY FEET PER SECOND METERS PER SECOND	71.49 21.79	70.49 21.49	70.66 21.54	71.10 21.67
9. VOLUMETRIC FLOW ACTUAL CUBIC FEET PER MINUTE ACTUAL CUBIC METERS PER SECOND	181.159 85.50	178.652 84.31	179.075 84.51	180.208 85.05
10. VOLUMETRIC FLOW DRY STANDARD CUBIC FEET PER MINUTE DRY STANDARD CUBIC METERS PER SECOND	168.915 79.72	165.561 78.14	165.283 78.01	167.234 78.93

GUARDIAN ** SYSTEMS ** INCORPORATED
P.O. BOX 300
LEENS, AL 35094
205-699-6647

Computed Air Test Results for Jim Walters Resources
Job Number 48032

RUN NUMBER	1	2	3	4
DATE OF TEST	11/06/84	11/06/84	11/07/84	11/09/84
LOCATION OF TEST	STACK	STACK	STACK	Average
11. CONCENTRATION				
GRAINS PER DRY STANDARD CUBIC FOOT	0.0068	0.0070	0.0028	0.0055
GRAMS PER DRY STANDARD CUBIC METER	0.0156	0.0161	0.0065	0.0125
15. PARTICULATE MASS RATE (W/HR.)	9.89	9.97	4.00	7.82
16. VOLUME AT NOZZLE				
ACTUAL CUBIC FEET	17.889	19.877	21.286	58.995
ACTUAL CUBIC METERS	0.507	0.563	0.603	1.671
17. CONCENTRATION				
GRAINS PER ACTUAL CUBIC FOOT	0.0064	0.0065	0.0026	0.0051
GRAMS PER ACTUAL CUBIC METER	0.0146	0.0149	0.0060	0.0116
18. % ISOKINETIC	106.60	104.54	105.00	104.84

Sampling & Analytical Procedures



III. METHOD 5 SAMPLING AND ANALYTICAL PROCEDURES

General

All sampling and analytical procedures for determination of the particulate emissions from this source were conducted in strict adherence with the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 1-5 as amended. The equipment used in this test was manufactured by Research Appliance Corporation and was properly calibrated before these tests (See **Calibrations**). The particulate mass was determined gravimetrically after removal of uncombined water.

METHOD 1

This method was used to determine the number of sampling points and the required matrix. The dimensions of the stack (see **Figure 1**) indicated that 24 points would be required to sample this source. We sampled 24 points (12 per diameter) for the time of a cycle at each point. Verification of absence of cyclonic flow was not determined because there was no tangential entry and cyclonic flow did not seem to exit from the stack exhaust.

METHOD 2

Velocity measurements were taken using a properly calibrated S type pitot tube and a 0-10 inch inclined manometer.

METHOD 3

Gas analysis for CO₂, O₂, and N₂ by difference was performed by using the grab sample technique twice during each test and analyzed with a Fyrite Gas Analyzer (0-20% scale with 0.5% divisions).

METHOD 4

Moisture content of the stack gases was determined in conjunction with Method 5 for each test by measuring the amount of water collected in the condenser and the increase in weight of the silica gel. These weights were combined to give the total amount of water collected.

METHOD 5

Sampling Techniques

Previous data was used to determine stack temperature, pressure, range of velocity heads, moisture content and stack gas dry molecular weight prior to sampling. A Monroe 1830 programable calculator or a Radio Shack PC-4 computer and a TI55 were used to calculate the sampling rate for isokinetic sampling. The particulate determinations were made by utilizing the sample train in **Figure 2**. The meter box was leak checked from the pump to the orifice and initial and final leak checks of the sampling system and pitot lines were performed as outlined in Method 5 and were recorded on the data sheets (**See Field Data**). The nozzle (stainless steel 316 with an angle of taper of 30° and of button hook design) was calibrated before and after each test using a micrometer and was also recorded on the data sheets.

The sampling probe was placed at each sampling point and the gases were drawn through a stainless steel nozzle attached to a heated glass lined probe. The probe was maintained at the proper setting to obtain an exit temperature of $248 \pm 25^{\circ}\text{F}$ (**See Calibrations**). The gases then pass through a glass fiber filter (Gelman, Class A) of 0.3 micron retention to remove particulate matter. The filter was maintained at a temperature of $248 \pm 25^{\circ}\text{F}$. These temperatures were recorded at each point on the data sheets.

The gases then pass through a condenser placed in an ice bath to maintain a maximum exit temperature of 68°F . This temperature was also recorded on the data sheets. The gases then pass through a pre-weighed drying column filled with indicating silica gel to remove any remaining moisture. The clean and cool gases then entered the meter box where the gas flow and temperature were measured and recorded.

Upon completion of the sampling and the final leak checks the gel column and the probe nozzle-filter holder assembly was transferred to the cleanup area making sure no particulate was lost. The cleanup data was recorded on **Particulate Sample Recovery and Integrity Sheet** located in the Field Data Section. Particulate catches were placed in sealed petri dishes. Each acetone rinse from the nozzle, probe, and filter holder was combined and placed in a sealed container. For the group of tests an acetone blank of approximately 200 milliliters was placed in a sealed container. These containers were clearly marked and transported to our laboratory for analysis.

Analysis

The Filter (Gelman, Class A, without organic binder, minimum 99.9% retention for particles of 0.3 microns as determined by DOP tests) were prepared for the field test by first heating for 2 hours 220°F then desiccating at $68 \pm 10^{\circ}\text{F}$ at ambient pressure for 24 hours and weighing at intervals of at least six (6) hours to a constant weight to the nearest 0.1 milligrams (less than 0.5 milligrams change from previous reading). Upon return to the laboratory, the filters were subjected to the same procedures as outlined above. The weights were recorded in a bound laboratory book and transferred to the sheets in this report (**Method 5 Train Analytical Particulate Data**). During each weighing the filter was not exposed to laboratory atmosphere for more than two (2) minutes and a relative humidity of less than fifty percent (50%).

The acetone blank (reagent grade, 0.001 % residue, in glass bottles) (**Blank Analytical Data**) for the group of tests and the acetone rinses for each test were evaporated to dryness in tared glass beakers. They were then desiccated for twenty-four (24) hour and weighed to a constant weight as describe above.

Point No.	Distance from wall
12	1.9
11	5.9
10	10.4
9	15.6
8	22.0
7	31.3
6	56.7
5	66.0
4	72.4
3	77.6
2	82.1
1	86.1




Figure 1





Figure 2

Field Data



NOMENCLATURE

ACF	- Actual Cubic Feet
ACFM	- Actual Cubic Feet per minute
ACM	- Actual Cubic Meters
ACMS	- Actual Cubic Meters per second
An	- Cross sectional area of nozzle, (ft ²)
As	- Area of Stack, (ft ²)
Bws	- Water vapor in the gas stream, proportion by volume (dimensionless)
Ca	- Acetone blank residue concentration, mg/g
c _a	- Particulate Concentration, ACF
CFM	- Cubic feet per minute
Cp	- Pitot tube coefficient, (dimensionless)
c _s	- Particulate Concentration, grains/DSCF
Cso ₂	- Concentration of sulfur dioxide (dry basis) corrected to standard conditions, lb/DSCF
C ₁₂	- Particulate concentration (c _s adjusted to 12% excess air), grains/DSCF
C ₅₀	- Particulate concentration (c _s adjusted to 50% excess air), grains/DSCF
DSCF	- Dry Standard Cubic Feet
DSCFM	- Dry Standard Cubic Feet per minute
DSCM	- Dry Standard Cubic Meters
DSCMS	- Dry Standard Cubic Meters per second
EA	- Excess Air, %
I	- Isokinetic Sampling, %
Km	- Orifice Correction Factor, (dimensionless)
Kp	- Pitot tube constant, 85.49 $\left[\frac{(\text{lb/lb-mole})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right]^{1/2}$

NOMENCLATURE - continued

- La - Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to 0.02 CFM or 4 percent of the average sampling rate, whichever is less.
- Li - Individual leakage rate observed during the leak check conducted prior to the "ith" component change ($i = 1, 2, 3, \dots, n$), CFM.
- Lp - Leakage rate observed during the post test leak check, $\text{ft}^3/\text{min. (cfm)}$.
- Ma - Mass of residue of acetone after evaporation, mg.
- Md - Molecular weight of stack gas; dry basis, lb/lb-mole.
- Mn - Total amount of particulate matter collected, mg.
- Ms - Molecular weight of stack gas; wet basis, lb/lb-mole.
- Mw - Molecular weight of water, 18.0 g/g-mole (18.01 lb/lb-mole)
- ΔP - Velocity head of stack gas, in. H_2O
- Pa - Density of acetone, mg/ml
- Pbar - Barometric pressure at the sampling site, in. Hg
- Pg - Stack static pressure, in. H_2O
- Pm - Meter pressure, in. Hg
- PMR - Particulate Mass Rate, lbs per hour
- Ps - Absolute stack pressure, in. Hg
- Pstd - Standard absolute pressure, 29.92 in. Hg
- Pw - Density of water, 0.9982 g/ml (0.002201 lb/ml)
- Qa - Volumetric flow rate, ACFM
- Qs - Volumetric flow rate, DSCFM
- R - Ideal gas constant, 0.06236 mm Hg - $\text{m}^3/^\circ\text{K-g-mole}$
(21.85 in. Hg- $\text{ft}^3/^\circ\text{R-lb-mole}$)
- SCF - Standard Cubic Foot
- ta - Ambient Temperature, $^\circ\text{F}$
- tm - Average Temperature of meter, $^\circ\text{F}$
- ts - Average Temperature of stack, $^\circ\text{F}$

NOMENCLATURE - continued

tstd - Standard Temperature, 68°F

NOTE: Capital "T" denotes degrees Rankin

Va - Volume of acetone blank, ml

Vaw - Volume of acetone used in wash, ml

Vlc - Total volume of liquid collected in condenser and silica gel, ml

Vm - Volume of gas sample, as measured by the dry gas meter, ACF

Vmc - Volume of gas sample, corrected for leak, ACF

Vm(std) - Volume of gas sample measured by the dry gas meter, corrected to standard conditions, DSCF

Vn - Volume collected at stack conditions through nozzle, ACF

Vs - Average stack gas velocity, ft/sec.

Vw(std) - Volume of water in the gas sample, corrected to standard conditions, SCF

Wa - Weight of residue in acetone wash, mg

Y - Dry gas meter calibration factor, (dimensionless)

ΔH - Average pressure differential across the calibrated orifice, in. H₂O

ΔH_a - Value of ΔH measured for a specific orifice when operated under the following conditions: 0.75 cfm of dry air (M.W. = 29) at 68°F, 29.92 in. Hg.

$\sqrt{\Delta P}$ - Average of the square roots of the velocity pressure, in. H₂O

θ - Total sampling time, min.

θ_1 - Sampling time interval from the beginning of a run until the first component change, min.

θ_i - Sampling time interval between two successive component changes, beginning with the interval between the first and second changes, min.

θ_p - Sampling time interval from the final (n^{th}) component change until the end of the sampling run, min.

%CO₂, %O₂, %N₂, %CO - Number percent (%) by volume (dry basis) of each compound in the stack gas.

EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\Delta H}{13.6}$$

$$3. \quad V_{m(\text{std})} = V_m Y \left(\frac{T_{\text{std}}}{T_m} \right)$$

$$\left[\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{P_{\text{std}}} \right]$$

$$4. \quad V_w(\text{std}) = 0.04707 V_{1c}$$

$$5. \quad B_{ws} = \frac{V_w(\text{std})}{V_{m(\text{std})} + V_w(\text{std})}$$

$$6. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$7. \quad M_s = M_d (1 - B_{ws}) + 18(B_{ws})$$

$$8. \quad v_s = K_p C_p (\sqrt{\Delta p}) \text{ avg.}$$

$$\sqrt{\frac{T_s}{M_s P_s}}$$

$$9. \quad Q_a = (v_s) (A_s) (60)$$

$$10. \quad Q_s = Q_a (1 - B_{ws}) \left(\frac{528}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$

$$11. \quad c_s = [0.0154 (Mn/V_{mstd})]$$

$$12. \quad EA = \left[\frac{\%O_2 - 0.5 \%CO}{0.264 \%N_2 (\%O_2 - 0.5 \%CO)} \right] 100$$

$$13. \quad c_{50} = \frac{c_s}{1 - \left[\frac{(1.5)(\%O_2) - 0.133(\%N_2) - 0.75 (\%CO)}{21} \right]}$$

$$14. \quad c_{12} = c_s \frac{12}{\%CO_2}$$

EQUATIONS - continued

$$15. \quad \text{PMR} = (c_s)(Q_s) \left(\frac{60}{7000} \right)$$

$$16. \quad V_n = \frac{T_s}{P_s} \left[(0.002669)(V_{1c}) + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6} \right) \right]$$

$$17. \quad C_a = (0.0154)(M_n) / V_n$$

$$18. \quad I = \frac{100 V_n}{60 \theta v_s A_n}$$

$$19. \quad V_{mc} = V_m - (L_p - L_a) \theta$$

$$20. \quad W_a = C_a V_a w p_a$$

FIELD DATA SHEET

PLANT

JIM WALTERS RUN # 1

LOCATION

BAGHOUSE STACK DATE 11-6-84

BARO. PRES.

30.72

TIME

0820-1348

GUARDIAN SYSTEMS INC.

2510 18th Street South
Birmingham, Alabama 35209
205/878-1860

	TIME		METER VOL FT 3	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE H ₂ O	VELOCITY PRESSURE H ₂ O	VACUUM PRESSURE H _g	STATIC PRESSURE "H ₂ O	
	MIN	DUR			IN	OUT	AVG						BEFORE	AFTER
A			184.079	(1)	(2)	(3)	(4)	(5)						7.30
1	36	17	184.5	78	47	47	47	35	223	1.88	1.85	31		
2	69	60	185.4	81	50	50	50	41	260	1.49	1.45	2.9	.180	.180
7	62	52	186.1	81	51	50	51	38	234	1.41	1.38	2.7	.180	.180
4	60	85	186.8	79	50	50	50	42	238	1.46	1.43	2.8		
5	44	41	187.3	78	51	51	51	41	253	1.45	1.42	2.8		
6	38	67	187.7	79	51	51	51	38	234	1.62	1.58			
7	44	21	188.2	79	51	51	51	34	266	1.41	1.38	2.6		
8	51	48	188.8	79	54	54	54	35	249	1.67	1.62	3.1		
9	49	35	189.4	82	55	55	55	36	242	1.52	1.48	3.0		
10	46	98	189.9	83	56	56	56	36	251	1.60	1.55	3.1		
11	48	27	190.5	83	57	57	57	34	253	1.73	1.68	3.5		
12	47	28	191.1	86	53	55	54	32	252	1.56	1.53	3.1		
B														
1	60	87	191.8	81	55	54	55	32	248	1.76	1.71	3.4		
2	59	14	192.6	82	55	54	55	33	238	2.11	2.05	3.9		
3	68	12	193.6	82	54	54	54	33	228	2.11	2.05	3.8		
4	58	59	194.2	83	54	54	54	32	233	1.39	1.35	2.5		
5	44	49	194.7	79	55	55	55	32	237	1.35	1.32	2.2		
6	43	05	195.2	85	57	56	56	32	242	1.62	1.58	3.1		
7	114	56	196.6	82	56	55	56	33	239	1.60	1.55	3.0		
8	44	10	197.1	81	55	55	55	34	265	1.46	1.42	3.1		
9	49	95	197.7	79	56	57	56	32	259	1.64	1.64	3.5		
10	46	30	198.2	83	58	57	57	33	261	1.54	1.49	3.2		
11	84	50	199.3	81	57	57	57	33	248	1.57	1.52	3.3		
12	54	16	199.863	78	57	57	57	32	268	1.42	1.36	2.8		
			15.784 X 1.0145											
24		22.14	16.013	81			54			1.60	1.25	3.9		

PROBE TIP SIZE
BEFORE AFTER.180 .180
.180 .080
.180 .180WATER
RED #1
ml. 17.0
gram 3
Total 20.0OPERATOR
LOTZ/KARSTENSample Box No. 4
Meter Box No. 400
Meter ΔH₀ 1.70
Pitot, CP .8Y
Temp. Device RTT
Probe No. 8-1
Probe Liner GLASS
Probe Htr. Set 500
Ambient Temp. 43°
% O₂ 20.5 20.5
% CO₂ 0 0NOTES
Orifice 1.06.1
Pitot ✓
Meter ✓184.078
184.068
0.0192
@ 7.246.1
FINAL AT 40" H₂O
.012
48
7.1

FIELD DATA SHEET

GUARDIAN SYSTEMS INC.

2010 18th Street South
Birmingham, Alabama 35209
205/879-1850PLANT JIM WALKERRUN # 2LOCATION PAVING JMCDATE 11-6-84BARO. PRES. 30.72TIME 1404-1555/0817-1054

	TIME		METER VOL FT 3	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	VACUUM PRESSURE "Hg	STATIC PRESSURE "H ₂ O	
	MIN	DUR			IN	OUT	AVG						T. 28	
			200.920	(1)	(2)	(3)	(4)	(5)					PROBE TIP SIZE	
													BEFORE	AFTER
B1	41	28	201.5	80	60	59	60	33	224	2.19	2.10	2.8	.180	.180
2	49	56	202.2	82	61	60	61	36	242	1.97	1.89	2.7	.180	.180
3	73	23	203.0	82	60	61	61	35	251	1.33	1.28	1.7	.180	.180
4	58	38	203.6	81	61	61	61	36	228	1.52	1.46	2.1		
5	47	55	204.1	86	62	62	62	38	243	1.46	1.35	1.9		
6	50	73	204.7	85	61	61	61	38	231	1.56	1.51	1.7		
7	39	38	205.2	85	61	61	61	37	254	1.59	1.53	1.8		
8	59	23	205.8	83	61	62	62	39	272	1.70	1.63	2.0		
9	59	67	206.5	83	61	62	62	39	269	1.31	1.26	1.5		
10	53	68	207.2	86	61	62	62	40	263	1.94	1.87	2.1		
11	47	43	207.8	89	62	62	62	41	264	1.67	1.62	1.8		
12	74	12	208.600	86	62	62	62	41	259	1.37	1.33	1.6		
A			209.065	11-7-84	B. P. 30.28									
1	58	87	209.9	83	64	63	64	32	269	1.65	1.57	2.2		
2	70	30	210.7	85	59	58	59	41	265	1.88	1.82	2.4		
3	63	28	211.4	86	58	57	58	38	232	1.96	1.43	1.7		
4	76	86	212.3	82	57	56	57	35	227	1.41	1.36	1.7		
5	90	03	213.2	84	56	56	56	33	232	1.35	1.31	1.6		
6	122	40	214.4	86	57	56	57	33	231	1.32	1.29	1.5		
7	70	93	215.3	91	58	57	58	34	242	1.32	1.30	1.5		
8	59	58	215.9	88	59	58	59	33	231	1.36	1.32	1.5		
9	61	79	216.7	86	60	60	60	33	270	1.69	1.64	2.0		
10	88	28	217.7	87	61	60	61	33	233	1.73	1.68	2.1		
11	59	73	218.4	87	61	61	61	33	247	1.59	1.54	2.1		
12	49	89	219.004	91	62	62	62	33	270	1.55	1.51	2.0		
			17.619 x 1.0145							1.58	1.23			
24		25.44	17.874	85			60		FINA			2.8		

#5 WATER

ml. 18.2gram 3.8Total 22.0

OPERATOR

LO72/KARSTEN'S

(11)

Sample Box No. 4Meter Box No. 100Meter ΔH@ 1.70Pitot, CP .84Temp. Device STTProbe No. 8-2Probe Liner GLASProbe Htr. Set 50%Ambient Temp. 58°% O₂ 20.5 19.5% CO₂ 0 1

NOTES

Orifice ✓Pitot ✓Meter ✓

SG.8

R 4.2

.014 of 25" Hg

LEAK CHECK at 5' Hg

.012

57.3

R.L.C

57.1

R.C.V

FIELD DATA SHEET

GUARDIAN SYSTEMS INC.

2510 18th Street South
Birmingham, Alabama 35209
205/878-1880

PLANT

JIM WALTER

RUN #

#3

LOCATION

RAHWUSE STAKE

DATE

11-7-84

BARO. PRES.

30.28

TIME

1105-1622

	TIME		METER VOL FT 3	STACK TEMP OF	METER TEMP. OF			IMP TEMP OF	BOX TEMP OF	METER PRESSURE "H ₂ O	VELOCITY PRESSURE "H ₂ O	VACUUM PRESSURE "Hg	STATIC PRESSURE "H ₂ O	
	MIN	DUR			IN	OUT	AVG						+3.34	
A			219.120	(1)	(2)	(3)		(4)	(5)				PROBE TIP SIZE BEFORE AFTER	
1	58	04	219.8	88	62	62	62	36	224	1.53	1.48	2.4	1180	1180
2	71	01	220.7	89	63	63	63	33	228	1.77	1.71	3.1	1180	1180
3	54	42	221.3	89	64	63	64	32	230	1.79	1.73	3.1	1180	1180
4	51	11	221.9	83	65	65	65	32	271	1.43	1.36	2.7		
5	86	27	222.8	88	67	66	67	34	269	1.32	1.27	2.7	No # WATER	
6	58	79	223.5	87	67	67	67	32	243	1.30	1.34	2.6	ml.	18.0
7	48	06	224.7	88	68	67	68	32	270	1.62	1.55	3.1	gram	3.1
8	52	56	225.3	84	70	68	69	32	253	1.39	1.32	2.9	Total	21.6
9	48	71	225.9	94	70	69	70	33	268	1.64	1.58	3.2	OPERATOR	
10	55	33	226.5	85	69	69	69	34	272	1.67	1.59	2.9	LOTZ /	
11	60	72	227.2	88	67	67	67	43	262	1.33	1.28	2.6	KARNTENS	
12	48	84	227.7	87	67	67	67	44	273	1.40	1.34	2.7	Sample Box No. 4	
B													Meter Box No. 400	
1	135	52	229.5	89	66	66	66	44	243	1.99	1.92	3.6	Meter ΔH@ 1.70	
2	60	23	230.2	95	66	66	66	44	250	2.13	2.07	3.8	Pitot, CP 84	
3	47	41	230.9	93	67	66	67	44	265	1.93	1.87	3.4	Temp. Device 32TT	
4	83	81	231.8	92	67	66	67	45	268	1.22	1.18	2.1	Probe No. 8-1	
5	90	69	232.8	91	67	66	67	45	269	1.50	1.45	2.7	Probe Liner GLASS	
6	52	20	233.4	95	67	67	67	46	258	1.55	1.51	2.8	Probe Htr. Set 552	
7	104	08	234.6	94	69	68	69	48	241	1.46	1.41	2.7	Ambient Temp. 65°	
8	56	39	235.3	93	70	69	70	45	252	1.57	1.51	2.6	% O ₂ 19.5 19.5	
9	42	60	235.8	93	71	70	71	46	262	1.75	1.68	3.2	% CO ₂ 1.0 1.0	
10	70	02	236.6	93	71	70	71	46	271	1.72	1.65	2.6	NOTES	
11	55	09	237.3	91	71	71	71	46	269	1.64	1.57	3.0	Orifice	
12	81	68	238.181	93	71	70	71	46	254	1.31	1.26	2.4	Pitot	
24		27.06	19.061	90			68			1.59	1.23	3.8	Meter	

55.0
28.3OIO at 15" H₂OS 5.6
R 6.4FINAL LEAK CHECK
at 40" H₂O
.009

BLANK ANALYTICAL DATA

Plant JIM WALTER COKE
 Sample location BAGHOUSE STACK
 Relative humidity 20%
 Type of blank ACETONE
 Liquid level at mark and container sealed ✓
 Density of blank (pa) .7852 g/ml
 Blank volume (Va) 200 ml
 Date and time of wt. 11-8-84 0700 Gross wt. 918.6 mg
 Date and time of wt. 11-8-84 1300 Gross wt. 918.7 mg
 Average gross wt. 918.65 mg
 Tare wt. 918.6 mg
 Weight of blank (ma) .05 mg

$$Ca = \frac{ma}{Va \cdot pa} = \frac{(0.05)}{(200)(.7852)} = .000318 \text{ mg/g}$$

Note: In no case shall a blank residue greater than (0.01 mg/g) or 0.001% of the weight of blank used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: JIM WALTER Sample date: 11-6-84
Sample location: BAGHOUSE STACK Run no.: #1
Sample recovery person: KARSTENS Recovery date: 11-6-84
Filter(s) no.: K-18

MOISTURE

Impingers Silica gel
Final volume (wt) 17 ml (gm) Final wt. 930.5 g 930.5 g
Initial volume (wt) 0 ml (gm) Initial wt. 927.5 g 927.5 g
Net volume (wt) 17 ml (gm) Net wt. 3.0 g 3.0 g
Total moisture 20.0 g
Color of silica gel Mixed
Description of impinger water Clear

RECOVERED SAMPLE

Filter container no. Run #1 sealed ✓
Description of particulate on filter Light Grey

Acetone rinse container no. Run #1 Liquid level marked ✓
Acetone blank container no. Blank Liquid level marked ✓
Samples stored and locked ✓

Remarks: _____

Date of laboratory custody NA

Laboratory personnel taking custody —

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant JIM WALTER COKE Run No. #1
 Sample location BAGHOUSE STACK
 Relative humidity 20%
 Density of acetone (pa) 7852 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse filter(s)	✓	✓

Acetone rinse container no. #2

Acetone rinse volume (Vaw) 230 ml

Acetone blank residue concentration (Ca) .000318 mg/g

Wa = Ca Vaw pa = $(.000318)(230)(7852) =$.06 mg

Date and time of wt 11-8-84 0700 Gross wt 110216.2 mg

Date and time of wt 11-8-84 1300 Gross wt 110286.3 mg

Average gross wt 110286.25 mg

Tare wt 110278.4 mg

Less acetone blank wt (Wa) .1 mg

Weight of particulate in acetone rinse 7.75 mg

Filter(s) container no. K-18

Date and time of wt 11-8-84 0700 Gross wt 237.8 mg

Date and time of wt 11-8-84 1300 Gross wt 238.3 mg

Average gross wt 238.05 mg

Tare wt 238.4 mg

Weight of particulate on filter(s) -.35 mg

Weight of particulate in acetone rinse 7.75 mg

Total weight of particulate 7.4 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: JIM WALTER Sample date: 11-6/7/84
Sample location: BAGHOUSE SMACK Run no.: #2
Sample recovery person: KARSTEN'S Recovery date: 11-7-84
Filter(s) no.: K-17

MOISTURE

Impingers	Silica gel
Final volume (wt) <u>18.2</u> ml (gm)	Final wt. <u>957.4g</u> <u>957.4g</u>
Initial volume (wt) <u>0</u> ml (gm)	Initial wt. <u>953.6g</u> <u>953.6g</u>
Net volume (wt) <u>18.2</u> ml (gm)	Net wt. <u>3.8g</u> <u>3.8g</u>
Total moisture <u>22.0g</u>	
Color of silica gel <u>Mixed</u>	
Description of impinger water <u>Clean</u>	

RECOVERED SAMPLE

Filter container no. Run #2 sealed ✓
Description of particulate on filter Light Grey

Acetone rinse container no. <u>Run #2</u>	Liquid level marked <u>✓</u>
Acetone blank container no. _____	Liquid level marked _____
Samples stored and locked <u>✓</u>	
Remarks: _____	

Date of laboratory custody NA
Laboratory personnel taking custody _____
Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant JIM WALTER COKE Run No. #2
 Sample location BAGHOUSE STACK
 Relative humidity 20%
 Density of acetone (pa) .7852 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse	✓	✓
filter(s)	✓	✓

Acetone rinse container no. #3

Acetone rinse volume (Vaw) 235 ml

Acetone blank residue concentration (Ca) .000318 mg/g

Wa = Ca Vaw pa = (.000318)(235)(.7852) = .06 mg

Date and time of wt 11-8-84 0700 Gross wt 1054661 mg

Date and time of wt 11-8-84 1300 Gross wt 1054662 mg

Average gross wt 1054661.5 mg

Tare wt 1054434 mg

Less acetone blank wt (Wa) .1 mg

Weight of particulate in acetone rinse 22.65 mg

Filter(s) container no. K-17

Date and time of wt 11-8-84 0700 Gross wt 223.0 mg

Date and time of wt 11-8-84 1300 Gross wt 222.6 mg

Average gross wt 222.8 mg

Tare wt 218.5 mg

Weight of particulate on filter(s) -14.2 mg

Weight of particulate in acetone rinse 22.65 mg

Total weight of particulate 8.45 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst Greg S. Eastman

Signature of reviewer _____

METHOD 5

PARTICULATE SAMPLE RECOVERY AND INTEGRITY SHEET

Plant: JIM WALTER Sample date: 11-7-84
Sample location: BAGHOUSE STACK Run no.: #3
Sample recovery person: KARSTENS Recovery date: 11-7-84
Filter(s) no.: A-1

MOISTURE

Impingers	Silica gel
Final volume (wt) <u>18.0</u> ml(gm)	Final wt. <u>941.4</u> g <u>941.4</u> g
Initial volume (wt) <u>0</u> ml(gm)	Initial wt. <u>937.8</u> g <u>937.8</u> g
Net volume (wt) <u>18.0</u> ml(gm)	Net wt. <u>3.6</u> g <u>3.6</u> g
Total moisture <u>21.6</u> g	
Color of silica gel	<u>1/10 PINK</u>
Description of impinger water	<u>CLEAR</u>

RECOVERED SAMPLE

Filter container no. RUN #3 sealed ✓
Description of particulate on filter LT GRAY

Acetone rinse container no. <u>RUN #3</u>	Liquid level marked <u>✓</u>
Acetone blank container no. <u>BLK</u>	Liquid level marked <u>✓</u>
Samples stored and locked <u>✓</u>	

Remarks: _____

Date of laboratory custody NA

Laboratory personnel taking custody _____

Remarks: _____

METHOD 5 TRAIN ANALYTICAL PARTICULATE DATA

Plant JIM WALTER COKE Run No. H3
 Sample location BAGHOUSE STACK
 Relative humidity 20%
 Density of acetone (pa) .7852 g/ml

Sample type	Sample identifiable	Liquid level marked and/or container sealed
Acetone rinse	✓	✓
filter(s)	✓	✓

Acetone rinse container no. H 4
 Acetone rinse volume (Vaw) 220 ml
 Acetone blank residue concentration (Ca) .000318 mg/g
 $W_a = Ca \cdot V_{aw} \cdot \rho_a = (.000318)(220)(.7852) = .05$ mg
 Date and time of wt 11-8-84 0700 Gross wt 104791.7 mg
 Date and time of wt 11-8-84 1300 Gross wt 104792.2 mg
 Average gross wt 104791.95 mg
 Tare wt 104791.4 mg
 Less acetone blank wt (Wa) .1 mg
 Weight of particulate in acetone rinse .45 mg

Filter(s) container no. A1
 Date and time of wt 11-8-84 0700 Gross wt 221.7 mg
 Date and time of wt 11-8-84 1300 Gross wt 221.5 mg
 Average gross wt 221.6 mg
 Tare wt 218.5 mg
 Weight of particulate on filter(s) 3.1 mg
 Weight of particulate in acetone rinse .45 mg
 Total weight of particulate 3.55 mg

Note: In no case shall a blank residue greater than (.01 mg/g) or .001% of the weight of acetone used be subtracted from the sample weight.

Remarks: _____

Signature of analyst [Signature]

Signature of reviewer [Signature]

PUSH CONTROL SYSTEM - OBSERVATIONS

Source Name Jim Walter Resources Corp Plant Date 11/6/84

Test Run No. #1

Oven Number	Time	Capture Efficiency	Opacity Of Leakage	Seconds Greater Than (20%)
223 - Ball #5	8:40	100%	0%	0
145 - Ball #3	9:00	70%	30%	5
22 - Ball #3	9:06	75%	25%	15
168 - Ball #4	9:17	70%	30%	0
178 - Ball #4	9:27	80%	20%	7
93 - Ball #5	9:44	95%	5%	10
213 - Ball #5	9:54	85%	15%	10
132 - Ball #3	10:33	70%	30%	5
142 - Ball #3	10:44	90%	10%	0
155 - Ball #4	10:54	95%	5%	0
165 - Ball #4	11:04	95%	5%	5
233 - Ball #5	11:17	100%	0%	0
90 - Ball #5	11:28	100%	0%	0
210 - Ball #5	11:38	100%	0%	0
30 - Ball #5	11:49	100%	0%	0
29 - Ball #3	12:00	95%	5%	0
139 - Ball #3	12:10	90%	10%	0
75 - Ball #4	12:20	90%	10%	0
152 - Ball #4	12:30	90%	10%	0
200 - Ball #5	13:07	100%	0%	0
220 - Ball #5	13:18	100%	0%	0
49 - Ball #3	13:32	90%	10%	0
26 - Ball #3	13:38	90%	10%	0
162 - Ball #4	13:47	95%	5%	0

Total Pushes Observed: 24
 Total Pushes Receiving 85% Capture
 OR GREATER: 19
 Total Pushes Receiving Less Than
 85% Capture: 5

OBSERVERS: Keith Wetherspoon
 &
 Veda Hampton

PUSH CONTROL SYSTEM - OBSERVATIONS

Source Name Jim Walter Coke Plant

Date 11/6/84
11/7/84

Test Run No. #2

OBSERVERS: Keth Wetherspoon
Veda Hampton

Oven Number	Time	Capture Efficiency	Opacity Of Leakage	Seconds Greater Than (20%)
184 240 - Batt #5	14:08	90%	10%	0
187 - Batt #5	14:18	90%	10%	0
136 - Batt #3	14:28	85%	15%	0
146 - Batt #3	14:35	85%	15%	0
159 - Batt #4	14:46	80%	20%	3
69 - Batt #4	14:56	95%	5%	0
107 - Batt #5	15:09	100%	0%	0
127 - Batt #5	15:18	100%	0%	0
117 - Batt #5	15:27	85%	15%	6
117 - Batt #5	15:36	95%	5%	0
113 - Batt #3	15:54	95%	5%	0
133 - Batt #3	16:03	85%	15%	0
109 - Batt #5	8:19	75%	25%	3
129 - Batt #5	8:29	90%	10%	0
139 - Batt #3	8:44	95%	5%	0
149 - Batt #3	8:57	90%	10%	1
152 - Batt #4	9:06	75%	25%	3
162 - Batt #4	9:17	70%	30%	6
199 - Batt #5	9:28	95%	5%	0
119 - Batt #5	9:39	90%	10%	0
126 - Batt #3	10:14	90%	10%	2
136 - Batt #3	10:23	95%	5%	0
172 - Batt #4	10:34	95%	5%	0
159 - Batt #4	10:42	50%	50%	9
139 - Batt #5	10:56	90%	10%	0

Total Pushes Observed: 25

Total Pushes Receiving 85% or Greater Capture: 20

Total Pushes Receiving Less Than 85% Capture: 5

Did Not Tr.
Dampers Not Op.

PUSH CONTROL SYSTEM - OBSERVATIONS

Source Name Jim Walter Coke Plant

Date 11/7/84

Test Run No. #3

Observers: Kathy Witherspoon
Vera Hampton

Oven Number	Time	Capture Efficiency	Opacity Of Leakage	Seconds Greater Than (20%)
186 - Batt #5	11:06	90%	10%	0
206 - Batt #5	11:15	80%	20%	6
226 - Batt #5	11:25	90%	10%	0
186 - Batt #3	12:16	100%	0%	0
133 - Batt #3	12:25	90%	10%	0
179 - Batt #4	12:36	95%	5%	0
179 - Batt #4	13:45	70%	30%	5
196 - Batt #5	13:56	100%	0%	0
216 - Batt #5	14:05	95%	5%	0
133 - Batt #3	14:13	85%	15%	3
153 - Batt #3	14:22	90%	10%	4
156 - Batt #4	14:33	95%	5%	0
156 - Batt #4	14:40	85%	15%	2
236 - Batt #5	14:50	90%	10%	1
153 - Batt #5	15:01	95%	5%	0
130 - Batt #3	15:12	95%	5%	0
170 - Batt #3	15:22	95%	5%	0
176 - Batt #4	15:32	95%	5%	0
153 - Batt #4	15:42	95%	5%	0
203 - Batt #5	15:51	100%	0%	0
223 - Batt #5	15:59	100%	0%	0
193 - Batt #5	16:07	100%	0%	0
213 - Batt #5	16:15	95%	5%	0
150 - Batt #3	16:26	90%	10%	0

Total Pushes Observed: 24

Total Pushes Receiving 85% or Greater Capture: 22

Total Pushes Receiving Less Than 85% Capture: 2



JEFFERSON COUNTY DEPARTMENT OF HEALTH
BUREAU OF ENVIRONMENTAL HEALTH
AIR POLLUTION CONTROL PROGRAM

VISIBLE EMISSIONS OBSERVATION REPORT

Company Name Jim Walter (Coke) Location 03
Source baghouse stack Permit No. 13
Start/Stop Time 8:00 - 11:04 Sky Condition clear Date 11/06/84
Observation Point E-SE of house Distance from Source 100 ft
Stack Height 50 ft Background sky Plume Color -
Method of Evaluation: ☐ 1 Hour Cumulative ☐ 6 Minute Average ☐ Other 23
Violation Observed ☐ If Notice Given, Notice Number 30
Total Minutes Observed 30 Highest 6 Minute Average 38
Minutes Exceeding: 20 % Opacity = 00, 60 % Opacity = 00
Observer Duckworth Time Analysis 04 ID VE

Seconds					Seconds					Seconds					Seconds				
Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45
0	0	0	0	0	15	0	0	0	0	30	0	0	0	0	46	0	0	0	0
1	0	0	0	0	16	0	0	0	0	31	0	0	0	0	47	0	0	0	0
2	0	0	0	0	17	0	0	0	0	32	0	0	0	0	48	0	0	0	0
3	0	0	0	0	18	0	0	0	0	33	0	0	0	0	49	0	0	0	0
4	0	0	0	0	19	0	0	0	0	34	0	0	0	0	50	0	0	0	0
5	0	0	0	0	20	0	0	0	0	35	0	0	0	0	51	0	0	0	0
6	0	0	0	0	21	0	0	0	0	36	0	0	0	0	52	0	0	0	0
7	0	0	0	0	22	0	0	0	0	37	0	0	0	0	53	0	0	0	0
8	0	0	0	0	23	0	0	0	0	38	0	0	0	0	54	0	0	0	0
9	0	0	0	0	24	0	0	0	0	39	0	0	0	0	55	0	0	0	0
10	0	0	0	0	25	0	0	0	0	40	0	0	0	0	56	0	0	0	0
11	0	0	0	0	26	0	0	0	0	41	0	0	0	0	57	0	0	0	0
12	0	0	0	0	27	0	0	0	0	42	0	0	0	0	58	0	0	0	0
13	0	0	0	0	28	0	0	0	0	43	0	0	0	0	59	0	0	0	0
14	0	0	0	0	29	0	0	0	0	44	0	0	0	0					

Results and Recommendations:



JEFFERSON COUNTY DEPARTMENT OF HEALTH
BUREAU OF ENVIRONMENTAL HEALTH
AIR POLLUTION CONTROL PROGRAM

VISIBLE EMISSIONS OBSERVATION REPORT

Company Name Jim Walter (Coke) Location 03
Source baghouse stack Permit No. 3
Start/Stop Time 11:15 - 2:19 Sky Condition clear Date 11/06/84
Observation Point S-SE of source Distance from Source 120 ft
Stack Height 50 ft Background sky Plume Color -
Method of Evaluation: ☐ 1 Hour Cumulative ☐ 6 Minute Average ☐ Other 23
Violation Observed ☐ If Notice Given, Notice Number 30
Total Minutes Observed 28 Highest 6 Minute Average 38
Minutes Exceeding: 20 % Opacity = 00, 60 % Opacity = 00
Observer Duckworth Time Analysis 04 ID VF

Seconds					Seconds					Seconds					Seconds				
Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45
11:01 ¹⁵	0	0	0	0	15:58 ¹⁵	0	0	0	0	1:30 ⁰⁰	0	0	0	0	1:45 ⁰⁰	0	0	0	0
11:04 ⁴⁵	0	0	0	0	16:00	0	0	0	0	31:00	0	0	0	0	46:00	0	0	0	0
2:00	0	0	0	0	17:00	0	0	0	0	32:00	0	0	0	0	1:47:00	0	0	0	0
11:30 ⁰⁰	0	0	0	0	18:00	0	0	0	0	33:00	0	0	0	0	1:48:00	0	0	0	0
11:45 ⁰⁰	0	0	0	0	19:00	0	0	0	0	34:00	0	0	0	0	49:00	0	0	0	0
5:00	0	0	0	0	20:00	0	0	0	0	35:00	0	0	0	0	50:00	0	0	0	0
11:30 ⁰⁰	0	0	0	0	21:00	0	0	0	0	36:00	0	0	0	0	51:00	0	0	0	0
7:00	0	0	0	0	22:00	0	0	0	0	37:00	0	0	0	0	52:00	0	0	0	0
11:30 ⁰⁰	0	0	0	0	23:00	0	0	0	0	38:00	0	0	0	0	53:00	0	0	0	0
9:00	0	0	0	0	24:00	0	0	0	0	39:00	0	0	0	0	54:00	0	0	0	0
11:00 ⁰⁰	0	0	0	0	25:00	0	0	0	0	40:00	0	0	0	0	55:00	0	0	0	0
12:00	0	0	0	0	26:00	0	0	0	0	41:00	0	0	0	0	56:00	0	0	0	0
13:00	0	0	0	0	27:00	0	0	0	0	42:00	0	0	0	0	57:00	0	0	0	0
14:00	0	0	0	0	28:00	0	0	0	0	43:00	0	0	0	0	58:00	0	0	0	0
					29:00	0	0	0	0	44:00	0	0	0	0	59:00	0	0	0	0

Results and Recommendations:



JEFFERSON COUNTY DEPARTMENT OF HEALTH
BUREAU OF ENVIRONMENTAL HEALTH
AIR POLLUTION CONTROL PROGRAM

VISIBLE EMISSIONS OBSERVATION REPORT

Company Name Jim Walter (Coke) Location 03
Source baghouse stack Permit No. 3
Start/Stop Time 2:28-4:06 Sky Condition clear Date 11/06/84
Observation Point S-SE of source Distance from Source 120 ft
Stack Height 50 ft Background sky Plume Color -
Method of Evaluation: ☐ 1 Hour Cumulative ☐ 6 Minute Average ☐ Other
Violation Observed ☐ If Notice Given, Notice Number 23
Total Minutes Observed 18 Highest 6 Minute Average 30
Minutes Exceeding: 20 % Opacity = 00 , 60 % Opacity = 00
Observer Dachworth Y2 Time Analysis 04 ID VE

Seconds					Seconds					Seconds					Seconds				
Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45
0:28					15:05					30:05					45				
1	0	0	0	0	16:05	0	0	0	0	31	0	0	0	0	46				
2	0	0	0	0	17					32	0	0	0	0	47				
3					18:05				0	33					48				
4	0	0	0	0	19	0	0	0	0	34	0	0	0	0	49				
5	0	0	0	0	20:05	0	0	0	0	35	0	0	0	0	50				
6	0	0	0	0	21					36	0	0	0	0	51				
7					22:05				0	37	0	0	0	0	52				
8				0	23	0	0	0	0	38					53				
9	0	0	0	0	24:05	0	0	0	0	39					54				
10	0	0	0	0	25					40					55				
11					26:05				0	41					56				
12	0	0	0	0	27	0	0	0	0	42					57				
13	0	0	0	0	28:05	0	0	0	0	43					58				
14					29					44					59				

Results and Recommendations:



JEFFERSON COUNTY DEPARTMENT OF HEALTH
BUREAU OF ENVIRONMENTAL HEALTH
AIR POLLUTION CONTROL PROGRAM

VISIBLE EMISSIONS OBSERVATION REPORT

Company Name Jim Walter (Coke) Location 03
Source Bayhouse stack Permit No. 3
Start/Stop Time 7:54 - 10:44 Sky Condition overcast Date 110784
Observation Point E-SE of source Distance from Source 120 ft
Stack Height 50 ft Background sky Plume Color -
Method of Evaluation: ☐ 1 Hour Cumulative ☐ 6 Minute Average ☐ Other -
Violation Observed ☐ If Notice Given, Notice Number 23
Total Minutes Observed 28 Highest 6 Minute Average 30
Minutes Exceeding: 20 % Opacity = 00, 60 % Opacity = 00
Observer Duchnowski 42 Time Analysis 04 ID VE

Seconds					Seconds					Seconds					Seconds				
Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45
7:54					15:45					30:45					45:15				
1					16					31					46				
7:54					17					32					47:45				
3					18:45					33:15					48				
8:00					19					34					49:30				
5					20:30					35:45					50				
8:00					21					36					51:30				
7					22:45					37:30					52				
8:15					23					38					53:30				
9					24:00					39:30					54				
8:10					25					40					55:30				
11					26					41:30					56				
8:12					27:00					42					57:45				
13					28					43					58				
8:14					29					44					59:30				

Results and Recommendations:



JEFFERSON COUNTY DEPARTMENT OF HEALTH
BUREAU OF ENVIRONMENTAL HEALTH
AIR POLLUTION CONTROL PROGRAM

VISIBLE EMISSIONS OBSERVATION REPORT

Company Name John Walter (Coke) Location 03
Source Bryham Creek Permit No. 3
Start/Stop Time 10:55-3:13 Sky Condition overcast Date 110784
Observation Point 1 SE of source Distance from Source 120 ft
Stack Height 50 ft Background sky Plume Color -
Method of Evaluation: ☐ 1 Hour Cumulative ☐ 6 Minute Average ☐ Other 23
Violation Observed ☐ If Notice Given, Notice Number 30
Total Minutes Observed 28 Highest 6 Minute Average 38
Minutes Exceeding: 20 % Opacity = 00, 60 % Opacity = 00
Observer D. Smith Time Analysis 04 ID VE

Seconds					Seconds					Seconds					Seconds				
Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45
10:55	0	0	0	0	13:35	0	0	0	0	10:55	0	0	0	0	45:30	0	0	0	0
10:56	0	0	0	0	16	0	0	0	0	31	0	0	0	0	46	0	0	0	0
2					17:30	0	0	0	0	32:00	0	0	0	0	47:30	0	0	0	0
3					18					33					48				
4					19:30			0	0	34:15		0	0	0	49:30		0	0	0
5					20	0	0	0	0	35:45	0	0	0	0	50:30	0	0	0	0
6					21:15	0	0	0	0	36					51				
7					22					37:15				0	52:00			0	0
8					23:45		0	0	0	38	0	0	0	0	53	0	0	0	0
9					24	0	0	0	0	39:30	0	0	0	0	54:15	0	0	0	0
10					25:15	0	0	0	0	40					55				
11					26					41:15			0	0	56:00				0
12	0	0	0	0	27:30			0	0	42	0	0	0	0	57	0	0	0	0
13	0	0	0	0	28	0	0	0	0	43:15	0	0	0	0	58	0	0	0	0
14					29:15	0	0	0	0	44					59:15	0	0	0	0

Results and Recommendations:



JEFFERSON COUNTY DEPARTMENT OF HEALTH
BUREAU OF ENVIRONMENTAL HEALTH
AIR POLLUTION CONTROL PROGRAM


VISIBLE EMISSIONS OBSERVATION REPORT

Company Name Jim Walter (Coke) Location 03
Source baghouse stack Permit No. 3
Start/Stop Time 3:00 - 4:06 Sky Condition broken Date 11/07/84
Observation Point E-SE of source Distance from Source 130 ft
Stack Height 50 Background sky Plume Color -
Method of Evaluation: ☐ 1 Hour Cumulative ☐ 6 Minute Average ☐ Other
Violation Observed ☐ If Notice Given, Notice Number 23
Total Minutes Observed 13 Highest 6 Minute Average 30
Minutes Exceeding: 20 % Opacity = 00, 60 % Opacity = 00
Observer Duckworth Time Analysis 02 ID VE

Seconds					Seconds					Seconds					Seconds				
Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45	Min.	0	15	30	45
0 ³⁰		0	0	0	15 ³⁰	0	0	0	0	30					45				
1	0	0	0	0	16 ³⁰	0	0	0	0	31					46				
2 ³⁰	0	0	0	0	17					32					47				
3					18 ³⁰		0	0	0	33					48				
4 ³⁰		0	0	0	19	0	0	0	0	34					49				
5 ³⁰	0	0	0	0	20 ³⁰	0	0	0	0	35					50				
6					21					36					51				
7 ³⁰	0	0	0	0	22 ³⁰				0	37					52				
8	0	0	0	0	23	0	0	0	0	38					53				
9 ³⁰	0	0	0	0	24 ³⁰	0	0	0	0	39					54				
10					25					40					55				
11 ³⁰	0	0	0	0	26 ³⁰	0	0	0	0	41					56				
12 ³⁰	0	0	0	0	27	0	0	0	0	42					57				
13					28 ³⁰	0	0	0	0	43					58				
14					29					44					59				

Results and Recommendations:

Plant Operation Data



OVEN REPORT

DATE 11-6-84
SHIFT 7:Am

CHARGING

TOP HOUSE
BIN NR

TYPE
COAL

NO OVENS
CHARGED

REMARKS

PUSHING

TYPE
CORE

NO OVENS
PUSHED

CORE TEMP
HOT, COLD, GOOD

SIZE
SMALL, LARGE, AVE

OTHER

OVEN TEMPERATURES

NR3 BATTERY

PS CS AVE
2157 2204 2181

NR4 BATTERY

PS CS AVE
2162 2201 2182

NR5 BATTERY

PS CS AVE
1852 1862 1857

REMARKS

*Temperature will vary with different coal
Blend*

OVEN REPORT

DATE 11-7-84
SHIFT 7:AM

CHARGING

TOP HOUSE
BIN NO

TYPE
COAL

NO OVENS
CHARGED

REMARKS

PUSHING

TYPE
CORE

NO OVENS
PUSHED

CORE TEMP
HOT, COLD, GOOD

SIZE
SMALL, LARGE, AVE

OTHER

OVEN TEMPERATURES

NO 3 BATTERY

PS	CS	AVE
<u>2118</u>	<u>2162</u>	<u>2145</u>
—	—	—

NO 4 BATTERY

PS	CS	AVE
<u>2136</u>	<u>2167</u>	<u>2152</u>
—	—	—

NO 5 BATTERY

PS	CS	AVE
<u>1826</u>	<u>1842</u>	<u>1833</u>
—	—	—

REMARKS

Temperatures will vary with different Coal
Blends

OVEN FILLING REPORT

DATE 11-6-84

BLOCK NO.


1ST SHIFT

2ND SHIFT

3RD SHIFT

Trip	Oven No.	Light No. of Ft.	Green No. of Ft.	Broke Up	Blk. Head Cut	Double Pushed	Disposition	Trip	Oven No.	Light No. of Ft.	Green No. of Ft.	Broke Up	Blk. Head Cut	Double Pushed	Disposition	Trip	Oven No.	Light No. of Ft.	Green No. of Ft.	Broke Up	Blk. Head Cut
1	236	7:10						1	197	300	15:27	BAH A.5				1	208	1100			
2	183	11						2	217	11	15:36	BAH A.5				2	228	11			
3	125	22						3	123	22	15:27	BAH A.3				3	121	22			
4	135	33						4	133	33	16:03	BAH A.3				4	131	33			
5	171	44						5	175	44						5	177	44			
6	158	55						6	156	55						6	154	55			
7	203	806						7	237	406						7	198	1206			
8	223	17	8:40	BAH A.5	TEST A.1			8	184	17						8	218	17			
9	145	28	9:00	BAH A.3	TEST A.1			9	143	29						9	141	28			
10	122	39	9:06	BAH A.3	TEST A.1			10	130	35						10	128	35			
11	168	50	9:12	BAH A.4	TEST A.1			11	166	50						11	164	50			
12	178	901	9:27	BAH A.4	TEST A.1			12	176	501						12	174	101			
13	193	12	9:49	BAH A.5	TEST A.1			13	204	12						13	238	12			
14	213	23	9:54	BAH A.5	TEST A.1			14	224	23						14	185	23			
15	X	34						15	X	34						15	X	34			
16	132	45	10:33	BAH A.3	TEST A.1			16	140	45						16	138	45			
17	142	56	10:44	BAH A.3	TEST A.1			17	150	56						17	148	56			
18	155	1007	10:59	BAH A.4	TEST A.1			18	153	1007						18	151	207			
19	165	18	11:04	BAH A.4	TEST A.1			19	163	18						19	161	18			
20	233	29	11:19	BAH A.5	TEST A.1			20	194	25						20	205	29			
21	190	40	11:28	BAH A.5	TEST A.1			21	214	40						21	225	40			
22	X	51						22	X	51						22	X	51			
23	X	1102						23	X	702						23	X	302			
24	210	13	11:38	BAH A.5	TEST A.1			24	234	13						24	195	13			
25	230	24	11:49	BAH A.5	TEST A.1			25	191	24						25	215	24			
26	129	35	12:00	BAH A.3	TEST A.1			26	127	35						26	125	35			
27	139	46	12:10	BAH A.3	TEST A.1			27	137	46						27	135	46			
28	175	57	12:26	BAH A.4	TEST A.1			28	173	57						28	171	57			
29	152	1708	12:30	BAH A.4	TEST A.1			29	120	808						29	158	408			
30	200	17	13:07	BAH A.5	TEST A.1			30	201	19						30	235	19			
31	220	30	13:18	BAH A.5	TEST A.1			31	221	30						31	182	30			
32	X	41						32	X	41						32	X	41			
33	149	52	13:32	BAH A.3	TEST A.1			33	147	52						33	145	52			
34	126	103	13:38	BAH A.3	TEST A.1			34	124	103						34	122	503			
35	162	14	13:44	BAH A.4	TEST A.1			35	170	14						35	168	14			
36	172	25	14:01	BAH A.5	TEST A.1			36	180	25						36	178	25			
37	240	36	14:11	BAH A.5	TEST A.1			37	191	36						37	202	36			
38	187	47	14:18	BAH A.5	TEST A.1			38	211	47						38	222	47			
39	136	58	14:28	BAH A.3	TEST A.1			39	134	58						39	132	58			
40	166	209	14:35	BAH A.3	TEST A.1			40	144	1009						40	142	7009			
41	159	30	14:46	BAH A.4	TEST A.1			41	157	20						41	155	20			
42	169	31	14:56	BAH A.4	TEST A.1			42	167	31						42	165	31			
43	207	42	15:01	BAH A.5	TEST A.1			43	231	42						43	192	42			
44	227	53	15:11	BAH A.5	TEST A.1			44	188	53						44	212	53			
45								45								45					
46								46								46					
47								47								47					
48								48								48					
49								49								49					
50								50								50					

Calibrations



VI. METHOD 5 CALIBRATIONS

Meter Box

The meter box shall be initially calibrated every 6 months at the fixed settings of 0.5, 1.0, 1.5, 2.0, and 2.5 inches of water. Upon return to the laboratory from this test the meter box was recalibrated using the average meter pressure for the test series. The recalibration point shall be the closest point to the initial calibration (for an average meter pressure of 1.59 a 1.50 "H₂O was used as the recalibration point). These recalibrations produced a single point MCF and a H@ which shall be compared to the original calibration to see if they are within the 5% allowed at the highest vacuum seen. These recalibration sheets are located behind the original calibration sheets.

Pitot Tubes

The S type pitot tubes shall be calibrated against a standard pitot tube ($C_p = 0.99$) every six months in a wind tunnel with a capacity to generate a test section velocity of approximately 3000 feet/ minute. Additionally the pitot tube shall be measured as to its specifications and alignment. Upon return, the intercomponent spacings and the face opening alignment of the pitot tube assembly shall be rechecked and if no changes are noticed; it shall be assumed that the coefficient of the assembly had not changed.

Temperature measurements

All temperature devices (impinger, meter box, hot box and stack) shall be calibrated every 6 months against an ASTM mercury-in-glass reference thermometer or a reference thermocouple and potentiometer calibrated by fixed points, e.g., ice bath and boiling water (corrected to barometric pressure). Upon return the stack temperature device shall be recalibrated within 10% of the average absolute stack temperature. If the device being tested agrees within 1.5% of the reference device, the temperature data taken in the field shall be considered valid.

VI. METHOD 5 CALIBRATIONS CONTINUED

Barometric Pressure

An aneroid barometer capable of measuring atmospheric pressure to within 0.1 inches Hg shall be used. If this device is defective the following alternate method shall be used. The barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the weather station and sampling point shall be applied at a rate of minus 0.1 inches Hg per 100 feet elevation increase or vice versa for elevation decrease.

Specific Test equipment and measurements

The equipment used during these tests was as follows:

Probe: 8-1 & 8-2

Meter Box: #400

Stack Temperature: OMEGA II

Sample Box: #4

Condenser: #1

The average temperature of the stack was 85⁰ F. The OMEGA II was recalibrated at 85⁰ F and agreed exactly with an ASTM mercury-in-glass reference thermometer. The intercomponent spacings and the face opening alignment of the Pitot Tube assembly was rechecked and no changes were noticed; therefore, it was assumed that the coefficient of the assembly had not changed.

Gauge	Average Test Condition Temperature	Gauge Reading	Reference Reading	Difference
Impinor (Pre) #1		66	Room Temp 66	—
Meter In (Pre) 400		66	Room Temp 66	—
Meter Out (Pre) 400		66	Room Temp 66	—
Filter Heated Area (Pre) #4		255	240 ± 25°F 255	—
Stack (Post)	85	85	Stack Temp °F 85	

Post Test

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>
Train Leak Rate	<u>.012 CFM</u>	<u>.008 CFM</u>	<u>.009 CFM</u>
Pipe Leak Check	<u>✓</u>	<u>✓</u>	<u>✓</u>

Pre Test (Answer Yes or No)

Orbit Leak Check	<u>NA</u>	<u> </u>	<u> </u>
Metering System Leak Check	<u>✓</u>		
Barometer Calibrated	<u>✓</u>		
Sample Bag Leak Check (if used)	<u>NA</u>		

Signature W. C. Kautz Title Asst Director Date 11-8-84

Calibration data for dry gas meter, orifice, nozzle, pitot and differential pressure gauge (if other than manometer) must be available for inspection at the time of the test and must be included in the test report.

Type A Glass Fiber Filters

FEATURES

- High tensile strength. ■ Excellent handling characteristics. ■ Good wetting properties. ■ Minimum of 99.9% retention for particles of $.3 \mu\text{m}$ as determined by DOP tests. ■ Binder free.

This is the original glass fiber filter pioneered by Gelman Instrument Company over 15 years ago. It continues to be widely used for high volume sampling. Since zinc is one of the raw materials incorporated in the glass fibers, Type A Filters have a variable zinc content. Another component of the filter, sulfuric acid, is used as a dispersion medium, making the sheets unsuitable for measurement of sulfates.

Type A Glass Fiber Filters are less likely to develop static charge or tear than other glass fiber media types. They are used extensively in applications where zinc and iron content is not important, or where sulfate content is not being determined.

Size	37 mm	47 mm	102 mm	8"x10"
Product No.	61715	61694	61696	61701
Filters/Pkg.	500	100	100	100

TYPE A GLASS FIBER FILTER SPECIFICATION REPORT

The following physical/chemical properties represent typical, average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/8" x 10" sheet).

ELEMENTS:

Antimony	.30	Manganese	.200
Arsenic	.30	Mercury	.100
Beryllium	.1	Molybdenum	.10
Bismuth	.10	Nickel	.10
Cadmium	.5	Selenium	.5000
Chromium	.10	Tin	.10
Cobalt	.10	Titanium	.170
Copper	.2	Vanadium	.10
Iron	.2300	Zinc	.5000
Lead	.20		to 25,000

OTHER PHYSICALS:

BSO	.522	Flow Resistance (Max.)	
*pH	.8.5	@ 320 cm/min.	.80 mm
DOP @ 320/cm/min		Flow Rate (air)	
(ASTM Method 2986)	.99.9%	lpm/cm ² @ 70 cm Hg	.50
Tensile Strength		Max. Use Temp.	400°C
(Fed. Spec. UUP31B)	.750 gr	Static Properties	Low
Weight,		Ability to	
8"x10" sheet	4.0 ± .3 gr.	Fold	Excellent

WATER EXTRACTABLE IONS:

Sulfate	.100	Chloride	.1500
Nitrate	.50	Fluoride	.15
Ammonia	.20		

*pH—Gelman Procedure:

- 500 ml distilled water.
- Add 15 drops saturated KCl solution
- Shred one 8"x10" sheet and soak in prepared water for one hour.
- Run pH at ambient temperature.

Type A/E Glass Fiber Filters

FEATURES

- Low trace metals. ■ Medium Handling characteristics. ■ Available in all sizes. ■ Minimum of 99.9% retention for particles of $.3 \mu\text{m}$ as determined by DOP tests. ■ Binder free.

Type A/E Glass Fiber Filters are composed of low acid soluble glass fiber. They contain low levels of both zinc and iron. The filters do react with atmospheric sulfur dioxide; and therefore, when high levels of sulfur are expected, corrections for this reaction should be accounted for.

Type A/E Glass Fiber Filters are binder free and ideal for gravimetric analysis of air pollutants. This pure, organic free filter is the basis for procedures widely used in determining municipal and industrial air polluting substances.

Size	25 mm	37 mm	47 mm	102 mm	8"x10"
Product No.	61630	61652	61631	61633	61638
Filters/Pkg.	500	500	100	100	100

TYPE A/E GLASS FIBER FILTER SPECIFICATION REPORT

The following physical/chemical properties represent typical, average values obtained in accordance with accepted test methods. They are subject to normal manufacturing variations and are supplied as a technical service. The analysis has been made in accordance with EPA procedures (micrograms/8" x 10" sheet).

ELEMENTS:

Antimony	.20	Manganese	.2
Arsenic	.20	Mercury	.80
Beryllium	.1	Molybdenum	.10
Bismuth	.10	Nickel	.10
Cadmium	.2	Selenium	.200
Chromium	.10	Tin	.10
Cobalt	.10	Titanium	.10
Copper	.2	Vanadium	.10
Iron	100-1800	Zinc	.90
Lead	.10		

OTHER PHYSICALS:






BSO	.522	Flow Resistance (Max.)	
*pH	.9.0	@ 320 cm/min.	.80 mm
DOP @ 320/cm/min		Flow Rate (air)	
ASTM Methods 2986)	.99.9%	lpm/cm ² @ 70 cm Hg	.60
Tensile Strength		Max. Use Temp.	400°C
(Fed. Spec. UUP31B)	.600 gr.	Static Properties	Medium
Weight		Ability to	
8"x10" sheet	4.0 ± .3 gr.	Fold	Good

WATER EXTRACTABLE IONS:

Sulfate	.600	Chloride	.1500
Nitrate	.115	Fluoride	.87
Ammonia	.13		

*pH—Gelman Procedure:

- 500 ml distilled water.
- Add 15 drops saturated KCl solution.
- Shred one 8"x10" sheet and soak in prepared water for one hour.
- Run pH at ambient temperature.



NOTE: Flow rate held constant at 0.75; 50% change in flow rate has little effect on probe temperature.

METER CALIBRATION FORM

Date 9/19/84 Box No. 400
P_{bar} = 30.00 in. Hg Calibrated by L072

Orifice Manometer Set- ting ΔH (in. H ₂ O)	Δ wtm (in. H ₂ O)	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Avg. Temp. Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Inlet	Outlet
0.5 @ 19	-0.40	0	6.225	682.762	685.846	21.5	21.5	97.5	87
1.0 @ 17.5	-0.60	14.707	23.463	698.628	707.351	21.5	22.0	103	92.5
1.5 @ 16.5	-0.83	23.463	34.035	707.351	715.045	22.0	22.0	108	94.5
2.0 @ 15.5	-1.05	34.035	47.071	715.045	731.341	22.0	22.2	112	96.5
2.5 @ 15.0	-1.32	47.071	60.912	731.341	745.353	22.2	22.5	113	97.5

Pump must be operated for at least 15 minutes at each ΔH setting (.5, 1, 1.5, 2 and 3)

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

P_{wtm} = P_{bar} - $\frac{\Delta wtm}{13.6}$

P_{dgm} = P_{bar} + $\frac{\Delta H}{13.6}$

Δwtm = pressure on wet test meter in inches of H₂O

Y = meter calibration factor

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$Y = \frac{(\text{wet final} - \text{wet initial})(T_{dgm})(P_{wtm})}{(\text{dry final} - \text{dry initial})(28.316)(T_{wtm})(P_{dgm})}$$

or (1)

$$\bar{Y} = \frac{\Sigma Y}{5}$$

Meter Tolerance = 1.00 ± 0.01

If the meter calibration factor is not within the allowable tolerance, the calibration factory Y may be used to mathematically correct the gas meter dial readings to the proper values instead of physically adjusting the dry gas meter dials to correspond to the wet test meter readings.

1.0197
1.0185
1.0145
1.0055
1.0116

1.0140 = 1.01 Avg

POST TEST METER CALIBRATION

PROJECT JIM WALTERS COKE STACK BACHHOUSE
 Date 11-8-84 Box No. 400
 P_{bar} = 30.26 in. Hg Calibrated by J. K. Keston
 Signature

Orifice Manometer Set- ting ΔH (in. H ₂ O)	Δ wtm (in. H ₂ O)	Gas Volume Wet Test Meter		Gas Volume Dry Gas Meter		Temperature Wet Test Meter		Avg. Temp. Dry Gas Meter	
		Initial	Final	Initial	Final	Initial	Final	Inlet	Outlet
15 @ 1.5" Hg	- .74	0	10.409	252.474	263.080	16	16	94	75
15 @ 1.5" Hg	- .74	0	10.506	263.060	273.037	16	16	104.5	83
15 @ 1.5" Hg	- .74	0	10.545	273.037	284.714	16	16	109	89

Pump must be operated for at least 15 minutes at each ΔH setting

T_{dgm} = average temperature of dry gas meter (inlet and outlet) + 460°F

T_{wtm} = average temperature of wet test meter + 460°F

P_{wtm} = P_{bar} - $\frac{\Delta wtm}{13.6}$ (includes vapor pressure of water at saturation at the temperature of the wet test meter)

P_{dgm} = P_{bar} + $\frac{\Delta H}{13.6}$

Δwtm = pressure on wet test meter in inches of H₂O

Y = meter calibration factor

28.316 = conversion factor when using a wet test meter calibrated in liters

Calculations

$$Y = \frac{(\text{wet final} - \text{wet initial})(T_{dgm})(P_{wtm})}{(\text{dry final} - \text{dry initial})(28.316)(T_{wtm})(P_{dgm})}$$

or (1)

$$\bar{Y} = \frac{\sum Y}{3} = \underline{1.01}$$

Pre test Y 1.01

% Difference —

ORIFICE CALIBRATION FORM

Date 9/19/84Meter Box No. 400P_{bar} 30.00Calibrated By L072

ΔH	V ₁	V ₂	θ	t ₁	t ₂	V ₂ - V ₁	Q _m	K _m	
in. H ₂ O	CF	CF	Sec.	°F	°F	CF			
0.5	683.762	689.946	900	97.5	88	6.184	.4168	.7431	1.67
1.0	689.946	707.391	900	103	92.5	8.763	.5894	.7405	1.68
1.5	707.391	718.045	900	108	94.5	10.654	.7119	.7294	1.73
2.0	718.045	731.341	960	112	96.5	13.296	.8241	.7303	1.73
2.5	731.341	745.350	900	113	97.5	14.012	.9320	.7386	1.69
Average K _m								.7364	

V₁ = Dry gas meter reading at the start of each testV₂ = Dry gas meter reading at the end of each testt₁ = Dry gas meter inlet temperaturet₂ = Dry gas meter outlet temperatureCalculations

$$1. \quad Q_m = \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{\frac{t_1 + t_2 + 460}{2}} \right] (60)(Y)$$

$$2. \quad K_m = \frac{Q_m}{\sqrt{\frac{P_m M_m}{T_m \Delta H}}} \quad \begin{array}{l} M_m = 29 \\ T_m = t_2 + 460 \\ P_m = P_{bar} + \frac{\Delta H}{13.6} \end{array}$$

Y = meter calibration factor

3. Calculate the average K_m as follows:

$$\bar{K}_m = \frac{\sum K_m}{5}$$

4. Calculate ΔH_a as follows:

$$\Delta H_a = \frac{Q @ \frac{P @ M @}{T @}}{\bar{K}_m^2} \left[\frac{1}{\bar{K}_m^2} \right] = \frac{0.921}{\bar{K}_m^2}$$

Q@ = 0.75 cfm

T@ = 528°R

P@ = 29.92 in.Hg

M@ = 29

5. Orifice Tolerance = $1.84 \pm .25$

POST TEST ORIFICE CALIBRATION

Date 11-8-84

Meter Box No. 400

P_{bar} 30.26

Calibrated By 91 K. K. K.
Signature

Δ H	V ₁	V ₂	θ	t ₁	t ₂	V ₂ - V ₁	Q _m	K _m
in. H ₂ O	CF	CF	Sec.	°F	°F	CF		
1.5	252.474	213.880	900	94	75	10.606	.6964	.7295
1.5	263.080	273.837	900	104.5	83	10.757	.7134	.7418
1.5	273.837	284.714	900	109	89	10.877	.7239	.7482
							Average K _m	.7400

V₁ = Dry gas meter reading at the start of each test

V₂ = Dry gas meter reading at the end of each test

t₁ = Dry gas meter inlet temperature

t₂ = Dry gas meter outlet temperature

Average K_m .7400

Average H₀ 1.68

Pre test H₀ 1.70

% Difference -1.22

Calculations

$$1. Q_m = \frac{V_2 - V_1}{\theta} \left[\frac{t_2 + 460}{t_1 + t_2 + 460} \right] (60)(Y)$$

$$2. K_m = Q_m \sqrt{\frac{P_m M_m}{T_m \Delta H}}$$

$$M_m = 29$$

$$T_m = t_2 + 460$$

$$P_m = P_{bar} + \frac{\Delta H}{13.6}$$

Y = meter calibration factor

3. Calculate the average K_m as follows:

$$K_m = \frac{\sum K_m}{3}$$

4. Calculate Δ H_a as follows:

$$\Delta H_a = \frac{Q^2 P_0 M_0}{T_0} \left[\frac{1}{K_m^2} \right] = \frac{0.921}{K_m^2}$$

$$Q_0 = 0.75 \text{ cfm}$$

$$T_0 = 5280R$$

$$P_0 = 29.92 \text{ in.Hg}$$

$$M_0 = 29$$

TEMPERATURE CALIBRATION

FOR

SM-600 I

DATE INITIAL

9/19/84

DATE FINAL

DEVICE READING (DEGREES F)

ACTUAL TEMPERATURE (DEGREES F)

TEMPERATURE CALIBRATION

FOR

DATE

DATE INITIAL

9/19/84

DATE FINAL

DEVICE READING (DEGREES F)

ACTUAL TEMPERATURE (DEGREES F)

100 300 500 700 900 1100 1300 1500

TEMPERATURE CALIBRATION

FOR 2014

DATE INITIAL 9-3-84

DATE FINAL 9-3-84

DEVICE READING (DEGREES F)

ACTUAL TEMPERATURE (DEGREES F)

220 230 240 250 260 270 280

DEVICE READING (DEGREES F)

TEMPERATURE CALIBRATION FOR 702022-41
DATE 8-17-87 INITIALS WZ

ACTUAL TEMPERATURE (DEGREES F)

0 10 20 30 40 50 60 70

PITOT CALIBRATION FORM

Date 9-17-84 Probe # 8'-1
 Calibrated By G KARSTENS
 Nozzle Size NONE

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	.655	.915	.837	-.001
2	.655	.915	.837	-.001
3	.665	.925	.839	+.001
$\bar{C}_p(A)$			.838	

SIDE B

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	.695	.965	.841	0
2	.700	.970	.842	+.001
3	.690	.960	.839	-.002
$\bar{C}_p(B)$			.841	

CALCULATIONS

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}} \quad (\text{or } 0.99)$$

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3}$$

3

← Must be ≤ 0.01

$$|\bar{C}_p(A) - \bar{C}_p(B)| \quad \leftarrow \text{Must be } \leq 0.01$$

PITOT CALIBRATION FORM

Date 9-17-84 Probe # 8'-2
 Calibrated By G KARSTENS
 Nozzle Size NONE

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	.695	.970	.838	+.002
2	.685	.960	.836	0
3	.670	.945	.833	-.003
			$\bar{C}_p(A)$	.836

SIDE B

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	.650	.900	.842	+.001
2	.650	.905	.839	-.002
3	.640	.890	.841	0
			$\bar{C}_p(B)$	.841

CALCULATIONS

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}} \quad (\text{or } 0.99)$$

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3}$$

← Must be ≤ 0.01

$$|\bar{C}_p(A) - \bar{C}_p(B)| \quad \leftarrow \text{Must be } \leq 0.01$$

