



639 Alpha Drive
Pittsburgh, Pennsylvania 15238
Telephone (412) 967-1900
FAX (412) 967-1911

ADVANCED TECHNOLOGY SYSTEMS, INC.

ATS Project No: 00-016-P

September 13, 2000

Mr. William C. Graeser
Manager – Environmental and Quality Assurance
U.S. Steel Clairton Works
400 State Street
Clairton, PA 15025

RE: LETTER REPORT – HYDROCHLORIC ACID AND CHLORINE GAS EMISIONS TESTING CONDUCTED AT B-BATTERY COMBUSTION STACK ON MARCH 8, 2000

Dear Mr. Graeser:

This letter, with attachments, constitutes the report that summarizes the results of the hydrochloric acid (HCl) and chlorine gas (Cl₂) emissions testing conducted at B-Battery Combustion Stack by Advanced Technology Systems, Inc. (ATS). Three two-hour test runs were conducted on March 8, 2000 simultaneous with the compliance test program at this stack (particulate matter and visible emissions were measured as part of the compliance test program).

The test results have been summarized in the attached Table 1. Hydrochloric acid and chlorine gas concentrations are listed in units of milligrams per dry standard cubic meter (mg/dscm). Hydrochloric acid and chlorine gas mass emission rates are listed in units of pounds per hour (lb/hr). Table 1 also presents pertinent exhaust gas and sampling parameters including exhaust gas flow rates in units of actual cubic feet per minute (acfm), standard cubic feet per minute (scfm), and dry standard cubic feet per minute (dscfm), exhaust gas temperature (°F), and moisture content of the exhaust gas (percent by volume), gas volume sampled for each test run in units of dry standard cubic feet (dscf) and the isokinetic variation value for each test run. The isokinetic variation value is equal to the ratio of the average linear gas velocity sampled through the probe nozzle to the average exhaust gas velocity. All isokinetic variation values are between 90 percent and 110 percent, which is the acceptable range of values. Actual test sampling times have also been included in Table 1.

Hydrochloric acid and chlorine gas emission testing was performed in accordance with U.S. EPA Reference Methods 1 through 4 and 26A and the requirements of the Pennsylvania Department of Environmental Protection (PA DEP) Source Testing Manual (Draft Revision 3.1, May 3, 1999). Detailed information regarding the procedures used to measure the exhaust gas stream velocity and volumetric flow rate (i.e., U.S. EPA Reference Methods 1 through 4) can be found in the summary report for the compliance test program. Hydrochloric acid and chlorine gas sampling was performed in accordance with U.S. EPA Reference Method 26A. Process gas samples were withdrawn

isokinetically from the stack, with particulate matter collected in a glass nozzle, a heated glass-lined probe, and on a heated quartz filter. Vapor phase hydrochloric acid and chlorine gas were collected in a series of chilled impingers. The impinger type and sequence is listed below:

<u>No.</u>	<u>Impinger Type</u>	<u>Contents</u>
1.	Modified Greenburg-Smith	50 mL 0.1 N sulfuric acid (for HCl collection)
2.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
3.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
4.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
5.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
6.	Modified Greenburg-Smith	200 g Silica Gel

A gas volume greater than 50 dry standard cubic feet (dscf) – the minimum gas volume required by the PA DEP for the compliance test program - was sampled for each test run. The flow rate through each sample train was less than 1 dry standard cubic foot per minute as required by U.S. EPA Reference Method 26A.

Following each test run, the sample trains were processed in accordance with PA DEP requirements. Detailed information regarding the procedures used to recover the particulate matter catch (essentially U.S. EPA Reference Method 5 procedures) can be found in the summary report for the compliance test program. Following the gravimetric analysis of the impingers for moisture gain, the following four samples fractions were generated for each sample train:

<u>Fraction</u>	<u>Description</u>
A	Contents of Impinger Nos. 1 & 2 plus applicable distilled deionized water rinses (for HCl)
B	Contents of Impinger No. 3 plus applicable distilled deionized water rinses (for HCl)
C	Contents of Impinger No. 4 plus applicable distilled deionized water rinses (for Cl ₂)
D	Contents of Impinger No. 5 plus applicable distilled deionized water rinses (for Cl ₂)

For each sample train, each of the four fractions were analyzed separately as required by the PA DEP to allow for the calculation of the collection efficiency of the sample train for HCl and Cl₂ collection. The contents of Impinger No. 6 were discarded.

The actual test samples plus field blanks of the impinger scrubbing solutions (0.1 N sulfuric acid and 0.1 N sodium hydroxide) were submitted to the subcontract analytical laboratory for chloride ion analyses using ion chromatographic techniques in accordance with U.S. EPA Reference Method 26A. The analytical laboratory results showed the following:

- The chloride ion concentrations of the field blanks were less than the analytical detection limit;

- For all three test runs, the HCl collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction B was at most 10 percent of the chloride catch from Sample Fraction A plus Sample Fraction B); and
- For the first test run, the Cl₂ collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction D was at most 10 percent of the chloride catch from Sample Fraction C plus Sample Fraction D). The Cl₂ collection efficiency of the sample train for the second and third test runs could not be calculated since the chloride catches in Sample Fractions C and D were less than the analytical detection limit.

Copies of the field data sheets, equipment calibration data, analytical laboratory results and emissions calculations are included in the appendix.

ATS appreciates the opportunity to provide U.S. Steel with process gas testing services. If you have any questions regarding this letter report, please call Dr. Robinson Khosah or me at (412) 967-1900 or e-mail me at the following address: jshimshock@atsengineers.com.

Very truly yours,



John P. Shimshock, Ph.D.
Senior Project Scientist

Approved by:



Robinson P. Khosah, Ph.D.
Vice President
Science and Technology Division

JPS/blc
Enclosures

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

TABLE 1

**B-BATTERY COMBUSTION STACK
HYDROCHLORIC ACID AND CHLORINE GAS EMISSIONS DATA
MARCH 8, 2000**

		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
<u>Emissions Data</u>					
Hydrochloric Acid (HCl)					
Concentration	(mg/dscm)	1.29E+01	1.12E+01	1.09E+01	1.17E+01
Mass Emission Rate	(lb/hr)	2.60E+00	2.31E+00	2.22E+00	2.38E+00
Chlorine Gas (Cl ₂)					
Concentration	(mg/dscm)	4.83E-01	< 1.93E-02	< 2.09E-02	< 1.74E-01
Mass Emission Rate	(lb/hr)	9.72E-02	< 3.98E-03	< 4.26E-03	< 3.51E-02
<u>Exhaust Stack Conditions</u>					
Volumetric Flow Rate	(acfm)	1.13E+05	1.15E+05	1.10E+05	1.13E+05
	(scfm)	6.30E+04	6.40E+04	6.26E+04	6.32E+04
	(dscfm)	5.37E+04	5.51E+04	5.44E+04	5.44E+04
Temperature	(°F)	473	472	455	467
Moisture Content	(%)	14.8	14.0	13.1	14.0
<u>Sampling Conditions</u>					
Test Times	(EST)	0805 to 1020	1053 to 1309	1350 to 1605	
Sampling Time - *	(minutes)	120	120	120	
Sample Volume - **	(dscf)	55.359	56.288	53.894	
Isokinetic Variation - ***	(%)	107.9	107.0	103.7	

mg / dscm = milligrams per dry standard cubic meter

*: Minimum required sampling time is 2 hours (120 minutes)

**: Minimum required sample volume is 50 dscf

***: Acceptable range of values is 90.0% <= Isokinetic Variation <= 110.0%

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

**Hydrochloric Acid and Chlorine Gas
Emissions Testing Conducted at
B-Battery Combustion Stack
on March 8, 2000**

September 2000

APPENDIX

**Field Data Sheets, Equipment Calibration Data,
Analytical Laboratory Results and Emissions
Calculations**



ADVANCED TECHNOLOGY SYSTEMS, INC.

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST UNIT B-Battery Combustion Stack
 TEST CREW JS, KA, RS
 PROJECT NO. 00-016-P
 TEST DATE March 8th, 2000
 TEST NO. CLR-BBS-M26A-1
 B.P. (in. Hg) 29.50
 STATIC P. (in. H2O) -1.50
 STACK DIA. (in.) 156
 CONTROL BOX NO. APEX-4
 ORIFICE FACTOR (ΔH@) 2.003
 METER CORR. (Y) 1.0023
 CALIBRATION DATE 9-26-99
 PORT SIZE & TYPE 4" Flanges PITOT COEF. 0.84
 HOT/COLD BOX NO. 7
 FILTER NO. 46767Z
 PROBE NO. 10-1
 NOZZLE DIA. (in.) 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcf)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
A	55.5	0805	714.685	0.04	0.82	0.82	241	468	73	71	63	5 min./pt.
	39.0			0.04	0.82	0.82	241	480	77	72	63	
	27.7			0.04	0.81	0.81	242	490	81	72	58	
	18.4			0.04	0.81	0.81	242	500	83	73	59	
	10.5			0.03	0.61	0.61	242	500	85	74	59	
	3.3	0835	729.141	0.03	0.60	0.60	242	468	86	74	59	
B	55.5	0840	729.141	0.03	0.61	0.61	242	444	81	76	61	
	39.0			0.03	0.61	0.61	242	451	85	76	60	
	27.7			0.03	0.63	0.63	241	457	87	77	60	
	18.4			0.04	0.84	0.84	241	466	90	78	59	
	10.5			0.02	0.42	0.42	241	466	89	79	58	
	3.3	0910	742.181	0.02	0.42	0.42	242	471	89	79	58	
Page 1	Δ = 60	min	Δ = 27.496	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			
Totals			dcf	0.032		0.66		472 (°F)	79 (°F)			Estimates:
Test	Δ = 120	min	Δ = 57.614	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			MW = 27.6
Totals			dcf	0.034		0.71		473 (°F)	84 (°F)			%H2O = 13

Dry Gas Composition

Run 1	Run 2
CO2 4.0%	
O2 11.0%	
CO -	
N2 85.0%	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.010	<0.02
After	7.00	0.006	<0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

No.	Impinging Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	613.4	489.6	123.8
2.	100 mL 0.1 N H2SO4	612.8	553.5	59.3
3.	100 mL 0.1 N H2SO4	528.5	523.9	4.6
4.	100 mL 0.1 N NaOH	537.8	534.4	4.4
5.	100 mL 0.1 N NaOH	534.6	553.0	1.6
6.	~200 g Silica Gel	591.6	578.0	13.6
7.				
8.				Total = 243.3g

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT U.S. Steel Clairton Works TEST DATE March 8th, 2000 CONTROL BOX NO. APEX-4 HOT/COLD BOX NO. 7
 PLANT SITE Clairton, PA TEST NO. 29-50 ORIFICE FACTOR (ΔH) 2.003 FILTER NO. 467 Q7Z
 EST UNIT B-Battery Combustion Stack B.P. (in. Hg) 29.50 METER CORR. (Y) 1.0023 PROBE NO. 10-1
 EST CREW JS, KA, DS. STATIC P. (in. H2O) -1.50 CALIBRATION DATE 9-20-99 NOZZLE DIA. (in.) 0.440
 PROJECT NO. 00-016-P STACK DIA. (in.) 156 PORT SIZE & TYPE 4" Flanges PITOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
	55.5	0915	742.181	0.05	1.05	1.05	242	462	86	81	243	58
	39.0			0.06	1.26	1.26	242	503	92	81	242	58
	27.7			0.05	1.05	1.05	241	513	94	82	242	58
	18.4			0.04	0.84	0.84	241	522	94	83	242	58
	10.5			0.03	0.63	0.63	241	444	94	83	243	62
	3.3	0945	758.418	0.02	0.42	0.42	242	446	93	84	243	60
	55.5	0950	758.418	0.04	0.86	0.86	242	456	90	85	243	60
	39.0			0.03	0.64	0.64	242	468	92	85	242	58
	27.7			0.03	0.64	0.64	243	475	93	85	243	58
	18.4			0.04	0.86	0.86	243	469	94	85	242	57
	10.5			0.03	0.64	0.64	243	476	95	85	242	57
	3.3	1020	772.299	0.02	0.43	0.43	242	460	94	86	242	57
Page 2	Δ = 60	Δ = 29.118	(AP) avg =	(ΔH) avg =	(Tstack) avg =	(Tmeter) avg =						Estimates:
Totals	min	def	0.036	0.76	474 (°F)	88 (°F)						MW = 27.6 %H2O = 13

Dry Gas Composition

System Leak Check (60 sec)

Run 1	Run 2
Before	After
Vacuum (in. Hg)	Vacuum (in. Hg)
DGM Rate (cfm)	DGM Rate (cfm)
Required (cfm)	Required (cfm)
< 0.02	< 0.02

2

$$= \frac{2.54 \times 10^6}{1}$$

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

Pitot Leak Check (15 sec)

Before	After
Positive	Negative

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST DATE: March 8th, 2000
 CONTROL BOX NO.: APEX-4
 HOT/COLD BOX NO.: 5
 TEST NO.: CLR-BBS-M26A-2
 ORIFICE FACTOR (ΔH@): 2.003
 FILTER NO.: 469
 EXIZE: 10-1
 B.P. (in. Hg): 29.50
 METER CORR. (Y): 1-0023
 PROBE NO.: 10-1
 STATIC P. (in. H2O): -1.50
 CALIBRATION DATE: 9-20-99
 NOZZLE DIA. (in.): 0.440
 STACK DIA. (in.): 156
 PORT SIZE & TYPE: 4" Flanges
 PITOT COEF.: 0.84
 PROJECT NO.: 00-016-P

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH Required (in. H2O)	Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F) Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
A	55.5	1053	772.827	0.04	0.85	0.85	4.0	240	456	86	243	60	5 min./pt.
	39.0			0.03	0.64	0.64	3.0	240	478	90	243	60	
	27.7			0.04	0.85	0.85	4.0	240	473	93	243	60	
	18.4			0.04	0.83	0.83	4.0	240	483	95	242	59	
	10.5			0.03	0.63	0.63	3.0	241	475	96	242	55	
	3.3	1123	787.370	0.03	0.63	0.63	3.0	241	491	96	242	55	
B	55.5	1132	787.370	0.04	0.85	0.85	4.0	242	480	92	242	55	
	39.0			0.03	0.63	0.63	3.0	242	445	96	242	52	
	27.7			0.03	0.63	0.63	3.0	241	447	96	243	52	
	18.4			0.03	0.63	0.63	3.0	241	455	97	243	52	
	10.5			0.02	0.43	0.43	2.0	241	460	97	243	52	
	3.3		800.842	0.02	0.43	0.43	2.0	242	462	97	243	52	
Page 1	Δ = 60	min	Δ = 28.015	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =	(Tmeter) avg =			
Totals	min	def	def	0.031	0.66				467	91			Estimates:
Test	Δ = 120	min	Δ = 59.544	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =	(Tmeter) avg =			MW =
Totals	min	def	def	0.035	0.75				472	93			%H2O =

Dry Gas Composition

	Run 1	Run 2
CO2	30.1	
O2	18.0	
CO		
N2	85.0	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.004	< 0.02
After	5.00	0.005	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	637.1	572.8	124.3
2.	100 mL 0.1 N H2SO4	618.8	568.9	49.9
3.	100 mL 0.1 N H2SO4	569.0	566.0	3.0
4.	100 mL 0.1 N NaOH	553.1	551.5	1.6
5.	100 mL 0.1 N NaOH	535.3	533.8	1.5
6.	~200 g Silica Gel	661.9	648.6	13.3
7.				
8.				

total = 193.6 g

CLIENT
U.S. Steel Clairton Works

TEST DATE _____

March 8

CONTROL DAY NO.

1

U

CLAIRTON, PA

Clairton, PA

TEST NO.

CLB - nrc -

OPITECE EACTOP CA

000000

111

TEST UNIT

RP (in Mo)

9.50

MEETINGS

200

1.

TEST CREW
'S K.A. R.S.

STATICS 15

CS

100

— 100 —

-0-

PROJECT NO. 00-016-P

00-016-P

STACK BY

11

NO.	NOZZLE DIA. (IN.)
1	1/8
2	1/4
3	3/8
4	1/2
5	5/8
6	3/4
7	7/8
8	1
9	1 1/8
10	1 1/4
11	1 3/8
12	1 1/2
13	1 5/8
14	1 3/4
15	1 7/8
16	2
17	2 1/8
18	2 1/4
19	2 3/8
20	2 1/2
21	2 5/8
22	2 3/4
23	2 7/8
24	3
25	3 1/8
26	3 1/4
27	3 3/8
28	3 1/2
29	3 5/8
30	3 3/4
31	3 7/8
32	4
33	4 1/8
34	4 1/4
35	4 3/8
36	4 1/2
37	4 5/8
38	4 3/4
39	4 7/8
40	5
41	5 1/8
42	5 1/4
43	5 3/8
44	5 1/2
45	5 5/8
46	5 3/4
47	5 7/8
48	6
49	6 1/8
50	6 1/4
51	6 3/8
52	6 1/2
53	6 5/8
54	6 3/4
55	6 7/8
56	7
57	7 1/8
58	7 1/4
59	7 3/8
60	7 1/2
61	7 5/8
62	7 3/4
63	7 7/8
64	8
65	8 1/8
66	8 1/4
67	8 3/8
68	8 1/2
69	8 5/8
70	8 3/4
71	8 7/8
72	9
73	9 1/8
74	9 1/4
75	9 3/8
76	9 1/2
77	9 5/8
78	9 3/4
79	9 7/8
80	10
81	10 1/8
82	10 1/4
83	10 3/8
84	10 1/2
85	10 5/8
86	10 3/4
87	10 7/8
88	11
89	11 1/8
90	11 1/4
91	11 3/8
92	11 1/2
93	11 5/8
94	11 3/4
95	11 7/8
96	12
97	12 1/8
98	12 1/4
99	12 3/8
100	12 1/2
101	12 5/8
102	12 3/4
103	12 7/8
104	13
105	13 1/8
106	13 1/4
107	13 3/8
108	13 1/2
109	13 5/8
110	13 3/4
111	13 7/8
112	14
113	14 1/8
114	14 1/4
115	14 3/8
116	14 1/2
117	14 5/8
118	14 3/4
119	14 7/8
120	15
121	15 1/8
122	15 1/4
123	15 3/8
124	15 1/2
125	15 5/8
126	15 3/4
127	15 7/8
128	16
129	16 1/8
130	16 1/4
131	16 3/8
132	16 1/2
133	16 5/8
134	16 3/4
135	16 7/8
136	17
137	17 1/8
138	17 1/4
139	17 3/8
140	17 1/2
141	17 5/8
142	17 3/4
143	17 7/8
144	18
145	18 1/8
146	18 1/4
147	18 3/8
148	18 1/2
149	18 5/8
150	18 3/4
151	18 7/8
152	19
153	19 1/8
154	19 1/4
155	19

5

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
C	55.5	1205	800.842	0.04	0.86	0.86	4.0	241	455	92	90	243	54	5 min./pt.
	39.0			0.05	1.08	1.08	5.0	241	485	97	90	243	54	
	27.7			0.05	1.08	1.08	5.0	242	497	98	90	242	54	
	18.4			0.05	1.02	1.02	5.0	242	506	99	90	242	54	
	10.5			0.04	0.82	0.82	4.0	242	597	99	91	243	55	
	3.3	1225	816.751	0.03	0.61	0.61	2.0	243	461	98	91	243	55	
D	55.5	1239	816.751	0.04	0.86	0.86	4.0	242	452	96	91	243	55	
	39.0			0.04	0.86	0.86	4.0	242	454	96	91	243	55	
	27.7			0.04	0.86	0.86	4.0	242	464	98	91	243	54	
	18.4			0.04	0.86	0.86	4.0	242	467	99	91	243	54	
	10.5			0.03	0.65	0.65	3.0	242	455	99	91	243	54	
	3.3	1309	832.371	0.03	0.65	0.65	3.0	242	451	99	91	243	54	
														Estimates:
Page 2	Δ = 60	Δ = 31.529		(AP) avg =	(ΔH) avg =	(Tstack) avg =		(Tmeter) avg =		MW =	27.6			
Totals	min	def		0.04	0.844	4.78(°F)		94(°F)		%H2O =	13			

Dry Gas Composition

System Leak Check (60 sec)

	Run 1	Run 2
CO2		
O2		
CO		
N2		

Run 1 Run 2

Run 2

	Vacuum (in, Hg)	DGM Rate (cfm)	Required (cfm)
Before			< 0.02
After			< 0.02

Pilot Leak Check (15 sec)

	Positive	Negative
Before		
After		

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page

1 of 2

CLIENT U.S. Steel Clairton Works

TEST DATE:

March 8th, 2000

CONTROL BOX NO.

APEX-4

HOT/COLD BOX NO.

1

PLANT SITE Clairton, PA

TEST NO.

CLR - BBS - M26A - 3

ORIFICE FACTOR (AH/Q)

2.003

FILTER NO.

TEST UNIT B-Battery Combustion Stack

B.P. (in. Hg)

29.50

METER CORR. (V)

1.0023

PROBE NO.

10-1

TEST CREW JS, KA, RS.

STATIC P. (in. H2O) -1.50

CALIBRATION DATE

9-20-99

NOZZLE DIA. (in.)

0.440

PROJECT NO. 00-016-P

STACK DIA. (in.)

156

PORT SIZE & TYPE

4" Flanges

PITOT COEF.

0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (deg)	Pilot AP (in. H2O)	Orifice AH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
A	55.5	1350	833.350	0.03	0.65	0.65	2.0	241	449	89	89	242	59	
	39.0			0.03	0.65	0.65	2.0	241	460	93	89	242	56	5 min./pt.
	27.7			0.03	0.65	0.65	2.0	241	464	95	89	242	56	
	18.4			0.03	0.65	0.65	2.0	242	465	96	90	242	56	
	10.5			0.02	0.43	0.43	2.0	242	470	96	90	242	56	
	3.3	1420	846.294	0.02	0.43	0.43	2.0	242	477	96	90	243	54	
	55.5	1427	846.294	0.04	0.85	0.85	4.0	241	461	93	90	243	54	
	39.0			0.04	0.85	0.85	4.0	242	509	97	90	243	54	
	27.7			0.03	0.65	0.65	3.0	241	437	98	90	243	54	
	18.4			0.03	0.65	0.65	3.0	241	436	99	90	243	54	
	10.5			0.02	0.43	0.43	2.0	242	440	99	91	243	55	
	3.3	1457	859.875	0.02	0.43	0.43	2.0	241	441	98	91	242	55	
Page 1	Δ = 60		Δ = 26.525		(ΔP) avg =		(ΔH) avg =		(Tstack) avg =		(Tmeter) avg =			
Totals	min		def		0.028		0.60		459 (°F)		93 (°F)			
Test	Δ = 12.0		Δ = 57.122		(ΔP) avg =		(ΔH) avg =		(Tstack) avg =		(Tmeter) avg =			
Totals	min		def		0.033		0.70		455 (°F)		94 (°F)			

Dry Gas Composition

3.5%

System Leak Check (60 sec)

	Vacuum (in. Hg)		DGM Rate (cfm)		Required (cfm)	
	Before	After	Before	After	Before	After
	5.00	5.00	0.010	0.006	<0.02	<0.02

Pilot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	588.1	484.7	103.4
2.	100 mL 0.1 N H2SO4	595.6	546.4	49.2
3.	100 mL 0.1 N H2SO4	568.1	565.4	2.7
4.	100 mL 0.1 N NaOH	524.7	523.4	1.3
5.	100 mL 0.1 N NaOH	545.4	542.9	2.5
6.	~200 g Silica Gel	646.6	653.3	13.3
7.				
8.				

Total = 172.39



HIGH FLOW SOURCE SAMPLING DATA SHEET

CLIENT U.S. Steel Clairton Works TEST DATE March 8th, 2000 CONTROL BOX NO. APEX-4 HOT/COLD BOX NO. 1

PLANT SITE Clairton, PA TEST NO. CLR-BBS-M26A-3 ORIFICE FACTOR (ΔH/Q) 2.003 FILTER NO. 470 Q7Z

TEST UNIT B-Battery Combustion Stack B.P. (in. Hg) 29.50 METER CORR. (V) 1.0023 PROBE NO. 10-1

TEST CREW JS, KA, RS STATIC P. (in. H2O) -1.50 CALIBRATION DATE 9-20-99 NOZZLE DIA. (in.) 0.440

PROJECT NO. 00-016-P STACK DIA. (in.) 156 PORT SIZE & TYPE 4" Flanges P/TOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pilot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
C	55.5	1500	859-875	0.03	0.65	0.65	2.0	242	452	95	92	243	53	5 min./pt.
	39.0			0.05	1.05	1.05	5.0	242	466	99	92	243	53	
	27.7			0.05	1.05	1.05	5.0	242	474	99	92	243	53	
	18.4			0.04	0.85	0.85	4.0	242	480	100	92	243	53	
	10.5			0.04	0.85	0.85	4.0	242	479	99	91	243	54	
	3.3	1530	875-605	0.03	0.65	0.65	4.0	242	431	99	91	243	54	
D	55.5	1535	875-605	6.04	0.86	0.86	4.0	241	430	93	90	242	54	
	39.0			0.04	0.86	0.86	4.0	241	436	97	90	242	54	
	27.7			0.04	0.86	0.86	4.0	242	442	98	90	243	53	
	18.4			0.04	0.86	0.86	4.0	241	446	98	90	243	53	
	10.5			0.03	0.65	0.65	3.0	241	449	98	90	242	53	
	3.3	1605	890-472	0.03	0.65	0.65	3.0	242	445	98	90	241	53	
				(ΔP) avg =		(ΔH) avg =		(T) avg =		(T) avg =		Estimates:		
Page 2				Δ = 60		Δ = 30.597		452 (°F)		95 (°F)		MW =		27.6
Totals				min		0.038	0.81					%H2O =		13

Dry Gas Composition

	Run 1	Run 2
CO2	3.1	
O2	12.6	
CO		
N2	85.6	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before			< 0.02
After			< 0.02

No. Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4	7.660 = 13.17		
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH	150 = 144.70		
6.	~ 200 g Silica Gel			

$$= \left[\frac{\sum \Delta P_i}{n} \right]$$

Pilot Leak Check (15 sec)

	Positive	Negative

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:

02/29/00

Nozzle No.	Size (inches)				Calibrated
	Avg.	A	B	C	By
1	0.125	0.125	0.125	0.125	KA
2	0.156	0.156	0.156	0.156	KA
3	0.156	0.156	0.156	0.156	KA
44	0.156	0.156	0.156	0.156	KA
11	0.180	0.180	0.180	0.180	KA
5	0.190	0.190	0.190	0.190	KA
27	0.190	0.190	0.190	0.190	KA
28	0.190	0.190	0.190	0.190	KA
29	0.190	0.190	0.190	0.190	KA
31	0.190	0.190	0.190	0.190	KA
4	0.219	0.219	0.219	0.219	KA
6	0.219	0.219	0.219	0.219	KA
7	0.219	0.219	0.219	0.219	KA
15	0.219	0.219	0.219	0.219	KA
42	0.219	0.219	0.219	0.219	KA
40	0.220	0.220	0.220	0.220	KA
10	0.225	0.225	0.225	0.225	KA
8	0.240	0.240	0.240	0.240	KA
9	0.240	0.240	0.240	0.240	KA
41	0.240	0.240	0.240	0.240	KA
50	0.260	0.260	0.260	0.260	KA
51	0.260	0.260	0.260	0.260	KA
12	0.281	0.281	0.281	0.281	KA
13	0.281	0.281	0.281	0.281	KA
14	0.281	0.281	0.281	0.281	KA
16	0.290	0.290	0.290	0.290	KA
17	0.290	0.290	0.290	0.290	KA
18	0.290	0.290	0.290	0.290	KA
45	0.290	0.290	0.290	0.290	KA
20	0.310	0.310	0.310	0.310	KA
33	0.310	0.310	0.310	0.310	KA
35	0.320	0.320	0.320	0.320	KA
21	0.344	0.344	0.344	0.344	KA
22	0.344	0.344	0.344	0.344	KA
23	0.347	0.347	0.347	0.347	KA
24	0.375	0.375	0.375	0.375	KA
25	0.375	0.375	0.375	0.375	KA
26	0.406	0.406	0.406	0.406	KA
30	0.406	0.406	0.406	0.406	KA
47	0.415	0.415	0.415	0.415	KA
34	0.425	0.425	0.425	0.425	KA
55	0.425	0.425	0.425	0.425	KA
52	0.440	0.440	0.440	0.440	KA
					02/27/00

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed: 02/29/00


Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
53	0.440		0.440	0.440	0.440	KA	02/27/00
19	0.450		0.450	0.450	0.450	KA	04-14-98
36	0.490		0.490	0.490	0.490	KA	06-10-97
37	0.490		0.490	0.490	0.490	KA	07-05-96
38	0.495		0.495	0.495	0.495	KA	07-05-96
39	0.500		0.500	0.500	0.500	KA	07-05-96
46	0.625		0.625	0.625	0.625	KA	03-10-98
43	0.750		0.750	0.750	0.750	KA	01/05/00
49	1.060		1.060	1.060	1.060	KA	11-25-96

GEOMETRIC PITOT CALIBRATION

Caliper # XFS-59
 Prochant _____
 Post Check _____

Probe # 10-1
 Date 02-10-00
 Initials KBA


①



$$\begin{aligned} \alpha^1 &= 1^\circ & \alpha^1, \alpha^2 &< 10^\circ \\ \alpha^2 &= 2^\circ \\ \beta^1 &= 1^\circ & \beta^1, \beta^2 &< 5^\circ \\ \beta^2 &= 1^\circ \end{aligned}$$


$$F = 0.975''$$

②



$$\begin{aligned} \mu &= 0.017'' & \mu &\leq 0.1250'' (\delta \tan \times F_p) \\ V &= 0.000'' & V &\leq 0.03125'' (\theta \tan \times F_p) \\ W &= 0.195'' & W &\geq 0'' \end{aligned}$$


③




$$\begin{aligned} 1.05 D_1 &\leq 1.50 D_2 \\ P_A &= P_B \\ 2.10 D_1 &\leq 3.00 D_2 \end{aligned}$$

$$\begin{aligned} Y &= 6.215'' & Y &\geq 3.0'' \\ Z &= 2.417'' & Z &\geq 2.0'' \\ D_1 &= 0.376'' & D_1 &\geq .1875'' \end{aligned}$$


④




⑤



⑥



⑦



CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN WET TEST gas meter,
serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 10 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date

Mark Poe
Signature

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex-A
09-24-99
29.10

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

JPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		318.302			1.0	8.0
	MIDWAY			71		88	78		
	STOP	5.000	9.33		323.417				
	DELTA *	5.000	9.33		5.115				
2	START	0.000	0		324.438			2.0	8.0
	MIDWAY			71		92	79		
	STOP	5.000	6.39		329.522				
	DELTA *	5.000	6.65		5.084				
3	START	0.000	0		331.550			3.0	8.0
	MIDWAY			71		95	80		
	STOP	5.000	5.25		336.644				
	DELTA *	5.000	5.42		5.094				
Dry Gas	START	0.050	0		336.713			0.0	1.0
Meter Leak	STOP	0.358	10.00		337.112				
Check	DELTA *	0.308	10.0		0.399				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0071</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):

☒ Inclined Manometers

☐ Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.33	6.65	5.42	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	88	92	95	
To (°F)	78	79	80	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.115	5.084	5.094	
ΔH@ (in. H2O)	1.988	2.016	2.005	2.003
Y (Pre-test)	0.9971	1.0053	1.0044	1.0023

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

1724-4
04-13-04
29.40


CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
ITS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		75.842			1.5	7.5
	MIDWAY			56		85	69		
	STOP	5.000	8.12		75.927				
	DELTA *	5.000	8.12		5.125				
2	START	0.000	0		75.927			1.5	7.5
	MIDWAY			54		86	69		
	STOP	5.000	8.07		75.052				
	DELTA *	5.000	8.12		5.125				
3	START	0.000	0		75.452			1.5	7.5
	MIDWAY			56		86	69		
	STOP	5.000	8.06		76.102				
	DELTA *	5.000	8.10		5.134				
Dry Gas	START	0.244	0		76.404			0.0	7.5
Meter Leak	STOP	0.400	10:00		76.070				
Check	DELTA *	0.244	10.0		0.394				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0194</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.40	29.40	29.40	
Time (min)	8.12	8.12	8.10	
Tw (°F)	56	56	56	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	85	86	86	
To (°F)	69	69	69	
ΔH (in. H2O)	1.50	1.50	1.50	
Vm (dcf)	5.125	5.125	5.130	
Y (Pre-test)				1.0023
ΔH@ (in. H2O)	2.147	2.147	2.136	2.143
Y (Post-test)	1.0115	1.0125	1.0115	1.0118
ΔY (%)				0.9%

$$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^2$$

$$BP * (To + 460) * (Vw)^2$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

4000 Tech Center Drive
Monroeville, PA 15146
412 825 2400
Fax: 412 825 2407

IH & Environmental Laboratory

RECEIVED MAR 27 2000



UEC

USX Engineers
& Consultants, Inc.

March 23, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on March 10, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

ANALYTE	METHOD
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,



Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

A subsidiary of USX Corporation

USX

REPORT OF TEST RESULTS

DATE - 03/22/2000
 PAGE - 1

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3629 SITE LOCATION : US STEEL CLAIRTON WORKS
TRACKING NUMBER: 1023		

UFC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/kg	PPM	µg/L	µg/kg	pH	%	L00
07367	CLRBBSM26A-1A	CHLORIDE	03/08/00	*	*	*	03/18/00	39							0.20 mg/L
07368	CLRBBSM26A-1B	CHLORIDE	03/08/00	*	*	*	03/18/00	6.8							0.20 mg/L
07369	CLRBBSM26A-1C	CHLORIDE	03/08/00	*	*	*	03/18/00	5.1							0.20 mg/L
07370	CLRBBSM26A-1D	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07371	CLRBBSM26A-2A	CHLORIDE	03/08/00	*	*	*	03/18/00	39							0.20 mg/L
07372	CLRBBSM26A-2B	CHLORIDE	03/08/00	*	*	*	03/18/00	3.4							0.20 mg/L
07373	CLRBBSM26A-2C	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07374	CLRBBSM26A-2D	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07375	CLRBBSM26A-3A	CHLORIDE	03/08/00	*	*	*	03/18/00	33							0.20 mg/L
07376	CLRBBSM26A-3B	CHLORIDE	03/08/00	*	*	*	03/18/00	10							0.20 mg/L
07377	CLRBBSM26A-3C	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07378	CLRBBSM26A-3D	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07379	CLR-H2S04-BLK	CHLORIDE	03/09/00	*	*	*	03/18/00	<0.20							0.20 mg/L

NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable.
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.
 A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE

USX Engineers & Consultants Inc.
 IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 03/22/2000
 PAGE - 2

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harrisville, PA 15238		CUSTOMER P.O. # : 3629 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1023

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	ng/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
07380	CLR-NAOH-BLK	CHLORIDE	03/09/00	*	*	*	03/18/00	<0.20							0.20 mg/L

ANALYST :


APPROVED:

Stephanie A. Guilford
 Date: 3-22-00
 Date: 3/23/00

Stephanie A. Guilford, IHIT, Project Manager

NOTES: * = Information not supplied by client. < = Less than.
 # = Information not requested by client. N/A = Not Applicable.
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE



* Please add 25mg Sodium Thiosulfate prior to analyses
Na₂S₂O₃, 3.5460

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 016-P ; P.O. #3629		ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Clinton Works							
ANALYTICAL LAB DEC Int and Environmental Laboratories							
DELIVER TO Sample Receiving							
COMMENTS B-Battery Combustion Stack							
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	Chloride by us.	Uranium by us.	EA Reference Method 26A
016-005-N26A-1A	03-09-00	0805 →	1	Comp.	✓		
016-005-N26A-1B	↓	1020 EST	1	Comp.	✓		
016-005-N26A-1C	↓	↓	1	Comp.	✓		
016-005-N26A-1D	↓	↓	1	Comp.	✓		
016-005-N26A-2A	03-09-00	1053 →	1	Comp.	✓		
016-005-N26A-2B	↓	1309 EST	1	Comp.	✓		
016-005-N26A-2C	↓	↓	1	Comp.	✓		
016-005-N26A-2D	↓	↓	1	Comp.	✓		

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

* please add 25 mg sodium thiosulfate prior to analysis

CHAIN OF CUSTODY RECORD

[illegible]

**U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
B-BATTERY COMBUSTION STACK**

MARCH 8, 2000

U.S. EPA REFERENCE METHOD 26A SAMPLING

CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-BBS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H2SO4 - Impingers 1 & 2	39	478.6	18.67	94.5
	1B	0.1 N H2SO4 - Impinger 3	6.8	150.9	1.03	
	1C	0.1 N NaOH - Impinger 4	5.1	148.5	0.76	100.0
	1D	0.1 N NaOH - Impinger 5	< 0.20	157.2	< 0.03	
2	2A	0.1 N H2SO4 - Impingers 1 & 2	39	431.9	16.84	97.0
	2B	0.1 N H2SO4 - Impinger 3	3.4	150.9	0.51	
	2C	0.1 N NaOH - Impinger 4	< 0.20	154.0	< 0.03	NA
	2D	0.1 N NaOH - Impinger 5	< 0.20	166.1	< 0.03	
3	3A	0.1 N H2SO4 - Impingers 1 & 2	33	438.2	14.46	88.4
	3B	0.1 N H2SO4 - Impinger 3	10	168.3	1.68	
	3C	0.1 N NaOH - Impinger 4	< 0.20	159.5	< 0.03	NA
	3D	0.1 N NaOH - Impinger 5	< 0.20	164.0	< 0.03	
Blank	Blank	0.1 N H2SO4	< 0.20			
Blank	Blank	0.1 N NaOH	< 0.20			

0.1 N H2SO4

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (< 0.20) ---->
Chloride catch = 0

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE:

3/8/00

TEST NO.: CLR-

BBS-M26A-1

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.50
B.	Process Gas Static Pressure (in. H ₂ O)	-1.50
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	156
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H ₂ O) = [(ΔP ^{0.5}) _{avg}] ² - for flows	0.03
J.	Average ΔP (in. H ₂ O) = [(ΔP ^{0.5}) _{avg}] ² - for isokinetic	0.03
K.	Average ΔH (in. H ₂ O) variation	0.71
L.	Average Process Gas Temperature (°F)	473
M.	Average Dry Gas Meter Temperature (°F)	84
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	11.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H ₂ O Mass Collected in Impingers (g)	203.3
Q.	Metered Gas Volume (dcf)	57.614

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.39	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.55	[A+(K/13.6)]
T.	Duct Area (ft. ²)	1.33E+02	[Pi*E ² /(4*144) or F*G/144]
U.	Nozzle Area (ft. ²)	1.06E-03	[Pi*H ² /(4*144)]
V.	Average Absolute Process Gas Temperature (R)	933	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	544	[M+460]
X.	Dry Gas Volume Sampled (dscf)	55.359	[Q*D*(528/W)*(S/29.92)]
Y.	H ₂ O Vapor Condensed (scf)	9.586	[P*0.04715]
Z.	Calculated Percent H ₂ O in Gas Stream (%)	14.8	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H ₂ O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor
BB.	Actual Percent H ₂ O in Gas Stream (%)	14.8	Pressure / Stack Pressure]
CC.	Process Gas Molecular Weight:		[Calculated %H ₂ O <= Theoretical
			Max. %H ₂ O]

Gas	% Volume / 100	* (1 - %H ₂ O/100)	* Mol. Weight	= Wt./Mol
H ₂ O	0.148		18	2.657
CO ₂	0.040	0.852	44	1.500
O ₂	0.110	0.852	32	3.000
N ₂	0.850	0.852	28	20.287
CO	0.000	0.852	28	0.000
H ₂	0.000	0.852	2	0.000
CH ₄	0.000	0.852	16	0.000
C ₂ H ₆	0.000	0.852	30	0.000
Ar	0.000	0.852	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.44	
DD.	Average Process Gas Velocity (ft/sec)	1.42E+01	$[85.49 * C * [(I * V) / (R * CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	1.13E+05	$[DD * T * 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	6.30E+04	$[EE * (528 / V) * (R / 29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.37E+04	$[FF * (1 - (BB / 100))]$
HH.	Isokinetic Variation (%)	107.9	$[100 * V * \{((0.002669 * P) + (Q * D * S / W))\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0060	
JJ.	Front-Half Residue Weight (g)	0.0129	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0189	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0053	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	2.42E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 3/8/00

TEST SITE: B-BATTERY COMBUSTION STACK

TEST NO.: CLR- BBS-M26A-1

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	20.25	
QQ.	Concentration (mg/dscm)	1.29E+01	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.60E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	0.76	
TT.	Concentration (mg/dscm)	4.83E-01	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	9.72E-02	[TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE: 3/8/00
TEST NO.: CLR- BBS-M26A-2

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.50
B.	Process Gas Static Pressure (in. H2O)	-1.50
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	156
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.04
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.04
K.	Average ΔH (in. H2O) variation	0.75
L.	Average Process Gas Temperature (°F)	472
M.	Average Dry Gas Meter Temperature (°F)	93
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	3.0
	Oxygen (%)	12.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	193.6
Q.	Metered Gas Volume (dcf)	59.544

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.39	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.56	[A+(K/13.6)]
T.	Duct Area (ft. ²)	1.33E+02	[Pi*E ² /(4*144) or F*G/144]
U.	Nozzle Area (ft. ²)	1.06E-03	[Pi*H ² /(4*144)]
V.	Average Absolute Process Gas Temperature (R)	932	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	553	[M+460]
X.	Dry Gas Volume Sampled (dscf)	56.288	[Q*D*(528/W)*(S/29.92)]
Y.	H2O Vapor Condensed (scf)	9.128	[P*0.04715]
Z.	Calculated Percent H2O in Gas Stream (%)	14.0	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%)	#N/A.	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H2O in Gas Stream (%)	14.0	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.140		18	2.512
CO2	0.030	0.860	44	1.136
O2	0.120	0.860	32	3.304
N2	0.850	0.860	28	20.479
CO	0.000	0.860	28	0.000
H2	0.000	0.860	2	0.000
CH4	0.000	0.860	16	0.000
C2H6	0.000	0.860	30	0.000
Ar	0.000	0.860	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.43	
DD.	Average Process Gas Velocity (ft/sec)	1.44E+01	[85.49*C*[(I*V)/(R*CC)]^0.5]
EE.	Process Gas Volumetric Flow Rate (acfm)	1.15E+05	[DD*T*60]
FF.	Process Gas Volumetric Flow Rate (scfm)	6.40E+04	[EE*(528/V)*(R/29.92)]
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.51E+04	[FF*(1-(BB/100))]
HH.	Isokinetic Variation (%)	107.0	[100*V*{(0.002669*P)+(Q*D*S/W)}]

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)		
JJ.	Front-Half Residue Weight (g)	0.0051	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0204	
LL.	Total Weight (g)	0.0000	
NN.	Concentration (gr/dscf)	0.0255	[II+JJ+KK]
OO.	Mass Flow Rate (lb/hr)	0.0070	[(7000/454)*LL/X]
		3.30E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 3/8/00

TEST SITE: B-BATTERY COMBUSTION STACK

TEST NO.: CLR- BBS-M26A-2

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	17.85	
QQ.	Concentration (mg/dscm)	1.12E+01	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.31E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.03
TT.	Concentration (mg/dscm)	<	1.93E-02 [SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	3.98E-03 [TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE: 3/8/00
TEST NO.: CLR- BBS-M26A-3

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.50
B.	Process Gas Static Pressure (in. H2O)	-1.50
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	156
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.03
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.03
K.	Average ΔH (in. H2O) variation	0.70
L.	Average Process Gas Temperature (°F)	455
M.	Average Dry Gas Meter Temperature (°F)	94
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	3.0
	Oxygen (%)	12.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	172.3
Q.	Metered Gas Volume (dcf)	57.122

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.39	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.55	[A+(K/13.6)]
T.	Duct Area (ft. ²)	1.33E+02	[$\pi E^2/(4 \times 144)$ or $F \times G/144$]
U.	Nozzle Area (ft. ²)	1.06E-03	[$\pi H^2/(4 \times 144)$]
V.	Average Absolute Process Gas Temperature (R)	915	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	554	[M+460]
X.	Dry Gas Volume Sampled (dscf)	53.894	[$Q \times D \times (528/W) \times (S/29.92)$]
Y.	H2O Vapor Condensed (scf)	8.124	[$P \times 0.04715$]
Z.	Calculated Percent H2O in Gas Stream (%)	13.1	[$100 \times Y/(X+Y)$]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%) (empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)	#N/A	[$100 \times \text{Saturated Water Vapor Pressure} / \text{Stack Pressure}$]
BB.	Actual Percent H2O in Gas Stream (%)	13.1	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.131		18	2.358
CO2	0.030	0.869	44	1.147
O2	0.120	0.869	32	3.337
N2	0.850	0.869	28	20.682
CO	0.000	0.869	28	0.000
H2	0.000	0.869	2	0.000
CH4	0.000	0.869	16	0.000
C2H6	0.000	0.869	30	0.000
Ar	0.000	0.869	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.52	
DD.	Average Process Gas Velocity (ft/sec)	1.39E+01	[85.49*C*[(I*V)/(R*CC)]^0.5]
EE.	Process Gas Volumetric Flow Rate (acfm)	1.10E+05	[DD*T*60]
FF.	Process Gas Volumetric Flow Rate (scfm)	6.26E+04	[EE*(528/V)*(R/29.92)]
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.44E+04	[FF*(1-(BB/100))]
HH.	Isokinetic Variation (%)	103.7	[100*V*{(0.002669*P)+(O*D*S/W)}]

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0035	
JJ.	Front-Half Residue Weight (g)	0.0131	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0166	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0047	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	2.22E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
 TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE: 3/8/00
 TEST NO.: CLR- BBS-M26A-3

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	16.60	
QQ.	Concentration (mg/dscm)	1.09E+01	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.22E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.03
TT.	Concentration (mg/dscm)	<	2.09E-02 [SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	4.26E-03 [TT*0.02832*GG*60/454000]



United States Steel
Clairton Works
400 State Street
Clairton, PA 15025-1855

September 6, 2001

Mr. Gary Fischman
Allegheny County Health Department
301 39th Street
Pittsburgh, PA 15201-1891

SUBJECT: Stack Testing Results

Dear Mr. Fischman:

Enclosed are the most recent reports of stack testing (for HCl, Cl_2 and NH_3) that you requested. These would include: Batteries 1,2,3,9,13,14,19,20 and B and the SCOT Plant Incinerator.

If you have any questions, please contact me at (412) 233-1486.

Sincerely,

A handwritten signature in dark ink, appearing to read "R. P. Spargal".

R. P. Spargal, P.E.
Environmental Engineer

C: WCG



639 Alpha Drive
Pittsburgh, Pennsylvania 15238
Telephone (412) 967-1900
FAX (412) 967-1911

ADVANCED TECHNOLOGY SYSTEMS, INC.

ATS Project No. 00-016-P

September 13, 2000

Mr. William C. Graeser
Manager – Environmental and Quality Assurance
U.S. Steel Clairton Works
400 State Street
Clairton, PA 15025

RE: LETTER REPORT – HYDROCHLORIC ACID AND CHLORINE GAS EMISSIONS TESTING CONDUCTED AT B-BATTERY COMBUSTION STACK ON MARCH 8, 2000

Dear Mr. Graeser:

This letter, with attachments, constitutes the report that summarizes the results of the hydrochloric acid (HCl) and chlorine gas (Cl₂) emissions testing conducted at B-Battery Combustion Stack by Advanced Technology Systems, Inc. (ATS). Three two-hour test runs were conducted on March 8, 2000 simultaneous with the compliance test program at this stack (particulate matter and visible emissions were measured as part of the compliance test program).

The test results have been summarized in the attached Table 1. Hydrochloric acid and chlorine gas concentrations are listed in units of milligrams per dry standard cubic meter (mg/dscm). Hydrochloric acid and chlorine gas mass emission rates are listed in units of pounds per hour (lb/hr). Table 1 also presents pertinent exhaust gas and sampling parameters including exhaust gas flow rates in units of actual cubic feet per minute (acfm), standard cubic feet per minute (scfm), and dry standard cubic feet per minute (dscfm), exhaust gas temperature (°F), and moisture content of the exhaust gas (percent by volume), gas volume sampled for each test run in units of dry standard cubic feet (dscf) and the isokinetic variation value for each test run. The isokinetic variation value is equal to the ratio of the average linear gas velocity sampled through the probe nozzle to the average exhaust gas velocity. All isokinetic variation values are between 90 percent and 110 percent, which is the acceptable range of values. Actual test sampling times have also been included in Table 1.

Hydrochloric acid and chlorine gas emission testing was performed in accordance with U.S. EPA Reference Methods 1 through 4 and 26A and the requirements of the Pennsylvania Department of Environmental Protection (PA DEP) Source Testing Manual (Draft Revision 3.1, May 3, 1999). Detailed information regarding the procedures used to measure the exhaust gas stream velocity and volumetric flow rate (i.e., U.S. EPA Reference Methods 1 through 4) can be found in the summary report for the compliance test program. Hydrochloric acid and chlorine gas sampling was performed in accordance with U.S. EPA Reference Method 26A. Process gas samples were withdrawn

isokinetically from the stack, with particulate matter collected in a glass nozzle, a heated glass-lined probe, and on a heated quartz filter. Vapor phase hydrochloric acid and chlorine gas were collected in a series of chilled impingers. The impinger type and sequence is listed below:

<u>No.</u>	<u>Impinger Type</u>	<u>Contents</u>
1.	Modified Greenburg-Smith	50 mL 0.1 N sulfuric acid (for HCl collection)
2.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
3.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
4.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
5.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
6.	Modified Greenburg-Smith	200 g Silica Gel

A gas volume greater than 50 dry standard cubic feet (dscf) – the minimum gas volume required by the PA DEP for the compliance test program - was sampled for each test run. The flow rate through each sample train was less than 1 dry standard cubic foot per minute as required by U.S. EPA Reference Method 26A.

Following each test run, the sample trains were processed in accordance with PA DEP requirements. Detailed information regarding the procedures used to recover the particulate matter catch (essentially U.S. EPA Reference Method 5 procedures) can be found in the summary report for the compliance test program. Following the gravimetric analysis of the impingers for moisture gain, the following four samples fractions were generated for each sample train:

<u>Fraction</u>	<u>Description</u>
A	Contents of Impinger Nos. 1 & 2 plus applicable distilled deionized water rinses (for HCl)
B	Contents of Impinger No. 3 plus applicable distilled deionized water rinses (for HCl)
C	Contents of Impinger No. 4 plus applicable distilled deionized water rinses (for Cl ₂)
D	Contents of Impinger No. 5 plus applicable distilled deionized water rinses (for Cl ₂)

For each sample train, each of the four fractions were analyzed separately as required by the PA DEP to allow for the calculation of the collection efficiency of the sample train for HCl and Cl₂ collection. The contents of Impinger No. 6 were discarded.

The actual test samples plus field blanks of the impinger scrubbing solutions (0.1 N sulfuric acid and 0.1 N sodium hydroxide) were submitted to the subcontract analytical laboratory for chloride ion analyses using ion chromatographic techniques in accordance with U.S. EPA Reference Method 26A. The analytical laboratory results showed the following:

- The chloride ion concentrations of the field blanks were less than the analytical detection limit;

- For all three test runs, the HCl collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction B was at most 10 percent of the chloride catch from Sample Fraction A plus Sample Fraction B); and
- For the first test run, the Cl₂ collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction D was at most 10 percent of the chloride catch from Sample Fraction C plus Sample Fraction D). The Cl₂ collection efficiency of the sample train for the second and third test runs could not be calculated since the chloride catches in Sample Fractions C and D were less than the analytical detection limit.

Copies of the field data sheets, equipment calibration data, analytical laboratory results and emissions calculations are included in the appendix.

ATS appreciates the opportunity to provide U.S. Steel with process gas testing services. If you have any questions regarding this letter report, please call Dr. Robinson Khosah or me at (412) 967-1900 or e-mail me at the following address: jshimshock@atsengineers.com.

Very truly yours,



John P. Shimshock, Ph.D.
Senior Project Scientist

Approved by:



Robinson P. Khosah, Ph.D.
Vice President
Science and Technology Division

JPS/blc
Enclosures

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

TABLE 1

**B-BATTERY COMBUSTION STACK
HYDROCHLORIC ACID AND CHLORINE GAS EMISSIONS DATA
MARCH 8, 2000**

		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
<u>Emissions Data</u>					
Hydrochloric Acid (HCl)					
Concentration	(mg/dscm)	1.29E+01	1.12E+01	1.09E+01	1.17E+01
Mass Emission Rate	(lb/hr)	2.60E+00	2.31E+00	2.22E+00	2.38E+00
Chlorine Gas (Cl ₂)					
Concentration	(mg/dscm)	4.83E-01	< 1.93E-02	< 2.09E-02	< 1.74E-01
Mass Emission Rate	(lb/hr)	9.72E-02	< 3.98E-03	< 4.26E-03	< 3.51E-02
<u>Exhaust Stack Conditions</u>					
Volumetric Flow Rate	(acfm)	1.13E+05	1.15E+05	1.10E+05	1.13E+05
	(scfm)	6.30E+04	6.40E+04	6.26E+04	6.32E+04
	(dscfm)	5.37E+04	5.51E+04	5.44E+04	5.44E+04
Temperature	(°F)	473	472	455	467
Moisture Content	(%)	14.8	14.0	13.1	14.0
<u>Sampling Conditions</u>					
Test Times	(EST)	0805 to 1020	1053 to 1309	1350 to 1605	
Sampling Time - *	(minutes)	120	120	120	
Sample Volume - **	(dscf)	55.359	56.288	53.894	
Isokinetic Variation - ***	(%)	107.9	107.0	103.7	

mg / dscm = milligrams per dry standard cubic meter

*: Minimum required sampling time is 2 hours (120 minutes)

**: Minimum required sample volume is 50 dscf

***: Acceptable range of values is 90.0% <= Isokinetic Variation <= 110.0%

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

**Hydrochloric Acid and Chlorine Gas
Emissions Testing Conducted at
B-Battery Combustion Stack
on March 8, 2000**

September 2000

APPENDIX

**Field Data Sheets, Equipment Calibration Data,
Analytical Laboratory Results and Emissions
Calculations**



ADVANCED TECHNOLOGY SYSTEMS, INC.

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST DATE March 8th, 2000
 TEST NO. CLR-BBS-M26A-1
 B.P. (in. Hg) 29.50
 STATIC P. (in. H2O) -1.50
 STACK DIA. (in.) 156
 PORT SIZE & TYPE 4" Flanges P/TOT COEF. 0.84
 U.S. Steel Clairton Works
 Clairton, PA
 B-Battery Combustion Stack
 PROJECT NO. 00-016-P
 TEST UNIT B-Battery Combustion Stack
 TEST CREW JS, KA, RS
 CONTROL BOX NO. APEX-4
 ORIFICE FACTOR (AH@) 2.003
 METER CORR. (V) 1.0023
 CALIBRATION DATE 9-26-99
 NOZZLE DIA. (in.) 0.440
 FILTER NO. 467017
 PROBE NO. 10-1

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH Required (in. H2O)	Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F)	Meter Temp. Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
A	55.5	0805	714.685	0.04	0.82	0.82	4.0	241	468	73	71	245	63	5 min./pt.
	39.0			0.04	0.82	0.82	4.0	241	480	77	72	245	63	
	27.7			0.04	0.81	0.81	4.0	242	490	81	72	245	58	
	18.4			0.04	0.81	0.81	4.0	242	500	83	73	245	59	
	10.5			0.03	0.61	0.61	3.0	242	506	85	74	244	59	
	3.3	0835	729.141	0.03	0.60	0.60	3.0	242	468	86	74	243	59	
B	55.5	0840	729.141	0.03	0.61	0.61	3.0	242	444	81	76	243	61	
	39.0			0.03	0.61	0.61	3.0	242	451	85	76	243	60	
	27.7			0.03	0.63	0.63	3.0	241	457	87	77	243	60	
	18.4			0.04	0.84	0.84	5.0	241	466	90	78	243	59	
	10.5			0.02	0.42	0.42	2.0	241	466	89	79	243	58	
	3.3	0910	742.181	0.02	0.42	0.42	2.0	242	471	89	79	243	58	
Page 1	Δ = 60	Δ = 27.496		(ΔP) avg =	(ΔH) avg =				(Tstack) avg =		(Tmeter) avg =			
Totals	min	def		0.032	0.66				472 (°F)		79 (°F)			Estimates:
Test	Δ = 120	Δ = 57.614		(ΔP) avg =	(ΔH) avg =				(Tstack) avg =		(Tmeter) avg =			MW = 27.6
Totals	min	def		0.034	0.71				473 (°F)		84 (°F)			%H2O = 13

Dry Gas Composition

	Run 1	Run 2
CO2	4.0%	
O2	11.0%	
CO	-	
N2	85.0%	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.010	< 0.02
After	7.00	0.006	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	-

No. Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	613.4	489.6	123.8
2.	100 mL 0.1 N H2SO4	612.8	553.5	59.3
3.	100 mL 0.1 N H2SO4	528.5	523.9	4.6
4.	100 mL 0.1 N NaOH	537.8	534.4	4.4
5.	100 mL 0.1 N NaOH	534.6	553.0	1.6
6.	~ 200 g Silica Gel	591.6	578.0	13.6
7.				
8.				total = 243.39

CLIENT
U.S. Steel Clairton Works

U.S. Steel Clairton Works

TEST DATE:

March 8th 2000

CONTROL BOY NO.

ABREV. Δ TROT/COI D DOY NO

5

PLANT SITE

Clairton, PA

TEST NO.

CIR - PBS - M

OFFICE FACTOR (A)

002
THE NEW YORK

1

TEST UNIT

B-Battery Combustion Stack

Rp (in H α)

29.50

METER COPY 14

002 PROCEEDING

A

TEST CREW

515 VA. 25.

STATIC P (in

0
M
.

CAVALRY DATA

h-gg

PROJECT NO. 00-016-P

00-016-P

STACK DIA

156

PORT SIZE & TYPE

SECRET

1

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcl)	Pitot ΔP (in. H ₂ O)	Orifice ΔH (in. H ₂ O)		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filler Temp. (°F)	Exit Temp. (°F)	Comments
					Required	Actual				In	Out			
C	55.5	0915	742.181	0.05	1.05	1.05	6.0	242	462	86	81	243	58	5 min./pt.
	39.0			0.06	1.26	1.26	7.0	242	503	92	81	242	58	
	27.7			0.05	1.05	1.05	6.0	241	513	94	82	242	58	
	18.4			0.04	0.84	0.84	5.0	241	522	94	83	242	58	
	10.5			0.03	0.63	0.63	4.0	241	444	94	83	243	62	
	3.3	0945	758.418	0.02	0.42	0.42	2.0	242	446	93	84	243	60	
D	55.5	0950	758.418	0.04	0.86	0.86	5.0	242	456	90	85	243	60	
	39.0			0.03	0.64	0.64	3.0	242	468	92	85	242	58	
	27.7			0.03	0.64	0.64	3.0	243	476	93	85	243	58	
	18.4			0.04	0.86	0.86	5.0	243	469	94	85	242	57	
	10.5			0.03	0.64	0.64	3.0	243	476	95	85	242	57	
	3.3	1020	772.299	0.02	0.43	0.43	2.0	242	460	94	86	242	57	
Page 2	Δ = 60	Δ = 29.118	(ΔP) avg =	(ΔH) avg =					(Tstack) avg =		(Tmeter) avg =			Estimates:
Totals	min	dcl	0.036		0.76				474 (°F)		88 (°F)			MW = 27.6 %H ₂ O = 13

Dry Gas Composition

System Leak Check (60 sec)

Run 1 Run 2

Run 2

	Run 1	Run 2
CO ₂		
O ₂		
CO		
N ₂		

	vacuum (in. Hg)	DGM rate (cfm)	required (cfm)
Before			< 0.02
After			< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before		
After		

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H ₂ SO ₄			
2.	100 mL 0.1 N H ₂ SO ₄			
3.	100 mL 0.1 N H ₂ SO ₄			9.460 = 14.8%
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			150. = 168%
6.	~ 200 g Silica Gel			
7.				
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST UNIT: B-Battery Combustion Stack
 TEST CREW: JS, KA, RS
 PROJECT NO.: 00-016-P
 TEST DATE: March 8, 2000
 TEST NO.: CLR-BBS-M26A-2
 B.P. (in. Hg): 29.50
 STATIC P. (in. H2O): -1.50
 STACK DIA. (in.): 156
 CONTROL BOX NO.: APEX-4
 ORIFICE FACTOR (ΔH): 2.003
 METER CORR. (%): 1.0023
 CALIBRATION DATE: 9-20-99
 PORT SIZE & TYPE: 4" Flanges
 PITOT COEF.: 0.84
 FILTER NO.: 469
 PROBE NO.: 10-1
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)	
A	55.5	1053	772.827	0.04	0.85	0.85	240	456	86	86	5 min./pt.
	39.0			0.03	0.64	0.64	240	478	90	86	
	27.7			0.04	0.85	0.85	240	473	93	87	
	18.4			0.04	0.83	0.83	240	483	95	87	
	10.5			0.03	0.63	0.63	241	475	96	88	
	3.3	1123	787.370	0.03	0.63	0.63	241	491	96	88	
B	55.5	1132	787.370	0.04	0.85	0.85	242	480	92	89	
	39.0			0.03	0.63	0.63	242	445	96	89	
	27.7			0.03	0.63	0.63	241	447	96	89	
	18.4			0.03	0.63	0.63	241	455	97	90	
	10.5			0.02	0.43	0.43	241	460	97	90	
	3.3		800.842	0.02	0.43	0.43	242	462	97	90	
Page 1	Δ = 60	min	Δ = 28.015	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =		
Totals		def	def	0.031		0.66		467	91		Estimates:
Test	Δ = 120	min	Δ = 59.544	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =		MW = 27.6
Totals		def	def	0.035		0.75		472	93		%H2O = 13

Dry Gas Composition: Run 1 Run 2
 CO2: 30.1
 O2: 12.0
 CO: 1.0
 N2: 85.0
 System Leak Check (60 sec):
 Vacuum (in. Hg): 5.00
 DGM Rate (cfm): 0.004
 Required (cfm): <0.02
 Before: 5.00
 After: 5.00
 Pilot Leak Check (15 sec):
 Positive: OK
 Negative: OK
 Before: OK
 After: OK
 Impinger Contents:
 No. 1: 50 mL 0.1 N H2SO4
 No. 2: 100 mL 0.1 N H2SO4
 No. 3: 100 mL 0.1 N H2SO4
 No. 4: 100 mL 0.1 N NaOH
 No. 5: 100 mL 0.1 N NaOH
 No. 6: ~200 g Silica Gel
 No. 7:
 No. 8:
 Final Initial Δ (g):
 1: 637.1 52.8 124.3
 2: 618.8 508.9 49.9
 3: 588.0 566.0 3.0
 4: 553.1 531.5 1.6
 5: 535.3 533.8 1.5
 6: 661.9 648.6 13.3
 7:
 8:
 Total = 193.4

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works Clairton, PA TEST DATE March 8, 2000 CONTROL BOX NO. APEX-4 HOT/COLD BOX NO. 1

PLANT SITE B-Battery Combustion Stack TEST NO. CLR - BBS - M26A - 3 ORIFICE FACTOR (ΔH%) 2.003 FILTER NO. 470

TEST UNIT TS, KA, RS. B.P. (in. Hg) 29.50 METER CORR. (%) 1.0023 PROBE NO. 10-1

TEST CREW PROJECT NO. 00-016-P STACK DIA. (in.) 156 PORT SIZE & TYPE 4" Flanges PITOT COEF. 0.84

STATIC P. (in. H2O) -1.50 CALIBRATION DATE 9-20-99 NOZZLE DIA. (in.) 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
A	55.5	1350	833.350	0.03	0.65	0.65	241	449	89	89	242	59
	39.0			0.03	0.65	0.65	241	460	93	89	242	56
	27.7			0.03	0.65	0.65	241	464	95	89	242	56
	18.4			0.03	0.65	0.65	242	465	96	90	242	56
	10.5			0.02	0.43	0.43	242	470	96	90	242	56
	3.3	1420	846.294	0.02	0.43	0.43	242	477	96	90	243	54
B	55.5	1427	846.294	0.04	0.85	0.85	241	461	93	90	243	54
	39.0			0.04	0.85	0.85	242	509	97	90	243	54
	27.7			0.03	0.65	0.65	241	437	98	90	243	54
	18.4			0.03	0.65	0.65	241	436	99	90	243	54
	10.5			0.02	0.43	0.43	242	440	99	91	243	55
	3.3	1457	859.875	0.02	0.43	0.43	241	441	98	91	242	55
Page 1	Δ = 60	min	Δ = 26.525	def	ΔP avg = (ΔH) avg =			(Tstack) avg =		(Tmeter) avg =		
Totals					0.028			459 (°F)		93 (°F)		Estimates:
Test	Δ = 120	min	Δ = 57.122	def	ΔP avg = (ΔH) avg =			(Tstack) avg =		(Tmeter) avg =		MW =
Totals					0.033			455 (°F)		94 (°F)		%H2O =

Dry Gas Composition

Run 1 Run 2

CO2	3.0	
O2	12.0	
CO	-	
N2	85.0	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.010	<0.02
After	5.00	0.006	<0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

Impinging Contents

No.	Impinging Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	588.1	484.7	103.4
2.	100 mL 0.1 N H2SO4	595.6	546.0	49.6
3.	100 mL 0.1 N H2SO4	568.1	565.9	2.2
4.	100 mL 0.1 N NaOH	574.7	573.4	1.3
5.	100 mL 0.1 N NaOH	545.4	542.9	2.5
6.	~ 200 g Silica Gel	666.6	653.3	13.3
7.				
8.				

Total = 172.3g

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT U.S. Steel Clairton Works Clairton, PA TEST DATE March 8th, 2000 CONTROL BOX NO. APEX-4 HOT/COLD BOX NO. 1

PLANT SITE B-Battery Combustion Stack TEST NO. CLR-BBS-M26A-3 ORIFICE FACTOR ($\Delta H/\rho$) 2.003 FILTER NO. 470 Q7Z

TEST UNIT B.P. (in. Hg) 29.50 METER CORR. (V) 1.0023 PROBE NO. 10-1

TEST CREW JS, KA, RS STATIC P. (in. H2O) -1.50 CALIBRATION DATE 9-20-99 NOZZLE DIA. (in.) 0.440

PROJECT NO. 00-016-P STACK DIA. (in.) 156 PORT SIZE & TYPE 4" Flanges PITOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcf)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
C	55.5	1500	859.875	0.03	0.65	0.65	2.0	452	95	92	243	53
	39.0			0.05	1.05	1.05	5.0	466	99	92	243	53
	27.7			0.05	1.05	1.05	5.0	474	99	92	243	53
	18.4			0.04	0.85	0.85	4.0	480	100	92	243	53
	10.5			0.04	0.85	0.85	4.0	479	99	92	243	54
	3.3	1530	875.605	0.03	0.65	0.65	4.0	431	99	91	243	54
D	55.5	1535	875.605	0.04	0.86	0.86	4.0	430	93	90	242	54
	39.0			0.04	0.86	0.86	4.0	436	97	90	242	54
	27.7			0.04	0.86	0.86	4.0	442	98	90	243	53
	18.4			0.04	0.86	0.86	4.0	446	98	90	243	53
	10.5			0.03	0.65	0.65	3.0	449	98	90	242	53
	3.3	1605	890.472	0.03	0.65	0.65	3.0	445	98	90	241	53
Page 2	$\Delta = 60$	$\Delta = 30.597$		$(\Delta P)_{avg} =$	$(\Delta H)_{avg} =$			$(T_{stack})_{avg} =$		$(T_{meter})_{avg} =$		Estimates:
Totals	min	dcf		0.038	0.81			452 (°F)		95 (°F)		MW = 27.6
												%H2O = 13

Dry Gas Composition

	Run 1	Run 2
CO2	3.6	
O2	12.6	
CO		
N2	85.6	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before			< 0.02
After			< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before		
After		

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

Total = 13.1%

ISO = 104%

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:

02/29/00

Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
1	0.125		0.125	0.125	0.125	KA	03-12-96
2	0.156		0.156	0.156	0.156	KA	03-12-96
3	0.156		0.156	0.156	0.156	KA	09-04-96
44	0.156		0.156	0.156	0.156	KA	09-04-96
11	0.180		0.180	0.180	0.180	KA	07-20-98
5	0.190		0.190	0.190	0.190	KA	02/18/00
27	0.190		0.190	0.190	0.190	KA	05-19-99
28	0.190		0.190	0.190	0.190	KA	05-19-99
29	0.190		0.190	0.190	0.190	KA	01/05/00
31	0.190		0.190	0.190	0.190	KA	05-19-99
4	0.219		0.219	0.219	0.219	KA	10-20-98
6	0.219		0.219	0.219	0.219	KA	03-12-97
7	0.219		0.219	0.219	0.219	KA	03-12-97
15	0.219		0.219	0.219	0.219	KA	05-19-99
42	0.219		0.219	0.219	0.219	KA	01/05/00
40	0.220		0.220	0.220	0.220	KA	05-19-99
10	0.225		0.225	0.225	0.225	KA	05-19-99
8	0.240		0.240	0.240	0.240	KA	01/05/00
9	0.240		0.240	0.240	0.240	KA	01/05/00
41	0.240		0.240	0.240	0.240	KA	01/05/00
50	0.260		0.260	0.260	0.260	KA	05-19-99
51	0.260		0.260	0.260	0.260	KA	01/05/00
12	0.281		0.281	0.281	0.280	KA	07-18-97
13	0.281		0.281	0.281	0.281	KA	10-20-98
14	0.281		0.281	0.280	0.281	KA	03-12-97
16	0.290		0.290	0.290	0.290	KA	07-24-96
17	0.290		0.290	0.290	0.290	KA	03-10-98
18	0.290		0.290	0.290	0.290	KA	07-05-96
45	0.290		0.290	0.290	0.290	KA	01/05/00
20	0.310		0.310	0.310	0.310	KA	03-10-98
33	0.310		0.310	0.310	0.310	KA	04-14-98
35	0.320		0.320	0.320	0.320	KA	01/05/00
21	0.344		0.344	0.344	0.344	KA	03-10-98
22	0.344		0.344	0.344	0.344	KA	02/18/00
23	0.347		0.347	0.347	0.347	KA	03-10-98
24	0.375		0.375	0.375	0.375	KA	02/18/00
25	0.375		0.375	0.375	0.375	KA	03-12-96
26	0.406		0.406	0.406	0.406	KA	04-19-96
30	0.406		0.406	0.406	0.406	KA	07-20-98
47	0.415		0.415	0.415	0.415	KA	11-25-96
34	0.425		0.425	0.425	0.424	KA	06-10-97
55	0.425		0.425	0.425	0.424	KA	01/05/00
52	0.440		0.440	0.440	0.440	KA	02/27/00

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:


02/29/00

Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
53	0.440		0.440	0.440	0.440	KA	02/27/00
19	0.450		0.450	0.450	0.450	KA	04-14-98
36	0.490		0.490	0.490	0.490	KA	06-10-97
37	0.490		0.490	0.490	0.490	KA	07-05-96
38	0.495		0.495	0.495	0.495	KA	07-05-96
39	0.500		0.500	0.500	0.500	KA	07-05-96
46	0.625		0.625	0.625	0.625	KA	03-10-98
43	0.750		0.750	0.750	0.750	KA	01/05/00
49	1.060		1.060	1.060	1.060	KA	11-25-96

GEOMETRIC PITOT CALIBRATION

Caliper # XFS-59
 Presheet _____
 Post Check _____

Probe #: 10-1
 Date: 02-10-00
 Initials: KBF



$A_1 = 1^\circ$
 $A_2 = 2^\circ$ $\Rightarrow A_1, A_2 = < 10^\circ$
 $B_1 = 1^\circ$
 $B_2 = 1^\circ$ $\Rightarrow B_1, B_2 = < 5^\circ$

$F = 0.975"$

$\mu = 0.017"$

$\mu \leq 0.1250" (\delta_{TAN} \times F_{aj})$

$V = 0.000"$

$V \leq 0.03125" (\Theta_{TAN} \times F_{aj})$

$W = 0.195"$

$W \geq 0"$

$X = 0.321"$

$X \geq 0.750"$
 (3/4" using 1/8" scale)

$Y = 6.215"$







$Y \geq 3.0"$

$Z = 2.417"$

$Z \geq 2.0"$

$D_1 = 0.376"$

$D_1 \geq .1875"$



CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN Wet Test gas meter,
serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 10 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

_____	_____
_____	_____
_____	_____
_____	_____

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date:

Mark Poe

Signature

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex-A
09-24-99
29.10

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
JPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		318.302			1.0	8.0
	MIDWAY			71		88	78		
	STOP	5.000	9.20		323.417				
	DELTA *	5.000	9.33		5.115				
2	START	0.000	0		324.438			2.0	8.0
	MIDWAY			71		92	79		
	STOP	5.000	6.39		329.522				
	DELTA *	5.000	6.65		5.084				
3	START	0.000	0		331.550			3.0	8.0
	MIDWAY			71		95	80		
	STOP	5.000	5.25		336.644				
	DELTA *	5.000	5.42		5.094				
Dry Gas	START	0.050	0		336.713			0.0	1.0
Meter Leak	STOP	0.358	10:00		337.112				
Check	DELTA *	0.308	10.0		0.359				
$\{ \text{DELTA Vw (cf)} - \text{DELTA Vd (dcf)} \} / 10 \text{ (min.)} = \underline{0.001} \text{ cfm} \leq 0.02 \text{ cfm}$									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.33	6.65	5.42	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	88	92	95	
To (°F)	78	79	80	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.115	5.084	5.094	
ΔH@ (in. H2O)	1.988	2.016	2.005	2.003
Y (Pre-test)	0.9971	1.0053	1.0044	1.0023

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

APR-4
04-13-04
29.44

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
DS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.444	0		745.842			1.5	7.5
	MIDWAY			56		85	69		
	STOP	5.044	8.104		754.927				
	DELTA *	5.044	8.12		5.125				
2	START	0.444	0		754.927			1.5	7.5
	MIDWAY			54		86	69		
	STOP	5.444	8.67		756.052				
	DELTA *	5.444	8.12		5.125				
3	START	0.444	0		756.452			1.5	7.5
	MIDWAY			56		86	69		
	STOP	5.444	8.46		761.182				
	DELTA *	5.444	8.14		5.134				
Dry Gas	START	0.244	0		761.484			0.4	7.5
Meter Leak	STOP	0.444	10:00		761.878				
Check	DELTA *	0.244	10.0		0.394				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0194</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):

✓ Inclined Manometers

 Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.40	29.40	29.40	
Time (min)	8.12	8.12	8.10	
Tw (°F)	56	56	56	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	85	86	86	
To (°F)	69	69	69	
ΔH (in. H2O)	1.50	1.50	1.50	
Vm (dcf)	5.125	5.125	5.130	
Y (Pre-test)				1.0023
ΔH@ (in. H2O)	2.147	2.147	2.136	2.143
Y (Post-test)	1.0115	1.0125	1.0115	1.0118
ΔY (%)				0.9%

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP/(\Delta H/13.6)] * (Tw+460)}$$

RECEIVED MAR 27 2000



UEC

USX Engineers
& Consultants, Inc.

March 23, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on March 10, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

ANALYTE	METHOD
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Guilyard

Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

REPORT OF TEST RESULTS

DATE - 03/22/2000
 PAGE - 1

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3629 SITE LOCATION : US STEEL CLAIRTON WORKS
TRACKING NUMBER: 1023		

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
07367	CLRBBSM26A-1A	CHLORIDE	03/08/00	*	*	*	03/18/00	39							0.20 mg/L
07368	CLRBBSM26A-1B	CHLORIDE	03/08/00	*	*	*	03/18/00	6.8							0.20 mg/L
07369	CLRBBSM26A-1C	CHLORIDE	03/08/00	*	*	*	03/18/00	5.1							0.20 mg/L
07370	CLRBBSM26A-1D	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07371	CLRBBSM26A-2A	CHLORIDE	03/08/00	*	*	*	03/18/00	39							0.20 mg/L
07372	CLRBBSM26A-2B	CHLORIDE	03/08/00	*	*	*	03/18/00	3.4							0.20 mg/L
07373	CLRBBSM26A-2C	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07374	CLRBBSM26A-2D	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07375	CLRBBSM26A-3A	CHLORIDE	03/08/00	*	*	*	03/18/00	33							0.20 mg/L
07376	CLRBBSM26A-3B	CHLORIDE	03/08/00	*	*	*	03/18/00	10							0.20 mg/L
07377	CLRBBSM26A-3C	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07378	CLRBBSM26A-3D	CHLORIDE	03/08/00	*	*	*	03/18/00	<0.20							0.20 mg/L
07379	CLR-H2S04-BLK	CHLORIDE	03/09/00	*	*	*	03/18/00	<0.20							0.20 mg/L

NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable.
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.
 A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE

USX Engineers & Consultants Inc.
 IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 03/22/2000
 PAGE - 2

Customer: Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park Harmarville, PA 15238	CD-0020	ATTENTION: Mr. John Shimshock Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900 CUSTOMER P.O. # : 3629 SITE LOCATION : US STEEL CLAIRTON WORKS
TRACKING NUMBER: 1023		

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
07380	CLR-NAOH-BLK	CHLORIDE	03/09/00	*	*	*	03/18/00	<0.20							0.20 mg/L
															E

ANALYST : Stephanie A. Guilford Date: 3-22-00
 APPROVED: Stephanie A. Guilford Date: 3/23/00
 Stephanie A. Guilford, IHIT, Project Manager
 NOTES: * = Information not supplied by client. # = Information not requested by client. N/A = Not Applicable. A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted. B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

* Please add 25mg Sodium Thiosulfate prior to analysis $\text{Na}_2\text{S}_2\text{O}_3 \cdot 3.5 \text{H}_2\text{O}$

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 02-016-P ; P.O. # 3629		ANALYSES TO BE CONDUCTED										REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Clinton Works		Chloride by ur fluorometry - U.S. EPA Reference Method 200.7											
ANALYTICAL LAB UEC IH and Environmental Laboratories													
DELIVER TO Sample Receiving													
COMMENTS B-Battery Combustion Stack													
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB									
CLR-885-M26A-1A	03-08-00	0805 →	1	Comp.	✓							0.1 N H ₂ SO ₄ - Sample Volume = 478.6 ml	
CLR-885-M26A-1B	↓	1020 EST	1	Comp.	✓							0.1 N H ₂ SO ₄ - Sample Volume = 150.9 ml	
CLR-885-M26A-1C	↓	↓	1	Comp.	✓							0.1 N NaOH - Sample Volume = 148.5 ml	
CLR-885-M26A-1D	↓	↓	1	Comp.	✓							0.1 N NaOH - Sample Volume = 157.2 ml	
CLR-885-M26A-2A	03-08-00	1053 →	1	Comp.	✓							0.1 N H ₂ SO ₄ - Sample Volume = 431.9 ml	
CLR-885-M26A-2B	↓	1309 EST	1	Comp.	✓							0.1 N H ₂ SO ₄ - Sample Volume = 150.9 ml	
CLR-885-M26A-2C	↓	↓	1	Comp.	✓							0.1 N NaOH - Sample Volume = 154.6 ml	
CLR-885-M26A-2D	↓	↓	1	Comp.	✓							0.1 N NaOH - Sample Volume = 166.1 ml	



ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 00-016-P; P.O.# 3629		ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS							
PROJECT NAME U.S. Steel Clanton Works						A: Impinger 1+2							
ANALYTICAL LAB USE ITH and Environmental Laboratories						B: Impinger 3							
DELIVER TO Sample Receiving						C: Impinger 4							
COMMENTS B-Battery Combustion Stack						D: Impinger 5							
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	Chromatography - U.S. EPA Reference Method 204	Chloride by ion							
CLP-BBS-N26A-3A	03-08-00	1350 →	1	Comp.	✓	✓	0.1 N H ₂ SO ₄ - Sample volume = 438.2 mL						
CLP-BBS-N26A-3B	↓	1605 EST	1	Comp.	✓	✓	0.1 N H ₂ SO ₄ - Sample volume = 168.3 mL						
CLP-BBS-N26A-3C	↓	↓	1	Comp.	✓	✓	0.1 N H ₂ SO ₄ - Sample volume = 159.5 mL						
CLP-BBS-N26A-3D	↓	↓	1	Comp.	✓	✓	0.1 N NaOH - Sample volume = 164.4 mL						
CLP-H2SO4-BLK	03-09-00	BLANK	1	Grb	✓	✓	0.1 N H ₂ SO ₄						
CLP-NaOH-BLK	↓	BLANK	1	Grb	✓	✓	0.1 N NaOH						
RELINQUISHED BY (SIGNATURE) DATE TIME RECEIVED BY (SIGNATURE) DATE TIME ICE CHEST #													
John P. Shumaker		03-09-00		1530 EST		John P. Shumaker		3-10-00		9:00 AM			
K. W. G. G.		03-09-00		554 EST								CHEST TEMP.	
												TAG #	

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

B-BATTERY COMBUSTION STACK

MARCH 8, 2000

U.S. EPA REFERENCE METHOD 26A SAMPLING

CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-BBS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	39	478.6	18.67	94.5
	1B	0.1 N H ₂ SO ₄ - Impinger 3	6.8	150.9	1.03	
	1C	0.1 N NaOH - Impinger 4	5.1	148.5	0.76	100.0
	1D	0.1 N NaOH - Impinger 5	< 0.20	157.2	< 0.03	
2	2A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	39	431.9	16.84	97.0
	2B	0.1 N H ₂ SO ₄ - Impinger 3	3.4	150.9	0.51	
	2C	0.1 N NaOH - Impinger 4	< 0.20	154.0	< 0.03	NA
	2D	0.1 N NaOH - Impinger 5	< 0.20	166.1	< 0.03	
3	3A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	33	438.2	14.46	88.4
	3B	0.1 N H ₂ SO ₄ - Impinger 3	10	168.3	1.68	
	3C	0.1 N NaOH - Impinger 4	< 0.20	159.5	< 0.03	NA
	3D	0.1 N NaOH - Impinger 5	< 0.20	164.0	< 0.03	
Blank	Blank	0.1 N H ₂ SO ₄	< 0.20			
Blank	Blank	0.1 N NaOH	< 0.20			

0.1 N H₂SO₄

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (<0.20) ---->

Chloride catch = 0

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE: 3/8/00
TEST NO.: CLR- BBS-M26A-1

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.50
B.	Process Gas Static Pressure (in. H ₂ O)	-1.50
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	156
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H ₂ O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.03
J.	Average ΔP (in. H ₂ O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.03
K.	Average ΔH (in. H ₂ O) variation	0.71
L.	Average Process Gas Temperature (°F)	473
M.	Average Dry Gas Meter Temperature (°F)	84
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	11.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H ₂ O Mass Collected in Impingers (g)	203.3
Q.	Metered Gas Volume (dcf)	57.614

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.39	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.55	[A+(K/13.6)]
T.	Duct Area (ft. ²)	1.33E+02	[Pi*E ² /(4*144) or F*G/144]
U.	Nozzle Area (ft. ²)	1.06E-03	[Pi*H ² /(4*144)]
V.	Average Absolute Process Gas Temperature (R)	933	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	544	[M+460]
X.	Dry Gas Volume Sampled (dscf)	55.359	[Q*D*(528/W)*(S/29.92)]
Y.	H ₂ O Vapor Condensed (scf)	9.586	[P*0.04715]
Z.	Calculated Percent H ₂ O in Gas Stream (%)	14.8	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H ₂ O in Gas Stream (%) (empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H ₂ O in Gas Stream (%)	14.8	[Calculated %H ₂ O <= Theoretical Max. %H ₂ O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H ₂ O/100)	* Mol. Weight	= Wt./Mol
H ₂ O	0.148		18	2.657
CO ₂	0.040	0.852	44	1.500
O ₂	0.110	0.852	32	3.000
N ₂	0.850	0.852	28	20.287
CO	0.000	0.852	28	0.000
H ₂	0.000	0.852	2	0.000
CH ₄	0.000	0.852	16	0.000
C ₂ H ₆	0.000	0.852	30	0.000
Ar	0.000	0.852	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.44	
DD.	Average Process Gas Velocity (ft/sec)	1.42E+01	$[85.49 \cdot C \cdot [(I \cdot V) / (R \cdot CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	1.13E+05	$[DD \cdot T \cdot 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	6.30E+04	$[EE \cdot (528 / V) \cdot (R / 29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.37E+04	$[FF \cdot (1 - (BB / 100))]$
HH.	Isokinetic Variation (%)	107.9	$[100 \cdot V \cdot \{(0.002669 \cdot P) + (Q \cdot D \cdot S / W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0060	
JJ.	Front-Half Residue Weight (g)	0.0129	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0189	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0053	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	2.42E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE:

3/8/00

TEST NO.: CLR-

BBS-M26A-1

Hydrochloric Acid (corrected for blank)

PP. Total Catch (mg)

20.25

QQ. Concentration (mg/dscm)

1.29E+01 [PP/(X*0.02832)]

RR. Mass Flow Rate (lb/hr)

2.60E+00 [QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS. Total Catch (mg)

0.76

TT. Concentration (mg/dscm)

4.83E-01 [SS/(X*0.02832)]

UU. Mass Flow Rate (lb/hr)

9.72E-02 [TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
 TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE: 3/8/00
 TEST NO.: CLR- BBS-M26A-2

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.50
B.	Process Gas Static Pressure (in. H2O)	-1.50
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	156
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.04
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.04
K.	Average ΔH (in. H2O) variation	0.75
L.	Average Process Gas Temperature (°F)	472
M.	Average Dry Gas Meter Temperature (°F)	93
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	3.0
	Oxygen (%)	12.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	193.6
Q.	Metered Gas Volume (dscf)	59.544

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.39	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.56	[A+(K/13.6)]
T.	Duct Area (ft.^2)	1.33E+02	[Pi*E^2/(4*144) or F*G/144]
U.	Nozzle Area (ft.^2)	1.06E-03	[Pi*H^2/(4*144)]
V.	Average Absolute Process Gas Temperature (R)	932	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	553	[M+460]
X.	Dry Gas Volume Sampled (dscf)	56.288	[Q*D*(528/W)*(S/29.92)]
Y.	H2O Vapor Condensed (scf)	9.128	[P*0.04715]
Z.	Calculated Percent H2O in Gas Stream (%)	14.0	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	(empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)		
CC.	Actual Percent H2O in Gas Stream (%)	14.0	[Calculated %H2O <= Theoretical Max. %H2O]
	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.140		18	2.512
CO2	0.030	0.860	44	1.136
O2	0.120	0.860	32	3.304
N2	0.850	0.860	28	20.479
CO	0.000	0.860	28	0.000
H2	0.000	0.860	2	0.000
CH4	0.000	0.860	16	0.000
C2H6	0.000	0.860	30	0.000
Ar	0.000	0.860	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.43	
DD.	Average Process Gas Velocity (ft/sec)	1.44E+01	$[85.49 * C * [(I * V) / (R * CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	1.15E+05	$[DD * T * 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	6.40E+04	$[EE * (528 / V) * (R / 29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.51E+04	$[FF * (1 - (BB / 100))]$
HH.	Isokinetic Variation (%)	107.0	$[100 * V * \{(0.002669 * P) + (Q * D * S / W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0051	
JJ.	Front-Half Residue Weight (g)	0.0204	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0255	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0070	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	3.30E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE:

3/8/00

TEST NO.: CLR-

BBS-M26A-2

Hydrochloric Acid (corrected for blank)

PP. Total Catch (mg)

17.85

QQ. Concentration (mg/dscm)

1.12E+01

[PP/(X*0.02832)]

RR. Mass Flow Rate (lb/hr)

2.31E+00

[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS. Total Catch (mg)

0.03

TT. Concentration (mg/dscm)

1.93E-02

[SS/(X*0.02832)]

UU. Mass Flow Rate (lb/hr)

3.98E-03

[TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: B-BATTERY COMBUSTION STACK

TEST DATE: 3/8/00
TEST NO.: CLR- BBS-M26A-3

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.50
B.	Process Gas Static Pressure (in. H ₂ O)	-1.50
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	156
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H ₂ O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.03
J.	Average ΔP (in. H ₂ O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.03
K.	Average ΔH (in. H ₂ O) variation	0.70
L.	Average Process Gas Temperature (°F)	455
M.	Average Dry Gas Meter Temperature (°F)	94
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	3.0
	Oxygen (%)	12.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H ₂ O Mass Collected in Impingers (g)	172.3
Q.	Metered Gas Volume (dcf)	57.122

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.39	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.55	[A+(K/13.6)]
T.	Duct Area (ft. ²)	1.33E+02	[Pi*E ² /(4*144) or F*G/144]
U.	Nozzle Area (ft. ²)	1.06E-03	[Pi*H ² /(4*144)]
V.	Average Absolute Process Gas Temperature (R)	915	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	554	[M+460]
X.	Dry Gas Volume Sampled (dscf)	53.894	[Q*D*(528/W)*(S/29.92)]
Y.	H ₂ O Vapor Condensed (scf)	8.124	[P*0.04715]
Z.	Calculated Percent H ₂ O in Gas Stream (%)	13.1	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H ₂ O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H ₂ O in Gas Stream (%)	13.1	[Calculated %H ₂ O <= Theoretical Max. %H ₂ O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H ₂ O/100)	* Mol. Weight	= Wt./Mol
H ₂ O	0.131		18	2.358
CO ₂	0.030	0.869	44	1.147
O ₂	0.120	0.869	32	3.337
N ₂	0.850	0.869	28	20.682
CO	0.000	0.869	28	0.000
H ₂	0.000	0.869	2	0.000
CH ₄	0.000	0.869	16	0.000
C ₂ H ₆	0.000	0.869	30	0.000
Ar	0.000	0.869	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.52	
DD.	Average Process Gas Velocity (ft/sec)	1.39E+01	$[85.49 \cdot C \cdot [(I \cdot V) / (R \cdot CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	1.10E+05	$[DD \cdot T \cdot 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	6.26E+04	$[EE \cdot (528 / V) \cdot (R / 29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.44E+04	$[FF \cdot (1 - (BB / 100))]$
HH.	Isokinetic Variation (%)	103.7	$[100 \cdot V \cdot \{(0.002669 \cdot P) + (Q \cdot D \cdot S / W)\}]$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0035	
JJ.	Front-Half Residue Weight (g)	0.0131	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0166	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0047	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	2.22E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 3/8/00

TEST SITE: B-BATTERY COMBUSTION STACK

TEST NO.: CLR- BBS-M26A-3

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	16.60	
QQ.	Concentration (mg/dscm)	1.09E+01	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.22E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.03
TT.	Concentration (mg/dscm)	<	2.09E-02 [SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	4.26E-03 [TT*0.02832*GG*60/454000]