



639 Alpha Drive
Pittsburgh, Pennsylvania 15238
Telephone (412) 967-1900
FAX (412) 967-1911

ADVANCED TECHNOLOGY SYSTEMS, INC.

ATS Project No. 00-030-P

September 13, 2000

Mr. William C. Graeser
Manager – Environmental and Quality Assurance
U.S. Steel Clairton Works
400 State Street
Clairton, PA 15025

**RE: LETTER REPORT – HYDROCHLORIC ACID AND CHLORINE GAS EMISISONS
TESTING CONDUCTED AT NO. 1 BATTERY COMBUSTION STACK ON APRIL
19 AND 20, 2000**

Dear Mr. Graeser:

This letter, with attachments, constitutes the report that summarizes the results of the hydrochloric acid (HCl) and chlorine gas (Cl₂) emissions testing conducted at No. 1 Battery Combustion Stack by Advanced Technology Systems, Inc. (ATS). Three two-hour test runs were conducted on April 19 and 20, 2000 simultaneous with the compliance test program at this stack (particulate matter and visible emissions were measured as part of the compliance test program).

The test results have been summarized in the attached Table 1. Hydrochloric acid and chlorine gas concentrations are listed in units of milligrams per dry standard cubic meter (mg/dscm). Hydrochloric acid and chlorine gas mass emission rates are listed in units of pounds per hour (lb/hr). Table 1 also presents pertinent exhaust gas and sampling parameters including exhaust gas flow rates in units of actual cubic feet per minute (acfm), standard cubic feet per minute (scfm), and dry standard cubic feet per minute (dscfm), exhaust gas temperature (°F), and moisture content of the exhaust gas (percent by volume), gas volume sampled for each test run in units of dry standard cubic feet (dscf) and the isokinetic variation value for each test run. The isokinetic variation value is equal to the ratio of the average linear gas velocity sampled through the probe nozzle to the average exhaust gas velocity. All isokinetic variation values are between 90 percent and 110 percent, which is the acceptable range of values. Actual test sampling times have also been included in Table 1.

Hydrochloric acid and chlorine gas emission testing was performed in accordance with U.S. EPA Reference Methods 1 through 4 and 26A and the requirements of the Pennsylvania Department of Environmental Protection (PA DEP) Source Testing Manual (Draft Revision 3.1, May 3, 1999). Detailed information regarding the procedures used to measure the exhaust gas stream velocity and volumetric flow rate (i.e., U.S. EPA Reference Methods 1 through 4) can be found in the summary report for the compliance test program. Hydrochloric acid and chlorine gas sampling was performed in accordance with U.S. EPA Reference Method 26A. Process gas samples were withdrawn isokinetically from the stack, with particulate matter collected in a glass nozzle, a heated glass-lined

probe, and on a heated quartz filter. Vapor phase hydrochloric acid and chlorine gas were collected in a series of chilled impingers. The impinger type and sequence is listed below:

<u>No.</u>	<u>Impinger Type</u>	<u>Contents</u>
1.	Modified Greenburg-Smith	50 mL 0.1 N sulfuric acid (for HCl collection)
2.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
3.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
4.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
5.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
6.	Modified Greenburg-Smith	200 g Silica Gel

A gas volume greater than 50 dry standard cubic feet (dscf) – the minimum gas volume required by the PA DEP for the compliance test program – was sampled for each test run. The flow rate through each sample train was less than 1 dry standard cubic foot per minute as required by U.S. EPA Reference Method 26A.

Following each test run, the sample trains were processed in accordance with PA DEP requirements. Detailed information regarding the procedures used to recover the particulate matter catch (essentially U.S. EPA Reference Method 5 procedures) can be found in the summary report for the compliance test program. Following the gravimetric analysis of the impingers for moisture gain, the following four samples fractions were generated for each sample train:

Fraction Description

- | | |
|---|--|
| A | Contents of Impinger Nos. 1 & 2 plus applicable distilled deionized water rinses (for HCl) |
| B | Contents of Impinger No. 3 plus applicable distilled deionized water rinses (for HCl) |
| C | Contents of Impinger No. 4 plus applicable distilled deionized water rinses (for Cl ₂) |
| D | Contents of Impinger No. 5 plus applicable distilled deionized water rinses (for Cl ₂) |

For each sample train, each of the four fractions were analyzed separately as required by the PA DEP to allow for the calculation of the collection efficiency of the sample train for HCl and Cl₂ collection. The contents of Impinger No. 6 were discarded.

The actual test samples plus field blanks of the impinger scrubbing solutions (0.1 N sulfuric acid and 0.1 N sodium hydroxide) were submitted to the subcontract analytical laboratory for chloride ion analyses using ion chromatographic techniques in accordance with U.S. EPA Reference Method 26A. The analytical laboratory results showed the following:

- The chloride ion concentrations of the field blanks were less than the analytical detection limit;
- For all three test runs, the HCl collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction B was at most 10 percent of the chloride catch from Sample Fraction A plus Sample Fraction B); and

September 13, 2000

- For all three test runs, the Cl_2 collection efficiency of the sample train could not be calculated since the chloride catch of Sample Fractions C and D were less than the analytical detection limit.

Copies of the field data sheets, equipment calibration data, analytical laboratory results and emissions calculations are included in the appendix.

ATS appreciates the opportunity to provide U.S. Steel with process gas testing services. If you have any questions regarding this letter report, please call Dr. Robinson Khosah or me at (412) 967-1900 or e-mail me at the following address: jshimshock@atsengineers.com.

Very truly yours,



John P. Shimshock, Ph.D.
Senior Project Scientist

Approved by:



Robinson P. Khosah, Ph.D.
Vice President
Science and Technology Division

JPS/blc
Enclosures

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

TABLE 1

**NO. 1 BATTERY COMBUSTION STACK
HYDROCHLORIC ACID AND CHLORINE GAS EMISSIONS DATA
APRIL 19 AND 20, 2000**

Test Date		<u>Run 1</u> 4/19/00	<u>Run 2</u> 4/19/00	<u>Run 3</u> 4/20/00	<u>Average</u>
<u>Emissions Data</u>					
Hydrochloric Acid (HCl)					
Concentration	(mg/dscm)	6.60E+00	6.76E+00	6.51E+00	6.62E+00
Mass Emission Rate	(lb/hr)	8.85E-01	8.54E-01	7.64E-01	8.34E-01
Chlorine Gas (Cl ₂)					
Concentration	(mg/dscm)	< 1.49E-01	< 1.48E-01	< 1.77E-01	< 1.58E-01
Mass Emission Rate	(lb/hr)	< 2.00E-02	< 1.87E-02	< 2.07E-02	< 1.98E-02
<u>Exhaust Stack Conditions</u>					
Volumetric Flow Rate	(acfm)	7.78E+04	7.33E+04	6.87E+04	7.33E+04
	(scfm)	4.14E+04	3.90E+04	3.65E+04	3.90E+04
	(dscfm)	3.58E+04	3.38E+04	3.14E+04	3.37E+04
Temperature	(°F)	516	516	513	515
Moisture Content	(%)	13.4	13.4	14.1	13.6
<u>Sampling Conditions</u>					
Test Times +	(EDT)	0810 to 0912 & 1117 to 1220	1510 to 1718	1055 to 1308	
Sampling Time *	(minutes)	120	120	120	
Sample Volume **	(dscf)	65.979	63.092	58.614	
Isokinetic Variation ***	(%)	103.0	104.5	104.6	

mg / dscm = milligrams per dry standard cubic meter

+ : Battery heat delay from 0912 to 1030 EDT

* : Minimum required sampling time is 2 hours (120 minutes)

** : Minimum required sample volume is 50 dscf

*** : Acceptable range of values is 90.0% <= Isokinetic Variation <= 110.0%

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

**Hydrochloric Acid and Chlorine Gas
Emissions Testing Conducted at
No. 1 Battery Combustion Stack
on April 19 and 20, 2000**

September 2000

APPENDIX

**Field Data Sheets, Equipment Calibration Data,
Analytical Laboratory Results and Emissions
Calculations**



ADVANCED TECHNOLOGY SYSTEMS, INC.

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST DATE: April 19, 2000
 TEST NO.: 29,51
 B.P. (in. Hg): 29.51
 STATIC P. (in. H2O): -1.0
 STACK DIA. (in.): 114
 PORT SIZE & TYPE: 4" Flanges
 PITOT COEF.: 0.84
 U.S. Steel Clairton Works
 No. 1 Battery Combustion Stack
 TEST UNIT: JS, KA
 TEST CREW: JS, KA
 PROJECT NO.: 00-030-P
 CONTROL BOX NO.: APEX-1
 ORIFICE FACTOR (AH@): 1.911
 METER CORR. (Y): 0.9851
 CALIBRATION DATE: 9-20-99
 HOT/COLD BOX NO.: 5
 FILTER NO.: 480 Q7Z
 PROBE NO.: 7-1
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH Required (in. H2O)	Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F)	Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
1	40.6	0810	688.863	0.07	1.30	1.30	8.0	248	502	59	57	245	60	5 min./pt.
	28.5			0.07	1.30	1.30	8.0	248	509	62	58	245	50	
	20.2			0.07	1.28	1.28	6.0	248	519	67	59	245	50	
	13.5			0.06	1.09	1.09	4.0	248	529	68	60	245	51	
	7.6			0.04	0.72	0.72	2.0	247	517	70	60	245	48	
	2.4	0840	706.567	0.03	0.54	0.54	2.0	247	505	72	61	245	48	
2	40.6	0842	706.567	0.08	1.47	1.47	7.0	247	513	68	61	245	48	
	28.5			0.07	1.24	1.24	6.0	247	557	75	62	245	49	
	20.2			0.07	1.23	1.23	6.0	247	569	78	63	245	49	
	13.5			0.06	1.05	1.05	5.0	247	489	79	64	244	48	
	7.6			0.03	0.53	0.53	2.0	247	480	78	64	245	49	
	2.4	0912	724.682	0.03	0.53	0.53	2.0	247	482	78	64	245	49	
Page 1	Δ = 60	min	Δ = 35.819	(ΔP) avg = 0.055	(ΔH) avg =	0.99			(Tstack) avg = 514	(Tmeter) avg = 66				Estimates:
Totals	min	def	def	(ΔP) avg = 0.055	(ΔH) avg =	0.99			(Tstack) avg = 516	(Tmeter) avg = 69				MW = 27.6
Test	Δ = 120	min	Δ = 67.869	(ΔP) avg = 0.054	(ΔH) avg =	0.99								%H2O = 13
Totals	min	def	def											

Dry Gas Composition
 Run 1: 4.4% CO2, 12.4% CO, 84.4% N2
 Run 2: 4.4% CO2, 12.4% CO, 84.4% N2
 System Leak Check (60 sec): Vacuum 5.0, DGM Rate 0.008, Required < 0.02
 After: Vacuum 8.0, DGM Rate 0.009, Required < 0.02
 Pilot Leak Check (15 sec): Positive OK, Negative OK
 Before: OK, After: OK

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	634.1	525.5	117.6
2.	100 mL 0.1 N H2SO4	644.8	545.3	69.5
3.	100 mL 0.1 N H2SO4	674.2	563.5	110.7
4.	100 mL 0.1 N NaOH	541.7	539.4	2.3
5.	100 mL 0.1 N NaOH	534.5	548.5	2.0
6.	~200 g Silica Gel	664.5	649.2	15.3
7.			Total =	217.4g
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST DATE: April 19th, 2000
 CONTROL BOX NO.: APEX-1
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS KA
 PROJECT NO.: 00-030-P
 TEST NO.: CLR-#1BS-M26A-1
 B.P. (in. Hg): 29.51
 STATIC P. (in. H2O): -1.4
 STACK DIA. (in.): 114
 ORIFICE FACTOR (ΔH): 1.911
 METER CORR. (Y): 0.9851
 CALIBRATION DATE: 9-20-99
 PORT SIZE & TYPE: 4" Flanges PITOT COEF. 0.84
 FILTER NO.: 480 Q17
 PROBE NO.: 7-1
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH Required (in. H2O)	Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F)	Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
C	40.6	1117	724.682	0.06	1.10	1.10	5.00	249	513	66	64	245	50	5 min./pt.
	28.5			0.06	1.10	1.10	5.0	249	519	69	65	245	49	
	20.2			0.06	1.10	1.10	5.0	248	506	69	64	245	49	
	13.5			0.07	1.29	1.29	6.0	248	518	71	65	245	49	
	7.6			0.05	0.92	0.92	4.0	248	539	76	65	245	49	
	2.4	1147	740.606	0.04	0.74	0.74	3.0	248	500	78	66	245	49	
D	40.6	1150	740.606	0.08	1.47	1.47	6.0	248	551	77	67	245	49	
	28.5			0.08	1.47	1.47	6.0	248	577	79	67	245	50	
	20.2			0.05	0.92	0.92	5.0	247	501	80	68	245	50	
	13.5			0.03	0.56	0.56	2.0	248	498	81	68	245	49	
	7.6			0.03	0.56	0.56	2.0	248	494	81	68	244	52	
	2.4	1220	756.732	0.03	0.56	0.56	2.0	248	496	81	68	244	52	
Page 2	$\Delta = 60$	$\Delta = 32.050$	ΔP avg =	ΔH avg =	ΔH avg =	ΔH avg =			(Tstack) avg =		(Tmeter) avg =			Estimates:
Totals	min	def		0.052					517		71			MW =
														%H2O =

Dry Gas Composition

Run 1	Run 2
C02 4%	
O2 13%	
CO 1%	
N2 84%	

System Leak Check (60 sec)

Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before		<0.02
After		<0.02

Pitot Leak Check (15 sec)

Positive	Negative
Before	
After	

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~200 g Silica Gel			
7.				
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS, KA
 PROJECT NO.: 00-030-P
 TEST DATE: April 19, 2000
 TEST NO.: 1911
 B.P. (in. Hg): 29.51
 STATIC P. (in. H2O): -1.1
 STACK DIA. (in.): 114
 CONTROL BOX NO.: APEX-1
 CLORIFICE FACTOR (ΔH@): 1.911
 METER CORR. (%): 0.9851
 CALIBRATION DATE: 9-20-00
 PORT SIZE & TYPE: 4" Flanges
 PITOT COEF.: 0.84
 HOT/COLD BOX NO.: 481 Q1Z
 FILTER NO.: 7-1
 PROBE NO.: 0.440
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
AD	40.6	1510	757-105	0.05	0.94	0.94	243	500	71	69	248	60
	28.5			0.05	0.94	0.94	243	507	72	69	248	59
	20.2			0.04	0.74	0.74	243	513	75	70	248	59
	13.5			0.035	0.65	0.65	242	520	78	70	248	59
	7.6			0.04	0.74	0.74	242	526	80	70	246	53
	2.4	1540	772-258	0.035	0.65	0.65	242	522	82	71	247	51
PC	40.6	1542	772-258	0.08	1.50	1.50	243	534	81	72	246	50
	28.5			0.08	1.50	1.50	243	561	84	72	246	50
	20.2			0.07	1.27	1.27	244	570	85	73	246	50
	13.5			0.05	0.91	0.91	244	496	85	73	246	49
	7.6			0.04	0.72	0.72	245	489	86	73	245	49
	2.4	1612	790-867	0.03	0.54	0.54	244	490	86	73	245	49
Page 1	Δ = 60	Δ = 33.762		(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			
Totals	min	dcf		0.049	0.90			519 (°F)	76 (°F)			Estimates:
Test	Δ = 120	Δ = 66.020		(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			MW = 27.6
Totals	min	dcf		0.048	0.886			516 (°F)	78 (°F)			%H2O = 13

Dry Gas Composition

Run 1	Run 2
CO2 4.10	
O2 12.51	
CO -	
N2 83.51	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DCM Rate (cfm)	Required (cfm)
Before	5.00	0.009	< 0.02
After	1.00	0.010	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	622.75	543.6	119.1
2.	100 mL 0.1 N H2SO4	634.1	568.4	65.7
3.	100 mL 0.1 N H2SO4	522.9	522.3	0.6
4.	100 mL 0.1 N NaOH	517.7	519.3	-1.6
5.	100 mL 0.1 N NaOH	561.4	532.9	28.5
6.	~200 g Silica Gel	679.5	664.1	15.4
7.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST UNIT No. 1 Battery Combustion Stack
 TEST CREW JS, KA
 PROJECT NO. 00-030-P
 TEST DATE April 20th, 2000
 TEST NO. 29.35
 B.P. (in. Hg) 29.35
 STATIC P. (in. H2O) -1.1
 CONTROL BOX NO. APEX-1
 ORIFICE FACTOR ($\Delta H @$) 1.911
 METER CORR. (V) 0.9851
 CALIBRATION DATE 9-20-99
 PORT SIZE & TYPE 4" Flanges PITOT COEF. 0.84
 HOT/COLD BOX NO. 8
 FILTER NO. 466 Q72
 PROBE NO. 7-1
 NOZZLE DIA. (in.) 0.440

PROJECT NO. 00 - 030 - P			STACK DIA. (in.)			PORT SIZE & TYPE			4" Flanges			PITOT COEF.			0.84		
Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcf)	Pitot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments			
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)						
A	40.6	1055	823.543	0.06	1.07	1.07	5.0	235	562	71	71	250	59	5 min./pt.			
	28.5			0.05	0.89	0.89	4.0	245	494	74	71	250	59				
	20.2			0.05	0.89	0.89	4.0	245	491	77	73	246	56				
	13.5			0.03	0.57	0.57	2.0	245	500	81	72	246	56				
	7.6			0.03	0.57	0.57	2.0	245	504	83	72	246	54				
	2.4	1125	838.352	0.03	0.57	0.57	2.0	245	506	84	73	246	54				
B	40.6	1130	838.352	0.06	1.14	1.14	5.0	247	498	82	74	246	54				
	28.5			0.06	1.14	1.14	5.0	247	525	86	75	246	54				
	20.2			0.04	0.75	0.75	4.0	247	527	88	75	246	54				
	13.5			0.04	0.75	0.75	4.0	246	538	88	76	247	54				
	7.6			0.03	0.55	0.55	2.0	245	542	89	76	247	55				
	2.4	1200	853.857	0.03	0.55	0.55	2.0	245	480	89	76	247	55				
Page 1	Δ = 60	min	Δ = 30.314	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =		(Tmeter) avg =						
Totals		min	dcf	0.042	0.771				514 (°F)		78 (°F)			Estimates:			
Test	Δ = 120	min	Δ = 62.141	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =		(Tmeter) avg =			MW =		27.6	
Totals		min	dcf	0.042	0.785				513 (°F)		82 (°F)			%H2O =		13	

Dry Gas Composition

Run 1	Run 2
CO2 4.6	
O2 12.5	
CO 1.5	
N2 83.5	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.006	< 0.02
After	5.00	0.004	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	614.4	468.5	145.5
2.	100 mL 0.1 N H2SO4	525.9	486.8	39.1
3.	100 mL 0.1 N H2SO4	584.5	583.7	0.8
4.	100 mL 0.1 N NaOH	553.4	554.7	2.3
5.	100 mL 0.1 N NaOH	533.1	531.4	1.7
6.	~200 g Silica Gel	632.6	608.5	14.1
7.				
8.				total = 243.50

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT U.S. Steel Clairton Works

TEST DATE April 20, 2000

CONTROL BOX NO.

APEX-1

HOT/COLD BOX NO. 8

PLANT SITE Clairton, PA

TEST NO.

CLR - #1BS - M26A - 3

ORIFICE FACTOR (ΔH@) 1.911

FILTER NO.

466 QIZ

TEST UNIT No. 1 Battery Combustion Stack

B.P. (in. Hg)

29.35

METER CORR. (V)

0.9851

PROBE NO. 7.1

TEST CREW JS, KA

STATIC P. (in. H2O)

-1.1

CALIBRATION DATE

9-20-99

NOZZLE DIA. (in.)

0.440

PROJECT NO. 00-030-P

STACK DIA. (in.)

114

PORT SIZE & TYPE

4" Flanges

PITOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcf)	Pitot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
C	40.6	1204	853.857	0.05	0.96	0.96	4.0	246	500	84	77	247	55	5 min./pt.
	28.5			0.04	0.77	0.77	3.0	246	495	87	77	247	56	
	20.2			0.04	0.77	0.77	3.0	247	504	91	78	246	56	
	13.5			0.04	0.76	0.76	3.0	247	509	92	79	246	56	
	7.6			0.03	0.59	0.59	2.0	246	493	93	80	246	56	
	2.4	1234	869.550	0.03	0.59	0.59	2.0	246	490	92	80	247	57	
D	40.6	1238	869.550	0.06	1.15	1.15	5.0	246	507	86	81	247	57	
	28.5			0.06	1.15	1.15	5.0	246	544	92	81	248	57	
	20.2			0.05	0.92	0.92	4.0	247	548	94	82	248	56	
	13.5			0.05	0.92	0.92	4.0	246	555	95	82	246	57	
	7.6			0.03	0.58	0.58	2.0	247	501	95	83	246	57	
	2.4	1308	885.684	0.03	0.58	0.58	2.0	247	498	95	83	246	56	
Page 2 Δ = 60 Δ = 31.827				(ΔP) avg =	(ΔH) avg =				(Tstack) avg =		(Tmeter) avg =		Estimates:	
Totals				min	dcf				512 (°F)		86 (°F)		MW =	27.6
													%H2O =	13

Dry Gas Composition

Run 1 Run 2

CO2	4%
O2	12.5%
CO	
N2	83.5%

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before			< 0.02
After			< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before		
After		

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~200 g Silica Gel			
7.				
8.				

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:

03/06/00

Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
1	0.125		0.125	0.125	0.125	KA	03-12-96
2	0.156		0.156	0.156	0.156	KA	03-12-96
3	0.156		0.156	0.156	0.156	KA	09-04-96
44	0.156		0.156	0.156	0.156	KA	09-04-96
11	0.180		0.180	0.180	0.180	KA	07-20-98
5	0.190		0.190	0.190	0.190	KA	02/18/00
27	0.190		0.190	0.190	0.190	KA	05-19-99
28	0.190		0.190	0.190	0.190	KA	05-19-99
29	0.190		0.190	0.190	0.190	KA	01/05/00
31	0.190		0.190	0.190	0.190	KA	05-19-99
4	0.219		0.219	0.219	0.219	KA	10-20-98
6	0.219		0.219	0.219	0.219	KA	03-12-97
7	0.219		0.219	0.219	0.219	KA	03-12-97
15	0.219		0.219	0.219	0.219	KA	05-19-99
42	0.219		0.219	0.219	0.219	KA	01/05/00
40	0.220		0.220	0.220	0.220	KA	05-19-99
10	0.225		0.225	0.225	0.225	KA	05-19-99
8	0.240		0.240	0.240	0.240	KA	01/05/00
9	0.240		0.240	0.240	0.240	KA	01/05/00
41	0.240		0.240	0.240	0.240	KA	01/05/00
50	0.260		0.260	0.260	0.260	KA	05-19-99
51	0.260		0.260	0.260	0.260	KA	01/05/00
12	0.281		0.281	0.281	0.280	KA	07-18-97
13	0.281		0.281	0.281	0.281	KA	10-20-98
14	0.281		0.281	0.280	0.281	KA	03-12-97
16	0.290		0.290	0.290	0.290	KA	07-24-96
17	0.290		0.290	0.290	0.290	KA	03-10-98
18	0.290		0.290	0.290	0.290	KA	07-05-96
45	0.290		0.290	0.290	0.290	KA	01/05/00
20	0.310		0.310	0.310	0.310	KA	03-10-98
33	0.310		0.310	0.310	0.310	KA	04-14-98
35	0.320		0.320	0.320	0.320	KA	01/05/00
21	0.344		0.344	0.344	0.344	KA	03-10-98
22	0.344		0.344	0.344	0.344	KA	03/06/00
23	0.347		0.347	0.347	0.347	KA	03-10-98
24	0.375		0.375	0.375	0.375	KA	02/18/00
25	0.375		0.375	0.375	0.375	KA	03-12-96
26	0.406		0.406	0.406	0.406	KA	04-19-96
30	0.406		0.406	0.406	0.406	KA	07-20-98
47	0.415		0.415	0.415	0.415	KA	11-25-96
34	0.425		0.425	0.425	0.424	KA	06-10-97
55	0.425		0.425	0.425	0.424	KA	01/05/00
52	0.440		0.440	0.440	0.440	KA	02/27/00

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:

03/06/00


Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
53	0.440		0.440	0.440	0.440	KA	02/27/00
19	0.450		0.450	0.450	0.450	KA	04-14-98
36	0.490		0.490	0.490	0.490	KA	06-10-97
37	0.490		0.490	0.490	0.490	KA	07-05-96
38	0.495		0.495	0.495	0.495	KA	07-05-96
39	0.500		0.500	0.500	0.500	KA	07-05-96
46	0.625		0.625	0.625	0.625	KA	03-10-98
43	0.750		0.750	0.750	0.750	KA	01/05/00
49	1.060		1.060	1.060	1.060	KA	11-25-96

GEOMETRIC PITOT CALIBRATION

Caliper # FS-59
 Preset ✓
 Post Check _____

Probe # 7-1
 Date 01-10-100
 Initials KDA


①



$$\begin{aligned} \alpha^1 &= 2^\circ \\ \alpha^2 &= 1^\circ \\ \beta^1 &= 1^\circ \\ \beta^2 &= 1^\circ \end{aligned} \quad \begin{aligned} \alpha^1, \alpha^2 &= < 10^\circ \\ \beta^1, \beta^2 &= < 5^\circ \end{aligned}$$

$$F = 1.000''$$


②



$$\begin{aligned} \mu &= 0.017'' \\ V &= 0.017'' \\ W &= 0.480'' \end{aligned} \quad \begin{aligned} \mu &\leq 0.1250'' (\delta \tan \times F) \\ V &\leq 0.03125'' (\Theta \tan \times F) \\ W &\geq 0'' \end{aligned}$$


$$X = 0.910'' \quad \begin{aligned} X &\geq 0.750'' \\ &(3/4'' \text{ using } 1/2'' \text{ scale}) \end{aligned}$$

③




$$\begin{aligned} Y &= 6.211'' \\ Z &= 2.495'' \\ D_1 &= 0.376'' \end{aligned} \quad \begin{aligned} Y &\geq 3.0'' \\ Z &\geq 2.0'' \\ D_1 &\geq .1875'' \end{aligned}$$

④




(δ, θ EXPRESSED IN DEGREES)


⑤



⑥



⑦



CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN WET TEST gas meter,

serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 16 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date

Mark Poe

Signature

CERTIFICATE OF CALIBRATION

This certifies that your AL-ZO AMERICAN Wet Test gas meter,

serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 16 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date

Mark Poe

Signature

CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN Wet Test gas meter,
serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 16 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

_____	_____
_____	_____
_____	_____

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date

Mark Poe

Signature

CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN Wet Test gas meter,

serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 16 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date

Mark Poe

Signature

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

APK-1
29-24-99
29.10

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
TPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	5.000	0		51.245			1.0	8.0
	MIDWAY			71		94	81		
	STOP	5.000	9.49		56.283				
	DELTA *	5.000	9.15		5.238				
2	START	5.000	0		57.334			2.0	8.0
	MIDWAY			71		97	81		
	STOP	5.000	6.31		62.546				
	DELTA *	5.000	6.52		5.216				
3	START	5.000	0		63.598			3.0	8.0
	MIDWAY			71		104	81		
	STOP	5.000	5.17		68.848				
	DELTA *	5.000	5.28		5.210				
Dry Gas	START	0.150	0		68.995			0.0	1.0
Meter Leak	STOP	0.343	10:00		69.291				
Check	DELTA *	0.193	10.0		0.296				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0103</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):

☒ Inclined Manometers

☐ Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.15	6.52	5.28	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	94	97	100	
To (°F)	81	81	81	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.238	5.216	5.210	
ΔH@ (in. H2O)	1.901	1.931	1.899	1.911
Y (Pre-test)	0.9817	0.9861	0.9875	0.9851

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

APC-1
09-24-99
29.10

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
TPD

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		051.045			1.0	8.0
	MIDWAY			71		94	81		
	STOP	5.000	9.49		050.283				
	DELTA *	5.000	9.15		5.238				
2	START	0.000	0		057.330			2.0	8.0
	MIDWAY			71		97	81		
	STOP	5.000	6.31		062.546				
	DELTA *	5.000	6.52		5.216				
3	START	0.000	0		063.598			3.0	8.0
	MIDWAY			71		100	81		
	STOP	5.000	5.17		068.848				
	DELTA *	5.000	5.28		5.210				
Dry Gas	START	0.150	0		068.995			0.0	1.0
Meter Leak	STOP	0.343	10:00		069.291				
Check	DELTA *	0.193	10.0		0.296				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0103</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):

☒ Inclined Manometers

☐ Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.15	6.52	5.28	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	94	97	100	
To (°F)	81	81	81	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.238	5.216	5.210	
ΔH@ (in. H2O)	1.901	1.931	1.899	1.911
Y (Pre-test)	0.9817	0.9861	0.9875	0.9851

$$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^2$$

$$BP * (To + 460) * (Vw)^2$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

$$Vm * [BP+(\Delta H/13.6)] * (Tw+460)$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

APC-1
09-24-99
29.10


CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
TPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		51.045			1.0	8.0
	MIDWAY			71		94	81		
	STOP	5.000	9.49		56.283				
	DELTA *	5.000	9.15		5.238				
2	START	0.000	0		57.330			2.0	8.0
	MIDWAY			71		97	81		
	STOP	5.000	6.31		62.546				
	DELTA *	5.000	6.52		5.216				
3	START	0.000	0		63.590			3.0	8.0
	MIDWAY			71		100	81		
	STOP	5.000	5.17		68.848				
	DELTA *	5.000	5.28		5.210				
Dry Gas	START	0.150	0		68.975			0.0	1.0
Meter Leak	STOP	0.343	10:00		69.291				
Check	DELTA *	0.193	10.0		0.296				
$\{ \text{DELTA Vw (cf)} - \text{DELTA Vd (dcf)} \} / 10 \text{ (min.)} = 0.00103 \text{ cfm} \leq 0.02 \text{ cfm}$									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.15	6.52	5.28	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	94	97	100	
To (°F)	81	81	81	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.238	5.216	5.210	
ΔH@ (in. H2O)	1.901	1.931	1.899	1.911
Y (Pre-test)	0.9817	0.9861	0.9875	0.9851

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex - 1
09-24-99
29.10

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
TPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		0.045			1.7	8.0
	MIDWAY			71		94	81		
	STOP	5.000	9.49		0.283				
	DELTA *	5.000	9.15		5.238				
2	START	0.000	0		0.330			2.0	8.0
	MIDWAY			71		97	81		
	STOP	5.000	6.31		0.546				
	DELTA *	5.000	6.52		5.216				
3	START	0.000	0		0.598			3.0	8.0
	MIDWAY			71		100	81		
	STOP	5.000	5.17		0.848				
	DELTA *	5.000	5.28		5.210				
Dry Gas	START	0.150	0		0.995			0.0	1.0
Meter Leak	STOP	0.343	10:00		0.291				
Check	DELTA *	0.193	10.0		0.296				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0103</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):

✓

Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.15	6.52	5.28	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	94	97	100	
To (°F)	81	81	81	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.238	5.216	5.210	
ΔH@ (in. H2O)	1.901	1.931	1.899	1.911
Y (Pre-test)	0.9817	0.9861	0.9875	0.9851

$$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^2$$

$$BP * (To + 460) * (Vw)^2$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex - 1
05-18-08
29.03

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

1
35

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	6.000	0		078.370			2.4	8
	MIDWAY			75		102	83		
	STOP	6.000	7.42		084.592				
	DELTA *	6.000	7.70		6.292				
2	START	5.000	0		084.592			2.4	8
	MIDWAY			75		102	84		
	STOP	5.000	6:25		089.787				
	DELTA *	5.000	6.42		5.195				
3	START	5.000	0		089.787			2.4	8
	MIDWAY			75		103	84		
	STOP	5.000	6:25		094.974				
	DELTA *	5.000	6.42		5.187				
Dry Gas	START	0.350	0		095.357			0.0	8
Meter Leak	STOP	6.574	10:00		095.604				
Check	DELTA *	6.164	10.0		0.247				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.408</u> cfm <= 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.03	29.03	29.03	
Time (min)	7.70	6.42	6.42	
Tw (°F)	75	75	75	
Vw (cf)	6.000	5.000	5.000	
Ti (°F)	102	102	103	
To (°F)	83	84	84	
ΔH (in. H2O)	2.00	2.00	2.00	
Vm (dcf)	6.292	5.195	5.187	
Y (Pre-test)				0.9851
ΔH@ (in. H2O)	1.896	1.894	1.894	1.895
Y (Post-test)	0.9798	0.9898	0.9923	0.9873
ΔY (%)				0.2%

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex - 1
05-12-08
29.03

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

35

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	6.000	0		078.370			2.4	8
	MIDWAY			75		102	83		
	STOP	6.000	7.142		084.592				
	DELTA *	6.000	7.70		6.292				
2	START	5.000	0		084.592			2.4	8
	MIDWAY			75		102	84		
	STOP	5.000	6:25		089.787				
	DELTA *	5.000	6.42		5.195				
3	START	5.000	0		089.787			2.4	8
	MIDWAY			75		103	84		
	STOP	5.000	6:25		094.974				
	DELTA *	5.000	6.42		5.187				
Dry Gas	START	0.350	0		095.357			0.0	8
Meter Leak	STOP	0.574	10:00		095.604				
Check	DELTA *	0.164	10.0		0.247				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.408</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.	
BP (in. Hg)	29.03	29.03	29.03		$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$
Time (min)	7.70	6.42	6.42		
Tw (°F)	75	75	75		$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$
Vw (cf)	6.000	5.000	5.000		
Ti (°F)	102	102	103		0.9851
To (°F)	83	84	84		
ΔH (in. H2O)	2.00	2.00	2.00		
Vm (dcf)	6.292	5.195	5.187		
Y (Pre-test)					
ΔH@ (in. H2O)	1.896	1.894	1.894	1.895	
Y (Post-test)	0.9798	0.9898	0.9923	0.9873	
ΔY (%)				0.2%	

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex - 1
05-2-00
29.03

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

35

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		078.370			2.4	8
	MIDWAY			75		102	83		
	STOP	6.000	7.42		084.592				
	DELTA *	6.000	7.70		6.292				
2	START	0.000	0		084.592			2.4	8
	MIDWAY			75		102	84		
	STOP	5.000	6:25		089.787				
	DELTA *	5.000	6.42		5.195				
3	START	0.000	0		089.787			2.4	8
	MIDWAY			75		103	84		
	STOP	5.000	6:25		094.974				
	DELTA *	5.000	6.42		5.187				
Dry Gas	START	0.350	0		095.357			0.0	8
Meter Leak	STOP	0.574	10:00		095.604				
Check	DELTA *	0.164	10.0		0.247				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.408</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.03	29.03	29.03	
Time (min)	7.70	6.42	6.42	
Tw (°F)	75	75	75	
Vw (cf)	6.000	5.000	5.000	
Ti (°F)	102	102	103	
To (°F)	83	84	84	
ΔH (in. H2O)	2.00	2.00	2.00	
Vm (dcf)	6.292	5.195	5.187	
Y (Pre-test)				0.9851
ΔH@ (in. H2O)	1.896	1.894	1.894	1.895
Y (Post-test)	0.9798	0.9898	0.9923	0.9873
ΔY (%)				0.2%

$$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^2$$

$$BP * (To + 460) * (Vw)^2$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex - 1
05-12-08
29.03

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

35

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	6.000	0		078.370			2.4	8
	MIDWAY			75		102	83		
	STOP	6.000	7.42		084.592				
	DELTA *	6.000	7.70		6.292				
2	START	5.000	0		084.592			2.4	8
	MIDWAY			75		102	84		
	STOP	5.000	6.25		089.787				
	DELTA *	5.000	6.42		5.195				
3	START	5.000	0		089.787			2.4	8
	MIDWAY			75		103	84		
	STOP	5.000	6.25		094.974				
	DELTA *	5.000	6.42		5.187				
Dry Gas	START	0.350	0		095.357			0.0	8
Meter Leak	STOP	0.574	10:00		095.604				
Check	DELTA *	0.164	10.0		0.247				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.408</u> cfm <= 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

☐ Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.03	29.03	29.03	
Time (min)	7.70	6.42	6.42	
Tw (°F)	75	75	75	
Vw (cf)	6.000	5.000	5.000	
Ti (°F)	102	102	103	
To (°F)	83	84	84	
ΔH (in. H2O)	2.00	2.00	2.00	
Vm (dcf)	6.292	5.195	5.187	
Y (Pre-test)				0.9851
ΔH@ (in. H2O)	1.896	1.894	1.894	1.895
Y (Post-test)	0.9798	0.9898	0.9923	0.9873
ΔY (%)				0.2%

$$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

RECEIVED MAY 10 2000



UEC

USX Engineers
& Consultants, Inc.

May 3, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on April 25, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

ANALYTE	METHOD
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Guilyard

Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

RECEIVED MAY 10 2000



UEC

USX Engineers
& Consultants, Inc.

May 3, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on April 25, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

ANALYTE	METHOD
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Gullyard

Stephanie A. Gullyard, IHIT, Project Manager

Enclosures

RECEIVED MAY 10 2000



UEC

USX Engineers
& Consultants, Inc.

May 3, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on April 25, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

<u>ANALYTE</u>	<u>METHOD</u>
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Guilyard

Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

RECEIVED MAY 10 2000



UEC

USX Engineers
& Consultants, Inc.

May 3, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on April 25, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

ANALYTE	METHOD
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Guilyard

Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 1

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13753	CLR-#IBS-M26A-1A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13754	CLR-#IBS-M26A-1B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13755	CLR-#IBS-M26A-1C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13756	CLR-#IBS-M26A-1D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13757	CLR-#IBS-M26A-2A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13758	CLR-#IBS-M26A-2B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13759	CLR-#IBS-M26A-2C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13760	CLR-#IBS-M26A-2D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13761	CLR-#IBS-M26A-3A	CHLORIDE	04/20/00	*	*	*	05/02/00	26							2.0 mg/L
13762	CLR-#IBS-M26A-3B	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13763	CLR-#IBS-M26A-3C	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13764	CLR-#IBS-M26A-3D	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13765	CLR-H2S04-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable. B - TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.
 A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 D - BULK MATERIALS OR WIPES I - FILTER + TUBE

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

DEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPH)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13753	CLR-#1BS-M26A-1A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13754	CLR-#1BS-M26A-1B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13755	CLR-#1BS-M26A-1C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13756	CLR-#1BS-M26A-1D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13757	CLR-#1BS-M26A-2A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13758	CLR-#1BS-M26A-2B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13759	CLR-#1BS-M26A-2C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13760	CLR-#1BS-M26A-2D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13761	CLR-#1BS-M26A-3A	CHLORIDE	04/20/00	*	*	*	05/02/00	26							2.0 mg/L
13762	CLR-#1BS-M26A-3B	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13763	CLR-#1BS-M26A-3C	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13764	CLR-#1BS-M26A-3D	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13765	CLR-H2S04-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

NOTES: * = Information not supplied by client. < = less than. A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 # = Information not requested by client. N/A = Not Applicable. B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

USX Engineers & Consultants Inc.

JH & Environmental Laboratories
4000 Tech Center Drive
Monroeville, PA 15146
PHONE: (412)825-2400 FAX: (412)825-2407
AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 05/03/2000
PAGE - 1

Customer:	CD-0020	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13753	CLR-#1BS-M26A-1A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13754	CLR-#1BS-M26A-1B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13755	CLR-#1BS-M26A-1C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13756	CLR-#1BS-M26A-1D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13757	CLR-#1BS-M26A-2A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13758	CLR-#1BS-M26A-2B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13759	CLR-#1BS-M26A-2C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13760	CLR-#1BS-M26A-2D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13761	CLR-#1BS-M26A-3A	CHLORIDE	04/20/00	*	*	*	05/02/00	26							2.0 mg/L
13762	CLR-#1BS-M26A-3B	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13763	CLR-#1BS-M26A-3C	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13764	CLR-#1BS-M26A-3D	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13765	CLR-H2S04-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

NOTES: * = Information not supplied by client. < = less than. A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
= Information not requested by client. N/A = Not Applicable. B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE
Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 1

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RIOC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	ATR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13753	CLR-#1BS-M26A-1A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13754	CLR-#1BS-M26A-1B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13755	CLR-#1BS-M26A-1C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13756	CLR-#1BS-M26A-1D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13757	CLR-#1BS-M26A-2A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13758	CLR-#1BS-M26A-2B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13759	CLR-#1BS-M26A-2C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13760	CLR-#1BS-M26A-2D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13761	CLR-#1BS-M26A-3A	CHLORIDE	04/20/00	*	*	*	05/02/00	26							2.0 mg/L
13762	CLR-#1BS-M26A-3B	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13763	CLR-#1BS-M26A-3C	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13764	CLR-#1BS-M26A-3D	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13765	CLR-H2S04-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

NOTES: * = Information not supplied by client. < = less than. A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 # = Information not requested by client. N/A = Not Applicable. B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

USX Engineers & Consultants Inc.

IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 2

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

DEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	L00
13766	CLR-NAOH-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
															E

COMMENTS: SAMPLES ARE BLANK CORRECTED.

ANALYST : Neelam Patel Date: 5-3-00
 APPROVED: Stephanie A. Guilford Date: 5/5/00

NOTES: * = Information not requested by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable.
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE

USX Engineers & Consultants Inc.

IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 ALPHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 2

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13766	CLR-NAOH-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
															E

COMMENTS: SAMPLES ARE BLANK CORRECTED.

ANALYST : Neelam Patel Date: 5-3-00
 APPROVED: Stephanie A. Guilford Date: 5/5/00

NOTES: * = Information not supplied by client. < = Less than.
 # = Information not requested by client. N/A = Not Applicable. B - TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 D - BULK MATERIALS OR WIPES I - FILTER + TUBE

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 2

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13766	CLR-NAOH-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
															E

COMMENTS: SAMPLES ARE BLANK CORRECTED.

ANALYST : Neelam Patel Date: 5-3-00
 APPROVED: Stephanie A. Guilford Date: 5/5/00

NOTES: * = Information not supplied by client. < = Less than.
 # = Information not requested by client. N/A = Not Applicable.
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE

USX Engineers & Consultants Inc.
 IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 2

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13766	CLR-NAOH-BLANK	CHLORIDE	04/20/00	*	*	*	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

ANALYST : Neelam Patel Date: 5-3-00
 APPROVED: Stephanie A. Guilford Date: 5/5/00

NOTES: * = Information not supplied by client. < = Less than.
 # = Information not requested by client. N/A = Not Applicable. 8 - TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 D - BULK MATERIALS OR WIPES I - FILTER + TUBE


ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

* Please add Long
Sodium Thiosulfate
 $\text{Na}_2\text{S}_2\text{O}_3 \cdot 3.5\text{H}_2\text{O}$
prior to analysis

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 00-039-P ; P.O. # 3692		ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Clairton Works							
ANALYTICAL LAB UEC ITH and Environmental Laboratories							
DELIVER TO Sample Receiving							
COMMENTS No. 1 Battery Combustion Stack							
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	Chloride (in Cl-)	U.S. EPA Method 8000	Method 8000
00-#1BS-N26A-1A	04-19-00	Test #1	1	Comp.	✓		A: Impurities 1+2
00-#1BS-N26A-1B	↓	↓	1	Comp.	✓		B: Impurities 3
00-#1BS-N26A-1C	↓	↓	1	Comp.	✓		C: Impurities 4
00-#1BS-N26A-1D	↓	↓	1	Comp.	✓		D: Impurities 5
* $\text{0.1N H}_2\text{SO}_4$ - Sample Volume = 413.8 mL * $\text{0.1N H}_2\text{SO}_4$ - Sample Volume = 149.3 mL * 0.1N NaOH - Sample Volume = 139.3 mL * 0.1N NaOH - Sample Volume = 157.4 mL							
00-#1BS-N26A-2A	04-19-00	Test #2	1	Comp.	✓		$\text{0.1N H}_2\text{SO}_4$ - Sample Volume = 404.8 mL
00-#1BS-N26A-2B	↓	↓	1	Comp.	✓		$\text{0.1N H}_2\text{SO}_4$ - Sample Volume = 135.3 mL
00-#1BS-N26A-2C	↓	↓	1	Comp.	✓		* 0.1N NaOH - Sample Volume = 132.6 mL
00-#1BS-N26A-2D	↓	↓	1	Comp.	✓		* 0.1N NaOH - Sample Volume = 153.4 mL
RELINQUISHED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME	ICE CHEST #	TAG #
John P. Summerville	04-24-00	11:00	Wally C.	04-24-00	11:00		
Wally Summerville	04-25-00	12:45pm	Wally Summerville	04-24-00	4:27pm		



* lower ppm would:
Sodium phosphate
 $\text{Na}_2\text{S}_2\text{O}_3$ 3.54%
prior to analysis

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 44-4342P ; P.O. # 3692		ANALYSES TO BE CONDUCTED										REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Claiton Works													
ANALYTICAL LAB U.S. Steel Claiton Works													
DELIVER TO Sample Receiving													
COMMENTS No. 1 Battery Combustion Stack													
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	Chloride ion (Cl-)	Na ion (Na+)	US EPA Method 8160A	US EPA Method 8160A	DATE	TIME	ICE CHEST #		
44-4342P-1A	4-19-00	Test #1	1	Comp.	✓						4-19-00 11:02		
44-4342P-1B	4-19-00	↓	1	Comp.	✓						4-19-00 11:02		
44-4342P-1C	4-19-00	↓	1	Comp.	✓						4-19-00 11:02		
44-4342P-1D	4-19-00	↓	1	Comp.	✓						4-19-00 11:02		
44-4342P-2A	4-19-00	Test #2	1	Comp.	✓						4-19-00 11:02		
44-4342P-2B	4-19-00	↓	1	Comp.	✓						4-19-00 11:02		
44-4342P-2C	4-19-00	↓	1	Comp.	✓						4-19-00 11:02		
44-4342P-2D	4-19-00	↓	1	Comp.	✓						4-19-00 11:02		


ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

* Please add Long
Sodium Thiosulfate
Na₂S₂O₃ · 3.5H₂O
prior to analysis

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 00-037-P ; P.O. # 3692		ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Claiton Works							
ANALYTICAL LAB UEC Ilt and Environmental Laboratories							
DELIVER TO Sample Receiving							
COMMENTS No. 1 Battery Combustion Stack							
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	Chloride (m. Cl-)	U.S. EPA Method 8000	Method 8000
00-037-P-1A	04-19-00	Test #1	1	Comp.	✓		A: Impurities 1+2
00-037-P-1B	↓	↓	1	Comp.	✓		B: Impurities 3
00-037-P-1C	↓	↓	1	Comp.	✓		C: Impurities 4
00-037-P-1D	↓	↓	1	Comp.	✓		D: Impurities 5
* 0.1N H₂SO₄ - Sample Volume = 413.8 mL * 0.1N H₂SO₄ - Sample Volume = 149.3 mL * 0.1N NaOH - Sample Volume = 139.3 mL * 0.1N NaOH - Sample Volume = 157.4 mL							
00-037-P-2A	04-19-00	Test #2	1	Comp.	✓		0.1N H ₂ SO ₄ - Sample Volume = 404.8 mL
00-037-P-2B	↓	↓	1	Comp.	✓		0.1N H ₂ SO ₄ - Sample Volume = 135.3 mL
00-037-P-2C	↓	↓	1	Comp.	✓		* 0.1N NaOH - Sample Volume = 132.0 mL
00-037-P-2D	↓	↓	1	Comp.	✓		* 0.1N NaOH - Sample Volume = 153.4 mL
* 0.1N H₂SO₄ - Sample Volume = 404.8 mL * 0.1N H₂SO₄ - Sample Volume = 135.3 mL * 0.1N NaOH - Sample Volume = 132.0 mL * 0.1N NaOH - Sample Volume = 153.4 mL							
RELINQUISHED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)		DATE	TIME	ICE CHEST #
John P. Samuels	04-24-00	11:00 AM	Kathy Cy.		04-24-00	11:00 AM	
John P. Samuels	04-25-00	12:45 PM	John P. Samuels		04-25-00	04:27 PM	CHEST TEMP.
TAG #							



* please add long sodium phosphate $\text{Na}_2\text{S}_2\text{O}_3 \cdot 3.5\text{H}_2\text{O}$ prior to analysis

CHAIN OF CUSTODY RECORD


PROJECT NUMBER 04-030P ; P.O. # 3692		ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Clackson Works							
ANALYTICAL LAB UEC IIT and Environmental Laboratories							
DELIVER TO Sample Receiving							
COMMENTS No. 1 Battery Combustion Stack							
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	(Chloride ion (Cl-))	Via Ion Chromatography	U.S. EPA Method 8000
04-030P-1A	04-19-04	Test #1	1	Comp.	✓		
04-030P-1B			1	Comp.	✓		
04-030P-1C			1	Comp.	✓		
04-030P-1D			1	Comp.	✓		
04-030P-2A	04-19-04	Test #2	1	Comp.	✓		
04-030P-2B			1	Comp.	✓		
04-030P-2C			1	Comp.	✓		
04-030P-2D			1	Comp.	✓		
RELINQUISHED BY (SIGNATURE)		DATE	TIME	RECEIVED BY (SIGNATURE)		DATE	TIME
John P. Samuels		04-24-04	11:00 AM	Kelly C.		04-24-04	11:02
John P. Samuels		4-25-04	12:45 PM	John P. Samuels		4-24-04	4:27 PM
TAG #							

ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

CHAIN OF CUSTODY RECORD

PROJECT NUMBER PP-43P-P ; P.O. #3692				ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Clanton Works				ANALYSES TO BE CONDUCTED				A: Impinger 1+2	
ANALYTICAL LAB U.S. Steel and Environmental Laboratories				ANALYSES TO BE CONDUCTED				B: Impinger 3	
DELIVER TO Sample Receiving				ANALYSES TO BE CONDUCTED				C: Impinger 4	
COMMENTS No. 1 Battery Combustion Stack				ANALYSES TO BE CONDUCTED				D: Impinger 5	
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	ANALYSES TO BE CONDUCTED	ANALYSES TO BE CONDUCTED	ANALYSES TO BE CONDUCTED	ANALYSES TO BE CONDUCTED	REMARKS OR OBSERVATIONS
CLL-#1BS-M2GA-3A	04-24-00	Test #3	1	Comp.	✓	✓	✓	✓	Φ IN H ₂ O ₂ - Sample Volume = 404.2 mL
CLL-#1BS-M2GA-3B	↓	↓	1	Comp.	✓	✓	✓	✓	Φ IN H ₂ O ₂ - Sample Volume = 137.4 mL
CLL-#1BS-M2GA-3C	↓	↓	1	Comp.	✓	✓	✓	✓	* Φ IN NaOH - Sample Volume = 146.6 mL
CLL-#1BS-M2GA-3D	↓	↓	1	Comp.	✓	✓	✓	✓	* Φ IN NaOH - Sample Volume = 132.5 mL
CLL-H2SO4-BLANK	04-24-00	BLANK	1	Grab	✓	✓	✓	✓	Φ IN Na ₂ SO ₄
CLL-NaOH-BLANK	↓	↓	1	Grab	✓	✓	✓	✓	* Φ IN NaOH
RELINQUISHED BY (SIGNATURE)				DATE		TIME		ICE CHEST #	
<i>Paul P. Jansen</i>				04-24-00		11:02			
<i>July Jansen</i>				4-25-00		12:45 PM		CHEST TEMP.	
								TAG #	



CHAIN OF CUSTODY RECORD

PROJECT NUMBER ~~06-636~~-P ; P.O. #3692

PROJECT NAME U.S. Steel Clanton Works

ANALYTICAL LAB UZH and Environmental Laboratories

DELIVER TO Sample Processing

COMMENTS	No.	Battery Combustion Stack

SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE	
				OR	GRAB
04-28-20	Test #3	1	Comp.		
04-28-20	↓	1	Comp.		
04-28-20	↓	1	Comp.		
04-28-20	↓	1	Comp.		
04-28-20	Blank	1	Grab		
04-28-20	↓	1	Grab		

RELINQUISHED BY (SIGNATURE)	DATE	TIME
Paul P. Summerville	08-24-00	1140 EST
Judy Abtela	4-25-00	12:45 pm

ANALYSES TO BE CONDUCTED						REMARKS OR OBSERVATIONS
Chloride ion (Cl^-)	Via ion chromatography	US EPA Reference Method 800A			A: Impinger 1+2 B: Impinger 3 C: Impinger 4 D: Impinger 5	
✓						$\Phi \cdot 1\text{N H}_2\text{SO}_4 - \text{Sample Volume} = 44$
✓						$\Phi \cdot 1\text{N H}_2\text{SO}_4 - \text{Sample Volume} = 13$
✓						* $\Phi \cdot 1\text{N NaOH} - \text{Sample Volume} = 14$
✓						* $\Phi \cdot 1\text{N NaOH} - \text{Sample Volume} = 11$
✓						$\Phi \cdot 1\text{N H}_2\text{SO}_4$
✓						* $\Phi \cdot 1\text{N NaOH}$

RECEIVED BY (SIGNATURE)	DATE	TIME	ICE CHEST #
<i>Wally Sy</i>	04-24-02	11:01	
<i>Greg Sy</i>	4-24-02	4:35 PM	CHEST TEMP.
			TAG #

ATC 10/09

PAGE 2 OF 2

CHAIN OF CUSTODY RECORD

[illegible]



Place - add 50

CHAIN OF CUSTODY RECORD

[illegible]

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
 NO. 1 BATTERY COMBUSTION STACK
 APRIL 19 AND 20, 2000
 U.S. EPA REFERENCE METHOD 26A SAMPLING
 CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#1BS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H2SO4 - Impingers 1 & 2	29	413.8	12.00	100.0
	1B	0.1 N H2SO4 - Impinger 3	< 2.0	149.3	< 0.30	
	1C	0.1 N NaOH - Impinger 4	< 2.0	139.3	< 0.28	NA
	1D	0.1 N NaOH - Impinger 5	< 2.0	157.4	< 0.31	
2	2A	0.1 N H2SO4 - Impingers 1 & 2	29	404.8	11.74	100.0
	2B	0.1 N H2SO4 - Impinger 3	< 2.0	135.3	< 0.27	
	2C	0.1 N NaOH - Impinger 4	< 2.0	132.0	< 0.26	NA
	2D	0.1 N NaOH - Impinger 5	< 2.0	153.0	< 0.31	
3	3A	0.1 N H2SO4 - Impingers 1 & 2	26	404.2	10.51	100.0
	3B	0.1 N H2SO4 - Impinger 3	< 2.0	137.0	< 0.27	
	3C	0.1 N NaOH - Impinger 4	< 2.0	146.6	< 0.29	NA
	3D	0.1 N NaOH - Impinger 5	< 2.0	132.5	< 0.27	
Blank	Blank	0.1 N H2SO4	< 2.0			
Blank	Blank	0.1 N NaOH	< 2.0			

0.1 N H2SO4

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (< 2.0) ---->

Chloride catch = 0

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
 NO. 1 BATTERY COMBUSTION STACK
 APRIL 19 AND 20, 2000
 U.S. EPA REFERENCE METHOD 26A SAMPLING
 CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#1BS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	29	413.8	12.00	100.0
	1B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	149.3	< 0.30	
	1C	0.1 N NaOH - Impinger 4	< 2.0	139.3	< 0.28	NA
	1D	0.1 N NaOH - Impinger 5	< 2.0	157.4	< 0.31	
2	2A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	29	404.8	11.74	100.0
	2B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	135.3	< 0.27	
	2C	0.1 N NaOH - Impinger 4	< 2.0	132.0	< 0.26	NA
	2D	0.1 N NaOH - Impinger 5	< 2.0	153.0	< 0.31	
3	3A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	26	404.2	10.51	100.0
	3B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	137.0	< 0.27	
	3C	0.1 N NaOH - Impinger 4	< 2.0	146.6	< 0.29	NA
	3D	0.1 N NaOH - Impinger 5	< 2.0	132.5	< 0.27	
Blank	Blank	0.1 N H ₂ SO ₄	< 2.0			
Blank	Blank	0.1 N NaOH	< 2.0			

0.1 N H₂SO₄

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (< 2.0) ---->

Chloride catch = 0

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

NO. 1 BATTERY COMBUSTION STACK

APRIL 19 AND 20, 2000

U.S. EPA REFERENCE METHOD 26A SAMPLING

CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#1BS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	29	413.8	12.00	100.0
	1B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	149.3	< 0.30	
	1C	0.1 N NaOH - Impinger 4	< 2.0	139.3	< 0.28	NA
	1D	0.1 N NaOH - Impinger 5	< 2.0	157.4	< 0.31	
2	2A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	29	404.8	11.74	100.0
	2B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	135.3	< 0.27	
	2C	0.1 N NaOH - Impinger 4	< 2.0	132.0	< 0.26	NA
	2D	0.1 N NaOH - Impinger 5	< 2.0	153.0	< 0.31	
3	3A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	26	404.2	10.51	100.0
	3B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	137.0	< 0.27	
	3C	0.1 N NaOH - Impinger 4	< 2.0	146.6	< 0.29	NA
	3D	0.1 N NaOH - Impinger 5	< 2.0	132.5	< 0.27	
Blank	Blank	0.1 N H ₂ SO ₄	< 2.0			
Blank	Blank	0.1 N NaOH	< 2.0			

0.1 N H₂SO₄

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (< 2.0) ---->

Chloride catch = 0

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

NO. 1 BATTERY COMBUSTION STACK

APRIL 19 AND 20, 2000

U.S. EPA REFERENCE METHOD 26A SAMPLING

CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#1BS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	29	413.8	12.00	100.0
	1B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	149.3	< 0.30	NA
	1C	0.1 N NaOH - Impinger 4	< 2.0	139.3	< 0.28	
	1D	0.1 N NaOH - Impinger 5	< 2.0	157.4	< 0.31	
2	2A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	29	404.8	11.74	100.0
	2B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	135.3	< 0.27	NA
	2C	0.1 N NaOH - Impinger 4	< 2.0	132.0	< 0.26	
	2D	0.1 N NaOH - Impinger 5	< 2.0	153.0	< 0.31	
3	3A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	26	404.2	10.51	100.0
	3B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	137.0	< 0.27	NA
	3C	0.1 N NaOH - Impinger 4	< 2.0	146.6	< 0.29	
	3D	0.1 N NaOH - Impinger 5	< 2.0	132.5	< 0.27	
Blank	Blank	0.1 N H ₂ SO ₄	< 2.0			
Blank	Blank	0.1 N NaOH	< 2.0			

0.1 N H₂SO₄

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (< 2.0) ---->

Chloride catch = 0

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 4/19/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR- #1BS-M26A-1

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.51
B.	Process Gas Static Pressure (in. H2O)	-1.00
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	0.9851
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	114
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.05
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.05
K.	Average ΔH (in. H2O) variation	0.99
L.	Average Process Gas Temperature (°F)	516
M.	Average Dry Gas Meter Temperature (°F)	69
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	12.0
	Nitrogen (%)	84.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	217.4
Q.	Metered Gas Volume (dcf)	67.869

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.44	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.58	[A+(K/13.6)]
T.	Duct Area (ft. ²)	7.09E+01	[$\pi E^2/(4*144)$ or $F*G/144$]
U.	Nozzle Area (ft. ²)	1.06E-03	[$\pi H^2/(4*144)$]
V.	Average Absolute Process Gas Temperature (R)	976	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	529	[M+460]
X.	Dry Gas Volume Sampled (dscf)	65.979	[$Q*D*(528/W)*(S/29.92)$]
Y.	H2O Vapor Condensed (scf)	10.250	[$P*0.04715$]
Z.	Calculated Percent H2O in Gas Stream (%)	13.4	[$100*Y/(X+Y)$]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%) (empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)	#N/A	[$100*\text{Saturated Water Vapor Pressure} / \text{Stack Pressure}$]
BB.	Actual Percent H2O in Gas Stream (%)	13.4	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.134		18	2.420
CO2	0.040	0.866	44	1.523
O2	0.120	0.866	32	3.324
N2	0.840	0.866	28	20.357
CO	0.000	0.866	28	0.000
H2	0.000	0.866	2	0.000
CH4	0.000	0.866	16	0.000
C2H6	0.000	0.866	30	0.000
Ar	0.000	0.866	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.62	
DD.	Average Process Gas Velocity (ft/sec)	1.83E+01	[85.49*C*[(I*V)/(R*CC)]^0.5]
EE.	Process Gas Volumetric Flow Rate (acfm)	7.78E+04	[DD*T*60]
FF.	Process Gas Volumetric Flow Rate (scfm)	4.14E+04	[EE*(528/V)*(R/29.92)]
GG.	Process Gas Volumetric Flow Rate (dscfm)	3.58E+04	[FF*(1-(BB/100))]
HH.	Isokinetic Variation (%)	103.0	[100*V*{(0.002669*P)+(Q*D*S/W)}] /

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0052	
JJ.	Front-Half Residue Weight (g)	0.0075	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0127	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0030	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	9.11E-01	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE:

4/19/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR-

#1BS-M26A-1

Hydrochloric Acid (corrected for blank)

PP. Total Catch (mg)

12.34

QQ. Concentration (mg/dscm)

6.60E+00 [PP/(X*0.02832)]

RR. Mass Flow Rate (lb/hr)

8.85E-01 [QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS. Total Catch (mg)

0.28

TT. Concentration (mg/dscm)

1.49E-01 [SS/(X*0.02832)]

UU. Mass Flow Rate (lb/hr)

2.00E-02 [TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST DATE:

4/19/00

TEST NO.: CLR-

#1BS-M26A-2

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.51
B.	Process Gas Static Pressure (in. H2O)	-1.10
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	0.9851
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	114
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.05
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.05
K.	Average ΔH (in. H2O) variation	0.89
L.	Average Process Gas Temperature (°F)	516
M.	Average Dry Gas Meter Temperature (°F)	78
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	12.5
	Nitrogen (%)	83.5
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	206.8
Q.	Metered Gas Volume (dcf)	66.020

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.43	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.58	[A+(K/13.6)]
T.	Duct Area (ft.^2)	7.09E+01	[Pi*E^2/(4*144) or F*G/144]
U.	Nozzle Area (ft.^2)	1.06E-03	[Pi*H^2/(4*144)]
V.	Average Absolute Process Gas Temperature (R)	976	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	538	[M+460]
X.	Dry Gas Volume Sampled (dscf)	63.092	[Q*D*(528/W)*(S/29.92)]
Y.	H2O Vapor Condensed (scf)	9.751	[P*0.04715]
Z.	Calculated Percent H2O in Gas Stream (%)	13.4	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H2O in Gas Stream (%)	13.4	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.134		18	2.409
CO2	0.040	0.866	44	1.524
O2	0.125	0.866	32	3.465
N2	0.835	0.866	28	20.250
CO	0.000	0.866	28	0.000
H2	0.000	0.866	2	0.000
CH4	0.000	0.866	16	0.000
C2H6	0.000	0.866	30	0.000
Ar	0.000	0.866	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.65	
DD.	Average Process Gas Velocity (ft/sec)	1.72E+01	[85.49*C*[(I*V)/(R*CC)]^0.5]
EE.	Process Gas Volumetric Flow Rate (acfm)	7.33E+04	[DD*T*60]
FF.	Process Gas Volumetric Flow Rate (scfm)	3.90E+04	[EE*(528/V)*(R/29.92)]
GG.	Process Gas Volumetric Flow Rate (dscfm)	3.38E+04	[FF*(1-(BB/100))]
HH.	Isokinetic Variation (%)	104.5	[100*V*{(0.002669*P)+(Q*D*S/W)}]

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0040	
JJ.	Front-Half Residue Weight (g)	0.0066	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0106	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0026	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	7.50E-01	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE:

4/19/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR-

#1BS-M26A-2

Hydrochloric Acid (corrected for blank)

PP. Total Catch (mg)

12.07

QQ. Concentration (mg/dscm)

6.76E+00

[PP/(X*0.02832)]

RR. Mass Flow Rate (lb/hr)

8.54E-01

[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS. Total Catch (mg)

0.26

TT. Concentration (mg/dscm)

1.48E-01

[SS/(X*0.02832)]

UU. Mass Flow Rate (lb/hr)

1.87E-02

[TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST DATE: 4/20/00
TEST NO.: CLR- #1BS-M26A-3

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.35
B.	Process Gas Static Pressure (in. H2O)	-1.10
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	0.9851
»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	114
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.04
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.04
K.	Average ΔH (in. H2O) variation	0.79
L.	Average Process Gas Temperature (°F)	513
M.	Average Dry Gas Meter Temperature (°F)	82
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	12.5
	Nitrogen (%)	83.5
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	203.5
Q.	Metered Gas Volume (dcf)	62.141

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.27	$[A + (B/13.6)]$
S.	Absolute Meter Pressure (in. Hg)	29.41	$[A + (K/13.6)]$
T.	Duct Area (ft. ²)	7.09E+01	$[P_i^2 E^2 / (4 * 144)]$ or $F * G / 144$
U.	Nozzle Area (ft. ²)	1.06E-03	$[P_i^2 H^2 / (4 * 144)]$
V.	Average Absolute Process Gas Temperature (R)	973	$[L + 460]$
W.	Average Absolute Dry Gas Meter Temperature (R)	542	$[M + 460]$
X.	Dry Gas Volume Sampled (dscf)	58.614	$[Q * D * (528/W) * (S/29.92)]$
Y.	H2O Vapor Condensed (scf)	9.595	$[P * 0.04715]$
Z.	Calculated Percent H2O in Gas Stream (%)	14.1	$[100 * Y / (X + Y)]$
AA.	Theoretical Maximum Percent H2O in Gas Stream (%) (empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)	#N/A	$[100 * \text{Saturated Water Vapor Pressure} / \text{Stack Pressure}]$
BB.	Actual Percent H2O in Gas Stream (%)	14.1	$[\text{Calculated \%H2O} \leq \text{Theoretical Max. \%H2O}]$
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.141		18	2.532
CO2	0.040	0.859	44	1.512
O2	0.125	0.859	32	3.437
N2	0.835	0.859	28	20.091
CO	0.000	0.859	28	0.000
H2	0.000	0.859	2	0.000
CH4	0.000	0.859	16	0.000
C2H6	0.000	0.859	30	0.000
Ar	0.000	0.859	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.57	
DD.	Average Process Gas Velocity (ft/sec)	1.62E+01	$[85.49 * C * [(I * V) / (R * CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	6.87E+04	$[DD * T * 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	3.65E+04	$[EE * (528/V) * (R/29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	3.14E+04	$[FF * (1 - (BB/100))]$
HH.	Isokinetic Variation (%)	104.6	$[100 * V * \{(0.002669 * P) + (Q * D * S / W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0030	
JJ.	Front-Half Residue Weight (g)	0.0083	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0113	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0030	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	7.99E-01	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE:

4/20/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR-

#1BS-M26A-3

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	10.81	
QQ.	Concentration (mg/dscm)	6.51E+00	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	7.64E-01	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.29	
TT.	Concentration (mg/dscm)	<	1.77E-01	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	2.07E-02	[TT*0.02832*GG*60/454000]



639 Alpha Drive
Pittsburgh, Pennsylvania 15238
Telephone (412) 967-1900
FAX (412) 967-1911

ADVANCED TECHNOLOGY SYSTEMS, INC.

ATS Project No. 00-030-P

September 13, 2000

Mr. William C. Graeser
Manager – Environmental and Quality Assurance
U.S. Steel Clairton Works
400 State Street
Clairton, PA 15025

**RE: LETTER REPORT – HYDROCHLORIC ACID AND CHLORINE GAS EMISSIONS
TESTING CONDUCTED AT NO. 1 BATTERY COMBUSTION STACK ON APRIL
19 AND 20, 2000**

Dear Mr. Graeser:

This letter, with attachments, constitutes the report that summarizes the results of the hydrochloric acid (HCl) and chlorine gas (Cl₂) emissions testing conducted at No. 1 Battery Combustion Stack by Advanced Technology Systems, Inc. (ATS). Three two-hour test runs were conducted on April 19 and 20, 2000 simultaneous with the compliance test program at this stack (particulate matter and visible emissions were measured as part of the compliance test program).

The test results have been summarized in the attached Table 1. Hydrochloric acid and chlorine gas concentrations are listed in units of milligrams per dry standard cubic meter (mg/dscm). Hydrochloric acid and chlorine gas mass emission rates are listed in units of pounds per hour (lb/hr). Table 1 also presents pertinent exhaust gas and sampling parameters including exhaust gas flow rates in units of actual cubic feet per minute (acfm), standard cubic feet per minute (scfm), and dry standard cubic feet per minute (dscfm), exhaust gas temperature (°F), and moisture content of the exhaust gas (percent by volume), gas volume sampled for each test run in units of dry standard cubic feet (dscf) and the isokinetic variation value for each test run. The isokinetic variation value is equal to the ratio of the average linear gas velocity sampled through the probe nozzle to the average exhaust gas velocity. All isokinetic variation values are between 90 percent and 110 percent, which is the acceptable range of values. Actual test sampling times have also been included in Table 1.

Hydrochloric acid and chlorine gas emission testing was performed in accordance with U.S. EPA Reference Methods 1 through 4 and 26A and the requirements of the Pennsylvania Department of Environmental Protection (PA DEP) Source Testing Manual (Draft Revision 3.1, May 3, 1999). Detailed information regarding the procedures used to measure the exhaust gas stream velocity and volumetric flow rate (i.e., U.S. EPA Reference Methods 1 through 4) can be found in the summary report for the compliance test program. Hydrochloric acid and chlorine gas sampling was performed in accordance with U.S. EPA Reference Method 26A. Process gas samples were withdrawn isokinetically from the stack, with particulate matter collected in a glass nozzle, a heated glass-lined

probe, and on a heated quartz filter. Vapor phase hydrochloric acid and chlorine gas were collected in a series of chilled impingers. The impinger type and sequence is listed below:

<u>No.</u>	<u>Impinger Type</u>	<u>Contents</u>
1.	Modified Greenburg-Smith	50 mL 0.1 N sulfuric acid (for HCl collection)
2.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
3.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl collection)
4.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
5.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
6.	Modified Greenburg-Smith	200 g Silica Gel

A gas volume greater than 50 dry standard cubic feet (dscf) – the minimum gas volume required by the PA DEP for the compliance test program - was sampled for each test run. The flow rate through each sample train was less than 1 dry standard cubic foot per minute as required by U.S. EPA Reference Method 26A.

Following each test run, the sample trains were processed in accordance with PA DEP requirements. Detailed information regarding the procedures used to recover the particulate matter catch (essentially U.S. EPA Reference Method 5 procedures) can be found in the summary report for the compliance test program. Following the gravimetric analysis of the impingers for moisture gain, the following four samples fractions were generated for each sample train:

<u>Fraction</u>	<u>Description</u>
A	Contents of Impinger Nos. 1 & 2 plus applicable distilled deionized water rinses (for HCl)
B	Contents of Impinger No. 3 plus applicable distilled deionized water rinses (for HCl)
C	Contents of Impinger No. 4 plus applicable distilled deionized water rinses (for Cl ₂)
D	Contents of Impinger No. 5 plus applicable distilled deionized water rinses (for Cl ₂)

For each sample train, each of the four fractions were analyzed separately as required by the PA DEP to allow for the calculation of the collection efficiency of the sample train for HCl and Cl₂ collection. The contents of Impinger No. 6 were discarded.

The actual test samples plus field blanks of the impinger scrubbing solutions (0.1 N sulfuric acid and 0.1 N sodium hydroxide) were submitted to the subcontract analytical laboratory for chloride ion analyses using ion chromatographic techniques in accordance with U.S. EPA Reference Method 26A. The analytical laboratory results showed the following:

- The chloride ion concentrations of the field blanks were less than the analytical detection limit;
- For all three test runs, the HCl collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction B was at most 10 percent of the chloride catch from Sample Fraction A plus Sample Fraction B); and

September 13, 2000

- For all three test runs, the Cl_2 collection efficiency of the sample train could not be calculated since the chloride catch of Sample Fractions C and D were less than the analytical detection limit.

Copies of the field data sheets, equipment calibration data, analytical laboratory results and emissions calculations are included in the appendix.

ATS appreciates the opportunity to provide U.S. Steel with process gas testing services. If you have any questions regarding this letter report, please call Dr. Robinson Khosah or me at (412) 967-1900 or e-mail me at the following address: jshimshock@atsengineers.com.

Very truly yours,



John P. Shimshock, Ph.D.
Senior Project Scientist

Approved by:



Robinson P. Khosah, Ph.D.

Vice President
Science and Technology Division

JPS/blc
Enclosures

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

TABLE 1

**NO. 1 BATTERY COMBUSTION STACK
HYDROCHLORIC ACID AND CHLORINE GAS EMISSIONS DATA
APRIL 19 AND 20, 2000**

Test Date		<u>Run 1</u> 4/19/00	<u>Run 2</u> 4/19/00	<u>Run 3</u> 4/20/00	<u>Average</u>
<u>Emissions Data</u>					
Hydrochloric Acid (HCl)					
Concentration	(mg/dscm)	6.60E+00	6.76E+00	6.51E+00	6.62E+00
Mass Emission Rate	(lb/hr)	8.85E-01	8.54E-01	7.64E-01	8.34E-01
Chlorine Gas (Cl ₂)					
Concentration	(mg/dscm)	< 1.49E-01	< 1.48E-01	< 1.77E-01	< 1.58E-01
Mass Emission Rate	(lb/hr)	< 2.00E-02	< 1.87E-02	< 2.07E-02	< 1.98E-02
<u>Exhaust Stack Conditions</u>					
Volumetric Flow Rate	(acfm)	7.78E+04	7.33E+04	6.87E+04	7.33E+04
	(scfm)	4.14E+04	3.90E+04	3.65E+04	3.90E+04
	(dscfm)	3.58E+04	3.38E+04	3.14E+04	3.37E+04
Temperature	(°F)	516	516	513	515
Moisture Content	(%)	13.4	13.4	14.1	13.6
<u>Sampling Conditions</u>					
Test Times +	(EDT)	0810 to 0912 & 1117 to 1220	1510 to 1718	1055 to 1308	
Sampling Time *	(minutes)	120	120	120	
Sample Volume **	(dscf)	65.979	63.092	58.614	
Isokinetic Variation ***	(%)	103.0	104.5	104.6	

mg / dscm = milligrams per dry standard cubic meter

+: Battery heat delay from 0912 to 1030 EDT

*: Minimum required sampling time is 2 hours (120 minutes)

**: Minimum required sample volume is 50 dscf

***: Acceptable range of values is 90.0% <= Isokinetic Variation <= 110.0%

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

**Hydrochloric Acid and Chlorine Gas
Emissions Testing Conducted at
No. 1 Battery Combustion Stack
on April 19 and 20, 2000**

September 2000

APPENDIX

**Field Data Sheets, Equipment Calibration Data,
Analytical Laboratory Results and Emissions
Calculations**



ADVANCED TECHNOLOGY SYSTEMS, INC.

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS, KA
 PROJECT NO.: 00-030-P
 TEST DATE: April 19, 2000
 TEST NO.: 29,51
 B.P. (in. Hg): 29.51
 STATIC P. (in. H2O): -1.0
 STACK DIA. (in.): 114
 CONTROL BOX NO.: APEX-1
 ORIFICE FACTOR (AH@): 1.911
 METER CORR. (Y): 0.9851
 CALIBRATION DATE: 9-20-99
 PORT SIZE & TYPE: 4" Flanges
 PITOT COEF.: 0.84
 HOT/COLD BOX NO.: 5
 FILTER NO.: 480 QIZ
 PROBE NO.: 7-1
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
A	40.6	0810	688.863	0.07	1.30	1.30	248	502	59	57	245	60
	28.5			0.07	1.30	1.30	248	509	62	58	245	50
	20.2			0.07	1.28	1.28	248	519	67	59	245	50
	13.5			0.06	1.09	1.09	248	529	68	60	245	51
	7.6			0.04	0.72	0.72	247	517	70	60	245	48
	2.4	0840	706.567	0.03	0.54	0.54	247	505	72	61	245	48
3	40.6	0842	706.567	0.08	1.47	1.47	247	513	68	61	245	48
	28.5			0.07	1.24	1.24	247	557	75	62	245	49
	20.2			0.07	1.23	1.23	247	569	78	63	245	49
	13.5			0.06	1.05	1.05	247	489	79	64	244	48
	7.6			0.03	0.53	0.53	247	480	78	64	245	49
	2.4	0912	724.682	0.03	0.53	0.53	247	482	78	64	245	49
Page 1	Δ = 60	min	Δ = 35.819	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			
Totals			def	0.055	0.99			514 (°F)	66 (°F)			Estimates:
Test	Δ = 120	min	Δ = 67.869	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			MW = 27.6
Totals			def	0.054	0.99			516 (°F)	69 (°F)			%H2O = 13

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.0	0.008	< 0.02
After	8.0	0.009	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

Dry Gas Composition

Run 1	Run 2
CO2 4.6%	
O2 12.4%	
CO	
N2 84.6%	

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	634.1	92.5	117.6
2.	100 mL 0.1 N H2SO4	644.8	545.3	69.5
3.	100 mL 0.1 N H2SO4	574.2	563.5	10.7
4.	100 mL 0.1 N NaOH	541.7	539.4	2.3
5.	100 mL 0.1 N NaOH	534.5	518.5	2.0
6.	~ 200 g Silica Gel	664.5	649.2	15.3
7.			Total =	217.4g
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS, KA
 PROJECT NO.: 00-030-P
 TEST DATE: April 19th, 2000
 TEST NO.: 29.51
 B.P. (in. Hg): -1.4
 STATIC P. (in. H2O): 114
 STACK DIA. (in.): 114
 CONTROL BOX NO.: APEX-1
 ORIFICE FACTOR (AH@): 1.911
 METER CORR. (Y): 0.9851
 CALIBRATION DATE: 9-20-99
 PORT SIZE & TYPE: 4" Flanges PITOT COEF. 0.84
 FILTER NO.: 480 Q17
 PROBE NO.: 7-1
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
C	40.6	1117	724.682	0.06	1.10	1.10	249	513	66	64	245	50
	28.5			0.06	1.10	1.10	249	519	69	65	245	49
	20.2			0.06	1.10	1.10	248	506	69	64	245	49
	13.5			0.07	1.29	1.29	248	518	71	65	245	49
	7.6			0.05	0.92	0.92	248	539	76	65	245	49
	2.4	1147	740.606	0.04	0.74	0.74	248	500	78	66	245	49
D	40.6	1150	740.606	0.08	1.47	1.47	248	551	77	67	245	49
	28.5			0.08	1.47	1.47	248	577	79	67	245	50
	20.2			0.05	0.92	0.92	247	501	80	68	245	50
	13.5			0.03	0.56	0.56	248	498	81	68	245	49
	7.6			0.03	0.56	0.56	248	494	81	68	244	52
	2.4	1220	756.732	0.03	0.56	0.56	248	496	81	68	244	52
Page 2	Δ = 60	Δ = 32.050	(ΔP) avg = 0.052	(ΔH) avg = 0.98	(Tstack) avg = 517	(Tmeter) avg = 71						Estimates: MW = 27.6 %H2O = 13
Totals		min	def									

Dry Gas Composition

Run 1	Run 2
CO2 4%	
O2 13%	
CO 1%	
N2 84%	

System Leak Check (60 sec)

Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before		< 0.02
After		< 0.02

Pitot Leak Check (15 sec)

Before	After	Positive	Negative

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST DATE: April 19, 2000
 TEST NO.: 19
 CONTROL BOX NO.: APEX-1
 HOT/COLD BOX NO.: 4
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS, KA
 CLP - #IBS - M26A - ZORIFICE FACTOR (ΔH@): 1.911
 FILTER NO.: 481
 QIZ
 METER CORR. (Y): 0.9851
 PROBE NO.: 7.1
 CALIBRATION DATE: 9-20-00
 NOZZLE DIA. (in.): 0.440
 PROJECT NO.: 00-030-P
 STACK DIA. (in.): 114
 PORT SIZE & TYPE: 4" Flanges
 PITOT COEF.: 0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcf)	Pitot ΔP (in. H ₂ O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H ₂ O)	Actual (in. H ₂ O)				In (°F)	Out (°F)			
AD	40.6	1510	757.105	0.05	0.94	0.94	5.0	243	500	71	69	248	60	5 min./pt.
	28.5			0.05	0.94	0.94	5.0	243	507	72	69	248	59	
	20.2			0.04	0.74	0.74	4.0	243	513	75	70	248	59	
	13.5			0.035	0.65	0.65	3.0	242	520	78	70	248	59	
	7.6			0.04	0.74	0.74	4.0	242	526	80	70	246	53	
	2.4	1540	772.258	0.035	0.65	0.65	3.0	242	522	82	71	247	51	
AC	40.6	1542	772.258	0.08	1.50	1.50	7.0	243	534	81	72	246	50	
	28.5			0.08	1.50	1.50	7.0	243	561	84	72	246	50	
	20.2			0.07	1.27	1.27	6.0	244	570	85	73	246	50	
	13.5			0.05	0.91	0.91	6.0	244	496	85	73	246	49	
	7.6			0.04	0.72	0.72	4.0	245	489	86	73	245	49	
	2.4	1612	790.867	0.03	0.54	0.54	2.0	244	490	86	73	245	49	
Page 1	Δ = 60	min	Δ = 33.762	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =	(Tmeter) avg =				
Totals			dcf	0.049		0.90			519	76				Estimates:
Test	Δ = 120	min	Δ = 66.020	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =	(Tmeter) avg =				MW =
Totals			dcf	0.048		0.886			516	78				%H ₂ O =

Dry Gas Composition

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.009	< 0.02
After	1.00	0.010	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

Run 1

Run 2

CO ₂	4.6%
O ₂	12.5%
CO	—
N ₂	83.5%

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H ₂ SO ₄	622.7	503.6	119.1
2.	100 mL 0.1 N H ₂ SO ₄	634.1	568.4	65.7
3.	100 mL 0.1 N H ₂ SO ₄	522.9	522.3	0.6
4.	100 mL 0.1 N NaOH	517.7	519.3	-1.6
5.	100 mL 0.1 N NaOH	561.4	552.9	8.5
6.	~ 200 g Silica Gel	679.5	664.1	15.4
7.				
8.				

Total = 240.8 g

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT	U.S. Steel Clairton Works	TEST DATE	April 19 th , 2000	CONTROL BOX NO.	APEX-1	HOT/COLD BOX NO.	4
PLANT SITE	Clairton, PA	TEST NO.	CLR-#IBS-M26A-2	ORIFICE FACTOR (ΔH@)	1.911	FILTER NO.	481 QTE
TEST UNIT	No. 1 Battery Combustion Stack	B.P. (in. Hg)	29.51	METER CORR. (Y)	0.9851	PROBE NO.	7.1
TEST CREW	JS, KA	STATIC P. (in. H2O)	-1.1	CALIBRATION DATE	9-20-00	NOZZLE DIA. (in.)	0.440
PROJECT NO.	00-030-P	STACK DIA. (in.)	114	PORT SIZE & TYPE	4" Flanges	PITOT COEF.	0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
RB	40.6	1616	790.867	0.06	1.13	1.13	6.0	244	509	83	73	246	47	5 min./pt.
	28.5			0.06	1.13	1.13	6.0	244	516	84	73	246	47	
	20.2			0.05	0.94	0.94	5.0	246	529	86	73	246	48	
	13.5			0.05	0.94	0.94	5.0	246	512	87	73	244	48	
	7.6			0.03	0.56	0.56	3.0	244	529	87	73	245	48	
	2.4	1646	806.964	0.03	0.56	0.56	3.0	244	480	86	73	245	48	
PA	40.6	1648	806.964	0.06	1.11	1.11	6.0	245	536	83	73	245	49	
	28.5			0.06	1.11	1.11	6.0	245	565	86	74	245	49	
	20.2			0.06	1.11	1.11	6.0	245	509	86	74	246	50	
	13.5			0.05	0.96	0.96	5.0	247	498	88	74	246	49	
	7.6			0.03	0.57	0.57	3.0	247	495	88	74	246	50	
	2.4	1718	823.125	0.03	0.57	0.57	3.0	247	490	88	74	246	50	
Totals				(ΔP) avg =	(ΔH) avg =				(T _{stack}) avg =		(T _{meter}) avg =		Estimates:	
Page 2				Δ = 60	Δ = 32.258				513 (°F)		79 (°F)		MW =	27.6
													%H2O =	13

Dry Gas Composition

	Run 1	Run 2
CO2		
O2		
CO		
N2		

System Leak Check (60 sec)

	Vacuum (in. Hg)	DCGM Rate (cfm)	Required (cfm)
2			
Before			< 0.02
After			< 0.02

↑
= [2.258]
[1718]

Pitot Leak Check (15 sec)

	Positive	Negative
Before		
After		

No.	Impinging Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS, KA
 PROJECT NO.: 00-030-P
 TEST DATE: April 20, 2000
 TEST NO.: 2935
 B.P. (in. Hg): 29.35
 STATIC P. (in. H2O): -1.1
 STACK DIA. (in.): 114
 CONTROL BOX NO.: APEX-1
 ORIFICE FACTOR (ΔH@): 1.911
 METER CORR. (Y): 0.9851
 CALIBRATION DATE: 9-20-99
 PORT SIZE & TYPE: 4" Flanges PITOT COEF. 0.84
 FILTER NO.: 466 Q7Z
 PROBE NO.: 7-1
 NOZZLE DIA. (in.): 0.440

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
A	40.6	1055	823.543	0.06	1.07	1.07	235	562	71	71	59	5 min./pt.
	28.5			0.05	0.89	0.89	245	494	74	71	59	
	20.2			0.05	0.89	0.89	245	491	77	73	56	
	13.5			0.03	0.57	0.57	245	500	81	72	56	
	7.6			0.03	0.57	0.57	245	504	83	72	54	
	2.4	1125	838.352	0.03	0.57	0.57	245	506	84	73	54	
B	40.6	1130	838.352	0.06	1.14	1.14	247	498	82	74	54	
	28.5			0.06	1.14	1.14	247	525	86	75	54	
	20.2			0.04	0.75	0.75	247	527	88	75	54	
	13.5			0.04	0.75	0.75	246	538	88	76	54	
	7.6			0.03	0.55	0.55	245	542	89	76	55	
	2.4	1200	853.857	0.03	0.55	0.55	245	480	89	76	55	
Page 1	Δ = 60	Δ = 30.314		(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			
Totals	min	def		0.042	0.771			514 (°F)	78 (°F)			Estimates:
Test	Δ = 120	Δ = 62.141		(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			MW =
Totals	min	def		0.042	0.785			513 (°F)	82 (°F)			%H2O =

Dry Gas Composition

Run 1	Run 2
CO2 4.6	
O2 12.5	
CO 1.9	
N2 83.5	

System Leak Check (60 sec)

Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before 5.00	0.006	< 0.02
After 5.00	0.004	< 0.02

12
 [21.41]
 n

Pitot Leak Check (15 sec)

Positive	Negative
Before OK	OK
After OK	OK

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	614.4	468.5	145.5
2.	100 mL 0.1 N H2SO4	525.9	486.8	39.1
3.	100 mL 0.1 N H2SO4	584.5	583.7	0.8
4.	100 mL 0.1 N NaOH	533.4	534.7	2.3
5.	100 mL 0.1 N NaOH	533.1	531.7	1.7
6.	~200 g Silica Gel	632.6	488.5	14.1
7.				
8.				total = 243.50

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT: U.S. Steel Clairton Works
 PLANT SITE: Clairton, PA
 TEST UNIT: No. 1 Battery Combustion Stack
 TEST CREW: JS, KA
 PROJECT NO.: 00-030-P
 TEST DATE: April 20, 2000
 TEST NO.: 29-35
 B.P. (in. Hg): 29-35
 STATIC P. (in. H2O): -1.1
 CONTROL BOX NO.: APEX-1
 ORIFICE FACTOR (ΔH@): 1.911
 METER CORR. (Y): 0.9851
 CALIBRATION DATE: 9-20-99
 NOZZLE DIA. (in.): 0.440
 FILTER NO.: 466 QIZ
 PROBE NO.: 7-1
 PORT SIZE & TYPE: 4" Flanges PITOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EST)	DGM Reading (dcf)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
C	40.6	1204	853.857	0.05	0.96	0.96	246	500	84	77	55	5 min./pt.
	28.5			0.04	0.77	0.77	246	495	87	77	56	
	20.2			0.04	0.77	0.77	247	504	91	78	56	
	13.5			0.04	0.76	0.76	247	509	92	79	56	
	7.6			0.03	0.59	0.59	246	493	93	80	56	
	2.4	1234	869.550	0.03	0.59	0.59	246	490	92	80	57	
D	40.6	1238	869.550	0.06	1.15	1.15	246	507	86	81	57	
	28.5			0.06	1.15	1.15	246	544	92	81	57	
	20.2			0.05	0.92	0.92	247	548	94	82	56	
	13.5			0.05	0.92	0.92	246	555	95	82	57	
	7.6			0.03	0.58	0.58	247	501	95	83	57	
	2.4	1308	885.684	0.03	0.58	0.58	247	498	95	83	56	
Page 2	Δ = 60	Δ = 31.827	(ΔP) avg = (ΔH) avg =	0.042		0.799		512		86		Estimates:
Totals	min	dcf										MW = 27.6
												%H2O = 13

Dry Gas Composition

Run 1	Run 2
CO2 4%	
O2 12.5%	
CO	
N2 83.5%	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before			< 0.02
After			< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before		
After		

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:

03/06/00

Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
1	0.125		0.125	0.125	0.125	KA	03-12-96
2	0.156		0.156	0.156	0.156	KA	03-12-96
3	0.156		0.156	0.156	0.156	KA	09-04-96
44	0.156		0.156	0.156	0.156	KA	09-04-96
11	0.180		0.180	0.180	0.180	KA	07-20-98
5	0.190		0.190	0.190	0.190	KA	02/18/00
27	0.190		0.190	0.190	0.190	KA	05-19-99
28	0.190		0.190	0.190	0.190	KA	05-19-99
29	0.190		0.190	0.190	0.190	KA	01/05/00
31	0.190		0.190	0.190	0.190	KA	05-19-99
4	0.219		0.219	0.219	0.219	KA	10-20-98
6	0.219		0.219	0.219	0.219	KA	03-12-97
7	0.219		0.219	0.219	0.219	KA	03-12-97
15	0.219		0.219	0.219	0.219	KA	05-19-99
42	0.219		0.219	0.219	0.219	KA	01/05/00
40	0.220		0.220	0.220	0.220	KA	05-19-99
10	0.225		0.225	0.225	0.225	KA	05-19-99
8	0.240		0.240	0.240	0.240	KA	01/05/00
9	0.240		0.240	0.240	0.240	KA	01/05/00
41	0.240		0.240	0.240	0.240	KA	01/05/00
50	0.260		0.260	0.260	0.260	KA	05-19-99
51	0.260		0.260	0.260	0.260	KA	01/05/00
12	0.281		0.281	0.281	0.280	KA	07-18-97
13	0.281		0.281	0.281	0.281	KA	10-20-98
14	0.281		0.281	0.280	0.281	KA	03-12-97
16	0.290		0.290	0.290	0.290	KA	07-24-96
17	0.290		0.290	0.290	0.290	KA	03-10-98
18	0.290		0.290	0.290	0.290	KA	07-05-96
45	0.290		0.290	0.290	0.290	KA	01/05/00
20	0.310		0.310	0.310	0.310	KA	03-10-98
33	0.310		0.310	0.310	0.310	KA	04-14-98
35	0.320		0.320	0.320	0.320	KA	01/05/00
21	0.344		0.344	0.344	0.344	KA	03-10-98
22	0.344		0.344	0.344	0.344	KA	03/06/00
23	0.347		0.347	0.347	0.347	KA	03-10-98
24	0.375		0.375	0.375	0.375	KA	02/18/00
25	0.375		0.375	0.375	0.375	KA	03-12-96
26	0.406		0.406	0.406	0.406	KA	04-19-96
30	0.406		0.406	0.406	0.406	KA	07-20-98
47	0.415		0.415	0.415	0.415	KA	11-25-96
34	0.425		0.425	0.425	0.424	KA	06-10-97
55	0.425		0.425	0.425	0.424	KA	01/05/00
52	0.440		0.440	0.440	0.440	KA	02/27/00

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:

03/06/00


Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
53	0.440		0.440	0.440	0.440	KA	02/27/00
19	0.450		0.450	0.450	0.450	KA	04-14-98
36	0.490		0.490	0.490	0.490	KA	06-10-97
37	0.490		0.490	0.490	0.490	KA	07-05-96
38	0.495		0.495	0.495	0.495	KA	07-05-96
39	0.500		0.500	0.500	0.500	KA	07-05-96
46	0.625		0.625	0.625	0.625	KA	03-10-98
43	0.750		0.750	0.750	0.750	KA	01/05/00
49	1.060		1.060	1.060	1.060	KA	11-25-96

GEOMETRIC PITOT CALIBRATION

Caliper # XS-59
 Freshness ✓
 Post Check _____

Probe #: 7-1
 Date: 01-10-00
 Initials: KBA

①



$$\begin{aligned} z^1 &= 2^\circ \\ z^2 &= 1^\circ \\ B^1 &= 1^\circ \\ B^2 &= 1^\circ \end{aligned} \quad \begin{aligned} z^1, z^2 &= < 10^\circ \\ B^1, B^2 &= < 5^\circ \end{aligned}$$

$$F = 1.000''$$

$$\mu = 0.017''$$

$$V = 0.017''$$

$$W = 0.480''$$

$$X = 0.910''$$

$$Y = 6.211''$$

$$Z = 2.495''$$

$$D_i = 0.376''$$

$$\mu = \leq 0.1250'' (\delta \tan \mu F)$$

$$V = \leq 0.03125'' (\theta \tan \mu F)$$

$$W \geq 0''$$

$$X \geq 0.750''$$


(3/4" using 1/2" scale)

$$Y \geq 3.0''$$


$$Z \geq 2.0''$$

$$D_i \geq .1875''$$

②



③





$$1.05 \theta_1 \leq \theta < 1.50 \theta_1$$


$$p_1 = p_2$$

$$2.10 \theta_1 \leq \theta < 3.00 \theta_1$$

④




⑤




(δ, θ EXPRESSED IN DEGREES)

⑥



⑦



CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN Wet Test gas meter,
serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 10 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007
713-861-3816

2-8-96

Date

Mark Poe

Signature

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

APK-1
29-24-99
29.10

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
TPJ

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		51.445			1.9	8.4
	MIDWAY			71		94	81		
	STOP	5.000	9.49		56.283				
	DELTA *	5.000	9.15		5.238				
2	START	0.000	0		57.334			2.0	8.4
	MIDWAY			71		97	81		
	STOP	5.000	6.31		62.546				
	DELTA *	5.000	6.52		5.216				
3	START	0.000	0		63.598			3.0	8.4
	MIDWAY			71		104	81		
	STOP	5.000	5.17		68.848				
	DELTA *	5.000	5.28		5.210				
Dry Gas	START	0.150	0		68.995			0.0	1.0
Meter Leak	STOP	0.343	10:00		69.291				
Check	DELTA *	0.193	10.0		0.296				

{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = 0.0143 cfm ≤ 0.02 cfm

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	
Time (min)	9.15	6.52	5.28	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	
Ti (°F)	94	97	100	
To (°F)	81	81	81	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.238	5.216	5.210	
ΔH@ (in. H2O)	1.901	1.931	1.899	1.911
Y (Pre-test)	0.9817	0.9861	0.9875	0.9851

$$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^2$$

$$BP * (To + 460) * (Vw)^2$$

$$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$$

$$Vm * [BP+(\Delta H/13.6)] * (Tw+460)$$

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex - 1
05-12-08
29.83

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

25

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		078.374			2.4	8
	MIDWAY			75		142	83		
	STOP	6.000	7.142		084.592				
	DELTA *	6.000	7.74		6.292				
2	START	0.000	0		084.592			2.4	8
	MIDWAY			75		142	84		
	STOP	5.000	6:25		089.787				
	DELTA *	5.000	6.42		5.195				
3	START	0.000	0		089.787			2.4	8
	MIDWAY			75		143	84		
	STOP	5.000	6:25		094.974				
	DELTA *	5.000	6.42		5.187				
Dry Gas	START	0.354	0		095.357			0.0	8
Meter Leak	STOP	0.574	10:00		095.644				
Check	DELTA *	0.164	10.0		0.247				
$\{ \text{DELTA Vw (cf)} - \text{DELTA Vd (dcf)} \} / 10 \text{ (min.)} = 0.448 \text{ cfm} \leq 0.02 \text{ cfm}$									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.03	29.03	29.03	$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^2$ $BP * (To + 460) * (Vw)^2$
Time (min)	7.70	6.42	6.42	
Tw (°F)	75	75	75	
Vw (cf)	6.000	5.000	5.000	$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$
Ti (°F)	102	102	103	
To (°F)	83	84	84	
ΔH (in. H2O)	2.00	2.00	2.00	
Vm (dcf)	6.292	5.195	5.187	
Y (Pre-test)				0.9851
ΔH@ (in. H2O)	1.896	1.894	1.894	1.895
Y (Post-test)	0.9798	0.9898	0.9923	0.9873
ΔY (%)				0.2%

RECEIVED MAY 10 2000



UEC

USX Engineers
& Consultants, Inc.

May 3, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on April 25, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

<u>ANALYTE</u>	<u>METHOD</u>
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Guilyard

Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

A subsidiary of USX Corporation

USX

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 1

Customer:	CD-0020	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13753	CLR-#1BS-M26A-1A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13754	CLR-#1BS-M26A-1B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13755	CLR-#1BS-M26A-1C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13756	CLR-#1BS-M26A-1D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13757	CLR-#1BS-M26A-2A	CHLORIDE	04/19/00	*	*	*	05/02/00	29							2.0 mg/L
13758	CLR-#1BS-M26A-2B	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13759	CLR-#1BS-M26A-2C	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13760	CLR-#1BS-M26A-2D	CHLORIDE	04/19/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13761	CLR-#1BS-M26A-3A	CHLORIDE	04/20/00	*	*	*	05/02/00	26							2.0 mg/L
13762	CLR-#1BS-M26A-3B	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13763	CLR-#1BS-M26A-3C	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13764	CLR-#1BS-M26A-3D	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
13765	CLR-H2504-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable.
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.
 A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 B - TUBE D - BULK MATERIALS OR WIPES I - FILTER + TUBE

REPORT OF TEST RESULTS

DATE - 05/03/2000
 PAGE - 2

Customer: Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park Harmarville, PA 15238	CD-002D	ATTENTION: Mr. John Shimshock Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900 CUSTOMER P.O. # : 3692 SITE LOCATION : US STEEL CLAIRTON WORKS
--	---------	--

TRACKING NUMBER: 1748

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/Kg	PPM	µg/L	µg/Kg	pH	%	LOD
13766	CLR-NAOH-BLANK	CHLORIDE	04/20/00	*	*	*	05/02/00	<2.0							2.0 mg/L
															E

COMMENTS: SAMPLES ARE BLANK CORRECTED.

ANALYST : Neelam Patel Date: 5-3-00
 APPROVED: Stephanie A. Guilford Date: 5/5/00
 Stephanie A. Guilford, THIT, Project Manager
 NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable. B - TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 D - BULK MATERIALS OR WIPES I - FILTER + TUBE


ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 44-434-P; P.O. # 3692				ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS	
PROJECT NAME U.S. Steel Clariston Works									
ANALYTICAL LAB U.S. Steel Clariston Works									
DELIVER TO Sample Receiving									
COMMENTS No. 1 Battery Combustion Stack									
SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB	Chloride ion (Cl-)	Via ion chromatography	US EPA Method 814		
44-434-P-1A	4-19-00	Test #1	1	Comp.	✓			A: Impurities 1+2	
44-434-P-1B	↓	↓	1	Comp.	✓			B: Impurities 3	
44-434-P-1C	↓	↓	1	Comp.	✓			C: Impurities 4	
44-434-P-1D	↓	↓	1	Comp.	✓			D: Impurities 5	
* 44-434-P-1A - Sample Volume = 413.8 mL * 44-434-P-1B - Sample Volume = 149.3 mL * 44-434-P-1C - Sample Volume = 139.3 mL * 44-434-P-1D - Sample Volume = 157.4 mL									
44-434-P-2A	4-19-00	Test #2	1	Comp.	✓			44-434-P-2A - Sample Volume = 404.8 mL	
44-434-P-2B	↓	↓	1	Comp.	✓			44-434-P-2B - Sample Volume = 135.3 mL	
44-434-P-2C	↓	↓	1	Comp.	✓			44-434-P-2C - Sample Volume = 132.4 mL	
44-434-P-2D	↓	↓	1	Comp.	✓			44-434-P-2D - Sample Volume = 153.4 mL	
* 44-434-P-2A - Sample Volume = 404.8 mL * 44-434-P-2B - Sample Volume = 135.3 mL * 44-434-P-2C - Sample Volume = 132.4 mL * 44-434-P-2D - Sample Volume = 153.4 mL									

RELINQUISHED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME	ICE CHEST #
John P. Starnoback	4-24-00	11:00 AM	Wally G.	4-24-00	11:00 AM	
Wally G.	4-25-00	12:45 PM	John P. Starnoback	4-24-00	4:00 PM	CHEST TEMP.
						TAG #



INC.

ADV

ATS

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

NO. 1 BATTERY COMBUSTION STACK

APRIL 19 AND 20, 2000

U.S. EPA REFERENCE METHOD 26A SAMPLING

CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#1BS-M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H2SO4 - Impingers 1 & 2	29	413.8	12.00	100.0
	1B	0.1 N H2SO4 - Impinger 3	< 2.0	149.3	< 0.30	NA
	1C	0.1 N NaOH - Impinger 4	< 2.0	139.3	< 0.28	
	1D	0.1 N NaOH - Impinger 5	< 2.0	157.4	< 0.31	
2	2A	0.1 N H2SO4 - Impingers 1 & 2	29	404.8	11.74	100.0
	2B	0.1 N H2SO4 - Impinger 3	< 2.0	135.3	< 0.27	NA
	2C	0.1 N NaOH - Impinger 4	< 2.0	132.0	< 0.26	
	2D	0.1 N NaOH - Impinger 5	< 2.0	153.0	< 0.31	
3	3A	0.1 N H2SO4 - Impingers 1 & 2	26	404.2	10.51	100.0
	3B	0.1 N H2SO4 - Impinger 3	< 2.0	137.0	< 0.27	NA
	3C	0.1 N NaOH - Impinger 4	< 2.0	146.6	< 0.29	
	3D	0.1 N NaOH - Impinger 5	< 2.0	132.5	< 0.27	
Blank	Blank	0.1 N H2SO4	< 2.0			
Blank	Blank	0.1 N NaOH	< 2.0			

0.1 N H2SO4

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
(%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (<2.0) ---->

Chloride catch = 0

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST DATE: 4/19/00
TEST NO.: CLR- #1BS-M26A-1

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.51
B.	Process Gas Static Pressure (in. H2O)	-1.00
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	0.9851
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	114
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.05
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.05
K.	Average ΔH (in. H2O) variation	0.99
L.	Average Process Gas Temperature (°F)	516
M.	Average Dry Gas Meter Temperature (°F)	69
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	12.0
	Nitrogen (%)	84.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	217.4
Q.	Metered Gas Volume (dcf)	67.869

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.44	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.58	[A+(K/13.6)]
T.	Duct Area (ft.^2)	7.09E+01	[Pi*E^2/(4*144) or F*G/144]
U.	Nozzle Area (ft.^2)	1.06E-03	[Pi*H^2/(4*144)]
V.	Average Absolute Process Gas Temperature (R)	976	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	529	[M+460]
X.	Dry Gas Volume Sampled (dscf)	65.979	[Q*D*(528/W)*(S/29.92)]
Y.	H2O Vapor Condensed (scf)	10.250	[P*0.04715]
Z.	Calculated Percent H2O in Gas Stream (%)	13.4	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H2O in Gas Stream (%)	13.4	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.134		18	2.420
CO2	0.040	0.866	44	1.523
O2	0.120	0.866	32	3.324
N2	0.840	0.866	28	20.357
CO	0.000	0.866	28	0.000
H2	0.000	0.866	2	0.000
CH4	0.000	0.866	16	0.000
C2H6	0.000	0.866	30	0.000
Ar	0.000	0.866	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.62	
DD.	Average Process Gas Velocity (ft/sec)	1.83E+01	$[85.49 \cdot C \cdot [(I \cdot V) / (R \cdot CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	7.78E+04	$[DD \cdot T \cdot 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	4.14E+04	$[EE \cdot (528 / V) \cdot (R / 29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	3.58E+04	$[FF \cdot (1 - (BB / 100))]$
HH.	Isokinetic Variation (%)	103.0	$[100 \cdot V \cdot \{(0.002669 \cdot P) + (Q \cdot D \cdot S / W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0052	
JJ.	Front-Half Residue Weight (g)	0.0075	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0127	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0030	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	9.11E-01	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 4/19/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR- #1BS-M26A-1

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	12.34	
QQ.	Concentration (mg/dscm)	6.60E+00	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	8.85E-01	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.28
TT.	Concentration (mg/dscm)	<	1.49E-01 [SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	2.00E-02 [TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST DATE: 4/19/00
TEST NO.: CLR- #1BS-M26A-2

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.51
B.	Process Gas Static Pressure (in. H2O)	-1.10
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	0.9851
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	114
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.05
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.05
K.	Average ΔH (in. H2O) variation	0.89
L.	Average Process Gas Temperature (°F)	516
M.	Average Dry Gas Meter Temperature (°F)	78
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	12.5
	Nitrogen (%)	83.5
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	206.8
Q.	Metered Gas Volume (dcf)	66.020

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.43	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.58	[A+(K/13.6)]
T.	Duct Area (ft.^2)	7.09E+01	[Pi*E^2/(4*144) or F*G/144]
U.	Nozzle Area (ft.^2)	1.06E-03	[Pi*H^2/(4*144)]
V.	Average Absolute Process Gas Temperature (R)	976	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	538	[M+460]
X.	Dry Gas Volume Sampled (dscf)	63.092	[Q*D*(528/W)*(S/29.92)]
Y.	H2O Vapor Condensed (scf)	9.751	[P*0.04715]
Z.	Calculated Percent H2O in Gas Stream (%)	13.4	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H2O in Gas Stream (%)	13.4	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.134		18	2.409
CO2	0.040	0.866	44	1.524
O2	0.125	0.866	32	3.465
N2	0.835	0.866	28	20.250
CO	0.000	0.866	28	0.000
H2	0.000	0.866	2	0.000
CH4	0.000	0.866	16	0.000
C2H6	0.000	0.866	30	0.000
Ar	0.000	0.866	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.65	
DD.	Average Process Gas Velocity (ft/sec)	1.72E+01	$[85.49 \cdot C \cdot [(I \cdot V) / (R \cdot CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	7.33E+04	$[DD \cdot T \cdot 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	3.90E+04	$[EE \cdot (528/V) \cdot (R/29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	3.38E+04	$[FF \cdot (1 - (BB/100))]$
HH.	Isokinetic Variation (%)	104.5	$[100 \cdot V \cdot \{(0.002669 \cdot P) + (Q \cdot D \cdot S/W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0040	
JJ.	Front-Half Residue Weight (g)	0.0066	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0106	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0026	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	7.50E-01	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 4/19/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR- #1BS-M26A-2

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	12.07	
QQ.	Concentration (mg/dscm)	6.76E+00	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	8.54E-01	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.26	
TT.	Concentration (mg/dscm)	<	1.48E-01	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	1.87E-02	[TT*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST DATE:

4/20/00

TEST NO.: CLR-

#IBS-M26A-3

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.35
B.	Process Gas Static Pressure (in. H ₂ O)	-1.10
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	0.9851
»»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	114
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.440
I.	Average ΔP (in. H ₂ O) = [(ΔP ^{0.5}) _{avg}] ² - for flows	0.04
J.	Average ΔP (in. H ₂ O) = [(ΔP ^{0.5}) _{avg}] ² - for isokinetic	0.04
K.	Average ΔH (in. H ₂ O) variation	0.79
L.	Average Process Gas Temperature (°F)	513
M.	Average Dry Gas Meter Temperature (°F)	82
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	12.5
	Nitrogen (%)	83.5
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H ₂ O Mass Collected in Impingers (g)	203.5
Q.	Metered Gas Volume (dcf)	62.141

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.27	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.41	[A+(K/13.6)]
T.	Duct Area (ft. ²)	7.09E+01	[Pi*E ² /(4*144) or F*G/144]
U.	Nozzle Area (ft. ²)	1.06E-03	[Pi*H ² /(4*144)]
V.	Average Absolute Process Gas Temperature (R)	973	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	542	[M+460]
X.	Dry Gas Volume Sampled (dscf)	58.614	[Q*D*(528/W)*(S/29.92)]
Y.	H ₂ O Vapor Condensed (scf)	9.595	[P*0.04715]
Z.	Calculated Percent H ₂ O in Gas Stream (%)	14.1	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H ₂ O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H ₂ O in Gas Stream (%)	14.1	[Calculated %H ₂ O <= Theoretical Max. %H ₂ O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H ₂ O/100)	* Mol. Weight	= Wt./Mol
H ₂ O	0.141		18	2.532
CO ₂	0.040	0.859	44	1.512
O ₂	0.125	0.859	32	3.437
N ₂	0.835	0.859	28	20.091
CO	0.000	0.859	28	0.000
H ₂	0.000	0.859	2	0.000
CH ₄	0.000	0.859	16	0.000
C ₂ H ₆	0.000	0.859	30	0.000
Ar	0.000	0.859	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.57	
DD.	Average Process Gas Velocity (ft/sec)	1.62E+01	$[85.49 * C * [(I * V) / (R * CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	6.87E+04	$[DD * T * 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	3.65E+04	$[EE * (528 / V) * (R / 29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	3.14E+04	$[FF * (1 - (BB / 100))]$
HH.	Isokinetic Variation (%)	104.6	$[100 * V * \{(0.002669 * P) + (Q * D * S / W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0030	
JJ.	Front-Half Residue Weight (g)	0.0083	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0113	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0030	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	7.99E-01	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 4/20/00

TEST SITE: NO. 1 BATTERY COMBUSTION STACK

TEST NO.: CLR- #1BS-M26A-3

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	10.81	
QQ.	Concentration (mg/dscm)	6.51E+00	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	7.64E-01	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	< 0.29	
TT.	Concentration (mg/dscm)	< 1.77E-01	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	< 2.07E-02	[TT*0.02832*GG*60/454000]