



639 Alpha Drive
Pittsburgh, Pennsylvania 15238
Telephone (412) 967-1900
FAX (412) 967-1911

ADVANCED TECHNOLOGY SYSTEMS, INC.

Ref. Project No. 00-116-P

November 7, 2000

Mr. William C. Graeser
Manager – Environmental and Quality Assurance
U.S. Steel Clairton Works
400 State Street
Clairton, PA 15025

**RE: LETTER REPORT – HYDROCHLORIC ACID, CHLORINE GAS AND AMMONIA
GAS EMISIONS TESTING CONDUCTED AT NO. 19 BATTERY COMBUSTION
STACK ON SEPTEMBER 20, 2000**

Dear Mr. Graeser:

This letter, with attachments, constitutes the report that summarizes the results of the hydrochloric acid (HCl), chlorine gas (Cl₂) and ammonia gas (NH₃) emissions testing conducted at No. 19 Battery Combustion Stack by Advanced Technology Systems, Inc. (ATS). Three two-hour test runs were conducted on September 20, 2000 simultaneous with the compliance test program at this stack (particulate matter and visible emissions were measured as part of the compliance test program).

The test results have been summarized in the attached Table 1. Hydrochloric acid, chlorine gas and ammonia gas concentrations are listed in units of milligrams per dry standard cubic meter (mg/dscm). Hydrochloric acid, chlorine gas and ammonia gas mass emission rates are listed in units of pounds per hour (lb/hr). Table 1 also presents pertinent exhaust gas and sampling parameters including exhaust gas flow rates in units of actual cubic feet per minute (acfm), standard cubic feet per minute (scfm), and dry standard cubic feet per minute (dscfm), exhaust gas temperature (°F), and moisture content of the exhaust gas (percent by volume), gas volume sampled for each test run in units of dry standard cubic feet (dscf) and the isokinetic variation value for each test run. The isokinetic variation value is equal to the ratio of the average linear gas velocity sampled through the probe nozzle to the average exhaust gas velocity. All isokinetic variation values are between 90 percent and 110 percent, which is the acceptable range of values. Actual test sampling times have also been included in Table 1.

Hydrochloric acid, chlorine gas and ammonia gas emission testing were performed in accordance with U.S. EPA Reference Methods 1 through 4 and 26A, U.S. EPA Conditional Test Method 027 and the requirements of the Pennsylvania Department of Environmental Protection (PA DEP) Source Testing Manual (Draft Revision 3.1, May 3, 1999). Detailed information regarding the procedures used to measure the exhaust gas stream velocity and volumetric flow rate (i.e., U.S. EPA Reference Methods 1 through 4) can be found in the summary report for the compliance test program. Hydrochloric acid and chlorine gas sampling was performed in accordance with U.S. EPA Reference Method 26A. Ammonia gas sampling was performed, where possible, in accordance with U.S. EPA Conditional Test Method 027. (The test procedures specified in Method 027 were modified slightly for this test program based on the expected exhaust gas temperatures of 450°F. The modifications were made after ATS consulted with Ms. Rima Howell of the U.S. EPA, who is the pertinent contact

027. It should also be noted that the U.S. EPA had not promulgated Method 027 at the time of this test program, however, this method was apparently the only test method available from the U.S. EPA designed for measuring ammonia gas emissions from stationary sources.) Process gas samples were withdrawn isokinetically from the stack, with particulate matter collected in a glass nozzle, a heated glass-lined probe, a heated Teflon-lined flexible probe, and on a heated quartz filter. Vapor phase hydrochloric acid, chlorine gas and ammonia gas were collected in a series of chilled impingers. The impinger type and sequence is listed below:

<u>No.</u>	<u>Impinger Type</u>	<u>Contents</u>
1.	Modified Greenburg-Smith	50 mL 0.1 N sulfuric acid (for HCl and NH ₃ collection)
2.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl & NH ₃ collection)
3.	Greenburg-Smith	100 mL 0.1 N sulfuric acid (for HCl & NH ₃ collection)
4.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
5.	Modified Greenburg-Smith	100 mL 0.1 N sodium hydroxide (for Cl ₂ collection)
6.	Modified Greenburg-Smith	200 g Silica Gel

A gas volume greater than 50 dry standard cubic feet (dscf) – the minimum gas volume required by the PA DEP for the compliance test program - was sampled for each test run. The flow rate through each sample train was less than 1 dry standard cubic foot per minute as required by U.S. EPA Reference Method 26A.

Following each test run, the sample trains were processed in accordance with PA DEP requirements. Detailed information regarding the procedures used to recover the particulate matter catch (essentially U.S. EPA Reference Method 5 procedures) can be found in the summary report for the compliance test program. Following the gravimetric analysis of the impingers for moisture gain, the following four samples fractions were generated for each sample train:

<u>Fraction</u>	<u>Description</u>
A	Contents of Impinger Nos. 1 & 2 plus applicable distilled deionized water rinses (for HCl and NH ₃)
B	Contents of Impinger No. 3 plus applicable distilled deionized water rinses (for HCl and NH ₃)
C	Contents of Impinger No. 4 plus applicable distilled deionized water rinses (for Cl ₂)
D	Contents of Impinger No. 5 plus applicable distilled deionized water rinses (for Cl ₂)

For each sample train, each of the four fractions were analyzed separately as required by the PA DEP to allow for the calculation of the collection efficiency of the sample train for HCl, Cl₂ and NH₃ collection. The contents of Impinger No. 6 were discarded.

The actual test samples plus field blanks of the impinger scrubbing solutions (0.1 N sulfuric acid and 0.1 N sodium hydroxide) were submitted to the subcontract analytical laboratory for chloride ion analyses using ion chromatographic techniques in accordance with U.S. EPA Reference Method 26A. Sample Fractions A and B and the 0.1 N sulfuric acid solution field blank were also analyzed

October 20, 2000

for ammonium ion concentration using specific ion electrode analysis techniques. The analytical laboratory results showed the following:

- The chloride ion concentrations of the field blanks were less than the analytical detection limit;
- For all three test runs, the HCl collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the chloride catch of the Sample Fraction B was at most 10 percent of the chloride catch from Sample Fraction A plus Sample Fraction B);
- For all three test runs, the Cl₂ collection efficiency of the sample train could not be calculated since the chloride catches of Sample Fractions C and D were less than the analytical detection limit;
- The ammonium ion concentration of the field blank was less than the analytical detection limit; and
- For all three test runs, the NH₃ collection efficiency of the sample train was calculated to be greater than the minimum collection efficiency specified by the PA DEP (i.e., the ammonium catch of the Sample Fraction B was at most 10 percent of the ammonium catch from Sample Fraction A plus Sample Fraction B).

Copies of the field data sheets, equipment calibration data, analytical laboratory results and emissions calculations are included in the appendix.

ATS appreciates the opportunity to provide U.S. Steel with process gas testing services. If you have any questions regarding this letter report, please call Dr. Robinson Khosah or me at (412) 967-1900 or e-mail me at the following address: jshimshock@atsengineers.com.

Very truly yours,



John P. Shimshock, Ph.D.
Senior Project Scientist

Approved by:



Robinson P. Khosah, Ph.D.
Vice President
Science and Technology Division

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**

TABLE 1

**NO. 19 BATTERY COMBUSTION STACK
HYDROCHLORIC ACID, CHLORINE GAS AND AMMONIA GAS EMISSIONS DATA
SEPTEMBER 20, 2000**

		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
<u>Emissions Data</u>					
Hydrochloric Acid (HCl)					
Concentration	(mg/dscm)	9.52E+00	1.01E+01	9.42E+00	9.68E+00
Mass Emission Rate	(lb/hr)	2.09E+00	2.43E+00	2.36E+00	2.29E+00
Chlorine Gas (Cl ₂)					
Concentration	(mg/dscm)	< 2.01E-01	< 1.24E-01	< 9.70E-02	< 1.41E-01
Mass Emission Rate	(lb/hr)	< 4.42E-02	< 2.98E-02	< 2.43E-02	< 3.28E-02
Ammonia Gas (NH ₃)					
Concentration	(mg/dscm)	3.14E-01	3.64E-02	2.09E-01	1.86E-01
Mass Emission Rate	(lb/hr)	6.90E-02	8.77E-03	5.24E-02	4.34E-02
<u>Exhaust Stack Conditions</u>					
Volumetric Flow Rate	(acfm)	1.32E+05	1.46E+05	1.53E+05	1.44E+05
	(scfm)	6.93E+04	7.62E+04	7.91E+04	7.49E+04
	(dscfm)	5.87E+04	6.44E+04	6.70E+04	6.34E+04
Temperature	(°F)	525	529	535	530
Moisture Content	(%)	15.2	15.5	15.3	15.3
<u>Sampling Conditions</u>					
Test Times	(EDT)	0731 to 0950	1013 to 1222	1245 to 1453	
Sampling Time - PM *	(minutes)	120	120	120	
Sample Volume - PM **	(dscf)	68.513	77.348	84.198	
Isokinetic Variation - PM ***	(%)	91.7	94.4	98.8	

mg / dscm = milligrams per dry standard cubic meter

*: Minimum required sampling time is 2 hours (120 minutes)

**: Minimum required sample volume is 50 dscf

***: Acceptable range of values is 90.0% ≤ Isokinetic Variation ≤ 110.0%



ADVANCED TECHNOLOGY SYSTEMS, INC.

**U.S. STEEL CLAIRTON WORKS
CLAIRTON, PENNSYLVANIA**



**Hydrochloric Acid, Chlorine Gas and
Ammonia Gas Emissions Testing Conducted at
No. 19 Battery Combustion Stack
on September 20, 2000**

October 2000

APPENDIX

**Field Data Sheets, Equipment Calibration Data,
Analytical Laboratory Results and Emissions
Calculations**



ADVANCED TECHNOLOGY SYSTEMS, INC.

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST UNIT No. 19 Battery Combustion Stack
 TEST CREW JPS KLA
 PROJECT NO. 00-116-P
 TEST DATE 09-20-2000
 TEST NO. CLR-#19BS-M26A-1
 B.P. (in. Hg) 29.32
 STATIC P. (in. H2O) -1.4
 STACK DIA. (in.) 192
 CONTROL BOX NO. APEX-4
 ORIFICE FACTOR (AH@) ~ 2.003
 METER CORR. (Y) ~ 1.0023
 CALIBRATION DATE 9/20/99
 PORT SIZE & TYPE 4" Nipples
 PITOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EDT)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH Required (in. H2O) Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F) Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
A	68.3	0731	204.346	0.02	1.45	1.45	237	542	061	219	063	5 min./pt.
	48.0		207.600	0.01	0.73	0.73	250	549	063	175	051	5
	34.0		210.100	0.02	1.45	1.45	248	527	067	201	054	10
	22.7		212.700	0.01	0.73	0.73	235	518	068	218	059	15
	12.9		215.800	0.01	0.73	0.73	229	518	071	229	061	20
	4.1		217.800	0.02	1.45	1.45	225	511	073	236	062	25
		0801										30
B	68.3	0805	220.564	0.01	0.73	0.73	234	486	068	247	062	Summary
	48.0		222.800	0.01	0.73	0.73	240	502	072	249	060	5
	34.0		224.8	0.01	0.74	0.74	241	527	074	249	061	10
	22.7		227.5	0.02	1.50	1.50	240	530	076	251	061	15
	12.9		230.7	0.01	0.74	0.74	238	532	074	253	064	20
	4.1	0835	233.0	0.01	0.74	0.74	223	502	075	251	064	25
		Δ = 60		(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			30
Totals		min	def 30.954	0.013		0.977		(°F) 525	66.7			Estimates:
Test		Δ =		(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			MW =
Totals		min 120	def 69.925	0.019		1.294		(°F) 525	71.1			%H2O =

Dry Gas Composition

	Run 1	Run 2
CO2	4.5	
O2	10.5	
CO	—	
N2	85.0	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	5.00	0.005	< 0.02
After	18.00	0.005	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	513.6	431.6	59.0
2.	100 mL 0.1 N H2SO4	635.9	527.9	108.0
3.	100 mL 0.1 N H2SO4	597.2	549.6	47.6
4.	100 mL 0.1 N NaOH	574.8	507.5	67.3
5.	100 mL 0.1 N NaOH	499.0	441.7	57.3
6.	~ 200 g Silica Gel	659.6	634.4	25.2
7.				
8.				

Total = 261.4g

$$72.52$$

$$74.34$$

$$= \left[\frac{\sum \Delta P}{n} \right]^2$$

$$1.420 = 15.2$$

$$1.150 = 9.8$$

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT	U.S. Steel Clairton Works	TEST DATE	09-20-2000	CONTROL BOX NO.	APEX-4	HOT/COLD BOX NO.	7
PLANT SITE	Clairton, PA	TEST NO.	CLR-#19BS-M26A-1	ORIFICE FACTOR (ΔH@)	2.003 FILTER NO. 497-Q7Z		
TEST UNIT	No. 19 Battery Combustion Stack	B.P. (in. Hg)	29.32	METER CORR. (Y)	1.0023 PROBE NO. 10-1		
TEST CREW	DAN JPS KLA	STATIC P. (in. H2O)	-1.4	CALIBRATION DATE	9/20/99 NOZZLE DIA. (in.) 0.625		
PROJECT NO.	00-116-P	STACK DIA. (in.)	192	PORT SIZE & TYPE	4" Nipples PITOT COEF. 0.84		

Test Port	Traverse Point (in.)	Time (EDT)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
C	68.3	0838	235.300	0.01	0.74	0.74	7.0	232	548	072	067	253	064	5 min./pt.
	48.0		237.7	0.03	2.23	1.80	17.5	236	529	076	068	255	061	
	34.0		240.8	0.04	2.98	1.70	18.0	237	537	073	068	254	067	Max Hg
	22.7		244.1	0.03	2.23	1.70	18.0	239	543	072	069	256	071	
	12.9		247.5	0.03	2.23	1.70	18.0	235	544	072	070	256	074	
	4.1		250.7	0.02	1.50	1.70	18.0	232	517	073	070	256	075	
D	68.3	0920	254.169	0.02	1.50	1.50	13.0	250	495	073	071	261	070	Sunny
	48.0		257.3	0.03	2.23	1.70	18.0	246	514	077	071	257	069	5
	34.0		260.7	0.04	2.98	1.70	18.0	242	516	077	072	258	072	10
	22.7		264.1	0.03	2.23	1.70	18.0	240	512	077	073	259	074	15
	12.9		267.4	0.03	2.23	1.70	18.0	230	518	078	074	258	076	20
	4.1	0950	270.7	0.02	1.50	1.70	18.0	216	524	078	075	254	075	25
			274.271											30
														Estimates:
Page 2		Δ = 60	Δ = 38.971	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =		(Tmeter) avg =			MW = 27.5
Totals		min	def	0.027		1.612			(°F)	524.8	75.8			%H2O = 15

Dry Gas Composition			
Run 1	Run 2		
CO2			
O2			
CO			
N2			

74.6 ↑

$$= \left[\frac{\sum \Delta P_i}{n} \right]$$

System Leak Check (60 sec)			
Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)	
Before		<0.02	
After		<0.02	

Pitot Leak Check (15 sec)

Positive	Negative
Before	
After	

No.	Impinging Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~200 g Silica Gel			
7.				
8.				

4. TD = 15" Δ = 248"

1.1 - 1.1 - (2 * 2.7") = 19.4" 15.2"

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST UNIT No. 19 Battery Combustion Stack
 TEST CREW DAN JPS KSA
 PROJECT NO. 00-116-P
 TEST DATE 09-20-00
 TEST NO. CLR-#19BS-M26A-2
 B.P. (in. Hg) 29.32
 STATIC P. (in. H2O) -1.4
 STACK DIA. (in.) 192
 CONTROL BOX NO. APEX-4
 ORIFICE FACTOR (ΔH@) 2.003
 METER CORR. (Y) 1.0023
 CALIBRATION DATE 9/20/99
 PORT SIZE & TYPE 4" Nipples
 PITOT COEFF. 0.84
 HOT/COLD BOX NO. 5
 2.003 FILTER NO. 498-QT2
 1.0023 PROBE NO. 10-1
 9/20/99 NOZZLE DIA. (in.) 0.625

Test Port	Traverse Point (in.)	Time (EDT)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Required (in. H2O)	Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F)	Meter Temp. Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
A	68.3	1013	274.967	0.02	1.52	1.5	1.5	9.0	209	554	078	079	222	077	Change @ 5 min./pt.
	48.0		278.1	0.04	3.03	2.5	2.5	16.5	239	524	084	079	240	054	5 Umbilical in Sun
	34.0		282.0	0.02	1.52	1.7	1.7	9.5	249	531	084	080	246	060	10 H/C Box in Shade
	22.7		286.0	0.01	0.76	0.76	0.76	5.0	239	537	087	081	248	060	15
	12.9		288.5	0.01	0.76	0.76	0.76	5.0	217	540	089	081	250	060	20
	4.1		291.0	0.01	0.76	0.76	0.76	4.5	213	467	090	082	252	059	25
B	68.3	1046	293.222	0.02	1.52	1.50	1.50	7.5	235	488	087	082	258	056	30
	48.0		296.4	0.02	1.52	1.50	1.50	7.5	246	542	090	083	265	055	
	34.0		299.6	0.01	0.76	0.76	0.76	4.6	248	548	090	083	264	058	
	22.7		302.2	0.01	0.76	0.76	0.76	4.5	219	549	090	083	260	060	
	12.9		304.5	0.01	0.76	0.76	0.76	4.5	231	546	091	084	265	061	
	4.1		306.9	0.02	1.52	1.50	1.50	7.6	227	518	091	084	263	059	
Page 1	Δ=60		Δ=35.104	(ΔP) avg =	(ΔH) avg =					(Tstack) avg =		(Tmeter) avg =			Estimates: 310.071
Totals	min		def	0.016			1.230			528.7		84.7			MW = 27.5
Test	Δ=120		Δ=81.235	(ΔP) avg =	(ΔH) avg =					(Tstack) avg =		(Tmeter) avg =			%H2O = 15
Totals	min		def	0.0225			1.71			529		87			

Dry Gas Composition

Run 1	Run 2
CO2	
O2	
CO	
N2	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	7.0	0.007	< 0.02
After	16.5	0.019	< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before	OK	OK
After	OK	OK

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	661.3	492.1	169.2
2.	100 mL 0.1 N H2SO4	603.6	513.4	90.2
3.	100 mL 0.1 N H2SO4	568.7	551.6	17.1
4.	100 mL 0.1 N NaOH	531.6	527.7	3.9
5.	100 mL 0.1 N NaOH	574.8	573.8	1.0
6.	~ 200 g Silica Gel	616.9	598.5	18.4
7.				
8.			TOTAL	299.8

%H2O = 15.5

%H2O = 9.4

HIGH FLOW SOURCE SAMPLING DATA SHEET

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST UNIT No. 19 Battery Combustion Stack
 TEST CREW DAN JFS KJA
 PROJECT NO. 00-116-P
 TEST DATE 09-20-00
 TEST NO. CLR-#19BS-M26A-2
 B.P. (in. Hg) 29.32
 STATIC P. (in. H2O) -1.4
 STACK DIA. (in.) 192
 CONTROL BOX NO. APEX-4
 ORIFICE FACTOR (AH@) 2.003
 METER CORR. (Y) 1.0023
 CALIBRATION DATE 9/20/99
 PORT SIZE & TYPE 4" Nipples PITOT COEF. 0.84
 HOT/COLD BOX NO. 5
 2.003 FILTER NO. 498-QT2
 1.0023 PROBE NO. 10-1
 9/20/99 NOZZLE DIA. (in.) 0.625

Test Port	Traverse Point (in.)	Time (EDT)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH		Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.		Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)				In (°F)	Out (°F)			
C	68.3	1118	310.071	0.03	2.27	2.3	12.4	241	518	089	084	247	059	5 min./pt.
	48.0		314.1	0.03	2.27	2.3	12.4	242	542	089	084	240	058	
	34.0		318.0	0.04	3.07	2.9	16.0	239	550	090	084	233	059	
	22.7		322.3	0.03	2.27	2.3	12.5	236	556	089	084	241	060	
	12.9		326.4	0.02	1.54	1.6	8.5	218	560	091	085	253	063	
	4.1		330.1	0.02	1.54	1.5	8.0	204	516	093	085	244	064	
D	68.3	1152	333.281	0.02	1.54	1.5	8.0	227	488	089	085	244	064	Windy & Sunny
	48.0		336.1	0.03	2.27	2.3	12.5	228	530	091	085	234	063	
	34.0		339.9	0.03	2.27	2.3	12.5	242	532	091	085	240	065	
	22.7		344.1	0.04	3.07	2.9	16.5	236	532	092	086	222	068	
	12.9		348.3	0.04	3.07	2.9	16.5	225	539	089	086	228	075	
	4.1	1222	352.7	0.02	1.54	1.6	8.5	215	473	089	086	217	072	
			356.202											
Page 2	Δ = 60	min	Δ = 46.131	ΔP avg =	ΔH avg =				(Tstack) avg =		(Tmeter) avg =			Estimates:
Totals			def	0.029		2.19			528 (°F)		88 (°F)			MW = 27.5 %H2O = 15

Dry Gas Composition

	Run 1	Run 2
CO2	4%	
O2	11%	
CO		
N2	85%	

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before			< 0.02
After			< 0.02

Pitot Leak Check (15 sec)

	Positive	Negative
Before		
After		

Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 1 of 2

CLIENT U.S. Steel Clairton Works PLANT SITE Clairton, PA TEST DATE 09-20-2000 CONTROL BOX NO. APEX-4 HOT/COLD BOX NO. 8
 TEST UNIT No. 19 Battery Combustion Stack TEST NO. CLR-#19BS-M26A-3 ORIFICE FACTOR (ΔH@) 2.003 FILTER NO. 462 Q7Z
 TEST CREW JAN 15 KA B.P. (in. Hg) 29.32 METER CORR. (Y) 1.0023 PROBE NO. 10-1
 STACK DIA. (in.) 192 PORT SIZE & TYPE 4" Nipples PITOT COEFF. 0.84
 STATIC P. (in. H2O) -1.40 CALIBRATION DATE 9/20/99 NOZZLE DIA. (in.) 0.625

Test Port	Traverse Point (in.)	Time (EDT)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp.	Filter Temp. (°F)	Exit Temp. (°F)	Comments
					Required (in. H2O)	Actual (in. H2O)			In (°F)	Out (°F)		
A	68.3	1245	356.928	0.02	1.55	1.55	246	520	85	85	65	5 min./pt.
	48.0			0.02	1.55	1.55	246	530	90	85	65	
	34.0			0.02	1.54	1.54	246	538	92	86	65	
	22.7			0.02	1.54	1.54	246	539	94	86	60	
	12.9			0.02	1.54	1.54	246	540	94	87	60	
	4.1	1215	376.084	0.01	0.80	0.80	245	500	93	87	60	
B	68.3	1317	376.084	0.03	2.35	2.35	245	519	92	87	57	
	48.0			0.02	1.57	1.57	245	540	93	88	57	
	34.0			0.02	1.57	1.57	244	550	94	88	53	
	22.7			0.02	1.52	1.52	243	554	95	88	53	
	12.9			0.01	0.76	0.76	243	546	96	88	53	
	4.1	1347	396.223	0.02	1.53	1.53	243	500	96	88	53	
Page 1	Δ = 60	min	Δ = 39.295	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			
Totals		def		0.019		1.225		531	90			Estimates:
Test	Δ = 120	min	Δ = 89.052	(ΔP) avg =	(ΔH) avg =			(Tstack) avg =	(Tmeter) avg =			MW = 27.5
Totals		def		0.025		1.82		535	91			%H2O = 15

Dry Gas Composition

Run 1	Run 2
CO2 4.5%	
O2 11%	
CO -	
N2 84.5%	

System Leak Check (60 sec)

Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before 5.00	0.007	<0.02
After 12.00	0.010	<0.02

$$= \frac{\sum \Delta P_i}{n}$$

Pitot Leak Check (15 sec)

Positive	Negative
Before OK	OK
After 19K	OK

$$\% H_2O = 15.3$$

$$\% H_2O = 15.0$$

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4	585.8	417.3	168.5
2.	100 mL 0.1 N H2SO4	602.3	491.3	111.0
3.	100 mL 0.1 N H2SO4	545.5	540.1	5.4
4.	100 mL 0.1 N NaOH	509.4	508.2	1.2
5.	100 mL 0.1 N NaOH	555.9	548.0	7.9
6.	~200 g Silica Gel	672.2	644.5	27.7
7.				
8.				
			TOTAL	321.7 g

HIGH FLOW SOURCE SAMPLING DATA SHEET

Page 2 of 2

CLIENT U.S. Steel Clairton Works
 PLANT SITE Clairton, PA
 TEST UNIT No. 19 Battery Combustion Stack
 TEST CREW DAN, JS, KA
 PROJECT NO. 00-116-P
 TEST DATE 09-20-2000
 TEST NO. CLR-#19BS-M26A-3
 B.P. (in. Hg) 29.32
 STATIC P. (in. H2O) -1.40
 CONTROL BOX NO. 8
 ORIFICE FACTOR (AH@) 2.003
 METER CORR. (Y) 1.0023
 CALIBRATION DATE 9/20/99 NOZZLE DIA. (in.) 0.625
 PORT SIZE & TYPE 4" Nipples PITOT COEF. 0.84

Test Port	Traverse Point (in.)	Time (EDT)	DGM Reading (def)	Pitot ΔP (in. H2O)	Orifice ΔH Required (in. H2O)	Actual (in. H2O)	Vacuum (in. Hg)	Probe Temp. (°F)	Stack Temp. (°F)	Meter Temp. In (°F) Out (°F)	Filter Temp. (°F)	Exit Temp. (°F)	Comments
C	68.3	1350	396.223	0.04	3.13	3.13	12.0	244	525	82	243	52	5 min./pt.
	48.0			0.04	3.13	3.13	12.0	244	551	92	243	52	
	34.0			0.04	3.13	3.13	12.0	243	557	92	244	51	
	22.7			0.04	3.13	3.13	12.0	244	558	92	243	51	
	12.9			0.03	2.25	2.25	9.0	243	562	92	244	51	
	4.1	1420	422.183	0.03	2.25	2.25	9.0	243	521	95	244	51	
D	68.3	1423	422.183	0.03	2.25	2.25	9.0	245	524	91	244	50	
	48.0			0.03	2.25	2.25	9.0	245	533	94	244	50	
	34.0			0.03	2.32	2.32	9.0	245	536	95	244	50	
	22.7			0.03	2.32	2.32	9.0	244	535	93	244	50	
	12.9			0.02	1.57	1.57	7.0	244	544	93	243	50	
	4.1	1453	445.980	0.02	1.57	1.57	7.0	243	521	93	243	49	
Page 2	Δ = 60		Δ = 49.757	(ΔP) avg =	(ΔH) avg =				(Tstack) avg =	(Tmeter) avg =			Estimates: MW = 27.5 %H2O = 15
Totals			def	0.031					539 (°F)	91 (°F)			

Dry Gas Composition

	Run 1	Run 2
CO2		
O2		
CO		
N2		

System Leak Check (60 sec)

	Vacuum (in. Hg)	DGM Rate (cfm)	Required (cfm)
Before	29.32	0.006	< 0.02
After	29.32	0.006	< 0.02

No. Impinger Contents

No.	Impinger Contents	Final	Initial	Δ (g)
1.	50 mL 0.1 N H2SO4			
2.	100 mL 0.1 N H2SO4			
3.	100 mL 0.1 N H2SO4			
4.	100 mL 0.1 N NaOH			
5.	100 mL 0.1 N NaOH			
6.	~ 200 g Silica Gel			
7.				
8.				

Pitot Leak Check (15 sec)

	Positive	Negative
Before	29.32	0.006
After	29.32	0.006

$$\Delta = \frac{\sum \Delta P_i}{n}$$

APEX GLASS NOZZLE CALIBRATION DATA SHEET

Printed:


09/18/00

Nozzle No.	Size (inches)					Calibrated	
	Avg.		A	B	C	By	Date
52	0.440		0.440	0.440	0.440	KA	05/01/00
19	0.450		0.450	0.450	0.450	KA	04-14-98
36	0.490		0.490	0.490	0.490	KA	06-10-97
37	0.490		0.490	0.490	0.490	KA	07-05-96
38	0.495		0.495	0.495	0.495	KA	07-05-96
39	0.500		0.500	0.500	0.500	KA	09/18/00
46	0.625		0.625	0.625	0.625	KA	09/18/00
43	0.750		0.750	0.750	0.750	KA	01/05/00

Caliper # XFS-59
 Preset # _____
 Post Count _____

Probe #: 10-1
 Date: 02-10-00
 Initials: KBA

①



$$\alpha_1 = 1^\circ$$

$$\alpha_2 = 2^\circ$$

$$\alpha_1, \alpha_2 < 10^\circ$$

$$\beta_1 = 1^\circ$$

$$\beta_2 = 1^\circ$$

$$\beta_1, \beta_2 < 5^\circ$$

$$F = 0.975''$$

$$\mu = 0.017''$$

$$\mu \leq 0.1250'' (\delta \tan \alpha \times F \times \mu)$$

$$V = 0.000$$

$$V \leq 0.03125'' (\theta \tan \alpha \times F \times V)$$

$$W = 0.195''$$

$$W \geq 0''$$

$$X = 0.321''$$

$$X \geq 0.750''$$

(3/4" using 1/2" scale)

$$Y = 6.215''$$

$$Y \geq 3.0''$$


$$Z = 2.417''$$

$$Z \geq 2.0''$$


$$D_1 = 0.376''$$

$$D_1 > .1875''$$

②



③




$$1.05 \alpha_1 \leq \alpha_2 \leq 1.50 \alpha_1$$

$$P_1 = P_2$$


$$2.10 \alpha_1 \leq \alpha_2 \leq 3.00 \alpha_1$$

④




α, θ EXPRESSED IN DEGREES


⑤



⑥



⑦



CERTIFICATE OF CALIBRATION

This certifies that your AL-20 AMERICAN WET TEST gas meter,

serial no. P-1146

has been calibrated with a bell prover.

AMERICAN 10 foot, # 3157

It is traceable to the N.I.S.T., reference no. 1249811.

Calibration by Carl Poe Co., Inc.

99 Reinerman Houston, TX 77007

713-861-3816

2-8-96

Date:

Mark Poe

Signature

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

AP-4
89-24-99
29.17

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
JPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		318.302			1.0	8.0
	MIDWAY			71		88	78		
	STOP	5.000	9.20		323.417				
	DELTA *	5.000	9.33		5.115				
2	START	0.000	0		324.438			2.0	8.0
	MIDWAY			71		92	79		
	STOP	5.000	6.39		329.522				
	DELTA *	5.000	6.65		5.084				
3	START	0.000	0		331.550			3.0	8.0
	MIDWAY			71		95	80		
	STOP	5.000	5.25		336.644				
	DELTA *	5.000	5.42		5.094				
Dry Gas	START	0.050	0		336.713			0.0	1.0
Meter Leak	STOP	0.358	10:00		337.112				
Check	DELTA *	0.308	10.0		0.359				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.001</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):

✓ Inclined Manometers

 Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.10	29.10	29.10	$\Delta H@ = 0.0317 * \Delta H * [(Tw+460) * Time]^{1/2}$ $BP * (To + 460) * (Vw)^{1/2}$
Time (min)	9.33	6.65	5.42	
Tw (°F)	71	71	71	
Vw (cf)	5.000	5.000	5.000	$Y = \frac{Vw * BP * [(Ti-460-To-460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$
Ti (°F)	88	92	95	
To (°F)	78	79	80	
ΔH (in. H2O)	1.00	2.00	3.00	
Vm (dcf)	5.115	5.084	5.094	
ΔH@ (in. H2O)	1.988	2.016	2.005	2.003
Y (Pre-test)	0.9971	1.0053	1.0044	1.0023

DRY GAS METER CALIBRATION DATA SHEET

CONTROL BOX NO.
CALIBRATION DATE
BAROMETRIC PRESSURE (in. Hg)

Apex-4
10-20-00
29.24

CHECK PRE-TEST
ONE: POST-TEST
CALIBRATION OFFICER

✓
JPS

RUN NO.		WET TEST METER			DRY GAS METER				
		Gas Volume Vw (cf)	Elapsed Time (min.)	Meter Temp. Tw (°F)	Gas Volume Vd (dcf)	Inlet Temp. Ti (°F)	Outlet Temp. To (°F)	Orifice Diff. Pres. ΔH (in. H2O)	Vacuum (in. H2O)
1	START	0.000	0		752.023			1.5	18.0
	MIDWAY			67		83	74		
	STOP	5.000	7.43		757.099				
	DELTA *	5.000	7.72		5.076				
2	START	0.000	0		757.099			1.5	18.0
	MIDWAY			67		83	74		
	STOP	5.000	7.43		762.172				
	DELTA *	5.000	7.72		5.073				
3	START	0.000	0		762.172			1.5	18.0
	MIDWAY			67		83	75		
	STOP	5.000	7.43		767.253				
	DELTA *	5.000	7.72		5.081				
Dry Gas	START	0.130	0		767.398			0.0	18.0
Meter Leak	STOP	0.302	10:00		767.658				
Check	DELTA *	0.172	10.0		0.260				
{DELTA Vw (cf) - DELTA Vd (dcf)} / 10 (min.) = <u>0.0038</u> cfm ≤ 0.02 cfm									

*: Express final elapsed time in decimal format

Differential Pressure Gauges (check one):



Inclined Manometers

_____ Magnehelic Gauges

	Run #1	Run #2	Run #3	Avg.
BP (in. Hg)	29.24	29.24	29.24	$\Delta H@ = \frac{0.0317 * \Delta H * [(Tw+460) * Time]^2}{BP * (To + 460) * (Vw)^2}$
Time (min)	7.72	7.72	7.72	
Tw (°F)	67	67	67	
Vw (cf)	5.000	5.000	5.000	$Y = \frac{Vw * BP * [(Ti+460+To+460)/2]}{Vm * [BP+(\Delta H/13.6)] * (Tw+460)}$
Ti (°F)	83	83	83	
To (°F)	74	74	75	
ΔH (in. H2O)	1.50	1.50	1.50	
Vm (dcf)	5.076	5.073	5.081	
Y (Pre-test)				1.0023
ΔH@ (in. H2O)	2.016	2.016	2.012	2.015
Y (Post-test)	1.0027	1.0033	1.0027	1.0029
ΔY (%)				0.1%



UEC

USX Engineers
& Consultants, Inc.

October 4, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on September 26, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

<u>ANALYTE</u>	<u>METHOD</u>
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,

Stephanie A. Guilyard

Stephanie A. Guilyard, IHIT, Project Manager

Enclosures

USX Engineers & Consultants Inc.

IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 10/03/2000
 PAGE - 1

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park Harmarville, PA 15238		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900 CUSTOMER P.O. # : 3858 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 4156 A

DEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/kg	PPM	µg/L	µg/kg	pH	±	LOD
35806	CLR-19BS-M26A-3A	CHLORIDE	09/20/00	*	*	*	09/29/00	47							2.0 mg/L
35807	CLR-19BS-M26A-3B	CHLORIDE	09/20/00	*	*	*	09/29/00	3.1							2.0 mg/L
35808	CLR-19BS-M26A-3C	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35809	CLR-19BS-M26A-3D	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35810	CLR-H2SO4-BLK	CHLORIDE	09/21/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35811	CLR-NAOH-BLK	CHLORIDE	09/21/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35812	CLR-19BS-M26A-1A	CHLORIDE	09/20/00	*	*	*	09/29/00	47							2.0 mg/L
35813	CLR-19BS-M26A-1B	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35814	CLR-19BS-M26A-1C	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35815	CLR-19BS-M26A-1D	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35816	CLR-19BS-M26A-2A	CHLORIDE	09/20/00	*	*	*	09/29/00	51							2.0 mg/L
35817	CLR-19BS-M26A-2B	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L
35818	CLR-19BS-M26A-2C	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0							2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable. A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted. D - BULK MATERIALS OR WIPES I - FILTER + TUBE

USX Engineers & Consultants Inc.

IH & Environmental Laboratories
4000 Tech Center Drive
Monroeville, PA 15146
PHONE: (412) 825-2400 FAX: (412) 825-2407
AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 10/03/2000
PAGE - 2

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RDC Park Harmarville, PA 15238		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900 CUSTOMER P.O. # : 3858 SITE LOCATION : US STEEL CLAIRTON WORKS

TRACKING NUMBER: 4156 A

UIC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	AIR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	PPM	µg/L	µg/Kg	pH	%	LOD
35819	CLR-19BS-M26A-2D	CHLORIDE	09/20/00	*	*	*	09/29/00	<2.0						2.0 mg/L

COMMENTS: SAMPLES ARE BLANK CORRECTED.

ANALYST :

APPROVED:

Stephanie A. Guilyard
Date: 10-2-00
Date: 10/5/00

Stephanie A. Guilyard, IHIT, Project Manager

NOTES: * = Information not supplied by client. < = less than.
= Information not requested by client. N/A = Not Applicable. B - TUBE
Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted.

A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
D - BULK MATERIALS OR WIPES I - FILTER + TUBE



UEC
USX Engineers
& Consultants, Inc.

RECEIVED NOV 02 2000

October 9, 2000

Advanced Technology Systems, Inc.
ATTN: Mr. John Shimshock
639 Alpha Drive
RIDC Park
Harmarville, PA 15238

Attached are the analytical result(s) of the analysis on sample(s) submitted to the UEC Laboratories on September 26, 2000. Should you have any questions regarding this report, please contact us. An invoice will be issued shortly.

These results are submitted pursuant to USX Engineers & Consultants, Inc.'s current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions, and no responsibility or liability is assumed for the manner in which the results are used or interpreted.

The results were derived with the following methods.

ANALYTE	METHOD
AMMONIUM-WATER	EPA 350.2 (MOD)
CHLORIDE	EPA 26A

We appreciate the opportunity to be of service and look forward to our continued assistance to you.

NOTE: Samples will be stored for only one month following the report date.

Sincerely,


Stephanie A. Guilyard, ~~PHIT~~, Project Manager

Enclosures

USX Engineers & Consultants Inc.
 IH & Environmental Laboratories
 4000 Tech Center Drive
 Monroeville, PA 15146
 PHONE: (412)825-2400 FAX: (412)825-2407
 AIHA Accreditation #322

REPORT OF TEST RESULTS

DATE - 10/05/2000
 PAGE - 1

Customer:	CD-002D	ATTENTION: Mr. John Shimshock
Advanced Technology Systems, Inc. 639 Alpha Drive RIOC Park		Work Requested by : Mr. John Shimshock Phone No. : 412-967-1900
Harmarville, PA 15238		CUSTOMER P.O. # : 3858 SITE LOCATION : US STEEL CLAIRTON WORKS
TRACKING NUMBER: 4156		

UEC ID	CLIENT ID	ANALYTE	DATE SAMPLED	SAMPLE TIME (min)	PUMP RATE (LPM)	ATR VOL. SAMPLED (L)	ANALYSIS DATE	mg/L	mg/kg	PPM	µg/L	µg/kg	pH	%	LOD
35806	CLR-19BS-M26A-3A	AMMONIUM-WATER	09/20/00	*	*	*	09/26/00			1.1					0.1
35807	CLR-19BS-M26A-3B	AMMONIUM-WATER	09/20/00	*	*	*	09/26/00			0.2					0.1
35810	CLR-H2S04-BLK	AMMONIUM-WATER	09/21/00	*	*	*	09/26/00			< 0.1					0.1
35812	CLR-19BS-M26A-1A	AMMONIUM-WATER	09/20/00	*	*	*	09/26/00			1.6					0.1
35813	CLR-19BS-M26A-1B	AMMONIUM-WATER	09/20/00	*	*	*	09/26/00			0.2					0.1
35816	CLR-19BS-M26A-2A	AMMONIUM-WATER	09/20/00	*	*	*	09/26/00			0.2					0.1
35817	CLR-19BS-M26A-2B	AMMONIUM-WATER	09/20/00	*	*	*	09/26/00			< 0.1					0.1

COMMENTS: REVISION: Results for samples PRN35806 and PRN35807 have been corrected. Please note changes to these samples.

ANALYST: James J. Miller Date: 10-5-2000
 APPROVED: Stephanie Osuliyard Date: 10/6/00
 Stephanie A. Gulliard, IHIT, Project Manager

NOTES: * = Information not supplied by client. < = less than.
 # = Information not requested by client. N/A = Not Applicable. A - FILTER OR SINGLE STAGE MONITOR C - TUBE OR 2 STAGE MONITOR E - LIQUIDS OR SOLIDS J - FILTER + TUBE
 Time, flow rate and/or sample volume data are based on client supplied information, unless otherwise noted. D - BULK MATERIALS OR WIPES I - FILTER + TUBE

RECEIVED NOV 02 2000

Legend:

Work Requested by : Mr. John Shimshock
Phone No. : 412-967-1900
CUSTOMER P.O. # : 3858
SITE LOCATION

ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.
639 ALPHA DRIVE, R.I.D.C. PARK
PITTSBURGH, PA 15238
(412)967-1900 FAX (412)967-1911

CHAIN OF CUSTODY RECORD

PROJECT NUMBER 44 116-P ; P.O. # 3858		ANALYSES TO BE CONDUCTED				REMARKS OR OBSERVATIONS
PROJECT NAME US. Steel Clinton Works	ANALYTICAL LAB USE JH and Environmental Laboratories	DELIVER TO Sample Receiving	COMMENTS	Legend:		
No. A Battery Combustion Stack		SAMPLE IDENTIFICATION NUMBER	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	NUMBER OF CONTAINERS	COMPOSITE OR GRAB
CLE-#1985-N26A-3A	09-20-04	1245	→	1	Comp.	✓
CLE-#1985-N26A-3B	↓	1453 EDT		1	↓	✓
CLE-#1985-N26A-3C	↓	↓		1	↓	✓
CLE-#1985-N26A-3D	↓	↓		1	↓	✓
CLE-#1985-N26A-3E	09-21-04	1600 EDT		1	Grab	✓
CLE-N26A-3F	↓	↓		1	↓	✓
Legend: A = Impinger 1+2 B = Impinger 3 C = Impinger 4 D = Impinger 5						
REMARKS OR OBSERVATIONS 456.1ml 129.3ml 115.7ml 123.4ml						
ANALYSES TO BE CONDUCTED ice chromatography ice chromatography ice chromatography						
RECEIVED BY (SIGNATURE) John P. Stumback 9-25-04 1515 EDT						
RELINQUISHED BY (SIGNATURE) John P. Stumback 9-26-04 9:25 am						
DATE 09-25-04 1515						
TIME 1515 8:15 PM						
ICE CHEST # 1						
TAG #						

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: NO. 19 BATTERY COMBUSTION STACK

TEST DATE: 9/20/00
TEST NO.: CLR- #19BS-M26A-1

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.32
B.	Process Gas Static Pressure (in. H2O)	-1.40
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	192
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.625
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.019
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.019
K.	Average ΔH (in. H2O) variation	1.29
L.	Average Process Gas Temperature (°F)	525
M.	Average Dry Gas Meter Temperature (°F)	71
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.5
	Oxygen (%)	10.5
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	261.4
Q.	Metered Gas Volume (dscf)	69.925

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.22	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.41	[A+(K/13.6)]
T.	Duct Area (ft.^2)	2.01E+02	[$\pi * E^2 / (4 * 144)$ or $F * G / 144$]
U.	Nozzle Area (ft.^2)	2.13E-03	[$\pi * H^2 / (4 * 144)$]
V.	Average Absolute Process Gas Temperature (R)	985	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	531	[M+460]
X.	Dry Gas Volume Sampled (dscf)	68.513	[$Q * D * (528/W) * (S/29.92)$]
Y.	H2O Vapor Condensed (scf)	12.325	[$P * 0.04715$]
Z.	Calculated Percent H2O in Gas Stream (%)	15.2	[$100 * Y / (X+Y)$]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H2O in Gas Stream (%)	15.2	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.152		18	2.744
CO2	0.045	0.848	44	1.678
O2	0.105	0.848	32	2.848
N2	0.850	0.848	28	20.171
CO	0.000	0.848	28	0.000
H2	0.000	0.848	2	0.000
CH4	0.000	0.848	16	0.000
C2H6	0.000	0.848	30	0.000
Ar	0.000	0.848	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.44
DD.	Average Process Gas Velocity (ft/sec)	1.10E+01 [85.49*C*[(I*V)/(R*CC)]^0.5]
EE.	Process Gas Volumetric Flow Rate (acfm)	1.32E+05 [DD*T*60]
FF.	Process Gas Volumetric Flow Rate (scfm)	6.93E+04 [EE*(528/V)*(R/29.92)]
GG.	Process Gas Volumetric Flow Rate (dscfm)	5.87E+04 [FF*(1-(BB/100))]
HH.	Isokinetic Variation (%)	91.7 [100*V*{((0.002669*P)+(Q*D*S/W))}/

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0109
JJ.	Front-Half Residue Weight (g)	0.0295
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000
LL.	Total Weight (g)	0.0404 [II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0091 [(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	4.58E+00 [NN*GG*60/7000]

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

NO. 19 BATTERY COMBUSTION STACK

SEPTEMBER 20, 2000

U.S. EPA CONDITIONAL TEST METHOD 027 SAMPLING

CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#19BS -M26A-)	Sample Type	Ammonium Conc. (mg / L)	Sample Volume (mL)	Ammonium Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H2SO4 - Impingers 1 & 2	1.6	382.3	0.61	94.5
	1B	0.1 N H2SO4 - Impinger 3	0.2	167.1	0.03	
2	2A	0.1 N H2SO4 - Impingers 1 & 2	0.2	421.9	0.08	100.0
	2B	0.1 N H2SO4 - Impinger 3	< 0.1	136.4	< 0.01	
3	3A	0.1 N H2SO4 - Impingers 1 & 2	1.1	456.1	0.50	94.8
	3B	0.1 N H2SO4 - Impinger 3	0.2	129.3	0.03	
Blank Blank		0.1 N H2SO4	< 0.1			

0.1 N H2SO4

Collection Eff. = $100 * \{1 - [\text{XB Ammonium Catch (mg)} / \text{XA Ammonium Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

For ammonium concentrations less than the analytical detection limit (< 0.1) ---->

Ammonium catch = 0

U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
 NO. 19 BATTERY COMBUSTION STACK
 SEPTEMBER 20, 2000
 U.S. EPA REFERENCE METHOD 26A SAMPLING
 CALCULATION OF THE IMPINGER COLLECTION EFFICIENCIES

Test No.	Sample ID (CLR-#19BS -M26A-)	Sample Type	Chloride Conc. (mg / L)	Sample Volume (mL)	Chloride Catch (mg)	Collection Efficiency (%)
1	1A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	47	382.3	17.97	100.0
	1B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	167.1	< 0.33	
	1C	0.1 N NaOH - Impinger 4	< 2.0	195.3	< 0.39	NA
	1D	0.1 N NaOH - Impinger 5	< 2.0	83.9	< 0.17	
2	2A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	51	421.9	21.52	100.0
	2B	0.1 N H ₂ SO ₄ - Impinger 3	< 2.0	136.4	< 0.27	
	2C	0.1 N NaOH - Impinger 4	< 2.0	135.3	< 0.27	NA
	2D	0.1 N NaOH - Impinger 5	< 2.0	128.0	< 0.26	
3	3A	0.1 N H ₂ SO ₄ - Impingers 1 & 2	47	456.1	21.44	98.1
	3B	0.1 N H ₂ SO ₄ - Impinger 3	3.1	129.3	0.40	
	3C	0.1 N NaOH - Impinger 4	< 2.0	115.7	< 0.23	NA
	3D	0.1 N NaOH - Impinger 5	< 2.0	123.0	< 0.25	
Blank	Blank	0.1 N H ₂ SO ₄	< 2.0			
Blank	Blank	0.1 N NaOH	< 2.0			

0.1 N H₂SO₄

Collection Eff. = $100 * \{1 - [\text{XB Chloride Catch (mg)} / \text{XA Chloride Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

0.1 N NaOH

Collection Eff. = $100 * \{1 - [\text{XD Chloride Catch (mg)} / \text{XC Chloride Catch (mg)}]\}$
 (%) where X = 1, 2 or 3

For chloride concentrations less than the analytical detection limit (< 2.0) ---->
 Chloride catch = 0

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 9/20/00

TEST SITE: NO. 19 BATTERY COMBUSTION STACK

TEST NO.: CLR- #19BS-M26A-1

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	18.47	
QQ.	Concentration (mg/dscm)	9.52E+00	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.09E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.39	
TT.	Concentration (mg/dscm)	<	2.01E-01	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	4.42E-02	[TT*0.02832*GG*60/454000]

Ammonia Gas Acid (corrected for blank)

VV.	Total Catch (mg)		0.61	
WW.	Concentration (mg/dscm)		3.14E-01	[VV/(X*0.02832)]
XX.	Mass Flow Rate (lb/hr)		6.90E-02	[WW*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: NO. 19 BATTERY COMBUSTION STACK

TEST DATE: 9/20/00
TEST NO.: CLR- #19BS-M26A-2

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.32
B.	Process Gas Static Pressure (in. H2O)	-1.40
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	192
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.625
I.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for flows	0.023
J.	Average ΔP (in. H2O) = $[(\Delta P^{0.5})_{avg}]^2$ - for isokinetic	0.023
K.	Average ΔH (in. H2O) variation	1.71
L.	Average Process Gas Temperature (°F)	529
M.	Average Dry Gas Meter Temperature (°F)	87
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.0
	Oxygen (%)	11.0
	Nitrogen (%)	85.0
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H2O Mass Collected in Impingers (g)	299.8
Q.	Metered Gas Volume (dcf)	81.235

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.22	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.45	[A+(K/13.6)]
T.	Duct Area (ft.^2)	2.01E+02	[Pi*E^2/(4*144) or F*G/144]
U.	Nozzle Area (ft.^2)	2.13E-03	[Pi*H^2/(4*144)]
V.	Average Absolute Process Gas Temperature (R)	989	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	547	[M+460]
X.	Dry Gas Volume Sampled (dscf)	77.348	[Q*D*(528/W)*(S/29.92)]
Y.	H2O Vapor Condensed (scf)	14.136	[P*0.04715]
Z.	Calculated Percent H2O in Gas Stream (%)	15.5	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H2O in Gas Stream (%) (empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H2O in Gas Stream (%)	15.5	[Calculated %H2O <= Theoretical Max. %H2O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H2O/100)	* Mol. Weight	= Wt./Mol
H2O	0.155		18	2.781
CO2	0.040	0.845	44	1.488
O2	0.110	0.845	32	2.976
N2	0.850	0.845	28	20.123
CO	0.000	0.845	28	0.000
H2	0.000	0.845	2	0.000
CH4	0.000	0.845	16	0.000
C2H6	0.000	0.845	30	0.000
Ar	0.000	0.845	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.37
DD.	Average Process Gas Velocity (ft/sec)	1.21E+01 [85.49*C*[(I*V)/(R*CC)]^0.5]
EE.	Process Gas Volumetric Flow Rate (acfm)	1.46E+05 [DD*T*60]
FF.	Process Gas Volumetric Flow Rate (scfm)	7.62E+04 [EE*(528/V)*(R/29.92)]
GG.	Process Gas Volumetric Flow Rate (dscfm)	6.44E+04 [FF*(1-(BB/100))]
HH.	Isokinetic Variation (%)	94.4 [100*V*{((0.002669*P)+(Q*D*S/W))} /

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0086
JJ.	Front-Half Residue Weight (g)	0.0315
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000
LL.	Total Weight (g)	0.0401 [II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0080 [(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	4.41E+00 [NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA

TEST DATE: 9/20/00

TEST SITE: NO. 19 BATTERY COMBUSTION STACK

TEST NO.: CLR- #19BS-M26A-2

Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	22.12	
QQ.	Concentration (mg/dscm)	1.01E+01	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.43E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.27	
TT.	Concentration (mg/dscm)	<	1.24E-01	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	2.98E-02	[TT*0.02832*GG*60/454000]

Ammonia Gas Acid (corrected for blank)

VV.	Total Catch (mg)		0.08	
WW.	Concentration (mg/dscm)		3.64E-02	[VV/(X*0.02832)]
XX.	Mass Flow Rate (lb/hr)		8.77E-03	[WW*0.02832*GG*60/454000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
 TEST SITE: NO. 19 BATTERY COMBUSTION STACK

TEST DATE: 9/20/00
 TEST NO.: CLR- #19BS-M26A-3

Input Parameters (excluding analytical data)

A.	Barometric Pressure (in. Hg)	29.32
B.	Process Gas Static Pressure (in. H ₂ O)	-1.40
C.	Pitot Tube Coefficient	0.84
D.	Dry Gas Meter Calibration Factor	1.0023
»»»	Is the Duct Round (Y/N)?	Y
E.	Duct Diameter (in.) - for round duct	192
F.	Duct Width (in.) - for rectangular duct	0
G.	Duct Depth (in.) - for rectangular duct	0
H.	Nozzle Diameter (in.)	0.625
I.	Average ΔP (in. H ₂ O) = [(ΔP ^{0.5} avg)] ² - for flows	0.025
J.	Average ΔP (in. H ₂ O) = [(ΔP ^{0.5} avg)] ² - for isokinetic	0.025
K.	Average ΔH (in. H ₂ O) variation	1.82
L.	Average Process Gas Temperature (°F)	535
M.	Average Dry Gas Meter Temperature (°F)	91
N.	Dry Gas Composition (should total to 100%)	
	Carbon Dioxide (%)	4.5
	Oxygen (%)	11.0
	Nitrogen (%)	84.5
	Carbon Monoxide (%)	0.0
	Hydrogen (%)	0.0
	Methane (%)	0.0
	Ethane (%)	0.0
	Argon (%)	0.0
O.	Sample Time (min)	120
P.	Total H ₂ O Mass Collected in Impingers (g)	321.7
Q.	Metered Gas Volume (dcf)	89.052

Calculated Parameters (excluding analytical data)

R.	Absolute Process Gas Pressure (in. Hg)	29.22	[A+(B/13.6)]
S.	Absolute Meter Pressure (in. Hg)	29.45	[A+(K/13.6)]
T.	Duct Area (ft. ²)	2.01E+02	[Pi*E ² /(4*144) or F*G/144]
U.	Nozzle Area (ft. ²)	2.13E-03	[Pi*H ² /(4*144)]
V.	Average Absolute Process Gas Temperature (R)	995	[L+460]
W.	Average Absolute Dry Gas Meter Temperature (R)	551	[M+460]
X.	Dry Gas Volume Sampled (dscf)	84.198	[Q*D*(528/W)*(S/29.92)]
Y.	H ₂ O Vapor Condensed (scf)	15.168	[P*0.04715]
Z.	Calculated Percent H ₂ O in Gas Stream (%)	15.3	[100*Y/(X+Y)]
AA.	Theoretical Maximum Percent H ₂ O in Gas Stream (%) (empirical equation derived from EPA QA Handbook Vol. III, S3.3.6, T6.1A)	#N/A	[100*Saturated Water Vapor Pressure / Stack Pressure]
BB.	Actual Percent H ₂ O in Gas Stream (%)	15.3	[Calculated %H ₂ O <= Theoretical Max. %H ₂ O]
CC.	Process Gas Molecular Weight:		

Gas	% Volume / 100	* (1 - %H ₂ O/100)	* Mol. Weight	= Wt./Mol
H ₂ O	0.153		18	2.748
CO ₂	0.045	0.847	44	1.678
O ₂	0.110	0.847	32	2.983
N ₂	0.845	0.847	28	20.048
CO	0.000	0.847	28	0.000
H ₂	0.000	0.847	2	0.000
CH ₄	0.000	0.847	16	0.000
C ₂ H ₆	0.000	0.847	30	0.000
Ar	0.000	0.847	40	0.000

	Process Gas Molecular Weight (lb/lb-mol)	27.46	
DD.	Average Process Gas Velocity (ft/sec)	1.26E+01	$[85.49 \cdot C \cdot [(I \cdot V) / (R \cdot CC)]^{0.5}]$
EE.	Process Gas Volumetric Flow Rate (acfm)	1.53E+05	$[DD \cdot T \cdot 60]$
FF.	Process Gas Volumetric Flow Rate (scfm)	7.91E+04	$[EE \cdot (528/V) \cdot (R/29.92)]$
GG.	Process Gas Volumetric Flow Rate (dscfm)	6.70E+04	$[FF \cdot (1 - (BB/100))]$
HH.	Isokinetic Variation (%)	98.8	$[100 \cdot V \cdot \{(0.002669 \cdot P) + (O \cdot D \cdot S/W)\}] /$

Particulate Matter Results (corrected for blank)

II.	Filter Weight (g)	0.0113	
JJ.	Front-Half Residue Weight (g)	0.0324	
KK.	Back-Half H2O-Condensibles Weight (g)	0.0000	
LL.	Total Weight (g)	0.0437	[II+JJ+KK]
NN.	Concentration (gr/dscf)	0.0080	[(7000/454)*LL/X]
OO.	Mass Flow Rate (lb/hr)	4.59E+00	[NN*GG*60/7000]

PROCESS GAS TESTING CALCULATIONS - ISOKINETIC SAMPLING

CLIENT: U.S. STEEL CLAIRTON WORKS - CLAIRTON, PA
TEST SITE: NO. 19 BATTERY COMBUSTION STACKTEST DATE: 9/20/00
TEST NO.: CLR- #19BS-M26A-3Hydrochloric Acid (corrected for blank)

PP.	Total Catch (mg)	22.45	
QQ.	Concentration (mg/dscm)	9.42E+00	[PP/(X*0.02832)]
RR.	Mass Flow Rate (lb/hr)	2.36E+00	[QQ*0.02832*GG*60/454000]

Chlorine Gas Acid (corrected for blank)

SS.	Total Catch (mg)	<	0.23	
TT.	Concentration (mg/dscm)	<	9.70E-02	[SS/(X*0.02832)]
UU.	Mass Flow Rate (lb/hr)	<	2.43E-02	[TT*0.02832*GG*60/454000]

Ammonia Gas Acid (corrected for blank)

VV.	Total Catch (mg)		0.50	
WW.	Concentration (mg/dscm)		2.09E-01	[VV/(X*0.02832)]
XX.	Mass Flow Rate (lb/hr)		5.24E-02	[WW*0.02832*GG*60/454000]