

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 112
AP-42 Section 10.2
Reference 4
Report Sect. 78
Reference 4
Reference 78

**USS CLAIRTON WORKS
A DIVISION OF USX CORPORATION
CLAIRTON, PENNSYLVANIA**

Reviewed

Report on

**COMPLIANCE DEMONSTRATION
NO. 13 BATTERY COMBUSTION STACK**

AUGUST 1994

**USS CLAIRTON WORKS
A DIVISION OF USX CORPORATION
CLAIRTON, PENNSYLVANIA**

**Report on

COMPLIANCE DEMONSTRATION
NO. 13 BATTERY COMBUSTION STACK**

AUGUST 1994

**Prepared By
Advanced Technology Systems, Inc.
3000 Tech Center Drive
Monroeville, Pennsylvania 15146**

Project No. IKM-0202

AP-42 Section 12.2
Reference _____
Report Sect. 4
Reference 78



U. S. Steel
Clairton Works
400 State Street
Clairton, PA 15025-1855

R. L. WESTMAN
Reu
Clark
G. L. Sear
RECEIVED
Arg. files

AUG 30 1994

August 24, 1994

DEPUTY DIRECTOR'S OFFICE
Bureau of Environmental Quality

Director
Bureau of Air Quality Control
Department of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Deputy Director
Allegheny County Health Department
Department of Air Quality
301 Thirty-ninth Street
Pittsburgh, PA 15201

U.S. Environmental Protection Agency
Region III
841 Chestnut Building
Philadelphia, PA 19017

Office of Chief Counsel
Western Region
Department of Environmental Resources
400 Waterfront Drive
Pittsburgh, PA 15222-4745

Gentlemen:

Subject: #13 Battery Stack Compliance Demonstration
USS Clairton Works

I am enclosing with this letter the mass emission report on #13 Battery Combustion Stack. The compliance demonstration was conducted at USS Clairton Works, a division of USX Corporation, on July 28-29, 1994.

For questions regarding these reports please call William C. Graeser at (412) 233-1467

Very truly yours,


G. T. Weber, Jr.
General Manager
USS Clairton Works

GTW/BAC
Enclosure



TABLE OF CONTENTS

	Page
EXECUTIVE SUMMARY	iii
1.0 INTRODUCTION	1
2.0 METHODOLOGIES	2
3.0 RESULTS	4

LIST OF TABLES

Table 1	Particulate Matter Emissions Data	6
---------	---	---

APPENDICES

APPENDIX A	TEST PROTOCOL, FIELD DATA SHEETS, CALIBRATION RESULTS
APPENDIX B	PLANT OPERATIONAL DATA
APPENDIX C	GRAVIMETRIC AND ANALYTICAL RESULTS, EMISSIONS CALCULATIONS

EXECUTIVE SUMMARY

On July 28 and 29, 1994, a compliance test program was conducted for USS Clairton Works, Clairton, Pennsylvania, on the #13 Battery Combustion Stack. The purpose of the testing was to determine the (1) concentration and mass emission rate of particulate matter, and (2) presence and extent of visible emissions from the stack as required by the Second Consent Decree (Civil Action Nos. 79-709, 91-329), Chapter V (Compliance Requirements - Clairton Works), Section F (Combustion Stacks), Specific Items 2 through 4.

The results of the testing showed an average particulate matter concentration and emission rate of 0.0120 grains per dry standard cubic foot (gr/dscf) and 3.43 pounds per hour (lb/hr), respectively. As promulgated by the Second Consent Decree, Chapter V, Section F.2.a, the allowable particulate matter concentration for #13 Battery Combustion Stack is 0.015 gr/dscf (a Lowest Achievable Emission Rate [LAER] standard). Thus, the particulate matter emissions from the stack are less than the allowable concentration.

During the test periods, the greatest three-minute average opacity was less than 5 percent. The maximum opacity observed was 5 percent. As promulgated by the Second Consent Decree, Chapter V, Sections F.2.b and F.3, the visible emissions shall not equal or exceed 20 percent opacity for a period or periods aggregating in excess of 3 minutes in any 60-minute period and shall never equal or exceed 60 percent opacity. Thus, the observed opacities were less than the allowable values.

1.0 INTRODUCTION

On July 28 and 29, 1994, a compliance test program was conducted for USS Clairton Works, Clairton, Pennsylvania, on the #13 Battery Combustion Stack. The purpose of the testing was to determine the (1) concentration and mass emission rate of particulate matter, and (2) presence and extent of visible emissions from the stack as required by the Second Consent Decree (Civil Action Nos. 79-709, 91-329), Chapter V (Compliance Requirements - Clairton Works), Section F (Combustion Stacks), Specific Items 2 through 4.

Testing was performed by Messrs. Richard Casselberry and Thomas Morgan of Advanced Technology Systems, Inc. (previously the Monroeville, Pennsylvania-based Air Emissions Measurement Group of Chester Environmental) and Mr. Brian Fajtak of Environmental Technical Services under the direction of Mr. Bernie Clark of Chester Environmental. All test procedures were witnessed by Mr. Phil Lawrence of the Allegheny County Health Department - Department of Air Quality (DAQ).

The test program required two days to complete the field work activities due to a delay in the operation of the Battery #13. Since no ovens in Battery #13 were pushed or charged from approximately 1000 to 1245 on July 28, 1994, no emissions testing was completed during this time period. Once normal operations of the battery resumed (about 1245), emissions testing was resumed. Since there was an insufficient amount of daylight remaining after the completion of the second test run, the third test run was conducted on the following day, July 29, 1994.

2.0 METHODOLOGIES

The compliance test program was conducted in accordance with the emissions measurement test protocol, which can be found in Appendix A.

Particulate matter sampling was performed in accordance with EPA Stationary Source Sampling Methods 1 through 5, Sections 139.11 and 139.12 of the Pennsylvania Department of Environmental Resources (PA DER) Source Testing Manual, and Appendix A of the Amended Installation Permit for USS Clairton Works Nos. 13, 14, and 15 Batteries. Three two-hour tests were executed during normal operating conditions. Greater than 50 dry standard cubic feet of sample gas was collected during each test run.

The process exhausts through a 120 inch diameter stack. A total of 24 traverse points (12 per diameter) were sampled; the traverse points were calculated in accordance with EPA Method 1. Sampling was conducted through four equally spaced ports, with six traverse points sampled per port. Each point was sampled for 5 minutes, thus bringing the total sampling time to 120 minutes.

In accordance with EPA Method 2, velocities and volumetric flow rates of the exhaust gas were determined using a calibrated S type pitot tube. Positive and negative pitot lines were leak-checked at the beginning and end of each test run. Gas velocity differential pressures along with stack gas temperatures were recorded at each sampling point.

At the beginning and end of each test, gas concentrations of carbon dioxide (CO_2), oxygen (O_2), and nitrogen (N_2 - by difference) were determined with the use of Fyrite apparatus as specified by EPA Method 3. Gas concentrations were used to obtain dry molecular weight of the process gas.

Percent moisture content, by volume, of the exhaust gas was determined by measuring the weight gain of the four sample train impingers in accordance with EPA Method 4.

As specified by EPA Method 5, each sample train was assembled as required by the method, leak-checked on site at the beginning and end of each test run, and operated such that isokinetic conditions are maintained. Clean up of the sampling train will include a

water rinse followed by an acetone rinse of both the front-half and back-half components of the sample train, as per PA DER particulate matter test methods. The water soluble and water insoluble portions of the front-half of the sampling train were determined as a total; that is, the water rinse was not filtered to determine soluble and insoluble portions. Front-half acetone and water rinses were evaporated to dryness, desiccated, and weighed to a constant weight. The water soluble and water insoluble portions of the back-half were determined separately in accordance with Section 139.12 of the PA DER Source Testing Manual. The back-half water rinses and first three impinger solutions were combined and then filtered under suction through a preweighed 0.22 micrometer membrane filter. The filter used to capture the insoluble material was dried, desiccated, and weighed to a constant weight. After filtration, the soluble back-half water was extracted with chloroform and ethyl ether. The extracts were evaporated to dryness, desiccated, and weighed to a constant weight. The filtrate, or remaining water from the extraction process, was evaporated to dryness, desiccated, and weighed to a constant weight. Following the gravimetric analyses for the filtrate residue, the residue was resolubilized and the solution submitted for sulfate analysis via ion chromatography. Back-half acetone rinses were evaporated to dryness, desiccated, and weighed to a constant weight. Sample train filters were desiccated for 24 hours, and particulate matter weight was determined gravimetrically. Rinse residue weights and filter weights were measured to the nearest 0.1 mg. One acetone blank and one deionized distilled water blank were prepared in the same manner as the test sample rinses. The blank residue weights were subtracted from the test sample residue weights. After blank correction, front-half water and acetone rinse residue weights, sample train filter weights, and back-half water insoluble filter weights were used to determine total particulate matter catch.



All visible emissions determinations were performed in accordance with EPA Stationary Source Sampling Method 9. Visible emission readings were recorded for the duration of each particulate matter test.

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter --									
	2	4	6	8	10	12	14	16	18	20
1	14.8	9.7	7.4	5.7	4.3	3.3	2.5	1.9	1.4	1.1
2	25.0	15.6	12.0	9.1	6.9	5.2	3.9	2.9	2.2	1.7
3	35.4	22.0	16.5	12.5	9.5	7.2	5.4	4.0	3.0	2.3
4	45.8	28.0	21.0	15.5	11.5	8.7	6.4	4.7	3.5	2.7
5	56.2	34.0	25.5	19.0	14.0	10.5	7.7	5.7	4.3	3.3
6	66.6	40.0	30.0	22.0	16.0	12.0	9.0	6.7	5.0	3.8
7	77.0	46.0	34.5	25.0	18.0	13.5	10.0	7.5	5.6	4.2
8	87.4	52.0	39.0	28.0	20.0	15.0	11.0	8.3	6.2	4.6
9	97.8	58.0	43.5	31.0	22.0	16.5	12.0	9.0	6.7	5.0
10	108.2	64.0	48.0	34.0	24.0	18.0	13.5	10.0	7.5	5.6
11	118.6	70.0	52.5	37.0	26.0	19.5	14.5	10.5	8.0	6.0
12	129.0	76.0	57.0	40.0	28.0	21.0	15.5	11.5	8.5	6.4
13	139.4	82.0	61.5	43.0	30.0	22.5	16.5	12.5	9.5	6.8
14	149.8	88.0	66.0	46.0	32.0	24.0	17.5	13.5	10.5	7.2
15	160.2	94.0	70.5	49.0	34.0	25.5	18.5	14.5	11.5	7.6
16	170.6	100.0	75.0	52.0	36.0	27.0	19.5	15.5	12.5	8.0
17	181.0	106.0	79.5	55.0	38.0	28.5	20.5	16.5	13.5	8.4
18	191.4	112.0	84.0	58.0	40.0	30.0	21.5	17.5	14.5	8.8
19	201.8	118.0	88.5	61.0	42.0	31.5	22.5	18.5	15.5	9.2
20	212.2	124.0	93.0	64.0	44.0	33.0	23.5	19.5	16.5	9.6
21	222.6	130.0	97.5	67.0	46.0	34.5	24.5	20.5	17.5	10.0
22	233.0	136.0	102.0	70.0	48.0	36.0	25.5	21.5	18.5	10.4
23	243.4	142.0	106.5	73.0	50.0	37.5	26.5	22.5	19.5	10.8
24	253.8	148.0	111.0	76.0	52.0	39.0	27.5	23.5	20.5	11.2

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Stack layout
2	3-3
4	4-4
6	5-5
8	6-6
10	7-7
12	8-8
14	9-9
16	10-10
18	11-11
20	12-12
22	13-13
24	14-14
26	15-15
28	16-16
30	17-17
32	18-18
34	19-19
36	20-20
38	21-21
40	22-22



Page 2 of 2

Page 2 of 2

ORIFICE CORRECTION (ΔH) 1.837 HOT/COLD BOX NO. 4
METER CORRECTION (V) 1.277 PROFILE NO.

CALIBRATION DATE	06-20-94	FILTER NO.	1284
PLOT CONNECTION:			

CONTROL BOX NO.	517	PORT SIZE	1 1/2"
NOT CORRECTION	0.84	STACK DIA.	120"

Vacuum	Stock	Probe	Insertion	Port Size
			1/2" N	4.0" NPS

[illegible][illegible]

3.0	50/	11200	11800	12200
	(1.1)	(1.1)	(1.1)	(1.1)

3.0	361	$\sim 250^\circ$	$\sim 250^\circ$	5 min./
-----	-----	------------------	------------------	---------

3.0	500
2.0	
1.0	
0.0	

3.0	504				
-----	-----	--	--	--	--

45	509			
----	-----	--	--	--

0-17	469			
18	301			

469	47	2
469	47	2

30	450		

--	--	--	--	--	--

--	--	--	--	--

27	27			
----	----	--	--	--

40	490
----	-----

4.5	520				
-----	-----	--	--	--	--

40529

30	101		
30	101		

30	30	30	30
----	----	----	----

30	422		
30	422		

30	479		
----	-----	--	--

[illegible][illegible]

Estimates:

1100

498.12	1	8/11/20	14.0
--------	---	---------	------

Impinger  Impinger	$701120 = 14.6$
--	-----------------

No.	Contents	Final	Initial	Difference
-----	----------	-------	---------	------------

	Initial	Difference
1.		

2.			
----	--	--	--

3			
2			
1			
0			
-1			
-2			
-3			
-4			
-5			
-6			
-7			
-8			
-9			
-10			
-11			
-12			
-13			
-14			
-15			
-16			
-17			
-18			
-19			
-20			
-21			
-22			
-23			
-24			
-25			
-26			
-27			
-28			
-29			
-30			
-31			
-32			
-33			
-34			
-35			
-36			
-37			
-38			
-39			
-40			
-41			
-42			
-43			
-44			
-45			
-46			
-47			
-48			
-49			
-50			
-51			
-52			
-53			
-54			
-55			
-56			
-57			
-58			
-59			
-60			
-61			
-62			
-63			
-64			
-65			
-66			
-67			
-68			
-69			
-70			
-71			
-72			
-73			
-74			
-75			
-76			
-77			
-78			
-79			
-80			
-81			
-82			
-83			
-84			
-85			
-86			
-87			
-88			
-89			
-90			
-91			
-92			
-93			
-94			
-95			
-96			
-97			
-98			
-99			
-100			
-101			
-102			
-103			
-104			
-105			
-106			
-107			
-108			
-109			
-110			
-111			
-112			
-113			
-114			
-115			
-116			
-117			
-118			
-119			
-120			
-121			
-122			
-123			
-124			
-125			
-126			
-127			
-128			
-129			
-130			
-131			
-132			

[illegible]

4	5		
---	---	--	--

5			
6			

6.		
7.		

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

0				
1				
2				
3				
4				
5				
6				
7				
8				
9				

1



Downloaded from <http://ajph.org/> on November 10, 2014

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.8	9.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.2	1.1	1.1
2	26.6	16.6	10.6	8.2	6.7	5.7	4.9	4.3	3.9	3.5	3.3	3.3
3	38.4	24.4	15.4	11.4	9.4	8.0	6.9	6.1	5.5	5.1	4.8	4.8
4	50.2	32.2	20.2	14.2	11.2	9.6	8.3	7.3	6.6	6.1	5.7	5.7
5	62.0	39.0	24.0	17.0	13.0	11.0	9.5	8.4	7.6	7.0	6.5	6.5
6	73.8	45.8	28.8	20.8	16.8	14.0	12.1	10.8	9.9	9.2	8.6	8.6
7	85.6	51.6	32.6	23.6	19.6	16.0	13.7	12.2	11.2	10.4	9.8	9.8
8	97.4	57.4	36.4	26.4	22.4	18.0	15.3	13.6	12.4	11.5	10.8	10.8
9	109.2	63.2	40.2	29.2	25.2	20.0	16.9	14.8	13.5	12.5	11.7	11.7
10	121.0	69.0	44.0	32.0	28.0	22.0	18.5	16.2	14.8	13.7	12.8	12.8
11	132.8	74.8	47.8	35.0	31.0	24.0	20.0	17.4	15.8	14.6	13.7	13.7
12	144.6	80.6	51.6	38.0	34.0	26.0	21.5	18.7	16.9	15.6	14.7	14.7
13	156.4	86.4	55.4	41.0	37.0	28.0	23.0	20.0	18.0	16.7	15.8	15.8
14	168.2	92.2	59.2	44.0	40.0	30.0	24.5	21.1	19.0	17.7	16.8	16.8
15	180.0	98.0	63.0	47.0	43.0	32.0	26.0	22.2	20.0	18.7	17.8	17.8
16	191.8	103.8	66.8	50.0	46.0	34.0	27.5	23.3	21.0	19.7	18.8	18.8
17	203.6	109.6	70.6	53.0	49.0	36.0	29.0	24.4	22.0	20.7	19.8	19.8
18	215.4	115.4	74.4	56.0	52.0	38.0	30.5	25.5	23.0	21.7	20.8	20.8
19	227.2	121.2	78.2	59.0	55.0	40.0	32.0	26.6	24.0	22.7	21.8	21.8
20	239.0	127.0	82.0	62.0	58.0	42.0	33.5	27.7	25.0	23.7	22.8	22.8
21	250.8	132.8	85.8	65.0	61.0	44.0	35.0	28.8	26.0	24.7	23.8	23.8
22	262.6	138.6	89.6	68.0	64.0	46.0	36.5	29.9	27.0	25.7	24.8	24.8
23	274.4	144.4	93.4	71.0	67.0	48.0	38.0	31.0	28.0	26.7	25.8	25.8
24	286.2	150.2	97.2	74.0	70.0	50.0	39.5	32.1	29.0	27.7	26.8	26.8

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Stack layout
2	2-2
4	4-4
6	6-6
8	8-8
10	10-10
12	12-12
14	14-14
16	16-16
18	18-18
20	20-20
22	22-22
24	24-24
26	26-26
28	28-28
30	30-30
32	32-32
34	34-34
36	36-36
38	38-38
40	40-40



STACK SAMPLING DATA SHEET

Page 1 of 2

CLIENT USS-CLAIRTON WORKS TEST DATE 07-28-94 (THURS) ORIFICE CORRECTION (ΔH) 1.837 HOT/COLD BOX NO. 4
 TEST UNIT # 13 BATTERY STACK TEST NO. USS-CL-85-13-2 METER CORRECTION (V) 1.0172 PROBE NO. 10-2
 PROJECT NO. PA-1-0242 NOZZLE (SIZE #) 0.490" CALIBRATION DATE 6-6-80-94 FILTER NO. 1284
 TEST CREW RSC-ITM STATIC PRESSURE -1.0" H₂O PITOT CORRECTION 0.84 STACK DIA. 120"
 BAROMETRIC PRESSURE 23.36 PORT DIRECTION SOUTH WEST CONTROL BOX NO. 518 PORT SIZE 40" Messing Nuts

Traverse Point (Inches)	Time	Dry Gas Meter Reading (scf)	Pitot ΔP (in. H ₂ O)	Orifice ΔH (in. H ₂ O)	Meter Temperature In (°F)	Meter Temperature Out (°F)	Vacuum (in. Hg)	Stack Temp. (°F)	Probe Temp. (°F)	Impinger Temp. (°F)	Hot Box Temp. (°F)	Comments
42.7	13:40	890.730	0.05	1.44	1.73	88	5.0	509	~280°	568°	~280°	5 min./point
30.0			0.06	1.73	104	87	5.0	489				
21.3			0.06	1.73	105	88	5.0	499				
14.2			0.06	1.74	110	90	5.6	505				
9.0			0.04	1.16	112	92	3.5	498				
2.6	18:40	911.200	0.04	1.16	115	95	3.0	500				
42.7	18:14	911.200	0.04	1.16	110	95	3.0	509				
30.0			0.04	1.16	115	96	3.0	520				
21.3			0.04	1.16	118	97	3.0	519				
14.2			0.05	1.45	119	98	4.0	506				
8.0			0.05	1.45	120	98	4.0	520				
2.6	18:44	928.707	0.03	0.87	121	100	3.6	450				

Estimates:
 MW = 28.0
 %H₂O = 14.0

Vacuum (in. Hg)	DGM Rate (cfm)
Before	5.0
After	7.0

Before	Positive	Negative
After	0.45	0.45
GAS	1	2
CO ₂	6.0	6.0
O ₂	10.5	10.5
CO	0	0
N ₂	33.5	33.5

Impinger No.	Impinger Contents	Final	Initial	Difference
1.	100 ml DI H ₂ O	748.5	532.8	215.7
2.	100 ml DI H ₂ O	603.9	539.8	50.1
3.	EMPTY	109.8	452.2	9.6
4.	Stuen Gas	664.0	449.0	21.3
5.				
6.				
7.				
8.				

275.49



ADVANCED TECHNOLOGY SYSTEMS, INC.
 339 Haymaker Road Suite 201
 Montroeville, PA 15146
 412/856-0662
 FAX 412/856-0666

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from heads and to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter--										
	3	4	5	6	7	8	9	10	11	12	13
1	10.0	0.7	0.4	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0.1
2	86.4	25.0	14.0	10.0	6.7	4.3	3.2	2.3	1.6	1.2	0.9
3		71.0	39.0	24.0	16.0	10.0	6.7	4.3	3.2	2.3	1.6
4		60.3	34.4	21.3	13.3	8.3	5.0	3.3	2.3	1.6	1.2
5			26.7	16.0	10.0	6.7	4.3	3.2	2.3	1.6	1.2
6				13.3	8.3	5.0	3.3	2.3	1.6	1.2	0.9
7					10.0	6.7	4.3	3.2	2.3	1.6	1.2
8						8.3	5.0	3.3	2.3	1.6	1.2
9							6.7	4.3	3.2	2.3	1.6
10								5.0	3.3	2.3	1.6
11									4.3	3.2	2.3
12										3.2	2.3
13											2.3
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											

TABLE 1-1. CROSS-SECTION LAYOUT FOR
RECTANGULAR STACKS

Number of traverse points	Stack layout
3	3-3
4	4-4
5	5-5
6	6-6
7	7-7
8	8-8
9	9-9
10	10-10
11	11-11
12	12-12
13	13-13
14	14-14
15	15-15
16	16-16
17	17-17
18	18-18
19	19-19
20	20-20
21	21-21
22	22-22
23	23-23
24	24-24



Page 2 of 2

HOT/COLD BOX NO. /

FILTER NO. 13 OK

SICK DIA. 120"

Hot Doc	Comments
---------	----------



1.	100ml AE H ₂ O		
2.	100ml AE H ₂ O		
3.	empty		
4.	500ml AE		
5.			
6.			
7.			
8.			

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter									
	2	4	6	8	10	12	14	16	18	20
1	100	97	94	92	90	87	85	83	81	79
2	86.4	78.0	70.4	64.0	58.0	52.0	46.0	40.0	34.0	28.0
3	78.0	69.6	62.0	55.6	49.6	43.6	37.6	31.6	25.6	19.6
4	70.4	62.0	55.6	49.6	43.6	37.6	31.6	25.6	19.6	13.6
5	64.0	55.6	49.6	43.6	37.6	31.6	25.6	19.6	13.6	7.6
6	58.0	49.6	43.6	37.6	31.6	25.6	19.6	13.6	7.6	1.6
7	52.0	43.6	37.6	31.6	25.6	19.6	13.6	7.6	1.6	0.0
8	46.0	37.6	31.6	25.6	19.6	13.6	7.6	1.6	0.0	0.0
9	40.0	31.6	25.6	19.6	13.6	7.6	1.6	0.0	0.0	0.0
10	34.0	25.6	19.6	13.6	7.6	1.6	0.0	0.0	0.0	0.0
11	28.0	19.6	13.6	7.6	1.6	0.0	0.0	0.0	0.0	0.0
12	22.0	13.6	7.6	1.6	0.0	0.0	0.0	0.0	0.0	0.0
13	16.0	7.6	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14	10.0	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15	4.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
24	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Stack layout
2	3-3
4	4-4
6	5-5
8	6-6
10	7-7
12	8-8
14	9-9
16	10-10
18	11-11
20	12-12
22	13-13
24	14-14
26	15-15
28	16-16
30	17-17
32	18-18
34	19-19
36	20-20
38	21-21
40	22-22
42	23-23
44	24-24
46	25-25
48	26-26
50	27-27
52	28-28
54	29-29
56	30-30
58	31-31
60	32-32
62	33-33
64	34-34
66	35-35
68	36-36
70	37-37
72	38-38
74	39-39
76	40-40
78	41-41
80	42-42
82	43-43
84	44-44
86	45-45
88	46-46
90	47-47
92	48-48
94	49-49
96	50-50
98	51-51
100	52-52



155

STACK SAMPLING DATA SHEET

Page 1 of 2

CLIENT: USS - Clinton Works

TEST DATE: 07-28-94 (THURS)

OFFICE CORRECTION (ΔH₀) 1.837

NOT/COLD BOX NO. 1

TEST UNIT: BATTERY Stack #13

TEST NO. USS-CLB-85#13-#1

METER CORRECTION (Y) 1.0172

PROBE NO. 10-2

PROJECT NO. 1744-0202

NOZZLE (SIZE #) 0.490"

CALIBRATION DATE 06-20-94

FILTER NO. 1296

TEST CREW

STATIC PRESSURE -1.0"

PITOT CORRECTION 0.84

STACK DIA. 120"

BAROMETRIC PRESSURE 29.30

PORT DIRECTION 100°N, EAST

CONTROL BOX NO. 517

PORT SIZE 4.0 inches

Test Point (feet)	Time	Dry Gas Meter Reading (scf)	Phot A.P. (in. H ₂ O)	Orifice A.H. Required (in. H ₂ O)	Orifice A.H. Actual (in. H ₂ O)	Meter Temperature In (°F)	Meter Temperature Out (°F)	Vacuum (in. Hg)	Stack Temp. (°F)	Probe Temp. (°F)	Impinger Temp. (°F)	Hot Box Temp. (°F)	Comments
42.7	08:20	816.635	0.05	1.40	1.40	71	71	4.5	521	~250°	~168°	~250°	5 min./point
30.0			0.06	1.68	1.68	86	71	5.0	536				
21.3			0.04	1.12	1.12	93	73	4.0	529				
14.2			0.05	1.40	1.40	100	75	4.5	480				
8.0			0.05	1.40	1.40	100	76	4.5	475				
2.6	09:20	835.180	0.03	0.84	0.84	100	76	3.5	450				
42.7	09:06	835.180	0.06	1.40	1.40	84	78	5.0	516				
30.0			0.04	1.12	1.12	100	78	4.5	509				
21.3			0.04	1.12	1.12	102	79	4.5	508				
14.2			0.05	1.40	1.40	105	80	5.0	495				
8.0			0.03	0.84	0.84	105	81	3.8	480				
2.6	09:38	853.205	0.03	0.84	0.84	104	81	3.5	450				

Estimates:

MW = 28.0

%H₂O = 14.0

SYSTEM LEAK CHECK

	Vacuum (in. Hg)	DGM Rate (cfm)
Before	5.0	<0.01 cfm
After	8.0	0.01 cfm

PITOT LEAK CHECK

	Positive (cfm/sc)	Negative (cfm/sc)
Before	0.05 sc	0.05 sc
After	0.05 sc	0.05 sc

Impinger

Impinger No.	Impinger Contents	Final	Initial	Difference
1.	100ml AT H ₂ O	761.5	559.5	202.0
2.	100ml AT H ₂ O	596.4	553.3	43.1
3.	50ml AT H ₂ O	446.3	437.4	8.8
4.	50ml AT H ₂ O	671.5	649.4	22.1
5.				
6.				
7.				
8.				

253.9g

ADVANCED TECHNOLOGY SYSTEMS, INC.

339 Haymaker Road Suite 201

Monroeville, PA 15146

412/856-0662

FAX 412/856-0666

A report summarizing the compliance test program will be submitted within 60 days following completion of field work. The report will describe test methodologies utilized and present a textual and tabular summary of the emissions results and related sampling information. Copies of operational data will be included in the report to verify that all testing was performed during periods of normal plant operation. Also incorporated into the report will be copies of the pre-test calibration results, post-test calibration results, the results of an audit conducted with a critical orifice provided by the Allegheny County Health Department - Department of Air Quality, field data sheets for the particulate matter sampling and visible emissions determinations, emissions calculations sheets, and analytical results for each test.

water rinse followed by an acetone rinse of both the front-half and back-half components of the sample train, as per PA DER particulate matter test methods. The water soluble and water insoluble portions of the front-half of the sampling train will be determined as a total; that is, the water rinse will not be filtered to determine soluble and insoluble portions. Front-half acetone and water rinses will be evaporated to dryness, desiccated, and weighed to a constant weight. The water soluble and water insoluble portions of the back-half will be determined separately in accordance with Section 139.12 of the PA DER Source Testing Manual. The back-half water rinses and first three impinger solutions will be combined and then filtered under suction through a preweighed 0.22 micrometer membrane filter. The filter used to capture the insoluble material will be dried, desiccated, and weighed to a constant weight. After filtration, the soluble back-half water will be extracted with chloroform and ethyl ether. The extracts will be evaporated to dryness, desiccated, and weighed to a constant weight. The filtrate, or remaining water from the extraction process, will be evaporated to dryness, desiccated, and weighed to a constant weight. Following the gravimetric analyses for the filtrate residue, the residue will be resolubilized and the solution submitted for sulfate analysis via ion chromatography. Back-half acetone rinses will be evaporated to dryness, desiccated, and weighed to a constant weight. Sample train filters will be desiccated for 24 hours, and particulate matter weight will be determined gravimetrically. Rinse residue weights and filter weights will be measured to the nearest 0.1 mg. One acetone blank and one deionized distilled water blank will be prepared in the same manner as the test sample rinses. The blank residue weights will be subtracted from the test sample residue weights. After blank correction, front-half water and acetone rinse residue weights, sample train filter weights, and back-half water insoluble filter weights will be used to determine total particulate matter catch.

All visible emissions determinations will be performed in accordance with EPA Stationary Source Sampling Method 9. Visible emission readings will be recorded for the duration of each particulate matter test.

**TEST PROTOCOL
COMPLIANCE DEMONSTRATION
#13 BATTERY COMBUSTION STACK**

**USS CLAIRTON WORKS
CLAIRTON, PA**

Particulate matter sampling will be performed in accordance with EPA Stationary Source Sampling Methods 1 through 5, Sections 139.11 and 139.12 of the Pennsylvania Department of Environmental Resources (PA DER) Source Testing Manual, and Appendix A of the Amended Installation Permit for USS Clairton Works Nos. 13, 14, and 15 Batteries. Three two-hour tests will be executed during normal operating conditions. Greater than 50 dry standard cubic feet of sample gas will be collected during each test run.

The process exhausts through a 120 inch diameter stack. A total of 24 traverse points (12 per diameter) will be sampled; the traverse points will be calculated in accordance with EPA Method 1. Sampling will be conducted through four equally spaced ports, with six traverse points sampled per port. Each point will be sampled for 5 minutes, thus bringing the total sampling time to 120 minutes.

In accordance with EPA Method 2, velocities and volumetric flow rates of the exhaust gas will be determined using a calibrated S type pitot tube. Positive and negative pitot lines will be leak-checked at the beginning and end of each test run. Gas velocity differential pressures along with stack gas temperatures will be recorded at each sampling point.

At the beginning and end of each test, gas concentrations of CO₂, O₂, and N₂ (by difference) will be determined with the use of a Fyrite apparatus as specified by EPA Method 3. Gas concentrations will be used to obtain molecular weight of the process gas.

Percent moisture content, by volume, of the exhaust gas will be determined by measuring the weight gain of the four sample train impingers in accordance with EPA Method 4.

As specified by EPA Method 5, each sample train will be assembled as required by the method, leak-checked on site at the beginning and end of each test run, and operated such that isokinetic conditions are maintained. Clean up of the sampling train will include a

**COMPLIANCE DEMONSTRATION
NO. 13 BATTERY COMBUSTION STACK**

**USS CLAIRTON WORKS
A DIVISION OF USX CORPORATION
CLAIRTON, PENNSYLVANIA**

APPENDIX A

**TEST PROTOCOL, FIELD DATA SHEETS, CALIBRATION
RESULTS**

ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.

All testing was performed during periods of normal plant operation. Copies of the plant operational data can be found in Appendix B.

The gravimetric and analytical results (including the results of the sulfate analyses of the back-half filtrate from the sample trains) and the emissions calculations for each test can be found in Appendix C.

USS CLAIRTON WORKS
CLAIRTON, PA

TABLE 1

#13 BATTERY COMBUSTION STACK
PARTICULATE MATTER EMISSIONS DATA

		Run 1	Run 2	Run 3	Average
Test Number		CLR-BS#13-1	CLR-BS#13-2	CLR-BS#13-3	
Test Date		07-28-94	07-28-94	07-29-94	
<u>Mass Emissions Rate and Concentration</u>					
Particulate Matter	(lb/hr)	3.49	3.11	3.69	3.43
	(gr/dscf)	0.0121	0.0109	0.0129	0.0120
<u>Stack Conditions</u>					
Flow Rate	(acfm)	73700	73900	73500	73700
	(scfm)	39800	39800	39800	39800
	(dscfm)	33600	33200	33400	33400
Temperature	(°F)	496	498	495	496
Moisture Content	(%)	15.5	16.6	16.2	16.1
<u>Sampling Conditions</u>					
Test times		0830	1340	0740	
		to 0900	to 1410	to 0810	
		0906	1414	0813	
		to 0936	to 1444	to 0843	
		0939	1447	0846	
		to 1009	to 1517	to 0916	
		1242	1520	0919	
		to 1312	to 1550	to 0949	
Sampling Time	(minutes)	120	120	120	
Sample Volume	(dscf)	70.923	70.515	69.046	
Isokinetics	(%)	105.4	106.2	103.4	

3.0 RESULTS

The test results have been summarized in Table 1. The results of the testing showed an average particulate matter concentration and emission rate of 0.0120 grains per dry standard cubic foot (gr/dscf) and 3.43 pounds per hour (lb/hr), respectively. As promulgated by the Second Consent Decree, Chapter V, Section F.2.a, the allowable particulate matter concentration for #13 Battery Combustion Stack is 0.015 gr/dscf (a Lowest Achievable Emission Rate [LAER] standard). Thus, the particulate matter emissions from the stack are less than the allowable concentration.

Table 1 also lists other pertinent stack and sampling parameters which include stack gas flow rate in units of actual cubic feet per minute (acfm), standard cubic feet per minute (scfm), and dry standard cubic feet per minute (dscfm), stack gas temperature ($^{\circ}\text{F}$), moisture content of the stack gas (percent by volume), gas volume sampled for each test in units of dry standard cubic feet (dscf), and the isokinetics value for each test. The isokinetics value is equal to the ratio of the average linear gas velocity sampled through the probe nozzle to the average stack gas velocity. An isokinetics value between 90 percent and 110 percent is considered acceptable. All isokinetic values were within the acceptable range of values. The gas volume sampled for each 120 minute test was greater than 50 dry standard cubic feet. Actual test sampling times have also been included in Table 1.

Copies of all field data sheets, including the visible emissions readings, can be found in Appendix A. As promulgated by the Second Consent Decree, Chapter V, Sections F.2.b and F.3, the visible emissions shall not equal or exceed 20 percent opacity for a period or periods aggregating in excess of 3 minutes in any 60-minute period and shall never equal or exceed 60 percent opacity. During the test periods, the greatest three-minute average opacity was less than 5 percent. The maximum opacity observed was 5 percent. Thus, the observed opacities were less than the allowable values.

All sampling equipment was calibrated and operated in accordance with EPA Stationary Source Sampling Methods 1 through 5. Copies of the pre-test calibration results, post-test calibration results, and the results of an audit conducted with a critical orifice provided by the Allegheny County Health Department DAQ can be found in Appendix A.

STACK SAMPLING DATA SHEET

Page 1 of 3

CLIENT USS-CLARKTON WORKS TEST DATE 07-29-94 (Fri) ORIFICE CORRECTION (ΔH) @ 1837 HOT/COLD BOX NO. 4
 TEST UNIT #13 SATURDAY STACK TEST NO. USS-CL-AS-13-3 METER CORRECTION (Y) 10173 PROBE NO. 10-2
 PROJECT NO. 100-8282 NOZZLE (SIZE, #) 0.490 CALIBRATION DATE 06-20-94 FILTER NO. 1305
 TEST CREW RAC TH STATIC PRESSURE -11.740 PITOT CORRECTION 0.84 STACK DIA. 120"
 BAROMETRIC PRESSURE 29.40 PORT DIRECTION NORTH, EAST CONTROL BOX NO. 518 PORT SIZE 4.0" Thread Male

Inverse Point (inches)	Time	Dry Gas Meter Reading (def)	Pitot ΔP (in. H ₂ O)	Orifice ΔH		Meter Temperature		Vacuum (in. Hg)	Stack Temp. (°F)	Probe Temp. (°F)	Impinger Temp. (°F)	Hot Box Temp. (°F)	Comments
				Required (in. H ₂ O)	Actual (in. H ₂ O)	In (°F)	Out (°F)						
42.7	07:40	966.761	0.05	1.39	1.39	68	68	35	533	~250F	~68F	~250F	5 min./point
30.0			0.05	1.39	1.39	82	68	35	509				
21.3			0.04	1.11	1.11	91	70	30	500				
14.2			0.04	1.11	1.11	97	73	30	489				
8.0			0.03	0.83	0.83	100	75	25	479				
2.6	08:12	984.654	0.03	0.83	0.83	99	75	25	484				
42.7	08:13	984.654	0.04	1.11	1.11	95	80	35	511				
30.0			0.05	1.39	1.39	105	81	40	509				
21.3			0.04	1.11	1.11	107	82	35	511				
14.2			0.03	0.83	0.83	107	82	30	494				
8.0			0.03	0.83	0.83	108	82	25	500				
2.6	08:43	1001.677	0.03	0.83	0.83	107	83	25	450				
													Estimates:
													MW = 28.0
													% H ₂ O = 14.0

PITOT LEAK CHECK

	Positive	Negative
Before	0.15/15 sec.	0.15/15 sec.
After	0.15/15 sec.	0.15/15 sec.
GAS	1	2
CO ₂	6.5	6.5
O ₂	10.5	10.5
CO	0	0
N ₂	83.0	83.0

SYSTEM LEAK CHECK

	Vacuum (in. Hg)	U/GM Ratio (cfm)
Before	5.0	0.01245
After	5.0	0.01245

Impinger

Impinger No.	Impinger Contents	Final	Initial	Difference
1.	100 ml DI H ₂ O	7437	534.1	209.6
2.	100 ml DI H ₂ O	603.8	555.8	48.0
3.	50 ml DI H ₂ O	457.3	451.2	6.1
4.	50 ml DI H ₂ O	660.8	642.2	18.2
5.				
6.				
7.				
8.				

ADVANCED TECHNOLOGY SYSTEMS, INC.

339 Haymaker Road Suite 201

Monroeville, PA 15146

412/856-0662

FAX 412/856-0666





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter -									
	3	4	5	6	7	8	9	10	11	12
1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Stack layout
1	1-1
2	2-2
3	3-3
4	4-4
5	5-5
6	6-6
7	7-7
8	8-8
9	9-9
10	10-10
11	11-11
12	12-12
13	13-13
14	14-14
15	15-15
16	16-16
17	17-17
18	18-18
19	19-19
20	20-20
21	21-21

STACK SAMPLING DATA SHEET

Page 2 of 2

CLIENT USS CLARKTON WORKS TEST DATE 07-29-94 (FRI) ORIFICE CORRECTION (A1100) 1837 HOT/COLD BOX NO. 4
 TEST UNIT BATTERY STACK #13 TEST NO. 155-ET-1385-13 METER CORRECTION (V) 1.0172 PROBE NO. 10-2
 PROJECT NO. JH1-PR-22 NOZZLE (SIZE) 490" CALIBRATION DATE 06-20-94 FILTER NO. 1365
 TEST CREW RLC TH STATIC PRESSURE -1.1"H₂O PITOT CORRECTION 0.84 STACK DIA. 120"
 BAROMETRIC PRESSURE 29.40 PORT DIRECTION SOUTH, 4851 CONTROL BOX NO. 51F PORT SIZE 40 Threaded IN

Traverse Point (inches)	Time	Dry Gas Meter Reading (def)	Pitot ΔP (in. H ₂ O)	Orifice ΔH	Meter Temperature	Vacuum (in. Hg)	Stack Temp. (°F)	Probe Temp. (°F)	Impinger Temp. (°F)	Hot Box Temp. (°F)	Comments
42.7	08:46	1001.677	0.05	1.41	In 95	3.0	525	~250F	<68F	~250F	5 min./point
30.0			0.06	1.70	In 99	4.0	493				
21.3			0.06	1.76	In 110	4.0	495				
14.2			0.04	1.41	In 112	3.0	501				
8.0			0.03	0.85	In 112	2.0	481				
2.6	09:14	1020.960	0.03	0.85	In 112	2.0	499				
42.7	09:19	1020.960	0.05	1.41	In 97	3.5	511				
30.0			0.05	1.41	In 105	3.5	515				
21.3			0.05	1.41	In 116	3.5	516				
14.2			0.03	0.85	In 116	2.5	500				
9.0			0.03	0.85	In 116	2.5	465				
2.6	09:49	1038.903	0.03	0.85	In 116	2.5	460				
Test	1=12.0	1=72.142	1=0.04	1.41	In 116		495	Estimate = 495			Estimates:
Details	min.	def	0.04	1.41	In 116		495	495			MW = 28.0 %H ₂ O = 14.0

PITOT LEAK CHECK

Before	Positive	Negative

GAS	1	2
CO ₂	6.5	6.5
O ₂	10.5	10.5
CO	8.0	8.0
N ₂	83.0	83.0

SYSTEM LEAK CHECK

Before	Vacuum (in. Hg)	DGM Rate (cfm)
After		

Impinger Contents

Impinger No.	Final	Initial	Difference
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			

ADVANCED TECHNOLOGY SYSTEMS, INC.

339 Haymaker Road Suite 201

Monroeville, PA 15146

412/856-0662

FAX 412/856-0666





TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
Percent of stack diameter from inside wall to traverse point

Traverse point number on a diameter	Number of traverse points on a diameter --											
	3	4	5	6	7	8	9	10	11	12	13	14
1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
24	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE 1-1. CROSS SECTION LAYOUT FOR
RECTANGULAR STACKS

Number of traverse points	Stack layout
3	3-3
4	4-4
5	5-5
6	6-6
7	7-7
8	8-8
9	9-9
10	10-10
11	11-11
12	12-12
13	13-13
14	14-14
15	15-15
16	16-16
17	17-17
18	18-18
19	19-19
20	20-20
21	21-21
22	22-22
23	23-23
24	24-24

THREE POINT CALIBRATION

	WET TEST METER						DRY TEST METER							METER COEFFICIENT Y	ORIFICE COEFFICIENT Δ H@
	TIME (min)	TEMP TW	VOLUME VM	PRESSURE PW	TEMP IN TI	TEMP OUT TO	TEMP AVG TA	ORIFICE PD	VOLUME VD						
START			0.000	28.95	98.0	89.0	93.5	0.50	350.100						
HALF		81.0													
STOP	12.75		5.000						355.151						
CALCULATION	12.75	541.0	5.013	28.95			553.5	28.99	5.051				1.0140		1.873
START			0.000	28.95	105.0	90.0	97.5	1.00	355.600						
HALF		81.0													
STOP	8.95		5.000						360.700						
CALCULATION	8.95	541.0	5.013	28.95			557.5	29.02	5.100				1.0103		1.833
START			0.000	28.95	110.0	92.0	101.0	2.00	361.200						
HALF		81.0													
STOP	6.30		5.000						366.234						
CALCULATION	6.30	541.0	5.013	28.95			561.0	29.10	5.034				1.0273		1.905
AVERAGE													1.0172		1.837

POST TEST

BOX # 6 BP 29.00 In. Hg
DATE 08-03-94 OPERATOR RPC

	WET TEST METER				DRY TEST METER							METER COEFFICIENT Y	ORIFICE COEFFICIENT Δ H@
	TIME (min)	TEMP TW	VOLUME VM	PRESSURE PW	TEMP IN TI	TEMP OUT TO	TEMP AVG TA	ORIFICE PD	VOLUME VD				
START			0.000	29.00	98.0	82.0	90.0	1.25	63.000				
HALF	7.90	72.0	5.000						68.309				
STOP													
CALCULATION	7.90	532.0	5.013	29.00			550.0	29.09	5.309		0.9730	1.747	
START			0.000	29.00	105.0	84.0	94.5	1.25	68.500				
HALF	7.95	72.0	5.000						73.541				
STOP													
CALCULATION	7.95	532.0	5.013	29.00			554.5	29.09	5.041		1.0331	1.754	
START			0.000	29.00				1.25	74.000				
HALF	7.98	72.0	5.000		111.0	87.0	99.0		79.073				
STOP													
CALCULATION	7.98	532.0	5.013	29.00			559.0	29.09	5.073		1.0349	1.753	
AVERAGE											1.0137	1.751	
DIFFERENCE											0.3%	4.9%	

PRE-TEST MAGNEHELIC CALIBRATION

BOX# 6
DATE 06-09-94
OPERATOR RPC

0 to 3.0" H2O RANGE

MAGNEHELIC	ΔP	MANOMETER
	0.50	0.50
	1.00	1.00
	2.00	2.00
	3.00	3.00

0 to 0.50" H2O RANGE
SLANT TUBE
PRIMARY STANDARD

MAGNEHELIC	ΔH	MANOMETER
	4.00	4.00
	3.00	3.00
	2.00	2.00
	1.00	1.00
	0.50	0.50

0 to 5" H2O RANGE

PRE-TEST LEAK CHECK

DATE 06-20-94
OPERATOR RPC

	START CF	STOP CF	VOLUME CF	TIME (min)	LEAK RATE
DRY	394.400	394.619	0.219	10.000	0.000
WET	0.000	0.222	0.222		

PYROMETER CALIBRATION

DATE 04-28-88
OPERATOR AGL

VOLTAGE INPUT (mV)	ARGE TEMP (°F)	TEMP READING (°F)
0.18	40	40.0
0.40	50	50.0
0.84	70	70.0
1.29	90	90.0
1.74	110	110.0
2.66	150	150.0
3.82	200	200.0
6.09	300	301.0
8.31	400	400.0
10.57	500	500.0

PRE-TEST PYROMETER CHECK

DATE 06-09-94
OPERATOR RPC

VOLTAGE INPUT (mV)	TARGET TEMP (°F)	TEMP READING (°F)
0.18	40	40.0
0.40	50	50.0
0.84	70	70.0
1.29	90	90.0
1.74	110	110.0
2.66	150	150.0
3.82	200	200.0
6.09	300	301.0
8.31	400	402.0
10.57	500	502.0

POST-TEST MAGNEHELIC CALIBRATION

BOX# 6

DATE 08-03-94

OPERATOR RPC

0 to 3.0" H2O RANGE

MAGNEHELIC
Δ P MANOMETER

0.50	0.50
1.00	1.00
2.00	2.00
3.00	3.00

0 to 0.50" H2O RANGE

SLANT TUBE

PRIMARY STANDARD

MAGNEHELIC
Δ H MANOMETER

4.00	4.00
3.00	3.00
2.00	2.00
1.00	1.00
0.50	0.50

0 to 5" H2O RANGE

POST-TEST LEAK CHECK

DATE 08-03-94

OPERATOR RPC

	START CF	STOP CF	VOLUME CF	TIME (min)	LEAK RATE
DRY	62.400	62.590	0.190	10.000	0.0000
WET	0.000	0.190	0.190		

PYROMETER CALIBRATION

DATE 04-28-88

OPERATOR AGL

POST-TEST PYROMETER CHECK

DATE 08-03-94

OPERATOR RPC

VOLTAGE INPUT (mV)	ARGE TEMP (°F)	TEMP READING (°F)	VOLTAGE INPUT (mV)	TARGET TEMP (°F)	TEMP READING (°F)
0.18	40	40.0	0.18	40	40.0
0.40	50	50.0	0.40	50	50.0
0.84	70	70.0	0.84	70	70.0
1.29	90	90.0	1.29	90	90.0
1.74	110	110.0	1.74	110	110.0
2.66	150	150.0	2.66	150	150.0
3.82	200	200.0	3.82	200	200.0
6.09	300	301.0	6.09	300	302.0
8.31	400	400.0	8.31	400	402.0
10.57	500	500.0	10.57	500	502.0

QA ORIFICE AUDIT

ORIFICE BAPC-3 DATE 06-09-94 B.P. 29.00
 OPERATOR RPC BOX # 6


RUN	1		2		3	
INITIAL CF	110.300		118.300		126.300	
FINAL CF	117.825		125.828		133.810	
DIFFERENCE	7.525		7.528		7.510	
TEMP INITIAL	IN	OUT	IN	OUT	IN	OUT
TEMP 5 MIN	105	100	102	98	102	97
TEMP 10 MIN	102	99	101	97	102	97
TEMP 15 MIN	102	98	102	97	103	98
	102	98	102	97	103	98
TEMP AVG	100.75		99.5		100	
	560.75		559.5		560	
TEMP R						
TIME (MIN.)	15.00		15.00		15.00	
ORIFICE	IN WATER	IN HG	IN WATER	IN HG	IN WATER	IN HG
	0.75	0.06	0.75	0.06	0.75	0.06
METER PRESSURE	29.06		29.06		29.06	
AMBIENT TEMP.	°F	°C	°F	°C	°F	°C
	78.0	25.6	78.0	25.6	78.0	25.6
VACUUM IN HG	21.0		21.0		21.0	
DGM CAL Y	1.0128		1.0128		1.0128	
STD CF	6.995		7.014		6.991	
STD CUBIC METERS	0.1981		0.1986		0.1980	

GEOMETRIC PITOT CALIBRATION

Caliper # X6F-59
 Precheck _____
 Post Check _____

Probe #: 10.2
 Date: 6-10-94
 Initials: RPC


①



$a^1 = 3^\circ$
 $a^2 = 0^\circ$
 $B^1 = 0^\circ$
 $B^2 = 1^\circ$
 $F = .93$

$a^1, a^2 = < 10^\circ$
 $B^1, B^2 = < 5^\circ$


②



$\mu = 16$
 $V = 0$
 $W = .194$

$\mu \leq 0.1250^\circ (\mu = F \tan \delta)$
 $V \leq 0.03125^\circ (V = F \tan \theta)$
 $W \geq 0^\circ$

③




$1.05 D_1 \leq D_2 \leq 1.50 D_1$
 $P_A = P_B$
 $2.10 D_1 \leq D_2 \leq 3.00 D_1$

$X = .097$
 $Y = 5.6$
 $Z = 3.6$
 $D_1 = .375$


$X \geq 0.750$
 $(3/4" \text{ using } 1/2" \text{ nozzle})$
 $Y \geq 3.0^\circ$
 $Z \geq 2.0^\circ$
 $D_1 \geq .1875$

④




(θ, ϕ EXPRESSED IN DEGREES)


⑤



⑥



⑦




GEOMETRIC PITOT CALIBRATION

Caliper # YGE-59
 Precheck _____
 Post Check _____

Probe #: 10-2
 Date: 08-03-84
 Initials: KE


①



$a^1 = 3^\circ$
 $a^2 = 0^\circ$
 $B^1 = 0^\circ$
 $B^2 = 1^\circ$
 $F = .94$

$a^1, a^2 < 10^\circ$
 $B^1, B^2 < 5^\circ$


②



$\mu = .16$
 $V = 0$
 $W = .194$

$\mu \leq 0.1250 (\mu = F \cdot T)$
 $V \leq 0.03125 (V = F \cdot T)$
 $W \geq 0$

③




$1.05 B_1 < 1.50 B_2$
 $P_A = P_B$
 $2.10 D_1 < 3.00 D_2$


$X = 0.97$
 $Y = 5.6$
 $Z = 3.8$
 $D_1 = .376$

$X \geq 0.750$
 (3/4" using 1/2" nozzle)
 $Y \geq 3.0$
 $Z \geq 2.0$
 $D_1 > .1875$


④




⑤



⑥



⑦



VISIBLE EMISSIONS OBSERVATION FORM

①

13 STACK

OBSERVER: R. BRIAN FAYTAK

DATE: 7/28/94

FACILITY: USX/CLAIRTON

OBSERVATION START TIME: 0830

END TIME: 0930

OBSERVATION POINT:
100' south of #19 BATH.

SOURCE:

DISTANCE: ≈ 300'

DIRECTION FROM: S-W

HEIGHT: ≈ 150'

WIND:

SPEED: < 5 mph

DIRECTION: South

TEMPERATURE: 66°F

WEATHER CONDITION: OVERCAST

BACKGROUND: SKY

LOADING CONDITIONS: GOOD

COLOR OF EMISSIONS: -

TOTAL # OF READINGS: 240

NO. READINGS 0 - 15%: 240

1). READINGS 20%: -

NO. READINGS 25 - 50%: -

1). READINGS 60 - 100%: -

NO. READINGS > 20%: 0

CLEAREST OPACITY: 0

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	☐
10	☐	☐	☐	☐
11	☐	☐	☐	☐
12	☐	☐	☐	☐
13	☐	☐	☐	☐
14	☐	☐	☐	☐
15	☐	☐	☐	☐
16	☐	☐	☐	☐
17	☐	☐	☐	☐
18	☐	☐	☐	☐
19	☐	☐	☐	☐
20	☐	☐	☐	☐
21	☐	☐	☐	☐
22	☐	☐	☐	☐
23	☐	☐	☐	☐
24	☐	☐	☐	☐
25	☐	☐	☐	☐
26	☐	☐	☐	☐
27	☐	☐	☐	☐
28	☐	☐	☐	☐
29	☐	☐	☐	☐

	:00	:15	:30	:45
30	☐	☐	☐	☐
31	☐	☐	☐	☐
32	☐	☐	☐	☐
33	☐	☐	☐	☐
34	☐	☐	☐	☐
35	☐	☐	☐	☐
36	☐	☐	☐	☐
37	☐	☐	☐	☐
38	☐	☐	☐	☐
39	☐	☐	☐	☐
40	☐	☐	☐	☐
41	☐	☐	☐	☐
42	☐	☐	☐	☐
43	☐	☐	☐	☐
44	☐	☐	☐	☐
45	☐	☐	☐	☐
46	☐	☐	☐	☐
47	☐	☐	☐	☐
48	☐	☐	☐	☐
49	☐	☐	☐	☐
50	☐	☐	☐	☐
51	☐	☐	☐	☐
52	☐	☐	☐	☐
53	☐	☐	☐	☐
54	☐	☐	☐	☐
55	☐	☐	☐	☐
56	☐	☐	☐	☐
57	☐	☐	☐	☐
58	☐	☐	☐	☐
59	☐	☐	☐	☐

VISIBLE EMISSIONS OBSERVATION FORM

②

#13 STACK

OBSERVER: R. BRIAN FAYTAK

DATE: 7/28/94

FACILITY: USX/CLAIRTON

OBSERVATION START TIME: 0930

END TIME: 1010

OBSERVATION POINT:

100' south of #19 Batt.

SOURCE:

DISTANCE: ≈ 300'

DIRECTION FROM: S-W

HEIGHT: ≈ 150'

WIND:

SPEED: < 5 mph

DIRECTION: South

TEMPERATURE: 68°F

SKY CONDITION: OVERCAST

BACKGROUND: SKY

WEATHER CONDITIONS: GOOD

COLOR OF EMISSIONS: -

TOTAL # OF READINGS: 162

NO. READINGS 0 - 15% -

NO. READINGS 16 - 20% -

NO. READINGS 21 - 50% -

NO. READINGS 51 - 100% -

NO. READINGS > 20% -

GREATEST OPACITY: 0

COMMENTS:

	:00	:15	:30	:45
00	○	○	○	○
01	○	○	○	○
02	○	○	○	○
03	○	○	○	○
04	○	○	○	○
05	○	○	○	○
06	○	○	○	○
07	○	○	○	○
08	○	○	○	○
09	○	○	○	○
10	○	○	○	○
11	○	○	○	○
12	○	○	○	○
13	○	○	○	○
14	○	○	○	○
15	○	○	○	○
16	○	○	○	○
17	○	○	○	○
18	○	○	○	○
19	○	○	○	○
20	○	○	○	○
21	○	○	○	○
22	○	○	○	○
23	○	○	○	○
24	○	○	○	○
25	○	○	○	○
26	○	○	○	○
27	○	○	○	○
28	○	○	○	○
29	○	○	○	○

	:00	:15	:30	:45
30	○	○	○	○
31	○	○	○	○
32	○	○	○	○
33	○	○	○	○
34	○	○	○	○
35	○	○	○	○
36	○	○	○	○
37	○	○	○	○
38	○	○	○	○
39	○	○	○	○
40	○	○		
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				

VISIBLE EMISSIONS OBSERVATION FORM

③

#13 STACK

OBSERVER: R. BRIAN FAYTAK

DATE: 7/28/94

FACILITY: USX/CLAIRTON

OBSERVATION START TIME: 1242 hrs

END TIME: 1342 hrs

OBSERVATION POINT:

1/2 mi South of #19 BATT.

SOURCE:

DISTANCE: ≈ 300'

DIRECTION FROM: S-W

HEIGHT: ≈ 150'

WIND:

SPEED: ≈ 5-10 mph

DIRECTION: S

TEMPERATURE: 76°

SKY CONDITION: 80% Cloudy

BACKGROUND: SKY

WEATHER CONDITIONS: Good

COLOR OF EMISSIONS: -

TOTAL # OF READINGS: 240

NO. READINGS 0 - 15%: 240

NO. READINGS 20%: -

NO. READINGS 25 - 50%: -

NO. READINGS 60 - 100%: -

NO. READINGS > 20%: -

GREATEST OPACITY: 0

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	☐
10	☐	☐	☐	☐
11	☐	☐	☐	☐
12	☐	☐	☐	☐
13	☐	☐	☐	☐
14	☐	☐	☐	☐
15	☐	☐	☐	☐
16	☐	☐	☐	☐
17	☐	☐	☐	☐
18	☐	☐	☐	☐
19	☐	☐	☐	☐
20	☐	☐	☐	☐
21	☐	☐	☐	☐
22	☐	☐	☐	☐
23	☐	☐	☐	☐
24	☐	☐	☐	☐
25	☐	☐	☐	☐
26	☐	☐	☐	☐
27	☐	☐	☐	☐
28	☐	☐	☐	☐
29	☐	☐	☐	☐

	:00	:15	:30	:45
30	☐	☐	☐	☐
31	☐	☐	☐	☐
32	☐	☐	☐	☐
33	☐	☐	☐	☐
34	☐	☐	☐	☐
35	☐	☐	☐	☐
36	☐	☐	☐	☐
37	☐	☐	☐	☐
38	☐	☐	☐	☐
39	☐	☐	☐	☐
40	☐	☐	☐	☐
41	☐	☐	☐	☐
42	☐	☐	☐	☐
43	☐	☐	☐	☐
44	☐	☐	☐	☐
45	☐	☐	☐	☐
46	☐	☐	☐	☐
47	☐	☐	☐	☐
48	☐	☐	☐	☐
49	☐	☐	☐	☐
50	☐	☐	☐	☐
51	☐	☐	☐	☐
52	☐	☐	☐	☐
53	☐	☐	☐	☐
54	☐	☐	☐	☐
55	☐	☐	☐	☐
56	☐	☐	☐	☐
57	☐	☐	☐	☐
58	☐	☐	☐	☐
59	☐	☐	☐	☐

VISIBLE EMISSIONS OBSERVATION FORM

④

#13 STACK

OBSERVER: R. BRIAN FAJAK

DATE: 7-28-94

ACTIVITY: USX / CLARTON

OBSERVATION START TIME: 1342 hrs.

END TIME: 1442 hrs

OBSERVATION POINT:
≈ 100' south of #19 Batt.

SOURCE:
DISTANCE: ≈ 300'
DIRECTION FROM: S-W
HEIGHT: ≈ 100'

WIND:
SPEED: ≈ 5-10 mph
DIRECTION: South

TEMPERATURE: 78°

MOON CONDITION: 90% Clouds

BACKGROUND: SKY

WINDING CONDITIONS: GOOD

COLOR OF EMISSIONS: —

TOTAL # OF READINGS: 240

NO. READINGS 0 - 15% 240

NO. READINGS 20% —

NO. READINGS 25 - 50% —

NO. READINGS 60 - 100% —

NO. READINGS > 20% —

GREATEST OPACITY: 0

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	☐
10	☐	☐	☐	☐
11	☐	☐	☐	☐
12	☐	☐	☐	☐
13	☐	☐	☐	☐
14	☐	☐	☐	☐
15	☐	☐	☐	☐
16	☐	☐	☐	☐
17	☐	☐	☐	☐
18	☐	☐	☐	☐
19	☐	☐	☐	☐
20	☐	☐	☐	☐
21	☐	☐	☐	☐
22	☐	☐	☐	☐
23	☐	☐	☐	☐
24	☐	☐	☐	☐
25	☐	☐	☐	☐
26	☐	☐	☐	☐
27	☐	☐	☐	☐
28	☐	☐	☐	☐
29	☐	☐	☐	☐

	:00	:15	:30	:45
30	☐	☐	☐	☐
31	☐	☐	☐	☐
32	☐	☐	☐	☐
33	☐	☐	☐	☐
34	☐	☐	☐	☐
35	☐	☐	☐	☐
36	☐	☐	☐	☐
37	☐	☐	☐	☐
38	☐	☐	☐	☐
39	☐	☐	☐	☐
40	☐	☐	☐	☐
41	☐	☐	☐	☐
42	☐	☐	☐	☐
43	☐	☐	☐	☐
44	☐	☐	☐	☐
45	☐	☐	☐	☐
46	☐	☐	☐	☐
47	☐	☐	☐	☐
48	☐	☐	☐	☐
49	☐	☐	☐	☐
50	☐	☐	☐	☐
51	☐	☐	☐	☐
52	☐	☐	☐	☐
53	☐	☐	☐	☐
54	☐	☐	☐	☐
55	☐	☐	☐	☐
56	☐	☐	☐	☐
57	☐	☐	☐	☐
58	☐	☐	☐	☐
59	☐	☐	☐	☐

VISIBLE EMISSIONS OBSERVATION FORM

5

#13 STACK

OBSERVER: R. Brian Fajtak

DATE: 7-28-94

ACTIVITY: USX/CLAIRTON

OBSERVATION START TIME: 1442 hrs.

END TIME: 1542 hrs

OBSERVATION POINT:

≈ 100' South of 19 Bldg.

SOURCE:

DISTANCE: ≈ 300'

DIRECTION FROM: S-W

HEIGHT: ≈ 150'

WIND:

SPEED: ≈ 5-10 mph

DIRECTION: S

TEMPERATURE: 77°

SKY CONDITION: 80% clouds

BACKGROUND: SKY

LOADING CONDITIONS: GOOD

COLOR OF EMISSIONS: -

TOTAL # OF READINGS: 240

NO. READINGS 0 - 15%: 240

NO. READINGS 20%: -

NO. READINGS 25 - 50%: -

NO. READINGS 60 - 100%: -

NO. READINGS > 200%: -

GREATEST OPACITY: 0

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	☐
10	☐	☐	☐	☐
11	☐	☐	☐	☐
12	☐	☐	☐	☐
13	☐	☐	☐	☐
14	☐	☐	☐	☐
15	☐	☐	☐	☐
16	☐	☐	☐	☐
17	☐	☐	☐	☐
18	☐	☐	☐	☐
19	☐	☐	☐	☐
20	☐	☐	☐	☐
21	☐	☐	☐	☐
22	☐	☐	☐	☐
23	☐	☐	☐	☐
24	☐	☐	☐	☐
25	☐	☐	☐	☐
26	☐	☐	☐	☐
27	☐	☐	☐	☐
28	☐	☐	☐	☐
29	☐	☐	☐	☐

	:00	:15	:30	:45
30	☐	☐	☐	☐
31	☐	☐	☐	☐
32	☐	☐	☐	☐
33	☐	☐	☐	☐
34	☐	☐	☐	☐
35	☐	☐	☐	☐
36	☐	☐	☐	☐
37	☐	☐	☐	☐
38	☐	☐	☐	☐
39	☐	☐	☐	☐
40	☐	☐	☐	☐
41	☐	☐	☐	☐
42	☐	☐	☐	☐
43	☐	☐	☐	☐
44	☐	☐	☐	☐
45	☐	☐	☐	☐
46	☐	☐	☐	☐
47	☐	☐	☐	☐
48	☐	☐	☐	☐
49	☐	☐	☐	☐
50	☐	☐	☐	☐
51	☐	☐	☐	☐
52	☐	☐	☐	☐
53	☐	☐	☐	☐
54	☐	☐	☐	☐
55	☐	☐	☐	☐
56	☐	☐	☐	☐
57	☐	☐	☐	☐
58	☐	☐	☐	☐
59	☐	☐	☐	☐

VISIBLE EMISSIONS OBSERVATION FORM

6

#13 ~~5~~ STACK

OBSERVER: R. BRIAN FAJAK

DATE: 7-28-94

FACILITY: USX/CLARTON

OBSERVATION START TIME: 1542 hrs.

END TIME: 1552 hrs.

OBSERVATION POINT:

~100' south of #19 Batt.

SOURCE:

DISTANCE: ~300'

DIRECTION FROM: S-W

HEIGHT: ~100'

WIND:

SPEED: ~5-10 mph

DIRECTION: S

TEMPERATURE: 79°

SKY CONDITION: 80% Clouds

BACKGROUND: SKY

WEATHER CONDITIONS: GOOD

COLOR OF EMISSIONS: _____

TOTAL # OF READINGS: 42

NO. READINGS 0 - 15%: 42

NO. READINGS 16 - 20%: -

NO. READINGS 21 - 25%: -

NO. READINGS 26 - 30%: -

NO. READINGS 31 - 35%: -

NO. READINGS 36 - 40%: -

NO. READINGS 41 - 45%: 0

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	☐
10	☐	☐		
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				

	:00	:15	:30	:45
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				

VISIBLE EMISSIONS OBSERVATION FORM

①

OBSERVER: R. BRIAN FAJTAK

DATE: 7/29/94

FACILITY: USX/CLAIRTON

OBSERVATION START TIME: 0740 hrs.

END TIME: 0840 hrs.

OBSERVATION POINT:

≈ 100' south of #19 Batt.

SOURCE:

DISTANCE: ≈ 300'

DIRECTION FROM: S-W

HEIGHT: ≈ 150'

WIND:

SPEED: ≈ 5-10 mph

DIRECTION: N-E

TEMPERATURE: 65°

SKY CONDITION: 10% clouds

BACKGROUND: SKY

READING CONDITIONS: GOOD

COLOR OF EMISSIONS: -

TOTAL # OF READINGS: 240

NO. READINGS 0 - 15%: 240

NO. READINGS 20%: -

NO. READINGS 25 - 50%: -

NO. READINGS 60 - 100%: -

NO. READINGS > 20%: -

GREATEST OPACITY: 0

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	☐
10	☐	☐	☐	☐
11	☐	☐	☐	☐
12	☐	☐	☐	☐
13	☐	☐	☐	☐
14	☐	☐	☐	☐
15	☐	☐	☐	☐
16	☐	☐	☐	☐
17	☐	☐	☐	☐
18	☐	☐	☐	☐
19	☐	☐	☐	☐
20	☐	☐	☐	☐
21	☐	☐	☐	☐
22	☐	☐	☐	☐
23	☐	☐	☐	☐
24	☐	☐	☐	☐
25	☐	☐	☐	☐
26	☐	☐	☐	☐
27	☐	☐	☐	☐
28	☐	☐	☐	☐
29	☐	☐	☐	☐

	:00	:15	:30	:45
30	☐	☐	☐	☐
31	☐	☐	☐	☐
32	☐	☐	☐	☐
33	☐	☐	☐	☐
34	☐	☐	☐	☐
35	☐	☐	☐	☐
36	☐	☐	☐	☐
37	☐	☐	☐	☐
38	☐	☐	☐	☐
39	☐	☐	☐	☐
40	☐	☐	☐	☐
41	☐	☐	☐	☐
42	☐	☐	☐	☐
43	☐	☐	☐	☐
44	☐	☐	☐	☐
45	☐	☐	☐	☐
46	☐	☐	☐	☐
47	☐	☐	☐	☐
48	☐	☐	☐	☐
49	☐	☐	☐	☐
50	☐	☐	☐	☐
51	☐	☐	☐	☐
52	☐	☐	☐	☐
53	☐	☐	☐	☐
54	☐	☐	☐	☐
55	☐	☐	☐	☐
56	☐	☐	☐	☐
57	☐	☐	☐	☐
58	☐	☐	☐	☐
59	☐	☐	☐	☐

VISIBLE EMISSIONS OBSERVATION FORM

(2)

OBSERVER: R. BRIAN FAYLAK

DATE: 7/29/94

FACILITY: USX/CLARKTON

OBSERVATION START TIME: 0840 LRS

END TIME: ~~0940 LRS~~ 0940 LRS

OBSERVATION POINT:
≈ 100' south of #19 BnH.

SOURCE:

DISTANCE: ≈ 300'

DIRECTION FROM: S-W

HEIGHT: ≈ 150'

WIND:

SPEED: ≈ 5-10 mph

DIRECTION: N-E

TEMPERATURE: 68°

SKY CONDITION: 25% clouds

BACKGROUND: SKY

READING CONDITIONS: GOOD

COLOR OF EMISSIONS: Green/Black

TOTAL # OF READINGS: 240

NO. READINGS 0 - 15%: 240

NO. READINGS 20%: —

NO. READINGS 25 - 55%: —

NO. READINGS 60 - 100%: —

NO. READINGS > 20%: —

GREATEST OPACITY: 5%

COMMENTS:

	:00	:15	:30	:45
00	☐	☐	☐	☐
01	☐	☐	☐	☐
02	☐	☐	☐	☐
03	☐	☐	☐	☐
04	☐	☐	☐	☐
05	☐	☐	☐	☐
06	☐	☐	☐	☐
07	☐	☐	☐	☐
08	☐	☐	☐	☐
09	☐	☐	☐	5
10	5	5	0	0
11	☐	☐	☐	☐
12	☐	☐	☐	☐
13	☐	☐	☐	☐
14	☐	☐	☐	☐
15	☐	☐	☐	☐
16	☐	☐	☐	☐
17	☐	☐	☐	☐
18	☐	☐	☐	☐
19	☐	☐	☐	☐
20	☐	☐	☐	☐
21	☐	☐	☐	☐
22	☐	☐	☐	☐
23	☐	☐	☐	☐
24	☐	☐	☐	☐
25	☐	☐	☐	☐
26	☐	☐	☐	☐
27	☐	☐	☐	☐
28	☐	☐	☐	☐
29	☐	☐	☐	☐

	:00	:15	:30	:45
30	☐	☐	☐	☐
31	☐	☐	☐	☐
32	☐	☐	☐	☐
33	☐	☐	☐	☐
34	☐	☐	☐	☐
35	☐	☐	☐	☐
36	☐	☐	☐	☐
37	☐	☐	☐	☐
38	☐	☐	☐	☐
39	☐	☐	☐	☐
40	☐	☐	☐	☐
41	☐	☐	☐	☐
42	☐	☐	☐	☐
43	☐	☐	☐	☐
44	☐	☐	☐	☐
45	☐	☐	☐	☐
46	☐	☐	☐	☐
47	☐	☐	☐	☐
48	☐	☐	☐	☐
49	☐	☐	☐	☐
50	☐	☐	☐	☐
51	☐	☐	☐	☐
52	☐	☐	☐	☐
53	☐	☐	☐	☐
54	☐	☐	☐	☐
55	☐	☐	☐	☐
56	☐	☐	☐	☐
57	☐	☐	☐	☐
58	☐	☐	☐	☐
59	☐	☐	☐	☐

VISIBLE EMISSIONS OBSERVATION FORM

③

OBSERVER: R. BRIAN FAYLAK

DATE: 7/29/94

FACILITY: USX/CLARKTON

OBSERVATION START TIME: 0940

END TIME: 0951

OBSERVATION POINT:

≈100' south of #19 BATT.

SOURCE:

DISTANCE: ≈300'

DIRECTION FROM: S-W

HEIGHT: ≈150'

WIND:

SPEED: ≈5-10 mph

DIRECTION: N-E

TEMPERATURE: 69°

SKY CONDITION: 10% clouds

BACKGROUND: SKY

READING CONDITIONS: GOOD

COLOR OF EMISSIONS: _____

TOTAL # OF READINGS: 46

NO. READINGS 0 - 15%: 46

0. READINGS 20%: -

NO. READINGS 25 - 55%: -

NO. READINGS 60 - 100%: -

NO. READINGS > 20%: -

GREATEST OPACITY: _____

COMMENTS:

	:00	:15	:30	:45
00	○	○	○	○
01	○	○	○	○
02	○	○	○	○
03	○	○	○	○
04	○	○	○	○
05	○	○	○	○
06	○	○	○	○
07	○	○	○	○
08	○	○	○	○
09	○	○	○	○
10	○	○	○	○
11	○	○		
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				

	:00	:15	:30	:45
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				

**COMPLIANCE DEMONSTRATION
NO. 13 BATTERY COMBUSTION STACK**

**USS CLAIRTON WORKS
A DIVISION OF USX CORPORATION
CLAIRTON, PENNSYLVANIA**

APPENDIX B

PLANT OPERATIONAL DATA

ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.

PUSHING SCHEDULE

Thursday, July 28, 1994 Turn 2

Batteries: 13-15_2

I	Oven	Last Pushed	Earliest	Desired	Latest
	B25/14	17:48	6:45aa	7:08aa	7:15aa
	A28/13	17:48	6:51aa	7:08aa	7:21aa
	B27/14	17:48	6:57aa	7:12aa	7:27aa
	A38/13	17:48	7:03aa	7:18aa	7:33aa
	B29/14	17:48	7:09aa	7:24aa	7:39aa
	B1/13	17:48	7:15aa	7:30aa	7:45aa
	A2/15	17:48	7:21aa	7:36aa	7:51aa
	B3/13	17:48	7:27aa	7:42aa	7:57aa
	A4/15	17:48	7:33aa	7:48aa	8:03aa
	B5/13	17:48	7:39aa	7:54aa	8:09aa
	A6/15	17:48	7:45aa	8:00aa	8:15aa
	B7/13	17:48	7:51aa	8:06aa	8:21aa
	A8/15	17:48	7:57aa	8:12aa	8:27aa
	B9/13	17:48	8:03aa	8:18aa	8:33aa
	A10/15	17:48	8:09aa	8:24aa	8:39aa
	B11/13	17:48	8:15aa	8:30aa	8:45aa
	A12/15	17:48	8:21aa	8:36aa	8:51aa
	B13/13	17:48	8:27aa	8:42aa	8:57aa
	A13/14	17:54	8:33aa	8:48aa	9:03aa
	B14/15	17:54	8:39aa	8:54aa	9:09aa
	A15/13	17:55	8:45aa	9:00aa	9:15aa
	B15/15	17:55	8:51aa	9:06aa	9:21aa
	A16/13	17:55	8:57aa	9:12aa	9:27aa
	B17/15	17:55	9:03aa	9:18aa	9:33aa
	A18/13	17:55	9:09aa	9:24aa	9:39aa
	B19/15	17:55	9:15aa	9:30aa	9:45aa
	A20/13	17:55	9:21aa	9:36aa	9:51aa
	B21/15	17:56	9:27aa	9:42aa	9:57aa
	A22/13	17:56	9:33aa	9:48aa	10:03aa
	B23/15	17:56	9:39aa	9:54aa	10:09aa
	A24/13	17:56	9:45aa	10:00aa	10:15aa
	B25/15	17:56	9:51aa	10:06aa	10:21aa
	A26/13	17:56	9:57aa	10:12aa	10:27aa
	B27/15	17:57	10:03aa	10:18aa	10:33aa
	A28/13	17:57	10:09aa	10:24aa	10:39aa
	B29/15	17:57	10:15aa	10:30aa	10:45aa
	A30/13	17:57	10:21aa	10:36aa	10:51aa
	B1/14	17:57	10:27aa	10:42aa	10:57aa
	A3/15	17:57	10:33aa	10:48aa	11:03aa
	B3/13	17:57	10:39aa	10:54aa	11:09aa
	A5/14	17:58	10:45aa	11:00aa	11:15aa
	B5/15	17:58	10:51aa	11:06aa	11:21aa
	A7/13	17:58	10:57aa	11:12aa	11:27aa
	B7/15	17:58	11:03aa	11:18aa	11:33aa
	A9/14	17:58	11:09aa	11:24aa	11:39aa
	B9/13	17:58	11:15aa	11:30aa	11:45aa
	A11/15	17:58	11:21aa	11:36aa	11:51aa
	B11/13	17:59	11:27aa	11:42aa	11:57aa
	A13/14	17:59	11:33aa	11:48aa	12:03aa
	B13/15	17:59	11:39aa	11:54aa	12:09aa
	A15/13	17:59	11:45aa	12:00aa	12:15aa
	B17/14	17:59	11:51aa	12:06aa	12:21aa
	A17/15	17:59	11:57aa	12:12aa	12:27aa
	B19/13	17:59	12:03aa	12:18aa	12:33aa
	A19/15	18:00	12:09aa	12:24aa	12:39aa
	B19/15	18:00	12:15aa	12:30aa	12:45aa
	A21/14	18:00	12:21aa	12:36aa	12:51aa
	B21/15	18:00	12:27aa	12:42aa	12:57aa
	A23/14	18:00	12:33aa	12:48aa	13:03aa
	B23/15	18:00	12:39aa	12:54aa	13:09aa
	A25/14	18:00	12:45aa	13:00aa	13:15aa
	B25/15	18:01	12:51aa	13:06aa	13:21aa
	A27/14	18:01	12:57aa	13:12aa	13:27aa
	B27/15	18:01	13:03aa	13:18aa	13:33aa
	A29/14	18:01	13:09aa	13:24aa	13:39aa
	B29/15	18:01	13:15aa	13:30aa	13:45aa
	A31/14	18:01	13:21aa	13:36aa	13:51aa
	B1/13	18:01	13:27aa	13:42aa	13:57aa
	A3/14	18:02	13:33aa	13:48aa	14:03aa
	B4/14	18:02	13:39aa	13:54aa	14:09aa
	A5/13	18:02	13:45aa	14:00aa	14:15aa
	B6/14	18:02	13:51aa	14:06aa	14:21aa
	A7/13	18:02	13:57aa	14:12aa	14:27aa
	B8/14	18:02	14:03aa	14:18aa	14:33aa
	A9/13	18:02	14:09aa	14:24aa	14:39aa
	B10/14	18:02	14:15aa	14:30aa	14:45aa
	A11/13	18:02	14:21aa	14:36aa	14:51aa
	B12/14	18:02	14:27aa	14:42aa	14:57aa
	A13/13	18:02	14:33aa	14:48aa	15:03aa
	B14/14	18:02	14:39aa	14:54aa	15:09aa

14/-A15

A15/14 after B13/13

PUSHING SCHEDULE

Thursday, July 28, 1994 Turn 3

Batteries: 13-15_2

#	Oven	Last Pushed	Earliest	Desired	Latest
---	A15/13	18:03	2:49pm	3:08pm	3:11pm
---	B16/14	18:03	2:53pm	3:05pm	3:16pm
---	A17/13	18:03	3:08pm	3:11pm	3:22pm
---	B18/14	18:03	3:08pm	3:17pm	3:26pm
---	A19/13	18:03	3:12pm	3:23pm	3:34pm
---	B20/14	18:03	3:16pm	3:25pm	3:40pm
---	A21/13	18:03	3:24pm	3:35pm	3:46pm
---	B22/14	18:02	3:29pm	3:40pm	3:51pm
---	A23/13	18:03	3:35pm	3:46pm	3:57pm
---	B24/14	18:03	3:41pm	3:52pm	4:03pm
---	A25/13	18:03	3:47pm	3:58pm	4:09pm
---	B26/14	18:03	3:53pm	4:04pm	4:15pm
---	A27/13	18:03	3:59pm	4:10pm	4:21pm
---	B28/14	18:03	4:05pm	4:16pm	4:27pm
---	A29/13	18:02	4:10pm	4:21pm	4:32pm
---	B30/14	18:03	4:16pm	4:27pm	4:38pm
---	A31/13	18:03	4:22pm	4:33pm	4:44pm
---	B1 /15	18:03	4:28pm	4:39pm	4:50pm
---	B2 /13	18:03	4:34pm	4:45pm	4:56pm
---	A3 /13	18:03	4:40pm	4:51pm	5:02pm
---	B4 /13	18:03	4:46pm	4:57pm	5:08pm
---	A5 /15	35:05	4:51pm	5:02pm	5:13pm
---	B6 /13	36:06	4:57pm	5:08pm	5:19pm
---	A7 /15	36:06	5:03pm	5:14pm	5:25pm
---	B8 /13	36:06	5:09pm	5:20pm	5:31pm
---	A9 /15	36:06	5:15pm	5:26pm	5:37pm
---	B10/13	36:06	5:21pm	5:32pm	5:43pm
---	A11/15	36:06	5:27pm	5:38pm	5:49pm
---	B12/13	36:06	5:33pm	5:44pm	5:55pm
---	A13/15	36:06	5:39pm	5:50pm	6:01pm
---	B14/13	36:06	5:45pm	5:56pm	6:07pm
---	A15/15	36:06	5:51pm	6:02pm	6:13pm
---	B16/13	36:06	5:57pm	6:08pm	6:19pm
---	A17/15	36:06	6:03pm	6:14pm	6:25pm
---	B18/13	36:06	6:09pm	6:20pm	6:31pm
---	A19/15	36:06	6:15pm	6:26pm	6:37pm
---	B20/13	36:06	6:21pm	6:32pm	6:43pm
---	A21/15	36:06	6:27pm	6:38pm	6:49pm
---	B22/13	36:06	6:33pm	6:44pm	6:55pm
---	A23/15	36:06	6:39pm	6:50pm	7:01pm
---	B24/13	36:06	6:45pm	6:56pm	7:07pm
---	A25/15	36:06	6:51pm	7:02pm	7:13pm
---	B26/13	36:06	6:57pm	7:08pm	7:19pm
---	A27/15	36:06	7:03pm	7:14pm	7:25pm
---	B28/13	36:06	7:09pm	7:20pm	7:31pm
---	A29/15	36:06	7:15pm	7:26pm	7:37pm
---	B30/13	36:06	7:21pm	7:32pm	7:43pm
---	A31/15	36:06	7:27pm	7:38pm	7:49pm
---	B1 /14	36:04	7:33pm	7:44pm	7:55pm
---	B2 /15	36:04	7:39pm	7:50pm	8:01pm
---	A4 /14	36:04	7:45pm	7:56pm	8:07pm
---	B4 /15	36:04	7:51pm	8:02pm	8:13pm
---	A6 /14	36:04	7:57pm	8:08pm	8:19pm
---	B6 /15	36:04	8:03pm	8:14pm	8:25pm
---	A8 /14	36:04	8:09pm	8:20pm	8:31pm
---	B8 /15	36:05	8:15pm	8:26pm	8:37pm
---	A10/14	36:05	8:21pm	8:32pm	8:43pm
---	B10/15	36:05	8:27pm	8:38pm	8:49pm
---	A12/14	36:03	8:33pm	8:44pm	8:55pm
---	B12/15	36:03	8:39pm	8:50pm	9:01pm
---	A14/14	36:03	8:45pm	8:56pm	9:07pm
---	B14/15	36:03	8:51pm	9:02pm	9:13pm
---	A16/14	36:03	8:57pm	9:08pm	9:19pm
---	B16/15	36:03	9:03pm	9:14pm	9:25pm
---	A18/14	36:02	9:09pm	9:20pm	9:31pm
---	B18/15	36:02	9:15pm	9:26pm	9:37pm
---	A20/14	36:02	9:21pm	9:32pm	9:43pm
---	B20/15	36:02	9:27pm	9:38pm	9:49pm
---	A22/14	36:02	9:33pm	9:44pm	9:55pm
---	B22/15	36:01	9:39pm	9:50pm	10:01pm
---	A24/14	36:01	9:45pm	9:56pm	10:07pm
---	B24/15	36:01	9:51pm	10:02pm	10:13pm
---	A26/14	36:01	9:57pm	10:08pm	10:19pm
---	B26/15	36:01	10:03pm	10:14pm	10:25pm
---	A28/14	36:01	10:09pm	10:20pm	10:31pm
---	B28/15	36:01	10:15pm	10:26pm	10:37pm
---	A30/14	36:00	10:21pm	10:32pm	10:43pm
---	B30/15	35:54	10:27pm	10:38pm	10:49pm
---	A2 /13	35:54	10:33pm	10:44pm	10:55pm
---	B1 /14	35:54	10:39pm	10:50pm	11:01pm

PUSHING SCHEDULE

Thursday, July 28, 1994 Turn 3

Batteries: 13-15_2

Oven	Last Pushed	Earliest	Desired	Latest
A4 /13	35:54	10:37pm	10:48pm	10:59pm
B3 /14	35:54	10:43pm	10:54pm	11:05pm

PUSHING SCHEDULE

Friday, July 29, 1994 Turn 1
Batteries: 13-15_2

Oven	Last Pushed	Earliest	Desired	Latest
A6 /13	35:54	18:49aa	11:08aa	11:11aa
B5 /14	35:53	18:55aa	11:05aa	11:16aa
A8 /13	35:53	11:00aa	11:11aa	11:22aa
B7 /14	35:53	11:06aa	11:17aa	11:28aa
A10/13	35:53	11:12aa	11:23aa	11:34aa
B9 /14	35:53	11:18aa	11:29aa	11:40aa
A12/13	35:53	11:24aa	11:35aa	11:46aa
B11/14	35:52	11:27aa	11:48aa	11:51aa
A14/13	35:52	11:33aa	11:46aa	11:57aa
B13/14	35:52	11:41aa	11:52aa	12:03aa
A16/13	35:52	11:47aa	11:58aa	12:09aa
B15/14	35:52	11:53aa	12:04aa	12:15aa
A18/13	35:52	11:59aa	12:10aa	12:21aa
B17/14	35:52	12:05aa	12:16aa	12:27aa
A20/13	35:51	12:10aa	12:21aa	12:32aa
B19/14	35:51	12:16aa	12:27aa	12:38aa
A22/13	35:51	12:22aa	12:33aa	12:44aa
B21/14	35:51	12:28aa	12:39aa	12:50aa
A24/13	35:51	12:34aa	12:45aa	12:56aa
B23/14	35:51	12:40aa	12:51aa	13:02aa
A26/13	35:51	12:46aa	12:57aa	13:08aa
B25/14	18:02	12:51aa	13:02aa	13:13aa
A28/13	18:02	12:57aa	13:08aa	13:19aa
B27/14	18:02	13:03aa	13:14aa	13:25aa
A30/13	18:02	13:09aa	13:20aa	13:31aa
B29/14	18:02	13:15aa	13:26aa	13:37aa
A1 /13	18:02	13:21aa	13:32aa	13:43aa
B2 /15	18:02	13:27aa	13:38aa	13:49aa
A3 /13	18:01	13:32aa	13:43aa	13:54aa
B4 /15	18:01	13:38aa	13:49aa	14:00aa
A5 /13	18:01	13:44aa	13:55aa	14:06aa
B6 /15	18:01	13:50aa	14:01aa	14:12aa
A7 /13	18:01	13:56aa	14:07aa	14:18aa
B8 /15	18:01	14:02aa	14:13aa	14:24aa
A9 /13	18:01	14:08aa	14:19aa	14:30aa
B10/15	18:00	14:14aa	14:25aa	14:36aa
A11/13	18:00	14:20aa	14:31aa	14:42aa
B12/14	18:00	14:26aa	14:37aa	14:48aa
A13/13	18:00	14:32aa	14:43aa	14:54aa
B14/15	17:54	14:38aa	14:49aa	15:00aa
A15/13	17:54	14:44aa	14:55aa	15:06aa
B16/15	17:53	14:50aa	15:01aa	15:12aa
A17/13	17:53	14:56aa	15:07aa	15:18aa
B18/15	17:53	15:02aa	15:13aa	15:24aa
A19/13	17:53	15:08aa	15:19aa	15:30aa
B20/15	17:53	15:14aa	15:25aa	15:36aa
A21/13	17:53	15:20aa	15:31aa	15:42aa
B22/15	17:53	15:26aa	15:37aa	15:48aa
A23/13	17:53	15:32aa	15:43aa	15:54aa
B24/15	17:53	15:38aa	15:49aa	16:00aa
A25/13	17:53	15:44aa	15:55aa	16:06aa
B26/15	17:53	15:50aa	16:01aa	16:12aa
A27/13	17:53	15:56aa	16:07aa	16:18aa
B28/15	17:53	16:02aa	16:13aa	16:24aa
A29/13	17:53	16:08aa	16:19aa	16:30aa
B30/15	17:53	16:14aa	16:25aa	16:36aa
A1 /14	17:51	16:20aa	16:31aa	16:42aa
B1 /15	17:51	16:26aa	16:37aa	16:48aa
A3 /14	17:51	16:32aa	16:43aa	16:54aa
B3 /15	17:51	16:38aa	16:49aa	17:00aa
A5 /14	17:51	16:44aa	16:55aa	17:06aa
B5 /15	17:51	16:50aa	17:01aa	17:12aa
A7 /14	17:50	16:56aa	17:07aa	17:18aa
B7 /15	17:50	17:02aa	17:13aa	17:24aa
A9 /14	17:50	17:08aa	17:19aa	17:30aa
B9 /15	17:50	17:14aa	17:25aa	17:36aa
A11/14	17:50	17:20aa	17:31aa	17:42aa
B11/15	17:50	17:26aa	17:37aa	17:48aa
A13/14	17:50	17:32aa	17:43aa	17:54aa
B13/15	17:49	17:38aa	17:49aa	18:00aa
A15/14	17:49	17:44aa	17:55aa	18:06aa
B15/15	17:49	17:50aa	18:01aa	18:12aa
A17/14	17:49	17:56aa	18:07aa	18:18aa
B17/15	17:49	18:02aa	18:13aa	18:24aa
A19/14	17:49	18:08aa	18:19aa	18:30aa
B19/15	17:49	18:14aa	18:25aa	18:36aa
A21/14	17:54	18:20aa	18:31aa	18:42aa
B21/15	17:54	18:26aa	18:37aa	18:48aa
A23/14	17:54	18:32aa	18:43aa	18:54aa
B23/15	17:54	18:38aa	18:49aa	19:00aa

PUSHING SCHEDULE

Friday, July 29, 1994 Turn 1
Batteries: 13-15_2

Oven	Last Pushed	Earliest	Desired	Latest
A25/14	17:54	6:37aa	6:48aa	6:59aa
B25/15	17:54	6:43aa	6:54aa	7:05aa

PUSHING SCHEDULE

Friday, July 29, 1994 Turn 2
Batteries: 13-15.2

Oven	Last Pushed	Earliest	Desired	Latest
A27/14	17:54	6:45am	7:00am	7:15am
B27/14	17:54	6:51am	7:06am	7:21am
A29/14	17:54	6:57am	7:12am	7:27am
B29/14	17:54	7:03am	7:18am	7:33am
A31/14	17:54	7:09am	7:24am	7:39am
B31/14	17:54	7:15am	7:30am	7:45am
A1/13	17:54	7:21am	7:36am	7:51am
B2/14	17:54	7:27am	7:42am	7:57am
A3/13	17:54	7:33am	7:48am	8:03am
B4/14	17:54	7:39am	7:54am	8:09am
A5/13	17:54	7:45am	8:00am	8:15am
B6/14	17:54	7:51am	8:06am	8:21am
A7/13	17:54	7:57am	8:12am	8:27am
B8/14	17:54	8:03am	8:18am	8:33am
A9/13	17:54	8:09am	8:24am	8:39am
B10/14	17:54	8:15am	8:30am	8:45am
A11/13	17:54	8:21am	8:36am	8:51am
B12/14	17:54	8:27am	8:42am	8:57am
A13/13	17:54	8:33am	8:48am	9:03am
B14/14	17:54	8:39am	8:54am	9:09am
A15/13	17:54	8:45am	9:00am	9:15am
B16/14	17:55	8:51am	9:06am	9:21am
A17/13	17:55	8:57am	9:12am	9:27am
B18/14	17:55	9:03am	9:18am	9:33am
A19/13	17:55	9:09am	9:24am	9:39am
B20/14	17:55	9:15am	9:30am	9:45am
A21/13	17:55	9:21am	9:36am	9:51am
B22/14	17:56	9:27am	9:42am	9:57am
A23/13	17:56	9:33am	9:48am	10:03am
B24/14	17:56	9:39am	9:54am	10:09am
A25/13	17:56	9:45am	10:00am	10:15am
B26/14	17:56	9:51am	10:06am	10:21am
A27/13	17:56	9:57am	10:12am	10:27am
B28/14	17:57	10:03am	10:18am	10:33am
A29/13	17:57	10:09am	10:24am	10:39am
B30/14	17:57	10:15am	10:30am	10:45am
A31/13	17:57	10:21am	10:36am	10:51am
B1/15	17:57	10:27am	10:42am	10:57am
A2/13	17:57	10:33am	10:48am	11:03am
B3/15	17:57	10:39am	10:54am	11:09am
A4/13	17:58	10:45am	11:00am	11:15am
B5/15	17:58	10:51am	11:06am	11:21am
A6/13	17:58	10:57am	11:12am	11:27am
B7/15	17:58	11:03am	11:18am	11:33am
A8/13	17:58	11:09am	11:24am	11:39am
B9/15	17:58	11:15am	11:30am	11:45am
A10/13	17:58	11:21am	11:36am	11:51am
B11/15	17:59	11:27am	11:42am	11:57am
A12/13	17:59	11:33am	11:48am	12:03am
B13/15	17:59	11:39am	11:54am	12:09am
A14/13	17:59	11:45am	12:00am	12:15am
B15/15	17:59	11:51am	12:06am	12:21am
A16/13	17:59	11:57am	12:12am	12:27am
B17/15	17:59	12:03pm	12:18pm	12:33pm
A18/13	17:59	12:09pm	12:24pm	12:39pm
B19/15	18:00	12:15pm	12:30pm	12:45pm
A20/13	18:00	12:21pm	12:36pm	12:51pm
B21/15	18:00	12:27pm	12:42pm	12:57pm
A22/13	18:00	12:33pm	12:48pm	1:03pm
B23/15	18:00	12:39pm	12:54pm	1:09pm
A24/13	18:00	12:45pm	1:00pm	1:15pm
B25/15	18:01	12:51pm	1:06pm	1:21pm
A26/13	18:01	12:57pm	1:12pm	1:27pm
B27/15	18:01	1:03pm	1:18pm	1:33pm
A28/13	18:01	1:09pm	1:24pm	1:39pm
B29/15	18:01	1:15pm	1:30pm	1:45pm
A30/13	18:01	1:21pm	1:36pm	1:51pm
B31/15	18:02	1:27pm	1:42pm	1:57pm
A1/14	18:02	1:33pm	1:48pm	2:03pm
B2/15	18:02	1:39pm	1:54pm	2:09pm
A3/14	18:02	1:45pm	2:00pm	2:15pm
B4/15	18:02	1:51pm	2:06pm	2:21pm
A5/14	18:02	1:57pm	2:12pm	2:27pm
B6/15	18:02	2:03pm	2:18pm	2:33pm
A7/14	18:02	2:09pm	2:24pm	2:39pm
B8/15	18:02	2:15pm	2:30pm	2:45pm
A9/14	18:02	2:21pm	2:36pm	2:51pm
B10/15	18:02	2:27pm	2:42pm	2:57pm
A11/14	18:02	2:33pm	2:48pm	3:03pm
B12/15	18:02	2:39pm	2:54pm	3:09pm
A13/14	18:02	2:45pm	3:00pm	3:15pm

CG-10295 REV. 1181
03.001.0020

UNITED STATES STEEL CORPORATION
CLAIRTON COKE AND COAL CHEMICAL WORKS

PUSHING AND CHARGING REPORT

UNIT NO. 5

12 Hrs. Beginning 10:00 AM

Date 7-28-94

11 AM 7/28/94

BATTERY NO. <u>13-A</u>				BATTERY NO. <u>13-B</u>				BATTERY NO. <u>14-A</u>			
OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES
1	1 08	1 39		1				1			
3	1 19	1 50	✓	3				3			
5	1 30	2 01	✓	5				5			
7	1 41	2 13		7				7			
9	1 52	2 18	✓	9				9		11 29	
11	2 03	2 24	✓	11				11		11 45	
13	2 15	2 30	✓	13				13	11 31	11 54	
15	3 00	3 19		15				15		12 05	Pass-on
17	3 11	3 29		17				17	11 45	12 16	
19	3 21	3 39	✓	19				19	11 57	12 27	
21	3 31	3 49	✓	21				21	12 07	12 37	
23	3 41	4 00		23				23	12 18	12 49	1/81
25	3 51	4 11		25				25	12 29	12 55	1/81
27	4 02	4 21		27				27	12 40	1 06	1/81
29	4 13	4 32		29				29	12 51	1 17	
31	4 23	4 43		31				31	12 57	1 28	
2	10 04			2	4 34	5 04		2	7 13	7 44	
4	10 16			4	4 45	5 14		4	7 24	7 55	
6				6	4 56	5 24		6	7 35	8 05	
8				8	5 06	5 34		8	7 46	8 17	
10				10	5 16	5 44		10	7 57	8 28	
12				12	5 26	5 56		12	8 07	8 41	
14				14	5 36	6 06		14	8 18	8 52	
16				16	5 46	6 17		16	8 31	9 03	
18				18	5 58	6 28		18	8 43	9 15	
20				20	6 08	6 39		20	8 54	9 27	
22				22	6 19	6 50		22	9 05	9 39	
24				24	6 30	7 00		24	9 17	9 51	
26				26	6 41	7 11		26	9 29	10 02	
28				28	6 52	7 22		28	9 41	10 14	
30				30	7 02	7 33		30	9 53		
1				1				1			
2				2				2			

REMARKS:

18 / 16 15 / 15 2 / 26

Condition of Signals

Condition of Pusher

HOURLY REPORT OF OPERATION

TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	
11-12	3	3	8 8	5-6	6	6	12 12	
1-7	6	6	11 11	6-7	5	5	11 11	Total Ovens Pushed 57
1-2	5	5	10 10	7-8	6	6	11 11	Total Ovens Charged 57
1-9	2	5	5 9	8-9	5	5	10 10	
1-4	6	4	12 10	9-10	5	5	10 10	Pusherman
4-8	6	5	12 11	10-11	2	2	4 4	Battery Foreman <u>J. J. [unclear]</u>
	28	28			29	29		

CG-10285 REV. 1161
03.001.0020

UNITED STATES STEEL CORPORATION
CLAIRTON COKE AND COAL CHEMICAL WORKS

PUSHING AND CHARGING REPORT

UNIT NO. 5

12 Hrs. Beginning 11:00 AM 11 PM 7/27/94
Date 7-28-94

BATTERY NO. <u>13-A</u>				BATTERY NO. <u>13-B</u>				BATTERY NO. <u>14-A</u>			
OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES
1				1	7 25	7 33		1	10 00	10 00	
3				3	7 35	7 43		3	10 10	10 15	✓
5				5	7 45	7 53		5	10 20	10 30	✓
7				7	7 55	8 03		7	10 30	10 38	✓
9				9	8 05	8 13		9	10 40		
11				11	8 15	8 23		11	10 50		
13				13	8 25	8 28		13			
15				15	8 40	8 48	41	15	8 50		
17				17	8 50	8 58	101	17			
19				19	9 00	9 08	101	19			
21				21	9 10	9 18	101	21			
23				23	9 20	9 28	101	23			
25				25	9 30	9 38		25			
27				27	9 40	9 48	✓ 101	27			
29				29	9 50	9 58	✓ 101	29			
31		11 04		31				31			
2	3 55	4 22		2		11 14		2	1 17	1 45	
4	4 04	4 32		4		11 24		4	1 27	1 56	
6	4 14	4 42		6	11 06	11 34		6	1 37	2 06	
8	4 24	4 52		8	11 16	11 44		8	1 47	2 16	
10	4 34	5 03		10	11 26	11 54		10	1 58	2 25	
12	4 44	5 14		12	11 36	12 04		12	2 08	2 36	
14	4 54	5 23		14	11 46	12 14		14	2 18	2 46	
16	5 05	5 40		16	11 56	12 24		16	2 28	2 56	
18	5 16	5 52		18	12 06	12 34		18	2 38	3 07	
20	5 30	6 01		20	12 16	12 44		20	2 48	3 17	
22	5 42	6 10		22	12 26	12 54		22	2 58	3 27	
24	5 54	6 15		24	12 36	1 05		24	3 08	3 37	
26	6 06	6 20		26	12 46	1 15		26	3 19	3 48	
28	7 05	7 13		28	12 56	1 25		28	3 29	4 02	
30	7 15	7 23		30	1 07	1 35		30	3 39	4 12	
1				1				1			
2				2				2			

REMARKS:

15/16 28/30 22/10

Condition of Signals

Condition of Pusher

HOURLY REPORT OF OPERATION

TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	
11/1	6	6	12/13	5	5	6	10/10	
11/2	6	6	12/12	6	1	2	1/2	Total Ovens Pushed 25
11/3	6	6	12/12	7	6	5	12/11	Total Ovens Charged 65
11/4	6	6	12/12	8	6	6	11/11	
11/5	5	5	11/12	9	6	6	12/12	Pusherman
11/6	6	7	12/12	10	6	4	11/9	Battery Foreman
	35	35			30	30		

CC-10295 REV. 1161
03.001.0020

UNITED STATES STEEL CORPORATION
CLAIRTON COKE AND COAL CHEMICAL WORKS

PUSHING AND CHARGING REPORT

UNIT NO. #5

12 Hrs. Beginning 12:00 PM

Date 7-29-94

11 AM 7/29/94

BATTERY NO. <u>13-A's</u>				BATTERY NO. <u>13-B's</u>				BATTERY NO. <u>14-A's</u>			
OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES
1				1	7 05	7 34		1	9 52		
3				3	7 16	7 47		3	10 04		
5				5	7 26	7 54		5	10 16		
7				7	7 36	8 04		7			
9				9	7 46	8 15		9			
11				11	7 56	8 25		11			
13				13	8 06	8 36		13			
15				15	8 17	8 48		15			
17				17	8 27	9 02		17			
19				19	8 38	9 14		19			
21				21	8 50	9 26		21			
23				23	9 04	9 38		23			
25				25	9 16	9 50		25			
27				27	9 28	10 02		27			
29				29	9 40	10 14		29			
31				X	X	X		31			
2	4 28	4 46		2				2	1 16	1 57	
4	4 38	5 05		4				4	1 27	2 01	
6	4 48	5 15		6				6	1 38	2 10	
8	4 58	5 25		8				8	1 49	2 20	
10	5 07	5 36		10				10	1 59	3 03	
12	5 17	5 37		12				12	2 11	3 13	
14	5 27	5 43		14	11 39	12 08		14	2 22	3 23	
16	5 34	6 13		16	11 49	12 19		16	3 05	3 33	
18	5 39	6 18		18	11 59	12 30		18	3 15	3 43	
20	5 45	6 33		22	12 10	12 47		20	3 25	3 53	
22	6 15	6 43		22	12 21	12 53		22	3 35	4 04	
24	6 20	6 53		24	12 32	1 03		24	3 45	4 14	
26	6 35	7 03		26	12 43	1 14		26	3 55	4 20	
28	6 45	7 14		28	12 54	1 25		28	4 06	4 36	
30	6 55	7 24		30	1 05	1 36		30	4 16	4 36	
X	X	X		X	X	X		X	X	X	
X	X	X		X	X	X		X	X	X	

REMARKS:

15/15 24/24 18/15

Condition of Signals

Condition of Pusher

HOURLY REPORT OF OPERATION

TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	
11-12	3	0	9 6	5-6	6	6	11 11	
12-1	5	5	9 9	6-7	5	5	11 11	Total Ovens Pushed <u>57</u>
1-2	6	6	11 11	7-8	6	6	12 12	Total Ovens Charged <u>54</u>
2-3	2	2	4 4	8-9	5	5	10 10	
3-4	6	6	12 12	9-10	5	5	10 10	Pusherman
4-5	6	6	12 12	10-11	2	2	4 4	Battery Foreman
	<u>28</u>	<u>25</u>			<u>29</u>	<u>29</u>		

GC-16295 REV. 1181
03.001.0020

UNITED STATES STEEL CORPORATION
CLAIRTON COKE AND COAL CHEMICAL WORKS

PUSHING AND CHARGING REPORT

UNIT NO. #5

12 Hrs. Beginning 11 pm 7/22/94

Date 7-29-94

BATTERY NO. <u>13-A</u>				BATTERY NO. <u>13-B</u>				BATTERY NO. <u>14-H</u>			
OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES	OVEN NO.	TIME PUSHED	TIME CHARGED	NOTES
1	7 25	7 53	✓	1	1 08	1 30		1	3 36	3 58	
3	7 35	8 03	✓	3	1 12	1 39		3	3 46	4 09	
5	7 45	8 13	✓	5	1 28	1 48		5	3 56	4 19	
7	7 55	8 23	✓	7	1 37	1 58		7	4 07	4 29	
9	8 05	8 33	✓	9	1 46	2 08		9	4 17	4 27	
11	8 15	8 43	✓	11	1 56	2 17		11	4 27	4 47	
13	8 25	8 53	✓	13	2 06	2 27		13	4 37	5 00	
15	8 35	9 03	✓	15	2 15	2 37		15	4 47	5 50	S.M.T.
17	8 45	9 13	✓	17	2 25	2 47		17	4 57	5 35	
19	8 55	9 23	✓	19	2 35	2 57		19	5 10	6 03	
21	9 05	9 33	✓	21	2 45	3 07		21	5 30	7 11	
23	9 15	9 43	✓	23	2 55	3 17		23	5 47	7 01	
25	9 25	9 53		25	3 05	3 27		25	6 10	7 13	
27	9 35	10 03		27	3 15	3 38		27	7 00	7 23	
29	9 45	10 13		29	3 25	3 48		29	7 10	7 51	
31	9 55	10 23		31				31	7 15	7 43	✓
2		11 10		2	10 05	10 37		2			
4		11 19		4	10 15	10 38		4			
6	11 00	11 26		6	10 25	10 47		6			
8	11 08	11 36		8	10 35	10 48		8			
10	11 17	11 42		10	10 45	10 53		10			
12	11 28	11 50		12	10 55	10 58		12			
14	11 38	12 00		14				14			
16	11 48	12 10		16				16			
18	11 58	12 20		18				18			
20	12 08	12 30		20				20			
22	12 18	12 40		22				22			
24	12 28	12 50		24				24			
26	12 38	1 00		26				26			
28	12 48	1 10		28				28			
30	12 58	1 20		30				30		11 02	
1				1				1			
2				2				2			

REMARKS: A15/13 CHUCK DOOR NEEDS OILED

VERY TIGHT!

29/31

21/21


16/17


Condition of Signals


Condition of Pusher


HOURLY REPORT OF OPERATION


TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED	TIME	OVENS PUSHED	OVENS CHARGED	OVENS SCHEDULED
11	7	7		65	3	2	
12	6	6		76	1	1	
13	6	7		87	7	7	
24	6	6		98	6	7	
35	6	6		109	6	6	
46	6	5		110	6	9	
	37	37			29	32	
				Total Ovens Pushed <u>66</u>			
				Total Ovens Charged <u>69</u>			
				Pusherman			
				Battery Foreman <u>W. J. ...</u>			





























**COMPLIANCE DEMONSTRATION
NO. 13 BATTERY COMBUSTION STACK**

**USS CLAIRTON WORKS
A DIVISION OF USX CORPORATION
CLAIRTON, PENNSYLVANIA**

**APPENDIX C
GRAVIMETRIC AND ANALYTICAL RESULTS, EMISSIONS
CALCULATIONS**

ATS

ADVANCED TECHNOLOGY SYSTEMS, INC.

[illegible]

Analyst's Signature _____
Date _____

Comments

STACK SAMPLING CALCULATIONS

CLIENT: USS CLAIRTON WORKS

TEST DATE: 07-28-94

TEST SITE #13 BATTERY COMBUSTION STACK

TEST NUMBER: CLR-BS#13-1

A.	Barometric Pressure	29.30	in. Hg	
B.	Static Pressure	-1.0	in. H2O	
C.	Stack Pressure	29.23	in. Hg	[A+(B/13.6)]
D.	Average Δ H	1.21	in. H2O	
E.	Meter Pressure	29.39	in. Hg	[A+(D/13.6)]
F.	Average Δ P	0.04	in. H2O	
G.	Pitot Coefficient	0.84		
H.	Gas Meter Coefficient	1.0172		
I.	Stack Diameter	120	in.	
J.	Stack Area	78.54	ft ²	(0.00545*I ²)
K.	Nozzle Diameter	0.490	in.	
L.	Nozzle Area	1.31E-03	ft ²	(0.00545*K ²)
M.	Average Stack Temperature	496	°F	
N.	Average Stack Temperature	956	°R	(460+M)
O.	Average Meter Temperature	90	°F	
P.	Average Meter Temperature	550	°R	(460+O)
Q.	Condensate Volume	253.9	ml	
R.	Absorbed H2O	22.1	ml	
S.	Total H2O	276.0	ml	(Q+R)
T.	Filter Weight	0.0203	g	
U.	Probe Weight	0.0341	g	
V.	Impinger Weight	0.0013	g	
W.	Total Weight	0.0557	g	(T+U+V)
X.	Metered Gas Volume	73.885	dscf	
Y.	Corrected Metered Gas Volume	75.156	dscf	(X*H)
Z.	H2O Gas Volume	13.822	cf	(0.00267*S*P/A)
AA.	Total Sample Volume	88.978	cf	(Y+Z)
BB.	Percent H2O	15.5	%	(100*Z/AA)
CC.	Gas Volume Sampled	70.923	dscf	[Y*(528/P)*(E/29.92)]
DD.	Grain Loading	0.0121	gr/dscf	(15.43*W/CC)
EE.	Average Molecular Weight:			

Component	% Volume +100	*(1-BB/100)	* Mol. Weight	= Weight/Mol
H2O	0.155		18	2.796
CO2	0.060	0.845	44	2.230
CO	0.000	0.845	28	0.000
O2	0.105	0.845	32	2.838
N2	0.835	0.845	28	19.748

Average Molecular Weight

27.61

lb./lb. mol

FF.	Average Stack Velocity	15.6	fps	{85.49*G*[(F*N)/(C*EE)]^0.5}
GG.	Average Flow Rate	73700	acfm	(60*FF*I)
HH.	Standard Flow Rate	39800	scfm	[GG*(528/N)*(C/29.92)]
II.	Sample Time	7200	sec	
JJ.	Percent Isokinetic	105.4	%	{[100*CC*60*J]/[HH*L*II*(1-BB/100)]}
KK.	Mass Flow Rate	3.49	lb/hr	[DD*HH*(1-BB/100)*60/7000]

STACK SAMPLING CALCULATIONS

CLIENT: USS CLAIRTON WORKS
 TEST SITE #13 BATTERY COMBUSTION STACK

TEST DATE: 07-28-94
 TEST NUMBER: CLR-BS#13-2

A.	Barometric Pressure	29.30	in. Hg	
B.	Static Pressure	-1.0	in. H2O	
C.	Stack Pressure	29.23	in. Hg	[A*(B/13.6)]
D.	Average ΔH	1.27	in. H2O	
E.	Meter Pressure	29.39	in. Hg	[A*(D/13.6)]
F.	Average ΔP	0.04	in. H2O	
G.	Pitot Coefficient	0.84		
H.	Gas Meter Coefficient	1.0172		
I.	Stack Diameter	120	in.	
J.	Stack Area	78.54	ft²	(0.00545*I²)
K.	Nozzle Diameter	0.490	in.	
L.	Nozzle Area	1.31E-03	ft²	(0.00545*K²)
M.	Average Stack Temperature	498	°F	
N.	Average Stack Temperature	958	°R	(460+M)
O.	Average Meter Temperature	106	°F	
P.	Average Meter Temperature	566	°R	(460+O)
Q.	Condensate Volume	275.4	mL	
R.	Absorbed H2O	21.3	mL	
S.	Total H2O	296.7	mL	(Q+R)
T.	Filter Weight	0.0178	g	
U.	Probe Weight	0.0310	g	
V.	Impinger Weight	0.0011	g	
W.	Total Weight	0.0499	g	(T+U+V)
X.	Metered Gas Volume	75.690	def	
Y.	Corrected Metered Gas Volume	76.992	def	(X*H)
Z.	H2O Gas Volume	15.312	cf	(0.00267*S*P/A)
AA.	Total Sample Volume	92.304	cf	(Y+Z)
BB.	Percent H2O	16.6	%	(100*Z/AA)
CC.	Gas Volume Sampled	70.515	dscf	[Y*(528/P)*(E/29.92)]
DD.	Grain Loading	0.0109	gr/dscf	(15.43*W/CC)
EE.	Average Molecular Weight:			

Component	% Volume -100	*(1-BB/100)	* Mol. Weight	= Weight/Mol
H2O	0.166		18	2.986
CO2	0.060	0.834	44	2.202
CO	0.000	0.834	28	0.000
O2	0.105	0.834	32	2.803
N2	0.835	0.834	28	19.501

Average Molecular Weight 27.49 lb./lb. mol

FF.	Average Stack Velocity	15.7	fps	{85.49*G*[(F*N)/(C*EE)]*0.5}
GG.	Average Flow Rate	73900	acfm	(60*FF*J)
HH.	Standard Flow Rate	39800	scfm	[GG*(528/N)*(C/29.92)]
II.	Sample Time	7200	sec	
JJ.	Percent Isokinetic	106.2	%	{[100*CC*60*J]/[HH*L*II*(1-BB/100)]}
KK.	Mass Flow Rate	3.11	lb/hr	[DD*HH*(1-BB/100)*60/7000]

STACK SAMPLING CALCULATIONS

CLIENT: USS CLAIRTON WORKS
TEST SITE #13 BATTERY COMBUSTION STACK

TEST DATE: 07-29-94
TEST NUMBER: CLR-BS#13-3

A.	Barometric Pressure	29.40	in. Hg	
B.	Static Pressure	-1.1	in. H2O	
C.	Stack Pressure	29.32	in. Hg	[A+(B/13.6)]
D.	Average ΔH	1.14	in. H2O	
E.	Meter Pressure	29.48	in. Hg	[A+(D/13.6)]
F.	Average ΔP	0.04	in. H2O	
G.	Pitot Coefficient	0.84		
H.	Gas Meter Coefficient	1.0172		
I.	Stack Diameter	120	in.	
J.	Stack Area	78.54	ft ²	(0.00545*I ²)
K.	Nozzle Diameter	0.490	in.	
L.	Nozzle Area	1.31E-03	ft ²	(0.00545*K ²)
M.	Average Stack Temperature	495	°F	
N.	Average Stack Temperature	955	°R	(460+M)
O.	Average Meter Temperature	93	°F	
P.	Average Meter Temperature	553	°R	(460+O)
Q.	Condensate Volume	263.7	mL	
R.	Absorbed H2O	18.2	mL	
S.	Total H2O	281.9	mL	(Q+R)
T.	Filter Weight	0.0150	g	
U.	Probe Weight	0.0415	g	
V.	Impinger Weight	0.0013	g	
W.	Total Weight	0.0578	g	(T+U+V)
X.	Metered Gas Volume	72.142	def	
Y.	Corrected Metered Gas Volume	73.383	def	(X*H)
Z.	H2O Gas Volume	14.157	cf	(0.00267*S*P/A)
AA.	Total Sample Volume	87.540	cf	(Y+Z)
BB.	Percent H2O	16.2	%	(100*Z/AA)
CC.	Gas Volume Sampled	69.046	dscf	[Y*(528/P)*(E/29.92)]
DD.	Grain Loading	0.0129	gr/dscf	(15.43*W/CC)
EE.	Average Molecular Weight:			

Component	% Volume +100	*(1-BB/100)	* Mol. Weight	= Weight/Mol
H2O	0.162		18	2.911
CO2	0.065	0.838	44	2.397
CO	0.000	0.838	28	0.000
O2	0.105	0.838	32	2.817
N2	0.830	0.838	28	19.482

Average Molecular Weight 27.61 lb./lb. mol

FF.	Average Stack Velocity	15.6	fps	{85.49*G*[(F*N)/(C*EE)]*0.5}
GG.	Average Flow Rate	73500	acfm	(60*FF*J)
HH.	Standard Flow Rate	39800	scfm	[GG*(528/N)*(C/29.92)]
II.	Sample Time	7200	sec	
JJ.	Percent Isokinetic	103.4	%	{[100*CC*60*J]/[HH*L*II*(1-BB/100)]}
KK.	Mass Flow Rate	3.69	lb/hr	[DD*HH*(1-BB/100)*60/7000]

CHAIN OF CUSTODY RECORD

[illegible]

RJ Lee Group, Inc.

LABORATORY REPORT

350 Hochberg Road Monroeville, PA 15146
Phone (412) 325-1776 Fax (412) 733-1799

RECEIVED

RJ Lee Group Job No.: INH408743

At:

Samples Received: 10-Aug-94

Report Date: 12-Aug-94

Client Project: NA

Purchase Order No.: 29182

ATS

Advanced Technology Systems, Inc.
339 Haymaker Road, Suite 201
Monroeville, PA 15146
Attention: Patrick Stockton
(412) 856-0662
Analysis: Determination of Sulfate in Solution
Method: Ion Chromatography

Sample Identification		Sulfate	Volume	Total mg
Client	RJ Lee Group	ppm	ml	
Q1R-BSM13-1	0134074	204	50	10.2
Q1R-BSM13-2	0134075	190	50	9.50
Q1R-BSM13-3	0134076	426	50	21.3
Q1R-BSM13-SOI-BLK	0134077	< 1.0	50	< 0.050

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted. Users notified in writing to return the samples covered by this report. RJ Lee Group will store the samples for a period of thirty (30) days before discarding. A shipping and handling fee will be assessed for the return of any samples.

Analyst

Date

9.4
8-12-94