

Prepared for
U.S. Environmental Protection Agency

EPA Contract No. 68-02-3157

Technical Directive 008

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

FERROALLOY FURNACE EMISSION
FACTOR DEVELOPMENT
INTERLAKE INC., ALABAMA METALLURGICAL
CORPORATION, SELMA, ALABAMA

Revised Draft Final Report

May 1981

Prepared by
Sandra Beaton
Stephen Gronberg
Joseph Vay

GCA CORPORATION
GCA/TECHNOLOGY DIVISION
Bedford, Massachusetts

CONTENTS

Figures	iii
Tables	iv
1. Introduction	1
2. Summary of Results and Conclusions	2
3. Process Description	6
4. Sampling and Analysis Procedures	9
Introduction	9
Presampling Preparations	9
Cascade Impactor Sampling	10
Andersen Impactor Gravimetric Analysis	12
Process Observations	13
Sampling and Analysis Quality Assurance	13
5. Test Results	14
Introduction	14
Total Particulate Results	15
Particle Sizing Results	15
Size-Specific Particulate Emission Factors	26
Visible Emissions Data	26
Furnace Operations Data	28
 Appendices	
A. Sample Train Calibrations	35
B. Particle Size Data Reduction Example Calculations	51
C. Total Particulate Example Calculations (by RTI)	56
D-1 Cascade Impactor Data Reduction System Printouts, Baghouse Inlet	62
D-2 Cascade Impactor Data Reduction System Printouts Baghouse Outlet	77
E-1 Cascade Impactor Field Data Sheets	88
E-2 Visible Emission Observer Data Sheets	120
E-3 Process Observer Data Sheets	133
E-4 Process Observer Data Sheets by RTI	145

FIGURES

<u>Number</u>		<u>Page</u>
1	Average particle size distribution, uncontrolled silicon metal furnace emissions (baghouse inlet), Alamet, Selma, Alabama	4
2	Average particle size distribution, controlled silicon metal furnace emissions (baghouse outlet), Alamet, Selma, Alabama	5
3	Process schematic--Alamet, Selma, Alabama	7
4	Andersen sampling train	11
5	Average change in concentration per particle size (all runs), Alamet, Selma, Alabama	21
6	Baghouse efficiency per particle size, Alamet, Selma, Alabama .	22

TABLES

<u>Number</u>		<u>Page</u>
1	Summary of Total Particulate and Particle Size Distribution Test Results, Alamet, Selma, Alabama	3
2	Baghouse Inlet Sampling Data, Alamet, Selma, Alabama	16
3	Baghouse Outlet Sampling Data, Alamet, Selma, Alabama	17
4	Total Particulate Test Results (by RTI) Baghouse Inlet Sampling Location, Alamet, Selma, Alabama	18
5	Total Particulate Test Results (by RTI) Baghouse Outlet Sampling Location, Alamet, Selma, Alabama	19
6	Baghouse Total Particulate Removal Efficiencies, Alamet, Selma, Alabama	20
7	Baghouse Size Specific Particulate Removal Efficiencies, Alamet, Selma, Alabama	23
8	Impactor Sampling Data Summary, Baghouse Inlet, Alamet, Selma, Alabama	25
9	Size Specific Emission Factors, Alamet, Selma, Alabama	27
10	Correlation of Test Runs to Furnace Operations at Furnace No. 2, Alamet, Selma, Alabama	29
11	Power Consumption of Furnace No. 2 at Alamet	29
12	Charge Composition, No. 2 Furnace, Alamet, Selma, Alabama	30
13	Production and Metal Analysis Data for Furnace No. 2 at Alamet, Selma, Alabama	31
14	Daily Average of Baghouse Pressure, Temperature and Fan Amps, Alamet, Selma, Alabama	31
15	Baghouse Control System Design Parameters, Alamet, Selma, Alabama	33

SECTION 1

INTRODUCTION

The purpose of this program was to develop total and size specific particulate emission factors for the silicon (Si) metal furnace at Interlake Inc., Alabama Metallurgical Corporation (Alamet), Selma, Alabama. Furnace No. 2 at Alamet, an open submerged electric arc furnace rated at 17 megawatts (MW), was producing 98 percent silicon metal during the January 1981 test program. Total particulate concentration and particle size distribution of emissions captured by the canopy hood evacuation system were measured before and after the baghouse using EPA Method 1-5 procedures and Andersen cascade impactors.

Entropy Environmentalists conducted the total particulate tests under subcontract to Research Triangle Institute (RTI) as part of a Level 2 Environmental Assessment of emissions of organic species from various ferroalloy furnaces. This Level 2 characterization of organic species (as BaP) was conducted utilizing EPA Method 1-5 particulate sampling procedures modified to include an absorbent trap (XAD-2) between the third and fourth impingers. GCA/Technology Division conducted particle size distribution tests simultaneous with the total particulate (Level 2) tests by Entropy. In addition, GCA provided a process observer to document relevant furnace operations and cycle times, to assess the capture efficiency of the canopy hood control system and to ensure that testing was performed only during normal furnace operations. This observer also performed EPA Method 9 visible emission observations of the furnace building roof monitor and the baghouse outlet.

SECTION 2

SUMMARY OF RESULTS AND CONCLUSIONS

The sampling and analysis program was conducted according to the approved Test Plan. Modified EPA Method 5 and Andersen cascade impactor sampling procedures were performed at the inlet and outlet of the baghouse controlling emissions from the No. 2 furnace at Alamet. A summary of results of the combined efforts of GCA/Technology Division and Entropy Environmentalists is presented in Table 1 and Figures 1 and 2. Research Triangle Institute analyzed the total particulate data and provided results that were utilized in the size specific emission factor calculations. The report to be published by RTI should be consulted concerning sampling and analytical procedures and results for the total particulate runs. The uncontrolled particulate emission factors (inlet side tests) are considered more viable than controlled emission factors (baghouse outlet test results) since outlet testing was performed at a poor sampling location. The uncontrolled emission factors in this report represent the emissions that would occur if only the baghouse was off-line.

The field testing program was performed during the week of 26 January 1981 while the furnace was producing 98+ percent silicon metal. Production of silicon metal is very energy intensive and high temperatures in the furnace are required, e.g., tap stream temperature is about 2700°F. Approximately 12 MWH are required to produce 1 ton of metal. This furnace produces 33 tons of silicon metal per day. Sections 3 and 5 of this report describe the process and present the operating data obtained during the field testing program.

TABLE 1. SUMMARY OF TOTAL PARTICULATE AND PARTICLE
SIZE DISTRIBUTION TEST RESULTS
ALAMET, SELMA, ALABAMA

		Average inlet	Average outlet
<u>Total Particulate Emission Factors</u>			
Mass Concentration	mg/dscm	1236.6	31.3
	gr/dscf	0.54	0.014
Mass Emission Rate	kg/MWh	32.55	1.22
	lb/hr	1250.4	43.45
Process Weight Rate	kg/Mg produced	436	16.5
	lb/ton produced	872	33
<u>Particle Size Distribution</u>			
Cumulative % mass	<15 μ m d ₅₀	86	91
	<2.5 μ m d ₅₀	70	56
Mass Emission Rate	lb <15 μ m d ₅₀ /hr	1075	40
	lb <2.5 μ m d ₅₀ /hr	875	24
<u>Size Specific Emission Factors</u>			
kg particulate <15 μ m d ₅₀ /Mg produced		375	15
lb particulate <15 μ m d ₅₀ /ton produced		750	30
kg particulate <2.5 μ m d ₅₀ /Mg produced		305	9
lb particulate <2.5 μ m d ₅₀ /ton produced		610	18

OVERALL EMISSION RATE = 872 $\frac{\text{lbs. PARTICULATE}}{\text{ton SILICON METAL}}$




Figure 1. Average particle size distribution, uncontrolled silicon metal furnace emissions (baghouse inlet), Alamet, Selma, Alabama.

OVERALL EMISSION RATE = 33 $\frac{\text{lbs. PARTICULATE}}{\text{ton SILICON METAL}}$




Figure 2. Average particle size distribution, controlled silicon metal furnace emissions (baghouse outlet), Alamet, Selma, Alabama.

SECTION 3

PROCESS DESCRIPTION


The No. 2 furnace at Alamet, Selma, Alabama is a submerged electric arc furnace rated at 17 megawatts which produces 98+ percent silicon metal. A schematic of the furnace and pollution control system is provided in Figure 3. The furnace vessel has a top diameter of 32 feet and tapers to a diameter of 22 feet at the bottom. The furnace is 14 feet deep and slowly revolves around its vertical axis. Four 7 x 12 foot panels are installed 13 feet apart between the top perimeter of the furnace and the canopy hood to provide more draft across the surface of the furnace and to help direct smoke and fumes into the canopy hood. The canopy hood is fixed 5 feet above the rotating furnace and is connected by two 7 foot diameter offtakes to a 9 foot diameter main duct. Exhaust gases are drawn through the main duct and through a Western Precipitation multiclone by two 800 horsepower fans. The gas is then forced through a positive pressure baghouse and vented to the atmosphere via a louvered roof monitor.

The furnace is charged with raw materials manually as necessary to keep the mix at a constant level near the top of the vessel. The charge mixture is composed of: 50 percent quartzite, 38 percent hardwood chips, 8 percent No. 1 coal and 4 percent No. 2 coal and petroleum coke.

The wood chips are added to the mix to provide porosity. This is necessary to allow gases to escape evenly from the charge. When gases are trapped in the mix, they sometimes escape rapidly (erupt) causing what is known as a "blow." Blows occur near the electrodes because the mix descends more rapidly and loses porosity where the refining and melting occurs.

Stoking, the mechanical leveling of the charge, is performed frequently to prevent the occurrence of blows. During stoking, the mix is pushed from the perimeter of the vessel into mounds around the electrodes; the mix is also pushed down to break up the crust formed on the surface. Stoking is usually performed before and after charging.

The prebaked carbon electrodes, arranged in a delta formation, are normally kept about 40 inches above the hearth level or 6 feet into the charge. The smelting reaction occurs about 8 feet down into the charge. The temperature of the arc can approach 6000°F.



^aWater sprays are normally used but were not used during testing.

Figure 3. Process schematic--Alamet, Selma, Alabama.

Tapping occurs approximately once every 2 hours. This is accomplished by shooting the carbon-paste plug out of the taphole area with a special 8-gauge shotgun. If necessary, a long wooden pole is used to poke the plug out and to keep the molten metal flowing. Generally the tapping process lasts about 50 minutes. The molten metal flows into a transfer ladle for subsequent casting.

SECTION 4

SAMPLING AND ANALYSIS PROCEDURES

INTRODUCTION

Emissions generated during the silicon metal refining process are evacuated to a positive pressure baghouse. Prior to initiation of the field sampling program, facilities for traversing the horizontal duct were installed by Alamet with funds provided by EPA through Research Triangle Institute Contract No. 68-02-3152. Refer to the RTI report for details concerning the installed sampling facilities.

The baghouse inlet sampling location was approximately 25 feet above grade and sampling was performed from a platform mounted underneath the circular duct. The sampling points were located 0.9 diameters downstream and 0.7 diameter upstream of flow disturbances. Both flow disturbances were 45 degree bends in the duct. The baghouse outlet sampling ports were installed in each of the 12 baghouse compartments on the access doors. The ports were located about 5 feet above the bags.

PRESAMPLING PREPARATIONS

Glassware and Nalgene sample bottles utilized in this test program were cleaned with an Alconox solution, rinsed with tap water, distilled- deionized (DDI) water and finally rinsed with spectro grade acetone. The glassware was air-dried and capped with Parafilm. Filters were desiccated to constant tare weight (± 0.5 mg).

Pitot tube-thermocouple-probe assemblies used for preliminary velocity traverses were calibrated by the measurement procedure as specified in 40 CFR 60, Appendix A, Method 2. Sampling nozzles were calibrated with a dial vernier micrometer. Thermocouples were calibrated against a mercury in-glass ASTM thermometer in an ice bath, at ambient temperature and in a boiling water bath. All calibrations are given in Appendix A.

Impactors were prepared for sampling by cleaning with soap and water, then rinsing with DDI water and finally with acetone. Particle sizing dry gas meters and orifices were calibrated prior to sampling according to procedures outlined in APTD 0576.

CASCADE IMPACTOR SAMPLING

Reeve Angel type 934-AH glass fiber substrates were prepared for use in the cascade impactors. Each substrate was labeled and placed in a folded aluminum foil liner. Both foil and filter were placed in labeled petri dishes and desiccated for 24 hours. The top half of each foil liner was folded back during desiccation. Initial tare weights and all subsequent weights are a combination of foil and filter weights. A minimum of 6 hours was allowed between weighings. After reaching constant weight (± 0.5 mg) substrates were sealed in their petri dishes for transport to the field.

Sample train preparation and recovery took place in a clean environment inside the truck used to transport equipment. Once onsite, a preliminary velocity traverse was performed in order to:

1. Determine if cyclonic flow conditions exist and, if present, determine the gas flow angles.
2. Determine which sample points represent average flow and temperature for particle sizing measurements.
3. Properly size the nozzles and obtain the data necessary to perform isokinetic sampling.

Four sample points of average velocity near $0.7R$ (R = duct radius) were determined through use of the preliminary traverse data. The proper nozzle size and sample train flow rate was selected and single-point sampling was performed during each Level 2 test run. Only one of the four sample points was sampled per inlet test run. Total sampling time was designed to collect approximately 50 mg per impactor run through estimated grain loading values, and by visual inspection of the first run filters. Baghouse inlet test runs were performed with a cyclone precutter installed in front of the impactor to remove particles $15 \mu\text{m}$ diameter. No visible sample was recovered from the cyclone precutter during initial baghouse outlet test runs, therefore only straight nozzles were used for all subsequent outlet tests.

Prior to each sampling run the impactors were carefully loaded with tared substrates. The sample train consisting of the impactor, an unheated probe, vacuum hose, silica gel moisture trap and dry gas meter/orifice/pump assembly as shown in Figure 4, was assembled and leak checked. The impactor was then inserted into the gas stream at the appropriate sample point with the nozzle pointed away from the gas flow (inlet tests) and allowed to reach temperature equilibrium. After approximately 10 minutes, the sampling nozzle was then turned into the flow (inlet tests) and the sample flow was adjusted to the desired rate. Outlet tests were performed as above however the nozzles were perpendicular to the assumed direction of flow at all times. The flow was monitored and recorded by observing the pressure drop across a calibrated orifice and the total dry gas volume sampled was determined by a calibrated dry gas meter. The flow rate through the impactor was held constant (± 0.05 cfm) for the duration of each run.




Figure 4. Andersen sampling train.

Upon completion of each sample run, the probe/impactor assembly was removed from the duct and sample train shut off. The nozzle was immediately capped with foil. The probe was disconnected and the impactor transported to the sample recovery area. No leak checks were performed at the end of a run so as not to disturb the particle distribution.

Two types of preliminary sampling runs were performed. The first involved the use of "blank" impactors loaded with pretared substrates to determine anomalous weight gain due to gaseous specie absorption. The impactors were fitted with dual prefilters to prevent particulate matter from reaching the substrates. Blank inlet and outlet runs were 28 minutes and 210 minutes long respectively.

Preliminary loading runs were conducted to obtain a visual indication of particle loading rates. Impactors equipped with cyclone precutters were operated for the length of time calculated as necessary to sample 50 mg of particulate. Upon recovery, substrates were examined and sampling times adjusted according to the degree of loading observed. Preliminary outlet runs were conducted with a cyclone precutter in order to verify the assumption that no particles greater than 15 microns were present in the outlet stream. These preliminary loading runs were performed with unweighed substrates which were discarded upon visual inspection.

ANDERSEN IMPACTOR GRAVIMETRIC ANALYSIS

At the conclusion of each test run, each impactor was carefully disassembled and the nozzle, impactor expander section and cyclone precutter (if used) was washed with acetone into a sample container. Each impactor substrate was placed into its respective petri dish and any particulate adhering to both sides of the top jet plate, the crossbar, and the gasket was brushed onto the substrate. In all cases the substrates were carefully placed in preweighed aluminum foil liners to minimize loss of particulate during subsequent handling of the substrate.

Upon completion of the sample recovery procedures, the samples were labeled, sealed, then liquid levels marked, and the samples were carefully packed for shipment to the GCA/Technology Division laboratory for analysis. A chain of custody log book that outlines the recovery procedures and documents the history of the samples was kept. Each substrate and weighing jacket, upon return to the GCA laboratory, was placed in a desiccator and dried for at least 24 hours before being weighed. A minimum of 6 hours was allowed between each subsequent weighing until constant weight (± 0.5 mg) was achieved. After weighing, all samples were carefully stored in closed containers.

Sampling data reduction was performed by computer. A preliminary program was used to calculate inputs needed to further reduce the data after the weight gains on each impactor stage have been determined. Once the appropriate input parameters were checked they were keypunched and entered into the "Computer Based Cascade Impactor Data Reduction System" (EPA-600/7-78-042) as developed by SoRI. Example calculations used by the programmable calculator are provided in Appendix B.

PROCESS OBSERVATIONS

During critical periods of the field testing, a GCA process engineer was positioned inside the No. 2 Furnace control room. From this vantage point the process engineer performed the following duties:

- Notified the test crew by radio when to start and stop so as to test only during normal operating conditions.
- Document the origin and approximate magnitude of all emissions generated within the furnace shop. Emission magnitude was assessed for charging, stoking and tapping operations using a scale of light, moderate or heavy.

Other process data and information was given to GCA by Research Triangle Institute in the form of daily process data sheets and notes at the end of the test period.

Visible Emission Observations

The emissions escaping capture by the canopy hood system were observed in accordance with EPA Reference Method 9 in the Federal Register, 40 CFR, Part 60, Appendix A. The VE observer was certified by EPA to observe visible emissions within the previous 6 months by the certification technique specified in Method 9. The observer was positioned outside the furnace shop and observed emissions emanating from the furnace shop roof monitor.

SAMPLING AND ANALYSIS QUALITY ASSURANCE

GCA/Technology Division management is fully committed to an effective Quality Assurance/Quality Control program. The Quality Assurance Manager reports directly to the General Manager, thereby assuring the QA Manager the necessary authority and independence to find and correct any existing quality problems. The QA Manager is also chairman of the Division QA/QC Committee.

Each Technology Division department participates in the quality assurance program in the way most appropriate to divisional needs. Each department manager appoints at least one staff member to serve on the Division QA/QC Committee and report back to the department on QA/QC methods, procedures, requirements, and problems. In addition, the Analytical Laboratory, the Environmental Measurements Department, and the Instrumentation Department maintain department QC committees whose staff members implement and record internal QA activities. These committees are appointed by the department manager and report to him as well as to the QA Manager.

SECTION 5

TEST RESULTS

INTRODUCTION

The field sampling program was conducted during the week of 26 January 1981. The program objective, to develop emission factors for ferroalloy production, was met by completion of 6 total particulate (Level 2) runs and 13 cascade impactor runs at the inlet sampling location. Ten impactor runs were completed during five total particulate runs at the baghouse outlet locations. The shorter inlet impactor runs were operated at various times during the production cycle, however, the longer outlet test runs were operated for complete tap to tap cycles or more.

Major modifications to the baghouse outlet would have been required to facilitate a more accurate measurement of controlled emission rates. These modifications, which in themselves could alter the outlet emission factors, were considered too costly and since the ferroalloy industry in general uses this baghouse outlet design, EPA requested that testing be performed at this less than ideal sampling location. An industrywide comparison of outlet emission factors is still possible, by performing tests at similar sampling locations at different ferroalloy plants, however, the actual emission rates are still questionable. Each of the 12 baghouse compartments (15 feet by 30 feet) was sampled immediately (5 feet) above the top of the bags at a single sample point. The gas flow in each compartment was below detectable limits; less than 0.002 in. H₂O velocity pressure; therefore, isokinetic sampling was not performed. Each compartment was tested at least once. An emission factor based on the average of all outlet test results should be considered one complete test run and since very little confidence can be applied to the results of one test, this emission factor should only be considered an estimate.

Careful monitoring of the process insured that the test runs were conducted only during normal furnace operations. Emissions escaping capture were documented by the process engineer/visible emission observer. Detailed process data was obtained to allow possible correlations between source operations and measured emission factors.

The field samples and data were driven back to the GCA/Technology Division Laboratory for analysis. The following subsections describe the results of the sample and data analysis efforts.

TOTAL PARTICULATE RESULTS

The total particulate measurements were performed by Entropy Environmentalists and the sample analysis was performed by RTI. Tables 2 through 6 summarize the results of the total particulate measurements as provided by Dr. Wayne Westbrook of RTI. Tables 2 and 3 present sampling data and gas characteristics, Tables 4 and 5 the particulate emission rates, and Table 6 presents the baghouse total particulate removal efficiency.

PARTICLE SIZING RESULTS

Figures 1 and 2 are each curve fitted composite plots of mean cumulative percent mass concentration versus particle aerodynamic diameter as defined by the Task Group on Lung Dynamics.

Figure 1 is a composite of all 13 impactor runs performed on the inlet and Figure 2 is a composite of all 9 impactor runs completed on the baghouse outlet. Some of the impactor runs incorporated into Figures 1 and 2 had rather light substrate loading. To determine if light substrate loading (<10 mg total particulate) affected the shape of the particle size distribution curves, the data was analyzed using only those runs with greater than 10 mg of particulate in the impactor. This included 9 of 13 inlet runs and 4 of the 9 outlet runs. This treatment of the data produced no significant change in the particle size distribution curves.

Figure 5 is a plot of particle aerodynamic diameter versus the mean change in mass concentration ($dM/d \log D$) for both the inlet and outlet. The graph is a composite of all inlet and outlet runs. The values of $dM/d \log D$ for the outlet can be divided by the inlet value corresponding to the same particle size to determine the baghouse efficiency for removing particles of that specific size. Baghouse efficiency versus particle diameter is illustrated more clearly in Figure 6 and Table 7. The intervals marked on Figure 5 correspond to the minimum and maximum values of $dM/d \log D$.

To determine the particle size distributions presented herein, data from Entropy and GCA were combined. During each individual test run a cascade impactor data sheet was filled out. Time, impactor number, local barometric pressure, dry gas meter volume, inlet and outlet temperature, orifice pressure drop and dry gas meter static pressure were recorded at specific intervals during the run. Stack gas temperature, gas static pressure, velocity pressure and gas fraction analysis data were obtained from Entropy Environmentalists, who operated a Method 5 type sampling train concurrent with the impactor sampling.

A computer based cascade impactor data reduction system, (CIDRS) developed by Southern Research Institute for the EPA, (EPA 600/7-78-042) was initially used to analyze the field data. This reference contains a thorough discussion of the design and use of the above mentioned system. The system calculates and prints for each impactor run: the D-50 cutpoint of each stage, the cumulative percent mass less than D-50, the cumulative mass concentration

TABLE 2. BAGHOUSE INLET SAMPLING DATA, ALAMET, SELMA, ALABAMA

Run No.	1	2	3	4	5	6
Date	1/26/81	1/27/81	1/27/81	1/28/81	1/28/81	1/28/81
Start time	1335	0913	1400	0830	1120	1400
Stop time	1525	1201	1545	1017	1322	1600
Net sampling time, min	96	96	96	96	96	96
Stack Temp., °C	161	153	158	149	153	158
Stack flow rate dsm ³ /min ^a	7272.9	7747.9	7478.2	7650.9	7712.1	7823.9
Stack flow rate Am ³ /min ^b	11,151.6	11,563.9	11,409.1	11,256.6	11,560.7	11,753.2
Volume collected dsm ³	0.7888	1.7917	0.8153	0.8389	0.8637	0.8585
% Isokinetic	99.7	98.4	100.2	100.8	103.0	100.9

^aMoisture free and at 20°C and 76.0 cm Hg

^bActual flow rate at stack conditions

TABLE 3. BAGHOUSE OUTLET SAMPLING DATA, ALAMET, SELMA, ALABAMA

Run No.	1	2	3	4	5
Date	1/26/81	1/27/81	1/27/81	1/28/81	1/28/81
Start time	1330	0935	1358	0826	1240
Stop time	1627	1236	1659	1139	1531
Net sampling time, min	160	160	160	160	160
Stack temp., °C	119	120	108	98	113
Volume collected dsm ^{3a}	1.0173	1.2544	3.2559	3.3476	3.2185
Gas flow rate ^b dsm ³ /min	10,670	11,380	10,980	11,230	11,400
Compartments samples	4,5,11,12	2,3,9,10	1,6,7,8	1,2,7,8	4,5,11,12

^aMoisture free and at 20°C and 76.0 cm Hg

^bEstimate based on inlet flow rate, ambient temperature, inlet gas temperature, and outlet gas temperature.

TABLE 4. TOTAL PARTICULATE TEST RESULTS (BY RTI) BAGHOUSE INLET SAMPLING LOCATION,
ALAMET, SELMA, ALABAMA

Run No.	Particulate captured (mg)	Particulate concentration (mg/dsm ³)	Particulate generated per hour (kg/hr)	Particulate generated per MW-h (kg/MW-h)	Particulate generated per Mg feed (kg/Mg)	Particulate generated per Mg alloy (kg/Mg)
1	553.2	701.3	306.0	18.27	52.2	247
2	2267.0	1265.3	588.2	35.28	84.9	463
3	1460.6	1791.5	803.8	46.01	106.2	604
4	672.5	801.6	368.0	20.70	50.2	282
5	725.6	840.1	388.7	22.59	53.0	308
6	1734.0	2019.8	948.2	52.47	118.2	715
Average all runs		1236.6	567.2	32.55	77.5	436

TABLE 5. TOTAL PARTICULATE TEST RESULTS (BY RTI) BAGHOUSE OUTLET SAMPLING LOCATION,
ALAMET, SELMA, ALABAMA

Run No.	Particulate captured (mg)	Particulate concentration (mg/dsm ³)	Particulate generated per hour (kg/hr)	Particulate generated per MW-h (kg/MW-h)	Particulate generated per Mg feed (kg/Mg)	Particulate generated per Mg alloy (kg/Mg)
1	5.3	5.2	3.3	0.18	0.49	2.5
2	16.3	13.0	8.9	0.53	1.28	7.0
3	25.5	7.8	5.1	0.29	0.64	3.8
4	252.6	75.5	50.9	2.92	6.94	39.8
5	177.7	55.2	37.2	2.17	4.99	29.6
Average all runs		31.3	21.2	1.22	2.87	16.5

TABLE 6. BAGHOUSE TOTAL PARTICULATE REMOVAL
EFFICIENCIES ALAMET, SELMA, ALABAMA

Outlet Run No.	Inlet Run No. used in calculation	Baghouse particulate capture efficiency ^a
1	1	98.9
2	2	98.5
3	3	99.4
4	4	86.2
5	5,6 ^b	94.3
Average all runs		96.3

^aCalculated using kg generated and kg emitted per hour. Comparisons based on particulate concentration in the gases will overstate baghouse efficiency because of additional air drawn into baghouse through the cooling air grates.

^bA simple average of the particulate generated in runs 5 and 6 was used. Outlet Run No. 5 overlapped both inlet runs 5 and 6.




Figure 5. Average change in concentration per particle size (all runs), Alamet, Selma, Alabama.




Figure 6. Baghouse efficiency per particle size, Alamet, Selma, Alabama.

TABLE 7. BAGHOUSE SIZE SPECIFIC PARTICULATE REMOVAL
EFFICIENCIES ALAMET, SELMA, ALABAMA

Particle aerodynamic diameter (microns)	Inlet dM/dLOG D (mg/DNCM)	Outlet dM/dLOG D (mg/DNCM)	Percent removal (%)
30	1990	6.1	99.69
20	1280	5.8	99.55
15	476	3.9	99.18
10	280	3.2	98.86
5	160	3.4	97.87
2.5	205	3.1	98.49
1.25	541	3.7	99.32
1.0	1160	5.5	99.53

less than D-50, the geometric mean diameter of particles caught by each stage, the change in particle mass concentration with respect to log of particle size ($dM/d \log D$), and the change in particle number concentration with respect to log of particle size ($dN/d \log D$). The system combines the results from all individual runs made on either the inlet or outlet; screens for and removes outlying data; fits the data to a composite curve, and calculates 90 percent confidence intervals. It is the output of this curve fitting program that was used to develop the draft version of this report. Upon review by EPA, the CIDRS program was found to be deficient in the treatment of the cyclone preseparator data associated with each inlet impactor run. EPA contracted Research Triangle Institute to develop an interactive computer program using CIDRS with modifications to more accurately treat the particulate catch resulting from the use of precutters.

The Particulate Data Reduction System (PADRE) prompts a user for input in an interactive mode and checks the inputted value. In CIDRS, the cyclone preseparator particulate catch was added to the first stage substrate weight gain. In PADRE, the lower cutpoint of the preseparator is associated with the particulate catch. Another major difference between the programs is that CIDRS screens for and eliminates outliers from the calculation of average results whereas PADRE only flags outlying data points (See Appendix D-1).

PADRE requires the user to make an assumption regarding the validity of the back-up filter weight gain. Some think that particles that should have impacted on previous substrates actually travel or are reentrained such that they end up on the back-up filter. On the other hand, fine particles may not reach the back-up filter due to diffusional, electrostatic, or other forces causing premature particulate removal. For this report, it was assumed that 50 percent of the weight gain of the back-up filter is attributable to particles less than the d_{50} of the last impactor stage. The computer printouts from the PADRE system are contained in Appendix D-1 and D-2 and the field data sheets are presented in Appendix E-1.

Table 8 summarizes isokinetic sampling rates, actual flow rate through the impactor, volumes metered at standard conditions and duration for each individual Andersen run. The inlet isokinetics ranged between 74 percent and 113 percent, the average for all runs was 97 percent. Due to the large cross-sectional area of the baghouse compartment where outlet sampling occurred, no flow could be detected by the s-type pitot tube equipped with a 0 to 0.25 in. H_2O inclined micromanometer. No attempt was made to sample isokinetically at this extremely low flow rate, and the impactor nozzles were oriented perpendicular to the assumed direction of flow for convenience when inserting and removing the impactor/probe assembly within the limited space of the outlet sampling location.

The lack of a significant flow rate and resultant superisokinetic sampling rates makes the outlet particle size distribution curve (Figure 2) and the control device efficiency plots (Figures 5 and 6) less viable than the inlet size distribution curve (Figure 1) where isokinetic sampling conditions were maintained.

TABLE 8. IMPACTOR SAMPLING DATA SUMMARY, BAGHOUSE INLET, ALAMET, SELMA, ALABAMA

Inlet Run No.	Velocity pressure (in. H ₂ O)	Gas temperature (°R)	Gas pressure (in. Hg)	Test duration (min)	Gas velocity (ft/min)	Volume metered (std ft ³)	Impactor flow rate (acfm)	Area of nozzle (ft ²)	Nozzle velocity (ft/min)	Isokinetic (%)
11A16	2.09	782	29.63	2.0	5960	0.75	0.580	1.01 x 10 ⁻⁴	5742	96
11B16	2.09	782	29.63	2.0	5960	0.72	0.557	1.01 x 10 ⁻⁴	5510	93
21A90	2.29	768	29.53	3.25	6200	1.09	0.505	7.21 x 10 ⁻⁵	7000	113
21B90	2.29	768	29.53	3.0	6200	0.97	0.489	7.21 x 10 ⁻⁵	6780	109
31A16	2.19	777	29.54	1.5	6090	0.32	0.324	7.21 x 10 ⁻⁵	4490	74
31B16	2.19	777	29.54	1.5	6090	0.43	0.437	7.21 x 10 ⁻⁵	6060	100
41A90	2.20	760	29.63	1.5	6030	0.33 ^a	0.405	7.21 x 10 ⁻⁵	5620	93
41B90	2.20	760	29.63	1.6	6030	0.48	0.443	7.21 x 10 ⁻⁵	6140	102
51A16	2.20	767	29.63	1.5	6060	0.43	0.435	7.21 x 10 ⁻⁵	6030	100
51B16	2.29	767	29.63	1.5	6180	0.42	0.428	7.21 x 10 ⁻⁵	5940	96
51B90-2	2.29	767	29.63	1.5	6180	0.44	0.445	7.21 x 10 ⁻⁵	6170	100
61A16	2.35	777	29.62	1.0	6300	0.29	0.435	7.21 x 10 ⁻⁵	6030	96
61B16	2.35	777	29.62	1.5	6300	0.40	0.405	7.21 x 10 ⁻⁵	5617	89

^aCorrection made for lack of final DGM reading.

SIZE-SPECIFIC PARTICULATE EMISSION FACTORS

Emission factors were calculated by applying the size distribution test results to the total particulate data results from the Level 2 testing. It was not possible to accurately measure flow inside the baghouse, therefore, the outlet gas flow rate is based strictly on calculations by RTI. Volumetric flow rate at the outlet of the baghouse was adjusted to by RTI include dilution air by consideration of the drop in stack gas temperature. The fume and emission factors presented in Table 9 based on tons produced were calculated by dividing the hourly emission factors by the average production rate recorded by GCA and RTI during the test period.

VISIBLE EMISSIONS DATA

All visible emissions observations were made in accordance with EPA Method 9. The field data sheets are provided in Appendix E-2. Visible emissions were recorded during the 3 days of the test program. The furnace shop roof monitor was observed for 3 hours, the baghouse outlet for 2 hours. A summary of the visible emissions data obtained is presented below.

On 26 January visible emissions from the casthouse were recorded for 124 minutes. During this time, which covered a complete tap to tap cycle, a total of four observations, or 1 minute of readings, were greater than 0 percent opacity. Operation of the floor fan was documented throughout the tap and emissions were observed blowing out the side of the building.

Visible emissions from the baghouse roof monitor were recorded on 27 January for 131 minutes. A total of 2.25 minutes of 5 percent opacity were observed, approximately 18 minutes of observations were interfered with by fugitive emissions from the raw materials handling station, and the rest of the observations were 0 percent opacity.

On 28 January, visible emissions were recorded again for the furnace shop roof monitor. A total of 55.5 minutes or 222 observations were recorded during the tapping cycle. Of these, 180 observations were between 0 to 25 percent opacity, 14 were between 30 to 50 percent opacity, 8 were between 55 to 75 percent opacity, and 20 were between 80 to 100 percent opacity. The floor fan was turned on about 20 minutes into the tap which corresponded to lower visible emissions observations since all of the readings greater than 50 percent occurred before the fan was turned on.

At no time during the testing period were visible emissions greater than 5 percent opacity observed originating from the baghouse compartments being tested. Capture efficiency of the canopy hood throughout the study, for all operations other than tapping, was close to 100 percent. Visible emissions originating from the furnace building could be attributed to mainly the tapping operation which occurs for about 50 minutes out of every 2 hours.

TABLE 9. SIZE SPECIFIC EMISSION FACTORS, ALAMET, SELMA, ALABAMA

Sampling location	Parameter	Particle aerodynamic diameter (d ₅₀ in μ m)					
		∞^a	15	10	5	2.5	1
Baghouse inlet	Cumulative % mass <d ₅₀	100	86	81	74	70	57
	Cumulative lb <d ₅₀ /hr	1250	1075	1012	925	875	712
	Cumulative lb <d ₅₀ /ton silicon metal	872	750	706	645	610	497
Baghouse outlet	Cumulative % mass <d ₅₀	100	92	84	68	56	38
	Cumulative lb <d ₅₀ /hr	43.4	39.9	36.5	29.5	24.3	16.5
	Cumulative lb <d ₅₀ /ton silicon metal	33.0	30.4	27.7	22.4	18.5	12.54

^aBased on EPA Methods 1-5 "front half" test results.

FURNACE OPERATIONS DATA

A process observer recorded furnace operations and cycle times, as well as fluctuations in furnace fume generation. Capture efficiency of the canopy hood and tapping hood was also assessed. Tapping, stoking, charging, and blows, all cause heavier emissions than just the smelting process. During several taps the fumes escaping the tapping hood limited visibility in the furnace shop to less than 20 feet. Fumes generated by stoking were usually completely captured by the canopy hood. Occasionally the mix would spill out of the furnace and burn on the floor. Charging fumes varied in magnitude. Many times there was no noticeable increase in fume generation. Blows, (characterized by an intense white flare), resulted in a short burst of heavier fumes and more flames than normal.

The furnace was operating smoothly on 26 January 1981. On 27 and 28 January, the furnace was running rougher, however source personnel considered this operation still normal. Heavier tapping emissions were observed during this time also. Throughout the test period canopy hood capture of fumes was close to 100 percent, except on rare occasions when a heavy surge of fumes would escape the hood.

Capture efficiency of the tapping hood was estimated at about 60 percent. Sometimes a portable floor fan brought near the tap hole would be used to force emissions out the side of the building instead of letting them rise to the top of the furnace shop. The plant engineer informed the GCA process observer that the fan was primarily used to increase visibility in the taphole area. The operation of this floor fan had a direct effect on visible emissions observations as presented in the preceeding section.

On 26 January, Furnace No. 2 underwent electrode sounding from 11:30 a.m. to 12:00 p.m., in order to get an accurate measurement of the electrode lengths. This is accomplished by allowing the mix level to drop below the top of the furnace by not adding raw materials to the vessel. The electrode holders are then lifted so that the tips of the electrodes can be observed. After sounding the electrodes are lowered to their normal position and raw materials are added. Testing was not begun until after the furnace stabilized for about 2 hours.

Table 10 relates observed furnace emissions to the test runs on 28 January. The process observation data sheets notes appear in Appendix E-3 and E-4. During the test program, furnace power consumption as recorded on a chart in the control room was generally between 17 and 19.5 MW. Actual power consumption and kWh/ton is presented in Table 11. The average actual load on the furnace during the 3-day test period was 16.9 MW. Table 12 presents the daily charge composition for the 3-day test period and Table 13 presents the alloy analysis, tap weight, and tap temperature during the test period.

The product weight rate averaged about 33 ton/day with an average tap temperature of 2760°F.

TABLE 10. CORRELATION OF TEST RUNS TO FURNACE OPERATIONS AT
FURNACE NO. 2, ALEMET, SELMA, ALABAMA

Date	Time	Impactor Run No.	Impactor particulate loading (mg/dscm)	Furnace operation
1/28/81	08:46	4IA90	729	Charging and tapping very heavy emissions
1/28/81	10:00	4IB90	1778	Charging--normal emissions
1/28/81	11:33	5IB16	960	Smelting--normal emissions
1/28/81	12:14	5IB90-2	1161	Smelting--normal emissions plus very light emissions from start of tapping
1/28/81	13:19	5IA16	1220	Charging--slightly heavier than normal
1/28/81	14:28	6IA16	3327	Tapping--heavy emissions
1/28/81	16:02	6IB16	1610	Smelting--normal emissions

TABLE 11. POWER CONSUMPTION OF FURNACE NO. 2 AT ALAMET

Date	Daily power consumption MWH ^a	Actual load MWH/hr ^b	Tons of product ^c	MWH/ton ^c
1/26/81	400	16.8	32.6	12.3
1/27/81	400	16.7	33.6	11.9
1/28/81	410	17.1	33.2	12.4
Average	403	16.9	33.1	12.2

^aMWH = megawatt hours.

^bActual load is the daily power consumption divided by the number of hours the furnace was in operation.

^cBased on actual production data.

TABLE 12. CHARGE COMPOSITION, NO. 2 FURNACE, ALAMET, SELMA, ALABAMA

Date	Charge materials										Total raw materials lbs
	Gravel (Quartzite)		Wood chips		No. 1 coal		No. 2 coal		Petroleum coke		
	lbs	% comp	lbs	% comp	lbs	% comp	lbs	% comp	lbs	% comp	
1/26/81	165,500	45.8	136,200	37.7	27,730	7.7	15,095	4.2	16,400	4.5	360,925
1/27/81	183,000	46.4	146,900	37.2	30,030	7.6	16,380	4.1	18,200	4.6	394,510
1/28/81	196,000	46.3	156,800	37.0	32,900	7.8	18,210	4.3	19,610	4.6	423,520
Average	181,500	46.2	146,633	37.3	30,223	7.7	16,558	4.2	18,067	4.6	392,985

TABLE 13. PRODUCTION AND METAL ANALYSIS DATA FOR FURNACE NO. 2 AT ALAMET, SELMA, ALABAMA

Date	Tap weight (lbs) ^a	Tap weight (tons) ^a	After O ₂ refining				Temp °F
			% Si	% Fe	% Ca	% Al	
1/26/81	65,246	32.6	98.92	0.44	0.11	0.28	2757°
1/27/81	67,203	33.6	98.84	0.45	0.15	0.31	2760°
1/28/81	66,351	33.2	98.76	0.53	0.14	0.32	2763°
Average	66,267	33.1	98.84	0.47	0.13	0.30	2760°

^aData based on actual production, not on saleable product.

TABLE 14. DAILY AVERAGE OF BAGHOUSE PRESSURE, TEMPERATURE AND FAN AMPS, ALAMET, SELMA, ALABAMA

Date	Overall P (in. H ₂ O)	Temperature (°F)	Fan No. 1 (amps)	Fan No. 2 (amps)
1/26/81	4.3	297	179	184
1/27/81	5.5	274	185	186
1/28/81	6.1	282	182	187
Average	5.3	283	182	186

Baghouse Observations

Individual compartment pressures, overall pressure, temperature range and fan currents, were recorded in the field and are presented in Appendix E-3. Table 14 summarizes the data as follows.

On 26 January, the baghouse inlet pressure was 4.3 in. H₂O, which is less than the design pressure of 5 in. H₂O. This could be related to the electrode sounding and to the smoother operation of the furnace that day. Gas temperature to the baghouse inlet averaged 297°F which was the highest temperature observed during the test program. The average gas temperature at the baghouse on 27 January, 274°F was the lowest value, with an overall ΔP of 5.5 in. H₂O, just over design pressure. On 28 January, the average ΔP was 6.1 in. H₂O while the average temperature was 282°F.

Individual baghouse compartment pressures ranged from 0.0 during cleaning to about 6.5 in. H₂O. The cleaning cycle, actuated by a timer device, takes each compartment off line for 40 seconds every hour. Fan current did not vary much throughout the study, although the Fan No. 2 indicator read slightly higher than Fan No. 1.

On 28 January, several fabric filters broke in three baghouse compartments; Numbers 6, 8 and 9. These compartments were not being tested at this time so the sampling program continued without interruption. The compartments were isolated one at a time and repairs were completed within 2 hours.

The source provided design parameters for the baghouse and these data are presented in Table 15.

TABLE 15. BAGHOUSE CONTROL SYSTEM DESIGN PARAMETERS, ALAMET, SELMA, ALABAMA

BAGHOUSE

- a. Manufacturer--Wheelabrator-Frye
- b. Type or trade name--Continuous Automatic Type
- c. Model No. 264, Series 8SR, Size No. 1227D
- d. No. of compartments--12
- e. Bags/compartment--324
- f. Bag dimensions--264 in. x 8 in.
- g. Total cloth area--178,860 ft²

FAN

- a. Manufacturer--U.S. Motors
- b. Model No. 2, Clarage No. 21, RT Exhausters
- c. Blade type--
- d. Belt or direct drive--belt
- e. Power rating--800 Hp each
- f. Positive or negative pressure--Positive

FABRIC

- a. Manufacturer--W.W. Criswell, Division of Wheelabrator-Frye
- b. Material--Nomex "DUSTUBES"
- c. Woven or felted--Woven
- d. Weave--3:1 twill
- e. Weight--
- f. Permeability--
- g. Operating temp. range--Max. 425°F
- h. Surface treatment--None
- i. Coating upon startup--Lime
- j. Guaranteed life--None
- k. Actual life--Approximately 18 months

CLEANING SYSTEM

- a. Method--Shaker
- b. Frequency--40 sec/hr/compartment
- c. Actuated by--Timer
- d. Anticollapse rings--None
- e. Wire mesh cages--None

OPERATING PARAMETERS

- a. Design volume flow rate--300,000 cfm
 - b. Design temperature--500°F
-

(continued)

TABLE 15 (continued)

-
- c. Gross mass design efficiency--99.7 percent
 - d. Design inlet grain loading--1.58 gr/dscfm
 - e. Total power consumption--1.5 Kwh x 1000
 - f. Design air/cloth ratio--1.83 ft³/ft² min
 - g. Design pressure (absolute)--20 in. W.C.
 - h. Design P (in. W.C.)--5 in. H₂O

MULTICLONE INFORMATION

- a. Manufacturer--Western Precipitator
 - b. Model--12 VM 35, Size 198-11, "Multiclone" Collector with Spirocones"
 - c. Purpose--Spark trap
-

APPENDIX A
SAMPLE TRAIN CALIBRATIONS

Digimike Calibration

T. E. SKM

1/12/31

	Terminal #	Hg (OF)	Digimike (F)	Hg	Digi	Hg	Digi
Long Probe	1	32.0	24	62.0	64	164.0	158
	2	"	23	"	63	"	154
	3	"	24	"	64	"	157
	4	"	25	"	65	"	158
	5	"	26	"	65	"	163
	6	"	26	"	65	"	160

Short Probe	1	32.0	27	64.0	69	169.0	161
	2	"	"	"	69	"	162
	3	"	"	"	70	"	162
	4	"	"	"	70	"	161
	5	"	"	"	71	"	161
	6	"	"	"	70	"	161

PRECUTTER Cyclone nozzels

1/9/81

Joe Vay

<u>ID</u>	<u>inches</u>
3.0 A	0.114
3.5 A	0.136
4.0 A	0.156
4.5 A	0.176
5.0 A	0.195
6.0 A	0.235
7.0 A	0.276
8.5 A	0.335
10.0 A	0.394
12.0 A	0.468
14.5 A	0.565

<u>ID</u>	<u>inches</u>
3.0 B	0.116
3.5 B	0.136
4.0 B	0.157
4.5 B	0.176
5.0 B	0.196
6.0 B	0.236
7.0 B	0.275
8.5 B	0.336
10.0 B	0.394
12.0 B	0.471
14.5 B	0.564

Cyclone nozzels

1/9/81

Joe Vay

<u>ID</u>	<u>inches</u>
3.0 A	0.114
3.5 A	0.136
4.0 A	0.156
4.5 A	<u>0.176</u>
6.0 A	0.235
7.0 A	0.276
8.5 A	0.335
10.0 A	0.394
12.0 A	0.468
14.5 A	0.565
5.0 A	0.195
3.0 B	0.11 6
3.5 B	0.136
4.0 B	0.157
4.5 B	0.176
5.0 B	0.197
6.0 B	0.236
7.0 B	0.275
8.5 B	0.336
10.0 B	0.394
12.0 B	0.471
14.5 B	0.564

Box - ORANGE
measured 1/7/80
inches

Joe Va.

oks	3A	
	3B	0.112 0.288
	3C	0.252
	3D	0.309
	3E	
	3F	0.496
s. rights	3G	0.130
	3H	0.187
	3I	0.250
	3J	0.313
	3K	0.374
	3L	0.501

Box 14
measured

1/7/81

Joe Vay

		<u>Inches</u>	
nooks	2 A	0.127	
	2 B	0.182	damaged
	2 C	0.250	
	2 D	0.309	
	2 E	0.372	
	2 F	0.497	
straights	2 G	0.126	
	2 H		damaged
	2 I	0.250	
	2 J	0.377	0.312
	2 K	0.374	
	2 L	0.503	

Box South
Measured

1/7/82

Joe Vay

hooks	1 A	0.127
	1 B	0.188
	1 C	0.252
	1 D	0.
	1 E	0.372
	1 F	0.496
Straights	1 G	0.127
	1 H	0.251
	1 I	0.251
	1 J	0.312
	1 K	0.375
	1 L	0.498

COCA TECHNOLOGY DIVISION

1618018

Selma / Alameda

SHEET 7 OF 8

BY 7/8/81

DATE 1/16/81

CHK BY

DATE CHK

BK CHK BY

11/16/81

V₁

0.40

V₁ = ~~5.00~~ 4.00

V₁ = ~~5.055~~ 4.055

T₁ = 63.7

T₂ = 68.5

ψ = 10.87

P₁ = 30.00

	V ₁	V ₂
0	187.635	66.56770
2	188.575	66.56770
4	189.120	67 70
6	189.870	67 70
8	190.618	67 70
10	191.315	67 70
12	191.690	67 70
14		
16		
18		
20		
22		
24		
26		
28		
30		
32		
34		
36		

Y = ~~0.997~~ 0.995

ΔH₁ = ~~1.937~~ 1.620

Q₁ = ~~0.465~~ 0.373

C₁ = ~~0.243~~ 0.243

Static = 0.05" H₂O

QUALITY TECHNOLOGY DIVISION

1618018

SHEET _____ OF _____

BY TR/Skm

DATE 1/16/81

CHK BY _____

DATE CHK. _____

BK. CHK BY _____

Meter # V₁

$\Delta H = 2.0$

$V_{in} = 1000$ 11.00

$V_0 = 11.123$

$T = 63.5$

$T = 68.5$

$Y = 12.50$

$V_{in} = 30.00$

time	V_0	T_0	T
0	194.870	67	70
2	196.500	67	70
4	198.140	67	70
6	199.770	67	70
8	201.422	67	70
10	203.058	67	70
12	204.692	67	70
14	205.993	67	70
16			
18			
20			
22			
24			
26			
28			
30			
32			
34			
36			

$Y = 0.994$

$\Delta H_a = 1.415$

$Q_u = 0.890$

$C_p = 1.217$

1618014

BY: T. S. S. S.
 DATE: 11/15/81
 CH'K. BY: [Signature]
 DATE CH'K.: 11/15/81
 B'K. CH'K. BY: _____

High Gas Meter Calibration

Meter # 2800017

$\Delta H = 0.40$

$V_w = 5.10$

$V_g = 5.168$

$T_w = 63.0$

$T_g = 61.0$

$\phi = 10.78$

$P_o = 30.07$

Time	V_o	V_w	V_g
0	559.580	62	60
2	340.535	62	60
4	841.490	62	60
6	842.460	62	60
8	843.410	62	60
10	844.370	62	60
12	844.748	62	60
14			
16			
18			
20			
22			
24			
26			
28			
30			
32			
34			
36			

$\gamma = 0.982$

$\Delta H_s = 0.989$

$Q_n = 0.479$

$C_r = 0.239$

V₂

1494 check $\checkmark$ - 0
 static - 0.08 "Hg

SHIPP
 BY T Rpsky
 DATE 1/15/81
 CH'K BY
 DATE CH'K
 B'K. CH'K. BY

1
 Summary: Dry run Meter Calibration

4
 Meter # 2800017

$\Delta H = 0.20$

$V_w = 5.00$

$V_a = 5.003$

$T_w = 63.0$

$T_a = 61.33$

$\gamma = 14.66$

$P_b = 30.08$

Time	V_0	T_b	T_a
0	849.861	60	62.5
2	850.548	60	62.5
4	851.235	60	62.5
6	851.930	60	62.5
8	852.625	60	62.5
10	853.0	60	62.5
12	854.015	60	63.0
14	854.700	60	63.0
16	854.924	60	63.0
18			62.67
20			
22			
24			
26			
28			
30			
32			
34			
36			

$\gamma = 0.984$

$\Delta H_a = 0.951$

$Q_a = 0.345$

$C_c = 0.120$

leak check ✓ - 0

static - 0.05 " Hg

V_2

SHIPPED BY _____
 DATE _____
 CH'K BY _____
 DATE CH'K _____
 EX. CH'K BY _____

NAME _____
 LOCATION _____
 DATE _____
 TIME _____
 OPERATOR _____
 SAMPLE NO. _____
 VOLUME _____
 TEMPERATURE _____
 PRESSURE _____
 WIND _____
 HAZARD _____
 COMMENTS _____

M-100 # V3

3
 5.0
 $V_d = 5.120$
 $T_w = 63.5$
 $T_d = 65.0$
 $\psi = 12.34$
 $p_v = 30.03$

Time	V_d	T_d	T_w
0	371.632	65	65
2	372.46	65	65
4	373.29	65	65
6	374.12	65	65
8	374.95	65	65
10	375.00	65	65
12	376.61	65	65
14	376.752		
16			
18			
20			
22			
24			
26			
28			
30			
32			
34			
36			

$\gamma = .979$
 $\Delta H_v = 1.007$
 $Q_{0.1} = .415$
 $C_2 = .181$

COCA/TECHNOLOGY DIVISION

COMMONWEALTH OF MASSACHUSETTS DEPARTMENT OF HEALTH SERVICES

SHEET _____ OF _____

DATE _____

DATE _____

DATE BY _____

DATE BY _____

DATE BY _____

DATE _____

PROJECT _____

SUBJECT _____

Dry Gas Meter Calibration

Meter # V3

$\Delta H = .4$

$V_{in} = 5.0$

$V_b = 5.063$

$T_w = 63.5$

$T_a = 65$

$\phi = 10.66$

$P_b = 30.03$

Time	V_b	T_w	T_a
0	365.550	66	65
2	366.46	65	65
4	367.42	65	65
6	368.38	65	65
8	369.33	65	65
10	370.29	65	65
12	370.63		
14			
16			
18			
20			
22			
24			
26			
28			
30			
32			
34			
36			

$\gamma = .989$

$\Delta H_a = 1.002$

$Q_a = .475$

$C_c = .242$

DATE

BY

DATE

Alameda
 by the Metro Calibration

BY

DATE

CH'K. BY

DATE CH'K.

B'K. CH'K. BY

$V_{w1} = 3.0$

Meter # 1517948

$\Delta H = 2.0$

$V_{w1} = 10.01$

$V_{w2} = 10.37$

$T_w = 63.8 / 63.5$

$T_a = 64.17$

$\phi = 9.64 \text{ mm}$

$P_b = 30.02''$

Time	V_0	T_w	T_a
0	354.101	65	64
2	355.264	65	64
4	358.402	65	63
6	360.500	65	63
8	362.720	65	63
10	364.473	65	63
12		65	63.33
14			
16			
18			
20			
22			
24			
26			
28			
30			
32			
34			
36			

$y = 0.962$

$\Delta H_a = 1.024$

$Q_a = 1.076$

$C_a = 1.206$

364.473
 354.101
 10.37

1 618 018
Alameda

NO. 1324018
DATE 1/15/81
CHK BY
DATE CHK
BY CHK BY

28000.4

$\Delta H = 0.4$

$V_m = 5.0 \checkmark$

$V_0 = 5.129$

$T_m = 63.85$

$T_0 = 68.79$

$\phi = 10.59 \text{ min}$

$V_1 = 30.07$

	V_0		
0	305.821	69	67
2	306.298	69	68
4	307.278	69	68
6	308.228	69	69
8	309.187	69	69
10	310.155	69	69
12	310.430	69	70
14			
16			
18			
20			
22			
24			
26			
28			
30			
32			
34			
36			

$\gamma = 0.983$

$\Delta H_a = 0.982$

$Q_a = 0.484$

$C_c = 0.243$

static = 0.04 " H₂

Leak check = 0.001 cfm/min

1618018

SHEET 1 OF 1

BY T. S. K. M.

DATE 1/15/81

CHK BY

DATE CHK.

BK CHK BY

Top of Meter Calibration

Meter # 2800014

$\Delta H = 2.0$

$V_0 = 10.0$ 11.02

$V_0 = 11.445$

$T_0 = 63.7$

$T_0 = 70$

$\phi = 10.38$

$P_0 = 30.07$

Time	V_0	T_0
0	312.535	70
2	314.725	70
4	316.930	70
6	319.125	70
8	321.325	70
10	323.980	70
12		
14		
16		
18		
20		
22		
24		
26		
28		
30		
32		
34		
36		

V₄

$\gamma = 0.970$

$\Delta H_1 = 0.968$

$Q_0 = 1.103$

$C_2 = 1.218$

static 0.2 " H₂

APPENDIX B

PARTICLE SIZE DATA REDUCTION EXAMPLE CALCULATIONS

The field sampling and laboratory analysis data is reduced by programmable calculation to provide the following input to the SORI data reduction system:

1. Impactor identification (required to call up hardware information)
2. Fractional gas composition (CO_2 , CO , N_2 , O_2 , H_2O)
3. Impactor flow rate (ACFM at stack conditions)
4. Stack pressure (inches of mercury)
5. Stack temperature (degrees Fahrenheit)
6. Gas temperature within impactor (degrees Fahrenheit)
7. Duration of sampling (minutes)
8. True density of particles (grams per cubic centimeter)
9. Maximum particle diameter present in sample (micrometers)
10. Masses of catches by stage (milligrams)

The following field data are also entered into the calculator to obtain the above input data:

- Barometric pressure (inches of mercury)
- Molecular weight of gas stream at meter (lb/lb-mole)
- Average static pressure at meter (inches of mercury)
- Average temperature at meter ($^{\circ}\text{F}$)
- Water collected in condenser and silica gel (grams)

- Gas volume at meter (ft³)
- Average stack static pressure, (inches of water)
- Average stack temperature (°F)
- Particulate mass collected in probe and expander section prior to top stage (grams)
- Particulate mass collected on each impactor stage (grams)
- Particulate mass on backup filter (grams)

The following calculations are performed by the calculator as a preliminary data check, however the results reported in the Appendix are the computer printouts detailing the calculations performed by the Data Reduction System developed by SoRI (EPA-600/7-78-042).

a. Total Mass Collected:

$$M_T = M_p + \sum_{L=t}^b M_s + M_f$$

where: M_T = total mass collected (grams)

M_p = mass collected in probe and impactor prior to top impactor stage (grams)

M_s = mass collected on impactor stage (grams)

$L=t$ = corresponds to the top impactor stage

$L=b$ = corresponds to the bottom impactor stage

M_f = mass collected on backup filter (grams)

b. Volume H₂O Vapor at STP:

where: V_{H_2O} = volume of water vapor @ STP (ft³)

W = water collected (grams)

STP = 29.92 in. Hg and 70°F

c. Meter Volume at STP:

$$V_{ms} = V_m \left(\frac{P_b - P_m}{T_m + 460} \right) \left(\frac{530}{29.92} \right)$$

where: V_{ms} = meter volume @ STP (ft³)

V_m = meter volume (ft³)

P_b = barometric pressure ("Hg)

P_m = average static pressure at meter (-"Hg)

T_m = average meter temperature (°F)

d. Total Volume Sampled at STP, V_T (ft³):

(1) Outlet impactor only

$$V_T = V_{H_2O} + V_{ms}$$

(2) Inlet impactor only

$$V_T = V_{ms}/F$$

where: F = dry gas fraction.

e. Percent Moisture, H_2O (%):

$$H_2O = (V_{H_2O}/V_T) (100)$$

f. Mass Concentration, C_m (grains/dscf):

$$C_m = (M_T/V_{ms}) (15.43 \text{ grains/gram})$$

g. Volume Sampled at Stack Conditions:

$$V_s = V_T \left(\frac{T_s + 460}{P_b + P_s/13.596} \right) \left(\frac{29.92}{530} \right)$$

where: V_s = volume sampled at stack conditions (ft^3)
 T_s = average stack temperature ($^{\circ}\text{F}$).
 P_s = average stack static pressure (+ " H_2O ")

h. Impactor Flow Rate:

$$Q_I = V_s/t$$

where: Q_I = impactor flow rate (acfm)
 t = time (minutes)

i. Impactor Stage Size Cutoffs:

$$d_{pca} = \left(\frac{0.135 \pi \mu_g d_c^3 N K_{p50}}{Q (10^{-8})} \right)^{1/2}$$

with $d_{pca} = d_p (C_{sp})^{1/2} 10^4$

and $C' = 1 + \frac{2\lambda}{d_p} [1.257 + 0.40 \exp (1 - 1.10 d_p/2\lambda)]$

where: C' = Cunningham slip correction factor
 λ = mean free path of gas molecules, cm
 d_p = particle diameter, cm
 ρ_p = particle density, g/cm^3
 d_{pca} = cut diameter, $\text{m (g/cm}^3)^{1/2}$
 μ_g = gas viscosity, g/cm-sec
 d_c = jet diameter, cm
 N = number of jets in an impaction stage

K_{p50} = inertial impaction cut parameter at 50 percent efficiency*

Q = total flow rate, l/min

j. Percent Mass Collected on Backup Filter, P_F (%)

$$P_F = (M_F/M_T) 100$$

k. Percent Mass Collected on Each Impactor Stage, P_I (%)

$$P_I = (M_I/M_T) 100$$

l. Percent Mass Collected in Probe and Impactor Prior to Top Impactor Stage, P_p (%)

$$P_p = (M_p/M_T) 100$$

m. Cumulative Percent Mass $\leq$ Stage Cutoff Diameter for Each Impactor Stage, C_{pn} (%)

$$C_{pn} = \sum_{L=b}^{n=1} P_I + P_F$$

where: $L=b$ = corresponds to the bottom impactor stage

$L=n$ = corresponds to the impactor stage of interest

n. $dM/d \log D$ (grains/dacf):

$$dM/d \log D = \frac{(P_I/100) C_m}{(\log D_s + 1) - (\log D_s)}$$

where: P_I = percent mass collected on a particular stage s (%)

o. Geometric Mean Diameter, D_M (μm):

$$D_M = \sqrt{D_{s+1} \times D_s}$$

* d_{50} from manufacturers calibration curves.

APPENDIX C

TOTAL PARTICULATE EXAMPLE CALCULATIONS
(BY RTI)

Ala met

Bay house Inlet

See Table for my calculated Results

A. Concentrations in gas

My data given in mg/dsm^3 correspond to previous data given to you (multiply my numbers by 0.028316847 - convert m^3 to ft^3 - to get result in mg/dsft^3)

I checked these and they agree.

B. generated per hour

Calculated by:

$$(1 \times 10^{-6} \frac{\text{kg}}{\text{mg}}) (\text{Conc. in gas, mg/dsm}^3) (\text{gas flow rate, ds cfm/min}) (60 \text{ min/hr}) (0.028316847)$$

Run #1

$$(1 \times 10^{-6}) (701.3) (256,840) (60) (0.028316847) = 306.0 \text{ Kg/hr} = 679.6 \text{ lb/hr}$$

$$\text{Run \#2 } (1 \times 10^{-6}) (1265.3) (273,614) (60) (0.028 \dots) = 588.2 \text{ Kg/hr} = 1,296.8 \text{ lb/hr}$$

$$\text{Run \#3 } (1 \times 10^{-6}) (1281.5) (269,091) (60) (0.028 \dots) = 803.8 \text{ Kg/hr} = 1,772.2 \text{ lb/hr}$$

$$\text{Run \#4 } (1 \times 10^{-6}) (801.6) (270,190) (60) (0.028 \dots) = 368.0 \text{ Kg/hr} = 811.3 \text{ lb/hr}$$

$$\text{Run \#5 } (1 \times 10^{-6}) (840.1) (272,349) (60) (0.028 \dots) = 388.7 \text{ Kg/hr} = 857.0 \text{ lb/hr}$$

$$\text{Run \#6 } (1 \times 10^{-6}) (2019.2) (276,300) (60) (0.028 \dots) = 948.2 \text{ Kg/hr} = 2,090.4 \text{ lb/hr}$$

$$\text{Avg} = \frac{567.2}{6} = 1,250.4$$

C. Avg load during test

	Meter reading at		Meter reading at		m-hr in hour		Avg m-hr/hr
Run #1	42198	1315	42241	1549	43	2.566	16.75
2	42577	0812	42612	1354	95	5.7	16.67
3	42612	1354	42658	1632	46	2.63	17.47
4	42926	0830	42958	1018	32	1.8	17.78
5	42972	1112	43009	1321	37	2.15	17.21
6	43009	1321	43052	1544	43	2.38	18.07

11. Calculate = generated / mwh

Divide amount generated / hr by AVG load

Example Run #1: $306.0 \div 16.75 = 18.27 \text{ Kg/mwh}$
or 40.28 lb/mwh

AVG for 6 runs = 32.55 Kg/mwh or 71.77 lb/hr
MW

E. Calculate Kg generated / Mg feed

Method: Divide total mix fed on shift by total operating hours on shift to get rate / hour. Divide this into Kg particulate generated / hour to get result. If test run over lap two shifts: first determine mix fed / hour on each shift. Then proportion this according to length of test on each shift to get average mix fed per hour during test.

Run #1 7-3 shift 39,708 Kg fed in 7 hours 46 minutes

Thus: $5112.6 \text{ Kg/operating hour}$

on 3-11 shift 67,447 Kg fed in 8.0 hours

Thus: 8430.9 Kg/hour

Run time was 1335 to 1525 yielding 1 hour 25 minutes on 7-3 shift and 25 min on 7-11 shift

Mix fed from 1335-1500 = $11 \frac{35}{60} \times 5112.6 = 7242.85$

1500-1525 = $25 \frac{0}{60} \times 8430.9 = 3512.85$

Total fed during test = 10755.73

or $10,755.73 \div 1 \frac{50}{60} = 5866.76 \text{ Kg/hour}$ during
= $12,934 \text{ lbs/hr}$ } Test
= 6.467 tons/hr

$306.0 \text{ Kg particulate generated/hour} \div 5.86676 \text{ Mg/hr}$

= 52.2 Kg/Mg

= 104.3 lbs/ton

I come up with the following mix feed rates for other runs

Run 2	6,927.5 Kg/hour	=	15,272.5 lb/hr
3	7,571.8 " "	=	16,692.96 " "
4	7,331.25 " "	=	16,162.64 " "
5	7,331.25 " "	=	16,162.64 " "
6	8,023.125 " "	=	17,687.96 " "

F. Calculate Kg / Mg alloy tapped

5

Method: Divide Total amount tapped for entire day by total MW-hrs for day to get average amount of alloy produced per MW-hr. Multiply this by average MW load during test to get alloy produced/hr during test. Divide this number into Kg of particulate generated per hour.

Run no. 1

29,596 Kg alloy (65,246 lbs) produced on 1/26/81
power consumption 24 hours - midnight to midnight
400 MW-hr
give 73.99 Kg alloy / MW-hr

$$73.99 \times 16.75 \text{ MW load} = 1239.33 \text{ Kg alloy / hour during Test.}$$

$$306 \div 1.23933 \text{ Mg alloy} = \boxed{246.9 \text{ Kg particulate / Mg alloy}}$$

$$= \boxed{493.8 \text{ lbs / ton}}$$

Run NO. 2

$$30,483 \text{ Kg alloy} \div 400 \text{ MW-hr} = 76.21 \text{ Kg prod / MW-hr}$$

$$76.21 \times 16.67 \text{ MW load} = 1270.37 \text{ Kg / hour}$$

$$588.2 \div 1.27037 = \boxed{463 \text{ Kg particulate / Mg alloy}}$$

$$= \boxed{926 \text{ lbs / Ton}}$$

Run 3

$$(30,483 \div 400) (17.47) = 1.33139 \text{ Mg alloy / hr}$$

$$803.8 \div 1.33139 = 604 \text{ Kg / Mg}$$

$$= 1207 \text{ lb / ton}$$

$$4 \quad 30,096.3 \div 410 = 73.406 \text{ Kg / MW-hr} \times 17.78 \text{ MW-hr} =$$

$$1305.15 \text{ Kg / hour}$$

$$368 \div 1.30515 = 282 \text{ Kg / Mg}$$

$$= 564 \text{ lb / ton}$$

$$5 \quad 73.406 \text{ Kg / MW-hr} \times 17.21 = 1263.31 \text{ Kg / hr}$$

$$388.7 \div 1.26331 = 308 \text{ Kg / Mg}$$

$$615 \text{ lb / ton}$$

$$6 \quad 73.406 \times 18.07 = 1326.45 \text{ Kg / hr}$$

$$948.2 \div 1.32645 = 715 \text{ Kg / Mg}$$

$$59 = 1430 \text{ lb / ton}$$

Baghouse outlet

Planet

A. First determine baghouse exhaust gas flow rate

Baghouse exhaust flow rate is sum of inlet gas flow rate and air drawn into baghouse through cooling air grates in bottom of baghouse.

Method: Calculate from inlet gas temp, outlet gas temp, and ambient temp (assume no heat loss)

$$(\text{Inlet Temp})(\text{Inlet flow rate}) + (\text{Ambient Temp})(\text{ambient air drawn in}) = \left(\begin{array}{c} \text{sum inlet} \\ \text{and ambient} \\ \text{flow rates} \\ \text{||} \\ \text{outlet} \\ \text{flow rate} \end{array} \right) (\text{outlet Temp})$$

$$\text{ie } (T_i)(F_i) + (T_A)(F_A) = (F_A + F_i)T_o$$

$$\text{or } \frac{(T_i - T_o)F_i}{(T_o - T_A)} = F_A$$

Ambient air Temp 60°F (Since using ratio don't need to convert to °R)

$$\text{Run \#1 } \frac{(322 - 246)F_i}{(246 - 60)} = F_A$$

0.41 $F_i = F_A$, ie Ambient air drawn in equal to 41% of inlet gas flow rate

$$\text{Run \#2 } \frac{(308 - 248)F_i}{(248 - 60)} = F_A$$

$$0.32 F_i = F_A$$

Rather than use individual data I used
Avg for the 5 runs is

$$\text{Run \#3 } \frac{(317 - 227)F_i}{(227 - 60)} = F_A$$

$$0.54 F_i = F_A$$

$$0.468 F_i = F_A$$

Thus, multiply inlet flow rate by 1.468 to get outlet flow rate.

$$\text{Run \#4 } \frac{(300 - 209)F_i}{(209 - 60)} = F_A$$

$$0.61 F_i = F_A$$

$$\text{Run \#5 } \frac{(317 - 236)F_i}{(236 - 60)} = F_A$$

$$0.16 F_i = F_A$$

Run #1	1.468	X	256,840 dscfm	=	377041	=	10,670 dscm/min	
Run #2	"	"	273,614	"	=	401665	=	11,340
Run #3	"	"	264,091	"	=	387686	=	10,980
Run #4	"	"	274,190	"	=	396639	=	11,230
Run #5	"	"	272,349	"	=	399808	=	11,400

B. Ceres in gas - My data (in mg/dscm³) agree (within rounding error) to data given to you previously

C. Emitted / hour

See (B) inlet for calc method
I calc. using rounded dscm³/min figures above and
Ceres in mg/dscm³

D. Avg Load during Test

Run no	meter	at	meter	at	mwh	in hours	Avg load mwh/hr
1	42198	1315	42268	1707	70	3.866	18.10
2	42577	0812	42612	1354	95	5.7	16.67
3	42612	1354	42671	1716	59	3.366	17.52
4	42926	0830	42989	1207	63	3.6166	17.42
5	42989	1207	43052	1544	63	3.6166	17.42

E. Emitted / mwh

Divide Kg emitted by Avg load

F. Calc. same as in E for inlet

I calc. the following feed rate during test

Run 1 =	6.7426 Mg/hr
2 =	6.9275
3 =	7.91643
4 =	7.33125
5 =	7.5821

G. Use same Kg alloy / mwh as in F for inlet and same
Calc. methods

Run #1	73.99 Kg alloy / mwh
2	76.21
3	76.21
4	73.4
5	77.

APPENDIX D-1

CASCADE IMPACTOR DATA REDUCTION SYSTEM PRINTOUTS,
BAGHOUSE INLET

"COMPARE" output for all inlet impactor runs

DATA COMPARISON FOR 13 INLET RUNS BY GCA

STD. PT.	IM/DLOGD (MICRONS)	IM/DLOGD (MG/INCM)	CUMULATIVE MASS < D50	AVG.	STD. DEV.	CUM. % MASS < D50	MIN.	MAX.
1	20.00	1.28E+03	1.19E+03	97.04	15.47		59.89	112.86
2	15.00	4.76E+02	1.09E+03	86.54	16.59		45.88	102.31
3	10.00	2.80E+02	1.03E+03	80.80	16.46		44.35	98.80
4	5.00	1.60E+02	9.66E+02	74.36	16.31		42.97	96.82
5	2.50	2.05E+02	9.14E+02	69.68	17.90		41.03	94.91
6	1.25	5.41E+02	8.23E+02	62.04	19.10		37.50	90.39
7	1.00	1.16E+03	7.43E+02	56.64	18.30		32.33	83.50

THE RUNS MARKED WITH AN * APPEAR TO CONTAIN OUTLIERS

TEST SITE	ALAM	ALAM	ALAM	ALAM	ALAM	ALAM	ALAM
TEST DATE	12681	12681	12681	12681	12681	12681	12681
RUN NUMBER	1*	2*	3	4*	5*	6*	7
RUN DATE	12681	12681	12781	12781	12781	12781	12881
START TIME	1410	1515	920	952	1552	1405	846
TOTAL MASS	2.569E+02	1.898E+02	5.482E+02	2.255E+03	4.692E+03	2.454E+03	7.920E+02

IM/DLOGD IN STANDARD INTERVALS (MG/INCM)

1	20.00	3.19E+02*	1.54E+02*	8.23E+02	2.23E+03*	1.89E+03	2.30E+03*	7.84E+02
2	15.00	1.43E+02*	6.34E+01*	1.86E+02	5.45E+02	3.90E+02	8.99E+02*	3.71E+02
3	10.00	2.25E+01	3.24E+01	1.17E+01	1.25E+01	9.09E+02*	9.61E+01	2.48E+02
4	5.00	2.21E+00	2.08E+01	2.58E+01	-5.18E+01*	1.54E+01	5.22E+02*	1.07E+02
5	2.50	1.20E+01*	8.41E+00*	3.41E+01	6.25E+01	2.89E+02	6.09E+02*	1.50E+02
6	1.25	1.24E+02	4.85E+01	6.52E+01	5.98E+02	2.62E+03*	8.10E+02	3.91E+02
7	1.00	2.13E+02	8.44E+01	1.11E+02	1.27E+03	5.98E+03*	1.39E+03	6.10E+02

TEST SITE	ALAM	ALAM	ALAM	ALAM	ALAM	ALAM
TEST DATE	12681	12681	12681	12681	12681	12681
RUN NUMBER	8*	9*	10*	11	12*	13
RUN DATE	12881	12881	12881	12881	12881	12881
START TIME	1000	1319	1133	1214	1428	1602
TOTAL MASS	1.779E+03	1.221E+03	9.651E+02	1.161E+03	3.325E+03	1.609E+03

IM/DLOGD IN STANDARD INTERVALS (MG/INCM)

1	20.00	1.51E+03	1.22E+03	7.28E+02	1.04E+03	2.31E+03*	1.34E+03
2	15.00	1.01E+03*	9.71E+02*	6.22E+02	5.29E+02	2.90E+02	1.70E+02
3	10.00	6.64E+02*	3.46E+02	4.80E+02	4.72E+02	1.36E+02	2.10E+02
4	5.00	3.67E+02*	5.23E+02*	2.14E+02	1.25E+02	1.25E+02	8.06E+01
5	2.50	3.28E+02	2.03E+02	4.53E+02*	1.52E+02	1.95E+02	1.72E+02
6	1.25	3.37E+02	5.05E+01	4.30E+02	3.95E+02	8.15E+02	3.50E+02
7	1.00	2.70E+02	2.61E+02	4.11E+02	4.89E+02	2.99E+03*	5.40E+02

THE VALUES MARKED BY AN * APPEAR TO BE OUTLIERS

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12691, RUN NO. 1
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAMET, SELMA, ALABAMA
 RUN COMMENTS: 1-I-B-16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1640 .0000 .3808
 2 264 .1250 .0000 .3808
 3 264 .0950 .0000 .3808
 4 264 .0760 .0000 .3808
 5 264 .0670 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .557 ACFM

IMPACTOR TEMPERATURE = 322.0 F (161.1 C)

SAMPLING DURATION = 2.00 MIN

IMPACTOR PRESSURE DROP = .431 IN. OF HG

STACK TEMPERATURE = 322.0 F (161.1 C)

STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 2.60

CALC. MASS LOADING = 7.3324-002 GR/ACF

1.1225-001 GR/DNCF

1.6779+002 MG/ACM

2.5686+002 MG/DNCF

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE 1	S1 2	S2 3	S3 4	S4 5	S5 6	S6 7	S7 8	S8 9	FILTER 10
D50 (MICRONS)	16.00	14.55	9.64	6.34	4.50	3.71	1.38	.80	.54	.54/2.0
MASS (MG)	1.89	.00	.18	.00	.11	.00	.27	.78	1.11	.95
MG/DNCF/STAGE	9.17+001	4.85-002	8.74+000	4.85-002	5.34+000	4.85-002	1.31+001	3.79+001	5.39+001	4.61+001
CUM. % OF MASS	60.77	60.75	57.02	56.99	54.71	54.69	49.09	32.90	9.86	
CUM. MASS (MG/ACM) < D50	9.28+001	9.28+001	8.71+001	8.70+001	8.36+001	8.35+001	7.50+001	5.02+001	1.51+001	
CUM. MASS (MG/DNCF) < D50	1.42+002	1.42+002	1.33+002	1.33+002	1.28+002	1.28+002	1.15+002	7.69+001	2.31+001	
CUM. MASS (GR/ACF) < D50	4.06-002	4.05-002	3.81-002	3.80-002	3.65-002	3.65-002	3.28-002	2.20-002	6.58-003	
CUM. MASS (GR/DNCF) < D50	6.21-002	6.21-002	5.83-002	5.82-002	5.59-002	5.59-002	5.02-002	3.36-002	1.01-002	
GEO. MEAN DIA. (MICRONS)	2.37+001	1.53+001	1.18+001	7.82+000	5.35+000	4.09+000	2.26+000	1.05+000	6.61-001	3.85-001
DM/DLOGD (MG/DNCF)	2.70+002	1.18+000	4.88+001	2.67-001	3.59+001	5.73-001	3.06+001	1.60+002	3.20+002	1.53+002
DN/DLOGD (NUMBER/DNCF)	3.89+007	6.34+005	5.61+007	1.07+006	4.48+008	1.61+007	5.04+009	2.61+011	2.12+012	5.13+012

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA AT SITE ALAM, ON DATE 12681, RUN NO. 2
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAHET,SELHA,ALABAMA
 RUN COMMENTS: 1-1-A-16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1640 .0000 .3908
 2 264 .1250 .0000 .3808
 3 264 .0950 .0000 .3908
 4 264 .0750 .0000 .3808
 5 264 .0670 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .580 ACFM

IMPACTOR TEMPERATURE = 322.0 F (161.1 C)

SAMPLING DURATION = 2.00 MIN

IMPACTOR PRESSURE DROP = .467 IN. OF HG STACK TEMPERATURE = 322.0 F (161.1 C) STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 2.60

CALC. MASS LOADING = 5.4186-002 GR/ACF 8.2949-002 GR/DNCF 1.2400+002 MG/ACM 1.8982+002 MG/DNCH

AEROHYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	16.00	14.26	9.45	6.21	4.41	3.63	1.35	.78	.53	.53/2.0
MASS (MG)	.00	.02	.00	.29	.13	.00	.15	.36	.74	2.38
MG/DNCH/STAGE	4.66-002	9.32-001	4.66-002	1.35+001	6.06+000	4.66-002	6.99+000	1.68+001	3.45+001	1.11+002
CUM. % OF MASS	99.97	99.27	99.24	89.18	84.67	84.63	79.43	66.94	41.28	
CUM. MASS (MG/ACH) < D50	8.77+001	8.71+001	8.71+001	7.83+001	7.43+001	7.43+001	6.97+001	5.88+001	3.62+001	
CUM. MASS (MG/DNCH) < D50	1.34+002	1.33+002	1.33+002	1.20+002	1.14+002	1.14+002	1.07+002	8.99+001	5.55+001	
CUM. MASS (GR/ACF) < D50	3.83-002	3.81-002	3.81-002	3.42-002	3.25-002	3.25-002	3.05-002	2.57-002	1.58-002	
CUM. MASS (GR/DNCF) < D50	5.87-002	5.83-002	5.83-002	5.24-002	4.97-002	4.97-002	4.66-002	3.93-002	2.42-002	
GEO. MEAN DIA. (MICRONS)	2.37+001	1.51+001	1.16+001	7.66+000	5.24+000	4.00+000	2.22+000	1.03+000	6.45-001	3.75-001
DH/DLOGD (MG/DNCH)	1.37-001	1.86+001	2.61-001	7.44+001	4.07+001	5.50-001	1.63+001	7.07+001	2.04+002	3.68+002
DN/DLOGD (NUMBER/DNCH)	1.98+004	1.03+007	3.18+005	3.16+008	5.41+008	1.64+007	2.86+009	1.24+011	1.45+012	1.33+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA - AT SITE ALAM, CN DATE 12681, RUN NO. 3
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALANET,SELMA,ALABAMA
 RUN COMMENTS: 2-1-A 90

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1640 .0300 .3503
 2 264 .1250 .0000 .3203
 3 264 .0950 .0000 .3203
 4 264 .0760 .0000 .3808
 5 264 .0570 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .505 ACFM IMPACTOR TEMPERATURE = 308.0 F (153.3 C) SAMPLING DURATION = 3.30 MIN
 IMPACTOR PRESSURE DROP = .359 IN. OF HG STACK TEMPERATURE = 308.0 F (153.3 C) STACK PRESSURE = 29.53 INCHES OF HG
 DRY GAS COMPOSITION (PERCENT) CO2 = .30 N2 = 78.00 O2 = 21.00 H2O = 2.60
 CALC. MASS LOADING = 1.5882-001 GR/ACF 2.3958-001 GR/DNCF 3.6344+002 MG/ACM 5.4825+002 MG/DNCF

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.0CGM/CU.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE 1	S1 2	S2 3	S3 4	S4 5	S5 6	S6 7	S7 8	S8 9	FILTER 10
D50 (MICRONS)	17.00	15.19	10.07	6.63	4.71	3.88	1.45	.84	.58	.58/2.0
MASS (MG)	7.62	.00	.06	.09	.15	.32	.31	.55	1.36	6.69
MG/DNCF/STAGE	2.44+002	3.20+002	1.92+000	2.88+000	4.79+000	1.02+001	9.91+000	1.76+001	4.35+001	2.14+002
CUM. % OF MASS	44.81	44.80	44.36	43.71	42.63	40.31	38.06	34.08	24.23	
CUM. MASS (MG/ACM) < D50	1.31+002	1.31+002	1.30+002	1.28+002	1.25+002	1.18+002	1.11+002	9.97+001	7.09+001	
CUM. MASS (MG/DNCF) < D50	1.98+002	1.93+002	1.96+002	1.93+002	1.88+002	1.78+002	1.68+002	1.50+002	1.07+002	
CUM. MASS (GR/ACF) < D50	5.73+002	5.73+002	5.67+002	5.59+002	5.45+002	5.15+002	4.87+002	4.36+002	3.10+002	
CUM. MASS (GR/DNCF) < D50	8.64+002	8.64+002	8.56+002	8.43+002	8.22+002	7.77+002	7.34+002	6.57+002	4.67+002	
GEO. MEAN DIA. (MICRONS)	2.44+001	1.61+001	1.24+001	8.17+000	5.59+000	4.27+000	2.37+000	1.11+000	6.98+001	4.08-001
DN/DLOGD (MG/DNCF)	7.77+002	6.55+001	1.07+001	1.58+001	3.23+001	1.21+002	2.32+001	7.48+001	2.62+002	7.10+002
DN/DLOGD (NUMBER/DNCF)	1.02+008	3.01+005	1.08+007	5.55+007	3.54+008	2.97+009	3.33+009	1.05+011	1.47+012	2.00+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 4
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAHET, SELMA, ALABAMA
 RUN COMMENTS: 2-I-B-90

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808	
2	264	.1250	.0000	.3908	
3	264	.0950	.0000	.3808	
4	264	.0760	.0000	.3808	
5	264	.0670	.0000	.3808	
6	264	.0360	.1760	.3908	
7	264	.0260	.2940	.3808	
8	156	.0250	1.0000	.3808	

IMPACTOR FLOWRATE = .489 ACFM

IMPACTOR PRESSURE DROP = .339 IN. OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30

CALC. MASS LOADING = 6.6276-001 GR/ACF

IMPACTOR TEMPERATURE = 308.0 F (153.3 C)

STACK TEMPERATURE = 308.0 F (153.3 C)

CO = .10 N2 = 78.00

9.8559-001 GR/DNCF 1.5166+003 MG/ACM

SAMPLING DURATION = 3.00 MIN

STACK PRESSURE = 29.53 INCHES OF HG

O2 = 21.00 H2O = 1.20

2.2554+003 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	17.00	15.48	10.26	6.76	4.80	3.95	1.48	.86	.59	.59/2.0
MASS (MG)	2.60	.00	.00	.08	.31	.60	1.19	4.66	13.56	40.00
MG/DNCH/STAGE	9.31+001	3.58+002	3.58+002	2.86+000	1.11+001	2.15+001	4.26+001	1.67+002	4.85+002	1.43+003
CUM. % OF MASS	93.95	93.95	93.95	93.76	93.04	91.65	88.88	78.04	46.51	
CUM. MASS (MG/ACM) < D50	9.73+002	9.73+002	9.73+002	9.71+002	9.63+002	9.49+002	9.20+002	8.08+002	4.81+002	
CUM. MASS (MG/DNCH) < D50	1.45+003	1.45+003	1.45+003	1.44+003	1.43+003	1.41+003	1.37+003	1.20+003	7.16+002	
CUM. MASS (GR/ACF) < D50	4.25+001	4.25+001	4.25+001	4.24+001	4.21+001	4.15+001	4.02+001	3.53+001	2.10+001	
CUM. MASS (GR/DNCF) < D50	6.32+001	6.32+001	6.32+001	6.31+001	6.26+001	6.17+001	5.98+001	5.25+001	3.13+001	
GEO. MEAN DIA. (MICRONS)	2.44+001	1.62+001	1.26+001	8.33+000	5.69+000	4.35+000	2.42+000	1.13+000	7.13+001	4.17+001
DN/DLOSD (MG/DNCH)	2.97+002	8.81+001	2.00+001	1.58+001	7.47+001	2.54+002	1.00+002	7.11+002	2.94+003	4.76+003
DN/DLOSD (NUMBER/DNCH)	3.91+007	3.94+005	1.91+005	5.22+007	7.73+008	5.89+009	1.35+010	9.40+011	1.54+013	1.25+014

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 5
 TEST COMMENTS: IP TEST OF PEPOSILICON FURNACE--ALANET, SELMA, ALABAMA
 RUN COMMENTS: 3 I A 16-2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .324 ACFM

IMPACTOR TEMPERATURE = 317.0 F (158.3 C)

SAMPLING DURATION = 1.50 MIN

IMPACTOR PRESSURE DROP = .146 IN. OF HG STACK TEMPERATURE = 317.0 F (158.3 C) STACK PRESSURE = 29.54 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 2.20

CALC. MASS LOADING = 1.3496+000 GR/ACF 2.0506+000 GR/DNCF 3.0883+003 MG/ACM 4.6924+003 MG/DNCF

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE 1	S1 2	S2 3	S3 4	S4 5	S5 6	S6 7	S7 8	S8 9	FILTER 10
D50 (MICRONS)	22.00	19.09	12.66	8.35	5.94	4.89	1.85	1.09	.76	.76/2.0
MASS (MG)	1.83	.00	.43	1.68	.14	.92	.96	2.23	10.14	24.17
MG/DNCF/STAGE	2.02+002	1.10+001	4.75+001	1.85+002	1.55+001	1.02+002	1.06+002	2.46+002	1.12+003	2.67+003
CUM. % OF MASS	93.98	93.98	92.57	87.04	86.58	83.56	80.40	73.07	39.73	
CUM. MASS (MG/ACM) < D50	2.08+003	2.08+003	2.05+003	1.92+003	1.91+003	1.85+003	1.78+003	1.61+003	8.78+002	
CUM. MASS (MG/DNCF) < D50	3.16+003	3.16+003	3.11+003	2.92+003	2.91+003	2.81+003	2.70+003	2.45+003	1.33+003	
CUM. MASS (GR/ACF) < D50	9.08+001	9.08+001	8.94+001	8.41+001	8.36+001	8.07+001	7.77+001	7.06+001	3.84+001	
CUM. MASS (GR/DNCF) < D50	1.38+000	1.38+000	1.36+000	1.28+000	1.27+000	1.23+000	1.18+000	1.07+000	5.83+001	
GEO. MEAN DIA. (MICRONS)	2.77+001	2.05+001	1.55+001	1.03+001	7.04+000	5.39+000	3.01+000	1.42+000	9.07+001	5.34+001
DN/DLOGD (MG/DNCF)	1.00+003	1.79+000	2.66+002	1.02+003	1.04+002	1.21+003	2.51+002	1.07+003	7.04+003	8.86+003
DN/DLOGD (NUMBER/DNCF)	8.96+007	3.98+005	1.35+008	1.80+009	5.72+008	1.48+010	1.76+010	7.14+011	1.60+013	1.11+014

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, ON DATE 12681, RUN NO. 6
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAMET,SELMA,ALABAMA
 RUN COMMENTS: 3 I B 16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR OP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1640 .0000 .3808
 2 264 .1250 .0000 .3808
 3 264 .0950 .0000 .3808
 4 264 .0760 .0000 .3808
 5 264 .0670 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .437 ACFM

IMPACTOR TEMPERATURE = 317.0 F (158.3 C)

SAMPLING DURATION = 1.50 MIN

IMPACTOR PRESSURE DROP = .268 IN. OF HG STACK TEMPERATURE = 317.0 F (158.3 C) STACK PRESSURE = 29.54 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.00

CALC. MASS LOADING = 7.1452-001 GR/ACF

1.0725+000 GR/DNCF

1.6351+003 MG/ACM

2.4543+003 MG/DHCM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE 1	S1 2	S2 3	S3 4	S4 5	S5 6	S6 7	S7 8	S8 9	FILTER 10
D50 (MICRONS)	19.00	16.46	10.91	7.18	5.10	4.20	1.58	.92	.63	.63/2.0
MASS (MG)	2.16	.49	1.92	.03	.88	1.95	2.18	2.19	4.66	13.89
MG/DHCM/STAGE	1.75+002	3.96+001	1.55+002	2.43+000	7.12+001	1.58+002	1.76+002	1.77+002	3.77+002	1.12+003
CUM. % OF MASS	90.77	88.68	80.47	80.35	76.59	68.25	58.94	49.58	29.67	
CUM. MASS (MG/ACM) < D50	1.14+003	1.12+003	1.01+003	1.01+003	9.66+002	8.61+002	7.43+002	6.25+002	3.74+002	
CUM. MASS (MG/DHCM) < D50	1.72+003	1.68+003	1.52+003	1.52+003	1.45+003	1.29+003	1.12+003	9.38+002	5.62+002	
CUM. MASS (GR/ACF) < D50	5.00-001	4.89-001	4.43-001	4.43-001	4.22-001	3.76-001	3.25-001	2.73-001	1.64-001	
CUM. MASS (GR/DNCF) < D50	7.51-001	7.33-001	6.66-001	6.65-001	6.33-001	5.65-001	4.87-001	4.10-001	2.45-001	
GEO. MEAN DIA. (MICRONS)	2.58+001	1.77+001	1.34+001	8.85+000	6.06+000	4.63+000	2.58+000	1.21+000	7.65-001	4.48-001
DM/DLOGD (MG/DHCM)	6.58+002	6.35+002	8.69+002	1.34+001	4.79+002	1.87+003	4.15+002	7.59+002	2.30+003	3.73+003
DN/DLOGD (NUMBER/DNCF)	7.33+007	2.19+008	6.90+008	3.68+007	4.12+009	3.59+010	4.63+010	8.23+011	9.85+012	7.93+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 7
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAMET,SELMA,ALABAMA
 RUN COMMENTS: 4 I A 90

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUM'P CALIB

1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .405 ACFM

IMPACTOR TEMPERATURE = 300.0 F (148.9 C)

SAMPLING DURATION = 1.50 MIN

IMPACTOR PRESSURE DROP = .235 IN. OF HG STACK TEMPERATURE = 300.0 F (148.9 C) STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.20

CALC. MASS LOADING = 2.3599-001 GR/ACF

3.4612-001 GR/DNCF

5.4004+002 MG/ACM

7.9204+002 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

D50 (MICRONS)
 MASS (MG)
 MG/DNCH/STAGE
 CUM. % OF MASS < D50
 CUM. MASS (MG/ACM) < D50
 CUM. MASS (MG/DNCH) < D50
 CUM. MASS (GR/ACF) < D50
 CUM. MASS (GR/DNCF) < D50
 GEO. MEAN DIA. (MICRONS)
 DN/DLOGD (MG/DNCH)
 DN/DLOGD (NUMBER/DNCH)

CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	2	3	4	5	6	7	8	9	10
19.00	16.96	11.25	7.41	5.27	4.34	1.63	.96	.66	.66/2.0
1.66	.47	.44	.53	.36	.41	.48	.96	1.45	2.53
1.42+002	4.01+001	3.75+001	4.52+001	3.07+001	3.50+001	4.09+001	8.18+001	1.24+002	2.16+002
79.31	73.46	67.98	61.37	56.88	51.78	45.79	33.83	15.76	
3.70+002	3.43+002	3.17+002	2.86+002	2.65+002	2.42+002	2.14+002	1.58+002	7.35+001	
5.43+002	5.03+002	4.65+002	4.20+002	3.89+002	3.54+002	3.13+002	2.31+002	1.08+002	
1.62-001	1.50-001	1.39-001	1.25-001	1.16-001	1.06-001	9.34-002	6.90-002	3.21-002	
2.37-001	2.20-001	2.03-001	1.83-001	1.70-001	1.55-001	1.37-001	1.01-001	4.71-002	
2.58+001	1.80+001	1.38+001	9.13+000	6.25+000	4.78+000	2.66+000	1.25+000	7.95-001	4.67-001
5.33+002	8.13+002	2.10+002	2.49+002	2.07+002	4.15+002	9.66+001	3.53+002	7.64+002	7.17+002
5.94+007	2.68+008	1.52+008	6.26+008	1.62+009	7.26+009	9.76+009	3.44+011	2.90+012	1.35+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, CH DATE 12681, RUN NO. 8
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAMET.SELHA,ALABAMA
 RUN COMMENTS: 4 I B 90

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	254	.1649	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .443 ACFM

IMPACTOR TEMPERATURE = 300.0 F (148.9 C)

SAMPLING DURATION = 1.60 MIN

IMPACTOR PRESSURE DROP = .284 IN. OF HG STACK TEMPERATURE = 300.0 F (148.9 C) STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 79.00 O2 = 21.00 H2O = 1.20

CALC. MASS LOADING = 5.3018-001 GR/ACF 7.7758-001 GR/DNCF 1.2132+003 MG/ACM 1.7794+003 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	18.00	16.21	10.75	7.08	5.03	4.14	1.56	.91	.63	.63/2.0
MASS (MG)	.00	1.14	1.61	1.47	.77	1.12	1.66	.97	3.73	11.88
HG/DNCH/STAGE	7.31-002	8.33+001	1.18+002	1.07+002	5.63+001	8.18+001	1.21+002	7.09+001	2.73+002	8.68+002
CUM. % OF MASS	99.99	93.80	85.06	77.07	72.89	66.81	57.79	52.52	32.26	
CUM. MASS (MG/ACH) < D50	9.17+002	8.60+002	7.80+002	7.07+002	6.69+002	6.13+002	5.30+002	4.82+002	2.96+002	
CUM. MASS (HG/DNCH) < D50	1.35+003	1.26+003	1.14+003	1.04+003	9.81+002	8.99+002	7.77+002	7.07+002	4.34+002	
CUM. MASS (GR/ACF) < D50	4.01-001	3.76-001	3.41-001	3.09-001	2.92-001	2.68-001	2.32-001	2.11-001	1.29-001	
CUM. MASS (GR/DNCF) < D50	5.88-001	5.51-001	5.00-001	4.53-001	4.29-001	3.93-001	3.40-001	3.09-001	1.90-001	
GEO. MEAN DIA. (MICRONS)	2.51+001	1.71+001	1.32+001	8.72+000	5.97+000	4.56+000	2.54+000	1.19+000	7.55-001	4.43-001
DH/DLOGD (HG/DNCH)	2.53-001	1.83+003	6.59+002	5.92+002	3.79+002	9.71+002	2.86+002	3.04+002	1.67+003	2.88+003
DH/DLOGD (NUMBER/DNCH)	3.06+004	7.02+008	5.47+008	1.71+009	3.41+009	1.95+010	3.33+010	3.43+011	7.41+012	6.35+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, ON DATE 12681, RUN NO. 9
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALANET,SELMA,ALABAMA
 RUN COMMENTS: 5-I-A 16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAH. CUMDP CALIB
 1 264 .1640 .0000 .3808
 2 264 .1250 .0000 .3808
 3 264 .0950 .0000 .3808
 4 264 .0760 .0000 .3808
 5 264 .0670 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .435 ACFM

IMPACTOR TEMPERATURE = 307.0 F (152.8 C)

SAMPLING DURATION = 1.70 MIN

IMPACTOR PRESSURE DROP = .271 IN. OF HG STACK TEMPERATURE = 307.0 F (152.8 C)

STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 79.00 O2 = 21.00 H2O = 2.10

CALC. MASS LOADING = 3.5708-001 GR/ACF 5.3340-001 GR/DNCF 8.1713+002 MG/ACM 1.2206+003 MG/DNCF

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE 1	S1 2	S2 3	S3 4	S4 5	S5 6	S6 7	S7 8	S8 9	FILTER 10
D50 (MICRONS)	18.00	16.39	10.86	7.15	5.08	4.19	1.58	.92	.63	.63/2.0
MASS (MG)	.00	1.29	1.74	.32	1.20	.27	1.77	.11	1.67	8.74
MG/DNCF/STAGE	7.13-002	9.20+001	1.24+002	2.28+001	8.56+001	1.93+001	1.26+002	7.85+000	1.19+002	6.23+002
CUM. % OF MASS	99.99	89.87	76.21	73.70	64.28	62.16	48.27	47.41	34.30	
CUM. MASS (MG/ACH) < D50	6.08+002	5.47+002	4.64+002	4.48+002	3.91+002	3.78+002	2.94+002	2.88+002	2.09+002	
CUM. MASS (MG/DNCF) < D50	9.09+002	8.17+002	6.93+002	6.70+002	5.84+002	5.65+002	4.39+002	4.31+002	3.12+002	
CUM. MASS (GR/ACF) < D50	2.66-001	2.39-001	2.03-001	1.96-001	1.71-001	1.65-001	1.28-001	1.26-001	9.12-002	
CUM. MASS (GR/DNCF) < D50	3.97-001	3.57-001	3.03-001	2.93-001	2.55-001	2.47-001	1.92-001	1.88-001	1.36-001	
GEO. MEAN DIA. (MICRONS)	2.51+001	1.72+001	1.33+001	8.82+000	6.03+000	4.61+000	2.57+000	1.20+000	7.64-001	4.48-001
DM/DLOGD (MG/DNCF)	2.47-001	2.26+003	6.95+002	1.26+002	5.77+002	2.28+002	2.97+002	3.37+001	7.31+002	2.07+003
DN/DLOGD (NUMBER/DNCF)	2.98+004	8.50+003	5.59+003	3.51+003	5.02+003	4.44+003	3.35+010	3.68+010	3.13+012	4.41+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12631, RUN NO. 10
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALANET, SELMA, ALABAMA
 RUN COMMENTS: 5-I-B-16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3809
3	264	.0950	.0000	.3809
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3809
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .426 ACFM

IMPACTOR TEMPERATURE = 307.0 F (152.8 C)

SAMPLING DURATION = 1.50 MIN

IMPACTOR PRESSURE DROP = .260 IN. OF HG STACK TEMPERATURE = 307.0 F (152.8 C) STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .20 N2 = 79.00 O2 = 21.00 H2O = 2.10

CALC. MASS LOADING = 2.8235-001 GR/ACF

4.2176-001 GR/DNCF

6.4611+002 MG/ACH

9.6513+002 MG/DNCFM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CH.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

CYCLONE
 1

S1
 2

S2
 3

S3
 4

S4
 5

S5
 6

S6
 7

S7
 8

S8
 9

FILTER
 10

D50 (MICRONS)	19.00	16.56	10.98	7.23	5.14	4.23	1.59	.93	.64	.64/2.0
MASS (MG)	.00	.91	.82	.99	.15	1.25	1.28	1.19	.76	4.34
MG/DNCFM/STAGE	8.26-002	7.51+001	6.77+001	8.17+001	1.24+001	1.03+002	1.06+002	9.82+001	6.27+001	3.58+002
CUM. % OF MASS	99.99	90.43	81.82	71.42	69.85	56.72	43.27	30.77	22.79	
CUM. MASS (MG/ACH) < D50	5.26+002	4.76+002	4.31+002	3.76+002	3.68+002	2.93+002	2.28+002	1.62+002	1.20+002	
CUM. MASS (MG/DNCFM) < D50	7.86+002	7.11+002	6.43+002	5.61+002	5.49+002	4.46+002	3.40+002	2.42+002	1.79+002	
CUM. MASS (GR/ACF) < D50	2.30-001	2.08-001	1.88-001	1.64-001	1.61-001	1.30-001	9.95-002	7.08-002	5.24-002	
CUM. MASS (GR/DNCF) < D50	3.43-001	3.11-001	2.81-001	2.45-001	2.40-001	1.95-001	1.49-001	1.06-001	7.83-002	
GEO. MEAN DIA. (MICRONS)	2.59+001	1.77+001	1.35+001	8.91+000	6.10+000	4.66+000	2.60+000	1.22+000	7.73-001	4.53-001
DM/DLOGD (MG/DNCFM)	3.11-001	1.26+003	3.79+002	4.51+002	8.35+001	1.22+003	2.49+002	4.22+002	3.86+002	1.19+003
DN/DLOGD (NUMBER/DNCFM)	3.47+004	4.31+008	2.95+008	1.22+009	7.04+008	2.31+010	2.72+010	4.46+011	1.59+012	2.44+013

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, CV DATE 12681, RUN NO. 11
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAMET, SELMA, ALABAMA
 RUN COMMENTS: 5-I-B-2-90

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0570	.0000	.3808
6	264	.0350	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .445 ACFM

IMPACTOR TEMPERATURE = 307.0 F (152.8 C)

SAMPLING DURATION = 1.50 MIN

IMPACTOR PRESSURE DROP = .283 IN. OF HG

STACK TEMPERATURE = 307.0 F (152.8 C)

STACK PRESSURE = 29.63 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30

CO = .10

N2 = 79.00

O2 = 21.00

H2O = 2.10

CALC. MASS LOADING = 3.3965-001 GR/ACF

5.0736-001 GR/DNCF

7.7724+002 MG/ACM

1.1610+003 MG/DHCM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CCU.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
D50 (MICRONS)	18.00	16.20	10.74	7.07	5.03	4.14	1.56	.91	.62	.62/2.0
MASS (MG)	.00	.77	.37	1.27	.64	.12	.70	1.22	1.23	8.37
MG/DNCH/STAGE	7.90-002	6.09+001	2.92+001	1.00+002	5.06+001	9.48+000	5.53+001	9.64+001	9.72+001	6.61+002
CUM. % OF MASS	99.99	92.66	89.14	77.05	70.96	69.82	63.15	51.54	39.83	
CUM. MASS (MG/ACM) < D50	5.56+002	5.15+002	4.95+002	4.28+002	3.94+002	3.88+002	3.51+002	2.86+002	2.21+002	
CUM. MASS (MG/DHCM) < D50	8.30+002	7.69+002	7.40+002	6.40+002	5.89+002	5.80+002	5.24+002	4.28+002	3.31+002	
CUM. MASS (GR/ACF) < D50	2.43-001	2.25-001	2.17-001	1.87-001	1.72-001	1.70-001	1.53-001	1.25-001	9.68-002	
CUM. MASS (GR/DNCF) < D50	3.63-001	3.36-001	3.23-001	2.80-001	2.57-001	2.53-001	2.29-001	1.87-001	1.45-001	
CUM. MASS (MG/DNCH) < D50	2.51+001	1.71+001	1.32+001	8.71+000	5.96+000	4.56+000	2.54+000	1.19+000	7.54-001	4.41-001
GEOM. MEAN DIA. (MICRONS)	2.74-001	1.33+003	1.64+002	5.53+002	3.41+002	1.12+002	1.30+002	4.13+002	5.95+002	2.20+003
DM/DLOGD (MG/DNCH)	3.31+004	5.10+008	1.36+008	1.60+009	3.07+009	2.26+009	1.52+010	4.69+011	2.66+012	4.88+013
DN/DLOGD (NUMBER/DNCH)										

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 12
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAHET, SELMA, ALABAMA
 RUN COMMENTS: 6 I A 16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUM'DP	CALIB
1	264	.1640	.0000	.3908
2	264	.1250	.0000	.3908
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3908
7	264	.0260	.2940	.3908
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .435 ACFM

IMPACTOR PRESSURE DROP = .268 IN. OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30

CALC. MASS LOADING = 9.7103-001 GR/ACF

IMPACTOR TEMPERATURE = 317.0 F (158.3 C)

STACK TEMPERATURE = 317.0 F (158.3 C)

CO = .10 N2 = 79.00

1.4531+000 GR/DNCF 2.2221+003 MG/ACM

SAMPLING DURATION = 1.00 MIN

STACK PRESSURE = 29.63 INCHES OF HG

H2O = 1.00

3.3252+003 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	19.00	16.49	10.93	7.20	5.12	4.21	1.58	.93	.64	.64/2.0
MASS (MG)	.00	.07	.14	.22	.23	.33	1.42	1.33	8.14	15.49
MG/DNCH/STAGE	1.21-001	8.50+000	1.70+001	2.67+001	2.79+001	4.01+001	1.73+002	1.62+002	9.89+002	1.88+003
CUM. % OF MASS	99.99	99.64	98.92	97.80	96.63	94.95	87.72	80.94	39.46	
CUM. MASS (MG/ACM) < D50	1.59+003	1.59+003	1.59+003	1.56+003	1.54+003	1.51+003	1.40+003	1.29+003	6.29+002	
CUM. MASS (MG/DNCH) < D50	2.38+003	2.38+003	2.36+003	2.33+003	2.30+003	2.26+003	2.09+003	1.93+003	9.41+002	
CUM. MASS (GR/ACF) < D50	6.96-001	6.94-001	6.89-001	6.81-001	6.73-001	6.61-001	6.11-001	5.64-001	2.75-001	
CUM. MASS (GR/DNCF) < D50	1.04+000	1.04+000	1.03+000	1.02+000	1.01+000	9.89-001	9.14-001	8.43-001	4.11-001	
GEO. MEAN DIA. (MICRONS)	2.58+001	1.77+001	1.34+001	8.87+000	6.07+000	4.64+000	2.58+000	1.21+000	7.67-001	4.50-001
DM/DLOGD (MG/DNCH)	4.58-001	1.38+002	9.52+001	1.47+002	1.88+002	4.75+002	4.06+002	6.93+002	6.06+003	6.25+003
DN/DLOGD (NUMBER/DNCH)	5.10+004	4.77+007	7.51+007	4.03+008	1.61+009	9.07+009	4.50+010	7.45+011	2.56+013	1.31+014

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, ON DATE 12681, RUN NO. 13
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAHET, SELMA, ALABAMA
 RUN COMMENTS: 6 I B 16

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1540	.0000	.3908
2	264	.1250	.0000	.3908
3	264	.0950	.0000	.3908
4	264	.0760	.0000	.3908
5	264	.0570	.0000	.3908
6	264	.0360	.1760	.3908
7	264	.0260	.2940	.3908
8	156	.0250	1.0000	.3908

IMPACTOR FLOWRATE = .405 ACFM

IMPACTOR TEMPERATURE = 317.0 F (158.3 C)

SAMPLING DURATION = 1.50 MIN

IMPACTOR PRESSURE DROP = .233 IN. OF HG STACK TEMPERATURE = 317.0 F (158.3 C) STACK PRESSURE = 29.62 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 79.00 O2 = 21.00 H2O = 1.00

CALC. MASS LOADING = 4.6973-001 GR/ACF 7.0316-001 GR/DNCF 1.0749+003 MG/ACM 1.6091+003 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.003M/CU.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	19.55	17.10	11.34	7.47	5.31	4.37	1.65	.96	.66	.66/2.0
MASS (MG)	.00	.25	.13	.48	.18	.47	.47	.88	1.51	14.12
HG/DNCH/STAGE	8.70-002	2.18+001	1.13+001	4.18+001	1.57+001	4.09+001	4.09+001	7.66+001	1.31+002	1.23+003
CUM. % OF MASS	99.99	97.80	96.67	92.47	90.89	86.78	82.67	74.97	61.76	
CUM. MASS (MG/ACH) < D50	6.64+002	6.50+002	6.42+002	6.14+002	6.04+002	5.77+002	5.49+002	4.98+002	4.10+002	
CUM. MASS (MG/DNCH) < D50	9.95+002	9.73+002	9.62+002	9.20+002	9.04+002	8.63+002	8.22+002	7.46+002	6.14+002	
CUM. MASS (GR/ACF) < D50	2.90-001	2.84-001	2.81-001	2.69-001	2.64-001	2.52-001	2.40-001	2.18-001	1.79-001	
CUM. MASS (GR/DNCF) < D50	4.35-001	4.25-001	4.20-001	4.02-001	3.95-001	3.77-001	3.59-001	3.26-001	2.68-001	
GEO. MEAN DIA. (MICRONS)	2.62+001	1.83+001	1.39+001	9.20+000	6.30+000	4.82+000	2.68+000	1.26+000	8.00-001	4.69-001
DN/DLOGD (MG/DNCH)	3.44-001	3.74+002	6.34+001	2.30+002	1.06+002	4.86+002	9.64+001	3.30+002	8.11+002	4.08+003
DN/DLOGD (NUMBER/DNCH)	3.67+004	1.17+008	4.49+007	5.65+008	8.09+008	8.30+009	9.54+009	3.15+011	3.02+012	7.53+013

APPENDIX D-2

CASCADE IMPACTOR DATA REDUCTION SYSTEM PRINTOUTS,
BAGHOUSE OUTLET

"COMPARE" output for all outlet impactor runs

DATA COMPARISON FOR 9 OUTLET RUNS BY GCA

TD. PT.	DM-BLDS	CUMULATIVE	CUM. % MASS < D50	MAX. < D50	AVG.	STD. DEV.	MIN.	MAX.
MICRON	CMG-PNOM	MM						
1 20.00	5.84E+00	7.65E+00	100.16	6.82	88.99	109.65		
2 15.00	3.43E+00	7.04E+00	91.91	7.37	79.56	100.54		
3 10.00	3.17E+00	6.49E+00	84.37	8.07	71.41	94.60		
4 5.00	3.38E+00	5.34E+00	68.58	10.26	55.50	85.44		
5 2.50	3.13E+00	4.37E+00	55.44	16.86	28.44	83.07		
6 1.25	3.25E+00	3.41E+00	43.46	19.80	9.64	70.99		
7 1.00	5.46E+00	3.97E+00	38.43	18.49	7.81	63.44		

THE RUN MARKED WITH AN * APPEARS TO CONTAIN OUTLIERS

TEST SITE	ALAM	ALAM	ALAM	ALAM	ALAM	ALAM	ALAM
TEST DATE	12781	12781	12681	12681	12681	12681	12681
RUN NUMBER	4	4	14	15	16	17	18
RUN DATE	12881	12881	12681	12681	12781	12781	12781
START TIME	810	1310	1325	1325	945	1200	1400
TOTAL MASS	4.412E+00	4.320E+00	8.139E+00	4.743E+00	1.861E+01	8.317E+00	4.876E+00

DM-BLDS IN STANDARD INTERVALS	CMG-PNOM						
1 20.00	7.10E+01	5.95E+00	7.04E+00	4.36E+00	1.21E+01	8.15E+00	3.76E+00
2 15.00	7.43E+01	4.05E+00	4.64E+00	1.04E+00	8.19E+00	5.32E+00	2.92E+00
3 10.00	2.45E+00	1.72E+00	2.22E+00	2.29E+00	4.86E+00	2.69E+00	1.54E+00
4 5.00	1.57E+00	3.71E+00	2.27E+00	8.34E-01	2.24E-01	9.66E-01	3.65E+00
5 2.50	2.44E+01	4.43E+00	2.84E+00	5.39E-01	2.94E+00	1.43E+00	3.90E+00
6 1.25	3.44E+00	4.11E+00	2.96E+00	4.53E-01	9.91E+00	2.42E+00	1.37E+00
7 1.00	6.21E+00	5.05E+00	5.79E+00	2.00E+00	1.55E+01	3.84E+00	4.10E-01

TEST SITE	ALAM	ALAM
TEST DATE	12681	12681
RUN NUMBER	19	20
RUN DATE	12681	12781
START TIME	815	1324
TOTAL MASS	1.001E+01	1.400E+01

DM-BLDS IN STANDARD INTERVALS	CMG-PNOM		
1 20.00	4.74E+00	6.18E+00	
2 15.00	5.50E+00	2.58E+00	
3 10.00	2.72E+00	2.91E+00	
4 5.00	6.99E+00	1.02E+01	
5 2.50	7.80E+00	2.09E+00	
6 1.25	3.62E+00	5.43E+00	
7 1.00	4.62E+00	5.43E+00	

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, ON DATE 12681, RUN NO. 14
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAHET,SELHA,ALABAMA
 RUN COMMENTS: 1-0-A

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .322 ACFM

IMPACTOR TEMPERATURE = 246.0 F (118.9 C)

SAMPLING DURATION = 192.00 MIN

IMPACTOR PRESSURE DROP = .162 IN. OF HG STACK TEMPERATURE = 246.0 F (118.9 C) STACK PRESSURE = 29.96 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 2.00

CALC. MASS LOADING = 2.6185-003 GR/ACF 3.5568-003 GR/DNCF 5.9920+000 MG/ACH 8.1392+000 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CH. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.
 D50 (MICRONS)
 MASS (MG)
 MG/DNCH/STAGE
 CUM. % OF MASS < D50
 CUM. MASS (MG/ACH) < D50
 CUM. MASS (MG/DNCH) < D50
 CUM. MASS (GR/ACF) < D50
 CUM. (GR/DNCF) < D50
 GEO. MEAN DIA. (MICRONS)
 DM/DLOGD (MG/DNCH)
 DN/DLOGD (NUMBER/DNCH)

S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	2	3	4	5	6	7	8	9
18.52	12.29	8.10	5.77	4.75	1.81	1.07	.74	.74/2.0
.21	1.10	.54	.17	.76	1.26	.55	1.45	4.45
1.63-001	8.53-001	4.19-001	1.32-001	5.90-001	9.78-001	4.27-001	1.13+000	3.45+000
97.46	84.15	77.62	75.56	66.36	51.12	44.46	26.92	
4.60+000	3.97+000	3.66+000	3.57+000	3.13+000	2.41+000	2.10+000	1.27+000	
6.25+000	5.40+000	4.98+000	4.85+000	4.26+000	3.28+000	2.85+000	1.73+000	
2.01-003	1.74-003	1.60-003	1.56-003	1.37-003	1.05-003	9.17-004	5.55-004	
2.73-003	2.36-003	2.18-003	2.12-003	1.86-003	1.43-003	1.25-003	7.54-004	
2.55+001	1.51+001	9.98+000	6.84+000	5.24+000	2.93+000	1.39+000	8.90-001	5.25-001
5.89-001	4.79+000	2.32+000	8.93-001	7.03+000	2.33+000	1.87+000	7.16+000	1.15+001
6.82+004	2.66+006	4.46+006	5.34+006	9.36+007	1.77+008	1.33+009	1.94+010	1.51+011

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, ON DATE 12681, RUN NO. 15
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAMET, SELMA, ALABAMA
 RUN COMMENTS: 1-0-B

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0750	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3908

IMPACTOR FLOWRATE = .333 ACFM

IMPACTOR TEMPERATURE = 246.0 F (118.9 C)

SAMPLING DURATION = 192.00 MIN

IMPACTOR PRESSURE DROP = .173 IN. OF HG STACK TEMPERATURE = 246.0 F (118.9 C)

STACK PRESSURE = 29.96 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 2.00

CALC. MASS LOADINGS = 1.5259-003 GR/ACF 2.0728-003 GR/DNCF 3.4919+000 MG/ACM 4.7432+000 MG/DNCF

4.7432+000 MG/DNCF

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	S1 1	S2 2	S3 3	S4 4	S5 5	S6 6	S7 7	S8 8	FILTER 9
D50 (MICRONS)	18.21	12.08	7.97	5.67	4.67	1.77	1.05	.73	.73/2.0
MASS (MG)	.00	.17	.61	.13	.33	.22	.00	.67	4.19
MG/DNCF/STAGE	7.50-004	1.28-001	4.58-001	9.75-002	2.48-001	1.65-001	7.50-004	5.03-001	3.14+000
CUM. % OF MASS	99.98	95.95	81.52	78.45	70.64	65.44	65.41	49.56	
CUM. MASS (MG/ACM) < D50	2.33+000	2.24+000	1.90+000	1.83+000	1.65+000	1.53+000	1.53+000	1.16+000	
CUM. MASS (MG/DNCF) < D50	3.17+000	3.04+000	2.59+000	2.49+000	2.24+000	2.08+000	2.07+000	1.57+000	
CUM. MASS (GR/ACF) < D50	1.02-003	9.79-004	8.32-004	8.00-004	7.21-004	6.68-004	6.67-004	5.06-004	
CUM. (GR/DNCF) < D50	1.39-003	1.33-003	1.13-003	1.09-003	9.79-004	9.07-004	9.07-004	6.87-004	
GEO. MEAN DIA. (MICRONS)	2.52+001	1.48+001	9.81+000	6.72+000	5.15+000	2.88+000	1.36+000	8.74-001	5.15-001
DN/DLOGD (MG/DNCF)	2.64-003	7.16-001	2.53+000	6.60-001	2.95+000	3.92-001	3.28-003	3.19+000	1.04+001
DN/DLOGD (NUMBER/DNCF)	3.14+002	4.19+005	5.12+006	4.15+006	4.14+007	3.14+007	2.47+006	9.14+009	1.46+011

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 16
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALAHET, SELMA, ALABAMA
 RUN COMMENTS: 2-0-A

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0030	.3809
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0750	.0000	.3808
5	264	.0570	.0000	.3808
6	264	.0350	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .484 ACFM

IMPACTOR TEMPERATURE = 248.0 F (120.0 C)

SAMPLING DURATION = 96.00 MIN

IMPACTOR PRESSURE DROP = .356 IN. OF HG STACK TEMPERATURE = 248.0 F (120.0 C) STACK PRESSURE = 29.91 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = .10

CALC. MASS LOADING = 6.0747-003 GR/ACF

1.3901+001 MG/ACM

1.8607+001 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE	STAGE INDEX NO.	D50 (MICRONS)	MASS (MG)	MG/DNCH/STAGE	CUM. % OF MASS	CUM. MASS (MG/ACM) < D50	CUM. MASS (MG/DNCH) < D50	CUM. MASS (GR/ACF) < D50	CUM. (GR/DNCH) < D50	GEO. MEAN DIA. (MICRONS)	DN/DLOGD (MG/DNCH)	DN/DLOGD (NUMBER/DNCH)
1	1	15.16	.11	1.12-001	5.09-001	1.38+000	2.85-001	4.83-001	4.83-001	4.83-001	4.83-001	4.83-001
		99.23	.50	84.32	86.27	84.32	84.32	80.97	80.97	80.97	80.97	80.97
		1.08+001	1.04+001	9.41+000	9.19+000	8.83+000	7.96+000	6.02+000	6.02+000	6.02+000	6.02+000	6.02+000
		1.45+001	1.40+001	1.26+001	1.23+001	1.18+001	1.07+001	8.06+000	8.06+000	8.06+000	8.06+000	8.06+000
		4.73-003	4.56-003	4.11-003	4.02-003	3.86-003	3.48-003	2.63-003	2.63-003	2.63-003	2.63-003	2.63-003
		6.33-003	6.11-003	5.50-003	5.38-003	5.16-003	4.66-003	3.52-003	3.52-003	3.52-003	3.52-003	3.52-003
		2.30+001	1.23+001	8.16+000	5.58+000	4.27+000	2.38+000	1.12+000	1.12+000	1.12+000	1.12+000	1.12+000
		3.08-001	2.85+000	7.63+000	1.92+000	5.80+000	2.73+000	1.12+001	1.12+001	1.12+001	1.12+001	1.12+001
		4.81+004	2.89+006	2.69+007	2.11+007	1.42+008	3.88+008	1.53+010	1.53+010	1.53+010	1.53+010	1.53+010

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE ALAM, ON DATE 12681, RUN NO. 17
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALABAMA, ALABAMA
 RUN COMMENTS: 2-0-B-2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0570	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .489 ACFM

IMPACTOR TEMPERATURE = 248.0 F (120.0 C)

SAMPLING DURATION = 96.00 MIN

IMPACTOR PRESSURE DROP = .373 IN. OF HG STACK TEMPERATURE = 248.0 F (120.0 C) STACK PRESSURE = 29.91 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = .10

CALC. MASS LOADING = 2.7154-003 GR/ACF 3.6346-003 GR/DNCF 6.2137+000 MG/ACM 8.3172+000 MG/DNCF

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE	STAGE INDEX NO.	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
D50 (MICRONS)		15.08	10.00	6.59	4.68	3.85	1.45	.85	.58	.58/2.0
MASS (HG)		1.30	.33	.73	.20	.34	.47	.61	1.22	3.06
HG/DNCF/STAGE		1.31+000	3.32-001	7.35-001	2.01-001	3.42-001	4.73-001	6.14-001	1.23+000	3.08+000
CUM. % OF MASS		80.68	75.78	64.93	61.96	56.91	49.93	40.86	22.73	
CUM. MASS (HG/ACM) < D50		4.08+000	3.84+000	3.29+000	3.14+000	2.88+000	2.53+000	2.07+000	1.15+000	
CUM. MASS (HG/DNCF) < D50		5.47+000	5.14+000	4.40+000	4.20+000	3.86+000	3.38+000	2.77+000	1.54+000	
CUM. MASS (GR/ACF) < D50		1.79-003	1.68-003	1.44-003	1.37-003	1.26-003	1.10-003	9.04-004	5.03-004	
CUM. (GR/DNCF) < D50		2.39-003	2.24-003	1.92-003	1.83-003	1.69-003	1.48-003	1.21-003	6.73-004	
GEO. MEAN DIA. (MICRONS)		2.30+001	1.23+001	8.11+000	5.55+000	4.25+000	2.36+000	1.11+000	7.03-001	4.12-001
DN/DLOGD (MG/DNCF)		3.58+000	1.86+000	4.05+000	1.36+000	4.06+000	1.11+000	2.64+000	7.51+000	1.02+001
DN/DLOGD (NUMBER/DNCF)		5.64+005	1.92+006	1.45+007	1.52+007	1.01+008	1.61+008	3.69+009	4.13+010	2.80+011

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 18
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALABAMA, SELMA, ALABAMA
 RUN COMMENTS: 3-0-B

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR OP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0750	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .243 ACFM

IMPACTOR TEMPERATURE = 227.0 F (108.3 C) SAMPLING DURATION = 192.00 MIN

IMPACTOR PRESSURE DROP = .095 IN. OF HG STACK TEMPERATURE = 227.0 F (108.3 C) STACK PRESSURE = 29.91 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.50

CALC. MASS LOADING = 1.6175-003 GR/ACF 2.1306-003 GR/DNCF 3.7013+000 MG/ACM 4.8755+000 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM³ MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	S1 1	S2 2	S3 3	S4 4	S5 5	S6 6	S7 7	S8 8	FILTER 9
D50 (MICRONS)	21.15	14.04	9.26	6.60	5.44	2.08	1.24	.87	.87/2.0
MASS (MG)	.40	.64	.31	.30	.18	1.66	.64	.08	.68
MG/DNCH/STAGE	3.99-001	6.38-001	3.09-001	2.99-001	1.79-001	1.66+000	6.38-001	7.98-002	6.78-001
CUM. % OF MASS	91.21	77.14	70.33	63.74	59.78	23.30	9.23	7.47	
CUM. MASS (MG/ACH) < D50	3.14+000	2.66+000	2.42+000	2.20+000	2.06+000	8.02-001	3.18-001	2.57-001	
CUM. MASS (MG/DNCH) < D50	4.14+000	3.50+000	3.19+000	2.89+000	2.71+000	1.06+000	4.19-001	3.39-001	
CUM. MASS (GR/ACF) < D50	1.37-003	1.16-003	1.06-003	9.59-004	9.00-004	3.51-004	1.39-004	1.12-004	
CUM. (GR/DNCF) < D50	1.81-003	1.53-003	1.39-003	1.26-003	1.19-003	4.62-004	1.83-004	1.48-004	
GEO. MEAN DIA. (MICRONS)	2.72+001	1.72+001	1.14+001	7.82+000	5.99+000	3.36+000	1.60+000	1.03+000	6.13-001
DM/DLOGD (MG/DNCH)	1.82+000	3.59+000	1.71+000	2.03+000	2.15+000	3.96+000	2.83+000	5.18-001	2.25+000
DN/DLOGD (NUMBER/DNCH)	1.73+005	1.34+006	2.20+006	8.11+006	1.90+007	1.99+008	1.31+009	8.92+008	1.87+010

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, CN DATE 12681, RUN NO. 19
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALANET, SELMA, ALABAMA
 RUN COMMENTS: 4-0-A

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0760	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0550	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .462 ACFM

IMPACTOR TEMPERATURE = 209.0 F (98.3 C)

SAMPLING DURATION = 192.00 MIN

IMPACTOR PRESSURE DROP = .352 IN. OF HG STACK TEMPERATURE = 209.0 F (98.3 C) STACK PRESSURE = 30.00 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.50

CALC. MASS LOADING = 3.4204-003 GR/ACF

4.3741-003 GR/DNCF

7.8270+000 MG/ACM

1.0010+001 MG/DNCFM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

D50 (MICRONS)	1	2	3	4	5	6	7	8	9
MASS (MG)	15.17	10.06	6.63	4.71	3.88	1.47	.86	.59	.59/2.0
MG/DNCFM/STAGE	.99	2.40	2.63	2.52	1.96	2.14	1.67	1.81	3.54
CUM. % OF MASS	5.04+001	1.22+000	1.34+000	1.28+000	9.98-001	1.09+000	8.50-001	9.22-001	1.80+000
CUM. MASS (MG/ACM) < D50	94.47	81.05	66.35	52.26	41.31	29.35	20.01	9.89	
CUM. MASS (MG/DNCFM) < D50	6.73+000	5.77+000	4.73+000	3.72+000	2.94+000	2.09+000	1.43+000	7.05-001	
CUM. MASS (GR/ACF) < D50	8.60+000	7.39+000	6.04+000	4.76+000	3.76+000	2.67+000	1.82+000	9.01-001	
CUM. (GR/DNCF) < D50	2.94-003	2.52-003	2.07-003	1.63-003	1.29-003	9.13-004	6.23-004	3.08-004	
GEO. MEAN DIA. (MICRONS)	3.76-003	3.23-003	2.64-003	2.08-003	1.64-003	1.17-003	7.97-004	3.94-004	
DN/DLOGD (MG/DNCF)	2.30+001	1.24+001	8.17+000	5.59+000	4.28+000	2.39+000	1.12+000	7.15-001	4.20-001
DN/DLOGD (NUMBER/DNCFM)	1.39+000	6.85+000	7.39+000	8.66+000	1.19+001	2.58+000	3.68+000	5.71+000	5.99+000
	2.17+005	6.94+006	2.59+007	9.48+007	2.89+008	3.62+008	4.95+009	2.98+010	1.54+011

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12681, RUN NO. 20
 TEST COMMENTS: IP TEST OF FERROSILICON FURNACE--ALANET, SELMA, ALABAMA
 RUN COMMENTS: 3-0-A

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1640 .0000 .3808
 2 264 .1250 .0000 .3808
 3 264 .0950 .0000 .3808
 4 264 .0760 .0000 .3808
 5 264 .0670 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .229 ACFM

IMPACTOR TEMPERATURE = 227.0 F (108.3 C)

SAMPLING DURATION = 96.00 MIN

IMPACTOR PRESSURE DROP = .084 IN. OF HG STACK TEMPERATURE = 227.0 F (108.3 C) STACK PRESSURE = 29.91 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.50

CALC. MASS LOADINGS = 4.6541-003 GR/ACF

6.1306-003 GR/DHCF

1.4029+001 MG/DNCFM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM. MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	S1	S2	S3	S4	S5	S6	S7	S8	S9	FILTER
D50 (MICRONS)	21.79	14.46	9.55	6.80	5.61	2.14	1.28	.90	.90	.90/2.0
MASS (MG)	.38	.29	.17	.33	.52	1.85	.53	.43	.43	2.13
MG/DHCF/STAGE	8.04-001	6.14-001	3.60-001	6.98-001	1.10+000	3.91+000	1.12+000	9.10-001	9.10-001	4.51+000
CUM. % OF MASS	93.17	87.96	84.91	78.98	69.63	36.39	26.86	19.14	19.14	
CUM. MASS (MG/ACH) < D50	8.33+000	7.86+000	7.59+000	7.06+000	6.22+000	3.25+000	2.40+000	1.71+000	1.71+000	
CUM. MASS (MG/DHCF) < D50	1.10+001	1.04+001	1.00+001	9.30+000	8.20+000	4.28+000	3.16+000	2.25+000	2.25+000	
CUM. MASS (GR/ACF) < D50	3.64-003	3.44-003	3.32-003	3.09-003	2.72-003	1.42-003	1.05-003	7.48-004	7.48-004	
CUM. (GR/DHCF) < D50	4.79-003	4.53-003	4.37-003	4.06-003	3.58-003	1.87-003	1.38-003	9.85-004	9.85-004	
GEO. MEAN DIA. (MICRONS)	2.76+001	1.78+001	1.18+001	8.06+000	6.18+000	3.47+000	1.65+000	1.07+000	1.07+000	6.34-001
DH/DLOGD (MG/DHCF)	3.91+000	3.45+000	1.99+000	4.74+000	1.32+001	9.37+000	4.97+000	5.92+000	5.92+000	1.50+001
DH/DLOGD (NUMBER/DNCFM)	3.54+005	1.18+006	2.35+006	1.73+007	1.07+008	4.29+008	2.10+009	9.25+009	9.25+009	1.12+011

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, CN DATE 12781, RUN NO. 3
 TEST COMMENTS: IP TEST FERROSILICON FCE DAY 2
 RUN COMMENTS: 4-O-A

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB

1	264	.1640	.0000	.3808
2	264	.1250	.0000	.3808
3	264	.0950	.0000	.3808
4	264	.0750	.0000	.3808
5	264	.0670	.0000	.3808
6	264	.0360	.1760	.3808
7	264	.0260	.2940	.3808
8	156	.0250	1.0000	.3808

IMPACTOR FLOWRATE = .459 ACFM

IMPACTOR TEMPERATURE = 209.0 F (98.3 C)

SAMPLING DURATION = 192.00 MIN

IMPACTOR PRESSURE DROP = .347 IN. OF HG STACK TEMPERATURE = 209.0 F (98.3 C) STACK PRESSURE = 30.00 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.60

CALC. MASS LOADING = 1.5077-003 GR/ACF 1.9301-003 GR/DNCF 3.4502+000 MG/ACM 4.4168+000 MG/DNCFM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

D50 (MICRONS)
 MASS (MG)
 MG/DNCFM/STAGE
 CUM. % OF MASS < D50
 CUM. MASS (MG/ACM) < D50
 CUM. MASS (MG/DNCFM) < D50
 CUM. MASS (GR/ACF) < D50
 CUM. (GR/DNCF) < D50
 GEO. MEAN DIA. (MICRONS)
 DM/DLOGD (MG/DNCFM)
 DN/DLOGD (NUMBER/DNCFM)

S1	S2	S3	S4	S5	S6	S7	S8	S9	FILTER
1	2	3	4	5	6	7	8	9	
15.21	10.09	6.65	4.73	3.90	1.47	.86	.60	.60/2.0	
.11	.29	1.65	1.29	.39	.21	1.61	2.19	.87	
5.64-002	1.49-001	8.46-001	6.62-001	2.00-001	1.08-001	8.26-001	1.12+000	4.46-001	
98.65	95.11	74.92	59.14	54.37	51.80	32.11	5.32		
3.23+000	3.12+000	2.45+000	1.94+000	1.78+000	1.70+000	1.05+000	1.74-001		
4.14+000	3.99+000	3.14+000	2.48+000	2.28+000	2.17+000	1.35+000	2.23-001		
1.41-003	1.36-003	1.07-003	8.47-004	7.78-004	7.42-004	4.60-004	7.62-005		
1.81-003	1.74-003	1.37-003	1.08-003	9.96-004	9.49-004	5.88-004	9.75-005		
2.31+001	1.24+001	8.19+000	5.61+000	4.29+000	2.59+000	1.13+000	7.18-001		
1.56-001	8.34-001	4.67+000	4.47+000	2.38+000	2.55-001	3.58+000	6.97+000		
2.42+004	8.37+005	1.62+007	4.84+007	5.75+007	3.55+007	4.76+009	3.60+010		

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 05/19/82 16:14:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE ALAM, ON DATE 12781, RUN NO. 4
 TEST COMMENTS: IP TEST FERROSILICON FCE DAY 2
 RUN COMMENTS: 5-0-B

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 7
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAH. CUMDP CALIB
 1 264 .1640 .0000 .3808
 2 264 .1250 .0000 .3808
 3 264 .0950 .0000 .3808
 4 264 .0760 .0000 .3808
 5 264 .0670 .0000 .3808
 6 264 .0360 .1760 .3808
 7 264 .0260 .2940 .3808
 8 156 .0250 1.0000 .3808

IMPACTOR FLOWRATE = .476 ACFM

IMPACTOR TEMPERATURE = 236.0 F (113.3 C)

SAMPLING DURATION = 192.00 MIN

IMPACTOR PRESSURE DROP = .359 IN. OF HG STACK TEMPERATURE = 236.0 F (113.3 C) STACK PRESSURE = 30.00 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = .30 CO = .10 N2 = 78.00 O2 = 21.00 H2O = 1.40

CALC. MASS LOADING = 3.0665-003 GR/ACF 4.0758-003 GR/DNCF 7.0171+000 MG/ACM 9.3269+000 MG/DNCFM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM.

MAX. PARTICLE DIAMETER = 35.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

IMPACTOR STAGE STAGE INDEX NO.	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	15.16	10.05	6.62	4.71	3.88	1.46	.86	.59	.59/2.0
MASS (MG)	1.08	.52	.97	.94	1.41	3.18	1.73	2.59	5.74
MG/DNCFM/STAGE	5.55-001	2.67-001	4.98-001	4.83-001	7.24-001	1.63+000	8.89-001	1.33+000	2.95+000
CUM. % OF MASS	92.94	89.54	83.19	77.04	67.82	47.02	35.71	18.77	
CUM. MASS (MG/ACM) < D50	5.49+000	5.29+000	4.92+000	4.55+000	4.01+000	2.78+000	2.11+000	1.11+000	
CUM. MASS (MG/DNCFM) < D50	7.30+000	7.03+000	6.53+000	6.05+000	5.33+000	3.69+000	2.80+000	1.47+000	
CUM. MASS (GR/ACF) < D50	2.40-003	2.31-003	2.15-003	1.99-003	1.75-003	1.21-003	9.22-004	4.85-004	
CUM. (GR/DNCF) < D50	3.19-003	3.07-003	2.85-003	2.64-003	2.33-003	1.61-003	1.23-003	6.44-004	
GEO. MEAN DIA. (MICRONS)	2.30+001	1.23+001	8.16+000	5.58+000	4.27+000	2.38+000	1.12+000	7.10-001	4.16-001
DM/DLOGD (MG/DNCFM)	1.53+000	1.50+000	2.75+000	3.26+000	8.60+000	3.85+000	3.83+000	8.18+000	9.79+000
DN/DLOGD (NUMBER/DNCFM)	2.39+005	1.52+006	9.68+006	3.58+007	2.11+008	5.46+008	5.23+009	4.37+010	2.59+011

APPENDIX E-1
CASCADE IMPACTOR FIELD DATA SHEETS

Plant <u>Alamet</u>	Time <u>1515</u>	Nozzle Dia. <u>3.5 B</u>
Location <u>Selma</u>	Run No. <u>1 IA 16"</u>	Avg. ΔP <u>2.3</u>
Operator <u>Fogden/Meserve</u>	Impactor Location <u>A, 16"</u>	Traverse Pt. _____
Date <u>1/26/81</u>	D.G.M. No. <u>V2</u>	Pb <u>30.02</u>
Andersen Imp No. <u>1 I</u>	D.G.M. Y _____	Static "Hg <u>-4.75/13.6</u>

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	870	871	872	873	894	875	896	877	B98	

[illegible]

Initial leak check 0.02

Final leak check n Done

Total H₂O Collected in Flask

Total H₂O Collected

$$T_s = 320$$
$$Q_c = 0.529$$
$$L_1 = 0.30\lambda$$
Si-Gel initial

Si-Gel final

Net _____

1-618-018

ANDERSEN IMPACTOR FIELD DATA

Plant Alant Time 1410 Nozzle Dia. 3.54
 Location Sub Run No. 1IB 16" Avg. ΔP 2.3
 Operator EPskm/Meserv Impactor Location INLET Traverse Pt. _____
 Date 1/26/91 D.G.M. No. V2 Pb 30.02
 Andersen Imp No. 2I D.G.M. Y 0.986 Static "Hg -4.75/13.6

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	886	887	888	889	890	891	892	893	894	

sub down
Siber up

B-100

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
867.205	0:00	0.25	64	64	1.55		
867.405	0:30	0.25	64	68	1.55		
867.580	1:00	0.25	64	68	1.55		
867.775	1:30	0.25	64	64	1.55		
867.966	2:00	0.25	64	64	1.55		

Initial leak check 0.01Final leak check n.p.p.c.Total H₂O Collected in Flask —Total H₂O Collected — $T_s = 320$ Si-Gel initial —Si-Gel final — $Q_c = 0.529$ Net — $C_c = 0.302$

ANDERSEN IMPACTOR FIELD DATA

Plant ALANET Time 9:20 Nozzle Dia. 3.0 0.1 mm ~~1~~
 Location SELMA Run No. 2-I-A90 Avg. ΔP 2.3 TS=320°
 Operator Hobbs/Voy Impactor Location Inlet A90 Traverse Pt. _____
 Date 1/27/81 D.G.M. No. V2 Pb. 29.91
 Andersen Imp No. 1 I D.G.M. Y _____ Static "Hg -4.75"

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	822	823	824	825	826	827	828	829	B-92	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
869.043	0	0.15	60	56	1.4		1
869.38	0:30	0.15	61	56	1.4		
869.42	1:00	0.15	61	56	1.4		
869.59	1:30	0.15	61	56	1.4		
869.74	2:00	0.15	61	56	1.4		
869.90	2:30	0.15	61	57	1.5		
870.07	3:00	0.15	61	57	1.5		
870.177	3:15	0.15	6			* End of run	✓

Initial leak check 0.001 ft³/min @ 5" Hg

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

91

• inserted nozzle for warm up @ ~9.02

ANDERSEN IMPACTOR FIELD DATA

Plant Alamogordo Time 9:52 Nozzle Dia. 3.5A
Location Selma Run No. 2-I-B-90 Avg. ΔP 2.3 ΔT_s = 320 °F
Operator WAY/HOBBS Impactor Location inlet-B-90 Traverse Pt. _____
Date 1/27/81 D.G.M. No. V2 Pb 29.91
Andersen Imp No. 2I D.G.M. Y _____ Static "Hg 4.75

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	806	807	808	809	810	811	812	813	814	

[illegible]

Initial leak check 0.016 ft³/min @ 5" Hg

Si-Gel initial

Final leak check _____

Si-Gel final

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Alamogordo Time 14:05 Nozzle Dia. 0.1 mm
 Location Selma Run No. 3I-B-16 Avg. ΔP 2.3 TS
 Operator Vay/Hall Impactor Location B-16 Traverse Pt. 16 B
 Date 1/27/81 D.G.M. No. V2 Pb 29.91
 Andersen Imp No. 1I D.G.M. Y Static "Hg - 4.5" H₂O

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.										

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
871.952	0	0.15	62	62	1.40		
872.10	0:30	0.15	62	62	1.50		
872.25	1:00	0.15	62	62	1.52		
872.40	1:30	0.15	62	62	1.52		

Initial leak check 0.018 ft³/min @ 5" HgSi-Gel initial Final leak check Si-Gel final Total H₂O Collected in Flask Net Total H₂O Collected

ANDERSEN IMPACTOR FIELD DATA

Plant Alamet Time 15:26 Nozzle Dia. 0.1 mm
 Location Selma Run No. 3I-A-16 Avg. ΔP 2.3 TS =
 Operator Vay/Hobb Impactor Location A-16 Traverse Pt. 16"
 Date 1/27/81 D.G.M. No. V2 Pb 29.91
 Andersen Imp No. 2I D.G.M. Y _____ Static "Hg -4.5" H₂O

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	974	975	976	977	978	979	980	981	B-111	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet	Orifice S.P. - "Hg	Impactor Temp	Traverse Point
872.741	0	0.15	Ran about 25 sec total!			
	0:30	0.15	Reversed flow			
	1:00	0.15	Ran another imp to cover			
	1:30	STOP				
			F.U. it run due to not starting stopwatch.			
			Spaces missing between 4th & 5th substrates - plugged holes			
			andient on #4 plate			

Initial leak check 0.01 "H₂O 5 $\pm$ min @ 5" Hg Si-Gel initial _____

Final leak check _____ Si-Gel final _____

Total H₂O Collected in Flask _____ Net _____

Total H₂O Collected _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	838	839	840	841	842	843	844	845	B-94	

Initial leak check	0.02 ft^3/min @ $5'' \text{ Hg}$	Si-Gel initial	_____
Final leak check	0.00	Si-Gel final	_____
Total H_2O Collected in Flask	_____	Net	_____
Total H_2O Collected	_____		

$T_s = 290^\circ\text{F}$

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	966	967	968	969	970	971	972	973	B-110	

[illegible]Si-Gel initial

Si-Gel final

Net _____

97

ANDERSEN IMPACTOR FIELD DATA

Plant ALAMET Time 1214 Nozzle Dia. 0.1 mm
 Location SELMA Run No. 5-I-B-2-90 Avg. ΔP TS-290 AP-23
 Operator EPSTEIN/HOOBS Impactor Location B-90" Traverse Pt. 90"
 Date 1/28/81 D.G.M. No. V2 Pb 30.00
 Andersen Imp No. 2E D.G.M. Y Static "Hg -4.75

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	998	999	000	001	002	003	004	005	B-114	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
875.220	0	0.15	-	-			
875.38	0:30	0.15	52	52	0.8		
875.53	1:00	0.15	53	57	0.8		
875.665	1:30	0.15	-	-	-		
					Began before tap hole was shut by ~ 2 min.		
					Preheated 7 min.		
					Repeat of earlier backwash r.		
					Last 2 filter out.		

Initial leak check 0.01 gm @ 5 "Hg.

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Almet Time 11343 Nozzle Dia. 0.1 mm
 Location Selma Run No. SI-B-96 Avg. ΔP 2.3
 Operator EPJm/Hobbs Impactor Location SI-B-16 Traverse Pt. B-96
 Date 1/28/41 D.G.M. No. V2 Pb 30.00
 Andersen Imp No. 11 D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	006	007	008	009	010	011	012	013	B-115	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
874.476	0.0	0.15 0.15	52	55	1.2		
874.620	30.0	0.15	52	55	1.25 1.25		
874.770	60.0 60.0	0.15	52	55	1.3		
874.910	90.0	0.15	52	55	1.3		

Initial leak check 0.005 50/min @ 5" Hg

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Alaret Time 1319 Nozzle Dia. 0.1 mm
 Location Selma Run No. SI-A-16 Avg. ΔP 2.3 290°F
 Operator Epstein/Hobbs Impactor Location met A, 16" Traverse Pt. 16"
 Date 1/28/81 D.G.M. No. V2 Pb 4. 30.00
 Andersen Imp No. 27 D.G.M. Y _____ Static "Hg -4.75

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	798	799	800	801	802	803	804	805	B-89	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
875.732	0	0.15	-	-	1.1	charging - light emission	
875.885	30.0	0.15	53	57	1.2		
876.030	60.0	0.15	53	57	1.3		
876.174	90.0	0.15	53	57	1.3		

Initial leak check 0.01 sec/min @ 5" HgSI-Gel initial -Final leak check -SI-Gel final -Total H₂O Collected in Flask -Net -Total H₂O Collected -

ANDERSEN IMPACTOR FIELD DATA

Plant	<u>Alamet</u>	Time	<u>1530 1602</u>	Nozzle Dia.	<u>0.1 mm</u>
Location	<u>Selma</u>	Run No.	<u>6I-B-46</u>	Avg. ΔP	<u>Ts = 290°F</u>
Operator	<u>Epstein / Hobbs</u>	Impactor Location	<u>6I B 46</u>	Traverse Pt.	<u>B-16"</u>
Date	<u>1/28/81</u>	D.G.M. No.	<u>V2</u>	Pb	<u>30.00</u>
Andersen Imp No.	<u>1I</u>	D.G.M. Y		Static "Hg	

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	790	791	792	793	794	795	796	797	B-88	

[illegible]

Initial leak check 0.005 ft^3/min @ 5" Hg

Si-Gel initial

Final leak check _____

Si-Gel final

Total H₂O Collected in Flask

Net

Total H₂O Collected

method 5 ended
~~after~~ before
end of our
run

ANDERSEN IMPACTOR FIELD DATA

Plant	Alabama	Time	14:26	Nozzle Dia.	0.1 mm
Location	Belma	Run No.	6IA16	Avg. ΔP	2.3 T. ≈ 290°K
Operator	egstein/Hobbs	Impactor Location	Inlet A, 16'	Traverse Pt.	16"
Date	1/29/81	D.G.M. No.	va	Pb	30.00
Andersen Imp No.	2I	D.G.M. Y		Static "Hg	-4.75

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	846	847	848	849	850	851	852	853	B-95	

[illegible]

Initial leak check Si-Gel initial

Final leak check SI-Gel final

Total H ₂ O Collected in Flask	Net
---	-----

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Alamet Time 13:25 Nozzle Dia. 2L
 Location Selma, Alabama Run No. 1-0-A Avg. ΔP 0002
 Operator Joe Vay Impactor Location OUT A Traverse Pt. Comp 7, 8
 Date 1/26/81 D.G.M. No. V.3 Pb 30.02
 Andersen Imp No. 48 OUT A D.G.M. Y + Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	918	919	920	921	922	923	924	925	B104	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
439.538	0	0.1	83	74	0.4	7	7
443.23	15	0.1	83	75	0.5	7	7
446.94	30	0.1	83	74	0.5	7	7
450.67	45	0.1	83	74	0.5	7	7
454.42	60	0.1	79	78	0.5	7	7
458.30	75.5	0.1	79	73	0.5	7	7
461.94	90	0.1	79	73	0.5	7	7
463.455	96	0.1	79	73	0.5	*stop 47	7
463.458	96	0.1	79	81	0.5	*stop 48	8
465.70	105	0.1	82	82	0.5		8
469.39	120	0.1	84	83	0.5		8
473.67	135	0.1	84	86	0.6		8
476.74	150	0.1	90	90	0.55		8
480.40	165	0.1	90	91	0.6		8
484.07	180	0.1	100	98	0.6		8
486.980	192	0.1	101	103	0.6	*stop	8

Initial leak check 0.000 cfm @ 5 inch HgSI-Gel initial End Time - 1712

SI-Gel final _____

Net _____

Total H₂O Collected in Flask _____Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant ALANET Time 13.25 → 17.10 Nozzle Dia. 1L
 Location Selma Run No. 103 Avg. ΔP .002
 Operator Hobbs Impactor Location OUTLET B Traverse Pt. Comp 1, 2
 Date 1/26/81 D.G.M. No. V4 Pb 30.02
 Andersen Imp No. 4601A D.G.M. Y Static "Hg

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	934	935	936	937	938	939	940	941	B-106	

13 1/2 min

W/ SEP BACK-UP FILTER

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter °F		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
375.587	30.0	0.1	86	86	0.45		1
380.500	46.0	0.1	89	89	0.48		↓
383.455	30.0	0.1	87	87	0.51		"
387.32	45.0	0.1	89	89	0.50		"
391.23	60.0	0.1	90	91	0.51		"
395.16	75.0	0.1	87	90	0.50		"
399.06	90.0	0.1	85	88	0.51		"
402.99	105.0	0.1	100	99	0.51		"
406.97	120.0	0.1	96	100	0.51		
411.49	137.1	0.1	101	103	0.51		
414.82	150.0	0.1	106	109	0.51		
418.77	165.0	0.1	108	112	0.49		
422.76	180.0	0.1	114	120	0.50		
425.97	192.0	0.1	120	124	0.50		

Initial leak check @ 5" Hg: pulled 0.004 cc³/min Si-Gel initial Final leak check Si-Gel final Total H₂O Collected in Flask Net Total H₂O Collected

ANDERSEN IMPACTOR FIELD DATA

Plant Alamet Time 12:00 20-B-II Nozzle Dia. 0.500
 Location Sdmp ALA Run No. 200 -AB Avg. ΔP 0.002
 Operator K. Meserle Impactor Location 12-outlet Traverse Pt. Comp 12
 Date 1-27-81 D.G.M. No. V3 Pb 29.91
 Andersen Imp No. 48 D.G.M. Y _____ Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	958	959	960	961	962	963	964	965	B-109	

w/o Sep Backup Filter

Dry Gas Meter Reading	Lapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
524.741	0	0.23	98	96	.7"		
529.942	13.45	0.23	99	95	.8" [stop due to shaker]		
530.580	15	0.23	99	95	.8"		
536.500	30	0.23	99	96	.9"		
540.076	39.5	0.23	99	96	.9" [stop - shaker]		
542.240	45	0.23	96	94	1.0		
548.100	60	0.23	92	90	1.0		
550.285	65.5	0.23	92	90	1.0 [stop - shaker]		
554.150	75	0.23	90	84	1.0		
559.400	90	0.23	90	84	1.0		
560.468	91.6	0.23	90	84	1.0 [stop - shaker]		
562.205	96						
"the End"							

Initial leak check 0.00A

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Alqmet Time 0950 Nozzle Dia. 0.500"
 Location Selma ALA Run No. 2-0-B Avg. ΔP 0.002
 Operator meane Impactor Location outlet Traverse Pt. 12 comp
1-27-81 D.G.M. No. V4 Pb 29.91
 Andersen Imp No. 4B D.G.M. Y Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	950	951	952	953	954	955	956	957	13-108	

w/o sep Backup Filter

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
426.213	0	0.23	98	96	4" Hg		
429.550	5	0.23	96	94	Stop at 8 min into Run due to shock		
432.020	10 15	0.23			5"		
434.500	20 21				(stop at 21 min due to VAC build up)		
	25				could not pull flow		
	30				Plugged @ 21 - probably in		
					flex hose since substrate looked		
					clean		

Initial leak check 005

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____ 106

* (stop the meter

1.2250 Arth 11-27-84
yes for 28.41, start up 1 min Arth
if stop

ANDERSEN IMPACTOR FIELD DATA

Plant Alamogordo Time 0945 Nozzle Dia. 1L
 Location Selma Run No. 20A Avg. ΔP 0.002
 Operator Epskin Impactor Location Unit #6 Traverse Pt. _____
 Date 1/27/81 D.G.M. No. V3 1517048 Pb 29.91
 Andersen Imp No. outlet A(4601A) D.G.M. Y _____ Static "Hg 4.5/13.6

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	014	015	016	017	018	019	020	021	B-116	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
487.038	0.0	0.23	98	98	0.8		
493.050	15.8	0.23	98	101	0.8		
498.655	30.0	0.23	97	102	0.9		
504.550	45.0	0.23	97	102	1.0		
510.460	60.0	0.23	99	105	1.0		
516.360	75.0	0.23	99	103	1.0		
522.270	90.0	0.23	101	105	1.0		
524.646	96.0	0.23	101	105	1.05		

Initial leak check 0.005 *stop train 1:22 after end of previous shaker cycle.* Si-Gel initial —
 Final leak check A None Si-Gel final —
 Total H₂O Collected in Flask — *start 3:20 after.* Net —
 Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant Alaret Time 1524 1324 Nozzle Dia. 1L
 Location 511 Run No. 3-0-11A Avg. ΔP 0.002
 Operator 1 Impactor Location outlet #11 Traverse Pt. _____
 Date 1/27/81 D.G.M. No. V4 2400014 Pb 27.11
 Andersen Imp No. 4601 A D.G.M. Y _____ Static "Hg 4.5/13.6

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	982	983	984	985	986	987	988	989	3112	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
510.562	0.0	0.047/0.05	78	74	0.28		
513.240	15.0	0.05	82	77	0.28		
516.000	30.0	0.05	86	82	0.28	COMP. #11	
518.750	45.0	0.05	86	84	0.30		
521.490	60.0	0.05	87	85	0.30		
524.205	75.0	0.05	89	87	0.29		
526.892	90	0.05	86	84	0.30		
527.961	96	0.05	85	83	0.30		
529.605	96.0	0.05	85	82	0.30	COMP. #4	
532.240	105.0	0.05	86	84	0.30		
534.920	120.0	0.05	88	85	0.30		
537.760	135.0	0.05	91	88	0.30		
540.355	150.0	0.05	87	87	0.30		
542.990	158.5	0.05	86	86	0.30		
545.215	190.0	0.05	82	82	0.32		
545.215	192.0	0.05	84	82	0.33		

Initial leak check 0.005 compartment #11 for 96 min Si-Gel initial _____
 Final leak check _____ compartment #4 for 96 min. Si-Gel final _____
 Total H₂O Collected in Flask _____ Net _____
 Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant ALAMET Time 1400 Nozzle Dia. 0.500
 Location Selma Ala Run No. 33-0 Avg. ΔP 0.002
 Operator Meserve Impactor Location only 5 Traverse Pt. COMP 5
 Date 1-27-81 D.G.M. No. V4 Pb 29.91
 Andersen Imp No. 4B D.G.M. Y Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	910	911	912	913	914	915	916	917	B-103	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
562.272	0	.05	92	90	0		
565.18	15	.05	90	88	0		
567.428	26.25	.05	90	88	stop - SHAKER		
568.10	30	.05	92	89	0		
570.90	45	.05	92	89	0		
572.337	52.4	.05	92	89	stop - SHAKER		
573.81	60	.05	94	90	0		
576.85	75	.05	94	90	0		
577.53	79	.05	94	90	stop - SHAKER		* sampled for 2 sec during shake
579.540	90	.05	94	90	0		
580.712	96	.05	94	90	0		
the end							

leak check 005

SI-Gel initial

leak check

SI-Gel final

Net H₂O Collected in Flask

Net

Net H₂O Collected

ANDERSEN IMPACTOR FIELD DATA

Plant Alamet Time 8:15 Nozzle Dia. _____
 Location Selma Run No. 4-0-A Avg. ΔP _____
 Operator Vay Impactor Location outlet 9 Traverse Pt. 9 + 3
 Date 1-28-81 D.G.M. No. V4 Pb _____
 Andersen Imp No. 4601 D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	830	831	832	833	834	835	836	837	893	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
545.240	0	0.21	60	56	0.65		9
550.72	15	0.21	60	57	0.7		9
556.30	30	0.21	60	58	0.8		9
561.82	45	0.21	62	60	0.8		9
567.41	60	0.21	64	62	0.8		9
572.98	75	0.21	64	64	0.8		9
578.55	90	0.21	65	64	0.8		9
580.769	96	0.21	65	64	0.8		9
580.769	0	0.21	68	64	0.8		3
586.64	16	0.21	72	70	0.8		3
591.79	30	0.21	74	73	0.8		3
597.31	45	0.21	78	74	0.8		3
602.80	60	0.21	82	78	0.8		3
608.30	75	0.21	82	80	0.8		3
613.79	90	0.21	86	82	0.8		3
615.969	96	0.21	86	82	0.8		3

Initial leak check 0.003 ft³ @ >5" Hg 1 min Si-Gel initial _____

Final leak check _____ Si-Gel final _____

Total H₂O Collected in Flask _____ Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant ALAMET Time 8:10 Nozzle Dia. 2 L
 Location SELMA ALA Run No. 4-0-B Avg. ΔP _____
 Operator K MESERVE Impactor Location Outlet-5 Traverse Pt. _____
 Date 1-28-81 D.G.M. No. V3 Pb _____
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	894	895	896	897	898	899	900	901	B101	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
581.696	0	.21	72	73	.7"		
587.290	15	.21	73	74	.8		
588.940	19.5	.21	73	74	[stop - SHAKER]		
593.20	30	.21	73	74	.8		
598.400	45	.21	73	74			
598.672	45.6	.21	73	74	[stop - SHAKER]		
604.08	60	.21	73	73	.8		
608.440	71.7	.21	73	73	[stop - SHAKER]		
609.34	75	.21	74	74	.8		
615.265	90	.21	74	74	.8		
617.487	96	.21	74	74	.8		
617.487	0	.21	74	72		stop Post 5	start Post 10
620.286	7.5	.21	74	72	.8	(stop - SHAKER)	
623.01	15	.21	74	72	.8		
628.490	30	.21	72	70	.9		
629.758	33.5	.21	72	70	.9	[stop - SHAKER]	

Initial leak check 0.004

SI-Gel initial _____

Final leak check _____

SI-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

1 min about 1/2 hr
 22 Sec then 1 min

ANDERSEN IMPACTOR FIELD DATA

ANDERSEN IMPACTOR FIELD DATA

Plant	ALAMET	Time		Nozzle Dia.	
Location	SELMA, Ala	Run No.	4A	Avg. ΔP	
Operator	KMESERUE	Impactor Location	Outlet 10	Traverse Pt.	
Date	1-28-81	D.G.M. No.	V3	Pb	
Andersen Imp No.		D.G.M. Y		Static "Hg	

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	894	895	896	897	898	899	900	901	8101	

[illegible]

Initial leak check	_____	Si-Gel initial	_____
Final leak check	_____	Si-Gel final	_____
Total H ₂ O Collected in Flask	_____	Net	_____
Total H ₂ O Collected	_____		

ANDERSEN IMPACTOR FIELD DATA

Plant LAMET Time 1:01 Nozzle Dia. 2L
 Location SELMA Ala. Run No. 5-0-0 Avg. ΔP _____
 Operator K. MESERVE Impactor Location 10 alt Traverse Pt. 10
 Date 1-28-81 D.G.M. No. V3 Pb 30.00
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	814	815	816	817	818	819	820	821	B-91	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
652.865	0	.21	74	74	0.7"		
658.38	15	.21	74	76	0.7"		
659.624	18.4	.21	74	76	(stop - SHAKER)		
663.900	30	0.21	74	76	0.8"		
669.225	44.6	0.21	70	74	0.8"	[stop - SHAKER]	
669.400	45	0.21	70	74	0.8"		
674.850	60	0.21	74	74	0.8"		
678.045	68.8	0.21	74	74	0.8"	(stop - SHAKER)	
680.300	75	0.21	74	74	0.8"		
685.700	90	0.21	74	74	0.8"		
686.774	92.8	0.21	74	74	0.8"	[stop - SHAKER]	
687.944	96	0.21	74	74	0.8"	stop port 10 211	
688.055	0	0.21	74	74	0.8"		
693.770	15	0.21	77	76	0.8"		
698.148	26.6	0.21	77	76	0.8"	[stop - SHAKER]	
699.440	30	0.21	77	76	0.8"		

Initial Leak check 0.005

Si-Gel initial _____

Leak check _____

Si-Gel final _____

20 Collected in Flask _____

Net _____

H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant ALAMET Time _____ Nozzle Dia. _____
Location SELMA Ala Run No. 5-0-11 Avg. ΔP _____
Operator KMESERVE Impactor Location auth 12 Traverse Pt. _____
Date 1-28-81 D.G.M. No. V3 Pb _____
Andersen Imp No. _____ D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	84	85	86	87	88	89	820	821	B-9	

[illegible]

Initial leak check _____

Si-Gel initial _____

Final leak check _____

Si-Gel final

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR ELD DATA

Plant Alumet Time 1400 Nozzle Dia. 1L
 Location Selma Run No. 5-0-A (3e9) Avg. ΔP 0.003
 Operator Vay Impactor Location #3⁸⁵ Traverse Pt. Comp 3⁸⁵
 Date 1/28/89 D.G.M. No. V4 Pb 30.00
 Andersen Imp No. 4601 D.G.M. Y Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	942	943	944	945	946	947	948	949	8-107	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
616.566	0	0.21	76	74	0.7		#3
622.09	15	0.21	82	78	0.8		#3
627.67	30	0.21	76	76	0.9		3
633.20	45	0.21	77	78	0.9		3
638.79	60	0.21	76	78	0.9		3
644.33	75	0.21	80	80	0.9		3
649.91	90	0.21	80	82	0.9		3
652.096	96	0.21	80	82	0.9		3
652.096	0	0.21	85	84	0.9		5
657.86	15	0.21	86	84	0.9		5
663.47	30	0.21	83	82	0.9		5
669.07	45	0.21	82	80	0.9		5
674.68	60	0.21	82	80	0.9		5
680.29	75	0.21	84	80	0.9		5
685.87	90	0.21	86	85	0.9		5
688.115	96	0.21	88	86	0.9		5

Initial leak check 0.014 #3 @ 5" Hg 1 min

SI-Gel initial _____

Final leak check _____

SI-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

(40)
ANDERSEN IMPACTOR FIELD DATA

Pg. 1 of _____

Plant Intitlake/Alumet Time 0840 1-B-0 Nozzle Dia. 2K
 Location OUTLET Run No. 1 OUT BLANK Avg. ΔP <.005
 Operator GRONBERG Impactor Location COMP#2 Traverse Pt. 5' in
 Date 1/24/81 D.G.M. No. V-3 Pb _____
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg +

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	862	863	864	865	866	867	868	869	B-97	

Dry Gas Meter Reading	(mm) Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
386.703	0 0 (0841)	0.100	50	44	1.0"	~260	#2 COMP
388.0	50	0.100	50	44	1.0	(guess)	
389.28	100	0.10	50	44	1.2		
390.565	150	0.10	50	44	1.2		
392.025	20.7	0.10	50	44	1.2		
393.8	27.7	0.10	50	48	1.3		
395.8	35.7	0.10	50	48	1.3		
399	48.8	0.10	50	50	1.3		
401.38	57.6	0.10	51	51	1.4		
404.15	68.7	0.10	50	52	1.4		
407.400	81.8	0.10	50	54	1.4		
413.01	104.5	0.10	50	56	1.4		
418.05	125.0	0.10	50	60	1.55		
424.83	151.5	0.10	50	58	1.60		
439.485	210.0	0.10	54	62	1.80	end @ 12:10	

Initial leak check 1/15/80 - 5" Hg - 0.002 ft³ JU. Si-Gel initial _____

~~Initial~~ leak check 1/24 42" Hg - 0.006 cm Si-Gel final _____

Total H₂O Collected in Flask _____ Net _____

Total H₂O Collected _____ 116

Note - Run during shaking cycle!

(151)
ANDERSEN IMPACTOR FIELD DATA

Plant Interlois / Alcon START Time 12:41 am Nozzle Dia. 0.30
 Location INLET Run No. 1 B-7 VIS Avg. ΔP 2.35
 Operator T. E. Fisher Impactor Location B-7 Traverse Pt. ?
 Date 1/23/81 D.G.M. No. 250007 Pb 30.11
 Andersen Imp No. 1 D.G.M. Y C Static "Hg -4.75

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	704	203	204	201	200	199	198	205	B139	

UNWEIGHED SUBSTRATES

Blank B/1

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
856.502	0:00	0.133 <i>hand</i>	38	46	1.95		
857.105	2:00		38.5	47	2.00		
857.647	4:00		38.5	47.5	2.00		
858.285	6:00		38.5	47.5	2.05		
858.895	8:00		39	47	2.4		
859.490	10:00		39	47	2.75		
860.045	12:00		39	47	2.2		
860.715	14:00		39	47	3.65		
861.335	16:00		39	47	4.0		
861.950	18:00		39	47	4.3		
862.580	20:00		39	47	4.9		
863.153	22:00		39	47	5.0 +		
	24:00		EQUIPPED w/ CYCLONE PRESS				
	26:00		Recovery Note - Overload last 4 stages visible				
	28:00		load - much overload on last 2 high towers				
	30:00						

Initial leak check 0.01Si-Gel initial XFinal leak check NONESi-Gel final XTotal H₂O Collected in Flask XNet XTotal H₂O Collected X

ANDERSEN IMPACTOR FIELD DATA

Plant Alaret Time 2:45 1-B-I Nozzle Dia. 0.374 (G-3K)
 Location Selma Ala Run No. Inlet blank #1 Avg. ΔP 2.35
 Operator T Eyster Impactor Location inlet Traverse Pt. -
 Date 1/23/81 D.G.M. No. 2800017 Pb 30.13
 Andersen Imp No. #2 D.G.M. Y Static "Hg -4.75 H₂O

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	878	879	880	881	882	883	884	885	B-99	

Pre weighed. w/ 2 unweighed prefilters

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
863.533	0	0.133	42	48	4.4		
864.394	5	0.018	42	48	4.35		
864.832	10	0.015	42	48	4.35		
865.290	15	0.018	42	48	4.6		
865.732	20	0.014	42	48	4.9		
866.215	25	0.011	42	48	5.0		
866.349	30	0.010	42	48	5.01		
	35	L ?? is it really .01 or is it 0.1					
	40	S _F = 2.8 15 c/s					
	45	Time = 28 min, 5 sec					
	50	DIT = .031					
	55	4.132/60 min = .07 cfm. meter					
	60	? DIT = 0.031 = 4 cfm					
		DIT = 0.75 cfm					

Initial leak check 1/16 - @ 5" Hg: pulled 0.0015 $\frac{ft^3}{min}$ SI-Gel initial ---
 Final leak check N/A SI-Gel final ---
 Total H₂O Collected in Flask --- Net ---
 Total H₂O Collected ---

after shut off heard particulate in duct

ANDERSEN IMPACTOR FIELD DATA

Plant Indulato / Reunet Time ^{start} 0905 Nozzle Dia. 810.0
 Location Selma Run No. loading V15 Avg. ΔP 0.00
 Operator T Epstein Impactor Location outlet 4 Traverse Pt. CMP # 4
 Date 1/24/91 D.G.M. No. V4 V-4 Pb _____
 Andersen Imp No. 5 / unweighed D.G.M. Y _____ Static "Hg See data sheet

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	190	191	192	193	194	195	196	197	198	

1/24/91

 EQUIPPED w/ CYCLONE PRECUTTER Blank 8/31

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
329.040	0	0.10	60	57	0.4		
329.425	5.0	0.10	62	58	0.4		
330.635	10.0	0.10	63	59	0.4		
331.920	15.0	0.10	65	61	0.4		
334.455	25.2	0.10	66	64	0.4		
335.58	30.0	0.10	66	66	0.4		
337.97	40.0	0.10	68	69	0.45		
345.765	71.8	0.10	61	74	0.45		
349.530	87.6 87.6	0.10	76	79	0.45		
352.73	100.0	0.10	72	78	0.45		
358.6	124.0	0.10	68	72	0.47	11:11 am	
373.1	182.2	0.10	77	81	0.48	12:10	
375.515	192.0	0.10	76	81	0.48	end	
Recovery notes - perfect loading - grey white - slightly heavy, cut back to 120-150 mm. On 1-5, 67 heavy all of a sudden. None on Back-up.							

 Initial leak check 0.17

 Si-Gel initial -

 Final leak check -

 Si-Gel final -

 Total H₂O Collected in Flask -

 Net -

 Total H₂O Collected -

APPENDIX E-2

VISIBLE EMISSION OBSERVER DATA SHEETS

Date 1/26/81Company Name ALAMETObserver Sandra BeatonLocation Selma, AL.

U.S. EPA Region _____

Source: 3 stacks left end
of Cast houseSource Height: 175 ftDistance from Source: 200 ftDirection from Source: SWind Direction: West Speed: 0-5 mph

Background(s) Used: (1) _____

(2) _____ (3) _____

Colors of Background(s): (1) _____

(2) _____ (3) _____

Color of Emissions: (1) _____


(2) _____ (3) _____

Ambient Temperature: 70 °FRelative Humidity: <50% ☒ >50% ☐Reading Conditions: EX ☒ GD ☐ FR ☐ PR ☐

Comments: (Include Contacts)

partly cloudyObservation Point: ON GROUNDSignature: Sandra BeatonDate Last Certified: 10/28/80

Show: Sun, Wind, and North Arrow





COMPANY: ALAMET
LOCATION: Selma, AL

OBSERVER: S. Beaton 2/7
DATE: 1/26/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
0							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14	0	0	0	0	SHOOTING TAPHOLE		
15	0	0	0	0	No. 2. END		
16	0	0	0	0			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	0	0	0	0			
31	0	0	0	0			
32	0	0	0	0			
33	0	0	0	0			
34	0	0	0	0			
35	0	0	0	0			
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	0	0			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	0	0	0	0			
47	0	0	0	0			
48	0	0	0	0			
49	0	0	0	0			
50	0	0	0	0			
51	0	0	0	0			
52	0	0	0	0			
53	0	0	0	0			
54	0	0	0	0			
55	0	0	0	0			
56	0	0	0	0			
57	0	0	0	0			
58	0	0	0	0			
59	0	0	0	0			

COMMENTS:

- a) See legend for abbreviated words.
b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.
c) Color of emissions: (B) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.



COMPANY:

ALAMET

LOCATION:

Selma, AL

OBSERVER:

S. Beaton

3/4

DATE:

1/26/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
15	0	0	0	0			
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	0			
6	0	0	0	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	0	0	0			
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	0	0	0	0			
31	0	0	0	0			
32	0	0	0	0			
33	0	0	0	0			
34	0	0	0	0			
35	0	0	0	0			
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	0	0			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	0	0	0	0			
47	0	0	0	0			
48	0	0	0	0			
49	0	0	0	0			
50	0	0	0	0			
51	0	0	0	0			
52	0	0	0	0			
53	0	0	0	0			
54	0	0	0	0			
55	0	0	0	0			
56	0	0	0	0			
57	0	0	0	0			
58	0	0	0	0			
59	0	0	0	0			

SHOOTING TAP HOSE
No 1

COMMENTS: AT 15:50 moved 30 ft to the west.

partly cloudy

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (B) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.



COMPANY: ALAMET
LOCATION: Selma, AL

OBSERVER: S. Beaton 414
DATE: 1/26/81

SAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
16	0	0	0	0			
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			GRAY
5	0	5	5	5	SHOOTING	TAPHOLE	
6	5	0	0	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	0	0	0			
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							

Time (M)	0	15	30	45	Proc.	Loca.	Color
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							

COMMENTS:

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.



Technology Division
213 Burlington Road
Bedford, Massachusetts 01730
(617) 275-5444

VISIBLE EMISSION OBSERVATION FORM

Page 1 of 5

Date 1/22/81
Observer Sandra Braton
U.S. EPA Region

Company Name ALANET
Location Selma, AL

Source: BAGHOUSE ROOF MONITOR


Source Height: 750 ft
Distance from Source: 2500 ft
Direction from Source: SSW
Wind Direction: Variable Speed: 0-5 mph
Background(s) Used: (1) Roof Monitor
(2) (3)
Colors of Background(s): (1) GRAY
(2) (3)
Color of Emissions: (1) White
(2) (3)
Ambient Temperature: 65 °F
Relative Humidity: <50% ☒ >50% ☐
Reading Conditions: EX ☐ GD ☒ FR ☐ PR ☐

Comments: (Include Contacts)
mostly cloudy, reading
against a white sky.

Observation Point: on ground in
front of a parking lot.

Signature: Sandra Braton
Date Last Certified: 10/28/81

Show: Sun, Wind, and North Arrow



COMPANY: ALAMITLOCATION: Silva, ALOBSERVER: S. ButlerDATE: 1/27/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
9	0						
	1						
	2						
	3						
	4						
	5						
	6						
	7						
	8						
	9						
	10						
	11						
	12						
	13						
	14						
	15						
	16						
	17						
	18						
	19						
	20						
	21						
	22						
	23						
	24						
	25						
	26						
	27						
	28						
	29						

Time (M)	0	15	30	45	Proc.	Loca.	Color
	30						
	31						
	32						
	33						
	34						
	35						
	36						
	37						
	38						
	39						
	40						
	41						
	42						
	43						
	44						
	45						
	46						
	47						
	48						
	49						
9	50	0	0	0	0		
	51	0	0	0	0		
	52	0	0	0	0		
	53	0	0	0	0		
	54	0	0	0	0		
	55	0	0	0	0		
	56	0	0	0	0		
	57	0	0	0	0		
	58	0	0	0	0		
	59	0	0	0	0		

COMMENTS: _____

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

COMPANY: ALPINELOCATION: Spring Hill

CAST:

OBSERVER: Sandra GatorDATE: 1/27/81

Time (M)	0	15	30	45	Proc.	Loca.	Color
10	0	0	0	0			
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	0			
6	0	0	0	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	0	0	0			
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	X	int	from Siz106	
20	X	X	X	X		Station	
21	X	X	X	X			
22	X	X	X	X			
23	X	X	X	X			
24	X	X	X	0			
25	0	0	0	X			
26	X	X	X	X			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	X	X	X	X			
31	X	X	X	X			
32	X	X	X	X			
33	X	X	X	0			
34	0	0	0	0			
35	0	0	0	0			
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	X	X			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	0	0			
45	X	X	X	X			
46	X	X	X	X			
47	X	X	X	X			
48	0	0	0	0			
49	0	0	0	0			
50	0	0	0	0			
51	0	0	0	0			
52	0	0	X	X			
53	X	X	X	X			
54	X	X	X	X			
55	X	X	X	X			
56	X	X	X	X			
57	0	0	0	0			
58	0	0	0	0			
59	0	0	0	0			

COMMENTS: 10:19 WIND FROM SE, 10:28 WIND FROM SW
10:30 WIND FROM SE.

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

COMPANY: ALH 117
 LOCATION: SE Pine, AK
 EAST:

OBSERVER: S. Beaton 475
 DATE: 1/27/81

Time (M)	0	15	30	45	Proc.	Loca.	Color
11	0	0	0	0			
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	0			
6	0	0	0	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	0	0	0			
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	5	5	5	5		White	Far right comp
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	0	0	0	0			
31	0	0	0	0			
32	0	0	0	0			
33	0	0	0	0			
34	0	0	0	0			
35	0	0	0	0			
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	0	0			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	0	0	0	0			
47	0	0	0	0			
48	0	0	0	0			
49	0	0	0	0			
50	0	0	0	0			
51	0	0	0	0			
52	0	0	0	0			
53	0	0	0	0			
54	0	0	0	0			
55	0	0	0	0			
56	5	5	0	0			Far right comp White
57	0	0	0	0			
58	0	0	0	5			
59	5	5	5	5			Far right White

COMMENTS:

Compact. sent

- a) See legend for abbreviated words.
 b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.
 c) Color of emissions: (B) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

COMPANY:

ALPHEE

LOCATION:

Spring, FL

OBSERVER:

S. Benton

DATE:

4/27/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
0	5	5	0	0			
1	0	0	0	0			
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							

Time (M)	0	15	30	45	Proc.	Loca.	Color
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							

COMMENTS:

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

Date 1/28/81

Company Name ALAMET

Observer Sandra Beaton

Location Selma, AL

U.S. LPA Region

Source:

Source: CAST HOUSE
3 Stacks for No. 2 FCE.

Source Height: 200 ft

Distance from Source: $\Delta 500$ ~~W 5 IN~~ ft

Direction from Source: WSW

Wind Direction: *NN* Speed: *0-5* mph

Background(s) Used: (1) Sky

(2) (3)

Colors of Background(s): (1) Blue

(2) (3)

Color of Emissions: (1) light brown-red.

(2) (3)

Ambient Temperature: 65 of

Relative Humidity: < 50% ☒ > 50% ☐

Reading Conditions: EX ☒ GD ☐ FR ☐ PR ☐

Comments: (Include Contacts)


Observation Point: on ground

Signature: Sandra A. Beatson

Date Last Certified: 10/28/80

Show: Sun, Wind, and ~~North~~ Arrow

← 3 stacks



130

16:00



COMPANY: ALAMET
LOCATION: Selma, AL

OBSERVER: Sandra Beaton
DATE: 1/28/81

EAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
0							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			SHOOTING TAP HOLE
25	0	0	20	50			2 far streak H. brown
26	60	75	100	100	①		lite Red.
27	100	100	100	100			
28	100	100	100	100			
29	100	100	75	75			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	75	75	75	100			
31	100	100	100	100			
32	100	100	100	70			
33	50	50	50	40			
34	30	25	25	50	(2)		
35	50	30	30	25			
36	25	25	25	25			
37	25	25	25	35			
38	40	30	35	25			
39	25	25	25	15			
40	20	15	15	25			
41	20	20	25	25			
42	25	25	20	20			
43	15	15	10	20			
44	20	15	15	20			
45	10	10	10	10			
46	5	5	5	5			
47	5	5	5	5			
48	5	5	5	5			
49	5	5	5	5			
50	5	5	25	20			
51	15	15	15	10			
52	15	10	10	10			
53	10	10	10	15			
54	10	10	10	5			
55	5	5	5	5			
56	5	5	5	5			
57	5	5	0	0			
58	0	0	0	0			
59	0	0	0	0			

COMMENTS: ① plume dispersing at about 2 100 ft.

(2) Heavy white emissions escaping from the bottom floor of the Bldg near the FCC No. 2 tapping side. It was verified that the floor fan was turned on about 4:30.

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown, (R) Red, (O) Orange, (W) White, (G) Gray.



COMPANY: ALAMET
LOCATION: SELMA, AL.

OBSERVER: S. Beaton 1-7/5
DATE: 1/28/81

CAS: 1

Time (M)	0	15	30	45	Proc.	Loca.	Color
17	0	0	0	0			
1	0	5	0	0			
2	5	0	0	0			
3	0	0	0	0			
4	0	5	0	0			
5	0	0	0	0			
6	0	0	0	0			
7	0	0	0	0			
8	0	5	5	5	Plugging		
9	0	0	0	0			
10	0	0			END PLUGGING		
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							

Time (M)	0	15	30	45	Proc.	Loca.	Color
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							

COMMENTS:

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

APPENDIX E-3
PROCESS OBSERVER DATA SHEETS

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Interlake Inc. Alameda, Selma, AL
 EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER: S. Beaton
 DATE: 1/26/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
8:46	Charging	V HE		Tapping in progress - emissions heavier than usual.
				Tapping emissions come up from below and most are sucked into the hood.
8:49	smelting			
9:02	Stoking			
9:07:31				very high flames
9:09:27	end Stoking			
	→ continued			
9:10	→ tapping			whole floor has cleared up.
			100%	during stoking.
9:12	end of Stoking			
9:13:40	Charging			1 bucket dumped in ≈ 6 sec.

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
Interlake Inc. Alameda, Selma, AL
EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER: S. Beaton
DATE: 1/28/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
9:14:28	Charged 1 Bucket	No real increase	100%	each charge only takes a couple seconds.
9:15:10	" "	"	100%	
9:15:55	" "	"		
9:16:50	" "	"		
9:17:48	" "	"		
9:18:40	" "	"	100%	
9:19:30	" "	"		
9:20:25	" "	"		
9:21:05	" "	"		
9:42:40			80%	heavy surge of emissions escaped charge is burning on floor
9:44:20	Stoking	heavier than normal	80%	Capture at one section of furnace.

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
Interlake Inc. Alameda, Selma, AL
EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER: *S. Beaton*
DATE: *1/28/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
9:17	END STOKING	very turbulent flames	99%	
9:49	STOKING		99%	
9:50	stoker spill charge on floor	HBC Burst	0%	only lasted for a couple seconds.
9:52	END STOKING		100%	
9:53	Charging		100%	1794 H No. blocks charged.
10:01	end charging		100%	
10:02	Stoking	Very turbulent flames	100%	
10:03	Silicon flame	very bright white	100%	lasted 30 secs.
10:04	END STOKING	died down	100%	
10:10	Smelting	H smoke left side of fee		
10:15	stoking	left side of fee		where there were heaviest emission.
		Very high flames	100%	

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Interlake Inc. Alameda, Selma, AL
 EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER: S. Beaton
 DATE: 1/28/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
10:18	END STOKING		100	
10:19	STOKING RIGHT SIDE		100	
10:20	END STOKING			ALSO SHOOTING THE TAPHOLE No. 2.
10:20	CHARGING	VHE in whole fce. area		TAPPING EMISSIONS FLOWING UP THE GRATES, AND OVER THE RAILINGS.
		from TAPPING.		
		Smoke so thick can't see through it.		
		emissions coming up the side of fce. are sucked in.		
		there is a general flow of emissions to the fce.		
10:25	UPON EXITING THE BLDG.	I glanced at the stacks on the No. 2 Fce. and VE's were 100% (NOT IN METHOD 9 POSITION)		
		FAN IS NOT ON.		

LE = Light emissions; 5 to 25 percent opacity
 ME = Moderate emissions; 30 to 60 percent opacity
 HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
Interlake Inc. Alameda, Delma, AL
EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER: Sandra Beaton
DATE: 1/28/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
11:29	Stoking in progress			
11:31	Smelting	Smooth operation	100	
11:36	"	Starting to flare up on backside		
11:43	Stoking		100	~ 1.0 minute duration.
11:44	Smelting			
11:52	charging	heavier flames + emissions	100%	"
12:00	cleaning floor			appears to be using an air blower.
12:06	Finished cleaning.			directs dust into furnace.
	Smelting			
12:12	we're burning the slag from the taphole - LE			
12:16	Smelting	heavier than usual		
12:17:40		HE	80%-90%	Some mix was shot out of fee. Stoker said the fee. just broke open.

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
Interlake Inc. Alameda, Selma, AL
EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER:

DATE:

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
12:20	SHOOTING TAPHOLE	VVHE	80-90	emissions from tapping come up through gratings & along side furnace.
12:21	Stoking			~ 1.0 min.
12:23	Charging			Charging where he just stoked. MUST HAVE FAN ON TAPPING EMISSIONS Because the cast house is not bad.
12:20				
				Operator opened bypass stack to the baghouse. at 12:20 due to some problem in BH. No. 1.
12:30 -		emissions increasing throughout cast house floor.		
		BREAK		
13:15	charging in progress			
13:19	charging	somewhat heavier than normal	100%	emissions heavier than during smelting. Some mix shot from fce.
13:21	stoking	increased emissions		
13:23	charging			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Interlake Inc. Alameda, AL
 EPA CONTRACT No. 68-02-3157, Technical Directive 008

OBSERVER: GRONBERG
 DATE: 1/28/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
1420	Shedding	heavy	~	down stairs
1427	Tapping	heavy	med	100% - Smoke in op floor area VISIB = 25' Start
1430	Stoking	Started	testing done	1433 Stopped
1433	Charging	Started 1, (only 2)		1434

LE = Light emissions; 5 to 25 percent opacity
 ME = Moderate emissions; 30 to 60 percent opacity
 HE = Heavy emissions; 65 to 100 percent opacity