

Prepared for
U.S. Environmental Protection Agency

EPA Contract No. 68-02-2687

Technical Directive 017

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

FERROALLOY FURNACE EMISSION
FACTOR DEVELOPMENT
FOOTE MINERAL COMPANY, GRAHAM,
WEST VIRGINIA

Final Report

October 1983

Prepared by
Stephen Gronberg

GCA CORPORATION
GCA/TECHNOLOGY DIVISION
Bedford, Massachusetts

CONTENTS

Figures	iii
Tables	iv
1 Introduction	1
2 Summary of Results and Conclusions	2
3 Process Description.	7
4 Sampling and Analysis Procedures	9
Introduction.	9
Presampling Preparations.	9
Cascade Impactor Sampling	11
Dual Cyclone Sampling	13
Andersen Impactor Sample Analysis	15
Dual Cyclone Sample Analysis.	16
Process Observations.	16
Sampling and Analysis Quality Assurance	17
5 Test Results	18
Introduction.	18
Total Particulate Results	18
Impactor Particle Sizing Results.	24
Dual Cyclone Sampler Results.	27
Size-Specific Particulate Emission Factors.	32
Visible Emissions Data.	35
Furnace Operations Data	35
Appendices	
A Sample Train Calibrations.	42
B-1 Example Calculations Andersen Cascade Impactor	60
B-2 Example Calculations Dual Cyclone Samplers	65
C Total Particulate Example Calculations (By RTI).	67
D-1 Cascade Impactor Data Reduction System Printouts, Baghouse Inlet.	74
D-2 Cascade Impactor Data Reduction System Printouts, Baghouse Outlet	92
E-1 Cascade Impactor Field Data Sheets	102
E-2 Visible Emission Observer Field Data Sheets.	133
E-3 Process Observer Field Data Sheets	142
E-4 Dual Cyclone Sampler Field Data Sheets	163
E-5 Gravimetric Analysis Data Summary Sheets	168

FIGURES

<u>Number</u>		<u>Page</u>
1	Average particle size distribution, uncontrolled ferrosilicon furnace emissions (baghouse inlet), Foote Mineral Company, Graham, West Virginia	4
2	Average particle size distribution, controlled ferrosilicon furnace emissions (baghouse outlet), Foote Mineral Company, Graham, West Virginia	5
3	Process schematic, Foote Mineral Company, Graham, West Virginia	8
4	Sampling facility schematic, Foote Mineral Company, Graham, West Virginia.	10
5	Andersen sampling train.	12
6	Schematic drawing of the dual cyclone sampler.	14
7	Average particle size distribution, uncontrolled ferrosilicon furnace emissions (baghouse inlet), Foote Mineral Company, Graham, West Virginia	25
8	Average particle size distribution, controlled ferrosilicon furnace emissions (baghouse outlet), Foote Mineral Company, Graham, West Virginia	26
9	Average change in concentration per particle size (all runs), Foote Mineral Company, Graham, West Virginia	28
10	Baghouse efficiency by particle size, Foote Mineral Company, Graham, West Virginia	29
11	Comparison of dual cyclone and cascade impactor results, Foote Mineral Company, Graham, West Virginia	33

TABLES

<u>Number</u>		<u>Page</u>
1	Summary of Total Particulate and Particle Size Distribution Test Results, Foote Mineral Company, Graham, West Virginia . .	3
2	Baghouse Inlet Level 2 Sampling Data, Foote Mineral Company, Graham, West Virginia	19
3	Baghouse Outlet Level 2 Sampling Data, Foote Mineral Company, Graham, West Virginia	20
4	Total Particulate Test Results (By RTI), Baghouse Inlet Sampling Location, Foote Mineral Company, Graham, West Virginia	21
5	Total Particulate Test Results (By RTI), Baghouse Outlet Sampling Location, Foote Mineral Company, Graham, West Virginia	22
6	Baghouse Particulate Removal Efficiencies, Foote Mineral Company, Graham, West Virginia	23
7	Dual Cyclone Sampler Results, Foote Mineral Company, Graham, West Virginia	30
8	Size Specific Emission Factors, Foote Mineral Company, Graham, West Virginia	31
9	Summary of Visible Emissions Observations, Foote Mineral Company, Graham, West Virginia	34
10	Charge Composition and Weights, Foote Mineral Company, Graham, West Virginia	36
11	Tap Weight and Alloy Analysis, Foote Mineral Company, Graham, West Virginia.	37
12	Tap Weight and Alloy Analysis, Foote Mineral Company, Graham, West Virginia	38

TABLES

<u>Number</u>		<u>Page</u>
13	Baghouse Operating Data, Foote Mineral Company, Graham, West Virginia	38
14	Baghouse Control System Design Parameters, Foote Mineral Company, Graham, West Virginia	39

SECTION 1

INTRODUCTION

The purpose of this program was to establish size specific particulate emission factors for the ferrosilicon furnace at Foote Mineral Company, Graham, West Virginia. Furnace No. 2 at Foote is an open submerged electric arc furnace rated at 35 megawatts (MW). The furnace was producing 50 percent grade ferrosilicon which contained an average of 47 percent silicon alloy during the March 1981 test program. Total particulate concentration and particle size distribution of emissions captured by the canopy hood evacuation system were measured before and after the baghouse using modified EPA Method 1-5 procedures and Andersen cascade impactors. The dual cyclone sampler developed by Southern Research Institute was also used at the inlet sampling location.

Entropy Environmentalists conducted the total particulate testing under subcontract to Research Triangle Institute (RTI) as part of a Level 2 Environmental Assessment of emissions of organic species from various ferroalloy furnaces. This Level 2 characterization of organic species utilized EPA Method 1-5 procedures modified to include an absorbent trap (XAD-2) between the third and fourth impingers. GCA/Technology Division conducted particle size distribution tests simultaneous with the total particulate (Level 2) tests by Entropy. In addition, GCA provided a process observer to document relevant furnace operations and cycle times, to assess the capture efficiency of the canopy hood control system and to ensure that testing was performed only during normal furnace operations. This observer also performed EPA Method 9 visible emission observations of the furnace building roof monitor and the baghouse outlet for at least one tap to tap cycle.

SECTION 2

SUMMARY OF RESULTS AND CONCLUSIONS

The sampling and analysis program was conducted according to the approved Test Plan. Modified EPA Method 5 and Andersen cascade impactor sampling procedures were performed at the inlet and outlet of the baghouse controlling emissions from the No. 2 furnace at Foote Mineral Company. In addition, dual cyclone sampling runs were performed at the inlet sampling location. A summary of results of the combined efforts of GCA/Technology Division and Entropy Environmentalists is presented in Table 1 and Figures 1 and 2. These results were prepared using the total particulate data and the impactor derived size distributions; the results of the dual cyclone sampling effort will be presented later. Research Triangle Institute analyzed the total particulate data that were utilized in the size specific emission factor calculations. The report to be published by RTI should be consulted concerning details of sampling and analytical procedures and other results and discussions. The uncontrolled particulate emission factors (inlet side tests) are considered more viable than controlled emission factors (baghouse outlet test results) since outlet testing was performed at a poor sampling location. Each of the 11 baghouse compartments was sampled immediately (5 feet) above the top of the bags at a single sample point. The gas flow in each compartment was below detectable limits; less than 0.002 in. H₂O velocity pressure; therefore, isokinetic sampling was not possible. Also, each compartment (with one exception) was tested only once. An emission factor based on the average of all outlet test results should be considered one complete test run and since very little confidence can be applied to the results of one test, this emission factor should only be considered an estimate.

Major modifications to the baghouse outlet would have been required to facilitate a more accurate measurement of controlled emission rates. These modifications, which in themselves could alter the outlet emission factors, were considered too costly and since the ferroalloy industry in general uses this baghouse outlet design, EPA requested that testing be performed at this less than ideal sampling location. An industrywide comparison of outlet emission factors is still possible, by performing tests at similar sampling locations at different ferroalloy plants, however, the actual controlled emission rates are questionable.

The field testing program was performed during the week of 16 March 1981 while the furnace was producing ferrosilicon at a rate of about 170 tons per day. The average total electrical load on the furnaces including downtime was

TABLE 1. SUMMARY OF TOTAL PARTICULATE AND PARTICLE SIZE DISTRIBUTION TEST RESULTS, FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

		Average inlet	Average outlet
<u>Total Particulate Emission Factors</u>			
Mass Concentration	mg/dscm	518.2	9.75
	gr/dscf	0.23	0.004
Mass Emission Rate	kg/MWH	7.36	0.20
	lb/hr	517.6	13.9
Process Weight Rate	kg/Mg produced	34.87	0.92
	lb/ton produced	69.74	1.84
<u>Particle Size Distribution^a</u>			
Cumulative % mass	15 μ m d ₅₀	66	80
	2.5 μ m d ₅₀	57	54
Mass Emission Rate	lb 15 μ m d ₅₀ /hr	341.6	11.1
	lb 2.5 μ m d ₅₀ /hr	295.0	7.5
<u>Size Specific Emission Factors</u>			
kg particulate	15 μ m d ₅₀ /Mg produced	23.0	0.74
lb particulate	15 μ m d ₅₀ /ton produced	46.0	1.47
kg particulate	2.5 μ m d ₅₀ /Mg produced	19.9	0.50
lb particulate	2.5 μ m d ₅₀ /ton produced	39.8	0.99

^aResults based on cascade impactor data and EPA Method 5 results reported by RTI. Dual cyclone sampler results presented later.

OVERALL EMISSION RATE = 70 $\frac{\text{lbs. PARTICULATE}}{\text{ton 50\% FERROSILICON}}$




Figure 1. Average particle size distribution, uncontrolled ferrosilicon furnace emissions (baghouse inlet), Foote Mineral Company, Graham, West Virginia.

OVERALL EMISSION RATE = 1.8

$\frac{\text{lbs. PARTICULATE}}{\text{ton 50\% FERROSILICON}}$




Figure 2. Average particle size distribution, controlled ferrosilicon furnace emissions (baghouse outlet), Foote Mineral Company, Graham, West Virginia.

30 MWH/hr and testing was conducted only when the furnace was operating normally. Testing was performed during all phases of the refining cycle including charging, stoking and tapping.

The results of the process and visible emissions observations indicate good capture of emissions by the canopy hood since none of the 479 furnace shop roof monitor opacity readings were as high as 20 to 25 percent. Observations of the baghouse roof monitor indicated adequate control of emissions with 5 of the 480 readings in the 20 to 25 percent opacity range. (Some of the baghouse visible emissions may have been generated by dust transfer procedures).

SECTION 3

PROCESS DESCRIPTION

The No. 2 furnace at Foote Mineral Company, Graham, West Virginia is a submerged electric arc furnace rated at 35 megawatts. During the test program, the furnace was producing 47 percent ferrosilicon alloy (FeSi). A schematic of the furnace and pollution control system is provided in Figure 3. The furnace vessel has an inside diameter of 37 feet and is 10'-8" deep. A 40' diameter hexagonal shaped hood is fixed 5 feet above the furnace and is connected by two 6'-6" diameter oftakes to a 12'-6" diameter main duct. Exhaust gases are drawn through the main by two 1500 horsepower fans at a total design flow rate of 450,000 acfm at 500°F. The gas is cooled in u-tube heat exchangers, passes through the fans and is then forced through a positive pressure baghouse venting to the atmosphere via a roof monitor. The perimeter of the hood is equipped with fold down panels to further enclose the furnace as desired.

The furnace is charged with raw materials automatically and intermittently through weighing hoppers and automatic feeders. The raw materials drop about 4 feet from the end of the feed pipes to the top of the charge mixture and are typically composed of: 41 percent quartz, 22 percent scrap, 4 percent remelts, 14 percent wood chips and 19 percent coal.

Stoking, the mechanical leveling of the charge, is performed frequently and as necessary to prevent the occurrence of blows. A blow is when gases trapped in the mix escape rapidly (erupt). Blows occur near the electrodes because the mix loses porosity where the refining and melting occurs. Wood chips are added to the charge mix to help maintain porosity. During stoking, the mix is pushed from the perimeter of the vessel into mounds around the electrodes. Stoking is performed with a ram mounted on a fork-lift type vehicle.

Tapping occurs approximately once every 90 minutes or about 5 taps per shift. This is accomplished by poking, drilling, or shooting the carbon-paste plug out of the taphole area. Generally the tapping process lasts about 30 minutes. The molten metal (at 2800 to 3000°F) flows into a transfer ladle for subsequent casting. A tapping hood is mounted over the taphole to direct emissions into the canopy hood above the furnace. The 63,000 cfm fan with 100 hp motor is connected to the tapping hood and is manually started by the control room operator. The tapping emission control system had been in operation for 6 months and appeared to provide greater than 95 percent capture during typical tapping operations.




Figure 3. Process schematic, Foote Mineral Company, Graham, West Virginia.

SECTION 4

SAMPLING AND ANALYSIS PROCEDURES

INTRODUCTION

Emissions generated during the ferrosilicon production process are evacuated to a positive pressure baghouse. Prior to initiation of the field sampling program, facilities for traversing the horizontal duct were designed by GCA/Technology Division and installed by CGM Contractors, Vienna, West Virginia. The cost of the sampling facility installation was equitably shared by GCA and RTI. The baghouse inlet sampling facilities, consisting of a platform, slider boards and ports, was approximately 40 feet above grade and sampling was performed from a platform mounted on top of the circular duct as shown in Figure 4. The sampling points were located 4.4 diameters downstream and 1.1 diameters upstream of flow disturbances. Both flow disturbances were bends in the duct, a 45° bend upstream, and a 90° bend downstream. The baghouse outlet sampling ports were installed in each of the 11 baghouse compartments on the compartment wall. The ports were located about 5 feet above the bags.

PRESAMPLING PREPARATIONS

All glassware and Nalgene sample bottles utilized in this test program were cleaned with an Alconox solution, rinsed with tap water, distilled-deionized (DDI) water and finally rinsed with spectral grade acetone. The glassware was air-dried and capped with Parafilm. All filters were desiccated to constant tare weight (± 0.5 mg).

Pitot tube-thermocouple-probe assemblies used for preliminary velocity traverses were calibrated by the measurement procedure as specified in 40 CFR 60, Appendix A, Method 2. Sampling nozzles were calibrated with a dial vernier micrometer. Thermocouples were calibrated against a mercury in-glass ASTM thermometer in an ice bath, at ambient temperature and in a boiling water bath. All calibrations are given in Appendix A.

Impactors and cyclones were prepared for sampling by cleaning with soap and water, then rinsing with DDI water and finally with acetone. All particle sizing train dry gas meters and orifices were calibrated according to procedures outlined in APTD 0576 prior to sampling.





Figure 4. Sampling facility schematic, Foote Mineral Company, Graham, West Virginia.

CASCADE IMPACTOR SAMPLING

Reeve Angel type 934-AH glass fiber substrates were prepared for use in the cascade impactors. Each substrate was labeled and placed in a folded aluminum foil liner. Both foil and filter were placed in labeled petri dishes and desiccated for 24 hours. The top half of each foil liner was folded back during desiccation. Initial tare weights and all subsequent weights are a combination of foil and filter weights. A minimum of 6 hours was allowed between weighings. After reaching constant weight (± 0.5 mg) substrates were sealed in their petri dishes for transport to the field.

Sample train preparation and recovery took place in a clean environment inside the truck used to transport equipment. Once onsite, a preliminary velocity traverse was performed in order to:

1. Determine if cyclonic flow conditions exist and, if present, determine the gas flow angles.
2. Determine which sample points represent average flow and temperature for particle sizing measurements.
3. Properly size nozzles and obtain the data necessary to perform isokinetic sampling.

Four sample points of average velocity near $0.7R$ (R = duct radius) were determined through use of the preliminary traverse data. The proper nozzle size and sample train flow rate were selected and single-point cascade impactor sampling was performed during each Level 2 test run. Only one of the four sample points was sampled per impactor run and typically four runs were completed per Level 2 run. Total sampling time was designed to collect approximately 50 mg per impactor run through estimated grain loading values, and by visual inspection of the first run filters. Baghouse inlet test runs were performed with a cyclone precutter installed in front of the impactor to remove particles $>15 \mu\text{m}$ diameter. No visible sample was recovered from the cyclone precutter during initial baghouse outlet test runs, therefore straight nozzles were used for all subsequent outlet tests.

Prior to each sampling run the impactors were carefully loaded with tared substrates. The sample train consisting of the impactor, an unheated probe, vacuum hose, silica gel moisture trap and dry gas meter/orifice/pump assembly as shown in Figure 5, was assembled and leak checked. The impactor was then inserted into the gas stream at the appropriate sample point with the nozzle pointed away from the gas flow (inlet tests) and allowed to reach temperature equilibrium. After approximately 10 minutes, the sampling nozzle was turned into the flow (inlet tests) and the sample flow was adjusted to the desired rate. Outlet tests were performed as above; however, ~~the nozzles were~~ perpendicular to the assumed direction of flow at all times. The flow was monitored and recorded by observing the pressure drop across a calibrated orifice and the total dry gas volume sampled was determined by a calibrated dry gas meter. The flow rate through the impactor was held constant (± 0.05 cfm) for the duration of each run.




Figure 5. Andersen sampling train.

Upon completion of each sample run, the probe/impactor assembly was removed from the duct and sample train shut off. The nozzle was immediately capped with foil. The probe was disconnected and the impactor transported to the sample recovery area. No leak checks were performed at the end of a run so as not to disturb the particle distribution.

Two types of preliminary impactor runs were performed. The first involved the use of "blank" impactors loaded with pretared substrates to determine anomalous weight gain due to gaseous specie absorption. The impactors were fitted with dual prefilters to prevent particulate matter from reaching the substrates. Blank inlet and outlet runs were 28 minutes and 210 minutes long, respectively.

Preliminary loading runs were conducted to obtain a visual indication of particle loading rates. Impactors equipped with cyclone precutters were operated for the estimated length of time necessary to sample 50 mg of particulate. Upon recovery, substrates were examined and sampling times adjusted according to the degree of loading observed. Also, preliminary outlet runs were conducted with a cyclone precutter in order to verify the assumption that no particles greater than 15 microns were present in the outlet stream. These preliminary loading runs were performed with unweighed substrates which were discarded after visual inspection.

DUAL CYCLONE SAMPLING

Preparations for sampling with the dual cyclones consisted of the same washing steps and filter weighing procedures as the impactors. The newly developed series cyclone designed by Southern Research Institute, Birmingham, Alabama, and built by Sierra Instruments, Carmel Valley, California, was operated simultaneously with the EPA Method 5 train at the inlet sampling location only. The two cyclones in series have size cuts of 15 and 2.5 μ m when operated at a nominal flow rate of 0.8 cfm at 300°F. The cyclones, as shown in Figure 6, are operated with the same equipment required by the impactors (as shown in Figure 5).

Prior to each sample run, the train is assembled and leak checked to less than 0.02 cfm at 5 in. Hg. The cyclones are then inserted into the duct with the nozzle pointing away from the flow. The sampler was operated simultaneous (+ 5 minutes) with the Level 2 sampling. Upon start-up, the nozzle was turned into the flow and sampling was conducted at one of two points along the traverse. When the EPA Method 5 train completed one-half of a traverse, the nozzle was then moved along the same diameter to the other 0.7R sample point without shutting off. Sampling continued at the second point until the end of the Method 5 traverse.

Sampling at Foote Mineral Company required a 45° from vertical orientation of the sampler. In this position, the sampler was right side up; that is, the collection cup was below the body of the cyclone during sampling. The procedures manual¹ indicates that the flow through the sampler should not be terminated until the cyclones are approximately horizontal. This would require sampling some ambient air during each run




Figure 6. Schematic drawing of the dual cyclone sampler.

while the sampler was removed from the duct and properly positioned. It was assumed in the field that the sampler could be shut off when in the 45° from vertical position without loss of particulate. Sampling was terminated several times during each run for port changes and process upsets without removing it from the duct.

The dual cyclone sampler would normally be fitted with a backup filter to collect particles <2.5 μm . Upon recovery of preliminary cascade impactor runs, it was evident that most of the particulate was very fine. The backup filter was eliminated from the cyclone train in order to allow run times of around 200 minutes. This would allow enough particulate to be caught in the collection cups to recover dry. By eliminating the backup filter, particulate less than 2.5 μm probably travelled through the probe and connecting hose and was caught in the filters before and after the silica gel trap. It was assumed in the field that good quantification of the first two fractions, >15 μm and 2.5 to 15 μm , would allow subtraction from the total particulate results to obtain the <2.5 μm fraction lost by elimination of the backup filter.

ANDERSEN IMPACTOR SAMPLE ANALYSIS

At the conclusion of each test run, each impactor was carefully disassembled and the nozzle, impactor expander section and cyclone precutter (if used) were washed with acetone into a sample container. Each impactor substrate was placed into its respective petri dish and any particulate adhering to both sides of the top jet plate, the crossbar, and the gasket was brushed onto the substrate. In all cases the substrates were carefully placed in preweighed aluminum foil liners to minimize loss of particulate during subsequent handling of the substrate.

Upon completion of the sample recovery procedures, the samples were labeled, sealed, then liquid levels marked, and the samples were carefully packed for shipment to the GCA/Technology Division laboratory for analysis. A chain of custody log book that outlines the recovery procedures and documents the history of the samples was maintained. Each substrate and weighing jacket, upon return to the GCA laboratory, was placed in a desiccator and dried for at least 24 hours before being weighed. A minimum of 6 hours was allowed between each subsequent weighing until constant weight (± 0.5 mg) was achieved. After weighing, all samples were carefully stored in closed containers.

Sampling data reduction was performed by computer. A preliminary program was used to calculate inputs needed to further reduce the data after the weight gains on each impactor stage have been determined. Once the appropriate input parameters were checked, they were keypunched and entered into the "Computer Based Cascade Impactor Data Reduction System" (EPA-600/7-78-042) as developed by SoRI. Example calculations used by the programmable calculator are provided in Appendix B-1.

DUAL CYCLONE SAMPLE ANALYSIS

Recovery of particulate collected in the cyclones was initiated by dismantling the cyclone stages. The sampler was kept upright at an angle of 45° from horizontal during dismantling. Dry samples were recovered from the collection cups of Cyclone X and Cyclone III. After removal of the dry catch, the cyclones and connecting parts were rinsed three times with acetone into one of two sample containers.

The nozzle, body, collection cup and top half of Cyclone X were rinsed into one container; the connecting tube, canister, outside and inside of the body and collection cup of Cyclone III were rinsed into a second container. The samples were labeled and sealed for transfer to the GCA/Technology Division laboratory for analysis. Upon receipt at the weighing laboratory, the samples are logged in and aliquotted appropriately. The dry catches were desiccated for 24 hours before weighing. The rinses were dried in a hood at ambient temperature in preweighed beakers and desiccated to constant weight.

Data analysis was performed by entering the relevant data into a programmable calculator to determine isokinetics, grain loading, etc. Example calculations are provided in Appendix B-2. The size cuts of the cyclones as used in the field were calculated using the calibration factors and equations provided by Southern Research Institute in the operation manual¹ and through previous phone conversations.

PROCESS OBSERVATIONS

During field testing, a GCA process engineer was positioned inside the furnace control room. From this vantage point the process engineer performed the following:

- Notified the test crew by radio when to start and stop so as to test only during normal furnace operating conditions.
- Documented the origin and approximate magnitude of all emissions generated within the furnace shop. Emission magnitude was assessed for charging, stoking and tapping operations using a scale of light, moderate or heavy.

Other process data and information were given to GCA by Research Triangle Institute in the form of daily process data sheets, at the end of the field test program.

Visible Emission Observations

The degree of emissions escaping capture by the canopy hood system was visually evaluated in accordance with EPA Reference Method 9 as published in the Federal Register, 40 CFR, Part 60, Appendix A. The VE observer was certified by EPA within the previous 6 months by the certification technique specified in Method 9. The observer was positioned outside the furnace shop

and recorded opacity of visible emissions emanating from the furnace shop roof monitor and also the baghouse roof monitor.

SAMPLING AND ANALYSIS QUALITY ASSURANCE

The GCA/Technology Division Quality Assurance Program conforms with EPA and NIOSH recommendations and is directed by the Division QA Manager who reports directly to the General Manager. This gives the QA Manager the necessary authority and independence to find and correct any existing quality problems. Department QC Coordinators are responsible for the QC program within each technical department; they report to both their Department Manager and the QA Manager.

GCA's program includes a Division QA/QC Committee, Department QC Committees, QA/QC Manuals, specific QA Project Plans and Inspection Plans, personnel training, and audit and corrective action procedures. The program is designed to provide both continuity and flexibility in ongoing QC activities in all departments. GCA's technical staff operates under the guidelines of the QA Program using appropriate procedures provided in the QC Manuals and in sampling and analysis method manuals. This ensures that projects like this one for which a specific QA Project Plan was not prepared have written QC procedures provided.

The number and scope of QC procedures used in this program precludes completely detailing them here; however, some key points should be mentioned. All beaker and filter weights were replicated until constant (± 0.5 mg); sample trains were calibrated both before and after a test program to insure H_2 and Y integrity; and all data, calculations, and results were reviewed by committee for accuracy. For details concerning all procedures used, please refer to the Division QA/QC Manual, Parts 1 and 2.

The Appendices to this report provide QC data such as the dry gas meter and nozzle calibration data sheets, the calculation formulas used for particle sizing and total particulate calculations, and the standardized field data sheets used to ensure that pertinent data is recorded.

Comments or questions on data quality are made when appropriate in this report; no formal corrective actions were initiated during this program. NO system audit was performed.

SECTION 5

TEST RESULTS

INTRODUCTION

The field sampling program was conducted during the week of 16 March 1981. The program objective, to develop emission factors for ferroalloy production, was met by completion of 5 total particulate (Level 2) runs and 17 cascade impactor runs at the inlet sampling location. Nine impactor runs were completed during three total particulate runs at the baghouse outlet locations. The shorter inlet impactor runs were operated at various times during the production cycle; however, the longer outlet test runs were operated for complete tap to tap cycles or more. Careful monitoring of the process insured that the test runs were conducted only during normal furnace operations. Emissions escaping capture were documented by the process engineer/visible emission observer. Detailed process data were obtained to allow possible correlations between source operations and measured emission factors.

The field samples and data were driven back to the GCA/Technology Division Laboratory for analysis. The following sections describe the results of the sample and data analysis efforts.

TOTAL PARTICULATE RESULTS

The total particulate measurements were performed by Entropy Environmentalists and the sample analysis was performed by RTI. Tables 2 through 6 summarize the results of the total particulate measurements as provided by Dr. Wayne Westbrook of RTI. Tables 2 and 3 present sampling data and gas characteristics, Tables 4 and 5 present the particulate emission rates, and Table 6 presents the baghouse particulate removal efficiency. Example calculations are provided in Appendix C.

As described previously, the outlet tests were conducted at poor sampling locations, only about 5 feet above the bags. The emission rates and baghouse efficiencies presented in Tables 3, 5 and 6 are therefore less viable than the inlet test results. Outlet emission factors are also questionable because outlet gas flow rate could not be measured, since no baghouse inlet temperatures were obtained just prior to the baghouse (after the dilution air inlet). Based on the ambient temperature, baghouse outlet temperature and previous experience, RTI estimated that 30 percent of the outlet gas was ambient air that was drawn into the baghouse through the grates and dilution air intake louvers. The error associated with these test results is carried into the calculation of outlet size specific emission factors.

TABLE 2. BAGHOUSE INLET LEVEL 2 SAMPLING DATA, FOOTE MINERAL
COMPANY, GRAHAM, WEST VIRGINIA

Run No.	1	2	3	4	5
Date	3/17/81	3/17/81	3/17/81	3/18/81	3/18/81
Start time	0937	1315	1615	1315	1635
Stop time	1145	1520	1805	1513	1835
Net sampling time, min	90	90	90	90	90
Stack Temp., °F	351	356	340	349	363
Stack flow rate ^a dsm ³ /min	6994	7487	8165	7551	7905
Stack flow rate ^b Am ³ /min	11,201	12,049	12,049	12,071	12,950
Volume collected dsm ³	1.54	1.67	1.77	1.66	1.77
% Isokinetic	98.0	99.4	96.3	97.5	99.4

^aMoisture free and at 20°C and 76.0 cm Hg.

^bActual flow rate at stack conditions.

TABLE 3. BAGHOUSE OUTLET LEVEL 2 SAMPLING DATA, FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

Run No.	1	2	3
Date	3/17/81	3/17/81	3/18/81
Start time	0945	1355	1257
Stop time	1252	1659	1557
Net sampling time, min	160	160	160
Stack temp., °F	180	199	205
Volume collected ^a dsm ³	3.28	3.20	3.24
Gas flow rate ^b dsm ³ /min	9990	11,180	10,790
Compartments sampled	1, 2, 3, 4	5, 6, 7, 8	8, 9, 10, 11

^aMoisture free and at 20°C and 76.0 cm Hg.

^bEstimate based on inlet flow rate, and assumption that 30 percent of the baghouse exhaust gas was dilution air.

TABLE 4. TOTAL PARTICULATE TEST RESULTS (BY RTI), BAGHOUSE INLET SAMPLING LOCATION,
FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

Run No.	Particulate captured (mg)	Particulate concentration (mg/dsm ³)	Particulate generated per hour (kg/hr)	Particulate generated per MWH (kg/MWH)	Particulate generated per Mg feed (kg/Mg)	Particulate generated per Mg alloy (kg/Mg)
1	1,073.8	696.2	292.2	9.74	25.38	47.34
2	1,004.8	600.0	269.5	8.29	21.61	40.30
3	852.1	481.8	236.0	7.31	11.23	33.12
4	700.4	422.7	191.5	5.77	10.34	26.35
5	689.8	390.1	185.0	5.67	10.02	27.26
Average all runs		518.2	234.8	7.36	15.72	34.87

TABLE 5. TOTAL PARTICULATE TEST RESULTS (BY RTI) BAGHOUSE OUTLET SAMPLING LOCATION,
FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

Run No.	Particulate captured (mg)	Particulate concentration (mg/dsm ³)	Particulate emitted per hour (kg/hr)	Particulate emitted per MWH (kg/MWH)	Particulate emitted per Mg feed (kg/Mg)	Particulate emitted per Mg alloy (kg/Mg)
1	20.1	6.13	3.67	0.117	0.31	0.57
2	32.7	10.21	6.85	0.207	0.32	0.94
3	41.8	12.92	8.36	0.267	0.47	1.26
Average all runs		9.75	6.29	0.197	0.37	0.92

TABLE 6. BAGHOUSE TOTAL PARTICULATE REMOVAL EFFICIENCIES
FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

Outlet Run No.	Inlet Run No. used in calculation	Baghouse particulate capture efficiency ^a
1	1	98.7
2	2,3	97.3
3	4	95.6
Average/all runs		97.2

^aCalculated using kg generated and kg emitted per hour. Comparisons based on particulate concentration in the gases will overstate baghouse efficiency because of additional air drawn into baghouse through the cooling air grates.

^bA simple average of the particulate results of runs 2 and 3 was used. Outlet Run No. 2 overlapped both inlet runs 2 and 3.

IMPACTOR PARTICLE SIZING RESULTS

Each inlet impactor run was conducted at one of four points in the inlet duct; each outlet run was conducted in several baghouse compartments at a single point within each compartment. Each inlet sample point was sampled four times; only one compartment was sampled more than once at the outlet.

Figures 7 and 8 (same as Figures 1 and 2 presented in Section 2) are each curve fitted composite plots of mean cumulative percent mass concentration versus particle aerodynamic diameter as defined by the Task Group on Lung Dynamics. Figure 7 is a composite of all 17 impactor runs performed on the inlet and Figure 8 is a composite of all 9 impactor runs completed on the baghouse outlet. To plot the particle size distributions presented in Figures 7 and 8, a computer based cascade impactor data reduction system was used and combined with the total particulate results reported by RTI. During each individual test run an impactor data sheet was filled out, containing time, impactor number, and local barometric pressure. Recorded at specific intervals during the run were elapsed time, dry gas meter volume, inlet and outlet temperature, orifice pressure drop and dry gas meter static pressure. Stack gas temperature, gas static pressure, velocity pressure and gas fraction analysis data were obtained from Entropy Environmentalists. The cascade impactor data reduction system (CIDRS), developed by Southern Research Institute for EPA, was first used to analyze the field and resulting gravimetric data. This reference (EPA 600/7-78-042) contains a thorough discussion of the design and use of the above mentioned data reduction system. The system combined the output from all individual runs made on either the inlet or outlet; screened and removed outlying data; fitted the data to a composite curve, and calculated results with 90 percent confidence intervals. Upon review of the draft report by EPA, the CIDRS program was found to be deficient in the treatment of the cyclone precut data associated with each inlet impactor run. EPA contracted Research Triangle Institute to develop an interactive computer program using CIDRS with modifications to more accurately treat the particulate catch resulting from the use of precutters.

The particulate Data Reduction System (PADRE) prompts a user for input in the interactive mode and checks the inputted value. In CIDRS, the cyclone precutter particulate catch was added to the first stage substrate weight gain. In PADRE, the lower cutpoint of the cyclone precutter is calculated and associated with the particulate catch. Another major difference between the programs is that CIDRS screens for and eliminates outliers from the calculation of average results whereas PADRE only flags outlying data points. (Appendix D-1).

PADRE allows the user to decide if the back-up filter catch represents a valid number. Basically it gives the option of an all or nothing situation. All impactor runs showed a significant amount of particulate on the filter and upon visual inspection no large particles were found. Therefore, 100 percent of the filter weight was used in all calculations.

OVERALL EMISSION RATE = 70 $\frac{\text{lbs. PARTICULATE}}{\text{ton 50\% FERROSILICON}}$




Figure 7. Average particle size distribution, uncontrolled ferrosilicon furnace emissions (baghouse inlet), Foote Mineral Company, Graham, West Virginia.

OVERALL EMISSION RATE = 1.8 $\frac{\text{lbs. PARTICULATE}}{\text{ton 50 \% FERROSILICON}}$




Figure 8. Average particle size distribution, controlled ferrosilicon furnace emissions (baghouse outlet), Foote Mineral Company, Graham, West Virginia.

In the previous draft report the cyclone cutpoints that were recorded were too high. Recalculations showed the cutpoints to be approximately 25 μm which are probably still too high to correct. However, a new formula based on updated calibration data, was developed by SoRI. This has been incorporated into the PADRE program and corrected cyclone cutpoints have been calculated.

Straight nozzles were used on the outlet impactor runs instead of cyclones, and the resulting nozzle rinse weights were combined with the first stage weights for each run. Therefore, the outlet data was treated the same way as the inlet data. The nozzle cutpoint was set equal to the first stage cutpoint which treated the data as if the nozzle wasn't there.

Specific "generic" calibration constants supplied by SoRI were used in all calculations rather than the Ranz and Wong value of 0.38 which was used previously. For the spline fit interpolation, Padre now automatically skips the downstream stage of two stages whose cutpoints differ by less than 30 percent. The computer printouts from Padre are contained in Appendix D-1 and D-2 and the field data sheets are presented in Appendix E-1. Example calculations are provided in Appendix B-1.

Figure 9 is a plot of particle aerodynamic diameter versus the mean change in mass concentration ($dM/d \log D$) for both the inlet and outlet. The graph is a composite of both inlet and outlet runs. The values of $dM/d \log D$ for the outlet can be divided by the corresponding inlet value for the same particle size to determine the baghouse efficiency for removing particles of that specific size. Baghouse particulate mass removal efficiency versus particle diameter is illustrated more clearly in Figure 10 and Table 7.

Due to the large cross-sectional area of the baghouse compartments where outlet sampling occurred, no flow could be detected by the s-type pitot tube equipped with a zero to 0.25 in. H_2O micromanometer. No attempt was made to sample isokinetically at this extremely low flow rate, and the impactor nozzles were oriented perpendicular to the assumed direction of flow for convenience when inserting and removing the impactor/probe assembly within the limited space of the outlet sampling location. The lack of a significant flow rate and resultant superisokinetic sampling rates makes the outlet particle size distribution curve (Figure 8) and the control device efficiency plots (Figures 9 and 10) less viable than the inlet size distribution curve (Figure 7) where isokinetic sampling conditions were maintained.

DUAL CYCLONE SAMPLER RESULTS

The recently developed dual cyclone sampler was operated at the inlet location simultaneous with the Modified EPA Method 5 sample train. A summary of results is presented in Figure 11 and Table 8. These results were calculated using the appropriate stack gas characteristics reported by RTI. Example calculations are provided in Appendix B-2 and field data sheets are presented in Appendix E-5. The two dual cyclone runs reported in Table 7 each span more than one Method 5 run. The first cyclone run (No. 1-2) was operated during Method 5 runs 1 and 2, cyclone run 3-4 during Method 5 runs 3 and 4.




Figure 9. Average change in concentration per particle size (all runs), Foote Mineral Company, Graham, West Virginia.




Figure 10. Baghouse efficiency by particle size, Foote Mineral Company, Graham, West Virginia.

TABLE 7. BAGHOUSE SIZE SPECIFIC PARTICULATE REMOVAL
EFFICIENCIES, FOOTE MINERAL COMPANY,
GRAHAM, WEST VIRGINIA

Particle aerodynamic (microns)	Inlet dM/d log D (mg/dnm ³)	Outlet dM/d log D (mg/dnm ³)	Removal efficiency (percent)
20	317	6.37	98.0
15	123	5.23	95.7
10	93.3	4.47	95.2
6	58.8	2.74	95.3
2.5	76.0	2.83	96.3
1.25	177	3.80	97.9
1.00	187	4.08	97.8
0.63	164	2.82	98.3

TABLE 8. DUAL CYCLONE SAMPLER RESULTS, FOOTE MINERAL COMPANY,
GRAHAM, WEST VIRGINIA

Date		3/17/81	3/17/81 and 3/18/81
Run Number	Units	1-2	3-4
Stack Gas Characteristics			
Temperature	°F	351	360
Velocity	afpm	3295	3585
Pressure	in. Hg abs.	28.8	28.7
Viscosity	micropoise	245.9	247.5
Volume Sampled	dscf	38.99	48.52
Sampler Flow Rate	acfm	0.33	0.33
Nozzle Diameter	in.	0.138	0.138
Isokinetic Sampling Rate	percent	92.5	85.0
Particulate Total Weight Caught^a			
Cyclone III	mg	63.38	47.58
Cyclone X	mg	34.63	51.28
Total	mg	98.01	98.86
Particulate Emission Rates			
Cyclone III d50	microns	6.8	6.9
Emissions < Cyclone III d50	lb/hr	534.3 ^b	396.3 ^b
Cyclone X d50	microns	16.2	16.3
Emissions between Cyclone III d50 and Cyclone X d50	lb/hr	54.8	36.1
Emissions > Cyclone X d50	lb/hr	30.0	38.9
Total	lb/hr	619.2 ^c	471.2 ^c
Particulate Emission Factors			
Average Emissions < 6.85 μ m d50	lb/ton		59.3
Average Emissions between 6.85 and 16.2 μ m d50	lb/ton		5.6
Average Emissions > 16.2 μ m d50	lb/ton		4.15
Total Emission Rate	lb/ton		69.7 ^c

^aTotal weight of dry catch and rinse residue.

^bCalculated using daily average total particulate emission rate from Method 5 tests less total caught in dual cyclone train since no backup filter was used to measure this fraction.

^cThe average of the corresponding two Method 5 test results.

The cyclone was assembled and operated per the IP protocol, and due to the anticipated large amount of fine particulate in the gas stream, the backup filter assembly was removed in order to increase the possibility of obtaining enough particulate in the collection cups to recover in a dry state. This eliminated quantification of the particles $2.5\ \mu\text{m}$ by the cyclone train; however, this fraction could be calculated by difference between the total particulate (Level 2) results and the total catch from the two cyclones. Removal of the backup filter allowed total sample run times of approximately 200 minutes. This allowed collection of up to 98 mg particulate in the cyclones. This larger amount of sample and the longer test time substantially increases the viability of the results. The dual cyclone results are compared to the cascade impactor results graphically in Figure 11.

The dual cyclone results show a slightly higher fraction of particles in the 6 and $16\ \mu\text{m}$ range than the impactor results. Only 2 cyclone runs are compared to 17 impactor runs in Figure 11 which could explain some of the difference. Particulate loss during recovery and gravimetric analysis is more of a problem with the cyclones than the impactor substrates since actual transfers of particulate from cyclone cup to a sample container to a second weighing container are required. These transfer steps usually result in some loss of particulate in both the impactor cyclone and series cyclones. During this test program, very little particulate was recovered from the cyclone precutter installed on the impactor. An average of 4 mg was caught in the impactor cyclone; an average of 47 mg was caught in each series cyclone, therefore any losses would effect the impactor results more. The sample recovery procedures for the impactor cyclone were identical to those for the dual cyclones. Care is taken during sample recovery and analysis to completely quantify particulate weights by careful rinsing and weighing, however, acetone does not completely remove particulate from the cyclone and sample container walls.

The results of previous tests using the series cyclones have always shown a lesser amount of 3 and $15\ \mu\text{m}$ particles than the impactor results. In all previous tests, however, the cyclones were operated either horizontal or a degree of upside-down. This is the first test program where the cyclones were upright (at 45° from vertical). The capture efficiency of the cyclones may have been enhanced, however, the cyclones operating manual indicates that the orientation is not pertinent while the sampler is in operation.

SIZE-SPECIFIC PARTICULATE EMISSION FACTORS

The emission factors contained in Table 9 were calculated by applying the size distribution test results from GCA's Andersen testing to the total particulate data results from the Level 2 testing. The volumetric flow rate at the outlet of the baghouse was adjusted to include dilution air by consideration of the drop in stack gas temperature. It was not possible to accurately measure flow inside the baghouse utilizing EPA procedures; therefore, the outlet gas flow rate is based strictly on calculations by RTI. The fume and emission factors based on tons produced were calculated by dividing the hourly emission factors by the average production rate recorded by GCA and RTI during the test period.

OVERALL EMISSION RATE = 70 $\frac{\text{lbs. PARTICULATE}}{\text{ton 50\% FERROSILICON}}$




Figure 11. Comparison of dual cyclone and cascade impactor results, baghouse inlet, Foote Mineral Company, Graham, West Virginia.

TABLE 9. SIZE SPECIFIC EMISSION FACTORS, FOOTE MINERAL COMPANY,
GRAHAM, WEST VIRGINIA

Sampling location	Particle aerodynamic diameter (d50, μ m)					
	∞^a	15	10	6	2.5	1
Cumulative % mass <d50	100	66	63	61	57	50
Baghouse inlet	517.6	341.6	326.1	315.7	295.0	258.8
Cumulative lb <d50/hr						
Cumulative lb <d50/ton ferrosilicon	69.7	46.0	43.9	42.5	39.7	34.9
Cumulative % mass <d50	100	80	72	63	54	39
Baghouse outlet	13.9	11.1	10.0	8.8	7.5	5.4
Cumulative lb <d50/ton ferrosilicon	1.84	1.47	1.32	1.16	0.99	0.72

^aObtained from total particulate "front half" test results by Entropy Environmentalists.

VISIBLE EMISSIONS DATA

All visible emissions observations were made in accordance with EPA Method 9. The field data sheets appear in Appendix E-2. Visible emissions were recorded during the 2 days of the test program. The furnace shop roof monitor was observed for 2 hours, the baghouse outlet for 2 hours. A summary of the visible emissions data obtained is presented in Table 10.

At no time during the testing period were visible emissions greater than 20 percent opacity observed originating from the baghouse compartments being tested. Five readings in the 20 to 25 percent range were recorded; these may have been due to dust transfer procedures. Capture efficiency of the canopy hood throughout the study, for all operations other than tapping, was close to 100 percent. Visible emissions originating from the furnace building could be attributed mainly to other operations in the shop such as casting and furnace repairs.

FURNACE OPERATIONS DATA

A process observer recorded furnace operations and cycle times, as well as fluctuations in furnace fume generation. Capture efficiency of the canopy hood and tapping hood was also assessed. Tapping, stoking, charging, and blows, all cause heavier emissions than just the smelting process. Fumes generated by stoking were usually completely captured by the canopy hood. Blows (characterized by an intense white flare) resulted in a short burst of heavier fumes and more flames than normal. Table 11 presents a summary of all materials charged to the furnace for the test day. The furnace was operated at an average of greater than 85 percent design capacity.

The furnace was tapped based on MW consumption. When a set amount of power has been consumed, which usually occurs every 90 minutes, the furnace is tapped. Table 12 presents the daily tap weights and average results of the alloy analysis performed by the source.

~~The product weight rate averaged about 7 ton/hour with an average tap duration of 30 minutes.~~

Baghouse Observations

Individual compartment pressures, overall pressure, temperature range and fan currents, were recorded in the field and are presented in Appendix E-3. A summary of the recorded baghouse data is provided in Table 13. The source provided design parameters for the baghouse and these data are presented in Table 14.

TABLE 10. SUMMARY OF VISIBLE EMISSION OPACITY OBSERVATIONS FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

Date	3/18/81	3/18/81
Source	Baghouse roof monitor	Furnace shop roof monitor
Total No. of 15-second observations	480	479
Total minutes	120	120
Number of observations 0-5% opacity	473	456
Total minutes 0-5% opacity	113	114
Number of observations 10-15% opacity	6	6
Total minutes 10-15% opacity	5	0
Number of observations 20-25% opacity	1	0
Total minutes 20-25% opacity	0	0
Number observations >25% opacity	0	0
Total minutes >25% opacity	0	0

TABLE 11. CHARGE COMPOSITION AND WEIGHTS, FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

Date	Units	Quartz	Scrap	Wood chips	Silicon remelts	No. 1 coal	No. 2 coal	Regular scrap	Total materials
3/16/81	Tons	177.77	47.39	58.35	10.89	23.09	66.48	52.00	435.97
	Percent	40.8	10.9	13.4	2.5	5.3	15.2	11.9	100
3/17/81	Tons	195.18	36.56	66.04	14.20	22.69	64.11	59.37	458.15
	Percent	42.6	8.0	14.4	3.1	4.9	14.0	13.0	100
3/18/81	Tons	174.21	34.80	68.74	19.77	22.44	61.63	62.76	444.35
	Percent	39.2	7.8	15.5	4.4	5.1	13.9	14.1	100
	Average Tons	182.38	39.58	64.38	14.95	22.74	64.07	58.04	446.2
	Average Percent	40.9	8.9	14.4	3.3	5.1	14.4	13.0	100

TABLE 12. TAP WEIGHT AND ALLOY ANALYSIS, FOOTE MINERAL COMPANY,
GRAHAM, WEST VIRGINIA

Date		3/16/81	3/17/81	3/18/81
Tap Weight (daily total)	lbs	338,600	351,600	315,500
	tons	169.3	175.8	157.7
Alloy Analysis				
Percent Silicon		47.73	47.05	47.55
Percent Calcium		0.25	0.45	0.28
Percent Chromium		0.24	0.18	0.24
Percent Aluminum		1.01	1.32	0.97
Percent Cesium		0.01	0.01	0.02

TABLE 13. BAGHOUSE OPERATING DATA, FOOTE MINERAL COMPANY,
GRAHAM, WEST VIRGINIA

Date	3/17/81	3/18/81
Average Temperature °F ^a	349	356
Average Compartment Pressure "H ₂ O	10.5	10.5
Fan Amperage	290	290
Cleaning cycles:		
Collection period	15 minutes	
Clean period	45 seconds	
Null period	30 seconds	
Soft reinflate	20 seconds	

^aMeasured inlet temperature.

TABLE 14. BAGHOUSE CONTROL SYSTEM DESIGN PARAMETERS
FOOTE MINERAL COMPANY, GRAHAM, WEST VIRGINIA

COLLECTION SYSTEM(S)

Baghouse

- a. Manufacturer: American Air Filter Inc.
- b. Type or trade name: AMER-therm Collector
- c. Model No.
- d. No. of compartments: 11
- e. Bags/compartment: 256
- f. Bag l x d: 372 in. x 11.75 in.
- g. Total cloth area: 268,535 ft² (12 compartments)

Fan

- a. Manufacturer: Robinson
- b. Model No.: TVC-CCW-Double inlet
- c. Blade size: 104 in. x 36 ft 1/8 in.
- d. Belt or direct drive: Belt
- e. Power rating: 2 at 1500 Hp
- f. Positive or negative pressure: Positive

Fabric

- a. Manufacturer: Carborundum Co., Filter Media Division
 - b. Material: Glass cloth
 - c. Woven or felted: woven
 - d. Weave: 3:1 cf
 - e. Weight: 8.5 oz. sq. yard
-

(continued)

TABLE 14 (continued)

-
- f. Thread Count: 54 x 52
 - g. Operating temp. range: 550°F
 - h. Surface treatment: Siliconized
 - i. Coating upon startup: Graphite
 - j. Guaranteed life: None
 - k. Actual life: 2 years

Cleaning System

- a. Method: Reverse air
- b. Frequency: 1 compartment/50 minutes
- c. Actuated by: Timer
- d. Anti-collapse rings: Yes
- e. Wire mesh cages: None
- f. Cleaning air: 300 Hp Robinson

Operating Parameters

- a. Design volume flow rate: 450,000 acfm
 - b. Design temperature: 550°F
 - c. Gross media design efficiency: 99+
 - d. Design inlet grain loading:
 - e. Total power consumption: 2400 volts, 3300 Hp
 - f. Design air/cloth ratio: 1.68 acf/ft² min gross;
2.05 acf/ft² min net (9 compartments)
 - g. Design pressure (absolute): 24 in. H₂O
 - h. Design ΔP (WC): 24 in. H₂O
-

(continued)

TABLE 14 (continued)

Precollector

- a. Manufacturer: American Air Filter
 - b. Type: Multiclone
 - c. Model No.: No. 9 WU14, Size 170-S
 - d. Design Temperature: 1200°F
 - e. Cooler surface area: 24,000 ft²
-

APPENDIX A
SAMPLE TRAIN CALIBRATIONS

DGM # V1

Man ΔH	D.G.M. Initial	DGM Final
0.05	428.582	
	428.91	
	429.300	
25.80 min	429.600	
	429.92	
	430.55	
	430.90	
	431.33	
	431.650	
	432.100	
	432.500	
	432.917	
	433.300	

DGM Net	W.T.m Initial	W.T.m Final	W.T.m Net
	1	6	5

$\gamma = 1.005$
 $\Delta H @ = .738$

Temp In	Temp out	W.T.m CF
76	72	690
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	
76	72	

433.605 5.023

Box # V

$\frac{\Delta H}{0.05}$

0.1

0.2

0.3

0.4

0.5

1.0

$P_0 = 29.9$

DCM # V 1

man ΔH	DC m Initial	DC m Final	DC m Net	WTM Initial	WTM Final	WTM Net	Temp In out	WTM of δ
0.1	423.558			6	11	5	76 72	69°P
	424.00							
	424.2							
	424.67							
	425.40							
20.9 min	426.00							
	426.500							
	427.10							
	427.500							
	427.900							
	428.37							
	428.582							
		428.532	5.024					
0.2	396.700			9.5	14.5	5	76 72	69°P
	397.64							
	398.21							
14.5 min	398.81							
	399.52							
	400.7							
	401.01							
	401.714	401.714	5.014					

$$Y = 1.004$$

$$\Delta H @ = 0.969$$

$$Y = 1.006$$

$$\Delta H @ = .931$$

PB = 29.95

DGM# VI


man ΔH	DGM Initial	DGM Final	DGM NET	WTM Initial	WTM Final	WTM NET	Temp In out	WTM OF
0.3	4103.250			6	11	5	76 72	64°F
	4104.42							
	4104.95							
11.39 min	4106.00							
	4106.75							
	4107.70							
	4108.307	4108.377	5.057					
0.4	4108.307			1	6	5		
	4109.52							
9.92 min	4110.55							
	4111.66							
	4112.12							
	4113.379	4113.379	5.072					
0.5	4113.379			6	11	5	76 72	
	4114.00							
9.10 min	4115.60							
	4116.60							
	4117.77							
	4118.450	4118.450	5.071					
1.0	4118.450			1	6	5	76 72	
	4120.52							
	4120.65							
6.40 min	4123.20							
	4123.558	4123.558	5.108		45			

Y = .997
ΔH@ = .863

Y = .994
ΔH@ = .873

Y = .994
ΔH@ = .901

Y = .986
ΔH@ = .909



TEST - FORTÉ MINERALS 1-616-027
CALIBRATIONS REC'D 03/25/8

Dry Gas Meter Calibrations - VI

OH → (in H ₂ O)	0.05	0.10	0.20	0.30	0.40	0.50	1.00	
Wet Volume (ft ³)	5.00	5.00	5.00	5.00	5.00	5.00	5.00	
Dry Volume (ft ³)	5.023	5.024	5.014	5.057	5.072	5.071	5.108	
Wet Temp. (°F)	69.0	69.0	69.0	69.0	69.0	69.0	69.0	
Dry Temp. (°F)	74.0	74.0	74.0	74.0	74.0	74.0	74.0	
Time (min)	25.00	20.90	14.50	11.39	9.92	9.10	6.40	
Barom. Pressure (in Hg)	29.95	29.95	29.95	29.95	29.95	29.95	29.95	
<u>Outputs</u>								
Y	1.005	1.004	1.006	0.997	0.994	0.994	0.986	
ΔH _a	0.738	0.969	0.933	0.863	0.873	0.919	0.909	
Q _a	0.195	0.240	0.346	0.444	0.511	0.557	0.798	
C _c	0.031	0.062	0.123	0.185	0.246	0.308	0.616	

Rate 0.000m

Fig 101 4.40 my

V2

top

	ΔH m4h	DC Inch	DC Fm4h	Net	LT Inch	Fin	Net	In	out	W.Tm7. °F
0	0.05	917.720			8	13	5	62	64	
		918.07						62	64	108
4		918.45						62	64	
6		919.01						62	64	
8		919.87						62	64	
10		919.52						62	64	
12		919.720						62	64	
14		919.97						62	64	
16		920.20						62	64	
18		920.75						62	64	
20		920.910						62	64	
22		921.17						62	64	
24		921.45						62	64	
26		921.78						62	64	
28		922.11						62	64	
30		922.34						62	64	

Y = 992
ΔH@ = 1.142 → 1.162 BN

31.46
31.76

922.704 4.984

K. d. 5 Mar '51

12-2-13

" 1/2

PB =

							Temp	
							In	Out
0	0.1	923.700		4	9	(5)	67	63
2		924.21					67	63
4		924.61					67	63
6	2.55	925.17					67	63
8		925.47					67	63
10	2.55	926.390					67	63
12		926.65					67	63
14		927.00					67	63
16		927.66					67	63
18		927.40	928.711	5.011			67	63
							(6)	

$$y = -991 \rightarrow 0.991$$

$$1.110 - 466 \rightarrow 70.977$$

BN

0	0.2	929.715		0	5		67	63
2		930.60					67	63
4	15.02	931.10					67	63
6		931.80					67	63
8	15.03	932.40					67	63
10		933.02					67	63
12		933.71					67	63
14		934.400	934.730	5.015			67	63
								$\bar{x} = 6.5$

$$y = -984 \rightarrow 0.970$$

$$0.110 - 1.972 \rightarrow 1.037$$

BN

0	0.3	934.730		5	10	(5)	68	62
2		935.60					68	62
4	14.62	936.30					68	62
6		936.370					68	62
8		937.53					68	62
10		938.48					68	62
12		938.970	939.761	5.031			68	62

$$y = .986$$

$$0.110 - 1.432 \rightarrow 1.472$$

BN

Page 2 of 3

Ambient { Bar 29.30
Temp. 66.6

D.C.M. V2

	D.C. Tmed	D.C. Tmed	D.C. Tmed	W.T. Tmed	W.T. Tmed	W.T. Tmed	Temp. of	W.T.M Temp. °F
411 (0.4)		955.985		85.000			62 64	(68.6)
		956.555					62 64	
		957.125					62 64	
		---					---	
		960.075					62 64	
960.361	960.335	(4.11)	96.000	85.000	(5.000)		X =	(63)
		$\bar{X}$ 0.993						
		ΔH_c 1.629						
0.2 4 6 8 (0.5)		963.535		93.000			62 64	(68.6)
		964.125					62 65	
		964.715					62 65	
		965.305					62 65	
		965.895					62 65	
967.337	967.335	(4.77)	98.000	93.000	(5.000)		X =	(63)
		$\bar{X}$ 0.911						
		ΔH_c 1.011						
0.2 4 6 8 (1.0)		969.335		99.000			62 65	(68.6)
		970.535					62 66	
		971.745					62 66	
		972.940					62 66	
975.375	969.335	(6.040)	100.000	99.000	(6.009)		X =	(64)
		$\bar{X}$ 0.957						
		ΔH_c 1.058						

Amb. { Bar 29.30
Temp 66.6

Amb. { Bar 29.30
Temp 66.6

March 1989

Amber { B. 21
Temp 6

DGM HUS

Alt

0.03

140.92

141.22

141.52

141.82

142.12

142.42

142.72

143.02

143.32

143.62

143.92

144.22

144.52

144.82

145.12

145.42

145.72

146.02

146.32

146.62

146.92

147.22

147.52

147.82

148.12

148.42

148.72

149.02

149.32

149.62

150.02

150.32

150.62

150.92

151.22

151.52

151.82

152.12

152.42

152.72

153.02

153.32

153.62

153.92

154.22

154.52

154.82

155.12

Temp °F

in out

59 63

60 63

60 63

61 64

61 64

61 64

61 64

62 65

63 66

63 66

64 66

64 67

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

64 68

W.F.M

Temp °F

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

68.6

145.848

146.148

146.448

146.748

147.048

147.348

147.648

147.948

148.248

148.548

146.148

146.448

146.748

147.048

147.348

147.648

147.948

148.248

148.548

148.848

149.148

149.448

149.748

150.048

150.348

150.648

150.948

151.248

151.548

151.848

152.148

152.448

152.748

153.048

153.348

153.648

153.948

154.248

154.548

154.848

155.148

155.448

146.148

146.448

146.748

147.048

147.348

147.648

147.948

148.248

148.548

148.848

146.148

146.448

146.748

147.048

147.348

147.648

147.948

148.248

148.548

148.848

149.148

149.448

50 6 March '81

DGM # V3

WT	D.C.	D.C.	WT	WT	WT	D.C.T.	WT	WT
Net	Initial	Final	Net	Initial	Final	In	Out	R
0.20	104.505			6.5	11.5	5	71	65
	105.44							70.5
	105.95							
14.63 min	106.57							
	107.20							
	108.55							
	109.25							
	109.519		5.014					
							69.5	

$$y = .995$$

$$\Delta H @ = .968$$

0	0.30	110.030						
2		110.920	2	7	5	72	68	70.5
4	12.15 min	111.70						
6		112.50						
8		113.30						
10		114.120						
12		115.068	5.038					

$$y = .991$$

$$\Delta H @ = 1.001$$

0	0.40	117.110	9	14	5	68	74	70.5
2	10.6 min	118.01						
		118.98						
6		119.99						
8		120.42						
10		122.177	5.063					

$$y = .988$$

$$\Delta H @ = 1.014$$

K. Meserve

5 Mar. '81

DGM # 13

T	ΔH	Z G	O. G	DG	WT	WT	WT	DGT. &	WTM	WTM
	MAN	In W	Find	Net	IFD	Find	Net	In	Out	T ° F
0	0.5	123.19			5	10	5	69	75	70.5
2		124.30								
4		125.52								
6	(9.45)	126.45								
8		127.30								
10		128.265								
					5.080					

$$Y = .986$$


$$\Delta H Q = 1.006$$



0	2.0	129.240			1	11	10	69	75	
2		131.46								
4	(9.6 min)	134.30								
6		135.61								
8		137.80								
10		139.535								
12										
					10.245					

$$Y = .974$$

$$\Delta H Q = 1.034$$



14. Average 5 Mar. '81

Dry Gas Meter Calibrations - V2

OH →	(in H ₂ O)	0.05	0.10	0.20	0.30	0.40	0.50	1.00	
Wet Volume	(F+3)	5.00	5.00	5.00	5.00	5.006	5.008	6.009	
Dry Volume	(F+3)	4.984	5.011	5.015	5.031	4.981	4.999	6.020	
Wet Temp.	(°F)	68.6	68.6	68.6	68.6	68.6	68.6	68.6	
Dry Temp.	(°F)	63.0	65.0	65.0	65.0	63.0	63.0	64.0	
Time	(min)	31.76	20.63	15.03	14.62	10.56	9.37	8.06	
Barom. Pressure	(in Hg)	29.40	29.40	29.40	29.40	29.30	29.30	29.30	
<u>Outputs</u>									
Y		0.992	0.991	0.990	0.986	0.993	0.990	0.987	
OH _a		1.162	0.977	1.037	1.472	1.029	1.012	1.038	
Q _a		0.157	0.243	0.334	0.344	0.472	0.534	0.747	
C _c		0.031	0.062	0.123	0.185	0.247	0.308	0.618	

Dry Gas Meter Calibrations - V3

$\Delta H \rightarrow$ (in H_2O)	0.05	0.10	0.20	0.30	0.40	0.50	2.00	
Wet Volume (H^3)	5.004	5.003	5.000	5.000	5.000	5.000	10.000	
Dry Volume (H^3)	4.978	4.937	5.014	5.038	5.063	5.080	10.245	
Wet Temp. ($^{\circ}F$)	68.6	68.7	70.5	70.5	70.5	70.5	70.5	
Dry Temp. ($^{\circ}F$)	63.2	67.1	69.5	70.0	71.0	72.0	72.0	
Time (min.)	30.06	20.39	14.62	12.15	10.60	9.45	9.60	
Barom. Pressure (in Hg)	29.30	29.30	29.80	29.80	29.80	29.80	29.80	
<u>0.4 ppts</u>								
γ	1.015	1.010	0.995	0.991	0.988	0.986	0.974	
ΔH_a	1.042	0.953	0.967	1.001	1.014	1.005	1.037	
Q_a	0.162	0.242	0.343	0.415	0.478	0.538	1.067	
C_c	0.031	0.062	0.123	0.184	0.246	0.308	1.233	

10³ 10³ 7

Bar 29.80

5 Nov. 31

DGM # V4

	ΔH man	D.C. Initial	D.C. Final	D.C. Net	WT Initial	WT Final	WT Net	D.C. of In out	WT of
0	.05	9.395						76	78
2		9.70							
4		10.13							
6		10.410							
8		10.85							
10		11.16							
12		11.40							
14		11.83							
16		12.1							
18	30.3 min	12.45							
20		12.73							
22		13.12							
24		13.34							
26		13.82							
28		19.16							
30		14.40	14.464	5.119	9.5	14.5	5	↓	↓

$$X = .993$$

$$DHG = 1.025$$

assume
70°F

K. Mesone

DGm# V4

Bp = 29.44

T	ΔH mm	D.C. Initial	D.C. Final	D.C. Net	WT Initial	WT Final	WT Net	D.G.T. % In, out	
0	0.1	19.045			9	14	5	75 77	
2		19.730							
4		20.10							
6	19.55 mm	20.65							
8		21.21							
10		21.65							
12		22.30							
14		22.70							
16		23.22							
18		23.78							
		24.154	24.154	5.109					
0	0.2	976.852			8	13	5	72 72	
2		977.050							
4		978.270							
6	14.25 mm	978.42							
8		979.95							
10		980.45							
12		981.33							
14		981.914	981.914	5.064					
0	0.3	982.955			5	10		74 74	
2		984.95							
4	11.80 mm	985.97							
6		986.60							
8		987.40							
10		988.61	989.054	5.054		56			

$$y = .991$$

$$\Delta H\% = .859$$

$$y = .994$$

$$\Delta H\% = .912$$

$$y = .990$$

$$\Delta H\% = .936$$

D 6m# V4

	Δ H mm	D.C. Initial	D.C. Final	O.C. NET	WT Initial	WT Final	WT NET	D.C.T. or Fh	or ot
0	0.4	990.315			1	6	5	76	78
2		991.740							
4	10 min	992.85							
6		993.300							
8		994.510							
10		995.440	995.440						
0	0.5	996.750			7	12	5	76	78
2		997.750							
4	9.1 min	998.880							
6		1000.00							
8		1,000							
		1001.605 x							
					5.135	4.855			
0	1.0	3.675						76	78
2		5.80							
4	6.5 min	6.80							
6		8.40							
8		8.835							
					5.160				

$$Y = .991$$

$$\Delta H = .892$$

$$Y = 1.008$$

$$\Delta H = .923$$

$$Y = .982$$

$$\Delta H = .942$$

Dry Gas Meter Calibrations - V4

$\Delta H \rightarrow$ (in H_2O)	0.05	0.10	0.20	0.30	0.40	0.50	1.00	
Wet Volume (ft ³)	5.000	5.000	5.000	5.000	5.000	5.000	5.000	
Dry Volume (ft ³)	5.119	5.109	5.064	5.099	5.125	5.135	5.160	
Wet Temp. (°F)	70.0	70.0	70.0	70.0	70.0	70.0	70.0	
Dry Temp. (°F)	77.0	76.0	72.0	74.0	77.0	77.0	77.0	
Time (min)	30.30	19.55	14.25	11.80	10.00	9.10	6.50	
Barom. Pressure (in Hg)	29.80	29.44	29.44	29.44	29.44	29.44	29.44	
<u>Outputs</u>								
Y	0.990	0.989	0.991	0.987	0.988	0.985	0.979	
ΔH_a	1.022	0.963	0.924	0.946	0.901	0.933	0.952	
Q_a	0.169	0.261	0.355	0.432	0.513	0.564	0.794	
C_c	0.031	0.063	0.125	0.188	0.252	0.315	0.630	

straight nozzles

inches

3/4/81

Set /	1 st	2 nd	3 rd	Average
G	0.124	0.126	0.126	0.125
H	0.180	0.180	0.185	0.181
I				0.251
J				0.311
K				0.375
L				0.501

SET 2

G	0.124
H	0.198
I	0.250
J	0.311
K	0.374
L	0.500

Set 3

F	0.127
G	0.185
H	0.250
I	0.310
J	0.372
K	0.500

46 0.125

4H 59 0.166

APPENDIX B-1

EXAMPLE CALCULATOR ANDERSEN CASCADE IMPACTOR

The field sampling and laboratory analysis data is reduced by programmable calculation to provide the following input to the SORI data reduction system:

1. Impactor identification (required to call up hardware information)
2. Fractional gas composition (CO_2 , CO, N_2 , O_2 , H_2O)
3. Impactor flow rate (ACFM at stack conditions)
4. Stack pressure (inches of mercury)
5. Stack temperature (degrees Fahrenheit)
6. Gas temperature within impactor (degrees Fahrenheit)
7. Duration of sampling (minutes)
8. True density of particles (grams per cubic centimeter)
9. Maximum particle diameter present in sample (micrometers)
10. Masses of catches by stage (milligrams)

The following field data are also entered into the calculator to obtain the above input data:

- Barometric pressure (inches of mercury)
- Molecular weight of gas stream at meter (lb/lb-mole)
- Average static pressure at meter (inches of mercury)
- Average temperature at meter ($^{\circ}\text{F}$)
- Water collected in condenser and silica gel (grams)

- Gas volume at meter (ft³)
- Average stack static pressure, (inches of water)
- Average stack temperature (°F)
- Particulate mass collected in probe and expander section prior to top stage (grams)
- Particulate mass collected on each impactor stage (grams)
- Particulate mass on backup filter (grams)

The following calculations are performed by the calculator as a preliminary data check, however the results reported in the Appendix are the computer printouts detailing the calculations performed by the Data Reduction System developed by SoRI (EPA-600/7-78-042).

a. Total Mass Collected:

$$M_T = M_p + \sum_{L=t}^b M_s + M_f$$

where: M_T = total mass collected (grams)

M_p = mass collected in probe and impactor prior to top impactor stage (grams)

M_s = mass collected on impactor stage (grams)

$L=t$ = corresponds to the top impactor stage

$L=b$ = corresponds to the bottom impactor stage

M_f = mass collected on backup filter (grams)

b. Volume H₂O Vapor at STP:

where: V_{H_2O} = volume of water vapor @ STP (ft³)

W = water collected (grams)

STP = 29.92 in. Hg and 70°F

c. Meter Volume at STP:

$$V_{ms} = V_m \left(\frac{P_b - P_m}{T_m + 460} \right) \left(\frac{530}{29.92} \right)$$

where: V_{ms} = meter volume @ STP (ft^3)

V_m = meter volume (ft^3)

P_b = barometric pressure ("Hg)

P_m = average static pressure at meter (-"Hg)

T_m = average meter temperature ($^{\circ}\text{F}$)

d. Total Volume Sampled at STP, V_T (ft^3):

(1) Outlet impactor only

$$V_T = V_{H_2O} + V_{ms}$$

(2) Inlet impactor only

$$V_T = V_{ms}/F$$

where: F = dry gas fraction.

e. Percent Moisture, H_2O (%):

$$H_2O = (V_{H_2O}/V_T) (100)$$

f. Mass Concentration, C_m (grains/dscf):

$$C_m = (M_T/V_{ms}) (15.43 \text{ grains/gram})$$

g. Volume Sampled at Stack Conditions:

$$V_s = V_T \left(\frac{T_s + 460}{P_b + P_s/13.596} \right) \left(\frac{29.92}{530} \right)$$

where: V_s = volume sampled at stack conditions (ft^3)

T_s = average stack temperature ($^{\circ}\text{F}$).

P_s = average stack static pressure (+ " H_2O ")

h. Impactor Flow Rate:

$$Q_I = V_s/t$$

where: Q_I = impactor flow rate (acfm)

t = time (minutes)

i. Impactor Stage Size Cutoffs:

$$d_{pca} = \left(\frac{0.135 \pi \mu g d_c^3 N K_{p50}}{Q (10^{-8})} \right)^{1/2}$$

with $d_{pca} = d_p (C' \rho_p)^{1/2} 10^4$

and $C' = 1 + \frac{2\lambda}{d_p} [1.257 + 0.40 \exp (1 - 1.10 d_p/2\lambda)]$

where: C' = Cunningham slip correction factor

λ = mean free path of gas molecules, cm

d_p = particle diameter, cm

ρ_p = particle density, g/cm^3

d_{pca} = cut diameter, $\text{m} (\text{g/cm}^3)^{1/2}$

μg = gas viscosity, g/cm-sec

d_c = jet diameter, cm

N = number of jets in an impaction stage

K_{p50} = inertial impaction cut parameter at 50 percent efficiency*

Q = total flow rate, l/min

j. Percent Mass Collected on Backup Filter, P_F (%)

$$P_F = (M_f/M_T) 100$$

k. Percent Mass Collected on Each Impactor Stage, P_I (%)

$$P_I = (M_s/M_T) 100$$

l. Percent Mass Collected in Probe and Impactor Prior to Top Impactor Stage, P_p (%)

$$P_p = (M_p/M_T) 100$$

m. Cumulative Percent Mass $\leq$ Stage Cutoff Diameter for Each Impactor Stage, C_{pn} (%)

$$C_{pn} = \sum_{L=b}^{n=1} P_I + P_F$$

where: $L=b$ = corresponds to the bottom impactor stage

$L=n$ = corresponds to the impactor stage of interest

n. $dM/d \log D$ (grains/dscf):

$$dM/d \log D = \frac{(P_I/100) C_m}{(\log D_{s+1}) - (\log D_s)}$$

where: P_I = percent mass collected on a particular stage s (%)

o. Geometric Mean Diameter, D_M (μm):

$$D_M = \sqrt{D_{s+1} \times D_s}$$

* d_{50} from manufacturers calibration curves.

APPENDIX B-2

EXAMPLE CALCULATIONS DUAL CYCLONE SAMPLERS

1. Calculate stack gas velocity given flow rate by RTI

$$V_s = Q_s \times 288.13 \times \frac{(T_s + 460)}{A_s \times M_d \times P_s}$$

where V_s = velocity in afpm
 Q_s = flow rate in dscm/min
 T_s = gas temperature in °F
 A_s = stack or duct area in square inches
 M_d = mole fraction of dry gas - unitless
 P_s = stack gas absolute pressure in inches Hg.

and

$$288.13 = 35.31 \frac{\text{dscf}}{\text{dscm}} \times 29.92 \text{ in. Hg abs} \times \frac{144 \text{ in}^2/\text{ft}^2}{528^\circ\text{R}}$$

2. Gas viscosity calculation

$$= 174.4 + 0.406 (T_s^\circ\text{C}) \text{ in micropoise}$$

3. Isokinetic rate

$$\% I = \frac{1039 \times (T_s + 460) \times V_m \text{ STD}}{V_s + TT \times P_s \times M_d \times (DN)^2}$$

4. Cyclone III cut size

$$\text{Cyclone III } d_{50} = [0.024 - 3.09] Q_i^{-0.8} \text{ in microns}$$

where μ = viscosity in micropoise
 Q_i = sampler flow rate in acfm.

5. Cyclone X cut size

$$\text{Cyclone X } d_{50} = 15 \frac{Q_{cal}}{Q_i}$$

where $Q_{cal} = 69.5 \log - 150.0$

APPENDIX C

TOTAL PARTICULATE EXAMPLE CALCULATIONS (BY RTI)

Bayhouse Inlet

A. Concentration in gas check with those I gave you per

B. Kg generated/hour

$$(10^{-6}) \text{ conc in gas } \text{mg/ds.m}^3 \times (\text{Flow rate } \text{ds.m}^3/\text{min}) (60) = \text{Kg/hr}$$

Run #1

$$() (646.2 \times 6994) (60) = 292.2 \text{ Kg} = 644.1 \text{ lb/hr}$$

$$\text{Run #2 } () (600) (7487) (60) = 269.5 \text{ Kg} = 594.2$$

$$\text{Run #3 } () (431.8) (8165) (60) = 236.0 = 520.4$$

$$\text{Run #4 } () (422.7) (7551) (60) = 191.5 = 422.2$$

$$\text{Run #5 } () (390.1) (7905) (60) = 185.0 = 407.9$$

$$\underline{234.8} \quad \underline{517.8}$$

C. Avg Load during Test

Run #1	Meters reading at	MW in house	Avg Load
	950 - 1200	65 2.167	30.0
Run #2	1200 - 1600	130 4	32.5
3	1600 - 1810	70 2.167	32.3
4	1300 - 1530	83 2.5	33.2
5	1600 - 1807	69 2.11667	32.6

D. Generated/mw-h

Run #10	Particulate/h	MW	= 900 Kg/mw-h	
1	292.2	30	= 9.74 Kg/mw-h	21.47 lb/h
2	269.5	32.5	= 8.29	18.28
3	236.0	32.3	= 7.31	16.11
4	191.5	33.2	= 5.77	12.72
5	185.0	32.6	= 5.67	12.51
			<u>7.36</u>	<u>16.22</u>

Kg / Mg feed

(total Input)

10

Run #1 Power consumed 8-11 shift = 248 MW-hr
 Mix 95.16 Mg = 104.899 tons
 $95.16 \text{ Mg} \div 248 \text{ MW-hr} = 0.38371 \text{ Mg/MW-hr}$
 $0.38371 \text{ Mg/MW-hr} \times 20 \text{ MW-hr} = 11.5113 \text{ Mg/feed/hr}$
 $292.2 \div 11.5113 = 25.38 \text{ Kg/Mg feed} = 50.77 \text{ lb/ton}$

Run #2 $32.5 \text{ MW-hr} \times 0.38371 = 12.47 \text{ Mg/hr}$
 $269.5 \div 12.47 = 21.61 \text{ Kg/Mg} = 43.22 \text{ lb/ton}$

Run #3 Power on 4-12 shift 252 MW
 Mix 163.91 Mg = 180.68 tons
 $163.91 \div 252 = 0.6504 \text{ Mg/MW-hr}$
 $32.3 \text{ MW-hr} \times 0.6504 = 21.009 \text{ Mg/hr}$
 $236 \div 21.009 = 11.23 \text{ Kg/Mg} = 22.47 \text{ lb/ton}$

Run #4 Power consumed 8-4 shift = 181 MW-hr
 100.93 Mg = 111.247 tons
 $100.93 \div 181 = 0.5576 \text{ Mg/MW-hr}$
 $33.2 \text{ MW-hr} \times 0.5576 \text{ Mg/MW-hr} = 18.5131 \text{ Mg/hr}$
 $191.5 \div 18.513 = 10.34 \text{ Kg/Mg} = 20.69 \text{ lb/ton}$

Run #5 4-12 shift power = 273 MW-hr
 Mix feed 154.61 Mg = 170.43 tons

* Note: I have changed the value Sandy sent me for mix on this shift. I changed the amount of ± titanium coal from 3.24 tons to 23.24 tons. The 3.24 ton figure is severely different from mix feed on other shifts, leads to a drastic change in the quartz/coal ratio, and if actually feed would probably have clogged up the furnace to the point of non operability. Changing to 23.24 brings it back in line with previous feed and with the % theoretical reduction. It still doesn't add up to her figure of 176 tons total mix.

$154.61 \div 273 = 0.566337 \text{ Mg/MW-hr}$
 $32.6 \text{ MW} \times 0.566337 = 18.463 \text{ Mg/hr}$
 $185 \div 18.463 = 10.02 \text{ Kg/Mg} = 20.04 \text{ lb/ton}$

119 / 119 alloy 1200 Inlet 1

Run #1 power 248 MW-h 8-4 shift
Alloy 51,029 Kg - 112,500 lbs on shift
 $51,029 \div 248 = 0.20576 \text{ Kg/MW-h}$

$$30 \text{ MW} \times 0.20576 = 6.173 \text{ Mg/hr}$$

$$292.2 \div 6.173 = 47.34 \text{ Kg/Mg} = 94.67 \text{ lbs/ton}$$

Run #2 32.5 MW $\times 0.20576 = 6.687 \text{ Mg/hr}$

$$269.5 \div 6.687 = 40.30 \text{ Kg/Mg} = 80.60 \text{ lbs/ton}$$

Run #3 55,588 Mg Tapped on 4-12 shift (122,550 lbs)
252 MW-h on shift

$$55,588 \div 252 = 0.220587 \text{ Mg/MW-h}$$

$$32.3 \text{ MW} \times 0.220587 = 7.1250 \text{ Mg/hr}$$

$$236 \div 7.1250 = 33.12 \text{ Kg/Mg} = 66.25 \text{ lbs/ton}$$

Run #4 8-4 shift 39.621 Mg alloy = 87,350 lbs
181 MW on shift

$$39.621 \div 181 = 0.2189 \text{ Mg/MW-h}$$

$$33.2 \text{ MW} \times 0.2189 = 7.2675 \text{ Mg/hr}$$

$$191.5 \div 7.2675 = 26.35 \text{ Kg/Mg} = 52.70 \text{ lbs/ton}$$

Run #5 4-12 shift 56.835 Mg alloy = 125,300 lbs
power = 273 MW-h/shift

$$56.835 \div 273 = 0.20819 \text{ Mg/MW-h}$$

$$32.6 \times 0.20819 = 6.7869 \text{ Mg/hr}$$

$$185 \div 6.7869 = 27.26 \text{ Kg/Mg} = 54.52 \text{ lbs/ton}$$

Booth outlet

First step is to get flow rate leaving Booth.
Unfortunately we didn't get the gas temperature
of the U-Tube Coolers (or at least the correct temp).
The inlet gas temp meter in the Booth was
reading about 400°F, well above the temp at the inlet sample
location. Then either the meter was wrong or it read temp
before the inlet sample point.

Faced with this problem, I have chosen to estimate
the outlet flow rate based on comparison to other bag houses
operating at similar outlet temp. and ambient temp.
For Almet, the outlet flow rate is about 32 percent
ambient air with baghouse gas temp + ambient temp both
slightly higher than for Foots. This number quite similar
to other EPA tests where flow rate into grates of baghouse
measured by wind anemometer. I have, therefore, assumed
that 30 percent of the gas flow leaving the baghouse
is ambient air drawn into the baghouse grates. This
assumption to be pointed out in text of my report. It is
inappropriate to assume outlet flow rate same as
measured at inlet sample point. Even with this
assumption, emission is still less than NSPS of
0.23 Kg/mw-hr.

Then, to get outlet flow rate, multiply the
inlet flow rate by 1.4286
(ie $0.7(\text{outlet flow}) = \text{inlet flow}$
 $\text{outlet flow} = \frac{\text{inlet flow}}{0.7} = 1.4286 \text{ inlet flow}$)

Run #1	1.4286	X	6999 dsm ³ /min	=	9980 dsm ³ /min			
2, 3	(		)	[	$\frac{(7487 + 8165)}{2}$	]	=	11,180
	3	(		)	(7557)	=	10,790	

... you ... owner
 these check with data previously given to you

C. Emitted/hour $\text{mg/dm}^3 \times \text{dm}^3/\text{min} \times (10^{-6}) (\text{core in gas}) (\text{gas flow rate/min}) (60) = \text{Kg/hr}$

Run 1 () $(6.13) (9990) (60) = 3.67 \text{ Kg/hr} = 8.1 \text{ lb/hr}$
 2 () $(10.21) (11,180) (60) = 6.85 = 15.1$
 3 () $(12.92) (10,750) (60) = 8.36 = 18.4$

D. Avg Load

Run #1 meter readings at 950 - 1405 $\rightarrow 133 \text{ m.u.hrs in } 4.25 \text{ hr}$
 $= 31.3 \text{ m.u.hrs/hr}$

Run 2 meter readings at 1405 - 1710 $\rightarrow 102 \text{ m.u.hrs in } 3.0833$
 $= 33.1 \text{ m.u.hrs/hr}$

Run #3 meter readings at 1300 - 1600 $\rightarrow 94 \text{ m.u.hrs in } 3 \text{ hr}$
 $= 31.3 \text{ m.u.hrs/hr}$

E. Emitted / m.u.hrs

	Kg/hr	m.u.	Kg/m.u.hrs	lb/m.u.hrs
Run #1	$3.67 \pm$	31.3	$= 0.117$	0.258
2	$6.85 \pm$	33.1	$= 0.207$	0.456
3	$8.36 \pm$	31.3	$= 0.267$	0.589

F. Emitted / Mg feed

Power 8-a shift 248-m.u.hrs, 95.16 mg feed
 $= 0.38371 \text{ mg/m.u.hrs}$

Run #1 $0.38371 \times 31.3 = 12.01 \text{ mg/hr}$
 $3.67 \div 12.01 = 0.31 \text{ Kg/Mg} = 0.61 \text{ lb/lb}$

Run #2 4-12 shift 252 m.u.hrs, 163.91 mg feed
 $= 0.6504 \text{ mg/m.u.hrs}$

$0.6504 \times 33.1 \text{ m.u.} = 21.529 \text{ mg/hr}$
 $6.85 \div 21.529 = 0.32 \text{ Kg/Mg} = 0.61 \text{ lb/lb}$

run runs 17/ Mg feed

Run #3 power 8-4 = 181 mwh, 100.93 Mg feed
= 0.5576 Mg/mwh

power 4-12 = 273 mwh, 154.61 Mg feed
= 0.5663 Mg/mwh

Run was 1 hr 3 min on 8-4 shift

and 1 hr 57 min on 4-8 shift

then

8-4 $(1.05)(0.5576)(31.3) = 18.3255 \text{ Mg feed}$

4-12 $(1.95)(0.5663)(31.3) = 34.5641 \text{ Mg feed}$

52.8896 Mg feed in 3 hrs

= 17.6298 Mg feed/hour

$8.36 \div 17.6298 = 0.47 \text{ Kg/Mg feed} = 0.95 \text{ lb/ton}$

G. Emitted / Mg alloy

Run #1 8-4 shift Tapped 51.029 Mg, power 248 mwh
= 0.20576 Mg alloy / mwh

$0.20576 \times 31.3 = 6.4403 \text{ Mg/hour}$

$3.67 \div 6.44 = 0.57 \text{ Kg/Mg alloy} = 1.14 \text{ lb/ton}$

Run #2 4-12 shift Tapped 55.583 Mg, power 252 mwh
= 0.220567 Mg / mwh

$0.22057 \times 33.1 = 7.301 \text{ Mg/h}$

$6.85 \div 7.301 = 0.938 \text{ Kg/Mg alloy} = 1.88 \text{ lb/ton}$

Run #3 8-4 shift 39.621 Mg alloy, power 181 mwh
= 0.2189 Mg / mwh

4-12 shift 56.835 Mg alloy, power 273 mwh
= 0.20819 Mg / mwh

4-8 shift $(1.05 \text{ hours})(0.2189)(31.3 \text{ mwh}) = 7.194 \text{ Mg feed}$

8-4 shift $(1.95 \text{ hr})(0.20819)(31.3 \text{ mwh}) = 12.707 \text{ Mg feed}$

19.901 Mg feed in 3 hours

= 6.634 Mg/h

$8.36 \div 6.634 = 1.26 \text{ Kg/Mg} = 2.52 \text{ lb/ton}$

APPENDIX D-1

CASCADE IMPACTOR DATA REDUCTION SYSTEM PRINTOUTS,
BAGHOUSE INLET

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:20:30
 DATA FOR TEST BY CONTRACTOR GCA , AT SITE FOOT, ON DATE 31781, RUN NO. 1
 TEST COMMENTS: I.P. TEST TEPGOSILICON
 RUN COMMENTS: 11A15
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.8

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.267
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .257 ACFM

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

SAMPLING DURATION = 2.50 MIN

IMPACTOR PRESSURE DROP = .083 IN. OF HG

STACK TEMPERATURE = 351.0 F (177.2 C)

STACK PRESSURE = 27.40 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.70 O2 = 17.90 H2O = .40

CALC. MASS LOADING = 4.1289-001 GR/ACF

6.9328-001 GR/DNCF

9.4483+002 MG/ACH

1.5865+003 MG/DNCH

SAMPLING AT 76.3 % OF ISOKINETIC RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GH/CU.CH. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	19.92	17.36	15.33	10.22	6.83	3.79	1.84	1.13	.60
MASS (MG)	10.89	.18	.23	.01	.25	.51	.17	.78	.81
MG/DNCH/STAGE	1.01+003	1.66+001	2.12+001	9.23+001	2.31+001	4.71+001	1.57+001	7.20+001	7.48+001
CUM. % OF MASS	36.65	35.60	34.26	34.21	32.75	29.78	28.80	24.26	19.55
CUM. MASS (MG/ACH) < D50	3.46+002	3.36+002	3.24+002	3.23+002	3.09+002	2.81+002	2.72+002	2.29+002	1.85+002
CUM. MASS (MG/DNCH) < D50	5.81+002	5.65+002	5.46+002	5.43+002	5.20+002	4.73+002	4.57+002	3.85+002	3.10+002
CUM. MASS (GR/ACF) < D50	1.51+001	1.47+001	1.41+001	1.41+001	1.35+001	1.23+001	1.19+001	1.00+001	8.07+002
CUM. MASS (GR/DNCF) < D50	2.54+001	2.47+001	2.35+001	2.37+001	2.27+001	2.06+001	2.00+001	1.68+001	1.36+001
GEO. MEAN DIA. (MICRONS)	3.73+001	1.66+001	1.63+001	1.25+001	8.35+000	5.09+000	2.64+000	1.44+000	8.25+001
DN/DLOGD (MG/DNCH)	1.04+003	2.78+002	3.93+002	5.24+000	1.32+002	1.84+002	5.00+001	3.41+002	2.73+002
DN/DLOGD (MG/GR/ACH)	6.75+007	8.25+007	1.73+008	5.10+006	4.32+008	2.67+009	5.19+009	2.17+011	9.28+011

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGES 1 2 WITH D50= 17.36 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGES 1 2 WITH D50= 15.33 OMITTED FROM INTERPOLATION

*** LINEAR INTERPOLATION USED BETWEEN 1.8399127 3.789188

*** LINEAR INTERPOLATION USED BETWEEN 10.218366 19.924791

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

S.T. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*

CUM. MASS (MG/DNCH) 313.875 368.624 403.709 463.497 510.632 541.427 564.951 581.675

DN/DLOGD (MG/DNCH) .00 2.96+002 4.09+002 5.00+001 1.67+002 1.33+002 1.34+002 3.38+002

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:20:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE FOOT, ON DATE 31781, RUN NO. 2
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 11A35
 *** GAS COMPONENTS NORMALIZED TO CUM= 100%, NOT 98.8

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR OP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CURTOP CALIB
 1 264 .1639 .0000 .3050
 2 264 .1253 .0300 .4330
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3250
 5 264 .0533 .0000 .3590
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR PRESSURE DROP = .122 IN. OF HG

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

ASSURED PARTICLE DENSITY = 1.00GR/CM.
 MAX. PARTICLE DIAMETER = 70.0 MICRONS

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSURED PARTICLE DENSITY = 1.00GR/CM.

IMPACTOR STAGE
 STAGE INDEX NO.

IMPACTOR STAGE	STAGE INDEX NO.	CYCLORE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
D50 (MICRONS)	1	18.19	15.75	13.90	9.26	6.18	3.43	1.66	1.01	.53	.53/2.0
MASS (MG)	1	3.33	.12	.01	.01	.25	.04	.49	.45	.66	4.00
MG/DNCH/STAGE	1	1.61+002	5.70+000	4.75+001	6.65+000	1.19+001	1.90+000	2.33+001	2.14+001	3.14+001	1.90+002
CUM. % OF MASS	1	64.57	63.31	61.74	59.12	56.70	53.56	50.42	48.85	41.93	1.13+002
CUM. MASS (MG/ACH)	1	1.74+002	1.71+002	1.67+002	1.60+002	1.58+002	1.45+002	1.32+002	1.32+002	1.32+002	1.32+002
CUM. MASS (MG/DNCH)	1	2.93+002	2.87+002	2.80+002	2.68+002	2.66+002	2.43+002	2.21+002	2.21+002	2.21+002	2.21+002
CUM. MASS (GR/ACH)	1	7.62+002	7.47+002	7.46+002	7.28+002	6.97+002	6.92+002	6.32+002	5.76+002	5.76+002	5.76+002
CUM. MASS (GR/DNCH)	1	1.28+001	1.25+001	1.25+001	1.22+001	1.17+001	1.16+001	1.06+001	1.06+001	1.06+001	1.06+001
GEOM. MEAN DIA. (MICRONS)	1	3.57+001	1.69+001	1.48+001	1.13+001	7.57+000	4.60+000	2.38+000	1.30+000	1.30+000	1.30+000
DN/DLOGD (MG/DNCH)	1	2.74+002	9.10+001	8.79+001	3.77+001	6.77+001	7.41+000	7.13+001	8.78+010	8.78+010	8.78+010
DN/DLOGD (MG/ACH)	1	1.15+007	3.59+007	5.18+006	4.93+007	2.98+008	1.45+008	1.04+010	1.04+010	1.04+010	1.04+010

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE 1 WITH D50= 15.75 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE 2 WITH D50= 13.90 OMITTED FROM INTERPOLATION

*** LINEAR INTERPOLATION USED BETWEEN 3.4258346 6.1630958

*** LINEAR INTERPOLATION USED BETWEEN 9.2608150 18.189036

*** LINEAR INTERPOLATION USED BETWEEN 258.810 267.879 281.313 289.019 296.519

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*

CUM. MASS (MG/DNCH) 198.078 220.771 231.072 258.810 267.879 281.313 289.019 296.519

DN/DLOGD (MG/DNCH) 1.16+002 1.03+002 1.02+002 6.90+001 3.06+001 4.53+001 4.38+001 1.37+002

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 16:20:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE FOOT, CH DATE 31781, RUN NO. 3
 TEST COMMENTS: I.P. TEST REPRODUCTION
 RUN COMMENTS: 11015
 *** GAS COMPONENTS NORMALIZED TO SURF 100%, N2 98.8

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO. JETS DIAM. CURVE CALIB
 1 264 .1633 .0000 .4030
 2 264 .1253 .0000 .4100
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3350
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .382 ACFM

IMPACTOR PRESSURE DROP = .183 IN. OF HG

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

IMPACTOR PRESSURE DROP = 1.2622-001 GR/ACF

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:20:30
 DATA FOR TEST BY COMPACTION CCA, AT SITE FOOT, ON DATE 31701, RUN NO. 4
 TEST COMMENTS: I.P. TEST FERTUGILICCH
 RUN COMMENTS: 11865
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NGT 98.8

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUM. DP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4630
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3250
 5 264 .0533 .0000 .3650
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3520
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .335 ACFM

SAMPLING DURATION = 6.00 MIN

IMPACTOR PRESSURE DROP = .141 IN. OF HG

IMPACTOR TEMPERATURE = 351.0 F (177.2 C)

STACK PRESSURE = 27.40 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.70 O2 = 17.90 H2O = .40

7.5374+002 MG/ACM

CALC. MASS LOADING = 3.2938-001 GR/ACF
 SAMPLING AT 99.5 % OF ISOINETIC RATE

1.2656+003 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00G/CM³

MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	17.59	15.19	13.41	8.93	5.96	3.30	1.59	.97	.51	.51/2.0
MASS (MG)	13.76	.00	.11	.05	.19	.69	2.12	2.49	3.60	19.89
MG/DNCH/STAGE	4.06+002	2.95-002	3.25+000	1.48+000	5.61+000	2.04+001	6.25+001	7.33+001	1.06+002	5.87+002
CUM. % OF MASS	67.93	67.92	67.67	67.55	67.11	65.50	63.56	54.75	46.36	
CUM. MASS (MG/ACM) < D50	5.12+002	5.12+002	5.10+002	5.09+002	5.04+002	4.94+002	4.56+002	4.13+002	3.49+002	
CUM. MASS (MG/DNCH) < D50	8.60+002	8.60+002	8.56+002	8.55+002	8.49+002	8.29+002	7.66+002	6.93+002	5.87+002	
CUM. MASS (GR/ACF) < D50	2.24-001	2.24-001	2.23-001	2.23-001	2.21-001	2.16-001	1.59-001	1.80-001	1.53-001	
CUM. MASS (GR/DNCH) < D50	3.76-001	3.76-001	3.74-001	3.74-001	3.71-001	3.62-001	3.35-001	3.03-001	2.56-001	
GEOM. MEAN DIA. (MICRONS)	3.51+001	1.63+001	1.43+001	1.09+001	7.30+003	4.44+002	2.29+000	1.25+000	7.06-001	3.61-001
DN/DLOGD (MG/DNCH)	6.77+002	4.63-001	6.00+001	8.36+000	3.17+001	7.93+001	1.93+002	3.43+002	3.79+002	1.95+003
DN/DLOGD (NUMBER/DNCH)	2.99+007	2.02+005	3.94+007	1.22+007	1.57+003	1.73+009	3.13+010	3.38+011	2.06+012	7.88+013

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 15.19 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 13.41 OMITTED FROM INTERPOLATION

*** LINEAR INTERPOLATION USED BETWEEN 8.932457 17.591031

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

ST. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*
 CUM. MASS (MG/DNCH) 621.127 697.539 733.281 809.959 849.433 855.726 858.568 870.291
 DN/DLOGD (MG/DNCH) 3.87+002 3.78+002 3.42+002 1.83+002 4.52+001 1.61+001 1.61+001 3.46+002

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR CCA , AT SITE FOOT, ON DATE 31781, RUN NO. 5
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 21A15
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUM. CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4160
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3520
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .331 ACFM
 IMPACTOR PRESSURE DROP = .135 IN. OF HG
 IMPACTOR TEMPERATURE = 366.0 F (185.6 C)
 STACK TEMPERATURE = 366.0 F (185.6 C)
 DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 H2 = 80.00
 CALC. MASS LOADING = 2.3615-001 GR/ACF
 SAMPLING AT 98.3 % OF ISOKINETIC RATE
 4.0383-001 GR/DNCF
 5.4040+002 MG/ACH
 9.2411+002 MG/DNCH

IMPACTOR TEMPERATURE = 366.0 F (185.6 C) SAMPLING DURATION = 6.00 MIN
 STACK PRESSURE = 27.29 INCHES OF HG
 H2O = .00
 O2 = 18.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

MAX. PARTICLE DIAMETER = 70.0 MICRONS

ASSUMED PARTICLE DENSITY = 1.006G/CCU.CH.

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE 1	S1 2	S2 3	S3 4	S4 5	S5 6	S6 7	S7 8	S8 9	FILTER 10
D50 (MICRONS)	13.15	15.39	13.59	9.05	6.64	3.34	1.61	.99	.52	.52/2.0
MASS (MG)	4.24	.00	.57	.40	.80	.62	.95	1.59	2.48	18.74
MG/DNCH/STAGE	1.29+002	3.04+002	1.73+001	1.22+001	2.43+001	1.89+001	2.89+001	4.83+001	7.54+001	5.70+002
CUM. % OF MASS	86.05	86.05	84.17	82.65	80.22	78.18	75.06	69.82	61.66	
CUM. MASS (MG/ACH) < D50	4.65+002	4.65+002	4.55+002	4.48+002	4.31+002	4.22+002	4.06+002	3.77+002	3.33+002	
CUM. MASS (MG/DNCH) < D50	7.95+002	7.95+002	7.73+002	7.66+002	7.41+002	7.22+002	6.94+002	6.45+002	5.70+002	
CUM. MASS (GR/ACH) < D50	2.03-001	2.03-001	1.99-001	1.96-001	1.89-001	1.85-001	1.77-001	1.65-001	1.46-001	
CUM. MASS (GR/DNCF) < D50	3.47-001	3.47-001	3.40-001	3.35-001	3.24-001	3.16-001	3.03-001	2.82-001	2.49-001	
CUM. MASS (MG/DNCH) < D50	3.56+001	1.67+001	1.45+001	1.11+001	7.37+000	4.49+000	2.32+000	1.26+000	7.13-001	3.65-001
GEOM. MEAN DIA. (MICRONS)	2.20+002	4.25-001	3.20+002	6.09+001	1.39+002	7.34+001	9.14+001	2.25+002	2.69+002	1.89+003
D50/DNCH (MG/DNCH)	9.23+006	1.74+005	2.32+003	9.65+007	6.55+003	1.55+009	1.39+010	2.15+011	1.42+012	7.43+013
DN/DLOCD (NUMBER/DNCH)										

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 15.39 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 13.59 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STO. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*
 CUM. MASS (MG/DNCH) 593.590 647.069 671.466 711.703 741.618 768.357 794.610 800.653
 DN/DLOCD (MG/DNCH) 2.79+002 2.59+002 2.27+002 8.94+001 1.26+002 6.81+001 1.17+002 1.58+002

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR GCA, AT SITE FOOT, ON DATE 31781, RUN NO. 6

TEST COMMENTS: I.P. TEST FETTERLICON

RUN COMMENTS: 21AGS

*** GAS COMPONENTS NORMALIZED TO 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUM-DP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3050
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .326 ACFM

IMPACTOR PRESSURE DROP = .131 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .131 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00G/CM³.CH. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.										
D50 (MICRONS)	18.28	15.51	13.69	9.12	6.09	3.37	1.63	.99	.52	.52/2.0
MASS (MG)	3.50	.13	.09	.35	.34	.51	1.68	1.64	1.72	15.07
MG/DNCH/STAGE	2.16+002	8.03+000	5.56+000	2.16+001	2.10+001	3.15+001	6.67+001	1.01+002	1.06+002	9.31+002
CUM. % OF MASS	85.67	85.14	84.77	83.34	81.85	79.86	75.44	68.73	61.69	
CUM. MASS (MG/ACH)	7.56+002	7.51+002	7.48+002	7.35+002	7.23+002	7.04+002	6.65+002	6.06+002	5.44+002	
CUM. MASS (MG/DNCH) < D50	1.29+003	1.23+003	1.20+003	1.26+003	1.24+003	1.20+003	1.14+003	1.04+003	9.31+002	
CUM. MASS (MG/ACH) < D50	3.30+001	3.20+001	3.27+001	3.21+001	3.16+001	3.08+001	2.91+001	2.65+001	2.38+001	
CUM. MASS (GR/ACH) < D50	5.65+001	5.61+001	5.59+001	5.49+001	5.40+001	5.26+001	4.97+001	4.53+001	4.07+001	
CUM. MASS (GR/DNCH) < D50	3.53+001	1.60+001	1.46+001	1.12+001	7.45+003	4.53+003	2.34+003	1.27+003	7.20+001	
GEOM. MEAN DIA. (MICRONS)	3.71+002	1.13+002	1.03+002	1.22+002	1.20+002	1.23+002	2.11+002	4.73+002	3.79+002	
DM/DLOGD (MG/DNCH)	1.55+007	4.51+007	6.34+007	1.68+003	5.52+003	2.52+009	3.14+010	4.39+011	1.94+012	
DM/DLOGD (MG/ACH)										

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR TO INVERTED

MEASURED DATA FOR STAGES 1 WITH D50= 15.51 CHITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR TO INVERTED

MEASURED DATA FOR STAGES 2 WITH D50= 13.69 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*

CUM. MASS (MG/DNCH) 957.431 1038.336 1059.480 1191.060 1235.439 1258.843 1277.057 1299.140

CUM. MASS (MG/ACH) 3.56+002 4.95+002 4.60+002 2.02+002 1.21+002 5.44+001 1.54+002 2.25+002

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR CCA, AT SITE FOOT, ON DATE 31781, RUN NO. 7

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 21015

*** GAS COMPONENTS NORMALIZED TO SUM= 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO. JETS DIAM. CURTOP CALIB

1	264	.1638	.0030	.3050
2	264	.1253	.0000	.4030
3	264	.0948	.0000	.4100
4	264	.0759	.0000	.3650
5	264	.0533	.0000	.3690
6	264	.0343	.1760	.3600
7	264	.0254	.2940	.3620
8	156	.0254	1.0000	.2740

IMPACTOR FLOWRATE = .398 ACFM

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR PRESSURE DROP = .185 IN. OF HG

PARTICULATE DATA REDUCTION AND EMRY SYSTEM DATA FOR TEST BY CONTRACTOR GCA, AT SITE FOOT, ON DATE

TEST COMMENTS: I.P. TEST FERROSILICCH
 RUN COMMENTS: 21855
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%. NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR OP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CURDP CALID
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4830
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3520
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .327 ACFM

IMPACTOR PRESSURE DROP = .132 IN. OF HG

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

IMPACTOR TEMPERATURE = 366.0 F (185.6 C)

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/81 17:20:39
 DATA FOR TEST BY CONTRACTOR CCA, AT SITE FOOT, ON DATE 31781, RUN NO. 9
 TEST COMMENTS: 1. P. TEST FERGOLIGN
 RUN COMMENTS: 3.145
 *** GAS COMPONENTS NORMALIZED TO SOME 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MDEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO. JETS DIAM. CUR-IP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0030 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3950
 5 264 .0533 .0000 .3590
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3820
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .332 ACFM

IMPACTOR PRESSURE DROP = .141 IN. OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00

CALC. MASS LOADING = 1.1118-001 GR/ACF
 SAMPLING AT 98.6 % OF ISOKINETIC RATE

SAMPLING DURATION = 6.00 MIN
 STACK PRESSURE = 27.40 INCHES OF HG
 O2 = 18.00 H2O = .00
 4.1971+002 MG/DNCH

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

STACK TEMPERATURE = 340.0 F (171.1 C)

2.5442+002 MG/ACM

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.005H/CM. CH. MAX. PARTICLE DIAHETER = 70.0 MICRONS

IMPACTOR STAGE
 STAGE INDEX NO.

CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	17.41	15.20	13.42	8.94	5.97	3.30	1.60	.98	.51
	6.04	.35	.00	.10	.05	.20	.38	.56	.71
	2.00+002	1.00+001	2.92+002	2.92+000	1.46+000	5.85+000	1.11+001	1.64+001	2.08+001
	52.34	49.50	49.89	49.20	43.95	47.45	44.81	40.90	35.96
	1.33+002	1.27+002	1.27+002	1.25+002	1.24+002	1.21+002	1.14+002	1.04+002	9.15+001
	CUM. MASS (MG/ACM) < D50	2.20+002	2.09+002	2.06+002	2.03+002	1.99+002	1.83+002	1.72+002	1.51+002
	CUM. MASS (MG/DNCH) < D50	5.82+002	5.55+002	5.47+002	5.43+002	5.29+002	4.89+002	4.55+002	4.00+002
	CUM. MASS (GR/ACF) < D50	9.60+002	9.15+002	9.02+002	8.95+002	8.70+002	8.22+002	7.50+002	6.59+002
	CUM. MASS (GR/DNCF) < D50	3.49+001	1.63+001	1.43+001	1.10+001	7.30+000	4.44+000	2.30+000	1.25+000
	GEOM. MEAN DIA. (MICRONS)	3.31+002	1.74+002	5.41+001	1.66+001	8.33+000	2.28+001	7.66+001	7.44+001
	DM/DLOGD (MG/DNCH)	1.49+007	7.71+007	3.55+005	2.41+007	4.09+007	4.97+008	5.54+009	7.51+010
	DM/DLOGD (MG/DNCH)								

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR CR INVERTED

MEASURED DATA FOR STAGES 1 WITH D50= 15.20 OBTAINED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR CR INVERTED

MEASURED DATA FOR STAGES 2 WITH D50= 13.42 OBTAINED FROM INTERPOLATION

*** LINEAR INTERPOLATION USED BETWEEN 5.966266 8.937909

*** LINEAR INTERPOLATION USED BETWEEN 8.937909 17.407903

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*

CUM. MASS (MG/DNCH) 157.184 172.630 180.783 195.409 205.034 208.690 216.721 227.466

DM/DLOGD (MG/DNCH) 7.39+001 8.41+001 7.65+001 3.36+001 1.17+001 4.56+001 4.56+001 2.04+002

PARTICULATE DATA PRODUCTION AND ENTRY SYSTEM 11/29/03 10:00:00
 DATA FOR TEST BY COMPACTOR COCA, AT SITE FOOT, CH DATE 31781, RUN NO. 10
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 3185
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR OR SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMSP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4930
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3050
 5 264 .0533 .0000 .2570
 6 264 .0343 .1769 .2600
 7 264 .0254 .2840 .2620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .335 ACFH

IMPACTOR PRESSURE DROP = .143 IN. OF HG

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

*** GASES COMPONENTS NORMALIZED TO SUM= 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0

MODELS: MARK 3 IMPACTOR DR SCALING FACTOR: 1.207

STAGE	NO. JETS	DIAM.	CUMDP	CALIB
1	264	.1638	.0050	.3050
2	264	.1253	.0050	.4030
3	264	.0948	.0050	.4100
4	264	.0759	.0000	.3850
5	264	.0533	.0000	.3690
6	264	.0343	.1720	.3000
7	264	.0254	.2940	.3020
8	156	.0254	1.0000	.2740

IMPACTOR FLOWRATE = .333 ACFM

IMPACTOR PRESSURE DROP = .141 IN. OF HG

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR PRESSURE DROP = .141 IN. OF HG

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

IMPACTOR TEMPERATURE = 340.0 F (171.1 C)

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:20:30
 DATA FOR TEST BY COMPACTOR GCA , AT SITE FOOT, ON DATE 31781, RUN NO. 12
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 31205
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 99.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CURT. CALID
 1 264 .1639 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .320 ACFM IMPACTOR TEMPERATURE = 340.0 F (171.1 C) SAMPLING DURATION = 3.00 MIN
 IMPACTOR PRESSURE DROP = .131 IN. OF HG STACK TEMPERATURE = 340.0 F (171.1 C) STACK PRESSURE = 27.40 INCHES OF HG
 DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 80.00 O2 = 18.00 H2O = .00
 CALC. MASS LOADING = 1.2944-001 GR/ACF 2.9620+002 MG/ACM 4.8864+002 MG/DNCH
 SAMPLING AT 95.0 % OF ISOKINETIC RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CCU.CM. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
1	17.71	15.48	13.67	9.11	6.08	3.37	1.63	1.00	.53	.53/2.0
	4.35	.00	.14	.01	.11	.20	.00	.27	.12	2.85
	2.64+002	6.07-002	8.50+000	6.07-001	6.63+000	1.21+001	6.07-002	1.64+001	7.28+000	1.73+002
	45.98	45.96	44.23	44.10	42.73	40.25	40.24	36.89	35.19	
	1.36+002	1.35+002	1.31+002	1.27+002	1.27+002	1.19+002	1.19+002	1.09+002	1.05+002	
	2.25+002	2.25+002	2.16+002	2.15+002	2.09+002	1.97+002	1.97+002	1.89+002	1.73+002	
	5.95-002	5.95-002	5.72-002	5.71-002	5.53-002	5.21-002	5.21-002	4.77-002	4.59-002	
	9.32-002	9.01-002	9.44-002	9.45-002	9.13-002	8.59-002	8.59-002	7.88-002	7.56-002	
	3.52+001	1.66+001	1.45+001	1.12+001	7.44+000	4.53+000	2.34+000	1.27+000	7.24-001	3.72-001
	4.42+002	1.04+000	1.57+002	3.44+000	3.09+001	4.73+001	1.92-001	7.68+001	2.62+001	5.75+002
	1.93+007	4.37+005	9.75+007	4.73+006	1.76+008	9.75+008	2.86+007	7.08+010	1.32+011	2.14+013

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 15.48 OBTAINED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 13.67 OBTAINED FROM INTERPOLATION

*** LINEAR INTERPOLATION USED BETWEEN .52545142 .99704239

*** LINEAR INTERPOLATION USED BETWEEN 1.6297005 3.3606247

*** LINEAR INTERPOLATION USED BETWEEN 9.1065739 17.711725

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000 20.000*

CUM. MASS (MG/DNCH) 174.926 180.374 189.414 196.656 208.577 216.733 222.368 231.873

DN/DLOGD (MG/DNCH) 2.62+001 6.50+001 7.92+001 1.97-001 4.16+001 3.18+001 3.17+001 2.31+002

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:00:30
 DATA FOR TEST BY CONTRACTOR CCA, AT SITE FOOT, ON DATE 31781, RUN NO. 13
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 41A15
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.3

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO. JETS	DIAM.	CUMUL	CALIB
1	264	.1638	.0000	.3050
2	264	.1253	.0000	.4030
3	264	.0948	.0000	.4100
4	264	.0759	.0000	.3050
5	264	.0533	.0000	.3090
6	264	.0343	.1760	.3600
7	264	.0254	.2940	.3620
8	156	.0254	1.0000	.2740

IMPACTOR FLOWRATE = .341 ACFM

IMPACTOR TEMPERATURE = 360.0 F (162.2 C)

SAMPLING DURATION = 5.00 MIN

IMPACTOR PRESSURE DROP = .143 IN. OF HG STACK TEMPERATURE = 360.0 F (182.2 C) STACK PRESSURE = 27.08 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 H2 = 79.70 O2 = 17.90 H2O = .43

CALC. MASS LOADINGS = 1.3169-001 GR/ACF
 SAMPLING AT 101.3 % OF ISOKINETIC RATE

2.2618-001 GR/DNCF

5.1759+002 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.005H/CM³ MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE	STAGE INDEX NO.	CYCLONE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
D50 (MICRONS)		17.69	15.11	13.34	8.88	5.93	3.28	1.58	.97	.50	.50/2.0
MASS (MG)		2.92	.05	.01	.07	.03	.27	.35	.74	1.99	8.12
MG/DNCH/STAGE		1.04+002	1.78+000	3.56+001	2.49+000	1.07+000	9.60+000	1.25+001	2.63+001	7.08+001	2.89+002
CUM. % OF MASS	< D50	79.93	79.59	79.52	79.04	78.93	76.98	74.57	69.48	55.81	
CUM. MASS (MG/ACF) < D50		2.41+002	2.40+002	2.40+002	2.35+002	2.33+002	2.33+002	2.25+002	2.09+002	1.68+002	
CUM. MASS (MG/DNCH) < D50		4.14+002	4.12+002	4.12+002	4.09+002	4.08+002	3.92+002	3.66+002	3.60+002	2.89+002	
CUM. MASS (GR/ACF) < D50		1.05+001	1.05+001	1.05+001	1.04+001	1.04+001	1.01+001	9.82+002	9.15+002	7.35+002	
CUM. MASS (GR/DNCF) < D50		1.81+001	1.80+001	1.80+001	1.79+001	1.78+001	1.74+001	1.69+001	1.57+001	1.26+001	
GEO. MEAN DIA. (MICRONS)		3.52+001	1.63+001	1.42+001	1.09+001	7.26+000	4.41+000	2.28+000	1.24+000	6.98+001	3.57+001
CH/DLOGD (MG/DNCH)		1.74+002	2.60+001	6.58+000	1.41+001	6.03+000	3.74+001	3.93+001	1.23+002	2.51+002	9.60+002
DN/DLOGD (NUMBER/DNCH)		7.62+006	1.14+007	4.39+006	2.09+007	3.04+007	8.32+008	6.35+009	1.24+011	1.41+012	4.03+013

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGES 1 WITH D50= 15.11 OBTAINED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGES 2 WITH D50= 13.34 OBTAINED FROM INTERPOLATION

*** LINEAR INTERPOLATION USED BETWEEN 8.88370% 17.68352

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS)	625	1.000	1.250	2.500	6.000	10.000	15.000	20.000*
CUM. MASS (MG/DNCH)	316.747	362.011	375.207	393.855	408.036	409.834	412.607	416.735
DN/DLOGD (MG/DNCH)	2.76+002	1.59+002	1.21+002	3.91+001	1.13+001	1.55+001	9.35+001	

STG 51300100 SHIPBOARD 02717000 CS 1003 = 1003 101 1003

TYPE: ANDERSEN PLATE SET ID: 0 SCALING FACTOR: 1.287

IMPACTOR FLOWRATE = .328 ACFM

IMPACTION PRESSURE (PERCENT)

DRY GAS COMPOSITION (PERCENT)

97.4 % OF LOOKING AT

ASSUMED PARTICLE DENSITY = 1.00GM/CU.C

IMPACTOR STAGE

050 (MICRONS)	18.01	7.4%
---------------	-------	------

FIG/DRUG/STAGE	CUTL. % OF MASS	< D50	44.36
		< D50	6.25+001

CUM. MASS (GR/ACF)	< D50
2.73-00	
4.69-00	

DM/DLOC (HS/DNCH)	DM/DLOC (NUTBER/DNCH)
2.20+00	9.74+00

*** CUT POINTS FOR STAGES 1

*** LINEAR INTERPOLATION USED BETWEEN
*** LINEAR INTERPOLATION USED BETWEEN

[illegible]

10

Figure 1. The effect of the concentration of the *Agrobacterium* strain on the transformation efficiency of *Agrobacterium* strain.

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:20:30
 DATA FOR TEST BY CONTRACTOR GCA, AT SITE FOOT, CN DATE 31781, RUN NO. 21
 TEST COMMENTS: I.P. TEST FERGUSILLION
 RUN COMMENTS: 41015
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.8

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.267

STAGE NO. JETS IMPACTOR CALIB
 1 264 .1639 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3050
 5 264 .0533 .0000 .2690
 6 264 .0343 .1760 .3600
 7 264 .0254 .0254 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .370 ACFH

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .168 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM 11/29/83 10:20:39
 DATA FOR TEST BY CONTRACTOR CCA , AT SITE FOOT, CH DATE 31781, RUN NO. 22
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 41835
 *** GAS COMPOSITIONS NORMALIZED SO SUM= 100%, NOT 98.8

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CURDP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3050
 5 264 .0533 .0000 .2690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2540 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .387 ACFM

IMPACTOR PRESSURE DROP = .184 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR PRESSURE DROP = .184 IN. OF HG

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

IMPACTOR TEMPERATURE = 360.0 F (182.2 C)

TEST COMMENTS: I.P. TEST PERFORMED

RUN COMMENTS: 51815

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.2

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: MICRERSEN PLATE SET ID: 0

MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO. JETS DIAM. CUM. DP CALIB

1 264 .1638 .0000 .3050

2 264 .1253 .0000 .4350

3 264 .0948 .0000 .4100

4 264 .0759 .0000 .3350

5 264 .0533 .0000 .3690

6 264 .0343 .1760 .3600

7 264 .0254 .2540 .3620

8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .363 ACFM

IMPACTOR PRESSURE DROP = .159 IN. OF HG

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR PRESSURE = 26.87 INCHES OF HG

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

IMPACTOR TEMPERATURE = 367.0 F (166.1 C)

APPENDIX D-2

CASCADE IMPACTOR DATA REDUCTION SYSTEM PRINTOUTS,
BAGHOUSE OUTLET

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 10A

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.5

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0

MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO. JETS DIAM. CUMDP CALIB

1 264 .1638 .0000 .3050

2 264 .1253 .0000 .4030

3 264 .0948 .0000 .4100

4 264 .0759 .0000 .3200

5 264 .0533 .0000 .3690

6 264 .0343 .1760 .3600

7 264 .0254 .2940 .3620

8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .383 ACFM

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

IMPACTOR PRESSURE DROP = .248 IN. OF HG

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR 6CA , AT SITE FOOT, ON DATE 31781, RUN NO. 15

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 20A

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 99.7

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.237
 STAGE NO. JETS DIAM. CURDP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3950
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3520
 8 155 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .396 ACFM

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

SAMPLING DURATION = 90.00 MIN

IMPACTOR PRESSURE DROP = .257 IN. OF HG STACK TEMPERATURE = 199.0 F (92.8 C) STACK PRESSURE = 29.10 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.60 O2 = 17.90 H2O = .60

CALC. MASS LOADING = 2.5591-003 GR/ACF

3.2930-003 GR/DNCF

7.5355+000 MG/DNCH

SAMPLING AT 168.6 % OF ISOINET.C RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM.CM. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	NOZZLE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
D50 (MICRONS)	12.99	12.99	11.47	7.64	5.11	2.84	1.38	.85	.45	.45/2.0
MASS (MG)	4.70-001	1.28-003	6.89-001	7.14-001	7.52-001	4.72-001	8.93-001	3.95-001	5.99-001	2.55+000
MG/DNCH/STAGE	93.76	93.74	84.60	75.13	65.14	58.88	47.04	41.79	33.84	
CUM. % OF MASS	5.49+000	5.49+000	4.95+000	4.40+000	3.81+000	3.45+000	2.75+000	2.45+000	1.93+000	
CUM. MASS (MG/ACF) < D50	7.06+000	7.06+000	6.38+000	5.66+000	4.91+000	4.44+000	3.54+000	3.15+000	2.55+000	
CUM. MASS (MG/DNCH) < D50	2.40-003	2.40-003	2.17-003	1.92-003	1.67-003	1.51-003	1.20-003	1.07-003	0.66-004	
CUM. MASS (GR/ACF) < D50	3.09-003	3.09-003	2.79-003	2.47-003	2.15-003	1.94-003	1.55-003	1.38-003	1.11-003	
CUM. MASS (GR/DNCF) < D50	3.02+001	1.30+001	1.22+001	9.36+000	6.25+000	3.81+000	1.98+000	1.08+000	6.17-001	3.18-001
GEO. MEAN DIA. (MICRONS)	6.43-001	1.07+001	1.27+001	4.05+000	4.30+000	1.85+000	2.84+000	1.87+000	2.18+000	8.47+000
DH/DLOGD (MG/DNCH)	4.48+004	9.29+006	1.34+007	9.43+006	3.36+007	6.40+007	7.04+008	2.84+009	1.77+010	5.03+011
DN/DLOGD (NUMBER/DNCH)										

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 12.99 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 2 WITH D50= 11.47 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS)	2.874	3.266	3.453	4.306	5.177	6.448	7.352	7.532	15.000*	20.000*
CUM. MASS (MG/DNCH)	2.874	3.266	3.453	4.306	5.177	6.448	7.352	7.532	15.000*	20.000*
DH/DLOGD (MG/DNCH)	2.17+000	1.75+000	2.11+000	2.49+000	4.14+000	6.08+000	3.31+000	2.86-001		

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 108

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.5

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUMDP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .396 ACFM

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

IMPACTOR TEMPERATURE = 180.0 F (82.2 C)

IMPACTOR PRESSURE DROP = .265 IN. OF HG

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR GCA , AT SITE FOOT, ON DATE 31781, RUN NO. 17

TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 208
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.7

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CURDP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3500
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .388 ACFM

IMPACTOR PRESSURE DROP = .247 IN. OF HG

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR PRESSURE DROP = .247 IN. OF HG

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR GCA , AT SITE FOOT, ON DATE 31781, RUN NO. 18
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 30A
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.7

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1638	.0000	.3050
2	264	.1253	.0000	.4030
3	264	.0948	.0000	.4100
4	264	.0759	.0000	.3850
5	264	.0533	.0000	.3690
6	264	.0343	.1760	.3600
7	264	.0254	.2940	.3620
8	156	.0254	1.0000	.2740

IMPACTOR FLOWRATE = .401 ACFM IMPACTOR TEMPERATURE = 199.0 F (92.8 C) SAMPLING DURATION = 90.00 MIN
 IMPACTOR PRESSURE DROP = .264 IN. OF HG STACK TEMPERATURE = 199.0 F (92.8 C) STACK PRESSURE = 29.10 INCHES OF HG
 DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.60 O2 = 17.90 H2O = .50
 CALC. MASS LOADING = 3.9340-003 GP/ACF 5.0571-003 GR/DNCF 9.0023+000 MG/ACH 1.1572+001 MG/DNCH
 SAMPLING AT 170.7 % OF ISOINETIC RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSURED PARTICLE DENSITY = 1.00GM/CU.CH. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE	NOZZLE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.										
D50 (MICRONS)	12.91	12.91	11.40	7.60	5.08	2.82	1.37	.84	.45	.45/2.0
MASS (MG)	1.41	1.77+000	1.26-003	7.17-001	1.13+000	7.17-001	4.15-001	8.81-001	1.13+000	1.57+000
MG/DNCH/STAGE	1.41	84.67	78.48	68.70	62.50	58.91	51.30	41.52	27.93	2.57
CUM. % OF MASS										
CUM. MASS (MG/ACH) < D50		7.62+000	7.06+000	6.18+000	5.63+000	5.30+000	4.62+000	3.74+000	2.51+000	
CUM. MASS (MG/DNCH) < D50		9.89+000	9.89+000	9.08+000	7.23+000	6.82+000	5.94+000	4.81+000	3.23+000	
CUM. MASS (GR/ACH) < D50		3.33-003	3.33-003	3.09-003	2.70-003	2.46-003	2.32-003	2.02-003	1.63-003	
CUM. MASS (GR/DNCF) < D50		4.28-003	4.28-003	3.97-003	3.47-003	3.16-003	2.98-003	2.59-003	2.10-003	
GEOM. MEAN DIA. (MICRONS)		3.01+001	1.29+001	1.21+001	9.31+000	6.21+000	3.78+000	1.96+000	1.07+000	
DM/DLOGD (MG/DNCH)		2.41+000	1.36+001	1.33+001	6.42+000	4.09+003	1.62+000	2.81+000	5.35+000	
DM/DLOGD (NUMBER/DNCH)		1.70+005	1.20+007	1.42+007	1.52+007	3.27+007	5.73+007	7.08+008	8.30+009	

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 12.91 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 11.40 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS)	.625	1.000	1.250	2.500	6.000	10.000	15.000*	20.000*
CUM. MASS (MG/DNCH)	4.083	5.259	5.760	6.700	7.458	8.986	10.274	10.931
DM/DLOGD (MG/DNCH)	5.70+000	5.65+000	4.68+000	2.37+000	3.81+000	7.98+000	6.54+000	4.09+000

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 303

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.7

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO.	JETS	DIAM.	CUMDP	CALIB
1	264	.1638	.0000	.3050
2	264	.1253	.0000	.4030
3	264	.0948	.0000	.4100
4	264	.0759	.0000	.3850
5	264	.0533	.0000	.3650
6	264	.0343	.1760	.3600
7	264	.0254	.2940	.3620
8	156	.0254	1.0000	.2740

IMPACTOR FLOWRATE = .395 ACFM

IMPACTOR TEMPERATURE = 199.0 F (92.8 C)

SAMPLING DURATION = 90.00 MIN

IMPACTOR PRESSURE DROP = .256 IN. OF HG

STACK TEMPERATURE = 199.0 F (92.8 C)

STACK PRESSURE = 29.10 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.60 O2 = 17.90 H2O = .50

1.5246-003 GR/DNCF

3.4887+000 MG/DNCH

CALC. MASS LOADING = 1.1860-003 GR/ACF

2.7139+000 MG/ACH

SAMPLING AT 168.8 % OF ISOINETIC RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.006G/CM.
 MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE	NOZZLE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	13.01	13.01	11.49	7.65	5.12	2.84	1.38	.85	.45	.45/2.0
MASS (MG)	1.24	.00	.00	.04	.18	.28	.15	.29	.00	.55
MG/DNCH/STAGE	1.50+000	1.28-003	1.28-003	5.11-002	2.30-001	3.53-001	1.92-001	3.70-001	1.28-003	7.02-001
CUM. % OF MASS	54.65	54.61	54.58	53.11	46.52	36.27	30.78	20.17	20.13	
CUM. MASS (MG/ACH) < D50	1.48+000	1.48+000	1.48+000	1.44+000	1.26+000	9.84-001	8.35-001	5.47-001	5.46-001	
CUM. MASS (MG/DNCH) < D50	1.91+000	1.91+000	1.90+000	1.85+000	1.62+000	1.27+000	1.07+000	7.04-001	7.02-001	
CUM. MASS (GR/ACF) < D50	6.48-004	6.48-004	6.47-004	6.30-004	5.52-004	4.30-004	3.65-004	2.39-004	2.39-004	
CUM. MASS (GR/DNCF) < D50	8.33-004	8.33-004	8.32-004	8.10-004	7.09-004	5.53-004	4.49-004	3.07-004	3.07-004	
CUM. MASS (MG/DNCH) < D50	3.02+001	1.30+001	1.22+001	9.38+000	6.26+000	3.81+000	1.98+000	1.08+000	6.18-001	3.19-001
GEO. MEAN DIA. (MICRONS)	2.16+000	8.90+000	2.36-002	2.90-001	1.31+000	1.40+000	6.11-001	1.75+000	4.65-003	2.33+000
DN/DLOGD (MG/DNCH)	1.50+005	7.72+006	2.47+004	6.72+005	1.02+007	4.83+007	1.50+008	2.65+009	3.76+007	1.38+011

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 13.01 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 11.49 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000* 20.000*

CUM. MASS (MG/DNCH) .703 .851 1.015 1.212 1.734 1.890 1.951 2.188

DN/DLOGD (MG/DNCH) 4.65-003 1.90+000 1.48+000 8.92-001 1.41+000 2.33-001 1.15+000 2.50+000

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR GCA, AT SITE FOOT, ON DATE 31781, RUN NO. 24
 TEST COMMENTS: I.P. TEST FERROSILICON
 RUN COMMENTS: 40A
 *** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.3

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE NO. JETS DIAM. CUMDP CALIB
 -1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0918 .0000 .4100
 4 264 .0759 .0000 .3850
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .484 ACFM

IMPACTOR PRESSURE DROP = .388 IN. OF HG

IMPACTOR PRESSURE DROP = .388 IN. OF HG

IMPACTOR TEMPERATURE = 205.0 F (96.1 C)
 STACK TEMPERATURE = 205.0 F (96.1 C)
 DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.30 O2 = 17.80 H2O = .90
 CALC. MASS LOADING = 8.8215-004 GR/ACF
 SAMPLING AT 206.0 % OF ISOKINETIC RATE

SAMPLING DURATION = 90.00 MIN
 STACK PRESSURE = 29.68 INCHES OF HG
 2.5780+000 MG/DNCH

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.0CGH/CU.CM. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE	NOZZLE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
STAGE INDEX NO.	1	2	3	4	5	6	7	8	9	10
D50 (MICRONS)	11.77	11.77	10.39	6.92	4.62	2.56	1.24	.76	.40	.40/2.0
MASS (MG)	.01	.00	.04	.25	.07	.13	.41	.36	.20	1.02
MG/DNCH/STAGE	9.32-003	1.04-003	4.14-002	2.59-001	7.25-002	1.35-001	4.24-001	3.73-001	2.07-001	1.06+000
CUM. % OF MASS	99.64	99.60	97.99	87.95	85.14	79.92	63.45	49.00	40.96	
CUM. MASS (MG/ACF) < D50	2.01+000	2.01+000	1.98+000	1.78+000	1.72+000	1.61+000	1.28+000	9.89-001	8.27-001	
CUM. MASS (MG/DNCH) < D50	2.57+000	2.57+000	2.53+000	2.27+000	2.19+000	2.06+000	1.64+000	1.26+000	1.06+000	
CUM. MASS (GR/ACF) < D50	8.79-004	8.79-004	8.64-004	7.76-004	7.51-004	7.05-004	5.60-004	4.32-004	3.61-004	
CUM. MASS (GR/DNCF) < D50	1.12-003	1.12-003	1.10-003	9.91-004	9.59-004	9.00-004	7.15-004	5.52-004	4.61-004	
CUM. MASS (MG/DNCH) < D50	2.87+001	1.18+001	1.11+001	8.48+000	5.66+000	3.44+000	1.78+000	9.70-001	5.50-001	2.81-001
GEOM. MEAN DIA. (MICRONS)	1.20-002	1.77+001	7.66-001	1.47+000	4.13-001	5.25-001	1.35+000	1.75+000	7.39-001	3.51+000
DN/DLOGD (MG/DNCH)	9.72+002	2.08+007	1.08+006	4.59+006	4.36+006	2.46+007	4.54+008	3.66+009	8.50+009	3.00+011

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 11.77 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 10.39 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)
 STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000* 20.000*
 CUM. MASS (MG/DNCH) 1.167 1.481 1.642 2.226 2.491 2.578 2.578
 DN/DLOGD (MG/DNCH) 9.68-001 1.73+000 1.66+000 8.26-001 5.26-001 1.19+000 .00

PARTICULATE DATA REDUCTION AND ENTRY SYSTEM DATA FOR TEST BY CONTRACTOR GCA , AT SITE FOOT, ON DATE 31781, RUN NO. 25

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 408

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.3

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287

STAGE	NO.	JETS	DIAM.	CUT- DP	CALIB
1	264	.1638	.0000	.3050	
2	264	.1253	.0000	.4030	
3	264	.0948	.0000	.4100	
4	264	.0759	.0000	.3250	
5	264	.0533	.0000	.3690	
6	264	.0343	.1760	.3600	
7	264	.0254	.2940	.3520	
8	155	.0254	1.0000	.2740	

IMPACTOR FLOWRATE = .390 ACFM

IMPACTOR PRESSURE DROP = .252 IN. OF HG IMPACTOR TEMPERATURE = 205.0 F (96.1 C) SAMPLING DURATION = 90.00 MIN

IMPACTOR PRESSURE DROP = .252 IN. OF HG STACK TEMPERATURE = 205.0 F (96.1 C) STACK PRESSURE = 29.68 INCHES OF HG

DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.30 O2 = 17.80 H2O = .90

CALC. MASS LOADING = 2.1939-003 GR/ACF 2.8019-003 GR/DNCF 5.0205+000 MG/ACH 6.4116+000 MG/DNCH

SAMPLING AT 166.7 % OF ISOKINETIC RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CM³CH. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE	NOZZLE	S1	S2	S3	S4	S5	S6	S7	S8	S9	S10	FILTER
STAGE INDEX NO.	1	2	3	4	5	6	7	8	9	10		
D50 (MICRONS)	13.12	13.12	11.59	7.72	5.16	2.87	1.39	.86	.46	.46/2.0		
MASS (MG)	1.24	.00	.03	.48	.15	.39	.54	.30	.39	.47		
MG/DNCH/STAGE	1.59+000	1.28-003	3.85-002	6.17-001	1.93-001	5.01-001	6.94-001	3.85-001	5.01-001	1.89+000		
CUM. % OF MASS	75.17	75.15	74.55	64.93	61.92	54.11	43.29	37.27	29.46			
CUM. MASS (MG/ACH) < D50	3.77+000	3.77+000	3.74+000	3.26+000	3.11+000	2.72+000	2.17+000	1.87+000	1.48+000			
CUM. MASS (MG/DNCH) < D50	4.82+000	4.82+000	4.78+000	4.16+000	3.97+000	3.47+000	2.78+000	2.39+000	1.89+000			
CUM. MASS (GR/ACF) < D50	1.65-003	1.65-003	1.64-003	1.42-003	1.36-003	1.19-003	9.50-004	8.18-004	6.46-004			
CUM. MASS (GR/DNCF) < D50	2.11-003	2.11-003	2.09-003	1.82-003	1.74-003	1.52-003	1.21-003	1.04-003	8.25-004			
GEO. MEAN DIA. (MICRONS)	3.03+001	1.31+001	1.23+001	9.46+000	6.31+000	3.85+000	2.00+000	1.09+000	6.25-001			
DM/DLOGD (MG/DNCH)	2.19+000	-1.84+001	7.14-001	3.50+000	1.10+000	1.96+000	2.21+000	1.83+000	1.83+000			
DN/DLOGD (NUMBER/DNCH)	1.50+005	-1.53+007	7.27+005	7.90+006	8.35+006	6.58+007	5.30+008	2.68+009	1.43+010			

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGES 1 WITH D50= 13.12 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGES 2 WITH D50= 11.59 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STG.	DIA. (MICRONS)	CUM. MASS (MG/DNCH)	DM/DLOGD (MG/DNCH)
1	1.000	1.250	6.000
2	1.250	2.505	2.684
3	1.500	3.750	1.344
4	2.000	4.011	4.492
5	2.500	4.989	5.364
6	3.000	5.967	6.235
7	3.500	6.946	7.106
8	4.000	7.925	7.977
9	4.500	8.904	8.848
10	5.000	9.883	9.719
11	5.500	10.862	10.590
12	6.000	11.841	11.461
13	6.500	12.820	12.332
14	7.000	13.799	13.203
15	7.500	14.778	14.074
16	8.000	15.757	14.945
17	8.500	16.736	15.816
18	9.000	17.715	16.687
19	9.500	18.694	17.558
20	10.000	19.673	18.429
21	10.500	20.652	19.300
22	11.000	21.631	20.171
23	11.500	22.610	21.042
24	12.000	23.589	21.913
25	12.500	24.568	22.784
26	13.000	25.547	23.655
27	13.500	26.526	24.526
28	14.000	27.505	25.397
29	14.500	28.484	26.268
30	15.000	29.463	27.139
31	15.500	30.442	28.010
32	16.000	31.421	28.881
33	16.500	32.400	29.752
34	17.000	33.379	30.623
35	17.500	34.358	31.494
36	18.000	35.337	32.365
37	18.500	36.316	33.236
38	19.000	37.295	34.107
39	19.500	38.274	34.978
40	20.000	39.253	35.849
41	20.500	40.232	36.720
42	21.000	41.211	37.591
43	21.500	42.190	38.462
44	22.000	43.169	39.333
45	22.500	44.148	40.204
46	23.000	45.127	41.075
47	23.500	46.106	41.946
48	24.000	47.085	42.817
49	24.500	48.064	43.688
50	25.000	49.043	44.559
51	25.500	50.022	45.430
52	26.000	51.001	46.301
53	26.500	51.980	47.172
54	27.000	52.959	48.043
55	27.500	53.938	48.914
56	28.000	54.917	49.785
57	28.500	55.896	50.656
58	29.000	56.875	51.527
59	29.500	57.854	52.398
60	30.000	58.833	53.269
61	30.500	59.812	54.140
62	31.000	60.791	55.011
63	31.500	61.770	55.882
64	32.000	62.749	56.753
65	32.500	63.728	57.624
66	33.000	64.707	58.495
67	33.500	65.686	59.366
68	34.000	66.665	60.237
69	34.500	67.644	61.108
70	35.000	68.623	61.979
71	35.500	69.602	62.850
72	36.000	70.581	63.721
73	36.500	71.560	64.592
74	37.000	72.539	65.463
75	37.500	73.518	66.334
76	38.000	74.497	67.205
77	38.500	75.476	68.076
78	39.000	76.455	68.947
79	39.500	77.434	69.818
80	40.000	78.413	70.689
81	40.500	79.392	71.560
82	41.000	80.371	72.431
83	41.500	81.350	73.302
84	42.000	82.329	74.173
85	42.500	83.308	75.044
86	43.000	84.287	75.915
87	43.500	85.266	76.786
88	44.000	86.245	77.657
89	44.500	87.224	78.528
90	45.000	88.203	79.399
91	45.500	89.182	80.270
92	46.000	90.161	81.141
93	46.500	91.140	82.012
94	47.000	92.119	82.883
95	47.500	93.098	83.754
96	48.000	94.077	84.625
97	48.500	95.056	85.496
98	49.000	96.035	86.367
99	49.500	97.014	87.238
100	50.000	97.993	88.109

TEST COMMENTS: I.P. TEST FERROSILICON

RUN COMMENTS: 50A

*** GAS COMPONENTS NORMALIZED SO SUM= 100%, NOT 98.3

IMPACTOR DESCRIPTION AND CALIBRATION

TYPE: ANDERSEN PLATE SET ID: 0
 MODEL: MARK 3 IMPACTOR DP SCALING FACTOR: 1.287
 STAGE NO. JETS DIAM. CUR-DP CALIB
 1 264 .1638 .0000 .3050
 2 264 .1253 .0000 .4030
 3 264 .0948 .0000 .4100
 4 264 .0759 .0000 .3350
 5 264 .0533 .0000 .3690
 6 264 .0343 .1760 .3600
 7 264 .0254 .2940 .3620
 8 156 .0254 1.0000 .2740

IMPACTOR FLOWRATE = .417 ACFM

IMPACTOR TEMPERATURE = 205.0 F (96.1 C) SAMPLING DURATION = 90.00 MIN
 IMPACTOR PRESSURE DROP = .288 IN. OF HG STACK TEMPERATURE = 205.0 F (96.1 C) STACK PRESSURE = 29.68 INCHES OF HG
 DRY GAS COMPOSITION (PERCENT) CO2 = 1.20 CO = .00 N2 = 79.30 O2 = 17.80 H2O = 1.20
 CALC. MASS LOADING = 2.2205-003 GR/ACF 5.0812+000 MG/ACH 6.5089+000 MG/D1CH
 SAMPLING AT 177.5 % OF ISOKINETIC RATE

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNGS DYNAMICS.

ASSUMED PARTICLE DENSITY = 1.00GM/CU.CM. MAX. PARTICLE DIAMETER = 70.0 MICRONS

IMPACTOR STAGE STAGE INDEX NO.	NOZZLE	S1	S2	S3	S4	S5	S6	S7	S8	FILTER
D50 (MICRONS)	12.68	12.68	11.20	7.46	4.99	2.77	1.34	.82	.44	.44/2.0
MASS (MG)	.37	.00	.19	.19	.32	.15	.50	.91	.64	1.93
HG/D1CH/STAGE	4.45-001	1.21-003	2.29-001	2.29-001	3.86-001	1.81-001	6.03-001	1.10+000	1.01+000	2.33+000
CUM. % OF MASS	93.17	93.15	89.63	86.11	80.19	77.41	68.15	51.30	35.74	
CUM. MASS (MG/ACH) < D50	4.73+000	4.73+000	4.55+000	4.38+000	4.07+000	3.93+000	3.46+000	2.61+000	1.82+000	
CUM. MASS (MG/D1CH) < D50	6.06+000	6.06+000	5.83+000	5.60+000	5.22+000	5.04+000	4.44+000	3.34+000	2.33+000	
CUM. MASS (GR/ACH) < D50	2.07-003	2.07-003	1.99-003	1.91-003	1.78-003	1.72-003	1.51-003	1.14-003	7.94-004	
CUM. MASS (GR/D1CH) < D50	2.65-003	2.65-003	2.55-003	2.45-003	2.28-003	2.20-003	1.93-003	1.46-003	1.02-003	
GEOM. MEAN DIA. (MICRONS)	2.98+001	1.27+001	1.19+001	9.14+000	6.10+000	3.71+000	1.93+000	1.05+000	6.01-001	3.09-001
D1/D50 (MG/D1CH)	5.99-001	3.00+001	4.24+000	1.30+000	2.20+000	7.07-001	1.92+000	5.18+000	3.67+000	7.73+000
D1/D50 (NUMBER/D1CH)	4.33+004	2.81+007	4.79+006	3.25+006	1.65+007	2.64+007	5.12+008	8.49+009	3.24+010	4.97+011

*** CUT POINTS FOR STAGES 0 1 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 1 WITH D50= 12.68 OMITTED FROM INTERPOLATION

*** CUT POINTS FOR STAGES 1 2 ARE SIMILAR OR INVERTED

MEASURED DATA FOR STAGE, 2 WITH D50= 11.20 OMITTED FROM INTERPOLATION

INTERPOLATED VALUES (VALUES AT DIAMETERS MARKED WITH * ARE EXTRAPOLATED)

STD. DIA. (MICRONS) .625 1.000 1.250 2.500 6.000 10.000 15.000* 20.000*
 CUM. MASS (MG/D1CH) 2.838 3.838 4.309 4.979 5.400 5.877 6.194 6.354
 DM/DLOD (MG/D1CH) 3.78+000 5.46+000 4.10+000 2.21+000 1.96+000 1.59+000 9.92-001

APPENDIX E-1
CASCADE IMPACTOR FIELD DATA SHEETS

A' DERSEN IMPACTOR FIELD DATA

Plant Footc Time 10 59 Nozzle Dia. _____
Location Vay/Hobbs Run No. 1 I A .85 Avg. ΔP _____
Operator INLET #2 FCC Impactor Location _____ Traverse Pt. _____
Date 3/17/81 D.G.F. No. VI Pb _____
Andersen Imp No. 2 I D.G. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	26	327	328	329	330	331	332	333	B-155	

[illegible]

initial leak check 0.010

Si-Gel initial

Send link check

Si-Ge1 final

Total H₂O Collected in Flask

Net _____

Total H₂O Collected _____

A


$$\omega$$

var $\Delta H = 0.08$

SI-Cel Initial _____

Si-Gel final

et

105

ANDERSEN IMPACTOR FIELD DATA

Plant Foote Time 9:35 Nozzle Dia. 3.5 B
Location #2 FC, INLET Run No. 1 IB.85 Avg. ΔP 0.7
Operator VAY Impactor Location _____ Traverse Pt. B-0.85D
Date 3/17/81 D.G.M. No. V1 Pb TS=400
Andersen Imp No. 2I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	186	487	488	489	490	491	492	493	B-175	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet	Orifice S.P. - "Hg	Impactor Temp	Traverse Point
437.947	0	0.06	37 38	0.7		
438.17	1	0.06	37 38	0.7		
438.36	2	0.06	36 39	0.8		
438.56	3	0.06	37 39	0.9		
438.75	4	0.06	37 39	1.0		
438.95	5	0.06	37 39	1.0		
439.146	6	0.06	37 39	1.2		

INLET LOADING

St-Gel initial

Si-Gel final

Net

106

ANDERSEN IMPACTOR FIELD DATA

ANDERSEN IMPACTOR FIELD DATA

Plant	FOOTE	Time	14:00	Nozzle Dia.	3.5
Location	INLET	Run No.	214.15	Avg. ΔP	
Operator	Vay/Horns	Impactor Location		Traverse Pt.	- ? D.E.S or 0.15.
Date	3/17/81	D.G.M. No.	V1	Pb	
Andersen Imp No.	11	D.G.M. Y		Static "Hg	

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	454	455	456	457	458	459	460	461	B-17	

[illegible]

Initial leak clock 2.016 ft³/min

Si-Cel initial

...and leak check

Si-Gel final

Total H₂O Collected in Flask

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant	Footy	Time	13:23	Nozzle Dia.	3.5
Location	INLET	Run No.	214-85	Avg. ΔP	
Operator	Way Hobbs	Impactor Location		Traverse Pt.	
Date	3/17/81	D.G.M. No.	V1	Pb	
Andersen Imp No.	21	D.G.M. Y		Static "Hg	

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	430	431	432	433	434	435	436	437	B-165	

[illegible]

initial leak check 2012 3/2/12

Si-Gel initial _____

Final leak check

Si-Ge1 final

Total H₂O Collected in Flask

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Footc Time 14:41 Nozzle Dia. 3.5
Location Inlet Run No. 2 I B.85 Avg. ΔP _____
Operator Vay/Abbs Impactor Location _____ Traverse Pt. _____
Date 3/17/81 D.G.M. No. ✓1 Pb _____
Anderson Imp No. 2 I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	414	415	416	417	418	419	420	421	B-166	

[illegible]

Initial leak check	0.019 $\frac{H_2}{min}$	Si-Gel initial	
Final leak check		Si-Gel final	
Total H ₂ O Collected in Flask		Net	
Total H ₂ O Collected			

ANDERSEN IMPACTOR FIELD DATA

Plant	Footo	Time	18:19 18:19	Nozzle Dia.	
Location	Iraba W/a	Run No.	3IB-0.15	Avg. ΔP.	-
Operator	Vay / Helle	Impactor Location	B-0.15	Traverse Pt.	B-0.15
Date	3/17/81	D.G.M. No.	V1	Ph	
Andersen Imp No.	1I	D.G.M. Y		Static "Hg	

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	302	303	304	305	306	307	308	309	B-152	

[illegible]

Initial bank check 

Si-Gel initial

Final leak check

Si-Gel final

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

ANDERSEN IMPACTOR FIELD DATA

Plant	Footle	Time	16:35	Nozzle Dia.	3.5
Location	1 met	Run No.	3-I-B-85	Avg. ΔP	
Operator	Uay	Impactor Location		Traverse Pt.	B-85
Date	3/17/81	D.G.M. No.	V1	Pb	
Andersen Imp No.	2 F	D.G.M. Y		Static "Hg	

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	398	399	400	401	402	403	404	405	B-76	

[illegible]

Initial leak check $0.012 \text{ } \frac{\text{ft}^3}{\text{min}}$

Si-Gel initial

Final leak check

Si-Gel final

Total H₂O Collected in Flask

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Foote Time 18:19 Nozzle Dia. 3.5
Location Inlet Run No. 3 I A .15 Avg. ΔP _____
Operator Way/Hobbs Impactor Location _____ Traverse Pt. _____
Date 3/17/81 D.G.M. No. V1 Pb _____
Andersen Imp No. 1 I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	446	447	448	449	450	451	452	453	B-170	

[illegible]

Initial leak check	0.019	Si-Gel initial	_____
Final leak check	_____	Si-Gel final	_____
Total H ₂ O Collected in Flask	_____	Net	_____
Total H ₂ O Collected	_____		

ALDERSEN IMPACTOR FIELD DATA

Parent Footc Time 17-47 Nozzle Dia. 3.5
 Location Inlet Run No. 3 I A .85 Avg. ΔP _____
 Operator Jay / Hobbs Impactor Location _____ Traverse Pt. _____
 Date 3/17/84 D.C.M. No. V1 Pb _____
 Andersen Imp No. 2 I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	518	519	520	521	522	523	524	525	B-179	

[illegible]

Initial leak check _____

Si-Gel initial _____

Final leak check

Si-Gel final

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Footo Time 13:45 Nozzle Dia. 3.5
Location inlet Run No. 4 IA.15 Avg. ΔP _____
Operator Way/Hobbs Impactor Location _____ Traverse Pt. _____
Date 3/18/81 D.G.M. No. ✓1 Pb _____
Andersen Imp No. 2 I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	406	407	408	409	410	411	412	413	3-165	

[illegible]

Initial leak check 0.01 ft³/min

Si-Gel initial _____

Final leak check _____

Si-Gel final

Total H₂O Collected in Flask _____

Net _____

total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Forte Time 13:03 Nozzle Dia. 3.5
 Location _____ Run No. 4I A .85 Ave. ΔP _____
 Operator Vay/Hobbs Impactor Location _____ Traverse Pt. _____
 Date 3/18/81 D.G.M. No. V1 Ph _____
 Andersen Imp No. 1 I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	286	287	288	289	290	291	292	293	B-150	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
450.415	0	0.06	52	52	0.7		
450.61	1	0.06	50	50	0.7		
450.80	2	0.06	51	50	0.7		
451.00	3	0.06	51	50	0.7		
451.20	4	0.06	51	51	0.8		
451.395	5	0.06	51	51	0.8		
• Impactor dropped ~ 10 St. before recovery.							
• Warmup was ~ 30 hours							

Initial leak check 0.020 ft³/min

Si-Gel initial _____

Plant leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Fauto Time 15:41 Nozzle Dia. 3.5
Location _____ Run No. 4IB.15 Avg. ΔP _____
Operator Uay/Hobbs Impactor Location _____ Traverse Pt. _____
Date 3/18/81 D.G.M. No. U1 Pb _____
Andersen Imp No. 2I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	382	383	384	385	386	387	388	389	B-162	

[illegible]

Initial leak check $0.005^{+3}_{-1} \text{ min}$

Si-Gel initial

Final leak check

Si-Ge1 final

Total H₂O Collected in Flask

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Footo Time 14:36 Nozzle Dia. 4.0
 Location _____ Run No. 4 IB-85 Avg. ΔP _____
 Operator Day/Hobbs Impactor Location _____ Traverse Pt. _____
 Date 3/17/81 D.G.M. No. V1 Pb _____
 Andersen Imp No. I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	478	479	480	481	482	483	484	485	5174	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
452.761	0	0.11	56	48	0.2		
452.85	1	0.11	55	48	0.7		
453.10	2	0.11	55	48	0.7		
453.38	3	0.11	55	47	0.8		
453.64	4	0.11	54	47	0.8		
453.918	5	0.11	54	47	0.9		
note the first 60 seconds of run did not draw at proper ΔH ΔH was 0.011 instead of 0.11							

Initial leak check 0.015 $\frac{L}{min}$

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

ANDERSEN IMPACTOR FIELD DATA

Plant Footie Time 16:48 Nozzle Dia. 3.5

Location _____ Run No. 5 I B 15 Avg. ΔP _____

Operator Way/Hobbs Impactor Location _____ Traverse Pt. _____

Date 3/18/81 D.G.M. No. V1 Pb _____

Andersen Imp No. 21 D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	365	366	367	368	369	370	371	372	B160	

[illegible]

internal leak check 0.006 ft³/min

SI-Gel Initial _____

Si-Gel final

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Client Footle Time 16:55 Nozzle Dia. X
 Location inlet Run No. 1 I Blank Avg. ΔP _____
 Operator Vay/Hubs Impactor Location _____ Traverse Pt. _____
 Date 3/18/81 D.G.M. No. V1 Pb _____
 Andersen Imp No. I D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	I
Substrate No.	342	343	344	345	346	347	348	349	B157	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
454.747	0	0.07	55	55	0.8		
454.95	1	0.07	55	55	1.2		
455.28	2	0.07	55	55	1.4		
455.38	3	0.07	55	55	1.6		
455.69	4	0.07	55	55	1.6		
455.80	5	0.07	55	55	2.0		
456.01	6	0.07	55	55	2.4		
456.22	7	0.07	55	55	2.7		
456.44	8	0.07	55	55	3.1		
456.64	9	0.07	55	55	3.5		
456.85	10	0.07	54	54	3.8		
457.06	11	0.07	54	54	4.0		
457.27	12	0.07	54	54	4.1		
457.48	13	0.07	54	54	4.3		
457.69	14	0.07	55	55	4.8		
457.84	15	0.07	55	55	5.1		

Initial leak check 0.008 ²⁴3/min

Si-Gel initial _____

Final leak check _____

Si-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Name Book Time 0933 Nozzle Dia. 1/2
 Location Graham WUA OUTLET Run No. 10A Avg. ΔP _____
 Operator TEJEN Impactor Location alt. # 11 Traverse Pt. 6'
 Date 3/17/81 D.G.M. No. V2 Pb _____
 Andersen Imp No. 4/2A D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	28	439	440	441	442	443	444	445	5169	

OH - 117

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
7.795	0	0.17	46	50	0.25		
9.600	6.0	0.17	45	51	0.25		
11.500	12.0	0.17	43	51	0.30		
13.395	18.0	0.17	45	51	0.30		
15.270	24.0	0.17	46	51	0.30		
17.145	30.0	0.17	48	52	0.30		
19.020	36.0	0.17	49	52	0.30		
20.900	42.0	0.17	51	54	0.30		
22.775	48.0	0.17	54	56	0.30		
24.655	54.0	0.17	54	58	0.30		
26.535	60.0	0.17	55	59	0.30		
28.415	66.0	0.17	58	60	0.30		
30.300	72.0	0.17	58	61	0.30		
32.175	78.0	0.17	60	62	0.30		
34.060	84.0	0.17	60	63	0.30		
35.939	90.0	0.17	58	63	0.30		

Initial Leak check 0.015

SI-Gel Initial 1

Final Leak check —

SI-Gel Final 1

Total H₂O Collected in Flask —

Net 1

Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant FOOTE Time 0930 Nozzle Dia. 2L
 Location OUTLET Run No. 10B Avg. ΔP _____
 Operator T Epsk Impactor Location Unit #10 Traverse Pt. ~6'
 Date 3/17/81 D.G.M. No. V4 Pb _____
 Andersen Imp No. 4/B D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	8	T
Substrate No.	475	476	477	478	479	500	501	502		

AH - 0.17

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
54.934	0	0.17	60	51	0.65	0.65	
56.960	6.0	0.17	59	51	0.65		
58.960	12.0	0.17	59	50	0.70		
60.960	18.0	0.17	59	51	0.70		
62.950	24.0	0.17	59	51	0.70		
64.930	30.0	0.17	59	52	0.75		
66.915	36.0	0.17	59	53	0.75		
68.900	42.0	0.17	60	55	0.75		
70.880	48.0	0.17	59	57	0.75		
72.855	54.0	0.17	60	58	0.75		
74.835	60.0	0.17	60	60	0.75		
76.815	66.0	0.17	60	61	0.75		
78.790	72.0	0.17	62	63	0.80		
80.770	78.0	0.17	62	64	0.80		
82.745	84.0	0.17	66	66	0.80		
84.723	90.0	0.17	66	66	0.80		

Initial leak check 0.004

SI-Gel initial _____

Final leak check _____

SI-Gel final _____

Total H₂O Collected In Filter _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Foote Time 1315 Nozzle Dia. 1L
 Location Grain, w Va Run No. 20-A Avg. ΔP _____
 Operator TEPKIN Impactor Location 41 Traverse Pt. 6'
 Date 3/17/61 D.G.M. No. V4 Pb _____
 Andersen Imp No. 4A D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	470	471	472	473	474	475	476	477	8-123	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point.
			Inlet	Outlet			
84.884	0	0.17	72	70	0.85		
86.900	6.0	0.17	73	69	0.90		
88.910	12.0	0.17	73	70	0.90		
90.910	18.0	0.17	73	69	0.90		
92.910	24.0	0.17	73	70	0.90		
94.910	30.0	0.17	74	71	0.90		
96.910	36.0	0.17	74	71	0.95		
98.910	42.0	0.17	74	72	0.95		
100.910	48.0	0.17	74	72	0.95		
102.910	54.0	0.17	74	72	0.95		
104.910	60.0	0.17	74	72	0.95		
106.905	66.0	0.17	74	72	0.95		
108.900	72.0	0.17	73	72	0.95		
110.895	78.0	0.17	74	72	0.95		
112.890	84.0	0.17	73	72	0.95		
114.887	90.0	0.17	73	72	0.95		

Initial leak check 0.003St-Gel initial —Final leak check —St-Gel final —Total H₂O Collected in Flask —Net ✓Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant Fook Time 1318 Nozzle Dia. 2L
 Location bruham, wva Run No. 20-B Avg. ΔP _____
 Operator T Egle Impactor Location atlet #2 Traverse Pt. 6'
 Date 3/17/81 D.G.M. No. 12 Pb _____
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	318	319	320	321	322	323	324	325	B-154	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
35.999	0	0.17	84	78	0.55		
37.975	6.0	0.17	77	80	0.55		
40.265	12.0 13.0	0.17	76	81	0.55 0.60		
41.900	15.0	0.17	75	82	0.60		
43.885	24.0	0.17	74	82	0.60		
45.860	30.0	0.17	76	83	0.60		
47.840	36.0	0.17	76	83	0.60		
49.815	42.0	0.17	77	84	0.65		
51.765	48.0	0.17	74	84	0.65		
53.720	54.0	0.17	75	84	0.65		
55.680	60.0	0.17	76	84	0.65		
57.630	66.0	0.17	75	85	0.65		
59.595	72.0	0.17	74	84	0.65		
61.535	78.0	0.17	77	84	0.65		
63.480	84.0	0.17	76	85	0.65		
65.439	90.0	0.17	74	84	0.65		

Initial leak check 0.005Si-Gel initial 1Final leak check —Si-Gel final 2Total H₂O Collected in Flask —Net —Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant Fork Time 1610 Nozzle Dia. 1L
 Location Graham, W Va Run No. 3-0-A Avg. ΔP _____
 Operator TEPkin Impactor Location Outlet, #3 Traverse Pt. 6'
 Date 3/17/81 D.G.M. No. V4 Pb _____
 Andersen Imp No. 4A D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	358	359	360	361	362	363	364	365	B-199	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
115.014	0	0.17	70	66	0.65		
117.035	6.0	0.17	71	67	0.70		
119.050	12.0	0.17	72	68	0.70		
121.020	18.0	0.17	72	68	0.75		
123.355	25.0	0.17	71	68	0.75		
125.030	30.0	0.17	71	68	0.75		
127.035	36.0	0.17	71	69	0.75		
129.035	42.0	0.17	71	69	0.75		
131.035	48.0	0.17	71	69	0.75		
133.035	54.0	0.17	71	69	0.75		
135.030	60.0	0.17	70	69	0.80		
137.030	66.0	0.17	70	68	0.80		
139.025	72.0	0.17	70	68	0.80		
141.025	78.0	0.17	70	69	0.80		
143.020	84.0	0.17	70	67	0.80		
145.007	90.0	0.17	70	67	0.80		

Initial leak check 0.015Si-Gel initial —Final leak check —Si-Gel final —Total H₂O Collected in Flask —Net ✓Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant Foot Time 1613 Nozzle Dia. 2L
 Location braham, W Va Run No. 3-0-6 Avg. ΔP _____
 Operator T E Stein Impactor Location outlet, #4 Traverse Pt. 6'
 Date 3/17/81 D.C.M. No. V2 Pb _____
 Andersen Imp No. 4B D.C.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	390	391	392	393	394	395	396	397	B-163	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
65.501	0	0.17	60	63	0.75		
67.475	6.0	0.17	60	65	0.75		
69.450	12.0	0.17	59	65	0.75		
71.405	18.0	0.17	60	65	0.80		
73.355	24.0	0.17	60	65	0.80		
75.315	30.0	0.17	60	65	0.80		
77.270	36.0	0.17	60	65	0.80		
79.220	42.0	0.17	60	65	0.80		
81.180	48.0	0.17	61	65	0.80		
83.085	54.0	0.17	60	65	0.80		
85.020	60.0	0.17	60	65	0.80		
86.960	66.0	0.17	60	65	0.80		
88.900	72.0	0.17	60	65	0.80		
90.840	78.0	0.17	58	64	0.80		
92.775	84.0	0.17	58	64	0.80		
94.715	90.0	0.17	58	63	0.80		

Initial leak check 0.005Si-Gel initial ✓Final leak check ✓Si-Gel final ✓Total H₂O Collected in Flask ✓Net ✓Total H₂O Collected ✓

ANDERSEN IMPACTOR FIELD DATA

Plant Fork Time 1300 Nozzle Dia. 1L
 Location Graham w/4 Run No. 4-0-A Avg. ΔP _____
 Operator T Epton Impactor Location (461, 45) Traverse Pt. 6'
 Date 3/14/81 D.G.M. No. V4 Pb _____
 Andersen Imp No. 4A D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	462	463	464	465	466	467	468	469	B-172	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
145.067	0	0.17	60	65	0.60		
147.125	6.0	0.17	60	63	0.60		
149.105	12.0	0.17	61	65	0.60		
151.085	18.0	0.17	61	66	0.65		
153.060	24.0	0.17	61	68	0.65		
155.045	30.0	0.17	61	68	0.65		
157.010	36.0	0.17	61	68	0.65		
158.980	42.0	0.17	61	69	0.65		
160.950	48.0	0.17	68	70	0.65		
162.915	54.0	0.17	69	70	0.65		
164.885	60.0	0.17	72	72	0.65		
166.850	66.0	0.17	74	74	0.65		
168.815	72.0	0.17	75	75	0.65		
170.780	78.0	0.17	74	74	0.65		
172.745	84.0	0.17	74	71	0.65		
174.703	90.0	0.17	74	71	0.65		

Initial leak check 0.015Si-Gel initial 11Final leak check —Si-Gel final 11Total H₂O Collected in Flask —Net 11Total H₂O Collected —warmed up
for 3 hrs. +

ANDERSEN IMPACTOR FIELD DATA

Plant Fort Time 1303 Nozzle Dia. 24
 Location Graham, WVA Run No. B 4-C-B Avg. ΔP _____
 Operator T E. Sten Impactor Location outlet, #6 Traverse Pt. G'
 Date 3/15/91 D.G.M. No. 12 Pb _____
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	422	423	424	425	426	427	428	429	B-167	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
94.798	0	0.17	44	43	0.70		
96.670	6.0	0.17	44	44	0.70		
98.540	12.0	0.17	46	45	0.70		
100.400	18.0	0.17	48	46	0.70		
102.250	24.0	0.17	48	47	0.70		
104.095	30.0	0.17	48	48	0.75		
105.935	36.0	0.17	49	49	0.75		
107.800	42.0	0.17	50	50	0.75		
109.640	48.0	0.17	52	52	0.75		
111.470	54.0	0.17	53	53	0.75		
113.300	60.0	0.17	52	52	0.75		
115.145	66.0	0.17	54	54	0.75		
116.940	72.0	0.17	57	52	0.75		
118.825	78.0	0.17	54	50	0.75		
120.655	84.0	0.17	54	49	0.75		
122.496	90.0	0.17	40	47	0.80		

Initial leak check 0.010 Si-Gel initial _____
 Final leak check _____ Si-Gel final _____
 Total H₂O Collected in Flask _____ Net _____
 Total H₂O Collected _____
 warmed up
 for 3 hrs. +

ANDERSEN IMPACTOR FIELD DATA

Plant Fuck Time 1545 Nozzle Dia. 1L
 Location bruhm, WVA Run No. 5-0-A Avg. ΔP _____
 Operator T Epstein Impactor Location 444, #7 Traverse Pt. 61
 Date 3/16/61 D.G.M. No. V4 Pb _____
 Andersen Imp No. 4A D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	310	311	312	313	314	315	316	317	B153	

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
174.943	0	0.17	62	56	0.65		
176.970	6.0 6.0	0.17	62	56	0.65		
178.980	12.0	0.17	62	56	0.65		
180.995	18.0	0.17	63	58	0.70		
183.005	24.0	0.17	62	58	0.70		
185.015	30.0	0.17	63	58	0.70		
187.015	36.0	0.17	63	60	0.70		
189.020	42.0	0.17	63	60	0.70		
191.020	48.0	0.17	64	61	0.70		
193.035	54.0	0.17	64	60	0.70		
195.060	60.0	0.17	64	60	0.75		
197.090	66.0	0.17	64	60	0.75		
199.116	72.0	0.17	64	60	0.75		
201.140	78.0	0.17	64	60	0.75		
203.160	84.0	0.17	64	60	0.75		
205.182	90.0	0.17	64	60	0.75		

Initial leak check 0.015Si-Gel initial —Final leak check —Si-Gel final —Total H₂O Collected in Flask —Net —Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant Fork Time 1548 Nozzle Dia. none
 Location Graham, W Va Run No. 5-0-B (blank) Avg. ΔP _____
 Operator T Eggen Impactor Location cutlet #8 Traverse Pt. 6'
 Date 3/18/81 D.G.M. No. V2 Pb _____
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	334	335	336	337	338	339	340	341	B156	

Blank

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
122.556	0	0.17	42	45	1.70		
124.500	6.0	0.17	42	47	1.75		
126.430	12.0	0.17	44	47	1.75		
129.345	18.0	0.17	46	49	1.85		
130.290	24.0	0.17	45	49	2.05		
132.235	30.0	0.17	47	50	2.30		
134.155	36.0	0.17	50	52	2.45		
136.115	42.0	0.17	50	53	2.50		
139.080	48.0	0.17	50	54	2.60		
140.050	54.0	0.17	49	54	2.85		
142.030	60.0	0.17	49	54	2.95		
144.010	66.0	0.17	49	54	2.95		
145.975	72.0	0.17	49	54	2.95		
147.950	78.0	0.17	50	54	3.15		
149.960	84.0	0.17	50	55	3.30		
151.946	90.0	0.17	51	55	3.30		

Initial leak check 0.005SI-Gel initial —Final leak check —SI-Gel final —Total H₂O Collected in Flask —Net —Total H₂O Collected —

ANDERSEN IMPACTOR FIELD DATA

Plant Forte Time 1314 Nozzle Dia. 14.5
 Location crabapple Ln Run No. outlet visible Avg. ΔP _____
 Operator TEJ Impactor Location #3, outlet Traverse Pt. ~6'
 Date 3/16/81 D.G.M. No. V2 250017 Pb _____
 Andersen Imp No. 4B D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	254	255	256	257	258	259	260	261	6146	

w/cyclone & visibiles (outlet)

Dry Gas Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature Inlet Outlet		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
975.467	0	0.20	47	48	0.50		
979.155	5.0	0.20	44	46	0.50		
980.830	16.0	0.20	42	48	0.55		
983.530	24.0	0.20	42	47	0.60		
986.215	32.0	0.20	43	47	0.60		
988.410	40.0	0.20	45	47	0.65		
991.540	48.0	0.20	47	48	0.65		
994.180	56.0	0.20	50	50	0.70		
996.915	64.0	0.20	51	51	0.70		
999.440	72.0	0.20	49	52	0.70		
1002.110	80.0	0.20	49	52	0.70		
1004.780	88.0	0.20	47	52	0.75		
1007.444	96.0	0.20	48	53	0.80		

Initial leak check 0.002

SI-Gel initial _____

Final leak check _____

SI-Gel final _____

Total H₂O Collected in Flask _____

Net _____

Total H₂O Collected _____

ANDERSEN IMPACTOR FIELD DATA

Plant Fuck Time 1245 Nozzle Dia. _____
 Location Grubbs W Va Run No. outlet blank Avg. ΔP _____
 Operator J. E. H. M. Impactor Location outlet, "2" Traverse Pt. ~6'
 Date 2/10/73 D.G.M. No. V4 2500014 Pb _____
 Andersen Imp No. 21 D.G.M. Y _____ Static "Hg _____

Stage No.	0	1	2	3	4	5	6	7	F	T
Substrate No.	350	351	352	353	354	355	356	357	B5B	

Dry Gas/ Meter Reading	Elapsed Time	Orifice Δh "H ₂ O	Meter Temperature		Orifice S.P. - "Hg	Impactor Temp	Traverse Point
			Inlet	Outlet			
27.275	0	0.20	54	53	1.70		
31.540	4.0	0.20	56	55	1.70		
32.975	16.0	0.20	56	56	1.70		
35.515	34.0	0.20	62	60	1.70		
38.685	32.0	0.20	64	61	1.70		
41.455	40.0	0.20	67	67	1.75		
44.245	48.0	0.20	65	64	1.75		
47.030	56.0	0.20	64	60	1.75		
49.950	64.0	0.20	92	86	1.75		
52.625	72.0	0.20	96	92	1.85		
scrubbed, no pet. disks for filters!							

Initial leak check 0.002SI-Gel initial Final leak check SI-Gel final Total H₂O Collected in Flask Net Total H₂O Collected

APPENDIX E-2

VISIBLE EMISSION OBSERVER FIELD DATA SHEETS



GCA CORPORATION
Technology Division
213 Burlington Road
Bedford, Massachusetts 01730
(617) 275-5441

VISIBLE EMISSION OBSERVATION FORM

Page 1 of 4

Date 3/18/81

Company Name Foote Mineral Co.

Observer Sandra Beaton

Location Graham, W. VA.

U.S. EPA Region

Source: Baghouse ROOF MONITOR


Source Height: ~ 100 ft
Distance from Source: ~ 300 ft
Direction from Source:
Wind Direction: Speed: 0-5 mph
Background(s) Used: (1) SKY
(2) (3)
Colors of Background(s): (1) Blue
(2) (3)
Color of Emissions: (1) Red + Brown
(2) (3)
Ambient Temperature: 40 °F
Relative Humidity: < 50% ☒ > 50% ☐
Reading Conditions: EX ☒ GD ☐ FR ☐ PR ☐

Comments: (Include Contacts)

Observation Point: across R.R. track
in front of power station

Signature: Sandra A. Beaton
Date Last Certified: 10/28/80

Show: Sun, Wind, and North Arrow



COMPANY: Fooke Mineral Co.LOCATION: Graham, W.VA.OBSERVER: S. BeatonDATE: 3/18/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
13 0							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							

Time (M)	0	15	30	45	Proc.	Loca.	Color
30							
31							
32							
33							
34							
35							
13 36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	0	0			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	0	0	0	0			
47	0	0	0	0			
48	0	0	0	0			
49	0	0	0	0			
50	0	0	0	0			
51	0	0	0	0			
52	0	0	0	0			
53	0	0	0	0			
54	0	0	0	0			
55	0	0	0	0			
56	0	0	0	0			
57	0	0	0	0			
58	0	0	0	0			
59	0	0	0	0			

COMMENTS:

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

3.40



COMPANY: Foot Mineral Co
LOCATION: Graham, W, VA.

OBSERVER: S. Beaton
DATE: 3/18/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
0	0	0	0	0			
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	0			
6	0	0	0	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	0	0	0			
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	0	0	0	0			
31	0	0	0	0			
32	0	0	0	0			
33	0	0	0	0			
34	0	0	0	0			
35	0	0	0	0			
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	0	0			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	0	0	0	0			
47	0	0	0	0			
48	0	0	0	0			
49	0	0	0	0			
50	0	0	0	0			
51	0	0	0	0			
52	0	0	0	0			
53	0	0	0	0			
54	0	0	0	0			
55	0	0	0	0			
56	0	0	0	0			
57	0	0	0	0			
58	0	0	0	0			
59	0	0	0	0			

COMMENTS: _____

- a) See legend for abbreviated words.
b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.
c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gr.



COMPANY: Fook Mineral Co.
LOCATION: Graham, W. VA.

OBSERVER: S. Beaton
DATE: 3/18/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
15	0	0	0	0			
	1	0	0	0			
	2	0	0	0			
	3	0	0	0			
	4	0	0	0			
	5	0	0	0			
	6	0	0	5			Red
	7	0	0	0			
	8	0	0	0			
	9	0	0	0			
	10	0	0	0			
	11	0	0	0			
	12	0	5	5			Red
	13	5	5	5			
	14	10	10	5			
	15	5	5	10			
	16	10	5	5			
	17	5	10	20			Br
	18	5	10	20			
	19	15	5	10			
	20	10	5	5			
	21	5	10	10			
	22	5	5	5			
	23	10	10	5			
	24	0	0	0			
	25	10	5	10			
	26	0	0	0			
	27	0	0	0			
	28	5	5	5			
	29	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
	30	0	0	5			
	31	0	0	0			
	32	0	0	0			
	33	10	10	10			Red.
	34	5	5	5			
	35	5	15	15			
	36						
	37						
	38						
	39						
	40						
	41						
	42						
	43						
	44						
	45						
	46						
	47						
	48						
	49						
	50						
	51						
	52						
	53						
	54						
	55						
	56						
	57						
	58						
	59						

COMMENTS:

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.



GCA CORPORATION
Technology Division
213 Burlington Road
Bedford, Massachusetts 01730
(617) 275-5444

VISIBLE EMISSION OBSERVATION FORM

Page 1 of 4

Date 3/18/81

Company Name Fook Mineral Co.

Observer Sandra Beator

Location Graham, W.VA.

U.S. EPA Region

Source: Furnace Bldg.
ROOF + OFFTAKE STACKS

Source Height: 2 200 ft

Distance from Source: 2 200 ft

Direction from Source:

Wind Direction: Speed: 0-5 mph

Background(s) Used: (1) SKY

(2) (3)

Colors of Background(s): (1) blue

(2) (3)

Color of Emissions: (1) white

(2) (3)

Ambient Temperature: 40 °F

Relative Humidity: <50% ☒ >50% ☐

Reading Conditions: EX ☒ GD ☐ FR ☐ PR ☐


Comments: (Include Contacts)

Observation Point: across R.R. tracks
in front of Power station

Signature: Sandra A. Beator

Date Last Certified: 10/28/80

Show: Sun, Wind, and North Arrow



OK
13:40



COMPANY: Foote Mineral Co.
LOCATION: Graham, W.Va.

OBSERVER: S. Beata

DATE: 3/18/81

For:

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
0							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							

Time (M)	0	15	30	45	Proc.	Loca.	Color
30							
31							
32							
33							
34							
35							
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	5	0	0		stuck	wh
40	0	0	0	0			
41	0	0	0	0			
42	0	0	5	5		stuck	wh
43	5	5	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	0	0	5	5		stuck	wh
47	0	0	0	0			
48	0	5	5	10			
49	5	5	5	5			
50	10	15	15	15			
51	10	10	10	10			
52	10	10	10	10			
53	10	10	10	10			
54	10	10	10	10			
55	5	5	5	5			
56	5	5	5	5			
57	5	5	0	0			
58	0	0	0	0			
59	0	0	0	0			

COMMENTS:

- a) See legend for abbreviated words.
b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.
c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray



COMPANY:

LOCATION:

CAST:

OBSERVER:

DATE:

3/18/81

Fce

Time (M)	0	15	30	45	Proc.	Loca.	Color
19	0	0	0	0			
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	5	5	5		stack	white
5	5	0	0	0			
6	0	5	5	5			
7	5	5	5	5			
8	5	5	5	5			
9	5	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	5			
14	0	5	5	5			
15	0	0	5	5			
16	5	5	5	5			
17	0	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	X	0		int f/ lower R.M.	
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	0	0	0	0			
31	0	0	0	0			
32	0	0	0	0			
33	0	0	0	0			
34	0	0	0	0			
35	0	0	0	0			
36	0	0	0	0			
37	0	0	0	0			
38	0	0	0	0			
39	0	0	0	0			
40	0	0	0	0			
41	0	0	0	0			
42	0	0	0	0			
43	0	0	0	0			
44	0	0	5	5		stack	wh
45	5	5	5	5			
46	5	5	5	5			
47	5	5	5	5			
48	5	5	5	5			
49	5	5	5	5			
50	5	5	5	5			
51	5	5	5	5			
52	5	5	5	5			
53	5	5	5	5			
54	5	5	0	0			
55	0	0	0	0			
56	0	0	0	0			
57	5	5	5	5			
58	5	5	5	5			
59	5	0	0	0			

COMMENTS:

a) See legend for abbreviated words.

b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.

c) Color of emissions: (B1) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gra



COMPANY: Frost Mineral Co.
LOCATION: Graham, W. VA.

OBSERVER: S. Benton
DATE: 3/18/81

CAST:

Time (M)	0	15	30	45	Proc.	Loca.	Color
15	0	0	0	5			
1	5	5	5	0			
2	0	5	5	5			
3	5	5	5	5			
4	5	5	0	0			
5	0	0	5	5			
6	5	5	5	5			
7	5	5	5	5			
8	5	5	5	5			
9	5	5	5	5			
10	5	5	5	5			
11	5	5	5	10			
12	5	5	5	5			
13	5	5	5	5			
14	5	5	5	5			
15	5	0	0	0			
16	0	5	5	5			
17	5	0	0	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			

Time (M)	0	15	30	45	Proc.	Loca.	Color
30	0	0	0	0			
31	0	0	0	0			
32	0	0	0	0			
33	0	0	0	0			
34	0	0	0	0			
35	0	0	0	0			
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							

COMMENTS:

- a) See legend for abbreviated words.
b) Location of emissions applicable to a roof monitor: (E) East. (C) Center. (W) West.
c) Color of emissions: (Bl) Black, (Br) Brown. (R) Red. (O) Orange. (W) White. (G) Gray.

APPENDIX E-3
PROCESS OBSERVER FIELD DATA SHEETS

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/16/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
1311	Smelting		95%	
1321	Stoking	VH		
1322	blow st			
1333	Stoking	VH		
1335	charging			~ 30 secs.
13:36:20	end stoking			
13:37	stoking			
13:38	end stoking			
13:38:30	Start test			Normal emissions.
13:41:30	end test			100% Capture - Normal E. throughout test.
13:52	Stoking	VH Surge	90%	
13:53	end stok.			

LE = Light emissions; 5 to 25 percent opacity
 ME = Moderate emissions; 30 to 60 percent opacity
 HE = Heavy emissions; 65 to 100 percent opacity

EPA Contract No. 68-02-2637 Technical Director's Office 010

100

S. Beatix
3/16/81

[illegible]

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER:

S. Beaton

DATE:

3/17/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
9:26	SMELTING	Normal	100	
9:35	stoking			
9:37	end stoking			lowered I door to keep heat off stoking machine.
9:38	Charging			
9:38	Blow	VHE	100%	
9:35	TAPPING		100%	Capture by Tap Hood.
9:43	stoking in progress	VVHE	90%	Same mix Spilling out of fce.
9:44	end stoking			
9:52	START	I.P.	RUN.	Normal Emissions
10:07	PLUGGING TAPHOLE			
10:10	JET CHARGING	HE		
10:14	Normal Emissions			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
Foote Mineral Co., Graham, W. VA
EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
10:16	JET		775% ~ 100%	Blowing MIX OUT FCE.
10:20	Staking in Progress			
10:23	END Staking			
10:28	Hard BLOW		795%	SHOOTING MIX OUT
10:31	STOKING			
10:32	END STOKING			
10:35	Hard BLOW		100%	
10:37	Charging		100%	~ 4 minutes
10:38	STOKING			for 1 minute
10:45	CHARGING			
10:48	HARD BLOW			
	CONTINUING	VH		

LE = Light emissions; 5 to 25 percent opacity
ME = Moderate emissions; 30 to 60 percent opacity
HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02 2697 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
10:57	Stoking	VHE	100	
10:59	END STOKING			
10:59	START RUN			Normal fumes throughout test.
11:03	END TEST			
11:12	poking plug out	Taphole		
	START RUN (I.P.)			
	TAPPING			
11:13	Stoking in progress			
11:15	END.			
	SMELTING	to 11:31		
11:32	STOKING			~ 1.0 min.
11:41	BLOW	VHE		BLOWING MIX. OUT FCE.
11:43	STOKING			

LE = Light emissions; 5 to 25 percent opacity
 ME = Moderate emissions; 30 to 60 percent opacity
 HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By hood	Comments
11:46	PLUGGING —			
WILL 11:49	SHOOT OUT PLUG SLAG etc.			
11:52	STILL TAPPING			
11:52	SHOOTING TAPHOLE			
11:58	STILL NOT RUNNING WELL			
12:05	to 12:15 —		Break	
12:19	Smelting			
12:22	hard blows			
12:23	Stoking			≈ 2 mins.
12:37	Normal			
12:45	PLUGGED TAPHOLE			
12:47	STOKING			≈ 1.0 minute
12:49	SMEETING —			heavier than normal
13:00	Stoking HE			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*

DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
13:17	stoking		100	≈ 1.0 min.
13:22	2 blows	HVE	100	≈ 30 sec.
13:23	charging	start Run (?)	≈	10 secs.
13:25	charging	* Blowing HE		
13:27	stoking	VHE		
	END RUN			
13:29	end stoking			
13:29	stoking			≈ 1.0 min.
14:03	PLUGGING TAP HOLE	start a Run		
14:05	PLUGGED	END RUN		Note: had to shut the plug out. fce is sluggy so had to let it run
14:08	BLOW	VHE		≈ 2.0 min.
				Furnace is running smoothly now.

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
14:12	charging mty			△ 10 sec. Normal Emissions
14:26	BLOW	HE		
14:29	Stoking	till Stoking	100	
14:30	end Stoking			
14:42	around	start Run.		
14:45				still tapping - have been all along.
	SMELTING			
14:55	BLOW			△ 5 sec.
14:55	STOKING			
15:01	added mty.			△ 5 sec.
15:02	Stoking			
15:03	end Stoking			
15:06	PLUGGED			

LE = Light emissions: 5 to 25 percent opacity

ME = Moderate emissions: 30 to 60 percent opacity

HE = Heavy emissions: 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: S. Beaton
 DATE: 3/17/81

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
1522	JET			
1521	START	RUN.		
1523	Charge			5 secs:
1524	Charge			5 secs:
1525	Stoking	MHE	100	
1533	END STOKING			
1547	BLOW			
1548	Stoking			5 secs.
1554	Stoking	VHE		
1557	END STOKING			
16:15	tapping - poking			plug out.
16:24	Flowing	GOOD		

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALEABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
<i>16:25</i>	<i>Stoking in progress</i>			
<i>16:26</i>	<i>END STOKING</i>			
<i>16:30</i>	<i>BLOW</i>			
<i>16:31</i>	<i>STOKING</i>			
<i>16:33</i>	<i>END STOKING</i>			
<i>16:36 or 37</i>	<i>Start run</i>			<i>Normal fee emissions Still Tapping.</i>
<i>16:40:58</i>	<i>Run Over With</i>			
<i>16:55</i>	<i>add mix.</i>			<i>2 secs.</i>
<i>16:56</i>	<i>Stoking HE</i>		<i>100%</i>	
<i>16:58</i>	<i>END stoking</i>			
<i>17:07</i>	<i>Stoking</i>			
<i>17:11</i>	<i>END STOKING</i>			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/17/81*

PROCESS DATA

Time	Process	Magnitude of Emissions	Percent Capture B. Pool	Comments
17:11	SMELTING		100	NORMAL FUMES
17:24	"			
17:36	JET	VHE		spitting mix
17:37	STOKING			
17:41	END STOKING			
17:47	TAPPING IN PROGRESS			
	RUN TEST			
17:54	JET			
17:55	STOKE			
17:57	END STOKE			
18:20	add mix			5 sec.
18:21	testing			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

DATE:

INHABITABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foster Mineral Co., Graham, W. VA
 EPA Contract No. 68-02-2697 Technical Directive 017

OBSERVER: *S. Bator*
 DATE: *3/17/81*

CONTROL ROOM DATA

Time	9:29	9:48	10:14	10:41	11:28	12:24	13:50	15:00
Furnace MW.	25.48	28.88	28.49	30.83	29.76	30.69	32.62	31.62
Power Factor	.54	.6143	.5951	.6711	.6686	.6849	.7465	.7258
Mega Vars.	47	45	45	44	42	43	38.5	40.5
KWH		4938.8						
TIME	15:46	16:46	17:38	16:22				
Furnace MW.	32.21	31.87	31.35	30.37				
Power Factor	.7128	.7335	.7072	.6735				
Mega Vars.	41	39.0	42	43				
KWH				4966.1				

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
Foote Mineral Co., Graham, W. VA
EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *clw*

DATE: *3/18/81*

PROCESS DATA

Time	Process	Magnitude of Emissions <i>purpose</i> <i>flame</i>	Percent Capture By Hood	Comments
12:58	PLUGGING		100	
	START RUN			
13:03	STOKING			
13:05	Tap plugged			
13:14	blow - 15 sec	Heavy	100	
13:15	add mix - stake			
13:17	stop stake			
	add mix stake			
13:31				
13:42	right blow add mix stake	moderate	100	
14:14	Hand blow add mix stake	Heavy (for 15 sec)	80%	
14:15	stake	moderate	100	
13:45	tap			
14:15	plug tap			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-268 Technical Directive 017

PROCESS DATA

OBSERVER: *cww*
 DATE: *3/18/81*

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
14:39	add mix	light	100	
14:45	stake	moderate	100	Loaded ~ 2 min
14:50	Tapping		100	
15:07	Add mix	moderate	100	
15:10	stake	" "	" "	
15:20	Plug Tap			
15:40	stoking	Heavy moderate	90%	(moderate most of time with 100% capture) Hood blow on one phase during stake
16:02	BLOW			≈ 1.0 min.
16:06	add mix			5 sec
	stoking			
16:20	BLOW	Heavy		
16:15 also	TAPPED			
16:22	stoking			

LE = Light emissions; 5 to 25 percent opacity

ME = Moderate emissions; 30 to 60 percent opacity

HE = Heavy emissions; 65 to 100 percent opacity

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Foote Mineral Co., Graham, W. VA
 EPA CONTRACT No. 68-02-2687 Technical Directive 017

OBSERVER: *S. Beaton*
 DATE: *3/18/81*

PROCESS DATA

before

Time	Process	Magnitude of Emissions	Percent Capture By Hood	Comments
16:26	<i>end stoking</i>		<i>100</i>	
16:39	<i>stoking</i>			
16:44	<i>END TAPPING</i>			
16:49	<i>START RUN</i>			<i>Normal Emissions</i>
16:56	<i>END TEST.</i>			
17:00	<i>add mix</i>			
17:02	<i>stoking</i>	<i>HEAVY</i>		
17:09	<i>END stoking</i>			

LE = Light emissions; 5 to 25 percent opacity
 ME = Moderate emissions; 30 to 60 percent opacity
 HE = Heavy emissions; 65 to 100 percent opacity

OBSERVER: S. Beaton
DATE: 3/18/81

[illegible]

7-1-72

INHALABLE PARTICULATE FIELD SAMPLING PROGRAM
 Route "Ingram" (C. Graham, W. VA)
 EPA Contract No. 68-00-2037 Technical Directive 017

OBSERVER: G. ROSENBERG
 DATE: 03/17/81 2/18/80

BAGHOUSE CONTROL ROOM DATA

TIME	COMPARTMENT	PRESSURES (inches Water)	TEMP	FAN AMPS	COMBINED TIMER SETTINGS
1100	1 2 3 4	5 6 7 8 9 10 11	420	285	COLLECTION CYCLE 15 min
1230			420	285	CLEAR PERIOD 45 secs
1500	12.5 13 12.5 0 11 11	11.5 10.2 10.5 10.5 10.8	420	290	NULL PERIOD 30 secs
1725			420	302	SOFT REINITIATE 20 secs
1843	10 10.5 10.5 10 9.5 10	9.5 11.5 9.5 9.5 9.5 9.5	410	291	
	2 Compartment feed valve off				
	TESTS 1-3 above	3/18/81	Test 4, 5, 6 Below		
0915	11 11	10.8 10.5 9 0 10.5 9	9 9 380	290	
1305	9.7 9.7 10 9 9	8.5 9 8.5 9 8.5 0 8.2 420		290	
1430	10.2 10.5 11 10.5 10 9.5	9.7 10 9 9 9.5 590		290	

Foots Mineral Co., Graham, W. Va.

CONFIDENTIAL

DATE. 03/18/51

BAGHOUSE DATA

[illegible]

Fact Sheet: American Air Filter
Fume Collectors, Graham

247
4260

	#2	#5
Gas Volume	450,000 ACFM	250,000 ACFM
Max Operating Temp.	550° F	550° F
Max System Sp	24" W. G.	24" W. G.
Main Fans	2 @ 1500 HP	1 @ 1500 HP
Reverse Air Fans	1 @ 300 HP	1 @ 300 HP
Auxilliaries	150 HP	125 HP
Total HP	3450	1925
<u>Physical Size</u>		
Length	157'	100'
Width (Incl. Precoolers)	92'	79'
Height	90' +	90' +
Duct Diameter	12' - 6"	9' - 2"
<u>Compartments</u>		
Number	11	7
No. Bags/Comp.	256 - 2816	256 - 1792
Size	11 3/4" x 31'	11 3/4" x 31'
Mat'l.	Glass Cloth	
	Crows Foot Weave,	
	15 - 20 perm -	
	Siliconized, Graphitized	
Life Of Bags (Approx.)	2 yrs.	2 yrs.

APPENDIX E-4

DUAL CYCLONE SAMPLER FIELD DATA SHEETS

IP DUAL CYCLOPE SAMPLER FIELD DATA

8618 C 10

Plant Name ECOT No. to # 3.5 mm Diameter 0.138"
 Location Asheboro, NC Av. Sp. 0.7 Stack T 400
 Date 3/17/85 Barom P. 29.7 Static P -1.0"
 Operator H. O. O. Start Time 0953 Meter # V-3 Y = 1
 IP Sampler # 1 Impactor Location 1-B 0.85'
 Run No. 1-B-0.85 % Moisture 21% Leak Check 0.01 sec³/hr
1-2
 Filter # none X Part. Bottle# — III Part. Bottle# —

DGM Reading	Elapsed Time	Orifice Δh ("H ₂ O)	Meter Temperature		Orifice SP-"Hg	Comments
			Inlet	Outlet		
153.952	0	0.08	35	40	0.0	
154.01	5	0.08	35	40	0.2	out to
154.75	10	0.08	35	40	0.1	0.15 (2 Ev)
155.45	15	0.08	35	40	0.2	
156.57	20	0.08	36	41	0.2	
157.67	25	0.08	36	41	0.2	switch to 1
158.66	30	0.08	44	49	0.2	
159.74	35	0.08	44	49	0.2	
160.80	40	0.08	43	49	0.3	
162.08	46	0.08	44	49	0.5	
162.93	50	0.08	45	50	0.8	
163.99	55	0.08	45	50	1.0	
164.96	60	0.08	45	50	3.2	Andersen
166.03	65	0.08	45	50	5.4	Runny
166.11	65	0.08	45	50	6.0	stop
167.32	71	0.08	45	50	2.0	NOTE: Atic
170.52	86	0.08	45	50	2.9	andersen
171.66	91	0.08	45	50	3.2	was removed
172.78	96	0.08	45	50	3.6	static P
173.90	101	0.08	45	50	3.9	dropped
174.99	106	0.08	45	50	4.3	Andersen

TP DUST CYCLONE SAMPLER FIELD DATA

pg 2 of 2

Plant Name Foota Nozzle # 3/17 contd Diameter _____
 Location Graham Ave Av. AP Run 1-2 Back T _____
 Date 3/17/81 Barom P _____ Static P _____
 Operator Holbo Start Time _____ Meter _____
 IP Sampler # 1 Impactor Location _____
 Run No. 1-B-85 % Moisture _____ Leak Check _____
1-2
 Filter # not used X Part. Bottle# _____ Ill Part. Bottle# _____

DGM Reading	Elapsed Time	Orifice Δh ("H ₂ O)	Meter Temperature		Orifice SP-"Hg	Comments
			Inlet	Outlet		
177.20	116	0.8	44	50	0.2	Jiggly hoses
178.31	122	0.8	45	50	0.3	2 wind caused
179.09	126	0.8	45	50	1.4	static P to
180.21	131	0.8	45	50	0.3	disco.
STOPPED TO REPLACE SIL @ 132						
181.42	137	0.8	43	45	0.9	Knocking
182.56	142	0.8	43	48	1.0	Sil 62N
186.57	160	0.8	42	49	1.4	Containers
- 170 removed IP for And. -						
→ inserted in B-0.15 →						
187.82	170					
189.22	175	0.8	38	43	1.7	
191.51	185	0.8	38	43	1.6	
→ 190 Andersen in for ramp; @ B-15						
192.64	191	0.8	38	43	1.9	
194.42	198	0.8	35	43	2.2	
- stopped to run Andersen @ 199 -						
- Reinserted @ B-0.15 -						

IP DUAL CYCLONE MILLER TEST DATA

Plant Name Fonte Nozzle # 861182 Diameter 0
 Location Evolution, Va App. SP 0.7 to 0.8" and Inlet T 400°F
 Date 5/13/81 Barom P 29.0 Static P -1.0"
 Operator H. J. / A. Start Time 1653 Meter # V-3 Y = 11
 IP Sampler # Impactor Location B-0.15
 Run No. 1P-3/4 % Moisture ~1% Leak Check 0.015 sec

Filter # X Part. Bottle# III Part. Bottle#

DGM Reading	Elapsed Time	Orifice Δh ("H ₂ O)	Meter Temperature		Orifice SP-"Hg	Comments
			Inlet	Outlet		
194.718	0:00	0.08	38	44	0	
196.48	7:00	0.08	37	42	2.2	
197.80	13:00	0.08	37	42	7.4	
199.34	18:00	0.08	35	43	1.5	- Start of run Anderson sk begin at A-0.1
200.45	-	-	-	-	-	- Kink in hose slowed gas flow
200.59	30:00	0.08	37	43	0.8	
203.83	41:00	0.08	37	43	1.0	
205.63	51:00	0.08	37	43	1.2	
207.88	60:00	0.08	37	43	2.0	- Turn off to run Anderson - 12 ft in dist back to A-0.15
209.19	68:00	0.08	37	43	1.5	
211.54	85:00	0.08	37	43	1.2	
[5/13 - 1072 A-0.15 (P) ~ 13:00 hours]						
212.73	91:00	0.08	35	40	0.6	
216.01	101:00	0.08	38	42	0.8	
218.16	131:00	0.08	39	43	0.5	
220.30	142:00	0.08	40	44	2.0	
220.75	143	0.08	40	44	0.6	← Filled out for An
223.21	154	0.08	53	54	0.8	← into B-0.15

IP DUAL CYCLONE SAMPLER FIELD DATA

Plant Name _____ Nozzle # _____ Diameter _____
 Location _____ Ave. Alt. Run 3/4 _____
 Date _____ Barom. _____ _____
 Operator _____ Start Time _____ Meter # _____ Y = _____
 IP Sampler # _____ Impactor Location _____
 Run No. _____ % Moisture _____ Leak Check _____
 Filter # _____ X Part. Bottle# _____ III Part. Bottle# _____

DCM Reading	Elapsed Time	Orifice Δh ("H ₂ O)	Meter Temperature		Orifice SP-"Hg	Comments
			Inlet	Outlet		
224.73	160 ²³⁹	0.05	51	56	1.0	Switch used
226.22	166	0.05	51	56	2.8	off for ~ 3 min
228.45	176 ²⁵⁵	0.08	50	57	1.0	
230.00	183	0.05	50	57	1.1	STOPPED
231.36	189 ²⁶⁵	0.08	42	45	0.8	TO RUN
233.43	195	0.05	42	48	1.1	AND
235.65	208	0.08	42	45	1.0	FOR 8 min
238.50	224 ²⁸¹	0.05	42	45	0.8	
204.52	233	0.05	41	45	1.6	
242.31	241	0.08	42	49	1.1	
244.272	250	0.08				

APPENDIX E-5
GRAVIMETRIC ANALYSIS DATA SUMMARY SHEETS

GCA/TECHNOLOGY DIVISION

BURLINGTON ROAD, BEDFORD, MASSACHUSETTS 01730 / PHONE: 617-275-9000

SHEET 1 OF 3

BY SG

DATE 4/14

CH'K. BY _____

DATE CH'K. _____

S'K. CH'K. BY _____

JOB NO. 1 616-027

PROJECT FRONT HILL COPPER RESULTS

SUBJECT 102 HILLTOP 1P

LAST FINAL - LAST INITIAL NET

Corr factor = -0.025 mg/ml.

RUN NO	IRK.#	LAST FINAL	LAST INITIAL	NET -mg-	mls	Corrected Net.
1IA 15	B155	108.22059	108.21132	9.27	65	10.89
1IA 85	B177	106.11072	106.11336	2.26	45	3.38
1IB 15	B145	108.42246	108.41717	5.23	30	5.98
1IB 85	B191	108.4459	95.35610	11.89	75	13.76
2IA 15	B153	103.17172	103.13910	2.62	65	4.24
2IA 85	B110	108.73200	108.73000	2.00	60	3.50
2IB 15	B 78	96.21101	96.20550	4.51	90	6.76
2IB 85	B 13	109.45335	109.43710	1.15	50	2.40
3IA 15	B200	101.45139	101.44030	3.09	150	6.84
3IA 85	B157	96.15301	96.15100	2.57	80	4.57
3IB 15	B200	106.74266	106.74370	-1.04	55	0.34
3IB 85	B 20	103.48660	103.47450	2.10	70	4.35
4IA 15	B142	103.46500	103.46333	1.67	50	2.12
4IA 85	B164	106.68737	106.68000	1.77	75	3.64
4IB 15	B171	106.78171	106.78070	2.09	50	3.64
4IB 85	B 113	95.81500	95.84132	-0.77	75	1.10
5IB 15	B 77	109.00330	109.00000	-1.24	50	1.01

GCA/TECHNOLOGY DIVISION

BURLINGTON ROAD, BEDFORD, MASSACHUSETTS 01730 / PHONE: 617-275-9000

SHEET 2 OF 3

BY 56

DATE 4/14

CH'K. BY _____

DATE CH'K. _____

B'K. CH'K. BY _____

JOB NO. 1-616-027

PROJECT Front Yard Cont'd

SUBJECT _____

Loc.	Sample #	21	22	23	24	25	26
10A	B111	101.92759	101.92680	0.79	30	1.54	
10B	B113	103.87460	103.87380	16.20	90	18.45	
20A	B120	104.17540	104.17754	-2.14	70	-0.39	
20B	B116	106.81.75	106.81.750	-0.75	50	0.50	
30A	B172	104.64435	104.64442	-0.57	60	0.93	
30B	B151	103.77412	103.77412	-0.02	40	0.98	
40A	B143	95.00663	95.00790	-1.27	40	-0.27	
40B	B173	102.30850	102.30836	0.14	40	1.14	
50A	B131	95.90910	95.91020	-1.20	50	0.05	

Loc.	Sample #	21	22	23	24	25	26
BLK-1	B150	80.62853	80.63040	-1.87	60	0.031	
BLK-2	B134	83.56565	83.56655	-0.90	45	0.02	
BLK-3	B154	102.13168	102.13209	-0.41	75	0.05	
BLK-4	B144	102.96650	102.96680	-0.80	65	0.02	
BLK-5	B126	102.44103	102.44266	-0.38	75	0.05	
BLK-6	B112	102.25910	102.25950	-0.80	100	0.0	
BLK-7	B145	100.12536	100.12503	-1.17	60	0.0	

GCA/TECHNOLOGY DIVISION

BURLINGTON ROAD, BEDFORD, MASSACHUSETTS 01730 / PHONE: 617-275-9000

SHEET 3 OF 3

BY SG

DATE 4/14

CH'K. BY _____

DATE CH'K. _____

B'K. CH'K. BY _____

JOB NO. 1-616-007

PROJECT IP 6102. F007E

SUBJECT _____

IP
SINGLES

	RUSS	SECK	LAST	LAST Z	Net (mg)	ml	Corr. Net
SA	IP-1-2	3.207	100.39450	100.33000	64.5	11.5	63.38
	IP-1-2	B.147	101.45350	101.44101	12.49	6.5	14.12
SM	IP-3-4	B.177	102.71701	102.70406	42.95	1.85	47.58
"	IP-5-6	B.122	84.11621	84.10902	7.21	6.5	8.84

WEIGHED
FOR - TOM EPSTEIN

WEIGHED
BY - LYNN Sorensen

15um DRY CATCHES

sample no#	time	Date	1st weight	time	Date	2nd weight	time	Date	1st (clean) weight
15-1/4	14:20	3/26	22.76336	14:15	3/27/81	22.76351	14:20	3/30	22.74300
15-1/2	"	"	22.86600	"	"	22.86620	"	"	22.82376