

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

|                    |                                                                                                                                                                                                                                |
|--------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| AP32 Section:      | 12.5.1                                                                                                                                                                                                                         |
| Background Chapter | 3                                                                                                                                                                                                                              |
| Reference:         | 37                                                                                                                                                                                                                             |
| Title:             | Source Evaluation Report, Oregon Steel Mills, Portland, OR, Electric Arc Furnace Baghouse.<br>December 27, 2000. Prepared for Oregon Steel Mills, Portland, OR by Michele R. Kinney & David R. Rossman, P.E. Project No. 1536. |



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizone@teleport.com

37

Project No. 1536

## SOURCE EVALUATION REPORT

### Oregon Steel Mills Portland, Oregon

#### Electric Arc Furnace Baghouse Total Suspended Particulate (TSP), CO, NO<sub>x</sub>, SO<sub>2</sub>, VOC, Lead and Opacity

December 27, 2000

Prepared for  
Oregon Steel Mills  
14400 N. Rivergate Blvd.  
Portland, Oregon 97203

by Michele R. Kinney &  
David R. Rossman, P.E.



Expires 12/31/02

## TABLE OF CONTENTS

|                                       | <u>Page Number</u> |
|---------------------------------------|--------------------|
| 1. Certification                      | 4                  |
| 2. Introduction                       | 5                  |
| 3. Summary of Results                 | 6                  |
| 4. Source Description and Operation   | 9                  |
| 5. Sampling and Analytical Procedures | 11                 |
| 6. Discussion                         | 14                 |

DEPT OF ENVIRONMENTAL QUALITY  
RECEIVED

FEB 15 2001

NORTHWEST REGION

## APPENDIX

|                                                          | <u>Page Number</u> |
|----------------------------------------------------------|--------------------|
| <b>Nomenclature &amp; Drift Correction Documentation</b> | <b>15</b>          |
| <b>Particulate and Lead Calculation Sheets</b>           | <b>17</b>          |
| Emission Calculation Worksheets                          |                    |
| Field Data Sheets                                        |                    |
| Blank Correction and Filter Rinse Allocation             |                    |
| Laboratory Results and Worksheets                        |                    |
| Baghouse Sampling Diagram                                |                    |
| <b>Volume Flow Rate Determination</b>                    | <b>46</b>          |
| Flow Rate Determinations and Field Data                  |                    |
| Traverse Point Location – Inlet & Outlet                 |                    |
| <b>Visible Emission Data</b>                             | <b>59</b>          |
| <b>Gaseous Emissions</b>                                 | <b>60</b>          |
| Gaseous Emissions                                        |                    |
| Molecular Weight Determinations                          |                    |
| Analyzer Calibration Data and Bias Checks                |                    |
| Data Logger Gas Charts                                   |                    |
| Strip Charts                                             |                    |
| <b>Production/Process Data</b>                           | <b>72</b>          |
| Furnace Heat Logs                                        |                    |
| Baghouse Pressure Drop Field Data                        |                    |
| <b>Calibration Information</b>                           | <b>80</b>          |
| High-Volume Sampler Calibrations                         |                    |
| Pitots                                                   |                    |
| Thermocouples and Indicators                             |                    |
| Shortridge Micro manometer                               |                    |
| Magnehelic                                               |                    |
| Barometer                                                |                    |
| Filter Tare Weights                                      |                    |
| NOx Converter Efficiency Test                            |                    |
| Calibration Gas Certificates                             |                    |
| Audit Sample Results, reporting forms and instructions   |                    |
| <b>QA/QC Documentation</b>                               | <b>111</b>         |
| <b>Correspondence</b>                                    | <b>114</b>         |
| Source Test Plan and Correspondence                      |                    |
| Permit (Selected Pages)                                  |                    |

## 1. CERTIFICATIONS

### 1.1 Test Team Leader

I hereby certify that the test detailed in this report, to the best of my knowledge, was accomplished in conformance with applicable rules and good practices. The results submitted herein are accurate and true to the best of my knowledge.

Name: C. David Bagwell

Signature C. David Bagwell Date 2/5/01

### 1.2 Report Reviewer

I hereby certify that I have reviewed this report and find it to be true and accurate, and in conformance with applicable rules and good practices, to the best of my knowledge.

Name: David R. Rossman, P.E.

Signature David Rossman Date 2/12/01

## 2. INTRODUCTION

**2.1 Client:** Oregon Steel Mills

**2.2 Physical Location:** 14400 N. Rivergate Blvd., Portland, OR 97208

**2.3 Mailing Location:** P. O. Box 2760, Portland, OR 97208

### 2.4 Test Log

| Test Date         | Source Name                      | Pollutants                                                                    |
|-------------------|----------------------------------|-------------------------------------------------------------------------------|
| December 27, 2000 | Electric Arc Furnace<br>Baghouse | Particulate, CO, NO <sub>x</sub> , SO <sub>2</sub> , VOC,<br>Lead and Opacity |

**2.5 Test Purpose:** Emission factor verification as required by Title V Permit No. 26-1865 issued by the Oregon Department of Environmental Quality (ODEQ).

**2.6 Background Information:** None.

### 2.7 Participants

Horizon Personnel:

C. David Bagwell, Team Leader  
Brian T. Fallon, Field Technician  
Michael J. Eisele, Field Technician  
Tim J. Hertel, Field Technician  
Michael E. Wallace, QA/QC Officer  
David R. Rossman, P.E., Report Review  
Michele R. Kinney, Technical Writer

Test Arranged by: Debbie Deetz Silva, Oregon Steel Mills

Test Plan Sent to: Jack Herbert, ODEQ.

### 3. SUMMARY OF RESULTS

#### 3.1 Table(s) of Results

Table 1

#### Particulate and Lead Test Results

Test Date: December 27, 2000

|                            | Units               | Run 1   | Run 2   | Run 3   | Average |
|----------------------------|---------------------|---------|---------|---------|---------|
| Start Time                 |                     | 11:39   | 13:18   | 14:55   |         |
| End Time                   |                     | 13:16   | 14:52   | 16:29   |         |
| Sampling Time              | min                 | 80      | 82      | 80      | 81      |
| <b>Sampling Results</b>    |                     |         |         |         |         |
| Particulate Conc.(Actual)  | gr/scfd             | 0.00038 | 0.00054 | 0.00031 | 0.00041 |
| Particulate Rate           | lb/hr               | 1.5     | 2.0     | 1.2     | 1.6     |
| Based on Cold Charge       | lb/ton              | 0.0093  | 0.0161  | 0.0089  | 0.0114  |
| Sample Volume              | dscf                | 2,276   | 2,082   | 2,247   | 2,202   |
| Sample Weight, Total       | mg                  | 55.3    | 73.4    | 44.5    | 57.8    |
| Percent Isokinetic         | %                   | 98      | 99      | 99      | 99      |
| Lead Rate                  | lb/hr               | 0.026   | 0.046   | 0.024   | 0.032   |
| Based on Cold Charge       | lb/ton              | 0.00015 | 0.00037 | 0.00017 | 0.00023 |
| % of Total Particulate     | %                   | 1.67    | 2.33    | 1.91    | 1.97    |
| Opacity                    | %                   | 0       | 0       | 0       | 0       |
| <b>Source Parameters</b>   |                     |         |         |         |         |
| Inlet Flow Rate            | dscf/min            |         |         |         | 410,000 |
| Outlet Flow Rate           | dscf/min            | 477,000 | 426,000 | 473,000 | 459,000 |
| Inlet Velocity             | ft/min              |         |         |         | 5,650   |
| Outlet Velocity            | ft/min              | 656     | 599     | 668     | 641     |
| Temperature, Outlet        | °F                  | 160     | 171     | 180     | 170     |
| <b>Process Data</b>        |                     |         |         |         |         |
| Cold Charge Production     | tons/hr             | 166     | 124     | 139     | 141     |
| Baghouse Press. Drop, Avg. | in H <sub>2</sub> O | 5.2     | 5.1     | 5.5     | 5.3     |

Table 2

**Gaseous Emissions Test Results**

**Test Date:** December 27, 2000

|                               | Units  | Run 1 | Run 2 | Run 3 | Average           |
|-------------------------------|--------|-------|-------|-------|-------------------|
| Start Time                    |        | 11:39 | 13:18 | 14:55 |                   |
| End Time                      |        | 13:16 | 14:52 | 16:29 |                   |
| Sampling Time                 | min    | 80    | 82    | 80    | 81                |
| <b>Sampling Results</b>       |        |       |       |       |                   |
| O <sub>2</sub>                | %      | 20.5  | 20.4  | 20.4  | 20.4              |
| CO <sub>2</sub>               | %      | 0.4   | 0.5   | 0.5   | 0.5               |
| CO Concentration              | ppmv   | 126   | 76    | 97    | 100               |
| Rate                          | lb/hr  | 225   | 136   | 174   | 178               |
| Based on Cold Charge          | lb/ton | 1.36  | 1.09  | 1.25  | 1.23              |
| NO <sub>x</sub> Concentration | ppmv   | 8     | 9     | 11    | 9                 |
| Rate                          | lb/hr  | 22.3  | 25.0  | 33.0  | 26.8              |
| Based on Cold Charge          | lb/ton | 0.14  | 0.20  | 0.24  | 0.19              |
| SO <sub>2</sub> Concentration | ppmv   | 4     | 3     | 3     | 3                 |
| Rate                          | lb/hr  | 16.8  | 11.1  | 11.4  | 13.1              |
| Based on Cold Charge          | lb/ton | 0.10  | 0.09  | 0.08  | 0.09              |
| TGOC Concentration            | ppmv   | 16    | 10    | 8     | 11                |
| Rate                          | lb/hr  | 12.4  | 7.8   | 5.8   | 8.7               |
| Based on Cold Charge          | lb/ton | 0.08  | 0.06  | 0.04  | 0.06              |
| TGNMOC Concentration          | ppmv   |       |       |       | 27 <sup>1</sup>   |
| Rate                          | lb/hr  |       |       |       | 1.7 <sup>1</sup>  |
| Based on Cold Charge          | lb/ton |       |       |       | 0.01 <sup>1</sup> |

**3.2 Description of Collected Samples:**

See Blank Correction and Rinse Allocation in Appendix.

<sup>1</sup> Total Gaseous Non-Methane Organic Compounds (TGNMOC) numbers were figured using the VOC Methane component of 80.2% from the October 20, 1998 testing.

### 3.3 Discussion of Errors and Quality Assurance Procedures

This table is taken from a paper entitled "Significance of Errors in Stack Sampling Measurements", by R.T. Shigahara, W.F. Todd and W.S. Smith. It summarizes the maximum error expressed in percent, which may be introduced into the Method 5 particulate test procedures by equipment or instrument limitations.

| Measurement                              | % Max Error |
|------------------------------------------|-------------|
| Stack Temperature $T_s$                  | 1.4         |
| Meter Temperature $T_m$                  | 1.0         |
| Stack Gauge Pressure $P_s$               | 0.42        |
| Meter Gauge Pressure $P_m$               | 0.42        |
| Atmospheric Pressure $P_{atm}$           | 0.21        |
| Dry Molecular Weight $M_d$               | 0.42        |
| Moisture Content $B_{ws}$ (Absolute)     | 1.1         |
| Differential Pressure Head $\Delta P$    | 10.0        |
| Orifice Pressure Differential $\Delta H$ | 5.0         |
| Pitot Tube Coefficient $C_p$             | 2.4         |
| Orifice Meter Coefficient $K_m$          | 1.5         |
| Diameter of Probe Nozzle $D_n$           | 0.80        |

QA procedures outlined in the test methods are followed, including procedures, equipment specifications, calibrations, sample recovery and handling, calculations and performance tolerances. Many of the checks performed have been noted on the Field Data Sheets.

Three audit samples (two liquid samples and one filter sample), prepared by EPA in accordance with Method 12 and provided to Jack Herbert of ODEQ, were submitted to the particulate analysis laboratory (Antech) along with the filter and acetone samples collected during the source test. The particulate analysis laboratory is responsible for drying and weighing of the samples prior to Environmental Services Laboratory (ESL) performing the lead analysis. Following the instructions from ODEQ, the two sealed liquid audit samples were also opened and dried along with the source test and audit filter samples. It should be noted that EPA

instructions with the audit samples do not specify any drying of the audit samples prior to analysis.

From the particulate analysis laboratory, the samples were submitted to ESL for lead analysis. It is Horizon's understanding that ESL re-dissolved the samples with nitric acid and analyzed for lead content consistent with EPA lead analysis methods.

On January 25, 2001, Horizon Engineering notified Jack Herbert via e-mail of the audit sample lab results. Horizon has been not informed of the actual EPA audit sample values. According to Mr. Herbert, two of the three audit samples (the spiked filter and one of the liquid samples) were acceptable and within the Method 29 allowed range of plus or minus 25%. The remaining liquid audit sample was outside that range.

The audit sample lab results are in the Calibration Information section of the Appendix.

#### **4. SOURCE DESCRIPTION AND OPERATION**

##### **4.1 Process and Control Device Description and Operation:**

The EAF baghouse at Oregon Steel Mills cleans particulate from two significant sources in the melt shop. The main furnace, No. 3, normally produces between 100 and 115 tons of steel per heat from two charges of scrap metal, plus some molten "pour back" material left over from casting. Records for each heat during the testing times are in the Production-Process Data Section of the Appendix.

The main furnace dust control system is a "fourth hole" duct connection to the top of the furnace, and a series of three openings in the roof above the main furnace that can open into the duct to the baghouse. Each of these pick-up points has a damper that is controlled automatically by certain furnace operations. Generally, the roof vents are open for several minutes following charging of the furnace.

The ladle metallurgy furnace is between the main furnace and the casting area and is used to fine-tune the content and temperature of the molten steel before being cast. Charging is only of molten steel and alloying material and is the minor contributor to the baghouse system. The exhaust from this furnace enters the duct system downstream from the main furnace and roof vents.

All of the pick-up points are evacuated into an 11 foot-diameter duct by two 1250-Hp fans. The fans have automatically controlled dampers on the inlets.

Particulate control is by a 16-compartment, (21 ft. by 14 ft. each) Industrial Clean Air, reverse-air type, baghouse with seamless tube polyester bags. Magnehelic gauges on each of the compartments showed pressure drops averaging 5.3 inches of water.

#### **4.2 Test Ports:**

Ports and traverse points are described and diagrammed on the Field Data sheets.

#### **4.3 Test Duct Characteristics:**

Cyclonic Flow: No Cyclonic flow expected.

Meets EPA M-1 Criteria: No.

**4.4 Process & Control Equipment Flow Diagram:** See Process-Sampling Equipment Flow Diagram in Appendix

**4.5 Operating Parameters:** See Production/Process Data section of Appendix

**4.6 Process Startups/Shutdowns or Other Operational Changes During Tests:** The process was continuous during testing.

## 5. SAMPLING AND ANALYTICAL PROCEDURES

### 5.1 Sampling Procedures

#### 5.1.1 Sampling and Analytical Methods

Flow Rate: EPA Methods 1 and 2 (S-type pitot flow traverses)  
CO<sub>2</sub> and O<sub>2</sub>: EPA Method 3A (NDIR and paramagnetic analyzers)  
Moisture: ODEQ Method 4 (psychrometry – wet bulb / dry bulb)  
Particulate: ODEQ Method 8 (High Volume sampler)  
Lead: Analysis of the filters and sampler residue for lead.  
Residue allocated to the runs according to Method 8  
procedure 11.2.1. Analysis by EPA 6010 (ICP).  
SO<sub>2</sub>: EPA Method 6C (non-dispersive ultraviolet analyzer)  
NO<sub>x</sub>: EPA Method 7E (chemiluminescent analyzer)  
CO: EPA Method 10 (gas filter correlation analyzer)  
VOC as total gaseous organic compounds (TGOC) by EPA Method 25A,  
(heated flame ionization analyzer and sample line)  
Opacity: EPA Method 9 (six minutes per run)

#### 5.1.2 Sample Analysis

| <u>Analyte</u>                                        | <u>Laboratory</u>                    |
|-------------------------------------------------------|--------------------------------------|
| Particulate and Audit Sample-<br>volume determination | Antech                               |
| Lead and Audit Samples                                | Environmental Services<br>Laboratory |

## 5.2 Sampling Train Diagrams

Figure 1

EPA Methods 3A, 6C, 7E & 10 Analyzer Sample System Diagram




Figure 2

EPA Method 25A VOC Analyzer Sample System Diagram




Figure 25A-1. Organic Concentration Measurement System.

1262

### 5.3 Horizon Test Equipment

#### 5.3.1 Manual Methods

| <u>Equipment Name</u>    | <u>Equipment Identification</u> |
|--------------------------|---------------------------------|
| Hi Volume Orifice        | Horizon No. 1192                |
| Manometer                | Shortridge Manometers No. 1 & 2 |
| Pitots and Thermocouples | 11-S, 14-S1                     |
| Magnehelic Gauge         | 0-1F (orifice $\Delta H$ )      |
| Barometer                | Test Van III                    |

#### 5.3.2 Continuous Analyzers and Methods)

| Gas             | Brand       | Model | Range      | Measurement Method     | Method |
|-----------------|-------------|-------|------------|------------------------|--------|
| O <sub>2</sub>  | Servomex    | 1400  | 0-25%      | Paramagnetic           | 3A     |
| CO <sub>2</sub> | Servomex    | 1400  | 0-25%      | Chopperless NDIR       | 3A     |
| CO              | Thermo Env  | 48    | 0-1000 ppm | Gas Filter Correlation | 10     |
| TGOC            | J.U.M.      | VE-7  | 0-100 ppm  | Flame Ionization       | 25A    |
| NO <sub>x</sub> | Thermo Env  | 42C   | 0-250 ppm  | Chemiluminescent       | 7E     |
| SO <sub>2</sub> | West. Resch | 721M  | 0-30 ppm   | Non Disp. Ultra-violet | 6C     |

#### 5.3.3 Continuous Emissions Monitors Sampling Setup

Sampling: Above listed gases except TGOC  
Probe: Stainless Steel with sintered stainless and polyester filters  
Sample Line(s): Teflon (heated)  
Conditioning: Refrigerated M & C Cooler  
Data Logger: Keithley

Sampling: TGOC.  
Probe: Stainless  
Conditioning: none  
Sample Line(s): Teflon (heated)  
Pump: heated, internal to analyzer  
Data Logger: Keithley

## 6. DISCUSSION

The results of the testing should be valid in all respects. All quality assurance checks including leak checks, instrument checks and calibrations, were within method-allowable tolerances.

As mentioned in Section 3.3, two of the three EPA audit samples were acceptable and with-in the Method 29 allowed range of plus or minus 25%. The third audit sample that was not in the acceptable range, was rechecked by the laboratory for all dilution and QA procedures. Prior to Environmental Services Laboratory receiving the audit samples, per Jack Herbert of ODEQ's request, the two liquid audit samples were evaporated to dryness along with the particulate samples. Antech reported the audit-solution volume upon submitting the samples to ESL for lead analysis.

The VOC values reported in this work are total gaseous organic compounds (TGOC) and include methane, which is not a VOC, in the value. It is likely that a high fraction of the total is methane because it is used for heat in the furnace.

# **APPENDIX**

**NOMENCLATURE & DRIFT CORRECTION  
DOCUMENTATION**

# Nomenclature

| Constants                | Value                                     | Units                                                                 | Definition                                                                                 | Ref        |
|--------------------------|-------------------------------------------|-----------------------------------------------------------------------|--------------------------------------------------------------------------------------------|------------|
| Pstd(1)                  | 29.92126                                  | inHg                                                                  | Standard Pressure                                                                          | CRC        |
| Pstd(2)                  | 2116.22                                   | lbf / ft <sup>2</sup>                                                 |                                                                                            | CRC        |
| Tstd                     | 527.67                                    | °R                                                                    | Standard Temperature                                                                       | CRC        |
| R                        | 1545.33                                   | ft lbf / lbmol °R                                                     | Ideal Gas Constant                                                                         | CRC        |
| MWatm                    | 28.965                                    | lbm / lbmole                                                          | Atmospheric (20.946 %O <sub>2</sub> , 0.033% CO <sub>2</sub> , Balance N <sub>2</sub> +Ar) |            |
| MWc                      | 12.011                                    | lbm / lbmole                                                          | Carbon                                                                                     | CRC        |
| MWco                     | 28.010                                    | lbm / lbmole                                                          | Carbon Monoxide                                                                            | CRC        |
| MWco <sub>2</sub>        | 44.010                                    | lbm / lbmole                                                          | Carbon Dioxide                                                                             | CRC        |
| MWh <sub>2</sub> O       | 18.015                                    | lbm / lbmole                                                          | Water                                                                                      | CRC        |
| MWno <sub>2</sub>        | 46.006                                    | lbm / lbmole                                                          | Nitrogen Dioxide                                                                           | CRC        |
| MWo <sub>2</sub>         | 31.999                                    | lbm / lbmole                                                          | Oxygen                                                                                     | CRC        |
| MWso <sub>2</sub>        | 64.063                                    | lbm / lbmole                                                          | Sulfur Dioxide                                                                             | CRC        |
| MWn <sub>2</sub> +ar     | 28.154                                    | lbm / lbmole (Balance with 98.82% N <sub>2</sub> & 1.18% Ar)          | Emission balance                                                                           |            |
| C1                       | 385.3211                                  | ft <sup>3</sup> / lbmol                                               | Ideal Gas Constant @ Standard Conditions                                                   |            |
| C2                       | 816.5455                                  | inHg in <sup>3</sup> / °R ft <sup>3</sup>                             | Isokinetics units correction constant                                                      |            |
| Kp                       | 5129.4                                    | ft / min [ (inHg lbm/mole) / (°R inH <sub>2</sub> O) ] <sup>1/2</sup> | Pitot tube constant                                                                        | Ref 2.5.1  |
| Symbol                   | Units                                     | Definition                                                            | Calculating Equation or Source of Data                                                     | EPA        |
| As                       | in <sup>2</sup>                           | Area, Stack                                                           |                                                                                            |            |
| An                       | in <sup>2</sup>                           | Area, Nozzle                                                          |                                                                                            |            |
| Bws                      | %                                         | Moisture, % Stack gas                                                 | $[ 100 Vw(std) / [ Vw(std) + Vm(std) ] ]$                                                  | Eq. 5-3    |
| C                        | ppmv-C                                    | Carbon (General Reporting Basis for Organics)                         |                                                                                            |            |
| C1                       | ft <sup>3</sup> /lbmol                    | Gas Constant @ Standard Conditions                                    | $[ R Tstd / Pstd(2) ]$                                                                     |            |
| C2                       | inHg in <sup>3</sup> / °R ft <sup>3</sup> |                                                                       | $[ 14,400 Pstd / Tstd ]$                                                                   |            |
| Cd                       | lbm-GAS / MMdscf                          | Mass of gas per unit volume                                           | $[ Cgas MWgas / C1 ]$                                                                      |            |
| cg                       | gr/dscf                                   | Grain Loading, Actual                                                 | $[ 15,432 mn / Vm(std) 1,000 ]$                                                            | Eq. 5-6    |
| cg @ X%CO <sub>2</sub>   | gr/dscf                                   | Grain Loading Corrected to X% Carbon Dioxide                          | $[ X\% / CO2\% ]$                                                                          |            |
| cg @ X%O <sub>2</sub>    | gr/dscf                                   | Grain Loading Corrected to X% Oxygen                                  | $[ (20.946-X) / (20.946-O2) ]$                                                             |            |
| Cgas                     | ppmv, %                                   | Gas Concentration, (Corrected)                                        |                                                                                            |            |
| Cgas @ X%CO <sub>2</sub> | ppmv                                      | Gas Concentration Correction to X% Carbon Dioxide                     | $[ X\% / CO2\% ]$                                                                          |            |
| Cgas @ X%O <sub>2</sub>  | ppmv                                      | Gas Concentration Correction to X% Oxygen                             | $[ (20.946-X\%) / (20.946-O2\%) ]$                                                         |            |
| CO                       | ppmv                                      | Carbon Monoxide                                                       |                                                                                            |            |
| Co                       | ft                                        | Outer Circumference of Circular Stack                                 |                                                                                            |            |
| Ci                       | ft                                        | Inner Circumference of Circular Stack                                 |                                                                                            |            |
| CO <sub>2</sub>          | %                                         | Carbon Dioxide                                                        |                                                                                            |            |
| Cp                       |                                           | Pitot tube coefficient                                                |                                                                                            |            |
| Ct                       | lb/hr                                     | Particulate Mass Emissions                                            | $[ 60 cg Qsd / 7,000 ]$                                                                    |            |
| dH                       | in H <sub>2</sub> O                       | Pressure differential across orifice                                  |                                                                                            |            |
| Dn                       | in                                        | Diameter, Nozzle                                                      |                                                                                            |            |
| dp <sup>1/2</sup>        |                                           | Average square root of velocity pressure                              |                                                                                            |            |
| Ds                       | in                                        | Diameter, Stack                                                       |                                                                                            |            |
| E                        | lb / MMBtu                                | Pollutant Emission Rate                                               | $Cgas Fd MWgas ( 20.946 / ( 20.946-O2 ) ) / ( 1,000,000 C1 )$                              | Table 19-1 |
| Fd                       | dscf / MMBtu                              | F Factor for Various Fuels                                            |                                                                                            | Eq. 5-8*   |
| I                        | %                                         | Percent Isokinetic                                                    | $[ C2 Ts(abs) Vm(std) / (vs Ps mfg As Ø) ]$                                                | Eq. 3-1*   |
| Md                       | lbm / lbmole                              | Molecular weight, Dry Stack Gas                                       | $[ (1-\%O2-\%CO2)(MWn2+ar) + (\%O2 MWo2) + (\%CO2 MWco2) ]$                                |            |
| mfg                      |                                           | Mole fraction of dry stack gas                                        | $[ 1-Bws/100 ]$                                                                            |            |
| Mgas                     | lbm/hr                                    | Gaseous Mass Emissions                                                | $[ 60 Cgas(ppmv) MW Pstd(2) Qsd / 1,000,000 R Tstd ]$                                      |            |
| mn                       | mg                                        | Particulate lab sample weight                                         |                                                                                            |            |
| Ms                       | lbm / lbmole                              | Molecular weight, Wet Stack                                           | $[ Md mfg + MWh2o (1-mfg) ]$                                                               | Eq. 2-5    |
| MW                       | lbm / lbmole                              | Molecular Weight                                                      |                                                                                            |            |
| NO <sub>2</sub>          | ppmv-NO <sub>2</sub>                      | Nitrogen Dioxide ( General Reporting Basis for NO <sub>x</sub> )      |                                                                                            |            |
| NO <sub>x</sub>          | ppmv-NO <sub>2</sub>                      | Nitrogen Oxides (Reported as NO <sub>2</sub> )                        |                                                                                            |            |
| O <sub>2</sub>           | %                                         | Oxygen                                                                |                                                                                            |            |
| OPC                      | %                                         | Opacity                                                               |                                                                                            |            |
| Pbar                     | in Hg                                     | Pressure, Barometric                                                  |                                                                                            |            |
| Pg                       | in H <sub>2</sub> O                       | Pressure, Static Stack                                                |                                                                                            |            |
| Po                       | in Hg                                     | Pressure, Absolute across Orifice                                     | $[ Pbar + dH / 13.5951 ]$                                                                  |            |
| Ps                       | in Hg                                     | Pressure, Absolute Stack                                              | $[ Pbar + Pg / 13.5951 ]$                                                                  | Eq. 2-6*   |
| Qa                       | acft/min                                  | Volumetric Flowrate, Actual                                           | $[ As vs / 144 ]$                                                                          |            |
| Qsd                      | dscf/min                                  | Volumetric Flowrate, Dry Standard                                     | $[ Qa Tstd mfg Ps ] / [ Pstd(1) Ts(abs) ]$                                                 | Eq. 2-10*  |
| Rf                       | MMBtu/hr                                  |                                                                       | $1,000,000 Mgas (20.946-O2) / [ Cd Fd 20.946 ]$                                            |            |
| SO <sub>2</sub>          | ppmv-SO <sub>2</sub>                      | Sulfur Dioxide                                                        |                                                                                            |            |
| t                        | in                                        | Wall thickness of a stack or duct                                     |                                                                                            |            |
| TGOC                     | ppmv-C                                    | Total Gaseous Organic Concentration (Reported as C)                   |                                                                                            |            |
| Tm                       | °F                                        | Temperature, Dry gas meter                                            |                                                                                            |            |
| Tm(abs)                  | °R                                        | Temperature, Absolute Dry Meter                                       | $[ Tm + 459.67 ]$                                                                          |            |
| Ts                       | °F                                        | Temperature, Stack gas                                                |                                                                                            |            |
| Ts(abs)                  | °R                                        | Temperature, Absolute Stack gas                                       | $[ Ts + 459.67 ]$                                                                          |            |
| Vlc                      | ml                                        | Volume of condensed water                                             |                                                                                            |            |
| Vm                       | dscf                                      | Volume, Gas sample                                                    |                                                                                            |            |
| Vm(std)                  | dscf                                      | Volume, Dry standard gas sample                                       | $[ Y Vm Tstd Po ] / [ Pstd(1) Tm(abs) ]$                                                   | Eq. 5-1    |
| vs                       | fpm                                       | Velocity, Stack gas                                                   | $Kp Cp dp^{1/2} [ Ts(abs) / (Ps Ms) ]^{1/2}$                                               | Eq. 2-9*   |
| Vw(std)                  | scf                                       | Volume, Water Vapor                                                   | 0.04707 Vlc                                                                                | Eq. 5-2    |
| Y                        |                                           | Dry gas meter calibration factor                                      |                                                                                            | Fig. 5.6   |
| Ø                        | min                                       | Time, Total sample                                                    |                                                                                            |            |

\* Based on equation



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizone@teleport.com

## DRIFT CORRECTION DOCUMENTATION

### EPA Drift Equations:

- Method 3A: Oxygen and Carbon Dioxide

$$C_{gas} = \frac{(C_{ma} - C_{oa})(C - C_m) + C_{ma}}{(C_m - C_o)} \quad (\text{Eq. 3A-1})$$

- Method 6C: Sulfur Dioxide

$$C_{gas} = \frac{C_{ma}(C - C_o)}{(C_m - C_o)} \quad \text{where } C_{oa} = 0 \quad (\text{Eq. 6C-1})$$

- Method 7E: Nitrogen Oxides, Section 8 of Method 7E states: "Follow Section 8 of Method 6C (Eq. 6C-1)"
- Method 10: Carbon Monoxide, the EPA does not currently address Gas Filter Correlation instruments, therefore there are no current standards.
- Method 25A: Total Gaseous Organic Concentration (TGO), this method does not mention correcting for drift although there are established limits.

### Horizon Engineering Drift Correction Equations:

$$C_{gas} = \frac{(C_{id} - Z_x)(C_{ma} - C_{oa})}{(S_x - Z_x)} \quad S_x = \frac{C_{mf} - C_{mi}(T_x - T_{ci})}{(T_{cf} - T_{ci})} + C_{mi}$$

$$Z_x = \frac{(C_{of} - C_{oi})(T_x - T_{ci})}{(T_{cf} - T_{ci})} + C_{oi} \quad T_x = \frac{(T_{te} - T_{ts})}{2} + T_{ts}$$

| EPA       | Definition                                                              | Horizon   |
|-----------|-------------------------------------------------------------------------|-----------|
| $C_{gas}$ | Effluent gas concentration, dry basis                                   | $C_{gas}$ |
| $C_{ma}$  | Actual upscale calibration gas concentration                            | $C_{ma}$  |
| $C_{oa}$  | Actual zero/low calibration gas concentration                           | $C_{oa}$  |
| $C_m$     | Average of initial and final system upscale calibration bias responses  |           |
|           | Initial system upscale calibration bias response                        | $C_{mi}$  |
|           | Final system upscale calibration bias response                          | $C_{mf}$  |
| $C_o$     | Average of initial and final system zero/low calibration bias responses |           |
|           | Initial system zero/low calibration bias response                       | $C_{oi}$  |
|           | Final system zero/low calibration bias response                         | $C_{of}$  |
| $C$       | Average gas concentration indicated by gas analyzer, dry basis          | $C_{id}$  |
|           | Starting test time                                                      | $T_{ts}$  |
|           | Ending test time                                                        | $T_{te}$  |
|           | Initial system bias calibration response time                           | $T_{ci}$  |
|           | Final system bias calibration response time                             | $T_{cf}$  |
|           | Mid-point of test time or gas sampling interval to be analyzed          | $T_x$     |
|           | Approximate upscale response at mid-point test time                     | $S_x$     |
|           | Approximate zero/low response at mid-point test time                    | $Z_x$     |

#### Notes or exceptions:

TGO is first recorded on a wet basis, then corrected to a dry basis

The TGO instruments used by Horizon have some historic data on instrument response to different hydrocarbons.

For propane the response is 1 to 1 molecule while methane is 1.037 to 1 molecule. We correct for the instrument's "over response" to methane.

**PARTICULATE AND LEAD CALCULATION  
SHEETS**

Emission Calculation Worksheets

Field Data Sheets

Blank Correction and Filter Rinse Allocation

Laboratory Results and Worksheets

Baghouse Sampling Diagram

# Particulate and Lead Emissions

|                                      |                            |           |          |             |          |           |              |             |                 |          |         |       |
|--------------------------------------|----------------------------|-----------|----------|-------------|----------|-----------|--------------|-------------|-----------------|----------|---------|-------|
| Plant                                | Oregon Steel Mills         |           |          |             |          |           |              | File        | osm1536         |          |         |       |
| Source                               | ICA Baghouse-EAF           |           |          |             |          |           |              | Tester      | MJE/BTF/TJH/CDB |          |         |       |
| Date                                 | 27-Dec-2000                |           |          |             |          |           |              | Analysis/QA | MJE/MEW         |          |         |       |
| Run#                                 | 1                          |           |          |             |          |           |              |             |                 |          |         |       |
| Points                               |                            | Wt(mg)    | 47.9956  | Stack Area  | As=      | 7.59 sqft | Mol Wt. Dry  | Md=         | 29.60           | molwt    |         |       |
|                                      |                            | Lead (mg) | 0.923    | Stack Temp. | Tdb=     | 155 °F    | Mol Wt. Wet  | Ms=         | 28.68           | molwt    |         |       |
|                                      |                            |           |          | Stack Temp. | Twb=     | 93 °F     | Barometric   | Pb=         | 30.49           | in H2O   |         |       |
| Hivol ID                             | SN#                        | 1192      |          | Moisture    | bws=     | 2.88 %    | Static Pres. | Pstat=      | 0.03            | in H2O   |         |       |
| Orifice                              | A=                         | 47.9956   |          | Nozzle Dia. | Dn=      | 3.109 in  | Stack Pres.  | Ps=         | 29.60           | in Hg    |         |       |
| Constants                            | B=                         | 0.4623    |          | Nozzle Area | An=      | 7.59 sqin | Pitot        | Cp=         | 0.7802          |          |         |       |
| TIME                                 | Compartment                | Velocity  | Velocity | Orifice     | Pressure | Temp      | Temp         | Time        | Rate            | Volume   | Volume  |       |
|                                      | POINT                      | Pressure  | vs       | in H2O      | in H2O   | (F)       | (F)          | min         | cfm             | cuft     | cuft    |       |
|                                      | #                          | dP        | fpm      | dHo         | dHo      | Orifice   | Stack        | t           | Standard        | Standard | Orifice |       |
|                                      | pt                         | inH2O     |          | Calc        | Act      | Tor       | Tso          |             | Q@68°F          | @68°F    | @Tor    |       |
| 11:39                                |                            |           |          |             |          |           |              |             |                 |          |         |       |
| 11:41                                | 1                          | 3         | 0.0462   | 722.9       | 0.4849   | 0.4700    | 96.0         | 140.0       | 5.0             | 33.05    | 165.3   | 174.0 |
| 11:46                                | 2                          | 3         | 0.0374   | 649.3       | 0.3956   | 0.3900    | 108.0        | 138.0       | 5.0             | 30.02    | 150.1   | 161.5 |
| 11:56                                | 3                          | 3         | 0.0361   | 652.2       | 0.3636   | 0.3700    | 109.0        | 165.0       | 5.0             | 29.28    | 146.4   | 157.8 |
| 12:02                                | 4                          | 3         | 0.0436   | 719.6       | 0.4561   | 0.4300    | 127.0        | 170.0       | 5.0             | 30.94    | 154.7   | 172.0 |
| 12:08                                | 5                          | 3         | 0.0489   | 757.2       | 0.5209   | 0.5000    | 124.0        | 162.0       | 5.0             | 33.25    | 166.2   | 183.9 |
| 12:11                                | 6                          | 3         | 0.0325   | 622.3       | 0.3269   | 0.3200    | 120.0        | 172.0       | 5.0             | 27.14    | 135.7   | 149.1 |
| 12:26                                | 7                          | 3         | 0.0430   | 709.0       | 0.4627   | 0.4400    | 134.0        | 160.0       | 5.0             | 31.10    | 155.5   | 174.9 |
| 12:26                                | 8                          | 3         | 0.0133   | 392.7       | 0.1285   | 0.1200    | 122.0        | 155.0       | 5.0             | 17.22    | 86.1    | 94.9  |
| 12:32                                | 9                          | 3         | 0.0397   | 686.1       | 0.3953   | 0.3900    | 102.0        | 169.0       | 5.0             | 30.17    | 150.9   | 160.6 |
| 12:37                                | 10                         | 3         | 0.0452   | 735.0       | 0.4542   | 0.4500    | 106.0        | 174.0       | 5.0             | 32.13    | 160.7   | 172.2 |
| 12:44                                | 11                         | 3         | 0.0269   | 554.4       | 0.2750   | 0.2600    | 112.0        | 146.0       | 5.0             | 24.81    | 124.1   | 134.4 |
| 12:49                                | 13                         | 3         | 0.0382   | 666.1       | 0.3947   | 0.3600    | 112.0        | 156.0       | 5.0             | 28.84    | 144.2   | 156.2 |
| 12:56                                | 14                         | 3         | 0.0395   | 680.6       | 0.4022   | 0.3800    | 108.0        | 162.0       | 5.0             | 29.67    | 148.3   | 159.6 |
| 13:02                                | 15                         | 3         | 0.0336   | 624.7       | 0.3412   | 0.4000    | 108.0        | 156.0       | 5.0             | 30.38    | 151.9   | 163.4 |
| 13:16                                | 16                         | 3         | 0.0257   | 547.6       | 0.2576   | 0.3300    | 116.0        | 159.0       | 5.0             | 27.61    | 138.1   | 150.6 |
| 13:16                                | 1                          | 3         | 0.0499   | 769.2       | 0.5188   | 0.2500    | 116.0        | 169.0       | 5.0             | 24.29    | 121.4   | 132.5 |
| Time weighting used in averaging. => |                            |           | 655.6    | 0.3861      | 0.3663   | 113.8     | 159.6        | 80.00       | 28.74           | 2,299.5  | 2,497.6 |       |
| Run#                                 |                            |           |          |             |          |           |              |             |                 |          |         |       |
| 1 2 3 Average                        |                            |           |          |             |          |           |              |             |                 |          |         |       |
| Sample Volume                        | V@68 (Pb/29.92)(1-bws/100) |           |          | dscf        | Vd       | 2,275.8   | 2,082.0      | 2,246.7     | 2,201.5         |          |         |       |
| Total Flowrate                       | Outlet Flow                |           |          | dscf/min    | Qsd      | 476,850   | 426,494      | 472,546     | 458,630         |          |         |       |
| Particulate                          |                            |           |          |             |          |           |              |             |                 |          |         |       |
| Grain loading                        | 0.01543 Wt/Vd              |           |          | gr/dscf     | Cg       | 0.00038   | 0.00054      | 0.00031     | 0.00041         |          |         |       |
|                                      |                            |           |          | ug/m3       |          | 859       | 1245         | 700         | 935             |          |         |       |
| Emissions                            | 0.00857 Cg Qs              |           |          | lbm/hr      | Ct       | 1.5335    | 1.9897       | 1.2384      | 1.5872          |          |         |       |
|                                      |                            |           |          | lbm/ton     |          | 0.0093    | 0.0161       | 0.0089      | 0.0114          |          |         |       |
| LEAD                                 |                            |           |          |             |          |           |              |             |                 |          |         |       |
| Grain loading                        | 0.01543 Lead/Vd            |           |          | gr/dscf     | Cg       | 0.0000063 | 0.0000127    | 0.0000058   | 0.0000083       |          |         |       |
|                                      |                            |           |          | ug/m3       |          | 14.3      | 29.0         | 13.3        | 18.9            |          |         |       |
| Emissions                            | 0.00857 Cg Qs              |           |          | lbm/hr      | Ct       | 0.0256    | 0.0464       | 0.0236      | 0.0319          |          |         |       |
|                                      |                            |           |          | lbm/ton     |          | 0.00015   | 0.00037      | 0.00017     | 0.00023         |          |         |       |
| Avg Sample Rate                      | V@Tor / t                  |           |          | acf/min     | Qan      | 31.22     | 28.81        | 31.75       | 30.59           |          |         |       |
| Avg Velocity @ Sample Point          | vs=Qa/As                   |           |          | fpm         | vs       | 655.56    | 598.73       | 667.51      | 640.60          |          |         |       |
| Avg Orifice temp                     |                            |           |          | °R          | Tor      | 573.42    | 584.72       | 580.67      | 579.60          |          |         |       |
| Avg Stack temp                       |                            |           |          | °R          | Ts       | 619.23    | 631.04       | 639.61      | 629.96          |          |         |       |
| Avg Nozzle Velocity                  | Qan*Ts / An*Tor            |           |          | fpm         | vn       | 639.51    | 589.77       | 663.40      | 630.89          |          |         |       |
| % ISOKINETIC                         | 100 vn/vs                  |           |          | %I          |          | 97.6      | 98.5         | 99.4        | 98.5            |          |         |       |
| Percent Lead of Total Particulate    |                            |           |          |             |          |           |              |             |                 |          |         |       |
| Opacity                              | cdb #979                   |           |          | %           |          | 1.67      | 2.33         | 1.91        | 1.97            |          |         |       |
|                                      |                            |           |          | %           |          | 0.0       | 0.0          | 0.0         | 0.0             |          |         |       |

\* The baghouse has 16 compartments. One is always cycling.

\* Each Compartment is 52"x179".

# **Particulate and Lead Emissions**

|                                      |                      |          |                                     |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
|--------------------------------------|----------------------|----------|-------------------------------------|----------------------|----------------------------------|----------------------------------|-------------------------------|----------------------------|------------------|-----------------------------------|-------------------------------------|-----------------------------------|
| Plant                                | Oregon Steel Mills   |          |                                     |                      |                                  |                                  |                               | File                       | osm1536          |                                   |                                     |                                   |
| Source                               | RCA Baghouse-1 AF    |          |                                     |                      |                                  |                                  |                               | Tester                     | MUEBTEJELCDR     |                                   |                                     |                                   |
| Date                                 | 27-Dec-2000          |          |                                     |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
| Run#                                 | 2                    |          |                                     |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
| Points                               | 10                   | Wt(mg)   | 73.442                              | Stack Area           | As=                              | 969.6                            | sqft                          | Mol Wt. Dry                | Md=              | 29.01                             | molwt                               |                                   |
|                                      |                      | Lead(mg) | 1.713                               | Stack Temp.          | Tdb=                             | 164                              | °F                            | Mol Wt. Wet                | Ms=              | 28.55                             | molwt                               |                                   |
|                                      |                      |          |                                     | Stack Temp.          | Twb=                             | 101                              | °F                            | Barometric                 | Pb=              | 30.49                             | in H2O                              |                                   |
| Hivol ID                             | SN#                  |          |                                     | Moisture             | bws=                             | 4.25                             | %                             | Static Pres.               | Pstat=           | 0.00                              | in H2O                              |                                   |
| Orifice                              | A=                   |          |                                     | Nozzle Dia.          | Dn=                              | 1.69                             | in                            | Stack Pres.                | Ps=              | 30.49                             | in Hg                               |                                   |
| Constants                            | B=                   |          |                                     | Nozzle Area          | An=                              | 7.59                             | sqin                          | Pitot                      | Cp=              | 0.7802                            |                                     |                                   |
| TIME                                 | Compartment<br>POINT |          | Velocity<br>Pressure<br>dP<br>inH2O | Correct<br>fpm<br>Vs | Orifice<br>in H2O<br>dHo<br>Calc | Pressure<br>in H2O<br>dHo<br>Act | Temp<br>(F)<br>Orifice<br>Tor | Temp<br>(F)<br>Stack<br>Ts | Time<br>min<br>t | Rate<br>cfm<br>Standard<br>Q@68°F | Volume<br>cuft<br>Standard<br>@68°F | Volume<br>cuft<br>Orifice<br>@Tor |
|                                      |                      | #        | pt                                  |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
| 13:18                                |                      |          |                                     |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
| 13:23                                | 2                    | 3        | 0.0497                              | 760.61               | 0.5029                           | 0.4900                           | 120.0                         | 173.0                      | 5.0              | 33.05                             | 165.2                               | 181.5                             |
| 13:29                                | 3                    | 3        | 0.0411                              | 685.64               | 0.4043                           | 0.4000                           | 102.0                         | 162.0                      | 5.0              | 30.53                             | 152.6                               | 162.5                             |
| 13:35                                | 4                    | 3        | 0.0404                              | 683.59               | 0.4061                           | 0.4000                           | 122.0                         | 169.0                      | 5.0              | 30.04                             | 150.2                               | 165.6                             |
| 13:40                                | 5                    | 3        | 0.0348                              | 630.90               | 0.3558                           | 0.3400                           | 132.0                         | 162.0                      | 5.0              | 27.65                             | 138.2                               | 155.0                             |
| 13:46                                | 6                    | 3        | 0.0322                              | 612.71               | 0.3183                           | 0.3100                           | 128.0                         | 174.0                      | 5.0              | 26.57                             | 132.9                               | 148.0                             |
| 13:52                                | 7                    | 3        | 0.0438                              | 713.47               | 0.4500                           | 0.4300                           | 134.0                         | 172.0                      | 5.0              | 30.77                             | 153.8                               | 173.1                             |
| 13:57                                | 8                    | 3        | 0.0264                              | 553.03               | 0.2594                           | 0.2500                           | 130.0                         | 170.0                      | 5.0              | 24.02                             | 120.1                               | 134.2                             |
| 14:03                                | 9                    | 3        | 0.0377                              | 663.50               | 0.3742                           | 0.3700                           | 124.0                         | 175.0                      | 5.0              | 28.93                             | 144.6                               | 160.0                             |
| 14:09                                | 10                   | 3        | 0.0320                              | 616.08               | 0.3103                           | 0.3100                           | 128.0                         | 185.0                      | 5.0              | 26.57                             | 132.9                               | 148.0                             |
| 14:15                                | 11                   | 3        | 0.0254                              | 548.03               | 0.2384                           | 0.2300                           | 118.0                         | 183.0                      | 5.0              | 23.33                             | 116.7                               | 127.7                             |
| 14:21                                | 13                   | 3        | 0.0344                              | 639.76               | 0.3287                           | 0.3300                           | 118.0                         | 187.0                      | 5.0              | 27.57                             | 137.8                               | 150.9                             |
| 14:27                                | 14                   | 3        | 0.0125                              | 375.68               | 0.1172                           | 0.1100                           | 122.0                         | 154.0                      | 5.0              | 16.54                             | 82.7                                | 91.2                              |
| 14:33                                | 15                   | 3        | 0.0111                              | 355.74               | 0.1044                           | 0.1000                           | 136.0                         | 160.0                      | 5.0              | 15.65                             | 78.3                                | 88.3                              |
| 14:38                                | 15                   | 3        | 0.0111                              | 355.74               | 0.1034                           | 0.1000                           | 130.0                         | 160.0                      | 5.0              | 15.73                             | 78.6                                | 87.9                              |
| 14:44                                | 16                   | 3        | 0.0281                              | 570.11               | 0.2780                           | 0.2700                           | 130.0                         | 169.0                      | 5.0              | 24.89                             | 124.4                               | 139.1                             |
| 14:50                                | 1                    | 3        | 0.0497                              | 766.59               | 0.5012                           | 0.4800                           | 128.0                         | 183.0                      | 5.0              | 32.52                             | 162.6                               | 181.1                             |
| 14:52                                | 2                    | 3        | 0.0440                              | 720.17               | 0.4363                           | 0.4300                           | 122.0                         | 181.0                      | 2.0              | 31.06                             | 62.1                                | 68.5                              |
| Time weighting used in averaging. => |                      |          |                                     | 598.73               | 0.3187                           | 0.3105                           | 125.05                        | 171.37                     | 82.00            | 26.02                             | 2,133.9                             | 2,362.4                           |
|                                      |                      |          |                                     |                      |                                  |                                  | Run#                          | 2                          |                  |                                   |                                     |                                   |
| Sample Volume                        |                      |          | V@68 (Pb/29.92)(1-bws/100)          |                      |                                  | dscf                             | Vd                            | 2,082.0                    |                  |                                   |                                     |                                   |
| Total Flowrate                       |                      |          | Outlet Flow                         |                      |                                  | dscf/min                         | Qs                            | 426.494                    |                  |                                   |                                     |                                   |
| Particulate                          |                      |          |                                     |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
| Grain loading                        |                      |          | 0.01543 Wt/Vd                       |                      |                                  | gr/dscf                          | Cg                            | 0.00054                    |                  |                                   |                                     |                                   |
| Emissions                            |                      |          | 0.00857 Cg Qs                       |                      |                                  | lb/hr                            | Ct                            | 1.9896940658               |                  |                                   |                                     |                                   |
| LEAD                                 |                      |          |                                     |                      |                                  |                                  |                               |                            |                  |                                   |                                     |                                   |
| Grain loading                        |                      |          | 0.01543 Lead/Vd                     |                      |                                  | gr/dscf                          | Cg                            | 1.27E-05                   |                  |                                   |                                     |                                   |
| Emissions                            |                      |          | 0.00857 Cg Qs                       |                      |                                  | lb/hr                            | Ct                            | 0.04640656693              |                  |                                   |                                     |                                   |
| Avg Sample Rate                      |                      |          | V@Tor / t                           |                      |                                  | acf/min                          | Qan                           | 28.81                      |                  |                                   |                                     |                                   |
| Avg Velocity @ Sample Point          |                      |          | vs=Qa/As                            |                      |                                  | fpm                              | vs                            | 598.73                     |                  |                                   |                                     |                                   |
| Avg Orifice temp                     |                      |          |                                     |                      |                                  | °R                               | Tor                           | 584.72                     |                  |                                   |                                     |                                   |
| Avg Stack temp                       |                      |          |                                     |                      |                                  | °R                               | Ts                            | 631.04                     |                  |                                   |                                     |                                   |
| Avg Nozzle Velocity                  |                      |          | Qan*Ts / An*Tor                     |                      |                                  | fpm                              | vn                            | 589.77                     |                  |                                   |                                     |                                   |
| % ISOKINETIC                         |                      |          | 100 vn/vs                           |                      |                                  | %I                               |                               | 98.50                      |                  |                                   |                                     |                                   |

# Particulate and Lead Emissions

| Plant                                | Oregon Steel Mills         |          |          |             |         |             | File        | osm1            |               |          |         |         |
|--------------------------------------|----------------------------|----------|----------|-------------|---------|-------------|-------------|-----------------|---------------|----------|---------|---------|
| Source                               | IOVA Baghouse #1A          |          |          |             |         |             | Tester      | MIE-BTE-THE-CDR |               |          |         |         |
| Date                                 | 27-Dec-2000                |          |          |             |         |             |             |                 |               |          |         |         |
| Run#                                 | 3                          |          |          |             |         |             |             |                 |               |          |         |         |
| Points                               | 11                         |          |          |             |         |             |             |                 |               |          |         |         |
|                                      |                            | Wt(mg)   | 44521    | Stack Area  | As=     | 0.0001 sqft |             | Mol Wt. Dry     | Md=           | 29.01    | molwt   |         |
|                                      |                            | Lead(mg) | 0.848    | Stack Temp. | Tdb=    | 180 °F      |             | Mol Wt. Wet     | Ms=           | 28.52    | molwt   |         |
|                                      |                            |          |          | Stack Temp. | Twb=    | 104 °F      |             | Barometric      | Pb=           | 30.49    | in H2O  |         |
| Hivol ID                             | SN#                        |          | 1102     | Moisture    | bws=    | 4.41 %      |             | Static Pres.    | Pstat=        | 0.03     | in H2O  |         |
| Orifice                              | A=                         | 17.0056  |          | Nozzle Dia. | Dn=     | 1.00 in     |             | Stack Pres.     | Ps=           | 30.49    | in Hg   |         |
| Constants                            | B=                         | 0.4623   |          | Nozzle Area | An=     | 7.59 sqin   |             | Pitot           | Cp=           | 0.7802   |         |         |
| TIME                                 | Compartment                | Velocity | Pressure | Correct     | Orifice | Pressure    | Temperature | Time            | Rate          | Volume   |         |         |
|                                      | POINT                      |          |          |             |         |             |             |                 |               |          |         |         |
|                                      | #                          | pt       | dP       | fpm         | in H2O  | in H2O      | (F)         | min             | cfm           | cuft     |         |         |
|                                      |                            |          | inH2O    | Vs          | Calc    | Act         | Orifice     | t               | Standard      | Standard | Orifice |         |
|                                      |                            |          |          |             |         |             | Tor         | Ts              | Q@68°F        | @68°F    | @Tor    |         |
| 14:55                                |                            |          |          |             |         |             |             |                 |               |          |         |         |
| 15:00                                | 2                          | 3        | 0.0440   | 720.46      | 0.4262  | 0.4300      | 108.0       | 181.0           | 5.0           | 31.41    | 157.1   | 169.0   |
| 15:07                                | 3                          | 3        | 0.0354   | 648.24      | 0.3464  | 0.3400      | 128.0       | 185.0           | 5.0           | 27.73    | 138.7   | 154.4   |
| 15:14                                | 4                          | 3        | 0.0318   | 617.25      | 0.3012  | 0.3000      | 120.0       | 191.0           | 5.0           | 26.34    | 131.7   | 144.7   |
| 15:19                                | 5                          | 3        | 0.0597   | 845.73      | 0.5974  | 0.5800      | 122.0       | 191.0           | 5.0           | 35.67    | 178.3   | 196.6   |
| 15:24                                | 6                          | 3        | 0.0625   | 858.66      | 0.6471  | 0.6200      | 130.0       | 181.0           | 5.0           | 36.55    | 182.8   | 204.2   |
| 15:29                                | 7                          | 3        | 0.0397   | 683.28      | 0.3988  | 0.3800      | 132.0       | 179.0           | 5.0           | 29.10    | 145.5   | 163.2   |
| 15:35                                | 8                          | 3        | 0.0246   | 533.63      | 0.2393  | 0.2300      | 126.0       | 169.0           | 5.0           | 23.18    | 115.9   | 128.7   |
| 15:42                                | 9                          | 3        | 0.0382   | 668.67      | 0.3780  | 0.3700      | 122.0       | 176.0           | 5.0           | 28.97    | 144.9   | 159.7   |
| 15:47                                | 10                         | 3        | 0.0309   | 605.64      | 0.2960  | 0.2900      | 122.0       | 185.0           | 5.0           | 25.89    | 129.4   | 142.7   |
| 15:53                                | 11                         | 3        | 0.0145   | 414.55      | 0.1281  | 0.1300      | 110.0       | 184.0           | 5.0           | 18.04    | 90.2    | 97.4    |
| 15:58                                | 13                         | 3        | 0.0466   | 728.60      | 0.4793  | 0.4700      | 118.0       | 159.0           | 5.0           | 32.47    | 162.3   | 177.7   |
| 16:04                                | 14                         | 3        | 0.0461   | 728.18      | 0.4753  | 0.4700      | 126.0       | 165.0           | 5.0           | 32.26    | 161.3   | 179.0   |
| 16:11                                | 15                         | 3        | 0.0461   | 726.43      | 0.4745  | 0.4700      | 122.0       | 162.0           | 5.0           | 32.36    | 161.8   | 178.4   |
| 16:16                                | 16                         | 3        | 0.0266   | 561.92      | 0.2465  | 0.2500      | 110.0       | 185.0           | 5.0           | 24.41    | 122.0   | 131.7   |
| 16:23                                | 1                          | 3        | 0.0362   | 658.57      | 0.3418  | 0.3400      | 112.0       | 191.0           | 5.0           | 28.09    | 140.4   | 152.2   |
| 16:29                                | 2                          | 3        | 0.0384   | 680.36      | 0.3720  | 0.3700      | 128.0       | 195.0           | 5.0           | 28.84    | 144.2   | 160.6   |
| Time weighting used in averaging. => |                            |          |          | 667.51      | 0.3842  | 0.3775      | 121.00      | 179.94          | 80.00         | 28.83    | 2,306.6 | 2,540.1 |
| Run# 3                               |                            |          |          |             |         |             |             |                 |               |          |         |         |
| Sample Volume                        | V@68 (Pb/29.92)(1-bws/100) |          |          |             |         |             | dscf        | Vd              | 2,246.7       |          |         |         |
| Total Flowrate                       | Outlet Flow                |          |          |             |         |             | dscf/min    | Qs              | 472.546       |          |         |         |
| Particulate                          |                            |          |          |             |         |             |             |                 |               |          |         |         |
| Grain loading                        | 0.01543 Wt/Vd              |          |          |             |         |             | gr/dscf     | Cg              | 0.00031       |          |         |         |
| Emissions                            | 0.00857 Cg Qs              |          |          |             |         |             | lb/hr       | Ct              | 1.23844339583 |          |         |         |
| LEAD                                 |                            |          |          |             |         |             |             |                 |               |          |         |         |
| Grain loading                        | 0.01543 Lead/Vd            |          |          |             |         |             | gr/dscf     | Cg              | 5.82E-06      |          |         |         |
| Emissions                            | 0.00857 Cg Qs              |          |          |             |         |             | lb/hr       | Ct              | 0.02359294533 |          |         |         |
| Avg Sample Rate                      | V@Tor / t                  |          |          |             |         |             | acf/min     | Qan             | 31.75         |          |         |         |
| Avg Velocity @ Sample Point          | vs=Qa/As                   |          |          |             |         |             | fpm         | vs              | 667.51        |          |         |         |
| Avg Orifice temp                     |                            |          |          |             |         |             | °R          | Tor             | 580.67        |          |         |         |
| Avg Stack temp                       |                            |          |          |             |         |             | °R          | Ts              | 639.61        |          |         |         |
| Avg Nozzle Velocity                  | Qan*Ts / An*Tor            |          |          |             |         |             | fpm         | vn              | 663.40        |          |         |         |
| % ISOKINETIC                         | 100 vn/vs                  |          |          |             |         |             | %I          |                 | 99.38         |          |         |         |



DP's from: Presurvey \_\_\_\_\_  
During test 1

|       |              |
|-------|--------------|
| Run # | Process Rate |
| 2     | Normal       |

\*\*\*\*\*Horizon Engineering\*\*\*\*\*



## Blank Correction and Filter Rinse Allocation

|                                                                         |          |                        |                                           |                   |                                  |                                   |             |
|-------------------------------------------------------------------------|----------|------------------------|-------------------------------------------|-------------------|----------------------------------|-----------------------------------|-------------|
| Oregon Steel Mills Plant<br>ICA Baghouse-EAF Source<br>27-Dec-2000 Date |          |                        |                                           |                   | osm1536                          | 0.00%                             |             |
|                                                                         |          |                        |                                           |                   | Tester                           | 0.00%                             |             |
| PARTICULATE                                                             |          |                        |                                           |                   |                                  |                                   |             |
| RUN I.D.                                                                | FILTER # | Filter Sample Wt<br>mg | Wt less Filter Blank<br>mg                | Fraction of total | Rinse Residue Contribution<br>mg | Filter Residue Contribution<br>mg | TOTAL<br>mg |
| 1                                                                       | 6555863  | 46.9                   | 48.6                                      | 31.93%            | 6.195                            | 0.543                             | 55.338      |
| 2                                                                       | 6855688  | 62.8                   | 64.5                                      | 42.38%            | 8.221                            | 0.720                             | 73.442      |
| 3                                                                       | 6855689  | 37.4                   | 39.1                                      | 25.69%            | 4.984                            | 0.437                             | 44.521      |
| TOTALS                                                                  |          | 147.10                 | 152.20                                    | 100.00%           | 19.400                           | 1.700                             | 173.300     |
| Runs 1, 2, & 3                                                          |          |                        |                                           |                   |                                  |                                   |             |
| Sampler rinse residue                                                   |          | 238 ml                 |                                           | 19.40 mg          |                                  |                                   |             |
| Blank Acetone                                                           |          | 191 ml                 |                                           | -0.5 mg           |                                  |                                   |             |
| Blank correct residue                                                   |          |                        |                                           | 19.40 mg          |                                  |                                   |             |
| Sampler filter residue                                                  |          | 999                    |                                           | 0.0000 mg         |                                  | System Blank                      |             |
| Blank correct residue                                                   |          |                        |                                           | 1.7000 mg         |                                  |                                   |             |
| Blank Filter                                                            |          | 6855687/73             |                                           | -1.70 mg          |                                  | Lab Blank                         |             |
| *LEAD                                                                   |          |                        |                                           |                   |                                  |                                   |             |
| RUN I.D.                                                                | FILTER # | Filter Sample Wt<br>mg | Wt less Filter Blank<br>mg<br>(Corrected) | Fraction of total | Rinse Residue Contribution<br>mg | Filter Residue Contribution<br>mg | TOTAL<br>mg |
| 1                                                                       | 6555863  | 0.9260                 | 0.9037                                    | 26.49%            | 0.0190                           | 0.0000                            | 0.9227      |
| 2                                                                       | 6855688  | 1.7000                 | 1.6777                                    | 49.17%            | 0.0352                           | 0.0000                            | 1.7129      |
| 3                                                                       | 6855689  | 0.8530                 | 0.8307                                    | 24.35%            | 0.0174                           | 0.0000                            | 0.8481      |
| TOTALS                                                                  |          | 3.4790                 | 3.4121                                    | 100.00%           | 0.0716                           | 0.0000                            | 3.4837      |
| Runs 1, 2, & 3                                                          |          |                        |                                           |                   |                                  |                                   |             |
| Sampler rinse residue                                                   |          | 238 ml                 |                                           | 0.0725 mg         |                                  |                                   |             |
| Blank Acetone                                                           |          | 191 ml                 |                                           | 0.0007 mg         |                                  |                                   |             |
| Blank correct residue                                                   |          |                        |                                           | 0.0716 mg         |                                  |                                   |             |
| Sampler filter residue                                                  |          | 999                    |                                           | 0.0000 mg         |                                  | System Blank                      |             |
| Blank correct residue                                                   |          |                        |                                           | 0.0000 mg         |                                  |                                   |             |
| Blank Filter                                                            |          | 6855687/73             |                                           | 0.0223 mg         |                                  | Lab Blank                         |             |

# ANTECH

## Analysis/Technology

Mr. David Rossman  
HORIZON ENGINEERING  
13585 NE Whitaker  
Portland OR 97220

01-25-01

January 23, 2001  
Job# 0026402-03

Identification: OSM (Horizon # 1536)  
Received: 12/30/00

|                       |            |        |
|-----------------------|------------|--------|
| <u>Sample #</u>       | 36400      | 36401  |
| <u>Identification</u> | OSM        | OSM    |
|                       | Rinse      | blanks |
|                       | (Runs 1-3) |        |


Front acetone rinse:

|                     |        |         |
|---------------------|--------|---------|
| <u>Volume (mls)</u> | 238    | 191     |
| <u>Residue (g)</u>  | 0.0194 | -0.0005 |

---

|                       |         |         |         |         |         |
|-----------------------|---------|---------|---------|---------|---------|
| <u>Sample #</u>       | 36400   | 36400   | 36400   | 36401   | 36401   |
| <u>Identification</u> | Run 1   | Run 2   | Run 3   | blank   | blank   |
| <u>Filters:</u>       |         |         |         |         |         |
| <u>numbers</u>        | 6555863 | 6855688 | 6855689 | 6855687 | 6855673 |
| <u>Residue (g)</u>    | 0.0469  | 0.0628  | 0.0374  | -0.0007 | -0.0027 |

Respectfully submitted:  
ANTECH

  
Diana Tracy  
president

ANTECH

SAMPLE DATA: EPA RESIDUES

Analyst: MD reviewer: \_\_\_\_\_  
Job# 364 Identification: QSM 1536

FRONT ACETONE:

|                 |                 |                   |                   |                   |
|-----------------|-----------------|-------------------|-------------------|-------------------|
| Sample #        | <u>36400</u>    | _____             | _____             | _____             |
| Sample ID       | <u>✓</u>        | _____             | _____             | _____             |
| vol mark        | _____           | _____             | _____             | _____             |
| Date/time       | <u>1-1 9P</u>   | _____             | _____             | _____             |
| Into dessicator | _____           | _____             | _____             | _____             |
| Vol.(mls)       | <u>238.1</u>    | date/time weighed | date/time weighed | date/time weighed |
| GWt1(g)         | <u>148.1166</u> | <u>1-2 9A</u>     | _____             | _____             |
| GWt2(g)         | <u>148.1170</u> | <u>1-3 9A</u>     | _____             | _____             |
| GWt3(g)         | _____           | _____             | _____             | _____             |
| GWt4(g)         | _____           | _____             | _____             | _____             |
| GWt5(g)         | _____           | _____             | _____             | _____             |
| GWt6(g)         | _____           | _____             | _____             | _____             |
| Average         | <u>148.1168</u> | _____             | _____             | _____             |
| Tare (g)        | <u>148.0974</u> | <u>12-31 1P</u>   | _____             | _____             |
| Net (g)         | <u>.0194</u>    | _____             | _____             | _____             |

BACK ACETONE:

|                 |       |                   |                   |                   |
|-----------------|-------|-------------------|-------------------|-------------------|
| Sample #        | _____ | _____             | _____             | _____             |
| Sample ID       | _____ | _____             | _____             | _____             |
| vol mark        | _____ | _____             | _____             | _____             |
| Date/time       | _____ | _____             | _____             | _____             |
| Into dessicator | _____ | _____             | _____             | _____             |
| Vol.(mls)       | _____ | date/time weighed | date/time weighed | date/time weighed |
| GWt1(g)         | _____ | _____             | _____             | _____             |
| GWt2(g)         | _____ | _____             | _____             | _____             |
| GWt3(g)         | _____ | _____             | _____             | _____             |
| GWt4(g)         | _____ | _____             | _____             | _____             |
| GWt5(g)         | _____ | _____             | _____             | _____             |
| GWt6(g)         | _____ | _____             | _____             | _____             |
| Average         | _____ | _____             | _____             | _____             |
| Tare (g)        | _____ | _____             | _____             | _____             |
| Net (g)         | _____ | _____             | _____             | _____             |

ANTECH  
SAMPLE DATA: EPA RESIDUES

Analyst: MD reviewer: \_\_\_\_\_  
Job# 364 Identification: OSM 1536

BLANKS:

ACETONE:

Sample # 36401  
Sample ID Blank  
vol mark ✓

Date/time 1-1 2P

Into dessicator

Vol(mls) 191.2 date/time weighed \_\_\_\_\_

GWt1(g) 130.3012 1-2 9A

GWt2(g) 130.3008 1-3 9A

GWt3(g) \_\_\_\_\_

GWt4(g) \_\_\_\_\_

GWt5(g) \_\_\_\_\_

GWt6(g) \_\_\_\_\_

Average 130.3010

Tare (g) 130.3015 12-31 1P

Net (g) -0.0005

IMPINGER WATER:

DCM:

FILTER:

Sample # 36401  
Sample ID OSM 6855687  
vol mark \_\_\_\_\_

Date/time 12-29 9A

Into dessicator

Vol(mls) \_\_\_\_\_ date/time weighed \_\_\_\_\_

GWt1(g) 4.2101 1-2 9A

GWt2(g) 4.2102 1-3 9A

GWt3(g) \_\_\_\_\_

GWt4(g) \_\_\_\_\_

GWt5(g) \_\_\_\_\_

GWt6(g) \_\_\_\_\_

Average 4.2102

Tare (g) 4.2109 9-27-00

Net (g) -0.0007

FILTER:

Sample # 36401  
Sample ID OSM 6855673

Date/time 12-29 9A

Vol(mls) \_\_\_\_\_ date/time weighed \_\_\_\_\_

GWt1(g) 4.2874 1-2 9A

GWt2(g) 4.2875 1-3 9A

GWt3(g) \_\_\_\_\_

GWt4(g) \_\_\_\_\_

GWt5(g) \_\_\_\_\_

GWt6(g) \_\_\_\_\_

Average 4.2875

Tare (g) 4.2902 9-26-00

Net (g) -0.0027

SAMPLE DATA: EPA RESIDUES (page 3)

|                           |                 |                 |
|---------------------------|-----------------|-----------------|
| Sample # <u>36400</u>     | <u>36400</u>    | <u>36400</u>    |
| Sample ID <u>05m R1</u>   | <u>05m R2</u>   | <u>05m R2</u>   |
| Date/time <u>12-29 9A</u> | <u>12-29 9A</u> | <u>12-29 9A</u> |
| In dessicator             |                 |                 |

|          | Date/time         |                   | Date/time         |                   | Date/time     |
|----------|-------------------|-------------------|-------------------|-------------------|---------------|
| GWt1(g)  | <u>4.2884</u>     | <u>1-2 9A</u>     | <u>4.3261</u>     | <u>1-2 9A</u>     | <u>4.2561</u> |
| GWt2(g)  | <u>4.2886</u>     | <u>1-3 9A</u>     | <u>4.3260</u>     | <u>1-3 9A</u>     | <u>4.2568</u> |
| GWt3(g)  | <u>          </u> | <u>          </u> | <u>          </u> | <u>          </u> | <u>4.2588</u> |
| GWt4(g)  | <u>          </u> | <u>          </u> | <u>          </u> | <u>          </u> | <u>4.2585</u> |
| Average  | <u>4.2885</u>     | <u>          </u> | <u>4.3261</u>     | <u>          </u> | <u>4.2587</u> |
| Tare (g) | <u>4.2416</u>     | <u>9-27-00</u>    | <u>4.2633</u>     | <u>9-27-00</u>    | <u>4.2213</u> |
| Net (g)  | <u>.0469</u>      | <u>          </u> | <u>.0628</u>      | <u>          </u> | <u>.0374</u>  |

Sample # \_\_\_\_\_  
 Sample ID \_\_\_\_\_  
 Date/time \_\_\_\_\_  
 In dessicator \_\_\_\_\_

|          | Date/time | Date/time | Date/time |
|----------|-----------|-----------|-----------|
| GWt1(g)  |           |           |           |
| GWt2(g)  |           |           |           |
| GWt3(g)  |           |           |           |
| GWt4(g)  |           |           |           |
| Average  |           |           |           |
| Tare (g) |           |           |           |
| Net (g)  |           |           |           |

|                       |       |       |       |       |       |       |
|-----------------------|-------|-------|-------|-------|-------|-------|
| Date/time             | 1-2   | 1-3   | 1-4   | 1-5   | 1-7   | 1-8   |
| Balance calibrated    | ✓     | ✓     | ✓     | ✓     | ✓     | ✓     |
| (NTIS cert wts)       | ✓     | ✓     | ✓     | ✓     | ✓     | ✓     |
| Date/time             | 9A    | 9A    | 8A    | 8A    | 10A   | 8A    |
| Temp/temp             | 71/59 | 70/58 | 70/59 | 70/58 | 71/58 | 70/57 |
| Relative humidity (%) | 49    | 48    | 52    | 48    | 45    | 44    |


ANTECH  
SAMPLE DATA: EPA RESIDUES

Analyst: mw reviewer: \_\_\_\_\_  
Job# 364 Identification: 05m 1536

HOUSE BLANKS:

| ACETONE:        |       |                   | IMMINGER WATER: |                   |       | DCM:  |                   |       |
|-----------------|-------|-------------------|-----------------|-------------------|-------|-------|-------------------|-------|
| Sample #        | _____ |                   | _____           |                   | _____ | _____ |                   |       |
| Sample ID       | _____ |                   | _____           |                   | _____ | _____ |                   |       |
| vol mark        | _____ |                   | _____           |                   | _____ | _____ |                   |       |
| Date/time       | _____ |                   | _____           |                   | _____ | _____ |                   |       |
| Into dessicator |       |                   |                 |                   |       |       |                   |       |
| Vol(mls)        | _____ | date/time weighed | _____           | date/time weighed | _____ | _____ | date/time weighed | _____ |
| GWt1(g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| GWt2(g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| GWt3(g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| GWt4(g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| GWt5(g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| GWt6(g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| Average         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| Tare (g)        | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |
| Net (g)         | _____ | _____             | _____           | _____             | _____ | _____ | _____             | _____ |

| FILTER:         |                  |                   | FILTER |                   |       | EMPTY:           |                   |       |
|-----------------|------------------|-------------------|--------|-------------------|-------|------------------|-------------------|-------|
| Sample #        | _____            |                   | _____  |                   | _____ | _____            |                   |       |
| Sample ID       | <u>lab blank</u> |                   | _____  |                   | _____ | <u>364</u>       |                   |       |
| vol mark        | <u>6855659</u>   |                   | _____  |                   | _____ | <u>lab blank</u> |                   |       |
| Date/time       | _____            |                   | _____  |                   | _____ | _____            |                   |       |
| Into dessicator |                  |                   |        |                   |       |                  |                   |       |
| Vol(mls)        | _____            | date/time weighed | _____  | date/time weighed | _____ | <u>empty</u>     | date/time weighed | _____ |
| GWt1(g)         | <u>4.2940</u>    | <u>1-2 7A</u>     | _____  | _____             | _____ | <u>104.9108</u>  | <u>1-2 9A</u>     | _____ |
| GWt2(g)         | <u>4.2946</u>    | <u>1-3 9A</u>     | _____  | _____             | _____ | <u>104.9109</u>  | <u>1-3 9A</u>     | _____ |
| GWt3(g)         | <u>4.2962</u>    | <u>1-4 8A</u>     | _____  | _____             | _____ | <u>104.9111</u>  | <u>1-4 8A</u>     | _____ |
| GWt4(g)         | <u>4.2962</u>    | <u>1-5 8A</u>     | _____  | _____             | _____ | <u>104.9113</u>  | <u>1-5 8A</u>     | _____ |
| GWt5(g)         | _____            | _____             | _____  | _____             | _____ | <u>104.9113</u>  | <u>1-7 10A</u>    | _____ |
| GWt6(g)         | _____            | _____             | _____  | _____             | _____ | <u>104.9113</u>  | <u>1-8 10A</u>    | _____ |
| Average         | <u>4.2962</u>    | _____             | _____  | _____             | _____ | _____            | _____             | _____ |
| Tare (g)        | <u>4.2990</u>    | _____             | _____  | _____             | _____ | <u>104.9113</u>  | <u>12-31 1P</u>   | _____ |
| Net (g)         | <u>-0028</u>     | _____             | _____  | _____             | _____ | <u>-0000</u>     | _____             | _____ |



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizone@teleport.com

Date Sent to Lab: 12/28/00

### Particulate Chain of Custody Form

Client: OSM Horizon Job No. 1536 Field Personnel Contact: Daniel Bagwell  
Source: Bayview Antech Job No. \_\_\_\_\_ Office (Secondary) Contact: Emily Bagwell

Laboratory: Antech  
501 N.E. Thompson Mill Road  
Corbett, Oregon 97019

Check boxes to indicate samples sent to lab

| Sample Type | Acetone-Front                       | Acetone-Back | Imp. H <sub>2</sub> O | Filter-Front                        | Filter-Back |
|-------------|-------------------------------------|--------------|-----------------------|-------------------------------------|-------------|
| Run 1       | <input checked="" type="checkbox"/> |              |                       | <input checked="" type="checkbox"/> |             |
| Run 2       | <input checked="" type="checkbox"/> |              |                       | <input checked="" type="checkbox"/> |             |
| Run 3       | <input checked="" type="checkbox"/> |              |                       | <input checked="" type="checkbox"/> |             |
| Run         |                                     |              |                       |                                     |             |
| Run         |                                     |              |                       |                                     |             |
| Run         |                                     |              |                       |                                     |             |
| Run         |                                     |              |                       |                                     |             |
| Run         |                                     |              |                       |                                     |             |
| Blank       | <input checked="" type="checkbox"/> |              |                       | <input checked="" type="checkbox"/> |             |

|                                                                                         |                                                                             |
|-----------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| Return Sample to Horizon ASAP for Further Analysis? <input checked="" type="checkbox"/> | Rush <input type="checkbox"/><br>Normal <input checked="" type="checkbox"/> |
|-----------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|

Relinquished by: Daniel Bagwell  
Emily Bagwell 12/28/00  
1106

★ Need Samples Returned to Horizon

# *Environmental Services Laboratory, Inc.*

17400 SW Upper Boones Ferry Road • Suite 270 • Portland, OR 97224 • (503) 670-8520

January 25, 2001

01-30-01

Mike Wallace  
Horizon Engineering  
13585 NE Whitaker Way  
Portland, OR 97230  
TEL: (503) 255-5050  
FAX (503) 255-0505

RE: OSM-1536

Order No.: 0101063

Dear Mike Wallace,

Environmental Services Laboratory received 13 samples on 1/12/01 for the analyses presented in the following report.

The Samples were analyzed for the following tests:  
ICP Metals (EPA 6010B)

There were no problems with the analyses and all data for associated QC met EPA or laboratory specifications except where noted in the Case Narrative. Results apply only to the samples analyzed. Reproduction of this report is permitted only in its entirety, without the written approval from the Laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

*Nichole Karl*

Nichole Karl  
Project Manager

*Kirby Hunter*

Technical Review

# Environmental Services Laboratory

Date: 25-Jan-01

|            |                     |                   |                       |
|------------|---------------------|-------------------|-----------------------|
| CLIENT:    | Horizon Engineering | Client Sample ID: | Filter Run 1(6855683) |
| Lab Order: | 0101063             | Tag Number:       |                       |
| Project:   | OSM-1536            | Collection Date:  | 1/11/01               |
| Lab ID:    | 0101063-01A         | Matrix:           | SOLID                 |

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 926    | 1.00      |      | ug    | 1  | 1/22/01       |

|             |                                                     |                                                     |
|-------------|-----------------------------------------------------|-----------------------------------------------------|
| Qualifiers: | ND - Not Detected at the Reporting Limit            | S - Spike Recovery outside accepted recovery limits |
|             | J - Analyte detected below quantitation limits      | R - RPD outside accepted recovery limits            |
|             | B - Analyte detected in the associated Method Blank | E - Value above quantitation range                  |
|             | * - Value exceeds Maximum Contaminant Level         |                                                     |

1 of 11

**Environmental Services Laboratory**

Date: 25-Jan-01

|                   |                     |                          |                       |
|-------------------|---------------------|--------------------------|-----------------------|
| <b>CLIENT:</b>    | Horizon Engineering | <b>Client Sample ID:</b> | Filter Run 2(6855688) |
| <b>Lab Order:</b> | 0101063             | <b>Tag Number:</b>       |                       |
| <b>Project:</b>   | OSM-1536            | <b>Collection Date:</b>  | 1/11/01               |
| <b>Lab ID:</b>    | 0101063-02A         | <b>Matrix:</b>           | SOLID                 |

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 1,700  | 1.00      |      | ug    | 1  | 1/22/01       |

|                    |                                                     |                                                     |
|--------------------|-----------------------------------------------------|-----------------------------------------------------|
| <b>Qualifiers:</b> | ND - Not Detected at the Reporting Limit            | S - Spike Recovery outside accepted recovery limits |
|                    | J - Analyte detected below quantitation limits      | R - RPD outside accepted recovery limits            |
|                    | B - Analyte detected in the associated Method Blank | E - Value above quantitation range                  |
|                    | • - Value exceeds Maximum Contaminant Level         |                                                     |

2 of 11

**Environmental Services Laboratory**

Date: 25-Jan-01

**CLIENT:** Horizon Engineering**Client Sample ID:** Filter Run 3(6855689)**Lab Order:** 0101063**Tag Number:****Project:** OSM-1536**Collection Date:** 1/11/01**Lab ID:** 0101063-03A**Matrix:** SOLID

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 853    | 1.00      |      | ug    | 1  | 1/22/01       |

**Qualifiers:** ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
\* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

3 of 11

# Environmental Services Laboratory

Date: 25-Jan-01

|            |                     |                   |                        |
|------------|---------------------|-------------------|------------------------|
| CLIENT:    | Horizon Engineering | Client Sample ID: | Filter Blank (6855687) |
| Lab Order: | 0101063             | Tag Number:       |                        |
| Project:   | OSM-1536            | Collection Date:  | 1/11/01                |
| Lab ID:    | 0101063-04A         | Matrix:           | SOLID                  |

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 37.0   | 1.00      |      | ug    | 1  | 1/22/01       |

Qualifiers: ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
\* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

4 of 11

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering  
Lab Order: 0101063  
Project: OSM-1536  
Lab ID: 0101063-05A

Client Sample ID: Filter End Blank(6855673)  
Tag Number:  
Collection Date: 1/11/01  
Matrix: SOLID

| Analyses   | Result    | Limit | Qual | Units | DF | Date Analyzed |
|------------|-----------|-------|------|-------|----|---------------|
| ICP METALS | EPA 6010B |       |      |       |    | Analyst: lmc  |
| Lead       | 7.60      | 1.00  |      | ug    | 1  | 1/22/01       |

Qualifiers: ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
• - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

5 of 11

**Environmental Services Laboratory**

Date: 25-Jan-01

CLIENT: Horizon Engineering  
Lab Order: 0101063  
Project: OSM-1536  
Lab ID: 0101063-06A

Client Sample ID: 36400 Acetone  
Tag Number:  
Collection Date: 1/11/01  
Matrix: SOLID

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 72.5   | 0.500     |      | ug    | 1  | 1/22/01       |

**Qualifiers:** ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
\* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

6 of 11

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering  
Lab Order: 0101063  
Project: OSM-1536  
Lab ID: 0101063-07A

Client Sample ID: 36401 Acetone  
Tag Number:  
Collection Date: 1/11/01  
Matrix: SOLID

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 0.700  | 0.500     |      | ug    | 1  | 1/22/01       |

Qualifiers: ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
• - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

7 of 11

**Environmental Services Laboratory**

Date: 25-Jan-01

CLIENT: Horizon Engineering  
Lab Order: 0101063  
Project: OSM-1536  
Lab ID: 0101063-10A

Client Sample ID: 364 Lab Blank  
Tag Number:  
Collection Date: 1/11/01  
Matrix: SOLID

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | ND     | 0.500     |      | ug    | 1  | 1/22/01       |

Qualifiers: ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
\* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

10 of 11

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering

Work Order: 0101063

Project: OSM-1536

## QC SUMMARY REPORT

Method Blank

|                    |                |                      |           |                        |                                                        |
|--------------------|----------------|----------------------|-----------|------------------------|--------------------------------------------------------|
| Sample ID: MB-2273 | Batch ID: 2273 | Test Code: EPA 6010B | Units: ug | Analysis Date: 1/22/01 | Prep Date: 1/22/01                                     |
| Client ID:         | 0101063        | Run ID: ICP_010122C  |           | SeqNo: 64372           |                                                        |
| Analyte            | Result         | PQL                  | SPK value | SPK Ref Val            | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |
| Lead               | ND             |                      |           |                        | 0.5                                                    |

|             |                                                |                                                     |                                                     |
|-------------|------------------------------------------------|-----------------------------------------------------|-----------------------------------------------------|
| Qualifiers: | ND - Not Detected at the Reporting Limit       | S - Spike Recovery outside accepted recovery limits | B - Analyte detected in the associated Method Blank |
|             | J - Analyte detected below quantitation limits | R - RPD outside accepted recovery limits            |                                                     |

1 of 1

**Date: 25-Jan-01**

**Project:** OSM-1536

## QC SUMMARY REPORT

**Sample Duplicate**

|                                |                     |                      |           |                       |                    |          |           |             |      |          |      |
|--------------------------------|---------------------|----------------------|-----------|-----------------------|--------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: 0101063-04A DUP     | Batch ID: 2273      | Test Code: EPA 6010B | Units: ug | Analysis Date 1/22/01 | Prep Date: 1/22/01 |          |           |             |      |          |      |
| Client ID: Filter Blank (6855) | Run ID: ICP_010122C | SeqNo: 64378         |           |                       |                    |          |           |             |      |          |      |
| Analyte                        | Result              | PQL                  | SPK value | SPK Ref Val           | %REC               | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Lead                           | 34.1                | 1                    | 0         | 0                     | 0.0%               | 0        | 0         | 37          | 8.2% | 20       |      |

**Lead**

R - RPD outside accepted recovery limits

**B - Analyte detected in the associated Method Blank**

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering

Work Order: 0101063

Project: OSM-1536

## QC SUMMARY REPORT

Sample Matrix Spike

|                                |        |                |                      |             |           |                        |           |                    |      |
|--------------------------------|--------|----------------|----------------------|-------------|-----------|------------------------|-----------|--------------------|------|
| Sample ID: 0101063-05A MS      |        | Batch ID: 2273 | Test Code: EPA 6010B |             | Units: ug | Analysis Date: 1/22/01 |           | Prep Date: 1/22/01 |      |
| Client ID: Filter End Blank(6) |        | 0101063        | Run ID: ICP_010122C  |             |           | SeqNo: 64375           |           |                    |      |
| Analyte                        | Result | PQL            | SPK value            | SPK Ref Val | %REC      | LowLimit               | HighLimit | RPD Ref Val        | Qual |
| Lead                           | 26.8   | 1              | 25                   | 7.6         | 76.8%     | 75                     | 125       |                    | 0    |
| Sample ID: 0101063-05A MSD     |        | Batch ID: 2273 | Test Code: EPA 6010B |             | Units: ug | Analysis Date: 1/22/01 |           | Prep Date: 1/22/01 |      |
| Client ID: Filter End Blank(6) |        | 0101063        | Run ID: ICP_010122C  |             |           | SeqNo: 64376           |           |                    |      |
| Analyte                        | Result | PQL            | SPK value            | SPK Ref Val | %REC      | LowLimit               | HighLimit | RPD Ref Val        | Qual |
| Lead                           | 27.3   | 1              | 25                   | 7.6         | 78.8%     | 75                     | 125       | 26.8               | 20   |

Qualifiers: ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits

B - Analyte detected in the associated Method Blank

1 of 1

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering

Work Order: 0101063

Project: OSM-1536

## QC SUMMARY REPORT

Laboratory Control Spike - generic

|                     |                |                      |           |                       |                    |          |           |             |      |          |      |
|---------------------|----------------|----------------------|-----------|-----------------------|--------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: LCS-2273 | Batch ID: 2273 | Test Code: EPA 6010B | Units: ug | Analysis Date 1/22/01 | Prep Date: 1/22/01 |          |           |             |      |          |      |
| Client ID:          | 0101063        | Run ID: ICP_010122C  |           | SeqNo: 64373          |                    |          |           |             |      |          |      |
| Analyte             | Result         | PQL                  | SPK value | SPK Ref Val           | %REC               | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Lead                | 25.8           | 0.5                  | 25        | 0                     | 103.2%             | 80       | 120       | 0           |      |          |      |

|             |                                                |                                                     |                                                     |
|-------------|------------------------------------------------|-----------------------------------------------------|-----------------------------------------------------|
| Qualifiers: | ND - Not Detected at the Reporting Limit       | S - Spike Recovery outside accepted recovery limits | B - Analyte detected in the associated Method Blank |
|             | J - Analyte detected below quantitation limits | R - RPD outside accepted recovery limits            |                                                     |

1 of 1

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering

Work Order: 0101063

Project: OSM-1536

## QC SUMMARY REPORT

Minerals ICP for ICP

|                    |                |                      |             |                        |                    |
|--------------------|----------------|----------------------|-------------|------------------------|--------------------|
| Sample ID: ICPVHI  | Batch ID: 2273 | Test Code: EPA 6010B | Units: mg/L | Analysis Date: 1/22/01 | Prep Date: 1/22/01 |
| Client ID:         | 0101063        | Run ID: ICP_010122C  |             | SeqNo: 64371           |                    |
| Analyte            | Result         | PQL                  | SPK value   | SPK Ref Val            | %REC               |
| Lead               | 10.2           | 0.005                | 10          | 0                      | 102.0%             |
|                    |                |                      |             | LowLimit               | HighLimit          |
|                    |                |                      |             | 90                     | 110                |
|                    |                |                      |             | RPDLimit               | Qual               |
|                    |                |                      |             | 0                      |                    |
| Sample ID: ICPVLOW | Batch ID: 2273 | Test Code: EPA 6010B | Units: mg/L | Analysis Date: 1/22/01 | Prep Date: 1/22/01 |
| Client ID:         | 0101063        | Run ID: ICP_010122C  |             | SeqNo: 64370           |                    |
| Analyte            | Result         | PQL                  | SPK value   | SPK Ref Val            | %REC               |
| Lead               | .532           | 0.005                | 0.5         | 0                      | 106.4%             |
|                    |                |                      |             | LowLimit               | HighLimit          |
|                    |                |                      |             | 90                     | 110                |
|                    |                |                      |             | RPDLimit               | Qual               |
|                    |                |                      |             | 0                      |                    |

### Qualifiers:

ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits

B - Analyte detected in the associated Method Blank

1 of 1

ENVIRONMENTAL SERVICES LAB  
503-670-8520


13585 N.E. Whitaker Way  
Portland, OR 97230  
Ph. (503)255-5050  
Fax (503)255-0505  
horizone@teleport.com

# CHAIN OF CUSTODY REPORT

# Work Order #

|                                                                                                                                               |                          |                                 |               |
|-----------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|---------------|
| REPORT TO: HORIZON ENGINEERING/                                                                                                               |                          | INVOICE TO: HORIZON ENGINEERING |               |
| ATTENTION: MIKE WALLACE                                                                                                                       | ATTENTION: PENNY ROSSMAN |                                 |               |
| ADDRESS: 13585 NE WHITAKER WAY                                                                                                                | ADDRESS: - SAME -        |                                 |               |
| PHONE: 503-255-5050                                                                                                                           | FAX: 503-255-0505        |                                 |               |
| PROJECT NAME: OSM                                                                                                                             | QUOTE #:                 |                                 |               |
| PROJECT NUMBER: 1536                                                                                                                          | ANALYSED REQUEST:        |                                 |               |
| SAMPLED BY: DAVID BAGWELL                                                                                                                     | LEAD                     |                                 |               |
| CLIENT SAMPLE IDENTIFICATION                                                                                                                  | SAMPLING DATE/TIME       | SAMPLE ID (Lab/Client)          |               |
| FILTER RUN 1 (6855683)                                                                                                                        |                          | 0101063-01                      | X             |
| FILTER RUN 2 (6855688)                                                                                                                        |                          | 02                              | X             |
| FILTER RUN 3 (6855689)                                                                                                                        |                          | 03                              | X             |
| FILTER BLANK (6855687)                                                                                                                        |                          | 04                              | X             |
| FILTER END BLANK (6855673)                                                                                                                    |                          | 05                              | X             |
| 36400 ACETONE                                                                                                                                 |                          | 06                              | X             |
| 36401 ACETONE                                                                                                                                 |                          | 07                              | X             |
| 36402 H <sub>2</sub> O                                                                                                                        |                          | 08                              | X             |
| 36403 H <sub>2</sub> O                                                                                                                        |                          | 09                              | X             |
| 364 LAB BLANK                                                                                                                                 |                          | 10                              | X             |
| RELINQUISHED BY: YVANKA WHITAKER                                                                                                              | DATE: 11/1/01            | RECEIVED BY: J. J. J.           | DATE: 11/1/01 |
| PRINT NAME:                                                                                                                                   | TIME:                    | PRINT NAME: JEREMY JOONEY       | TIME: 2:45    |
| RELINQUISHED BY:                                                                                                                              | DATE:                    | RECEIVED BY:                    | DATE:         |
| PRINT NAME:                                                                                                                                   | TIME:                    | PRINT NAME:                     | TIME:         |
| ADDITIONAL REMARKS: ANALYSIS BY EPA 6010 (ICP). DIGEST COMPLETE FILTERS. PERFORM A SINGLE SPIKE, METHOD OF STANDARD ADDITIONS RECOVERY CHECK. |                          |                                 |               |

## Baghouse Sampling Diagram



\*\*\*\*\*Horizon Engineering\*\*\*\*\*

## **VOLUME FLOW RATE DETERMINATION**

Flow Rate Determinations and Field Data

Traverse Point Location – Inlet & Outlet

# Outlet Flow Rate Determination

| Client<br>Source<br>Location | Oregon Steel Mills<br>ICA Baghouse-EAF<br>Portland, OR | Compart.<br>Point | HI-VOL RUN #1 |          |          |          |          |          |          |          |        |          |          |          |          |          |          |          | Avg/Total<br>16                    | 15 of 16<br>Compart. |
|------------------------------|--------------------------------------------------------|-------------------|---------------|----------|----------|----------|----------|----------|----------|----------|--------|----------|----------|----------|----------|----------|----------|----------|------------------------------------|----------------------|
|                              |                                                        |                   | 1             | 2        | 3        | 4        | 5        | 6        | 7        | 8        | 9      | 10       | 11       | 12       | 13       | 14       | 15       |          |                                    |                      |
| Date                         | 27-Dec-2000                                            | K                 | 0.0199        | 0.0167   | 0.0012   | 0.0053   | 0.0004   | 0.0060   | 0.0101   | 0.0025   | A      | 0.0059   | 0.0193   | 0.0336   | 0.0344   | 0.0091   | 0.0160   | 0.0058   | 0.1732<br>0.0864                   |                      |
| Testes                       | MIE/BTE/JH/CDB                                         | L                 | 0.0472        | 0.0115   | 0.0391   | 0.0473   | 0.0483   | 0.0330   | 0.0462   | 0.0113   | B      | 0.0447   | 0.0436   | 0.0223   | 0.0313   | 0.0422   | 0.0285   | 0.0238   |                                    |                      |
| File                         | unit1336                                               | *M                | 0.0462        | 0.0374   | 0.0361   | 0.0436   | 0.0489   | 0.0325   | 0.0430   | *C       | 0.0397 | 0.0452   | 0.0269   | 0.0363   | 0.0382   | 0.0395   | 0.0336   | 0.0257   |                                    |                      |
| Analysis/QA                  | MIE/MEW                                                | N                 | 0.0450        | 0.0400   | 0.0381   | 0.0377   | 0.0474   | 0.0355   | 0.0587   | 0.0126   | D      | 0.0562   | 0.0507   | 0.0389   | 0.0348   | 0.0384   | 0.0375   | 0.0391   |                                    | 0.0260               |
|                              |                                                        | O                 | 0.0450        | 0.0325   | 0.0372   | 0.0259   | 0.0422   | 0.0406   | 0.0582   | 0.0143   | E      | 0.0540   | 0.0473   | 0.0397   | 0.0217   | 0.0454   | 0.0318   | 0.0310   |                                    | 0.0314               |
| Equipment                    | ShortRidge.11s                                         | K                 | 0.0241        |          |          |          |          |          |          |          | A      |          |          |          |          |          |          |          | 583.0<br>37.686<br>490.9<br>31.790 |                      |
| Total Runs                   | Run #1                                                 | L                 | 0.0351        |          |          |          |          |          |          |          | *C     |          |          |          |          |          |          |          |                                    |                      |
| Pis per Run                  |                                                        | *M                | 0.0499        |          |          |          |          |          |          |          | D      |          |          |          |          |          |          |          |                                    |                      |
|                              |                                                        | N                 | 0.0471        |          |          |          |          |          |          |          |        |          |          |          |          |          |          |          |                                    |                      |
|                              |                                                        | O                 | 0.0410        |          |          |          |          |          |          |          | E      |          |          |          |          |          |          |          |                                    |                      |
| All Points                   | SQRT(dP)                                               | 0.1732            | 0.2042        | 0.1620   | 0.1621   | 0.1708   | 0.1768   | 0.1659   | 0.2013   | 0.1007   |        | 0.1914   | 0.2006   | 0.1786   | 0.1774   | 0.2042   | 0.1706   | 0.1581   | 0.1458                             |                      |
| Standard Deviation           | STD(SQRT(dP))                                          | 0.0864            | 0.0191        | 0.0851   | 0.0927   | 0.0932   | 0.1044   | 0.0888   | 0.1072   | 0.0535   |        | 0.1044   | 0.1027   | 0.0904   | 0.0894   | 0.1022   | 0.0895   | 0.0823   | 0.0772                             |                      |
| Symbol                       | Definitions, Units                                     | Method/Notes      | 1             | 2        | 3        | 4        | 5        | 6        | 7        | 8        |        | 9        | 10       | 11       | 12       | 13       | 14       | 15       | 16                                 |                      |
| As                           | Cross Section                                          | in <sup>2</sup>   | 9.308         | 9.308    | 9.308    | 9.308    | 9.308    | 9.308    | 9.308    | 9.308    |        | 9.308    | 9.308    | 9.308    | 9.308    | 9.308    | 9.308    | 9.308    | 148.928                            |                      |
| Cp                           | Pilot Coef.                                            |                   | 0.7802        | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 0.7802   |        | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 0.7802   | 139.620                            |                      |
| Ts                           | Duct temperature                                       | °F                | 134.5         | 138.0    | 185.0    | 170.0    | 162.0    | 172.0    | 160.0    | 155.0    |        | 169.0    | 174.0    | 146.0    | 150.0    | 162.0    | 156.0    | 150.0    | 159.3                              |                      |
| Ts                           | Duct temperature                                       | °R                | 614.2         | 597.7    | 624.7    | 624.7    | 621.7    | 621.7    | 619.7    | 614.7    |        | 628.7    | 633.7    | 605.7    | 609.7    | 618.7    | 613.7    | 618.7    |                                    |                      |
| Tdb                          | Dry bulb temp.                                         | °F                | 155.0         |          |          |          |          |          |          |          |        |          |          |          |          |          |          |          |                                    |                      |
| Twb                          | Wet bulb temp.                                         | °F                | 93.0          |          |          |          |          |          |          |          |        |          |          |          |          |          |          |          |                                    |                      |
| Pbar                         | Barometric Pressure                                    | in Hg             | 30.49         | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    |        | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    |                                    |                      |
| Pg                           | Static Pressure                                        | in H2O            | 0.03          | 0.03     | 0.03     | 0.03     | 0.03     | 0.03     | 0.03     | 0.03     |        | 0.03     | 0.03     | 0.03     | 0.03     | 0.03     | 0.03     | 0.03     |                                    |                      |
| Ps                           | Duct Pressure                                          | in Hg             | 30.49         | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    |        | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    | 30.49    |                                    |                      |
| dp-%                         | Moisture, % Stack                                      |                   | 0.2042        | 0.1620   | 0.1621   | 0.1708   | 0.1768   | 0.1659   | 0.2013   | 0.1007   |        | 0.1914   | 0.2006   | 0.1786   | 0.1774   | 0.2042   | 0.1706   | 0.1581   | 0.1458                             |                      |
| Bws                          | Mole fraction dry gas                                  | mfg               | 2.88          | 2.88     | 2.88     | 2.88     | 2.88     | 2.88     | 2.88     | 2.88     |        | 2.88     | 2.88     | 2.88     | 2.88     | 2.88     | 2.88     | 2.88     |                                    |                      |
| Oxygen                       | Outlet-Estimated                                       |                   | 97.1%         | 97.1%    | 97.1%    | 97.1%    | 97.1%    | 97.1%    | 97.1%    | 97.1%    |        | 97.1%    | 97.1%    | 97.1%    | 97.1%    | 97.1%    | 97.1%    | 97.1%    |                                    |                      |
| Carbon Dioxide               | Outlet-Estimated                                       |                   | 20.58         | 20.58    | 20.58    | 20.58    | 20.58    | 20.58    | 20.58    | 20.58    |        | 20.58    | 20.58    | 20.58    | 20.58    | 20.58    | 20.58    | 20.58    |                                    |                      |
| Md                           | Molecular weight Dry                                   |                   | 0.33          | 0.33     | 0.33     | 0.33     | 0.33     | 0.33     | 0.33     | 0.33     |        | 0.33     | 0.33     | 0.33     | 0.33     | 0.33     | 0.33     | 0.33     |                                    |                      |
| Ms                           | Molecular weight Wet                                   |                   | 29.00         | 29.00    | 29.00    | 29.00    | 29.00    | 29.00    | 29.00    | 29.00    |        | 29.00    | 29.00    | 29.00    | 29.00    | 29.00    | 29.00    | 29.00    |                                    |                      |
| vs                           | Velocity actual                                        | fpm               | 28.68         | 28.68    | 28.68    | 28.68    | 28.68    | 28.68    | 28.68    | 28.68    |        | 28.68    | 28.68    | 28.68    | 28.68    | 28.68    | 28.68    | 28.68    |                                    |                      |
| Qa                           | Flowrate actual                                        | acfm/min          | 684.7         | 536.0    | 548.2    | 580.1    | 596.5    | 564.1    | 678.0    | 337.8    |        | 649.3    | 683.3    | 594.9    | 592.6    | 685.5    | 575.7    | 530.8    | 490.9                              |                      |
| Qsd (5-pt)                   | Flowrate @std                                          | scfm/min          | 44,257.5      | 34,647.3 | 35,434.7 | 37,496.7 | 38,560.0 | 36,462.0 | 43,823.1 | 21,835.7 |        | 41,973.2 | 44,168.0 | 38,451.4 | 38,303.7 | 44,311.8 | 37,214.4 | 34,307.1 | 31,728.5                           |                      |
|                              | Average Flow During Hi-vol testing                     |                   | 37,634.3      | 30,275.6 | 29,625.4 | 31,100.4 | 32,393.8 | 30,146.4 | 36,934.1 | 18,552.8 |        | 34,868.6 | 36,402.4 | 33,156.0 | 32,811.9 | 37,588.7 | 31,263.4 | 29,102.0 | 26,784.1                           |                      |

### Outlet Flow Rate Determination

[illegible]

• High volume sampler tested these points (in BOLD)

# Outlet Flow Rate Determination

| Client | Source | Location | Date | Testers | File | Analysis-QA | Equipment | Total Runs | Pts per Run | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84 | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 | 101 | 102 | 103 | 104 | 105 | 106 | 107 | 108 | 109 | 110 | 111 | 112 | 113 | 114 | 115 | 116 | 117 | 118 | 119 | 120 | 121 | 122 | 123 | 124 | 125 | 126 | 127 | 128 | 129 | 130 | 131 | 132 | 133 | 134 | 135 | 136 | 137 | 138 | 139 | 140 | 141 | 142 | 143 | 144 | 145 | 146 | 147 | 148 | 149 | 150 | 151 | 152 | 153 | 154 | 155 | 156 | 157 | 158 | 159 | 160 | 161 | 162 | 163 | 164 | 165 | 166 | 167 | 168 | 169 | 170 | 171 | 172 | 173 | 174 | 175 | 176 | 177 | 178 | 179 | 180 | 181 | 182 | 183 | 184 | 185 | 186 | 187 | 188 | 189 | 190 | 191 | 192 | 193 | 194 | 195 | 196 | 197 | 198 | 199 | 200 | 201 | 202 | 203 | 204 | 205 | 206 | 207 | 208 | 209 | 210 | 211 | 212 | 213 | 214 | 215 | 216 | 217 | 218 | 219 | 220 | 221 | 222 | 223 | 224 | 225 | 226 | 227 | 228 | 229 | 230 | 231 | 232 | 233 | 234 | 235 | 236 | 237 | 238 | 239 | 240 | 241 | 242 | 243 | 244 | 245 | 246 | 247 | 248 | 249 | 250 | 251 | 252 | 253 | 254 | 255 | 256 | 257 | 258 | 259 | 260 | 261 | 262 | 263 | 264 | 265 | 266 | 267 | 268 | 269 | 270 | 271 | 272 | 273 | 274 | 275 | 276 | 277 | 278 | 279 | 280 | 281 | 282 | 283 | 284 | 285 | 286 | 287 | 288 | 289 | 290 | 291 | 292 | 293 | 294 | 295 | 296 | 297 | 298 | 299 | 300 | 301 | 302 | 303 | 304 | 305 | 306 | 307 | 308 | 309 | 310 | 311 | 312 | 313 | 314 | 315 | 316 | 317 | 318 | 319 | 320 | 321 | 322 | 323 | 324 | 325 | 326 | 327 | 328 | 329 | 330 | 331 | 332 | 333 | 334 | 335 | 336 | 337 | 338 | 339 | 340 | 341 | 342 | 343 | 344 | 345 | 346 | 347 | 348 | 349 | 350 | 351 | 352 | 353 | 354 | 355 | 356 | 357 | 358 | 359 | 360 | 361 | 362 | 363 | 364 | 365 | 366 | 367 | 368 | 369 | 370 | 371 | 372 | 373 | 374 | 375 | 376 | 377 | 378 | 379 | 380 | 381 | 382 | 383 | 384 | 385 | 386 | 387 | 388 | 389 | 390 | 391 | 392 | 393 | 394 | 395 | 396 | 397 | 398 | 399 | 400 | 401 | 402 | 403 | 404 | 405 | 406 | 407 | 408 | 409 | 410 | 411 | 412 | 413 | 414 | 415 | 416 | 417 | 418 | 419 | 420 | 421 | 422 | 423 | 424 | 425 | 426 | 427 | 428 | 429 | 430 | 431 | 432 | 433 | 434 | 435 | 436 | 437 | 438 | 439 | 440 | 441 | 442 | 443 | 444 | 445 | 446 | 447 | 448 | 449 | 450 | 451 | 452 | 453 | 454 | 455 | 456 | 457 | 458 | 459 | 460 | 461 | 462 | 463 | 464 | 465 | 466 | 467 | 468 | 469 | 470 | 471 | 472 | 473 | 474 | 475 | 476 | 477 | 478 | 479 | 480 | 481 | 482 | 483 | 484 | 485 | 486 | 487 | 488 | 489 | 490 | 491 | 492 | 493 | 494 | 495 | 496 | 497 | 498 | 499 | 500 | 501 | 502 | 503 | 504 | 505 | 506 | 507 | 508 | 509 | 510 | 511 | 512 | 513 | 514 | 515 | 516 | 517 | 518 | 519 | 520 | 521 | 522 | 523 | 524 | 525 | 526 | 527 | 528 | 529 | 530 | 531 | 532 | 533 | 534 | 535 | 536 | 537 | 538 | 539 | 540 | 541 | 542 | 543 | 544 | 545 | 546 | 547 | 548 | 549 | 550 | 551 | 552 | 553 | 554 | 555 | 556 | 557 | 558 | 559 | 560 | 561 | 562 | 563 | 564 | 565 | 566 | 567 | 568 | 569 | 570 | 571 | 572 | 573 | 574 | 575 | 576 | 577 | 578 | 579 | 580 | 581 | 582 | 583 | 584 | 585 | 586 | 587 | 588 | 589 | 590 | 591 | 592 | 593 | 594 | 595 | 596 | 597 | 598 | 599 | 600 | 601 | 602 | 603 | 604 | 605 | 606 | 607 | 608 | 609 | 610 | 611 | 612 | 613 | 614 | 615 | 616 | 617 | 618 | 619 | 620 | 621 | 622 | 623 | 624 | 625 | 626 | 627 | 628 | 629 | 630 | 631 | 632 | 633 | 634 | 635 | 636 | 637 | 638 | 639 | 640 | 641 | 642 | 643 | 644 | 645 | 646 | 647 | 648 | 649 | 650 | 651 | 652 | 653 | 654 | 655 | 656 | 657 | 658 | 659 | 660 | 661 | 662 | 663 | 664 | 665 | 666 | 667 | 668 | 669 | 670 | 671 | 672 | 673 | 674 | 675 | 676 | 677 | 678 | 679 | 680 | 681 | 682 | 683 | 684 | 685 | 686 | 687 | 688 | 689 | 690 | 691 | 692 | 693 | 694 | 695 | 696 | 697 | 698 | 699 | 700 | 701 | 702 | 703 | 704 | 705 | 706 | 707 | 708 | 709 | 710 | 711 | 712 | 713 | 714 | 715 | 716 | 717 | 718 | 719 | 720 | 721 | 722 | 723 | 724 | 725 | 726 | 727 | 728 | 729 | 730 | 731 | 732 | 733 | 734 | 735 | 736 | 737 | 738 | 739 | 740 | 741 | 742 | 743 | 744 | 745 | 746 | 747 | 748 | 749 | 750 | 751 | 752 | 753 | 754 | 755 | 756 | 757 | 758 | 759 | 760 | 761 | 762 | 763 | 764 | 765 | 766 | 767 | 768 | 769 | 770 | 771 | 772 | 773 | 774 | 775 | 776 | 777 | 778 | 779 | 780 | 781 | 782 | 783 | 784 | 785 | 786 | 787 | 788 | 789 | 790 | 791 | 792 | 793 | 794 | 795 | 796 | 797 | 798 | 799 | 800 | 801 | 802 | 803 | 804 | 805 | 806 | 807 | 808 | 809 | 810 | 811 | 812 | 813 | 814 | 815 | 816 | 817 | 818 | 819 | 820 | 821 | 822 | 823 | 824 | 825 | 826 | 827 | 828 | 829 | 830 | 831 | 832 | 833 | 834 | 835 | 836 | 837 | 838 | 839 | 840 | 841 | 842 | 843 | 844 | 845 | 846 | 847 | 848 | 849 | 850 | 851 | 852 | 853 | 854 | 855 | 856 | 857 | 858 | 859 | 860 | 861 | 862 | 863 | 864 | 865 | 866 | 867 | 868 | 869 | 870 | 871 | 872 | 873 | 874 | 875 | 876 | 877 | 878 | 879 | 880 | 881 | 882 | 883 | 884 | 885 | 886 | 887 | 888 | 889 | 890 | 891 | 892 | 893 | 894 | 895 | 896 | 897 | 898 | 899 | 900 | 901 | 902 | 903 | 904 | 905 | 906 | 907 | 908 | 909 | 910 | 911 | 912 | 913 | 914 | 915 | 916 | 917 | 918 | 919 | 920 | 921 | 922 | 923 | 924 | 925 | 926 | 927 | 928 | 929 | 930 | 931 | 932 | 933 | 934 | 935 | 936 | 937 | 938 | 939 | 940 | 941 | 942 | 943 | 944 | 945 | 946 | 947 | 948 | 949 | 950 | 951 | 952 | 953 | 954 | 955 | 956 | 957 | 958 | 959 | 960 | 961 | 962 | 963 | 964 | 965 | 966 | 967 | 968 | 969 | 970 | 971 | 972 | 973 | 974 | 975 | 976 | 977 | 978 | 979 | 980 | 981 | 982 | 983 | 984 | 985 | 986 | 987 | 988 | 989 | 990 | 991 | 992 | 993 | 994 | 995 | 996 | 997 | 998 | 999 | 1000 | 1001 | 1002 | 1003 | 1004 | 1005 | 1006 | 1007 | 1008 | 1009 | 1010 | 1011 | 1012 | 1013 | 1014 | 1015 | 1016 | 1017 | 1018 | 1019 | 1020 | 1021 | 1022 | 1023 | 1024 | 1025 | 1026 | 1027 | 1028 | 1029 | 1030 | 1031 | 1032 | 1033 | 1034 | 1035 | 1036 | 1037 | 1038 | 1039 | 1040 | 1041 | 1042 | 1043 | 1044 | 1045 | 1046 | 1047 | 1048 | 1049 | 1050 | 1051 | 1052 | 1053 | 1054 | 1055 | 1056 | 1057 | 1058 | 1059 | 1060 | 1061 | 1062 | 1063 | 1064 | 1065 | 1066 | 1067 | 1068 | 1069 | 1070 | 1071 | 1072 | 1073 | 1074 | 1075 | 1076 | 1077 | 1078 | 1079 | 1080 | 1081 | 1082 | 1083 | 1084 | 1085 | 1086 | 1087 | 1088 | 1089 | 1090 | 1091 | 1092 | 1093 | 1094 | 1095 | 1096 | 1097 | 1098 | 1099 | 1100 | 1101 | 1102 | 1103 | 1104 | 1105 | 1106 | 1107 | 1108 | 1109 | 1110 | 1111 | 1112 | 1113 | 1114 | 1115 | 1116 | 1117 | 1118 | 1119 | 1120 | 1121 | 1122 | 1123 | 1124 | 1125 | 1126 | 1127 | 1128 | 1129 | 1130 | 1131 | 1132 | 1133 | 1134 | 1135 | 1136 | 1137 | 1138 | 1139 | 1140 | 1141 | 1142 | 1143 | 1144 | 1145 | 1146 | 1147 | 1148 | 1149 | 1150 | 1151 | 1152 | 1153 | 1154 | 1155 | 1156 | 1157 | 1158 | 1159 | 1160 | 1161 | 1162 | 1163 | 1164 | 1165 | 1166 | 1167 | 1168 | 1169 | 1170 | 1171 | 1172 | 1173 | 1174 | 1175 | 1176 | 1177 | 1178 | 1179 | 1180 | 1181 | 1182 | 1183 | 1184 | 1185 | 1186 | 1187 | 1188 | 1189 | 1190 | 1191 | 1192 | 1193 | 1194 | 1195 | 1196 | 1197 | 1198 | 1199 | 1200 | 1201 | 1202 | 1203 | 1204 | 1205 | 1206 | 1207 | 1208 | 1209 | 1210 | 1211 | 1212 | 1213 | 1214 | 1215 | 1216 | 1217 | 1218 | 1219 | 1220 | 1221 | 1222 | 1223 | 1224 | 1225 | 1226 | 1227 | 1228 | 1229 | 1230 | 1231 | 1232 | 1233 | 1234 | 1235 | 1236 | 1237 | 1238 | 1239 | 1240 | 1241 | 1242 | 1243 | 1244 | 1245 | 1246 | 1247 | 1248 | 1249 | 1250 | 1251 | 1252 | 1253 | 1254 | 1255 | 1256 | 1257 | 1258 | 1259 | 1260 | 1261 | 1262 | 1263 | 1264 | 1265 | 1266 | 1267 | 1268 | 1269 | 1270 | 1271 | 1272 | 1273 | 1274 | 1275 | 1276 | 1277 | 1278 | 1279 | 1280 | 1281 | 1282 | 1283 | 1284 | 1285 | 1286 | 1287 | 1288 | 1289 | 1290 | 1291 | 1292 | 1293 | 1294 | 1295 | 1296 | 1297 | 1298 | 1299 | 1300 | 1301 | 1302 | 1303 | 1304 | 1305 | 1306 | 1307 | 1308 | 1309 | 1310 | 1311 | 1312 | 1313 | 1314 | 1315 | 1316 | 1317 | 1318 | 1319 | 1320 | 1321 | 1322 | 1323 | 1324 | 1325 | 1326 | 1327 | 1328 | 1329 | 1330 | 1331 | 1332 | 1333 | 1334 | 1335 | 1336 | 1337 | 1338 | 1339 | 1340 | 1341 | 1342 | 1343 | 1344 | 1345 | 1346 | 1347 | 1348 | 1349 | 1350 | 1351 | 1352 | 1353 | 1354 | 1355 | 1356 | 1357 | 1358 | 1359 | 1360 | 1361 | 1362 | 1363 | 1364 | 1365 | 1366 | 1367 | 1368 | 1369 | 1370 | 1371 | 1372 | 1373 | 1374 | 1375 | 1376 | 1377 | 1378 | 1379 | 1380 | 1381 | 1382 | 1383 | 1384 | 1385 | 1386 | 1387 | 1388 | 1389 | 1390 | 1391 | 1392 | 1393 | 1394 | 1395 | 1396 | 1397 | 1398 | 1399 | 1400 | 1401 | 1402 | 1403 | 1404 | 1405 | 1406 | 1407 | 1408 | 1409 | 1410 | 1411 | 1412 | 1413 | 1414 | 1415 | 1416 | 1417 | 1418 | 1419 | 1420 | 1421 | 1422 | 1423 | 1424 | 1425 | 1426 | 1427 | 1428 | 1429 | 1430 | 1431 | 1432 | 1433 | 1434 | 1435 | 1436 | 1437 | 1438 | 1439 | 1440 | 1441 | 1442 | 1443 | 1444 | 1445 | 1446 | 1447 | 1448 | 1449 | 1450 | 1451 | 1452 | 1453 | 1454 | 1455 | 1456 | 1457 | 1458 | 1459 | 1460 | 1461 | 1462 | 1463 | 1464 | 1465 | 1466 | 1467 | 1468 | 1469 | 1470 | 1471 | 1472 | 1473 | 1474 | 1475 | 1476 | 1477 | 1478 | 1479 | 1480 | 1481 | 1482 | 1483</ |
|--------|--------|----------|------|---------|------|-------------|-----------|------------|-------------|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|--------|
|--------|--------|----------|------|---------|------|-------------|-----------|------------|-------------|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|--------|

# Inlet Flow Rate Determination

| Client<br>Source<br>Location<br>Date<br>Testers<br>File<br>Analysis/QA<br>Equipment<br>Total Runs<br>Pts per Run | Oregon Steel Mills<br>1 AF Station 2 - 1.71<br>Portland - OR<br>12/16/2000<br>NHE-BEL-1171-08<br>040156<br>NHE-MEAW<br>ShortRidge #2.pilot 14 s<br>2<br>48 | Compartment<br>Point | Pre-test        |           |              |           | Post-Test       |           |              |           |         |
|------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|-----------------|-----------|--------------|-----------|-----------------|-----------|--------------|-----------|---------|
|                                                                                                                  |                                                                                                                                                            |                      | dP (inH2O)      | Ts ( °F ) | dP (inH2O)   | Ts ( °F ) | dP (inH2O)      | Ts ( °F ) | dP (inH2O)   | Ts ( °F ) |         |
|                                                                                                                  |                                                                                                                                                            | 1                    | 2.1240          | 180.0     | 1.2690       | 221.0     | 2.0860          | 199.0     | 1.6300       | 242.0     |         |
|                                                                                                                  |                                                                                                                                                            | 2                    | 1.9740          | 192.0     | 1.1830       | 228.0     | 2.1400          | 173.0     | 1.9800       | 257.0     |         |
|                                                                                                                  |                                                                                                                                                            | 3                    | 2.3680          | 202.0     | 1.2110       | 233.0     | 2.9400          | 162.0     | 2.1200       | 268.0     |         |
|                                                                                                                  |                                                                                                                                                            | 4                    | 2.4180          | 189.0     | 1.3210       | 236.0     | 2.7500          | 156.0     | 2.3700       | 278.0     |         |
|                                                                                                                  |                                                                                                                                                            | 5                    | 2.1980          | 185.0     | 1.2500       | 229.0     | 2.7400          | 153.0     | 2.7600       | 283.0     |         |
|                                                                                                                  |                                                                                                                                                            | 6                    | 2.4560          | 186.0     | 1.4050       | 239.0     | 2.5200          | 150.0     | 2.9400       | 281.0     |         |
|                                                                                                                  |                                                                                                                                                            | 7                    | 2.2460          | 186.0     | 1.7470       | 233.0     | 2.3500          | 146.0     | 2.8800       | 285.0     |         |
|                                                                                                                  |                                                                                                                                                            | 8                    | 2.2350          | 186.0     | 1.8930       | 235.0     | 1.8300          | 146.0     | 2.9900       | 282.0     |         |
|                                                                                                                  |                                                                                                                                                            | 9                    | 2.0960          | 187.0     | 2.1360       | 224.0     | 1.8910          | 145.0     | 3.2100       | 282.0     |         |
|                                                                                                                  |                                                                                                                                                            | 10                   | 2.2890          | 192.0     | 2.4370       | 213.0     | 2.0000          | 144.0     | 2.8700       | 282.0     |         |
|                                                                                                                  |                                                                                                                                                            | 11                   | 1.9930          | 195.0     | 2.3280       | 207.0     | 2.2000          | 142.0     | 2.9600       | 280.0     |         |
|                                                                                                                  |                                                                                                                                                            | 12                   | 1.9650          | 201.0     | 2.6550       | 203.0     | 1.4200          | 140.0     | 2.5300       | 270.0     |         |
|                                                                                                                  |                                                                                                                                                            | 13                   | 2.0150          | 207.0     | 2.6480       | 200.0     | 3.4400          | 130.0     | 1.7000       | 261.0     |         |
|                                                                                                                  |                                                                                                                                                            | 14                   | 1.6710          | 218.0     | 2.4100       | 199.0     | 3.5100          | 124.0     | 1.5500       | 251.0     |         |
|                                                                                                                  |                                                                                                                                                            | 15                   | 1.8190          | 220.0     | 2.6160       | 205.0     | 3.8100          | 121.0     | 1.5300       | 249.0     |         |
|                                                                                                                  |                                                                                                                                                            | 16                   | 2.0070          | 218.0     | 2.5520       | 205.0     | 3.7300          | 120.0     | 1.7900       | 249.0     |         |
|                                                                                                                  |                                                                                                                                                            | 17                   | 2.2190          | 230.0     | 2.3790       | 205.0     | 3.4700          | 118.0     | 1.7600       | 254.0     |         |
|                                                                                                                  |                                                                                                                                                            | 18                   | 2.1190          | 244.0     | 2.6180       | 193.0     | 3.6300          | 117.0     | 2.1900       | 258.0     |         |
|                                                                                                                  |                                                                                                                                                            | 19                   | 2.3890          | 244.0     | 1.9890       | 200.0     | 3.6300          | 115.0     | 1.5500       | 261.0     |         |
|                                                                                                                  |                                                                                                                                                            | 20                   | 2.0880          | 247.0     | 2.2290       | 199.0     | 3.3800          | 115.0     | 2.1000       | 269.0     |         |
|                                                                                                                  |                                                                                                                                                            | 21                   | 2.2360          | 243.0     | 2.3630       | 203.0     | 3.5200          | 114.0     | 2.0600       | 262.0     |         |
|                                                                                                                  |                                                                                                                                                            | 22                   | 2.4180          | 244.0     | 2.5710       | 209.0     | 3.5100          | 114.0     | 2.0300       | 258.0     |         |
|                                                                                                                  |                                                                                                                                                            | 23                   | 2.1160          | 252.0     | 2.4150       | 211.0     | 3.3800          | 114.0     | 2.1800       | 258.0     |         |
|                                                                                                                  |                                                                                                                                                            | 24                   | 1.8980          | 250.0     | 2.2090       | 208.0     | 3.4600          | 114.0     | 1.9000       | 269.0     |         |
| All Points                                                                                                       | SQRT(dP)                                                                                                                                                   |                      | 1.4448 sqrt(dP) |           | 213.3 ( °F ) |           | 1.5846 sqrt(dP) |           | 201.3 ( °F ) |           |         |
| Symbol                                                                                                           | Definitions, Units                                                                                                                                         | Method/Notes         | Pre-test        |           |              |           | Post-Test       |           |              |           | Average |
| As                                                                                                               | Time                                                                                                                                                       |                      | 11:00           |           |              |           | 16:35           |           |              |           |         |
| As                                                                                                               | Cross Section                                                                                                                                              | in²                  | 13.685          |           |              |           | 13.685          |           |              |           |         |
| Cp                                                                                                               | Pitot Coef.                                                                                                                                                |                      | 0.8242          |           |              |           | 0.8242          |           |              |           |         |
| Ts                                                                                                               | Duct temperature                                                                                                                                           | °F                   | 213.3           |           |              |           | 201.3           |           |              |           | 207.3   |
| Ts                                                                                                               | Duct temperature                                                                                                                                           | °R                   | 672.9           |           |              |           | 660.9           |           |              |           |         |
| Phar                                                                                                             | Barometric Pressure                                                                                                                                        | in Hg                | 30.49           |           |              |           | 30.49           |           |              |           |         |
| Pg                                                                                                               | Static Pressure                                                                                                                                            | in H2O               | -7.32           |           |              |           | -7.22           |           |              |           |         |
| Ps                                                                                                               | Duct Pressure                                                                                                                                              | in Hg                | 29.95           |           |              |           | 29.96           |           |              |           |         |
| dp^1/2                                                                                                           |                                                                                                                                                            |                      | 1.4448          |           |              |           | 1.5846          |           |              |           |         |
| Bws                                                                                                              | Moisture, % Stack                                                                                                                                          | (outlet)             | 2.88            |           |              |           | 4.41            |           |              |           | 3.64    |
| mfg                                                                                                              | Mole fraction dry gas                                                                                                                                      |                      | 97.1%           |           |              |           | 95.6%           |           |              |           |         |
| Md (inlet)                                                                                                       | Molecular weight Dry                                                                                                                                       |                      | 29.01           |           |              |           | 29.01           |           |              |           |         |
| Ms (inlet)                                                                                                       | Molecular weight Wet                                                                                                                                       |                      | 28.69           |           |              |           | 28.52           |           |              |           |         |
| vs                                                                                                               | Velocity stack                                                                                                                                             | fpm                  | 5,405           |           |              |           | 5,891           |           |              |           | 5,648   |
| Qa                                                                                                               | Flowrate actual                                                                                                                                            | acft/min             | 513,635         |           |              |           | 559,873         |           |              |           | 536,754 |
| Qsd (inlet)                                                                                                      | Flowrate @std                                                                                                                                              | dscf/min             | 391,573         |           |              |           | 427,802         |           |              |           | 409,688 |
| Qsd(Outlet)                                                                                                      | Flowrate @std                                                                                                                                              | dscf/min             |                 |           |              |           |                 |           |              |           | 458,630 |
|                                                                                                                  | Difference                                                                                                                                                 | (Out-In)/In          |                 |           |              |           |                 |           |              |           | 11.9%   |



13585 N.E. Whitaker Way  
Portland, OR 97230  
Phone (503)255-5050  
Fax (503)255-0505

# VOLUME FLOWRATE MEASUREMENT

Plant OSM  
Sampling Location Baghouse outlet  
Test Conditions 1-1  
Date 2/27/02 Time -  
Duct Dimensions -  
Duct Area - in<sup>2</sup>  
Gauge I.D. 2 in H<sub>2</sub>O By 1/1  
Post Test Leak Check Good


Cyclonic Flow ? Yes No Avg Null Angle -  
P<sub>0</sub> = Barometric Pressure 29.97 in Hg  
C<sub>p</sub> = Pitot Coefficient 0.98  
Pitot I.D. 1/8

| Run #  |        |      |     |        |     |      |        |     |      |        |
|--------|--------|------|-----|--------|-----|------|--------|-----|------|--------|
| Time   | AP     | Temp |     | ΔP     | T   |      | ΔP     | T   | ΔP   |        |
| Pt 1-1 | 0.0399 |      | 5-1 | 0.0004 |     | 1-1  | 0.0059 |     | 13-1 | 0.0445 |
| 2      | 0.0472 |      | 2   | 0.0483 |     | 2    | 0.0447 |     | 2    | 0.0422 |
| 3      | 0.0482 | 140  | 3   | 0.0489 | 102 | 3    | 0.0397 |     | 3    | 0.0382 |
| 4      | 0.0420 |      | 4   | 0.0474 |     | 4    | 0.0562 |     | 4    | 0.0331 |
| 5      | 0.0450 |      | 5   | 0.0422 |     | 5    | 0.0540 |     | 5    | 0.0451 |
| 2-1    | 0.0157 |      | 2-1 | 0.0060 |     | 10-1 | 0.0193 |     | 14-1 | 0.0091 |
| 2      | 0.0115 |      | 2   | 0.0330 |     | 2    | 0.0430 |     | 2    | 0.0350 |
| 3      | 0.0374 | 138  | 3   | 0.0325 | 172 | 3    | 0.0452 | 174 | 3    | 0.0375 |
| 4      | 0.0400 |      | 4   | 0.0345 |     | 4    | 0.0507 |     | 4    | 0.0375 |
| 5      | 0.0325 |      | 5   | 0.0406 |     | 5    | 0.0473 |     | 5    | 0.0317 |
| 7-1    | 0.0012 |      | 7-1 | 0.0101 |     | 11-1 | 0.0336 |     | 15-1 | 0.0105 |
| 2      | 0.0391 |      | 2   | 0.0462 |     | 2    | 0.0223 |     | 2    | 0.0285 |
| 3      | 0.0361 | 165  | 3   | 0.0450 | 160 | 3    | 0.0269 | 164 | 3    | 0.0336 |
| 4      | 0.0341 |      | 4   | 0.0587 |     | 4    | 0.0389 |     | 4    | 0.0391 |
| 5      | 0.0372 |      | 5   | 0.0582 |     | 5    | 0.0397 |     | 5    | 0.0150 |
| 4-1    | 0.0053 |      | 4-1 | 0.0025 |     | 12-1 | 0.0344 |     | 16-1 | 0.0058 |
| 2      | 0.0472 |      | 2   | 0.0113 |     | 2    | 0.0313 |     | 2    | 0.0238 |
| 3      | 0.0436 | 170  | 3   | 0.0133 | 155 | 3    | 0.0363 | 150 | 3    | 0.0257 |
| 4      | 0.0377 |      | 4   | 0.0120 |     | 4    | 0.0348 |     | 4    | 0.0260 |
| 5      | 0.0359 |      | 5   | 0.0143 |     | 5    | 0.0217 |     | 5    | 0.0314 |

Avg ΔP

| Symbol            | Definition, Units                  | Method/Equation                          | Run 1  | Run 2 | Run 3 | Average |
|-------------------|------------------------------------|------------------------------------------|--------|-------|-------|---------|
| T <sub>db</sub>   | Dry bulb temp., °F                 |                                          | 155    |       |       |         |
| T <sub>wb</sub>   | Wet bulb temp., °F                 |                                          | 72     |       |       |         |
| P <sub>stat</sub> | Static press., in H <sub>2</sub> O |                                          | 0.0251 |       |       |         |
| T <sub>s</sub>    | Duct temp., °R                     | T <sub>db</sub> + 460                    |        |       |       |         |
| P <sub>s</sub>    | Duct press., in Hg                 | P <sub>0</sub> ± P <sub>stat</sub> /13.6 |        |       |       |         |
| S                 |                                    | Avg √ΔP × √T <sub>s</sub>                |        |       |       |         |
| mv                | % H <sub>2</sub> O in gas stream   | Psychrometry                             |        |       |       |         |
| md                | Mole fraction dry gas              | 1.00 - mv/100                            |        |       |       |         |
| Md                | Molecular weight of dry gas        | Gas analysis                             |        |       |       |         |
| Ms                | Molecular wt of act. gas           | Ms = mdMd + 18 (1-md)                    |        |       |       |         |
| Vs                | Velocity, fpm                      | Vs = 5125s (1/PsMs) <sup>1/2</sup> (Cp)  |        |       |       |         |
| qa                | Actual flowrate, acfm              | qa = VsAs/144                            |        |       |       |         |
| qs                | Flowrate @ std cond, scfm          | qs = 0.123 VsAs md Ps / Ts               |        |       |       |         |





13585 N.E. Whitaker Way  
Portland, OR 97230  
Phone (503)255-5050  
Fax (503)255-0505

# VOLUME FLOWRATE MEASUREMENT

Plant OSM  
Sampling Location Boothouse  
Test Conditions Normal  
Date 2/27/00 Time —  
Duct Dimensions —  
Duct Area — in<sup>2</sup>  
Gauge I.D. 3A-1 in H<sub>2</sub>O By M. T. E. / P. S. F. / F. H.  
Post Test Leak Check —

Cyclonic Flow ? Yes No Avg Null Angle —  
P<sub>0</sub> = Barometric Pressure 30.4 in Hg  
C<sub>p</sub> = Pitot Coefficient 2.75  
Pitot I.D. 11-5

| Run #  | Time | ΔP     | Temp | ΔP   | Temp   | ΔP   | Temp   | ΔP | Temp |
|--------|------|--------|------|------|--------|------|--------|----|------|
| Pt 1-1 | 1-1  | 0.0312 | 173  | 10-1 | 0.0326 | 14-1 | 0.0335 |    |      |
| 2      | 2    | 0.0334 |      | 2    | 0.0334 | 2    | 0.0334 |    |      |
| 3      | 3    | 0.0322 | 174  | 3    | 0.0322 | 3    | 0.0322 |    |      |
| 4      | 4    | 0.0306 |      | 4    | 0.0306 | 4    | 0.0306 |    |      |
| 5      | 5    | 0.0327 |      | 5    | 0.0327 | 5    | 0.0327 |    |      |
| 7-1    | 7-1  | 0.0298 |      | 11-1 | 0.0668 | 15-1 | 0.0630 |    |      |
| 2      | 2    | 0.0430 |      | 2    | 0.0338 | 2    | 0.0370 |    |      |
| 3      | 3    | 0.0438 | 162  | 3    | 0.0254 | 3    | 0.0111 |    |      |
| 4      | 4    | 0.0410 |      | 4    | 0.0357 | 4    | 0.0079 |    |      |
| 5      | 5    | 0.0413 |      | 5    | 0.0575 | 5    | 0.0011 |    |      |
| 8-1    | 8-1  | 0.0213 |      | 12-1 | 0.0122 | 15-1 | 0.0071 |    |      |
| 2      | 2    | 0.0277 |      | 2    | 0.0398 | 2    | 0.0050 |    |      |
| 3      | 3    | 0.0264 | 169  | 3    | 0.0355 | 3    | 0.0281 |    |      |
| 4      | 4    | 0.0282 |      | 4    | 0.0246 | 4    | 0.0088 |    |      |
| 5      | 5    | 0.0298 |      | 5    | 0.0221 | 5    | 0.0035 |    |      |
| 9-1    | 9-1  | 0.0064 |      | 13-1 | 0.0086 | 17-1 | 0.0654 |    |      |
| 2      | 2    | 0.0367 |      | 2    | 0.0350 | 2    | 0.0674 |    |      |
| 3      | 3    | 0.0377 | 162  | 3    | 0.0344 | 3    | 0.0497 |    |      |
| 4      | 4    | 0.0361 |      | 4    | 0.0450 | 4    | 0.0430 |    |      |
| 5      | 5    | 0.0329 |      | 5    | 0.0566 | 5    | 0.0472 |    |      |

Avg √ΔP

| Symbol            | Definition, Units                  | Method/Equation                          | Run 1  | Run 2 | Run 3 | Average |
|-------------------|------------------------------------|------------------------------------------|--------|-------|-------|---------|
| T <sub>db</sub>   | Dry bulb temp., °F                 |                                          | 164    |       |       |         |
| T <sub>wb</sub>   | Wet bulb temp., °F                 |                                          | 101    |       |       |         |
| P <sub>stat</sub> | Static press., in H <sub>2</sub> O |                                          | 4.0115 |       |       |         |
| T <sub>s</sub>    | Duct temp., °R                     | T <sub>db</sub> + 460                    |        |       |       |         |
| P <sub>s</sub>    | Duct press., in Hg                 | P <sub>0</sub> ± P <sub>stat</sub> /13.6 |        |       |       |         |
| S                 |                                    | Avg √ΔP × √T <sub>s</sub>                |        |       |       |         |
| mv                | % H <sub>2</sub> O in gas stream   | Psychrometry                             |        |       |       |         |
| md                | Mole fraction dry gas              | 1.00 - mv/100                            |        |       |       |         |
| Md                | Molecular weight of dry gas        | Gas analysis                             |        |       |       |         |
| Ms                | Molecular wt of act. gas           | Ms = mdMd + 18 (1-md)                    |        |       |       |         |
| Vs                | Velocity, fpm                      | Vs = 5125s (1/PsMs) <sup>1/2</sup> (Cp)  |        |       |       |         |
| qa                | Actual flowrate, acfm              | qa = VsAs/144                            |        |       |       |         |
| qs                | Flowrate @ std cond, scfm          | qs = 0.123 VsAs md Ps / Ts               |        |       |       |         |



13585 N.E. Whillaker Way  
Portland, OR 97230  
Phone (503)255-5050  
Fax (503)255-0505

# VOLUME FLOWRATE MEASUREMENT

Plant 0:11  
Sampling Location Baghouse  
Test Conditions Normal  
Date 12/27/00 Time         
Duct Dimensions         
Duct Area        in<sup>2</sup>  
Gauge I.D. 3R in H<sub>2</sub>O By B-E/M  
Post Test Leak Check Good

Cyclonic Flow ? Yes    No    Avg Null Angle         
P<sub>0</sub> = Barometric Pressure        in Hg  
C<sub>p</sub> = Pitot Coefficient         
Pitot I.D. 11-5

| Run # | Time   | ΔP  | Temp | ΔP     | Temp | ΔP | Temp   | ΔP  | Temp |        |
|-------|--------|-----|------|--------|------|----|--------|-----|------|--------|
| 1     | 0.0400 | 151 | 2    | 0.0416 | 151  | 3  | 0.0389 | 155 | 4    | 0.0420 |
| 2     | 0.0490 | 151 | 3    | 0.0488 | 151  | 4  | 0.0308 | 155 | 5    | 0.0420 |
| 3     | 0.0435 | 151 | 4    | 0.0295 | 151  | 5  | 0.0235 | 155 | 6    | 0.0420 |
| 4     | 0.0155 | 151 | 5    | 0.0069 | 151  | 6  | 0.0072 | 155 | 7    | 0.0200 |
| 5     | 0.0488 | 151 | 6    | 0.0404 | 151  | 7  | 0.0257 | 155 | 8    | 0.0431 |
| 6     | 0.0339 | 185 | 7    | 0.0397 | 179  | 8  | 0.0145 | 184 | 9    | 0.0461 |
| 7     | 0.0387 | 185 | 8    | 0.0531 | 179  | 9  | 0.0271 | 184 | 10   | 0.0458 |
| 8     | 0.0476 | 185 | 9    | 0.0440 | 179  | 10 | 0.0271 | 184 | 11   | 0.0347 |
| 9     | 0.0175 | 185 | 10   | 0.0165 | 179  | 11 | 0.0120 | 184 | 12   | 0.0030 |
| 10    | 0.0340 | 185 | 11   | 0.0199 | 179  | 12 | 0.0318 | 184 | 13   | 0.0276 |
| 11    | 0.0315 | 191 | 12   | 0.0246 | 169  | 13 | 0.0309 | 186 | 14   | 0.0266 |
| 12    | 0.0334 | 191 | 13   | 0.0323 | 169  | 14 | 0.0255 | 186 | 15   | 0.0349 |
| 13    | 0.0224 | 191 | 14   | 0.0295 | 169  | 15 | 0.0722 | 186 | 16   | 0.0363 |
| 14    | 0.0092 | 191 | 15   | 0.0061 | 169  | 16 | 0.0586 | 186 | 17   | 0.0321 |
| 15    | 0.0486 | 191 | 16   | 0.0361 | 169  | 17 | 0.0524 | 186 | 18   | 0.0301 |
| 16    | 0.0597 | 191 | 17   | 0.0382 | 176  | 18 | 0.0466 | 159 | 19   | 0.0362 |
| 17    | 0.0340 | 191 | 18   | 0.0360 | 176  | 19 | 0.0496 | 159 | 20   | 0.0380 |
| 18    | 0.0458 | 191 | 19   | 0.0442 | 176  | 20 | 0.0431 | 159 | 21   | 0.0382 |

Avg √ΔP

| Symbol            | Definition, Units                  | Method/Equation                          | Run 1  | Run 2 | Run 3 | Average |
|-------------------|------------------------------------|------------------------------------------|--------|-------|-------|---------|
| T <sub>db</sub>   | Dry bulb temp., °F                 |                                          | 150    |       |       |         |
| T <sub>wb</sub>   | Wet bulb temp., °F                 |                                          | 101    |       |       |         |
| P <sub>stat</sub> | Static press., in H <sub>2</sub> O |                                          | 0.0510 |       |       |         |
| T <sub>s</sub>    | Duct temp., °R                     | T <sub>db</sub> + 460                    |        |       |       |         |
| P <sub>s</sub>    | Duct press., in Hg                 | P <sub>0</sub> ± P <sub>stat</sub> /13.6 |        |       |       |         |
| S                 |                                    | Avg √ΔP × √T <sub>s</sub>                |        |       |       |         |
| inv               | % H <sub>2</sub> O in gas stream   | Psychrometry                             |        |       |       |         |
| md                | Mole fraction dry gas              | 1.00 - mv/100                            |        |       |       |         |
| Md                | Molecular weight of dry gas        | Gas analysis                             |        |       |       |         |
| Ms                | Molecular wt of act. gas           | Ms = mdMd + 18 (1-md)                    |        |       |       |         |
| Vs                | Velocity, fpm                      | Vs = 5125s (1/PsMs) <sup>1/2</sup> (Cp)  |        |       |       |         |
| qa                | Actual flowrate, acfm              | qa = VsAs/144                            |        |       |       |         |
| qs                | Flowrate @ std cond, scfm          | qs = 0.123 VsAs md Ps / Ts               |        |       |       |         |





13585 N.E. Whitaker Way  
Portland, OR 97230  
Phone (503)255-5050  
Fax (503)255-0505

# VOLUME FLOWRATE MEASUREMENT

Plant OSM  
Sampling Location Baghouse Inlet  
Test Conditions Normal  
Date 12/27/00 Time \_\_\_\_\_  
Duct Dimensions \_\_\_\_\_  
Duct Area \_\_\_\_\_ in<sup>2</sup>  
Gauge I.D. SR in H<sub>2</sub>O By \_\_\_\_\_  
Post Test Leak Check Good

Cyclonic Flow ? Yes No Avg Null Angle ✓  
P<sub>0</sub> = Barometric Pressure 30.43 in Hg  
C<sub>p</sub> = Pitot Coefficient 0.82413  
Pitot I.D. 7-1

| Run #           | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | 14    | 15    | 16    | 17    | 18    | 19    | 20    | 21    |
|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Time            | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 | 11:00 |
| P <sub>1</sub>  | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 | 21.14 |
| P <sub>2</sub>  | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 | 21.77 |
| P <sub>3</sub>  | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 | 21.36 |
| P <sub>4</sub>  | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 | 21.18 |
| P <sub>5</sub>  | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 | 21.07 |
| P <sub>6</sub>  | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 | 20.95 |
| P <sub>7</sub>  | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 | 20.86 |
| P <sub>8</sub>  | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 | 20.75 |
| P <sub>9</sub>  | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 | 20.61 |
| P <sub>10</sub> | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 | 20.52 |
| P <sub>11</sub> | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 | 20.43 |
| P <sub>12</sub> | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 | 20.32 |
| P <sub>13</sub> | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 | 20.28 |
| P <sub>14</sub> | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 | 20.15 |
| P <sub>15</sub> | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 | 20.07 |
| P <sub>16</sub> | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 | 20.00 |
| P <sub>17</sub> | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 | 19.89 |
| P <sub>18</sub> | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 | 19.77 |
| P <sub>19</sub> | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 | 19.61 |
| P <sub>20</sub> | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 | 19.52 |
| P <sub>21</sub> | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 | 19.43 |

Avg  $\Delta P$

| Symbol            | Definition, Units                  | Method/Equation                                                                            | Run 1 | Run 2 | Run 3 | Average |
|-------------------|------------------------------------|--------------------------------------------------------------------------------------------|-------|-------|-------|---------|
| T <sub>db</sub>   | Dry bulb temp., °F                 |                                                                                            |       |       |       |         |
| T <sub>wb</sub>   | Wet bulb temp., °F                 |                                                                                            |       |       |       |         |
| P <sub>stat</sub> | Static press., in H <sub>2</sub> O |                                                                                            |       |       |       |         |
| T <sub>s</sub>    | Duct temp., °R                     | T <sub>db</sub> + 460                                                                      |       |       |       |         |
| P <sub>s</sub>    | Duct press., in Hg                 | P <sub>0</sub> ± P <sub>stat</sub> /13.6                                                   |       |       |       |         |
| S                 |                                    | Avg $\sqrt{\Delta P} \times \sqrt{T_s}$                                                    |       |       |       |         |
| mv                | % H <sub>2</sub> O                 | Psychrometry                                                                               |       |       |       |         |
| md                | mole fraction dry gas              | 1.00 - mv/100                                                                              |       |       |       |         |
| M                 | molecular weight of dry gas        | Gas analysis                                                                               |       |       |       |         |
| M <sub>s</sub>    | Molecular wt of act. gas           | M <sub>s</sub> = mdM <sub>d</sub> + 18 (1-md)                                              |       |       |       |         |
| V <sub>s</sub>    | Velocity, fpm                      | V <sub>s</sub> = 5125s (1/P <sub>s</sub> M <sub>s</sub> ) <sup>1/2</sup> (C <sub>p</sub> ) |       |       |       |         |
| q <sub>a</sub>    | Actual flow, acfm                  | q <sub>a</sub> = V <sub>s</sub> A <sub>s</sub> /144                                        |       |       |       |         |
| q <sub>s</sub>    | Flowrate, std cond, scfm           | q <sub>s</sub> = 0.123 V <sub>s</sub> A <sub>s</sub> md P <sub>s</sub> / T <sub>s</sub>    |       |       |       |         |



13585 N.E. Whitaker Way  
Portland, OR 97230  
Phone (503)255-5050  
Fax (503)255-0505

# VOLUME FLOWRATE MEASUREMENT

Plant OSM  
Sampling Location Boilerhouse  
Test Conditions NORMAL  
Date 12/2/00 Time 1  
Duct Dimensions             
Duct Area            in<sup>2</sup>  
Gauge I.D. 5R-1 in H<sub>2</sub>O By MT  
Post Test Leak Check Good

Cyclonic Flow ? Yes    No    Avg Null Angle             
P<sub>0</sub> = Barometric Pressure            in Hg  
C<sub>p</sub> = Pitot Coefficient             
Pitot I.D. 14-51

| Run #  | ΔP    | Temp | ΔP    | Temp | ΔP    | Temp |
|--------|-------|------|-------|------|-------|------|
| Pt 1-1 | 2.086 | 199  | 2.086 | 199  | 2.086 | 199  |
| 2      | 2.14  | 170  | 2.14  | 170  | 2.14  | 170  |
| 3      | 2.04  | 172  | 2.04  | 172  | 2.04  | 172  |
| 4      | 2.14  | 170  | 2.14  | 170  | 2.14  | 170  |
| 5      | 2.14  | 170  | 2.14  | 170  | 2.14  | 170  |
| 6      | 2.14  | 170  | 2.14  | 170  | 2.14  | 170  |
| 7      | 2.35  | 146  | 2.35  | 146  | 2.35  | 146  |
| 8      | 1.83  | 146  | 1.83  | 146  | 1.83  | 146  |
| 9      | 1.83  | 145  | 1.83  | 145  | 1.83  | 145  |
| 10     | 2.00  | 144  | 2.00  | 144  | 2.00  | 144  |
| 11     | 2.12  | 142  | 2.12  | 142  | 2.12  | 142  |
| 12     | 1.42  | 140  | 1.42  | 140  | 1.42  | 140  |
| 13     | 3.14  | 130  | 3.14  | 130  | 3.14  | 130  |
| 14     | 3.21  | 124  | 3.21  | 124  | 3.21  | 124  |
| 15     | 3.51  | 121  | 3.51  | 121  | 3.51  | 121  |
| 16     | 3.23  | 120  | 3.23  | 120  | 3.23  | 120  |
| 17     | 3.47  | 118  | 3.47  | 118  | 3.47  | 118  |
| 18     | 3.23  | 117  | 3.23  | 117  | 3.23  | 117  |
| 19     | 3.53  | 115  | 3.53  | 115  | 3.53  | 115  |
| 20     | 3.38  | 115  | 3.38  | 115  | 3.38  | 115  |
| 21     | 3.52  | 114  | 3.52  | 114  | 3.52  | 114  |

Avg ΔP

| Symbol            | Definition, Units                  | Method/Equation                          | Run 1 | Run 2 | Run 3 | Average |
|-------------------|------------------------------------|------------------------------------------|-------|-------|-------|---------|
| T <sub>db</sub>   | Dry bulb temp., °F                 |                                          | 114.4 |       |       |         |
| T <sub>wb</sub>   | Wet bulb temp., °F                 |                                          |       |       |       |         |
| P <sub>stat</sub> | Static press., in H <sub>2</sub> O |                                          | -7.22 |       |       |         |
| T <sub>s</sub>    | Duct temp., °R                     | T <sub>db</sub> + 460                    |       |       |       |         |
| P <sub>s</sub>    | Duct press., in Hg                 | P <sub>0</sub> ± P <sub>stat</sub> /13.6 |       |       |       |         |
| S                 |                                    | Avg √ΔP × √T <sub>s</sub>                |       |       |       |         |
| mv                | % H <sub>2</sub> O in gas stream   | Psychrometry                             |       |       |       |         |
| md                | Mole fraction dry gas              | 1.00 - mv/100                            |       |       |       |         |
| Md                | Molecular weight of dry gas        | Gas analysis                             |       |       |       |         |
| Ms                | Molecular wt of act. gas           | Ms = mdMd + 18 (1-md)                    |       |       |       |         |
| Vs                | Velocity, fpm                      | Vs = 5125s (1/PsMs) <sup>1/2</sup> (Cp)  |       |       |       |         |
| qa                | Actual flowrate, acfm              | qa = VsAs/144                            |       |       |       |         |
| qs                | Flowrate @ std cond, scfm          | qs = 0.123 VsAs md Ps / Ts               |       |       |       |         |

# Traverse Point Location - Outlet

|                             |                       |                        |                            |                         |                            |                              |                              |       |
|-----------------------------|-----------------------|------------------------|----------------------------|-------------------------|----------------------------|------------------------------|------------------------------|-------|
| Client                      | Oregon Steel Mills    |                        |                            | Portland, OR            | Date                       |                              |                              |       |
| Location                    | Portland, OR          |                        |                            | MJE/BTF-TJH C           | By                         |                              |                              |       |
| EPA Method #1               | Outlet                |                        |                            | osm1536                 | File                       |                              |                              |       |
| Number of PORTS             | P                     | #                      | 5                          |                         |                            |                              |                              |       |
| INSIDE of FAR WALL          | F                     | in                     | 52.0                       |                         |                            |                              |                              |       |
| to OUTSIDE of Nipple        |                       |                        |                            |                         |                            |                              |                              |       |
| INSIDE of NEAR WALL         | N                     |                        | 0.00                       |                         |                            |                              |                              |       |
| to OUTSIDE of Nipple        |                       |                        |                            |                         |                            |                              |                              |       |
| Stack/Duct WIDTH            | Dw                    | in                     | 179.0                      |                         |                            |                              |                              |       |
| DOWNstream Disturb          | A                     | in                     |                            |                         |                            |                              |                              |       |
| UPstream Disturb            | B                     | in                     |                            |                         |                            |                              |                              |       |
| Stack/Duct DEPTH            | Dh                    | in                     | 52.0                       |                         |                            |                              |                              |       |
| Equivalent Diameter         | De                    | in                     | 80.6                       |                         |                            |                              |                              |       |
| Area                        | As                    | sqin                   | 9308.0                     |                         |                            |                              |                              |       |
| DOWNstream Ratio            | A/De                  |                        | 0.00                       |                         |                            |                              |                              |       |
| UPstream Ratio              | B/De                  |                        | 0.00                       |                         |                            |                              |                              |       |
| Traverse (Particulate)      |                       |                        | 25                         |                         |                            |                              |                              |       |
| Recommended #Pts/Port       |                       | 5                      | 5                          |                         |                            |                              |                              |       |
| Traverse (NON-Particulate)  |                       |                        | 16                         |                         |                            |                              |                              |       |
| Recommended #Pts/Port       |                       | 3                      | 4                          |                         |                            |                              |                              |       |
| Actual Points used per Port |                       |                        | 5                          |                         |                            |                              |                              |       |
| Actual Number of Points     |                       |                        | 25                         |                         |                            |                              |                              |       |
| Trav<br>Pt<br>#No           | Fract<br>Depth<br>(f) | Stack<br>Depth<br>(Dp) | Actual<br>Points<br>(Dpxf) | Nearest<br>8ths<br>(TP) | Adjusted<br>Points<br>(TP) | Traverse<br>Points<br>(TP+N) | Traverse<br>Points<br>(TP+N) |       |
| 1                           | 10.00%                | 52.0                   | 5.2                        | 5.250                   | 5.250                      | 5.250                        | 5                            | 1 / 4 |
| 2                           | 30.00%                | 52.0                   | 15.6                       | 15.625                  | 15.625                     | 15.625                       | 15                           | 5 / 8 |
| 3                           | 50.00%                | 52.0                   | 26.0                       | 26.000                  | 26.000                     | 26.000                       | 26                           |       |
| 4                           | 70.00%                | 52.0                   | 36.4                       | 36.375                  | 36.375                     | 36.375                       | 36                           | 3 / 8 |
| 5                           | 90.00%                | 52.0                   | 46.8                       | 46.750                  | 46.750                     | 46.750                       | 46                           | 3 / 4 |

# Traverse Point Location - Baghouse Inlet

|               |                    |               |      |
|---------------|--------------------|---------------|------|
| Client        | Oregon Steel Mills | Portland, OR  | Date |
| Location      | Portland, OR       | MJE: BTF-EJEC | By   |
| EPA Method #1 | Baghouse Inlet     | osm1536       | File |

|                                          |             |          |
|------------------------------------------|-------------|----------|
| Outer Circumference                      | (ft) [Co]   | "        |
| Wall thickness                           | (in) [t]    | "        |
| Inner Circumference                      | (ft) [Ci]   | "        |
| INSIDE of FAR WALL to OUTSIDE of Nipple  | (in) [F]    | 134.00 " |
| INSIDE of NEAR WALL to OUTSIDE of Nipple | (in) [N]    | 2.00 "   |
| DOWNStream Disturb                       | (in) [A]    | 128.0 "  |
| UPstream Disturb                         | (in) [B]    | 516.0 "  |
| Inner Diameter                           | (in) [Ds]   | 132.00 " |
| Area                                     | (sqin) [As] | 13,685   |
| DOWNStream Ratio                         | [A/Ds]      | 1.0      |
| UPstream Ratio                           | [B/Ds]      | 3.91     |
| Traverse (Particulate)                   |             | 24       |
| Recommended #Pts/Diameter                |             | 12       |
| Traverse (NON-Particulate)               |             | 16       |
| Recommended #Pts/Diameter                |             | 8        |
| Actual Points per Diameter               |             | 24       |

| Trav Pt #No | Fract Stk ID (f) | Stack ID (Ds) | Actual Points (Dsxf) | Nearest 8ths (TP) | Adjusted Points (TP)* | Traverse Points (TP + N) | Traverse Points (TP + N) |
|-------------|------------------|---------------|----------------------|-------------------|-----------------------|--------------------------|--------------------------|
| 1           | 1.05%            | 132.0         | 1.4                  | 1.375             | 1.375                 | 3.375                    | 3 3 / 8                  |
| 2           | 3.23%            | 132.0         | 4.3                  | 4.250             | 4.250                 | 6.250                    | 6 1 / 4                  |
| 3           | 5.51%            | 132.0         | 7.3                  | 7.250             | 7.250                 | 9.250                    | 9 1 / 4                  |
| 4           | 7.92%            | 132.0         | 10.5                 | 10.500            | 10.500                | 12.500                   | 12 1 / 2                 |
| 5           | 10.47%           | 132.0         | 13.8                 | 13.875            | 13.875                | 15.875                   | 15 7 / 8                 |
| 6           | 13.20%           | 132.0         | 17.4                 | 17.375            | 17.375                | 19.375                   | 19 3 / 8                 |
| 7           | 16.15%           | 132.0         | 21.3                 | 21.375            | 21.375                | 23.375                   | 23 3 / 8                 |
| 8           | 19.38%           | 132.0         | 25.6                 | 25.625            | 25.625                | 27.625                   | 27 5 / 8                 |
| 9           | 23.00%           | 132.0         | 30.4                 | 30.375            | 30.375                | 32.375                   | 32 3 / 8                 |
| 10          | 27.18%           | 132.0         | 35.9                 | 35.875            | 35.875                | 37.875                   | 37 7 / 8                 |
| 11          | 32.32%           | 132.0         | 42.7                 | 42.625            | 42.625                | 44.625                   | 44 5 / 8                 |
| 12          | 39.79%           | 132.0         | 52.5                 | 52.500            | 52.500                | 54.500                   | 54 1 / 2                 |
| 13          | 60.21%           | 132.0         | 79.5                 | 79.500            | 79.500                | 81.500                   | 81 1 / 2                 |
| 14          | 67.68%           | 132.0         | 89.3                 | 89.375            | 89.375                | 91.375                   | 91 3 / 8                 |
| 15          | 72.82%           | 132.0         | 96.1                 | 96.125            | 96.125                | 98.125                   | 98 1 / 8                 |
| 16          | 77.00%           | 132.0         | 101.6                | 101.625           | 101.625               | 103.625                  | 103 5 / 8                |
| 17          | 80.62%           | 132.0         | 106.4                | 106.375           | 106.375               | 108.375                  | 108 3 / 8                |
| 18          | 83.85%           | 132.0         | 110.7                | 110.625           | 110.625               | 112.625                  | 112 5 / 8                |
| 19          | 86.80%           | 132.0         | 114.6                | 114.625           | 114.625               | 116.625                  | 116 5 / 8                |
| 20          | 89.53%           | 132.0         | 118.2                | 118.125           | 118.125               | 120.125                  | 120 1 / 8                |
| 21          | 92.08%           | 132.0         | 121.5                | 121.500           | 121.500               | 123.500                  | 123 1 / 2                |
| 22          | 94.49%           | 132.0         | 124.7                | 124.750           | 124.750               | 126.750                  | 126 3 / 4                |
| 23          | 96.77%           | 132.0         | 127.7                | 127.750           | 127.750               | 129.750                  | 129 3 / 4                |
| 24          | 98.95%           | 132.0         | 130.6                | 130.625           | 130.625               | 132.625                  | 132 5 / 8                |

## **VISIBLE EMISSION DATA**



13565 N.E. Whitaker Way • Portland, OR 97230  
Phone (503) 255-5050 • Fax (503) 255-0505  
horizone@teleport.com

|                           |              |
|---------------------------|--------------|
| <b>SOURCE INFORMATION</b> |              |
| Company Name              | OSM          |
| Address                   | Portland, OR |
| Phone #                   |              |

|                                                  |                  |                |
|--------------------------------------------------|------------------|----------------|
| Source Description                               |                  | ID #           |
| Barnhouse Throat                                 |                  |                |
| Operating Mode/Output Rate                       |                  |                |
| Normal                                           |                  |                |
| Control Equipment                                |                  | Operating Mode |
| Barnhouse                                        |                  | Normal         |
| <b>PLUME INFORMATION</b>                         |                  | @ Start @ End  |
| Emission Point Description                       | BH Throat        |                |
| Height Above Ground                              | ~ 20'            | /              |
| Height Relative to Observer                      | ~ 65'            | /              |
| Distance from Observer                           | ~ 300'           | /              |
| Direction from Observer                          | N                | /              |
| Plume Type: Continuous                           |                  |                |
| Intermittent                                     | /                | /              |
| Fugitive                                         |                  |                |
| Plume Color                                      | none             | /              |
| Water Droplets Present?                          | N/C              | /              |
| Attached Plume?                                  |                  |                |
| Detached Plume?                                  |                  |                |
| Point in the Plume at Which Opacity was Observed | BH Throat        | /              |
| Description of Background                        | Throat BH + Comp | /              |
| Color of Background                              | Blk              | /              |
| Condition of Sky                                 | Cloudy           | /              |
| Wind Speed (0-3)                                 |                  | /              |
| Wind Direction (from)                            | N                | /              |
| Ambient Temperature (°F)                         | 50               | /              |

|                      |                  |
|----------------------|------------------|
| Source Layout Sketch | Draw North Arrow |
|                      |                  |
| Comments             |                  |
|                      |                  |
|                      |                  |

|                                          |          |             |               |
|------------------------------------------|----------|-------------|---------------|
| <b>VISIBLE EMISSION OBSERVATION FORM</b> |          |             |               |
| <b>OBSERVATION RECORD</b>                |          |             |               |
| DATE                                     | 12/27/00 | TIME: Start | 1203 End 1510 |

| Seconds |   |    |    |    | Time / Comments |
|---------|---|----|----|----|-----------------|
| MIN     | 0 | 15 | 30 | 45 |                 |
| 1       |   |    |    |    | 1203            |
| 2       |   |    |    |    | R1              |
| 3       |   |    |    |    |                 |
| 4       |   |    |    |    |                 |
| 5       |   |    |    |    |                 |
| 6       |   |    |    |    |                 |
| 7       |   |    |    |    | 1209            |
| 8       |   |    |    |    |                 |
| 9       |   |    |    |    | 1340            |
| 10      |   |    |    |    |                 |
| 11      |   |    |    |    |                 |
| 12      |   |    |    |    | R2              |
| 13      |   |    |    |    |                 |
| 14      |   |    |    |    |                 |
| 15      |   |    |    |    |                 |
| 16      |   |    |    |    | 1346            |
| 17      |   |    |    |    |                 |
| 18      |   |    |    |    | 1504            |
| 19      |   |    |    |    |                 |
| 20      |   |    |    |    | R3              |
| 21      |   |    |    |    |                 |
| 22      |   |    |    |    |                 |
| 23      |   |    |    |    |                 |
| 24      |   |    |    |    | 1510            |
| 25      |   |    |    |    |                 |
| 26      |   |    |    |    |                 |
| 27      |   |    |    |    |                 |
| 28      |   |    |    |    |                 |
| 29      |   |    |    |    |                 |
| 30      |   |    |    |    |                 |
| 31      |   |    |    |    |                 |
| 32      |   |    |    |    |                 |
| 33      |   |    |    |    |                 |
| 34      |   |    |    |    |                 |
| 35      |   |    |    |    |                 |

|                                                      |                   |
|------------------------------------------------------|-------------------|
| Observer's Name (print)                              | Certification No. |
| Daniel Beaudin                                       | 279               |
| Organization:                                        |                   |
| Horizon Engineering, Portland, Oregon (503) 255-5050 |                   |

|                       |          |
|-----------------------|----------|
| Certified By:         | Date:    |
| Oregon DEQ            |          |
| Observer's Signature: | Date:    |
| [Signature]           | 12/27/00 |

## **GASEOUS EMISSIONS**

Emissions Determination

Molecular Weight Determinations

Analyzer Calibration Data and Bias Checks

Data Logger Gas Charts

Strip Charts

# Gaseous Emissions

|                                                        |                        |                 |         |         |         |             |
|--------------------------------------------------------|------------------------|-----------------|---------|---------|---------|-------------|
| Client                                                 | Oregon Steel Mills     | MJE/BTF/TJH/CDB |         |         |         | Testers     |
| Source                                                 | ICA Baghouse-EAF Inlet | osm1536         |         |         |         | File        |
| Location                                               | Portland, OR           | MJE/MEW         |         |         |         | Analysis/QA |
| Date                                                   | 27-Dec-2000            |                 |         |         |         |             |
| Number of Completed Runs                               |                        | Combined        | Run 1   | Run 2   | Run 3   | Average     |
| Date Tested                                            |                        |                 |         |         |         |             |
| System Calibration Time - Initial                      | Tci                    | 11:10           | 11:10   | 11:10   | 11:10   |             |
| Test Time-Starting                                     | Tts                    | 12:00           | 12:00   | 12:23   | 12:00   |             |
| Test Time-Ending                                       | Tte                    | 16:42           | 13:16   | 14:56   | 16:29   |             |
| System Calibration Time - Final                        | Tcf                    | 16:43           | 16:43   | 16:43   | 16:43   |             |
| Test Mid-point Time                                    | Tx                     | 14:21           | 12:38   | 14:09   | 15:44   |             |
| Volumetric Flowrate, Dry Standard                      | dscf/min Qsd           | 409.688         | 409.688 | 409.688 | 409.688 |             |
| Production                                             | Tons/hr                | 141.0           | 165.6   | 123.8   | 138.8   | 142.8       |
| Oxygen                                                 | % O2                   | 20.46           | 20.52   | 20.39   | 20.40   |             |
| Carbon Dioxide                                         | % CO2                  | 0.43            | 0.43    | 0.37    | 0.49    |             |
| <b>Carbon Monoxide</b>                                 | CO Span                | 1.000           | 1.000   | 1.000   | 1.000   |             |
| Indicated average - Dry                                | ppmv Cid               | 91.7            | 125.0   | 75.1    | 96.1    | 98.7        |
| Cylinder Value - High Range calibration gas            | ppmv Cma               | 898.0           | 898.0   | 898.0   | 898.0   |             |
| Cylinder Value - Low Range (Zero) calibration gas      | ppmv Coa               | 0.0             | 0.0     | 0.0     | 0.0     |             |
| System Calibration Response - High Range gas - Initial | ppmv Cmi               | 898.0           | 898.0   | 898.0   | 898.0   |             |
| System Calibration Response - Low Range gas - Initial  | ppmv Coi               | -0.3            | -0.3    | -0.3    | -0.3    |             |
| System Calibration Response - Low Range gas - Final    | ppmv Cof               | -0.3            | -0.3    | -0.3    | -0.3    |             |
| System Calibration Response - High Range gas - Final   | ppmv Cmf               | 887.1           | 887.1   | 887.1   | 887.1   |             |
| Actual average - Dry (Corrected for Drift)             | ppmv-CO Cgas           | 92.6            | 125.6   | 75.8    | 97.3    | 99.6        |
| Mass Emissions                                         | lbm / hr Mgas          | 165.5           | 224.5   | 135.5   | 173.9   | 178.0       |
| Mass Emissions on Production Basis                     | lbm/Ton                | 1.174           | 1.355   | 1.094   | 1.253   | 1.234       |
| <b>Nitrogen Oxides</b>                                 | NOx Span               | 250             | 250     | 250     | 250     |             |
| Indicated average-Dry                                  | ppmv Cid               | 8.77            | 7.59    | 8.43    | 11.01   | 9.01        |
| Cylinder Value - High Range calibration gas            | ppmv Cma               | 90.30           | 90.30   | 90.30   | 90.30   |             |
| Cylinder Value - Low Range (Zero) calibration gas      | ppmv Coa               | 0.00            | 0.00    | 0.00    | 0.00    |             |
| System Calibration Response - High Range gas - Initial | ppmv Cmi               | 87.50           | 87.50   | 87.50   | 87.50   |             |
| System Calibration Response - Low Range gas - Initial  | ppmv Coi               | 0.30            | 0.30    | 0.30    | 0.30    |             |
| System Calibration Response - Low Range gas - Final    | ppmv Cof               | 0.10            | 0.10    | 0.10    | 0.10    |             |
| System Calibration Response - High Range gas - Final   | ppmv Cmf               | 87.50           | 87.50   | 87.50   | 87.50   |             |
| Actual average - Dry (Corrected for Drift)             | ppmv-NO2 Cgas          | 8.88            | 7.60    | 8.52    | 11.24   | 9.12        |
| Mass Emissions                                         | lbm-NO2 / hr Mgas      | 26.06           | 22.30   | 25.01   | 32.99   | 26.77       |
| Mass Emissions on Production Basis                     | lbm/Ton                | 0.185           | 0.135   | 0.202   | 0.238   | 0.191       |
| <b>Sulfur Dioxide</b>                                  | SO2 Span               | 30              | 30      | 30      | 30      |             |
| Indicated average-Dry                                  | ppmv Cid               | 4.31            | 5.24    | 3.92    | 4.23    | 4.46        |
| Cylinder Value - High Range calibration gas            | ppmv Sc                | 26.40           | 26.40   | 26.40   | 26.40   |             |
| Cylinder Value - Low Range (Zero) calibration gas      | ppmv Coa               | 0.00            | 0.00    | 0.00    | 0.00    |             |
| System Calibration Response - High Range gas - Initial | ppmv Sbs               | 29.32           | 29.32   | 29.32   | 29.32   |             |
| System Calibration Response - Low Range gas - Initial  | ppmv Zbs               | 0.56            | 0.56    | 0.56    | 0.56    |             |
| System Calibration Response - Low Range gas - Final    | ppmv Zbe               | 1.34            | 1.34    | 1.34    | 1.34    |             |
| System Calibration Response - High Range gas - Final   | ppmv Sbe               | 29.85           | 29.85   | 29.85   | 29.85   |             |
| Actual average - Dry (Corrected for Drift)             | ppmv-SO2 Cgas          | 3.05            | 4.12    | 2.71    | 2.80    | 3.21        |
| Mass Emissions                                         | lbm-SO2 / hr Mgas      | 12.45           | 16.82   | 11.08   | 11.44   | 13.11       |
| Mass Emissions on Production Basis                     | lbm/Ton                | 0.088           | 0.102   | 0.089   | 0.082   | 0.091       |

# TGOC Emissions

|                                                        |                        |                 |         |             |         |         |
|--------------------------------------------------------|------------------------|-----------------|---------|-------------|---------|---------|
| Client                                                 | Oregon Steel Mills     | MJE/BTF/TJH/CDB |         | Testers     |         |         |
| Source                                                 | ICA Baghouse-EAF Inlet | osm1536         |         | File        |         |         |
| Location                                               | Portland, OR           | MJE/MEW         |         | Analysis/QA |         |         |
| Date                                                   | 27-Dec-2000            |                 |         |             |         |         |
| Number of Completed Runs                               |                        | Combined        | Run 1   | Run 2       | Run 3   | Average |
| Date Tested                                            |                        |                 |         |             |         |         |
| System Calibration Time - Initial                      | Tci                    | 11:10           | 11:10   | 11:10       | 11:10   |         |
| Test Time-Starting                                     | Tts                    | 12:00           | 12:00   | 13:23       | 15:00   |         |
| Test Time-Ending                                       | Tte                    | 16:42           | 13:16   | 14:56       | 16:29   |         |
| System Calibration Time - Final                        | Tcf                    | 16:43           | 16:43   | 16:43       | 16:43   |         |
| Test Mid-point Time                                    | Tx                     | 14:21           | 12:38   | 14:09       | 15:44   |         |
| Volumetric Flowrate, Dry Standard                      | dscf/min Qsd           | 409.688         | 409.688 | 409.688     | 409.688 |         |
| Production                                             | Tons/hr                | 141.0           | 165.6   | 123.8       | 138.8   | 142.8   |
| Oxygen                                                 | % O2                   | 20.46           | 20.52   | 20.39       | 20.40   |         |
| Carbon Dioxide                                         | % CO2                  | 0.43            | 0.37    | 0.49        | 0.47    |         |
| Moisture, Mole Fraction dry Gas                        | mfg                    | 96.36%          | 96.36%  | 96.36%      | 96.36%  |         |
| Total Gaseous Organic Concentration (TGOC) Span        |                        | 100             | 100     | 100         | 100     |         |
| Span Gas- Instrument Response Factor                   | JUM Factor C3H8        | 1.00            | 1.00    | 1.00        | 1.00    |         |
| Span Gas- Carbon Count Equivalent                      | K                      | 3               |         |             |         |         |
| Cylinder Value - High Range calibration gas            | ppmv                   | 27.79           | 27.79   | 27.79       | 27.79   |         |
| Cylinder Value - Low Range (Zero) calibration gas      | ppmv Coa               | 0.00            | 0.00    | 0.00        | 0.00    |         |
| Indicated average- Wet                                 | ppmv-C3H8 Ciw          | 2.93            | 4.83    | 2.74        | 1.79    | 3.12    |
| Span Gas Concentration- Equivalent                     | ppmv Sc                | 27.79           | 27.79   | 27.79       | 27.79   |         |
| Zero Gas Concentration- Equivalent                     | ppmv Zc                | 0.00            | 0.00    | 0.00        | 0.00    |         |
| System Calibration Response - High Range gas - Initial | ppmv Ss                | 28.18           | 28.18   | 28.18       | 28.18   |         |
| System Calibration Response - Low Range gas - Initial  | ppmv Zs                | -0.37           | -0.37   | -0.37       | -0.37   |         |
| System Calibration Response - Low Range gas - Final    | ppmv Ze                | -0.67           | -0.67   | -0.67       | -0.67   |         |
| System Calibration Response - High Range gas - Final   | ppmv Se                | 26.55           | 26.55   | 26.55       | 26.55   |         |
| Actual average - Wet (Corrected for Drift & Response)  | ppmv-C3H8              | 3.47            | 5.20    | 3.27        | 2.44    | 3.64    |
| Actual average - Dry (Corrected for Drift & Response)  | ppmv-C3H8              | 3.60            | 5.40    | 3.39        | 2.53    | 3.77    |
| Actual average - Dry                                   | ppmv-C Cgas            | 10.81           | 16.20   | 10.17       | 7.59    | 11.32   |
| Mass Emissions                                         | lbm / hr               | 8.28            | 12.41   | 7.79        | 5.81    | 8.67    |
| Mass Emissions on Production Basis                     | lbm/Ton                | 0.059           | 0.075   | 0.063       | 0.042   | 0.060   |

# Molecular Weight Determination

|                                                       |                       |      |                 |         |             |         |       |
|-------------------------------------------------------|-----------------------|------|-----------------|---------|-------------|---------|-------|
| Client                                                | Oregon Steel Mills    |      | MJE/BTF/TJH/CDB |         | Testers     |         |       |
| Source                                                | ICA Baghouse-EAF Inle |      | osm1536         |         | File        |         |       |
| Location                                              | Portland, OR          |      | MJE/MEW         |         | Analysis/QA |         |       |
| Date                                                  | 27-Dec-2000           |      |                 |         |             |         |       |
|                                                       |                       |      | Combined        | Run 1   | Run 2       | Run 3   | Avg   |
| System Calibration Time - Initial                     | Tci                   |      | 11:10           | 11:10   | 11:10       | 11:10   |       |
| Test Time-Starting (Hivol Interval)                   | Tts                   |      | 12:00           | 12:00   | 13:23       | 15:00   |       |
| Test Time-Ending (Hivol Interval)                     | Tte                   |      | 16:42           | 13:16   | 14:56       | 16:29   |       |
| System Calibration Time - Final                       | Tcf                   |      | 16:43           | 16:43   | 16:43       | 16:43   |       |
| Test Mid-point Time                                   | Tx                    |      | 14:21           | 12:38   | 14:09       | 15:44   |       |
| Volumetric Flowrate, Dry Standard - Inlet Average     | dscf/min              | Qsd  | 409,688         | 409,688 | 409,688     | 409,688 |       |
| Production Rate                                       | Ton/hr                |      | 141.04          | 165.65  | 123.82      | 138.82  |       |
| Molecular weight, Dry Stack                           | lbm/lb-mole           | Md   | 29.01           | 29.00   | 29.02       | 29.01   |       |
| Oxygen-Inlet                                          | O2                    | Span | 25              | 25      | 25          | 25      |       |
| Indicated average - Dry                               | %                     | Cid  | 20.62           | 20.67   | 20.55       | 20.57   | 20.60 |
| Cylinder Value - High Range calibration gas           | %                     | Cma  | 11.61           | 11.61   | 11.61       | 11.61   |       |
| Cylinder Value - Low Range (Zero) calibration gas     | %                     | Coa  | 0.00            | 0.00    | 0.00        | 0.00    |       |
| System Calibration Response - High Range gas - Initia | %                     | Cmi  | 11.70           | 11.70   | 11.70       | 11.70   |       |
| System Calibration Response - Low Range gas - Initia  | %                     | Coi  | 0.02            | 0.02    | 0.02        | 0.02    |       |
| System Calibration Response - Low Range gas - Final   | %                     | Cof  | 0.04            | 0.04    | 0.04        | 0.04    |       |
| System Calibration Response - High Range gas - Final  | %                     | Cmf  | 11.73           | 11.73   | 11.73       | 11.73   |       |
| Actual average - Dry (Corrected for Drift)            | %                     | Cgas | 20.46           | 20.52   | 20.39       | 20.40   | 20.43 |
| Carbon Dioxide-Inlet                                  | CO2                   | Span | 25              | 25      | 25          | 25      |       |
| Indicated average - Dry                               | %                     | Cid  | 0.40            | 0.36    | 0.46        | 0.43    | 0.42  |
| Cylinder Value - High Range calibration gas           | %                     | Cma  | 12.52           | 12.52   | 12.52       | 12.52   |       |
| Cylinder Value - Low Range (Zero) calibration gas     | %                     | Coa  | 0.00            | 0.00    | 0.00        | 0.00    |       |
| System Calibration Response - High Range gas - Initia | %                     | Cmi  | 12.52           | 12.52   | 12.52       | 12.52   |       |
| System Calibration Response - Low Range gas - Initia  | %                     | Coi  | 0.00            | 0.00    | 0.00        | 0.00    |       |
| System Calibration Response - Low Range gas - Final   | %                     | Cof  | -0.05           | -0.05   | -0.05       | -0.05   |       |
| System Calibration Response - High Range gas - Final  | %                     | Cmf  | 12.42           | 12.42   | 12.42       | 12.42   |       |
| Actual average - Dry (Corrected for Drift)            | %                     | Cgas | 0.430           | 0.374   | 0.488       | 0.473   | 0.445 |



13585 NE Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizon@telecom.com

# Calibration Field Record

Client OSM  
Date 12/27/00  
Source BH In 102

Tester CTD  
Observer \_\_\_\_\_  
Data Logger ID K-1414

| Leak Checks<br>Pre-OK _____<br>Post-OK _____<br>Response Time <u>6 sec</u>                                                                                                                                                                                                                                                                                | Valve<br>Position  | Cylinder<br>#  | Span<br>Gas                   | Cylinder<br>Value<br>(CV) | Analyzer<br>Calibration<br>Response<br>(ACR) | Start Run <u>1</u><br>System<br>Calibration<br>Response<br>(SCR) | End Run <u>3</u><br>System<br>Calibration<br>Response<br>(SCR) | End Run _____<br>System<br>Calibration<br>Response<br>(SCR) | End Run _____<br>System<br>Calibration<br>Response<br>(SCR) |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------|----------------|-------------------------------|---------------------------|----------------------------------------------|------------------------------------------------------------------|----------------------------------------------------------------|-------------------------------------------------------------|-------------------------------------------------------------|-------|-------------------|--|----------------------------|-----------------|--------------|----------------------|-------------------|---|--------------------|--------------------|---|
| <b>CO2 %</b>                                                                                                                                                                                                                                                                                                                                              |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| ch <u>2</u>                                                                                                                                                                                                                                                                                                                                               |                    | <u>35</u>      | CO2                           | <u>21.86</u>              | <u>21.75</u>                                 | <u>21.65</u>                                                     | <u>21.51</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Range <u>0-25%</u>                                                                                                                                                                                                                                                                                                                                        |                    | <u>22</u>      | CO2                           | <u>12.52</u>              | <u>12.49</u>                                 | <u>12.52</u>                                                     | <u>12.42</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Model <u>400</u>                                                                                                                                                                                                                                                                                                                                 |                    | <u>26</u>      | N2                            | <u>0.0</u>                | <u>-0.01</u>                                 | <u>0.0</u>                                                       | <u>-0.05</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer SN: <u>1</u>                                                                                                                                                                                                                                                                                                                                     |                    | <u>CC-7C1</u>  |                               | <u>49.8</u>               | <u>49.6</u>                                  | <u>51.1</u>                                                      | <u>49.1</u>                                                    |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| <b>CO ppm</b>                                                                                                                                                                                                                                                                                                                                             |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| ch <u>3</u>                                                                                                                                                                                                                                                                                                                                               |                    | <u>35</u>      | CO                            | <u>898</u>                | <u>891.3</u>                                 | <u>898.0</u>                                                     | <u>887.1</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Range <u>0-1000</u>                                                                                                                                                                                                                                                                                                                                       |                    | <u>22</u>      | CO                            | <u>508</u>                | <u>500.9</u>                                 | <u>504.8</u>                                                     | <u>502.8</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Model <u>43</u>                                                                                                                                                                                                                                                                                                                                  |                    | <u>26</u>      | N2                            | <u>0.0</u>                | <u>0.1</u>                                   | <u>-0.3</u>                                                      | <u>-0.3</u>                                                    |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer SN: <u>10</u>                                                                                                                                                                                                                                                                                                                                    |                    | <u>CC-7C2</u>  |                               | <u>84.9</u>               | <u>87.6</u>                                  | <u>87.4</u>                                                      | <u>86.8</u>                                                    |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| <b>O2 %</b>                                                                                                                                                                                                                                                                                                                                               |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| ch <u>1</u>                                                                                                                                                                                                                                                                                                                                               |                    | <u>A1</u>      | O2                            | <u>20.95</u>              | <u>20.98</u>                                 |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Range <u>0-25%</u>                                                                                                                                                                                                                                                                                                                                        |                    | <u>0-2</u>     | O2                            | <u>11.61</u>              | <u>11.85</u>                                 | <u>11.70</u>                                                     | <u>11.73</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Model <u>1400</u>                                                                                                                                                                                                                                                                                                                                |                    | <u>26</u>      | N2                            | <u>0.0</u>                | <u>0.02</u>                                  | <u>0.02</u>                                                      | <u>0.04</u>                                                    |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer SN: <u>1</u>                                                                                                                                                                                                                                                                                                                                     |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| <b>NOx ppm</b>                                                                                                                                                                                                                                                                                                                                            |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| ch <u>4</u>                                                                                                                                                                                                                                                                                                                                               |                    | <u>35</u>      | NOx                           | <u>183</u>                | <u>183.3</u>                                 | <u>180.3</u>                                                     | <u>177.8</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Range <u>0-250</u>                                                                                                                                                                                                                                                                                                                                        |                    | <u>22</u>      | NOx                           | <u>90.3</u>               | <u>88.3</u>                                  | <u>87.5</u>                                                      | <u>87.5</u>                                                    |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Model <u>475</u>                                                                                                                                                                                                                                                                                                                                 |                    | <u>26</u>      | N2                            | <u>0.0</u>                | <u>0.3</u>                                   | <u>0.3</u>                                                       | <u>0.1</u>                                                     |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer SN: <u>3</u>                                                                                                                                                                                                                                                                                                                                     |                    | <u>502-751</u> |                               | <u>45</u>                 | <u>46.2</u>                                  | <u>45.36</u>                                                     | <u>45.49</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| <b>THC ppm</b>                                                                                                                                                                                                                                                                                                                                            |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| ch <u>6</u>                                                                                                                                                                                                                                                                                                                                               |                    | <u>R9</u>      |                               | <u>26.4</u>               | <u>28.29</u>                                 | <u>29.33</u>                                                     | <u>29.85</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Range <u>0-30</u>                                                                                                                                                                                                                                                                                                                                         |                    | <u>R14</u>     |                               | <u>9.39</u>               | <u>9.26</u>                                  | <u>10.94</u>                                                     | <u>11.56</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Model <u>721M</u>                                                                                                                                                                                                                                                                                                                                |                    | <u>26</u>      |                               | <u>0.0</u>                | <u>0.12</u>                                  | <u>0.56</u>                                                      | <u>1.34</u>                                                    |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer SN: _____                                                                                                                                                                                                                                                                                                                                        |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| <b>HC ppm</b>                                                                                                                                                                                                                                                                                                                                             |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| ch <u>5</u>                                                                                                                                                                                                                                                                                                                                               |                    | <u>35</u>      | C <sub>3</sub> H <sub>8</sub> | <u>86.5</u>               | <u>86.5</u>                                  | <u>88.23</u>                                                     | <u>91.56</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Range <u>0-100</u>                                                                                                                                                                                                                                                                                                                                        |                    | <u>22</u>      | "                             | <u>49.5</u>               | <u>49.5</u>                                  | <u>45.07</u>                                                     | <u>45.32</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Model <u>VE7</u>                                                                                                                                                                                                                                                                                                                                 |                    | <u>15</u>      | "                             | <u>27.79</u>              | <u>27.79</u>                                 | <u>28.18</u>                                                     | <u>26.55</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer SN: <u>2</u>                                                                                                                                                                                                                                                                                                                                     |                    | <u>A3</u>      | "                             | <u>0.0</u>                | <u>0.0</u>                                   | <u>-0.37</u>                                                     | <u>-0.67</u>                                                   |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| <table border="0"> <tr> <td>Check</td> <td colspan="2">Performance Specs</td> </tr> <tr> <td>Analyzer Calibration Error</td> <td>  ACR-CV   / SPAN</td> <td>2 (25A @ 5%)</td> </tr> <tr> <td>Sampling System Bias</td> <td>(SRCx-ACR) / SPAN</td> <td>5</td> </tr> <tr> <td>Zero and Cal Drift</td> <td>(SRC2-SRC1) / SPAN</td> <td>3</td> </tr> </table> |                    |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             | Check | Performance Specs |  | Analyzer Calibration Error | ACR-CV   / SPAN | 2 (25A @ 5%) | Sampling System Bias | (SRCx-ACR) / SPAN | 5 | Zero and Cal Drift | (SRC2-SRC1) / SPAN | 3 |
| Check                                                                                                                                                                                                                                                                                                                                                     | Performance Specs  |                |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Analyzer Calibration Error                                                                                                                                                                                                                                                                                                                                | ACR-CV   / SPAN    | 2 (25A @ 5%)   |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Sampling System Bias                                                                                                                                                                                                                                                                                                                                      | (SRCx-ACR) / SPAN  | 5              |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |
| Zero and Cal Drift                                                                                                                                                                                                                                                                                                                                        | (SRC2-SRC1) / SPAN | 3              |                               |                           |                                              |                                                                  |                                                                |                                                             |                                                             |       |                   |  |                            |                 |              |                      |                   |   |                    |                    |   |

Test Times  
Run 1  
Start Time 1200  
End Time 1642  
Run 2  
Run 3

Horizon Engineering, 13585 NE Whitaker Way, Portland, OR, 97230 Tel. 255-5050

★ Didn't start Gas until 1200 lost Cal Gas


# Bias Check

| Oregon Steel Mills<br>EAF Baghouse<br>27-December-2000 |            | Span | Cylinder<br>Value<br>CV | Analyzer<br>Calibration<br>Response<br>ACR | Initial<br>System<br>Calibration<br>Response<br>SCRi | Final<br>System<br>Calibration<br>Response<br>SCRf | Cylinder<br>Value<br>Percent<br>of<br>Span | Difference<br>< 2% | Initial<br>System<br>Calibration<br>Bias<br>< 5% | Final<br>System<br>Calibration<br>Bias<br>< 5% | Drift<br>< 3% |
|--------------------------------------------------------|------------|------|-------------------------|--------------------------------------------|------------------------------------------------------|----------------------------------------------------|--------------------------------------------|--------------------|--------------------------------------------------|------------------------------------------------|---------------|
| OXYGEN                                                 |            |      |                         |                                            |                                                      |                                                    |                                            |                    |                                                  |                                                |               |
| Run 1-3                                                | High Range | 25   | 20.95                   | 20.98                                      |                                                      |                                                    | 84%                                        | 0%                 |                                                  |                                                | 0%            |
|                                                        | Mid-Range  | 25   | 11.61                   | 11.85                                      | 11.70                                                | 11.73                                              | 46%                                        | 1%                 | 1%                                               | 0%                                             | 0%            |
|                                                        | Zero       | 25   | 0.00                    | 0.02                                       | 0.02                                                 | 0.04                                               | 0%                                         | 0%                 | 0%                                               | 0%                                             | 0%            |
| CARBON DIOXIDE                                         |            |      |                         |                                            |                                                      |                                                    |                                            |                    |                                                  |                                                |               |
| Run 1-3                                                | High Range | 25   | 21.86                   | 21.75                                      | 21.65                                                | 21.51                                              | 87%                                        | 0%                 |                                                  |                                                |               |
|                                                        | Mid-Range  | 25   | 49.80                   | 49.60                                      | 51.10                                                | 49.10                                              | 199%                                       | 1%                 | 6%                                               | 2%                                             | 8%            |
|                                                        | Mid-Range  | 25   | 12.52                   | 12.49                                      | 12.52                                                | 12.42                                              | 50%                                        | 0%                 | 0%                                               | 0%                                             | 0%            |
|                                                        | Zero       | 25   | 0.00                    | -0.01                                      | 0.00                                                 | -0.05                                              | 0%                                         | 0%                 | 0%                                               | 0%                                             | 0%            |
| CARBON MONOXIDE                                        |            |      |                         |                                            |                                                      |                                                    |                                            |                    |                                                  |                                                |               |
| Run 1-3                                                | High Range | 1000 | 898.00                  | 891.30                                     | 898.00                                               | 887.10                                             | 90%                                        | 1%                 |                                                  |                                                |               |
|                                                        | Mid-Range  | 1000 | 508.00                  | 500.90                                     | 504.80                                               | 502.80                                             | 51%                                        | 1%                 | 0%                                               | 0%                                             | 0%            |
|                                                        | Mid-Range  | 1000 | 84.90                   | 87.60                                      | 87.40                                                | 86.80                                              | 8%                                         | 0%                 | 0%                                               | 0%                                             | 0%            |
|                                                        | Zero       | 1000 | 0.00                    | 0.10                                       | -0.30                                                | -0.30                                              | 0%                                         | 0%                 | 0%                                               | 0%                                             | 0%            |
| NITROGEN OXIDES                                        |            |      |                         |                                            |                                                      |                                                    |                                            |                    |                                                  |                                                |               |
| Run 1                                                  | High Range | 250  | 183.00                  | 183.30                                     | 180.30                                               | 177.80                                             | 73%                                        | 0%                 | 1%                                               | 2%                                             | 1%            |
|                                                        | Mid-Range  | 250  | 90.30                   | 88.30                                      | 87.50                                                | 87.50                                              | 36%                                        | 1%                 | 0%                                               | 0%                                             | 0%            |
|                                                        | Mid-Range  | 250  | 45.00                   | 46.20                                      | 45.36                                                | 45.49                                              | 18%                                        | 0%                 | 0%                                               | 0%                                             | 0%            |
|                                                        | Zero       | 250  | 0.00                    | 0.30                                       | 0.30                                                 | 0.10                                               | 0%                                         | 0%                 | 0%                                               | 0%                                             | 0%            |
| SULFUR DIOXIDE                                         |            |      |                         |                                            |                                                      |                                                    |                                            |                    |                                                  |                                                |               |
| Run 1                                                  | High Range | 30   | 26.40                   | 28.29                                      | 29.22                                                | 29.85                                              | 88%                                        | 6%                 | 3%                                               | 5%                                             | 2%            |
|                                                        | Mid-Range  | 30   | 9.39                    | 9.86                                       | 10.94                                                | 11.56                                              | 31%                                        | 2%                 | 4%                                               | 6%                                             | 2%            |
|                                                        | Zero       | 30   | 0.00                    | 0.12                                       | 0.56                                                 | 1.34                                               | 0%                                         | 0%                 | 1%                                               | 4%                                             | 3%            |
| TOTAL GASEOUS ORGANIC CONCENTRATION                    |            |      |                         |                                            |                                                      |                                                    |                                            |                    |                                                  |                                                |               |
| Run 1                                                  | High Range | C3H8 | 100                     | 86.50                                      | 88.23                                                | 91.56                                              | 87%                                        |                    |                                                  |                                                | 3%            |
|                                                        | Mid-#1     | CH4  | 100                     | 49.50                                      | 45.07                                                | 45.38                                              | 50%                                        |                    |                                                  |                                                | 0%            |
|                                                        | Mid-#2     | CH4  | 100                     | 27.79                                      | 28.18                                                | 26.55                                              | 28%                                        |                    |                                                  |                                                | 2%            |
|                                                        | Zero       | N2   | 100                     | 0.00                                       | -0.37                                                | -0.67                                              | 0%                                         |                    |                                                  |                                                | 0%            |

Part 60, Appendix A, Method 6C, Figures 6C-3 to 6C-5


# Oregon Steel Mills

EAF Baghouse




# Oregon Steel Mills

## EAF Baghouse




# Oregon Steel Mills

EAF Baghouse - Continuous




# Oregon Steel Mills

EAF Baghouse - Continuous




## Oregon Steel Mills



### Particulate Emissions



## Oregon Steel Mills



### Lead Emissions






# Oregon Steel Mills

NOx, SO2, TGOC Emissions





## **PRODUCTION/PROCESS DATA**

Furnace Heat Logs

Baghouse Pressure Drop Field Data

# OSN #3 FURNACE HEAT LOG

## HEAT SUMMARY

Heat Number: 109390      Grade: A572-50-3-71      Grade No: 8437  
 Crew No : 1      Heat Tap Date: 12/27/2000      Charge Time: 1139  
                                                                                                  Tap Time: 1222  
 Heats on Delta: 788      Last heat Tapped: 1135

|                               |                         |
|-------------------------------|-------------------------|
| Total Charge Wt : 280.0       | Furnace Line Lbs : 0    |
| Hot Metal Wt : 0.0            | Oxygen Batch : 0        |
| Pour Back : 0.0               | Nat. Gas Batch : 146    |
|                               | Tap Teno : 0            |
| Melt Efficiency Rating : 0.00 | Total KWH : 39.2        |
| Charge to Tap Time : 43       | Avg. KW : 61.2          |
| Tap to Tap Time : 47          | KWH/Ton : 280.0         |
| Total Delay Time : 9.6        | Avg. Pwr. Factor : 0.85 |

## CHEMISTRY SUMMARY

LADLE ADDITIONS:

*132,100 First Charge*  
*70,100 2nd Charge*

# 0 6 1 H3 FURNACE HEAT LOG

## HEAT SUMMARY

Heat Number: 109391      Grade: A572-50-3-71      Grade No: 5437  
 Crew No : 1      Heat Tap Date: 12/27/2000      Charge Time: 1229  
                                                                                          Tap Time: 1318  
 Beats on Delta: 759      Last Heat Tapped: 1222

|                               |                         |
|-------------------------------|-------------------------|
| Total Charge Wt : 280.0       | Furnace Line Lbs : 0    |
| Hot Metal Wt : 0.0            | Oxygen Batch : 0        |
| Pour Back : 0.0               | Nat. Gas Batch : 136    |
|                               | Tap Temp : 0            |
| Belt Efficiency Rating : 0.00 | Total KWH : 34.9        |
| Charge to Tap Time : 49       | Avg. MW : 58.8          |
| Tap to Tap Time : 56          | KWH/Ton : 249.3         |
| Total Delay Time : 20.6       | Avg. Pwr. Factor : 0.84 |

## CHEMISTRY SUMMARY

LADLE ADDITIONS:

135,600 1st Charge  
 70,800 2nd Charge

HEAT SUMMARY

Heat Number: 109392      Grade: A572-50-3-71      Grade No: 5437  
 Crew No : 1      Heat Tap Date: 12/27/2000      Charge Time: 1322  
                                                                                          Tap Time: 1410  
 Beats on Delta: 790      Last Heat Tapped: 1318

|                               |                         |
|-------------------------------|-------------------------|
| Total Charge Wt : 280.0       | Furnace Line Lbs : 0    |
| Hot Metal Wt : 0.0            | Oxygen Batch : 0        |
| Pour Back : 0.0               | Nat. Gas Batch : 140    |
|                               | Tap Temp : 0            |
| Melt Efficiency Rating : 0.00 | Total MWh : 40.0        |
| Charge to Tap Time : 48       | Avg. MW : 59.7          |
| Tap to Tap Time : 52          | KWH/Ton : 285.7         |
| Total Delay Time : 11.9       | Avg. Pwr. Factor : 0.84 |

CHEMISTRY SUMMARY

LADLE ADDITIONS:

*136,700 1st Charge*  
*60,900 2nd Charge*

## HEAT SUMMARY

```
Heat Number: 109395      Grade: A572-50-3-71      Grade No: 5437
Drew No      : 1          Heat Tap Date: 12/27/2000      Charge Time: 1412
                                           Tap Time: 1457
Heats on Delta: 791      Last Heat Tapped: 1410
```

Total Charge Wt : 280.0  
 Hot Metal Wt : 0.0  
 Pour Back : 0.0

```
Furnace Line Lbs :      0
Oxygen Batch      :      0
Nat. Gas Batch    :    121
Tap Temp          :      0
```

```

Belt Efficiency Rating : 0.00
Charge to Tap Time    : 45
Tap to Tap Time       : 47
Total Delay Time      : 9.8


```

Total KWH : 37.1  
Avg. KW : 59.6  
KWH/Ton : 265.0  
Avg. Pwr. Factor : 0.84

## CHEMISTRY SUMMARY

LADLE ADDITIONS:

137,500 1st Charge.  
57,000 2nd Charge



# D S A #3 FURNACE HEAT LOG

## HEAT SUMMARY

Heat Number: 109394      Grade: A572-50-3-71      Grade No: 5437  
 Crew No : 2      Heat Tap Date: 12/27/2000      Charge Time: 1501  
                                                                                          Tap Time: 1542  
 Beats on Delta: 792      Last Heat Tapped: 1457

|                               |                         |
|-------------------------------|-------------------------|
| Total Charge Wt : 280.0       | Furnace Line Lbs : 0    |
| Hot Metal Wt : 0.0            | Oxygen Batch : 0        |
| Pour Back : 0.0               | Nat. Gas Batch : 136    |
|                               | Tap Temp : 0            |
| Melt Efficiency Rating : 0.00 | Total MWH : 37.2        |
| Charge to Tap Time : 41       | Avg. MW : 60.7          |
| Tap to Tap Time : 45          | KWH/Ton : 265.7         |
| Total Delay Time : 9.4        | Avg. Pwr. Factor : 0.85 |

## CHEMISTRY SUMMARY

LADLE ADDITIONS:

*134,30 1st Charge*  
*60,500 2nd Charge*

HEAT SUMMARY

---

|                     |                           |                        |
|---------------------|---------------------------|------------------------|
| Heat Number: 109395 | Grade: A572-50-3-71       | Grade No: 5437         |
| Crew No : 2         | Heat Tap Date: 12/27/2000 | Charge Time: 1546      |
|                     |                           | Tap Time: 1630         |
| Heats on Delta: 793 |                           | Last Heat Tapped: 1543 |

---

|                               |                         |
|-------------------------------|-------------------------|
| Total Charge Wt : 280.0       | Furnace Line Lbs : 0    |
| Hot Metal Wt : 0.0            | Oxygen Batch : 0        |
| Pour Back : 0.0               | Nat. Gas Batch : 143    |
|                               | Tap Temp : 0            |
| Melt Efficiency Rating : 0.00 | Total MWH : 37.9        |
| Charge to Tap Time : 44       | Avg. MW : 60.5          |
| Tap to Tap Time : 47          | KWH/Ton : 270.7         |
| Total Delay Time : 10.5       | Avg. Pwr. Factor : 0.85 |

---

CHEMISTRY SUMMARY

LADLE ADDITIONS:

*134,400 1st Charge*  
*59,500 2nd Charge*

# Production Data

OSM #3 Furnace Heat Log Data Reduction  
27-Dec-2000

| Heat    | Last Tap | Start Charge | Finish Tap | C-T mins | T-T mins | First Charge lbs | Second Charge lbs | Total Charge lbs | Run Total lbs | Total Time mins | Down Time mins | Run Time mins | Tons/hr |        |
|---------|----------|--------------|------------|----------|----------|------------------|-------------------|------------------|---------------|-----------------|----------------|---------------|---------|--------|
| 109,389 |          |              |            |          |          |                  |                   |                  |               |                 |                |               |         |        |
| Run 1   | 109,390  | 11:35        | 11:39      | 12:22    | 43.0     | 47.0             | 132,100           | 70,100           | 202,200       | 408,600         | 99             | 25            | 74      | 165.65 |
|         | 109,391  | 12:22        | 12:29      | 13:18    | 49.0     | 56.0             | 135,600           | 70,800           | 206,400       |                 |                |               |         |        |
| Run 2   | 109,392  | 13:18        | 13:22      | 14:10    | 48.0     | 52.0             | 136,700           | 60,900           | 197,600       | 392,100         | 95             |               | 95      | 123.82 |
|         | 109,393  | 14:10        | 14:12      | 14:57    | 45.0     | 47.0             | 137,500           | 57,000           | 194,500       |                 |                |               |         |        |
| Run 3   | 109,394  | 14:57        | 15:01      | 15:42    | 41.0     | 45.0             | 134,300           | 60,500           | 194,800       | 388,700         | 89             | 5             | 84      | 138.82 |
|         | 109,395  | 15:42        | 15:46      | 16:30    | 44.0     | 48.0             | 134,400           | 59,500           | 193,900       |                 |                |               |         |        |
| Average |          |              |            | 46.3     | 50.5     | 135,475          | 64,700            | 200,175          |               |                 |                |               |         |        |
| Total   |          |              |            |          |          |                  |                   |                  | 1,189,400     | 283             | 30             | 253           |         | 141.04 |

OSM Baghouse 12/27/00  
 Compartment Press Drops

R1  
1152

| 1  | 2  | 3  | 4  | 5    | 6  | 7    | 8    |
|----|----|----|----|------|----|------|------|
| 6" | 5" | 5" | 5" | 5.5" | 5" | 4.9" | 5.5" |

| 9  | 10 | 11 | 12 | 13 | 14 | 15 | 16   |
|----|----|----|----|----|----|----|------|
| 5" | 5" | 5" | 5" | 5" | 5" | —  | 5.5" |

R2  
1350

| 1  | 2  | 3  | 4 | 5    | 6  | 7    | 8  |
|----|----|----|---|------|----|------|----|
| 5" | 4" | 5" | — | 5.5" | 5" | 4.5" | 5" |

| 9  | 10 | 11 | 12   | 13   | 14   | 15 | 16   |
|----|----|----|------|------|------|----|------|
| 5" | 5" | 5" | 5.5" | 5.5" | 5.5" | 6" | 4.5" |

R3  
1502

| 1  | 2  | 3    | 4  | 5    | 6    | 7  | 8  |
|----|----|------|----|------|------|----|----|
| 6" | 5" | 5.5" | 5" | 5.5" | 4.5" | 4" | 5" |

| 9 | 10   | 11 | 12 | 13 | 14 | 15   | 16   |
|---|------|----|----|----|----|------|------|
| — | 5.5" | 6" | 6" | 6" | 6" | 6.5" | 5.5" |

## **CALIBRATION INFORMATION**

High –Volume Sampler Calibrations

Pitots

Thermocouples and Indicators

Shortridge Micro manometer

Barometer

Filter Tare Weights

Nox Converter Efficiency Data

Calibration Gas Certificates

Audit Sample Results, reporting forms and  
instructions

# High Volume Orifice Calibration Data

|                                                                                           |                 |                       |                          |                 |          |                 |                       |                          |                 |
|-------------------------------------------------------------------------------------------|-----------------|-----------------------|--------------------------|-----------------|----------|-----------------|-----------------------|--------------------------|-----------------|
| File                                                                                      | cal1192         | #1192                 | A = 47.996               | ✓               | #1032    | A = 44.898      |                       |                          |                 |
| Date                                                                                      | 02-03-00        | 02-03-00              | B = 0.462                |                 | 02-03-00 | B = 0.454       |                       |                          |                 |
| Tester                                                                                    | cdb             | Last                  | A = 48.643               |                 | Last     | A = 45.958      |                       |                          |                 |
| Analysis                                                                                  | cdb/mew         |                       | B = 0.440                |                 |          | B = 0.441       |                       |                          |                 |
|                                                                                           |                 | CHANGE                | A = -1.3%                |                 | CHANGE   | A = -2.3%       |                       |                          |                 |
|                                                                                           |                 |                       | B = 5.1%                 |                 |          | B = 3.0%        |                       |                          |                 |
| General Form Of Solution: $Q(68F) = A * (dHo * T68/T)^B$ ; $A = Q(68) @ T68F, dHo = 1.00$ |                 |                       |                          |                 |          |                 |                       |                          |                 |
| $Q = A(dHo)^B$                                                                            |                 |                       |                          |                 |          |                 |                       |                          |                 |
| 1) $\ln(Q) = \ln(A) + B * \ln(dHo)$                                                       |                 |                       | N                        | W               | C1       | Z               |                       |                          |                 |
| 2) $Z = \ln(Q)$                                                                           |                 |                       | W                        | W²              | C2       | WZ              |                       |                          |                 |
| $W = \ln(dHo)$                                                                            |                 |                       |                          |                 |          |                 |                       |                          |                 |
| $C1 = \ln(A)$                                                                             |                 |                       |                          |                 |          |                 |                       |                          |                 |
| $C2 = B$                                                                                  |                 |                       |                          |                 |          |                 |                       |                          |                 |
| 3) $Z = C1 + C2(W)$                                                                       |                 |                       |                          |                 |          |                 |                       |                          |                 |
| Point                                                                                     | dHo<br>(in H2O) | Q<br>(cfm)<br>@To=68F | Q<br>(cfm)<br>Calculated | Difference<br>% | Point    | dHo<br>(in H2O) | Q<br>(cfm)<br>@To=68F | Q<br>(cfm)<br>Calculated | Difference<br>% |
| 1                                                                                         | 0.130           | 19.01                 | 18.69                    | -1.7%           | 2        | 0.090           | 15.20                 | 15.03                    | -1.1%           |
| 2                                                                                         | 0.150           | 20.19                 | 19.97                    | -1.1%           | 3        | 0.090           | 15.42                 | 15.03                    | -2.5%           |
| 3                                                                                         | 0.160           | 20.61                 | 20.57                    | -0.2%           | 4        | 0.220           | 22.23                 | 22.57                    | 1.5%            |
| 4                                                                                         | 0.210           | 23.43                 | 23.33                    | -0.4%           | 5        | 0.210           | 21.90                 | 22.09                    | 0.9%            |
| 5                                                                                         | 0.230           | 23.74                 | 23.83                    | 0.4%            | 6        | 0.210           | 21.82                 | 22.09                    | 1.2%            |
| 6                                                                                         | 0.230           | 23.91                 | 24.33                    | 1.7%            | 7        | 0.420           | 29.73                 | 30.27                    | 1.8%            |
| 7                                                                                         | 0.420           | 31.51                 | 32.14                    | 2.0%            | 8        | 0.420           | 29.87                 | 30.27                    | 1.3%            |
| 8                                                                                         | 0.420           | 31.83                 | 32.14                    | 1.0%            | 9        | 0.420           | 30.01                 | 30.27                    | 0.9%            |
| 9                                                                                         | 0.420           | 31.84                 | 32.14                    | 1.0%            | 10       | 0.620           | 36.18                 | 36.13                    | -0.1%           |
| 10                                                                                        | 0.650           | 39.36                 | 39.33                    | -0.1%           | 11       | 0.630           | 36.40                 | 36.40                    | -0.0%           |
| 11                                                                                        | 0.670           | 39.59                 | 39.88                    | 0.7%            | 12       | 0.640           | 36.61                 | 36.66                    | 0.1%            |
| 12                                                                                        | 0.670           | 39.84                 | 39.88                    | 0.1%            | 13       | 0.820           | 41.13                 | 41.03                    | -0.2%           |
| 13                                                                                        | 0.820           | 44.24                 | 43.79                    | -1.0%           | 14       | 0.820           | 41.41                 | 41.03                    | -0.9%           |
| 14                                                                                        | 0.860           | 44.90                 | 44.76                    | -0.3%           | 15       | 0.830           | 41.41                 | 41.25                    | -0.4%           |
| 15                                                                                        | 0.870           | 44.88                 | 45.00                    | 0.3%            | 16       | 1.000           | 45.51                 | 44.90                    | -1.3%           |
| 16                                                                                        | 1.000           | 48.50                 | 48.00                    | -1.0%           | 17       | 1.000           | 45.15                 | 44.90                    | -0.6%           |
| 17                                                                                        | 1.000           | 48.50                 | 48.00                    | -1.0%           | 18       | 1.000           | 45.14                 | 44.90                    | -0.5%           |
| 18                                                                                        | 1.000           | 48.10                 | 48.00                    | -0.2%           |          |                 |                       |                          |                 |
| Average                                                                                   |                 |                       |                          |                 | Average  |                 |                       |                          |                 |
| No#                                                                                       | W               | W²                    | Z                        | WZ              | No#      | W               | W²                    | Z                        | WZ              |
| 1                                                                                         | -2.04           | 4.1625                | 2.9447                   | -6.0079         | 2        | -2.41           | 5.7982                | 2.7211                   | -6.5522         |
| 2                                                                                         | -1.90           | 3.5991                | 3.0054                   | -5.7016         | 3        | -2.41           | 5.7982                | 2.7356                   | -6.5872         |
| 3                                                                                         | -1.83           | 3.3584                | 3.0259                   | -5.5453         | 4        | -1.51           | 2.2926                | 3.1014                   | -4.6959         |
| 4                                                                                         | -1.56           | 2.4356                | 3.1539                   | -4.9222         | 5        | -1.56           | 2.4356                | 3.0867                   | -4.8172         |
| 5                                                                                         | -1.51           | 2.2926                | 3.1671                   | -4.7953         | 6        | -1.56           | 2.4356                | 3.0829                   | -4.8114         |
| 6                                                                                         | -1.47           | 2.1599                | 3.1745                   | -4.6655         | 7        | -0.87           | 0.7526                | 3.3922                   | -2.9428         |
| 7                                                                                         | -0.87           | 0.7526                | 3.4502                   | -2.9930         | 8        | -0.87           | 0.7526                | 3.3969                   | -2.9468         |
| 8                                                                                         | -0.87           | 0.7526                | 3.4604                   | -3.0019         | 9        | -0.87           | 0.7526                | 3.4016                   | -2.9509         |
| 9                                                                                         | -0.87           | 0.7526                | 3.4606                   | -3.0021         | 10       | -0.48           | 0.2285                | 3.5885                   | -1.7154         |
| 10                                                                                        | -0.43           | 0.1856                | 3.6726                   | -1.5821         | 11       | -0.46           | 0.2135                | 3.5945                   | -1.6608         |
| 11                                                                                        | -0.40           | 0.1604                | 3.6785                   | -1.4732         | 12       | -0.45           | 0.1992                | 3.6002                   | -1.6067         |
| 12                                                                                        | -0.40           | 0.1604                | 3.6848                   | -1.4757         | 13       | -0.20           | 0.0394                | 3.7166                   | -0.7376         |
| 13                                                                                        | -0.20           | 0.0394                | 3.7897                   | -0.7521         | 14       | -0.20           | 0.0394                | 3.7234                   | -0.7389         |
| 14                                                                                        | -0.15           | 0.0227                | 3.8044                   | -0.5738         | 15       | -0.19           | 0.0347                | 3.7236                   | -0.6938         |
| 15                                                                                        | -0.14           | 0.0194                | 3.8040                   | -0.5298         | 16       | 0.00            | 0.0000                | 3.8178                   | 0.0000          |
| 16                                                                                        | 0.00            | 0.0000                | 3.8817                   | 0.0000          | 17       | 0.00            | 0.0000                | 3.8099                   | 0.0000          |
| 17                                                                                        | 0.00            | 0.0000                | 3.8815                   | 0.0000          | 18       | 0.00            | 0.0000                | 3.8097                   | 0.0000          |
| 18                                                                                        | 0.00            | 0.0000                | 3.8733                   | 0.0000          |          |                 |                       |                          |                 |
| No#                                                                                       | W               | W²                    | Z                        | WZ              | No#      | W               | W²                    | Z                        | WZ              |
| 18                                                                                        | -14.64          | 20.8536               | 62.9132                  | -47.0213        | 17       | -14.02          | 21.7726               | 58.3029                  | -43.4577        |
| 18                                                                                        | -14.64          | C1                    | 62.91                    |                 | 17       | -14.02          | C1                    | 58.30                    |                 |
| -14.64                                                                                    | 20.85           | C2                    | -47.02                   |                 | -14.02   | 21.77           | C2                    | -43.46                   |                 |
| 1                                                                                         | -0.81           | C1                    | 3.50                     | C1 = 3.87111    | 0.9444   | -0.82           | C1                    | 3.43                     | C1 = 3.80440    |
| 0                                                                                         | 8.95            | C2                    | 4.14                     | C2 = 0.46230    | -0.7791  | 10.20           | C2                    | 4.64                     | C2 = 0.45438    |
| 1                                                                                         | -0.81           | C1                    | 3.50                     | A = 47.99563    | 0.9444   | -0.82           | C1                    | 3.43                     | A = 44.89831    |
| 0                                                                                         | 1               | C2                    | 0.46                     | B = 0.46230     | -0.087   | 1               | C2                    | 0.45                     | B = 0.45438     |
| 1                                                                                         | 0               | C1                    | 3.87                     | @1.00 48.00     | 0.8737   | 0               | C1                    | 3.80                     | @1.00 44.90     |
| 0                                                                                         | 1               | C2                    | 0.46                     | @0.10 16.55     | -0.087   | 1               | C2                    | 0.45                     | @0.10 15.77     |

## TRANSFER PROVER DATA SHEET

Date 5/12/00Customer Harrison Usage            c.f.            sec. Total usage on bypass            s.c.f.            Plat No.           Location Juel Motor Shop Metering Pr.            psi Reading—as found            Turb. Gears            A.F.           Time by pass A.L. hrs. Reading—as left            Turb. Gears            A.L.           Meter Data: Type Roots 3M No. 9019232 Temp. Control: Yes ☐ No ☒ Index Proof Circle 10 Paint Cond.           

| FLOW RANGE SELECTOR | INDICATED FLOW RATE CFH | PROVER PRESET COUNT | RUNNING TIME SECONDS | CALCULATED FLOW RATE CFH | UNCORR. PROOF PERCENT | $\Delta$ P PERCENT | $\Delta$ T PERCENT | CORRECTED PROOF PERCENT | ACCURACY PERCENT | AVERAGE ERROR | IF METER IS TEMP. CONTROLLED, FILL IN REMAINING SPACES |  |  |  | GAS TEMP. | PROOF TARGET | CORRECTED PROOF PERCENT | PERCENT ERROR | AVERAGE ERROR |
|---------------------|-------------------------|---------------------|----------------------|--------------------------|-----------------------|--------------------|--------------------|-------------------------|------------------|---------------|--------------------------------------------------------|--|--|--|-----------|--------------|-------------------------|---------------|---------------|
| 5M 3600             |                         | 11                  |                      | 3533                     |                       | -1.0               | -0.2               | 100.2                   | -0.2             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 3571                     |                       | -1.0               | -0.2               | 100.4                   | -0.4             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 3566                     |                       | -1.0               | -0.1               | 100.0                   | ✓                | -0.2          |                                                        |  |  |  |           |              |                         |               |               |
| 5M 3000             |                         | 11                  |                      | 3015                     |                       | -0.7               | -0.4               | 99.4                    | +0.6             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 3018                     |                       | -0.7               | -0.4               | 99.3                    | +0.7             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 3030                     |                       | -0.7               | -0.4               | 99.6                    | +0.4             | +0.5          |                                                        |  |  |  |           |              |                         |               |               |
| 5M 2000             |                         | 11                  |                      | 2073                     |                       | -0.3               | -0.3               | 99.7                    | +0.3             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 1996                     |                       | -0.3               | -0.3               | 99.6                    | +0.4             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 1996                     |                       | -0.3               | -0.3               | 99.4                    | +0.6             | +0.4          |                                                        |  |  |  |           |              |                         |               |               |
| 5M 1000             |                         | 13                  |                      | 1038                     |                       | -0.1               | -0.3               | 99.9                    | +0.1             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 1034                     |                       | -0.1               | -0.3               | 99.9                    | +0.1             |               |                                                        |  |  |  |           |              |                         |               |               |
|                     |                         |                     |                      | 1001                     |                       | -0.1               | -0.3               | 99.9                    | +0.1             | +0.1          |                                                        |  |  |  |           |              |                         |               |               |

COMMENTS:

2 LB. SET DATA

Regulator Set Press. A.F.            A.L.           Relief Set Press. A.F.            A.L.           Filter/Strainer Checked? Yes ☐ No ☐Total Man Hours           Crew Leader           Truck No.

# Pitot Calibration Calculations

|                 |             |                        |         |          |                 |
|-----------------|-------------|------------------------|---------|----------|-----------------|
| Date 19-Sep-00  |             | Pb= 29.73              |         | in Hg    |                 |
| File Sep-00     |             | Ta= 520.0              |         | R        |                 |
| Method #2 sec 4 |             | Location Whitaker Shop |         |          |                 |
| Who TJH,DLR     |             |                        |         |          |                 |
| Pitot           | Tested Last | [Cp] New               | [S]     | [Cp] Old | [%] Change      |
| ss7-4           | 8-Sep-00    | 0.79741                | 0.00382 | 0.80179  | -0.5%           |
| ss7-5           | 18-Sep-00   | 0.81845                | 0.00478 | 0.79189  | 3.4%            |
| ss7-6           | 11-Sep-00   | 0.78783                | 0.00725 | 0.81115  | -2.9%           |
| ss10-1          | 6-Sep-00    | 0.80365                | 0.00551 | 0.81671  | -1.6%           |
| ss10-2          | 18-Sep-00   | 0.80589                | 0.00680 | 0.80973  | -0.3%           |
| ss10-3          | 8-Sep-00    | 0.80521                | 0.00655 | 0.79971  | 0.7%            |
| 3s-1            | 11-Sep-00   | 0.83017                | 0.00654 | 0.83568  | -0.7%           |
| 3s-2            | 04/02/98    | 0.83734                | 0.00642 | 0.83734  | 0.0%            |
| 5s-1            | 11-Sep-00   | 0.83856                | 0.00681 | 0.83579  | 0.3%            |
| 5s-2            | 23-Mar-99   | 0.83403                | 0.00741 | 0.83403  | 0.0%            |
| Average         |             | 0.81585                | 0.00619 | 0.81738  | -0.18%          |
| Pitot           | Tested Last | [Cp] New               | [S]     | [Cp] Old | [%] Change      |
| 6s-1            | 19-Sep-00   | 0.82519                | 0.00735 | 0.84417  | -2.20%          |
| 6s-2            | 15-Feb-00   | 0.82451                | 0.00569 | 0.80373  | 2.60%           |
| HT-4            | 8-Sep-00    | 0.80791                | 0.00908 | 0.84367  | -4.20%          |
| SR-18           | 11-Sep-00   | 0.82139                | 0.00505 | 0.83573  | -1.70%          |
| SR-36           | 11-Sep-00   | 0.80674                | 0.00850 | 0.83797  | -3.70%          |
| SR-48           | 11-Sep-00   | 0.81766                | 0.00000 | 0.84270  | -1.40%          |
| 10-s            | 7-Sep-00    | 0.83016                | 0.00023 | 0.8421   | -4.20%          |
| 11-s            | 19-Sep-00   | 0.78015                | 0.00252 | 0.8144   | -4.20%          |
| 14-s            | 19-Sep-00   | 0.82415                | 0.00389 | 0.82054  | 0.40%           |
| 14-2S           | 19-Sep-00   | 0.80192                | 0.00653 |          | #DIV/0!         |
| WC 3-5          | 19-Sep-00   | 0.82072                | 0.00000 |          | #DIV/0!         |
| Average         |             | 0.81975                | 0.00679 | 0.83167  | -2.07%          |
| dPp             | dPs         | Cp                     | dS      | Avg Cp   | S               |
| ss7-4           | 1.290       | 1.970                  | 0.80112 | 0.00371  | 0.79741 0.00382 |
| Pass            | 1.200       | 1.860                  | 0.79519 | 0.00222  |                 |
| 9/8/00          | 0.800       | 1.250                  | 0.79200 | 0.00541  |                 |
| TJH             | 0.380       | 0.580                  | 0.80133 | 0.00392  |                 |
| ss7-5           | 1.300       | 1.920                  | 0.81462 | 0.00383  | 0.81845 0.00478 |
| Pass            | 1.200       | 1.750                  | 0.81980 | 0.00135  |                 |
| 9/18/00         | 0.775       | 1.150                  | 0.81271 | 0.00574  |                 |
| DLR             | 0.380       | 0.545                  | 0.82666 | 0.00821  |                 |
| ss7-6           | 1.280       | 2.000                  | 0.79200 | 0.00417  | 0.78783 0.00725 |
| Pass            | 1.190       | 1.850                  | 0.79400 | 0.00617  |                 |
| 9/11/00         | 0.800       | 1.250                  | 0.79200 | 0.00417  |                 |
| TJH             | 0.360       | 0.590                  | 0.77332 | 0.01451  |                 |
| ss10-1          | 1.250       | 1.950                  | 0.79263 | 0.01101  | 0.80365 0.00551 |
| Pass            | 1.200       | 1.820                  | 0.80388 | 0.00023  |                 |
| 9/6/00          | 0.810       | 1.200                  | 0.81337 | 0.00972  |                 |
| TJH             | 0.370       | 0.560                  | 0.80472 | 0.00107  |                 |
| ss10-2          | 1.250       | 1.900                  | 0.80300 | 0.00289  | 0.80589 0.00680 |
| Pass            | 1.220       | 1.850                  | 0.80395 | 0.00194  |                 |
| 9/18/00         | 0.765       | 1.180                  | 0.79712 | 0.00877  |                 |
| DLR             | 0.370       | 0.540                  | 0.81948 | 0.01352  |                 |
| ss10-3          | 1.260       | 1.930                  | 0.79991 | 0.00530  | 0.80521 0.00655 |
| Pass            | 1.180       | 1.780                  | 0.80606 | 0.00085  |                 |
| 9/8/00          | 0.785       | 1.210                  | 0.79740 | 0.00781  |                 |
| TJH             | 0.375       | 0.550                  | 0.81747 | 0.01226  |                 |
| 3s-1            | 1.250       | 1.780                  | 0.82962 | 0.00055  | 0.83017 0.00654 |
| Pass            | 1.160       | 1.660                  | 0.82758 | 0.00259  |                 |
| 9/11/00         | 0.810       | 1.180                  | 0.82023 | 0.00994  |                 |
| TJH             | 0.370       | 0.510                  | 0.84324 | 0.01307  |                 |
| 3s-2            | 1.200       | 1.650                  | 0.84428 | 0.00694  | 0.83734 0.00642 |
| Pass            | 0.690       | 0.980                  | 0.83071 | 0.00663  |                 |
| 04/02/98        | 0.585       | 0.830                  | 0.83114 | 0.00620  |                 |
| bef             | 0.370       | 0.510                  | 0.84324 | 0.00590  |                 |
| 5s-1            | 1.250       | 1.740                  | 0.83910 | 0.00054  | 0.83856 0.00681 |
| Pass            | 1.160       | 1.650                  | 0.83008 | 0.00848  |                 |
| 9/11/00         | 0.815       | 1.150                  | 0.83342 | 0.00514  |                 |
| TJH             | 0.370       | 0.500                  | 0.85163 | 0.01307  |                 |
| 5s-2            | 1.300       | 1.850                  | 0.82989 | 0.00414  | 0.83403 0.00741 |
| Pass            | 1.100       | 1.500                  | 0.84779 | 0.01376  |                 |
| 3/23/99         | 0.830       | 1.200                  | 0.82335 | 0.01068  |                 |
| kds             | 0.370       | 0.520                  | 0.83509 | 0.00106  |                 |
| dPp             | dPs         | Cp                     | dS      | Avg Cp   | S               |
| 6s-1            | 1.300       | 1.900                  | 0.81890 | 0.00629  | 0.82519 0.00735 |
| Pass            | 1.230       | 1.750                  | 0.82998 | 0.00479  |                 |
| 09/19/00        | 0.810       | 1.190                  | 0.81678 | 0.00841  |                 |
| DLR             | 0.370       | 0.520                  | 0.83509 | 0.00990  |                 |
| 6s-2            | 1.240       | 1.770                  | 0.82863 | 0.00412  | 0.82451 0.00569 |
| Pass            | 1.150       | 1.660                  | 0.82401 | 0.00050  |                 |
| 02/15/00        | 0.770       | 1.140                  | 0.81363 | 0.01088  |                 |
| MJE             | 0.360       | 0.510                  | 0.83177 | 0.00726  |                 |
| HT-4            | 1.240       | 1.800                  | 0.82169 | 0.01378  | 0.80791 0.00908 |
| Pass            | 1.150       | 1.710                  | 0.81187 | 0.00396  |                 |
| 09/08/00        | 0.770       | 1.210                  | 0.78975 | 0.01816  |                 |
| TJH             | 0.360       | 0.540                  | 0.80833 | 0.00042  |                 |
| SR-18           | 1.230       | 1.750                  | 0.82998 | 0.00859  | 0.82139 0.00505 |
| Pass            | 1.140       | 1.650                  | 0.82290 | 0.00150  |                 |
| 09/11/00        | 0.810       | 1.190                  | 0.81678 | 0.00462  |                 |
| TJH             | 0.360       | 0.530                  | 0.81592 | 0.00547  |                 |
| SR-36           | 1.230       | 1.800                  | 0.81837 | 0.01163  | 0.80674 0.00780 |
| Pass            | 1.140       | 1.700                  | 0.81071 | 0.00397  |                 |
| 09/11/00        | 0.810       | 1.250                  | 0.79694 | 0.00981  |                 |
| TJH             | 0.360       | 0.550                  | 0.80095 | 0.00579  |                 |
| SR-48           | 1.220       | 1.750                  | 0.82660 | 0.00894  | 0.81766 0.00850 |
| Pass            | 1.120       | 1.610                  | 0.82572 | 0.00805  |                 |
| 09/11/00        | 0.810       | 1.210                  | 0.81000 | 0.00766  |                 |
| TJH             | 0.360       | 0.540                  | 0.80833 | 0.00933  |                 |
| 10-s            | 1.300       | 1.850                  | 0.82989 | 0.00027  | 0.83016 0.00023 |
| Pass            | 1.230       | 1.750                  | 0.82998 | 0.00018  |                 |
| 09/07/00        | 0.830       | 1.180                  | 0.83030 | 0.00013  |                 |
| TJH             | 0.380       | 0.540                  | 0.83048 | 0.00032  |                 |
| 11-s            | 1.300       | 2.100                  | 0.77893 | 0.00122  | 0.78015 0.00252 |
| Pass            | 1.240       | 2.000                  | 0.77953 | 0.00063  |                 |
| 09/19/00        | 0.850       | 1.380                  | 0.77697 | 0.00318  |                 |
| DLR             | 0.390       | 0.620                  | 0.78518 | 0.00503  |                 |
| 14-s            | 1.300       | 1.850                  | 0.82989 | 0.00575  | 0.82415 0.00389 |
| Pass            | 1.240       | 1.820                  | 0.81717 | 0.00698  |                 |
| 09/19/00        | 0.830       | 1.200                  | 0.82335 | 0.00080  |                 |
| DLR             | 0.390       | 0.560                  | 0.82618 | 0.00203  |                 |
| 14-2S           | 1.300       | 2.000                  | 0.79816 | 0.00376  | 0.80192 0.00653 |
| Pass            | 1.230       | 1.880                  | 0.80077 | 0.00115  |                 |
| 09/19/00        | 0.820       | 1.210                  | 0.81499 | 0.01306  |                 |
| DLR             | 0.380       | 0.580                  | 0.79377 | 0.00816  |                 |
| WC 3-5          | 1.280       | 1.820                  | 0.83024 | 0.00952  | 0.82072         |
| Pass            | 1.220       | 1.720                  | 0.83378 | 0.01306  |                 |
| 09/19/00        | 0.850       | 1.250                  | 0.81638 | 0.00434  |                 |
| DLR             | 0.365       | 0.520                  | 0.82943 | 0.00871  |                 |

Note: \*\* Not calibrated; will calibrate when needed.

Note: \*\* Not calibrated; will calibrate when needed.

# Thermocouple Calibration

|                   |           |               |             |                      |                |             |              |              |             |              |              |
|-------------------|-----------|---------------|-------------|----------------------|----------------|-------------|--------------|--------------|-------------|--------------|--------------|
| Date:             | 16-Mar-00 | Deviation     | @60 F       | 7.8 Allowable Diff.  | Pb=            | 29.60 in Hg | cdb          |              |             |              |              |
| Next Calibration: | 16-Mar-01 | Limit         | @212 F      | 10.1 Allowable Diff. | Ta=            | 60.0 oF     | 980324tc     |              |             |              |              |
|                   |           |               | @325 F      | 11.8 Allowable Diff. |                |             |              |              |             |              |              |
|                   |           | Ambient       |             |                      | Boiling, Water |             |              | Boiling, Oil |             |              | Average      |
|                   | Probe/ID  | Standard, F   | Measured, F | Difference F         | Standard, F    | Measured, F | Difference F | Standard, F  | Measured, F | Difference F | Difference F |
| Probe             | 3-1       | 58.2          | 58.0        | 0.2                  | 177.6          | 178.2       | -0.6         | 340.1        | 340.2       | -0.1         | -0.17        |
| Probe             | 3-2       | 58.0          | 57.6        | 0.4                  | 210.2          | 212         | -1.8         | 337.8        | 338.8       | -1.0         | -0.80        |
| Probe             | 3-3       | 58.0          | 58.6        | -0.6                 | 207.4          | 208.6       | -1.2         | 336.4        | 336.8       | -0.4         | -0.73        |
| Probe             | wc3-4     | 0.0           | 0.0         | 0.0                  | 0              | 0           | 0.0          | 0.0          | 0.0         | 0.0          | 0.00         |
| Probe             | 3-5       | 57.6          | 58.4        | -0.8                 | 208            | 210         | -2.0         | 336.2        | 336.4       | -0.2         | -1.00        |
| Probe             | 3-6       | 58.0          | 58.4        | -0.4                 | 210.6          | 213.6       | -3.0         | 322.8        | 323.0       | -0.2         | -1.20        |
| Probe             | 3-7       | 58.2          | 58.6        | -0.4                 | 179.4          | 180.2       | -0.8         | 340.6        | 341.8       | -1.2         | -0.80        |
| Probe             | 3-8       | 57.8          | 58.8        | -1.0                 | 209.6          | 209.4       | 0.2          | 335.0        | 336.0       | -1.0         | -0.60        |
| Probe             | 4-1       | 58.6          | 58.8        | -0.2                 | 203            | 204.4       | -1.4         | 337.6        | 336.6       | 1.0          | -0.20        |
| Probe             | 4-2       | 58.6          | 58.4        | 0.2                  | 205.6          | 206.8       | -1.2         | 351.2        | 351.8       | -0.6         | -0.63        |
| Probe             | 4-3       | 58.2          | 59.0        | -0.8                 | 203.6          | 205         | -1.4         | 340.6        | 340.8       | -0.2         | -0.80        |
| Probe             | 4-4       | 58.2          | 58.8        | -0.6                 | 203.6          | 206         | -2.4         | 329.4        | 330.4       | -1.0         | -1.33        |
| Probe             | 4-5       | 59.4          | 60.2        | -0.8                 | 203.8          | 205.2       | -1.4         | 340.2        | 341.0       | -0.8         | -1.00        |
| Probe             | 4-6       | 58.4          | 57.4        | 1.0                  | 206.4          | 207.8       | -1.4         | 339.0        | 335.2       | 3.8          | 1.13         |
| Probe             | 4-7       | 58.4          | 58.6        | -0.2                 | 204.4          | 205         | -0.6         | 338.6        | 338.8       | -0.2         | -0.33        |
| Probe             | 5-2       | 59.0          | 59.8        | -0.8                 | 211            | 214         | -3.0         | 326.8        | 328.9       | -2.1         | -1.97        |
| Probe             | 5-3       | 58.8          | 59.2        | -0.4                 | 204.2          | 206.4       | -2.2         | 341.0        | 344.0       | -3.0         | -1.87        |
| Probe             | 5-4       | 58.8          | 59.2        | -0.4                 | 211.2          | 212.2       | -1.0         | 335.0        | 334.6       | 0.4          | -0.33        |
| Probe             | 5-5       | 59.0          | 61.2        | -2.2                 | 208.8          | 210         | -1.2         | 365.4        | 365.0       | 0.4          | -1.00        |
| Probe             | 5-6       | 59.0          | 59.4        | -0.4                 | 203.8          | 204.8       | -0.8         | 337.0        | 336.0       | 1.0          | -0.07        |
| Probe             | 5-7       | 59.0          | 59.2        | -0.2                 | 203.6          | 204.6       | -1.0         | 329.2        | 329.2       | 0.0          | -0.40        |
| Probe             | 5-8       | 59.0          | 59.6        | -0.6                 | 211.2          | 213.2       | -2.0         | 337.0        | 338.4       | -1.4         | -1.33        |
| Probe             | 5-9       | 58.8          | 59.2        | -0.4                 | 211            | 212.4       | -1.4         | 342.0        | 340.8       | 1.2          | -0.20        |
| Probe             | 7-1       | 59.2          | 59.8        | -0.6                 | 207.6          | 208.2       | -0.6         | 328.0        | 326.4       | 1.6          | 0.13         |
| Probe             | 7-2       | 59.2          | 59.6        | -0.4                 | 210.6          | 212.6       | -2.0         | 343.6        | 342.0       | 1.6          | -0.27        |
| Probe             | 7-3       | 59.4          | 59.4        | 0.0                  | 210.6          | 213.6       | -3.0         | 331.4        | 333.8       | -2.4         | -1.80        |
| Probe             | 7-4       | 59.2          | 59.6        | -0.4                 | 211            | 213         | -2.0         | 335.2        | 336.4       | -1.2         | -1.20        |
| Probe             | 7-5       | 59.2          | 60.2        | -1.0                 | 210.6          | 212.6       | -2.0         | 341.0        | 342.2       | -1.2         | -1.40        |
| Probe             | 7-6       | 59.8          | 59.4        | 0.2                  | 210.6          | 212.4       | -1.8         | 338.4        | 339.4       | -1.0         | -0.87        |
| Probe             | 10-1      | 59.4          | 59.6        | -0.2                 | 211.2          | 213.2       | -2.0         | 345.6        | 346.6       | -1.0         | -1.07        |
| Probe             | 10-2      | 59.8          | 59.6        | 0.0                  | 211            | 213         | -2.0         | 346.0        | 347.2       | -1.2         | -1.07        |
| Probe             | 10-3      | 0.0           | 0.0         | 0.0                  | 0              | 0           | 0.0          | 0.0          | 0.0         | 0.0          | 0.00         |
| FS Pitot          | 10-S      | 54.0          | 53.8        | 0.2                  | 210.8          | 212.8       | -2.0         | 344.0        | 344.8       | -0.8         | -0.87        |
| FS Pitot          | 11-S      | 59.6          | 59.8        | -0.2                 | 210.8          | 213.4       | -2.6         | 346.0        | 346.0       | 0.0          | -0.93        |
|                   | 14-S      | 60.0          | 60.2        | -0.2                 | 210.8          | 212.6       | -1.8         | 346.4        | 349.6       | -3.2         | -1.73        |
|                   | F3        | 60.2          | 60.6        | -0.4                 | 209.6          | 210.6       | -1.0         | 345.2        | 345.8       | -0.6         | -0.67        |
|                   | F23       | 61.2          | 60.8        | 0.4                  | 210.8          | 212.6       | -1.8         | 344.2        | 345.2       | -1.0         | -0.80        |
|                   | F51       | 0.0           | 0.0         | 0.0                  | 0              | 0           | 0.0          | 0.0          | 0.0         | 0.0          | 0.00         |
|                   | F84       | 60.2          | 60.4        | -0.2                 | 209.4          | 210.8       | -1.4         | 345.2        | 346.0       | -0.8         | -0.80        |
|                   | F85       | 54.0          | 54.2        | -0.2                 | 210.8          | 213.4       | -2.6         | 347.2        | 347.4       | -0.2         | -1.00        |
|                   | A1        | 60.0          | 60.2        | -0.2                 | 210.8          | 212.6       | -1.8         | 341.0        | 334.8       | 6.2          | 1.40         |
|                   | A2        | 60.4          | 60.4        | 0.0                  | 210.8          | 212.8       | -2.0         | 346.6        | 346.6       | 0.0          | -0.67        |
|                   | A3        | 60.0          | 60.0        | 0.0                  | 210.4          | 212.4       | -2.0         | 346.2        | 346.8       | -0.6         | -0.87        |
|                   | A5        | 54.2          | 54.2        | 0.0                  | 209.6          | 210.4       | -0.8         | 343.6        | 343.4       | 0.2          | -0.20        |
|                   | A6        | 60.0          | 60.8        | -0.8                 | 209.4          | 207.4       | 2.0          | 343.8        | 344.1       | -0.3         | 0.30         |
|                   | B10       | 60.8          | 61.4        | -0.6                 | 211            | 213.6       | -2.6         | 347.2        | 359.0       | -11.8        | -5.00        |
|                   | B4        | 54.0          | 54.2        | -0.2                 | 209            | 214         | -5.0         | 340.2        | 355.2       | -15.0        | -8.73        |
|                   | F9        | 60.0          | 60.2        | -0.2                 | 210.4          | 213.2       | -2.8         | 345.2        | 345.0       | 0.2          | -0.93        |
|                   | F73       | 61.0          | 61.8        | -0.8                 | 210.8          | 212.8       | -2.0         | 347.8        | 348.6       | -0.8         | -1.20        |
|                   | F4        | 60.6          | 60.8        | -0.2                 | 210.4          | 212         | -1.6         | 348.0        | 347.6       | 0.4          | -0.47        |
|                   | F83       | 61.2          | 61.4        | -0.2                 | 210.8          | 212.4       | -1.6         | 347.8        | 347.8       | 0.0          | -0.60        |
|                   | B7        | 60.6          | 61.0        | -0.4                 | 211            | 213.2       | -2.2         | 340.0        | 342.2       | -2.2         | -1.60        |
|                   | B15       | 60.4          | 60.6        | -0.2                 | 210.8          | 212         | -1.2         | 332.0        | 332.4       | -0.4         | -0.60        |
|                   | 6S-2      | 0.0           | 0.0         | 0.0                  | 0              | 0           | 0.0          | 0.0          | 0.0         | 0.0          | 0.00         |
| Probe             | 14-2      | 60.2          | 61.0        | -0.8                 | 210.8          | 211.6       | -0.8         | 346.6        | 344.8       | 1.8          | 0.07         |
| Probe             | w/c 4     | 58.2          | 58.4        | -0.2                 | 210.8          | 212.2       | -1.6         | 335.4        | 332.0       | 3.4          | 0.63         |
|                   | A4        | 60.0          | 60.2        | -0.2                 | 210.8          | 212.6       | -2.0         | 342.6        | 343.6       | -1.0         | -1.07        |
|                   | B1        | 60.2          | 60.6        | -0.4                 | 210.4          | 211.2       | -0.8         | 344.0        | 344.4       | -0.4         | -0.63        |
|                   | B3        | 60.2          | 60.4        | -0.2                 | 210.6          | 211.6       | -1.0         | 338.6        | 339.4       | -0.8         | -0.67        |
|                   | B11       | 60.8          | 61.0        | -0.2                 | 210.4          | 210.2       | 0.2          | 341.2        | 333.4       | 7.8          | 2.60         |
| AVERAGE           |           | 55.1          | 55.4        | -0.3                 | 194.2          | 195.7       | -1.5         | 318.1        | 318.6       | -0.5         | -0.8         |
|                   |           | -0.06%        |             |                      | -0.23%         |             |              | -0.06%       |             |              |              |
| Rivet Dial Gauges |           |               |             |                      |                |             |              |              |             |              |              |
|                   | D20       |               |             | 0.0                  | 211.2          | 208         | 3.2          |              |             | 0.0          |              |
|                   | D1        |               |             | 0.0                  | 211.2          | 205         | 6.2          |              |             | 0.0          |              |
|                   | D13       |               |             | 0.0                  | 211            | 210         | 1.0          |              |             | 0.0          |              |
|                   | 9142      |               |             | 0.0                  | 210.8          | 200         | 10.8         |              |             | 0.0          |              |
|                   | D4        |               |             | 0.0                  | 210.6          | 210         | 0.6          |              |             | 0.0          |              |
|                   | 1032      |               |             | 0.0                  | 205            | 200         | 5.0          | 338.4        | 336.0       | 2.4          |              |
| Standard Used     |           | Fluke 5895570 |             |                      |                |             |              |              |             |              |              |

Thermocouple Indicator Calibration

| Date: 8-7-00            |         | Deviation   |             | 7.4                  |             | Pb=         |                      | 30.05 in Hg |             | TJH7/MJE/DLR         |                      |
|-------------------------|---------|-------------|-------------|----------------------|-------------|-------------|----------------------|-------------|-------------|----------------------|----------------------|
| Next Calibration: 08-01 |         | Lmt         |             | 10.1                 |             | Ta=         |                      | 55.0 oF     |             | TCINDm00.WB1         |                      |
|                         |         | @32 F       |             | 7.4                  |             |             |                      |             |             |                      |                      |
|                         |         | @212 F      |             | 10.1                 |             |             |                      |             |             |                      |                      |
|                         |         | @400 F      |             | 12.9                 |             |             |                      |             |             |                      |                      |
| Thermocouple Indicator  | Channel | Measured, F | Standard, F | Deviation % absolute | Measured, F | Standard, F | Deviation % absolute | Measured, F | Standard, F | Deviation % absolute | Average Deviation, % |
| Dial multi-indicator    | 1       | 122.0       | 120.0       | 0.3                  | 510.0       | 510.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
|                         | 2       | 117.0       | 115.0       | 0.3                  | 510.0       | 510.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
|                         | 3       | 117.0       | 115.0       | 0.3                  | 510.0       | 510.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
|                         | 4       | 117.0       | 115.0       | 0.3                  | 510.0       | 509.0       | 0.1                  | 1030.0      | 1029.0      | 0.1                  | 0.17                 |
|                         | 5       | 117.0       | 115.0       | 0.3                  | 510.0       | 510.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
|                         | 8       | 117.0       | 115.0       | 0.3                  | 510.0       | 510.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
|                         | 7       | 110.0       | 108.0       | 0.4                  | 510.0       | 510.0       | 0.0                  | 1040.0      | 1040.0      | 0.0                  | 0.12                 |
|                         | 8       | 119.0       | 117.0       | 0.3                  | 511.0       | 511.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
|                         | 9       | 119.0       | 117.0       | 0.3                  | 511.0       | 510.0       | 0.1                  | 1029.0      | 1029.0      | 0.0                  | 0.15                 |
|                         | 10      | 119.0       | 117.0       | 0.3                  | 511.0       | 511.0       | 0.0                  | 1030.0      | 1029.0      | 0.1                  | 0.14                 |
| Omega trendicator       | 1       | 119.0       | 116.0       | 0.5                  | 510.0       | 510.0       | 0.0                  | 1026.0      | 1026.0      | 0.0                  | 0.17                 |
|                         | 2       | 119.0       | 116.0       | 0.5                  | 510.0       | 510.0       | 0.0                  | 1026.0      | 1026.0      | 0.0                  | 0.17                 |
|                         | 3       | 119.0       | 116.0       | 0.5                  | 510.0       | 510.0       | 0.0                  | 1026.0      | 1026.0      | 0.0                  | 0.17                 |
|                         | 4       | 119.0       | 116.0       | 0.5                  | 510.0       | 510.0       | 0.0                  | 1026.0      | 1026.0      | 0.0                  | 0.17                 |
|                         | 5       | 118.0       | 116.0       | 0.3                  | 510.0       | 510.0       | 0.0                  | 1026.0      | 1026.0      | 0.0                  | 0.12                 |
| Fluke 8393007           |         | 98.0        | 99.0        | -0.2                 | 492.0       | 493.0       | -0.1                 | 1012.0      | 1013.0      | -0.1                 | -0.12                |
| Fluke 7029062           |         | 104.0       | 102.0       | 0.4                  | 509.0       | 508.0       | 0.1                  | 1025.0      | 1024.0      | 0.1                  | 0.18                 |
| Fluke 72760077          | 1       | 102.0       | 100.2       | 0.3                  | 501.0       | 498.6       | 0.3                  | 1009.0      | 1007.8      | 0.1                  | 0.22                 |
|                         | 2       | 99.0        | 100.2       | -0.2                 | 498.4       | 498.6       | -0.0                 | 1006.4      | 1007.8      | -0.1                 | -0.11                |
| Meter Box 4             | 1       | 90.0        | 90.0        | 0.0                  | 505.0       | 506.0       | -0.1                 | 1003.0      | 1003.0      | 0.0                  | -0.03                |
|                         | 2       | 97.0        | 98.0        | -0.2                 | 512.0       | 513.0       | -0.1                 | 1003.0      | 1003.0      | 0.0                  | -0.09                |
|                         | 3       | 97.0        | 97.0        | 0.0                  | 512.0       | 513.0       | -0.1                 | 1012.0      | 1012.0      | 0.0                  | -0.03                |
|                         | 4       | 86.0        | 86.0        | 0.0                  | 503.0       | 503.0       | 0.0                  | 1011.0      | 1011.0      | 0.0                  | 0.00                 |
|                         | 5       | 85.0        | 85.0        | 0.0                  | 502.0       | 502.0       | 0.0                  | 1005.0      | 1005.0      | 0.0                  | 0.00                 |
| Meter Box 5             | 1       | 95.0        | 97.0        | -0.4                 | 502.0       | 503.0       | -0.1                 | 1006.0      | 1005.0      | 0.1                  | -0.13                |
|                         | 2       | 94.0        | 95.0        | -0.2                 | 508.0       | 508.0       | 0.0                  | 986.0       | 986.0       | 0.0                  | -0.06                |
|                         | 3       | 104.0       | 104.0       | 0.0                  | 522.0       | 522.0       | 0.0                  | 1000.0      | 1000.0      | 0.0                  | 0.00                 |
|                         | 4       | 97.0        | 98.0        | -0.2                 | 516.0       | 517.0       | -0.1                 | 1019.0      | 1018.0      | 0.1                  | -0.07                |
|                         | 5       | 88.0        | 90.0        | -0.4                 | 505.0       | 509.0       | -0.4                 | 1010.0      | 1010.0      | 0.0                  | -0.26                |
| Meter Box 6             | 1       | 102.0       | 103.0       | -0.2                 | 502.0       | 502.0       | 0.0                  | 1011.0      | 1011.0      | 0.0                  | -0.06                |
|                         | 2       | 99.0        | 98.0        | 0.2                  | 501.0       | 501.0       | 0.0                  | 1011.0      | 1011.0      | 0.0                  | 0.06                 |
|                         | 3       | 98.0        | 98.0        | 0.0                  | 498.0       | 499.0       | -0.1                 | 1008.0      | 1009.0      | -0.1                 | -0.06                |
|                         | 4       | 102.0       | 101.0       | 0.2                  | 498.0       | 499.0       | -0.1                 | 1008.0      | 1009.0      | -0.1                 | 0.00                 |
|                         | 5       | 102.0       | 102.0       | 0.0                  | 502.0       | 502.0       | 0.0                  | 1010.0      | 1011.0      | -0.1                 | -0.02                |
| Meter Box 7             | 1       | 98.0        | 97.0        | 0.2                  | 497.0       | 497.0       | 0.0                  | 1019.0      | 1018.0      | 0.1                  | 0.08                 |
|                         | 2       | 97.0        | 96.0        | 0.2                  | 496.0       | 496.0       | 0.0                  | 1018.0      | 1018.0      | 0.0                  | 0.06                 |
|                         | 3       | 98.0        | 97.0        | 0.2                  | 497.0       | 497.0       | 0.0                  | 1019.0      | 1018.0      | 0.1                  | 0.08                 |
|                         | 4       | 98.0        | 97.0        | 0.2                  | 497.0       | 497.0       | 0.0                  | 1019.0      | 1018.0      | 0.1                  | 0.08                 |
|                         | 5       | 98.0        | 97.0        | 0.2                  | 497.0       | 497.0       | 0.0                  | 1019.0      | 1018.0      | 0.1                  | 0.08                 |
| Meter Box 8             | 1       | 101.0       | 101.0       | 0.0                  | 501.0       | 500.0       | 0.1                  | 1009.0      | 1008.0      | 0.1                  | 0.06                 |
|                         | 2       | 101.0       | 100.0       | 0.2                  | 500.0       | 500.0       | 0.0                  | 1008.0      | 1008.0      | 0.0                  | 0.06                 |
|                         | 3       | 101.0       | 100.0       | 0.2                  | 501.0       | 500.0       | 0.1                  | 1008.0      | 1008.0      | 0.0                  | 0.09                 |
|                         | 4       | 101.0       | 100.0       | 0.2                  | 501.0       | 501.0       | 0.0                  | 1009.0      | 1009.0      | 0.0                  | 0.06                 |
|                         | 5       | 100.0       | 100.0       | 0.0                  | 500.0       | 500.0       | 0.0                  | 1009.0      | 1009.0      | 0.0                  | 0.00                 |
| Meter Box 9             | 1       | 100.0       | 101.0       | -0.2                 | 510.0       | 512.0       | -0.2                 | 1000.0      | 1000.0      | 0.0                  | -0.13                |
|                         | 2       | 101.0       | 102.0       | -0.2                 | 511.0       | 513.0       | -0.2                 | 1001.0      | 1000.0      | 0.1                  | -0.10                |
|                         | 3       | 101.0       | 103.0       | -0.4                 | 511.0       | 513.0       | -0.2                 | 1001.0      | 1000.0      | 0.1                  | -0.16                |
|                         | 4       | 100.0       | 102.0       | -0.4                 | 511.0       | 513.0       | -0.2                 | 1001.0      | 1000.0      | 0.1                  | -0.16                |
|                         | 5       | 100.0       | 102.0       | -0.4                 | 511.0       | 513.0       | -0.2                 | 1001.0      | 1000.0      | 0.1                  | -0.16                |
| temp. control box 1     | 1       | 104.0       | 103.0       | 0.2                  | 505.0       | 507.0       | -0.2                 | 997.0       | 992.0       | 0.3                  | 0.11                 |
|                         | 2       | 106.0       | 105.0       | 0.2                  | 518.0       | 520.0       | -0.2                 | 1012.0      | 1007.0      | 0.3                  | 0.10                 |
|                         | 3       | 105.0       | 104.0       | 0.2                  | 505.0       | 509.0       | -0.4                 | 1007.0      | 1003.0      | 0.3                  | 0.01                 |
|                         | 4       | 102.0       | 100.0       | 0.4                  | 507.0       | 510.0       | -0.3                 | 1005.0      | 1001.0      | 0.3                  | 0.11                 |
|                         | 5       | 103.0       | 102.0       | 0.2                  | 497.0       | 499.0       | -0.2                 | 997.0       | 993.0       | 0.3                  | 0.08                 |
|                         | 6       | 99.0        | 99.0        | 0.0                  | 497.0       | 500.0       | -0.3                 | 1003.0      | 999.0       | 0.3                  | -0.01                |
| temp. control box 2     | 1       | 97.0        | 99.0        | -0.4                 | 497.0       | 502.0       | -0.5                 | 988.0       | 990.0       | -0.1                 | -0.34                |
|                         | 2       | 96.0        | 98.0        | -0.4                 | 497.0       | 502.0       | -0.5                 | 986.0       | 989.0       | -0.2                 | -0.36                |
|                         | 3       | 97.0        | 98.0        | -0.2                 | 497.0       | 501.0       | -0.4                 | 986.0       | 989.0       | -0.2                 | -0.27                |
|                         | 4       | 98.0        | 100.0       | -0.4                 | 498.0       | 503.0       | -0.5                 | 986.0       | 988.0       | -0.1                 | -0.34                |
|                         | 5       | 97.0        | 94.0        | 0.5                  | 497.0       | 501.0       | -0.4                 | 986.0       | 987.0       | -0.1                 | 0.02                 |
|                         | 6       | 96.0        | 98.0        | -0.4                 | 499.0       | 503.0       | -0.4                 | 985.0       | 988.0       | -0.2                 | -0.33                |
| Van II Heater Controls  | 1       | 95.0        | 94.0        | 0.2                  | 491.0       | 496.0       | -0.5                 | 1018.0      | 1090.8      | -4.7                 | -1.68                |
|                         | 2       | 93.0        | 92.0        | 0.2                  | 490.0       | 498.0       | -0.8                 | 1020.0      | 1021.0      | -0.1                 | -0.24                |
|                         | 3       | 37.0        | 35.0        | 0.4                  | 258.0       | 259.0       | -0.1                 | 548.0       | 548.0       | 0.0                  | 0.08                 |
|                         | 4       | 37.0        | 34.0        | 0.8                  | 255.0       | 258.0       | -0.4                 | 549.0       | 549.0       | 0.0                  | 0.06                 |
| AVERAGE                 |         | 100.98      | 100.42      | 0.10                 | 496.78      | 497.93      | -0.12                | 997.05      | 997.76      | -0.04                | -0.02                |

Standard used, Fluke 5895570 calibrated 4-1-98 by Grant Edge Co.



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horlzone@teleport.com

(Serial No. M94064)

On June 20, 2000, the Shortridge SR1 digital manometer was calibrated against a zero to three-inch incline manometer. The table below shows the results.

| Incline Manometer | Shortridge 1 |
|-------------------|--------------|
| 0.00              | 0.0000       |
| 0.05              | 0.0504       |
| 0.10              | 0.1075       |
| 0.15              | 0.1515       |
| 0.20              | 0.2030       |
| 0.30              | 0.3037       |
| 0.40              | 0.4030       |
| 0.50              | 0.5060       |
| 0.70              | 0.7040       |
| 0.90              | 0.9030       |
| 1.10              | 1.1010       |
| 1.50              | 1.500        |
| 2.00              | 1.948        |
| 2.50              | 2.501        |
| 2.90              | 2.895        |

TJH



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizone@teleport.com

(Serial No. M961010)

On June 20, 2000, the Shortridge SR2 digital manometer was calibrated against a zero to three-inch incline manometer. The table below shows the results.

| Incline Manometer | Shortridge 2 |
|-------------------|--------------|
| 0.00              | 0.0000       |
| 0.05              | 0.0450       |
| 0.10              | 0.1047       |
| 0.15              | 0.1495       |
| 0.20              | 0.2049       |
| 0.30              | 0.3085       |
| 0.40              | 0.4145       |
| 0.50              | 0.5177       |
| 0.70              | 0.7107       |
| 0.90              | 0.9162       |
| 1.10              | 1.090        |
| 1.50              | 1.511        |
| 2.00              | 2.010        |
| 3.00              | 2.911        |

TJH

# Magnehelic Calibrations

| Date              | 02-Feb-00     | MG020220 File         |              |                   |                  |                   |              |                    |
|-------------------|---------------|-----------------------|--------------|-------------------|------------------|-------------------|--------------|--------------------|
| Testers           | cdh           | 80.0 Temp.(F)         |              |                   |                  |                   |              |                    |
| Location          | Whitaker Shop | 30.50 Pb(in H2O)      |              |                   |                  |                   |              |                    |
|                   |               | 0-31nc/MB-1 Manometer |              |                   |                  |                   |              |                    |
| Magnehelic ID     | 15 sec. High  | leak check Low        | Scale Inches | Magnehelic in H2O | Manometer in H2O | Difference in H2O | Difference % | Difference Average |
| 1-A               | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | -0.4%              |
|                   |               |                       |              | 0.300             | 0.300            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.600             | 0.590            | -0.010            | -1.7%        |                    |
|                   |               |                       |              | 0.940             | 0.940            | 0.000             | 0.0%         |                    |
| 1-C<br>21-sept-99 | n/a           | n/a                   | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | ERR                |
|                   |               |                       |              | 0.000             | 0.000            | 0.000             | ERR          |                    |
|                   |               |                       |              | 0.000             | 0.000            | 0.000             | ERR          |                    |
|                   |               |                       |              | 0.000             | 0.000            | 0.000             | ERR          |                    |
| 1-E               | ok            | ok                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | 2.4%               |
|                   |               |                       |              | 0.130             | 0.140            | 0.010             | 7.1%         |                    |
|                   |               |                       |              | 0.440             | 0.440            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.820             | 0.840            | 0.020             | 2.4%         |                    |
| 1-F ✓             | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | 3.3%               |
|                   |               |                       |              | 0.220             | 0.240            | 0.020             | 8.3%         |                    |
|                   |               |                       |              | 0.460             | 0.470            | 0.010             | 2.1%         |                    |
|                   |               |                       |              | 0.740             | 0.760            | 0.020             | 2.6%         |                    |
| 1-G               | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | -2.7%              |
|                   |               |                       |              | 0.190             | 0.190            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.480             | 0.460            | -0.020            | -4.3%        |                    |
|                   |               |                       |              | 0.840             | 0.790            | -0.050            | -6.3%        |                    |
| 1-H               | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | 0.1%               |
|                   |               |                       |              | 0.600             | 0.590            | -0.010            | -1.7%        |                    |
|                   |               |                       |              | 0.800             | 0.800            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 1.000             | 1.020            | 0.020             | 2.0%         |                    |
| 1-I<br>21-sept-99 | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | -0.1%              |
|                   |               |                       |              | 0.920             | 0.950            | 0.030             | 3.2%         |                    |
|                   |               |                       |              | 0.670             | 0.670            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.300             | 0.290            | -0.010            | -3.4%        |                    |
| 1-K               | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | 1.2%               |
|                   |               |                       |              | 0.210             | 0.220            | 0.010             | 4.5%         |                    |
|                   |               |                       |              | 0.330             | 0.340            | 0.010             | 2.9%         |                    |
|                   |               |                       |              | 0.800             | 0.780            | -0.020            | -2.6%        |                    |
| 1-L               | OK            | OK                    | 1            | 0.000             | 0.000            | 0.000             | 0.0%         | 1.0%               |
|                   |               |                       |              | 0.120             | 0.120            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.510             | 0.510            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.940             | 0.980            | 0.040             | 4.1%         |                    |
| 2-A               | OK            | OK                    | 2            | 0.000             | 0.000            | 0.000             | 0.0%         | 0.0%               |
|                   |               |                       |              | 0.850             | 0.850            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.450             | 0.450            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 1.600             | 1.600            | 0.000             | 0.0%         |                    |
| 2-B               | OK            | OK                    | 2            | 0.000             | 0.000            | 0.000             | 0.0%         | -1.0%              |
|                   |               |                       |              | 0.500             | 0.480            | -0.020            | -4.2%        |                    |
|                   |               |                       |              | 0.870             | 0.870            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 1.400             | 1.400            | 0.000             | 0.0%         |                    |
| 2-C               | OK            | OK                    | 2            | 0.000             | 0.000            | 0.000             | 0.0%         | 0.0%               |
|                   |               |                       |              | 0.400             | 0.400            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.720             | 0.720            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 1.500             | 1.500            | 0.000             | 0.0%         |                    |
| 2-D<br>10-Feb-99  | OK            | OK                    | 2            | 0.000             | 0.000            | 0.000             | 0.0%         | -0.8%              |
|                   |               |                       |              | 0.450             | 0.470            | 0.020             | 4.3%         |                    |
|                   |               |                       |              | 1.050             | 1.000            | -0.050            | -5.0%        |                    |
|                   |               |                       |              | 1.700             | 1.660            | -0.040            | -2.4%        |                    |
| 2-E               | OK            | OK                    | 2            | 0.000             | 0.000            | 0.000             | 0.0%         | 0.4%               |
|                   |               |                       |              | 0.350             | 0.350            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 0.750             | 0.740            | -0.010            | -1.4%        |                    |
|                   |               |                       |              | 1.750             | 1.800            | 0.050             | 2.8%         |                    |
| 3-A<br>10-Feb-99  | OK            | OK                    | 3            | 0.000             | 0.000            | 0.000             | 0.0%         | 0.2%               |
|                   |               |                       |              | 0.550             | 0.550            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 1.500             | 1.500            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 2.980             | 3.000            | 0.020             | 0.7%         |                    |
| 3-H<br>10-Feb-99  | OK            | OK                    | 3            | 0.000             | 0.000            | 0.000             | 0.0%         | 0.8%               |
|                   |               |                       |              | 0.500             | 0.500            | 0.000             | 0.0%         |                    |
|                   |               |                       |              | 1.500             | 1.530            | 0.030             | 2.0%         |                    |
|                   |               |                       |              | 2.500             | 2.510            | 0.010             | 0.4%         |                    |



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizone@teleport.com

October 27, 2000  
Horizon Engineering shop  
Barometer Calibration

The Barometric pressure reported at Portland Troutdale airport was 29.83" Hg and was corrected to the altitude of the Horizon Engineering shop. The barometer reading in TVIII was 29.89"Hg. The barometer reading in TVII was 29.61" Hg. The barometer reading in TVI was 29.92" Hg. All pressures are absolute read at the horizon engineering shop.

DLR

These filters are stored in the desiccator

22-141 50 SHEETS  
22-142 100 SHEETS  
22-144 200 SHEETS



# NOx Converter Efficiency Data

## NOx Converter Efficiency Test Thermo Environmental Model 42C

Date 11-Jan-2000

Pretest Post test

|        |        |
|--------|--------|
| 0.06   | 0.26   |
| 182.60 | 182.40 |
| 89.10  | 89.32  |
| 14:39  | 15:35  |

Readings Time


Zero

Span

Mid

Time

60.7 14:57  
60.7 14:58  
60.7 14:59  
60.7 15:00  
60.7 15:01  
60.7 15:02  
60.7 15:03  
60.7 15:04  
60.7 15:05  
60.7 15:06  
60.7 15:07  
60.7 15:08  
60.7 15:09  
60.7 15:10  
60.67 15:11  
60.67 15:12  
60.64 15:13  
60.66 15:14  
60.5 15:15  
60.54 15:16  
60.5 15:17  
60.5 15:18  
60.5 15:19  
60.5 15:20  
60.5 15:21  
60.5 15:22  
60.5 15:23  
60.5 15:24  
60.5 15:25  
60.5 15:26



Percent Loss=

0.329

PASS

| Cyl # | EPA Value | Conc. |
|-------|-----------|-------|
| 32    | 182.5     | ppm   |
| 25    | 91.3      | ppm   |
| R4    | 0         | ppm   |



06-23-00  
SCOTT-MARRIN, INC.  
6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507  
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

#15

REPORT OF ANALYSIS  
EPA PROTOCOL GAS MIXTURES

HENG01  
TO: DAVID ROSSMAN  
HORIZON ENGINEERING/INFRARED NW  
13585 NE WHITAKER WAY  
PORTLAND OR 97230

DATE: June 15 2000

CUSTOMER ORDER NUMBER: 002945

| COMPONENT                                        | CONCENTRATION(v/v)<br>± EPA UNCERTAINTY | REFERENCE<br>STANDARD | ANALYZER<br>MAKE, MODEL, S/N, DETECTION | EXPIRATION<br>DATE | REPLICATE<br>ANALYSIS DATA |  |
|--------------------------------------------------|-----------------------------------------|-----------------------|-----------------------------------------|--------------------|----------------------------|--|
| CYLINDER NO: CC97886                             |                                         |                       |                                         |                    |                            |  |
| Carbon Dioxide                                   | 6.02 ± 0.07 %                           | GMIS                  | VARIAN MODEL 1860 TCD                   | 06/07/02           | 06/07/00                   |  |
|                                                  |                                         |                       | S/N NONE                                |                    | 6.05 %                     |  |
|                                                  |                                         | CYLINDER #:           | THERMAL CONDUCTIVITY                    |                    | 6.01 %                     |  |
|                                                  |                                         | CC86199               | GAS CHROMATOGRAPHY                      |                    | 6.00 %                     |  |
|                                                  |                                         | @ 7.25 %              | LAST CAL DATE: 05/25/00                 | MEAN:              | 6.02 %                     |  |
| Nitric Oxide<br>NOx                              | 50.0 ± 0.3 ppm<br>50.0 ppm              | GMIS                  | BOVAR MODEL 922M                        | 06/15/02           | 06/07/00                   |  |
|                                                  |                                         |                       | S/N VD92284844                          |                    | 49.6 ppm                   |  |
|                                                  |                                         | CYLINDER #:           | CONTINUOUS                              |                    | 49.8 ppm                   |  |
|                                                  |                                         | CC108765              | UV PHOTOMETRY                           |                    | 49.8 ppm                   |  |
|                                                  |                                         | @ 50.3 ppm            | LAST CAL DATE: 05/18/00                 | MEAN:              | 49.7 ppm                   |  |
| Carbon Monoxide                                  | 304 ± 3 ppm                             | GMIS                  | CARLE INST MODEL 8000                   | 06/15/02           | 06/07/00                   |  |
|                                                  |                                         |                       | S/N 8249                                |                    | 303 ppm                    |  |
|                                                  |                                         | CYLINDER #:           | METHANATION/FID                         |                    | 304 ppm                    |  |
|                                                  |                                         | CC42843               | GAS CHROMATOGRAPHY                      |                    | 304 ppm                    |  |
|                                                  |                                         | @ 286.7 ppm           | LAST CAL DATE: 06/13/00                 | MEAN:              | 304 ppm                    |  |
| Propane                                          | 27.79 ± 0.22 ppm                        | GMIS                  | VARIAN MODEL 1860 FID                   | 06/06/02           | 06/06/00                   |  |
|                                                  |                                         |                       | S/N NONE                                |                    | 27.79 ppm                  |  |
|                                                  |                                         | CYLINDER #:           | FLAME IONIZATION                        |                    | 27.80 ppm                  |  |
|                                                  |                                         | CC121986              | GAS CHROMATOGRAPHY                      |                    | 27.77 ppm                  |  |
| O2-free Nitrogen<br>CYLINDER PRESSURE: 2000 psig | Balance                                 | @ 50.6 ppm            | LAST CAL DATE: 06/02/00                 | MEAN:              | 27.79 ppm                  |  |

ppm =  $\mu\text{mole/mole}$

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R93/224, dated September 1993.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST:   
M. S. CALHOUN

APPROVED:   
J. E. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.  
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

**SCOTT-MARRIN, INC.**6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507  
TELEPHONE (909) 653-6780 • FAX (909) 653-2430#22  
PO#303**REPORT OF ANALYSIS  
EPA PROTOCOL GAS MIXTURES**HENG01  
TO: DAVID ROSSMAN  
HORIZON ENGINEERING/INFRARED NW  
13585 NE WHITAKER WAY  
PORTLAND, OR 97230

DATE: September 5 2000

CUSTOMER ORDER NUMBER: 003030

| COMPONENT                    | CONCENTRATION(V/V)<br>± EPA UNCERTAINTY | REFERENCE<br>STANDARD                         | ANALYZER<br>MAKE, MODEL, S/N, DETECTION | EXPIRATION<br>DATE | REPLICATE<br>ANALYSIS DATA |          |
|------------------------------|-----------------------------------------|-----------------------------------------------|-----------------------------------------|--------------------|----------------------------|----------|
| CYLINDER NO: CC1859          |                                         |                                               |                                         |                    |                            |          |
| Carbon Dioxide               | 12.52 ± 0.05 %                          | GMIS<br>CYLINDER #:<br>CC122859<br>@ 17.93%   | VARIAN MODEL 1860 TCD                   | 08/23/02           | 08/23/00                   |          |
|                              |                                         |                                               | S/N NONE                                |                    | 12.51 %                    |          |
|                              |                                         |                                               | THERMAL CONDUCTIVITY                    |                    | 12.53 %                    |          |
|                              |                                         |                                               | GAS CHROMATOGRAPHY                      |                    | 12.51 %                    |          |
|                              |                                         |                                               | LAST CAL DATE: 08/21/00                 |                    | MEAN:                      | 12.52 %  |
| Nitric Oxide<br>NOx          | 90.3 ± 1.1 ppm<br>90.3 ppm              | GMIS<br>CYLINDER #:<br>CA01327<br>@ 98.6 ppm  | BOVAR MODEL 922M                        | 08/23/02           | 08/16/00                   | 08/23/00 |
|                              |                                         |                                               | S/N VD92284844                          |                    | 90.5 ppm                   | 89.7 ppm |
|                              |                                         |                                               | CONTINUOUS                              |                    | 90.1 ppm                   | 90.8 ppm |
|                              |                                         |                                               | UV PHOTOMETRY                           |                    | 90.0 ppm                   | 90.6 ppm |
|                              |                                         |                                               | LAST CAL DATE: 08/16/00                 |                    | MEAN:                      | 90.2 ppm |
| Carbon Monoxide              | 508 ± 5 ppm                             | GMIS<br>CYLINDER #:<br>CC278<br>@ 539 ppm     | CARLE INST MODEL 8000                   | 08/30/02           | 08/17/00                   | 08/30/00 |
|                              |                                         |                                               | S/N 8249                                |                    | 507 ppm                    | 506 ppm  |
|                              |                                         |                                               | METHANATION/FID                         |                    | 507 ppm                    | 508 ppm  |
|                              |                                         |                                               | GAS CHROMATOGRAPHY                      |                    | 508 ppm                    | 509 ppm  |
|                              |                                         |                                               | LAST CAL DATE: 08/15/00                 |                    | MEAN:                      | 507 ppm  |
| Propane                      | 49.5 ± 0.5 ppm                          | GMIS<br>CYLINDER #:<br>CC121986<br>@ 50.6 ppm | VARIAN MODEL 1860 FID                   | 09/05/02           | 09/05/00                   |          |
|                              |                                         |                                               | S/N NONE                                |                    | 49.2 ppm                   |          |
|                              |                                         |                                               | FLAME IONIZATION                        |                    | 49.7 ppm                   |          |
|                              |                                         |                                               | GAS CHROMATOGRAPHY                      |                    | 49.6 ppm                   |          |
|                              |                                         |                                               | LAST CAL DATE: 09/05/00                 |                    | MEAN:                      | 49.5 ppm |
| Nitrogen, O2-free Balance    |                                         |                                               |                                         |                    |                            |          |
| CYLINDER PRESSURE: 2000 psig |                                         |                                               |                                         |                    |                            |          |

ppm =  $\mu$ mole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R93/224, dated September 1993.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST:

M. S. CALHOUN

APPROVED:

J. T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.  
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



# SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507  
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

## REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

E 35 p 0 F  
9/25/00

HENG01  
TO: DAVID ROSSMAN  
HORIZON ENG'G/INFRARED NW  
13585 NE WHITAKER WAY  
PORTLAND OR 97230

DATE: September 21 2000

CUSTOMER ORDER NUMBER: 003073

| COMPONENT                    | CONCENTRATION(v/v)<br>± EPA UNCERTAINTY | REFERENCE<br>STANDARD                         | ANALYZER<br>MAKE, MODEL, S/N, DETECTION | EXPIRATION<br>DATE | REPLICATE<br>ANALYSIS DATA |           |
|------------------------------|-----------------------------------------|-----------------------------------------------|-----------------------------------------|--------------------|----------------------------|-----------|
| CYLINDER NO: CC53889         |                                         |                                               |                                         |                    |                            |           |
| Carbon Dioxide               | 21.86 ± 0.06 %                          | GMIS<br>CYLINDER #:<br>CC122859<br>@ 17.93 %  | VARIAN MODEL 1860 TCD                   | 09/21/02           | 09/21/00                   |           |
|                              |                                         |                                               | S/N NONE                                |                    | 21.84 %                    |           |
|                              |                                         |                                               | THERMAL CONDUCTIVITY                    |                    | 21.84 %                    |           |
|                              |                                         |                                               | GAS CHROMATOGRAPHY                      |                    | 21.89 %                    |           |
|                              |                                         |                                               | LAST CAL DATE: 09/21/00                 |                    | MEAN:                      | 21.86 %   |
| Nitric Oxide<br>NOx          | 183.0 ± 1.1 ppm<br>183.0 ppm            | GMIS<br>CYLINDER #:<br>CC72078<br>@ 258.5 ppm | BOVAR MODEL 922M                        | 09/20/02           | 09/13/00                   | 09/20/00  |
|                              |                                         |                                               | S/N VD92284844                          |                    | 183.1 ppm                  | 182.7 ppm |
|                              |                                         |                                               | CONTINUOUS                              |                    | 183.4 ppm                  | 182.9 ppm |
|                              |                                         |                                               | UV PHOTOMETRY                           |                    | 182.7 ppm                  | 183.2 ppm |
|                              |                                         |                                               | LAST CAL DATE: 09/13/00                 |                    | MEAN:                      | 183.1 ppm |
| Carbon Monoxide              | 898 ± 9 ppm                             | GMIS<br>CYLINDER #:<br>CC108729<br>@ 1106 ppm | CARLE INST MODEL 8000                   | 09/21/02           | 09/06/00                   | 09/21/00  |
|                              |                                         |                                               | S/N 8249                                |                    | 897 ppm                    | 900 ppm   |
|                              |                                         |                                               | METHANATION/FID                         |                    | 899 ppm                    | 899 ppm   |
|                              |                                         |                                               | GAS CHROMATOGRAPHY                      |                    | 896 ppm                    | 899 ppm   |
|                              |                                         |                                               | LAST CAL DATE: 09/20/00                 |                    | MEAN:                      | 897 ppm   |
| Propane                      | 86.5 ± 0.9 ppm                          | GMIS<br>CYLINDER #:<br>CC51261<br>@ 104.1 ppm | VARIAN MODEL 1860 FID                   | 09/07/02           | 09/07/00                   |           |
|                              |                                         |                                               | S/N NONE                                |                    | 86.9 ppm                   |           |
|                              |                                         |                                               | FLAME IONIZATION                        |                    | 86.6 ppm                   |           |
|                              |                                         |                                               | GAS CHROMATOGRAPHY                      |                    | 86.1 ppm                   |           |
|                              |                                         |                                               | LAST CAL DATE: 09/05/00                 |                    | MEAN:                      | 86.5 ppm  |
| O2-free Nitrogen Balance     |                                         |                                               |                                         |                    |                            |           |
| CYLINDER PRESSURE: 2000 psig |                                         |                                               |                                         |                    |                            |           |

ppm =  $\mu$ mole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R93/224, dated September 1993.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST: M.S. CALHOUN

APPROVED: J.T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



**6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507**  
**TELEPHONE (909) 653-6780 • FAX (909) 653-2430**

REPORT OF ANALYSIS  
EPA PROTOCOL GAS MIXTURES

#02  
PO. 30916

HENG01

TO: DAVID ROSSMAN  
HORIZON ENGINEERING/  
INFRARED NW  
13585 NE WHITAKER WAY  
PORTLAND, OR 97230-

DATE : 09/28/00

CUSTOMER ORDER NUMBER: 003096

PAGE 1

| COMPONENT          | CONCENTRATION (v/v)<br>+/-EPA UNCERTAINTY | REFERENCE<br>STANDARD | ANALYZER<br>MAKE, MODEL, S/N, DETECTION               | EXPIRATION<br>DATE | REPLICATE<br>ANALYSIS DATA     |
|--------------------|-------------------------------------------|-----------------------|-------------------------------------------------------|--------------------|--------------------------------|
| CYLINDER NO.:      | CC53843                                   |                       |                                                       |                    |                                |
| Oxygen             | 11.61 $\pm$ .28 %                         | GMIS<br>Cylinder #    | Varian Model 1860<br>S/N None<br>Thermal Conductivity | 09/28/03           | 09/28/00<br>11.52 %<br>11.70 % |
| Nitrogen           | Balance                                   | CC50175               | Gas Chromatography                                    |                    | 11.60 %                        |
| Cylinder Pressure: | 2000 psig                                 | 0 25.69 %             | Last Cal Date: 09/27/00                               | Mean:              | 11.61 %                        |

ppm = umole/mole                      % = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

Analyst:

M.S. Calhoun

**Approved:**

**J.T. Marrin**

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

# BYRNE SPECIALTY GASES

601 10TH AND OVER STREET • SEATTLE, WASHINGTON 98108  
206.621.8400

E#R9Temp.

PO 2774 of 14  
For: BF Job #113  
F. JANE

## Certificate of Analysis: E.P.A. Protocol Gas Mixture

|                    |             |                  |              |
|--------------------|-------------|------------------|--------------|
| Customer:          | Airgas West | P.O.             | 700794/BYRNE |
| Cylinder No.:      | CC44545     | Order No.        | 538395-00    |
| Cylinder Pressure: | 2000        | Expiration Date: | 5/1/00       |
| Certification Date | 11/1/99     | Laboratory:      | LOS ANGELES  |

### Reference Standard Information:

|             |                  |                    |                      |
|-------------|------------------|--------------------|----------------------|
| <u>Type</u> | <u>Component</u> | <u>Cyl. Number</u> | <u>Concentration</u> |
| GMIS        | Sulfur Dioxide   | CC38281            | 51.1 PPM             |

### Instrumentation:

|                                    |                             |
|------------------------------------|-----------------------------|
| <u>Instrument/Model/Serial No.</u> | <u>Analytical Principle</u> |
| Seimens/Ultramat 5E                | NDIR                        |

Analytical Methodology does not require correction for analytical interferences.

### Certified Concentrations:

| Component      | Concentration | Accuracy | Procedure |
|----------------|---------------|----------|-----------|
| Sulfur Dioxide | 26.4 PPM      | +/-1%    | G1        |
| Nitrogen       | Balance       |          |           |

### Analytical Results:

#### 1st Component:

#### Sulfur Dioxide

1st Analysis Date: 10/25/99


|   |        |   |        |   |        |      |            |
|---|--------|---|--------|---|--------|------|------------|
| R | 98.000 | S | 50.800 | Z | 0.000  | Conc | 26.489 PPM |
| S | 50.800 | Z | 0.000  | R | 98.000 | Conc | 26.489 PPM |
| Z | 0.000  | R | 98.000 | S | 50.800 | Conc | 26.489 PPM |
|   |        |   |        |   |        | AVG: | 26.489 PPM |

2nd Analysis Date: 11/1/99

|   |        |   |        |   |        |      |            |
|---|--------|---|--------|---|--------|------|------------|
| R | 98.500 | S | 50.800 | Z | 0.000  | Conc | 26.354 PPM |
| S | 50.800 | Z | 0.000  | R | 98.500 | Conc | 26.354 PPM |
| Z | 0.000  | R | 98.500 | S | 50.800 | Conc | 26.354 PPM |
|   |        |   |        |   |        | AVG: | 26.354 PPM |

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.

Do not use cylinder below 150 psig.

  
Approved for Release

## Certificate of Analysis: E.P.A. Protocol Gas Mixture

|                    |                |                  |             |
|--------------------|----------------|------------------|-------------|
| Customer:          | Airgas Pacific | P.O.             | 94987       |
| Cylinder No.:      | CC66028        | Order No.        | 895310-00   |
| Cylinder Pressure: | 1900           | Expiration Date: | 1/22/01     |
| Certification Date | 7/22/00        | Laboratory:      | LOS ANGELES |

### Reference Standard Information:

| Type | Component      | Cyl. Number | Concentration |
|------|----------------|-------------|---------------|
| GMIS | Sulfur Dioxide | CC49561     | 50.6 PPM      |

### Instrumentation:

| Instrument/Model/Serial No. | Analytical Principle |
|-----------------------------|----------------------|
| Siemens/Ultramat 5E         | NDIR                 |

Analytical Methodology does not require correction for analytical interferences.

### Certified Concentrations:

| Component      | Concentration | Accuracy | Procedure |
|----------------|---------------|----------|-----------|
| Sulfur Dioxide | 9.39 PPM      | +/- 1%   | G1        |
| Nitrogen       | Balance       |          |           |

### Analytical Results:

#### 1st Component:

#### Sulfur Dioxide

1st Analysis Date: 7/15/00

|   |        |   |        |   |        |      |           |
|---|--------|---|--------|---|--------|------|-----------|
| R | 97.500 | S | 18.100 | Z | 0.000  | Conc | 9.393 PPM |
| S | 18.100 | Z | 0.000  | R | 97.500 | Conc | 9.393 PPM |
| Z | 0.000  | R | 97.500 | S | 18.100 | Conc | 9.393 PPM |
|   |        |   |        |   |        | AVG: | 9.393 PPM |


2nd Analysis Date: 7/22/00

|   |        |   |        |   |        |      |           |
|---|--------|---|--------|---|--------|------|-----------|
| R | 97.500 | S | 18.100 | Z | 0.000  | Conc | 9.393 PPM |
| S | 18.100 | Z | 0.000  | R | 97.500 | Conc | 9.393 PPM |
| Z | 0.000  | R | 97.500 | S | 18.100 | Conc | 9.393 PPM |
|   |        |   |        |   |        | AVG: | 9.393 PPM |

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.

Do not use cylinder below 150 psig.

Approved for Release



# Polar Cryogenics Inc.

■ Specialty Gas

■ Cryogenics

■ Bulk Gases

■ Liquid Helium

## Certificate of Analysis

A3

Customer: Horizon Engineering  
Product: Air  
Grade: Ultra Zero  
Cylinder Number: cc101218  
Lot Number: E3101302

5-31-2000

### Purity Analysis

| Component        | Specification    | Actual Concentration | Analytical Method |
|------------------|------------------|----------------------|-------------------|
| Air              | Ultra Zero grade | Ultra Zero grade     |                   |
| Oxygen           | <21 %            | 20.7%                | GC-TCD            |
| H <sub>2</sub> O | < 2.0 ppm        | 1.6 ppm              | Meeko Aquamatic   |
| THC              | < 0.1 ppm        | 0.01 ppm             | Varian GC/MS      |
| CO               | < 1.0 ppm        | 0.23 ppm             | Varian GC/MS      |
| CO <sub>2</sub>  | < 1.0 ppm        | 0.12 ppm             | Varian GC/MS      |
| NO               | < 0.1 ppm        | <0.1 ppm             | Varian GC/MS      |

I certify the above referenced cylinder was analyzed and found to contain the listed concentrations.

*Stephanie Dazer*  
Stephanie Dazer, Chemist

*5.31.00*  
Date

Shipping Address: 2734 SE Raymond ■ Portland, Oregon 97202

P.O. Box 82039 ■ Portland, Oregon 97282 ■ (503) 239-5252 ■ (800) 426-0689 ■ Fax (503) 236-0486

# Polar Cryogenics Inc.

■ Specialty Gas

■ Cryogenics

■ Bulk Gases

■ Liquid Helium

## Certificate of Analysis

26


Customer: Horizon Engineering  
Product: Nitrogen  
Grade: Zero, 99.998% Purity  
Cylinder Number: cc180290  
Lot Number: E08013

Date: 5-10-00

### Purity Analysis

| Component        | Specification | Actual Concentration | Analytical Method |
|------------------|---------------|----------------------|-------------------|
| Nitrogen         | 99.998 %      | >99.998%             | Difference        |
| H <sub>2</sub> O | < 5.0 ppm     | 0.8 ppm              | Meeko Tracer      |
| THC              | < 0.5 ppm     | 0.1 ppm              | Varian GC/MS      |
| CO               | < 1.0 ppm     | 0.3 ppm              | Varian GC/MS      |
| CO <sub>2</sub>  | < 1.0 ppm     | 0.1 ppm              | Varian GC/MS      |
| NO               | < 0.1 ppm     | < 0.1 ppm            | Varian GC/MS      |

I certify the above referenced cylinder was analyzed and found to contain the listed concentrations.

  
Stephanie Dazer, Chemist

5-10-00  
Date

Shipping Address: 2734 SE Raymond ■ Portland, Oregon 97202

P.O. Box 82039 ■ Portland, Oregon 97282 ■ (503) 239-5252 ■ (800) 426-0689 ■ Fax (503) 236-0486

01-22-01

# ANTECH

## Analysis/Technology

Mr. David Rossman  
HORIZON ENGINEERING  
13585 NE Whitaker  
Portland OR 97220

January 15, 2001  
Job# 0036402-04

Identification: OR-DEQ  
Received: 12/30/00 (Horizon # ?)

|                       |          |          |          |
|-----------------------|----------|----------|----------|
| <u>Sample #</u>       | 36402    | 36403    | 36404    |
| <u>Identification</u> | AMM1-113 | AML2-124 | FMH1-101 |

Aqueous nitric

Acid solution:


|                     |        |        |
|---------------------|--------|--------|
| <u>Volume (mls)</u> | 11.0   | 10.9   |
| <u>Residue (g)</u>  | 0.0023 | 0.0002 |

Filters:

|                    |          |
|--------------------|----------|
| <u>Number:</u>     | FMH1-101 |
| <u>Residue (g)</u> | 0.6087*  |

\*avg-no tare  
Weight available

Respectfully submitted:  
ANTECH

  
Diana Tracy, president

ANTECH

SAMPLE DATA: EPA RESIDUES

Analyst: mw reviewer: \_\_\_\_\_Job: 364 Identification: DR-DEB~~PP-10388-1~~ Aqueous nitric acid solution

|                 |                   |                   |                |                 |
|-----------------|-------------------|-------------------|----------------|-----------------|
| San plc #       | <u>36402</u>      | <u>36403</u>      | _____          | _____           |
| Sample ID       | <u>AMM1-113</u>   | <u>AML2-124</u>   | _____          | _____           |
| vol mark        | _____             | _____             | _____          | _____           |
| Date/time       | <u>1-1-01 9A</u>  | <u>1-1-01 9A</u>  | _____          | _____           |
| Into dessicator | _____             | _____             | _____          | _____           |
| Vol(mls)        | <u>11.0-2</u>     | <u>10.9-2</u>     | _____          | _____           |
|                 | date/time weighed | date/time weighed | _____          | _____           |
| GWt1(g)         | <u>111.7357</u>   | <u>1-2 9A</u>     | <u>87.9813</u> | <u>1-2 9A</u>   |
| GWt2(g)         | <u>111.7356</u>   | <u>1-3 9A</u>     | <u>87.9815</u> | <u>1-3 9A</u>   |
| GWt3(g)         | <u>111.7360</u>   | <u>1-5 9A</u>     | <u>87.9814</u> | <u>1-5 9A</u>   |
| GWt4(g)         | _____             | _____             | <u>87.9821</u> | <u>1-7 11A</u>  |
| GWt5(g)         | _____             | _____             | <u>87.9816</u> | <u>1-8 10A</u>  |
| GWt6(g)         | _____             | _____             | _____          | _____           |
| Average         | <u>111.7357</u>   | _____             | <u>87.9819</u> | _____           |
| Tare (g)        | <u>111.7334</u>   | <u>12-31 1P</u>   | <u>87.9817</u> | <u>12-31 1P</u> |
| Net (g)         | <u>.0023</u>      | _____             | <u>.0002</u>   | _____           |

BACK ACETONE.

|                 |       |                   |                   |                   |
|-----------------|-------|-------------------|-------------------|-------------------|
| Sample #        | _____ | _____             | _____             | _____             |
| Sample ID       | _____ | _____             | _____             | _____             |
| vol mark        | _____ | _____             | _____             | _____             |
| Date/time       | _____ | _____             | _____             | _____             |
| Into dessicator | _____ | _____             | _____             | _____             |
| Vol(mls)        | _____ | date/time weighed | date/time weighed | date/time weighed |
| GV t1(g)        | _____ | _____             | _____             | _____             |
| GWt2(g)         | _____ | _____             | _____             | _____             |
| GWt3(g)         | _____ | _____             | _____             | _____             |
| GWt4(g)         | _____ | _____             | _____             | _____             |
| GWt5(g)         | _____ | _____             | _____             | _____             |
| GWt6(g)         | _____ | _____             | _____             | _____             |
| Average         | _____ | _____             | _____             | _____             |
| Tare (g)        | _____ | _____             | _____             | _____             |
| Net (g)         | _____ | _____             | _____             | _____             |

ANTECH

SAMPLE DATA: EPA RESIDUES (page 3)

FILTERS:

Sample # 36404

Sample ID FMH 1-101

Date/time 12-29 9A

In dessicator

|                      | Date/time     | Date/time | Date/time |
|----------------------|---------------|-----------|-----------|
| GWt1(g) <u>.6106</u> | <u>1-2 9A</u> |           |           |
| GWt2(g) <u>.6093</u> | <u>1-3 9A</u> |           |           |
| GWt3(g) <u>.6088</u> | <u>1-4 8A</u> |           |           |
| GWt4(g) <u>.6086</u> | <u>1-5 9A</u> |           |           |
| Average <u>.6087</u> |               |           |           |

Tare (g) \*

Net (g)

FILTERS:

Sample #

Sample ID

Date/time

In dessicator

|                 | Date/time | Date/time | Date/time |
|-----------------|-----------|-----------|-----------|
| GWt1(g) <u></u> | <u></u>   | <u></u>   | <u></u>   |
| GWt2(g) <u></u> | <u></u>   | <u></u>   | <u></u>   |
| GWt3(g) <u></u> | <u></u>   | <u></u>   | <u></u>   |
| GWt4(g) <u></u> | <u></u>   | <u></u>   | <u></u>   |
| Average <u></u> | <u></u>   | <u></u>   | <u></u>   |

Tare (g)

Net (g)

QC DATA:

|                       | 1-2          | 1-3          | 1-4          | 1-5          | 1-7          | 1-8          |
|-----------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Date/time             | <u></u>      | <u></u>      | <u></u>      | <u></u>      | <u></u>      | <u></u>      |
| Balance calibrated    | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     |
| (NTIS cert wts)       | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     | <u>✓</u>     |
| Date/time             | <u>9A</u>    | <u>9A</u>    | <u>8A</u>    | <u>8A</u>    | <u>10A</u>   | <u>8A</u>    |
| Temp/temp             | <u>71/59</u> | <u>70/58</u> | <u>70/59</u> | <u>70/58</u> | <u>71/58</u> | <u>70/57</u> |
| Relative humidity (%) | <u>49</u>    | <u>48</u>    | <u>50</u>    | <u>48</u>    | <u>45</u>    | <u>44</u>    |

\* Allow me Tare wt in this letter - m

## Case Narrative

ESL Job: 0101063  
Run Batch: ICP\_010122C  
Prep Batch: 2273

January 25, 2001

The two Lead Spiked Aqueous Solution samples numbered 0036402 and 0036403 were brought in two 400ml beakers. The aqueous samples were evaporated off and only the residue was left in the beakers. The Audit directions for these samples requested 1:2 and 1:5 time dilutions respectively. Since the samples had gone dry, I brought them up to a volume of 10 ml of dilute Nitric Acid (as per the approximate initial volume) and then proceeded to perform the requested dilutions prior to running.

Please do not hesitate to call if there are any questions, or if we can be of further assistance in this project. Thank you.

Leslie Crow, Chemist

# Environmental Services Laboratory

Date: 25-Jan-01

CLIENT: Horizon Engineering  
Lab Order: 0101063  
Project: OSM-1536  
Lab ID: 0101063-11A

Client Sample ID: FMH1-101 (Filter)  
Tag Number:  
Collection Date: 1/11/01  
Matrix: SOLID

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 947    | 1.00      |      | ug    | 1  | 1/22/01       |

Qualifiers: ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
• - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

11 of 11

**Environmental Services Laboratory**

Date: 25-Jan-01

**CLIENT:** Horizon Engineering  
**Lab Order:** 0101063  
**Project:** OSM-1536  
**Lab ID:** 0101063-08A

**Client Sample ID:** 36402 H2O  
**Tag Number:**  
**Collection Date:** 1/11/01  
**Matrix:** AQUEOUS

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 21.6   | 0.00500   |      | ug/ml | 1  | 1/22/01       |

**Qualifiers:** ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
• - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

8 of 11

**Environmental Services Laboratory**

Date: 25-Jan-01

**CLIENT:** Horizon Engineering  
**Lab Order:** 0101063  
**Project:** OSM-1536  
**Lab ID:** 0101063-09A

**Client Sample ID:** 36403 H2O  
**Tag Number:**  
**Collection Date:** 1/11/01  
**Matrix:** AQUEOUS

| Analyses   | Result | Limit     | Qual | Units | DF | Date Analyzed |
|------------|--------|-----------|------|-------|----|---------------|
| ICP METALS |        | EPA 6010B |      |       |    | Analyst: lmc  |
| Lead       | 0.290  | 0.00500   |      | ug/ml | 1  | 1/22/01       |

**Qualifiers:** ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
• - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range

9 of 11

# CHAIN OF CUSTODY REPORT

**Work Order #**

[illegible]

0036406  
0101063-08 A

**Method 12 Compliance Audit Material  
(Lead Spiked Aqueous Solution)**

**REPORTING FORM:** To be completed by laboratory

Request Number/Sample Number: M12 - 0020 - 01 / AMM1 - 113 Date Issued: 12/06/00

Concentration Level: Medium

**Auditee:**

Company: Horizon Engineering, LLC

Address: 13585 NE Whitaker Way, Portland, OR, 97230

Attention of: Michelle Kinney Phone: (503) 255-5050

**Requestor:**

Agency: OR - DEQ

Address: 2020 SW 4th Street, Suite 400, Portland, OR, 97201

Attention of: Jack Herbert Phone: (503) 229-5579

**Project Name:** OR Steel Mills

**Audit Results (Results in  $\mu\text{g/mL}$ )**

| <u>Compound</u> | <u>Result</u>                           |
|-----------------|-----------------------------------------|
| Lead            | <u>21.6 <math>\mu\text{g/mL}</math></u> |

36903  
0101063-09A

**Method 12 Compliance Audit Material  
(Lead Spiked Aqueous Solution)**

**REPORTING FORM:** To be completed by laboratory

Request Number/Sample Number: M12 - 0020 - 02 / AML2 - 124 Date Issued: 12/06/00

Concentration Level: Low

**Auditee:**

Company: Horizon Engineering, LLC

Address: 13585 NE Whitaker Way, Portland, OR, 97230

Attention of: Michelle Kinney Phone: (503) 255-5050

**Requestor:**

Agency: OR - DEQ

Address: 2020 SW 4th Street, Suite 400, Portland, OR, 97201

Attention of: Jack Herbert Phone: (503) 229-5579

**Project Name:** OR Steel Mills

**Audit Results (Results in  $\mu\text{g/mL}$ )**

| <u>Compound</u> | <u>Result</u>                           |
|-----------------|-----------------------------------------|
| Lead            | <u>0.29 <math>\mu\text{g/mL}</math></u> |

0036404  
0101063-10A

**Method 12 Compliance Audit Material  
(Lead Spiked Filter)**

**REPORTING FORM:** To be completed by laboratory

Request Number/Sample Number: M12 - 0017 - 01 / FMH1 - 101 Date Issued: 12/06/00

Concentration Level: High1

**Auditee:**

Company: Horizon Engineering, LLC

Address: 13585 NE Whitaker Way, Portland, OR, 97230

Attention of: Michelle Kinney Phone: (503) 255-5050

**Requestor:**

Agency: OR - DEQ

Address: 2020 SW 4th Street, Suite 400, Portland, OR, 97201

Attention of: Jack Herbert Phone: (503) 229-5579

**Project Name:** OR Steel Mills

**Audit Results (Results in µg)**

| <u>Compound</u> | <u>Result</u> |
|-----------------|---------------|
| Lead            | <u>947 µg</u> |

Debbie Deetz Silva, David R Rossman, and C David Bagwell  
 December 22, 2000  
 Page 2

The three tests earlier this year found 10 to 700 ppm carbon monoxide, 19.8 to 20.6 percent oxygen, and 0.1 to 1.8 percent carbon dioxide.

For carbon monoxide, accurate calibrations from about 20 to about 300 or 500 ppmv have been important to obtain accurate total emissions. Horizon's analyzer with two ranges seems capable of giving more reliable calibrations over this entire range of significant emissions than a single upscale calibration would. You would need to measure the analyzer linearity and the system bias of each range.

With one carbon-monoxide range, corrected low readings should be similar with low or high upscale calgases. Please check upscale system biases with a low level (20 to 50 ppmv) and a high level (probably 200 to 500 ppmv, or as high as necessary). Check linearity with three suitable non-zero calgases.

3. The EPA Emission Measurement Center has sent lead audit samples to Horizon Engineering. Send the lead audit samples with the field samples to your two laboratories for side-by-side processing. **The laboratory that measures particulate samples must accurately report each audit-solution volume. The audit is of the lead concentration.** The volumes are about 10 mL -- about five percent of field-rinse volumes. Total lead may also be much smaller.

4. The laboratory performing lead analyses should record how they treat samples and perform quality control. Section 8 in your plan identifies essential quality control.
5. Leak checks and system bias checks are before and after each run. See Section 6.
6. Reports include field charts of analyzer readings. Please change Section 6.
7. Oregon Steel Mills is to document any significant furnace production delays.
8. Oregon Steel Mills is to send me one (1) test report within seventy-five (75) days after testing.

Please call me at 503-229-5579 if you have questions or change the test schedule or plan. My fax number is 229-5265. [Herbert.jack@deq.state.or.us](mailto:Herbert.jack@deq.state.or.us) is my email address.

Sincerely,



Jack Herbert  
 Source Testing Coordinator

JHH

c: Greg Grunow:NWR

*Diana,  
 J.H. wants  
 you to  
 dry how  
 the dip  
 audit is  
 just as you  
 do for the  
 test sample  
 leave it  
 to rotate  
 to  
 H. H.  
 Call in  
 G. H.*

**QUALITY ASSURANCE AND  
QUALITY CONTROL DOCUMENTATION**

**Introduction** The QA procedures outlined in the U. S. Environmental Protection Agency (EPA) test methods are followed, including procedures, equipment specifications, calibrations, *sample extraction and handling*, calculations, and performance tolerances. Many of the checks performed have been cited in the Sampling section of the report text. The results of those checks are on the applicable field data sheets in the Appendix.

**Continuous Analyzer Methods** Field crews operate the continuous analyzers according to the test method requirements, and Horizon's additional specifications. On site quality control procedures include:

- calibrations with EPA Protocol 1 gases or NIST traceable gases
- pre-test zero and span checks and linearity test
- bias checks (introducing calibration gas as near to the probe tip as possible)
- calibration error (linearity) checks if any analyzer adjustments are made
- leak checks on the gas sampling system
- correction of problems that show up as the results of checks
- strip chart recordings for backup to the electronic data acquisition system

**Manual Equipment QC Procedures** On site quality control procedures include pre- and post-test leak checks on trains and pitot systems. If pre-test checks indicate problems, the system is fixed and rechecked before starting testing. If post-test leak checks are not acceptable, the test run is voided and the run is repeated. Thermocouples and readouts are verified in the field to read ambient prior to the start of any heating or cooling devices. Nozzles are checked for nicks or dents and are measured on three diameters twice each year.

**Sample Handling** Samples taken during testing are handled to prevent contamination from other runs and ambient conditions. Sample containers are glass, Teflon™, or polystyrene (filter petri dishes) and are pre-cleaned by the laboratory and in the Horizon Engineering shop. Sample levels are marked on containers and are verified by the laboratory. All particulate sample containers are kept upright and are delivered to the laboratory by Horizon personnel.

**Data Processing** Personnel performing data processing double-check that data entry and calculations are correct. Results include corrections for field blanks and analyzer drift. Any abnormal values are verified with testing personnel and the laboratory, if necessary.

After results are obtained, the data processing supervisor validates the data with the following actions:

- verify data entry
- check for variability within replicate runs
- account for variability that is not within performance goals (check the method, testing, and operation of the plant)
- verify field quality checks

**Equipment Calibrations** Periodic calibrations are performed on each piece of measurement equipment according to manufacturers' specifications and applicable test method requirements. The Oregon Department of Environmental Quality (ODEQ) Source Testing Calibration Requirements sheet is used as a guideline. Calibrations are performed using primary standard references and calibration curves where applicable.

**Thermocouples** Thermocouples are calibration checked against an NIST traceable thermocouple and indicator system every six months at three points. Thermocouple indicators and temperature controllers are checked using a NIST traceable signal generator. Readouts are checked over their usable range and are adjusted if necessary (which is very unusual).

**Pitots** Every six months, S-type pitots are checked for misalignment, angles, lengths, and proximity to thermocouples. They are then calibrated in a wind tunnel at four points against a standard pitot using inclined manometers. They are examined for dents or distortion before each test. Pitots are protected with covers during storage and handling until they are ready to be inserted in the sample ports.

**Dry Gas Meters** Dry gas meters used in the manual sampling trains are calibrated at five rates using a standard dry gas meter that is never taken into the field. The standard meter is calibration verified by the Northwest Natural Gas meter shop once every year. Dry gas meters are post-test calibrated with documentation provided in test reports.

**High Volume Sampler Orifice** The orifice for the High Volume sampler is calibrated annually against a positive displacement (Roots type) flow meter, two or more trials at six flow rates. The Roots meter came with a manufacturer's calibration curve and has been calibration checked by the Northwest Natural Gas meter shop.

## **CORRESPONDENCE**

Source Test Plan and Correspondence  
Permit (Selected Pages)



13585 N.E. Whitaker Way • Portland, OR 97230  
Phone (503)255-5050 • Fax (503)255-0505  
horizone@teleport.com

FAXED  
12/13/2000

December 13, 2000

Mr. Jack Herbert  
Oregon Department of Environmental Quality  
2020 SW 4<sup>th</sup>, Suite #400  
Portland, OR 97201-4987

Re: Source Testing: Oregon Steel Mills  
Portland, OR

This correspondence is notice that Horizon Engineering is to do source testing for the above-referenced facility, scheduled for December 27, 2000. This will serve as the Source Test Plan unless changes are requested prior to the start of testing.

1. **Source(s) to be Tested:** Electric Arc Furnace (EAF) Baghouse.
2. **Purpose of the Testing:** Emission factor verification as required by Title V Permit No. 26-1865.
3. **Source Description:** 16-compartment baghouse controlling particulate emissions from the EAF.
4. **Pollutants to be Tested:** Total Suspended Particulate (TSP), CO, NO<sub>x</sub>, SO<sub>2</sub>, Lead, VOC and Opacity.
5. **Test Methods to be Used:** Testing will be conducted in accordance with EPA Methods in Title 40 Code of Federal Regulations Part 60 (40 CFR 60), Appendix A, July 1, 1999; and Oregon Department of Environmental Quality (ODEQ) methods in Source Sampling Manual Volume 1, January 1992.

|                                      |                                                                                                                                                               |
|--------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Flow Rate:                           | EPA Methods 1 and 2 (S-type pitot flow traverses)                                                                                                             |
| CO <sub>2</sub> and O <sub>2</sub> : | EPA Method 3A (NDIR and paramagnetic analyzers)                                                                                                               |
| Moisture:                            | ODEQ Method 4 (psychrometry – wet bulb / dry bulb)                                                                                                            |
| SO <sub>2</sub> :                    | EPA Method 6C (non-dispersive ultraviolet analyzer)                                                                                                           |
| NO <sub>x</sub> :                    | EPA Method 7E (chemiluminescent analyzer)                                                                                                                     |
| Particulate:                         | ODEQ Method 8 (High Volume sampler)                                                                                                                           |
| Opacity:                             | EPA Method 9 (six minutes per run)                                                                                                                            |
| CO:                                  | EPA Method 10 (gas filter correlation analyzer)                                                                                                               |
| Lead:                                | Analysis of the filters and sampler residue for lead.<br>Residue allocated to the runs according to Method 8<br>procedure 11.2.1. Analysis by EPA 6010 (ICP). |
| VOC (TGOC):                          | VOC as total gaseous organic compounds (TGOC) by<br>EPA Method 25A, (heated flame ionization analyzer and<br>sample line)                                     |

6. **Continuous Analyzer Data Recording:** Data acquisition system (DAS) with strip chart records as backup. Either 10-second data points or one-minute averages of one-second readings are logged. Normally only run averages and the graphic outputs from the DAS are included in the test reports.
7. **Continuous Analyzer Gas Sampling:** Fixed point in the baghouse inlet.
8. **Quality Assurance /Quality Control (QA/QC):** Documentation of the procedures and results will be presented in the source test report for review. This documentation will include at least the following:

Continuous Analyzer QC Procedures: Field crews will operate the analyzers according to the manufacturer's specification, the test method's requirements, and Horizon's additional specifications. On-site quality control procedures include:

- daily calibration (zero and span) and calibration error (linearity) checks
- pre- and post-test zero bias and span bias checks
- checks performed with EPA Protocol 1 or NIST traceable gases
- data acquisition systems record 10-second data points or one-minute averages of one second readings
- strip chart recordings taken for backup to the electronic data acquisition system

Manual Equipment QC Procedures: Operators will perform pre- and post-test leak checks on the sampling system and pitot lines. Thermocouple systems are checked for ambient temperature before heaters are started. Nozzles and pitots are inspected for nicks or dents before each test. Pre- and post-test calibrations on the meter boxes will be included with the report, along with semi-annual calibrations on the pitots, thermocouples, and nozzles. Blank reagents (water, acetone and filter) are submitted to the laboratory with the samples. Liquid levels are marked on sample jars in the field and are verified by the laboratory.

Laboratory QC Procedures: EPA audit samples for lead will be analyzed with the field samples. The Laboratory will perform normal laboratory QC procedures. The Laboratory will follow EPA Method 12 with special attention to sections 11.2.1: digestion of complete filter, 11.2.4 and 11.2.5: field blanks, one solvent and two filters, 11.4.1: sample concentrations brought into the linear analytical range, and 11.5: a single spike, method-of-standard-additions recovery check. Also the particulate filter tare weights will be weighed to a constant weight and the records submitted with the final report.

9. **Number of Sampling Replicates and their Duration:** Three (3): Each Oregon Method 8 run will be during two complete furnace heat cycles. Gaseous sampling will be continuous through all of the particulate testing. Opacity tests will be a minimum of 6 minutes with 24 observations during each TSP run while furnace is in melting and refining mode. Inlet duct flow measurements shall be made before the first and after the third Oregon Method 8 test. Baghouse outlet flow measurements will be made three times, measuring five points through the sampling port on each compartment outlet (five points per compartment). In no case will sampling replicates be separated by a time duration of twenty-four (24) or more hours unless prior authorization is granted by the Department.

10. **Reporting Units for Results:** Particulate – gr/dscf, lb/hr, and lb/ton cold charge. Gases – ppmv, lb/hr, and lb/ton cold charge.

11. **Horizon Engrg. Contacts:** David Rossman or  
David Bagwell  
(503) 255-5050  
Fax (503) 255-0505

12. **Source Site Personnel:** Debbie Deetz Silva  
(503) 978-6044  
Fax (503) 240-5775

13. **Regulatory Contacts:** Jack Herbert  
(503) 229-5579  
Fax (503) 229-5265

14. **Applicable Process/Production Information:** Process operating data and production information that characterizes the source operation is considered to be: Heat charge weights and materials, tap weights and materials, heat times. Process information is normally gathered by the Source-site personnel and provided to Horizon for inclusion in the report.

The source must operate at a normal maximum rate during testing. Rates not in agreement with those stipulated in the Permit can result in test rejection for application to determine emission factor verification. Imposed process limitations could also result from atypical rates.

15. **Control Device Operating Parameters:** Baghouse pressure drops.

16. **Opacity Readings to be Taken By:** Horizon Engineering

17. **Certified Plume Evaluator:** Yes (x) No ( ) N/A ( )

18. **Other Process Considerations,** including sampling site configurations, equipment limitations, special methods, etc.:

Particulate: Each Oregon Method 8 test shall encompass two complete heat cycles with samples collected for 5 minutes from as many as possible of the 16 compartments. The next test shall begin in the next compartment after the final compartment sampled in the previous test. Particulate is to be sampled in the gas stream above the bags in the slot shaped area where gas flows up and toward the center of the baghouse. This allows the sampler nozzle to be inserted through ports in the ceiling of the breezeway at the top of the baghouse. As in the past, sampling will be isokinetic at a single point at the outlet of each compartment.

Flow Rate Measurements: Velocities will be measured at five points through each port, giving 5 velocities per compartment, 80 points for the baghouse. Velocity pressure determinations will be by use of an S-type pitot and a micro-manometer. Past testing has shown that traversing this single port adequately characterizes the outlet flow rate.

Gaseous Pollutant Measurements: Gas analyzer readings at the baghouse inlet will be continuous through all of the M-8 tests.

Timing: The testers will synchronize their watches to record times in sync with the OSM heat log in the arc furnace control pulpit.


19. **Administrative:** Unless notified prior to the start of testing, this test plan is considered approved for compliance testing of this source. A letter acknowledging receipt of this plan and agreement on the content (or changes as necessary) would be appreciated.

The Department will be notified of any changes in source test plans prior to testing. It is recognized that significant changes not acknowledged, which could affect accuracy and reliability of the results, could result in test report rejection.

Source test reports will be prepared by Horizon Engineering and will include all results and example calculations, field sampling and data reduction procedures, laboratory analysis reports, and QA/QC documentation. Source test reports will be submitted to you within 75 days of the completion of the field work, unless another deadline has been stipulated. Oregon Steel Mills will send two (2) copies of the completed Source Test Report to you at the address above.

Any questions or comments relating to this test plan should be directed to me.

Sincerely,



Emily U. Bagwell,  
Project Coordinator

cc: Debbie Deetz Silva, Oregon Steel Mills



# Oregon

John A. Kitzhaber, M.D., Governor

Oregon Steel Mills, Inc  
Attn: Debbie Deetz Silva  
PO Box 2760  
Portland, Oregon 97208

Horizon Engineering  
Attn: David R Rossman and David Bagwell  
13585 NE Whitaker Way  
Portland, Oregon 97230

## Department of Environmental Quality

December 22, 2000

Northwest Region  
2020 SW Fourth Avenue  
Suite 400  
Portland, OR 97201-4987  
(503) 229-5263 Voice  
TTY (503) 229-5471

Re: AQ Multnomah County  
Title V Permit No 26-1865  
Oregon Steel Mills  
Source-test plan for electric-arc and  
ladle-metallurgy furnaces' annual  
baghouse tests for emission-factor  
verification and PM and SO<sub>2</sub>  
concentrations' compliance

Dear Ms Silva and Messrs Rossman and Bagwell:

On December 13, 2000, I received your test plan for Oregon Steel Mills' ICA baghouse's emissions. The test will measure particulate, lead, and visible emissions from the baghouse and carbon-monoxide, nitrogen-oxide, sulfur-dioxide, volatile-organic-compounds emissions in the baghouse inlet. You will calculate emission factors based on cold charges to the electric-arc furnace. You will test compliance of filterable-particulate and sulfur-dioxide concentrations. You plan to test on December 27, 2000.

Oregon Steel Mills' Title V Operating Permit' Conditions require annual emissions tests:

37. Verify emission factors for filterable particulate matter, lead, carbon monoxide, nitrogen oxides, and volatile organic compounds.
38. Measure filterable particulate grain loading.
39. Measure sulfur-dioxide concentrations, at least during the permit's first two years.

I approve your test plan with these conditions:

1. Use analyzer ranges corresponding closely to expected measurements.
2. Use non-zero calibration concentrations bracketing measurements as much as possible. As we discussed, these may deviate from published methods' instructions. To address your concern in this matter, I contacted Paul Boys of EPA's Region-10 office. He agreed that this was within the Department's authority and that we (the Department) may require and approve such modifications to published test methods.



The three tests earlier this year found 10 to 700 ppm carbon monoxide, 19.8 to 20.6 percent oxygen, and 0.1 to 1.8 percent carbon dioxide.


For carbon monoxide, accurate calibrations from about 20 to about 300 or 500 ppmv have been important to obtain accurate total emissions. Horizon's analyzer with two ranges seems capable of giving more reliable calibrations over this entire range of significant emissions than a single upscale calibration would. You would need to measure the analyzer linearity and the system bias of each range.

With one carbon-monoxide range, corrected low readings should be similar with low or high upscale calgases. Please check upscale system biases with a low level (20 to 50 ppmv) and a high level (probably 200 to 500 ppmv, or as high as necessary). Check linearity with three suitable non-zero calgases.

3. The EPA Emission Measurement Center has sent lead audit samples to Horizon Engineering. Send the lead audit samples with the field samples to your two laboratories for side-by-side processing. **The laboratory that measures particulate samples must accurately report each audit-solution volume. The audit is of the lead concentration.** The volumes are about 10 mL -- about five percent of field-rinse volumes. Total lead may also be much smaller.
4. The laboratory performing lead analyses should record how they treat samples and perform quality control. Section 8 in your plan identifies essential quality control.
5. Leak checks and system bias checks are before and after each run. See Section 6.
6. Reports include field charts of analyzer readings. Please change Section 6.
7. Oregon Steel Mills is to document any significant furnace production delays.
8. Oregon Steel Mills is to send me one (1) test report within seventy-five (75) days after testing.

Please call me at 503-229-5579 if you have questions or change the test schedule or plan. My fax number is 229-5265. [Herbert.jack@deq.state.or.us](mailto:Herbert.jack@deq.state.or.us) is my email address.

Sincerely,



Jack Herbert  
Source Testing Coordinator

JHH

c: Greg Grunow:NWR

37. The permittee shall conduct emission factor verification tests in accordance with the Department's Source Sampling Manual for the following: PM/PM<sub>10</sub>, CO, NO<sub>x</sub>, VOC and Pb emission factors listed for emissions units EU-4, EU-5, EU-7, EU-8 and EU-10 and monitoring points CDP-1, CDP-2, CDP-4, CDP-5 and CDP-7 in condition 36.c using the following test methods and minimum test frequencies, unless otherwise approved in writing by the Department:

| Monitoring Point | Pollutant           | Test Method    | Minimum Frequency      |
|------------------|---------------------|----------------|------------------------|
| CDP-1 (EU-4)     | PM/PM <sub>10</sub> | ODEQ Method 8  | Annual                 |
|                  | CO                  | EPA Method 10  | Annual                 |
|                  | NO <sub>x</sub>     | EPA Method 7E  | Annual                 |
|                  | VOC                 | EPA Method 25A | Annual                 |
|                  | Pb                  | EPA Method 12* | Annual                 |
| CDP-2(EU-5)      | CO                  | EPA Method 10  | 1 time per permit term |
|                  | NO <sub>x</sub>     | EPA Method 7E  | 1 time per permit term |
| CDP-4 (EU-7)     | PM/PM <sub>10</sub> | ODEQ Method 8  | 1 time per permit term |
| CDP-5 (EU-8)     | PM/PM <sub>10</sub> | ODEQ Method 8  | 1 time per permit term |
| CDP-7 (EU-10)    | CO                  | EPA Method 10  | Annual                 |
|                  | NO <sub>x</sub>     | EPA Method 7E  | Annual                 |
|                  | VOC                 | EPA Method 25A | 1 time per permit term |

Note: All PM emissions are assumed to be PM<sub>10</sub> for this permit.

\* modified by sampling according to ODEQ method 8

For CDP-1, CDP-4 and CDP-5 flow rate must be measured according to EPA methods 1, 2, 3, or 3A, and ODEQ method 4. For CDP-2 flow rates must be measured using EPA methods 1, 2, 3, or 3A, ODEQ method 4, and EPA method 19. For CDP-7 flow rates must be measured using EPA methods 1, 2, 3, or 3A, and EPA method 19.

- 37.a. When more than one test is required during the permit term, the tests shall be separated by a minimum period of ten (10) months.
- 37.b. The testing required in condition 38 may be used to satisfy this requirement in part.
- 37.c. The permittee shall notify the Department at least 15 days prior to conducting any emission factor verification tests by submitting a source test plan in accordance with the Department's Source Sampling Manual. The permittee is not required to submit a source test plan if a plan has already been approved for the emissions unit and the pollutant to be tested. Notification of the proposed source test is required even if a plan is not needed.
- 37.d. The permittee shall submit a summary of all emission factor verification tests to the Department within 75 days of any test. The summary shall include the following information:
- 37.d.i. Emissions unit and monitoring point identification;
  - 37.d.ii. Emission results in pounds per hour and in units of emission factor;
  - 37.d.iii. Process parameters during the test (e.g. material throughput, types and amounts of fuels, heat input, etc.); and
  - 37.d.iv. Control device operating parameters.
- 37.e. The emissions factors listed in condition 36.c are not enforceable limits unless otherwise specified in this permit. Compliance with PSELs shall only be determined by the calculations contained in condition 36.b of this permit using the monitored parameters recorded during the reporting period in condition 36.a and the emission factors contained in condition 36.c.

**TEST METHODS AND PROCEDURES [OAR 340-218-0050(1)]**

38. The following procedures and test methods shall be used to conduct monitoring pertaining to condition 13 limiting particulate grain loading for EU-4 from compliance demonstration point CDP-4.1, for EU-7 from compliance demonstration point CDP-7.1, and for EU-8 from compliance demonstration point CDP 8.1;
- 38.a. All source testing shall be performed in accordance with the Department's Source Sampling Manual and the source test plan submitted to the Department prior to the scheduled test.
  - 38.b. Unless otherwise approved by the Department, ODEQ Method 8 shall be used to measure PM emissions. EPA Methods 1, 2, 3 or 3A and ODEQ method 4 shall be used to determine the volumetric flow rate during each ODEQ Method 8 test run.
  - 38.c. During each test for EU-4, the permittee shall record the following information:
    - 38.c.i. date and time of each furnace tap;
    - 38.c.ii. total tons of scrap charged in each heat;
    - 38.c.iii. baghouse operating parameters; and
    - 38.c.iv. any significant furnace production delays.
  - 38.d. During each test for EU-7 and 8, the permittee shall record the following information:
    - 38.d.i. Process parameters; and
    - 38.d.ii. baghouse operating parameters; and
  - 38.e. The arithmetic average of at least 3 test runs shall be used.
  - 38.f. Source testing shall be performed at compliance demonstration point CDP-4.1 (EU-4) annually. Source testing shall be performed at compliance demonstration points CDP-7.1 (EU-7) and CDP-8.1 (EU-8) once per permit term.
  - 38.g. The Department shall be notified, in writing, at least 15 days prior to any source test. The written notification shall include an identification of the testing company performing the tests, if other than the permittee and the testing protocol if not on file with the Department or changed since the last source test.
39. The following procedures and test methods shall be used to conduct monitoring pertaining to condition 15 limiting the SO<sub>2</sub> concentration for EU-4 from compliance demonstration point CDP-1; This condition is State-only enforceable.
- 39.a. All source testing shall be performed in accordance with the Department's Source Sampling Manual and the source test plan submitted to the Department prior to the scheduled test.
  - 39.b. Unless otherwise approved by the Department, EPA Method 6C shall be used to measure the SO<sub>2</sub> concentration. EPA Methods 1 and 2 shall be used to determine the volumetric flow rate, and ODEQ method 4 to determine moisture, during each EPA Method 6C test run.
  - 39.c. During each test, the permittee shall record the following information:
    - 39.c.i. date and time of each furnace tap;
    - 39.c.ii. total tons of scrap charged in each heat;

- 39.c.iii. baghouse operating parameters; and
- 39.c.iv. any significant furnace production delays.

39.d. The arithmetic average of at least 3 test runs shall be used.

39.e. Source testing shall be performed at compliance demonstration point CDP-1 (EU-4) annually. If two consecutive source test results indicate emissions are below 75% of the specified limit, no further testing is required for that emissions unit/pollutant combination for the remaining duration of this permit. The permittee may use the last source tests conducted on each of the emission points as one of the required consecutive tests, if they were conducted during the 1998 calendar year or after and are considered valid tests by the Department, to comply with this condition.

39.f. The Department shall be notified, in writing, at least 15 days prior to any source test. The written notification shall include an identification of the testing company performing the tests, if other than the permittee and the testing protocol if not on file with the Department or changed since the last source test.

40. Although source testing is not required by this permit for the permit conditions listed below, if testing is conducted in addition to the monitoring specified in this permit, the permittee shall use the following test methods and averaging times to measure the pollutant emissions:

| Permit Condition       | Test Method                                                                      | Averaging Time                                                                                                                            | Special Conditions                                                                                                                                                                                                                                                                                                                                                      |
|------------------------|----------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 19, 20                 | Modified EPA Method 9 in accordance with the Department's Source Sampling Manual | aggregate of three minutes in any 60 minute period for condition 19; aggregate of thirty seconds in any 60 minute period for condition 20 | Each Method 9 observation shall represent a period of 15 seconds for the purpose of determining the aggregate amount of time in a 60 minute period that the visible emissions are greater than the opacity limit. The test duration may be less than 60 minutes if a violation of the standard is documented before the full 60 minute observation period is completed. |
| 11, 12, 13, 18, 21, 22 | ODEQ Methods 5, 7, or 8                                                          | average of three one-hour test runs                                                                                                       | ODEQ Method 8 is for sources with exhaust gases at essentially ambient conditions (e.g. material handling cyclones); ODEQ Method 7 is for direct contact combustion sources (e.g. particle and veneer dryers); ODEQ Method 5 is for indirect contact fuel burning equipment (e.g. boilers) and any other source.                                                        |

All testing shall be conducted in accordance with the Department's Source Sampling Manual unless otherwise specified in the special conditions column of the table above.

#### RECORDKEEPING REQUIREMENTS [OAR 340-218-050(3)(B)]

41. The permittee shall maintain the following general records of required monitoring information:

- 41.a. the date, place as defined in the permit, and time of sampling or measurements;
- 41.b. the date(s) analyses were performed;
- 41.c. the company or entity that performed the analyses;
- 41.d. the analytical techniques or methods used;