

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP32 Section:	12.5.1
Background Chapter	3
Reference:	43
Title:	Stack test report summary sheets for IPSCO Steel, Mobile, AL. Testing conducted on October 2, 2001. Received from Doug Carr, Alabama Department of Environmental Management on April 10, 2002.

Stack Test Report

Report generated on 11/05/2001

Facility Name: IPSCO Steel

Facility Number: 503-8065 X001

Source Name: Electric Arc Furnace

Title V?: Yes Test Date: 10/02/2001

Source Information

Pollutants	Allowables	Regulations	Subpart/Chapter
PM	0.0052 gr/dscf	NSPS	AAa
Opacity	3%	NSPS	AAa

ESB inspector: DKC

Signature: 

Date: 11-8-01

Observation Information

Test Methods: 5, 6c, 9

Test Company: AAS

Initial Test?: Yes

EMS Observer: KF

ESB Observer: DKC

Activity: STACK TEST

Evaluation Information

Report Received by ADEM:

Evaluator:

Report Submitted to EMS:

Date Evaluation Finished

Pollutant	Run #1	Run #2	Run #3	Average	Units
PM	.0004	.0004	.0002	.0003	gr/dscf
SO ₂	0.2300	0.5800	0.4000	0.4049	lb/Ton
SO ₂	34.1582	95.6486	60.3406	63.3825	lb/Hr

Baghouse VE 0.0%

Meltshop VE 3.3%

D.H.S. VE 0.0%

Signature: 

Date: 11-08-01

FACILITY NAME: IPSCO
FACILITY NUMBER: 503-8065-X001
EVALUATION BY: KF

TEST DATE: 10/02/01
TESTED BY: AAS
EVAL. DATE: 11/08/2001

METHOD 6C - SULFUR DIOXIDE EMISSIONS

MONITOR SPAN = 25

RANGE	Cyl. (ppm)	Mon. (ppm)	% OF SPAN
ZERO	0	-0.03	0.12%
MID	12.07	12.13	0.24%
HIGH	24.8	24.80	0.00%
ZERO	0	-0.22	0.88%
MID	12.07	12.36	1.16%
HIGH	24.8	24.63	0.68%

RECAL

< 2% Allowable Calibration Error
< 3% Allowable Drift
< 5% Allowable System Bias

RUN	UPSCALE					ZERO				
	INITIAL SYSTEM RESPONSE (ppm)	INITIAL BIAS (% OF SPAN)	FINAL SYSTEM RESPONSE (ppm)	FINAL BIAS (% OF SPAN)	MONITOR DRIFT (% OF SPAN)	INITIAL SYSTEM RESPONSE (ppm)	INITIAL BIAS (% OF SPAN)	FINAL SYSTEM RESPONSE (ppm)	FINAL BIAS (% OF SPAN)	MONITOR DRIFT (% OF SPAN)
1	12.13	0.0%	11.84	1.2%	1.2%	-0.03	0.00%	0.01	0.16%	0.16%
2	12.36	0.0%	12.33	0.1%	0.1%	-0.22	0.00%	-0.07	0.60%	0.60%
3	12.33	0.1%	12.06	1.2%	1.1%	-0.07	0.60%	-0.19	0.12%	0.48%

EMISSIONS

AVG

RUN #	1	2	3	AVG
Cs	3.68	10.94	6.89	5.29 PPM
Cs (CORR)	3.71	10.71	6.87	2.00 PPM

FLOW RATE (FROM FLOW SHEET)	923639.0	896476.0	881237.0	900450.7 DSCFM
PRODUCTION	149.40	164.50	149.10	154.33 TONS/HR
MASS RATE	34.1582	95.6486	60.3406	63.3825 LB/HR
EMISSIONS	0.23	0.58	0.40	0.4049 LB/TON

COMPANY: IPSCO STEEL
 FAC NO: 503-8065-X001
 EVAL. BY: KF
 SOURCE: ELECTRIC ARC FURNACE

TEST DATE: 10/02-03/01
 TESTED BY: AAS
 EVAL. DATE: 11/06/01

RUN #	1	2	3
Start Time	1507	750	1359
F FACTOR			
$\Delta H(^{\circ}H_2O)$	0.998	1.331	1.283
SQRT Δp	0.623	0.601	0.590
tm	95	99	104
ts	176	173	170
Pb	29.85	29.97	29.97
Ps	29.83	29.95	29.95
Vm	166.894	206.534	190.625
Y	0.994	0.994	0.994
%CO2	0.0	0.0	0.0
%O2	20.9	20.9	20.9
%CO	0.00	0.00	0.00
Vlc (ml)	62.9	70.4	65.7
Mn (mg) PM	3.60	5.50	2.80
Cp	0.840	0.840	0.840
As (sqft)	490.87	490.87	490.87
dn	0.246	0.269	0.269
time	260.0	292.0	270.0

	RUN 1	RUN 2	RUN 3	AVERAGE
An	3.30E-04	3.95E-04	3.95E-04	
Pm	29.92	30.07	30.06	
Md	28.84	28.84	28.84	
Vwstd	2.961	3.314	3.092	
Vmstd	157.805	194.860	178.045	
Bws	1.8	1.7	1.7	
Bws THEO.	46.0	43.1	40.3	%
Bws MEAS.	1.8	1.7	1.7	%
Ms	28.64	28.65	28.65	%
vs	38.6	37.1	36.3	37.3 fps
Q	1135969	1091421	1068332	1098574 acf/m
Qstd	923639	896476	881237	900451 sdcf/m
vn	194.160	237.329	215.932	

% ISOKINETIC	98	93	93	
Cs	0.0004	0.0004	0.0002	0.0003 gr/sdcf
PMR	2.7814	3.3400	1.8293	2.6502 #/hr