

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 12.15

Background Chapter: 4

Reference Number: 18

Title: Test Report, Lead Emission Rate for
COS Line #3, Johnson Controls, Inc.,
Tampa, FL

PACE Laboratories, Inc.

1988

Not NSPS
(4)

TEST REPORT

LEAD EMISSION RATE

COS Line #3
10215 North 30th Street
Tampa, Florida 33687

Test Date: February 10, 1988

Project Number: 280215.401

Report Prepared for:

Johnson Controls, Inc.
P. O. Box 16068
Tampa, Florida 33687

Report Prepared by:

PACE Laboratories, Inc.
5460 Beaumont Center Boulevard
Tampa, Florida 33634

March 7, 1988

TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>
1.0	Test Summary
2.0	Source and Process Description
3.0	Methodology
4.0	Test Data and Calculations Test Nomenclature
5.0	Opacity
Appendix A	Calibration Data
Appendix B	Process Rate Data

SECTION 1.0

TEST SUMMARY

On February 10, 1988, PACE Laboratories, Inc. conducted Lead emissions tests at Johnson Controls, Inc., Globe Battery Division, 10215 North 30th Street, Tampa, Florida. Tests were conducted on the COS Line #3 (S/N 134A).

Test team personnel for this test include:

Thomas A. Jackman, Ph.D.	Technical Director
Timothy M. O'Dell	Project Manager
Michael C. Jackman	Team Leader & VE Observer
James E. Franklin	Technician


The results of the Lead emissions tests are summarized in the following table.

Date	Operation	Parameter	Actual Emission Rate*
2/10/88	COS Line #3	Lead	7.97×10^{-5}
2/10/88	COS Line #3	Opacity	0

• = gr/dscf except for opacity (%)

Respectfully submitted,

PACE Laboratories, Inc.


Timothy M. O'Dell
Project Manager


Thomas A. Jackman, Ph.D.
Director, Florida Division

Source Test Summary

Company Name: Johnson Controls, Inc.
Source Identification: COS Line #3 (S/N 134A)
Test Parameter: Lead
Process Weight Rate: 2050 Pounds / Hour
Test Date: February 10, 1988

RUN NUMBER	1	2	3	Average
SCF	4.7724E+01	4.9223E+01	4.8073E+01	4.8340E+01
ACFM	1.77E+04	1.73E+04	1.76E+04	1.75E+04
WATER, %	1.65E+00	1.60E+00	2.57E+00	1.94E+00
ISOKINETIC, %	9.84E+01	1.05E+02	1.02E+02	1.02E+02
EMISSIONS, GR/DSCF	1.35E-04	5.54E-05	4.84E-05	7.97E-05
EMISSIONS, LB/HR	2.00E-02	7.96E-03	6.99E-03	1.17E-02

EMISSION SUMMARY:

Lead, gr/dscf

Actual: 7.97E-05 ✓

SECTION 2.0
Source Description

SOURCE DESCRIPTION

Johnson Controls, Inc., Globe Battery Division, operates a lead-acid storage battery manufacturing facility at 10215 North 30th Street, Tampa, Florida.

At this location, lead pigs are received, melted and cast to form lead grids. Bulk lead oxide is received from off site and is also produced on site in a ball mill. Lead oxide is mixed with sulfuric acid and is applied as a paste to the lead grids. These grids are then used in the production of lead-acid storage batteries for automotive and marine applications.

COS Line #3 (S/N 134A)

The Cast-On-Strap (COS) machine was developed by Globe Union, Inc. to replace gas torches used to weld pre-cast post to cell element lugs. This machine casts the straps and posts and fuses them to the lugs ready for insertion into containers. This produces finished cell elements for through-partition (HV), and over, or conventional post and link intercell connectors.

The Cast-On-Strap machine consists of a separate lead melting furnace (electrically heated) mounted in close proximity to two lead dispensing pots (electrically heated). These two lead dispensing pots are fed lead by automatic mechanical devices from the main lead furnace.

The element loading station, loaded by an operator taking elements produced from the Globe/Reed Stacker, properly aligns and squares up each cell element before processing through succeeding operations. This machine is designed for production of high volume, 12 or 6 volt battery types. Each station and operation of this machine handles six elements simultaneously. When the elements are properly aligned, a set of pick-up clamps mounted on a four position rotating arm assembly transfers the element to a flux station, a casting station, and an unloading station.

The emissions from the COS Line #3 are controlled by a Ruemelin model 4120 baghouse.

SECTION 3.0

Methodology

3.1 GENERAL SAMPLING METHODOLOGY

Sampling methodologies as described in the latest revision of the Florida Department of Environmental Regulation publication Standard Sampling Techniques and Methods of Analysis for the Determination of Air Pollutants from Point Sources and U. S. Environmental Protection Agency Regulations found in 40CFR Part 60 (Standards of Performance for New Stationary Sources) Appendix A, Reference Methods, were used in conducting this test.

The test was conducted using a Lear Siegler Model PM100 Manual Stack Sampler.

Gas stream velocity is measured using a Type S pitot tube. Differential pressures for velocity determinations and in maintaining the proper orifice pressure are measured using a five inch incline manometer. The probe nozzle, filter holder, and pitot tubes are all constructed of type 316 stainless steel.

A Gelman glass fiber filter is supported on a stainless steel filter holder. The sampling nozzle is a conventional button hook design and attached directly to the stainless steel filter holder. A borosilicate glass probe liner is attached to the exit side of the filter holder and the condenser train. The condenser train consists of four impingers connected in series. The first, third, and fourth impingers are of the modified Greenburg-Smith type while the second impinger is of standard design. In all testing situations, the fourth impinger contains a known weight of silica gel (typically 200g). The contents of the first and second impingers depends on the nature of the test being conducted. The third impinger is usually empty. The condenser system is immersed in an ice bath to maintain the gas exit temperature at or below 68°F during all sampling runs. Both the nozzle and filter holder are inserted directly into the stack.

A leak check is performed before and after each run by blocking the nozzle and drawing the appropriate vacuum. All leakages are below 0.02 CFM at a vacuum exceeding the maximum vacuum encountered during the test cycle.

Prior to the first run, a velocity traverse was performed and appropriate calculations were made to determine the most suitable test conditions. The moisture content used for these calculations is based on the results of previous test on the same or similar sources.

At the end of each test run, the volume of water collected in the first, second, and third impingers was measured. Where appropriate, the contents of the impingers is transferred to a container for laboratory analysis. The silica gel desiccant in the fourth impinger is transferred to a tared bottle for transfer to the laboratory. The filter is removed and transferred to a clean petri dish. The nozzle is rinsed with 0.1 N nitric acid or

appropriate solution when specified by a particular methodology and the washings saved for further analysis. A fresh filter is installed and the train assembled for the next run.

3.2 SPECIFIC SAMPLING METHODOLOGY

COS Line #3 (S/N 134A)

Two (2) sampling ports are installed in a 36 inch diameter circular duct. The ports are positioned at 90° angles and are located 0.75 duct diameters from the closest downstream disturbance and 2.5 duct diameters from the closest upstream flow disturbance.

During each test run, 24 points are sampled along two (2) traverses. Each point was sampled for three (3) minutes.

3.3 ANALYTICAL METHODOLOGY

Lead Methodology

The analytical methodology employed is described below.

After the particulate determination described above, the filter and probe wash residue were retained for lead analysis. The volume of the impinger catch was reduced to approximately ten (10) milliliters. The probe wash residue and the particulate filter (cut in strips) and the impinger wash was taken to dryness. The dried residue of each sample was digested with 1:1 nitric acid and 3% hydrogen peroxide. The solutions were filtered and the filtrate diluted to 250 ml. A blank containing 0.1 N nitric acid and a blank filter was treated similarly.

The solutions generated above were analyzed for lead content by atomic absorption spectrophotometry using the Method of Standard Additions. The analysis was performed on an Instrumentation Laboratories Model 251 Atomic Absorption Spectrophotometer at the analytical wavelength for lead (217.0 nm).

3.4 STACK SAMPLING EQUIPMENT DESCRIPTION

a. Nozzle

Stainless steel, type 316, with a 0.225 inch diameter orifice as measure on site with a vernier caliper.

b. Probe

Five (5) foot type 316 stainless steel with a borosilicate glass liner.

c. Thermocouple

Chromel-Alumel K-type

d. Pitot Tube

Five foot type 316 stainless steel Strauscribe type.

e. Sample Collection Assembly

The nozzle is attached directly to the stainless steel filter holder and both are inserted directly into the stack. The exit of the filter holder consists of a borosilicate glass liner which is attached to the first impinger in the condensing train.

f. Lear Siegler Control Unit

This unit contains a diaphragm vacuum pump, dry gas meter, digital pyrometer, temperature controllers, and dual Dwyer Inclined Manometers (five inch).

3.5 LABORATORY PREPARATION

a. Glassware

Washed and dried prior to each stack test.

b. Filters

Oven dried at 105°C to constant weight (four hours minimum) and weighed to the nearest 0.5 mg. Tared filters are stored in a desiccator until used in a test.

c. Silica Gel

Dried at 250°F for two hours and stored in air tight containers until used.

d. Control Unit

Check operation of all systems.

3.6 SAMPLE RECOVER EQUIPMENT

a. Probe Brush

b. Water Wash Bottles

c. Sample Storage Bottles

- d. Graduated Cylinder
- e. Desiccator
- f. Analytical Balances
 - 1. Mettler EL
 - 2. Mettler H10w
- g. Filters
 - Gelman borosilicate glass fiber filters (47 mm diameter)
- h. Silica Gel
 - Indicating type, 6-16 mesh, dried at 350°F immediately before test.
- i. Nitric Acid, ACS, Reagent Grade
- j. Water, Deionized
- k. Ice

SECTION 4.0

Test Data and Calculations

Source Testing Nomenclature and Dimensions

ACFM	=	Actual ft^3/min
A_n	=	Probe nozzle tip area, ft^2
A_s	=	Area of stack, ft^2
B_{ws}	=	Proportion of water vapor in gas stream by volume, dimensionless
C_p	=	Pitot Coefficient
Delta H	=	Average pressure differential across the orifice meter
I	=	Percent of Isokinetic sampling
M_d	=	Molecular weight of stack gas, dry basis
M_s	=	Molecular weight of stack gas, wet basis
$(\Delta p)^{1/2}$	=	Square root of velocity head, inches of H_2O
P_b	=	Barometric pressure, inches of Hg
P_s	=	Absolute stack pressure, inches of Hg
Q_{std}	=	Dry volumetric stack gas flow rate corrected to standard conditions
θ	=	Sampling time, minutes
SCF	=	V_m (standard)
SCFM	=	Q_{std}
T_m	=	Absolute meter temperature
T_s	=	Absolute stack temperature
V_f	=	Final volume of condenser water, ml
V_i	=	Initial volume, if any, of condenser water
V_m	=	Volume of total sample metered under actual conditions, ft^3
$V_m(\text{std})$	=	Dry gas volume measured by the dry gas meter, corrected to standard conditions (dscf)
V_s	=	Gas stream velocity, ft/sec .

$V_{wc}(std)$ = Volume of water vapor condensed corrected to standard conditions, scf.

Y = Dry gas meter calibration factor

EQUATIONS

Water Vapor Volume of Moisture Condensate

$$V_{wc}(std) = 0.047 (V_t - V_i)$$

Moisture in Gas Stream

$$B_{ws} = \frac{V_{wc}(std)}{V_{wc}(std) + V_m(std)}$$

Wet Molecular Weight of Gas

$$M_s = M_d (1 - B_{ws}) + B_{ws}$$

Gas Stream Velocity

$$V_s = 85.49 (C_p) (\Delta P)^{1/2}_{avg} \left(\frac{T_s}{P_s M_s} \right)^{1/2}$$

Sample Gas Volume Corrected to Std. Conditions

$$V_m(std) = \frac{17.64 V_m Y (P_b + \Delta H / 13.6)}{T_m}$$

% Isokinetic

$$I = 0.09450 \frac{T_s V_m(std)}{P_s V_s A_n \theta (1 - B_{ws})}$$

Stack Volumetric Flow Rate (ACFM)

$$ACFM = A_s \times V_s \times 60$$

Stack Volumetric Flow Rate (SCFM) corrected to std. cdt.

$$Q_{sd} = 60 (1 - B_{ws}) V_s A_s \left(\frac{528}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$


Sampling Location COS LINE #3

Stack Diameter (A) 36"

Inside of Near Wall to
Outside of Nipple (B) -

Closest Upstream Disturbance 2.5 S.D

Closest Downstream Disturbance 0.75 S.D



Schematic of Sampling
Location

PT. NO.	% STK DIA	TRAV PT LOC	VEL HEAD ΔP	STACK TEMP	
1	2.1	3/4 1	0.51	67	
2	6.7	2 7/16	0.54	68	
3	11.8	4 1/4	0.56	68	
4	17.7	6 3/8	0.57	68	
5	25.0	9	0.57	68	
6	35.6	12 13/16	0.52	68	
7	64.4	23 3/16	0.39	68	
8	75.0	27	0.42	69	
9	82.3	29 5/8	0.43	69	
10	88.2	31 3/4	0.46	68	
11	93.3	33 9/16	0.48	69	
12	97.9	35 1/4 35	0.44	69	
13	2.1	3/4 1	0.64	71	
14	6.7	2 7/16	0.64	71	
15	11.8	4 1/4	0.67	71	
16	17.7	6 3/8	0.58	71	
17	25.0	9	0.58	71	
18	35.6	12 13/16	0.54	70	
19	64.4	23 3/16	0.41	71	
20	75.0	27	0.40	71	
21	82.3	29 5/8	0.39	71	
22	88.2	31 3/4	0.39	71	
23	93.3	33 9/16	0.38	71	
24	97.9	35	0.34	70	
		Ave	0.49	69.5	

static @ 0.47

Ave 0.5

static @ 0.40

PROJECT

SUBJECT

COMPUTED BY

DATE

NOMOGRAPH DATA

PLANT Tabor ControlsDATE 2-10-88SAMPLING LOCATION COS LINE # 3

CALIBRATED PRESSURE DIFFERENTIAL ACROSS ORIFICE, in. H ₂ O	ΔH_0	1.67 1.70
AVERAGE METER TEMPERATURE (AMBIENT + 20°F), °F	$T_{m\text{ avg.}}$	90
PERCENT MOISTURE IN GAS STREAM BY VOLUME	B_{w0}	3
BAROMETRIC PRESSURE AT METER, in. Hg	P_m	29.92
STATIC PRESSURE IN STACK, in. Hg ($P_m \pm 0.073 \times \text{STACK GAUGE PRESSURE in in. H}_2\text{O}$)	P_s	29.95
RATIO OF STATIC PRESSURE TO METER PRESSURE	P_s/P_m	1.00
AVERAGE STACK TEMPERATURE, °F	$T_{s\text{ avg.}}$	69.5
AVERAGE VELOCITY HEAD, in. H ₂ O	$\Delta p_{\text{ avg.}}$	0.49
MAXIMUM VELOCITY HEAD, in. H ₂ O	$\Delta p_{\text{ max.}}$	0.67
C FACTOR		0.99
CALCULATED NOZZLE DIAMETER, in.		0.245
ACTUAL NOZZLE DIAMETER, in.		0.225
REFERENCE Δp , in. H ₂ O		0.68



Environmental Laboratories, Inc.

EPA Method 5 Field Data Sheet

Project Johnson Controls Train No. Cp Leak Check:
Sample Location Unit 3 C Factor 0.76 Bar. Pres. Ins. Hg Pretest: 0000 @ 15 Ins. Hg
Date 2-20-88 Test 1 Run 1 ΔPR 0.68 Static Pres. Ins. H₂O Post-test: 0000 @ 15 Ins. Hg
Operators Jackman, Franklin Nozzle No. Dn 0.225 Estimated MC %

Point Number	Time ΔT	Meter Vol. V _m cu. ft.	Velocity Head-ΔP Ins. H ₂ O	VΔP	ORIFACE ΔH	Vacuum Ins. Hg	Stack Temp. °F	Sampling Train Temperatures - °F				Clock Time	
								Filter	Probe	Imp. Out	M/In		M/Out
1	3	(988.463)	0.56	0.75	1.51	5	76			51	53	69	
2	6	992.8	0.54	0.73	1.48	0	78			53	87	70	1120
3	9	994.1	0.60	0.77	1.05	0	78			55	90	70	1123
4	12	995.4	0.54	0.72	1.48	0	78			54	92	70	1126
5	15	998.4	0.51	0.71	1.40	0	78			55	93	71	1129
6	18	600.3	0.47	0.68	1.20	0	78			56	94	72	1132
7	21	002.0	0.40	0.63	1.08	0	78			56	94	72	1135
8	24	003.7	0.41	0.64	1.12	0	78			56	94	72	1138
9	27	005.6	0.49	0.70	1.35	0	78			56	93	72	1141
10	30	007.5	0.52	0.72	1.45	0	79			55	92	72	1144
11	33	009.4	0.54	0.73	1.48	0	79			56	93	73	1147
12	36	011.4	0.57	0.71	1.40	0	79			56	93	73	1150
13	39	013.7	0.65	0.81	1.30	0	79			56	93	73	1153
14	42	015.9	0.66	0.81	1.32	1	79			55	94	74	1156
15	45	016.0	0.64	0.80	1.75	1	79			57	94	74	1159
16	48	020.2	0.61	0.78	1.65	1	79			58	95	74	1200
17	51	022.2	0.60	0.77	1.63	0	79			57	95	75	1203
18	54	024.3	0.49	0.71	1.35	0	79			57	96	75	1206
19	57	026.2	0.46	0.68	1.28	0	79			57	95	74	1209
20	60	028.1	0.46	0.68	1.24	0	78			56	94	73	1212
21	63	030.0	0.47	0.66	1.21	0	78			56	94	73	1215
22	66	031.8	0.44	0.66	1.21	0	78			56	94	74	1218
23	69	033.6	0.43	0.65	1.19	0	78			56	94	74	1221
24	72	035.2	0.39	0.62	1.06	0	78			56	94	74	1224
Σ =								V _m = 46.401				T _s = 78	
								ΔH = 0.74				ΔH = 1.47	
												T _m = 82	

Samples Recovered: Filter Number ; ☐ Probe Wash; ☐ Wet Catch; ☐ T_m = 82

Gas Sampling Data:

Box No. Bag Material
Bag No. Leak Check cc @ 15" Hg
Bag Vol. Post Test O₂ Reading %
320 P No.

Moisture Recovery Data:

Impinger No.	1	2	3	4	Total
Final Vol.	157	44	1		214.9
Initial Vol.	100	100	0		211.2
Difference	57	-52	1		7.7



laboratories, inc.

EPA Method 5 Field Data Sheet

Project Johnson Controls Train No. Cp Leak Check:
Sample Location COS #13 C Factor 0.99 Ins. Hg Pretest: 0.00 @ 15 Ins. Hg
Date 2-10-88 Test 1 Run 2 ΔPR 0.67 Ins. H₂O Post-test: 0.00 @ 15 Ins. Hg
Operators Tackman, Franklin Nozzle No. Dn Estimated MC %

Point Number	Time ΔT	Meter Vol. V _m cu. ft.	Velocity Head-ΔP Ins. H ₂ O	VΔP	ORIFACE ΔH	Vacuum Ins. Hg	Stack Temp. °F	Sampling Train Temperatures - °F				Clock Time	
								Filter	Probe	Imp. Out	M/In		M/Out
1	3	036.693	0.63	0.74	1.20	1	80			54	84	70	1251
2	6	041.7	0.59	0.71	1.40	0	80			53	92	76	1254
3	9	042.8	0.66	0.81	1.82	0	80			50	74	78	1257
4	12	045.0	0.61	0.84	1.65	0	80			52	78	77	1300
5	15	047.5	0.56	0.75	1.51	0	80			58	50	79	1303
6	18	049.3	0.49	0.70	1.35	0	81			60	97	80	1306
7	21	051.4	0.43	0.65	1.13	0	81			60	99	80	1309
8	24	053.5	0.44	0.66	1.21	0	81			59	97	80	1312
9	27	056.7	0.46	0.69	1.30	0	81			60	90	80	1315
10	30	059.8	0.52	0.72	1.45	0	82			60	97	80	1318
11	33	059.9	0.56	0.73	1.51	0	82			51	100	80	1321
12	36	062.0	0.52	0.72	1.5	0	82			62	101	81	1324
13	39	064.0	0.67	0.83	0.85	0	83			66	101	83	1336
14	42	066.1	0.64	0.80	1.73	0	83			63.61	101	83	1339
15	45	066.4	0.66	0.81	1.31	0	83			62	99	82	1342
16	48	070.6	0.57	0.82	1.35	0	83			64	101	82	1345
17	51	072.7	0.53	0.73	1.48	0	83			64	101	82	1348
18	54	074.6	0.48	0.69	1.30	0	82			64	102	82	1351
19	57	076.8	0.45	0.67	1.25	0	82			65	102	84	1354
20	60	078.4	0.44	0.66	1.21	0	83			65	102	84	1357
21	63	080.3	0.44	0.66	1.21	0	84			65	101	83	1359
22	66	082.2	0.44	0.66	1.21	0	84			64	101	83	1400
23	69	084.6	0.42	0.65	1.17	0	84			65	102	85	1403
24	72	085.793	0.40	0.63	1.16	0	85			65	101	86	1409
θ =		V _m = 49.106	ΔP = 0.12		AH = 1.41	T _s = 82		T _m = 90					

Samples Recovered: Filter Number : Probe Wash : Wet Catch :

Gas Sampling Data:

Box No. Bag No. Baq Vol. Liters

Bag Material Leak Check cc @ 15" Hg

Post Test O₂ Reading 320 P No.

Moisture Recovery Data:

1	2	3	4
103	34	69	
100	100	0	
3	-66	69	
Impinger No.	Final Vol.	Initial Vol.	Difference
	103	100	3
	222	210	12
	121	107	14



Environmental
Laboratories, Inc.

EPA Method 5 Field Data Sheet

Project Johnson Creek Train No. Cp Leak Check:
Sample Location 111th St Pitot Tube No. Bar. Pres. Ins. Hg Pretest: 2.000 @ 15 Ins. Hg
Date 2-28-86 Test 1 Run 3 Δ PR 0.67 Static Pres. Ins. H₂O Post-test: 2.000 @ 15 Ins. Hg
Operators Joe B. Miller, Eric Miller Nozzle No. Dn Estimated MC %

Point Number	Time ΔT	Meter Vol. V_m cu. ft.	Velocity Head- ΔP Ins. H ₂ O	$V \Delta P$	ORIFACE ΔH	Vacuum Ins. Hg	Stack Temp. °F	Sampling Train Temperatures - °F				Clock Time	
								Filter	Probe	Imp. Out	M/In		M/Out
1	(3)	(133.654)											
2	5	13.53	0.54	0.77	1.60	1	82			62	90	74	1542
3	6	17.02	0.61	0.78	1.65	1	82			65	92	74	1545
4	9	13.43	0.67	0.86	1.73	1	82			54	94	74	1548
5	12	14.64	0.61	0.98	1.85	1	82			54	94	74	1551
6	15	14.34	0.53	0.73	1.48	1	82			54	94	74	1554
7	18	14.57	0.51	0.71	1.46	1	82			54	94	74	1557
8	21	14.72	0.44	0.66	1.21	1	82			54	94	74	1560
9	24	14.91	0.44	0.66	1.21	1	82			55	94	74	1563
10	27	15.10	0.48	0.61	1.30	1	82			55	94	74	1566
11	30	15.30	0.53	0.73	1.48	1	82			55	94	74	1569
12	33	15.48	0.56	0.75	1.51	1	82			56	96	74	1572
13	36	15.68	0.53	0.73	1.48	1	82			56	96	74	1575
14	39	15.89	0.70	0.84	1.91	2	82			57	96	74	1578
15	42	16.13	0.67	0.82	1.85	2	82			57	95	74	1581
16	45	16.34	0.62	0.79	1.73	2	82			57	95	74	1584
17	48	16.55	0.62	0.79	1.73	2	82			57	95	74	1587
18	51	16.76	0.57	0.73	1.48	1	82			57	97	74	1590
19	54	16.6	0.53	0.73	1.48	1	82			57	97	74	1593
20	57	17.16	0.45	0.63	1.25	1	82			57	97	74	1596
21	60	17.36	0.45	0.67	1.25	1	82			57	97	74	1599
22	63	17.52	0.44	0.66	1.21	1	82			57	96	74	1602
23	66	17.70	0.44	0.66	1.21	1	82			57	96	74	1605
24	69	17.80	0.44	0.66	1.21	1	82			58	96	74	1608
25	72	18.05	0.44	0.66	1.21	1	82			58	96	74	1611
$\Theta =$		$V_m = 47.810$	$\Delta P = 0.33$	$PH = 1.47$		$T_s = 82$		$T_m = 83$					

Samples Recovered: Filter Number : Probe Wash : ☐ Wet Catch : ☐

Gas Sampling Data:

Box No. Bag Material
Bag No. Leak Check cc @ 15" Hg
Bag Vol. Liters Post Test O₂ Reading %
320 P No.

Moisture Recovery Data:

Impinger No.	1	2	3	4	Dealcont	Total
Final Vol.	164	41	1		229.5	
Initial Vol.	100	100	0		200	
Difference	64	36			29.5	

Source Test Data Summation

Company Name: Johnson Controls, Inc.
Source Identification: COS Line #3 (S/N 134A)
Source Test For: Lead
Test Date: February 10, 1988

RUN NUMBER	1	2	3
V(w) Volume of moisture collected, ml	1.70E+01	1.70E+01	2.70E+01
T(m) Average Meter Temperature, °F	82	90	85
V(m) Actual Sample Volume, cu. ft.	4.6906E+01	4.9100E+01	4.7510E+01
GC Dry Gas Meter Coefficient	1.03E+00	1.03E+00	1.03E+00
P(b) Barometric Pressure, inches Hg	30.16	30.16	30.16
P(m) Pressure across orifice, in Hg	1.47	1.41	1.47
A(s) Stack Diameter, inches	36.0	36.0	36.0
A(n) Probe Nozzle Diameter, inches	0.225	0.225	0.225
T(s) Stack Temperature, ave °F	78	82	82
mg Weight of Lead, mg	0.42	0.18	0.15
t Sampling Time, min.	72	72	72
√dP Velocity Head, √(ave), in. water	0.740	0.720	0.730
P(s) Stack Pressure, Ave inches Hg	30.19	30.19	30.19

CALCULATIONS

RUN NUMBER	1	2	3
SCF Sampled	4.7724E+01	4.9223E+01	4.8073E+01
Water, %	1.6	1.6	2.6
Gas Molecular Weight	28.78	28.79	28.68
Gas Stream Velocity	4.18E+01	4.08E+01	4.15E+01
ACFM	1.77E+04	1.73E+04	1.76E+04
SCFM	1.73E+04	1.67E+04	1.68E+04
Isokinetic, %	98	105	102
Emissions, gr/dscf	1.35E-04	5.54E-05	4.84E-05
Emissions, lb/hr	2.00E-02	7.96E-03	6.99E-03

SECTION 5.0

Opacity

Source/Process Information				Opacity Readings														
FACILITY NAME <i>Johnson Controls</i>				OBSERVATION <i>2-0-88</i>					START TIME <i>1542</i>					STOP TIME <i>1642</i>				
SOURCE NAME <i>LOS #?</i>		PERMIT NO		SEC	0	15	30	45	SEC	0	15	30	45					
LOCATION/ADDRESS				1	0	0	0	0	21	0	0	0	0					
CONTACT <i>Bill Scott</i>		PHONE NO		2	0	0	0	0	22	0	0	0	0					
PROCESS/PRODUCTION RATE				3	0	0	0	0	23	0	0	0	0					
CONTROL EQUIPMENT <i>SCRAPHOUSE</i>		OPERATING MODE <i>Good</i>		4	0	0	0	0	24	0	0	0	0					
FUEL TYPE/RATE	MATERIAL TYPE/RATE	PERMITTED RATE		5	0	0	0	0	25	0	0	0	0					
DESCRIBE EMISSION POINT <i>36" stack</i>				6	0	0	0	0	26	0	0	0	0					
HEIGHT ABOVE GROUND LEVEL <i>25' ft</i>		HEIGHT RELATIVE TO OBSERVER <i>21' ft</i>		7	0	0	0	0	27	0	0	0	0					
Emissions Description																		
DESCRIBE EMISSIONS <i>None</i>				8	0	0	0	0	28	0	0	0	0					
START <i>None</i>		END <i>None</i>		9	0	0	0	0	29	0	0	0	0					
PLUME COLOR <i>None</i>		PLUME TYPE <i>None</i>		10	0	0	0	0	30	0	0	0	0					
WATER DROPLETS PRESENT? YES ☐ NO ☒		IF YES, IS PLUME ATTACHED ☐ DETACHED ☐		11	0	0	0	0	31	0	0	0	0					
Meteorological Information																		
BACKGROUND START <i>SKY</i> END <i>SKY</i>		BACKGROUND COLOR START <i>Blue + Gray</i> END		12	0	0	0	0	32	0	0	0	0					
SKY CONDITIONS % CLOUD COVER START <i>40</i> END <i>80</i>		AMBIENT TEMP START <i>70°</i> END <i>70</i>		13	0	0	0	0	33	0	0	0	0					
WIND SPEED START <i>7-10</i> END <i>7-10</i>		WIND DIRECTION START <i>N</i> END <i>N</i>		14	0	0	0	0	34	0	0	0	0					
Observation Data, Site Diagram																		
Stack with Plume Sun Wind Draw North Arrow 				15	0	0	0	0	35	0	0	0	0					
				16	0	0	0	0	36	0	0	0	0					
				17	0	0	0	0	37	0	0	0	0					
				18	0	0	0	0	38	0	0	0	0					
				19	0	0	0	0	39	0	0	0	0					
				20	0	0	0	0	40	0	0	0	0					
				21	0	0	0	0	41	0	0	0	0					
				22	0	0	0	0	42	0	0	0	0					
				23	0	0	0	0	43	0	0	0	0					
				24	0	0	0	0	44	0	0	0	0					
				25	0	0	0	0	45	0	0	0	0					
				26	0	0	0	0	46	0	0	0	0					
				27	0	0	0	0	47	0	0	0	0					
				28	0	0	0	0	48	0	0	0	0					
				29	0	0	0	0	49	0	0	0	0					
				30	0	0	0	0	50	0	0	0	0					
				Compliance Information				Certification Data, Signatures										
RANGE OF OPACITY READINGS MIN <i>0</i> MAX <i>0</i>				OBSERVERS NAME <i>Michael Jackman</i>														
AVERAGE OF HIGHEST 20 CONSECUTIVE READINGS <i>0</i>				OBSERVERS SIGNATURE <i>Michael C. Jackman</i> DATE <i>3-9-88</i>														
SHORT TERM AVERAGE DATA				ORGANIZATION <i>PACE LABORATORIES INC</i>														
AVERAGING PERIOD MINUTES ACTUAL AVERAGE				CERTIFIED BY <i>Eastern Technical Assoc</i> DATE <i>9-10-87</i>														
COMMENTS				I HAVE RECEIVED A COPY OF THESE OBSERVATIONS SIGNATURE DATE														
				APIS NUMBER:														

APPENDIX A

Calibration Data

SUMMARY OF SAMPLING EQUIPMENT CALIBRATION

<u>Equipment Calibration</u>	<u>Date of Calibration</u>	<u>Place of Calibration</u>	<u>Method of Calibration</u>	<u>Calibration Date</u>
Nozzle	2/10/88	On Site	Vernier Caliper Ave.	See Following
Pitot Tube	2/3/88	PACE	FDER Alt. Method	$C_p = 0.84$
Dry Gas Meter and Orifice	3/1/88	PACE	Wet Test Meter JU	MCF = 1.033
Barometer	----	Tampa Airport	-----	@ 12 noon
Thermocouples	1/88	PACE	Calibrated at ambient and boiling water temperatures against ASTM mercury bulb thermometer	$\pm 5^\circ\text{F}$
Nomograph Accuracy	1/88	PACE	EPA Pub. "Adjustments in the EPA Nomograph for different Pitot Tube Coeff. and Dry Molecular Weights	$\pm 10\%$

Client: Johnson Controls, Inc.
Source I.D.: COS Line #3 (S/N 134A)
Test Date: February 10, 1988
Computed By: Michael C. Jackman

	<u>Nozzle Diameter</u>					
<u>DATE</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>Average</u>
2/10/88	0.225	0.225	0.225	0.225	0.225	0.225

DRY GAS METER AND ORIFICE CALIBRATION

Calibration Date: February 3, 1988
Calibrated by: Michael Jackman

Barometric Pressure: 30.24 in Hg
Calibration Time: 15 min

-----WET TEST METER-----					-----DRY GAS METER-----							---CALIBRATION---	
Initial Vol	Final Vol	Vw	dW	Tw °F	Initial Vol	Final Vol	Vm	dH	T in	T out	Tm ave	MCF	dH ₀
0.000	6.305	6.305	0.20	73.7	631.851	637.939	6.088	0.50	101	77	89.0	1.057	1.574
0.000	7.575	7.575	0.20	73.5	637.939	645.308	7.369	0.75	103	78	90.5	1.052	1.631
0.000	8.654	8.654	0.25	73.0	645.308	653.773	8.465	1.00	107	80	93.5	1.050	1.657
0.000	10.341	10.341	0.30	73.0	668.941	679.254	10.313	1.50	110	82	96.0	1.032	1.734
0.000	11.966	11.966	0.30	73.0	679.254	691.120	11.866	2.00	110	82	96.0	1.036	1.727
0.000	13.143	13.143	0.40	73.0	691.120	704.124	13.004	2.50	110	83	96.5	1.035	1.786
0.000	14.334	14.334	0.40	72.5	704.124	718.433	14.309	3.00	111	84	97.5	1.027	1.795
AVERAGE												1.041	1.700

dH = Orifice Pressure inches water
dW = Pressure (-) at Wet Test Meter inches Hg
Vm = Gas Volume, Dry Gas Meter cubic feet
Vw = Gas Volume, Wet Test Meter cubic feet
Tw = Temperature, Wet Test Meter °F
Tm = Temperature, Dry Gas Meter °F
t = Calibration Time minutes
MCF = Meter Correction Factor
dH₀ = Standard Orifice Pressure Differential
0.75 CFM dry air @70°F, 29.92 inches Hg

$$MCF = [Vw * (Tm + 460) * (Pb - dW)] / [Vm * (Tw + 460) * (Pb + dH / 13.6)]$$

$$dH_0 = [(0.0317 * dH / (Pb * (Tm_{out} + 460))) * ((Tw + 460) * t / Vw)]^2$$

DRY GAS METER AND ORIFICE CALIBRATION

Calibration Date: March 1, 1988
Calibrated by: Michael Jackman

Barometric Pressure: 30.18 in Hg
Calibration Time: 15 min


-----WET TEST METER-----					-----DRY GAS METER-----					--CALIBRATION--			
Initial Vol	Final Vol	Vw	dW	Tw °F	Initial Vol	Final Vol	Vm	dH	T in	T out	Tm ave	MCF	dH ₀
0.000	6.192	6.192	0.30	71.3	722.278	728.281	6.003	0.50	97	71	84.0	1.044	1.638
0.000	7.598	7.598	0.35	71.3	728.281	735.697	7.416	0.75	101	76	88.5	1.044	1.617
0.000	8.509	8.509	0.40	71.2	735.697	744.072	8.375	1.00	104	76	90.0	1.035	1.718
0.000	10.209	10.209	0.40	71.3	744.072	754.207	10.135	1.50	106	77	91.5	1.028	1.788
0.000	11.715	11.715	0.45	71.3	754.207	765.845	11.638	2.00	108	79	93.5	1.028	1.804
0.000	13.221	13.221	0.50	71.5	780.303	793.252	12.949	2.50	99	75	87.0	1.027	1.785
0.000	14.354	14.354	0.50	71.5	807.505	821.799	14.294	3.00	110	79	94.5	1.023	1.803
AVERAGE												1.033	1.736

dH = Orifice Pressure inches water
dW = Pressure (-) at Wet Test Meter inches Hg
Vm = Gas Volume, Dry Gas Meter cubic feet
Vw = Gas Volume, Wet Test Meter cubic feet
Tw = Temperature, Wet Test Meter °F
Tm = Temperature, Dry Gas Meter °F
t = Calibration Time minutes
MCF = Meter Correction Factor
dH₀ = Standard Orifice Pressure Differential
0.75 CFM dry air @70°F, 29.92 inches Hg


$$MCF = [Vw \cdot (Tm + 460) \cdot (Pb - dW)] / [Vm \cdot (Tw + 460) \cdot (Pb + dH / 13.6)]$$

$$dH_0 = [(0.0317 \cdot dH / (Pb \cdot (Tm_{out} + 460))] [(Tw + 460) \cdot t / Vw]^2$$

SIDE "A"




SIDE "B"




$W = 0.05$ cm

$W < 0.08$ cm




$\beta^2 = 0.7$



$\beta^2 = 1.3$

$\beta^2 < 5$

SIDE "A"



$a = 1.125$ cm

$b = 1.075$ cm


$c = 0.460$ cm

$\angle A = 84$ °

$\alpha^2 = 180^\circ - (180^\circ - \angle A) + 90^\circ$

$\alpha^2 = -6$ °


$\alpha^2 < 10^\circ$



$Z =$ cm

$Z < 0.32$ cm

SIDE "B"



$a = 1.135$ cm

$b = 1.075$ cm

$c = 0.440$ cm

$\angle A = 84.1$ °

$\alpha^1 = 180^\circ - (180^\circ - \angle A) + 90^\circ$

$\alpha^1 = -5.9$ °

$\alpha^2 < 10^\circ$

SOURCE SAMPLING PITOT TUBE CALIBRATION
ALIGNMENT MEASUREMENT OF FACE-OPENINGS

DATE: 2/3/88
S/N: 5' pitot tube

APPENDIX B

Process Weight Statement

STATEMENT OF PROCESS WEIGHT

COMPANY NAME Johnson Controls, Inc., Globe Battery Division

ADDRESS P. O. Box 16068, Tampa, Florida 33687

SOURCE IDENTIFICATION COS Line #3 (S/N 134A)

SOURCE LOCATION 10215 North 30th Street, Tampa, Florida

DATE 2/10/88 SAMPLING TIME: 1100 TO: 1700

DATA ON OPERATING CYCLE TIME;

START OF OPERATION, TIME _____

END OF OPERATION, TIME _____

ELAPSED TIME _____

IDLE TIME DURING CYCLE _____

DESIGN PROCESS RATING;

PROCESS WEIGHT RATE (INPUT) _____ PRODUCT (OUTPUT) _____

DATA ON ACTUAL PROCESS RATE DURING OPERATION CYCLE;

MATERIAL Lead Alloys RATE 174 lbs/hr

MATERIAL Separators RATE 287 lbs/hr

MATERIAL Pasted Plates RATE 1589 lbs/hr

TOTAL PROCESS WEIGHT RATE;

PRODUCT Element Packs RATE 2050 lbs/hr

I certify that the above statement is true to the best of my knowledge and belief.

Signature William Scott

Title Managing Engineer