

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 12.20

Background Chapter: 4

Reference Number: 34

Title: Emissions Test Report.
SVS/MECATM at a Chromic
Anodizing Facility, Santa Ana, CA, on
December 12, 1988 by Truesdart
Laboratories, Inc., Tusti, CA


January 1989

ELECTROPLATING

REF. 4-34

EMISSIONS TEST REPORT

REID



SVS/MECA™

AT
A CHROME ANODIZING FACILITY
Santa Ana, California

ON
December 12, 1988

BY
TRUESDAIL LABORATORIES, INC.
Tustin, California

CM&E
INTERNATIONAL

REPORT

TRUESDAIL LABORATORIES, INC.



14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUE LABS

CHEMISTS - MICROBIOLOGISTS - ENGINEERS
RESEARCH - DEVELOPMENT - TESTING

CLIENT **C M and E International**
18011-D Skypark Circle
Irvine, CA 92714
Attention: Dave Miller

DATE January 11, 1989

RECEIVED Dec. 12, 1988

SAMPLE Source tests for chromium on scrubber at Reid
Metal Finishing

LABORATORY NO. 26163

INVESTIGATION

Total and hexavalent chromium

RESULTS

On December 12, 1988 representatives of Truesdail Laboratories, Inc. conducted source tests for total and hexavalent chromium on the inlet and outlet of CM and E International VSV\MECA II scrubber serving a chrome plating tank at Reid Metal Finishing in Santa Ana, California.

A 360-minute isokinetic sample of the flue gas was collected at each sampling location by the wet impingement method (SCAQMD method 5.1). The sampling train consisted of a glass probe connected with Teflon tubing to a set of Greenburg-Smith impingers charged with 200 mls of 0.1N NaOH and followed by a Teflon filter on a glass fiber backing filter, a vacuum pump, and a dry gas meter. The inlet sampling location was 6 inches in diameter and the sample was collected at 2 sampling points on each of two diameters 90° apart. The outlet sampling location was 6 inches in diameter and the sample was collected at 2 sampling points on each of the two diameters 90° apart.

During the test period, a 30-minute integrated sample of the flue gas was collected at each sampling location simultaneously. The samples were collected with an evacuated 8-liter stainless steel cylinder and a stainless steel sampling line.

The flue gas flow rate was determined from in-line 6-inch orifice tubes at each sampling location. The flow was monitored throughout the entire test period by recording the velocity head and temperature at 15-minute intervals. The average temperature at each location was measured with a chromel-alumel thermocouple connected to a Micromite potentiometer.

C M and E International

LN 26163

Page 2

Sampling trains were prepared by soaking all impingers for 12 hours in 50% nitric acid, then rinsing three times with distilled water and charging with 200 mls of 0.1N NaOH. All probes and Teflon tubing were rinsed on site with 50% nitric acid and washed three times with distilled water. Samples were recovered by measuring condensate gain and rinsing the probe, Teflon tubing, and impingers twice with 0.1N NaOH and once with 0.1N nitric acid. The Teflon filter was placed in the impinger catch and the sample refrigerated, and analyzed within 48 hours. A blank sampling train was taken to the job site, leak-checked, sealed and returned to the lab for analysis.

The total chrome was determined by atomic absorption and the hexavalent chrome by the diphenylcarbazide colorimetric method. The analyses included glassware prepped as above, calibration curves, spike recovery, and a blank sampling train.

The hydrogen, nitrogen, and oxygen content of the integrated samples was determined by gas chromatography utilizing thermal conductivity detection.

The results are as follows:

SAMPLING SUMMARY SHEET

PLANT	Chrome Anodizing Facility
LOCATION	Santa Ana, Calif

SAMPLED SOURCE SVS/MCA Adapting Facility

Run	Date	N _p	(3) Y _m	(4) ΔH	(5) P Bar.	(6) V _m	(7) T _m	(8) V _m Std.	(9) %	(10) P _{st}	(17) P _s	(18) T _s	(19) VP	(20) V _w	(21) V _w gas	(22) %M	(23) N _d
1	12 DEC 88	24	997	.36	30.15	214.40	76	212.583	0.1	-319	30.13	80		38.5	1.81	.85	992
1	12 DEC 88	24	1021	.49	30.15	247.58	68			.31	30.17	78		93	4.38	1.69	983

Run	(24) CO ₂	(25) O ₂	26 N ₂	(27) CO	(28) H ₂	29 MW _d	30 MW	(31) $C_p \sqrt{4 P_s (T_s + 460)}$	(32)	(33) T _t	(34) D _n	35 V _s	(36) D _s	Area (37)	38 ACFM	(39) DSCFM	40 %I
1	0.0	21.3	78.6		$\frac{1000}{2}$	28.83	28.73	.84	3.6227	360	.472	8.34	6"	0.20	104	102	93.1
1	0.0	21.0	78.9		$\frac{1000}{2}$	28.81	28.63	.84	3.90898	360	.5	9.55	6"	0.20	113	109	93.2

$$\begin{aligned}
\text{Std.} &= Y_m \frac{17.64 \times V_m \left(P \text{ Bar.} + \frac{\Delta H}{13.6} \right)}{(T_m + 460)} \\
\text{ZM} &= \frac{100 \times V_{\text{gas}}}{V_{\text{Std.}} + V_{\text{gas}}} \\
M_d &= 100 - \frac{\text{ZM}}{100} \\
V_{\text{gas}} &= 0.0471 V_m \\
M_d &= \text{XCO}_2 \times .44 + (\text{XO}_2 \times .32) + (\text{XCO} + \text{XN}_2) \times \frac{.28 + (\text{XOther} \times \text{Mol. wt.})}{100} \\
M_d &= M_d \times M_d + 18(1 - M_d) \\
&= 85.49 \times C \sqrt{\frac{P_s}{P_m} (T_s + 460)} \left[\frac{1}{P_s \times M_d} \right]^{1/2} \\
I &= \frac{0.09450 \times (T_s + 460) \times V_{\text{Std.}}}{V_m \times T_m \times P_s \times M_d \times A_n}
\end{aligned}$$

N_p = Total No. of Sampling Points
 Y_m = Meter Box Correction Factor
 ΔH = Average Orifice Pressure Drop, inches H_2O
 $P \text{ Bar.}$ = Barometric Pressure, Inches Hg. Absolute
 V = Volume of Dry Gas at Meter Conditions, DCF
 T_m = Average Meter Temperature, $^{\circ}F$
 $V_{\text{Std.}}$ = Volume of Dry Gas at STP, DSCF^a
 X = Per Cent other gas removed before Dry Gas Meter
 P_{at} = Static Pressure of Stack Gas, inches H_2O
 P_s = Stack Gas Pressure, inches Hg.
 T_s = Average Stack Temperature, $^{\circ}F$

VP = Vapor Pressure of H_2O at Stack Temperature
 V_w = Total H_2O Collected in Impingers and Silica Gel
 V_{gas} = Volume of water vapor collected at STP, SCF^b
 ZM = Per Cent Moisture by volume
 M_d = Mole Fraction of Dry Gas
 XCO_2 = Volume % Dry
 XO_2 = Volume % Dry
 XN_2 = Volume % Dry
 XCO = Volume % Dry
 M_d = Molecular Weight of Stack Gas Dry Basis
 MW = Molecular Weight of Stack Gas, Wet Basis
 C_p = Pitot Tube Coefficient

$\Delta P (T_s + 460)$ is determined by averaging the square root of the product of the velocity head (P) and the absolute stack temperature from each sampling point.
 T_m = Wet time of test in minutes
 D_n = Sampling Nozzle Diameter, inches
 A_n = Area of Nozzle opening, ft^2
 V_s = Stack Gas Velocity at Stack Conditions, Feet per second.
 D_s = Diameter of Stack, inches
 A_{area} = Area of duct in ft^2
 $ACFM$ = Actual Cubic Feet per minute
 $DSCFM$ = Dry Standard Cubic Feet per minute
 ZI = Per Cent Isokinetic
^a Dry Standard Cubic Feet @ $68^{\circ}F$, 29.92 in. Hg.
^b Standard Conditions @ $68^{\circ}F$, 29.92 in. Hg.

TRUESDAIL LABORATORIES, INC.

C M AND E INTERNATIONAL
REID METAL FINISHING
12-12-88

<u>Flue Gas:</u>	<u>Scrubber Inlet</u>	<u>Scrubber Outlet</u>
Temperature, °F	80	78
Velocity, ft./sec*	26.9*	29.0*
Static Pressure, in H ₂ O	-0.32	+0.31
Duct Diameter, in.	6.0	6.0
Orifice Diameter, in.	3.44	3.44
Orifice Area, sq. ft.	0.065	0.065
Gas Volume: ACFM	105.	113.
SCFM	102.	110.
DSCFM	99.	107.
Moisture, % by Vol.	2.5	2.7

* Through orifice.

<u>Chromium:</u>	(10:53-17:02)	(10:52-16:58)
Sample Volume, DSCF	207.80	243.71
Concentration, ppmv		
Total Cr	7.1	0.00037
Cr ⁺⁶	1.8	0.00046
Concentration, mg/m ³		
Total Cr	15.6	0.00069
Cr ⁺⁶	3.9	0.00086
Emission Rate, mg/hr		
Total Cr	2,625 0.00779 lb/hr	0.13
Cr ⁺⁶	666 0.00145 lb/hr	0.16
Removal Efficiency, %		
Total Cr	99.995	
Cr ⁺⁶	99.98	


<u>Intregated Sample:</u>	(15:00-15:35)	(14:48-15:18)
Concentration, %		
Hydrogen (H ₂)	0.1	0.1
Oxygen (O ₂)	21.3	21.0
Carbon Dioxide (CO ₂)	<0.1	<0.1

Respectfully submitted,

TRUESDAIL LABORATORIES, INC.

S. Hugh Brown

S. Hugh Brown, Supervisor
Air Pollution Testing



APPENDIX

SVS/MECA™ FIELD TEST DATA

TEST Date : 12-12-88

TEST Supervisor : David Miller _____

TEST Site : Reid Metal Finishing _____

TEST No. : Source Test CME-2080A _____

TEST READINGS

TIME	AT (°F)	IT (°F)	OT (°F)	TT (°F)	ST (°C)	SR (GPM)	pH	SP (In)	RA (Amp)	RV (Volt)
10:52	72	71	73	90	17	27	7*	9.8	60	40.5
11:20	80			92						
11:23		72	73		19	26		9.8	95	40
12:03	78			94						
12:20		74	75		21	26		9.8	112	38.5
12:52		75	76		21	26		9.8	145	38.5
12:58	82	76	78	93	21	26			130	40
13:52	84			93					125	40
13:58		75	78		21	26		9.8		
14:38	84			94					130	40.5

TEST READING NOTES

- | | | | |
|--------------------------------------|------|---|------|
| 1. Ambient Air Temperature, °F | = AT | 6. Scrubber Solution Flow Rate, GPM | = SR |
| 2. MECA Inlet Temperature, °F | = IT | 7. Scrubber Solution pH | = pH |
| 3. MECA Outlet Temperature, °F | = OT | 8. Blower Static Pressure, inches W. G. | = SP |
| 4. Tank Solution Temperature, °F | = TT | 9. Rectifier Amperage, amps | = RA |
| 5. Scrubber Solution Temperature, °C | = ST | 10. Rectifier Voltage, volts | = RV |

SUPPLEMENTAL DATA & NOTES

- | | | | |
|--|----------------|--|----------------|
| 1. Start of Test Hour Meter Reading | 10.7 _____ Hrs | 6. Liquid Collected Inlet Exhaust Duct | 1 _____ Lbs |
| 2. End of Test Hour Meter Reading | 17.1 _____ Hrs | 7. Liquid Collected Mist Collection | Undetected Gal |
| 3. Blower Speed Control Setting | 71 _____ Hz | 8. Liquid Collected Demist Section | Undetected Gal |
| 4. SVS/MECA™ Inlet Static Pressure | 3.8 _____ Inch | 9. Scrubber Solution Level Change | 0 _____ Inch |
| 5. Tank CrO ₃ Concentration | 7 _____ Oz/Gal | * pH recorded at Test start and end only | |

- Notes : 1. Ambient Air Temp (AT) taken adjacent to process tank.
 2. Note rectifiers shut down for loading of each workload rack into the process tank for an aveage of 3 to 5 minutes.
 3. Workload racks were placed in the process tank for a 40 minute process time.
 4. pH of scrubber solution read by using litmus paper.

SVS/MECA™ FIELD TEST DATA

TEST Date : 12-12-88 _____ TEST Supervisor : David Miller _____

TEST Site : Reid Metal Finishing _____ TEST No. : Source Test MECA-2080A _____

TEST READINGS										
TIME	AT (°F)	IT (°F)	OT (°F)	TT (°F)	ST (°C)	SR (GPM)	pH	SP (In)	RA (Amp)	RV (Volt)
14:45		74	77		22	26		9.8		40
15:25	84			95					135	40
15:30		74	78		22	26		9.75		
16:10	77			97					81	41
16:15		70.5	78		21	26		9.75		
16:58	74			94					120	39
17:00		71	76		21	26	7*	9.75		
:										
:										
:									Note 5	

TEST READING NOTES


- | | | | |
|--------------------------------------|------|---|------|
| 1. Ambient Air Temperature, °F | = AT | 6. Scrubber Solution Flow Rate, GPM | = SR |
| 2. MECA Inlet Temperature, °F | = IT | 7. Scrubber Solution pH | = pH |
| 3. MECA Outlet Temperature, °F | = OT | 8. Blower Static Pressure, inches W. G. | = SP |
| 4. Tank Solution Temperature, °F | = TT | 9. Rectifier Amperage, amps | = RA |
| 5. Scrubber Solution Temperature, °C | = ST | 10. Rectifier Voltage, volts | = RV |

SUPPLEMENTAL DATA & NOTES

- | | | | |
|--|--------------|--|------------|
| 1. Start of Test Hour Meter Reading | _____ Hrs | 6. Liquid Collected Inlet Exhaust Duct | _____ Lbs |
| 2. End of Test Hour Meter Reading | _____ Hrs | 7. Liquid Collected Mist Collection | _____ Gal |
| 3. Blower Speed Control Setting | _____ Hz | 8. Liquid Collected Demist Section | _____ Gal |
| 4. SVS/MECA™ Inlet Static Pressure | _____ Inch | 9. Scrubber Solution Level Change | _____ Inch |
| 5. Tank CrO ₃ Concentration | _____ Oz/Gal | * pH recorded at Test start and end only | |


Notes : See Notes 1 thru 4 Pg 1

5. Summation of Amp-hrs for this source test 638.7 Amp-hr from a total of 9 different workloads placed in the tank during the 6 hour test.




SYM.	REVISION	DR	BY	DATE
CM&E INTERNATIONAL				
THE INFORMATION AND DESIGN DISCLOSED HEREIN ARE UNCLASSIFIED BY AND FOR THE SECRETARY OF DEFENSE, WASHINGTON, D.C. 20301-1000, ON 08-23-88, BY SP-6 J. J. HARRIS, CM&E INTERNATIONAL, INC., 10000 WILSON AVENUE, SUITE 100, BELLFLOWER, CALIF. 91710. ALL RIGHTS ARE RESERVED, EXCEPT TO THE EXTENT RIGHTS ARE EXPRESSLY GRANTED BY THE U.S. GOVERNMENT.				
DATE:	0-23-88	DR:	BY:	W. J. HARRIS
TITLE: TESTING DIAGRAM FOR SVS - MECA				
CURR. NAME: CM&E INTERNATIONAL				
SKETCH - 1				


11'-3" - 135'



TOP VIEW




FRONT VIEW



TYP. 1/4" PRESS. TAP
(2 - PLACES)

NOTE:
MAKE ONE W/ 6" FLANGE
ON LEFT END (INLET)
MAKE ONE W/ 6" FLANGE
ON RIGHT END (OUTLET)



(2) - 2' DIA. SAMPLE
PORTS @ 90° APART
ALL PORTS TO BE
SEALED W/ DUCT TAPE
AFTER PLACING
SAMPLING TUBE


SYN.	REVISION	REV. LENGTH, FILE	SK	PK	DATE

CM&E
INTERNATIONAL

THE INFORMATION AND DATA CONTAINED HEREIN ARE THE PROPERTY OF CM&E INTERNATIONAL AND ARE NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF CM&E INTERNATIONAL.

DATE	7-14-88	BY	CM&E
TITLE	INLET/ OUTLET TEST DUCT		
PROJECT	CM&E		
SKETCH	SK-1		

FLUE GAS SAMPLING TRAIN



1. Glass Sampling Probe
2. Smith-Greenburgh Impingers in Ice Bath w/ 0.1 N NaOH
3. Thermometer
4. Back-up Filter, Gelman, Stainless Steel Filter Holder for 47 mm Filter
TEFLON + GLASS FIBER FILTER
5. Leakless Vacuum Pump
6. Dry Gas Meter
7. Thermometer
8. Orifice Flow Rate Gauge
9. Dry Gas Sampling Outlet
10. Tedlar Gas Sampling Bag (optional)

TRUESDAIL LABORATORIES, INC.

 Sampling Location: **C M & E - INLET**
 Test No. _____

 Date: **12-12-88**
 Barometric Pressure: **30.15**
 Nozzle Diameter: **1/4725"**

Time	Gas Meter			Impinger Temp. OF Ti	Sample Point	CFM			
	Reading cu. ft. Vm	Press. in. H ₂ O Pm	Temp. OF Tm						
10:41	276.14	.36	73	—	1	60			
10:43	—	—	—	—	1				
10:53	—	—	—	—	1				
11:06	284.40	.36	73	42	2	60			
12:01	292.85	.36	76	42	1	60			
12:36	301.80	.36	79	44	2	60			
12:51	310.75	.36	80	45	1	60			
12:06	319.80	.36	80	45	2	60			
12:21	328.85	.36	80	45	1	60			
12:36	337.85	.36	79	40	2	60			
12:51	346.85	.36	79	46	1	60			
13:06	355.85	.36	79	47	2	60			
13:21	364.95	.36	78	47	1	60			
13:36	373.90	.36	78	47	2	60			
13:51	382.68	—	—	44	—	—			

Weight Collected, grams _____

METER - 003

 Leak check pre ✓
 mf: .95 post ✓

- A. Total Weight _____
- B. Condensate Volume, ml. _____
- C. Condensate Vapor Volume, $0.00267 \times \frac{460 + T_m}{B.P. + P_m/13.6} \times B$, cu. ft. _____
- D. Total Sample Volume, $V_m + C$, cu. ft. _____
- E. Sample Volume, $D \times \frac{520}{460 + T_m} \times \frac{B.P. + P_m/13.6}{29.9} \times \text{Moisture corr., DSCF}$ _____
- F. Concentration, $15.43 \times A/E$, grains/DSCF _____
- G. Stack Gas Flow Rate, DSCFM _____
- H. Emissions, $60 \times G \times F/7000$, lbs/hr _____

TRUESDAIL LABORATORIES, INC.

 Sampling Location: CM+E INLET
 Test No. _____

 Date: 12-12-88
 Barometric Pressure: 30.15
 Nozzle Diameter: (.472)

Time	Gas Meter			Impinger Temp. OF Ti	Sample Point		
	Reading cu. ft. Vm	Press. in. H ₂ O Pm	Temp. OF Tm				
14:02	382.68	.36	75	—	1	60	
14:17	391.80	.36	76	44	2	60	
14:32	400.80	.36	76	45	1	60	
14:47	409.80	.36	76	45	2	60	
15:02	418.80	.36	76	46	1	60	
15:17	427.80	.36	76	44	2	60	
15:32	436.80	.36	76	45	1	60	
15:47	445.80	.36	76	44	2	60	
16:02	454.80	.36	76	44	1	60	
16:17	463.80	.36	73	44	2	60	
16:32	472.80	.36	72	44	1	60	
16:47	481.80	.36	70	44	2	60	
17:02	490.54	—	—	43	1	—	
					2		
	214.40	.36	76	45			

Weight Collected, grams _____

M=385ml

 GAS DCM
E

 15:00
 15:09
 15:10
 15:15
 15:20

- A. Total Weight _____
- B. Condensate Volume, ml. _____
- C. Condensate Vapor Volume, $0.00267 \times \frac{460 + T_m}{B.P. + P_m/13.6} \times B$, cu. ft. _____
- D. Total Sample Volume, $V_m + C$, cu. ft. _____
- E. Sample Volume, $D \times \frac{520}{460 + T_m} \times \frac{B.P. + P_m/13.6}{29.9} \times \text{Moisture corr., DSC}$ ^{.975} _____
- F. Concentration, $15.43 \times A/E$, grains/DSCF _____
- G. Stack Gas Flow Rate, DSCFM _____
- H. Emissions, $60 \times G \times F/7000$, lbs/hr _____

Sampling Location: **CM&E - INLET**

Date: 12-19-88

Static Pressure, Ps: -319

Test No.:


Barometric Pressure: 30.15

TIME	Vel. Head H ₂ O"	Temp. °F	Velocity ft/sec	Point	Vel. Head H ₂ O"	Temp. °F	Velocity ft/sec	Point	Vel. Head H ₂ O"	Temp. °F	Velocity ft/sec
10:41	250	74	26.71		-325	14:02	-320	1	245	80	26.59
11:06	255	80	27.13		-330	14:17	-320	2	245	80	26.59
21	260	82	27.45		-330	14:32	-320	1	245	80	26.59
36	260	83	27.47		-330	14:47	-320	2	245	80	26.59
51	260	84	27.50		-330	15:02	-320	1	245	80	26.59
12:06	255	83	27.21		-320	15:17	-320	2	245	80	26.59
21	255	82	27.18		-320	15:32	-310	1	240	80	26.32
36	250	81	26.89		-320	15:47	-310	2	245	80	26.59
51	250	81	26.89		-320	16:02	-310	1	240	79	26.30
13:06	250	81	26.89		-320	16:17	-305	2	235	78	26.00
21	250	81	26.89		-320	16:32	-305	1	240	77	26.25
36	250	80	26.86		-320	16:47	-305	2	240	76	26.22
51	-	-	-		-	17:02	-	1	-	-	-

LEAK CHECK
PRE ☒ POST ☒

EQUIPMENT IDENTIFICATION
MAGNEHELIC A644 (0-1/2)"
MICROMITE B

- A. AVERAGE VELOCITY (TRAVERSE) ft/sec 26.76 (8.70)
- B. REFERENCE POINT VELOCITY (TRAVERSE) ft/sec _____
- C. AVERAGE VELOCITY (REFERENCE PT.) ft/sec _____
- D. FLUE FACTOR C/B _____
- E. PILOT TUBE CORRECTION FACTOR .80
- F. GAS DENSITY CORRECTION FACTOR 1.004
- G. CORRECTED VELOCITY, A x E x F, ft/sec 26.87 (8.73)
or, A x D x E x F, ft/sec _____
- H. AREA OF FLUE, SQ. FT. 0.065 (0.20)
- J. AVERAGE FLUE TEMPERATURE, °F 80
- K. FLOW RATE, G x H x 60, CFM 105
- L. FLOW RATE, K x $\frac{520}{460 + J} \times \frac{BP + Ps/13.6}{29.9}$, SCFM 102
- M. FLOW RATE, L x MOISTURE CORR., DSCFM 99



TRUESDAIL LABORATORIES, INC.

Date: 12/12/83

Sampling Location: CME E (Reid)

Barometric Pressure: 30.15

Test No. DETECT OF SOOT 2 Pg. 1

Nozzle Diameter: 1/2"

Time	Gas Meter			Impinger Temp. OF Ti	Sample Point	CFM	STACK TEMP °F		
	Reading cu. ft. Vm	Press. in. H ₂ O Pm	Temp. OF Tm						
1052	039.38	.43	67	—	1	.68	73		
1107	049.58	.46	66	42	2	.70	73		
1122	059.79	.43	66	42	1	.68	74		
1137	068.90	.42	67	43	2	.67	76		
1152	078.50	.41	68	45	1	.66	77		
1207	088.20	.47	68	46	2	.72	78		
1222	098.00	.51	69	44	1	.74	78		
1237	108.50	.51	69	45	2	.74	78		
1252	119.10	.51	69	46	1	.74	79		
1307	129.90	.51	69	46	2	.74	78		
1322	140.80	.51	69	46	1	.74	79		
1337	151.80	.33	69	45	2	.60	79		
1352	160.19	—	—	45			79		

ME - .95

Weight Collected, grams

LEAK CHECK - PRE ☒ POST ☒
 METER # 009

- A. Total Weight _____
- B. Condensate Volume, ml. _____
- C. Condensate Vapor Volume, $0.00267 \times \frac{460 + T_m}{B.P. + P_m/13.6} \times B$, cu. ft. _____
- D. Total Sample Volume, $V_m + C$, cu. ft. _____
- E. Sample Volume, $D \times \frac{520}{460 + T_m} \times \frac{B.P. + P_m/13.6}{29.9} \times \text{Moisture corr.}$, DSCF _____
- F. Concentration, $15.43 \times A/E$, grains/DSCF _____
- G. Stack Gas Flow Rate, DSCFM _____
- H. Emissions, $60 \times G \times F/7000$, lbs/hr _____

TRUESDAIL LABORATORIES, INC.

Date: 12/12/89

 Sampling Location: CM & E (22.0)
 Test No. DUTY OF SCORPER PG. 2

Barometric Pressure: 30.15

Nozzle Diameter: 1/8"

Time	Gas Meter			Impinger Temp. OF Ti	Sample Point	CFM	Stack Temp °F	CO TANK EW
	Reading cu. ft. Vm	Press. in. H ₂ O Pm	Temp. OF Tm					
1359	160.19	.51	68	—	1	.74	79	1448
1413	171.29	.48	68	45	2	.74	79	53
1428	182.70	.51	68	45	1	.74	79	58
1443	192.20	.51	68	45	2	.74	79	1503
1458	203.00	.52	68	46	1	.75	79	08
1513	213.30	.52	68	46	2	.75	79	13
1528	224.00	.52	68	45	1	.75	79	18
1543	235.00	.54	67	45	2	.76	78	
1558	245.80	.51	67	45	1	.74	78	
1613	256.50	.51	66	45	2	.76	78	
1628	267.00	.56	65	44	1	.78	77	
1643	277.40	.50	65	44	2	.72	77	
1658	286.96	—	—	44				
	24758	.49	68	45				

Weight Collected, grams

METER-009

 SYSTEM RUN: 0.0200 mps
 40 MIN. RUN AT 40 VOLTS
 TANK - 90°F

M = 395 mls

- A. Total Weight _____
- B. Condensate Volume, ml. 93 ml
- C. Condensate Vapor Volume, $0.00267 \times \frac{460 + T_m}{B.P. + P_m/13.6} \times B$, cu. ft. 4.34
- D. Total Sample Volume, $V_m + C$, cu. ft. 251.92
- E. Sample Volume, $D \times \frac{520}{460 + T_m} \times \frac{B.P. + P_m/13.6}{29.9} \times \text{Moisture corr., DSCF}$ 243.71
6.90 m³
- F. Concentration, $15.43 \times A/E$, grains/DSCF _____
- G. Stack Gas Flow Rate, DSCFM _____
- H. Emissions, $60 \times G \times F/7000$, lbs/hr _____

Sampling Location: CME

Test No.: OUTLET

Date: 12/12/87

Static Pressure, Ps: +.31

Barometric Pressure: 30.15

Point	Vel. Head H ₂ O"	Temp. °F	Velocity ft/sec	TIME	Point	Vel. Head H ₂ O"	Temp. °F	Velocity ft/sec	TIME	Point	Vel. Head H ₂ O"	Temp. °F	Velocity ft/sec	TIME
1	.26	73	27.19	10:52	1	.31	79	30.33	13:58	1	.32	79	30.33	13:58
2	.28	73	28.21	11:07	2	.30	79	29.37	14:13	2	.30	79	29.37	14:13
1	.26	74	27.21	11:22	1	.30	79	29.37	14:28	1	.30	79	29.37	14:28
2	.25	76	26.74	11:37	2	.30	79	29.37	14:43	2	.30	79	29.37	14:43
1	.24	77	26.22	11:52	1	.31	79	29.85	14:58	1	.31	79	29.85	14:58
2	.29	78	28.85	2:07	2	.32	79	30.33	15:13	2	.32	79	30.33	15:13
1	.30	78	29.34	2:22	1	.32	78	30.30	15:28	1	.32	78	30.30	15:28
2	.30	78	29.34	2:37	2	.30	78	29.34	15:43	2	.30	78	29.34	15:43
1	.31	79	29.85	12:52	1	.32	79	30.36	15:58	1	.32	79	30.36	15:58
2	.31	78	29.83	13:07	2	.34	77	31.21	16:13	2	.34	77	31.21	16:13
1	.20	79	23.98	13:22	1	.31	77	29.80	16:28	1	.31	77	29.80	16:28
2				13:37	2				16:43	2				16:43

LEAK CHECK

PRE < POST

EQUIPMENT IDENTIFICATION

MAGNEHELIC

Pm 243

MICROMITE

A

(circled)

A. AVERAGE VELOCITY (TRAVERSE) ft/sec 28.92 (9.40)

B. REFERENCE POINT VELOCITY (TRAVERSE) ft/sec

C. AVERAGE VELOCITY (REFERENCE PT.) ft/sec

D. FLUE FACTOR C/B

E. PIVOT TUBE CORRECTION FACTOR .80

F. GAS DENSITY CORRECTION FACTOR 1.004

G. CORRECTED VELOCITY, A x E x F, ft/sec 29.04 9.44

or, A x D x E x F, ft/sec



H. AREA OF ORIFICE, SQ. FT. 0.065 (0.2)

J. AVERAGE FLUE TEMPERATURE, °F 78

K. FLOW RATE, G x H x 60, CFM 113

L. FLOW RATE, K x $\frac{520}{460 + J}$ x $\frac{BP + Ps/13.6}{29.9}$, SCFM 110

M. FLOW RATE, L x MOISTURE CORR., DSCFM 107



Date : 12-12-88

Client : CM&E INTERNATIONAL

Sampling Station : Scrubber Inlet and outlet

WATER VAPOR AND GAS DENSITY CALCULATIONS

PERCENT WATER VAPOR IN GASES :

	SCRUBBER INLET	SCRUBBER OUTLET
A. Gas pressure at meter, in. Hg (absolute)	30.18	30.19
B. Vapor pressure of water at impinger temp., in. Hg.	0.3004	0.3004
C. Volume of metered gas, cu.ft.	214.40	247.58
D. Volume of water vapor metered, B*C/A. cu.ft	2.13	2.46
E. Volume of water vapor condensed, cu.ft.	3.27	4.34
F. Total volume of water vapor in gas sample, D+E, cu.ft	5.40	6.80
G. Total volume of gas sample, C+E, cu.ft	217.67	251.92
H. Percent water vapor in sampled gas, 100*F/G	2.5	2.7
I. Density of gas referred to air*	0.992	0.9914
J. Gas density correction factor**	1.004	1.004

GAS DENSITY CORRECTION FACTOR :

Component	Volume fraction	Moisture correction	Mol. Wt.	Wt./mole (Wet basis)
SCRUBBER INLET				
Water	0.025	1.0	18.0	0.450
Oxygen	0.209	0.975	32.0	6.521
Nitrogen & inerts	0.791	0.975	28.2	21.749
Average Molecular Weight				28.720
SCRUBBER OUTLET				
Water	0.027	1.0	18.0	0.486
Oxygen	0.210	0.973	32.0	6.539
Nitrogen & inerts	0.790	0.973	28.2	21.676
Average Molecular Weight				28.701

Note:

* Density of gas referred to air = Average Mol. Wt./28.95

** Gas density correction factor = SQRT (1.00 / density of gas)

METHODS FOR DETERMINATION OF VELOCITY, VOLUME, DUST AND MIST CONTENT OF GASES

BULLETIN WP-50

SEVENTH EDITION

P R E F A C E

In order to determine the performance of an existing gas handling or gas cleaning system, to evaluate the necessity of installing a cleaning system, or to obtain information for the design of a cleaning system, it is necessary or desirable to obtain a measure of the concentration and character of the dust in the gas stream, and accurate data regarding the temperature, velocity, and volume of the gas stream itself.

The purpose of this bulletin is to outline a standard method of procedure for the study of gas streams contained in industrial flue systems, and of the suspended matter carried by these gases. In addition, various other methods are mentioned, as no one process is applicable to all situations. Many industrial processes are of such a specialized nature that it is necessary to start with some such standard procedure as described herein, and alter it to develop a procedure to suit the individual conditions.

HAROLD H. HAALAND
EDITOR

COPYRIGHT
1936, 1948, 1951,
1956, 1958, 1968

WESTERN PRECIPITATION DIVISION / JOY MANUFACTURING COMPANY
LOS ANGELES 90051 P.O. Box 2744, (213) 240-2300 / PITTSBURGH 15222 Oliver Building, (412) 471-2116
NEW YORK 10022 110 East 59th Street, (212) 836-2924 / CHICAGO 60162 4421 Harrison Street, Hillside, Ill.,
(312) 449-5700 / ATLANTA 30328 3445 Peachtree Road, N.E., (404) 266-1822 / MONTREAL 308 P.Q., Precipco
Division, Joy Manufacturing Co. (Canada) Ltd., 8285 Mountain Sights Avenue, (514) 739-2781 / ENGLAND
Capitol House, Church Street, Epsom, Surrey, Epsom 27661 / AUSTRALIA Joy Manufacturing Co. Pty.,
78 Kent Road, Mascot, N.S.W., 67-5151 / SOUTH AFRICA Joy Manufacturing Co., (Africa) (Pty), Ltd.,
1 Steeldale, Johannesburg, 869-5241 / FRANCE Precipco de France, 30 Rue Chabrol, Paris X, France, 824-7560
MEXICO Joy Manufacturing De Mexico S.A. de C.V., Apartado Postal M-9617, Mexico 1, D.F., 533-23-85

FORMULAS

(1) BASIC FLOW EQUATION

$$V_s = \sqrt{2gh}$$

(2) GAS VELOCITY IN FLUE—Using standard Pitot tube

Assume gas density equivalent to air, and flue pressure equal to one atmosphere.

For temperature in °F absolute

For temperature in °C absolute

$$V_s = 2.90 \sqrt{HT_s}$$

$$V_s = 3.90 \sqrt{HT_s}$$

(3) GAS VELOCITY IN FLUE—Using standard Pitot tube

For temperature in °F absolute

For temperature in °C absolute

$$V_s = 2.90 \sqrt{\frac{29.92}{P_s} \times \frac{1.00}{G_s} \times HT_s}$$

$$V_s = 3.90 \sqrt{\frac{29.92}{P_s} \times \frac{1.00}{G_s} \times HT_s}$$

(4) GAS VELOCITY IN FLUE—Using Type "S" Pitot tube

Assume gas specific gravity equivalent to air, and flue pressure equal to one atmosphere.

For temperature in °F absolute

For temperature in °C absolute

$$V_s = 2.90 F_s \sqrt{HT_s}$$

$$V_s = 3.90 F_s \sqrt{HT_s}$$

For Pitot tube as shown in Figure 5, $F_s = 0.83$

(5) GAS VELOCITY IN FLUE—Using orifice disc meter

Assume gas specific gravity equivalent to air, and flue pressure equal to one atmosphere.

For temperature in °F absolute

For temperature in °C absolute

$$V_s = 2.90 F_d \sqrt{HT_s}$$

$$V_s = 3.90 F_d \sqrt{HT_s}$$

For orifice as described in Figure 6, values of F_d can be obtained from Figure 7.

(6) GAS VOLUME IN FLUE

$$V_o = V_{s, av} \times A \times 60$$

(7) CONVERSION OF FLUE GAS VOLUME TO STANDARD CONDITIONS OF 29.92 INCHES MERCURY PRESSURE AND 0° CENTIGRADE (32° FAHRENHEIT)

For temperature in °F absolute

For temperature in °C absolute

$$V_{std} = V_o \times \frac{P_s}{29.92} \times \frac{492}{T_s}$$

$$V_{std} = V_o \times \frac{P_s}{29.92} \times \frac{273}{T_s}$$

(8) METER RATE—Dry gas—Isokinetic sampling

$$R_m = 0.33 \times \frac{T_m}{T_s} \times V_s \times d^2 \times \frac{P_s}{P_s - P_m}$$

(9) CONVERTING CONDENSATE TO VAPOR VOLUME—Meter conditions

For temperature in °F absolute

$$V_v = 0.00267 \times \frac{V_c \times T_m}{P_s - P_m}$$

NOMENCLATURE

- a —Area of nozzle in square inches.
- A —Effective area of flue in square feet.
- CF —Cubic feet.
- CFM—Cubic feet per minute.
- D —Diameter of flue in inches.
- d —Diameter of sampling nozzle in inches.
- F_a —Orifice disc factor.
- F_p —Pitot tube correction factor.
- g —Acceleration due to gravity in feet per second per second.
- G_a —Specific gravity of gas referred to that of air.
- h —Velocity head in equivalent feet of gas column in the flue.
- H —Velocity head draft gauge reading in equivalent inches of water.
- Hg —Mercury
- M_c —Meter rate correction factor.
- M_m —Volume of moisture remaining in metered gas at meter conditions in cubic feet.
- P_a —Absolute pressure in inches mercury.
- P_b —Barometric pressure in inches mercury.
- P_s —Suction at meter in inches mercury.
- P_f —Absolute pressure in flue in inches mercury.
- R_m —Meter rate in CFM (dependent on gas velocity, nozzle size, and moisture content of gas).
- T —Duration of test in hours.
- T_m —Temperature at meter in degrees absolute.
- T_f —Flue gas temperature in degrees absolute.
- W_d —Weight of dust separated from gas sample in grams.
- V_m —Volume of gas sample as measured by the gas meter in CF at meter conditions.
- V_f —Volume of flue gas in CFM at flue conditions.
- V.P. —Vapor pressure of water in inches of mercury.
- V_f —Flue gas velocity at some given point in feet per second.
- V_t —Total gas sampled converted to flue conditions in CF.
- V_v —Volume of water vapor condensed in cubic feet converted to meter conditions (vapor state).
- V_l —Volume of water condensed in cubic centimeters (liquid state).

CM&E/REID
ISO KINETICS

INLET: $H_2O = 2.5\%$ MT = $76^\circ F$ ST = $80^\circ F$
NOZZLE = $0.472''$ VEL = 8.7 FT/SEC

$$R_{iso} = \frac{0.975 \times 0.33 \times 536^\circ R \times (0.472)^2 \times 8.7 \text{ FT/SEC}}{540^\circ R}$$
$$= 0.62 \text{ ACFM}$$

$$R_{ACTUAL} = 214.40 \text{ ACF} / 360 \text{ MIN} = 0.60 \text{ ACFM}$$

$$\frac{0.60}{0.62} \times 100 = \sim 97\% \text{ ISO KINETIC}$$

OUTLET: $H_2O = 2.7\%$ MT = $68^\circ F$ ST = $78^\circ F$
NOZZLE = $0.50''$ VEL = 9.4 FT/SEC

$$R_{iso} = \frac{0.973 \times 0.33 \times 528^\circ R \times (0.5)^2 \times 9.4 \text{ FT/SEC}}{538^\circ R}$$

$$= 0.74 \text{ ACFM}$$

$$R_{ACTUAL} = 243.71 \text{ ACF} / 360 \text{ MIN} = 0.68 \text{ ACFM}$$

$$\frac{0.68}{0.74} \times 100 = \sim 92\% \text{ ISO KINETIC}$$

SHF

TRUESDAIL LABORATORIES, INC.

LABORATORY No. _____

DATE RECEIVED 8-31-28

CLIENT: C. M. & E.

DATE REPORTED _____

SAMPLE _____

CALIBRATION OF 2 ORIFICE TUBES

METHODS USED _____

DATA & CALCULATIONS: _____

BOTH INSIDE DIA. OF 6.00" $3.44/16 = 0.57$

BOTH ORIFICE RING DIA. OF 3.44" $0.57 = 0.90$ PINT TUBE

0.57

COLLECTION FACT

TUBE "4-1"

ORIFICE TUBE

STD. PINT TUBE

HIGH SPEED 194 CFM

186 CFM

MED SPEED 140 CFM

137 CFM

LOW SPEED 80 CFM

79 CFM

TUBE "4-5"

ORIFICE TUBE

STD. PINT TUBE

HIGH SPEED 195 CFM

186 CFM


MED SPEED 140 CFM

137 CFM

SUMMARY OF RESULTS:

DATE	<u>8</u>	<u>M</u>				
HRS.						
Signed _____						

TRUESDAIL LABORATORIES, INC.



CHEMISTS - MICROBIOLOGISTS - ENGINEERS

14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUELABS

MICROMITE CALIBRATION

DATE: 11/1/88

MICRO	LOW		MED		HIGH	
	MICRO	THERM	MICRO	THERM	MICRO	THERM
A	31 F	32 F	73 F	73 F	212 F	212 F
B	32	32	75	75	211	212
C	32	32	76	75	212	212
D	32	32	75	75	212	212

ICE WATER

AMBIENT AIR

BOILING WATER

CALIBRATED WITH: THERMOMETERS #280-7 and #TL03146

TRUESDAIL LABORATORIES, INC.

MAGNEHELIC CALIBRATION

=====

DATE: 11/01/88

MAGY. # =====	LOW		MED		HIGH	
	MAGY.	MICRO.	MAGY.	MICRO.	MAGY.	MICRO.
1/4" - GW92	0.045	0.044	0.133	0.134	0.233	0.232
1/2" - AM78	0.050	0.050	0.250	0.250	0.450	0.450
1/2" - AG44	0.050	0.048	0.250	0.248	0.450	0.442
1" - NH125	0.110	0.108	0.410	0.418	0.910	0.906
1" - PM283	0.100	0.100	0.400	0.402	0.900	0.986
1" - AM112	0.100	0.100	0.410	0.410	0.460	0.460
2" - PM9	0.250	0.250	0.900	0.900	1.800	1.800
2" - PM28	0.250	0.254	0.900	0.894	1.800	1.800

(CALIBRATED WITH DWYER MICROTECTOR)

TRUESDAIL LABORATORIES, INC.



14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUELABB

CHEMISTS - MICROBIOLOGISTS - ENGINEERS

METER CALIBRATION

=====

11/01/88

METER #003

RUN 1

CBP: 29.96
T in F: 74

WET: 11.943
DRY: 11.971
dY: 0.998

WET TEST #1

DRY TEST #1

VOL	dP	T in F	CFM	VOL	dP	T in F
0.000	*****		0.30	90.53	0.06	*****
1.000	0.35	73.0		91.52	0.06	64.0
2.000	0.35	72.5		92.50	0.06	64.0
3.000	0.35	72.5		93.48	0.06	64.0
4.000	0.34	72.5		94.47	0.06	64.0
4.000	*****		0.50	94.47	0.24	*****
5.000	0.93	72.5		95.45	0.24	64.0
6.000	0.92	72.5		96.43	0.24	65.0
7.000	0.92	72.5		97.42	0.24	65.0
8.000	0.94	72.5		98.41	0.24	65.0
8.000	*****		0.70	98.41	0.51	*****
9.000	1.65	72.5		99.40	0.51	65.0
10.000	1.65	72.5		100.40	0.51	65.0
11.000	1.65	72.5		101.40	0.51	65.0
12.000	1.65	72.5		102.40	0.51	65.0
0.000	*****				*****	
12.000	0.97	72.5		11.870	0.27	64.6

CALCULATION:

$$\text{WET, SCF: } 12.000 * \frac{528}{532.5} * \left(\frac{29.96 + 0.97 / 13.6}{29.92} \right) = 11.943$$

$$\text{DRY, SCF: } 11.87 * \frac{528}{524.6} * \left(\frac{29.96 + 0.27 / 13.6}{29.92} \right) = 11.971$$

TRUESDAIL LABORATORIES, INC.



CHEMISTS - MICROBIOLOGISTS - ENGINEERS

14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUELABS

METER CALIBRATION

11/01/88

METER #003

RUN 2

CBP: 29.92
T in F: 74

WET: 11.961
DRY: 12.025
dY: 0.995

WET TEST #2

DRY TEST #2

VOL	dP	T in F	CFM	VOL	dP	T in F
0.000	*****		0.30	102.40	0.06	*****
1.000	0.38	71.5		103.39	0.06	62.0
2.000	0.42	71.5		104.37	0.06	62.0
3.000	0.38	71.5		105.36	0.06	62.0
4.000	0.38	71.5		106.34	0.06	62.0
4.000	*****		0.50	106.34	0.24	*****
5.000	0.98	71.0		107.34	0.24	62.0
6.000	0.98	71.0		108.32	0.24	62.0
7.000	0.98	71.0		109.32	0.24	62.0
8.000	0.98	71.0		110.30	0.24	62.0
8.000	*****		0.70	110.30	0.51	*****
9.000	1.75	71.0		111.30	0.51	62.0
10.000	1.75	71.0		112.29	0.51	62.0
11.000	1.75	71.0		113.29	0.51	62.0
12.000	1.75	71.0		114.28	0.51	62.0
0.003	*****				*****	
12.003	1.04	71.2		11.880	0.27	62.0

CALCULATION:

$$\text{WET, SCF: } 12.003 * \frac{528}{531.2} * \left(\frac{29.92 + 1.04 / 13.6}{29.92} \right) = 11.961$$

$$\text{DRY, SCF: } 11.88 * \frac{528}{530} * \left(\frac{29.92 + 0.27 / 13.6}{29.92} \right) = 12.025$$

TRUESDAIL LABORATORIES, INC.



CHEMISTS - MICROBIOLOGISTS - ENGINEERS

14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRU ELAB 8

METER CALIBRATION

=====

11/01/88

METER #009

RUN 1

CBP: 29.86
T in F: 74

WET, SCF: 11.915
DRY, SCF: 11.666
dY: 1.021

WET TEST #1

DRY TEST #1

VOL	dP	T in F	CFM	VOL	dP	T in F
0.000	*****	*****	0.30	381.36	0.11	*****
1.000	0.54	72.0		382.33	0.10	65.0
2.000	0.48	72.0		383.30	0.10	66.0
3.000	0.48	72.0		384.27	0.10	66.0
4.000	0.48	72.0		385.21		66.0
4.000	*****	*****	0.50	385.21	0.23	*****
5.000	0.88	72.0		386.19	0.23	66.0
6.000	0.88	72.0		387.16	0.23	66.0
7.000	0.88	72.0		388.14	0.23	66.0
8.000	0.88	72.0		389.10		66.0
8.000	*****	*****	0.70	389.10	0.46	*****
9.000	1.50	72.0		390.07	0.46	66.5
10.000	1.50	72.0		391.05	0.46	66.5
11.000	1.55	72.0		392.03	0.46	66.5
12.000	1.55	72.0		393.00		67.0
0.001	*****	*****			*****	*****
12.001	0.97	72.0		11.640	0.26	66.1


CALCULATION:

$$\text{WET, SCF: } 12.001 * \frac{528}{532} * \left(\frac{29.86 + 0.97 / 13.6}{29.92} \right) = 11.915$$

$$\text{DRY, SCF: } 11.640 * \frac{528}{526.1} * \left(\frac{29.86 + 0.26 / 13.6}{29.92} \right) = 11.666$$

TRUESDAIL LABORATORIES, INC.

CHEMISTS - MICROBIOLOGISTS - ENGINEERS



14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 228-1864

METER CALIBRATION

=====

11/01/88

METER #009

RUN 2

CBP: 29.92
T in F: 74

WET, SCF: 11.953
DRY, SCF: 11.710
dY: 1.021

WET TEST #2

DRY TEST #2

VOL	dP	T in F	CFM	VOL	dP	T in F
0.000	*****	*****	0.30	86.98	0.10	*****
1.000	0.48	71.5		87.96	0.10	67.0
2.000	0.48	71.5		88.95	0.10	67.0
3.000	0.50	71.5		89.93	0.10	67.0
4.000	0.50	71.5		90.91	0.10	67.0
4.000	*****	*****	0.50	90.91	0.23	*****
5.000	0.90	71.5		91.89	0.23	67.0
6.000	0.90	71.5		92.88	0.23	67.0
7.000	0.89	71.5		93.86	0.23	67.0
8.000	0.90	71.5		94.84	0.23	67.0
8.000	*****	*****	0.70	94.84	0.51	*****
9.000	1.65	71.5		95.83	0.51	67.0
10.000	1.70	71.5		96.82	0.51	67.0
11.000	1.65	71.5		97.81	0.51	67.0
12.000	1.70	71.5		98.80	0.51	67.0
0.002	*****	*****		*****	*****	*****
12.002	1.02	71.5		11.68	0.28	67.0

CALCULATION:

$$\text{WET, SCF: } 12.002 * \frac{528}{531.5} * \left(\frac{29.92 + 1.02 / 13.6}{29.92} \right) = 11.953$$

$$\text{DRY, SCF: } 11.680 * \frac{528}{527} * \left(\frac{29.92 + 0.28 / 13.6}{29.92} \right) = 11.710$$

Date : 12-12-88

Client : CM&E INTERNATIONAL

CALCULATION OF CONCENTRATION

SCRUBBER INLET:

1. Concentration (ppm)

$$\begin{aligned} (a) \text{ Cr (total) concentration} &= 239 \frac{\mu g}{ml} \\ &= 239 \frac{\mu g}{ml} \cdot 385 ml \cdot \frac{1 \mu m}{52 \mu g} \cdot \frac{23.7 \mu l}{1 \mu m} \cdot \frac{1 DSCF}{28.3 l} \cdot \frac{1}{207.80 DSCF} \\ &= 7.1 \text{ ppm} \end{aligned}$$

$$\begin{aligned} (b) \text{ Cr}^{+6} \text{ concentration} &= 60 \frac{\mu g}{ml} \\ &= 60 \frac{\mu g}{ml} \cdot 385 ml \cdot \frac{1 \mu m}{52 \mu g} \cdot \frac{23.7 \mu l}{1 \mu m} \cdot \frac{1 DSCF}{28.3 l} \cdot \frac{1}{207.80 DSCF} \\ &= 1.8 \text{ ppm} \end{aligned}$$

2. Concentration (mg/m³)

$$\begin{aligned} (a) \text{ Cr (total) concentration} &= 239 \frac{\mu g}{ml} \cdot 385 ml \cdot \frac{1}{5.89 m^3} \\ &= 15.6 \frac{mg}{m^3} \end{aligned}$$

$$\begin{aligned} (b) \text{ Cr}^{+6} \text{ concentration} &= 60 \frac{\mu g}{ml} \cdot 385 ml \cdot \frac{1}{5.89 m^3} \\ &= 3.9 \frac{mg}{m^3} \end{aligned}$$

3. Emission rate

$$\begin{aligned} (a) \text{ Cr (total) emission rate} &= \frac{15.6 mg}{m^3} \cdot \frac{99 DSCF}{min} \cdot \frac{1 m^3}{35.3 ft^3} \cdot \frac{60 min}{1 hr} \\ &= 2,625 \text{ mg/hr} \end{aligned}$$

$$\begin{aligned} (b) \text{ Cr}^{+6} \text{ emission rate} &= \frac{3.9 mg}{m^3} \cdot \frac{99 DSCF}{min} \cdot \frac{1 m^3}{35.3 ft^3} \cdot \frac{60 min}{1 hr} \\ &= 656 \text{ mg/hr} \end{aligned}$$

Date: 9-15-88

Client: CM&E INTERNATIONAL

SCRUBBER OUTLET:

1. Concentration (ppm)

$$\begin{aligned} (a) \text{ Cr (total) concentration} &= 0.012 \frac{\mu g}{ml} \\ &= 0.012 \frac{\mu g}{ml} \cdot 395 ml \cdot \frac{1 \mu m}{52 \mu g} \cdot \frac{23.7 \mu l}{1 \mu m} \cdot \frac{1 DSCF}{28.3 l} \cdot \frac{1}{207.80 DSCF} \\ &= 0.00037 \text{ ppm} \end{aligned}$$

$$\begin{aligned} (b) \text{ Cr}^{+6} \text{ concentration} &= 0.015 \frac{\mu g}{ml} \\ &= 0.015 \frac{\mu g}{ml} \cdot 395 ml \cdot \frac{1 \mu m}{52 \mu g} \cdot \frac{23.7 \mu l}{1 \mu m} \cdot \frac{1 DSCF}{28.3 l} \cdot \frac{1}{207.80 DSCF} \\ &= 0.00046 \text{ ppm} \end{aligned}$$

2. Concentration (mg/m³)

$$\begin{aligned} (a) \text{ Cr (total) Concentration} &= 0.012 \frac{\mu g}{ml} \cdot 395 ml \cdot \frac{1}{6.90 m^3} \\ &= 0.00069 \frac{mg}{m^3} \end{aligned}$$

$$\begin{aligned} (b) \text{ Cr}^{+6} \text{ Concentration} &= 0.015 \frac{\mu g}{ml} \cdot 395 ml \cdot \frac{1}{6.90 m^3} \\ &= 0.00086 \frac{mg}{m^3} \end{aligned}$$

3. Emission rate

$$\begin{aligned} (a) \text{ Cr (total) emission rate} &= \frac{0.00069 mg}{m^3} \cdot \frac{107 DSCF}{min} \cdot \frac{1 m^3}{35.3 ft^3} \cdot \frac{60 min}{1 hr} \\ &= 0.13 \text{ mg/hr} \end{aligned}$$

$$\begin{aligned} (b) \text{ Cr}^{+6} \text{ emission rate} &= \frac{0.00086 mg}{m^3} \cdot \frac{107 DSCF}{min} \cdot \frac{1 m^3}{35.3 ft^3} \cdot \frac{60 min}{1 hr} \\ &= 0.16 \text{ mg/hr} \end{aligned}$$

Date: 9-15-88

Client: CM&E INTERNATIONAL

EFFICIENCY:

$$\text{Cr (total)} = \frac{2,625 \frac{\text{mg}}{\text{hr}} - 0.13 \frac{\text{mg}}{\text{hr}}}{2,625 \frac{\text{mg}}{\text{hr}}} \cdot 100$$

$$= 99.995 \%$$

$$\text{Cr}^{+6} = \frac{656 \frac{\text{mg}}{\text{hr}} - 0.16 \frac{\text{mg}}{\text{hr}}}{656 \frac{\text{mg}}{\text{hr}}} \cdot 100$$

$$= 99.98 \%$$

TRUESDAIL LABORATORIES, INC.

CM:E, #26163

CHAIN OF CUSTODY

SAMPLING EQUIPMENT PREPARED BY:

DATE

NAME

DATE

NAME

DATE

NAME

FIELD CREW:

DATE

NAME

DATE

NAME

DATE

NAME

DATE

NAME

SAMPLE RECOVERY:

DATE

NAME

DATE

NAME

ANALYSIS:

RELINQUISHED BY:

FOR (ANALYSIS)

RECEIVED BY:

DATE

NAME

DATE

NAME




Fig. 6 ORIFICE DISC METER




Fig. 7 ORIFICE DISC FACTOR

In the discussion above, it has been assumed that the Standard Pitot Tube or one of similar construction, was employed. Where the gases are nearly saturated with some condensable constituent or carry heavy dust loads, this tube tends to stop up. Here, the Special Pitot Tube (Type S) may be used. (Fig. 5)

This Type S Pitot tube does not give the true static pressure, and a correction factor F, must therefore be added to the formula (2), which then becomes

$$(4) V_s = 2.90 F \sqrt{HT} \quad (\text{for temperatures in } ^\circ\text{F absolute})$$

$$V_s = 3.90 F \sqrt{HT} \quad (\text{for temperatures in } ^\circ\text{C absolute})$$

The value of the factor F, must be determined from comparison with a Standard Pitot tube. For the type Pitot tube illustrated, F, averages 0.83 for velocities up to 50 feet per second. For accurate work the individual Pitot tube should be calibrated at the velocity range being measured.

ORIFICE DISC METER

When determining the velocity of gas flowing through relatively small pipes or ducts, an orifice disc may be more convenient than the Pitot tube for obtaining the velocity pressure. Such an arrangement is outlined in Figure 6.

One arrangement of an orifice disc would be a plate of thickness not in excess of 1/50 of the pipe diameter having an accurately cut central, circular opening and may conveniently be located in an existing flanged joint. The gauge connections should be located so that the distance from the orifice disc on the upstream side is $2\frac{1}{2}$ times the pipe diameter D and 8 times the pipe diameter on the downstream side. For other types see the standard references on the subject.

The orifice diameter should be such as to give a suitable gauge reading. They shall not be used with a diameter ratio greater than 0.7. The throat diameter shall not be less than 0.75 inches.

The basic formula expressing the relation between gas velocity through the orifice and the pressure differential is the same as with the Pitot tube

$$(1) V_s = \sqrt{2gh}$$

With orifice discs, however, a factor must be introduced, the value of which depends only on the ratio of the pipe or duct diameter D to the orifice diameter d; hence, where the gas pressure is at standard atmospheric pressure, or 29.92 inches of mercury, and the gas density is equal to that of air, then the formulae for temperatures in $^\circ\text{F}$ and $^\circ\text{C}$ become

$$(5) V_s = 2.90 F_s \sqrt{HT} \quad (\text{for temperatures in } ^\circ\text{F absolute})$$

$$V_s = 3.90 F_s \sqrt{HT} \quad (\text{for temperatures in } ^\circ\text{C absolute})$$

Here, as with the Pitot tube, H is the gauge reading in inches of water.

The numerical constants 2.90 and 3.90 may be corrected for other pressures and densities as in equation (3).

Values of the factor " F_s " for gauge connections located as indicated above, and for the different ratios d/D of the orifice and pipe diameters are given in Figure 7.*

USE OF THE ANEMOMETER

Where the gas velocity is much less than 10 feet per second, the differential gauge reading resulting from the Pitot tube pressures is ordinarily too small to permit accurate measurement. In such cases, an anemometer can be used to advantage. The instrument is usually calibrated to read directly in feet per minute of gas flow. It is, therefore, only necessary to insert the anemometer in the proper position at the point for measurement for some definite time (preferably measured by a stop watch). The difference in the anemometer reading for one minute represents the velocity of the gas at that point in feet per minute. The instrument is hard to keep in adjustment under field conditions and should be carefully calibrated before each use. It should not be used in hot, dirty, or corrosive gas.

*NOTE: For extreme accuracy, all orifice meters should be carefully calibrated.

$$17.16^2 \times \frac{1}{2} = \frac{1}{2} K \Delta P$$

$$1100 \times 50 (1 - \frac{1}{2}) =$$

TRUESDAIL LABORATORIES, INC.

SCAQMD
12-1-88

The sampling trains will be prepared beforehand by soaking all impingers overnight in 50% nitric acid, then rinsing three times with distilled water and charging with 200 mls of 0.1N NaOH. All probes and Teflon tubing will be rinsed on site with 50% nitric acid and washed three times with distilled water. Samples will be recovered by measuring condensate gain and rinsing the probe, Teflon tubing, and impingers twice with 0.1N NaOH and once with 0.1N nitric acid. The Teflon filter will be placed in the impinger collection.

The flue gas flow rate will be determined by the inline orifice tubes on the inlet and outlet test locations. The flow will be monitored throughout the entire test period by recording the velocity head and temperature at 30-minute intervals. The average temperature at each location will be measured with a chromel-alumel thermocouple connected to a Micromite potentiometer. The sampling trains and flow measurement equipment will be leak-checked before and after use.

The total chrome will be determined by atomic absorption spectroscopy and the hexavalent chrome by the diphenylcarbazide colorimetric method. The analyses will include calibration curves, spike recovery, and a blank sampling train.

The hydrogen, nitrogen and oxygen content of the integrated samples will be determined by gas chromatography utilizing thermal conductivity detection.

The test report will include a copy of this test plan, the field data, chain of custody, calculations, and recent calibrations of the flow measuring devices.

The test is currently scheduled for December 12, 1988 at 8:00 AM.

Please contact me at (714) 730-6239 if you need more information.

Sincerely,

TRUESDAIL LABORATORIES, INC.

S. Hugh Brown, Supervisor
Air Pollution Testing

cc: Dave Miller - CM and E

TRUESDAIL LABORATORIES, INC.



PLEASE REPLY TO

CHEMISTS - MICROBIOLOGISTS - ENGINEERS
RESEARCH - DEVELOPMENT - TESTING

ESTABLISHED 1951

14201 FRANKLIN AVENUE
TUSTIN, CALIF. 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
FAX 714 • 730-5452

December 1, 1988

507-2112-63

SCAQMD
9150 Flair Drive
El Monte, CA 91731
Attention: Andrew Lee

Dear Andrew:

This letter is to serve as our test plan for conducting source tests for total and hexavalent chromium on a VSV/MECA II control device installed on the plating operation at Reid Metal Finishing in Santa Ana, California. The control device will be tested for a 6-hour period at the inlet and outlet simultaneously. Each sampling location will consist of a 6-inch orifice disc tube 11 feet long and installed in-line on the control device.

The chromium will be determined by a modified version of the wet impingement method (SCAQMD method 5.1). The sampling train will consist of a glass probe connected with Teflon tubing to a set of Greenburg-Smith impingers charged with 200 mls of 0.1N NaOH and followed by a Teflon filter on a glass fiber backing filter, a vacuum pump, and a dry gas meter. Each sample will be collected isokinetically at 4 points on each of two diameters, 90° apart. The isokinetic sampling rates will be determined either from a preliminary traverse with a mini-Standard Pitot tube and Magnehelic differential pressure gage, or by back calculation from the observed orifice velocity during the test period. Near the end of the test a 60-minute integrated sample of the flue gas will be taken at each location with an evacuated 7-liter aluminum cylinder.

BRANCH OFFICES

133 NO. SAN GABRIEL BLVD. SUITE 204, PASADENA, CA 91107	•	(619) 405-8019
1154 FORT STREET MALL #218, HONOLULU, HAWAII 96813	•	(808) 541-5450
6165 GREENWICH DRIVE, SUITE 340, SAN DIEGO, CA 92122	•	(619) 546-3742

MEMBERSHIPS

Corporation and Staff Memberships in over thirty Professional, Scientific and Technical Societies and Organizations including Charter Membership in the American Council of Independent Laboratories

Date : 12-12-88

Client : CM&E INTERNATIONAL

SUMMARY OF REPORT

	SCRUBBER INLET	SCRUBBER OUTLET
FLUE GAS :		
Temperature, °F	80	78
Velocity, ft/sec (Thro orifice)	26.9	29.0
Static pressure, in. H ₂ O	-0.32	+0.31
Duct diameter, in.	6.0	6.0
Orifice diameter, in.	3.44	3.44
Orifice area, sq.ft	0.065	0.065
Gas volume: ACFM	105	113
SCFM	102	110
DSCFM	99	107
Moisture, % by volume	2.5	2.7
CHROMIUM :		
Sample volume, DSCF	207.80	243.71
Concentration, ppmv:		
Total Cr	7.1	0.00037
Cr+6	1.8	0.00046
Concentration, mg/m ³ :		
Total Cr	15.6	0.00069
Cr+6	3.9	0.00086
Emission rate, mg/hr:		
Total Cr	2,625	0.13
Cr+6	656	0.16
Removal Efficiency, %:		
Total Cr	-	99.995
Cr+6	-	99.98
INTEGRATED SAMPLE :		
Concentration, %		
Hydrogen (H ₂)	0.1	0.1
Oxygen, (O ₂)	21.3	21.0
Carbon dioxide (CO ₂)	<0.1	<0.1

Respectfully submitted,
TRUESDAIL LABORATORIES, INC.

S. Hugh Brown, Supervisor
Air Pollution Testing