

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 12.20

Background Chapter: 4

Reference Number: 36

Title: September 1984 (Naval Energy and Environmental Support Activity, Port Huenana, CA) Source Emission Testing and Industrial Ventilation Survey of Bldg. 210 Plating Shop

June 1984

ELECTROPLATING

REF. 4-36

4

SOURCE EMISSION TESTING AND INDUSTRIAL VENTILATION SURVEY
OF BUILDING 210 PLATING SHOP
Long Beach Naval Shipyard
Long Beach, California
7 May - 2 June 1984

ACCEPTABLE

SOURCE EMISSION TESTING OF THE BUILDING 195 PLATING SHOP
Norfolk Naval Shipyard
Portsmouth, Virginia
11-18 March 1985

ACCEPTABLE



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Office of Air Quality Planning and Standards
Research Triangle Park, North Carolina 27711

122 : 109

MEMORANDUM

SUBJECT: Acceptability of Test Reports for Use as a Data
Base for Chromium NESHP

FROM: Frank R. Clay *FR*
Field Testing Section, EMB, TSD (MD-14)

TO: Andrew Smith
Industrial Studies Branch, ESD (MD-13)

I have reviewed the test reports that are attached. Some of the reports are acceptable while others are not. The reports are listed below, and unacceptable reports are described in detail as to why they should not be used. I will continue to review the other reports that you have given to me and will send another group of reports as soon as the review has been completed.

TRUESDAIL LABORATORIES, INC.
Test of Dames and Moore
222 E. Annapamu
Santa Barbara, California 93101

UNACCEPTABLE

In reviewing the data, the outlet location gives the moisture content at the outlet as 2.50 percent. At 66°F, saturation moisture content at the absolute stack pressure and this temperature is 2.16 percent.

There are no meter box calibration sheets present, and consequently, no meter box correction factor.

There are no delta p values on the field data sheets to determine the point velocities during sampling.

The nozzles do not appear to have been measured with a micrometer.

TRUESDAIL LABORATORIES, INC.
Source Test of Intermetro Industries
9393 Arrow Highway
Cucamonga, California 91730

UNACCEPTABLE

Page 1 of the report describes cyclonic flow that was found at the outlet. The page also mentions that sampling was done at the angle of maximum velocity head which was 45 degrees. When testing for cyclonic flow, the angle of maximum delta p is not the angle of flow. The angle of flow is 90 degrees from the null reading on the pitot tube which is not the same as the angle of maximum delta p. When cyclonic flow is present, the sampling time per point must also be adjusted based on the angle. If all the angles are the same, the time adjustment is not necessary, however, in this case, it is not possible to know what the true angles were.

EMBEE PLATING TEST
2136 South Hathaway
Santa Ana, California 92705

UNACCEPTABLE

This report should not be used. First, there are not enough data sheets and related forms/sheets to tell how precisely the test was performed. On System 1, the moisture content was given at 3.7 percent. Saturation moisture content at 70 degrees F is 2.47 percent. Emission data based on 3.7 percent are incorrect. The text also mentions that a piece of 3/8 inch Teflon tubing was used to collect the sample. There is no mention of a nozzle so it must be assumed that the tubing is also the nozzle. To sample isokinetically, the sample size should have been around 90 cubic feet an hour. The sample volume was about half that so the sampling was not within the acceptable isokinetic limits. For System 2, the runs are not within the isokinetic limits that the Agency requires.

CHEVROLET LIVONIA BUMPER PLANT

No. 4 Heil Evaporator

Tested by the Chevrolet Central Office of Environmental
Engineering Department

Tested September 24, 1979

UNACCEPTABLE

This report is unacceptable for the following reasons: First, the necessary field data sheets to determine the correctness of the values in the report are not available. Second, all points at the inlet were not sampled (see further comments). Third, this test effort was made to gather data to correct emission problems, not to sample the control device in normal operating conditions. Fourth, there appears to be a large discrepancy between the volumetric flow rates found by the EMB test and this test.

This facility has been tested by EMB, but only at the inlet location. EMB testing performed in the normal production mode. The test done by the Chevrolet environmental group was done in an effort to maximize collection efficiency, and two parameters of the evaporator operation were monitored and/or altered to simulate conditions which could exist within the system, possibly causing an upset in the collection efficiency of the unit. Thus data generated on this test may not be typical of normal operating conditions.

The Chevrolet test sampled the inlet location at only two ports and chose sampling points of average velocity. While the points may be of average velocity, it does not necessarily follow that the distribution of chromium in the duct is uniform. Furthermore, the outlet volumetric flow rate was also used to determine emissions at the inlet. If leakage occurs between the inlet and outlet, the mass emission rates at the inlet will be biased high and the control device efficiency will also be biased high. When comparing the inlet volumetric flow rates, the EMB flows are about 28 percent lower than company flows.

In checking the outlet data, there are no field data sheets or other associated data sheets that were generated at the site; only typewritten data are provided. It appears that the calculations were done based on 70 degrees as standard temperature rather than 68.

It appears that the outlet data might be usable if the data sheets from the test could be provided. One item to consider, however, is whether or not this test represents process conditions that could be used in determining chromium emission standards.

accept

NEESA 2-119

September 1984

SOURCE EMISSION TESTING
AND
INDUSTRIAL VENTILATION SURVEY
OF BUILDING 210 PLATING SHOP

at

Long Beach Naval Shipyard
Long Beach, California
7 May-2 June 1984

By:

Susan Suzuki
William Powers
Robert Wood

Naval Energy and Environmental Support Activity
Port Hueneme, California 93043-5014

EXECUTIVE SUMMARY

Emission testing was performed on five wet scrubbers at the Electronics Weapons Precision Facility Plating Shop, Building 210, Long Beach Naval Shipyard, from 7 May to 2 June 1984. An industrial ventilation survey of the plating shop was performed concurrently with the emission testing program.

A. Emission Testing

Emission tests show that four of the scrubbers operating at the plating shop are unnecessary due to the negligible pollutant concentrations entering the scrubbers. Recommend that scrubbers on exhaust lines 101, 102, 105, and 106 be taken out of service and that the internal gas cleaning components be removed from these scrubbers to reduce the static pressure load on the exhaust fans. A reduction in exhaust fan static pressure load will reduce fan power requirements and result in significant energy savings.

Pollutant concentrations in exhaust lines 103 and 104 are high and the use of scrubbers on these exhaust lines is appropriate. The efficiency of the scrubber on Line 103 (chrome plating tank exhaust) is greater than 90%, adequate to control the chromic acid mist emissions. The scrubber on Line 104 (hydrochloric acid tank exhaust) was not operational during the test period and efficiency testing was not performed on Scrubber 104. Extensive acid attack of metal surfaces in the vicinity of the Scrubber 104 outlet indicates inadequate scrubber efficiency. Efficiency testing of the scrubber on Line 104 is recommended. It is also recommended that feedwater flowmeters be installed on the scrubbers on lines 103 and 104 to ensure scrubbers are operating at feedwater flowrates required for maximum scrubber efficiency.

B. Ventilation

Existing mechanical supply air equipment provides 94,000 standard cubic feet per minute (SCFM) less than is required to provide a balance with exhausted air. This condition causes turbulent cross-drafts which reduce local exhaust hood capture efficiencies. Recommend the installation of additional supply air equipment to correct the 94,000 SCFM imbalance. Sealing the three 8-foot by 8-foot wall-mounted air grills and providing tank baffles are also recommended to improve capture efficiency.

Recommend sealing the sump trench connecting exhaust lines 101, 102, and 103 to prevent cross-contamination. Installation of indicating devices to monitor supply air and exhaust air fans is also recommended to ensure proper fan operation.

Table of Contents

		<u>Page</u>
	Nomenclature.....	iv
<u>Section</u>		
I	Introduction.....	1
II	Technical Background.....	1
III	Procedure.....	17
IV	Chain of Custody.....	38
V	Results.....	39
VI	Discussion.....	39
VII	Conclusions.....	60
VIII	Recommendations.....	62
	References.....	65

Appendixes

A	Tank Data.....	A-1
B	Field Data.....	B-1
C	Truesdail Report.....	C-1
D	Impactor Discussion.....	D-1
E	Sample Calculations.....	E-1
F	Tare Weight Data.....	F-1
G	Equipment Calibration Sheets.....	G-1
H	Ventilation Data.....	H-1
I	Photographs of Impactor Filter Stages.....	I-1
J	Team Resumes.....	J-1

Figures

1	Scrubber and Tank Locations, B210 Plating Shop.....	2
2	Line 101.....	3
3	Line 102.....	4
4	Line 103.....	5
5	Line 104.....	6
6	Line 105.....	7
7	Line 106.....	8
8	Supply Air Schematic.....	9
9	Sampling Point Location, Inlet.....	26
10	Sampling Point Location, Outlet.....	27
11	Mass Emissions Sampling Train, Inlet.....	28
12	Mass Emissions Sampling Train, Outlet.....	29

Table of Contents (Contd.)

	<u>Page</u>
<u>Figures (Contd.)</u>	
13 Gas Conditioner.....	31
14 Particle Sizing Sampling Train, Inlet.....	34
15 Particle Sizing Sampling Train, Outlet.....	35
16 University of Washington Mark III Cascade Impactor (Modified)	36
17 Mass Mean Particle Diameter, Scrubber 103 Inlet.....	56
18 Mass Mean Particle Diameter, Scrubber 103 Outlet.....	57

Tables

1 Tank Data.....	11
2 Tank Loading Summary.....	19
3 Tank Loading.....	20
4 Electrical Equipment Rating.....	25
5 Mass Emissions Data--Flow Rate and Isokinetic.....	40
6 Mass Emissions Data--Sample Volume and Lab Sample Weight....	41
7 Analysis Schedule for Samples.....	42
8 Mass Emissions Chemical Analysis Results.....	43
9 Mass Emissions Data--Concentration vs OSHA Standards.....	47
10 Impactor Data--Flow Rate and Isokinetic.....	48
11 Impactor Data--Stage 5 Aerodynamic Cutpoints.....	49
12 Scrubber 103, Total Chromium Particle Sizing Test Results...	50
13 Static Pressure Drop Across Scrubbers.....	52
14 Supply Air Flow Rates.....	53
15 Exhaust Air Flow Rates.....	54

NOMENCLATURE

<u>Symbol</u>	<u>Unit</u>	<u>Description</u>
A _s	in ²	Stack cross sectional area
	CF	Cubic feet
	CFM	Cubic feet per minute
	BHP	Brake horsepower
CO ₂	%	Measured carbon dioxide content
CO _{2m}	SCFM	Carbon dioxide measured flow rate = (CO ₂)(Q _s)/100
C _p		Pitot tube calibration factor
D _n	inches	Nozzle diameter
D _p	microns	Particle diameter
	DSCF	Dry standard cubic feet
	DSCFM	Dry standard cubic feet per minute.
D _{p50}	microns	Mass mean particle diameter
	ft/min	Feet per minute
G	32.1725 ft/sec	Acceleration due to gravity
	g	Gram
	gr	Grain, 1/7000th of a pound
	hp	Horsepower
	hr	Hour
ZI	%	Isokinetic
	lb	Pound
	kW	Kilowatt
ZM	%	Percent moisture in stack gas by volume
ME	%	Mechanical efficiency
M _d		Mole fraction dry gas

<u>Symbol</u>	<u>Unit</u>	<u>Description</u>
	μ	Micron, 1×10^{-6} meters
	mg	Milligram, 1×10^{-3} grams
M_f	g	Particulate weight collected on probe and filter
M_t	g	Particulate weight—total
M_w	g	Mass of water in particulate train
MW	lb/lb-mole	Molecular weight of stack gas
MW_{air}	28.9641 lb/lb-mole	Molecular weight of air at standard conditions
MW_d	lb/lb-mole	Molecular weight of dry stack gas
MW_{H_2O}	18.0153 lb/lb mole	Molecular weight of water
O_2	%	Measured oxygen content
Pb	"Hg absolute	Barometric pressure
Ps	"Hg absolute	Stack pressure
ΔP	"H ₂ O	Velocity head of stack gas
P_{std}	29.92125 "Hg	Standard barometric pressure
Q_s	DSCFM	Stack gas dry flow rate
R	21.85 "Hg-ft ³ /lb-mole-R°	Universal gas constant
	RPM	Revolutions per minute
	SCF	Standard cubic feet
SP	"H ₂ O	Static pressure
t_{amb}	°F	Ambient temperature
t_m	°F	Control box meter temperature
T_t	min	Net time of test
t_s	°F	Stack gas temperature
T_{std}	528°R	Standard temperature

<u>Symbol</u>	<u>Unit</u>	<u>Description</u>
V_m	ft ³	Volume of dry gas sampled @ meter conditions
$V_{m\text{ std}}$	DSCF	Volume of dry gas sampled @ standard conditions
V_s	fpm	Stack velocity @ stack conditions
V_w	ml	Total water collected in impingers and desiccant
$V_{w\text{ gas}}$	ft ³	Volume of water vapor collected @ standard conditions
ΔH_0	"H ₂ O	Orifice pressure drop across meter
ρ_{air}	0.075224 lbs/ft ³	Density of air at standard conditions
$\rho_{\text{H}_2\text{O}}$	62.31639 lbs/ft ³	Density of water at standard conditions
$\rho_{\text{H}_2\text{O}}$	0.99824 g/ml	Density of water at standard conditions

Standard conditions are 68°F, 29.92126 "Hg

<u>Symbol</u>	<u>Description</u>
Ag^+	Silver ion
AgCN	Silver Cyanide
Al^{+++}	Aluminum ion
Cd^{++}	Cadmium ion
Cl^-	Chloride ion
CN^-	Cyanide ion
$\text{CO}_3^{=}$	Carbonate ion
Cr^{+3}	Trivalent Chromium ion
Cr^{+6}	Hexavalent Chromium ion
Cr_{tot}	Total Chromium ion
CrO_3	Chromic Acid
Cu^{++}	Copper ion
CuCN	Copper Cyanide
F^-	Fluoride ion
HCL	Hydrochloric Acid/Muriatic Acid
K^+	Potassium ion
K_2CO_3	Potassium Carbonate
KCN	Potassium Cyanide
KOH	Potassium Hydroxide
Na^+	Sodium ion
Na_2CO_3	Sodium Carbonate
NaCN	Sodium Cyanide
NaOH	Sodium Hydroxide
Ni^{++}	Nickel ion
$\text{NiCl}_2 \cdot 6\text{H}_2\text{O}$	Nickel Chloride
NiSO_4	Nickel Sulfate
PO_4^{-3}	Phosphate ion
$\text{SO}_4^{=}$	Sulfate ion

LONG BEACH NAVAL SHIPYARD PLATING SHOP

I. INTRODUCTION

In response to a request¹ from Western Division, Naval Facilities Engineering Command (WESTNAVFACENGCOM), San Bruno, California, the Naval Energy and Environmental Support Activity (NAVENENVSA) Source Emission Test (SET) team tested emissions from five wet scrubbers at the Electronic Weapons Precision Facility Plating Shop, Building 210, Long Beach Naval Shipyard (NAVSHIPYD), from 7 May to 2 June 1984. An industrial ventilation survey was also performed during the emission test period.

II. TECHNICAL BACKGROUND

A. General


Lack of adequate emissions data has made it difficult to determine the level of emission control necessary on cleaning and plating processes in Navy plating shops. Commander, Naval Facilities Engineering Command (COMNAVFACENGCOM) tasked NAVENENVSA to evaluate emissions from selected Navy plating shops to determine the level of air pollution control needed for various plating shop processes. Building 210 plating shop, Long Beach NAVSHIPYD is one of two Navy plating shops being tested by the NAVENENVSA SET team. Long Beach NAVSHIPYD requested NAVENENVSA test the plating shop ventilation system during air emissions testing. Results from ventilation system testing are reported concurrently with the air emissions test results.


B. Facility Description

1. General. The plating shop ventilation system consists of six separate local exhaust systems (figures 1-7) and four roof-mounted heating and ventilating (HV) units supplying air through sixteen concentric cone diffusers mounted in the ceiling (Figure 8). The local exhaust systems ventilate thirty-three tanks, with push-pull exhaust hoods on eighteen tanks and lateral exhaust hoods on fifteen tanks.

2. Exhaust System. The plating shop exhaust system consists of six subsystems: Chrome line, acid line, heavy metal line, chromate line, and two alkaline lines. Two scrubbers (101 and 102), each designed to operate at 35,000 cfm, serve the alkaline tanks. The chrome line has one scrubber (103) designed to operate at 25,000 cfm. The acid line has one scrubber (104) designed to operate at 39,000 cfm. The heavy metal line (105) and the chromate line (106) each have scrubbers designed to operate at 50,000 cfm. See figures 1-7.


The scrubbers are thin-bed packed tower units designed for the control of aerosols. These units consist of a spray chamber with media pads located below a network of spray nozzles. The chamber is followed by mist eliminator pads. The scrubber body is mated to the fan by a reducing transition.






<u>Tank No.</u>	<u>Item</u>
8	Alkaline cleaner
9	Zinc Phosphate
18	Manganese phosphate
23	Electro cleaner
25	Electro cleaner
26	Nickel sulfamate

Figure 2. Line 101




<u>Tank No.</u>	<u>Item</u>
4	Electro-cleaner
33	Nickel plate
48	Alkaline cleaner
50	Satin etch

Figure 3. Line 102




<u>Tank No.</u>	<u>Item</u>
41	Hard chrome
42	Hard chrome
43	Hard chrome
44	Decorative chrome

Figure 4. Line 103



<u>Tank No.</u>	<u>Item</u>
3	Muriatic (HCL) acid
5	Sulfuric acid strip
6	Sulfuric acid strip
15	Counter-flow rinse
14	Iradite

Figure 5. Line 104



<u>Tank No.</u>	<u>Item</u>
1	Cad plate
11	Cad plate
20	Nickel strike
21	Silver plate
22	Silver plate
29	Copper plate

Figure 6. Line 105





Figure 7. Line 106



○ : Concentric Cone Diffusers HV-XX : Heating & Ventilating Units
 △ : Pitot Traverse Locations

Figure 8. Supply Air Schematic

Thin-bed packed towers collect liquid aerosols by particle size growth in the spray chamber section. Removal is accomplished by impingement in the media pads.

Table 1 identifies the plating tanks and tank chemical solutions served by each line.

3. Supply Air System. Air exhausted from the plating shop is partially supplied by four mechanical heating and ventilating units on the roof. Infiltration through three 8-foot by 8-foot wall grills, two 6-foot by 9-foot double doors, and two 6-foot by 7-foot double doors accounts for the additional supply air. The three grills and two 6-foot by 9-foot doors are located in the northwest wall. The two doors remained open 24 hours a day during the survey.

C. Air Emission Sources³

Air pollution is associated with two processes in the plating operation, cleaning and electroplating. In the cleaning process, work pieces are cleaned to remove oil, grease, dirt, scale, and old plating. Cleaning involves the following major steps:

1. Mechanical cleaning to remove loose dirt and scale is usually done using a wire brush or wire wheel. Some particulate air pollution is produced, though the particles are large and their effect is limited to the work area.

2. Precleaning by solvent-soaking or vapor-degreasing is used to clean heavily soiled or painted items. Hydrocarbon gases can be generated by the process, but usually are not a major source of pollution unless the precleaning operation is large. The Long Beach NAVSHIPYD plating shop has three tanks for this purpose. Potentially hazardous gases are emitted from these tanks, which have no exhaust ventilation.

3. Intermediate cleaning in a strong alkaline bath is used to further remove greases. Aerosols are formed by the intermittent dipping of items into these solutions. Aerosols can also be formed by agitation or splashing during the cleaning process. The amount of aerosol formed is usually small and represents a localized nuisance in the shop rather than an air pollution source. Intermediate alkaline cleaning in the Long Beach NAVSHIPYD plating shop is not an air pollution problem, but it is responsible for localized corrosion around the cleaning tanks.

4. Electrocleaning, one of the two final cleaning steps, is accomplished by passing a current through a strong alkaline bath. Chemical action from the caustic solution dissolves and loosens remaining dirt. Mechanical action from electrolysis (gassing) lifts off the loosened dirt. Gassing can form an aerosol mist at the liquid surface and contribute small amounts of airborne emissions.

5. Pickling is also used in the cleaning process. Pickling is achieved by soaking items in an acid bath with or without an induced current. The cleaning process is similar to electrocleaning but usually produces more

TABLE 1
Tank Data

Location: LBNSY, Plating Shop
Building: 210

Date: _____

Scrubber No.	Tank No.	Dimensions LxWxD (ft)	Capacity (gallons)	Temp (°F)	Name	Constituents (oz/gal)
101	8	9x3.5x6	1300	140	Cleaner soak A-54	Cee-Bee A-54 (8-16, sodium orthosilicate 10-20%)
101	9	9x3.5x6	1300	150	Phosphate Acid	
101	18	9x3.5x6	1300	120	Phosphate Seal	
101	23	9x3.5x6	1300	150	Electro Cleaner PD #77	Cee-Bee PC-77 (2-3, sodium orthosilicate 30-50%, NaOH 40-60%) pH 12.5
101	25	16x1.5x5	900	150	Caustic Cleaner Soak #107	Micel soak #107 (8-16, NaOH 20%)
101	26	16x1.5x5	900	150	Al Etch #3	Omega Al Etch #3 (2-12, NaOH 95%) pH 13
102	4	16x6x8	5400	180	Caustic Cleaner #180	Cleaner 180 (4)
102	33	9x3.5x6	1300	150	Nickel Plate	Ni (10-14) + NiCl ₂ 6H ₂ O (6-12) + NiSO ₄ (36-48) + Boric Acid (6-7) pH 4-4.6
102	48	5x5x5	700	Room	Caustic Cleaner, Soak	
102	50	5x5x5	700	180	Al Etch #3	Omega Al Etch #3 (2-12, NaOH 95%) pH 13

TANK DATA

Location: LBNSY, Plating Shop
Building: 210

Date: _____

Scrubber No.	Tank No.	Dimensions LxWxD (ft)	Capacity (gallons)	Temp (F)	Name	Constituents (oz/gal)
103	41	16x3.5x6	2500	132	Hard Chrome	CrO ₃ (33) + SO ₄ (0.17)
103	42	9x3.5x16	3650	132	Hard Chrome	Same as above
103	43	9x3.5x6	1300	132	Hard Chrome	Same as above
103	44	9x3.5x6	1300	115	Decorative Chrome	CrO ₃ (24) + SO ₄ (0.13)
104	3	9x3.5x6	1300	Room	Muratic Acid	HCL
104	5	9x3.5x6	1300	Room	Electro Strip	
104	6	9x3.5x6	1300	Room	Muratic Acid	HCL
104	14	9x3.5x6	1300	Room	Iridite	
104	15	9x3.5x6	1300	Room	Water Rinse/ Paint Stripper	
105	1	9x3.5x6	1300	Room	Cadmium	Cd (2.6-3.3) + NaCN (16-18) + Na ₂ CO ₃ (2-8) + NaOH (2.5)
105	11	9x3.5x6	1300	Room	Cadmium Cyanide	Same as above
105	20	9x3.5x6	1300	Room	Nickel Strike	NiCl ₂ 6 H ₂ O (16-32) + HCL (8-16)

TANK DATA

Location: LBNSY, Plating Shop
Building: 210

Date: _____

Scrubber No.	Tank No.	Dimensions LxWxD (ft)	Capacity (gallons)	Temp (F)	Name	Constituents (oz/gal)
105	21	9x3.5x6	1300	Room	Silver Plate	AgCN (6) + KCN (12-14) + K ₂ CO ₃ (2-12)
105	22	9x3.5x6	1300	Room	Silver Strike	AgCN (0.3-0.5) + KCN (12)
105	29	9x3.5x6	1300	140	Copper Plate	CuCN (7.5-8) + KCN (2.5-3) + KOH (1.75-2)
106	16	9x3.5x6	1300	Room	Copper Brite 320	Micel Copper Brite 320 (B-32, Acidic)
106	19	9x3.5x6	1300	160-170	Phosphate Detergent	
106	28A	16x1.5x5	700	Room	Smutt-off "A"	Omega smutt-off A (8-16, CrO ₃ 10%, Fluoride salts 1%) Acidic
106	35	16x1.5x5	900	Room	Aurous #19	Omega Aurous #19 (2, CrO ₃ 45-55%, Barium Nitrate 15-25%, Sodium silicofluoride 10-20%, Potassium Nitrate 5-15%) pH 1.5
106	36	16x1.5x5	900	Room	Micro Brite Seal	Micel micro brite seal (1.3) + CrO ₃ (2.6)

TANK DATA

Location: LBNSY, Plating Shop
Building: 210

Date: _____

Scrubber No.	Tank No.	Dimensions (LxWxD (ft))	Capacity (gallons)	Temp (F)	Name	Constituents (oz/gal)
106	28B	16x1.5x5	700	Room	Micro Brite Etch	Micel Micro brite (10.3) + HCL (.34% Vol)
106	45	5x7x5	700	Room	Aurous #19	Omega Aurous #19 (3/4-2 1/4, CrO3 45-55%, Barium Nitrate 15-25%, Sodium Silicofluoride 10-20%, Potassium Nitrate 5-15%)
106	47	5x5x5	700	Room	Smutt-off "A"	Omega smutt-off A (8-16, CrO3 10%, Fluoride Salts 1%)
N/A	31	9x3.5x6	1300	Room	Sour Water	HCL (10% - Trilacid Salts #303)
N/A	52	5x10x5	1400	Room	Paint Strip	Magnaflux Omega 11321X stripper (full strength, ChHCl's 82%, Phenol 9%, Formic Acid 5%)
N/A	24	N/A	N/A	N/A	Nonexistent	
N/A	2				Water Rinse	
N/A	7				Water Rinse	
N/A	10				Water Rinse	

TANK DATA

Location: LBNSY, Plating Shop
 Building: 210

Date: _____

Scrubber No.	Tank No.	Dimensions LxWxD (ft)	Capacity (gallons)	Temp (F)	Name	Constituents (oz/gal)
N/A	12				Water Rinse	
N/A	13				Water Rinse	
N/A	15				Water Rinse	
N/A	17				Water Rinse	
N/A	27				Water Rinse	
N/A	30				Water Rinse	
N/A	32				Water Rinse	
N/A	34				Water Rinse	
N/A	37				Water Rinse	
N/A	39				Water Rinse	
N/A	46				Water Rinse	
N/A	49				Water Rinse	
N/A	51				Water Rinse	

gassing. In addition, electro-pickling creates more gases than ordinary pickling. The electroprocesses, however, are both faster and more thorough. Significant amounts of air pollutants can be generated during this process.

The second and greatest source of air emissions is the plating process itself. Emissions are generated by two sources: electrolytic processes, and tank loading and unloading.

A portion of the electrical power applied to the plating solution is consumed by the electrolysis of water in the solution. Hydrogen and oxygen are produced and bubble to the surface, causing a condition known as "gassing." The vigorous hydrogen gassing at the cathode tends to remove any contaminants left from the cleaning process. It is this mechanical action that makes electroplating feasible.

Most electroplating and cleaning operations have little impact from an air pollution standpoint. When emissions are non-offensive and small in volume due to low gassing rates, air pollution control equipment is not required. Building ventilation is required, however, for worker safety and corrosion prevention.

Exhaust gases from chrome plating tanks do require air pollution control equipment. Large volumes of both hydrogen and oxygen are liberated during chrome plating. The bubbles break the surface and produce a chromic acid aerosol. The aerosol is then carried into the shop ambient air and is eventually discharged to the environment. Since chromic acid is both toxic and corrosive, its discharge requires control. The emission of chromic acid mists will often result in nuisance complaints and property damage. Especially susceptible are automobile paint finishes which can be spotted by even small amounts of the mist.

Hard chrome plating produces an extremely hard, corrosion-resistant coating. It is used in rebuilding and repairing operations to build up worn parts, especially shafts. Hard chrome plating requires a current density of approximately 250 amperes per square foot of workpiece area. This high current density produces large quantities of hydrogen and oxygen and a dense chromic acid mist. The plating facility at Long Beach NAVSHIPYD has three large hard chrome plating tanks which are vented through a scrubber to the atmosphere.

Decorative chrome plating is typically used on small items such as plaques and name plates. Decorative chrome plating requires a current density of approximately 100 amperes per square foot of workpiece area, and, therefore, evolves less gas than hard chrome plating. There is one decorative chrome tank at the Long Beach NAVSHIPYD plating shop.

Splash fill of piece work into and out of tanks, and splash fill of liquid into tanks, generates aerosol mists containing large liquid droplets (>15 um diameter) of plating solution. Aerosol mists generated by splash filling tend to deposit on interior exhaust line surfaces and are not a significant source of air pollution.

D. Emission Removal Mechanisms

Contaminants generated from open surface tanks used in plating are controlled by local exhaust hoods. Typically, the exhaust ductwork from several tanks containing similar chemical solutions are combined and vented to the atmosphere through one exhaust fan. Local exhaust hoods used at the plating shop contain slots across the length of the hood (slot hood) to evenly distribute the exhaust suction. Slot hoods require a face velocity of 2000 feet per minute (fpm) and a plenum velocity not greater than one-half the face velocity.² These hood design criteria are given in Appendix H. The 2000 fpm face velocity is recommended so that uniform suction is maintained at the slot. Slot hoods should not be greater than 10 feet in length. Splitters or multiple take-offs are used to reduce the effective slot length in hoods greater than 10 feet in length.

Cross drafts are controlled by using side and hood baffles. Side baffles increase effective tank height and help contain aerosols in the tank area.

The quantity of exhaust air used to control a given tank must be adequate to effectively remove contaminants from the tank surface area and exhaust them outside the building. Exhaust rates based on exhaust hood type, tank contents and process conditions are provided in American National Standards Institute (ANSI) Z9.1--1977, "Practices for Ventilation and Operation of Open-Surface Tanks." Plating shop exhaust system design should comply with this standard.

Aerosol emissions can be reduced by floating one or more layers of plastic spheres, cylinders, or ellipsoids on the liquid surface. Tests indicate that aerosol emissions and evaporation can be reduced by as much as 90%, and that heat losses from open tanks can be reduced by as much as 80% by using floating layers. Both hollow and solid balls are used. They are usually made of high density polyethylene (HDPE) or polypropylene (PP). Solid PP or hollow HDPE balls are normally used for hard chrome plating solutions. Some success has been achieved using solid PP balls on nitric/sulfuric acid bright-dip tanks. It is important to understand that gassing is not affected by the floating ball covers. The chief advantage is limitation of aerosol formation by gassing and reduction of process heat losses.

Several disadvantages can arise from using floating ball covers on plating tanks. First, floats are sometimes dragged out of the tanks with the work. Once out of the tanks, they may inadvertently enter drain systems. Drains and liquid effluent handling equipment have been plugged and damaged in this manner. Second, at elevated temperatures, hollow floats may burst and spray liquid into the work area. Third, hollow floats sometimes leak and sink to the bottom of the tank.

III. PROCEDURE

A. Air Emissions

Scrubbers on lines 102, 103, 104, 105, and 106 were tested. Scrubber 101 emissions were not tested, as tanks contain similar solutions existed on lines 102 and 106. The two types of tests performed on each scrubber were mass emissions and particle size distribution. Mass emission tests were performed simultaneously on the inlet and outlet of each

scrubber.⁺ Three separate two-hour sampling runs comprised one mass emissions test. Mass emission test data was used to provide information on the total quantity of a pollutant in the exhaust gas. Particle size distribution tests were also performed simultaneously on the inlet and outlet of each scrubber.⁺ Two separate sampling runs comprised one particle size distribution test. Particle size distribution test data was used to aid in determining the appropriate air pollution control device for a particular gas stream.

Each tank connected to a scrubber undergoing testing was loaded with actual work pieces or with scrap metal to simulate tank loads at or above the maximum load encountered during normal shop operation. Tank loads and electrical readings were monitored during each test, and are included in tables 1, 2, 3, and 4 and Appendix A.

1. Mass Emissions Test.

a. Sampling procedures and equipment coincided with the following U.S. Environmental Protection Agency (EPA) test methods described in the Federal Register, Volume 42, No. 160, Part II of 18 August 1977⁴, except as noted in the following paragraphs.

- (1) Method I--Sample and Velocity Traverse
- (2) Method II--Determination of Stack Gas Velocity and Volumetric Flow Rate
- (3) Method III (modified)--Gas Analysis for O₂, CO₂
- (4) Method IV--Determination of Moisture Content of Stack Gases
- (5) Method VIII (modified)--Determination of Sulfuric Acid Mist and Sulfur Dioxide

b. Location of sampling sites (figures 1-7) and number of sampling points (figures 9 and 10) were determined from Method I of the Federal Register cited above.

c. Sampling trains are shown in figures 11 and 12. Type "S" pitot tubes were used. Gold-plated, button-hook nozzles and quartz-glass probe-liners were used to prevent any chemical reactions between the exhaust gas and internal sampling train surfaces. Sampling at each scrubber inlet was performed with a probe mounted vertically and connected to the impinger box by 25 feet of 0.5 in. diameter teflon tubing. Sampling at each scrubber outlet was performed with the probe mounted horizontally and connected to the impinger box with borosilicate glassware.

⁺The outlet of Scrubber 104 was not tested. Scrubber 104 was not operational during the test period.

TABLE 2
Tank Loading Summary

Scrubber No.	Tank No.	Voltage Load (V)	Current Load (Amp)	Workpiece Surface Area (Ft ²)	Lifting Interval (Min.)
102	4	7.0	1950	38	15
	33	5.0	150	4.5	15
	48	N.A.	N.A.	N.A.	N.A.
	50	N.A.	N.A.	22.5	15
103	41	8.0	1580	12	N.A.
	42	8.2	2000	13	N.A.
	43	6.4	1060	12	N.A.
	44	8.5	1060	21	N.A.
104	3	N.A.	N.A.	10	20
	5	5.0	1325	9	N.A.
	6	N.A.	N.A.	9	20
	14	N.A.	N.A.	N.A.	N.A.
	15	N.A.	N.A.	N.A.	N.A.
105	1	4.0	450	8	N.A.
	11	4.0	450	7	N.A.
	20	6.0	330	4	N.A.
	21	1.1	22	2	N.A.
	22	0	0	2	N.A.
	29	2.4	310	4	N.A.
106	16	N.A.	N.A.	3	30
	19	N.A.	N.A.	8	30
	28A	N.A.	N.A.	9	30
	28B	N.A.	N.A.	4	30
	35	N.A.	N.A.	6	30
	36	N.A.	N.A.	3	30
	45	N.A.	N.A.	15	30
	47	N.A.	N.A.	25	30

TABLE 3
Tank Loading
Scribber 102

Test Run	Lift Internal (Min.)	Tank 4			Tank 33*			Tank 48			Tank 50		
		V	A	Ft ²	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²
2-1	--	4.8	--	26	--	--	--	--	--	--	--	--	--
2-2	15	6.9	2000	20.5	5	140	4.5	--	--	--	--	--	16
2-3	15	8.5	1980	32	5	150	4.5	--	--	--	--	--	16
2-4	15	8.5	1975	18	5	140	4.5	--	--	--	--	--	32
3-1	15	7.3	2000	64	5	150	4.5	--	--	--	--	--	24
3-2	15	6.4	1825	66	5	150	4.5	--	--	--	--	--	24
Average	15	7.0	1950	38	5	150	4.5	--	--	--	--	--	22.5

*Load in tank not lifted during test.

TABLE 3 (CONTD.)
Tank Loading

Scrubber 103*

Test-Run	Tank 41			Tank 42			Tank 43			Tank 44		
	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²
4-1	7	400	2	8	2000	18	7.7	1100	1	7	840	28
4-2	7	450	2	8	2000	12	7.6	1100	14	9	1100	20
4-3	8.9	2075	17	8.5	2000	12	6.4	970	24	9.6	950	19.5
4-4	9	2200	17	8.5	2000	12	6.4	660	10.5	9.6	1275	19.5
5-1	8	2150	17	8.1	2000	12	9.3	1350	11	8	1100	19.5
5-2	8.4	2200	17	8	1800	12	8	1180	11	7.7	1100	19.5
Average	8	1580	12	8.2	2000	13	6.4	1060	12	8.5	1060	21

*Load in tanks not lifted during test.

TABLE 3 (CONTD.)
Tank Loading

Scrubber 104

Test Run	Lift Internal (Min.)	Tank 3			Tank 5*			Tank 6			Tank 14*			Tank 15*		
		V	A	Ft^2	V	A	Ft^2	V	A	Ft^2	V	A	Ft^2	V	A	Ft^2
6-1	20	--	--	8	5	1300	9	--	--	8	--	--	--	--	--	--
6-2	25	--	--	10	5	1300	8	--	--	8	--	--	--	--	--	--
6-3	24	--	--	11	5	1350	9	--	--	11	--	--	--	--	--	--
7-1	23	--	--	11	5	1175	9	--	--	11	--	--	--	--	--	--
7-2	10	--	--	10	5	1450	10.5	--	--	8	--	--	--	--	--	--
Average	20	--	--	10	5	1325	9	--	--	9	--	--	--	--	--	--

*Load in tank not lifted during test.

TABLE 3 (CONTD.)
Tank Loading

Scrubber 105*

Test Run	Tank 1			Tank 11			Tank 20			Tank 21			Tank 22			Tank 29		
	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²	V	A	Ft ²
10-1	4	400	5	4	400	5	6	310	4	1	20	2	--	--	2	2.4	310	4
10-2	4	450	9	4	450	8	6	350	4	1	20	2	--	--	--	2.5	300	4
10-3	4	490	9	4	490	8	6	350	4	1.3	30	2	--	--	2	2.4	310	4
11-1	3.8	440	9	3.8	440	8	6	330	4	1.2	20	2	--	--	2	2.3	300	4
11-2	4	490	9	4	490	8	6	330	4	0.8	20	2	--	--	2	2.3	330	4
Average	4	450	8	4	450	7	6	330	4	1.1	22	2	--	--	2	2.4	310	4

*Load in tanks not lifted during test.

TABLE 3 (CONTD.)
Tank Loading

Scrubber 106*

Test-Run	Lift Internal (Min.)	Tank 16 Ft ²	Tank 19 Ft ²	Tank 28A Ft ²	Tank 28B Ft ²	Tank 35 Ft ²	Tank 36 Ft ²	Tank 45 Ft ²	Tank 47 Ft ²
8-1	--	3	8	9	4.5	6	3	18	24
8-2	30	3	8	9	4.5	6	3	18	24
8-3	25	3	8	9	4.5	6	3	18	24
9-1	40	3	8	9	3	6	3	8	30
1-1, 2, 3	--	--	--	--	--	--	--	--	--
Average	30	3	8	9	4	6	3	15	25

*No electrical load.

TABLE 4
Electrical Equipment Rating

Tank	Scrubber	Rectifier Number	ID#	Voltage (V)		Current (Amps)	
				Input	Output	Input	Output
1/11	105	1	616692	480	0-15	69	3,000
4/5	102	7	616691	480	0-15	69	3,000
21/22	105	4	417726	480	0-12	19	1,000
23	101	5	417724	480	0-9	23	1,500
29/20	105	3	417723	480	0-9	23	1,500
33	102	6	616693	480	0-15	69	3,000
41	103	--	601627	480	0-12	95	5,000
42	103	--	601626	480	0-12	95	5,000
43	103	--	601623	480	0-12	210	10,000
44	103	--	601622	480	0-12	210	10,000

All are Clinton Plator Rectifiers, Clinton Supply Co., Chicago, Ill.

All are 3Ø, 60 cycle





Figure 9. Sampling Point Locations, Inlet



SCRUBBER NUMBER	102	103	105	106
DIAMETER (D), INCHES	64	64	66	66
NO. of SAMPLING POINTS	24	24	24	24

Figure 10. Sampling Point Locations, Outlet




Figure 11. Mass Emissions Sampling Train Inlet




Figure 12. Mass Emissions Sampling Train, Outlet

d. Leak checks were performed both before and after each sampling sequence at the pitot tubes, at the beginning of the impingers and at the sampling nozzle as detailed in Method V, Section 4.1.4.1, Federal Register.

e. Impingers were initially weighed, tared, then weighed with the following: 100 ml 0.1 N KOH (1st impinger, modified Greenburg-Smith design), 100 ml deionized water (2nd impinger, Greenburg-Smith design with standard tip), dry (3rd impinger, modified Greenburg-Smith design), and 200 ml silica gel (4th impinger, modified Greenburg-Smith design). Impingers were reweighed following each run to determine water gain. This method is both simpler and more accurate than the specified transfer/weigh procedure (Method V, Section 2.2.6 and Section 4.2), as the samples are handled less and temperature error is eliminated. A Mettler PB 3000 electronic balance, calibrated using International Organization of Legal Metrology (IOLM) specification metric weights, was used for all field impinger weighings.

f. O₂ and CO₂ monitors were used instead of an Orsat to determine dry stack gas molecular weight (Method III, modified). The gas sample was passed through polyethylene tubing to the gas conditioner (Figure 13) to remove moisture and particulate, then to the monitors. Solid-state, nondispersive infrared analyzers were used. The zero point was set using zero grade air rather than nitrogen, and one span point was set using a National Bureau of Standards (NBS) traced span gas. Plating shop exhaust ventilation O₂ and CO₂ concentrations are the same as ambient air concentrations (O₂ = 20.9%, CO₂ ≈ 0.0%).

g. Following each run the sampling nozzle, probe liner, connecting glassware, and teflon tubing (inlet sampling train only) were rinsed with deionized water and the rinse water collected in a borosilicate glass recovery bottle or polyethylene "cubitainer." Liquid from the first three impingers was poured into the same recovery bottle or "cubitainer."

Total sample weight was determined and the samples delivered to Truesdail Laboratories, Tustin, California, for chemical analysis. The Truesdail Laboratories report is included in Appendix C.

h. Percent isokinetic was calculated for each run. An isokinetic value between 90% and 110% was required for the run to be considered valid.




Figure 13. Gas Conditioner

i. The following constants were used to reflect the change by EPA from 70°F to 68°F for standard temperature in the above Federal Register:

<u>Symbol</u>	<u>Unit</u>	<u>Description</u>
g/lb	453.59237	Conversion factor
K_p	$85.39 \frac{\text{ft (lb/lb-mole)(in.Hg)}^{1/2}}{\text{sec } (^{\circ}\text{R})(\text{in. H}_2\text{O})}$	Pitot tube constant (Method II)
K_1	0.04710 ft ³ /ml	Conversion factor (Method IV)
K_2	0.04718 ft ³ /ml	Conversion factor (Method IV)
K_3	17.65 °R/in. Hg	Standardizes temperature and pressure (Method IV)
K_1	17.65 °R/in. Hg	Standardizes temperature and pressure (Method V)
K_2	0.04710 ft ³ /ml	Conversion factor (Method V)
K_4	$0.09444 \frac{(\text{min})(\text{in. Hg})}{(^{\circ}\text{R})(\text{sec})}$	Constant for standard pressure and temperature (Method V)
MW_{air}	28.9641 lb/lb-mole	Molecular weight of air
$MW_{\text{H}_2\text{O}}$	18.01534 lb/lb-mole	Molecular weight of water
P_{std}	29.92126 "Hg	Absolute standard pressure
ρ_{air}	0.0752236 lb/ft ³	Density of air at 20°C
$\rho_{\text{H}_2\text{O}}$	0.99824 g/ml	Density of water at 20°C

2. Particle Size Distribution Test.

a. Sampling locations, procedures and equipment used were similar to those used during the mass emissions test and followed EPA Methods I through IV, given in Federal Register Vol 42, No. 160, Part II of 18 August 1977. The following guidelines were also used:

- (1) ASME Performance Test Code (PTC) 28--Determining Properties of Fine Particulate Matter (draft revision).⁵
- (2) Operations Manual--University of Washington Mark III Cascade Impactor.⁶

b. Particle size distribution sampling trains are shown in figures 14 and 15. The differences between a mass emissions sampling train and a particle size distribution sampling train are as follows:

- (1) University of Washington Mark III Cascade Impactors replaced gold-plated nozzles at the probe tip.
- (2) Stainless-steel probe liners replaced quartz glass probe liners. The torque imposed on the tip of the glass probe liner by the weight of the impactor caused the glass liner to break. Using stainless-steel probe liners eliminated this problem.

c. The University of Washington Mark III Cascade Impactor was assembled as shown in Figure 16. Teflon O-ring gaskets were used on both sides of the backup filter to prevent the filter from sticking to the screen. The Mark III Cascade Impactor was modified to contain only four stages. See Appendix D.

d. Reeve Angel 934AH fiberglass filters were used. Filters were pre-washed in sulfuric acid solution as follows:

- (1) Filters were submerged in a 50-50 mixture (by volume) of distilled water and reagent grade concentrated sulfuric acid at 230-239°F for two hours.
- (2) Filters were removed from the acid bath, cooled to room temperature, then thoroughly rinsed with distilled water until the pH of the rinsewater was nearly the same as that of the distilled water.
- (3) Filters were submerged in reagent grade isopropanol (isopropyl alcohol) and allowed to stand for several minutes. This step was repeated four to five times, each time using fresh isopropanol.
- (4) Filters were drained, spread out to dry in a clean, dry place, then baked at 120°F for two hours, at 390°F for two additional hours, and finally at 700°F for three more hours.
- (5) As a final check, two filters were torn into small pieces, placed in distilled water and the pH checked.

All filters and aluminum filter holders were stabilized at 30% + 5% relative humidity and 68°F + 4°F for 24 hours prior to weighing. Filters were combined with filter holders using 5 to 10 mg of Apiezon H grease as an adhesive. Filters were weighed using a Mettler AK 160 electronic balance at intervals greater than six hours until a constant weight (≤ 0.5 mg change from previous weighings) was achieved for three consecutive weighings. The results of the three weighings were averaged and recorded to the nearest 0.1 mg. See Appendix F.

e. Prior to sampling, a velocity traverse was performed as outlined in Method II, Federal Register, cited above. Velocity traverses were performed without the impactor attached.




Figure 14. Particle Sizing Sampling Train, Inlet




Figure 15. Particle Sizing Sampling Train, Outlet




Figure 16. University of Washington Mark III Cascade--Impactor (Modified)

f. Pitot tubes were leak checked before and after each run as detailed in Method V, Section 4.1.4.1, Federal Register. A leak check was performed at the impactor nozzle prior to the beginning of a sampling run. No leak check was performed at the impactor nozzle following a sampling run to prevent any disturbance to particulate collected on the impactor stages.

g. Impactor sampling runs varied in duration from one hour to four hours. Sampling times were based on anticipated particulate loading in the gas stream. Four hours was used as a maximum sampling time on scrubber lines with very low particulate loadings.

h. One or two sampling points were used during a sampling run depending on the velocity profile within the duct. An average duct velocity was determined from the initial velocity profile and velocity points at or near the average velocity were chosen as sampling points. In several cases only one sampling point was within 10% of average velocity, and in such cases one sampling point was used. In cases where several points had acceptable velocities, the two most symmetrically spaced points were used. A maximum of two sampling points were used to minimize impactor jostling caused by insertion and removal from sampling ports.

i. Impingers were initially weighed, tared, then weighed with the following; 100 ml deionized water (1st impinger, modified Greenburg-Smith design and 2nd impinger, Greenburg-Smith design with standard tip), dry (3rd impinger, modified Greenburg-Smith design), and 200 ml silica gel (4th impinger, modified Greenburg-Smith design). Impingers were reweighed following each run to determine water gain. The impinger water was disposed of following the weighing.

j. As in the mass emission tests, O_2 and CO_2 solid-state, nondispersive infrared analyzers were used instead of an Orsat to determine dry stack gas molecular weight (Method III, modified). The zero point was set using zero grade air rather than nitrogen, and one span point was set using NBS traced span gas. Planting shop exhaust ventilation O_2 and CO_2 concentrations are the same as ambient air concentrations ($O_2 = 20.9\%$, $CO_2 \approx 0.0\%$).

k. Following a sampling run the impactor was dismantled and each filter stage placed in a disposable plastic petri dish. The back-up filter (with teflon O-rings) was placed in an pre-weighed aluminum foil pouch. The filter stages were then weighed at approximately 30 minute intervals for 2 to 3 weighings. Whenever a significant weight gain (>0.5 mg) was observed three weighings were made. See Appendix F for details. A Mettler AK 160 electronic balance, calibrated using IOLM specification metric weights, was used for all field filter stage weighings. The test support van was set on blocks during the test period to minimize the transmission of vibration to the balance.

l. Filter stages showing visual indications of collected particulate were sent to Truesdail Laboratories for chemical analysis. A copy of the laboratory results appears in Appendix C.

m. Percent isokinetic was calculated for each sampling run. An isokinetic value between 80% and 120% was necessary for the run to be considered valid.

B. Ventilation Survey

The supply air flow rates were measured for heating and ventilating (HV) units 10, 12, and 13 at locations in Figure 8. Measurements were taken using a standard pitot tube and a dual U/inclined manometer. Twenty, twenty-five, and thirty point pitot traverses were performed to measure velocity pressures in round, rectangular, and square ducts, respectively.

Smoke tests were conducted inside the plating shop to identify any turbulent air currents that might affect local exhaust systems. The tests were performed by igniting smoke pellets at different elevations near perimeter walls, opened doors, wall-mounted air grills, and ventilated tank surfaces, and observing the direction and velocity of the smoke.

IV. CHAIN OF CUSTODY

A. Source Emission Test

	<u>Inlet</u>	<u>Outlet</u>
Stack	Peter Fanning Darrow Kirkpatrick Bill Powers	Susan Suzuki Tom Belanger Tim Quarles
Sample Train Set-Up and Recovery	Susan Suzuki Bill Powers Charles Yee	

B. Sample Recovery and Analysis

Bill Powers
Charles Yee
Susan Suzuki

C. Industrial Ventilation Study

Bob Wood

D. Sample Transport.

Samples were stored in an onsite mobile freezer for up to five days. Each mass emissions sample, KOH blank, deionized water blank, and tank solution sample was sealed in a glass borosilicate container or polyethylene "cubitaainer." Impactor filter stages were sealed in zip-lock plastic bags. Samples were then transported by car to Truesdail Laboratories in Tustin, California. No damage was caused during transport.

V. RESULTS

A. Air Emissions

Tables 1 through 4 summarize tank data and transformer electrical ratings. Table 5 contains flowrates and isokinetic calculations for all mass emissions runs. The sample volume and lab sample weight are presented in Table 6. Table 7 lists the chemical analyses performed on each sample. Table 8 lists the results of chemical analyses and scrubber efficiencies. Sample pollutant concentrations are compared to OSHA workplace standards in Table 9. Table 10 contains flowrates and isokinetic calculations for all impactor runs. Stage 5 impactor cutpoints for all impactor runs are listed in Table 11. Results from impactor runs on Scrubber 103 are given in Table 12. Static pressure drops measured across each scrubber are listed in Table 13.

An error was found in the source test calculator program during report preparation. The program error was corrected and all field test calculations were redone. The correction resulted in scrubber flowrates dropping an average of 0.1%.

B. Ventilation Survey

Table 14 lists the measured flowrates for three of the four supply air HV units. The rated flow for both HV-10 and HV-11 is 30,000 cfm. The rated flow for both HV-12 and HV-13 is 40,000 cfm. The measured flowrate for HV-10 was 20500 cfm. HV-11 was not operating during the study and it is assumed that HV-11 has a flowrate approximately equal to HV-10. The measured flowrates for units HV-12 and HV-13 were 27800 and 27300 cfm, respectively.

Table 15 lists the average exhaust volume flowrates measured during emission testing. Table 15 also lists the exhaust air flowrates required to meet recommended exhaust ventilation standards.²

VI. DISCUSSION

A. General

Tanks were loaded with actual workpieces or with scrap metal to produce tank loads at or above the maximum load expected during shop operation. Workpieces were lifted on regular intervals to simulate emissions caused by moving workpieces from tank to tank. Lifting intervals and tank loads are indicated in Appendix A.

Testing initially was attempted during the day shift. Problems were encountered maintaining high loads in the tanks without interfering with the production schedule of the shop. A week into the test, the workday was moved to the swing shift (1600 to 0200) to prevent conflicts with the production schedule.

No air emission limits are specified for chemicals typically emitted from plating shops. Occupational Safety and Health Administration (OSHA) exposure limits do exist for these chemicals, however, and these limits are used as a standard to compare test results. It is important to note that OSHA

TABLE 5
MASS EMISSIONS DATA
FLOW RATE AND ISOKINETIC

DATE	SCRUBBER	TEST-RUN	VOL FLOW RATE (ACFM)		VOL FLOW RATE (SCFM)		ISOKINETIC (%)	
			INLET	OUTLET	INLET	OUTLET	INLET	OUTLET
MAY 30	101	X-X	27985.05	XX	XX	XX	XX	XX
16	102	2-1	31991.6	38700.4	31669.3	38760.1	91.1	104.2
17	102	2-2	29984.3	38073.2	29676.8	38278.8	100.3	103.5
18	102	2-3	32306.6	36983.7	31779.5	37199.4	92.4	101.8
18	102	2-4	30727.4	38730.5	30737.7	38845.6	95.3	101.9
22	103	4-1	32385.8	30009.9	32454.8	30126.9	85.8	99.5
22	103	4-2	31476.3	29466.9	31735.9	29669.8	96.4	103.1
23	103	4-3	32857.1	30225.5	32771.5	30272.6	106.5	99.4
23	103	4-4	33645.0	27640.4	33835.1	27747.2	96.2	104
25	104	6-1	32276.8	XX	32262.4	XX	103.1	XX
25	104	6-2	32687.7	XX	32745.9	XX	104.6	XX
26	104	6-3	33265.1	XX	33078.5	XX	104.1	XX
31	105	10-1	49278.9	50239.8	48696.1	50462.7	101.5	94.8
31	105	10-2	49360.4	49687.9	49070.9	50110.3	103.2	96
31	105	10-3	49064.2	49234.3	48793.9	49700.4	101.5	96.7
29	106	8-1	43581.0	44181.0	43272.7	44160.8	95.1	102.5
29	106	8-2	43717.8	44133.4	43501.6	44269.1	96.1	101.2
29	106	8-3	44053.9	44988.9	43995.6	45129.6	95.4	101.2

TABLE 6
MASS EMISSIONS DATA
SAMPLE VOLUME AND LAB SAMPLE WEIGHT

DATE	SCRUBBER	TEST-RUN	SAMPLE VOL(SCF)		LAB SAMPLE WT(GRAM)	
			INLET	OUTLET	INLET	OUTLET
MAY 16	102	2-1	104.63	71.59	698.9	482.7
17	102	2-2	109.76	70.22	686.9	486.7
18	102	2-3	105.82	67.07	743.4	624.5
18	102	2-4	53.75	69.02	676	647
22	103	4-1	62.57	123.46	766.4	536.8
22	103	4-2	68.03	123.33	904.3	663.6
23	103	4-3	74.03	121.1	701	473.5
23	103	4-4	70.08	118.18	805.9	790.5
25	104	6-1	94.78	XX	930.5	XX
25	104	6-2	92.54	XX	825.4	XX
26	104	6-3	95.67	XX	790	XX
31	105	10-1	66.75	62.73	640.9	387.4
31	105	10-2	65.1	63.08	682.2	519.2
31	105	10-3	64.2	63.03	641.6	499.9
29	106	8-1	73.38	61.55	745.8	446.2
29	106	8-2	74.54	60.18	750.3	522.5
29	106	8-3	73.64	60.88	715.9	473.7

TABLE 7
Analysis Schedule for Samples
From Building 210 Plating Shop
Long Beach Naval Shipyard

Scrubber Line	Specie
102	Cl^- , SO_4 , Al^{+++} , Na^+ , Ni^{++}
103	Cr_{tot} , SO_4
104	Cl^- , Cr_{tot} , SO_4 , F^-
105	Cl^- , CN^- , Ag^+ , Cd^{++} , Cu^{++} , Na^+ , Ni^{++}
106	Cl^- , Cr_{tot} , F^- , PO_4^{-3}

TABLE 8
MASS EMISSIONS CHEMICAL ANALYSIS RESULTS

SCRUBBER 102

TEST-RUN	SPECIE	LOADING (ug/m ³)		EFFICIENCY (%)
		INLET	OUTLET	
2-1	Cl-	100	0	100
2-1	SO ₄	---	---	---
2-1	Al	---	---	---
2-1	Na	110	95	14
2-1	Ni	---	---	---
2-2	Cl-	208	0	100
2-2	SO ₄	---	---	---
2-2	Al	---	---	---
2-2	Na	152	93	39
2-2	Ni	---	---	---
2-3	CL-	227	362	-59
2-3	SO ₄	---	---	---
2-3	Al	---	---	---
2-3	Na	113	165	-46
2-3	Ni	---	---	---
2-4	CL-	224	232	-4.
2-4	SO ₄	---	---	---
2-4	Al	---	---	---
2-4	Na	220	0	100
2-4	Ni	---	---	---

TABLE 8 (CONTD.)
MASS EMISSIONS CHEMICAL ANALYSIS RESULTS

SCRUBBER 103

TEST-RUN	SPECIE	LOADING (ug/m ³)		EFFICIENCY (%)
		INLET	OUTLET	
4-1	Cr	554	28	95
4-1	SO ₄	---	---	---
4-2	Cr	284	48	85
4-2	SO ₄	---	---	---
4-3	Cr	1389	19	99
4-3	SO ₄	---	---	---
4-4	Cr	504	57	89
4-4	SO ₄	---	---	---

SCRUBBER 104

TEST-RUN	SPECIE	LOADING (ug/m ³)		EFFICIENCY (%)
		INLET	OUTLET	
6-1	Cl	36821	---	---
6-1	Cr	3864	---	---
6-1	SO ₄	---	---	---
6-1	F	---	---	---
6-2	Cl	27837	---	---
6-2	Cr	3413	---	---
6-2	SO ₄	---	---	---
6-2	F	---	---	---
6-3	Cl	31857	---	---
6-3	Cr	2347	---	---
6-3	SO ₄	---	---	---
6-3	F	---	---	---

TABLE 8 (CONTD.)
MASS EMISSIONS CHEMICAL ANALYSIS RESULTS

SCRUBBER 105

TEST-RUN	SPECIE	LOADING (ug/m3)		EFFICIENCY (%)
		INLET	OUTLET	
10-1	Cl-	---	---	---
10-1	CN	17	24	-41
10-1	Ag	---	---	---
10-1	Cd	---	---	---
10-1	Cu	---	---	---
10-1	Na	426	337	21
10-1	Ni	---	---	---
10-2	CL-	135	160	-19
10-2	CN	10	49	-390
10-2	Ag	---	---	---
10-2	Cd	---	---	---
10-2	Cu	---	---	---
10-2	Na	30	106	>>>
10-2	Ni	---	---	---
10-3	Cl-	14	41	-192
10-3	CN	32	38	-19
10-3	Ag	---	---	---
10-3	Cd	---	---	---
10-3	Cu	---	---	---
10-3	Na	229	220	3.9
10-3	Ni	---	---	---

TABLE 8 (CONTD.)
MASS EMISSIONS CHEMICAL ANALYSIS RESULTS

SCRUBBER 106

TEST-RUN	SPECIE	LOADING (ug/m ³)		EFFICIENCY (%)
		INLET	OUTLET	
8-1	Cl ⁻	11	40	264
8-1	Cr _{tot}	---	---	---
8-1	F ⁻	---	---	---
8-1	PO ₄ ³⁻	---	---	---
8-2	Cl ⁻	182	230	-26
8-2	Cr _{tot}	---	---	---
8-2	F ⁻	---	---	---
8-2	PO ₄ ³⁻	---	---	---
8-3	Cl ⁻	45	41	9
8-3	Cr _{tot}	---	---	---
8-3	F ⁻	---	---	---
8-3	PO ₄ ³⁻	---	---	---

TABLE 9
MASS EMISSIONS DATA
CONCENTRATION vs OSHA STANDARDS

SCRUBBER	CHEMICAL	OSHA STD* (mg/m ³)	INLET CONC. AVE (mg/m ³)	ABOVE(+) OR BELOW(-) STD	OUTLET CONC AVE (mg/m ³)	ABOVE(+) OR BELOW(-) STD*
102	NaOH	2.0	0.26	-	0.16	-
	HCl	7.0	0.19	-	0.15	-
	Ni	1.0	0.00	-	0.00	-
103	CrO ₃	0.1	1.31	+	0.08	-
104	HCl	7.0	32.20	+	N.A.	N.A.
	H ₂ SO ₄	1.0	0.00	-	N.A.	N.A.
105	Ag	0.01	0.00	-	0.00	-
	Cd	0.1	0.00	-	0.00	-
	Cl	7.0	0.05	-	0.07	-
	NaCN/KCN	5.0	0.02	-	0.04	-
	Cu	0.1	0.00	-	0.00	-
	Ni	1.0	0.00	-	0.00	-
106	HCl	7.0	0.08	-	0.10	-
	Cr	0.1	0.00	-	0.00	-

* OSHA WORKPLACE STANDARD (PERMISSIBLE EXPOSURE
LIMIT) IS FOR AN 8-HOUR TIME WEIGHED AVERAGE.

TABLE 10
IMPACTOR DATA
FLOW RATE AND ISOKINETIC

DATE	SCRUBBER	TEST-RUN	VOLUME (SCF)	FLOW RATE (ACFM)	FLOW RATE (SCFM)	ISOKINETIC (%)
MAY 21	102	3-1 INLET	40.40	29901.75	29490.32	115.2
MAY 21	102	3-1 OUTLET	45.94	38809.95	38804.47	100.2
MAY 21	102	3-2 INLET	92.98	30424.26	30157.49	115.2
MAY 21	102	3-2 OUTLET	97.72	38866.91	38876.35	95.4
MAY 24	103	5-1 INLET	79.52	31911.59	31556.02	123.2
MAY 24	103	5-1 OUTLET	116.62	31855.72	31867.28	105.8
MAY 24	103	5-2 INLET	79.27	31893.18	31626.56	123.0
MAY 24	103	5-2 OUTLET	73.89	31771.81	31828.66	101.6
MAY 26	104	7-1 INLET	180.44	33807.88	33374.18	105.1
MAY 26	104	7-2 INLET	63.00	33539.28	33419.78	108.1
JUN 1	105	11-1 INLET	120.51	45075.22	44505.27	105.2
JUN 1	105	11-1 OUTLET	119.92	50577.63	50891.25	98.6
JUN 1	105	11-2 INLET	117.90	44919.58	44659.57	102.5
JUN 1	105	11-2 OUTLET	121.65	50518.74	50950.58	95.5
MAY 15	106	1-1 INLET	63.52	42527.42	42954.40	128.4
MAY 15	106	1-1 OUTLET	41.00	44650.10	45369.29	107.6
MAY 15	106	1-2 OUTLET	42.28	50676.92	51631.78	99.1
MAY 15	106	1-3 INLET	55.04	43985.09	44009.16	109.5
MAY 15	106	1-3 OUTLET	44.10	50671.82	51551.96	105.2
MAY 30	106	9-1 INLET	142.79	44389.89	42817.19	97.3
MAY 30	106	9-1 OUTLET	127.17	47498.81	47492.18	106.3

TABLE 11
IMPACTOR DATA
STAGE 5 AERODYNAMIC CUTPOINTS

DATE	SCRUBBER	TEST-RUN	SAMPLE TIME (min)	FLOW RATE* (CFM)	CUTPOINT (Um)
MAY 21	102	3-1 INLET	80	0.52	1.3(X)4.4
MAY 21	102	3-1 OUTLET	80	0.59	1.3(X)4.2
MAY 21	102	3-2 INLET	180	0.54	1.3(X)4.3
MAY 21	102	3-2 OUTLET	180	0.57	1.3(X)4.2
MAY 24	103	5-1 INLET	240	0.35	1.6(X)5.5
MAY 24	103	5-1 OUTLET	240	0.51	1.3(X)4.7
MAY 24	103	5-2 INLET	240	0.35	1.6(X)5.5
MAY 24	103	5-2 OUTLET	240	0.50	1.3(X)4.7
MAY 26	104	7-1 INLET	180	1.07	0.87(X)3.2
MAY 26	104	7-2 INLET	60	1.12	0.83(X)3.2
JUN 1	105	11-1 INLET	180	0.71	1.1(X)3.8
JUN 1	105	11-1 OUTLET	180	0.72	1.1(X)3.8
JUN 1	105	11-2 INLET	180	0.70	1.1(X)3.8
JUN 1	105	11-2 OUTLET	180	0.73	1.1(X)3.8
MAY 15	106	1-1 INLET	60	1.11	0.83(X)3.2
MAY 15	106	1-1 OUTLET	60	0.72	1.1(X)3.8
MAY 15	106	1-2 OUTLET	60	0.74	1.1(X)3.7
MAY 15	106	1-3 INLET	60	0.95	0.92(X)3.2
MAY 15	106	1-3 OUTLET	60	0.78	1.1(X)3.6
MAY 30	106	9-1 INLET	180	0.87	0.98(X)3.3
MAY 30	106	9-1 OUTLET	180	0.75	1.1(X)3.7

* CALCULATED FLOW RATE = (NET METER VOLUME-FT³)/(SAMPLE TIME-MIN)

TABLE 12
Scrubber 103
Total Chromium Particle Sizing Test Results

Test 5-Run 1, Inlet
Total Catch Weight = 92.5 grams
Gas Flow Rate = .35

	D50	Outpoints (μm)	%	Cum. % Less than D50
Stage 1	19	$x > 19$	12	88
Stage 2	15	$15 < x \leq 19$	2	86
Stage 3	5.5	$5.5 < x \leq 15$	53	33
Stage 5	1.6	$1.6 < x \leq 5.5$	26	7
Filter		$x \leq 1.6$	7	

Test 5-Run 2, Inlet
Total Catch Weight = 77.3 grams
Gas Flow Rate = 0.35

	D50	Outpoints (μm)	%	Cum. % Less than D50
Stage 1	19	$x > 19$	14	86
Stage 2	15	$15 < x \leq 19$	7	79
Stage 3	5.5	$5.5 < x \leq 15$	47	32
Stage 5	1.6	$1.6 < x \leq 5.5$	27	5
Filter		$x \leq 1.6$	5	

TABLE 12 (CONTD.)

Scrubber 103

Total Chromium Particle Sizing Test Results (Contd.)

Test 5-Run 1, Outlet

Total Catch Weight = 16.1 gms

Gas Flow Rate = 0.5 acfm

	D50	Cutpoints (μm)	%	Cum. % Less than D50
Stage 1	17	$x > 17$	14	86
Stage 2	12	$12 < x \leq 17$	13	73
Stage 3	4.7	$4.7 < x \leq 12$	12	61
Stage 5	1.3	$1.3 < x \leq 4.7$	28	33
Filter		$x \leq 1.3$	33	

Test 5-Run 2, Outlet

Total Catch Weight = 11.0 grams

Gas Flow Rate = 0.5 acfm

	D50	Cutpoints (μm)	%	Cum. % Less than D50
Stage 1	17	$x > 17$	21	79
Stage 2	12	$12 < x \leq 17$	18	61
Stage 3	4.7	$4.7 < x \leq 12$	18	43
Stage 5	1.3	$1.3 < x \leq 4.7$	25	18
Filter		$x \leq 1.3$	18	

TABLE 13
STATIC PRESSURE DROP ACROSS SCRUBBERS

SCRUBBER	INLET STATIC PRESSURE (in.H2O)	OUTLET STATIC PRESSURE (in.H2O)	STATIC PRESSURE DROP (in.H2O)
101	1.9	6.8	4.8
102	3.3	6.4	3.1
103	1.7	5.4	3.7
104	FAN NOT OPERATIONAL		
105	3.8	5.1	1.3
106	FAN NOT OPERATIONAL		

NOTE: THE CROSS-SECTIONAL AREA OF THE INLET STATIC PRESSURE MEASURING POINT IS APPROXIMATELY EQUAL TO THE CROSS-SECTIONAL AREA OF THE OUTLET STATIC PRESSURE MEASURING POINT FOR EACH SCRUBBER. THESE MEASUREMENTS WERE MADE ON 24 JUL 84, DURING A FOLLOW-UP VISIT TO THE PLATING SHOP.

TABLE 14
Supply Air Flowrates

Heating and Ventilating Unit No.	Measured Flow Rates (cfm)
10	20520
11	* 20520
12	27784
13	27327
Total	96151

*Unit not operating during survey.

TABLE 15
Exhaust Air Flowrates

Scrubber Fan #	Recommended Flowrate (SCFM)*	Measured Flowrate (SCFM)		Measured Fan Inlet SP (inches WG)
		Scrubber Inlet	Fan Outlet	
101	25140	28129		-6.8
102	22785	30966	38271	-6.4
103	37625	32700	29454	-5.4
104	23625	32696	**	*
105	28350	48854	50091	-5.1
106	45450	43590	44520	***

*See Appendix G.

**Line 104 outlet flowrate was not measured because existing scrubber and fan are scheduled to be replaced.

***Fan on Line 106 was not operable.

standards indicate the time-weighted permissible exposure limit (PEL) of a pollutant over an 8-hour workday. Pollutant concentrations measured at levels lower than the OSHA standard indicate that the pollutant is at a safe workplace concentration.

Strong odors emanate from both the paint strip tank (Tank 52) and the large vapor degreaser tank (between Tank 12 and Tank 13). Although both tanks present potential health hazards, neither tank is ventilated. The paint strip tank contains approximately 80 percent methylene chloride (CH_2Cl_2). The PEL for methylene chloride is 100 parts per million. The vapor degreaser contains full strength 1,1,1 trichloroethane (Cl_3CCH_3). The PEL for trichloroethane is 350 parts per million.⁷

B. Air Emissions

1. Scrubber 102 (Alkaline). Mass emissions data show an average inlet sodium hydroxide (NaOH) emission rate of 0.26 mg/m^3 . The average outlet NaOH emission rate is 0.16 mg/m^3 . Both inlet and outlet emission rates for NaOH are well below the OSHA workplace standard of 2.0 mg/m^3 . See Table 9.

The inlet hydrochloric acid (HCl) emission rate was 0.19 mg/m^3 . The HCl outlet emission rate was 0.15 mg/m^3 . Both the inlet and outlet HCl emission rates are well below the allowable workplace limit of 7.0 mg/m^3 . See Table 9.

Nickel (Ni) emission rates were below detectable limits ($> 0.01 \text{ mg/m}^3$) at both inlet and outlet sampling sites.

One 80-minute impactor run and one 180-minute impactor run were performed on Scrubber 102. No significant weight gains ($> 0.5 \text{ mg}$) were measured on any of the inlet or outlet impactor filter stages. The lack of measurable weight gain on the impactor stages is consistent with the low emission rates measured during mass emissions testing.

2. Scrubber 103 (Decorative/Hard Chrome Plating). The average inlet chromic acid concentration of 1.31 mg/m^3 is well above the 0.1 mg/m^3 OSHA workplace standard.⁷ The average scrubber outlet chromic acid concentration is $< 0.1 \text{ mg/m}^3$. Scrubber efficiency is good, with an average removal efficiency of 92%.

Particle size distribution data show an inlet median aerodynamic diameter of $7.6 \text{ }\mu\text{m}$ for the chromic acid mist. See figures 17 and 18. No significant weight gains ($> 0.5 \text{ mg}$) were measured on any of the inlet or outlet impactor stages, though collected particulate was visibly evident on all filter stages. Each filter stage was chemically analyzed to determine quantities of chromic acid mist collected. See Appendix C. The high efficiency measured across Scrubber 103 is consistent with the scrubber manufacturer's claims for particulate removal efficiency.⁸ See Appendix I for photographs of Scrubber 103 impactor filter stages.




Figure 17. Mass Mean Particle Diameter, Scrubber 103 Inlet




Figure 18. Mass Mean Particle Diameter, Scrubber 103 Outlet

NOTE: The Scrubber 103 inlet duct dimensions were incorrectly assumed to be the same as the inlet duct dimensions of scrubbers 101 and 102. Measurements made of the Scrubber 103 inlet duct during the initial velocity traverse showed the duct width to be 64 inches versus 43 inches on scrubbers 102 and 103. The three test ports installed prior to testing allowed sampling of only 60% of the duct cross-section. Measured inlet flow rates averaged 3% higher than the outlet flow rates. Test results have not been modified to account for the higher measured velocities at the scrubber inlet.

3. Scrubber 104 (Acid). The average inlet hydrochloric (HCl) acid concentration of 32.2 mg/m^3 is well above the OSHA workplace standard of 7.0 mg/m^3 . Acid attack was evident on metal structures within 100 feet of this scrubber. Outlet emissions were not measured, as the scrubber and fan are scheduled for replacement in the immediate future.

Particle size distribution data was inconclusive. The acid aerosol deposited on all interior surfaces of the impactor, invalidating the weight gains measured on individual filter stages. See Appendix I for photographs of the Scrubber 104 impactor filter stages.

High levels of chromium were detected in each mass emissions sample collected at Scrubber 104. The presence of chrome in the samples was inconsistent with the fact that no tank connected to Scrubber 104 contained chromates. Heavy acid attack was evident on all stainless-steel sampling probe components exposed to the exhaust gases. The probable source of the chrome is the sampling nozzle. The sampling nozzle interior had been gold-plated prior to the test teams' arrival at Long Beach NAVSHIPYD, and frequent measurements of the inside diameter with a steel micrometer (required to calculate actual sample flow rate) had chipped away some of the protective gold-plating. Reaction between HCl and the high chrome content (17%) of the stainless-steel nozzle would contribute chrome to the emissions sample. No inconsistent chrome levels were noted in samples taken from the other four scrubbers tested, indicating that the high reactivity of HCl with the stainless-steel was the source of the chrome detected in Scrubber 104 samples.

4. Scrubber 105 (Heavy Metal). Average inlet concentrations of Silver (Ag), Cadmium (Cd), Chlorine (Cl), Cyanide (CN), Copper (Cu), and Nickel (Ni) were all well below OSHA workplace standards. See Table 9. No reduction in emissions was achieved by the scrubber on Ag, Cd, Cu, and Ni.

Scrubber outlet emissions increased slightly for Cl and CN. This phenomenon occurs under certain conditions in wet scrubbers treating gas streams with very low particulate loadings. Circulating scrubber water acts as a reservoir concentrating captured pollutants, and some of this scrubber water is entrained as mist and carried out the stack.

Two 3-hour impactor runs were performed on Scrubber 105. No significant weight gains ($>0.5 \text{ mg}$) were measured on any of the inlet or outlet impactor filter stages. The lack of measureable weight gain on the impactor stages is consistent with the low emission rates measured during mass emissions testing.

On both inlet and outlet, collected particulate was visible on Stage 5 of each impactor following each run. The aerodynamic particle size range collected on Stage 5 was between 1.1 μm and 3.8 μm . See Table 11. Wet scrubber efficiencies on particles in this size range are low (<50%).

5. Scrubber 106 (Chromates). Both the scrubber inlet and outlet chromium emission levels were below detectable limits. Hydrochloric acid concentrations averaged 0.1 mg/m^3 at both the scrubber inlet and the outlet. These hydrochloric concentrations are well below the OSHA workplace standard of 7.0 mg/m^3 .

The tanks connected to Scrubber 106 contain proprietary chromate solutions used to clean and coat aluminum, brass, and copper components. Compressed air provides mechanical agitation to these tanks. No visual indications of chemical action are evident when a workpiece is immersed in the chromate solutions, unlike the gassing which is evident at the workpiece during electrocleaning or hard chrome electroplating.

Three 1-hour impactor runs and one 3-hour impactor run were performed on Scrubber 106. The results are identical to the impactor results discussed for Scrubber 105.

C. Ventilation Survey

1. Smoke Tests. Turbulent air currents were identified by observing smoke travel at different locations within the shop. Along the perimeter walls smoke rose upward at different velocities from floor level to 25 feet above the floor. Near tank exhaust hoods in the northwest half of the shop, where cross drafts had been identified, smoke was not effectively captured. Throughout the shop smoke traveled in various directions at relatively high velocities (greater than 200 fpm).

NAVENENVSA and Long Beach NAVSHIPYD personnel discussed causes for the turbulent cross drafts. The quantity of supply air is insufficient and is not distributed uniformly throughout the shop. Infiltration through existing openings is excessive.

A solution to control the cross drafts is: Supply additional air into the shop, install perforated ducting horizontally three to four feet below the ceiling to provide uniform distribution of supply air, seal off the three 8-foot by 8-foot wall grills, and close perimeter doors.

Good engineering practice² requires maintaining the plating shop under a negative pressure by mechanically supplying a quantity of air equal to 90 percent of the exhaust air. A uniform distribution of supply air, entering the plating shop at a rate of 50 to 100 feet per minute (fpm), is necessary. The remaining supply air will infiltrate through existing openings.

2. A sump trench connecting lines 101, 102, and 103 was identified. This trench causes the three fans to compete for air. Mist and liquid waste from one line can be drawn through the trench and contaminate another line. This condition was observed on a subsequent visit to Long Beach

NAVSHIPYD. Liquid solution from a hard chrome tank on Line 103 overflowed into the exhaust system and was drawn into the scrubber on Line 102 through the sump trench.

Scrubber 102 has an elevated inlet static pressure relative to scrubbers 101 and 103, causing a portion of the exhaust air in lines 101 and 103 to flow through the trench to Line 102. Pitot tube traverse point locations were directly above the trench. Because of this location, the quantity of air flow into Line 102 from lines 101 and 103 was not "seen" by the pitot tube. A 7300 scfm increase in air flow was measured between the Scrubber 102 inlet and outlet. See Table 10. No leaks were evident in the scrubber housing, indicating that the additional air was coming through the sump trench.

A 3200 scfm decrease in air flow between scrubber inlet and fan outlet was measured at Line 103. The outlet air flow at Line 101 was not measured, but it is expected that the fan outlet flow rate is approximately 4100 scfm less than the inlet flowrate.

3. Prefilters in the roof-mounted heating and ventilating (HV) units were in poor condition during a pretest inspection. These prefilters were replaced for the tests. However, the filter support screens were broken and torn open (apparently when replacing filters), prefilter supports were misaligned, two of the four supply air units were operating with loose fan belts, and HV-11 was not in operation. No monitoring instrumentation (such as magnahelics) is located inside the plating shop for the roof-mounted HV units.

VII. CONCLUSIONS

A. General

Emissions test data demonstrate that several types of metal cleaning and plating processes do not produce sufficient emissions to justify the use of air pollution control equipment. An exhaust ventilation system without air pollution control equipment is sufficient for caustic tanks, chromate tanks, and metal (non-chrome) plating tanks. Chrome plating tanks and HCl tanks do require control equipment.

B. Specific

1. Line 101. Scrubber 101 emissions were not tested, as tanks containing similar solutions existed on lines 102 and 106. Tanks solutions that are unique to Line 101, sodium orthosilicate (Tank 8) and phosphate cleaner (Tank 9), are not significant sources of atmospheric air pollution.

A scrubber is not necessary on Line 101, based on emission test results from lines 102 and 106. Exhaust ventilation alone is required. Removal of the scrubber internals will reduce fan static pressure requirements by approximately 4.5" H₂O. See Table 13. Fan horsepower required to maintain the present exhaust volume can be reduced by 27 hp, resulting in a yearly electricity cost reduction of \$11,100. See Appendix E for calculations. Cost savings would also result by eliminating a source of wastewater to the water treatment system. Yearly scrubber

maintenance costs will be reduced as scrubber water pumping and recirculating systems will no longer be used.

2. Line 102. Inlet emission rates for NaOH and Ni are well below OSHA workplace standards.⁷ Exhaust ventilation alone is required on Line 102. Removal of scrubber internals would reduce fan static pressure requirements by approximately 3.0 "H₂O. Fan horsepower required to maintain the present exhaust volume can be reduced by 18.6 hp, resulting in a yearly electricity cost reduction of \$7,600. Wastewater treatment costs and scrubber maintenance costs will be eliminated.

3. Line 103. Inlet chromic acid emission rates exceed the OSHA workplace standard.⁷ The high collection efficiency of the scrubber is consistent with particle sizing test data, which show a relatively large mean particle diameter of approximately 7.6 μ m.

Scrubber collection efficiency varies depending on the scrubber water flowrate. An accurate scrubber water flowrate meter is necessary to ensure that an adequate volume of water is reaching the scrubber spray nozzles.

4. Line 104. Inlet HCl emission rates exceed the OSHA workplace standard.⁷ Inlet sulfuric acid emission rates are below detectable limits. Reduction of the HCl emission rate using a wet scrubber is necessary to protect personnel and equipment in the immediate vicinity of the fan outlet.

Commercially available wet scrubbers can achieve HCl collection efficiencies exceeding 95%. A wet scrubber operating continuously at collection efficiencies exceeding 95% will provide adequate protection to personnel and equipment located near the Line 104 fan outlet. A scrubber water flowrate meter is necessary to insure that a sufficient volume of water reaches the spray nozzles.

5. Line 105. Inlet emission rates for Ag, Cd, Cl, KCN, NaCN, Cu, and Ni are all well below OSHA workplace standards. See Table 9. Scrubber outlet concentrations for NiCl and CN are slightly higher than inlet concentrations. Outlet concentrations for Ag, Cd, Cu were below detectable limits.

Air pollution control equipment is not required on Line 105. Removal of the scrubber internals will reduce fan static pressure requirements by approximately 1.0" H₂O. Fan horsepower required to maintain the present exhaust volume can be reduced by 12 hp, resulting in a yearly electricity cost reduction of \$4,900. Wastewater treatment cost and scrubber maintenance costs will be eliminated.

6. Line 106. Inlet chromate emissions are below detectable limits. Inlet HCl emissions are well below the OSHA workplace standard. HCl emissions at the scrubber outlet are slightly above the inlet HCl emission level.

Air pollution control equipment is not required on Line 106. Removal of scrubber internals will reduce fan static pressure requirements by approximately 1.0" H₂O. Fan horsepower required to maintain the present

exhaust volume can be reduced by 12 hp, resulting in a yearly electricity cost reduction of \$4,900. Wastewater treatment costs and scrubber maintenance costs will be eliminated.

C. Ventilation Survey

1. Turbulent cross-drafts which adversely affect contaminant control are the result of the following:

- a. Mechanical supply air deficiency of 94,000 scfm.
- b. Non-uniform distribution of air supplied through sixteen ceiling-mounted concentric cone diffusers.
- c. Supply air drawn in through three 8-foot by 8-foot northwest wall air grills.
- d. Supply air drawn in through two 6-foot by 9-foot doors in the northwest wall.

2. Exhaust flow rates for lines 101, 102, 104, 105, and 106 are sufficient to control contaminants if turbulent cross-drafts are eliminated.

3. The measured exhaust flowrate from Line 103 is not sufficient to control chromic acid mist from tanks 41, 42, 43, and 44.

4. Maintenance of roof-mounted supply air equipment is inadequate. Plating shop and maintenance personnel must be able to identify the ventilation system operating conditions. The lack of indicating devices contributes to system maintenance neglect.

VIII. RECOMMENDATIONS

A. Air Emissions

1. Scrubbers 101 and 102. Remove the scrubber internals to reduce static pressure at the exhaust fan inlet. Adjust the fan RPMs to maintain present exhaust flowrates.

2. Scrubbers 103 and 104. Install a flowmeter on the scrubber feedwater pump outlet pipe. Scrubber efficiency is proportional to the flow through the spray nozzles. A flowmeter is necessary to insure an adequate flowrate. A simple rotometer is available through Harrington Industrial Plastics Company, Anaheim, California, for this application. Record the flowrate in a daily log.

Perform a source test on Scrubber 104. Acid emissions from Line 104 are the cause of extensive property damage. This scrubber must meet the manufacturer's claims for HCl removal efficiency, otherwise HCl emissions will continue to be a problem.

3. Scrubbers 105 and 106. Remove the scrubber internals to reduce static pressure at the exhaust fan inlet. Adjust the fan RPMs to maintain present exhaust flowrates.

B. Ventilation Survey

1. Supply Air.

- a. Close off three 8-foot by 8-foot outside air grills located on the northwest wall.
- b. Close all doors during process operations.
- c. Add roof-mounted heating and ventilating units to increase the supply air flowrate by 94,000 scfm.
- d. Recommend that air be supplied through perforated round ducting, running horizontally below the ceiling. Supply air will be distributed uniformly at low velocity using this perforated ducting.
- e. Recommend measurement of pressure drop across prefilters on each roof-mounted supply-air HV unit. Install magnahelic gauges for each prefilter on a panel unit located within the plating shop. Record pressure drop across each prefilter in a daily log. Replace filters when pressure drop exceeds manufacturer's recommendation.
- f. Recommend installation of annunciator panel displaying status of supply-air fan motors inside the plating shop.

2. Exhaust Air.

- a. Install baffles six to eight inches high at the ends of each tank with push-pull exhaust hoods. Install baffles perpendicular to the exhaust slot faces. Also, install 6-inch to 8-inch high baffles at each end of tanks 35, 36, 41, 42, 43, 44, 45, 47, 48 and 50 (lateral exhaust hoods).
- b. Install exhaust ventilation on the large paint strip tank (Tank 52). Recommend a push-pull exhaust hood to minimize the required exhaust air. Appendix H provides design data.
- d. Recommend removable cover for the anodes located in tanks 41, 42, 43, and 44. An anode cover will reduce tank surface area, lessening exhaust air requirements.
- e. Recommend installation of magnahelic gauges at the inlet and outlet of scrubbers 103 and 104 to monitor system operating conditions. Locate these four magnahelic gauges on the panel containing the supply air magnahelics. Recommend a three-way valve at the connection of each magnahelic gauge pressure tap for calibration purposes.

- f. Recommend installation of magnahelic gauges upstream of existing scrubbers, 101, 102, 105, and 106 to monitor system operating conditions. Locate the four gauges on the panel containing the supply air magnahelics. Recommend a three-way valve at the connection of each magnahelic gauge pressure tap for calibration purposes.
- g. Isolate lines 101, 102, and 103 by sealing off the interconnecting sump trench.

References

1. CO WESTNAVFACENGCOM ltr 1141E:WJD:eca NAVSHIPYD Long Beach ser 1141/65 of 27 Mar 84.
2. Industrial Ventilation a Manual of Recommended Practice, Committee on Industrial Ventilation, American Conference of Governmental Industrial Hygienists, Ann Arbor, Michigan, Seventeenth Edition, 1982.
3. NESO 2-039, Analysis of Emission Controls at the Electronics Weapon Precision Facility Rating Shop, Long Beach Naval Shipyard, February 1976.
4. Federal Register, Environmental Protection Agency, Standards of Performance for New Stationary Sources, Vol 42, No. 160, August 1977.
5. American Society of Mechanical Engineers Performance Test Code (PTC) 28 Determining Properties of Fine Particulate Matter, (draft edition)
6. Pollution Control Systems Corporation, Operations Manual, Pilot Mark 3 and Mark 5 Source Test Cascade Impactors, Seattle, Washington, January 1983.
7. 29 CFR 1910.
8. Harrington Industrial Plastics, Inc., Anaheim, California, Air Pollution Control Equipment Specifications.

APPENDIX A
TANK DATA.

Occurrence: 7/10/84 and 8/10/84 ALFick
 Tanks 4, 33, 40, 48, 50

16 MAY 1984

- pm - Tank 48-empty.

Tank 33 - Not used Today

Tank 4 - 2 pieces $9" \times 2\frac{1}{2}" \times 3\frac{1}{2}" = 26 \text{ H?}$
 1 piece

Tank 40 - No work

Tank 50 - No work

3:34 Start Emission Test

#4 - 3 pieces within tank however there is no current being use because the operator (Terry) is moving the pieces around. In my conversation w/ Terry he had said that yes when the pieces are moved, more vapors are released. Any vapors are released even w/o workpieces in the tank and because of this evaporation, water is regularly added to the tank to replenish the sln. (He said that this is done twice every 24 hour period)

4:00-4:01 #50 - 1 cylinder Rod $\approx 3(\text{rod}) \times 6'$

4:05 #4 - turned electrical current on. $\approx 5 \text{ V.}$

4:10 #4 - 4.8 V

4:15 #4 - 4.8 V

4:20 #4 - 4.8 V

4:25 #4 - 4.8 V (actually 4.75 V)

4:30 #4 - 4.7 V

4:35 #4 - 4.7 V

4:40 #4 - 4.7 V

4:45 #4 - 4.7 V The same 3 pieces from 3:34 were still in the tank. None of the other tanks (40, 33, 48, 50) were being use. Only one operator in the shop @ that time.

4:50 END of TEST

TANK ELECTRICAL DATA SHEET

Location LINEY
Building _____
Tank 4,30
Scrubber 102
Read by SWANK
Date 17 May 84

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

[illegible]

TANK C
 $4.5 \text{ ft} = \text{Tanket (m)}$
 $1.5 \text{ ft} = \text{Hookab w}$
 20.5 ft^2

I.
 $1\frac{1}{2} \times 1\frac{1}{2} = 2$
(concise)

* 2nd load added

BNSY
17 May 1984

Scrubber 102

4 (cleaner) $\rightarrow \approx 2000$ Amps

33 (Ni Plate) $\rightarrow \approx 5V$

48 (Rinse)

50 (Al Etch)

5:10 #4 has load of 2 hooks w/ valve bodies (misc $\approx 4' \times 2' = 8ft^2$) 16

#33 has load of 1 piece $\approx 1' \times 1\frac{1}{2}'$ (2ft²) 2

#50 had load of 2 pieces $\approx 2' \times 2'$ (4ft²) 16

5:15 #4 add load of basket $\approx 6' \times 1\frac{1}{2}' \times 3'$ of misc parts (4ft²) 4

#4 - 6.4V, 2000 Amps

#50 - load raised

5:25 load raised @ Tanks #4 + 50 & elect. data taken #4 & #33

5:40 " " " " " (approx 3-5 min later) " " "

5:55 " " " " " " "

6:10 " " " " " "

6:25 " both pieces in T50 replaced because the 1st 2 pieces

1:40 " were getting too thin. (1' x 1/2', 1' x 2' = 1' (6)

6:55 " " " " " "

7:10 " " " " " "

7:25 " " " " " "

7:40 " " " " " "

END of TEST.

18 MAY 1984
LBNSY, B210

TEST 2 RUN 3

Scrubber #102

#33 - 1 piece ($1\frac{1}{2} \times 1\frac{1}{2}$)

2.25"

#50 - misc pieces that mtl. ($8\frac{1}{2}$) ~~1/2~~ ~~8 1/2~~

#4 - 2 pieces - $7' \times 1' (LD)$ 1 PIECE IS HEAT EXCH CORE (TUBES)
- 5 misc parts VERY LARGE SURFACE AREA

4:30 Begin test. Water added into tank #4 & pieces in tank 4 were lifted. Items in tanks #33 & #50 were inserted at approx 4:25.

TANK 4 & 50 will have their loads lifted every 15 min.

4:50 Tank 50 - new lg AL piece added $8\frac{1}{2}$ "

↓
TOTAL AL AREA IN TANK = 16 FT²

6:30

NOTE: TOTAL SURFACE AREA OF WORKPIECES IN

TANKS ABOVE IS NORMAL DOUBLE THE

WORKPIECE AREA STATED ABOVE.

MAY 1984
CRNSY, B210

TEST 2 RUN 3

rubber #102

#33 - 1 piece ($1\frac{1}{2} \times 1\frac{1}{2}$)

#50 - misc pieces that add. (8ft^2) ~~+ 17 pieces (8ft^2)~~

#4 - 2 pieces - $7' \times 1' (40)$ 1 piece is heat exch core (TUBES)
VERY LARGE SURFACE AREA

- 5 misc parts

2.25 ft

~~16~~
16

4:30 Begin Test. Water added into tank #4 & pieces in tank #4 were lifted. Items in tanks #33 & #50 were inserted at approx. 4:25.

→ TANK #4 & #50 will have their loads lifted every 15 min.

50 Tank 50 - new lrg AL piece added — 8ft^2

↓

6:30

TOTAL AL AREA IN TANK = 16ft^2

NOTE: TOTAL SURFACE AREA OF WORKPIECES IN
TANKS ABOVE IS NORMAL DOUBLE THE
WORKPIECE AREA STATED ABOVE.

TANK ELECTRICAL DATA SHEET

TEST 3 RUN 1

Location LBNSY
 Building 210
 Tank 4, 33, 50
 Scrubber 102
 Read by SUZUKI, POW
 Date 21 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

TANK 4 [3 CHAIRS = 12 FT²
 8 LARGE L.V. MOTORS = 32 FT²
 5 STEEL PLATES = 20 FT²
 TOTAL SURFACE = 64 FT²]

TANK 33 [1.5' x 1.5' x 1/4" STEEL PLATE]

START

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
1850	6.8V	2000 amps	5.0V	150 amps	
1915	7.5V	2050 amps	5.0V	150 amps	
1930	7.6V	2025 amps	5.0V	150 amps	
1945	7.6V	2025 amps	5.0V	150 amps	
2000	6.8V	1975 amps	5.0V	150 amps	
2010	7.6V	1975 amps	5.0V	150 amps	

END OF TEST

TANK 50 [11 1/4" PLATE 24 FT²]

1850	LOAD ENTERS TANK	TOTAL SURFACE
1915	LOAD LIFTED & DROPPED	
1930	" " " "	
1945	" " " "	
2000	" " " "	
2010	" " " "	

TANK ELECTRICAL DATA SHEET

TEST 4 RUN 1

Location LBNSY
 Building 210
 Tanks 41, 42, 43, 44
 Scrubber 103
 Read by CHARLES BEL
 Date 22 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

TANK #41 [ROTOR BEARING SURFACE 1.0 FT ²]			TANK #42 [3 1/2" STEEL PLATE DUMMIES 9.0 FT ² ONE SIDE]		
Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
6:23 PM	7.0 V	400 a	6:23 PM	7.2 V	2200 a
6:32	7.0	400	6:32	8.0	2000
6:48	7.0	400	6:48	8.0	2000
7:46	7.0	400	7:47	8.0	2000
8:00	7.0	400	8:00	8.0	2000
8:12	7.0	400	8:12	8.0	2000
8:24	7.0	400	8:24	8.0	2000
8:36	7.0	400	8:36	8.0	2000
8:50	7.0	400	8:50	8.0	2000
TANK #43 [SMALL ROTOR SHAFT 0.5 FT ²]			TANK #44 [3 1/4" STEEL DUMMIES 14 FT ² ONE SIDE]		
6:23 PM	4.5	0	6:23 PM	8.4	1250
6:32	7.7	1100 a	6:32	1.5	150
6:48	7.7	1100	6:48	1.5	150
7:47	7.7	1100	7:48	8.6	1000 a
8:01	7.7	1100	8:01	8.6	1000
8:13	7.7	1100	8:13	8.6	1000
8:25	7.7	1100	8:25	8.6	1000
8:37	7.7	1100	8:37	8.6	1000
8:51	7.7	1100	8:51	8.6	1000

6:27 moved plate (~4 ft²) from 44 to 43. removed small rotor shaft from 43. moved plate (~3 ft²) from 42 to 4

TANK ELECTRICAL DATA SHEET

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

All tanks are mechanically agitated

TANK ELECTRICAL DATA SHEET

Location LBNSY

Building 210

Tank 41, 42, 43, 44

Scrubber 103

Read by CHARLES

Date - 23 MAY 84

Rectifier -

Make

Type

Voltage Rating

Amperage Rating

Workplace Size

12-6" long
2" dia.

TANK 41 $\left\{ \begin{array}{l} 2 \frac{1}{4}'' \text{ steel plate dummies} \\ \sim \\ 8.5 \text{ FT}^2 \end{array} \right.$ (in TANK 43 yesterday)

TANK 42 $\left\{ \begin{array}{l} 2 \cdot \frac{1}{4}'' \text{ steel plate dummies} \\ \sim \end{array} \right.$

[illegible]

TANK ELECTRICAL DATA SHEET

TEST 5 RUN 1

Location LBNSY
 Building 210
 Tank 41-44
 Scrubber _____
 Read by FEL
 Date 24 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

TEST 5 RUN 1

VOLTS			CURRENT			VOLTS			CURRENT		
Time	TANK 41 Reading	8.5 FT ² 4" STEEL Avg. Reading	Time	TANK 42 Reading	6 FT ² 4" STEEL Avg. Reading	Time	TANK 43 Reading	5.5 FT ² 4" STEEL Avg. Reading	Time	TANK 44 Reading	9.75 FT ² 4" STEEL Avg. Reading
1800	8.4	2000	1800	8.1	2000	1800	8.0	1050	1800	8.0	1100
1828	8.4	2000	1828	8.1	2000	1827	7.8	1050	1827	8.0	1100
1855	8.4	2100	1855	8.1	2000	1854	7.8	1050	1854	8.0	1100
1921	8.4	2100	1921	8.1	2000	1920	7.8	1050	1920	7.9	1100
1950	8.4	2100	1950	8.0	2000	1950	7.7	1000	1950	7.9	1100
2054	8.5	2300	2054	8.1	2000	2053	11.2	1700	2053	7.8	1100
2132	8.5	2300	2132	8.0	2000	2132	11.2	1750	2132	7.8	1100
2149	8.5	2300	2148	8.0	2000	2148	11.2	1750	2147	7.7	1075

15

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

Tank 5 (H₂SO₄)

2.00

The snap connections plated a set of steel pieces
which function for ~~analysis~~ ^{analysis} the ACI book,
check the test

TEST 6

RUN 1 (CONT.)

TANK ELECTRICAL DATA SHEET

Location LRNSX
Building 210
Tank 3, 576
Scrubber 104
Read by D. Kirkpatrick
Date 5/25/84

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

Funk & (H21)

[illegible]

END
1255

has only 100 mg. and next time I will
design this test

Test 6
Run 2

TANK ELECTRICAL DATA SHEET

Location LBIOSY
Building 210
Tank 3, 5, 6
Scrubber 1, 2, 3
Read by W. J. S.
Date 5-12-1966

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

Tank 3 (HCL)

Tank 5 (H₂SO₄)

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
2235	2 new pieces Cathodic steel 1-15		2235	1 pc Cathodic steel 1 pc Nickel Plate	
2255	2 new pieces Cathodic steel		2255	Low ^{MOD} activity 5V 1300 AMPS	
2315	LOW ACTIVITY		2315	Low ^{MOD} STEADY ACTIVITY	
2325	2 PCS. 4 FT ² ADDED FOLLOWING 'CATH' PLATE - VERY HIGH ACTIVITY		5V 1300 AMPS		
2350	LOW-MOD. ACTIVITY 2 PCS. 4 FT ²		2350	Low ^{MOD} STEADY ACTIVITY 5V 1300 AMPS	
1205	END TEST		1205	END TEST	
<u>TANK 6 (HCL)</u>					
2245	2 PCS. 4 FT. LOW-MOD ACT.				
2310	2 PCS. 4 FT ² LOW ACT.				
2320	2 PCS. 3 FT ² ADDED FOLLOWING 'CATH' PLATING TANK VERY ACTIVE				
2345	2 PCS. 4 FT ² ADDED VERY HIGH ACTIVITY				
1205	END TEST				

Ship continuously panned and steel pieces
all components cycling through the tanks

— 2 —

Location _____	Rectifier _____
Building _____	Make _____
Tank _____	Type _____
Scrubber _____	Voltage Rating _____
Read by _____	Amperage Rating _____
Date _____	Workplace Size _____

Vol 6-CD

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
1-2	100	100			
1-3	100	100			
1-4	100	100			
1-5	100	100			
1-6	100	100			
1-7	100	100			
1-8	100	100			
1-9	100	100			
1-10	100	100			
1-11	100	100			
1-12	100	100			
1-13	100	100			
1-14	100	100			
1-15	100	100			
1-16	100	100			
1-17	100	100			
1-18	100	100			
1-19	100	100			
1-20	100	100			
1-21	100	100			
1-22	100	100			
1-23	100	100			
1-24	100	100			
1-25	100	100			
1-26	100	100			
1-27	100	100			
1-28	100	100			
1-29	100	100			
1-30	100	100			
1-31	100	100			
1-32	100	100			
1-33	100	100			
1-34	100	100			
1-35	100	100			
1-36	100	100			
1-37	100	100			
1-38	100	100			
1-39	100	100			
1-40	100	100			
1-41	100	100			
1-42	100	100			
1-43	100	100			
1-44	100	100			
1-45	100	100			
1-46	100	100			
1-47	100	100			
1-48	100	100			
1-49	100	100			
1-50	100	100			
1-51	100	100			
1-52	100	100			
1-53	100	100			
1-54	100	100			
1-55	100	100			
1-56	100	100			
1-57	100	100			
1-58	100	100			
1-59	100	100			
1-60	100	100			
1-61	100	100			
1-62	100	100			
1-63	100	100			
1-64	100	100			
1-65	100	100			
1-66	100	100			
1-67	100	100			
1-68	100	100			
1-69	100	100			
1-70	100	100			
1-71	100	100			
1-72	100	100			
1-73	100	100			
1-74	100	100			
1-75	100	100			
1-76	100	100			
1-77	100	100			
1-78	100	100			
1-79	100	100			
1-80	100	100			
1-81	100	100			
1-82	100	100			
1-83	100	100			
1-84	100	100			
1-85	100	100			
1-86	100	100			
1-87	100	100			
1-88	100	100			
1-89	100	100			
1-90	100	100			
1-91	100	100			
1-92	100	100			
1-93	100	100			
1-94	100	100			
1-95	100	100			

TEST 6, RUN:

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

ALL PLATES
Cadmium PLATED 1/4 STEEL

— — —

2

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

1

TANK ELECTRICAL DATA SHEET

Location 76120
Building 710
Tank 352
Scrubber 200
Read by 100
Date 100

Rectifier TEST 1 Run 1
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

[illegible]

TANK ELECTRICAL DATA SHEET

Location _____
 Building _____
 Tank _____
 Scrubber _____
 Read by _____
 Date _____

Rectifier TEST 7 Run 1
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
1:00	2-1/2	2			
1:05	2-1/2	2			
1:10	2-1/2	2			
1:15	2-1/2	2			
1:20	2-1/2	2			
1:25	2-1/2	2			
1:30	2-1/2	2			
1:35	2-1/2	2			
1:40	2-1/2	2			
1:45	2-1/2	2			
1:50	2-1/2	2			
1:55	2-1/2	2			
2:00	2-1/2	2			
2:05	2-1/2	2			
2:10	2-1/2	2			
2:15	2-1/2	2			
2:20	2-1/2	2			
2:25	2-1/2	2			
2:30	2-1/2	2			
2:35	2-1/2	2			
2:40	2-1/2	2			
2:45	2-1/2	2			
2:50	2-1/2	2			
2:55	2-1/2	2			
3:00	2-1/2	2			
3:05	2-1/2	2			
3:10	2-1/2	2			
3:15	2-1/2	2			
3:20	2-1/2	2			
3:25	2-1/2	2			
3:30	2-1/2	2			
3:35	2-1/2	2			
3:40	2-1/2	2			
3:45	2-1/2	2			
3:50	2-1/2	2			
3:55	2-1/2	2			
4:00	2-1/2	2			

TEST 7- RUN 2

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

A-21

TEST 7 RUN 2

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

[illegible]

TANK ELECTRICAL DATA SHEET

TEST 8
RUN 1

Location LBUSY
 Building 210
 Tank _____
 Scrubber 100
 Read by POWERS
 Date 29 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

TEST START: 1730

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	<u>TANK 16</u>	<u>CONTENTS: 3 FT² TOTAL</u>		<u>TANK 19</u>	<u>CONTENTS: 1/4" STEEL PLATE</u>
1730	<u>LIFT & DROP</u>	<u>1 1/2" PLATE</u>		<u>LIFT & DROP</u>	<u>8 FT² TOTAL</u>
		<u>WAVEGUIDE</u>	1750		
↓			↓		
1915	<u>END TEST</u>		1915	<u>END TEST</u>	
	<u>MECHANICALLY AGITATED</u>			<u>MECHANICALLY AGITATED</u>	
	<u>TANK 28B</u>	<u>CONTENTS: 2 WAVEGUIDES</u>		<u>TANK 28A</u>	<u>CONTENTS: 2 W.S.</u>
1730	<u>LIFT & DROP</u>	<u>TOTAL SQ. FT. = 3 FT²</u>	1730	<u>LIFT & DROP</u>	<u>1/4" AL PLATE</u>
↓			↓		<u>4 1/2 FT² TOTAL</u>
1915	<u>END</u>		1915	<u>END TEST</u>	
	<u>MECHANICALLY AGITATED</u>			<u>MECHANICALLY AGITATED</u>	
	<u>TANK 35</u>	<u>CONTENTS: 2 W.S.</u>		<u>TANK 36</u>	<u>CONTENTS: 3 WAVEGUIDES</u>
1735	<u>LIFT & DROP</u>	<u>3 FT² 1/4" AL PLATE</u>	1735	<u>LIFT & DROP</u>	<u>AREA: 3 FT²</u>
↓		<u>TOTAL ONE SIDE</u>	↓		<u>TOTAL</u>
1915	<u>END TEST</u>		1915	<u>END TEST</u>	

TANK ELECTRICAL DATA SHEET

Location LENS
Building 210
Tank _____
Scrubber 106
Read by POWERS
Date 29 MAY 84

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

[illegible]

TANK ELECTRICAL DATA SHEET

TEST 8
RUN 2

Location 1 BNSY
 Building 210
 Tank _____
 Scrubber 106
 Read by POWERS
 Date 29 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

ALL TANK CONTENTS IDENTICAL TO TANK CONTENTS FOR TEST 8 RUN 1

TEST START:

110

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	TANK 16			TANK 19	
2115	LIFT & DROP		2125	LIFT & DROP	
2150	LIFT & DROP		2150	LIFT & DROP	
2240	LIFT & DROP		2240	LIFT & DROP	
2255	END TEST		2255	END TEST	
			2255	END TEST	
2125	TANK 28A			TANK 28B	
2125	LIFT & DROP		2125	LIFT & DROP	
2150	LIFT & DROP		2240		
2240	LIFT & DROP		2150	LIFT & DROP	
2255	END TEST		2240	LIFT & DROP	
			2255	END TEST	
2125	TANK 35			TANK 36	
2125	LIFT & DROP		2125	LIFT & DROP	
2150	LIFT & DROP		2150	LIFT & DROP	
2240	LIFT & DROP		2240	LIFT & DROP	
2255	END TEST		2255	END TEST	

TEST 8
RUN 2

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

A-29

TANK ELECTRICAL DATA SHEET

TEST 8
RUN 3

Location LBNSY
 Building 210
 Tank _____
 Scrubber # 106
 Read by PCWERS
 Date 29 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

ALL TANK CONTENTS ARE SAME AS IN TEST 8 RUN 1

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	TANK 16			TANK 19	
0000	TEST START		0000	TEST START	
0010	LIFT & DROP		0010	LIFT & DROP	
0050	" "		0050	" "	
0110	" "		0110	" "	
0135	END TEST		0135	END TEST	
	TANK 28A			TANK 28B	
0000	TEST START		0000	TEST START	
0010	LIFT & DROP		0010	LIFT & DROP	
0050	" "		0050	" "	
0110	" "		0110	" "	
	TANK 35			TANK 36	
0000	TEST START		0000	TEST START	
0010	LIFT & DROP		0010	LIFT & DROP	
0050	" "		0050	" "	
0110	" "		0110	" "	

TEST 8
RUN 3

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

A-31

TANK ELECTRICAL DATA SHEET

Test 9
Run 1

Location LBNSY
 Building 210
 Tank _____
 Scrubber 1526
 Read by DE
 Date 5/30/87

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

TEST END: 2125

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
<u>Tank 16</u>			<u>Tank 19</u>		
1800	Lift / 1 3 ft 2 pc 3" 0		1800	Lift (8 ft 2 Steel)	
1825	Start / 1 3 ft 2 pc 3" 0		1825	Start	
1855	Lift & Drop 1		1855	Lift & Drop	
1940	Lift & Drop (3 times)		1940	Lift & Drop (3 times)	
2050	LIFT & DROP (4 ")		2050	LIFT & DROP (4 ")	
2115	LIFT & DROP 4X		2115	LIFT & DROP 4X	
<u>Tank 28B</u>			<u>Tank 28A</u>		
1800	Lift / 1 3 ft 2 pc 3" 0		1800	Lift / 1 5 ft 2 pc 3" 0	
1825	Start / 1 3 ft 2 pc 3" 0		1825	Start / A1	
1850	Lift & Drop 1		1850	Lift & Drop 1 3 ft 2 pc A1	
1940	Lift & Drop (3 times)		1940	Lift & Drop (3 times)	
2050	LIFT & DROP (4 ")		2050	LIFT & DROP (4 ")	
2120	LIFT & DROP 4X		2120	LIFT & DROP 4X	
<u>Tank 35</u>			<u>Tank 36</u>		
1800	Lift / 1 2 3 ft 2 pc 3" 0		1800	Lift 3 1 ft 2 pc 3" 0	
1825	Start / A1		1825	Start / 1 3 ft 2 pc 3" 0	
1845	Lift & Drop		1845	Lift & Drop	
1940	Lift & Drop (3 times)		1940	Lift & Drop (3 times)	
2050	LIFT & DROP (4 ")		2050	LIFT & DROP 4 TIMES	
2123	LIFT & DROP 4X		2125	LIFT & DROP 4X	

Scrubber 1526: Tanks 16, 19, 28, 35, 36, 37, 45, 47
 All wave guide is copper material.

Test
Run

Rectifier _____ E
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

2
1
0

TANK ELECTRICAL DATA SHEET

TEST 10 RUN 1

Location LGMSY
 Building 210
 Tank _____
 Scrubber # 175
 Read by FLYERS
 Date 21 May 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	TANK 1	CADMIUM / 5 FT ² / 2 STEEL PLATES		TANK 11	CADMIUM / 5 FT ² / 2 STEEL PLATES
1700	TEST START		1700	TEST START	
1715	4 V. 400amp	TANK LOADED	1715	4 V. 400amp	TANK LOADED
1745	4 V. 400amp		1745	4 V. 400amp	
1800	4 V. 400amp		1800	4 V. 400amp	
1815	4 V. 400amp		1815	4 V. 400amp	
1840	4 V. 400amp		1840	4 V. 400amp	
1850	END TEST		1850	END TEST	
	TANK 20	SILVER STAIN / 4 FT ² STEEL DRAWER		TANK 21	SILVER / 2 FT ² STEEL PLATE
1700	TEST START		1700		
1710	6 V. 300amp	TANK LOADED	1705	1 V. 20 amp	TANK LOADED
1745	6 V. 320amp		1745	1 V. 20 amp	
1800	6 V. 320amp		1800	1 V. 20 amp	
1815	6 V. 310amp		1815	1 V. 20 amp	STEEL PLATE REMOVED - NO ACTION IN TANK - CONSECUTIVE SILVER
1840	6 V. 310amp		1850	END TEST	
1850	END TEST				
	TANK 22	SILVER STAIN / 2 FT ² STEEL PLATE		TANK 29	COPPER / 4 FT ² / 3 WATSONS
1700	TEST START		1700	TEST START	
1705			1710	2 V. 300amp	TANK LOADED
1816	30 SECONDS SILVER STAIN		1745	2.5 V. 320amp	
1817			1800	2.5 V. 320amp	
1850	END TEST		1815	2.5 V. 310amp	
			1840	2.5 V. 310amp	
			1850	END TEST	

Notes: ① TANK 1 & TANK 11 SHARE RECTIFIER

② TANK 20 & TANK 29 SHARE RECTIFIER

③ SURFACE AREAS GIVEN ARE TOTAL SURFACE AREAS OF THOSE(S) IN TANK

TANK ELECTRICAL DATA SHEET

TEST 10
RUN 2

Location LBNSY
 Building 210
 Tank _____
 Scrubber #105
 Read by PETERS
 Date 31 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	TANK 1	[9 FT ² STEEL 3 TOS.]		TANK 11	[8 FT ² STEEL 3 TOS.]
2005	START TEST		2005	START TEST	
	4V. 400amp			4V. 100amp	
2025	4V 410a		2030	4V 410a	
2030	4V 410a (4.25 added)		2035	4V 500a	
2100	4V 410a (4.25 added)		2100	4V 475a	
2125	4V 410a		2135	4V 475a	
2150	END TEST		2150	END TEST	
	TANK 20	[4 FT ² STEEL DRAILER]		TANK 21	[2 FT ² STEEL FLA]
2005	START TEST		2005	START TEST	
20	6V. 350amp.			1V. 20 amp	
2030	6.12V 250amp		2030	1V 20 amp	
2100	6.12V 250amp		2100	1V 20 amp	
2135	6.12V 250amp		2135	1V 20 amp	
2150	END TEST		2150	END TEST	
	TANK 22	[NO LEAD]		TANK 29	[4 FT ² 3 WAREHOUSES]
2005	START TEST		2005	START TEST	
2030				2.5V 370 amp	
2150	END TEST		2030	2.9V 300a	
			2100	2.9V 300a	
			2135	2.7V 300a	
			2150	END TEST	

TANK ELECTRICAL DATA SHEET

TEST 10
RUN 3

Location LBNSY
 Building 2-10
 Tank _____
 Scrubber # 105
 Read by P. HERS
 Date 31 MAY 84

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	TANK 1	[9 FT ² 1/4" STEEL PLATE 3 TCS]		TANK 11	[8 FT ² 1/4" STEEL PLATE 3 TCS]
2305	TEST START		2305	TEST START	
2310	4 V. 500amp		2310	4 V. 500amp	
2355	4 V. 480amp		2355	4 V 480amp	
0055	4 V 480amp		0055	4 V 480amp	
0055	TEST END		0055	TEST END	
	TANK 20	[4 FT ² STEEL DOWNER]		TANK 21	[2 FT ² STEEL PLATE]
2305	TEST START		2305	TEST START	
2310	6.0V 350amp		2310	1.5V 30amp	
2355	6.2V 360amp		2355	1.2V 30amp	
0055	6.0V 350amp		0005	RECTIFIER SHUT DOWN (CAUSING SILVER)	
0055	TEST END		0055	TEST END	
	TANK 22	[2 FT ² 1/4" STEEL PLATE]		TANK 29	[4 FT ² 1/4" STEEL PLATE]
2305	TEST START		2305	TEST START	
2310			2310	2.5V 350amp	
0001	} 30 SECONDS SILVER STRIKE		2325-2345	REACTOR SHUT - NO CURRENT FLOW	
0002	} (MODERATE REACTION IN TANK)		2355	2.3 V 280amp	
0055	TEST END		0055	2.5V 300amp	
			0055	TEST END	

TANK ELECTRICAL DATA SHEET

Test 11
Run 1

Location LRMSV
Building 210
Tank 1, 11, 20, 21, 22, 29
Scrubber 1155
Read by 1155
Date 6/1/80

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

Test Start (1730) (Same pieces as previous test - T102)

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
Tank 1 (Cad. Ground)			Tank 11 (Cad. Ground)		
1716	3.90 375a		1716	3.90 375a	
1745	3.80 450a		1745	3.80 450a	
1815	3.80 450a		1815	3.80 450a	
1855	3.80 450a		1855	3.80 450a	
1925	3.80 450a		1925	3.80 450a	
1945	3.90 460a		1955	3.91 460a	
2025	3.80 450a		2025	3.80 450a	
Tank 20 (Nickel Strick)			Tank 21 (Sil. Gran)		
1716	6V 320a		1716	1.20 20a	
1745	6V 320a		1745	1.20 20a	
1815	6V 330a		1815	1.25V 15a	
1855	6V 330a		1855	1.20 20a	
1925	6V 330a		1925	1.20 20a	
1955	6V 330a		1955	1.20 20a	
2025	6V 320a		2025	1.10 20a	
Tank 22 (Silver Silver)			Tank 29 (Cadm. Ground)		
1716	Silver Silver		1716	2.20 290a	
1745	Silver Silver		1745	2.10 300a	
1815	Silver Silver		1815	2.25V 290a	
1855	Silver Silver		1855	2.30V 300a	
1925	Silver Silver		1925	2.30V 300a	
1955	Silver Silver		1955	2.40V 310a	
2025	Silver Silver		2025	2.35V 300a	

Test End 2030

TANK ELECTRICAL DATA SHEET

Test 11
Run 2

Location LRN3V
Building 210
Tank 1,1 22.21.22.27
Scrubber 185
Read by
Date 6/1/87

Rectifier
Make
Type
Voltage Rating
Amperage Rating
Workplace Size

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
	TANK1			TANK1	
2145	4V	470 A	2145	4V	470 A
2245	4V	500 A	2245	4V	500 A
2315	4V	500 A	2315	4V	500 A
2345	4V	500 A	2345	4V	500 A
2350	END	TEST	2350	END	TEST
	TANK2			TANK2	
2145	0.5V	220 A	2145	1V	220 A
2245	0.5V	220 A	2245	1V	220 A
2315	0.5V	220 A	2315	0.5V	200 A
2345	0.5V	220 A	2345	0.5V	200 A
2350	END	TEST	2350	END	TEST
	TANK3			TANK3	
2145	2V	300 A	2145	2V	300 A
2245	2.6V	310 A	2245	2.6V	310 A
2315	2.75V	380 A	2315	2.75V	380 A
2345	0V	0 A	2345	0V	0 A
2350	END	TEST	2350	END	TEST

RECEIVED OFF

No. 1 INLET/OUTLET IMPACTOR RUN
1515 → 1545 11 MAY 84

TANK ELECTRICAL DATA SHEET

Location LBNSY
Building 210
Tank _____
Scrubber 106
Read by POINCE
Date 11 MAY 84

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

WORKPLACE CONTENTS MECHANICAL AGITATION

Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
16	EMPTY				
19	NONE	NONE			
28A	NONE	? (SOME)			
28B	NONE	? (SOME)			
35	NONE	? (SOME)			
36	NONE	SOME			
45	NONE	YES			
47	NONE	NONE			

#1 INLET / OUTLET IMPACTOR RUN SCRUBBER #16

TANK ELECTRICAL DATA SHEET

Location LENEY
 Building 210
 Tank _____
 Scrubber 106
 Read by FOWLES
 Date 14 MAY 94

Rectifier _____
 Make _____
 Type _____
 Voltage Rating _____
 Amperage Rating _____
 Workplace Size _____

10:05 AM

TANK	WORKPIECE FT ²	MECHANICAL AGITATION	W/THRU (1.5)	MECH AGITATION	
Time	Reading	Avg. Reading	Time	Reading	Avg. Reading
16	EMPTY TANK		N/A	N/A	
19	NO WORK	NO		NO	
28A	NO WORK	YES	✓	YES	
	2 FT ² AVE.				
	(EST.)				
28B	NO WORK	YES	✓	YES	
	2 FT ² AVE				
		YES			
35	2 FT ² AVE		✓	YES	
36	2 FT ² AVE	YES	✓	YES	
45	0.5 FT ² →	YES	✓	YES	
	2 FT ² AVE.				
47	NO WORK	NO	✓	NO	

11 min
 (48 x 1' AREA)
 TFE

TANK ELECTRICAL DATA SHEET

Location LPNS4
Building 21C
Tank 19, 28A, 28B, 36, 45, 47
Scrubber 106
Read by JSuzuki
Date 15 May 84

~~Rectifier~~ TEST 1 RUNS 1, 7
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

[illegible]

TEST 1
RUNS 1, 2, 3

Rectifier _____
Make _____
Type _____
Voltage Rating _____
Amperage Rating _____
Workplace Size _____

A-42

APPENDIX B
FIELD DATA

-dF-- --SPT 10--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.01 .1
.02 .1414214
.3 .5477226
.36 .6
.45 .6708204
.47 .6856655
.48 .6708204
.44 .6673250
0 0
.02 .1414214
.13 .5305551
.15 .5570983
.2 .4472136
.34 .5530952
.42 .6420741
.42 .6420741
0 0
0 0
.03 .1732051
.04 .2
.11 .3511688
.25 .5
.35 .5715020
.39 .6244998

DATE 15 MAY 64

SCFUBBER: 101-IN

TEST 1

RUN 1

.4045493

dF AVE = .1679029

1.00
1.00
1.00
1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

$$Q = VA$$

$$= (1,266.951 \text{ ft/min}) (43\frac{1}{2} \text{ ft}) (74\frac{1}{2} \text{ ft})$$

$$= 27,985.05 \text{ ft}^3/\text{min}$$

Serial 101

DUCT DIMENSIONS:
43" x 86" x 1/4"

VELOCITY TRAVERSE
30 MAY 84

SCRUBBER
101

POWERS/KIRKPATRICK

SOURCE EMISSIONS TESTING DATA SHEET
11/10/79-3060/82 (Rev. 11-79)

PLANT		LOCATION		SCHEMATIC OF STACK CROSS SECTION (Show Traverse Points)		PITOT COEFFICIENT, CP		AMBIENT TEMPERATURE		BAROMETRIC PRESSURE, IN HG	
UNIT NO.	OPERATOR	DATE	SAMPLE BOX NO.	METER ΔH	VELOCITY LEADING Inlet	STACK TEMPERATURE (T _s) of	GAS METER HEADING (V _m) ft ³	STACK TEMPERATURE (T _s) of	INLET TEMPERATURE (T _{inlet}) of	OUTLET TEMPERATURE (T _{outlet}) of	LEAK RATE (CFM) @ 175
1					0.01	2	0.01	0.01	62	120"	
2					0.02	0.02	0.02	0.02			
3					0.03	0.03	0.03	0.03			
4					0.036	0.15	0.15	0.15			
5					0.045	0.29	0.29	0.29			
6					0.047	0.34	0.34	0.34			
7					0.045	0.42	0.42	0.42			
8					0.044	0.42	0.42	0.42			
TOTAL											
AVERAGE											

0.045, 0.047, 0.045, 0.044

--dP-- --SQR dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

0	0
.06	.2449490
.19	.4358899
.31	.5567764
.40	.6324555
.78	.8831761
.54	.7348469
.42	.6480741
0	0
.02	.1414214
.10	.3162278
.25	.5
.35	.5916080
.48	.6928203
.53	.7280110
.35	.5916080
0	0
0	0
.08	.2828427
.22	.4690416
.36	.6
.38	.6164414
.38	.6164414
.25	.5

DATE : 16 MAY 1984

SCRUBBER: 102-IN

TEST : 2

RUN : 1

=====

.4492763

dP AVE = .2018492

SOURCE EMISSIONS TESTING DATA SHEET

Date : 16 May 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 2	Box # : 5	I.D. # : 2	I.D. # : 6M-2	I.D. # : 2	I.D. # : 5
Run # : 1	Delta H ₀ : 1.273	Liner : glass	Diam : .35	Coeffici: .8	Filter # : -
Location: LBNSY - Bldg 210	Cret Fac: .996	Length : 10			Leak rt : .002cfm
Source : 102 -IN	Heat Set: -	Heater : -			θ : 25in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 38.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 65F	Stack gas	length: 74in.
Barometer: 29.89in. Hg	dry wt : 29lb/lb-mol	width: 43in.
Stk Stat: -2.8in. H ₂ O	Water vap	area-in ² : 3182in. ²
	proports: .018	area-ft ² : 22.09722ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	772.59	67	67	66	.00	.00	0	0	20.9
2	5	772.59	68	68	67	.07	.70	3	0	20.9
3	10	775.62	69	71	68	.22	2.21	8	0	20.9
4	15	780.10	69	79	66	.32	3.27	14	0	20.9
5	20	786.02	69	91	65	.39	4.07	16	0	20.9
6	25	792.35	69	99	68	.80	8.47	16	0	20.9
7	30	798.74	69	105	68	.57	6.10	17	0	20.9
8	35	805.11	70	110	67	.40	4.31	17	0	20.9
9	40	811.54	70	95	68	.00	.00	0	0	20.9
10	45	811.54	70	88	68	.02	.21	4	0	20.9
11	50	813.79	69	88	56	.10	1.04	6	0	20.9
12	55	817.26	70	91	59	.26	2.71	12	0	20.9
13	60	822.48	70	100	63	.35	3.70	18	0	20.9
14	65	828.78	70	107	61	.52	5.57	19	0	20.9
15	70	835.24	69	111	57	.58	6.27	19	0	20.9
16	75	841.73	70	114	56	.36	3.91	18	0	20.9
17	80	848.39	69	82	65	.00	.00	0	0	20.9
18	85	848.39	69	81	67	.00	.00	0	0	20.9
19	90	848.39	69	81	67	.07	.72	5	0	20.9
20	95	851.48	69	81	48	.23	2.36	12	0	20.9
21	100	856.30	69	81	54	.36	3.69	18	0	20.9
22	105	862.60	69	82	56	.40	4.10	18	0	20.9
23	110	869.08	69	84	55	.38	3.91	18	0	20.9
24	115	875.60	69	85	54	.27	2.79	13	0	20.9
25	120	881.23					.00			

AVERAGE	69.16667	89.20833	60.79167	.21	2.92	11.20833	0	20.9
---------	----------	----------	----------	-----	------	----------	---	------

METER VOLUME = 108.21 ft ³	ABS STACK PRES = 29.68 in. Hg
DRY GAS VOL. SCF = 104.63 ft ³	WET GAS MOLC WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.82 ft ³	STACK GAS VELO = 24.57 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0006681 ft ²
MOI FRAC DRY GAS = .98	DUCT GASFLOW.ACFM = 31991.58 CFM
	DUCT GASFLOW.SCFM = 31669.32 CFM

ISOKINETIC VARIATION = 91.11 %

--dP-- --SGRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.43 .6557439
.41 .6403124
.35 .5916080
.29 .5385165
.23 .4795832
.15 .3872983
.11 .3316625
.12 .3464102
.13 .3605551
.17 .4123106
.19 .4358899
.24 .4898979
.47 .6855655
.43 .6557439
.44 .6633250
.42 .6480741
.37 .6082763
.26 .5099020
.06 .2449490
.12 .3464102
.21 .4582576
.32 .5656854
.43 .6557439
.47 .6855655

DATE : 16 MAY 84

SCRUBBER: 102-OUT

TEST : 2

RUN : 1

=====

.5165536

dP AVE = .2668276

SOURCE EMISSIONS TESTING DATA SHEET

Date : 16 MAY 84 CONTROL PROBE NOZZLE PITOT IMPINGER
 Test # : 2 Box # : 5 I.D. # : 1 I.D. # : - I.D. # : 1 I.D. # : 5
 Run # : 1 Delta H: 1.8443 Liner : GLASS Diam : .246 Coeff: .85 Filter # : -
 Location: LBNEY - Bldg 210 Crct Fac: .9998 Length : 6 Leak rt : .02cfm
 Source : 102-OUT Heat Set: - Heater : - @ : 25 in. H2O
 Engineer : GUA/BEL H2O gain: 32.1ml

ATMOSPHERE ESTIMATE DUCT AREA
 Ambient : 65F Stack gas length: 64 in. dia.
 Barometer: 29.89 in. Hg dry wt : 29 lb/lb-mol width: - in.
 Stk Stat: .20 in. H2O water vap area-in2: 3217 in.2
 absorpt: .02 area-ft2: 22.34028 ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	813.79	69	69	67	.36	1.45	2	0	20.9
2	5	817.38	68	78	68	.36	1.47	2	0	20.9
3	10	820.86	68	87	69	.33	1.37	2	0	20.9
4	15	824.30	67	90	70	.30	1.26	2	0	20.9
5	20	827.58	67	92	71	.23	.97	1.5	0	20.9
6	25	830.51	67	93	73	.16	.67	1.5	0	20.9
7	30	833.00	67	93	74	.11	.46	1.5	0	20.9
8	35	.00	67	92	75	.11	.46	1.5	0	20.9
9	40	.00	67	92	76	.14	.59	1.5	0	20.9
10	45	.00	67	93	76	.17	.72	<2	0	20.9
11	50	.00	67	94	77	.25	1.05	<2	0	20.9
12	55	844.75	67	98	78	.32	1.36	<2	0	20.9
13	60	848.19	67	78	75	.48	1.97	2.5	0	20.9
14	65	.00	66	92	76	.46	1.94	2.5	0	20.9
15	70	856.24	66	98	77	.43	1.83	2.5	0	20.9
16	75	860.10	66	104	78	.42	1.81	2.5	0	20.9
17	80	864.00	66	106	79	.39	1.68	2.5	0	20.9
18	85	867.82	66	108	80	.26	1.13	2.5	0	20.9
19	90	871.31	67	107	81	.07	.30	<2	0	20.9
20	95	873.10	67	103	82	.09	.39	<2	0	20.9
21	100	874.96	67	104	83	.20	.86	<2	0	20.9
22	105	877.64	67	111	84	.32	1.39	2	0	20.9
23	110	881.20	67	114	85	.41	1.79	2.3	0	20.9
24	115	885.05	66	115	86	.45	1.97	2.5	0	20.9
25	120	889.11					.00			

AVERAGE 66.91667 96.29167 76.66667 .27 1.20 2.072222 0 20.9

METER VOLUME = 75.31 ft3 ABS STACK PRES = 29.90 in. Hg
 DRY GAS VOL.SCF = 71.59 ft3 WET GAS MOLE WT = 28.80 lb/lb-mole
 WATER VAPOR VOL = 1.51 ft3 STACK GAS VELO = 29.40 ft/sec
 MOIST CONTENT = .02 NOZZLE AREA = .0003301 ft2
 MOLE FRAC DRY GAS = .98 DUCT GASFLOW.ACFM = 38700.39 CFM
 DUCT GASFLOW.SCFM = 38760.14 CFM

>> ISO KINETIC VARIATION = 104.24 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 17 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 2	Box # : 8	I.D. # : 2	I.D. # : 2.00	I.D. # : 2	I.D. # : 8
Run # : 2	Delta H ₂ : 1.2014	Liner : GLASS	Diam : .353	Coeffic: .8	Filtr # : -
Location: LBNSY - Bldg 210	Crc ₂ Fac: 1.063	Length : 10			Leak rt : 0cfm
Source : 102-IN	Heat Set: -	Heater : -			θ : 25in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 27.9ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 67F	Stack gas	length: 74in.
Barometer: 29.96in. Hg	dry wt : 29lb/lb-mol	width: 43in.
Stk Stat: -3.00in. H ₂ O	Water vap	area-in ² : 3182in. ²
	proport: .015	area-ft ² : 22.09722ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	883.79	71	72	69	.00	.00	0	0	20.9
2	5	883.79	71	72	69	.09	.89	4	0	20.9
3	10	887.25	71	75	42	.20	1.98	4	0	20.9
4	15	891.87	71	82	49	.30	3.01	6	0	20.9
5	20	897.41	71	91	54	.41	4.18	8	0	20.9
6	25	903.85	71	99	58	.77	7.96	11	0	20.9
7	30	911.17	70	109	62	.40	4.22	15	0	20.9
8	35	917.89	70	112	61	.18	1.91	11	0	20.9
9	40	922.75	71	95	64	.00	.00	0	0	20.9
10	45	922.75	71	94	65	.02	.21	4	0	20.9
11	50	925.13	70	93	50	.09	.92	5	0	20.9
12	55	928.32	70	94	52	.24	2.46	9	0	20.9
13	60	933.29	70	100	57	.36	3.74	12	0	20.9
14	65	939.49	70	108	60	.45	4.74	14	0	20.9
15	70	946.43	69	115	62	.43	4.59	14	0	20.9
16	75	953.50	69	119	62	.21	2.26	8	0	20.9
17	80	958.78	71	101	62	.00	.00	0	0	20.9
18	85	958.78	71	99	63	.00	.00	0	0	20.9
19	90	958.78	70	97	64	.08	.83	6	0	20.9
20	95	962.29	70	99	45	.22	2.28	9	0	20.9
21	100	967.16	70	104	48	.38	3.97	13	0	20.9
22	105	973.48	70	112	50	.41	4.35	14	0	20.9
23	110	980.38	69	118	50	.37	3.97	-	0	20.9
24	115	987.06	69	119	50	.22	2.37	9	0	20.9
25	120	992.36					.00			
AVERAGE			70.25	99.125	57	.18	2.53	7.652174	0	20.9

METER VOLUME = 115.40 ft ³	ABS STACK PRES = 29.74 in. Hg
DRY GAS VOL. SCF = 109.76 ft ³	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.31 ft ³	STACK GAS VELO = 23.03 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0006796 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW.ACFM = 29984.32 CFM
	DUCT GASFLOW.SCFM = 29676.82 CFM

----->> ISOKINETIC VARIATION = 100.27 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 17 MAY 84
 Test # : 2
 Run # : 2
 Location: LBNSY - Bldg 210
 Source : 102-OUT
 Engineer: GUA/BEL

CONTROL
 Box # : 5
 Delta Hg: 1.8443
 Crct Fac: .9998
 Heat Set: -

PROBE
 I.Q. # : 1
 Lifer : GLASS
 Length : 6
 Heater : -

NOZZLE
 I.D. # : -
 Diam : .246

PITOT
 I.D. # : 1
 Coeff: .85

IMPINGER
 I.D. # : 5
 Filtr # : -
 Leak rt : .017cfm
 @ : 10in. H2O
 H2O gain: 32ml

ATMOSPHERE
 Ambient : 67F
 Barometer: 29.96in. Hg
 Stk Stat: .20in. H2O

ESTIMATE
 Stack gas
 drv wt : 29lb/lb-mol
 Water vap
 proport: .02

DUCT AREA
 length: 64in. dia.
 width: - in.
 area-in2: 3217in.2
 area-ft2: 22.34028ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	890.60	67	73	42	.40	1.62	<2	0	20.9
2	5	894.27	67	81	45	.36	1.48	<2	0	20.9
3	10	.00	67	88	49	.34	1.42	<2	0	20.9
4	15	901.24	67	93	52	.27	1.14	<2	0	20.9
5	20	.00	67	92	54	.22	.93	<2	0	20.9
6	25	.00	67	95	55	.14	.59	<2	0	20.9
7	30	909.60	66	93	56	.11	.46	<2	0	20.9
8	35	.00	66	95	50	.10	.42	<2	0	20.9
9	40	.00	66	95	48	.12	.51	<2	0	20.9
10	45	.00	66	98	48	.15	.64	<2	0	20.9
11	50	918.20	66	96	48	.20	.85	<2	0	20.9
12	55	920.75	66	97	48	.25	1.06	<2	0	20.9
13	60	923.78	66	84	47	.52	2.16	2	0	20.9
14	65	928.30	66	97	44	.48	2.04	2	0	20.9
15	70	.00	66	106	47	.45	1.94	2	0	20.9
16	75	936.01	66	108	47	.42	1.82	2	0	20.9
17	80	939.97	66	112	48	.40	1.75	2	0	20.9
18	85	944.00	66	114	48	.26	1.14	<2	0	20.9
19	90	947.05	66	112	49	.05	.22	<2	0	20.9
20	95	948.60	66	108	50	.11	.48	<2	0	20.9
21	100	950.70	66	108	47	.20	.87	<2	0	20.9
22	105	.00	65	111	47	.31	1.35	<2	0	20.9
23	110	956.80	65	111	47	.40	1.75	<2	0	20.9
24	115	960.65	65	111	48	.44	1.92	2	0	20.9
25	120	964.68					.00			
AVERAGE		66.125	99.08333	48.5		.26	1.19	2	0	20.9

METER VOLUME = 74.06 ft3
 DRY GAS VOL.SCF = 70.22 ft3
 WATER VAPOR VOL = 1.51 ft3
 MOIST CONTENT = .02
 MOL FRAC DRY GAS = .98

ABS STACK PRES = 29.97 in. Hg
 WET GAS MOLC WT = 28.80 lb/lb-mole
 STACK GAS VELO = 28.92 ft/sec
 NOZZLE AREA = .0003301 ft2
 DUCT GASFLOW.ACFM = 38073.20 CFM
 DUCT GASFLOW.SCFM = 38278.75 CFM

>> ISOKINETIC VARIATION = 103.52 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 18 May 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 2	Box # : 4	I.D. # : 2	I.D. # : 6M-2	I.D. # : 2	I.D. # : 4
Run # : 3	Delta H ₂ O : 1.2014	Liner : GLASS	Diam : .349	Coeffici : .8	Filtr # : -
Location: LBNSY - Bldg 210	Crct Fac: 1.063	Length : 10			Leak rt : 0cfm
Source : 102-IN	Heat Set: -	Heater : -			@ : 27in. H2O
Engineer: KIRK/FAN					H2O gain: 39.4ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 71F	Stack gas	length: 74in.
Barometer: 29.98in. Hg	dry wt : 29lb/lb-mol	width: 43in.
Stk Stat: -3.00in. H2O	Water vap	area-in2: 3182in.2
	proport: .015	area-ft2: 22.09722ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	.00	75	78	73	.04	.38	4	0	20.9
2	5	2.13	74	79	43	.03	.28	4	0	20.9
3	10	4.07	75	81	45	.07	.66	4	0	20.9
4	15	6.38	75	85	46	.06	.57	4	0	20.9
5	20	8.96	75	85	49	.40	3.82	10	0	20.9
6	25	15.16	75	100	54	.78	7.66	16	0	20.9
7	30	22.51	74	111	60	.47	4.72	13	0	20.9
8	35	29.57	74	117	55	.33	3.35	9	0	20.9
9	40	35.69	74	97	67	.00	.00	0	0	20.9
10	45	35.69	75	96	68	.01	.10	5	0	20.9
11	50	36.83	75	76	52	.10	.94	6	0	20.9
12	55	39.60	75	99	46	.25	2.45	9	0	20.9
13	60	44.38	74	107	50	.35	3.49	11	0	20.9
14	65	50.26	74	115	54	.48	4.85	15	0	20.9
15	70	57.22	74	122	57	.50	5.12	15	0	20.9
16	75	64.51	74	126	54	.32	3.30	11	0	20.9
17	80	70.74	73	103	67	.07	.69	6	0	20.9
18	85	73.57	73	103	45	.07	.69	6	0	20.9
19	90	76.42	73	103	47	.08	.79	6	0	20.9
20	95	49.42	73	103	48	.22	2.18	9	0	20.9
21	100	83.27	73	106	51	.70	6.98	10	0	20.9
22	105	88.36	72	109	53	.43	4.32	13	0	20.9
23	110	94.19	72	113	54	.37	3.74	13	0	20.9
24	115	100.56	72	116	54	.27	2.74	10	0	20.9
25	120	104.96					.00			

AVERAGE	73.875	101.25	53.8333	.21	2.66	8.708333	0	20.9
---------	--------	--------	---------	-----	------	----------	---	------

METER VOLUME = 111.57 ft3	ABS STACK PRES = 29.76 in. Hg
DRY GAS VOL. SCF = 105.82 ft3	WET GAS MOLC WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.81 ft3	STACK GAS VELO = 24.81 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0006643 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW ACFM = 32306.59 CFM
	DUCT GASFLOW SCFM = 31779.52 CFM

ISOKINETIC VARIATION = 92.35 %

ISOURCE EMISSIONS TESTING DATA SHEET

Date : 16 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 2	Box # : 3	I.D. # : 1	I.D. # : -	I.D. # : 1	I.D. # : 3
Run # : 3	Delta H# : 1.8088	Liner : GLASS	Diam : .246	Coeffici : .85	Filtr # : -
Location: LBNSY - Bldg 210	Crcr Fac: .9996	Length : 6			Leak rt : .004cfm
Source : 102-OUT	Heat Set: -	Heater : -			@ : 15in. H2O
Engineer: QUA/BEL					H2O gains: 28.3ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 74F	Stack gas	length: 64in. dia.
Barometer: 29.98in. Hg	drv wt : 29lb/lb-mol	width: - in.
Stk Stat: .20in. H2O	Water vap	area-in2: 3217 in.2
	proport: .02	area-ft2: 22.34028ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	964.83	68	78	52	.39	1.56	4	0	20.9
2	5	967.70	67	86	45	.35	1.43	4	0	20.9
3	10	971.11	66	95	47	.33	1.37	4	0	20.9
4	15	974.55	65	101	50	.28	1.18	3.5	0	20.9
5	20	977.77	65	102	50	.22	.93	3.5	0	20.9
6	25	980.55	65	98	49	.14	.59	2.5	0	20.9
7	30	.00	65	101	50	.10	.42	2	0	20.9
8	35	984.80	65	102	49	.11	.46	2	0	20.9
9	40	986.92	65	104	46	.13	.55	2.5	0	20.9
10	45	989.05	65	107	46	.17	.72	3	0	20.9
11	50	991.57	66	110	45	.23	.98	3.5	0	20.9
12	55	994.50	66	113	44	.28	1.20	3.5	0	20.9
13	60	997.75	67	99	54	.28	1.17	3.5	0	20.9
14	65	1001.10	66	108	44	.30	1.28	3.5	0	20.9
15	70	1004.40	66	112	46	.29	1.24	3.5	0	20.9
16	75	1007.70	67	116	46	.43	1.85	4.5	0	20.9
17	80	1011.61	67	121	46	.37	1.61	4.5	0	20.9
18	85	1014.90	67	120	48	.26	1.13	3.5	0	20.9
19	90	1018.64	67	117	49	.06	.26	<2	0	20.9
20	95	1020.30	67	110	50	.11	.47	2.5	0	20.9
21	100	1022.37	67	107	48	.20	.85	3	0	20.9
22	105	1025.04	67	109	47	.32	1.36	4	0	20.9
23	110	1028.49	67	112	47	.41	1.75	4.5	0	20.9
24	115	1032.39	67	114	47	.46	1.97	4.8	0	20.9
25	120	1036.44					.00			

AVERAGE	66.25	105.9167	47.70833		.25	1.10	3.469565		0	20.9
---------	-------	----------	----------	--	-----	------	----------	--	---	------

METER VOLUME =	71.58 ft3	ABS STACK PRES =	29.99 in. Hg
DRY GAS VOL. SCF =	67.07 ft3	WET GAS MOL WT =	28.80 lb/lb-mole
WATER VAPOR VOL =	1.33 ft3	STACK GAS VELO =	28.10 ft/sec
MOIST CONTENT =	.02	NOZZLE AREA =	.0003301 ft2
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	36983.71 CFM
		DUCT GASFLOW, SCFM =	37199.35 CFM

>> ISOKINETIC VARIATION = 101.76 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 18 MAY 84 CONTROL PROBE NOZZLE PITOT IMPINGER
 Test # : 2 Box # : 8 I.D. # : 2 I.D. # : 12 I.D. # : 2 I.D. # : 8
 Run # : 4 Delta H: 1.8739 Liner : GLASS Diam : .249 Coeff: .8 Filt: # : -
 Location: LBNSY - Bldg 210 Crot Fac: 1.0085 Length : 10 Leak rt : 0cfm
 Source : 102-IN Heat Set: - Heater : - @ : 25in. H2O
 Engineer: KIRK/FAN H2O gain: 36.4ml

ATMOSPHERE ESTIMATE DUCT AREA
 Ambient : 62F Stack gas length: 74in.
 Barometer: 29.98in. Hg dry wt : 29lb/lb-mol width: 43in.
 Stk Stat: -2.80in. H2O Water vap area-in2: 3182in.2
 proportion: .015 area-ft2: 22.09722ft.2

Port # Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	706.68	66	71	64	.00	.00	0	0	20.9
2	5	706.68	65	69	64	.06	.23	0	0	20.9
3	10	708.00	65	70	47	.19	.73	0	0	20.9
4	15	710.09	65	75	40	.31	1.20	1	0	20.9
5	20	712.98	65	82	39	.42	1.65	1	0	20.9
6	25	716.14	65	90	42	.83	3.30	5	0	20.9
7	30	720.52	65	102	47	.49	1.99	2	0	20.9
8	35	724.58	66	105	50	.40	1.63	2	0	20.9
9	40	728.11	66	92	57	.00	.00	0	0	20.9
10	45	728.11	66	90	58	.02	.08	0	0	20.9
11	50	728.96	66	89	52	.10	.40	0	0	20.9
12	55	730.57	66	91	43	.22	.87	0	0	20.9
13	60	732.99	66	96	38	.36	1.44	1	0	20.9
14	65	736.13	65	102	41	.45	1.83	2	0	20.9
15	70	739.65	65	105	43	.48	1.96	2	0	20.9
16	75	746.32	65	107	45	.31	1.27	1	0	20.9
17	80	745.99	65	96	56	.00	.00	0	0	20.9
18	85	745.99	65	96	56	.00	.00	0	0	20.9
19	90	745.99	65	94	57	.08	.32	0	0	20.9
20	95	747.54	65	92	43	.21	.84	0	0	20.9
21	100	749.88	64	95	40	.38	1.53	1	0	20.9
22	105	753.00	65	100	40	.39	1.58	1	0	20.9
23	110	756.34	65	105	52	.32	1.31	1	0	20.9
24	115	759.51	65	106	44	.21	.86	1	0	20.9
25	120	762.22					.00			
AVERAGE			65.25	92.5	48.25	.19	1.04	.875	0	20.9

METER VOLUME = 56.01 ft3 ABS STACK PRES = 29.77 in. Hg
 DRY GAS VOL. SCF = 53.75 ft3 WET GAS MOL WT = 28.90 lb/lb-mole
 WATER VAPOR VOL = 1.71 ft3 STACK GAS VELO = 23.60 ft/sec
 MOIST CONTENT = .02 NOZZLE AREA = .0003382 ft2
 MOL FRAC DRY GAS = .98 DUCT GASFLOW, ACFM = 30727.44 CFM
 DUCT GASFLOW, SCFM = 30737.66 CFM

ISOKINETIC VARIATION = 95.28 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 18 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 2	Box # : 6	I.D. # : 1	I.D. # : -	I.D. # : 1	I.D. # : 6
Run # : 4	Delta H# : 1.8088	Liner : GLASS	Dia# : .244	Coeffici : .95	Filtr # : -
Location: LBNBY - Bldg 210	Crcd Fac: .9996	Length : 6			Leak rt : .004cfm
Source : 102-DUT	Heat Set: -	Heater : -			@ : 15in. H2O
Engineer: GUA/BEL					H2O gain: 32.9ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 62F	Stack gas	length: 64in. dia.
Barometer: 29.98in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .20in. H2O	Water vap	area-in2: 3217in.2
	proport: .02	area-ft2: 22.34028ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	37.43	67	69	45	.40	1.53	2.9	0	20.9
2	5	41.00	68	78	41	.36	1.40	2.5	0	20.9
3	10	44.50	68	85	43	.33	1.30	2.5	0	20.9
4	15	.00	68	89	45	.27	1.07	2.5	0	20.9
5	20	50.72	68	90	46	.22	.87	2	0	20.9
6	25	53.44	67	90	46	.14	.56	<2	0	20.9
7	30	55.66	67	91	45	.11	.44	<2	0	20.9
8	35	57.63	67	92	45	.10	.40	<2	0	20.9
9	40	59.54	67	94	45	.13	.52	2	0	20.9
10	45	61.68	67	98	45	.19	.77	2.5	0	20.9
11	50	64.20	67	99	46	.25	1.01	2.5	0	20.9
12	55	67.17	67	103	46	.30	1.22	2.5	0	20.9
13	60	70.37	68	95	50	.53	2.12	3.5	0	20.9
14	65	74.53	68	109	48	.50	2.05	3	0	20.9
15	70	78.62	68	114	49	.44	1.82	3	0	20.9
16	75	82.53	68	116	50	.41	1.70	3	0	20.9
17	80	86.34	68	116	50	.38	1.58	2.5	0	20.9
18	85	90.00	68	116	50	.26	1.08	2.5	0	20.9
19	90	93.05	68	113	51	.06	.25	<2	0	20.9
20	95	94.68	68	108	50	.12	.49	<2	0	20.9
21	100	96.76	68	108	49	.20	.82	2.5	0	20.9
22	105	99.40	68	110	49	.31	1.28	2.8	0	20.9
23	110	102.67	69	113	50	.42	1.73	3.5	0	20.9
24	115	106.47	69	117	50	.44	1.83	3.5	0	20.9
25	120	110.41					.00			

AVERAGE	67.75	100.5417	47.25	.27	1.16	2.715789	0	20.9
---------	-------	----------	-------	-----	------	----------	---	------

METER VOLUME	=	72.95 ft3	ABS STACK PRES	=	29.99 in. Hg
DRY GAS VOL. SCF	=	69.02 ft3	WET GAS MOLE WT	=	28.80 lb/lb-mole
WATER VAPOR VOL	=	1.55 ft3	STACK GAS VELO	=	29.42 ft/sec
MOIST CONTENT	=	.02	NOZZLE AREA	=	.0003247 ft2
MOL FRAC DRY GAS	=	.98	DUCT GASFLOW, ACFM	=	38730.49 CFM
			DUCT GASFLOW, SCFM	=	38845.60 CFM

----->> ISOKINETIC VARIATION = 101.93 %

--GF-- --SFT GF--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

0	0
.07	.2645751
.22	.4690416
.31	.5567764
.43	.6557435
.81	.9
.88	.7416195
.94	.4898979
0	0
.02	.1414214
.1	.3162278
.25	.5
.35	.5916080
.5	.7071068
.61	.7141428
.68	.5291503
0	0
.01	.1
.08	.2525427
.09	.4795832
.36	.6164414
.79	.6244998
.37	.6082763
.23	.4795832

DATE : 21 MAY 64

SCRUBBER: 102-IN/IMPACTOR

TEST : 3

RUN : 2

=====

.4486891

GP AVE = .2013219

IMPACTOR TESTING DATA SHEET

Date: 101 MAY 64
 Test #: 7
 Run #: 1
 Location: ALBANY - Bldg 210
 Source: 1100-1N
 Engineer: KIRK/FAN

CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Eq. #: 1	I.D. #: 10-2	I.D. #: 7	I.D. #: 10-2	I.D. #: 3
Delta Hg: 1.6775	Liner: STAINLESS	Diam: .1045	Coefficient: .75	Filter #: -
Orif. Fac: 1.0085	Length: 10			Leak rt: 0cfm
West Set: -	Heater: -			Q: 3151.420
				Wet gain: 25ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient: 60F	Stack gas	length: 74in.
Barometer: 29.84in. Hg	dry wt: 2915/lb-mol	width: 47in.
Sat. Stet: -0.50in. H2O	Water vap	area-in ² : 7183in. ²
	pressure: .015	area-ft ² : 22.09722ft. ²

Port % Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Water Inlet Temp (F)	Impinger Temp (F)	Velocity Head dp (in. H2O)	Orifice Delta W (in. H2O)	Sample Vacuum (in. Hg)	CO (%)	O2 (%)
1	0	760.75	70.25	80.5	57.88	.19	.66	.675	0	20.9
2	40	760.15	70.25	80.5	57.88	.19	.66	.675	0	20.9
3	80	807.97	70.25	80.5	57.88	.19	.66	.675	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			70.25	80.5	57.88	.19	.66	.675	0	20.9

METER VOLUME = 40.40 ft ³	ABS STACK PRESS = 29.82 in. Hg
DRY GAS VOL. SCF = 40.40 ft ³	METRIC MOLE WT = 29.64 lb/lb-mole
WATER VAPOR VOL = 1.15 ft ³	STACK GAS VELO = 22.90 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007287 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 29901.75 CFM
	DUCT GASFLOW, SCFM = 29490.72 CFM

ISOKINETIC VARIATION = 115.15 %

IMPACTOR TESTING DATA SHEET

Date : 21 MAY 84
 Test # : 3
 Run # : 1
 Location: LENSEY - Bldg 210
 Source : 100-GUT
 Engineer: GUY/BEL

CONTROL
 Box # : 5
 Delta Hg: 1.9086
 Crot Fac: .9994
 Heat Set: -

SCOPE
 I.D. # : -
 Liner : 18-STEEL
 Length : 6
 Heater : -

NOZZLE
 I.D. # : -
 Diam : .046

PITOT
 I.D. # : -
 Coeff: .95

IMPINGER
 I.D. # : 4
 Filter # : -
 Seal mt : .0120 ft
 E : 15 in. H2O
 H2O gain: 20.9 ml

ATMOSPHERE
 Ambient : 59F
 Barometric: 29.84 in. Hg
 RH State: .26 in. H2O

ESTIMATE
 Stack gas
 dry wt : 2915/1b-mol
 Water vap
 percent: .02

DUCT AREA
 length: 44 in. dia.
 width: - in.
 area-in²: 73.7 in.²
 area-ft²: 0.514028 ft²

Port % Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Water Inlet Temp (F)	Impinger Temp (F)	Velocity Head (F) (in H2O)	Griffice Delta H (in H2O)	Sample Vacuum (in Hg)	% (%)	% (%)
1	0	110.22	67	85.25	44.375	.27	1.10	2.8	0	20.9
2	40	124.39	67	85.25	44.375	.27	1.10	2.8	0	20.9
3	80	155.30	67	85.25	44.375	.27	1.10	2.8	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			67	85.25	44.375	.27	1.10	2.8	0	20.9

METER VOLUME = 47.44 ft³
 DRY GAS VOL. SCF = 45.94 ft³
 WATER VAPOR VOL = .96 ft³
 MOIST CONTENT = .02
 VOL REAC DRY GAS = .98

ABS STACK PRES = 29.84 in. Hg
 WET GAS MOLE WT = 28.77 lb/lb-mole
 STACK GAS VELO = 29.57 ft/sec
 NOZZLE AREA = .0007301 ft²
 DUCT GASFLOW, ACFM = 38609.55 CFM
 DUCT GASFLOW, SCFM = 38604.47 CFM

ISOKINETIC VARIATION = 100.27 %

IMPACTOR TESTING DATA SHEET

Date : 01 MAY 64 CONTROL PFDSE NOZZLE PITOT IMPINGER
 Test # : 3 Box # : 1 I.D. # : 10-2 I.D. # : - I.D. # : 10-2 I.D. # : 7
 Run # : 2 Delta Hg: 1.8779 Liner : GLASS Diam : .0455 Coeffici: .76 Filter #: -
 Location: LBNEY - Bldg 210 Orst Fac: 1.0085 Length : 10 Leak rt : 0cfa
 Source : 102-IN Heat Set: - Heater : - @ : 24in. H2O
 Engineer: KIRK/PAN H2O gain: 51.4ml

ATMOSPHERE ESTIMATE DUCT AREA
 Ambient : 57F Stack gas length: 43in.
 Barometer: 29.84in. Hg dry wt : 29lb/lb-mol width: 74in.
 Stk Stati: -2.80in. H2O Water vap area-in2: 3182in.2
 proports: .015 area-ft2: 22.09722ft.2

Port	Sample	Gas	Stack	Meter	Impinger	Velocity	Griffice	Sample				
Point	Time	Meter	Temp	Inlet	Temp	Head cP	Delta H	Vacuum		CO2	O2	
Number	(min)	(ft3)	(F)	Temp (F)	(F)	(in H2O)	(in H2O)	(in Hg)		(%)	(%)	
1	0	804.00	67.56	67.11	49.61	.20	.71	1	1	0	20.9	
2	90	851.53	67.59	67.11	49.61	.20	.71	1	1	0	20.9	
3	180	899.66	67.59	67.11	49.61	.20	.71	1	1	0	20.9	
4	-	-	-	-	-	-	-	-	1	0	20.9	
5	-	-	-	-	-	-	-	-	1	0	20.9	
AVERAGE			67.58	67.11	49.61	.20	.71	1	1	0	20.9	

METER VOLUME = 96.47 ft3 ABS STACK PRES = 29.83 in. Hg
 DRY GAS VOL.SCF = 92.98 ft3 WETGAS MDL WT = 29.73 lb/lb-mol
 WATER VAPOR VOL = 3.42 ft3 STACK GAS VELO = 23.54 ft/sec
 MOIST CONTENT = .03 NOZZLE AREA = .0003287 ft2
 MOL FRAC DRY GAS = .98 DUCT GASFLOW.ACFM = 30424.26 CFM
 DUCT GASFLOW.SCFM = 30157.49 CFM

ISOKINETIC VARIATION = 115.21 %

IMPACTOR TESTING DATA SHEET

Date : 01 MAY 84	CONTRL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 3	Box # : 5	I.D. # : -	I.D. # : -	I.D. # : -	I.D. # : 5
Run # : 2	Delta H# : 1.8068	Liner : GLASS	Dia# : .245	Coeffici : .95	Filtr # : -
Location: LBNV - Bldg 210	Orat Fac: .9996	Length : 6			Leak rt : .004cfm
Source : 102-DUT	Heat Set: -	Heater : -			@ : 15in. H2O
Engineer: GUA/BEL					H2O gain: 42.4ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 58F	Stack gas	length: 64in. dia.
Barometer: 29.84in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk. Stat: .20in. H2O	Water vap	area-in2: 3217in.2
	proporti: .02	area-ft2: 22.74028ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	159.20	66.72	96.28	51.17	.27	1.10	2.9	0	20.9
2	90	210.54	66.72	96.28	51.17	.27	1.10	2.9	0	20.9
3	180	262.03	66.72	96.28	51.17	.27	1.10	2.9	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			66.72	96.28	51.17	.27	1.10	2.9	0	20.9

METER VOLUME = 102.95 ft3	ABG STACK PRES = 29.85 in. Hg
RY GAS VOL.SCF = 97.72 ft3	METGAS MOLE WT = 28.79 lb/lb-mole
WATER VAPOR VOL = 2.00 ft3	STACK GAS VELO = 29.56 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003274 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW.ACFM = 38666.91 CFM
	DUCT GASFLOW.SCFM = 38676.35 CFM

--> ISOKINETIC VARIATION = 95.35 %

--dP-- --SQRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

0 0

0 0

0 0

.15 .3672983

.17 .4123106

.19 .4358899

.19 .4358899

.19 .4358899

0 0

0 0

.01 .1

.15 .3672983

.17 .4123106

.18 .4242641

.19 .4358899

.19 .4358899

0 0

0 0

.01 .1

.12 .3464102

.18 .4242641

.19 .4358899

.19 .4358899

.19 .4358899

=====

.2700531

dP AVE = .0729287

DATE : 24 MAY 94

SCRUBBER: 103-IN

TEST : 4

RUN : 1

--dP-- --SQRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.22 .4690416
.26 .5099020
.22 .4690416
.18 .4242641
.15 .3872983
.06 .2449490
.07 .2645751
.12 .3464102
.22 .4690416
.31 .5567764
.37 .6082763
.46 .6782330
.2 .4472136
.2 .4472136
.18 .4242641
.15 .3872983
.13 .3605551
.08 .2828427
.04 .2
.08 .2828427
.14 .3741657
.21 .4582576
.29 .5385165
.36 .6

DATE : 24 MAY 84

SCRUBBER: 103-OUT

TEST : 4

RUN : 1

=====

.4262908

dP AVE = .1817238

Date	:22 MAY 64	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test #	: 4	Box # : 4	I.D. # : 2	I.D. # : DM-3	I.D. # : 2	I.D. # : 4
Run #	: 1	Delta H ₂ : 1.7782	Linear : GLASS	Diam : .3623	Coeffici: .81	Filtr #: -
Location: LANSY - Bldg 210	Crc't Fac: 1.0049	Length : 10				Leak rt : 0cfm
Source : 103-IN	Heat Set: -	Heater : -				@ : 25in. H ₂ O
Engineer: KIRK/FAN						H ₂ O gain: 55.6ml

ATMOSPHERE		ESTIMATE		DUCT AREA	
Ambient :	60F	Stack gas		length:	64in.
Barometer:	29.9in. Hg	dry wt :	29lb/lb-mol	width:	86in.
Stk Stat:	-1.50in. H2O	Water vap		area-in2:	5504in.2
		proport:	.03	area-ft2:	39.22222ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Drift Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	899.91	65	66	64	.00	.00	0	0	20.9
2	5	899.91	65	66	64	.00	.00	0	0	20.9
3	10	899.91	65	66	64	.00	.00	0	0	20.9
4	15	899.91	65	66	64	.14	2.27	12	0	20.9
5	20	963.83	65	75	42	.18	2.97	17	0	20.9
6	25	908.08	65	86	50	.19	3.20	17	0	20.9
7	30	912.38	65	93	54	.18	3.07	17	0	20.9
8	35	916.69	65	99	55	.20	3.45	-	0	20.9
9	40	920.99	65	90	61	.00	.00	0	0	20.9
10	45	920.99	65	88	62	.00	.00	0	0	20.9
11	50	920.99	65	86	62	.01	.17	1	0	20.9
12	55	922.20	65	84	54	.15	2.52	15	0	20.9
13	60	925.59	65	93	49	.18	3.07	17	0	20.9
14	65	929.93	65	102	52	.19	3.29	17	0	20.9
15	70	934.29	64	107	51	.18	3.15	17	0	20.9
16	75	938.68	64	110	51	.18	3.17	17	0	20.9
17	80	943.05	64	100	59	.00	.00	0	0	20.9
18	85	943.05	64	97	60	.00	.00	0	0	20.9
19	90	943.05	64	96	60	.00	.00	0	0	20.9
20	95	943.05	64	94	61	.15	2.57	16	0	20.9
21	100	947.29	64	103	48	.17	2.96	17	0	20.9
22	105	951.62	64	109	50	.18	3.17	17	0	20.9
23	110	956.00	64	112	51	.18	3.18	17	0	20.9
24	115	960.38	64	114	52	.18	3.19	17	0	20.9
25	120	964.74					.00			
AVERAGE		64.58333	91.75	85.83333		.07	1.89	10.04348	0	20.9

WATER VOLUME	=	65.15	ft3	ABS STACK PRES	=	29.79	in. Hg
DRY GAS VOL, SCF	=	62.57	ft3	WET GAS MOL WT	=	28.80	lb/lb-mole
WATER VAPOR VOL	=	2.62	ft3	STACK GAS VELO	=	14.38	ft/sec
MOIST CONTENT	=	.02		NOZZLE AREA	=	.0007159	ft2
MOL FRAC DRY GAS	=	.98		DUCT GASFLOW, ACFM	=	32385.83	CFM
				DUCT GASFLOW, SCFM	=	32454.78	CFM

- -> ISOKINETIC VARIATION = 85.83 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 22 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINER
Test # : 4	Box # : E	I.D. # : -	I.D. # : 10	I.D. # : -	I.D. # : 5
Run # : 1	Delta H ₂ : 1.8088	Liner : GLASS	Diam : .375	Coeffici: .85	Filtr # : -
Location: LBNSY - Bldg 210	Crc ₂ Fac: .9996	Length : 7			Leak rt : .004cfm
Source : 103-OUT	Heat Set: -	heater : -			Q : 15in. H ₂ O
Engineer: SUZ/BEL					H ₂ O gain: 34.4ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 62F	Stack gas	length: 64in. dia.
Barometer: 29.9in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .15in. H ₂ O	Water vap	area-in ² : 3217in. ²
	proport: .02	area-ft ² : 22.34028ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Drifce Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	263.16	67	67	66	.26	5.53	7	0	20.9
2	5	70.00	66	87	48	.24	5.31	7	0	20.9
3	10	.00	66	95	50	.22	4.93	7	0	20.9
4	15	283.70	66	96	50	.21	4.72	7	0	20.9
5	20	289.10	66	99	51	.19	4.29	7	0	20.9
6	25	294.62	66	103	51	.09	2.05	3	0	20.9
7	30	298.98	66	99	50	.04	.90	<2	0	20.9
8	35	301.97	66	95	50	.04	.90	<2	0	20.9
9	40	304.70	66	94	49	.07	1.57	3	0	20.9
10	45	308.20	66	99	49	.11	2.48	4	0	20.9
11	50	312.57	66	103	49	.15	3.41	5	0	20.9
12	55	317.78	66	106	50	.21	4.80	6.5	0	20.9
13	60	323.91	65	73	62	.32	6.91	8	0	20.9
14	65	331.13	66	96	49	.36	8.09	10	0	20.9
15	70	338.78	66	107	52	.33	7.56	8	0	20.9
16	75	346.26	66	112	54	.31	7.17	8.5	0	20.9
17	80	353.61	65	113	54	.23	5.34	7	0	20.9
18	85	360.25	65	112	54	.11	2.55	3.5	0	20.9
19	90	364.94	66	103	54	.04	.91	<2	0	20.9
20	95	368.00	65	96	54	.06	1.35	2	0	20.9
21	100	371.41	65	97	52	.10	2.26	3	0	20.9
22	105	375.59	66	97	52	.13	2.93	4	0	20.9
23	110	380.55	65	99	53	.18	4.07	5	0	20.9
24	115	386.12	66	104	54	.23	5.24	7	0	20.9
25	120	392.55					.00			

AVERAGE	65.79167	98	52.375	.16	3.97	5.833333	0	20.9
---------	----------	----	--------	-----	------	----------	---	------

METER VOLUME = 129.35 ft ³	ABS STACK PRES = 29.91 in. Hg
DRY GAS VOL. SCF = 123.46 ft ³	WET GAS MOLC WT = 29.80 lb/lb-mole
WATER VAPOR VOL = 1.62 ft ³	STACK GAS VELO = 22.80 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007670 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 30009.91 CFM
	DUCT GASFLOW, SCFM = 30126.92 CFM

----->> ISOKINETIC VARIATION = 99.52 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 22 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 4	Box # : B	I.D. # : -	I.D. # : -	I.D. # : -	I.D. # : 8
Run # : 2	Delta Hg: 2.1179	Liner : GLASS	Diam : .3605	Coeffici : .81	Filtr # : -
Location: LBNSY - Bldg 210	Crcd Fac: 1.0263	Length : -			Leak rt : .005cfm
Source : 103-IN	Heat Set: -	Heater : -			@ : 20in. H2O
Engineer: SUZ/BEL					H2O gain: 32.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 60F	Stack gas	length: 64in.
Barometer: 29.97in. Hg	dry wt : 29lb/lb-mol	width: 86in.
Stk Stat: -1.50in. H2O	Water vap	area-in2: 5504in.2
	proport: .03	area-ft2: 38.2222ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	571.30	63	64	62	.00	.00	-	0	20.9
2	5	571.30	63	64	62	.00	.00	-	0	20.9
3	10	571.30	63	64	62	.00	.00	-	0	20.9
4	15	571.30	63	64	62	.13	2.46	2.5	0	20.9
5	20	575.22	63	79	42	.18	3.51	3.5	0	20.9
6	25	580.00	63	92	46	.18	3.59	3.5	0	20.9
7	30	584.43	63	100	49	.18	3.64	3.5	0	20.9
8	35	589.24	63	105	50	.18	3.68	3.5	0	20.9
9	40	594.06	62	85	60	.00	.00	-	0	20.9
10	45	594.06	63	85	60	.00	.00	-	0	20.9
11	50	594.06	63	83	60	.00	.00	-	0	20.9
12	55	594.06	63	80	61	.15	2.93	3.4	0	20.9
13	60	597.72	63	94	45	.17	3.40	3.8	0	20.9
14	65	602.39	63	104	49	.18	3.67	4	0	20.9
15	70	607.26	63	110	51	.18	3.71	4	0	20.9
16	75	612.15	63	112	52	.19	3.93	4	0	20.9
17	80	617.13	62	94	59	.00	.00	-	0	20.9
18	85	617.13	62	92	59	.00	.00	-	0	20.9
19	90	617.13	62	91	60	.00	.00	-	0	20.9
20	95	617.13	62	96	50	.15	3.02	3.5	0	20.9
21	100	620.59	62	103	48	.18	3.67	4	0	20.9
22	105	625.35	62	112	51	.18	3.73	4	0	20.9
23	110	620.28	62	117	52	.18	3.76	4	0	20.9
24	115	635.24	62	118	52	.17	3.56	4	0	20.9
25	120	640.14					.00			

AVERAGE	62.625	92 54.33333	.07	2.18	3.68	0	20.9
---------	--------	-------------	-----	------	------	---	------

METER VOLUME = 70.65 ft3	ABS STACK PRES = 29.86 in. Hg
DRY GAS VOL.SCF = 68.03 ft3	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.53 ft3	STACK GAS VELO = 13.98 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007088 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW.ACFM = 31476.25 CFM
	DUCT GASFLOW.SCFM = 31735.86 CFM

-->> ISOKINETIC VARIATION = 96.38 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 22 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 4	Box # : 1	I.D. # : 1	I.D. # : 6.00	I.D. # : 1	I.D. # : 1
Run # : 2	Delta H ₀ : 2.002	Liner : 6LASS	Diam : .371	Coeffic: .83	Filtr # : -
Location: LBNSY - Bldg 210	Cnst Fac: .9963	Length : 7			Leak rt : .005cfa
Source : 103-OUT	Heat Set: -	Heater : -			@ : 25in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 68.1ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 60F	Stack gas	length: 64in. dia.
Barometer: 29.97in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .15in. H ₂ O	Water vap	area-in ² : 3217in. ²
	proport: .02	area-ft ² : 22.34028ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	393.64	66	67	61	.27	5.81	9	0	20.9
2	5	400.40	65	86	47	.30	6.71	10	0	20.9
3	10	407.20	66	99	50	.29	6.62	10	0	20.9
4	15	414.26	66	106	51	.26	6.01	9	0	20.9
5	20	421.13	66	110	51	.19	4.42	6	0	20.9
6	25	427.32	66	110	51	.09	2.10	3	0	20.9
7	30	432.02	65	107	51	.05	1.16	2	0	20.9
8	35	435.43	66	103	59	.09	2.07	4	0	20.9
9	40	439.09	66	104	50	.13	3.00	4	0	20.9
10	45	443.81	66	108	50	.19	4.41	6	0	20.9
11	50	449.30	66	110	51	.26	6.05	9	0	20.9
12	55	455.97	66	115	52	.33	7.75	11	0	20.9
13	60	463.33	65	87	59	.26	5.82	9	0	20.9
14	65	470.01	66	103	50	.25	5.75	8	0	20.9
15	70	476.74	65	111	51	.22	5.14	8	0	20.9
16	75	483.26	65	115	52	.19	4.47	7	0	20.9
17	80	489.36	65	113	52	.15	3.52	5	0	20.9
18	85	494.87	65	111	51	.08	1.87	4	0	20.9
19	90	499.16	65	104	52	.03	.69	2	0	20.9
20	95	502.24	65	97	52	.04	.91	3	0	20.9
21	100	504.93	65	98	51	.07	1.60	3	0	20.9
22	105	508.43	65	103	51	.12	2.77	5	0	20.9
23	110	512.78	65	104	51	.17	3.92	6	0	20.9
24	115	518.11	65	112	51	.22	5.15	8	0	20.9
25	120	524.27					.00			

AVERAGE	65.45833	103.4583	51.95833		.16	4.07	6.291667		0	20.9
---------	----------	----------	----------	--	-----	------	----------	--	---	------

METER VOLUME =	130.15 ft ³	APS STACK PRES =	29.98 in. Hg
DRY GAS VOL. SCF =	123.33 ft ³	WET GAS MOLE WT =	28.80 lb/lb-mole
WATER VAPOR VOL =	3.21 ft ³	STACK GAS VELO =	22.39 ft/sec
MOIST CONTENT =	.02	NOZZLE AREA =	.0007507 ft ²
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	29466.86 CFM
		DUCT GASFLOW, SCFM =	29669.80 CFM

>> ISOKINETIC VARIATION = 103.14 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 23 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 4	Box # : 3	I.D. # : -	I.D. # : 5M-2	I.D. # : -	I.D. # : 3
Run # : 7	Delta H ₀ : 2.1179	Liner : GLASS	Dia ₀ : .352	Coeffic: .81	Filtr # : -
Location: LBNSV - Bldg 210	Cnst Fac: 1.0263	Length : 10			Leak rt : .008cfm
Source : 103-IN	Heat Set: -	Heater : -			@ : 25in. H ₂ O
Engineer: SUZ/BEL					H ₂ O gain: 30.3ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 68F	Stack gas	length: 64in.
Barometer: 29.95in. Hg	dry wt : 29lb/lb-mol	width: 86in.
Stk Stat: -1.50in. H ₂ O	Water vap	area-in ² : 5504in. ²
	proport: .023	area-ft ² : 38.22222ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	641.52	69	70	68	.00	.00	-	0	20.9
2	5	641.52	69	70	68	.00	.00	-	0	20.9
3	10	641.52	69	70	68	.00	.00	-	0	20.9
4	15	641.52	69	78	50	.15	2.65	4	0	20.9
5	20	645.52	69	89	47	.19	3.43	5.8	0	20.9
6	25	650.43	69	106	51	.19	3.53	6	0	20.9
7	30	.00	68	116	53	.19	3.60	6	0	20.9
8	35	660.11	68	121	54	.18	3.44	-	0	20.9
9	40	668.25	68	105	64	.00	.00	-	0	20.9
10	45	668.25	68	105	64	.00	.00	-	0	20.9
11	50	668.25	68	105	64	.00	.00	-	0	20.9
12	55	668.25	68	105	64	.16	2.98	5.8	0	20.9
13	60	673.09	68	116	54	.19	3.60	6.3	0	20.9
14	65	678.11	68	125	55	.20	3.85	6.8	0	20.9
15	70	683.09	68	130	56	.20	3.89	6.8	0	20.9
16	75	688.42	68	133	56	.19	3.71	6.8	0	20.9
17	80	693.46	68	105	65	.00	.00	-	0	20.9
18	85	693.46	68	105	65	.00	.00	-	0	20.9
19	90	693.46	68	105	65	.00	.00	-	0	20.9
20	95	693.46	68	105	65	.16	2.98	5.8	0	20.9
21	100	698.24	67	116	54	.19	3.61	6.2	0	20.9
22	105	702.12	66	125	56	.20	3.87	6.6	0	20.9
23	110	708.09	66	129	57	.20	3.89	6.9	0	20.9
24	115	713.49	66	132	57	.19	3.72	-	0	20.9
25	120	718.50					.00			

AVERAGE	67.95833	106.9167	59.16667	.07	2.20	6.138462	0	20.9
---------	----------	----------	----------	-----	------	----------	---	------

METER VOLUME =	79.01 ft ³	ABS STACK PRES =	29.84 in. Hg
DRY GAS VOL. SCF =	74.03 ft ³	WET GAS MOLE WT =	28.80 lb/lb-mole
WATER VAPOR VOL =	1.43 ft ³	STACK GAS VELO =	14.59 ft/sec
MOIST CONTENT =	.02	NOZZLE AREA =	.0006758 ft ²
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	32857.14 CFM
		DUCT GASFLOW, SCFM =	32771.52 CFM

> ISO KINETIC VARIATION = 106.53 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 123 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 4	Box # : 5	I.D. # : 1	I.D. # : 6.00	I.D. # : 1	I.D. # : 5
Run # : 3	Delta H: 2.0026	Liner : GLASS	Diam : .37075	Coeffici: .83	Filtr # : -
Location: LBNSY - Bldg 210	Cret Fac: .9963	Length : 7			Leak rt : .008cfm
Source : 103-OUT	Heat Set: -	Heater : -			θ : 29in. H2O
Engineer: KIRK/FAN					H2O gain: 53.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 68F	Stack gas	length: 64in. dia.
Barometer: 29.95in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: -.16in. H2O	Water vap	area-in2: 3217in.2
	proport: .02	area-ft2: 22.34028ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	535.13	69	73	69	.22	.00	12	0	20.9
2	5	531.08	69	87	49	.21	.00	12	0	20.9
3	10	537.12	68	99	56	.21	.00	12	0	20.9
4	15	543.21	68	104	58	.18	.00	12	0	20.9
5	20	549.13	68	109	55	.13	.00	8	0	20.9
6	25	554.27	68	107	52	.08	.00	5	0	20.9
7	30	558.36	68	106	51	.03	.00	3	0	20.9
8	35	561.22	68	102	52	.05	.00	4	0	20.9
9	40	564.23	68	102	51	.09	.00	5	0	20.9
10	45	568.06	67	107	49	.16	.00	9	0	20.9
11	50	573.18	68	112	50	.22	.00	13	0	20.9
12	55	579.42	67	121	53	.34	.00	20	0	20.9
13	60	586.31	67	88	67	.28	.00	20	0	20.9
14	65	592.51	67	102	50	.27	.00	21	0	20.9
15	70	598.59	67	114	51	.27	.00	21	0	20.9
16	75	605.07	67	121	52	.23	.00	16	0	20.9
17	90	611.80	67	123	51	.19	.00	11	0	20.9
18	85	617.99	67	121	52	.08	.00	5	0	20.9
19	90	622.47	67	114	52	.05	.00	4	0	20.9
20	95	625.81	67	104	53	.09	.00	5	0	20.9
21	100	629.74	67	105	51	.15	.00	8	0	20.9
22	105	634.83	67	105	51	.22	.00	13	0	20.9
23	110	641.01	67	110	51	.31	.00	20	0	20.9
24	115	648.16	67	113	52	.39	.00	-	0	20.9
25	120	655.40					.00			

AVERAGE	67.5	106.2083	53.25		.17	.00	11.26087		0	20.9
---------	------	----------	-------	--	-----	-----	----------	--	---	------

METER VOLUME = 129.79 ft3	ABS STACK PRES = 29.94 in. Hg
DRY GAS VOL.SCF = 121.10 ft3	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 2.52 ft3	STACK GAS VELO = 22.96 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007497 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW.ACFM = 30225.49 CFM
	DUCT GASFLOW.SCFM = 30272.58 CFM

ISOKINETIC VARIATION = 99.40 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 23 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 4	Box # : 6	I.D. # : -	I.D. # : 6M-2	I.D. # : -	I.D. # : 6
Run # : 4	Delta H ₀ : 2.1179	Liner : GLASS	Diam : .3547	Coeffici: .81	Filtr #: -
Location: LBNSY - Bldg 210	Cnst Fac: .9926	Length : -			Leak rt: .007cfm
Source : 103-IN	Heat Set: -	Heater : -			θ : 22in. H ₂ O
Engineer: SUZ/BEL					H ₂ O gain: 31.8ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 59F	Stack gas	length: 64in.
Barometer: 29.91in. Hg	dry wt : 29lb/lb-mol	width: 8in.
Stk Stat: -1.50in. H ₂ O	Water vap	area-in ² : 5504in. ²
	proport: .023	area-ft ² : 38.22222ft. ²

Port # Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	720.40	63	75	61	.00	.00	-	0	20.9
2	5	720.40	63	75	61	.00	.00	-	0	20.9
3	10	720.40	63	75	61	.00	.00	-	0	20.9
4	15	720.40	63	75	61	.15	2.75	3.9	0	20.9
5	20	724.62	63	91	41	.19	3.59	3.6	0	20.9
6	25	729.44	63	104	44	.20	3.87	3.9	0	20.9
7	30	734.28	63	112	46	.21	4.12	3.9	0	20.9
8	35	740.00	63	116	49	.20	3.95	4	0	20.9
9	40	744.90	63	110	55	.00	.00	-	0	20.9
10	45	744.90	63	110	55	.00	.00	-	0	20.9
11	50	744.90	63	110	55	.00	.00	-	0	20.9
12	55	744.90	63	110	55	.18	3.52	3.5	0	20.9
13	60	.00	63	111	48	.18	3.52	3.5	0	20.9
14	65	753.40	63	118	50	.22	4.36	4.2	0	20.9
15	70	759.29	63	123	51	.21	4.20	4.2	0	20.9
16	75	764.69	63	125	52	.21	4.21	4.2	0	20.9
17	80	769.97	63	113	57	.00	.00	-	0	20.9
18	85	769.97	63	109	57	.00	.00	-	0	20.9
19	90	769.97	63	107	58	.00	.00	-	0	20.9
20	95	769.97	63	104	58	.18	3.48	4.6	0	20.9
21	100	774.84	63	115	49	.20	3.94	4	0	20.9
22	105	779.98	63	122	52	.21	4.19	4	0	20.9
23	110	785.37	63	125	53	.20	4.01	4	0	20.9
24	115	790.61	63	127	53	.20	4.02	4	0	20.9
25	120	795.79					.00			

AVERAGE	63	106.75	53.41667		.08	2.41	3.966667		0	20.9
---------	----	--------	----------	--	-----	------	----------	--	---	------

METER VOLUME = 74.83 ft ³	ABS STACK PRES = 29.80 in. Hg
DRY GAS VOL. SCF = 70.08 ft ³	METGAS MOL WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.50 ft ³	STACK GAS VELO = 14.94 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0006862 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 33649.98 CFM
	DUCT GASFLOW, SCFM = 33835.07 CFM

-----> ISOKINETIC VARIATION = 96.19 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 05 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 4	Box # : 1	I.D. # : 1	I.D. # : 6.00	I.D. # : 1	I.D. # : 1
Run # : 4	Delta H: 2.0026	Liner : GLASS	Diam : .374	Coeff: .83	Filtr # : -
Location: LBNSY - Bldg 210	Crt Fac: .9963	Length : 7			Leak rt : .002cfm
Source : 103-DUT	Heat Set: -	Heater : -			@ : 25in. H2O
Engineer: KIRK/FAN					H2O gain: 53.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 5BF	Stack gas	length: 64in. dia.
Barometer: 29.91in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .13in. H2O	Water vap	area-in2: 3217in.2
	proport: .02	area-ft2: 22.34028ft.2

Port # Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Drifrice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	656.02	66	65	59	.30	6.65	11	0	20.9
2	5	.00	66	87	46	.29	6.69	11	0	20.9
3	10	669.95	66	96	51	.26	6.10	11	0	20.9
4	15	676.85	66	104	54	.21	5.00	9	0	20.9
5	20	683.26	66	105	55	.17	4.05	7	0	20.9
6	25	689.00	66	104	55	.10	2.38	5	0	20.9
7	30	693.67	66	100	54	.03	.71	3	0	20.9
8	35	696.59	66	94	54	.04	.94	3	0	20.9
9	40	699.31	66	93	53	.05	1.17	3	0	20.9
10	45	702.41	66	98	53	.07	1.65	4	0	20.9
11	50	706.00	66	100	53	.09	2.13	5	0	20.9
12	55	709.99	66	100	53	.09	2.13	5	0	20.9
13	60	714.15	65	79	58	.34	7.75	13	0	20.9
14	65	720.08	66	98	49	.35	8.24	14	0	20.9
15	70	729.33	66	113	54	.32	7.74	13	0	20.9
16	75	736.99	66	116	54	.29	7.05	12	0	20.9
17	80	744.40	66	119	55	.20	4.89	8	0	20.9
18	85	750.90	66	116	55	.10	2.43	5	0	20.9
19	90	755.83	66	113	54	.04	.97	3	0	20.9
20	95	759.39	66	107	55	.06	1.44	4	0	20.9
21	100	762.63	66	106	54	.08	1.91	4	0	20.9
22	105	766.49	66	105	53	.10	2.38	5	0	20.9
23	110	770.80	66	105	53	.13	3.10	6	0	20.9
24	115	775.69	66	108	53	.16	3.84	7	0	20.9
25	120	781.04					.00			

AVERAGE	65.95833	101.2917	53.625		.14	3.81	7.125		0	20.9
---------	----------	----------	--------	--	-----	------	-------	--	---	------

METER VOLUME = 124.56 ft3	ABS STACK PRES = 29.92 in. Hg
DRY GAS VOL.SCF = 118.18 ft3	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 2.52 ft3	STACK GAS VELO = 21.00 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007629 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW.ACFM = 27640.35 CFM
	DUCT GASFLOW.SCFM = 27747.24 CFM

ISOKINETIC VARIATION = 104.00 %

--dP-- --SQRT dP--
 =====

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

0 0
 0 0
 0 0
 .15 .3872983
 .17 .4127106
 .19 .4358899
 .19 .4358899
 .19 .4358899
 0 0
 0 0
 .01 .1
 .15 .3872983
 .17 .4127106
 .19 .4242641
 .19 .4358899
 .19 .4358899
 0 0
 0 0
 .01 .1
 .12 .3444102
 .18 .4242641
 .19 .4358899
 .19 .4358899
 .19 .4358899

DATE 123 MAY 84

SCRUBBER/103-IN/IMPACTOR

TEST 1 5

RUN 1 1

=====

.2700531

dP AVE = .0729287

--dP-- --dPFT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.22 .4690416
.26 .5099020
.22 .4690416
.18 .4242641
.15 .3872983
.06 .2449490
.07 .2645751
.12 .3464102
.22 .4690416
.31 .5567764
.37 .6082763
.46 .6792330
.2 .4472136
.2 .4472136
.18 .4242641
.15 .3872983
.13 .3605551
.08 .2828427
.04 .2
.08 .2828427
.14 .3741657
.21 .4582576
.29 .5385165
.36 .6

DATE : 24 MAY 84

SCRUBBER: 103-OUT/IMPACTOR

TEST : 5

RUN : 1

=====

.4262908

dP AVE = .1817238

IMPACTOR TESTING DATA SHEET

Date : 24 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 5	Box # : 3	I.D. # : 10-2	I.D. # : 3	I.D. # : 10-2	I.D. # : 8
Run # : 1	Delta Hg: 2.0014	Liner : S-STEEL	Diam : .2445	Coeffic: .78	Filtr #:
Location: LBNSV - Bldg 210	Cnst Fac: .9972	Length : 10			Leak rt : .009cfm
Source : 107 IN	Heat Set: -	Heater : -			g : 27in. H2O
Engineer: KIRK/FAN					H2O gain: 32.7ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 63F	Stack gas	length: 86in.
Barometer: 29.86in. Hg	dry wt : 26lb/lb-mol	width: 64in.
Stk Stati: -1.50in. H2O	Water vap	area-in2: 3304in.2
	proport: .023	area-ft2: 75.000226ft.2

Port 9 Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	798.14	70.91	101.27	51.36	.07	.27	2.5	0	20.9
2	240	897.00	70.91	101.27	51.36	.07	.27	2.5	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			70.91	101.27	51.36	.07	.27	2.5	0	20.9

METER VOLUME = 64.68 ft3	ABS STACK PRES = 29.75 in. Hg
DRY GAS VOL. SCF = 72.32 ft3	WET GAS MOLE WT = 26.79 lb/lb-mol
WATER VAPOR VOL = 1.54 ft3	STACK GAS VELO = 14.18 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003261 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 31911.59 CFM
	DUCT GASFLOW, SCFM = 31556.02 CFM

ISOKINETIC VARIATION = 123.17 %

IMPACTOR TESTING DATA SHEET

Date : 24 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 5	Box # : 5	I.D. # : 7-1	I.D. # : -	I.D. # : 7-1	I.D. # : - 3
Run # : 1	Delta Hg: 1.8088	Liner : SS 316	Diam : .243	Coeffic: .85	Filtr # : -
Location: LBNSV - Bldg 210	Crtt Fac: .9996	Length : 7			Leak rt : .004cfm
Source : 103-DUT	Heat Set: -	Heater : -			@ : 25in. H2O
Engineer: PDK/BEL					H2O gain: 51.1ml

ATMOSPHERE	ESTIMATE	DUCT AREA
ambient : 69F	Stack gas	length: 64in. dia.
Barometer: 29.86in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .00in. H2O	Water vap	area-in2: 3217in.2
	proport: .021	area-ft2: 22.34028ft.2

Port # Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	789.22	66.75	89.58	50.67	.18	.71	3	0	20.9
2	240	909.74	66.75	89.58	50.67	.18	.71	3	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			66.75	89.58	50.67	.18	.71	3	0	20.9

METER VOLUME = 121.47 ft3	ABS STACK PRES = 29.86 in. Hg
RY GAS VOL. SCF = 116.62 ft3	WET GAS MOLE WT = 28.77 lb/lb-mole
WATER VAPOR VOL = 2.41 ft3	STACK GAS VELO = 24.28 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003221 ft2
OL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 31855.72 CFM
	DUCT GASFLOW, SCFM = 31867.29 CFM

>> ISOKINETIC VARIATION = 105.84 %

IMPACTOR TESTING DATA SHEET

Date : 24 MAY 84
 Test # : 5
 Run # : 2
 Location: LBNSV - Bldg C10
 Source : 103-IN
 Engineer: KIRK/FAN

CONTROL
 Box # : 3
 Delta Hg: 2.0014
 Orif Fac: .9943
 Heat Set: -

PROBE
 I.D. # : 10-2
 Liner : STEEL
 Length : 10
 Heater : -

NOZZLE
 I.D. # : 3
 Diam : .044

FITST
 I.D. # : 10-2
 Coeffici: .78

IMPINGER
 I.D. # : 5
 Filter # : -
 Leak rt : .000cfm
 B : 27in. H2O
 H2O gain: .1

ATMOSPHERE
 Ambient : 58F
 Barometer: 29.86in. Hg
 Stk Stat: -1.50in. H2O

ESTIMATE
 Stack gas
 dry wt : 29lb/lb-mol
 Water vap
 proporti: .023

DUCT AREA
 length: 86in.
 width: 64in.
 area-in2: 5504in.2
 area-ft2: 38.22222ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head d ⁵ (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	887.29	69.42	100.46	49	.07	.27	2	0	20.9
2	240	948.06	69.42	100.46	49	.07	.27	2	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			69.42	100.46	49	.07	.27	2	0	20.9

METER VOLUME = 84.29 ft3
 DRY GAS VOL. SCF = 79.27 ft3
 WATER VAPOR VOL = .00 ft3
 MOIST CONTENT = .02
 MOL FRAC DRY GAS = .99

ABS STACK PRES = 29.75 in. Hg
 WET GAS MOLE WT = 29.80 lb/lb-mole
 STACK GAS VELO = 14.16 ft/sec
 NOZZLE AREA = .0003247 ft2
 DUCT GASFLOW, ACFM = 31893.18 CFM
 DUCT GASFLOW, SCFM = 31626.56 CFM

ISOKINETIC VARIATION = 103.00 %

IMPACTOR TESTING DATA SHEET

```

=====
Date : 24 MAY 84          CONTROL          PROBE          NOZZLE          PITOT          IMPINGER
Test # : 5              Box # : -          I.D. # : 7-1      I.D. # : 1/4 in.  I.D. # : 7-1      I.D. # : -
Run # : 2              Delta H@: 1.6808  Liner : SS 316    Diam : .245        Coeffici: .85      Filtr #: -
Location: LBNSY - Bldg 210  Crct Fac: .9996  Length : 7        Leak rt : .007cfm
Source : 103-DUT       Heat Set: -        Heater : -        @ : 25in. H2O
Engineer: PDW/BEL      H2O gain: 31.7ml
=====
  
```

```

=====
ATMOSPHERE          ESTIMATE          DUCT AREA
Ambient : 60F          Stack gas          length: 64in. dia.
Barometer: 29.86in. Hg  drv wt : 29lb/lb-mol  width: - in.
Stk Stat: .00in. H2O    Water vap          area-in2: 3217in.2
                        proprot: .021        area-ft2: 22.34025ft.2
=====
  
```

Port 1 Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Drift Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	911.89	66	93.43	53	.18	.77	10	0	20.9
2	156	989.41	66	93.43	53	.18	.77	10	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			66	93.43	53	.18	.77	10	0	20.9

```

=====
METER VOLUME = 77.49 ft3  ABS STACK PRES = 29.96 in. Hg
TRY GAS VOL.SCF = 73.89 ft3  WET GAS MOLE WT = 28.78 lb/lb-mole
WATER VAPOR VOL = 1.49 ft3  STACK GAS VELO = 24.19 ft/sec
MOIST CONTENT = .02        NOZZLE AREA = .0003274 ft2
MOL FRAC DRY GAS = .98     DUCT GASFLOW.ACFM = 31771.81 CFM
                        DUCT GASFLOW.SCFM = 31828.66 CFM
=====
  
```

--> ISOKINETIC VARIATION = 101.61 %

--dP-- --SRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.23 .4795832
.23 .4795832
.2 .4472136
.19 .4358899
.11 .3316625
0 0
0 0
.24 .4898579
.2 .4472136
.2 .4472136
.17 .4123106
.21 .4582576
.1 .3162278
.05 .2236068
.26 .5099020
.27 .5196152
.2 .4472136
.19 .4358899
.21 .4582576
.28 .5291503
.33 .5744563
.33 .5744563
.33 .5744563
.36 .6

DATE : 24 MAY 84

SCRUBBER: 104-IN

TEST : 6

RUN : 1

=====

.4246691

dP AVE = .1803438

SOURCE EMISSIONS TESTING DATA SHEET

Date : 125 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 6	Box # : 7	I.D. # : 2	I.D. # : 11	I.D. # : 2	I.D. # : 7
Run # : 1	Delta H ₀ : 2.002	Liner : GLASS	Diam : .374	Coeffici: .8	Filtr # : -
Location: LBNSY - Bldg 210	Cret Fac: .9963	Length : 10			Leak rt : .01cfm
Source : 104-IN	Heat Set: -	Heater : -			@ : 29in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 34.4ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 58F	Stack gas	length: 43in.
Barometer: 29.82in. Hg	dry wt : 29lb/lb-mol	width: 8in.
Stk Stat: -1.10in. H ₂ O	Water vap	area-in ² : 3698in. ²
	proport: .02	area-ft ² : 25.68056ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	.12	65	67	62	.23	4.75	12	0	20.9
2	4	4.77	65	82	68	.21	4.46	12	0	20.9
3	8	9.55	66	93	86	.19	4.11	10	0	20.9
4	12	14.12	65	99	72	.19	4.16	10	0	20.9
5	16	18.66	65	106	62	.10	2.22	6	0	20.9
6	20	22.33	65	105	53	.00	.00	0	0	20.9
7	24	22.70	65	97	57	.00	.00	0	0	20.9
8	28	22.70	65	88	60	.27	5.79	14	0	20.9
9	32	27.92	65	90	55	.21	4.52	11	0	20.9
10	36	32.64	65	101	47	.16	3.51	8	0	20.9
11	40	37.00	65	106	50	.16	3.55	8	0	20.9
12	44	41.24	65	109	51	.20	4.46	11	0	20.9
13	48	45.88	65	113	53	.09	2.02	5	0	20.9
14	52	49.46	65	111	52	.01	.22	2	0	20.9
15	56	51.03	65	102	50	.24	5.28	12	0	20.9
16	60	55.15	65	114	53	.17	3.82	9	0	20.9
17	64	59.83	65	98	59	.17	3.71	9	0	20.9
18	68	64.15	65	106	51	.16	3.55	9	0	20.9
19	72	68.46	65	112	53	.19	4.26	10	0	20.9
20	76	73.01	65	114	55	.25	5.62	13	0	20.9
21	80	78.20	65	121	55	.27	6.14	15	0	20.9
22	84	83.74	65	124	55	.32	7.32	17	0	20.9
23	88	89.64	65	129	56	.33	7.61	18	0	20.9
24	92	95.74	65	132	51	.25	5.79	13	0	20.9
25	96	101.29					.00			

AVERAGE	65.04167	104.9583	56.91667		.16	4.04		0	20.9
---------	----------	----------	----------	--	-----	------	--	---	------

METER VOLUME = 100.80 ft ³	ABS STACK PRES = 29.74 in. Hg
DRY GAS VOL. SCF = 94.78 ft ³	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.62 ft ³	STACK GAS VELO = 21.33 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007629 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW ACFM = 32276.82 CFM
	DUCT GASFLOW SCFM = 32262.43 CFM

ISOKINETIC VARIATION = 103.07 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 25 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 6	Box # : 6	I.D. # : 2	I.D. # : 6A-3	I.D. # : 2	I.D. # : 6
Run # : 2	Delta H@: 2.002	Liner : GLASS	Diam : .361	Coeffic: .8	Filtr #: -
Location: LBNSY - Bldg 210	Cnst Fac: .9963	Length : 10			Leak rt : .003cfm
Source : 104-IN	Heat Set: -	Heater : -			@ : 29in. H2O
Engineer: FAN/BEL					H2O gain: 34.3ol

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 58F	Stack gas	length: 86.5in.
Barometer: 29.82in. Hg	dry wt : 29lb/lb-mol	width: 42in.
Stk Stat: -1.10in. H2O	water vap	area-in2: 3633in.2
	proport: .02	area-ft2: 25.22917ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	102.17	64	77	44	.24	4.39	11	0	20.9
2	4	107.93	64	93	40	.24	4.52	11	0	20.9
3	8	111.69	64	104	47	.20	3.84	10	0	20.9
4	12	116.18	64	109	49	.20	3.88	10	0	20.9
5	16	120.63	64	111	51	.11	2.14	6	0	20.9
6	20	124.17	64	110	51	.00	.00	6	0	20.9
7	24	124.17	64	110	51	.00	.00	6	0	20.9
8	28	124.17	64	110	51	.27	5.24	14	0	20.9
9	32	129.05	64	102	56	.22	4.21	10	0	20.9
10	36	133.62	64	106	50	.20	3.85	10	0	20.9
11	40	138.10	64	111	53	.17	3.31	8	0	20.9
12	44	142.30	64	114	55	.21	4.10	10	0	20.9
13	48	.00	64	116	56	.11	2.16	6	0	20.9
14	52	150.52	64	114	54	.03	.59	3	0	20.9
15	56	152.73	64	107	50	.28	5.41	13	0	20.9
16	60	157.03	65	114	52	.08	1.56	5	0	20.9
17	64	161.71	63	98	58	.17	3.24	8	0	20.9
18	68	165.79	64	103	47	.16	3.07	8	0	20.9
19	72	169.82	64	108	50	.19	3.67	9	0	20.9
20	76	174.09	64	113	52	.26	5.07	12	0	20.9
21	80	179.17	64	118	54	.30	5.90	15	0	20.9
22	84	184.52	63	123	55	.33	6.56	17	0	20.9
23	88	190.23	63	125	56	.33	6.59	17	0	20.9
24	92	196.00	63	129	56	.34	6.83	17	0	20.9
25	96	201.79					.00			

AVERAGE	63.875	109.375	51.58333		.17	3.76	10.08333		0	20.9
---------	--------	---------	----------	--	-----	------	----------	--	---	------

METER VOLUME =	99.25 ft3	ABS STACK PRES =	29.74 in. Hg
DRY GAS VOL. SCF =	92.54 ft3	WET GAS MOLC WT =	26.80 lb/lb-mole
WATER VAPOR VOL =	1.61 ft3	STACK GAS VELO =	21.99 ft/sec
MOIST CONTENT =	.02	NOZZLE AREA =	.0007108 ft2
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	32687.69 CFM
		DUCT GASFLOW, SCFM =	32745.88 CFM

ISOKINETIC VARIATION = 104.55 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 26 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 6	Box # : 5	I.D. # : 2	I.D. # : 6M-3	I.D. # : 2	I.D. # : 5
Run # : 3	Delta H# : 2.002	Liner : GLASS	Diam : .366	Coeffici : .6	Filtr # : -
Location: LBNSY - Bldg 210	Crtt Fac: .9963	Length : 10			Leak rt : .002cfm
Source : 104-IN	Heat Set: -	Heater : -			@ : 26in. H2O
Engineer: PDW/FAN					H2O gain: 38.1ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 70F	Stack gas	length: 86.5in.
Barometer: 29.88in. Hg	dry wt : 29lb/lb-mol	width: 42in.
Stk Stat: -1.10in. H2O	Water vap	area-in2: 3633in.2
	proport: .017	area-ft2: 25.22917ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	202.17	68	70	45	.23	4.37	10	0	20.9
2	4	207.50	69	84	47	.24	4.68	10	0	20.9
3	8	211.71	69	91	51	.19	3.75	11	0	20.9
4	12	216.16	68	94	54	.19	3.79	9	0	20.9
5	16	220.40	69	97	55	.10	1.99	9	0	20.9
6	20	223.60	69	94	55	.00	.00	3	0	20.9
7	24	227.60	69	94	55	.00	.00	3	0	20.9
8	28	224.76	69	90	53	.22	4.33	10	0	20.9
9	32	228.47	67	87	58	.21	4.13	9	0	20.9
10	36	232.98	69	96	54	.20	3.98	9	0	20.9
11	40	237.51	68	100	55	.17	3.42	8	0	20.9
12	44	241.80	69	101	55	.21	4.22	9	0	20.9
13	48	246.30	69	102	57	.11	2.21	6	0	20.9
14	52	249.89	69	95	59	.06	1.19	4	0	20.9
15	56	252.42	69	90	54	.32	6.30	14	0	20.9
16	60	258.00	69	100	55	.08	1.60	5	0	20.9
17	64	261.08	68	85	61	.17	3.32	8	0	20.9
18	68	265.18	69	92	51	.18	3.56	8	0	20.9
19	72	269.41	69	97	54	.20	3.99	9	0	20.9
20	76	273.92	69	101	55	.27	5.42	12	0	20.9
21	80	279.30	69	105	57	.34	6.88	15	0	20.9
22	84	284.99	69	109	58	.40	8.15	15	0	20.9
23	88	290.62	70	114	56	.33	6.77	15	0	20.9
24	92	296.49	70	114	56	.34	6.98	15	0	20.9
25	96	302.47					.00			

AVERAGE	68.83333	95.91667	54.58333		.17	3.96	9.416667		0	20.9
---------	----------	----------	----------	--	-----	------	----------	--	---	------

METER VOLUME = 99.93 ft3	ABS STACK PRES = 29.80 in. Hg
DRY GAS VOL. SCF = 95.67 ft3	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.79 ft3	STACK GAS VELO = 22.38 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007306 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 33265.13 CFM
	DUCT GASFLOW, SCFM = 33078.50 CFM

ISOKINETIC VARIATION = 104.09 %

IMPACTOR TESTING DATA SHEET

Date : 26 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 7	Box # : -	I.D. # : 10-2	I.D. # : -	I.D. # : 10-2	I.D. # : -
Run # : 1	Delta H8: 2.002	Liner : 95316	Diam : .367	Coeffici: .75	Filter # : -
Location: LBNSY - Bldg 210	Crcd Fac: .9963	Length : 10			Leak rt : .001cfm
Source : 104-IN	Heat Set: -	Heater : -			Q : 25in. H2O
Engineer: POM/FAN					H2O gain: 61.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 74F	Stack gas	length: 86dia.
Barometer: 29.88in. Hg	dry wt : 29lb/lb-mole	width: 43in.
Stk Stat: -1.10in. H2O	Water vap	area-in2: 3698in.2
	proport: .017	area-ft2: 25.66056ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dp (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	303.41	72.7	109.3	55.89	.18	3.50	7	0	20.9
2	180	497.35	72.7	109.3	55.89	.18	3.50	7	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			72.7	109.3	55.89	.18	3.50	7	0	20.9

METER VOLUME = 193.22 ft3	ABS STACK PRES = 29.80 in. Hg
DRY GAS VOL. SCF = 180.44 ft3	WET GAS MOLE WT = 28.84 lb/lb-mole
WATER VAPOR VOL = 2.90 ft3	STACK GAS VELD = 22.28 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0007346 ft2
MOL FRAC DRY GAS = .99	DUCT GASFLOW. ACFM = 33807.88 CFM
	DUCT GASFLOW. SCFM = 33374.18 CFM

----->> ISOKINETIC VARIATION = 105.06 %

IMPACTOR TESTING DATA SHEET

Date : 26 MAY 84 CONTROL PROBE NOZZLE PITOT IMPINGER
Test # : 7 Box # : 5 I.D. # : 10-2 I.D. # : - I.D. # : 10-2 I.D. # : 7
Run # : 2 Delta H: 2.002 Liner : SS316 Dia : .37 Coeff: .78 Filt: -
Location: LBNSY - Bldg 210 Crt Fac: .9963 Length : 10 Leak rt : .016cfm
Source : 104-IN Heat Set: - Heater : - @ : 20in. H2O
Engineer: FAN/PDW H2O gain: 25.2ml

ATMOSPHERE ESTIMATE DUCT AREA
Ambient : 59F Stack gas length: 96in.
Barometer: 29.8in. Hg dry wt : 29lb/lb-mol width: 43in.
Stk Stat: -1.10in. H2O Water vap area-in2: 3698in.2
proport: .018 area-ft2: 25.66056ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	500.53	66.33	106.67	54.67	.18	3.64	5.7	0	20.9
2	60	569.09	66.33	106.67	54.67	.18	3.64	5.7	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			66.33	106.67	54.67	.18	3.64	5.7	0	20.9

METER VOLUME = 67.31 ft3 ABS STACK PRES = 29.72 in. Hg
RY GAS VOL.SCF = 63.00 ft3 WET GAS MOLE WT = 28.79 lb/lb-mole
WATER VAPOR VOL = 1.19 ft3 STACK GAS VELD = 22.19 ft/sec
MOIST CONTENT = .02 NOZZLE AREA = .0007467 ft2
VOL FRAC DRY GAS = .98 DUCT GASFLOW.ACFM = 33539.28 CFM
DUCT GASFLOW.SCFM = 33419.78 CFM

ISOKINETIC VARIATION = 108.12 %

--dP-- --50FT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.26 .5099020
.35 .5916080
.43 .6557439
.55 .7416198
.34 .5830952
.47 .6557439
.48 .6928203
.57 .7549834
.31 .5567764
.41 .6403124
.49 .7
.56 .7483315
.34 .5830952
.42 .6480741
.47 .6855655
.51 .7141428
.37 .6082763
.43 .6557439
.49 .7
.54 .7348469
.26 .5099020
.36 .6
.42 .6480741
.47 .6855655

DATE : 1 JUNE 84

SCRUBBER: 105-IN

TEST : 10

RUN : 1

.6501760

dP AVE = .4227288

-1P-- --32P* 1P--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.345 .5377170
.4 .6704555
.39 .6244998
.39 .6244998
.39 .6244998
.36 .6
.3 .6477226
.31 .5567764
.36 .6
.4 .6704555
.45 .6708204
.45 .6708204
.42 .6708203
.45 .6708203
.44 .6677250
.47 .6557439
.42 .64580741
.39 .6244998
.41 .6408104
.44 .6677250
.46 .6708204
.45 .6708204
.44 .6677250
.4 .6704555

DATE : 1 JUNE 64

SCRUBBER: 105-DU*

TEST : 10

RUN : 1

.6774030

CP AVE = .4062826

SOURCE EMISSIONS TESTING DATA SHEET

Date : 01 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 10	Box # : 5	I.D. # : 5	I.D. # : 6M-10	I.D. # : 5	I.D. # : 5
Run # : 1	Delta H ₂ : 1.8989	Liner : GLASS	Diam : .245	Coeffici: .82	Filter # : -
Location: LENS - Bldg 210	Crcd Fac: .9953	Length : 3			Leak rt : 0cfm
Source : 105-IN	Heat Set: -	Heater : -			@ : 25in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 25.4ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 65F	Stack gas	length: 108in.
Barometer: 29.85in. Hg	dry wt : 29lb/lb-mol	width: 31in.
Stk Stati: -3.90in. H ₂ O	Water vap	area-in ² : 3345in. ²
	proport: .015	area-ft ² : 23.25ft. ²

Port # Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head cP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	901.60	70	78	70	.27	1.04	4	0	20.9
2	4	904.00	70	84	43	.36	1.40	4	0	20.9
3	8	906.67	70	91	44	.44	1.73	5	0	20.9
4	12	909.61	69	99	47	.54	2.16	6	0	20.9
5	16	912.89	69	81	57	.73	1.27	4	0	20.9
6	20	915.56	68	81	49	.43	1.66	5	0	20.9
7	24	918.42	68	85	50	.49	1.91	5	0	20.9
8	28	921.56	69	87	52	.58	2.27	5	0	20.9
9	32	924.90	69	108	59	.72	1.30	4	0	20.9
10	36	927.59	68	110	52	.42	1.71	5	0	20.9
11	40	930.53	68	114	53	.47	1.93	5	0	20.9
12	44	933.69	68	118	54	.55	2.27	6	0	20.9
13	48	937.03	68	114	59	.73	1.36	4	0	20.9
14	52	939.72	68	113	54	.40	1.64	5	0	20.9
15	56	942.63	68	117	55	.45	1.86	5	0	20.9
16	60	945.76	68	120	52	.52	2.16	6	0	20.9
17	64	949.07	67	117	54	.31	1.28	4	0	20.9
18	68	951.75	67	114	49	.47	1.93	5	0	20.9
19	72	954.84	67	117	49	.52	2.15	6	0	20.9
20	76	958.15	67	118	50	.57	2.36	6	0	20.9
21	80	961.54	67	115	53	.29	1.20	4	0	20.9
22	84	964.28	68	112	50	.37	1.51	5	0	20.9
23	88	967.03	67	112	51	.41	1.68	5	0	20.9
24	92	970.05	67	114	51	.47	1.93	5	0	20.9
25	96	973.23					.00			

AVERAGE	68.125	104.9583	52.375		.42	1.74	4.916667		0	20.9
---------	--------	----------	--------	--	-----	------	----------	--	---	------

METER VOLUME =	71.29 ft ³	ABS STACK PRES =	29.57 in. Hg
DRY GAS VOL. SCF =	66.75 ft ³	WET GAS MOLE WT =	28.80 lb/lb-mole
WATER VAPOR VOL =	1.20 ft ³	STACK GAS VELO =	35.97 ft/sec
MOIST CONTENT =	.02	NOZZLE AREA =	.0003274 ft ²
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	49278.93 CFM
		DUCT GASFLOW, SCFM =	48696.14 CFM

----->> ISOKINETIC VARIATION = 101.46 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 31 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 10	Box # : 3	I.D. # : 1	I.D. # : 10.00	I.D. # : 1	I.D. # : 3
Run # : 1	Delta H ₂ O: 2.01	Liner : 6LASS	Diam : .244	Coeffic: .85	Filtr # : -
Location: LBNSY - Bldg 210	Crt Fac: .9979	Length : 6			Leak rt : .004cfm
Source : 105-OUT	Heat Set: -	Heater : -			@ : 22in. H ₂ O
Engineer: SUZ/BEL					H ₂ O gain: 29.1ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 66F	Stack gas	length: 66in. dia.
Barometer: 29.86in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .17in. H ₂ O	water vap	area-in ² : 3421.2in. ²
	proport: .02	area-ft ² : 23.75833ft. ²

Port 1 Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	368.99	67	78	69	.35	1.51	2.8	0	20.9
2	4	371.47	66	87	49	.39	1.72	2.8	0	20.9
3	8	374.19	66	96	50	.41	1.83	2.8	0	20.9
4	12	376.96	65	104	52	.40	1.82	2.8	0	20.9
5	16	379.77	65	110	52	.40	1.84	2.8	0	20.9
6	20	382.57	65	113	52	.37	1.71	2.8	0	20.9
7	24	385.31	65	115	52	.32	1.48	2.8	0	20.9
8	28	387.94	65	116	53	.30	1.39	2.8	0	20.9
9	32	390.39	65	118	53	.33	1.54	3	0	20.9
10	36	393.04	65	119	54	.37	1.73	3	0	20.9
11	40	395.82	65	120	53	.40	1.87	3.4	0	20.9
12	44	398.68	65	122	53	.43	2.02	3.6	0	20.9
13	48	401.63	67	106	64	.46	2.09	3.8	0	20.9
14	52	404.49	65	114	46	.49	2.27	4	0	20.9
15	56	407.00	65	119	47	.47	2.19	4	0	20.9
16	60	410.64	65	122	48	.44	2.07	4	0	20.9
17	64	413.62	64	124	48	.43	2.03	4	0	20.9
18	68	416.62	64	125	48	.38	1.80	4	0	20.9
19	72	419.54	64	125	49	.40	1.89	4	0	20.9
20	76	422.46	64	124	49	.43	2.03	3.8	0	20.9
21	80	425.42	64	124	49	.43	2.03	3.8	0	20.9
22	84	428.41	63	123	49	.44	2.08	3.8	0	20.9
23	88	431.39	64	123	49	.42	1.98	3.8	0	20.9
24	92	434.38	63	123	50	.37	1.75	3.8	0	20.9
25	96	437.26					.00			

AVERAGE	64.83333	114.5833	51.58333		.40	1.86	3.425		0	20.9
---------	----------	----------	----------	--	-----	------	-------	--	---	------

METER VOLUME = 68.12 ft ³	ABS STACK PRES = 29.87 in. Hg
DRY GAS VOL, SCF = 62.73 ft ³	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.37 ft ³	STACK GAS VELO = 35.89 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003247 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 50239.77 CFM
	DUCT GASFLOW, SCFM = 50462.66 CFM

>> ISOKINETIC VARIATION = 94.80 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 31 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 10	Box # : 4	I.D. # : E	I.D. # : BM-10	I.D. # : E	I.D. # : 4
Run # : 2	Delta H# : 1.8981	Liner : GLASS	Diam : .239	Coeffic : .82	Filtr # : -
Location: LBSY - Bldg 210	Crtt Fac: .9953	Length : 3			Leak rt : 0cfm
Source : 105-IN	Heat Set: -	Heater : -			θ : 25in. H2O
Engineer: FAN/KIRK					H2O gain: 25.7ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 60F	Stack gas	length: 108in.
Barometer: 29.86in. Hg	dry wt : 29lb/lb-mol	width: 3in.
Stk Stat: -3.90in. H2O	Water vap	area-in2: 3348in.2
	proport: .015	area-ft2: 23.25ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	2.53	66	83	62	.28	.99	3	0	20.9
2	4	5.51	66	86	39	.37	1.31	3	0	20.9
3	8	8.13	66	92	41	.43	1.54	3	0	20.9
4	12	10.94	66	97	43	.51	1.85	4	0	20.9
5	16	14.02	66	91	53	.32	1.15	3	0	20.9
6	20	16.53	66	95	44	.41	1.48	3	0	20.9
7	24	19.26	66	100	44	.49	1.78	4	0	20.9
8	28	22.27	65	103	46	.58	2.13	4	0	20.9
9	32	25.52	65	96	53	.32	1.16	3	0	20.9
10	36	28.19	65	100	46	.43	1.57	4	0	20.9
11	40	30.85	65	104	47	.49	1.80	4	0	20.9
12	44	33.92	65	105	48	.56	2.06	4	0	20.9
13	48	37.14	65	98	54	.32	1.16	3	0	20.9
14	52	39.71	65	100	48	.43	1.57	4	0	20.9
15	56	42.53	65	104	49	.48	1.76	4	0	20.9
16	60	45.53	65	106	50	.54	1.99	4	0	20.9
17	64	48.73	64	100	55	.32	1.17	3	0	20.9
18	68	51.29	64	101	50	.47	1.72	4	0	20.9
19	72	54.21	64	105	50	.53	1.95	4	0	20.9
20	76	57.38	64	107	51	.57	2.11	4	0	20.9
21	80	60.68	64	102	55	.28	1.03	3	0	20.9
22	84	63.12	64	100	51	.37	1.35	3	0	20.9
23	88	65.77	64	104	51	.42	1.55	3	0	20.9
24	92	68.64	64	106	52	.49	1.81	4	0	20.9
25	96	71.72					.00			

AVERAGE	64.95833	99.375	49.25		.43	1.58	3.541667		0	20.9
---------	----------	--------	-------	--	-----	------	----------	--	---	------

METER VOLUME =	68.86 ft3	ABS STACK PRES =	29.57 in. Hg
DRY GAS VOL. SCF =	65.10 ft3	WET GAS MOLE WT =	28.80 lb/lb-mole
WATER VAPOR VOL =	1.21 ft3	STACK GAS VELO =	36.03 ft/sec
MOIST CONTENT =	.02	NOZZLE AREA =	.0003115 ft2
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	49360.39 CFM
		DUCT GASFLOW, SCFM =	49070.87 CFM

----->> ISOKINETIC VARIATION = 103.19 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 31 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 10	Box # : 6	I.D. # : 1	I.D. # : 10	I.D. # : 1	I.D. # : 6
Run # : 2	Delta H ₂ O: 2.01	Liner : GLASS	Diam : .244	Coeffici: .85	Filter #: -
Location: LBNSY - Bldg 210	Crcd Fac: .9979	Length : 6			Leak rt : .003cfe
Source : 105-DUT	Heat Set: -	Heater : -			@ : 25in. H2O
Engineer: BEL/SUZ					H2O gain: 27.7ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Aspirant : 64F	Stack gas	length: 66in. dia.
Barometer: 29.86in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .00in. H2O	Water vap	area-in2: 3421.2in.2
	proport: .02	area-ft2: 23.75833ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	436.31	63	77	60	.35	1.52	2	0	20.9
2	4	436.31	63	95	60	.35	1.57	2	0	20.9
3	8	444.00	63	99	43	.41	1.85	2	0	20.9
4	12	447.00	63	105	45	.40	1.83	2	0	20.9
5	16	449.00	63	108	46	.39	1.79	2	0	20.9
6	20	452.00	63	111	47	.36	1.66	2	0	20.9
7	24	455.00	63	112	48	.29	1.34	2	0	20.9
8	28	457.00	62	113	48	.31	1.44	2	0	20.9
9	32	460.00	62	114	48	.33	1.54	2	0	20.9
10	36	462.00	62	115	48	.36	1.68	2	0	20.9
11	40	465.00	63	115	49	.41	1.91	2	0	20.9
12	44	468.00	63	116	49	.41	1.91	2.4	0	20.9
13	48	471.10	63	103	49	.46	2.10	2.5	0	20.9
14	52	474.00	63	109	44	.48	2.21	3	0	20.9
15	56	477.00	63	113	45	.45	2.09	3	0	20.9
16	60	480.00	62	116	46	.44	2.05	3	0	20.9
17	64	483.00	62	117	47	.41	1.92	3	0	20.9
18	68	486.00	62	117	47	.37	1.73	3	0	20.9
19	72	489.00	62	116	48	.40	1.87	3	0	20.9
20	76	492.00	62	117	48	.43	2.01	2.8	0	20.9
21	80	495.00	62	118	48	.43	2.02	2.8	0	20.9
22	84	498.00	62	118	49	.44	2.06	2.8	0	20.9
23	88	501.00	62	119	49	.41	1.92	2.8	0	20.9
24	92	504.00	62	117	49	.37	1.73	2.8	0	20.9
25	96	506.51					.00			

AVERAGE	62.5	110.8333	48.29167		.39	1.82	2.454167		0	20.9
---------	------	----------	----------	--	-----	------	----------	--	---	------

METER VOLUME = 68.06 ft3	ABS STACK PRES = 29.86 in. Hg
DRY GAS VOL, SCF = 63.08 ft3	WET GAS MOL WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.30 ft3	STACK GAS VELO = 35.50 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003247 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 49687.94 CFM
	DUCT GASFLOW, SCFM = 50110.28 CFM

----->> ISOKINETIC VARIATION = 96.00 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 31 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 10	Box # : 8	I.D. # : 5	I.D. # : 5H-10	I.D. # : 5	I.D. # : 8
Run # : 3	Delta H0: 1.8989	Liner : GLASS	Dia. : .24	Coeffici: .82	Filter # : -
Location: LBNSY - Bldg 210	Crt Fac: .9953	Length : 3			Leak rt : 0cfs
Source : 105-IN	Heat Set: -	Heater : -			@ : 25in. H2O
Engineer: KIRK/FAN					H2O gain: 25.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 59F	Stack gas	length: 108in.
Barometer: 29.88in. Hg	dry wt : 29lb/lb-mol	width: 3in.
Stk Stat: -3.90in. H2O	Water vap	area-in2: 3348in.2
	proporti: .015	area-ft2: 23.25ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	72.28	65	70	61	.32	1.12	3	0	20.9
2	4	74.78	65	77	44	.35	1.25	3	0	20.9
3	8	77.34	65	84	45	.46	1.66	3	0	20.9
4	12	80.21	65	92	47	.54	1.97	3	0	20.9
5	16	83.32	65	90	53	.29	1.06	3	0	20.9
6	20	85.72	65	94	47	.43	1.58	3	0	20.9
7	24	88.44	65	99	48	.49	1.81	3	0	20.9
8	28	91.46	65	103	49	.57	2.13	3	0	20.9
9	32	94.70	65	102	52	.31	1.15	3	0	20.9
10	36	97.17	65	101	49	.44	1.64	3	0	20.9
11	40	100.02	65	105	50	.50	1.87	3	0	20.9
12	44	103.08	65	108	50	.55	2.07	3	0	20.9
13	48	106.33	65	100	50	.27	1.00	3	0	20.9
14	52	108.70	65	102	50	.39	1.45	3	0	20.9
15	56	111.35	65	105	49	.46	1.72	3	0	20.9
16	60	114.33	65	109	51	.52	1.96	3	0	20.9
17	64	117.46	65	107	54	.28	1.05	3	0	20.9
18	68	119.90	65	105	50	.48	1.80	3	0	20.9
19	72	122.70	66	109	51	.52	1.96	3	0	20.9
20	76	125.96	66	111	52	.56	2.11	3	0	20.9
21	80	129.26	65	105	50	.31	1.16	3	0	20.9
22	84	131.82	66	106	50	.37	1.38	3	0	20.9
23	88	134.51	65	108	51	.42	1.58	3	0	20.9
24	92	137.57	65	111	52	.47	1.78	3	0	20.9
25	96	140.56					.00			

AVERAGE	65.125	100.125	50.20833		.42	1.59	3		0	20.9
---------	--------	---------	----------	--	-----	------	---	--	---	------

METER VOLUME = 67.96 ft3	ABS STACK PRES = 29.59 in. Hg
DRY GAS VOL. SCF = 64.20 ft3	WET GAS MOL. WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.20 ft3	STACK GAS VELO = 35.82 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003142 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 49064.22 CFM
	DUCT GASFLOW, SCFM = 48793.93 CFM

--->> ISOKINETIC VARIATION = 101.49 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 31 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 10	Box # : 3	I.D. # : 10	I.D. # : 10	I.D. # : 10	I.D. # : 3
Run # : 3	Delta H ₀ : 2.101	Liner : GLASS	Diam : .244	Coeffici: .85	Filtr #: -
Location: LBNSY - Bldg 210	Crc't Fac: .9979	Length : -			Leak rt : .018cfm
Source : 105-OUT	Heat Set: -	Heater : -			g : 25in. H2O
Engineer: BEL/SUZ					H2O gain: 27.3ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 58F	Stack gas	length: 66in. dia.
Barometer: 29.86in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .00in. H2O	Water vap	area-in2: 3421.2in.2
	proport: .02	area-ft2: 23.75833ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dF (in H2O)	Drifrice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	507.21	62	80	46	.47	2.15	2.5	0	20.9
2	4	510.00	62	91	44	.47	2.19	2.5	0	20.9
3	8	513.00	62	105	46	.45	2.15	2.5	0	20.9
4	12	516.00	62	114	50	.42	2.04	2.5	0	20.9
5	16	519.00	62	119	51	.40	1.96	2.5	0	20.9
6	20	522.00	62	122	53	.37	1.82	2.4	0	20.9
7	24	525.00	62	124	54	.41	2.03	2.5	0	20.9
8	28	528.00	62	126	55	.42	2.09	2.5	0	20.9
9	32	531.00	62	127	55	.44	2.19	2.5	0	20.9
10	36	534.00	62	127	56	.43	2.14	2.9	0	20.9
11	40	537.00	62	129	56	.41	2.05	2.8	0	20.9
12	44	540.00	62	130	56	.35	1.75	2.8	0	20.9
13	48	543.00	62	109	56	.34	1.64	2.5	0	20.9
14	52	545.00	62	115	53	.39	1.88	2.8	0	20.9
15	56	548.00	62	120	54	.38	1.87	2.8	0	20.9
16	60	551.00	62	124	55	.39	1.91	2.8	0	20.9
17	64	554.00	62	126	51	.38	1.89	2.8	0	20.9
18	68	557.00	62	127	51	.36	1.79	2.8	0	20.9
19	72	560.00	62	127	52	.29	1.44	2.8	0	20.9
20	76	563.00	62	126	51	.29	1.44	2.8	0	20.9
21	80	565.00	62	125	51	.31	1.54	2.5	0	20.9
22	84	568.00	62	125	52	.32	1.56	2.5	0	20.9
23	88	570.00	62	125	52	.40	1.98	2.5	0	20.9
24	92	573.00	62	127	53	.43	2.14	3	0	20.9
25	96	576.38					.00			

AVERAGE	62	119.5833	52.20833		.39	1.90	2.641667		0	20.9
---------	----	----------	----------	--	-----	------	----------	--	---	------

METER VOLUME =	69.03 ft3	ABS STACK PRES =	29.86 in. Hg
DRY GAS VOL, SCF =	63.03 ft3	WET GAS MOLE WT =	28.80 lb/lb-mole
WATER VAPOR VOL =	1.29 ft3	STACK GAS VELO =	35.17 ft/sec
ADIST CONTENT =	.02	NOZZLE AREA =	.0003247 ft2
MOL FRAC DRY GAS =	.98	DUCT GASFLOW, ACFM =	49234.34 CFM
		DUCT GASFLOW, SCFM =	49700.39 CFM

-->> ISOKINETIC VARIATION = 96.71 %

--GP-- --GP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.26 .5099020
.35 .5916080
.47 .6557439
.55 .7416198
.34 .5230952
.45 .6557439
.48 .6908203
.57 .7549834
.31 .5567764
.41 .6407124
.49 .7
.56 .7487315
.34 .5230952
.42 .6480741
.47 .6855655
.51 .7141428
.37 .6062763
.47 .6557439
.49 .7
.54 .7348469
.26 .5099020
.36 .6
.42 .6480741
.47 .6855655

DATE 11 JUNE 84

SCPIBEEF1105-IN/IMPACTOR

TEST 1 11

RUN 1 1

.6501760

GP AVE = .4227288

-dF-- --SERT dF--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.345	.5677670
.4	.6324555
.39	.6244998
.39	.6244998
.39	.6244998
.36	.6
.3	.5477225
.31	.5567764
.36	.6
.4	.6324555
.45	.6706204
.45	.6706204
.46	.6706204
.48	.6928203
.44	.6677250
.47	.6557439
.42	.6460741
.39	.6244998
.41	.6403124
.42	.6677250
.46	.6706204
.45	.6706204
.44	.6677250
.4	.6324555

DATE : 1 JUNE 64

SCRUBBER: 105-GUT/IMPACTOR

TEST : 11

RUN : 1

=====

.6374030

GP AVE = .4062826

IMPACTOR TESTING DATA SHEET

Date : JUNE 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 11	Box # : 5	I.D. # : -8	I.D. # : -	I.D. # : -8	I.D. # : 6
Run # : 1	Delta H ₀ : 1.8961	Liner : S STEEL	Dia : .247	Coeffic: .75	Filtr #:
Location: LBNSY - Bldg 210	Crcr Fac: .9953	Length : 3			Leak rt : .003cfm
Source : 105-IN	Heat Set: -	Heater : -			θ : 25in. H ₂ O
Engineer: FAN/KIRK					H ₂ O gain: 41.8ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 75F	Stack gas	length: 103in.
Barometer: 29.89in. Hg	dry wt : 29lb/lb-mol	width: 3in.
Stk Stats: -3.90in. H ₂ O	Water vap	area-in ² : 3348in. ²
	proport: .015	area-ft ² : 23.25ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	141.30	69.1	99.7	52.6	.42	1.46	4	0	20.9
2	90	205.16	69.1	99.7	52.6	.42	1.46	4	0	20.9
3	180	269.37	69.1	99.7	52.6	.42	1.46	4	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			69.1	99.7	52.6	.42	1.46	4	0	20.9

METER VOLUME = 127.47 ft ³	ABS STACK PRES = 29.60 in. Hg
DRY GAS VOL. SCF = 120.51 ft ³	WET GAS MOL WT = 28.82 lb/lb-mole
WATER VAPOR VOL = 1.97 ft ³	STACK GAS VELOCITY = 72.84 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003328 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 45075.32 CFM
	DUCT GASFLOW, SCFM = 44505.27 CFM

ISOKINETIC VARIATION = 105.17 %

MPACTOR TESTING DATA SHEET

Date : JUNE 84
 Test # : 11
 Run # : 1
 Location: LDNSV - Bldg 210
 Source : 105-DUT
 Engineer: BEL/SUZ

CONTROL
 Box # : 3
 Delta H₀: 2.125
 Crct Fac: .994
 Heat Set: -

PROCES
 I.D. # : -
 Liner : -
 Length : -
 Heater : -

NOZZLE
 I.D. # : 2
 Diam : .2475

FITOT
 I.D. # : -
 Coeffici: .85

IMPINGER
 I.D. # : -
 Filter #: -
 Leak rt : .012cfm
 θ : 25in. H₂O
 H₂O gain: 50.5ml

ATMOSPHERE
 Ambient : 78F
 Barometer: 29.69in. Hg
 Stk Stat: .00in. H₂O

ESTIMATE
 Stack gas
 dry wt : 29lb/lb-mol
 Water vap
 proports: .02

DUCT AREA
 length: 66in. dia.
 width: - in.
 area-in²: 3421.2in.²
 area-ft²: 23.75533ft.²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	577.17	64.22	114.33	54.44	.41	2.12	4.1	0	20.9
2	170	707.90	64.22	114.33	54.44	.41	2.12	4.1	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			64.22	114.33	54.44	.41	2.12	4.1	0	20.9

METER VOLUME = 129.84 ft³
 DRY GAS VOL, SCF = 119.92 ft³
 WATER VAPOR VOL = 2.38 ft³
 MOIST CONTENT = .02
 VOL FRAC DRY GAS = .98

ABS STACK PRES = 29.89 in. Hg
 WET GAS MOLE WT = 28.80 lb/lb-mole
 STACK GAS VELO = 76.13 ft/sec
 NOZZLE AREA = .0003341 ft²
 DUCT GASFLOW, ACFM = 50577.63 CFM
 DUCT GASFLOW, SCFM = 50291.25 CFM

ISCKINETIC VARIATION = 98.62 %

IMPACTOR TESTING DATA SHEET

Date : 11 JUNE 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 11	Box # : 5	I.D. # : -8	I.D. # : 2	I.D. # : -8	I.D. # : 8
Run # : 2	Delta H ₀ : 1.8088	Liner : S STEEL	Dia : .247	Coeffic: .75	Filtr #:
Location: LBNV - Bldg 210	Crit Fac: .9996	Length : 3			Leak rt : .014cfm
Source : 105-IN	Heat Set: -	Heater : -			@ : 25in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 41.4ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 60F	Stack gas	length: 108in.
Barometer: 29.89in. Hg	dry wt : 29lb/lb-mole	width: 3lin.
Stk Stat: -3.90in. H ₂ O	Water vap	area-in ² : 3348in. ²
	properties: .015	area-ft ² : 23.25ft. ²

Port 1 Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head @ (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	270.13	65.45	108.3	50	.42	1.42	-	0	20.9
2	90	333.31	65.45	108.3	50	.42	1.42	-	0	20.9
3	180	396.51	65.45	108.3	50	.42	1.42	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9

AVERAGE			65.45	108.3	50	.42	1.42	ERROR	0	20.9

METER VOLUME = 126.63 ft ³	ABS STACK PRES = 29.60 in. Hg
DRY GAS VOL. SCF = 117.90 ft ³	WET GAS MOLE WT = 29.82 lb/lb-mole
WATER VAPOR VOL = 1.95 ft ³	STACK GAS VELO = 32.72 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003328 ft ²
NOL FPAC DRY GAS = .98	DUCT GASFLOW. ACFM = 44919.58 CFM
	DUCT GASFLOW. SCFM = 44659.57 CFM

-----> ISOKINETIC VARIATION = 102.53 %

IMPACTOR TESTING DATA SHEET

```

=====
Date      : 1 JUNE 84      CONTROL      PROBE      NOZZLE      PITOT      IMPINGER
Test #    : 11           Box # : 3      I.D. # : -      I.D. # : -      I.D. # : -      I.D. # : 5
Run #     : 2           Delta H0: 2.135  Liner : S STEEL  Dia  : .246  Coeffici: .85    Filt # : -
Location: LBSNY - Bldg 210  Cret Fac: .994  Length : -      Leak rt : .003cfm
Source    : 105-DUT      Heat Set: -      Heater : -      @ : 25in. H2O
Engineer: BEL/SUZ      H2O gain: 50.1ml

```

```

=====
ATMOSPHERE      ESTIMATE      DUCT AREA
Ambient : 59F      Stack gas      length: 66in. dia.
Barometer: 29.89in. Hg  dry wt : 29lb/lb-mol  width: - in.
Stk Stati: .00in. H2O  Water vap      area-in2: 3421.2in.2
                        proports: .02  area-ft2: 23.75833ft.2
=====

```

Port # Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Drifce Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	708.46	63	114.55	55	.41	2.07	5.1	0	20.9
2	90	774.41	63	114.55	55	.41	2.07	5.1	0	20.9
3	180	841.14	63	114.55	55	.41	2.07	5.1	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			63	114.55	55	.41	2.07	5.1	0	20.9

```

=====
METER VOLUME = 131.89 ft3  ABS STACK PRES = 29.89 in. Hg
RY GAS VOL. SCF = 121.65 ft3  WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 2.36 ft3  STACK GAS VELO = 36.09 ft/sec
MOIST CONTENT = .02  NOZZLE AREA = .0003301 ft2
MOL FRAC DRY GAS = .98  DUCT GASFLOW.ACFM = 50518.74 CFM
                        DUCT GASFLOW.SCFM = 50950.58 CFM
=====

```

--> ISOKINETIC VARIATION = 95.54 %

--dP-- --SRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.44 .6633250
.53 .7280110
.65 .8062258
.84 .9165151
.98 .9899495
1.2 1.095445
1.42 .6480741
.59 .7691146
.75 .8660254
.86 .9273618
.93 .9643651
1.1 1.048809
.41 .6403124
.56 .7483315
.7 .8366600
.91 .9539392
.96 .9797059
1.1 1.048809
.33 .5744563
.41 .6403124
.6 .7745967
.65 .8062258
.73 .8544004
.78 .8831761

DATE 115 MAY 84

SCRUBBER: 106-IN/IMPACTOR

TEST : 1

RUN : 1

=====

.8401349

dP AVE = .7058266

-dP-- --SQRT dP--
=====

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.5 .7071068
.52 .7211103
.39 .6244998
.3 .5477226
.2 .4472136
.07 .2645751
.12 .3464102
.24 .4898979
.38 .6164414
.5 .7071068
.46 .6528203
.43 .6557439
.14 .3741657
.16 .4
.17 .4123106
.18 .4242641
.12 .3464102
.1 .3162278
.32 .5656854
.54 .7348469
.65 .8062258
.69 .8706624
.63 .7937254
.53 .7280110

DATE :15 MAY 84

SCRUBBER:106-OUT/IMPACTOR

TEST : 1

RUN : 1

=====

.5647160

dP AVE = .3189042

IMPACTOR TESTING DATA SHEET

```

=====
Date : 15 MAY 84          CONTROL      PROBE      NOZZLE      PITOT      IMPINGER
Test # : 1                Box # : 2      I.D. # : 8      I.D. # : 4      I.D. # : 8      I.D. # : -
Run # : 1                Delta H8: 1.2546  Liner : S STEEL  Diam : .246      Coeffici: .75      Filter #: -
Location: LBNSY - Bldg 210  Crct Fac: 1.0254  Length : 3      Leak rt : .016cfm
Source : 106-IN          Heat Set: -      Heater : -      @ : 10in. H2O
Engineer: KIRK/FAN      H2O gain: 23.1ml
    
```

```

=====
ATMOSPHERE      ESTIMATE      DUCT AREA
Ambient : 58F      Stack gas      length: 33in.
Barometer: 29.9in. Hg  dry wt : 29lb/lb-mol  width: 75in.
Stk Stat: -3.30in. H2O  Water vap      area-in2: 2475in.2
                        proports: .02      area-ft2: 17.1875ft.2
    
```

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	566.80	58.29	93.43	55.86	.71	1.59	10	0	20.9
2	30	623.90	58.29	93.43	55.86	.71	1.59	10	0	20.9
3	60	633.55	58.29	93.43	55.86	.71	1.59	10	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9

AVERAGE			58.29	93.43	55.86	.71	1.59	10	0	20.9
=====										

```

=====
METER VOLUME = 66.39 ft3      ABS STACK PRES = 29.66 in. Hg
DRY GAS VOL. SCF = 63.52 ft3  WET GAS MOLE WT = 28.81 lb/lb-mole
WATER VAPOR VOL = 1.09 ft3    STACK GAS VELO = 41.95 ft/sec
MOIST CONTENT = .02           NOZZLE AREA = .0003301 ft2
MOL FRAC DRY GAS = .98       DUCT GASFLOW. ACFM = 42527.42 CFM
                                DUCT GASFLOW. SCFM = 42954.40 CFM
    
```

```

----->> ISO KINETIC VARIATION = 126.42 %
=====
    
```

IMPACTOR TESTING DATA SHEET

```

=====
Date : 15 MAY 84          CONTROL          PROBE          NOZZLE          PITOT          IMPINGER
Test # : 1              Box # : 5          I.D. # : -        I.D. # : -        I.D. # : -        I.D. # : 5
Run # : 1              Delta H0: 1.7484    Liner : -         Dia : .247        Coeffic: .85      Filt # : -
Location: LBNSY - Bldg 210 Crt Fac: .9996    Length : 7
Source : 106-OUT       Heat Set: -        Heater : -
Engineer: GUA/BEL
                                Leak rt : .01cfm
                                @ : 15in. H2O
                                H2O gain: 15.7ml
    
```

```

=====
ATMOSPHERE          ESTIMATE          DUCT AREA
Ambient : 58F
Barometer: 29.9in. Hg
Stk Stat: .17in. H2O
Stack gas
dry wt : 29lb/lb-mol
Water vap
proporti: .02
length: 66in. dia.
width: - in.
area-in2: 3421.2in.2
area-ft2: 23.75833ft.2
    
```

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	674.92	59.5	98.33	55.58	.32	1.33	2.4	0	20.9
2	60	718.20	59.5	98.33	55.58	.32	1.33	2.4	0	20.9
3	-	-	-	-	-	-	-	-	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			59.5	98.33	55.58	.32	1.33	2.4	0	20.9

```

=====
METER VOLUME = 43.26 ft3    ABS STACK PRES = 29.91 in. Hg
RY GAS VOL.SCF = 41.00 ft3    WETGAS MOLC WT = 28.81 lb/lb-mole
WATER VAPOR VOL = .74 ft3    STACK GAS VELO = 31.86 ft/sec
MOIST CONTENT = .02          NOZZLE AREA = .0003328 ft2
VOL FRAC DRY GAS = .98       DUCT GASFLOW.ACFM = 44450.10 CFM
                                DUCT GASFLOW.SCFM = 45369.29 CFM
    
```

>> ISOKINETIC VARIATION = 107.61 %

--dP-- --SGT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.63	.7937254
.72	.8485281
.71	.8426150
.64	.8
.57	.7549834
.35	.5916080
.08	.3528427
.13	.3464102
.18	.4242641
.18	.4242641
.23	.4795832
.14	.3741657
.51	.7141428
.56	.7483315
.48	.6928203
.4	.6324555
.26	.5099020
.1	.3162278
.25	.5
.41	.6403124
.65	.8062258
.53	.9110434
.91	.9536392
.97	.9848858

DATE : 15 MAY 84

SCRUBBER: 106-OUT/IMPACTOR

TEST : 1

RUN : 2

=====

.6405572

dP AVE = .4103084

IMPACTOR TESTING DATA SHEET

```

=====
Date   :15 MAY 84      CONTROL      PROBE      NOZZLE      PITOT      IMPINER
Test # :      1      Box # : 5      I.D. # : 7-1      I.D. # : -      I.D. # : 7-1      I.D. # :      5
Run #  :      2      Delta H# : 1.8981      Liner : -      Dia# : .245      Coeff: .85      Filt # :      -
Location:LBNSY - Bldg 210      Crct Fac: .9953      Length : 7      Leak rt :      .016cfm
Source :106-DUT      Heat Set: -      Heater : -      @ :      15in. H2O
Engineer:GUA/BEL      H2O gain:      13.5ml
  
```

```

=====
ATMOSPHERE      ESTIMATE      DUCT AREA
Ambient :      62F      Stack gas      length:      66in. dia.
Barometer:      29.9in. Hg      dry wt :      29lb/lb-mol      width:      - in.
Stk Stat:      .15in. H2O      Water vap      area-in2:      3421.2in.2
      proportion:      .02      area-ft2:      23.75933ft.2
  
```

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	719.66	58.08	97.08	56.25	.41	1.79	2.9	0	20.9
2	30	741.00	58.08	97.08	56.25	.41	1.79	2.9	0	20.9
3	60	764.33	58.08	97.08	56.25	.41	1.79	2.9	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			58.08	97.08	56.25	.41	1.79	2.9	0	20.9

```

=====
METER VOLUME = 44.46 ft3      ABS STACK PRES = 29.91 in. Hg
WRY GAS VOL.SCF = 42.28 ft3      WETGAS MOLC WT = 28.85 lb/lb-mole
WATER VAPOR VOL = .64 ft3      STACK GAS VELO = 36.06 ft/sec
MOIST CONTENT = .01      NOZZLE AREA = .0003274 ft2
VOL FRAC DRY GAS = .99      DUCT GASFLOW.ACFM= 50676.92 CFM
      DUCT GASFLOW.SCFM= 51631.78 CFM
  
```

-->> ISOXINETIC VARIATION = 99.10 %

--dP-- --SDRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.43 .6557439
.58 .7615773
.67 .8185353
.8 .8944272
.95 .9746794
1.2 1.095445
.45 .6708204
.67 .8185353
.79 .8888194
.96 .9797959
1.1 1.048809
1.2 1.095445
.46 .6782730
.63 .7937254
.85 .9219544
.97 .9643651
1 1
.93 .9643651
.32 .5656854
.44 .5633250
.62 .7874008
.77 .8774964
.83 .9110474
.72 .8485281

DATE : 15 MAY 84

SCRUBBER: 106-IN/IMPACTOR

TEST : 1

RUN : 3

.8616148

dP AVE = .7423801

IMPACTOR TESTING DATA SHEET

Date : 15 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 1	Box # : 2	I.D. # : 8	I.D. # : -	I.D. # : 8	I.D. # : -
Run # : 3	Delta H ₂ : 1.2548	Liner : S STEEL	Diam : .245	Coeffic: .75	Filtr #: -
Location: LBNSY - Bldg 210	Crc ₂ Fac: 1.025	Length : 3			Leak rt : .002cm
Source : 106-IN	Heat Set: -	Heater : -			@ : 26in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain: 13.7ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 62F	Stack gas	length: 33in.
Barometer: 29.9in. Hg	dry wt : 29lb/lb-mol	width: 7in.
Stk Stat: -3.10in. H ₂ O	Water vap	area-in ² : 247in. ²
	proport: .014	area-ft ² : 17.1675ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	716.25	63.33	90.5	55.17	.74	1.64	9	0	20.9
2	30	744.44	63.33	90.5	55.17	.74	1.64	9	0	20.9
3	60	772.07	63.33	90.5	55.17	.74	1.64	9	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			63.33	90.5	55.17	.74	1.64	9	0	20.9

METER VOLUME = 57.22 ft ³	ABS STACK PRES = 29.67 in. Hg
RY GAS VOL.SCF = 55.04 ft ³	METGAS MOLC WT = 28.87 lb/lb-mole
WATER VAPOR VOL = .64 ft ³	STACK GAS VELO = 43.17 ft/sec
MOIST CONTENT = .01	NOZZLE AREA = .0003274 ft ²
VOL FRAC DRY GAS = .99	DUCT GASFLOW.ACFM= 43985.09 CFM
	DUCT GASFLOW.SCFM= 44009.76 CFM

>> ISOKINETIC VARIATION = 109.49 %

IMPACTOR TESTING DATA SHEET

```

=====
Date : 15 MAY 84          CONTROL          PROBE          NOZZLE          PITOT          IMPINGER
Test # : 1                Box # : 5          I.D. # : -          I.D. # : -          I.D. # : -          I.D. # : 5
Run # : 3                Delta H2: 1.2961    Liner : -          Diam : .243          Coeffic: .85          Filtr #: -
Location: LBNSY - Bldg 210  Cret Fac: .9953    Length : 7          Heater : -          Leak rt : .01cfm
Source : 106-DUT          Heat Set: -          H2O gain: 14ml
Engineer: QUA/BEL
    
```

```

=====
ATMOSPHERE          ESTIMATE          DUCT AREA
Ambient : 63F          Stack gas          length: 66in. dia.
Barometer: 29.9in. Hg  dry wt : 29lb/lb-mol  width: - in.
Stk Stat: .15in. H2O  Water vap          area-in2: 3421.2in.2
                      propert: .014          area-ft2: 23.75833ft.2
    
```

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Impinger Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Grifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	764.92	58.83	102.3	52.57	.41	1.77	2.9	0	20.9
2	30	788.30	58.83	102.3	52.57	.41	1.77	2.9	0	20.9
3	60	811.95	58.83	102.3	52.57	.41	1.77	2.9	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			58.83	102.3	52.57	.41	1.77	2.9	0	20.9

```

=====
METER VOLUME      = 46.81 ft3    ABS STACK PRES   = 29.91 in. Hg
DRY GAS VOL.SCF   = 44.10 ft3    WETGAS MOLE WT  = 29.84 lb/lb-mole
WATER VAPOR VOL   = .66 ft3     STACK GAS VELO   = 36.09 ft/sec
MOIST CONTENT     = .02          NOZZLE AREA      = .0003221 ft2
MOL FRAC DRY GAS  = .99          DUCT GASFLOW.ACFM= 50671.82 CFM
                      DUCT GASFLOW.SCFM= 51551.96 CFM
    
```

```

----->> ISOINETIC VARIATION = 105.23 %
=====
    
```


--dP-- --SQRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

=====

.37 .6082763

.41 .6403124

.59 .7681146

.66 .8124038

.84 .9165151

.78 .8831761

.46 .6782330

.61 .7810250

.85 .9219544

.9 .9486633

1 1

1.1 1.048809

.45 .6708204

.62 .7574008

.74 .8602325

.97 .9848858

1.1 1.045609

1.2 1.095445

.44 .6633250

.47 .6855655

.66 .8124038

.8 .8944272

1 1

1.2 1.095445

=====

.8585943

dP AVE = .7371841

--dP-- --SQRT dP--

INITIAL VELOCITY TRAVERSE DATA AND CALCULATIONS

.54	.7348469
.63	.7937254
.64	.8
.6	.7745967
.48	.6928203
.32	.5656854
.06	.2828427
.11	.3316625
.11	.3316625
.14	.3741657
.15	.3672953
.15	.3672993
.42	.6460741
.47	.6855655
.46	.6782330
.4	.6324555
.27	.5196152
.18	.4242641
.21	.4582576
.32	.5656854
.5	.7071068
.60	.8306624
.81	.9
.7	.8366600

DATE : 30 MAY 64

SCRUBBER: 106-OUT/IMPACTOR

TEST : 9

RUN : 1

.5976327

dP AVE = .3571648

Date	TEST	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
129 MAY 64	B	Box # : 5	I.D. # : 5	I.D. # : 6M-10	I.D. # : 5	I.D. # : 5
Run # : 1	Delta H ₀ : 2.135	Liner : GLASS	Diam : .242	Coeffic: .82	Filtr #:	-
Location: LBNSY - Bldg 210	Crt Fac: .994	Length : 3			Leak rt :	.007cfm
Source : 106-IN	Heat Set: -	Heater : -			@ :	28in. H ₂ O
Engineer: KIRK/FAN					H ₂ O gain:	43.7ml

ATMOSPHERE		ESTIMATE		DUCT AREA	
Ambient :	66F	Stack gas		length:	33in.
Barometer:	29.79in. Hg	dry wt :	29lb/lb-mol	width:	75in.
Vak Stat:	-2.80in. H2O	Water vap		area-in2:	2475in.2
		proport:	.015	area-ft2:	17.1875ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Griffice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	968.40	66	74	66	.30	1.23	3	0	20.9
2	4	970.74	64	78	48	.38	1.58	4	0	20.9
3	8	973.27	64	85	48	.47	1.96	4	0	20.9
4	12	976.08	64	92	50	.64	2.73	6	0	20.9
5	16	979.35	64	102	51	.70	3.04	6	0	20.9
6	20	982.89	64	111	53	.71	3.14	7	0	20.9
7	24	986.46	65	104	59	.32	1.39	4	0	20.9
8	28	988.95	65	109	54	.49	2.15	5	0	20.9
9	32	991.83	65	114	55	.67	2.97	7	0	20.9
10	36	995.22	70	114	57	.62	2.72	6	0	20.9
11	40	998.82	63	117	58	.75	3.35	7	0	20.9
12	44	1002.39	64	120	59	.82	3.68	8	0	20.9
13	48	1006.28	63	105	62	.37	1.62	5	0	20.9
14	52	1009.00	65	106	57	.64	2.80	6	0	20.9
15	56	1011.71	68	106	57	.75	3.26	7	0	20.9
16	60	1015.30	68	115	58	.84	3.71	8	0	20.9
17	64	1019.24	66	119	61	.91	4.06	9	0	20.9
18	68	1023.36	64	124	63	.97	4.38	10	0	20.9
19	72	1027.63	63	123	64	.37	1.67	4	0	20.9
20	76	1030.34	68	116	60	.44	1.95	5	0	20.9
21	80	1033.24	70	116	60	.52	2.29	5	0	20.9
22	84	1036.33	70	118	60	.66	2.92	7	0	20.9
23	88	1039.81	68	117	60	.82	3.63	8	0	20.9
24	92	1043.71	66	121	61	.89	3.98	9	0	20.9
25	96	1047.73					.00			
AVERAGE			65.79167	108.5833	57.54167	.61	2.76	6.25	0	20.9

[illegible]

->> ISOKINETIC VARIATION = 95.10 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 09 MAY 84 CONTROL PROBE NOZZLE PITOT IMPINGER
 Test # : 8 Box # : 8 I.D. # : - I.D. # : 6-7 I.D. # : - I.D. # : 8
 Run # : 1 Delta Hg: 1.8066 Liner : ELASE Dia : .0485 Coeffici: .85 Filter # : -
 Location: LBNV - Bldg 210 Crt Fac: .9996 Length : - Leak rt : .001cfa
 Source : 106-DUT Heat Set: - Heater : - @ : 17in. H2O
 Engineer: SUZ/BEL H2O gain: 29.7ml

ATMOSPHERE ESTIMATE DUCT AREA
 Ambient : 63F Stack gas length: 66in. dia.
 Barometer: 29.79in. Hg dry wt : 29lb/lb-mol width: - in.
 Stk Stat: .17in. H2O Water vap area-in2: 3421.2in.2
 proports: .02 area-ft2: 23.75633ft.2

Port & Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head cP (in H2O)	Griffice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	568.34	67	74	65	.53	2.20	3.8	0	20.9
2	4	571.61	67	77	41	.60	2.51	4.2	0	20.9
3	8	575.10	67	87	44	.55	2.32	4.2	0	20.9
4	12	576.59	67	88	45	.52	2.22	3.8	0	20.9
5	16	591.99	67	94	46	.47	2.03	3.8	0	20.9
6	20	585.28	67	99	46	.26	1.13	2.4	0	20.9
7	24	597.98	66	101	47	.08	.35	<2	0	20.9
8	28	589.56	66	98	47	.09	.39	<2	0	20.9
9	32	591.00	66	96	46	.10	.43	<2	0	20.9
10	36	591.00	66	96	47	.07	.30	<2	0	20.9
11	40	597.96	66	94	47	.08	.35	<2	0	20.9
12	44	595.40	66	93	48	.07	.30	<2	0	20.9
13	48	597.06	66	85	60	.42	1.78	3.6	0	20.9
14	52	600.20	66	92	47	.47	2.02	4	0	20.9
15	56	603.44	66	95	46	.41	1.77	3.4	0	20.9
16	60	606.49	66	99	49	.31	1.35	3	0	20.9
17	64	609.30	66	99	49	.07	.30	<2	0	20.9
18	68	610.88	66	96	49	.09	.39	<2	0	20.9
19	72	612.37	66	98	46	.21	.91	2.4	0	20.9
20	76	614.70	65	102	49	.40	1.76	3.4	0	20.9
21	80	617.60	65	107	51	.54	2.39	4.2	0	20.9
22	84	621.02	66	111	50	.62	3.03	4.8	0	20.9
23	88	624.99	66	111	51	.75	3.34	5	0	20.9
24	92	629.20	66	110	52	.69	3.06	4.8	0	20.9
25	96	633.22					.00			

AVERAGE 66.16667 95.75 48.91667 .31 1.53 3.8 0 20.9

METER VOLUME = 64.85 ft3 ABS STACK PRES = 29.80 in. Hg
 DRY GAS VOL.SCF = 61.55 ft3 WET GAS MOLC WT = 28.80 lb/lb-mole
 WATER VAPOR VOL = 1.40 ft3 STACK GAS VELO = 31.56 ft/sec
 MOIST CONTENT = .02 NOZZLE AREA = .0003368 ft2
 MOL FRAC DRY GAS = .98 DUCT GASFLOW.ACFM = 44181.00 CFM
 DUCT GASFLOW.SCFM = 44160.84 CFM

ISOKINETIC VARIATION = 102.46 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 29 MAY 84
 Test # : 8
 Run # : 2
 Location: LBNSV - Bldg 310
 Source : 106-IN
 Engineer: KIRK/FAN

CONTROL
 ID # : 3
 Delta H₀: 2.1179
 Orif. Fac: .9926
 Heat Set: -

PROBE
 ID # : 5
 Liner : GLASS
 Length : 3
 Heater : -

NOZZLE
 I.D. # : 6M-10
 Dia : .042

PITOT
 I.D. # : 5
 Coeff: .92

IMPINGER
 I.D. # : 8
 Filter # : -
 Leak rt : .005-cfm
 @ : 29in. H₂O
 H₂O gain: 99.4ml

ATMOSPHERE
 Ambient : 61F
 Barometer: 29.79in. Hg
 Stk Stat: -2.80in. H₂O

ESTIMATE
 Stack gas
 dry wt : 2915/lb-mol
 Water vap
 proports: .015

DUCT AREA
 length: 33in.
 width: 75in.
 area-in²: 2475in.²
 area-ft²: 17.1875ft.²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta P (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	48.79	64	70	62	.33	1.74	2	0	20.9
2	4	51.48	64	79	50	.37	1.53	2	0	20.9
3	8	53.73	64	87	51	.45	1.89	2	0	20.9
4	12	56.10	64	95	53	.62	2.64	3	0	20.9
5	16	59.72	64	101	54	.68	2.93	3	0	20.9
6	20	62.82	64	106	55	.71	3.08	3	0	20.9
7	24	66.49	64	107	56	.37	1.61	2	0	20.9
8	28	69.07	64	103	55	.47	2.03	3	0	20.9
9	32	71.82	64	106	55	.63	2.74	3	0	20.9
10	36	75.24	64	111	55	.75	3.29	4	0	20.9
11	40	78.95	64	114	56	.83	3.66	4	0	20.9
12	44	82.86	64	117	56	.90	3.99	4	0	20.9
13	48	86.95	63	111	56	.42	1.84	3	0	20.9
14	52	89.83	63	111	56	.61	2.67	3	0	20.9
15	56	93.14	63	114	56	.73	3.32	4	0	20.9
16	60	96.37	63	118	57	.84	3.70	4	0	20.9
17	64	100.84	66	119	57	.90	3.98	4	0	20.9
18	68	104.96	64	121	57	.95	4.24	5	0	20.9
19	72	109.19	64	109	57	.34	1.48	2	0	20.9
20	76	111.82	63	110	52	.43	1.88	3	0	20.9
21	80	114.63	66	112	52	.53	2.32	3	0	20.9
22	84	117.71	66	114	52	.66	2.90	4	0	20.9
23	88	121.16	63	118	51	.75	3.32	4	0	20.9
24	92	124.89	64	120	51	.86	3.83	4	0	20.9
25	96	128.90					.00			

AVERAGE 64.66667 107.2083 54.75 .62 2.76 3.25 0 20.9

WET VOLUME = 79.91 ft³
 DRY GAS VOL. SCF = 74.54 ft³
 WATER VAPOR VOL = 4.68 ft³
 MOIST CONTENT = .02
 DL FRAC DRY GAS = .98

ABS STACK PRES = 29.58 in. Hg
 WET GAS MOLE WT = 28.80 lb/lb-mole
 STACK GAS VELO = 43.17 ft/sec
 NOZZLE AREA = .0003194 ft²
 DUCT GAS FLOW ACFM = 43717.81 CFM
 DUCT GAS FLOW SCFM = 43501.58 CFM

ISOKINETIC VARIATION = 96.10 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 29 MAY 84 CONTROL PROBE NOZZLE PITOT IMPINGER
 Test # : 2 Box # : 6 I.D. # : - I.D. # : I.D. # : - I.D. # : 7
 Run # : C Delta H: 1.8086 Liner : GLASS Dia : .247 Coeff: .85 Filter # : -
 Location: LBNSY - Bldg 210 Crst Fac: .9996 Length : - Leak rt : .002cfm
 Source : 106-DUT Heat Set: - Heater : - @ : 17in. H2O
 Engineer: SUZ/BEL H2O gain: 26.3ml

ATMOSPHERE	ESTIMATE	DUST AREA
Ambient : 62F	Stack gas	length: 66in. dia.
Barometer: 29.91in. Hg	dry wt : 29lb/lb-mol	width: - in.
Stk Stati: 17in. H2O	Water vap	area-in2: 3421.2in.2
	proporti: .02	area-ft2: 23.75633ft.2

Port # Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Orifice Delta H (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	633.95	65	69	63	.57	2.14	4	0	20.9
2	4	636.99	66	75	41	.57	2.32	4	0	20.9
3	8	640.32	65	84	57	.57	2.36	4	0	20.9
4	12	643.92	65	91	47	.52	2.18	4	0	20.9
5	16	647.24	65	94	48	.42	1.77	3	0	20.9
6	20	650.34	65	96	49	.24	1.02	3	0	20.9
7	24	652.84	65	96	49	.07	.30	2	0	20.9
8	28	654.36	65	92	50	.08	.34	2	0	20.9
9	32	655.67	65	91	50	.09	.36	2	0	20.9
10	36	657.10	65	92	48	.11	.46	2	0	20.9
11	40	658.68	65	92	48	.09	.38	2	0	20.9
12	44	660.16	65	92	49	.06	.25	3	0	20.9
13	48	661.35	65	85	58	.45	1.87	3	0	20.9
14	52	664.45	65	97	46	.49	2.08	4	0	20.9
15	56	667.79	65	101	46	.42	1.80	3	0	20.9
16	60	670.83	65	103	50	.28	1.20	3	0	20.9
17	64	673.39	65	99	50	.16	.68	2	0	20.9
18	68	675.42	65	98	51	.07	.30	2	0	20.9
19	72	676.77	56	96	50	.21	.91	3	0	20.9
20	76	678.93	65	99	49	.37	1.58	3	0	20.9
21	80	681.84	65	103	50	.51	2.19	4	0	20.9
22	84	685.26	65	106	51	.64	2.76	5	0	20.9
23	88	689.11	65	109	52	.74	3.21	5	0	20.9
24	92	693.10	65	111	52	.72	3.13	5	0	20.9
25	96	697.12					.00			

AVERAGE 64.66667 94.625 50.16667 .31 1.48 3.208333 0 20.9

METER VOLUME = 63.24 ft3	ABS STACK PRES = 29.82 in. Hg
DRY GAS VOL. SCF = 60.18 ft3	WET GAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.33 ft3	STACK GAS VELO = 31.53 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003328 ft2
MOLE FRAC DRY GAS = .98	DUCT GAS FLOW, ACFM = 44133.35 CFM
	DUCT GAS FLOW, SCFM = 44269.01 CFM

ISOKINETIC VARIATION = 101.17 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 25 MAY 84
 Test # : 8
 Run # : 7
 Location: LBNSV - Bldg 210
 Source : 106-IN
 Engineer: KIRK/FAN

CONTROL
 ID # : 3
 Delta Hg: 2.1179
 Orct Fac: .9926
 Heat Set: -

PROBE
 ID # : 5
 Liner : GLASS
 Length : 3
 Heater : -

NOZZLE
 I.D. # : 6M-10
 Diam : .24

PITOT
 I.D. # : 5
 Coeff: .82

IMPINGER
 I.D. # : 6
 Filter # : -
 Leaf # : .005cfs
 @ : 29in. H2O
 H2O gain: 39.7ml

ATMOSPHERE
 Ambient : 60F
 Barostat: 29.84in. Hg
 Stl Stat: -3.40in. H2O

ESTIMATE
 Stack gas
 dry wt : 29lb/lb-mol
 Water vap
 proports: .015

DUCT AREA
 length: 33in.
 width: 75in.
 area-in2: 2475in.2
 area-ft2: 17.1875ft.2

Port S Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Water Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Griffice Delta P (in H2O)	Sample Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	129.64	64	77	63	.25	.99	2	0	20.9
2	4	131.93	64	92	64	.34	1.37	2	0	20.9
3	8	134.18	64	92	56	.46	1.69	3	0	20.9
4	12	136.90	64	99	56	.59	2.45	3	0	20.9
5	16	140.04	64	104	53	.65	2.72	3	0	20.9
6	20	143.44	64	109	51	.73	3.09	4	0	20.9
7	24	146.97	64	102	54	.75	1.46	2	0	20.9
8	28	149.49	64	105	49	.80	2.06	3	0	20.9
9	32	152.33	64	110	49	.86	2.80	4	0	20.9
10	36	155.80	64	114	54	.80	3.41	4	0	20.9
11	40	159.33	64	117	51	.85	3.64	4	0	20.9
12	44	163.24	64	120	53	.90	3.38	5	0	20.9
13	48	167.26	63	111	56	.74	1.45	2	0	20.9
14	52	169.85	64	110	52	.61	2.58	3	0	20.9
15	56	173.02	64	114	52	.87	3.71	4	0	20.9
16	60	176.84	64	119	54	.93	4.00	5	0	20.9
17	64	180.91	64	120	56	.95	4.09	5	0	20.9
18	68	185.10	64	122	58	.97	4.19	5	0	20.9
19	72	189.29	63	115	59	.75	1.50	3	0	20.9
20	76	191.85	65	113	55	.50	2.12	3	0	20.9
21	80	194.80	66	115	51	.55	2.34	3	0	20.9
22	84	197.96	66	116	48	.67	2.86	4	0	20.9
23	88	201.41	65	119	49	.83	3.56	4	0	20.9
24	92	205.21	64	120	50	.93	4.01	5	0	20.9
25	96	209.32					.00			

AVERAGE 64.16667 109.1567 53.675 1 .63 2.76 3.541667 1 0 20.9

STEAM VOLUME = 79.09 ft3
 DRY GAS VOL. SCF = 73.64 ft3
 WATER VAPOR VOL = 1.87 ft3
 MOIST CONTENT = .02
 LIQ FRAC DRY GAS = .98

ABS STACK PRES = 29.66 in. Hg
 METGAS MOLE WT = 28.80 lb/lb-mole
 STACK GAS VELO = 43.50 ft/sec
 NOZZLE AREA = .0003142 ft2
 DUCT GASFLOW, ACFM = 44033.67 CFM
 DUCT GASFLOW, SCFM = 43995.58 CFM

ISOKINETIC VARIATION = 95.44 %

SOURCE EMISSIONS TESTING DATA SHEET

Date : 05 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 8	Box # : 5	I.D. # : 0	I.D. # : 0	I.D. # : 0	I.D. # : 3
Run # : 3	Delta H ₀ : 1.8088	Liner : SLASS	Diam : .246	Coeff: .85	Filter # : -
Location: LBNBY - Bldg 210	Crit Fac: .9996	Length : 0			Leak rt : .001cfm
Source : 106-D	Heat Set: -	Heater : -			Q : 17in. H ₂ O
Engineer: SUZ/BEL					H ₂ O gain: 29.1ml

ATMOSPHERE	ESTIMATE	DUCT AREA
Ambient : 61F	Stack gas	length: 66in. (dia)
Barometer: 29.84in. Hg	dry wt : 29lb/lb-mol	width: in.
Stk Stati: .17in. H ₂ O	Water vap	area-in ² : 3421.2in.2
	proport: .02	area-ft ² : 23.75633ft.2

Port # Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Water Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	698.92	65	72	61	.53	2.11	3	0	20.9
2	4	702.14	65	85	47	.65	2.66	4	0	20.9
3	8	705.77	65	94	49	.55	2.28	3	0	20.9
4	12	709.20	65	99	51	.52	2.18	3	0	20.9
5	16	712.44	66	101	52	.42	1.74	3	0	20.9
6	20	715.60	66	102	52	.28	1.18	2	0	20.9
7	24	718.20	66	100	52	.08	.34	2	0	20.9
8	28	719.67	66	97	51	.07	.29	2	0	20.9
9	32	721.01	65	95	51	.08	.33	2	0	20.9
10	36	722.56	65	96	50	.09	.39	0	0	20.9
11	40	723.89	65	97	50	.08	.33	2	0	20.9
12	44	725.30	65	97	50	.07	.29	2	0	20.9
13	48	726.62	65	89	59	.42	1.73	3	0	20.9
14	52	729.62	65	98	50	.51	2.13	3	0	20.9
15	56	732.89	65	103	51	.47	1.98	3	0	20.9
16	60	735.90	65	105	52	.33	1.40	3	0	20.9
17	64	738.94	65	106	52	.22	.93	2	0	20.9
18	68	741.25	65	105	52	.09	.39	2	0	20.9
19	72	742.85	65	102	53	.24	1.01	3	0	20.9
20	76	745.15	65	105	52	.39	1.63	3	0	20.9
21	80	748.12	65	110	52	.52	2.22	3	0	20.9
22	84	751.78	65	112	53	.65	2.79	4	0	20.9
23	88	755.24	65	113	55	.74	3.18	4	0	20.9
24	92	759.33	65	115	55	.70	3.02	4	0	20.9
25	96	763.45					.00			

AVERAGE	65.16667	99.875	52.16667		.72	1.52	2.706333		0	20.9
---------	----------	--------	----------	--	-----	------	----------	--	---	------

METER VOLUME = 64.51 ft ³	ABS STACK PRES = 29.85 in. Hg
DRY GAS VOL. SCF = 60.82 ft ³	METGAS MOLE WT = 28.80 lb/lb-mole
WATER VAPOR VOL = 1.77 ft ³	STACK GAS VELO = 32.14 ft/sec
WET CONTENT = .02	NOZZLE AREA = .0003301 ft ²
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 44998.88 CFM
	DUCT GASFLOW, SCFM = 45129.56 CFM

>> ISOkinetic VARIATION = 101.20 %

MPACTOR TESTING DATA SHEET

Date : 30 MAY 84
 Test # : 9
 Run # : 1
 Location: LBNSY - Bldg 210
 Source : 106-IN
 Engineer: FAN/KIRK

CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Box # : 3	I.D. # : -8	I.D. # : -	I.D. # : -8	I.D. # : - 8
Delta H ₀ : 2.1179	Liner : S STEEL	Diam : .245	Coeffic: .75	Filtr # : -
Crc ₀ Fac: .9926	Length : 3			Leak rt : .005cfm
Heat Set: -	Heater : -			@ : 25in. H ₂ O
				H ₂ O gain: 59.6ml

ATMOSPHERE	ESTIMATE	DUCT AREA
ambient : 67F	Stack gas	length: 33in.
barometer: 29.29in. Hg	dry wt : 29lb/lb-mol	width: 75in.
Stk Stat: -2.80in. H ₂ O	Water vap	area-in ² : 2475in. ²
	proport: .015	area-ft ² : 17.1875ft. ²

Port & Point Number	Sample Time (min)	Gas Meter (ft ³)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H ₂ O)	Orifice Delta H (in H ₂ O)	Sample Vacuum (in Hg)	CO ₂ (%)	O ₂ (%)
1	0	210.09	72.1	113.1	54.4	.74	2.80	5	0	20.9
2	90	299.30	72.1	113.1	54.4	.74	2.80	5	0	20.9
3	180	366.54	72.1	113.1	54.4	.74	2.80	5	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			72.1	113.1	54.4	.74	2.80	5	0	20.9

METER VOLUME = 157.26 ft ³	ABS STACK PRES = 29.06 in. Hg
RY GAS VOL. SCF = 142.79 ft ³	WETGAS MOLE WT = 28.79 lb/lb-mole
WATER VAPOR VOL = 2.81 ft ³	STACK GAS VELO = 43.88 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003274 ft ²
OL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 44389.89 CFM
	DUCT GASFLOW, SCFM = 42917.19 CFM

ISOKINETIC VARIATION = 97.32 %

IMPACTOR TESTING DATA SHEET

Date : 30 MAY 84	CONTROL	PROBE	NOZZLE	PITOT	IMPINGER
Test # : 9	Box # : 5	I.D. # : -	I.D. # : -	I.D. # : -	I.D. # : 4
Run # : 1	Delta H8: 1.8089	Liner : -	Diam : .247	Coeffic: .85	Filtr # : -
Location: LBNSY - Bldg 210	Crot Fac: .9996	Length : 7			Leak rt : - cfm
Source : 106-OUT	Heat Set: -	Heater : -			θ : - in. H2O
Engineer: SUZ/BEL					H2O gain: 55.7ml

ATMOSPHERE		ESTIMATE	DUCT AREA
Ambient : 69F		Stack gas	length: 66in. dia.
Barometer: 29.79in. Hg		dry wt : 29lb/lb-mol	width: - in.
Stk Stat: .17in. H2O		Water vap	area-in2: 3421.2in.2
		proport: .02	area-ft2: 23.75833ft.2

Port 1 Point Number	Sample Time (min)	Gas Meter (ft3)	Stack Temp (F)	Meter Inlet Temp (F)	Impinger Temp (F)	Velocity Head dP (in H2O)	Grifice Delta H (in H2O)	Saddle Vacuum (in Hg)	CO2 (%)	O2 (%)
1	0	765.14	66	103.3	56.7	.36	1.53	4	0	20.9
2	90	833.58	66	103.3	56.7	.36	1.53	4	0	20.9
3	180	901.00	66	103.3	56.7	.36	1.53	4	0	20.9
4	-	-	-	-	-	-	-	-	0	20.9
5	-	-	-	-	-	-	-	-	0	20.9
AVERAGE			66	103.3	56.7	.36	1.53	4	0	20.9

METER VOLUME = 135.80 ft3	ABS STACK PRES = 29.80 in. Hg
DRY GAS VOL. SCF = 127.17 ft3	NET GAS MOLE WT = 28.78 lb/lb-mole
WATER VAPOR VOL = 2.62 ft3	STACK GAS VELO = 34.00 ft/sec
MOIST CONTENT = .02	NOZZLE AREA = .0003328 ft2
MOL FRAC DRY GAS = .98	DUCT GASFLOW, ACFM = 47498.91 CFM
	DUCT GASFLOW, SCFM = 47492.18 CFM


>> ISCKINETIC VARIATION = 106.28 %

APPENDIX C
TRUESDAIL REPORT

REPORT

TRUESDAIL LABORATORIES, INC.

CHEMISTS - MICROBIOLOGISTS - ENGINEERS
RESEARCH - DEVELOPMENT - TESTING



14201 FRANKLIN AVE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6200
AREA CODE 213 • 225-1564
CABLE: TRUELABS

CLIENT U.S. Navy NEESA
NCBC, Code 111C
Port Hueneme, California 93043
Attention: Mr. Bill Powers

DATE June 26, 1984

RECEIVED May 22-31, 1984

SAMPLE Blank solutions

LABORATORY NO. 01014- (14,15,
68,69)

P.O. No. N62583/84M P935

INVESTIGATION

As requested

RESULTS

<u>Parameter</u>	<u>0.1N KOH Blank</u>	<u>DI #1</u>	<u>DI #2</u>	<u>DI #3</u>
Chloride (Cl)	<0.1	<0.1	<0.1	<0.1
Cyanide (CN)	<0.01	<0.01	<0.01	<0.01
Carbonate (CO ₃)	830.	<1.	<1.	<1.
Chromium (VI)	<0.1	<0.05	<0.05	<0.05
Chromium (III)	<0.1	<0.02	<0.02	<0.02
Fluoride (F)	<0.1	<0.01	<0.01	<0.01
Phosphate (P)	1.3	<0.1	<0.1	<0.1
Sulfate (SO ₄)	<1.	<1.	<1.	<1.
Silver (Ag)	<0.01	<0.01	<0.01	<0.01
Aluminum (Al)	0.34	<0.3	---	---
Cadmium (Cd)	<0.004	<0.004	<0.004	<0.004
Copper (Cu)	<0.02	<0.02	<0.02	0.03
Potassium (K)	3300	<0.03	0.18	<0.03
Sodium (Na)	3.2	<0.04	<0.04	<0.04
Nickel (Ni)	0.26	<0.02	<0.02	<0.02

(Results expressed in milligrams per Liter)

Misc. samples for scrubber #102, Bldg 210 LongBeach Naval Ship Yard

(Results expressed in milligrams per Liter)

<u>Sample</u>	<u>Chloride</u>	<u>Sulfate</u>	<u>Aluminum</u>	<u>Sodium</u>	<u>Nickel</u>	<u>pH</u>	<u>Boiling</u>	<u>2</u>
Bottle 1	0.7	<1	0.22	1.11	0.043	---	---	
Bottle 2	<0.1	<1	0.18	1.54	0.029	---	---	
Bottle 3	1.5	<1	0.36	1.46	<0.02	---	---	
Bottle 4	<0.1	<1	0.18	1.48	0.039	---	---	
Bottle 5	1.4	<1	0.27	1.07	0.036	---	---	
Bottle 6	1.5	<1	0.22	1.15	0.158	---	---	
Bottle 7	0.9	<1	0.27	1.23	<0.02	---	---	
Bottle 8	1.2	<1	<0.2	0.31	<0.02	---	---	
Petri Dish A(stage 1)---	---	---	290ug	289ug	38.9ug	---	---	
Petri Dish B(stage 5)---	---	---	802ug	80.9ug	229ug	---	---	
Tank 4	---	---	----	146,000	---	13.1	---	
Tank 33	23,800	108,000	----	----	129,000	4.4	94.	
Tank 50	---	---	----	421,000	---	13.5	---	
Scrubber H ₂ O	---	---	----	----	---	7.21	---	

*The initial boiling point was 94°C. Shortly after the low boiling species boiled away, the boiling point stabilized at 100°C.

Misc. samples for scrubber #103, Bldg 210, LongBeach Naval Ship Yard

Sample	Chromium VI, ppm	Chromium III, ppm	Sulfate, ppm	pH, units
Scrubber Water 5/24)	<0.05	0.39	<1	7.5
Bottle 9	0.30	<0.02	<1	---
Bottle 10	<0.05	0.03	<1	---
Bottle 11	0.07	0.13	<1	---
Bottle 12	<0.05	0.04	<1	---
Bottle 13	1.05	<0.02	<1	---
Bottle 14	<0.05	0.02	<1	---
Bottle 15	0.25	0.10	<1	---
Bottle 16	<0.05	0.04	<1	---
Tank 41	94,600	13,200	---	<1
Tank 42	112,200	6,100	---	<1
Tank 43	106,000	7,600	---	<1
Tank 44	10,040	2,400	---	<1

Filters-Run No. 1 Test 5 (Results expressed in micrograms per filter)

Inlet, Stage 1	4.0	7.2	---	---
Inlet, Stage 2	0.8	<1.	---	---
Inlet, Stage 3	<1.ug	48.2	---	---
Inlet, Stage 5	20.8	3.3	---	---
Inlet, Backup	<1.	5.2	---	---
Outlet, Stage 1	<1.	1.3	---	---
Outlet, Stage 2	<1.	<1.	---	---
Outlet, Stage 3	<1.	<1.	---	---
Outlet, Stage 5	<1.	3.5	---	---
Outlet, Backup	<1.	4.3	---	---

Sample	Chromium VI, ug	Chromium III, ug
Filters-Run 2, Test 5		
Inlet, Stage 1	<1	9.9
Inlet, Stage 2	<1	4.7
Inlet, Stage 3	20.0	15.9
Inlet, Stage 5	17.6	3.2
Inlet, Backup	<1.	3.0
Outlet, Stage 1	<1.	1.3
Outlet, Stage 2	<1.	<1.
Outlet, Stage 3	<1.	<1.
Outlet, Stage 5	<1.	1.7
Outlet, Backup	<1.	<1.

Misc. Samples for scrubber #104, Bldg 210, LongBeach Naval Ship yard

<u>Sample</u>	<u>Chloride</u> <u>ppm</u>	<u>Chromium VI</u> <u>ppm</u>	<u>Chromium III</u> <u>ppm</u>	<u>Sulfate</u> <u>ppm</u>	<u>Potassium</u> <u>ppm</u>	<u>Fluoride</u> <u>ppm</u>	<u>pH</u> <u>Units</u>
Bottle 18	57.4	1.98	0.32	<1	420	---	-
Bottle 19	53.9	<0.05	4.44	<1	649	---	---
Bottle 20	69.3	<0.05	3.42	<1	529	---	
Wash Water	3.7	<0.05	0.14	<1	0.15	---	
Tank 3 (HCl)	283,000	----	----	--	----	---	<1
Tank 6 (HCl)	255,000	----	----	--	----	---	<1
Tank 5 (H ₂ SO ₄)	---	----	----	12,400	----	---	
Tank 15	---	----	----	--	----	0.20	2.4

Total Phenols

Tank 15 9,640

Misc. samples for scrubber #105, Bldg 210, LongBeach Naval Ship Yard
(Results expressed in milligrams per Liter)

<u>Sample</u>	<u>Cl</u>	<u>CN</u>	<u>CO₃</u>	<u>Ag</u>	<u>Cd</u>	<u>Cu</u>	<u>K</u>	<u>Na</u>	<u>Ni</u>	<u>pH,units</u>
Bottle 27	1.6	0.097	832	<0.01	<0.004	0.01	688	2.47	0.17	---
Bottle 28	0.4	0.39	1030	<0.01	0.020	0.12	1106	4.83	0.04	---
Bottle 29	0.9	0.082	895	<0.01	<0.004	<0.01	522	1.07	0.09	---
Bottle 30	1.2	0.38	1090	<0.01	<0.004	0.01	783	1.34	0.07	---
Bottle 31	<0.1	0.15	823	<0.01	<0.004	0.01	603	1.52	0.08	---
Bottle 32	3.0	0.29	1110	<0.01	<0.004	0.05	654	2.25	0.10	---
Scrubber H ₂ O	56.8	<0.01	----	----	0.73	0.06	---	----	0.89	7.55
Tank 1	----	62,500	382,000	----	25,100	----	---	137,000	----	13.6
Tank 11	----	62,500	331,000	----	27,200	----	---	158,800	----	13.4
Tank 20	114,000	-----	-----	----	-----	----	---	-----	67,300	<1.
Tank 21	----	53,800	233,000	449	-----	-----	91,100	-----	----	13.5
Tank 22	----	9,630	6,450	354	-----	-----	68,800	-----	----	13.4
Tank 29	----	39,000	-----	----	-----	49,100	884	-----	----	>13.6

Filters, Test 11 (Results expressed in micrograms per filter pad)


1 Inlet	<100	0.2	---	<0.6	<0.3	1.9	---	---	<1	---
Run 1 Outlet	600	<0.1	---	<0.6	5.8	5.9	---	---	11.4	---
Run 2 Inlet	340	<0.1	---	<0.6	1.6	<1.	---	---	6.3	---
2 Outlet	<100	0.8	---	1.7	1.2	4.6	---	---	4.2	---

Misc. samples for scrubber #106, Bldg 210, LongBeach Naval Ship Yard
(Results expressed in milligrams per Liter)

Sample	Chloride	Chromium VI	Chromium III	Fluoride	Phosphate	Potassium	l	s
Bottle 21	<0.1	<0.05	<0.02	<0.05	----	70,400	---	---
Bottle 22	0.4	<0.05	0.07	<0.05	----	768	---	---
Bottle 23	0.8	<0.05	0.07	<0.05	----	654	---	---
Bottle 24	1.5	<0.05	0.02	<0.05	----	1,370	---	---
Bottle 25	0.2	<0.05	<0.02	<0.05	----	541	---	---
Bottle 26	0.4	<0.05	0.03	<0.05	----	719	---	---
Scrubber Water	---	0.095	0.12	----	----	---	7.4	---
Bank 16	66.2	0.09	0.01	----	----	8.02	<1	---
Bank 28A	<500	5630.	2670.	----	----	8.64	---	---
Bank 28B	<500	7100.	8900.	----	----	2.37	<1.	---
Bank 35	<500	6130.	1970.	----	----	580.	<1	---
Bank 36	<500	9950.	120.	----	----	2.77	---	---
Bank 45	<500	398	4700.	----	----	577.	<1.	---
Bank 47	<500	2900.	5000.	----	----	13.2	<1.	---
Bank 19	-----	----	----	----	272,000	----	---	8

Impactor Filter (Results expressed in micrograms per filter pad)

Test 9 Run) In	4200	<1	<1	---	---	---	---
Out	300	<1	<1	---	---	---	---



Respectfully submitted,

TRUESDAIL LABORATORIES, INC.

Richard D. Reid

Richard D. Reid
Chief Water Chemist

☐ INCOMING		☒ OUTGOING		DATE 20 Jul 1984	
PERSON CALLING SUSAN J. SUZUKI		PHONE NUMBER x4797		ACTIVITY NEESA	
PERSON CALLED RICHARD REID		PHONE NUMBER (213) 225-1564		ACTIVITY TRUESDALE LABORATORIES INC	
GENERAL SUBJECT CHEMICAL ANALYSIS of LBNSY PLATING SHOP SAMPLES					
TOPICS DISCUSSED AND ACTION TAKEN					

The lab report from Truesdale Laboratories INC. indicated chemical concentrations in units of both milligrams per liter and parts per million (ppm). I called Dick Reid to get an explanation of these units and how to equate them.

PPM is the concentration by volume. In order to convert ppm to mg/L one must take into ^{account} the density of the chemical being identified. An easy way to do this is to multiply the concentration (in ppm) by the molecular weight of the chemical and divide by 18 (the molecular weight of water).

Assuming perfect gas, ... $\frac{f_{\text{sample}}}{p_{\text{H}_2\text{O}}} \approx \left(\frac{PM}{R_h T} \right)_{\text{sample}} \left(\frac{R_h T}{PM} \right)_{\text{H}_2\text{O}} \approx \frac{M_{\text{sample}}}{M_{\text{H}_2\text{O}}}$

FILE	DISTRIBUTION (interested codes)	SIGNATURE Susan J. Suzuki 7/20/84
------	---------------------------------	--------------------------------------

APPENDIX D
IMPACTOR DISCUSSION

☐ INCOMING		☒ OUTGOING		DATE 3 APR 84	
PERSON CALLING Bill Powers		PHONE NUMBER		ACTIVITY NEESH 111C	
PERSON CALLED Joe McCain		PHONE NUMBER (205) 323-6592		ACTIVITY Southern Research Institute	
GENERAL SUBJECT Use of Mark III U./W impactors for particle sizing acid mist.					
TOPICS DISCUSSED AND ACTION TAKEN					

① Joe thought that in order to make a gravimetric analysis of impactor filter stages as valid as possible the filter stages should be weighed immediately following the test without dissection. Filters should be weighed at regular intervals for 2 to 3 hours! Plot weights on log paper to determine evaporation loss rate (over time). Extrapolate back to time at end of test to get approx. weight of collected liquid at time test ended.

② I mentioned that we really only needed 2 to 3 stages in the impactor for our purpose, not the 6 stages normally found in the Mark III. Joe said that is not a problem, simply remove the unnecessary stages and replace with spacers. Cutpoints for the impactor stages do not change significantly, and the problem of increased particle bounce is a minor concern with liquid droplets.

FILE 2116 LBVSY	DISTRIBUTION (inserted codes)	SIGNATURE Bill Powers
--------------------	-------------------------------	-----------------------

APPENDIX E
SAMPLE CALCULATIONS

MASS EMISSIONS CALCULATIONS

93-8/6

$DI_{mg/L}$ = DEIONIZED WATER BLANK CONCENTRATION (mg/L)

$KOH_{mg/L}$ = POTASSIUM HYDROXIDE BLANK CONCENTRATION (mg/L)

X = SAMPLE WEIGHT (grams)

MW = MOLECULAR WEIGHT

18 = MOLECULAR WEIGHT

$DSCF$ = VOLUME of AIR SAMPLED

$CF1$ = CONVERSION FACTOR for KOH SAMPLE BLANK
 $= (1000 \text{ ml SAMPLE} / 1 \text{ L lab basis}) \times (14 / 1000 \text{ ml})$

$CF2$ = CONVERSION FACTOR for DI SAMPLE BLANK
 $= (X - 1000 \text{ ml} / 1 \text{ L lab basis}) \times (14 / 1000 \text{ ml})$

$CF3$ = CONVERSION FACTOR for CONCENTRATION
 $= (X / 1000 \text{ ml})$

$CF4$ = CORRECTION FACTOR for PPM
 $= (MW / 18)$

BLANK CONCENTRATION

$$mg/L_B = (KOH_{mg/L} \times CF1) + (DI_{mg/L} \times CF2)$$

SAMPLE CONCENTRATION

$$mg/m^3 = [mg/L] (CF3) - (mg/L_B) \times (X / DSCF) \times (35.3147 \text{ ft}^3/m^3)$$

$$mg/m^3 = [PPM] (CF3 \times CF4) - (mg/L_B) \times (X / DSCF) \times (35.3147 \text{ ft}^3/m^3)$$

FAN POWER COST SAVINGS CALCULATIONS

WEI
2016

NOTE: ALL STATIC PRESSURES (SP) ARE FOUND IN TABLE 13

ASSUMPTIONS: a. STATIC PRESSURE DROP ACROSS SCRUBBERS WILL BE ELIMINATED BY REMOVING SCRUBBER INTERNALS

b. EXHAUST VOLUME WILL REMAIN THE SAME FOR EACH SCRUBBER

1. FAN 101: BHP DETERMINED FROM FAN CHART ON PG. D-4

$$Q = 28130 \text{ SCFM}$$

$$\text{BHP REQUIRED AT } -6.8" \text{ SP} = 41.2 \text{ BHP}$$

$$\text{BHP REQUIRED AT } -1.9" \text{ SP} = \underline{14.2 \text{ BHP}}$$

$$\text{REDUCTION IN BHP: } 27. \text{ BHP}$$

FAN POWER COST REDUCTION:

ASSUME: a. 90% FAN AVAILABILITY PER YEAR (7860 HRS.)

b. ELECTRICITY COST OF \$.07 PER KW-HR

$$27 \text{ BHP} \times .746 \frac{\text{KW}}{\text{BHP}} \times 7860 \text{ HRS.} \times \frac{\$.07}{\text{KW-HRS}} \approx \underline{\underline{\$11,100/\text{YR.}}}$$

2. FAN 102:

$$Q = 30970 \text{ CFM}$$

$$\text{BHP REQUIRED AT } -6.4" \text{ SP} = 42.8 \text{ BHP}$$

$$\text{BHP REQUIRED AT } -3.3" \text{ SP} = \underline{24.2 \text{ BHP}}$$

$$\text{REDUCTION IN BHP } 18.6 \text{ BHP}$$

FAN POWER COST REDUCTION:

$$18.6 \text{ BHP} \times .746 \frac{\text{KW}}{\text{BHP}} \times 7860 \text{ HRS.} \times \frac{\$.07}{\text{KW-HRS}} \approx \underline{\underline{\$7,600/\text{YR.}}}$$

3. FAN 105: BHP DETERMINED FROM GRAPH ON PG.

$$Q = 50090 \text{ SCFM}$$

BHP REQUIRED AT -5.1" SP = 72 BHP

BHP REQUIRED AT -3.8" SP = 60 BHP

REDUCTION IN BHP 12 BHP

FAN POWER COST REDUCTION:

$$12 \text{ BHP} \times .746 \frac{\text{KW}}{\text{BHP}} \times 7860 \text{ HRS.} \times \frac{\$.07}{\text{KW-HR}} \approx \underline{\underline{\$4,900/\text{YR.}}}$$

4. FAN 106:

THIS FAN WAS NOT OPERATIONAL ON DAY STATIC PRESSURE MEASUREMENTS WERE MADE. FANS 105 AND 106 HAVE THE SAME VOLUME AND STATIC PRESSURE RATINGS, AND IT IS ASSUMED THAT A SIMILAR HORSEPOWER REDUCTION WOULD OCCUR WITH THE REMOVAL OF SCRAPER 106 INTERNALS.

ESTIMATED REDUCTION IN BHP = 12 BHP

ESTIMATED FAN POWER COST REDUCTION:

$$12 \text{ BHP} \times .746 \frac{\text{KW}}{\text{BHP}} \times 7860 \text{ HRS.} \times \frac{\$.07}{\text{KW-HR}} \approx \underline{\underline{\$4,900/\text{YR.}}}$$

5. TOTAL FAN POWER COST SAVINGS:

$$\$11,100 + \$7,600 + \$4,900 + \$4,900 = \underline{\underline{\$28,500/\text{YR.}}}$$

SIZE 445										MAXIMUM BHP = 361.0 [1000]									
CFM	Outlet Velocity	1/2" SP	3/4" SP	1" SP	1 1/4" SP	2" SP	3" SP	4" SP	5" SP	6" SP	7" SP	8" SP	9" SP	10" SP	11" SP	12" SP	13" SP	14" SP	15" SP
RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
10125	500	281	0.78	322	1.21	361	1.67	398	2.19	469	3.30	535	4.59	596	6.00	655	6.72	705	11.9
12150	600	370	1.14	423	2.16	473	2.71	515	3.43	545	5.24	601	6.72	655	8.33	677	10.5	711	15.7
14175	700	462	1.62	515	2.71	565	3.43	615	4.59	645	6.00	677	8.33	705	11.9	738	15.7	778	27.7
16200	800	557	2.16	615	3.43	677	4.59	738	6.00	778	8.33	812	10.5	846	13.0	886	17.0	924	34.7
18225	900	655	2.71	711	4.14	778	5.24	846	6.72	886	8.33	924	10.5	964	13.0	1004	17.0	1044	34.7
20250	1000	753	3.26	812	4.69	873	5.78	938	6.72	978	8.33	1018	10.5	1058	13.0	1098	17.0	1138	34.7
22275	1100	851	3.81	913	5.24	973	6.27	1038	7.21	1078	8.33	1118	10.5	1158	13.0	1198	17.0	1238	34.7
24300	1200	949	4.36	1015	5.78	1075	6.72	1135	7.71	1175	8.33	1215	10.5	1255	13.0	1295	17.0	1335	34.7
26325	1300	1047	4.91	1117	6.33	1177	7.21	1237	8.26	1277	8.33	1317	10.5	1357	13.0	1397	17.0	1437	34.7
28350	1400	1145	5.46	1219	6.88	1279	7.71	1339	8.76	1379	8.33	1419	10.5	1459	13.0	1499	17.0	1539	34.7
30375	1500	1243	6.01	1321	7.43	1381	8.26	1441	9.21	1481	8.33	1521	10.5	1561	13.0	1601	17.0	1641	34.7
32400	1600	1341	6.56	1423	7.98	1483	8.76	1543	9.71	1583	8.33	1623	10.5	1663	13.0	1703	17.0	1743	34.7
34425	1700	1439	7.11	1525	8.53	1585	9.21	1645	10.26	1685	8.33	1725	10.5	1765	13.0	1805	17.0	1845	34.7
36450	1800	1537	7.66	1627	9.08	1687	9.71	1747	10.76	1787	8.33	1827	10.5	1867	13.0	1907	17.0	1947	34.7
38475	1900	1635	8.21	1729	9.63	1789	10.26	1849	11.21	1889	8.33	1929	10.5	1969	13.0	2009	17.0	2049	34.7
40500	2000	1733	8.76	1831	10.18	1891	10.76	1951	11.76	1991	8.33	2031	10.5	2071	13.0	2111	17.0	2151	34.7
42525	2100	1831	9.31	1933	10.73	1993	11.31	2053	12.31	2093	8.33	2133	10.5	2173	13.0	2213	17.0	2253	34.7
44550	2200	1929	9.86	2035	11.28	2095	11.86	2155	12.86	2195	8.33	2235	10.5	2275	13.0	2315	17.0	2355	34.7
46575	2300	2027	10.41	2137	11.83	2197	12.41	2257	13.41	2297	8.33	2337	10.5	2377	13.0	2417	17.0	2457	34.7
48600	2400	2125	10.96	2239	12.38	2299	12.96	2359	13.96	2399	8.33	2439	10.5	2479	13.0	2519	17.0	2559	34.7
50625	2500	2223	11.51	2341	12.93	2401	13.51	2461	14.51	2501	8.33	2541	10.5	2581	13.0	2621	17.0	2661	34.7
52650	2600	2321	12.06	2443	13.48	2503	14.06	2563	15.06	2603	8.33	2643	10.5	2683	13.0	2723	17.0	2763	34.7
54675	2700	2419	12.61	2545	14.03	2605	14.61	2665	15.61	2705	8.33	2745	10.5	2785	13.0	2825	17.0	2865	34.7
56700	2800	2517	13.16	2647	14.58	2707	15.16	2767	16.16	2807	8.33	2847	10.5	2887	13.0	2927	17.0	2967	34.7

CLASS I—Max. RPM = 1974 CLASS II—Max. RPM = 1262 CLASS III—Max. RPM = 1585 Max. Static Efficiency—Bold face type

SIZE 490										MAXIMUM BHP = 581.0 [1000]									
CFM	Outlet Velocity	1/2" SP	3/4" SP	1" SP	1 1/4" SP	2" SP	3" SP	4" SP	5" SP	6" SP	7" SP	8" SP	9" SP	10" SP	11" SP	12" SP	13" SP	14" SP	15" SP
RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
12290	500	255	0.94	294	1.47	338	2.03	381	2.65	426	3.26	473	3.81	520	4.36	567	4.91	615	5.46
14748	600	344	1.39	395	2.16	449	2.71	502	3.26	557	3.81	612	4.36	667	4.91	722	5.46	777	6.01
17206	700	433	1.84	496	2.93	561	3.48	626	4.03	691	4.58	756	5.13	821	5.68	886	6.23	951	6.78
19664	800	522	2.29	595	3.48	670	4.03	745	4.58	820	5.13	895	5.68	970	6.23	1045	6.78	1120	7.33
22122	900	611	2.74	694	4.03	779	4.58	864	5.13	949	5.68	1034	6.23	1119	6.78	1204	7.33	1289	7.88
24580	1000	700	3.19	793	4.58	888	5.13	983	5.68	1078	6.23	1173	6.78	1268	7.33	1363	7.88	1458	8.43
27038	1100	789	3.64	892	5.13	997	5.68	1092	6.23	1187	6.78	1282	7.33	1377	7.88	1472	8.43	1567	8.98
29496	1200	878	4.09	981	5.68	1086	6.23	1181	6.78	1276	7.33	1371	7.88	1466	8.43	1561	8.98	1656	9.53
31954	1300	967	4.54	1070	6.23	1175	6.78	1270	7.33	1365	7.88	1460	8.43	1555	8.98	1650	9.53	1745	10.08
34412	1400	1056	4.99	1159	6.78	1264	7.33	1359	7.88	1454	8.43	1549	8.98	1644	9.53	1739	10.08	1834	10.63
36870	1500	1145	5.44	1248	7.33	1353	7.88	1448	8.43	1543	8.98	1638	9.53	1733	10.08	1828	10.63	1923	11.18
39328	1600	1234	5.89	1337	7.88	1442	8.43	1537	8.98	1632	9.53	1727	10.08	1822	10.63	1917	11.18	2012	11.73
41786	1700	1323	6.34	1426	8.43	1531	8.98	1626	9.53	1721	10.08	1816	10.63	1911	11.18	2006	11.73	2101	12.28
44244	1800	1412	6.79	1515	8.98	1620	9.53	1715	10.08	1810	10.63	1905	11.18	2000	11.73	2095	12.28	2190	12.83
46702	1900	1501	7.24	1604	9.53	1709	10.08	1804	10.63	1900	11.18	1995	11.73	2090	12.28	2185	12.83	2280	13.38
49160	2000	1590	7.69	1693	10.08	1798	10.63	1893	11.18	1988	11.73	2083	12.28	2178	12.83	2273	13.38	2368	13.93
51618	2100	1679	8.14	1782	10.63	1887	11.18	1982	11.73	2077	12.28	2172	12.83	2267	13.38	2362	13.93	2457	14.48
54076	2200	1768	8.59	1871	11.18	1976	11.73	2071	12.28	2166	12.83	2261	13.38	2356	13.93	2451	14.48	2546	15.03
56534	2300	1857	9.04	1960	11.73	2065	12.28	2160	12.83	2255	13.38	2350	13.93	2445	14.48	2540	15.03	2635	15.58
58992	2400	1946	9.49	2049	12.28	2154	12.83	2249	13.38	2344	13.93	2439	14.48	2534	15.03	2629	15.58	2724	16.13
61450	2500	2035	9.94	2138	12.83	2243	13.38	2338	13.93	2433	14.48	2528	15.03	2623	15.58	2718	16.13	2813	16.68
63908	2600	2124	10.39	2227	13.38	2332	13.93	2427	14.48	2522	15.03	2617	15.58	2712	16.13	2807	16.68	2902	17.23
66366	2700	2213	10.84	2316	13.93	2421	14.48	2516	15.03	2611	15.58	2706	16.13	2801	16.68	2896	17.23	2991	17.78
68824	2800	2302	11.29	2405	14.48	2510	15.03	2605	15.58	2700	16.13	2795	16.68	2890	17.23	2985	17.78	3080	18.33

CLASS I—Max. RPM = 884 CLASS II—Max. RPM = 1146 CLASS III—Max. RPM = 1439 Max. Static Efficiency—Bold face type

Performance shown is for line fans without outlet duct.

CFM does not include loss.

FAN CURVE FOR FAN 105 FAN 106

TEST DIA. ON
Naval Facilities Engineering Command
San Diego, Calif. 92160
APPROVED


ALL DATA were obtained from
Curve 105. 8 to 11 tested with
no change in motor drive or flow.
PICARD 1000-14. Material required

By *CFH* Date 5-21-79

for OICC/EOICC

Spec. 78-C-0244

CMHB-48



APPENDIX F
TARE WEIGHT DATA

I A II B II C II D II E II F II G II H I
 11 DONUT179 TARE WEIGHT ANALYSIS SHEET

21 Start Date:05/02/84

31 Finish Date:05/04/84

41 Weighing Interval:~ 24 hours

Engineer:Darrow Kirkpatrick

51 =====

61 Filter Tare Weight (grams) Max Diff
 71 Number 1 2 3 AVERAGE (mg)

81	2	4	6	8	10
91	100	1.2099	1.2099	1.2099	1.2099
01	101	1.2327	1.2329	1.2329	1.2329
11	102	1.2009	1.2011	1.2012	1.2011
21	103	1.2285	1.2287	1.2288	1.2287
31	104	1.2261	1.2261	1.2262	1.2261
41	105	1.1999	1.1999	1.1999	1.1999
51	106	1.1858	1.1858	1.1858	1.1858
61	107	1.2383	1.238	1.2381	1.2381
71	108	1.2369	1.2368	1.2369	1.2369
81	109	1.2171	1.2172	1.2172	1.2172
91	110	1.2297	1.2297	1.2298	1.2297
01	111	1.1868	1.1869	1.1871	1.1869
11	112	1.2265	1.2268	1.2267	1.2267
22	113	1.2246	1.2249	1.225	1.2248
31	114	1.2107	1.2108	1.2109	1.2108
41	115	1.2272	1.2273	1.2274	1.2273
51	116	1.2267	1.2268	1.2266	1.2267
61	117	1.2179	1.2181	1.2178	1.2179
71	118	1.2167	1.2167	1.2166	1.2167
81	119	1.2109	1.2109	1.2109	1.2109
91	120	1.2192	1.2192	1.2191	1.2192
01	121		1.2379	1.2377	1.2378
11	122	1.2347	1.2349	1.2346	1.2347
21	123	1.218	1.2182	1.2182	1.2181
31	124	1.1988	1.1988	1.1989	1.1988
41	125	1.1923	1.1927	1.1926	1.1925
51	126	1.2226	1.2228	1.2228	1.2227
61	127	1.2041	1.2043	1.2043	1.2042
71	128	1.2055	1.2058	1.2059	1.2057
81	129	1.1972	1.1974	1.1976	1.1974
91	130	1.2048	1.2048	1.2049	1.2048
01	131	1.2262	1.2263	1.2265	1.2263
11	132	1.2341	1.234	1.2341	1.2341
21	133	1.2316	1.2319	1.2317	1.2317
31	134	1.2328	1.2332	1.2328	1.2329
41	135	1.2327	1.2331	1.2327	1.2329
51	136	1.2354	1.2354	1.2352	1.2353
61	137	1.2085	1.2085	1.2083	1.2084
71	138	1.2352	1.235	1.235	1.2351
81	139	1.1958	1.1956	1.1955	1.1956
91	140	1.2217	1.2216	1.2218	1.2217
01	141	1.2274	1.2273	1.2274	1.2274
11	142	1.2304	1.2305	1.2305	1.2305
21	143	1.2292	1.2295	1.2295	1.2294
31	144	1.2309	1.2311	1.2312	1.2311
41	145	1.2025	1.2028	1.2029	1.2027
51	146	1.1945	1.1946	1.1948	1.1946
61	147	1.2004	1.2006	1.2007	1.2006
71	148	1.1995	1.1994	1.1996	1.1995
81	149	1.2316	1.2315	1.2316	1.2316
91	150	1.2322	1.2321	1.2322	1.2322
01	151	1.2277	1.2277	1.2278	1.2277
11	152	1.1928	1.1927	1.1929	1.1928

65	155	1.2101	1.2101	1.2101	1.2101	0
66	157	1.2008	1.2006	1.2007	1.2007	.2
67	158	1.2107	1.2107	1.2107	1.2107	0
68	159	1.1899	1.1898	1.1898	1.1898	.1
69	160	1.186	1.186	1.186	1.186	0
70	161	1.2041	1.204	1.204	1.204	.1
71	162	1.1919	1.1919	1.1919	1.1919	0
72	163	1.2063	1.2061	1.2061	1.2062	.2
73	164	1.2021	1.2025	1.2024	1.2023	.4
74	165	1.2188	1.219	1.2191	1.219	.3
75	166	1.2037	1.2038	1.2038	1.2038	.1
76	167	1.1982	1.1981	1.1984	1.1982	.3
77	168	1.2282	1.2282	1.2283	1.2282	.1
78	169	1.1962	1.1964	1.1965	1.1964	.3
79	170	1.2054	1.2055	1.2056	1.2055	.2
80	171	1.2014	1.2014	1.2015	1.2014	.1
81	172	1.1989	1.1991	1.1991	1.199	.2
82	173	1.1992	1.1995	1.1994	1.1994	.3
83	174	1.1961	1.1964	1.1963	1.1963	.3
84	175	1.2258	1.2259	1.2259	1.2259	.1
85	176	1.2271	1.2272	1.2271	1.2271	.1
86	177	1.1906	1.1907	1.1907	1.1907	.1
87	178	1.2215	1.2215	1.2216	1.2215	.1
88	179	1.1877	1.1878	1.1879	1.1878	.2

89:-----

90:Date: 05/02/84 05/03/84 05/04/84

91:Time: 0930 1500 1300

92:Temp: 61 F 69 F 67 F

93:Humid: 37% 33% 31%

94:=====

95:* -Mettler AK160 (No. 40750) calibration checked w/ Christian Becker

96: Class S weights before all weighing sessions.

1 A 11 B 11 C 11 D 11 E 11 F 11 G 11 H 1
 11 DONUT269 TARE WEIGHT ANALYSIS SHEET

21 Start Date:05/02/84

31 Finish Date:05/05/84

41 Weighing Interval:~ 24 hours

Engineer:Darrow Kirkpatrick

51 =====

61 Filter Tare Weight (grams) Max Diff

71 Number 1 2 3 AVERAGE (mg)

81 -----

91	180	1.2027	1.2086	1.2087	1.2087	.1
01	181	1.2411	1.2409	1.2409	1.241	.2
11	182	1.23	1.2297	1.2299	1.2299	.3
12	183	1.2506	1.2505	1.2506	1.2506	.1
13	184	1.2106	1.2105	1.2107	1.2106	.2
41	185	1.2029	1.2028	1.2031	1.2029	.3
15	186	1.2554	1.2553	1.2555	1.2554	.2
16	187	1.2233	1.2234	1.2235	1.2234	.2
71	188	1.206	1.206	1.206	1.206	0
18	189	1.1969	1.197	1.1969	1.1969	.1
19	190	1.2095	1.2096	1.2096	1.2096	.1
01	191	1.2306	1.2307	1.2306	1.2306	.1
11	192	1.1943	1.1945	1.1944	1.1944	.2
22	193	1.2267	1.2268	1.2268	1.2268	.1
31	194	1.2159	1.2161	1.2162	1.2161	.3
41	195	1.2396	1.2397	1.2397	1.2397	.1
25	196	1.2402	1.2402	1.2402	1.2402	0
26	197	1.2008	1.2007	1.2008	1.2008	.1
11	198	1.2385	1.2385	1.2385	1.2385	0
28	199	1.2326	1.2326	1.2325	1.2326	.1
29	200	1.2043	1.2043	1.2043	1.2043	0
01	201	1.2041	1.2042	1.2042	1.2042	.1
11	202	1.2087	1.2089	1.209	1.2089	.3
32	203	1.2157	1.2157	1.2158	1.2157	.1
31	204	1.2038	1.2039	1.2039	1.2039	.1
41	205	1.2158	1.2159	1.2157	1.2158	.2
35	206	1.1989	1.199	1.199	1.199	.1
36	207	1.2119	1.212	1.212	1.212	.1
11	208	1.2237	1.2236	1.2238	1.2237	.2
38	209	1.2169	1.2169	1.2169	1.2169	0
39	210	1.2075	1.2073	1.2074	1.2074	.2
01	211	1.2092	1.2092	1.2093	1.2092	.1
11	212	1.2063	1.2063	1.2063	1.2063	0
42	213	1.1936	1.1937	1.1939	1.1937	.3
31	214	1.2392	1.2393	1.2393	1.2393	.1
41	215	1.2156	1.2158	1.2156	1.2157	.2
45	216	1.2033	1.2033	1.2033	1.2033	0
16	217	1.2039	1.2036	1.2037	1.2037	.3
11	218	1.2217	1.2214	1.2215	1.2215	.3
48	219	1.1917	1.1913	1.1916	1.1915	.4
49	220	1.2431	1.2432	1.2431	1.2431	.1
11	221	1.2292	1.2294	1.2292	1.2293	.2
11	222	1.2429	1.243	1.2428	1.2429	.2
52	223	1.2635	1.2636	1.2634	1.2635	.2
11	224	1.2391	1.2393	1.2393	1.2392	.2
11	225	1.2442	1.2443	1.2441	1.2442	.2
55	226	1.2316	1.2317	1.2315	1.2316	.2
76	227	1.2521	1.2522	1.2522	1.2522	.1
11	228	1.215	1.2151	1.215	1.215	.1
58	229	1.2417	1.2417	1.2417	1.2417	0
59	230	1.2314	1.2315	1.2314	1.2314	.1
11	231	1.2412	1.2413	1.2411	1.2412	.2
11	232	1.2156	1.2158	1.2155	1.2156	.3
11	233	1.2156	1.2158	1.2155	1.2156	.3

64	235	1.2369	1.237	1.2369	1.2369	.1
65	236	1.2344	1.2343	1.2343	1.2343	.1
66	237	1.2434	1.2436	1.2433	1.2434	.3
67	238	1.2299	1.23	1.23	1.23	.1
68	239	1.1942	1.1944	1.1942	1.1943	.2
69	240	1.2237	1.2237	1.2236	1.2237	.1
70	241	1.2247	1.2249	1.2246	1.2247	.3
71	242	1.2289	1.229	1.2289	1.2289	.1
72	243	1.2158	1.2161	1.2159	1.2159	.3
73	244	1.2102	1.2099	1.21	1.21	.3
74	245	1.2063	1.2061	1.2061	1.2062	.2
75	246	1.2125	1.2123	1.2131	1.2123	.4
76	247	1.2069	1.2067	1.2068	1.2068	.2
77	248	1.1935	1.1936	1.1934	1.1935	.2
78	249	1.2106	1.2106	1.2106	1.2106	0
79	250	1.2105	1.2105	1.2104	1.2105	.1
80	251	1.2195	1.2194	1.2193	1.2194	.2
81	252	1.2347	1.2347	1.2348	1.2347	.1
82	253	1.2118	1.2117	1.2117	1.2117	.1
83	254	1.2091	1.209	1.2091	1.2091	.1
84	255	1.2312	1.2312	1.2314	1.2313	.2
85	256	1.2248	1.2249	1.225	1.2249	.2
86	257	1.2407	1.2406	1.2407	1.2407	.1
87	258	1.2269	1.227	1.227	1.227	.1
88	259	1.223	1.2231	1.223	1.223	.1
89	260	1.234	1.2339	1.234	1.234	.1
90	261	1.2181	1.2182	1.2182	1.2182	.1
91	262	1.2338	1.2336	1.2336	1.2337	.2
92	263	1.2283	1.2284	1.2283	1.2283	.1
93	264	1.2368	1.2369	1.2369	1.2369	.1
94	265	1.2057	1.2056	1.2057	1.2057	.1
95	266	1.231	1.231	1.231	1.231	0
96	267	1.2204	1.2202	1.2204	1.2203	.2
97	268	1.2274	1.2271	1.2275	1.2273	.4
98	269	1.2297	1.2296	1.2298	1.2297	.2
99						

```

100 Date:      05/03/84 05/04/84 05/05/84
101 Time:      0830      0830      1130
102 Temp:      65 F      66 F      68 F
103 Humid:     32%      32%      28%
104 =====
105 * -Mettler AK160 (No. 40750) calibration checked w/ Christian Becker
106 Class S weights before all weighing sessions.

```

1 A B C D E F G H
 1 HOLES TARE WEIGHT ANALYSIS SHEET

2 Start Date:05/02/84

3 Finish Date:05/06/84

4 Weighing Interval:~ 24 hours

Engineer:Darrow Kirkpatrick

5 =====

6 Filter	Tare Weight (grams)			Average	Max Diff
7 Number	1	2	3		(mg)

8 -----

9	1	.1201	.12	.1201	.1201	.1
10	2	.1222	.1222	.1219	.1221	.3
11	3	.1218	.1218	.1218	.1218	0
12	4	.123	.1229	.1231	.123	.2
13	5	.1179	.1178	.118	.1179	.2
14	6	.1189	.1186	.1189	.1188	.3
15	7	.1213	.121	.1213	.1212	.3
16	8	.1175	.1173	.1176	.1175	.3
17	9	.1212	.1209	.121	.121	.3
18	10	.1206	.1204	.1204	.1205	.2
19	11	.1219	.1218	.1218	.1218	.1
20	12	.1198	.1197	.1197	.1197	.1
21	13	.1201	.1201	.1201	.1201	0
22	14	.1204	.1204	.1202	.1203	.2
23	15	.1209	.1208	.1207	.1208	.2
24	16	.1171	.117	.1169	.117	.2
25	17	.119	.1188	.1188	.1189	.2
26	18	.1191	.1191	.1191	.1191	0
27	19	.1181	.118	.1181	.1181	.1
28	20	.1203	.1203	.1202	.1203	.1
29	21	.1223	.1224	.1223	.1223	.1
30	22	.1217	.1216	.1215	.1216	.2
31	23	.1194	.1196	.1195	.1195	.2
32	24	.1188	.1187	.1187	.1187	.1
33	25	.1181	.118	.1182	.1181	.2
34	26	.1181	.1179	.1181	.118	.2
35	27	.121	.121	.121	.121	0
36	28	.1196	.1196	.1198	.1197	.2
37	29	.1195	.1195	.1194	.1195	.1
38	30	.1196	.1197	.1195	.1196	.2
39	31	.1208	.121	.1208	.1209	.2
40	32	.1217	.1218	.1218	.1218	.1
41	33	.1196	.1196	.1196	.1196	0
42	34	.1213	.1213	.1213	.1213	0
43	35	.1188	.1188	.1188	.1188	0
44	36	.1223	.1223	.1222	.1223	.1
45	37	.1217	.1219	.1217	.1218	.2
46	38	.1196	.1196	.1196	.1196	0
47	39	.1229	.1231	.1228	.1229	.3
48	40	.1182	.1182	.1181	.1182	.1
49	41	.122	.1219	.1219	.1219	.1
50	42	.119	.1186	.119	.1189	.4
51	43	.119	.1186	.1189	.1188	.4
52	44	.1207	.1203	.1206	.1205	.4
53	45	.1188	.1186	.119	.1188	.4
54	46	.1174	.1171	.1174	.1173	.3
55	47	.1184	.118	.1183	.1182	.4
56	48	.1207	.1203	.1207	.1206	.4
57	49	.1196	.1192	.1196	.1195	.4
58	50	.1202	.1199	.1202	.1201	.3
59	51	.1224	.1224	.1224	.1224	0
60	52	.1225	.1227	.1226	.1226	.2
61	53	.1194	.1195	.1194	.1194	.1

64	56	.1216	.1214	.1213	.1214	.3
65	57	.1214	.1213	.1212	.1213	.2
66	58	.1215	.1216	.1211	.1214	.5
67	59	.1232	.1231	.1231	.1231	.1

68	-----					
69	Date:	05/03/84	05/05/84	05/05/84		
70	Time:	1300	1100	1800		
71	Temp:	67 F	67 F	67 F		
72	Humid:	33 %	28%	29%		

73	=====					
74	300				ERROR	0
75	301				ERROR	0
76	302				ERROR	0
77	303				ERROR	0
78	304				ERROR	0
79	305				ERROR	0
80	306				ERROR	0
81	307				ERROR	0
82	308				ERROR	0
83	309				ERROR	0
84	310				ERROR	0
85	311				ERROR	0
86	312				ERROR	0
87	313				ERROR	0
88	314				ERROR	0
89	315	.8626	.8628	.8628	.8627	.2
90	316	.861	.8611	.8612	.8611	.2
91	317	.8526	.8528	.8529	.8528	.3
92	318	.8589	.859	.8591	.859	.2
93	319	.8688	.8689	.8689	.8689	.1
94	320	.8457	.8458	.8457	.8457	.1
95	321	.8539	.8538	.854	.8539	.2
96	322	.8578	.858	.858	.8579	.2
97	323	.8655	.8655	.8657	.8656	.2
98	324	.8619	.862	.862	.862	.1
99	325	.8462	.8463	.8462	.8462	.1
100	326	.8705	.8705	.8706	.8705	.1
101	327	.8672	.8673	.8674	.8673	.2
102	328	.8782	.8784	.8783	.8783	.2
103	329	.8666	.8667	.8668	.8667	.2
104	330	.8458	.8456	.8459	.8458	.3
105	331	.8614	.8614	.8614	.8614	0
106	332	.8489	.8487	.8489	.8488	.2
107	333	.8612	.8613	.8612	.8612	.1
108	334	.8559	.8559	.8559	.8559	0
109	335	.8593	.8592	.8594	.8593	.2
110	336	.858	.858	.858	.858	0
111	337	.879	.879	.879	.879	0
112	338	.8827	.8827	.8827	.8827	0
113	339	.828	.8279	.8279	.8279	.1
114	340	.8582	.8583	.8582	.8582	.1
115	341	.864	.8639	.8642	.864	.3
116	342	.8584	.8584	.8584	.8584	0
117	343	.8559	.856	.856	.856	.1
118	344	.8461	.8462	.8462	.8462	.1
119	345	.8573	.8575	.8574	.8574	.2
120	346	.8495	.8496	.8496	.8496	.1
121	347	.8689	.869	.869	.869	.1
122	348	.8532	.8533	.8534	.8533	.2
123	349	.8588	.8588	.8588	.8588	0
124	350	.8554	.8556	.8554	.8555	.2
125	351	.8782	.8784	.8784	.8783	.2
126	352	.8651	.8651	.8652	.8651	.1
127	353	.8477	.8478	.8478	.8478	.1
128	354	.8243	.8243	.8244	.8247	.

131:	358	.8558	.856	.8559	.8674	.2
132:	359	.8569	.857	.8569	.8559	.2
133:					.8569	.1

134: Date: 05/05/84 05/05/84 05/06/84
 135: Time: 0930 1945 1430
 136: Temp: 65 F 68 F 68 F
 137: Humid: 31% 27% 28%

138: =====
 9: * -Mettler AK160 (No. 40750) calibration checked w/ Christian Becker
 140: Class S weights before all weighing sessions.

RECOVERY ANALY SIS WORKSHEET

TEST LOCATION: Alum FILTER HOLDERS

TEST DATE 21 MAY 1989

DATE _____

TIME _____

TEMP. _____

HUMID. 58

PETRI NO.	FILTER NO.	PETRI WEIGHTS			AVE.	TARE WT. FILTER	TARE WT. PETRI	COMB. TARE	SAMPLE WT
		1	2	3					
		1615	1715	1815					
	1	0.4994	0.4994	0.4995	0.4994				
	2	0.5116	0.5118	0.5117	0.5117				
	3	0.5391	0.5392	0.5392	0.5392				
	4	0.5051	0.5051	0.5051	0.5051				
	5	0.4936	0.4936	0.4989	0.4985				
	6	0.5585	0.5586	0.5586	0.5586				
		1645	1745	1845					
	7	0.6756	0.6759	0.6758	0.6757				
	8	0.6896	0.6896	0.6895	0.6896				
	9	0.5796	0.5797	0.5796	0.5796				
	10	0.5235	0.5235	0.5236	0.5235				
	11	0.5196	0.5196	0.5195	0.5196				
	12	0.6413	0.6417	0.6416	0.6417				
	13	0.6290	0.6290	0.6290	0.6290				
	14	0.6417	0.6418	0.6420	0.6418				
	15	0.6460	0.6460	0.6461	0.6460				
	16	0.6541	0.6543	0.6544	0.6543				
	17	0.6151	0.6151	0.6152	0.6151				
	18	0.6096	0.6096	0.6096	0.6096				
	19	0.5847	0.5848	0.5849	0.5848				
	20	0.6173	0.6175	0.6175	0.6174				

DN BEAKER NO.	FILTER NO.	BEAKER SPECIMEN			AVE.	TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE WT. #3
		1	2	3					
	21	0.5598	0.5600	0.5599	0.5599				
	22	0.5080	0.5081	0.5081	0.5081				
	23	0.6291	0.6291	0.6292	0.6291				
	24	0.6583	0.6582	0.6581	0.6582				
	25	0.6564	0.6563	0.6562	0.6564				
	26	0.5618	0.5617	0.5618	0.5618				
	27	0.5633	0.5633	0.5634	0.5633				
	28	0.5715	0.5716	0.5715	0.5715				
	29	0.5361	0.5360	0.5361	0.5361				
	30	0.4831	0.4831	0.4832	0.4831				

RECOVERY ANALYSIS WORKSHEET

IMPACTOR

TEST LOCATION: #106 Bldg. 210

TEST DATE 11 MAY 1984

DATE

TIME

TEMP.

77°F

HUMID. 65%

V	PETRI NO.	FILTER NO.	FILTER PETRI WEIGHTS			AVE.	TARE WT. FILTER	TARE WT. PETRI	COMP. TARE	SAMPLE Δ WT.
			1	2	3					
			10:15	11:15	12:15					
	Nozzle #1	318	0.8597	0.8597	0.8595		0.8590			
	IMPACTOR #4	115	1.2274	1.2275	1.2232		1.2248			
		114	1.2110	1.2111	1.2108		1.2108			
		113	1.2249	1.2249	1.2250		1.2248			
		4	0.1223	0.1141	0.1152		0.1230			
	Nozzle #2	315	0.8629	0.8629	0.8628		0.8627			
	IMPACTOR #1	C1	1.2330	1.2330	1.2329		1.2328			
		C2	1.2012	1.2011	1.2012		1.2011			
		C3	1.2288	1.2238	1.2288		1.2287			
	IS 4707	1	0.1082	0.1077	0.1072		0.1061			
	AVES 1		0.0104							
	IMPACTOR		17.2521	17.2497	17.2499					
			4:30		6:30					
	Nozzle #	316	0.8612	0.8613	0.8611		0.8611			
	IMPACTOR 2	105	1.1999	1.2002	1.2000		1.1999			
		106	1.1860	1.1860	1.1859		1.1858			
		107	1.2383	1.2383	1.2380		1.2381			
		2	17.3687	17.3683	17.3690		0.1221			
	Nozzle #	357	0.8677	0.8676	0.8677		0.8674			
	IMPACTOR 3	109	1.2174	1.2173	1.2172		1.2172			
		110	1.2299	1.2298	1.2299		1.2297			
		11	1.1870	1.1870	1.1869		1.1868			
		4	16.1677	16.1664	16.1650		0.1215			
ON	BEAKER NO.	FILTER NO.	BEAKER SPECIMEN			AVE.	TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE 1+2
			1	2	3					

RECOVERY ANALYSIS WORKSHEET

TEST LOCATION: LBNSY Bldg 710 #102

TEST DATE 21 MAY 84

DATE 21 May 84

TIME 2020

TEMP. 75°F

HUMID. 58

V	PETRI	FILTER	PETRI WEIGHTS			TAKE WT.	TAKE WT.	COMB.	SAMP
	NO.	NO.	1	2	3	AVE.	FILTER	PETRI	TARE
			2045	2130					
	IMPACTOR		TEST 3	RUN 1	INLET #102	21 MAY 84			
	INLET	326	0.8707	0.8707		8705			Δ wt.
		146	1.1949	1.1949		1.1946			0.0002
		145	1.2030	1.2034		1.2027			0.0004
		144	1.2311	1.2312		1.2311			0.0001
		12	1.7854	1.7854		1.7851			0.0003
		[L.F. 1]							0.0000
		(1.1949 + 1.2857) =	1.7851						0.0000
	OUTLET	325	0.8466	0.8466		8462			0.0004
		142	1.2304	1.2307		1.2305			0.0003
		141	1.2273	1.2275		1.2274			0.0002
		140	1.2217	1.2218		1.2217			0.0001
		11	1.7440	1.7442		1.7439			0.0002
		[L.F. 2]							0.0000
		(1.5117 + 1.2322) =	1.7439						0.0000

[illegible]

RECOVERY ANALYSIS WORKSHEET

TEST LOCATION: LB154 Box 210 #102 TEST DATE 21 May 84
 DATE 22 May TIME 0115 TEMP. 74 °F HUMID. 62 %

PETRI NO.	FILTER NO.	PETRI WEIGHTS	TARE WT. FILTER	TARE WT. PETRI	COMB. TARE	SAMPLE WT.
		10125 20155 30210 AVE.				

IMPACTOR TEST 3 RUN 2 2205 → 0105

INLET	321	0.8688	0.8684	0.8685	0.8686	0.8673	0013
150	1.2322	1.2324	1.2324	1.2323	1.2322	0001	
149	1.2318	1.2316	1.2317	1.2317	1.2316	0001	
148	1.1996	1.1996	1.1997	1.1996	1.1995	0001	
13	1.6066	1.6066	1.6067	1.6066	1.6063	0003	
[4.3]						Σ 00019	

OUTLET	324	0.8795	0.8796	0.8789	0.8796	0.8783	0.000
154	1.2206	1.2203	1.2206	1.2205	1.2208	0002	
153	1.2219	1.2218	1.2219	1.2219	1.2217	0001	
152	1.1928	1.1930	1.1930	1.1929	1.1928	0004	
14	1.6682	1.6683	1.6683	1.6683	1.6679	Σ 0.0013	

BEAKER NO.	FILTER NO.	BEAKER SPECIMEN	AVE.	TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE 1+2
1		2	3				

RECOVERY ANALYSIS WORKSHEET

TEST LOCATION: LBVSY 210 #103 TEST DATE 21 May 84
 DATE 24 May 84 TIME 2230 TEMP. 75 F HUMID. 62

V	PETRI NO.	FILTER NO.	PETRI WEIGHTS				TARE WT. FILTER	TARE WT. PETRI	COMB. TARE	SAMP. WT.
			1	2	3	AVE.				
			2242	2315	2345					
			TEST 5 RUN 1 IMPACTOR				INLET/out #103			
							TEST TIME: 1742-2142			
	INLET	329	0.9669	0.9671	0.9669	0.9669	0.9669			.0002
		158	1.2105	1.2109	1.2107	1.2107	1.2107			.0000
		157	1.2010	1.2012	1.2010	1.2011	1.2007			.0001
		156	1.2104	1.2105	1.2105	1.2105	1.2101			.0004
		15	1.2901	1.2900	1.2902	1.2901	1.2897			.0004
		[A #7]								
		330	0.8459	0.8459	0.8461	0.8460	0.8458			.0002
	OUTLET	162	1.1918	1.1919	1.1918	1.1918	1.1919			.0001
		161	1.2037	1.2042	1.2041	1.2041	1.2040			.0001
		160	1.1860	1.1861	1.1862	1.1861	1.1860			.0001
		16	1.0294	1.0295	1.0295	1.0295	1.0293			.0002
		[A #5]								
		4495								
		5363								
		1.0293								

METTLER CHECKED (C) CALIBRATION WEIGHTS 0120

DN	BEAKER NO.	FILTER NO.	BEAKER SPECIMEN				TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMP. WT. 1+
			1	2	3	AVE.				
			0315	0335	0					
			TEST 5 RUN 2 IMPACTOR				#103			
							TEST TIME: 2300-0156			
	INLET	331	0.8617	0.8615	0.8616	0.8616	0.8614			.0002
		166	1.2035	1.2036	1.2039	1.2037	1.2038			.0001
		165	1.2195	1.2193	1.2192	1.2193	1.2190			.0001
		164	1.2024	1.2024	1.2025	1.2024	1.2023			.0001
		17	1.8315	1.8319	1.8319	1.8318	1.8315			.0001
		[A #9]								
		1.8319 + .57%								
			TIME: 0204	0254	0305					
	OUTLET	332	0.8491	0.8488	0.8490	0.8490	0.8488			.0001
		170	1.2054	1.2057	1.2055	1.2055	1.2055			.0000
		169	1.1964	1.1965	1.1964	1.1964	1.1964			.0000
		163	1.2283	1.2285	1.2284	1.2284	1.2282			.0001
		18	1.2726	1.2724	1.2724	1.2725	1.2723			.0001
		[A #8]								
		1.6996								
		1.5827								
		1.2723								

RECOVERY ANALY SIS WORKSHEET

TEST LOCATION: LBNSY Bldg. 210 #104 TEST DATE 26 MAY 84
 DATE 26 May 84 TIME 2115 TEMP. 75 HUMID. 63%
 TEST: 1610-1910

PETRI NO.	FILTER NO.	PETRI WEIGHTS				TARE WT. FILTER	TARE WT. PETRI	COMB. TARE	SAMPLE WT.
		1	2	3	AVE.				
		2115	2145	2215					
		TEST 7	RUN 1	#104	INLET			TEST TIME: 1610-1910	
333		0.9034	0.9029	0.9025	0.9029	0.8612			.041%
174		1.2649	1.2643	1.2641	1.2644	1.1963			.063%
173		1.2466	1.2448	1.2447	1.2454	1.1994			.046%
172		1.2145	1.2145	1.2145	1.2145	1.1990			.015%
19		1.4716	1.4716	1.4716	1.4716	1.4688			.0028
[AL #10]									
5225									
7753									
1.4688									

LARGE VOLUMES OF LIQUID COLLECTED ON EACH STAGE OF THE IMPACTOR IN ADDITION TO LIQUID COLLECTED ON THE FILTER STAGES. THE ABOVE FILTER WEIGHTS DO NOT ACCURATELY REFLECT PARTICLE SIZE DISTRIBUTION ON THIS RUN.

SEE FRAMES

152 OF FILM ROLL

-POWERS

2235

26 MAY 84

BEAKER NO.	FILTER NO.	BEAKER SPECIMEN				TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE WT. 1+2
		1	2	3	AVE.				
		2230	2250	2320					
		TEST 7	RUN 2	#104	INLET			TEST TIME: 2105-2205	
334		0.8709	0.8697	0.8695	0.8701	0.8559			.0142
178		1.2379	1.2370	1.2366	1.2372	1.2215			.015%
177		1.1919	1.1919	1.1919	1.1919	1.1907			.000%
176		1.2281	1.2282	1.2282	1.2282	1.2271			.0011
20		1.0822	1.0824	1.0824	1.0823	1.0824			.000%
[AI #11]									
0.5146									
.5678									
1.0824									

MAJORITY OF MIST COLLECTED ON UNDERSIDE OF FILTER SUPPORT PLATES. AVERAGE SAMPLE WEIGHTS ABOVE DO NOT ACCURATELY SIZE DISTRIBUTION ON THIS RUN

SEE FRAME 3 ON FILM ROLL

-POWERS

2250

26 MAY 84

RECOVERY ANALYSIS WORKSHEET

TEST LOCATION: Penon, N. SV TEST DATE 1 June
DATE 1 June TIME 2305 TEMP. 74°F HUMID. 74%

DATE 11/1/54 TIME 2214 TEMP. 74 F HUMID. 75

[illegible]

UN	BEAKER	FILTER	BEAKER SPECIMEN			AVE.	TARE WT.	SAMPLE	SAMPLE	SAMPLE
2.	NO.	NO.	1	2	3	BEAKER	WT. #1	WT. #2	WT. #2	1+
			11		11		11	11		
			2105		2257					
					0.8830		0.8827			0.000
				62	1.2163		1.2161			1.000
					1.2271		1.2268			0.000
					1.1946		1.1244			0.000
			24		0.6069					0.000

RECOVERY ANALY SIS WORKSHEET

TEST LOCATION: _____

TEST DATE _____

DATE _____

TIME _____

TEMP. _____

HUMID. _____

PETRI NO.	FILTER NO.	PETRI WEIGHTS			AVE.	TARE WT.	TARE WT.	COMB.	Samp. WT.
		1	2	3		FILTER	PETRI	TARE	
TEST 11 RUN 2 INLET # 105 SCRUBBER									
Time 0110 0.139									
339		0.8284	0.8286			0.8279		0.0006	
198		1.2387	1.2390			1.2385		0.0003	
197		1.2012	1.2013			1.2008		0.0005	
196		1.2403	1.2405			1.2402		0.0001	
25		1.1508	1.1506			1.1501		0.0007	
									Σ 0.0022

IN	BEAKER	FILTER	BEAKER SPECIMEN			AVE.	TARE WT.	SAMPLE	SAMPLE	SAMPLE
	NO.	NO.	1	2	3		BEAKER	WT. #1	WT. #2	1+2
	TEST	11	Run 2				Outlet	# 105	Scrubby	
		Time 0114	0.143							
	340	0.8583	0.8583					0.8582		0.0001
	202	1.2048	1.2088					1.2089		0.0001
	201	1.2043	1.2043					1.2042		0.0001
	200	1.2044	1.2046					1.2043		0.0001
	26	0.7771	0.7770					0.7766		0.0001
										Σ 0.0005

RECOVERY ANALY SIS WORKSHEET

TEST #1 RUN #1

TEST LOCATION: F106 F106 SID LF106

TEST DATE 15 May 84

DATE 15 May 84

TIME 11:50 AM

TEMP. 81°F

HUMID. 52

TEST CAPLE 9:45 AM

PETRI NO.	FILTER NO.	PETRI WEIGHTS	TARE WT. FILTER	TARE WT. PETRI	COMB. TARE	SAMPLE WT
		112:15 PM 2 3:15 PM 34:30 PM AVE.				

IMPACTOR #3 1/4" NOZZLE

OUTLET		0.8627	0.8627	0.8627	0.8628	0.8559	
324							0.0060
138		1.2353	1.2353	1.2354	1.2353	1.2351	0.0002
137		1.2085	1.2085	1.2086	1.2085	1.2084	0.0
136		1.2353	1.2353	1.2354	1.2353	1.2353	0.0001
16.0574	10	16.7374	16.7350	16.7366	16.7363	16.7362	0.0001
.6788							Σ 0.0002

IMPACTOR #2 1/4" NOZZLE

INLET		0.8571	0.8581	0.8581	0.8581	0.8579	
322							0.0
129		1.1974	1.1974	1.1975	1.1974	1.1974	0.0000
130		1.2048	1.2049	1.2049	1.2049	1.2048	0.0001
131		1.2264	1.2263	1.2264	1.2264	1.2263	0.0
15.8244	2	16.5522	16.5530	16.5517	16.5523	16.5511	0.0002
.7167							Σ 0.0003

END OF CALIBRATION CHECKED

UN. BEAKER NO.	FILTER NO.	BEAKER SPECIMEN	AVE.	TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE WT. #3
		1 3:30 PM 2 4:20 PM 3 4:45 PM					

IMPACTOR #1 1/4" NOZZLE

TEST #1 RUN #2

INLET		0.8691	0.8691	0.8692	0.8691	0.8689	
319							0.0002
118		1.2167	1.2167	1.2168	1.2167	1.2167	0.0
117		1.2181	1.2180	1.2181	1.2181	1.2179	0.0001
116		1.2267	1.2268	1.2269	1.2268	1.2267	0.0001
17.1671	5	17.8454	17.8452	17.8446	17.8449	17.8525	0.0006
.6154							Σ 0.0009

IMPACTOR #4 1/4" NOZZLE

OUTLET		0.8458	0.8457	0.8460	0.8458	0.8457	
320							0.0001
122		1.2349	1.2348	1.2349	1.2349	1.2347	0.0002
121		1.2376	1.2378	1.2379	1.2378	1.2378	0.0
120		1.2192	1.2192	1.2191	1.2192	1.2192	0.0000
16.0912	6	16.8070	16.8074	16.8085	16.8076	16.8084	0.0002
.7172							Σ 0.0005

END OF TEST 1:20 PM

RECOVERY ANALYSIS WORKSHEET

TEST LOCATION: LBNSY EDGE 210 #106TEST DATE 15 MAY 84DATE 15 MAY 84TIME 3:45 - 4:45 PMTEMP. 78°FHUMID. 43%

PETRI NO.	FILTER NO.	PETRI WEIGHTS				TARE WT. FILTER	TARE WT. PETRI	COMB. TARE	SAMP. WT.
		15:15 ^{PM}	25:45 ^{PM}	36:20 ^{PM}	AVE.				

IMPACTOR # 2, NOZZLE 1/4"

ET	321	0.8542	0.8540	0.8541	0.8541	0.8539		0.0002
	126	1.2228	1.2228	1.2227	1.2228	1.2227		0.0001
	125	1.1927	1.1925	1.1928	1.1927	1.1926		0.0001
	124	1.1987	1.1990	1.1990	1.1990	1.1988		0.0002
16.0256	7	16.6349	16.6330	16.6324	16.6334	16.6421		0.0087
6165								

IMPACTOR # 3, NOZZLE 1/4"

DET	323	0.8658	0.8658	0.8659	0.8658	0.8656		0.0002
	134	1.2329	1.2330	1.2330	1.2330	1.2329		0.0001
	133	1.2318	1.2318	1.2319	1.2318	1.2317		0.0001
	132	1.2342	1.2343	1.2343	1.2343	1.2341		0.0002
16.0377	6	16.6513	16.6510	16.6503	16.6509	16.6463		0.0046
6086								0.0005

BEAKER NO.	FILTER NO.	BEAKER SPECIMEN			AVE.	TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE 1+2
		1	2	3					

RECOVERY ANALYSIS WORKSHEET

TEST LOCATION: L.B.N.S.Y

TEST DATE 30 MAY 84

DATE 30 MAY 84

TIME 2200

TEMP. 75°F

HUMID. _____

N	PETRI NO.	FILTER NO.	PETRI WEIGHTS			AVE.	TARE WT.	TARE WT.	COMB. TARE	SAMPLE WT
			1	2	3		FILTER	PETRI		
TEST 9 RUN 1 INLET #106 30 MAY 84										
INLET										
	336		0.8581	0.8581			0.8580			0.0001
	186		1.2556	1.2556			1.2554			0.0002
	185		1.2030	1.2030			1.2029			0.0001
	184		1.2107	1.2107			1.2106			0.0001
	22		1.1830	1.1830			1.1829			0.0001
	[AI #12]									0.0001
	.607									
	.613									
	.621									
OUTLET										
	335		0.8594	0.8594			0.8593			0.0001
	182		1.2300	1.2299			1.2299			0.0001
	181		1.2411	1.2411			1.2410			0.0001
	180		1.2086	1.2086			1.2087			0.0001
	21		1.2512	1.2512			1.2509			0.0003
	AI #13									0.0001
	.624									
	.6240									
	.6249									
DN	BEAKER NO.	FILTER NO.	BEAKER SPECIMEN			AVE.	TARE WT. BEAKER	SAMPLE WT. #1	SAMPLE WT. #2	SAMPLE WT. #3
			1	2	3					

APPENDIX G
EQUIPMENT CALIBRATION SHEETS

METER CALIBRATION

Barometric Pressure 30.105DONE BY JAGDATE 3-5-84METER # RAC # 1

NEW CALIBRATION

 $\Delta H = 0.3$ Vd initial 640.800 ft³

Start test and record temperatures every cubic ft.

1240

Vw	TW(°F)	Tdin (°F)
0	63.0	80
1		80
2		80
3		80
4		80
5	63.0	80

END TEST

Actual Vw 5.000 ft³Vd final 645.942 ft³Tt 16.290 (min).(sec)

RUN PROGRAM

 γ 1.0033H₂O 1.7390 "H₂O

AVERAGE

 $\gamma = 1.0070$ H₂O = 1.8627 $\Delta H = 0.5$ Vd initial 646.200 ft³

Start test and record temperatures every Cf.

1300

Vw	TW(°F)	Tdin (°F)
0	63.0	80
1		81
2		81
3		81
4		82
5	63.0	82

END TEST

Actual Vw 5.000 ft³Vd final 651.342 ft³Tt 12.555 (min).(sec)

RUN PROGRAM

 γ 1.0049H₂O 1.7782 "H₂O $\Delta H = 0.8$ Vd initial 651.700 ft³

Start test and record temperatures every Cf.

Vw	TW(°F)	Tdin (°F)
0	63	82
1	1	83
2		83
3		84
4	1	84
5	63	84

END TEST

Actual Vw 5.000 ft³Vd final 656.838 ft³Tt 10.255 (min).(sec)

RUN PROGRAM

 γ 1.0090H₂O 1.8442 "H₂O

METER CALIBRATION

Barometric Pressure 30.105DONE BY JAG & NAVAMETER # #1DATE 3-5-84 $\Delta H = \cancel{0.3} 1.0$ Vd initial 657.800 ft³

Start test and record temperatures every cubic ft.

Vw	TW(°F)	Tdin (°F)
0	63.5	84
1	/	84
2	/	85
3	/	85
4	/	85
5	63.5	85

END TEST

Actual Vw 5.000 ft³Vd final 662.94.6 ft³Tt 9.242 (min).(sec)

RUN PROGRAM

 γ 1.0085H₂O 1.8739 "H₂O $\Delta H = \cancel{2.5} 2.0$ Vd initial 668.800 ft³

Start test and record temperatures every Cf.

Vw	TW(°F)	Tdin (°F)
0	63.5	85
1	/	86
2	/	86
3	/	86
4	/	87
5	63.5	87

END TEST

Actual Vw 5.000 ft³Vd final 673.948 ft³Tt 6.486 (min).(sec)

RUN PROGRAM

 γ 1.0084H₂O 1.9603 "H₂O $\Delta H = \cancel{6.8} 3.0$ Vd initial 675.200 ft³

Start test and record temperatures every Cf.

Vw	TW(°F)	Tdin (°F)
0	64	86
1	/	86
2	/	87
3	/	87
4	/	87
5	64	87

END TEST

Actual Vw 5.000 ft³Vd final 680.838 ft³Tt 5.352 (min).(sec)

RUN PROGRAM

 γ 1.0079H₂O 1.9808 "H₂O

673.948

668.8

5.144

Pump SER# 26345

Worksheet 1 of 2

METER CALIBRATION

Barometric Pressure 30.080

DONE BY M. L. P.

DATE 2-10-84

METER # RAC # 2

$\Delta H = 0.3$

Vd initial 373.300 ft³

Start test and record temperatures every cubic ft.

10:05

Vw	Tw(°F)	Tdin (°F)
0	61.5	76
1		77
2		77
3		78
4	↓	79
5	61.5	80

END TEST

Actual Vw 5.000 ft³

Vd final 378.496 ft³

Tt 13.418 (min).(sec)

RUN PROGRAM

η 0.9917

HQ 1.1996 "H₂O

$\Delta H = 0.5$

Vd initial 378.900 ft³

Start test and record temperatures every Cf.

10:25

Vw	Tw(°F)	Tdin (°F)
0	62	78
1		79
2		80
3		81
4	↓	82
5	62	82

END TEST

Actual Vw 5.000 ft³

Vd final 384.105 ft³

Tt 10.500 (min).(sec)

RUN PROGRAM

η 0.9941

HQ 1.2450 "H₂O

$\Delta H = 0.8$

Vd initial 384.400 ft³

Start test and record temperatures every Cf.

10:40

Vw	Tw(°F)	Tdin (°F)
0	62	81
1		82
2		83
3		84
4	↓	85
5	62	85

END TEST

Actual Vw 5.000 ft³

Vd final 389.600 ft³

Tt 8.402 (min).(sec)

RUN PROGRAM

η 0.9989

HQ 1.2713 "H₂O

$\eta = 0.9969$ HQ = 1.1874

$\eta = 0.9935$ HQ = 1.1837

AVERAGE (THREE RUNS)

$\eta = 0.9940$ HQ = 1.1902

2-14-84

$\eta = 1.0006$ HQ = 1.2312

$\eta = 0.9963$ HQ = 1.2332

AVERAGE (THREE RUNS)

$\eta = 0.9970$ HQ = 1.2364

2-14-84

$\eta = 1.0003$ HQ = 1.2800

$\eta = 1.0058$ HQ = 1.2516

AVERAGE (THREE RUNS)

$\eta = 1.0016$ HQ = 1.2676

Final

$\eta = 1.0123$

Final

HQ = 1.2373

G-3

Pump SER# 26345

Worksheet 2 of 2

PETER CALIBRATION

Barometric Pressure 30.080

DONE BY JAG

DATE 2-10-84

METER # RAC#2

$\Delta H =$ 1.0

Vd initial 389.900 ft³

Start test and record temperatures every cubic ft.

10:55

VW	TW(°F)	Tdin (°F)
0	62.0	81
1		83
2		84
3		84
4		85
5	62.0	86

END TEST

Actual VW 5.000 ft³

Vd final 395.190 ft³

Tt 7.456 (min).(sec)

RUN PROGRAM

γ 0.9823

HC 1.2719 "H₂O

2-14-84

$\gamma = 0.9997$ HC = 1.2745

$\gamma = 1.0068$ HC = 1.2744

AVERAGE (THREE RUNS)

$\gamma = 0.9962$

HC = 1.2736

$\Delta H =$ 2.0

Vd initial 395.400 ft³

Start test and record temperatures every Cf.

11:05

VW	TW(°F)	Tdin (°F)
0	62.0	83
1		85
2		86
3		86
4		87
5	62.0	88

END TEST

Actual VW 5.000 ft³

Vd final 400.485 ft³

Tt 5.270 (min).(sec)

RUN PROGRAM

γ 1.0232

HC 1.2501 "H₂O

2-15-84

$\gamma = 1.0247$ HC = 1.2679

$\gamma = 1.0285$ HC = 1.2466

AVERAGE (THREE RUNS)

$\gamma = 1.0254$

HC = 1.2542

$\Delta H =$ 3.0

Vd initial 400.485 ft³

Start test and record temperatures every Cf.

12:15

VW	TW(°F)	Tdin (°F)
0	62.0	85
1		87
2		88
3		89
4		90
5	62.0	91

END TEST

Actual VW 5.000 ft³

Vd final 405.423 ft³

Tt 4.250 (min).(sec)

RUN PROGRAM

γ 1.0559

HC 1.2259 "H₂O

2-15-84

$\gamma = 1.0655$ HC = 1.1990

$\gamma = 1.0677$ HC = 1.1794

AVERAGE (THREE RUNS)

$\gamma = 1.0630$

HC = 1.2014

METER CALIBRATION

Barometric Pressure 30.040DONE BY MJDDATE Feb 13/84METER # Box #3 $\Delta H = 1.0$ Vd initial 548.700 ft³

Start test and record temperatures every cubic ft.

15.50

Vw	TW(°F)	Tdin (°F)
0	62	84
1	↓	84
2	↓	84
3	↓	84
4	↓	85
5	62	85

END TEST

Actual Vw 5.000 ft³Vd final 553.912 ft³Tt 9.452 (min).(sec)

RUN PROGRAM

x 0.9979: He 2.0100 "H₂O $\Delta H = 2.0$ Vd initial 554.100 ft³

Start test and record temperatures every Cf.

16.05

Vw	TW(°F)	Tdin (°F)
0	62	84
1	↓	85
2	↓	85
3	↓	85
4	↓	86
5	62	86

END TEST

Actual Vw 5.000 ft³Vd final 559.328 ft³Tt 7.068 (min).(sec)

RUN PROGRAM

x 0.9940He 2.1350 "H₂O $\Delta H = 3.0$ Vd initial 559.500 ft³

Start test and record temperatures every Cf.

16.12

Vw	TW(°F)	Tdin (°F)
0	62	85
1	↓	86
2	↓	86
3	↓	86
4	↓	87
5	62	87

END TEST

Actual Vw 5.000 ft³Vd final 564.732 ft³Tt 5.474 (min).(sec)

RUN PROGRAM

x 0.9926He 2.1179 "H₂O

METER CALIBRATION

Barometric Pressure 30.040DONE BY m & dDATE FEB / 23 / 84METER # Box #3

NEW CALIBRATION

 $\Delta H =$ 0.3Vd initial 532.400 ft³

Start test and record temperatures every cubic ft.

15.00

Vw	TW(°F)	Tdin (°F)
0	62	79
1	↑	81
2		81
3		81
4	↓	81
5	62	81

END TEST

Actual Vw 5.000 ft³Vd final 537.622 ft³Tt 17.229 (min).(sec)

RUN PROGRAM

* 0.9910: HE 1.9221 "H₂OAVE 0.9943AVE HE 2.0299 $\Delta H =$ 0.5Vd initial 537.400 ft³

Start test and record temperatures every Cf.

15.22

Vw	TW(°F)	Tdin (°F)
0	62	81
1		81
2		82
3		82
4	↓	82
5	62	82

END TEST

Actual Vw 5.000 ft³Vd final 543.112 ft³Tt 13.438 (min).(sec)

RUN PROGRAM

* 0.9943HE 2.0014 "H₂O $\Delta H =$ 0.8Vd initial 543.300 ft³

Start test and record temperatures every Cf.

15.40

Vw	TW(°F)	Tdin (°F)
0	62	82
1		83
2		83
3		83
4	↓	84
5	62	84

END TEST

Actual Vw 5.000 ft³Vd final 548.512 ft³Tt 10.499 (min).(sec)

RUN PROGRAM

* 0.9963HE 1.9275 "H₂O

METER CALIBRATION

Barometric Pressure 30.120DONE BY JACDATE 1-25-84METER # RAC # 5

NEW CALIBRATION

 $\Delta H = 0.3$ Vd initial 586.400 ft³

Start test and record temperatures every cubic ft.

1355 - VAC=0

Vw	TW(°F)	Tdin (°F)
0	63.5	97
1		99
2		102
3		105
4		107
5	63.5	109

END TEST

Actual Vw 5 ft³Vd final 591.749 ft³Tt 16.520 (min).(sec)

RUN PROGRAM

 δ 1.0045He 1.7484 "H₂O $\Delta H = 0.5$ Vd initial 592.000 ft³

Start test and record temperatures every Cf.

1415 - VAC=0

Vw	TW(°F)	Tdin (°F)
0	64	104
1		108
2		110
3		112
4		114
5	64	115

END TEST

Actual Vw 5 ft³Vd final 597.421 ft³Tt 13.212 (min).(sec)

RUN PROGRAM

 δ 1.0030He 1.8064 "H₂O $\Delta H = 0.8$ Vd initial 597.800 ft³

Start test and record temperatures every Cf.

1437 - VAC=0

Vw	TW(°F)	Tdin (°F)
0	64	105
1		107
2		110
3		112
4		114
5	64	115

END TEST

Actual Vw 5 ft³Vd final 603.267 ft³Tt 10.325 (min).(sec)

RUN PROGRAM

 δ .9938He 1.8013 "H₂OCHECK QAL - WITH WET
TEST METER WATER QAL -

METER CALIBRATION

Barometric Pressure 30.120DONE BY JAGARCIAMETER # 5 (RAC)DATE 25 JAN. 1984SER # 2562 $\Delta H = \cancel{0.2} 1.0$ Vd initial 603.500 ft³

Start test and record temperatures every cubic ft.

1450 - VAC = 0

Vw	TW(°F)	Tdin (°F)
0	64	109
1		112
2		114
3		116
4		117
5	64	118

END TEST

Actual Vw 5 ft³Vd final 608.969 ft³Tt 9.288 (min).(sec)

RUN PROGRAM

 γ 0.9996He 1.8088 "H₂O $\Delta H = \cancel{2.0} 2.0$ Vd initial 609.300 ft³

Start test and record temperatures every Cf.

15.05 - VAC = 0

Vw	TW(°F)	Tdin (°F)
0	64	109
1		112
2		114
3		116
4		118
5	64	120

END TEST

Actual Vw 5 ft³Vd final 614.784 ft³Tt 6.522 (min).(sec)

RUN PROGRAM

 γ 0.9953He 1.8981 "H₂O $\Delta H = \cancel{3.0} 3.0$ Vd initial 615.100 ft³

Start test and record temperatures every Cf.

15.15 - VAC = 0

Vw	TW(°F)	Tdin (°F)
0	64	114
1		116
2		118
3		120
4		121
5	64	122

END TEST

Actual Vw 5 ft³Vd final 620.600 ft³Tt 5.468 (min).(sec)

RUN PROGRAM

 γ 0.9963He 2.0026 "H₂O

PITOT TUBE IDENTIFICATION NUMBER: 1DATE: 27 APRIL 84CALIBRATED BY: T. BELANDER

4" NOZZLE				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.945	1.34	.840	-.002
2	.948	1.35	.838	-.004
3	.943	1.31	.848	.006
		$\bar{C}_p$ (SIDE A)	.842	

RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1				
2				
3				
		$\bar{C}_p$ (SIDE B)		

$$\text{AVERAGE DEVIATION} = \mu(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 1 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.190	.278	.827	
2	.188	.278	.822	
3	.190	.278	.827	
		$\bar{C}_p$ (SIDE A)		

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.492	.720	.827	.001
2	.492	.720	.827	.001
3	.490	.720	.825	-.001
		$\bar{C}_p$ (SIDE B)	.826	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2.9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 1DATE: 26 APRIL 84CALIBRATED BY: T. BELANGER

<u>3/8" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.520	.770	.822	-.002
2	.522	.773	.822	-.002
3	.525	.765	.828	.004
		$\bar{C}_p$ (SIDE A)	.824	

<u>3/8" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.191	.283	.822	.002
2	.183	.283	.815	-.005
3	.190	.280	.824	.004
		$\bar{C}_p$ (SIDE B)	.820	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2.9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 1DATE: 26 APRIL 84CALIBRATED BY: T. BELANGER

<u>1/2" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.942	1.32	.845	0.0
2	.945	1.33	.843	-.002
3	.930	1.30	.846	.001
		$\bar{C}_p$ (SIDE A)	.845	

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.945	1.33	.843	-.002
2	.945	1.32	.846	.001
3	.942	1.32	.845	0.0
		$\bar{C}_p$ (SIDE B)	.845	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 1DATE: 26 APR 54CALIBRATED BY: T. BELANGER

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.208	.305	.826	-.005
2	.210	.305	.830	-.001
3	.212	.302	.838	.007
			$\bar{C}_p$ (SIDE A)	.831

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.505	.720	.838	.004
2	.495	.723	.827	-.007
3	.505	.720	.838	.004
			$\bar{C}_p$ (SIDE B)	.834

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2.9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 2 DATE: 25 APR 84
 CALIBRATED BY: T. Belonger

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.960	1.37	.837	.007
2	.945	1.40	.822	-.008
3	.950	1.38	.830	0.0
			$\bar{C}_p$ (SIDE A)	.830

RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1				
2				
3				
			$\bar{C}_p$ (SIDE B)	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 2 DATE: 19 APR 84
 CALIBRATED BY: T. BELANGER

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	0.195	0.300	.806	.005
2	0.195	0.305	.800	-.001
3	0.190	0.300	.796	-.005
		$\bar{C}_p$ (SIDE A)	.801	

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.490	0.722	.824	-.001
2	.490	0.720	.825	0.0
3	.492	0.720	.827	.002
		$\bar{C}_p$ (SIDE B)	.825	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 2DATE: 19 APR 84CALIBRATED BY: T. BELANGER

<u>3/8" TUBE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	0.481	0.745	.804	.001
2	0.475	0.735	.804	.001
3	0.475	0.740	.801	-.002
		$\bar{C}_p$ (SIDE A)	.803	

<u>1/8" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	0.190	0.300	.796	-.001
2	0.190	0.300	.796	-.001
3	0.192	0.300	.800	.003
		$\bar{C}_p$ (SIDE B)	.797	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2.9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 2DATE: 19 APR 84CALIBRATED BY: T. B. ELKNER

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	0.970	1.50	.804	.005
2	0.990	1.55	.799	0.0
3	0.975	1.55	.793	-.006
		$\bar{C}_p$ (SIDE A)	.799	

<u>3/8" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	0.960	1.45	.814	.005
2	0.975	1.50	.806	-.003
3	0.975	1.50	.806	-.003
		$\bar{C}_p$ (SIDE B)	.809	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 2DATE: 19 APR 84CALIBRATED BY: T. BELLAH GER

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION: $C_p(s) - \bar{C}_p(A)$
1	0.210	0.330	.798	-.003
2	0.210	0.330	.798	-.003
3	0.212	0.325	.808	.007
		$\bar{C}_p$ (SIDE A)	.801	

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION: $C_p(s) - \bar{C}_p(B)$
1	0.515	0.800	.802	-.002
2	0.525	0.805	.808	.004
3	0.515	0.800	.802	-.002
		$\bar{C}_p$ (SIDE B)	.804	

$$\text{AVERAGE DEVIATION} = \sigma \text{ (A OR B)} = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p \text{ (SIDE A)} - \bar{C}_p \text{ (SIDE B)}| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 5 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.950	1.37	.833	.001
2	.945	1.35	.837	.005
3	.940	1.38	.825	-.007
		$\bar{C}_p$ (SIDE A)	.832	

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.540	.800	.822	.001
2	.542	.812	.817	-.004
3	.545	.800	.825	.004
		$\bar{C}_p$ (SIDE B)	.821	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 5 DATE: 27 APR 84
 CALIBRATED BY: T. DELANGE

<u>1/4" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.182	.270	.821	-.001
2	.182	.270	.821	-.001
3	.183	.270	.823	.001
		$\bar{C}_p$ (SIDE A)	.822	

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.181	.270	.819	0.0
2	.182	.270	.821	.002
3	.180	.270	.816	-.003
		$\bar{C}_p$ (SIDE B)	.819	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 5 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.491	.730	.820	.001
2	.490	.730	.819	0.0
3	.490	.730	.819	0.0
$\bar{C}_p$ (SIDE A)			.819	

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.952	1.40	.823	.003
2	.955	1.43	.817	-.005
3	.950	1.40	.824	.002
$\bar{C}_p$ (SIDE B)			.822	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2.9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 5 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.960	1.42	.822	-.002
2	.960	1.38	.834	.010
3	.955	1.43	.817	-.007
		$\bar{C}_p$ (SIDE A)	.824	

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.520	.780	.816	-.003
2	.522	.775	.821	0
3	.530	.775	.827	.006
		$\bar{C}_p$ (SIDE B)	.821	

$$\text{AVERAGE DEVIATION} = a(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: EDATE: 27 APR 84CALIBRATED BY: T. BELANGER

<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.210	.310	.823	0
2	.210	.310	.823	0
3	.210	.310	.823	0
			$\bar{C}_p$ (SIDE A)	.823

RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1				
2				
3				
			$\bar{C}_p$ (SIDE B)	

$$\text{AVERAGE DEVIATION} = \sigma \text{ (A OR B)} = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p \text{ (A OR B)}|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p \text{ (SIDE A)} - \bar{C}_p \text{ (SIDE B)}| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 8 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.980	1.32	.862	.003
2	.980	1.32	.862	.003
3	.985	1.35	.854	-.005
		$\bar{C}_p$ (SIDE A)	.859	

<u>1/4" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.490	.705	.834	.002
2	.490	.702	.835	.003
3	.482	.705	.827	-.005
		$\bar{C}_p$ (SIDE B)	.832	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 8 DATE: 27 APR 94
 CALIBRATED BY: T. BELANGER

<u>1/4" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.210	.310	.823	.004
2	.212	.312	.812	-.007
3	.210	.310	.823	.004
			$\bar{C}_p$ (SIDE A)	.819

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.210	.320	.810	0.0
2	.210	.320	.810	0.0
3	.210	.320	.810	0.0
			$\bar{C}_p$ (SIDE B)	.810

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2.9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 8 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.515	.785	.810	-.003
2	.518	.782	.814	.001
3	.520	.780	.816	.003
		$\bar{C}_p$ (SIDE A)	.813	

<u>3/8" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.985	1.38	.845	.006
2	.975	1.40	.835	-.004
3	.983	1.40	.839	-.001
		$\bar{C}_p$ (SIDE B)	.839	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 8DATE: 27 APR 84CALIBRATED BY: T. BELANGER

<u>1/2" NOZZLE</u>				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.985	1.38	.845	.004
2	.987	1.42	.834	-.007
3	.980	1.38	.843	.002
		$\bar{C}_p$ (SIDE A)	.841	

RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	.528	.775	.825	0.0
2	.530	.780	.824	-.001
3	.530	.778	.825	0.0
		$\bar{C}_p$ (SIDE B)	.825	

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

PITOT TUBE IDENTIFICATION NUMBER: 8 DATE: 27 APR 84
 CALIBRATED BY: T. BELANGER


<u>1/2" NOZZLE</u>				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	.205	.305	.820	.005
2	.200	.305	.810	-.005
3	.203	.305	.816	.001
		$\bar{C}_p$ (SIDE A)	.815	

RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	$\Delta p(s)$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1				
2				
3				
		$\bar{C}_p$ (SIDE B)		

$$\text{AVERAGE DEVIATION} = \sigma(A \text{ OR } B) = \frac{\sum_{i=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)|}{3} \leftarrow \text{MUST BE } \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \leftarrow \text{MUST BE } \leq 0.01$$

Figure 2.9. Pitot tube calibration data.



PUSH PULL HOODS

Exhaust Hood

Quantity of air exhausted,
 $Q_2 = 100 \text{ to } 150 \text{ cfm /sq. ft. of tank area, depending on temperature of liquid, cross drafts, agitation, etc.}$

Hood height should be,
 $H = D \times \tan. 10^\circ$
 $= 0.18D$

Pressure Slot

Quantity of air supplied,

$$Q_1 = \frac{1}{D \times E} \times Q_2$$

where; D = length of throw, feet
 E = entrainment factor.

Throw length, D , feet	Entrainment factor, E
0 - 8	2.0
8 - 16	1.4
16 - 24	1.0
over 24	0.7

Slot width W should be designed for a velocity of 1000 to 2000 fpm.

Design such systems so they can be easily modified or adjusted to obtain desired results.


AMERICAN CONFERENCE OF
GOVERNMENTAL INDUSTRIAL HYGIENISTS

HOOD DESIGN DATA

DATE

1-64

Fig. 4-17



$$Q = 50LW$$

Slot velocity = 1000 fpm maximum

Entry loss = $1.78 \text{ slot VP} + 0.25 \text{ duct VP}$

Duct velocity = 2500-3000 fpm

- Also provide:
1. Separate flue for combustion products if direct-fired unit.
 2. For cleaning operation, an air-line respirator is necessary.
 3. For pit units, the pit should be mechanically ventilated.
 4. For further safe guards, see VS-501.
- NOTE: Provide downdraft grille for parts that cannot be removed dry; $Q = 50 \text{ cfm /sq ft grille area}$.

AMERICAN CONFERENCE OF
GOVERNMENTAL INDUSTRIAL HYGIENISTS

SOLVENT DEGREASING TANKS

DATE

1-78

VS-501

Solvent vapor degreasing refers to boiling liquid cleaning systems utilizing trichloroethylene, perchloroethylene, methylene chloride, freons (R) or other halogenated hydrocarbons. Cleaning action is accomplished by the condensation of the solvent vapors in contact with the work surface producing a continuous liquid rinsing action. Cleaning ceases when the temperature of the work reaches the temperature of the surrounding solvent vapors. Since halogenated hydrocarbons are somewhat similar in their physical, chemical and toxic characteristics, the following safeguards should be provided to prevent the creation of a health or life hazard:

1. Vapor degreasing tanks should be equipped with a condenser or vapor level thermostat to keep the vapor level below the top edge of the tank by a distance equal to one-half the tank width or 36 inches, whichever is shorter.
2. Where water type condensers are used, inlet water temperatures should not be less than 80 F (27 C) and the outlet temperature should not exceed 110 F (43 C).
3. Degreasers should be equipped with a boiling liquid thermostat to regulate the rate of vapor generation, and with a safety control at an appropriate height above the vapor line to prevent the escape of solvent in case of a malfunction.
4. Tanks or machines of more than 4 square feet of vapor area should be equipped with suitable gasketed cleanout or sludge doors, located near the bottom, to facilitate cleaning.
5. Work should be placed in and removed slowly from the degreaser, at a rate no greater than 11 feet/minute (0.055 m/s), to prevent sudden disturbances of the vapor level.
6. CARE MUST BE TAKEN TO PREVENT DIRECT SOLVENT CARRYOUT DUE TO THE SHAPE OF THE PART. Maximum rated workloads as determined by the rate of heat transfer (surface area and specific heat) should not be exceeded.
7. Special precautions should be taken where natural gas or other open flames are used to heat the solvent to prevent vapors* from entering the combustion air supply.
8. Heating elements should be designed and maintained so that their surface temperature will not cause the solvent or mixture to breakdown* or produce excessive vapors.
9. Degreasers should be located in such a manner that vapors* will not reach or be drawn into atmospheres used for gas or electric arc welding, high temperature heat treating, combustion air or open electric motors.
10. Whenever spray or other mechanical means are used to disperse solvent liquids, sufficient enclosure or baffling should be provided to prevent direct release of airborne vapor above the top of the tank.
11. An emergency quick-drenching facility should be located in near proximity to the degreaser for use in the event of accidental eye contact with the degreasing liquid.
 - Electric arcs, open flames and hot surfaces will thermally decompose halogenated hydrocarbons to toxic and corrosive substances (such as hydrochloric and/or hydrofluoric acid). Under some circumstances, phosgene may be formed.

AMERICAN CONFERENCE OF
GOVERNMENTAL INDUSTRIAL HYGIENISTS

SOLVENT VAPOR DEGREASING

DATE

1-78

VS-501.1

APPENDIX H
VENTILATION DATA

RECOMMENDED TANK EXHAUST FLOW/RATES

Scrubber: #101

REW 9/20/84

Tanks Exhausted		Haze Cat	Recommended Gfm / $\square'$	Tank Surface Area $\square'$	Calc Cfm/Tank
#	Type				
8	PP	C-1	150	31.5	4725
9	PP	C-2	150	31.5	4725
18	PP	A-3	150	31.5	4725
23	PP	C-2	150	31.5	4725
25	Zs Lot	C-2	110	24	2640
26	Zs Lot	C-1	150	24	3600
					=
					Total = 25,140

Minimum Exhaust Required to meet Recommended Tank
Exhaust Volumes: 25140 cfm

Total Exhaust by Scrubbers 101-106 = 182975 cfm

Measured Q ($\frac{GPM}{(1000)}$)	Scrubber #	Recommended Min CFM	Quant. of Tanks/PP	
5293	101	25140	6/4	110222 cfm
2735	102	22785	4/1	$\approx 58\%$ supplied
55355	103	37625	4/0	
22184	104	23625	5/5	
22357	105	28350	6/6	
52010	106	45450	8/2	
		182975	33/18	

Scrubber: #102

Tanks Exhausted	Hose Cat	Recommended Cfm / D'	Tank Surface Area D'	Calc. Cfm/Tank
4 Lot	C-2	110	96	10560
33 PP	B-2	150	31.5	4725
40 None	NA	—	31.5	—
* 48 2s Lot	D-2	100	25	2500
50 2s Lot	C-1	200	25	5000
			Total =	2271

Minimum Exhaust Required to meet Recommended Tank Exhaust Volumes: 22785 cfm

- * Is not needed could be blanked off if form requires greater capacity.

Scrubber: #103

Tanks Exhausted # Type	Hose Cat	Recommended Cfm / □'	Tank Surface Area □'	Calc. Cfm/Tank
41 2s Lot	A-1	250	56	14000
42 2s Lot	A-1	250	31.5	7875
43 2s Lot	A-1	250	31.5	7875
44 2s Lot	A-1	250	31.5	7875
			Total =	27,625

Minimum Exhaust Required to meet Recommended Tank Exhaust Volumes: 37625 cfm

Scrubber: #104

Tanks Exhausted		Haze Cat	Recommended Cfm / $\square'$	Tank Surface Area $\square'$	Calc. Cfm/Tank
#	Type				
3	PP	A-2	150	31.5	4725
5	PP	B-2	150	31.5	4725
6	PP	A-2	150	31.5	4725
14	PP	A-2	150	31.5	4725
15	PP	A-3	150	31.5	4725
				total	23,625

Minimum Exhaust Required to meet Recommended Tank
Exhaust Volumes: 23625 cfm

Scrubber: #105

Tanks Exhausted		Haze Cat	Recommended Cfm / $\square'$	Tank Surface Area $\square'$	Cater Cfm/Tank
1	PP	C-3	150	31.5	4725
11	PP	C-3	150	31.5	4725
20	PP	A-2	150	31.5	4725
* 21	PP	(D-4) C-2	150	31.5	4725
22	PP	C-2	150	31.5	4725
29	PP	(D-4) C-2	150	31.5	4725
					=
					Total = 28,350

Minimum Exhaust Required to meet Recommended Tank
Exhaust Volumes: 28350 cfm

* Is not needed, hood could be blanked off if
fan requires increased capacity.

Scrubber: #106

Tanks Exhausted		Horiz Cat	Recommended Cfm / D'	Tank Surface Area D'	Calc. Cfm/Tank
#	Type				
16	PP	A-2	150	31.5	4725
19	PP	C-2	150	31.5	4725
28A	2s Lat	A-2	250	24	6000
28B	2s Lat	A-2	250	24	6000
35	2s Lat	A-2	250	24	6000
36	2s Lat	A-2	250	24	6000
45	2s Lat	A-2	250	35	6000
47	2s Lat	A-2	250	25	6000

Total = 45450

Minimum Exhaust Required to meet Recommended Tank
Exhaust Volumes: 45450 cfm

Pitot Traverse Measurements (See Figure 8 for Location Matchup)

Location		1		2		3		4		REL.
		VP	Vel.	VP	Vel.	VP	Vel.	VP	Vel.	
1		.02	566	0	0	.20	1791	(20 pt traverse) .16	1602	
2		.02	566	0	0	.20	1791	.14	1499	
3		.03	694	0	0	.20	1791	.12	1397	
4		.02	566	0	0	.20	1791	.17	1651	
5		.03	694	0	0	.18	1699	.21	1835	
6		.04	801	.02	566	.21	1835	.14	1499	
7		.04	801	.02	566	.14	1499	.20	1791	
8		.05	896	.02	566	.10	1206	.16	1602	
9		.05	896	.02	566	.08	1133	.08	1133	
10		.05	896	.01	401	.18	1699	0	0	
11		.04	801	.04	801	.14	1499	.19	1746	
12		.05	896	.09	1202	.10	1266	.21	1835	
13		.05	896	.07	1060	.02	566	.21	1835	
14		.05	896	.05	896	.01	401	.23	1921	
15		.04	801	.07	1060	.08	1133	.24	1962	
16		.04	801	.13	1444	.05	896	0	0	
17		.04	801	.17	1651	.01	401	0	0	
18		.05	896	.14	1499	0	0	0	0	
19		.05	896	.14	1499	0	0	0	0	
20		.05	896	.16	1602	.03	694	0	0	
21		.04	801	.19	1746	0	0	0	0	
22		.04	801	.24	1962	0	0	0	0	
23		.05	896	.22	1879	0	0	0	0	
24		.05	896	.23	1921	0	0	0	0	
25		.04	801	.24	1962	0	0	0	0	
Average Velocity (fpm)		—								
Duct Cross-Sectional Area (ft ²)		—								
Calculated Flow Rate (cfm)		—								

Pitot Traverse Measurements
(See Figure 8 for Location Matchup)

Location		5		6		7 & 10		8	
Pt		VP	Vel	VP	Vel	VP	Vel	VP	Vel
1		.11	1328	.02	566	.06	981		
2		.15	1699	.02	566	.07	1060		
3		.21	1835	0	0	.11	1328		
4		.26	2042	0	0	.12	1387		
5		.26	2042	.02	566	.16	1602		
6		.15	1551	.05	896	.06	981		
7		.15	1551	.02	566	.07	1060		
8		.14	1499	.03	694	.12	1387		
9		.20	1791	.02	566	.14	1499		
10		.22	1879	.02	566	.15	1551		
11		.11	1328	.14	1499	.08	1133		
12		.09	1202	.09	1202	.09	1202		
13		.12	1387	.08	1133	.10	1266		
14		.03	694	.06	981	.12	1387		
15		.08	1133	.12	1387	.14	1499		
16		.02	566	.20	1791	.10	1266		
17		0	0	.18	1699	.05	1133		
18		0	0	.17	1651	.09	1202		
19		0	0	.16	1602	.11	1328		
20		.05	896	.17	1651	.10	1266		
21		0	0	.20	1791	.12	1387		
22		0	0	.24	1962	.09	1202		
23		0	0	.24	1962	.08	1133		
24		0	0	.24	1962	.07	1060		
25		0	0	.25	2003	.07	1060		
26						.10	1266		
27						.10	1266		
28						.09	1202		
29						.08	1133		
30						.06	981		
Average Velocity (fpm)		—							
Duct Cross-Sectional Area (ft ²)		—							
Calculated Flow Rate (cfm)		—							

Pitot Traverse Measurements
(See Figure 8 for Location Match-ups)

Location		9		7 E 10		11		12	
Pt		VP	Vel	VP	Vel	VP	Vel	VP	Vel
				(see 7 E 10 previous page)					
Average Velocity (fpm)									
Duct									

H-9

Pitot Traverse Measurements (See Figure 8 for Location Matchups)

Location		13		13 & 14		15 & 16			
Pt		VP	Vel	VP	Vel	VP	Vel		
1		.05	896	.03	694	.01	401		
2		.05	896	0	0	0	0		
3		.03	694	0	0	0	0		
4		.03	694	.20	1791	0	0		
5		.03	694	.32	2260	.01	401		
6		.05	896	0	0	0	0		
7		.05	896	0	0	0	0		
8		.03	694	.01	401	0	0		
9		.02	566	0	0	0	0		
10		.03	694	0	0	0	0		
11		.07	1060	.10	1266	.19	1746		
12		.05	896	.04	801	.18	1699		
13		.04	801	0	0	.38	2469		
14		.04	801	.12	1387	.47	2746		
15		.04	801	.90	3800	.32	2266		
16		.08	1133	.38	2469	.18	1699		
17		.07	1060	.12	1387	.20	1791		
18		.06	981	.10	1266	.18	1699		
19		.06	981	0	0	.17	1651		
20		.06	981	.15	1551	.21	1835		
21		.08	1133	.01	401	.14	1499		
22		.09	1201	.02	566	.15	1551		
23		.07	1060	.02	566	.01	401		
24		.03	1133	.02	566	0	0		
25		.06	981	0	0	.08	1133		

Average Velocity (fpm) —

Duct Cross-Sectional Area (ft²) —

Calculated Flow Rate (cfm) —

APPENDIX I
PHOTOGRAPHS OF IMPACTOR FILTER STAGES


CHROME PLATING SCRUBBER #103

BLDG. 210 LBNSY


24 MAY 84

RUN 1

INLET IMPACTOR STAGES -



OUTLET IMPACTOR STAGES -




CHROME PLATING SCRUBBER # 103

BLDG. 210 LBNSY


24 MAY 84

RUN 2

INLET IMPACTOR STAGES -



OUTLET IMPACTOR STAGES -




HCI SCRUBBER #104


BLDG. 210 LBNSY

26 MAY 84

INLET IMPACTOR STAGES -




UNDERSIDE OF IMPACTOR FILTER SUPPORT PLATES (NOTE PATTERNS OF COLLECTED AEROSOL)




CHROMATE SCRUBBER #106

BLDG. 210 LBNSY 30 MAY 84

INLET IMPACTOR STAGES -



OUTLET IMPACTOR STAGES -



RESUME

THOMAS BELANGER

1983, June to December

SET Engineer Trainee

Engineering Intern
Southern California Gas
Bakersfield, California

1984, January to June

Engineering Trainee
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME

PETER K. FANNING

SET Engineer

1979

B.S. Physics
Bridgewater State College
Bridgewater, Mass.

1982

M.S. Mechanical Engineering
Worcester Polytechnic Institute
Worcester, Mass.

1982-1983

Junior Field Engineer
Dresser--Atlas (International)
Houston, Texas

1983 to Present

Mechanical Engineer
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME

DARROW KIRKPATRICK

SET Engineer

1982

B.S. Civil Engineering
University of Virginia

1977-1980

United States Environmental Protection
Agency
Water Quality Standards Division
Region IV
Atlanta, Georgia

1982-1984

Civil Engineer
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME

WILLIAM E. POWERS

SET Engineer

1978

B.S. Mechanical Engineering
Duke University
Durham, N.C.

1981

MPH Environmental Science & Engineering
University of North Carolina
Chapel Hill, N.C.

1980-81

General Engineer
Health Effects Research Laboratory
National Environmental Research Center
Environmental Protection Agency
Research Triangle Park, N.C.

1982 to Present

Mechanical Engineer
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME

TIMOTHY D. QUARLES

SET Engineer

1976

B.S. Environmental Engineering
Vanderbilt University
Nashville, Tenn.

1977

Source Test Engineer
Air Pollution Technology, Inc.
San Diego, California

1978

Air Pollution Instrument Technician
San Diego County APCD
San Diego, California

1979-1981

M.S. Chemical Engineering
Washington State
Pullman, Washington

1981-1983

Environmental Engineer
Wisconsin Bureau of Air Management
Madison, Wisconsin

1983

Chemical Engineer
NCEL
Port Hueneme, California

1983-Present

Chemical Engineer
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME

SUSAN J. SUZUKI

SET Engineer

1982

B.S. Environmental Engineering
California State University
San Luis Obispo, California

1982-1984

Mechanical/Environmental Engineer
Naval Air Rework Facility
Alameda, California

1984-Present

Mechanical Engineer
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME .

CHARLES K. YEE

SET Engineer

1963

B.S. Chemical Engineering
Auburn University
Auburn, Alabama

1969

M.S. Environmental Systems Engineering
Clemson University
Clemson, S.C.

1965-72

Public Health Engineer: Air Pollution
Control Commission
State Health Department
Montgomery, Alabama

1972 to Present

Chemical Engineer
Coal/Air Department
Naval Energy & Environmental Support
Activity
Port Hueneme, California

RESUME

ROBERT E. WOOD

1980

B.S. Environmental Engineering
California State University
San Luis Obispo, California

1980-1982

General Engineer
Energy Department
Naval Energy and Environmental Support
Activity

1982-1984

Mechanical Engineer
NAVOSH Department
Naval Energy and Environmental Support
Activity