

NO₂/SO₂ AIWG:
Analysis of intermittent emissions &
cumulative analyses

Erik Snyder & James Thurman
2012 Regional/State/Local Modelers
Workshop
May 1st, 2012

AIWG summary

1. Started Spring 2011 with focus on single source modeling of NO₂ and SO₂ facilities of most interest to states
 2. Initial report out at 2011 Regional/State/Local Modelers Workshop in Atlanta
 3. Post-workshop QA of results and development of cumulative scenarios in fall 2011
 4. Additional report out at 10th Modeling Conference in March 2012
 5. Single source modeling draft summary and results available on SCRAM
 - Contains full set of charts/maps for each modeled source
- http://www.epa.gov/ttn/scram/10thmodconf/review_material/AIWG_Summary_v2.pdf

Cumulative Analyses

- AIWG created eight hypothetical case studies based on the single source examples
 - Three facilities per study with eight scenarios
 - Two modeling scenarios per facility
- States also provided actual cases
- Caveats: No background concentration added on some scenarios, limited cumulative analysis. Modeling conducted to inform, some model set-ups may not be acceptable in a regulatory analysis without technical support.

Cumulative analyses: case studies

Pollutant(s)	Facility 1	Facility 2	Facility 3
NO ₂	Natural gas turbine	Materials recycler	Fuel oil turbine
NO ₂	Steel Mill	Biomass facility	Fuel oil turbine
NO ₂	Ethanol plant	Natural gas processing facility	Refinery
NO ₂ , SO ₂	Coal EGU	Cement kiln	Refinery
SO ₂	Coal EGU	Cement kiln	Pulp & paper
SO ₂	Flare	Landfill gas turbine	Pulp & paper
SO ₂	Ethanol plant	Fuel oil turbine	Asphalt plant


Steel mill, fuel oil turbine, and biomass facility (NO₂)

- Modeler: Doris Jung (CO)
- Modeled with OLM and PVMRM
- Emissions
 - Steel Mill: 711 tpy
 - Fuel oil turbine: 1,190 tpy
 - Biomass facility: 240 tpy


Modeling Scenarios

Modeling scenario	Steel mill	Fuel oil turbine	Biomass facility
1	Baseline	Baseline	Baseline
2	Baseline	Baseline	Increased stack height
3	Baseline	Increased stack height	Baseline
4	Baseline	Increased stack height	Increased stack height
5	Increased stack height to 45 m for stacks > 1 g/s	Baseline	Baseline
6	Increased stack height to 45 m for stacks > 1 g/s	Baseline	Increased stack height
7	Increased stack height to 45 m for stacks > 1 g/s	Increased stack height	Baseline
8	Increased stack height to 45 m for stacks > 1 g/s	Increased stack height	Increased stack height

Fuel oil turbine, steel mill, biomass facility: NO₂




Maximum design values




Scenario 1
OLM
Max DV: 212 $\mu\text{g}/\text{m}^3$

Legend



Scenario 1
PVMRM
Max DV: 260 $\mu\text{g}/\text{m}^3$


Legend



0 250 500 1,000 1,500 2,000 Meters


Scenario 5
OLM
Max DV: 168 $\mu\text{g}/\text{m}^3$

Legend



Scenario 5
PVMRM
Max DV: 235 $\mu\text{g}/\text{m}^3$

Legend



Findings

- Use of PVMRM leads to higher maximum DV versus OLM
- All design values drop once steel mill stack heights increase
- Source that is giving maximum shifted between source on the SW corner for OLM and Northern edge for PVMRM. May investigate further


Ethanol plant, refinery, natural gas plant (NO₂)

- Modeler: Jennifer Krzak (IA)
- Comparisons between two different surface stations and two 5-year periods
 - Moline, Waterloo; 2000-2004, 2005-2009
- Receptor grid centered on ethanol plant
- Background of 71.5 µg/m³ for Moline runs
- Emissions
 - Ethanol plant: 1,180 tpy
 - Refinery: 8,770 tpy
 - Natural gas plant: 330 tpy


Modeling Scenarios

Modeling scenario	Ethanol plant	Refinery	Natural gas plant
1	Baseline	Baseline	Baseline
2	Baseline	Baseline	Increased stack height
3	Baseline	Increased stack height	Baseline
4	Baseline	Increased stack height	Increased stack height
5	Increased stack height for ETH0004	Baseline	Baseline
6	Increased stack height for ETH0004	Baseline	Increased stack height
7	Increased stack height for ETH0004	Increased stack height	Baseline
8	Increased stack height for ETH0004	Increased stack height	Increased stack height

Ethanol plant, refinery, natural gas processing plant: NO₂



Waterloo maximum NO₂ design values



Legend

- 35 - 50
- 51 - 100
- 101 - 150
- 151 - 188
- 189 - 400
- 401 - 600
- 601 - 800
- 801 - 1000
- 1001 - 5000
- 5001 - 10929


Waterloo 2000-2004
NO₂ design values

Refinery



0 1,250 2,500 5,000 7,500 10,000 Meters

Waterloo maximum NO₂ design values: refinery receptors removed




Legend


- 35 - 50
- 51 - 100
- 101 - 150
- 151 - 188
- 189 - 400
- 401 - 600
- 601 - 800
- 801 - 1000
- 1001 - 5000
- 5001 - 10928

Waterloo 2000-2004
NO₂ design values
Refinery receptors
removed


0 1,250 2,500 5,000 7,500 10,000 Meters



Moline maximum NO₂ design values



Moline maximum NO₂ design values: refinery receptors removed



Findings

- Maximum design values driven by refinery
 - Overall maximum on refinery property
- Removing refinery on-property receptors results in lower design values
 - Still exceedances (driven by ethanol plant) but lower


Ethanol plant, fuel oil turbine, and asphalt plant (SO₂)

- Modeler: Jennifer Krzak (IA)
- Comparisons between two different surface stations and two 5-year periods
- Receptor grid centered on ethanol plant
- Emissions
 - Ethanol plant: 890 tpy
 - Fuel oil turbine: 417 tpy
 - Asphalt plant: 13 tpy


Modeling Scenarios

Modeling scenario	Ethanol plant	Fuel oil turbine	Asphalt plant
1	Baseline	Baseline	Baseline
2	Baseline	Baseline	Increased stack height
3	Baseline	Increased stack height	Baseline
4	Baseline	Increased stack height	Increased stack height
5	Increased stack height for ETH0004	Baseline	Baseline
6	Increased stack height for ETH0004	Baseline	Increased stack height
7	Increased stack height for ETH0004	Increased stack height	Baseline
8	Increased stack height for ETH0004	Increased stack height	Increased stack height


Ethanol plant, fuel oil turbine, asphalt plant: SO₂



Moline maximum SO₂ design values



Waterloo maximum SO₂ design values



Findings



- No NAAQS exceedances
- Maximum design values driven by ethanol plant
- Control strategies have little effect
 - Other sources within facilities driving design values

Real World - Actual cumulative modeling

- MN: ceiling tile manufacturer
 - OLM
 - Hourly background
- TN: explosives component manufacturing
 - OLM
 - Hourly background
- WI: coal facility and biomass facility
 - Compared four meteorological sites and OLM vs. PVMRM
 - Compared urban vs. rural for one site
 - Regional background of $48.9 \mu\text{g}/\text{m}^3$
- All cases are for NO_2

MN NO₂ PSD

Legend




TN: NO₂ design values

Legend


- 188.0 - 212.6
- 212.7 - 246.5
- 246.6 - 287.9
- 288.0 - 332.2
- 332.3 - 468.2

Source of interest


0 2 4 8 12 16 Kilometers



TN: Maximum NO₂ design value contribution analysis



WI: Maximum NO₂ design value contribution analysis



MKE; PVMRM

Max DV: 266.2 $\mu\text{g}/\text{m}^3$


Legend

- 62.5 - 70.5
- 70.6 - 73.6
- 73.7 - 76.6
- 76.7 - 80.6
- 80.7 - 90.1
- 90.2 - 107.6
- 107.7 - 131.6
- 131.7 - 188.0
- 188.1 - 205.2
- 205.3 - 266.2


Coal facility

Biomass facility

0 0.5 1 2 3 4 Kilometers





Legend



MKE; PVMRM

Max DV: 266.2 $\mu\text{g}/\text{m}^3$




AIWG Scenarios - Intermittent emissions analyses


- March 1, 2011 NO₂ memo discusses the emissions of intermittent type sources (emergency generators)
- Several of the single source modeling cases involved sources that could be intermittent in nature
 - Ethanol plant, Coal EGU, biomass facility
- Sensitivity runs for informational purposes only

Coal EGU: NO₂ intermittent emissions

- Coal fired EGU NO₂ maximum design values changed very little among scenarios
- Contribution analyses showed that C0003 (emergency diesel generator) and C0005 (diesel fire water booster pump) are the dominant contributors to maximum DV
 - C0003 and C0004 (fire water pump) were not to exceed 500 hours/year in proposed facility
 - C0003:
 - Emissions 3 g/s (104 tpy)
 - height=6 m
 - C0004:
 - Emissions 0.3 g/s (10 tpy)
 - Height=5 m
 - C0005:
 - Emissions 0.3 g/s (10 tpy)
 - Height=5 m

Coal EGU (OAQPS): NO₂






Coal EGU: NO₂ intermittent emissions

- Modeled sources C0003-C0005 with following emission limits
 - 1 hour/day (noon-1:00 PM)
 - 6:00 AM – 6:00 PM (daytime operations)
- Modeled with baseline stack parameters & emissions
 - Compared NO2STACK ratio of 0.05 and 0.1


Source contributions to maximum design values




Ethanol plant: NO₂ intermittent emissions

- Ethanol plant maximum design values changed very little among scenarios
- Contribution analyses showed that C0003 (emergency diesel generator) is the dominant contributor to maximum DV
 - C0003 was not to exceed 500 hours/year in proposed facility
 - C0003 emissions 1.2 g/s, release height 2 m

Ethanol Plant (Moline): NO₂




Ethanol plant sources with 50 m fence line (blue) and 300 m fence line (red)




Ethanol plant: NO₂ intermittent emissions

- Modeled C0003 with following emission limits
 - 1 hour/day (noon-1:00 PM)
 - 6:00 AM – 6:00 PM (daytime operations)
- Modeled with baseline stack parameters & emissions
 - Compared NO2STACK ratio of 0.05, 0.1, 0.25, and 0.5
 - Fenceline 50 m and 300 m

Source contributions to maximum design values (50 m FL)




Source contributions to maximum design values (300 m FL)




Ethanol plant: SO₂

- Applied same methodology to SO₂ for C0003
- C0003 SO₂ emissions 0.1 g/s h=2 m

Ethanol Plant (Moline): SO₂



Source contributions to maximum design values (50 m FL)



Ethanol plant findings

- For NO₂, restricting C0003 emissions lowers maximum design values
- There are still exceedances at 50 m fenceline, increasing distance to 300 m lowers design values below NAAQS
- For SO₂, restricting C0003 at 50 m does not change maximum design values
 - C0001 driving max DV
 - C0003 SO₂ emissions much lower than C0003 NO₂ emissions
 - No NAAQS exceedances for SO₂ at 300 m fenceline, did not apply C0003 restrictions.

Intermittent emissions-summary

- In some cases, limiting intermittent type emissions to certain hours could mitigate such sources' contributions to NAAQS violations, especially where such sources could be driving design values

Acknowledgements

- We want to thank all the members of the Work Group for their time and efforts
- We hope this work proves beneficial and that members came away with information that will help in future applications

Next steps

- Continue AIWG process, looking at source groupings, cumulative, adding background (different tier approach), evaluate guidance issues and sensitivity, etc.
- Loop in more state experiences with permit modeling
- Finalize Draft AIWG report as needed.

Discussion/Input

- Would appreciate input on the types of sources that are a concern based on stakeholder initial investigations.
- Issues/items we should investigate?
- State modeling experiences?